

DOCKETED	
Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	264959
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q2 2025 - Part 2s
Description:	N/A
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public Agency
Submission Date:	7/22/2025 8:58:42 AM
Docketed Date:	7/22/2025

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
04/01/2025 00:00	0.7	14.3	0.0	0.0	0.0
04/01/2025 01:00	0.7	14.3	0.0	0.0	0.0
04/01/2025 02:00	0.7	14.3	0.0	0.0	0.0
04/01/2025 03:00	0.8	14.3	0.0	0.0	0.0
04/01/2025 04:00	0.9	14.2	0.0	0.0	0.0
04/01/2025 05:00	0.7	13.3	0.0	0.0	0.0
04/01/2025 06:00	0.3	12.4	0.0	0.0	0.0
04/01/2025 07:00	1.0	13.9	0.0	0.0	0.0
04/01/2025 08:00	1.0	13.9	0.0	0.0	0.0
04/01/2025 09:00	1.0	13.8	0.0	0.0	0.0
04/01/2025 10:00	0.9	13.7	0.0	0.0	0.0
04/01/2025 11:00	0.9	13.7	0.0	0.0	0.0
04/01/2025 12:00	0.9	14.0	0.0	0.0	0.0
04/01/2025 13:00	0.8	14.3	0.0	0.0	0.0
04/01/2025 14:00	0.7	14.3	0.0	0.0	0.0
04/01/2025 15:00	0.7	14.3	0.0	0.0	0.0
04/01/2025 16:00	0.7	14.3	0.0	0.0	0.0
04/01/2025 17:00	0.6	14.4	0.0	0.0	0.0
04/01/2025 18:00	0.7	14.3	0.0	0.0	0.0
04/01/2025 19:00	0.7	14.3	0.0	0.0	0.0
04/01/2025 20:00	0.7	14.3	0.0	0.0	0.0
04/01/2025 21:00	0.7	14.3	0.0	0.0	0.0
04/01/2025 22:00	0.7	14.3	0.0	0.0	0.0
04/01/2025 23:00	0.7	14.3	0.0	0.0	0.0
Average/Sum#:	0.8	14.1	0.0	0.0	0.0
Minimum:	0.3	12.4	0.0	0.0	0.0
Maximum:	1.0	14.4	0.0	0.0	0.0
%SI	0.00	0.00	100.00	100.00	100.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
04/02/2025 00:00	0.8	14.3	0.0	0.0	0.0
04/02/2025 01:00	0.8	14.2	0.0	0.0	0.0
04/02/2025 02:00	0.8	14.2	0.0	0.0	0.0
04/02/2025 03:00	0.9	14.2	0.0	0.0	0.0
04/02/2025 04:00	1.0	14.2	0.0	0.0	0.0
04/02/2025 05:00	0.6	12.8	0.0	0.0	0.0
04/02/2025 06:00	0.5	12.9	0.0	0.0	0.0
04/02/2025 07:00	1.1	14.1	0.0	0.0	0.0
04/02/2025 08:00	0.8	14.3	0.0	0.0	0.0
04/02/2025 09:00	0.7	14.4	0.0	0.0	0.0
04/02/2025 10:00	0.7	14.3	0.0	0.0	0.0
04/02/2025 11:00	0.7	14.3	0.0	0.0	0.0
04/02/2025 12:00	0.7	14.3	0.5	1.3	13.9
04/02/2025 13:00	0.7	14.3	0.6	1.5	14.5
04/02/2025 14:00	0.7	14.6	0.6	1.5	14.5
04/02/2025 15:00	0.7	14.6	0.6	1.4	14.9
04/02/2025 16:00	0.7	14.5	0.0	0.0	0.0
04/02/2025 17:00	0.7	14.5	0.0	0.0	0.0
04/02/2025 18:00	0.7	14.4	0.0	0.0	0.0
04/02/2025 19:00	0.7	14.4	0.0	0.0	0.0
04/02/2025 20:00	0.7	14.3	0.0	0.0	0.0
04/02/2025 21:00	0.7	14.3	0.0	0.0	0.0
04/02/2025 22:00	0.7	14.3	0.0	0.0	0.0
04/02/2025 23:00	0.8	14.3	0.0	0.0	0.0
Average/Sum#:	0.7	14.2	0.6	1.4	14.5
Minimum:	0.5	12.8	0.5	1.3	13.9
Maximum:	1.1	14.6	0.6	1.5	14.9
%SI	0.00	0.00	83.33	83.33	83.33

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
04/03/2025 00:00	0.8	14.3	0.0	0.0	0.0
04/03/2025 01:00	0.8	14.3	0.0	0.0	0.0
04/03/2025 02:00	0.8	14.3	0.0	0.0	0.0
04/03/2025 03:00	1.1	14.2	0.0	0.0	0.0
04/03/2025 04:00	0.7	13.4	0.0	0.0	0.0
04/03/2025 05:00	0.8	13.4	0.0	0.0	0.0
04/03/2025 06:00	1.1	13.9	0.0	0.0	0.0
04/03/2025 07:00	0.9	14.3	0.0	0.0	0.0
04/03/2025 08:00	0.8	14.3	0.0	0.0	0.0
04/03/2025 09:00	0.8	14.3	0.0	0.0	0.0
04/03/2025 10:00	0.8	14.3	0.0	0.0	0.0
04/03/2025 11:00	0.7	14.3	0.0	0.0	0.0
04/03/2025 12:00	0.7	14.4	0.0	0.0	0.0
04/03/2025 13:00	0.7	14.4	0.0	0.0	0.0
04/03/2025 14:00	0.7	14.4	0.0	0.0	0.0
04/03/2025 15:00	0.7	14.4	0.0	0.0	0.0
04/03/2025 16:00	0.7	14.4	0.0	0.0	0.0
04/03/2025 17:00	0.7	14.5	0.0	0.0	0.0
04/03/2025 18:00	0.7	14.4	0.0	0.0	0.0
04/03/2025 19:00	0.7	14.4	0.0	0.0	0.0
04/03/2025 20:00	0.8	14.4	0.0	0.0	0.0
04/03/2025 21:00	0.8	14.3	0.0	0.0	0.0
04/03/2025 22:00	0.7	14.4	0.0	0.0	0.0
04/03/2025 23:00	0.7	14.5	0.0	0.0	0.0
Average/Sum#:	0.8	14.3	0.0	0.0	0.0
Minimum:	0.7	13.4	0.0	0.0	0.0
Maximum:	1.1	14.5	0.0	0.0	0.0
%SI	0.00	0.00	100.00	100.00	100.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
04/04/2025 00:00	0.8	14.3	0.0	0.0	0.0
04/04/2025 01:00	0.8	14.3	0.0	0.0	0.0
04/04/2025 02:00	0.7	14.4	0.0	0.0	0.0
04/04/2025 03:00	0.8	14.4	0.0	0.0	0.0
04/04/2025 04:00	0.8	14.3	0.0	0.0	0.0
04/04/2025 05:00	0.7	14.3	0.0	0.0	0.0
04/04/2025 06:00	0.8	14.3	0.0	0.0	0.0
04/04/2025 07:00	0.8	14.3	0.0	0.0	0.0
04/04/2025 08:00	0.8	14.3	0.0	0.0	0.0
04/04/2025 09:00	0.8	14.3	0.0	0.0	0.0
04/04/2025 10:00	0.7	14.4	0.0	0.0	0.0
04/04/2025 11:00	0.7	14.4	0.0	0.0	0.0
04/04/2025 12:00	0.7	14.4	0.0	0.0	0.0
04/04/2025 13:00	0.7	14.4	0.0	0.0	0.0
04/04/2025 14:00	0.7	14.4	0.0	0.0	0.0
04/04/2025 15:00	0.7	14.4	0.0	0.0	0.0
04/04/2025 16:00	0.7	14.4	0.0	0.0	0.0
04/04/2025 17:00	0.7	14.5	0.0	0.0	0.0
04/04/2025 18:00	0.7	14.4	0.0	0.0	0.0
04/04/2025 19:00	0.7	14.4	0.0	0.0	0.0
04/04/2025 20:00	0.7	14.4	0.0	0.0	0.0
04/04/2025 21:00	0.7	14.4	0.0	0.0	0.0
04/04/2025 22:00	0.8	14.3	0.0	0.0	0.0
04/04/2025 23:00	0.8	14.4	0.0	0.0	0.0
Average/Sum#:	0.7	14.4	0.0	0.0	0.0
Minimum:	0.7	14.3	0.0	0.0	0.0
Maximum:	0.8	14.5	0.0	0.0	0.0
%SI	0.00	0.00	100.00	100.00	100.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
04/05/2025 00:00	0.9	14.3	0.0	0.0	0.0
04/05/2025 01:00	0.9	14.3	0.0	0.0	0.0
04/05/2025 02:00	1.0	14.3	0.0	0.0	0.0
04/05/2025 03:00	1.0	14.3	0.0	0.0	0.0
04/05/2025 04:00	0.9	14.4	0.0	0.0	0.0
04/05/2025 05:00	0.8	14.4	0.0	0.0	0.0
04/05/2025 06:00	0.7	14.3	0.0	0.0	0.0
04/05/2025 07:00	0.8	14.3	0.0	0.0	0.0
04/05/2025 08:00	0.8	14.3	0.0	0.0	0.0
04/05/2025 09:00	0.7	14.4	0.0	0.0	0.0
04/05/2025 10:00	0.7	14.4	0.0	0.0	0.0
04/05/2025 11:00	0.7	14.4	0.0	0.0	0.0
04/05/2025 12:00	0.7	14.4	0.0	0.0	0.0
04/05/2025 13:00	0.7	14.4	0.0	0.0	0.0
04/05/2025 14:00	0.7	14.4	0.0	0.0	0.0
04/05/2025 15:00	0.6	14.5	0.0	0.0	0.0
04/05/2025 16:00	0.6	14.5	0.0	0.0	0.0
04/05/2025 17:00	0.7	14.5	0.0	0.0	0.0
04/05/2025 18:00	0.7	14.5	0.0	0.0	0.0
04/05/2025 19:00	0.7	14.4	0.0	0.0	0.0
04/05/2025 20:00	0.7	14.4	0.0	0.0	0.0
04/05/2025 21:00	0.8	14.4	0.0	0.0	0.0
04/05/2025 22:00	0.8	14.3	0.0	0.0	0.0
04/05/2025 23:00	0.8	14.4	0.0	0.0	0.0
Average/Sum#:	0.8	14.4	0.0	0.0	0.0
Minimum:	0.6	14.3	0.0	0.0	0.0
Maximum:	1.0	14.5	0.0	0.0	0.0
%SI	0.00	0.00	100.00	100.00	100.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
04/06/2025 00:00	0.8	14.3	0.0	0.0	0.0
04/06/2025 01:00	0.8	14.3	0.0	0.0	0.0
04/06/2025 02:00	0.8	14.3	0.0	0.0	0.0
04/06/2025 03:00	0.9	14.3	0.0	0.0	0.0
04/06/2025 04:00	0.8	14.3	0.0	0.0	0.0
04/06/2025 05:00	0.8	14.3	0.0	0.0	0.0
04/06/2025 06:00	0.8	14.3	0.0	0.0	0.0
04/06/2025 07:00	0.8	14.3	0.0	0.0	0.0
04/06/2025 08:00	0.8	14.3	0.0	0.0	0.0
04/06/2025 09:00	0.8	14.4	0.0	0.0	0.0
04/06/2025 10:00	0.7	14.4	0.0	0.0	0.0
04/06/2025 11:00	0.7	14.4	0.0	0.0	0.0
04/06/2025 12:00	0.7	14.4	0.0	0.0	0.0
04/06/2025 13:00	0.7	14.4	0.0	0.0	0.0
04/06/2025 14:00	0.7	14.4	0.0	0.0	0.0
04/06/2025 15:00	0.7	14.4	0.0	0.0	0.0
04/06/2025 16:00	0.7	14.4	0.0	0.0	0.0
04/06/2025 17:00	0.7	14.5	0.0	0.0	0.0
04/06/2025 18:00	0.7	14.4	0.0	0.0	0.0
04/06/2025 19:00	0.7	14.4	0.0	0.0	0.0
04/06/2025 20:00	0.8	14.4	0.0	0.0	0.0
04/06/2025 21:00	0.7	14.4	0.0	0.0	0.0
04/06/2025 22:00	0.7	14.4	0.0	0.0	0.0
04/06/2025 23:00	0.8	14.3	0.0	0.0	0.0
Average/Sum#:	0.8	14.4	0.0	0.0	0.0
Minimum:	0.7	14.3	0.0	0.0	0.0
Maximum:	0.9	14.5	0.0	0.0	0.0
%SI	0.00	0.00	100.00	100.00	100.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
04/07/2025 00:00	0.8	14.3	0.0	0.0	0.0
04/07/2025 01:00	0.8	14.3	0.0	0.0	0.0
04/07/2025 02:00	0.8	14.3	0.0	0.0	0.0
04/07/2025 03:00	0.8	14.3	0.0	0.0	0.0
04/07/2025 04:00	0.8	14.3	0.0	0.0	0.0
04/07/2025 05:00	0.7	14.4	0.0	0.0	0.0
04/07/2025 06:00	0.7	14.3	0.0	0.0	0.0
04/07/2025 07:00	0.8	14.3	0.0	0.0	0.0
04/07/2025 08:00	0.8	14.3	0.0	0.0	18.0
04/07/2025 09:00	0.7	14.3	0.7	1.5	14.2
04/07/2025 10:00	0.8	15.1	0.7	1.5	14.3
04/07/2025 11:00	0.0	0.0	0.7	1.5	14.3
04/07/2025 12:00	0.0	0.0	0.7	1.5	14.3
04/07/2025 13:00	0.0	0.0	0.7	1.5	14.3
04/07/2025 14:00	0.0	0.0	0.7	1.5	14.3
04/07/2025 15:00	0.0	0.0	0.7	1.5	14.3
04/07/2025 16:00	0.0	0.0	0.7	1.5	14.4
04/07/2025 17:00	0.0	0.0	0.7	1.5	14.4
04/07/2025 18:00	0.0	0.0	0.7	1.5	14.3
04/07/2025 19:00	0.0	0.0	0.8	1.5	14.3
04/07/2025 20:00	0.0	0.0	0.7	1.5	14.3
04/07/2025 21:00	0.0	0.0	0.8	1.5	14.3
04/07/2025 22:00	0.0	0.0	0.8	1.5	14.3
04/07/2025 23:00	0.0	0.0	0.8	1.5	14.2
Average/Sum#:	0.8	14.4	0.7	1.4	14.5
Minimum:	0.7	14.3	0.0	0.0	14.2
Maximum:	0.8	15.1	0.8	1.5	18.0
%SI	54.17	54.17	33.33	33.33	33.33

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
04/08/2025 00:00	0.0	0.0	0.8	1.5	14.2
04/08/2025 01:00	0.0	0.0	0.8	1.5	14.2
04/08/2025 02:00	0.0	0.0	0.8	1.5	14.2
04/08/2025 03:00	0.0	0.0	0.7	1.5	14.2
04/08/2025 04:00	0.0	0.0	0.8	1.5	14.2
04/08/2025 05:00	0.0	0.0	0.8	1.4	14.2
04/08/2025 06:00	0.0	0.0	0.8	1.5	14.2
04/08/2025 07:00	0.0	0.0	0.8	1.5	14.2
04/08/2025 08:00	0.0	0.0	0.8	1.5	14.3
04/08/2025 09:00	0.0	0.0	0.7	1.5	14.3
04/08/2025 10:00	0.0	0.0	0.8	1.5	14.3
04/08/2025 11:00	0.0	0.0	0.8	1.5	14.3
04/08/2025 12:00	0.0	0.0	0.8	1.5	14.3
04/08/2025 13:00	0.0	0.0	0.8	1.5	14.3
04/08/2025 14:00	0.0	0.0	0.7	1.5	14.3
04/08/2025 15:00	0.0	0.0	0.7	1.5	14.4
04/08/2025 16:00	0.0	0.0	0.8	1.5	14.4
04/08/2025 17:00	0.0	0.0	0.8	1.5	14.4
04/08/2025 18:00	0.0	0.0	0.9	1.5	14.3
04/08/2025 19:00	0.0	0.0	1.0	1.5	14.3
04/08/2025 20:00	0.0	0.0	1.2	1.5	14.3
04/08/2025 21:00	0.0	0.0	1.3	1.5	14.3
04/08/2025 22:00	0.0	0.0	1.1	1.5	14.3
04/08/2025 23:00	0.0	0.0	0.9	1.5	14.2
Average/Sum#:	0.0	0.0	0.9	1.5	14.3
Minimum:	0.0	0.0	0.7	1.4	14.2
Maximum:	0.0	0.0	1.3	1.5	14.4
%SI	100.00	100.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
04/09/2025 00:00	0.0	0.0	0.9	1.5	14.2
04/09/2025 01:00	0.0	0.0	0.9	1.5	14.2
04/09/2025 02:00	0.0	0.0	0.8	1.5	14.2
04/09/2025 03:00	0.0	0.0	1.0	1.5	14.2
04/09/2025 04:00	0.0	0.0	1.2	1.5	14.2
04/09/2025 05:00	0.0	0.0	0.9	1.5	14.2
04/09/2025 06:00	0.0	0.0	0.9	1.6	14.2
04/09/2025 07:00	0.0	0.0	0.9	1.5	14.2
04/09/2025 08:00	0.0	0.0	0.8	1.5	14.3
04/09/2025 09:00	0.0	0.0	0.8	1.5	14.3
04/09/2025 10:00	0.0	0.0	0.8	1.5	14.3
04/09/2025 11:00	0.0	0.0	0.7	1.5	14.3
04/09/2025 12:00	0.0	0.0	0.8	1.5	14.4
04/09/2025 13:00	0.0	0.0	0.7	1.5	14.4
04/09/2025 14:00	0.0	0.0	0.7	1.5	14.4
04/09/2025 15:00	0.0	0.0	0.7	1.5	14.4
04/09/2025 16:00	0.0	0.0	0.8	1.5	14.4
04/09/2025 17:00	0.0	0.0	0.7	1.5	14.5
04/09/2025 18:00	0.0	0.0	0.8	1.5	14.4
04/09/2025 19:00	0.0	0.0	0.9	1.5	14.3
04/09/2025 20:00	0.0	0.0	0.8	1.5	14.3
04/09/2025 21:00	0.0	0.0	0.8	1.5	14.3
04/09/2025 22:00	0.0	0.0	0.8	1.5	14.3
04/09/2025 23:00	0.0	0.0	0.8	1.5	14.3
Average/Sum#:	0.0	0.0	0.8	1.5	14.3
Minimum:	0.0	0.0	0.7	1.5	14.2
Maximum:	0.0	0.0	1.2	1.6	14.5
%SI	100.00	100.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
04/10/2025 00:00	0.0	0.0	0.8	1.5	14.3
04/10/2025 01:00	0.0	0.0	0.8	1.5	14.3
04/10/2025 02:00	0.0	0.0	0.8	1.5	14.2
04/10/2025 03:00	0.0	0.0	0.8	1.5	14.2
04/10/2025 04:00	0.0	0.0	0.8	1.5	14.3
04/10/2025 05:00	0.0	0.0	0.8	1.5	14.2
04/10/2025 06:00	0.0	0.0	0.8	1.5	14.2
04/10/2025 07:00	0.0	0.0	0.8	1.5	14.2
04/10/2025 08:00	0.0	0.0	0.8	1.5	14.3
04/10/2025 09:00	0.0	0.0	0.8	1.5	14.3
04/10/2025 10:00	0.0	0.0	0.8	1.5	14.3
04/10/2025 11:00	0.0	0.0	0.8	1.5	14.3
04/10/2025 12:00	0.0	0.0	0.8	1.5	14.3
04/10/2025 13:00	0.0	0.0	0.8	1.5	14.3
04/10/2025 14:00	0.0	0.0	0.7	1.5	14.5
04/10/2025 15:00	0.0	0.0	0.8	1.5	14.4
04/10/2025 16:00	0.0	0.0	0.7	1.5	14.4
04/10/2025 17:00	0.0	0.0	0.7	1.5	14.5
04/10/2025 18:00	0.0	0.0	0.7	1.5	14.5
04/10/2025 19:00	0.0	0.0	0.7	1.5	14.4
04/10/2025 20:00	0.0	0.0	0.8	1.5	14.3
04/10/2025 21:00	0.0	0.0	0.8	1.5	14.3
04/10/2025 22:00	0.0	0.0	0.8	1.5	14.3
04/10/2025 23:00	0.0	0.0	0.8	1.5	14.3
Average/Sum#:	0.0	0.0	0.8	1.5	14.3
Minimum:	0.0	0.0	0.7	1.5	14.2
Maximum:	0.0	0.0	0.8	1.5	14.5
%SI	100.00	100.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
04/11/2025 00:00	0.0	0.0	0.8	1.5	14.2
04/11/2025 01:00	0.0	0.0	0.8	1.5	14.2
04/11/2025 02:00	0.0	0.0	0.8	1.5	14.2
04/11/2025 03:00	0.0	0.0	0.9	1.5	14.2
04/11/2025 04:00	0.0	0.0	0.8	1.5	14.2
04/11/2025 05:00	0.0	0.0	0.8	1.4	14.3
04/11/2025 06:00	0.0	0.0	0.8	1.5	14.2
04/11/2025 07:00	0.0	0.0	0.8	1.5	14.2
04/11/2025 08:00	0.0	0.0	0.8	1.5	14.2
04/11/2025 09:00	0.0	0.0	0.9	1.5	14.3
04/11/2025 10:00	0.0	0.0	0.8	1.5	14.3
04/11/2025 11:00	0.0	0.0	0.8	1.5	14.3
04/11/2025 12:00	0.0	0.0	0.8	1.5	14.3
04/11/2025 13:00	0.0	0.0	0.8	1.5	14.4
04/11/2025 14:00	0.0	0.0	0.8	1.5	14.4
04/11/2025 15:00	0.0	0.0	0.8	1.5	14.4
04/11/2025 16:00	0.0	0.0	0.8	1.5	14.4
04/11/2025 17:00	0.0	0.0	0.7	1.5	14.4
04/11/2025 18:00	0.0	0.0	0.8	1.5	14.3
04/11/2025 19:00	0.0	0.0	0.8	1.5	14.3
04/11/2025 20:00	0.0	0.0	0.8	1.5	14.3
04/11/2025 21:00	0.0	0.0	0.8	1.5	14.3
04/11/2025 22:00	0.0	0.0	0.8	1.5	14.2
04/11/2025 23:00	0.0	0.0	0.8	1.5	14.2
Average/Sum#:	0.0	0.0	0.8	1.5	14.3
Minimum:	0.0	0.0	0.7	1.4	14.2
Maximum:	0.0	0.0	0.9	1.5	14.4
%SI	100.00	100.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
04/12/2025 00:00	0.0	0.0	0.8	1.5	14.2
04/12/2025 01:00	0.0	0.0	0.8	1.5	14.2
04/12/2025 02:00	0.0	0.0	0.8	1.5	14.2
04/12/2025 03:00	0.0	0.0	0.9	1.5	14.2
04/12/2025 04:00	0.0	0.0	0.8	1.5	14.2
04/12/2025 05:00	0.0	0.0	0.9	1.5	14.2
04/12/2025 06:00	0.0	0.0	0.9	1.5	14.2
04/12/2025 07:00	0.0	0.0	0.9	1.5	14.2
04/12/2025 08:00	0.0	0.0	0.9	1.5	14.2
04/12/2025 09:00	0.0	0.0	0.8	1.5	14.2
04/12/2025 10:00	0.0	0.0	0.8	1.5	14.2
04/12/2025 11:00	0.0	0.0	0.8	1.5	14.3
04/12/2025 12:00	0.0	0.0	0.8	1.5	14.3
04/12/2025 13:00	0.0	0.0	0.8	1.5	14.3
04/12/2025 14:00	0.0	0.0	0.8	1.5	14.3
04/12/2025 15:00	0.0	0.0	0.8	1.5	14.3
04/12/2025 16:00	0.0	0.0	0.8	1.5	14.3
04/12/2025 17:00	0.0	0.0	0.8	1.5	14.3
04/12/2025 18:00	0.0	0.0	0.9	1.5	14.3
04/12/2025 19:00	0.0	0.0	0.9	1.5	14.3
04/12/2025 20:00	0.0	0.0	0.9	1.5	14.3
04/12/2025 21:00	0.0	0.0	0.9	1.5	14.2
04/12/2025 22:00	0.0	0.0	0.9	1.5	14.2
04/12/2025 23:00	0.0	0.0	0.9	1.5	14.2
Average/Sum#:	0.0	0.0	0.8	1.5	14.2
Minimum:	0.0	0.0	0.8	1.5	14.2
Maximum:	0.0	0.0	0.9	1.5	14.3
%SI	100.00	100.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
04/13/2025 00:00	0.0	0.0	0.9	1.5	14.2
04/13/2025 01:00	0.0	0.0	0.9	1.5	14.2
04/13/2025 02:00	0.0	0.0	1.0	1.5	14.2
04/13/2025 03:00	0.0	0.0	1.0	1.5	14.2
04/13/2025 04:00	0.0	0.0	0.9	1.5	14.2
04/13/2025 05:00	0.0	0.0	0.9	1.5	14.2
04/13/2025 06:00	0.0	0.0	0.9	1.4	14.2
04/13/2025 07:00	0.0	0.0	0.9	1.5	14.2
04/13/2025 08:00	0.0	0.0	0.8	1.5	14.2
04/13/2025 09:00	0.0	0.0	0.8	1.5	14.3
04/13/2025 10:00	0.0	0.0	0.8	1.5	14.3
04/13/2025 11:00	0.0	0.0	0.8	1.5	14.4
04/13/2025 12:00	0.0	0.0	0.8	1.5	14.4
04/13/2025 13:00	0.0	0.0	0.8	1.5	14.4
04/13/2025 14:00	0.0	0.0	0.8	1.5	14.4
04/13/2025 15:00	0.0	0.0	0.8	1.5	14.4
04/13/2025 16:00	0.0	0.0	0.8	1.5	14.4
04/13/2025 17:00	0.0	0.0	0.8	1.5	14.5
04/13/2025 18:00	0.0	0.0	0.8	1.5	14.4
04/13/2025 19:00	0.0	0.0	0.8	1.5	14.3
04/13/2025 20:00	0.0	0.0	0.9	1.5	14.3
04/13/2025 21:00	0.0	0.0	0.8	1.5	14.3
04/13/2025 22:00	0.0	0.0	0.9	1.5	14.3
04/13/2025 23:00	0.0	0.0	1.0	1.5	14.3
Average/Sum#:	0.0	0.0	0.9	1.5	14.3
Minimum:	0.0	0.0	0.8	1.4	14.2
Maximum:	0.0	0.0	1.0	1.5	14.5
%SI	100.00	100.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
04/14/2025 00:00	0.0	0.0	1.1	1.5	14.3
04/14/2025 01:00	0.0	0.0	1.0	1.5	14.3
04/14/2025 02:00	0.0	0.0	1.0	1.5	14.2
04/14/2025 03:00	0.0	0.0	0.9	1.5	14.2
04/14/2025 04:00	0.0	0.0	0.9	1.5	14.2
04/14/2025 05:00	0.0	0.0	0.9	1.5	14.2
04/14/2025 06:00	0.0	0.0	0.9	1.5	14.2
04/14/2025 07:00	0.0	0.0	0.9	1.5	14.2
04/14/2025 08:00	0.0	0.0	0.9	1.5	14.2
04/14/2025 09:00	0.0	0.0	0.9	1.5	14.3
04/14/2025 10:00	0.0	0.0	0.8	1.5	14.3
04/14/2025 11:00	0.0	0.0	0.8	1.5	14.4
04/14/2025 12:00	0.0	0.0	0.8	1.5	14.4
04/14/2025 13:00	0.0	0.0	0.8	1.5	14.4
04/14/2025 14:00	0.0	0.0	0.8	1.5	14.4
04/14/2025 15:00	0.0	0.0	0.8	1.5	14.4
04/14/2025 16:00	0.0	0.0	0.8	1.5	14.4
04/14/2025 17:00	0.0	0.0	0.8	1.5	14.5
04/14/2025 18:00	0.0	0.0	0.8	1.5	14.4
04/14/2025 19:00	0.0	0.0	0.8	1.5	14.4
04/14/2025 20:00	0.0	0.0	0.8	1.5	14.3
04/14/2025 21:00	0.0	0.0	0.8	1.5	14.3
04/14/2025 22:00	0.0	0.0	0.8	1.5	14.3
04/14/2025 23:00	0.0	0.0	0.9	1.5	14.3
Average/Sum#:	0.0	0.0	0.9	1.5	14.3
Minimum:	0.0	0.0	0.8	1.5	14.2
Maximum:	0.0	0.0	1.1	1.5	14.5
%SI	100.00	100.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
04/15/2025 00:00	0.0	0.0	0.8	1.5	14.2
04/15/2025 01:00	0.0	0.0	0.9	1.5	14.2
04/15/2025 02:00	0.0	0.0	0.8	1.5	14.2
04/15/2025 03:00	0.0	0.0	0.8	1.5	14.2
04/15/2025 04:00	0.0	0.0	0.9	1.5	14.2
04/15/2025 05:00	0.0	0.0	0.9	1.5	14.2
04/15/2025 06:00	0.0	0.0	0.9	1.5	14.2
04/15/2025 07:00	0.0	0.0	0.9	1.5	14.2
04/15/2025 08:00	0.0	0.0	0.8	1.5	14.2
04/15/2025 09:00	0.0	0.0	0.8	1.5	14.2
04/15/2025 10:00	0.0	0.0	0.8	1.5	14.2
04/15/2025 11:00	0.0	0.0	0.8	1.5	14.3
04/15/2025 12:00	0.0	0.0	0.8	1.5	14.3
04/15/2025 13:00	0.0	0.0	0.8	1.5	14.3
04/15/2025 14:00	0.0	0.0	0.8	1.5	14.3
04/15/2025 15:00	0.0	0.0	0.8	1.5	14.3
04/15/2025 16:00	0.0	0.0	0.8	1.5	14.3
04/15/2025 17:00	0.0	0.0	0.7	1.5	14.4
04/15/2025 18:00	0.0	0.0	0.8	1.5	14.2
04/15/2025 19:00	0.0	0.0	0.8	1.5	14.2
04/15/2025 20:00	0.0	0.0	0.9	1.5	14.2
04/15/2025 21:00	0.0	0.0	0.8	1.5	14.2
04/15/2025 22:00	0.0	0.0	0.8	1.5	14.2
04/15/2025 23:00	0.0	0.0	0.8	1.4	14.2
Average/Sum#:	0.0	0.0	0.8	1.5	14.2
Minimum:	0.0	0.0	0.7	1.4	14.2
Maximum:	0.0	0.0	0.9	1.5	14.4
%SI	100.00	100.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
04/16/2025 00:00	0.0	0.0	0.9	1.5	14.2
04/16/2025 01:00	0.0	0.0	0.8	1.5	14.2
04/16/2025 02:00	0.0	0.0	0.9	1.5	14.2
04/16/2025 03:00	0.0	0.0	0.9	1.5	14.2
04/16/2025 04:00	0.0	0.0	0.9	1.5	14.2
04/16/2025 05:00	0.0	0.0	0.8	1.5	14.2
04/16/2025 06:00	0.0	0.0	0.9	1.5	14.2
04/16/2025 07:00	0.0	0.0	0.9	1.5	14.2
04/16/2025 08:00	0.0	0.0	0.8	1.5	14.2
04/16/2025 09:00	0.0	0.0	0.8	1.5	14.2
04/16/2025 10:00	0.0	0.0	0.9	1.5	14.2
04/16/2025 11:00	0.0	0.0	0.8	1.5	14.3
04/16/2025 12:00	0.0	0.0	0.8	1.5	14.3
04/16/2025 13:00	0.0	0.0	0.8	1.5	14.3
04/16/2025 14:00	0.0	0.0	0.8	1.5	14.3
04/16/2025 15:00	0.0	0.0	0.8	1.5	14.3
04/16/2025 16:00	0.0	0.0	0.8	1.5	14.3
04/16/2025 17:00	0.0	0.0	0.8	1.5	14.3
04/16/2025 18:00	0.0	0.0	0.8	1.5	14.2
04/16/2025 19:00	0.0	0.0	0.8	1.5	14.2
04/16/2025 20:00	0.0	0.0	0.8	1.5	14.2
04/16/2025 21:00	0.0	0.0	0.8	1.5	14.2
04/16/2025 22:00	0.0	0.0	0.8	1.5	14.2
04/16/2025 23:00	0.0	0.0	0.8	1.5	14.2
Average/Sum#:	0.0	0.0	0.8	1.5	14.2
Minimum:	0.0	0.0	0.8	1.5	14.2
Maximum:	0.0	0.0	0.9	1.5	14.3
%SI	100.00	100.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
04/17/2025 00:00	0.0	0.0	0.8	1.5	14.2
04/17/2025 01:00	0.0	0.0	0.8	1.5	14.2
04/17/2025 02:00	0.0	0.0	0.8	1.6	14.2
04/17/2025 03:00	0.0	0.0	0.9	1.5	14.2
04/17/2025 04:00	0.0	0.0	0.8	1.5	14.2
04/17/2025 05:00	0.0	0.0	0.8	1.5	14.2
04/17/2025 06:00	0.0	0.0	0.9	1.5	14.2
04/17/2025 07:00	0.0	0.0	0.8	1.5	14.2
04/17/2025 08:00	0.0	0.0	0.8	1.5	14.3
04/17/2025 09:00	0.0	0.0	0.8	1.5	14.2
04/17/2025 10:00	0.0	0.0	0.8	1.5	14.2
04/17/2025 11:00	0.0	0.0	0.8	1.5	14.3
04/17/2025 12:00	0.0	0.0	0.8	1.5	14.3
04/17/2025 13:00	0.0	0.0	0.8	1.5	14.3
04/17/2025 14:00	0.0	0.0	0.8	1.5	14.3
04/17/2025 15:00	0.0	0.0	0.8	1.5	14.3
04/17/2025 16:00	0.0	0.0	0.8	1.5	14.3
04/17/2025 17:00	0.0	0.0	0.8	1.5	14.3
04/17/2025 18:00	0.0	0.0	0.8	1.5	14.3
04/17/2025 19:00	0.0	0.0	0.8	1.5	14.2
04/17/2025 20:00	0.0	0.0	0.8	1.5	14.2
04/17/2025 21:00	0.0	0.0	0.9	1.5	14.2
04/17/2025 22:00	0.0	0.0	0.8	1.5	14.2
04/17/2025 23:00	0.0	0.0	0.8	1.5	14.2
Average/Sum#:	0.0	0.0	0.8	1.5	14.2
Minimum:	0.0	0.0	0.8	1.5	14.2
Maximum:	0.0	0.0	0.9	1.6	14.3
%SI	100.00	100.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
04/18/2025 00:00	0.0	0.0	0.8	1.5	14.2
04/18/2025 01:00	0.0	0.0	0.9	1.5	14.2
04/18/2025 02:00	0.0	0.0	0.8	1.5	14.2
04/18/2025 03:00	0.0	0.0	0.9	1.5	14.2
04/18/2025 04:00	0.0	0.0	0.9	1.5	14.2
04/18/2025 05:00	0.0	0.0	0.8	1.5	14.2
04/18/2025 06:00	0.0	0.0	0.7	1.5	14.3
04/18/2025 07:00	0.0	15.6	0.7	1.5	14.3
04/18/2025 08:00	0.9	14.3	0.8	1.5	14.2
04/18/2025 09:00	0.8	14.4	0.8	1.5	14.4
04/18/2025 10:00	0.8	13.9	0.0	0.0	0.0
04/18/2025 11:00	0.7	14.4	0.0	0.0	0.0
04/18/2025 12:00	0.6	14.5	0.0	0.0	0.0
04/18/2025 13:00	0.6	14.5	0.0	0.0	0.0
04/18/2025 14:00	0.6	14.5	0.0	0.0	0.0
04/18/2025 15:00	0.6	14.5	0.0	0.0	0.0
04/18/2025 16:00	0.6	14.5	0.0	0.0	0.0
04/18/2025 17:00	0.6	14.5	0.0	0.0	0.0
04/18/2025 18:00	0.6	14.4	0.0	0.0	0.0
04/18/2025 19:00	0.6	14.5	0.0	0.0	0.0
04/18/2025 20:00	0.7	14.6	0.0	0.0	0.0
04/18/2025 21:00	0.7	14.6	0.0	0.0	0.0
04/18/2025 22:00	0.7	14.5	0.0	0.0	0.0
04/18/2025 23:00	0.7	13.5	0.0	0.0	0.0
Average/Sum#:	0.6	14.5	0.8	1.5	14.2
Minimum:	0.0	13.5	0.7	1.5	14.2
Maximum:	0.9	15.6	0.9	1.5	14.4
%SI	29.17	29.17	58.33	58.33	58.33

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOX, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
04/19/2025 00:00	0.8	13.8	0.0	0.0	0.0
04/19/2025 01:00	0.9	13.8	0.0	0.0	0.0
04/19/2025 02:00	0.9	13.8	0.0	0.0	0.0
04/19/2025 03:00	1.0	13.8	0.0	0.0	0.0
04/19/2025 04:00	1.0	13.9	0.0	0.0	0.0
04/19/2025 05:00	1.0	13.9	0.0	0.0	0.0
04/19/2025 06:00	0.9	14.1	0.0	0.0	0.0
04/19/2025 07:00	0.8	14.3	0.0	0.0	0.0
04/19/2025 08:00	0.7	14.3	0.0	0.0	0.0
04/19/2025 09:00	0.7	14.4	0.0	0.0	0.0
04/19/2025 10:00	0.7	14.4	0.0	0.0	0.0
04/19/2025 11:00	0.7	14.4	0.0	0.0	0.0
04/19/2025 12:00	0.6	14.4	0.0	0.0	0.0
04/19/2025 13:00	0.6	14.4	0.0	0.0	0.0
04/19/2025 14:00	0.6	14.5	0.0	0.0	0.0
04/19/2025 15:00	0.6	14.5	0.0	0.0	0.0
04/19/2025 16:00	0.6	14.5	0.0	0.0	0.0
04/19/2025 17:00	0.6	14.5	0.0	0.0	0.0
04/19/2025 18:00	0.8	14.4	0.0	0.0	0.0
04/19/2025 19:00	0.8	13.8	0.0	0.0	0.0
04/19/2025 20:00	0.9	13.9	0.0	0.0	0.0
04/19/2025 21:00	0.9	13.9	0.0	0.0	0.0
04/19/2025 22:00	1.0	13.9	0.0	0.0	0.0
04/19/2025 23:00	0.8	14.3	0.0	0.0	0.0
Average/Sum#:	0.8	14.2	0.0	0.0	0.0
Minimum:	0.6	13.8	0.0	0.0	0.0
Maximum:	1.0	14.5	0.0	0.0	0.0
%SI	0.00	0.00	100.00	100.00	100.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
04/20/2025 00:00	0.7	14.3	0.0	0.0	0.0
04/20/2025 01:00	0.8	14.3	0.0	0.0	0.0
04/20/2025 02:00	0.8	14.3	0.0	0.0	0.0
04/20/2025 03:00	0.8	14.3	0.0	0.0	0.0
04/20/2025 04:00	0.8	14.3	0.0	0.0	0.0
04/20/2025 05:00	0.7	14.3	0.0	0.0	0.0
04/20/2025 06:00	0.7	14.3	0.0	0.0	0.0
04/20/2025 07:00	0.7	14.3	0.0	0.0	0.0
04/20/2025 08:00	1.3	14.3	0.0	0.0	0.0
04/20/2025 09:00	0.7	14.3	0.0	0.0	0.0
04/20/2025 10:00	0.6	14.4	0.0	0.0	0.0
04/20/2025 11:00	0.6	14.4	0.0	0.0	0.0
04/20/2025 12:00	0.6	14.4	0.0	0.0	0.0
04/20/2025 13:00	0.6	14.5	0.0	0.0	0.0
04/20/2025 14:00	0.6	14.5	0.0	0.0	0.0
04/20/2025 15:00	0.6	14.5	0.0	0.0	0.0
04/20/2025 16:00	0.6	14.5	0.0	0.0	0.0
04/20/2025 17:00	0.7	14.4	0.0	0.0	0.0
04/20/2025 18:00	0.5	13.5	0.0	0.0	0.0
04/20/2025 19:00	0.6	13.6	0.0	0.0	0.0
04/20/2025 20:00	0.6	13.6	0.0	0.0	0.0
04/20/2025 21:00	0.7	13.7	0.0	0.0	0.0
04/20/2025 22:00	0.8	13.7	0.0	0.0	0.0
04/20/2025 23:00	0.9	13.8	0.0	0.0	0.0
Average/Sum#:	0.7	14.2	0.0	0.0	0.0
Minimum:	0.5	13.5	0.0	0.0	0.0
Maximum:	1.3	14.5	0.0	0.0	0.0
%SI	0.00	0.00	100.00	100.00	100.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
04/21/2025 00:00	0.9	13.8	0.0	0.0	0.0
04/21/2025 01:00	0.8	13.7	0.0	0.0	0.0
04/21/2025 02:00	0.8	13.8	0.0	0.0	0.0
04/21/2025 03:00	0.9	13.8	0.0	0.0	0.0
04/21/2025 04:00	0.9	13.8	0.0	0.0	0.0
04/21/2025 05:00	1.0	13.8	0.0	0.0	0.0
04/21/2025 06:00	1.0	14.1	0.0	0.0	0.0
04/21/2025 07:00	0.9	14.3	0.0	0.0	0.0
04/21/2025 08:00	0.8	14.3	0.0	0.0	0.0
04/21/2025 09:00	0.8	14.4	0.0	0.0	0.0
04/21/2025 10:00	0.7	14.4	0.0	0.0	0.0
04/21/2025 11:00	0.7	14.4	0.0	0.0	0.0
04/21/2025 12:00	0.7	14.5	0.0	0.0	0.0
04/21/2025 13:00	0.7	14.5	0.0	0.0	0.0
04/21/2025 14:00	0.6	14.5	0.0	0.0	0.0
04/21/2025 15:00	0.7	14.5	0.0	0.0	0.0
04/21/2025 16:00	0.6	14.5	0.0	0.0	0.0
04/21/2025 17:00	0.6	13.9	0.0	0.0	0.0
04/21/2025 18:00	0.2	12.7	0.0	0.0	0.0
04/21/2025 19:00	0.4	13.1	0.0	0.0	0.0
04/21/2025 20:00	0.3	12.8	0.0	0.0	0.0
04/21/2025 21:00	0.2	12.5	0.0	0.0	0.0
04/21/2025 22:00	0.3	12.6	0.0	0.0	0.0
04/21/2025 23:00	0.5	13.0	0.0	0.0	0.0
Average/Sum#:	0.7	13.8	0.0	0.0	0.0
Minimum:	0.2	12.5	0.0	0.0	0.0
Maximum:	1.0	14.5	0.0	0.0	0.0
%SI	0.00	0.00	100.00	100.00	100.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOX, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
04/22/2025 00:00	0.5	13.2	0.0	0.0	0.0
04/22/2025 01:00	0.8	13.6	0.0	0.0	0.0
04/22/2025 02:00	0.9	13.8	0.0	0.0	0.0
04/22/2025 03:00	0.5	12.9	0.0	0.0	0.0
04/22/2025 04:00	0.6	13.2	0.0	0.0	0.0
04/22/2025 05:00	0.5	13.2	0.0	0.0	0.0
04/22/2025 06:00	1.1	13.9	0.0	0.0	0.0
04/22/2025 07:00	0.9	14.1	0.0	0.0	0.0
04/22/2025 08:00	0.8	14.3	0.0	0.0	0.0
04/22/2025 09:00	0.7	14.3	0.0	0.0	0.0
04/22/2025 10:00	0.7	14.3	0.0	0.0	0.0
04/22/2025 11:00	0.7	14.3	0.0	0.0	0.0
04/22/2025 12:00	0.7	14.3	0.0	0.0	0.0
04/22/2025 13:00	0.7	14.3	0.0	0.0	0.0
04/22/2025 14:00	0.7	14.4	0.0	0.0	0.0
04/22/2025 15:00	0.6	14.4	0.0	0.0	0.0
04/22/2025 16:00	0.8	14.3	0.0	0.0	0.0
04/22/2025 17:00	0.5	13.2	0.0	0.0	0.0
04/22/2025 18:00	0.3	12.8	0.0	0.0	0.0
04/22/2025 19:00	0.3	12.8	0.0	0.0	0.0
04/22/2025 20:00	0.4	13.0	0.0	0.0	0.0
04/22/2025 21:00	0.5	13.1	0.0	0.0	0.0
04/22/2025 22:00	0.5	13.1	0.0	0.0	0.0
04/22/2025 23:00	0.6	13.3	0.0	0.0	0.0
Average/Sum#:	0.6	13.7	0.0	0.0	0.0
Minimum:	0.3	12.8	0.0	0.0	0.0
Maximum:	1.1	14.4	0.0	0.0	0.0
%SI	0.00	0.00	100.00	100.00	100.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOX, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
04/23/2025 00:00	0.9	13.8	0.0	0.0	0.0
04/23/2025 01:00	0.9	13.7	0.0	0.0	0.0
04/23/2025 02:00	1.0	13.8	0.0	0.0	0.0
04/23/2025 03:00	1.0	13.8	0.0	0.0	0.0
04/23/2025 04:00	1.0	13.8	0.0	0.0	0.0
04/23/2025 05:00	1.0	13.8	0.0	0.0	0.0
04/23/2025 06:00	0.9	14.1	0.0	0.0	0.0
04/23/2025 07:00	0.8	14.3	0.0	0.0	0.0
04/23/2025 08:00	0.8	14.3	0.0	0.0	0.0
04/23/2025 09:00	0.7	14.3	0.0	0.0	0.0
04/23/2025 10:00	0.7	14.3	0.0	0.0	0.0
04/23/2025 11:00	0.7	14.3	0.0	0.0	0.0
04/23/2025 12:00	0.7	14.3	0.0	0.0	0.0
04/23/2025 13:00	0.7	14.3	0.0	0.0	0.0
04/23/2025 14:00	0.7	14.3	0.0	0.0	0.0
04/23/2025 15:00	0.7	14.3	0.0	0.0	0.0
04/23/2025 16:00	0.7	14.3	0.0	0.0	0.0
04/23/2025 17:00	0.8	14.3	0.0	0.0	0.0
04/23/2025 18:00	0.7	13.7	0.0	0.0	0.0
04/23/2025 19:00	0.8	13.8	0.0	0.0	0.0
04/23/2025 20:00	0.9	13.8	0.0	0.0	0.0
04/23/2025 21:00	0.9	13.8	0.0	0.0	0.0
04/23/2025 22:00	1.0	13.8	0.0	0.0	0.0
04/23/2025 23:00	1.0	13.8	0.0	0.0	0.0
Average/Sum#:	0.8	14.0	0.0	0.0	0.0
Minimum:	0.7	13.7	0.0	0.0	0.0
Maximum:	1.0	14.3	0.0	0.0	0.0
%SI	0.00	0.00	100.00	100.00	100.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
04/24/2025 00:00	1.0	13.9	0.0	0.0	0.0
04/24/2025 01:00	1.0	13.9	0.0	0.0	0.0
04/24/2025 02:00	1.0	13.9	0.0	0.0	0.0
04/24/2025 03:00	1.0	13.9	0.0	0.0	0.0
04/24/2025 04:00	1.0	13.9	0.0	0.0	0.0
04/24/2025 05:00	0.8	14.3	0.0	0.0	0.0
04/24/2025 06:00	0.8	14.3	0.0	0.0	0.0
04/24/2025 07:00	0.7	14.3	0.0	0.0	0.0
04/24/2025 08:00	0.7	14.3	0.0	0.0	0.0
04/24/2025 09:00	0.7	14.3	0.0	0.0	0.0
04/24/2025 10:00	0.7	14.3	0.0	0.0	0.0
04/24/2025 11:00	0.7	14.4	0.0	0.0	0.0
04/24/2025 12:00	0.7	14.4	0.0	0.0	0.0
04/24/2025 13:00	0.7	14.4	0.0	0.0	0.0
04/24/2025 14:00	0.7	14.4	0.0	0.0	0.0
04/24/2025 15:00	0.7	14.4	0.0	0.0	0.0
04/24/2025 16:00	0.7	14.5	0.0	0.0	0.0
04/24/2025 17:00	0.8	14.4	0.0	0.0	0.0
04/24/2025 18:00	0.9	13.9	0.0	0.0	0.0
04/24/2025 19:00	0.9	13.8	0.0	0.0	0.0
04/24/2025 20:00	0.9	13.8	0.0	0.0	0.0
04/24/2025 21:00	0.9	13.9	0.0	0.0	0.0
04/24/2025 22:00	1.0	13.9	0.0	0.0	0.0
04/24/2025 23:00	1.0	13.9	0.0	0.0	0.0
Average/Sum#:	0.8	14.1	0.0	0.0	0.0
Minimum:	0.7	13.8	0.0	0.0	0.0
Maximum:	1.0	14.5	0.0	0.0	0.0
%SI	0.00	0.00	100.00	100.00	100.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
04/25/2025 00:00	1.0	13.9	0.0	0.0	0.0
04/25/2025 01:00	1.0	13.9	0.0	0.0	0.0
04/25/2025 02:00	0.8	14.3	0.0	0.0	0.0
04/25/2025 03:00	0.8	14.3	0.0	0.0	0.0
04/25/2025 04:00	0.7	14.3	0.0	0.0	0.0
04/25/2025 05:00	0.6	14.5	0.0	0.0	0.0
04/25/2025 06:00	0.6	14.5	0.0	0.0	18.5
04/25/2025 07:00	0.7	14.4	0.0	0.0	15.5
04/25/2025 08:00	0.6	14.5	0.6	1.5	14.4
04/25/2025 09:00	0.7	14.5	0.7	1.5	14.3
04/25/2025 10:00	0.6	14.6	0.7	1.5	14.3
04/25/2025 11:00	0.6	14.6	0.6	1.5	14.4
04/25/2025 12:00	0.6	14.5	0.7	1.3	14.4
04/25/2025 13:00	0.7	14.5	0.6	1.2	14.7
04/25/2025 14:00	0.8	13.9	0.0	0.0	0.0
04/25/2025 15:00	0.7	14.4	0.0	0.0	0.0
04/25/2025 16:00	0.6	14.4	0.0	0.0	0.0
04/25/2025 17:00	0.7	14.4	0.0	0.0	0.0
04/25/2025 18:00	0.7	13.7	0.0	0.0	0.0
04/25/2025 19:00	0.8	13.8	0.0	0.0	0.0
04/25/2025 20:00	0.8	13.8	0.0	0.0	0.0
04/25/2025 21:00	0.7	14.5	0.0	0.0	0.0
04/25/2025 22:00	0.7	14.4	0.0	0.0	0.0
04/25/2025 23:00	0.7	14.3	0.0	0.0	0.0
Average/Sum#:	0.7	14.3	0.5	1.1	15.1
Minimum:	0.6	13.7	0.0	0.0	14.3
Maximum:	1.0	14.6	0.7	1.5	18.5
%SI	0.00	0.00	66.67	66.67	66.67

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
04/26/2025 00:00	0.7	14.3	0.0	0.0	0.0
04/26/2025 01:00	0.7	14.3	0.0	0.0	0.0
04/26/2025 02:00	0.7	14.3	0.0	0.0	0.0
04/26/2025 03:00	0.8	14.3	0.0	0.0	0.0
04/26/2025 04:00	0.7	14.3	0.0	0.0	0.0
04/26/2025 05:00	0.7	14.3	0.0	0.0	0.0
04/26/2025 06:00	0.8	14.3	0.0	0.0	0.0
04/26/2025 07:00	0.7	14.4	0.0	0.0	0.0
04/26/2025 08:00	0.6	14.5	0.0	0.0	0.0
04/26/2025 09:00	0.6	14.4	0.0	0.0	0.0
04/26/2025 10:00	0.7	14.4	0.0	0.0	0.0
04/26/2025 11:00	0.7	14.4	0.0	0.0	0.0
04/26/2025 12:00	0.7	14.3	0.0	0.0	0.0
04/26/2025 13:00	0.7	14.3	0.0	0.0	0.0
04/26/2025 14:00	0.7	14.3	0.0	0.0	0.0
04/26/2025 15:00	0.7	14.4	0.0	0.0	0.0
04/26/2025 16:00	0.7	14.5	0.0	0.0	0.0
04/26/2025 17:00	0.7	14.5	0.0	0.0	0.0
04/26/2025 18:00	0.7	14.3	0.0	0.0	0.0
04/26/2025 19:00	0.7	14.3	0.0	0.0	0.0
04/26/2025 20:00	0.7	14.3	0.0	0.0	0.0
04/26/2025 21:00	0.7	14.3	0.0	0.0	0.0
04/26/2025 22:00	0.7	14.3	0.0	0.0	0.0
04/26/2025 23:00	0.6	14.5	0.0	0.0	0.0
Average/Sum#:	0.7	14.4	0.0	0.0	0.0
Minimum:	0.6	14.3	0.0	0.0	0.0
Maximum:	0.8	14.5	0.0	0.0	0.0
%SI	0.00	0.00	100.00	100.00	100.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOX, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
04/27/2025 00:00	0.7	14.4	0.0	0.0	0.0
04/27/2025 01:00	0.7	14.3	0.0	0.0	0.0
04/27/2025 02:00	0.7	14.3	0.0	0.0	0.0
04/27/2025 03:00	0.8	14.4	0.0	0.0	0.0
04/27/2025 04:00	0.8	14.3	0.0	0.0	0.0
04/27/2025 05:00	0.8	14.3	0.0	0.0	0.0
04/27/2025 06:00	0.8	14.3	0.0	0.0	0.0
04/27/2025 07:00	0.7	14.3	0.0	0.0	0.0
04/27/2025 08:00	0.7	14.3	0.0	0.0	0.0
04/27/2025 09:00	0.7	14.3	0.0	0.0	0.0
04/27/2025 10:00	0.7	14.3	0.0	0.0	0.0
04/27/2025 11:00	0.7	14.3	0.0	0.0	0.0
04/27/2025 12:00	0.7	14.3	0.0	0.0	0.0
04/27/2025 13:00	0.7	14.3	0.0	0.0	0.0
04/27/2025 14:00	0.7	14.3	0.0	0.0	0.0
04/27/2025 15:00	0.7	14.4	0.0	0.0	0.0
04/27/2025 16:00	0.7	14.4	0.0	0.0	0.0
04/27/2025 17:00	0.7	14.4	0.0	0.0	0.0
04/27/2025 18:00	0.7	14.3	0.0	0.0	0.0
04/27/2025 19:00	0.7	14.3	0.0	0.0	0.0
04/27/2025 20:00	0.7	14.3	0.0	0.0	0.0
04/27/2025 21:00	1.1	14.3	0.0	0.0	0.0
04/27/2025 22:00	1.1	14.3	0.0	0.0	0.0
04/27/2025 23:00	0.9	14.3	0.0	0.0	0.0
Average/Sum#:	0.8	14.3	0.0	0.0	0.0
Minimum:	0.7	14.3	0.0	0.0	0.0
Maximum:	1.1	14.4	0.0	0.0	0.0
%SI	0.00	0.00	100.00	100.00	100.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
04/28/2025 00:00	0.9	14.3	0.0	0.0	0.0
04/28/2025 01:00	0.8	14.3	0.0	0.0	0.0
04/28/2025 02:00	0.8	14.3	0.0	0.0	0.0
04/28/2025 03:00	0.9	14.3	0.0	0.0	0.0
04/28/2025 04:00	0.8	14.3	0.0	0.0	0.0
04/28/2025 05:00	0.8	14.3	0.0	0.0	0.0
04/28/2025 06:00	0.8	14.3	0.0	0.0	0.0
04/28/2025 07:00	0.8	14.3	0.0	0.0	0.0
04/28/2025 08:00	0.7	14.3	0.0	0.0	0.0
04/28/2025 09:00	0.7	14.3	0.0	0.0	0.0
04/28/2025 10:00	0.7	14.4	0.0	0.0	0.0
04/28/2025 11:00	0.7	14.4	0.0	0.0	0.0
04/28/2025 12:00	0.7	14.4	0.0	0.0	0.0
04/28/2025 13:00	0.6	14.4	0.0	0.0	0.0
04/28/2025 14:00	0.7	14.4	0.0	0.0	0.0
04/28/2025 15:00	0.7	14.4	0.0	0.0	0.0
04/28/2025 16:00	0.7	14.4	0.0	0.0	0.0
04/28/2025 17:00	0.7	14.5	0.0	0.0	0.0
04/28/2025 18:00	0.7	14.4	0.0	0.0	0.0
04/28/2025 19:00	0.7	14.4	0.0	0.0	0.0
04/28/2025 20:00	0.7	14.4	0.0	0.0	0.0
04/28/2025 21:00	0.7	14.4	0.0	0.0	0.0
04/28/2025 22:00	0.8	14.3	0.0	0.0	0.0
04/28/2025 23:00	0.8	14.3	0.0	0.0	0.0
Average/Sum#:	0.7	14.4	0.0	0.0	0.0
Minimum:	0.6	14.3	0.0	0.0	0.0
Maximum:	0.9	14.5	0.0	0.0	0.0
%SI	0.00	0.00	100.00	100.00	100.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
04/29/2025 00:00	0.8	14.3	0.0	0.0	0.0
04/29/2025 01:00	0.8	14.3	0.0	0.0	0.0
04/29/2025 02:00	0.8	14.3	0.0	0.0	0.0
04/29/2025 03:00	0.8	14.3	0.0	0.0	0.0
04/29/2025 04:00	0.8	14.3	0.0	0.0	0.0
04/29/2025 05:00	0.8	14.3	0.0	0.0	0.0
04/29/2025 06:00	0.8	14.3	0.0	0.0	0.0
04/29/2025 07:00	0.7	14.3	0.0	0.0	0.0
04/29/2025 08:00	0.7	14.4	0.0	0.0	0.0
04/29/2025 09:00	0.7	14.4	0.0	0.0	0.0
04/29/2025 10:00	0.7	14.4	0.0	0.0	0.0
04/29/2025 11:00	0.7	14.4	0.0	0.0	0.0
04/29/2025 12:00	0.7	14.5	0.0	0.0	0.0
04/29/2025 13:00	0.6	14.5	0.0	0.0	0.0
04/29/2025 14:00	0.6	14.5	0.0	0.0	0.0
04/29/2025 15:00	0.6	14.5	0.0	0.0	0.0
04/29/2025 16:00	0.6	14.5	0.0	0.0	0.0
04/29/2025 17:00	0.6	14.5	0.0	0.0	0.0
04/29/2025 18:00	0.7	14.4	0.0	0.0	0.0
04/29/2025 19:00	0.7	14.4	0.0	0.0	0.0
04/29/2025 20:00	0.7	14.4	0.0	0.0	0.0
04/29/2025 21:00	0.7	14.4	0.0	0.0	0.0
04/29/2025 22:00	0.7	14.4	0.0	0.0	0.0
04/29/2025 23:00	0.7	14.4	0.0	0.0	0.0
Average/Sum#:	0.7	14.4	0.0	0.0	0.0
Minimum:	0.6	14.3	0.0	0.0	0.0
Maximum:	0.8	14.5	0.0	0.0	0.0
%SI	0.00	0.00	100.00	100.00	100.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
04/30/2025 00:00	0.7	14.4	0.0	0.0	0.0
04/30/2025 01:00	0.7	14.4	0.0	0.0	0.0
04/30/2025 02:00	0.7	14.4	0.0	0.0	0.0
04/30/2025 03:00	0.8	14.4	0.0	0.0	0.0
04/30/2025 04:00	0.8	14.3	0.0	0.0	0.0
04/30/2025 05:00	0.8	14.3	0.0	0.0	0.0
04/30/2025 06:00	1.0	14.3	0.0	0.0	0.0
04/30/2025 07:00	0.8	14.3	0.0	0.0	0.0
04/30/2025 08:00	0.8	14.4	0.0	0.0	0.0
04/30/2025 09:00	0.7	14.4	0.0	0.0	0.0
04/30/2025 10:00	0.6	14.4	0.0	0.0	0.0
04/30/2025 11:00	0.6	14.5	0.0	0.0	0.0
04/30/2025 12:00	0.7	14.5	0.0	0.0	0.0
04/30/2025 13:00	0.7	14.5	0.0	0.0	0.0
04/30/2025 14:00	0.7	14.5	0.0	0.0	0.0
04/30/2025 15:00	0.7	14.5	0.0	0.0	0.0
04/30/2025 16:00	0.7	14.5	0.0	0.0	0.0
04/30/2025 17:00	0.7	14.6	0.0	0.0	0.0
04/30/2025 18:00	0.7	14.5	0.0	0.0	0.0
04/30/2025 19:00	0.7	14.7	0.0	0.0	0.0
04/30/2025 20:00	0.7	14.6	0.0	0.0	0.0
04/30/2025 21:00	0.7	14.6	0.0	0.0	0.0
04/30/2025 22:00	0.7	14.5	0.0	0.0	0.0
04/30/2025 23:00	0.7	14.4	0.0	0.0	0.0
Average/Sum#:	0.7	14.5	0.0	0.0	0.0
Minimum:	0.6	14.3	0.0	0.0	0.0
Maximum:	1.0	14.7	0.0	0.0	0.0
%SI	0.00	0.00	100.00	100.00	100.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
05/01/2025 00:00	0.8	14.3	0.0	0.0	0.0
05/01/2025 01:00	0.7	14.3	0.0	0.0	0.0
05/01/2025 02:00	0.8	14.3	0.0	0.0	0.0
05/01/2025 03:00	0.8	14.3	0.0	0.0	0.0
05/01/2025 04:00	0.8	14.3	0.0	0.0	0.0
05/01/2025 05:00	0.8	14.3	0.0	0.0	0.0
05/01/2025 06:00	0.8	14.3	0.0	0.0	0.0
05/01/2025 07:00	0.6	14.3	0.0	0.0	0.0
05/01/2025 08:00	0.6	14.3	0.0	0.0	0.0
05/01/2025 09:00	0.7	14.4	0.0	0.0	0.0
05/01/2025 10:00	0.6	14.4	0.0	0.0	0.0
05/01/2025 11:00	0.6	14.4	0.0	0.0	0.0
05/01/2025 12:00	0.6	14.5	0.0	0.0	0.0
05/01/2025 13:00	0.6	14.5	0.0	0.0	0.0
05/01/2025 14:00	0.6	14.5	0.0	0.0	0.0
05/01/2025 15:00	0.6	14.5	0.0	0.0	0.0
05/01/2025 16:00	0.6	14.5	0.0	0.0	0.0
05/01/2025 17:00	0.5	14.5	0.0	0.0	0.0
05/01/2025 18:00	0.6	14.5	0.0	0.0	0.0
05/01/2025 19:00	0.6	14.4	0.0	0.0	0.0
05/01/2025 20:00	0.6	14.4	0.0	0.0	0.0
05/01/2025 21:00	0.6	14.5	0.0	0.0	0.0
05/01/2025 22:00	0.6	14.3	0.0	0.0	0.0
05/01/2025 23:00	0.6	14.3	0.0	0.0	0.0
Average/Sum#:	0.7	14.4	0.0	0.0	0.0
Minimum:	0.5	14.3	0.0	0.0	0.0
Maximum:	0.8	14.5	0.0	0.0	0.0
%SI	0.00	0.00	100.00	100.00	100.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
05/02/2025 00:00	0.6	14.3	0.0	0.0	0.0
05/02/2025 01:00	0.6	14.3	0.0	0.0	0.0
05/02/2025 02:00	0.6	14.3	0.0	0.0	0.0
05/02/2025 03:00	0.7	14.3	0.0	0.0	0.0
05/02/2025 04:00	0.6	14.3	0.0	0.0	0.0
05/02/2025 05:00	0.6	14.3	0.0	0.0	0.0
05/02/2025 06:00	0.6	14.3	0.0	0.0	15.5
05/02/2025 07:00	0.6	14.3	0.8	0.9	14.2
05/02/2025 08:00	0.6	14.3	0.8	1.5	14.2
05/02/2025 09:00	0.6	14.3	0.8	1.5	14.2
05/02/2025 10:00	0.6	14.4	0.9	1.4	14.2
05/02/2025 11:00	0.6	14.4	0.8	1.5	14.3
05/02/2025 12:00	0.6	14.4	0.8	1.5	14.3
05/02/2025 13:00	0.5	14.4	0.8	1.5	14.3
05/02/2025 14:00	0.5	14.4	0.8	1.5	14.3
05/02/2025 15:00	0.6	14.9	0.8	1.4	14.4
05/02/2025 16:00	0.0	0.0	0.8	1.5	14.3
05/02/2025 17:00	0.0	0.0	0.8	1.5	14.4
05/02/2025 18:00	0.0	0.0	0.8	1.4	14.3
05/02/2025 19:00	0.0	0.0	0.8	1.5	14.3
05/02/2025 20:00	0.0	0.0	0.8	1.5	14.2
05/02/2025 21:00	0.0	0.0	0.8	1.5	14.2
05/02/2025 22:00	0.0	0.0	0.8	1.5	14.2
05/02/2025 23:00	0.0	0.0	0.8	1.5	14.2
Average/Sum#:	0.6	14.4	0.8	1.4	14.3
Minimum:	0.5	14.3	0.0	0.0	14.2
Maximum:	0.7	14.9	0.9	1.5	15.5
%SI	33.33	33.33	25.00	25.00	25.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
05/03/2025 00:00	0.0	0.0	0.9	1.5	14.2
05/03/2025 01:00	0.0	0.0	0.8	1.5	14.2
05/03/2025 02:00	0.0	0.0	0.9	1.5	14.2
05/03/2025 03:00	0.0	0.0	0.9	1.5	14.2
05/03/2025 04:00	0.0	0.0	0.9	1.5	14.2
05/03/2025 05:00	0.0	0.0	0.9	1.5	14.2
05/03/2025 06:00	0.0	0.0	0.9	1.5	14.2
05/03/2025 07:00	0.0	0.0	0.8	1.5	14.2
05/03/2025 08:00	0.0	0.0	0.8	1.5	14.2
05/03/2025 09:00	0.0	0.0	0.9	1.5	14.2
05/03/2025 10:00	0.0	0.0	0.9	1.5	14.2
05/03/2025 11:00	0.0	0.0	0.8	1.5	14.3
05/03/2025 12:00	0.0	0.0	0.8	1.5	14.3
05/03/2025 13:00	0.0	0.0	0.8	1.5	14.3
05/03/2025 14:00	0.0	0.0	0.8	1.5	14.3
05/03/2025 15:00	0.0	0.0	0.8	1.5	14.3
05/03/2025 16:00	0.0	0.0	0.8	1.5	14.3
05/03/2025 17:00	0.0	0.0	0.8	1.5	14.3
05/03/2025 18:00	0.0	0.0	0.8	1.5	14.3
05/03/2025 19:00	0.0	0.0	0.8	1.5	14.2
05/03/2025 20:00	0.0	0.0	0.9	1.5	14.2
05/03/2025 21:00	0.0	0.0	0.8	1.5	14.2
05/03/2025 22:00	0.0	0.0	0.9	1.5	14.2
05/03/2025 23:00	0.0	0.0	0.9	1.5	14.2
Average/Sum#:	0.0	0.0	0.8	1.5	14.2
Minimum:	0.0	0.0	0.8	1.5	14.2
Maximum:	0.0	0.0	0.9	1.5	14.3
%SI	100.00	100.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
05/04/2025 00:00	0.0	0.0	0.9	1.5	14.2
05/04/2025 01:00	0.0	0.0	0.9	1.5	14.2
05/04/2025 02:00	0.0	0.0	0.9	1.5	14.2
05/04/2025 03:00	0.0	0.0	0.9	1.5	14.2
05/04/2025 04:00	0.0	0.0	0.9	1.5	14.2
05/04/2025 05:00	0.0	0.0	0.9	1.5	14.2
05/04/2025 06:00	0.0	0.0	0.8	1.4	14.3
05/04/2025 07:00	0.0	0.0	0.8	1.5	14.3
05/04/2025 08:00	0.0	0.0	0.9	1.5	14.2
05/04/2025 09:00	0.0	0.0	0.9	1.5	14.3
05/04/2025 10:00	0.0	0.0	0.8	1.5	14.3
05/04/2025 11:00	0.0	0.0	0.9	1.5	14.3
05/04/2025 12:00	0.0	0.0	0.9	1.5	14.3
05/04/2025 13:00	0.0	0.0	0.8	1.5	14.4
05/04/2025 14:00	0.0	0.0	0.8	1.5	14.4
05/04/2025 15:00	0.0	0.0	0.8	1.5	14.4
05/04/2025 16:00	0.0	0.0	0.8	1.5	14.4
05/04/2025 17:00	0.0	0.0	0.8	1.5	14.5
05/04/2025 18:00	0.0	0.0	0.8	1.5	14.4
05/04/2025 19:00	0.0	0.0	0.7	1.5	14.5
05/04/2025 20:00	0.0	0.0	0.7	1.5	14.5
05/04/2025 21:00	0.0	0.0	0.7	1.5	14.5
05/04/2025 22:00	0.0	0.0	0.7	1.5	14.4
05/04/2025 23:00	0.0	0.0	0.9	1.4	14.3
Average/Sum#:	0.0	0.0	0.8	1.5	14.3
Minimum:	0.0	0.0	0.7	1.4	14.2
Maximum:	0.0	0.0	0.9	1.5	14.5
%SI	100.00	100.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
05/05/2025 00:00	0.0	0.0	0.9	1.5	14.3
05/05/2025 01:00	0.0	0.0	0.9	1.5	14.3
05/05/2025 02:00	0.0	0.0	0.9	1.5	14.2
05/05/2025 03:00	0.0	0.0	0.9	1.5	14.2
05/05/2025 04:00	0.0	0.0	0.9	1.5	14.3
05/05/2025 05:00	0.0	0.0	0.9	1.5	14.3
05/05/2025 06:00	0.0	0.0	0.8	1.5	14.4
05/05/2025 07:00	0.0	0.0	0.7	1.0	14.3
05/05/2025 08:00	0.0	0.0	0.6	1.6	14.3
05/05/2025 09:00	0.0	0.0	0.7	1.1	14.4
05/05/2025 10:00	0.0	0.0	0.7	1.5	14.4
05/05/2025 11:00	0.0	0.0	0.7	1.5	14.4
05/05/2025 12:00	0.0	0.0	0.7	1.5	14.4
05/05/2025 13:00	0.0	0.0	0.7	1.5	14.4
05/05/2025 14:00	0.0	0.0	0.7	1.5	14.4
05/05/2025 15:00	0.0	0.0	0.7	1.5	14.4
05/05/2025 16:00	0.0	0.0	0.7	1.5	14.4
05/05/2025 17:00	0.0	0.0	0.7	1.5	14.4
05/05/2025 18:00	0.0	0.0	0.7	1.5	14.5
05/05/2025 19:00	0.0	0.0	0.7	1.5	14.6
05/05/2025 20:00	0.0	0.0	0.6	1.5	14.6
05/05/2025 21:00	0.0	0.0	0.7	1.5	14.5
05/05/2025 22:00	0.0	0.0	0.7	1.5	14.5
05/05/2025 23:00	0.0	0.0	0.7	1.5	14.5
Average/Sum#:	0.0	0.0	0.7	1.5	14.4
Minimum:	0.0	0.0	0.6	1.0	14.2
Maximum:	0.0	0.0	0.9	1.6	14.6
%SI	100.00	100.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
05/06/2025 00:00	0.0	0.0	0.7	1.4	14.4
05/06/2025 01:00	0.0	0.0	0.7	1.5	14.3
05/06/2025 02:00	0.0	0.0	0.7	1.9	14.4
05/06/2025 03:00	0.0	0.0	0.7	1.5	14.4
05/06/2025 04:00	0.0	0.0	0.7	1.5	14.3
05/06/2025 05:00	0.0	0.0	0.6	1.5	14.4
05/06/2025 06:00	0.0	0.0	0.7	1.5	14.3
05/06/2025 07:00	0.0	0.0	0.8	1.5	14.3
05/06/2025 08:00	0.0	0.0	0.7	1.5	14.3
05/06/2025 09:00	0.0	0.0	0.7	1.5	14.4
05/06/2025 10:00	0.0	0.0	0.7	1.5	14.4
05/06/2025 11:00	0.0	0.0	0.7	1.5	14.4
05/06/2025 12:00	0.0	0.0	0.7	1.5	14.4
05/06/2025 13:00	0.0	0.0	0.7	1.5	14.4
05/06/2025 14:00	0.0	0.0	0.7	1.5	14.5
05/06/2025 15:00	0.0	0.0	0.7	1.5	14.5
05/06/2025 16:00	0.0	0.0	0.7	1.5	14.5
05/06/2025 17:00	0.0	0.0	0.7	1.5	14.5
05/06/2025 18:00	0.0	0.0	0.7	1.5	14.6
05/06/2025 19:00	0.0	0.0	0.7	1.5	14.6
05/06/2025 20:00	0.0	0.0	0.6	1.5	14.5
05/06/2025 21:00	0.0	0.0	0.6	1.5	14.5
05/06/2025 22:00	0.0	0.0	0.6	1.5	14.4
05/06/2025 23:00	0.0	0.0	0.7	1.4	14.3
Average/Sum#:	0.0	0.0	0.7	1.5	14.4
Minimum:	0.0	0.0	0.6	1.4	14.3
Maximum:	0.0	0.0	0.8	1.9	14.6
%SI	100.00	100.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
05/07/2025 00:00	0.0	0.0	0.7	1.5	14.3
05/07/2025 01:00	0.0	0.0	0.7	1.5	14.2
05/07/2025 02:00	0.0	0.0	0.8	1.5	14.2
05/07/2025 03:00	0.0	0.0	0.7	1.4	14.3
05/07/2025 04:00	0.0	0.0	0.8	1.3	14.2
05/07/2025 05:00	0.0	0.0	0.8	1.5	14.2
05/07/2025 06:00	0.0	0.0	0.8	1.5	14.2
05/07/2025 07:00	0.0	0.0	0.7	1.5	14.2
05/07/2025 08:00	0.0	18.0	0.7	1.5	14.4
05/07/2025 09:00	0.5	14.3	0.7	1.5	14.3
05/07/2025 10:00	0.5	14.4	0.7	1.5	14.3
05/07/2025 11:00	0.6	14.4	0.7	1.5	14.3
05/07/2025 12:00	0.5	14.4	0.7	1.5	14.3
05/07/2025 13:00	0.6	14.5	0.7	1.5	14.7
05/07/2025 14:00	0.6	14.5	0.0	0.0	0.0
05/07/2025 15:00	0.6	14.5	0.0	0.0	0.0
05/07/2025 16:00	0.6	14.5	0.0	0.0	0.0
05/07/2025 17:00	0.5	14.5	0.0	0.0	0.0
05/07/2025 18:00	0.5	14.4	0.0	0.0	0.0
05/07/2025 19:00	0.5	14.4	0.0	0.0	0.0
05/07/2025 20:00	0.5	14.4	0.0	0.0	0.0
05/07/2025 21:00	0.5	14.4	0.0	0.0	0.0
05/07/2025 22:00	0.5	14.4	0.0	0.0	0.0
05/07/2025 23:00	0.5	14.4	0.0	0.0	0.0
Average/Sum#:	0.5	14.7	0.7	1.5	14.3
Minimum:	0.0	14.3	0.7	1.3	14.2
Maximum:	0.6	18.0	0.8	1.5	14.7
%SI	33.33	33.33	41.67	41.67	41.67

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
05/08/2025 00:00	0.6	14.4	0.0	0.0	0.0
05/08/2025 01:00	0.6	14.3	0.0	0.0	0.0
05/08/2025 02:00	0.6	14.3	0.0	0.0	0.0
05/08/2025 03:00	0.7	14.3	0.0	0.0	0.0
05/08/2025 04:00	0.6	14.3	0.0	0.0	0.0
05/08/2025 05:00	0.6	14.3	0.0	0.0	0.0
05/08/2025 06:00	0.6	14.3	0.0	0.0	0.0
05/08/2025 07:00	0.6	14.4	0.0	0.0	0.0
05/08/2025 08:00	0.6	14.4	0.0	0.0	0.0
05/08/2025 09:00	0.5	14.4	0.0	0.0	0.0
05/08/2025 10:00	0.6	14.5	0.0	0.0	0.0
05/08/2025 11:00	0.6	14.5	0.0	0.0	0.0
05/08/2025 12:00	0.6	14.5	0.0	0.0	0.0
05/08/2025 13:00	0.6	14.5	0.0	0.0	0.0
05/08/2025 14:00	0.6	14.5	0.0	0.0	0.0
05/08/2025 15:00	0.6	14.5	0.0	0.0	0.0
05/08/2025 16:00	0.6	14.6	0.0	0.0	0.0
05/08/2025 17:00	0.5	14.7	0.0	0.0	0.0
05/08/2025 18:00	0.5	14.0	0.0	0.0	0.0
05/08/2025 19:00	0.1	12.7	0.0	0.0	0.0
05/08/2025 20:00	0.1	12.3	0.0	0.0	0.0
05/08/2025 21:00	0.1	11.9	0.0	0.0	0.0
05/08/2025 22:00	0.1	12.4	0.0	0.0	0.0
05/08/2025 23:00	0.4	13.4	0.0	0.0	0.0
Average/Sum#:	0.5	14.0	0.0	0.0	0.0
Minimum:	0.1	11.9	0.0	0.0	0.0
Maximum:	0.7	14.7	0.0	0.0	0.0
%SI	0.00	0.00	100.00	100.00	100.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
05/09/2025 00:00	0.6	14.5	0.0	0.0	0.0
05/09/2025 01:00	0.6	14.5	0.0	0.0	15.8
05/09/2025 02:00	0.6	14.5	0.6	1.3	14.4
05/09/2025 03:00	0.6	14.6	0.6	1.5	14.4
05/09/2025 04:00	0.6	14.6	0.6	1.5	14.4
05/09/2025 05:00	0.7	14.4	0.7	1.4	14.3
05/09/2025 06:00	0.7	14.6	0.7	1.4	14.3
05/09/2025 07:00	0.0	0.0	0.7	1.5	14.3
05/09/2025 08:00	0.0	0.0	0.7	1.5	14.3
05/09/2025 09:00	0.0	0.0	0.7	1.5	14.3
05/09/2025 10:00	0.0	0.0	0.7	1.5	14.4
05/09/2025 11:00	0.0	0.0	0.7	1.5	14.4
05/09/2025 12:00	0.0	0.0	0.7	1.5	14.4
05/09/2025 13:00	0.0	0.0	0.6	1.5	14.4
05/09/2025 14:00	0.0	0.0	0.7	1.5	14.5
05/09/2025 15:00	0.0	0.0	0.6	1.5	14.5
05/09/2025 16:00	0.0	0.0	0.6	1.5	14.5
05/09/2025 17:00	0.0	16.0	0.6	1.5	14.5
05/09/2025 18:00	0.5	14.6	0.7	1.5	14.5
05/09/2025 19:00	0.5	14.6	0.7	1.5	14.5
05/09/2025 20:00	0.6	14.6	0.7	1.5	14.4
05/09/2025 21:00	0.6	14.6	0.6	1.5	14.4
05/09/2025 22:00	0.6	14.6	0.6	1.5	14.4
05/09/2025 23:00	0.6	14.6	0.6	1.5	14.4
Average/Sum#:	0.6	14.7	0.6	1.4	14.5
Minimum:	0.0	14.4	0.0	0.0	14.3
Maximum:	0.7	16.0	0.7	1.5	15.8
%SI	41.67	41.67	4.17	4.17	4.17

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
05/10/2025 00:00	0.6	14.6	0.6	1.5	14.4
05/10/2025 01:00	0.6	14.4	0.7	1.5	14.3
05/10/2025 02:00	0.6	14.5	0.8	1.6	14.3
05/10/2025 03:00	0.0	17.3	0.8	1.4	14.3
05/10/2025 04:00	0.0	0.0	0.8	1.5	14.3
05/10/2025 05:00	0.0	0.0	0.8	1.5	14.2
05/10/2025 06:00	0.0	0.0	0.8	1.5	14.3
05/10/2025 07:00	0.0	0.0	0.8	1.5	14.3
05/10/2025 08:00	0.0	0.0	0.7	1.5	14.3
05/10/2025 09:00	0.0	0.0	0.7	1.5	14.4
05/10/2025 10:00	0.0	0.0	0.7	1.5	14.4
05/10/2025 11:00	0.0	0.0	0.7	1.5	14.5
05/10/2025 12:00	0.0	0.0	0.7	1.5	14.5
05/10/2025 13:00	0.0	0.0	0.7	1.5	14.5
05/10/2025 14:00	0.0	0.0	0.6	1.5	14.5
05/10/2025 15:00	0.0	0.0	0.6	1.5	14.5
05/10/2025 16:00	0.0	0.0	0.7	1.5	14.5
05/10/2025 17:00	0.0	0.0	0.6	1.5	14.5
05/10/2025 18:00	0.0	0.0	0.6	1.5	14.5
05/10/2025 19:00	0.0	16.0	0.6	1.4	14.4
05/10/2025 20:00	0.6	14.6	0.8	1.5	14.4
05/10/2025 21:00	0.6	14.6	0.6	1.5	14.4
05/10/2025 22:00	0.5	14.6	0.6	1.5	14.4
05/10/2025 23:00	0.5	14.5	0.7	1.5	14.3
Average/Sum#:	0.4	15.0	0.7	1.5	14.4
Minimum:	0.0	14.4	0.6	1.4	14.2
Maximum:	0.6	17.3	0.8	1.6	14.5
%SI	62.50	62.50	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
05/11/2025 00:00	0.5	14.6	0.7	1.5	14.4
05/11/2025 01:00	0.0	17.5	0.7	1.5	14.3
05/11/2025 02:00	0.0	0.0	0.7	1.5	14.3
05/11/2025 03:00	0.0	0.0	0.8	1.5	14.3
05/11/2025 04:00	0.0	0.0	0.8	1.5	14.2
05/11/2025 05:00	0.0	0.0	0.8	1.5	14.2
05/11/2025 06:00	0.0	0.0	0.8	1.5	14.2
05/11/2025 07:00	0.0	0.0	0.8	1.5	14.3
05/11/2025 08:00	0.0	0.0	0.8	1.5	14.3
05/11/2025 09:00	0.0	0.0	0.7	1.5	14.3
05/11/2025 10:00	0.0	0.0	0.7	1.5	14.3
05/11/2025 11:00	0.0	0.0	0.7	1.5	14.3
05/11/2025 12:00	0.0	0.0	0.7	1.5	14.4
05/11/2025 13:00	0.0	0.0	0.7	1.5	14.4
05/11/2025 14:00	0.0	0.0	0.7	1.5	14.4
05/11/2025 15:00	0.0	0.0	0.7	1.5	14.3
05/11/2025 16:00	0.0	0.0	0.7	1.5	14.3
05/11/2025 17:00	0.0	0.0	0.7	1.5	14.4
05/11/2025 18:00	0.0	0.0	0.8	1.5	14.3
05/11/2025 19:00	0.0	0.0	0.7	1.5	14.3
05/11/2025 20:00	0.0	0.0	0.7	1.4	14.2
05/11/2025 21:00	0.0	0.0	0.7	1.5	14.2
05/11/2025 22:00	0.0	0.0	0.7	1.4	14.2
05/11/2025 23:00	0.0	0.0	0.8	1.5	14.2
Average/Sum#:	0.3	16.1	0.7	1.5	14.3
Minimum:	0.0	14.6	0.7	1.4	14.2
Maximum:	0.5	17.5	0.8	1.5	14.4
%SI	91.67	91.67	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
05/12/2025 00:00	0.0	0.0	0.8	1.5	14.2
05/12/2025 01:00	0.0	0.0	0.8	1.5	14.2
05/12/2025 02:00	0.0	0.0	0.8	1.5	14.2
05/12/2025 03:00	0.0	0.0	0.8	1.5	14.2
05/12/2025 04:00	0.0	0.0	0.8	1.5	14.2
05/12/2025 05:00	0.0	0.0	0.8	1.5	14.2
05/12/2025 06:00	0.0	0.0	0.8	1.5	14.2
05/12/2025 07:00	0.0	0.0	0.8	1.4	14.2
05/12/2025 08:00	0.0	0.0	0.8	1.5	14.2
05/12/2025 09:00	0.0	0.0	0.7	1.5	14.2
05/12/2025 10:00	0.0	0.0	0.7	1.5	14.2
05/12/2025 11:00	0.0	0.0	0.7	1.5	14.2
05/12/2025 12:00	0.0	0.0	0.7	1.5	14.2
05/12/2025 13:00	0.0	0.0	0.7	1.5	14.3
05/12/2025 14:00	0.0	0.0	0.7	1.5	14.3
05/12/2025 15:00	0.0	0.0	0.8	1.5	14.3
05/12/2025 16:00	0.0	0.0	0.7	1.5	14.3
05/12/2025 17:00	0.0	0.0	0.7	1.5	14.3
05/12/2025 18:00	0.0	0.0	0.7	1.5	14.2
05/12/2025 19:00	0.0	0.0	0.8	1.5	14.2
05/12/2025 20:00	0.0	0.0	0.8	1.5	14.2
05/12/2025 21:00	0.0	0.0	0.8	1.5	14.2
05/12/2025 22:00	0.0	0.0	0.7	1.5	14.2
05/12/2025 23:00	0.0	0.0	0.8	1.5	14.2
Average/Sum#:	0.0	0.0	0.8	1.5	14.2
Minimum:	0.0	0.0	0.7	1.4	14.2
Maximum:	0.0	0.0	0.8	1.5	14.3
%SI	100.00	100.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
05/13/2025 00:00	0.0	0.0	0.8	1.5	14.2
05/13/2025 01:00	0.0	0.0	0.8	1.5	14.2
05/13/2025 02:00	0.0	0.0	0.8	1.5	14.2
05/13/2025 03:00	0.0	0.0	0.8	1.4	14.2
05/13/2025 04:00	0.0	0.0	0.8	1.4	14.2
05/13/2025 05:00	0.0	0.0	0.8	1.4	14.2
05/13/2025 06:00	0.0	0.0	0.8	1.5	14.2
05/13/2025 07:00	0.0	0.0	0.8	1.5	14.2
05/13/2025 08:00	0.0	0.0	0.8	1.5	14.2
05/13/2025 09:00	0.0	0.0	0.8	1.5	14.2
05/13/2025 10:00	0.0	0.0	0.8	1.5	14.2
05/13/2025 11:00	0.0	0.0	0.7	1.5	14.3
05/13/2025 12:00	0.0	0.0	0.7	1.5	14.3
05/13/2025 13:00	0.0	0.0	0.7	1.5	14.3
05/13/2025 14:00	0.0	0.0	0.7	1.5	14.3
05/13/2025 15:00	0.0	0.0	0.7	1.5	14.3
05/13/2025 16:00	0.0	0.0	0.7	1.5	14.3
05/13/2025 17:00	0.0	0.0	0.7	1.5	14.3
05/13/2025 18:00	0.0	0.0	0.8	1.5	14.3
05/13/2025 19:00	0.0	0.0	0.8	1.5	14.3
05/13/2025 20:00	0.0	0.0	0.7	1.5	14.3
05/13/2025 21:00	0.0	0.0	0.8	1.5	14.3
05/13/2025 22:00	0.0	0.0	0.8	1.5	14.2
05/13/2025 23:00	0.0	0.0	0.8	1.5	14.2
Average/Sum#:	0.0	0.0	0.8	1.5	14.2
Minimum:	0.0	0.0	0.7	1.4	14.2
Maximum:	0.0	0.0	0.8	1.5	14.3
%SI	100.00	100.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
05/14/2025 00:00	0.0	0.0	0.8	1.5	14.2
05/14/2025 01:00	0.0	0.0	0.8	1.5	14.2
05/14/2025 02:00	0.0	0.0	0.8	1.5	14.2
05/14/2025 03:00	0.0	0.0	0.8	1.5	14.2
05/14/2025 04:00	0.0	0.0	0.9	1.5	14.2
05/14/2025 05:00	0.0	0.0	0.9	1.4	14.2
05/14/2025 06:00	0.0	0.0	0.9	1.5	14.2
05/14/2025 07:00	0.0	0.0	0.8	1.5	14.2
05/14/2025 08:00	0.0	0.0	0.7	1.5	14.2
05/14/2025 09:00	0.0	0.0	0.7	1.5	14.3
05/14/2025 10:00	0.0	0.0	0.7	1.5	14.3
05/14/2025 11:00	0.0	0.0	0.8	1.5	14.3
05/14/2025 12:00	0.0	0.0	0.7	1.5	14.4
05/14/2025 13:00	0.0	0.0	0.7	1.5	14.4
05/14/2025 14:00	0.0	0.0	0.7	1.5	14.4
05/14/2025 15:00	0.0	0.0	0.7	1.5	14.4
05/14/2025 16:00	0.0	0.0	0.7	1.5	14.4
05/14/2025 17:00	0.0	0.0	0.7	1.5	14.4
05/14/2025 18:00	0.0	0.0	0.7	1.5	14.4
05/14/2025 19:00	0.0	0.0	0.7	1.5	14.4
05/14/2025 20:00	0.0	0.0	0.7	1.5	14.3
05/14/2025 21:00	0.0	0.0	0.8	1.5	14.3
05/14/2025 22:00	0.0	0.0	0.8	1.5	14.3
05/14/2025 23:00	0.0	0.0	0.8	1.5	14.3
Average/Sum#:	0.0	0.0	0.8	1.5	14.3
Minimum:	0.0	0.0	0.7	1.4	14.2
Maximum:	0.0	0.0	0.9	1.5	14.4
%SI	100.00	100.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
05/15/2025 00:00	0.0	0.0	0.8	1.5	14.3
05/15/2025 01:00	0.0	0.0	0.8	1.5	14.2
05/15/2025 02:00	0.0	0.0	0.8	1.5	14.2
05/15/2025 03:00	0.0	0.0	0.8	1.5	14.2
05/15/2025 04:00	0.0	0.0	0.8	1.5	14.2
05/15/2025 05:00	0.0	0.0	0.8	1.5	14.2
05/15/2025 06:00	0.0	0.0	0.8	1.5	14.2
05/15/2025 07:00	0.0	0.0	0.8	1.5	14.3
05/15/2025 08:00	0.0	0.0	0.8	1.5	14.3
05/15/2025 09:00	0.0	0.0	0.8	1.5	14.3
05/15/2025 10:00	0.0	0.0	0.7	1.5	14.3
05/15/2025 11:00	0.0	0.0	0.8	1.5	14.4
05/15/2025 12:00	0.0	0.0	0.7	1.5	14.4
05/15/2025 13:00	0.0	0.0	0.7	1.5	14.4
05/15/2025 14:00	0.0	0.0	0.7	1.5	14.4
05/15/2025 15:00	0.0	0.0	0.7	1.5	14.4
05/15/2025 16:00	0.0	0.0	0.7	1.5	14.4
05/15/2025 17:00	0.0	0.0	0.7	1.5	14.4
05/15/2025 18:00	0.0	0.0	0.7	1.4	14.4
05/15/2025 19:00	0.0	0.0	0.7	1.5	14.3
05/15/2025 20:00	0.0	0.0	0.7	1.5	14.3
05/15/2025 21:00	0.0	0.0	0.8	1.5	14.3
05/15/2025 22:00	0.0	0.0	0.8	1.5	14.3
05/15/2025 23:00	0.0	0.0	0.8	1.5	14.3
Average/Sum#:	0.0	0.0	0.8	1.5	14.3
Minimum:	0.0	0.0	0.7	1.4	14.2
Maximum:	0.0	0.0	0.8	1.5	14.4
%SI	100.00	100.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
05/16/2025 00:00	0.0	0.0	0.7	1.5	14.3
05/16/2025 01:00	0.0	0.0	0.8	1.5	14.3
05/16/2025 02:00	0.0	0.0	0.8	1.5	14.3
05/16/2025 03:00	0.0	0.0	0.8	1.5	14.2
05/16/2025 04:00	0.0	0.0	0.8	1.5	14.2
05/16/2025 05:00	0.0	0.0	0.9	1.5	14.2
05/16/2025 06:00	0.0	0.0	0.8	1.5	14.3
05/16/2025 07:00	0.0	0.0	0.8	1.5	14.3
05/16/2025 08:00	0.0	0.0	0.8	1.5	14.3
05/16/2025 09:00	0.0	0.0	0.8	1.5	14.3
05/16/2025 10:00	0.0	0.0	0.7	1.5	14.3
05/16/2025 11:00	0.0	0.0	0.7	2.6	14.4
05/16/2025 12:00	0.0	0.0	0.7	2.2	14.5
05/16/2025 13:00	0.0	0.0	0.7	1.5	14.6
05/16/2025 14:00	0.0	16.7	0.7	1.5	14.5
05/16/2025 15:00	0.6	14.5	0.6	1.5	14.4
05/16/2025 16:00	0.6	14.5	0.7	1.5	14.4
05/16/2025 17:00	0.6	14.6	0.6	1.5	14.5
05/16/2025 18:00	0.6	14.6	0.7	1.5	14.5
05/16/2025 19:00	0.6	14.4	0.7	1.5	14.3
05/16/2025 20:00	0.6	14.4	0.7	1.5	14.3
05/16/2025 21:00	0.0	16.0	0.7	1.4	14.3
05/16/2025 22:00	0.0	0.0	0.7	1.5	14.4
05/16/2025 23:00	0.0	0.0	0.6	1.5	14.5
Average/Sum#:	0.5	15.0	0.7	1.6	14.4
Minimum:	0.0	14.4	0.6	1.4	14.2
Maximum:	0.6	16.7	0.9	2.6	14.6
%SI	66.67	66.67	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
05/17/2025 00:00	0.0	0.0	0.7	1.5	14.4
05/17/2025 01:00	0.0	0.0	0.8	1.5	14.2
05/17/2025 02:00	0.0	0.0	0.8	1.5	14.2
05/17/2025 03:00	0.0	0.0	0.8	1.4	14.2
05/17/2025 04:00	0.0	0.0	0.7	1.4	14.2
05/17/2025 05:00	0.0	0.0	0.7	1.5	14.2
05/17/2025 06:00	0.0	0.0	0.7	1.4	14.3
05/17/2025 07:00	0.0	0.0	0.7	1.5	14.3
05/17/2025 08:00	0.0	0.0	0.7	1.5	14.3
05/17/2025 09:00	0.0	0.0	0.7	1.5	14.3
05/17/2025 10:00	0.0	0.0	0.7	1.5	14.3
05/17/2025 11:00	0.0	0.0	0.7	1.5	14.4
05/17/2025 12:00	0.0	0.0	0.7	1.6	14.4
05/17/2025 13:00	0.0	0.0	0.7	1.2	14.4
05/17/2025 14:00	0.0	0.0	0.7	1.5	14.4
05/17/2025 15:00	0.0	0.0	0.7	1.5	14.4
05/17/2025 16:00	0.0	0.0	0.7	1.0	14.4
05/17/2025 17:00	0.0	0.0	0.7	1.6	14.4
05/17/2025 18:00	0.0	0.0	0.7	1.4	14.4
05/17/2025 19:00	0.0	0.0	0.7	1.5	14.3
05/17/2025 20:00	0.0	0.0	0.7	1.5	14.3
05/17/2025 21:00	0.0	0.0	0.7	1.5	14.3
05/17/2025 22:00	0.0	0.0	0.8	1.5	14.3
05/17/2025 23:00	0.0	0.0	0.7	1.5	14.3
Average/Sum#:	0.0	0.0	0.7	1.5	14.3
Minimum:	0.0	0.0	0.7	1.0	14.2
Maximum:	0.0	0.0	0.8	1.6	14.4
%SI	100.00	100.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
05/18/2025 00:00	0.0	0.0	0.8	1.5	14.2
05/18/2025 01:00	0.0	0.0	0.8	1.5	14.2
05/18/2025 02:00	0.0	0.0	0.8	1.5	14.2
05/18/2025 03:00	0.0	0.0	0.9	1.5	14.2
05/18/2025 04:00	0.0	0.0	1.1	1.5	14.2
05/18/2025 05:00	0.0	0.0	1.1	1.5	14.2
05/18/2025 06:00	0.0	0.0	0.8	1.5	14.2
05/18/2025 07:00	0.0	0.0	0.8	1.5	14.2
05/18/2025 08:00	0.0	0.0	0.7	1.5	14.3
05/18/2025 09:00	0.0	0.0	0.7	1.5	14.3
05/18/2025 10:00	0.0	0.0	0.7	1.5	14.3
05/18/2025 11:00	0.0	0.0	0.7	1.5	14.4
05/18/2025 12:00	0.0	0.0	0.7	1.5	14.4
05/18/2025 13:00	0.0	0.0	0.7	1.5	14.4
05/18/2025 14:00	0.0	0.0	0.7	1.5	14.4
05/18/2025 15:00	0.0	0.0	0.7	1.5	14.4
05/18/2025 16:00	0.0	0.0	0.7	1.5	14.4
05/18/2025 17:00	0.0	0.0	0.7	1.5	14.4
05/18/2025 18:00	0.0	0.0	0.7	1.5	14.5
05/18/2025 19:00	0.0	0.0	0.7	1.5	14.4
05/18/2025 20:00	0.0	0.0	0.7	1.5	14.3
05/18/2025 21:00	0.0	0.0	0.7	1.5	14.3
05/18/2025 22:00	0.0	0.0	0.8	1.5	14.3
05/18/2025 23:00	0.0	0.0	0.8	1.5	14.3
Average/Sum#:	0.0	0.0	0.8	1.5	14.3
Minimum:	0.0	0.0	0.7	1.5	14.2
Maximum:	0.0	0.0	1.1	1.5	14.5
%SI	100.00	100.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
05/19/2025 00:00	0.0	0.0	0.8	1.5	14.3
05/19/2025 01:00	0.0	0.0	0.8	1.5	14.3
05/19/2025 02:00	0.0	0.0	0.8	1.5	14.3
05/19/2025 03:00	0.0	16.0	0.7	1.4	14.4
05/19/2025 04:00	0.9	14.3	0.8	1.4	14.3
05/19/2025 05:00	1.0	14.3	1.1	1.5	14.2
05/19/2025 06:00	0.0	0.0	0.8	1.5	14.3
05/19/2025 07:00	0.4	12.9	0.4	1.5	13.2
05/19/2025 08:00	0.1	12.6	0.2	1.5	12.8
05/19/2025 09:00	0.1	12.6	0.2	1.5	12.8
05/19/2025 10:00	0.1	12.5	0.1	1.5	12.7
05/19/2025 11:00	0.1	12.4	0.1	1.5	12.7
05/19/2025 12:00	0.1	12.4	0.1	1.5	12.6
05/19/2025 13:00	0.0	12.3	0.1	1.5	12.6
05/19/2025 14:00	0.0	12.3	0.1	1.5	12.6
05/19/2025 15:00	0.0	12.3	0.1	1.5	12.5
05/19/2025 16:00	0.0	12.3	0.1	1.5	12.6
05/19/2025 17:00	0.0	12.3	0.1	1.5	12.5
05/19/2025 18:00	0.0	12.4	0.1	1.5	12.7
05/19/2025 19:00	0.6	14.1	0.8	1.4	14.1
05/19/2025 20:00	0.5	14.3	0.7	1.5	14.2
05/19/2025 21:00	0.5	14.6	0.6	1.5	14.4
05/19/2025 22:00	0.5	14.5	0.6	1.5	14.4
05/19/2025 23:00	0.6	14.5	0.6	1.5	14.4
Average/Sum#:	0.3	13.3	0.5	1.5	13.5
Minimum:	0.0	12.3	0.1	1.4	12.5
Maximum:	1.0	16.0	1.1	1.5	14.4
%SI	16.67	16.67	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
05/20/2025 00:00	0.6	14.5	0.6	1.5	14.4
05/20/2025 01:00	0.6	14.5	0.6	1.5	14.4
05/20/2025 02:00	0.5	14.5	0.6	1.5	14.3
05/20/2025 03:00	1.2	14.3	1.1	1.5	14.2
05/20/2025 04:00	0.5	13.2	0.6	1.5	13.3
05/20/2025 05:00	0.2	12.7	0.3	1.5	12.9
05/20/2025 06:00	0.2	12.8	0.0	0.0	0.0
05/20/2025 07:00	0.1	12.7	0.4	1.5	12.9
05/20/2025 08:00	0.1	12.6	0.4	1.5	12.9
05/20/2025 09:00	0.1	12.5	0.4	1.5	12.9
05/20/2025 10:00	0.1	12.4	0.3	1.5	12.9
05/20/2025 11:00	0.1	12.4	0.4	1.5	13.0
05/20/2025 12:00	0.1	12.4	0.4	1.5	13.0
05/20/2025 13:00	0.0	12.3	0.4	1.5	13.0
05/20/2025 14:00	0.0	12.3	0.4	1.5	13.0
05/20/2025 15:00	0.0	12.3	0.4	1.5	13.0
05/20/2025 16:00	0.4	13.3	0.5	1.5	13.2
05/20/2025 17:00	0.7	13.8	0.9	1.5	13.8
05/20/2025 18:00	0.3	13.0	0.5	1.5	13.2
05/20/2025 19:00	0.1	12.7	0.4	1.5	12.9
05/20/2025 20:00	0.5	13.3	0.4	1.5	13.0
05/20/2025 21:00	0.1	12.4	0.2	1.5	12.5
05/20/2025 22:00	1.2	14.2	0.9	1.5	13.5
05/20/2025 23:00	0.7	14.5	0.9	1.5	14.4
Average/Sum#:	0.4	13.2	0.5	1.5	13.3
Minimum:	0.0	12.3	0.2	1.5	12.5
Maximum:	1.2	14.5	1.1	1.5	14.4
%SI	0.00	0.00	4.17	4.17	4.17

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
05/21/2025 00:00	0.6	14.5	0.9	1.5	14.3
05/21/2025 01:00	0.0	16.7	0.9	1.4	14.3
05/21/2025 02:00	0.0	0.0	1.0	1.6	14.3
05/21/2025 03:00	0.0	0.0	1.0	1.5	14.2
05/21/2025 04:00	0.0	0.0	1.0	1.5	14.2
05/21/2025 05:00	0.0	0.0	1.0	1.5	14.2
05/21/2025 06:00	0.0	0.0	0.9	1.5	14.3
05/21/2025 07:00	0.0	0.0	0.9	1.5	14.3
05/21/2025 08:00	0.0	0.0	0.9	1.5	14.3
05/21/2025 09:00	0.0	0.0	0.9	1.5	14.4
05/21/2025 10:00	0.0	0.0	0.9	1.5	14.4
05/21/2025 11:00	0.0	0.0	0.9	1.5	14.4
05/21/2025 12:00	0.0	0.0	0.9	1.5	14.4
05/21/2025 13:00	0.0	0.0	0.8	1.5	14.4
05/21/2025 14:00	0.0	0.0	0.9	1.5	14.5
05/21/2025 15:00	0.0	0.0	0.8	1.5	14.5
05/21/2025 16:00	0.0	0.0	0.8	1.5	14.5
05/21/2025 17:00	0.0	20.0	0.8	1.5	14.5
05/21/2025 18:00	0.0	14.9	0.8	1.5	14.4
05/21/2025 19:00	0.5	14.6	0.8	1.5	14.4
05/21/2025 20:00	0.6	14.5	0.8	1.5	14.3
05/21/2025 21:00	0.6	14.4	0.9	1.5	14.3
05/21/2025 22:00	0.6	14.7	0.9	1.5	14.4
05/21/2025 23:00	0.0	0.0	0.9	1.5	14.3
Average/Sum#:	0.4	15.5	0.9	1.5	14.4
Minimum:	0.0	14.4	0.8	1.4	14.2
Maximum:	0.6	20.0	1.0	1.6	14.5
%SI	66.67	66.67	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
05/22/2025 00:00	0.0	0.0	0.9	1.5	14.3
05/22/2025 01:00	0.0	0.0	0.9	1.5	14.3
05/22/2025 02:00	0.0	0.0	0.9	1.4	14.3
05/22/2025 03:00	0.0	0.0	0.9	1.5	14.2
05/22/2025 04:00	0.0	0.0	1.0	1.5	14.2
05/22/2025 05:00	0.0	0.0	0.9	1.5	14.2
05/22/2025 06:00	0.0	0.0	0.9	1.5	14.2
05/22/2025 07:00	0.0	0.0	0.9	1.5	14.3
05/22/2025 08:00	0.0	0.0	0.9	1.5	14.3
05/22/2025 09:00	0.0	0.0	0.9	1.5	14.3
05/22/2025 10:00	0.0	0.0	0.9	1.5	14.3
05/22/2025 11:00	0.0	0.0	0.9	1.5	14.4
05/22/2025 12:00	0.0	0.0	0.9	1.5	14.4
05/22/2025 13:00	0.0	0.0	0.9	1.5	14.4
05/22/2025 14:00	0.0	0.0	0.9	1.5	14.4
05/22/2025 15:00	0.0	0.0	0.9	1.5	14.4
05/22/2025 16:00	0.0	0.0	0.9	1.5	14.4
05/22/2025 17:00	0.0	0.0	0.9	1.5	14.4
05/22/2025 18:00	0.0	0.0	0.9	1.5	14.4
05/22/2025 19:00	0.0	0.0	0.9	1.5	14.3
05/22/2025 20:00	0.0	0.0	0.9	1.5	14.3
05/22/2025 21:00	0.0	0.0	0.9	1.5	14.3
05/22/2025 22:00	0.0	0.0	0.9	1.5	14.2
05/22/2025 23:00	0.0	0.0	0.9	1.5	14.2
Average/Sum#:	0.0	0.0	0.9	1.5	14.3
Minimum:	0.0	0.0	0.9	1.4	14.2
Maximum:	0.0	0.0	1.0	1.5	14.4
%SI	100.00	100.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
05/23/2025 00:00	0.0	0.0	0.9	1.5	14.2
05/23/2025 01:00	0.0	0.0	0.9	1.5	14.2
05/23/2025 02:00	0.0	0.0	0.9	1.5	14.2
05/23/2025 03:00	0.0	0.0	1.0	1.5	14.2
05/23/2025 04:00	0.0	0.0	1.0	1.5	14.2
05/23/2025 05:00	0.0	0.0	1.0	1.5	14.2
05/23/2025 06:00	0.0	0.0	0.9	1.5	14.2
05/23/2025 07:00	0.0	0.0	1.0	1.5	14.2
05/23/2025 08:00	0.0	0.0	0.9	1.5	14.2
05/23/2025 09:00	0.0	0.0	0.9	1.5	14.2
05/23/2025 10:00	0.0	0.0	0.9	1.5	14.3
05/23/2025 11:00	0.0	0.0	0.9	1.5	14.3
05/23/2025 12:00	0.0	0.0	0.9	1.5	14.3
05/23/2025 13:00	0.0	0.0	0.9	1.5	14.3
05/23/2025 14:00	0.0	0.0	0.9	1.5	14.3
05/23/2025 15:00	0.0	0.0	0.9	1.5	14.4
05/23/2025 16:00	0.0	0.0	0.9	1.5	14.4
05/23/2025 17:00	0.0	0.0	0.9	1.5	14.4
05/23/2025 18:00	0.0	0.0	0.8	1.5	14.4
05/23/2025 19:00	0.0	0.0	0.9	1.5	14.3
05/23/2025 20:00	0.0	0.0	0.9	1.5	14.3
05/23/2025 21:00	0.0	0.0	0.9	1.4	14.4
05/23/2025 22:00	0.0	0.0	0.8	1.5	14.3
05/23/2025 23:00	0.0	0.0	0.8	1.5	14.4
Average/Sum#:	0.0	0.0	0.9	1.5	14.3
Minimum:	0.0	0.0	0.8	1.4	14.2
Maximum:	0.0	0.0	1.0	1.5	14.4
%SI	100.00	100.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
05/24/2025 00:00	0.0	0.0	0.8	1.4	14.3
05/24/2025 01:00	0.0	0.0	0.9	1.5	14.3
05/24/2025 02:00	0.0	0.0	1.0	1.5	14.2
05/24/2025 03:00	0.0	0.0	1.0	1.5	14.2
05/24/2025 04:00	0.0	0.0	1.0	1.5	14.2
05/24/2025 05:00	0.0	0.0	1.0	1.5	14.2
05/24/2025 06:00	0.0	0.0	0.9	1.5	14.2
05/24/2025 07:00	0.0	0.0	0.9	1.5	14.2
05/24/2025 08:00	0.0	0.0	0.9	1.5	14.2
05/24/2025 09:00	0.0	0.0	0.9	1.5	14.3
05/24/2025 10:00	0.0	0.0	0.9	1.5	14.3
05/24/2025 11:00	0.0	0.0	0.9	1.5	14.3
05/24/2025 12:00	0.0	0.0	0.8	1.5	14.4
05/24/2025 13:00	0.0	0.0	0.9	1.5	14.4
05/24/2025 14:00	0.0	0.0	0.8	1.5	14.4
05/24/2025 15:00	0.0	0.0	0.9	1.5	14.4
05/24/2025 16:00	0.0	0.0	0.9	1.5	14.4
05/24/2025 17:00	0.0	0.0	0.8	1.5	14.4
05/24/2025 18:00	0.0	0.0	0.8	1.5	14.4
05/24/2025 19:00	0.0	0.0	0.9	1.5	14.3
05/24/2025 20:00	0.0	0.0	0.9	1.5	14.3
05/24/2025 21:00	0.0	0.0	0.9	1.5	14.2
05/24/2025 22:00	0.0	0.0	0.9	1.5	14.2
05/24/2025 23:00	0.0	0.0	0.9	1.5	14.2
Average/Sum#:	0.0	0.0	0.9	1.5	14.3
Minimum:	0.0	0.0	0.8	1.4	14.2
Maximum:	0.0	0.0	1.0	1.5	14.4
%SI	100.00	100.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
05/25/2025 00:00	0.0	0.0	0.9	1.5	14.2
05/25/2025 01:00	0.0	0.0	0.9	1.5	14.2
05/25/2025 02:00	0.0	0.0	0.9	1.5	14.2
05/25/2025 03:00	0.0	0.0	0.9	1.4	14.2
05/25/2025 04:00	0.0	0.0	0.9	1.4	14.2
05/25/2025 05:00	0.0	0.0	0.9	1.3	14.2
05/25/2025 06:00	0.0	0.0	0.9	1.5	14.2
05/25/2025 07:00	0.0	0.0	0.9	1.5	14.2
05/25/2025 08:00	0.0	0.0	0.9	1.5	14.2
05/25/2025 09:00	0.0	0.0	0.9	1.5	14.2
05/25/2025 10:00	0.0	0.0	0.9	1.5	14.3
05/25/2025 11:00	0.0	0.0	0.9	1.5	14.3
05/25/2025 12:00	0.0	0.0	0.9	1.5	14.3
05/25/2025 13:00	0.0	0.0	0.8	1.5	14.3
05/25/2025 14:00	0.0	0.0	0.8	1.5	14.3
05/25/2025 15:00	0.0	0.0	0.8	1.5	14.3
05/25/2025 16:00	0.0	0.0	0.8	1.5	14.3
05/25/2025 17:00	0.0	0.0	0.9	1.5	14.3
05/25/2025 18:00	0.0	0.0	0.9	1.5	14.3
05/25/2025 19:00	0.0	0.0	0.9	1.5	14.3
05/25/2025 20:00	0.0	0.0	0.9	1.5	14.3
05/25/2025 21:00	0.0	0.0	0.9	1.5	14.2
05/25/2025 22:00	0.0	0.0	0.9	1.5	14.2
05/25/2025 23:00	0.0	0.0	0.9	1.5	14.2
Average/Sum#:	0.0	0.0	0.9	1.5	14.2
Minimum:	0.0	0.0	0.8	1.3	14.2
Maximum:	0.0	0.0	0.9	1.5	14.3
%SI	100.00	100.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
05/26/2025 00:00	0.0	0.0	0.9	1.5	14.2
05/26/2025 01:00	0.0	0.0	0.9	1.5	14.2
05/26/2025 02:00	0.0	0.0	0.9	1.5	14.2
05/26/2025 03:00	0.0	0.0	0.9	1.5	14.2
05/26/2025 04:00	0.0	0.0	0.9	1.5	14.2
05/26/2025 05:00	0.0	0.0	0.9	1.5	14.2
05/26/2025 06:00	0.0	0.0	0.9	1.5	14.2
05/26/2025 07:00	0.0	0.0	0.9	1.5	14.2
05/26/2025 08:00	0.0	0.0	0.9	1.5	14.2
05/26/2025 09:00	0.0	0.0	0.9	1.5	14.3
05/26/2025 10:00	0.0	0.0	0.9	1.5	14.3
05/26/2025 11:00	0.0	0.0	0.9	1.5	14.3
05/26/2025 12:00	0.0	0.0	0.9	1.5	14.3
05/26/2025 13:00	0.0	0.0	0.8	1.5	14.3
05/26/2025 14:00	0.0	0.0	0.9	1.5	14.3
05/26/2025 15:00	0.0	0.0	0.8	1.5	14.3
05/26/2025 16:00	0.0	0.0	0.8	1.5	14.3
05/26/2025 17:00	0.0	0.0	0.8	1.5	14.4
05/26/2025 18:00	0.0	0.0	0.9	1.4	14.2
05/26/2025 19:00	0.0	0.0	0.8	1.5	14.3
05/26/2025 20:00	0.0	0.0	0.9	1.5	14.3
05/26/2025 21:00	0.0	0.0	0.9	1.5	14.3
05/26/2025 22:00	0.0	0.0	0.9	1.5	14.3
05/26/2025 23:00	0.0	0.0	0.9	1.5	14.2
Average/Sum#:	0.0	0.0	0.9	1.5	14.3
Minimum:	0.0	0.0	0.8	1.4	14.2
Maximum:	0.0	0.0	0.9	1.5	14.4
%SI	100.00	100.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
05/27/2025 00:00	0.0	0.0	0.9	1.5	14.2
05/27/2025 01:00	0.0	0.0	0.9	1.5	14.2
05/27/2025 02:00	0.0	0.0	1.0	1.5	14.2
05/27/2025 03:00	0.0	0.0	1.0	1.5	14.2
05/27/2025 04:00	0.0	0.0	1.0	1.5	14.2
05/27/2025 05:00	0.0	0.0	1.0	1.5	14.2
05/27/2025 06:00	0.0	0.0	0.9	1.5	14.2
05/27/2025 07:00	0.0	0.0	0.9	1.5	14.2
05/27/2025 08:00	0.0	0.0	0.9	1.5	14.3
05/27/2025 09:00	0.0	0.0	0.9	1.5	14.3
05/27/2025 10:00	0.0	0.0	0.8	1.5	14.4
05/27/2025 11:00	0.0	0.0	0.7	1.5	14.4
05/27/2025 12:00	0.0	0.0	0.9	1.5	14.4
05/27/2025 13:00	0.0	0.0	0.8	1.5	14.4
05/27/2025 14:00	0.0	0.0	0.7	1.5	14.5
05/27/2025 15:00	0.0	0.0	0.7	1.5	14.5
05/27/2025 16:00	0.0	0.0	0.8	1.5	14.3
05/27/2025 17:00	0.0	0.0	0.7	1.5	14.4
05/27/2025 18:00	0.0	0.0	0.7	1.5	14.5
05/27/2025 19:00	0.0	0.0	0.7	1.5	14.4
05/27/2025 20:00	0.0	0.0	0.7	1.5	14.4
05/27/2025 21:00	0.0	0.0	0.7	1.5	14.5
05/27/2025 22:00	0.0	0.0	0.7	1.5	14.5
05/27/2025 23:00	0.0	0.0	0.7	1.5	14.5
Average/Sum#:	0.0	0.0	0.8	1.5	14.3
Minimum:	0.0	0.0	0.7	1.5	14.2
Maximum:	0.0	0.0	1.0	1.5	14.5
%SI	100.00	100.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
05/28/2025 00:00	0.0	0.0	0.7	1.5	14.4
05/28/2025 01:00	0.0	0.0	0.7	1.5	14.4
05/28/2025 02:00	0.0	0.0	0.7	1.5	14.4
05/28/2025 03:00	0.0	0.0	0.8	1.5	14.4
05/28/2025 04:00	0.0	0.0	0.8	1.4	14.3
05/28/2025 05:00	0.0	0.0	0.9	1.4	14.2
05/28/2025 06:00	0.0	0.0	0.9	1.5	14.2
05/28/2025 07:00	0.0	0.0	0.9	1.5	14.2
05/28/2025 08:00	0.0	0.0	0.9	1.5	14.2
05/28/2025 09:00	0.0	0.0	0.9	1.5	14.3
05/28/2025 10:00	0.0	0.0	0.9	1.5	14.3
05/28/2025 11:00	0.0	0.0	0.9	1.5	14.4
05/28/2025 12:00	0.0	0.0	0.8	1.5	14.4
05/28/2025 13:00	0.0	0.0	0.9	1.5	14.4
05/28/2025 14:00	0.0	0.0	0.8	1.5	14.4
05/28/2025 15:00	0.0	0.0	0.8	1.5	14.4
05/28/2025 16:00	0.0	0.0	0.8	1.5	14.4
05/28/2025 17:00	0.0	0.0	0.9	1.5	14.4
05/28/2025 18:00	0.0	0.0	0.8	1.4	14.5
05/28/2025 19:00	0.0	0.0	0.9	1.5	14.3
05/28/2025 20:00	0.0	0.0	0.9	1.5	14.3
05/28/2025 21:00	0.0	0.0	0.9	1.5	14.3
05/28/2025 22:00	0.0	0.0	0.9	1.5	14.3
05/28/2025 23:00	0.0	0.0	0.9	1.5	14.3
Average/Sum#:	0.0	0.0	0.8	1.5	14.3
Minimum:	0.0	0.0	0.7	1.4	14.2
Maximum:	0.0	0.0	0.9	1.5	14.5
%SI	100.00	100.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
05/29/2025 00:00	0.0	0.0	0.9	1.5	14.2
05/29/2025 01:00	0.0	0.0	0.9	1.5	14.2
05/29/2025 02:00	0.0	0.0	0.9	1.5	14.2
05/29/2025 03:00	0.0	0.0	0.9	1.5	14.2
05/29/2025 04:00	0.0	0.0	0.9	1.5	14.3
05/29/2025 05:00	0.0	0.0	0.9	1.4	14.3
05/29/2025 06:00	0.0	0.0	0.9	1.5	14.2
05/29/2025 07:00	0.0	0.0	0.9	1.5	14.3
05/29/2025 08:00	0.0	0.0	0.9	1.5	14.3
05/29/2025 09:00	0.0	0.0	0.9	1.5	14.3
05/29/2025 10:00	0.0	0.0	0.9	1.5	14.3
05/29/2025 11:00	0.0	0.0	0.8	1.5	14.4
05/29/2025 12:00	0.0	0.0	0.8	1.5	14.4
05/29/2025 13:00	0.0	0.0	0.9	1.5	14.4
05/29/2025 14:00	0.0	0.0	0.8	1.5	14.4
05/29/2025 15:00	0.0	0.0	0.8	1.5	14.4
05/29/2025 16:00	0.0	0.0	0.8	1.5	14.4
05/29/2025 17:00	0.0	0.0	0.8	1.5	14.5
05/29/2025 18:00	0.0	0.0	0.8	1.5	14.4
05/29/2025 19:00	0.0	0.0	0.8	1.5	14.4
05/29/2025 20:00	0.0	0.0	0.9	1.5	14.4
05/29/2025 21:00	0.0	0.0	0.9	1.5	14.3
05/29/2025 22:00	0.0	0.0	0.9	1.5	14.3
05/29/2025 23:00	0.0	0.0	0.9	1.5	14.3
Average/Sum#:	0.0	0.0	0.9	1.5	14.3
Minimum:	0.0	0.0	0.8	1.4	14.2
Maximum:	0.0	0.0	0.9	1.5	14.5
%SI	100.00	100.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
05/30/2025 00:00	0.0	0.0	0.9	1.5	14.3
05/30/2025 01:00	0.0	0.0	0.9	1.5	14.3
05/30/2025 02:00	0.0	0.0	0.9	1.5	14.3
05/30/2025 03:00	0.0	0.0	1.0	1.5	14.3
05/30/2025 04:00	0.0	0.0	0.9	1.5	14.3
05/30/2025 05:00	0.0	0.0	0.9	1.5	14.3
05/30/2025 06:00	0.0	0.0	0.9	1.5	14.3
05/30/2025 07:00	0.0	0.0	0.9	1.5	14.3
05/30/2025 08:00	0.0	0.0	0.9	1.5	14.3
05/30/2025 09:00	0.0	0.0	0.9	1.5	14.4
05/30/2025 10:00	0.0	0.0	0.8	1.5	14.4
05/30/2025 11:00	0.0	0.0	0.8	1.5	14.4
05/30/2025 12:00	0.0	0.0	0.8	1.5	14.5
05/30/2025 13:00	0.0	0.0	0.8	1.5	14.5
05/30/2025 14:00	0.0	0.0	0.7	1.5	14.4
05/30/2025 15:00	0.0	0.0	0.8	1.5	14.4
05/30/2025 16:00	0.0	17.0	0.8	1.5	14.4
05/30/2025 17:00	0.5	14.4	0.7	1.5	14.4
05/30/2025 18:00	0.5	14.5	0.7	1.5	14.4
05/30/2025 19:00	0.6	14.5	0.7	1.5	14.4
05/30/2025 20:00	0.6	14.6	0.7	1.5	14.5
05/30/2025 21:00	0.6	14.5	0.7	1.5	14.5
05/30/2025 22:00	0.6	14.4	0.8	1.5	14.3
05/30/2025 23:00	0.6	14.5	0.8	1.5	14.3
Average/Sum#:	0.5	14.8	0.8	1.5	14.4
Minimum:	0.0	14.4	0.7	1.5	14.3
Maximum:	0.6	17.0	1.0	1.5	14.5
%SI	66.67	66.67	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
05/31/2025 00:00	0.6	14.3	0.9	1.5	14.2
05/31/2025 01:00	0.6	14.5	0.8	1.5	14.3
05/31/2025 02:00	0.0	16.7	0.8	1.1	14.3
05/31/2025 03:00	0.0	0.0	0.9	1.5	14.3
05/31/2025 04:00	0.0	0.0	0.9	1.5	14.3
05/31/2025 05:00	0.0	0.0	0.9	1.5	14.3
05/31/2025 06:00	0.0	0.0	0.9	1.5	14.3
05/31/2025 07:00	0.0	0.0	0.9	1.5	14.4
05/31/2025 08:00	0.0	0.0	0.8	1.5	14.4
05/31/2025 09:00	0.0	0.0	0.8	1.5	14.4
05/31/2025 10:00	0.0	0.0	0.8	1.5	14.4
05/31/2025 11:00	0.0	0.0	0.8	1.5	14.5
05/31/2025 12:00	0.0	0.0	0.8	1.5	14.5
05/31/2025 13:00	0.0	0.0	0.8	1.5	14.5
05/31/2025 14:00	0.0	0.0	0.8	1.5	14.5
05/31/2025 15:00	0.0	0.0	0.7	1.5	14.5
05/31/2025 16:00	0.0	0.0	0.8	1.5	14.6
05/31/2025 17:00	0.0	0.0	0.7	1.5	14.4
05/31/2025 18:00	0.0	0.0	0.7	1.5	14.5
05/31/2025 19:00	0.0	0.0	0.7	1.5	14.5
05/31/2025 20:00	0.0	0.0	0.7	1.5	14.5
05/31/2025 21:00	0.0	0.0	0.8	1.5	14.4
05/31/2025 22:00	0.0	0.0	0.8	1.5	14.3
05/31/2025 23:00	0.0	0.0	0.9	1.5	14.2
Average/Sum#:	0.4	15.2	0.8	1.5	14.4
Minimum:	0.0	14.3	0.7	1.1	14.2
Maximum:	0.6	16.7	0.9	1.5	14.6
%SI	87.50	87.50	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
06/01/2025 00:00	0.0	0.0	0.9	1.5	14.3
06/01/2025 01:00	0.0	0.0	0.9	1.5	14.3
06/01/2025 02:00	0.0	0.0	0.9	1.6	14.3
06/01/2025 03:00	0.0	0.0	0.9	1.5	14.3
06/01/2025 04:00	0.0	0.0	0.9	1.5	14.3
06/01/2025 05:00	0.0	0.0	0.9	1.5	14.3
06/01/2025 06:00	0.0	0.0	0.9	1.5	14.3
06/01/2025 07:00	0.0	0.0	0.9	1.5	14.3
06/01/2025 08:00	0.0	0.0	0.9	1.5	14.3
06/01/2025 09:00	0.0	0.0	0.9	1.5	14.4
06/01/2025 10:00	0.0	0.0	0.8	1.5	14.4
06/01/2025 11:00	0.0	0.0	0.7	1.5	14.4
06/01/2025 12:00	0.0	0.0	0.8	1.5	14.4
06/01/2025 13:00	0.0	0.0	0.8	1.5	14.4
06/01/2025 14:00	0.0	0.0	0.7	1.5	14.4
06/01/2025 15:00	0.0	0.0	0.8	1.5	14.4
06/01/2025 16:00	0.0	0.0	0.8	1.5	14.4
06/01/2025 17:00	0.0	0.0	0.9	1.5	14.4
06/01/2025 18:00	0.0	0.0	0.8	1.5	14.3
06/01/2025 19:00	0.0	0.0	0.9	1.5	14.3
06/01/2025 20:00	0.0	0.0	0.9	1.5	14.3
06/01/2025 21:00	0.0	0.0	0.9	1.5	14.3
06/01/2025 22:00	0.0	0.0	0.9	1.5	14.3
06/01/2025 23:00	0.0	0.0	0.9	1.5	14.3
Average/Sum#:	0.0	0.0	0.9	1.5	14.3
Minimum:	0.0	0.0	0.7	1.5	14.3
Maximum:	0.0	0.0	0.9	1.6	14.4
%SI	100.00	100.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
06/02/2025 00:00	0.0	0.0	0.9	1.5	14.2
06/02/2025 01:00	0.0	0.0	0.9	1.5	14.3
06/02/2025 02:00	0.0	0.0	0.9	1.5	14.2
06/02/2025 03:00	0.0	0.0	0.9	1.5	14.2
06/02/2025 04:00	0.0	0.0	0.8	1.5	14.3
06/02/2025 05:00	0.0	0.0	0.8	1.5	14.3
06/02/2025 06:00	0.0	0.0	0.9	1.5	14.2
06/02/2025 07:00	0.0	0.0	0.9	1.5	14.3
06/02/2025 08:00	0.0	0.0	0.9	1.5	14.3
06/02/2025 09:00	0.0	0.0	0.9	1.5	14.3
06/02/2025 10:00	0.0	0.0	0.9	1.5	14.3
06/02/2025 11:00	0.0	0.0	0.9	1.5	14.4
06/02/2025 12:00	0.0	0.0	0.8	1.5	14.4
06/02/2025 13:00	0.0	0.0	0.8	1.5	14.4
06/02/2025 14:00	0.0	0.0	0.8	1.4	14.4
06/02/2025 15:00	0.0	0.0	0.8	1.5	14.4
06/02/2025 16:00	0.0	0.0	0.7	1.5	14.5
06/02/2025 17:00	0.0	0.0	0.7	1.5	14.4
06/02/2025 18:00	0.0	0.0	0.7	1.5	14.5
06/02/2025 19:00	0.0	0.0	0.7	1.5	14.4
06/02/2025 20:00	0.0	0.0	0.7	1.5	14.4
06/02/2025 21:00	0.0	0.0	0.8	1.5	14.3
06/02/2025 22:00	0.0	0.0	0.8	1.5	14.4
06/02/2025 23:00	0.0	0.0	0.8	1.4	14.3
Average/Sum#:	0.0	0.0	0.8	1.5	14.3
Minimum:	0.0	0.0	0.7	1.4	14.2
Maximum:	0.0	0.0	0.9	1.5	14.5
%SI	100.00	100.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
06/03/2025 00:00	0.0	0.0	0.9	1.5	14.3
06/03/2025 01:00	0.0	0.0	0.9	1.5	14.2
06/03/2025 02:00	0.0	0.0	0.9	1.5	14.2
06/03/2025 03:00	0.0	0.0	1.0	1.5	14.2
06/03/2025 04:00	0.0	0.0	0.9	1.5	14.2
06/03/2025 05:00	0.0	0.0	0.9	1.5	14.2
06/03/2025 06:00	0.0	0.0	0.9	1.5	14.3
06/03/2025 07:00	0.0	0.0	0.9	1.5	14.3
06/03/2025 08:00	0.0	0.0	0.8	1.5	14.3
06/03/2025 09:00	0.0	0.0	0.8	1.5	14.4
06/03/2025 10:00	0.0	19.3	0.8	1.5	14.4
06/03/2025 11:00	0.5	14.5	0.8	1.4	14.3
06/03/2025 12:00	0.5	14.3	0.8	1.5	14.3
06/03/2025 13:00	0.6	14.6	0.7	1.5	14.4
06/03/2025 14:00	0.5	14.5	0.7	1.5	14.4
06/03/2025 15:00	0.5	14.6	0.7	1.5	14.4
06/03/2025 16:00	0.0	17.1	0.8	1.4	14.3
06/03/2025 17:00	0.0	0.0	0.8	1.5	14.4
06/03/2025 18:00	0.0	0.0	0.8	1.5	14.4
06/03/2025 19:00	0.0	0.0	0.8	1.5	14.3
06/03/2025 20:00	0.0	0.0	0.8	1.5	14.3
06/03/2025 21:00	0.0	0.0	0.8	1.5	14.3
06/03/2025 22:00	0.0	0.0	0.9	1.5	14.3
06/03/2025 23:00	0.0	0.0	0.9	1.5	14.3
Average/Sum#:	0.4	15.6	0.8	1.5	14.3
Minimum:	0.0	14.3	0.7	1.4	14.2
Maximum:	0.6	19.3	1.0	1.5	14.4
%SI	70.83	70.83	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
06/04/2025 00:00	0.0	0.0	0.9	1.5	14.3
06/04/2025 01:00	0.0	0.0	0.9	1.5	14.3
06/04/2025 02:00	0.0	0.0	0.9	1.5	14.3
06/04/2025 03:00	0.0	0.0	0.9	1.5	14.3
06/04/2025 04:00	0.0	0.0	0.9	1.4	14.3
06/04/2025 05:00	0.0	0.0	0.9	1.5	14.3
06/04/2025 06:00	0.0	0.0	0.9	1.5	14.3
06/04/2025 07:00	0.0	0.0	0.9	1.5	14.3
06/04/2025 08:00	0.0	0.0	0.9	1.5	14.3
06/04/2025 09:00	0.0	0.0	0.8	1.5	14.3
06/04/2025 10:00	0.0	0.0	0.8	1.5	14.4
06/04/2025 11:00	0.0	0.0	0.8	1.3	14.4
06/04/2025 12:00	0.0	0.0	0.8	1.2	14.4
06/04/2025 13:00	0.0	0.0	0.8	1.5	14.4
06/04/2025 14:00	0.0	0.0	0.8	1.5	14.4
06/04/2025 15:00	0.0	0.0	0.8	1.5	14.5
06/04/2025 16:00	0.0	0.0	0.8	1.5	14.5
06/04/2025 17:00	0.0	0.0	0.8	1.5	14.5
06/04/2025 18:00	0.0	0.0	0.8	1.5	14.4
06/04/2025 19:00	0.0	0.0	0.8	1.5	14.4
06/04/2025 20:00	0.0	0.0	0.8	1.5	14.3
06/04/2025 21:00	0.0	0.0	0.9	1.5	14.3
06/04/2025 22:00	0.0	0.0	0.8	1.5	14.3
06/04/2025 23:00	0.0	0.0	0.8	1.5	14.3
Average/Sum#:	0.0	0.0	0.8	1.5	14.4
Minimum:	0.0	0.0	0.8	1.2	14.3
Maximum:	0.0	0.0	0.9	1.5	14.5
%SI	100.00	100.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
06/05/2025 00:00	0.0	0.0	0.9	1.5	14.2
06/05/2025 01:00	0.0	0.0	0.9	1.5	14.2
06/05/2025 02:00	0.0	0.0	0.9	1.5	14.2
06/05/2025 03:00	0.0	0.0	0.9	1.5	14.2
06/05/2025 04:00	0.0	0.0	0.9	1.5	14.2
06/05/2025 05:00	0.0	0.0	0.9	1.5	14.2
06/05/2025 06:00	0.0	0.0	0.9	1.5	14.2
06/05/2025 07:00	0.0	0.0	0.9	1.5	14.2
06/05/2025 08:00	0.0	0.0	0.9	1.5	14.3
06/05/2025 09:00	0.0	0.0	0.8	1.5	14.3
06/05/2025 10:00	0.0	0.0	0.8	1.5	14.3
06/05/2025 11:00	0.0	0.0	0.8	1.5	14.3
06/05/2025 12:00	0.0	0.0	0.8	1.5	14.3
06/05/2025 13:00	0.0	0.0	0.8	1.5	14.4
06/05/2025 14:00	0.0	0.0	0.8	1.5	14.4
06/05/2025 15:00	0.0	0.0	0.8	1.5	14.4
06/05/2025 16:00	0.0	0.0	0.8	1.5	14.4
06/05/2025 17:00	0.0	0.0	0.7	1.5	14.4
06/05/2025 18:00	0.0	0.0	0.8	1.5	14.3
06/05/2025 19:00	0.0	0.0	0.8	1.5	14.3
06/05/2025 20:00	0.0	0.0	0.8	1.5	14.3
06/05/2025 21:00	0.0	0.0	0.8	1.5	14.3
06/05/2025 22:00	0.0	0.0	0.8	1.5	14.2
06/05/2025 23:00	0.0	0.0	0.8	1.4	14.3
Average/Sum#:	0.0	0.0	0.8	1.5	14.3
Minimum:	0.0	0.0	0.7	1.4	14.2
Maximum:	0.0	0.0	0.9	1.5	14.4
%SI	100.00	100.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
06/06/2025 00:00	0.0	0.0	0.9	1.5	14.2
06/06/2025 01:00	0.0	0.0	0.9	1.5	14.2
06/06/2025 02:00	0.0	0.0	0.9	1.5	14.2
06/06/2025 03:00	0.0	0.0	0.9	1.5	14.2
06/06/2025 04:00	0.0	0.0	0.9	1.5	14.2
06/06/2025 05:00	0.0	0.0	0.8	1.5	14.2
06/06/2025 06:00	0.0	0.0	0.8	1.5	14.2
06/06/2025 07:00	0.0	0.0	0.8	1.5	14.2
06/06/2025 08:00	0.0	0.0	0.8	1.5	14.2
06/06/2025 09:00	0.0	0.0	0.8	1.5	14.3
06/06/2025 10:00	0.0	0.0	0.8	1.5	14.3
06/06/2025 11:00	0.0	0.0	0.8	1.5	14.4
06/06/2025 12:00	0.0	0.0	0.8	1.5	14.4
06/06/2025 13:00	0.0	0.0	0.8	1.4	14.4
06/06/2025 14:00	0.0	0.0	0.8	1.5	14.3
06/06/2025 15:00	0.0	0.0	0.7	1.5	14.4
06/06/2025 16:00	0.0	0.0	0.8	1.5	14.5
06/06/2025 17:00	0.0	0.0	0.8	1.5	14.5
06/06/2025 18:00	0.0	0.0	0.7	1.4	14.4
06/06/2025 19:00	0.0	0.0	0.8	1.5	14.4
06/06/2025 20:00	0.0	0.0	0.8	1.5	14.3
06/06/2025 21:00	0.0	0.0	0.8	1.5	14.3
06/06/2025 22:00	0.0	0.0	0.9	1.5	14.3
06/06/2025 23:00	0.0	0.0	0.8	1.5	14.3
Average/Sum#:	0.0	0.0	0.8	1.5	14.3
Minimum:	0.0	0.0	0.7	1.4	14.2
Maximum:	0.0	0.0	0.9	1.5	14.5
%SI	100.00	100.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
06/07/2025 00:00	0.0	0.0	0.8	1.5	14.3
06/07/2025 01:00	0.0	0.0	0.8	1.5	14.3
06/07/2025 02:00	0.0	0.0	0.8	1.5	14.2
06/07/2025 03:00	0.0	0.0	0.9	1.5	14.2
06/07/2025 04:00	0.0	0.0	0.8	1.5	14.2
06/07/2025 05:00	0.0	0.0	0.8	1.5	14.2
06/07/2025 06:00	0.0	0.0	0.8	1.5	14.2
06/07/2025 07:00	0.0	0.0	0.8	1.5	14.3
06/07/2025 08:00	0.0	0.0	0.8	1.5	14.3
06/07/2025 09:00	0.0	0.0	0.8	1.5	14.3
06/07/2025 10:00	0.0	0.0	0.8	1.5	14.4
06/07/2025 11:00	0.0	0.0	0.8	1.5	14.4
06/07/2025 12:00	0.0	0.0	0.8	1.5	14.4
06/07/2025 13:00	0.0	0.0	0.8	1.5	14.4
06/07/2025 14:00	0.0	0.0	0.8	1.5	14.4
06/07/2025 15:00	0.0	0.0	0.7	1.5	14.4
06/07/2025 16:00	0.0	0.0	0.7	1.5	14.5
06/07/2025 17:00	0.0	0.0	0.7	1.4	14.5
06/07/2025 18:00	0.0	0.0	0.7	1.5	14.4
06/07/2025 19:00	0.0	0.0	0.8	1.4	14.3
06/07/2025 20:00	0.0	0.0	0.8	1.5	14.3
06/07/2025 21:00	0.0	0.0	0.8	1.5	14.3
06/07/2025 22:00	0.0	0.0	0.8	1.5	14.3
06/07/2025 23:00	0.0	0.0	0.8	1.5	14.3
Average/Sum#:	0.0	0.0	0.8	1.5	14.3
Minimum:	0.0	0.0	0.7	1.4	14.2
Maximum:	0.0	0.0	0.9	1.5	14.5
%SI	100.00	100.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
06/08/2025 00:00	0.0	0.0	0.8	1.5	14.2
06/08/2025 01:00	0.0	0.0	0.8	1.5	14.2
06/08/2025 02:00	0.0	0.0	0.9	1.5	14.2
06/08/2025 03:00	0.0	0.0	0.9	1.5	14.2
06/08/2025 04:00	0.0	0.0	0.9	1.5	14.2
06/08/2025 05:00	0.0	0.0	0.8	1.5	14.2
06/08/2025 06:00	0.0	0.0	0.9	1.5	14.2
06/08/2025 07:00	0.0	0.0	0.8	1.5	14.2
06/08/2025 08:00	0.0	0.0	0.8	1.5	14.3
06/08/2025 09:00	0.0	0.0	0.8	1.5	14.3
06/08/2025 10:00	0.0	0.0	0.8	1.5	14.3
06/08/2025 11:00	0.0	0.0	0.8	1.5	14.3
06/08/2025 12:00	0.0	0.0	0.8	1.5	14.4
06/08/2025 13:00	0.0	0.0	0.7	1.5	14.4
06/08/2025 14:00	0.0	0.0	0.7	1.4	14.4
06/08/2025 15:00	0.0	0.0	0.8	1.5	14.2
06/08/2025 16:00	0.0	0.0	0.7	1.5	14.3
06/08/2025 17:00	0.0	0.0	0.7	1.5	14.3
06/08/2025 18:00	0.0	0.0	0.7	1.5	14.5
06/08/2025 19:00	0.0	0.0	0.6	1.5	14.4
06/08/2025 20:00	0.0	0.0	0.8	1.5	14.2
06/08/2025 21:00	0.0	0.0	0.8	1.5	14.3
06/08/2025 22:00	0.0	0.0	0.8	1.5	14.3
06/08/2025 23:00	0.0	0.0	0.8	1.5	14.3
Average/Sum#:	0.0	0.0	0.8	1.5	14.3
Minimum:	0.0	0.0	0.6	1.4	14.2
Maximum:	0.0	0.0	0.9	1.5	14.5
%SI	100.00	100.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
06/09/2025 00:00	0.0	0.0	0.8	1.5	14.3
06/09/2025 01:00	0.0	0.0	0.8	1.5	14.2
06/09/2025 02:00	0.0	0.0	0.8	1.5	14.2
06/09/2025 03:00	0.0	0.0	0.9	1.5	14.2
06/09/2025 04:00	0.0	0.0	0.8	1.5	14.2
06/09/2025 05:00	0.0	0.0	0.9	1.5	14.2
06/09/2025 06:00	0.0	0.0	0.8	1.5	14.2
06/09/2025 07:00	0.0	0.0	0.8	1.5	14.2
06/09/2025 08:00	0.0	0.0	0.8	1.5	14.3
06/09/2025 09:00	0.0	0.0	0.8	1.5	14.3
06/09/2025 10:00	0.0	0.0	0.8	1.5	14.3
06/09/2025 11:00	0.0	0.0	0.8	1.5	14.4
06/09/2025 12:00	0.0	0.0	0.8	1.5	14.4
06/09/2025 13:00	0.0	0.0	0.7	1.5	14.4
06/09/2025 14:00	0.0	0.0	0.7	1.5	14.4
06/09/2025 15:00	0.0	0.0	0.7	1.5	14.4
06/09/2025 16:00	0.0	0.0	0.7	1.5	14.4
06/09/2025 17:00	0.0	15.6	0.7	1.4	14.3
06/09/2025 18:00	1.2	14.4	1.8	1.5	14.3
06/09/2025 19:00	0.3	12.4	0.5	1.5	13.0
06/09/2025 20:00	0.6	13.8	0.9	1.5	13.8
06/09/2025 21:00	0.6	14.4	0.8	1.5	14.2
06/09/2025 22:00	0.6	14.4	0.8	1.5	14.3
06/09/2025 23:00	0.6	14.4	0.8	1.4	14.3
Average/Sum#:	0.6	14.2	0.8	1.5	14.2
Minimum:	0.0	12.4	0.5	1.4	13.0
Maximum:	1.2	15.6	1.8	1.5	14.4
%SI	70.83	70.83	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
06/10/2025 00:00	0.6	14.4	0.8	1.5	14.2
06/10/2025 01:00	0.6	14.4	0.8	1.5	14.2
06/10/2025 02:00	0.6	14.3	0.8	1.5	14.2
06/10/2025 03:00	0.7	14.3	0.8	1.5	14.2
06/10/2025 04:00	0.6	14.3	0.8	1.5	14.2
06/10/2025 05:00	0.6	14.3	0.8	1.5	14.2
06/10/2025 06:00	0.6	14.3	0.8	1.5	14.2
06/10/2025 07:00	0.6	14.3	0.8	1.5	14.2
06/10/2025 08:00	0.6	14.4	0.8	1.5	14.2
06/10/2025 09:00	0.6	14.4	0.8	1.5	14.3
06/10/2025 10:00	0.6	14.4	0.8	1.5	14.3
06/10/2025 11:00	0.6	14.4	0.8	1.5	14.3
06/10/2025 12:00	0.6	14.5	0.8	1.5	14.3
06/10/2025 13:00	0.6	14.5	0.8	1.5	14.4
06/10/2025 14:00	0.6	14.5	0.8	1.5	14.4
06/10/2025 15:00	0.6	14.6	0.9	1.5	14.4
06/10/2025 16:00	0.6	14.5	0.8	1.4	14.3
06/10/2025 17:00	0.6	14.4	0.7	1.5	14.3
06/10/2025 18:00	0.6	14.5	0.6	1.5	14.4
06/10/2025 19:00	0.6	14.3	0.8	1.5	14.2
06/10/2025 20:00	0.6	14.3	0.8	1.5	14.2
06/10/2025 21:00	0.6	14.4	0.8	1.5	14.3
06/10/2025 22:00	0.6	14.3	0.8	1.5	14.2
06/10/2025 23:00	0.6	14.3	0.8	1.5	14.2
Average/Sum#:	0.6	14.4	0.8	1.5	14.3
Minimum:	0.6	14.3	0.6	1.4	14.2
Maximum:	0.7	14.6	0.9	1.5	14.4
%SI	0.00	0.00	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
06/11/2025 00:00	0.6	14.3	0.8	1.5	14.2
06/11/2025 01:00	0.6	14.3	0.8	1.5	14.2
06/11/2025 02:00	0.6	14.3	0.9	1.5	14.2
06/11/2025 03:00	0.7	14.3	0.8	1.5	14.2
06/11/2025 04:00	0.6	14.3	0.8	1.5	14.2
06/11/2025 05:00	0.6	14.3	0.8	1.5	14.2
06/11/2025 06:00	0.6	14.3	0.8	1.5	14.2
06/11/2025 07:00	0.6	14.3	0.8	1.5	14.2
06/11/2025 08:00	0.6	14.4	0.8	1.5	14.2
06/11/2025 09:00	0.6	14.4	0.8	1.5	14.3
06/11/2025 10:00	0.6	14.4	0.8	1.5	14.3
06/11/2025 11:00	0.6	14.4	0.8	1.5	14.3
06/11/2025 12:00	0.6	14.5	0.8	1.5	14.4
06/11/2025 13:00	0.6	14.5	0.8	1.5	14.4
06/11/2025 14:00	0.6	14.5	0.8	1.5	14.4
06/11/2025 15:00	0.6	14.5	0.8	1.5	14.4
06/11/2025 16:00	0.6	14.5	0.8	1.5	14.4
06/11/2025 17:00	0.6	14.5	0.8	1.5	14.4
06/11/2025 18:00	0.6	14.5	0.8	1.5	14.3
06/11/2025 19:00	0.6	14.5	0.9	1.5	15.1
06/11/2025 20:00	0.6	14.4	0.0	0.0	0.0
06/11/2025 21:00	0.6	14.4	0.0	0.0	0.0
06/11/2025 22:00	0.6	14.4	0.0	0.0	0.0
06/11/2025 23:00	0.6	14.4	0.0	0.0	0.0
Average/Sum#:	0.6	14.4	0.8	1.5	14.3
Minimum:	0.6	14.3	0.8	1.5	14.2
Maximum:	0.7	14.5	0.9	1.5	15.1
%SI	0.00	0.00	16.67	16.67	16.67

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
06/12/2025 00:00	0.6	14.3	0.0	0.0	0.0
06/12/2025 01:00	0.6	14.3	0.0	0.0	0.0
06/12/2025 02:00	0.6	14.3	0.0	0.0	0.0
06/12/2025 03:00	0.7	14.3	0.0	0.0	0.0
06/12/2025 04:00	0.7	14.3	0.0	0.0	0.0
06/12/2025 05:00	0.7	14.3	0.0	0.0	0.0
06/12/2025 06:00	0.7	14.3	0.0	0.0	0.0
06/12/2025 07:00	0.6	14.3	0.0	0.0	0.0
06/12/2025 08:00	0.6	14.4	0.0	0.0	0.0
06/12/2025 09:00	0.6	14.4	0.0	0.0	0.0
06/12/2025 10:00	0.6	14.4	0.0	0.0	0.0
06/12/2025 11:00	0.6	14.5	0.0	0.0	0.0
06/12/2025 12:00	0.6	14.5	0.0	0.0	0.0
06/12/2025 13:00	0.6	14.5	0.0	0.0	0.0
06/12/2025 14:00	0.6	14.5	0.0	0.0	0.0
06/12/2025 15:00	0.6	14.6	0.0	0.0	0.0
06/12/2025 16:00	0.6	14.6	0.0	0.0	0.0
06/12/2025 17:00	0.6	14.5	0.0	0.0	0.0
06/12/2025 18:00	0.6	14.5	0.0	0.0	0.0
06/12/2025 19:00	0.6	14.5	0.0	0.0	0.0
06/12/2025 20:00	0.6	14.4	0.0	0.0	0.0
06/12/2025 21:00	0.6	14.4	0.0	0.0	0.0
06/12/2025 22:00	0.6	14.4	0.0	0.0	0.0
06/12/2025 23:00	0.6	14.5	0.0	0.0	0.0
Average/Sum#:	0.6	14.4	0.0	0.0	0.0
Minimum:	0.6	14.3	0.0	0.0	0.0
Maximum:	0.7	14.6	0.0	0.0	0.0
%SI	0.00	0.00	100.00	100.00	100.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOX, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
06/13/2025 00:00	0.6	14.4	0.0	0.0	0.0
06/13/2025 01:00	0.6	14.4	0.0	0.0	0.0
06/13/2025 02:00	0.6	14.3	0.0	0.0	0.0
06/13/2025 03:00	0.7	14.3	0.0	0.0	0.0
06/13/2025 04:00	0.7	14.3	0.0	0.0	0.0
06/13/2025 05:00	0.7	14.3	0.0	0.0	0.0
06/13/2025 06:00	0.6	14.3	0.0	0.0	0.0
06/13/2025 07:00	0.6	14.4	0.0	0.0	0.0
06/13/2025 08:00	0.6	14.4	0.0	0.0	0.0
06/13/2025 09:00	0.6	14.4	0.0	0.0	0.0
06/13/2025 10:00	0.6	14.5	0.0	0.0	0.0
06/13/2025 11:00	0.6	14.5	0.0	0.0	0.0
06/13/2025 12:00	0.6	14.5	0.0	0.0	0.0
06/13/2025 13:00	0.6	14.6	0.0	0.0	0.0
06/13/2025 14:00	0.6	14.6	0.0	0.0	0.0
06/13/2025 15:00	0.6	14.6	0.0	0.0	0.0
06/13/2025 16:00	0.6	14.6	0.0	0.0	0.0
06/13/2025 17:00	0.6	14.5	0.0	0.0	0.0
06/13/2025 18:00	0.6	14.5	0.0	0.0	0.0
06/13/2025 19:00	0.6	14.5	0.0	0.0	0.0
06/13/2025 20:00	0.6	14.4	0.0	0.0	0.0
06/13/2025 21:00	0.6	14.4	0.0	0.0	0.0
06/13/2025 22:00	0.6	14.4	0.0	0.0	0.0
06/13/2025 23:00	0.6	14.4	0.0	0.0	0.0
Average/Sum#:	0.6	14.4	0.0	0.0	0.0
Minimum:	0.6	14.3	0.0	0.0	0.0
Maximum:	0.7	14.6	0.0	0.0	0.0
%SI	0.00	0.00	100.00	100.00	100.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
06/14/2025 00:00	0.6	14.4	0.0	0.0	0.0
06/14/2025 01:00	0.6	14.4	0.0	0.0	0.0
06/14/2025 02:00	0.6	14.4	0.0	0.0	0.0
06/14/2025 03:00	0.7	14.3	0.0	0.0	0.0
06/14/2025 04:00	0.6	14.4	0.0	0.0	0.0
06/14/2025 05:00	0.6	14.3	0.0	0.0	0.0
06/14/2025 06:00	0.6	14.3	0.0	0.0	0.0
06/14/2025 07:00	0.6	14.4	0.0	0.0	0.0
06/14/2025 08:00	0.6	14.4	0.0	0.0	0.0
06/14/2025 09:00	0.6	14.4	0.0	0.0	0.0
06/14/2025 10:00	0.6	14.4	0.0	0.0	0.0
06/14/2025 11:00	0.6	14.5	0.0	0.0	0.0
06/14/2025 12:00	0.6	14.5	0.0	0.0	0.0
06/14/2025 13:00	0.6	14.5	0.0	0.0	0.0
06/14/2025 14:00	0.6	14.5	0.0	0.0	0.0
06/14/2025 15:00	0.6	14.5	0.0	0.0	0.0
06/14/2025 16:00	0.7	14.6	0.0	0.0	0.0
06/14/2025 17:00	0.6	14.6	0.0	0.0	0.0
06/14/2025 18:00	0.7	13.6	0.0	0.0	0.0
06/14/2025 19:00	0.6	13.5	0.0	0.0	0.0
06/14/2025 20:00	0.6	13.5	0.0	0.0	0.0
06/14/2025 21:00	0.6	14.0	0.0	0.0	0.0
06/14/2025 22:00	0.7	13.7	0.0	0.0	0.0
06/14/2025 23:00	0.7	13.6	0.0	0.0	0.0
Average/Sum#:	0.6	14.2	0.0	0.0	0.0
Minimum:	0.6	13.5	0.0	0.0	0.0
Maximum:	0.7	14.6	0.0	0.0	0.0
%SI	0.00	0.00	100.00	100.00	100.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOX, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
06/15/2025 00:00	0.8	13.7	0.0	0.0	0.0
06/15/2025 01:00	0.7	13.6	0.0	0.0	0.0
06/15/2025 02:00	0.8	13.6	0.0	0.0	0.0
06/15/2025 03:00	0.8	13.6	0.0	0.0	0.0
06/15/2025 04:00	0.8	13.6	0.0	0.0	0.0
06/15/2025 05:00	0.8	14.1	0.0	0.0	0.0
06/15/2025 06:00	0.8	14.3	0.0	0.0	0.0
06/15/2025 07:00	0.7	14.3	0.0	0.0	0.0
06/15/2025 08:00	0.7	14.3	0.0	0.0	0.0
06/15/2025 09:00	0.6	14.4	0.0	0.0	0.0
06/15/2025 10:00	0.6	14.4	0.0	0.0	0.0
06/15/2025 11:00	0.6	14.4	0.0	0.0	0.0
06/15/2025 12:00	0.6	14.4	0.0	0.0	0.0
06/15/2025 13:00	0.6	14.4	0.0	0.0	0.0
06/15/2025 14:00	0.6	14.4	0.0	0.0	0.0
06/15/2025 15:00	0.6	14.4	0.0	0.0	0.0
06/15/2025 16:00	0.8	14.3	0.0	0.0	0.0
06/15/2025 17:00	0.4	13.0	0.0	0.0	0.0
06/15/2025 18:00	0.2	12.6	0.0	0.0	0.0
06/15/2025 19:00	0.4	13.2	0.0	0.0	0.0
06/15/2025 20:00	0.5	13.3	0.0	0.0	0.0
06/15/2025 21:00	0.5	13.4	0.0	0.0	0.0
06/15/2025 22:00	0.6	13.5	0.0	0.0	0.0
06/15/2025 23:00	0.6	13.6	0.0	0.0	0.0
Average/Sum#:	0.6	13.9	0.0	0.0	0.0
Minimum:	0.2	12.6	0.0	0.0	0.0
Maximum:	0.8	14.4	0.0	0.0	0.0
%SI	0.00	0.00	100.00	100.00	100.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
06/16/2025 00:00	0.7	13.6	0.0	0.0	0.0
06/16/2025 01:00	0.6	13.5	0.0	0.0	0.0
06/16/2025 02:00	0.6	13.5	0.0	0.0	0.0
06/16/2025 03:00	0.7	13.6	0.0	0.0	0.0
06/16/2025 04:00	0.7	13.6	0.0	0.0	0.0
06/16/2025 05:00	0.7	14.0	0.0	0.0	0.0
06/16/2025 06:00	0.7	14.3	0.0	0.0	0.0
06/16/2025 07:00	0.7	14.4	0.0	0.0	0.0
06/16/2025 08:00	0.7	14.4	0.0	0.0	0.0
06/16/2025 09:00	0.6	14.4	0.0	0.0	0.0
06/16/2025 10:00	0.6	14.5	0.0	0.0	0.0
06/16/2025 11:00	0.6	14.5	0.0	0.0	0.0
06/16/2025 12:00	0.6	14.5	0.0	0.0	0.0
06/16/2025 13:00	0.6	14.5	0.0	0.0	0.0
06/16/2025 14:00	0.6	14.5	0.0	0.0	0.0
06/16/2025 15:00	0.9	14.3	0.0	0.0	0.0
06/16/2025 16:00	0.5	13.3	0.0	0.0	0.0
06/16/2025 17:00	0.5	13.4	0.0	0.0	0.0
06/16/2025 18:00	0.4	13.2	0.0	0.0	0.0
06/16/2025 19:00	0.5	13.2	0.0	0.0	0.0
06/16/2025 20:00	0.4	13.2	0.0	0.0	0.0
06/16/2025 21:00	0.6	13.5	0.0	0.0	0.0
06/16/2025 22:00	0.6	13.6	0.0	0.0	0.0
06/16/2025 23:00	0.5	13.3	0.0	0.0	0.0
Average/Sum#:	0.6	13.9	0.0	0.0	0.0
Minimum:	0.4	13.2	0.0	0.0	0.0
Maximum:	0.9	14.5	0.0	0.0	0.0
%SI	0.00	0.00	100.00	100.00	100.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
06/17/2025 00:00	0.7	13.6	0.0	0.0	0.0
06/17/2025 01:00	0.8	13.6	0.0	0.0	0.0
06/17/2025 02:00	0.7	13.6	0.0	0.0	0.0
06/17/2025 03:00	0.8	13.6	0.0	0.0	0.0
06/17/2025 04:00	0.7	13.6	0.0	0.0	0.0
06/17/2025 05:00	0.8	13.8	0.0	0.0	0.0
06/17/2025 06:00	0.7	14.3	0.0	0.0	0.0
06/17/2025 07:00	0.7	14.4	0.0	0.0	0.0
06/17/2025 08:00	0.7	14.4	0.0	0.0	0.0
06/17/2025 09:00	0.7	14.5	0.0	0.0	0.0
06/17/2025 10:00	0.6	14.5	0.0	0.0	0.0
06/17/2025 11:00	0.6	14.5	0.0	0.0	0.0
06/17/2025 12:00	0.6	14.5	0.0	0.0	0.0
06/17/2025 13:00	0.7	14.5	0.0	0.0	0.0
06/17/2025 14:00	0.7	14.6	0.0	0.0	0.0
06/17/2025 15:00	0.7	14.5	0.0	0.0	0.0
06/17/2025 16:00	0.8	14.4	0.0	0.0	0.0
06/17/2025 17:00	0.3	12.9	0.0	0.0	0.0
06/17/2025 18:00	0.1	12.2	0.0	0.0	0.0
06/17/2025 19:00	0.1	12.2	0.0	0.0	0.0
06/17/2025 20:00	0.3	12.8	0.0	0.0	0.0
06/17/2025 21:00	0.6	13.4	0.0	0.0	0.0
06/17/2025 22:00	0.6	13.5	0.0	0.0	0.0
06/17/2025 23:00	0.6	13.5	0.0	0.0	0.0
Average/Sum#:	0.6	13.8	0.0	0.0	0.0
Minimum:	0.1	12.2	0.0	0.0	0.0
Maximum:	0.8	14.6	0.0	0.0	0.0
%SI	0.00	0.00	100.00	100.00	100.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
06/18/2025 00:00	0.7	13.5	0.0	0.0	0.0
06/18/2025 01:00	0.7	13.5	0.0	0.0	0.0
06/18/2025 02:00	0.7	13.5	0.0	0.0	0.0
06/18/2025 03:00	0.8	13.6	0.0	0.0	0.0
06/18/2025 04:00	0.7	13.6	0.0	0.0	0.0
06/18/2025 05:00	0.7	13.6	0.0	0.0	0.0
06/18/2025 06:00	0.7	14.0	0.0	0.0	0.0
06/18/2025 07:00	0.7	14.3	0.0	0.0	0.0
06/18/2025 08:00	0.7	14.3	0.0	0.0	0.0
06/18/2025 09:00	0.7	14.4	0.0	0.0	0.0
06/18/2025 10:00	0.6	14.4	0.0	0.0	0.0
06/18/2025 11:00	0.6	14.4	0.0	0.0	0.0
06/18/2025 12:00	0.6	14.4	0.0	0.0	0.0
06/18/2025 13:00	0.6	14.4	0.0	0.0	0.0
06/18/2025 14:00	0.6	14.4	0.0	0.0	0.0
06/18/2025 15:00	0.6	14.4	0.0	0.0	0.0
06/18/2025 16:00	0.6	14.2	0.0	0.0	0.0
06/18/2025 17:00	0.3	13.0	0.0	0.0	0.0
06/18/2025 18:00	0.1	12.1	0.0	0.0	0.0
06/18/2025 19:00	0.1	12.3	0.0	0.0	0.0
06/18/2025 20:00	0.3	13.0	0.0	0.0	0.0
06/18/2025 21:00	0.5	13.2	0.0	0.0	0.0
06/18/2025 22:00	0.5	13.3	0.0	0.0	0.0
06/18/2025 23:00	0.4	13.2	0.0	0.0	0.0
Average/Sum#:	0.6	13.7	0.0	0.0	0.0
Minimum:	0.1	12.1	0.0	0.0	0.0
Maximum:	0.8	14.4	0.0	0.0	0.0
%SI	0.00	0.00	100.00	100.00	100.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOX, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
06/19/2025 00:00	0.4	13.2	0.0	0.0	0.0
06/19/2025 01:00	0.5	13.4	0.0	0.0	0.0
06/19/2025 02:00	0.5	13.4	0.0	0.0	0.0
06/19/2025 03:00	0.6	13.4	0.0	0.0	0.0
06/19/2025 04:00	0.6	13.5	0.0	0.0	0.0
06/19/2025 05:00	0.7	13.8	0.0	0.0	0.0
06/19/2025 06:00	0.6	14.4	0.0	0.0	0.0
06/19/2025 07:00	0.6	14.4	0.0	0.0	0.0
06/19/2025 08:00	0.6	14.5	0.0	0.0	0.0
06/19/2025 09:00	0.6	14.5	0.0	0.0	0.0
06/19/2025 10:00	0.6	14.5	0.0	0.0	0.0
06/19/2025 11:00	0.6	14.5	0.0	0.0	0.0
06/19/2025 12:00	0.6	14.6	0.0	0.0	0.0
06/19/2025 13:00	0.6	14.6	0.0	0.0	0.0
06/19/2025 14:00	0.6	14.6	0.0	0.0	0.0
06/19/2025 15:00	0.6	14.6	0.0	0.0	0.0
06/19/2025 16:00	0.6	14.5	0.0	0.0	0.0
06/19/2025 17:00	0.6	14.5	0.0	0.0	0.0
06/19/2025 18:00	0.6	14.5	0.0	0.0	0.0
06/19/2025 19:00	0.6	14.4	0.0	0.0	0.0
06/19/2025 20:00	0.6	14.4	0.0	0.0	0.0
06/19/2025 21:00	0.6	14.4	0.0	0.0	0.0
06/19/2025 22:00	0.6	14.4	0.0	0.0	0.0
06/19/2025 23:00	0.6	14.4	0.0	0.0	0.0
Average/Sum#:	0.6	14.2	0.0	0.0	0.0
Minimum:	0.4	13.2	0.0	0.0	0.0
Maximum:	0.7	14.6	0.0	0.0	0.0
%SI	0.00	0.00	100.00	100.00	100.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
06/20/2025 00:00	0.6	14.4	0.0	0.0	0.0
06/20/2025 01:00	0.6	14.4	0.0	0.0	0.0
06/20/2025 02:00	0.6	14.3	0.0	0.0	0.0
06/20/2025 03:00	0.7	14.3	0.0	0.0	0.0
06/20/2025 04:00	0.6	14.3	0.0	0.0	0.0
06/20/2025 05:00	0.6	14.4	0.0	0.0	0.0
06/20/2025 06:00	0.6	14.3	0.0	0.0	0.0
06/20/2025 07:00	0.6	14.4	0.0	0.0	0.0
06/20/2025 08:00	0.6	14.4	0.0	0.0	0.0
06/20/2025 09:00	0.6	14.4	0.0	0.0	0.0
06/20/2025 10:00	0.6	14.4	0.0	0.0	0.0
06/20/2025 11:00	0.6	14.5	0.0	0.0	0.0
06/20/2025 12:00	0.6	14.5	0.0	0.0	0.0
06/20/2025 13:00	1.3	14.5	0.0	0.0	0.0
06/20/2025 14:00	0.6	14.6	0.0	0.0	0.0
06/20/2025 15:00	0.6	14.5	0.0	0.0	0.0
06/20/2025 16:00	0.6	14.5	0.0	0.0	0.0
06/20/2025 17:00	0.6	14.5	0.0	0.0	0.0
06/20/2025 18:00	0.6	14.5	0.0	0.0	0.0
06/20/2025 19:00	0.6	14.4	0.0	0.0	0.0
06/20/2025 20:00	0.6	14.4	0.0	0.0	0.0
06/20/2025 21:00	0.6	14.4	0.0	0.0	0.0
06/20/2025 22:00	0.6	14.4	0.0	0.0	0.0
06/20/2025 23:00	0.6	14.4	0.0	0.0	0.0
Average/Sum#:	0.6	14.4	0.0	0.0	0.0
Minimum:	0.6	14.3	0.0	0.0	0.0
Maximum:	1.3	14.6	0.0	0.0	0.0
%SI	0.00	0.00	100.00	100.00	100.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
06/21/2025 00:00	0.6	14.4	0.0	0.0	0.0
06/21/2025 01:00	0.6	14.4	0.0	0.0	0.0
06/21/2025 02:00	0.7	14.4	0.0	0.0	0.0
06/21/2025 03:00	0.8	14.3	0.0	0.0	0.0
06/21/2025 04:00	0.7	14.4	0.0	0.0	0.0
06/21/2025 05:00	0.7	14.4	0.0	0.0	0.0
06/21/2025 06:00	0.6	14.4	0.0	0.0	0.0
06/21/2025 07:00	0.6	14.4	0.0	0.0	0.0
06/21/2025 08:00	0.6	14.4	0.0	0.0	0.0
06/21/2025 09:00	0.6	14.4	0.0	0.0	0.0
06/21/2025 10:00	0.6	14.5	0.0	0.0	0.0
06/21/2025 11:00	0.6	14.5	0.0	0.0	0.0
06/21/2025 12:00	0.6	14.5	0.0	0.0	0.0
06/21/2025 13:00	0.6	14.5	0.0	0.0	0.0
06/21/2025 14:00	0.6	14.5	0.0	0.0	0.0
06/21/2025 15:00	0.6	14.5	0.0	0.0	0.0
06/21/2025 16:00	0.6	14.5	0.0	0.0	0.0
06/21/2025 17:00	0.6	14.5	0.0	0.0	0.0
06/21/2025 18:00	0.6	14.5	0.0	0.0	0.0
06/21/2025 19:00	0.6	14.5	0.0	0.0	0.0
06/21/2025 20:00	0.6	14.5	0.0	0.0	0.0
06/21/2025 21:00	0.6	14.5	0.0	0.0	0.0
06/21/2025 22:00	0.7	14.4	0.0	0.0	0.0
06/21/2025 23:00	0.7	14.4	0.0	0.0	0.0
Average/Sum#:	0.6	14.4	0.0	0.0	0.0
Minimum:	0.6	14.3	0.0	0.0	0.0
Maximum:	0.8	14.5	0.0	0.0	0.0
%SI	0.00	0.00	100.00	100.00	100.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
06/22/2025 00:00	0.7	14.4	0.0	0.0	0.0
06/22/2025 01:00	0.7	14.4	0.0	0.0	0.0
06/22/2025 02:00	0.7	14.4	0.0	0.0	0.0
06/22/2025 03:00	0.8	14.4	0.0	0.0	0.0
06/22/2025 04:00	0.7	14.4	0.0	0.0	0.0
06/22/2025 05:00	0.7	14.4	0.0	0.0	0.0
06/22/2025 06:00	0.7	14.4	0.0	0.0	0.0
06/22/2025 07:00	0.7	14.4	0.0	0.0	0.0
06/22/2025 08:00	0.7	14.4	0.0	0.0	0.0
06/22/2025 09:00	0.6	14.4	0.0	0.0	0.0
06/22/2025 10:00	0.6	14.5	0.0	0.0	0.0
06/22/2025 11:00	0.6	14.5	0.0	0.0	0.0
06/22/2025 12:00	0.6	14.5	0.0	0.0	0.0
06/22/2025 13:00	0.6	14.5	0.0	0.0	0.0
06/22/2025 14:00	0.6	14.5	0.0	0.0	0.0
06/22/2025 15:00	0.6	14.5	0.0	0.0	0.0
06/22/2025 16:00	0.6	14.5	0.0	0.0	0.0
06/22/2025 17:00	0.6	14.6	0.0	0.0	0.0
06/22/2025 18:00	0.7	14.5	0.0	0.0	0.0
06/22/2025 19:00	0.6	14.5	0.0	0.0	0.0
06/22/2025 20:00	0.6	14.5	0.0	0.0	0.0
06/22/2025 21:00	0.7	14.5	0.0	0.0	0.0
06/22/2025 22:00	0.7	14.4	0.0	0.0	0.0
06/22/2025 23:00	0.7	14.4	0.0	0.0	0.0
Average/Sum#:	0.7	14.5	0.0	0.0	0.0
Minimum:	0.6	14.4	0.0	0.0	0.0
Maximum:	0.8	14.6	0.0	0.0	0.0
%SI	0.00	0.00	100.00	100.00	100.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
06/23/2025 00:00	0.7	14.4	0.0	0.0	0.0
06/23/2025 01:00	0.7	14.4	0.0	0.0	0.0
06/23/2025 02:00	0.7	14.4	0.0	0.0	0.0
06/23/2025 03:00	0.8	14.4	0.0	0.0	0.0
06/23/2025 04:00	0.7	14.4	0.0	0.0	0.0
06/23/2025 05:00	0.7	14.5	0.0	0.0	0.0
06/23/2025 06:00	0.7	14.4	0.0	0.0	0.0
06/23/2025 07:00	0.7	14.4	0.0	0.0	0.0
06/23/2025 08:00	0.6	14.4	0.0	0.0	0.0
06/23/2025 09:00	0.6	14.5	0.0	0.0	0.0
06/23/2025 10:00	0.6	14.5	0.0	0.0	0.0
06/23/2025 11:00	0.6	14.5	0.0	0.0	0.0
06/23/2025 12:00	0.7	14.6	0.0	0.0	0.0
06/23/2025 13:00	0.7	14.6	0.0	0.0	0.0
06/23/2025 14:00	0.7	14.6	0.0	0.0	0.0
06/23/2025 15:00	0.7	14.6	0.0	0.0	0.0
06/23/2025 16:00	0.7	14.6	0.0	0.0	0.0
06/23/2025 17:00	0.7	14.6	0.0	0.0	0.0
06/23/2025 18:00	0.6	14.6	0.0	0.0	0.0
06/23/2025 19:00	0.6	14.6	0.0	0.0	0.0
06/23/2025 20:00	0.6	14.5	0.0	0.0	0.0
06/23/2025 21:00	0.6	14.6	0.0	0.0	0.0
06/23/2025 22:00	0.6	14.7	0.0	0.0	0.0
06/23/2025 23:00	0.6	14.6	0.0	0.0	0.0
Average/Sum#:	0.7	14.5	0.0	0.0	0.0
Minimum:	0.6	14.4	0.0	0.0	0.0
Maximum:	0.8	14.7	0.0	0.0	0.0
%SI	0.00	0.00	100.00	100.00	100.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
06/24/2025 00:00	0.7	14.4	0.0	0.0	0.0
06/24/2025 01:00	0.6	14.4	0.0	0.0	0.0
06/24/2025 02:00	0.6	14.6	0.0	0.0	0.0
06/24/2025 03:00	0.7	14.6	0.0	0.0	0.0
06/24/2025 04:00	0.6	14.5	0.0	0.0	0.0
06/24/2025 05:00	0.6	14.4	0.0	0.0	0.0
06/24/2025 06:00	0.7	14.3	0.0	0.0	0.0
06/24/2025 07:00	0.7	14.4	0.0	0.0	0.0
06/24/2025 08:00	0.6	14.4	0.0	0.0	0.0
06/24/2025 09:00	0.6	14.4	0.0	0.0	0.0
06/24/2025 10:00	0.6	14.4	0.0	0.0	0.0
06/24/2025 11:00	0.6	14.5	0.0	0.0	0.0
06/24/2025 12:00	0.6	14.5	0.0	0.0	0.0
06/24/2025 13:00	0.6	14.5	0.0	0.0	0.0
06/24/2025 14:00	0.6	14.5	0.0	0.0	0.0
06/24/2025 15:00	0.7	14.6	0.0	0.0	0.0
06/24/2025 16:00	0.6	14.6	0.0	0.0	0.0
06/24/2025 17:00	0.6	14.6	0.0	0.0	0.0
06/24/2025 18:00	0.6	14.6	0.0	0.0	0.0
06/24/2025 19:00	0.6	14.4	0.0	0.0	0.0
06/24/2025 20:00	0.6	14.4	0.0	0.0	0.0
06/24/2025 21:00	0.6	14.4	0.0	0.0	0.0
06/24/2025 22:00	0.6	14.4	0.0	0.0	0.0
06/24/2025 23:00	0.6	14.4	0.0	0.0	0.0
Average/Sum#:	0.6	14.5	0.0	0.0	0.0
Minimum:	0.6	14.3	0.0	0.0	0.0
Maximum:	0.7	14.6	0.0	0.0	0.0
%SI	0.00	0.00	100.00	100.00	100.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
06/25/2025 00:00	0.6	14.3	0.0	0.0	0.0
06/25/2025 01:00	0.7	14.3	0.0	0.0	0.0
06/25/2025 02:00	0.7	14.3	0.0	0.0	0.0
06/25/2025 03:00	0.8	14.3	0.0	0.0	0.0
06/25/2025 04:00	0.7	14.3	0.0	0.0	0.0
06/25/2025 05:00	0.7	14.3	0.0	0.0	0.0
06/25/2025 06:00	0.7	14.3	0.0	0.0	0.0
06/25/2025 07:00	0.7	14.3	0.0	0.0	0.0
06/25/2025 08:00	0.7	14.4	0.0	0.0	0.0
06/25/2025 09:00	0.6	14.4	0.0	0.0	0.0
06/25/2025 10:00	0.6	14.4	0.0	0.0	0.0
06/25/2025 11:00	0.6	14.5	0.0	0.0	0.0
06/25/2025 12:00	0.6	14.5	0.0	0.0	0.0
06/25/2025 13:00	0.6	14.5	0.0	0.0	0.0
06/25/2025 14:00	0.6	14.5	0.0	0.0	0.0
06/25/2025 15:00	0.7	14.6	0.0	0.0	0.0
06/25/2025 16:00	0.7	14.6	0.0	0.0	0.0
06/25/2025 17:00	0.7	14.6	0.0	0.0	0.0
06/25/2025 18:00	0.6	14.6	0.0	0.0	0.0
06/25/2025 19:00	0.7	14.5	0.0	0.0	0.0
06/25/2025 20:00	0.7	14.4	0.0	0.0	0.0
06/25/2025 21:00	0.7	14.3	0.0	0.0	0.0
06/25/2025 22:00	0.7	14.3	0.0	0.0	0.0
06/25/2025 23:00	0.7	14.3	0.0	0.0	0.0
Average/Sum#:	0.7	14.4	0.0	0.0	0.0
Minimum:	0.6	14.3	0.0	0.0	0.0
Maximum:	0.8	14.6	0.0	0.0	0.0
%SI	0.00	0.00	100.00	100.00	100.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
06/26/2025 00:00	0.7	14.3	0.0	0.0	0.0
06/26/2025 01:00	0.7	14.3	0.0	0.0	0.0
06/26/2025 02:00	0.7	14.3	0.0	0.0	0.0
06/26/2025 03:00	0.8	14.3	0.0	0.0	0.0
06/26/2025 04:00	0.7	14.3	0.0	0.0	0.0
06/26/2025 05:00	0.8	14.3	0.0	0.0	0.0
06/26/2025 06:00	0.7	14.3	0.0	0.0	0.0
06/26/2025 07:00	0.7	14.4	0.0	0.0	0.0
06/26/2025 08:00	0.7	14.4	0.0	0.0	0.0
06/26/2025 09:00	0.7	14.4	0.0	0.0	0.0
06/26/2025 10:00	0.6	14.4	0.0	0.0	0.0
06/26/2025 11:00	0.6	14.5	0.0	0.0	0.0
06/26/2025 12:00	0.6	14.5	0.0	0.0	0.0
06/26/2025 13:00	0.6	14.5	0.0	0.0	0.0
06/26/2025 14:00	0.6	14.5	0.0	0.0	0.0
06/26/2025 15:00	0.6	14.5	0.0	0.0	0.0
06/26/2025 16:00	0.6	14.5	0.0	0.0	0.0
06/26/2025 17:00	0.7	14.6	0.0	0.0	0.0
06/26/2025 18:00	0.6	14.6	0.0	0.0	0.0
06/26/2025 19:00	0.6	14.6	0.0	0.0	0.0
06/26/2025 20:00	0.6	14.5	0.0	0.0	0.0
06/26/2025 21:00	0.7	14.4	0.0	0.0	0.0
06/26/2025 22:00	0.7	14.4	0.0	0.0	0.0
06/26/2025 23:00	0.7	14.4	0.0	0.0	0.0
Average/Sum#:	0.7	14.4	0.0	0.0	0.0
Minimum:	0.6	14.3	0.0	0.0	0.0
Maximum:	0.8	14.6	0.0	0.0	0.0
%SI	0.00	0.00	100.00	100.00	100.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
06/27/2025 00:00	0.7	14.4	0.0	0.0	0.0
06/27/2025 01:00	0.8	14.4	0.0	0.0	0.0
06/27/2025 02:00	0.8	14.4	0.0	0.0	0.0
06/27/2025 03:00	0.8	14.3	0.0	0.0	0.0
06/27/2025 04:00	0.8	14.4	0.0	0.0	0.0
06/27/2025 05:00	0.7	14.4	0.0	0.0	0.0
06/27/2025 06:00	0.7	14.4	0.0	0.0	0.0
06/27/2025 07:00	0.7	14.4	0.0	0.0	0.0
06/27/2025 08:00	0.7	14.4	0.0	0.0	0.0
06/27/2025 09:00	0.6	14.5	0.0	0.0	0.0
06/27/2025 10:00	0.6	14.5	0.0	0.0	0.0
06/27/2025 11:00	0.6	14.5	0.0	0.0	0.0
06/27/2025 12:00	0.7	14.6	0.0	0.0	0.0
06/27/2025 13:00	0.7	14.6	0.0	0.0	0.0
06/27/2025 14:00	0.7	14.5	0.0	0.0	0.0
06/27/2025 15:00	0.7	14.5	0.0	0.0	0.0
06/27/2025 16:00	0.7	14.5	0.0	0.0	17.3
06/27/2025 17:00	0.7	14.5	0.7	1.4	14.5
06/27/2025 18:00	0.8	14.4	0.7	1.5	14.5
06/27/2025 19:00	0.2	12.0	0.3	1.5	12.2
06/27/2025 20:00	0.5	13.4	0.7	1.5	13.5
06/27/2025 21:00	0.7	14.1	0.9	1.5	14.0
06/27/2025 22:00	0.0	16.8	0.9	1.5	14.4
06/27/2025 23:00	0.0	0.0	0.9	1.5	14.4
Average/Sum#:	0.6	14.4	0.6	1.3	14.4
Minimum:	0.0	12.0	0.0	0.0	12.2
Maximum:	0.8	16.8	0.9	1.5	17.3
%SI	4.17	4.17	66.67	66.67	66.67

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
06/28/2025 00:00	0.0	0.0	0.9	1.5	14.3
06/28/2025 01:00	0.0	0.0	0.9	1.5	14.3
06/28/2025 02:00	0.0	0.0	0.9	1.5	14.3
06/28/2025 03:00	0.0	0.0	0.9	1.5	14.3
06/28/2025 04:00	0.0	0.0	0.9	1.5	14.3
06/28/2025 05:00	0.0	0.0	0.9	1.5	14.3
06/28/2025 06:00	0.0	0.0	1.0	1.5	14.3
06/28/2025 07:00	0.0	0.0	1.0	1.5	14.3
06/28/2025 08:00	0.0	0.0	0.9	1.5	14.4
06/28/2025 09:00	0.0	0.0	0.8	1.5	14.4
06/28/2025 10:00	0.0	0.0	0.8	1.5	14.4
06/28/2025 11:00	0.0	0.0	0.8	1.5	14.4
06/28/2025 12:00	0.0	0.0	0.8	1.5	14.5
06/28/2025 13:00	0.0	0.0	0.8	1.5	14.5
06/28/2025 14:00	0.0	19.1	0.7	1.5	14.5
06/28/2025 15:00	0.6	14.6	0.7	1.5	14.4
06/28/2025 16:00	0.6	14.6	0.7	1.5	14.5
06/28/2025 17:00	0.8	14.4	0.8	1.5	14.3
06/28/2025 18:00	0.1	11.9	0.2	1.5	12.3
06/28/2025 19:00	0.1	11.8	0.1	1.5	12.2
06/28/2025 20:00	0.1	12.0	0.2	1.5	12.2
06/28/2025 21:00	0.1	11.9	0.2	1.5	12.2
06/28/2025 22:00	0.2	12.6	0.2	1.5	12.2
06/28/2025 23:00	0.5	13.5	0.4	1.4	12.5
Average/Sum#:	0.3	13.6	0.7	1.5	13.8
Minimum:	0.0	11.8	0.1	1.4	12.2
Maximum:	0.8	19.1	1.0	1.5	14.5
%SI	58.33	58.33	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
06/29/2025 00:00	0.7	14.4	0.8	1.4	14.3
06/29/2025 01:00	0.7	14.4	0.8	1.5	14.3
06/29/2025 02:00	0.0	16.7	0.9	1.5	14.4
06/29/2025 03:00	0.0	0.0	0.9	1.5	14.3
06/29/2025 04:00	0.0	0.0	0.8	1.5	14.4
06/29/2025 05:00	0.0	0.0	0.9	1.5	14.3
06/29/2025 06:00	0.0	0.0	0.9	1.5	14.3
06/29/2025 07:00	0.0	0.0	0.9	1.5	14.3
06/29/2025 08:00	0.0	0.0	0.8	1.5	14.4
06/29/2025 09:00	0.0	0.0	0.8	1.5	14.4
06/29/2025 10:00	0.0	0.0	0.8	1.5	14.4
06/29/2025 11:00	0.0	0.0	0.8	1.5	14.4
06/29/2025 12:00	0.0	0.0	0.7	1.5	14.5
06/29/2025 13:00	0.0	0.0	0.8	1.5	14.5
06/29/2025 14:00	0.0	0.0	0.7	1.5	14.5
06/29/2025 15:00	0.0	0.0	0.7	1.5	14.5
06/29/2025 16:00	0.0	17.0	0.7	1.5	14.4
06/29/2025 17:00	0.6	14.5	0.7	1.5	14.4
06/29/2025 18:00	0.6	14.6	0.7	1.5	14.4
06/29/2025 19:00	0.6	14.6	0.7	1.5	14.4
06/29/2025 20:00	0.6	14.6	0.7	1.5	14.4
06/29/2025 21:00	0.6	14.5	0.8	1.5	14.4
06/29/2025 22:00	0.7	14.5	0.8	1.5	14.2
06/29/2025 23:00	0.0	17.6	0.8	1.4	14.3
Average/Sum#:	0.5	15.2	0.8	1.5	14.4
Minimum:	0.0	14.4	0.7	1.4	14.2
Maximum:	0.7	17.6	0.9	1.5	14.5
%SI	54.17	54.17	0.00	0.00	0.00

AQ32 HOURLY NOX CO



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)
06/30/2025 00:00	0.0	0.0	0.9	1.5	14.3
06/30/2025 01:00	0.0	0.0	0.9	1.5	14.3
06/30/2025 02:00	0.0	0.0	0.8	1.5	14.3
06/30/2025 03:00	0.0	0.0	0.9	1.5	14.3
06/30/2025 04:00	0.0	0.0	0.8	1.5	14.3
06/30/2025 05:00	0.0	0.0	0.8	1.5	14.3
06/30/2025 06:00	0.0	0.0	0.9	1.5	14.3
06/30/2025 07:00	0.0	0.0	0.8	1.5	14.3
06/30/2025 08:00	0.0	0.0	0.8	1.5	14.3
06/30/2025 09:00	0.0	0.0	0.8	1.5	14.4
06/30/2025 10:00	0.0	0.0	0.8	1.5	14.4
06/30/2025 11:00	0.0	0.0	0.8	1.5	14.4
06/30/2025 12:00	0.0	0.0	0.8	1.5	14.5
06/30/2025 13:00	0.0	0.0	0.7	1.5	14.5
06/30/2025 14:00	0.0	0.0	0.7	1.4	14.3
06/30/2025 15:00	0.0	0.0	0.7	1.4	14.4
06/30/2025 16:00	0.0	19.1	0.7	1.5	14.4
06/30/2025 17:00	0.6	14.6	0.7	1.5	14.4
06/30/2025 18:00	0.6	14.6	0.7	1.5	14.4
06/30/2025 19:00	0.6	14.6	0.7	1.5	14.4
06/30/2025 20:00	0.6	14.5	0.7	1.5	14.4
06/30/2025 21:00	0.6	14.4	0.8	1.5	14.3
06/30/2025 22:00	0.7	14.3	0.8	1.5	14.2
06/30/2025 23:00	0.6	14.6	0.7	1.5	14.4
Average/Sum#:	0.5	15.1	0.8	1.5	14.4
Minimum:	0.0	14.3	0.7	1.4	14.2
Maximum:	0.7	19.1	0.9	1.5	14.5
%SI	66.67	66.67	0.00	0.00	0.00

AQ-33

AQ-33 The Project owner shall maintain records of Sox lb/hr, lb/day, and lb, quarter emissions. Sox emissions shall be based on fuel use records, natural gas sulfur content, and mass balance calculations.

Verification: The Project owner shall submit to the CPM all hourly, daily, and quarterly Sox emissions as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

Tons 12 Month Rolling Summary

CT1 and CT2 Combined



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 07/01/2025 08:05 Location: Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2									
	CO, Ton		NOx, Ton		PM10, Ton		SO2, Ton		VOC, Ton	
	1 Day(s)	1 Day(s)								
	Sum	Rolling Sum								
Apr 2025	0.5613	5.3364	0.7823	12.6435	0.1784	2.8652	0.0893	1.4325	0.2973	4.7737
May 2025	0.5209	5.4804	1.0365	12.7350	0.2154	2.8799	0.1076	1.4395	0.3597	4.7987
Jun 2025	0.4191	5.2637	0.9143	12.5786	0.2025	2.8552	0.1012	1.4269	0.3379	4.7576
Sum/Avg	5.2637		12.5786		2.8552		1.4269		4.7576	
Limit Value										

AQ33 DAILY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
04/01/2025 00:00	5.9	0.0
Average/Sum#:	5.9 #	0.0 #
Minimum:	5.9	0.0
Maximum:	5.9	0.0
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
04/02/2025 00:00	5.6	1.5
Average/Sum#:	5.6 #	1.5 #
Minimum:	5.6	1.5
Maximum:	5.6	1.5
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
04/03/2025 00:00	5.4	0.0
Average/Sum#:	5.4 #	0.0 #
Minimum:	5.4	0.0
Maximum:	5.4	0.0
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
04/04/2025 00:00	5.1	0.0

AQ33 DAILY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	5.1 #	0.0 #
Minimum:	5.1	0.0
Maximum:	5.1	0.0
%SI	0.00	0.00

Unit CT1	Unit CT2
SO2, Lb	SO2, Lb
1 Day(s)	1 Day(s)

04/05/2025 00:00	4.9	0.0
------------------	-----	-----

Average/Sum#:	4.9 #	0.0 #
Minimum:	4.9	0.0
Maximum:	4.9	0.0
%SI	0.00	0.00

Unit CT1	Unit CT2
SO2, Lb	SO2, Lb
1 Day(s)	1 Day(s)

04/06/2025 00:00	4.8	0.0
------------------	-----	-----

Average/Sum#:	4.8 #	0.0 #
Minimum:	4.8	0.0
Maximum:	4.8	0.0
%SI	0.00	0.00

Unit CT1	Unit CT2
SO2, Lb	SO2, Lb
1 Day(s)	1 Day(s)

04/07/2025 00:00	2.1	3.2
------------------	-----	-----

Average/Sum#:	2.1 #	3.2 #
Minimum:	2.1	3.2
Maximum:	2.1	3.2
%SI	0.00	0.00

AQ33 DAILY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	so2, Lb	so2, Lb
	1 Day(s)	1 Day(s)
04/08/2025 00:00	0.0	4.8
Average/Sum#:	0.0 #	4.8 #
Minimum:	0.0	4.8
Maximum:	0.0	4.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	so2, Lb	so2, Lb
	1 Day(s)	1 Day(s)
04/09/2025 00:00	0.0	4.9
Average/Sum#:	0.0 #	4.9 #
Minimum:	0.0	4.9
Maximum:	0.0	4.9
%SI	0.00	0.00

	Unit CT1	Unit CT2
	so2, Lb	so2, Lb
	1 Day(s)	1 Day(s)
04/10/2025 00:00	0.0	5.3
Average/Sum#:	0.0 #	5.3 #
Minimum:	0.0	5.3
Maximum:	0.0	5.3
%SI	0.00	0.00

	Unit CT1	Unit CT2
	so2, Lb	so2, Lb
	1 Day(s)	1 Day(s)
04/11/2025 00:00	0.0	5.0

AQ33 DAILY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	0.0 #	5.0 #
Minimum:	0.0	5.0
Maximum:	0.0	5.0
%SI	0.00	0.00

Unit CT1	Unit CT2
SO2, Lb	SO2, Lb
1 Day(s)	1 Day(s)

04/12/2025 00:00	0.0	4.8
------------------	-----	-----

Average/Sum#:	0.0 #	4.8 #
Minimum:	0.0	4.8
Maximum:	0.0	4.8
%SI	0.00	0.00

Unit CT1	Unit CT2
SO2, Lb	SO2, Lb
1 Day(s)	1 Day(s)

04/13/2025 00:00	0.0	4.8
------------------	-----	-----

Average/Sum#:	0.0 #	4.8 #
Minimum:	0.0	4.8
Maximum:	0.0	4.8
%SI	0.00	0.00

Unit CT1	Unit CT2
SO2, Lb	SO2, Lb
1 Day(s)	1 Day(s)

04/14/2025 00:00	0.0	4.9
------------------	-----	-----

Average/Sum#:	0.0 #	4.9 #
Minimum:	0.0	4.9
Maximum:	0.0	4.9
%SI	0.00	0.00

AQ33 DAILY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, Lb 1 Day(s)	Unit CT2 SO2, Lb 1 Day(s)
04/15/2025 00:00	0.0	4.9
Average/Sum#:	0.0 #	4.9 #
Minimum:	0.0	4.9
Maximum:	0.0	4.9
%SI	0.00	0.00

	Unit CT1 SO2, Lb 1 Day(s)	Unit CT2 SO2, Lb 1 Day(s)
04/16/2025 00:00	0.0	4.8
Average/Sum#:	0.0 #	4.8 #
Minimum:	0.0	4.8
Maximum:	0.0	4.8
%SI	0.00	0.00

	Unit CT1 SO2, Lb 1 Day(s)	Unit CT2 SO2, Lb 1 Day(s)
04/17/2025 00:00	0.0	4.8
Average/Sum#:	0.0 #	4.8 #
Minimum:	0.0	4.8
Maximum:	0.0	4.8
%SI	0.00	0.00

	Unit CT1 SO2, Lb 1 Day(s)	Unit CT2 SO2, Lb 1 Day(s)
04/18/2025 00:00	3.7	2.2

AQ33 DAILY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	3.7 #	2.2 #
Minimum:	3.7	2.2
Maximum:	3.7	2.2
%SI	0.00	0.00

Unit CT1	Unit CT2
SO2, Lb	SO2, Lb
1 Day(s)	1 Day(s)

04/19/2025 00:00	6.0	0.0
------------------	-----	-----

Average/Sum#:	6.0 #	0.0 #
Minimum:	6.0	0.0
Maximum:	6.0	0.0
%SI	0.00	0.00

Unit CT1	Unit CT2
SO2, Lb	SO2, Lb
1 Day(s)	1 Day(s)

04/20/2025 00:00	5.4	0.0
------------------	-----	-----

Average/Sum#:	5.4 #	0.0 #
Minimum:	5.4	0.0
Maximum:	5.4	0.0
%SI	0.00	0.00

Unit CT1	Unit CT2
SO2, Lb	SO2, Lb
1 Day(s)	1 Day(s)

04/21/2025 00:00	6.4	0.0
------------------	-----	-----

Average/Sum#:	6.4 #	0.0 #
Minimum:	6.4	0.0
Maximum:	6.4	0.0
%SI	0.00	0.00

AQ33 DAILY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, Lb 1 Day(s)	Unit CT2 SO2, Lb 1 Day(s)
04/22/2025 00:00	6.6	0.0
Average/Sum#:	6.6 #	0.0 #
Minimum:	6.6	0.0
Maximum:	6.6	0.0
%SI	0.00	0.00

	Unit CT1 SO2, Lb 1 Day(s)	Unit CT2 SO2, Lb 1 Day(s)
04/23/2025 00:00	6.2	0.0
Average/Sum#:	6.2 #	0.0 #
Minimum:	6.2	0.0
Maximum:	6.2	0.0
%SI	0.00	0.00

	Unit CT1 SO2, Lb 1 Day(s)	Unit CT2 SO2, Lb 1 Day(s)
04/24/2025 00:00	6.0	0.0
Average/Sum#:	6.0 #	0.0 #
Minimum:	6.0	0.0
Maximum:	6.0	0.0
%SI	0.00	0.00

	Unit CT1 SO2, Lb 1 Day(s)	Unit CT2 SO2, Lb 1 Day(s)
04/25/2025 00:00	6.4	1.6

AQ33 DAILY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	6.4 #	1.6 #
Minimum:	6.4	1.6
Maximum:	6.4	1.6
%SI	0.00	0.00

Unit CT1	Unit CT2
SO2, Lb	SO2, Lb
1 Day(s)	1 Day(s)

04/26/2025 00:00	5.3	0.0
------------------	-----	-----

Average/Sum#:	5.3 #	0.0 #
Minimum:	5.3	0.0
Maximum:	5.3	0.0
%SI	0.00	0.00

Unit CT1	Unit CT2
SO2, Lb	SO2, Lb
1 Day(s)	1 Day(s)

04/27/2025 00:00	4.9	0.0
------------------	-----	-----

Average/Sum#:	4.9 #	0.0 #
Minimum:	4.9	0.0
Maximum:	4.9	0.0
%SI	0.00	0.00

Unit CT1	Unit CT2
SO2, Lb	SO2, Lb
1 Day(s)	1 Day(s)

04/28/2025 00:00	4.8	0.0
------------------	-----	-----

Average/Sum#:	4.8 #	0.0 #
Minimum:	4.8	0.0
Maximum:	4.8	0.0
%SI	0.00	0.00

AQ33 DAILY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
04/29/2025 00:00	4.8	0.0
Average/Sum#:	4.8 #	0.0 #
Minimum:	4.8	0.0
Maximum:	4.8	0.0
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
04/30/2025 00:00	5.2	0.0
Average/Sum#:	5.2 #	0.0 #
Minimum:	5.2	0.0
Maximum:	5.2	0.0
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
05/01/2025 00:00	5.1	0.0
Average/Sum#:	5.1 #	0.0 #
Minimum:	5.1	0.0
Maximum:	5.1	0.0
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
05/02/2025 00:00	3.1	3.7

AQ33 DAILY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	3.1 #	3.7 #
Minimum:	3.1	3.7
Maximum:	3.1	3.7
%SI	0.00	0.00

Unit CT1	Unit CT2
SO2, Lb	SO2, Lb
1 Day(s)	1 Day(s)

05/03/2025 00:00 0.0 4.8

Average/Sum#:	0.0 #	4.8 #
Minimum:	0.0	4.8
Maximum:	0.0	4.8
%SI	0.00	0.00

Unit CT1	Unit CT2
SO2, Lb	SO2, Lb
1 Day(s)	1 Day(s)

05/04/2025 00:00 0.0 5.6

Average/Sum#:	0.0 #	5.6 #
Minimum:	0.0	5.6
Maximum:	0.0	5.6
%SI	0.00	0.00

Unit CT1	Unit CT2
SO2, Lb	SO2, Lb
1 Day(s)	1 Day(s)

05/05/2025 00:00 0.0 5.6

Average/Sum#:	0.0 #	5.6 #
Minimum:	0.0	5.6
Maximum:	0.0	5.6
%SI	0.00	0.00

AQ33 DAILY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	so2, Lb	so2, Lb
	1 Day(s)	1 Day(s)
05/06/2025 00:00	0.0	6.0
Average/Sum#:	0.0 #	6.0 #
Minimum:	0.0	6.0
Maximum:	0.0	6.0
%SI	0.00	0.00

	Unit CT1	Unit CT2
	so2, Lb	so2, Lb
	1 Day(s)	1 Day(s)
05/07/2025 00:00	3.0	2.8
Average/Sum#:	3.0 #	2.8 #
Minimum:	3.0	2.8
Maximum:	3.0	2.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	so2, Lb	so2, Lb
	1 Day(s)	1 Day(s)
05/08/2025 00:00	5.9	0.0
Average/Sum#:	5.9 #	0.0 #
Minimum:	5.9	0.0
Maximum:	5.9	0.0
%SI	0.00	0.00

	Unit CT1	Unit CT2
	so2, Lb	so2, Lb
	1 Day(s)	1 Day(s)
05/09/2025 00:00	3.6	5.5

AQ33 DAILY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	3.6 #	5.5 #
Minimum:	3.6	5.5
Maximum:	3.6	5.5
%SI	0.00	0.00

Unit CT1	Unit CT2
SO2, Lb	SO2, Lb
1 Day(s)	1 Day(s)

05/10/2025 00:00	1.9	5.5
------------------	-----	-----

Average/Sum#:	1.9 #	5.5 #
Minimum:	1.9	5.5
Maximum:	1.9	5.5
%SI	0.00	0.00

Unit CT1	Unit CT2
SO2, Lb	SO2, Lb
1 Day(s)	1 Day(s)

05/11/2025 00:00	0.2	4.9
------------------	-----	-----

Average/Sum#:	0.2 #	4.9 #
Minimum:	0.2	4.9
Maximum:	0.2	4.9
%SI	0.00	0.00

Unit CT1	Unit CT2
SO2, Lb	SO2, Lb
1 Day(s)	1 Day(s)

05/12/2025 00:00	0.0	4.8
------------------	-----	-----

Average/Sum#:	0.0 #	4.8 #
Minimum:	0.0	4.8
Maximum:	0.0	4.8
%SI	0.00	0.00

AQ33 DAILY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, Lb 1 Day(s)	Unit CT2 SO2, Lb 1 Day(s)
05/13/2025 00:00	0.0	4.8
Average/Sum#:	0.0 #	4.8 #
Minimum:	0.0	4.8
Maximum:	0.0	4.8
%SI	0.00	0.00

	Unit CT1 SO2, Lb 1 Day(s)	Unit CT2 SO2, Lb 1 Day(s)
05/14/2025 00:00	0.0	4.9
Average/Sum#:	0.0 #	4.9 #
Minimum:	0.0	4.9
Maximum:	0.0	4.9
%SI	0.00	0.00

	Unit CT1 SO2, Lb 1 Day(s)	Unit CT2 SO2, Lb 1 Day(s)
05/15/2025 00:00	0.0	4.8
Average/Sum#:	0.0 #	4.8 #
Minimum:	0.0	4.8
Maximum:	0.0	4.8
%SI	0.00	0.00

	Unit CT1 SO2, Lb 1 Day(s)	Unit CT2 SO2, Lb 1 Day(s)
05/16/2025 00:00	1.3	5.4

AQ33 DAILY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	1.3 #	5.4 #
Minimum:	1.3	5.4
Maximum:	1.3	5.4
%SI	0.00	0.00

Unit CT1	Unit CT2
SO2, Lb	SO2, Lb
1 Day(s)	1 Day(s)

05/17/2025 00:00	0.0	5.1
------------------	-----	-----

Average/Sum#:	0.0 #	5.1 #
Minimum:	0.0	5.1
Maximum:	0.0	5.1
%SI	0.00	0.00

Unit CT1	Unit CT2
SO2, Lb	SO2, Lb
1 Day(s)	1 Day(s)

05/18/2025 00:00	0.0	4.8
------------------	-----	-----

Average/Sum#:	0.0 #	4.8 #
Minimum:	0.0	4.8
Maximum:	0.0	4.8
%SI	0.00	0.00

Unit CT1	Unit CT2
SO2, Lb	SO2, Lb
1 Day(s)	1 Day(s)

05/19/2025 00:00	6.8	7.8
------------------	-----	-----

Average/Sum#:	6.8 #	7.8 #
Minimum:	6.8	7.8
Maximum:	6.8	7.8
%SI	0.00	0.00

AQ33 DAILY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	so2, Lb	so2, Lb
	1 Day(s)	1 Day(s)
05/20/2025 00:00	8.5	8.9
Average/Sum#:	8.5 #	8.9 #
Minimum:	8.5	8.9
Maximum:	8.5	8.9
%SI	0.00	0.00

	Unit CT1	Unit CT2
	so2, Lb	so2, Lb
	1 Day(s)	1 Day(s)
05/21/2025 00:00	1.2	5.3
Average/Sum#:	1.2 #	5.3 #
Minimum:	1.2	5.3
Maximum:	1.2	5.3
%SI	0.00	0.00

	Unit CT1	Unit CT2
	so2, Lb	so2, Lb
	1 Day(s)	1 Day(s)
05/22/2025 00:00	0.0	4.8
Average/Sum#:	0.0 #	4.8 #
Minimum:	0.0	4.8
Maximum:	0.0	4.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	so2, Lb	so2, Lb
	1 Day(s)	1 Day(s)
05/23/2025 00:00	0.0	5.0

AQ33 DAILY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	0.0 #	5.0 #
Minimum:	0.0	5.0
Maximum:	0.0	5.0
%SI	0.00	0.00

Unit CT1	Unit CT2
SO2, Lb	SO2, Lb
1 Day(s)	1 Day(s)

05/24/2025 00:00	0.0	5.0
------------------	-----	-----

Average/Sum#:	0.0 #	5.0 #
Minimum:	0.0	5.0
Maximum:	0.0	5.0
%SI	0.00	0.00

Unit CT1	Unit CT2
SO2, Lb	SO2, Lb
1 Day(s)	1 Day(s)

05/25/2025 00:00	0.0	4.8
------------------	-----	-----

Average/Sum#:	0.0 #	4.8 #
Minimum:	0.0	4.8
Maximum:	0.0	4.8
%SI	0.00	0.00

Unit CT1	Unit CT2
SO2, Lb	SO2, Lb
1 Day(s)	1 Day(s)

05/26/2025 00:00	0.0	4.8
------------------	-----	-----

Average/Sum#:	0.0 #	4.8 #
Minimum:	0.0	4.8
Maximum:	0.0	4.8
%SI	0.00	0.00

AQ33 DAILY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	so2, Lb	so2, Lb
	1 Day(s)	1 Day(s)
05/27/2025 00:00	0.0	5.9
Average/Sum#:	0.0 #	5.9 #
Minimum:	0.0	5.9
Maximum:	0.0	5.9
%SI	0.00	0.00

	Unit CT1	Unit CT2
	so2, Lb	so2, Lb
	1 Day(s)	1 Day(s)
05/28/2025 00:00	0.0	5.4
Average/Sum#:	0.0 #	5.4 #
Minimum:	0.0	5.4
Maximum:	0.0	5.4
%SI	0.00	0.00

	Unit CT1	Unit CT2
	so2, Lb	so2, Lb
	1 Day(s)	1 Day(s)
05/29/2025 00:00	0.0	4.8
Average/Sum#:	0.0 #	4.8 #
Minimum:	0.0	4.8
Maximum:	0.0	4.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	so2, Lb	so2, Lb
	1 Day(s)	1 Day(s)
05/30/2025 00:00	1.7	5.9

AQ33 DAILY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	1.7 #	5.9 #
Minimum:	1.7	5.9
Maximum:	1.7	5.9
%SI	0.00	0.00

Unit CT1	Unit CT2
SO2, Lb	SO2, Lb
1 Day(s)	1 Day(s)

05/31/2025 00:00	0.4	5.4
------------------	-----	-----

Average/Sum#:	0.4 #	5.4 #
Minimum:	0.4	5.4
Maximum:	0.4	5.4
%SI	0.00	0.00

Unit CT1	Unit CT2
SO2, Lb	SO2, Lb
1 Day(s)	1 Day(s)

06/01/2025 00:00	0.0	4.8
------------------	-----	-----

Average/Sum#:	0.0 #	4.8 #
Minimum:	0.0	4.8
Maximum:	0.0	4.8
%SI	0.00	0.00

Unit CT1	Unit CT2
SO2, Lb	SO2, Lb
1 Day(s)	1 Day(s)

06/02/2025 00:00	0.0	5.4
------------------	-----	-----

Average/Sum#:	0.0 #	5.4 #
Minimum:	0.0	5.4
Maximum:	0.0	5.4
%SI	0.00	0.00

AQ33 DAILY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	so2, Lb	so2, Lb
	1 Day(s)	1 Day(s)
06/03/2025 00:00	1.2	5.4
Average/Sum#:	1.2 #	5.4 #
Minimum:	1.2	5.4
Maximum:	1.2	5.4
%SI	0.00	0.00

	Unit CT1	Unit CT2
	so2, Lb	so2, Lb
	1 Day(s)	1 Day(s)
06/04/2025 00:00	0.0	4.8
Average/Sum#:	0.0 #	4.8 #
Minimum:	0.0	4.8
Maximum:	0.0	4.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	so2, Lb	so2, Lb
	1 Day(s)	1 Day(s)
06/05/2025 00:00	0.0	4.9
Average/Sum#:	0.0 #	4.9 #
Minimum:	0.0	4.9
Maximum:	0.0	4.9
%SI	0.00	0.00

	Unit CT1	Unit CT2
	so2, Lb	so2, Lb
	1 Day(s)	1 Day(s)
06/06/2025 00:00	0.0	4.9

AQ33 DAILY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	0.0 #	4.9 #
Minimum:	0.0	4.9
Maximum:	0.0	4.9
%SI	0.00	0.00

Unit CT1	Unit CT2
SO2, Lb	SO2, Lb
1 Day(s)	1 Day(s)

06/07/2025 00:00	0.0	4.9
------------------	-----	-----

Average/Sum#:	0.0 #	4.9 #
Minimum:	0.0	4.9
Maximum:	0.0	4.9
%SI	0.00	0.00

Unit CT1	Unit CT2
SO2, Lb	SO2, Lb
1 Day(s)	1 Day(s)

06/08/2025 00:00	0.0	5.3
------------------	-----	-----

Average/Sum#:	0.0 #	5.3 #
Minimum:	0.0	5.3
Maximum:	0.0	5.3
%SI	0.00	0.00

Unit CT1	Unit CT2
SO2, Lb	SO2, Lb
1 Day(s)	1 Day(s)

06/09/2025 00:00	1.8	5.3
------------------	-----	-----

Average/Sum#:	1.8 #	5.3 #
Minimum:	1.8	5.3
Maximum:	1.8	5.3
%SI	0.00	0.00

AQ33 DAILY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
06/10/2025 00:00	4.9	5.2
Average/Sum#:	4.9 #	5.2 #
Minimum:	4.9	5.2
Maximum:	4.9	5.2
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
06/11/2025 00:00	4.8	3.8
Average/Sum#:	4.8 #	3.8 #
Minimum:	4.8	3.8
Maximum:	4.8	3.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
06/12/2025 00:00	4.9	0.0
Average/Sum#:	4.9 #	0.0 #
Minimum:	4.9	0.0
Maximum:	4.9	0.0
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
06/13/2025 00:00	4.8	0.0

AQ33 DAILY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	4.8 #	0.0 #
Minimum:	4.8	0.0
Maximum:	4.8	0.0
%SI	0.00	0.00

Unit CT1	Unit CT2
SO2, Lb	SO2, Lb
1 Day(s)	1 Day(s)

06/14/2025 00:00	5.4	0.0
------------------	-----	-----

Average/Sum#:	5.4 #	0.0 #
Minimum:	5.4	0.0
Maximum:	5.4	0.0
%SI	0.00	0.00

Unit CT1	Unit CT2
SO2, Lb	SO2, Lb
1 Day(s)	1 Day(s)

06/15/2025 00:00	6.3	0.0
------------------	-----	-----

Average/Sum#:	6.3 #	0.0 #
Minimum:	6.3	0.0
Maximum:	6.3	0.0
%SI	0.00	0.00

Unit CT1	Unit CT2
SO2, Lb	SO2, Lb
1 Day(s)	1 Day(s)

06/16/2025 00:00	6.3	0.0
------------------	-----	-----

Average/Sum#:	6.3 #	0.0 #
Minimum:	6.3	0.0
Maximum:	6.3	0.0
%SI	0.00	0.00

AQ33 DAILY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, Lb 1 Day(s)	Unit CT2 SO2, Lb 1 Day(s)
06/17/2025 00:00	6.4	0.0
Average/Sum#:	6.4 #	0.0 #
Minimum:	6.4	0.0
Maximum:	6.4	0.0
%SI	0.00	0.00

	Unit CT1 SO2, Lb 1 Day(s)	Unit CT2 SO2, Lb 1 Day(s)
06/18/2025 00:00	6.5	0.0
Average/Sum#:	6.5 #	0.0 #
Minimum:	6.5	0.0
Maximum:	6.5	0.0
%SI	0.00	0.00

	Unit CT1 SO2, Lb 1 Day(s)	Unit CT2 SO2, Lb 1 Day(s)
06/19/2025 00:00	5.4	0.0
Average/Sum#:	5.4 #	0.0 #
Minimum:	5.4	0.0
Maximum:	5.4	0.0
%SI	0.00	0.00

	Unit CT1 SO2, Lb 1 Day(s)	Unit CT2 SO2, Lb 1 Day(s)
06/20/2025 00:00	4.8	0.0

AQ33 DAILY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	4.8 #	0.0 #
Minimum:	4.8	0.0
Maximum:	4.8	0.0
%SI	0.00	0.00

Unit CT1	Unit CT2
SO2, Lb	SO2, Lb
1 Day(s)	1 Day(s)

06/21/2025 00:00	4.8	0.0
------------------	-----	-----

Average/Sum#:	4.8 #	0.0 #
Minimum:	4.8	0.0
Maximum:	4.8	0.0
%SI	0.00	0.00

Unit CT1	Unit CT2
SO2, Lb	SO2, Lb
1 Day(s)	1 Day(s)

06/22/2025 00:00	4.8	0.0
------------------	-----	-----

Average/Sum#:	4.8 #	0.0 #
Minimum:	4.8	0.0
Maximum:	4.8	0.0
%SI	0.00	0.00

Unit CT1	Unit CT2
SO2, Lb	SO2, Lb
1 Day(s)	1 Day(s)

06/23/2025 00:00	5.2	0.0
------------------	-----	-----

Average/Sum#:	5.2 #	0.0 #
Minimum:	5.2	0.0
Maximum:	5.2	0.0
%SI	0.00	0.00

AQ33 DAILY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	so2, Lb	so2, Lb
	1 Day(s)	1 Day(s)
06/24/2025 00:00	5.1	0.0
Average/Sum#:	5.1 #	0.0 #
Minimum:	5.1	0.0
Maximum:	5.1	0.0
%SI	0.00	0.00

	Unit CT1	Unit CT2
	so2, Lb	so2, Lb
	1 Day(s)	1 Day(s)
06/25/2025 00:00	4.9	0.0
Average/Sum#:	4.9 #	0.0 #
Minimum:	4.9	0.0
Maximum:	4.9	0.0
%SI	0.00	0.00

	Unit CT1	Unit CT2
	so2, Lb	so2, Lb
	1 Day(s)	1 Day(s)
06/26/2025 00:00	5.0	0.0
Average/Sum#:	5.0 #	0.0 #
Minimum:	5.0	0.0
Maximum:	5.0	0.0
%SI	0.00	0.00

	Unit CT1	Unit CT2
	so2, Lb	so2, Lb
	1 Day(s)	1 Day(s)
06/27/2025 00:00	5.1	2.0

AQ33 DAILY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	5.1 #	2.0 #
Minimum:	5.1	2.0
Maximum:	5.1	2.0
%SI	0.00	0.00

Unit CT1	Unit CT2
SO2, Lb	SO2, Lb
1 Day(s)	1 Day(s)

06/28/2025 00:00 3.1 6.5

Average/Sum#:	3.1 #	6.5 #
Minimum:	3.1	6.5
Maximum:	3.1	6.5
%SI	0.00	0.00

Unit CT1	Unit CT2
SO2, Lb	SO2, Lb
1 Day(s)	1 Day(s)

06/29/2025 00:00 2.0 5.9

Average/Sum#:	2.0 #	5.9 #
Minimum:	2.0	5.9
Maximum:	2.0	5.9
%SI	0.00	0.00

Unit CT1	Unit CT2
SO2, Lb	SO2, Lb
1 Day(s)	1 Day(s)

06/30/2025 00:00 1.8 5.7

Average/Sum#:	1.8 #	5.7 #
Minimum:	1.8	5.7
Maximum:	1.8	5.7
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
04/01/2025 00:00	0.22410	0.00000
04/01/2025 01:00	0.23052	0.00000
04/01/2025 02:00	0.22314	0.00000
04/01/2025 03:00	0.24540	0.00000
04/01/2025 04:00	0.25902	0.00000
04/01/2025 05:00	0.34452	0.00000
04/01/2025 06:00	0.37818	0.00000
04/01/2025 07:00	0.31248	0.00000
04/01/2025 08:00	0.31176	0.00000
04/01/2025 09:00	0.31476	0.00000
04/01/2025 10:00	0.31866	0.00000
04/01/2025 11:00	0.31722	0.00000
04/01/2025 12:00	0.26994	0.00000
04/01/2025 13:00	0.22158	0.00000
04/01/2025 14:00	0.22308	0.00000
04/01/2025 15:00	0.22506	0.00000
04/01/2025 16:00	0.22524	0.00000
04/01/2025 17:00	0.25134	0.00000
04/01/2025 18:00	0.22884	0.00000
04/01/2025 19:00	0.22992	0.00000
04/01/2025 20:00	0.22632	0.00000
04/01/2025 21:00	0.22584	0.00000
04/01/2025 22:00	0.22596	0.00000
04/01/2025 23:00	0.22650	0.00000
Average/Sum#:	0.26081	0.00000
Minimum:	0.22158	0.00000
Maximum:	0.37818	0.00000
%SI	0.00	100.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
04/02/2025 00:00	0.22680	0.00000
04/02/2025 01:00	0.22716	0.00000
04/02/2025 02:00	0.22776	0.00000
04/02/2025 03:00	0.22836	0.00000
04/02/2025 04:00	0.26130	0.00000
04/02/2025 05:00	0.37128	0.00000
04/02/2025 06:00	0.35940	0.00000
04/02/2025 07:00	0.27564	0.00000
04/02/2025 08:00	0.22602	0.00000
04/02/2025 09:00	0.24498	0.06588
04/02/2025 10:00	0.22698	0.15396
04/02/2025 11:00	0.22062	0.28884
04/02/2025 12:00	0.21906	0.30468
04/02/2025 13:00	0.23040	0.30222
04/02/2025 14:00	0.26820	0.30090
04/02/2025 15:00	0.27378	0.21264
04/02/2025 16:00	0.24972	0.00000
04/02/2025 17:00	0.23442	0.00000
04/02/2025 18:00	0.22296	0.00000
04/02/2025 19:00	0.22302	0.00000
04/02/2025 20:00	0.22386	0.00000
04/02/2025 21:00	0.22464	0.00000
04/02/2025 22:00	0.22458	0.00000
04/02/2025 23:00	0.22470	0.00000
Average/Sum#:	0.24649	0.23273
Minimum:	0.21906	0.06588
Maximum:	0.37128	0.30468
%SI	0.00	70.83

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
04/03/2025 00:00	0.22506	0.00000
04/03/2025 01:00	0.22536	0.00000
04/03/2025 02:00	0.22542	0.00000
04/03/2025 03:00	0.25872	0.00000
04/03/2025 04:00	0.34038	0.00000
04/03/2025 05:00	0.33612	0.00000
04/03/2025 06:00	0.31632	0.00000
04/03/2025 07:00	0.23574	0.00000
04/03/2025 08:00	0.22482	0.00000
04/03/2025 09:00	0.22518	0.00000
04/03/2025 10:00	0.22518	0.00000
04/03/2025 11:00	0.22584	0.00000
04/03/2025 12:00	0.22494	0.00000
04/03/2025 13:00	0.22446	0.00000
04/03/2025 14:00	0.22956	0.00000
04/03/2025 15:00	0.22602	0.00000
04/03/2025 16:00	0.22566	0.00000
04/03/2025 17:00	0.23994	0.00000
04/03/2025 18:00	0.22524	0.00000
04/03/2025 19:00	0.22494	0.00000
04/03/2025 20:00	0.22548	0.00000
04/03/2025 21:00	0.22548	0.00000
04/03/2025 22:00	0.25278	0.00000
04/03/2025 23:00	0.26826	0.00000
Average/Sum#:	0.24404	0.00000
Minimum:	0.22446	0.00000
Maximum:	0.34038	0.00000
%SI	0.00	100.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
04/04/2025 00:00	0.22800	0.00000
04/04/2025 01:00	0.22800	0.00000
04/04/2025 02:00	0.26736	0.00000
04/04/2025 03:00	0.26280	0.00000
04/04/2025 04:00	0.23946	0.00000
04/04/2025 05:00	0.25626	0.00000
04/04/2025 06:00	0.23982	0.00000
04/04/2025 07:00	0.22620	0.00000
04/04/2025 08:00	0.22632	0.00000
04/04/2025 09:00	0.22626	0.00000
04/04/2025 10:00	0.22584	0.00000
04/04/2025 11:00	0.22572	0.00000
04/04/2025 12:00	0.22428	0.00000
04/04/2025 13:00	0.22368	0.00000
04/04/2025 14:00	0.22362	0.00000
04/04/2025 15:00	0.22344	0.00000
04/04/2025 16:00	0.22344	0.00000
04/04/2025 17:00	0.24042	0.00000
04/04/2025 18:00	0.22560	0.00000
04/04/2025 19:00	0.22710	0.00000
04/04/2025 20:00	0.22428	0.00000
04/04/2025 21:00	0.23250	0.00000
04/04/2025 22:00	0.22452	0.00000
04/04/2025 23:00	0.23694	0.00000
Average/Sum#:	0.23258	0.00000
Minimum:	0.22344	0.00000
Maximum:	0.26736	0.00000
%SI	0.00	100.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
04/05/2025 00:00	0.22392	0.00000
04/05/2025 01:00	0.22590	0.00000
04/05/2025 02:00	0.22596	0.00000
04/05/2025 03:00	0.23100	0.00000
04/05/2025 04:00	0.24432	0.00000
04/05/2025 05:00	0.26178	0.00000
04/05/2025 06:00	0.24666	0.00000
04/05/2025 07:00	0.22608	0.00000
04/05/2025 08:00	0.22572	0.00000
04/05/2025 09:00	0.22554	0.00000
04/05/2025 10:00	0.22500	0.00000
04/05/2025 11:00	0.22410	0.00000
04/05/2025 12:00	0.22278	0.00000
04/05/2025 13:00	0.22356	0.00000
04/05/2025 14:00	0.22338	0.00000
04/05/2025 15:00	0.22314	0.00000
04/05/2025 16:00	0.22332	0.00000
04/05/2025 17:00	0.24606	0.00000
04/05/2025 18:00	0.24810	0.00000
04/05/2025 19:00	0.22344	0.00000
04/05/2025 20:00	0.22326	0.00000
04/05/2025 21:00	0.22314	0.00000
04/05/2025 22:00	0.22380	0.00000
04/05/2025 23:00	0.23430	0.00000
Average/Sum#:	0.23018	0.00000
Minimum:	0.22278	0.00000
Maximum:	0.26178	0.00000
%SI	0.00	100.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
04/06/2025 00:00	0.22470	0.00000
04/06/2025 01:00	0.22590	0.00000
04/06/2025 02:00	0.22626	0.00000
04/06/2025 03:00	0.22632	0.00000
04/06/2025 04:00	0.22650	0.00000
04/06/2025 05:00	0.24204	0.00000
04/06/2025 06:00	0.23076	0.00000
04/06/2025 07:00	0.22560	0.00000
04/06/2025 08:00	0.22428	0.00000
04/06/2025 09:00	0.22296	0.00000
04/06/2025 10:00	0.22266	0.00000
04/06/2025 11:00	0.22296	0.00000
04/06/2025 12:00	0.22296	0.00000
04/06/2025 13:00	0.22176	0.00000
04/06/2025 14:00	0.22038	0.00000
04/06/2025 15:00	0.22044	0.00000
04/06/2025 16:00	0.22020	0.00000
04/06/2025 17:00	0.24354	0.00000
04/06/2025 18:00	0.22206	0.00000
04/06/2025 19:00	0.22164	0.00000
04/06/2025 20:00	0.22176	0.00000
04/06/2025 21:00	0.22356	0.00000
04/06/2025 22:00	0.22194	0.00000
04/06/2025 23:00	0.22176	0.00000
Average/Sum#:	0.22512	0.00000
Minimum:	0.22020	0.00000
Maximum:	0.24354	0.00000
%SI	0.00	100.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
04/07/2025 00:00	0.22140	0.00000
04/07/2025 01:00	0.22158	0.00000
04/07/2025 02:00	0.22254	0.00000
04/07/2025 03:00	0.22152	0.00000
04/07/2025 04:00	0.22902	0.00000
04/07/2025 05:00	0.25734	0.00000
04/07/2025 06:00	0.24402	0.00000
04/07/2025 07:00	0.22212	0.00000
04/07/2025 08:00	0.22326	0.10230
04/07/2025 09:00	0.22266	0.23706
04/07/2025 10:00	0.16368	0.26514
04/07/2025 11:00	0.00000	0.23418
04/07/2025 12:00	0.00000	0.23430
04/07/2025 13:00	0.00000	0.23448
04/07/2025 14:00	0.00000	0.23472
04/07/2025 15:00	0.00000	0.23568
04/07/2025 16:00	0.00000	0.24750
04/07/2025 17:00	0.00000	0.25854
04/07/2025 18:00	0.00000	0.23532
04/07/2025 19:00	0.00000	0.23460
04/07/2025 20:00	0.00000	0.23514
04/07/2025 21:00	0.00000	0.23526
04/07/2025 22:00	0.00000	0.23532
04/07/2025 23:00	0.00000	0.23508
Average/Sum#:	0.22265	0.23091
Minimum:	0.16368	0.10230
Maximum:	0.25734	0.26514
%SI	54.17	33.33

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
04/08/2025 00:00	0.00000	0.23550
04/08/2025 01:00	0.00000	0.23694
04/08/2025 02:00	0.00000	0.23766
04/08/2025 03:00	0.00000	0.23742
04/08/2025 04:00	0.00000	0.24162
04/08/2025 05:00	0.00000	0.23748
04/08/2025 06:00	0.00000	0.23664
04/08/2025 07:00	0.00000	0.23640
04/08/2025 08:00	0.00000	0.23634
04/08/2025 09:00	0.00000	0.23442
04/08/2025 10:00	0.00000	0.23406
04/08/2025 11:00	0.00000	0.23424
04/08/2025 12:00	0.00000	0.23412
04/08/2025 13:00	0.00000	0.23454
04/08/2025 14:00	0.00000	0.23448
04/08/2025 15:00	0.00000	0.23460
04/08/2025 16:00	0.00000	0.23418
04/08/2025 17:00	0.00000	0.24702
04/08/2025 18:00	0.00000	0.23376
04/08/2025 19:00	0.00000	0.23358
04/08/2025 20:00	0.00000	0.23358
04/08/2025 21:00	0.00000	0.23406
04/08/2025 22:00	0.00000	0.23418
04/08/2025 23:00	0.00000	0.23394
Average/Sum#:	0.00000	0.23587
Minimum:	0.00000	0.23358
Maximum:	0.00000	0.24702
%SI	100.00	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
04/09/2025 00:00	0.00000	0.23412
04/09/2025 01:00	0.00000	0.23400
04/09/2025 02:00	0.00000	0.23418
04/09/2025 03:00	0.00000	0.23466
04/09/2025 04:00	0.00000	0.23502
04/09/2025 05:00	0.00000	0.23640
04/09/2025 06:00	0.00000	0.23622
04/09/2025 07:00	0.00000	0.23652
04/09/2025 08:00	0.00000	0.23754
04/09/2025 09:00	0.00000	0.23628
04/09/2025 10:00	0.00000	0.23544
04/09/2025 11:00	0.00000	0.23550
04/09/2025 12:00	0.00000	0.23580
04/09/2025 13:00	0.00000	0.23634
04/09/2025 14:00	0.00000	0.23544
04/09/2025 15:00	0.00000	0.23358
04/09/2025 16:00	0.00000	0.23274
04/09/2025 17:00	0.00000	0.25506
04/09/2025 18:00	0.00000	0.23298
04/09/2025 19:00	0.00000	0.23256
04/09/2025 20:00	0.00000	0.23274
04/09/2025 21:00	0.00000	0.24870
04/09/2025 22:00	0.00000	0.23652
04/09/2025 23:00	0.00000	0.23364
Average/Sum#:	0.00000	0.23633
Minimum:	0.00000	0.23256
Maximum:	0.00000	0.25506
%SI	100.00	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
04/10/2025 00:00	0.00000	0.23514
04/10/2025 01:00	0.00000	0.23478
04/10/2025 02:00	0.00000	0.23520
04/10/2025 03:00	0.00000	0.23496
04/10/2025 04:00	0.00000	0.24114
04/10/2025 05:00	0.00000	0.23502
04/10/2025 06:00	0.00000	0.23406
04/10/2025 07:00	0.00000	0.23412
04/10/2025 08:00	0.00000	0.23376
04/10/2025 09:00	0.00000	0.23376
04/10/2025 10:00	0.00000	0.23334
04/10/2025 11:00	0.00000	0.23136
04/10/2025 12:00	0.00000	0.23112
04/10/2025 13:00	0.00000	0.23154
04/10/2025 14:00	0.00000	0.26040
04/10/2025 15:00	0.00000	0.23142
04/10/2025 16:00	0.00000	0.25284
04/10/2025 17:00	0.00000	0.26970
04/10/2025 18:00	0.00000	0.28620
04/10/2025 19:00	0.00000	0.26436
04/10/2025 20:00	0.00000	0.23322
04/10/2025 21:00	0.00000	0.23388
04/10/2025 22:00	0.00000	0.23424
04/10/2025 23:00	0.00000	0.23394
Average/Sum#:	0.00000	0.24081
Minimum:	0.00000	0.23112
Maximum:	0.00000	0.28620
%SI	100.00	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
04/11/2025 00:00	0.00000	0.23370
04/11/2025 01:00	0.00000	0.23340
04/11/2025 02:00	0.00000	0.23346
04/11/2025 03:00	0.00000	0.23310
04/11/2025 04:00	0.00000	0.23772
04/11/2025 05:00	0.00000	0.25548
04/11/2025 06:00	0.00000	0.23322
04/11/2025 07:00	0.00000	0.23346
04/11/2025 08:00	0.00000	0.23148
04/11/2025 09:00	0.00000	0.23064
04/11/2025 10:00	0.00000	0.23034
04/11/2025 11:00	0.00000	0.23052
04/11/2025 12:00	0.00000	0.23076
04/11/2025 13:00	0.00000	0.23118
04/11/2025 14:00	0.00000	0.23202
04/11/2025 15:00	0.00000	0.22878
04/11/2025 16:00	0.00000	0.22812
04/11/2025 17:00	0.00000	0.25224
04/11/2025 18:00	0.00000	0.22890
04/11/2025 19:00	0.00000	0.22830
04/11/2025 20:00	0.00000	0.22896
04/11/2025 21:00	0.00000	0.24852
04/11/2025 22:00	0.00000	0.22992
04/11/2025 23:00	0.00000	0.23844
Average/Sum#:	0.00000	0.23428
Minimum:	0.00000	0.22812
Maximum:	0.00000	0.25548
%SI	100.00	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
04/12/2025 00:00	0.00000	0.22914
04/12/2025 01:00	0.00000	0.22914
04/12/2025 02:00	0.00000	0.22914
04/12/2025 03:00	0.00000	0.22962
04/12/2025 04:00	0.00000	0.23124
04/12/2025 05:00	0.00000	0.23076
04/12/2025 06:00	0.00000	0.23088
04/12/2025 07:00	0.00000	0.23046
04/12/2025 08:00	0.00000	0.23076
04/12/2025 09:00	0.00000	0.23166
04/12/2025 10:00	0.00000	0.23202
04/12/2025 11:00	0.00000	0.22926
04/12/2025 12:00	0.00000	0.22872
04/12/2025 13:00	0.00000	0.22956
04/12/2025 14:00	0.00000	0.22986
04/12/2025 15:00	0.00000	0.23010
04/12/2025 16:00	0.00000	0.22920
04/12/2025 17:00	0.00000	0.23742
04/12/2025 18:00	0.00000	0.22974
04/12/2025 19:00	0.00000	0.22842
04/12/2025 20:00	0.00000	0.22974
04/12/2025 21:00	0.00000	0.22968
04/12/2025 22:00	0.00000	0.22968
04/12/2025 23:00	0.00000	0.23046
Average/Sum#:	0.00000	0.23028
Minimum:	0.00000	0.22842
Maximum:	0.00000	0.23742
%SI	100.00	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
04/13/2025 00:00	0.00000	0.23070
04/13/2025 01:00	0.00000	0.22986
04/13/2025 02:00	0.00000	0.22974
04/13/2025 03:00	0.00000	0.22974
04/13/2025 04:00	0.00000	0.23124
04/13/2025 05:00	0.00000	0.23184
04/13/2025 06:00	0.00000	0.24960
04/13/2025 07:00	0.00000	0.23172
04/13/2025 08:00	0.00000	0.23172
04/13/2025 09:00	0.00000	0.23214
04/13/2025 10:00	0.00000	0.23202
04/13/2025 11:00	0.00000	0.23220
04/13/2025 12:00	0.00000	0.23010
04/13/2025 13:00	0.00000	0.22794
04/13/2025 14:00	0.00000	0.22566
04/13/2025 15:00	0.00000	0.22524
04/13/2025 16:00	0.00000	0.22518
04/13/2025 17:00	0.00000	0.24318
04/13/2025 18:00	0.00000	0.22566
04/13/2025 19:00	0.00000	0.22554
04/13/2025 20:00	0.00000	0.22866
04/13/2025 21:00	0.00000	0.22698
04/13/2025 22:00	0.00000	0.22782
04/13/2025 23:00	0.00000	0.23316
Average/Sum#:	0.00000	0.23074
Minimum:	0.00000	0.22518
Maximum:	0.00000	0.24960
%SI	100.00	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
04/14/2025 00:00	0.00000	0.23130
04/14/2025 01:00	0.00000	0.23202
04/14/2025 02:00	0.00000	0.23250
04/14/2025 03:00	0.00000	0.23280
04/14/2025 04:00	0.00000	0.23268
04/14/2025 05:00	0.00000	0.23310
04/14/2025 06:00	0.00000	0.26070
04/14/2025 07:00	0.00000	0.22956
04/14/2025 08:00	0.00000	0.23010
04/14/2025 09:00	0.00000	0.23040
04/14/2025 10:00	0.00000	0.22956
04/14/2025 11:00	0.00000	0.22926
04/14/2025 12:00	0.00000	0.22950
04/14/2025 13:00	0.00000	0.22962
04/14/2025 14:00	0.00000	0.22920
04/14/2025 15:00	0.00000	0.22890
04/14/2025 16:00	0.00000	0.22860
04/14/2025 17:00	0.00000	0.24384
04/14/2025 18:00	0.00000	0.22914
04/14/2025 19:00	0.00000	0.22926
04/14/2025 20:00	0.00000	0.22968
04/14/2025 21:00	0.00000	0.22956
04/14/2025 22:00	0.00000	0.22992
04/14/2025 23:00	0.00000	0.23160
Average/Sum#:	0.00000	0.23220
Minimum:	0.00000	0.22860
Maximum:	0.00000	0.26070
%SI	100.00	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
04/15/2025 00:00	0.00000	0.23118
04/15/2025 01:00	0.00000	0.23058
04/15/2025 02:00	0.00000	0.23118
04/15/2025 03:00	0.00000	0.23430
04/15/2025 04:00	0.00000	0.23928
04/15/2025 05:00	0.00000	0.23244
04/15/2025 06:00	0.00000	0.23622
04/15/2025 07:00	0.00000	0.23160
04/15/2025 08:00	0.00000	0.23214
04/15/2025 09:00	0.00000	0.23250
04/15/2025 10:00	0.00000	0.23328
04/15/2025 11:00	0.00000	0.23334
04/15/2025 12:00	0.00000	0.23274
04/15/2025 13:00	0.00000	0.23142
04/15/2025 14:00	0.00000	0.23094
04/15/2025 15:00	0.00000	0.23100
04/15/2025 16:00	0.00000	0.23874
04/15/2025 17:00	0.00000	0.25488
04/15/2025 18:00	0.00000	0.23124
04/15/2025 19:00	0.00000	0.23088
04/15/2025 20:00	0.00000	0.24402
04/15/2025 21:00	0.00000	0.23034
04/15/2025 22:00	0.00000	0.23106
04/15/2025 23:00	0.00000	0.24720
Average/Sum#:	0.00000	0.23469
Minimum:	0.00000	0.23034
Maximum:	0.00000	0.25488
%SI	100.00	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
04/16/2025 00:00	0.00000	0.23160
04/16/2025 01:00	0.00000	0.23244
04/16/2025 02:00	0.00000	0.23238
04/16/2025 03:00	0.00000	0.23250
04/16/2025 04:00	0.00000	0.23232
04/16/2025 05:00	0.00000	0.23184
04/16/2025 06:00	0.00000	0.23088
04/16/2025 07:00	0.00000	0.23166
04/16/2025 08:00	0.00000	0.23196
04/16/2025 09:00	0.00000	0.23190
04/16/2025 10:00	0.00000	0.23088
04/16/2025 11:00	0.00000	0.22992
04/16/2025 12:00	0.00000	0.22992
04/16/2025 13:00	0.00000	0.22992
04/16/2025 14:00	0.00000	0.23022
04/16/2025 15:00	0.00000	0.23004
04/16/2025 16:00	0.00000	0.23010
04/16/2025 17:00	0.00000	0.23052
04/16/2025 18:00	0.00000	0.23112
04/16/2025 19:00	0.00000	0.23202
04/16/2025 20:00	0.00000	0.23280
04/16/2025 21:00	0.00000	0.23334
04/16/2025 22:00	0.00000	0.23304
04/16/2025 23:00	0.00000	0.23334
Average/Sum#:	0.00000	0.23153
Minimum:	0.00000	0.22992
Maximum:	0.00000	0.23334
%SI	100.00	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
04/17/2025 00:00	0.00000	0.23328
04/17/2025 01:00	0.00000	0.23334
04/17/2025 02:00	0.00000	0.23340
04/17/2025 03:00	0.00000	0.23352
04/17/2025 04:00	0.00000	0.23352
04/17/2025 05:00	0.00000	0.23346
04/17/2025 06:00	0.00000	0.23334
04/17/2025 07:00	0.00000	0.23226
04/17/2025 08:00	0.00000	0.24918
04/17/2025 09:00	0.00000	0.23058
04/17/2025 10:00	0.00000	0.23070
04/17/2025 11:00	0.00000	0.23058
04/17/2025 12:00	0.00000	0.23058
04/17/2025 13:00	0.00000	0.23052
04/17/2025 14:00	0.00000	0.23040
04/17/2025 15:00	0.00000	0.23688
04/17/2025 16:00	0.00000	0.23052
04/17/2025 17:00	0.00000	0.23052
04/17/2025 18:00	0.00000	0.23070
04/17/2025 19:00	0.00000	0.23046
04/17/2025 20:00	0.00000	0.23106
04/17/2025 21:00	0.00000	0.23124
04/17/2025 22:00	0.00000	0.23112
04/17/2025 23:00	0.00000	0.23118
Average/Sum#:	0.00000	0.23260
Minimum:	0.00000	0.23040
Maximum:	0.00000	0.24918
%SI	100.00	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
04/18/2025 00:00	0.00000	0.23202
04/18/2025 01:00	0.00000	0.23244
04/18/2025 02:00	0.00000	0.23250
04/18/2025 03:00	0.00000	0.23256
04/18/2025 04:00	0.00000	0.23346
04/18/2025 05:00	0.00000	0.23394
04/18/2025 06:00	0.00000	0.26994
04/18/2025 07:00	0.18846	0.26616
04/18/2025 08:00	0.22152	0.24132
04/18/2025 09:00	0.22572	0.21540
04/18/2025 10:00	0.29856	0.00000
04/18/2025 11:00	0.22116	0.00000
04/18/2025 12:00	0.22086	0.00000
04/18/2025 13:00	0.22074	0.00000
04/18/2025 14:00	0.21996	0.00000
04/18/2025 15:00	0.21906	0.00000
04/18/2025 16:00	0.21834	0.00000
04/18/2025 17:00	0.22848	0.00000
04/18/2025 18:00	0.21924	0.00000
04/18/2025 19:00	0.22578	0.00000
04/18/2025 20:00	0.27288	0.00000
04/18/2025 21:00	0.27336	0.00000
04/18/2025 22:00	0.24090	0.00000
04/18/2025 23:00	0.32592	0.00000
Average/Sum#:	0.23770	0.23897
Minimum:	0.18846	0.21540
Maximum:	0.32592	0.26994
%SI	29.17	58.33

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
04/19/2025 00:00	0.31470	0.00000
04/19/2025 01:00	0.31458	0.00000
04/19/2025 02:00	0.31422	0.00000
04/19/2025 03:00	0.31338	0.00000
04/19/2025 04:00	0.31260	0.00000
04/19/2025 05:00	0.31236	0.00000
04/19/2025 06:00	0.27378	0.00000
04/19/2025 07:00	0.21990	0.00000
04/19/2025 08:00	0.21978	0.00000
04/19/2025 09:00	0.21972	0.00000
04/19/2025 10:00	0.21966	0.00000
04/19/2025 11:00	0.22014	0.00000
04/19/2025 12:00	0.22032	0.00000
04/19/2025 13:00	0.22062	0.00000
04/19/2025 14:00	0.22050	0.00000
04/19/2025 15:00	0.22014	0.00000
04/19/2025 16:00	0.21972	0.00000
04/19/2025 17:00	0.22734	0.00000
04/19/2025 18:00	0.25242	0.00000
04/19/2025 19:00	0.31134	0.00000
04/19/2025 20:00	0.30936	0.00000
04/19/2025 21:00	0.30948	0.00000
04/19/2025 22:00	0.30978	0.00000
04/19/2025 23:00	0.23430	0.00000
Average/Sum#:	0.26292	0.00000
Minimum:	0.21966	0.00000
Maximum:	0.31470	0.00000
%SI	0.00	100.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
04/20/2025 00:00	0.22050	0.00000
04/20/2025 01:00	0.22056	0.00000
04/20/2025 02:00	0.22158	0.00000
04/20/2025 03:00	0.22254	0.00000
04/20/2025 04:00	0.22260	0.00000
04/20/2025 05:00	0.22290	0.00000
04/20/2025 06:00	0.22272	0.00000
04/20/2025 07:00	0.22284	0.00000
04/20/2025 08:00	0.22242	0.00000
04/20/2025 09:00	0.22248	0.00000
04/20/2025 10:00	0.22086	0.00000
04/20/2025 11:00	0.22074	0.00000
04/20/2025 12:00	0.22104	0.00000
04/20/2025 13:00	0.22104	0.00000
04/20/2025 14:00	0.22086	0.00000
04/20/2025 15:00	0.22026	0.00000
04/20/2025 16:00	0.21960	0.00000
04/20/2025 17:00	0.24804	0.00000
04/20/2025 18:00	0.31890	0.00000
04/20/2025 19:00	0.31728	0.00000
04/20/2025 20:00	0.31686	0.00000
04/20/2025 21:00	0.31524	0.00000
04/20/2025 22:00	0.31338	0.00000
04/20/2025 23:00	0.31170	0.00000
Average/Sum#:	0.24612	0.00000
Minimum:	0.21960	0.00000
Maximum:	0.31890	0.00000
%SI	0.00	100.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
04/21/2025 00:00	0.31140	0.00000
04/21/2025 01:00	0.31440	0.00000
04/21/2025 02:00	0.31512	0.00000
04/21/2025 03:00	0.31482	0.00000
04/21/2025 04:00	0.31458	0.00000
04/21/2025 05:00	0.31308	0.00000
04/21/2025 06:00	0.27108	0.00000
04/21/2025 07:00	0.22050	0.00000
04/21/2025 08:00	0.22050	0.00000
04/21/2025 09:00	0.22026	0.00000
04/21/2025 10:00	0.21954	0.00000
04/21/2025 11:00	0.22014	0.00000
04/21/2025 12:00	0.22098	0.00000
04/21/2025 13:00	0.22044	0.00000
04/21/2025 14:00	0.22086	0.00000
04/21/2025 15:00	0.22032	0.00000
04/21/2025 16:00	0.21960	0.00000
04/21/2025 17:00	0.27048	0.00000
04/21/2025 18:00	0.34836	0.00000
04/21/2025 19:00	0.33414	0.00000
04/21/2025 20:00	0.34974	0.00000
04/21/2025 21:00	0.36864	0.00000
04/21/2025 22:00	0.36492	0.00000
04/21/2025 23:00	0.34674	0.00000
Average/Sum#:	0.28086	0.00000
Minimum:	0.21954	0.00000
Maximum:	0.36864	0.00000
%SI	0.00	100.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
04/22/2025 00:00	0.33774	0.00000
04/22/2025 01:00	0.31794	0.00000
04/22/2025 02:00	0.31248	0.00000
04/22/2025 03:00	0.34416	0.00000
04/22/2025 04:00	0.33894	0.00000
04/22/2025 05:00	0.34104	0.00000
04/22/2025 06:00	0.30804	0.00000
04/22/2025 07:00	0.26844	0.00000
04/22/2025 08:00	0.21852	0.00000
04/22/2025 09:00	0.21846	0.00000
04/22/2025 10:00	0.21996	0.00000
04/22/2025 11:00	0.22116	0.00000
04/22/2025 12:00	0.22020	0.00000
04/22/2025 13:00	0.21960	0.00000
04/22/2025 14:00	0.21948	0.00000
04/22/2025 15:00	0.21894	0.00000
04/22/2025 16:00	0.25080	0.00000
04/22/2025 17:00	0.33792	0.00000
04/22/2025 18:00	0.35154	0.00000
04/22/2025 19:00	0.35388	0.00000
04/22/2025 20:00	0.34830	0.00000
04/22/2025 21:00	0.34536	0.00000
04/22/2025 22:00	0.34386	0.00000
04/22/2025 23:00	0.33864	0.00000
Average/Sum#:	0.29148	0.00000
Minimum:	0.21846	0.00000
Maximum:	0.35388	0.00000
%SI	0.00	100.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
04/23/2025 00:00	0.31428	0.00000
04/23/2025 01:00	0.31770	0.00000
04/23/2025 02:00	0.31284	0.00000
04/23/2025 03:00	0.31368	0.00000
04/23/2025 04:00	0.31452	0.00000
04/23/2025 05:00	0.31302	0.00000
04/23/2025 06:00	0.27486	0.00000
04/23/2025 07:00	0.22164	0.00000
04/23/2025 08:00	0.22236	0.00000
04/23/2025 09:00	0.22272	0.00000
04/23/2025 10:00	0.22326	0.00000
04/23/2025 11:00	0.22218	0.00000
04/23/2025 12:00	0.22170	0.00000
04/23/2025 13:00	0.22206	0.00000
04/23/2025 14:00	0.22128	0.00000
04/23/2025 15:00	0.22170	0.00000
04/23/2025 16:00	0.22170	0.00000
04/23/2025 17:00	0.25530	0.00000
04/23/2025 18:00	0.31674	0.00000
04/23/2025 19:00	0.31512	0.00000
04/23/2025 20:00	0.31464	0.00000
04/23/2025 21:00	0.31254	0.00000
04/23/2025 22:00	0.31374	0.00000
04/23/2025 23:00	0.31362	0.00000
Average/Sum#:	0.27180	0.00000
Minimum:	0.22128	0.00000
Maximum:	0.31770	0.00000
%SI	0.00	100.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
04/24/2025 00:00	0.31332	0.00000
04/24/2025 01:00	0.31344	0.00000
04/24/2025 02:00	0.31362	0.00000
04/24/2025 03:00	0.31386	0.00000
04/24/2025 04:00	0.31332	0.00000
04/24/2025 05:00	0.23580	0.00000
04/24/2025 06:00	0.22224	0.00000
04/24/2025 07:00	0.22242	0.00000
04/24/2025 08:00	0.22194	0.00000
04/24/2025 09:00	0.22152	0.00000
04/24/2025 10:00	0.22002	0.00000
04/24/2025 11:00	0.22002	0.00000
04/24/2025 12:00	0.21966	0.00000
04/24/2025 13:00	0.21978	0.00000
04/24/2025 14:00	0.22056	0.00000
04/24/2025 15:00	0.22026	0.00000
04/24/2025 16:00	0.23538	0.00000
04/24/2025 17:00	0.25224	0.00000
04/24/2025 18:00	0.31008	0.00000
04/24/2025 19:00	0.31230	0.00000
04/24/2025 20:00	0.31248	0.00000
04/24/2025 21:00	0.31200	0.00000
04/24/2025 22:00	0.31098	0.00000
04/24/2025 23:00	0.31104	0.00000
Average/Sum#:	0.26535	0.00000
Minimum:	0.21966	0.00000
Maximum:	0.31386	0.00000
%SI	0.00	100.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
04/25/2025 00:00	0.31104	0.00000
04/25/2025 01:00	0.31026	0.00000
04/25/2025 02:00	0.22572	0.00000
04/25/2025 03:00	0.22224	0.00000
04/25/2025 04:00	0.22752	0.00000
04/25/2025 05:00	0.27702	0.00000
04/25/2025 06:00	0.27702	0.07908
04/25/2025 07:00	0.25002	0.17574
04/25/2025 08:00	0.25530	0.25728
04/25/2025 09:00	0.25914	0.25944
04/25/2025 10:00	0.27666	0.24156
04/25/2025 11:00	0.26628	0.20628
04/25/2025 12:00	0.26052	0.20898
04/25/2025 13:00	0.23316	0.19110
04/25/2025 14:00	0.30762	0.00000
04/25/2025 15:00	0.23754	0.00000
04/25/2025 16:00	0.22674	0.00000
04/25/2025 17:00	0.25836	0.00000
04/25/2025 18:00	0.31998	0.00000
04/25/2025 19:00	0.31344	0.00000
04/25/2025 20:00	0.31320	0.00000
04/25/2025 21:00	0.26382	0.00000
04/25/2025 22:00	0.23556	0.00000
04/25/2025 23:00	0.22578	0.00000
Average/Sum#:	0.26475	0.20243
Minimum:	0.22224	0.07908
Maximum:	0.31998	0.25944
%SI	0.00	66.67

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
04/26/2025 00:00	0.22782	0.00000
04/26/2025 01:00	0.22530	0.00000
04/26/2025 02:00	0.22524	0.00000
04/26/2025 03:00	0.22536	0.00000
04/26/2025 04:00	0.22644	0.00000
04/26/2025 05:00	0.22470	0.00000
04/26/2025 06:00	0.22308	0.00000
04/26/2025 07:00	0.24150	0.00000
04/26/2025 08:00	0.26868	0.00000
04/26/2025 09:00	0.25422	0.00000
04/26/2025 10:00	0.23340	0.00000
04/26/2025 11:00	0.23520	0.00000
04/26/2025 12:00	0.22122	0.00000
04/26/2025 13:00	0.22110	0.00000
04/26/2025 14:00	0.22188	0.00000
04/26/2025 15:00	0.22128	0.00000
04/26/2025 16:00	0.25122	0.00000
04/26/2025 17:00	0.25452	0.00000
04/26/2025 18:00	0.22206	0.00000
04/26/2025 19:00	0.22746	0.00000
04/26/2025 20:00	0.22140	0.00000
04/26/2025 21:00	0.22134	0.00000
04/26/2025 22:00	0.22494	0.00000
04/26/2025 23:00	0.27618	0.00000
Average/Sum#:	0.23315	0.00000
Minimum:	0.22110	0.00000
Maximum:	0.27618	0.00000
%SI	0.00	100.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
04/27/2025 00:00	0.24516	0.00000
04/27/2025 01:00	0.22344	0.00000
04/27/2025 02:00	0.22350	0.00000
04/27/2025 03:00	0.25332	0.00000
04/27/2025 04:00	0.22362	0.00000
04/27/2025 05:00	0.22302	0.00000
04/27/2025 06:00	0.22296	0.00000
04/27/2025 07:00	0.22200	0.00000
04/27/2025 08:00	0.22152	0.00000
04/27/2025 09:00	0.22260	0.00000
04/27/2025 10:00	0.22296	0.00000
04/27/2025 11:00	0.22206	0.00000
04/27/2025 12:00	0.22170	0.00000
04/27/2025 13:00	0.22176	0.00000
04/27/2025 14:00	0.22218	0.00000
04/27/2025 15:00	0.24066	0.00000
04/27/2025 16:00	0.24378	0.00000
04/27/2025 17:00	0.22944	0.00000
04/27/2025 18:00	0.22224	0.00000
04/27/2025 19:00	0.22134	0.00000
04/27/2025 20:00	0.22164	0.00000
04/27/2025 21:00	0.22146	0.00000
04/27/2025 22:00	0.22146	0.00000
04/27/2025 23:00	0.22134	0.00000
Average/Sum#:	0.22647	0.00000
Minimum:	0.22134	0.00000
Maximum:	0.25332	0.00000
%SI	0.00	100.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
04/28/2025 00:00	0.22104	0.00000
04/28/2025 01:00	0.22092	0.00000
04/28/2025 02:00	0.22092	0.00000
04/28/2025 03:00	0.22110	0.00000
04/28/2025 04:00	0.22188	0.00000
04/28/2025 05:00	0.22290	0.00000
04/28/2025 06:00	0.22296	0.00000
04/28/2025 07:00	0.22266	0.00000
04/28/2025 08:00	0.22164	0.00000
04/28/2025 09:00	0.22188	0.00000
04/28/2025 10:00	0.22206	0.00000
04/28/2025 11:00	0.22218	0.00000
04/28/2025 12:00	0.22224	0.00000
04/28/2025 13:00	0.22170	0.00000
04/28/2025 14:00	0.22218	0.00000
04/28/2025 15:00	0.22134	0.00000
04/28/2025 16:00	0.21972	0.00000
04/28/2025 17:00	0.23124	0.00000
04/28/2025 18:00	0.21972	0.00000
04/28/2025 19:00	0.21954	0.00000
04/28/2025 20:00	0.22038	0.00000
04/28/2025 21:00	0.22254	0.00000
04/28/2025 22:00	0.22074	0.00000
04/28/2025 23:00	0.22056	0.00000
Average/Sum#:	0.22184	0.00000
Minimum:	0.21954	0.00000
Maximum:	0.23124	0.00000
%SI	0.00	100.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
04/29/2025 00:00	0.22086	0.00000
04/29/2025 01:00	0.22086	0.00000
04/29/2025 02:00	0.22242	0.00000
04/29/2025 03:00	0.22602	0.00000
04/29/2025 04:00	0.22182	0.00000
04/29/2025 05:00	0.22092	0.00000
04/29/2025 06:00	0.22050	0.00000
04/29/2025 07:00	0.22062	0.00000
04/29/2025 08:00	0.22068	0.00000
04/29/2025 09:00	0.22050	0.00000
04/29/2025 10:00	0.22062	0.00000
04/29/2025 11:00	0.22092	0.00000
04/29/2025 12:00	0.22122	0.00000
04/29/2025 13:00	0.22170	0.00000
04/29/2025 14:00	0.22140	0.00000
04/29/2025 15:00	0.22092	0.00000
04/29/2025 16:00	0.22044	0.00000
04/29/2025 17:00	0.23118	0.00000
04/29/2025 18:00	0.22152	0.00000
04/29/2025 19:00	0.22008	0.00000
04/29/2025 20:00	0.21990	0.00000
04/29/2025 21:00	0.22056	0.00000
04/29/2025 22:00	0.22206	0.00000
04/29/2025 23:00	0.22002	0.00000
Average/Sum#:	0.22157	0.00000
Minimum:	0.21990	0.00000
Maximum:	0.23118	0.00000
%SI	0.00	100.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
04/30/2025 00:00	0.21990	0.00000
04/30/2025 01:00	0.21996	0.00000
04/30/2025 02:00	0.22014	0.00000
04/30/2025 03:00	0.21972	0.00000
04/30/2025 04:00	0.21990	0.00000
04/30/2025 05:00	0.22002	0.00000
04/30/2025 06:00	0.22032	0.00000
04/30/2025 07:00	0.22026	0.00000
04/30/2025 08:00	0.21996	0.00000
04/30/2025 09:00	0.22014	0.00000
04/30/2025 10:00	0.22074	0.00000
04/30/2025 11:00	0.22050	0.00000
04/30/2025 12:00	0.21906	0.00000
04/30/2025 13:00	0.21918	0.00000
04/30/2025 14:00	0.21930	0.00000
04/30/2025 15:00	0.21840	0.00000
04/30/2025 16:00	0.21750	0.00000
04/30/2025 17:00	0.23892	0.00000
04/30/2025 18:00	0.22932	0.00000
04/30/2025 19:00	0.25104	0.00000
04/30/2025 20:00	0.26766	0.00000
04/30/2025 21:00	0.26994	0.00000
04/30/2025 22:00	0.27090	0.00000
04/30/2025 23:00	0.22998	0.00000
Average/Sum#:	0.22887	0.00000
Minimum:	0.21750	0.00000
Maximum:	0.27090	0.00000
%SI	0.00	100.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
05/01/2025 00:00	0.21744	0.00000
05/01/2025 01:00	0.22092	0.00000
05/01/2025 02:00	0.21894	0.00000
05/01/2025 03:00	0.22524	0.00000
05/01/2025 04:00	0.22800	0.00000
05/01/2025 05:00	0.22896	0.00000
05/01/2025 06:00	0.21906	0.00000
05/01/2025 07:00	0.21948	0.00000
05/01/2025 08:00	0.21942	0.00000
05/01/2025 09:00	0.21972	0.00000
05/01/2025 10:00	0.21978	0.00000
05/01/2025 11:00	0.22050	0.00000
05/01/2025 12:00	0.21894	0.00000
05/01/2025 13:00	0.21828	0.00000
05/01/2025 14:00	0.21822	0.00000
05/01/2025 15:00	0.21732	0.00000
05/01/2025 16:00	0.21708	0.00000
05/01/2025 17:00	0.24696	0.00000
05/01/2025 18:00	0.26808	0.00000
05/01/2025 19:00	0.25284	0.00000
05/01/2025 20:00	0.22602	0.00000
05/01/2025 21:00	0.26946	0.00000
05/01/2025 22:00	0.22848	0.00000
05/01/2025 23:00	0.21990	0.00000
Average/Sum#:	0.22746	0.00000
Minimum:	0.21708	0.00000
Maximum:	0.26946	0.00000
%SI	0.00	100.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
05/02/2025 00:00	0.21882	0.00000
05/02/2025 01:00	0.21882	0.00000
05/02/2025 02:00	0.21936	0.00000
05/02/2025 03:00	0.21996	0.00000
05/02/2025 04:00	0.22236	0.00000
05/02/2025 05:00	0.22584	0.00000
05/02/2025 06:00	0.23898	0.18642
05/02/2025 07:00	0.21942	0.23088
05/02/2025 08:00	0.21774	0.22884
05/02/2025 09:00	0.21744	0.22884
05/02/2025 10:00	0.21702	0.22836
05/02/2025 11:00	0.21720	0.22818
05/02/2025 12:00	0.21756	0.22818
05/02/2025 13:00	0.21696	0.22770
05/02/2025 14:00	0.21678	0.22782
05/02/2025 15:00	0.17874	0.23862
05/02/2025 16:00	0.00000	0.23136
05/02/2025 17:00	0.00000	0.25020
05/02/2025 18:00	0.00000	0.23214
05/02/2025 19:00	0.00000	0.24348
05/02/2025 20:00	0.00000	0.23286
05/02/2025 21:00	0.00000	0.23250
05/02/2025 22:00	0.00000	0.23256
05/02/2025 23:00	0.00000	0.23268
Average/Sum#:	0.21769	0.23009
Minimum:	0.17874	0.18642
Maximum:	0.23898	0.25020
%SI	33.33	25.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
05/03/2025 00:00	0.00000	0.23202
05/03/2025 01:00	0.00000	0.23202
05/03/2025 02:00	0.00000	0.23352
05/03/2025 03:00	0.00000	0.23352
05/03/2025 04:00	0.00000	0.23400
05/03/2025 05:00	0.00000	0.23430
05/03/2025 06:00	0.00000	0.23424
05/03/2025 07:00	0.00000	0.23460
05/03/2025 08:00	0.00000	0.23292
05/03/2025 09:00	0.00000	0.23262
05/03/2025 10:00	0.00000	0.23268
05/03/2025 11:00	0.00000	0.23346
05/03/2025 12:00	0.00000	0.23340
05/03/2025 13:00	0.00000	0.23178
05/03/2025 14:00	0.00000	0.23148
05/03/2025 15:00	0.00000	0.23100
05/03/2025 16:00	0.00000	0.23160
05/03/2025 17:00	0.00000	0.23586
05/03/2025 18:00	0.00000	0.23274
05/03/2025 19:00	0.00000	0.23232
05/03/2025 20:00	0.00000	0.23214
05/03/2025 21:00	0.00000	0.23226
05/03/2025 22:00	0.00000	0.23280
05/03/2025 23:00	0.00000	0.23286
Average/Sum#:	0.00000	0.23292
Minimum:	0.00000	0.23100
Maximum:	0.00000	0.23586
%SI	100.00	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
05/04/2025 00:00	0.00000	0.23226
05/04/2025 01:00	0.00000	0.23256
05/04/2025 02:00	0.00000	0.23298
05/04/2025 03:00	0.00000	0.23286
05/04/2025 04:00	0.00000	0.23304
05/04/2025 05:00	0.00000	0.23322
05/04/2025 06:00	0.00000	0.26808
05/04/2025 07:00	0.00000	0.26652
05/04/2025 08:00	0.00000	0.23250
05/04/2025 09:00	0.00000	0.23154
05/04/2025 10:00	0.00000	0.23172
05/04/2025 11:00	0.00000	0.23130
05/04/2025 12:00	0.00000	0.23106
05/04/2025 13:00	0.00000	0.23088
05/04/2025 14:00	0.00000	0.23064
05/04/2025 15:00	0.00000	0.23040
05/04/2025 16:00	0.00000	0.22968
05/04/2025 17:00	0.00000	0.25494
05/04/2025 18:00	0.00000	0.25434
05/04/2025 19:00	0.00000	0.28890
05/04/2025 20:00	0.00000	0.28920
05/04/2025 21:00	0.00000	0.29028
05/04/2025 22:00	0.00000	0.27516
05/04/2025 23:00	0.00000	0.23904
Average/Sum#:	0.00000	0.24596
Minimum:	0.00000	0.22968
Maximum:	0.00000	0.29028
%SI	100.00	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
05/05/2025 00:00	0.00000	0.23094
05/05/2025 01:00	0.00000	0.23160
05/05/2025 02:00	0.00000	0.23148
05/05/2025 03:00	0.00000	0.23208
05/05/2025 04:00	0.00000	0.23724
05/05/2025 05:00	0.00000	0.25080
05/05/2025 06:00	0.00000	0.25848
05/05/2025 07:00	0.00000	0.23256
05/05/2025 08:00	0.00000	0.23028
05/05/2025 09:00	0.00000	0.23022
05/05/2025 10:00	0.00000	0.22914
05/05/2025 11:00	0.00000	0.23004
05/05/2025 12:00	0.00000	0.23052
05/05/2025 13:00	0.00000	0.23010
05/05/2025 14:00	0.00000	0.23040
05/05/2025 15:00	0.00000	0.23064
05/05/2025 16:00	0.00000	0.23034
05/05/2025 17:00	0.00000	0.23478
05/05/2025 18:00	0.00000	0.26658
05/05/2025 19:00	0.00000	0.28644
05/05/2025 20:00	0.00000	0.28650
05/05/2025 21:00	0.00000	0.28638
05/05/2025 22:00	0.00000	0.28632
05/05/2025 23:00	0.00000	0.28392
Average/Sum#:	0.00000	0.24616
Minimum:	0.00000	0.22914
Maximum:	0.00000	0.28650
%SI	100.00	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
05/06/2025 00:00	0.00000	0.27000
05/06/2025 01:00	0.00000	0.25968
05/06/2025 02:00	0.00000	0.26046
05/06/2025 03:00	0.00000	0.25944
05/06/2025 04:00	0.00000	0.24750
05/06/2025 05:00	0.00000	0.28770
05/06/2025 06:00	0.00000	0.24546
05/06/2025 07:00	0.00000	0.23190
05/06/2025 08:00	0.00000	0.23190
05/06/2025 09:00	0.00000	0.23280
05/06/2025 10:00	0.00000	0.23292
05/06/2025 11:00	0.00000	0.23196
05/06/2025 12:00	0.00000	0.23184
05/06/2025 13:00	0.00000	0.23196
05/06/2025 14:00	0.00000	0.23196
05/06/2025 15:00	0.00000	0.23250
05/06/2025 16:00	0.00000	0.23550
05/06/2025 17:00	0.00000	0.25560
05/06/2025 18:00	0.00000	0.27786
05/06/2025 19:00	0.00000	0.28260
05/06/2025 20:00	0.00000	0.28764
05/06/2025 21:00	0.00000	0.28980
05/06/2025 22:00	0.00000	0.28860
05/06/2025 23:00	0.00000	0.27114
Average/Sum#:	0.00000	0.25453
Minimum:	0.00000	0.23184
Maximum:	0.00000	0.28980
%SI	100.00	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
05/07/2025 00:00	0.00000	0.24324
05/07/2025 01:00	0.00000	0.23178
05/07/2025 02:00	0.00000	0.23184
05/07/2025 03:00	0.00000	0.24186
05/07/2025 04:00	0.00000	0.23250
05/07/2025 05:00	0.00000	0.23316
05/07/2025 06:00	0.00000	0.23352
05/07/2025 07:00	0.00000	0.23454
05/07/2025 08:00	0.10470	0.27750
05/07/2025 09:00	0.22512	0.23598
05/07/2025 10:00	0.21906	0.23118
05/07/2025 11:00	0.21702	0.22848
05/07/2025 12:00	0.21738	0.22836
05/07/2025 13:00	0.22434	0.20232
05/07/2025 14:00	0.22020	0.00000
05/07/2025 15:00	0.22032	0.00000
05/07/2025 16:00	0.21930	0.00000
05/07/2025 17:00	0.23064	0.00000
05/07/2025 18:00	0.21960	0.00000
05/07/2025 19:00	0.21864	0.00000
05/07/2025 20:00	0.22020	0.00000
05/07/2025 21:00	0.22110	0.00000
05/07/2025 22:00	0.22128	0.00000
05/07/2025 23:00	0.22296	0.00000
Average/Sum#:	0.21387	0.23473
Minimum:	0.10470	0.20232
Maximum:	0.23064	0.27750
%SI	33.33	41.67

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
05/08/2025 00:00	0.22122	0.00000
05/08/2025 01:00	0.22116	0.00000
05/08/2025 02:00	0.22140	0.00000
05/08/2025 03:00	0.22152	0.00000
05/08/2025 04:00	0.22092	0.00000
05/08/2025 05:00	0.22284	0.00000
05/08/2025 06:00	0.22044	0.00000
05/08/2025 07:00	0.22092	0.00000
05/08/2025 08:00	0.22092	0.00000
05/08/2025 09:00	0.22164	0.00000
05/08/2025 10:00	0.22002	0.00000
05/08/2025 11:00	0.22002	0.00000
05/08/2025 12:00	0.22044	0.00000
05/08/2025 13:00	0.22212	0.00000
05/08/2025 14:00	0.22110	0.00000
05/08/2025 15:00	0.22008	0.00000
05/08/2025 16:00	0.22596	0.00000
05/08/2025 17:00	0.25080	0.00000
05/08/2025 18:00	0.28050	0.00000
05/08/2025 19:00	0.35274	0.00000
05/08/2025 20:00	0.37266	0.00000
05/08/2025 21:00	0.39438	0.00000
05/08/2025 22:00	0.36786	0.00000
05/08/2025 23:00	0.30720	0.00000
Average/Sum#:	0.25370	0.00000
Minimum:	0.22002	0.00000
Maximum:	0.39438	0.00000
%SI	0.00	100.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
05/09/2025 00:00	0.27312	0.00000
05/09/2025 01:00	0.25068	0.17484
05/09/2025 02:00	0.25530	0.26982
05/09/2025 03:00	0.26976	0.28470
05/09/2025 04:00	0.26958	0.28458
05/09/2025 05:00	0.24078	0.25356
05/09/2025 06:00	0.19464	0.24696
05/09/2025 07:00	0.00000	0.23136
05/09/2025 08:00	0.00000	0.23256
05/09/2025 09:00	0.00000	0.23226
05/09/2025 10:00	0.00000	0.23076
05/09/2025 11:00	0.00000	0.23064
05/09/2025 12:00	0.00000	0.23028
05/09/2025 13:00	0.00000	0.23070
05/09/2025 14:00	0.00000	0.23532
05/09/2025 15:00	0.00000	0.23220
05/09/2025 16:00	0.00000	0.24630
05/09/2025 17:00	0.16638	0.24342
05/09/2025 18:00	0.24150	0.25164
05/09/2025 19:00	0.26880	0.28560
05/09/2025 20:00	0.26934	0.28488
05/09/2025 21:00	0.26982	0.28518
05/09/2025 22:00	0.26952	0.28470
05/09/2025 23:00	0.26994	0.28488
Average/Sum#:	0.25065	0.25075
Minimum:	0.16638	0.17484
Maximum:	0.27312	0.28560
%SI	41.67	4.17

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
05/10/2025 00:00	0.27024	0.28554
05/10/2025 01:00	0.23070	0.24408
05/10/2025 02:00	0.20640	0.23604
05/10/2025 03:00	0.06936	0.24150
05/10/2025 04:00	0.00000	0.23190
05/10/2025 05:00	0.00000	0.23238
05/10/2025 06:00	0.00000	0.23316
05/10/2025 07:00	0.00000	0.23088
05/10/2025 08:00	0.00000	0.23064
05/10/2025 09:00	0.00000	0.23082
05/10/2025 10:00	0.00000	0.23100
05/10/2025 11:00	0.00000	0.23106
05/10/2025 12:00	0.00000	0.23028
05/10/2025 13:00	0.00000	0.22974
05/10/2025 14:00	0.00000	0.22962
05/10/2025 15:00	0.00000	0.22974
05/10/2025 16:00	0.00000	0.23154
05/10/2025 17:00	0.00000	0.24684
05/10/2025 18:00	0.00000	0.28806
05/10/2025 19:00	0.16626	0.26370
05/10/2025 20:00	0.25404	0.27276
05/10/2025 21:00	0.26850	0.28524
05/10/2025 22:00	0.26874	0.28452
05/10/2025 23:00	0.24378	0.25806
Average/Sum#:	0.21978	0.24621
Minimum:	0.06936	0.22962
Maximum:	0.27024	0.28806
%SI	62.50	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
05/11/2025 00:00	0.21690	0.26238
05/11/2025 01:00	0.05526	0.24054
05/11/2025 02:00	0.00000	0.23166
05/11/2025 03:00	0.00000	0.23166
05/11/2025 04:00	0.00000	0.23214
05/11/2025 05:00	0.00000	0.23382
05/11/2025 06:00	0.00000	0.23472
05/11/2025 07:00	0.00000	0.23484
05/11/2025 08:00	0.00000	0.23532
05/11/2025 09:00	0.00000	0.23442
05/11/2025 10:00	0.00000	0.23148
05/11/2025 11:00	0.00000	0.23124
05/11/2025 12:00	0.00000	0.23142
05/11/2025 13:00	0.00000	0.23286
05/11/2025 14:00	0.00000	0.23256
05/11/2025 15:00	0.00000	0.23196
05/11/2025 16:00	0.00000	0.23160
05/11/2025 17:00	0.00000	0.24906
05/11/2025 18:00	0.00000	0.23316
05/11/2025 19:00	0.00000	0.24348
05/11/2025 20:00	0.00000	0.23820
05/11/2025 21:00	0.00000	0.23616
05/11/2025 22:00	0.00000	0.23652
05/11/2025 23:00	0.00000	0.23244
Average/Sum#:	0.13608	0.23599
Minimum:	0.05526	0.23124
Maximum:	0.21690	0.26238
%SI	91.67	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
05/12/2025 00:00	0.00000	0.23412
05/12/2025 01:00	0.00000	0.23502
05/12/2025 02:00	0.00000	0.23454
05/12/2025 03:00	0.00000	0.23442
05/12/2025 04:00	0.00000	0.23370
05/12/2025 05:00	0.00000	0.23382
05/12/2025 06:00	0.00000	0.23376
05/12/2025 07:00	0.00000	0.23334
05/12/2025 08:00	0.00000	0.23244
05/12/2025 09:00	0.00000	0.23514
05/12/2025 10:00	0.00000	0.23322
05/12/2025 11:00	0.00000	0.23184
05/12/2025 12:00	0.00000	0.23184
05/12/2025 13:00	0.00000	0.23178
05/12/2025 14:00	0.00000	0.23190
05/12/2025 15:00	0.00000	0.23172
05/12/2025 16:00	0.00000	0.23178
05/12/2025 17:00	0.00000	0.23250
05/12/2025 18:00	0.00000	0.23154
05/12/2025 19:00	0.00000	0.23106
05/12/2025 20:00	0.00000	0.23100
05/12/2025 21:00	0.00000	0.23118
05/12/2025 22:00	0.00000	0.23088
05/12/2025 23:00	0.00000	0.23100
Average/Sum#:	0.00000	0.23265
Minimum:	0.00000	0.23088
Maximum:	0.00000	0.23514
%SI	100.00	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
05/13/2025 00:00	0.00000	0.23226
05/13/2025 01:00	0.00000	0.23370
05/13/2025 02:00	0.00000	0.23256
05/13/2025 03:00	0.00000	0.23250
05/13/2025 04:00	0.00000	0.23262
05/13/2025 05:00	0.00000	0.23250
05/13/2025 06:00	0.00000	0.23214
05/13/2025 07:00	0.00000	0.23184
05/13/2025 08:00	0.00000	0.23232
05/13/2025 09:00	0.00000	0.23214
05/13/2025 10:00	0.00000	0.23208
05/13/2025 11:00	0.00000	0.23280
05/13/2025 12:00	0.00000	0.23298
05/13/2025 13:00	0.00000	0.23250
05/13/2025 14:00	0.00000	0.23268
05/13/2025 15:00	0.00000	0.23184
05/13/2025 16:00	0.00000	0.23154
05/13/2025 17:00	0.00000	0.23184
05/13/2025 18:00	0.00000	0.23190
05/13/2025 19:00	0.00000	0.23232
05/13/2025 20:00	0.00000	0.23220
05/13/2025 21:00	0.00000	0.23232
05/13/2025 22:00	0.00000	0.23238
05/13/2025 23:00	0.00000	0.23274
Average/Sum#:	0.00000	0.23236
Minimum:	0.00000	0.23154
Maximum:	0.00000	0.23370
%SI	100.00	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
05/14/2025 00:00	0.00000	0.23262
05/14/2025 01:00	0.00000	0.23274
05/14/2025 02:00	0.00000	0.23256
05/14/2025 03:00	0.00000	0.23310
05/14/2025 04:00	0.00000	0.23598
05/14/2025 05:00	0.00000	0.25032
05/14/2025 06:00	0.00000	0.23406
05/14/2025 07:00	0.00000	0.23490
05/14/2025 08:00	0.00000	0.23472
05/14/2025 09:00	0.00000	0.23454
05/14/2025 10:00	0.00000	0.23448
05/14/2025 11:00	0.00000	0.23484
05/14/2025 12:00	0.00000	0.23448
05/14/2025 13:00	0.00000	0.23442
05/14/2025 14:00	0.00000	0.23412
05/14/2025 15:00	0.00000	0.23454
05/14/2025 16:00	0.00000	0.23508
05/14/2025 17:00	0.00000	0.23514
05/14/2025 18:00	0.00000	0.23502
05/14/2025 19:00	0.00000	0.23466
05/14/2025 20:00	0.00000	0.23502
05/14/2025 21:00	0.00000	0.23454
05/14/2025 22:00	0.00000	0.23472
05/14/2025 23:00	0.00000	0.23496
Average/Sum#:	0.00000	0.23507
Minimum:	0.00000	0.23256
Maximum:	0.00000	0.25032
%SI	100.00	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
05/15/2025 00:00	0.00000	0.23454
05/15/2025 01:00	0.00000	0.23424
05/15/2025 02:00	0.00000	0.23418
05/15/2025 03:00	0.00000	0.23412
05/15/2025 04:00	0.00000	0.23370
05/15/2025 05:00	0.00000	0.23190
05/15/2025 06:00	0.00000	0.23088
05/15/2025 07:00	0.00000	0.23076
05/15/2025 08:00	0.00000	0.23058
05/15/2025 09:00	0.00000	0.23124
05/15/2025 10:00	0.00000	0.23166
05/15/2025 11:00	0.00000	0.23016
05/15/2025 12:00	0.00000	0.22980
05/15/2025 13:00	0.00000	0.23040
05/15/2025 14:00	0.00000	0.23082
05/15/2025 15:00	0.00000	0.23034
05/15/2025 16:00	0.00000	0.23004
05/15/2025 17:00	0.00000	0.23766
05/15/2025 18:00	0.00000	0.23052
05/15/2025 19:00	0.00000	0.23022
05/15/2025 20:00	0.00000	0.23178
05/15/2025 21:00	0.00000	0.23268
05/15/2025 22:00	0.00000	0.23274
05/15/2025 23:00	0.00000	0.23250
Average/Sum#:	0.00000	0.23198
Minimum:	0.00000	0.22980
Maximum:	0.00000	0.23766
%SI	100.00	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
05/16/2025 00:00	0.00000	0.23244
05/16/2025 01:00	0.00000	0.23244
05/16/2025 02:00	0.00000	0.23280
05/16/2025 03:00	0.00000	0.23226
05/16/2025 04:00	0.00000	0.23214
05/16/2025 05:00	0.00000	0.23208
05/16/2025 06:00	0.00000	0.23220
05/16/2025 07:00	0.00000	0.23274
05/16/2025 08:00	0.00000	0.23310
05/16/2025 09:00	0.00000	0.23352
05/16/2025 10:00	0.00000	0.23370
05/16/2025 11:00	0.00000	0.23616
05/16/2025 12:00	0.00000	0.25614
05/16/2025 13:00	0.00000	0.28398
05/16/2025 14:00	0.14304	0.26976
05/16/2025 15:00	0.22218	0.23238
05/16/2025 16:00	0.22068	0.23256
05/16/2025 17:00	0.23508	0.24900
05/16/2025 18:00	0.23718	0.25212
05/16/2025 19:00	0.21798	0.23046
05/16/2025 20:00	0.21522	0.23202
05/16/2025 21:00	0.11466	0.23496
05/16/2025 22:00	0.00000	0.27558
05/16/2025 23:00	0.00000	0.29022
Average/Sum#:	0.20075	0.24312
Minimum:	0.11466	0.23046
Maximum:	0.23718	0.29022
%SI	66.67	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
05/17/2025 00:00	0.00000	0.27528
05/17/2025 01:00	0.00000	0.23244
05/17/2025 02:00	0.00000	0.23334
05/17/2025 03:00	0.00000	0.23346
05/17/2025 04:00	0.00000	0.23328
05/17/2025 05:00	0.00000	0.23838
05/17/2025 06:00	0.00000	0.27150
05/17/2025 07:00	0.00000	0.25770
05/17/2025 08:00	0.00000	0.23250
05/17/2025 09:00	0.00000	0.23064
05/17/2025 10:00	0.00000	0.23040
05/17/2025 11:00	0.00000	0.23022
05/17/2025 12:00	0.00000	0.23010
05/17/2025 13:00	0.00000	0.22998
05/17/2025 14:00	0.00000	0.22974
05/17/2025 15:00	0.00000	0.22968
05/17/2025 16:00	0.00000	0.22980
05/17/2025 17:00	0.00000	0.23322
05/17/2025 18:00	0.00000	0.23040
05/17/2025 19:00	0.00000	0.23046
05/17/2025 20:00	0.00000	0.23076
05/17/2025 21:00	0.00000	0.23076
05/17/2025 22:00	0.00000	0.23100
05/17/2025 23:00	0.00000	0.23112
Average/Sum#:	0.00000	0.23609
Minimum:	0.00000	0.22968
Maximum:	0.00000	0.27528
%SI	100.00	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
05/18/2025 00:00	0.00000	0.23124
05/18/2025 01:00	0.00000	0.23136
05/18/2025 02:00	0.00000	0.23130
05/18/2025 03:00	0.00000	0.23142
05/18/2025 04:00	0.00000	0.23148
05/18/2025 05:00	0.00000	0.23160
05/18/2025 06:00	0.00000	0.23154
05/18/2025 07:00	0.00000	0.23136
05/18/2025 08:00	0.00000	0.23112
05/18/2025 09:00	0.00000	0.23082
05/18/2025 10:00	0.00000	0.23040
05/18/2025 11:00	0.00000	0.23016
05/18/2025 12:00	0.00000	0.22980
05/18/2025 13:00	0.00000	0.22974
05/18/2025 14:00	0.00000	0.22974
05/18/2025 15:00	0.00000	0.22938
05/18/2025 16:00	0.00000	0.22938
05/18/2025 17:00	0.00000	0.22944
05/18/2025 18:00	0.00000	0.24834
05/18/2025 19:00	0.00000	0.23022
05/18/2025 20:00	0.00000	0.23016
05/18/2025 21:00	0.00000	0.23046
05/18/2025 22:00	0.00000	0.23070
05/18/2025 23:00	0.00000	0.23082
Average/Sum#:	0.00000	0.23133
Minimum:	0.00000	0.22938
Maximum:	0.00000	0.24834
%SI	100.00	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
05/19/2025 00:00	0.00000	0.23082
05/19/2025 01:00	0.00000	0.23088
05/19/2025 02:00	0.00000	0.23418
05/19/2025 03:00	0.17862	0.27996
05/19/2025 04:00	0.23364	0.24666
05/19/2025 05:00	0.22026	0.23142
05/19/2025 06:00	0.24660	0.25998
05/19/2025 07:00	0.34044	0.36672
05/19/2025 08:00	0.37002	0.39510
05/19/2025 09:00	0.36912	0.39420
05/19/2025 10:00	0.37116	0.39618
05/19/2025 11:00	0.37416	0.39816
05/19/2025 12:00	0.37572	0.39972
05/19/2025 13:00	0.37578	0.39984
05/19/2025 14:00	0.37464	0.39900
05/19/2025 15:00	0.37470	0.39942
05/19/2025 16:00	0.37428	0.39864
05/19/2025 17:00	0.37386	0.39774
05/19/2025 18:00	0.36648	0.39048
05/19/2025 19:00	0.26454	0.28500
05/19/2025 20:00	0.21840	0.23046
05/19/2025 21:00	0.26802	0.28296
05/19/2025 22:00	0.27174	0.28716
05/19/2025 23:00	0.27180	0.28710
<hr/>		
Average/Sum#:	0.31495	0.32591
Minimum:	0.17862	0.23046
Maximum:	0.37578	0.39984
%SI	12.50	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
05/20/2025 00:00	0.27198	0.28758
05/20/2025 01:00	0.27156	0.28704
05/20/2025 02:00	0.27114	0.28638
05/20/2025 03:00	0.27636	0.29424
05/20/2025 04:00	0.34098	0.36702
05/20/2025 05:00	0.36216	0.38952
05/20/2025 06:00	0.36030	0.38838
05/20/2025 07:00	0.36258	0.38682
05/20/2025 08:00	0.36762	0.38592
05/20/2025 09:00	0.36978	0.38364
05/20/2025 10:00	0.37392	0.38190
05/20/2025 11:00	0.37506	0.38220
05/20/2025 12:00	0.37656	0.38106
05/20/2025 13:00	0.37824	0.37998
05/20/2025 14:00	0.37818	0.37962
05/20/2025 15:00	0.37698	0.37908
05/20/2025 16:00	0.32598	0.36678
05/20/2025 17:00	0.30720	0.33360
05/20/2025 18:00	0.34410	0.37122
05/20/2025 19:00	0.35460	0.38166
05/20/2025 20:00	0.32448	0.37818
05/20/2025 21:00	0.37314	0.40998
05/20/2025 22:00	0.28896	0.34956
05/20/2025 23:00	0.27402	0.28968
Average/Sum#:	0.33775	0.35921
Minimum:	0.27114	0.28638
Maximum:	0.37824	0.40998
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
05/21/2025 00:00	0.24402	0.26580
05/21/2025 01:00	0.09498	0.23880
05/21/2025 02:00	0.00000	0.23358
05/21/2025 03:00	0.00000	0.23364
05/21/2025 04:00	0.00000	0.23352
05/21/2025 05:00	0.00000	0.23280
05/21/2025 06:00	0.00000	0.23280
05/21/2025 07:00	0.00000	0.23310
05/21/2025 08:00	0.00000	0.23250
05/21/2025 09:00	0.00000	0.23112
05/21/2025 10:00	0.00000	0.23094
05/21/2025 11:00	0.00000	0.23100
05/21/2025 12:00	0.00000	0.23100
05/21/2025 13:00	0.00000	0.23082
05/21/2025 14:00	0.00000	0.23088
05/21/2025 15:00	0.00000	0.23088
05/21/2025 16:00	0.00000	0.23058
05/21/2025 17:00	0.04914	0.27654
05/21/2025 18:00	0.21912	0.25002
05/21/2025 19:00	0.26334	0.28068
05/21/2025 20:00	0.24864	0.26340
05/21/2025 21:00	0.22668	0.24030
05/21/2025 22:00	0.19116	0.24582
05/21/2025 23:00	0.00000	0.23196
Average/Sum#:	0.19214	0.24052
Minimum:	0.04914	0.23058
Maximum:	0.26334	0.28068
%SI	66.67	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
05/22/2025 00:00	0.00000	0.23280
05/22/2025 01:00	0.00000	0.23286
05/22/2025 02:00	0.00000	0.23256
05/22/2025 03:00	0.00000	0.23268
05/22/2025 04:00	0.00000	0.23322
05/22/2025 05:00	0.00000	0.23376
05/22/2025 06:00	0.00000	0.23238
05/22/2025 07:00	0.00000	0.23214
05/22/2025 08:00	0.00000	0.23244
05/22/2025 09:00	0.00000	0.23334
05/22/2025 10:00	0.00000	0.23160
05/22/2025 11:00	0.00000	0.23076
05/22/2025 12:00	0.00000	0.23028
05/22/2025 13:00	0.00000	0.23004
05/22/2025 14:00	0.00000	0.22968
05/22/2025 15:00	0.00000	0.23016
05/22/2025 16:00	0.00000	0.23076
05/22/2025 17:00	0.00000	0.23184
05/22/2025 18:00	0.00000	0.23088
05/22/2025 19:00	0.00000	0.23148
05/22/2025 20:00	0.00000	0.23226
05/22/2025 21:00	0.00000	0.23244
05/22/2025 22:00	0.00000	0.23202
05/22/2025 23:00	0.00000	0.23334
Average/Sum#:	0.00000	0.23191
Minimum:	0.00000	0.22968
Maximum:	0.00000	0.23376
%SI	100.00	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
05/23/2025 00:00	0.00000	0.23460
05/23/2025 01:00	0.00000	0.23496
05/23/2025 02:00	0.00000	0.23538
05/23/2025 03:00	0.00000	0.23598
05/23/2025 04:00	0.00000	0.23568
05/23/2025 05:00	0.00000	0.23412
05/23/2025 06:00	0.00000	0.23286
05/23/2025 07:00	0.00000	0.23250
05/23/2025 08:00	0.00000	0.23274
05/23/2025 09:00	0.00000	0.23304
05/23/2025 10:00	0.00000	0.23328
05/23/2025 11:00	0.00000	0.23304
05/23/2025 12:00	0.00000	0.23124
05/23/2025 13:00	0.00000	0.23112
05/23/2025 14:00	0.00000	0.23130
05/23/2025 15:00	0.00000	0.23136
05/23/2025 16:00	0.00000	0.23070
05/23/2025 17:00	0.00000	0.24414
05/23/2025 18:00	0.00000	0.24150
05/23/2025 19:00	0.00000	0.23706
05/23/2025 20:00	0.00000	0.24318
05/23/2025 21:00	0.00000	0.27246
05/23/2025 22:00	0.00000	0.24876
05/23/2025 23:00	0.00000	0.28140
Average/Sum#:	0.00000	0.23885
Minimum:	0.00000	0.23070
Maximum:	0.00000	0.28140
%SI	100.00	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
05/24/2025 00:00	0.00000	0.27462
05/24/2025 01:00	0.00000	0.24678
05/24/2025 02:00	0.00000	0.23250
05/24/2025 03:00	0.00000	0.23226
05/24/2025 04:00	0.00000	0.23250
05/24/2025 05:00	0.00000	0.23262
05/24/2025 06:00	0.00000	0.23214
05/24/2025 07:00	0.00000	0.23202
05/24/2025 08:00	0.00000	0.23160
05/24/2025 09:00	0.00000	0.23196
05/24/2025 10:00	0.00000	0.23250
05/24/2025 11:00	0.00000	0.23088
05/24/2025 12:00	0.00000	0.23010
05/24/2025 13:00	0.00000	0.23040
05/24/2025 14:00	0.00000	0.23010
05/24/2025 15:00	0.00000	0.23100
05/24/2025 16:00	0.00000	0.23070
05/24/2025 17:00	0.00000	0.24948
05/24/2025 18:00	0.00000	0.25944
05/24/2025 19:00	0.00000	0.23100
05/24/2025 20:00	0.00000	0.23328
05/24/2025 21:00	0.00000	0.23154
05/24/2025 22:00	0.00000	0.23154
05/24/2025 23:00	0.00000	0.23088
Average/Sum#:	0.00000	0.23591
Minimum:	0.00000	0.23010
Maximum:	0.00000	0.27462
%SI	100.00	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
05/25/2025 00:00	0.00000	0.23166
05/25/2025 01:00	0.00000	0.23286
05/25/2025 02:00	0.00000	0.23280
05/25/2025 03:00	0.00000	0.23310
05/25/2025 04:00	0.00000	0.23484
05/25/2025 05:00	0.00000	0.24804
05/25/2025 06:00	0.00000	0.23466
05/25/2025 07:00	0.00000	0.23454
05/25/2025 08:00	0.00000	0.23454
05/25/2025 09:00	0.00000	0.23502
05/25/2025 10:00	0.00000	0.23328
05/25/2025 11:00	0.00000	0.23280
05/25/2025 12:00	0.00000	0.23268
05/25/2025 13:00	0.00000	0.23328
05/25/2025 14:00	0.00000	0.23304
05/25/2025 15:00	0.00000	0.23184
05/25/2025 16:00	0.00000	0.23154
05/25/2025 17:00	0.00000	0.23142
05/25/2025 18:00	0.00000	0.23244
05/25/2025 19:00	0.00000	0.23202
05/25/2025 20:00	0.00000	0.23418
05/25/2025 21:00	0.00000	0.23472
05/25/2025 22:00	0.00000	0.23274
05/25/2025 23:00	0.00000	0.23292
Average/Sum#:	0.00000	0.23379
Minimum:	0.00000	0.23142
Maximum:	0.00000	0.24804
%SI	100.00	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
05/26/2025 00:00	0.00000	0.23352
05/26/2025 01:00	0.00000	0.23340
05/26/2025 02:00	0.00000	0.23322
05/26/2025 03:00	0.00000	0.23382
05/26/2025 04:00	0.00000	0.23430
05/26/2025 05:00	0.00000	0.23268
05/26/2025 06:00	0.00000	0.23166
05/26/2025 07:00	0.00000	0.23148
05/26/2025 08:00	0.00000	0.23178
05/26/2025 09:00	0.00000	0.23214
05/26/2025 10:00	0.00000	0.23262
05/26/2025 11:00	0.00000	0.23178
05/26/2025 12:00	0.00000	0.23076
05/26/2025 13:00	0.00000	0.23052
05/26/2025 14:00	0.00000	0.23058
05/26/2025 15:00	0.00000	0.23040
05/26/2025 16:00	0.00000	0.23058
05/26/2025 17:00	0.00000	0.23418
05/26/2025 18:00	0.00000	0.23226
05/26/2025 19:00	0.00000	0.23112
05/26/2025 20:00	0.00000	0.23142
05/26/2025 21:00	0.00000	0.23280
05/26/2025 22:00	0.00000	0.23292
05/26/2025 23:00	0.00000	0.23256
Average/Sum#:	0.00000	0.23219
Minimum:	0.00000	0.23040
Maximum:	0.00000	0.23430
%SI	100.00	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
05/27/2025 00:00	0.00000	0.23256
05/27/2025 01:00	0.00000	0.23256
05/27/2025 02:00	0.00000	0.23256
05/27/2025 03:00	0.00000	0.23262
05/27/2025 04:00	0.00000	0.23310
05/27/2025 05:00	0.00000	0.23244
05/27/2025 06:00	0.00000	0.23256
05/27/2025 07:00	0.00000	0.23280
05/27/2025 08:00	0.00000	0.23478
05/27/2025 09:00	0.00000	0.23244
05/27/2025 10:00	0.00000	0.25896
05/27/2025 11:00	0.00000	0.27972
05/27/2025 12:00	0.00000	0.23286
05/27/2025 13:00	0.00000	0.23424
05/27/2025 14:00	0.00000	0.28344
05/27/2025 15:00	0.00000	0.28458
05/27/2025 16:00	0.00000	0.24258
05/27/2025 17:00	0.00000	0.26784
05/27/2025 18:00	0.00000	0.29130
05/27/2025 19:00	0.00000	0.29088
05/27/2025 20:00	0.00000	0.29052
05/27/2025 21:00	0.00000	0.29076
05/27/2025 22:00	0.00000	0.29118
05/27/2025 23:00	0.00000	0.29160
Average/Sum#:	0.00000	0.25662
Minimum:	0.00000	0.23244
Maximum:	0.00000	0.29160
%SI	100.00	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
05/28/2025 00:00	0.00000	0.28950
05/28/2025 01:00	0.00000	0.29034
05/28/2025 02:00	0.00000	0.28968
05/28/2025 03:00	0.00000	0.28548
05/28/2025 04:00	0.00000	0.27252
05/28/2025 05:00	0.00000	0.24486
05/28/2025 06:00	0.00000	0.23442
05/28/2025 07:00	0.00000	0.23430
05/28/2025 08:00	0.00000	0.23448
05/28/2025 09:00	0.00000	0.23520
05/28/2025 10:00	0.00000	0.23514
05/28/2025 11:00	0.00000	0.23064
05/28/2025 12:00	0.00000	0.23016
05/28/2025 13:00	0.00000	0.23034
05/28/2025 14:00	0.00000	0.23100
05/28/2025 15:00	0.00000	0.23076
05/28/2025 16:00	0.00000	0.23076
05/28/2025 17:00	0.00000	0.23442
05/28/2025 18:00	0.00000	0.27420
05/28/2025 19:00	0.00000	0.23268
05/28/2025 20:00	0.00000	0.23010
05/28/2025 21:00	0.00000	0.23064
05/28/2025 22:00	0.00000	0.23082
05/28/2025 23:00	0.00000	0.23106
Average/Sum#:	0.00000	0.24556
Minimum:	0.00000	0.23010
Maximum:	0.00000	0.29034
%SI	100.00	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
05/29/2025 00:00	0.00000	0.23106
05/29/2025 01:00	0.00000	0.23094
05/29/2025 02:00	0.00000	0.23148
05/29/2025 03:00	0.00000	0.23118
05/29/2025 04:00	0.00000	0.24858
05/29/2025 05:00	0.00000	0.24924
05/29/2025 06:00	0.00000	0.23484
05/29/2025 07:00	0.00000	0.23496
05/29/2025 08:00	0.00000	0.23556
05/29/2025 09:00	0.00000	0.23424
05/29/2025 10:00	0.00000	0.23352
05/29/2025 11:00	0.00000	0.23412
05/29/2025 12:00	0.00000	0.23430
05/29/2025 13:00	0.00000	0.23382
05/29/2025 14:00	0.00000	0.23274
05/29/2025 15:00	0.00000	0.23208
05/29/2025 16:00	0.00000	0.23148
05/29/2025 17:00	0.00000	0.23802
05/29/2025 18:00	0.00000	0.22914
05/29/2025 19:00	0.00000	0.22872
05/29/2025 20:00	0.00000	0.22890
05/29/2025 21:00	0.00000	0.22842
05/29/2025 22:00	0.00000	0.22974
05/29/2025 23:00	0.00000	0.22944
Average/Sum#:	0.00000	0.23361
Minimum:	0.00000	0.22842
Maximum:	0.00000	0.24924
%SI	100.00	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
05/30/2025 00:00	0.00000	0.23004
05/30/2025 01:00	0.00000	0.23022
05/30/2025 02:00	0.00000	0.23052
05/30/2025 03:00	0.00000	0.23088
05/30/2025 04:00	0.00000	0.23082
05/30/2025 05:00	0.00000	0.23262
05/30/2025 06:00	0.00000	0.23448
05/30/2025 07:00	0.00000	0.23436
05/30/2025 08:00	0.00000	0.23484
05/30/2025 09:00	0.00000	0.23484
05/30/2025 10:00	0.00000	0.23484
05/30/2025 11:00	0.00000	0.23328
05/30/2025 12:00	0.00000	0.24702
05/30/2025 13:00	0.00000	0.26400
05/30/2025 14:00	0.00000	0.27348
05/30/2025 15:00	0.00000	0.26316
05/30/2025 16:00	0.13044	0.26616
05/30/2025 17:00	0.22008	0.25884
05/30/2025 18:00	0.24936	0.26664
05/30/2025 19:00	0.25032	0.26850
05/30/2025 20:00	0.26538	0.28626
05/30/2025 21:00	0.26598	0.28632
05/30/2025 22:00	0.24786	0.26388
05/30/2025 23:00	0.24666	0.26112
Average/Sum#:	0.23451	0.24988
Minimum:	0.13044	0.23004
Maximum:	0.26598	0.28632
%SI	66.67	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
05/31/2025 00:00	0.22356	0.23670
05/31/2025 01:00	0.22008	0.24360
05/31/2025 02:00	0.09588	0.23802
05/31/2025 03:00	0.00000	0.23268
05/31/2025 04:00	0.00000	0.23262
05/31/2025 05:00	0.00000	0.23364
05/31/2025 06:00	0.00000	0.23526
05/31/2025 07:00	0.00000	0.23448
05/31/2025 08:00	0.00000	0.23334
05/31/2025 09:00	0.00000	0.23346
05/31/2025 10:00	0.00000	0.23358
05/31/2025 11:00	0.00000	0.23310
05/31/2025 12:00	0.00000	0.23280
05/31/2025 13:00	0.00000	0.23328
05/31/2025 14:00	0.00000	0.22992
05/31/2025 15:00	0.00000	0.22908
05/31/2025 16:00	0.00000	0.23802
05/31/2025 17:00	0.00000	0.25812
05/31/2025 18:00	0.00000	0.28398
05/31/2025 19:00	0.00000	0.28338
05/31/2025 20:00	0.00000	0.28422
05/31/2025 21:00	0.00000	0.26184
05/31/2025 22:00	0.00000	0.26226
05/31/2025 23:00	0.00000	0.23178
Average/Sum#:	0.17984	0.24372
Minimum:	0.09588	0.22908
Maximum:	0.22356	0.28422
%SI	87.50	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
06/01/2025 00:00	0.00000	0.23070
06/01/2025 01:00	0.00000	0.23058
06/01/2025 02:00	0.00000	0.23118
06/01/2025 03:00	0.00000	0.23250
06/01/2025 04:00	0.00000	0.23250
06/01/2025 05:00	0.00000	0.23106
06/01/2025 06:00	0.00000	0.23202
06/01/2025 07:00	0.00000	0.23238
06/01/2025 08:00	0.00000	0.23232
06/01/2025 09:00	0.00000	0.23274
06/01/2025 10:00	0.00000	0.23304
06/01/2025 11:00	0.00000	0.23172
06/01/2025 12:00	0.00000	0.23148
06/01/2025 13:00	0.00000	0.23100
06/01/2025 14:00	0.00000	0.23334
06/01/2025 15:00	0.00000	0.23070
06/01/2025 16:00	0.00000	0.23046
06/01/2025 17:00	0.00000	0.23178
06/01/2025 18:00	0.00000	0.23034
06/01/2025 19:00	0.00000	0.23190
06/01/2025 20:00	0.00000	0.23052
06/01/2025 21:00	0.00000	0.23124
06/01/2025 22:00	0.00000	0.23196
06/01/2025 23:00	0.00000	0.23256
Average/Sum#:	0.00000	0.23167
Minimum:	0.00000	0.23034
Maximum:	0.00000	0.23334
%SI	100.00	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
06/02/2025 00:00	0.00000	0.23286
06/02/2025 01:00	0.00000	0.23274
06/02/2025 02:00	0.00000	0.23292
06/02/2025 03:00	0.00000	0.23280
06/02/2025 04:00	0.00000	0.26076
06/02/2025 05:00	0.00000	0.26472
06/02/2025 06:00	0.00000	0.23232
06/02/2025 07:00	0.00000	0.23244
06/02/2025 08:00	0.00000	0.23298
06/02/2025 09:00	0.00000	0.23322
06/02/2025 10:00	0.00000	0.23232
06/02/2025 11:00	0.00000	0.23070
06/02/2025 12:00	0.00000	0.23076
06/02/2025 13:00	0.00000	0.23070
06/02/2025 14:00	0.00000	0.24774
06/02/2025 15:00	0.00000	0.22968
06/02/2025 16:00	0.00000	0.22884
06/02/2025 17:00	0.00000	0.24894
06/02/2025 18:00	0.00000	0.28914
06/02/2025 19:00	0.00000	0.28812
06/02/2025 20:00	0.00000	0.28800
06/02/2025 21:00	0.00000	0.24564
06/02/2025 22:00	0.00000	0.26880
06/02/2025 23:00	0.00000	0.24990
Average/Sum#:	0.00000	0.24571
Minimum:	0.00000	0.22884
Maximum:	0.00000	0.28914
%SI	100.00	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
06/03/2025 00:00	0.00000	0.23478
06/03/2025 01:00	0.00000	0.23268
06/03/2025 02:00	0.00000	0.23226
06/03/2025 03:00	0.00000	0.23316
06/03/2025 04:00	0.00000	0.23328
06/03/2025 05:00	0.00000	0.23412
06/03/2025 06:00	0.00000	0.24696
06/03/2025 07:00	0.00000	0.23550
06/03/2025 08:00	0.00000	0.25410
06/03/2025 09:00	0.00000	0.26976
06/03/2025 10:00	0.06828	0.28218
06/03/2025 11:00	0.22458	0.24372
06/03/2025 12:00	0.22182	0.23346
06/03/2025 13:00	0.26874	0.28398
06/03/2025 14:00	0.26142	0.27654
06/03/2025 15:00	0.24594	0.27330
06/03/2025 16:00	0.08034	0.23922
06/03/2025 17:00	0.00000	0.23850
06/03/2025 18:00	0.00000	0.23058
06/03/2025 19:00	0.00000	0.23022
06/03/2025 20:00	0.00000	0.23178
06/03/2025 21:00	0.00000	0.23262
06/03/2025 22:00	0.00000	0.23274
06/03/2025 23:00	0.00000	0.23208
Average/Sum#:	0.19587	0.24448
Minimum:	0.06828	0.23022
Maximum:	0.26874	0.28398
%SI	70.83	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
06/04/2025 00:00	0.00000	0.23250
06/04/2025 01:00	0.00000	0.23376
06/04/2025 02:00	0.00000	0.23358
06/04/2025 03:00	0.00000	0.24276
06/04/2025 04:00	0.00000	0.23424
06/04/2025 05:00	0.00000	0.23328
06/04/2025 06:00	0.00000	0.23286
06/04/2025 07:00	0.00000	0.23202
06/04/2025 08:00	0.00000	0.23130
06/04/2025 09:00	0.00000	0.23154
06/04/2025 10:00	0.00000	0.23214
06/04/2025 11:00	0.00000	0.23232
06/04/2025 12:00	0.00000	0.23118
06/04/2025 13:00	0.00000	0.23058
06/04/2025 14:00	0.00000	0.23028
06/04/2025 15:00	0.00000	0.22836
06/04/2025 16:00	0.00000	0.22854
06/04/2025 17:00	0.00000	0.23562
06/04/2025 18:00	0.00000	0.22998
06/04/2025 19:00	0.00000	0.23004
06/04/2025 20:00	0.00000	0.23016
06/04/2025 21:00	0.00000	0.23172
06/04/2025 22:00	0.00000	0.23250
06/04/2025 23:00	0.00000	0.24042
Average/Sum#:	0.00000	0.23257
Minimum:	0.00000	0.22836
Maximum:	0.00000	0.24276
%SI	100.00	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
06/05/2025 00:00	0.00000	0.23130
06/05/2025 01:00	0.00000	0.23232
06/05/2025 02:00	0.00000	0.23274
06/05/2025 03:00	0.00000	0.23280
06/05/2025 04:00	0.00000	0.23262
06/05/2025 05:00	0.00000	0.23298
06/05/2025 06:00	0.00000	0.23256
06/05/2025 07:00	0.00000	0.23274
06/05/2025 08:00	0.00000	0.23304
06/05/2025 09:00	0.00000	0.23346
06/05/2025 10:00	0.00000	0.23400
06/05/2025 11:00	0.00000	0.23406
06/05/2025 12:00	0.00000	0.23196
06/05/2025 13:00	0.00000	0.23130
06/05/2025 14:00	0.00000	0.23172
06/05/2025 15:00	0.00000	0.23232
06/05/2025 16:00	0.00000	0.23208
06/05/2025 17:00	0.00000	0.24648
06/05/2025 18:00	0.00000	0.23304
06/05/2025 19:00	0.00000	0.23202
06/05/2025 20:00	0.00000	0.23220
06/05/2025 21:00	0.00000	0.23214
06/05/2025 22:00	0.00000	0.23442
06/05/2025 23:00	0.00000	0.25482
Average/Sum#:	0.00000	0.23413
Minimum:	0.00000	0.23130
Maximum:	0.00000	0.25482
%SI	100.00	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
06/06/2025 00:00	0.00000	0.23418
06/06/2025 01:00	0.00000	0.23424
06/06/2025 02:00	0.00000	0.23466
06/06/2025 03:00	0.00000	0.23454
06/06/2025 04:00	0.00000	0.23406
06/06/2025 05:00	0.00000	0.23412
06/06/2025 06:00	0.00000	0.23370
06/06/2025 07:00	0.00000	0.23412
06/06/2025 08:00	0.00000	0.23412
06/06/2025 09:00	0.00000	0.23460
06/06/2025 10:00	0.00000	0.23298
06/06/2025 11:00	0.00000	0.23178
06/06/2025 12:00	0.00000	0.23214
06/06/2025 13:00	0.00000	0.25290
06/06/2025 14:00	0.00000	0.23094
06/06/2025 15:00	0.00000	0.22980
06/06/2025 16:00	0.00000	0.22968
06/06/2025 17:00	0.00000	0.23286
06/06/2025 18:00	0.00000	0.23088
06/06/2025 19:00	0.00000	0.23226
06/06/2025 20:00	0.00000	0.23256
06/06/2025 21:00	0.00000	0.23244
06/06/2025 22:00	0.00000	0.23226
06/06/2025 23:00	0.00000	0.23196
Average/Sum#:	0.00000	0.23366
Minimum:	0.00000	0.22968
Maximum:	0.00000	0.25290
%SI	100.00	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
06/07/2025 00:00	0.00000	0.23244
06/07/2025 01:00	0.00000	0.23406
06/07/2025 02:00	0.00000	0.23406
06/07/2025 03:00	0.00000	0.23376
06/07/2025 04:00	0.00000	0.23364
06/07/2025 05:00	0.00000	0.23370
06/07/2025 06:00	0.00000	0.23370
06/07/2025 07:00	0.00000	0.23376
06/07/2025 08:00	0.00000	0.23370
06/07/2025 09:00	0.00000	0.23196
06/07/2025 10:00	0.00000	0.23196
06/07/2025 11:00	0.00000	0.23238
06/07/2025 12:00	0.00000	0.23208
06/07/2025 13:00	0.00000	0.23232
06/07/2025 14:00	0.00000	0.22986
06/07/2025 15:00	0.00000	0.22992
06/07/2025 16:00	0.00000	0.24108
06/07/2025 17:00	0.00000	0.24594
06/07/2025 18:00	0.00000	0.27126
06/07/2025 19:00	0.00000	0.23376
06/07/2025 20:00	0.00000	0.23106
06/07/2025 21:00	0.00000	0.23148
06/07/2025 22:00	0.00000	0.23142
06/07/2025 23:00	0.00000	0.23172
Average/Sum#:	0.00000	0.23504
Minimum:	0.00000	0.22986
Maximum:	0.00000	0.27126
%SI	100.00	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
06/08/2025 00:00	0.00000	0.23298
06/08/2025 01:00	0.00000	0.23304
06/08/2025 02:00	0.00000	0.23256
06/08/2025 03:00	0.00000	0.23250
06/08/2025 04:00	0.00000	0.23256
06/08/2025 05:00	0.00000	0.23292
06/08/2025 06:00	0.00000	0.23328
06/08/2025 07:00	0.00000	0.23316
06/08/2025 08:00	0.00000	0.23352
06/08/2025 09:00	0.00000	0.23400
06/08/2025 10:00	0.00000	0.23436
06/08/2025 11:00	0.00000	0.23262
06/08/2025 12:00	0.00000	0.23250
06/08/2025 13:00	0.00000	0.23292
06/08/2025 14:00	0.00000	0.25734
06/08/2025 15:00	0.00000	0.23586
06/08/2025 16:00	0.00000	0.25920
06/08/2025 17:00	0.00000	0.25716
06/08/2025 18:00	0.00000	0.29070
06/08/2025 19:00	0.00000	0.29034
06/08/2025 20:00	0.00000	0.23838
06/08/2025 21:00	0.00000	0.24726
06/08/2025 22:00	0.00000	0.23268
06/08/2025 23:00	0.00000	0.23700
Average/Sum#:	0.00000	0.24204
Minimum:	0.00000	0.23250
Maximum:	0.00000	0.29070
%SI	100.00	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
06/09/2025 00:00	0.00000	0.23472
06/09/2025 01:00	0.00000	0.23472
06/09/2025 02:00	0.00000	0.23490
06/09/2025 03:00	0.00000	0.23490
06/09/2025 04:00	0.00000	0.23514
06/09/2025 05:00	0.00000	0.23466
06/09/2025 06:00	0.00000	0.23454
06/09/2025 07:00	0.00000	0.23478
06/09/2025 08:00	0.00000	0.23424
06/09/2025 09:00	0.00000	0.23418
06/09/2025 10:00	0.00000	0.23298
06/09/2025 11:00	0.00000	0.23274
06/09/2025 12:00	0.00000	0.23280
06/09/2025 13:00	0.00000	0.23148
06/09/2025 14:00	0.00000	0.23124
06/09/2025 15:00	0.00000	0.23100
06/09/2025 16:00	0.00000	0.24534
06/09/2025 17:00	0.18588	0.25914
06/09/2025 18:00	0.26796	0.29562
06/09/2025 19:00	0.36342	0.37092
06/09/2025 20:00	0.29574	0.32070
06/09/2025 21:00	0.22770	0.24066
06/09/2025 22:00	0.21942	0.23154
06/09/2025 23:00	0.22866	0.24162
Average/Sum#:	0.25554	0.24769
Minimum:	0.18588	0.23100
Maximum:	0.36342	0.37092
%SI	70.83	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
06/10/2025 00:00	0.21930	0.23100
06/10/2025 01:00	0.21942	0.23124
06/10/2025 02:00	0.21942	0.23142
06/10/2025 03:00	0.21948	0.23190
06/10/2025 04:00	0.22752	0.24018
06/10/2025 05:00	0.22920	0.24180
06/10/2025 06:00	0.21978	0.23172
06/10/2025 07:00	0.22038	0.23202
06/10/2025 08:00	0.22008	0.23208
06/10/2025 09:00	0.21954	0.23202
06/10/2025 10:00	0.21888	0.23118
06/10/2025 11:00	0.21948	0.23142
06/10/2025 12:00	0.21996	0.23172
06/10/2025 13:00	0.22014	0.23178
06/10/2025 14:00	0.21966	0.23142
06/10/2025 15:00	0.23562	0.25242
06/10/2025 16:00	0.24228	0.25968
06/10/2025 17:00	0.24258	0.25728
06/10/2025 18:00	0.26736	0.28422
06/10/2025 19:00	0.22470	0.23760
06/10/2025 20:00	0.21822	0.23034
06/10/2025 21:00	0.21798	0.23052
06/10/2025 22:00	0.21822	0.23070
06/10/2025 23:00	0.21894	0.23094
Average/Sum#:	0.22492	0.23778
Minimum:	0.21798	0.23034
Maximum:	0.26736	0.28422
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
06/11/2025 00:00	0.22002	0.23220
06/11/2025 01:00	0.22026	0.23244
06/11/2025 02:00	0.22032	0.23262
06/11/2025 03:00	0.22068	0.23262
06/11/2025 04:00	0.22008	0.23202
06/11/2025 05:00	0.21936	0.23082
06/11/2025 06:00	0.21924	0.23130
06/11/2025 07:00	0.21960	0.23112
06/11/2025 08:00	0.21984	0.23190
06/11/2025 09:00	0.21972	0.23190
06/11/2025 10:00	0.21942	0.23232
06/11/2025 11:00	0.21930	0.23130
06/11/2025 12:00	0.21936	0.23100
06/11/2025 13:00	0.21906	0.23052
06/11/2025 14:00	0.21768	0.22896
06/11/2025 15:00	0.21732	0.22878
06/11/2025 16:00	0.21726	0.22860
06/11/2025 17:00	0.21732	0.22872
06/11/2025 18:00	0.21714	0.22920
06/11/2025 19:00	0.23106	0.17838
06/11/2025 20:00	0.22266	0.00000
06/11/2025 21:00	0.22248	0.00000
06/11/2025 22:00	0.22356	0.00000
06/11/2025 23:00	0.22374	0.00000
Average/Sum#:	0.22027	0.22834
Minimum:	0.21714	0.17838
Maximum:	0.23106	0.23262
%SI	0.00	16.67

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
06/12/2025 00:00	0.22326	0.00000
06/12/2025 01:00	0.22254	0.00000
06/12/2025 02:00	0.22344	0.00000
06/12/2025 03:00	0.22368	0.00000
06/12/2025 04:00	0.22344	0.00000
06/12/2025 05:00	0.22356	0.00000
06/12/2025 06:00	0.22338	0.00000
06/12/2025 07:00	0.22350	0.00000
06/12/2025 08:00	0.22416	0.00000
06/12/2025 09:00	0.22452	0.00000
06/12/2025 10:00	0.22386	0.00000
06/12/2025 11:00	0.22314	0.00000
06/12/2025 12:00	0.22344	0.00000
06/12/2025 13:00	0.22344	0.00000
06/12/2025 14:00	0.22254	0.00000
06/12/2025 15:00	0.22218	0.00000
06/12/2025 16:00	0.22296	0.00000
06/12/2025 17:00	0.22512	0.00000
06/12/2025 18:00	0.22026	0.00000
06/12/2025 19:00	0.21930	0.00000
06/12/2025 20:00	0.22014	0.00000
06/12/2025 21:00	0.22056	0.00000
06/12/2025 22:00	0.22212	0.00000
06/12/2025 23:00	0.25728	0.00000
Average/Sum#:	0.22424	0.00000
Minimum:	0.21930	0.00000
Maximum:	0.25728	0.00000
%SI	0.00	100.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
06/13/2025 00:00	0.23022	0.00000
06/13/2025 01:00	0.22242	0.00000
06/13/2025 02:00	0.22230	0.00000
06/13/2025 03:00	0.22242	0.00000
06/13/2025 04:00	0.22236	0.00000
06/13/2025 05:00	0.22242	0.00000
06/13/2025 06:00	0.22314	0.00000
06/13/2025 07:00	0.22434	0.00000
06/13/2025 08:00	0.22518	0.00000
06/13/2025 09:00	0.22440	0.00000
06/13/2025 10:00	0.22350	0.00000
06/13/2025 11:00	0.22476	0.00000
06/13/2025 12:00	0.22422	0.00000
06/13/2025 13:00	0.22332	0.00000
06/13/2025 14:00	0.22338	0.00000
06/13/2025 15:00	0.22326	0.00000
06/13/2025 16:00	0.22332	0.00000
06/13/2025 17:00	0.22314	0.00000
06/13/2025 18:00	0.22302	0.00000
06/13/2025 19:00	0.22248	0.00000
06/13/2025 20:00	0.22224	0.00000
06/13/2025 21:00	0.22230	0.00000
06/13/2025 22:00	0.22410	0.00000
06/13/2025 23:00	0.22416	0.00000
Average/Sum#:	0.22360	0.00000
Minimum:	0.22224	0.00000
Maximum:	0.23022	0.00000
%SI	0.00	100.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
06/14/2025 00:00	0.22422	0.00000
06/14/2025 01:00	0.22434	0.00000
06/14/2025 02:00	0.22398	0.00000
06/14/2025 03:00	0.22398	0.00000
06/14/2025 04:00	0.22410	0.00000
06/14/2025 05:00	0.22392	0.00000
06/14/2025 06:00	0.22356	0.00000
06/14/2025 07:00	0.22350	0.00000
06/14/2025 08:00	0.22344	0.00000
06/14/2025 09:00	0.22398	0.00000
06/14/2025 10:00	0.22368	0.00000
06/14/2025 11:00	0.22284	0.00000
06/14/2025 12:00	0.22290	0.00000
06/14/2025 13:00	0.22308	0.00000
06/14/2025 14:00	0.23694	0.00000
06/14/2025 15:00	0.22104	0.00000
06/14/2025 16:00	0.22152	0.00000
06/14/2025 17:00	0.23676	0.00000
06/14/2025 18:00	0.31572	0.00000
06/14/2025 19:00	0.31914	0.00000
06/14/2025 20:00	0.31854	0.00000
06/14/2025 21:00	0.28866	0.00000
06/14/2025 22:00	0.31122	0.00000
06/14/2025 23:00	0.31650	0.00000
Average/Sum#:	0.24657	0.00000
Minimum:	0.22104	0.00000
Maximum:	0.31914	0.00000
%SI	0.00	100.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
06/15/2025 00:00	0.31536	0.00000
06/15/2025 01:00	0.31644	0.00000
06/15/2025 02:00	0.31794	0.00000
06/15/2025 03:00	0.31824	0.00000
06/15/2025 04:00	0.31830	0.00000
06/15/2025 05:00	0.25116	0.00000
06/15/2025 06:00	0.22398	0.00000
06/15/2025 07:00	0.22440	0.00000
06/15/2025 08:00	0.22476	0.00000
06/15/2025 09:00	0.22566	0.00000
06/15/2025 10:00	0.22500	0.00000
06/15/2025 11:00	0.22428	0.00000
06/15/2025 12:00	0.22476	0.00000
06/15/2025 13:00	0.22536	0.00000
06/15/2025 14:00	0.22524	0.00000
06/15/2025 15:00	0.22536	0.00000
06/15/2025 16:00	0.25320	0.00000
06/15/2025 17:00	0.33990	0.00000
06/15/2025 18:00	0.35514	0.00000
06/15/2025 19:00	0.33126	0.00000
06/15/2025 20:00	0.33078	0.00000
06/15/2025 21:00	0.32550	0.00000
06/15/2025 22:00	0.31926	0.00000
06/15/2025 23:00	0.32028	0.00000
Average/Sum#:	0.27757	0.00000
Minimum:	0.22398	0.00000
Maximum:	0.35514	0.00000
%SI	0.00	100.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
06/16/2025 00:00	0.31896	0.00000
06/16/2025 01:00	0.32202	0.00000
06/16/2025 02:00	0.32232	0.00000
06/16/2025 03:00	0.32154	0.00000
06/16/2025 04:00	0.32064	0.00000
06/16/2025 05:00	0.27366	0.00000
06/16/2025 06:00	0.22476	0.00000
06/16/2025 07:00	0.22500	0.00000
06/16/2025 08:00	0.22506	0.00000
06/16/2025 09:00	0.22536	0.00000
06/16/2025 10:00	0.22560	0.00000
06/16/2025 11:00	0.22488	0.00000
06/16/2025 12:00	0.22524	0.00000
06/16/2025 13:00	0.22524	0.00000
06/16/2025 14:00	0.22452	0.00000
06/16/2025 15:00	0.25272	0.00000
06/16/2025 16:00	0.32388	0.00000
06/16/2025 17:00	0.32472	0.00000
06/16/2025 18:00	0.33012	0.00000
06/16/2025 19:00	0.33234	0.00000
06/16/2025 20:00	0.33324	0.00000
06/16/2025 21:00	0.32124	0.00000
06/16/2025 22:00	0.32010	0.00000
06/16/2025 23:00	0.33438	0.00000
Average/Sum#:	0.28240	0.00000
Minimum:	0.22452	0.00000
Maximum:	0.33438	0.00000
%SI	0.00	100.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
06/17/2025 00:00	0.31908	0.00000
06/17/2025 01:00	0.31818	0.00000
06/17/2025 02:00	0.32040	0.00000
06/17/2025 03:00	0.32082	0.00000
06/17/2025 04:00	0.32172	0.00000
06/17/2025 05:00	0.30522	0.00000
06/17/2025 06:00	0.22854	0.00000
06/17/2025 07:00	0.22506	0.00000
06/17/2025 08:00	0.22434	0.00000
06/17/2025 09:00	0.22416	0.00000
06/17/2025 10:00	0.22452	0.00000
06/17/2025 11:00	0.22524	0.00000
06/17/2025 12:00	0.22560	0.00000
06/17/2025 13:00	0.22458	0.00000
06/17/2025 14:00	0.24234	0.00000
06/17/2025 15:00	0.22458	0.00000
06/17/2025 16:00	0.25038	0.00000
06/17/2025 17:00	0.34626	0.00000
06/17/2025 18:00	0.37284	0.00000
06/17/2025 19:00	0.37230	0.00000
06/17/2025 20:00	0.34722	0.00000
06/17/2025 21:00	0.32286	0.00000
06/17/2025 22:00	0.32040	0.00000
06/17/2025 23:00	0.32238	0.00000
Average/Sum#:	0.28454	0.00000
Minimum:	0.22416	0.00000
Maximum:	0.37284	0.00000
%SI	0.00	100.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
06/18/2025 00:00	0.32232	0.00000
06/18/2025 01:00	0.32130	0.00000
06/18/2025 02:00	0.32106	0.00000
06/18/2025 03:00	0.32064	0.00000
06/18/2025 04:00	0.32022	0.00000
06/18/2025 05:00	0.32016	0.00000
06/18/2025 06:00	0.27450	0.00000
06/18/2025 07:00	0.22620	0.00000
06/18/2025 08:00	0.22548	0.00000
06/18/2025 09:00	0.22578	0.00000
06/18/2025 10:00	0.22536	0.00000
06/18/2025 11:00	0.22482	0.00000
06/18/2025 12:00	0.22470	0.00000
06/18/2025 13:00	0.22392	0.00000
06/18/2025 14:00	0.22398	0.00000
06/18/2025 15:00	0.22386	0.00000
06/18/2025 16:00	0.25074	0.00000
06/18/2025 17:00	0.33204	0.00000
06/18/2025 18:00	0.37188	0.00000
06/18/2025 19:00	0.36150	0.00000
06/18/2025 20:00	0.33474	0.00000
06/18/2025 21:00	0.32478	0.00000
06/18/2025 22:00	0.32478	0.00000
06/18/2025 23:00	0.32724	0.00000
<hr/>		
Average/Sum#:	0.28550	0.00000
Minimum:	0.22386	0.00000
Maximum:	0.37188	0.00000
%SI	0.00	100.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
06/19/2025 00:00	0.32538	0.00000
06/19/2025 01:00	0.32268	0.00000
06/19/2025 02:00	0.32154	0.00000
06/19/2025 03:00	0.32130	0.00000
06/19/2025 04:00	0.32094	0.00000
06/19/2025 05:00	0.29970	0.00000
06/19/2025 06:00	0.22470	0.00000
06/19/2025 07:00	0.22674	0.00000
06/19/2025 08:00	0.22662	0.00000
06/19/2025 09:00	0.22524	0.00000
06/19/2025 10:00	0.22470	0.00000
06/19/2025 11:00	0.22434	0.00000
06/19/2025 12:00	0.22488	0.00000
06/19/2025 13:00	0.22434	0.00000
06/19/2025 14:00	0.22410	0.00000
06/19/2025 15:00	0.22374	0.00000
06/19/2025 16:00	0.22386	0.00000
06/19/2025 17:00	0.22272	0.00000
06/19/2025 18:00	0.22230	0.00000
06/19/2025 19:00	0.22242	0.00000
06/19/2025 20:00	0.22344	0.00000
06/19/2025 21:00	0.22332	0.00000
06/19/2025 22:00	0.22320	0.00000
06/19/2025 23:00	0.22398	0.00000
Average/Sum#:	0.24776	0.00000
Minimum:	0.22230	0.00000
Maximum:	0.32538	0.00000
%SI	0.00	100.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
06/20/2025 00:00	0.22386	0.00000
06/20/2025 01:00	0.22368	0.00000
06/20/2025 02:00	0.22368	0.00000
06/20/2025 03:00	0.22362	0.00000
06/20/2025 04:00	0.22422	0.00000
06/20/2025 05:00	0.22734	0.00000
06/20/2025 06:00	0.22350	0.00000
06/20/2025 07:00	0.22410	0.00000
06/20/2025 08:00	0.22362	0.00000
06/20/2025 09:00	0.22428	0.00000
06/20/2025 10:00	0.22386	0.00000
06/20/2025 11:00	0.22506	0.00000
06/20/2025 12:00	0.22590	0.00000
06/20/2025 13:00	0.22590	0.00000
06/20/2025 14:00	0.22560	0.00000
06/20/2025 15:00	0.22452	0.00000
06/20/2025 16:00	0.22326	0.00000
06/20/2025 17:00	0.22314	0.00000
06/20/2025 18:00	0.22218	0.00000
06/20/2025 19:00	0.22152	0.00000
06/20/2025 20:00	0.22194	0.00000
06/20/2025 21:00	0.22260	0.00000
06/20/2025 22:00	0.22374	0.00000
06/20/2025 23:00	0.22374	0.00000
Average/Sum#:	0.22395	0.00000
Minimum:	0.22152	0.00000
Maximum:	0.22734	0.00000
%SI	0.00	100.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
06/21/2025 00:00	0.22446	0.00000
06/21/2025 01:00	0.22476	0.00000
06/21/2025 02:00	0.22536	0.00000
06/21/2025 03:00	0.22518	0.00000
06/21/2025 04:00	0.22470	0.00000
06/21/2025 05:00	0.22524	0.00000
06/21/2025 06:00	0.22512	0.00000
06/21/2025 07:00	0.22404	0.00000
06/21/2025 08:00	0.22488	0.00000
06/21/2025 09:00	0.22632	0.00000
06/21/2025 10:00	0.22560	0.00000
06/21/2025 11:00	0.22434	0.00000
06/21/2025 12:00	0.22524	0.00000
06/21/2025 13:00	0.22548	0.00000
06/21/2025 14:00	0.22530	0.00000
06/21/2025 15:00	0.22326	0.00000
06/21/2025 16:00	0.22254	0.00000
06/21/2025 17:00	0.22260	0.00000
06/21/2025 18:00	0.22350	0.00000
06/21/2025 19:00	0.22512	0.00000
06/21/2025 20:00	0.22536	0.00000
06/21/2025 21:00	0.22554	0.00000
06/21/2025 22:00	0.22560	0.00000
06/21/2025 23:00	0.22500	0.00000
Average/Sum#:	0.22477	0.00000
Minimum:	0.22254	0.00000
Maximum:	0.22632	0.00000
%SI	0.00	100.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
06/22/2025 00:00	0.22500	0.00000
06/22/2025 01:00	0.22548	0.00000
06/22/2025 02:00	0.22470	0.00000
06/22/2025 03:00	0.22530	0.00000
06/22/2025 04:00	0.22524	0.00000
06/22/2025 05:00	0.23262	0.00000
06/22/2025 06:00	0.22470	0.00000
06/22/2025 07:00	0.22380	0.00000
06/22/2025 08:00	0.22452	0.00000
06/22/2025 09:00	0.22422	0.00000
06/22/2025 10:00	0.22452	0.00000
06/22/2025 11:00	0.22314	0.00000
06/22/2025 12:00	0.22338	0.00000
06/22/2025 13:00	0.22362	0.00000
06/22/2025 14:00	0.22320	0.00000
06/22/2025 15:00	0.22266	0.00000
06/22/2025 16:00	0.22224	0.00000
06/22/2025 17:00	0.22842	0.00000
06/22/2025 18:00	0.22194	0.00000
06/22/2025 19:00	0.22188	0.00000
06/22/2025 20:00	0.22350	0.00000
06/22/2025 21:00	0.22194	0.00000
06/22/2025 22:00	0.22218	0.00000
06/22/2025 23:00	0.22530	0.00000
Average/Sum#:	0.22431	0.00000
Minimum:	0.22188	0.00000
Maximum:	0.23262	0.00000
%SI	0.00	100.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
06/23/2025 00:00	0.22176	0.00000
06/23/2025 01:00	0.22170	0.00000
06/23/2025 02:00	0.22296	0.00000
06/23/2025 03:00	0.22302	0.00000
06/23/2025 04:00	0.22338	0.00000
06/23/2025 05:00	0.24414	0.00000
06/23/2025 06:00	0.22188	0.00000
06/23/2025 07:00	0.22206	0.00000
06/23/2025 08:00	0.22236	0.00000
06/23/2025 09:00	0.22116	0.00000
06/23/2025 10:00	0.22116	0.00000
06/23/2025 11:00	0.22194	0.00000
06/23/2025 12:00	0.22176	0.00000
06/23/2025 13:00	0.22170	0.00000
06/23/2025 14:00	0.22146	0.00000
06/23/2025 15:00	0.22158	0.00000
06/23/2025 16:00	0.22206	0.00000
06/23/2025 17:00	0.23202	0.00000
06/23/2025 18:00	0.25008	0.00000
06/23/2025 19:00	0.25956	0.00000
06/23/2025 20:00	0.24048	0.00000
06/23/2025 21:00	0.24954	0.00000
06/23/2025 22:00	0.26040	0.00000
06/23/2025 23:00	0.26706	0.00000
Average/Sum#:	0.23147	0.00000
Minimum:	0.22116	0.00000
Maximum:	0.26706	0.00000
%SI	0.00	100.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
06/24/2025 00:00	0.24120	0.00000
06/24/2025 01:00	0.22656	0.00000
06/24/2025 02:00	0.26790	0.00000
06/24/2025 03:00	0.26730	0.00000
06/24/2025 04:00	0.26718	0.00000
06/24/2025 05:00	0.24438	0.00000
06/24/2025 06:00	0.22224	0.00000
06/24/2025 07:00	0.22206	0.00000
06/24/2025 08:00	0.22062	0.00000
06/24/2025 09:00	0.21852	0.00000
06/24/2025 10:00	0.21684	0.00000
06/24/2025 11:00	0.21750	0.00000
06/24/2025 12:00	0.21840	0.00000
06/24/2025 13:00	0.21858	0.00000
06/24/2025 14:00	0.21858	0.00000
06/24/2025 15:00	0.21888	0.00000
06/24/2025 16:00	0.21966	0.00000
06/24/2025 17:00	0.24480	0.00000
06/24/2025 18:00	0.23586	0.00000
06/24/2025 19:00	0.21786	0.00000
06/24/2025 20:00	0.21744	0.00000
06/24/2025 21:00	0.21858	0.00000
06/24/2025 22:00	0.21954	0.00000
06/24/2025 23:00	0.23820	0.00000
Average/Sum#:	0.22995	0.00000
Minimum:	0.21684	0.00000
Maximum:	0.26790	0.00000
%SI	0.00	100.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
06/25/2025 00:00	0.21912	0.00000
06/25/2025 01:00	0.21900	0.00000
06/25/2025 02:00	0.21954	0.00000
06/25/2025 03:00	0.21930	0.00000
06/25/2025 04:00	0.21996	0.00000
06/25/2025 05:00	0.22224	0.00000
06/25/2025 06:00	0.21930	0.00000
06/25/2025 07:00	0.21924	0.00000
06/25/2025 08:00	0.21942	0.00000
06/25/2025 09:00	0.21894	0.00000
06/25/2025 10:00	0.21918	0.00000
06/25/2025 11:00	0.21990	0.00000
06/25/2025 12:00	0.21858	0.00000
06/25/2025 13:00	0.21810	0.00000
06/25/2025 14:00	0.21768	0.00000
06/25/2025 15:00	0.21666	0.00000
06/25/2025 16:00	0.21660	0.00000
06/25/2025 17:00	0.22674	0.00000
06/25/2025 18:00	0.25236	0.00000
06/25/2025 19:00	0.24000	0.00000
06/25/2025 20:00	0.22872	0.00000
06/25/2025 21:00	0.21780	0.00000
06/25/2025 22:00	0.21774	0.00000
06/25/2025 23:00	0.21792	0.00000
Average/Sum#:	0.22184	0.00000
Minimum:	0.21660	0.00000
Maximum:	0.25236	0.00000
%SI	0.00	100.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
06/26/2025 00:00	0.21804	0.00000
06/26/2025 01:00	0.21930	0.00000
06/26/2025 02:00	0.21978	0.00000
06/26/2025 03:00	0.22056	0.00000
06/26/2025 04:00	0.22080	0.00000
06/26/2025 05:00	0.22074	0.00000
06/26/2025 06:00	0.22020	0.00000
06/26/2025 07:00	0.22074	0.00000
06/26/2025 08:00	0.22050	0.00000
06/26/2025 09:00	0.21876	0.00000
06/26/2025 10:00	0.21858	0.00000
06/26/2025 11:00	0.21918	0.00000
06/26/2025 12:00	0.21960	0.00000
06/26/2025 13:00	0.21936	0.00000
06/26/2025 14:00	0.21828	0.00000
06/26/2025 15:00	0.21798	0.00000
06/26/2025 16:00	0.21774	0.00000
06/26/2025 17:00	0.22632	0.00000
06/26/2025 18:00	0.23802	0.00000
06/26/2025 19:00	0.26364	0.00000
06/26/2025 20:00	0.25062	0.00000
06/26/2025 21:00	0.22404	0.00000
06/26/2025 22:00	0.21852	0.00000
06/26/2025 23:00	0.21882	0.00000
Average/Sum#:	0.22376	0.00000
Minimum:	0.21774	0.00000
Maximum:	0.26364	0.00000
%SI	0.00	100.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
06/27/2025 00:00	0.21864	0.00000
06/27/2025 01:00	0.21876	0.00000
06/27/2025 02:00	0.21846	0.00000
06/27/2025 03:00	0.21876	0.00000
06/27/2025 04:00	0.22560	0.00000
06/27/2025 05:00	0.24372	0.00000
06/27/2025 06:00	0.22032	0.00000
06/27/2025 07:00	0.22116	0.00000
06/27/2025 08:00	0.22140	0.00000
06/27/2025 09:00	0.22218	0.00000
06/27/2025 10:00	0.22290	0.00000
06/27/2025 11:00	0.22368	0.00000
06/27/2025 12:00	0.24510	0.00000
06/27/2025 13:00	0.26466	0.00000
06/27/2025 14:00	0.25506	0.00000
06/27/2025 15:00	0.24948	0.00000
06/27/2025 16:00	0.24894	0.11892
06/27/2025 17:00	0.24426	0.26130
06/27/2025 18:00	0.26610	0.28584
06/27/2025 19:00	0.37722	0.40986
06/27/2025 20:00	0.31482	0.34020
06/27/2025 21:00	0.25632	0.28614
06/27/2025 22:00	0.08784	0.24174
06/27/2025 23:00	0.00000	0.23172
Average/Sum#:	0.23849	0.27197
Minimum:	0.08784	0.11892
Maximum:	0.37722	0.40986
%SI	4.17	66.67

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
06/28/2025 00:00	0.00000	0.23124
06/28/2025 01:00	0.00000	0.23166
06/28/2025 02:00	0.00000	0.23196
06/28/2025 03:00	0.00000	0.23166
06/28/2025 04:00	0.00000	0.23142
06/28/2025 05:00	0.00000	0.23142
06/28/2025 06:00	0.00000	0.23154
06/28/2025 07:00	0.00000	0.23178
06/28/2025 08:00	0.00000	0.23136
06/28/2025 09:00	0.00000	0.22980
06/28/2025 10:00	0.00000	0.23016
06/28/2025 11:00	0.00000	0.23010
06/28/2025 12:00	0.00000	0.23946
06/28/2025 13:00	0.00000	0.25152
06/28/2025 14:00	0.07110	0.27120
06/28/2025 15:00	0.24174	0.26436
06/28/2025 16:00	0.26064	0.27666
06/28/2025 17:00	0.26460	0.28320
06/28/2025 18:00	0.37872	0.40680
06/28/2025 19:00	0.38634	0.41160
06/28/2025 20:00	0.37554	0.41088
06/28/2025 21:00	0.38124	0.41292
06/28/2025 22:00	0.35328	0.41538
06/28/2025 23:00	0.29316	0.39018
Average/Sum#:	0.30064	0.28368
Minimum:	0.07110	0.22980
Maximum:	0.38634	0.41538
%SI	58.33	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
06/29/2025 00:00	0.24132	0.25590
06/29/2025 01:00	0.21072	0.23376
06/29/2025 02:00	0.09522	0.24474
06/29/2025 03:00	0.00000	0.23136
06/29/2025 04:00	0.00000	0.25956
06/29/2025 05:00	0.00000	0.24000
06/29/2025 06:00	0.00000	0.23232
06/29/2025 07:00	0.00000	0.23208
06/29/2025 08:00	0.00000	0.23202
06/29/2025 09:00	0.00000	0.23184
06/29/2025 10:00	0.00000	0.23160
06/29/2025 11:00	0.00000	0.23052
06/29/2025 12:00	0.00000	0.23676
06/29/2025 13:00	0.00000	0.26916
06/29/2025 14:00	0.00000	0.28068
06/29/2025 15:00	0.00000	0.28044
06/29/2025 16:00	0.12972	0.26766
06/29/2025 17:00	0.24354	0.25554
06/29/2025 18:00	0.25890	0.27324
06/29/2025 19:00	0.25740	0.27246
06/29/2025 20:00	0.25758	0.27288
06/29/2025 21:00	0.25494	0.27012
06/29/2025 22:00	0.20946	0.24132
06/29/2025 23:00	0.04362	0.23838
Average/Sum#:	0.20022	0.25060
Minimum:	0.04362	0.23052
Maximum:	0.25890	0.28068
%SI	54.17	0.00

AQ33 HOURLY SOX



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
06/30/2025 00:00	0.00000	0.22920
06/30/2025 01:00	0.00000	0.22896
06/30/2025 02:00	0.00000	0.22998
06/30/2025 03:00	0.00000	0.23052
06/30/2025 04:00	0.00000	0.23076
06/30/2025 05:00	0.00000	0.23184
06/30/2025 06:00	0.00000	0.23232
06/30/2025 07:00	0.00000	0.23262
06/30/2025 08:00	0.00000	0.23808
06/30/2025 09:00	0.00000	0.23142
06/30/2025 10:00	0.00000	0.23190
06/30/2025 11:00	0.00000	0.23076
06/30/2025 12:00	0.00000	0.24666
06/30/2025 13:00	0.00000	0.26550
06/30/2025 14:00	0.00000	0.24054
06/30/2025 15:00	0.00000	0.26646
06/30/2025 16:00	0.07086	0.27228
06/30/2025 17:00	0.24168	0.25770
06/30/2025 18:00	0.26070	0.27456
06/30/2025 19:00	0.25890	0.27372
06/30/2025 20:00	0.25836	0.27348
06/30/2025 21:00	0.24384	0.25824
06/30/2025 22:00	0.21672	0.22932
06/30/2025 23:00	0.25026	0.26466
Average/Sum#:	0.22517	0.24590
Minimum:	0.07086	0.22896
Maximum:	0.26070	0.27456
%SI	66.67	0.00