

DOCKETED	
Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	264964
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q2 2025 - Part 7s
Description:	N/A
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public Agency
Submission Date:	7/22/2025 8:58:42 AM
Docketed Date:	7/22/2025

Cylinder Gas Audit

07/06/2025

Page 1

Facility: ROSEVILLE ENERGY

Unit/Stack: CT2

Parameter/Scale: CO / High

Test Date: 05/05/2025

Test Result: **Pass**

Instrument Name: CT2_CODualRg_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
05/05/2025	08:35	L	200	49.900	49.600	25.0 %
05/05/2025	08:40	M	200	109.100	109.400	54.6 %
05/05/2025	08:52	L	200	49.900	49.900	25.0 %
05/05/2025	08:57	M	200	109.100	112.300	54.6 %
05/05/2025	09:09	L	200	49.900	49.800	25.0 %
05/05/2025	09:14	M	200	109.100	111.200	54.6 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	49.900	49.767	Std	0.3
M	109.100	110.967	Std	1.7

Cylinder Gas Audit

07/06/2025

Page 2

Facility: ROSEVILLE ENERGY

Unit/Stack: CT2

Parameter/Scale: CO / Low

Test Date: 05/05/2025

Test Result: **Pass**

Instrument Name: CT2_CODualRg_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
05/05/2025	12:37	L	10	2.600	2.300	26.0 %
05/05/2025	12:42	M	10	5.700	6.100	57.0 %
05/05/2025	12:49	L	10	2.600	2.100	26.0 %
05/05/2025	12:54	M	10	5.700	5.400	57.0 %
05/05/2025	13:01	L	10	2.600	2.300	26.0 %
05/05/2025	13:06	M	10	5.700	5.700	57.0 %

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Specification Used	Results
L	2.600		2.233	Std	14.1
M	5.700		5.733	Std	0.6

Linearity Report

07/06/2025

Page 1

ORIS Code: 56298 Facility Name: ROSEVILLE ENERGY
EDR Site ID: CT002 Component ID: A21 ReasonForTest: QA
Component Type: NOXA Grace Period: 0
Instrument Name: CT2_NOXDualRg_P_Instrum Test End Date/Time: 05/05/2025 Scale: High
Performance Spec: 5 % Test No.: 139 Highest Error: 1.2
Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
05/05/2025	0835	L	200.0	51.1	50.8		25.6 %
05/05/2025	0840	M	200.0	111.3	111.5		55.7 %
05/05/2025	0845	H	200.0	179.9	180.1		90.0 %
05/05/2025	0852	L	200.0	51.1	50.4		25.6 %
05/05/2025	0857	M	200.0	111.3	111.2		55.7 %
05/05/2025	0902	H	200.0	179.9	180.0		90.0 %
05/05/2025	0909	L	200.0	51.1	50.2		25.6 %
05/05/2025	0914	M	200.0	111.3	110.6		55.7 %
05/05/2025	0919	H	200.0	179.9	179.8		90.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	51.100	50.467	No	1.2
M	111.300	111.100	No	0.2
H	179.900	179.967	No	0.0

Linearity Report

07/06/2025

Page 2

ORIS Code: 56298 Facility Name: ROSEVILLE ENERGY
EDR Site ID: CT002 Component ID: A22 ReasonForTest: QA
Component Type: O2D Grace Period: 0
Instrument Name: CT2_O2D_P_Instrument Test End Date/Time: 05/05/2025 Scale: High
Performance Spec: 5 % Test No.: 140 Highest Error: 0.3
Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
05/05/2025	1035	L	21.0	5.0	5.0		23.8 %
05/05/2025	1040	M	21.0	11.0	11.0		52.4 %
05/05/2025	1045	H	21.0	18.0	18.0		85.7 %
05/05/2025	1052	L	21.0	5.0	5.0		23.8 %
05/05/2025	1057	M	21.0	11.0	11.0		52.4 %
05/05/2025	1102	H	21.0	18.0	17.9		85.7 %
05/05/2025	1109	L	21.0	5.0	5.0		23.8 %
05/05/2025	1114	M	21.0	11.0	11.1		52.4 %
05/05/2025	1119	H	21.0	18.0	18.0		85.7 %

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Alt Perf Spec	Results
L	5.000		5.000	No	0.0
M	11.000		11.033	No	0.3
H	18.000		17.967	No	0.2

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2	Unit CT2	Unit CT2
	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr					
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/01/2025 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2025 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2025 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2025 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2025 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2025 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2025 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2025 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2025 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2025 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2025 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2025 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2025 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2025 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2025 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2025 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2025 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2025 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2025 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2025 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2025 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2025 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2025 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/01/2025 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/02/2025 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/02/2025 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/02/2025 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/02/2025 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/02/2025 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/02/2025 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/02/2025 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/02/2025 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/02/2025 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/02/2025 09:00	1,043.4	175.9	1,043.4	105,200.0	109.8	0.0	0.0	0.0
04/02/2025 10:00	2,439.1	176.9	2,439.1	105,200.0	256.6	0.0	0.0	0.0
04/02/2025 11:00	4,575.7	178.8	4,575.7	105,200.0	481.4	0.6	0.3	1.0
04/02/2025 12:00	4,827.4	184.0	4,827.4	105,200.0	507.8	0.6	0.3	1.1
04/02/2025 13:00	4,787.7	195.0	4,787.7	105,200.0	503.7	0.6	0.3	1.0
04/02/2025 14:00	4,766.7	186.6	4,766.7	105,200.0	501.5	0.6	0.3	1.0
04/02/2025 15:00	3,369.0	187.3	3,369.0	105,200.0	354.4	0.5	0.3	0.8
04/02/2025 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/02/2025 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/02/2025 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/02/2025 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/02/2025 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/02/2025 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/02/2025 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/02/2025 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,687.0	183.5	3,687.0	105,200.0	387.9	0.6	0.3	1.0
Minimum:	1,043.4	175.9	1,043.4	105,200.0	109.8	0.5	0.3	0.8
Maximum:	4,827.4	195.0	4,827.4	105,200.0	507.8	0.6	0.3	1.1
%SI	70.83	70.83	70.83	0.00	70.83	79.17	79.17	79.17

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

Const. Value/Limit Tag:		> 4.73 > 1 > 1.8							
		Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	
		GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
		1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/03/2025 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/03/2025 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/03/2025 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/03/2025 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/03/2025 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/03/2025 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/03/2025 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/03/2025 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/03/2025 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/03/2025 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/03/2025 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/03/2025 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/03/2025 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/03/2025 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/03/2025 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/03/2025 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/03/2025 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/03/2025 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/03/2025 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/03/2025 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/03/2025 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/03/2025 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/03/2025 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/03/2025 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00	

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

Const. Value/Limit Tag:		> 4.73 > 1 > 1.8							
		Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	
		GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
		1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/04/2025 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/04/2025 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/04/2025 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/04/2025 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/04/2025 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/04/2025 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/04/2025 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/04/2025 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/04/2025 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/04/2025 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/04/2025 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/04/2025 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/04/2025 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/04/2025 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/04/2025 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/04/2025 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/04/2025 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/04/2025 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/04/2025 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/04/2025 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/04/2025 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/04/2025 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/04/2025 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/04/2025 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00	

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/05/2025 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/05/2025 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/05/2025 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/05/2025 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/05/2025 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/05/2025 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/05/2025 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/05/2025 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/05/2025 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/05/2025 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/05/2025 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/05/2025 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/05/2025 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/05/2025 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/05/2025 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/05/2025 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/05/2025 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/05/2025 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/05/2025 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/05/2025 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/05/2025 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/05/2025 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/05/2025 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/05/2025 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/06/2025 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2025 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2025 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2025 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2025 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2025 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2025 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2025 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2025 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2025 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2025 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2025 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2025 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2025 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2025 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2025 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2025 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2025 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2025 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2025 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2025 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2025 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2025 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/06/2025 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/07/2025 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/07/2025 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/07/2025 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/07/2025 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/07/2025 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/07/2025 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/07/2025 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/07/2025 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/07/2025 08:00	1,620.5	181.5	1,620.5	105,200.0	170.5	0.0	0.0	0.0
04/07/2025 09:00	3,756.1	184.3	3,756.1	105,200.0	395.1	0.5	0.2	0.8
04/07/2025 10:00	4,200.1	186.4	4,200.1	105,200.0	441.9	0.6	0.3	0.9
04/07/2025 11:00	3,709.8	187.4	3,709.8	105,200.0	390.3	0.5	0.2	0.8
04/07/2025 12:00	3,712.2	191.3	3,712.2	105,200.0	390.5	0.5	0.2	0.8
04/07/2025 13:00	3,714.9	193.9	3,714.9	105,200.0	390.8	0.5	0.2	0.8
04/07/2025 14:00	3,718.7	190.2	3,718.7	105,200.0	391.2	0.5	0.2	0.8
04/07/2025 15:00	3,733.9	191.3	3,733.9	105,200.0	392.8	0.5	0.2	0.8
04/07/2025 16:00	3,921.3	190.6	3,921.3	105,200.0	412.5	0.5	0.3	0.9
04/07/2025 17:00	4,095.6	189.8	4,095.6	105,200.0	430.9	0.5	0.3	0.9
04/07/2025 18:00	3,728.4	188.6	3,728.4	105,200.0	392.2	0.5	0.2	0.8
04/07/2025 19:00	3,716.9	187.3	3,716.9	105,200.0	391.0	0.5	0.2	0.8
04/07/2025 20:00	3,725.7	186.2	3,725.7	105,200.0	391.9	0.5	0.2	0.8
04/07/2025 21:00	3,727.5	185.3	3,727.5	105,200.0	392.1	0.5	0.2	0.8
04/07/2025 22:00	3,728.0	184.5	3,728.0	105,200.0	392.2	0.5	0.2	0.8
04/07/2025 23:00	3,724.8	183.3	3,724.8	105,200.0	391.8	0.5	0.2	0.8
Average/Sum#:	3,658.4	187.6	3,658.4	105,200.0	384.9	0.5	0.2	0.8
Minimum:	1,620.5	181.5	1,620.5	105,200.0	170.5	0.5	0.2	0.8
Maximum:	4,200.1	193.9	4,200.1	105,200.0	441.9	0.6	0.3	0.9
%SI	33.33	33.33	33.33	0.00	33.33	37.50	37.50	37.50

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/08/2025 00:00	3,731.0	182.4	3,731.0	105,200.0	392.5	0.5	0.2	0.8
04/08/2025 01:00	3,754.2	182.3	3,754.2	105,200.0	394.9	0.5	0.2	0.8
04/08/2025 02:00	3,765.4	182.1	3,765.4	105,200.0	396.1	0.5	0.2	0.8
04/08/2025 03:00	3,761.1	181.1	3,761.1	105,200.0	395.7	0.5	0.2	0.8
04/08/2025 04:00	3,827.7	181.1	3,827.7	105,200.0	402.7	0.5	0.3	0.8
04/08/2025 05:00	3,762.1	180.5	3,762.1	105,200.0	395.8	0.5	0.2	0.8
04/08/2025 06:00	3,749.0	181.1	3,749.0	105,200.0	394.4	0.5	0.2	0.8
04/08/2025 07:00	3,745.4	184.5	3,745.4	105,200.0	394.0	0.5	0.2	0.8
04/08/2025 08:00	3,743.9	189.2	3,743.9	105,200.0	393.9	0.5	0.2	0.8
04/08/2025 09:00	3,714.0	183.4	3,714.0	105,200.0	390.7	0.5	0.2	0.8
04/08/2025 10:00	3,708.1	184.7	3,708.1	105,200.0	390.1	0.5	0.2	0.8
04/08/2025 11:00	3,711.0	186.1	3,711.0	105,200.0	390.4	0.5	0.2	0.8
04/08/2025 12:00	3,709.1	194.1	3,709.1	105,200.0	390.2	0.5	0.2	0.8
04/08/2025 13:00	3,715.9	203.0	3,715.9	105,200.0	390.9	0.5	0.2	0.8
04/08/2025 14:00	3,714.7	187.6	3,714.7	105,200.0	390.8	0.5	0.2	0.8
04/08/2025 15:00	3,716.4	190.4	3,716.4	105,200.0	391.0	0.5	0.2	0.8
04/08/2025 16:00	3,709.7	189.5	3,709.7	105,200.0	390.3	0.5	0.2	0.8
04/08/2025 17:00	3,913.5	188.1	3,913.5	105,200.0	411.7	0.5	0.3	0.9
04/08/2025 18:00	3,703.4	187.6	3,703.4	105,200.0	389.6	0.5	0.2	0.8
04/08/2025 19:00	3,700.7	186.5	3,700.7	105,200.0	389.3	0.5	0.2	0.8
04/08/2025 20:00	3,700.8	186.5	3,700.8	105,200.0	389.3	0.5	0.2	0.8
04/08/2025 21:00	3,708.1	184.9	3,708.1	105,200.0	390.1	0.5	0.2	0.8
04/08/2025 22:00	3,710.3	184.0	3,710.3	105,200.0	390.3	0.5	0.2	0.8
04/08/2025 23:00	3,706.2	183.0	3,706.2	105,200.0	389.9	0.5	0.2	0.8
Average/Sum#:	3,736.7	186.0	3,736.7	105,200.0	393.1	0.5	0.2	0.8
Minimum:	3,700.7	180.5	3,700.7	105,200.0	389.3	0.5	0.2	0.8
Maximum:	3,913.5	203.0	3,913.5	105,200.0	411.7	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/09/2025 00:00	3,708.9	182.8	3,708.9	105,200.0	390.2	0.5	0.2	0.8
04/09/2025 01:00	3,707.5	180.8	3,707.5	105,200.0	390.0	0.5	0.2	0.8
04/09/2025 02:00	3,710.3	181.1	3,710.3	105,200.0	390.3	0.5	0.2	0.8
04/09/2025 03:00	3,717.6	180.7	3,717.6	105,200.0	391.1	0.5	0.2	0.8
04/09/2025 04:00	3,723.7	179.3	3,723.7	105,200.0	391.7	0.5	0.2	0.8
04/09/2025 05:00	3,745.4	179.3	3,745.4	105,200.0	394.0	0.5	0.2	0.8
04/09/2025 06:00	3,742.3	180.2	3,742.3	105,200.0	393.7	0.5	0.2	0.8
04/09/2025 07:00	3,747.6	191.5	3,747.6	105,200.0	394.2	0.5	0.2	0.8
04/09/2025 08:00	3,763.6	191.3	3,763.6	105,200.0	395.9	0.5	0.2	0.8
04/09/2025 09:00	3,743.1	183.8	3,743.1	105,200.0	393.8	0.5	0.2	0.8
04/09/2025 10:00	3,730.5	185.8	3,730.5	105,200.0	392.4	0.5	0.2	0.8
04/09/2025 11:00	3,731.2	187.2	3,731.2	105,200.0	392.5	0.5	0.2	0.8
04/09/2025 12:00	3,736.2	195.5	3,736.2	105,200.0	393.0	0.5	0.2	0.8
04/09/2025 13:00	3,744.2	202.9	3,744.2	105,200.0	393.9	0.5	0.2	0.8
04/09/2025 14:00	3,730.1	188.9	3,730.1	105,200.0	392.4	0.5	0.2	0.8
04/09/2025 15:00	3,700.3	193.7	3,700.3	105,200.0	389.3	0.5	0.2	0.8
04/09/2025 16:00	3,686.8	192.0	3,686.8	105,200.0	387.9	0.5	0.2	0.8
04/09/2025 17:00	4,041.1	193.0	4,041.1	105,200.0	425.1	0.5	0.3	0.9
04/09/2025 18:00	3,690.7	191.1	3,690.7	105,200.0	388.3	0.5	0.2	0.8
04/09/2025 19:00	3,684.6	189.7	3,684.6	105,200.0	387.6	0.5	0.2	0.8
04/09/2025 20:00	3,687.1	188.8	3,687.1	105,200.0	387.9	0.5	0.2	0.8
04/09/2025 21:00	3,939.8	188.2	3,939.8	105,200.0	414.5	0.5	0.3	0.9
04/09/2025 22:00	3,746.7	188.1	3,746.7	105,200.0	394.2	0.5	0.2	0.8
04/09/2025 23:00	3,701.2	187.2	3,701.2	105,200.0	389.4	0.5	0.2	0.8
Average/Sum#:	3,744.2	187.6	3,744.2	105,200.0	393.9	0.5	0.2	0.8
Minimum:	3,684.6	179.3	3,684.6	105,200.0	387.6	0.5	0.2	0.8
Maximum:	4,041.1	202.9	4,041.1	105,200.0	425.1	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/10/2025 00:00	3,725.5	186.2	3,725.5	105,200.0	391.9	0.5	0.2	0.8
04/10/2025 01:00	3,719.8	185.8	3,719.8	105,200.0	391.3	0.5	0.2	0.8
04/10/2025 02:00	3,726.4	185.2	3,726.4	105,200.0	392.0	0.5	0.2	0.8
04/10/2025 03:00	3,722.9	184.8	3,722.9	105,200.0	391.6	0.5	0.2	0.8
04/10/2025 04:00	3,820.7	184.0	3,820.7	105,200.0	401.9	0.5	0.3	0.8
04/10/2025 05:00	3,723.1	184.1	3,723.1	105,200.0	391.7	0.5	0.2	0.8
04/10/2025 06:00	3,708.2	186.0	3,708.2	105,200.0	390.1	0.5	0.2	0.8
04/10/2025 07:00	3,709.4	196.6	3,709.4	105,200.0	390.2	0.5	0.2	0.8
04/10/2025 08:00	3,703.8	193.8	3,703.8	105,200.0	389.6	0.5	0.2	0.8
04/10/2025 09:00	3,703.2	190.0	3,703.2	105,200.0	389.6	0.5	0.2	0.8
04/10/2025 10:00	3,697.2	192.0	3,697.2	105,200.0	388.9	0.5	0.2	0.8
04/10/2025 11:00	3,665.3	193.0	3,665.3	105,200.0	385.6	0.5	0.2	0.8
04/10/2025 12:00	3,661.8	194.5	3,661.8	105,200.0	385.2	0.5	0.2	0.8
04/10/2025 13:00	3,668.4	198.6	3,668.4	105,200.0	385.9	0.5	0.2	0.8
04/10/2025 14:00	4,125.6	195.3	4,125.6	105,200.0	434.0	0.5	0.3	0.9
04/10/2025 15:00	3,666.4	196.2	3,666.4	105,200.0	385.7	0.5	0.2	0.8
04/10/2025 16:00	4,005.9	195.0	4,005.9	105,200.0	421.4	0.5	0.3	0.9
04/10/2025 17:00	4,272.6	193.6	4,272.6	105,200.0	449.5	0.6	0.3	0.9
04/10/2025 18:00	4,534.3	190.9	4,534.3	105,200.0	477.0	0.6	0.3	1.0
04/10/2025 19:00	4,188.2	190.4	4,188.2	105,200.0	440.6	0.6	0.3	0.9
04/10/2025 20:00	3,694.8	189.4	3,694.8	105,200.0	388.7	0.5	0.2	0.8
04/10/2025 21:00	3,705.7	188.7	3,705.7	105,200.0	389.8	0.5	0.2	0.8
04/10/2025 22:00	3,711.1	187.9	3,711.1	105,200.0	390.4	0.5	0.2	0.8
04/10/2025 23:00	3,706.3	186.5	3,706.3	105,200.0	389.9	0.5	0.2	0.8
Average/Sum#:	3,815.3	190.4	3,815.3	105,200.0	401.4	0.5	0.2	0.8
Minimum:	3,661.8	184.0	3,661.8	105,200.0	385.2	0.5	0.2	0.8
Maximum:	4,534.3	198.6	4,534.3	105,200.0	477.0	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/11/2025 00:00	3,702.0	185.5	3,702.0	105,200.0	389.5	0.5	0.2	0.8
04/11/2025 01:00	3,698.0	185.1	3,698.0	105,200.0	389.0	0.5	0.2	0.8
04/11/2025 02:00	3,698.9	184.2	3,698.9	105,200.0	389.1	0.5	0.2	0.8
04/11/2025 03:00	3,692.8	184.0	3,692.8	105,200.0	388.5	0.5	0.2	0.8
04/11/2025 04:00	3,765.8	182.3	3,765.8	105,200.0	396.2	0.5	0.2	0.8
04/11/2025 05:00	4,047.3	182.0	4,047.3	105,200.0	425.8	0.5	0.3	0.9
04/11/2025 06:00	3,694.6	184.1	3,694.6	105,200.0	388.7	0.5	0.2	0.8
04/11/2025 07:00	3,698.6	191.9	3,698.6	105,200.0	389.1	0.5	0.2	0.8
04/11/2025 08:00	3,667.6	189.7	3,667.6	105,200.0	385.8	0.5	0.2	0.8
04/11/2025 09:00	3,654.0	183.4	3,654.0	105,200.0	384.4	0.5	0.2	0.8
04/11/2025 10:00	3,649.1	186.8	3,649.1	105,200.0	383.9	0.5	0.2	0.8
04/11/2025 11:00	3,651.8	190.5	3,651.8	105,200.0	384.2	0.5	0.2	0.8
04/11/2025 12:00	3,656.3	199.0	3,656.3	105,200.0	384.6	0.5	0.2	0.8
04/11/2025 13:00	3,662.4	203.2	3,662.4	105,200.0	385.3	0.5	0.2	0.8
04/11/2025 14:00	3,675.5	195.6	3,675.5	105,200.0	386.7	0.5	0.2	0.8
04/11/2025 15:00	3,624.1	195.3	3,624.1	105,200.0	381.3	0.5	0.2	0.8
04/11/2025 16:00	3,613.7	194.7	3,613.7	105,200.0	380.2	0.5	0.2	0.8
04/11/2025 17:00	3,996.2	194.6	3,996.2	105,200.0	420.4	0.5	0.3	0.9
04/11/2025 18:00	3,626.5	191.1	3,626.5	105,200.0	381.5	0.5	0.2	0.8
04/11/2025 19:00	3,616.7	189.5	3,616.7	105,200.0	380.5	0.5	0.2	0.8
04/11/2025 20:00	3,627.3	188.6	3,627.3	105,200.0	381.6	0.5	0.2	0.8
04/11/2025 21:00	3,937.6	187.1	3,937.6	105,200.0	414.2	0.5	0.3	0.9
04/11/2025 22:00	3,642.6	185.7	3,642.6	105,200.0	383.2	0.5	0.2	0.8
04/11/2025 23:00	3,777.1	184.5	3,777.1	105,200.0	397.4	0.5	0.3	0.8
Average/Sum#:	3,711.5	189.1	3,711.5	105,200.0	390.5	0.5	0.2	0.8
Minimum:	3,613.7	182.0	3,613.7	105,200.0	380.2	0.5	0.2	0.8
Maximum:	4,047.3	203.2	4,047.3	105,200.0	425.8	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/12/2025 00:00	3,630.4	183.6	3,630.4	105,200.0	381.9	0.5	0.2	0.8
04/12/2025 01:00	3,630.2	182.3	3,630.2	105,200.0	381.9	0.5	0.2	0.8
04/12/2025 02:00	3,630.2	180.6	3,630.2	105,200.0	381.9	0.5	0.2	0.8
04/12/2025 03:00	3,637.4	180.4	3,637.4	105,200.0	382.7	0.5	0.2	0.8
04/12/2025 04:00	3,663.6	179.4	3,663.6	105,200.0	385.4	0.5	0.2	0.8
04/12/2025 05:00	3,655.5	178.9	3,655.5	105,200.0	384.6	0.5	0.2	0.8
04/12/2025 06:00	3,657.5	179.3	3,657.5	105,200.0	384.8	0.5	0.2	0.8
04/12/2025 07:00	3,651.2	184.8	3,651.2	105,200.0	384.1	0.5	0.2	0.8
04/12/2025 08:00	3,655.7	188.1	3,655.7	105,200.0	384.6	0.5	0.2	0.8
04/12/2025 09:00	3,669.9	182.7	3,669.9	105,200.0	386.1	0.5	0.2	0.8
04/12/2025 10:00	3,675.9	183.2	3,675.9	105,200.0	386.7	0.5	0.2	0.8
04/12/2025 11:00	3,632.2	184.4	3,632.2	105,200.0	382.1	0.5	0.2	0.8
04/12/2025 12:00	3,623.3	193.7	3,623.3	105,200.0	381.2	0.5	0.2	0.8
04/12/2025 13:00	3,637.1	200.9	3,637.1	105,200.0	382.6	0.5	0.2	0.8
04/12/2025 14:00	3,641.6	190.8	3,641.6	105,200.0	383.1	0.5	0.2	0.8
04/12/2025 15:00	3,645.0	188.3	3,645.0	105,200.0	383.5	0.5	0.2	0.8
04/12/2025 16:00	3,630.8	187.9	3,630.8	105,200.0	382.0	0.5	0.2	0.8
04/12/2025 17:00	3,761.8	188.9	3,761.8	105,200.0	395.7	0.5	0.2	0.8
04/12/2025 18:00	3,639.8	185.9	3,639.8	105,200.0	382.9	0.5	0.2	0.8
04/12/2025 19:00	3,618.6	185.2	3,618.6	105,200.0	380.7	0.5	0.2	0.8
04/12/2025 20:00	3,639.9	185.5	3,639.9	105,200.0	382.9	0.5	0.2	0.8
04/12/2025 21:00	3,639.2	184.8	3,639.2	105,200.0	382.8	0.5	0.2	0.8
04/12/2025 22:00	3,639.2	183.6	3,639.2	105,200.0	382.8	0.5	0.2	0.8
04/12/2025 23:00	3,651.5	182.8	3,651.5	105,200.0	384.1	0.5	0.2	0.8
Average/Sum#:	3,648.2	185.3	3,648.2	105,200.0	383.8	0.5	0.2	0.8
Minimum:	3,618.6	178.9	3,618.6	105,200.0	380.7	0.5	0.2	0.8
Maximum:	3,761.8	200.9	3,761.8	105,200.0	395.7	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/13/2025 00:00	3,655.3	181.7	3,655.3	105,200.0	384.5	0.5	0.2	0.8
04/13/2025 01:00	3,641.8	180.8	3,641.8	105,200.0	383.1	0.5	0.2	0.8
04/13/2025 02:00	3,639.8	179.7	3,639.8	105,200.0	382.9	0.5	0.2	0.8
04/13/2025 03:00	3,640.2	177.9	3,640.2	105,200.0	382.9	0.5	0.2	0.8
04/13/2025 04:00	3,663.5	177.5	3,663.5	105,200.0	385.4	0.5	0.2	0.8
04/13/2025 05:00	3,672.6	176.6	3,672.6	105,200.0	386.4	0.5	0.2	0.8
04/13/2025 06:00	3,954.8	182.5	3,954.8	105,200.0	416.0	0.5	0.3	0.9
04/13/2025 07:00	3,671.3	194.6	3,671.3	105,200.0	386.2	0.5	0.2	0.8
04/13/2025 08:00	3,670.7	190.4	3,670.7	105,200.0	386.2	0.5	0.2	0.8
04/13/2025 09:00	3,677.8	182.9	3,677.8	105,200.0	386.9	0.5	0.2	0.8
04/13/2025 10:00	3,675.6	185.9	3,675.6	105,200.0	386.7	0.5	0.2	0.8
04/13/2025 11:00	3,678.7	186.7	3,678.7	105,200.0	387.0	0.5	0.2	0.8
04/13/2025 12:00	3,645.2	198.9	3,645.2	105,200.0	383.5	0.5	0.2	0.8
04/13/2025 13:00	3,611.4	201.3	3,611.4	105,200.0	379.9	0.5	0.2	0.8
04/13/2025 14:00	3,575.2	193.4	3,575.2	105,200.0	376.1	0.5	0.2	0.8
04/13/2025 15:00	3,568.1	192.4	3,568.1	105,200.0	375.4	0.5	0.2	0.8
04/13/2025 16:00	3,567.6	192.1	3,567.6	105,200.0	375.3	0.5	0.2	0.8
04/13/2025 17:00	3,853.0	194.0	3,853.0	105,200.0	405.3	0.5	0.3	0.9
04/13/2025 18:00	3,575.3	191.9	3,575.3	105,200.0	376.1	0.5	0.2	0.8
04/13/2025 19:00	3,573.5	190.2	3,573.5	105,200.0	375.9	0.5	0.2	0.8
04/13/2025 20:00	3,622.3	188.5	3,622.3	105,200.0	381.1	0.5	0.2	0.8
04/13/2025 21:00	3,596.3	188.0	3,596.3	105,200.0	378.3	0.5	0.2	0.8
04/13/2025 22:00	3,609.0	186.9	3,609.0	105,200.0	379.7	0.5	0.2	0.8
04/13/2025 23:00	3,693.9	183.4	3,693.9	105,200.0	388.6	0.5	0.2	0.8
Average/Sum#:	3,655.5	187.4	3,655.5	105,200.0	384.6	0.5	0.2	0.8
Minimum:	3,567.6	176.6	3,567.6	105,200.0	375.3	0.5	0.2	0.8
Maximum:	3,954.8	201.3	3,954.8	105,200.0	416.0	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/14/2025 00:00	3,664.8	184.7	3,664.8	105,200.0	385.5	0.5	0.2	0.8
04/14/2025 01:00	3,676.2	184.8	3,676.2	105,200.0	386.7	0.5	0.2	0.8
04/14/2025 02:00	3,683.9	182.3	3,683.9	105,200.0	387.5	0.5	0.2	0.8
04/14/2025 03:00	3,688.5	180.1	3,688.5	105,200.0	388.0	0.5	0.2	0.8
04/14/2025 04:00	3,686.4	178.8	3,686.4	105,200.0	387.8	0.5	0.2	0.8
04/14/2025 05:00	3,693.1	178.8	3,693.1	105,200.0	388.5	0.5	0.2	0.8
04/14/2025 06:00	4,130.2	183.7	4,130.2	105,200.0	434.5	0.5	0.3	0.9
04/14/2025 07:00	3,637.3	194.1	3,637.3	105,200.0	382.6	0.5	0.2	0.8
04/14/2025 08:00	3,645.3	195.1	3,645.3	105,200.0	383.5	0.5	0.2	0.8
04/14/2025 09:00	3,649.9	184.5	3,649.9	105,200.0	384.0	0.5	0.2	0.8
04/14/2025 10:00	3,636.5	190.7	3,636.5	105,200.0	382.6	0.5	0.2	0.8
04/14/2025 11:00	3,631.9	189.8	3,631.9	105,200.0	382.1	0.5	0.2	0.8
04/14/2025 12:00	3,636.3	206.9	3,636.3	105,200.0	382.5	0.5	0.2	0.8
04/14/2025 13:00	3,637.7	209.0	3,637.7	105,200.0	382.7	0.5	0.2	0.8
04/14/2025 14:00	3,631.5	199.1	3,631.5	105,200.0	382.0	0.5	0.2	0.8
04/14/2025 15:00	3,626.2	196.4	3,626.2	105,200.0	381.5	0.5	0.2	0.8
04/14/2025 16:00	3,621.4	194.7	3,621.4	105,200.0	381.0	0.5	0.2	0.8
04/14/2025 17:00	3,863.1	198.9	3,863.1	105,200.0	406.4	0.5	0.3	0.9
04/14/2025 18:00	3,630.5	195.1	3,630.5	105,200.0	381.9	0.5	0.2	0.8
04/14/2025 19:00	3,632.3	193.4	3,632.3	105,200.0	382.1	0.5	0.2	0.8
04/14/2025 20:00	3,638.4	193.1	3,638.4	105,200.0	382.8	0.5	0.2	0.8
04/14/2025 21:00	3,637.0	190.9	3,637.0	105,200.0	382.6	0.5	0.2	0.8
04/14/2025 22:00	3,642.5	188.4	3,642.5	105,200.0	383.2	0.5	0.2	0.8
04/14/2025 23:00	3,668.8	187.6	3,668.8	105,200.0	386.0	0.5	0.2	0.8
Average/Sum#:	3,678.7	190.9	3,678.7	105,200.0	387.0	0.5	0.2	0.8
Minimum:	3,621.4	178.8	3,621.4	105,200.0	381.0	0.5	0.2	0.8
Maximum:	4,130.2	209.0	4,130.2	105,200.0	434.5	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/15/2025 00:00	3,662.5	185.5	3,662.5	105,200.0	385.3	0.5	0.2	0.8
04/15/2025 01:00	3,653.3	183.8	3,653.3	105,200.0	384.3	0.5	0.2	0.8
04/15/2025 02:00	3,662.9	182.4	3,662.9	105,200.0	385.3	0.5	0.2	0.8
04/15/2025 03:00	3,711.9	180.2	3,711.9	105,200.0	390.5	0.5	0.2	0.8
04/15/2025 04:00	3,790.5	178.3	3,790.5	105,200.0	398.8	0.5	0.3	0.8
04/15/2025 05:00	3,682.9	177.6	3,682.9	105,200.0	387.4	0.5	0.2	0.8
04/15/2025 06:00	3,742.6	178.8	3,742.6	105,200.0	393.7	0.5	0.2	0.8
04/15/2025 07:00	3,669.0	182.9	3,669.0	105,200.0	386.0	0.5	0.2	0.8
04/15/2025 08:00	3,677.7	184.4	3,677.7	105,200.0	386.9	0.5	0.2	0.8
04/15/2025 09:00	3,683.2	182.5	3,683.2	105,200.0	387.5	0.5	0.2	0.8
04/15/2025 10:00	3,696.0	186.0	3,696.0	105,200.0	388.8	0.5	0.2	0.8
04/15/2025 11:00	3,697.2	185.9	3,697.2	105,200.0	388.9	0.5	0.2	0.8
04/15/2025 12:00	3,686.8	196.2	3,686.8	105,200.0	387.9	0.5	0.2	0.8
04/15/2025 13:00	3,666.0	198.8	3,666.0	105,200.0	385.7	0.5	0.2	0.8
04/15/2025 14:00	3,658.6	190.4	3,658.6	105,200.0	384.9	0.5	0.2	0.8
04/15/2025 15:00	3,659.9	189.4	3,659.9	105,200.0	385.0	0.5	0.2	0.8
04/15/2025 16:00	3,782.7	187.6	3,782.7	105,200.0	397.9	0.5	0.3	0.8
04/15/2025 17:00	4,037.9	186.5	4,037.9	105,200.0	424.8	0.5	0.3	0.9
04/15/2025 18:00	3,663.5	184.4	3,663.5	105,200.0	385.4	0.5	0.2	0.8
04/15/2025 19:00	3,657.5	183.2	3,657.5	105,200.0	384.8	0.5	0.2	0.8
04/15/2025 20:00	3,866.1	180.9	3,866.1	105,200.0	406.7	0.5	0.3	0.9
04/15/2025 21:00	3,649.2	179.3	3,649.2	105,200.0	383.9	0.5	0.2	0.8
04/15/2025 22:00	3,660.6	178.3	3,660.6	105,200.0	385.1	0.5	0.2	0.8
04/15/2025 23:00	3,916.2	178.1	3,916.2	105,200.0	412.0	0.5	0.3	0.9
Average/Sum#:	3,718.1	184.2	3,718.1	105,200.0	391.1	0.5	0.2	0.8
Minimum:	3,649.2	177.6	3,649.2	105,200.0	383.9	0.5	0.2	0.8
Maximum:	4,037.9	198.8	4,037.9	105,200.0	424.8	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/16/2025 00:00	3,668.8	177.4	3,668.8	105,200.0	386.0	0.5	0.2	0.8
04/16/2025 01:00	3,682.1	177.8	3,682.1	105,200.0	387.4	0.5	0.2	0.8
04/16/2025 02:00	3,681.3	177.9	3,681.3	105,200.0	387.3	0.5	0.2	0.8
04/16/2025 03:00	3,683.9	177.3	3,683.9	105,200.0	387.5	0.5	0.2	0.8
04/16/2025 04:00	3,680.8	176.7	3,680.8	105,200.0	387.2	0.5	0.2	0.8
04/16/2025 05:00	3,673.2	176.6	3,673.2	105,200.0	386.4	0.5	0.2	0.8
04/16/2025 06:00	3,657.8	177.8	3,657.8	105,200.0	384.8	0.5	0.2	0.8
04/16/2025 07:00	3,670.0	180.4	3,670.0	105,200.0	386.1	0.5	0.2	0.8
04/16/2025 08:00	3,675.2	182.1	3,675.2	105,200.0	386.6	0.5	0.2	0.8
04/16/2025 09:00	3,673.5	183.9	3,673.5	105,200.0	386.5	0.5	0.2	0.8
04/16/2025 10:00	3,657.6	186.7	3,657.6	105,200.0	384.8	0.5	0.2	0.8
04/16/2025 11:00	3,642.8	185.4	3,642.8	105,200.0	383.2	0.5	0.2	0.8
04/16/2025 12:00	3,642.3	201.4	3,642.3	105,200.0	383.2	0.5	0.2	0.8
04/16/2025 13:00	3,642.9	202.3	3,642.9	105,200.0	383.2	0.5	0.2	0.8
04/16/2025 14:00	3,647.3	187.7	3,647.3	105,200.0	383.7	0.5	0.2	0.8
04/16/2025 15:00	3,644.3	186.4	3,644.3	105,200.0	383.4	0.5	0.2	0.8
04/16/2025 16:00	3,645.0	186.6	3,645.0	105,200.0	383.5	0.5	0.2	0.8
04/16/2025 17:00	3,652.1	187.2	3,652.1	105,200.0	384.2	0.5	0.2	0.8
04/16/2025 18:00	3,661.8	182.8	3,661.8	105,200.0	385.2	0.5	0.2	0.8
04/16/2025 19:00	3,675.5	180.8	3,675.5	105,200.0	386.7	0.5	0.2	0.8
04/16/2025 20:00	3,688.3	179.5	3,688.3	105,200.0	388.0	0.5	0.2	0.8
04/16/2025 21:00	3,696.5	178.1	3,696.5	105,200.0	388.9	0.5	0.2	0.8
04/16/2025 22:00	3,692.2	177.8	3,692.2	105,200.0	388.4	0.5	0.2	0.8
04/16/2025 23:00	3,697.1	177.5	3,697.1	105,200.0	388.9	0.5	0.2	0.8
Average/Sum#:	3,668.0	182.8	3,668.0	105,200.0	385.9	0.5	0.2	0.8
Minimum:	3,642.3	176.6	3,642.3	105,200.0	383.2	0.5	0.2	0.8
Maximum:	3,697.1	202.3	3,697.1	105,200.0	388.9	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/17/2025 00:00	3,695.4	177.0	3,695.4	105,200.0	388.8	0.5	0.2	0.8
04/17/2025 01:00	3,696.5	176.8	3,696.5	105,200.0	388.9	0.5	0.2	0.8
04/17/2025 02:00	3,697.3	176.9	3,697.3	105,200.0	389.0	0.5	0.2	0.8
04/17/2025 03:00	3,699.3	176.9	3,699.3	105,200.0	389.2	0.5	0.2	0.8
04/17/2025 04:00	3,699.6	177.1	3,699.6	105,200.0	389.2	0.5	0.2	0.8
04/17/2025 05:00	3,698.8	177.4	3,698.8	105,200.0	389.1	0.5	0.2	0.8
04/17/2025 06:00	3,697.0	178.1	3,697.0	105,200.0	388.9	0.5	0.2	0.8
04/17/2025 07:00	3,679.5	179.5	3,679.5	105,200.0	387.1	0.5	0.2	0.8
04/17/2025 08:00	3,947.6	180.8	3,947.6	105,200.0	415.3	0.5	0.3	0.9
04/17/2025 09:00	3,653.1	181.5	3,653.1	105,200.0	384.3	0.5	0.2	0.8
04/17/2025 10:00	3,654.5	184.3	3,654.5	105,200.0	384.5	0.5	0.2	0.8
04/17/2025 11:00	3,653.2	186.1	3,653.2	105,200.0	384.3	0.5	0.2	0.8
04/17/2025 12:00	3,652.6	187.7	3,652.6	105,200.0	384.3	0.5	0.2	0.8
04/17/2025 13:00	3,652.2	192.9	3,652.2	105,200.0	384.2	0.5	0.2	0.8
04/17/2025 14:00	3,650.4	187.6	3,650.4	105,200.0	384.0	0.5	0.2	0.8
04/17/2025 15:00	3,752.6	184.0	3,752.6	105,200.0	394.8	0.5	0.2	0.8
04/17/2025 16:00	3,652.4	183.7	3,652.4	105,200.0	384.2	0.5	0.2	0.8
04/17/2025 17:00	3,652.0	185.7	3,652.0	105,200.0	384.2	0.5	0.2	0.8
04/17/2025 18:00	3,655.4	183.4	3,655.4	105,200.0	384.5	0.5	0.2	0.8
04/17/2025 19:00	3,651.2	181.9	3,651.2	105,200.0	384.1	0.5	0.2	0.8
04/17/2025 20:00	3,660.7	181.7	3,660.7	105,200.0	385.1	0.5	0.2	0.8
04/17/2025 21:00	3,663.1	180.7	3,663.1	105,200.0	385.4	0.5	0.2	0.8
04/17/2025 22:00	3,662.0	178.2	3,662.0	105,200.0	385.2	0.5	0.2	0.8
04/17/2025 23:00	3,663.0	176.6	3,663.0	105,200.0	385.3	0.5	0.2	0.8
Average/Sum#:	3,685.0	181.5	3,685.0	105,200.0	387.7	0.5	0.2	0.8
Minimum:	3,650.4	176.6	3,650.4	105,200.0	384.0	0.5	0.2	0.8
Maximum:	3,947.6	192.9	3,947.6	105,200.0	415.3	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/18/2025 00:00	3,675.8	176.7	3,675.8	105,200.0	386.7	0.5	0.2	0.8
04/18/2025 01:00	3,682.7	176.4	3,682.7	105,200.0	387.4	0.5	0.2	0.8
04/18/2025 02:00	3,683.5	176.3	3,683.5	105,200.0	387.5	0.5	0.2	0.8
04/18/2025 03:00	3,684.8	176.0	3,684.8	105,200.0	387.6	0.5	0.2	0.8
04/18/2025 04:00	3,698.6	176.6	3,698.6	105,200.0	389.1	0.5	0.2	0.8
04/18/2025 05:00	3,706.2	176.5	3,706.2	105,200.0	389.9	0.5	0.2	0.8
04/18/2025 06:00	4,276.2	176.7	4,276.2	105,200.0	449.9	0.6	0.3	0.9
04/18/2025 07:00	4,216.5	180.6	4,216.5	105,200.0	443.6	0.6	0.3	0.9
04/18/2025 08:00	3,823.4	184.0	3,823.4	105,200.0	402.2	0.5	0.3	0.8
04/18/2025 09:00	3,412.3	184.4	3,412.3	105,200.0	359.0	0.5	0.2	0.8
04/18/2025 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/18/2025 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/18/2025 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/18/2025 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/18/2025 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/18/2025 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/18/2025 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/18/2025 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/18/2025 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/18/2025 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/18/2025 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/18/2025 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/18/2025 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/18/2025 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,786.0	178.4	3,786.0	105,200.0	398.3	0.5	0.2	0.8
Minimum:	3,412.3	176.0	3,412.3	105,200.0	359.0	0.5	0.2	0.8
Maximum:	4,276.2	184.4	4,276.2	105,200.0	449.9	0.6	0.3	0.9
%SI	58.33	58.33	58.33	0.00	58.33	58.33	58.33	58.33

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/19/2025 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2025 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2025 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2025 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2025 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2025 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2025 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2025 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2025 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2025 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2025 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2025 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2025 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2025 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2025 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2025 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2025 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2025 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2025 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2025 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2025 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2025 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2025 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/19/2025 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/20/2025 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2025 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2025 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2025 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2025 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2025 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2025 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2025 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2025 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2025 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2025 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2025 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2025 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2025 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2025 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2025 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2025 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2025 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2025 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2025 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2025 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2025 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2025 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/20/2025 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

Const. Value/Limit Tag:		> 4.73 > 1 > 1.8							
		Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	
		GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
		1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/21/2025 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/21/2025 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/21/2025 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/21/2025 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/21/2025 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/21/2025 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/21/2025 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/21/2025 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/21/2025 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/21/2025 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/21/2025 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/21/2025 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/21/2025 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/21/2025 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/21/2025 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/21/2025 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/21/2025 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/21/2025 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/21/2025 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/21/2025 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/21/2025 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/21/2025 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/21/2025 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/21/2025 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00	

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

Const. Value/Limit Tag:		> 4.73 > 1 > 1.8							
		Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	
		GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
		1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/22/2025 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/22/2025 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/22/2025 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/22/2025 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/22/2025 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/22/2025 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/22/2025 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/22/2025 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/22/2025 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/22/2025 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/22/2025 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/22/2025 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/22/2025 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/22/2025 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/22/2025 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/22/2025 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/22/2025 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/22/2025 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/22/2025 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/22/2025 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/22/2025 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/22/2025 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/22/2025 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/22/2025 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00	

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/23/2025 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2025 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2025 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2025 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2025 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2025 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2025 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2025 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2025 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2025 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2025 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2025 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2025 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2025 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2025 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2025 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2025 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2025 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2025 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2025 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2025 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2025 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2025 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/23/2025 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/24/2025 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2025 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2025 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2025 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2025 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2025 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2025 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2025 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2025 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2025 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2025 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2025 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2025 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2025 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2025 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2025 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2025 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2025 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2025 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2025 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2025 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2025 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2025 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/24/2025 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/25/2025 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2025 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2025 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2025 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2025 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2025 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2025 06:00	1,252.5	0.0	1,252.5	105,200.0	131.8	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2025 07:00	2,783.9	0.0	2,783.9	105,200.0	292.9	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2025 08:00	4,075.8	0.0	4,075.8	105,200.0	428.8	0.5	0.3	0.9	0.5	0.3	0.9
04/25/2025 09:00	4,110.2	0.0	4,110.2	105,200.0	432.4	0.5	0.3	0.9	0.5	0.3	0.9
04/25/2025 10:00	3,827.3	0.0	3,827.3	105,200.0	402.6	0.5	0.2	0.8	0.5	0.2	0.8
04/25/2025 11:00	3,268.3	0.0	3,268.3	105,200.0	343.8	0.4	0.2	0.7	0.4	0.2	0.7
04/25/2025 12:00	3,311.1	0.0	3,311.1	105,200.0	348.3	0.4	0.2	0.7	0.4	0.2	0.7
04/25/2025 13:00	3,027.1	0.0	3,027.1	105,200.0	318.5	0.4	0.2	0.7	0.4	0.2	0.7
04/25/2025 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2025 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2025 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2025 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2025 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2025 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2025 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2025 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2025 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
04/25/2025 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,207.0	0.0	3,207.0	105,200.0	337.4	0.5	0.2	0.8	0.5	0.2	0.8
Minimum:	1,252.5	0.0	1,252.5	105,200.0	131.8	0.4	0.2	0.7	0.4	0.2	0.7
Maximum:	4,110.2	0.0	4,110.2	105,200.0	432.4	0.5	0.3	0.9	0.5	0.3	0.9
%SI	66.67	66.67	66.67	0.00	66.67	75.00	75.00	75.00	75.00	75.00	75.00

Fuel Gas and Emissions Daily Summary



CT2

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/26/2025 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2025 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2025 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2025 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2025 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2025 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2025 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2025 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2025 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2025 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2025 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2025 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2025 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2025 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2025 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2025 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2025 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2025 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2025 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2025 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2025 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2025 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2025 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/26/2025 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

Const. Value/Limit Tag:		> 4.73 > 1 > 1.8							
		Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	
		GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
		1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/27/2025 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/27/2025 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/27/2025 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/27/2025 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/27/2025 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/27/2025 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/27/2025 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/27/2025 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/27/2025 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/27/2025 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/27/2025 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/27/2025 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/27/2025 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/27/2025 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/27/2025 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/27/2025 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/27/2025 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/27/2025 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/27/2025 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/27/2025 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/27/2025 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/27/2025 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/27/2025 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
04/27/2025 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0	
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00	

Fuel Gas and Emissions Daily Summary



CT2

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/28/2025 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2025 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2025 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2025 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2025 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2025 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2025 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2025 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2025 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2025 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2025 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2025 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2025 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2025 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2025 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2025 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2025 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2025 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2025 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2025 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2025 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2025 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2025 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/28/2025 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/29/2025 00:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2025 01:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2025 02:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2025 03:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2025 04:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2025 05:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2025 06:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2025 07:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2025 08:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2025 09:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2025 10:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2025 11:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2025 12:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2025 13:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2025 14:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2025 15:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2025 16:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2025 17:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2025 18:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2025 19:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2025 20:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2025 21:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2025 22:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
04/29/2025 23:00	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

Const. Value/Limit Tag:									
		Unit CT2		Unit CT2		Unit CT2		Unit CT2	
		GasFlow, _CT, 100scfh		GasFlow, _DB, 100scfh		GasFlowTotal, 100scfh		GCVGas, BtuPer100scf	
		HI, MBtuPerHr		PM10_Norm, LbPerHr		SO2_Norm, LbPerHr		VOC_Norm, LbPerHr	
		1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	
04/30/2025 00:00		0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	
04/30/2025 01:00		0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	
04/30/2025 02:00		0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	
04/30/2025 03:00		0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	
04/30/2025 04:00		0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	
04/30/2025 05:00		0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	
04/30/2025 06:00		0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	
04/30/2025 07:00		0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	
04/30/2025 08:00		0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	
04/30/2025 09:00		0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	
04/30/2025 10:00		0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	
04/30/2025 11:00		0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	
04/30/2025 12:00		0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	
04/30/2025 13:00		0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	
04/30/2025 14:00		0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	
04/30/2025 15:00		0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	
04/30/2025 16:00		0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	
04/30/2025 17:00		0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	
04/30/2025 18:00		0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	
04/30/2025 19:00		0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	
04/30/2025 20:00		0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	
04/30/2025 21:00		0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	
04/30/2025 22:00		0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	
04/30/2025 23:00		0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	
Average/Sum#:		0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	
Minimum:		0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	
Maximum:		0.0	0.0	0.0	105,200.0	0.0	0.0	0.0	
%SI		100.00	100.00	100.00	0.00	100.00	100.00	100.00	

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

Const. Value/Limit Tag:		> 4.73 > 1 > 1.8							
		Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	
		GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
		1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/01/2025 00:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0	
05/01/2025 01:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0	
05/01/2025 02:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0	
05/01/2025 03:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0	
05/01/2025 04:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0	
05/01/2025 05:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0	
05/01/2025 06:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0	
05/01/2025 07:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0	
05/01/2025 08:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0	
05/01/2025 09:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0	
05/01/2025 10:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0	
05/01/2025 11:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0	
05/01/2025 12:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0	
05/01/2025 13:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0	
05/01/2025 14:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0	
05/01/2025 15:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0	
05/01/2025 16:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0	
05/01/2025 17:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0	
05/01/2025 18:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0	
05/01/2025 19:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0	
05/01/2025 20:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0	
05/01/2025 21:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0	
05/01/2025 22:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0	
05/01/2025 23:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0	
Average/Sum#:	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0	
Minimum:	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0	
Maximum:	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0	
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00	

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/02/2025 00:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2025 01:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2025 02:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2025 03:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2025 04:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2025 05:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2025 06:00	2,958.6	0.0	2,958.6	105,000.0	310.7	0.0	0.0	0.0	0.0	0.0	0.0
05/02/2025 07:00	3,664.6	0.0	3,664.6	105,000.0	384.8	0.5	0.2	0.2	0.8	0.8	0.8
05/02/2025 08:00	3,632.4	0.0	3,632.4	105,000.0	381.4	0.5	0.2	0.2	0.8	0.8	0.8
05/02/2025 09:00	3,632.1	0.0	3,632.1	105,000.0	381.4	0.5	0.2	0.2	0.8	0.8	0.8
05/02/2025 10:00	3,624.5	0.0	3,624.5	105,000.0	380.6	0.5	0.2	0.2	0.8	0.8	0.8
05/02/2025 11:00	3,621.8	52.1	3,621.8	105,000.0	380.3	0.5	0.2	0.2	0.8	0.8	0.8
05/02/2025 12:00	3,621.8	71.2	3,621.8	105,000.0	380.3	0.5	0.2	0.2	0.8	0.8	0.8
05/02/2025 13:00	3,614.7	27.6	3,614.7	105,000.0	379.5	0.5	0.2	0.2	0.8	0.8	0.8
05/02/2025 14:00	3,616.6	0.0	3,616.6	105,000.0	379.7	0.5	0.2	0.2	0.8	0.8	0.8
05/02/2025 15:00	3,787.8	0.0	3,787.8	105,000.0	397.7	0.5	0.2	0.2	0.8	0.8	0.8
05/02/2025 16:00	3,672.4	0.0	3,672.4	105,000.0	385.6	0.5	0.2	0.2	0.8	0.8	0.8
05/02/2025 17:00	3,971.3	0.0	3,971.3	105,000.0	417.0	0.5	0.3	0.3	0.8	0.8	0.8
05/02/2025 18:00	3,684.6	0.0	3,684.6	105,000.0	386.9	0.5	0.2	0.2	0.8	0.8	0.8
05/02/2025 19:00	3,864.6	0.0	3,864.6	105,000.0	405.8	0.5	0.2	0.2	0.8	0.8	0.8
05/02/2025 20:00	3,696.1	0.0	3,696.1	105,000.0	388.1	0.5	0.2	0.2	0.8	0.8	0.8
05/02/2025 21:00	3,690.1	0.0	3,690.1	105,000.0	387.5	0.5	0.2	0.2	0.8	0.8	0.8
05/02/2025 22:00	3,691.4	0.0	3,691.4	105,000.0	387.6	0.5	0.2	0.2	0.8	0.8	0.8
05/02/2025 23:00	3,693.1	0.0	3,693.1	105,000.0	387.8	0.5	0.2	0.2	0.8	0.8	0.8
Average/Sum#:	3,652.1	8.4	3,652.1	105,000.0	383.5	0.5	0.2	0.2	0.8	0.8	0.8
Minimum:	2,958.6	0.0	2,958.6	105,000.0	310.7	0.5	0.2	0.2	0.8	0.8	0.8
Maximum:	3,971.3	71.2	3,971.3	105,000.0	417.0	0.5	0.3	0.3	0.8	0.8	0.8
%SI	25.00	25.00	25.00	0.00	25.00	29.17	29.17	29.17	29.17	29.17	29.17

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/03/2025 00:00	3,682.8	0.0	3,682.8	105,000.0	386.7	0.5	0.2	0.8			
05/03/2025 01:00	3,683.3	0.0	3,683.3	105,000.0	386.7	0.5	0.2	0.8			
05/03/2025 02:00	3,706.5	0.0	3,706.5	105,000.0	389.2	0.5	0.2	0.8			
05/03/2025 03:00	3,706.6	0.0	3,706.6	105,000.0	389.2	0.5	0.2	0.8			
05/03/2025 04:00	3,714.1	0.0	3,714.1	105,000.0	390.0	0.5	0.2	0.8			
05/03/2025 05:00	3,718.7	0.0	3,718.7	105,000.0	390.5	0.5	0.2	0.8			
05/03/2025 06:00	3,717.8	0.0	3,717.8	105,000.0	390.4	0.5	0.2	0.8			
05/03/2025 07:00	3,723.5	0.0	3,723.5	105,000.0	391.0	0.5	0.2	0.8			
05/03/2025 08:00	3,696.7	0.0	3,696.7	105,000.0	388.2	0.5	0.2	0.8			
05/03/2025 09:00	3,692.4	0.0	3,692.4	105,000.0	387.7	0.5	0.2	0.8			
05/03/2025 10:00	3,693.5	0.0	3,693.5	105,000.0	387.8	0.5	0.2	0.8			
05/03/2025 11:00	3,705.9	52.6	3,705.9	105,000.0	389.1	0.5	0.2	0.8			
05/03/2025 12:00	3,704.6	62.9	3,704.6	105,000.0	389.0	0.5	0.2	0.8			
05/03/2025 13:00	3,679.3	5.9	3,679.3	105,000.0	386.3	0.5	0.2	0.8			
05/03/2025 14:00	3,674.3	0.0	3,674.3	105,000.0	385.8	0.5	0.2	0.8			
05/03/2025 15:00	3,666.2	0.0	3,666.2	105,000.0	385.0	0.5	0.2	0.8			
05/03/2025 16:00	3,675.8	0.0	3,675.8	105,000.0	386.0	0.5	0.2	0.8			
05/03/2025 17:00	3,744.2	0.0	3,744.2	105,000.0	393.1	0.5	0.2	0.8			
05/03/2025 18:00	3,694.5	0.0	3,694.5	105,000.0	387.9	0.5	0.2	0.8			
05/03/2025 19:00	3,687.8	0.0	3,687.8	105,000.0	387.2	0.5	0.2	0.8			
05/03/2025 20:00	3,685.2	0.0	3,685.2	105,000.0	386.9	0.5	0.2	0.8			
05/03/2025 21:00	3,686.3	0.0	3,686.3	105,000.0	387.1	0.5	0.2	0.8			
05/03/2025 22:00	3,695.5	0.0	3,695.5	105,000.0	388.0	0.5	0.2	0.8			
05/03/2025 23:00	3,695.9	0.0	3,695.9	105,000.0	388.1	0.5	0.2	0.8			
Average/Sum#:	3,697.1	5.1	3,697.1	105,000.0	388.2	0.5	0.2	0.8			
Minimum:	3,666.2	0.0	3,666.2	105,000.0	385.0	0.5	0.2	0.8			
Maximum:	3,744.2	62.9	3,744.2	105,000.0	393.1	0.5	0.2	0.8			
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/04/2025 00:00	3,687.1	0.0	3,687.1	105,000.0	387.1	0.5	0.2	0.8			
05/04/2025 01:00	3,691.9	0.0	3,691.9	105,000.0	387.6	0.5	0.2	0.8			
05/04/2025 02:00	3,698.5	0.0	3,698.5	105,000.0	388.3	0.5	0.2	0.8			
05/04/2025 03:00	3,696.3	0.0	3,696.3	105,000.0	388.1	0.5	0.2	0.8			
05/04/2025 04:00	3,698.9	0.0	3,698.9	105,000.0	388.4	0.5	0.2	0.8			
05/04/2025 05:00	3,701.5	0.0	3,701.5	105,000.0	388.7	0.5	0.2	0.8			
05/04/2025 06:00	4,255.3	0.0	4,255.3	105,000.0	446.8	0.5	0.3	0.9			
05/04/2025 07:00	4,230.9	0.0	4,230.9	105,000.0	444.2	0.5	0.3	0.9			
05/04/2025 08:00	3,690.0	0.0	3,690.0	105,000.0	387.5	0.5	0.2	0.8			
05/04/2025 09:00	3,675.4	0.0	3,675.4	105,000.0	385.9	0.5	0.2	0.8			
05/04/2025 10:00	3,678.4	0.0	3,678.4	105,000.0	386.2	0.5	0.2	0.8			
05/04/2025 11:00	3,671.8	24.1	3,671.8	105,000.0	385.5	0.5	0.2	0.8			
05/04/2025 12:00	3,667.7	11.5	3,667.7	105,000.0	385.1	0.5	0.2	0.8			
05/04/2025 13:00	3,665.1	3.3	3,665.1	105,000.0	384.8	0.5	0.2	0.8			
05/04/2025 14:00	3,661.4	0.0	3,661.4	105,000.0	384.4	0.5	0.2	0.8			
05/04/2025 15:00	3,657.3	0.0	3,657.3	105,000.0	384.0	0.5	0.2	0.8			
05/04/2025 16:00	3,645.7	0.0	3,645.7	105,000.0	382.8	0.5	0.2	0.8			
05/04/2025 17:00	4,046.4	0.0	4,046.4	105,000.0	424.9	0.5	0.3	0.9			
05/04/2025 18:00	4,037.4	0.0	4,037.4	105,000.0	423.9	0.5	0.3	0.8			
05/04/2025 19:00	4,585.3	0.0	4,585.3	105,000.0	481.5	0.6	0.3	1.0			
05/04/2025 20:00	4,590.9	0.0	4,590.9	105,000.0	482.0	0.6	0.3	1.0			
05/04/2025 21:00	4,607.8	0.0	4,607.8	105,000.0	483.8	0.6	0.3	1.0			
05/04/2025 22:00	4,367.9	0.0	4,367.9	105,000.0	458.6	0.6	0.3	0.9			
05/04/2025 23:00	3,794.1	0.0	3,794.1	105,000.0	398.4	0.5	0.2	0.8			
Average/Sum#:	3,904.3	1.6	3,904.3	105,000.0	409.9	0.5	0.2	0.8			
Minimum:	3,645.7	0.0	3,645.7	105,000.0	382.8	0.5	0.2	0.8			
Maximum:	4,607.8	24.1	4,607.8	105,000.0	483.8	0.6	0.3	1.0			
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/05/2025 00:00	3,665.6	0.0	3,665.6	105,000.0	384.9	0.5	0.2	0.2	0.8	0.8
05/05/2025 01:00	3,676.2	0.0	3,676.2	105,000.0	386.0	0.5	0.2	0.2	0.8	0.8
05/05/2025 02:00	3,674.0	0.0	3,674.0	105,000.0	385.8	0.5	0.2	0.2	0.8	0.8
05/05/2025 03:00	3,683.5	0.0	3,683.5	105,000.0	386.8	0.5	0.2	0.2	0.8	0.8
05/05/2025 04:00	3,766.1	0.0	3,766.1	105,000.0	395.4	0.5	0.2	0.2	0.8	0.8
05/05/2025 05:00	3,980.7	0.0	3,980.7	105,000.0	418.0	0.5	0.3	0.3	0.8	0.8
05/05/2025 06:00	4,102.8	0.0	4,102.8	105,000.0	430.8	0.5	0.3	0.3	0.9	0.9
05/05/2025 07:00	3,691.5	0.0	3,691.5	105,000.0	387.6	0.5	0.2	0.2	0.8	0.8
05/05/2025 08:00	3,655.3	0.1	3,655.3	105,000.0	383.8	0.5	0.2	0.2	0.8	0.8
05/05/2025 09:00	3,654.5	0.0	3,654.5	105,000.0	383.7	0.5	0.2	0.2	0.8	0.8
05/05/2025 10:00	3,636.8	0.0	3,636.8	105,000.0	381.9	0.5	0.2	0.2	0.8	0.8
05/05/2025 11:00	3,651.8	44.2	3,651.8	105,000.0	383.4	0.5	0.2	0.2	0.8	0.8
05/05/2025 12:00	3,659.5	40.9	3,659.5	105,000.0	384.2	0.5	0.2	0.2	0.8	0.8
05/05/2025 13:00	3,652.8	12.0	3,652.8	105,000.0	383.5	0.5	0.2	0.2	0.8	0.8
05/05/2025 14:00	3,657.3	0.0	3,657.3	105,000.0	384.0	0.5	0.2	0.2	0.8	0.8
05/05/2025 15:00	3,661.1	0.0	3,661.1	105,000.0	384.4	0.5	0.2	0.2	0.8	0.8
05/05/2025 16:00	3,656.0	0.0	3,656.0	105,000.0	383.9	0.5	0.2	0.2	0.8	0.8
05/05/2025 17:00	3,726.3	0.0	3,726.3	105,000.0	391.3	0.5	0.2	0.2	0.8	0.8
05/05/2025 18:00	4,231.4	0.0	4,231.4	105,000.0	444.3	0.5	0.3	0.3	0.9	0.9
05/05/2025 19:00	4,546.3	0.0	4,546.3	105,000.0	477.4	0.6	0.3	0.3	1.0	1.0
05/05/2025 20:00	4,547.2	0.0	4,547.2	105,000.0	477.5	0.6	0.3	0.3	1.0	1.0
05/05/2025 21:00	4,545.9	0.0	4,545.9	105,000.0	477.3	0.6	0.3	0.3	1.0	1.0
05/05/2025 22:00	4,544.5	0.0	4,544.5	105,000.0	477.2	0.6	0.3	0.3	1.0	1.0
05/05/2025 23:00	4,507.1	0.0	4,507.1	105,000.0	473.2	0.6	0.3	0.3	0.9	0.9
Average/Sum#:	3,907.3	4.1	3,907.3	105,000.0	410.3	0.5	0.2	0.2	0.8	0.8
Minimum:	3,636.8	0.0	3,636.8	105,000.0	381.9	0.5	0.2	0.2	0.8	0.8
Maximum:	4,547.2	44.2	4,547.2	105,000.0	477.5	0.6	0.3	0.3	1.0	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/06/2025 00:00	4,285.5	0.0	4,285.5	105,000.0	450.0	0.5	0.3	0.9
05/06/2025 01:00	4,121.8	0.0	4,121.8	105,000.0	432.8	0.5	0.3	0.9
05/06/2025 02:00	4,134.4	0.0	4,134.4	105,000.0	434.1	0.5	0.3	0.9
05/06/2025 03:00	4,118.2	0.0	4,118.2	105,000.0	432.4	0.5	0.3	0.9
05/06/2025 04:00	3,928.3	0.0	3,928.3	105,000.0	412.5	0.5	0.2	0.8
05/06/2025 05:00	4,567.1	0.0	4,567.1	105,000.0	479.5	0.6	0.3	1.0
05/06/2025 06:00	3,896.4	0.0	3,896.4	105,000.0	409.1	0.5	0.2	0.8
05/06/2025 07:00	3,681.4	5.7	3,681.4	105,000.0	386.5	0.5	0.2	0.8
05/06/2025 08:00	3,681.3	39.6	3,681.3	105,000.0	386.5	0.5	0.2	0.8
05/06/2025 09:00	3,695.3	11.8	3,695.3	105,000.0	388.0	0.5	0.2	0.8
05/06/2025 10:00	3,697.5	1.8	3,697.5	105,000.0	388.2	0.5	0.2	0.8
05/06/2025 11:00	3,682.3	83.9	3,682.3	105,000.0	386.6	0.5	0.2	0.8
05/06/2025 12:00	3,680.3	85.3	3,680.3	105,000.0	386.4	0.5	0.2	0.8
05/06/2025 13:00	3,681.5	41.3	3,681.5	105,000.0	386.6	0.5	0.2	0.8
05/06/2025 14:00	3,681.6	11.2	3,681.6	105,000.0	386.6	0.5	0.2	0.8
05/06/2025 15:00	3,690.7	0.0	3,690.7	105,000.0	387.5	0.5	0.2	0.8
05/06/2025 16:00	3,737.9	0.1	3,737.9	105,000.0	392.5	0.5	0.2	0.8
05/06/2025 17:00	4,056.9	1.7	4,056.9	105,000.0	426.0	0.5	0.3	0.9
05/06/2025 18:00	4,410.2	2.7	4,410.2	105,000.0	463.1	0.6	0.3	0.9
05/06/2025 19:00	4,486.1	0.0	4,486.1	105,000.0	471.0	0.6	0.3	0.9
05/06/2025 20:00	4,566.1	0.0	4,566.1	105,000.0	479.4	0.6	0.3	1.0
05/06/2025 21:00	4,600.1	0.0	4,600.1	105,000.0	483.0	0.6	0.3	1.0
05/06/2025 22:00	4,580.8	0.0	4,580.8	105,000.0	481.0	0.6	0.3	1.0
05/06/2025 23:00	4,303.4	0.0	4,303.4	105,000.0	451.9	0.5	0.3	0.9
Average/Sum#:	4,040.2	11.9	4,040.2	105,000.0	424.2	0.5	0.3	0.9
Minimum:	3,680.3	0.0	3,680.3	105,000.0	386.4	0.5	0.2	0.8
Maximum:	4,600.1	85.3	4,600.1	105,000.0	483.0	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/07/2025 00:00	3,861.0	0.0	3,861.0	105,000.0	405.4	0.5	0.2	0.8			
05/07/2025 01:00	3,678.7	0.0	3,678.7	105,000.0	386.3	0.5	0.2	0.8			
05/07/2025 02:00	3,679.6	0.0	3,679.6	105,000.0	386.4	0.5	0.2	0.8			
05/07/2025 03:00	3,839.1	0.0	3,839.1	105,000.0	403.1	0.5	0.2	0.8			
05/07/2025 04:00	3,690.7	0.0	3,690.7	105,000.0	387.5	0.5	0.2	0.8			
05/07/2025 05:00	3,701.2	0.0	3,701.2	105,000.0	388.6	0.5	0.2	0.8			
05/07/2025 06:00	3,706.4	0.0	3,706.4	105,000.0	389.2	0.5	0.2	0.8			
05/07/2025 07:00	3,722.7	0.0	3,722.7	105,000.0	390.9	0.5	0.2	0.8			
05/07/2025 08:00	4,404.6	0.1	4,404.6	105,000.0	462.5	0.6	0.3	0.9			
05/07/2025 09:00	3,745.4	1.1	3,745.4	105,000.0	393.3	0.5	0.2	0.8			
05/07/2025 10:00	3,669.1	0.0	3,669.1	105,000.0	385.3	0.5	0.2	0.8			
05/07/2025 11:00	3,626.5	64.1	3,626.5	105,000.0	380.8	0.5	0.2	0.8			
05/07/2025 12:00	3,624.7	76.3	3,624.7	105,000.0	380.6	0.5	0.2	0.8			
05/07/2025 13:00	3,211.5	72.3	3,211.5	105,000.0	337.2	0.5	0.2	0.8			
05/07/2025 14:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0			
05/07/2025 15:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0			
05/07/2025 16:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0			
05/07/2025 17:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0			
05/07/2025 18:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0			
05/07/2025 19:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0			
05/07/2025 20:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0			
05/07/2025 21:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0			
05/07/2025 22:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0			
05/07/2025 23:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0			
Average/Sum#:	3,725.8	15.3	3,725.8	105,000.0	391.2	0.5	0.2	0.8			
Minimum:	3,211.5	0.0	3,211.5	105,000.0	337.2	0.5	0.2	0.8			
Maximum:	4,404.6	76.3	4,404.6	105,000.0	462.5	0.6	0.3	0.9			
%SI	41.67	41.67	41.67	0.00	41.67	41.67	41.67	41.67			

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2	
	GasFlow, _CT, 100scfh		GasFlow, _DB, 100scfh		GasFlowTotal, 100scfh		GCVGas, BtuPer100scf		HI, MBtuPerHr		> 4.73 PM10_Norm, LbPerHr		> 1 SO2_Norm, LbPerHr		> 1.8 VOC_Norm, LbPerHr			
	1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)	
05/08/2025 00:00	0.0		0.0		0.0		105,000.0		0.0		0.0		0.0		0.0		0.0	
05/08/2025 01:00	0.0		0.0		0.0		105,000.0		0.0		0.0		0.0		0.0		0.0	
05/08/2025 02:00	0.0		0.0		0.0		105,000.0		0.0		0.0		0.0		0.0		0.0	
05/08/2025 03:00	0.0		0.0		0.0		105,000.0		0.0		0.0		0.0		0.0		0.0	
05/08/2025 04:00	0.0		0.0		0.0		105,000.0		0.0		0.0		0.0		0.0		0.0	
05/08/2025 05:00	0.0		0.0		0.0		105,000.0		0.0		0.0		0.0		0.0		0.0	
05/08/2025 06:00	0.0		0.0		0.0		105,000.0		0.0		0.0		0.0		0.0		0.0	
05/08/2025 07:00	0.0		0.0		0.0		105,000.0		0.0		0.0		0.0		0.0		0.0	
05/08/2025 08:00	0.0		0.0		0.0		105,000.0		0.0		0.0		0.0		0.0		0.0	
05/08/2025 09:00	0.0		0.0		0.0		105,000.0		0.0		0.0		0.0		0.0		0.0	
05/08/2025 10:00	0.0		0.0		0.0		105,000.0		0.0		0.0		0.0		0.0		0.0	
05/08/2025 11:00	0.0		0.0		0.0		105,000.0		0.0		0.0		0.0		0.0		0.0	
05/08/2025 12:00	0.0		0.0		0.0		105,000.0		0.0		0.0		0.0		0.0		0.0	
05/08/2025 13:00	0.0		0.0		0.0		105,000.0		0.0		0.0		0.0		0.0		0.0	
05/08/2025 14:00	0.0		0.0		0.0		105,000.0		0.0		0.0		0.0		0.0		0.0	
05/08/2025 15:00	0.0		0.0		0.0		105,000.0		0.0		0.0		0.0		0.0		0.0	
05/08/2025 16:00	0.0		0.0		0.0		105,000.0		0.0		0.0		0.0		0.0		0.0	
05/08/2025 17:00	0.0		0.0		0.0		105,000.0		0.0		0.0		0.0		0.0		0.0	
05/08/2025 18:00	0.0		0.0		0.0		105,000.0		0.0		0.0		0.0		0.0		0.0	
05/08/2025 19:00	0.0		0.0		0.0		105,000.0		0.0		0.0		0.0		0.0		0.0	
05/08/2025 20:00	0.0		0.0		0.0		105,000.0		0.0		0.0		0.0		0.0		0.0	
05/08/2025 21:00	0.0		0.0		0.0		105,000.0		0.0		0.0		0.0		0.0		0.0	
05/08/2025 22:00	0.0		0.0		0.0		105,000.0		0.0		0.0		0.0		0.0		0.0	
05/08/2025 23:00	0.0		0.0		0.0		105,000.0		0.0		0.0		0.0		0.0		0.0	
Average/Sum#:	0.0		0.0		0.0		105,000.0		0.0		0.0		0.0		0.0		0.0	
Minimum:	0.0		0.0		0.0		105,000.0		0.0		0.0		0.0		0.0		0.0	
Maximum:	0.0		0.0		0.0		105,000.0		0.0		0.0		0.0		0.0		0.0	
%SI	100.00		100.00		100.00		0.00		100.00		100.00		100.00		100.00		100.00	

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/09/2025 00:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
05/09/2025 01:00	2,775.4	0.0	2,775.4	105,000.0	291.4	0.0	0.0	0.0
05/09/2025 02:00	4,283.0	0.0	4,283.0	105,000.0	449.7	0.6	0.3	1.0
05/09/2025 03:00	4,519.0	0.0	4,519.0	105,000.0	474.5	0.6	0.3	0.9
05/09/2025 04:00	4,517.0	0.0	4,517.0	105,000.0	474.3	0.6	0.3	0.9
05/09/2025 05:00	4,025.2	0.0	4,025.2	105,000.0	422.6	0.5	0.3	0.8
05/09/2025 06:00	3,919.7	0.3	3,919.7	105,000.0	411.6	0.5	0.2	0.8
05/09/2025 07:00	3,672.6	35.2	3,672.6	105,000.0	385.6	0.5	0.2	0.8
05/09/2025 08:00	3,691.8	49.8	3,691.8	105,000.0	387.6	0.5	0.2	0.8
05/09/2025 09:00	3,686.4	17.4	3,686.4	105,000.0	387.1	0.5	0.2	0.8
05/09/2025 10:00	3,662.8	13.8	3,662.8	105,000.0	384.6	0.5	0.2	0.8
05/09/2025 11:00	3,660.5	99.1	3,660.5	105,000.0	384.4	0.5	0.2	0.8
05/09/2025 12:00	3,655.6	108.5	3,655.6	105,000.0	383.8	0.5	0.2	0.8
05/09/2025 13:00	3,662.2	71.9	3,662.2	105,000.0	384.5	0.5	0.2	0.8
05/09/2025 14:00	3,734.8	24.9	3,734.8	105,000.0	392.2	0.5	0.2	0.8
05/09/2025 15:00	3,685.8	6.9	3,685.8	105,000.0	387.0	0.5	0.2	0.8
05/09/2025 16:00	3,909.6	19.0	3,909.6	105,000.0	410.5	0.5	0.2	0.8
05/09/2025 17:00	3,863.6	31.0	3,863.6	105,000.0	405.7	0.5	0.2	0.8
05/09/2025 18:00	3,994.7	16.1	3,994.7	105,000.0	419.4	0.5	0.3	0.8
05/09/2025 19:00	4,533.3	0.0	4,533.3	105,000.0	476.0	0.6	0.3	1.0
05/09/2025 20:00	4,521.8	0.0	4,521.8	105,000.0	474.8	0.6	0.3	1.0
05/09/2025 21:00	4,526.9	0.0	4,526.9	105,000.0	475.3	0.6	0.3	1.0
05/09/2025 22:00	4,519.4	0.0	4,519.4	105,000.0	474.5	0.6	0.3	0.9
05/09/2025 23:00	4,522.2	3.2	4,522.2	105,000.0	474.8	0.6	0.3	1.0
Average/Sum#:	3,980.1	21.6	3,980.1	105,000.0	417.9	0.5	0.2	0.9
Minimum:	2,775.4	0.0	2,775.4	105,000.0	291.4	0.5	0.2	0.8
Maximum:	4,533.3	108.5	4,533.3	105,000.0	476.0	0.6	0.3	1.0
%SI	4.17	4.17	4.17	0.00	4.17	8.33	8.33	8.33

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/10/2025 00:00	4,532.8	0.1	4,532.8	105,000.0	475.9	0.6	0.3	1.0
05/10/2025 01:00	3,874.4	0.0	3,874.4	105,000.0	406.8	0.5	0.2	0.8
05/10/2025 02:00	3,747.0	0.0	3,747.0	105,000.0	393.4	0.5	0.2	0.8
05/10/2025 03:00	3,832.9	0.0	3,832.9	105,000.0	402.5	0.5	0.2	0.8
05/10/2025 04:00	3,680.5	0.0	3,680.5	105,000.0	386.5	0.5	0.2	0.8
05/10/2025 05:00	3,688.5	0.0	3,688.5	105,000.0	387.3	0.5	0.2	0.8
05/10/2025 06:00	3,701.3	0.7	3,701.3	105,000.0	388.6	0.5	0.2	0.8
05/10/2025 07:00	3,664.9	19.9	3,664.9	105,000.0	384.8	0.5	0.2	0.8
05/10/2025 08:00	3,661.3	72.9	3,661.3	105,000.0	384.4	0.5	0.2	0.8
05/10/2025 09:00	3,663.7	36.1	3,663.7	105,000.0	384.7	0.5	0.2	0.8
05/10/2025 10:00	3,666.3	20.4	3,666.3	105,000.0	385.0	0.5	0.2	0.8
05/10/2025 11:00	3,667.5	105.0	3,667.5	105,000.0	385.1	0.5	0.2	0.8
05/10/2025 12:00	3,655.4	116.6	3,655.4	105,000.0	383.8	0.5	0.2	0.8
05/10/2025 13:00	3,646.2	70.7	3,646.2	105,000.0	382.9	0.5	0.2	0.8
05/10/2025 14:00	3,644.9	21.2	3,644.9	105,000.0	382.7	0.5	0.2	0.8
05/10/2025 15:00	3,646.5	8.4	3,646.5	105,000.0	382.9	0.5	0.2	0.8
05/10/2025 16:00	3,675.2	47.9	3,675.2	105,000.0	385.9	0.5	0.2	0.8
05/10/2025 17:00	3,917.9	46.7	3,917.9	105,000.0	411.4	0.5	0.2	0.8
05/10/2025 18:00	4,572.5	22.6	4,572.5	105,000.0	480.1	0.6	0.3	1.0
05/10/2025 19:00	4,185.6	0.0	4,185.6	105,000.0	439.5	0.5	0.3	0.9
05/10/2025 20:00	4,328.5	10.9	4,329.4	105,000.0	454.6	0.5	0.3	0.9
05/10/2025 21:00	4,527.8	0.0	4,527.8	105,000.0	475.4	0.6	0.3	1.0
05/10/2025 22:00	4,516.0	0.0	4,516.0	105,000.0	474.2	0.6	0.3	0.9
05/10/2025 23:00	4,096.0	0.0	4,096.0	105,000.0	430.1	0.5	0.3	0.9
Average/Sum#:	3,908.1	25.0	3,908.1	105,000.0	410.4	0.5	0.2	0.8
Minimum:	3,644.9	0.0	3,644.9	105,000.0	382.7	0.5	0.2	0.8
Maximum:	4,572.5	116.6	4,572.5	105,000.0	480.1	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/11/2025 00:00	4,165.0	0.0	4,165.0	105,000.0	437.3	0.5	0.3	0.9
05/11/2025 01:00	3,817.9	0.0	3,817.9	105,000.0	400.9	0.5	0.2	0.8
05/11/2025 02:00	3,676.7	0.0	3,676.7	105,000.0	386.1	0.5	0.2	0.8
05/11/2025 03:00	3,677.2	0.0	3,677.2	105,000.0	386.1	0.5	0.2	0.8
05/11/2025 04:00	3,685.0	0.0	3,685.0	105,000.0	386.9	0.5	0.2	0.8
05/11/2025 05:00	3,711.4	0.0	3,711.4	105,000.0	389.7	0.5	0.2	0.8
05/11/2025 06:00	3,726.1	0.0	3,726.1	105,000.0	391.2	0.5	0.2	0.8
05/11/2025 07:00	3,728.0	0.4	3,728.0	105,000.0	391.4	0.5	0.2	0.8
05/11/2025 08:00	3,735.4	14.7	3,735.4	105,000.0	392.2	0.5	0.2	0.8
05/11/2025 09:00	3,721.3	16.3	3,721.3	105,000.0	390.7	0.5	0.2	0.8
05/11/2025 10:00	3,674.1	7.9	3,674.1	105,000.0	385.8	0.5	0.2	0.8
05/11/2025 11:00	3,670.1	87.0	3,670.1	105,000.0	385.4	0.5	0.2	0.8
05/11/2025 12:00	3,673.1	88.4	3,673.1	105,000.0	385.7	0.5	0.2	0.8
05/11/2025 13:00	3,696.1	49.4	3,696.1	105,000.0	388.1	0.5	0.2	0.8
05/11/2025 14:00	3,691.5	0.8	3,691.5	105,000.0	387.6	0.5	0.2	0.8
05/11/2025 15:00	3,681.9	0.0	3,681.9	105,000.0	386.6	0.5	0.2	0.8
05/11/2025 16:00	3,675.9	0.0	3,675.9	105,000.0	386.0	0.5	0.2	0.8
05/11/2025 17:00	3,953.0	0.0	3,953.0	105,000.0	415.1	0.5	0.2	0.8
05/11/2025 18:00	3,700.9	0.0	3,700.9	105,000.0	388.6	0.5	0.2	0.8
05/11/2025 19:00	3,864.7	0.0	3,864.7	105,000.0	405.8	0.5	0.2	0.8
05/11/2025 20:00	3,781.2	0.0	3,781.2	105,000.0	397.0	0.5	0.2	0.8
05/11/2025 21:00	3,748.5	0.0	3,748.5	105,000.0	393.6	0.5	0.2	0.8
05/11/2025 22:00	3,754.6	0.0	3,754.6	105,000.0	394.2	0.5	0.2	0.8
05/11/2025 23:00	3,689.1	0.0	3,689.1	105,000.0	387.4	0.5	0.2	0.8
Average/Sum#:	3,745.8	11.0	3,745.8	105,000.0	393.3	0.5	0.2	0.8
Minimum:	3,670.1	0.0	3,670.1	105,000.0	385.4	0.5	0.2	0.8
Maximum:	4,165.0	88.4	4,165.0	105,000.0	437.3	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/12/2025 00:00	3,716.2	0.0	3,716.2	105,000.0	390.2	0.5	0.2	0.8
05/12/2025 01:00	3,730.5	0.0	3,730.5	105,000.0	391.7	0.5	0.2	0.8
05/12/2025 02:00	3,723.2	0.0	3,723.2	105,000.0	390.9	0.5	0.2	0.8
05/12/2025 03:00	3,721.3	0.0	3,721.3	105,000.0	390.7	0.5	0.2	0.8
05/12/2025 04:00	3,709.5	0.0	3,709.5	105,000.0	389.5	0.5	0.2	0.8
05/12/2025 05:00	3,711.9	0.0	3,711.9	105,000.0	389.7	0.5	0.2	0.8
05/12/2025 06:00	3,710.0	0.0	3,710.0	105,000.0	389.6	0.5	0.2	0.8
05/12/2025 07:00	3,704.0	0.0	3,704.0	105,000.0	388.9	0.5	0.2	0.8
05/12/2025 08:00	3,689.8	0.0	3,689.8	105,000.0	387.4	0.5	0.2	0.8
05/12/2025 09:00	3,732.6	0.0	3,732.6	105,000.0	391.9	0.5	0.2	0.8
05/12/2025 10:00	3,702.2	0.0	3,702.2	105,000.0	388.7	0.5	0.2	0.8
05/12/2025 11:00	3,679.7	9.9	3,679.7	105,000.0	386.4	0.5	0.2	0.8
05/12/2025 12:00	3,680.4	33.6	3,680.4	105,000.0	386.4	0.5	0.2	0.8
05/12/2025 13:00	3,679.0	1.0	3,679.0	105,000.0	386.3	0.5	0.2	0.8
05/12/2025 14:00	3,680.5	0.0	3,680.5	105,000.0	386.5	0.5	0.2	0.8
05/12/2025 15:00	3,678.4	0.0	3,678.4	105,000.0	386.2	0.5	0.2	0.8
05/12/2025 16:00	3,679.2	0.0	3,679.2	105,000.0	386.3	0.5	0.2	0.8
05/12/2025 17:00	3,690.7	0.0	3,690.7	105,000.0	387.5	0.5	0.2	0.8
05/12/2025 18:00	3,675.3	0.0	3,675.3	105,000.0	385.9	0.5	0.2	0.8
05/12/2025 19:00	3,667.7	0.0	3,667.7	105,000.0	385.1	0.5	0.2	0.8
05/12/2025 20:00	3,667.0	0.0	3,667.0	105,000.0	385.0	0.5	0.2	0.8
05/12/2025 21:00	3,669.7	0.0	3,669.7	105,000.0	385.3	0.5	0.2	0.8
05/12/2025 22:00	3,664.5	0.0	3,664.5	105,000.0	384.8	0.5	0.2	0.8
05/12/2025 23:00	3,666.4	0.0	3,666.4	105,000.0	385.0	0.5	0.2	0.8
Average/Sum#:	3,692.9	1.9	3,692.9	105,000.0	387.7	0.5	0.2	0.8
Minimum:	3,664.5	0.0	3,664.5	105,000.0	384.8	0.5	0.2	0.8
Maximum:	3,732.6	33.6	3,732.6	105,000.0	391.9	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/13/2025 00:00	3,686.5	0.0	3,686.5	105,000.0	387.1	0.5	0.2	0.8			
05/13/2025 01:00	3,709.3	0.0	3,709.3	105,000.0	389.5	0.5	0.2	0.8			
05/13/2025 02:00	3,691.7	0.0	3,691.7	105,000.0	387.6	0.5	0.2	0.8			
05/13/2025 03:00	3,690.7	0.0	3,690.7	105,000.0	387.5	0.5	0.2	0.8			
05/13/2025 04:00	3,692.8	0.0	3,692.8	105,000.0	387.7	0.5	0.2	0.8			
05/13/2025 05:00	3,690.9	0.0	3,690.9	105,000.0	387.5	0.5	0.2	0.8			
05/13/2025 06:00	3,684.6	0.0	3,684.6	105,000.0	386.9	0.5	0.2	0.8			
05/13/2025 07:00	3,679.8	0.0	3,679.8	105,000.0	386.4	0.5	0.2	0.8			
05/13/2025 08:00	3,687.4	0.1	3,687.4	105,000.0	387.2	0.5	0.2	0.8			
05/13/2025 09:00	3,684.4	0.1	3,684.4	105,000.0	386.9	0.5	0.2	0.8			
05/13/2025 10:00	3,683.7	0.0	3,683.7	105,000.0	386.8	0.5	0.2	0.8			
05/13/2025 11:00	3,695.2	44.3	3,695.2	105,000.0	388.0	0.5	0.2	0.8			
05/13/2025 12:00	3,698.3	24.9	3,698.3	105,000.0	388.3	0.5	0.2	0.8			
05/13/2025 13:00	3,690.7	22.1	3,690.7	105,000.0	387.5	0.5	0.2	0.8			
05/13/2025 14:00	3,693.6	0.0	3,693.6	105,000.0	387.8	0.5	0.2	0.8			
05/13/2025 15:00	3,680.1	0.0	3,680.1	105,000.0	386.4	0.5	0.2	0.8			
05/13/2025 16:00	3,675.5	0.0	3,675.5	105,000.0	385.9	0.5	0.2	0.8			
05/13/2025 17:00	3,679.7	0.0	3,679.7	105,000.0	386.4	0.5	0.2	0.8			
05/13/2025 18:00	3,680.5	0.0	3,680.5	105,000.0	386.5	0.5	0.2	0.8			
05/13/2025 19:00	3,687.5	0.0	3,687.5	105,000.0	387.2	0.5	0.2	0.8			
05/13/2025 20:00	3,685.6	0.0	3,685.6	105,000.0	387.0	0.5	0.2	0.8			
05/13/2025 21:00	3,688.0	0.0	3,688.0	105,000.0	387.2	0.5	0.2	0.8			
05/13/2025 22:00	3,688.6	0.0	3,688.6	105,000.0	387.3	0.5	0.2	0.8			
05/13/2025 23:00	3,694.4	0.0	3,694.4	105,000.0	387.9	0.5	0.2	0.8			
Average/Sum#:	3,688.3	3.8	3,688.3	105,000.0	387.3	0.5	0.2	0.8			
Minimum:	3,675.5	0.0	3,675.5	105,000.0	385.9	0.5	0.2	0.8			
Maximum:	3,709.3	44.3	3,709.3	105,000.0	389.5	0.5	0.2	0.8			
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/14/2025 00:00	3,692.2	0.0	3,692.2	105,000.0	387.7	0.5	0.2	0.8
05/14/2025 01:00	3,694.5	0.0	3,694.5	105,000.0	387.9	0.5	0.2	0.8
05/14/2025 02:00	3,691.4	0.0	3,691.4	105,000.0	387.6	0.5	0.2	0.8
05/14/2025 03:00	3,699.6	0.0	3,699.6	105,000.0	388.5	0.5	0.2	0.8
05/14/2025 04:00	3,745.7	0.0	3,745.7	105,000.0	393.3	0.5	0.2	0.8
05/14/2025 05:00	3,973.2	0.0	3,973.2	105,000.0	417.2	0.5	0.3	0.8
05/14/2025 06:00	3,715.3	0.0	3,715.3	105,000.0	390.1	0.5	0.2	0.8
05/14/2025 07:00	3,728.9	5.5	3,728.9	105,000.0	391.5	0.5	0.2	0.8
05/14/2025 08:00	3,725.8	4.9	3,725.8	105,000.0	391.2	0.5	0.2	0.8
05/14/2025 09:00	3,722.6	1.8	3,722.6	105,000.0	390.9	0.5	0.2	0.8
05/14/2025 10:00	3,722.1	0.0	3,722.1	105,000.0	390.8	0.5	0.2	0.8
05/14/2025 11:00	3,727.3	73.5	3,727.3	105,000.0	391.4	0.5	0.2	0.8
05/14/2025 12:00	3,722.3	80.0	3,722.3	105,000.0	390.8	0.5	0.2	0.8
05/14/2025 13:00	3,720.9	13.3	3,720.9	105,000.0	390.7	0.5	0.2	0.8
05/14/2025 14:00	3,716.2	0.0	3,716.2	105,000.0	390.2	0.5	0.2	0.8
05/14/2025 15:00	3,722.7	0.0	3,722.7	105,000.0	390.9	0.5	0.2	0.8
05/14/2025 16:00	3,731.2	0.0	3,731.2	105,000.0	391.8	0.5	0.2	0.8
05/14/2025 17:00	3,732.4	0.0	3,732.4	105,000.0	391.9	0.5	0.2	0.8
05/14/2025 18:00	3,730.5	0.0	3,730.5	105,000.0	391.7	0.5	0.2	0.8
05/14/2025 19:00	3,725.0	0.0	3,725.0	105,000.0	391.1	0.5	0.2	0.8
05/14/2025 20:00	3,730.1	0.0	3,730.1	105,000.0	391.7	0.5	0.2	0.8
05/14/2025 21:00	3,722.9	0.0	3,722.9	105,000.0	390.9	0.5	0.2	0.8
05/14/2025 22:00	3,726.0	0.0	3,726.0	105,000.0	391.2	0.5	0.2	0.8
05/14/2025 23:00	3,729.3	0.0	3,729.3	105,000.0	391.6	0.5	0.2	0.8
Average/Sum#:	3,731.2	7.5	3,731.2	105,000.0	391.8	0.5	0.2	0.8
Minimum:	3,691.4	0.0	3,691.4	105,000.0	387.6	0.5	0.2	0.8
Maximum:	3,973.2	80.0	3,973.2	105,000.0	417.2	0.5	0.3	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/15/2025 00:00	3,723.2	0.0	3,723.2	105,000.0	390.9	0.5	0.2	0.8			
05/15/2025 01:00	3,718.1	0.0	3,718.1	105,000.0	390.4	0.5	0.2	0.8			
05/15/2025 02:00	3,717.5	0.0	3,717.5	105,000.0	390.3	0.5	0.2	0.8			
05/15/2025 03:00	3,716.0	0.0	3,716.0	105,000.0	390.2	0.5	0.2	0.8			
05/15/2025 04:00	3,709.8	0.0	3,709.8	105,000.0	389.5	0.5	0.2	0.8			
05/15/2025 05:00	3,680.9	0.0	3,680.9	105,000.0	386.5	0.5	0.2	0.8			
05/15/2025 06:00	3,664.3	0.0	3,664.3	105,000.0	384.8	0.5	0.2	0.8			
05/15/2025 07:00	3,663.2	2.3	3,663.2	105,000.0	384.6	0.5	0.2	0.8			
05/15/2025 08:00	3,660.0	37.0	3,660.0	105,000.0	384.3	0.5	0.2	0.8			
05/15/2025 09:00	3,670.8	21.6	3,670.8	105,000.0	385.4	0.5	0.2	0.8			
05/15/2025 10:00	3,676.9	0.0	3,676.9	105,000.0	386.1	0.5	0.2	0.8			
05/15/2025 11:00	3,653.1	77.0	3,653.1	105,000.0	383.6	0.5	0.2	0.8			
05/15/2025 12:00	3,647.9	82.9	3,647.9	105,000.0	383.0	0.5	0.2	0.8			
05/15/2025 13:00	3,657.5	48.4	3,657.5	105,000.0	384.0	0.5	0.2	0.8			
05/15/2025 14:00	3,664.0	0.0	3,664.0	105,000.0	384.7	0.5	0.2	0.8			
05/15/2025 15:00	3,655.8	0.0	3,655.8	105,000.0	383.9	0.5	0.2	0.8			
05/15/2025 16:00	3,651.0	0.0	3,651.0	105,000.0	383.4	0.5	0.2	0.8			
05/15/2025 17:00	3,772.6	2.2	3,772.6	105,000.0	396.1	0.5	0.2	0.8			
05/15/2025 18:00	3,659.0	0.0	3,659.0	105,000.0	384.2	0.5	0.2	0.8			
05/15/2025 19:00	3,654.4	0.0	3,654.4	105,000.0	383.7	0.5	0.2	0.8			
05/15/2025 20:00	3,678.9	0.0	3,678.9	105,000.0	386.3	0.5	0.2	0.8			
05/15/2025 21:00	3,693.8	0.0	3,693.8	105,000.0	387.8	0.5	0.2	0.8			
05/15/2025 22:00	3,694.6	0.0	3,694.6	105,000.0	387.9	0.5	0.2	0.8			
05/15/2025 23:00	3,690.1	0.0	3,690.1	105,000.0	387.5	0.5	0.2	0.8			
Average/Sum#:	3,682.2	11.3	3,682.2	105,000.0	386.6	0.5	0.2	0.8			
Minimum:	3,647.9	0.0	3,647.9	105,000.0	383.0	0.5	0.2	0.8			
Maximum:	3,772.6	82.9	3,772.6	105,000.0	396.1	0.5	0.2	0.8			
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/16/2025 00:00	3,689.6	0.0	3,689.6	105,000.0	387.4	0.5	0.2	0.2	0.8	0.8
05/16/2025 01:00	3,689.9	0.0	3,689.9	105,000.0	387.4	0.5	0.2	0.2	0.8	0.8
05/16/2025 02:00	3,695.5	0.0	3,695.5	105,000.0	388.0	0.5	0.2	0.2	0.8	0.8
05/16/2025 03:00	3,686.2	0.0	3,686.2	105,000.0	387.1	0.5	0.2	0.2	0.8	0.8
05/16/2025 04:00	3,684.9	0.0	3,684.9	105,000.0	386.9	0.5	0.2	0.2	0.8	0.8
05/16/2025 05:00	3,684.0	0.0	3,684.0	105,000.0	386.8	0.5	0.2	0.2	0.8	0.8
05/16/2025 06:00	3,685.5	0.0	3,685.5	105,000.0	387.0	0.5	0.2	0.2	0.8	0.8
05/16/2025 07:00	3,693.9	1.4	3,693.9	105,000.0	387.9	0.5	0.2	0.2	0.8	0.8
05/16/2025 08:00	3,700.0	38.4	3,700.0	105,000.0	388.5	0.5	0.2	0.2	0.8	0.8
05/16/2025 09:00	3,706.3	18.8	3,706.3	105,000.0	389.2	0.5	0.2	0.2	0.8	0.8
05/16/2025 10:00	3,709.5	0.1	3,709.5	105,000.0	389.5	0.5	0.2	0.2	0.8	0.8
05/16/2025 11:00	3,748.9	77.3	3,748.9	105,000.0	393.6	0.5	0.2	0.2	0.8	0.8
05/16/2025 12:00	4,065.3	90.1	4,065.3	105,000.0	426.9	0.5	0.3	0.3	0.9	0.9
05/16/2025 13:00	4,507.8	57.2	4,507.8	105,000.0	473.3	0.6	0.3	0.3	1.0	1.0
05/16/2025 14:00	4,282.3	0.0	4,282.3	105,000.0	449.6	0.5	0.3	0.3	0.9	0.9
05/16/2025 15:00	3,688.7	0.0	3,688.7	105,000.0	387.3	0.5	0.2	0.2	0.8	0.8
05/16/2025 16:00	3,691.0	0.1	3,691.0	105,000.0	387.6	0.5	0.2	0.2	0.8	0.8
05/16/2025 17:00	3,952.1	2.4	3,952.1	105,000.0	415.0	0.5	0.2	0.2	0.8	0.8
05/16/2025 18:00	4,002.0	0.1	4,002.0	105,000.0	420.2	0.5	0.3	0.3	0.8	0.8
05/16/2025 19:00	3,657.8	0.0	3,657.8	105,000.0	384.1	0.5	0.2	0.2	0.8	0.8
05/16/2025 20:00	3,682.9	0.0	3,682.9	105,000.0	386.7	0.5	0.2	0.2	0.8	0.8
05/16/2025 21:00	3,729.7	0.0	3,729.7	105,000.0	391.6	0.5	0.2	0.2	0.8	0.8
05/16/2025 22:00	4,374.4	0.0	4,374.4	105,000.0	459.3	0.6	0.3	0.3	0.9	0.9
05/16/2025 23:00	4,606.8	0.0	4,606.8	105,000.0	483.7	0.6	0.3	0.3	1.0	1.0
Average/Sum#:	3,859.0	11.9	3,859.0	105,000.0	405.2	0.5	0.2	0.2	0.8	0.8
Minimum:	3,657.8	0.0	3,657.8	105,000.0	384.1	0.5	0.2	0.2	0.8	0.8
Maximum:	4,606.8	90.1	4,606.8	105,000.0	483.7	0.6	0.3	0.3	1.0	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/17/2025 00:00	4,369.6	0.0	4,369.6	105,000.0	458.8	0.6	0.3	0.9
05/17/2025 01:00	3,689.5	0.0	3,689.5	105,000.0	387.4	0.5	0.2	0.8
05/17/2025 02:00	3,703.9	0.0	3,703.9	105,000.0	388.9	0.5	0.2	0.8
05/17/2025 03:00	3,705.7	0.0	3,705.7	105,000.0	389.1	0.5	0.2	0.8
05/17/2025 04:00	3,703.3	0.0	3,703.3	105,000.0	388.8	0.5	0.2	0.8
05/17/2025 05:00	3,783.8	0.0	3,783.8	105,000.0	397.3	0.5	0.2	0.8
05/17/2025 06:00	4,309.3	0.0	4,309.3	105,000.0	452.5	0.5	0.3	0.9
05/17/2025 07:00	4,090.7	0.0	4,090.7	105,000.0	429.5	0.5	0.3	0.9
05/17/2025 08:00	3,690.2	2.2	3,690.2	105,000.0	387.5	0.5	0.2	0.8
05/17/2025 09:00	3,661.3	13.9	3,661.3	105,000.0	384.4	0.5	0.2	0.8
05/17/2025 10:00	3,657.5	0.0	3,657.5	105,000.0	384.0	0.5	0.2	0.8
05/17/2025 11:00	3,654.2	53.6	3,654.2	105,000.0	383.7	0.5	0.2	0.8
05/17/2025 12:00	3,652.4	74.2	3,652.4	105,000.0	383.5	0.5	0.2	0.8
05/17/2025 13:00	3,650.8	46.5	3,650.8	105,000.0	383.3	0.5	0.2	0.8
05/17/2025 14:00	3,646.5	0.0	3,646.5	105,000.0	382.9	0.5	0.2	0.8
05/17/2025 15:00	3,645.6	0.0	3,645.6	105,000.0	382.8	0.5	0.2	0.8
05/17/2025 16:00	3,647.4	0.0	3,647.4	105,000.0	383.0	0.5	0.2	0.8
05/17/2025 17:00	3,701.7	0.0	3,701.7	105,000.0	388.7	0.5	0.2	0.8
05/17/2025 18:00	3,656.7	0.0	3,656.7	105,000.0	384.0	0.5	0.2	0.8
05/17/2025 19:00	3,658.3	0.0	3,658.3	105,000.0	384.1	0.5	0.2	0.8
05/17/2025 20:00	3,662.5	0.0	3,662.5	105,000.0	384.6	0.5	0.2	0.8
05/17/2025 21:00	3,662.6	0.0	3,662.6	105,000.0	384.6	0.5	0.2	0.8
05/17/2025 22:00	3,667.1	0.0	3,667.1	105,000.0	385.0	0.5	0.2	0.8
05/17/2025 23:00	3,668.1	0.0	3,668.1	105,000.0	385.2	0.5	0.2	0.8
Average/Sum#:	3,747.4	7.9	3,747.4	105,000.0	393.5	0.5	0.2	0.8
Minimum:	3,645.6	0.0	3,645.6	105,000.0	382.8	0.5	0.2	0.8
Maximum:	4,369.6	74.2	4,369.6	105,000.0	458.8	0.6	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/18/2025 00:00	3,670.4	0.0	3,670.4	105,000.0	385.4	0.5	0.2	0.8
05/18/2025 01:00	3,672.0	0.0	3,672.0	105,000.0	385.6	0.5	0.2	0.8
05/18/2025 02:00	3,671.2	0.0	3,671.2	105,000.0	385.5	0.5	0.2	0.8
05/18/2025 03:00	3,673.7	0.0	3,673.7	105,000.0	385.7	0.5	0.2	0.8
05/18/2025 04:00	3,674.2	0.0	3,674.2	105,000.0	385.8	0.5	0.2	0.8
05/18/2025 05:00	3,676.6	0.0	3,676.6	105,000.0	386.0	0.5	0.2	0.8
05/18/2025 06:00	3,675.2	0.0	3,675.2	105,000.0	385.9	0.5	0.2	0.8
05/18/2025 07:00	3,672.1	0.0	3,672.1	105,000.0	385.6	0.5	0.2	0.8
05/18/2025 08:00	3,668.2	11.7	3,668.2	105,000.0	385.2	0.5	0.2	0.8
05/18/2025 09:00	3,663.9	0.0	3,663.9	105,000.0	384.7	0.5	0.2	0.8
05/18/2025 10:00	3,657.5	0.0	3,657.5	105,000.0	384.0	0.5	0.2	0.8
05/18/2025 11:00	3,653.5	47.6	3,653.5	105,000.0	383.6	0.5	0.2	0.8
05/18/2025 12:00	3,647.4	61.4	3,647.4	105,000.0	383.0	0.5	0.2	0.8
05/18/2025 13:00	3,646.5	30.7	3,646.5	105,000.0	382.9	0.5	0.2	0.8
05/18/2025 14:00	3,646.8	0.0	3,646.8	105,000.0	382.9	0.5	0.2	0.8
05/18/2025 15:00	3,641.0	0.0	3,641.0	105,000.0	382.3	0.5	0.2	0.8
05/18/2025 16:00	3,641.4	0.0	3,641.4	105,000.0	382.3	0.5	0.2	0.8
05/18/2025 17:00	3,642.3	0.0	3,642.3	105,000.0	382.4	0.5	0.2	0.8
05/18/2025 18:00	3,942.2	0.0	3,942.2	105,000.0	413.9	0.5	0.2	0.8
05/18/2025 19:00	3,654.5	0.0	3,654.5	105,000.0	383.7	0.5	0.2	0.8
05/18/2025 20:00	3,653.0	0.0	3,653.0	105,000.0	383.6	0.5	0.2	0.8
05/18/2025 21:00	3,658.1	0.0	3,658.1	105,000.0	384.1	0.5	0.2	0.8
05/18/2025 22:00	3,661.9	0.0	3,661.9	105,000.0	384.5	0.5	0.2	0.8
05/18/2025 23:00	3,663.5	0.0	3,663.5	105,000.0	384.7	0.5	0.2	0.8
Average/Sum#:	3,672.0	6.3	3,672.0	105,000.0	385.6	0.5	0.2	0.8
Minimum:	3,641.0	0.0	3,641.0	105,000.0	382.3	0.5	0.2	0.8
Maximum:	3,942.2	61.4	3,942.2	105,000.0	413.9	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/19/2025 00:00	3,664.2	0.0	3,664.2	105,000.0	384.7	0.5	0.2	0.8
05/19/2025 01:00	3,665.1	0.0	3,665.1	105,000.0	384.8	0.5	0.2	0.8
05/19/2025 02:00	3,716.8	0.0	3,716.8	105,000.0	390.3	0.5	0.2	0.8
05/19/2025 03:00	4,443.9	0.0	4,443.9	105,000.0	466.6	0.6	0.3	0.9
05/19/2025 04:00	3,914.9	0.0	3,914.9	105,000.0	411.1	0.5	0.2	0.8
05/19/2025 05:00	3,673.3	0.0	3,673.3	105,000.0	385.7	0.5	0.2	0.8
05/19/2025 06:00	4,126.9	0.0	4,126.9	105,000.0	433.3	0.5	0.3	0.9
05/19/2025 07:00	4,853.0	1,139.3	5,821.4	105,000.0	611.2	0.8	0.4	1.3
05/19/2025 08:00	4,869.5	1,401.5	6,271.0	105,000.0	658.5	0.8	0.4	1.3
05/19/2025 09:00	4,840.2	1,416.9	6,257.1	105,000.0	657.0	0.8	0.4	1.3
05/19/2025 10:00	4,813.2	1,474.9	6,288.1	105,000.0	660.3	0.8	0.4	1.3
05/19/2025 11:00	4,795.2	1,524.4	6,319.6	105,000.0	663.6	0.8	0.4	1.3
05/19/2025 12:00	4,779.1	1,565.8	6,344.9	105,000.0	666.2	0.8	0.4	1.3
05/19/2025 13:00	4,765.1	1,581.7	6,346.8	105,000.0	666.4	0.8	0.4	1.3
05/19/2025 14:00	4,754.8	1,578.5	6,333.3	105,000.0	665.0	0.8	0.4	1.3
05/19/2025 15:00	4,727.7	1,611.9	6,339.6	105,000.0	665.7	0.8	0.4	1.3
05/19/2025 16:00	4,719.0	1,608.9	6,327.9	105,000.0	664.4	0.8	0.4	1.3
05/19/2025 17:00	4,699.0	1,614.7	6,313.7	105,000.0	662.9	0.8	0.4	1.3
05/19/2025 18:00	4,713.7	1,484.6	6,198.3	105,000.0	650.8	0.8	0.4	1.3
05/19/2025 19:00	4,404.5	229.4	4,523.8	105,000.0	475.0	0.6	0.3	1.0
05/19/2025 20:00	3,658.5	0.0	3,658.5	105,000.0	384.1	0.5	0.2	0.8
05/19/2025 21:00	4,491.0	0.0	4,491.0	105,000.0	471.6	0.6	0.3	0.9
05/19/2025 22:00	4,558.4	0.0	4,558.4	105,000.0	478.6	0.6	0.3	1.0
05/19/2025 23:00	4,557.2	0.0	4,557.2	105,000.0	478.5	0.6	0.3	1.0
Average/Sum#:	4,425.2	759.7	5,173.2	105,000.0	543.2	0.7	0.3	1.1
Minimum:	3,658.5	0.0	3,658.5	105,000.0	384.1	0.5	0.2	0.8
Maximum:	4,869.5	1,614.7	6,346.8	105,000.0	666.4	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/20/2025 00:00	4,564.9	0.0	4,564.9	105,000.0	479.3	0.6	0.3	0.3	1.0	1.0
05/20/2025 01:00	4,555.9	0.0	4,555.9	105,000.0	478.4	0.6	0.3	0.3	1.0	1.0
05/20/2025 02:00	4,545.9	0.0	4,545.9	105,000.0	477.3	0.6	0.3	0.3	1.0	1.0
05/20/2025 03:00	4,648.5	82.8	4,670.9	105,000.0	490.4	0.6	0.3	0.3	1.0	1.0
05/20/2025 04:00	4,893.4	931.9	5,825.3	105,000.0	611.7	0.7	0.4	0.4	1.2	1.2
05/20/2025 05:00	4,901.1	1,281.9	6,183.0	105,000.0	649.2	0.8	0.4	0.4	1.3	1.3
05/20/2025 06:00	4,890.8	1,273.9	6,164.7	105,000.0	647.3	0.8	0.4	0.4	1.3	1.3
05/20/2025 07:00	4,877.4	1,262.7	6,140.1	105,000.0	644.7	0.8	0.4	0.4	1.3	1.3
05/20/2025 08:00	4,861.5	1,264.1	6,125.6	105,000.0	643.2	0.8	0.4	0.4	1.3	1.3
05/20/2025 09:00	4,827.5	1,261.6	6,089.1	105,000.0	639.4	0.8	0.4	0.4	1.3	1.3
05/20/2025 10:00	4,803.0	1,258.9	6,061.9	105,000.0	636.5	0.8	0.4	0.4	1.3	1.3
05/20/2025 11:00	4,803.5	1,262.8	6,066.3	105,000.0	637.0	0.8	0.4	0.4	1.3	1.3
05/20/2025 12:00	4,786.7	1,261.4	6,048.1	105,000.0	635.1	0.8	0.4	0.4	1.3	1.3
05/20/2025 13:00	4,768.4	1,263.5	6,031.9	105,000.0	633.3	0.8	0.4	0.4	1.3	1.3
05/20/2025 14:00	4,765.1	1,260.9	6,026.0	105,000.0	632.7	0.8	0.4	0.4	1.3	1.3
05/20/2025 15:00	4,759.2	1,258.1	6,017.3	105,000.0	631.8	0.8	0.4	0.4	1.3	1.3
05/20/2025 16:00	4,755.2	1,066.4	5,821.6	105,000.0	611.3	0.7	0.4	0.4	1.2	1.2
05/20/2025 17:00	4,753.9	541.0	5,294.9	105,000.0	556.0	0.7	0.3	0.3	1.1	1.1
05/20/2025 18:00	4,762.1	1,129.9	5,892.0	105,000.0	618.7	0.7	0.4	0.4	1.2	1.2
05/20/2025 19:00	4,769.4	1,288.8	6,058.2	105,000.0	636.1	0.8	0.4	0.4	1.3	1.3
05/20/2025 20:00	4,788.5	1,214.7	6,003.2	105,000.0	630.3	0.8	0.4	0.4	1.3	1.3
05/20/2025 21:00	4,817.1	1,690.1	6,507.2	105,000.0	683.3	0.8	0.4	0.4	1.4	1.4
05/20/2025 22:00	4,818.9	729.8	5,548.7	105,000.0	582.6	0.7	0.3	0.3	1.2	1.2
05/20/2025 23:00	4,598.1	2.0	4,598.1	105,000.0	482.8	0.6	0.3	0.3	1.0	1.0
Average/Sum#:	4,763.2	941.1	5,701.7	105,000.0	598.7	0.7	0.4	0.4	1.2	1.2
Minimum:	4,545.9	0.0	4,545.9	105,000.0	477.3	0.6	0.3	0.3	1.0	1.0
Maximum:	4,901.1	1,690.1	6,507.2	105,000.0	683.3	0.8	0.4	0.4	1.4	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/21/2025 00:00	4,219.5	0.0	4,219.5	105,000.0	443.0	0.5	0.3	0.3	0.9	0.9
05/21/2025 01:00	3,790.2	0.0	3,790.2	105,000.0	398.0	0.5	0.2	0.2	0.8	0.8
05/21/2025 02:00	3,707.4	0.0	3,707.4	105,000.0	389.3	0.5	0.2	0.2	0.8	0.8
05/21/2025 03:00	3,709.0	0.0	3,709.0	105,000.0	389.4	0.5	0.2	0.2	0.8	0.8
05/21/2025 04:00	3,707.0	0.0	3,707.0	105,000.0	389.2	0.5	0.2	0.2	0.8	0.8
05/21/2025 05:00	3,694.8	0.0	3,694.8	105,000.0	388.0	0.5	0.2	0.2	0.8	0.8
05/21/2025 06:00	3,695.3	1.5	3,695.3	105,000.0	388.0	0.5	0.2	0.2	0.8	0.8
05/21/2025 07:00	3,699.9	45.8	3,699.9	105,000.0	388.5	0.5	0.2	0.2	0.8	0.8
05/21/2025 08:00	3,690.6	72.9	3,690.6	105,000.0	387.5	0.5	0.2	0.2	0.8	0.8
05/21/2025 09:00	3,668.7	29.9	3,668.7	105,000.0	385.2	0.5	0.2	0.2	0.8	0.8
05/21/2025 10:00	3,666.0	18.5	3,666.0	105,000.0	384.9	0.5	0.2	0.2	0.8	0.8
05/21/2025 11:00	3,666.4	99.1	3,666.4	105,000.0	385.0	0.5	0.2	0.2	0.8	0.8
05/21/2025 12:00	3,666.6	106.0	3,666.6	105,000.0	385.0	0.5	0.2	0.2	0.8	0.8
05/21/2025 13:00	3,663.8	69.1	3,663.8	105,000.0	384.7	0.5	0.2	0.2	0.8	0.8
05/21/2025 14:00	3,664.4	26.8	3,664.4	105,000.0	384.8	0.5	0.2	0.2	0.8	0.8
05/21/2025 15:00	3,664.9	3.3	3,664.9	105,000.0	384.8	0.5	0.2	0.2	0.8	0.8
05/21/2025 16:00	3,660.1	18.2	3,660.1	105,000.0	384.3	0.5	0.2	0.2	0.8	0.8
05/21/2025 17:00	4,389.0	17.1	4,389.5	105,000.0	460.9	0.6	0.3	0.3	0.9	0.9
05/21/2025 18:00	3,968.4	16.8	3,968.4	105,000.0	416.7	0.5	0.3	0.3	0.8	0.8
05/21/2025 19:00	4,455.1	0.0	4,455.1	105,000.0	467.8	0.6	0.3	0.3	0.9	0.9
05/21/2025 20:00	4,181.4	0.0	4,181.4	105,000.0	439.0	0.5	0.3	0.3	0.9	0.9
05/21/2025 21:00	3,814.0	0.0	3,814.0	105,000.0	400.5	0.5	0.2	0.2	0.8	0.8
05/21/2025 22:00	3,902.3	0.0	3,902.3	105,000.0	409.7	0.5	0.2	0.2	0.8	0.8
05/21/2025 23:00	3,681.8	0.0	3,681.8	105,000.0	386.6	0.5	0.2	0.2	0.8	0.8
Average/Sum#:	3,817.8	21.9	3,817.8	105,000.0	400.9	0.5	0.2	0.2	0.8	0.8
Minimum:	3,660.1	0.0	3,660.1	105,000.0	384.3	0.5	0.2	0.2	0.8	0.8
Maximum:	4,455.1	106.0	4,455.1	105,000.0	467.8	0.6	0.3	0.3	0.9	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/22/2025 00:00	3,695.3	0.0	3,695.3	105,000.0	388.0	0.5	0.2	0.2	0.8	0.8	0.8
05/22/2025 01:00	3,695.9	0.0	3,695.9	105,000.0	388.1	0.5	0.2	0.2	0.8	0.8	0.8
05/22/2025 02:00	3,691.5	0.0	3,691.5	105,000.0	387.6	0.5	0.2	0.2	0.8	0.8	0.8
05/22/2025 03:00	3,693.3	0.0	3,693.3	105,000.0	387.8	0.5	0.2	0.2	0.8	0.8	0.8
05/22/2025 04:00	3,702.0	0.0	3,702.0	105,000.0	388.7	0.5	0.2	0.2	0.8	0.8	0.8
05/22/2025 05:00	3,710.7	0.0	3,710.7	105,000.0	389.6	0.5	0.2	0.2	0.8	0.8	0.8
05/22/2025 06:00	3,688.4	0.0	3,688.4	105,000.0	387.3	0.5	0.2	0.2	0.8	0.8	0.8
05/22/2025 07:00	3,685.2	5.3	3,685.2	105,000.0	386.9	0.5	0.2	0.2	0.8	0.8	0.8
05/22/2025 08:00	3,689.6	49.2	3,689.6	105,000.0	387.4	0.5	0.2	0.2	0.8	0.8	0.8
05/22/2025 09:00	3,703.8	33.4	3,703.8	105,000.0	388.9	0.5	0.2	0.2	0.8	0.8	0.8
05/22/2025 10:00	3,675.9	30.1	3,675.9	105,000.0	386.0	0.5	0.2	0.2	0.8	0.8	0.8
05/22/2025 11:00	3,663.2	100.7	3,663.2	105,000.0	384.6	0.5	0.2	0.2	0.8	0.8	0.8
05/22/2025 12:00	3,655.4	108.2	3,655.4	105,000.0	383.8	0.5	0.2	0.2	0.8	0.8	0.8
05/22/2025 13:00	3,651.6	76.7	3,651.6	105,000.0	383.4	0.5	0.2	0.2	0.8	0.8	0.8
05/22/2025 14:00	3,645.8	31.9	3,645.8	105,000.0	382.8	0.5	0.2	0.2	0.8	0.8	0.8
05/22/2025 15:00	3,653.8	2.2	3,653.8	105,000.0	383.6	0.5	0.2	0.2	0.8	0.8	0.8
05/22/2025 16:00	3,662.5	8.3	3,662.5	105,000.0	384.6	0.5	0.2	0.2	0.8	0.8	0.8
05/22/2025 17:00	3,679.7	0.1	3,679.7	105,000.0	386.4	0.5	0.2	0.2	0.8	0.8	0.8
05/22/2025 18:00	3,664.8	0.7	3,664.8	105,000.0	384.8	0.5	0.2	0.2	0.8	0.8	0.8
05/22/2025 19:00	3,674.1	0.0	3,674.1	105,000.0	385.8	0.5	0.2	0.2	0.8	0.8	0.8
05/22/2025 20:00	3,687.0	0.0	3,687.0	105,000.0	387.1	0.5	0.2	0.2	0.8	0.8	0.8
05/22/2025 21:00	3,689.5	0.0	3,689.5	105,000.0	387.4	0.5	0.2	0.2	0.8	0.8	0.8
05/22/2025 22:00	3,682.5	0.0	3,682.5	105,000.0	386.7	0.5	0.2	0.2	0.8	0.8	0.8
05/22/2025 23:00	3,704.0	0.0	3,704.0	105,000.0	388.9	0.5	0.2	0.2	0.8	0.8	0.8
Average/Sum#:	3,681.1	18.6	3,681.1	105,000.0	386.5	0.5	0.2	0.2	0.8	0.8	0.8
Minimum:	3,645.8	0.0	3,645.8	105,000.0	382.8	0.5	0.2	0.2	0.8	0.8	0.8
Maximum:	3,710.7	108.2	3,710.7	105,000.0	389.6	0.5	0.2	0.2	0.8	0.8	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

Const. Value/Limit Tag:		> 4.73 > 1 > 1.8							
		Unit CT2		Unit CT2		Unit CT2		Unit CT2	
		GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
		1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/23/2025 00:00		3,723.6	0.0	3,723.6	105,000.0	391.0	0.5	0.2	0.8
05/23/2025 01:00		3,729.7	0.0	3,729.7	105,000.0	391.6	0.5	0.2	0.8
05/23/2025 02:00		3,735.9	0.0	3,735.9	105,000.0	392.3	0.5	0.2	0.8
05/23/2025 03:00		3,745.6	0.0	3,745.6	105,000.0	393.3	0.5	0.2	0.8
05/23/2025 04:00		3,740.7	0.0	3,740.7	105,000.0	392.8	0.5	0.2	0.8
05/23/2025 05:00		3,715.8	0.0	3,715.8	105,000.0	390.2	0.5	0.2	0.8
05/23/2025 06:00		3,696.0	0.0	3,696.0	105,000.0	388.1	0.5	0.2	0.8
05/23/2025 07:00		3,690.4	0.0	3,690.4	105,000.0	387.5	0.5	0.2	0.8
05/23/2025 08:00		3,694.5	12.6	3,694.5	105,000.0	387.9	0.5	0.2	0.8
05/23/2025 09:00		3,698.8	27.6	3,698.8	105,000.0	388.4	0.5	0.2	0.8
05/23/2025 10:00		3,702.4	5.6	3,702.4	105,000.0	388.8	0.5	0.2	0.8
05/23/2025 11:00		3,699.2	100.9	3,699.2	105,000.0	388.4	0.5	0.2	0.8
05/23/2025 12:00		3,670.5	96.5	3,670.5	105,000.0	385.4	0.5	0.2	0.8
05/23/2025 13:00		3,668.7	61.9	3,668.7	105,000.0	385.2	0.5	0.2	0.8
05/23/2025 14:00		3,671.3	9.3	3,671.3	105,000.0	385.5	0.5	0.2	0.8
05/23/2025 15:00		3,672.0	0.0	3,672.0	105,000.0	385.6	0.5	0.2	0.8
05/23/2025 16:00		3,661.8	0.1	3,661.8	105,000.0	384.5	0.5	0.2	0.8
05/23/2025 17:00		3,875.7	0.1	3,875.7	105,000.0	406.9	0.5	0.2	0.8
05/23/2025 18:00		3,833.1	2.0	3,833.1	105,000.0	402.5	0.5	0.2	0.8
05/23/2025 19:00		3,762.7	0.0	3,762.7	105,000.0	395.1	0.5	0.2	0.8
05/23/2025 20:00		3,860.1	0.0	3,860.1	105,000.0	405.3	0.5	0.2	0.8
05/23/2025 21:00		4,324.5	0.0	4,324.5	105,000.0	454.1	0.5	0.3	0.9
05/23/2025 22:00		3,948.6	0.0	3,948.6	105,000.0	414.6	0.5	0.2	0.8
05/23/2025 23:00		4,466.3	0.0	4,466.3	105,000.0	469.0	0.6	0.3	0.9
Average/Sum#:		3,791.2	13.2	3,791.2	105,000.0	398.1	0.5	0.2	0.8
Minimum:		3,661.8	0.0	3,661.8	105,000.0	384.5	0.5	0.2	0.8
Maximum:		4,466.3	100.9	4,466.3	105,000.0	469.0	0.6	0.3	0.9
%SI		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/24/2025 00:00	4,358.6	0.0	4,358.6	105,000.0	457.7	0.5	0.3	0.9
05/24/2025 01:00	3,917.1	0.0	3,917.1	105,000.0	411.3	0.5	0.2	0.8
05/24/2025 02:00	3,690.7	0.0	3,690.7	105,000.0	387.5	0.5	0.2	0.8
05/24/2025 03:00	3,686.7	0.0	3,686.7	105,000.0	387.1	0.5	0.2	0.8
05/24/2025 04:00	3,690.5	0.0	3,690.5	105,000.0	387.5	0.5	0.2	0.8
05/24/2025 05:00	3,692.0	0.0	3,692.0	105,000.0	387.7	0.5	0.2	0.8
05/24/2025 06:00	3,685.2	0.0	3,685.2	105,000.0	386.9	0.5	0.2	0.8
05/24/2025 07:00	3,683.2	0.2	3,683.2	105,000.0	386.7	0.5	0.2	0.8
05/24/2025 08:00	3,675.9	6.8	3,675.9	105,000.0	386.0	0.5	0.2	0.8
05/24/2025 09:00	3,681.6	13.3	3,681.6	105,000.0	386.6	0.5	0.2	0.8
05/24/2025 10:00	3,690.8	36.3	3,690.8	105,000.0	387.5	0.5	0.2	0.8
05/24/2025 11:00	3,664.9	100.2	3,664.9	105,000.0	384.8	0.5	0.2	0.8
05/24/2025 12:00	3,652.7	105.7	3,652.7	105,000.0	383.5	0.5	0.2	0.8
05/24/2025 13:00	3,657.1	68.7	3,657.1	105,000.0	384.0	0.5	0.2	0.8
05/24/2025 14:00	3,652.6	36.3	3,652.6	105,000.0	383.5	0.5	0.2	0.8
05/24/2025 15:00	3,666.2	1.0	3,666.2	105,000.0	385.0	0.5	0.2	0.8
05/24/2025 16:00	3,661.6	8.8	3,661.6	105,000.0	384.5	0.5	0.2	0.8
05/24/2025 17:00	3,960.1	0.2	3,960.1	105,000.0	415.8	0.5	0.2	0.8
05/24/2025 18:00	4,118.2	0.6	4,118.2	105,000.0	432.4	0.5	0.3	0.9
05/24/2025 19:00	3,667.1	0.0	3,667.1	105,000.0	385.0	0.5	0.2	0.8
05/24/2025 20:00	3,702.8	0.0	3,702.8	105,000.0	388.8	0.5	0.2	0.8
05/24/2025 21:00	3,674.8	0.0	3,674.8	105,000.0	385.9	0.5	0.2	0.8
05/24/2025 22:00	3,675.4	0.0	3,675.4	105,000.0	385.9	0.5	0.2	0.8
05/24/2025 23:00	3,664.7	0.0	3,664.7	105,000.0	384.8	0.5	0.2	0.8
Average/Sum#:	3,744.6	15.8	3,744.6	105,000.0	393.2	0.5	0.2	0.8
Minimum:	3,652.6	0.0	3,652.6	105,000.0	383.5	0.5	0.2	0.8
Maximum:	4,358.6	105.7	4,358.6	105,000.0	457.7	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/25/2025 00:00	3,676.9	0.0	3,676.9	105,000.0	386.1	0.5	0.2	0.8
05/25/2025 01:00	3,696.1	0.0	3,696.1	105,000.0	388.1	0.5	0.2	0.8
05/25/2025 02:00	3,695.3	0.0	3,695.3	105,000.0	388.0	0.5	0.2	0.8
05/25/2025 03:00	3,699.8	0.0	3,699.8	105,000.0	388.5	0.5	0.2	0.8
05/25/2025 04:00	3,727.7	0.0	3,727.7	105,000.0	391.4	0.5	0.2	0.8
05/25/2025 05:00	3,937.0	0.0	3,937.0	105,000.0	413.4	0.5	0.2	0.8
05/25/2025 06:00	3,724.7	0.0	3,724.7	105,000.0	391.1	0.5	0.2	0.8
05/25/2025 07:00	3,722.8	0.0	3,722.8	105,000.0	390.9	0.5	0.2	0.8
05/25/2025 08:00	3,723.0	6.3	3,723.0	105,000.0	390.9	0.5	0.2	0.8
05/25/2025 09:00	3,730.1	11.9	3,730.1	105,000.0	391.7	0.5	0.2	0.8
05/25/2025 10:00	3,702.8	16.7	3,702.8	105,000.0	388.8	0.5	0.2	0.8
05/25/2025 11:00	3,695.5	98.1	3,695.5	105,000.0	388.0	0.5	0.2	0.8
05/25/2025 12:00	3,693.8	95.5	3,693.8	105,000.0	387.8	0.5	0.2	0.8
05/25/2025 13:00	3,702.8	63.1	3,702.8	105,000.0	388.8	0.5	0.2	0.8
05/25/2025 14:00	3,699.3	20.5	3,699.3	105,000.0	388.4	0.5	0.2	0.8
05/25/2025 15:00	3,680.4	0.0	3,680.4	105,000.0	386.4	0.5	0.2	0.8
05/25/2025 16:00	3,675.3	0.0	3,675.3	105,000.0	385.9	0.5	0.2	0.8
05/25/2025 17:00	3,672.9	0.0	3,672.9	105,000.0	385.7	0.5	0.2	0.8
05/25/2025 18:00	3,689.8	0.0	3,689.8	105,000.0	387.4	0.5	0.2	0.8
05/25/2025 19:00	3,682.9	0.0	3,682.9	105,000.0	386.7	0.5	0.2	0.8
05/25/2025 20:00	3,717.2	0.0	3,717.2	105,000.0	390.3	0.5	0.2	0.8
05/25/2025 21:00	3,725.4	0.0	3,725.4	105,000.0	391.2	0.5	0.2	0.8
05/25/2025 22:00	3,694.7	0.0	3,694.7	105,000.0	387.9	0.5	0.2	0.8
05/25/2025 23:00	3,697.3	0.0	3,697.3	105,000.0	388.2	0.5	0.2	0.8
Average/Sum#:	3,711.0	13.0	3,711.0	105,000.0	389.7	0.5	0.2	0.8
Minimum:	3,672.9	0.0	3,672.9	105,000.0	385.7	0.5	0.2	0.8
Maximum:	3,937.0	98.1	3,937.0	105,000.0	413.4	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/26/2025 00:00	3,706.7	0.0	3,706.7	105,000.0	389.2	0.5	0.2	0.8
05/26/2025 01:00	3,705.1	0.0	3,705.1	105,000.0	389.0	0.5	0.2	0.8
05/26/2025 02:00	3,701.6	0.0	3,701.6	105,000.0	388.7	0.5	0.2	0.8
05/26/2025 03:00	3,711.2	0.0	3,711.2	105,000.0	389.7	0.5	0.2	0.8
05/26/2025 04:00	3,719.0	0.0	3,719.0	105,000.0	390.5	0.5	0.2	0.8
05/26/2025 05:00	3,693.1	0.0	3,693.1	105,000.0	387.8	0.5	0.2	0.8
05/26/2025 06:00	3,677.0	0.0	3,677.0	105,000.0	386.1	0.5	0.2	0.8
05/26/2025 07:00	3,674.3	0.0	3,674.3	105,000.0	385.8	0.5	0.2	0.8
05/26/2025 08:00	3,678.7	0.0	3,678.7	105,000.0	386.3	0.5	0.2	0.8
05/26/2025 09:00	3,685.1	0.0	3,685.1	105,000.0	386.9	0.5	0.2	0.8
05/26/2025 10:00	3,692.8	39.5	3,692.8	105,000.0	387.7	0.5	0.2	0.8
05/26/2025 11:00	3,678.7	92.4	3,678.7	105,000.0	386.3	0.5	0.2	0.8
05/26/2025 12:00	3,663.2	83.2	3,663.2	105,000.0	384.6	0.5	0.2	0.8
05/26/2025 13:00	3,658.7	42.9	3,658.7	105,000.0	384.2	0.5	0.2	0.8
05/26/2025 14:00	3,659.8	8.3	3,659.8	105,000.0	384.3	0.5	0.2	0.8
05/26/2025 15:00	3,657.0	0.0	3,657.0	105,000.0	384.0	0.5	0.2	0.8
05/26/2025 16:00	3,659.6	0.0	3,659.6	105,000.0	384.3	0.5	0.2	0.8
05/26/2025 17:00	3,717.2	0.0	3,717.2	105,000.0	390.3	0.5	0.2	0.8
05/26/2025 18:00	3,686.8	0.0	3,686.8	105,000.0	387.1	0.5	0.2	0.8
05/26/2025 19:00	3,668.2	0.0	3,668.2	105,000.0	385.2	0.5	0.2	0.8
05/26/2025 20:00	3,673.6	0.0	3,673.6	105,000.0	385.7	0.5	0.2	0.8
05/26/2025 21:00	3,695.2	0.0	3,695.2	105,000.0	388.0	0.5	0.2	0.8
05/26/2025 22:00	3,696.7	0.0	3,696.7	105,000.0	388.2	0.5	0.2	0.8
05/26/2025 23:00	3,691.6	0.0	3,691.6	105,000.0	387.6	0.5	0.2	0.8
Average/Sum#:	3,685.5	11.1	3,685.5	105,000.0	387.0	0.5	0.2	0.8
Minimum:	3,657.0	0.0	3,657.0	105,000.0	384.0	0.5	0.2	0.8
Maximum:	3,719.0	92.4	3,719.0	105,000.0	390.5	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/27/2025 00:00	3,691.6	0.0	3,691.6	105,000.0	387.6	0.5	0.2	0.8
05/27/2025 01:00	3,691.4	0.0	3,691.4	105,000.0	387.6	0.5	0.2	0.8
05/27/2025 02:00	3,691.6	0.0	3,691.6	105,000.0	387.6	0.5	0.2	0.8
05/27/2025 03:00	3,692.2	0.0	3,692.2	105,000.0	387.7	0.5	0.2	0.8
05/27/2025 04:00	3,699.6	0.0	3,699.6	105,000.0	388.5	0.5	0.2	0.8
05/27/2025 05:00	3,689.8	0.0	3,689.8	105,000.0	387.4	0.5	0.2	0.8
05/27/2025 06:00	3,691.3	0.0	3,691.3	105,000.0	387.6	0.5	0.2	0.8
05/27/2025 07:00	3,695.7	0.2	3,695.7	105,000.0	388.0	0.5	0.2	0.8
05/27/2025 08:00	3,726.3	44.7	3,726.3	105,000.0	391.3	0.5	0.2	0.8
05/27/2025 09:00	3,689.9	34.1	3,689.9	105,000.0	387.4	0.5	0.2	0.8
05/27/2025 10:00	4,110.9	66.8	4,110.9	105,000.0	431.6	0.5	0.3	0.9
05/27/2025 11:00	4,440.1	107.7	4,440.1	105,000.0	466.2	0.6	0.3	1.0
05/27/2025 12:00	3,696.4	106.8	3,696.4	105,000.0	388.1	0.5	0.2	0.8
05/27/2025 13:00	3,717.9	80.3	3,717.9	105,000.0	390.4	0.5	0.2	0.8
05/27/2025 14:00	4,499.2	49.5	4,499.2	105,000.0	472.4	0.6	0.3	1.0
05/27/2025 15:00	4,516.9	1.5	4,516.9	105,000.0	474.3	0.6	0.3	0.9
05/27/2025 16:00	3,850.7	21.5	3,850.7	105,000.0	404.3	0.5	0.2	0.8
05/27/2025 17:00	4,251.2	6.8	4,251.2	105,000.0	446.4	0.5	0.3	0.9
05/27/2025 18:00	4,624.2	18.7	4,624.2	105,000.0	485.5	0.6	0.3	1.0
05/27/2025 19:00	4,617.3	0.0	4,617.3	105,000.0	484.8	0.6	0.3	1.0
05/27/2025 20:00	4,611.3	0.0	4,611.3	105,000.0	484.2	0.6	0.3	1.0
05/27/2025 21:00	4,615.7	0.0	4,615.7	105,000.0	484.6	0.6	0.3	1.0
05/27/2025 22:00	4,621.6	0.0	4,621.6	105,000.0	485.3	0.6	0.3	1.0
05/27/2025 23:00	4,628.5	0.0	4,628.5	105,000.0	486.0	0.6	0.3	1.0
Average/Sum#:	4,073.4	22.4	4,073.4	105,000.0	427.7	0.5	0.2	0.9
Minimum:	3,689.8	0.0	3,689.8	105,000.0	387.4	0.5	0.2	0.8
Maximum:	4,628.5	107.7	4,628.5	105,000.0	486.0	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT2

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/28/2025 00:00	4,595.6	0.0	4,595.6	105,000.0	482.5	0.6	0.3	0.3	1.0	1.0	1.0
05/28/2025 01:00	4,608.8	0.0	4,608.8	105,000.0	483.9	0.6	0.3	0.3	1.0	1.0	1.0
05/28/2025 02:00	4,598.1	0.0	4,598.1	105,000.0	482.8	0.6	0.3	0.3	1.0	1.0	1.0
05/28/2025 03:00	4,531.2	0.0	4,531.2	105,000.0	475.8	0.6	0.3	0.3	1.0	1.0	1.0
05/28/2025 04:00	4,325.5	0.0	4,325.5	105,000.0	454.2	0.5	0.3	0.3	0.9	0.9	0.9
05/28/2025 05:00	3,886.7	0.0	3,886.7	105,000.0	408.1	0.5	0.2	0.2	0.8	0.8	0.8
05/28/2025 06:00	3,720.5	0.0	3,720.5	105,000.0	390.7	0.5	0.2	0.2	0.8	0.8	0.8
05/28/2025 07:00	3,719.5	0.0	3,719.5	105,000.0	390.5	0.5	0.2	0.2	0.8	0.8	0.8
05/28/2025 08:00	3,721.8	9.2	3,721.8	105,000.0	390.8	0.5	0.2	0.2	0.8	0.8	0.8
05/28/2025 09:00	3,733.8	22.6	3,733.8	105,000.0	392.0	0.5	0.2	0.2	0.8	0.8	0.8
05/28/2025 10:00	3,732.7	74.2	3,732.7	105,000.0	391.9	0.5	0.2	0.2	0.8	0.8	0.8
05/28/2025 11:00	3,660.9	114.5	3,660.9	105,000.0	384.4	0.5	0.2	0.2	0.8	0.8	0.8
05/28/2025 12:00	3,653.5	117.2	3,653.5	105,000.0	383.6	0.5	0.2	0.2	0.8	0.8	0.8
05/28/2025 13:00	3,656.1	86.1	3,656.1	105,000.0	383.9	0.5	0.2	0.2	0.8	0.8	0.8
05/28/2025 14:00	3,666.8	53.2	3,666.8	105,000.0	385.0	0.5	0.2	0.2	0.8	0.8	0.8
05/28/2025 15:00	3,663.2	4.7	3,663.2	105,000.0	384.6	0.5	0.2	0.2	0.8	0.8	0.8
05/28/2025 16:00	3,663.3	21.7	3,663.3	105,000.0	384.6	0.5	0.2	0.2	0.8	0.8	0.8
05/28/2025 17:00	3,720.6	4.7	3,720.6	105,000.0	390.7	0.5	0.2	0.2	0.8	0.8	0.8
05/28/2025 18:00	4,352.3	6.8	4,352.3	105,000.0	457.0	0.5	0.3	0.3	0.9	0.9	0.9
05/28/2025 19:00	3,693.7	0.0	3,693.7	105,000.0	387.8	0.5	0.2	0.2	0.8	0.8	0.8
05/28/2025 20:00	3,652.2	0.0	3,652.2	105,000.0	383.5	0.5	0.2	0.2	0.8	0.8	0.8
05/28/2025 21:00	3,661.1	0.0	3,661.1	105,000.0	384.4	0.5	0.2	0.2	0.8	0.8	0.8
05/28/2025 22:00	3,663.8	0.0	3,663.8	105,000.0	384.7	0.5	0.2	0.2	0.8	0.8	0.8
05/28/2025 23:00	3,667.2	0.0	3,667.2	105,000.0	385.1	0.5	0.2	0.2	0.8	0.8	0.8
Average/Sum#:	3,897.9	21.5	3,897.9	105,000.0	409.3	0.5	0.2	0.2	0.8	0.8	0.8
Minimum:	3,652.2	0.0	3,652.2	105,000.0	383.5	0.5	0.2	0.2	0.8	0.8	0.8
Maximum:	4,608.8	117.2	4,608.8	105,000.0	483.9	0.6	0.3	0.3	1.0	1.0	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/29/2025 00:00	3,667.9	0.0	3,667.9	105,000.0	385.1	0.5	0.2	0.8
05/29/2025 01:00	3,665.9	0.0	3,665.9	105,000.0	384.9	0.5	0.2	0.8
05/29/2025 02:00	3,674.1	0.0	3,674.1	105,000.0	385.8	0.5	0.2	0.8
05/29/2025 03:00	3,669.7	0.0	3,669.7	105,000.0	385.3	0.5	0.2	0.8
05/29/2025 04:00	3,945.3	0.0	3,945.3	105,000.0	414.3	0.5	0.2	0.8
05/29/2025 05:00	3,956.5	0.0	3,956.5	105,000.0	415.4	0.5	0.2	0.8
05/29/2025 06:00	3,727.9	0.0	3,727.9	105,000.0	391.4	0.5	0.2	0.8
05/29/2025 07:00	3,729.6	3.6	3,729.6	105,000.0	391.6	0.5	0.2	0.8
05/29/2025 08:00	3,738.8	50.5	3,738.8	105,000.0	392.6	0.5	0.2	0.8
05/29/2025 09:00	3,718.4	42.3	3,718.4	105,000.0	390.4	0.5	0.2	0.8
05/29/2025 10:00	3,707.0	77.5	3,707.0	105,000.0	389.2	0.5	0.2	0.8
05/29/2025 11:00	3,716.0	93.2	3,716.0	105,000.0	390.2	0.5	0.2	0.8
05/29/2025 12:00	3,718.8	96.8	3,718.8	105,000.0	390.5	0.5	0.2	0.8
05/29/2025 13:00	3,711.5	53.7	3,711.5	105,000.0	389.7	0.5	0.2	0.8
05/29/2025 14:00	3,694.5	36.4	3,694.5	105,000.0	387.9	0.5	0.2	0.8
05/29/2025 15:00	3,683.7	1.6	3,683.7	105,000.0	386.8	0.5	0.2	0.8
05/29/2025 16:00	3,674.3	16.8	3,674.3	105,000.0	385.8	0.5	0.2	0.8
05/29/2025 17:00	3,778.4	6.8	3,778.4	105,000.0	396.7	0.5	0.2	0.8
05/29/2025 18:00	3,637.4	24.6	3,637.4	105,000.0	381.9	0.5	0.2	0.8
05/29/2025 19:00	3,630.2	0.1	3,630.2	105,000.0	381.2	0.5	0.2	0.8
05/29/2025 20:00	3,633.0	0.0	3,633.0	105,000.0	381.5	0.5	0.2	0.8
05/29/2025 21:00	3,625.9	0.0	3,625.9	105,000.0	380.7	0.5	0.2	0.8
05/29/2025 22:00	3,647.1	0.0	3,647.1	105,000.0	382.9	0.5	0.2	0.8
05/29/2025 23:00	3,641.8	0.0	3,641.8	105,000.0	382.4	0.5	0.2	0.8
Average/Sum#:	3,708.1	21.0	3,708.1	105,000.0	389.3	0.5	0.2	0.8
Minimum:	3,625.9	0.0	3,625.9	105,000.0	380.7	0.5	0.2	0.8
Maximum:	3,956.5	96.8	3,956.5	105,000.0	415.4	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/30/2025 00:00	3,651.5	0.0	3,651.5	105,000.0	383.4	0.5	0.2	0.8			
05/30/2025 01:00	3,654.2	0.0	3,654.2	105,000.0	383.7	0.5	0.2	0.8			
05/30/2025 02:00	3,659.3	0.0	3,659.3	105,000.0	384.2	0.5	0.2	0.8			
05/30/2025 03:00	3,664.3	0.0	3,664.3	105,000.0	384.8	0.5	0.2	0.8			
05/30/2025 04:00	3,663.6	0.0	3,663.6	105,000.0	384.7	0.5	0.2	0.8			
05/30/2025 05:00	3,692.6	0.0	3,692.6	105,000.0	387.7	0.5	0.2	0.8			
05/30/2025 06:00	3,722.0	41.4	3,722.0	105,000.0	390.8	0.5	0.2	0.8			
05/30/2025 07:00	3,720.3	75.8	3,720.3	105,000.0	390.6	0.5	0.2	0.8			
05/30/2025 08:00	3,728.0	86.8	3,728.0	105,000.0	391.4	0.5	0.2	0.8			
05/30/2025 09:00	3,727.5	83.4	3,727.5	105,000.0	391.4	0.5	0.2	0.8			
05/30/2025 10:00	3,728.0	107.7	3,728.0	105,000.0	391.4	0.5	0.2	0.8			
05/30/2025 11:00	3,702.8	121.8	3,702.8	105,000.0	388.8	0.5	0.2	0.8			
05/30/2025 12:00	3,920.7	120.9	3,920.7	105,000.0	411.7	0.5	0.3	0.8			
05/30/2025 13:00	4,190.1	101.0	4,190.1	105,000.0	440.0	0.5	0.3	0.9			
05/30/2025 14:00	4,340.7	75.9	4,340.7	105,000.0	455.8	0.6	0.3	0.9			
05/30/2025 15:00	4,177.4	54.2	4,177.4	105,000.0	438.6	0.5	0.3	0.9			
05/30/2025 16:00	4,224.8	69.3	4,224.8	105,000.0	443.6	0.5	0.3	0.9			
05/30/2025 17:00	4,108.1	67.8	4,108.1	105,000.0	431.4	0.5	0.3	0.9			
05/30/2025 18:00	4,232.5	79.6	4,232.5	105,000.0	444.4	0.5	0.3	0.9			
05/30/2025 19:00	4,262.0	43.5	4,262.0	105,000.0	447.5	0.5	0.3	0.9			
05/30/2025 20:00	4,543.9	27.3	4,543.9	105,000.0	477.1	0.6	0.3	1.0			
05/30/2025 21:00	4,544.4	15.1	4,544.4	105,000.0	477.2	0.6	0.3	1.0			
05/30/2025 22:00	4,189.0	7.7	4,189.0	105,000.0	439.8	0.5	0.3	0.9			
05/30/2025 23:00	4,144.9	0.0	4,144.9	105,000.0	435.2	0.5	0.3	0.9			
Average/Sum#:	3,966.4	49.1	3,966.4	105,000.0	416.5	0.5	0.3	0.9			
Minimum:	3,651.5	0.0	3,651.5	105,000.0	383.4	0.5	0.2	0.8			
Maximum:	4,544.4	121.8	4,544.4	105,000.0	477.2	0.6	0.3	1.0			
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/31/2025 00:00	3,757.2	0.0	3,757.2	105,000.0	394.5	0.5	0.2	0.2	0.8	0.8	0.8
05/31/2025 01:00	3,866.5	0.0	3,866.5	105,000.0	406.0	0.5	0.2	0.2	0.8	0.8	0.8
05/31/2025 02:00	3,778.2	0.0	3,778.2	105,000.0	396.7	0.5	0.2	0.2	0.8	0.8	0.8
05/31/2025 03:00	3,693.4	0.0	3,693.4	105,000.0	387.8	0.5	0.2	0.2	0.8	0.8	0.8
05/31/2025 04:00	3,692.8	0.0	3,692.8	105,000.0	387.7	0.5	0.2	0.2	0.8	0.8	0.8
05/31/2025 05:00	3,708.8	10.7	3,708.8	105,000.0	389.4	0.5	0.2	0.2	0.8	0.8	0.8
05/31/2025 06:00	3,733.9	59.7	3,733.9	105,000.0	392.1	0.5	0.2	0.2	0.8	0.8	0.8
05/31/2025 07:00	3,721.8	71.6	3,721.8	105,000.0	390.8	0.5	0.2	0.2	0.8	0.8	0.8
05/31/2025 08:00	3,703.9	97.4	3,703.9	105,000.0	388.9	0.5	0.2	0.2	0.8	0.8	0.8
05/31/2025 09:00	3,705.5	87.6	3,705.5	105,000.0	389.1	0.5	0.2	0.2	0.8	0.8	0.8
05/31/2025 10:00	3,707.3	118.6	3,707.3	105,000.0	389.3	0.5	0.2	0.2	0.8	0.8	0.8
05/31/2025 11:00	3,699.6	133.6	3,699.6	105,000.0	388.5	0.5	0.2	0.2	0.8	0.8	0.8
05/31/2025 12:00	3,695.4	131.6	3,695.4	105,000.0	388.0	0.5	0.2	0.2	0.8	0.8	0.8
05/31/2025 13:00	3,703.0	102.9	3,703.0	105,000.0	388.8	0.5	0.2	0.2	0.8	0.8	0.8
05/31/2025 14:00	3,649.3	84.5	3,649.3	105,000.0	383.2	0.5	0.2	0.2	0.8	0.8	0.8
05/31/2025 15:00	3,636.3	72.3	3,636.3	105,000.0	381.8	0.5	0.2	0.2	0.8	0.8	0.8
05/31/2025 16:00	3,777.8	80.7	3,777.8	105,000.0	396.7	0.5	0.2	0.2	0.8	0.8	0.8
05/31/2025 17:00	4,097.1	73.0	4,097.1	105,000.0	430.2	0.5	0.3	0.3	0.9	0.9	0.9
05/31/2025 18:00	4,507.5	77.4	4,507.5	105,000.0	473.3	0.6	0.3	0.3	1.0	1.0	1.0
05/31/2025 19:00	4,498.1	48.5	4,498.1	105,000.0	472.3	0.6	0.3	0.3	1.0	1.0	1.0
05/31/2025 20:00	4,511.5	28.2	4,511.5	105,000.0	473.7	0.6	0.3	0.3	1.0	1.0	1.0
05/31/2025 21:00	4,156.6	2.3	4,156.6	105,000.0	436.4	0.5	0.3	0.3	0.9	0.9	0.9
05/31/2025 22:00	4,162.6	0.1	4,162.6	105,000.0	437.1	0.5	0.3	0.3	0.9	0.9	0.9
05/31/2025 23:00	3,679.3	0.0	3,679.3	105,000.0	386.3	0.5	0.2	0.2	0.8	0.8	0.8
Average/Sum#:	3,868.5	53.4	3,868.5	105,000.0	406.2	0.5	0.2	0.2	0.8	0.8	0.8
Minimum:	3,636.3	0.0	3,636.3	105,000.0	381.8	0.5	0.2	0.2	0.8	0.8	0.8
Maximum:	4,511.5	133.6	4,511.5	105,000.0	473.7	0.6	0.3	0.3	1.0	1.0	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/01/2025 00:00	3,665.3	0.0	3,665.3	104,900.0	384.5	0.5	0.2	0.2	0.8	0.8
06/01/2025 01:00	3,663.6	0.0	3,663.6	104,900.0	384.3	0.5	0.2	0.2	0.8	0.8
06/01/2025 02:00	3,673.4	0.0	3,673.4	104,900.0	385.3	0.5	0.2	0.2	0.8	0.8
06/01/2025 03:00	3,693.9	0.0	3,693.9	104,900.0	387.5	0.5	0.2	0.2	0.8	0.8
06/01/2025 04:00	3,693.8	0.0	3,693.8	104,900.0	387.5	0.5	0.2	0.2	0.8	0.8
06/01/2025 05:00	3,670.8	0.0	3,670.8	104,900.0	385.1	0.5	0.2	0.2	0.8	0.8
06/01/2025 06:00	3,686.4	0.2	3,686.4	104,900.0	386.7	0.5	0.2	0.2	0.8	0.8
06/01/2025 07:00	3,692.3	10.9	3,692.3	104,900.0	387.3	0.5	0.2	0.2	0.8	0.8
06/01/2025 08:00	3,691.3	64.8	3,691.3	104,900.0	387.2	0.5	0.2	0.2	0.8	0.8
06/01/2025 09:00	3,698.2	82.2	3,698.2	104,900.0	387.9	0.5	0.2	0.2	0.8	0.8
06/01/2025 10:00	3,702.5	96.5	3,702.5	104,900.0	388.4	0.5	0.2	0.2	0.8	0.8
06/01/2025 11:00	3,681.7	113.5	3,681.7	104,900.0	386.2	0.5	0.2	0.2	0.8	0.8
06/01/2025 12:00	3,677.9	123.2	3,677.9	104,900.0	385.8	0.5	0.2	0.2	0.8	0.8
06/01/2025 13:00	3,670.6	87.0	3,670.6	104,900.0	385.0	0.5	0.2	0.2	0.8	0.8
06/01/2025 14:00	3,707.8	55.4	3,707.8	104,900.0	388.9	0.5	0.2	0.2	0.8	0.8
06/01/2025 15:00	3,665.7	4.7	3,665.7	104,900.0	384.5	0.5	0.2	0.2	0.8	0.8
06/01/2025 16:00	3,661.2	26.7	3,661.2	104,900.0	384.1	0.5	0.2	0.2	0.8	0.8
06/01/2025 17:00	3,682.3	1.4	3,682.3	104,900.0	386.3	0.5	0.2	0.2	0.8	0.8
06/01/2025 18:00	3,659.8	4.9	3,659.8	104,900.0	383.9	0.5	0.2	0.2	0.8	0.8
06/01/2025 19:00	3,684.8	0.0	3,684.8	104,900.0	386.5	0.5	0.2	0.2	0.8	0.8
06/01/2025 20:00	3,662.4	0.0	3,662.4	104,900.0	384.2	0.5	0.2	0.2	0.8	0.8
06/01/2025 21:00	3,673.6	0.0	3,673.6	104,900.0	385.4	0.5	0.2	0.2	0.8	0.8
06/01/2025 22:00	3,685.2	0.0	3,685.2	104,900.0	386.6	0.5	0.2	0.2	0.8	0.8
06/01/2025 23:00	3,695.0	0.0	3,695.0	104,900.0	387.6	0.5	0.2	0.2	0.8	0.8
Average/Sum#:	3,680.8	28.0	3,680.8	104,900.0	386.1	0.5	0.2	0.2	0.8	0.8
Minimum:	3,659.8	0.0	3,659.8	104,900.0	383.9	0.5	0.2	0.2	0.8	0.8
Maximum:	3,707.8	123.2	3,707.8	104,900.0	388.9	0.5	0.2	0.2	0.8	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/02/2025 00:00	3,700.0	0.0	3,700.0	104,900.0	388.1	0.5	0.2	0.2	0.8	0.8
06/02/2025 01:00	3,697.9	0.0	3,697.9	104,900.0	387.9	0.5	0.2	0.2	0.8	0.8
06/02/2025 02:00	3,701.1	0.0	3,701.1	104,900.0	388.2	0.5	0.2	0.2	0.8	0.8
06/02/2025 03:00	3,698.6	0.0	3,698.6	104,900.0	388.0	0.5	0.2	0.2	0.8	0.8
06/02/2025 04:00	4,143.3	0.0	4,143.3	104,900.0	434.6	0.5	0.3	0.3	0.9	0.9
06/02/2025 05:00	4,205.7	0.0	4,205.7	104,900.0	441.2	0.5	0.3	0.3	0.9	0.9
06/02/2025 06:00	3,690.7	0.0	3,690.7	104,900.0	387.2	0.5	0.2	0.2	0.8	0.8
06/02/2025 07:00	3,692.9	0.0	3,692.9	104,900.0	387.4	0.5	0.2	0.2	0.8	0.8
06/02/2025 08:00	3,702.0	3.5	3,702.0	104,900.0	388.3	0.5	0.2	0.2	0.8	0.8
06/02/2025 09:00	3,705.8	29.6	3,705.8	104,900.0	388.7	0.5	0.2	0.2	0.8	0.8
06/02/2025 10:00	3,691.6	85.7	3,691.6	104,900.0	387.2	0.5	0.2	0.2	0.8	0.8
06/02/2025 11:00	3,665.4	104.9	3,665.4	104,900.0	384.5	0.5	0.2	0.2	0.8	0.8
06/02/2025 12:00	3,666.6	110.1	3,666.6	104,900.0	384.6	0.5	0.2	0.2	0.8	0.8
06/02/2025 13:00	3,665.7	89.3	3,665.7	104,900.0	384.5	0.5	0.2	0.2	0.8	0.8
06/02/2025 14:00	3,936.1	50.4	3,936.1	104,900.0	412.9	0.5	0.3	0.3	0.8	0.8
06/02/2025 15:00	3,649.6	14.7	3,649.6	104,900.0	382.8	0.5	0.2	0.2	0.8	0.8
06/02/2025 16:00	3,635.6	45.5	3,635.6	104,900.0	381.4	0.5	0.2	0.2	0.8	0.8
06/02/2025 17:00	3,955.5	14.3	3,955.5	104,900.0	414.9	0.5	0.2	0.2	0.8	0.8
06/02/2025 18:00	4,593.8	5.9	4,593.8	104,900.0	481.9	0.6	0.3	0.3	1.0	1.0
06/02/2025 19:00	4,577.8	0.0	4,577.8	104,900.0	480.2	0.6	0.3	0.3	1.0	1.0
06/02/2025 20:00	4,575.9	0.0	4,575.9	104,900.0	480.0	0.6	0.3	0.3	1.0	1.0
06/02/2025 21:00	3,902.6	0.0	3,902.6	104,900.0	409.4	0.5	0.2	0.2	0.8	0.8
06/02/2025 22:00	4,270.3	0.0	4,270.3	104,900.0	448.0	0.5	0.3	0.3	0.9	0.9
06/02/2025 23:00	3,970.1	0.0	3,970.1	104,900.0	416.5	0.5	0.2	0.2	0.8	0.8
Average/Sum#:	3,903.9	23.1	3,903.9	104,900.0	409.5	0.5	0.2	0.2	0.8	0.8
Minimum:	3,635.6	0.0	3,635.6	104,900.0	381.4	0.5	0.2	0.2	0.8	0.8
Maximum:	4,593.8	110.1	4,593.8	104,900.0	481.9	0.6	0.3	0.3	1.0	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/03/2025 00:00	3,729.8	0.0	3,729.8	104,900.0	391.3	0.5	0.2	0.8
06/03/2025 01:00	3,696.5	0.0	3,696.5	104,900.0	387.8	0.5	0.2	0.8
06/03/2025 02:00	3,690.3	0.0	3,690.3	104,900.0	387.1	0.5	0.2	0.8
06/03/2025 03:00	3,704.3	0.0	3,704.3	104,900.0	388.6	0.5	0.2	0.8
06/03/2025 04:00	3,706.4	0.0	3,706.4	104,900.0	388.8	0.5	0.2	0.8
06/03/2025 05:00	3,719.9	0.0	3,719.9	104,900.0	390.2	0.5	0.2	0.8
06/03/2025 06:00	3,923.3	0.0	3,923.3	104,900.0	411.6	0.5	0.2	0.8
06/03/2025 07:00	3,742.0	0.0	3,742.0	104,900.0	392.5	0.5	0.2	0.8
06/03/2025 08:00	4,037.2	0.5	4,037.2	104,900.0	423.5	0.5	0.3	0.8
06/03/2025 09:00	4,285.9	58.0	4,285.9	104,900.0	449.6	0.5	0.3	0.9
06/03/2025 10:00	4,483.3	78.3	4,483.3	104,900.0	470.3	0.6	0.3	1.0
06/03/2025 11:00	3,871.9	99.6	3,871.9	104,900.0	406.2	0.5	0.2	0.8
06/03/2025 12:00	3,709.1	105.5	3,709.1	104,900.0	389.1	0.5	0.2	0.8
06/03/2025 13:00	4,512.1	55.4	4,512.1	104,900.0	473.3	0.6	0.3	1.0
06/03/2025 14:00	4,394.0	29.1	4,394.0	104,900.0	460.9	0.6	0.3	0.9
06/03/2025 15:00	4,341.8	0.8	4,341.8	104,900.0	455.5	0.5	0.3	0.9
06/03/2025 16:00	3,800.6	18.1	3,800.6	104,900.0	398.7	0.5	0.2	0.8
06/03/2025 17:00	3,789.7	2.6	3,789.7	104,900.0	397.5	0.5	0.2	0.8
06/03/2025 18:00	3,663.7	13.9	3,663.7	104,900.0	384.3	0.5	0.2	0.8
06/03/2025 19:00	3,658.2	0.0	3,658.2	104,900.0	383.7	0.5	0.2	0.8
06/03/2025 20:00	3,682.7	0.0	3,682.7	104,900.0	386.3	0.5	0.2	0.8
06/03/2025 21:00	3,696.3	0.0	3,696.3	104,900.0	387.7	0.5	0.2	0.8
06/03/2025 22:00	3,697.4	0.0	3,697.4	104,900.0	387.9	0.5	0.2	0.8
06/03/2025 23:00	3,687.4	0.0	3,687.4	104,900.0	386.8	0.5	0.2	0.8
Average/Sum#:	3,884.3	19.2	3,884.3	104,900.0	407.5	0.5	0.2	0.8
Minimum:	3,658.2	0.0	3,658.2	104,900.0	383.7	0.5	0.2	0.8
Maximum:	4,512.1	105.5	4,512.1	104,900.0	473.3	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/04/2025 00:00	3,694.4	0.0	3,694.4	104,900.0	387.5	0.5	0.2	0.2	0.8	0.8
06/04/2025 01:00	3,713.9	0.0	3,713.9	104,900.0	389.6	0.5	0.2	0.2	0.8	0.8
06/04/2025 02:00	3,711.5	0.0	3,711.5	104,900.0	389.3	0.5	0.2	0.2	0.8	0.8
06/04/2025 03:00	3,856.9	0.0	3,856.9	104,900.0	404.6	0.5	0.2	0.2	0.8	0.8
06/04/2025 04:00	3,721.9	0.0	3,721.9	104,900.0	390.4	0.5	0.2	0.2	0.8	0.8
06/04/2025 05:00	3,706.3	0.0	3,706.3	104,900.0	388.8	0.5	0.2	0.2	0.8	0.8
06/04/2025 06:00	3,699.5	1.9	3,699.5	104,900.0	388.1	0.5	0.2	0.2	0.8	0.8
06/04/2025 07:00	3,686.6	41.1	3,686.6	104,900.0	386.7	0.5	0.2	0.2	0.8	0.8
06/04/2025 08:00	3,675.3	70.5	3,675.3	104,900.0	385.5	0.5	0.2	0.2	0.8	0.8
06/04/2025 09:00	3,679.0	81.5	3,679.0	104,900.0	385.9	0.5	0.2	0.2	0.8	0.8
06/04/2025 10:00	3,688.6	154.7	3,688.6	104,900.0	386.9	0.5	0.2	0.2	0.8	0.8
06/04/2025 11:00	3,690.8	111.7	3,690.8	104,900.0	387.2	0.5	0.2	0.2	0.8	0.8
06/04/2025 12:00	3,673.4	94.5	3,673.4	104,900.0	385.3	0.5	0.2	0.2	0.8	0.8
06/04/2025 13:00	3,663.5	35.6	3,663.5	104,900.0	384.3	0.5	0.2	0.2	0.8	0.8
06/04/2025 14:00	3,658.5	43.1	3,658.5	104,900.0	383.8	0.5	0.2	0.2	0.8	0.8
06/04/2025 15:00	3,628.6	3.7	3,628.6	104,900.0	380.6	0.5	0.2	0.2	0.8	0.8
06/04/2025 16:00	3,631.1	29.0	3,631.1	104,900.0	380.9	0.5	0.2	0.2	0.8	0.8
06/04/2025 17:00	3,743.2	6.8	3,743.2	104,900.0	392.7	0.5	0.2	0.2	0.8	0.8
06/04/2025 18:00	3,654.2	10.3	3,654.2	104,900.0	383.3	0.5	0.2	0.2	0.8	0.8
06/04/2025 19:00	3,654.7	0.0	3,654.7	104,900.0	383.4	0.5	0.2	0.2	0.8	0.8
06/04/2025 20:00	3,657.2	0.0	3,657.2	104,900.0	383.6	0.5	0.2	0.2	0.8	0.8
06/04/2025 21:00	3,681.3	0.0	3,681.3	104,900.0	386.2	0.5	0.2	0.2	0.8	0.8
06/04/2025 22:00	3,693.7	0.0	3,693.7	104,900.0	387.5	0.5	0.2	0.2	0.8	0.8
06/04/2025 23:00	3,819.8	0.0	3,819.8	104,900.0	400.7	0.5	0.2	0.2	0.8	0.8
Average/Sum#:	3,695.2	28.5	3,695.2	104,900.0	387.6	0.5	0.2	0.2	0.8	0.8
Minimum:	3,628.6	0.0	3,628.6	104,900.0	380.6	0.5	0.2	0.2	0.8	0.8
Maximum:	3,856.9	154.7	3,856.9	104,900.0	404.6	0.5	0.2	0.2	0.8	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/05/2025 00:00	3,675.4	0.0	3,675.4	104,900.0	385.5	0.5	0.2	0.8
06/05/2025 01:00	3,691.1	0.0	3,691.1	104,900.0	387.2	0.5	0.2	0.8
06/05/2025 02:00	3,698.0	0.0	3,698.0	104,900.0	387.9	0.5	0.2	0.8
06/05/2025 03:00	3,698.3	0.0	3,698.3	104,900.0	388.0	0.5	0.2	0.8
06/05/2025 04:00	3,695.6	0.0	3,695.6	104,900.0	387.7	0.5	0.2	0.8
06/05/2025 05:00	3,701.9	0.0	3,701.9	104,900.0	388.3	0.5	0.2	0.8
06/05/2025 06:00	3,695.0	0.0	3,695.0	104,900.0	387.6	0.5	0.2	0.8
06/05/2025 07:00	3,698.1	0.0	3,698.1	104,900.0	387.9	0.5	0.2	0.8
06/05/2025 08:00	3,702.4	15.3	3,702.4	104,900.0	388.4	0.5	0.2	0.8
06/05/2025 09:00	3,709.6	31.1	3,709.6	104,900.0	389.1	0.5	0.2	0.8
06/05/2025 10:00	3,717.5	89.8	3,717.5	104,900.0	390.0	0.5	0.2	0.8
06/05/2025 11:00	3,719.1	105.7	3,719.1	104,900.0	390.1	0.5	0.2	0.8
06/05/2025 12:00	3,685.3	101.1	3,685.3	104,900.0	386.6	0.5	0.2	0.8
06/05/2025 13:00	3,675.4	76.2	3,675.4	104,900.0	385.5	0.5	0.2	0.8
06/05/2025 14:00	3,681.4	25.5	3,681.4	104,900.0	386.2	0.5	0.2	0.8
06/05/2025 15:00	3,691.0	0.2	3,691.0	104,900.0	387.2	0.5	0.2	0.8
06/05/2025 16:00	3,687.5	12.2	3,687.5	104,900.0	386.8	0.5	0.2	0.8
06/05/2025 17:00	3,915.9	0.0	3,915.9	104,900.0	410.8	0.5	0.2	0.8
06/05/2025 18:00	3,702.2	0.7	3,702.2	104,900.0	388.4	0.5	0.2	0.8
06/05/2025 19:00	3,686.7	0.0	3,686.7	104,900.0	386.7	0.5	0.2	0.8
06/05/2025 20:00	3,689.0	0.0	3,689.0	104,900.0	387.0	0.5	0.2	0.8
06/05/2025 21:00	3,687.9	0.0	3,687.9	104,900.0	386.9	0.5	0.2	0.8
06/05/2025 22:00	3,724.8	0.0	3,724.8	104,900.0	390.7	0.5	0.2	0.8
06/05/2025 23:00	4,048.3	0.0	4,048.3	104,900.0	424.7	0.5	0.3	0.8
Average/Sum#:	3,719.9	19.1	3,719.9	104,900.0	390.2	0.5	0.2	0.8
Minimum:	3,675.4	0.0	3,675.4	104,900.0	385.5	0.5	0.2	0.8
Maximum:	4,048.3	105.7	4,048.3	104,900.0	424.7	0.5	0.3	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/06/2025 00:00	3,720.9	0.0	3,720.9	104,900.0	390.3	0.5	0.2	0.8
06/06/2025 01:00	3,722.0	0.0	3,722.0	104,900.0	390.4	0.5	0.2	0.8
06/06/2025 02:00	3,728.1	0.0	3,728.1	104,900.0	391.1	0.5	0.2	0.8
06/06/2025 03:00	3,726.4	0.0	3,726.4	104,900.0	390.9	0.5	0.2	0.8
06/06/2025 04:00	3,718.9	0.0	3,718.9	104,900.0	390.1	0.5	0.2	0.8
06/06/2025 05:00	3,719.5	0.0	3,719.5	104,900.0	390.2	0.5	0.2	0.8
06/06/2025 06:00	3,712.9	0.0	3,712.9	104,900.0	389.5	0.5	0.2	0.8
06/06/2025 07:00	3,719.7	0.0	3,719.7	104,900.0	390.2	0.5	0.2	0.8
06/06/2025 08:00	3,720.2	13.1	3,720.2	104,900.0	390.2	0.5	0.2	0.8
06/06/2025 09:00	3,727.0	62.0	3,727.0	104,900.0	391.0	0.5	0.2	0.8
06/06/2025 10:00	3,701.9	89.9	3,701.9	104,900.0	388.3	0.5	0.2	0.8
06/06/2025 11:00	3,683.0	110.0	3,683.0	104,900.0	386.3	0.5	0.2	0.8
06/06/2025 12:00	3,687.9	100.2	3,687.9	104,900.0	386.9	0.5	0.2	0.8
06/06/2025 13:00	4,018.0	79.3	4,018.0	104,900.0	421.5	0.5	0.3	0.9
06/06/2025 14:00	3,669.6	43.5	3,669.6	104,900.0	384.9	0.5	0.2	0.8
06/06/2025 15:00	3,651.0	16.6	3,651.0	104,900.0	383.0	0.5	0.2	0.8
06/06/2025 16:00	3,648.9	51.3	3,648.9	104,900.0	382.8	0.5	0.2	0.8
06/06/2025 17:00	3,699.4	32.5	3,699.4	104,900.0	388.1	0.5	0.2	0.8
06/06/2025 18:00	3,668.2	31.7	3,668.2	104,900.0	384.8	0.5	0.2	0.8
06/06/2025 19:00	3,690.5	0.3	3,690.5	104,900.0	387.1	0.5	0.2	0.8
06/06/2025 20:00	3,695.0	0.0	3,695.0	104,900.0	387.6	0.5	0.2	0.8
06/06/2025 21:00	3,692.9	0.0	3,692.9	104,900.0	387.4	0.5	0.2	0.8
06/06/2025 22:00	3,689.8	0.0	3,689.8	104,900.0	387.1	0.5	0.2	0.8
06/06/2025 23:00	3,685.4	0.0	3,685.4	104,900.0	386.6	0.5	0.2	0.8
Average/Sum#:	3,712.4	26.3	3,712.4	104,900.0	389.4	0.5	0.2	0.8
Minimum:	3,648.9	0.0	3,648.9	104,900.0	382.8	0.5	0.2	0.8
Maximum:	4,018.0	110.0	4,018.0	104,900.0	421.5	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/07/2025 00:00	3,692.8	0.0	3,692.8	104,900.0	387.4	0.5	0.2	0.8
06/07/2025 01:00	3,719.2	0.0	3,719.2	104,900.0	390.1	0.5	0.2	0.8
06/07/2025 02:00	3,718.8	0.0	3,718.8	104,900.0	390.1	0.5	0.2	0.8
06/07/2025 03:00	3,713.9	0.0	3,713.9	104,900.0	389.6	0.5	0.2	0.8
06/07/2025 04:00	3,712.3	0.0	3,712.3	104,900.0	389.4	0.5	0.2	0.8
06/07/2025 05:00	3,713.5	0.0	3,713.5	104,900.0	389.5	0.5	0.2	0.8
06/07/2025 06:00	3,713.4	0.0	3,713.4	104,900.0	389.5	0.5	0.2	0.8
06/07/2025 07:00	3,714.4	23.7	3,714.4	104,900.0	389.6	0.5	0.2	0.8
06/07/2025 08:00	3,712.8	61.8	3,712.8	104,900.0	389.5	0.5	0.2	0.8
06/07/2025 09:00	3,685.3	94.1	3,685.3	104,900.0	386.6	0.5	0.2	0.8
06/07/2025 10:00	3,685.0	110.4	3,685.0	104,900.0	386.6	0.5	0.2	0.8
06/07/2025 11:00	3,691.9	114.2	3,691.9	104,900.0	387.3	0.5	0.2	0.8
06/07/2025 12:00	3,687.3	121.3	3,687.3	104,900.0	386.8	0.5	0.2	0.8
06/07/2025 13:00	3,691.4	92.1	3,691.4	104,900.0	387.2	0.5	0.2	0.8
06/07/2025 14:00	3,651.9	56.0	3,651.9	104,900.0	383.1	0.5	0.2	0.8
06/07/2025 15:00	3,652.7	54.4	3,652.7	104,900.0	383.2	0.5	0.2	0.8
06/07/2025 16:00	3,830.5	66.4	3,830.5	104,900.0	401.8	0.5	0.2	0.8
06/07/2025 17:00	3,907.5	60.9	3,907.5	104,900.0	409.9	0.5	0.2	0.8
06/07/2025 18:00	4,309.5	32.4	4,309.5	104,900.0	452.1	0.5	0.3	0.9
06/07/2025 19:00	3,714.4	1.0	3,714.4	104,900.0	389.6	0.5	0.2	0.8
06/07/2025 20:00	3,671.5	0.0	3,671.5	104,900.0	385.1	0.5	0.2	0.8
06/07/2025 21:00	3,677.5	0.0	3,677.5	104,900.0	385.8	0.5	0.2	0.8
06/07/2025 22:00	3,676.9	0.0	3,676.9	104,900.0	385.7	0.5	0.2	0.8
06/07/2025 23:00	3,681.5	0.0	3,681.5	104,900.0	386.2	0.5	0.2	0.8
Average/Sum#:	3,734.4	37.0	3,734.4	104,900.0	391.7	0.5	0.2	0.8
Minimum:	3,651.9	0.0	3,651.9	104,900.0	383.1	0.5	0.2	0.8
Maximum:	4,309.5	121.3	4,309.5	104,900.0	452.1	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/08/2025 00:00	3,701.4	0.0	3,701.4	104,900.0	388.3	0.5	0.2	0.8
06/08/2025 01:00	3,702.5	0.0	3,702.5	104,900.0	388.4	0.5	0.2	0.8
06/08/2025 02:00	3,695.2	0.0	3,695.2	104,900.0	387.6	0.5	0.2	0.8
06/08/2025 03:00	3,693.9	0.0	3,693.9	104,900.0	387.5	0.5	0.2	0.8
06/08/2025 04:00	3,694.8	0.0	3,694.8	104,900.0	387.6	0.5	0.2	0.8
06/08/2025 05:00	3,700.2	0.0	3,700.2	104,900.0	388.2	0.5	0.2	0.8
06/08/2025 06:00	3,706.2	0.0	3,706.2	104,900.0	388.8	0.5	0.2	0.8
06/08/2025 07:00	3,704.8	0.0	3,704.8	104,900.0	388.6	0.5	0.2	0.8
06/08/2025 08:00	3,710.2	16.7	3,710.2	104,900.0	389.2	0.5	0.2	0.8
06/08/2025 09:00	3,718.0	54.8	3,718.0	104,900.0	390.0	0.5	0.2	0.8
06/08/2025 10:00	3,723.9	95.4	3,723.9	104,900.0	390.6	0.5	0.2	0.8
06/08/2025 11:00	3,696.0	111.0	3,696.0	104,900.0	387.7	0.5	0.2	0.8
06/08/2025 12:00	3,694.4	113.5	3,694.4	104,900.0	387.5	0.5	0.2	0.8
06/08/2025 13:00	3,701.0	91.6	3,701.0	104,900.0	388.2	0.5	0.2	0.8
06/08/2025 14:00	4,089.1	8.3	4,089.1	104,900.0	428.9	0.5	0.3	0.9
06/08/2025 15:00	3,747.5	18.9	3,747.5	104,900.0	393.1	0.5	0.2	0.8
06/08/2025 16:00	4,118.3	3.5	4,118.3	104,900.0	432.0	0.5	0.3	0.9
06/08/2025 17:00	4,086.1	2.8	4,086.1	104,900.0	428.6	0.5	0.3	0.9
06/08/2025 18:00	4,618.7	0.4	4,618.7	104,900.0	484.5	0.6	0.3	1.0
06/08/2025 19:00	4,612.6	0.0	4,612.6	104,900.0	483.9	0.6	0.3	1.0
06/08/2025 20:00	3,787.6	0.0	3,787.6	104,900.0	397.3	0.5	0.2	0.8
06/08/2025 21:00	3,928.2	0.0	3,928.2	104,900.0	412.1	0.5	0.2	0.8
06/08/2025 22:00	3,696.4	0.0	3,696.4	104,900.0	387.8	0.5	0.2	0.8
06/08/2025 23:00	3,765.3	0.0	3,765.3	104,900.0	395.0	0.5	0.2	0.8
Average/Sum#:	3,845.5	21.5	3,845.5	104,900.0	403.4	0.5	0.2	0.8
Minimum:	3,693.9	0.0	3,693.9	104,900.0	387.5	0.5	0.2	0.8
Maximum:	4,618.7	113.5	4,618.7	104,900.0	484.5	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/09/2025 00:00	3,729.0	0.0	3,729.0	104,900.0	391.2	0.5	0.2	0.8
06/09/2025 01:00	3,729.7	0.0	3,729.7	104,900.0	391.2	0.5	0.2	0.8
06/09/2025 02:00	3,732.6	0.0	3,732.6	104,900.0	391.5	0.5	0.2	0.8
06/09/2025 03:00	3,731.7	0.0	3,731.7	104,900.0	391.5	0.5	0.2	0.8
06/09/2025 04:00	3,735.6	0.0	3,735.6	104,900.0	391.9	0.5	0.2	0.8
06/09/2025 05:00	3,728.7	0.0	3,728.7	104,900.0	391.1	0.5	0.2	0.8
06/09/2025 06:00	3,726.4	0.0	3,726.4	104,900.0	390.9	0.5	0.2	0.8
06/09/2025 07:00	3,730.2	0.0	3,730.2	104,900.0	391.3	0.5	0.2	0.8
06/09/2025 08:00	3,721.7	30.3	3,721.7	104,900.0	390.4	0.5	0.2	0.8
06/09/2025 09:00	3,720.6	64.4	3,720.6	104,900.0	390.3	0.5	0.2	0.8
06/09/2025 10:00	3,702.0	100.0	3,702.0	104,900.0	388.3	0.5	0.2	0.8
06/09/2025 11:00	3,698.2	119.1	3,698.2	104,900.0	387.9	0.5	0.2	0.8
06/09/2025 12:00	3,698.4	113.6	3,698.4	104,900.0	388.0	0.5	0.2	0.8
06/09/2025 13:00	3,677.5	90.4	3,677.5	104,900.0	385.8	0.5	0.2	0.8
06/09/2025 14:00	3,673.6	63.1	3,673.6	104,900.0	385.4	0.5	0.2	0.8
06/09/2025 15:00	3,670.4	45.4	3,670.4	104,900.0	385.0	0.5	0.2	0.8
06/09/2025 16:00	3,898.2	52.8	3,898.2	104,900.0	408.9	0.5	0.2	0.8
06/09/2025 17:00	4,117.5	46.9	4,117.5	104,900.0	431.9	0.5	0.3	0.9
06/09/2025 18:00	4,613.8	131.8	4,696.8	104,900.0	492.7	0.6	0.3	1.0
06/09/2025 19:00	4,700.3	1,192.9	5,893.2	104,900.0	618.2	0.7	0.4	1.2
06/09/2025 20:00	4,705.7	499.4	5,095.2	104,900.0	534.5	0.7	0.3	1.1
06/09/2025 21:00	3,824.0	0.0	3,824.0	104,900.0	401.1	0.5	0.2	0.8
06/09/2025 22:00	3,678.9	0.0	3,678.9	104,900.0	385.9	0.5	0.2	0.8
06/09/2025 23:00	3,839.3	0.0	3,839.3	104,900.0	402.7	0.5	0.2	0.8
Average/Sum#:	3,866.0	106.3	3,935.4	104,900.0	412.8	0.5	0.2	0.8
Minimum:	3,670.4	0.0	3,670.4	104,900.0	385.0	0.5	0.2	0.8
Maximum:	4,705.7	1,192.9	5,893.2	104,900.0	618.2	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/10/2025 00:00	3,669.7	0.0	3,669.7	104,900.0	385.0	0.5	0.2	0.2	0.8	0.8
06/10/2025 01:00	3,673.7	0.0	3,673.7	104,900.0	385.4	0.5	0.2	0.2	0.8	0.8
06/10/2025 02:00	3,676.4	0.0	3,676.4	104,900.0	385.7	0.5	0.2	0.2	0.8	0.8
06/10/2025 03:00	3,684.9	0.0	3,684.9	104,900.0	386.5	0.5	0.2	0.2	0.8	0.8
06/10/2025 04:00	3,815.6	0.0	3,815.6	104,900.0	400.3	0.5	0.2	0.2	0.8	0.8
06/10/2025 05:00	3,841.8	0.0	3,841.8	104,900.0	403.0	0.5	0.2	0.2	0.8	0.8
06/10/2025 06:00	3,681.7	0.0	3,681.7	104,900.0	386.2	0.5	0.2	0.2	0.8	0.8
06/10/2025 07:00	3,686.6	0.1	3,686.6	104,900.0	386.7	0.5	0.2	0.2	0.8	0.8
06/10/2025 08:00	3,687.5	12.6	3,687.5	104,900.0	386.8	0.5	0.2	0.2	0.8	0.8
06/10/2025 09:00	3,686.1	39.3	3,686.1	104,900.0	386.7	0.5	0.2	0.2	0.8	0.8
06/10/2025 10:00	3,673.1	94.7	3,673.1	104,900.0	385.3	0.5	0.2	0.2	0.8	0.8
06/10/2025 11:00	3,677.1	107.0	3,677.1	104,900.0	385.7	0.5	0.2	0.2	0.8	0.8
06/10/2025 12:00	3,681.5	103.3	3,681.5	104,900.0	386.2	0.5	0.2	0.2	0.8	0.8
06/10/2025 13:00	3,682.9	82.2	3,682.9	104,900.0	386.3	0.5	0.2	0.2	0.8	0.8
06/10/2025 14:00	3,677.3	29.7	3,677.3	104,900.0	385.7	0.5	0.2	0.2	0.8	0.8
06/10/2025 15:00	4,010.5	28.5	4,010.5	104,900.0	420.7	0.5	0.3	0.3	0.8	0.8
06/10/2025 16:00	4,125.9	29.5	4,125.9	104,900.0	432.8	0.5	0.3	0.3	0.9	0.9
06/10/2025 17:00	4,087.3	2.8	4,087.3	104,900.0	428.8	0.5	0.3	0.3	0.9	0.9
06/10/2025 18:00	4,515.7	1.1	4,515.7	104,900.0	473.7	0.6	0.3	0.3	0.9	0.9
06/10/2025 19:00	3,775.4	0.0	3,775.4	104,900.0	396.0	0.5	0.2	0.2	0.8	0.8
06/10/2025 20:00	3,659.2	0.0	3,659.2	104,900.0	383.9	0.5	0.2	0.2	0.8	0.8
06/10/2025 21:00	3,662.5	0.0	3,662.5	104,900.0	384.2	0.5	0.2	0.2	0.8	0.8
06/10/2025 22:00	3,665.3	0.0	3,665.3	104,900.0	384.5	0.5	0.2	0.2	0.8	0.8
06/10/2025 23:00	3,669.6	0.0	3,669.6	104,900.0	384.9	0.5	0.2	0.2	0.8	0.8
Average/Sum#:	3,777.8	22.1	3,777.8	104,900.0	396.3	0.5	0.2	0.2	0.8	0.8
Minimum:	3,659.2	0.0	3,659.2	104,900.0	383.9	0.5	0.2	0.2	0.8	0.8
Maximum:	4,515.7	107.0	4,515.7	104,900.0	473.7	0.6	0.3	0.3	0.9	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/11/2025 00:00	3,689.7	0.0	3,689.7	104,900.0	387.0	0.5	0.2	0.8
06/11/2025 01:00	3,692.8	0.0	3,692.8	104,900.0	387.4	0.5	0.2	0.8
06/11/2025 02:00	3,695.8	0.0	3,695.8	104,900.0	387.7	0.5	0.2	0.8
06/11/2025 03:00	3,696.1	0.0	3,696.1	104,900.0	387.7	0.5	0.2	0.8
06/11/2025 04:00	3,686.8	0.0	3,686.8	104,900.0	386.7	0.5	0.2	0.8
06/11/2025 05:00	3,667.7	0.0	3,667.7	104,900.0	384.7	0.5	0.2	0.8
06/11/2025 06:00	3,674.7	0.0	3,674.7	104,900.0	385.5	0.5	0.2	0.8
06/11/2025 07:00	3,672.0	0.0	3,672.0	104,900.0	385.2	0.5	0.2	0.8
06/11/2025 08:00	3,684.3	0.1	3,684.3	104,900.0	386.5	0.5	0.2	0.8
06/11/2025 09:00	3,684.9	19.7	3,684.9	104,900.0	386.5	0.5	0.2	0.8
06/11/2025 10:00	3,690.8	84.5	3,690.8	104,900.0	387.2	0.5	0.2	0.8
06/11/2025 11:00	3,674.8	95.8	3,674.8	104,900.0	385.5	0.5	0.2	0.8
06/11/2025 12:00	3,670.2	94.3	3,670.2	104,900.0	385.0	0.5	0.2	0.8
06/11/2025 13:00	3,662.5	60.9	3,662.5	104,900.0	384.2	0.5	0.2	0.8
06/11/2025 14:00	3,637.8	3.6	3,637.8	104,900.0	381.6	0.5	0.2	0.8
06/11/2025 15:00	3,634.9	0.0	3,634.9	104,900.0	381.3	0.5	0.2	0.8
06/11/2025 16:00	3,632.0	3.5	3,632.0	104,900.0	381.0	0.5	0.2	0.8
06/11/2025 17:00	3,634.1	0.0	3,634.1	104,900.0	381.2	0.5	0.2	0.8
06/11/2025 18:00	3,641.2	0.0	3,641.2	104,900.0	382.0	0.5	0.2	0.8
06/11/2025 19:00	2,834.1	0.0	2,834.1	104,900.0	297.3	0.5	0.2	0.8
06/11/2025 20:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/11/2025 21:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/11/2025 22:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/11/2025 23:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,627.9	18.1	3,627.9	104,900.0	380.6	0.5	0.2	0.8
Minimum:	2,834.1	0.0	2,834.1	104,900.0	297.3	0.5	0.2	0.8
Maximum:	3,696.1	95.8	3,696.1	104,900.0	387.7	0.5	0.2	0.8
%SI	16.67	16.67	16.67	0.00	16.67	16.67	16.67	16.67

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/12/2025 00:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/12/2025 01:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/12/2025 02:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/12/2025 03:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/12/2025 04:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/12/2025 05:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/12/2025 06:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/12/2025 07:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/12/2025 08:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/12/2025 09:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/12/2025 10:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/12/2025 11:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/12/2025 12:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/12/2025 13:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/12/2025 14:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/12/2025 15:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/12/2025 16:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/12/2025 17:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/12/2025 18:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/12/2025 19:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/12/2025 20:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/12/2025 21:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/12/2025 22:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/12/2025 23:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/13/2025 00:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/13/2025 01:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/13/2025 02:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/13/2025 03:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/13/2025 04:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/13/2025 05:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/13/2025 06:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/13/2025 07:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/13/2025 08:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/13/2025 09:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/13/2025 10:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/13/2025 11:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/13/2025 12:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/13/2025 13:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/13/2025 14:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/13/2025 15:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/13/2025 16:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/13/2025 17:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/13/2025 18:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/13/2025 19:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/13/2025 20:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/13/2025 21:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/13/2025 22:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/13/2025 23:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/14/2025 00:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/14/2025 01:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/14/2025 02:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/14/2025 03:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/14/2025 04:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/14/2025 05:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/14/2025 06:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/14/2025 07:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/14/2025 08:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/14/2025 09:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/14/2025 10:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/14/2025 11:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/14/2025 12:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/14/2025 13:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/14/2025 14:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/14/2025 15:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/14/2025 16:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/14/2025 17:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/14/2025 18:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/14/2025 19:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/14/2025 20:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/14/2025 21:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/14/2025 22:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/14/2025 23:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/15/2025 00:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/15/2025 01:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/15/2025 02:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/15/2025 03:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/15/2025 04:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/15/2025 05:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/15/2025 06:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/15/2025 07:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/15/2025 08:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/15/2025 09:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/15/2025 10:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/15/2025 11:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/15/2025 12:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/15/2025 13:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/15/2025 14:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/15/2025 15:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/15/2025 16:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/15/2025 17:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/15/2025 18:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/15/2025 19:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/15/2025 20:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/15/2025 21:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/15/2025 22:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/15/2025 23:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/16/2025 00:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/16/2025 01:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/16/2025 02:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/16/2025 03:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/16/2025 04:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/16/2025 05:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/16/2025 06:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/16/2025 07:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/16/2025 08:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/16/2025 09:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/16/2025 10:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/16/2025 11:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/16/2025 12:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/16/2025 13:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/16/2025 14:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/16/2025 15:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/16/2025 16:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/16/2025 17:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/16/2025 18:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/16/2025 19:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/16/2025 20:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/16/2025 21:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/16/2025 22:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/16/2025 23:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/17/2025 00:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2025 01:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2025 02:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2025 03:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2025 04:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2025 05:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2025 06:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2025 07:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2025 08:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2025 09:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2025 10:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2025 11:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2025 12:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2025 13:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2025 14:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2025 15:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2025 16:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2025 17:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2025 18:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2025 19:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2025 20:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2025 21:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2025 22:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
06/17/2025 23:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/18/2025 00:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/18/2025 01:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/18/2025 02:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/18/2025 03:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/18/2025 04:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/18/2025 05:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/18/2025 06:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/18/2025 07:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/18/2025 08:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/18/2025 09:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/18/2025 10:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/18/2025 11:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/18/2025 12:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/18/2025 13:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/18/2025 14:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/18/2025 15:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/18/2025 16:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/18/2025 17:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/18/2025 18:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/18/2025 19:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/18/2025 20:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/18/2025 21:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/18/2025 22:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/18/2025 23:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/19/2025 00:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/19/2025 01:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/19/2025 02:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/19/2025 03:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/19/2025 04:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/19/2025 05:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/19/2025 06:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/19/2025 07:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/19/2025 08:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/19/2025 09:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/19/2025 10:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/19/2025 11:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/19/2025 12:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/19/2025 13:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/19/2025 14:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/19/2025 15:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/19/2025 16:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/19/2025 17:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/19/2025 18:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/19/2025 19:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/19/2025 20:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/19/2025 21:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/19/2025 22:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/19/2025 23:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/20/2025 00:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/20/2025 01:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/20/2025 02:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/20/2025 03:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/20/2025 04:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/20/2025 05:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/20/2025 06:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/20/2025 07:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/20/2025 08:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/20/2025 09:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/20/2025 10:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/20/2025 11:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/20/2025 12:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/20/2025 13:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/20/2025 14:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/20/2025 15:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/20/2025 16:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/20/2025 17:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/20/2025 18:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/20/2025 19:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/20/2025 20:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/20/2025 21:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/20/2025 22:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/20/2025 23:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2	
	GasFlow, _CT, 100scfh		GasFlow, _DB, 100scfh		GasFlowTotal, 100scfh		GCVGas, BtuPer100scf		HI, MBtuPerHr		> 4.73 PM10_Norm, LbPerHr		> 1 SO2_Norm, LbPerHr		> 1.8 VOC_Norm, LbPerHr			
	1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)	
06/21/2025 00:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/21/2025 01:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/21/2025 02:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/21/2025 03:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/21/2025 04:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/21/2025 05:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/21/2025 06:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/21/2025 07:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/21/2025 08:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/21/2025 09:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/21/2025 10:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/21/2025 11:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/21/2025 12:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/21/2025 13:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/21/2025 14:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/21/2025 15:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/21/2025 16:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/21/2025 17:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/21/2025 18:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/21/2025 19:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/21/2025 20:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/21/2025 21:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/21/2025 22:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/21/2025 23:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
Average/Sum#:	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
Minimum:	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
Maximum:	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
%SI	100.00		100.00		100.00		0.00		100.00		100.00		100.00		100.00		100.00	

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/22/2025 00:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/22/2025 01:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/22/2025 02:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/22/2025 03:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/22/2025 04:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/22/2025 05:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/22/2025 06:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/22/2025 07:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/22/2025 08:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/22/2025 09:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/22/2025 10:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/22/2025 11:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/22/2025 12:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/22/2025 13:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/22/2025 14:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/22/2025 15:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/22/2025 16:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/22/2025 17:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/22/2025 18:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/22/2025 19:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/22/2025 20:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/22/2025 21:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/22/2025 22:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/22/2025 23:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/23/2025 00:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/23/2025 01:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/23/2025 02:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/23/2025 03:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/23/2025 04:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/23/2025 05:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/23/2025 06:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/23/2025 07:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/23/2025 08:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/23/2025 09:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/23/2025 10:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/23/2025 11:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/23/2025 12:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/23/2025 13:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/23/2025 14:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/23/2025 15:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/23/2025 16:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/23/2025 17:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/23/2025 18:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/23/2025 19:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/23/2025 20:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/23/2025 21:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/23/2025 22:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/23/2025 23:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/24/2025 00:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/24/2025 01:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/24/2025 02:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/24/2025 03:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/24/2025 04:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/24/2025 05:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/24/2025 06:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/24/2025 07:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/24/2025 08:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/24/2025 09:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/24/2025 10:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/24/2025 11:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/24/2025 12:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/24/2025 13:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/24/2025 14:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/24/2025 15:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/24/2025 16:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/24/2025 17:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/24/2025 18:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/24/2025 19:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/24/2025 20:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/24/2025 21:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/24/2025 22:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/24/2025 23:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2	
	GasFlow, _CT, 100scfh		GasFlow, _DB, 100scfh		GasFlowTotal, 100scfh		GCVGas, BtuPer100scf		HI, MBtuPerHr		> 4.73 PM10_Norm, LbPerHr		> 1 SO2_Norm, LbPerHr		> 1.8 VOC_Norm, LbPerHr			
	1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)	
06/25/2025 00:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/25/2025 01:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/25/2025 02:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/25/2025 03:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/25/2025 04:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/25/2025 05:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/25/2025 06:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/25/2025 07:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/25/2025 08:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/25/2025 09:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/25/2025 10:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/25/2025 11:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/25/2025 12:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/25/2025 13:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/25/2025 14:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/25/2025 15:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/25/2025 16:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/25/2025 17:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/25/2025 18:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/25/2025 19:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/25/2025 20:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/25/2025 21:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/25/2025 22:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/25/2025 23:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
Average/Sum#:	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
Minimum:	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
Maximum:	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
%SI	100.00		100.00		100.00		0.00		100.00		100.00		100.00		100.00		100.00	

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2		Unit CT2	
	GasFlow, _CT, 100scfh		GasFlow, _DB, 100scfh		GasFlowTotal, 100scfh		GCVGas, BtuPer100scf		HI, MBtuPerHr		> 4.73 PM10_Norm, LbPerHr		> 1 SO2_Norm, LbPerHr		> 1.8 VOC_Norm, LbPerHr			
	1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)	
06/26/2025 00:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/26/2025 01:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/26/2025 02:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/26/2025 03:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/26/2025 04:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/26/2025 05:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/26/2025 06:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/26/2025 07:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/26/2025 08:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/26/2025 09:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/26/2025 10:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/26/2025 11:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/26/2025 12:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/26/2025 13:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/26/2025 14:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/26/2025 15:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/26/2025 16:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/26/2025 17:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/26/2025 18:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/26/2025 19:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/26/2025 20:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/26/2025 21:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/26/2025 22:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
06/26/2025 23:00	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
Average/Sum#:	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
Minimum:	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
Maximum:	0.0		0.0		0.0		104,900.0		0.0		0.0		0.0		0.0		0.0	
%SI	100.00		100.00		100.00		0.00		100.00		100.00		100.00		100.00		100.00	

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/27/2025 00:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/27/2025 01:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/27/2025 02:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/27/2025 03:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/27/2025 04:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/27/2025 05:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/27/2025 06:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/27/2025 07:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/27/2025 08:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/27/2025 09:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/27/2025 10:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/27/2025 11:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/27/2025 12:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/27/2025 13:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/27/2025 14:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/27/2025 15:00	0.0	0.0	0.0	104,900.0	0.0	0.0	0.0	0.0
06/27/2025 16:00	1,889.5	0.2	1,889.5	104,900.0	198.2	0.0	0.0	0.0
06/27/2025 17:00	4,151.7	4.0	4,151.7	104,900.0	435.5	0.6	0.3	1.0
06/27/2025 18:00	4,507.7	146.2	4,541.3	104,900.0	476.4	0.6	0.3	1.0
06/27/2025 19:00	4,609.0	1,903.3	6,512.3	104,900.0	683.1	0.8	0.4	1.4
06/27/2025 20:00	4,627.7	777.1	5,404.8	104,900.0	567.0	0.7	0.3	1.1
06/27/2025 21:00	4,399.8	275.6	4,545.9	104,900.0	476.9	0.6	0.3	1.0
06/27/2025 22:00	3,840.6	2.0	3,840.7	104,900.0	402.9	0.5	0.2	0.8
06/27/2025 23:00	3,681.9	0.0	3,681.9	104,900.0	386.2	0.5	0.2	0.8
Average/Sum#:	3,963.5	388.6	4,321.0	104,900.0	453.3	0.6	0.3	1.0
Minimum:	1,889.5	0.0	1,889.5	104,900.0	198.2	0.5	0.2	0.8
Maximum:	4,627.7	1,903.3	6,512.3	104,900.0	683.1	0.8	0.4	1.4
%SI	66.67	66.67	66.67	0.00	66.67	70.83	70.83	70.83

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/28/2025 00:00	3,674.1	0.0	3,674.1	104,900.0	385.4	0.5	0.2	0.8
06/28/2025 01:00	3,680.2	0.0	3,680.2	104,900.0	386.1	0.5	0.2	0.8
06/28/2025 02:00	3,685.0	0.0	3,685.0	104,900.0	386.6	0.5	0.2	0.8
06/28/2025 03:00	3,680.5	0.0	3,680.5	104,900.0	386.1	0.5	0.2	0.8
06/28/2025 04:00	3,677.0	0.0	3,677.0	104,900.0	385.7	0.5	0.2	0.8
06/28/2025 05:00	3,676.4	0.0	3,676.4	104,900.0	385.7	0.5	0.2	0.8
06/28/2025 06:00	3,678.3	12.4	3,678.3	104,900.0	385.9	0.5	0.2	0.8
06/28/2025 07:00	3,682.6	8.0	3,682.6	104,900.0	386.3	0.5	0.2	0.8
06/28/2025 08:00	3,675.7	66.4	3,675.7	104,900.0	385.6	0.5	0.2	0.8
06/28/2025 09:00	3,650.8	90.9	3,650.8	104,900.0	383.0	0.5	0.2	0.8
06/28/2025 10:00	3,656.4	113.6	3,656.4	104,900.0	383.6	0.5	0.2	0.8
06/28/2025 11:00	3,655.9	117.5	3,655.9	104,900.0	383.5	0.5	0.2	0.8
06/28/2025 12:00	3,805.0	115.9	3,805.0	104,900.0	399.1	0.5	0.2	0.8
06/28/2025 13:00	3,996.4	111.8	3,996.4	104,900.0	419.2	0.5	0.3	0.9
06/28/2025 14:00	4,308.8	76.4	4,308.8	104,900.0	452.0	0.6	0.3	0.9
06/28/2025 15:00	4,200.4	70.6	4,200.4	104,900.0	440.6	0.5	0.3	0.9
06/28/2025 16:00	4,396.0	78.4	4,396.0	104,900.0	461.1	0.6	0.3	0.9
06/28/2025 17:00	4,449.8	217.9	4,499.9	104,900.0	472.0	0.6	0.3	1.0
06/28/2025 18:00	4,585.0	1,878.0	6,463.0	104,900.0	678.0	0.8	0.4	1.4
06/28/2025 19:00	4,620.3	1,919.1	6,539.4	104,900.0	686.0	0.8	0.4	1.4
06/28/2025 20:00	4,642.1	1,886.1	6,528.2	104,900.0	684.8	0.8	0.4	1.4
06/28/2025 21:00	4,666.5	1,893.8	6,560.3	104,900.0	688.2	0.8	0.4	1.4
06/28/2025 22:00	4,700.0	1,899.4	6,599.4	104,900.0	692.3	0.8	0.4	1.4
06/28/2025 23:00	4,719.7	1,608.2	6,199.2	104,900.0	650.3	0.8	0.4	1.3
Average/Sum#:	4,048.5	506.9	4,507.0	104,900.0	472.8	0.6	0.3	1.0
Minimum:	3,650.8	0.0	3,650.8	104,900.0	383.0	0.5	0.2	0.8
Maximum:	4,719.7	1,919.1	6,599.4	104,900.0	692.3	0.8	0.4	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/29/2025 00:00	4,065.4	0.0	4,065.4	104,900.0	426.5	0.5	0.3	0.3	0.9	0.9
06/29/2025 01:00	3,714.0	0.0	3,714.0	104,900.0	389.6	0.5	0.2	0.2	0.8	0.8
06/29/2025 02:00	3,888.8	0.8	3,888.8	104,900.0	407.9	0.5	0.2	0.2	0.8	0.8
06/29/2025 03:00	3,675.9	0.0	3,675.9	104,900.0	385.6	0.5	0.2	0.2	0.8	0.8
06/29/2025 04:00	4,124.4	0.0	4,124.4	104,900.0	432.6	0.5	0.3	0.3	0.9	0.9
06/29/2025 05:00	3,813.0	0.0	3,813.0	104,900.0	400.0	0.5	0.2	0.2	0.8	0.8
06/29/2025 06:00	3,690.7	0.0	3,690.7	104,900.0	387.2	0.5	0.2	0.2	0.8	0.8
06/29/2025 07:00	3,687.6	3.3	3,687.6	104,900.0	386.8	0.5	0.2	0.2	0.8	0.8
06/29/2025 08:00	3,685.9	54.0	3,685.9	104,900.0	386.7	0.5	0.2	0.2	0.8	0.8
06/29/2025 09:00	3,683.6	79.6	3,683.6	104,900.0	386.4	0.5	0.2	0.2	0.8	0.8
06/29/2025 10:00	3,679.7	116.1	3,679.7	104,900.0	386.0	0.5	0.2	0.2	0.8	0.8
06/29/2025 11:00	3,662.2	123.2	3,662.2	104,900.0	384.2	0.5	0.2	0.2	0.8	0.8
06/29/2025 12:00	3,762.1	123.2	3,762.1	104,900.0	394.6	0.5	0.2	0.2	0.8	0.8
06/29/2025 13:00	4,262.1	119.6	4,276.5	104,900.0	448.6	0.6	0.3	0.3	0.9	0.9
06/29/2025 14:00	4,459.1	77.2	4,459.1	104,900.0	467.8	0.6	0.3	0.3	1.0	1.0
06/29/2025 15:00	4,455.5	72.7	4,455.5	104,900.0	467.4	0.6	0.3	0.3	1.0	1.0
06/29/2025 16:00	4,252.9	76.4	4,252.9	104,900.0	446.1	0.5	0.3	0.3	0.9	0.9
06/29/2025 17:00	4,060.1	73.7	4,060.1	104,900.0	425.9	0.5	0.3	0.3	0.9	0.9
06/29/2025 18:00	4,341.1	63.8	4,341.1	104,900.0	455.4	0.6	0.3	0.3	0.9	0.9
06/29/2025 19:00	4,328.7	31.2	4,328.7	104,900.0	454.1	0.6	0.3	0.3	0.9	0.9
06/29/2025 20:00	4,335.2	4.9	4,335.2	104,900.0	454.8	0.5	0.3	0.3	0.9	0.9
06/29/2025 21:00	4,291.5	0.0	4,291.5	104,900.0	450.2	0.5	0.3	0.3	0.9	0.9
06/29/2025 22:00	3,833.9	0.0	3,833.9	104,900.0	402.2	0.5	0.2	0.2	0.8	0.8
06/29/2025 23:00	3,787.4	0.0	3,787.4	104,900.0	397.3	0.5	0.2	0.2	0.8	0.8
Average/Sum#:	3,980.9	42.5	3,981.5	104,900.0	417.7	0.5	0.2	0.2	0.9	0.9
Minimum:	3,662.2	0.0	3,662.2	104,900.0	384.2	0.5	0.2	0.2	0.8	0.8
Maximum:	4,459.1	123.2	4,459.1	104,900.0	467.8	0.6	0.3	0.3	1.0	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/30/2025 00:00	3,641.1	0.0	3,641.1	104,900.0	382.0	0.5	0.2	0.8
06/30/2025 01:00	3,638.0	0.0	3,638.0	104,900.0	381.6	0.5	0.2	0.8
06/30/2025 02:00	3,654.2	0.0	3,654.2	104,900.0	383.3	0.5	0.2	0.8
06/30/2025 03:00	3,662.5	0.0	3,662.5	104,900.0	384.2	0.5	0.2	0.8
06/30/2025 04:00	3,666.1	0.0	3,666.1	104,900.0	384.6	0.5	0.2	0.8
06/30/2025 05:00	3,683.8	0.0	3,683.8	104,900.0	386.4	0.5	0.2	0.8
06/30/2025 06:00	3,691.3	0.0	3,691.3	104,900.0	387.2	0.5	0.2	0.8
06/30/2025 07:00	3,696.2	0.0	3,696.2	104,900.0	387.7	0.5	0.2	0.8
06/30/2025 08:00	3,783.1	13.3	3,783.1	104,900.0	396.8	0.5	0.2	0.8
06/30/2025 09:00	3,676.4	60.0	3,676.4	104,900.0	385.7	0.5	0.2	0.8
06/30/2025 10:00	3,684.7	98.4	3,684.7	104,900.0	386.5	0.5	0.2	0.8
06/30/2025 11:00	3,666.4	112.0	3,666.4	104,900.0	384.6	0.5	0.2	0.8
06/30/2025 12:00	3,919.3	114.7	3,919.3	104,900.0	411.1	0.5	0.3	0.8
06/30/2025 13:00	4,218.5	110.3	4,218.5	104,900.0	442.5	0.5	0.3	0.9
06/30/2025 14:00	3,821.4	56.4	3,821.4	104,900.0	400.9	0.5	0.2	0.8
06/30/2025 15:00	4,233.8	58.7	4,233.8	104,900.0	444.1	0.5	0.3	0.9
06/30/2025 16:00	4,326.3	69.4	4,326.3	104,900.0	453.8	0.6	0.3	0.9
06/30/2025 17:00	4,094.6	69.6	4,094.6	104,900.0	429.5	0.5	0.3	0.9
06/30/2025 18:00	4,362.0	64.1	4,362.0	104,900.0	457.6	0.6	0.3	0.9
06/30/2025 19:00	4,349.3	36.1	4,349.3	104,900.0	456.2	0.6	0.3	0.9
06/30/2025 20:00	4,345.1	6.1	4,345.1	104,900.0	455.8	0.5	0.3	0.9
06/30/2025 21:00	4,102.6	0.1	4,102.6	104,900.0	430.4	0.5	0.3	0.9
06/30/2025 22:00	3,643.6	0.0	3,643.6	104,900.0	382.2	0.5	0.2	0.8
06/30/2025 23:00	4,205.1	0.0	4,205.1	104,900.0	441.1	0.5	0.3	0.9
Average/Sum#:	3,906.9	36.2	3,906.9	104,900.0	409.8	0.5	0.2	0.8
Minimum:	3,638.0	0.0	3,638.0	104,900.0	381.6	0.5	0.2	0.8
Maximum:	4,362.0	114.7	4,362.0	104,900.0	457.6	0.6	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

CO Ppmvdc EDS/CMS Summary Report



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:12 Location: Roseville, CA
Description: Electric Utility

CMS Data from: CT1_CO_Ppmvdc_1H, CT1_UnitOn_TF_1H
EDS Data from: CT1_CO_Ppmvdc_3H, CT1_UnitOn_TF_1H
Emission Limitation: 4
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 04/09/2006 14:00
Process Unit(s) Description:
Operating time for EDS: 1,111.00 Hour(s)
Operating time for CMS: 1,111.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	1
2. Total CMS Downtime	1
3. Total Downtime as a percentage of operating time	0.09
4. Total Availability as a percentage of operating time	99.91

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

CO Lb/Hr EDS/CMS Summary Report

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59

Generated: 07/01/2025 08:12

Facility Name: ROSEVILLE ENERGY

Location: Roseville, CA

Description: Electric Utility

CMS Data from:

EDS Data from:

Emission Limitation:

No Value Exclusions Allowed

Monitor Manufacturer and Model No.:

Date of Latest CMS Certification or Audit:

Process Unit(s) Description:

Operating time for EDS:

Operating time for CMS:

CT1_CO_3Hr_LbPerHr_1H, CT1_UnitOn_TF_1H

CT1_CO_3Hr_LbPerHr_1H, CT1_UnitOn_TF_1H

6.2

TELEDYNE MONITOR LABS INC, TML30

04/09/2006 14:00

1,111.00 Hour(s)

1,111.00 Hour(s)

Emission Data Summary		CMS Performance Summary	
1. Duration of excess emission in reporting period due to:		1. CMS downtime in reporting period due to:	
a. Startup/shutdown	0	a. Monitor equipment malfunctions	0
b. Control equipment problems	0	b. Non-Monitor equipment malfunctions	0
c. Process Problems	0	c. Quality assurance calibration	0
d. Other known causes	0	d. Other known causes	0
e. Unknown causes	0	e. Unknown causes	49
2. Upset Conditions	0	2. Total CMS Downtime	49
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0	3. Total Downtime as a percentage of operating time	4.41
4. Time of Excess Emission as a percentage of operating time	0.00	4. Total Availability as a percentage of operating time	95.59
5. Time in compliance as percentage of operating time	100.00		

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

CO SUSL Lb/Hr EDS/CMS Summary Report



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 12:49 Location: Roseville, CA
Description: Electric Utility

CMS Data from: CT1_CO_SUSL_LbPerHr_1H, CT1_UnitOn_TF_1H
EDS Data from: CT1_CO_SUSL_LbPerHr_1H, CT1_UnitOn_TF_1H
Emission Limitation: 89.5
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 04/09/2006 14:00
Process Unit(s) Description:
Operating time for EDS: 1,111.00 Hour(s)
Operating time for CMS: 1,111.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	77
2. Total CMS Downtime	77
3. Total Downtime as a percentage of operating time	6.93
4. Total Availability as a percentage of operating time	93.07

NOx Ppmvdc EDS/CMS Summary Report



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:12 Location: Roseville, CA
Description: Electric Utility

CMS Data from: CT1_NOx_Ppmvdc_1H, CT1_UnitOn_TF_1H
EDS Data from: CT1_NOx_Ppmvdc_1H, CT1_UnitOn_TF_1H
Emission Limitation: 2.0
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-02
Date of Latest CMS Certification or Audit: 04/09/2006 14:00
Process Unit(s) Description:
Operating time for EDS: 1,111.00 Hour(s)
Operating time for CMS: 1,111.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	1
2. Total CMS Downtime	1
3. Total Downtime as a percentage of operating time	0.09
4. Total Availability as a percentage of operating time	99.91

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

NOx Lb/Hr EDS/CMS Summary Report



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:12 Location: Roseville, CA
Description: Electric Utility

CMS Data from: CT1_NOx_Norm_LbPerHr_1H, CT1_UnitOn_TF_1H
EDS Data from: CT1_NOx_Norm_LbPerHr_1H, CT1_UnitOn_TF_1H
Emission Limitation: 5.1
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-02
Date of Latest CMS Certification or Audit: 04/09/2006 14:00
Process Unit(s) Description:
Operating time for EDS: 1,111.00 Hour(s)
Operating time for CMS: 1,111.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	23
2. Total CMS Downtime	23
3. Total Downtime as a percentage of operating time	2.07
4. Total Availability as a percentage of operating time	97.93

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

NOx SUSD Lb/Hr EDS/CMS Summary Report



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:12 Location: Roseville, CA
Description: Electric Utility

CMS Data from: CT1_NOx_SUSD_LbPerHr_1H, CT1_UnitOn_TF_1H
EDS Data from: CT1_NOx_SUSD_LbPerHr_1H, CT1_UnitOn_TF_1H
Emission Limitation: 37.1
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-02
Date of Latest CMS Certification or Audit: 04/09/2006 14:00
Process Unit(s) Description:
Operating time for EDS: 1,111.00 Hour(s)
Operating time for CMS: 1,111.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	77
2. Total CMS Downtime	77
3. Total Downtime as a percentage of operating time	6.93
4. Total Availability as a percentage of operating time	93.07

CO Ppmvdc EDS/CMS Summary Report

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59

Generated: 07/01/2025 08:14

Facility Name: ROSEVILLE ENERGY

Location: Roseville, CA

Description: Electric Utility

CMS Data from:

EDS Data from:

Emission Limitation:

No Value Exclusions Allowed

Monitor Manufacturer and Model No.:

Date of Latest CMS Certification or Audit:

Process Unit(s) Description:

Operating time for EDS:

Operating time for CMS:

CT2_CO_Ppmvdc_1H, CT2_UnitOn_TF_1H

CT2_CO_Ppmvdc_3H, CT2_UnitOn_TF_1H

4

TELEDYNE MONITOR LABS INC, TML30

04/10/2006 07:00

1,300.00 Hour(s)

1,300.00 Hour(s)

Emission Data Summary		CMS Performance Summary	
1. Duration of excess emission in reporting period due to:		1. CMS downtime in reporting period due to:	
a. Startup/shutdown	0	a. Monitor equipment malfunctions	0
b. Control equipment problems	0	b. Non-Monitor equipment malfunctions	0
c. Process Problems	0	c. Quality assurance calibration	0
d. Other known causes	0	d. Other known causes	0
e. Unknown causes	0	e. Unknown causes	4
2. Upset Conditions	0	2. Total CMS Downtime	4
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0	3. Total Downtime as a percentage of operating time	0.31
4. Time of Excess Emission as a percentage of operating time	0.00	4. Total Availability as a percentage of operating time	99.69
5. Time in compliance as percentage of operating time	100.00		

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

CO Lb/Hr EDS/CMS Summary Report

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59

Generated: 07/01/2025 08:14

Facility Name: ROSEVILLE ENERGY

Location: Roseville, CA

Description: Electric Utility

CMS Data from:

EDS Data from:

Emission Limitation:

No Value Exclusions Allowed

Monitor Manufacturer and Model No.:

Date of Latest CMS Certification or Audit:

Process Unit(s) Description:

Operating time for EDS:

Operating time for CMS:

CT2_CO_3Hr_LbPerHr_1H, CT2_UnitOn_TF_1H

CT2_CO_3Hr_LbPerHr_1H, CT2_UnitOn_TF_1H

6.2

TELEDYNE MONITOR LABS INC, TML30

04/10/2006 07:00

1,300.00 Hour(s)

1,300.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	21
2. Total CMS Downtime	21
3. Total Downtime as a percentage of operating time	1.62
4. Total Availability as a percentage of operating time	98.38

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

CO SUSL Lb/Hr EDS/CMS Summary Report



CT2

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:14 Location: Roseville, CA
Description: Electric Utility

CMS Data from: CT2_CO_SUSL_LbPerHr_1H, CT2_UnitOn_TF_1H
EDS Data from: CT2_CO_SUSL_LbPerHr_1H, CT2_UnitOn_TF_1H
Emission Limitation: 89.5
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 04/10/2006 07:00
Process Unit(s) Description:
Operating time for EDS: 1,300.00 Hour(s)
Operating time for CMS: 1,300.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
f. Report function is being updated to reflect actual pounds	0
g. TABLE 53.A.1.ii: EQUIPMENT PROTECTION CAUSING RAPID UNLOAD	2
h. EQUIPMENT PROTECTION CAUSING RAPID UNLOAD	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	2
4. Time of Excess Emission as a percentage of operating time	0.15
5. Time in compliance as percentage of operating time	99.85

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	88
2. Total CMS Downtime	88
3. Total Downtime as a percentage of operating time	6.77
4. Total Availability as a percentage of operating time	93.23

NOx Ppmvdc EDS/CMS Summary Report



CT2

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:14 Location: Roseville, CA
Description: Electric Utility

CMS Data from: CT2_NOx_Ppmvdc_1H, CT2_UnitOn_TF_1H
EDS Data from: CT2_NOx_Ppmvdc_1H, CT2_UnitOn_TF_1H
Emission Limitation: 2.0
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 04/10/2006 07:00
Process Unit(s) Description:
Operating time for EDS: 1,300.00 Hour(s)
Operating time for CMS: 1,300.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	2
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	2
4. Time of Excess Emission as a percentage of operating time	0.15
5. Time in compliance as percentage of operating time	99.85

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	4
2. Total CMS Downtime	4
3. Total Downtime as a percentage of operating time	0.31
4. Total Availability as a percentage of operating time	99.69

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

NOx Lb/Hr EDS/CMS Summary Report



CT2

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:14 Location: Roseville, CA
Description: Electric Utility

CMS Data from: CT2_NOx_Norm_LbPerHr_1H, CT2_UnitOn_TF_1H
EDS Data from: CT2_NOx_Norm_LbPerHr_1H, CT2_UnitOn_TF_1H
Emission Limitation: 5.1
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 04/10/2006 07:00
Process Unit(s) Description:
Operating time for EDS: 1,300.00 Hour(s)
Operating time for CMS: 1,300.00 Hour(s)

Emission Data Summary	
-----------------------	--

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
-------------------------	--

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	9
2. Total CMS Downtime	9
3. Total Downtime as a percentage of operating time	0.69
4. Total Availability as a percentage of operating time	99.31

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

NOx SUSD Lb/Hr EDS/CMS Summary Report



CT2

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 12:49 Location: Roseville, CA
Description: Electric Utility

CMS Data from: CT2_NOx_SUSD_LbPerHr_1H, CT2_UnitOn_TF_1H
EDS Data from: CT2_NOx_SUSD_LbPerHr_1H, CT2_UnitOn_TF_1H
Emission Limitation: 37.1
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-02
Date of Latest CMS Certification or Audit: 04/10/2006 07:00
Process Unit(s) Description:
Operating time for EDS: 1,300.00 Hour(s)
Operating time for CMS: 1,300.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	88
2. Total CMS Downtime	88
3. Total Downtime as a percentage of operating time	6.77
4. Total Availability as a percentage of operating time	93.23

CO Invalid Data

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Tag Name: CT1_CO_Ppm_1H
Total Operating Time: 1,111.00 Hour(s)
Non-Operating Time: 1,097.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	05/19/2025 06:00	05/19/2025 06:59	1	3 - Quality assurance calibration	5 - Performed online calibration when unit was stable

Total Operating Time:	1,111.00 Hour(s)
Total Monitor Downtime (Online only):	1.00 Hour(s)
Percent Monitor Availability:	99.91 %
Percent Monitor Downtime:	0.09 %

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	1	100.00
5	Action	Performed online calibration when unit was stable	1	100.00

NOx Invalid Data

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Tag Name: CT1_NOx_Ppm_1H
Total Operating Time: 1,111.00 Hour(s)
Non-Operating Time: 1,097.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	05/19/2025 06:00	05/19/2025 06:59	1	3 - Quality assurance calibration	5 - Performed online calibration when unit was stable

Total Operating Time:	1,111.00 Hour(s)
Total Monitor Downtime (Online only):	1.00 Hour(s)
Percent Monitor Availability:	99.91 %
Percent Monitor Downtime:	0.09 %

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	1	100.00
5	Action	Performed online calibration when unit was stable	1	100.00

NOx SCR Invalid Data



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Tag Name: CT1_NOx_SCR_Ppm_1H
Total Operating Time: 1,111.00 Hour(s)
Non-Operating Time: 1,097.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	05/02/2025 02:00	05/02/2025 02:59	1	3 - Quality assurance calibration	
2	05/02/2025 03:00	05/02/2025 03:59	1		
3	05/02/2025 04:00	05/02/2025 04:59	1		
4	05/02/2025 05:00	05/02/2025 05:59	1		
5	05/02/2025 06:00	05/02/2025 06:59	1		
6	05/02/2025 07:00	05/02/2025 07:59	1		
7	05/02/2025 08:00	05/02/2025 08:59	1		
8	05/02/2025 09:00	05/02/2025 09:59	1		
9	05/02/2025 10:00	05/02/2025 10:59	1		
10	05/02/2025 11:00	05/02/2025 11:59	1		
11	05/02/2025 12:00	05/02/2025 12:59	1		
12	05/02/2025 13:00	05/02/2025 13:59	1		
13	05/02/2025 14:00	05/02/2025 14:59	1		
14	05/02/2025 15:00	05/02/2025 15:59	1		
15	05/07/2025 08:00	05/07/2025 08:59	1		
16	05/07/2025 09:00	05/07/2025 09:59	1		
17	05/07/2025 10:00	05/07/2025 10:59	1		
18	05/07/2025 11:00	05/07/2025 11:59	1		
19	05/07/2025 12:00	05/07/2025 12:59	1		
20	05/07/2025 13:00	05/07/2025 13:59	1		
21	05/07/2025 14:00	05/07/2025 14:59	1		
22	05/07/2025 15:00	05/07/2025 15:59	1		
23	05/07/2025 16:00	05/07/2025 16:59	1		
24	05/07/2025 17:00	05/07/2025 17:59	1		
25	05/07/2025 18:00	05/07/2025 18:59	1		
26	05/07/2025 19:00	05/07/2025 19:59	1		

NOx SCR Invalid Data

CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA



Tag Name: CT1_NOx_SCR_Ppm_1H
Total Operating Time: 1,111.00 Hour(s)
Non-Operating Time: 1,097.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
27	05/07/2025 20:00	05/07/2025 20:59	1		
28	05/07/2025 21:00	05/07/2025 21:59	1		
29	05/07/2025 22:00	05/07/2025 22:59	1		
30	05/07/2025 23:00	05/07/2025 23:59	1		
31	05/08/2025 00:00	05/08/2025 00:59	1		
32	05/08/2025 01:00	05/08/2025 01:59	1		
33	05/08/2025 02:00	05/08/2025 02:59	1	3 - Quality assurance calibration	
34	05/08/2025 03:00	05/08/2025 03:59	1		
35	05/08/2025 04:00	05/08/2025 04:59	1		
36	05/08/2025 05:00	05/08/2025 05:59	1		

Total Operating Time:	1,111.00 Hour(s)
Total Monitor Downtime (Online only):	36.00 Hour(s)
Percent Monitor Availability:	96.76 %
Percent Monitor Downtime:	3.24 %

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	2	5.56

02 Invalid Data

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Tag Name: CT1_O2Dry_Pct_1H
Total Operating Time: 1,111.00 Hour(s)
Non-Operating Time: 1,097.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	05/19/2025 06:00	05/19/2025 06:59	1	3 - Quality assurance calibration	5 - Performed online calibration when unit was stable

Total Operating Time:	1,111.00 Hour(s)
Total Monitor Downtime (Online only):	1.00 Hour(s)
Percent Monitor Availability:	99.91 %
Percent Monitor Downtime:	0.09 %

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	1	100.00
5	Action	Performed online calibration when unit was stable	1	100.00

CO Invalid Data

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Tag Name: CT2_CO_Ppm_1H
Total Operating Time: 1,300.00 Hour(s)
Non-Operating Time: 908.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	05/20/2025 06:00	05/20/2025 06:59	1	23 - Maintenance	

Total Operating Time:	1,300.00 Hour(s)
Total Monitor Downtime (Online only):	1.00 Hour(s)
Percent Monitor Availability:	99.92 %
Percent Monitor Downtime:	0.08 %

Report Code	Type	Text	Duration	Duration Percent
23	Reason	Maintenance	1	100.00

NOx Invalid Data

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:15 Location: Roseville, CA

Tag Name: CT2_NOx_Ppm_1H
Total Operating Time: 1,300.00 Hour(s)
Non-Operating Time: 908.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	04/02/2025 09:00	04/02/2025 09:59	1		
2	04/02/2025 10:00	04/02/2025 10:59	1		
3	04/02/2025 11:00	04/02/2025 11:59	1	3 - Quality assurance calibration	
4	05/20/2025 06:00	05/20/2025 06:59	1	23 - Maintenance	

Total Operating Time:	1,300.00 Hour(s)
Total Monitor Downtime (Online only):	4.00 Hour(s)
Percent Monitor Availability:	99.69 %
Percent Monitor Downtime:	0.31 %

Report Code	Type	Text	Duration	Duration Percent
23	Reason	Maintenance	1	25.00
3	Reason	Quality assurance calibration	1	25.00

NOx SCR Invalid Data



CT2

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Tag Name: CT2_NOx_SCR_Ppm_1H
Total Operating Time: 1,300.00 Hour(s)
Non-Operating Time: 908.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	1,300.00 Hour(s)
Total Monitor Downtime (Online only):	0.00 Hour(s)
Percent Monitor Availability:	100.00 %
Percent Monitor Downtime:	0.00 %

02 Invalid Data

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Tag Name: CT2_O2Dry_Pct_1H
Total Operating Time: 1,300.00 Hour(s)
Non-Operating Time: 908.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	04/02/2025 09:00	04/02/2025 09:59	1		
2	04/02/2025 10:00	04/02/2025 10:59	1		
3	04/02/2025 11:00	04/02/2025 11:59	1	3 - Quality assurance calibration	
4	05/20/2025 06:00	05/20/2025 06:59	1	23 - Maintenance	

Total Operating Time:	1,300.00 Hour(s)
Total Monitor Downtime (Online only):	4.00 Hour(s)
Percent Monitor Availability:	99.69 %
Percent Monitor Downtime:	0.31 %

Report Code	Type	Text	Duration	Duration Percent
23	Reason	Maintenance	1	25.00
3	Reason	Quality assurance calibration	1	25.00

AQ-36 thru AQ-38, AQ-41, & AQ-117

AQ-36 thru AQ-38, AQ-41, & AQ-117: PCAPCD notifications/
corrective action: breakdowns, excess emissions, CEMS inoperable, or a
negative declaration when no excess emissions occurred.

Verification: The Project owner shall include the identification of all
breakdowns, PCAPCD notification, resulting excess emission (if any) and
corrective actions taken (if any) as part of the Quarterly Air Quality
Report required in Condition of Certification AQ-SC6

Daily Calibration Results

All Units

From: 03/19/2025 00:00 To: 03/19/2025 23:00 Facility Name: ROSEVILLE ENERGY

Generated: 04/03/2025 06:36 Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/19/25 02:14	200.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/19/25 02:24	200.0	182.2	178.9	R-A /Span * 100		1.7
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/19/25 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/19/25 02:19	30.0	21.0	20.7	R-A /Span * 100		1.0
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/19/25 03:14	200.0	0.0	1.1	R-A /Span * 100		0.6
	High	03/19/25 03:24	200.0	177.6	178.5	R-A /Span * 100		0.5
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/19/25 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	03/19/25 03:19	10.0	9.1	9.2	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	03/19/25 03:14	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	03/19/25 03:24	200.0	182.2	180.9	R-A /Span * 100		0.7
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	03/19/25 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/19/25 03:19	10.0	9.5	9.6	R-A /Span * 100		1.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	03/19/25 03:14	18.0	18.0	18.0	R-A		0.0
	Zero	03/19/25 03:19	18.0	0.0	0.0	R-A		0.0
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Offline	Pass	
	Zero	03/19/25 07:34	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	03/19/25 07:44	200.0	180.1	175.1	R-A /Span * 100		2.5
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Offline	Pass	
	Zero	03/19/25 07:34	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	03/19/25 07:39	10.0	9.1	9.3	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Offline	offline	
	Zero	03/19/25 07:34	200.0	0.0	0.3	off R-A /Span * 100		0.2
	High	03/19/25 07:44	200.0	179.9	181.7	off R-A /Span * 100		0.9
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Offline	offline	
	Zero	03/19/25 07:34	10.0	0.0	0.0	off R-A /Span * 100		0.0
	High	03/19/25 07:39	10.0	9.6	9.7	off R-A /Span * 100		1.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Offline	offline	
	High	03/19/25 07:34	21.0	18.0	18.0	off R-A		0.0
	Zero	03/19/25 07:39	21.0	0.0	0.0	off R-A		0.0

POST



Daily Calibration Results

All Units

From: 04/02/2025 00:00 To: 04/02/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/03/2025 06:27 Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	04/02/25 02:14	200.0	0.0	-0.1	R-A /Span * 100		0.1
	High	04/02/25 02:24	200.0	182.2	179.6	R-A /Span * 100		1.3
Part 60	CT1_NOXInlet_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	04/02/25 02:14	30.0	0.0	0.0	R-A /Span * 100		0.0
	High	04/02/25 02:19	30.0	21.0	20.8	R-A /Span * 100		0.7
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	04/02/25 03:14	200.0	0.0	1.1	R-A /Span * 100		0.6
	High	04/02/25 03:24	200.0	177.6	179.9	R-A /Span * 100		1.2
Part 60	CT1_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	04/02/25 03:14	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	04/02/25 03:19	10.0	9.1	9.2	R-A /Span * 100		1.0
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	04/02/25 03:14	200.0	0.0	0.1	R-A /Span * 100		0.1
	High	04/02/25 03:24	200.0	182.2	181.6	R-A /Span * 100		0.3
Part 75	CT1_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	04/02/25 03:14	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	04/02/25 03:19	10.0	9.5	9.7	R-A /Span * 100		2.0
Part 75	CT1_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	04/02/25 03:14	18.0	18.0	18.0	R-A		0.0
	Zero	04/02/25 03:19	18.0	0.0	-0.1	R-A		0.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	04/02/25 11:49	200.0	0.0	0.6	R-A /Span * 100		0.3
	High	04/02/25 11:59	200.0	180.1	182.3	R-A /Span * 100		1.1
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	04/02/25 11:49	10.0	0.0	0.2	R-A /Span * 100		2.0
	High	04/02/25 11:54	10.0	9.1	9.2	R-A /Span * 100		1.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	04/02/25 11:49	200.0	0.0	0.2	R-A /Span * 100		0.1
	High	04/02/25 11:59	200.0	179.9	179.6	R-A /Span * 100		0.2
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	04/02/25 11:49	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	04/02/25 11:54	10.0	9.6	9.6	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	04/02/25 11:49	21.0	18.0	17.1	R-A		0.9
	Zero	04/02/25 11:54	21.0	0.0	0.1	R-A		0.1

Post



Daily Calibration Results

All Units

From: 04/02/2025 00:00 To: 04/02/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/03/2025 06:27 Location: Roseville, CA

All Monitoring Sites, All Instruments, Daily Calibrations

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Deviation
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	04/02/25 13:35	200.0	0.0	0.5	R-A /Span * 100		0.3
	High	04/02/25 13:45	200.0	180.1	178.8	R-A /Span * 100		0.7
Part 60	CT2_CODualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	04/02/25 13:35	10.0	0.0	0.1	R-A /Span * 100		1.0
	High	04/02/25 13:40	10.0	9.1	8.9	R-A /Span * 100		2.0
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	Zero	04/02/25 13:35	200.0	0.0	0.3	R-A /Span * 100		0.2
	High	04/02/25 13:45	200.0	179.9	179.3	R-A /Span * 100		0.3
Part 75	CT2_NOXDualRg_P_Instrument	Used For QA	Range: Low			Calibration Result: Online	Pass	
	Zero	04/02/25 13:35	10.0	0.0	0.0	R-A /Span * 100		0.0
	High	04/02/25 13:40	10.0	9.6	9.6	R-A /Span * 100		0.0
Part 75	CT2_O2D_P_Instrument	Used For QA	Range: High			Calibration Result: Online	Pass	
	High	04/02/25 13:35	21.0	18.0	18.0	R-A		0.0
	Zero	04/02/25 13:40	21.0	0.0	0.0	R-A		0.0

Sample Spreadsheet Listing

	CT2_SUSD_TF_1M		CT2_CO_SUSD_Lbs_1M		CT2_NOx_SUSD_Lbs_1M		CT2_GasFlow_CT_scfh_1M		CT2_Load_CT_MWe_1M		CT2_ExhaustFlow_LbPerHr_1M	
Date/Time	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
04/02/25 9:40	0		0		0		0		0		253343.5	X
04/02/25 9:41	0		0		0		0		0		251974.1	X
04/02/25 9:42	0		0		0		0		0		254712.9	X
04/02/25 9:43	0		0		0		0		0		254712.9	X
04/02/25 9:44	1		0	X	0	X	4615.2		0		321814.7	X
04/02/25 9:45	1		0	X	0	X	18807.3		0		479298.5	X
04/02/25 9:46	1		0.06	X	0	X	30746.7		0		634914.9	X
04/02/25 9:47	1		1.62	X	0.01	X	44003.1		0		493753.6	X
04/02/25 9:48	1		3.53	X	0.04	X	55827		0		423973.8	X
04/02/25 9:49	1		5.01	X	0.1	X	67812.6		0		441150.3	X
04/02/25 9:50	1		6.48	X	0.21	X	91125.3		0		542103.2	X
04/02/25 9:51	1		8.19	X	0.41	X	138952.2		0		730212.4	X
04/02/25 9:52	1		9.7	X	0.61	X	153929.9		0		708970.6	X
04/02/25 9:53	1		13.55	X	0.79	X	148373.2		0		631376.7	X
04/02/25 9:54	1		23.41	X	0.97	X	148026.6		0		630295.6	X
04/02/25 9:55	1		34.41	X	1.16	X	146813.6		0		660747.3	X
04/02/25 9:56	1		45.04	X	1.34	X	147137.1		0		643629.5	X
04/02/25 9:57	1		55.7	X	1.52	X	145704.6		0		656182.5	X
04/02/25 9:58	1		66.95	X	1.71	X	155108.2		0.9		693841.7	X
04/02/25 9:59	1		79.08	X	1.92	X	172523.5		3.8		743190.3	X
04/02/25 10:00	1		90.82	X	2.12	X	178074.4		4.9		707650.1	X
04/02/25 10:01	1		101.72	X	2.3	X	178230.4		5		658597.6	X
04/02/25 10:02	1		111.89	X	2.48	X	178218.8		5		643629.5	X
04/02/25 10:03	1		121.69	X	2.66	X	178698.2		5.1		644874.4	X
04/02/25 10:04	1		131.29	X	2.84	X	177756.7		4.9		642073.3	X
04/02/25 10:05	1		140.98	X	3.02	X	178923.5		5.1		645808.1	X
04/02/25 10:06	1		150.87	X	3.2	X	176399.3		5		652546.6	X
04/02/25 10:07	1		160.9	X	3.38	X	176133.6		5		651272.8	X
04/02/25 10:08	1		170.84	X	3.56	X	176064.3		5		636471.1	X
04/02/25 10:09	1		181.05	X	3.74	X	175140.1		5		648406.5	X
04/02/25 10:10	1		191.36	X	3.92	X	175688.8		5		649998.9	X
04/02/25 10:11	1		201.42	X	4.1	X	175411.6		4.8		634292.5	X

	CT2_SUSD_TF_1M			CT2_CO_SUSD_Lbs_1M			CT2_NOx_SUSD_Lbs_1M			CT2_GasFlow_CT_scfh_1M			CT2_Load_CT_MWe_1M			CT2_ExhaustFlow_LbPerHr_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
04/02/25 10:12	1			211.44	X		4.28	X		174932.2			4.9			632425.1	X	
04/02/25 10:13	1			221.71	X		4.46	X		175174.8			5			648088.1	X	
04/02/25 10:14	1			231.98	X		4.64	X		175203.6			5			648088.1	X	
04/02/25 10:15	1			242.18	X		4.82	X		175787			5			649998.9	X	
04/02/25 10:16	1			252.12	X		5	X		173794.2			5			643629.5	X	
04/02/25 10:17	1			261.98	X		5.18	X		173372.6			5			642355.6	X	
04/02/25 10:18	1			271.89	X		5.36	X		174262.1			5			645858.8	X	
04/02/25 10:19	1			281.77	X		5.54	X		174423.9			5			645858.8	X	
04/02/25 10:20	1			291.96	X		5.73	X		181586.3			5.9			670381	X	
04/02/25 10:21	1			302.4	X		5.93	X		201109.9			8.7			719259	X	
04/02/25 10:22	1			307.59	X		6.14	X		222949.7			11.7			740654.6	X	
04/02/25 10:23	1			308.58	X		6.34	X		230689.8			12.8			704313.8	X	
04/02/25 10:24	1			308.78	X		6.53	X		232156.9			13			669242.8	X	
04/02/25 10:25	1			308.93	X		6.71	X		231001.7			12.9			653837.9	X	
04/02/25 10:26	1			309.08	X		6.89	X		232370.7			13			657572.7	X	
04/02/25 10:27	1			309.23	X		7.08	X		231371.4			13.2			667467.6	X	
04/02/25 10:28	1			309.37	X		7.26	X		230476.1			13			652593	X	
04/02/25 10:29	1			309.52	X		7.45	X		231954.8			13			668735.6	X	
04/02/25 10:30	1			309.67	X		7.63	X		231486.9			12.9			655580.8	X	
04/02/25 10:31	1			309.82	X		7.81	X		231683.3			13.1			656078.8	X	
04/02/25 10:32	1			309.96	X		7.99	X		231810.4			13.1			656078.8	X	
04/02/25 10:33	1			310.09	X		8.17	X		230759.1			13			653339.9	X	
04/02/25 10:34	1			310.22	X		8.35	X		230042.9			13			651597	X	
04/02/25 10:35	1			310.35	X		8.53	X		229829.1			13			651099	X	
04/02/25 10:36	1			310.48	X		8.71	X		227911.5			13			645870.3	X	
04/02/25 10:37	1			310.61	X		8.89	X		230591.6			13			653090.9	X	
04/02/25 10:38	1			310.74	X		9.08	X		241912.9			14.3			682720.3	X	
04/02/25 10:39	1			310.81	X		9.28	X		264960			17.1			730196.6	X	
04/02/25 10:40	1			310.83	X		9.49	X		292737.7			20.2			761075	X	
04/02/25 10:41	1			310.84	X		9.7	X		319331.3			23.4			761528.3	X	
04/02/25 10:42	1			310.85	X		9.9	X		329156.7			24.9			716795.8	X	
04/02/25 10:43	1			310.86	X		10.09	X		331010.8			25			681566.2	X	
04/02/25 10:44	1			310.88	X		10.28	X		329335.7			25.1			678420.2	X	
04/02/25 10:45	1			310.9	X		10.5	X		330225.3			25.1			679900.7	X	
04/02/25 10:46	1			310.92	X		10.64	X		331351.6			25			682121.4	X	

	CT2_SUSD_TF_1M			CT2_CO_SUSD_Lbs_1M			CT2_NOx_SUSD_Lbs_1M			CT2_GasFlow_CT_scfh_1M			CT2_Load_CT_MWe_1M			CT2_ExhaustFlow_LbPerHr_1M		
Date/Time	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
04/02/25 10:47	1			310.93	X		10.74	X		327088.8			25			683023.9	X	
04/02/25 10:48	1			310.94	X		10.83	X		328394.2			25			685650.2	X	
04/02/25 10:49	1			310.95	X		10.9	X		328613.7			25			686025.3	X	
04/02/25 10:50	1			310.96	X		10.97	X		330051.9			25.1			688839.2	X	
04/02/25 10:51	1			310.97	X		11.03	X		328151.6			25.1			685087.4	X	
04/02/25 10:52	1			310.98	X		11.09	X		329387.7			25			687526.1	X	
04/02/25 10:53	1			310.99	X		11.14	X		329341.5			25			687526.1	X	
04/02/25 10:54	1			311	X		11.19	X		328688.8			25			686212.9	X	
04/02/25 10:55	1			311.01	X		11.23	X		328613.7			25			686025.3	X	
04/02/25 10:56	1			311.02	X		11.27	X		328636.8			25			686400.5	X	
04/02/25 10:57	1			311.03	X		11.31	X		327880.1			25			684712.2	X	
04/02/25 10:58	1			311.04	X		11.34	X		328451.9			25			685837.7	X	
04/02/25 10:59	1			311.05	X		11.37	X		329532.1			24.9			687713.7	X	
04/02/25 11:00	1			311.06	X		11.4	X		327712.6			25			694031.9	X	
04/02/25 11:01	1			311.07	X		11.43	X		330404.3			25.3			699357.4	X	
04/02/25 11:02	1			311.08	X		11.46	X		346046.3			27.5			720729.9	X	
04/02/25 11:03	1			311.09	X		11.49	X		368556.1			30.2			765564.5	X	
04/02/25 11:04	1			311.1	X		11.52	X		386733.8			33			801394.7	X	
04/02/25 11:05	0			0			0			409289.8			35.7			857792.2	X	
04/02/25 11:06	0			0			0			422679.1			37.4			884610.1	X	
04/02/25 11:07	0			0			0			422863.9			37.8			884990.5	X	
04/02/25 11:08	0			0			0			425705.8			38			890696.4	X	
04/02/25 11:09	0			0			0			426502.9			38.1			892218	X	
04/02/25 11:10	0			0			0			426872.6			38.1			893169	X	



2025 007

Year

Non-Compliance
Event Number

110 Maple Street, Auburn, CA 95603 • (530) 745-2330 • Fax (530) 745-2373 • www.placer.ca.gov/apcd

Erik C. White, Air Pollution Control Officer

NON-COMPLIANCE EVENT NOTIFICATION FORM – PART I

submit within 2 business hours after detection of the Non-Compliance Event

1. Company Name	ROSEVILLE ENERGY PARK	Address	5120 PHILLIP ROAD, ROSEVILLE, CA.					
2. Title V Source Status	Major Yes ☒ No ☐	Synthetic Minor	Yes ☐ No ☒					
3. For Title V Sources, is the Non-Compliance Event the Result of an Emergency under District Rule 507, Section 402.2(l)	Yes ☐ No ☒							
4. Emission Exceedances	NOx ☐	SOx ☐	PM ☐	VOC ☐	CO ☒	Opacity ☐	None ☐	check all that apply
5. CEMS / COMS / CMS Breakdown	Yes ☐ No ☒							
6. Detection of Non-Compliance Event	Date	4/2/25	Time	14:00	☐ AM ☒ PM			
7. Start of Non-Compliance Event	Date	4/2/25	Time	11:00	☒ AM ☐ PM ☐ Not known			
8. Violation	Permit No. REPR-20-02	Condition No. 51	Rule	Section				
9. Unit / Equipment Involved	CT2							
10. Description / Cause of Non-Compliance Event	HIGH CO DURING TUNING AT LOW LOAD					☒ additional information attached		
11. Immediate Corrective Actions	RAISED LOAD, COMPLETED TUNING RUN					☒ additional information attached		
12. Was the Non-Compliance Event an Emission Violation or Monitoring Equipment Failure or Malfunction	Yes ☐ No ☒							
If yes, do you Request that the Violation, Failure or Malfunction be Shielded from Enforcement Action as an Upset / Breakdown Pursuant to District Rule 404								
Yes ☐		No ☒		Not Able to Determine at this Time ☐		If "Yes", complete and submit the Upset / Breakdown Checklist Form with Part I		
13. Submitted By	TONY JOHNSON		Telephone	(916) 295 - 9804				
Signature			Date	4/3/25	Time	11:30	☒ AM ☐ PM	

NON-COMPLIANCE EVENT NOTIFICATION FORM – PART II

submit within 7 calendar days after end of the Non-Compliance Event

14. End of Non-Compliance Event	Date	4/2/25	Time	12:00	☐ AM ☒ PM		
15. Duration of Non-Compliance Event	Hours	Minutes		64			
16. Excess Emissions Estimates	NOx	SOx	PM				
VOC	CO 311 LBS	Opacity	%, for	minutes	Other		
17. Variance in Effect	Yes ☒ Variance # 2501		No ☐				
18. Corrective and Preventative Actions Taken	(a) Minimize Emissions RAISED LOAD		(b) Correct Event		(c)		
Prevent Future Events	☐ additional information attached						
19. If Not Able to Determine in Item 12 of Part I, Was the Non-Compliance Event an Emission Violation or Monitoring Equipment Failure or Malfunction	If yes, do you Request that the Violation, Failure or Malfunction be Shielded from Enforcement Action as an Upset / Breakdown Under District Rule 404						
Yes ☐		No ☒		If "Yes", complete and submit the Upset / Breakdown Checklist Form if not previously submitted with Part I			
20. Submitted By	TONY JOHNSON		Telephone	(916) 295 - 9804			
I certify under penalty of law that I am the responsible official for this facility, or his/her duly designated representative, and based on information and belief formed after reasonable inquiry, the statements and information in this document are true, accurate, and complete.							
Signature			Date	4/3/25	Time	11:30	☒ AM ☐ PM

CO LbPerHr SUSd 1-Hour Block Excess Emissions

CT2

From: 04/25/2025 00:00 **To:** 04/25/2025 08:03 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/25/2025 08:04 **Location:** Roseville, CA



Tag Name: CT2_CO_SUSD_LbPerHr_1H

Total Operating Time: 2.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 7.00 Hour(s) Report Time: 9.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Tag Value	Limit	Reason Code	Action Code
1	04/25/25 06:00	04/25/25 06:59	1	104.0	89.5	19 - COMMISSIONING	13 - MINIMIZED EMISSIONS, RECORDED DATA FOR VARIANCE REPORT
2	04/25/25 07:00	04/25/25 07:59	1	244.7	89.5	19 - COMMISSIONING	13 - MINIMIZED EMISSIONS, RECORDED DATA FOR VARIANCE REPORT

Total Operating Time:	2.00 Hour(s)
Total Duration (Online only):	2.00 Hour(s)
Time in exceedance as a percentage of operating time:	100.00 %
Time in compliance as a percentage of operating time:	0.00 %

Report Code	Type	Text	Duration	Duration Percent
19	Reason	COMMISSIONING	2	100.00
13	Action	MINIMIZED EMISSIONS, RECORDED DATA FOR VARIANCE REPORT	2	100.00

Sample Spreadsheet Listing

	CT2_ExhaustFlow_LbPerHr_1M		CT2_CO_SUSD_Lbs_1M		CT2_Load_CT_MWe_1M		CT2_CO_Ppmvdc_1M		CT2_NH3Inj_LbPerHr_1M		CT2_UnitOn_TF_1M	
Date/Time	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
04/25/25 6:37	0		0		0		0		0		0	
04/25/25 6:38	0		0		0		0		0		0	
04/25/25 6:39	0		0		0		0		0		0	
04/25/25 6:40	0		0		0		0		0		0	
04/25/25 6:41	0		0		0		0		0		0	
04/25/25 6:42	0		0		0		0		0		0	
04/25/25 6:43	0		0		0		-0.1		0		1	
04/25/25 6:44	0		0		0		-0.1		0		1	
04/25/25 6:45	1369424.4		1.69		0		1135.8		0		1	
04/25/25 6:46	523315.7		4.07		0		1194.3		0		1	
04/25/25 6:47	498318.3		6.01		0		794.5		0		1	
04/25/25 6:48	563518.1		7.68		0		543.4		0		1	
04/25/25 6:49	806656.2		9.72		0		442.5		0		1	
04/25/25 6:50	938626.3		11.78		0		336.3		0		1	
04/25/25 6:51	817252.9		13.69		0.8		306.4		0		1	
04/25/25 6:52	854520.8		25.38		3.7		1673.8		0		1	
04/25/25 6:53	821226.7		39.07		4.8		1912.5		0		1	
04/25/25 6:54	749662		51.03		5		1673.1		0		1	
04/25/25 6:55	724653.7		62.07		5.1		1553.3		0		1	
04/25/25 6:56	723132.2		72.47		5.1		1466.6		0		1	
04/25/25 6:57	720089		82.7		4.9		1448.5		0		1	
04/25/25 6:58	720089		93.13		4.9		1476.3		0		1	
04/25/25 6:59	735967.8		103.99		5.1		1548		0		1	
04/25/25 7:00	737141.6		115.15		5.1		1587.6		0		1	
04/25/25 7:01	734402.7		126.49		5.1		1618.8		0		1	
04/25/25 7:02	731272.6		137.88		5		1633.6		0		1	
04/25/25 7:03	735185.3		149.36		5		1637.3		0		1	
04/25/25 7:04	728533.8		160.86		4.9		1655.9		0		1	
04/25/25 7:05	728533.8		172.49		5.1		1673.7		0		1	
04/25/25 7:06	727751.2		184.14		5		1678.1		0		1	
04/25/25 7:07	747544.6		196.17		5.1		1737		0		1	
04/25/25 7:08	728925		208		4.9		1701.6		0		1	

	CT2_ExhaustFlow_LbPerHr_1M		CT2_CO_SUSD_Lbs_1M		CT2_Load_CT_MWe_1M		CT2_CO_Ppmvdc_1M		CT2_NH3Inj_LbPerHr_1M		CT2_UnitOn_TF_1M	
Date/Time	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
04/25/25 7:09	747544.6		220.16		5		1756.1		0		1	
04/25/25 7:10	748350.1		232.31		5		1753.3		0		1	
04/25/25 7:11	723056.1		243.99		5		1693.8		0		1	
04/25/25 7:12	728142.5		255.8		4.9		1701.2		0		1	
04/25/25 7:13	743114.1		267.8		5		1744		0		1	
04/25/25 7:14	740697.5		279.81		5		1750		0		1	
04/25/25 7:15	740697.5		291.83		5		1751.6		0		1	
04/25/25 7:16	721882.3		303.41		5		1682.7		0		1	
04/25/25 7:17	720317.2		314.65		4.9		1636.8		0		1	
04/25/25 7:18	760030.5		326.28		5.6		1652		0		1	
04/25/25 7:19	813829.3		338.6		8.1		1588.1		0		1	
04/25/25 7:20	862367.2		346.16		11.5		870.2		0		1	
04/25/25 7:21	818788.4		347.92		14.2		184		0		1	
04/25/25 7:22	821654.6		348.13		17		20.1		0		1	
04/25/25 7:23	814280.8		348.18		20.2		4.3		0		1	
04/25/25 7:24	792613.4		348.21		23.3		2.6		0		1	
04/25/25 7:25	788614.5		348.24		26.4		2.4		0		1	
04/25/25 7:26	771106.8		348.27		29.2		2.3		0		1	
04/25/25 7:27	758465.5		348.3		29.9		2.1		0		1	
04/25/25 7:28	770648.5		348.33		30.2		2.1		0		1	
04/25/25 7:29	775014.8		348.36		30.1		2		0		1	
04/25/25 7:30	769060.8		348.38		30.2		1.7		0		1	
04/25/25 7:31	771045.5		348.4		30		1.5		0		1	
04/25/25 7:32	765488.4		348.42		30		1.5		0		1	
04/25/25 7:33	759931.3		348.44		29.7		1.5		0		1	
04/25/25 7:34	729419.9		348.46		27.4		1.5		0		1	
04/25/25 7:35	698406.4		348.48		25.2		1.3		0		1	
04/25/25 7:36	705560.1		348.49		25		1.1		0.9		1	
04/25/25 7:37	708012.8		348.5		25		0.9		25.3		1	
04/25/25 7:38	723097.6		348.51		25.1		0.9		50.1		1	
04/25/25 7:39	720815.2		348.52		25		0.8		12		1	
04/25/25 7:40	718117.8		348.53		25		0.6		0.3		1	
04/25/25 7:41	714175.6		348.54		25		0.6		0		1	
04/25/25 7:42	717080.4		348.55		25		0.6		0		1	
04/25/25 7:43	719570.3		348.56		24.9		0.6		0.1		1	

	CT2_ExhaustFlow_LbPerHr_1M		CT2_CO_SUSD_Lbs_1M		CT2_Load_CT_MWe_1M		CT2_CO_Ppmvdc_1M		CT2_NH3Inj_LbPerHr_1M		CT2_UnitOn_TF_1M	
Date/Time	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
04/25/25 7:44	716872.9		348.57		25		0.5		0		1	
04/25/25 7:45	719985.2		348.58		25		0.6		0.3		1	
04/25/25 7:46	719570.3		348.59		25.1		0.7		8.3		1	
04/25/25 7:47	716250.5		348.6		25		0.7		20.8		1	
04/25/25 7:48	718532.8		348.61		24.9		0.7		27.1		1	
04/25/25 7:49	734854.2		348.62		25.2		0.7		14.8		1	
04/25/25 7:50	726427		348.63		25.2		0.7		11.9		1	
04/25/25 7:51	718325.3		348.64		25		0.6		16		1	
04/25/25 7:52	718532.8		348.65		25		0.6		22.9		1	
04/25/25 7:53	720400.2		348.66		25		0.6		27.2		1	
04/25/25 7:54	718325.3		348.67		25		0.6		27.5		1	
04/25/25 7:55	732326		348.68		25.1		0.6		31.6		1	
04/25/25 7:56	713968.1		348.69		25		0.6		28.1		1	
04/25/25 7:57	717495.4		348.7		25		0.7		20.8		1	
04/25/25 7:58	717495.4		348.71		25		0.6		12.9		1	
04/25/25 7:59	716457.9		348.72		25		0.5		6		1	
04/25/25 8:00	717910.4		348.73		25		0.5		3.4		1	
04/25/25 8:01	715005.5		348.74		25		0.6		1.2		1	
04/25/25 8:02	717287.9		348.75		25		0.6		0.2		1	
04/25/25 8:03	716043		348.76		25		0.6		0.3		1	
04/25/25 8:04	719570.3		348.77		25		0.5		0.1		1	
04/25/25 8:05	716872.9		0		24.8		0.5		0		1	
04/25/25 8:06	713345.6		0		24.9		0.5		0.2		1	
04/25/25 8:07	720400.2		0		25.1		0.6		1		1	
04/25/25 8:08	714798		0		25.1		0.5		7.7		1	



110 Maple Street, Auburn, CA 95603 • (530) 745-2330 • Fax (530) 745-2373 • www.placer.ca.gov/apcd

Erik C. White, Air Pollution Control Officer

| | | | - | | 2 0 2 5 0 0 8

Year

Non-Compliance
Event Number**NON-COMPLIANCE EVENT NOTIFICATION FORM – PART I**

submit within 2 business hours after detection of the Non-Compliance Event

1. Company Name	ROSEVILLE ENERGY PARK -	Address	5120 PHILLIP ROAD, ROSEVILLE, CA.						
2. Title V Source Status	Major Yes ☒ No ☐	Synthetic Minor	Yes ☐ No ☒						
3. For Title V Sources, is the Non-Compliance Event the Result of an Emergency under District Rule 507, Section 402.2(l)	Yes ☐ No ☒								
4. Emission Exceedances	NOx ☐	SOx ☐	PM ☐	VOC ☐	CO ☒	Opacity ☐	None ☐	check all that apply	
5. CEMS / COMS / CMS Breakdown	Yes ☐ No ☒								
6. Detection of Non-Compliance Event	Date	4/25/25	Time	08:30	☒ AM ☐ PM				
7. Start of Non-Compliance Event	Date	4/25/25	Time	08:00	☒ AM ☐ PM ☐ Not known				
8. Violation	Permit No. REPR-20-02	Condition No. 51	Rule	Section					
9. Unit / Equipment Involved	CT2								
10. Description / Cause of Non-Compliance Event	Hi CO during low load hold checking for gas leaks							☒	
additional information attached									
11. Immediate Corrective Actions	fixed leaks, raised load							☒ additional information attached	
12. Was the Non-Compliance Event an Emission Violation or Monitoring Equipment Failure or Malfunction	Yes ☐ No ☒								
If yes, do you Request that the Violation, Failure or Malfunction be Shielded from Enforcement Action as an Upset / Breakdown Pursuant to District Rule 404									
Yes ☐		No ☒		Not Able to Determine at this Time ☒		If "Yes", complete and submit the Upset / Breakdown Checklist Form with Part I			
13. Submitted By	TONY JOHNSON			Telephone	(916) 295 - 9804				
Signature				Date	4/25/25	Time	10:30	☒ AM ☐ PM	

NON-COMPLIANCE EVENT NOTIFICATION FORM – PART II

submit within 7 calendar days after end of the Non-Compliance Event

14. End of Non-Compliance Event	Date	4/25/25	Time	09:05	☒ AM ☐ PM			
15. Duration of Non-Compliance Event	Hours	1	Minutes	7				
16. Excess Emissions Estimates	NOx		SOx		PM			
	VOC	CO 259.2 lbs	Opacity	%	for	minutes	Other	
17. Variance in Effect	Yes ☒ Variance # 25-01		No ☐					
18. Corrective and Preventative Actions Taken	(a) Minimize Emissions raised load (b) Correct Event (c)							
Prevent Future Events ☐ additional information attached								
19. If Not Able to Determine in Item 12 of Part I, Was the Non-Compliance Event an Emission Violation or Monitoring Equipment Failure or Malfunction	If yes, do you Request that the Violation, Failure or Malfunction be Shielded from Enforcement Action as an Upset / Breakdown Under District Rule 404							
Yes ☐		No ☒		If "Yes", complete and submit the Upset / Breakdown Checklist Form if not previously submitted with Part I				
20. Submitted By	Tony Johnson			Telephone	(916) 295 - 9804			
I certify under penalty of law that I am the responsible official for this facility, or his/her duly designated representative, and based on information and belief formed after reasonable inquiry, the statements and information in this document are true, accurate, and complete.								
Signature				Date	4/25/25	Time	10:30	☒ AM ☐ PM

NOx Ppmvdc 1-Hour Block Excess Emissions

CT2

From: 05/16/2025 00:00 To: 05/16/2025 22:48

Generated: 05/19/2025 06:04

Facility Name:

ROSEVILLE ENERGY

Location:

Roseville, CA



Tag Name: CT2_NOx_Ppmvdc_1H

Total Operating Time: 23.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 0.00 Hour(s) Report Time: 23.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Tag Value	Limit	Reason Code	Action Code
1	05/16/25 11:00	05/16/25 11:59	1	2.6	2.0	2 - Control equipment problems	22 - REPAIR CT2 SCR AMONIA HEATER THERMO-COUPLE
2	05/16/25 12:00	05/16/25 12:59	1	2.2	2.0	2 - Control equipment problems	22 - REPAIR CT2 SCR AMONIA HEATER THERMO-COUPLE

Total Operating Time:	23.00 Hour(s)
Total Duration (Online only):	2.00 Hour(s)
Time in exceedance as a percentage of operating time:	8.70 %
Time in compliance as a percentage of operating time:	91.30 %

Report Code	Type	Text	Duration	Duration Percent
2	Reason	Control equipment problems	2	100.00
22	Action	REPAIR CT2 SCR AMONIA HEATER THERMO-COUPLE	2	100.00

Sample Spreadsheet Listing

CT2_ExhaustFlow_LbPerHr_1M			CT2_Load_CT_MWe_1M			CT2_NOx_Ppmvdc_1M			CT2_NH3Inj_LbPerHr_1M			_None		
Date/Time	Value	SI Modc	Value	SI Modc		Value	SI Modc		Value	SI Modc		Value	SI Modc	
05/16/25 11:20	851782		31.6			1.54			5					
05/16/25 11:21	854520.8		31.7			1.54			6					
05/16/25 11:22	858313.1		31.9			1.54			5.9					
05/16/25 11:23	859787.8		32			1.54			7.4					
05/16/25 11:24	855363.5		31.7			1.54			8.4					
05/16/25 11:25	850728.6		31.5			1.63			11.3					
05/16/25 11:26	849043.1		31.2			1.54			8.1					
05/16/25 11:27	850939.2		31.4			1.54			7.2					
05/16/25 11:28	850939.2		31.6			1.54			4.9					
05/16/25 11:29	854731.5		31.7			1.45			3.6					
05/16/25 11:30	860209.2		32			1.45			5.4					
05/16/25 11:31	858945.1		32			1.45			3					
05/16/25 11:32	844685.9		31.7			1.52			0					
05/16/25 11:33	854520.8		31.6			1.54			0					
05/16/25 11:34	851360.6		31.6			1.72			0					
05/16/25 11:35	847779		31.3			1.91			0					
05/16/25 11:36	831199.1		31.1			2.06			0					
05/16/25 11:37	851360.6		31.6			2.27			0					
05/16/25 11:38	851571.3		31.6			2.45			0					
05/16/25 11:39	851571.3		31.7			2.72			0					
05/16/25 11:40	843648.4		31.7			2.86			0					
05/16/25 11:41	859155.8		32.1			3.18			0					
05/16/25 11:42	861473.3		32			3.36			0					
05/16/25 11:43	854731.5		31.7			3.81			0					
05/16/25 11:44	851992.6		31.6			4.18			0					
05/16/25 11:45	847568.4		31.2			4.18			0					
05/16/25 11:46	845672.2		31.3			4.27			0					
05/16/25 11:47	834726.4		31.4			4.29			0					
05/16/25 11:48	841781		31.5			4.47			0					
05/16/25 11:49	857259.7		32			4.63			0					
05/16/25 11:50	859155.8		32.1			4.81			0					
05/16/25 11:51	851360.6		31.6			4.9			0					

	CT2_ExhaustFlow_LbPerHr_1M	CT2_Load_CT_MWe_1M	CT2_NOx_Ppmvdc_1M	CT2_NH3Inj_LbPerHr_1M	_None					
Date/Time	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
05/16/25 11:52	833689		31.1		5.01		0			
05/16/25 11:53	824559.5		31		5.18		0			
05/16/25 11:54	831199.1		30.9		5.27		0			
05/16/25 11:55	847989.7		31.6		5.45		0			
05/16/25 11:56	852414		31.6		5.45		0			
05/16/25 11:57	841781		31.7		5.36		0			
05/16/25 11:58	857470.3		32		5.63		0			
05/16/25 11:59	851571.3		31.7		5.72		0			
05/16/25 12:00	833896.5		31.3		5.9		0			
05/16/25 12:01	839351.8		31.2		6.08		0			
05/16/25 12:02	843986.8		31.4		6.08		0			
05/16/25 12:03	847147		31.4		6.08		8.9			
05/16/25 12:04	840615.9		31		6.08		0			
05/16/25 12:05	835980.9		30.6		6.17		0			
05/16/25 12:06	822069.6		30.5		6.08		0			
05/16/25 12:07	837034.3		31		6.26		0			
05/16/25 12:08	839773.2		31.1		6.26		0			
05/16/25 12:09	842722.7		31.3		6.26		0			
05/16/25 12:10	842722.7		31.1		6.26		0			
05/16/25 12:11	823937		30.8		6.26		0			
05/16/25 12:12	834716.8		30.6		6.44		0			
05/16/25 12:13	825596.9		30.6		6.35		3			
05/16/25 12:14	825389.4		30.7		6.26		18.8			
05/16/25 12:15	830991.6		30.9		4.83		28.1			
05/16/25 12:16	845882.9		31.2		3.27		34.3			
05/16/25 12:17	840194.5		30.9		2.27		34			
05/16/25 12:18	831978		30.5		1.91		33.8			
05/16/25 12:19	831345.9		30.3		1.27		33.7			
05/16/25 12:20	836823.6		30.6		1.18		33.4			
05/16/25 12:21	835138.2		30.7		1.09		33			
05/16/25 12:22	842933.4		30.9		1		32.9			
05/16/25 12:23	845040.2		30.9		0.82		30.8			
05/16/25 12:24	837034.3		30.7		0.73		21.5			
05/16/25 12:25	835348.9		30.5		0.64		21.6			
05/16/25 12:26	845040.2		30.9		0.64		21.9			

	CT2_ExhaustFlow_LbPerHr_1M		CT2_Load_CT_MWe_1M		CT2_NOx_Ppmvdc_1M		CT2_NH3Inj_LbPerHr_1M		_None			
Date/Time	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
05/16/25 12:27	847989.7		31.2		0.54		21.9					
05/16/25 12:28	840615.9		30.8		0.54		21.7					
05/16/25 12:29	837245		30.6		0.54		21.6					
05/16/25 12:30	828396.4		30.4		0.54		21.8					
05/16/25 12:31	832651.5		30.9		0.54		22					
05/16/25 12:32	846936.3		31.2		0.45		22					
05/16/25 12:33	869268.5		32.5		0.45		22.1					
05/16/25 12:34	910140.5		34.9		0.45		22.1					
05/16/25 12:35	975928.8		37.5		0.46		21.8					



| | | | - | | 2 0 2 5 0 1 1

Year

Non-Compliance
Event Number

110 Maple Street, Auburn, CA 95603 • (530) 745-2330 • Fax (530) 745-2373 • www.placer.ca.gov/apcd

Erik C. White, Air Pollution Control Officer

NON-COMPLIANCE EVENT NOTIFICATION FORM – PART I

submit within 2 business hours after detection of the Non-Compliance Event

1. Company Name	ROSEVILLE ENERGY PARK -	Address	5120 PHILLIP ROAD, ROSEVILLE, CA.				
2. Title V Source Status	Major Yes ☒ No ☐	Synthetic Minor	Yes ☐ No ☒				
3. For Title V Sources, is the Non-Compliance Event the Result of an Emergency under District Rule 507, Section 402.2(l)	Yes ☐ No ☒						
4. Emission Exceedances	NOx ☒	SOx ☐	PM ☐	VOC ☐	CO ☐	Opacity ☐ None ☐ check all that apply	
5. CEMS / COMS / CMS Breakdown	Yes ☐ No ☒						
6. Detection of Non-Compliance Event	Date	5/16/25	Time	12:31	☐ AM ☒ PM		
7. Start of Non-Compliance Event	Date	5/16/25	Time	12:38	☐ AM ☒ PM ☐ Not known		
8. Violation	Permit No. REPR-20-02	Condition No. 49	Rule	Section			
9. Unit / Equipment Involved	CT2						
10. Description / Cause of Non-Compliance Event	NH3 heater thermocouple failed, closing supply valve					☐	
additional information attached							
11. Immediate Corrective Actions	Replaced thermocouple and controller, returned to service					☒ additional information attached	
12. Was the Non-Compliance Event an Emission Violation or Monitoring Equipment Failure or Malfunction	Yes ☒ No ☐						
If yes, do you Request that the Violation, Failure or Malfunction be Shielded from Enforcement Action as an Upset / Breakdown Pursuant to District Rule 404							
Yes ☒		No ☐	Not Able to Determine at this Time ☐		If "Yes", complete and submit the Upset / Breakdown Checklist Form with Part I		
13. Submitted By	TONY JOHNSON		Telephone	(916) 295 - 9804			
Signature	<i>Tony Johnson</i>		Date	5/19/25	Time	08:00 ☒ AM ☐ PM	

NON-COMPLIANCE EVENT NOTIFICATION FORM – PART II

submit within 7 calendar days after end of the Non-Compliance Event

14. End of Non-Compliance Event	Date	5/16/25	Time	13:18	☐ AM ☒ PM	
15. Duration of Non-Compliance Event	Hours	Minutes		40		
16. Excess Emissions Estimates	NOx 2.6 ppm	SOx	PM			
	VOC	CO	Opacity	%, for	minutes	Other
17. Variance in Effect	Yes ☐ Variance #		No ☒			
18. Corrective and Preventative Actions Taken	(a) Minimize Emissions thermocouple and controller		(b) Correct Event replaced		(c) Prevent Future Events ☐ additional information attached	
19. If Not Able to Determine in Item 12 of Part I, Was the Non-Compliance Event an Emission Violation or Monitoring Equipment Failure or Malfunction	If yes, do you Request that the Violation, Failure or Malfunction be Shielded from Enforcement Action as an Upset / Breakdown Under District Rule 404					
Yes ☒		No ☐	If "Yes", complete and submit the Upset / Breakdown Checklist Form if not previously submitted with Part I			
20. Submitted By	Tony Johnson		Telephone	(916) 295 - 9804		
I certify under penalty of law that I am the responsible official for this facility, or his/her duly designated representative, and based on information and belief formed after reasonable inquiry, the statements and information in this document are true, accurate, and complete.						
Signature	<i>Tony Johnson</i>		Date	5/19/25	Time	08:00 ☒ AM ☐ PM

UPSET / BREAKDOWN AND EMERGENCY CHECKLIST

Non-Compliance
Event Number

Company Name	ROSEVILLE ENERGY PARK	Address	5120 PHILLIP ROAD, ROSEVILLE.		
Detection of Non-Compliance Event	Date	5/16/25	Time	12:31	☐ AM ☒ PM

Complete the following questions associated with determining whether an event is an "Upset/Breakdown" Event pursuant to Rule 404, and/or an "Emergency" Event pursuant to Rule 507. To be considered as a legitimate Upset / Breakdown or Emergency event, all of the checklist questions must be answered with a "Yes" checkmark.

Yes No

- | | | |
|-------------------------------------|--------------------------|--|
| ☒ | ☐ | 1. Equipment associated with the breakdown event have been designed, maintained, and operated in a manner consistent with minimizing emissions. |
| ☒ | ☐ | 2. The amount and duration of emissions as a result of the event have been minimized. |
| ☒ | ☐ | 3. The event is not part of a recurring pattern of previous breakdowns of the same equipment for same/similar reasons that are indicative of inadequate equipment design, operation, or maintenance. |
| ☒ | ☐ | 4. The event is not the result of operator error, negligence, carelessness, or willful misconduct (i.e., the facility is being properly operated). |
| ☒ | ☐ | 5. The event is not the result of improper equipment design. |
| ☒ | ☐ | 6. The event is not the result of improper preventative maintenance of equipment. |
| ☒ | ☐ | 7. The event is the result of a sudden, unavoidable breakdown of equipment, beyond the control of the operator. |
| ☒ | ☐ | 8. The event could not have been foreseen or avoided or planned for, and could not have been avoided or prevented by better operating and maintenance practices. |
| ☒ | ☐ | 9. The event has not resulted in a nuisance. |
| ☒ | ☐ | 10. The event is not the result of the disregard of air pollution rules or regulations. |
| ☒ | ☐ | 11. This Upset / Breakdown form has been completed and submitted to the District in a timely manner -- within 7 calendar days from the end of the Non-Compliance Event. |
| ☒ | ☐ | 12. Immediate corrective actions have been taken to minimize emissions, as described in Item 11 on the Part I Non-Compliance Event Notification Form. |

I certify under penalty of law that I am the responsible official for this facility, or his/her duly designated representative, and based on information and belief formed after reasonable inquiry, the statements and information in this document are true, accurate, and complete.

Signature



You are requesting that the District not take enforcement action because the Non-Compliance Event is the result of an "Upset / Breakdown" Event under District Rule 404. A breakdown condition means an unforeseeable failure or malfunction of 1) any air pollution control equipment or related operating equipment which causes a violation of any emission limitations or restriction prescribed by the District Rules and Regulations, or by State law, or 2) any in-stack continuous monitoring equipment, where such failure or malfunction: (1) is not the result of neglect or disregard of any air pollution control law or rule or regulation; (2) is not intentional or the result of negligence; (3) is not the result of improper maintenance; (4) does not constitute a nuisance; (5) is not a recurrent breakdown of the same equipment. You have the burden of providing sufficient information to demonstrate that the Upset / Breakdown was an unforeseeable equipment failure or malfunction that meets the above listed criteria. This checklist must be completed and returned to the District with either the Part 1 or Part II Non-Compliance Event Notification form to attest to your having made this determination. Submission of a request for shielding from enforcement action does not by itself confer such a shield. If breakdown or emission exceeding operations continue after the breakdown or emission exceedance is identified, the possibility exists that the District after consideration of the information provided, the timeliness and completeness of the submittals, and a comparison to other like breakdowns, may ultimately determine that the Non-Compliance Event was not the result of a legitimate Upset / Breakdown event and may elect to take enforcement action. Action to return to compliance should be accomplished as expeditiously as possible. Thus, you are advised to: (1) assure that the breakdown meets the criteria for an unforeseeable failure or malfunction; (2) minimize emissions resulting from the event to the maximum degree possible; and (3) assure that the required failure and malfunction information and information on the corrective actions taken is provided to the District in a complete and timely manner.

Excess Emission Report



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 08:15 **Location:** Roseville, CA

Tag Name: ALL_CO_Lb_1D
Total Operating Time: 91.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 1.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	91.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 12:59 **Location:** Roseville, CA

Tag Name: ALL_NOX_Lb_1D
Total Operating Time: 91.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 1.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	91.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 12:59 **Location:** Roseville, CA

Tag Name: ALL_PM10_Lb_1D
Total Operating Time: 91.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 1.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	91.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 12:59 **Location:** Roseville, CA

Tag Name: ALL_SO2_Lb_1D
Total Operating Time: 91.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 1.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	91.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 04/01/2025 00:00 **To:** 06/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2025 13:00 **Location:** Roseville, CA

Tag Name: ALL_VOC_Lb_1D
Total Operating Time: 91.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 1.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	91.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO LbPerHr 3-Hour Rolling Excess Emissions

CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:17 Location: Roseville, CA



Tag Name: CT1_CO_3Hr_LbPerHr_1H
Total Operating Time: 1,111.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,097.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,111.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO Ppmvdc 3-Hour Block Excess Emissions



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:17 Location: Roseville, CA

Tag Name: CT1_CO_Ppmvdc_3H
Total Operating Time: 1,111.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,097.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,111.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO LbPerHr SUSd 1-Hour Block Excess Emissions



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:17 Location: Roseville, CA

Tag Name: CT1_CO_SUSD_LbPerHr_1H
Total Operating Time: 1,111.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,097.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,111.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NH3 Slip Ppmvdc 1-Hour Block Excess Emissions



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:17 Location: Roseville, CA

Tag Name: CT1_NH3Slip_Ppmvdc_1H
Total Operating Time: 1,111.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,097.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,111.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx LbPerHr 1-Hour Block Excess Emissions

CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:17 Location: Roseville, CA



Tag Name: CT1_NOx_Norm_LbPerHr_1H
Total Operating Time: 1,111.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,097.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,111.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx Ppmvdc 1-Hour Block Excess Emissions



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:17 Location: Roseville, CA

Tag Name: CT1_NOx_Ppmvdc_1H
Total Operating Time: 1,111.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,097.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,111.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx LbPerHr SUSd 1-Hour Block Excess Emissions



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:17 Location: Roseville, CA

Tag Name: CT1_NOx_SUSd_LbPerHr_1H
Total Operating Time: 1,111.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,097.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,111.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

PM10 LbPerHr 1-Hour Block Excess Emissions



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:17 Location: Roseville, CA

Tag Name: CT1_PM10_Norm_LbPerHr_1H
Total Operating Time: 1,111.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,097.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,111.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

S02 LbPerHr 1-Hour Block Excess Emissions



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:17 Location: Roseville, CA

Tag Name: CT1_S02_Norm_LbPerHr_1H
Total Operating Time: 1,111.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,097.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,111.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

VOC LbPerHr 1-Hour Block Excess Emissions



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:17 Location: Roseville, CA

Tag Name: CT1_VOC_Norm_LbPerHr_1H
Total Operating Time: 1,111.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 1,097.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,111.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO LbPerHr 3-Hour Rolling Excess Emissions

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:19 Location: Roseville, CA

Tag Name: CT2_CO_3Hr_LbPerHr_1H
Total Operating Time: 1,300.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 908.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,300.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO Ppmvdc 3-Hour Block Excess Emissions

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:19 Location: Roseville, CA

Tag Name: CT2_CO_Ppmvdc_3H
Total Operating Time: 1,300.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 908.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,300.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO LbPerHr SUSd 1-Hour Block Excess Emissions

CT2

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:19 Location: Roseville, CA



Tag Name: CT2_CO_SUSd_LbPerHr_1H
Total Operating Time: 1,300.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 908.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Tag Value	Limit	Reason Code	Action Code
1	04/25/25 06:00	04/25/25 06:59	1	103.6	89.5	19 - COMMISSIONING	13 - MINIMIZED EMISSIONS, RECORDED DATA FOR VARIANCE REPORT
2	04/25/25 07:00	04/25/25 07:59	1	243.8	89.5	19 - COMMISSIONING	13 - MINIMIZED EMISSIONS, RECORDED DATA FOR VARIANCE REPORT

Total Operating Time:	1,300.00 Hour(s)
Total Duration (Online only):	2.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.15 %
Time in compliance as a percentage of operating time:	99.85 %

Report Code	Type	Text	Duration	Duration Percent
19	Reason	COMMISSIONING	2	100.00
13	Action	MINIMIZED EMISSIONS, RECORDED DATA FOR VARIANCE REPORT	2	100.00

NH3 Slip Ppmvdc 1-Hour Block Excess Emissions



CT2

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:19 Location: Roseville, CA

Tag Name: CT2_NH3Slip_Ppmvdc_1H
Total Operating Time: 1,300.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 908.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,300.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx LbPerHr 1-Hour Block Excess Emissions

CT2

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:19 Location: Roseville, CA



Tag Name: CT2_NOx_Norm_LbPerHr_1H
Total Operating Time: 1,300.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 908.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,300.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx Ppmvdc 1-Hour Block Excess Emissions

CT2

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:19 Location: Roseville, CA



Tag Name: CT2_NOx_Ppmvdc_1H

Total Operating Time: 1,300.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 908.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Tag Value	Limit	Reason Code	Action Code
1	05/16/25 11:00	05/16/25 11:59	1	2.6	2.0	2 - Control equipment problems	22 - REPAIR CT2 SCR AMONIA HEATER THERMO-COUPLE
2	05/16/25 12:00	05/16/25 12:59	1	2.2	2.0	2 - Control equipment problems	22 - REPAIR CT2 SCR AMONIA HEATER THERMO-COUPLE

Total Operating Time:	1,300.00 Hour(s)
Total Duration (Online only):	2.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.15 %
Time in compliance as a percentage of operating time:	99.85 %

Report Code	Type	Text	Duration	Duration Percent
2	Reason	Control equipment problems	2	100.00
22	Action	REPAIR CT2 SCR AMONIA HEATER THERMO-COUPLE	2	100.00

NOx LbPerHr SUSd 1-Hour Block Excess Emissions



CT2

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:19 Location: Roseville, CA

Tag Name: CT2_NOx_SUSd_LbPerHr_1H
Total Operating Time: 1,300.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 908.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,300.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

PM10 LbPerHr 1-Hour Block Excess Emissions

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:19 Location: Roseville, CA

Tag Name: CT2_PM10_Norm_LbPerHr_1H
Total Operating Time: 1,300.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 908.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,300.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

S02 LbPerHr 1-Hour Block Excess Emissions

CT2



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:19 Location: Roseville, CA

Tag Name: CT2_S02_Norm_LbPerHr_1H
Total Operating Time: 1,300.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 908.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,300.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

VOC LbPerHr 1-Hour Block Excess Emissions

CT2

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:19 Location: Roseville, CA



Tag Name: CT2_VOC_Norm_LbPerHr_1H
Total Operating Time: 1,300.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 908.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,300.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

AQ-40

AQ-40 The Project owner shall comply with the applicable requirements for quality assurance testing and maintenance of the continuous emission monitor equipment in accordance with the procedures and guidance specified in 40 CFR Part 60, Appendix F.

Verification: The Project owner shall include all CEMS quality assurance test failures that required corrective action as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

Cylinder Gas Audit

07/06/2025

Page 1

Facility: ROSEVILLE ENERGY

Unit/Stack: CT1

Parameter/Scale: CO / High

Test Date: 05/01/2025

Test Result: **Pass**

Instrument Name: CT1_CODualRg_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
05/01/2025	08:44	L	200	50.200	46.600	25.1 %
05/01/2025	08:49	M	200	109.000	107.900	54.5 %
05/01/2025	09:01	L	200	50.200	46.500	25.1 %
05/01/2025	09:06	M	200	109.000	107.900	54.5 %
05/01/2025	09:18	L	200	50.200	46.600	25.1 %
05/01/2025	09:23	M	200	109.000	107.900	54.5 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	50.200	46.567	Std	7.2
M	109.000	107.900	Std	1.0

Cylinder Gas Audit

07/06/2025

Page 2

Facility: ROSEVILLE ENERGY

Unit/Stack: CT1

Parameter/Scale: CO / Low

Test Date: 05/01/2025

Test Result: **Pass**

Instrument Name: CT1_CODualRg_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
05/01/2025	13:40	L	10	2.600	2.100	26.0 %
05/01/2025	13:45	M	10	5.700	5.500	57.0 %
05/01/2025	13:52	L	10	2.600	2.200	26.0 %
05/01/2025	13:57	M	10	5.700	5.500	57.0 %
05/01/2025	14:04	L	10	2.600	2.100	26.0 %
05/01/2025	14:09	M	10	5.700	5.500	57.0 %

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Specification Used	Results
L	2.600		2.133	Alt	0.5
M	5.700		5.500	Std	3.5

Linearity Report

07/06/2025

Page 1

ORIS Code: 56298 Facility Name: ROSEVILLE ENERGY
EDR Site ID: CT001 Component ID: A15 ReasonForTest: QA
Component Type: NOXA Grace Period: 0
Instrument Name: CT1_NOXDualRg_P_Instrum Test End Date/Time: 05/01/2025 Scale: High
Performance Spec: 5 % Test No.: 138 Highest Error: 0.6
Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
05/01/2025	0844	L	200.0	51.7	50.9		25.9 %
05/01/2025	0849	M	200.0	111.5	111.6		55.8 %
05/01/2025	0854	H	200.0	181.6	181.9		90.8 %
05/01/2025	0901	L	200.0	51.7	51.5		25.9 %
05/01/2025	0906	M	200.0	111.5	112.3		55.8 %
05/01/2025	0911	H	200.0	181.6	181.8		90.8 %
05/01/2025	0918	L	200.0	51.7	51.7		25.9 %
05/01/2025	0923	M	200.0	111.5	112.5		55.8 %
05/01/2025	0928	H	200.0	181.6	181.8		90.8 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	51.700	51.367	No	0.6
M	111.500	112.133	No	0.6
H	181.600	181.833	No	0.1

Linearity Report

07/06/2025

Page 2

ORIS Code: 56298 Facility Name: ROSEVILLE ENERGY
EDR Site ID: CT001 Component ID: A16 ReasonForTest: QA
Component Type: O2D Grace Period: 0
Instrument Name: CT1_O2D_P_Instrument Test End Date/Time: 05/01/2025 Scale: High
Performance Spec: 5 % Test No.: 139 Highest Error: 4.7
Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
05/01/2025	1135	L	18.0	5.0	4.8		27.8 %
05/01/2025	1140	M	18.0	11.0	10.9		61.1 %
05/01/2025	1145	H	18.0	18.0	18.0		100.0 %
05/01/2025	1152	L	18.0	5.0	4.8		27.8 %
05/01/2025	1157	M	18.0	11.0	10.9		61.1 %
05/01/2025	1202	H	18.0	18.0	18.0		100.0 %
05/01/2025	1209	L	18.0	5.0	4.7		27.8 %
05/01/2025	1214	M	18.0	11.0	10.9		61.1 %
05/01/2025	1219	H	18.0	18.0	18.0		100.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.000	4.767	No	4.7
M	11.000	10.900	No	0.9
H	18.000	18.000	No	0.0

Cylinder Gas Audit

07/06/2025

Page 1

Facility: ROSEVILLE ENERGY

Unit/Stack: CT2

Parameter/Scale: CO / High

Test Date: 05/05/2025

Test Result: **Pass**

Instrument Name: CT2_CODualRg_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
05/05/2025	08:35	L	200	49.900	49.600	25.0 %
05/05/2025	08:40	M	200	109.100	109.400	54.6 %
05/05/2025	08:52	L	200	49.900	49.900	25.0 %
05/05/2025	08:57	M	200	109.100	112.300	54.6 %
05/05/2025	09:09	L	200	49.900	49.800	25.0 %
05/05/2025	09:14	M	200	109.100	111.200	54.6 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	49.900	49.767	Std	0.3
M	109.100	110.967	Std	1.7

Cylinder Gas Audit

07/06/2025

Page 2

Facility: ROSEVILLE ENERGY

Unit/Stack: CT2

Parameter/Scale: CO / Low

Test Date: 05/05/2025

Test Result: **Pass**

Instrument Name: CT2_CODualRg_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
05/05/2025	12:37	L	10	2.600	2.300	26.0 %
05/05/2025	12:42	M	10	5.700	6.100	57.0 %
05/05/2025	12:49	L	10	2.600	2.100	26.0 %
05/05/2025	12:54	M	10	5.700	5.400	57.0 %
05/05/2025	13:01	L	10	2.600	2.300	26.0 %
05/05/2025	13:06	M	10	5.700	5.700	57.0 %

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Specification Used	Results
L	2.600		2.233	Std	14.1
M	5.700		5.733	Std	0.6

Linearity Report

07/06/2025

Page 1

ORIS Code: 56298 Facility Name: ROSEVILLE ENERGY
EDR Site ID: CT002 Component ID: A21 ReasonForTest: QA
Component Type: NOXA Grace Period: 0
Instrument Name: CT2_NOXDualRg_P_Instrum Test End Date/Time: 05/05/2025 Scale: High
Performance Spec: 5 % Test No.: 139 Highest Error: 1.2
Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
05/05/2025	0835	L	200.0	51.1	50.8		25.6 %
05/05/2025	0840	M	200.0	111.3	111.5		55.7 %
05/05/2025	0845	H	200.0	179.9	180.1		90.0 %
05/05/2025	0852	L	200.0	51.1	50.4		25.6 %
05/05/2025	0857	M	200.0	111.3	111.2		55.7 %
05/05/2025	0902	H	200.0	179.9	180.0		90.0 %
05/05/2025	0909	L	200.0	51.1	50.2		25.6 %
05/05/2025	0914	M	200.0	111.3	110.6		55.7 %
05/05/2025	0919	H	200.0	179.9	179.8		90.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	51.100	50.467	No	1.2
M	111.300	111.100	No	0.2
H	179.900	179.967	No	0.0

Linearity Report

07/06/2025

Page 2

ORIS Code: 56298 Facility Name: ROSEVILLE ENERGY
EDR Site ID: CT002 Component ID: A22 ReasonForTest: QA
Component Type: O2D Grace Period: 0
Instrument Name: CT2_O2D_P_Instrument Test End Date/Time: 05/05/2025 Scale: High
Performance Spec: 5 % Test No.: 140 Highest Error: 0.3
Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
05/05/2025	1035	L	21.0	5.0	5.0		23.8 %
05/05/2025	1040	M	21.0	11.0	11.0		52.4 %
05/05/2025	1045	H	21.0	18.0	18.0		85.7 %
05/05/2025	1052	L	21.0	5.0	5.0		23.8 %
05/05/2025	1057	M	21.0	11.0	11.0		52.4 %
05/05/2025	1102	H	21.0	18.0	17.9		85.7 %
05/05/2025	1109	L	21.0	5.0	5.0		23.8 %
05/05/2025	1114	M	21.0	11.0	11.1		52.4 %
05/05/2025	1119	H	21.0	18.0	18.0		85.7 %

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Alt Perf Spec	Results
L	5.000		5.000	No	0.0
M	11.000		11.033	No	0.3
H	18.000		17.967	No	0.2