

DOCKETED	
Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	264963
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q2 2025 - Part 6s
Description:	N/A
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public Agency
Submission Date:	7/22/2025 8:58:42 AM
Docketed Date:	7/22/2025

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/01/2025 00:00	1	46	0
04/01/2025 01:00	1	47	0
04/01/2025 02:00	1	46	0
04/01/2025 03:00	1	48	0
04/01/2025 04:00	1	50	0
04/01/2025 05:00	1	59	0
04/01/2025 06:00	1	67	0
04/01/2025 07:00	1	71	0
04/01/2025 08:00	1	69	0
04/01/2025 09:00	1	66	0
04/01/2025 10:00	1	66	0
04/01/2025 11:00	1	66	0
04/01/2025 12:00	1	63	0
04/01/2025 13:00	1	56	0
04/01/2025 14:00	1	49	0
04/01/2025 15:00	1	45	0
04/01/2025 16:00	1	45	0
04/01/2025 17:00	1	47	0
04/01/2025 18:00	1	48	0
04/01/2025 19:00	1	48	0
04/01/2025 20:00	1	46	0
04/01/2025 21:00	1	45	0
04/01/2025 22:00	1	45	0
04/01/2025 23:00	1	45	0
Average/Sum#:	24 #	53	0
Minimum:	1	45	0
Maximum:	1	71	0
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF		Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)		1 Hour(s)	1 Hour(s)
04/02/2025 00:00	1		45	0
04/02/2025 01:00	1		45	0
04/02/2025 02:00	1		45	0
04/02/2025 03:00	1		45	0
04/02/2025 04:00	1		49	0
04/02/2025 05:00	1		58	0
04/02/2025 06:00	1		67	0
04/02/2025 07:00	1		69	0
04/02/2025 08:00	1		59	0
04/02/2025 09:00	1		51	0
04/02/2025 10:00	1		45	7
04/02/2025 11:00	1		45	27
04/02/2025 12:00	1		44	49
04/02/2025 13:00	1		46	64
04/02/2025 14:00	1		51	65
04/02/2025 15:00	1		56	55
04/02/2025 16:00	1		57	34
04/02/2025 17:00	1		53	12
04/02/2025 18:00	1		48	0
04/02/2025 19:00	1		46	0
04/02/2025 20:00	1		45	0
04/02/2025 21:00	1		45	0
04/02/2025 22:00	1		45	0
04/02/2025 23:00	1		45	0
Average/Sum#:	24 #		50	13
Minimum:	1		44	0
Maximum:	1		69	65
%SI	0.00		0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/03/2025 00:00	1	45	0
04/03/2025 01:00	1	45	0
04/03/2025 02:00	1	45	0
04/03/2025 03:00	1	48	0
04/03/2025 04:00	1	56	0
04/03/2025 05:00	1	64	0
04/03/2025 06:00	1	68	0
04/03/2025 07:00	1	61	0
04/03/2025 08:00	1	53	0
04/03/2025 09:00	1	46	0
04/03/2025 10:00	1	45	0
04/03/2025 11:00	1	45	0
04/03/2025 12:00	1	45	0
04/03/2025 13:00	1	45	0
04/03/2025 14:00	1	45	0
04/03/2025 15:00	1	45	0
04/03/2025 16:00	1	45	0
04/03/2025 17:00	1	46	0
04/03/2025 18:00	1	46	0
04/03/2025 19:00	1	46	0
04/03/2025 20:00	1	45	0
04/03/2025 21:00	1	45	0
04/03/2025 22:00	1	47	0
04/03/2025 23:00	1	50	0
Average/Sum#:	24 #	49	0
Minimum:	1	45	0
Maximum:	1	68	0
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF		Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)		1 Hour(s)	1 Hour(s)
04/04/2025 00:00	1		50	0
04/04/2025 01:00	1		48	0
04/04/2025 02:00	1		48	0
04/04/2025 03:00	1		51	0
04/04/2025 04:00	1		52	0
04/04/2025 05:00	1		52	0
04/04/2025 06:00	1		50	0
04/04/2025 07:00	1		49	0
04/04/2025 08:00	1		46	0
04/04/2025 09:00	1		45	0
04/04/2025 10:00	1		45	0
04/04/2025 11:00	1		45	0
04/04/2025 12:00	1		45	0
04/04/2025 13:00	1		45	0
04/04/2025 14:00	1		45	0
04/04/2025 15:00	1		45	0
04/04/2025 16:00	1		45	0
04/04/2025 17:00	1		46	0
04/04/2025 18:00	1		46	0
04/04/2025 19:00	1		47	0
04/04/2025 20:00	1		45	0
04/04/2025 21:00	1		46	0
04/04/2025 22:00	1		46	0
04/04/2025 23:00	1		47	0
Average/Sum#:	24 #		47	0
Minimum:	1		45	0
Maximum:	1		52	0
%SI	0.00		0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF		Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)		1 Hour(s)	1 Hour(s)
04/05/2025 00:00	1		46	0
04/05/2025 01:00	1		46	0
04/05/2025 02:00	1		45	0
04/05/2025 03:00	1		45	0
04/05/2025 04:00	1		47	0
04/05/2025 05:00	1		50	0
04/05/2025 06:00	1		51	0
04/05/2025 07:00	1		50	0
04/05/2025 08:00	1		47	0
04/05/2025 09:00	1		45	0
04/05/2025 10:00	1		45	0
04/05/2025 11:00	1		45	0
04/05/2025 12:00	1		45	0
04/05/2025 13:00	1		45	0
04/05/2025 14:00	1		45	0
04/05/2025 15:00	1		45	0
04/05/2025 16:00	1		45	0
04/05/2025 17:00	1		47	0
04/05/2025 18:00	1		49	0
04/05/2025 19:00	1		49	0
04/05/2025 20:00	1		47	0
04/05/2025 21:00	1		45	0
04/05/2025 22:00	1		45	0
04/05/2025 23:00	1		46	0
Average/Sum#:	24 #		46	0
Minimum:	1		45	0
Maximum:	1		51	0
%SI	0.00		0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF		Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)		1 Hour(s)	1 Hour(s)
04/06/2025 00:00	1		46	0
04/06/2025 01:00	1		46	0
04/06/2025 02:00	1		45	0
04/06/2025 03:00	1		45	0
04/06/2025 04:00	1		45	0
04/06/2025 05:00	1		46	0
04/06/2025 06:00	1		47	0
04/06/2025 07:00	1		47	0
04/06/2025 08:00	1		45	0
04/06/2025 09:00	1		45	0
04/06/2025 10:00	1		45	0
04/06/2025 11:00	1		45	0
04/06/2025 12:00	1		45	0
04/06/2025 13:00	1		45	0
04/06/2025 14:00	1		45	0
04/06/2025 15:00	1		45	0
04/06/2025 16:00	1		45	0
04/06/2025 17:00	1		47	0
04/06/2025 18:00	1		47	0
04/06/2025 19:00	1		47	0
04/06/2025 20:00	1		45	0
04/06/2025 21:00	1		45	0
04/06/2025 22:00	1		45	0
04/06/2025 23:00	1		45	0
Average/Sum#:	24 #		46	0
Minimum:	1		45	0
Maximum:	1		47	0
%SI	0.00		0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF		Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)		1 Hour(s)	1 Hour(s)
04/07/2025 00:00	1		45	0
04/07/2025 01:00	1		45	0
04/07/2025 02:00	1		45	0
04/07/2025 03:00	1		45	0
04/07/2025 04:00	1		46	0
04/07/2025 05:00	1		49	0
04/07/2025 06:00	1		50	0
04/07/2025 07:00	1		50	0
04/07/2025 08:00	1		46	3
04/07/2025 09:00	1		43	17
04/07/2025 10:00	1		36	35
04/07/2025 11:00	1		21	47
04/07/2025 12:00	1		7	48
04/07/2025 13:00	1		0	45
04/07/2025 14:00	1		0	45
04/07/2025 15:00	1		0	45
04/07/2025 16:00	1		0	46
04/07/2025 17:00	1		0	48
04/07/2025 18:00	1		0	48
04/07/2025 19:00	1		0	47
04/07/2025 20:00	1		0	45
04/07/2025 21:00	1		0	45
04/07/2025 22:00	1		0	45
04/07/2025 23:00	1		0	45
Average/Sum#:	24 #		22	27
Minimum:	1		0	0
Maximum:	1		50	48
%SI	0.00		0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/08/2025 00:00	1	0	45
04/08/2025 01:00	1	0	45
04/08/2025 02:00	1	0	45
04/08/2025 03:00	1	0	45
04/08/2025 04:00	1	0	45
04/08/2025 05:00	1	0	45
04/08/2025 06:00	1	0	45
04/08/2025 07:00	1	0	45
04/08/2025 08:00	1	0	45
04/08/2025 09:00	1	0	45
04/08/2025 10:00	1	0	45
04/08/2025 11:00	1	0	45
04/08/2025 12:00	1	0	45
04/08/2025 13:00	1	0	45
04/08/2025 14:00	1	0	45
04/08/2025 15:00	1	0	45
04/08/2025 16:00	1	0	45
04/08/2025 17:00	1	0	46
04/08/2025 18:00	1	0	46
04/08/2025 19:00	1	0	46
04/08/2025 20:00	1	0	45
04/08/2025 21:00	1	0	45
04/08/2025 22:00	1	0	45
04/08/2025 23:00	1	0	45
Average/Sum#:	24 #	0	45
Minimum:	1	0	45
Maximum:	1	0	46
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/09/2025 00:00	1	0	45
04/09/2025 01:00	1	0	45
04/09/2025 02:00	1	0	45
04/09/2025 03:00	1	0	45
04/09/2025 04:00	1	0	45
04/09/2025 05:00	1	0	45
04/09/2025 06:00	1	0	45
04/09/2025 07:00	1	0	45
04/09/2025 08:00	1	0	45
04/09/2025 09:00	1	0	45
04/09/2025 10:00	1	0	45
04/09/2025 11:00	1	0	45
04/09/2025 12:00	1	0	45
04/09/2025 13:00	1	0	45
04/09/2025 14:00	1	0	45
04/09/2025 15:00	1	0	45
04/09/2025 16:00	1	0	45
04/09/2025 17:00	1	0	47
04/09/2025 18:00	1	0	47
04/09/2025 19:00	1	0	47
04/09/2025 20:00	1	0	45
04/09/2025 21:00	1	0	46
04/09/2025 22:00	1	0	47
04/09/2025 23:00	1	0	47
Average/Sum#:	24 #	0	45
Minimum:	1	0	45
Maximum:	1	0	47
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/10/2025 00:00	1	0	45
04/10/2025 01:00	1	0	45
04/10/2025 02:00	1	0	45
04/10/2025 03:00	1	0	45
04/10/2025 04:00	1	0	45
04/10/2025 05:00	1	0	45
04/10/2025 06:00	1	0	45
04/10/2025 07:00	1	0	45
04/10/2025 08:00	1	0	45
04/10/2025 09:00	1	0	45
04/10/2025 10:00	1	0	45
04/10/2025 11:00	1	0	45
04/10/2025 12:00	1	0	44
04/10/2025 13:00	1	0	44
04/10/2025 14:00	1	0	46
04/10/2025 15:00	1	0	46
04/10/2025 16:00	1	0	48
04/10/2025 17:00	1	0	49
04/10/2025 18:00	1	0	54
04/10/2025 19:00	1	0	55
04/10/2025 20:00	1	0	52
04/10/2025 21:00	1	0	47
04/10/2025 22:00	1	0	45
04/10/2025 23:00	1	0	45
Average/Sum#:	24 #	0	46
Minimum:	1	0	44
Maximum:	1	0	55
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/11/2025 00:00	1	0	45
04/11/2025 01:00	1	0	45
04/11/2025 02:00	1	0	45
04/11/2025 03:00	1	0	44
04/11/2025 04:00	1	0	45
04/11/2025 05:00	1	0	47
04/11/2025 06:00	1	0	47
04/11/2025 07:00	1	0	46
04/11/2025 08:00	1	0	44
04/11/2025 09:00	1	0	44
04/11/2025 10:00	1	0	44
04/11/2025 11:00	1	0	44
04/11/2025 12:00	1	0	44
04/11/2025 13:00	1	0	44
04/11/2025 14:00	1	0	44
04/11/2025 15:00	1	0	44
04/11/2025 16:00	1	0	44
04/11/2025 17:00	1	0	46
04/11/2025 18:00	1	0	46
04/11/2025 19:00	1	0	46
04/11/2025 20:00	1	0	44
04/11/2025 21:00	1	0	46
04/11/2025 22:00	1	0	46
04/11/2025 23:00	1	0	46
Average/Sum#:	24 #	0	45
Minimum:	1	0	44
Maximum:	1	0	47
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/12/2025 00:00	1	0	45
04/12/2025 01:00	1	0	45
04/12/2025 02:00	1	0	44
04/12/2025 03:00	1	0	44
04/12/2025 04:00	1	0	44
04/12/2025 05:00	1	0	44
04/12/2025 06:00	1	0	44
04/12/2025 07:00	1	0	44
04/12/2025 08:00	1	0	44
04/12/2025 09:00	1	0	44
04/12/2025 10:00	1	0	44
04/12/2025 11:00	1	0	44
04/12/2025 12:00	1	0	44
04/12/2025 13:00	1	0	44
04/12/2025 14:00	1	0	44
04/12/2025 15:00	1	0	44
04/12/2025 16:00	1	0	44
04/12/2025 17:00	1	0	45
04/12/2025 18:00	1	0	45
04/12/2025 19:00	1	0	45
04/12/2025 20:00	1	0	44
04/12/2025 21:00	1	0	44
04/12/2025 22:00	1	0	44
04/12/2025 23:00	1	0	44
Average/Sum#:	24 #	0	44
Minimum:	1	0	44
Maximum:	1	0	45
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/13/2025 00:00	1	0	44
04/13/2025 01:00	1	0	44
04/13/2025 02:00	1	0	44
04/13/2025 03:00	1	0	44
04/13/2025 04:00	1	0	44
04/13/2025 05:00	1	0	44
04/13/2025 06:00	1	0	45
04/13/2025 07:00	1	0	45
04/13/2025 08:00	1	0	45
04/13/2025 09:00	1	0	44
04/13/2025 10:00	1	0	44
04/13/2025 11:00	1	0	44
04/13/2025 12:00	1	0	44
04/13/2025 13:00	1	0	44
04/13/2025 14:00	1	0	44
04/13/2025 15:00	1	0	44
04/13/2025 16:00	1	0	44
04/13/2025 17:00	1	0	45
04/13/2025 18:00	1	0	45
04/13/2025 19:00	1	0	45
04/13/2025 20:00	1	0	44
04/13/2025 21:00	1	0	44
04/13/2025 22:00	1	0	44
04/13/2025 23:00	1	0	44
Average/Sum#:	24 #	0	44
Minimum:	1	0	44
Maximum:	1	0	45
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/14/2025 00:00	1	0	44
04/14/2025 01:00	1	0	44
04/14/2025 02:00	1	0	44
04/14/2025 03:00	1	0	44
04/14/2025 04:00	1	0	44
04/14/2025 05:00	1	0	44
04/14/2025 06:00	1	0	46
04/14/2025 07:00	1	0	46
04/14/2025 08:00	1	0	46
04/14/2025 09:00	1	0	44
04/14/2025 10:00	1	0	44
04/14/2025 11:00	1	0	44
04/14/2025 12:00	1	0	44
04/14/2025 13:00	1	0	44
04/14/2025 14:00	1	0	44
04/14/2025 15:00	1	0	44
04/14/2025 16:00	1	0	44
04/14/2025 17:00	1	0	45
04/14/2025 18:00	1	0	45
04/14/2025 19:00	1	0	45
04/14/2025 20:00	1	0	44
04/14/2025 21:00	1	0	44
04/14/2025 22:00	1	0	44
04/14/2025 23:00	1	0	44
Average/Sum#:	24 #	0	44
Minimum:	1	0	44
Maximum:	1	0	46
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/15/2025 00:00	1	0	44
04/15/2025 01:00	1	0	44
04/15/2025 02:00	1	0	44
04/15/2025 03:00	1	0	44
04/15/2025 04:00	1	0	45
04/15/2025 05:00	1	0	45
04/15/2025 06:00	1	0	45
04/15/2025 07:00	1	0	44
04/15/2025 08:00	1	0	44
04/15/2025 09:00	1	0	44
04/15/2025 10:00	1	0	44
04/15/2025 11:00	1	0	44
04/15/2025 12:00	1	0	44
04/15/2025 13:00	1	0	44
04/15/2025 14:00	1	0	44
04/15/2025 15:00	1	0	44
04/15/2025 16:00	1	0	45
04/15/2025 17:00	1	0	47
04/15/2025 18:00	1	0	47
04/15/2025 19:00	1	0	46
04/15/2025 20:00	1	0	45
04/15/2025 21:00	1	0	45
04/15/2025 22:00	1	0	45
04/15/2025 23:00	1	0	45
Average/Sum#:	24 #	0	45
Minimum:	1	0	44
Maximum:	1	0	47
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/16/2025 00:00	1	0	45
04/16/2025 01:00	1	0	45
04/16/2025 02:00	1	0	44
04/16/2025 03:00	1	0	44
04/16/2025 04:00	1	0	44
04/16/2025 05:00	1	0	44
04/16/2025 06:00	1	0	44
04/16/2025 07:00	1	0	43
04/16/2025 08:00	1	0	43
04/16/2025 09:00	1	0	44
04/16/2025 10:00	1	0	44
04/16/2025 11:00	1	0	44
04/16/2025 12:00	1	0	44
04/16/2025 13:00	1	0	43
04/16/2025 14:00	1	0	43
04/16/2025 15:00	1	0	44
04/16/2025 16:00	1	0	44
04/16/2025 17:00	1	0	44
04/16/2025 18:00	1	0	44
04/16/2025 19:00	1	0	44
04/16/2025 20:00	1	0	44
04/16/2025 21:00	1	0	44
04/16/2025 22:00	1	0	44
04/16/2025 23:00	1	0	44
Average/Sum#:	24 #	0	44
Minimum:	1	0	43
Maximum:	1	0	45
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/17/2025 00:00	1	0	44
04/17/2025 01:00	1	0	44
04/17/2025 02:00	1	0	44
04/17/2025 03:00	1	0	44
04/17/2025 04:00	1	0	44
04/17/2025 05:00	1	0	44
04/17/2025 06:00	1	0	44
04/17/2025 07:00	1	0	44
04/17/2025 08:00	1	0	46
04/17/2025 09:00	1	0	46
04/17/2025 10:00	1	0	46
04/17/2025 11:00	1	0	44
04/17/2025 12:00	1	0	44
04/17/2025 13:00	1	0	44
04/17/2025 14:00	1	0	44
04/17/2025 15:00	1	0	44
04/17/2025 16:00	1	0	44
04/17/2025 17:00	1	0	44
04/17/2025 18:00	1	0	44
04/17/2025 19:00	1	0	44
04/17/2025 20:00	1	0	44
04/17/2025 21:00	1	0	44
04/17/2025 22:00	1	0	44
04/17/2025 23:00	1	0	44
Average/Sum#:	24 #	0	44
Minimum:	1	0	44
Maximum:	1	0	46
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/18/2025 00:00	1	0	44
04/18/2025 01:00	1	0	44
04/18/2025 02:00	1	0	44
04/18/2025 03:00	1	0	44
04/18/2025 04:00	1	0	44
04/18/2025 05:00	1	0	44
04/18/2025 06:00	1	0	47
04/18/2025 07:00	1	9	48
04/18/2025 08:00	1	23	48
04/18/2025 09:00	1	39	44
04/18/2025 10:00	1	50	28
04/18/2025 11:00	1	51	14
04/18/2025 12:00	1	50	0
04/18/2025 13:00	1	44	0
04/18/2025 14:00	1	44	0
04/18/2025 15:00	1	44	0
04/18/2025 16:00	1	44	0
04/18/2025 17:00	1	45	0
04/18/2025 18:00	1	45	0
04/18/2025 19:00	1	46	0
04/18/2025 20:00	1	49	0
04/18/2025 21:00	1	54	0
04/18/2025 22:00	1	55	0
04/18/2025 23:00	1	58	0
Average/Sum#:	24 #	31	21
Minimum:	1	0	0
Maximum:	1	58	48
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/19/2025 00:00	1	61	0
04/19/2025 01:00	1	66	0
04/19/2025 02:00	1	65	0
04/19/2025 03:00	1	65	0
04/19/2025 04:00	1	65	0
04/19/2025 05:00	1	65	0
04/19/2025 06:00	1	63	0
04/19/2025 07:00	1	56	0
04/19/2025 08:00	1	49	0
04/19/2025 09:00	1	44	0
04/19/2025 10:00	1	44	0
04/19/2025 11:00	1	44	0
04/19/2025 12:00	1	44	0
04/19/2025 13:00	1	44	0
04/19/2025 14:00	1	44	0
04/19/2025 15:00	1	44	0
04/19/2025 16:00	1	44	0
04/19/2025 17:00	1	45	0
04/19/2025 18:00	1	48	0
04/19/2025 19:00	1	55	0
04/19/2025 20:00	1	61	0
04/19/2025 21:00	1	65	0
04/19/2025 22:00	1	65	0
04/19/2025 23:00	1	59	0
Average/Sum#:	24 #	54	0
Minimum:	1	44	0
Maximum:	1	66	0
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/20/2025 00:00	1	52	0
04/20/2025 01:00	1	45	0
04/20/2025 02:00	1	44	0
04/20/2025 03:00	1	44	0
04/20/2025 04:00	1	44	0
04/20/2025 05:00	1	44	0
04/20/2025 06:00	1	44	0
04/20/2025 07:00	1	44	0
04/20/2025 08:00	1	44	0
04/20/2025 09:00	1	44	0
04/20/2025 10:00	1	44	0
04/20/2025 11:00	1	44	0
04/20/2025 12:00	1	44	0
04/20/2025 13:00	1	44	0
04/20/2025 14:00	1	44	0
04/20/2025 15:00	1	44	0
04/20/2025 16:00	1	44	0
04/20/2025 17:00	1	47	0
04/20/2025 18:00	1	54	0
04/20/2025 19:00	1	61	0
04/20/2025 20:00	1	65	0
04/20/2025 21:00	1	65	0
04/20/2025 22:00	1	65	0
04/20/2025 23:00	1	65	0
Average/Sum#:	24 #	49	0
Minimum:	1	44	0
Maximum:	1	65	0
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/21/2025 00:00	1	65	0
04/21/2025 01:00	1	65	0
04/21/2025 02:00	1	65	0
04/21/2025 03:00	1	65	0
04/21/2025 04:00	1	65	0
04/21/2025 05:00	1	65	0
04/21/2025 06:00	1	62	0
04/21/2025 07:00	1	55	0
04/21/2025 08:00	1	48	0
04/21/2025 09:00	1	44	0
04/21/2025 10:00	1	44	0
04/21/2025 11:00	1	44	0
04/21/2025 12:00	1	44	0
04/21/2025 13:00	1	44	0
04/21/2025 14:00	1	44	0
04/21/2025 15:00	1	44	0
04/21/2025 16:00	1	44	0
04/21/2025 17:00	1	49	0
04/21/2025 18:00	1	57	0
04/21/2025 19:00	1	65	0
04/21/2025 20:00	1	70	0
04/21/2025 21:00	1	71	0
04/21/2025 22:00	1	73	0
04/21/2025 23:00	1	73	0
Average/Sum#:	24 #	57	0
Minimum:	1	44	0
Maximum:	1	73	0
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/22/2025 00:00	1	71	0
04/22/2025 01:00	1	69	0
04/22/2025 02:00	1	67	0
04/22/2025 03:00	1	67	0
04/22/2025 04:00	1	68	0
04/22/2025 05:00	1	70	0
04/22/2025 06:00	1	68	0
04/22/2025 07:00	1	64	0
04/22/2025 08:00	1	55	0
04/22/2025 09:00	1	48	0
04/22/2025 10:00	1	44	0
04/22/2025 11:00	1	44	0
04/22/2025 12:00	1	44	0
04/22/2025 13:00	1	44	0
04/22/2025 14:00	1	44	0
04/22/2025 15:00	1	44	0
04/22/2025 16:00	1	47	0
04/22/2025 17:00	1	55	0
04/22/2025 18:00	1	64	0
04/22/2025 19:00	1	71	0
04/22/2025 20:00	1	71	0
04/22/2025 21:00	1	71	0
04/22/2025 22:00	1	71	0
04/22/2025 23:00	1	71	0
Average/Sum#:	24 #	60	0
Minimum:	1	44	0
Maximum:	1	71	0
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/23/2025 00:00	1	69	0
04/23/2025 01:00	1	67	0
04/23/2025 02:00	1	66	0
04/23/2025 03:00	1	65	0
04/23/2025 04:00	1	65	0
04/23/2025 05:00	1	65	0
04/23/2025 06:00	1	63	0
04/23/2025 07:00	1	56	0
04/23/2025 08:00	1	49	0
04/23/2025 09:00	1	44	0
04/23/2025 10:00	1	44	0
04/23/2025 11:00	1	44	0
04/23/2025 12:00	1	44	0
04/23/2025 13:00	1	44	0
04/23/2025 14:00	1	44	0
04/23/2025 15:00	1	44	0
04/23/2025 16:00	1	44	0
04/23/2025 17:00	1	47	0
04/23/2025 18:00	1	54	0
04/23/2025 19:00	1	61	0
04/23/2025 20:00	1	65	0
04/23/2025 21:00	1	65	0
04/23/2025 22:00	1	65	0
04/23/2025 23:00	1	65	0
Average/Sum#:	24 #	56	0
Minimum:	1	44	0
Maximum:	1	69	0
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/24/2025 00:00	1	65	0
04/24/2025 01:00	1	65	0
04/24/2025 02:00	1	65	0
04/24/2025 03:00	1	65	0
04/24/2025 04:00	1	65	0
04/24/2025 05:00	1	59	0
04/24/2025 06:00	1	52	0
04/24/2025 07:00	1	45	0
04/24/2025 08:00	1	44	0
04/24/2025 09:00	1	44	0
04/24/2025 10:00	1	44	0
04/24/2025 11:00	1	44	0
04/24/2025 12:00	1	44	0
04/24/2025 13:00	1	44	0
04/24/2025 14:00	1	44	0
04/24/2025 15:00	1	44	0
04/24/2025 16:00	1	45	0
04/24/2025 17:00	1	48	0
04/24/2025 18:00	1	55	0
04/24/2025 19:00	1	61	0
04/24/2025 20:00	1	65	0
04/24/2025 21:00	1	65	0
04/24/2025 22:00	1	65	0
04/24/2025 23:00	1	65	0
Average/Sum#:	24 #	54	0
Minimum:	1	44	0
Maximum:	1	65	0
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF		Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)		1 Hour(s)	1 Hour(s)
04/25/2025 00:00	1		65	0
04/25/2025 01:00	1		65	0
04/25/2025 02:00	1		58	0
04/25/2025 03:00	1		51	0
04/25/2025 04:00	1		45	0
04/25/2025 05:00	1		50	0
04/25/2025 06:00	1		54	1
04/25/2025 07:00	1		55	10
04/25/2025 08:00	1		54	27
04/25/2025 09:00	1		53	44
04/25/2025 10:00	1		58	52
04/25/2025 11:00	1		59	47
04/25/2025 12:00	1		60	43
04/25/2025 13:00	1		56	38
04/25/2025 14:00	1		58	25
04/25/2025 15:00	1		54	11
04/25/2025 16:00	1		53	0
04/25/2025 17:00	1		49	0
04/25/2025 18:00	1		55	0
04/25/2025 19:00	1		62	0
04/25/2025 20:00	1		66	0
04/25/2025 21:00	1		63	0
04/25/2025 22:00	1		56	0
04/25/2025 23:00	1		49	0
Average/Sum#:	24 #		56	12
Minimum:	1		45	0
Maximum:	1		66	52
%SI	0.00		0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/26/2025 00:00	1	46	0
04/26/2025 01:00	1	45	0
04/26/2025 02:00	1	45	0
04/26/2025 03:00	1	45	0
04/26/2025 04:00	1	45	0
04/26/2025 05:00	1	45	0
04/26/2025 06:00	1	45	0
04/26/2025 07:00	1	47	0
04/26/2025 08:00	1	51	0
04/26/2025 09:00	1	53	0
04/26/2025 10:00	1	53	0
04/26/2025 11:00	1	50	0
04/26/2025 12:00	1	47	0
04/26/2025 13:00	1	45	0
04/26/2025 14:00	1	44	0
04/26/2025 15:00	1	44	0
04/26/2025 16:00	1	47	0
04/26/2025 17:00	1	50	0
04/26/2025 18:00	1	50	0
04/26/2025 19:00	1	48	0
04/26/2025 20:00	1	45	0
04/26/2025 21:00	1	45	0
04/26/2025 22:00	1	44	0
04/26/2025 23:00	1	49	0
Average/Sum#:	24 #	47	0
Minimum:	1	44	0
Maximum:	1	53	0
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF		Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)		1 Hour(s)	1 Hour(s)
04/27/2025 00:00	1		51	0
04/27/2025 01:00	1		51	0
04/27/2025 02:00	1		46	0
04/27/2025 03:00	1		47	0
04/27/2025 04:00	1		47	0
04/27/2025 05:00	1		47	0
04/27/2025 06:00	1		44	0
04/27/2025 07:00	1		44	0
04/27/2025 08:00	1		44	0
04/27/2025 09:00	1		44	0
04/27/2025 10:00	1		44	0
04/27/2025 11:00	1		44	0
04/27/2025 12:00	1		44	0
04/27/2025 13:00	1		44	0
04/27/2025 14:00	1		44	0
04/27/2025 15:00	1		46	0
04/27/2025 16:00	1		48	0
04/27/2025 17:00	1		48	0
04/27/2025 18:00	1		47	0
04/27/2025 19:00	1		45	0
04/27/2025 20:00	1		44	0
04/27/2025 21:00	1		44	0
04/27/2025 22:00	1		44	0
04/27/2025 23:00	1		44	0
Average/Sum#:	24 #		46	0
Minimum:	1		44	0
Maximum:	1		51	0
%SI	0.00		0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/28/2025 00:00	1	44	0
04/28/2025 01:00	1	44	0
04/28/2025 02:00	1	44	0
04/28/2025 03:00	1	44	0
04/28/2025 04:00	1	44	0
04/28/2025 05:00	1	44	0
04/28/2025 06:00	1	44	0
04/28/2025 07:00	1	44	0
04/28/2025 08:00	1	44	0
04/28/2025 09:00	1	44	0
04/28/2025 10:00	1	44	0
04/28/2025 11:00	1	44	0
04/28/2025 12:00	1	44	0
04/28/2025 13:00	1	44	0
04/28/2025 14:00	1	44	0
04/28/2025 15:00	1	44	0
04/28/2025 16:00	1	44	0
04/28/2025 17:00	1	45	0
04/28/2025 18:00	1	45	0
04/28/2025 19:00	1	45	0
04/28/2025 20:00	1	44	0
04/28/2025 21:00	1	44	0
04/28/2025 22:00	1	44	0
04/28/2025 23:00	1	44	0
Average/Sum#:	24 #	44	0
Minimum:	1	44	0
Maximum:	1	45	0
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF		Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)		1 Hour(s)	1 Hour(s)
04/29/2025 00:00	1		44	0
04/29/2025 01:00	1		44	0
04/29/2025 02:00	1		44	0
04/29/2025 03:00	1		44	0
04/29/2025 04:00	1		44	0
04/29/2025 05:00	1		44	0
04/29/2025 06:00	1		44	0
04/29/2025 07:00	1		44	0
04/29/2025 08:00	1		44	0
04/29/2025 09:00	1		44	0
04/29/2025 10:00	1		44	0
04/29/2025 11:00	1		44	0
04/29/2025 12:00	1		44	0
04/29/2025 13:00	1		44	0
04/29/2025 14:00	1		44	0
04/29/2025 15:00	1		44	0
04/29/2025 16:00	1		44	0
04/29/2025 17:00	1		45	0
04/29/2025 18:00	1		45	0
04/29/2025 19:00	1		45	0
04/29/2025 20:00	1		44	0
04/29/2025 21:00	1		44	0
04/29/2025 22:00	1		44	0
04/29/2025 23:00	1		44	0
Average/Sum#:	24 #		44	0
Minimum:	1		44	0
Maximum:	1		45	0
%SI	0.00		0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/30/2025 00:00	1	44	0
04/30/2025 01:00	1	44	0
04/30/2025 02:00	1	44	0
04/30/2025 03:00	1	44	0
04/30/2025 04:00	1	44	0
04/30/2025 05:00	1	44	0
04/30/2025 06:00	1	44	0
04/30/2025 07:00	1	44	0
04/30/2025 08:00	1	44	0
04/30/2025 09:00	1	44	0
04/30/2025 10:00	1	44	0
04/30/2025 11:00	1	44	0
04/30/2025 12:00	1	44	0
04/30/2025 13:00	1	44	0
04/30/2025 14:00	1	44	0
04/30/2025 15:00	1	44	0
04/30/2025 16:00	1	44	0
04/30/2025 17:00	1	46	0
04/30/2025 18:00	1	47	0
04/30/2025 19:00	1	50	0
04/30/2025 20:00	1	52	0
04/30/2025 21:00	1	56	0
04/30/2025 22:00	1	58	0
04/30/2025 23:00	1	54	0
Average/Sum#:	24 #	46	0
Minimum:	1	44	0
Maximum:	1	58	0
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF		Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)		1 Hour(s)	1 Hour(s)
05/01/2025 00:00	1		50	0
05/01/2025 01:00	1		45	0
05/01/2025 02:00	1		44	0
05/01/2025 03:00	1		45	0
05/01/2025 04:00	1		45	0
05/01/2025 05:00	1		46	0
05/01/2025 06:00	1		46	0
05/01/2025 07:00	1		45	0
05/01/2025 08:00	1		44	0
05/01/2025 09:00	1		44	0
05/01/2025 10:00	1		44	0
05/01/2025 11:00	1		44	0
05/01/2025 12:00	1		44	0
05/01/2025 13:00	1		44	0
05/01/2025 14:00	1		44	0
05/01/2025 15:00	1		44	0
05/01/2025 16:00	1		44	0
05/01/2025 17:00	1		46	0
05/01/2025 18:00	1		51	0
05/01/2025 19:00	1		54	0
05/01/2025 20:00	1		52	0
05/01/2025 21:00	1		52	0
05/01/2025 22:00	1		50	0
05/01/2025 23:00	1		49	0
Average/Sum#:	24 #		47	0
Minimum:	1		44	0
Maximum:	1		54	0
%SI	0.00		0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/02/2025 00:00	1	45	0
05/02/2025 01:00	1	44	0
05/02/2025 02:00	1	44	0
05/02/2025 03:00	1	44	0
05/02/2025 04:00	1	44	0
05/02/2025 05:00	1	45	0
05/02/2025 06:00	1	46	10
05/02/2025 07:00	1	46	25
05/02/2025 08:00	1	46	40
05/02/2025 09:00	1	46	46
05/02/2025 10:00	1	46	46
05/02/2025 11:00	1	46	46
05/02/2025 12:00	1	46	46
05/02/2025 13:00	1	46	46
05/02/2025 14:00	1	46	46
05/02/2025 15:00	1	40	47
05/02/2025 16:00	1	24	46
05/02/2025 17:00	1	9	47
05/02/2025 18:00	1	0	46
05/02/2025 19:00	1	0	47
05/02/2025 20:00	1	0	45
05/02/2025 21:00	1	0	45
05/02/2025 22:00	1	0	44
05/02/2025 23:00	1	0	44
Average/Sum#:	24 #	31	32
Minimum:	1	0	0
Maximum:	1	46	47
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/03/2025 00:00	1	0	44
05/03/2025 01:00	1	0	44
05/03/2025 02:00	1	0	44
05/03/2025 03:00	1	0	44
05/03/2025 04:00	1	0	44
05/03/2025 05:00	1	0	44
05/03/2025 06:00	1	0	44
05/03/2025 07:00	1	0	44
05/03/2025 08:00	1	0	44
05/03/2025 09:00	1	0	44
05/03/2025 10:00	1	0	44
05/03/2025 11:00	1	0	44
05/03/2025 12:00	1	0	44
05/03/2025 13:00	1	0	44
05/03/2025 14:00	1	0	44
05/03/2025 15:00	1	0	44
05/03/2025 16:00	1	0	44
05/03/2025 17:00	1	0	44
05/03/2025 18:00	1	0	44
05/03/2025 19:00	1	0	44
05/03/2025 20:00	1	0	44
05/03/2025 21:00	1	0	44
05/03/2025 22:00	1	0	44
05/03/2025 23:00	1	0	44
Average/Sum#:	24 #	0	44
Minimum:	1	0	44
Maximum:	1	0	44
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/04/2025 00:00	1	0	44
05/04/2025 01:00	1	0	44
05/04/2025 02:00	1	0	44
05/04/2025 03:00	1	0	44
05/04/2025 04:00	1	0	44
05/04/2025 05:00	1	0	45
05/04/2025 06:00	1	0	48
05/04/2025 07:00	1	0	50
05/04/2025 08:00	1	0	50
05/04/2025 09:00	1	0	47
05/04/2025 10:00	1	0	44
05/04/2025 11:00	1	0	45
05/04/2025 12:00	1	0	45
05/04/2025 13:00	1	0	45
05/04/2025 14:00	1	0	44
05/04/2025 15:00	1	0	44
05/04/2025 16:00	1	0	44
05/04/2025 17:00	1	0	46
05/04/2025 18:00	1	0	48
05/04/2025 19:00	1	0	53
05/04/2025 20:00	1	0	56
05/04/2025 21:00	1	0	59
05/04/2025 22:00	1	0	57
05/04/2025 23:00	1	0	53
Average/Sum#:	24 #	0	48
Minimum:	1	0	44
Maximum:	1	0	59
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF		Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)		1 Hour(s)	1 Hour(s)
05/05/2025 00:00	1		0	48
05/05/2025 01:00	1		0	45
05/05/2025 02:00	1		0	44
05/05/2025 03:00	1		0	44
05/05/2025 04:00	1		0	45
05/05/2025 05:00	1		0	46
05/05/2025 06:00	1		0	48
05/05/2025 07:00	1		0	48
05/05/2025 08:00	1		0	47
05/05/2025 09:00	1		0	44
05/05/2025 10:00	1		0	44
05/05/2025 11:00	1		0	44
05/05/2025 12:00	1		0	44
05/05/2025 13:00	1		0	44
05/05/2025 14:00	1		0	44
05/05/2025 15:00	1		0	44
05/05/2025 16:00	1		0	44
05/05/2025 17:00	1		0	44
05/05/2025 18:00	1		0	47
05/05/2025 19:00	1		0	52
05/05/2025 20:00	1		0	56
05/05/2025 21:00	1		0	58
05/05/2025 22:00	1		0	58
05/05/2025 23:00	1		0	58
Average/Sum#:	24 #		0	48
Minimum:	1		0	44
Maximum:	1		0	58
%SI	0.00		0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF		Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)		1 Hour(s)	1 Hour(s)
05/06/2025 00:00	1		0	56
05/06/2025 01:00	1		0	54
05/06/2025 02:00	1		0	52
05/06/2025 03:00	1		0	51
05/06/2025 04:00	1		0	50
05/06/2025 05:00	1		0	52
05/06/2025 06:00	1		0	51
05/06/2025 07:00	1		0	50
05/06/2025 08:00	1		0	45
05/06/2025 09:00	1		0	44
05/06/2025 10:00	1		0	44
05/06/2025 11:00	1		0	44
05/06/2025 12:00	1		0	44
05/06/2025 13:00	1		0	44
05/06/2025 14:00	1		0	44
05/06/2025 15:00	1		0	44
05/06/2025 16:00	1		0	44
05/06/2025 17:00	1		0	46
05/06/2025 18:00	1		0	51
05/06/2025 19:00	1		0	55
05/06/2025 20:00	1		0	58
05/06/2025 21:00	1		0	58
05/06/2025 22:00	1		0	58
05/06/2025 23:00	1		0	57
Average/Sum#:	24 #		0	50
Minimum:	1		0	44
Maximum:	1		0	58
%SI	0.00		0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF		Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)		1 Hour(s)	1 Hour(s)
05/07/2025 00:00	1		0	53
05/07/2025 01:00	1		0	48
05/07/2025 02:00	1		0	45
05/07/2025 03:00	1		0	45
05/07/2025 04:00	1		0	45
05/07/2025 05:00	1		0	45
05/07/2025 06:00	1		0	44
05/07/2025 07:00	1		0	44
05/07/2025 08:00	1		3	48
05/07/2025 09:00	1		17	48
05/07/2025 10:00	1		32	48
05/07/2025 11:00	1		45	45
05/07/2025 12:00	1		46	46
05/07/2025 13:00	1		46	43
05/07/2025 14:00	1		46	27
05/07/2025 15:00	1		46	12
05/07/2025 16:00	1		45	0
05/07/2025 17:00	1		45	0
05/07/2025 18:00	1		45	0
05/07/2025 19:00	1		46	0
05/07/2025 20:00	1		45	0
05/07/2025 21:00	1		44	0
05/07/2025 22:00	1		44	0
05/07/2025 23:00	1		44	0
Average/Sum#:	24 #		27	29
Minimum:	1		0	0
Maximum:	1		46	53
%SI	0.00		0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF		Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)		1 Hour(s)	1 Hour(s)
05/08/2025 00:00	1		44	0
05/08/2025 01:00	1		44	0
05/08/2025 02:00	1		44	0
05/08/2025 03:00	1		44	0
05/08/2025 04:00	1		44	0
05/08/2025 05:00	1		44	0
05/08/2025 06:00	1		44	0
05/08/2025 07:00	1		44	0
05/08/2025 08:00	1		44	0
05/08/2025 09:00	1		44	0
05/08/2025 10:00	1		44	0
05/08/2025 11:00	1		45	0
05/08/2025 12:00	1		45	0
05/08/2025 13:00	1		45	0
05/08/2025 14:00	1		45	0
05/08/2025 15:00	1		45	0
05/08/2025 16:00	1		45	0
05/08/2025 17:00	1		48	0
05/08/2025 18:00	1		54	0
05/08/2025 19:00	1		62	0
05/08/2025 20:00	1		70	0
05/08/2025 21:00	1		75	0
05/08/2025 22:00	1		76	0
05/08/2025 23:00	1		74	0
Average/Sum#:	24 #		51	0
Minimum:	1		44	0
Maximum:	1		76	0
%SI	0.00		0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF		Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)		1 Hour(s)	1 Hour(s)
05/09/2025 00:00	1		67	0
05/09/2025 01:00	1		58	8
05/09/2025 02:00	1		54	27
05/09/2025 03:00	1		54	47
05/09/2025 04:00	1		58	59
05/09/2025 05:00	1		57	58
05/09/2025 06:00	1		49	55
05/09/2025 07:00	1		29	49
05/09/2025 08:00	1		11	46
05/09/2025 09:00	1		0	44
05/09/2025 10:00	1		0	44
05/09/2025 11:00	1		0	44
05/09/2025 12:00	1		0	44
05/09/2025 13:00	1		0	44
05/09/2025 14:00	1		0	45
05/09/2025 15:00	1		0	45
05/09/2025 16:00	1		0	46
05/09/2025 17:00	1		8	45
05/09/2025 18:00	1		25	48
05/09/2025 19:00	1		45	52
05/09/2025 20:00	1		57	58
05/09/2025 21:00	1		60	61
05/09/2025 22:00	1		60	61
05/09/2025 23:00	1		60	61
Average/Sum#:	24 #		31	45
Minimum:	1		0	0
Maximum:	1		67	61
%SI	0.00		0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/10/2025 00:00	1	60	61
05/10/2025 01:00	1	57	58
05/10/2025 02:00	1	51	53
05/10/2025 03:00	1	31	49
05/10/2025 04:00	1	14	47
05/10/2025 05:00	1	0	45
05/10/2025 06:00	1	0	45
05/10/2025 07:00	1	0	44
05/10/2025 08:00	1	0	45
05/10/2025 09:00	1	0	45
05/10/2025 10:00	1	0	45
05/10/2025 11:00	1	0	45
05/10/2025 12:00	1	0	45
05/10/2025 13:00	1	0	44
05/10/2025 14:00	1	0	44
05/10/2025 15:00	1	0	44
05/10/2025 16:00	1	0	44
05/10/2025 17:00	1	0	46
05/10/2025 18:00	1	0	51
05/10/2025 19:00	1	8	52
05/10/2025 20:00	1	26	55
05/10/2025 21:00	1	46	56
05/10/2025 22:00	1	58	60
05/10/2025 23:00	1	58	59
Average/Sum#:	24 #	17	49
Minimum:	1	0	44
Maximum:	1	60	61
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/11/2025 00:00	1	53	57
05/11/2025 01:00	1	33	52
05/11/2025 02:00	1	15	49
05/11/2025 03:00	1	0	45
05/11/2025 04:00	1	0	44
05/11/2025 05:00	1	0	44
05/11/2025 06:00	1	0	44
05/11/2025 07:00	1	0	45
05/11/2025 08:00	1	0	45
05/11/2025 09:00	1	0	45
05/11/2025 10:00	1	0	45
05/11/2025 11:00	1	0	45
05/11/2025 12:00	1	0	45
05/11/2025 13:00	1	0	45
05/11/2025 14:00	1	0	45
05/11/2025 15:00	1	0	45
05/11/2025 16:00	1	0	44
05/11/2025 17:00	1	0	46
05/11/2025 18:00	1	0	46
05/11/2025 19:00	1	0	47
05/11/2025 20:00	1	0	46
05/11/2025 21:00	1	0	46
05/11/2025 22:00	1	0	46
05/11/2025 23:00	1	0	45
Average/Sum#:	24 #	4	46
Minimum:	1	0	44
Maximum:	1	53	57
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF		Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)		1 Hour(s)	1 Hour(s)
05/12/2025 00:00	1		0	45
05/12/2025 01:00	1		0	45
05/12/2025 02:00	1		0	45
05/12/2025 03:00	1		0	45
05/12/2025 04:00	1		0	44
05/12/2025 05:00	1		0	44
05/12/2025 06:00	1		0	44
05/12/2025 07:00	1		0	44
05/12/2025 08:00	1		0	44
05/12/2025 09:00	1		0	44
05/12/2025 10:00	1		0	44
05/12/2025 11:00	1		0	44
05/12/2025 12:00	1		0	44
05/12/2025 13:00	1		0	44
05/12/2025 14:00	1		0	44
05/12/2025 15:00	1		0	44
05/12/2025 16:00	1		0	44
05/12/2025 17:00	1		0	44
05/12/2025 18:00	1		0	44
05/12/2025 19:00	1		0	44
05/12/2025 20:00	1		0	44
05/12/2025 21:00	1		0	44
05/12/2025 22:00	1		0	44
05/12/2025 23:00	1		0	44
Average/Sum#:	24 #		0	44
Minimum:	1		0	44
Maximum:	1		0	45
%SI	0.00		0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/13/2025 00:00	1	0	44
05/13/2025 01:00	1	0	44
05/13/2025 02:00	1	0	44
05/13/2025 03:00	1	0	44
05/13/2025 04:00	1	0	44
05/13/2025 05:00	1	0	44
05/13/2025 06:00	1	0	44
05/13/2025 07:00	1	0	44
05/13/2025 08:00	1	0	44
05/13/2025 09:00	1	0	44
05/13/2025 10:00	1	0	44
05/13/2025 11:00	1	0	44
05/13/2025 12:00	1	0	44
05/13/2025 13:00	1	0	44
05/13/2025 14:00	1	0	44
05/13/2025 15:00	1	0	44
05/13/2025 16:00	1	0	44
05/13/2025 17:00	1	0	44
05/13/2025 18:00	1	0	44
05/13/2025 19:00	1	0	44
05/13/2025 20:00	1	0	44
05/13/2025 21:00	1	0	44
05/13/2025 22:00	1	0	44
05/13/2025 23:00	1	0	44
Average/Sum#:	24 #	0	44
Minimum:	1	0	44
Maximum:	1	0	44
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/14/2025 00:00	1	0	44
05/14/2025 01:00	1	0	44
05/14/2025 02:00	1	0	44
05/14/2025 03:00	1	0	44
05/14/2025 04:00	1	0	44
05/14/2025 05:00	1	0	46
05/14/2025 06:00	1	0	46
05/14/2025 07:00	1	0	45
05/14/2025 08:00	1	0	44
05/14/2025 09:00	1	0	44
05/14/2025 10:00	1	0	44
05/14/2025 11:00	1	0	44
05/14/2025 12:00	1	0	44
05/14/2025 13:00	1	0	44
05/14/2025 14:00	1	0	44
05/14/2025 15:00	1	0	44
05/14/2025 16:00	1	0	44
05/14/2025 17:00	1	0	44
05/14/2025 18:00	1	0	44
05/14/2025 19:00	1	0	44
05/14/2025 20:00	1	0	44
05/14/2025 21:00	1	0	44
05/14/2025 22:00	1	0	44
05/14/2025 23:00	1	0	44
Average/Sum#:	24 #	0	44
Minimum:	1	0	44
Maximum:	1	0	46
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/15/2025 00:00	1	0	44
05/15/2025 01:00	1	0	44
05/15/2025 02:00	1	0	44
05/15/2025 03:00	1	0	44
05/15/2025 04:00	1	0	44
05/15/2025 05:00	1	0	44
05/15/2025 06:00	1	0	44
05/15/2025 07:00	1	0	44
05/15/2025 08:00	1	0	44
05/15/2025 09:00	1	0	44
05/15/2025 10:00	1	0	44
05/15/2025 11:00	1	0	44
05/15/2025 12:00	1	0	44
05/15/2025 13:00	1	0	44
05/15/2025 14:00	1	0	44
05/15/2025 15:00	1	0	44
05/15/2025 16:00	1	0	44
05/15/2025 17:00	1	0	45
05/15/2025 18:00	1	0	45
05/15/2025 19:00	1	0	45
05/15/2025 20:00	1	0	44
05/15/2025 21:00	1	0	44
05/15/2025 22:00	1	0	44
05/15/2025 23:00	1	0	44
Average/Sum#:	24 #	0	44
Minimum:	1	0	44
Maximum:	1	0	45
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/16/2025 00:00	1	0	44
05/16/2025 01:00	1	0	44
05/16/2025 02:00	1	0	44
05/16/2025 03:00	1	0	44
05/16/2025 04:00	1	0	44
05/16/2025 05:00	1	0	44
05/16/2025 06:00	1	0	44
05/16/2025 07:00	1	0	44
05/16/2025 08:00	1	0	44
05/16/2025 09:00	1	0	44
05/16/2025 10:00	1	0	44
05/16/2025 11:00	1	0	44
05/16/2025 12:00	1	0	46
05/16/2025 13:00	1	0	51
05/16/2025 14:00	1	5	53
05/16/2025 15:00	1	20	51
05/16/2025 16:00	1	35	47
05/16/2025 17:00	1	47	47
05/16/2025 18:00	1	49	50
05/16/2025 19:00	1	49	50
05/16/2025 20:00	1	47	48
05/16/2025 21:00	1	33	46
05/16/2025 22:00	1	17	49
05/16/2025 23:00	1	3	52
Average/Sum#:	24 #	13	47
Minimum:	1	0	44
Maximum:	1	49	53
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/17/2025 00:00	1	0	55
05/17/2025 01:00	1	0	52
05/17/2025 02:00	1	0	47
05/17/2025 03:00	1	0	44
05/17/2025 04:00	1	0	44
05/17/2025 05:00	1	0	44
05/17/2025 06:00	1	0	48
05/17/2025 07:00	1	0	50
05/17/2025 08:00	1	0	49
05/17/2025 09:00	1	0	46
05/17/2025 10:00	1	0	43
05/17/2025 11:00	1	0	43
05/17/2025 12:00	1	0	44
05/17/2025 13:00	1	0	44
05/17/2025 14:00	1	0	44
05/17/2025 15:00	1	0	44
05/17/2025 16:00	1	0	44
05/17/2025 17:00	1	0	44
05/17/2025 18:00	1	0	44
05/17/2025 19:00	1	0	44
05/17/2025 20:00	1	0	44
05/17/2025 21:00	1	0	43
05/17/2025 22:00	1	0	43
05/17/2025 23:00	1	0	43
Average/Sum#:	24 #	0	45
Minimum:	1	0	43
Maximum:	1	0	55
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/18/2025 00:00	1	0	43
05/18/2025 01:00	1	0	44
05/18/2025 02:00	1	0	44
05/18/2025 03:00	1	0	44
05/18/2025 04:00	1	0	44
05/18/2025 05:00	1	0	44
05/18/2025 06:00	1	0	43
05/18/2025 07:00	1	0	43
05/18/2025 08:00	1	0	44
05/18/2025 09:00	1	0	44
05/18/2025 10:00	1	0	44
05/18/2025 11:00	1	0	44
05/18/2025 12:00	1	0	44
05/18/2025 13:00	1	0	44
05/18/2025 14:00	1	0	43
05/18/2025 15:00	1	0	43
05/18/2025 16:00	1	0	43
05/18/2025 17:00	1	0	43
05/18/2025 18:00	1	0	45
05/18/2025 19:00	1	0	45
05/18/2025 20:00	1	0	45
05/18/2025 21:00	1	0	43
05/18/2025 22:00	1	0	43
05/18/2025 23:00	1	0	43
Average/Sum#:	24 #	0	44
Minimum:	1	0	43
Maximum:	1	0	45
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/19/2025 00:00	1	0	43
05/19/2025 01:00	1	0	43
05/19/2025 02:00	1	0	43
05/19/2025 03:00	1	8	46
05/19/2025 04:00	1	24	48
05/19/2025 05:00	1	39	48
05/19/2025 06:00	1	48	49
05/19/2025 07:00	1	56	58
05/19/2025 08:00	1	66	69
05/19/2025 09:00	1	74	78
05/19/2025 10:00	1	75	79
05/19/2025 11:00	1	75	79
05/19/2025 12:00	1	75	79
05/19/2025 13:00	1	75	79
05/19/2025 14:00	1	75	79
05/19/2025 15:00	1	75	79
05/19/2025 16:00	1	75	79
05/19/2025 17:00	1	75	79
05/19/2025 18:00	1	75	79
05/19/2025 19:00	1	69	73
05/19/2025 20:00	1	60	62
05/19/2025 21:00	1	55	56
05/19/2025 22:00	1	55	56
05/19/2025 23:00	1	60	61
Average/Sum#:	24 #	54	64
Minimum:	1	0	43
Maximum:	1	75	79
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF		Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)		1 Hour(s)	1 Hour(s)
05/20/2025 00:00	1		60	61
05/20/2025 01:00	1		60	61
05/20/2025 02:00	1		60	61
05/20/2025 03:00	1		61	62
05/20/2025 04:00	1		64	66
05/20/2025 05:00	1		69	72
05/20/2025 06:00	1		74	78
05/20/2025 07:00	1		75	79
05/20/2025 08:00	1		75	79
05/20/2025 09:00	1		75	79
05/20/2025 10:00	1		76	79
05/20/2025 11:00	1		76	78
05/20/2025 12:00	1		76	78
05/20/2025 13:00	1		76	78
05/20/2025 14:00	1		76	78
05/20/2025 15:00	1		76	78
05/20/2025 16:00	1		74	77
05/20/2025 17:00	1		71	75
05/20/2025 18:00	1		69	74
05/20/2025 19:00	1		70	74
05/20/2025 20:00	1		71	77
05/20/2025 21:00	1		73	79
05/20/2025 22:00	1		70	77
05/20/2025 23:00	1		67	72
Average/Sum#:	24 #		71	74
Minimum:	1		60	61
Maximum:	1		76	79
%SI	0.00		0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/21/2025 00:00	1	60	63
05/21/2025 01:00	1	40	55
05/21/2025 02:00	1	19	49
05/21/2025 03:00	1	2	45
05/21/2025 04:00	1	0	45
05/21/2025 05:00	1	0	45
05/21/2025 06:00	1	0	44
05/21/2025 07:00	1	0	44
05/21/2025 08:00	1	0	44
05/21/2025 09:00	1	0	44
05/21/2025 10:00	1	0	44
05/21/2025 11:00	1	0	44
05/21/2025 12:00	1	0	44
05/21/2025 13:00	1	0	44
05/21/2025 14:00	1	0	44
05/21/2025 15:00	1	0	44
05/21/2025 16:00	1	0	44
05/21/2025 17:00	1	0	48
05/21/2025 18:00	1	13	48
05/21/2025 19:00	1	33	54
05/21/2025 20:00	1	51	54
05/21/2025 21:00	1	54	55
05/21/2025 22:00	1	46	52
05/21/2025 23:00	1	28	48
Average/Sum#:	24 #	14	48
Minimum:	1	0	44
Maximum:	1	60	63
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF		Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)		1 Hour(s)	1 Hour(s)
05/22/2025 00:00	1		11	47
05/22/2025 01:00	1		0	45
05/22/2025 02:00	1		0	45
05/22/2025 03:00	1		0	45
05/22/2025 04:00	1		0	45
05/22/2025 05:00	1		0	45
05/22/2025 06:00	1		0	45
05/22/2025 07:00	1		0	45
05/22/2025 08:00	1		0	45
05/22/2025 09:00	1		0	45
05/22/2025 10:00	1		0	45
05/22/2025 11:00	1		0	45
05/22/2025 12:00	1		0	45
05/22/2025 13:00	1		0	44
05/22/2025 14:00	1		0	44
05/22/2025 15:00	1		0	44
05/22/2025 16:00	1		0	44
05/22/2025 17:00	1		0	44
05/22/2025 18:00	1		0	44
05/22/2025 19:00	1		0	44
05/22/2025 20:00	1		0	44
05/22/2025 21:00	1		0	44
05/22/2025 22:00	1		0	44
05/22/2025 23:00	1		0	44
Average/Sum#:	24 #		0	45
Minimum:	1		0	44
Maximum:	1		11	47
%SI	0.00		0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF		Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)		1 Hour(s)	1 Hour(s)
05/23/2025 00:00	1		0	44
05/23/2025 01:00	1		0	44
05/23/2025 02:00	1		0	45
05/23/2025 03:00	1		0	45
05/23/2025 04:00	1		0	45
05/23/2025 05:00	1		0	45
05/23/2025 06:00	1		0	45
05/23/2025 07:00	1		0	44
05/23/2025 08:00	1		0	45
05/23/2025 09:00	1		0	45
05/23/2025 10:00	1		0	45
05/23/2025 11:00	1		0	45
05/23/2025 12:00	1		0	45
05/23/2025 13:00	1		0	45
05/23/2025 14:00	1		0	45
05/23/2025 15:00	1		0	45
05/23/2025 16:00	1		0	44
05/23/2025 17:00	1		0	46
05/23/2025 18:00	1		0	46
05/23/2025 19:00	1		0	47
05/23/2025 20:00	1		0	47
05/23/2025 21:00	1		0	49
05/23/2025 22:00	1		0	50
05/23/2025 23:00	1		0	53
Average/Sum#:	24 #		0	46
Minimum:	1		0	44
Maximum:	1		0	53
%SI	0.00		0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/24/2025 00:00	1	0	53
05/24/2025 01:00	1	0	53
05/24/2025 02:00	1	0	49
05/24/2025 03:00	1	0	45
05/24/2025 04:00	1	0	44
05/24/2025 05:00	1	0	44
05/24/2025 06:00	1	0	44
05/24/2025 07:00	1	0	44
05/24/2025 08:00	1	0	44
05/24/2025 09:00	1	0	44
05/24/2025 10:00	1	0	44
05/24/2025 11:00	1	0	44
05/24/2025 12:00	1	0	44
05/24/2025 13:00	1	0	44
05/24/2025 14:00	1	0	44
05/24/2025 15:00	1	0	44
05/24/2025 16:00	1	0	44
05/24/2025 17:00	1	0	46
05/24/2025 18:00	1	0	48
05/24/2025 19:00	1	0	48
05/24/2025 20:00	1	0	47
05/24/2025 21:00	1	0	44
05/24/2025 22:00	1	0	44
05/24/2025 23:00	1	0	44
Average/Sum#:	24 #	0	46
Minimum:	1	0	44
Maximum:	1	0	53
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF		Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)		1 Hour(s)	1 Hour(s)
05/25/2025 00:00	1		0	44
05/25/2025 01:00	1		0	44
05/25/2025 02:00	1		0	44
05/25/2025 03:00	1		0	44
05/25/2025 04:00	1		0	44
05/25/2025 05:00	1		0	46
05/25/2025 06:00	1		0	46
05/25/2025 07:00	1		0	45
05/25/2025 08:00	1		0	44
05/25/2025 09:00	1		0	44
05/25/2025 10:00	1		0	44
05/25/2025 11:00	1		0	44
05/25/2025 12:00	1		0	44
05/25/2025 13:00	1		0	44
05/25/2025 14:00	1		0	44
05/25/2025 15:00	1		0	44
05/25/2025 16:00	1		0	44
05/25/2025 17:00	1		0	44
05/25/2025 18:00	1		0	44
05/25/2025 19:00	1		0	44
05/25/2025 20:00	1		0	44
05/25/2025 21:00	1		0	44
05/25/2025 22:00	1		0	44
05/25/2025 23:00	1		0	44
Average/Sum#:	24 #		0	44
Minimum:	1		0	44
Maximum:	1		0	46
%SI	0.00		0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/26/2025 00:00	1	0	44
05/26/2025 01:00	1	0	44
05/26/2025 02:00	1	0	44
05/26/2025 03:00	1	0	44
05/26/2025 04:00	1	0	44
05/26/2025 05:00	1	0	44
05/26/2025 06:00	1	0	44
05/26/2025 07:00	1	0	44
05/26/2025 08:00	1	0	44
05/26/2025 09:00	1	0	44
05/26/2025 10:00	1	0	44
05/26/2025 11:00	1	0	44
05/26/2025 12:00	1	0	44
05/26/2025 13:00	1	0	44
05/26/2025 14:00	1	0	44
05/26/2025 15:00	1	0	44
05/26/2025 16:00	1	0	44
05/26/2025 17:00	1	0	44
05/26/2025 18:00	1	0	44
05/26/2025 19:00	1	0	44
05/26/2025 20:00	1	0	44
05/26/2025 21:00	1	0	44
05/26/2025 22:00	1	0	44
05/26/2025 23:00	1	0	44
Average/Sum#:	24 #	0	44
Minimum:	1	0	44
Maximum:	1	0	44
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/27/2025 00:00	1	0	44
05/27/2025 01:00	1	0	44
05/27/2025 02:00	1	0	44
05/27/2025 03:00	1	0	44
05/27/2025 04:00	1	0	44
05/27/2025 05:00	1	0	44
05/27/2025 06:00	1	0	44
05/27/2025 07:00	1	0	44
05/27/2025 08:00	1	0	44
05/27/2025 09:00	1	0	44
05/27/2025 10:00	1	0	47
05/27/2025 11:00	1	0	50
05/27/2025 12:00	1	0	51
05/27/2025 13:00	1	0	49
05/27/2025 14:00	1	0	49
05/27/2025 15:00	1	0	53
05/27/2025 16:00	1	0	54
05/27/2025 17:00	1	0	53
05/27/2025 18:00	1	0	54
05/27/2025 19:00	1	0	57
05/27/2025 20:00	1	0	59
05/27/2025 21:00	1	0	59
05/27/2025 22:00	1	0	59
05/27/2025 23:00	1	0	59
Average/Sum#:	24 #	0	50
Minimum:	1	0	44
Maximum:	1	0	59
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/28/2025 00:00	1	0	59
05/28/2025 01:00	1	0	59
05/28/2025 02:00	1	0	59
05/28/2025 03:00	1	0	59
05/28/2025 04:00	1	0	57
05/28/2025 05:00	1	0	53
05/28/2025 06:00	1	0	49
05/28/2025 07:00	1	0	46
05/28/2025 08:00	1	0	45
05/28/2025 09:00	1	0	45
05/28/2025 10:00	1	0	45
05/28/2025 11:00	1	0	45
05/28/2025 12:00	1	0	44
05/28/2025 13:00	1	0	44
05/28/2025 14:00	1	0	44
05/28/2025 15:00	1	0	45
05/28/2025 16:00	1	0	45
05/28/2025 17:00	1	0	45
05/28/2025 18:00	1	0	48
05/28/2025 19:00	1	0	48
05/28/2025 20:00	1	0	48
05/28/2025 21:00	1	0	44
05/28/2025 22:00	1	0	44
05/28/2025 23:00	1	0	44
Average/Sum#:	24 #	0	49
Minimum:	1	0	44
Maximum:	1	0	59
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF		Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)		1 Hour(s)	1 Hour(s)
05/29/2025 00:00	1		0	44
05/29/2025 01:00	1		0	44
05/29/2025 02:00	1		0	44
05/29/2025 03:00	1		0	44
05/29/2025 04:00	1		0	46
05/29/2025 05:00	1		0	47
05/29/2025 06:00	1		0	48
05/29/2025 07:00	1		0	46
05/29/2025 08:00	1		0	45
05/29/2025 09:00	1		0	45
05/29/2025 10:00	1		0	45
05/29/2025 11:00	1		0	45
05/29/2025 12:00	1		0	45
05/29/2025 13:00	1		0	45
05/29/2025 14:00	1		0	45
05/29/2025 15:00	1		0	45
05/29/2025 16:00	1		0	45
05/29/2025 17:00	1		0	46
05/29/2025 18:00	1		0	45
05/29/2025 19:00	1		0	45
05/29/2025 20:00	1		0	44
05/29/2025 21:00	1		0	44
05/29/2025 22:00	1		0	44
05/29/2025 23:00	1		0	44
Average/Sum#:	24 #		0	45
Minimum:	1		0	44
Maximum:	1		0	48
%SI	0.00		0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF		Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)		1 Hour(s)	1 Hour(s)
05/30/2025 00:00	1		0	44
05/30/2025 01:00	1		0	44
05/30/2025 02:00	1		0	44
05/30/2025 03:00	1		0	44
05/30/2025 04:00	1		0	44
05/30/2025 05:00	1		0	44
05/30/2025 06:00	1		0	45
05/30/2025 07:00	1		0	45
05/30/2025 08:00	1		0	45
05/30/2025 09:00	1		0	45
05/30/2025 10:00	1		0	45
05/30/2025 11:00	1		0	45
05/30/2025 12:00	1		0	46
05/30/2025 13:00	1		0	49
05/30/2025 14:00	1		0	52
05/30/2025 15:00	1		0	54
05/30/2025 16:00	1		5	53
05/30/2025 17:00	1		19	52
05/30/2025 18:00	1		37	53
05/30/2025 19:00	1		51	55
05/30/2025 20:00	1		56	58
05/30/2025 21:00	1		58	60
05/30/2025 22:00	1		57	59
05/30/2025 23:00	1		56	57
Average/Sum#:	24 #		14	49
Minimum:	1		0	44
Maximum:	1		58	60
%SI	0.00		0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF		Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/31/2025 00:00	1	52	53	
05/31/2025 01:00	1	50	51	
05/31/2025 02:00	1	33	49	
05/31/2025 03:00	1	17	47	
05/31/2025 04:00	1	1	46	
05/31/2025 05:00	1	0	45	
05/31/2025 06:00	1	0	45	
05/31/2025 07:00	1	0	45	
05/31/2025 08:00	1	0	45	
05/31/2025 09:00	1	0	45	
05/31/2025 10:00	1	0	45	
05/31/2025 11:00	1	0	45	
05/31/2025 12:00	1	0	45	
05/31/2025 13:00	1	0	45	
05/31/2025 14:00	1	0	45	
05/31/2025 15:00	1	0	45	
05/31/2025 16:00	1	0	46	
05/31/2025 17:00	1	0	48	
05/31/2025 18:00	1	0	52	
05/31/2025 19:00	1	0	56	
05/31/2025 20:00	1	0	58	
05/31/2025 21:00	1	0	56	
05/31/2025 22:00	1	0	54	
05/31/2025 23:00	1	0	50	
Average/Sum#:	24 #	6	48	
Minimum:	1	0	45	
Maximum:	1	52	58	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/01/2025 00:00	1	0	47
06/01/2025 01:00	1	0	45
06/01/2025 02:00	1	0	45
06/01/2025 03:00	1	0	45
06/01/2025 04:00	1	0	45
06/01/2025 05:00	1	0	45
06/01/2025 06:00	1	0	45
06/01/2025 07:00	1	0	45
06/01/2025 08:00	1	0	45
06/01/2025 09:00	1	0	45
06/01/2025 10:00	1	0	45
06/01/2025 11:00	1	0	45
06/01/2025 12:00	1	0	45
06/01/2025 13:00	1	0	45
06/01/2025 14:00	1	0	45
06/01/2025 15:00	1	0	45
06/01/2025 16:00	1	0	45
06/01/2025 17:00	1	0	45
06/01/2025 18:00	1	0	44
06/01/2025 19:00	1	0	45
06/01/2025 20:00	1	0	44
06/01/2025 21:00	1	0	44
06/01/2025 22:00	1	0	44
06/01/2025 23:00	1	0	44
Average/Sum#:	24 #	0	45
Minimum:	1	0	44
Maximum:	1	0	47
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/02/2025 00:00	1	0	44
06/02/2025 01:00	1	0	44
06/02/2025 02:00	1	0	44
06/02/2025 03:00	1	0	44
06/02/2025 04:00	1	0	46
06/02/2025 05:00	1	0	49
06/02/2025 06:00	1	0	49
06/02/2025 07:00	1	0	47
06/02/2025 08:00	1	0	44
06/02/2025 09:00	1	0	44
06/02/2025 10:00	1	0	44
06/02/2025 11:00	1	0	44
06/02/2025 12:00	1	0	44
06/02/2025 13:00	1	0	44
06/02/2025 14:00	1	0	45
06/02/2025 15:00	1	0	46
06/02/2025 16:00	1	0	46
06/02/2025 17:00	1	0	46
06/02/2025 18:00	1	0	51
06/02/2025 19:00	1	0	56
06/02/2025 20:00	1	0	59
06/02/2025 21:00	1	0	55
06/02/2025 22:00	1	0	54
06/02/2025 23:00	1	0	50
Average/Sum#:	24 #	0	47
Minimum:	1	0	44
Maximum:	1	0	59
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/03/2025 00:00	1	0	49
06/03/2025 01:00	1	0	46
06/03/2025 02:00	1	0	45
06/03/2025 03:00	1	0	45
06/03/2025 04:00	1	0	45
06/03/2025 05:00	1	0	45
06/03/2025 06:00	1	0	46
06/03/2025 07:00	1	0	46
06/03/2025 08:00	1	0	48
06/03/2025 09:00	1	0	49
06/03/2025 10:00	1	0	53
06/03/2025 11:00	1	14	51
06/03/2025 12:00	1	30	49
06/03/2025 13:00	1	49	51
06/03/2025 14:00	1	54	55
06/03/2025 15:00	1	56	59
06/03/2025 16:00	1	37	55
06/03/2025 17:00	1	18	50
06/03/2025 18:00	1	1	46
06/03/2025 19:00	1	0	45
06/03/2025 20:00	1	0	45
06/03/2025 21:00	1	0	45
06/03/2025 22:00	1	0	45
06/03/2025 23:00	1	0	45
Average/Sum#:	24 #	11	48
Minimum:	1	0	45
Maximum:	1	56	59
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/04/2025 00:00	1	0	45
06/04/2025 01:00	1	0	45
06/04/2025 02:00	1	0	45
06/04/2025 03:00	1	0	45
06/04/2025 04:00	1	0	45
06/04/2025 05:00	1	0	45
06/04/2025 06:00	1	0	44
06/04/2025 07:00	1	0	44
06/04/2025 08:00	1	0	44
06/04/2025 09:00	1	0	44
06/04/2025 10:00	1	0	44
06/04/2025 11:00	1	0	44
06/04/2025 12:00	1	0	45
06/04/2025 13:00	1	0	45
06/04/2025 14:00	1	0	45
06/04/2025 15:00	1	0	45
06/04/2025 16:00	1	0	44
06/04/2025 17:00	1	0	45
06/04/2025 18:00	1	0	45
06/04/2025 19:00	1	0	45
06/04/2025 20:00	1	0	45
06/04/2025 21:00	1	0	45
06/04/2025 22:00	1	0	45
06/04/2025 23:00	1	0	46
Average/Sum#:	24 #	0	45
Minimum:	1	0	44
Maximum:	1	0	46
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/05/2025 00:00	1	0	45
06/05/2025 01:00	1	0	45
06/05/2025 02:00	1	0	44
06/05/2025 03:00	1	0	44
06/05/2025 04:00	1	0	44
06/05/2025 05:00	1	0	44
06/05/2025 06:00	1	0	44
06/05/2025 07:00	1	0	44
06/05/2025 08:00	1	0	44
06/05/2025 09:00	1	0	44
06/05/2025 10:00	1	0	45
06/05/2025 11:00	1	0	45
06/05/2025 12:00	1	0	45
06/05/2025 13:00	1	0	45
06/05/2025 14:00	1	0	44
06/05/2025 15:00	1	0	44
06/05/2025 16:00	1	0	45
06/05/2025 17:00	1	0	46
06/05/2025 18:00	1	0	46
06/05/2025 19:00	1	0	46
06/05/2025 20:00	1	0	45
06/05/2025 21:00	1	0	45
06/05/2025 22:00	1	0	45
06/05/2025 23:00	1	0	46
Average/Sum#:	24 #	0	45
Minimum:	1	0	44
Maximum:	1	0	46
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/06/2025 00:00	1	0	47
06/06/2025 01:00	1	0	47
06/06/2025 02:00	1	0	45
06/06/2025 03:00	1	0	45
06/06/2025 04:00	1	0	44
06/06/2025 05:00	1	0	44
06/06/2025 06:00	1	0	44
06/06/2025 07:00	1	0	44
06/06/2025 08:00	1	0	44
06/06/2025 09:00	1	0	44
06/06/2025 10:00	1	0	44
06/06/2025 11:00	1	0	44
06/06/2025 12:00	1	0	44
06/06/2025 13:00	1	0	44
06/06/2025 14:00	1	0	44
06/06/2025 15:00	1	0	44
06/06/2025 16:00	1	0	44
06/06/2025 17:00	1	0	44
06/06/2025 18:00	1	0	44
06/06/2025 19:00	1	0	44
06/06/2025 20:00	1	0	44
06/06/2025 21:00	1	0	44
06/06/2025 22:00	1	0	44
06/06/2025 23:00	1	0	44
Average/Sum#:	24 #	0	44
Minimum:	1	0	44
Maximum:	1	0	47
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/07/2025 00:00	1	0	44
06/07/2025 01:00	1	0	44
06/07/2025 02:00	1	0	44
06/07/2025 03:00	1	0	44
06/07/2025 04:00	1	0	44
06/07/2025 05:00	1	0	44
06/07/2025 06:00	1	0	44
06/07/2025 07:00	1	0	44
06/07/2025 08:00	1	0	44
06/07/2025 09:00	1	0	44
06/07/2025 10:00	1	0	44
06/07/2025 11:00	1	0	44
06/07/2025 12:00	1	0	44
06/07/2025 13:00	1	0	44
06/07/2025 14:00	1	0	44
06/07/2025 15:00	1	0	44
06/07/2025 16:00	1	0	45
06/07/2025 17:00	1	0	46
06/07/2025 18:00	1	0	50
06/07/2025 19:00	1	0	49
06/07/2025 20:00	1	0	48
06/07/2025 21:00	1	0	44
06/07/2025 22:00	1	0	44
06/07/2025 23:00	1	0	44
Average/Sum#:	24 #	0	45
Minimum:	1	0	44
Maximum:	1	0	50
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/08/2025 00:00	1	0	44
06/08/2025 01:00	1	0	44
06/08/2025 02:00	1	0	44
06/08/2025 03:00	1	0	44
06/08/2025 04:00	1	0	44
06/08/2025 05:00	1	0	44
06/08/2025 06:00	1	0	44
06/08/2025 07:00	1	0	44
06/08/2025 08:00	1	0	44
06/08/2025 09:00	1	0	44
06/08/2025 10:00	1	0	44
06/08/2025 11:00	1	0	44
06/08/2025 12:00	1	0	44
06/08/2025 13:00	1	0	44
06/08/2025 14:00	1	0	46
06/08/2025 15:00	1	0	47
06/08/2025 16:00	1	0	49
06/08/2025 17:00	1	0	49
06/08/2025 18:00	1	0	53
06/08/2025 19:00	1	0	55
06/08/2025 20:00	1	0	54
06/08/2025 21:00	1	0	51
06/08/2025 22:00	1	0	46
06/08/2025 23:00	1	0	46
Average/Sum#:	24 #	0	46
Minimum:	1	0	44
Maximum:	1	0	55
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF		Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/09/2025 00:00	1	0	44	
06/09/2025 01:00	1	0	44	
06/09/2025 02:00	1	0	44	
06/09/2025 03:00	1	0	44	
06/09/2025 04:00	1	0	45	
06/09/2025 05:00	1	0	45	
06/09/2025 06:00	1	0	45	
06/09/2025 07:00	1	0	45	
06/09/2025 08:00	1	0	45	
06/09/2025 09:00	1	0	44	
06/09/2025 10:00	1	0	44	
06/09/2025 11:00	1	0	44	
06/09/2025 12:00	1	0	44	
06/09/2025 13:00	1	0	44	
06/09/2025 14:00	1	0	44	
06/09/2025 15:00	1	0	44	
06/09/2025 16:00	1	0	45	
06/09/2025 17:00	1	10	46	
06/09/2025 18:00	1	29	52	
06/09/2025 19:00	1	53	61	
06/09/2025 20:00	1	65	68	
06/09/2025 21:00	1	62	64	
06/09/2025 22:00	1	53	54	
06/09/2025 23:00	1	47	48	
Average/Sum#:	24 #	13	48	
Minimum:	1	0	44	
Maximum:	1	65	68	
%SI	0.00	0.00	0.00	

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/10/2025 00:00	1	47	47
06/10/2025 01:00	1	47	47
06/10/2025 02:00	1	46	46
06/10/2025 03:00	1	46	46
06/10/2025 04:00	1	47	47
06/10/2025 05:00	1	47	48
06/10/2025 06:00	1	47	48
06/10/2025 07:00	1	47	47
06/10/2025 08:00	1	46	46
06/10/2025 09:00	1	46	46
06/10/2025 10:00	1	46	46
06/10/2025 11:00	1	46	47
06/10/2025 12:00	1	46	47
06/10/2025 13:00	1	46	47
06/10/2025 14:00	1	46	47
06/10/2025 15:00	1	47	48
06/10/2025 16:00	1	49	50
06/10/2025 17:00	1	51	53
06/10/2025 18:00	1	54	55
06/10/2025 19:00	1	52	54
06/10/2025 20:00	1	50	51
06/10/2025 21:00	1	46	47
06/10/2025 22:00	1	46	46
06/10/2025 23:00	1	45	46
Average/Sum#:	24 #	47	48
Minimum:	1	45	46
Maximum:	1	54	55
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/11/2025 00:00	1	45	46
06/11/2025 01:00	1	46	46
06/11/2025 02:00	1	46	47
06/11/2025 03:00	1	46	47
06/11/2025 04:00	1	46	47
06/11/2025 05:00	1	46	47
06/11/2025 06:00	1	46	46
06/11/2025 07:00	1	46	46
06/11/2025 08:00	1	46	46
06/11/2025 09:00	1	46	46
06/11/2025 10:00	1	46	46
06/11/2025 11:00	1	46	47
06/11/2025 12:00	1	46	47
06/11/2025 13:00	1	46	47
06/11/2025 14:00	1	46	47
06/11/2025 15:00	1	46	47
06/11/2025 16:00	1	46	47
06/11/2025 17:00	1	46	47
06/11/2025 18:00	1	46	47
06/11/2025 19:00	1	47	40
06/11/2025 20:00	1	47	24
06/11/2025 21:00	1	46	9
06/11/2025 22:00	1	45	0
06/11/2025 23:00	1	45	0
Average/Sum#:	24 #	46	40
Minimum:	1	45	0
Maximum:	1	47	47
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/12/2025 00:00	1	45	0
06/12/2025 01:00	1	45	0
06/12/2025 02:00	1	45	0
06/12/2025 03:00	1	45	0
06/12/2025 04:00	1	45	0
06/12/2025 05:00	1	45	0
06/12/2025 06:00	1	45	0
06/12/2025 07:00	1	45	0
06/12/2025 08:00	1	45	0
06/12/2025 09:00	1	45	0
06/12/2025 10:00	1	45	0
06/12/2025 11:00	1	45	0
06/12/2025 12:00	1	45	0
06/12/2025 13:00	1	45	0
06/12/2025 14:00	1	44	0
06/12/2025 15:00	1	44	0
06/12/2025 16:00	1	44	0
06/12/2025 17:00	1	44	0
06/12/2025 18:00	1	44	0
06/12/2025 19:00	1	44	0
06/12/2025 20:00	1	44	0
06/12/2025 21:00	1	44	0
06/12/2025 22:00	1	44	0
06/12/2025 23:00	1	47	0
Average/Sum#:	24 #	45	0
Minimum:	1	44	0
Maximum:	1	47	0
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF		Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)		1 Hour(s)	1 Hour(s)
06/13/2025 00:00	1		48	0
06/13/2025 01:00	1		48	0
06/13/2025 02:00	1		45	0
06/13/2025 03:00	1		44	0
06/13/2025 04:00	1		44	0
06/13/2025 05:00	1		44	0
06/13/2025 06:00	1		44	0
06/13/2025 07:00	1		44	0
06/13/2025 08:00	1		44	0
06/13/2025 09:00	1		44	0
06/13/2025 10:00	1		45	0
06/13/2025 11:00	1		45	0
06/13/2025 12:00	1		45	0
06/13/2025 13:00	1		45	0
06/13/2025 14:00	1		45	0
06/13/2025 15:00	1		45	0
06/13/2025 16:00	1		45	0
06/13/2025 17:00	1		45	0
06/13/2025 18:00	1		45	0
06/13/2025 19:00	1		45	0
06/13/2025 20:00	1		45	0
06/13/2025 21:00	1		45	0
06/13/2025 22:00	1		45	0
06/13/2025 23:00	1		45	0
Average/Sum#:	24 #		45	0
Minimum:	1		44	0
Maximum:	1		48	0
%SI	0.00		0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/14/2025 00:00	1	45	0
06/14/2025 01:00	1	45	0
06/14/2025 02:00	1	45	0
06/14/2025 03:00	1	45	0
06/14/2025 04:00	1	45	0
06/14/2025 05:00	1	45	0
06/14/2025 06:00	1	45	0
06/14/2025 07:00	1	45	0
06/14/2025 08:00	1	44	0
06/14/2025 09:00	1	44	0
06/14/2025 10:00	1	44	0
06/14/2025 11:00	1	44	0
06/14/2025 12:00	1	44	0
06/14/2025 13:00	1	44	0
06/14/2025 14:00	1	45	0
06/14/2025 15:00	1	45	0
06/14/2025 16:00	1	45	0
06/14/2025 17:00	1	45	0
06/14/2025 18:00	1	52	0
06/14/2025 19:00	1	60	0
06/14/2025 20:00	1	66	0
06/14/2025 21:00	1	63	0
06/14/2025 22:00	1	63	0
06/14/2025 23:00	1	63	0
Average/Sum#:	24 #	49	0
Minimum:	1	44	0
Maximum:	1	66	0
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/15/2025 00:00	1	66	0
06/15/2025 01:00	1	66	0
06/15/2025 02:00	1	65	0
06/15/2025 03:00	1	65	0
06/15/2025 04:00	1	66	0
06/15/2025 05:00	1	62	0
06/15/2025 06:00	1	54	0
06/15/2025 07:00	1	47	0
06/15/2025 08:00	1	44	0
06/15/2025 09:00	1	45	0
06/15/2025 10:00	1	45	0
06/15/2025 11:00	1	45	0
06/15/2025 12:00	1	45	0
06/15/2025 13:00	1	45	0
06/15/2025 14:00	1	45	0
06/15/2025 15:00	1	45	0
06/15/2025 16:00	1	48	0
06/15/2025 17:00	1	56	0
06/15/2025 18:00	1	65	0
06/15/2025 19:00	1	70	0
06/15/2025 20:00	1	69	0
06/15/2025 21:00	1	68	0
06/15/2025 22:00	1	67	0
06/15/2025 23:00	1	66	0
Average/Sum#:	24 #	57	0
Minimum:	1	44	0
Maximum:	1	70	0
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/16/2025 00:00	1	66	0
06/16/2025 01:00	1	66	0
06/16/2025 02:00	1	66	0
06/16/2025 03:00	1	66	0
06/16/2025 04:00	1	66	0
06/16/2025 05:00	1	63	0
06/16/2025 06:00	1	56	0
06/16/2025 07:00	1	49	0
06/16/2025 08:00	1	45	0
06/16/2025 09:00	1	45	0
06/16/2025 10:00	1	45	0
06/16/2025 11:00	1	45	0
06/16/2025 12:00	1	45	0
06/16/2025 13:00	1	45	0
06/16/2025 14:00	1	45	0
06/16/2025 15:00	1	47	0
06/16/2025 16:00	1	54	0
06/16/2025 17:00	1	62	0
06/16/2025 18:00	1	66	0
06/16/2025 19:00	1	67	0
06/16/2025 20:00	1	68	0
06/16/2025 21:00	1	67	0
06/16/2025 22:00	1	67	0
06/16/2025 23:00	1	67	0
Average/Sum#:	24 #	57	0
Minimum:	1	45	0
Maximum:	1	68	0
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/17/2025 00:00	1	67	0
06/17/2025 01:00	1	66	0
06/17/2025 02:00	1	65	0
06/17/2025 03:00	1	65	0
06/17/2025 04:00	1	66	0
06/17/2025 05:00	1	65	0
06/17/2025 06:00	1	59	0
06/17/2025 07:00	1	51	0
06/17/2025 08:00	1	45	0
06/17/2025 09:00	1	44	0
06/17/2025 10:00	1	45	0
06/17/2025 11:00	1	45	0
06/17/2025 12:00	1	45	0
06/17/2025 13:00	1	45	0
06/17/2025 14:00	1	46	0
06/17/2025 15:00	1	46	0
06/17/2025 16:00	1	49	0
06/17/2025 17:00	1	55	0
06/17/2025 18:00	1	65	0
06/17/2025 19:00	1	73	0
06/17/2025 20:00	1	73	0
06/17/2025 21:00	1	71	0
06/17/2025 22:00	1	68	0
06/17/2025 23:00	1	66	0
Average/Sum#:	24 #	58	0
Minimum:	1	44	0
Maximum:	1	73	0
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/18/2025 00:00	1	66	0
06/18/2025 01:00	1	66	0
06/18/2025 02:00	1	66	0
06/18/2025 03:00	1	66	0
06/18/2025 04:00	1	66	0
06/18/2025 05:00	1	66	0
06/18/2025 06:00	1	63	0
06/18/2025 07:00	1	56	0
06/18/2025 08:00	1	49	0
06/18/2025 09:00	1	45	0
06/18/2025 10:00	1	45	0
06/18/2025 11:00	1	45	0
06/18/2025 12:00	1	45	0
06/18/2025 13:00	1	45	0
06/18/2025 14:00	1	45	0
06/18/2025 15:00	1	45	0
06/18/2025 16:00	1	47	0
06/18/2025 17:00	1	54	0
06/18/2025 18:00	1	64	0
06/18/2025 19:00	1	70	0
06/18/2025 20:00	1	71	0
06/18/2025 21:00	1	69	0
06/18/2025 22:00	1	67	0
06/18/2025 23:00	1	66	0
Average/Sum#:	24 #	58	0
Minimum:	1	45	0
Maximum:	1	71	0
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/19/2025 00:00	1	66	0
06/19/2025 01:00	1	66	0
06/19/2025 02:00	1	66	0
06/19/2025 03:00	1	66	0
06/19/2025 04:00	1	66	0
06/19/2025 05:00	1	65	0
06/19/2025 06:00	1	58	0
06/19/2025 07:00	1	51	0
06/19/2025 08:00	1	45	0
06/19/2025 09:00	1	45	0
06/19/2025 10:00	1	45	0
06/19/2025 11:00	1	45	0
06/19/2025 12:00	1	45	0
06/19/2025 13:00	1	45	0
06/19/2025 14:00	1	45	0
06/19/2025 15:00	1	45	0
06/19/2025 16:00	1	45	0
06/19/2025 17:00	1	45	0
06/19/2025 18:00	1	45	0
06/19/2025 19:00	1	44	0
06/19/2025 20:00	1	44	0
06/19/2025 21:00	1	44	0
06/19/2025 22:00	1	44	0
06/19/2025 23:00	1	45	0
Average/Sum#:	24 #	51	0
Minimum:	1	44	0
Maximum:	1	66	0
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/20/2025 00:00	1	45	0
06/20/2025 01:00	1	45	0
06/20/2025 02:00	1	45	0
06/20/2025 03:00	1	45	0
06/20/2025 04:00	1	45	0
06/20/2025 05:00	1	45	0
06/20/2025 06:00	1	45	0
06/20/2025 07:00	1	45	0
06/20/2025 08:00	1	45	0
06/20/2025 09:00	1	45	0
06/20/2025 10:00	1	45	0
06/20/2025 11:00	1	44	0
06/20/2025 12:00	1	44	0
06/20/2025 13:00	1	45	0
06/20/2025 14:00	1	45	0
06/20/2025 15:00	1	45	0
06/20/2025 16:00	1	45	0
06/20/2025 17:00	1	45	0
06/20/2025 18:00	1	45	0
06/20/2025 19:00	1	44	0
06/20/2025 20:00	1	44	0
06/20/2025 21:00	1	44	0
06/20/2025 22:00	1	44	0
06/20/2025 23:00	1	44	0
Average/Sum#:	24 #	45	0
Minimum:	1	44	0
Maximum:	1	45	0
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/21/2025 00:00	1	44	0
06/21/2025 01:00	1	45	0
06/21/2025 02:00	1	45	0
06/21/2025 03:00	1	45	0
06/21/2025 04:00	1	45	0
06/21/2025 05:00	1	45	0
06/21/2025 06:00	1	45	0
06/21/2025 07:00	1	45	0
06/21/2025 08:00	1	45	0
06/21/2025 09:00	1	45	0
06/21/2025 10:00	1	45	0
06/21/2025 11:00	1	45	0
06/21/2025 12:00	1	45	0
06/21/2025 13:00	1	45	0
06/21/2025 14:00	1	45	0
06/21/2025 15:00	1	45	0
06/21/2025 16:00	1	44	0
06/21/2025 17:00	1	44	0
06/21/2025 18:00	1	44	0
06/21/2025 19:00	1	44	0
06/21/2025 20:00	1	44	0
06/21/2025 21:00	1	44	0
06/21/2025 22:00	1	44	0
06/21/2025 23:00	1	44	0
Average/Sum#:	24 #	45	0
Minimum:	1	44	0
Maximum:	1	45	0
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF		Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)		1 Hour(s)	1 Hour(s)
06/22/2025 00:00	1		44	0
06/22/2025 01:00	1		44	0
06/22/2025 02:00	1		44	0
06/22/2025 03:00	1		44	0
06/22/2025 04:00	1		44	0
06/22/2025 05:00	1		45	0
06/22/2025 06:00	1		45	0
06/22/2025 07:00	1		45	0
06/22/2025 08:00	1		44	0
06/22/2025 09:00	1		44	0
06/22/2025 10:00	1		44	0
06/22/2025 11:00	1		44	0
06/22/2025 12:00	1		44	0
06/22/2025 13:00	1		44	0
06/22/2025 14:00	1		44	0
06/22/2025 15:00	1		44	0
06/22/2025 16:00	1		44	0
06/22/2025 17:00	1		45	0
06/22/2025 18:00	1		45	0
06/22/2025 19:00	1		45	0
06/22/2025 20:00	1		44	0
06/22/2025 21:00	1		44	0
06/22/2025 22:00	1		44	0
06/22/2025 23:00	1		44	0
Average/Sum#:	24 #		44	0
Minimum:	1		44	0
Maximum:	1		45	0
%SI	0.00		0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF		Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)		1 Hour(s)	1 Hour(s)
06/23/2025 00:00	1		44	0
06/23/2025 01:00	1		44	0
06/23/2025 02:00	1		44	0
06/23/2025 03:00	1		44	0
06/23/2025 04:00	1		44	0
06/23/2025 05:00	1		46	0
06/23/2025 06:00	1		46	0
06/23/2025 07:00	1		46	0
06/23/2025 08:00	1		44	0
06/23/2025 09:00	1		44	0
06/23/2025 10:00	1		44	0
06/23/2025 11:00	1		44	0
06/23/2025 12:00	1		44	0
06/23/2025 13:00	1		44	0
06/23/2025 14:00	1		44	0
06/23/2025 15:00	1		44	0
06/23/2025 16:00	1		44	0
06/23/2025 17:00	1		45	0
06/23/2025 18:00	1		48	0
06/23/2025 19:00	1		51	0
06/23/2025 20:00	1		52	0
06/23/2025 21:00	1		52	0
06/23/2025 22:00	1		52	0
06/23/2025 23:00	1		54	0
Average/Sum#:	24 #		46	0
Minimum:	1		44	0
Maximum:	1		54	0
%SI	0.00		0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF		Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)		1 Hour(s)	1 Hour(s)
06/24/2025 00:00	1		53	0
06/24/2025 01:00	1		50	0
06/24/2025 02:00	1		50	0
06/24/2025 03:00	1		53	0
06/24/2025 04:00	1		56	0
06/24/2025 05:00	1		54	0
06/24/2025 06:00	1		50	0
06/24/2025 07:00	1		46	0
06/24/2025 08:00	1		44	0
06/24/2025 09:00	1		44	0
06/24/2025 10:00	1		44	0
06/24/2025 11:00	1		44	0
06/24/2025 12:00	1		44	0
06/24/2025 13:00	1		44	0
06/24/2025 14:00	1		44	0
06/24/2025 15:00	1		44	0
06/24/2025 16:00	1		44	0
06/24/2025 17:00	1		47	0
06/24/2025 18:00	1		48	0
06/24/2025 19:00	1		48	0
06/24/2025 20:00	1		46	0
06/24/2025 21:00	1		44	0
06/24/2025 22:00	1		44	0
06/24/2025 23:00	1		46	0
Average/Sum#:	24 #		47	0
Minimum:	1		44	0
Maximum:	1		56	0
%SI	0.00		0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF		Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)		1 Hour(s)	1 Hour(s)
06/25/2025 00:00	1		46	0
06/25/2025 01:00	1		46	0
06/25/2025 02:00	1		44	0
06/25/2025 03:00	1		44	0
06/25/2025 04:00	1		44	0
06/25/2025 05:00	1		45	0
06/25/2025 06:00	1		45	0
06/25/2025 07:00	1		44	0
06/25/2025 08:00	1		44	0
06/25/2025 09:00	1		44	0
06/25/2025 10:00	1		44	0
06/25/2025 11:00	1		44	0
06/25/2025 12:00	1		44	0
06/25/2025 13:00	1		44	0
06/25/2025 14:00	1		44	0
06/25/2025 15:00	1		44	0
06/25/2025 16:00	1		44	0
06/25/2025 17:00	1		45	0
06/25/2025 18:00	1		48	0
06/25/2025 19:00	1		51	0
06/25/2025 20:00	1		51	0
06/25/2025 21:00	1		48	0
06/25/2025 22:00	1		45	0
06/25/2025 23:00	1		44	0
Average/Sum#:	24 #		45	0
Minimum:	1		44	0
Maximum:	1		51	0
%SI	0.00		0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF		Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)		1 Hour(s)	1 Hour(s)
06/26/2025 00:00	1		44	0
06/26/2025 01:00	1		44	0
06/26/2025 02:00	1		44	0
06/26/2025 03:00	1		45	0
06/26/2025 04:00	1		45	0
06/26/2025 05:00	1		45	0
06/26/2025 06:00	1		45	0
06/26/2025 07:00	1		45	0
06/26/2025 08:00	1		45	0
06/26/2025 09:00	1		45	0
06/26/2025 10:00	1		44	0
06/26/2025 11:00	1		44	0
06/26/2025 12:00	1		44	0
06/26/2025 13:00	1		44	0
06/26/2025 14:00	1		44	0
06/26/2025 15:00	1		44	0
06/26/2025 16:00	1		44	0
06/26/2025 17:00	1		45	0
06/26/2025 18:00	1		47	0
06/26/2025 19:00	1		51	0
06/26/2025 20:00	1		53	0
06/26/2025 21:00	1		52	0
06/26/2025 22:00	1		48	0
06/26/2025 23:00	1		45	0
Average/Sum#:	24 #		46	0
Minimum:	1		44	0
Maximum:	1		53	0
%SI	0.00		0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF		Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)		1 Hour(s)	1 Hour(s)
06/27/2025 00:00	1		44	0
06/27/2025 01:00	1		44	0
06/27/2025 02:00	1		44	0
06/27/2025 03:00	1		44	0
06/27/2025 04:00	1		45	0
06/27/2025 05:00	1		47	0
06/27/2025 06:00	1		47	0
06/27/2025 07:00	1		46	0
06/27/2025 08:00	1		44	0
06/27/2025 09:00	1		44	0
06/27/2025 10:00	1		44	0
06/27/2025 11:00	1		44	0
06/27/2025 12:00	1		46	0
06/27/2025 13:00	1		50	0
06/27/2025 14:00	1		53	0
06/27/2025 15:00	1		54	0
06/27/2025 16:00	1		52	4
06/27/2025 17:00	1		51	22
06/27/2025 18:00	1		53	42
06/27/2025 19:00	1		62	65
06/27/2025 20:00	1		67	71
06/27/2025 21:00	1		66	71
06/27/2025 22:00	1		43	60
06/27/2025 23:00	1		20	51
Average/Sum#:	24 #		48	16
Minimum:	1		20	0
Maximum:	1		67	71
%SI	0.00		0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/28/2025 00:00	1	1	45
06/28/2025 01:00	1	0	44
06/28/2025 02:00	1	0	45
06/28/2025 03:00	1	0	45
06/28/2025 04:00	1	0	45
06/28/2025 05:00	1	0	45
06/28/2025 06:00	1	0	45
06/28/2025 07:00	1	0	45
06/28/2025 08:00	1	0	45
06/28/2025 09:00	1	0	45
06/28/2025 10:00	1	0	45
06/28/2025 11:00	1	0	45
06/28/2025 12:00	1	0	46
06/28/2025 13:00	1	0	47
06/28/2025 14:00	1	1	50
06/28/2025 15:00	1	16	51
06/28/2025 16:00	1	35	54
06/28/2025 17:00	1	54	56
06/28/2025 18:00	1	63	66
06/28/2025 19:00	1	70	74
06/28/2025 20:00	1	75	80
06/28/2025 21:00	1	76	81
06/28/2025 22:00	1	75	81
06/28/2025 23:00	1	72	80
Average/Sum#:	24 #	22	54
Minimum:	1	0	44
Maximum:	1	76	81
%SI	0.00	0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2		Unit CT1	Unit CT2
	UnitOn, TF		Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)		1 Hour(s)	1 Hour(s)
06/29/2025 00:00	1		64	71
06/29/2025 01:00	1		55	60
06/29/2025 02:00	1		34	50
06/29/2025 03:00	1		16	47
06/29/2025 04:00	1		1	48
06/29/2025 05:00	1		0	48
06/29/2025 06:00	1		0	48
06/29/2025 07:00	1		0	46
06/29/2025 08:00	1		0	45
06/29/2025 09:00	1		0	45
06/29/2025 10:00	1		0	45
06/29/2025 11:00	1		0	45
06/29/2025 12:00	1		0	45
06/29/2025 13:00	1		0	48
06/29/2025 14:00	1		0	52
06/29/2025 15:00	1		0	55
06/29/2025 16:00	1		5	54
06/29/2025 17:00	1		21	53
06/29/2025 18:00	1		40	53
06/29/2025 19:00	1		55	56
06/29/2025 20:00	1		57	58
06/29/2025 21:00	1		57	58
06/29/2025 22:00	1		52	55
06/29/2025 23:00	1		33	51
Average/Sum#:	24 #		20	52
Minimum:	1		0	45
Maximum:	1		64	71
%SI	0.00		0.00	0.00

AQ34 3HR AVG LOAD



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2	Unit CT1	Unit CT2
	UnitOn, TF	Load_Total_, 3Hr, MWe	Load_Total_, 3Hr, MWe
	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/30/2025 00:00	1	15	47
06/30/2025 01:00	1	0	45
06/30/2025 02:00	1	0	44
06/30/2025 03:00	1	0	44
06/30/2025 04:00	1	0	44
06/30/2025 05:00	1	0	44
06/30/2025 06:00	1	0	44
06/30/2025 07:00	1	0	44
06/30/2025 08:00	1	0	45
06/30/2025 09:00	1	0	45
06/30/2025 10:00	1	0	45
06/30/2025 11:00	1	0	44
06/30/2025 12:00	1	0	46
06/30/2025 13:00	1	0	49
06/30/2025 14:00	1	0	50
06/30/2025 15:00	1	0	51
06/30/2025 16:00	1	1	51
06/30/2025 17:00	1	17	52
06/30/2025 18:00	1	36	54
06/30/2025 19:00	1	54	55
06/30/2025 20:00	1	57	58
06/30/2025 21:00	1	56	57
06/30/2025 22:00	1	52	53
06/30/2025 23:00	1	51	52
Average/Sum#:	24 #	14	48
Minimum:	1	0	44
Maximum:	1	57	58
%SI	0.00	0.00	0.00

RegPerfect CEMS Logs

Log Time	Operator	Initials	Description	Tags	Files
06/22/2025 02:57	cro-operator	RC	REPLACE HIGH NOX/CO BOTTLE ON UNIT 1, CYLINDER NO 225701161, NOX @ 180.6PPM, CO @180.4PPM		
06/17/2025 22:56	cro-operator	RC	CORRECTION TO CT BOTTLE EB0096521 NOX VALUE @ 9.519PPM NOT 9.428PPM		
06/17/2025 22:52	cro-operator	RC	REPLACED CT-1 LO NOX/CO BOTTLE 9.428PPM/9.024PPM, CYL # EB0096521, EXP DATE 08/13/27		
06/11/2025 12:37	cro-operator	SM	CT2- STARTED HANDS FREE CAL INLET NOX ANALYZER		
06/11/2025 10:53	cro-operator	DC	CT 1- CHANGE O2 BOTTLE TO CYLINDER #213608054 CONC- 17.95, EXP- 12/08/2032		
06/11/2025 07:18	cro-operator	SM	CT-2 PERFORMED MANUAL CAL TO TRUE UP ANALYZER. SPANNED GOOD. WAITING FOR NEXT HOUR TO START AUTO CAL		
06/10/2025 11:24	cro-operator	DC	CT 2- CHANGED LOW INLET NOX BOTTLE CC362946 WITH CONCENTRATION OF 21.55 TOTAL NITROGEN OXIDES, 19.92 CO		
06/10/2025 07:50	cro-operator	BRB	CHANGED OUT DAILY HIGH NOX BOTTLE ON CT5, 452.1 CYL # 225702031, EXP 9/17/32		
06/07/2025 11:31	cro-operator	RC	REPLACE CT O2 BOTTLE, 17.98%, EXP DATE 09-16-32, CYLINDER # 225104102		
06/04/2025 20:02	cro-operator	AD	CT2 CHANGED HIGH NOC BOTTLE AND ENTERED NEW CYLINDER AND NOX VALUE OF 181.2PP AND CO OF 179PPM		
06/02/2025 16:24	cro-operator	SM	CT-6 ANUAL MAINTENANCE. REBUILT NOX REACTION CELL, VACUUM MANIFOLD AND O3 BIPASS VALVE, REPLACED DFU FILTER AND PARTICULATE FILTER FOR BOTH NOX ANALYZERS. REPLACED CO PUMP DIAPHRAGM AND PARTICULATE FILTER FOR CO ANALYZER. HANDS FREE CAL		
06/02/2025 16:20	cro-operator	SM	CT-5 ANUAL MAINTENANCE. REBUILT NOX REACTION CELL, VACUUM MANIFOLD AND O3 BIPASS VALVE, REPLACED DFU FILTER AND PARTICULATE FILTER FOR BOTH NOX ANALYZERS. REPLACED CO PUMP DIAPHRAGM AND PARTICULATE FILTER FOR CO ANALYZER. TROUBLE SHOT LOW SAMPLE FLOW. FOUND BAD ORICIFE IN VACUUM MANIFOLD. HANDS FREE CAL.		
06/01/2025 06:35	cro-operator	CMC	UPDATED GCV VALUES ON CT1, CT2, CT5, CT6 AND GCV_Gas TO 104900		
05/27/2025 13:11	cro-operator	SM	CT-6 SPANNED GAS. COMPLETED CGA'S. HI CO AND LO CO.		
05/27/2025 13:10	cro-operator	SM	CT-5 SPANNED GAS. COMPLETED CGA'S. HI CO AND LO CO.		
05/21/2025 16:37	cro-operator	BRB	5/16/25 ADDED CYL# EB0008336		

RegPerfect CEMS Logs

Log Time	Operator	Initials	Description	Tags	Files
			46.31 INLEX NOX CT6, EXP 2/20/26		
05/21/2025 09:31	cro-operator	SM	CT - 5 PERFORMED MANULA CAL AFTER START UP CEMS REPORT HAD A 1X ALARM FOR LNOX. AFTER MANUAL CAL, STARTED HANDS FREE CAL.		
05/21/2025 07:45	cro-operator	TJ	DISABLED CT6 STARTUP IN PREP FOR TOMORROWS RATA		
05/19/2025 11:05	cro-operator	SM	CT2 - SPANNED GAS INLET ANALYZER. STARTED HANDS FREE CAL FOR SCR.		
05/19/2025 09:59	cro-operator	SM	CT - 5 REPLACED PERISTALTIC PUMP DRIVE MOTOR B		
05/19/2025 08:16	cro-operator	SM	CT1 - PERFORMED MANUAL CALIBRATION ALL 3 ANALYZERS. STARTED HANDS FREE CAL. CHECKED REPORT AND AUTO CAL LOOKED GOOD.		
05/14/2025 13:29	cro-operator	BRB	CHANGED OUT LOW CO/O2 BOTTLE AND LOW NOX ON UNIT 6, CYLINDER # EB0150301, CO=18.13 & 22.46 O2 EXP 8/25/32 CYLINDER # CC205497, TOTAL NIT OX=9.875, EXP 2/27/26		
05/12/2025 23:40	cro-operator	AD	CHANGED UNIT 2 DAILY 18% O2 CYLINDER NUMBER 225104095 EXPIRATION DATE 11/10/2032 CHANGED UNIT 2 DAILY LOW NOX/CO 30PPM 20.52PPM CYLINDER NUMBER 225702027 EXPIRATION DATE 04/03/2028		
05/12/2025 14:30	cro-operator	SM	CT 1&2 - COMPLETED MONTHLY CEMS PM. SPANNED GAS AND RECORDED TST DATA		
05/10/2025 13:40	cro-operator	GAB	CT2 CHANGED HIGH NOX BOTTEL AND ENTERED NEW CYLINDER AND NOX VALUE OF 178.4PPM & CO 179.7PPM		
05/05/2025 14:53	cro-operator	SM	CT2- COMPLETED LINEARITY/CGA FOR 2ND QUARTER CT2		
05/05/2025 08:23	cro-operator	SM	SPANNED GAS PREPARING FOR LINEARITY		
05/02/2025 00:43	cro-operator	CMC	ADJUSTED START DATE/TIME OF GCV VALUES FOR MONTH OF APRIL TO 4/1/25 @ 00:00. ALSO ADDED GCV_Gas VALUE FOR MONTH OF APRIL THAT WAS MISSING		
05/01/2025 10:39	cro-operator	SM	CT-1 SPANNED GAS 730. 930 STARTED LINEARITY/CGA		
05/01/2025 02:42	cro-operator	CMC	UPDATED GCV VALUES ON CT1, CT2, CT5, CT6 AND GCV_Gas TO 105000		
04/30/2025 13:57	cro-operator	SM	CT1 - REPLACED NOX/CO LIN/CGA 110 AND 50 PPM BOTTLES. LOGGED IN EDITOR BOTTLE CHANGES		
04/28/2025 05:11	cro-operator	DE	REPLACED HRSG 1 DAILY HIGH SPAN NOX/CO BOTTLE. CYLINDER NUMBER CC734528. NEW TOTAL NITROGEN OXIDES VALUE 181.6. NEW CO VALUE 179.8.		

RegPerfect CEMS Logs

Log Time	Operator	Initials	Description	Tags	Files
04/28/2025 05:09	cro-operator	DE	REPLACED HRSG 1 DAILY INLET NOX LOW SPAN BOTTLE. CYLINDER NUMBER 225701155. NEW VALUE 21.17 TOTAL NITROGEN OXIDES.		
04/18/2025 15:56	cro-operator	DC	CT2, CHANGED LOW CO/NOX BOTTLE CONC: CO- 8.935 TOTAL NO- 9.689 BOTTLE ID: EB0004641 EXP: 11/22/27		
04/09/2025 13:55	cro-operator	RC	UPDATED CT 1/2, 5/6 GCV TO 105200		
04/09/2025 07:53	cro-operator	SM	CT2 - SPANNED GAS FOR INLET NOX ANALYZER AND STARTED HANDS FREE CAL. REPLACED INLET NOX BOTTLE. 21.15PPM CYL# 225104098		
04/07/2025 16:20	cro-operator	SM	CT-6 CEMS COMPLETED MONTHLY CEMS PM. SPANNED GAS. RECORDED TST DATA.		
04/07/2025 16:20	cro-operator	SM	CT-5 CEMS COMPLETED MONTHLY CEMS PM. SPANNED GAS. RECORDED TST DATA.		
04/03/2025 16:44	cro-operator	SL	CHANGED OUT DAILY 18% O2 BOTTLE CT1 NOX/CO ZERO O2 SPAN. OXYGEN 17.98% CYLINDER # ALM-016181 EXP DATE 09/16/32		
04/02/2025 15:25	cro-operator	SM	CT1 CEMS MONTHLY PM. RECORD TST DATA AND SPAN GAS		
04/02/2025 15:25	cro-operator	SM	CT2 HANDS FREE CAL		
04/02/2025 13:49	cro-operator	SM	CT-2 PERFORMED MONTHLY CEMS PM RECORDED TST DATA. SPANNED GAS. AFTER START UP, SPANNED O2.		
04/01/2025 16:05	cro-operator	DC	CT2- CHANGED O2 BOTTLE 225104089 WITH BOTTLE CC52527 CON: 18% EXP: 08/18/2032		

Cylinder Gas Audit

07/06/2025

Page 1

Facility: ROSEVILLE ENERGY

Unit/Stack: CT1

Parameter/Scale: CO / High

Test Date: 05/01/2025

Test Result: **Pass**

Instrument Name: CT1_CODualRg_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
05/01/2025	08:44	L	200	50.200	46.600	25.1 %
05/01/2025	08:49	M	200	109.000	107.900	54.5 %
05/01/2025	09:01	L	200	50.200	46.500	25.1 %
05/01/2025	09:06	M	200	109.000	107.900	54.5 %
05/01/2025	09:18	L	200	50.200	46.600	25.1 %
05/01/2025	09:23	M	200	109.000	107.900	54.5 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	50.200	46.567	Std	7.2
M	109.000	107.900	Std	1.0

Cylinder Gas Audit

07/06/2025

Page 2

Facility: ROSEVILLE ENERGY

Unit/Stack: CT1

Parameter/Scale: CO / Low

Test Date: 05/01/2025

Test Result: **Pass**

Instrument Name: CT1_CODualRg_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
05/01/2025	13:40	L	10	2.600	2.100	26.0 %
05/01/2025	13:45	M	10	5.700	5.500	57.0 %
05/01/2025	13:52	L	10	2.600	2.200	26.0 %
05/01/2025	13:57	M	10	5.700	5.500	57.0 %
05/01/2025	14:04	L	10	2.600	2.100	26.0 %
05/01/2025	14:09	M	10	5.700	5.500	57.0 %

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Specification Used	Results
L	2.600		2.133	Alt	0.5
M	5.700		5.500	Std	3.5

Linearity Report

07/06/2025

Page 1

ORIS Code: 56298 Facility Name: ROSEVILLE ENERGY
EDR Site ID: CT001 Component ID: A15 ReasonForTest: QA
Component Type: NOXA Grace Period: 0
Instrument Name: CT1_NOXDualRg_P_Instrum Test End Date/Time: 05/01/2025 Scale: High
Performance Spec: 5 % Test No.: 138 Highest Error: 0.6
Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
05/01/2025	0844	L	200.0	51.7	50.9		25.9 %
05/01/2025	0849	M	200.0	111.5	111.6		55.8 %
05/01/2025	0854	H	200.0	181.6	181.9		90.8 %
05/01/2025	0901	L	200.0	51.7	51.5		25.9 %
05/01/2025	0906	M	200.0	111.5	112.3		55.8 %
05/01/2025	0911	H	200.0	181.6	181.8		90.8 %
05/01/2025	0918	L	200.0	51.7	51.7		25.9 %
05/01/2025	0923	M	200.0	111.5	112.5		55.8 %
05/01/2025	0928	H	200.0	181.6	181.8		90.8 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	51.700	51.367	No	0.6
M	111.500	112.133	No	0.6
H	181.600	181.833	No	0.1

Linearity Report

07/06/2025

Page 2

ORIS Code: 56298 Facility Name: ROSEVILLE ENERGY
EDR Site ID: CT001 Component ID: A16 ReasonForTest: QA
Component Type: O2D Grace Period: 0
Instrument Name: CT1_O2D_P_Instrument Test End Date/Time: 05/01/2025 Scale: High
Performance Spec: 5 % Test No.: 139 Highest Error: 4.7
Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
05/01/2025	1135	L	18.0	5.0	4.8		27.8 %
05/01/2025	1140	M	18.0	11.0	10.9		61.1 %
05/01/2025	1145	H	18.0	18.0	18.0		100.0 %
05/01/2025	1152	L	18.0	5.0	4.8		27.8 %
05/01/2025	1157	M	18.0	11.0	10.9		61.1 %
05/01/2025	1202	H	18.0	18.0	18.0		100.0 %
05/01/2025	1209	L	18.0	5.0	4.7		27.8 %
05/01/2025	1214	M	18.0	11.0	10.9		61.1 %
05/01/2025	1219	H	18.0	18.0	18.0		100.0 %

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Alt Perf Spec	Results
L	5.000		4.767	No	4.7
M	11.000		10.900	No	0.9
H	18.000		18.000	No	0.0

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

Const. Value/Limit Tag:							> 4.73	> 1	> 1.8
		Unit CT1		Unit CT1		Unit CT1	Unit CT1	Unit CT1	Unit CT1
		GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
		1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/01/2025 00:00		3,550.0	0.0	3,550.0	105,200.0	373.5	0.45	0.2	0.7
04/01/2025 01:00		3,652.2	0.0	3,652.2	105,200.0	384.2	0.46	0.2	0.8
04/01/2025 02:00		3,535.3	0.0	3,535.3	105,200.0	371.9	0.45	0.2	0.7
04/01/2025 03:00		3,887.4	1.0	3,887.4	105,200.0	409.0	0.49	0.2	0.8
04/01/2025 04:00		4,072.7	115.0	4,103.8	105,200.0	431.7	0.53	0.3	0.9
04/01/2025 05:00		4,532.1	925.8	5,457.9	105,200.0	574.2	0.69	0.3	1.1
04/01/2025 06:00		4,528.8	1,462.7	5,991.5	105,200.0	630.3	0.76	0.4	1.3
04/01/2025 07:00		4,525.9	424.5	4,950.4	105,200.0	520.8	0.62	0.3	1.0
04/01/2025 08:00		4,518.1	420.6	4,938.7	105,200.0	519.6	0.62	0.3	1.0
04/01/2025 09:00		4,511.6	474.9	4,986.5	105,200.0	524.6	0.63	0.3	1.0
04/01/2025 10:00		4,498.2	550.3	5,048.5	105,200.0	531.1	0.64	0.3	1.1
04/01/2025 11:00		4,475.8	550.3	5,026.1	105,200.0	528.7	0.63	0.3	1.1
04/01/2025 12:00		4,148.2	247.3	4,276.8	105,200.0	449.9	0.56	0.3	0.9
04/01/2025 13:00		3,510.8	0.0	3,510.8	105,200.0	369.3	0.44	0.2	0.7
04/01/2025 14:00		3,534.1	0.0	3,534.1	105,200.0	371.8	0.45	0.2	0.7
04/01/2025 15:00		3,565.6	0.0	3,565.6	105,200.0	375.1	0.45	0.2	0.8
04/01/2025 16:00		3,568.0	0.0	3,568.0	105,200.0	375.4	0.45	0.2	0.8
04/01/2025 17:00		3,982.1	0.0	3,982.1	105,200.0	418.9	0.50	0.3	0.8
04/01/2025 18:00		3,625.0	0.0	3,625.0	105,200.0	381.4	0.46	0.2	0.8
04/01/2025 19:00		3,642.3	0.0	3,642.3	105,200.0	383.2	0.46	0.2	0.8
04/01/2025 20:00		3,585.1	0.0	3,585.1	105,200.0	377.2	0.45	0.2	0.8
04/01/2025 21:00		3,578.1	0.0	3,578.1	105,200.0	376.4	0.45	0.2	0.8
04/01/2025 22:00		3,580.0	0.0	3,580.0	105,200.0	376.6	0.45	0.2	0.8
04/01/2025 23:00		3,588.0	0.0	3,588.0	105,200.0	377.5	0.45	0.2	0.8
Average/Sum#:		3,924.8	215.5	4,131.8	105,200.0	434.7	0.52	0.2	0.9
Minimum:		3,510.8	0.0	3,510.8	105,200.0	369.3	0.44	0.2	0.7
Maximum:		4,532.1	1,462.7	5,991.5	105,200.0	630.3	0.76	0.4	1.3
%SI		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/02/2025 00:00	3,592.7	0.0	3,592.7	105,200.0	378.0	0.45	0.2	0.8
04/02/2025 01:00	3,599.2	0.0	3,599.2	105,200.0	378.6	0.45	0.2	0.8
04/02/2025 02:00	3,608.4	0.0	3,608.4	105,200.0	379.6	0.46	0.2	0.8
04/02/2025 03:00	3,617.6	0.0	3,617.6	105,200.0	380.6	0.46	0.2	0.8
04/02/2025 04:00	4,119.9	89.1	4,139.5	105,200.0	435.5	0.53	0.3	0.9
04/02/2025 05:00	4,615.0	1,267.2	5,882.2	105,200.0	618.8	0.74	0.4	1.2
04/02/2025 06:00	4,603.4	1,090.1	5,693.5	105,200.0	599.0	0.72	0.4	1.2
04/02/2025 07:00	4,253.6	218.3	4,367.1	105,200.0	459.4	0.56	0.3	0.9
04/02/2025 08:00	3,580.9	0.0	3,580.9	105,200.0	376.7	0.45	0.2	0.8
04/02/2025 09:00	3,881.2	0.0	3,881.2	105,200.0	408.3	0.49	0.2	0.8
04/02/2025 10:00	3,595.9	0.0	3,595.9	105,200.0	378.3	0.45	0.2	0.8
04/02/2025 11:00	3,495.6	0.0	3,495.6	105,200.0	367.7	0.44	0.2	0.7
04/02/2025 12:00	3,470.4	0.0	3,470.4	105,200.0	365.1	0.44	0.2	0.7
04/02/2025 13:00	3,650.0	2.2	3,650.1	105,200.0	384.0	0.46	0.2	0.8
04/02/2025 14:00	4,249.2	0.0	4,249.2	105,200.0	447.0	0.54	0.3	0.9
04/02/2025 15:00	4,337.2	0.0	4,337.2	105,200.0	456.3	0.55	0.3	0.9
04/02/2025 16:00	3,955.8	0.0	3,955.8	105,200.0	416.2	0.50	0.2	0.8
04/02/2025 17:00	3,713.5	0.0	3,713.5	105,200.0	390.7	0.47	0.2	0.8
04/02/2025 18:00	3,532.0	0.0	3,532.0	105,200.0	371.6	0.45	0.2	0.7
04/02/2025 19:00	3,532.9	0.0	3,532.9	105,200.0	371.7	0.45	0.2	0.7
04/02/2025 20:00	3,546.6	0.0	3,546.6	105,200.0	373.1	0.45	0.2	0.7
04/02/2025 21:00	3,558.7	0.0	3,558.7	105,200.0	374.4	0.45	0.2	0.7
04/02/2025 22:00	3,557.9	0.0	3,557.9	105,200.0	374.3	0.45	0.2	0.7
04/02/2025 23:00	3,559.6	0.0	3,559.6	105,200.0	374.5	0.45	0.2	0.7
Average/Sum#:	3,801.1	111.1	3,904.9	105,200.0	410.8	0.49	0.2	0.8
Minimum:	3,470.4	0.0	3,470.4	105,200.0	365.1	0.44	0.2	0.7
Maximum:	4,615.0	1,267.2	5,882.2	105,200.0	618.8	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/03/2025 00:00	3,565.4	0.0	3,565.4	105,200.0	375.1	0.45	0.2	0.8
04/03/2025 01:00	3,570.5	0.0	3,570.5	105,200.0	375.6	0.45	0.2	0.8
04/03/2025 02:00	3,571.0	0.0	3,571.0	105,200.0	375.7	0.45	0.2	0.8
04/03/2025 03:00	4,078.0	90.8	4,098.9	105,200.0	431.2	0.53	0.3	0.9
04/03/2025 04:00	4,567.1	825.3	5,392.4	105,200.0	567.3	0.68	0.3	1.1
04/03/2025 05:00	4,586.5	738.4	5,324.9	105,200.0	560.2	0.67	0.3	1.1
04/03/2025 06:00	4,588.7	423.1	5,011.8	105,200.0	527.2	0.63	0.3	1.1
04/03/2025 07:00	3,735.1	2.4	3,735.1	105,200.0	392.9	0.47	0.2	0.8
04/03/2025 08:00	3,561.5	0.0	3,561.5	105,200.0	374.7	0.45	0.2	0.7
04/03/2025 09:00	3,567.1	0.0	3,567.1	105,200.0	375.3	0.45	0.2	0.8
04/03/2025 10:00	3,567.1	0.0	3,567.1	105,200.0	375.3	0.45	0.2	0.8
04/03/2025 11:00	3,577.6	0.0	3,577.6	105,200.0	376.4	0.45	0.2	0.8
04/03/2025 12:00	3,563.8	0.0	3,563.8	105,200.0	374.9	0.45	0.2	0.8
04/03/2025 13:00	3,556.0	0.0	3,556.0	105,200.0	374.1	0.45	0.2	0.7
04/03/2025 14:00	3,637.3	0.0	3,637.3	105,200.0	382.6	0.46	0.2	0.8
04/03/2025 15:00	3,581.0	0.0	3,581.0	105,200.0	376.7	0.45	0.2	0.8
04/03/2025 16:00	3,575.4	0.0	3,575.4	105,200.0	376.1	0.45	0.2	0.8
04/03/2025 17:00	3,801.7	0.0	3,801.7	105,200.0	399.9	0.48	0.2	0.8
04/03/2025 18:00	3,568.4	0.0	3,568.4	105,200.0	375.4	0.45	0.2	0.8
04/03/2025 19:00	3,563.3	0.0	3,563.3	105,200.0	374.9	0.45	0.2	0.8
04/03/2025 20:00	3,571.9	0.0	3,571.9	105,200.0	375.8	0.45	0.2	0.8
04/03/2025 21:00	3,572.4	0.0	3,572.4	105,200.0	375.8	0.45	0.2	0.8
04/03/2025 22:00	4,004.9	0.0	4,004.9	105,200.0	421.3	0.51	0.3	0.8
04/03/2025 23:00	4,249.9	0.0	4,249.9	105,200.0	447.1	0.54	0.3	0.9
Average/Sum#:	3,782.6	86.7	3,866.2	105,200.0	406.7	0.49	0.2	0.8
Minimum:	3,556.0	0.0	3,556.0	105,200.0	374.1	0.45	0.2	0.7
Maximum:	4,588.7	825.3	5,392.4	105,200.0	567.3	0.68	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/04/2025 00:00	3,611.8	0.0	3,611.8	105,200.0	380.0	0.46	0.2	0.8
04/04/2025 01:00	3,612.3	0.0	3,612.3	105,200.0	380.0	0.46	0.2	0.8
04/04/2025 02:00	4,236.1	0.0	4,236.1	105,200.0	445.6	0.53	0.3	0.9
04/04/2025 03:00	4,163.1	0.0	4,163.1	105,200.0	438.0	0.52	0.3	0.9
04/04/2025 04:00	3,794.1	0.0	3,794.1	105,200.0	399.1	0.48	0.2	0.8
04/04/2025 05:00	4,059.9	0.0	4,059.9	105,200.0	427.1	0.51	0.3	0.9
04/04/2025 06:00	3,799.7	0.0	3,799.7	105,200.0	399.7	0.48	0.2	0.8
04/04/2025 07:00	3,583.4	0.0	3,583.4	105,200.0	377.0	0.45	0.2	0.8
04/04/2025 08:00	3,585.7	0.0	3,585.7	105,200.0	377.2	0.45	0.2	0.8
04/04/2025 09:00	3,584.7	0.0	3,584.7	105,200.0	377.1	0.45	0.2	0.8
04/04/2025 10:00	3,577.5	0.0	3,577.5	105,200.0	376.4	0.45	0.2	0.8
04/04/2025 11:00	3,576.2	0.0	3,576.2	105,200.0	376.2	0.45	0.2	0.8
04/04/2025 12:00	3,553.6	0.0	3,553.6	105,200.0	373.8	0.45	0.2	0.7
04/04/2025 13:00	3,544.2	0.0	3,544.2	105,200.0	372.8	0.45	0.2	0.7
04/04/2025 14:00	3,543.0	0.0	3,543.0	105,200.0	372.7	0.45	0.2	0.7
04/04/2025 15:00	3,540.3	0.0	3,540.3	105,200.0	372.4	0.45	0.2	0.7
04/04/2025 16:00	3,540.0	0.0	3,540.0	105,200.0	372.4	0.45	0.2	0.7
04/04/2025 17:00	3,809.0	0.0	3,809.0	105,200.0	400.7	0.48	0.2	0.8
04/04/2025 18:00	3,574.6	0.0	3,574.6	105,200.0	376.0	0.45	0.2	0.8
04/04/2025 19:00	3,598.0	0.0	3,598.0	105,200.0	378.5	0.46	0.2	0.8
04/04/2025 20:00	3,553.2	0.0	3,553.2	105,200.0	373.8	0.45	0.2	0.7
04/04/2025 21:00	3,683.0	0.0	3,683.0	105,200.0	387.5	0.47	0.2	0.8
04/04/2025 22:00	3,556.7	0.0	3,556.7	105,200.0	374.2	0.45	0.2	0.7
04/04/2025 23:00	3,753.6	0.0	3,753.6	105,200.0	394.9	0.47	0.2	0.8
Average/Sum#:	3,684.7	0.0	3,684.7	105,200.0	387.6	0.47	0.2	0.8
Minimum:	3,540.0	0.0	3,540.0	105,200.0	372.4	0.45	0.2	0.7
Maximum:	4,236.1	0.0	4,236.1	105,200.0	445.6	0.53	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/05/2025 00:00	3,547.9	0.0	3,547.9	105,200.0	373.2	0.45	0.2	0.7
04/05/2025 01:00	3,579.0	0.0	3,579.0	105,200.0	376.5	0.45	0.2	0.8
04/05/2025 02:00	3,579.7	0.0	3,579.7	105,200.0	376.6	0.45	0.2	0.8
04/05/2025 03:00	3,659.9	0.0	3,659.9	105,200.0	385.0	0.46	0.2	0.8
04/05/2025 04:00	3,870.7	0.0	3,870.7	105,200.0	407.2	0.49	0.2	0.8
04/05/2025 05:00	4,146.9	0.0	4,146.9	105,200.0	436.3	0.52	0.3	0.9
04/05/2025 06:00	3,907.4	0.0	3,907.4	105,200.0	411.1	0.49	0.2	0.8
04/05/2025 07:00	3,581.5	0.0	3,581.5	105,200.0	376.8	0.45	0.2	0.8
04/05/2025 08:00	3,575.7	0.0	3,575.7	105,200.0	376.2	0.45	0.2	0.8
04/05/2025 09:00	3,572.9	0.0	3,572.9	105,200.0	375.9	0.45	0.2	0.8
04/05/2025 10:00	3,564.4	0.0	3,564.4	105,200.0	375.0	0.45	0.2	0.8
04/05/2025 11:00	3,550.5	0.0	3,550.5	105,200.0	373.5	0.45	0.2	0.7
04/05/2025 12:00	3,529.1	0.0	3,529.1	105,200.0	371.3	0.45	0.2	0.7
04/05/2025 13:00	3,542.0	0.0	3,542.0	105,200.0	372.6	0.45	0.2	0.7
04/05/2025 14:00	3,539.2	0.0	3,539.2	105,200.0	372.3	0.45	0.2	0.7
04/05/2025 15:00	3,534.9	0.0	3,534.9	105,200.0	371.9	0.45	0.2	0.7
04/05/2025 16:00	3,538.2	0.0	3,538.2	105,200.0	372.2	0.45	0.2	0.7
04/05/2025 17:00	3,897.9	0.0	3,897.9	105,200.0	410.1	0.49	0.2	0.8
04/05/2025 18:00	3,930.2	0.0	3,930.2	105,200.0	413.5	0.50	0.2	0.8
04/05/2025 19:00	3,540.0	0.0	3,540.0	105,200.0	372.4	0.45	0.2	0.7
04/05/2025 20:00	3,536.9	0.0	3,536.9	105,200.0	372.1	0.45	0.2	0.7
04/05/2025 21:00	3,534.7	0.0	3,534.7	105,200.0	371.9	0.45	0.2	0.7
04/05/2025 22:00	3,545.4	0.0	3,545.4	105,200.0	373.0	0.45	0.2	0.7
04/05/2025 23:00	3,712.1	0.0	3,712.1	105,200.0	390.5	0.47	0.2	0.8
Average/Sum#:	3,646.5	0.0	3,646.5	105,200.0	383.6	0.46	0.2	0.8
Minimum:	3,529.1	0.0	3,529.1	105,200.0	371.3	0.45	0.2	0.7
Maximum:	4,146.9	0.0	4,146.9	105,200.0	436.3	0.52	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/06/2025 00:00	3,560.1	0.0	3,560.1	105,200.0	374.5	0.45	0.2	0.7
04/06/2025 01:00	3,579.0	0.0	3,579.0	105,200.0	376.5	0.45	0.2	0.8
04/06/2025 02:00	3,584.8	0.0	3,584.8	105,200.0	377.1	0.45	0.2	0.8
04/06/2025 03:00	3,585.2	0.0	3,585.2	105,200.0	377.2	0.45	0.2	0.8
04/06/2025 04:00	3,588.2	0.0	3,588.2	105,200.0	377.5	0.45	0.2	0.8
04/06/2025 05:00	3,834.6	0.0	3,834.6	105,200.0	403.4	0.48	0.2	0.8
04/06/2025 06:00	3,655.7	0.0	3,655.7	105,200.0	384.6	0.46	0.2	0.8
04/06/2025 07:00	3,574.6	0.0	3,574.6	105,200.0	376.0	0.45	0.2	0.8
04/06/2025 08:00	3,553.0	0.0	3,553.0	105,200.0	373.8	0.45	0.2	0.7
04/06/2025 09:00	3,532.7	0.0	3,532.7	105,200.0	371.6	0.45	0.2	0.7
04/06/2025 10:00	3,527.9	0.0	3,527.9	105,200.0	371.1	0.45	0.2	0.7
04/06/2025 11:00	3,532.2	0.0	3,532.2	105,200.0	371.6	0.45	0.2	0.7
04/06/2025 12:00	3,532.0	0.0	3,532.0	105,200.0	371.6	0.45	0.2	0.7
04/06/2025 13:00	3,513.4	0.0	3,513.4	105,200.0	369.6	0.44	0.2	0.7
04/06/2025 14:00	3,491.0	0.0	3,491.0	105,200.0	367.3	0.44	0.2	0.7
04/06/2025 15:00	3,492.4	0.0	3,492.4	105,200.0	367.4	0.44	0.2	0.7
04/06/2025 16:00	3,488.5	0.0	3,488.5	105,200.0	367.0	0.44	0.2	0.7
04/06/2025 17:00	3,858.8	0.0	3,858.8	105,200.0	405.9	0.49	0.2	0.8
04/06/2025 18:00	3,517.7	0.0	3,517.7	105,200.0	370.1	0.44	0.2	0.7
04/06/2025 19:00	3,511.4	0.0	3,511.4	105,200.0	369.4	0.44	0.2	0.7
04/06/2025 20:00	3,513.1	0.0	3,513.1	105,200.0	369.6	0.44	0.2	0.7
04/06/2025 21:00	3,541.5	0.0	3,541.5	105,200.0	372.6	0.45	0.2	0.7
04/06/2025 22:00	3,515.8	0.0	3,515.8	105,200.0	369.9	0.44	0.2	0.7
04/06/2025 23:00	3,513.6	0.0	3,513.6	105,200.0	369.6	0.44	0.2	0.7
Average/Sum#:	3,566.6	0.0	3,566.6	105,200.0	375.2	0.45	0.2	0.7
Minimum:	3,488.5	0.0	3,488.5	105,200.0	367.0	0.44	0.2	0.7
Maximum:	3,858.8	0.0	3,858.8	105,200.0	405.9	0.49	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/07/2025 00:00	3,507.3	0.0	3,507.3	105,200.0	369.0	0.44	0.2	0.7			
04/07/2025 01:00	3,510.0	0.0	3,510.0	105,200.0	369.3	0.44	0.2	0.7			
04/07/2025 02:00	3,525.9	0.0	3,525.9	105,200.0	370.9	0.45	0.2	0.7			
04/07/2025 03:00	3,509.9	0.0	3,509.9	105,200.0	369.2	0.44	0.2	0.7			
04/07/2025 04:00	3,628.8	0.0	3,628.8	105,200.0	381.7	0.46	0.2	0.8			
04/07/2025 05:00	4,076.6	0.0	4,076.6	105,200.0	428.9	0.51	0.3	0.9			
04/07/2025 06:00	3,865.7	0.0	3,865.7	105,200.0	406.7	0.49	0.2	0.8			
04/07/2025 07:00	3,519.1	0.0	3,519.1	105,200.0	370.2	0.44	0.2	0.7			
04/07/2025 08:00	3,536.9	0.0	3,536.9	105,200.0	372.1	0.45	0.2	0.7			
04/07/2025 09:00	3,527.7	0.0	3,527.7	105,200.0	371.1	0.45	0.2	0.7			
04/07/2025 10:00	2,593.4	0.0	2,593.4	105,200.0	272.8	0.44	0.2	0.7			
04/07/2025 11:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0			
04/07/2025 12:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0			
04/07/2025 13:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0			
04/07/2025 14:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0			
04/07/2025 15:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0			
04/07/2025 16:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0			
04/07/2025 17:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0			
04/07/2025 18:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0			
04/07/2025 19:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0			
04/07/2025 20:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0			
04/07/2025 21:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0			
04/07/2025 22:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0			
04/07/2025 23:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0			
Average/Sum#:	3,527.4	0.0	3,527.4	105,200.0	371.1	0.46	0.2	0.7			
Minimum:	2,593.4	0.0	2,593.4	105,200.0	272.8	0.44	0.2	0.7			
Maximum:	4,076.6	0.0	4,076.6	105,200.0	428.9	0.51	0.3	0.9			
%SI	54.17	54.17	54.17	0.00	54.17	54.17	54.17	54.17			

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

Const. Value/Limit Tag:		> 4.73 > 1 > 1.8							
		Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	
		GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
		1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/08/2025 00:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	
04/08/2025 01:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	
04/08/2025 02:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	
04/08/2025 03:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	
04/08/2025 04:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	
04/08/2025 05:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	
04/08/2025 06:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	
04/08/2025 07:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	
04/08/2025 08:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	
04/08/2025 09:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	
04/08/2025 10:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	
04/08/2025 11:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	
04/08/2025 12:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	
04/08/2025 13:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	
04/08/2025 14:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	
04/08/2025 15:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	
04/08/2025 16:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	
04/08/2025 17:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	
04/08/2025 18:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	
04/08/2025 19:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	
04/08/2025 20:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	
04/08/2025 21:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	
04/08/2025 22:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	
04/08/2025 23:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00	

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/09/2025 00:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/09/2025 01:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/09/2025 02:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/09/2025 03:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/09/2025 04:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/09/2025 05:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/09/2025 06:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/09/2025 07:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/09/2025 08:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/09/2025 09:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/09/2025 10:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/09/2025 11:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/09/2025 12:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/09/2025 13:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/09/2025 14:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/09/2025 15:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/09/2025 16:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/09/2025 17:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/09/2025 18:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/09/2025 19:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/09/2025 20:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/09/2025 21:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/09/2025 22:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/09/2025 23:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/10/2025 00:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/10/2025 01:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/10/2025 02:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/10/2025 03:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/10/2025 04:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/10/2025 05:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/10/2025 06:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/10/2025 07:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/10/2025 08:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/10/2025 09:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/10/2025 10:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/10/2025 11:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/10/2025 12:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/10/2025 13:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/10/2025 14:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/10/2025 15:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/10/2025 16:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/10/2025 17:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/10/2025 18:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/10/2025 19:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/10/2025 20:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/10/2025 21:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/10/2025 22:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/10/2025 23:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/11/2025 00:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/11/2025 01:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/11/2025 02:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/11/2025 03:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/11/2025 04:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/11/2025 05:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/11/2025 06:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/11/2025 07:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/11/2025 08:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/11/2025 09:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/11/2025 10:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/11/2025 11:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/11/2025 12:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/11/2025 13:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/11/2025 14:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/11/2025 15:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/11/2025 16:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/11/2025 17:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/11/2025 18:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/11/2025 19:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/11/2025 20:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/11/2025 21:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/11/2025 22:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/11/2025 23:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/12/2025 00:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/12/2025 01:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/12/2025 02:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/12/2025 03:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/12/2025 04:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/12/2025 05:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/12/2025 06:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/12/2025 07:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/12/2025 08:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/12/2025 09:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/12/2025 10:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/12/2025 11:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/12/2025 12:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/12/2025 13:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/12/2025 14:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/12/2025 15:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/12/2025 16:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/12/2025 17:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/12/2025 18:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/12/2025 19:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/12/2025 20:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/12/2025 21:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/12/2025 22:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/12/2025 23:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/13/2025 00:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/13/2025 01:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/13/2025 02:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/13/2025 03:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/13/2025 04:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/13/2025 05:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/13/2025 06:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/13/2025 07:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/13/2025 08:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/13/2025 09:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/13/2025 10:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/13/2025 11:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/13/2025 12:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/13/2025 13:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/13/2025 14:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/13/2025 15:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/13/2025 16:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/13/2025 17:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/13/2025 18:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/13/2025 19:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/13/2025 20:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/13/2025 21:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/13/2025 22:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/13/2025 23:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/14/2025 00:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/14/2025 01:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/14/2025 02:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/14/2025 03:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/14/2025 04:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/14/2025 05:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/14/2025 06:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/14/2025 07:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/14/2025 08:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/14/2025 09:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/14/2025 10:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/14/2025 11:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/14/2025 12:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/14/2025 13:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/14/2025 14:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/14/2025 15:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/14/2025 16:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/14/2025 17:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/14/2025 18:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/14/2025 19:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/14/2025 20:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/14/2025 21:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/14/2025 22:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
04/14/2025 23:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/15/2025 00:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/15/2025 01:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/15/2025 02:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/15/2025 03:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/15/2025 04:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/15/2025 05:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/15/2025 06:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/15/2025 07:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/15/2025 08:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/15/2025 09:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/15/2025 10:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/15/2025 11:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/15/2025 12:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/15/2025 13:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/15/2025 14:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/15/2025 15:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/15/2025 16:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/15/2025 17:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/15/2025 18:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/15/2025 19:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/15/2025 20:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/15/2025 21:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/15/2025 22:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/15/2025 23:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/16/2025 00:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/16/2025 01:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/16/2025 02:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/16/2025 03:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/16/2025 04:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/16/2025 05:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/16/2025 06:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/16/2025 07:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/16/2025 08:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/16/2025 09:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/16/2025 10:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/16/2025 11:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/16/2025 12:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/16/2025 13:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/16/2025 14:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/16/2025 15:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/16/2025 16:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/16/2025 17:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/16/2025 18:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/16/2025 19:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/16/2025 20:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/16/2025 21:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/16/2025 22:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/16/2025 23:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1		Unit CT1		Unit CT1		Unit CT1		Unit CT1		Unit CT1		Unit CT1		Unit CT1		Unit CT1	
	GasFlow, _CT, 100scfh		GasFlow, _DB, 100scfh		GasFlowTotal, 100scfh		GCVGas, BtuPer100scf		HI, MBtuPerHr		> 4.73 PM10_Norm, LbPerHr		> 1 SO2_Norm, LbPerHr		> 1.8 VOC_Norm, LbPerHr			
	1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)	
04/17/2025 00:00	0.0		0.0		0.0		105,200.0		0.0		0.00		0.0		0.0		0.0	
04/17/2025 01:00	0.0		0.0		0.0		105,200.0		0.0		0.00		0.0		0.0		0.0	
04/17/2025 02:00	0.0		0.0		0.0		105,200.0		0.0		0.00		0.0		0.0		0.0	
04/17/2025 03:00	0.0		0.0		0.0		105,200.0		0.0		0.00		0.0		0.0		0.0	
04/17/2025 04:00	0.0		0.0		0.0		105,200.0		0.0		0.00		0.0		0.0		0.0	
04/17/2025 05:00	0.0		0.0		0.0		105,200.0		0.0		0.00		0.0		0.0		0.0	
04/17/2025 06:00	0.0		0.0		0.0		105,200.0		0.0		0.00		0.0		0.0		0.0	
04/17/2025 07:00	0.0		0.0		0.0		105,200.0		0.0		0.00		0.0		0.0		0.0	
04/17/2025 08:00	0.0		0.0		0.0		105,200.0		0.0		0.00		0.0		0.0		0.0	
04/17/2025 09:00	0.0		0.0		0.0		105,200.0		0.0		0.00		0.0		0.0		0.0	
04/17/2025 10:00	0.0		0.0		0.0		105,200.0		0.0		0.00		0.0		0.0		0.0	
04/17/2025 11:00	0.0		0.0		0.0		105,200.0		0.0		0.00		0.0		0.0		0.0	
04/17/2025 12:00	0.0		0.0		0.0		105,200.0		0.0		0.00		0.0		0.0		0.0	
04/17/2025 13:00	0.0		0.0		0.0		105,200.0		0.0		0.00		0.0		0.0		0.0	
04/17/2025 14:00	0.0		0.0		0.0		105,200.0		0.0		0.00		0.0		0.0		0.0	
04/17/2025 15:00	0.0		0.0		0.0		105,200.0		0.0		0.00		0.0		0.0		0.0	
04/17/2025 16:00	0.0		0.0		0.0		105,200.0		0.0		0.00		0.0		0.0		0.0	
04/17/2025 17:00	0.0		0.0		0.0		105,200.0		0.0		0.00		0.0		0.0		0.0	
04/17/2025 18:00	0.0		0.0		0.0		105,200.0		0.0		0.00		0.0		0.0		0.0	
04/17/2025 19:00	0.0		0.0		0.0		105,200.0		0.0		0.00		0.0		0.0		0.0	
04/17/2025 20:00	0.0		0.0		0.0		105,200.0		0.0		0.00		0.0		0.0		0.0	
04/17/2025 21:00	0.0		0.0		0.0		105,200.0		0.0		0.00		0.0		0.0		0.0	
04/17/2025 22:00	0.0		0.0		0.0		105,200.0		0.0		0.00		0.0		0.0		0.0	
04/17/2025 23:00	0.0		0.0		0.0		105,200.0		0.0		0.00		0.0		0.0		0.0	
Average/Sum#:	0.0		0.0		0.0		105,200.0		0.0		0.00		0.0		0.0		0.0	
Minimum:	0.0		0.0		0.0		105,200.0		0.0		0.00		0.0		0.0		0.0	
Maximum:	0.0		0.0		0.0		105,200.0		0.0		0.00		0.0		0.0		0.0	
%SI	100.00		100.00		100.00		0.00		100.00		100.00		100.00		100.00		100.00	

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/18/2025 00:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/18/2025 01:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/18/2025 02:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/18/2025 03:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/18/2025 04:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/18/2025 05:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/18/2025 06:00	0.0	0.0	0.0	105,200.0	0.0	0.00	0.0	0.0
04/18/2025 07:00	2,985.8	0.0	2,985.8	105,200.0	314.1	0.00	0.0	0.0
04/18/2025 08:00	3,509.2	0.0	3,509.2	105,200.0	369.2	0.44	0.2	0.7
04/18/2025 09:00	3,576.0	0.0	3,576.0	105,200.0	376.2	0.45	0.2	0.8
04/18/2025 10:00	4,385.1	459.7	4,729.9	105,200.0	497.6	0.61	0.3	1.0
04/18/2025 11:00	3,503.8	0.0	3,503.8	105,200.0	368.6	0.44	0.2	0.7
04/18/2025 12:00	3,499.0	0.0	3,499.0	105,200.0	368.1	0.44	0.2	0.7
04/18/2025 13:00	3,497.3	0.0	3,497.3	105,200.0	367.9	0.44	0.2	0.7
04/18/2025 14:00	3,484.4	0.0	3,484.4	105,200.0	366.6	0.44	0.2	0.7
04/18/2025 15:00	3,470.7	0.0	3,470.7	105,200.0	365.1	0.44	0.2	0.7
04/18/2025 16:00	3,458.8	0.0	3,458.8	105,200.0	363.9	0.44	0.2	0.7
04/18/2025 17:00	3,619.3	0.0	3,619.3	105,200.0	380.8	0.46	0.2	0.8
04/18/2025 18:00	3,473.8	0.0	3,473.8	105,200.0	365.4	0.44	0.2	0.7
04/18/2025 19:00	3,577.2	0.0	3,577.2	105,200.0	376.3	0.45	0.2	0.8
04/18/2025 20:00	4,323.0	0.0	4,323.0	105,200.0	454.8	0.55	0.3	0.9
04/18/2025 21:00	4,331.1	0.0	4,331.1	105,200.0	455.6	0.55	0.3	0.9
04/18/2025 22:00	3,816.8	0.0	3,816.8	105,200.0	401.5	0.48	0.2	0.8
04/18/2025 23:00	4,411.6	775.2	5,163.5	105,200.0	543.2	0.65	0.3	1.1
Average/Sum#:	3,701.3	72.6	3,765.9	105,200.0	396.2	0.48	0.2	0.8
Minimum:	2,985.8	0.0	2,985.8	105,200.0	314.1	0.44	0.2	0.7
Maximum:	4,411.6	775.2	5,163.5	105,200.0	543.2	0.65	0.3	1.1
%SI	29.17	29.17	29.17	0.00	29.17	33.33	33.33	33.33

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/19/2025 00:00	4,446.0	539.8	4,985.8	105,200.0	524.5	0.63	0.3	1.0
04/19/2025 01:00	4,451.0	532.8	4,983.8	105,200.0	524.3	0.63	0.3	1.0
04/19/2025 02:00	4,471.0	507.5	4,978.5	105,200.0	523.7	0.63	0.3	1.0
04/19/2025 03:00	4,489.6	474.8	4,964.4	105,200.0	522.3	0.63	0.3	1.0
04/19/2025 04:00	4,524.6	427.4	4,952.0	105,200.0	521.0	0.63	0.3	1.0
04/19/2025 05:00	4,510.2	438.6	4,948.8	105,200.0	520.6	0.62	0.3	1.0
04/19/2025 06:00	4,222.6	221.7	4,337.9	105,200.0	456.3	0.56	0.3	0.9
04/19/2025 07:00	3,484.3	0.0	3,484.3	105,200.0	366.5	0.44	0.2	0.7
04/19/2025 08:00	3,481.9	0.0	3,481.9	105,200.0	366.3	0.44	0.2	0.7
04/19/2025 09:00	3,481.0	0.0	3,481.0	105,200.0	366.2	0.44	0.2	0.7
04/19/2025 10:00	3,479.6	0.0	3,479.6	105,200.0	366.1	0.44	0.2	0.7
04/19/2025 11:00	3,488.0	0.0	3,488.0	105,200.0	366.9	0.44	0.2	0.7
04/19/2025 12:00	3,490.2	0.0	3,490.2	105,200.0	367.2	0.44	0.2	0.7
04/19/2025 13:00	3,495.0	0.0	3,495.0	105,200.0	367.7	0.44	0.2	0.7
04/19/2025 14:00	3,493.8	0.0	3,493.8	105,200.0	367.5	0.44	0.2	0.7
04/19/2025 15:00	3,487.6	0.0	3,487.6	105,200.0	366.9	0.44	0.2	0.7
04/19/2025 16:00	3,481.2	0.0	3,481.2	105,200.0	366.2	0.44	0.2	0.7
04/19/2025 17:00	3,602.0	0.0	3,602.0	105,200.0	378.9	0.46	0.2	0.8
04/19/2025 18:00	3,974.8	110.6	3,999.1	105,200.0	420.7	0.52	0.3	0.9
04/19/2025 19:00	4,386.0	546.1	4,932.1	105,200.0	518.9	0.62	0.3	1.0
04/19/2025 20:00	4,413.8	487.8	4,901.6	105,200.0	515.6	0.62	0.3	1.0
04/19/2025 21:00	4,438.2	464.7	4,902.9	105,200.0	515.8	0.62	0.3	1.0
04/19/2025 22:00	4,457.4	450.5	4,907.9	105,200.0	516.3	0.62	0.3	1.0
04/19/2025 23:00	3,712.4	2.4	3,712.4	105,200.0	390.5	0.47	0.2	0.8
Average/Sum#:	3,956.8	216.9	4,165.5	105,200.0	438.2	0.53	0.3	0.9
Minimum:	3,479.6	0.0	3,479.6	105,200.0	366.1	0.44	0.2	0.7
Maximum:	4,524.6	546.1	4,985.8	105,200.0	524.5	0.63	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/20/2025 00:00	3,493.2	0.0	3,493.2	105,200.0	367.5	0.44	0.2	0.7
04/20/2025 01:00	3,494.1	0.0	3,494.1	105,200.0	367.6	0.44	0.2	0.7
04/20/2025 02:00	3,510.6	0.0	3,510.6	105,200.0	369.3	0.44	0.2	0.7
04/20/2025 03:00	3,525.7	0.0	3,525.7	105,200.0	370.9	0.45	0.2	0.7
04/20/2025 04:00	3,526.3	0.0	3,526.3	105,200.0	371.0	0.45	0.2	0.7
04/20/2025 05:00	3,531.0	0.0	3,531.0	105,200.0	371.5	0.45	0.2	0.7
04/20/2025 06:00	3,528.8	0.0	3,528.8	105,200.0	371.2	0.45	0.2	0.7
04/20/2025 07:00	3,530.7	0.0	3,530.7	105,200.0	371.4	0.45	0.2	0.7
04/20/2025 08:00	3,523.3	0.0	3,523.3	105,200.0	370.7	0.44	0.2	0.7
04/20/2025 09:00	3,524.3	0.0	3,524.3	105,200.0	370.8	0.44	0.2	0.7
04/20/2025 10:00	3,499.3	0.0	3,499.3	105,200.0	368.1	0.44	0.2	0.7
04/20/2025 11:00	3,497.4	0.0	3,497.4	105,200.0	367.9	0.44	0.2	0.7
04/20/2025 12:00	3,502.2	0.0	3,502.2	105,200.0	368.4	0.44	0.2	0.7
04/20/2025 13:00	3,501.8	0.0	3,501.8	105,200.0	368.4	0.44	0.2	0.7
04/20/2025 14:00	3,498.7	0.0	3,498.7	105,200.0	368.1	0.44	0.2	0.7
04/20/2025 15:00	3,489.9	0.0	3,489.9	105,200.0	367.1	0.44	0.2	0.7
04/20/2025 16:00	3,478.9	0.0	3,478.9	105,200.0	366.0	0.44	0.2	0.7
04/20/2025 17:00	3,894.5	153.6	3,929.8	105,200.0	413.4	0.51	0.3	0.9
04/20/2025 18:00	4,241.1	811.1	5,052.2	105,200.0	531.5	0.64	0.3	1.1
04/20/2025 19:00	4,264.9	761.8	5,026.7	105,200.0	528.8	0.64	0.3	1.1
04/20/2025 20:00	4,296.0	723.8	5,019.8	105,200.0	528.1	0.63	0.3	1.1
04/20/2025 21:00	4,338.0	656.4	4,994.4	105,200.0	525.4	0.63	0.3	1.1
04/20/2025 22:00	4,376.3	588.6	4,964.9	105,200.0	522.3	0.63	0.3	1.0
04/20/2025 23:00	4,406.3	531.8	4,938.1	105,200.0	519.5	0.62	0.3	1.0
Average/Sum#:	3,728.1	176.1	3,899.3	105,200.0	410.2	0.49	0.2	0.8
Minimum:	3,478.9	0.0	3,478.9	105,200.0	366.0	0.44	0.2	0.7
Maximum:	4,406.3	811.1	5,052.2	105,200.0	531.5	0.64	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/21/2025 00:00	4,425.7	508.0	4,933.7	105,200.0	519.0	0.62	0.3	1.0
04/21/2025 01:00	4,430.2	550.7	4,980.9	105,200.0	524.0	0.63	0.3	1.0
04/21/2025 02:00	4,447.2	545.4	4,992.6	105,200.0	525.2	0.63	0.3	1.1
04/21/2025 03:00	4,457.6	530.3	4,987.9	105,200.0	524.7	0.63	0.3	1.0
04/21/2025 04:00	4,470.4	513.2	4,983.6	105,200.0	524.3	0.63	0.3	1.0
04/21/2025 05:00	4,490.2	469.8	4,960.0	105,200.0	521.8	0.63	0.3	1.0
04/21/2025 06:00	4,174.1	232.4	4,294.9	105,200.0	451.8	0.56	0.3	0.9
04/21/2025 07:00	3,493.6	0.0	3,493.6	105,200.0	367.5	0.44	0.2	0.7
04/21/2025 08:00	3,493.3	0.0	3,493.3	105,200.0	367.5	0.44	0.2	0.7
04/21/2025 09:00	3,489.9	0.0	3,489.9	105,200.0	367.1	0.44	0.2	0.7
04/21/2025 10:00	3,477.7	0.0	3,477.7	105,200.0	365.9	0.44	0.2	0.7
04/21/2025 11:00	3,487.5	0.0	3,487.5	105,200.0	366.9	0.44	0.2	0.7
04/21/2025 12:00	3,500.5	0.0	3,500.5	105,200.0	368.3	0.44	0.2	0.7
04/21/2025 13:00	3,492.5	0.0	3,492.5	105,200.0	367.4	0.44	0.2	0.7
04/21/2025 14:00	3,499.1	0.0	3,499.1	105,200.0	368.1	0.44	0.2	0.7
04/21/2025 15:00	3,490.6	0.0	3,490.6	105,200.0	367.2	0.44	0.2	0.7
04/21/2025 16:00	3,478.9	0.0	3,478.9	105,200.0	366.0	0.44	0.2	0.7
04/21/2025 17:00	4,017.2	558.0	4,285.0	105,200.0	450.8	0.58	0.3	1.0
04/21/2025 18:00	4,163.8	1,355.4	5,519.2	105,200.0	580.6	0.70	0.3	1.2
04/21/2025 19:00	4,219.4	1,074.6	5,294.0	105,200.0	556.9	0.67	0.3	1.1
04/21/2025 20:00	4,247.5	1,293.4	5,540.9	105,200.0	582.9	0.70	0.3	1.2
04/21/2025 21:00	4,362.7	1,477.5	5,840.2	105,200.0	614.4	0.74	0.4	1.2
04/21/2025 22:00	4,397.9	1,383.2	5,781.1	105,200.0	608.2	0.73	0.4	1.2
04/21/2025 23:00	4,412.4	1,080.5	5,492.9	105,200.0	577.9	0.69	0.3	1.2
Average/Sum#:	3,984.2	482.2	4,449.6	105,200.0	468.1	0.56	0.3	0.9
Minimum:	3,477.7	0.0	3,477.7	105,200.0	365.9	0.44	0.2	0.7
Maximum:	4,490.2	1,477.5	5,840.2	105,200.0	614.4	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/22/2025 00:00	4,413.6	936.7	5,350.3	105,200.0	562.9	0.68	0.3	1.1
04/22/2025 01:00	4,433.7	603.7	5,037.4	105,200.0	529.9	0.64	0.3	1.1
04/22/2025 02:00	4,433.3	517.0	4,950.3	105,200.0	520.8	0.62	0.3	1.0
04/22/2025 03:00	4,435.0	1,017.4	5,452.4	105,200.0	573.6	0.69	0.3	1.1
04/22/2025 04:00	4,452.4	917.1	5,369.5	105,200.0	564.9	0.68	0.3	1.1
04/22/2025 05:00	4,460.0	942.6	5,402.6	105,200.0	568.4	0.68	0.3	1.1
04/22/2025 06:00	4,458.9	421.0	4,879.9	105,200.0	513.4	0.62	0.3	1.0
04/22/2025 07:00	4,131.0	233.9	4,252.6	105,200.0	447.4	0.55	0.3	0.9
04/22/2025 08:00	3,461.7	0.0	3,461.7	105,200.0	364.2	0.44	0.2	0.7
04/22/2025 09:00	3,460.8	0.0	3,460.8	105,200.0	364.1	0.44	0.2	0.7
04/22/2025 10:00	3,484.8	0.0	3,484.8	105,200.0	366.6	0.44	0.2	0.7
04/22/2025 11:00	3,503.6	0.0	3,503.6	105,200.0	368.6	0.44	0.2	0.7
04/22/2025 12:00	3,488.5	0.0	3,488.5	105,200.0	367.0	0.44	0.2	0.7
04/22/2025 13:00	3,479.3	0.0	3,479.3	105,200.0	366.0	0.44	0.2	0.7
04/22/2025 14:00	3,477.4	0.0	3,477.4	105,200.0	365.8	0.44	0.2	0.7
04/22/2025 15:00	3,468.8	0.0	3,468.8	105,200.0	364.9	0.44	0.2	0.7
04/22/2025 16:00	3,937.2	133.5	3,973.2	105,200.0	418.0	0.51	0.3	0.9
04/22/2025 17:00	4,349.7	1,003.8	5,353.5	105,200.0	563.2	0.68	0.3	1.1
04/22/2025 18:00	4,355.4	1,214.4	5,569.8	105,200.0	585.9	0.70	0.4	1.2
04/22/2025 19:00	4,375.8	1,230.4	5,606.2	105,200.0	589.8	0.71	0.4	1.2
04/22/2025 20:00	4,410.0	1,108.3	5,518.3	105,200.0	580.5	0.70	0.3	1.2
04/22/2025 21:00	4,436.0	1,035.1	5,471.1	105,200.0	575.6	0.69	0.3	1.2
04/22/2025 22:00	4,463.8	983.7	5,447.5	105,200.0	573.1	0.69	0.3	1.1
04/22/2025 23:00	4,480.5	884.9	5,365.4	105,200.0	564.4	0.68	0.3	1.1
Average/Sum#:	4,077.1	549.3	4,617.7	105,200.0	485.8	0.59	0.3	1.0
Minimum:	3,460.8	0.0	3,460.8	105,200.0	364.1	0.44	0.2	0.7
Maximum:	4,480.5	1,230.4	5,606.2	105,200.0	589.8	0.71	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/23/2025 00:00	4,487.9	490.9	4,978.8	105,200.0	523.8	0.63	0.3	1.0			
04/23/2025 01:00	4,498.3	535.2	5,033.5	105,200.0	529.5	0.64	0.3	1.1			
04/23/2025 02:00	4,503.9	452.4	4,956.3	105,200.0	521.4	0.63	0.3	1.0			
04/23/2025 03:00	4,508.5	461.1	4,969.6	105,200.0	522.8	0.63	0.3	1.0			
04/23/2025 04:00	4,511.7	470.9	4,982.6	105,200.0	524.2	0.63	0.3	1.0			
04/23/2025 05:00	4,515.2	443.6	4,958.8	105,200.0	521.7	0.63	0.3	1.0			
04/23/2025 06:00	4,240.6	220.0	4,355.0	105,200.0	458.1	0.56	0.3	0.9			
04/23/2025 07:00	3,511.7	0.0	3,511.7	105,200.0	369.4	0.44	0.2	0.7			
04/23/2025 08:00	3,522.8	0.0	3,522.8	105,200.0	370.6	0.44	0.2	0.7			
04/23/2025 09:00	3,528.5	0.0	3,528.5	105,200.0	371.2	0.45	0.2	0.7			
04/23/2025 10:00	3,537.5	0.0	3,537.5	105,200.0	372.1	0.45	0.2	0.7			
04/23/2025 11:00	3,520.4	0.0	3,520.4	105,200.0	370.3	0.44	0.2	0.7			
04/23/2025 12:00	3,512.8	0.0	3,512.8	105,200.0	369.5	0.44	0.2	0.7			
04/23/2025 13:00	3,517.6	0.0	3,517.6	105,200.0	370.1	0.44	0.2	0.7			
04/23/2025 14:00	3,505.5	0.0	3,505.5	105,200.0	368.8	0.44	0.2	0.7			
04/23/2025 15:00	3,512.1	0.0	3,512.1	105,200.0	369.5	0.44	0.2	0.7			
04/23/2025 16:00	3,512.1	0.0	3,512.1	105,200.0	369.5	0.44	0.2	0.7			
04/23/2025 17:00	4,001.5	153.7	4,044.5	105,200.0	425.5	0.52	0.3	0.9			
04/23/2025 18:00	4,430.4	587.6	5,018.0	105,200.0	527.9	0.63	0.3	1.1			
04/23/2025 19:00	4,453.2	539.1	4,992.3	105,200.0	525.2	0.63	0.3	1.1			
04/23/2025 20:00	4,478.0	507.2	4,985.2	105,200.0	524.4	0.63	0.3	1.0			
04/23/2025 21:00	4,491.6	459.9	4,951.5	105,200.0	520.9	0.62	0.3	1.0			
04/23/2025 22:00	4,501.9	468.6	4,970.5	105,200.0	522.9	0.63	0.3	1.0			
04/23/2025 23:00	4,507.3	461.7	4,969.0	105,200.0	522.7	0.63	0.3	1.0			
Average/Sum#:	4,054.6	260.5	4,306.1	105,200.0	453.0	0.54	0.3	0.9			
Minimum:	3,505.5	0.0	3,505.5	105,200.0	368.8	0.44	0.2	0.7			
Maximum:	4,515.2	587.6	5,033.5	105,200.0	529.5	0.64	0.3	1.1			
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/24/2025 00:00	4,512.6	451.2	4,963.8	105,200.0	522.2	0.63	0.3	1.0			
04/24/2025 01:00	4,522.4	443.8	4,966.2	105,200.0	522.4	0.63	0.3	1.0			
04/24/2025 02:00	4,513.1	455.3	4,968.4	105,200.0	522.7	0.63	0.3	1.0			
04/24/2025 03:00	4,511.5	460.8	4,972.3	105,200.0	523.1	0.63	0.3	1.0			
04/24/2025 04:00	4,513.2	450.9	4,964.1	105,200.0	522.2	0.63	0.3	1.0			
04/24/2025 05:00	3,735.5	2.5	3,735.6	105,200.0	393.0	0.47	0.2	0.8			
04/24/2025 06:00	3,520.6	0.0	3,520.6	105,200.0	370.4	0.44	0.2	0.7			
04/24/2025 07:00	3,523.9	0.0	3,523.9	105,200.0	370.7	0.45	0.2	0.7			
04/24/2025 08:00	3,516.2	0.0	3,516.2	105,200.0	369.9	0.44	0.2	0.7			
04/24/2025 09:00	3,509.5	0.0	3,509.5	105,200.0	369.2	0.44	0.2	0.7			
04/24/2025 10:00	3,485.8	0.0	3,485.8	105,200.0	366.7	0.44	0.2	0.7			
04/24/2025 11:00	3,485.8	0.0	3,485.8	105,200.0	366.7	0.44	0.2	0.7			
04/24/2025 12:00	3,480.0	0.0	3,480.0	105,200.0	366.1	0.44	0.2	0.7			
04/24/2025 13:00	3,482.3	0.0	3,482.3	105,200.0	366.3	0.44	0.2	0.7			
04/24/2025 14:00	3,494.1	0.0	3,494.1	105,200.0	367.6	0.44	0.2	0.7			
04/24/2025 15:00	3,489.3	0.0	3,489.3	105,200.0	367.1	0.44	0.2	0.7			
04/24/2025 16:00	3,729.2	0.0	3,729.2	105,200.0	392.3	0.47	0.2	0.8			
04/24/2025 17:00	3,974.3	96.4	3,996.5	105,200.0	420.4	0.51	0.3	0.9			
04/24/2025 18:00	4,424.9	488.0	4,912.9	105,200.0	516.8	0.62	0.3	1.0			
04/24/2025 19:00	4,441.9	506.2	4,948.1	105,200.0	520.5	0.62	0.3	1.0			
04/24/2025 20:00	4,454.5	495.9	4,950.4	105,200.0	520.8	0.62	0.3	1.0			
04/24/2025 21:00	4,465.5	477.0	4,942.5	105,200.0	520.0	0.62	0.3	1.0			
04/24/2025 22:00	4,474.4	452.8	4,927.2	105,200.0	518.3	0.62	0.3	1.0			
04/24/2025 23:00	4,475.2	453.0	4,928.2	105,200.0	518.4	0.62	0.3	1.0			
Average/Sum#:	3,989.0	218.1	4,203.9	105,200.0	442.2	0.53	0.3	0.9			
Minimum:	3,480.0	0.0	3,480.0	105,200.0	366.1	0.44	0.2	0.7			
Maximum:	4,522.4	506.2	4,972.3	105,200.0	523.1	0.63	0.3	1.0			
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/25/2025 00:00	4,479.8	447.7	4,927.5	105,200.0	518.4	0.62	0.3	1.0
04/25/2025 01:00	4,476.5	438.9	4,915.4	105,200.0	517.1	0.62	0.3	1.0
04/25/2025 02:00	3,575.6	2.5	3,575.7	105,200.0	376.2	0.45	0.2	0.8
04/25/2025 03:00	3,520.8	0.0	3,520.8	105,200.0	370.4	0.44	0.2	0.7
04/25/2025 04:00	3,604.1	0.0	3,604.1	105,200.0	379.2	0.46	0.2	0.8
04/25/2025 05:00	4,388.5	0.0	4,388.5	105,200.0	461.7	0.55	0.3	0.9
04/25/2025 06:00	4,388.4	0.0	4,388.4	105,200.0	461.7	0.55	0.3	0.9
04/25/2025 07:00	3,961.1	0.0	3,961.1	105,200.0	416.7	0.50	0.3	0.8
04/25/2025 08:00	4,044.3	0.0	4,044.3	105,200.0	425.5	0.51	0.3	0.9
04/25/2025 09:00	4,105.4	0.0	4,105.4	105,200.0	431.9	0.52	0.3	0.9
04/25/2025 10:00	4,383.4	0.0	4,383.4	105,200.0	461.1	0.56	0.3	0.9
04/25/2025 11:00	4,218.6	0.0	4,218.6	105,200.0	443.8	0.53	0.3	0.9
04/25/2025 12:00	4,127.2	0.0	4,127.2	105,200.0	434.2	0.52	0.3	0.9
04/25/2025 13:00	3,693.8	0.0	3,693.8	105,200.0	388.6	0.47	0.2	0.8
04/25/2025 14:00	4,415.7	520.8	4,874.0	105,200.0	512.7	0.62	0.3	1.0
04/25/2025 15:00	3,763.1	4.7	3,763.2	105,200.0	395.9	0.48	0.2	0.8
04/25/2025 16:00	3,591.8	0.0	3,591.8	105,200.0	377.9	0.45	0.2	0.8
04/25/2025 17:00	4,069.0	108.1	4,092.8	105,200.0	430.6	0.53	0.3	0.9
04/25/2025 18:00	4,422.6	647.2	5,069.8	105,200.0	533.3	0.64	0.3	1.1
04/25/2025 19:00	4,437.3	528.6	4,965.9	105,200.0	522.4	0.63	0.3	1.0
04/25/2025 20:00	4,456.9	505.4	4,962.3	105,200.0	522.0	0.63	0.3	1.0
04/25/2025 21:00	4,179.3	2.6	4,179.4	105,200.0	439.7	0.53	0.3	0.9
04/25/2025 22:00	3,731.7	0.0	3,731.7	105,200.0	392.6	0.47	0.2	0.8
04/25/2025 23:00	3,577.0	0.0	3,577.0	105,200.0	376.3	0.45	0.2	0.8
Average/Sum#:	4,067.2	133.6	4,194.3	105,200.0	441.2	0.53	0.3	0.9
Minimum:	3,520.8	0.0	3,520.8	105,200.0	370.4	0.44	0.2	0.7
Maximum:	4,479.8	647.2	5,069.8	105,200.0	533.3	0.64	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/26/2025 00:00	3,609.4	0.0	3,609.4	105,200.0	379.7	0.45	0.2	0.8
04/26/2025 01:00	3,569.2	0.0	3,569.2	105,200.0	375.5	0.45	0.2	0.8
04/26/2025 02:00	3,568.4	0.0	3,568.4	105,200.0	375.4	0.45	0.2	0.8
04/26/2025 03:00	3,569.9	0.0	3,569.9	105,200.0	375.6	0.45	0.2	0.8
04/26/2025 04:00	3,587.3	0.0	3,587.3	105,200.0	377.4	0.45	0.2	0.8
04/26/2025 05:00	3,560.0	0.0	3,560.0	105,200.0	374.5	0.45	0.2	0.7
04/26/2025 06:00	3,533.9	0.0	3,533.9	105,200.0	371.8	0.45	0.2	0.7
04/26/2025 07:00	3,826.2	0.0	3,826.2	105,200.0	402.5	0.48	0.2	0.8
04/26/2025 08:00	4,256.2	0.0	4,256.2	105,200.0	447.8	0.54	0.3	0.9
04/26/2025 09:00	4,028.0	0.0	4,028.0	105,200.0	423.7	0.51	0.3	0.8
04/26/2025 10:00	3,697.7	0.0	3,697.7	105,200.0	389.0	0.47	0.2	0.8
04/26/2025 11:00	3,726.2	0.0	3,726.2	105,200.0	392.0	0.47	0.2	0.8
04/26/2025 12:00	3,505.1	0.0	3,505.1	105,200.0	368.7	0.44	0.2	0.7
04/26/2025 13:00	3,502.4	0.0	3,502.4	105,200.0	368.5	0.44	0.2	0.7
04/26/2025 14:00	3,515.5	0.0	3,515.5	105,200.0	369.8	0.44	0.2	0.7
04/26/2025 15:00	3,505.9	0.0	3,505.9	105,200.0	368.8	0.44	0.2	0.7
04/26/2025 16:00	3,980.4	0.0	3,980.4	105,200.0	418.7	0.50	0.3	0.8
04/26/2025 17:00	4,032.2	0.0	4,032.2	105,200.0	424.2	0.51	0.3	0.8
04/26/2025 18:00	3,518.3	0.0	3,518.3	105,200.0	370.1	0.44	0.2	0.7
04/26/2025 19:00	3,603.5	0.0	3,603.5	105,200.0	379.1	0.45	0.2	0.8
04/26/2025 20:00	3,507.8	0.0	3,507.8	105,200.0	369.0	0.44	0.2	0.7
04/26/2025 21:00	3,506.2	0.0	3,506.2	105,200.0	368.9	0.44	0.2	0.7
04/26/2025 22:00	3,563.4	0.0	3,563.4	105,200.0	374.9	0.45	0.2	0.7
04/26/2025 23:00	4,375.1	0.0	4,375.1	105,200.0	460.3	0.55	0.3	0.9
Average/Sum#:	3,693.7	0.0	3,693.7	105,200.0	388.6	0.47	0.2	0.8
Minimum:	3,502.4	0.0	3,502.4	105,200.0	368.5	0.44	0.2	0.7
Maximum:	4,375.1	0.0	4,375.1	105,200.0	460.3	0.55	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/27/2025 00:00	3,883.9	0.0	3,883.9	105,200.0	408.6	0.49	0.2	0.8			
04/27/2025 01:00	3,539.5	0.0	3,539.5	105,200.0	372.4	0.45	0.2	0.7			
04/27/2025 02:00	3,540.4	0.0	3,540.4	105,200.0	372.5	0.45	0.2	0.7			
04/27/2025 03:00	4,012.9	0.0	4,012.9	105,200.0	422.2	0.51	0.3	0.8			
04/27/2025 04:00	3,542.7	0.0	3,542.7	105,200.0	372.7	0.45	0.2	0.7			
04/27/2025 05:00	3,533.3	0.0	3,533.3	105,200.0	371.7	0.45	0.2	0.7			
04/27/2025 06:00	3,532.2	0.0	3,532.2	105,200.0	371.6	0.45	0.2	0.7			
04/27/2025 07:00	3,517.5	0.0	3,517.5	105,200.0	370.0	0.44	0.2	0.7			
04/27/2025 08:00	3,509.1	0.0	3,509.1	105,200.0	369.2	0.44	0.2	0.7			
04/27/2025 09:00	3,526.8	0.0	3,526.8	105,200.0	371.0	0.45	0.2	0.7			
04/27/2025 10:00	3,532.4	0.0	3,532.4	105,200.0	371.6	0.45	0.2	0.7			
04/27/2025 11:00	3,517.7	0.0	3,517.7	105,200.0	370.1	0.44	0.2	0.7			
04/27/2025 12:00	3,512.8	0.0	3,512.8	105,200.0	369.5	0.44	0.2	0.7			
04/27/2025 13:00	3,512.9	0.0	3,512.9	105,200.0	369.6	0.44	0.2	0.7			
04/27/2025 14:00	3,520.0	0.0	3,520.0	105,200.0	370.3	0.44	0.2	0.7			
04/27/2025 15:00	3,813.1	0.0	3,813.1	105,200.0	401.1	0.48	0.2	0.8			
04/27/2025 16:00	3,862.6	0.0	3,862.6	105,200.0	406.3	0.49	0.2	0.8			
04/27/2025 17:00	3,634.8	0.0	3,634.8	105,200.0	382.4	0.46	0.2	0.8			
04/27/2025 18:00	3,520.6	0.0	3,520.6	105,200.0	370.4	0.44	0.2	0.7			
04/27/2025 19:00	3,506.4	0.0	3,506.4	105,200.0	368.9	0.44	0.2	0.7			
04/27/2025 20:00	3,511.3	0.0	3,511.3	105,200.0	369.4	0.44	0.2	0.7			
04/27/2025 21:00	3,508.5	0.0	3,508.5	105,200.0	369.1	0.44	0.2	0.7			
04/27/2025 22:00	3,508.4	0.0	3,508.4	105,200.0	369.1	0.44	0.2	0.7			
04/27/2025 23:00	3,506.6	0.0	3,506.6	105,200.0	368.9	0.44	0.2	0.7			
Average/Sum#:	3,587.8	0.0	3,587.8	105,200.0	377.4	0.45	0.2	0.7			
Minimum:	3,506.4	0.0	3,506.4	105,200.0	368.9	0.44	0.2	0.7			
Maximum:	4,012.9	0.0	4,012.9	105,200.0	422.2	0.51	0.3	0.8			
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/28/2025 00:00	3,502.1	0.0	3,502.1	105,200.0	368.4	0.44	0.2	0.2	0.7	0.7
04/28/2025 01:00	3,499.8	0.0	3,499.8	105,200.0	368.2	0.44	0.2	0.2	0.7	0.7
04/28/2025 02:00	3,500.0	0.0	3,500.0	105,200.0	368.2	0.44	0.2	0.2	0.7	0.7
04/28/2025 03:00	3,502.5	0.0	3,502.5	105,200.0	368.5	0.44	0.2	0.2	0.7	0.7
04/28/2025 04:00	3,515.3	0.0	3,515.3	105,200.0	369.8	0.44	0.2	0.2	0.7	0.7
04/28/2025 05:00	3,531.3	0.0	3,531.3	105,200.0	371.5	0.45	0.2	0.2	0.7	0.7
04/28/2025 06:00	3,532.3	0.0	3,532.3	105,200.0	371.6	0.45	0.2	0.2	0.7	0.7
04/28/2025 07:00	3,527.5	0.0	3,527.5	105,200.0	371.1	0.45	0.2	0.2	0.7	0.7
04/28/2025 08:00	3,511.8	0.0	3,511.8	105,200.0	369.4	0.44	0.2	0.2	0.7	0.7
04/28/2025 09:00	3,515.1	0.0	3,515.1	105,200.0	369.8	0.44	0.2	0.2	0.7	0.7
04/28/2025 10:00	3,517.9	0.0	3,517.9	105,200.0	370.1	0.44	0.2	0.2	0.7	0.7
04/28/2025 11:00	3,520.3	0.0	3,520.3	105,200.0	370.3	0.44	0.2	0.2	0.7	0.7
04/28/2025 12:00	3,520.7	0.0	3,520.7	105,200.0	370.4	0.44	0.2	0.2	0.7	0.7
04/28/2025 13:00	3,512.1	0.0	3,512.1	105,200.0	369.5	0.44	0.2	0.2	0.7	0.7
04/28/2025 14:00	3,519.6	0.0	3,519.6	105,200.0	370.3	0.44	0.2	0.2	0.7	0.7
04/28/2025 15:00	3,507.0	0.0	3,507.0	105,200.0	368.9	0.44	0.2	0.2	0.7	0.7
04/28/2025 16:00	3,480.8	0.0	3,480.8	105,200.0	366.2	0.44	0.2	0.2	0.7	0.7
04/28/2025 17:00	3,663.4	0.0	3,663.4	105,200.0	385.4	0.46	0.2	0.2	0.8	0.8
04/28/2025 18:00	3,481.1	0.0	3,481.1	105,200.0	366.2	0.44	0.2	0.2	0.7	0.7
04/28/2025 19:00	3,477.7	0.0	3,477.7	105,200.0	365.9	0.44	0.2	0.2	0.7	0.7
04/28/2025 20:00	3,491.0	0.0	3,491.0	105,200.0	367.3	0.44	0.2	0.2	0.7	0.7
04/28/2025 21:00	3,526.1	0.0	3,526.1	105,200.0	370.9	0.44	0.2	0.2	0.7	0.7
04/28/2025 22:00	3,496.8	0.0	3,496.8	105,200.0	367.9	0.44	0.2	0.2	0.7	0.7
04/28/2025 23:00	3,494.3	0.0	3,494.3	105,200.0	367.6	0.44	0.2	0.2	0.7	0.7
Average/Sum#:	3,514.4	0.0	3,514.4	105,200.0	369.7	0.44	0.2	0.2	0.7	0.7
Minimum:	3,477.7	0.0	3,477.7	105,200.0	365.9	0.44	0.2	0.2	0.7	0.7
Maximum:	3,663.4	0.0	3,663.4	105,200.0	385.4	0.46	0.2	0.2	0.8	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/29/2025 00:00	3,499.5	0.0	3,499.5	105,200.0	368.1	0.44	0.2	0.7
04/29/2025 01:00	3,498.7	0.0	3,498.7	105,200.0	368.1	0.44	0.2	0.7
04/29/2025 02:00	3,523.5	0.0	3,523.5	105,200.0	370.7	0.44	0.2	0.7
04/29/2025 03:00	3,580.4	0.0	3,580.4	105,200.0	376.7	0.45	0.2	0.8
04/29/2025 04:00	3,514.6	0.0	3,514.6	105,200.0	369.7	0.44	0.2	0.7
04/29/2025 05:00	3,500.1	0.0	3,500.1	105,200.0	368.2	0.44	0.2	0.7
04/29/2025 06:00	3,493.2	0.0	3,493.2	105,200.0	367.5	0.44	0.2	0.7
04/29/2025 07:00	3,495.0	0.0	3,495.0	105,200.0	367.7	0.44	0.2	0.7
04/29/2025 08:00	3,496.3	0.0	3,496.3	105,200.0	367.8	0.44	0.2	0.7
04/29/2025 09:00	3,493.5	0.0	3,493.5	105,200.0	367.5	0.44	0.2	0.7
04/29/2025 10:00	3,495.2	0.0	3,495.2	105,200.0	367.7	0.44	0.2	0.7
04/29/2025 11:00	3,500.1	0.0	3,500.1	105,200.0	368.2	0.44	0.2	0.7
04/29/2025 12:00	3,505.0	0.0	3,505.0	105,200.0	368.7	0.44	0.2	0.7
04/29/2025 13:00	3,512.8	0.0	3,512.8	105,200.0	369.5	0.44	0.2	0.7
04/29/2025 14:00	3,507.5	0.0	3,507.5	105,200.0	369.0	0.44	0.2	0.7
04/29/2025 15:00	3,500.0	0.0	3,500.0	105,200.0	368.2	0.44	0.2	0.7
04/29/2025 16:00	3,492.5	0.0	3,492.5	105,200.0	367.4	0.44	0.2	0.7
04/29/2025 17:00	3,663.0	0.0	3,663.0	105,200.0	385.3	0.46	0.2	0.8
04/29/2025 18:00	3,509.4	0.0	3,509.4	105,200.0	369.2	0.44	0.2	0.7
04/29/2025 19:00	3,486.6	0.0	3,486.6	105,200.0	366.8	0.44	0.2	0.7
04/29/2025 20:00	3,484.3	0.0	3,484.3	105,200.0	366.5	0.44	0.2	0.7
04/29/2025 21:00	3,494.4	0.0	3,494.4	105,200.0	367.6	0.44	0.2	0.7
04/29/2025 22:00	3,518.5	0.0	3,518.5	105,200.0	370.1	0.44	0.2	0.7
04/29/2025 23:00	3,485.5	0.0	3,485.5	105,200.0	366.7	0.44	0.2	0.7
Average/Sum#:	3,510.4	0.0	3,510.4	105,200.0	369.3	0.44	0.2	0.7
Minimum:	3,484.3	0.0	3,484.3	105,200.0	366.5	0.44	0.2	0.7
Maximum:	3,663.0	0.0	3,663.0	105,200.0	385.3	0.46	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/30/2025 00:00	3,483.8	0.0	3,483.8	105,200.0	366.5	0.44	0.2	0.2	0.7	0.7
04/30/2025 01:00	3,484.9	0.0	3,484.9	105,200.0	366.6	0.44	0.2	0.2	0.7	0.7
04/30/2025 02:00	3,487.7	0.0	3,487.7	105,200.0	366.9	0.44	0.2	0.2	0.7	0.7
04/30/2025 03:00	3,481.0	0.0	3,481.0	105,200.0	366.2	0.44	0.2	0.2	0.7	0.7
04/30/2025 04:00	3,483.4	0.0	3,483.4	105,200.0	366.5	0.44	0.2	0.2	0.7	0.7
04/30/2025 05:00	3,485.3	0.0	3,485.3	105,200.0	366.7	0.44	0.2	0.2	0.7	0.7
04/30/2025 06:00	3,490.5	0.0	3,490.5	105,200.0	367.2	0.44	0.2	0.2	0.7	0.7
04/30/2025 07:00	3,489.7	0.0	3,489.7	105,200.0	367.1	0.44	0.2	0.2	0.7	0.7
04/30/2025 08:00	3,485.0	0.0	3,485.0	105,200.0	366.6	0.44	0.2	0.2	0.7	0.7
04/30/2025 09:00	3,487.9	0.0	3,487.9	105,200.0	366.9	0.44	0.2	0.2	0.7	0.7
04/30/2025 10:00	3,497.2	0.0	3,497.2	105,200.0	367.9	0.44	0.2	0.2	0.7	0.7
04/30/2025 11:00	3,493.5	0.0	3,493.5	105,200.0	367.5	0.44	0.2	0.2	0.7	0.7
04/30/2025 12:00	3,470.5	0.0	3,470.5	105,200.0	365.1	0.44	0.2	0.2	0.7	0.7
04/30/2025 13:00	3,472.2	0.0	3,472.2	105,200.0	365.3	0.44	0.2	0.2	0.7	0.7
04/30/2025 14:00	3,474.4	0.0	3,474.4	105,200.0	365.5	0.44	0.2	0.2	0.7	0.7
04/30/2025 15:00	3,460.3	0.0	3,460.3	105,200.0	364.0	0.44	0.2	0.2	0.7	0.7
04/30/2025 16:00	3,445.8	0.0	3,445.8	105,200.0	362.5	0.44	0.2	0.2	0.7	0.7
04/30/2025 17:00	3,785.0	0.0	3,785.0	105,200.0	398.2	0.48	0.2	0.2	0.8	0.8
04/30/2025 18:00	3,633.1	0.0	3,633.1	105,200.0	382.2	0.46	0.2	0.2	0.8	0.8
04/30/2025 19:00	3,977.0	0.0	3,977.0	105,200.0	418.4	0.50	0.3	0.3	0.8	0.8
04/30/2025 20:00	4,240.5	0.0	4,240.5	105,200.0	446.1	0.54	0.3	0.3	0.9	0.9
04/30/2025 21:00	4,276.7	0.0	4,276.7	105,200.0	449.9	0.54	0.3	0.3	0.9	0.9
04/30/2025 22:00	4,291.4	0.0	4,291.4	105,200.0	451.5	0.54	0.3	0.3	0.9	0.9
04/30/2025 23:00	3,643.1	0.0	3,643.1	105,200.0	383.3	0.46	0.2	0.2	0.8	0.8
Average/Sum#:	3,625.8	0.0	3,625.8	105,200.0	381.4	0.46	0.2	0.2	0.7	0.7
Minimum:	3,445.8	0.0	3,445.8	105,200.0	362.5	0.44	0.2	0.2	0.7	0.7
Maximum:	4,291.4	0.0	4,291.4	105,200.0	451.5	0.54	0.3	0.3	0.9	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/01/2025 00:00	3,451.7	0.0	3,451.7	105,000.0	362.4	0.43	0.2	0.2	0.7	0.7	0.7
05/01/2025 01:00	3,506.2	0.0	3,506.2	105,000.0	368.2	0.44	0.2	0.2	0.7	0.7	0.7
05/01/2025 02:00	3,475.1	0.0	3,475.1	105,000.0	364.9	0.44	0.2	0.2	0.7	0.7	0.7
05/01/2025 03:00	3,575.2	0.0	3,575.2	105,000.0	375.4	0.45	0.2	0.2	0.8	0.8	0.8
05/01/2025 04:00	3,618.6	0.0	3,618.6	105,000.0	380.0	0.46	0.2	0.2	0.8	0.8	0.8
05/01/2025 05:00	3,634.6	0.0	3,634.6	105,000.0	381.6	0.46	0.2	0.2	0.8	0.8	0.8
05/01/2025 06:00	3,476.9	0.0	3,476.9	105,000.0	365.1	0.44	0.2	0.2	0.7	0.7	0.7
05/01/2025 07:00	3,483.9	0.0	3,483.9	105,000.0	365.8	0.44	0.2	0.2	0.7	0.7	0.7
05/01/2025 08:00	3,483.2	0.0	3,483.2	105,000.0	365.7	0.44	0.2	0.2	0.7	0.7	0.7
05/01/2025 09:00	3,487.8	0.0	3,487.8	105,000.0	366.2	0.44	0.2	0.2	0.7	0.7	0.7
05/01/2025 10:00	3,488.1	0.0	3,488.1	105,000.0	366.3	0.44	0.2	0.2	0.7	0.7	0.7
05/01/2025 11:00	3,499.9	0.0	3,499.9	105,000.0	367.5	0.44	0.2	0.2	0.7	0.7	0.7
05/01/2025 12:00	3,475.7	0.0	3,475.7	105,000.0	364.9	0.44	0.2	0.2	0.7	0.7	0.7
05/01/2025 13:00	3,464.7	0.0	3,464.7	105,000.0	363.8	0.44	0.2	0.2	0.7	0.7	0.7
05/01/2025 14:00	3,463.5	0.0	3,463.5	105,000.0	363.7	0.44	0.2	0.2	0.7	0.7	0.7
05/01/2025 15:00	3,449.1	0.0	3,449.1	105,000.0	362.2	0.43	0.2	0.2	0.7	0.7	0.7
05/01/2025 16:00	3,445.3	0.0	3,445.3	105,000.0	361.8	0.43	0.2	0.2	0.7	0.7	0.7
05/01/2025 17:00	3,919.8	0.0	3,919.8	105,000.0	411.6	0.50	0.2	0.2	0.8	0.8	0.8
05/01/2025 18:00	4,255.6	0.0	4,255.6	105,000.0	446.8	0.54	0.3	0.3	0.9	0.9	0.9
05/01/2025 19:00	4,013.7	0.0	4,013.7	105,000.0	421.4	0.51	0.3	0.3	0.8	0.8	0.8
05/01/2025 20:00	3,587.5	0.0	3,587.5	105,000.0	376.7	0.45	0.2	0.2	0.8	0.8	0.8
05/01/2025 21:00	4,277.4	0.0	4,277.4	105,000.0	449.1	0.54	0.3	0.3	0.9	0.9	0.9
05/01/2025 22:00	3,627.0	0.0	3,627.0	105,000.0	380.8	0.46	0.2	0.2	0.8	0.8	0.8
05/01/2025 23:00	3,490.2	0.0	3,490.2	105,000.0	366.5	0.44	0.2	0.2	0.7	0.7	0.7
Average/Sum#:	3,610.4	0.0	3,610.4	105,000.0	379.1	0.46	0.2	0.2	0.7	0.7	0.7
Minimum:	3,445.3	0.0	3,445.3	105,000.0	361.8	0.43	0.2	0.2	0.7	0.7	0.7
Maximum:	4,277.4	0.0	4,277.4	105,000.0	449.1	0.54	0.3	0.3	0.9	0.9	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:					> 4.73		> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/02/2025 00:00	3,473.5	0.0	3,473.5	105,000.0	364.7	0.44	0.2	0.2	0.7	0.7
05/02/2025 01:00	3,472.9	0.0	3,472.9	105,000.0	364.7	0.44	0.2	0.2	0.7	0.7
05/02/2025 02:00	3,481.6	0.0	3,481.6	105,000.0	365.6	0.44	0.2	0.2	0.7	0.7
05/02/2025 03:00	3,491.3	0.0	3,491.3	105,000.0	366.6	0.44	0.2	0.2	0.7	0.7
05/02/2025 04:00	3,529.4	0.0	3,529.4	105,000.0	370.6	0.44	0.2	0.2	0.7	0.7
05/02/2025 05:00	3,584.9	0.0	3,584.9	105,000.0	376.4	0.45	0.2	0.2	0.8	0.8
05/02/2025 06:00	3,793.1	0.0	3,793.1	105,000.0	398.3	0.48	0.2	0.2	0.8	0.8
05/02/2025 07:00	3,483.0	0.0	3,483.0	105,000.0	365.7	0.44	0.2	0.2	0.7	0.7
05/02/2025 08:00	3,456.3	0.0	3,456.3	105,000.0	362.9	0.44	0.2	0.2	0.7	0.7
05/02/2025 09:00	3,451.5	0.0	3,451.5	105,000.0	362.4	0.44	0.2	0.2	0.7	0.7
05/02/2025 10:00	3,444.6	0.0	3,444.6	105,000.0	361.7	0.43	0.2	0.2	0.7	0.7
05/02/2025 11:00	3,447.9	0.0	3,447.9	105,000.0	362.0	0.43	0.2	0.2	0.7	0.7
05/02/2025 12:00	3,453.4	0.0	3,453.4	105,000.0	362.6	0.44	0.2	0.2	0.7	0.7
05/02/2025 13:00	3,443.9	0.0	3,443.9	105,000.0	361.6	0.43	0.2	0.2	0.7	0.7
05/02/2025 14:00	3,440.7	0.0	3,440.7	105,000.0	361.3	0.43	0.2	0.2	0.7	0.7
05/02/2025 15:00	2,836.9	0.0	2,836.9	105,000.0	297.9	0.43	0.2	0.2	0.7	0.7
05/02/2025 16:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0
05/02/2025 17:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0
05/02/2025 18:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0
05/02/2025 19:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0
05/02/2025 20:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0
05/02/2025 21:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0
05/02/2025 22:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0
05/02/2025 23:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0
Average/Sum#:	3,455.3	0.0	3,455.3	105,000.0	362.8	0.44	0.2	0.2	0.7	0.7
Minimum:	2,836.9	0.0	2,836.9	105,000.0	297.9	0.43	0.2	0.2	0.7	0.7
Maximum:	3,793.1	0.0	3,793.1	105,000.0	398.3	0.48	0.2	0.2	0.8	0.8
%SI	33.33	33.33	33.33	0.00	33.33	33.33	33.33	33.33	33.33	33.33

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/03/2025 00:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/03/2025 01:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/03/2025 02:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/03/2025 03:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/03/2025 04:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/03/2025 05:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/03/2025 06:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/03/2025 07:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/03/2025 08:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/03/2025 09:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/03/2025 10:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/03/2025 11:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/03/2025 12:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/03/2025 13:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/03/2025 14:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/03/2025 15:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/03/2025 16:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/03/2025 17:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/03/2025 18:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/03/2025 19:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/03/2025 20:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/03/2025 21:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/03/2025 22:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/03/2025 23:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/04/2025 00:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/04/2025 01:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/04/2025 02:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/04/2025 03:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/04/2025 04:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/04/2025 05:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/04/2025 06:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/04/2025 07:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/04/2025 08:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/04/2025 09:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/04/2025 10:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/04/2025 11:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/04/2025 12:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/04/2025 13:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/04/2025 14:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/04/2025 15:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/04/2025 16:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/04/2025 17:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/04/2025 18:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/04/2025 19:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/04/2025 20:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/04/2025 21:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/04/2025 22:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/04/2025 23:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/05/2025 00:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/05/2025 01:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/05/2025 02:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/05/2025 03:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/05/2025 04:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/05/2025 05:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/05/2025 06:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/05/2025 07:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/05/2025 08:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/05/2025 09:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/05/2025 10:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/05/2025 11:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/05/2025 12:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/05/2025 13:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/05/2025 14:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/05/2025 15:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/05/2025 16:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/05/2025 17:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/05/2025 18:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/05/2025 19:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/05/2025 20:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/05/2025 21:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/05/2025 22:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/05/2025 23:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/06/2025 00:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/06/2025 01:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/06/2025 02:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/06/2025 03:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/06/2025 04:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/06/2025 05:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/06/2025 06:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/06/2025 07:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/06/2025 08:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/06/2025 09:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/06/2025 10:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/06/2025 11:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/06/2025 12:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/06/2025 13:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/06/2025 14:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/06/2025 15:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/06/2025 16:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/06/2025 17:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/06/2025 18:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/06/2025 19:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/06/2025 20:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/06/2025 21:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/06/2025 22:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/06/2025 23:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)		1 Hour(s)	
05/07/2025 00:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0		0.0	
05/07/2025 01:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0		0.0	
05/07/2025 02:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0		0.0	
05/07/2025 03:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0		0.0	
05/07/2025 04:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0		0.0	
05/07/2025 05:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0		0.0	
05/07/2025 06:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0		0.0	
05/07/2025 07:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0		0.0	
05/07/2025 08:00	1,662.1	0.0	1,662.1	105,000.0	174.5	0.00	0.0	0.0		0.0	
05/07/2025 09:00	3,573.2	0.0	3,573.2	105,000.0	375.2	0.44	0.2	0.7			
05/07/2025 10:00	3,477.1	0.0	3,477.1	105,000.0	365.1	0.44	0.2	0.7			
05/07/2025 11:00	3,444.6	0.0	3,444.6	105,000.0	361.7	0.43	0.2	0.7			
05/07/2025 12:00	3,450.7	0.0	3,450.7	105,000.0	362.3	0.44	0.2	0.7			
05/07/2025 13:00	3,561.4	0.0	3,561.4	105,000.0	373.9	0.45	0.2	0.7			
05/07/2025 14:00	3,495.5	0.0	3,495.5	105,000.0	367.0	0.44	0.2	0.7			
05/07/2025 15:00	3,497.1	0.0	3,497.1	105,000.0	367.2	0.44	0.2	0.7			
05/07/2025 16:00	3,480.6	0.0	3,480.6	105,000.0	365.5	0.44	0.2	0.7			
05/07/2025 17:00	3,660.8	0.0	3,660.8	105,000.0	384.4	0.46	0.2	0.8			
05/07/2025 18:00	3,485.9	0.0	3,485.9	105,000.0	366.0	0.44	0.2	0.7			
05/07/2025 19:00	3,470.3	0.0	3,470.3	105,000.0	364.4	0.44	0.2	0.7			
05/07/2025 20:00	3,495.3	0.0	3,495.3	105,000.0	367.0	0.44	0.2	0.7			
05/07/2025 21:00	3,509.7	0.0	3,509.7	105,000.0	368.5	0.44	0.2	0.7			
05/07/2025 22:00	3,512.8	0.0	3,512.8	105,000.0	368.8	0.44	0.2	0.7			
05/07/2025 23:00	3,539.0	0.0	3,539.0	105,000.0	371.6	0.45	0.2	0.7			
Average/Sum#:	3,394.8	0.0	3,394.8	105,000.0	356.4	0.44	0.2	0.7			
Minimum:	1,662.1	0.0	1,662.1	105,000.0	174.5	0.43	0.2	0.7			
Maximum:	3,660.8	0.0	3,660.8	105,000.0	384.4	0.46	0.2	0.8			
%SI	33.33	33.33	33.33	0.00	33.33	37.50	37.50	37.50			

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/08/2025 00:00	3,511.4	0.0	3,511.4	105,000.0	368.7	0.44	0.2	0.7
05/08/2025 01:00	3,510.4	0.0	3,510.4	105,000.0	368.6	0.44	0.2	0.7
05/08/2025 02:00	3,514.2	0.0	3,514.2	105,000.0	369.0	0.44	0.2	0.7
05/08/2025 03:00	3,516.4	0.0	3,516.4	105,000.0	369.2	0.44	0.2	0.7
05/08/2025 04:00	3,506.9	0.0	3,506.9	105,000.0	368.2	0.44	0.2	0.7
05/08/2025 05:00	3,537.2	0.0	3,537.2	105,000.0	371.4	0.45	0.2	0.7
05/08/2025 06:00	3,498.8	0.0	3,498.8	105,000.0	367.4	0.44	0.2	0.7
05/08/2025 07:00	3,506.9	0.0	3,506.9	105,000.0	368.2	0.44	0.2	0.7
05/08/2025 08:00	3,506.4	0.0	3,506.4	105,000.0	368.2	0.44	0.2	0.7
05/08/2025 09:00	3,518.0	0.0	3,518.0	105,000.0	369.4	0.44	0.2	0.7
05/08/2025 10:00	3,492.6	0.0	3,492.6	105,000.0	366.7	0.44	0.2	0.7
05/08/2025 11:00	3,492.6	0.0	3,492.6	105,000.0	366.7	0.44	0.2	0.7
05/08/2025 12:00	3,499.0	0.0	3,499.0	105,000.0	367.4	0.44	0.2	0.7
05/08/2025 13:00	3,526.0	0.0	3,526.0	105,000.0	370.2	0.44	0.2	0.7
05/08/2025 14:00	3,509.4	0.0	3,509.4	105,000.0	368.5	0.44	0.2	0.7
05/08/2025 15:00	3,492.9	0.0	3,492.9	105,000.0	366.8	0.44	0.2	0.7
05/08/2025 16:00	3,586.7	0.0	3,586.7	105,000.0	376.6	0.45	0.2	0.8
05/08/2025 17:00	3,981.1	0.0	3,981.1	105,000.0	418.0	0.50	0.3	0.8
05/08/2025 18:00	4,260.8	425.6	4,452.3	105,000.0	467.5	0.59	0.3	1.0
05/08/2025 19:00	4,279.4	1,319.9	5,599.3	105,000.0	587.9	0.71	0.4	1.2
05/08/2025 20:00	4,309.8	1,605.2	5,915.0	105,000.0	621.1	0.74	0.4	1.2
05/08/2025 21:00	4,344.2	1,915.7	6,259.9	105,000.0	657.3	0.79	0.4	1.3
05/08/2025 22:00	4,360.1	1,478.7	5,838.8	105,000.0	613.1	0.74	0.4	1.2
05/08/2025 23:00	4,345.4	736.8	4,875.9	105,000.0	512.0	0.64	0.3	1.1
Average/Sum#:	3,733.6	311.7	4,027.0	105,000.0	422.8	0.51	0.2	0.8
Minimum:	3,492.6	0.0	3,492.6	105,000.0	366.7	0.44	0.2	0.7
Maximum:	4,360.1	1,915.7	6,259.9	105,000.0	657.3	0.79	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/09/2025 00:00	4,335.7	0.0	4,335.7	105,000.0	455.2	0.55	0.3	0.9
05/09/2025 01:00	3,979.4	0.0	3,979.4	105,000.0	417.8	0.50	0.3	0.8
05/09/2025 02:00	4,052.5	0.0	4,052.5	105,000.0	425.5	0.51	0.3	0.9
05/09/2025 03:00	4,281.6	0.0	4,281.6	105,000.0	449.6	0.54	0.3	0.9
05/09/2025 04:00	4,279.3	0.0	4,279.3	105,000.0	449.3	0.54	0.3	0.9
05/09/2025 05:00	3,821.5	0.0	3,821.5	105,000.0	401.3	0.48	0.2	0.8
05/09/2025 06:00	3,089.9	0.0	3,089.9	105,000.0	324.4	0.43	0.2	0.7
05/09/2025 07:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/09/2025 08:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/09/2025 09:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/09/2025 10:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/09/2025 11:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/09/2025 12:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/09/2025 13:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/09/2025 14:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/09/2025 15:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/09/2025 16:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/09/2025 17:00	2,641.1	0.0	2,641.1	105,000.0	277.3	0.00	0.0	0.0
05/09/2025 18:00	3,833.7	0.0	3,833.7	105,000.0	402.5	0.51	0.3	0.9
05/09/2025 19:00	4,266.7	0.0	4,266.7	105,000.0	448.0	0.54	0.3	0.9
05/09/2025 20:00	4,275.1	0.0	4,275.1	105,000.0	448.9	0.54	0.3	0.9
05/09/2025 21:00	4,283.2	0.0	4,283.2	105,000.0	449.7	0.54	0.3	0.9
05/09/2025 22:00	4,277.9	0.0	4,277.9	105,000.0	449.2	0.54	0.3	0.9
05/09/2025 23:00	4,284.6	0.0	4,284.6	105,000.0	449.9	0.54	0.3	0.9
Average/Sum#:	3,978.7	0.0	3,978.7	105,000.0	417.8	0.52	0.3	0.9
Minimum:	2,641.1	0.0	2,641.1	105,000.0	277.3	0.43	0.2	0.7
Maximum:	4,335.7	0.0	4,335.7	105,000.0	455.2	0.55	0.3	0.9
%SI	41.67	41.67	41.67	0.00	41.67	45.83	45.83	45.83

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)		1 Hour(s)	1 Hour(s)
05/10/2025 00:00	4,289.8	0.0	4,289.8	105,000.0	450.4	0.54	0.3	0.9			
05/10/2025 01:00	3,662.2	0.0	3,662.2	105,000.0	384.5	0.46	0.2	0.8			
05/10/2025 02:00	3,276.6	0.0	3,276.6	105,000.0	344.0	0.43	0.2	0.7			
05/10/2025 03:00	1,101.2	0.0	1,101.2	105,000.0	115.6	0.00	0.0	0.0			
05/10/2025 04:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0			
05/10/2025 05:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0			
05/10/2025 06:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0			
05/10/2025 07:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0			
05/10/2025 08:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0			
05/10/2025 09:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0			
05/10/2025 10:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0			
05/10/2025 11:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0			
05/10/2025 12:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0			
05/10/2025 13:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0			
05/10/2025 14:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0			
05/10/2025 15:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0			
05/10/2025 16:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0			
05/10/2025 17:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0			
05/10/2025 18:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0			
05/10/2025 19:00	2,638.7	0.0	2,638.7	105,000.0	277.1	0.00	0.0	0.0			
05/10/2025 20:00	4,032.1	8.1	4,032.7	105,000.0	423.4	0.54	0.3	0.9			
05/10/2025 21:00	4,262.2	0.0	4,262.2	105,000.0	447.5	0.54	0.3	0.9			
05/10/2025 22:00	4,265.3	0.0	4,265.3	105,000.0	447.9	0.54	0.3	0.9			
05/10/2025 23:00	3,869.9	0.0	3,869.9	105,000.0	406.3	0.49	0.2	0.8			
Average/Sum#:	3,488.7	0.9	3,488.7	105,000.0	366.3	0.51	0.3	0.8			
Minimum:	1,101.2	0.0	1,101.2	105,000.0	115.6	0.43	0.2	0.7			
Maximum:	4,289.8	8.1	4,289.8	105,000.0	450.4	0.54	0.3	0.9			
%SI	62.50	62.50	62.50	0.00	62.50	70.83	70.83	70.83			

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/11/2025 00:00	3,442.9	0.0	3,442.9	105,000.0	361.5	0.46	0.2	0.8			
05/11/2025 01:00	877.3	0.0	877.3	105,000.0	92.1	0.00	0.0	0.0			
05/11/2025 02:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0			
05/11/2025 03:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0			
05/11/2025 04:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0			
05/11/2025 05:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0			
05/11/2025 06:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0			
05/11/2025 07:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0			
05/11/2025 08:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0			
05/11/2025 09:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0			
05/11/2025 10:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0			
05/11/2025 11:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0			
05/11/2025 12:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0			
05/11/2025 13:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0			
05/11/2025 14:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0			
05/11/2025 15:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0			
05/11/2025 16:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0			
05/11/2025 17:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0			
05/11/2025 18:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0			
05/11/2025 19:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0			
05/11/2025 20:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0			
05/11/2025 21:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0			
05/11/2025 22:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0			
05/11/2025 23:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0			
Average/Sum#:	2,160.1	0.0	2,160.1	105,000.0	226.8	0.46	0.2	0.8			
Minimum:	877.3	0.0	877.3	105,000.0	92.1	0.46	0.2	0.8			
Maximum:	3,442.9	0.0	3,442.9	105,000.0	361.5	0.46	0.2	0.8			
%SI	91.67	91.67	91.67	0.00	91.67	95.83	95.83	95.83			

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/12/2025 00:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/12/2025 01:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/12/2025 02:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/12/2025 03:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/12/2025 04:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/12/2025 05:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/12/2025 06:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/12/2025 07:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/12/2025 08:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/12/2025 09:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/12/2025 10:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/12/2025 11:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/12/2025 12:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/12/2025 13:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/12/2025 14:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/12/2025 15:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/12/2025 16:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/12/2025 17:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/12/2025 18:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/12/2025 19:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/12/2025 20:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/12/2025 21:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/12/2025 22:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/12/2025 23:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/13/2025 00:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/13/2025 01:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/13/2025 02:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/13/2025 03:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/13/2025 04:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/13/2025 05:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/13/2025 06:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/13/2025 07:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/13/2025 08:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/13/2025 09:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/13/2025 10:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/13/2025 11:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/13/2025 12:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/13/2025 13:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/13/2025 14:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/13/2025 15:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/13/2025 16:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/13/2025 17:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/13/2025 18:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/13/2025 19:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/13/2025 20:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/13/2025 21:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/13/2025 22:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/13/2025 23:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

Const. Value/Limit Tag:		> 4.73 > 1 > 1.8							
		Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	
		GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
		1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/14/2025 00:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/14/2025 01:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/14/2025 02:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/14/2025 03:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/14/2025 04:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/14/2025 05:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/14/2025 06:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/14/2025 07:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/14/2025 08:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/14/2025 09:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/14/2025 10:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/14/2025 11:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/14/2025 12:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/14/2025 13:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/14/2025 14:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/14/2025 15:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/14/2025 16:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/14/2025 17:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/14/2025 18:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/14/2025 19:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/14/2025 20:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/14/2025 21:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/14/2025 22:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/14/2025 23:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
Average/Sum#:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
Minimum:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
Maximum:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00	

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1		Unit CT1		Unit CT1		Unit CT1		Unit CT1		Unit CT1		Unit CT1		Unit CT1		Unit CT1	
	GasFlow, _CT, 100scfh		GasFlow, _DB, 100scfh		GasFlowTotal, 100scfh		GCVGas, BtuPer100scf		HI, MBtuPerHr		PM10_Norm, LbPerHr		SO2_Norm, LbPerHr		VOC_Norm, LbPerHr			
	1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)	
05/15/2025 00:00	0.0		0.0		0.0		105,000.0		0.0		0.00		0.0		0.0		0.0	
05/15/2025 01:00	0.0		0.0		0.0		105,000.0		0.0		0.00		0.0		0.0		0.0	
05/15/2025 02:00	0.0		0.0		0.0		105,000.0		0.0		0.00		0.0		0.0		0.0	
05/15/2025 03:00	0.0		0.0		0.0		105,000.0		0.0		0.00		0.0		0.0		0.0	
05/15/2025 04:00	0.0		0.0		0.0		105,000.0		0.0		0.00		0.0		0.0		0.0	
05/15/2025 05:00	0.0		0.0		0.0		105,000.0		0.0		0.00		0.0		0.0		0.0	
05/15/2025 06:00	0.0		0.0		0.0		105,000.0		0.0		0.00		0.0		0.0		0.0	
05/15/2025 07:00	0.0		0.0		0.0		105,000.0		0.0		0.00		0.0		0.0		0.0	
05/15/2025 08:00	0.0		0.0		0.0		105,000.0		0.0		0.00		0.0		0.0		0.0	
05/15/2025 09:00	0.0		0.0		0.0		105,000.0		0.0		0.00		0.0		0.0		0.0	
05/15/2025 10:00	0.0		0.0		0.0		105,000.0		0.0		0.00		0.0		0.0		0.0	
05/15/2025 11:00	0.0		0.0		0.0		105,000.0		0.0		0.00		0.0		0.0		0.0	
05/15/2025 12:00	0.0		0.0		0.0		105,000.0		0.0		0.00		0.0		0.0		0.0	
05/15/2025 13:00	0.0		0.0		0.0		105,000.0		0.0		0.00		0.0		0.0		0.0	
05/15/2025 14:00	0.0		0.0		0.0		105,000.0		0.0		0.00		0.0		0.0		0.0	
05/15/2025 15:00	0.0		0.0		0.0		105,000.0		0.0		0.00		0.0		0.0		0.0	
05/15/2025 16:00	0.0		0.0		0.0		105,000.0		0.0		0.00		0.0		0.0		0.0	
05/15/2025 17:00	0.0		0.0		0.0		105,000.0		0.0		0.00		0.0		0.0		0.0	
05/15/2025 18:00	0.0		0.0		0.0		105,000.0		0.0		0.00		0.0		0.0		0.0	
05/15/2025 19:00	0.0		0.0		0.0		105,000.0		0.0		0.00		0.0		0.0		0.0	
05/15/2025 20:00	0.0		0.0		0.0		105,000.0		0.0		0.00		0.0		0.0		0.0	
05/15/2025 21:00	0.0		0.0		0.0		105,000.0		0.0		0.00		0.0		0.0		0.0	
05/15/2025 22:00	0.0		0.0		0.0		105,000.0		0.0		0.00		0.0		0.0		0.0	
05/15/2025 23:00	0.0		0.0		0.0		105,000.0		0.0		0.00		0.0		0.0		0.0	
Average/Sum#:	0.0		0.0		0.0		105,000.0		0.0		0.00		0.0		0.0		0.0	
Minimum:	0.0		0.0		0.0		105,000.0		0.0		0.00		0.0		0.0		0.0	
Maximum:	0.0		0.0		0.0		105,000.0		0.0		0.00		0.0		0.0		0.0	
%SI	100.00		100.00		100.00		0.00		100.00		100.00		100.00		100.00		100.00	

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/16/2025 00:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/16/2025 01:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/16/2025 02:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/16/2025 03:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/16/2025 04:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/16/2025 05:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/16/2025 06:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/16/2025 07:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/16/2025 08:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/16/2025 09:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/16/2025 10:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/16/2025 11:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/16/2025 12:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/16/2025 13:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/16/2025 14:00	2,270.9	0.0	2,270.9	105,000.0	238.4	0.00	0.0	0.0	0.0	0.0	0.0
05/16/2025 15:00	3,526.2	0.0	3,526.2	105,000.0	370.3	0.45	0.2	0.7	0.7	0.7	0.7
05/16/2025 16:00	3,503.1	0.0	3,503.1	105,000.0	367.8	0.44	0.2	0.7	0.7	0.7	0.7
05/16/2025 17:00	3,731.8	0.0	3,731.8	105,000.0	391.8	0.47	0.2	0.8	0.8	0.8	0.8
05/16/2025 18:00	3,765.1	0.0	3,765.1	105,000.0	395.3	0.47	0.2	0.8	0.8	0.8	0.8
05/16/2025 19:00	3,460.3	0.0	3,460.3	105,000.0	363.3	0.43	0.2	0.7	0.7	0.7	0.7
05/16/2025 20:00	3,416.4	0.0	3,416.4	105,000.0	358.7	0.44	0.2	0.7	0.7	0.7	0.7
05/16/2025 21:00	1,820.3	0.0	1,820.3	105,000.0	191.1	0.00	0.0	0.0	0.0	0.0	0.0
05/16/2025 22:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/16/2025 23:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,186.8	0.0	3,186.8	105,000.0	334.6	0.45	0.2	0.7	0.7	0.7	0.7
Minimum:	1,820.3	0.0	1,820.3	105,000.0	191.1	0.43	0.2	0.7	0.7	0.7	0.7
Maximum:	3,765.1	0.0	3,765.1	105,000.0	395.3	0.47	0.2	0.8	0.8	0.8	0.8
%SI	66.67	66.67	66.67	0.00	66.67	75.00	75.00	75.00	75.00	75.00	75.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/17/2025 00:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/17/2025 01:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/17/2025 02:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/17/2025 03:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/17/2025 04:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/17/2025 05:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/17/2025 06:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/17/2025 07:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/17/2025 08:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/17/2025 09:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/17/2025 10:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/17/2025 11:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/17/2025 12:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/17/2025 13:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/17/2025 14:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/17/2025 15:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/17/2025 16:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/17/2025 17:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/17/2025 18:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/17/2025 19:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/17/2025 20:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/17/2025 21:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/17/2025 22:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/17/2025 23:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/18/2025 00:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/18/2025 01:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/18/2025 02:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/18/2025 03:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/18/2025 04:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/18/2025 05:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/18/2025 06:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/18/2025 07:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/18/2025 08:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/18/2025 09:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/18/2025 10:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/18/2025 11:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/18/2025 12:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/18/2025 13:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/18/2025 14:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/18/2025 15:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/18/2025 16:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/18/2025 17:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/18/2025 18:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/18/2025 19:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/18/2025 20:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/18/2025 21:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/18/2025 22:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/18/2025 23:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/19/2025 00:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/19/2025 01:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/19/2025 02:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/19/2025 03:00	2,834.8	0.0	2,834.8	105,000.0	297.7	0.00	0.0	0.0
05/19/2025 04:00	3,708.8	0.0	3,708.8	105,000.0	389.4	0.44	0.2	0.7
05/19/2025 05:00	3,496.0	0.0	3,496.0	105,000.0	367.1	0.44	0.2	0.7
05/19/2025 06:00	3,914.4	0.0	3,914.4	105,000.0	411.0	0.49	0.2	0.8
05/19/2025 07:00	4,469.6	1,125.0	5,403.4	105,000.0	567.4	0.71	0.4	1.2
05/19/2025 08:00	4,459.1	1,413.9	5,873.0	105,000.0	616.7	0.74	0.4	1.2
05/19/2025 09:00	4,429.9	1,429.5	5,859.4	105,000.0	615.2	0.74	0.4	1.2
05/19/2025 10:00	4,403.4	1,488.1	5,891.5	105,000.0	618.6	0.74	0.4	1.2
05/19/2025 11:00	4,401.4	1,538.1	5,939.5	105,000.0	623.6	0.75	0.4	1.2
05/19/2025 12:00	4,384.0	1,579.9	5,963.9	105,000.0	626.2	0.75	0.4	1.3
05/19/2025 13:00	4,369.1	1,596.0	5,965.1	105,000.0	626.3	0.75	0.4	1.3
05/19/2025 14:00	4,354.2	1,592.8	5,947.0	105,000.0	624.4	0.75	0.4	1.2
05/19/2025 15:00	4,321.3	1,626.2	5,947.5	105,000.0	624.5	0.75	0.4	1.2
05/19/2025 16:00	4,317.6	1,623.7	5,941.3	105,000.0	623.8	0.75	0.4	1.2
05/19/2025 17:00	4,305.1	1,629.4	5,934.5	105,000.0	623.1	0.75	0.4	1.2
05/19/2025 18:00	4,319.0	1,497.9	5,816.9	105,000.0	610.8	0.73	0.4	1.2
05/19/2025 19:00	4,079.5	230.4	4,199.3	105,000.0	440.9	0.54	0.3	0.9
05/19/2025 20:00	3,467.1	0.0	3,467.1	105,000.0	364.0	0.44	0.2	0.7
05/19/2025 21:00	4,254.7	0.0	4,254.7	105,000.0	446.7	0.54	0.3	0.9
05/19/2025 22:00	4,313.3	0.0	4,313.3	105,000.0	452.9	0.54	0.3	0.9
05/19/2025 23:00	4,314.3	0.0	4,314.3	105,000.0	453.0	0.54	0.3	0.9
Average/Sum#:	4,138.9	874.8	4,999.3	105,000.0	524.9	0.64	0.3	1.1
Minimum:	2,834.8	0.0	2,834.8	105,000.0	297.7	0.44	0.2	0.7
Maximum:	4,469.6	1,629.4	5,965.1	105,000.0	626.3	0.75	0.4	1.3
%SI	12.50	12.50	12.50	0.00	12.50	16.67	16.67	16.67

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/20/2025 00:00	4,317.4	0.0	4,317.4	105,000.0	453.3	0.54	0.3	0.3	0.9	0.9
05/20/2025 01:00	4,310.3	0.0	4,310.3	105,000.0	452.6	0.54	0.3	0.3	0.9	0.9
05/20/2025 02:00	4,304.2	0.0	4,304.2	105,000.0	451.9	0.54	0.3	0.3	0.9	0.9
05/20/2025 03:00	4,362.6	86.2	4,386.7	105,000.0	460.6	0.56	0.3	0.3	0.9	0.9
05/20/2025 04:00	4,473.3	939.4	5,412.7	105,000.0	568.3	0.68	0.3	0.3	1.1	1.1
05/20/2025 05:00	4,475.8	1,272.4	5,748.2	105,000.0	603.6	0.72	0.4	0.4	1.2	1.2
05/20/2025 06:00	4,466.1	1,253.2	5,719.3	105,000.0	600.5	0.72	0.4	0.4	1.2	1.2
05/20/2025 07:00	4,462.7	1,292.4	5,755.1	105,000.0	604.3	0.72	0.4	0.4	1.2	1.2
05/20/2025 08:00	4,442.2	1,392.7	5,834.9	105,000.0	612.7	0.74	0.4	0.4	1.2	1.2
05/20/2025 09:00	4,408.2	1,460.9	5,869.1	105,000.0	616.3	0.74	0.4	0.4	1.2	1.2
05/20/2025 10:00	4,391.2	1,543.9	5,935.1	105,000.0	623.2	0.75	0.4	0.4	1.2	1.2
05/20/2025 11:00	4,393.4	1,559.7	5,953.1	105,000.0	625.1	0.75	0.4	0.4	1.3	1.3
05/20/2025 12:00	4,379.0	1,597.9	5,976.9	105,000.0	627.6	0.75	0.4	0.4	1.3	1.3
05/20/2025 13:00	4,362.0	1,641.8	6,003.8	105,000.0	630.4	0.76	0.4	0.4	1.3	1.3
05/20/2025 14:00	4,351.7	1,651.1	6,002.8	105,000.0	630.3	0.76	0.4	0.4	1.3	1.3
05/20/2025 15:00	4,336.7	1,647.1	5,983.8	105,000.0	628.3	0.75	0.4	0.4	1.3	1.3
05/20/2025 16:00	4,331.9	905.5	5,174.0	105,000.0	543.3	0.66	0.3	0.3	1.1	1.1
05/20/2025 17:00	4,331.5	544.6	4,876.1	105,000.0	512.0	0.61	0.3	0.3	1.0	1.0
05/20/2025 18:00	4,325.1	1,137.2	5,462.3	105,000.0	573.5	0.69	0.3	0.3	1.1	1.1
05/20/2025 19:00	4,327.9	1,300.9	5,628.8	105,000.0	591.0	0.71	0.4	0.4	1.2	1.2
05/20/2025 20:00	4,352.6	916.8	5,150.2	105,000.0	540.8	0.66	0.3	0.3	1.1	1.1
05/20/2025 21:00	4,383.2	1,539.8	5,923.0	105,000.0	621.9	0.75	0.4	0.4	1.2	1.2
05/20/2025 22:00	4,387.7	228.2	4,586.2	105,000.0	481.6	0.58	0.3	0.3	1.0	1.0
05/20/2025 23:00	4,349.7	2.3	4,349.7	105,000.0	456.7	0.55	0.3	0.3	0.9	0.9
Average/Sum#:	4,376.1	996.4	5,361.0	105,000.0	562.9	0.68	0.4	0.4	1.1	1.1
Minimum:	4,304.2	0.0	4,304.2	105,000.0	451.9	0.54	0.3	0.3	0.9	0.9
Maximum:	4,475.8	1,651.1	6,003.8	105,000.0	630.4	0.76	0.4	0.4	1.3	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/21/2025 00:00	3,873.0	0.0	3,873.0	105,000.0	406.7	0.51	0.3	0.8
05/21/2025 01:00	1,507.8	0.0	1,507.8	105,000.0	158.3	0.00	0.0	0.0
05/21/2025 02:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/21/2025 03:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/21/2025 04:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/21/2025 05:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/21/2025 06:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/21/2025 07:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/21/2025 08:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/21/2025 09:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/21/2025 10:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/21/2025 11:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/21/2025 12:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/21/2025 13:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/21/2025 14:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/21/2025 15:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/21/2025 16:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/21/2025 17:00	779.8	0.0	779.8	105,000.0	81.9	0.00	0.0	0.0
05/21/2025 18:00	3,477.8	0.0	3,477.8	105,000.0	365.2	0.00	0.0	0.0
05/21/2025 19:00	4,180.4	0.0	4,180.4	105,000.0	438.9	0.53	0.3	0.9
05/21/2025 20:00	3,947.0	0.0	3,947.0	105,000.0	414.4	0.50	0.2	0.8
05/21/2025 21:00	3,597.7	0.0	3,597.7	105,000.0	377.8	0.45	0.2	0.8
05/21/2025 22:00	3,034.1	0.0	3,034.1	105,000.0	318.6	0.43	0.2	0.7
05/21/2025 23:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	3,049.7	0.0	3,049.7	105,000.0	320.2	0.48	0.2	0.8
Minimum:	779.8	0.0	779.8	105,000.0	81.9	0.43	0.2	0.7
Maximum:	4,180.4	0.0	4,180.4	105,000.0	438.9	0.53	0.3	0.9
%SI	66.67	66.67	66.67	0.00	66.67	79.17	79.17	79.17

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/22/2025 00:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/22/2025 01:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/22/2025 02:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/22/2025 03:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/22/2025 04:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/22/2025 05:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/22/2025 06:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/22/2025 07:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/22/2025 08:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/22/2025 09:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/22/2025 10:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/22/2025 11:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/22/2025 12:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/22/2025 13:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/22/2025 14:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/22/2025 15:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/22/2025 16:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/22/2025 17:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/22/2025 18:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/22/2025 19:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/22/2025 20:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/22/2025 21:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/22/2025 22:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/22/2025 23:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

Const. Value/Limit Tag:		> 4.73 > 1 > 1.8							
		Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	
		GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
		1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/23/2025 00:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/23/2025 01:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/23/2025 02:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/23/2025 03:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/23/2025 04:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/23/2025 05:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/23/2025 06:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/23/2025 07:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/23/2025 08:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/23/2025 09:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/23/2025 10:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/23/2025 11:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/23/2025 12:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/23/2025 13:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/23/2025 14:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/23/2025 15:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/23/2025 16:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/23/2025 17:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/23/2025 18:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/23/2025 19:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/23/2025 20:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/23/2025 21:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/23/2025 22:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/23/2025 23:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
Average/Sum#:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
Minimum:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
Maximum:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00	

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/24/2025 00:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/24/2025 01:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/24/2025 02:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/24/2025 03:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/24/2025 04:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/24/2025 05:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/24/2025 06:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/24/2025 07:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/24/2025 08:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/24/2025 09:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/24/2025 10:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/24/2025 11:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/24/2025 12:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/24/2025 13:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/24/2025 14:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/24/2025 15:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/24/2025 16:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/24/2025 17:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/24/2025 18:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/24/2025 19:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/24/2025 20:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/24/2025 21:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/24/2025 22:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
05/24/2025 23:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

Const. Value/Limit Tag:		> 4.73 > 1 > 1.8							
		Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	
		GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
		1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/25/2025 00:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/25/2025 01:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/25/2025 02:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/25/2025 03:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/25/2025 04:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/25/2025 05:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/25/2025 06:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/25/2025 07:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/25/2025 08:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/25/2025 09:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/25/2025 10:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/25/2025 11:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/25/2025 12:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/25/2025 13:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/25/2025 14:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/25/2025 15:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/25/2025 16:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/25/2025 17:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/25/2025 18:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/25/2025 19:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/25/2025 20:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/25/2025 21:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/25/2025 22:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/25/2025 23:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
Average/Sum#:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
Minimum:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
Maximum:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00	

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/26/2025 00:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/26/2025 01:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/26/2025 02:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/26/2025 03:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/26/2025 04:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/26/2025 05:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/26/2025 06:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/26/2025 07:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/26/2025 08:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/26/2025 09:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/26/2025 10:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/26/2025 11:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/26/2025 12:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/26/2025 13:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/26/2025 14:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/26/2025 15:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/26/2025 16:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/26/2025 17:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/26/2025 18:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/26/2025 19:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/26/2025 20:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/26/2025 21:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/26/2025 22:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/26/2025 23:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

Const. Value/Limit Tag:		> 4.73 > 1 > 1.8							
		Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	
		GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
		1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/27/2025 00:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/27/2025 01:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/27/2025 02:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/27/2025 03:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/27/2025 04:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/27/2025 05:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/27/2025 06:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/27/2025 07:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/27/2025 08:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/27/2025 09:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/27/2025 10:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/27/2025 11:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/27/2025 12:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/27/2025 13:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/27/2025 14:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/27/2025 15:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/27/2025 16:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/27/2025 17:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/27/2025 18:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/27/2025 19:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/27/2025 20:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/27/2025 21:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/27/2025 22:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
05/27/2025 23:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
Average/Sum#:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
Minimum:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
Maximum:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0	
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00	

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/28/2025 00:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/28/2025 01:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/28/2025 02:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/28/2025 03:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/28/2025 04:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/28/2025 05:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/28/2025 06:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/28/2025 07:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/28/2025 08:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/28/2025 09:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/28/2025 10:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/28/2025 11:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/28/2025 12:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/28/2025 13:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/28/2025 14:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/28/2025 15:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/28/2025 16:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/28/2025 17:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/28/2025 18:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/28/2025 19:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/28/2025 20:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/28/2025 21:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/28/2025 22:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/28/2025 23:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/29/2025 00:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/29/2025 01:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/29/2025 02:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/29/2025 03:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/29/2025 04:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/29/2025 05:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/29/2025 06:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/29/2025 07:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/29/2025 08:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/29/2025 09:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/29/2025 10:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/29/2025 11:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/29/2025 12:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/29/2025 13:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/29/2025 14:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/29/2025 15:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/29/2025 16:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/29/2025 17:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/29/2025 18:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/29/2025 19:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/29/2025 20:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/29/2025 21:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/29/2025 22:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/29/2025 23:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/30/2025 00:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/30/2025 01:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/30/2025 02:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/30/2025 03:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/30/2025 04:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/30/2025 05:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/30/2025 06:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/30/2025 07:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/30/2025 08:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/30/2025 09:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/30/2025 10:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/30/2025 11:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/30/2025 12:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/30/2025 13:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/30/2025 14:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/30/2025 15:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/30/2025 16:00	2,070.9	0.0	2,070.9	105,000.0	217.4	0.00	0.0	0.0
05/30/2025 17:00	3,493.6	0.0	3,493.6	105,000.0	366.8	0.44	0.2	0.7
05/30/2025 18:00	3,958.3	0.0	3,958.3	105,000.0	415.6	0.50	0.2	0.8
05/30/2025 19:00	3,973.7	0.0	3,973.7	105,000.0	417.2	0.50	0.3	0.8
05/30/2025 20:00	4,212.4	0.0	4,212.4	105,000.0	442.3	0.53	0.3	0.9
05/30/2025 21:00	4,221.6	0.0	4,221.6	105,000.0	443.3	0.53	0.3	0.9
05/30/2025 22:00	3,933.9	0.0	3,933.9	105,000.0	413.1	0.49	0.2	0.8
05/30/2025 23:00	3,915.4	0.0	3,915.4	105,000.0	411.1	0.50	0.2	0.8
Average/Sum#:	3,722.5	0.0	3,722.5	105,000.0	390.9	0.50	0.2	0.8
Minimum:	2,070.9	0.0	2,070.9	105,000.0	217.4	0.44	0.2	0.7
Maximum:	4,221.6	0.0	4,221.6	105,000.0	443.3	0.53	0.3	0.9
%SI	66.67	66.67	66.67	0.00	66.67	70.83	70.83	70.83

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

Const. Value/Limit Tag:		> 4.73 > 1 > 1.8							
		Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
		GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
		1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/31/2025	00:00	3,548.2	0.0	3,548.2	105,000.0	372.6	0.45	0.2	0.7
05/31/2025	01:00	3,492.9	0.0	3,492.9	105,000.0	366.8	0.45	0.2	0.8
05/31/2025	02:00	1,522.2	0.0	1,522.2	105,000.0	159.8	0.00	0.0	0.0
05/31/2025	03:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/31/2025	04:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/31/2025	05:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/31/2025	06:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/31/2025	07:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/31/2025	08:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/31/2025	09:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/31/2025	10:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/31/2025	11:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/31/2025	12:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/31/2025	13:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/31/2025	14:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/31/2025	15:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/31/2025	16:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/31/2025	17:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/31/2025	18:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/31/2025	19:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/31/2025	20:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/31/2025	21:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/31/2025	22:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
05/31/2025	23:00	0.0	0.0	0.0	105,000.0	0.0	0.00	0.0	0.0
Average/Sum#:		2,854.4	0.0	2,854.4	105,000.0	299.7	0.45	0.2	0.8
Minimum:		1,522.2	0.0	1,522.2	105,000.0	159.8	0.45	0.2	0.7
Maximum:		3,548.2	0.0	3,548.2	105,000.0	372.6	0.45	0.2	0.8
%SI		87.50	87.50	87.50	0.00	87.50	91.67	91.67	91.67

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1		Unit CT1		Unit CT1		Unit CT1		Unit CT1		Unit CT1		Unit CT1		Unit CT1		Unit CT1	
	GasFlow, _CT, 100scfh		GasFlow, _DB, 100scfh		GasFlowTotal, 100scfh		GCVGas, BtuPer100scf		HI, MBtuPerHr		> 4.73 PM10_Norm, LbPerHr		> 1 SO2_Norm, LbPerHr		> 1.8 VOC_Norm, LbPerHr			
	1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)	
06/01/2025 00:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/01/2025 01:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/01/2025 02:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/01/2025 03:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/01/2025 04:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/01/2025 05:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/01/2025 06:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/01/2025 07:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/01/2025 08:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/01/2025 09:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/01/2025 10:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/01/2025 11:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/01/2025 12:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/01/2025 13:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/01/2025 14:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/01/2025 15:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/01/2025 16:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/01/2025 17:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/01/2025 18:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/01/2025 19:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/01/2025 20:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/01/2025 21:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/01/2025 22:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/01/2025 23:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
Average/Sum#:	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
Minimum:	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
Maximum:	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
%SI	100.00		100.00		100.00		0.00		100.00		100.00		100.00		100.00		100.00	

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

Const. Value/Limit Tag:		Unit CT1							
		Unit CT1		Unit CT1		Unit CT1		Unit CT1	
		GasFlow, _CT, 100scfh		GasFlow, _DB, 100scfh		GasFlowTotal, 100scfh		GCVGas, BtuPer100scf	
		HI, MBtuPerHr		PM10_Norm, LbPerHr		SO2_Norm, LbPerHr		VOC_Norm, LbPerHr	
		1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/02/2025	00:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/02/2025	01:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/02/2025	02:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/02/2025	03:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/02/2025	04:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/02/2025	05:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/02/2025	06:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/02/2025	07:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/02/2025	08:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/02/2025	09:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/02/2025	10:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/02/2025	11:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/02/2025	12:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/02/2025	13:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/02/2025	14:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/02/2025	15:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/02/2025	16:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/02/2025	17:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/02/2025	18:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/02/2025	19:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/02/2025	20:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/02/2025	21:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/02/2025	22:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/02/2025	23:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
Average/Sum#:		0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
Minimum:		0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
Maximum:		0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
%SI		100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)		1 Hour(s)	1 Hour(s)
06/03/2025 00:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
06/03/2025 01:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
06/03/2025 02:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
06/03/2025 03:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
06/03/2025 04:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
06/03/2025 05:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
06/03/2025 06:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
06/03/2025 07:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
06/03/2025 08:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
06/03/2025 09:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
06/03/2025 10:00	1,085.0	0.0	1,085.0	104,900.0	113.8	0.00	0.0	0.0		0.0	0.0
06/03/2025 11:00	3,568.4	0.0	3,568.4	104,900.0	374.3	0.44	0.2	0.7		0.7	0.7
06/03/2025 12:00	3,524.5	0.0	3,524.5	104,900.0	369.7	0.45	0.2	0.7		0.7	0.7
06/03/2025 13:00	4,269.4	0.0	4,269.4	104,900.0	447.9	0.54	0.3	0.9		0.9	0.9
06/03/2025 14:00	4,153.8	0.0	4,153.8	104,900.0	435.7	0.52	0.3	0.9		0.9	0.9
06/03/2025 15:00	3,907.2	0.0	3,907.2	104,900.0	409.9	0.52	0.3	0.9		0.9	0.9
06/03/2025 16:00	1,276.3	0.0	1,276.3	104,900.0	133.9	0.00	0.0	0.0		0.0	0.0
06/03/2025 17:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
06/03/2025 18:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
06/03/2025 19:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
06/03/2025 20:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
06/03/2025 21:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
06/03/2025 22:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
06/03/2025 23:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
Average/Sum#:	3,112.1	0.0	3,112.1	104,900.0	326.5	0.49	0.3	0.8		0.8	0.8
Minimum:	1,085.0	0.0	1,085.0	104,900.0	113.8	0.44	0.2	0.7		0.7	0.7
Maximum:	4,269.4	0.0	4,269.4	104,900.0	447.9	0.54	0.3	0.9		0.9	0.9
%SI	70.83	70.83	70.83	0.00	70.83	79.17	79.17	79.17		79.17	79.17

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1		Unit CT1		Unit CT1		Unit CT1		Unit CT1		Unit CT1		Unit CT1		Unit CT1		Unit CT1	
	GasFlow, _CT, 100scfh		GasFlow, _DB, 100scfh		GasFlowTotal, 100scfh		GCVGas, BtuPer100scf		HI, MBtuPerHr		> 4.73 PM10_Norm, LbPerHr		> 1 SO2_Norm, LbPerHr		> 1.8 VOC_Norm, LbPerHr			
	1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)	
06/04/2025 00:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/04/2025 01:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/04/2025 02:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/04/2025 03:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/04/2025 04:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/04/2025 05:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/04/2025 06:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/04/2025 07:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/04/2025 08:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/04/2025 09:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/04/2025 10:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/04/2025 11:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/04/2025 12:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/04/2025 13:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/04/2025 14:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/04/2025 15:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/04/2025 16:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/04/2025 17:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/04/2025 18:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/04/2025 19:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/04/2025 20:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/04/2025 21:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/04/2025 22:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
06/04/2025 23:00	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
Average/Sum#:	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
Minimum:	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
Maximum:	0.0		0.0		0.0		104,900.0		0.0		0.00		0.0		0.0		0.0	
%SI	100.00		100.00		100.00		0.00		100.00		100.00		100.00		100.00		100.00	

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)		1 Hour(s)	1 Hour(s)
06/05/2025 00:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
06/05/2025 01:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
06/05/2025 02:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
06/05/2025 03:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
06/05/2025 04:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
06/05/2025 05:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
06/05/2025 06:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
06/05/2025 07:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
06/05/2025 08:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
06/05/2025 09:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
06/05/2025 10:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
06/05/2025 11:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
06/05/2025 12:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
06/05/2025 13:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
06/05/2025 14:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
06/05/2025 15:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
06/05/2025 16:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
06/05/2025 17:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
06/05/2025 18:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
06/05/2025 19:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
06/05/2025 20:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
06/05/2025 21:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
06/05/2025 22:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
06/05/2025 23:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
Minimum:	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
Maximum:	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0		0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00		100.00	100.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/06/2025 00:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/06/2025 01:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/06/2025 02:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/06/2025 03:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/06/2025 04:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/06/2025 05:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/06/2025 06:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/06/2025 07:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/06/2025 08:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/06/2025 09:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/06/2025 10:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/06/2025 11:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/06/2025 12:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/06/2025 13:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/06/2025 14:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/06/2025 15:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/06/2025 16:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/06/2025 17:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/06/2025 18:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/06/2025 19:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/06/2025 20:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/06/2025 21:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/06/2025 22:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/06/2025 23:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/07/2025 00:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/07/2025 01:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/07/2025 02:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/07/2025 03:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/07/2025 04:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/07/2025 05:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/07/2025 06:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/07/2025 07:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/07/2025 08:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/07/2025 09:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/07/2025 10:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/07/2025 11:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/07/2025 12:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/07/2025 13:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/07/2025 14:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/07/2025 15:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/07/2025 16:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/07/2025 17:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/07/2025 18:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/07/2025 19:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/07/2025 20:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/07/2025 21:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/07/2025 22:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/07/2025 23:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/08/2025 00:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/08/2025 01:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/08/2025 02:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/08/2025 03:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/08/2025 04:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/08/2025 05:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/08/2025 06:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/08/2025 07:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/08/2025 08:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/08/2025 09:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/08/2025 10:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/08/2025 11:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/08/2025 12:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/08/2025 13:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/08/2025 14:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/08/2025 15:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/08/2025 16:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/08/2025 17:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/08/2025 18:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/08/2025 19:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/08/2025 20:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/08/2025 21:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/08/2025 22:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/08/2025 23:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/09/2025 00:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/09/2025 01:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/09/2025 02:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/09/2025 03:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/09/2025 04:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/09/2025 05:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/09/2025 06:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/09/2025 07:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/09/2025 08:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/09/2025 09:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/09/2025 10:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/09/2025 11:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/09/2025 12:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/09/2025 13:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/09/2025 14:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/09/2025 15:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/09/2025 16:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	0.0	0.0	0.0
06/09/2025 17:00	2,953.0	0.0	2,953.0	104,900.0	309.8	0.00	0.0	0.0	0.0	0.0	0.0
06/09/2025 18:00	4,186.4	115.1	4,257.8	104,900.0	446.6	0.55	0.3	0.9	0.55	0.3	0.9
06/09/2025 19:00	4,277.6	1,496.5	5,774.1	104,900.0	605.7	0.73	0.4	1.2	0.73	0.4	1.2
06/09/2025 20:00	4,311.7	502.1	4,698.3	104,900.0	492.9	0.61	0.3	1.0	0.61	0.3	1.0
06/09/2025 21:00	3,618.1	0.0	3,618.1	104,900.0	379.5	0.46	0.2	0.8	0.46	0.2	0.8
06/09/2025 22:00	3,486.5	0.0	3,486.5	104,900.0	365.7	0.44	0.2	0.7	0.44	0.2	0.7
06/09/2025 23:00	3,633.3	0.0	3,633.3	104,900.0	381.1	0.46	0.2	0.8	0.46	0.2	0.8
Average/Sum#:	3,780.9	302.0	4,060.2	104,900.0	425.9	0.54	0.3	0.9	0.54	0.3	0.9
Minimum:	2,953.0	0.0	2,953.0	104,900.0	309.8	0.44	0.2	0.7	0.44	0.2	0.7
Maximum:	4,311.7	1,496.5	5,774.1	104,900.0	605.7	0.73	0.4	1.2	0.73	0.4	1.2
%SI	70.83	70.83	70.83	0.00	70.83	75.00	75.00	75.00	75.00	75.00	75.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/10/2025 00:00	3,484.1	0.0	3,484.1	104,900.0	365.5	0.44	0.2	0.7			
06/10/2025 01:00	3,486.5	0.0	3,486.5	104,900.0	365.7	0.44	0.2	0.7			
06/10/2025 02:00	3,486.5	0.0	3,486.5	104,900.0	365.7	0.44	0.2	0.7			
06/10/2025 03:00	3,487.2	0.0	3,487.2	104,900.0	365.8	0.44	0.2	0.7			
06/10/2025 04:00	3,614.9	0.0	3,614.9	104,900.0	379.2	0.46	0.2	0.8			
06/10/2025 05:00	3,641.3	0.0	3,641.3	104,900.0	382.0	0.46	0.2	0.8			
06/10/2025 06:00	3,492.2	0.0	3,492.2	104,900.0	366.3	0.44	0.2	0.7			
06/10/2025 07:00	3,501.5	0.0	3,501.5	104,900.0	367.3	0.44	0.2	0.7			
06/10/2025 08:00	3,497.1	0.0	3,497.1	104,900.0	366.8	0.44	0.2	0.7			
06/10/2025 09:00	3,488.1	0.0	3,488.1	104,900.0	365.9	0.44	0.2	0.7			
06/10/2025 10:00	3,477.2	0.0	3,477.2	104,900.0	364.8	0.44	0.2	0.7			
06/10/2025 11:00	3,486.8	0.0	3,486.8	104,900.0	365.8	0.44	0.2	0.7			
06/10/2025 12:00	3,494.8	0.0	3,494.8	104,900.0	366.6	0.44	0.2	0.7			
06/10/2025 13:00	3,497.5	0.0	3,497.5	104,900.0	366.9	0.44	0.2	0.7			
06/10/2025 14:00	3,490.3	0.0	3,490.3	104,900.0	366.1	0.44	0.2	0.7			
06/10/2025 15:00	3,743.3	0.0	3,743.3	104,900.0	392.7	0.47	0.2	0.8			
06/10/2025 16:00	3,849.7	0.0	3,849.7	104,900.0	403.8	0.48	0.2	0.8			
06/10/2025 17:00	3,854.6	0.0	3,854.6	104,900.0	404.3	0.48	0.2	0.8			
06/10/2025 18:00	4,247.9	0.0	4,247.9	104,900.0	445.6	0.54	0.3	0.9			
06/10/2025 19:00	3,569.9	0.0	3,569.9	104,900.0	374.5	0.45	0.2	0.8			
06/10/2025 20:00	3,467.5	0.0	3,467.5	104,900.0	363.7	0.44	0.2	0.7			
06/10/2025 21:00	3,463.0	0.0	3,463.0	104,900.0	363.3	0.44	0.2	0.7			
06/10/2025 22:00	3,466.7	0.0	3,466.7	104,900.0	363.7	0.44	0.2	0.7			
06/10/2025 23:00	3,478.5	0.0	3,478.5	104,900.0	364.9	0.44	0.2	0.7			
Average/Sum#:	3,573.6	0.0	3,573.6	104,900.0	374.9	0.45	0.2	0.7			
Minimum:	3,463.0	0.0	3,463.0	104,900.0	363.3	0.44	0.2	0.7			
Maximum:	4,247.9	0.0	4,247.9	104,900.0	445.6	0.54	0.3	0.9			
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/11/2025 00:00	3,495.3	0.0	3,495.3	104,900.0	366.7	0.44	0.2	0.2	0.7	0.7
06/11/2025 01:00	3,499.1	0.0	3,499.1	104,900.0	367.1	0.44	0.2	0.2	0.7	0.7
06/11/2025 02:00	3,500.2	0.0	3,500.2	104,900.0	367.2	0.44	0.2	0.2	0.7	0.7
06/11/2025 03:00	3,506.2	0.0	3,506.2	104,900.0	367.8	0.44	0.2	0.2	0.7	0.7
06/11/2025 04:00	3,497.0	0.0	3,497.0	104,900.0	366.8	0.44	0.2	0.2	0.7	0.7
06/11/2025 05:00	3,484.8	0.0	3,484.8	104,900.0	365.6	0.44	0.2	0.2	0.7	0.7
06/11/2025 06:00	3,483.0	0.0	3,483.0	104,900.0	365.4	0.44	0.2	0.2	0.7	0.7
06/11/2025 07:00	3,489.1	0.0	3,489.1	104,900.0	366.0	0.44	0.2	0.2	0.7	0.7
06/11/2025 08:00	3,492.4	0.0	3,492.4	104,900.0	366.4	0.44	0.2	0.2	0.7	0.7
06/11/2025 09:00	3,490.5	0.0	3,490.5	104,900.0	366.2	0.44	0.2	0.2	0.7	0.7
06/11/2025 10:00	3,486.4	0.0	3,486.4	104,900.0	365.7	0.44	0.2	0.2	0.7	0.7
06/11/2025 11:00	3,484.1	0.0	3,484.1	104,900.0	365.5	0.44	0.2	0.2	0.7	0.7
06/11/2025 12:00	3,484.8	0.0	3,484.8	104,900.0	365.6	0.44	0.2	0.2	0.7	0.7
06/11/2025 13:00	3,480.3	0.0	3,480.3	104,900.0	365.1	0.44	0.2	0.2	0.7	0.7
06/11/2025 14:00	3,458.3	0.0	3,458.3	104,900.0	362.8	0.44	0.2	0.2	0.7	0.7
06/11/2025 15:00	3,452.8	0.0	3,452.8	104,900.0	362.2	0.43	0.2	0.2	0.7	0.7
06/11/2025 16:00	3,452.0	0.0	3,452.0	104,900.0	362.1	0.44	0.2	0.2	0.7	0.7
06/11/2025 17:00	3,453.0	0.0	3,453.0	104,900.0	362.2	0.44	0.2	0.2	0.7	0.7
06/11/2025 18:00	3,450.0	0.0	3,450.0	104,900.0	361.9	0.43	0.2	0.2	0.7	0.7
06/11/2025 19:00	3,671.5	0.0	3,671.5	104,900.0	385.1	0.46	0.2	0.2	0.8	0.8
06/11/2025 20:00	3,538.1	0.0	3,538.1	104,900.0	371.1	0.45	0.2	0.2	0.7	0.7
06/11/2025 21:00	3,535.1	0.0	3,535.1	104,900.0	370.8	0.45	0.2	0.2	0.7	0.7
06/11/2025 22:00	3,551.7	0.0	3,551.7	104,900.0	372.6	0.45	0.2	0.2	0.7	0.7
06/11/2025 23:00	3,555.1	0.0	3,555.1	104,900.0	372.9	0.45	0.2	0.2	0.7	0.7
Average/Sum#:	3,499.6	0.0	3,499.6	104,900.0	367.1	0.44	0.2	0.2	0.7	0.7
Minimum:	3,450.0	0.0	3,450.0	104,900.0	361.9	0.43	0.2	0.2	0.7	0.7
Maximum:	3,671.5	0.0	3,671.5	104,900.0	385.1	0.46	0.2	0.2	0.8	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/12/2025 00:00	3,547.5	0.0	3,547.5	104,900.0	372.1	0.45	0.2	0.7			
06/12/2025 01:00	3,535.8	0.0	3,535.8	104,900.0	370.9	0.45	0.2	0.7			
06/12/2025 02:00	3,550.0	0.0	3,550.0	104,900.0	372.4	0.45	0.2	0.7			
06/12/2025 03:00	3,553.5	0.0	3,553.5	104,900.0	372.8	0.45	0.2	0.7			
06/12/2025 04:00	3,550.1	0.0	3,550.1	104,900.0	372.4	0.45	0.2	0.7			
06/12/2025 05:00	3,551.5	0.0	3,551.5	104,900.0	372.6	0.45	0.2	0.7			
06/12/2025 06:00	3,549.2	0.0	3,549.2	104,900.0	372.3	0.45	0.2	0.7			
06/12/2025 07:00	3,550.8	0.0	3,550.8	104,900.0	372.5	0.45	0.2	0.7			
06/12/2025 08:00	3,561.2	0.0	3,561.2	104,900.0	373.6	0.45	0.2	0.7			
06/12/2025 09:00	3,567.3	0.0	3,567.3	104,900.0	374.2	0.45	0.2	0.7			
06/12/2025 10:00	3,556.7	0.0	3,556.7	104,900.0	373.1	0.45	0.2	0.7			
06/12/2025 11:00	3,545.2	0.0	3,545.2	104,900.0	371.9	0.45	0.2	0.7			
06/12/2025 12:00	3,550.2	0.0	3,550.2	104,900.0	372.4	0.45	0.2	0.7			
06/12/2025 13:00	3,550.0	0.0	3,550.0	104,900.0	372.4	0.45	0.2	0.7			
06/12/2025 14:00	3,535.5	0.0	3,535.5	104,900.0	370.9	0.44	0.2	0.7			
06/12/2025 15:00	3,530.0	0.0	3,530.0	104,900.0	370.3	0.44	0.2	0.7			
06/12/2025 16:00	3,542.4	0.0	3,542.4	104,900.0	371.6	0.45	0.2	0.7			
06/12/2025 17:00	3,576.8	0.0	3,576.8	104,900.0	375.2	0.45	0.2	0.8			
06/12/2025 18:00	3,499.5	0.0	3,499.5	104,900.0	367.1	0.44	0.2	0.7			
06/12/2025 19:00	3,483.9	0.0	3,483.9	104,900.0	365.5	0.44	0.2	0.7			
06/12/2025 20:00	3,497.6	0.0	3,497.6	104,900.0	366.9	0.44	0.2	0.7			
06/12/2025 21:00	3,504.1	0.0	3,504.1	104,900.0	367.6	0.44	0.2	0.7			
06/12/2025 22:00	3,528.6	0.0	3,528.6	104,900.0	370.2	0.44	0.2	0.7			
06/12/2025 23:00	4,087.4	0.0	4,087.4	104,900.0	428.8	0.51	0.3	0.9			
Average/Sum#:	3,562.7	0.0	3,562.7	104,900.0	373.7	0.45	0.2	0.7			
Minimum:	3,483.9	0.0	3,483.9	104,900.0	365.5	0.44	0.2	0.7			
Maximum:	4,087.4	0.0	4,087.4	104,900.0	428.8	0.51	0.3	0.9			
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/13/2025 00:00	3,657.5	0.0	3,657.5	104,900.0	383.7	0.46	0.2	0.8
06/13/2025 01:00	3,533.4	0.0	3,533.4	104,900.0	370.7	0.44	0.2	0.7
06/13/2025 02:00	3,532.3	0.0	3,532.3	104,900.0	370.5	0.44	0.2	0.7
06/13/2025 03:00	3,533.4	0.0	3,533.4	104,900.0	370.7	0.45	0.2	0.7
06/13/2025 04:00	3,533.1	0.0	3,533.1	104,900.0	370.6	0.44	0.2	0.7
06/13/2025 05:00	3,533.7	0.0	3,533.7	104,900.0	370.7	0.44	0.2	0.7
06/13/2025 06:00	3,545.5	0.0	3,545.5	104,900.0	371.9	0.45	0.2	0.7
06/13/2025 07:00	3,564.6	0.0	3,564.6	104,900.0	373.9	0.45	0.2	0.7
06/13/2025 08:00	3,578.0	0.0	3,578.0	104,900.0	375.3	0.45	0.2	0.8
06/13/2025 09:00	3,565.6	0.0	3,565.6	104,900.0	374.0	0.45	0.2	0.7
06/13/2025 10:00	3,550.8	0.0	3,550.8	104,900.0	372.5	0.45	0.2	0.7
06/13/2025 11:00	3,571.2	0.0	3,571.2	104,900.0	374.6	0.45	0.2	0.7
06/13/2025 12:00	3,562.4	0.0	3,562.4	104,900.0	373.7	0.45	0.2	0.7
06/13/2025 13:00	3,547.9	0.0	3,547.9	104,900.0	372.2	0.45	0.2	0.7
06/13/2025 14:00	3,549.2	0.0	3,549.2	104,900.0	372.3	0.45	0.2	0.7
06/13/2025 15:00	3,547.2	0.0	3,547.2	104,900.0	372.1	0.45	0.2	0.7
06/13/2025 16:00	3,547.9	0.0	3,547.9	104,900.0	372.2	0.45	0.2	0.7
06/13/2025 17:00	3,545.3	0.0	3,545.3	104,900.0	371.9	0.45	0.2	0.7
06/13/2025 18:00	3,543.6	0.0	3,543.6	104,900.0	371.7	0.45	0.2	0.7
06/13/2025 19:00	3,534.6	0.0	3,534.6	104,900.0	370.8	0.45	0.2	0.7
06/13/2025 20:00	3,531.2	0.0	3,531.2	104,900.0	370.4	0.44	0.2	0.7
06/13/2025 21:00	3,532.0	0.0	3,532.0	104,900.0	370.5	0.45	0.2	0.7
06/13/2025 22:00	3,560.3	0.0	3,560.3	104,900.0	373.5	0.45	0.2	0.7
06/13/2025 23:00	3,561.2	0.0	3,561.2	104,900.0	373.6	0.45	0.2	0.7
Average/Sum#:	3,552.6	0.0	3,552.6	104,900.0	372.7	0.45	0.2	0.7
Minimum:	3,531.2	0.0	3,531.2	104,900.0	370.4	0.44	0.2	0.7
Maximum:	3,657.5	0.0	3,657.5	104,900.0	383.7	0.46	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/14/2025 00:00	3,562.9	0.0	3,562.9	104,900.0	373.7	0.45	0.2	0.7			
06/14/2025 01:00	3,564.2	0.0	3,564.2	104,900.0	373.9	0.45	0.2	0.7			
06/14/2025 02:00	3,558.8	0.0	3,558.8	104,900.0	373.3	0.45	0.2	0.7			
06/14/2025 03:00	3,558.6	0.0	3,558.6	104,900.0	373.3	0.45	0.2	0.7			
06/14/2025 04:00	3,560.9	0.0	3,560.9	104,900.0	373.5	0.45	0.2	0.7			
06/14/2025 05:00	3,557.5	0.0	3,557.5	104,900.0	373.2	0.45	0.2	0.7			
06/14/2025 06:00	3,552.0	0.0	3,552.0	104,900.0	372.6	0.45	0.2	0.7			
06/14/2025 07:00	3,551.3	0.0	3,551.3	104,900.0	372.5	0.45	0.2	0.7			
06/14/2025 08:00	3,549.6	0.0	3,549.6	104,900.0	372.4	0.45	0.2	0.7			
06/14/2025 09:00	3,558.7	0.0	3,558.7	104,900.0	373.3	0.45	0.2	0.7			
06/14/2025 10:00	3,554.1	0.0	3,554.1	104,900.0	372.8	0.45	0.2	0.7			
06/14/2025 11:00	3,540.3	0.0	3,540.3	104,900.0	371.4	0.45	0.2	0.7			
06/14/2025 12:00	3,541.3	0.0	3,541.3	104,900.0	371.5	0.45	0.2	0.7			
06/14/2025 13:00	3,543.9	0.0	3,543.9	104,900.0	371.8	0.45	0.2	0.7			
06/14/2025 14:00	3,764.1	0.0	3,764.1	104,900.0	394.9	0.47	0.2	0.8			
06/14/2025 15:00	3,511.6	0.0	3,511.6	104,900.0	368.4	0.44	0.2	0.7			
06/14/2025 16:00	3,519.5	0.0	3,519.5	104,900.0	369.2	0.44	0.2	0.7			
06/14/2025 17:00	3,761.6	0.0	3,761.6	104,900.0	394.6	0.47	0.2	0.8			
06/14/2025 18:00	4,308.2	707.6	5,015.8	104,900.0	526.2	0.63	0.3	1.1			
06/14/2025 19:00	4,333.3	736.9	5,070.2	104,900.0	531.9	0.64	0.3	1.1			
06/14/2025 20:00	4,358.6	702.6	5,061.2	104,900.0	530.9	0.64	0.3	1.1			
06/14/2025 21:00	4,374.1	372.9	4,586.7	104,900.0	481.1	0.60	0.3	1.0			
06/14/2025 22:00	4,390.8	595.8	4,944.9	104,900.0	518.7	0.63	0.3	1.0			
06/14/2025 23:00	4,403.0	625.3	5,028.3	104,900.0	527.5	0.63	0.3	1.1			
Average/Sum#:	3,770.0	155.9	3,917.4	104,900.0	410.9	0.50	0.2	0.8			
Minimum:	3,511.6	0.0	3,511.6	104,900.0	368.4	0.44	0.2	0.7			
Maximum:	4,403.0	736.9	5,070.2	104,900.0	531.9	0.64	0.3	1.1			
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/15/2025 00:00	4,414.4	596.1	5,010.5	104,900.0	525.6	0.63	0.3	0.3	1.1	1.1
06/15/2025 01:00	4,423.5	604.1	5,027.6	104,900.0	527.4	0.63	0.3	0.3	1.1	1.1
06/15/2025 02:00	4,435.4	616.1	5,051.5	104,900.0	529.9	0.64	0.3	0.3	1.1	1.1
06/15/2025 03:00	4,446.9	609.8	5,056.7	104,900.0	530.4	0.64	0.3	0.3	1.1	1.1
06/15/2025 04:00	4,448.7	608.1	5,056.8	104,900.0	530.5	0.64	0.3	0.3	1.1	1.1
06/15/2025 05:00	3,949.3	146.5	3,990.3	104,900.0	418.6	0.52	0.3	0.3	0.9	0.9
06/15/2025 06:00	3,558.8	0.0	3,558.8	104,900.0	373.3	0.45	0.2	0.2	0.7	0.7
06/15/2025 07:00	3,564.9	0.0	3,564.9	104,900.0	374.0	0.45	0.2	0.2	0.7	0.7
06/15/2025 08:00	3,570.8	0.0	3,570.8	104,900.0	374.6	0.45	0.2	0.2	0.7	0.7
06/15/2025 09:00	3,585.0	0.0	3,585.0	104,900.0	376.1	0.45	0.2	0.2	0.8	0.8
06/15/2025 10:00	3,575.2	0.0	3,575.2	104,900.0	375.0	0.45	0.2	0.2	0.8	0.8
06/15/2025 11:00	3,563.0	0.0	3,563.0	104,900.0	373.8	0.45	0.2	0.2	0.7	0.7
06/15/2025 12:00	3,571.3	0.0	3,571.3	104,900.0	374.6	0.45	0.2	0.2	0.7	0.7
06/15/2025 13:00	3,580.5	0.0	3,580.5	104,900.0	375.6	0.45	0.2	0.2	0.8	0.8
06/15/2025 14:00	3,578.8	0.0	3,578.8	104,900.0	375.4	0.45	0.2	0.2	0.8	0.8
06/15/2025 15:00	3,580.9	0.0	3,580.9	104,900.0	375.6	0.45	0.2	0.2	0.8	0.8
06/15/2025 16:00	3,969.4	190.9	4,022.9	104,900.0	422.0	0.52	0.3	0.3	0.9	0.9
06/15/2025 17:00	4,287.1	1,112.9	5,400.0	104,900.0	566.5	0.68	0.3	0.3	1.1	1.1
06/15/2025 18:00	4,293.8	1,348.5	5,642.3	104,900.0	591.9	0.71	0.4	0.4	1.2	1.2
06/15/2025 19:00	4,325.7	937.4	5,263.1	104,900.0	552.1	0.66	0.3	0.3	1.1	1.1
06/15/2025 20:00	4,348.3	906.8	5,255.1	104,900.0	551.3	0.66	0.3	0.3	1.1	1.1
06/15/2025 21:00	4,370.9	800.6	5,171.5	104,900.0	542.5	0.65	0.3	0.3	1.1	1.1
06/15/2025 22:00	4,387.8	684.7	5,072.5	104,900.0	532.1	0.64	0.3	0.3	1.1	1.1
06/15/2025 23:00	4,413.2	675.4	5,088.6	104,900.0	533.8	0.64	0.3	0.3	1.1	1.1
Average/Sum#:	4,010.2	409.9	4,409.9	104,900.0	462.6	0.56	0.3	0.3	0.9	0.9
Minimum:	3,558.8	0.0	3,558.8	104,900.0	373.3	0.45	0.2	0.2	0.7	0.7
Maximum:	4,448.7	1,348.5	5,642.3	104,900.0	591.9	0.71	0.4	0.4	1.2	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/16/2025 00:00	4,431.4	636.4	5,067.8	104,900.0	531.6	0.64	0.3	1.1
06/16/2025 01:00	4,396.7	719.4	5,116.1	104,900.0	536.7	0.64	0.3	1.1
06/16/2025 02:00	4,409.8	710.8	5,120.6	104,900.0	537.2	0.64	0.3	1.1
06/16/2025 03:00	4,417.6	691.5	5,109.1	104,900.0	535.9	0.64	0.3	1.1
06/16/2025 04:00	4,432.5	662.1	5,094.6	104,900.0	534.4	0.64	0.3	1.1
06/16/2025 05:00	4,177.5	320.7	4,347.5	104,900.0	456.1	0.57	0.3	0.9
06/16/2025 06:00	3,570.8	0.0	3,570.8	104,900.0	374.6	0.45	0.2	0.7
06/16/2025 07:00	3,575.3	0.0	3,575.3	104,900.0	375.0	0.45	0.2	0.8
06/16/2025 08:00	3,575.8	0.0	3,575.8	104,900.0	375.1	0.45	0.2	0.7
06/16/2025 09:00	3,580.2	0.0	3,580.2	104,900.0	375.6	0.45	0.2	0.8
06/16/2025 10:00	3,584.0	0.0	3,584.0	104,900.0	376.0	0.45	0.2	0.8
06/16/2025 11:00	3,573.4	0.0	3,573.4	104,900.0	374.8	0.45	0.2	0.7
06/16/2025 12:00	3,578.2	0.0	3,578.2	104,900.0	375.4	0.45	0.2	0.8
06/16/2025 13:00	3,578.6	0.0	3,578.6	104,900.0	375.4	0.45	0.2	0.8
06/16/2025 14:00	3,567.1	0.0	3,567.1	104,900.0	374.2	0.45	0.2	0.7
06/16/2025 15:00	3,959.2	199.7	4,015.1	104,900.0	421.2	0.52	0.3	0.9
06/16/2025 16:00	4,279.3	866.4	5,145.7	104,900.0	539.8	0.65	0.3	1.1
06/16/2025 17:00	4,292.0	867.5	5,159.5	104,900.0	541.2	0.65	0.3	1.1
06/16/2025 18:00	4,306.9	938.5	5,245.4	104,900.0	550.2	0.66	0.3	1.1
06/16/2025 19:00	4,336.3	943.6	5,279.9	104,900.0	553.9	0.66	0.3	1.1
06/16/2025 20:00	4,355.2	939.4	5,294.6	104,900.0	555.4	0.67	0.3	1.1
06/16/2025 21:00	4,381.8	721.8	5,103.6	104,900.0	535.4	0.64	0.3	1.1
06/16/2025 22:00	4,405.8	680.4	5,086.2	104,900.0	533.5	0.64	0.3	1.1
06/16/2025 23:00	4,427.0	885.3	5,312.3	104,900.0	557.3	0.67	0.3	1.1
Average/Sum#:	4,049.7	449.3	4,486.7	104,900.0	470.7	0.57	0.3	1.0
Minimum:	3,567.1	0.0	3,567.1	104,900.0	374.2	0.45	0.2	0.7
Maximum:	4,432.5	943.6	5,312.3	104,900.0	557.3	0.67	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/17/2025 00:00	4,433.5	636.4	5,069.9	104,900.0	531.8	0.64	0.3		1.1	
06/17/2025 01:00	4,445.3	610.4	5,055.7	104,900.0	530.3	0.64	0.3		1.1	
06/17/2025 02:00	4,459.4	631.4	5,090.8	104,900.0	534.0	0.64	0.3		1.1	
06/17/2025 03:00	4,466.2	631.5	5,097.7	104,900.0	534.7	0.64	0.3		1.1	
06/17/2025 04:00	4,470.1	641.8	5,111.9	104,900.0	536.2	0.64	0.3		1.1	
06/17/2025 05:00	4,437.6	502.0	4,849.2	104,900.0	508.7	0.62	0.3		1.0	
06/17/2025 06:00	3,631.0	0.0	3,631.0	104,900.0	380.9	0.46	0.2		0.8	
06/17/2025 07:00	3,576.1	0.0	3,576.1	104,900.0	375.1	0.45	0.2		0.8	
06/17/2025 08:00	3,564.7	0.0	3,564.7	104,900.0	373.9	0.45	0.2		0.7	
06/17/2025 09:00	3,561.3	0.0	3,561.3	104,900.0	373.6	0.45	0.2		0.7	
06/17/2025 10:00	3,566.8	0.0	3,566.8	104,900.0	374.2	0.45	0.2		0.7	
06/17/2025 11:00	3,579.1	0.0	3,579.1	104,900.0	375.4	0.45	0.2		0.8	
06/17/2025 12:00	3,584.3	0.0	3,584.3	104,900.0	376.0	0.45	0.2		0.8	
06/17/2025 13:00	3,568.3	0.0	3,568.3	104,900.0	374.3	0.45	0.2		0.7	
06/17/2025 14:00	3,850.3	0.0	3,850.3	104,900.0	403.9	0.49	0.2		0.8	
06/17/2025 15:00	3,567.7	0.0	3,567.7	104,900.0	374.3	0.45	0.2		0.7	
06/17/2025 16:00	3,944.5	154.5	3,978.5	104,900.0	417.3	0.52	0.3		0.9	
06/17/2025 17:00	4,261.6	1,239.5	5,501.1	104,900.0	577.1	0.69	0.3		1.2	
06/17/2025 18:00	4,243.5	1,680.4	5,923.9	104,900.0	621.4	0.75	0.4		1.2	
06/17/2025 19:00	4,268.5	1,646.3	5,914.8	104,900.0	620.5	0.75	0.4		1.2	
06/17/2025 20:00	4,326.4	1,190.1	5,516.5	104,900.0	578.7	0.69	0.3		1.2	
06/17/2025 21:00	4,342.4	787.4	5,129.8	104,900.0	538.1	0.65	0.3		1.1	
06/17/2025 22:00	4,352.1	738.0	5,090.1	104,900.0	534.0	0.64	0.3		1.1	
06/17/2025 23:00	4,372.8	749.1	5,121.9	104,900.0	537.3	0.64	0.3		1.1	
Average/Sum#:	4,036.4	493.3	4,520.9	104,900.0	474.2	0.57	0.3		1.0	
Minimum:	3,561.3	0.0	3,561.3	104,900.0	373.6	0.45	0.2		0.7	
Maximum:	4,470.1	1,680.4	5,923.9	104,900.0	621.4	0.75	0.4		1.2	
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00	

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/18/2025 00:00	4,386.8	734.4	5,121.2	104,900.0	537.2	0.64	0.3	1.1
06/18/2025 01:00	4,405.3	699.7	5,105.0	104,900.0	535.5	0.64	0.3	1.1
06/18/2025 02:00	4,413.5	687.9	5,101.4	104,900.0	535.1	0.64	0.3	1.1
06/18/2025 03:00	4,428.7	665.8	5,094.5	104,900.0	534.4	0.64	0.3	1.1
06/18/2025 04:00	4,429.6	658.5	5,088.1	104,900.0	533.7	0.64	0.3	1.1
06/18/2025 05:00	4,428.7	658.1	5,086.8	104,900.0	533.6	0.64	0.3	1.1
06/18/2025 06:00	4,187.6	328.4	4,361.7	104,900.0	457.5	0.57	0.3	0.9
06/18/2025 07:00	3,593.7	0.0	3,593.7	104,900.0	377.0	0.45	0.2	0.8
06/18/2025 08:00	3,582.1	0.0	3,582.1	104,900.0	375.8	0.45	0.2	0.8
06/18/2025 09:00	3,587.7	0.0	3,587.7	104,900.0	376.3	0.45	0.2	0.8
06/18/2025 10:00	3,580.8	0.0	3,580.8	104,900.0	375.6	0.45	0.2	0.8
06/18/2025 11:00	3,572.0	0.0	3,572.0	104,900.0	374.7	0.45	0.2	0.7
06/18/2025 12:00	3,569.9	0.0	3,569.9	104,900.0	374.5	0.45	0.2	0.7
06/18/2025 13:00	3,557.2	0.0	3,557.2	104,900.0	373.2	0.45	0.2	0.7
06/18/2025 14:00	3,558.2	0.0	3,558.2	104,900.0	373.3	0.45	0.2	0.7
06/18/2025 15:00	3,556.8	0.0	3,556.8	104,900.0	373.1	0.45	0.2	0.7
06/18/2025 16:00	3,916.0	242.5	3,983.9	104,900.0	417.9	0.52	0.3	0.9
06/18/2025 17:00	4,185.7	1,089.9	5,275.6	104,900.0	553.4	0.66	0.3	1.1
06/18/2025 18:00	4,169.3	1,738.8	5,908.1	104,900.0	619.8	0.74	0.4	1.2
06/18/2025 19:00	4,192.7	1,551.3	5,744.0	104,900.0	602.5	0.72	0.4	1.2
06/18/2025 20:00	4,227.6	1,090.7	5,318.3	104,900.0	557.9	0.67	0.3	1.1
06/18/2025 21:00	4,258.6	901.5	5,160.1	104,900.0	541.3	0.65	0.3	1.1
06/18/2025 22:00	4,273.9	886.5	5,160.4	104,900.0	541.3	0.65	0.3	1.1
06/18/2025 23:00	4,192.8	1,006.5	5,199.3	104,900.0	545.4	0.65	0.3	1.1
Average/Sum#:	4,010.6	539.2	4,536.1	104,900.0	475.8	0.57	0.3	1.0
Minimum:	3,556.8	0.0	3,556.8	104,900.0	373.1	0.45	0.2	0.7
Maximum:	4,429.6	1,738.8	5,908.1	104,900.0	619.8	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/19/2025 00:00	4,226.9	942.9	5,169.8	104,900.0	542.3	0.65	0.3	1.1			
06/19/2025 01:00	4,271.7	855.3	5,127.0	104,900.0	537.8	0.65	0.3	1.1			
06/19/2025 02:00	4,296.8	811.6	5,108.4	104,900.0	535.9	0.64	0.3	1.1			
06/19/2025 03:00	4,314.6	790.3	5,104.9	104,900.0	535.5	0.64	0.3	1.1			
06/19/2025 04:00	4,335.5	764.0	5,099.5	104,900.0	534.9	0.64	0.3	1.1			
06/19/2025 05:00	4,330.5	553.1	4,761.9	104,900.0	499.5	0.61	0.3	1.0			
06/19/2025 06:00	3,570.0	0.0	3,570.0	104,900.0	374.5	0.45	0.2	0.7			
06/19/2025 07:00	3,602.2	0.0	3,602.2	104,900.0	377.9	0.45	0.2	0.8			
06/19/2025 08:00	3,600.7	0.0	3,600.7	104,900.0	377.7	0.45	0.2	0.8			
06/19/2025 09:00	3,578.5	0.0	3,578.5	104,900.0	375.4	0.45	0.2	0.8			
06/19/2025 10:00	3,569.9	0.0	3,569.9	104,900.0	374.5	0.45	0.2	0.7			
06/19/2025 11:00	3,564.4	0.0	3,564.4	104,900.0	373.9	0.45	0.2	0.7			
06/19/2025 12:00	3,573.0	0.0	3,573.0	104,900.0	374.8	0.45	0.2	0.8			
06/19/2025 13:00	3,564.5	0.0	3,564.5	104,900.0	373.9	0.45	0.2	0.7			
06/19/2025 14:00	3,560.7	0.0	3,560.7	104,900.0	373.5	0.45	0.2	0.7			
06/19/2025 15:00	3,555.2	0.0	3,555.2	104,900.0	372.9	0.45	0.2	0.7			
06/19/2025 16:00	3,556.3	0.0	3,556.3	104,900.0	373.1	0.45	0.2	0.7			
06/19/2025 17:00	3,538.8	0.0	3,538.8	104,900.0	371.2	0.45	0.2	0.7			
06/19/2025 18:00	3,531.8	0.0	3,531.8	104,900.0	370.5	0.44	0.2	0.7			
06/19/2025 19:00	3,533.4	0.0	3,533.4	104,900.0	370.7	0.44	0.2	0.7			
06/19/2025 20:00	3,549.7	0.0	3,549.7	104,900.0	372.4	0.45	0.2	0.7			
06/19/2025 21:00	3,547.7	0.0	3,547.7	104,900.0	372.2	0.45	0.2	0.7			
06/19/2025 22:00	3,546.7	0.0	3,546.7	104,900.0	372.0	0.45	0.2	0.7			
06/19/2025 23:00	3,558.3	0.0	3,558.3	104,900.0	373.3	0.45	0.2	0.7			
Average/Sum#:	3,744.9	196.6	3,936.4	104,900.0	412.9	0.50	0.2	0.8			
Minimum:	3,531.8	0.0	3,531.8	104,900.0	370.5	0.44	0.2	0.7			
Maximum:	4,335.5	942.9	5,169.8	104,900.0	542.3	0.65	0.3	1.1			
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/20/2025 00:00	3,556.9	0.0	3,556.9	104,900.0	373.1	0.45	0.2	0.2	0.7	0.7
06/20/2025 01:00	3,554.0	0.0	3,554.0	104,900.0	372.8	0.45	0.2	0.2	0.7	0.7
06/20/2025 02:00	3,554.3	0.0	3,554.3	104,900.0	372.8	0.45	0.2	0.2	0.7	0.7
06/20/2025 03:00	3,553.0	0.0	3,553.0	104,900.0	372.7	0.45	0.2	0.2	0.7	0.7
06/20/2025 04:00	3,562.1	0.0	3,562.1	104,900.0	373.7	0.45	0.2	0.2	0.7	0.7
06/20/2025 05:00	3,611.7	0.0	3,611.7	104,900.0	378.9	0.46	0.2	0.2	0.8	0.8
06/20/2025 06:00	3,551.3	0.0	3,551.3	104,900.0	372.5	0.45	0.2	0.2	0.7	0.7
06/20/2025 07:00	3,561.0	0.0	3,561.0	104,900.0	373.5	0.45	0.2	0.2	0.7	0.7
06/20/2025 08:00	3,552.7	0.0	3,552.7	104,900.0	372.7	0.45	0.2	0.2	0.7	0.7
06/20/2025 09:00	3,563.4	0.0	3,563.4	104,900.0	373.8	0.45	0.2	0.2	0.7	0.7
06/20/2025 10:00	3,556.6	0.0	3,556.6	104,900.0	373.1	0.45	0.2	0.2	0.7	0.7
06/20/2025 11:00	3,575.5	0.0	3,575.5	104,900.0	375.1	0.45	0.2	0.2	0.8	0.8
06/20/2025 12:00	3,588.8	0.0	3,588.8	104,900.0	376.5	0.45	0.2	0.2	0.8	0.8
06/20/2025 13:00	3,589.0	0.0	3,589.0	104,900.0	376.5	0.45	0.2	0.2	0.8	0.8
06/20/2025 14:00	3,584.3	0.0	3,584.3	104,900.0	376.0	0.45	0.2	0.2	0.8	0.8
06/20/2025 15:00	3,566.8	0.0	3,566.8	104,900.0	374.2	0.45	0.2	0.2	0.7	0.7
06/20/2025 16:00	3,547.3	0.0	3,547.3	104,900.0	372.1	0.45	0.2	0.2	0.7	0.7
06/20/2025 17:00	3,545.3	0.0	3,545.3	104,900.0	371.9	0.45	0.2	0.2	0.7	0.7
06/20/2025 18:00	3,530.1	0.0	3,530.1	104,900.0	370.3	0.44	0.2	0.2	0.7	0.7
06/20/2025 19:00	3,520.0	0.0	3,520.0	104,900.0	369.2	0.44	0.2	0.2	0.7	0.7
06/20/2025 20:00	3,526.4	0.0	3,526.4	104,900.0	369.9	0.44	0.2	0.2	0.7	0.7
06/20/2025 21:00	3,536.5	0.0	3,536.5	104,900.0	371.0	0.45	0.2	0.2	0.7	0.7
06/20/2025 22:00	3,554.5	0.0	3,554.5	104,900.0	372.9	0.45	0.2	0.2	0.7	0.7
06/20/2025 23:00	3,555.1	0.0	3,555.1	104,900.0	372.9	0.45	0.2	0.2	0.7	0.7
Average/Sum#:	3,558.2	0.0	3,558.2	104,900.0	373.3	0.45	0.2	0.2	0.7	0.7
Minimum:	3,520.0	0.0	3,520.0	104,900.0	369.2	0.44	0.2	0.2	0.7	0.7
Maximum:	3,611.7	0.0	3,611.7	104,900.0	378.9	0.46	0.2	0.2	0.8	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/21/2025 00:00	3,566.6	0.0	3,566.6	104,900.0	374.1	0.45	0.2	0.7			
06/21/2025 01:00	3,570.9	0.0	3,570.9	104,900.0	374.6	0.45	0.2	0.7			
06/21/2025 02:00	3,581.0	0.0	3,581.0	104,900.0	375.6	0.45	0.2	0.8			
06/21/2025 03:00	3,577.4	0.0	3,577.4	104,900.0	375.3	0.45	0.2	0.8			
06/21/2025 04:00	3,569.8	0.0	3,569.8	104,900.0	374.5	0.45	0.2	0.7			
06/21/2025 05:00	3,579.1	0.0	3,579.1	104,900.0	375.4	0.45	0.2	0.8			
06/21/2025 06:00	3,576.7	0.0	3,576.7	104,900.0	375.2	0.45	0.2	0.8			
06/21/2025 07:00	3,559.9	0.0	3,559.9	104,900.0	373.4	0.45	0.2	0.7			
06/21/2025 08:00	3,572.9	0.0	3,572.9	104,900.0	374.8	0.45	0.2	0.7			
06/21/2025 09:00	3,595.6	0.0	3,595.6	104,900.0	377.2	0.45	0.2	0.8			
06/21/2025 10:00	3,584.8	0.0	3,584.8	104,900.0	376.0	0.45	0.2	0.8			
06/21/2025 11:00	3,564.3	0.0	3,564.3	104,900.0	373.9	0.45	0.2	0.7			
06/21/2025 12:00	3,578.5	0.0	3,578.5	104,900.0	375.4	0.45	0.2	0.8			
06/21/2025 13:00	3,582.4	0.0	3,582.4	104,900.0	375.8	0.45	0.2	0.8			
06/21/2025 14:00	3,580.0	0.0	3,580.0	104,900.0	375.5	0.45	0.2	0.8			
06/21/2025 15:00	3,546.8	0.0	3,546.8	104,900.0	372.1	0.45	0.2	0.7			
06/21/2025 16:00	3,535.8	0.0	3,535.8	104,900.0	370.9	0.44	0.2	0.7			
06/21/2025 17:00	3,536.3	0.0	3,536.3	104,900.0	371.0	0.45	0.2	0.7			
06/21/2025 18:00	3,551.3	0.0	3,551.3	104,900.0	372.5	0.45	0.2	0.7			
06/21/2025 19:00	3,576.7	0.0	3,576.7	104,900.0	375.2	0.45	0.2	0.8			
06/21/2025 20:00	3,580.4	0.0	3,580.4	104,900.0	375.6	0.45	0.2	0.8			
06/21/2025 21:00	3,583.6	0.0	3,583.6	104,900.0	375.9	0.45	0.2	0.8			
06/21/2025 22:00	3,583.9	0.0	3,583.9	104,900.0	376.0	0.45	0.2	0.8			
06/21/2025 23:00	3,574.9	0.0	3,574.9	104,900.0	375.0	0.45	0.2	0.8			
Average/Sum#:	3,571.2	0.0	3,571.2	104,900.0	374.6	0.45	0.2	0.8			
Minimum:	3,535.8	0.0	3,535.8	104,900.0	370.9	0.44	0.2	0.7			
Maximum:	3,595.6	0.0	3,595.6	104,900.0	377.2	0.45	0.2	0.8			
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/22/2025 00:00	3,574.7	0.0	3,574.7	104,900.0	375.0	0.45	0.2	0.2	0.7	0.7
06/22/2025 01:00	3,582.0	0.0	3,582.0	104,900.0	375.8	0.45	0.2	0.2	0.8	0.8
06/22/2025 02:00	3,570.4	0.0	3,570.4	104,900.0	374.5	0.45	0.2	0.2	0.7	0.7
06/22/2025 03:00	3,579.2	0.0	3,579.2	104,900.0	375.5	0.45	0.2	0.2	0.8	0.8
06/22/2025 04:00	3,578.4	0.0	3,578.4	104,900.0	375.4	0.45	0.2	0.2	0.8	0.8
06/22/2025 05:00	3,695.5	0.0	3,695.5	104,900.0	387.7	0.47	0.2	0.2	0.8	0.8
06/22/2025 06:00	3,570.0	0.0	3,570.0	104,900.0	374.5	0.45	0.2	0.2	0.7	0.7
06/22/2025 07:00	3,556.0	0.0	3,556.0	104,900.0	373.0	0.45	0.2	0.2	0.7	0.7
06/22/2025 08:00	3,567.3	0.0	3,567.3	104,900.0	374.2	0.45	0.2	0.2	0.7	0.7
06/22/2025 09:00	3,562.3	0.0	3,562.3	104,900.0	373.7	0.45	0.2	0.2	0.7	0.7
06/22/2025 10:00	3,566.8	0.0	3,566.8	104,900.0	374.2	0.45	0.2	0.2	0.7	0.7
06/22/2025 11:00	3,545.2	0.0	3,545.2	104,900.0	371.9	0.45	0.2	0.2	0.7	0.7
06/22/2025 12:00	3,549.4	0.0	3,549.4	104,900.0	372.3	0.45	0.2	0.2	0.7	0.7
06/22/2025 13:00	3,553.0	0.0	3,553.0	104,900.0	372.7	0.45	0.2	0.2	0.7	0.7
06/22/2025 14:00	3,545.8	0.0	3,545.8	104,900.0	372.0	0.45	0.2	0.2	0.7	0.7
06/22/2025 15:00	3,537.4	0.0	3,537.4	104,900.0	371.1	0.45	0.2	0.2	0.7	0.7
06/22/2025 16:00	3,531.1	0.0	3,531.1	104,900.0	370.4	0.44	0.2	0.2	0.7	0.7
06/22/2025 17:00	3,628.8	0.0	3,628.8	104,900.0	380.7	0.46	0.2	0.2	0.8	0.8
06/22/2025 18:00	3,526.2	0.0	3,526.2	104,900.0	369.9	0.44	0.2	0.2	0.7	0.7
06/22/2025 19:00	3,524.8	0.0	3,524.8	104,900.0	369.8	0.44	0.2	0.2	0.7	0.7
06/22/2025 20:00	3,551.2	0.0	3,551.2	104,900.0	372.5	0.45	0.2	0.2	0.7	0.7
06/22/2025 21:00	3,526.0	0.0	3,526.0	104,900.0	369.9	0.44	0.2	0.2	0.7	0.7
06/22/2025 22:00	3,529.6	0.0	3,529.6	104,900.0	370.3	0.44	0.2	0.2	0.7	0.7
06/22/2025 23:00	3,579.4	0.0	3,579.4	104,900.0	375.5	0.45	0.2	0.2	0.8	0.8
Average/Sum#:	3,563.8	0.0	3,563.8	104,900.0	373.9	0.45	0.2	0.2	0.7	0.7
Minimum:	3,524.8	0.0	3,524.8	104,900.0	369.8	0.44	0.2	0.2	0.7	0.7
Maximum:	3,695.5	0.0	3,695.5	104,900.0	387.7	0.47	0.2	0.2	0.8	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/23/2025 00:00	3,523.6	0.0	3,523.6	104,900.0	369.6	0.44	0.2	0.7			
06/23/2025 01:00	3,522.1	0.0	3,522.1	104,900.0	369.5	0.44	0.2	0.7			
06/23/2025 02:00	3,542.3	0.0	3,542.3	104,900.0	371.6	0.45	0.2	0.7			
06/23/2025 03:00	3,543.3	0.0	3,543.3	104,900.0	371.7	0.45	0.2	0.7			
06/23/2025 04:00	3,548.9	0.0	3,548.9	104,900.0	372.3	0.45	0.2	0.7			
06/23/2025 05:00	3,879.3	0.0	3,879.3	104,900.0	406.9	0.49	0.2	0.8			
06/23/2025 06:00	3,525.0	0.0	3,525.0	104,900.0	369.8	0.44	0.2	0.7			
06/23/2025 07:00	3,527.9	0.0	3,527.9	104,900.0	370.1	0.44	0.2	0.7			
06/23/2025 08:00	3,532.6	0.0	3,532.6	104,900.0	370.6	0.44	0.2	0.7			
06/23/2025 09:00	3,514.0	0.0	3,514.0	104,900.0	368.6	0.44	0.2	0.7			
06/23/2025 10:00	3,513.9	0.0	3,513.9	104,900.0	368.6	0.44	0.2	0.7			
06/23/2025 11:00	3,526.1	0.0	3,526.1	104,900.0	369.9	0.44	0.2	0.7			
06/23/2025 12:00	3,523.5	0.0	3,523.5	104,900.0	369.6	0.44	0.2	0.7			
06/23/2025 13:00	3,522.4	0.0	3,522.4	104,900.0	369.5	0.44	0.2	0.7			
06/23/2025 14:00	3,518.5	0.0	3,518.5	104,900.0	369.1	0.44	0.2	0.7			
06/23/2025 15:00	3,520.4	0.0	3,520.4	104,900.0	369.3	0.44	0.2	0.7			
06/23/2025 16:00	3,528.2	0.0	3,528.2	104,900.0	370.1	0.44	0.2	0.7			
06/23/2025 17:00	3,680.6	45.4	3,686.5	104,900.0	386.7	0.47	0.2	0.8			
06/23/2025 18:00	3,973.5	2.1	3,973.5	104,900.0	416.8	0.50	0.3	0.8			
06/23/2025 19:00	4,124.4	0.0	4,124.4	104,900.0	432.6	0.52	0.3	0.9			
06/23/2025 20:00	3,821.0	0.0	3,821.0	104,900.0	400.8	0.48	0.2	0.8			
06/23/2025 21:00	3,965.2	0.0	3,965.2	104,900.0	415.9	0.50	0.2	0.8			
06/23/2025 22:00	4,137.4	0.0	4,137.4	104,900.0	434.0	0.52	0.3	0.9			
06/23/2025 23:00	4,243.4	0.0	4,243.4	104,900.0	445.1	0.53	0.3	0.9			
Average/Sum#:	3,677.4	2.0	3,677.6	104,900.0	385.8	0.46	0.2	0.7			
Minimum:	3,513.9	0.0	3,513.9	104,900.0	368.6	0.44	0.2	0.7			
Maximum:	4,243.4	45.4	4,243.4	104,900.0	445.1	0.53	0.3	0.9			
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/24/2025 00:00	3,832.0	0.0	3,832.0	104,900.0	402.0	0.48	0.2	0.8
06/24/2025 01:00	3,599.2	0.0	3,599.2	104,900.0	377.6	0.45	0.2	0.8
06/24/2025 02:00	4,256.5	0.0	4,256.5	104,900.0	446.5	0.54	0.3	0.9
06/24/2025 03:00	4,247.3	0.0	4,247.3	104,900.0	445.5	0.53	0.3	0.9
06/24/2025 04:00	4,244.9	0.0	4,244.9	104,900.0	445.3	0.53	0.3	0.9
06/24/2025 05:00	3,882.9	0.0	3,882.9	104,900.0	407.3	0.49	0.2	0.8
06/24/2025 06:00	3,530.8	0.0	3,530.8	104,900.0	370.4	0.44	0.2	0.7
06/24/2025 07:00	3,527.7	0.0	3,527.7	104,900.0	370.1	0.44	0.2	0.7
06/24/2025 08:00	3,505.3	0.0	3,505.3	104,900.0	367.7	0.44	0.2	0.7
06/24/2025 09:00	3,472.3	0.0	3,472.3	104,900.0	364.2	0.44	0.2	0.7
06/24/2025 10:00	3,445.2	0.0	3,445.2	104,900.0	361.4	0.43	0.2	0.7
06/24/2025 11:00	3,456.0	0.0	3,456.0	104,900.0	362.5	0.44	0.2	0.7
06/24/2025 12:00	3,469.8	0.0	3,469.8	104,900.0	364.0	0.44	0.2	0.7
06/24/2025 13:00	3,472.5	0.0	3,472.5	104,900.0	364.3	0.44	0.2	0.7
06/24/2025 14:00	3,473.3	0.0	3,473.3	104,900.0	364.3	0.44	0.2	0.7
06/24/2025 15:00	3,477.6	0.0	3,477.6	104,900.0	364.8	0.44	0.2	0.7
06/24/2025 16:00	3,490.0	0.0	3,490.0	104,900.0	366.1	0.44	0.2	0.7
06/24/2025 17:00	3,889.1	0.0	3,889.1	104,900.0	408.0	0.49	0.2	0.8
06/24/2025 18:00	3,747.4	0.0	3,747.4	104,900.0	393.1	0.47	0.2	0.8
06/24/2025 19:00	3,461.5	0.0	3,461.5	104,900.0	363.1	0.44	0.2	0.7
06/24/2025 20:00	3,454.9	0.0	3,454.9	104,900.0	362.4	0.44	0.2	0.7
06/24/2025 21:00	3,472.8	0.0	3,472.8	104,900.0	364.3	0.44	0.2	0.7
06/24/2025 22:00	3,487.7	0.0	3,487.7	104,900.0	365.9	0.44	0.2	0.7
06/24/2025 23:00	3,784.7	0.0	3,784.7	104,900.0	397.0	0.48	0.2	0.8
Average/Sum#:	3,653.4	0.0	3,653.4	104,900.0	383.2	0.46	0.2	0.8
Minimum:	3,445.2	0.0	3,445.2	104,900.0	361.4	0.43	0.2	0.7
Maximum:	4,256.5	0.0	4,256.5	104,900.0	446.5	0.54	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/25/2025 00:00	3,481.2	0.0	3,481.2	104,900.0	365.2	0.44	0.2	0.7			
06/25/2025 01:00	3,479.2	0.0	3,479.2	104,900.0	365.0	0.44	0.2	0.7			
06/25/2025 02:00	3,487.8	0.0	3,487.8	104,900.0	365.9	0.44	0.2	0.7			
06/25/2025 03:00	3,484.0	0.0	3,484.0	104,900.0	365.5	0.44	0.2	0.7			
06/25/2025 04:00	3,494.9	0.0	3,494.9	104,900.0	366.6	0.44	0.2	0.7			
06/25/2025 05:00	3,531.1	0.0	3,531.1	104,900.0	370.4	0.44	0.2	0.7			
06/25/2025 06:00	3,484.2	0.0	3,484.2	104,900.0	365.5	0.44	0.2	0.7			
06/25/2025 07:00	3,482.9	0.0	3,482.9	104,900.0	365.4	0.44	0.2	0.7			
06/25/2025 08:00	3,486.4	0.0	3,486.4	104,900.0	365.7	0.44	0.2	0.7			
06/25/2025 09:00	3,478.8	0.0	3,478.8	104,900.0	364.9	0.44	0.2	0.7			
06/25/2025 10:00	3,482.2	0.0	3,482.2	104,900.0	365.3	0.44	0.2	0.7			
06/25/2025 11:00	3,494.2	0.0	3,494.2	104,900.0	366.5	0.44	0.2	0.7			
06/25/2025 12:00	3,473.2	0.0	3,473.2	104,900.0	364.3	0.44	0.2	0.7			
06/25/2025 13:00	3,465.2	0.0	3,465.2	104,900.0	363.5	0.44	0.2	0.7			
06/25/2025 14:00	3,458.9	0.0	3,458.9	104,900.0	362.8	0.44	0.2	0.7			
06/25/2025 15:00	3,442.7	0.0	3,442.7	104,900.0	361.1	0.43	0.2	0.7			
06/25/2025 16:00	3,441.0	0.0	3,441.0	104,900.0	361.0	0.43	0.2	0.7			
06/25/2025 17:00	3,602.8	0.0	3,602.8	104,900.0	377.9	0.45	0.2	0.8			
06/25/2025 18:00	4,009.7	0.0	4,009.7	104,900.0	420.6	0.50	0.3	0.8			
06/25/2025 19:00	3,813.6	0.0	3,813.6	104,900.0	400.0	0.48	0.2	0.8			
06/25/2025 20:00	3,633.7	0.0	3,633.7	104,900.0	381.2	0.46	0.2	0.8			
06/25/2025 21:00	3,460.9	0.0	3,460.9	104,900.0	363.0	0.44	0.2	0.7			
06/25/2025 22:00	3,459.5	0.0	3,459.5	104,900.0	362.9	0.44	0.2	0.7			
06/25/2025 23:00	3,462.2	0.0	3,462.2	104,900.0	363.2	0.44	0.2	0.7			
Average/Sum#:	3,524.6	0.0	3,524.6	104,900.0	369.7	0.44	0.2	0.7			
Minimum:	3,441.0	0.0	3,441.0	104,900.0	361.0	0.43	0.2	0.7			
Maximum:	4,009.7	0.0	4,009.7	104,900.0	420.6	0.50	0.3	0.8			
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/26/2025 00:00	3,463.9	0.0	3,463.9	104,900.0	363.4	0.44	0.2	0.7			
06/26/2025 01:00	3,484.5	0.0	3,484.5	104,900.0	365.5	0.44	0.2	0.7			
06/26/2025 02:00	3,491.6	0.0	3,491.6	104,900.0	366.3	0.44	0.2	0.7			
06/26/2025 03:00	3,504.3	0.0	3,504.3	104,900.0	367.6	0.44	0.2	0.7			
06/26/2025 04:00	3,508.4	0.0	3,508.4	104,900.0	368.0	0.44	0.2	0.7			
06/26/2025 05:00	3,507.2	0.0	3,507.2	104,900.0	367.9	0.44	0.2	0.7			
06/26/2025 06:00	3,499.0	0.0	3,499.0	104,900.0	367.0	0.44	0.2	0.7			
06/26/2025 07:00	3,506.7	0.0	3,506.7	104,900.0	367.9	0.44	0.2	0.7			
06/26/2025 08:00	3,503.2	0.0	3,503.2	104,900.0	367.5	0.44	0.2	0.7			
06/26/2025 09:00	3,475.9	0.0	3,475.9	104,900.0	364.6	0.44	0.2	0.7			
06/26/2025 10:00	3,473.1	0.0	3,473.1	104,900.0	364.3	0.44	0.2	0.7			
06/26/2025 11:00	3,482.0	0.0	3,482.0	104,900.0	365.3	0.44	0.2	0.7			
06/26/2025 12:00	3,488.7	0.0	3,488.7	104,900.0	366.0	0.44	0.2	0.7			
06/26/2025 13:00	3,484.8	0.0	3,484.8	104,900.0	365.6	0.44	0.2	0.7			
06/26/2025 14:00	3,467.8	0.0	3,467.8	104,900.0	363.8	0.44	0.2	0.7			
06/26/2025 15:00	3,463.1	0.0	3,463.1	104,900.0	363.3	0.44	0.2	0.7			
06/26/2025 16:00	3,459.3	0.0	3,459.3	104,900.0	362.9	0.44	0.2	0.7			
06/26/2025 17:00	3,595.7	0.0	3,595.7	104,900.0	377.2	0.45	0.2	0.8			
06/26/2025 18:00	3,781.3	0.0	3,781.3	104,900.0	396.7	0.48	0.2	0.8			
06/26/2025 19:00	4,188.3	0.0	4,188.3	104,900.0	439.4	0.53	0.3	0.9			
06/26/2025 20:00	3,981.5	0.0	3,981.5	104,900.0	417.7	0.50	0.3	0.8			
06/26/2025 21:00	3,560.0	0.0	3,560.0	104,900.0	373.4	0.45	0.2	0.7			
06/26/2025 22:00	3,472.2	0.0	3,472.2	104,900.0	364.2	0.44	0.2	0.7			
06/26/2025 23:00	3,476.6	0.0	3,476.6	104,900.0	364.7	0.44	0.2	0.7			
Average/Sum#:	3,555.0	0.0	3,555.0	104,900.0	372.9	0.45	0.2	0.7			
Minimum:	3,459.3	0.0	3,459.3	104,900.0	362.9	0.44	0.2	0.7			
Maximum:	4,188.3	0.0	4,188.3	104,900.0	439.4	0.53	0.3	0.9			
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/27/2025 00:00	3,473.8	0.0	3,473.8	104,900.0	364.4	0.44	0.2	0.7			
06/27/2025 01:00	3,475.9	0.0	3,475.9	104,900.0	364.6	0.44	0.2	0.7			
06/27/2025 02:00	3,471.2	0.0	3,471.2	104,900.0	364.1	0.44	0.2	0.7			
06/27/2025 03:00	3,475.7	0.0	3,475.7	104,900.0	364.6	0.44	0.2	0.7			
06/27/2025 04:00	3,584.3	0.0	3,584.3	104,900.0	376.0	0.45	0.2	0.8			
06/27/2025 05:00	3,872.1	0.0	3,872.1	104,900.0	406.2	0.49	0.2	0.8			
06/27/2025 06:00	3,500.6	0.0	3,500.6	104,900.0	367.2	0.44	0.2	0.7			
06/27/2025 07:00	3,513.8	0.0	3,513.8	104,900.0	368.6	0.44	0.2	0.7			
06/27/2025 08:00	3,518.0	0.0	3,518.0	104,900.0	369.0	0.44	0.2	0.7			
06/27/2025 09:00	3,529.8	0.0	3,529.8	104,900.0	370.3	0.44	0.2	0.7			
06/27/2025 10:00	3,541.8	0.0	3,541.8	104,900.0	371.5	0.45	0.2	0.7			
06/27/2025 11:00	3,553.5	0.0	3,553.5	104,900.0	372.8	0.45	0.2	0.7			
06/27/2025 12:00	3,893.8	0.0	3,893.8	104,900.0	408.5	0.49	0.2	0.8			
06/27/2025 13:00	4,205.0	0.0	4,205.0	104,900.0	441.1	0.53	0.3	0.9			
06/27/2025 14:00	4,052.8	0.0	4,052.8	104,900.0	425.1	0.51	0.3	0.9			
06/27/2025 15:00	3,964.1	0.0	3,964.1	104,900.0	415.8	0.50	0.2	0.8			
06/27/2025 16:00	3,955.5	0.0	3,955.5	104,900.0	414.9	0.50	0.2	0.8			
06/27/2025 17:00	3,881.2	0.0	3,881.2	104,900.0	407.1	0.49	0.2	0.8			
06/27/2025 18:00	4,198.7	130.9	4,227.5	104,900.0	443.5	0.55	0.3	0.9			
06/27/2025 19:00	4,199.4	1,794.0	5,993.4	104,900.0	628.7	0.75	0.4	1.3			
06/27/2025 20:00	4,219.9	781.6	5,001.5	104,900.0	524.7	0.63	0.3	1.1			
06/27/2025 21:00	3,925.7	276.2	4,072.1	104,900.0	427.2	0.55	0.3	0.9			
06/27/2025 22:00	1,395.7	0.0	1,395.7	104,900.0	146.4	0.00	0.0	0.0			
06/27/2025 23:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0			
Average/Sum#:	3,669.7	129.7	3,789.3	104,900.0	397.5	0.49	0.2	0.8			
Minimum:	1,395.7	0.0	1,395.7	104,900.0	146.4	0.44	0.2	0.7			
Maximum:	4,219.9	1,794.0	5,993.4	104,900.0	628.7	0.75	0.4	1.3			
%SI	4.17	4.17	4.17	0.00	4.17	8.33	8.33	8.33			

Fuel Gas and Emissions Daily Summary

CT1



From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/28/2025 00:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/28/2025 01:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/28/2025 02:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/28/2025 03:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/28/2025 04:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/28/2025 05:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/28/2025 06:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/28/2025 07:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/28/2025 08:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/28/2025 09:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/28/2025 10:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/28/2025 11:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/28/2025 12:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/28/2025 13:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/28/2025 14:00	1,129.9	0.0	1,129.9	104,900.0	118.5	0.00	0.0	0.0
06/28/2025 15:00	3,840.9	0.0	3,840.9	104,900.0	402.9	0.52	0.3	0.9
06/28/2025 16:00	4,141.1	0.0	4,141.1	104,900.0	434.4	0.52	0.3	0.9
06/28/2025 17:00	4,169.5	149.0	4,203.8	104,900.0	441.0	0.54	0.3	0.9
06/28/2025 18:00	4,181.4	1,835.4	6,016.8	104,900.0	631.2	0.76	0.4	1.3
06/28/2025 19:00	4,204.1	1,933.8	6,137.9	104,900.0	643.9	0.77	0.4	1.3
06/28/2025 20:00	4,214.9	1,752.0	5,966.9	104,900.0	625.9	0.75	0.4	1.3
06/28/2025 21:00	4,224.8	1,832.4	6,057.2	104,900.0	635.4	0.76	0.4	1.3
06/28/2025 22:00	4,249.4	1,363.2	5,612.6	104,900.0	588.8	0.71	0.4	1.2
06/28/2025 23:00	4,246.7	652.0	4,657.5	104,900.0	488.6	0.62	0.3	1.0
Average/Sum#:	3,860.3	951.8	4,776.5	104,900.0	501.1	0.66	0.4	1.1
Minimum:	1,129.9	0.0	1,129.9	104,900.0	118.5	0.52	0.3	0.9
Maximum:	4,249.4	1,933.8	6,137.9	104,900.0	643.9	0.77	0.4	1.3
%SI	58.33	58.33	58.33	0.00	58.33	62.50	62.50	62.50

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

Const. Value/Limit Tag:		> 4.73 > 1 > 1.8							
		Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	
		GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
		1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/29/2025 00:00	3,833.8	0.0	3,833.8	104,900.0	402.2	0.48	0.2	0.8	
06/29/2025 01:00	3,347.5	0.0	3,347.5	104,900.0	351.2	0.43	0.2	0.7	
06/29/2025 02:00	1,512.9	0.0	1,512.9	104,900.0	158.7	0.00	0.0	0.0	
06/29/2025 03:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	
06/29/2025 04:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	
06/29/2025 05:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	
06/29/2025 06:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	
06/29/2025 07:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	
06/29/2025 08:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	
06/29/2025 09:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	
06/29/2025 10:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	
06/29/2025 11:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	
06/29/2025 12:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	
06/29/2025 13:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	
06/29/2025 14:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	
06/29/2025 15:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0	
06/29/2025 16:00	2,061.1	0.0	2,061.1	104,900.0	216.2	0.00	0.0	0.0	
06/29/2025 17:00	3,869.0	0.0	3,869.0	104,900.0	405.9	0.52	0.3	0.9	
06/29/2025 18:00	4,113.1	0.0	4,113.1	104,900.0	431.5	0.52	0.3	0.9	
06/29/2025 19:00	4,090.0	0.0	4,090.0	104,900.0	429.0	0.51	0.3	0.9	
06/29/2025 20:00	4,092.3	0.0	4,092.3	104,900.0	429.3	0.51	0.3	0.9	
06/29/2025 21:00	4,050.8	0.0	4,050.8	104,900.0	424.9	0.51	0.3	0.9	
06/29/2025 22:00	3,327.7	0.0	3,327.7	104,900.0	349.1	0.44	0.2	0.7	
06/29/2025 23:00	692.9	0.0	692.9	104,900.0	72.7	0.00	0.0	0.0	
Average/Sum#:	3,181.0	0.0	3,181.0	104,900.0	333.7	0.49	0.3	0.8	
Minimum:	692.9	0.0	692.9	104,900.0	72.7	0.43	0.2	0.7	
Maximum:	4,113.1	0.0	4,113.1	104,900.0	431.5	0.52	0.3	0.9	
%SI	54.17	54.17	54.17	0.00	54.17	66.67	66.67	66.67	

Fuel Gas and Emissions Daily Summary



CT1

From: 04/01/2025 00:00 To: 06/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 07/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/30/2025 00:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/30/2025 01:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/30/2025 02:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/30/2025 03:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/30/2025 04:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/30/2025 05:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/30/2025 06:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/30/2025 07:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/30/2025 08:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/30/2025 09:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/30/2025 10:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/30/2025 11:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/30/2025 12:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/30/2025 13:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/30/2025 14:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/30/2025 15:00	0.0	0.0	0.0	104,900.0	0.0	0.00	0.0	0.0
06/30/2025 16:00	1,125.8	0.0	1,125.8	104,900.0	118.1	0.00	0.0	0.0
06/30/2025 17:00	3,840.0	0.0	3,840.0	104,900.0	402.8	0.53	0.3	0.9
06/30/2025 18:00	4,142.3	0.0	4,142.3	104,900.0	434.5	0.52	0.3	0.9
06/30/2025 19:00	4,113.5	0.0	4,113.5	104,900.0	431.5	0.52	0.3	0.9
06/30/2025 20:00	4,104.8	0.0	4,104.8	104,900.0	430.6	0.52	0.3	0.9
06/30/2025 21:00	3,873.8	0.0	3,873.8	104,900.0	406.4	0.49	0.2	0.8
06/30/2025 22:00	3,443.0	0.0	3,443.0	104,900.0	361.2	0.43	0.2	0.7
06/30/2025 23:00	3,976.6	0.0	3,976.6	104,900.0	417.1	0.50	0.3	0.8
Average/Sum#:	3,577.5	0.0	3,577.5	104,900.0	375.3	0.50	0.3	0.8
Minimum:	1,125.8	0.0	1,125.8	104,900.0	118.1	0.43	0.2	0.7
Maximum:	4,142.3	0.0	4,142.3	104,900.0	434.5	0.53	0.3	0.9
%SI	66.67	66.67	66.67	0.00	66.67	70.83	70.83	70.83