

DOCKETED	
Docket Number:	99-AFC-03C
Project Title:	METCALF Energy Center Compliance
TN #:	265825
Document Title:	ANNUAL COMPLIANCE REPORT- 2024
Description:	ANNUAL COMPLIANCE REPORT- 2024
Filer:	Anwar Ali
Organization:	California Energy Commission
Submitter Role:	Commission Staff
Submission Date:	8/29/2025 12:27:59 PM
Docketed Date:	8/29/2025

Metcalf Energy Center, LLC

1 Blanchard Road
Coyote, CA 95013

August 20, 2025

Mr. Anwar Ali
Compliance Project Manager
Systems Assessment & Facility Sitting Division
California Energy Commission
1516 Ninth Street, MS-2000
Sacramento, CA 95814

**Re: Metcalf Energy Center, LLC.
Docket No. 99-AFC-3
Annual Compliance Report for 2024**

Dear Mr. Ali:

In accordance with the Conditions of Certification for the Metcalf Energy Center, LLC, this report is intended to fulfill the requirements of the Annual Compliance Report for 2024 in the Conditions of Certification.

Enclosed are the documents required by the Conditions of Certification. The documents are provided as appendices, as noted in the Annual Compliance Summary:

- Annual Compliance Summary
- Conditions of Certification Matrix
- Operating Data Summary
- AQ-13: Gas Turbine and HRSG Firing with Natural Gas
- AQ-14: Heat Input Hourly Limit
- AQ-15: Heat Input daily Limit
- AQ-16: Heat Input Annual Limit
- AQ-17: HRSG Duct Burners Firing
- AQ-18: S-1 and S-2 SCR Operation and Maintenance
- AQ-19: S-3 and S-4 SCR Operation and Maintenance
- AQ-20: Gas Turbine Emissions
- AQ-21: Gas Turbine Mass Emissions
- AQ-22: Gas Turbine Start-up
- AQ-24: Gas Turbine and HRSG Total Combined Daily Emissions
- AQ-25: Gas Turbine and HRSG Total Combined 12-Month Emissions
- AQ-26: Annual Toxic Air Contaminants Emissions
- AQ-27: Operation and Maintenance of Continuous Monitors

Metcalf Energy Center, LLC

- AQ-28: Calculation and Recording of Daily Mass Emissions
- AQ-29: Projected Annual Emissions of Formaldehyde, Benzene, Specific PAHs
- AQ-36: Notification of Violations
- AQ-44: Compliance with 40 CFR Part 75
- AQ-56: Cold Start-up Hours
- BIO-2: Designated Biologist Summaries
- HAZ-1: Hazardous Materials List
- LAND-1: Trail Network Connection
- PUBLIC HEALTH-1: Cooling Tower Inspection
- SOIL & WATER-1: Water Use Summary
- TRANS-3: Permits or Licenses for Hazardous Material Transport
- VIS-1: Treatment of Project Structures
- VIS-10: Visible Plumes
- WASTE-3: Waste Management Comparison

If you have any additional questions, please feel free to contact Rosemary Silva, EHS Project Manager III, at 408-361-4954.

Sincerely,

Signed by:

Chris Schneider

BFFA23815E88434...

Christopher Schneider
Plant Manager

Metcalf Energy Center, LLC.

DS

JS

Signed by:

Chris German

81C6363202A1191...

Enclosures: Via Email

Appendix 1

**California Energy Commission
2024 Annual Compliance Report
Metcalf Energy Center – 99-AFC-3**

Table of Contents

1.	Compliance Summary.....	Appendix 01
2.	Conditions of Certification Matrix	Appendix 02
3.	Operating Data Summary	Appendix 03
4.	On-site Contingency Plan	Appendix 04
5.	40 CFR Part 75 Reports (AQ-44).....	Appendix 05
6.	Designated Biologist Summary Report (BIO-02)	Appendix 06
7.	Hazardous Material Inventory (HAZ-01).....	Appendix 07
8.	Cooling Tower Inspection (PH-01)	Appendix 08
9.	Water Usage Summary (S&W-01)	Appendix 09
10.	Hazardous Material Deliveries (TRANS-3)	Appendix 10
11.	Visible Plant Structures Inspection (VIS-01).....	Appendix 11
12.	Plume Summary YTD (VIS-10)	Appendix 12
13.	Waste Management Report (WASTE-03)	Appendix 13
14.	Events of Non-Compliance	Appendix 14

**Metcalf Energy Center – 99-AFC-3
2024 Annual Compliance Report**

Project Status

The Metcalf Energy Center, LLC (MEC) declared commercial operation (COD) on May 29, 2005. MEC is dispatched into the merchant market by Calpine Energy Services (CES) and participates in the Ancillary Services market with the California ISO.

The Annual Compliance Report has been prepared in accordance with the General Conditions of the Compliance Plan.

- 1. An updated compliance matrix which shows the status of all conditions of certification (fully satisfied and/or closed conditions do not need to be included in the matrix after they have been reported as closed).**

The compliance matrix is included as an attachment. See Appendix 2.

- 2. A summary of the current project operating status and an explanation of any significant changes to facility operations during the year.**

The facility is currently operating in a normal status. There have been no significant changes to facility operations during the reporting year. See Appendix 3

- 3. Documents required by specific conditions to be submitted along with the Annual Compliance Report. Each of these items must be identified in the transmittal letter and should be submitted as attachments to the Annual Compliance Report.**

The documents required by specific conditions are included in this report as attachments and are identified in the transmittal letter.

- 4. A cumulative listing of all post-certification changes approved by the Energy Commission or cleared by the CPM.**

- Petition to maintain the facility's post-commissioning daily and annual emission limits amendment. Order number 05-0316—03, approved on March 16, 2005.
- **PENDING:** Petition for Staff approval of a clarification to the term, "Gas Turbine Cold Start-Up Period", contained in the Air Quality section of the Final Decision for the Metcalf Energy Center. Waiting on issuance of new Title V permit and Permit to Operate from the Bay Area Air District.

- 5. An explanation for any submittal deadlines that were missed, accompanied by an estimate of when the information will be provided.**

There are currently no outstanding submittals for the 2024 reporting period.

- 6. A listing of filings made to, or permits issued by, other governmental agencies during the year.**

- Annual compliance report submitted to CEC
 - Monthly Plume Abatement Status Reports
- Annual Permit to Operate BAAQMD
 - Monthly Air Reports

- Annual Title V Compliance Certification Report submitted to BAAQMD and EPA.
- Annual Hazardous Material Permit City of San Jose
 - Annual Hazardous Materials Business Plan Update and Certification
- Annual Fire Safety Permit City of San Jose
- Annual Business License City of San Jose.
- Annual Storm Water Report to the State Water Resources Control Board
- Annual EIA-923S and EIA-860A to the U.S. Department of Energy
- Quarterly Electronic Data Reporting to the EPA (40 CFR 75)
- Semi-Annual NSPS Report to the EPA
- Semi-Annual Title V Monitoring Reports
- Semi-Annual Wastewater Self-Monitoring Report to the City of San Jose
- Monthly EIA-923M to the U.S. Department of Energy
- All submittals, except as noted above, required under our permits have been made on time to include, for the 2024 reporting year.

7. A projection of project compliance activities scheduled during the next year.

Currently there are no compliance activities scheduled.

8. A listing of the year's additions to the on-site compliance file.

No additions have been made to the on-site compliance files as required by the Decision.

9. An evaluation of the on-site contingency plan for unplanned facility closure, including any suggestions necessary for bringing the plan up to date.

An evaluation of the on-site contingency plan for unexpected facility closure was conducted with no modifications. A copy of the plan is attached in Appendix 4.

In addition, insurance coverage for the site remains current.

10. A listing of complaints, notices of violation, official warnings, and citations received during the year, a description of the resolution of any resolved complaints, and the status of any unresolved complaints.

- **January 17th, 2024 - BAAQMD Complaint (reported to CEC – 01/18/24)** – BAAQMD received a complaint from a member of the public because they saw plumes coming from Metcalf at around 12:00 – 03:00 am on January 17th, 2024. They were concerned about excess emissions. The facility provided the daily compliance reports for the period to our inspector and informed them we were operating at the time and that everything was within normal operating ranges and permit limits. – **NO FURTHER ACTION**
- **February 5th, 2024 - BAAQMD Complaint (reported to CEC – 02/07/24)** – BAAQMD received a complaint from a member of the public because they saw plumes coming from Metcalf at around 23:30 pm on February 5th, 2024. They were concerned about excess emissions. The facility provided the daily compliance reports for the period to our inspector and informed them we were operating at the time and that everything was within normal operating ranges and permit limits. – **NO FURTHER ACTION**

CONDITIONS OF CERTIFICATION SPECIFIC REQUIREMENTS

- AQ-13 The Gas Turbines and the Heat Recovery Steam Generators shall be fired exclusively on natural gas.**

No violation of this condition occurred for the 2024 reporting year

- AQ-14 The combined heat input rate to each power train shall not exceed 2,124 mmBTU per hour, averaged over any rolling 3-hour period.**

No violation of this condition occurred for the 2024 reporting year

- AQ-15 The combined heat input rate to each power train shall not exceed 49,908 mmBTU per calendar day.**

No violation of this condition occurred for the 2024 reporting year.

- AQ-16 The combined cumulative heat input rate for the Gas Turbines and HRSGs shall not exceed 35,274,060 mmBTU per year.**

No violation of this condition occurred for the 2024 reporting year.

- AQ-17 The HRSG duct burners shall not be fired unless its associated gas turbine is in operation.**

No violation of this condition occurred for the 2024 reporting year.

- AQ-18 S-1 Gas Turbine and S-2 HRSG shall be abated by the properly operated and properly maintained A-1 Selective Catalytic Reduction (SCR) system whenever fuel is combusted at those sources and the A-1 catalyst bed has reached minimum operating temperature.**

No violation of this condition occurred for the 2024 reporting year.

- AQ-19 S-3 Gas Turbine and S-4 HRSG shall be abated by the properly operated and properly maintained A-2 Selective Catalytic Reduction (SCR) system whenever fuel is combusted at those sources and the A-2 catalyst bed has reached minimum operating temperature.**

No violation of this condition occurred for the 2024 reporting year.

- AQ-20 The Gas Turbines and HRSGs shall comply with emission requirements (a) through (h) under all operating scenarios, including duct burner firing mode and steam injection power augmentation mode. Requirements (a) through (h) do not apply during a gas turbine start-up or shutdown.**

There were instances of non-compliance with this condition that occurred in the 2024 reporting year. Please refer to Appendix 14 for details.

- AQ-21 The regulated air pollutant mass emission rates from each of the Gas Turbines during a start-up or a shutdown shall not exceed the limits.**

No violation of this condition occurred for the 2024 reporting year.

- AQ-22 The Gas Turbines shall not be in start-up mode simultaneously.**

No violation of this condition occurred for the 2024 reporting year.

- AQ-24** **Total combined emissions from the Gas Turbines and HRSGs including emissions generated from the cooling tower and during Gas Turbine start-ups and shutdowns shall not exceed the following limits during any calendar day.**
- No violation of this condition occurred for the 2024 reporting year.
- AQ-25** **Combined emissions from the gas turbines and HRSGs, including emissions generated from cooling towers and during gas turbine startups, shutdowns and tuning shall not exceed permit limits during any consecutive twelve (12) month period.**
- No violation of this condition occurred for the 2024 reporting year.
- AQ-26** **Maximum projected annual toxic air contaminants emissions from the gas turbines shall not exceed permit limits.**
- No violation of this condition occurred for the 2024 reporting year.
- AQ-27** **Properly operated and maintained continuous monitors.**
- Continuous monitors are properly operated and maintained.
- AQ-28** **To demonstrate compliance with conditions 20(f), 20(g), 20(h), 21, 24(c') through 24(e), and 25('c) through 25(e) the owner/operator shall calculate and record on a daily basis the POC, PM10, and SO2 mass emissions from each power train.**
- No violation of this condition occurred for the 2024 reporting year.
- AQ-29** **Calculate and record on an annual basis the maximum projected annual emissions of formaldehyde, benzene, and specific PAHs.**
- No violation of this condition occurred for the 2024 reporting year.
- AQ-36** **Notification to the District and CPM of any violations of permit conditions.**
- No violations occurred during the 2024 reporting year.
- AQ-44** **Compliance with the continuous emission monitoring requirements of 40 CFR Part 75.**
- No violation of this condition occurred for the 2024 reporting year. See Appendix 5
- AQ-56** **Cold Start-up hours shall not exceed 30 hours per calendar year for each turbine.**
- No violation of this condition occurred for the 2024 reporting year.
- BIO-2** **The CPM approved Designated Biologist shall submit record summaries in the Annual Compliance Report:**
- Designated Biologist summary for the 2024-2025 reporting year provided in Appendix 6
- HAZ-1** **Do not use any hazardous materials in reportable quantities not listed in attachment 1 or in greater quantities or strengths than those identified unless approved in advance by Santa Clara County and the CPM.**
- A hazardous material inventory is included as an attachment and is identified in the table of contents. See Appendix 7.

LAND-1 **At such time as a connection to a trail network can be made, install, and maintain the portion of planned trail that would cross the site.**

No trail updates have been made at this time. MEC is awaiting direction from the City of San Jose for trail construction.

PUBLIC HEALTH-1 **Perform a visual inspection of the cooling tower drift eliminators once per calendar year.**

The inspection sheet is included as an attachment and is identified in the table of contents. See Appendix 8.

SOIL & WATER-1 **Potable water may be used for cooling purposes only in the event that SBWR recycled water service is interrupted.**

A record of water consumption has been included and identified in the table of contents. See Appendix 9.

TRANS-3 **Ensure that all federal and state regulations for the transport of hazardous materials are observed during both construction and operation of the facility.**

No permits or licenses have been acquired concerning the transport of hazardous substances. A list of the hazardous materials deliveries received in 2024 is in Appendix 10.

VIS-1 **Treat the project structures, buildings, and tanks visible to the public in a non-reflective color.**

The plant's structures, buildings, and tanks have all been treated in accordance with this condition of certification. No treatment maintenance has been necessary. A copy of the inspection is in Appendix 11.

VIS-10 **The power plant shall be designed and operated to minimize visible plume.**

The total cooling tower plume hours for 2024 were 2 hours and 56 minutes, as noted in the December 2024 Plume Summary Log. A copy of the submitted log is in Appendix 12.

WASTE-3 **Document the actual waste management methods used during the year compared to planned management methods.**

No violation of this condition occurred. A waste management sheet is included as an attachment and is identified in the table of contents. See Appendix 13.

Appendix 2

METCALF ENERGY CENTER - COMPLIANCE MATRIX						
START OF COMERCIAL OPERATION		5/29/2005				
THROUGH YEAR END OF 2024		12/31/2024				
Condition No.	Requirements & Task Summary	Action required	Event	Required Submittal Date	Date submitted to CPM	Status/ Comments
AQ-13	GTs (S-1, S-3) and HRSG (S-2, S-4) shall be fired exclusively on natural gas. (BACT for SO ₂ and PM ₁₀)	As part of the semiannual Air Quality Reports, indicate the date, time, and duration of any violation of this condition.	Semiannual Air Quality Reports	Ongoing	Monthly and Semi-Annually	Ongoing
AQ-14	Combined heat input rate of each power train (S-1 & S-2, S-3 & S-4) shall not exceed 2,124 MMBtu/hr (3-hour rolling average) (PSD for NO _x)	As part of the Air Quality monthly Reports, include information on the date and time when the hourly fuel consumption exceed this hourly limit.	Monthly Air Quality Reports	Ongoing	Monthly	Ongoing
AQ-15	Combined heat input rate of each power train (S-1 & S-2 and S-3 & S-4) shall not exceed 49,908 MMBtu/day (PSD for PM ₁₀)	As part of the Air Quality monthly Reports, include information on the date and time when the hourly fuel consumption exceed this daily limit.	Monthly Air Quality Reports	Ongoing	Monthly	Ongoing
AQ-16	Combined cumulative heat input rate of GTs (S-1, S-3) and HRSGs(S-2, S-4) shall not exceed 35,274,060 MMBtu/yr. (Offsets)	As part of the Air Quality annual Reports, include information on the date and time when the annual cumulative fuel consumption exceed this annual limit	Monthly Air Quality Reports	Ongoing	Monthly	Ongoing
AQ-17	HRSGs (S-2, S-4) duct burners shall not be fired unless associated GTs (S-1, S-3) are in operation. (BACT for NO _x)	As part of the Air Quality Reports, include information on the date, time, and duration of any violation of this permit condition.	Air Quality Reports	Ongoing	Ongoing	Ongoing
AQ-18	GT/HRSG (S-1/S-2) shall be abated by the A-1 SCR system whenever fuel is combusted in these units and the A-1 catalyst bed has reached min. operating temperature.	As part of the Air Quality Reports, provide information on any major problem in the operation of the Oxidizing Catalyst and Selective Catalytic Reduction Systems for the Gas Turbines and HRSG's.	Semi-Annual Air Quality Reports	Ongoing	Semi-Annual	Ongoing
AQ-19	GT/HRSG (S-3/S-4) shall be abated by the A-2 SCR system whenever fuel is combusted in these units and the A-2 catalyst bed has reached min. operating temperature.	As part of the Air Quality Reports, provide info. on any major problem in the operation of the Oxidizing Catalyst and Selective Catalytic Reduction Systems for the Gas Turbines and HRSGs.	Semi-Annual Air Quality Reports	Ongoing	Semi-Annual	Ongoing
AQ-20(a)	Emission requirements: Emission Point P-1 NO _x = 19.2 lbs/hr [0.00904 lbs/MMBtu (HHV) of nat. gas fired] ; Emission Point P-2 NO _x = 19.2 lbs/hr [0.00904 lbs/MMBtu (HHV) of nat. gas fired] .	As part of the Semi-Annual Air Quality Reports, indicate the date, time, and duration of any violation. Include quantitative info. on the severity of the violation.	Semi-Annual Air Quality Reports	Ongoing	Semi-Annual	Ongoing
AQ-20(b)	NO _x Emission concentration = 2.5 ppmvd (corrected to 15% O ₂), 1-hr average (Emission Point P-1, P-2) (BACT for NO _x).	Same as above	Semi-Annual Air Quality Reports	Ongoing	Semi-Annual	Ongoing
AQ-20(c)	CO mass emission = 28.07 lbs/hr (at any 3-hour rolling avg.) (Emission Point P-1, P-2).	Same as above	Semi-Annual Air Quality Reports	Ongoing	Semi-Annual	Ongoing

METCALF ENERGY CENTER - COMPLIANCE MATRIX						
START OF COMERCIAL OPERATION		5/29/2005				
THROUGH YEAR END OF 2024		12/31/2024				
Condition No.	Requirements & Task Summary	Action required	Event	Required Submittal Date	Date submitted to CPM	Status/ Comments
AQ-20(d)	When the heat input to a CT exceeds 1700 MMBTU/hr (HHV), the CO emission concentration shall not exceed 6.0 ppmvd on dry basis and the CO mass emission rate shall not exceed 0.0132 lb/MMBTU at any 3-hr rolling average.	Same as above	Semi-Annual Air Quality Reports	Ongoing	Semi-Annual	Ongoing
AQ-20(e)	Ammonia (NH3) emission concentration shall not exceed 5 ppmvd on dry basis, at any 3-hour rolling avg. Ammonia injection rate to A-1, A-2 to be verified through continuous recording of rate.	Same as above	Semi-Annual Air Quality Reports	Ongoing	Semi-Annual	Ongoing
AQ-20(f)	Precursor organic compounds (POC) mass emissions (as CH4) shall not exceed 2.7 lbs/hr or 0.00126 lbs/MMBTU of natural gas fired. (Emission points P-1, P-2).	Same as above	Semi-Annual Air Quality Reports	Ongoing	Semi-Annual	Ongoing
AQ-20(g)	Sulfur dioxide (SO2) mass emissions at P-1, P-2 each shall not exceed 1.28 pounds per hour or 0.0006 lb /MM BTU of natural gas fired. (BACT)	Same as above	Semi-Annual Air Quality Reports	Ongoing	Semi-Annual	Ongoing
AQ-20(h)	PM10 mass emission s at P-1, P-2 each shall not exceed 9 pounds per hour or 0.00452 lb PM10/MM BTU. Particulate matter (PM10) mass emissions at P-1, P-2 each shall not exceed 12 pounds per hour or 0.00565 lb PM10/MM BTU, when HRSG duct burners are in operation.	Same as above	Semi-Annual Air Quality Reports	Ongoing	Semi-Annual	Ongoing
AQ-20(i)	Testing to confirm the PM10 emissions levels shall occur at least three (3) times per year during each of the first two (2) years of operation. Each year, at least one (1) monitoring test shall occur during winter months.	Same as above	Semi-Annual Air Quality Reports	Ongoing	Semi-Annual	Ongoing
AQ-21	GT (S-1, S-3) Start-up and Shutdown emission rates.	Same as above	Semi-Annual Air Quality Reports	Ongoing	Semi-Annual	Ongoing
AQ-22	Not more than one GT (S-1, S-2) shall be in start-up mode at any one time.	In the monthly compliance report the owner/operator shall indicate any violations of this condition.	Monthly Air Quality Reports	Ongoing	Ongoing	Ongoing
AQ-24	Total combined emissions in lbs/day, from GTs and HRSGs (S-1, S-2, S-3, S-4), including start-up and shutdown.	As part of the Air Quality Reports, indicate the date of any violation of this Condition including quantitative information on the severity of the violation.	Semi-Annual Air Quality Reports	Ongoing	Semi-Annual	Ongoing
AQ-25	Cumulative combined emissions in tons/any consecutive 12-month period, from GTs and HRSGs shall not exceed Nox = 123.4 (offsets), CO=588, POC=28 (offsets), PM10=91.3 (offsets), SO2=10.6 (cumulative increase).	As part of the Air Quality Reports, indicate the date of any violation of this Condition including quantitative information on the severity of the violation.	Air Quality Reports	Ongoing	Monthly/Annual	Ongoing

METCALF ENERGY CENTER - COMPLIANCE MATRIX						
START OF COMERCIAL OPERATION		5/29/2005				
THROUGH YEAR END OF 2024		12/31/2024				
Condition No.	Requirements & Task Summary	Action required	Event	Required Submittal Date	Date submitted to CPM	Status/ Comments
AQ-26	Maximum projected combined annual toxic air contaminant emissions from GTs and HRSGs (S-1, S-2, S-3, S-4). (a) formaldehyde = 3,796 lbs/yr (b) Benzene = 480 lbs/yr (c) PAHs=22.8 lbs/yr	As part of the annual Air Quality Reports, indicate the date, duration, and severity of any violation including quantitative information on the severity of the violation.	Annual Air Quality Reports	Ongoing	Monthly/Annual	Ongoing
AQ-26	Perform health risk assessment using emission rates per BAAQMD approved procedures and submit risk analysis to District and CPM.	As part of the annual Air Quality Reports, indicate the date of any violation of this Condition including quantitative information on the severity of the violation or submit risk analysis to District and CPM.	Within 60 days of source test date	Ongoing	Monthly/Annual	Ongoing
AQ-27 (a-d)	Demonstrate compliance with conditions 14-17, 20(a-d), 21, 22, 24(a), 24(b), 25(a), 25(b) by using continuous monitors during all operating hours for the following parameters.	As part of the annual Air Quality Reports, indicate the date of any violation of this Condition including quantitative information on the severity of the violation.	Annual Air Quality Reports	Ongoing	Monthly/Annual	Ongoing
AQ-27(e-f)	Use parameters in condition 27(a-d) and District approved methods to calculate the following. (e) Heat input rate for S-1 & S-2 combined, and S-3 & S-4 combined (f) Corrected NOx and CO concentrations and mass emissions at each exhaust point (P-1, P-2)	As part of the annual Air Quality Reports, indicate the date of any violation of this Condition including quantitative information on the severity of the violation.	Annual Air Quality Reports	Ongoing	Monthly/Annual	Ongoing
AQ-27(g-l)	For each source, source grouping, or exhaust point record parameters at least once every 15 minutes and calculate and record for the following. Refer to AQ-27 for further details.	As part of the annual Air Quality Reports, indicate the date of any violation of this Condition including quantitative information on the severity of the violation.	Annual Air Quality Reports	Ongoing	Monthly/Annual	Ongoing
AQ-28(a-b)	Demonstrate compliance with conditions 20, 21, 24, 25 by calculating and recording on a daily basis POC, PM10, and SO2 mass emissions fine PM10 and SO2 from each power train.	As part of the monthly Air Quality Reports, the owner/operator shall indicate the date of any violation including quantitative information on the severity of the violation.	Monthly Air Quality Reports	Ongoing	Monthly/Annual	Ongoing
AQ-29	Calculate and record on annual basis the max. projected annual emissions of formaldehyde, benzene, Specified Poly-Aromatic Hydrocarbons (PAH's).	As part of the annual Air Quality Reports, indicate the date of any violation of this Condition including quantitative information on the severity of the violation.	Annual Air Quality Reports	Ongoing	Annual	Ongoing
AQ-35	Maintain records and reports on site for a minimum of 5 years.	During site inspection, make all records and reports available to the District, California Air Resources Board, and CEC staffs.	AQ Inspection per AQ-35	Ongoing	Ongoing	Ongoing
AQ-36	Notify District and CPM of any violations of these permit conditions.	Submittal of these notifications as required by this condition is the verification of these permit conditions.	Violation of Permit Conditions	Ongoing	Ongoing	Ongoing
AQ-44	MEC shall comply with the continuous emission monitoring requirements of 40 CFR Part 75			Ongoing	Ongoing	Ongoing

METCALF ENERGY CENTER - COMPLIANCE MATRIX						
START OF COMERCIAL OPERATION		5/29/2005				
THROUGH YEAR END OF 2024		12/31/2024				
Condition No.	Requirements & Task Summary	Action required	Event	Required Submittal Date	Date submitted to CPM	Status/ Comments
AQ-45	Take monthly samples of natural gas combusted at MEC and analyze these samples for sulfur content using District-approved lab methods.	Maintain on site the records of all the guarantees received from its natural gas suppliers indicating that the fuel delivered to MEC complies with the 40 CFR Part 60, Subpart GG.	On-site Compliance Inspections	Ongoing	Monthly	Ongoing
AQ-47a	Perform visual inspection of cooling tower drift eliminators once per calendar year and repair or replace any drift eliminators which are broken or missing.	As part of the monthly Air Quality Reports, indicate the date of any violation of this Condition.	Air Quality Reports	Ongoing	Annual	Ongoing
AQ-53	The heat input to the fire pump diesel engine shall not exceed 211 MM BTU totaled over any consecutive twelve month period.	As part of the monthly Air Quality Reports, indicate the date of any violation of this Condition including quantitative information on the severity of the violation.	Air Quality Reports	Ongoing	Monthly	Ongoing
AQ-54	The total hours of operation of the emergency generator shall not exceed 200 hours per calendar year, plus an additional 100 hours per calendar year for the purposes of maintenance and testing.	As part of the monthly Air Quality Reports, indicate the date of any violation of this Condition including quantitative information on the severity of the violation.	Air Quality Reports	Ongoing	Annual	Ongoing
AQ-56	Cold Start-up hours shall not exceed 30 hours per calendar year for each Gas Turbine.	Provide dates and durations of any violation of this Condition to the CPM.	Air Quality Reports	Ongoing	Annual	Ongoing
AQ-57	Record start time, end time, and duration of Gas Turbine Cold Startup and Combustor Tuning Periods.	Make all records available to Agencies during inspection.	Ongoing	Ongoing	Ongoing	Ongoing
BIO-2	The CPM approved Designated Biologist shall perform the following during project construction and operation: see BIO-2 for detailed tasks.	Submit record summaries in the Annual Compliance Report.	Annual Compliance Report	Annual	Annual	Ongoing
BIO-12	Incorporate into closure plan measures that address the local biological resources and incorporate into the BRMIMP.	Address all biological resource-related issues associated with facility closure.	12 months prior to facility closure	Ongoing	12 months Prior to Closure	Ongoing
HAZ-1	Do not use any hazardous material in reportable quantities, not listed in Attachment 1 or in greater quantities or strengths than those identified unless approved in advance by Santa Clara County and the CPM.	Provide to the CPM and Santa Clara County, in the Annual Compliance Report, a list of hazardous materials contained at the facility in reportable quantities.	Annual Compliance Report	Ongoing	Annual	Ongoing
LAND-1	At such time as a connection to a trail network can be made, install and maintain the portion of the planned trail that would cross the site.	In the Annual Compliance Reports provide updates on trail developments in the area around the site.	Annual Compliance Report	Ongoing	Annual	Ongoing
NOISE-2	Throughout the construction and operation, document, investigate, evaluate and attempt to resolve all project related noise complaints.	File a copy of the Noise Complaint Resolution Form with City of San Jose and with the CPM documenting the resolution of the complaint.	30 days after receiving a noise complaint	Ongoing	Within 30 Days	Ongoing
PAL-7	Include in the facility closure plan a description regarding facility closure activity's potential to impact paleontological resources.	Include a description of closure activities in the facility closure plan.	12 months prior to facility closure	Ongoing	12 months Prior to Closure	Ongoing

METCALF ENERGY CENTER - COMPLIANCE MATRIX						
START OF COMERCIAL OPERATION		5/29/2005				
THROUGH YEAR END OF 2024		12/31/2024				
Condition No.	Requirements & Task Summary	Action required	Event	Required Submittal Date	Date submitted to CPM	Status/ Comments
Public Health-1	Perform a visual inspection of the cooling tower drift eliminators once per calendar year. Prior to initial operation of the project, have the cooling tower vendor's field representative inspect the cooling tower drift eliminator and certify that the installation was performed in a satisfactory manner.	The project owner shall include the results of the annual inspection of the cooling tower drift eliminators and a description of any repairs performed in the next required compliance report.	Annual Compliance Report	Ongoing	Annual	Ongoing
SOIL & WATER-1	Potable water may be used for cooling purposes only in the event that SBWR recycled water service is interrupted.	Provide a record of water consumption for the MEC.	Annual Compliance Report	Ongoing	Annual	Ongoing
TRANS-3	Ensure that all federal and state regulations for the transport of hazardous materials are observed.	Copies of all permits and licenses acquired concerning the transport of hazardous substances.	Annual Compliance Report	Ongoing	Annual	Ongoing
VIS-1	Treat the project structures, buildings, and tanks visible to the public in a non-reflective color.	The project owner shall provide a status report regarding treatment maintenance in the Annual Compliance Report.	Annual Compliance Report	Ongoing	Annual	Ongoing
VIS-11	Trail development along the Fisher Creek corridor adjacent to the power plant site.	The project owner shall submit to the City of San Jose and the County of Santa Clara Parks and Recreation Department for review and comment a specific plan.	Start of construction of the trail between Blanchard Road and railroad tracks	Ongoing	Ongoing	Ongoing
VIS-11	Trail development along the Fisher Creek corridor adjacent to the power plant site.	Submit to the CPM for review and approval a specific plan describing its landscape plan.	Start of construction of the trail between Blanchard Road and railroad tracks	Ongoing	Ongoing	Ongoing
VIS-11	Trail development along the Fisher Creek corridor adjacent to the power plant site.	Submit any required revisions.	Within 30 days of notification by the CPM.	Ongoing	Within 30 days	Ongoing
VIS-11	Trail development along the Fisher Creek corridor adjacent to the power plant site.	Notify the CPM, City of San Jose and County of Santa Clara Parks and Recreation Department that the planting installation is ready for inspection.	7 days after completion of planting installation	Ongoing	Within 7 days	Ongoing
WASTE-2	Upon becoming aware of any impending waste management-related enforcement action, notify the CPM of any such enforcement action.	Notify the CPM in writing within 10 days of becoming aware of an impending enforcement action.	Within 10 days of becoming aware of an impending enforcement action	Ongoing	Within 10 Days	Ongoing
WASTE-3	Prepare and submit to the CPM a waste management plan for all wastes generated during construction and operation of the facility.	In the Annual Compliance Reports, document the actual waste management methods used during the year compared to planned management methods.	Annual Compliance Report	8/1/06	Annual	Ongoing
Compliance matrix	A compliance matrix shall be submitted by along with each annual compliance report.	Submit compliance matrix to CPM	Annual Compliance Report	Ongoing	Annual	Ongoing

Appendix 3

Operating Data Summary January 2024 - December 2024

<u>Metcalf CT1</u>			<u>Metcalf CT2</u>			<u>Metcalf ST1</u>		
Date	Total Net MWh	Total Primary Fuel Quantity Burned (MMcf GG)	Date	Total Net MWh	Total Primary Fuel Quantity Burned (MMcf GG)	Date	Total Net MWh	Total Secondary Fuel Quantity Burned (MMcf GG)
January	120,908	1,356.1	January	122,067	1,393.6	January	150,379	124.74
February	98,166	1,088.0	February	110,822	1,252.1	February	126,087	72.94
March	56,702	636.2	March	110,100	1,289.2	March	102,964	68.81
April	-	-	April	-	-	April	-	-
May	344	9.9	May	-	-	May	-	-
June	58,648	672.1	June	53,488	619.1	June	71,452	59.05
July	88,872	1,003.4	July	109,860	1,264.8	July	131,377	132.64
August	93,631	1,041.6	August	94,336	1,070.7	August	120,755	99.25
September	64,123	727.2	September	52,908	605.6	September	74,745	66.25
October	95,850	1,001.2	October	71,021	738.0	October	103,635	67.40
November	66,841	739.1	November	62,518	707.4	November	72,931	6.72
December	92,517	1,032.3	December	86,747	981.7	December	105,898	51.72

Appendix 4



Metcalfe Energy Center, LLC.
On-Site Contingency Plan for Unplanned Temporary and
Permanent Facility Closure

Date	Description of Revision	Revision No.	Revised By:
6/01/2005	Planned Developed	1	Dana Petrin
8/08/2008	Plan reviewed and contacted information updated.	2	Rosemary Silva
8/24/2009	Annual Review – Updated the notification list, updated the chemical inventory.	3	Rosemary Silva
8/06/2010	Annual Review – Updated the chemical list and CEC contact	4	Rosemary Silva
8/29/2011	Annual Review – Update contact list and chemical list	5	Rosemary Silva
8/24/2012	Annual Review - Updated the contact information for the regulatory agencies. Also updated the chemical list included in the plan. The updated plan was submitted as part of the annual compliance report for reporting year 2011.	6	Rosemary Silva
8/19/2013	Annual Review – Updated contact information and chemical list. The updated plan was submitted as part of the annual compliance report for reporting year 2012.	7	Rosemary Silva
11/07/2014	Annual Review – Updated the Wastewater Inspector information	8	Rosemary Silva
12/30/2015	Annual Review – No Changes	-	Rosemary Silva
8/08/2016	Annual Review – Updated contact information for CEC and HazMat Inspector	9	Rosemary Silva
8/22/2017	Annual Review – Updated contact information for PGE	10	Rosemary Silva
8/10/2018	Annual Review – Updated contact information for City of San Jose Wastewater Inspector	11	Rosemary Silva
8/09/2019	Annual Review – No changes	-	Rosemary Silva
8/06/2020	Annual Review – No changes	-	Rosemary Silva
8/05/2021	Annual Review – Update to the contact information for Santa Clara Environmental Health Department	12	Rosemary Silva
7/27/2022	Annual Review – Updated the San Jose Fire Department Inspector contact information	13	Rosemary Silva
8/10/2023	Annual Review – No changes	-	Rosemary Silva
1/19/2024	Updated the PG&E Customer Rep name and email	14	Rosemary Silva
3/04/2024	Updated the PG&E Customer Rep name and email	15	Rosemary Silva
8/19/2024	Annual Review – updated the plan to include minor additions is to comply with the requirements of CPUC GO-167	16	Rosemary Silva
8/20/2025	Annual Review – No changes	-	Rosemary Silva



TABLE OF CONTENTS

1.0 PURPOSE.....	2
2.0 SCOPE.....	2
3.0 RESPONSIBILITIES.....	2
3.1 Plant Manager	2
3.2 Operations Manager and Maintenance Manager	2
3.3 EHS Specialist.....	2
4.0 GENERAL	2
4.1 Notification Procedures	2
4.2 Plant Shut Down Procedure.....	4
4.3 Site Security and Emergency Response.....	5
4.4 Hazardous Material and Waste Removal	5
5.0 INSURANCE AND WARRANTY COVERAGE	9
6.0 UNEXPECTED TEMPORARY CLOSURE	9
6.1 Transmission Line Engineering	9
6.2 Biological Resources	9
7.0 PERMANENT CLOSURE	9
7.1 Facility Closure Plan	9
7.2 Agency Notification	10
7.3 Site Security.....	10
7.4 Removal of Hazardous Materials and Waste	10
7.5 Biological, Cultural, And Paleontological Resources	10



1.0 PURPOSE

This plan was developed to provide an on-site contingency plan to ensure that the unexpected closure occurs in such a way that public health and safety and the environment are protected from adverse impacts. The plan covers written procedures concerning site security, hazardous materials and waste removal, and insurance and warranty coverage.

2.0 SCOPE

The plan was prepared in accordance with the California Energy Commission's (CEC) Decision, Docket Number 99-AFC-03 and covers the following facility:

Metcalfe Energy Center, LLC (MEC)
1 Blanchard Road
San Jose, CA 95013

Telephone Number: (408) 361-4900

Type and Nature of Business: SIC 4911 Electric Power Production

3.0 RESPONSIBILITIES

3.1 PLANT MANAGER

The Plant Manager has the overall responsibility for ensuring all provisions of this plan are administered and adhered to.

3.2 OPERATIONS MANAGER AND MAINTENANCE MANAGER

The Operations Manager and Maintenance Manager are responsible for overseeing the program, and notification to the CEC & CPUC.

3.3 EHS SPECIALIST

The EHS Specialist is responsible for assisting with any required agency notifications.

4.0 GENERAL

The unit or facility will remain in a ready for service condition until it has been affirmed that it is unneeded by all regulating bodies.

4.1 NOTIFICATION PROCEDURES

In the event of an unexpected temporary or permanent closure, the Plant Manager or designee shall notify the CEC Compliance Project Manager (CPM) and other responsible agencies within 24 hours and take all necessary steps to implement this Plan. Notification shall be made by either telephone or e-mail (see **Table 1**). The Operations Manager, Maintenance Manager, or EHS Specialist shall keep the CPM informed of the circumstances and expected duration of the closure.

90 days prior to the long-term status change of a unit or the facility the California Public Utilities Commission will be notified in writing with a description of the planned change.



The California Public Utilities Commission will be notified in writing 90 days prior to a change in facility ownership.

If it is determined that a temporary closure is likely to be permanent, or for a duration of more than twelve months, a closure plan consistent with CEC requirements for a planned closure shall be developed and submitted to the CPM within 90 days or the CPM's determination (or another period mutually agreed to by the owner and the CPM).

90 days prior to the long-term status change of a unit or the facility plans and/or procedures for storage and restart of the unit or facility will be provided to the California Public Utilities Commission.

TABLE 1 - AGENCIES TO BE NOTIFIED

California Energy Commission	
Anwar Ali Compliance Project Manager California Energy Commission 1516 9th St. Sacramento, CA 95814-5504	Tel: (916) 654-5020 Fax: (916) 651-8868 Email: anwar.ali@energy.ca.gov
San Jose Fire Department (Hazardous Materials)	
Farheen Sultana San Jose Fire Department 200 E. Santa Clara St., 2nd Fl. Tower San Jose, CA 95113	Email: farheen.sultana@sanjoseca.gov
Santa Clara Environmental Health Department	
Robin Ward Sr. Hazardous Materials Specialist 1555 Berger Dr. San Jose, CA 95112	Tel: (408) 918-1945 Email: robin.ward@cep.sccgov.org
Regional Water Quality Control Board	
San Francisco Bay Regional Water Quality Control Board-Region 2 1515 Clay St. Suite 1400 Oakland, CA 94612	Tel: (510) 622-2300 Fax: (510) 622-2460 Email: info2@waterboards.ca.gov
South Bay Water Recycling	
Pedro Hernandez South Bay Water Recycling Environmental Services Dept. City of San Jose 200 East Santa Clara Street, 4th Floor San Jose, CA 95131	Tel: (408) 794-6804 Email: pedro.hernandez@sanjoseca.gov



San Jose/Santa Clara Water Pollution Control Plant	
Kimberly DeVillier Environmental Inspector City of San Jose 200 E. Santa Clara Street, 7 th Floor San Jose, CA 95113	Tel: (408) 793-5359 Fax: (408) 271-1930 Email: kimberly.devillier@sanjoseca.gov
Bay Area Air Quality Management District	
Xuna Cai Senior Air Quality Engineer Engineering Division Bay Area Air Quality Management District 375 Beale Street, Suite 600 San Francisco, Ca 94105	Tel: (650) 420-3749 Email: xcai@baaqmd.gov
Pacific Gas and Electric	
Chad Stout Customer Service Representative PG&E 2230 Lake Washington Blvd West Sacramento, CA 95691	Tel: (831) 784-3333 Email: C5SR@pge.com
Cal-ISO	
CAL-ISO Outage Coordination P.O. Box 639014 Folsom, CA 95763-9014	Tel: (916) 351-2241
US Environment Protection Agency – Region IX	
US EPA Region IX 75 Hawthorne Street San Francisco, CA 94105-3901	Tel: (415) 972-3990 Fax: (415) 947-3579 Email: reo9@epa.gov
California Public Utilities Commission	
California Public Utilities Commission 505 Van Ness Avenue San Francisco, California 94102	Email: GO167@cpuc.ca.gov

4.2 PLANT SHUT DOWN PROCEDURE

In the event of a plant closure, MEC, personnel will shut down all operating equipment that is not necessary to respond to an emergency, in accordance with plant operating procedures. In the event of an emergency shutdown (e.g., fire, earthquake, sabotage, etc.), MEC personnel should consult the MEC Emergency Response Plan, ERP. The purpose of the ERP is to provide emergency response guidelines so that the MEC shift, and management personnel can adequately evaluate the situation and respond in the interests of protecting personnel, company resources, and the environment.



The ERP provides guidelines for emergencies, including accidental release of toxic gases, chemical spills, fires, explosions, bomb threats, civil disobedience, and personnel injuries. There are several situations that may require emergency response by site personnel. The response required for each situation may vary, and each requires a separate course of action. Personnel should reference the facility ERP for proper response.

4.3 SITE SECURITY AND EMERGENCY RESPONSE

The plant perimeter is surrounded by a chain link fence. The main gate is located on Blanchard Road. Remote cameras monitor the perimeter entry into the Plant 24 hours per day, 365 days per year by Control Room Personnel. The duties of the Plant Operators include checking plant security measures during the shift.

In the event of an unexpected closure, MEC will ensure that all fencing is intact and a manned guard or private security services it used to maintain site security, if necessary.

In the event of an emergency, the San Jose Fire Department (SJFD) will have access through the main gate via a Knox Box. Additionally, the SJFD has been supplied with a Hazardous Materials Business Plan, Risk Management Plan, and Fire Protection and Prevention Plan. The information contained in these plans will enable SJFD to respond to any emergency if the plant personnel have evacuated the premises.

4.4 HAZARDOUS MATERIAL AND WASTE REMOVAL

Handling and disposal of all hazardous materials and wastes shall be in accordance with all applicable laws, ordinances, regulations, and standards. Figure 1 identifies all hazardous materials that are located at MEC in reportable quantities. In the event of an unexpected temporary closure, not all hazardous materials will require removal. If such an event occurs, MEC will conduct visual inspections of all hazardous material storage vessels daily to assess container condition. This process can be done remotely via site cameras if necessary.

MEC has implemented a Hazardous Materials Business Plan, HMBP, to assist with the identification and handling of all hazardous materials. In addition to HMBP other plans have been developed to assist plant personnel and emergency responders with handling of hazardous materials located at MEC.

Refer to Figure 1 on the following Page.



FIGURE 1 - HAZARDOUS MATERIALS IN REPORTABLE QUANTITIES LOCATED AT METCALFE

CHEMICAL NAME	CHEMICAL LOCATION
*MISCELLANEOUS FLAMMABLE LIQUID, CLASS IB	MAINTENANCE SHOP
*MISCELLANEOUS FLAMMABLE LIQUID, CLASS IB	Steam Turbine Flammable Locker
*MISCELLANEOUS FLAMMABLE LIQUID, CLASS IB	PROPANE STORAGE
76 Triton 5005 GEO SAE 30	Lube Oil Storage
76 TURBINE OIL 68	Lube Oil Storage
76 TURBINE OIL 68	Combustion Turbine Lube Oil
ACETYLENE	MAINTENANCE SHOP
AMMONIA	Aqueous Ammonia Storage Area
ARGON / CARBON DIOXIDE	MAINTENANCE SHOP
ARGON, COMPRESSED	MAINTENANCE SHOP
ARGON, COMPRESSED	CYLINDER GAS STORAGE
ARGON/CARBON MONOXIDE	CYLINDER GAS STORAGE
CALIBRATION GAS (NITROGEN, CARBON MONOXIDE)	CYLINDER GAS STORAGE
CARBON DIOXIDE	MAINTENANCE SHOP
CARBON DIOXIDE	VARIOUS
CHEMTREAT BL-152	Boiler Water Chemical Treatment Area
CHEMTREAT BL-152	WATER TREATMENT BUILDING
CHEMTREAT BL1794	Boiler Water Chemical Treatment Area
CHEMTREAT BL-8301	WATER TREATMENT BUILDING
CHEMTREAT BL-8401	WATER TREATMENT BUILDING
CHEMTREAT BL-8401	Boiler Water Chemical Treatment Area
CHEMTREAT CL2250	WATER TREATMENT BUILDING
CHEMTREAT CL243	Cooling Tower Chemical Treatment Area
CHEMTREAT CL-2875	WATER TREATMENT BUILDING
CHEMTREAT CL4500	Cooling Tower Chemical Treatment Area
CHEMTREAT P873L	WATER TREATMENT BUILDING
CHEMTREAT RL1245	WATER TREATMENT BUILDING
CHEMTREAT RL9007	WATER TREATMENT BUILDING
CHEMTREAT-BL-1794	WATER TREATMENT BUILDING
CONNTECT 6000	WATER TREATMENT BUILDING
CONOCO PHILLIPS MEGA FLOW 32	BOILER FEED PUMPS
CONOCO PHILLIPS TURBINE OIL 32	STEAM TURBINE PACKAGE
CT WATER WASH	CT WASH WATER SUMP
DEBRIS/RAGS CONTAMINATED WITH PETROLEUM/OIL	Hazardous Material Storage Area
DIESEL	Fire Pump House
DIESEL EXHAUST FLUID	Steam Turbine Under Deck
DIESEL FUEL	Steam Turbine Flammable Locker



CHEMICAL NAME	CHEMICAL LOCATION
DOLOMITIC HYDRATED LIME	Steam Turbine Under Deck
FLOODED LEAD-CALCIUM BATTERY	SWITCH YARD
FYRQUEL EHC PLUS	Lube Oil Storage
FYRQUEL EHC PLUS	Steam Turbine Under Deck
GASOLINE	Steam Turbine Flammable Locker
HELIUM	CYLINDER GAS STORAGE
HYDRO HEAT	MAINTENANCE SHOP
HYTRANS 61	GSU Transformers
HYTRANS 61	AUXILLARY TRANSFORMERS
HYTRANS 61	STATION SERVICE TRANSFORMERS
LEAD-ACID BATTERY	BALANCE OF PLANT
LEAD-ACID BATTERY	COMBUSTION TURBINE #1
LEAD-ACID BATTERY	COMBUSTION TURBINE #2
LEAD-ACID BATTERY	DIESEL FIRE PUMP HOUSE
LUBRICATING OIL	FUEL GAS COMPRESSORS
Megaflow AW HVI Hydraulic Oil	Lube Oil Storage
MISCELLANEOUS LUBE OIL	Lube Oil Storage
MOBIL DTE 26	Lube Oil Storage
MOBIL DTE 26	CT CONTROL OIL TANK
MOBIL DTE 26	Steam Turbine Under Deck
MULTIPURPOSE R+O OIL 220	Lube Oil Storage
NITROGEN	CYLINDER GAS STORAGE
NITROGEN	UNIT 2 NITROGEN STORAGE
NITROGEN	UNIT 1 NITROGEN STORAGE
NITROGEN / NITRIC OXIDE CALIBRATION GAS	CYLINDER GAS STORAGE
NITROGEN / NITRIC OXIDE CALIBRATION GAS	UNIT 1 CEMS GASES
NITROGEN / NITRIC OXIDE CALIBRATION GAS	UNIT 2 CEMS GASES
NITROGEN / OXYGEN CALIBRATION GAS	CYLINDER GAS STORAGE
NITROGEN / OXYGEN CALIBRATION GAS	UNIT 1 CEMS GASES
NITROGEN / OXYGEN CALIBRATION GAS	UNIT 2 CEMS GASES
NITROGEN, COMPRESSED	AUXILLARY TRANSFORMERS
NITROGEN/CARBON MONOXIDE CALIBRATION GAS	UNIT 1 CEMS GASES
NITROGEN/CARBON MONOXIDE CALIBRATION GAS	UNIT 2 CEMS GASES
OXYGEN	MAINTENANCE SHOP
Oxygen	CYLINDER GAS STORAGE
Phillips Turbine Oil 100	Lube Oil Storage
PROPANE	PROPANE STORAGE
Release Number 1 VOC	Lube Oil Storage
Reolube HYD 46	Lube Oil Storage



CHEMICAL NAME	CHEMICAL LOCATION
Shell Morlina S3 BA 220	Steam Turbine Under Deck
Shell Morlina S3 BA 220	Lube Oil Storage
SHELL TELLUS OIL	Lube Oil Storage
Shell Turbo Oil DR 46	Lube Oil Storage
Shell Turbo Oil DR 46	STEAM TURBINE CONTROL OIL TANK
SHELL TURBO OIL T 32	Steam Turbine Under Deck
Sodium Carbonate, Anhydrous	Connex Near Storm Water Pond
SODIUM HYPOCHLORITE 12.5%	Cooling Tower Chemical Treatment Area
SODIUM HYPOCHLORITE 12.5%	WATER TREATMENT BUILDING
SULFUR HEXAFLUORIDE	SWITCH YARD
SULFURIC ACID 93%	Cooling Tower Chemical Treatment Area
TURBO T OIL 32	Lube Oil Storage
USED OIL	Hazardous Material Storage Area
USED OIL	OIL/WATER SEPARATOR
USED OIL	Steam Turbine Under Deck
USED OIL FILTERS	Hazardous Material Storage Area
Vaprotec Light	Lube Oil Storage

4.4 HAZARDOUS MATERIAL AND WASTE REMOVAL, continued

Whenever practical, hazardous materials will be returned to the vendor or transferred to another Calpine site that has the need for the material(s). The following transporters or other qualified transporters will be used if it is deemed necessary to remove any hazardous material(s).

TRANSPORTER	TELEPHONE NUMBER
Bayview Environmental	510-562-6181
Hill Brothers Chemical Company	408-421-0043

If the unexpected temporary closure also results in a release of hazardous materials or waste, plant personnel will consult the Emergency Response Plan, HMBP, and/or Risk Management Plan. These plans address accidental release prevention and emergency policies, a hazardous materials inventory, employee training, and location of safety equipment, main utility shutoffs, notification methods, and accident investigation procedures.

In addition, the Storm Water Pollution Prevention Plan, SWPP, and the Spill Prevention Control and Countermeasure Plan, SPCC, describe the necessary actions in the event of a spill that might threaten off site locations. Both structural and non-structural Best Management Practices (BMPs) are utilized at the site to reduce pollutants in storm water discharge. Structural BMPs include such measures as valves, berms, curbs, and containment structures that are used to hold or divert storm water. Non-structural BMPs include such measures as regular inspections, good housekeeping, employee training, and special procedures for storing/loading hazardous materials and wastes. Plant personnel shall consult all these plans prior to proceeding with any hazardous material or waste removal.



5.0 INSURANCE AND WARRANTY COVERAGE

MEC is insured under an “All-Risk” Builder’s Risk policy for property damage and business interruption. The policy is provided by several insurance companies led by Underwriters at Lloyds of London. Liability insurance is provided by Liberty Mutual.

6.0 UNEXPECTED TEMPORARY CLOSURE

If the MEC closed temporarily, there are additional tasks to be performed, including notifications for areas of transmission line engineering and biological resources.

6.1 TRANSMISSION LINE ENGINEERING

MEC signed a third-party Generator Interconnection Agreement (GIA), with PG&E and CAISO. In the event of a planned, unexpected temporary, and unexpected permanent closure contact shall be made with PG&E and Cal ISO to ensure compliance with all applicable laws, ordinances, regulations, and standards (LORS), and that system safety and reliability will not be jeopardized.

6.2 BIOLOGICAL RESOURCES

In the case of temporary closure, measures to protect biological resources would be needed only if there was a potential to surface disturbances or releases of harmful materials. If such an event occurs, MEC will consult with responsible agencies to plan clean up and mitigation of impacts to biological resources.

7.0 PERMANENT CLOSURE

In the event the MEC is closed permanently, there are additional tasks that need to be performed, including preparing a facility closure plan, notifying agencies, ensuring site security, removing hazardous materials and waste.

7.1 FACILITY CLOSURE PLAN

To ensure that the permanent closure does not create adverse impacts, a closure process will be undertaken by MEC that provides for careful consideration of available options, applicable laws, ordinances, regulations, standards, and local plans in existence at the time of closure. MEC will meet with the CEC and other agencies as necessary prior to the development of the closure plan to establish the elements of the plan. In accordance with CEC Conditions of Certification, the plan will include the following:

- 1) Identify and discuss any impacts and mitigation to address significant adverse impacts associated with proposed closure activities and to address facilities, equipment, or other project related remnants that will remain at the site.
- 2) Identify a schedule of activities for closure of the power plant site, transmission line corridor, and all other appurtenant facilities constructed as part of the project.
- 3) Identify any facilities or equipment intended to remain on site after closure, the reason, and any future use.
- 4) Address conformance of the plan with all applicable laws, ordinances, regulations, standards, local/regional plans in existence at the time of facility closure, and applicable conditions of certification.



-
- 5) Removal of transmission conductors when they are no longer used or useful.
 - 6) Removal of all power plant site facilities and related facilities.
 - 7) Measures to restore wildlife habitat to promote the re-establishment of native plant and wildlife species.
 - 8) Revegetation of the plant site and other disturbed areas utilizing appropriate seed mixture.

The plan will be submitted to the CEC CPM, Santa Clara County, and City of San Jose for review and approval at least 12 months (or other mutually agreed to time) prior to commencing the permanent closure activities.

7.2 AGENCY NOTIFICATION

Additional notification may be necessary in the event of a permanent closure, including re-notifying each of the agencies listed in Table 1. The Closure Plan will also be sent to those appropriate agencies with which MEC has a current permit (e.g., Regional Water Quality Control Board, Bay Area Air Quality Management District, USEPA, etc.)

7.3 SITE SECURITY

Prior to permanent closure, the Plant Manager or designee will notify the San Jose Fire Department and City of San Jose Police Department, giving the notice that the existing level of site surveillance will not be in effect. This will enable these agencies to respond appropriately in the event of a disturbance or fire. It may be necessary for MEC to provide site security for a period following permanent closure, the Plant Manager or designee will determine the need for such interim security and will address it in the Closure Plan, if necessary.

7.4 REMOVAL OF HAZARDOUS MATERIALS AND WASTE

As required by the CEC Commission Decision, MEC is responsible for removing all hazardous materials from the site as part of permanent site closure. If MEC intends to redevelop the site, other plans may be made to either remove or store materials in different locations. The details of the removal will be covered in the Closure Plan.

7.5 BIOLOGICAL, CULTURAL, AND PALEONTOLOGICAL RESOURCES

When a permanent Closure Plan is prepared, it will include the take avoidance and mitigation requirements in effect at the time for the species that would be impacted. The plan will also include the removal of the transmission facilities when they are no longer used and useful and reclamation of areas where facilities would be removed. This may include ripping of soil contouring of disturbed areas, implementation of erosion control, revegetation, and other measures deemed appropriate at the time the Closure Plan is developed.

Biological resources compliance reporting for closure activities would likely include pre-activity survey reports, environmental monitoring reports during reclamation, and a final report describing the closure activities and any follow-on reclamation work that would be required.

The permanent Closure Plan will include a description regarding the potential of the closure activities to impact cultural and paleontological resources. The closure requirements are to be based upon the Cultural Resources and Paleontological Resources Final Report. If no activities are proposed that would



potentially impact either of these resources, no mitigation measures will be required. Should a discovery be made, it will be necessary to update the Cultural Resources and Paleontological Resources final report.

The facility will comply with all COC's including contracting with qualified Cultural, Paleontological, Native American and Biological Monitors when condition require. These monitors will be identified in the final Closure Plan if required.

Appendix 5



ECMPS Client Tool

Version 1.* 2024 Q1

United States Environmental Protection Agency (EPA)
Emissions Collection and Monitoring Plan System (ECMPS) Feedback

January 16, 2025 09:37 AM

Re: Metcalf Energy Center (55393) - 1

Dear Certifying Official:

Thank you for submitting your Quarterly Emissions Report using the U. S. EPA's Emissions Collection and Monitoring Plan System (ECMPS) software. This ECMPS Feedback report provides you with a detailed submission receipt, a summary of the evaluations performed on your submission, and guidance on any follow-up actions needed if any errors were found. EPA has also received a copy of this Feedback Report as part of your submission.

SUBMISSION STATUS

The EPA has received your Quarterly Emissions Report for the Facility and Monitoring Location(s) listed in Table 1 below. The Table also provides confirmation of EPA's receipt (Date, Time, etc.) of your submission. Prior to submission ECMPS evaluated your emissions report and assigned an overall "Feedback Status Level" to it, based on the results (see Table 1). This Feedback Report also contains Table 2, which displays EPA-Accepted Cumulative Values for emissions and other parameters.

Table 1: Submission Receipt and Feedback Status Level Information

Report Received for Facility ID (ORIS Code):	55393
Facility Name:	Metcalf Energy Center
State:	CA
Monitoring Locations:	1
Submission Type:	EM for 2024 QTR 4
Feedback Status Level:	No Errors
Submission Date/Time:	01/16/2025 9:36:59 AM
Submitter User ID:	rsilva
Submission ID:	1732959
Resubmission Required:	No
EPA Analyst:	Bryan Ramirez; (202) 564-7591; ramirez.bryan@epa.gov

EXPLANATION OF YOUR FEEDBACK STATUS LEVEL LISTED IN TABLE 1

The EPA has accepted your Emissions data submission. ECMPS detected no errors in your data based on the checks performed. NOTE: The ECMPS submission access window for this Emissions report has been closed. If you need to resubmit this data, please see the DATA RESUBMISSION guidance, below.

OTHER INFORMATION AND BULLETINS FROM EPA

QUESTIONS: Please contact your EPA Analyst listed in Table 1 with any questions regarding this submission and the evaluation results. If you need assistance with correcting problems in the Emissions data for this facility, please send an email to ECMPS Technical Support at: ecmps-support@camdsupport.com.

DATA RESUBMISSION: If you need to resubmit emissions data, including for previous calendar quarters, please complete the ECMPS Data Resubmission Request Form located at: https://ecmps.camdsupport.com/help_resubmit_form.shtml. Please provide detailed documentation of the reasons for the resubmission. Support staff will review your request and notify you via e-mail when the necessary database access window has been granted for your resubmission.

ECMPS Data Reporting Instructions: for detailed information about reporting Monitoring Plan, QA/Certification Test, and Emissions data, please see the ECMPS Reporting Instructions on EPA's website at: <https://www.epa.gov/power-sector/ecmps-reporting-instructions>.

If you have any questions regarding this correspondence, please feel free to contact your EPA Analyst listed in Table 1 as soon as possible. Thank you for your attention to this matter.

Facility Name: Metcalf Energy Center

Facility ID (ORISPL): 55393 State: CA

ECMPS Feedback

January 16, 2025 09:37 AM

Table 2: Cumulative Data Summary -- EPA-Accepted Values

Unit/Stack/Pipe ID: 1

	1st Quarter	2nd Quarter	3rd Quarter	4th Quarter	Ozone Season	Year-to-Date
Number of Operating Hours	1,712	444	1,654	1,616		5,426
Operating Time (hrs)	1,694.91	424.55	1,629.50	1,598.53		5,347.49
SO2 Mass (tons)	1.0	0.2	0.9	0.9		3.0
CO2 Mass (tons)	192,248.1	42,854.2	175,465.2	174,597.1		585,164.6
Heat Input (mmBtu)	3,234,976	721,114	2,952,551	2,937,942		9,846,583
NOx Emission Rate (lb/mmBtu)	0.008	0.013	0.008	0.008		0.008



ECMPS Client Tool

Version 1.* 2024 Q1

United States Environmental Protection Agency (EPA)
Emissions Collection and Monitoring Plan System (ECMPS) Feedback

January 16, 2025 09:38 AM

Re: Metcalf Energy Center (55393) - 2

Dear Certifying Official:

Thank you for submitting your Quarterly Emissions Report using the U. S. EPA's Emissions Collection and Monitoring Plan System (ECMPS) software. This ECMPS Feedback report provides you with a detailed submission receipt, a summary of the evaluations performed on your submission, and guidance on any follow-up actions needed if any errors were found. EPA has also received a copy of this Feedback Report as part of your submission.

SUBMISSION STATUS

The EPA has received your Quarterly Emissions Report for the Facility and Monitoring Location(s) listed in Table 1 below. The Table also provides confirmation of EPA's receipt (Date, Time, etc.) of your submission. Prior to submission ECMPS evaluated your emissions report and assigned an overall "Feedback Status Level" to it, based on the results (see Table 1). This Feedback Report also contains Table 2, which displays EPA-Accepted Cumulative Values for emissions and other parameters.

Table 1: Submission Receipt and Feedback Status Level Information

Report Received for Facility ID (ORIS Code):	55393
Facility Name:	Metcalf Energy Center
State:	CA
Monitoring Locations:	2
Submission Type:	EM for 2024 QTR 4
Feedback Status Level:	No Errors
Submission Date/Time:	01/16/2025 9:38:01 AM
Submitter User ID:	rsilva
Submission ID:	1732966
Resubmission Required:	No
EPA Analyst:	Bryan Ramirez; (202) 564-7591; ramirez.bryan@epa.gov

EXPLANATION OF YOUR FEEDBACK STATUS LEVEL LISTED IN TABLE 1

The EPA has accepted your Emissions data submission. ECMPS detected no errors in your data based on the checks performed. NOTE: The ECMPS submission access window for this Emissions report has been closed. If you need to resubmit this data, please see the DATA RESUBMISSION guidance, below.

OTHER INFORMATION AND BULLETINS FROM EPA

QUESTIONS: Please contact your EPA Analyst listed in Table 1 with any questions regarding this submission and the evaluation results. If you need assistance with correcting problems in the Emissions data for this facility, please send an email to ECMPS Technical Support at: ecmps-support@camdsupport.com.

DATA RESUBMISSION: If you need to resubmit emissions data, including for previous calendar quarters, please complete the ECMPS Data Resubmission Request Form located at: https://ecmps.camdsupport.com/help_resubmit_form.shtml. Please provide detailed documentation of the reasons for the resubmission. Support staff will review your request and notify you via e-mail when the necessary database access window has been granted for your resubmission.

ECMPS Data Reporting Instructions: for detailed information about reporting Monitoring Plan, QA/Certification Test, and Emissions data, please see the ECMPS Reporting Instructions on EPA's website at: <https://www.epa.gov/power-sector/ecmps-reporting-instructions>.

If you have any questions regarding this correspondence, please feel free to contact your EPA Analyst listed in Table 1 as soon as possible. Thank you for your attention to this matter.

Facility Name: Metcalf Energy Center

Facility ID (ORISPL): 55393 State: CA

ECMPS Feedback

January 16, 2025 09:38 AM

Table 2: Cumulative Data Summary -- EPA-Accepted Values

Unit/Stack/Pipe ID: 2

	1st Quarter	2nd Quarter	3rd Quarter	4th Quarter	Ozone Season	Year-to-Date
Number of Operating Hours	2,183	376	1,704	1,385		5,648
Operating Time (hrs)	2,182.80	366.50	1,680.86	1,370.54		5,600.70
SO2 Mass (tons)	1.2	0.2	0.9	0.8		3.1
CO2 Mass (tons)	244,399.2	39,202.4	186,823.0	153,241.6		623,666.2
Heat Input (mmBtu)	4,112,465	659,640	3,143,676	2,578,551		10,494,332
NOx Emission Rate (lb/mmBtu)	0.006	0.009	0.007	0.007		0.007

Appendix 6

2101 Webster Street
Suite 1410
155 Grand Avenue
Suite 800
Oakland, CA 94612
United States
T +1.510.251.2426
www.jacobs.com

Subject	Metcalf Energy Center – Year 2025 Annual Compliance Report for Biological Resources (COC BIO-2)
Facility Name	Metcalf Energy Center
Attention	Rosemary Silva/Calpine
From	Scott Lindemann/Jacobs
Date	June 26, 2025
Copies to	Joe Aguirre/Jacobs

1. Introduction

This Metcalf Energy Center (MEC) Year 2025 Annual Compliance Report for Biological Resources fulfills the California Energy Commission (CEC) requirement for Condition of Certification (COC) BIO-2, "Designated Biologist Duties." BIO-2 states that the Designated Biologist (DB) will perform the stated duties of BIO-2 relating to "any site (or related facilities) mobilization, ground disturbance, grading, construction, operation, and closure activities." In support of COC BIO-2, the DB is required to maintain written records of the tasks specified previously and those included in the Biological Resources Mitigation Implementation and Monitoring Plan (BRMIMP). Summaries of these records will be submitted in the annual compliance report.

The BRMIMP for the MEC was prepared in July 2001 as required under the COC BIO-4 set forth by the CEC in their final decision dated October 1, 2001 (99-AFC-3). The purpose of the BRMIMP is to ensure that actions authorized, funded, or carried out by state or federal lead agencies are not likely to jeopardize the continued existence of endangered, threatened, or other special-status species. The BRMIMP describes mitigation measures and guidance to protect biological resources within the project area.

2. Project Location

The MEC is a 600-megawatt natural gas-fired combined cycle power plant operated by Calpine. The MEC is located at the southern edge of the City of San Jose in Santa Clara County. Specifically, the 14.2-acre site is located on the northwestern portion of the Morgan Hill United States Geological Survey quadrangle (Township 8S, Range 2E). The site comprises a 10.9-acre footprint and 3.3-acre riparian corridor. Monterey Road and the Union Pacific Railroad immediately border the MEC site on the east, and farmed agricultural land borders the MEC site to the south. Site access is currently from a railroad overcrossing off Monterey Road, between Metcalf Road to the north and Blanchard Road to the south.

3. Monitored Activities

Since the MEC became operational, Calpine has complied with applicable CEC COCs and periodically consulted with the DB. This 2025 reporting period covers the period between January 2024 and

December 2024. The monitoring and compliance efforts for the subject year are documented further in this section and in Attachment 1 – Site Photographs.

A biological site walkthrough was completed by CEC-approved DB Scott Lindemann (Jacobs), on June 9, 2025. The purpose of the biological site walkthrough was to identify biological concerns and carry out a general monitoring survey.

During the biological site walkthrough, ground squirrel (*Otospermophilus beecheyi*) burrows were recorded within the MEC site on the northern boundary of the detention pond (Attachment 1, Photograph 4). While suitable burrows were observed, evidence of occupancy by burrowing owl (*Athene cunicularia*) such as feathers and white-wash was not detected.

Calpine staff noted that a rock pigeon (*Columba livia*) infestation occurred in approximately 2016, which resulted in excessive fecal waste presenting hazardous conditions to employees. As such, a falconer was employed to control the rock pigeon population on site. The falconer was not active during the 2025 reporting period. No rock pigeon infestation has occurred since these abatement measures were introduced. It is noted that rock pigeon is not afforded protection under the Migratory Bird Treaty Act of 1918 (*United States Code* Title 16, Sections 703–712).

The DB verified that all site personnel are provided training regarding the protected species that may be present in or around the MEC. The training slides are provided in Attachment 2.

4. Conclusion

The MEC has demonstrated continued compliance with biological mitigation and protection measures included in the COCs and BRMIMP that are applicable to operation of the facility for the period of January 2024 to December 2024. The DB will remain available to assist with any investigation and biological compliance issues that may arise.

Attachment 1 Site Photographs



Photograph 1. Trees along southern boundary of MEC site. June 9, 2025.



Photograph 2. Southwest site boundary of the MEC site. June 9, 2025.



Photograph 3. Detention pond in southwest area of the MEC site. June 9, 2025.



Photograph 4. Ground squirrel burrows bordering the detention ponds; southeast of MEC site. June 9, 2025.



Photograph 5. Built infrastructure within the MEC site. June 9, 2025.



Photograph 6. Boundary treatment along the western site boundary of MEC. June 9, 2025.



Photograph 7. Built infrastructure within the MEC site. June 9, 2025.



Photograph 8. Trees along entrance roadway at front gate to MEC site. June 9, 2025.

Attachment 2 Contractor Orientation

Contractor Orientation Biological Resources

Metcalf is situated in an ecologically diverse area.



Bay Checkerspot Butterfly



Burrowing Owl



Western Pond Turtle

This area is home to several threatened and endangered plants and animals, including the California Tiger Salamander, Western Pond Turtle, Burrowing Owl, and the Bay Checkerspot Butterfly.

DO NOT disturb or touch any wildlife you encounter onsite.

Report any wildlife encountered to the Control Room immediately.



California Tiger Salamander

Appendix 7

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility				Chemical Location	CERS ID 10096750					
Facility Name	Los Esteros Critical Energy Facility				4160 kV STATION SERVICE TRANSFORMERS	Facility ID FA0256442					
	800 THOMAS FOON CHEW WY, San Jose 95134					Status Submitted on 7/8/2025 12:14 PM					
								Hazardous Components (For mixture only)			
DOT Code/Fire Haz. Class	Common Name	Unit	Quantities			Annual Waste Amount	Federal Hazard Categories	Component Name	% Wt	EHS	CAS No.
DOT: 9 - Misc. Hazardous Materials	DIALA OIL AX	Gallons	Max. Daily	Largest Cont.	Avg. Daily		- Health	HIGHLY REFINED PETROLEUM OILS	100%		128-37-0
	CAS No	State	Storage Container		Pressue		Respiratory Skin				
	NA	Liquid	Other		Ambient	Waste Code	Sensitization				
	Map: 1	Type			Temperature						
	Grid: F8, E8	Mixture	Days on Site: 365		Ambient						

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility				Chemical Location	CERS ID 10096750			
Facility Name	Los Esteros Critical Energy Facility				480 V TRANSFORMERS	Facility ID FA0256442			
	800 THOMAS FOON CHEW WY, San Jose 95134					Status Submitted on 7/8/2025 12:14 PM			
					Quantities	Annual Waste Amount	Federal Hazard Categories	Hazardous Components (For mixture only)	
DOT Code/Fire Haz. Class	Common Name	Unit	Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt EHS CAS No.
DOT: 3 - Flammable and Combustible Liquids	DEILETRIC OIL	Gallons	2248	489	2248		- Physical		
	CAS No	State	Storage Container		Pressue		Flammable		
		Liquid	Other		Ambient	Waste Code	- Health Acute		
	Map: 1 Grid: C2, F7, C8, E7	Type			Temperature		Toxicity		
		Mixture	Days on Site: 365		Ambient				

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility				Chemical Location		CERS ID	10096750		
Facility Name	Los Esteros Critical Energy Facility				ADMIN BLDG OPEN AREA (1 BREAKER)		Facility ID	FA0256442		
800 THOMAS FOON CHEW WY, San Jose 95134							Status	Submitted on 7/8/2025 12:14 PM		
				Quantities		Annual Waste Amount	Hazardous Components (For mixture only)			
DOT Code/Fire Haz. Class	Common Name	Unit	Max. Daily	Largest Cont.	Avg. Daily	Federal Hazard Categories	Component Name	% Wt	EHS	CAS No.
DOT: 2.2 - Nonflammable Gases	SULFUR HEXAFLUORIDE (SF6)	Cu. Feet	128	24	24	- Physical Gas				
	CAS No	State	Storage Container		Pressue	Waste Code	Under Pressure			
	2551-62-4	Gas	Other		Ambient		- Health Simple			
	Map: 1 Grid: A10	Type			Temperature		Asphyxiant			
		Pure	Days on Site: 365		Ambient					

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility				Chemical Location	CERS ID 10096750			
Facility Name	Los Esteros Critical Energy Facility				AIR COMPRESSORS	Facility ID FA0256442			
800 THOMAS FOON CHEW WY, San Jose 95134						Status Submitted on 7/8/2025 12:14 PM			
								Hazardous Components (For mixture only)	
DOT Code/Fire Haz. Class	Common Name	Unit	Quantities			Annual Waste Amount	Federal Hazard Categories	Component Name	% Wt EHS CAS No.
DOT: 3 - Flammable and Combustible Liquids	LUBRICATING OIL	Gallons	98	49	98		- Physical		
	CAS No	State	Storage Container		Pressue		Flammable		
		Liquid	Other		Ambient	Waste Code	- Health Acute		
	Map: 1 Grid: C4	Type			Temperature		Toxicity		
		Mixture	Days on Site: 365		Ambient				

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility				Chemical Location		CERS ID	10096750		
Facility Name	Los Esteros Critical Energy Facility				AMMONIA STORAGE AREA		Facility ID	FA0256442		
	800 THOMAS FOON CHEW WY, San Jose 95134						Status	Submitted on 7/8/2025 12:14 PM		
				Quantities		Annual Waste Amount	Federal Hazard Categories	Hazardous Components (For mixture only)		
DOT Code/Fire Haz. Class	Common Name	Unit	Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt	EHS CAS No.
DOT: 8 - Corrosives (Liquids and Solids)	AMMONIUM HYDROXIDE 19%	Pounds	24741.81	14554	24741.81		- Physical			
	CAS No	State	Storage Container		Pressue		Corrosive To			
	1336-21-6	Liquid	Aboveground Tank		Ambient	Waste Code	Metal			
Corrosive	Map: 1 Grid: H6	Type			Temperature		- Health Acute			
		Mixture	Days on Site: 365		Ambient		Toxicity			
							- Health Skin			
							Corrosion			
							Irritation			
							- Health Serious			
							Eye Damage Eye			
							Irritation			

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org. Los Esteros Critical Energy Facility			Chemical Location				CERS ID	10096750		
Facility Name Los Esteros Critical Energy Facility			BOILER CHEMICAL SKID				Facility ID	FA0256442		
800 THOMAS FOON CHEW WY, San Jose 95134							Status	Submitted on 7/8/2025 12:14 PM		
DOT Code/Fire Haz. Class	Common Name	Unit	Quantities			Annual Waste Amount	Federal Hazard Categories	Hazardous Components (For mixture only)		
			Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt	EHS CAS No.
DOT: 8 - Corrosives (Liquids and Solids) Corrosive	CHEMTREAT BL-152	Gallons	400	400	400	0	- Physical	AMMONIUM HYDROXIDE	30%	✓ 1336-21-6
	CAS No	State	Storage Container		Pressue	Waste Code	Corrosive To	ETHANOLAMINE	10%	141-43-5
		Liquid	Aboveground Tank		Ambient		Metal			
	Map: 1 Grid: E5	Type			Temperature		- Health Acute			
		Mixture	Days on Site: 365		Ambient		Toxicity			
							- Health Skin			
DOT: 8 - Corrosives (Liquids and Solids) Corrosive	CHEMTREAT BL-17945	Gallons	400	400	400	0	- Physical	Sodium hydroxide	2%	1310-73-2
	CAS No	State	Storage Container		Pressue	Waste Code	Corrosive To	SODIUM PHOSPHATE	5%	7601-54-9
		Liquid	Aboveground Tank		Ambient		Metal			
	Map: 1 Grid: E5	Type			Temperature		- Health Acute			
		Mixture	Days on Site: 365		Ambient		Toxicity			
							- Health Skin			
DOT: 9 - Misc. Hazardous Materials	CHEMTREAT BL8401	Gallons	55	55	55		- Health Acute			
	CAS No	State	Storage Container		Pressue	Waste Code	Toxicity			
		Liquid	Plastic/Non-metalic Drum		Ambient		- Health Skin			
	Map: 1 Grid: E5	Type			Temperature		Corrosion			
		Mixture	Days on Site: 365		Ambient		Irritation			
							- Health Serious			
							Eye Damage Eye			
							Irritation			
							- Health Specific			
							Target Organ			
							Toxicity			

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility				Chemical Location	CERS ID 10096750			
Facility Name	Los Esteros Critical Energy Facility				BOILER FEED PUMPS	Facility ID FA0256442			
	800 THOMAS FOON CHEW WY, San Jose 95134					Status Submitted on 7/8/2025 12:14 PM			
					Quantities	Annual Waste Amount	Federal Hazard Categories	Hazardous Components (For mixture only)	
DOT Code/Fire Haz. Class	Common Name	Unit	Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt EHS CAS No.
	SHELL TELLAS S2 MX 32	Gallons	280	70	280		- Physical Hazard		
	CAS No	State	Storage Container		Pressue	Waste Code	Not Otherwise Classified		
		Liquid	Other		Ambient		- Health Hazard		
	Map: 1 Grid: E4, E7, D4, D7	Type			Temperature		Not Otherwise Classified		
		Mixture	Days on Site: 365		Ambient				

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility				Chemical Location	CERS ID	10096750			
Facility Name	Los Esteros Critical Energy Facility				CEMS STORAGE - UNIT 1	Facility ID	FA0256442			
	800 THOMAS FOON CHEW WY, San Jose 95134					Status	Submitted on 7/8/2025 12:14 PM			
						Annual Waste Amount	Federal Hazard Categories	Hazardous Components (For mixture only)		
DOT Code/Fire Haz. Class	Common Name	Unit	Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt	EHS CAS No.
DOT: 2.2 - Nonflammable Gases	NITROGEN / NITRIC OXIDE CALIBRATION GAS	Cu. Feet	1587.3	144.3	1587.3		- Physical Gas			
		State	Storage Container		Pressue	Waste Code	Under Pressure			
		Gas	Cylinder		Ambient		- Health			
		Type			Temperature		Respiratory Skin			
		Mixture	Days on Site: 365		Ambient		Sensitization			
	Map: 1 Grid: E5						- Health Serious			
							Eye Damage Eye			
							Irritation			
							- Health Specific			
							Target Organ			
							Toxicity			
DOT: 2.2 - Nonflammable Gases	NITROGEN / OXYGEN CALIBRATION GAS	Cu. Feet	865.8	144.3	865.8		- Physical Gas			
		State	Storage Container		Pressue	Waste Code	Under Pressure			
		Gas	Cylinder		Ambient		- Physical Oxidizer			
		Type			Temperature		- Health Acute			
		Mixture	Days on Site: 365		Ambient		Toxicity			
	Map: 1 Grid: E5						- Health Serious			
							Eye Damage Eye			
							Irritation			
							- Health Simple			
							Asphyxiant			
DOT: 2.2 - Nonflammable Gases	NITROGEN/CARBON MONOXIDE CALIBRATION GAS	Cu. Feet	1298.7	144.3	1298.7		- Physical Gas			
		State	Storage Container		Pressue	Waste Code	Under Pressure			
		Gas	Cylinder		Ambient		- Health			
		Type			Temperature		Respiratory Skin			
		Mixture	Days on Site: 365		Ambient		Sensitization			
	Map: 1 Grid: E5						- Health Serious			
							Eye Damage Eye			
							Irritation			
							- Health Simple			
							Asphyxiant			
DOT: 2.2 - Nonflammable Gases	NITROGEN/CARBON MONOXIDE/NITRIC OXIDE CALIBRATION GAS	Cu. Feet	576	144.3	432		- Physical Gas			
		State	Storage Container		Pressue	Waste Code	Under Pressure			
		Gas	Cylinder		Ambient		- Health			
		Type			Temperature		Respiratory Skin			
		Mixture	Days on Site: 365		Ambient		Sensitization			
	Map: 1 Grid: E5						- Health Serious			
							Eye Damage Eye			
							Irritation			
							- Health Simple			
							Asphyxiant			

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility	Chemical Location					CERS ID	10096750
Facility Name	Los Esteros Critical Energy Facility	CEMS STORAGE - UNIT 2					Facility ID	FA0256442
	800 THOMAS FOON CHEW WY, San Jose 95134						Status	Submitted on 7/8/2025 12:14 PM
						Annual Waste Amount	Hazardous Components (For mixture only)	
DOT Code/Fire Haz. Class	Common Name	Unit	Quantities			Federal Hazard Categories		
			Max. Daily	Largest Cont.	Avg. Daily		Component Name	% Wt EHS CAS No.
DOT: 2.2 - Nonflammable Gases	NITROGEN / NITRIC OXIDE	Cu. Feet	1587.3	144.3	1587.3		- Physical Gas	
	CALIBRATION GAS	State	Storage Container		Pressue	Waste Code	Under Pressure	
	CAS No	Gas	Cylinder		Ambient		- Health	
		Type			Temperature		Respiratory Skin	
	Map: 1 Grid: E6	Mixture	Days on Site: 365		Ambient		Sensitization	
							- Health Serious	
							Eye Damage Eye	
							Irritation	
							- Health Specific	
							Target Organ	
							Toxicity	
DOT: 2.2 - Nonflammable Gases	NITROGEN / OXYGEN	Cu. Feet	865.8	144.3	865.8		- Physical Gas	
	CALIBRATION GAS	State	Storage Container		Pressue	Waste Code	Under Pressure	
	CAS No	Gas	Cylinder		Ambient		- Physical Oxidizer	
		Type			Temperature		- Health	
	Map: 1 Grid: E6		Days on Site: 365		Ambient		Respiratory Skin	
							Sensitization	
							- Health Serious	
							Eye Damage Eye	
							Irritation	
							- Health Simple	
							Asphyxiant	
DOT: 2.2 - Nonflammable Gases	NITROGEN/CARBON MONOXIDE	Cu. Feet	1298.7	144.3	1298.7		- Physical Gas	
	CALIBRATION GAS	State	Storage Container		Pressue	Waste Code	Under Pressure	
	CAS No	Gas	Cylinder		Ambient		- Health	
		Type			Temperature		Respiratory Skin	
	Map: 1 Grid: E6	Mixture	Days on Site: 365		Ambient		Sensitization	
							- Health Serious	
							Eye Damage Eye	
							Irritation	
							- Health Simple	
							Asphyxiant	
DOT: 2.2 - Nonflammable Gases	NITROGEN/CARBON MONOXIDE/NITRIC OXIDE	Cu. Feet	576	144.3	432		- Physical Gas	
	CALIBRATION GAS	State	Storage Container		Pressue	Waste Code	Under Pressure	
	CAS No	Gas	Cylinder		Ambient		- Health	
		Type			Temperature		Respiratory Skin	
	Map: 1 Grid: E5	Mixture	Days on Site: 365		Ambient		Sensitization	
							- Health Serious	
							Eye Damage Eye	
							Irritation	
							- Health Simple	
							Asphyxiant	

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility					Chemical Location	CERS ID 10096750							
Facility Name	Los Esteros Critical Energy Facility					CEMS STORAGE - UNIT 3					Facility ID	FA0256442		
	800 THOMAS FOON CHEW WY, San Jose 95134											Status	Submitted on 7/8/2025 12:14 PM	
						Annual Waste	Federal Hazard		Hazardous Components					
						Amount	Categories		(For mixture only)					
DOT Code/Fire Haz. Class	Common Name	Unit	Max. Daily	Largest Cont.	Avg. Daily				Component Name	% Wt	EHS	CAS No.		
DOT: 2.2 - Nonflammable Gases	NITROGEN / NITRIC OXIDE CALIBRATION GAS CAS No Map: 1 Grid: D6	Cu. Feet	1587.3	144.3	1587.3			- Physical Gas						
		State	Storage Container		Pressue	Waste Code		Under Pressure						
		Gas	Cylinder		Ambient			- Health						
		Type			Temperature			Respiratory Skin						
		Mixture	Days on Site: 365		Ambient			Sensitization						
								- Health Serious						
								Eye Damage Eye						
								Irritation						
								- Health Specific						
								Target Organ						
								Toxicity						
DOT: 2.2 - Nonflammable Gases	NITROGEN / OXYGEN CALIBRATION GAS CAS No Map: 1 Grid: D6	Cu. Feet	865.8	144.3	865.8			- Physical Gas						
		State	Storage Container		Pressue	Waste Code		Under Pressure						
		Gas	Cylinder		Ambient			- Physical Oxidizer						
		Type			Temperature			- Health Acute						
		Mixture	Days on Site: 365		Ambient			Toxicity						
								- Health Serious						
								Eye Damage Eye						
								Irritation						
								- Health Simple						
								Asphyxiant						
DOT: 2.2 - Nonflammable Gases	NITROGEN/CARBON MONOXIDE CALIBRATION GAS CAS No Map: 1 Grid: D6	Cu. Feet	1298.7	144.3	1298.7			- Physical Gas						
		State	Storage Container		Pressue	Waste Code		Under Pressure						
		Gas	Cylinder		Ambient			- Health						
		Type			Temperature			Respiratory Skin						
		Mixture	Days on Site: 365		Ambient			Sensitization						
								- Health Serious						
								Eye Damage Eye						
								Irritation						
								- Health Simple						
								Asphyxiant						
DOT: 2.2 - Nonflammable Gases	NITROGEN/CARBON MONOXIDE/NITRIC OXIDE CALIBRATION GAS CAS No Map: 1 Grid: E5	Cu. Feet	576	144.3	432			- Physical Gas						
		State	Storage Container		Pressue	Waste Code		Under Pressure						
		Gas	Cylinder		Ambient			- Health						
		Type			Temperature			Respiratory Skin						
		Mixture	Days on Site: 365		Ambient			Sensitization						
								- Health Serious						
								Eye Damage Eye						
								Irritation						
								- Health Simple						
								Asphyxiant						

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility					Chemical Location	CERS ID	10096750		
Facility Name	Los Esteros Critical Energy Facility					CEMS STORAGE - UNIT 4	Facility ID	FA0256442		
	800 THOMAS FOON CHEW WY, San Jose 95134						Status	Submitted on 7/8/2025 12:14 PM		
						Annual Waste	Federal Hazard	Hazardous Components		
						Amount	Categories	(For mixture only)		
DOT Code/Fire Haz. Class	Common Name	Unit	Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt	EHS CAS No.
DOT: 2.2 - Nonflammable Gases	NITROGEN / NITRIC OXIDE	Cu. Feet	1587.3	144.3	1587.3		- Physical Gas			
	CALIBRATION GAS	State	Storage Container		Pressue	Waste Code	Under Pressure			
		Gas	Cylinder		Ambient		- Health			
	CAS No	Type			Temperature		Respiratory Skin			
	Map: 1 Grid: E6	Mixture	Days on Site: 365		Ambient		Sensitization			
							- Health Serious			
							Eye Damage Eye			
							Irritation			
							- Health Specific			
							Target Organ			
							Toxicity			
DOT: 2.2 - Nonflammable Gases	NITROGEN / OXYGEN	Cu. Feet	865.8	144.3	865.8		- Physical Gas			
	CALIBRATION GAS	State	Storage Container		Pressue	Waste Code	Under Pressure			
		Gas	Cylinder		Ambient		- Health Acute			
	CAS No	Type			Temperature		Toxicity			
	Map: 1 Grid: D5	Mixture	Days on Site: 365		Ambient		- Health Serious			
							Eye Damage Eye			
							Irritation			
							- Health Simple			
							Asphyxiant			
DOT: 2.2 - Nonflammable Gases	NITROGEN/CARBON MONOXIDE	Cu. Feet	1298.7	144.3	1298.7		- Physical Gas			
	CALIBRATION GAS	State	Storage Container		Pressue	Waste Code	Under Pressure			
		Gas	Cylinder		Ambient		- Health			
	CAS No	Type			Temperature		Respiratory Skin			
	Map: 1 Grid: D5	Mixture	Days on Site: 365		Ambient		Sensitization			
							- Health Serious			
							Eye Damage Eye			
							Irritation			
							- Health Simple			
							Asphyxiant			
DOT: 2.2 - Nonflammable Gases	NITROGEN/CARBON	Cu. Feet	576	144.3	432		- Physical Gas			
	MONOXIDE/NITRIC OXIDE	State	Storage Container		Pressue	Waste Code	Under Pressure			
	CALIBRATION GAS	Gas	Cylinder		Ambient		- Health			
	CAS No	Type			Temperature		Respiratory Skin			
	Map: 1 Grid: E5	Mixture	Days on Site: 365		Ambient		Sensitization			
							- Health Serious			
							Eye Damage Eye			
							Irritation			
							- Health Simple			
							Asphyxiant			

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility				Chemical Location		CERS ID	10096750		
Facility Name	Los Esteros Critical Energy Facility				CHILLER SKIDS		Facility ID	FA0256442		
800 THOMAS FOON CHEW WY, San Jose 95134							Status	Submitted on 7/8/2025 12:14 PM		
				Quantities		Annual Waste Amount	Federal Hazard Categories	Hazardous Components (For mixture only)		
DOT Code/Fire Haz. Class	Common Name	Unit	Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt	EHS CAS No.
DOT: 9 - Misc. Hazardous Materials	DUPONT HCFC-123	Pounds	7600	1900	7600		- Physical Hazard	2,2-DICHLORO-1,1,1-	100%	306-83-2
	CAS No	State	Storage Container		Pressue		Not Otherwise	TRIFLUOROETHANE		
	306-83-2	Liquid	Other		Ambient	Waste Code	Classified			
	Map: 1 Grid: F7	Type			Temperature		- Health			
		Pure	Days on Site: 365		Ambient		Respiratory Skin			
							Sensitization			
							- Health Specific			
							Target Organ			
							Toxicity			

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility				Chemical Location	CERS ID	10096750			
Facility Name	Los Esteros Critical Energy Facility				CIRC WATER PUMPS	Facility ID	FA0256442			
	800 THOMAS FOON CHEW WY, San Jose 95134					Status	Submitted on 7/8/2025 12:14 PM			
						Annual Waste	Hazardous Components			
						Amount	(For mixture only)			
DOT Code/Fire Haz. Class	Common Name	Unit	Quantities			Federal Hazard				
			Max. Daily	Largest Cont.	Avg. Daily	Categories	Component Name	% Wt	EHS	CAS No.
DOT: 9 - Misc. Hazardous Materials	SHELL MORLINA S3BA 150	Gallons	75	34	75	- Physical				
	CAS No	State	Storage Container		Pressue	Waste Code	- Health Acute			
		Liquid	Other		Ambient		Toxicity			
	Map: 1 Grid: F2	Type			Temperature		- Health Respiratory Skin Sensitization			
		Mixture	Days on Site: 365		Ambient					
	SHELL TURBO T68	Gallons	165	34	165	- Physical Hazard				
	CAS No	State	Storage Container		Pressue	Waste Code	Not Otherwise Classified			
		Liquid	Other		Ambient		- Health Hazard			
	Map: 1 Grid: F2	Type			Temperature		Not Otherwise Classified			
		Mixture	Days on Site: 365		Ambient					

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility				Chemical Location		CERS ID	10096750			
Facility Name	Los Esteros Critical Energy Facility				CONTROL ROOM (ENERSYS 4DX-11 60 UNITS)		Facility ID	FA0256442			
800 THOMAS FOON CHEW WY, San Jose 95134							Status	Submitted on 7/8/2025 12:14 PM			
				Quantities		Annual Waste Amount	Federal Hazard Categories	Hazardous Components (For mixture only)			
DOT Code/Fire Haz. Class	Common Name	Unit	Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt	EHS	CAS No.
DOT: 8 - Corrosives (Liquids and Solids) Corrosive	NON-SPILLABLE LEAD-ACID BATTERY CAS No Map: 1 Grid: C5	Gallons	840	14	840		- Physical	LEAD, LEAD COMPONENTS	60%		7439-92-1
		State	Storage Container		Pressue		Corrosive To				
		Liquid	Other		< Ambient	Waste Code	Metal	SULFURIC ACID	30%	✓	7664-93-9
		Type			Temperature		- Health Skin				
		Mixture	Days on Site: 365		< Ambient		Corrosion Irritation - Health Serious Eye Damage Eye Irritation				

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility				Chemical Location		CERS ID	10096750		
Facility Name	Los Esteros Critical Energy Facility				COOLING TOWER GEAR BOXES		Facility ID	FA0256442		
	800 THOMAS FOON CHEW WY, San Jose 95134						Status	Submitted on 7/8/2025 12:14 PM		
				Quantities		Annual Waste Amount	Federal Hazard Categories	Hazardous Components (For mixture only)		
DOT Code/Fire Haz. Class	Common Name	Unit	Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt	EHS CAS No.
DOT: 3 - Flammable and Combustible Liquids	SHELL MORLINA S3 BA 220	Gallons	126	21	126		- Physical			
	CAS No	State	Storage Container		Pressue		Flammable			
		Liquid	Other		Ambient	Waste Code	- Health Acute			
	Map: 1 Grid: H1 F1, E1	Type			Temperature		Toxicity			
		Mixture	Days on Site: 365		Ambient					

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org. Los Esteros Critical Energy Facility			Chemical Location				CERS ID	10096750		
Facility Name Los Esteros Critical Energy Facility			COOLING WATER CHEMICALS				Facility ID	FA0256442		
800 THOMAS FOON CHEW WY, San Jose 95134							Status	Submitted on 7/8/2025 12:14 PM		
DOT Code/Fire Haz. Class	Common Name	Unit	Quantities			Annual Waste Amount	Federal Hazard Categories	Hazardous Components (For mixture only)		
			Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt	EHS CAS No.
	CHEMTREAT CL-5428	Gallons	400	400	400		- Physical Hazard			
	CAS No	State	Storage Container		Pressue	Waste Code	Not Otherwise Classified			
		Liquid	Aboveground Tank		Ambient		- Health Hazard			
	Map: 1 Grid: E1	Type			Temperature		Not Otherwise Classified			
		Mixture	Days on Site: 365		Ambient					
DOT: 9 - Misc. Hazardous Materials	CHEMTREAT CT-709	Gallons	400	400	400		- Physical Hazard	SODIUM HEXAMETAPHOSPHATE	40%	10124-56-8
	CAS No	State	Storage Container		Pressue	Waste Code	Not Otherwise Classified			
		Liquid	Aboveground Tank		Ambient		- Health Acute Toxicity			
	Map: 1 Grid: E1	Type			Temperature					
		Mixture	Days on Site: 365		Ambient					
DOT: 8 - Corrosives (Liquids and Solids) Corrosive	SODIUM HYPOCHLORITE 12.5%	Gallons	6000	6000	6000		- Physical Corrosive To Metal			
	CAS No	State	Storage Container		Pressue	Waste Code	- Health Acute Toxicity			
		Liquid	Aboveground Tank		Ambient		- Health Skin Corrosion Irritation			
	Map: 1 Grid: E1	Type			Temperature		- Health Serious Eye Damage Eye Irritation			
		Mixture	Days on Site: 365		Ambient					
DOT: 8 - Corrosives (Liquids and Solids) Corrosive	SULFURIC ACID 93%	Pounds	87234	87234	87234		- Physical Corrosive To Metal			
	CAS No <input checked="" type="checkbox"/> EHS	State	Storage Container		Pressue	Waste Code	- Health Skin Corrosion Irritation			
	7664-93-9	Liquid	Aboveground Tank		Ambient		- Health Serious Eye Damage Eye Irritation			
	Map: 1 Grid: E1	Type			Temperature					
		Mixture	Days on Site: 365		Ambient					

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility	Chemical Location	CERS ID	10096750
Facility Name	Los Esteros Critical Energy Facility	CTG #1 & #4 OILY WATER SEPARATOR #1	Facility ID	FA0256442
	800 THOMAS FOON CHEW WY, San Jose 95134		Status	Submitted on 7/8/2025 12:14 PM

DOT Code/Fire Haz. Class	Common Name	Unit	Quantities			Annual Waste Amount	Federal Hazard Categories	Hazardous Components (For mixture only)		
			Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt	EHS CAS No.
	USED OIL	Gallons	773	773	600	773	- Health			
	CAS No	State	Storage Container		Pressue	Waste Code	Carcinogenicity			
	70514-12-4	Liquid	Other		< Ambient		- Health			
		Type			Temperature		Reproductive			
		Mixture	Days on Site: 365		< Ambient		Toxicity			
							- Health Skin			
							Corrosion			
							Irritation			
							- Health			
							Respiratory Skin			
							Sensitization			
							- Health Serious			
							Eye Damage Eye			
							Irritation			
							- Health Specific			
							Target Organ			
							Toxicity			
							- Health			
							Aspiration Hazard			
							- Health Germ			
							Cell Mutagenicity			

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility				Chemical Location		CERS ID	10096750		
Facility Name	Los Esteros Critical Energy Facility				CTG #2 & #3 OILY WATER SEPARATOR #2		Facility ID	FA0256442		
800 THOMAS FOON CHEW WY, San Jose 95134						Status		Submitted on 7/8/2025 12:14 PM		
				Quantities		Annual Waste	Hazardous Components			
						Amount	(For mixture only)			
DOT Code/Fire Haz. Class	Common Name	Unit	Max. Daily	Largest Cont.	Avg. Daily	Federal Hazard	Categories	Component Name	% Wt	EHS CAS No.
	USED OIL	Gallons	773	773	600	773	- Health			
	CAS No	State	Storage Container		Pressue	Waste Code	Carcinogenicity			
	70514-12-4	Liquid	Other		< Ambient		- Health Skin			
		Type			Temperature		Corrosion			
		Mixture	Days on Site: 365		< Ambient		Irritation			
							- Health			
							Respiratory Skin			
							Sensitization			
							- Health Serious			
							Eye Damage Eye			
							Irritation			

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility				Chemical Location		CERS ID	10096750					
Facility Name	Los Esteros Critical Energy Facility				CTG GENERATOR RESERVOIRS		Facility ID	FA0256442					
	800 THOMAS FOON CHEW WY, San Jose 95134						Status	Submitted on 7/8/2025 12:14 PM					
								Hazardous Components (For mixture only)					
DOT Code/Fire Haz. Class		Common Name		Unit	Quantities Max. Daily Largest Cont. Avg. Daily		Annual Waste Amount	Federal Hazard Categories	Component Name		% Wt	EHS	CAS No.
DOT: 3 - Flammable and Combustible Liquids		GST 32 GENERATOR LUBRICATING OIL		Gallons	2000 500 2000			- Physical Flammable	DISTILLATES, HYDROTREATED		98%		64742-54-7
		State		Storage Container		Pressue			HEAVY PARAFFINIC				
		CAS No		Liquid	Other		Ambient	Waste Code	- Health Hazard				
		Type				Temperature			Not Otherwise Classified				
Map: 1		Grid: D7, D4, E4, E7		Mixture	Days on Site: 365		Ambient						

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility				Chemical Location		CERS ID	10096750		
Facility Name	Los Esteros Critical Energy Facility				CTG HYDRAULIC STARTER RESERVOIRS		Facility ID	FA0256442		
	800 THOMAS FOON CHEW WY, San Jose 95134						Status	Submitted on 7/8/2025 12:14 PM		
				Quantities		Annual Waste Amount	Federal Hazard Categories	Hazardous Components (For mixture only)		
DOT Code/Fire Haz. Class	Common Name	Unit	Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt	EHS CAS No.
DOT: 3 - Flammable and Combustible Liquids	SHELL TELLUS S2 MX 46	Gallons	160	40	160		- Physical			
	CAS No	State	Storage Container		Pressue		Flammable			
		Liquid	Other		Ambient	Waste Code	- Health Acute			
	Map: 1 Grid: D4, E4, D7, E7	Type			Temperature		Toxicity			
		Mixture	Days on Site: 365		Ambient					

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility	Chemical Location				CERS ID	10096750
Facility Name	Los Esteros Critical Energy Facility	FIRE PUMP HOUSE				Facility ID	FA0256442
800 THOMAS FOON CHEW WY, San Jose 95134						Status	Submitted on 7/8/2025 12:14 PM
						Hazardous Components (For mixture only)	
DOT Code/Fire Haz. Class	Common Name	Unit	Quantities		Annual Waste	Federal Hazard	
			Max. Daily	Largest Cont.	Avg. Daily	Categories	Component Name
DOT: 3 - Flammable and Combustible Liquids	NO. 2 DIESEL FUEL	Gallons	320	320	320	- Physical	NAPHTHALENE
	CAS No	State	Storage Container		Pressue	Flammable	
	NA	Liquid	Aboveground Tank		Ambient	- Physical Contact	#2 DIESEL FUEL
Combustible Liquid, Class III-B	Map: 1 Grid: B9	Type			Temperature	Water Emits	
		Mixture	Days on Site: 365		Ambient	Flammable Gas	
						- Health Acute	
						Toxicity	
						- Health	
						Respiratory Skin	
						Sensitization	
						- Health	
						Aspiration Hazard	

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility	Chemical Location	CERS ID	10096750
Facility Name	Los Esteros Critical Energy Facility	FIRE PUMP HOUSE (INTERSTATE 8D-MHD 2 UNITS)	Facility ID	FA0256442
	800 THOMAS FOON CHEW WY, San Jose 95134		Status	Submitted on 7/8/2025 12:14 PM

DOT Code/Fire Haz. Class	Common Name	Unit	Quantities			Annual Waste Amount	Federal Hazard Categories	Hazardous Components (For mixture only)		
			Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt	EHS CAS No.
DOT: 8 - Corrosives (Liquids and Solids)	LEAD-ACID BATTERY	Gallons	9	4.5	9		- Physical	Lead/Lead Oxide (Litharge)/Lead	70%	7439-92-1
	CAS No	State	Storage Container		Pressue		Flammable	Sulfate		
Corrosive	Map: 1 Grid: B9	Liquid	Other		Ambient		- Physical	Sulfuric Acid (Battery Electrolyte)	15%	✓ 7664-93-9
		Type			Temperature		Explosive			
		Mixture	Days on Site: 365		Ambient		- Physical			
							Corrosive To Metal			
							- Health			
							Carcinogenicity			
							- Health Acute			
							Toxicity			
							- Health			
							Reproductive			
							Toxicity			
							- Health Skin			
							Corrosion			
							Irritation			
							- Health Serious			
							Eye Damage Eye			
							Irritation			
							- Health Specific			
							Target Organ			
							Toxicity			

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility				Chemical Location		CERS ID	10096750		
Facility Name	Los Esteros Critical Energy Facility				FUEL GAS COMPRESSOR SKID		Facility ID	FA0256442		
	800 THOMAS FOON CHEW WY, San Jose 95134						Status	Submitted on 7/8/2025 12:14 PM		
				Quantities		Annual Waste Amount	Federal Hazard Categories	Hazardous Components (For mixture only)		
DOT Code/Fire Haz. Class	Common Name	Unit	Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt	EHS CAS No.
DOT: 9 - Misc. Hazardous Materials	SHELL MORLINA S3 BA 100	Gallons	180	50	180		- Physical Hazard			
	CAS No	State	Storage Container		Pressue		Not Otherwise			
		Liquid	Other		Ambient	Waste Code	Classified			
	Map: 1 Grid: H4	Type			Temperature		- Health Serious			
		Mixture	Days on Site: 365		Ambient		Eye Damage Eye Irritation			

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility				Chemical Location		CERS ID	10096750		
Facility Name	Los Esteros Critical Energy Facility				FUEL GAS CONDENSATE DRAIN TANK		Facility ID	FA0256442		
	800 THOMAS FOON CHEW WY, San Jose 95134						Status	Submitted on 7/8/2025 12:14 PM		
				Quantities		Annual Waste	Hazardous Components			
						Amount	(For mixture only)			
DOT Code/Fire Haz. Class	Common Name	Unit	Max. Daily	Largest Cont.	Avg. Daily	Federal Hazard	Component Name	% Wt	EHS	CAS No.
	NATURAL GAS CONDENSATES	Gallons	500	500	50	50				
	CAS No	State	Storage Container		Pressue	Waste Code				
	68919-39-1	Liquid	Other		< Ambient	221				
		Type			Temperature					
		Mixture	Days on Site: 365		< Ambient					

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility				Chemical Location		CERS ID	10096750		
Facility Name	Los Esteros Critical Energy Facility				GAS TURBINE RESERVOIR		Facility ID	FA0256442		
	800 THOMAS FOON CHEW WY, San Jose 95134						Status	Submitted on 7/8/2025 12:14 PM		
DOT Code/Fire Haz. Class	Common Name	Unit	Quantities			Annual Waste Amount	Federal Hazard Categories	Hazardous Components (For mixture only)		
			Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt	EHS CAS No.
DOT: 9 - Misc. Hazardous Materials	AEROSHELL 500	Gallons	600	150	600		- Physical Hazard	1-NAPHTHYLAMINE, N-PHENYL	2%	90-30-2
	CAS No	State	Storage Container		Pressue		Not Otherwise			
		Liquid	Other		Ambient		Classified	TRICRESYL PHOSPHATE .04%	2%	1330-78-5
	Map: 1 Grid: D8, E8, D4, E4	Type			Temperature		- Health Acute			
		Mixture	Days on Site: 365		Ambient		Toxicity			
							- Health			
							Reproductive			
							Toxicity			
							- Health Skin			
							Corrosion			
							Irritation			
							- Health Specific			
							Target Organ			
							Toxicity			

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility					Chemical Location	CERS ID	10096750		
Facility Name	Los Esteros Critical Energy Facility					GENERATOR STEP UP TRANSFORMERS	Facility ID	FA0256442		
	800 THOMAS FOON CHEW WY, San Jose 95134						Status	Submitted on 7/8/2025 12:14 PM		
						Annual Waste Amount	Hazardous Components (For mixture only)			
DOT Code/Fire Haz. Class	Common Name	Unit	Max. Daily	Largest Cont.	Avg. Daily	Federal Hazard Categories	Component Name	% Wt	EHS	CAS No.
	HYVOLT II TRANSFORMER INSULATING OIL	Gallons	25036	6259	25036	- Physical Hazard	SEVERLY HYDROTREATED LIGHT	100%		64742-53-6
		State	Storage Container		Pressue	Not Otherwise Classified	NAPHTHENIC DISTILLATES			
		Liquid	Other		Ambient	- Health Skin				
		Type			Temperature	Corrosion				
	Map: 1 Grid: D8, D3, E3, E8	Mixture	Days on Site: 365		< Ambient	Irritation				
						- Health Aspiration Hazard				
DOT: 2.2 - Nonflammable Gases	NITROGEN	Cu. Feet	1200	300	1200	- Physical Gas				
		State	Storage Container		Pressue	Under Pressure				
		Gas	Cylinder		Ambient	- Health Serious				
		Type			Temperature	Eye Damage Eye				
	Map: 1 Grid: D8, D3, E3, E8	Pure	Days on Site: 365		Ambient	Irritation				

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org. Los Esteros Critical Energy Facility		Chemical Location				CERS ID	10096750			
Facility Name Los Esteros Critical Energy Facility		HAZARDOUS WASTE STORAGE				Facility ID	FA0256442			
800 THOMAS FOON CHEW WY, San Jose 95134						Status	Submitted on 7/8/2025 12:14 PM			
								Hazardous Components (For mixture only)		
DOT Code/Fire Haz. Class	Common Name	Unit	Quantities			Annual Waste Amount	Federal Hazard Categories	Component Name		
			Max. Daily	Largest Cont.	Avg. Daily			% Wt	EHS	CAS No.
DOT: 4.1 - Flammable Solids	DEBRIS/RAGS CONTAMINATED WITH PETROLEUM/OIL	Pounds	840	230	600	2500	- Physical			
Flammable Solid		State	Storage Container		Pressue	Waste Code	Flammable			
	CAS No	Solid	Steel Drum		Ambient	352	- Health Hazard			
		Type			Temperature		Not Otherwise			
	Map: 1 Grid: C8	Waste	Days on Site: 180		Ambient		Classified			
DOT: 3 - Flammable and Combustible Liquids	USED OIL	Gallons	330	55	285	2500	- Physical			
Flammable Liquid, Class I-A		State	Storage Container		Pressue		Flammable			
	CAS No	Liquid	Steel Drum		Ambient	Waste Code	- Health Acute			
	NA	Type			Temperature	221	Toxicity			
	Map: 1 Grid: C8	Waste	Days on Site: 180		Ambient					
DOT: 4.1 - Flammable Solids	USED OIL FILTERS	Pounds	400	200	200	400	- Physical			
Flammable Solid		State	Storage Container		Pressue	Waste Code	Flammable			
	CAS No	Solid	Steel Drum		Ambient	352	- Health Hazard			
	NA	Type			Temperature		Not Otherwise			
	Map: 1 Grid: C8	Waste	Days on Site: 180		Ambient		Classified			
DOT: 3 - Flammable and Combustible Liquids	USED OIL/OILY WATER	Gallons	330	55	285	3500	- Physical			
Flammable Liquid, Class I-A		State	Storage Container		Pressue		Flammable			
	CAS No	Liquid	Steel Drum		Ambient	Waste Code	- Health Acute			
	NA	Type			Temperature	221	Toxicity			
	Map: 1 Grid: C8	Waste	Days on Site: 180		Ambient					

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility				Chemical Location	CERS ID 10096750			
Facility Name	Los Esteros Critical Energy Facility				ICE SHOP AREA	Facility ID FA0256442			
	800 THOMAS FOON CHEW WY, San Jose 95134					Status Submitted on 7/8/2025 12:14 PM			
								Hazardous Components	
								(For mixture only)	
DOT Code/Fire Haz. Class	Common Name	Unit	Quantities			Annual Waste Amount	Federal Hazard Categories	Component Name	
			Max. Daily	Largest Cont.	Avg. Daily			% Wt	EHS CAS No.
DOT: 3 - Flammable and Combustible Liquids	MISCELLANEOUS FLAMMABLES	Gallons	95	1	75		- Physical		
	CAS No	State	Storage Container		Pressue		Flammable		
		Liquid	Other		Ambient	Waste Code	- Physical Gas		
Flammable Liquid, Class I-A	Map: 1 Grid: C8	Type			Temperature		Under Pressure		
		Mixture	Days on Site: 365		Ambient		- Health Acute Toxicity		

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility					Chemical Location		CERS ID	10096750		
Facility Name	Los Esteros Critical Energy Facility					OIL STORAGE SKID		Facility ID	FA0256442		
	800 THOMAS FOON CHEW WY, San Jose 95134							Status	Submitted on 7/8/2025 12:14 PM		
						Annual Waste Amount	Federal Hazard Categories	Hazardous Components (For mixture only)			
DOT Code/Fire Haz. Class	Common Name	Unit	Quantities								
			Max. Daily	Largest Cont.	Avg. Daily						
DOT: 8 - Corrosives (Liquids and Solids)	CHEMTREAT BL-1304	Gallons	220	55	220		- Physical	POTASSIUM HYDROXIDE	30%	1310-58-3	
	CAS No	State	Storage Container			Pressue	Waste Code	Corrosive To			
		Liquid	Plastic/Non-metalic Drum			Ambient		Metal	SODIUM HYDROXIDE`	40%	1310-73-2
	Map: C Grid: 8	Type				Temperature		- Health Skin			
		Mixture	Days on Site: 365			Ambient		Corrosion			
								Irritation			
DOT: 8 - Corrosives (Liquids and Solids)	CHEMTREAT BL-152	Gallons	275	55	165	0	- Physical	AMMONIUM HYDROXIDE	30%	✓	1336-21-6
	CAS No	State	Storage Container			Pressue	Waste Code	Corrosive To			
		Liquid	Plastic/Non-metalic Drum			Ambient		Metal	ETHANOLAMINE	10%	141-43-5
Corrosive	Map: 1 Grid: C8	Type				Temperature		- Health Acute			
		Mixture	Days on Site: 365			Ambient		Toxicity			
								- Health Skin			
								Corrosion			
								Irritation			
								- Health Serious			
								Eye Damage Eye			
								Irritation			
DOT: 9 - Misc. Hazardous Materials	CHEMTREAT BL8401	Gallons	110	55	55		- Health Acute				
	CAS No	State	Storage Container			Pressue	Waste Code	Toxicity			
		Liquid	Plastic/Non-metalic Drum			Ambient		- Health Skin			
	Map: 1 Grid: C8	Type				Temperature		Corrosion			
		Mixture	Days on Site: 365			Ambient		Irritation			
								- Health Serious			
								Eye Damage Eye			
								Irritation			
								- Health Specific			
								Target Organ			
								Toxicity			
DOT: 8 - Corrosives (Liquids and Solids)	CHEMTREAT CL-2230	Gallons	30	5	30		- Physical	5-CHLORO-2METHYL-4-	1%	26172-55-4	
	CAS No	State	Storage Container			Pressue	Waste Code	Corrosive To			
		Liquid	Carboy			Ambient		Metal	ISOTHIAZOLIN-3-ONE		
	Map: 1 Grid: C8	Type				Temperature		- Health Skin	2-METHYL-4-ISOTHIAZDIN-3-ONE	0%	2682-20-4
		Mixture	Days on Site: 365			Ambient		Corrosion			
								Irritation			
								- Health Serious			
								Eye Damage Eye			
								Irritation			
DOT: 8 - Corrosives (Liquids and Solids)	CHEMTREAT CL-2875	Gallons	550	55	275		- Physical				
	CAS No	State	Storage Container			Pressue	Waste Code	Corrosive To			
		Liquid	Plastic/Non-metalic Drum			Ambient		Metal			
Corrosive	Map: 1 Grid: C8	Type				Temperature		- Health Acute			
		Mixture	Days on Site: 365			Ambient		Toxicity			
								- Health Skin			
								Corrosion			
								Irritation			
								- Health Serious			
								Eye Damage Eye			
								Irritation			

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility				Chemical Location		CERS ID	10096750		
Facility Name	Los Esteros Critical Energy Facility				OIL STORAGE SKID		Facility ID	FA0256442		
	800 THOMAS FOON CHEW WY, San Jose 95134						Status	Submitted on 7/8/2025 12:14 PM		
						Annual Waste Amount	Federal Hazard Categories		Hazardous Components (For mixture only)	
DOT Code/Fire Haz. Class	Common Name	Unit	Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt	EHS CAS No.
DOT: 9 - Misc. Hazardous Materials	CHEMTREAT CL-5428	Gallons	220	55	110		- Physical Hazard			
	CAS No	State	Storage Container		Pressue	Waste Code	Not Otherwise Classified			
		Liquid	Plastic/Non-metalic Drum		Ambient		- Health Hazard			
	Map: 1 Grid: C8	Type			Temperature		Not Otherwise Classified			
		Mixture	Days on Site: 365		Ambient					
DOT: 9 - Misc. Hazardous Materials	CHEMTREAT CT-709	Gallons	550	55	550		- Physical Hazard	SODIUM HEXAMETAPHOSPHATE	40%	10124-56-8
	CAS No	State	Storage Container		Pressue	Waste Code	Not Otherwise Classified			
		Liquid	Plastic/Non-metalic Drum		Ambient		- Health Acute Toxicity			
	Map: 1 Grid: C8	Type			Temperature		- Health Serious Eye Damage Eye Irritation			
		Mixture	Days on Site: 365		Ambient					
	CHEMTREAT FO223	Gallons	275	55	220		- Physical			
	CAS No	State	Storage Container		Pressue	Waste Code	Flammable			
		Liquid	Plastic/Non-metalic Drum		Ambient		- Health Skin Corrosion Irritation			
	Map: 1 Grid: C8	Type			Temperature					
		Mixture	Days on Site: 365		Ambient					
DOT: 9 - Misc. Hazardous Materials	CONNECT 6000	Gallons	110	55	110		- Physical Hazard	ETHOXYLATED ALCOHOLS (C9-C11)		68439-46-3
	CAS No	State	Storage Container		Pressue	Waste Code	Not Otherwise Classified			
	NA	Liquid	Plastic/Non-metalic Drum		Ambient		- Health Hazard	2-BUTOXY ETHANOL		111-76-2
	Map: 1 Grid: C8	Type			Temperature		Not Otherwise Classified	WATER		7732-18-5
		Mixture	Days on Site: 365		Ambient					
DOT: 3 - Flammable and Combustible Liquids	DIESEL FUEL NO. 2	Gallons	100	10	60		- Physical			
	CAS No	State	Storage Container		Pressue	Waste Code	Flammable			
	68334-30-5	Liquid	Can		Ambient		- Health Carcinogenicity			
	Combustible Liquid, Class II	Type			Temperature		- Health Acute Toxicity			
		Pure			Ambient		- Health Skin Corrosion Irritation			
					- Health Specific Target Organ Toxicity					
					- Health Aspiration Hazard					
	HYTRANS 61 TRANSFORMER OIL	Gallons	165	55	110		- Physical Hazard			
	CAS No	State	Storage Container		Pressue	Waste Code	Not Otherwise Classified			
		Liquid	Steel Drum		Ambient		- Health Skin Corrosion Irritation			
	Map: 1 Grid: C8	Type			Temperature		- Health Serious Eye Damage Eye Irritation			
		Mixture	Days on Site: 365		Ambient					

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org. Los Esteros Critical Energy Facility			Chemical Location				CERS ID	10096750		
Facility Name Los Esteros Critical Energy Facility			OIL STORAGE SKID				Facility ID	FA0256442		
800 THOMAS FOON CHEW WY, San Jose 95134							Status	Submitted on 7/8/2025 12:14 PM		
DOT Code/Fire Haz. Class	Common Name	Unit	Quantities			Annual Waste Amount	Federal Hazard Categories	Hazardous Components (For mixture only)		
			Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt	EHS CAS No.
DOT: 3 - Flammable and Combustible Liquids Flammable Liquid, Class I-A	MISCELLANEOUS FLAMMABLES	Gallons	175	5	125		- Physical			
	CAS No	State	Storage Container		Pressue	Waste Code	Flammable			
		Liquid	Other		Ambient		- Physical Gas			
	Map: 1 Grid: C8	Type			Temperature		Under Pressure			
		Mixture	Days on Site: 365		Ambient		- Health Acute Toxicity			
	MISCELLANEOUS LUBE OILS	Gallons	200	5	150		- Physical Hazard			
	CAS No	State	Storage Container		Pressue	Waste Code	Not Otherwise Classified			
		Liquid	Other		Ambient		- Health Hazard			
	Map: 1 Grid: C8	Type			Temperature		Not Otherwise Classified			
		Mixture	Days on Site: 365		Ambient					
DOT: 8 - Corrosives (Liquids and Solids) Corrosive	ND-165	Gallons	110	55	110		- Physical			
	CAS No	State	Storage Container		Pressue	Waste Code	Corrosive To Metal			
		Liquid	Plastic/Non-metalic Drum		Ambient		- Health Skin Corrosion			
	Map: 1 Grid: C8	Type			Temperature		Irritation			
		Mixture	Days on Site: 365		Ambient		- Health Serious Eye Damage Eye Irritation			
							- Health Specific Target Organ Toxicity			
DOT: 2.1 - Flammable Gases Flammable Gas	PROPANE	Cu. Feet	100	15	75		- Physical			
	CAS No	State	Storage Container		Pressue	Waste Code	Flammable			
	74-98-6	Gas	Cylinder		Ambient		- Physical Gas			
	Map: 1 Grid: C8	Type			Temperature		Under Pressure			
		Pure	Days on Site: 365		Ambient		- Health Simple Asphyxiant			
	ROTO Z FLUID MINERAL LUBRICANT	Gallons	50	5	45		- Physical			
	CAS No	State	Storage Container		Pressue	Waste Code	Flammable			
		Liquid	Carboy				- Health Skin			
	Map: 1 Grid: C8	Type			Temperature		Corrosion			
		Mixture	Days on Site: 365				Irritation			
	SHELL MORLINA S3 BA 100	Gallons	330	55	220		- Physical Hazard			
	CAS No	State	Storage Container		Pressue	Waste Code	Not Otherwise Classified			
		Liquid	Steel Drum		Ambient		- Health Hazard			
	Map: 1 Grid: C8	Type			Temperature		Not Otherwise Classified			
		Mixture	Days on Site: 365		Ambient					
	SHELL TELLUS S2 MX32	Gallons	165	55	110		- Physical Hazard			
	CAS No	State	Storage Container		Pressue	Waste Code	Not Otherwise Classified			
		Liquid	Steel Drum		Ambient		- Health Serious			
	Map: 1 Grid: C8	Type			Temperature		Eye Damage Eye Irritation			
		Mixture	Days on Site: 365		Ambient					

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org. Los Esteros Critical Energy Facility			Chemical Location				CERS ID	10096750		
Facility Name Los Esteros Critical Energy Facility			OIL STORAGE SKID				Facility ID	FA0256442		
800 THOMAS FOON CHEW WY, San Jose 95134							Status	Submitted on 7/8/2025 12:14 PM		
DOT Code/Fire Haz. Class	Common Name	Unit	Quantities			Annual Waste Amount	Federal Hazard Categories	Hazardous Components (For mixture only)		
			Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt	EHS CAS No.
	SHELL TELLUS S2 MX46	Gallons	110	55	110		- Physical Hazard			
	<u>CAS No</u>	<u>State</u>	<u>Storage Container</u>		<u>Pressue</u>	<u>Waste Code</u>	Not Otherwise Classified			
	Map: 1 Grid: C8	<u>Liquid</u>	Steel Drum		<u>Ambient</u>		- Health Serious			
		<u>Type</u>			<u>Temperature</u>		Eye Damage Eye Irritation			
		Mixture	Days on Site: 365		<u>Ambient</u>					
	SHELL TURBO J 32	Gallons	330	55	220		- Physical Hazard			
	<u>CAS No</u>	<u>State</u>	<u>Storage Container</u>		<u>Pressue</u>	<u>Waste Code</u>	Not Otherwise Classified			
	Map: 1 Grid: C8	<u>Liquid</u>	Steel Drum		<u>Ambient</u>		- Health Hazard			
		<u>Type</u>			<u>Temperature</u>		Not Otherwise Classified			
		Mixture	Days on Site: 365		<u>Ambient</u>					
DOT: 9 - Misc. Hazardous Materials	SHELL TURBO T 32	Gallons	110	55	110		- Physical Hazard			
	<u>CAS No</u>	<u>State</u>	<u>Storage Container</u>		<u>Pressue</u>	<u>Waste Code</u>	Not Otherwise Classified			
	Map: 1 Grid: H3	<u>Liquid</u>	Steel Drum		<u>Ambient</u>		- Health Skin			
		<u>Type</u>			<u>Temperature</u>		Corrosion			
		Mixture	Days on Site: 365		<u>Ambient</u>		Irritation			
DOT: 3 - Flammable and Combustible Liquids	TURBINE OIL 500	Gallons	330	55	220		- Physical Flammable			
	<u>CAS No</u>	<u>State</u>	<u>Storage Container</u>		<u>Pressue</u>	<u>Waste Code</u>	- Physical Hazard			
	Map: 1 Grid: C8	<u>Liquid</u>	Steel Drum		<u>Ambient</u>		Not Otherwise Classified			
		<u>Type</u>			<u>Temperature</u>		- Health Reproductive			
		Mixture	Days on Site: 365		<u>Ambient</u>		Toxicity			
							- Health Respiratory Skin Sensitization			
							- Health Specific Target Organ Toxicity			
DOT: 3 - Flammable and Combustible Liquids	TURBINE OIL TURBO 68	Gallons	330	55	220		- Physical Flammable	PETROLEUM HYDROTREATED PARAFINIC	98%	64742-54-7
	<u>CAS No</u>	<u>State</u>	<u>Storage Container</u>		<u>Pressue</u>	<u>Waste Code</u>	- Health Hazard			
	NA	<u>Liquid</u>	Steel Drum		<u>Ambient</u>		Not Otherwise Classified			
	Map: 1 Grid: C8	<u>Type</u>			<u>Temperature</u>					
		Mixture	Days on Site: 365		<u>Ambient</u>					

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility	Chemical Location	CERS ID	10096750
Facility Name	Los Esteros Critical Energy Facility	OILY WATER SEPARATOR #4 (AMMONIA SOTRAGE)	Facility ID	FA0256442
	800 THOMAS FOON CHEW WY, San Jose 95134		Status	Submitted on 7/8/2025 12:14 PM

DOT Code/Fire Haz. Class	Common Name	Unit	Quantities			Annual Waste Amount	Federal Hazard Categories	Hazardous Components (For mixture only)		
			Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt	EHS CAS No.
	USED OIL	Gallons	773	773	600	773	- Health			
	CAS No	State	Storage Container		Pressue	Waste Code	Carcinogenicity			
	70514-12-4	Liquid	Other				- Health			
		Type			Temperature		Reproductive			
		Mixture	Days on Site: 365				Toxicity			
							- Health Skin			
							Corrosion			
							Irritation			
							- Health			
							Respiratory Skin			
							Sensitization			
							- Health Serious			
							Eye Damage Eye			
							Irritation			
							- Health Specific			
							Target Organ			
							Toxicity			
							- Health			
							Aspiration Hazard			
							- Health Germ			
							Cell Mutagenicity			

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility				Chemical Location		CERS ID	10096750			
Facility Name	Los Esteros Critical Energy Facility				PDC #1 (ENERSYS 4DX-11 60 UNITS)		Facility ID	FA0256442			
800 THOMAS FOON CHEW WY, San Jose 95134							Status	Submitted on 7/8/2025 12:14 PM			
				Quantities		Annual Waste Amount	Federal Hazard Categories	Hazardous Components (For mixture only)			
DOT Code/Fire Haz. Class	Common Name	Unit	Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt	EHS	CAS No.
DOT: 8 - Corrosives (Liquids and Solids) Corrosive	NON-SPILLABLE LEAD-ACID BATTERY CAS No Map: 1 Grid: E3	Gallons	840	14	840		- Physical	LEAD, LEAD COMPONENTS	60%		7439-92-1
		State	Storage Container		Pressue		Corrosive To				
		Liquid	Other		< Ambient	Waste Code	Metal	SULFURIC ACID	30%	✓	7664-93-9
		Type			Temperature		- Health Skin				
		Mixture	Days on Site: 365		< Ambient		Corrosion Irritation - Health Serious Eye Damage Eye Irritation				

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility	Chemical Location	CERS ID	10096750
Facility Name	Los Esteros Critical Energy Facility	PDC #1 (HOPPECKE FNC 333L 19 UNITS)	Facility ID	FA0256442
	800 THOMAS FOON CHEW WY, San Jose 95134		Status	Submitted on 7/8/2025 12:14 PM

DOT Code/Fire Haz. Class	Common Name	Unit	Quantities			Annual Waste Amount	Federal Hazard Categories	Hazardous Components (For mixture only)		
			Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt	EHS CAS No.
DOT: 8 - Corrosives (Liquids and Solids) Corrosive	NI-CAD BATTERY	Gallons	41.8	2.52	41.8		- Physical			
		State	Storage Container		Pressue		Flammable			
		Liquid	Other		< Ambient	Waste Code	- Physical			✓
		Type			Temperature		Explosive			
		Mixture	Days on Site: 365		< Ambient		- Physical			
	Map: 1 Grid: E3						Corrosive To Metal			
							- Health			
							Carcinogenicity			
							- Health Acute			
							Toxicity			
							- Health			
							Reproductive			
							Toxicity			
							- Health Skin			
							Corrosion			
							Irritation			
							- Health Serious			
							Eye Damage Eye			
							Irritation			
							- Health Specific			
							Target Organ			
							Toxicity			

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility				Chemical Location		CERS ID	10096750		
Facility Name	Los Esteros Critical Energy Facility				PDC #1 (HOPPECKE FNC 66 L 19 UNITS)		Facility ID	FA0256442		
800 THOMAS FOON CHEW WY, San Jose 95134							Status	Submitted on 7/8/2025 12:14 PM		
				Quantities		Annual Waste Amount	Federal Hazard Categories	Hazardous Components (For mixture only)		
DOT Code/Fire Haz. Class	Common Name	Unit	Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt	EHS CAS No.
DOT: 8 - Corrosives (Liquids and Solids)	NI-CAD BATTERY	Gallons	11.97	0.63	11.97		- Physical			
	CAS No	State	Storage Container		Pressue		Corrosive To			
		Liquid	Other		< Ambient	Waste Code	Metal			
	Corrosive	Map: 1 Grid: E3	Type			Temperature		- Health Skin		
			Mixture	Days on Site: 365		< Ambient		Corrosion		
								Irritation		
								- Health Serious		
								Eye Damage Eye		
								Irritation		

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility				Chemical Location		CERS ID	10096750			
Facility Name	Los Esteros Critical Energy Facility				PDC #10 (ENERSYS 4DX-11 60 UNITS)		Facility ID	FA0256442			
800 THOMAS FOON CHEW WY, San Jose 95134							Status	Submitted on 7/8/2025 12:14 PM			
				Quantities		Annual Waste Amount	Federal Hazard Categories	Hazardous Components (For mixture only)			
DOT Code/Fire Haz. Class	Common Name	Unit	Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt	EHS	CAS No.
DOT: 8 - Corrosives (Liquids and Solids) Corrosive	NON-SPILLABLE LEAD-ACID BATTERY CAS No Map: 1 Grid: F8	Gallons	840	14	840		- Physical	LEAD, LEAD COMPONENTS	60%		7439-92-1
		State	Storage Container		Pressue		Corrosive To				
		Liquid	Other		< Ambient	Waste Code	Metal	SULFURIC ACID	30%	✓	7664-93-9
		Type			Temperature		- Health Skin				
		Mixture	Days on Site: 365		< Ambient		Corrosion Irritation - Health Serious Eye Damage Eye Irritation				

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility	Chemical Location		CERS ID	10096750					
Facility Name	Los Esteros Critical Energy Facility	PDC #12 (ENERSYS 4DX-11 60 UNITS)		Facility ID	FA0256442					
	800 THOMAS FOON CHEW WY, San Jose 95134			Status	Submitted on 7/8/2025 12:14 PM					
		Quantities			Annual Waste	Federal Hazard	Hazardous Components			
DOT Code/Fire Haz. Class	Common Name	Unit	Max. Daily	Largest Cont.	Avg. Daily	Amount	Categories	(For mixture only)		
								Component Name	% Wt	EHS CAS No.
DOT: 8 - Corrosives (Liquids and Solids)	NON-SPILLABLE LEAD-ACID	Gallons	840	14	840		- Physical	LEAD, LEAD COMPONENTS	60%	7439-92-1
	BATTERY	State	Storage Container		Pressue		Corrosive To			
		Liquid	Other		< Ambient	Waste Code	Metal	SULFURIC ACID	30%	✓ 7664-93-9
		Type			Temperature		- Health Skin			
		Mixture	Days on Site: 365		< Ambient		Corrosion			
	Map: 1 Grid: C3						Irritation			
							- Health Serious			
							Eye Damage Eye			
							Irritation			

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility				Chemical Location		CERS ID	10096750			
Facility Name	Los Esteros Critical Energy Facility				PDC #2 (ENERSYS 4DX-11 60 UNITS)		Facility ID	FA0256442			
800 THOMAS FOON CHEW WY, San Jose 95134							Status	Submitted on 7/8/2025 12:14 PM			
				Quantities		Annual Waste Amount	Federal Hazard Categories	Hazardous Components (For mixture only)			
DOT Code/Fire Haz. Class	Common Name	Unit	Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt	EHS	CAS No.
DOT: 8 - Corrosives (Liquids and Solids) Corrosive	NON-SPILLABLE LEAD-ACID BATTERY CAS No Map: 1 Grid: E8	Gallons	840	14	840		- Physical	LEAD, LEAD COMPONENTS	60%		7439-92-1
		State	Storage Container		Pressue		Corrosive To				
		Liquid	Other		< Ambient	Waste Code	Metal	SULFURIC ACID	30%	✓	7664-93-9
		Type			Temperature		- Health Skin				
		Mixture	Days on Site: 365		< Ambient		Corrosion Irritation - Health Serious Eye Damage Eye Irritation				

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility				Chemical Location		CERS ID	10096750			
Facility Name	Los Esteros Critical Energy Facility				PDC #3 (ENERSYS 4DX-11 60 UNITS)		Facility ID	FA0256442			
800 THOMAS FOON CHEW WY, San Jose 95134							Status	Submitted on 7/8/2025 12:14 PM			
				Quantities		Annual Waste Amount	Federal Hazard Categories	Hazardous Components (For mixture only)			
DOT Code/Fire Haz. Class	Common Name	Unit	Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt	EHS	CAS No.
DOT: 8 - Corrosives (Liquids and Solids) Corrosive	NON-SPILLABLE LEAD-ACID BATTERY CAS No Map: 1 Grid: D8	Gallons	840	14	840		- Physical	LEAD, LEAD COMPONENTS	60%		7439-92-1
		State	Storage Container		Pressue		Corrosive To				
		Liquid	Other		< Ambient	Waste Code	Metal	SULFURIC ACID	30%	✓	7664-93-9
		Type			Temperature		- Health Skin				
		Mixture	Days on Site: 365		< Ambient		Corrosion Irritation - Health Serious Eye Damage Eye Irritation				

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility	Chemical Location	CERS ID	10096750
Facility Name	Los Esteros Critical Energy Facility	PDC #3 (HOPPECKE FNC 333L 19 UNITS)	Facility ID	FA0256442
	800 THOMAS FOON CHEW WY, San Jose 95134		Status	Submitted on 7/8/2025 12:14 PM

DOT Code/Fire Haz. Class	Common Name	Unit	Quantities			Annual Waste Amount	Federal Hazard Categories	Hazardous Components (For mixture only)		
			Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt	EHS CAS No.
DOT: 8 - Corrosives (Liquids and Solids) Corrosive	NI-CAD BATTERY	Gallons	41.8	2.52	41.8		- Physical			
		State	Storage Container		Pressue		Flammable			
		Liquid	Other		< Ambient	Waste Code	- Physical			✓
		Type			Temperature		Explosive			
		Mixture	Days on Site: 365		< Ambient		- Physical			
	Map: 1 Grid: D8						Corrosive To Metal			
							- Health			
							Carcinogenicity			
							- Health Acute			
							Toxicity			
							- Health			
							Reproductive			
							Toxicity			
							- Health Skin			
							Corrosion			
							Irritation			
							- Health Serious			
							Eye Damage Eye			
							Irritation			
							- Health Specific			
							Target Organ			
							Toxicity			

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility				Chemical Location		CERS ID	10096750		
Facility Name	Los Esteros Critical Energy Facility				PDC #3 (HOPPECKE FNC 66 L 19 UNITS)		Facility ID	FA0256442		
	800 THOMAS FOON CHEW WY, San Jose 95134						Status	Submitted on 7/8/2025 12:14 PM		
				Quantities		Annual Waste Amount	Federal Hazard Categories	Hazardous Components (For mixture only)		
DOT Code/Fire Haz. Class	Common Name	Unit	Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt	EHS CAS No.
DOT: 8 - Corrosives (Liquids and Solids)	NI-CAD BATTERY	Gallons	11.97	0.63	11.97		- Physical			
	CAS No	State	Storage Container		Pressue		Corrosive To			
		Liquid	Other		< Ambient	Waste Code	Metal			
Corrosive	Map: 1 Grid: D8	Type			Temperature		- Health Skin			
		Mixture	Days on Site: 365		< Ambient		Corrosion			
							Irritation			
							- Health Serious			
							Eye Damage Eye			
							Irritation			

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility				Chemical Location		CERS ID	10096750			
Facility Name	Los Esteros Critical Energy Facility				PDC #4 (ENERSYS 4DX-11 60 UNITS)		Facility ID	FA0256442			
800 THOMAS FOON CHEW WY, San Jose 95134							Status	Submitted on 7/8/2025 12:14 PM			
				Quantities		Annual Waste Amount	Federal Hazard Categories	Hazardous Components (For mixture only)			
DOT Code/Fire Haz. Class	Common Name	Unit	Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt	EHS	CAS No.
DOT: 8 - Corrosives (Liquids and Solids) Corrosive	NON-SPILLABLE LEAD-ACID BATTERY CAS No Map: 1 Grid: D3	Gallons	840	14	840		- Physical	LEAD, LEAD COMPONENTS	60%		7439-92-1
		State	Storage Container		Pressue		Corrosive To				
		Liquid	Other		< Ambient	Waste Code	Metal	SULFURIC ACID	30%	✓	7664-93-9
		Type			Temperature		- Health Skin				
		Mixture	Days on Site: 365		< Ambient		Corrosion Irritation - Health Serious Eye Damage Eye Irritation				

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility	Chemical Location	CERS ID	10096750
Facility Name	Los Esteros Critical Energy Facility	PDC #4 (HOPPECKE FNC 333L 19 UNITS)	Facility ID	FA0256442
	800 THOMAS FOON CHEW WY, San Jose 95134		Status	Submitted on 7/8/2025 12:14 PM

DOT Code/Fire Haz. Class	Common Name	Unit	Quantities			Annual Waste Amount	Federal Hazard Categories	Hazardous Components (For mixture only)		
			Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt	EHS CAS No.
DOT: 8 - Corrosives (Liquids and Solids) Corrosive	NI-CAD BATTERY	Gallons	41.8	2.52	41.8		- Physical			
		State	Storage Container		Pressue		Flammable			
		Liquid	Other		< Ambient	Waste Code	- Physical			✓
		Type			Temperature		Explosive			
		Mixture	Days on Site: 365		< Ambient		- Physical			
	Map: 1 Grid: D3						Corrosive To Metal			
							- Health			
							Carcinogenicity			
							- Health Acute			
							Toxicity			
							- Health			
							Reproductive			
							Toxicity			
							- Health Skin			
							Corrosion			
							Irritation			
							- Health Serious			
							Eye Damage Eye			
							Irritation			
							- Health Specific			
							Target Organ			
							Toxicity			

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility				Chemical Location		CERS ID	10096750		
Facility Name	Los Esteros Critical Energy Facility				PDC #4 (HOPPECKE FNC 66 L 19 UNITS)		Facility ID	FA0256442		
800 THOMAS FOON CHEW WY, San Jose 95134							Status	Submitted on 7/8/2025 12:14 PM		
				Quantities		Annual Waste Amount	Federal Hazard Categories		Hazardous Components (For mixture only)	
DOT Code/Fire Haz. Class	Common Name	Unit	Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt	EHS CAS No.
DOT: 8 - Corrosives (Liquids and Solids)	NI-CAD BATTERY	Gallons	11.97	0.63	11.97			- Physical		
	CAS No	State	Storage Container		Pressue			Corrosive To		
		Liquid	Other		< Ambient	Waste Code		Metal		
	Corrosive	Map: 1 Grid: D3	Type			Temperature		- Health Skin		
			Mixture	Days on Site: 365		< Ambient		Corrosion		
								Irritation		
								- Health Serious		
								Eye Damage Eye		
								Irritation		

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility				Chemical Location		CERS ID	10096750			
Facility Name	Los Esteros Critical Energy Facility				PDC #5 (ENERSYS 4DX-11 60 UNITS)		Facility ID	FA0256442			
800 THOMAS FOON CHEW WY, San Jose 95134							Status	Submitted on 7/8/2025 12:14 PM			
				Quantities		Annual Waste Amount	Federal Hazard Categories	Hazardous Components (For mixture only)			
DOT Code/Fire Haz. Class	Common Name	Unit	Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt	EHS	CAS No.
DOT: 8 - Corrosives (Liquids and Solids) Corrosive	NON-SPILLABLE LEAD-ACID BATTERY CAS No Map: 1 Grid: F2	Gallons	840	14	840		- Physical	LEAD, LEAD COMPONENTS	60%		7439-92-1
		State	Storage Container		Pressue		Corrosive To				
		Liquid	Other		< Ambient	Waste Code	Metal	SULFURIC ACID	30%	✓	7664-93-9
		Type			Temperature		- Health Skin				
		Mixture	Days on Site: 365		< Ambient		Corrosion Irritation - Health Serious Eye Damage Eye Irritation				

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility				Chemical Location		CERS ID	10096750			
Facility Name	Los Esteros Critical Energy Facility				PDC #7 (ENERSYS 4DX-11 60 UNITS)		Facility ID	FA0256442			
800 THOMAS FOON CHEW WY, San Jose 95134							Status	Submitted on 7/8/2025 12:14 PM			
				Quantities		Annual Waste Amount	Federal Hazard Categories	Hazardous Components (For mixture only)			
DOT Code/Fire Haz. Class	Common Name	Unit	Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt	EHS	CAS No.
DOT: 8 - Corrosives (Liquids and Solids) Corrosive	NON-SPILLABLE LEAD-ACID BATTERY CAS No Map: 1 Grid: E7	Gallons	840	14	840		- Physical	LEAD, LEAD COMPONENTS	60%		7439-92-1
		State	Storage Container		Pressue		Corrosive To				
		Liquid	Other		< Ambient	Waste Code	Metal	SULFURIC ACID	30%	✓	7664-93-9
		Type			Temperature		- Health Skin				
		Mixture	Days on Site: 365		< Ambient		Corrosion Irritation - Health Serious Eye Damage Eye Irritation				

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org. Los Esteros Critical Energy Facility			Chemical Location				CERS ID	10096750		
Facility Name Los Esteros Critical Energy Facility			RO SKIDS				Facility ID	FA0256442		
800 THOMAS FOON CHEW WY, San Jose 95134							Status	Submitted on 7/8/2025 12:14 PM		
DOT Code/Fire Haz. Class	Common Name	Unit	Quantities			Annual Waste Amount	Federal Hazard Categories	Hazardous Components (For mixture only)		
			Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt	EHS CAS No.
DOT: 8 - Corrosives (Liquids and Solids) Corrosive	CHEMTREAT RL124B	Gallons	165	55	110		- Physical			
	CAS No	State	Storage Container		Pressue	Waste Code	Corrosive To			
		Liquid	Plastic/Non-metalic Drum		Ambient		Metal			
		Type			Temperature		- Health			
		Mixture	Days on Site: 365		Ambient		Respiratory Skin Sensitization			
							- Health Serious			
							Eye Damage Eye Irritation			
DOT: 8 - Corrosives (Liquids and Solids) Corrosive	CHEMTREAT RL9007	Gallons	165	55	110		- Physical	Diethylenetriamine penta	20%	22042-96-2
	CAS No	State	Storage Container		Pressue	Waste Code	Corrosive To	methylene phosphonic acid		
		Liquid	Plastic/Non-metalic Drum		Ambient		Metal			
		Type			Temperature		- Health Skin			
		Mixture	Days on Site: 365		Ambient		Corrosion			
							Irritation			
							- Health Serious			
							Eye Damage Eye Irritation			

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility				Chemical Location	CERS ID 10096750			
Facility Name	Los Esteros Critical Energy Facility				SECONDARY UNIT SUBSTATION	Facility ID FA0256442			
800 THOMAS FOON CHEW WY, San Jose 95134						Status Submitted on 7/8/2025 12:14 PM			
								Hazardous Components (For mixture only)	
DOT Code/Fire Haz. Class	Common Name	Unit	Quantities			Annual Waste Amount	Federal Hazard Categories	Component Name	% Wt EHS CAS No.
DOT: 3 - Flammable and Combustible Liquids	LUBRICATING OIL	Gallons	Max. Daily	Largest Cont.	Avg. Daily		- Physical		
	CAS No	State	Storage Container			Pressue	Flammable		
		Liquid	Other			Ambient	- Health Acute		
	Map: 1 Grid: F4	Type				Temperature	Toxicity		
		Mixture	Days on Site: 365			Ambient			

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org. Los Esteros Critical Energy Facility			Chemical Location				CERS ID	10096750		
Facility Name Los Esteros Critical Energy Facility			SHOP AREA				Facility ID	FA0256442		
800 THOMAS FOON CHEW WY, San Jose 95134							Status	Submitted on 7/8/2025 12:14 PM		
DOT Code/Fire Haz. Class	Common Name	Unit	Quantities			Annual Waste Amount	Federal Hazard Categories	Hazardous Components (For mixture only)		
			Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt	EHS CAS No.
DOT: 2.1 - Flammable Gases	ACETYLENE	Cu. Feet	575	139	437	0	- Physical			
Unstable (Reactive), Class 2, Flammable Gas	CAS No 74-86-2 Map: 1 Grid: C7	State Gas Type Pure	Storage Container Cylinder Days on Site: 365		Pressue Ambient Temperature Ambient	Waste Code	Flammable - Physical Gas Under Pressure - Health Aspiration Hazard			
	AQUATENE 330GM	Gallons	75	5	55		- Health Acute Toxicity - Health Skin Corrosion Irritation - Health Serious Eye Damage Eye Irritation	Dipropylene Glycol Methyl Ether Triphosphoric Acid, Pentasodium Salt Silicic Acid (h2sio3), Disodium Salt	5% 5% 10%	34590-94-8 7758-29-4 6834-92-0
	CAS No 7440-37-1 Map: 1 Grid: C7	State Liquid Type Mixture	Storage Container Carboy Days on Site: 365		Pressue Ambient Temperature Ambient	Waste Code				
DOT: 2.2 - Nonflammable Gases	ARGON, COMPRESSED	Cu. Feet	875	250	776		- Physical Gas Under Pressure - Health Aspiration Hazard			
	CAS No 7440-37-1 Map: 1 Grid: C7	State Gas Type Pure	Storage Container Cylinder Days on Site: 365		Pressue Ambient Temperature Ambient	Waste Code				
	BAILEIGH COOLANT	Gallons	25	5	25		- Health Skin Corrosion Irritation - Health Respiratory Skin Sensitization - Health Serious Eye Damage Eye Irritation			
	CAS No Map: 1 Grid: C7	State Liquid Type Mixture	Storage Container Other Days on Site: 365		Pressue Ambient Temperature Ambient	Waste Code				
	BLAST-O-LITE INDUSTRIAL BEADS	Gallons	35	5	35		- Health Skin Corrosion Irritation			
	CAS No Map: 1 Grid: C7	State Solid Type Mixture	Storage Container Other Days on Site: 365		Pressue Ambient Temperature Ambient	Waste Code				
DOT: 3 - Flammable and Combustible Liquids	MISCELLANEOUS FLAMMABLES	Gallons	95	1	75		- Physical Flammable - Health Acute Toxicity - Health Serious Eye Damage Eye Irritation			
	CAS No Map: 1 Grid: C7	State Liquid Type Mixture	Storage Container Can Days on Site: 365		Pressue Ambient Temperature Ambient	Waste Code				
DOT: 2.2 - Nonflammable Gases	NITROGEN	Cu. Feet	330	116	272		- Physical Gas Under Pressure - Health Serious Eye Damage Eye Irritation			
	CAS No 7727-37-9 Map: 1 Grid: C7	State Gas Type Pure	Storage Container Cylinder Days on Site: 365		Pressue Ambient Temperature Ambient	Waste Code				

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility					Chemical Location	CERS ID	10096750		
Facility Name	Los Esteros Critical Energy Facility					SHOP AREA	Facility ID	FA0256442		
	800 THOMAS FOON CHEW WY, San Jose 95134						Status	Submitted on 7/8/2025 12:14 PM		
						Annual Waste Amount	Hazardous Components (For mixture only)			
DOT Code/Fire Haz. Class	Common Name	Unit	Quantities			Federal Hazard Categories	Component Name			
			Max. Daily	Largest Cont.	Avg. Daily		% Wt	EHS	CAS No.	
DOT: 2.2 - Nonflammable Gases	OXYGEN	Cu. Feet	785	337	712	- Physical Gas				
Oxidizing, Class 2	CAS No	State	Storage Container		Pressue	Waste Code	Under Pressure			
	7782-44-7	Gas	Cylinder		Ambient		- Physical Oxidizer			
	Map: 1 Grid: C7	Type			Temperature		- Health Hazard			
		Pure			Ambient		Not Otherwise Classified			
DOT: 2.2 - Nonflammable Gases	SULFUR HEXAFLUORIDE (SF6)	Cu. Feet	172	115	172	- Physical Gas				
	CAS No	State	Storage Container		Pressue	Waste Code	Under Pressure			
	2551-62-4	Gas	Cylinder		Ambient		- Health Simple			
		Type			Temperature		Asphyxiant			
		Pure	Days on Site: 365		Ambient					

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility				Chemical Location		CERS ID	10096750		
Facility Name	Los Esteros Critical Energy Facility				SITE PDC / MCC ROOMS		Facility ID	FA0256442		
	800 THOMAS FOON CHEW WY, San Jose 95134						Status	Submitted on 7/8/2025 12:14 PM		
				Quantities		Annual Waste Amount	Federal Hazard Categories	Hazardous Components (For mixture only)		
DOT Code/Fire Haz. Class	Common Name	Unit	Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt	EHS CAS No.
DOT: 2.2 - Nonflammable Gases	DUPONT HCFC-227	Pounds	2910	468	2910		- Physical Gas	HEPTAFLUOROPROPANE	100%	431-89-0
	CAS No	State	Storage Container		Pressue	Waste Code	Under Pressure			
	431-89-0	Gas	Other		Ambient		- Health			
	Map: E8,D3,F8 Grid: E3,E7,C3,C5	Type			Temperature		Respiratory Skin			
		Pure	Days on Site: 365		Ambient		Sensitization			

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility				Chemical Location		CERS ID	10096750		
Facility Name	Los Esteros Critical Energy Facility				STEAM TURBINE LUBE OIL RESERVOIR		Facility ID	FA0256442		
	800 THOMAS FOON CHEW WY, San Jose 95134						Status	Submitted on 7/8/2025 12:14 PM		
				Quantities		Annual Waste Amount	Federal Hazard Categories	Hazardous Components (For mixture only)		
DOT Code/Fire Haz. Class	Common Name	Unit	Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt	EHS CAS No.
DOT: 9 - Misc. Hazardous Materials	SHELL TURBO J 32	Gallons	10058	10058	10058		- Physical Hazard			
	CAS No	State	Storage Container		Pressue		Not Otherwise			
		Liquid	Other		Ambient	Waste Code	Classified			
	Map: 1 Grid: H3	Type			Temperature		- Health Hazard			
		Mixture	Days on Site: 365		Ambient		Not Otherwise			
							Classified			

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility				Chemical Location	CERS ID 10096750			
Facility Name	Los Esteros Critical Energy Facility				STEAM TURBINE UNDERDECK	Facility ID FA0256442			
	800 THOMAS FOON CHEW WY, San Jose 95134					Status Submitted on 7/8/2025 12:14 PM			
					Quantities	Annual Waste Amount	Federal Hazard Categories	Hazardous Components (For mixture only)	
DOT Code/Fire Haz. Class	Common Name	Unit	Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt EHS CAS No.
DOT: 2.2 - Nonflammable Gases	CARBON DIOXIDE (Fire Extinguishing Agent and Expellant)	Pounds	1200	100	1200		- Physical Gas		
		State	Storage Container		Pressue	Waste Code	Under Pressure		
		Gas	Cylinder		Ambient		- Health Simple		
		Type			Temperature		Asphyxiant		
		Pure	Days on Site: 365		Ambient				
	CAS No								
	124-38-9								
	Map: D4 Grid: D7								

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility				Chemical Location	CERS ID 10096750			
Facility Name	Los Esteros Critical Energy Facility				STG GSU TRANSFORMER	Facility ID FA0256442			
	800 THOMAS FOON CHEW WY, San Jose 95134					Status Submitted on 7/8/2025 12:14 PM			
					Quantities	Annual Waste Amount	Federal Hazard Categories	Hazardous Components (For mixture only)	
DOT Code/Fire Haz. Class	Common Name	Unit	Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt EHS CAS No.
	DIELECTRIC OIL	Gallons	9010	9010	9010		- Physical Hazard		
	CAS No	State	Storage Container		Pressue	Waste Code	Not Otherwise Classified		
		Liquid	Other		Ambient		- Health		
	Map: 1 Grid: F2	Type			Temperature		Aspiration Hazard		
		Mixture	Days on Site: 365		Ambient				

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility	Chemical Location					CERS ID	10096750		
Facility Name	Los Esteros Critical Energy Facility	STG OILY WATER SEPARATOR #3					Facility ID	FA0256442		
	800 THOMAS FOON CHEW WY, San Jose 95134						Status	Submitted on 7/8/2025 12:14 PM		
						Annual Waste Amount	Federal Hazard Categories	Hazardous Components (For mixture only)		
DOT Code/Fire Haz. Class	Common Name	Unit	Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt	EHS CAS No.
	USED OIL	Gallons	384	384	250	384	- Health			
	CAS No	State	Storage Container		Pressue	Waste Code	Carcinogenicity			
	70514-12-4	Liquid	Other		< Ambient		- Health			
		Type			Temperature		Reproductive			
		Mixture	Days on Site: 365		< Ambient		Toxicity			
							- Health Skin			
							Corrosion			
							Irritation			
							- Health			
							Respiratory Skin			
							Sensitization			
							- Health Serious			
							Eye Damage Eye			
							Irritation			
							- Health Specific			
							Target Organ			
							Toxicity			
							- Health			
							Aspiration Hazard			
							- Health Germ			
							Cell Mutagenicity			

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility				Chemical Location		CERS ID	10096750		
Facility Name	Los Esteros Critical Energy Facility				SWITCH YARD (ENERSYS 4DX-11 60 UNITS)		Facility ID	FA0256442		
800 THOMAS FOON CHEW WY, San Jose 95134							Status	Submitted on 7/8/2025 12:14 PM		
				Quantities		Annual Waste Amount	Federal Hazard Categories		Hazardous Components (For mixture only)	
DOT Code/Fire Haz. Class	Common Name	Unit	Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt	EHS CAS No.
DOT: 8 - Corrosives (Liquids and Solids) Corrosive	NON-SPILLABLE LEAD-ACID BATTERY CAS No Map: 1 Grid: B1	Gallons	840	14	840		- Physical	LEAD, LEAD COMPONENTS	60%	7439-92-1
		State	Storage Container		Pressue		Corrosive To			
		Liquid	Other		< Ambient	Waste Code	Metal	SULFURIC ACID	30%	✓ 7664-93-9
		Type			Temperature		- Health Skin			
		Mixture	Days on Site: 365		< Ambient		Corrosion Irritation - Health Serious Eye Damage Eye Irritation			

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility				Chemical Location	CERS ID 10096750			
Facility Name	Los Esteros Critical Energy Facility				SWITCHYARD (14 BREAKERS)	Facility ID FA0256442			
	800 THOMAS FOON CHEW WY, San Jose 95134					Status Submitted on 7/8/2025 12:14 PM			
					Quantities	Annual Waste Amount	Federal Hazard Categories	Hazardous Components (For mixture only)	
DOT Code/Fire Haz. Class	Common Name	Unit	Max. Daily	Largest Cont.	Avg. Daily			Component Name	% Wt EHS CAS No.
DOT: 2.2 - Nonflammable Gases	SULFUR HEXAFLUORIDE (SF6)	Cu. Feet	1280	128	1280		- Physical Gas		
	CAS No	State	Storage Container		Pressue	Waste Code	Under Pressure		
	2551-62-4	Gas	Other		Ambient		- Health Simple		
	Map: 1 Grid: B1	Type			Temperature		Asphyxiant		
		Pure	Days on Site: 365		Ambient				

Hazardous Materials And Wastes Inventory Matrix Report

CERS Business/Org.	Los Esteros Critical Energy Facility				Chemical Location		CERS ID	10096750		
Facility Name	Los Esteros Critical Energy Facility				TURBINE PACKAGES		Facility ID	FA0256442		
	800 THOMAS FOON CHEW WY, San Jose 95134						Status	Submitted on 7/8/2025 12:14 PM		
							Hazardous Components (For mixture only)			
DOT Code/Fire Haz. Class	Common Name	Unit	Quantities			Annual Waste Amount	Federal Hazard Categories	Component Name	% Wt	EHS CAS No.
			Max. Daily	Largest Cont.	Avg. Daily					
DOT: 2.2 - Nonflammable Gases	CARBON DIOXIDE	Pounds	4800	100	4800		- Physical Gas			
	CAS No	State	Storage Container		Pressue	Waste Code	Under Pressure			
	124-38-9	Gas	Cylinder		< Ambient		- Health			
	Map: 1 Grid: D7, D4, E4, E7	Type			Temperature		Respiratory Skin			
		Pure	Days on Site: 365		Ambient		Sensitization			
							- Health Simple			
							Asphyxiant			

Appendix 8



Cooling Tower Inspection Checklist

SM-CKLIST

Cell 10 p1

Tower Location Metcalf
Owner/Company Calpine
Company Contact _____
Signature _____
Owner's Tower Designation _____
Tower Manufacturer _____
Process Served by Tower _____
Design Conditions: GPM _____ HW _____ ° F CW _____ ° F WB _____ ° F
Cell No. 10 Number of Fan Cells 10
Date Tower was installed _____

Date Inspected May 13th through 25th
Inspected by Pat Mannion
Inspector _____
Signature Pat Mannion
Model No. _____ Serial No. _____
Operation: Continuous ☐ Intermittent ☐ Seasonal ☐
Tower Type: Crossflow ☐ Counterflow ☐

Condition: 1-Good 2-Keep an eye on it 3-Needs immediate attention

Structure

Casing Material _____
Structural Material _____
Fan Deck Material _____
Stairway ☐ Material _____
Ladder ☐ Material _____
Handrail ☐ Material _____
Interior Walkway ☐ Material _____
Cold Water Basin Material _____
Silt, Debris Buildup _____

1	2	3	Comments
x			Concrete basin fiberglass siding and stairs
x			Fiberglass
x			Fiberglass
x			Fiberglass
x			Fiberglass
x			Fiberglass
			no interior walkway
x			Concrete
x			No excess silt or debris

Water Distribution System

Open Basin System

Distribution Basin Material _____
Inlet Pipe Material _____
Inlet Manifold Material _____
Flow Control Valves _____ Size _____
Nozzles—Orifice Diameter _____ Size _____
Silt, Algae, Debris _____

	x		PVC
	x		PVC
	x		PVC
	x		PVC
	x		Replaced and or repaired many nozzles in all cells
	x		Plant was down for prolonged Outage, H2O to be chemically treated when back in service

Spray Type System

Header Pipe Material _____
Branch Pipe Material _____
Nozzles—Orifice Diameter _____ Size _____
Up spray ☐ Down spray ☐

	x		
	x		
	x		

Heat Transfer System

Fill—Type & Material _____
Eliminators—Type & Material _____
Louvers—Type & Material _____
Biological Fouling _____

	x		Fill is getting brittle, see attached pics of damage
	x		fiberglass
		x	Air operated plumb abatement louvers do not work
		x	somewhat normal build up on heat transfer coils

Use this space to list specific items needing attention: _____

Condition: 1—Good 2—Keep an eye on it 3—Needs immediate attention

Cell 10

P2

Mechanical Equipment

1	2	3	Comments
---	---	---	----------

Speed Reducer Type: Belt ☐ Gear ☒ Direct Drive ☐

Belt Drive Unit

Belt Designation N/A

Fan Sheave Designation N/A

Motor Sheave Designation N/A

Gear Drive Unit

Manufacturer MARLEY Model R4000 566 Ratio _____

Oil Level: Full ☒ Add Immediately ☐ Low, check again soon ☐

Oil Condition: Good ☐ Contains Water ☐ Contains Metal ☐ Contains Sludge ☐

Oil Type Used _____ Oil is sent out for scheduled oil testing

Seals pinion seal leak

Backlash _____

Fan Shaft Endplay _____

Unusual Noises? No ☐ Yes ☐

	X	after inspection was complete, verified correct oil level
	X	in gear box to correct level on site glass and topped
	X	up all gearboxes to FULL mark on site glass

Action Required _____

Drive Shaft

Manufacturer _____ Material _____

X		carbon fiber shaft with flex plate couplings
---	--	--

Fan

Fan Type: Propeller ☒ Blower ☐

Manufacturer _____

Diameter _____

noise heard when rotating shaft

Fixed Pitch ☐ Adjustable Pitch ☐

Number of Blades 10 see recorded

Blade Material fiberglass

Hub Material aluminum

Hub Cover Material fiberglass

Blade Assembly Hardware stainless

Tip Clearance _____ " min _____ " max

Vibration Level _____

Fan Cylinder Height _____

Mechanical Equipment Support _____

Oil Fill and Drain Line _____

Oil Level Sight Glass _____

Vibration Limit Switch _____

	X	heavy chemical build up (see pictures)
	X	
	X	
	X	
	X	g/box support foundation beam OK
	X	Secured all drain and breather lines in cell tower to stop
	X	them vibrating
	X	did not test switch for trip

Motor

Manufacturer _____

Name Plate Data: HP _____ RPM _____ Phase _____ Hz _____ Volts _____

F L Amps _____ Frame _____ S F _____ Special Info. _____

Last Lubrication—Date _____

Grease Used—Type _____

Unusual Noises? No ☐ Yes ☐ Action Required _____

Unusual Vibration? No ☐ Yes ☐ Action Required _____

Unusual Heat Build-up? No ☐ Yes ☐ Action Required _____

Make-up Valve _____

Other Component _____

Other Component _____



Cooling Tower Inspection Checklist

SM-CKLIST

Cell 9 p1

Tower Location Metcalf Date Inspected May 13th through 25th
Owner/Company Calpine Inspected by Pat Mannion
Company Contact _____ Inspector _____
Signature _____ Signature [Signature]
Owner's Tower Designation _____
Tower Manufacturer _____ Model No. _____ Serial No. _____
Process Served by Tower _____ Operation: Continuous ☐ Intermittent ☐ Seasonal ☐
Design Conditions: GPM _____ HW _____ ° F CW _____ ° F WB _____ ° F
Cell No. 9 Number of Fan Cells 10 Tower Type: Crossflow ☐ Counterflow ☐
Date Tower was installed _____

Condition: 1-Good 2-Keep an eye on it 3-Needs immediate attention

Structure

Casing Material _____
Structural Material _____
Fan Deck Material _____
Stairway ☐ Material _____
Ladder ☐ Material _____
Handrail ☐ Material _____
Interior Walkway ☐ Material _____
Cold Water Basin Material _____
Silt, Debris Buildup _____

1	2	3	Comments
x			Concrete basin fiberglass siding and stairs
x			Fiberglass
x			Fiberglass
x			Fiberglass
x			Fiberglass
x			Fiberglass
			no interior walkway
x			Concrete
x			No excess silt or debris

Water Distribution System

Open Basin System

Distribution Basin Material _____
Inlet Pipe Material _____
Inlet Manifold Material _____
Flow Control Valves _____ Size _____
Nozzles—Orifice Diameter _____ Size _____
Silt, Algae, Debris _____

Spray Type System

Header Pipe Material _____
Branch Pipe Material _____
Nozzles—Orifice Diameter _____ Size _____
Up spray ☐ Down spray ☐

	x		PVC
	x		PVC
	x		PVC
	x		PVC
	x		Replaced and or repaired many nozzles in all cells
	x		Plant was down for prolonged Outage, H2O to be chemically treated when back in service

Heat Transfer System

Fill—Type & Material _____
Eliminators—Type & Material _____
Louvers—Type & Material _____
Biological Fouling _____

	x		Fill is getting brittle, see attached pics of damage
	x		Air operated plumb abatement louvers do not work
	x		somewhat normal build up on heat transfer coils

Use this space to list specific items needing attention: _____

Condition: 1—Good 2—Keep an eye on it 3—Needs immediate attention

Cell 9 p 2

Mechanical Equipment

1	2	3	Comments
---	---	---	----------

Speed Reducer Type: Belt ☐ Gear ☒ Direct Drive ☐

Belt Drive Unit

Belt Designation N/A

Fan Sheave Designation N/A

Motor Sheave Designation N/A

Gear Drive Unit

Manufacturer Amarillo rebuild Model Marley M4000 Ratio 15.84:1

Oil Level: Full ☒ Add Immediately ☐ Low, check again soon ☐

Oil Condition: Good ☐ Contains Water ☐ Contains Metal ☐ Contains Sludge ☐

Oil Type Used Oil is sent out for scheduled oil testing

Seals

Backlash

Fan Shaft Endplay

Unusual Noises? No ☐ Yes ☐

	X		after inspection was complete, verified correct oil level
	X		in gear box to correct level on site glass and topped
	X		up all gearboxes to FULL mark on site glass

Action Required

Drive Shaft

Manufacturer Material

X			carbon fiber shaft with flex plate couplings
---	--	--	--

Fan

Fan Type: Propeller ☒ Blower ☐

Manufacturer

Diameter

Fixed Pitch ☐ Adjustable Pitch ☒

Number of Blades 10

Blade Material fiberglass

Hub Material aluminum

Hub Cover Material fiberglass

Blade Assembly Hardware stainless

Tip Clearance " min " max

Vibration Level

Fan Cylinder Height

Mechanical Equipment Support

Oil Fill and Drain Line

Oil Level Sight Glass

Vibration Limit Switch

	X		
	X		
	X		
	Y		g/box support foundation beam OK
	X		Secured all drain and breather lines in cell tower to stop
	X		them vibrating
	X		did not test switch for trip

Motor

Manufacturer

Name Plate Data: HP RPM Phase Hz Volts

F L Amps Frame S F Special Info.

Last Lubrication—Date

Grease Used—Type

Unusual Noises? No ☐ Yes ☐ Action Required

Unusual Vibration? No ☐ Yes ☐ Action Required

Unusual Heat Build-up? No ☐ Yes ☐ Action Required

Make-up Valve

Other Component

Other Component



Cooling Tower Inspection Checklist

SM-CKLIST

Cell 8 p1

Tower Location Metcalf
Owner/Company Calpine
Company Contact _____
Signature _____
Owner's Tower Designation _____
Tower Manufacturer _____
Process Served by Tower _____
Design Conditions: GPM _____ HW _____ ° F
Cell No. 8 Number of Fan Cells 10
Date Tower was installed _____

Date Inspected May 13th through 25th
Inspected by Pat Mannion
Inspector _____
Signature Pat Mannion
Model No. _____ Serial No. _____
Operation: Continuous ☐ Intermittent ☐ Seasonal ☐
° F CW _____ ° F WB _____ ° F
Tower Type: Crossflow ☐ Counterflow ☐

Condition: 1-Good 2-Keep an eye on it 3-Needs immediate attention

Structure

Casing Material _____
Structural Material _____
Fan Deck Material _____
Stairway ☐ Material _____
Ladder ☐ Material _____
Handrail ☐ Material _____
Interior Walkway ☐ Material _____
Cold Water Basin Material _____
Silt, Debris Buildup _____

1	2	3	Comments
x			Concrete basin fiberglass siding and stairs
x			Fiberglass
x			Fiberglass
x			Fiberglass
x			Fiberglass
x			Fiberglass
			no interior walkway
x			Concrete
x			No excess silt or debris

Water Distribution System

Open Basin System

Distribution Basin Material _____
Inlet Pipe Material _____
Inlet Manifold Material _____
Flow Control Valves _____ Size _____
Nozzles—Orifice Diameter _____ Size _____
Silt, Algae, Debris _____

	x		PVC
	x		PVC
	x		PVC
	x		PVC
	x		Replaced and or repaired many nozzles in all cells
	x		Plant was down for prolonged Outage, H2O to be chemically treated when back in service

Spray Type System

Header Pipe Material _____
Branch Pipe Material _____
Nozzles—Orifice Diameter _____ Size _____
Up spray ☐ Down spray ☐

	x		
	x		
	x		

Heat Transfer System

Fill—Type & Material _____
Eliminators—Type & Material _____
Louvers—Type & Material _____
Biological Fouling _____

	x		Fill is getting brittle, see attached pics of damage
	x		fiberglass
		x	Air operated plumb abatement louvers do not work
	x		somewhat normal build up on heat transfer coils

Use this space to list specific items needing attention: _____



Cooling Tower Inspection Checklist

SM-CKLIST

Cell 7 p 1

Tower Location Metcalf
Owner/Company Calpine
Company Contact _____
Signature _____
Owner's Tower Designation _____
Tower Manufacturer _____
Process Served by Tower _____
Design Conditions: GPM _____ HW _____ ° F
Cell No. 7 Number of Fan Cells 10
Date Tower was installed _____

Date Inspected May 13th through 25th
Inspected by Pat Mannion
Inspector _____
Signature Pat Mannion
Model No. _____ Serial No. _____
Operation: Continuous ☐ Intermittent ☐ Seasonal ☐
° F CW _____ ° F WB _____ ° F
Tower Type: Crossflow ☐ Counterflow ☐

Condition: 1-Good 2-Keep an eye on it 3-Needs immediate attention

Structure

Casing Material _____
Structural Material _____
Fan Deck Material _____
Stairway ☐ Material _____
Ladder ☐ Material _____
Handrail ☐ Material _____
Interior Walkway ☐ Material _____
Cold Water Basin Material _____
Silt, Debris Buildup _____

1	2	3	Comments
x			Concrete basin fiberglass siding and stairs
x			Fiberglass
x			Fiberglass
x			Fiberglass
x			Fiberglass
x			Fiberglass
			no interior walkway
x			Concrete
x			No excess silt or debris

Water Distribution System

Open Basin System

Distribution Basin Material _____
Inlet Pipe Material _____
Inlet Manifold Material _____
Flow Control Valves _____ Size _____
Nozzles—Orifice Diameter _____ Size _____
Silt, Algae, Debris _____

	x		PVC
	x		PVC
	x		PVC
	x		PVC
	x		Replaced and or repaired many nozzles in all cells
	x		Plant was down for prolonged Outage, H2O to be chemically treated when back in service

Spray Type System

Header Pipe Material ABS plastic
Branch Pipe Material _____
Nozzles—Orifice Diameter _____ Size _____
Up spray ☐ Down spray ☐

	x		
	x		
	x		

Heat Transfer System

Fill—Type & Material _____
Eliminators—Type & Material _____
Louvers—Type & Material _____
Biological Fouling _____

	x		Fill is getting brittle, see attached pics of damage
	x		fiberglass
	x		Air operated plumb abatement louvers do not work
	x		somewhat normal build up on heat transfer coils

Use this space to list specific items needing attention:

Cell 7_{p2}

1	2	3	Comments
---	---	---	----------

Belt Drive Unit

Manufacturer Marley Model _____ Ratio label unreadable.

Oil Type Used Oil is sent out for scheduled oil testing

	X		after inspection was complete, verified correct oil level
	X		in gear box to correct level on site glass and topped
	X		up all gearboxes to FULL mark on site glass

Fan Shaft Endplay

Action Required

Manufacturer	Material
--------------	----------

X			carbon fiber shaft with flex plate couplings
---	--	--	--

Fan Type: Propeller ☒ Blower ☐

Fixed Pitch ☐ Adjustable Pitch ☐

Number of Blades

x	starting to determine
---	-----------------------

	X		working in such as the
--	---	--	------------------------

	X		
--	---	--	--

	X		
--	---	--	--

--	--	--	--

--	--	--	--

[illegible]

			g/box support foundation beam OK
--	--	--	----------------------------------

	x	Secured all drain and breather lines in cell tower to stop
--	---	--

	x	them vibrating
--	---	----------------

x	did not test switch for trip
---	------------------------------

Manufacturer

F L Amps	Frame	S F	Special Info.
----------	-------	-----	---------------

Grease Used—Type

Unusual Vibration?	No <input type="checkbox"/>	Yes <input type="checkbox"/>	Action Required

--	--	--	--

[illegible]

--	--	--	--



Cooling Tower Inspection Checklist

SM-CKLIST

Cell 6 p1

Tower Location Metcalf
Owner/Company Calpine
Company Contact _____
Signature _____
Owner's Tower Designation _____
Tower Manufacturer _____
Process Served by Tower _____
Design Conditions: GPM _____ HW _____ ° F
Cell No. 6 Number of Fan Cells 10
Date Tower was installed _____

Date Inspected May 13th through 25th
Inspected by Pat Mannion
Inspector _____
Signature _____
Model No. _____ Serial No. _____
Operation: Continuous ☐ Intermittent ☐ Seasonal ☐
° F CW _____ ° F WB _____ ° F
Tower Type: Crossflow ☐ Counterflow ☐

Condition: 1-Good 2-Keep an eye on it 3-Needs immediate attention

Structure

Casing Material _____
Structural Material _____
Fan Deck Material _____
Stairway ☐ Material _____
Ladder ☐ Material _____
Handrail ☐ Material _____
Interior Walkway ☐ Material _____
Cold Water Basin Material _____
Silt, Debris Buildup _____

1	2	3	Comments
x			Concrete basin fiberglass siding and stairs
x			Fiberglass
x			Fiberglass
x			Fiberglass
x			Fiberglass
x			Fiberglass
			no interior walkway
x			Concrete
x			No excess silt or debris

Water Distribution System

Open Basin System

Distribution Basin Material _____
Inlet Pipe Material _____
Inlet Manifold Material _____
Flow Control Valves _____ Size _____
Nozzles—Orifice Diameter _____ Size _____
Silt, Algae, Debris _____

	x		PVC
	x		PVC
	x		PVC
	x		PVC
	x		Replaced and or repaired many nozzles in all cells
	x		Plant was down for prolonged Outage, H2O to be chemically treated when back in service

Spray Type System

Header Pipe Material _____
Branch Pipe Material _____
Nozzles—Orifice Diameter _____ Size _____
Up spray ☐ Down spray ☐

	x		
	x		
	x		

Heat Transfer System

Fill—Type & Material _____
Eliminators—Type & Material _____
Louvers—Type & Material _____
Biological Fouling _____

	x		Fill is getting brittle, see attached pics of damage
	x		fiberglass
		x	Air operated plumb abatement louvers do not work
	x		somewhat normal build up on heat transfer coils

Use this space to list specific items needing attention: _____

Cell 6 p 2

Condition: 1—Good 2—Keep an eye on it 3—Needs immediate attention

Mechanical Equipment

1	2	3	Comments
---	---	---	----------

Speed Reducer Type: Belt ☐ Gear ☒ Direct Drive ☐

Belt Drive Unit

Belt Designation N/A

Fan Sheave Designation N/A

Motor Sheave Designation N/A

Gear Drive Unit

Manufacturer _____ Model _____ Ratio _____

Oil Level: Full ☒ Add Immediately ☐ Low, check again soon ☐

Oil Condition: Good ☐ Contains Water ☐ Contains Metal ☐ Contains Sludge ☐

Oil Type Used Oil is sent out for scheduled oil testing

Seals _____

Backlash _____

Fan Shaft Endplay _____

Unusual Noises? No ☐ Yes ☐

				after inspection was complete, verified correct oil level
	X			in gear box to correct level on site glass and topped
	X			up all gearboxes to FULL mark on site glass

Action Required _____

Drive Shaft

Manufacturer _____ Material _____

X			carbon fiber shaft with flex plate couplings
---	--	--	--

Fan

Fan Type: Propeller ☐ Blower ☐

Manufacturer _____

Fixed Pitch ☐ Adjustable Pitch ☐

Diameter _____

Number of Blades _____

Blade Material fiberglass

Hub Material aluminum

Hub Cover Material fiberglass

Blade Assembly Hardware stainless

Tip Clearance _____ " min _____ " max

Vibration Level _____

Fan Cylinder Height _____

Mechanical Equipment Support _____

Oil Fill and Drain Line _____

Oil Level Sight Glass _____

Vibration Limit Switch _____

	X		
	X		
	X		
	X		
			OK
	X		g/box support foundation beam OK bolts were loose
	X		Secured all drain and breather lines in cell tower to stop
	X		them vibrating
	X		did not test switch for trip

Motor

Manufacturer _____

Name Plate Data: HP _____ RPM _____ Phase _____ Hz _____ Volts _____

F L Amps _____ Frame _____ S F _____ Special Info. _____

Last Lubrication—Date _____

Grease Used—Type _____

Unusual Noises? No ☐ Yes ☐ Action Required _____

Unusual Vibration? No ☐ Yes ☐ Action Required _____

Unusual Heat Build-up? No ☐ Yes ☐ Action Required _____

Make-up Valve _____

Other Component _____

Other Component _____



Cooling Tower Inspection Checklist

SM-CKLIST

Cell 5 p 1

Tower Location MetcalfDate Inspected May 13th through 25thOwner/Company CalpineInspected by Pat Mannion

Company Contact _____

Inspector _____

Signature _____

Signature _____

Owner's Tower Designation _____

Tower Manufacturer _____

Model No. _____ Serial No. _____

Process Served by Tower _____

Operation: Continuous ☐ Intermittent ☐ Seasonal ☐

Design Conditions: GPM _____ HW _____ ° F

CW _____ ° F WB _____ ° F

Cell No. _____ Number of Fan Cells 10Tower Type: Crossflow ☐ Counterflow ☐

Date Tower was installed _____

Condition: 1-Good 2-Keep an eye on it 3-Needs immediate attention

Structure

Casing Material _____

Structural Material _____

Fan Deck Material _____

Stairway ☐ Material _____Ladder ☐ Material _____Handrail ☐ Material _____Interior Walkway ☐ Material _____

Cold Water Basin Material _____

Silt, Debris Buildup _____

1	2	3	Comments
x			Concrete basin fiberglass siding and stairs
x			Fiberglass
x			Fiberglass
x			Fiberglass
x			Fiberglass
x			Fiberglass
			no interior walkway
x			Concrete
x			No excess silt or debris

Water Distribution System

Open Basin System

Distribution Basin Material _____

Inlet Pipe Material _____

Inlet Manifold Material _____

Flow Control Valves _____ Size _____

Nozzles—Orifice Diameter _____ Size _____

Silt, Algae, Debris _____

Spray Type System

Header Pipe Material _____

Branch Pipe Material _____

Nozzles—Orifice Diameter _____ Size _____

Up spray ☐ Down spray ☐

	x		PVC
	x		PVC
	x		PVC
	x		PVC
	x		Replaced and or repaired many nozzles in all cells
	x		Plant was down for prolonged Outage. H2O to be chemically treated when back in service
	x		
	x		
	x		

Heat Transfer System

Fill—Type & Material _____

Eliminators—Type & Material _____

Louvers—Type & Material _____

Biological Fouling _____

	x		Fill is getting brittle, see attached pics of damage
	x		fiberglass
		x	Air operated plumb abatement louvers do not work
	x		somewhat normal build up on heat transfer coils

Use this space to list specific items needing attention: _____

Condition: 1—Good 2—Keep an eye on it 3—Needs immediate attention

Cell 5
PZ

Mechanical Equipment

Speed Reducer Type: Belt ☐ Gear ☒ Direct Drive ☐

1	2	3	Comments
---	---	---	----------

Belt Drive Unit

Belt Designation N/A
Fan Sheave Designation N/A
Motor Sheave Designation N/A

Gear Drive Unit

Manufacturer Marley Model 0567C68358 Ratio ~~label unavailable~~
Oil Level: Full ☒ Add Immediately ☐ Low, check again soon ☐
Oil Condition: Good ☐ Contains Water ☐ Contains Metal ☐ Contains Sludge ☐

Oil Type Used Oil is sent out for scheduled oil testing

Seals _____
Backlash _____
Fan Shaft Endplay _____
Unusual Noises? No ☐ Yes ☐

			after inspection was complete, verified correct oil level
	X		in gear box to correct level on site glass and topped
	X		up all gearboxes to FULL mark on site glass

Action Required _____

Drive Shaft

Manufacturer _____ Material _____

X			carbon fiber shaft with flex plate couplings
---	--	--	--

Fan

Fan Type: Propeller ☒ Blower ☐

Manufacturer _____
Diameter _____

Fixed Pitch ☐ Adjustable Pitch ☐
Number of Blades _____

Blade Material fiberglass
Hub Material aluminum
Hub Cover Material fiberglass
Blade Assembly Hardware stainless
Tip Clearance _____" min _____" max
Vibration Level _____

	X		
	X		
	X		
	X		
	X		g/box support foundation beam OK
	X		Secured all drain and breather lines in cell tower to stop
	X		them vibrating
	X		did not test switch for trip

Fan Cylinder Height _____
Mechanical Equipment Support _____
Oil Fill and Drain Line _____
Oil Level Sight Glass _____
Vibration Limit Switch _____

Motor

Manufacturer _____
Name Plate Data: HP _____ RPM _____ Phase _____ Hz _____ Volts _____
F L Amps _____ Frame _____ S F _____ Special Info. _____
Last Lubrication—Date _____
Grease Used—Type _____
Unusual Noises? No ☐ Yes ☐ Action Required _____
Unusual Vibration? No ☐ Yes ☐ Action Required _____
Unusual Heat Build-up? No ☐ Yes ☐ Action Required _____

Make-up Valve _____

Other Component _____

Other Component _____



Cooling Tower Inspection Checklist

SM-CKLIST

Cell 4 p1

Tower Location Metcalf
Owner/Company Calpine
Company Contact _____
Signature _____
Owner's Tower Designation _____
Tower Manufacturer _____
Process Served by Tower _____
Design Conditions: GPM _____ HW _____ ° F
Cell No. _____ Number of Fan Cells 10
Date Tower was installed _____

Date Inspected May 13th through 25th
Inspected by Pat Mannion
Inspector _____
Signature _____
Model No. _____ Serial No. _____
Operation: Continuous ☐ Intermittent ☐ Seasonal ☐
° F CW _____ ° F WB _____ ° F
Tower Type: Crossflow ☐ Counterflow ☐

Condition: 1-Good 2-Keep an eye on it 3-Needs immediate attention

Structure

Casing Material _____
Structural Material _____
Fan Deck Material _____
Stairway ☐ Material _____
Ladder ☐ Material _____
Handrail ☐ Material _____
Interior Walkway ☐ Material _____
Cold Water Basin Material _____
Silt, Debris Buildup _____

1	2	3	Comments
x			Concrete basin fiberglass siding and stairs
x			Fiberglass
x			Fiberglass
x			Fiberglass
x			Fiberglass
x			Fiberglass
			no interior walkway
x			Concrete
x			No excess silt or debris

Water Distribution System

Open Basin System

Distribution Basin Material _____
Inlet Pipe Material _____
Inlet Manifold Material _____
Flow Control Valves _____ Size _____
Nozzles—Orifice Diameter _____ Size _____
Silt, Algae, Debris _____

	x		PVC
	x		PVC
	x		PVC
	x		PVC
	x		Replaced and or repaired many nozzles in all cells
	x		Plant was down for prolonged Outage, H2O to be chemically treated when back in service

Spray Type System

Header Pipe Material _____
Branch Pipe Material _____
Nozzles—Orifice Diameter _____ Size _____
Up spray ☐ Down spray ☐

	x		
	x		
	x		

Heat Transfer System

Fill—Type & Material _____
Eliminators—Type & Material _____
Louvers—Type & Material _____
Biological Fouling _____

	x		Fill is getting brittle, see attached pics of damage
	x		Air operated plumb abatement louvers do not work
	x		somewhat normal build up on heat transfer coils

Use this space to list specific items needing attention: _____

Cell 4
p2

1	2	3	Comments
			P2

p2

--	--	--	--

--	--	--	--

4000 mm
Model 68358

Ratio Label unreadable
 Check again soon ☐ can only read first and
 Metal ☐ Contains Sludge ☐ last numbers

Low, check again soon ☐ *can only read first and last number*
Contains Metal ☐ Contains Sludge ☐

Contains Metal ☐ Contains Sludge ☒ *last number*

Oil is sent out for scheduled oil testing

X	after inspection was complete, verified correct oil level
X	in gear box to correct level on site glass and topped
X	up all gearboxes to FULL mark on site glass

X	in gear box to correct level on site glass and topped
X	up all gearboxes to FULL mark on site glass

X	up all gearboxes to FULL mark on site glass
---	---

Action Required

X			carbon fiber shaft with flex plate couplings
---	--	--	--

X			carbon fiber shaft with flex plate couplings
---	--	--	--

Fixed Pitch ☐ Adjustable Pitch ☐

Number of Blades _____

--	--	--	--

	X		
--	---	--	--

[illegible]

	x	tap hardware to hub some were loose

loose

[illegible]

		g/box support foundation beam OK
	x	Secured all drain and breather lines in cell tower to stop
	x	them vibrating

	x	Secured all drain and breather lines in cell tower to stop
	y	them vibrating

x	them vibrating
x	did not test switch for trip

x	did not test switch for trip
---	------------------------------

[illegible]

RPM _____ Phase _____ Hz _____ Volts _____

_____ S F _____ Special Info. _____

Yes ☐ Action Required _____

Yes ☐ Action Required _____

Yes ☐ Action Required _____

Yes ☐ Action Required _____

--	--	--	--

--	--	--	--



Cooling Tower Inspection Checklist

SM-CKLIST

Cell 3 p1

Tower Location Metcalf
Owner/Company Calpine
Company Contact _____
Signature _____

Date Inspected May 13th through 25th
Inspected by Pat Mannion
Inspector _____
Signature _____

Owner's Tower Designation _____

Tower Manufacturer _____
Process Served by Tower _____
Design Conditions: GPM _____ HW _____ ° F
Cell No. _____ Number of Fan Cells 10
Date Tower was installed _____

Model No. _____ Serial No. _____
Operation: Continuous ☐ Intermittent ☐ Seasonal ☐
° F CW _____ ° F WB _____ ° F
Tower Type: Crossflow ☐ Counterflow ☐

Condition: 1-Good 2-Keep an eye on it 3-Needs immediate attention

Structure

Casing Material _____
Structural Material _____
Fan Deck Material _____
Stairway ☐ Material _____
Ladder ☐ Material _____
Handrail ☐ Material _____
Interior Walkway ☐ Material _____
Cold Water Basin Material _____
Silt, Debris Buildup _____

1	2	3	Comments
x			Concrete basin fiberglass siding and stairs
x			Fiberglass
x			Fiberglass
x			Fiberglass
x			Fiberglass
x			Fiberglass
			no interior walkway
x			Concrete
x			No excess silt or debris

Water Distribution System

Open Basin System

Distribution Basin Material _____
Inlet Pipe Material _____
Inlet Manifold Material _____
Flow Control Valves _____ Size _____
Nozzles—Orifice Diameter _____ Size _____
Silt, Algae, Debris _____

	x		PVC
	x		PVC
	x		PVC
	x		PVC
	x		Replaced and or repaired many nozzles in all cells
	x		Plant was down for prolonged Outage. H2O to be chemically treated when back in service

Spray Type System

Header Pipe Material _____
Branch Pipe Material _____
Nozzles—Orifice Diameter _____ Size _____
Up spray ☐ Down spray ☐

	x		fiberglass
	x		
	x		

Heat Transfer System

Fill—Type & Material _____
Eliminators—Type & Material fiberglass
Louvers—Type & Material _____
Biological Fouling _____

	x		Fill is getting brittle, see attached pics of damage
	x		
		x	Air operated plumb abatement louvers do not work
	x		somewhat normal build up on heat transfer coils

Use this space to list specific items needing attention: _____

Cell 3
P2

1	2	3	Comments
---	---	---	----------

Belt Drive Unit

Manufacturer SPX Model 2150120 Ratio 13.81:1 Serial # 54000
Oil Level: Full ☒ Add Immediately ☐ Low, check again soon ☐ 574

Oil Type Used Oil is sent out for scheduled oil testing

No Leaks!

Action Required

Manufacturer _____ Material _____

X		carbon fiber shaft with flex plate couplings
---	--	--

Fan Type: Propeller ☒ Blower ☐

Fixed Pitch ☐ Adjustable Pitch ☐

Number of Blades

[illegible]

Fan Cylinder Height

Mechanical Equipment Support

Oil Fill and Drain Line

Oil Level Sight Glass

Vibration Limit Switch

Manufacturer

Name Plate Data: HP _____ RPM _____ Phase _____ Hz _____ Volts _____
F L Amps _____ Frame _____ S F _____ Special Info. _____

Last Lubrication—Date _____

Grease Used—Type

Unusual Noises?	No <input type="checkbox"/>	Yes <input type="checkbox"/>	Action Required

Unusual Vibration?	No <input type="checkbox"/>	Yes <input type="checkbox"/>	Action Required

Unusual Heat Build-up?	No <input type="checkbox"/>	Yes <input type="checkbox"/>	Action Required

Make-up Valve

Other Component

Other Component



Cooling Tower Inspection Checklist

SM-CKLIST

Cell 2 p 1

Tower Location Metcalf Date Inspected May 13th through 25th
Owner/Company Calpine Inspected by Pat Mannion
Company Contact _____ Inspector _____
Signature _____ Signature _____
Owner's Tower Designation _____
Tower Manufacturer _____ Model No. _____ Serial No. _____
Process Served by Tower _____ Operation: Continuous ☐ Intermittent ☐ Seasonal ☐
Design Conditions: GPM _____ HW _____ ° F CW _____ ° F WB _____ ° F
Cell No. _____ Number of Fan Cells 10 Tower Type: Crossflow ☐ Counterflow ☐
Date Tower was installed _____

Condition: 1-Good 2-Keep an eye on it 3-Needs immediate attention

Structure

Casing Material _____
Structural Material _____
Fan Deck Material _____
Stairway ☐ Material _____
Ladder ☐ Material _____
Handrail ☐ Material _____
Interior Walkway ☐ Material _____
Cold Water Basin Material _____
Silt, Debris Buildup _____

1	2	3	Comments
x			Concrete basin fiberglass siding and stairs
x			Fiberglass
x			Fiberglass
x			Fiberglass
x			Fiberglass
x			Fiberglass
			no interior walkway
x			Concrete
x			No excess silt or debris

Water Distribution System

Open Basin System

Distribution Basin Material _____
Inlet Pipe Material _____
Inlet Manifold Material _____
Flow Control Valves _____ Size _____
Nozzles—Orifice Diameter _____ Size _____
Silt, Algae, Debris _____

	x		PVC
	x		PVC
	x		PVC
	x		PVC
	x		Replaced and or repaired many nozzles in all cells
	x		Plant was down for prolonged Outage, H2O to be chemically treated when back in service

Spray Type System

Header Pipe Material fiberglass
Branch Pipe Material _____
Nozzles—Orifice Diameter _____ Size _____
Up spray ☐ Down spray ☐

	x		
	x		
	x		

Heat Transfer System

Fill—Type & Material _____
Eliminators—Type & Material _____
Louvers—Type & Material _____
Biological Fouling _____

	x		Fill is getting brittle, see attached pics of damage
	x		
	x		Air operated plumb abatement louvers do not work
	x		somewhat normal build up on heat transfer coils

Use this space to list specific items needing attention: _____

Cell 2
p2

1	2	3	Comments
---	---	---	----------

Belt Drive Unit

--	--	--	--

--	--	--	--

--	--	--	--

Manufacturer Marley Overmolds Model M36 Ratio 15:84:1 Serial #

Oil Type Used, _____ Oil is sent out for scheduled oil testing

			after inspection was complete, verified correct oil level
	X		in gear box to correct level on site glass and topped
	X		up all gearboxes to FULL mark on site glass

x	in gear box to correct level on site glass and topp
---	---

	X	up all gearboxes to FULL mark on site glass
--	---	---

Action Required

Manufacturer	Material
--------------	----------

X			carbon fiber shaft with flex plate couplings
---	--	--	--

Fan Type: Propeller ☐ Blower ☐

Fixed Pitch ☐ Adjustable Pitch ☐

Number of Blades

--	--	--	--	--

	X		
--	---	--	--

	X		
--	---	--	--

	X		
--	---	--	--

--	--	--	--	--

--	--	--	--

--	--	--	--

			g/box support foundation beam OK
--	--	--	----------------------------------

	x	Secured all drain and breather lines in cell tower to stop
	y	them vibrating

x		did not test switch for trip
---	--	------------------------------

x	did not test switch for trip
---	------------------------------

Manufacturer

F L Amps	Frame	S F	Special Info.
----------	-------	-----	---------------

Grease Used—Type

Unusual Vibration?	No <input type="checkbox"/>	Yes <input type="checkbox"/>	Action Required

Unusual Heat Build-up?	No <input type="checkbox"/>	Yes <input type="checkbox"/>	Action Required

Make-up Valve

Other Component

Other Component

Appendix 9

Metcalf Energy Center

Annual Compliance Report 2024

Water Usage Summary

Recycled Water	
month	consumption (gal)
January	70,177,360
February	61,704,016
March	42,917,248
April	37,400
May	506,396
June	38,367,912
July	79,867,700
August	70,572,304
September	42,647,220
October	58,968,580
November	37,534,640
December	51,769,828
Total	555,070,604

Potable Water	
month	consumption (gal)
January	9,765,477
February	9,277,332
March	15,715,480
April	583,537
May	967,388
June	11,048,805
July	9,030,507
August	8,881,909
September	8,520,393
October	9,916,872
November	6,353,699
December	7,468,234
Total	97,529,633

Metcalf Energy Center

Annual Compliance Report 2024

Water Usage Summary

Condition of Certification S&W-1

Recycled Water

Cooling Tower for Steam Cycle Cooling	555,070,604
Total Gallons 2024	555,070,604

Potable Water

Condenser Make-Up	35,356,511
Steam Attemperation	33,440,064
Inlet Air Cooling	9,070,408
Domestic	752,118
RO Reject	14,969,798
Filter Backwash	2,993,960
CT Wash Water	482,475
Plant Wash Down	689,249
Total Gallons 2024	97,529,633

Appendix 10

METCALF ENERGY CENTER, LLC

TRANS-3 HAZARDOUS MATERIAL DELIVERIES

JANUARY				
VENDOR NAME	CHEMICAL	RECEIVED	QUANTITY	UOM
CHEMTREAT	RL9007	1/25/2024	539	LBS
CHEMTREAT	BL1794	1/25/2024	497	LBS
CHEMTREAT	BL8401	1/25/2024	957	LBS
CHEMTREAT	CL4500	1/19/2024	2,228	LBS
CHEMTREAT	BL8401	1/29/2024	916	LBS
CHEMTREAT	BL1794	1/29/2024	477	LBS
CHEMTREAT	RL9007	1/29/2024	519	LBS
CHEMTREAT	BL8401	1/29/2024	458	LBS
CHEMTREAT	CL243	1/29/2024	4,400	LBS
HILL BROTHERS	AQUEOUS AMMONIA	1/24/2024	6,701	LBS
HILL BROTHERS	AQUEOUS AMMONIA	1/22/2024	5,901	GAL
HILL BROTHERS	AQUEOUS AMMONIA	1/17/2024	6,704	GAL
HILL BROTHERS	AQUEOUS AMMONIA	1/30/2024	6,000	GAL
HILL BROTHERS	AQUEOUS AMMONIA	1/12/2024	6,009	GAL
HILL BROTHERS	AQUEOUS AMMONIA	1/9/2024	6,700	GAL
HILL BROTHERS	AQUEOUS AMMONIA	1/4/2024	6,700	GAL
NORTHSTAR CHEMICAL	SULFURIC ACID	1/17/2024	3,268	GAL
UNIVAR SOLUTIONS	SODIUM HYPOCHLORITE	1/21/2024	45,025	LBS
UNIVAR SOLUTIONS	SODIUM HYPOCHLORITE	1/4/2024	44,991	LBS

FEBRUARY				
VENDOR NAME	CHEMICAL	RECEIVED	QUANTITY	UOM
CHEMTREAT	RL1245	2/19/2024	511	LBS
CHEMTREAT	BL152	2/13/2024	1,990	LBS
CHEMTREAT	CL4500	2/8/2024	10,130	LBS
CHEMTREAT	RL1245	2/8/2024	531	LBS
CHEMTREAT	BL152	2/13/2024	1,592	LBS
CHEMTREAT	BL1794	2/13/2024	477	LBS
CHEMTREAT	BL8401	2/13/2024	458	LBS
HILL BROTHERS	AQUEOUS AMMONIA	2/7/2024	6,701	GAL
HILL BROTHERS	AQUEOUS AMMONIA	2/9/2024	3,902	GAL
HILL BROTHERS	AQUEOUS AMMONIA	2/23/2024	6,703	GAL
HILL BROTHERS	AQUEOUS AMMONIA	2/16/2024	6,701	GAL
HILL BROTHERS	AQUEOUS AMMONIA	2/14/2024	6,702	GAL
HILL BROTHERS	AQUEOUS AMMONIA	2/28/2024	6,701	GAL
HILL BROTHERS	AQUEOUS AMMONIA	2/2/2024	6,001	GAL
NORTHSTAR CHEMICAL	SULFURIC ACID	2/2/2024	3,268	GAL
NORTHSTAR CHEMICAL	SULFURIC ACID	2/13/2024	3,268	GAL
NORTHSTAR CHEMICAL	SULFURIC ACID	2/23/2024	3,268	GAL
UNIVAR SOLUTIONS	SODIUM HYPOCHLORITE	2/17/2024	45,003	LBS
UNIVAR SOLUTIONS	SODIUM HYPOCHLORITE	2/6/2024	45,042	LBS

MARCH				
VENDOR NAME	CHEMICAL	RECEIVED	QUANTITY	UOM
CHEMTREAT	BL8401	3/7/2024	478	LBS
CHEMTREAT	RL9007	3/21/2024	539	LBS
CHEMTREAT	RL1245	3/21/2024	531	LBS
CHEMTREAT	BL152	3/21/2024	418	LBS
CHEMTREAT	BL1794	3/21/2024	497	LBS
HILL BROTHERS	AQUEOUS AMMONIA	3/5/2024	6,700	GAL
HILL BROTHERS	AQUEOUS AMMONIA	3/28/2024	2,302	GAL
HILL BROTHERS	AQUEOUS AMMONIA	3/25/2024	3,502	GAL
HILL BROTHERS	AQUEOUS AMMONIA	3/18/2024	6,704	GAL
HILL BROTHERS	AQUEOUS AMMONIA	3/8/2024	5,905	GAL
HILL BROTHERS	AQUEOUS AMMONIA	3/18/2024	3,705	GAL
NORTHSTAR CHEMICAL	SULFURIC ACID	3/13/2024	3,268	GAL
UNIVAR SOLUTIONS	SODIUM HYPOCHLORITE	3/8/2024	45,057	LBS

APRIL				
VENDOR NAME	CHEMICAL	RECEIVED	QUANTITY	UOM

NO DELIVERIES

MAY				
VENDOR NAME	CHEMICAL	RECEIVED	QUANTITY	UOM
CHEMTREAT	RL1245	5/16/2024	1,063	LBS
CHEMTREAT	BL152	5/16/2024	1,672	LBS
CHEMTREAT	BL8401	5/30/2024	957	LBS
CHEMTREAT	CL243	5/30/2024	2,326	LBS
HILL BROTHERS	AQUEOUS AMMONIA	5/25/2024	3,705	GAL

JUNE				
VENDOR NAME	CHEMICAL	RECEIVED	QUANTITY	UOM
HILL BROTHERS	AQUEOUS AMMONIA	6/27/2024	6,702	GAL
HILL BROTHERS	AQUEOUS AMMONIA	6/21/2024	6,703	GAL
HILL BROTHERS	AQUEOUS AMMONIA	6/13/2024	5,201	GAL
HILL BROTHERS	AQUEOUS AMMONIA	6/4/2024	5,802	GAL
NORTHSTAR CHEMICAL	SULFURIC ACID	6/6/2024	3,137	GAL
UNIVAR SOLUTIONS	SODIUM HYPOCHLORITE	6/5/2024	45,095	LBS
UNIVAR SOLUTIONS	SODIUM HYPOCHLORITE	6/28/2024	45,035	LBS

JULY				
VENDOR NAME	CHEMICAL	RECEIVED	QUANTITY	UOM
CHEMTREAT	CL4500	7/5/2024	12,663	LBS
CHEMTREAT	BL152	7/10/2025	1,672	LBS
HILL BROTHERS	AQUEOUS AMMONIA	7/24/2024	6,701	GAL
HILL BROTHERS	AQUEOUS AMMONIA	7/30/2024	6,001	GAL
HILL BROTHERS	AQUEOUS AMMONIA	7/12/2024	6,701	GAL
HILL BROTHERS	AQUEOUS AMMONIA	7/19/2024	6,701	GAL
HILL BROTHERS	AQUEOUS AMMONIA	7/2/2024	4,001	GAL
HILL BROTHERS	AQUEOUS AMMONIA	7/5/2024	6,704	GAL
NORTHSTAR CHEMICAL	SULFURIC ACID	7/31/2024	3,194	GAL
NORTHSTAR CHEMICAL	SULFURIC ACID	7/1/2024	3,268	GAL
NORTHSTAR CHEMICAL	SULFURIC ACID	7/15/2024	3,268	GAL
UNIVAR SOLUTIONS	SODIUM HYPOCHLORITE	7/10/2024	44,566	LBS
UNIVAR SOLUTIONS	SODIUM HYPOCHLORITE	7/22/2024	44,376	LBS

AUGUST				
VENDOR NAME	CHEMICAL	RECEIVED	QUANTITY	UOM
CHEMTREAT	BL1794	8/22/2024	995	LBS
HILL BROTHERS	AQUEOUS AMMONIA	8/2/2024	6,701	GAL
HILL BROTHERS	AQUEOUS AMMONIA	8/30/2024	6,701	GAL
HILL BROTHERS	AQUEOUS AMMONIA	8/16/2024	6,700	GAL
HILL BROTHERS	AQUEOUS AMMONIA	8/22/2024	6,701	GAL
HILL BROTHERS	AQUEOUS AMMONIA	8/9/2024	6,701	GAL
NORTHSTAR CHEMICAL	SULFURIC ACID	8/14/2024	3,268	GAL
UNIVAR SOLUTIONS	SODIUM HYPOCHLORITE	8/2/2024	44,526	LBS
UNIVAR SOLUTIONS	SODIUM HYPOCHLORITE	8/12/2024	44,802	LBS
UNIVAR SOLUTIONS	SODIUM HYPOCHLORITE	8/26/2024	44,984	LBS

SEPTEMBER				
VENDOR NAME	CHEMICAL	RECEIVED	QUANTITY	UOM
CHEMTREAT	CL243	9/19/2024	6,977	LBS
CHEMTREAT	BL152	9/5/2024	1,592	LBS
HILL BROTHERS	AQUEOUS AMMONIA	9/27/2024	6,700	GAL
HILL BROTHERS	AQUEOUS AMMONIA	9/10/2024	6,700	GAL
HILL BROTHERS	AQUEOUS AMMONIA	9/5/2024	6,500	GAL
NORTHSTAR CHEMICAL	SULFURIC ACID	9/4/2024	3,268	GAL
UNIVAR SOLUTIONS	SODIUM HYPOCHLORITE	9/10/2024	47,859	LBS

OCTOBER				
VENDOR NAME	CHEMICAL	RECEIVED	QUANTITY	UOM
CHEMTREAT	RL9007	10/3/2024	1,618	LBS
CHEMTREAT	RL9007	10/3/2024	1,618	LBS
HILL BROTHERS	AQUEOUS AMMONIA	10/31/2024	6,701	GAL
HILL BROTHERS	AQUEOUS AMMONIA	10/11/2024	6,700	GAL
HILL BROTHERS	AQUEOUS AMMONIA	10/8/2024	6,702	GAL
HILL BROTHERS	AQUEOUS AMMONIA	10/2/2024	6,701	GAL
HILL BROTHERS	AQUEOUS AMMONIA	10/24/2024	6,702	GAL
NORTHSTAR CHEMICAL	SULFURIC ACID	10/3/2024	3,268	GAL
NORTHSTAR CHEMICAL	SULFURIC ACID	10/22/2024	3,268	GAL
UNIVAR SOLUTIONS	SODIUM HYPOCHLORITE	10/14/2024	45,021	LBS
UNIVAR SOLUTIONS	SODIUM HYPOCHLORITE	10/3/2024	45,012	LBS

NOVEMBER				
VENDOR NAME	CHEMICAL	RECEIVED	QUANTITY	UOM
CHEMTREAT	BL1794	11/7/2024	1,908	LBS
CHEMTREAT	BL152	11/4/2024	1,672	LBS
HILL BROTHERS	AQUEOUS AMMONIA	11/6/2024	6,701	GAL
HILL BROTHERS	AQUEOUS AMMONIA	11/11/2024	6,701	GAL
HILL BROTHERS	AQUEOUS AMMONIA	11/15/2024	6,705	GAL
NORTHSTAR CHEMICAL	SULFURIC ACID	11/14/2024	3,268	GAL
UNIVAR SOLUTIONS	SODIUM HYPOCHLORITE	11/1/2024	45,083	LBS

DECEMBER				
VENDOR NAME	CHEMICAL	RECEIVED	QUANTITY	UOM
CHEMTREAT	BL1794	12/6/2024	1,908	LBS
CHEMTREAT	BL152	12/6/2024	1,674	LBS
HILL BROTHERS	AQUEOUS AMMONIA	12/6/2024	6,700	GAL
HILL BROTHERS	AQUEOUS AMMONIA	12/18/2024	6,700	GAL
HILL BROTHERS	AQUEOUS AMMONIA	12/3/2024	6,701	GAL
HILL BROTHERS	AQUEOUS AMMONIA	12/13/2024	6,701	GAL
HILL BROTHERS	AQUEOUS AMMONIA	12/23/2024	5,001	GAL
NORTHSTAR CHEMICAL	SULFURIC ACID	12/12/2024	3,268	GAL
NORTHSTAR CHEMICAL	SULFURIC ACID	12/30/2024	3,500	GAL
UNIVAR SOLUTIONS	SODIUM HYPOCHLORITE	12/18/2024	44,951	LBS
UNIVAR SOLUTIONS	SODIUM HYPOCHLORITE	12/4/2024	46,173	LBS

Appendix 11



Work Order Details

32852802: MF-1Y ARCHITECTURAL TREATMENT INSPECTION FOR THE CEC

Asset: 10348123

Location: MF-01

Job Plan: 27731

METCALF ENERGY CENTER SYSTEMS POWER BLOCK 1

MF POWER BLOCK 1

MF-1Y ARCHITECTURAL TREATMENT INSPECTION FOR THE CEC

Sched Start:	Aug 5, 2024 10:02 AM	Site:	MF	Supervisor:	OPS MGR
Sched Finish:		Priority:	3	Lead:	MF-OPS
Target Start:	Aug 10, 2024 12:00 AM	Work Type:	PM	Work Group:	
Target Finish:	Aug 10, 2024 2:00 AM	Status:	COMP	Owner:	
Actual Start:	Aug 7, 2024 4:33 PM	Parent:		Owner Group:	
Actual Finish:	Aug 7, 2024 4:34 PM	Failure Class:	BG	Service:	
Report Date:	Jul 15, 2024 5:30 AM	Problem Code:		Service Group:	
Reported By:	MAXADMIN	Vendor:		Classification:	
On Behalf Of:		GL Account:	50300~623000~2070100~2901~S10030~OM000000	PM:	107859

Task IDs

Task ID	Description	Status	Measurement Point	Value	Date	Observations
10	PRINT OUT INSPECTION CHECKLIST AND DEFINITIONS	COMP		0		
20	PERFORM INSPECTION OF SITE AREAS LISTED IN THE CHECKLIST	COMP		0		
30	THE CEC IS ONLY CONCERNED WITH PORTIONS OF THE PLANT VISIBLE TO THE PUBLIC.	COMP		0		
40		COMP		0		
50	GIVE COMPLETED CHECKLIST TO THE OPERATIONS MANAGER	COMP		0		
60	OPS MANAGER TO INFORM EHS SPECIALIST THAT ANNUAL INSPECTION IS DONE AND CAN BE INCLUDED WITH THE ANNUAL CEC REPORT.	COMP		0		
70	IF NECESSARY CREATE ANY CORRECTIVE WORK ORDERS.	COMP		0		
80	UPDATE MAXIMO AND FILE THE INSPECTION CHECKLIST.	COMP		0		

Log

Date	Class	Created By	Subject	Description	Long Description
8/7/24	WORKORDER	SH13667		Performed architectural inspection	Architectural condition consistent with age of plant.<!-- RICH TEXT -->

California Energy Commission's Condition of Certification

VISUAL RESOURCES-1

METCALF ENERGY CENTER, LLC
STATUS REPORT REGARDING THE ARCHITECTURAL
DESIGN TREATMENT MAINTENANCE

California Energy Commission Condition of Certification Visual Resources – 1 requires the Metcalf Energy Center to submit in its Annual Compliance Report a status report regarding the treatment maintenance of the project structures. The project structures, which are visible to the public, have been painted with CPM-approved and City of San Jose-approved non-reflective colors with a low-gloss finish.

The Metcalf Energy Center Maintenance Department has procedures to address all aspects for maintaining the power plant efficiently. Issues such as coating or painting are captured by staff's surveillance and utilization of checklists. Once an item is deemed in need of maintenance, Plant Management schedule and prioritizes the maintenance through a work order process. Outside contractors are also utilized at Metcalf Energy Center. Plant Management inspects and signs off on the work once it is fully complete.

A copy of the checklists used to survey the architectural screen as well as the other painted surfaces visible from offsite is attached to this summary.

ARCHITECTURAL DESIGN TREATMENT INSPECTION METCALF ENERGY CENTER

UNIT: Steam Turbine

	TURBINE / GENERATOR ENCLOSURE	GENERATOR / CONDENSER SOUND WALL
Chalking	2	2
Erosion	1	1
Discoloration	3	3 2
Fading	3	3
Loss of Gloss	3	3
Mildew Defacement	1	1
Moisture Blushing	1	1
Orange Peel	1	1
Wrinkling	1	1
Chemical Attack	1	1
High Temperature Attack	3 2	1
Mottling	1	1
Crackling	1	1
Saponification	1	1
Disbanding (peel/blister)	1	1
Crawling (fish eye)	1	1

Comments:

Rating System: Mark a number from 1 through 5 in the appropriate box to indicate the condition of the coating:
1 = No Problems; 2 = Minor Problems; 3 = Average Problems; 4 = Increased Problems; 5 = Major Problems.

ARCHITECTURAL DESIGN TREATMENT INSPECTION METCALF ENERGY CENTER

UNIT: Cooling Tower

	SUPERSTRUCTURE
Chalking	3
Erosion/Corrosion	2
Discoloration	3
Fading	3
Loss of Gloss	3
Mildew Defacement	1
Moisture Blushing	3
Orange Peel	1
Wrinkling	1
Chemical Attack	1
High Temperature Attack	1
Mottling	1
Crackling	1
Saponification	1
Disbanding (peel/blister)	1
Crawling (fish eye)	1

Comments:

Rating System: Mark a number from 1 through 5 in the appropriate box to indicate the condition of the coating:
1 = No Problems; 2 = Minor Problems; 3 =Average Problems; 4 = Increased Problems; 5 = Major Problems.

ARCHITECTURAL DESIGN TREATMENT INSPECTION METCALF ENERGY CENTER

UNIT: HRSG & Gas Turbine 1

	INLET AIR FILTER HOUSE	TURBINE/ GENERATOR	STACK	SCREENING
Chalking	3	2	3	3
Erosion/Corrosion	1	2	1	1
Discoloration	2	2	2	2
FadinQ	3	3	3	3
Loss of Gloss	3	3	3	3
Mildew Defacement	1	1	1	1
Moisture Blushing	1	1	1	1
Orange Peel	1	1	1	1
Wrinkling	1	1	1	1
Chemical Attack	1	1	1	1
High Temperature Attack	1	2	1	1
Mottling	1	1	1	1
Crackling	1	1	1	1
Saponification	1	1	1	1
Disbanding (peel/blister)	1	1	1	1
Crawling (fish eye)	1	1	1	1

Comments:

Rating System: Mark a number from 1 through 5 in the appropriate box to indicate the condition of the coating:
1 = No Problems; 2 = Minor Problems; 3 = Average Problems; 4 = Increased Problems; 5 = Major Problems.

ARCHITECTURAL DESIGN TREATMENT INSPECTION METCALF ENERGY CENTER

UNIT: HRSG & Gas Turbine 2

	INLET AIR FILTER HOUSE	TURBINE/ GENERATOR	STACK	SCREENING
Chalking	2	2	3	3
Erosion/Corrosion	1	2	1	1
Discoloration	2	2	2	2
Fading	3	3	3	3
Loss of Gloss	3	3	3	3
Mildew Defacement	1	1	1	1
Moisture Blushing	1	1	1	1
Orange Peel	1	1	1	1
Wrinkling	1	1	1	1
Chemical Attack	1	1	1	1
High Temperature Attack	1	3	1	1
Mottling	1	1	1	1
Crackling	1	1	1	1
Saponification	1	1	1	1
Disbanding (peel/blister)	1	1	1	1
Crawling (fish eye)	1	1	1	1

Comments:

Rating System: Mark a number from 1 through 5 in the appropriate box to indicate the condition of the coating:

1 = No Problems; 2 = Minor Problems; 3 = Average Problems; 4 = Increased Problems; 5 = Major Problems.

ARCHITECTURAL DESIGN TREATMENT INSPECTION METCALF ENERGY CENTER

UNIT: Water Tanks

	SERVICE/FIRE WATER	DEMINERALIZED WATER
Chalking	3	3
Erosion/Corrosion	1	1
Discoloration	2	2
Fading	3	3
Loss of Gloss	3	3
Mildew Defacement	1	1
Moisture Blushing	1	1
Orange Peel	1	1
Wrinkling	1	1
Chemical Attack	1	1
High Temperature Attack	1	1
Mottling	1	1
Crackling	2	2
Saponification	1	1
Disbanding (peel/blister)	1	1
Crawling (fish eye)	1	1

Comments:

Rating System: Mark a number from 1 through 5 in the appropriate box to indicate the condition of the coating:

1 = No Problems; 2 = Minor Problems; 3 = Average Problems; 4 = Increased Problems; 5 = Major Problems.

ARCHITECTURAL DESIGN TREATMENT INSPECTION METCALF ENERGY CENTER

UNIT: Buildings

	ADMINISTRATION	WAREHOUSE
Chalking	3	3
Erosion/Corrosion	2	2
Discoloration	3	3
Fading	3	3
Loss of Gloss	3	3
Mildew Defacement	1	1
Moisture Blushing	1	1
Orange Peel	1	1
Wrinkling	1	1
Chemical Attack	1	1
High Temperature Attack	1	1
Mottling	1	1
Crackling	1	1
Saponification	1	1
Disbanding (peel/blister)	1	1
Crawling (fish eye)	1	1

Comments:

Rating System: Mark a number from 1 through 5 in the appropriate box to indicate the condition of the coating:

1 = No Problems; 2 = Minor Problems; 3 = Average Problems; 4 = Increased Problems; 5 = Major Problems.

Appendix 12

Metcalf Energy Center Plume Log - Year to Date									
Cooling Tower Plumes									
Date	Start Time	End time	Total Time		Event	Relative Humidity	Temperature	Supplemental Firing (On/Off)	Plume Abatement In Service (Louvers Open)
No Plume Events in January 2024									
No Plume Events in February 2024									
No Plume Events in March 2024									
No Plume Events in April 2024									
No Plume Events in May 2024									
No Plume Events in June 2024									
No Plume Events in July 2024									
No Plume Events in August 2024									
No Plume Events in September 2024									
No Plume Events in October 2024									
November 15, 2024	7:55	8:55	1 hr.		Plume	86%	45	Off	Yes
December 3, 2024	7:05	7:35	30 mins		Plume	85%	41	On	Yes
December 4, 2024	8:03	8:28	25 mins		Plume	89%	45	Off	Yes
December 5, 2024	7:07	7:37	30 mins		Plume	85%	45	On	Yes
December 6, 2024	7:07	7:38	31 mins		Plume	89%	42	On	Yes
Total Cooling Tower Plume Hours:			2:56						
Remedial Actions To Be Taken									
1. The Operator will verify that the plume abatement was in service.									
2. The Operator will verify that the louvers were completely opened.									
3. Curtail supplementary firing in the HRSG.									
Stack Plumes									
Date	Start Time	End time	Total Time		Event	Relative Humidity	Temperature	Supplemental Firing (On/Off)	Steam Injection (On/Off)
No Plume Events in January 2024									
No Plume Events in February 2024									
No Plume Events in March 2024									
No Plume Events in April 2024									
No Plume Events in May 2024									
No Plume Events in June 2024									
No Plume Events in July 2024									
No Plume Events in August 2024									
No Plume Events in September 2024									
No Plume Events in October 2024									
No Plume Events in November 2024									
No Plume Events in December 2024									
Total Stack Plume Hours:			0:00						
Remedial Actions Taken									
1. The Operator will operate the economizer bypass valve.									
2. Curtail steam injection to the combustion turbine (called PAG steam).									
3. Curtail supplementary firing in the HRSG.									
Total Combined Plume Hours:			2:56						

Appendix 13

METCALF ENERGY CENTER
2024 ANNUAL COMPLIANCE REPORT
WASTE-3

In accordance with **Waste-3**, the Metcalf Energy Facility is required to document actual waste management methods used during the year compared to planned management methods. The facility is currently using the planned waste management methods for all the waste streams generated within the facility, as listed in the table below.

Waste Stream	Type	Planned	Actual
Non-hazardous Solid Waste	Recyclables	Recycle (Off-site)	Recycle (Off-site)
	Non-Recyclables	Landfill	Landfill
Non-hazardous Liquid Waste	Sanitary Waste	Sewage Treatment Plant	Sewage Treatment Plant
	Process Wastewater	Sewage Treatment Plant	Sewage Treatment Plant
Hazardous Liquid Waste	Used Oil	Recycle (Off-site)	Recycle (Off-site)
	Oily Water	Off-site disposal company	Off-site disposal company
	Aqueous Parts Washer	Off-site disposal company	Off-site disposal company
	Flammable Liquid	Off-site disposal company	Off-site disposal company
Hazardous Solid Waste	Used Oil Filters	Recycle (Off-site)	Recycle (Off-site)
	Oily Rags	Off-site disposal company	Off-site disposal company
	Debris from HRSG Cleaning	Off-site disposal company	Off-site disposal company
	Universal Waste	Recycle (Off-site)	Recycle (Off-site)

Appendix 14

April 9, 2024

Director, Enforcement and Compliance Division
Bay Area Air Quality Management District, Suite 600
375 Beale Street
San Francisco, CA 94105-2066
Attn: Jeffrey Gove
compliance@baaqmd.gov

**RE: Metcalf Energy Center, LLC., Permit No. B2183
Major Facility Review Permit (Title V Permit)
30-Day Title V Non-Compliance Report
RCA ID: 200236**

Dear Mr. Gove,

In accordance with the Major Facility Review Permit ("Title V Permit") for Metcalf Energy Center, LLC (the "Facility"), this letter is intended to satisfy the 30-day follow-up reporting requirement as required by Section I.F. of the Title V Permit, which requires the reporting of all non-compliance instances of the Title V Permit in writing within 30 days of discovery of such non-compliance.

The RCA was submitted on March 13, 2024, and the Title V 10-day initial notification was submitted to the District on March 14, 2024.

On March 11, 2024, the facility experienced an indicated excess of the following NO_x emission limits of the Title V permit: 19.2 pounds per hour (Condition 20.a), 0.00904 lbs./MMBtu (Condition 20.a), and 2.5 ppm 1-hour average, corrected to 15% O₂ (Condition 20.b). All evidence indicates that this event was caused by a loose sample tube connected to the O₂ analyzer. The details of the troubleshooting and event are described in the event description section below. The Facility believes that these values do not accurately represent actual stack emissions and that no excess emissions occurred during this event.

Event Description

On March 11, 2024, the Facility experienced issues with the Combustion Turbine 1 (CT-1) O₂ analyzer after it failed a calibration check out of control (OOC). Subsequent to successfully passing a 2nd calibration check, the analyzer recorded 11 minutes of O₂ concentration data that were not representative of combustion gas as shown in Attachment 1. The high O₂ data resulted in high NO_x corrected values that led to the indicated excess emissions.

After recording the high O₂ data the analyzer was put into maintenance for troubleshooting. During troubleshooting, after the analyzer was challenged with calibration gas, it began reporting data typical of combustion gas. The system was returned to service and NO_x data were within normal range.

On March 12, 2024, while the unit was down, Facility staff continued to troubleshoot the O₂ analyzer since the cause of the failed calibration had not been determined. During this process, the analyzer OEM (Thermo) was contacted for guidance, and they advised checking the analyzer for loose connections. Upon inspection, staff found a loose connection on the O₂ sensor. After the loose sample tube was tightened, the O₂ values became stable, and a calibration check was successfully completed. No further issues have been noted.

The following is a chronology of the event:

March 11, 2024

- 13:17-13:41: O₂ analyzer fails calibration check OOC.
- 13:44-13:55: O₂ analyzer passes calibration check.
- 13:56-14:06: O₂ analyzer records data (> 24%) that is non-representative of combustion gas
- 14:07: O₂ analyzer placed into “Maintenance Mode” to troubleshoot cause of the elevated O₂ readings. During troubleshooting, the analyzer began reading O₂ data within normal range after analyzer was challenged with calibration gas.
- 15:12: O₂ analyzer returned to service.

March 12, 2024

- 06:30-14:10: staff continued troubleshooting O₂ analyzer. Contacted Thermo. Tightened sample tube on the O₂ sensor.
- 14:11: CEMS was placed back into “Service”
- 14:12-14:27: Initiated calibration check on the analyzer.

Corrective Actions

The Facility determined that a loose sample tube connected to the O₂ analyzer was the cause of the calibration failure and non-representative O₂ readings. The connection was tightened.

Compliance Status

The Facility was in full compliance with its air permit throughout the duration of this event. The 11 minutes of non-representative data will be invalidated and the database rebuilt upon District approval.

Investigation and Cause Determination

The O₂ concentration in combustion exhaust must be below the ambient O₂ concentration of 21% since oxygen is consumed to support combustion. The standard default O₂ concentration for combustion turbine exhaust is 15%, and the typical Facility exhaust gas O₂ concentration during normal operations is 14%. The O₂ data recorded during the event that led to the indicated NO_x excess emissions was greater than 24%. The Facility has determined that the loose sample tube connected to the analyzer affected the ability of the O₂ analyzer to accurately measure the O₂ concentration data.

Based on the investigation, it has been determined that the analyzer recorded O₂ data that was not representative of actual oxygen concentrations and the Facility did not emit excess emissions.

Preventative Actions

The onsite technicians perform quarterly CEMS analyzer preventive maintenance. The maintenance procedures have been updated to include a step to check all analyzer sample connections for loose fittings and make necessary adjustments. Furthermore, the Facility will utilize high O₂ alarms to alert operations when the analyzers are recording high indicated O₂ concentrations in the future.

Director, Enforcement and Compliance Division

April 9, 2024


Page 3

Certification

As the Responsible Official, I certify that based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate and complete.

If you have any questions or require additional information, please contact Rosemary Silva, EHS Specialist, at 408-361-4954.

Sincerely,

DocuSigned by:

C4DF598531F14B6...

Kevin Karwick

General Manager

Metcalf Energy Center, LLC

Cc:	Erin Phillips	BAAQMD	via email attachment
	Anwar Ali	CEC AQ-34	via email attachment
	EHSWalnutCreek@calpine.com		via email attachment
	CICS Records INC103103		

Attachments

Attachment 1: Hourly Emissions Report_031124

Attachment 1

Metcalf
San Jose, CA
Turbine-1 Hourly Emissions Report
March 11, 2024 - Hour 14

1-Hr Emission Limits		3-Hr Rolling Emission Limits				4-Hr Rolling (Subpart GG) Emission Limit	
NOx ppm @15% O2 - 2.5 *	NOx lb/hr - 19.2 *	CO ppm @15% O2 - 4 *	CO lb/hr - 18.7 *	NOx ppm @15% O2 - 100			
NOx lb/mmBtu - 0.00904 *		CO lb/mmBtu - 0.0088 *	NH3 Slip ppm @15% O2 - 5 *				

Minute	O2%	NOx ppm	NOx ppm @15% O2	NOx lb/mmBtu	NOx lb/hr	CO ppm	CO ppm @15% O2	CO lb/mmBtu	CO lb/hr	NH3 ppm Slip @15% O2	SCR NOx ppm	Process Status
14:00	24.67	2.38	7.39	0.02717	55.48	0.08	0.25	0.0006	1.23	0.00	21.4	Normal
14:01	24.66	2.50	7.76	0.02854	58.08	0.23	0.71	0.0016	3.26	0.00	21.2	Normal
14:02	24.64	2.51	7.79	0.02865	57.91	0.17	0.53	0.0012	2.43	0.00	20.2	Normal
14:03	24.64	2.60	8.07	0.02968	60.28	0.23	0.71	0.0016	3.25	0.00	20.1	Normal
14:04	24.65	2.92	9.07	0.03333	68.14	0.17	0.53	0.0012	2.46	0.00	20.5	Normal
14:05	24.67	3.36	10.43	0.03835	78.86	0.10	0.31	0.0007	1.44	0.00	21.2	Normal
14:06	24.70	3.86	11.99	0.04406	90.60	0.10	0.31	0.0007	1.44	0.00	21.8	Normal
14:07	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:08	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:09	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:10	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:11	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:12	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:13	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:14	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:15	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:16	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:17	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:18	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:19	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:20	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:21	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:22	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:23	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:24	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:25	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:26	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:27	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:28	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:29	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:30	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal

Minute	O2%	NOx ppm	NOx ppm @15% O2	NOx lb/mmBtu	NOx lb/hr	CO ppm	CO ppm @15% O2	CO lb/mmBtu	CO lb/hr	NH3 ppm Slip @15% O2	SCR NOx ppm	Process Status
14:31	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:32	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:33	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:34	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:35	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:36	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:37	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:38	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:39	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:40	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:41	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:42	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:43	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:44	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:45	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:46	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:47	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:48	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:49	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:50	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:51	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:52	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:53	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:54	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:55	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:56	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:57	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:58	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
14:59	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Maint	Normal
Average Total	24.7	2.9	8.9 *	0.03310 *	66.06 *	0.2	0.6	0.0014	2.79	0.0	20.9	Normal
4-Hr RIng			7.2				0.3 *	0.0006 *	1.14 *	1.17 *		
3-Hr RIng												

* - Excluding Startup and Shutdown

Metcalf Energy Center, LLC.

1 Blanchard Road
Coyote, CA 95013

May 9, 2024

Director, Enforcement and Compliance Division
Bay Area Air Quality Management District
375 Beale Street, Suite 600
San Francisco, CA 94105
compliance@baaqmd.gov

**RE: Metcalf Energy Center, Permit No. B2183
Major Facility Review Permit (Title V Permit)
10-Day Title V Non-Compliance Report
30-Day Title V Follow-Up Report**

To Whom It May Concern:

In accordance with the Major Facility Review Permit (Title V Permit) for the Metcalf Energy Center (the "Facility"), this letter is to advise you of an instance of potential non-compliance as required by Section I. F. of the Title V Permit, which requires the reporting of all non-compliance instances of the Title V Permit in writing within 10 days. It is also intended to satisfy the 30-day follow-up reporting requirement as required by Section I.F. of the Title V Permit.

On May 1, 2024, during a routine review of the cooling tower TDS data, it was discovered that the samples collected during April 25th to April 30th, 2024, showed negative values, due to a lack of water in the sampling system. During that period, the facility, including the cooling tower, did not operate and remains in a maintenance outage.

We are providing this notification as courtesy to explain readings during this period.

If you have any questions or require additional information, please contact Rosemary Silva, EHS Project Manager III, at 408-361-4954 or silvaro@calpine.com.

Sincerely,

DocuSigned by:

C4DF598531F14B6...

Kevin Karwick
Designated Representative and General Manager
Metcalf Energy Center, LLC

CC:	Region IX, EPA	via email attachment
	Anwar Ali, CEC AQ-34	via email attachment
	EHSWalnutCreek@calpine.com	via email attachment
	CICS INC103164	