

DOCKETED	
Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	266729
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q3 2025 - Part 2s
Description:	N/A
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public Agency
Submission Date:	10/21/2025 3:34:28 PM
Docketed Date:	10/21/2025

AQ-33

AQ-33 The Project owner shall maintain records of Sox lb/hr, lb/day, and lb, quarter emissions. Sox emissions shall be based on fuel use records, natural gas sulfur content, and mass balance calculations.

Verification: The Project owner shall submit to the CPM all hourly, daily, and quarterly Sox emissions as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

Tons 12 Month Rolling Summary

CT1 and CT2 Combined



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:05 Location: Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2	
	CO, Ton		NOx, Ton		PM10, Ton		SO2, Ton		VOC, Ton	
	1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)	
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Jul 2025	0.4934	5.2959	1.3940	12.2696	0.3331	2.8103	0.1665	1.4052	0.5558	4.6841
Aug 2025	0.6675	5.4425	1.8924	12.7838	0.4089	2.8727	0.2062	1.4389	0.6865	4.7941
Sep 2025	0.7718	5.7686	2.0691	13.3092	0.4625	2.9817	0.2315	1.4930	0.7721	4.9774
Sum/Avg	5.7686		13.3092		2.9817		1.4930		4.9774	
Limit Value										

AQ33 DAILY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/01/2025 00:00	5.8	6.3
Average/Sum#:	5.8 #	6.3 #
Minimum:	5.8	6.3
Maximum:	5.8	6.3
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/02/2025 00:00	4.9	5.0
Average/Sum#:	4.9 #	5.0 #
Minimum:	4.9	5.0
Maximum:	4.9	5.0
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/03/2025 00:00	4.8	4.8
Average/Sum#:	4.8 #	4.8 #
Minimum:	4.8	4.8
Maximum:	4.8	4.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/04/2025 00:00	4.8	4.9

AQ33 DAILY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	4.8 #	4.9 #
Minimum:	4.8	4.9
Maximum:	4.8	4.9
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/05/2025 00:00	4.8	4.8

Average/Sum#:	4.8 #	4.8 #
Minimum:	4.8	4.8
Maximum:	4.8	4.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/06/2025 00:00	5.2	5.2

Average/Sum#:	5.2 #	5.2 #
Minimum:	5.2	5.2
Maximum:	5.2	5.2
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/07/2025 00:00	5.2	5.4

Average/Sum#:	5.2 #	5.4 #
Minimum:	5.2	5.4
Maximum:	5.2	5.4
%SI	0.00	0.00

AQ33 DAILY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/08/2025 00:00	5.1	5.3
Average/Sum#:	5.1 #	5.3 #
Minimum:	5.1	5.3
Maximum:	5.1	5.3
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/09/2025 00:00	4.9	5.2
Average/Sum#:	4.9 #	5.2 #
Minimum:	4.9	5.2
Maximum:	4.9	5.2
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/10/2025 00:00	5.3	5.5
Average/Sum#:	5.3 #	5.5 #
Minimum:	5.3	5.5
Maximum:	5.3	5.5
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/11/2025 00:00	6.1	6.6

AQ33 DAILY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	6.1 #	6.6 #
Minimum:	6.1	6.6
Maximum:	6.1	6.6
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/12/2025 00:00	5.0	5.2

Average/Sum#:	5.0 #	5.2 #
Minimum:	5.0	5.2
Maximum:	5.0	5.2
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/13/2025 00:00	5.8	4.7

Average/Sum#:	5.8 #	4.7 #
Minimum:	5.8	4.7
Maximum:	5.8	4.7
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/14/2025 00:00	4.8	4.5

Average/Sum#:	4.8 #	4.5 #
Minimum:	4.8	4.5
Maximum:	4.8	4.5
%SI	0.00	0.00

AQ33 DAILY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/15/2025 00:00	4.8	4.8
Average/Sum#:	4.8 #	4.8 #
Minimum:	4.8	4.8
Maximum:	4.8	4.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/16/2025 00:00	4.8	5.0
Average/Sum#:	4.8 #	5.0 #
Minimum:	4.8	5.0
Maximum:	4.8	5.0
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/17/2025 00:00	5.0	5.1
Average/Sum#:	5.0 #	5.1 #
Minimum:	5.0	5.1
Maximum:	5.0	5.1
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/18/2025 00:00	4.8	4.9

AQ33 DAILY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	4.8 #	4.9 #
Minimum:	4.8	4.9
Maximum:	4.8	4.9
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/19/2025 00:00	4.8	4.8

Average/Sum#:	4.8 #	4.8 #
Minimum:	4.8	4.8
Maximum:	4.8	4.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/20/2025 00:00	4.8	4.8

Average/Sum#:	4.8 #	4.8 #
Minimum:	4.8	4.8
Maximum:	4.8	4.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/21/2025 00:00	4.8	4.8

Average/Sum#:	4.8 #	4.8 #
Minimum:	4.8	4.8
Maximum:	4.8	4.8
%SI	0.00	0.00

AQ33 DAILY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/22/2025 00:00	4.8	4.8
Average/Sum#:	4.8 #	4.8 #
Minimum:	4.8	4.8
Maximum:	4.8	4.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/23/2025 00:00	5.0	5.3
Average/Sum#:	5.0 #	5.3 #
Minimum:	5.0	5.3
Maximum:	5.0	5.3
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/24/2025 00:00	4.8	4.8
Average/Sum#:	4.8 #	4.8 #
Minimum:	4.8	4.8
Maximum:	4.8	4.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/25/2025 00:00	4.8	4.8

AQ33 DAILY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	4.8 #	4.8 #
Minimum:	4.8	4.8
Maximum:	4.8	4.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/26/2025 00:00	4.8	4.8

Average/Sum#:	4.8 #	4.8 #
Minimum:	4.8	4.8
Maximum:	4.8	4.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/27/2025 00:00	4.8	4.7

Average/Sum#:	4.8 #	4.7 #
Minimum:	4.8	4.7
Maximum:	4.8	4.7
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/28/2025 00:00	5.3	5.4

Average/Sum#:	5.3 #	5.4 #
Minimum:	5.3	5.4
Maximum:	5.3	5.4
%SI	0.00	0.00

AQ33 DAILY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/29/2025 00:00	5.4	5.7
Average/Sum#:	5.4 #	5.7 #
Minimum:	5.4	5.7
Maximum:	5.4	5.7
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/30/2025 00:00	4.8	4.8
Average/Sum#:	4.8 #	4.8 #
Minimum:	4.8	4.8
Maximum:	4.8	4.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
07/31/2025 00:00	5.0	5.4
Average/Sum#:	5.0 #	5.4 #
Minimum:	5.0	5.4
Maximum:	5.0	5.4
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/01/2025 00:00	4.8	5.0

AQ33 DAILY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	4.8 #	5.0 #
Minimum:	4.8	5.0
Maximum:	4.8	5.0
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/02/2025 00:00	4.8	4.8

Average/Sum#:	4.8 #	4.8 #
Minimum:	4.8	4.8
Maximum:	4.8	4.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/03/2025 00:00	4.8	4.8

Average/Sum#:	4.8 #	4.8 #
Minimum:	4.8	4.8
Maximum:	4.8	4.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/04/2025 00:00	4.9	4.8

Average/Sum#:	4.9 #	4.8 #
Minimum:	4.9	4.8
Maximum:	4.9	4.8
%SI	0.00	0.00

AQ33 DAILY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/05/2025 00:00	5.3	5.4
Average/Sum#:	5.3 #	5.4 #
Minimum:	5.3	5.4
Maximum:	5.3	5.4
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/06/2025 00:00	5.1	5.1
Average/Sum#:	5.1 #	5.1 #
Minimum:	5.1	5.1
Maximum:	5.1	5.1
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/07/2025 00:00	4.8	5.1
Average/Sum#:	4.8 #	5.1 #
Minimum:	4.8	5.1
Maximum:	4.8	5.1
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/08/2025 00:00	4.8	4.8

AQ33 DAILY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	4.8 #	4.8 #
Minimum:	4.8	4.8
Maximum:	4.8	4.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/09/2025 00:00	4.8	4.8

Average/Sum#:	4.8 #	4.8 #
Minimum:	4.8	4.8
Maximum:	4.8	4.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/10/2025 00:00	5.0	5.5

Average/Sum#:	5.0 #	5.5 #
Minimum:	5.0	5.5
Maximum:	5.0	5.5
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/11/2025 00:00	5.2	5.6

Average/Sum#:	5.2 #	5.6 #
Minimum:	5.2	5.6
Maximum:	5.2	5.6
%SI	0.00	0.00

AQ33 DAILY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/12/2025 00:00	5.2	6.1
Average/Sum#:	5.2 #	6.1 #
Minimum:	5.2	6.1
Maximum:	5.2	6.1
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/13/2025 00:00	4.8	4.8
Average/Sum#:	4.8 #	4.8 #
Minimum:	4.8	4.8
Maximum:	4.8	4.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/14/2025 00:00	4.8	4.8
Average/Sum#:	4.8 #	4.8 #
Minimum:	4.8	4.8
Maximum:	4.8	4.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/15/2025 00:00	4.8	4.8

AQ33 DAILY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	4.8 #	4.8 #
Minimum:	4.8	4.8
Maximum:	4.8	4.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/16/2025 00:00	5.0	5.0

Average/Sum#:	5.0 #	5.0 #
Minimum:	5.0	5.0
Maximum:	5.0	5.0
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/17/2025 00:00	5.4	5.5

Average/Sum#:	5.4 #	5.5 #
Minimum:	5.4	5.5
Maximum:	5.4	5.5
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/18/2025 00:00	5.8	6.1

Average/Sum#:	5.8 #	6.1 #
Minimum:	5.8	6.1
Maximum:	5.8	6.1
%SI	0.00	0.00

AQ33 DAILY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/19/2025 00:00	5.8	6.0
Average/Sum#:	5.8 #	6.0 #
Minimum:	5.8	6.0
Maximum:	5.8	6.0
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/20/2025 00:00	6.8	7.0
Average/Sum#:	6.8 #	7.0 #
Minimum:	6.8	7.0
Maximum:	6.8	7.0
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/21/2025 00:00	7.4	8.0
Average/Sum#:	7.4 #	8.0 #
Minimum:	7.4	8.0
Maximum:	7.4	8.0
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/22/2025 00:00	7.3	7.6

AQ33 DAILY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	7.3 #	7.6 #
Minimum:	7.3	7.6
Maximum:	7.3	7.6
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/23/2025 00:00	7.3	8.0

Average/Sum#:	7.3 #	8.0 #
Minimum:	7.3	8.0
Maximum:	7.3	8.0
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/24/2025 00:00	6.3	6.8

Average/Sum#:	6.3 #	6.8 #
Minimum:	6.3	6.8
Maximum:	6.3	6.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/25/2025 00:00	7.0	7.5

Average/Sum#:	7.0 #	7.5 #
Minimum:	7.0	7.5
Maximum:	7.0	7.5
%SI	0.00	0.00

AQ33 DAILY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/26/2025 00:00	2.9	6.8
Average/Sum#:	2.9 #	6.8 #
Minimum:	2.9	6.8
Maximum:	2.9	6.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/27/2025 00:00	5.5	5.9
Average/Sum#:	5.5 #	5.9 #
Minimum:	5.5	5.9
Maximum:	5.5	5.9
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/28/2025 00:00	5.8	6.1
Average/Sum#:	5.8 #	6.1 #
Minimum:	5.8	6.1
Maximum:	5.8	6.1
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/29/2025 00:00	5.0	5.1

AQ33 DAILY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	5.0 #	5.1 #
Minimum:	5.0	5.1
Maximum:	5.0	5.1
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/30/2025 00:00	5.4	5.5

Average/Sum#:	5.4 #	5.5 #
Minimum:	5.4	5.5
Maximum:	5.4	5.5
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
08/31/2025 00:00	5.5	5.9

Average/Sum#:	5.5 #	5.9 #
Minimum:	5.5	5.9
Maximum:	5.5	5.9
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/01/2025 00:00	7.5	7.9

Average/Sum#:	7.5 #	7.9 #
Minimum:	7.5	7.9
Maximum:	7.5	7.9
%SI	0.00	0.00

AQ33 DAILY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/02/2025 00:00	8.9	9.1
Average/Sum#:	8.9 #	9.1 #
Minimum:	8.9	9.1
Maximum:	8.9	9.1
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/03/2025 00:00	8.2	8.6
Average/Sum#:	8.2 #	8.6 #
Minimum:	8.2	8.6
Maximum:	8.2	8.6
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/04/2025 00:00	7.3	7.7
Average/Sum#:	7.3 #	7.7 #
Minimum:	7.3	7.7
Maximum:	7.3	7.7
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/05/2025 00:00	7.2	7.4

AQ33 DAILY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	7.2 #	7.4 #
Minimum:	7.2	7.4
Maximum:	7.2	7.4
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)

09/06/2025 00:00	6.8	6.8
------------------	-----	-----

Average/Sum#:	6.8 #	6.8 #
Minimum:	6.8	6.8
Maximum:	6.8	6.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)

09/07/2025 00:00	6.7	6.9
------------------	-----	-----

Average/Sum#:	6.7 #	6.9 #
Minimum:	6.7	6.9
Maximum:	6.7	6.9
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)

09/08/2025 00:00	6.8	6.8
------------------	-----	-----

Average/Sum#:	6.8 #	6.8 #
Minimum:	6.8	6.8
Maximum:	6.8	6.8
%SI	0.00	0.00

AQ33 DAILY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/09/2025 00:00	7.2	7.3
Average/Sum#:	7.2 #	7.3 #
Minimum:	7.2	7.3
Maximum:	7.2	7.3
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/10/2025 00:00	6.6	6.7
Average/Sum#:	6.6 #	6.7 #
Minimum:	6.6	6.7
Maximum:	6.6	6.7
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/11/2025 00:00	7.1	7.2
Average/Sum#:	7.1 #	7.2 #
Minimum:	7.1	7.2
Maximum:	7.1	7.2
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/12/2025 00:00	6.7	6.9

AQ33 DAILY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	6.7 #	6.9 #
Minimum:	6.7	6.9
Maximum:	6.7	6.9
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/13/2025 00:00	6.2	6.3

Average/Sum#:	6.2 #	6.3 #
Minimum:	6.2	6.3
Maximum:	6.2	6.3
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/14/2025 00:00	6.2	6.3

Average/Sum#:	6.2 #	6.3 #
Minimum:	6.2	6.3
Maximum:	6.2	6.3
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/15/2025 00:00	7.3	7.5

Average/Sum#:	7.3 #	7.5 #
Minimum:	7.3	7.5
Maximum:	7.3	7.5
%SI	0.00	0.00

AQ33 DAILY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/16/2025 00:00	7.2	7.2
Average/Sum#:	7.2 #	7.2 #
Minimum:	7.2	7.2
Maximum:	7.2	7.2
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/17/2025 00:00	7.2	7.2
Average/Sum#:	7.2 #	7.2 #
Minimum:	7.2	7.2
Maximum:	7.2	7.2
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/18/2025 00:00	7.2	7.4
Average/Sum#:	7.2 #	7.4 #
Minimum:	7.2	7.4
Maximum:	7.2	7.4
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/19/2025 00:00	7.2	7.3

AQ33 DAILY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	7.2 #	7.3 #
Minimum:	7.2	7.3
Maximum:	7.2	7.3
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/20/2025 00:00	7.2	7.3

Average/Sum#:	7.2 #	7.3 #
Minimum:	7.2	7.3
Maximum:	7.2	7.3
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/21/2025 00:00	7.2	7.2

Average/Sum#:	7.2 #	7.2 #
Minimum:	7.2	7.2
Maximum:	7.2	7.2
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/22/2025 00:00	6.9	7.1

Average/Sum#:	6.9 #	7.1 #
Minimum:	6.9	7.1
Maximum:	6.9	7.1
%SI	0.00	0.00

AQ33 DAILY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/23/2025 00:00	7.3	7.4
Average/Sum#:	7.3 #	7.4 #
Minimum:	7.3	7.4
Maximum:	7.3	7.4
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/24/2025 00:00	7.2	7.2
Average/Sum#:	7.2 #	7.2 #
Minimum:	7.2	7.2
Maximum:	7.2	7.2
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/25/2025 00:00	7.2	7.2
Average/Sum#:	7.2 #	7.2 #
Minimum:	7.2	7.2
Maximum:	7.2	7.2
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/26/2025 00:00	6.6	6.7

AQ33 DAILY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:05 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Average/Sum#:	6.6 #	6.7 #
Minimum:	6.6	6.7
Maximum:	6.6	6.7
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/27/2025 00:00	6.3	6.5

Average/Sum#:	6.3 #	6.5 #
Minimum:	6.3	6.5
Maximum:	6.3	6.5
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/28/2025 00:00	6.7	6.8

Average/Sum#:	6.7 #	6.8 #
Minimum:	6.7	6.8
Maximum:	6.7	6.8
%SI	0.00	0.00

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/29/2025 00:00	7.1	7.2

Average/Sum#:	7.1 #	7.2 #
Minimum:	7.1	7.2
Maximum:	7.1	7.2
%SI	0.00	0.00

AQ33 DAILY SOX



From: 07/01/2025 00:00 **To:** 09/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2025 08:05 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, Lb	SO2, Lb
	1 Day(s)	1 Day(s)
09/30/2025 00:00	6.8	6.8
Average/Sum#:	6.8 #	6.8 #
Minimum:	6.8	6.8
Maximum:	6.8	6.8
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/01/2025 00:00	0.24582	0.26022
07/01/2025 01:00	0.25116	0.26586
07/01/2025 02:00	0.25716	0.27246
07/01/2025 03:00	0.25728	0.27222
07/01/2025 04:00	0.25722	0.27180
07/01/2025 05:00	0.21984	0.23262
07/01/2025 06:00	0.21666	0.22926
07/01/2025 07:00	0.21684	0.22944
07/01/2025 08:00	0.21642	0.22884
07/01/2025 09:00	0.21756	0.23004
07/01/2025 10:00	0.22074	0.23364
07/01/2025 11:00	0.22944	0.24174
07/01/2025 12:00	0.25878	0.27426
07/01/2025 13:00	0.26298	0.28368
07/01/2025 14:00	0.26274	0.28248
07/01/2025 15:00	0.26250	0.28260
07/01/2025 16:00	0.23958	0.25482
07/01/2025 17:00	0.23760	0.25050
07/01/2025 18:00	0.26232	0.28314
07/01/2025 19:00	0.23910	0.25410
07/01/2025 20:00	0.23190	0.24570
07/01/2025 21:00	0.24588	0.26034
07/01/2025 22:00	0.22200	0.23532
07/01/2025 23:00	0.25626	0.27060
Average/Sum#:	0.24116	0.25607
Minimum:	0.21642	0.22884
Maximum:	0.26298	0.28368
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/02/2025 00:00	0.21756	0.23034
07/02/2025 01:00	0.21696	0.22932
07/02/2025 02:00	0.21684	0.22902
07/02/2025 03:00	0.21678	0.22908
07/02/2025 04:00	0.21708	0.22920
07/02/2025 05:00	0.21690	0.22938
07/02/2025 06:00	0.21690	0.22950
07/02/2025 07:00	0.21672	0.22914
07/02/2025 08:00	0.21636	0.22896
07/02/2025 09:00	0.21594	0.22848
07/02/2025 10:00	0.21570	0.22800
07/02/2025 11:00	0.21630	0.22800
07/02/2025 12:00	0.21642	0.22764
07/02/2025 13:00	0.21624	0.22758
07/02/2025 14:00	0.22290	0.23544
07/02/2025 15:00	0.25986	0.28380
07/02/2025 16:00	0.21804	0.22932
07/02/2025 17:00	0.21576	0.22662
07/02/2025 18:00	0.23382	0.25080
07/02/2025 19:00	0.21450	0.22728
07/02/2025 20:00	0.21468	0.22746
07/02/2025 21:00	0.21492	0.22782
07/02/2025 22:00	0.21510	0.22776
07/02/2025 23:00	0.21534	0.22806
Average/Sum#:	0.21907	0.23200
Minimum:	0.21450	0.22662
Maximum:	0.25986	0.28380
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 **To:** 09/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/03/2025 00:00	0.21552	0.22800
07/03/2025 01:00	0.21570	0.22806
07/03/2025 02:00	0.21582	0.22842
07/03/2025 03:00	0.21600	0.22854
07/03/2025 04:00	0.21600	0.22854
07/03/2025 05:00	0.21624	0.22878
07/03/2025 06:00	0.21576	0.22860
07/03/2025 07:00	0.21576	0.22818
07/03/2025 08:00	0.21558	0.22806
07/03/2025 09:00	0.21528	0.22788
07/03/2025 10:00	0.21492	0.22782
07/03/2025 11:00	0.21558	0.22716
07/03/2025 12:00	0.21552	0.22716
07/03/2025 13:00	0.21558	0.22686
07/03/2025 14:00	0.21540	0.22692
07/03/2025 15:00	0.21510	0.22680
07/03/2025 16:00	0.21510	0.22710
07/03/2025 17:00	0.21486	0.22740
07/03/2025 18:00	0.21492	0.22764
07/03/2025 19:00	0.21528	0.22818
07/03/2025 20:00	0.21546	0.22842
07/03/2025 21:00	0.21576	0.22842
07/03/2025 22:00	0.21606	0.22878
07/03/2025 23:00	0.21654	0.22932
Average/Sum#:	0.21557	0.22796
Minimum:	0.21486	0.22680
Maximum:	0.21654	0.22932
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/04/2025 00:00	0.24186	0.25578
07/04/2025 01:00	0.21162	0.22386
07/04/2025 02:00	0.22026	0.23310
07/04/2025 03:00	0.21048	0.22272
07/04/2025 04:00	0.21060	0.22278
07/04/2025 05:00	0.21066	0.22284
07/04/2025 06:00	0.21048	0.22278
07/04/2025 07:00	0.21048	0.22260
07/04/2025 08:00	0.21012	0.22242
07/04/2025 09:00	0.20988	0.22224
07/04/2025 10:00	0.20958	0.22206
07/04/2025 11:00	0.21024	0.22164
07/04/2025 12:00	0.21024	0.22140
07/04/2025 13:00	0.21018	0.22122
07/04/2025 14:00	0.21000	0.22128
07/04/2025 15:00	0.20988	0.22128
07/04/2025 16:00	0.20994	0.22134
07/04/2025 17:00	0.21498	0.22674
07/04/2025 18:00	0.22644	0.23994
07/04/2025 19:00	0.20970	0.22206
07/04/2025 20:00	0.21000	0.22224
07/04/2025 21:00	0.21048	0.22278
07/04/2025 22:00	0.21048	0.22260
07/04/2025 23:00	0.21072	0.22278
Average/Sum#:	0.21289	0.22502
Minimum:	0.20958	0.22122
Maximum:	0.24186	0.25578
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 **To:** 09/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/05/2025 00:00	0.21090	0.22296
07/05/2025 01:00	0.21120	0.22308
07/05/2025 02:00	0.21144	0.22308
07/05/2025 03:00	0.21144	0.22338
07/05/2025 04:00	0.21156	0.22344
07/05/2025 05:00	0.21162	0.22356
07/05/2025 06:00	0.21162	0.22344
07/05/2025 07:00	0.21180	0.22350
07/05/2025 08:00	0.21120	0.22320
07/05/2025 09:00	0.21084	0.22272
07/05/2025 10:00	0.21054	0.22254
07/05/2025 11:00	0.21060	0.22200
07/05/2025 12:00	0.21060	0.22176
07/05/2025 13:00	0.21084	0.22170
07/05/2025 14:00	0.21066	0.22164
07/05/2025 15:00	0.21018	0.22164
07/05/2025 16:00	0.21000	0.22140
07/05/2025 17:00	0.20976	0.22116
07/05/2025 18:00	0.22758	0.24258
07/05/2025 19:00	0.20916	0.22158
07/05/2025 20:00	0.20922	0.22170
07/05/2025 21:00	0.20952	0.22188
07/05/2025 22:00	0.20976	0.22200
07/05/2025 23:00	0.20982	0.22224
Average/Sum#:	0.21133	0.22326
Minimum:	0.20916	0.22116
Maximum:	0.22758	0.24258
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/06/2025 00:00	0.21006	0.22236
07/06/2025 01:00	0.21036	0.22236
07/06/2025 02:00	0.21036	0.22248
07/06/2025 03:00	0.21048	0.22248
07/06/2025 04:00	0.21072	0.22266
07/06/2025 05:00	0.21090	0.22266
07/06/2025 06:00	0.21078	0.22266
07/06/2025 07:00	0.21060	0.22230
07/06/2025 08:00	0.21012	0.22212
07/06/2025 09:00	0.20970	0.22194
07/06/2025 10:00	0.20910	0.22146
07/06/2025 11:00	0.20976	0.22098
07/06/2025 12:00	0.20958	0.22074
07/06/2025 13:00	0.21234	0.22326
07/06/2025 14:00	0.22158	0.23412
07/06/2025 15:00	0.20946	0.22056
07/06/2025 16:00	0.22752	0.24114
07/06/2025 17:00	0.23160	0.24402
07/06/2025 18:00	0.25410	0.26808
07/06/2025 19:00	0.25614	0.27096
07/06/2025 20:00	0.25590	0.27126
07/06/2025 21:00	0.25404	0.26910
07/06/2025 22:00	0.22542	0.23892
07/06/2025 23:00	0.24810	0.25968
Average/Sum#:	0.22203	0.23451
Minimum:	0.20910	0.22056
Maximum:	0.25614	0.27126
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 **To:** 09/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/07/2025 00:00	0.23604	0.24972
07/07/2025 01:00	0.20934	0.22146
07/07/2025 02:00	0.20928	0.22164
07/07/2025 03:00	0.21804	0.23100
07/07/2025 04:00	0.20988	0.22212
07/07/2025 05:00	0.20994	0.22224
07/07/2025 06:00	0.20976	0.22212
07/07/2025 07:00	0.20982	0.22200
07/07/2025 08:00	0.20952	0.22176
07/07/2025 09:00	0.20904	0.22122
07/07/2025 10:00	0.20880	0.22110
07/07/2025 11:00	0.20922	0.22068
07/07/2025 12:00	0.21348	0.22482
07/07/2025 13:00	0.21966	0.23202
07/07/2025 14:00	0.23460	0.24948
07/07/2025 15:00	0.21144	0.22266
07/07/2025 16:00	0.22260	0.23502
07/07/2025 17:00	0.23754	0.25008
07/07/2025 18:00	0.25608	0.27000
07/07/2025 19:00	0.25512	0.27012
07/07/2025 20:00	0.25512	0.26976
07/07/2025 21:00	0.24324	0.25764
07/07/2025 22:00	0.23220	0.24636
07/07/2025 23:00	0.25518	0.27054
Average/Sum#:	0.22437	0.23732
Minimum:	0.20880	0.22068
Maximum:	0.25608	0.27054
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/08/2025 00:00	0.25566	0.27102
07/08/2025 01:00	0.25518	0.27018
07/08/2025 02:00	0.25524	0.27036
07/08/2025 03:00	0.21318	0.22530
07/08/2025 04:00	0.23958	0.25356
07/08/2025 05:00	0.22752	0.24078
07/08/2025 06:00	0.21048	0.22254
07/08/2025 07:00	0.21042	0.22218
07/08/2025 08:00	0.21000	0.22188
07/08/2025 09:00	0.20976	0.22176
07/08/2025 10:00	0.20940	0.22146
07/08/2025 11:00	0.20988	0.22122
07/08/2025 12:00	0.20988	0.22110
07/08/2025 13:00	0.20976	0.22092
07/08/2025 14:00	0.20952	0.22074
07/08/2025 15:00	0.20934	0.22068
07/08/2025 16:00	0.20922	0.22056
07/08/2025 17:00	0.21396	0.22560
07/08/2025 18:00	0.23958	0.25476
07/08/2025 19:00	0.23388	0.24804
07/08/2025 20:00	0.21300	0.22566
07/08/2025 21:00	0.20928	0.22164
07/08/2025 22:00	0.21102	0.22362
07/08/2025 23:00	0.21702	0.22980
Average/Sum#:	0.22049	0.23314
Minimum:	0.20922	0.22056
Maximum:	0.25566	0.27102
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/09/2025 00:00	0.21024	0.22260
07/09/2025 01:00	0.21060	0.22278
07/09/2025 02:00	0.21096	0.22296
07/09/2025 03:00	0.21102	0.22296
07/09/2025 04:00	0.21114	0.22308
07/09/2025 05:00	0.21246	0.22464
07/09/2025 06:00	0.21078	0.22296
07/09/2025 07:00	0.21084	0.22272
07/09/2025 08:00	0.21048	0.22248
07/09/2025 09:00	0.21030	0.22224
07/09/2025 10:00	0.20982	0.22170
07/09/2025 11:00	0.20982	0.22128
07/09/2025 12:00	0.21006	0.22104
07/09/2025 13:00	0.20970	0.22068
07/09/2025 14:00	0.20928	0.22038
07/09/2025 15:00	0.20904	0.22020
07/09/2025 16:00	0.21678	0.22920
07/09/2025 17:00	0.22044	0.23214
07/09/2025 18:00	0.24504	0.25890
07/09/2025 19:00	0.25020	0.26514
07/09/2025 20:00	0.22962	0.24324
07/09/2025 21:00	0.24720	0.26154
07/09/2025 22:00	0.23562	0.24936
07/09/2025 23:00	0.24222	0.25626
Average/Sum#:	0.21890	0.23127
Minimum:	0.20904	0.22020
Maximum:	0.25020	0.26514
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 **To:** 09/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/10/2025 00:00	0.21150	0.22356
07/10/2025 01:00	0.21048	0.22260
07/10/2025 02:00	0.20994	0.22194
07/10/2025 03:00	0.21450	0.22668
07/10/2025 04:00	0.21942	0.23184
07/10/2025 05:00	0.21516	0.22746
07/10/2025 06:00	0.20982	0.22200
07/10/2025 07:00	0.20970	0.22158
07/10/2025 08:00	0.20910	0.22134
07/10/2025 09:00	0.20868	0.22080
07/10/2025 10:00	0.20856	0.22056
07/10/2025 11:00	0.20922	0.22026
07/10/2025 12:00	0.20922	0.22008
07/10/2025 13:00	0.20922	0.21960
07/10/2025 14:00	0.21738	0.22848
07/10/2025 15:00	0.22386	0.23532
07/10/2025 16:00	0.21066	0.22152
07/10/2025 17:00	0.25290	0.26586
07/10/2025 18:00	0.25248	0.26586
07/10/2025 19:00	0.25218	0.26640
07/10/2025 20:00	0.24558	0.25992
07/10/2025 21:00	0.25134	0.26556
07/10/2025 22:00	0.25038	0.26490
07/10/2025 23:00	0.24204	0.25626
Average/Sum#:	0.22306	0.23543
Minimum:	0.20856	0.21960
Maximum:	0.25290	0.26640
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/11/2025 00:00	0.20904	0.22146
07/11/2025 01:00	0.20922	0.22164
07/11/2025 02:00	0.20958	0.22206
07/11/2025 03:00	0.22914	0.24234
07/11/2025 04:00	0.24474	0.25896
07/11/2025 05:00	0.22698	0.24018
07/11/2025 06:00	0.21030	0.22296
07/11/2025 07:00	0.20922	0.22116
07/11/2025 08:00	0.20898	0.22116
07/11/2025 09:00	0.20856	0.22074
07/11/2025 10:00	0.22818	0.24264
07/11/2025 11:00	0.25380	0.26634
07/11/2025 12:00	0.24294	0.25572
07/11/2025 13:00	0.25410	0.26796
07/11/2025 14:00	0.25350	0.26808
07/11/2025 15:00	0.25278	0.26640
07/11/2025 16:00	0.24168	0.25554
07/11/2025 17:00	0.25392	0.27402
07/11/2025 18:00	0.35592	0.38064
07/11/2025 19:00	0.37254	0.39870
07/11/2025 20:00	0.32574	0.35148
07/11/2025 21:00	0.34404	0.37110
07/11/2025 22:00	0.29316	0.32124
07/11/2025 23:00	0.31212	0.34002
Average/Sum#:	0.25626	0.27302
Minimum:	0.20856	0.22074
Maximum:	0.37254	0.39870
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/12/2025 00:00	0.22674	0.24126
07/12/2025 01:00	0.20886	0.22134
07/12/2025 02:00	0.20904	0.22158
07/12/2025 03:00	0.20922	0.22164
07/12/2025 04:00	0.20958	0.22188
07/12/2025 05:00	0.20940	0.22182
07/12/2025 06:00	0.20922	0.22164
07/12/2025 07:00	0.20922	0.22146
07/12/2025 08:00	0.20892	0.22134
07/12/2025 09:00	0.20874	0.22104
07/12/2025 10:00	0.20868	0.22086
07/12/2025 11:00	0.20910	0.22050
07/12/2025 12:00	0.20916	0.22014
07/12/2025 13:00	0.20946	0.22002
07/12/2025 14:00	0.23928	0.25734
07/12/2025 15:00	0.23196	0.24588
07/12/2025 16:00	0.22746	0.24282
07/12/2025 17:00	0.22752	0.24036
07/12/2025 18:00	0.23892	0.25278
07/12/2025 19:00	0.25260	0.26766
07/12/2025 20:00	0.22566	0.23916
07/12/2025 21:00	0.21240	0.22506
07/12/2025 22:00	0.21678	0.23004
07/12/2025 23:00	0.25554	0.27036
Average/Sum#:	0.21973	0.23283
Minimum:	0.20868	0.22002
Maximum:	0.25554	0.27036
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 **To:** 09/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/13/2025 00:00	0.23712	0.25128
07/13/2025 01:00	0.24126	0.25560
07/13/2025 02:00	0.25566	0.27084
07/13/2025 03:00	0.22332	0.23664
07/13/2025 04:00	0.21726	0.23016
07/13/2025 05:00	0.21840	0.23124
07/13/2025 06:00	0.20946	0.22200
07/13/2025 07:00	0.20964	0.22176
07/13/2025 08:00	0.20934	0.22164
07/13/2025 09:00	0.20892	0.22116
07/13/2025 10:00	0.20880	0.22104
07/13/2025 11:00	0.20934	0.22080
07/13/2025 12:00	0.21384	0.22584
07/13/2025 13:00	0.25014	0.26736
07/13/2025 14:00	0.25494	0.27066
07/13/2025 15:00	0.25488	0.27078
07/13/2025 16:00	0.25440	0.27072
07/13/2025 17:00	0.23964	0.25296
07/13/2025 18:00	0.25626	0.00000
07/13/2025 19:00	0.25572	0.00000
07/13/2025 20:00	0.25566	0.00000
07/13/2025 21:00	0.25254	0.00000
07/13/2025 22:00	0.24120	0.23862
07/13/2025 23:00	0.25074	0.26544
Average/Sum#:	0.23452	0.24333
Minimum:	0.20880	0.22080
Maximum:	0.25626	0.27084
%SI	0.00	16.67

AQ33 HOURLY SOX



From: 07/01/2025 00:00 **To:** 09/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/14/2025 00:00	0.24318	0.27036
07/14/2025 01:00	0.21258	0.22338
07/14/2025 02:00	0.21024	0.22266
07/14/2025 03:00	0.21150	0.22398
07/14/2025 04:00	0.23538	0.24942
07/14/2025 05:00	0.23676	0.25110
07/14/2025 06:00	0.22260	0.23604
07/14/2025 07:00	0.20940	0.22152
07/14/2025 08:00	0.20898	0.22152
07/14/2025 09:00	0.20868	0.22116
07/14/2025 10:00	0.20838	0.22068
07/14/2025 11:00	0.20892	0.22044
07/14/2025 12:00	0.20898	0.21996
07/14/2025 13:00	0.20910	0.21954
07/14/2025 14:00	0.21582	0.22806
07/14/2025 15:00	0.21096	0.22206
07/14/2025 16:00	0.21114	0.22290
07/14/2025 17:00	0.21660	0.23046
07/14/2025 18:00	0.21510	0.22674
07/14/2025 19:00	0.20814	0.22038
07/14/2025 20:00	0.20808	0.22080
07/14/2025 21:00	0.20844	0.22140
07/14/2025 22:00	0.20910	0.22188
07/14/2025 23:00	0.20982	0.22260
Average/Sum#:	0.21450	0.22746
Minimum:	0.20808	0.21954
Maximum:	0.24318	0.27036
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/15/2025 00:00	0.21024	0.22290
07/15/2025 01:00	0.21054	0.22314
07/15/2025 02:00	0.21054	0.22314
07/15/2025 03:00	0.21084	0.22362
07/15/2025 04:00	0.21096	0.22338
07/15/2025 05:00	0.21090	0.22356
07/15/2025 06:00	0.21066	0.22338
07/15/2025 07:00	0.21060	0.22308
07/15/2025 08:00	0.20970	0.22218
07/15/2025 09:00	0.20904	0.22176
07/15/2025 10:00	0.20874	0.22122
07/15/2025 11:00	0.20922	0.22080
07/15/2025 12:00	0.20904	0.22056
07/15/2025 13:00	0.20910	0.22050
07/15/2025 14:00	0.20892	0.22014
07/15/2025 15:00	0.20844	0.22008
07/15/2025 16:00	0.20832	0.21996
07/15/2025 17:00	0.22224	0.23436
07/15/2025 18:00	0.21024	0.22242
07/15/2025 19:00	0.20802	0.22056
07/15/2025 20:00	0.20856	0.22128
07/15/2025 21:00	0.21204	0.22494
07/15/2025 22:00	0.20892	0.22152
07/15/2025 23:00	0.20922	0.22176
Average/Sum#:	0.21021	0.22251
Minimum:	0.20802	0.21996
Maximum:	0.22224	0.23436
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 **To:** 09/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
07/16/2025 00:00	0.20940	0.22194
07/16/2025 01:00	0.20964	0.22206
07/16/2025 02:00	0.20982	0.22212
07/16/2025 03:00	0.21000	0.22230
07/16/2025 04:00	0.21498	0.22770
07/16/2025 05:00	0.24792	0.26274
07/16/2025 06:00	0.21006	0.22236
07/16/2025 07:00	0.21030	0.22224
07/16/2025 08:00	0.20988	0.22188
07/16/2025 09:00	0.20952	0.22164
07/16/2025 10:00	0.20928	0.22152
07/16/2025 11:00	0.21906	0.23136
07/16/2025 12:00	0.22056	0.23358
07/16/2025 13:00	0.23790	0.25122
07/16/2025 14:00	0.22296	0.23484
07/16/2025 15:00	0.22074	0.23388
07/16/2025 16:00	0.20886	0.22044
07/16/2025 17:00	0.21126	0.22314
07/16/2025 18:00	0.20892	0.22116
07/16/2025 19:00	0.20862	0.22122
07/16/2025 20:00	0.20886	0.22152
07/16/2025 21:00	0.20910	0.22176
07/16/2025 22:00	0.20916	0.22176
07/16/2025 23:00	0.20910	0.22158
Average/Sum#:	0.21441	0.22692
Minimum:	0.20862	0.22044
Maximum:	0.24792	0.26274
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 **To:** 09/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/17/2025 00:00	0.20916	0.22158
07/17/2025 01:00	0.21084	0.22332
07/17/2025 02:00	0.20946	0.22170
07/17/2025 03:00	0.20976	0.22188
07/17/2025 04:00	0.20988	0.22200
07/17/2025 05:00	0.20976	0.22182
07/17/2025 06:00	0.20964	0.22176
07/17/2025 07:00	0.20958	0.22164
07/17/2025 08:00	0.20958	0.22158
07/17/2025 09:00	0.21006	0.22224
07/17/2025 10:00	0.20928	0.22134
07/17/2025 11:00	0.20904	0.22044
07/17/2025 12:00	0.21774	0.23016
07/17/2025 13:00	0.23928	0.25320
07/17/2025 14:00	0.25032	0.26406
07/17/2025 15:00	0.25554	0.26952
07/17/2025 16:00	0.20856	0.22020
07/17/2025 17:00	0.22182	0.23382
07/17/2025 18:00	0.20856	0.22056
07/17/2025 19:00	0.20778	0.22038
07/17/2025 20:00	0.20832	0.22086
07/17/2025 21:00	0.20862	0.22110
07/17/2025 22:00	0.21090	0.22368
07/17/2025 23:00	0.23568	0.24978
Average/Sum#:	0.21622	0.22869
Minimum:	0.20778	0.22020
Maximum:	0.25554	0.26952
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 **To:** 09/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/18/2025 00:00	0.21108	0.22338
07/18/2025 01:00	0.20946	0.22206
07/18/2025 02:00	0.20964	0.22200
07/18/2025 03:00	0.20982	0.22224
07/18/2025 04:00	0.21510	0.22806
07/18/2025 05:00	0.22230	0.23556
07/18/2025 06:00	0.21276	0.22560
07/18/2025 07:00	0.21150	0.22380
07/18/2025 08:00	0.21126	0.22356
07/18/2025 09:00	0.21066	0.22320
07/18/2025 10:00	0.21012	0.22248
07/18/2025 11:00	0.20976	0.22158
07/18/2025 12:00	0.20916	0.22062
07/18/2025 13:00	0.20886	0.22014
07/18/2025 14:00	0.20850	0.21990
07/18/2025 15:00	0.20814	0.21972
07/18/2025 16:00	0.20802	0.21972
07/18/2025 17:00	0.21306	0.22488
07/18/2025 18:00	0.20886	0.22092
07/18/2025 19:00	0.20772	0.22020
07/18/2025 20:00	0.20802	0.22068
07/18/2025 21:00	0.20844	0.22128
07/18/2025 22:00	0.21096	0.22386
07/18/2025 23:00	0.24198	0.25650
Average/Sum#:	0.21188	0.22425
Minimum:	0.20772	0.21972
Maximum:	0.24198	0.25650
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/19/2025 00:00	0.20964	0.22224
07/19/2025 01:00	0.20970	0.22230
07/19/2025 02:00	0.20958	0.22206
07/19/2025 03:00	0.20976	0.22212
07/19/2025 04:00	0.21000	0.22218
07/19/2025 05:00	0.21012	0.22236
07/19/2025 06:00	0.21018	0.22224
07/19/2025 07:00	0.21018	0.22200
07/19/2025 08:00	0.20970	0.22188
07/19/2025 09:00	0.20928	0.22146
07/19/2025 10:00	0.20874	0.22122
07/19/2025 11:00	0.20922	0.22098
07/19/2025 12:00	0.20910	0.22056
07/19/2025 13:00	0.20886	0.22014
07/19/2025 14:00	0.20862	0.21990
07/19/2025 15:00	0.20844	0.21996
07/19/2025 16:00	0.20880	0.21990
07/19/2025 17:00	0.21276	0.22452
07/19/2025 18:00	0.20850	0.22050
07/19/2025 19:00	0.20766	0.22026
07/19/2025 20:00	0.20826	0.22080
07/19/2025 21:00	0.20826	0.22098
07/19/2025 22:00	0.20844	0.22116
07/19/2025 23:00	0.20856	0.22116
Average/Sum#:	0.20927	0.22137
Minimum:	0.20766	0.21990
Maximum:	0.21276	0.22452
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 **To:** 09/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/20/2025 00:00	0.20880	0.22134
07/20/2025 01:00	0.20892	0.22146
07/20/2025 02:00	0.20904	0.22140
07/20/2025 03:00	0.20928	0.22176
07/20/2025 04:00	0.20958	0.22188
07/20/2025 05:00	0.20964	0.22188
07/20/2025 06:00	0.20970	0.22200
07/20/2025 07:00	0.20976	0.22194
07/20/2025 08:00	0.20952	0.22170
07/20/2025 09:00	0.20910	0.22140
07/20/2025 10:00	0.20856	0.22104
07/20/2025 11:00	0.20868	0.22062
07/20/2025 12:00	0.20850	0.22014
07/20/2025 13:00	0.20844	0.21978
07/20/2025 14:00	0.20820	0.21966
07/20/2025 15:00	0.20796	0.21966
07/20/2025 16:00	0.20808	0.21984
07/20/2025 17:00	0.21012	0.22188
07/20/2025 18:00	0.20832	0.22068
07/20/2025 19:00	0.20814	0.22098
07/20/2025 20:00	0.20862	0.22140
07/20/2025 21:00	0.20886	0.22152
07/20/2025 22:00	0.20904	0.22158
07/20/2025 23:00	0.20934	0.22188
Average/Sum#:	0.20893	0.22114
Minimum:	0.20796	0.21966
Maximum:	0.21012	0.22200
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 **To:** 09/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/21/2025 00:00	0.20916	0.22164
07/21/2025 01:00	0.20916	0.22170
07/21/2025 02:00	0.20922	0.22176
07/21/2025 03:00	0.20934	0.22194
07/21/2025 04:00	0.22392	0.23730
07/21/2025 05:00	0.22302	0.23616
07/21/2025 06:00	0.20982	0.22200
07/21/2025 07:00	0.20994	0.22200
07/21/2025 08:00	0.20958	0.22176
07/21/2025 09:00	0.20922	0.22158
07/21/2025 10:00	0.20892	0.22128
07/21/2025 11:00	0.20910	0.22080
07/21/2025 12:00	0.20892	0.22044
07/21/2025 13:00	0.20892	0.22032
07/21/2025 14:00	0.20862	0.22014
07/21/2025 15:00	0.20826	0.22026
07/21/2025 16:00	0.20814	0.22056
07/21/2025 17:00	0.20814	0.22068
07/21/2025 18:00	0.20838	0.22098
07/21/2025 19:00	0.20862	0.22128
07/21/2025 20:00	0.20892	0.22146
07/21/2025 21:00	0.20910	0.22146
07/21/2025 22:00	0.20934	0.22164
07/21/2025 23:00	0.20946	0.22188
Average/Sum#:	0.21022	0.22254
Minimum:	0.20814	0.22014
Maximum:	0.22392	0.23730
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 **To:** 09/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
07/22/2025 00:00	0.20982	0.22218
07/22/2025 01:00	0.21006	0.22242
07/22/2025 02:00	0.21012	0.22230
07/22/2025 03:00	0.20988	0.22218
07/22/2025 04:00	0.20964	0.22188
07/22/2025 05:00	0.20964	0.22206
07/22/2025 06:00	0.20964	0.22182
07/22/2025 07:00	0.20952	0.22200
07/22/2025 08:00	0.20958	0.22200
07/22/2025 09:00	0.20934	0.22200
07/22/2025 10:00	0.20916	0.22158
07/22/2025 11:00	0.20964	0.22140
07/22/2025 12:00	0.20964	0.22128
07/22/2025 13:00	0.20940	0.22086
07/22/2025 14:00	0.20904	0.22068
07/22/2025 15:00	0.20868	0.22056
07/22/2025 16:00	0.20868	0.22056
07/22/2025 17:00	0.20886	0.22086
07/22/2025 18:00	0.20922	0.22152
07/22/2025 19:00	0.20916	0.22176
07/22/2025 20:00	0.20952	0.22230
07/22/2025 21:00	0.20994	0.22248
07/22/2025 22:00	0.21108	0.22350
07/22/2025 23:00	0.21108	0.22332
Average/Sum#:	0.20960	0.22181
Minimum:	0.20868	0.22056
Maximum:	0.21108	0.22350
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 **To:** 09/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/23/2025 00:00	0.21012	0.22272
07/23/2025 01:00	0.21060	0.22284
07/23/2025 02:00	0.21066	0.22260
07/23/2025 03:00	0.21066	0.22266
07/23/2025 04:00	0.21078	0.22272
07/23/2025 05:00	0.21054	0.22302
07/23/2025 06:00	0.21048	0.22266
07/23/2025 07:00	0.21186	0.22410
07/23/2025 08:00	0.21006	0.22230
07/23/2025 09:00	0.20982	0.22230
07/23/2025 10:00	0.20934	0.22200
07/23/2025 11:00	0.20946	0.22182
07/23/2025 12:00	0.20964	0.22158
07/23/2025 13:00	0.21834	0.23070
07/23/2025 14:00	0.20946	0.22116
07/23/2025 15:00	0.20898	0.22086
07/23/2025 16:00	0.20898	0.22098
07/23/2025 17:00	0.21468	0.22710
07/23/2025 18:00	0.23784	0.25218
07/23/2025 19:00	0.24984	0.26490
07/23/2025 20:00	0.22650	0.23988
07/23/2025 21:00	0.25440	0.26958
07/23/2025 22:00	0.25488	0.27048
07/23/2025 23:00	0.23934	0.25368
Average/Sum#:	0.21905	0.23187
Minimum:	0.20898	0.22086
Maximum:	0.25488	0.27048
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/24/2025 00:00	0.21144	0.22398
07/24/2025 01:00	0.21048	0.22278
07/24/2025 02:00	0.21078	0.22272
07/24/2025 03:00	0.21090	0.22290
07/24/2025 04:00	0.21360	0.22608
07/24/2025 05:00	0.22656	0.23994
07/24/2025 06:00	0.21078	0.22296
07/24/2025 07:00	0.21084	0.22278
07/24/2025 08:00	0.21054	0.22260
07/24/2025 09:00	0.21012	0.22230
07/24/2025 10:00	0.20982	0.22194
07/24/2025 11:00	0.20976	0.22152
07/24/2025 12:00	0.20958	0.22116
07/24/2025 13:00	0.20952	0.22098
07/24/2025 14:00	0.20940	0.22086
07/24/2025 15:00	0.20898	0.22074
07/24/2025 16:00	0.20874	0.22068
07/24/2025 17:00	0.21780	0.23088
07/24/2025 18:00	0.20982	0.22218
07/24/2025 19:00	0.20862	0.22110
07/24/2025 20:00	0.20898	0.22152
07/24/2025 21:00	0.20922	0.22188
07/24/2025 22:00	0.20934	0.22200
07/24/2025 23:00	0.20952	0.22200
Average/Sum#:	0.21105	0.22327
Minimum:	0.20862	0.22068
Maximum:	0.22656	0.23994
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/25/2025 00:00	0.20976	0.22206
07/25/2025 01:00	0.21000	0.22230
07/25/2025 02:00	0.21006	0.22242
07/25/2025 03:00	0.21030	0.22248
07/25/2025 04:00	0.21054	0.22266
07/25/2025 05:00	0.21066	0.22278
07/25/2025 06:00	0.21060	0.22278
07/25/2025 07:00	0.21048	0.22248
07/25/2025 08:00	0.21024	0.22242
07/25/2025 09:00	0.21000	0.22230
07/25/2025 10:00	0.20964	0.22200
07/25/2025 11:00	0.20976	0.22164
07/25/2025 12:00	0.20970	0.22122
07/25/2025 13:00	0.20952	0.22086
07/25/2025 14:00	0.20928	0.22080
07/25/2025 15:00	0.20904	0.22098
07/25/2025 16:00	0.20904	0.22086
07/25/2025 17:00	0.20916	0.22104
07/25/2025 18:00	0.20916	0.22146
07/25/2025 19:00	0.20904	0.22176
07/25/2025 20:00	0.21066	0.22338
07/25/2025 21:00	0.20964	0.22218
07/25/2025 22:00	0.20994	0.22242
07/25/2025 23:00	0.21000	0.22230
Average/Sum#:	0.20984	0.22198
Minimum:	0.20904	0.22080
Maximum:	0.21066	0.22338
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 **To:** 09/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/26/2025 00:00	0.21006	0.22248
07/26/2025 01:00	0.21024	0.22248
07/26/2025 02:00	0.21048	0.22242
07/26/2025 03:00	0.21048	0.22248
07/26/2025 04:00	0.21066	0.22272
07/26/2025 05:00	0.21066	0.22272
07/26/2025 06:00	0.21054	0.22272
07/26/2025 07:00	0.21036	0.22254
07/26/2025 08:00	0.21006	0.22230
07/26/2025 09:00	0.20970	0.22188
07/26/2025 10:00	0.20922	0.22134
07/26/2025 11:00	0.20910	0.22068
07/26/2025 12:00	0.20874	0.22044
07/26/2025 13:00	0.20928	0.22086
07/26/2025 14:00	0.20946	0.22116
07/26/2025 15:00	0.20910	0.22116
07/26/2025 16:00	0.20910	0.22098
07/26/2025 17:00	0.21714	0.22968
07/26/2025 18:00	0.20934	0.22158
07/26/2025 19:00	0.20916	0.22170
07/26/2025 20:00	0.20940	0.22194
07/26/2025 21:00	0.20928	0.22206
07/26/2025 22:00	0.20934	0.22176
07/26/2025 23:00	0.20964	0.22200
Average/Sum#:	0.21002	0.22217
Minimum:	0.20874	0.22044
Maximum:	0.21714	0.22968
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 **To:** 09/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/27/2025 00:00	0.20982	0.22224
07/27/2025 01:00	0.20994	0.22224
07/27/2025 02:00	0.21030	0.22254
07/27/2025 03:00	0.21030	0.22242
07/27/2025 04:00	0.21048	0.22248
07/27/2025 05:00	0.21060	0.22230
07/27/2025 06:00	0.21042	0.22254
07/27/2025 07:00	0.21042	0.22260
07/27/2025 08:00	0.21036	0.22248
07/27/2025 09:00	0.21018	0.22230
07/27/2025 10:00	0.20988	0.22206
07/27/2025 11:00	0.21006	0.22188
07/27/2025 12:00	0.20988	0.22164
07/27/2025 13:00	0.20970	0.22104
07/27/2025 14:00	0.20946	0.22098
07/27/2025 15:00	0.20916	0.22104
07/27/2025 16:00	0.20916	0.22110
07/27/2025 17:00	0.21720	0.23034
07/27/2025 18:00	0.21066	0.22296
07/27/2025 19:00	0.21102	0.22644
07/27/2025 20:00	0.20928	0.22206
07/27/2025 21:00	0.20934	0.22218
07/27/2025 22:00	0.20952	0.22224
07/27/2025 23:00	0.20970	0.22230
Average/Sum#:	0.21029	0.22260
Minimum:	0.20916	0.22098
Maximum:	0.21720	0.23034
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 **To:** 09/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/28/2025 00:00	0.20970	0.22242
07/28/2025 01:00	0.20982	0.22242
07/28/2025 02:00	0.20982	0.22254
07/28/2025 03:00	0.21006	0.22242
07/28/2025 04:00	0.21018	0.22254
07/28/2025 05:00	0.21018	0.22248
07/28/2025 06:00	0.21018	0.22278
07/28/2025 07:00	0.21048	0.22272
07/28/2025 08:00	0.21012	0.22260
07/28/2025 09:00	0.21012	0.22284
07/28/2025 10:00	0.21420	0.22716
07/28/2025 11:00	0.21012	0.22218
07/28/2025 12:00	0.25650	0.27012
07/28/2025 13:00	0.25758	0.27090
07/28/2025 14:00	0.25752	0.27108
07/28/2025 15:00	0.22680	0.23940
07/28/2025 16:00	0.22266	0.23496
07/28/2025 17:00	0.24378	0.25722
07/28/2025 18:00	0.25626	0.27048
07/28/2025 19:00	0.21876	0.23196
07/28/2025 20:00	0.20886	0.22140
07/28/2025 21:00	0.21192	0.22482
07/28/2025 22:00	0.21084	0.22362
07/28/2025 23:00	0.25290	0.26748
Average/Sum#:	0.22289	0.23577
Minimum:	0.20886	0.22140
Maximum:	0.25758	0.27108
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/29/2025 00:00	0.22224	0.23562
07/29/2025 01:00	0.21744	0.23058
07/29/2025 02:00	0.23292	0.24690
07/29/2025 03:00	0.21702	0.23016
07/29/2025 04:00	0.23874	0.25314
07/29/2025 05:00	0.23706	0.25140
07/29/2025 06:00	0.21180	0.22446
07/29/2025 07:00	0.21606	0.22878
07/29/2025 08:00	0.21024	0.22284
07/29/2025 09:00	0.23922	0.25416
07/29/2025 10:00	0.25512	0.27024
07/29/2025 11:00	0.25404	0.26772
07/29/2025 12:00	0.25704	0.27036
07/29/2025 13:00	0.25752	0.27084
07/29/2025 14:00	0.25632	0.26958
07/29/2025 15:00	0.22278	0.23520
07/29/2025 16:00	0.21444	0.22668
07/29/2025 17:00	0.22284	0.23598
07/29/2025 18:00	0.24996	0.26376
07/29/2025 19:00	0.21072	0.22356
07/29/2025 20:00	0.20928	0.22206
07/29/2025 21:00	0.22458	0.23844
07/29/2025 22:00	0.20976	0.22254
07/29/2025 23:00	0.23076	0.24456
Average/Sum#:	0.22991	0.24332
Minimum:	0.20928	0.22206
Maximum:	0.25752	0.27084
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/30/2025 00:00	0.20994	0.22254
07/30/2025 01:00	0.21024	0.22248
07/30/2025 02:00	0.21036	0.22266
07/30/2025 03:00	0.21042	0.22278
07/30/2025 04:00	0.22206	0.23544
07/30/2025 05:00	0.22134	0.23412
07/30/2025 06:00	0.21048	0.22284
07/30/2025 07:00	0.21072	0.22266
07/30/2025 08:00	0.21012	0.22224
07/30/2025 09:00	0.20964	0.22194
07/30/2025 10:00	0.20922	0.22164
07/30/2025 11:00	0.20958	0.22128
07/30/2025 12:00	0.20964	0.22116
07/30/2025 13:00	0.20952	0.22122
07/30/2025 14:00	0.20928	0.22092
07/30/2025 15:00	0.20880	0.22080
07/30/2025 16:00	0.20970	0.22164
07/30/2025 17:00	0.21702	0.22974
07/30/2025 18:00	0.21300	0.22518
07/30/2025 19:00	0.21120	0.22404
07/30/2025 20:00	0.20922	0.22206
07/30/2025 21:00	0.20952	0.22236
07/30/2025 22:00	0.20982	0.22248
07/30/2025 23:00	0.20994	0.22260
Average/Sum#:	0.21128	0.22362
Minimum:	0.20880	0.22080
Maximum:	0.22206	0.23544
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
07/31/2025 00:00	0.21000	0.22272
07/31/2025 01:00	0.21018	0.22266
07/31/2025 02:00	0.21024	0.22278
07/31/2025 03:00	0.21036	0.22290
07/31/2025 04:00	0.21054	0.22296
07/31/2025 05:00	0.21048	0.22302
07/31/2025 06:00	0.21036	0.22302
07/31/2025 07:00	0.21054	0.22284
07/31/2025 08:00	0.21024	0.22290
07/31/2025 09:00	0.20982	0.22242
07/31/2025 10:00	0.20940	0.22206
07/31/2025 11:00	0.20958	0.22170
07/31/2025 12:00	0.21210	0.22368
07/31/2025 13:00	0.23046	0.24342
07/31/2025 14:00	0.24426	0.25830
07/31/2025 15:00	0.25476	0.26958
07/31/2025 16:00	0.20880	0.22062
07/31/2025 17:00	0.22284	0.23544
07/31/2025 18:00	0.24138	0.25512
07/31/2025 19:00	0.22014	0.23334
07/31/2025 20:00	0.23748	0.25362
07/31/2025 21:00	0.24912	0.26556
07/31/2025 22:00	0.25560	0.27114
07/31/2025 23:00	0.21168	0.22452
Average/Sum#:	0.22127	0.23443
Minimum:	0.20880	0.22062
Maximum:	0.25560	0.27114
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/01/2025 00:00	0.20970	0.22242
08/01/2025 01:00	0.21018	0.22278
08/01/2025 02:00	0.21042	0.22290
08/01/2025 03:00	0.21072	0.22308
08/01/2025 04:00	0.21282	0.22518
08/01/2025 05:00	0.21432	0.22668
08/01/2025 06:00	0.21048	0.22290
08/01/2025 07:00	0.21060	0.22284
08/01/2025 08:00	0.21024	0.22266
08/01/2025 09:00	0.20988	0.22236
08/01/2025 10:00	0.20952	0.22188
08/01/2025 11:00	0.20982	0.22170
08/01/2025 12:00	0.20982	0.22140
08/01/2025 13:00	0.22596	0.23958
08/01/2025 14:00	0.24924	0.26292
08/01/2025 15:00	0.21294	0.22440
08/01/2025 16:00	0.20910	0.22038
08/01/2025 17:00	0.22368	0.23682
08/01/2025 18:00	0.24342	0.25734
08/01/2025 19:00	0.20994	0.22290
08/01/2025 20:00	0.20970	0.22242
08/01/2025 21:00	0.22236	0.23610
08/01/2025 22:00	0.21984	0.23322
08/01/2025 23:00	0.23460	0.24852
Average/Sum#:	0.21664	0.22931
Minimum:	0.20910	0.22038
Maximum:	0.24924	0.26292
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 **To:** 09/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/02/2025 00:00	0.21072	0.22338
08/02/2025 01:00	0.23454	0.24852
08/02/2025 02:00	0.21882	0.23160
08/02/2025 03:00	0.21876	0.23172
08/02/2025 04:00	0.21906	0.23166
08/02/2025 05:00	0.21894	0.23190
08/02/2025 06:00	0.22026	0.23322
08/02/2025 07:00	0.21906	0.23148
08/02/2025 08:00	0.21852	0.23136
08/02/2025 09:00	0.21816	0.23106
08/02/2025 10:00	0.21774	0.23070
08/02/2025 11:00	0.21780	0.23022
08/02/2025 12:00	0.21786	0.22998
08/02/2025 13:00	0.21792	0.22968
08/02/2025 14:00	0.21774	0.22944
08/02/2025 15:00	0.21708	0.22944
08/02/2025 16:00	0.21684	0.22896
08/02/2025 17:00	0.22128	0.23448
08/02/2025 18:00	0.21696	0.22908
08/02/2025 19:00	0.21654	0.22974
08/02/2025 20:00	0.21672	0.22998
08/02/2025 21:00	0.21678	0.23016
08/02/2025 22:00	0.21702	0.23046
08/02/2025 23:00	0.21738	0.23076
Average/Sum#:	0.21844	0.23121
Minimum:	0.21072	0.22338
Maximum:	0.23454	0.24852
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/03/2025 00:00	0.21756	0.23058
08/03/2025 01:00	0.21786	0.23094
08/03/2025 02:00	0.21792	0.23124
08/03/2025 03:00	0.21822	0.23112
08/03/2025 04:00	0.21834	0.23112
08/03/2025 05:00	0.21822	0.23136
08/03/2025 06:00	0.21810	0.23112
08/03/2025 07:00	0.21804	0.23088
08/03/2025 08:00	0.21744	0.23076
08/03/2025 09:00	0.21714	0.23040
08/03/2025 10:00	0.21690	0.22992
08/03/2025 11:00	0.21744	0.22986
08/03/2025 12:00	0.21756	0.22956
08/03/2025 13:00	0.21744	0.22920
08/03/2025 14:00	0.21726	0.22902
08/03/2025 15:00	0.21672	0.22908
08/03/2025 16:00	0.21654	0.22884
08/03/2025 17:00	0.23196	0.24540
08/03/2025 18:00	0.21852	0.23112
08/03/2025 19:00	0.21636	0.22986
08/03/2025 20:00	0.21672	0.23010
08/03/2025 21:00	0.21696	0.23046
08/03/2025 22:00	0.21720	0.23040
08/03/2025 23:00	0.21732	0.23052
Average/Sum#:	0.21807	0.23095
Minimum:	0.21636	0.22884
Maximum:	0.23196	0.24540
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/04/2025 00:00	0.21732	0.23046
08/04/2025 01:00	0.21744	0.23040
08/04/2025 02:00	0.21762	0.23088
08/04/2025 03:00	0.21774	0.23076
08/04/2025 04:00	0.21786	0.23076
08/04/2025 05:00	0.21804	0.23124
08/04/2025 06:00	0.26220	0.27774
08/04/2025 07:00	0.22272	0.23586
08/04/2025 08:00	0.21696	0.23022
08/04/2025 09:00	0.21690	0.23010
08/04/2025 10:00	0.21678	0.22992
08/04/2025 11:00	0.21720	0.22956
08/04/2025 12:00	0.21726	0.22944
08/04/2025 13:00	0.21738	0.22926
08/04/2025 14:00	0.21768	0.22962
08/04/2025 15:00	0.21696	0.22920
08/04/2025 16:00	0.21648	0.22884
08/04/2025 17:00	0.22746	0.24222
08/04/2025 18:00	0.21792	0.23052
08/04/2025 19:00	0.21654	0.22962
08/04/2025 20:00	0.21672	0.22992
08/04/2025 21:00	0.21684	0.23010
08/04/2025 22:00	0.21714	0.23046
08/04/2025 23:00	0.21738	0.23034
Average/Sum#:	0.21977	0.23281
Minimum:	0.21648	0.22884
Maximum:	0.26220	0.27774
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/05/2025 00:00	0.21756	0.23058
08/05/2025 01:00	0.21762	0.23070
08/05/2025 02:00	0.21774	0.23064
08/05/2025 03:00	0.21780	0.23088
08/05/2025 04:00	0.21798	0.23106
08/05/2025 05:00	0.24090	0.25536
08/05/2025 06:00	0.23082	0.24492
08/05/2025 07:00	0.21810	0.23094
08/05/2025 08:00	0.21720	0.23058
08/05/2025 09:00	0.21702	0.23016
08/05/2025 10:00	0.21684	0.23004
08/05/2025 11:00	0.21738	0.22986
08/05/2025 12:00	0.21750	0.22974
08/05/2025 13:00	0.21756	0.22944
08/05/2025 14:00	0.21744	0.22932
08/05/2025 15:00	0.21696	0.22920
08/05/2025 16:00	0.22440	0.23700
08/05/2025 17:00	0.23478	0.24792
08/05/2025 18:00	0.26490	0.27996
08/05/2025 19:00	0.25578	0.27138
08/05/2025 20:00	0.25674	0.27246
08/05/2025 21:00	0.26448	0.28026
08/05/2025 22:00	0.25272	0.26808
08/05/2025 23:00	0.21684	0.22998
Average/Sum#:	0.22863	0.24210
Minimum:	0.21684	0.22920
Maximum:	0.26490	0.28026
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/06/2025 00:00	0.21720	0.23034
08/06/2025 01:00	0.21720	0.23040
08/06/2025 02:00	0.21756	0.23046
08/06/2025 03:00	0.21756	0.23040
08/06/2025 04:00	0.21768	0.23040
08/06/2025 05:00	0.23262	0.24648
08/06/2025 06:00	0.25986	0.27516
08/06/2025 07:00	0.22470	0.23766
08/06/2025 08:00	0.21708	0.23004
08/06/2025 09:00	0.21684	0.22998
08/06/2025 10:00	0.21672	0.22956
08/06/2025 11:00	0.21726	0.22908
08/06/2025 12:00	0.21744	0.22908
08/06/2025 13:00	0.21726	0.22908
08/06/2025 14:00	0.21660	0.22908
08/06/2025 15:00	0.21684	0.22872
08/06/2025 16:00	0.21858	0.23100
08/06/2025 17:00	0.22980	0.24246
08/06/2025 18:00	0.25068	0.26496
08/06/2025 19:00	0.22470	0.23820
08/06/2025 20:00	0.21978	0.23322
08/06/2025 21:00	0.23010	0.24402
08/06/2025 22:00	0.23352	0.24786
08/06/2025 23:00	0.25578	0.27120
Average/Sum#:	0.22514	0.23829
Minimum:	0.21660	0.22872
Maximum:	0.25986	0.27516
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/07/2025 00:00	0.23724	0.25170
08/07/2025 01:00	0.23028	0.24420
08/07/2025 02:00	0.21780	0.23100
08/07/2025 03:00	0.21798	0.23100
08/07/2025 04:00	0.22488	0.23844
08/07/2025 05:00	0.23646	0.25044
08/07/2025 06:00	0.21816	0.23124
08/07/2025 07:00	0.21858	0.23100
08/07/2025 08:00	0.21828	0.23094
08/07/2025 09:00	0.21798	0.23082
08/07/2025 10:00	0.21804	0.23064
08/07/2025 11:00	0.21858	0.23046
08/07/2025 12:00	0.21858	0.23040
08/07/2025 13:00	0.21882	0.23016
08/07/2025 14:00	0.23484	0.24726
08/07/2025 15:00	0.23100	0.24372
08/07/2025 16:00	0.21714	0.22944
08/07/2025 17:00	0.22626	0.23940
08/07/2025 18:00	0.24498	0.25920
08/07/2025 19:00	0.22974	0.24378
08/07/2025 20:00	0.22230	0.23640
08/07/2025 21:00	0.21612	0.22938
08/07/2025 22:00	0.21624	0.22932
08/07/2025 23:00	0.21636	0.22950
Average/Sum#:	0.22361	0.23666
Minimum:	0.21612	0.22932
Maximum:	0.24498	0.25920
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 **To:** 09/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/08/2025 00:00	0.21654	0.22974
08/08/2025 01:00	0.21666	0.22986
08/08/2025 02:00	0.21672	0.22992
08/08/2025 03:00	0.21684	0.22992
08/08/2025 04:00	0.21738	0.23040
08/08/2025 05:00	0.23070	0.24444
08/08/2025 06:00	0.21738	0.23034
08/08/2025 07:00	0.21744	0.23004
08/08/2025 08:00	0.21672	0.22974
08/08/2025 09:00	0.21618	0.22920
08/08/2025 10:00	0.21600	0.22908
08/08/2025 11:00	0.21678	0.22890
08/08/2025 12:00	0.21678	0.22842
08/08/2025 13:00	0.22182	0.23310
08/08/2025 14:00	0.22284	0.23418
08/08/2025 15:00	0.21822	0.22986
08/08/2025 16:00	0.23382	0.24720
08/08/2025 17:00	0.23544	0.24954
08/08/2025 18:00	0.21900	0.23142
08/08/2025 19:00	0.21732	0.23076
08/08/2025 20:00	0.22416	0.23904
08/08/2025 21:00	0.21786	0.23076
08/08/2025 22:00	0.21672	0.22956
08/08/2025 23:00	0.21612	0.22908
Average/Sum#:	0.21981	0.23269
Minimum:	0.21600	0.22842
Maximum:	0.23544	0.24954
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/09/2025 00:00	0.21606	0.22938
08/09/2025 01:00	0.21618	0.22944
08/09/2025 02:00	0.21630	0.22956
08/09/2025 03:00	0.21636	0.22962
08/09/2025 04:00	0.21666	0.22974
08/09/2025 05:00	0.21660	0.22998
08/09/2025 06:00	0.21648	0.22980
08/09/2025 07:00	0.21672	0.22944
08/09/2025 08:00	0.21606	0.22920
08/09/2025 09:00	0.21570	0.22890
08/09/2025 10:00	0.21570	0.22872
08/09/2025 11:00	0.21636	0.22854
08/09/2025 12:00	0.21648	0.22788
08/09/2025 13:00	0.21672	0.22752
08/09/2025 14:00	0.21864	0.23040
08/09/2025 15:00	0.21624	0.22728
08/09/2025 16:00	0.22992	0.24456
08/09/2025 17:00	0.21786	0.23022
08/09/2025 18:00	0.21588	0.22758
08/09/2025 19:00	0.23274	0.24810
08/09/2025 20:00	0.21744	0.23046
08/09/2025 21:00	0.21540	0.22860
08/09/2025 22:00	0.21534	0.22884
08/09/2025 23:00	0.21570	0.22890
Average/Sum#:	0.21765	0.23053
Minimum:	0.21534	0.22728
Maximum:	0.23274	0.24810
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/10/2025 00:00	0.21582	0.22908
08/10/2025 01:00	0.21600	0.22914
08/10/2025 02:00	0.21612	0.22938
08/10/2025 03:00	0.21642	0.22944
08/10/2025 04:00	0.21678	0.22968
08/10/2025 05:00	0.21684	0.22986
08/10/2025 06:00	0.21678	0.22986
08/10/2025 07:00	0.21678	0.22944
08/10/2025 08:00	0.21594	0.22902
08/10/2025 09:00	0.21558	0.22878
08/10/2025 10:00	0.21546	0.22848
08/10/2025 11:00	0.21624	0.22824
08/10/2025 12:00	0.21636	0.22752
08/10/2025 13:00	0.24204	0.25794
08/10/2025 14:00	0.25950	0.27918
08/10/2025 15:00	0.23436	0.25020
08/10/2025 16:00	0.23658	0.25350
08/10/2025 17:00	0.23748	0.25350
08/10/2025 18:00	0.26274	0.28074
08/10/2025 19:00	0.23694	0.25080
08/10/2025 20:00	0.22260	0.23616
08/10/2025 21:00	0.22992	0.24390
08/10/2025 22:00	0.21732	0.23058
08/10/2025 23:00	0.21702	0.23046
Average/Sum#:	0.22532	0.23937
Minimum:	0.21546	0.22752
Maximum:	0.26274	0.28074
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/11/2025 00:00	0.21570	0.22914
08/11/2025 01:00	0.21576	0.22896
08/11/2025 02:00	0.21582	0.22884
08/11/2025 03:00	0.21594	0.22902
08/11/2025 04:00	0.23088	0.24480
08/11/2025 05:00	0.24594	0.26064
08/11/2025 06:00	0.21624	0.22926
08/11/2025 07:00	0.21642	0.22920
08/11/2025 08:00	0.21582	0.22878
08/11/2025 09:00	0.21540	0.22854
08/11/2025 10:00	0.21516	0.22806
08/11/2025 11:00	0.21564	0.22782
08/11/2025 12:00	0.21564	0.22758
08/11/2025 13:00	0.22062	0.23310
08/11/2025 14:00	0.23466	0.24792
08/11/2025 15:00	0.21696	0.22848
08/11/2025 16:00	0.22950	0.24180
08/11/2025 17:00	0.24300	0.25596
08/11/2025 18:00	0.26136	0.27570
08/11/2025 19:00	0.25212	0.26730
08/11/2025 20:00	0.25950	0.27504
08/11/2025 21:00	0.25878	0.27474
08/11/2025 22:00	0.24504	0.26004
08/11/2025 23:00	0.24042	0.25500
Average/Sum#:	0.22968	0.24316
Minimum:	0.21516	0.22758
Maximum:	0.26136	0.27570
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 **To:** 09/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/12/2025 00:00	0.24630	0.26130
08/12/2025 01:00	0.24030	0.25488
08/12/2025 02:00	0.22020	0.23352
08/12/2025 03:00	0.22632	0.24000
08/12/2025 04:00	0.24756	0.26268
08/12/2025 05:00	0.25854	0.27450
08/12/2025 06:00	0.22578	0.23928
08/12/2025 07:00	0.21846	0.23082
08/12/2025 08:00	0.21774	0.23040
08/12/2025 09:00	0.21708	0.23016
08/12/2025 10:00	0.21672	0.22968
08/12/2025 11:00	0.21702	0.22950
08/12/2025 12:00	0.21684	0.22890
08/12/2025 13:00	0.22680	0.23964
08/12/2025 14:00	0.24720	0.26274
08/12/2025 15:00	0.24486	0.25974
08/12/2025 16:00	0.24858	0.26640
08/12/2025 17:00	0.26328	0.28374
08/12/2025 18:00	0.26082	0.27810
08/12/2025 19:00	0.26070	0.27612
08/12/2025 20:00	0.24498	0.26058
08/12/2025 21:00	0.23640	0.25098
08/12/2025 22:00	0.23862	0.25296
08/12/2025 23:00	0.21762	0.23088
Average/Sum#:	0.23578	0.25031
Minimum:	0.21672	0.22890
Maximum:	0.26328	0.28374
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/13/2025 00:00	0.21810	0.23130
08/13/2025 01:00	0.21822	0.23136
08/13/2025 02:00	0.21834	0.23136
08/13/2025 03:00	0.21828	0.23148
08/13/2025 04:00	0.21846	0.23136
08/13/2025 05:00	0.21858	0.23148
08/13/2025 06:00	0.21870	0.23160
08/13/2025 07:00	0.21876	0.23154
08/13/2025 08:00	0.21858	0.23136
08/13/2025 09:00	0.21810	0.23124
08/13/2025 10:00	0.21792	0.23094
08/13/2025 11:00	0.21828	0.23082
08/13/2025 12:00	0.21810	0.23028
08/13/2025 13:00	0.21762	0.22968
08/13/2025 14:00	0.21702	0.22908
08/13/2025 15:00	0.21684	0.22902
08/13/2025 16:00	0.21630	0.22902
08/13/2025 17:00	0.22488	0.23814
08/13/2025 18:00	0.21654	0.22938
08/13/2025 19:00	0.21606	0.22950
08/13/2025 20:00	0.21624	0.22968
08/13/2025 21:00	0.21618	0.22962
08/13/2025 22:00	0.21672	0.23004
08/13/2025 23:00	0.21732	0.23064
Average/Sum#:	0.21792	0.23083
Minimum:	0.21606	0.22902
Maximum:	0.22488	0.23814
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/14/2025 00:00	0.21768	0.23082
08/14/2025 01:00	0.21780	0.23106
08/14/2025 02:00	0.21792	0.23094
08/14/2025 03:00	0.21810	0.23118
08/14/2025 04:00	0.21858	0.23148
08/14/2025 05:00	0.21888	0.23166
08/14/2025 06:00	0.21894	0.23178
08/14/2025 07:00	0.21876	0.23160
08/14/2025 08:00	0.21852	0.23166
08/14/2025 09:00	0.21786	0.23100
08/14/2025 10:00	0.21738	0.23052
08/14/2025 11:00	0.21738	0.23004
08/14/2025 12:00	0.21732	0.22962
08/14/2025 13:00	0.21750	0.22944
08/14/2025 14:00	0.21744	0.22932
08/14/2025 15:00	0.21684	0.22914
08/14/2025 16:00	0.21606	0.22884
08/14/2025 17:00	0.22098	0.23442
08/14/2025 18:00	0.21636	0.22866
08/14/2025 19:00	0.21594	0.22926
08/14/2025 20:00	0.21606	0.22956
08/14/2025 21:00	0.21654	0.22992
08/14/2025 22:00	0.21642	0.22992
08/14/2025 23:00	0.21654	0.22968
Average/Sum#:	0.21758	0.23048
Minimum:	0.21594	0.22866
Maximum:	0.22098	0.23442
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 **To:** 09/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)
08/15/2025 00:00	0.21654	0.22986
08/15/2025 01:00	0.21684	0.22986
08/15/2025 02:00	0.21690	0.22998
08/15/2025 03:00	0.21726	0.23022
08/15/2025 04:00	0.21774	0.23040
08/15/2025 05:00	0.22062	0.23382
08/15/2025 06:00	0.22578	0.23910
08/15/2025 07:00	0.21750	0.23040
08/15/2025 08:00	0.21702	0.23022
08/15/2025 09:00	0.21666	0.22980
08/15/2025 10:00	0.21636	0.22968
08/15/2025 11:00	0.21660	0.22908
08/15/2025 12:00	0.21660	0.22878
08/15/2025 13:00	0.21660	0.22848
08/15/2025 14:00	0.21654	0.22818
08/15/2025 15:00	0.21648	0.22812
08/15/2025 16:00	0.21624	0.22836
08/15/2025 17:00	0.21678	0.22872
08/15/2025 18:00	0.21660	0.22914
08/15/2025 19:00	0.21666	0.23022
08/15/2025 20:00	0.21696	0.23052
08/15/2025 21:00	0.21720	0.23076
08/15/2025 22:00	0.21750	0.23100
08/15/2025 23:00	0.22446	0.23832
Average/Sum#:	0.21769	0.23054
Minimum:	0.21624	0.22812
Maximum:	0.22578	0.23910
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/16/2025 00:00	0.25632	0.27150
08/16/2025 01:00	0.21786	0.23136
08/16/2025 02:00	0.21822	0.23154
08/16/2025 03:00	0.21834	0.23154
08/16/2025 04:00	0.21840	0.23154
08/16/2025 05:00	0.21840	0.23160
08/16/2025 06:00	0.21864	0.23172
08/16/2025 07:00	0.21870	0.23154
08/16/2025 08:00	0.21810	0.23148
08/16/2025 09:00	0.21786	0.23118
08/16/2025 10:00	0.21762	0.23088
08/16/2025 11:00	0.21804	0.23064
08/16/2025 12:00	0.21804	0.23052
08/16/2025 13:00	0.21822	0.23046
08/16/2025 14:00	0.23160	0.24528
08/16/2025 15:00	0.21804	0.23046
08/16/2025 16:00	0.21738	0.23028
08/16/2025 17:00	0.22260	0.23556
08/16/2025 18:00	0.21948	0.23280
08/16/2025 19:00	0.23016	0.24504
08/16/2025 20:00	0.21696	0.23028
08/16/2025 21:00	0.21810	0.23154
08/16/2025 22:00	0.21858	0.23226
08/16/2025 23:00	0.25224	0.26730
Average/Sum#:	0.22241	0.23576
Minimum:	0.21696	0.23028
Maximum:	0.25632	0.27150
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/17/2025 00:00	0.21642	0.22968
08/17/2025 01:00	0.21666	0.22992
08/17/2025 02:00	0.21654	0.22974
08/17/2025 03:00	0.21660	0.22980
08/17/2025 04:00	0.21678	0.22986
08/17/2025 05:00	0.21708	0.23010
08/17/2025 06:00	0.21732	0.23034
08/17/2025 07:00	0.21738	0.23022
08/17/2025 08:00	0.21684	0.22998
08/17/2025 09:00	0.21672	0.22986
08/17/2025 10:00	0.21696	0.23010
08/17/2025 11:00	0.21762	0.23028
08/17/2025 12:00	0.21768	0.23010
08/17/2025 13:00	0.21792	0.23010
08/17/2025 14:00	0.21780	0.22998
08/17/2025 15:00	0.21762	0.22980
08/17/2025 16:00	0.22518	0.23844
08/17/2025 17:00	0.24702	0.26436
08/17/2025 18:00	0.26586	0.28230
08/17/2025 19:00	0.26592	0.28230
08/17/2025 20:00	0.26544	0.28188
08/17/2025 21:00	0.26520	0.28194
08/17/2025 22:00	0.26502	0.28170
08/17/2025 23:00	0.25998	0.27684
Average/Sum#:	0.23057	0.24457
Minimum:	0.21642	0.22968
Maximum:	0.26592	0.28230
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/18/2025 00:00	0.21798	0.23208
08/18/2025 01:00	0.21810	0.23196
08/18/2025 02:00	0.21816	0.23208
08/18/2025 03:00	0.21810	0.23208
08/18/2025 04:00	0.22788	0.24258
08/18/2025 05:00	0.25212	0.26832
08/18/2025 06:00	0.21870	0.23220
08/18/2025 07:00	0.21882	0.23214
08/18/2025 08:00	0.21828	0.23208
08/18/2025 09:00	0.21810	0.23190
08/18/2025 10:00	0.21804	0.23160
08/18/2025 11:00	0.26196	0.27744
08/18/2025 12:00	0.26406	0.27924
08/18/2025 13:00	0.26664	0.28152
08/18/2025 14:00	0.26754	0.28218
08/18/2025 15:00	0.26802	0.28332
08/18/2025 16:00	0.24000	0.25500
08/18/2025 17:00	0.24258	0.25650
08/18/2025 18:00	0.26820	0.28368
08/18/2025 19:00	0.26700	0.28326
08/18/2025 20:00	0.26616	0.28248
08/18/2025 21:00	0.25824	0.27420
08/18/2025 22:00	0.24252	0.25800
08/18/2025 23:00	0.22398	0.23856
Average/Sum#:	0.24088	0.25560
Minimum:	0.21798	0.23160
Maximum:	0.26820	0.28368
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/19/2025 00:00	0.21750	0.23172
08/19/2025 01:00	0.21768	0.23202
08/19/2025 02:00	0.21780	0.23208
08/19/2025 03:00	0.21786	0.23196
08/19/2025 04:00	0.23160	0.24624
08/19/2025 05:00	0.23370	0.24870
08/19/2025 06:00	0.22734	0.24144
08/19/2025 07:00	0.21870	0.23220
08/19/2025 08:00	0.21822	0.23184
08/19/2025 09:00	0.21780	0.23160
08/19/2025 10:00	0.21756	0.23136
08/19/2025 11:00	0.22824	0.24162
08/19/2025 12:00	0.26778	0.28242
08/19/2025 13:00	0.26766	0.28200
08/19/2025 14:00	0.26730	0.28128
08/19/2025 15:00	0.26670	0.28116
08/19/2025 16:00	0.25836	0.27330
08/19/2025 17:00	0.24276	0.25662
08/19/2025 18:00	0.26658	0.28176
08/19/2025 19:00	0.26526	0.28152
08/19/2025 20:00	0.26568	0.28218
08/19/2025 21:00	0.26556	0.28230
08/19/2025 22:00	0.26160	0.27834
08/19/2025 23:00	0.24708	0.26292
Average/Sum#:	0.24193	0.25661
Minimum:	0.21750	0.23136
Maximum:	0.26778	0.28242
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/20/2025 00:00	0.22164	0.23604
08/20/2025 01:00	0.21876	0.23268
08/20/2025 02:00	0.21852	0.23226
08/20/2025 03:00	0.21834	0.23220
08/20/2025 04:00	0.22122	0.23532
08/20/2025 05:00	0.23958	0.25476
08/20/2025 06:00	0.25488	0.27072
08/20/2025 07:00	0.25026	0.26580
08/20/2025 08:00	0.26712	0.28392
08/20/2025 09:00	0.26622	0.28416
08/20/2025 10:00	0.26322	0.28560
08/20/2025 11:00	0.26724	0.28314
08/20/2025 12:00	0.26706	0.28122
08/20/2025 13:00	0.27078	0.28974
08/20/2025 14:00	0.36144	0.38724
08/20/2025 15:00	0.32496	0.35148
08/20/2025 16:00	0.30714	0.33456
08/20/2025 17:00	0.32112	0.34800
08/20/2025 18:00	0.35244	0.37938
08/20/2025 19:00	0.30456	0.33300
08/20/2025 20:00	0.30324	0.33198
08/20/2025 21:00	0.30270	0.33120
08/20/2025 22:00	0.26658	0.28320
08/20/2025 23:00	0.26250	0.27816
Average/Sum#:	0.27298	0.29274
Minimum:	0.21834	0.23220
Maximum:	0.36144	0.38724
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/21/2025 00:00	0.26106	0.27858
08/21/2025 01:00	0.25518	0.27210
08/21/2025 02:00	0.26442	0.28146
08/21/2025 03:00	0.26796	0.28770
08/21/2025 04:00	0.33864	0.36546
08/21/2025 05:00	0.35958	0.38418
08/21/2025 06:00	0.30066	0.32412
08/21/2025 07:00	0.21882	0.23244
08/21/2025 08:00	0.21684	0.23058
08/21/2025 09:00	0.21666	0.22992
08/21/2025 10:00	0.21894	0.23220
08/21/2025 11:00	0.24816	0.26226
08/21/2025 12:00	0.29976	0.32526
08/21/2025 13:00	0.37356	0.39984
08/21/2025 14:00	0.37722	0.40344
08/21/2025 15:00	0.36396	0.39168
08/21/2025 16:00	0.33984	0.36768
08/21/2025 17:00	0.33720	0.36510
08/21/2025 18:00	0.38052	0.40776
08/21/2025 19:00	0.35220	0.38154
08/21/2025 20:00	0.36252	0.39066
08/21/2025 21:00	0.34290	0.37284
08/21/2025 22:00	0.31680	0.34704
08/21/2025 23:00	0.32652	0.35544
Average/Sum#:	0.30583	0.32872
Minimum:	0.21666	0.22992
Maximum:	0.38052	0.40776
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/22/2025 00:00	0.30264	0.33090
08/22/2025 01:00	0.26418	0.28962
08/22/2025 02:00	0.21792	0.23088
08/22/2025 03:00	0.21804	0.23106
08/22/2025 04:00	0.24942	0.26772
08/22/2025 05:00	0.30192	0.32838
08/22/2025 06:00	0.26274	0.29436
08/22/2025 07:00	0.21816	0.23064
08/22/2025 08:00	0.21726	0.23022
08/22/2025 09:00	0.21654	0.22950
08/22/2025 10:00	0.21624	0.22944
08/22/2025 11:00	0.23982	0.25440
08/22/2025 12:00	0.24180	0.25824
08/22/2025 13:00	0.26586	0.29250
08/22/2025 14:00	0.37320	0.39888
08/22/2025 15:00	0.36246	0.38886
08/22/2025 16:00	0.37836	0.40620
08/22/2025 17:00	0.38184	0.40962
08/22/2025 18:00	0.36210	0.39006
08/22/2025 19:00	0.35574	0.38448
08/22/2025 20:00	0.37704	0.40548
08/22/2025 21:00	0.38364	0.41262
08/22/2025 22:00	0.37692	0.40284
08/22/2025 23:00	0.35280	0.37626
Average/Sum#:	0.29736	0.31972
Minimum:	0.21624	0.22944
Maximum:	0.38364	0.41262
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/23/2025 00:00	0.30822	0.33450
08/23/2025 01:00	0.30666	0.33300
08/23/2025 02:00	0.30570	0.33258
08/23/2025 03:00	0.30504	0.33156
08/23/2025 04:00	0.30336	0.32946
08/23/2025 05:00	0.33294	0.35844
08/23/2025 06:00	0.24480	0.26334
08/23/2025 07:00	0.21756	0.23004
08/23/2025 08:00	0.21696	0.22998
08/23/2025 09:00	0.24672	0.26532
08/23/2025 10:00	0.30252	0.33048
08/23/2025 11:00	0.24408	0.26262
08/23/2025 12:00	0.30990	0.33786
08/23/2025 13:00	0.37740	0.40320
08/23/2025 14:00	0.38526	0.40998
08/23/2025 15:00	0.37248	0.40020
08/23/2025 16:00	0.37812	0.40560
08/23/2025 17:00	0.34566	0.37380
08/23/2025 18:00	0.33750	0.36576
08/23/2025 19:00	0.31092	0.34014
08/23/2025 20:00	0.31086	0.34128
08/23/2025 21:00	0.34488	0.37422
08/23/2025 22:00	0.35460	0.38358
08/23/2025 23:00	0.35646	0.38496
Average/Sum#:	0.31328	0.33841
Minimum:	0.21696	0.22998
Maximum:	0.38526	0.40998
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/24/2025 00:00	0.30450	0.33228
08/24/2025 01:00	0.29952	0.32706
08/24/2025 02:00	0.30108	0.32886
08/24/2025 03:00	0.30162	0.32868
08/24/2025 04:00	0.23220	0.24990
08/24/2025 05:00	0.24708	0.26610
08/24/2025 06:00	0.22572	0.24216
08/24/2025 07:00	0.21804	0.23352
08/24/2025 08:00	0.21756	0.23352
08/24/2025 09:00	0.21720	0.23316
08/24/2025 10:00	0.21684	0.23334
08/24/2025 11:00	0.21702	0.23334
08/24/2025 12:00	0.22308	0.24030
08/24/2025 13:00	0.23820	0.25962
08/24/2025 14:00	0.26232	0.28500
08/24/2025 15:00	0.32190	0.34824
08/24/2025 16:00	0.34794	0.37386
08/24/2025 17:00	0.33570	0.36192
08/24/2025 18:00	0.33690	0.36348
08/24/2025 19:00	0.35202	0.37932
08/24/2025 20:00	0.31434	0.34158
08/24/2025 21:00	0.30252	0.33000
08/24/2025 22:00	0.30504	0.33126
08/24/2025 23:00	0.30570	0.33240
Average/Sum#:	0.27684	0.29954
Minimum:	0.21684	0.23316
Maximum:	0.35202	0.37932
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/25/2025 00:00	0.30216	0.32886
08/25/2025 01:00	0.30180	0.32868
08/25/2025 02:00	0.30180	0.32856
08/25/2025 03:00	0.30114	0.32808
08/25/2025 04:00	0.30324	0.33042
08/25/2025 05:00	0.31884	0.34554
08/25/2025 06:00	0.34008	0.36606
08/25/2025 07:00	0.24618	0.26550
08/25/2025 08:00	0.21810	0.23112
08/25/2025 09:00	0.23034	0.24444
08/25/2025 10:00	0.25572	0.27678
08/25/2025 11:00	0.22434	0.23898
08/25/2025 12:00	0.26586	0.28824
08/25/2025 13:00	0.34032	0.36732
08/25/2025 14:00	0.31440	0.34110
08/25/2025 15:00	0.32004	0.34632
08/25/2025 16:00	0.32460	0.35130
08/25/2025 17:00	0.37104	0.39702
08/25/2025 18:00	0.37434	0.40110
08/25/2025 19:00	0.31398	0.34176
08/25/2025 20:00	0.32376	0.35160
08/25/2025 21:00	0.30372	0.33210
08/25/2025 22:00	0.30378	0.33078
08/25/2025 23:00	0.30840	0.33498
Average/Sum#:	0.30033	0.32486
Minimum:	0.21810	0.23112
Maximum:	0.37434	0.40110
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/26/2025 00:00	0.30690	0.33276
08/26/2025 01:00	0.30420	0.33018
08/26/2025 02:00	0.30294	0.32802
08/26/2025 03:00	0.30852	0.33228
08/26/2025 04:00	0.31830	0.34380
08/26/2025 05:00	0.36192	0.38856
08/26/2025 06:00	0.33570	0.41160
08/26/2025 07:00	0.31860	0.34680
08/26/2025 08:00	0.30288	0.32964
08/26/2025 09:00	0.29268	0.31728
08/26/2025 10:00	0.00000	0.00000
08/26/2025 11:00	0.00000	0.00000
08/26/2025 12:00	0.00000	0.23178
08/26/2025 13:00	0.00000	0.24702
08/26/2025 14:00	0.00000	0.23772
08/26/2025 15:00	0.00000	0.27726
08/26/2025 16:00	0.00000	0.28866
08/26/2025 17:00	0.03774	0.28938
08/26/2025 18:00	0.03684	0.34848
08/26/2025 19:00	0.00000	0.41448
08/26/2025 20:00	0.00000	0.41328
08/26/2025 21:00	0.00000	0.41280
08/26/2025 22:00	0.00000	0.41184
08/26/2025 23:00	0.00000	0.35022
Average/Sum#:	0.26894	0.33563
Minimum:	0.03684	0.23178
Maximum:	0.36192	0.41448
%SI	50.00	8.33

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/27/2025 00:00	0.04374	0.28410
08/27/2025 01:00	0.21318	0.24624
08/27/2025 02:00	0.21738	0.23514
08/27/2025 03:00	0.21744	0.23472
08/27/2025 04:00	0.22236	0.24018
08/27/2025 05:00	0.22410	0.24180
08/27/2025 06:00	0.21756	0.23484
08/27/2025 07:00	0.21768	0.23490
08/27/2025 08:00	0.21732	0.23484
08/27/2025 09:00	0.21708	0.23472
08/27/2025 10:00	0.21714	0.23430
08/27/2025 11:00	0.21762	0.23340
08/27/2025 12:00	0.24000	0.25884
08/27/2025 13:00	0.26700	0.28752
08/27/2025 14:00	0.26688	0.28728
08/27/2025 15:00	0.26688	0.28704
08/27/2025 16:00	0.25116	0.27066
08/27/2025 17:00	0.26532	0.28746
08/27/2025 18:00	0.30270	0.33072
08/27/2025 19:00	0.30156	0.32970
08/27/2025 20:00	0.30414	0.33084
08/27/2025 21:00	0.26526	0.28848
08/27/2025 22:00	0.21726	0.23154
08/27/2025 23:00	0.21762	0.23172
Average/Sum#:	0.23368	0.26296
Minimum:	0.04374	0.23154
Maximum:	0.30414	0.33084
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/28/2025 00:00	0.21792	0.23190
08/28/2025 01:00	0.25302	0.27186
08/28/2025 02:00	0.30042	0.32880
08/28/2025 03:00	0.28644	0.31224
08/28/2025 04:00	0.23832	0.25338
08/28/2025 05:00	0.22050	0.23484
08/28/2025 06:00	0.23274	0.24714
08/28/2025 07:00	0.21822	0.23190
08/28/2025 08:00	0.21786	0.23172
08/28/2025 09:00	0.21756	0.23148
08/28/2025 10:00	0.21720	0.23094
08/28/2025 11:00	0.21774	0.23064
08/28/2025 12:00	0.21786	0.23046
08/28/2025 13:00	0.22914	0.24354
08/28/2025 14:00	0.23184	0.24822
08/28/2025 15:00	0.23796	0.25218
08/28/2025 16:00	0.24948	0.26736
08/28/2025 17:00	0.30324	0.33282
08/28/2025 18:00	0.30270	0.33078
08/28/2025 19:00	0.30492	0.33180
08/28/2025 20:00	0.31044	0.33456
08/28/2025 21:00	0.30540	0.33312
08/28/2025 22:00	0.30318	0.33120
08/28/2025 23:00	0.30276	0.33078
Average/Sum#:	0.25570	0.27515
Minimum:	0.21720	0.23046
Maximum:	0.31044	0.33456
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/29/2025 00:00	0.30192	0.32976
08/29/2025 01:00	0.26514	0.28740
08/29/2025 02:00	0.21774	0.23166
08/29/2025 03:00	0.21804	0.23178
08/29/2025 04:00	0.21798	0.23178
08/29/2025 05:00	0.21804	0.23202
08/29/2025 06:00	0.21810	0.23214
08/29/2025 07:00	0.21786	0.23184
08/29/2025 08:00	0.21762	0.23172
08/29/2025 09:00	0.21744	0.23148
08/29/2025 10:00	0.21726	0.23112
08/29/2025 11:00	0.21750	0.23070
08/29/2025 12:00	0.21732	0.23034
08/29/2025 13:00	0.21678	0.23010
08/29/2025 14:00	0.21654	0.22986
08/29/2025 15:00	0.21642	0.22920
08/29/2025 16:00	0.21816	0.23136
08/29/2025 17:00	0.23820	0.25488
08/29/2025 18:00	0.21894	0.23262
08/29/2025 19:00	0.21690	0.23052
08/29/2025 20:00	0.21840	0.23244
08/29/2025 21:00	0.22182	0.23616
08/29/2025 22:00	0.21720	0.23148
08/29/2025 23:00	0.21666	0.23094
Average/Sum#:	0.22408	0.23889
Minimum:	0.21642	0.22920
Maximum:	0.30192	0.32976
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/30/2025 00:00	0.21690	0.23118
08/30/2025 01:00	0.21708	0.23130
08/30/2025 02:00	0.21714	0.23148
08/30/2025 03:00	0.21738	0.23124
08/30/2025 04:00	0.21726	0.23136
08/30/2025 05:00	0.21756	0.23166
08/30/2025 06:00	0.21780	0.23160
08/30/2025 07:00	0.21756	0.23142
08/30/2025 08:00	0.21696	0.23106
08/30/2025 09:00	0.21648	0.23064
08/30/2025 10:00	0.21636	0.23010
08/30/2025 11:00	0.21702	0.23004
08/30/2025 12:00	0.21708	0.22968
08/30/2025 13:00	0.21642	0.22968
08/30/2025 14:00	0.21624	0.22902
08/30/2025 15:00	0.21606	0.22872
08/30/2025 16:00	0.22530	0.23850
08/30/2025 17:00	0.24726	0.26730
08/30/2025 18:00	0.31758	0.33636
08/30/2025 19:00	0.32316	0.34254
08/30/2025 20:00	0.31842	0.34140
08/30/2025 21:00	0.31272	0.33636
08/30/2025 22:00	0.31164	0.33492
08/30/2025 23:00	0.26262	0.28626
Average/Sum#:	0.24125	0.25724
Minimum:	0.21606	0.22872
Maximum:	0.32316	0.34254
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
08/31/2025 00:00	0.21624	0.23058
08/31/2025 01:00	0.21642	0.23064
08/31/2025 02:00	0.21666	0.23076
08/31/2025 03:00	0.21666	0.23088
08/31/2025 04:00	0.21672	0.23100
08/31/2025 05:00	0.21684	0.23100
08/31/2025 06:00	0.21708	0.23118
08/31/2025 07:00	0.21702	0.23082
08/31/2025 08:00	0.21636	0.23034
08/31/2025 09:00	0.21612	0.22986
08/31/2025 10:00	0.21600	0.22956
08/31/2025 11:00	0.21654	0.22872
08/31/2025 12:00	0.23172	0.24630
08/31/2025 13:00	0.24612	0.26538
08/31/2025 14:00	0.30618	0.33402
08/31/2025 15:00	0.30594	0.33408
08/31/2025 16:00	0.30828	0.33642
08/31/2025 17:00	0.30972	0.35376
08/31/2025 18:00	0.30054	0.35220
08/31/2025 19:00	0.31578	0.34032
08/31/2025 20:00	0.22482	0.24042
08/31/2025 21:00	0.22164	0.23562
08/31/2025 22:00	0.23718	0.25338
08/31/2025 23:00	0.30618	0.33294
Average/Sum#:	0.24637	0.26626
Minimum:	0.21600	0.22872
Maximum:	0.31578	0.35376
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/01/2025 00:00	0.30774	0.33414
09/01/2025 01:00	0.30630	0.33324
09/01/2025 02:00	0.30570	0.33264
09/01/2025 03:00	0.30504	0.33114
09/01/2025 04:00	0.30498	0.32940
09/01/2025 05:00	0.30300	0.32892
09/01/2025 06:00	0.28794	0.31230
09/01/2025 07:00	0.21846	0.23220
09/01/2025 08:00	0.21666	0.23052
09/01/2025 09:00	0.21654	0.23040
09/01/2025 10:00	0.24840	0.26706
09/01/2025 11:00	0.31104	0.33690
09/01/2025 12:00	0.32802	0.34746
09/01/2025 13:00	0.33126	0.35172
09/01/2025 14:00	0.32778	0.35502
09/01/2025 15:00	0.31368	0.34086
09/01/2025 16:00	0.35394	0.38052
09/01/2025 17:00	0.37944	0.40704
09/01/2025 18:00	0.38724	0.41250
09/01/2025 19:00	0.38844	0.41520
09/01/2025 20:00	0.38484	0.41256
09/01/2025 21:00	0.37908	0.40650
09/01/2025 22:00	0.35520	0.38280
09/01/2025 23:00	0.34710	0.37332
Average/Sum#:	0.31699	0.34102
Minimum:	0.21654	0.23040
Maximum:	0.38844	0.41520
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/02/2025 00:00	0.30636	0.33258
09/02/2025 01:00	0.30864	0.33210
09/02/2025 02:00	0.30732	0.33264
09/02/2025 03:00	0.30684	0.33108
09/02/2025 04:00	0.34920	0.37308
09/02/2025 05:00	0.38226	0.40764
09/02/2025 06:00	0.36570	0.38958
09/02/2025 07:00	0.37446	0.39732
09/02/2025 08:00	0.37992	0.40560
09/02/2025 09:00	0.34620	0.37302
09/02/2025 10:00	0.31488	0.33876
09/02/2025 11:00	0.35418	0.37818
09/02/2025 12:00	0.38238	0.40728
09/02/2025 13:00	0.37668	0.40272
09/02/2025 14:00	0.38904	0.41466
09/02/2025 15:00	0.38766	0.41316
09/02/2025 16:00	0.38874	0.41418
09/02/2025 17:00	0.38946	0.41508
09/02/2025 18:00	0.39060	0.41736
09/02/2025 19:00	0.38892	0.41520
09/02/2025 20:00	0.38664	0.41346
09/02/2025 21:00	0.38508	0.41346
09/02/2025 22:00	0.38406	0.41256
09/02/2025 23:00	0.37608	0.40440
Average/Sum#:	0.36339	0.38896
Minimum:	0.30636	0.33108
Maximum:	0.39060	0.41736
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/03/2025 00:00	0.33762	0.36516
09/03/2025 01:00	0.30282	0.33030
09/03/2025 02:00	0.30336	0.33048
09/03/2025 03:00	0.30108	0.32832
09/03/2025 04:00	0.33786	0.36516
09/03/2025 05:00	0.35682	0.38328
09/03/2025 06:00	0.31320	0.34020
09/03/2025 07:00	0.30162	0.32748
09/03/2025 08:00	0.30360	0.32898
09/03/2025 09:00	0.30690	0.33186
09/03/2025 10:00	0.30984	0.33396
09/03/2025 11:00	0.31566	0.33612
09/03/2025 12:00	0.33570	0.35856
09/03/2025 13:00	0.33006	0.35478
09/03/2025 14:00	0.37296	0.39924
09/03/2025 15:00	0.38376	0.41034
09/03/2025 16:00	0.37764	0.40440
09/03/2025 17:00	0.38958	0.41646
09/03/2025 18:00	0.38682	0.41382
09/03/2025 19:00	0.35652	0.38376
09/03/2025 20:00	0.36228	0.38898
09/03/2025 21:00	0.37338	0.40062
09/03/2025 22:00	0.35058	0.37626
09/03/2025 23:00	0.30912	0.33624
Average/Sum#:	0.33828	0.36437
Minimum:	0.30108	0.32748
Maximum:	0.38958	0.41646
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/04/2025 00:00	0.30498	0.33282
09/04/2025 01:00	0.30432	0.33264
09/04/2025 02:00	0.30390	0.33180
09/04/2025 03:00	0.30246	0.33048
09/04/2025 04:00	0.33930	0.34176
09/04/2025 05:00	0.36588	0.39312
09/04/2025 06:00	0.30870	0.33570
09/04/2025 07:00	0.30192	0.32934
09/04/2025 08:00	0.30354	0.33024
09/04/2025 09:00	0.30576	0.33168
09/04/2025 10:00	0.31146	0.33150
09/04/2025 11:00	0.31224	0.33486
09/04/2025 12:00	0.31800	0.33906
09/04/2025 13:00	0.32106	0.34254
09/04/2025 14:00	0.32112	0.34128
09/04/2025 15:00	0.32064	0.34134
09/04/2025 16:00	0.34452	0.36702
09/04/2025 17:00	0.32418	0.35046
09/04/2025 18:00	0.34794	0.37272
09/04/2025 19:00	0.34692	0.37326
09/04/2025 20:00	0.31164	0.33894
09/04/2025 21:00	0.31080	0.33834
09/04/2025 22:00	0.30966	0.33756
09/04/2025 23:00	0.30708	0.33480
Average/Sum#:	0.31867	0.34305
Minimum:	0.30192	0.32934
Maximum:	0.36588	0.39312
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/05/2025 00:00	0.30702	0.33480
09/05/2025 01:00	0.30672	0.33462
09/05/2025 02:00	0.30624	0.33438
09/05/2025 03:00	0.30618	0.33468
09/05/2025 04:00	0.30624	0.33438
09/05/2025 05:00	0.32478	0.35256
09/05/2025 06:00	0.32664	0.35418
09/05/2025 07:00	0.30618	0.33348
09/05/2025 08:00	0.30636	0.33354
09/05/2025 09:00	0.30834	0.33492
09/05/2025 10:00	0.30678	0.33600
09/05/2025 11:00	0.30684	0.33048
09/05/2025 12:00	0.30828	0.33156
09/05/2025 13:00	0.31074	0.33348
09/05/2025 14:00	0.31236	0.33372
09/05/2025 15:00	0.31542	0.33648
09/05/2025 16:00	0.32328	0.34374
09/05/2025 17:00	0.31350	0.33480
09/05/2025 18:00	0.30900	0.33288
09/05/2025 19:00	0.30618	0.33168
09/05/2025 20:00	0.30372	0.33024
09/05/2025 21:00	0.30150	0.32844
09/05/2025 22:00	0.30054	0.32814
09/05/2025 23:00	0.29976	0.32766
Average/Sum#:	0.30928	0.33504
Minimum:	0.29976	0.32766
Maximum:	0.32664	0.35418
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/06/2025 00:00	0.29928	0.32736
09/06/2025 01:00	0.29886	0.32682
09/06/2025 02:00	0.29838	0.32610
09/06/2025 03:00	0.29808	0.32592
09/06/2025 04:00	0.29796	0.32574
09/06/2025 05:00	0.29832	0.32586
09/06/2025 06:00	0.26538	0.28746
09/06/2025 07:00	0.21672	0.23058
09/06/2025 08:00	0.21660	0.23040
09/06/2025 09:00	0.21648	0.23070
09/06/2025 10:00	0.23226	0.24762
09/06/2025 11:00	0.30732	0.33132
09/06/2025 12:00	0.31146	0.32892
09/06/2025 13:00	0.26064	0.28230
09/06/2025 14:00	0.31014	0.33312
09/06/2025 15:00	0.31086	0.33342
09/06/2025 16:00	0.30996	0.33348
09/06/2025 17:00	0.30744	0.33174
09/06/2025 18:00	0.30498	0.33084
09/06/2025 19:00	0.30204	0.32910
09/06/2025 20:00	0.30042	0.32820
09/06/2025 21:00	0.29976	0.32724
09/06/2025 22:00	0.29880	0.32652
09/06/2025 23:00	0.29862	0.32628
Average/Sum#:	0.28587	0.30946
Minimum:	0.21648	0.23040
Maximum:	0.31146	0.33348
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/07/2025 00:00	0.29856	0.32640
09/07/2025 01:00	0.29808	0.32610
09/07/2025 02:00	0.29706	0.32550
09/07/2025 03:00	0.29652	0.32490
09/07/2025 04:00	0.29646	0.32706
09/07/2025 05:00	0.29646	0.32412
09/07/2025 06:00	0.26526	0.28992
09/07/2025 07:00	0.21702	0.23076
09/07/2025 08:00	0.21678	0.23058
09/07/2025 09:00	0.21666	0.23046
09/07/2025 10:00	0.21642	0.23010
09/07/2025 11:00	0.21648	0.22980
09/07/2025 12:00	0.24480	0.26322
09/07/2025 13:00	0.30966	0.33282
09/07/2025 14:00	0.31092	0.33282
09/07/2025 15:00	0.31224	0.33246
09/07/2025 16:00	0.32976	0.35100
09/07/2025 17:00	0.35094	0.37758
09/07/2025 18:00	0.31158	0.33702
09/07/2025 19:00	0.30600	0.33072
09/07/2025 20:00	0.30450	0.33036
09/07/2025 21:00	0.30324	0.33108
09/07/2025 22:00	0.30054	0.33120
09/07/2025 23:00	0.30024	0.33036
Average/Sum#:	0.28401	0.30735
Minimum:	0.21642	0.22980
Maximum:	0.35094	0.37758
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/08/2025 00:00	0.29862	0.32658
09/08/2025 01:00	0.29802	0.32646
09/08/2025 02:00	0.29808	0.32658
09/08/2025 03:00	0.29814	0.32652
09/08/2025 04:00	0.29772	0.32580
09/08/2025 05:00	0.31566	0.34488
09/08/2025 06:00	0.29730	0.32532
09/08/2025 07:00	0.29916	0.32658
09/08/2025 08:00	0.28596	0.31146
09/08/2025 09:00	0.21780	0.23190
09/08/2025 10:00	0.21636	0.23034
09/08/2025 11:00	0.21678	0.22986
09/08/2025 12:00	0.21678	0.22992
09/08/2025 13:00	0.23040	0.24708
09/08/2025 14:00	0.30456	0.32970
09/08/2025 15:00	0.30882	0.33330
09/08/2025 16:00	0.32358	0.34974
09/08/2025 17:00	0.35436	0.37860
09/08/2025 18:00	0.31524	0.34116
09/08/2025 19:00	0.30690	0.33222
09/08/2025 20:00	0.30384	0.32958
09/08/2025 21:00	0.30912	0.33522
09/08/2025 22:00	0.31986	0.34644
09/08/2025 23:00	0.30114	0.32784
Average/Sum#:	0.28893	0.31305
Minimum:	0.21636	0.22986
Maximum:	0.35436	0.37860
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/09/2025 00:00	0.30120	0.32760
09/09/2025 01:00	0.30150	0.32964
09/09/2025 02:00	0.30138	0.32856
09/09/2025 03:00	0.30150	0.32826
09/09/2025 04:00	0.30072	0.32706
09/09/2025 05:00	0.33654	0.36306
09/09/2025 06:00	0.28674	0.31140
09/09/2025 07:00	0.27144	0.29328
09/09/2025 08:00	0.30078	0.32640
09/09/2025 09:00	0.30222	0.32874
09/09/2025 10:00	0.30246	0.32754
09/09/2025 11:00	0.30342	0.32850
09/09/2025 12:00	0.26304	0.28206
09/09/2025 13:00	0.30474	0.32874
09/09/2025 14:00	0.30510	0.32934
09/09/2025 15:00	0.30474	0.32898
09/09/2025 16:00	0.30438	0.32880
09/09/2025 17:00	0.30330	0.32814
09/09/2025 18:00	0.30216	0.32742
09/09/2025 19:00	0.30150	0.32712
09/09/2025 20:00	0.30078	0.32658
09/09/2025 21:00	0.30060	0.32736
09/09/2025 22:00	0.30006	0.32718
09/09/2025 23:00	0.29958	0.32676
Average/Sum#:	0.30000	0.32536
Minimum:	0.26304	0.28206
Maximum:	0.33654	0.36306
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/10/2025 00:00	0.29892	0.32598
09/10/2025 01:00	0.29850	0.32562
09/10/2025 02:00	0.29832	0.32562
09/10/2025 03:00	0.29826	0.32544
09/10/2025 04:00	0.29838	0.32568
09/10/2025 05:00	0.29940	0.32658
09/10/2025 06:00	0.30186	0.32904
09/10/2025 07:00	0.26418	0.28698
09/10/2025 08:00	0.24660	0.26478
09/10/2025 09:00	0.29982	0.32742
09/10/2025 10:00	0.22800	0.24432
09/10/2025 11:00	0.21576	0.22908
09/10/2025 12:00	0.21552	0.22890
09/10/2025 13:00	0.21516	0.22890
09/10/2025 14:00	0.22998	0.24558
09/10/2025 15:00	0.30114	0.32616
09/10/2025 16:00	0.30528	0.32964
09/10/2025 17:00	0.30246	0.32718
09/10/2025 18:00	0.30138	0.32652
09/10/2025 19:00	0.30012	0.32574
09/10/2025 20:00	0.29814	0.32436
09/10/2025 21:00	0.29712	0.32376
09/10/2025 22:00	0.29664	0.32430
09/10/2025 23:00	0.29604	0.32370
Average/Sum#:	0.27946	0.30297
Minimum:	0.21516	0.22890
Maximum:	0.30528	0.32964
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/11/2025 00:00	0.29556	0.32286
09/11/2025 01:00	0.29544	0.32298
09/11/2025 02:00	0.29514	0.32274
09/11/2025 03:00	0.29538	0.32250
09/11/2025 04:00	0.29514	0.32232
09/11/2025 05:00	0.29454	0.32388
09/11/2025 06:00	0.29442	0.32202
09/11/2025 07:00	0.29556	0.32202
09/11/2025 08:00	0.29634	0.32226
09/11/2025 09:00	0.29850	0.32400
09/11/2025 10:00	0.30372	0.32358
09/11/2025 11:00	0.28584	0.30918
09/11/2025 12:00	0.24600	0.26334
09/11/2025 13:00	0.30642	0.32976
09/11/2025 14:00	0.30870	0.32802
09/11/2025 15:00	0.30990	0.32742
09/11/2025 16:00	0.30804	0.32982
09/11/2025 17:00	0.30606	0.32922
09/11/2025 18:00	0.30432	0.32880
09/11/2025 19:00	0.30288	0.32904
09/11/2025 20:00	0.29616	0.33252
09/11/2025 21:00	0.29226	0.33480
09/11/2025 22:00	0.29928	0.32946
09/11/2025 23:00	0.29922	0.32706
Average/Sum#:	0.29687	0.32290
Minimum:	0.24600	0.26334
Maximum:	0.30990	0.33480
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/12/2025 00:00	0.29862	0.32700
09/12/2025 01:00	0.29790	0.32514
09/12/2025 02:00	0.29742	0.32478
09/12/2025 03:00	0.29646	0.32532
09/12/2025 04:00	0.29652	0.32640
09/12/2025 05:00	0.29610	0.32340
09/12/2025 06:00	0.29592	0.32340
09/12/2025 07:00	0.26352	0.28524
09/12/2025 08:00	0.24600	0.26388
09/12/2025 09:00	0.30102	0.32640
09/12/2025 10:00	0.24312	0.26082
09/12/2025 11:00	0.21558	0.22836
09/12/2025 12:00	0.21546	0.22824
09/12/2025 13:00	0.21840	0.23190
09/12/2025 14:00	0.28962	0.30996
09/12/2025 15:00	0.31146	0.33108
09/12/2025 16:00	0.31278	0.33186
09/12/2025 17:00	0.31212	0.33162
09/12/2025 18:00	0.30690	0.32994
09/12/2025 19:00	0.30456	0.32898
09/12/2025 20:00	0.30300	0.32766
09/12/2025 21:00	0.30186	0.32748
09/12/2025 22:00	0.30054	0.32718
09/12/2025 23:00	0.29934	0.32634
Average/Sum#:	0.28434	0.30718
Minimum:	0.21546	0.22824
Maximum:	0.31278	0.33186
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/13/2025 00:00	0.29850	0.32526
09/13/2025 01:00	0.29778	0.32472
09/13/2025 02:00	0.29700	0.32400
09/13/2025 03:00	0.29622	0.32382
09/13/2025 04:00	0.29598	0.32304
09/13/2025 05:00	0.29628	0.32310
09/13/2025 06:00	0.28326	0.30828
09/13/2025 07:00	0.21732	0.23046
09/13/2025 08:00	0.21714	0.23040
09/13/2025 09:00	0.21672	0.23028
09/13/2025 10:00	0.21654	0.22992
09/13/2025 11:00	0.21666	0.22950
09/13/2025 12:00	0.21630	0.22926
09/13/2025 13:00	0.21588	0.22920
09/13/2025 14:00	0.21576	0.22902
09/13/2025 15:00	0.21570	0.22908
09/13/2025 16:00	0.24534	0.26304
09/13/2025 17:00	0.31146	0.33336
09/13/2025 18:00	0.30768	0.33156
09/13/2025 19:00	0.30432	0.32928
09/13/2025 20:00	0.30216	0.32868
09/13/2025 21:00	0.30054	0.32766
09/13/2025 22:00	0.29928	0.32634
09/13/2025 23:00	0.29886	0.32616
Average/Sum#:	0.26595	0.28689
Minimum:	0.21570	0.22902
Maximum:	0.31146	0.33336
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/14/2025 00:00	0.29838	0.32562
09/14/2025 01:00	0.29868	0.32496
09/14/2025 02:00	0.29832	0.32448
09/14/2025 03:00	0.29814	0.32436
09/14/2025 04:00	0.29772	0.32400
09/14/2025 05:00	0.29736	0.32400
09/14/2025 06:00	0.26238	0.28374
09/14/2025 07:00	0.21708	0.23004
09/14/2025 08:00	0.21666	0.23004
09/14/2025 09:00	0.21648	0.22980
09/14/2025 10:00	0.21654	0.22980
09/14/2025 11:00	0.21756	0.22962
09/14/2025 12:00	0.21660	0.22938
09/14/2025 13:00	0.21582	0.22920
09/14/2025 14:00	0.21570	0.22890
09/14/2025 15:00	0.21540	0.22890
09/14/2025 16:00	0.24474	0.26244
09/14/2025 17:00	0.31230	0.33276
09/14/2025 18:00	0.30792	0.33060
09/14/2025 19:00	0.30546	0.32922
09/14/2025 20:00	0.30390	0.32874
09/14/2025 21:00	0.30378	0.32898
09/14/2025 22:00	0.30228	0.32910
09/14/2025 23:00	0.30174	0.32808
Average/Sum#:	0.26587	0.28612
Minimum:	0.21540	0.22890
Maximum:	0.31230	0.33276
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/15/2025 00:00	0.30060	0.32748
09/15/2025 01:00	0.30006	0.32652
09/15/2025 02:00	0.29898	0.32574
09/15/2025 03:00	0.29850	0.32514
09/15/2025 04:00	0.29808	0.32358
09/15/2025 05:00	0.29712	0.32082
09/15/2025 06:00	0.29652	0.32112
09/15/2025 07:00	0.29826	0.32304
09/15/2025 08:00	0.30102	0.32580
09/15/2025 09:00	0.30282	0.32730
09/15/2025 10:00	0.26148	0.28068
09/15/2025 11:00	0.30984	0.33108
09/15/2025 12:00	0.31338	0.33420
09/15/2025 13:00	0.31716	0.33744
09/15/2025 14:00	0.35484	0.37872
09/15/2025 15:00	0.33066	0.35364
09/15/2025 16:00	0.33792	0.36012
09/15/2025 17:00	0.31014	0.33702
09/15/2025 18:00	0.31110	0.33780
09/15/2025 19:00	0.30030	0.32712
09/15/2025 20:00	0.29952	0.32580
09/15/2025 21:00	0.29898	0.32568
09/15/2025 22:00	0.29826	0.32508
09/15/2025 23:00	0.29826	0.32436
Average/Sum#:	0.30558	0.33022
Minimum:	0.26148	0.28068
Maximum:	0.35484	0.37872
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/16/2025 00:00	0.29826	0.32412
09/16/2025 01:00	0.29898	0.32490
09/16/2025 02:00	0.29874	0.32460
09/16/2025 03:00	0.29760	0.32406
09/16/2025 04:00	0.29676	0.32256
09/16/2025 05:00	0.29832	0.32346
09/16/2025 06:00	0.29886	0.32346
09/16/2025 07:00	0.30096	0.32520
09/16/2025 08:00	0.30324	0.32832
09/16/2025 09:00	0.30726	0.33108
09/16/2025 10:00	0.31140	0.33264
09/16/2025 11:00	0.31566	0.33570
09/16/2025 12:00	0.31932	0.33948
09/16/2025 13:00	0.32226	0.34218
09/16/2025 14:00	0.32382	0.34278
09/16/2025 15:00	0.30846	0.33366
09/16/2025 16:00	0.31080	0.33714
09/16/2025 17:00	0.30492	0.33186
09/16/2025 18:00	0.30498	0.33114
09/16/2025 19:00	0.30840	0.33192
09/16/2025 20:00	0.31248	0.33228
09/16/2025 21:00	0.30834	0.33144
09/16/2025 22:00	0.30468	0.32928
09/16/2025 23:00	0.30534	0.32940
Average/Sum#:	0.30666	0.33053
Minimum:	0.29676	0.32256
Maximum:	0.32382	0.34278
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/17/2025 00:00	0.30450	0.32904
09/17/2025 01:00	0.30408	0.32832
09/17/2025 02:00	0.30276	0.32934
09/17/2025 03:00	0.30240	0.32856
09/17/2025 04:00	0.30084	0.32616
09/17/2025 05:00	0.29946	0.32298
09/17/2025 06:00	0.29826	0.32226
09/17/2025 07:00	0.30066	0.32484
09/17/2025 08:00	0.30504	0.32922
09/17/2025 09:00	0.30834	0.33156
09/17/2025 10:00	0.31380	0.33468
09/17/2025 11:00	0.31812	0.33816
09/17/2025 12:00	0.32292	0.34170
09/17/2025 13:00	0.32694	0.34512
09/17/2025 14:00	0.31482	0.34152
09/17/2025 15:00	0.31200	0.33894
09/17/2025 16:00	0.30396	0.33120
09/17/2025 17:00	0.32244	0.34308
09/17/2025 18:00	0.32070	0.34182
09/17/2025 19:00	0.31566	0.33720
09/17/2025 20:00	0.31200	0.33378
09/17/2025 21:00	0.31074	0.32982
09/17/2025 22:00	0.30762	0.33036
09/17/2025 23:00	0.30576	0.32970
Average/Sum#:	0.30974	0.33289
Minimum:	0.29826	0.32226
Maximum:	0.32694	0.34512
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/18/2025 00:00	0.30378	0.32904
09/18/2025 01:00	0.30264	0.32856
09/18/2025 02:00	0.30252	0.32880
09/18/2025 03:00	0.30162	0.32736
09/18/2025 04:00	0.30114	0.32604
09/18/2025 05:00	0.30078	0.32352
09/18/2025 06:00	0.30402	0.32634
09/18/2025 07:00	0.32826	0.35184
09/18/2025 08:00	0.30462	0.32850
09/18/2025 09:00	0.31266	0.33582
09/18/2025 10:00	0.31128	0.33246
09/18/2025 11:00	0.31350	0.33540
09/18/2025 12:00	0.31476	0.33810
09/18/2025 13:00	0.32310	0.34674
09/18/2025 14:00	0.31572	0.33822
09/18/2025 15:00	0.32946	0.35376
09/18/2025 16:00	0.31068	0.33636
09/18/2025 17:00	0.31002	0.33462
09/18/2025 18:00	0.30624	0.33150
09/18/2025 19:00	0.30552	0.33084
09/18/2025 20:00	0.30498	0.33042
09/18/2025 21:00	0.30420	0.33000
09/18/2025 22:00	0.30366	0.32976
09/18/2025 23:00	0.30342	0.32934
Average/Sum#:	0.30911	0.33347
Minimum:	0.30078	0.32352
Maximum:	0.32946	0.35376
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/19/2025 00:00	0.30306	0.32910
09/19/2025 01:00	0.30348	0.32946
09/19/2025 02:00	0.30342	0.32952
09/19/2025 03:00	0.30348	0.32952
09/19/2025 04:00	0.30372	0.32964
09/19/2025 05:00	0.30288	0.32988
09/19/2025 06:00	0.30852	0.33396
09/19/2025 07:00	0.30168	0.32616
09/19/2025 08:00	0.30210	0.32748
09/19/2025 09:00	0.30276	0.32796
09/19/2025 10:00	0.30306	0.32766
09/19/2025 11:00	0.30360	0.32814
09/19/2025 12:00	0.30372	0.32748
09/19/2025 13:00	0.30594	0.32808
09/19/2025 14:00	0.31248	0.33408
09/19/2025 15:00	0.30756	0.33084
09/19/2025 16:00	0.30930	0.33270
09/19/2025 17:00	0.30702	0.33048
09/19/2025 18:00	0.30636	0.33030
09/19/2025 19:00	0.30522	0.32928
09/19/2025 20:00	0.31164	0.33342
09/19/2025 21:00	0.34944	0.37194
09/19/2025 22:00	0.31782	0.34158
09/19/2025 23:00	0.30360	0.32856
Average/Sum#:	0.30758	0.33197
Minimum:	0.30168	0.32616
Maximum:	0.34944	0.37194
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/20/2025 00:00	0.30312	0.32796
09/20/2025 01:00	0.30222	0.32766
09/20/2025 02:00	0.30204	0.32616
09/20/2025 03:00	0.30150	0.32622
09/20/2025 04:00	0.30054	0.32562
09/20/2025 05:00	0.29976	0.32556
09/20/2025 06:00	0.29904	0.32520
09/20/2025 07:00	0.30066	0.32622
09/20/2025 08:00	0.30192	0.32730
09/20/2025 09:00	0.30456	0.32940
09/20/2025 10:00	0.30702	0.33072
09/20/2025 11:00	0.30882	0.33156
09/20/2025 12:00	0.31182	0.33228
09/20/2025 13:00	0.31194	0.33234
09/20/2025 14:00	0.31380	0.33306
09/20/2025 15:00	0.31482	0.33474
09/20/2025 16:00	0.33432	0.35550
09/20/2025 17:00	0.31488	0.33618
09/20/2025 18:00	0.31164	0.32964
09/20/2025 19:00	0.30600	0.32964
09/20/2025 20:00	0.30384	0.32826
09/20/2025 21:00	0.30390	0.32910
09/20/2025 22:00	0.30456	0.33030
09/20/2025 23:00	0.30114	0.32742
Average/Sum#:	0.30683	0.33034
Minimum:	0.29904	0.32520
Maximum:	0.33432	0.35550
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/21/2025 00:00	0.30060	0.32652
09/21/2025 01:00	0.30042	0.32652
09/21/2025 02:00	0.30030	0.32688
09/21/2025 03:00	0.30012	0.32700
09/21/2025 04:00	0.29970	0.32604
09/21/2025 05:00	0.29910	0.32598
09/21/2025 06:00	0.29892	0.32604
09/21/2025 07:00	0.30054	0.32658
09/21/2025 08:00	0.30234	0.32724
09/21/2025 09:00	0.30426	0.32844
09/21/2025 10:00	0.30690	0.33018
09/21/2025 11:00	0.31218	0.33234
09/21/2025 12:00	0.31632	0.33552
09/21/2025 13:00	0.31740	0.33708
09/21/2025 14:00	0.31872	0.33762
09/21/2025 15:00	0.31956	0.33828
09/21/2025 16:00	0.32028	0.33864
09/21/2025 17:00	0.31830	0.33744
09/21/2025 18:00	0.31362	0.33432
09/21/2025 19:00	0.30858	0.33114
09/21/2025 20:00	0.30708	0.33078
09/21/2025 21:00	0.30642	0.33042
09/21/2025 22:00	0.30552	0.32976
09/21/2025 23:00	0.30402	0.33006
Average/Sum#:	0.30755	0.33087
Minimum:	0.29892	0.32598
Maximum:	0.32028	0.33864
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/22/2025 00:00	0.30306	0.32904
09/22/2025 01:00	0.30222	0.32844
09/22/2025 02:00	0.30168	0.32766
09/22/2025 03:00	0.30156	0.32676
09/22/2025 04:00	0.30042	0.32454
09/22/2025 05:00	0.29898	0.32316
09/22/2025 06:00	0.29874	0.32268
09/22/2025 07:00	0.30174	0.32508
09/22/2025 08:00	0.30468	0.32850
09/22/2025 09:00	0.30690	0.33042
09/22/2025 10:00	0.23910	0.25734
09/22/2025 11:00	0.21480	0.22932
09/22/2025 12:00	0.24408	0.26394
09/22/2025 13:00	0.30528	0.33144
09/22/2025 14:00	0.32034	0.33936
09/22/2025 15:00	0.32208	0.34038
09/22/2025 16:00	0.33132	0.34962
09/22/2025 17:00	0.31176	0.33732
09/22/2025 18:00	0.30504	0.33132
09/22/2025 19:00	0.30360	0.32988
09/22/2025 20:00	0.30234	0.32886
09/22/2025 21:00	0.30252	0.32904
09/22/2025 22:00	0.30162	0.32682
09/22/2025 23:00	0.30108	0.32652
Average/Sum#:	0.29687	0.32031
Minimum:	0.21480	0.22932
Maximum:	0.33132	0.34962
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/23/2025 00:00	0.29994	0.32628
09/23/2025 01:00	0.29940	0.32598
09/23/2025 02:00	0.29916	0.32616
09/23/2025 03:00	0.29964	0.32706
09/23/2025 04:00	0.29922	0.32562
09/23/2025 05:00	0.30246	0.32706
09/23/2025 06:00	0.30150	0.32406
09/23/2025 07:00	0.30408	0.32646
09/23/2025 08:00	0.30690	0.33012
09/23/2025 09:00	0.31062	0.33324
09/23/2025 10:00	0.31524	0.33582
09/23/2025 11:00	0.31974	0.33942
09/23/2025 12:00	0.32442	0.34332
09/23/2025 13:00	0.30798	0.33384
09/23/2025 14:00	0.30672	0.33324
09/23/2025 15:00	0.31344	0.33966
09/23/2025 16:00	0.32022	0.34668
09/23/2025 17:00	0.35658	0.38280
09/23/2025 18:00	0.33912	0.36300
09/23/2025 19:00	0.32118	0.33540
09/23/2025 20:00	0.31632	0.33210
09/23/2025 21:00	0.31146	0.33234
09/23/2025 22:00	0.30594	0.32904
09/23/2025 23:00	0.30492	0.32916
Average/Sum#:	0.31193	0.33533
Minimum:	0.29916	0.32406
Maximum:	0.35658	0.38280
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/24/2025 00:00	0.30444	0.32754
09/24/2025 01:00	0.30342	0.32832
09/24/2025 02:00	0.30210	0.32910
09/24/2025 03:00	0.30030	0.32790
09/24/2025 04:00	0.30018	0.32742
09/24/2025 05:00	0.30546	0.33246
09/24/2025 06:00	0.30120	0.32784
09/24/2025 07:00	0.30216	0.32736
09/24/2025 08:00	0.30744	0.33258
09/24/2025 09:00	0.31548	0.34008
09/24/2025 10:00	0.30612	0.33120
09/24/2025 11:00	0.30546	0.33078
09/24/2025 12:00	0.30750	0.33264
09/24/2025 13:00	0.30978	0.33426
09/24/2025 14:00	0.31266	0.33420
09/24/2025 15:00	0.30948	0.33096
09/24/2025 16:00	0.31800	0.34128
09/24/2025 17:00	0.30804	0.33318
09/24/2025 18:00	0.30474	0.32904
09/24/2025 19:00	0.30396	0.32940
09/24/2025 20:00	0.30462	0.32754
09/24/2025 21:00	0.30240	0.32676
09/24/2025 22:00	0.30210	0.32664
09/24/2025 23:00	0.30240	0.32724
Average/Sum#:	0.30581	0.33066
Minimum:	0.30018	0.32664
Maximum:	0.31800	0.34128
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/25/2025 00:00	0.30192	0.32694
09/25/2025 01:00	0.30120	0.32658
09/25/2025 02:00	0.30132	0.32574
09/25/2025 03:00	0.30156	0.32526
09/25/2025 04:00	0.30198	0.32742
09/25/2025 05:00	0.30168	0.32742
09/25/2025 06:00	0.30372	0.32940
09/25/2025 07:00	0.30336	0.32772
09/25/2025 08:00	0.30456	0.32856
09/25/2025 09:00	0.30516	0.32928
09/25/2025 10:00	0.30600	0.32976
09/25/2025 11:00	0.30774	0.33180
09/25/2025 12:00	0.31026	0.33354
09/25/2025 13:00	0.31266	0.33324
09/25/2025 14:00	0.31362	0.33378
09/25/2025 15:00	0.31404	0.33420
09/25/2025 16:00	0.31788	0.34212
09/25/2025 17:00	0.31218	0.33744
09/25/2025 18:00	0.30582	0.33054
09/25/2025 19:00	0.30264	0.32790
09/25/2025 20:00	0.30018	0.32628
09/25/2025 21:00	0.29958	0.32634
09/25/2025 22:00	0.29832	0.32508
09/25/2025 23:00	0.29850	0.32514
Average/Sum#:	0.30525	0.32965
Minimum:	0.29832	0.32508
Maximum:	0.31788	0.34212
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/26/2025 00:00	0.29898	0.32520
09/26/2025 01:00	0.29832	0.32484
09/26/2025 02:00	0.29778	0.32430
09/26/2025 03:00	0.29754	0.32346
09/26/2025 04:00	0.29820	0.32292
09/26/2025 05:00	0.29766	0.32262
09/26/2025 06:00	0.29676	0.32232
09/26/2025 07:00	0.26238	0.28344
09/26/2025 08:00	0.21672	0.23022
09/26/2025 09:00	0.21612	0.23040
09/26/2025 10:00	0.21516	0.22986
09/26/2025 11:00	0.21468	0.22962
09/26/2025 12:00	0.21414	0.22974
09/26/2025 13:00	0.24078	0.26394
09/26/2025 14:00	0.31542	0.33552
09/26/2025 15:00	0.31698	0.33678
09/26/2025 16:00	0.31830	0.33762
09/26/2025 17:00	0.31626	0.33762
09/26/2025 18:00	0.31218	0.33756
09/26/2025 19:00	0.30768	0.33192
09/26/2025 20:00	0.30600	0.33072
09/26/2025 21:00	0.30474	0.32952
09/26/2025 22:00	0.30276	0.32964
09/26/2025 23:00	0.30192	0.32934
Average/Sum#:	0.28198	0.30413
Minimum:	0.21414	0.22962
Maximum:	0.31830	0.33762
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/27/2025 00:00	0.30138	0.32892
09/27/2025 01:00	0.30138	0.32868
09/27/2025 02:00	0.30108	0.32862
09/27/2025 03:00	0.30048	0.32718
09/27/2025 04:00	0.30048	0.32676
09/27/2025 05:00	0.30078	0.32688
09/27/2025 06:00	0.30048	0.32718
09/27/2025 07:00	0.24192	0.26094
09/27/2025 08:00	0.21618	0.23136
09/27/2025 09:00	0.21594	0.23112
09/27/2025 10:00	0.21576	0.23106
09/27/2025 11:00	0.21570	0.23094
09/27/2025 12:00	0.21576	0.23106
09/27/2025 13:00	0.21528	0.23070
09/27/2025 14:00	0.21528	0.23076
09/27/2025 15:00	0.24546	0.26532
09/27/2025 16:00	0.30864	0.33342
09/27/2025 17:00	0.30546	0.33072
09/27/2025 18:00	0.30180	0.32796
09/27/2025 19:00	0.29994	0.32610
09/27/2025 20:00	0.29898	0.32598
09/27/2025 21:00	0.29814	0.32472
09/27/2025 22:00	0.29778	0.32478
09/27/2025 23:00	0.29874	0.32622
Average/Sum#:	0.27137	0.29406
Minimum:	0.21528	0.23070
Maximum:	0.30864	0.33342
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/28/2025 00:00	0.29880	0.32652
09/28/2025 01:00	0.29814	0.32628
09/28/2025 02:00	0.29754	0.32532
09/28/2025 03:00	0.29784	0.32532
09/28/2025 04:00	0.29790	0.32520
09/28/2025 05:00	0.29772	0.32502
09/28/2025 06:00	0.29700	0.32406
09/28/2025 07:00	0.28500	0.30966
09/28/2025 08:00	0.21822	0.23316
09/28/2025 09:00	0.21666	0.23160
09/28/2025 10:00	0.21660	0.23142
09/28/2025 11:00	0.21648	0.23142
09/28/2025 12:00	0.24816	0.26682
09/28/2025 13:00	0.30384	0.32874
09/28/2025 14:00	0.26820	0.28956
09/28/2025 15:00	0.30198	0.32670
09/28/2025 16:00	0.30168	0.32652
09/28/2025 17:00	0.30096	0.32622
09/28/2025 18:00	0.29994	0.32526
09/28/2025 19:00	0.30000	0.32550
09/28/2025 20:00	0.29916	0.32472
09/28/2025 21:00	0.29970	0.32478
09/28/2025 22:00	0.29934	0.32418
09/28/2025 23:00	0.29910	0.32382
Average/Sum#:	0.28167	0.30533
Minimum:	0.21648	0.23142
Maximum:	0.30384	0.32874
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/29/2025 00:00	0.29850	0.32448
09/29/2025 01:00	0.29868	0.32424
09/29/2025 02:00	0.29910	0.32454
09/29/2025 03:00	0.29922	0.32466
09/29/2025 04:00	0.29982	0.32562
09/29/2025 05:00	0.29988	0.32616
09/29/2025 06:00	0.29976	0.32616
09/29/2025 07:00	0.29934	0.32496
09/29/2025 08:00	0.24858	0.26604
09/29/2025 09:00	0.30270	0.32856
09/29/2025 10:00	0.30348	0.32820
09/29/2025 11:00	0.30348	0.32826
09/29/2025 12:00	0.30330	0.32802
09/29/2025 13:00	0.30312	0.32814
09/29/2025 14:00	0.30450	0.32922
09/29/2025 15:00	0.30330	0.32778
09/29/2025 16:00	0.30318	0.32778
09/29/2025 17:00	0.29772	0.32232
09/29/2025 18:00	0.29646	0.32160
09/29/2025 19:00	0.29568	0.32088
09/29/2025 20:00	0.29544	0.32058
09/29/2025 21:00	0.29538	0.32022
09/29/2025 22:00	0.29490	0.32070
09/29/2025 23:00	0.29460	0.32046
Average/Sum#:	0.29751	0.32248
Minimum:	0.24858	0.26604
Maximum:	0.30450	0.32922
%SI	0.00	0.00

AQ33 HOURLY SOX



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1	Unit CT2
	SO2, LbPerHr	SO2, LbPerHr
	1 Hour(s)	1 Hour(s)
09/30/2025 00:00	0.29466	0.32004
09/30/2025 01:00	0.29436	0.32022
09/30/2025 02:00	0.29406	0.32016
09/30/2025 03:00	0.29382	0.31992
09/30/2025 04:00	0.29394	0.32016
09/30/2025 05:00	0.30498	0.33084
09/30/2025 06:00	0.31146	0.33726
09/30/2025 07:00	0.29460	0.32046
09/30/2025 08:00	0.26280	0.28308
09/30/2025 09:00	0.29652	0.32130
09/30/2025 10:00	0.29844	0.32292
09/30/2025 11:00	0.29958	0.32352
09/30/2025 12:00	0.30024	0.32376
09/30/2025 13:00	0.29940	0.32304
09/30/2025 14:00	0.26178	0.28170
09/30/2025 15:00	0.29814	0.32154
09/30/2025 16:00	0.30696	0.33060
09/30/2025 17:00	0.29646	0.32070
09/30/2025 18:00	0.29526	0.31968
09/30/2025 19:00	0.29508	0.32004
09/30/2025 20:00	0.29436	0.32022
09/30/2025 21:00	0.29424	0.32028
09/30/2025 22:00	0.22398	0.24036
09/30/2025 23:00	0.00000	0.00000
Average/Sum#:	0.29153	0.31573
Minimum:	0.22398	0.24036
Maximum:	0.31146	0.33726
%SI	4.17	4.17

AQ-51

AQ-51 The ammonia slip shall not exceed 10 ppmv @ 15% O₂ averaged over one hour. The SCR catalyst shall be replaced, repaired or otherwise reconditioned within 24 months of the ammonia slip reaching 7 ppm @ 15% O₂ averaged over 24 hours. The SCR ammonia injection grid replacement, repair or reconditioning scheduled event may be cancelled if the Project owner can demonstrate to the CPM that, subsequent to the initial exceedance, the ammonia slip consistently remains below 7 ppm @ 15% O₂ averaged over 24 hours and that the initial exceedance does not accurately indicate expected future operating conditions.

Compliance with ammonia slip limits shall be demonstrated by using the following calculation procedure:

$$\text{Ammonia slip ppmv @ 15\% O}_2 = ((a - (b \times c / 1,000,000)) \times 1,000,000 / b) \times d,$$

Where

a = ammonia injection rate (lb/hr)/17(lb/lb mol)

b = dry exhaust gas flow rate (lb/hr)/ (29(lb/lb mol)

c = change in measured NOX conc. Ppmv @ 15% O₂ across catalyst, and

d = correction factor

The correction factor shall be derived annually during compliance testing by comparing the measured and calculated ammonia slip.

Verification: The Project owner shall include the ammonia slip concentrations averaged on an hourly and 24 hour basis calculated via the protocol provided as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6. The Project owner shall notify the CPM within 10 days of an exceedance of the 7 ppm ammonia slip limit herein. The Project owner shall notify the CPM no less than 30 days prior to the scheduled date of the SCR catalyst replacement, repair or reconditioning event. If the Project owner finds that the exceedance of the 7 ppm slip limit does not accurately reflect the expected future operations provided for in this condition, the Project owner shall submit all relevant information to the CPM no less than 30 days prior to the scheduled date of the SCR catalyst replacement, repair or reconditioning event in order to cancel the event.

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/01/2025 00:00	1	1.2	8.7	14.5	22.5	876,645.6	0.00	1.00
07/01/2025 01:00	1	1.3	8.5	14.6	20.3	909,906.4	0.00	1.00
07/01/2025 02:00	1	1.4	8.9	14.6	20.7	931,643.3	0.00	1.00
07/01/2025 03:00	0	1.4	8.7	14.6	21.8	932,078.1	0.00	1.00
07/01/2025 04:00	1	1.3	8.6	14.6	24.2	931,860.7	0.00	1.00
07/01/2025 05:00	1	1.2	8.9	14.4	19.4	771,934.0	0.00	1.00
07/01/2025 06:00	1	1.3	8.6	14.4	17.8	760,767.9	0.00	1.00
07/01/2025 07:00	1	1.3	8.6	14.4	17.9	761,400.0	0.00	1.00
07/01/2025 08:00	1	1.3	8.6	14.4	17.9	759,925.2	0.00	1.00
07/01/2025 09:00	1	1.2	8.6	14.5	18.3	775,864.5	0.00	1.00
07/01/2025 10:00	1	1.3	8.4	14.5	18.2	787,205.0	0.00	1.00
07/01/2025 11:00	1	1.2	8.1	14.6	17.7	831,218.9	0.00	1.00
07/01/2025 12:00	0	1.4	8.2	14.6	17.9	937,512.3	0.00	1.00
07/01/2025 13:00	1	1.3	8.2	14.6	21.1	952,728.1	0.00	1.00
07/01/2025 14:00	1	1.4	8.4	14.6	24.4	951,858.6	0.00	1.00
07/01/2025 15:00	1	1.3	8.7	14.6	22.6	950,989.2	0.00	1.00
07/01/2025 16:00	1	1.2	8.4	14.5	18.7	854,392.4	0.00	1.00
07/01/2025 17:00	1	1.3	8.4	14.5	18.9	847,331.3	0.00	1.00
07/01/2025 18:00	1	1.4	8.3	14.6	20.6	950,337.0	0.00	1.00
07/01/2025 19:00	1	1.1	8.2	14.4	22.6	839,562.5	0.00	1.00
07/01/2025 20:00	1	1.2	8.2	14.4	18.4	814,280.8	0.00	1.00
07/01/2025 21:00	1	1.2	8.4	14.4	20.8	863,369.4	0.00	1.00
07/01/2025 22:00	1	1.1	8.3	14.3	18.6	767,707.6	0.00	1.00
07/01/2025 23:00	1	1.3	8.5	14.5	21.4	913,876.8	0.00	1.00
Average/Sum#:	1	1.3	8.5	14.5	20.1	861,433.2	0.00 #	24.00 #
Minimum:	0	1.1	8.1	14.3	17.7	759,925.2	0.00	1.00
Maximum:	1	1.4	8.9	14.6	24.4	952,728.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/02/2025 00:00	1	1.3	9.7	14.3	23.1	752,353.5	0.00	1.00
07/02/2025 01:00	1	1.3	10.4	14.3	23.3	750,278.6	0.00	1.00
07/02/2025 02:00	1	1.1	11.1	14.3	28.9	749,863.6	0.00	1.00
07/02/2025 03:00	1	1.5	10.9	14.3	23.6	749,656.1	0.00	1.00
07/02/2025 04:00	1	1.4	10.7	14.3	24.3	750,693.5	0.00	1.00
07/02/2025 05:00	1	1.3	10.7	14.3	27.9	750,071.1	0.00	1.00
07/02/2025 06:00	1	1.3	10.7	14.3	24.7	750,071.1	0.00	1.00
07/02/2025 07:00	1	1.3	10.6	14.4	25.7	760,978.6	0.00	1.00
07/02/2025 08:00	1	1.3	10.7	14.4	26.6	759,714.5	0.00	1.00
07/02/2025 09:00	1	1.3	10.6	14.4	25.0	758,239.7	0.00	1.00
07/02/2025 10:00	1	1.4	10.6	14.4	24.8	757,397.0	0.00	1.00
07/02/2025 11:00	1	1.0	9.1	14.5	20.6	771,371.1	0.00	1.00
07/02/2025 12:00	1	1.1	8.1	14.5	17.6	771,799.0	0.00	1.00
07/02/2025 13:00	1	1.0	8.0	14.5	17.6	771,157.1	0.00	1.00
07/02/2025 14:00	1	1.0	8.0	14.5	17.8	794,908.1	0.00	1.00
07/02/2025 15:00	0	1.3	8.1	14.6	17.9	941,424.9	0.00	1.00
07/02/2025 16:00	1	1.2	8.2	14.4	18.1	765,613.6	0.00	1.00
07/02/2025 17:00	1	1.0	7.9	14.5	17.8	769,445.3	0.00	1.00
07/02/2025 18:00	1	1.2	8.2	14.5	18.0	833,851.1	0.00	1.00
07/02/2025 19:00	1	1.2	8.2	14.5	17.7	764,951.9	0.00	1.00
07/02/2025 20:00	1	1.2	9.8	14.4	22.6	753,815.5	0.00	1.00
07/02/2025 21:00	1	1.3	10.5	14.4	25.8	754,658.2	0.00	1.00
07/02/2025 22:00	1	1.2	10.6	14.4	25.1	755,290.2	0.00	1.00
07/02/2025 23:00	1	1.4	10.7	14.4	25.2	756,132.9	0.00	1.00
Average/Sum#:	1	1.2	9.7	14.4	22.5	770,572.3	0.00 #	24.00 #
Minimum:	0	1.0	7.9	14.3	17.6	749,656.1	0.00	1.00
Maximum:	1	1.5	11.1	14.6	28.9	941,424.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/03/2025 00:00	1	1.3	10.8	14.4	26.1	756,765.0	0.00	1.00
07/03/2025 01:00	1	1.3	10.7	14.4	26.7	757,397.0	0.00	1.00
07/03/2025 02:00	1	1.0	9.6	14.4	21.2	757,818.4	0.00	1.00
07/03/2025 03:00	1	1.3	9.0	14.3	18.5	746,958.8	0.00	1.00
07/03/2025 04:00	1	1.3	8.9	14.3	18.0	746,958.8	0.00	1.00
07/03/2025 05:00	1	1.4	9.1	14.3	18.3	747,788.7	0.00	1.00
07/03/2025 06:00	1	1.4	8.9	14.4	18.4	757,607.7	0.00	1.00
07/03/2025 07:00	1	1.4	9.0	14.4	18.4	757,607.7	0.00	1.00
07/03/2025 08:00	1	1.4	8.8	14.4	17.9	756,975.7	0.00	1.00
07/03/2025 09:00	1	1.4	8.8	14.4	17.9	755,922.3	0.00	1.00
07/03/2025 10:00	1	1.4	8.7	14.4	17.9	754,658.2	0.00	1.00
07/03/2025 11:00	1	1.3	8.7	14.5	17.7	768,803.4	0.00	1.00
07/03/2025 12:00	1	1.3	8.6	14.5	17.6	768,589.4	0.00	1.00
07/03/2025 13:00	1	1.3	8.6	14.5	17.6	768,803.4	0.00	1.00
07/03/2025 14:00	1	1.3	8.8	14.5	17.7	768,161.5	0.00	1.00
07/03/2025 15:00	1	1.4	8.8	14.5	17.8	767,091.6	0.00	1.00
07/03/2025 16:00	1	1.4	8.7	14.5	17.8	767,091.6	0.00	1.00
07/03/2025 17:00	1	1.4	8.6	14.5	17.7	766,235.7	0.00	1.00
07/03/2025 18:00	1	1.4	8.6	14.5	17.5	766,449.7	0.00	1.00
07/03/2025 19:00	1	1.4	8.7	14.4	17.3	755,922.3	0.00	1.00
07/03/2025 20:00	1	1.5	8.7	14.4	17.3	756,554.3	0.00	1.00
07/03/2025 21:00	1	1.5	8.7	14.4	17.4	757,607.7	0.00	1.00
07/03/2025 22:00	1	1.5	8.8	14.4	17.5	758,661.1	0.00	1.00
07/03/2025 23:00	1	1.5	8.9	14.3	17.4	748,826.2	0.00	1.00
Average/Sum#:	1	1.4	9.0	14.4	18.7	758,969.0	0.00 #	24.00 #
Minimum:	1	1.0	8.6	14.3	17.3	746,958.8	0.00	1.00
Maximum:	1	1.5	10.8	14.5	26.7	768,803.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/04/2025 00:00	1	1.3	9.3	14.5	25.3	862,523.4	0.00	1.00
07/04/2025 01:00	1	1.4	8.9	14.3	18.1	731,812.1	0.00	1.00
07/04/2025 02:00	1	1.4	9.4	14.4	20.3	773,408.8	0.00	1.00
07/04/2025 03:00	1	1.5	9.3	14.3	18.9	727,869.8	0.00	1.00
07/04/2025 04:00	1	1.5	9.2	14.3	17.9	728,284.8	0.00	1.00
07/04/2025 05:00	1	1.5	9.2	14.3	18.2	728,492.3	0.00	1.00
07/04/2025 06:00	1	1.5	9.2	14.3	18.6	727,869.8	0.00	1.00
07/04/2025 07:00	1	1.5	9.2	14.4	18.7	739,067.8	0.00	1.00
07/04/2025 08:00	1	1.5	9.1	14.4	18.5	737,803.7	0.00	1.00
07/04/2025 09:00	1	1.5	9.0	14.4	18.0	736,961.0	0.00	1.00
07/04/2025 10:00	1	1.5	9.0	14.4	17.9	735,907.6	0.00	1.00
07/04/2025 11:00	1	1.5	8.9	14.5	18.1	749,759.9	0.00	1.00
07/04/2025 12:00	1	1.5	8.8	14.5	17.9	749,759.9	0.00	1.00
07/04/2025 13:00	1	1.5	8.9	14.5	17.7	749,545.9	0.00	1.00
07/04/2025 14:00	1	1.5	9.0	14.5	17.8	748,904.0	0.00	1.00
07/04/2025 15:00	1	1.5	9.0	14.5	18.0	748,476.0	0.00	1.00
07/04/2025 16:00	1	1.5	8.9	14.5	18.1	748,690.0	0.00	1.00
07/04/2025 17:00	1	1.5	8.9	14.5	19.6	766,663.7	0.00	1.00
07/04/2025 18:00	1	1.2	9.3	14.6	23.6	820,350.4	0.00	1.00
07/04/2025 19:00	1	1.1	9.2	14.4	21.2	736,329.0	0.00	1.00
07/04/2025 20:00	1	1.5	9.0	14.4	17.8	737,382.4	0.00	1.00
07/04/2025 21:00	1	1.5	9.1	14.4	18.7	739,067.8	0.00	1.00
07/04/2025 22:00	1	1.3	9.1	14.4	19.6	739,067.8	0.00	1.00
07/04/2025 23:00	1	1.5	9.1	14.3	18.1	728,699.8	0.00	1.00
Average/Sum#:	1	1.4	9.1	14.4	19.0	749,695.7	0.00 #	24.00 #
Minimum:	1	1.1	8.8	14.3	17.7	727,869.8	0.00	1.00
Maximum:	1	1.5	9.4	14.6	25.3	862,523.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/05/2025 00:00	1	1.5	9.2	14.3	20.2	729,322.2	0.00	1.00
07/05/2025 01:00	1	1.4	9.5	14.3	19.0	730,359.7	0.00	1.00
07/05/2025 02:00	1	1.4	9.9	14.3	21.1	731,189.6	0.00	1.00
07/05/2025 03:00	1	1.6	9.7	14.3	19.8	731,189.6	0.00	1.00
07/05/2025 04:00	1	1.4	9.6	14.3	21.4	731,604.6	0.00	1.00
07/05/2025 05:00	1	1.4	9.6	14.3	23.6	731,812.1	0.00	1.00
07/05/2025 06:00	1	1.3	10.0	14.3	23.2	731,812.1	0.00	1.00
07/05/2025 07:00	1	1.4	10.1	14.3	22.3	732,434.6	0.00	1.00
07/05/2025 08:00	1	1.4	9.9	14.3	21.8	730,359.7	0.00	1.00
07/05/2025 09:00	1	1.5	9.4	14.4	18.1	740,331.9	0.00	1.00
07/05/2025 10:00	1	1.4	9.4	14.4	21.1	739,278.5	0.00	1.00
07/05/2025 11:00	1	1.5	9.0	14.4	18.1	739,489.2	0.00	1.00
07/05/2025 12:00	1	1.5	8.8	14.5	18.0	751,043.7	0.00	1.00
07/05/2025 13:00	1	1.4	8.8	14.5	17.9	751,899.6	0.00	1.00
07/05/2025 14:00	1	1.4	9.0	14.5	18.0	751,257.7	0.00	1.00
07/05/2025 15:00	1	1.5	9.3	14.5	18.1	749,545.9	0.00	1.00
07/05/2025 16:00	1	1.5	9.2	14.5	18.1	748,904.0	0.00	1.00
07/05/2025 17:00	1	1.5	9.1	14.5	18.0	748,048.1	0.00	1.00
07/05/2025 18:00	1	1.4	9.2	14.6	23.4	824,480.4	0.00	1.00
07/05/2025 19:00	1	1.2	9.2	14.5	19.2	745,908.3	0.00	1.00
07/05/2025 20:00	1	1.4	9.0	14.5	17.8	746,122.3	0.00	1.00
07/05/2025 21:00	1	1.4	8.9	14.4	18.2	735,696.9	0.00	1.00
07/05/2025 22:00	1	1.4	8.8	14.4	18.0	736,539.6	0.00	1.00
07/05/2025 23:00	1	1.4	8.8	14.4	17.9	736,750.3	0.00	1.00
Average/Sum#:	1	1.4	9.3	14.4	19.7	742,724.2	0.00 #	24.00 #
Minimum:	1	1.2	8.8	14.3	17.8	729,322.2	0.00	1.00
Maximum:	1	1.6	10.1	14.6	23.6	824,480.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/06/2025 00:00	1	1.4	8.8	14.4	18.0	737,593.0	0.00	1.00
07/06/2025 01:00	1	1.4	8.9	14.4	18.0	738,646.4	0.00	1.00
07/06/2025 02:00	1	1.4	9.4	14.4	18.4	738,646.4	0.00	1.00
07/06/2025 03:00	1	1.3	9.4	14.3	22.0	727,869.8	0.00	1.00
07/06/2025 04:00	2	1.3	11.2	14.3	28.3	728,699.8	0.00	1.00
07/06/2025 05:00	1	1.3	11.2	14.3	27.8	729,322.2	0.00	1.00
07/06/2025 06:00	1	1.4	11.4	14.3	27.1	728,907.3	0.00	1.00
07/06/2025 07:00	1	1.4	11.3	14.4	27.2	739,489.2	0.00	1.00
07/06/2025 08:00	1	1.3	9.3	14.4	19.6	737,803.7	0.00	1.00
07/06/2025 09:00	1	1.4	9.0	14.4	18.4	736,329.0	0.00	1.00
07/06/2025 10:00	1	1.4	8.9	14.5	18.3	745,694.4	0.00	1.00
07/06/2025 11:00	1	1.4	8.9	14.5	18.6	748,048.1	0.00	1.00
07/06/2025 12:00	1	1.3	8.7	14.5	18.1	747,406.2	0.00	1.00
07/06/2025 13:00	1	1.3	8.7	14.5	18.4	757,248.9	0.00	1.00
07/06/2025 14:00	1	1.3	8.9	14.6	18.7	802,743.5	0.00	1.00
07/06/2025 15:00	1	1.4	9.2	14.5	18.7	746,978.2	0.00	1.00
07/06/2025 16:00	1	1.4	8.9	14.6	21.0	824,263.1	0.00	1.00
07/06/2025 17:00	1	1.2	8.8	14.5	20.0	825,934.1	0.00	1.00
07/06/2025 18:00	1	1.2	8.9	14.6	26.8	920,557.5	0.00	1.00
07/06/2025 19:00	1	1.3	8.6	14.6	23.2	927,948.0	0.00	1.00
07/06/2025 20:00	1	1.3	8.5	14.6	21.8	927,078.6	0.00	1.00
07/06/2025 21:00	1	1.3	8.6	14.6	23.9	920,340.1	0.00	1.00
07/06/2025 22:00	1	1.3	8.7	14.4	18.9	791,527.3	0.00	1.00
07/06/2025 23:00	1	1.3	8.5	14.5	21.6	884,776.5	0.00	1.00
Average/Sum#:	1	1.3	9.3	14.5	21.4	788,077.1	0.00 #	24.00 #
Minimum:	1	1.2	8.5	14.3	18.0	727,869.8	0.00	1.00
Maximum:	2	1.4	11.4	14.6	28.3	927,948.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/07/2025 00:00	1	1.3	8.6	14.4	21.9	828,817.8	0.00	1.00
07/07/2025 01:00	1	1.2	8.6	14.4	18.4	735,064.9	0.00	1.00
07/07/2025 02:00	1	1.3	9.2	14.4	18.5	734,854.2	0.00	1.00
07/07/2025 03:00	1	1.4	9.0	14.5	19.3	777,576.3	0.00	1.00
07/07/2025 04:00	1	1.3	9.2	14.4	20.3	736,961.0	0.00	1.00
07/07/2025 05:00	1	1.4	9.0	14.4	18.7	737,171.7	0.00	1.00
07/07/2025 06:00	1	1.4	9.0	14.4	19.1	736,539.6	0.00	1.00
07/07/2025 07:00	1	1.3	8.9	14.4	19.2	736,750.3	0.00	1.00
07/07/2025 08:00	1	1.3	8.8	14.4	18.7	735,696.9	0.00	1.00
07/07/2025 09:00	1	1.3	8.8	14.4	18.6	734,011.5	0.00	1.00
07/07/2025 10:00	1	1.4	8.8	14.5	18.5	744,624.5	0.00	1.00
07/07/2025 11:00	1	1.4	9.4	14.5	22.8	746,122.3	0.00	1.00
07/07/2025 12:00	1	1.1	9.2	14.5	21.2	761,314.4	0.00	1.00
07/07/2025 13:00	1	1.1	8.2	14.4	18.3	771,301.9	0.00	1.00
07/07/2025 14:00	1	1.3	8.6	14.5	20.0	836,632.7	0.00	1.00
07/07/2025 15:00	1	1.0	8.7	14.4	20.8	742,438.7	0.00	1.00
07/07/2025 16:00	1	1.2	8.9	14.6	20.7	806,438.8	0.00	1.00
07/07/2025 17:00	1	1.3	8.7	14.5	20.5	847,117.4	0.00	1.00
07/07/2025 18:00	1	1.4	8.4	14.6	20.9	927,730.7	0.00	1.00
07/07/2025 19:00	1	1.4	8.3	14.6	21.4	924,252.8	0.00	1.00
07/07/2025 20:00	1	1.4	8.3	14.5	21.2	909,811.3	0.00	1.00
07/07/2025 21:00	1	1.3	8.5	14.4	22.9	854,099.5	0.00	1.00
07/07/2025 22:00	1	1.2	8.5	14.4	21.0	815,334.2	0.00	1.00
07/07/2025 23:00	1	1.3	8.5	14.5	23.1	910,025.3	0.00	1.00
Average/Sum#:	1	1.3	8.8	14.5	20.3	795,445.4	0.00 #	24.00 #
Minimum:	1	1.0	8.2	14.4	18.3	734,011.5	0.00	1.00
Maximum:	1	1.4	9.4	14.6	23.1	927,730.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/08/2025 00:00	1	1.3	8.6	14.5	22.4	911,737.1	0.00	1.00
07/08/2025 01:00	1	1.3	8.8	14.5	24.9	910,025.3	0.00	1.00
07/08/2025 02:00	1	1.2	9.3	14.5	26.3	910,239.3	0.00	1.00
07/08/2025 03:00	1	1.5	9.6	14.3	22.0	737,206.8	0.00	1.00
07/08/2025 04:00	1	1.2	9.2	14.4	25.7	841,247.9	0.00	1.00
07/08/2025 05:00	1	1.3	9.4	14.4	22.4	798,901.1	0.00	1.00
07/08/2025 06:00	1	1.4	9.3	14.3	19.6	727,869.8	0.00	1.00
07/08/2025 07:00	1	1.5	9.2	14.4	19.8	738,857.1	0.00	1.00
07/08/2025 08:00	1	1.5	9.2	14.4	19.5	737,382.4	0.00	1.00
07/08/2025 09:00	1	1.5	9.2	14.4	18.9	736,539.6	0.00	1.00
07/08/2025 10:00	1	1.4	10.8	14.4	27.5	735,275.6	0.00	1.00
07/08/2025 11:00	2	1.3	11.3	14.5	29.8	748,476.0	0.00	1.00
07/08/2025 12:00	1	1.3	10.9	14.5	25.7	748,476.0	0.00	1.00
07/08/2025 13:00	1	1.2	9.3	14.5	21.3	748,048.1	0.00	1.00
07/08/2025 14:00	1	1.2	8.7	14.5	18.3	747,192.2	0.00	1.00
07/08/2025 15:00	1	1.3	8.8	14.5	18.3	746,550.3	0.00	1.00
07/08/2025 16:00	1	1.3	8.9	14.5	18.3	746,122.3	0.00	1.00
07/08/2025 17:00	1	1.4	8.9	14.5	18.3	763,026.1	0.00	1.00
07/08/2025 18:00	1	1.2	9.1	14.6	26.8	867,954.2	0.00	1.00
07/08/2025 19:00	1	1.2	9.0	14.5	21.6	834,065.0	0.00	1.00
07/08/2025 20:00	1	1.4	9.2	14.4	19.0	747,916.4	0.00	1.00
07/08/2025 21:00	1	1.6	9.0	14.4	17.1	734,854.2	0.00	1.00
07/08/2025 22:00	1	1.3	8.9	14.4	20.6	740,963.9	0.00	1.00
07/08/2025 23:00	1	1.3	9.0	14.4	20.0	762,032.0	0.00	1.00
Average/Sum#:	1	1.3	9.3	14.4	21.8	780,039.9	0.00 #	24.00 #
Minimum:	1	1.2	8.6	14.3	17.1	727,869.8	0.00	1.00
Maximum:	2	1.6	11.3	14.6	29.8	911,737.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/09/2025 00:00	1	1.5	8.9	14.3	16.8	727,039.9	0.00	1.00
07/09/2025 01:00	1	1.6	8.9	14.3	16.9	728,284.8	0.00	1.00
07/09/2025 02:00	1	1.6	9.6	14.3	21.0	729,529.7	0.00	1.00
07/09/2025 03:00	1	1.4	9.4	14.3	19.3	729,737.2	0.00	1.00
07/09/2025 04:00	1	1.4	9.4	14.3	21.4	730,152.2	0.00	1.00
07/09/2025 05:00	1	1.3	9.4	14.3	22.1	734,716.9	0.00	1.00
07/09/2025 06:00	1	1.5	9.4	14.3	26.0	728,907.3	0.00	1.00
07/09/2025 07:00	1	1.0	9.3	14.3	17.8	729,114.7	0.00	1.00
07/09/2025 08:00	1	1.6	9.2	14.3	18.2	727,869.8	0.00	1.00
07/09/2025 09:00	1	1.4	9.2	14.4	17.9	738,435.8	0.00	1.00
07/09/2025 10:00	1	1.3	9.1	14.4	20.2	736,750.3	0.00	1.00
07/09/2025 11:00	1	1.5	8.7	14.4	16.4	736,750.3	0.00	1.00
07/09/2025 12:00	1	1.6	8.6	14.5	16.0	749,117.9	0.00	1.00
07/09/2025 13:00	1	1.5	8.7	14.5	16.3	747,834.1	0.00	1.00
07/09/2025 14:00	1	1.3	8.7	14.5	20.0	746,336.3	0.00	1.00
07/09/2025 15:00	1	1.4	8.8	14.5	16.2	745,480.4	0.00	1.00
07/09/2025 16:00	1	1.4	8.7	14.5	18.8	773,082.9	0.00	1.00
07/09/2025 17:00	1	1.4	8.5	14.4	18.3	774,040.8	0.00	1.00
07/09/2025 18:00	1	1.3	8.4	14.5	20.2	873,863.9	0.00	1.00
07/09/2025 19:00	1	1.3	8.4	14.6	22.2	906,428.5	0.00	1.00
07/09/2025 20:00	1	1.2	8.6	14.4	20.6	806,274.9	0.00	1.00
07/09/2025 21:00	1	1.3	8.4	14.5	21.8	881,566.9	0.00	1.00
07/09/2025 22:00	1	1.2	8.4	14.4	21.5	827,343.0	0.00	1.00
07/09/2025 23:00	1	1.3	8.5	14.4	20.7	850,517.9	0.00	1.00
Average/Sum#:	1	1.4	8.9	14.4	19.4	769,132.4	0.00 #	24.00 #
Minimum:	1	1.0	8.4	14.3	16.0	727,039.9	0.00	1.00
Maximum:	1	1.6	9.6	14.6	26.0	906,428.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/10/2025 00:00	1	1.3	8.6	14.3	17.0	731,397.1	0.00	1.00
07/10/2025 01:00	1	1.5	9.6	14.3	20.9	727,869.8	0.00	1.00
07/10/2025 02:00	1	1.3	11.0	14.3	26.3	726,002.4	0.00	1.00
07/10/2025 03:00	1	1.3	9.4	14.3	20.9	741,771.5	0.00	1.00
07/10/2025 04:00	1	1.5	9.1	14.3	20.2	758,785.6	0.00	1.00
07/10/2025 05:00	1	1.1	9.1	14.3	22.0	744,053.9	0.00	1.00
07/10/2025 06:00	1	1.4	8.8	14.3	17.4	725,587.4	0.00	1.00
07/10/2025 07:00	1	1.5	8.7	14.4	17.0	736,329.0	0.00	1.00
07/10/2025 08:00	1	1.5	8.6	14.4	16.3	734,222.2	0.00	1.00
07/10/2025 09:00	1	1.5	8.7	14.4	16.3	732,747.4	0.00	1.00
07/10/2025 10:00	1	1.5	8.6	14.5	16.9	743,768.6	0.00	1.00
07/10/2025 11:00	1	1.5	8.5	14.5	16.4	746,122.3	0.00	1.00
07/10/2025 12:00	1	1.5	8.3	14.5	16.1	746,122.3	0.00	1.00
07/10/2025 13:00	1	1.4	8.4	14.5	15.9	746,122.3	0.00	1.00
07/10/2025 14:00	1	1.4	8.2	14.6	16.1	787,527.7	0.00	1.00
07/10/2025 15:00	1	1.4	8.5	14.5	18.6	798,331.6	0.00	1.00
07/10/2025 16:00	1	1.3	8.6	14.5	17.0	751,257.7	0.00	1.00
07/10/2025 17:00	1	1.3	8.3	14.6	22.8	916,210.1	0.00	1.00
07/10/2025 18:00	1	1.3	8.2	14.6	20.4	914,688.5	0.00	1.00
07/10/2025 19:00	1	1.3	8.2	14.6	19.1	913,601.7	0.00	1.00
07/10/2025 20:00	1	1.2	8.1	14.5	22.2	875,789.7	0.00	1.00
07/10/2025 21:00	1	1.4	7.9	14.6	18.1	910,558.5	0.00	1.00
07/10/2025 22:00	1	1.3	7.9	14.5	19.6	892,907.5	0.00	1.00
07/10/2025 23:00	1	1.4	8.1	14.5	19.3	863,165.3	0.00	1.00
Average/Sum#:	1	1.4	8.6	14.5	18.9	790,205.8	0.00 #	24.00 #
Minimum:	1	1.1	7.9	14.3	15.9	725,587.4	0.00	1.00
Maximum:	1	1.5	11.0	14.6	26.3	916,210.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/11/2025 00:00	1	1.4	8.4	14.4	15.9	734,011.5	0.00	1.00
07/11/2025 01:00	1	1.5	8.5	14.4	15.8	734,643.5	0.00	1.00
07/11/2025 02:00	1	1.5	9.0	14.4	16.1	735,907.6	0.00	1.00
07/11/2025 03:00	1	1.5	8.9	14.5	21.0	817,161.2	0.00	1.00
07/11/2025 04:00	1	1.2	8.9	14.6	22.6	886,647.9	0.00	1.00
07/11/2025 05:00	1	1.3	9.2	14.5	23.2	809,458.2	0.00	1.00
07/11/2025 06:00	1	1.2	9.1	14.4	20.3	738,435.8	0.00	1.00
07/11/2025 07:00	1	1.3	8.7	14.4	17.3	734,643.5	0.00	1.00
07/11/2025 08:00	1	1.4	8.6	14.4	17.0	733,800.8	0.00	1.00
07/11/2025 09:00	1	1.4	8.5	14.5	16.8	743,768.6	0.00	1.00
07/11/2025 10:00	1	1.4	8.2	14.6	17.5	826,654.1	0.00	1.00
07/11/2025 11:00	1	1.4	8.1	14.6	20.9	919,470.7	0.00	1.00
07/11/2025 12:00	1	1.3	8.2	14.5	18.9	866,374.9	0.00	1.00
07/11/2025 13:00	1	1.3	8.4	14.6	21.9	920,557.5	0.00	1.00
07/11/2025 14:00	1	1.3	8.6	14.6	22.1	918,383.8	0.00	1.00
07/11/2025 15:00	1	1.3	8.6	14.6	23.4	915,775.4	0.00	1.00
07/11/2025 16:00	1	1.4	8.5	14.5	19.6	861,881.5	0.00	1.00
07/11/2025 17:00	1	1.4	8.8	14.4	22.6	891,600.6	0.00	1.00
07/11/2025 18:00	2	2.2	14.3	12.1	40.8	923,116.5	0.00	1.00
07/11/2025 19:00	3	2.2	15.1	11.7	48.9	924,212.6	0.00	1.00
07/11/2025 20:00	2	1.7	12.6	12.8	36.0	917,852.5	0.00	1.00
07/11/2025 21:00	2	2.0	13.6	12.3	37.7	913,055.7	0.00	1.00
07/11/2025 22:00	1	1.5	10.0	13.6	26.7	916,576.4	0.00	1.00
07/11/2025 23:00	1	1.7	11.7	13.2	31.1	925,161.8	0.00	1.00
Average/Sum#:	1	1.5	9.7	14.0	23.9	846,214.7	0.00 #	24.00 #
Minimum:	1	1.2	8.1	11.7	15.8	733,800.8	0.00	1.00
Maximum:	3	2.2	15.1	14.6	48.9	925,161.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/12/2025 00:00	1	1.2	8.6	14.4	22.1	796,162.3	0.00	1.00
07/12/2025 01:00	1	1.2	8.5	14.4	18.6	733,379.4	0.00	1.00
07/12/2025 02:00	1	1.2	9.0	14.4	18.6	734,011.5	0.00	1.00
07/12/2025 03:00	1	1.3	8.8	14.4	18.9	734,643.5	0.00	1.00
07/12/2025 04:00	1	1.2	8.7	14.4	19.1	735,907.6	0.00	1.00
07/12/2025 05:00	1	1.2	8.6	14.4	19.4	735,275.6	0.00	1.00
07/12/2025 06:00	1	1.2	8.7	14.4	19.9	734,643.5	0.00	1.00
07/12/2025 07:00	1	1.1	8.6	14.4	19.4	734,643.5	0.00	1.00
07/12/2025 08:00	1	1.1	8.5	14.4	19.1	733,590.1	0.00	1.00
07/12/2025 09:00	1	1.1	8.5	14.4	18.8	732,958.1	0.00	1.00
07/12/2025 10:00	1	1.2	8.5	14.5	18.8	744,196.6	0.00	1.00
07/12/2025 11:00	1	1.1	8.3	14.5	18.8	745,694.4	0.00	1.00
07/12/2025 12:00	1	1.1	8.0	14.5	18.6	745,908.3	0.00	1.00
07/12/2025 13:00	1	1.0	7.9	14.5	18.6	746,978.2	0.00	1.00
07/12/2025 14:00	1	1.1	7.9	14.6	18.7	866,867.4	0.00	1.00
07/12/2025 15:00	1	1.2	8.1	14.5	18.8	827,217.9	0.00	1.00
07/12/2025 16:00	1	1.2	8.1	14.5	18.9	811,170.0	0.00	1.00
07/12/2025 17:00	1	1.2	8.1	14.5	18.8	811,383.9	0.00	1.00
07/12/2025 18:00	1	1.4	8.4	14.5	19.7	852,038.7	0.00	1.00
07/12/2025 19:00	1	1.3	8.6	14.5	22.2	900,824.5	0.00	1.00
07/12/2025 20:00	1	1.2	8.3	14.4	19.3	792,370.0	0.00	1.00
07/12/2025 21:00	1	1.1	8.3	14.3	18.6	734,509.4	0.00	1.00
07/12/2025 22:00	1	1.2	8.3	14.3	18.5	749,656.1	0.00	1.00
07/12/2025 23:00	1	1.4	8.2	14.5	18.5	911,309.1	0.00	1.00
Average/Sum#:	1	1.2	8.4	14.4	19.2	776,889.2	0.00 #	24.00 #
Minimum:	1	1.0	7.9	14.3	18.5	732,958.1	0.00	1.00
Maximum:	1	1.4	9.0	14.6	22.2	911,309.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/13/2025 00:00	1	1.4	8.6	14.4	21.2	832,610.0	0.00	1.00
07/13/2025 01:00	1	1.3	8.8	14.5	21.3	860,383.7	0.00	1.00
07/13/2025 02:00	1	1.1	9.1	14.6	27.8	926,209.1	0.00	1.00
07/13/2025 03:00	1	1.3	9.1	14.4	20.9	784,153.5	0.00	1.00
07/13/2025 04:00	1	1.2	8.9	14.4	21.5	762,874.7	0.00	1.00
07/13/2025 05:00	1	1.3	9.1	14.4	20.2	766,877.7	0.00	1.00
07/13/2025 06:00	1	1.2	8.8	14.3	19.7	724,342.5	0.00	1.00
07/13/2025 07:00	1	1.3	9.8	14.3	25.0	724,965.0	0.00	1.00
07/13/2025 08:00	1	1.3	10.8	14.4	25.7	735,064.9	0.00	1.00
07/13/2025 09:00	1	1.4	10.8	14.4	25.0	733,590.1	0.00	1.00
07/13/2025 10:00	1	1.3	10.7	14.4	27.3	733,168.7	0.00	1.00
07/13/2025 11:00	1	1.3	10.6	14.5	25.1	746,550.3	0.00	1.00
07/13/2025 12:00	1	1.1	8.2	14.5	18.6	762,598.2	0.00	1.00
07/13/2025 13:00	1	1.3	8.1	14.6	18.5	906,211.2	0.00	1.00
07/13/2025 14:00	1	1.5	8.3	14.6	18.5	923,600.7	0.00	1.00
07/13/2025 15:00	1	1.3	8.4	14.6	23.3	923,383.3	0.00	1.00
07/13/2025 16:00	1	1.4	8.4	14.6	21.1	921,644.3	0.00	1.00
07/13/2025 17:00	1	1.3	8.2	14.5	19.2	854,606.4	0.00	1.00
07/13/2025 18:00	1	1.3	8.5	14.6	24.0	928,382.8	0.00	1.00
07/13/2025 19:00	1	1.4	8.4	14.6	21.1	926,426.5	0.00	1.00
07/13/2025 20:00	1	1.5	8.0	14.6	18.4	926,209.1	0.00	1.00
07/13/2025 21:00	1	1.5	8.1	14.6	21.3	914,905.9	0.00	1.00
07/13/2025 22:00	1	1.2	8.4	14.4	21.6	846,936.3	0.00	1.00
07/13/2025 23:00	1	1.4	8.5	14.5	22.3	894,191.3	0.00	1.00
Average/Sum#:	1	1.3	8.9	14.5	22.0	835,828.6	0.00 #	24.00 #
Minimum:	1	1.1	8.0	14.3	18.4	724,342.5	0.00	1.00
Maximum:	1	1.5	10.8	14.6	27.8	928,382.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/14/2025 00:00	1	1.3	8.8	14.4	22.9	853,888.8	0.00	1.00
07/14/2025 01:00	1	1.2	8.9	14.3	19.6	735,131.9	0.00	1.00
07/14/2025 02:00	1	1.2	9.2	14.3	19.4	727,039.9	0.00	1.00
07/14/2025 03:00	1	1.3	9.2	14.3	20.7	731,397.1	0.00	1.00
07/14/2025 04:00	1	1.3	9.1	14.5	22.2	839,414.4	0.00	1.00
07/14/2025 05:00	1	1.3	9.3	14.5	25.1	844,335.7	0.00	1.00
07/14/2025 06:00	1	1.3	9.1	14.4	21.4	781,625.3	0.00	1.00
07/14/2025 07:00	2	1.3	10.8	14.4	28.4	735,275.6	0.00	1.00
07/14/2025 08:00	1	1.2	11.0	14.4	26.8	733,800.8	0.00	1.00
07/14/2025 09:00	1	1.3	10.9	14.4	27.1	732,747.4	0.00	1.00
07/14/2025 10:00	1	1.2	10.3	14.5	26.3	743,126.7	0.00	1.00
07/14/2025 11:00	1	1.1	8.4	14.5	18.7	745,052.5	0.00	1.00
07/14/2025 12:00	1	1.1	8.2	14.6	18.4	757,096.1	0.00	1.00
07/14/2025 13:00	1	1.0	8.0	14.6	18.3	757,530.8	0.00	1.00
07/14/2025 14:00	1	1.0	7.9	14.6	18.7	781,876.1	0.00	1.00
07/14/2025 15:00	1	1.0	8.1	14.5	18.8	752,327.5	0.00	1.00
07/14/2025 16:00	1	0.9	7.8	14.6	18.7	764,921.3	0.00	1.00
07/14/2025 17:00	1	1.0	7.8	14.6	18.6	784,701.9	0.00	1.00
07/14/2025 18:00	1	1.1	8.3	14.5	18.6	767,091.6	0.00	1.00
07/14/2025 19:00	1	1.1	8.4	14.5	18.4	742,270.8	0.00	1.00
07/14/2025 20:00	1	1.2	8.6	14.5	18.2	742,056.8	0.00	1.00
07/14/2025 21:00	1	1.3	8.6	14.4	18.1	731,904.7	0.00	1.00
07/14/2025 22:00	1	1.2	8.6	14.4	18.5	734,222.2	0.00	1.00
07/14/2025 23:00	1	1.2	8.7	14.4	19.0	736,750.3	0.00	1.00
Average/Sum#:	1	1.2	8.9	14.5	20.9	760,649.4	0.00 #	24.00 #
Minimum:	1	0.9	7.8	14.3	18.1	727,039.9	0.00	1.00
Maximum:	2	1.3	11.0	14.6	28.4	853,888.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/15/2025 00:00	1	1.2	8.9	14.4	19.6	738,225.1	0.00	1.00
07/15/2025 01:00	1	1.2	8.8	14.3	19.4	728,077.3	0.00	1.00
07/15/2025 02:00	1	1.3	9.3	14.3	19.7	728,077.3	0.00	1.00
07/15/2025 03:00	1	1.3	9.1	14.3	19.6	729,114.7	0.00	1.00
07/15/2025 04:00	1	1.3	9.0	14.3	19.5	729,529.7	0.00	1.00
07/15/2025 05:00	1	1.3	9.0	14.3	19.1	729,322.2	0.00	1.00
07/15/2025 06:00	1	1.3	9.0	14.3	19.6	728,492.3	0.00	1.00
07/15/2025 07:00	1	1.3	8.9	14.3	19.7	728,284.8	0.00	1.00
07/15/2025 08:00	1	1.2	8.8	14.3	19.7	725,172.5	0.00	1.00
07/15/2025 09:00	1	1.2	8.7	14.4	19.2	734,011.5	0.00	1.00
07/15/2025 10:00	1	1.3	8.5	14.4	18.5	732,958.1	0.00	1.00
07/15/2025 11:00	1	1.3	8.4	14.4	18.3	734,643.5	0.00	1.00
07/15/2025 12:00	1	1.2	8.3	14.5	18.0	745,480.4	0.00	1.00
07/15/2025 13:00	1	1.2	8.3	14.5	18.0	745,694.4	0.00	1.00
07/15/2025 14:00	1	1.1	8.3	14.5	18.0	745,052.5	0.00	1.00
07/15/2025 15:00	1	1.2	8.4	14.5	18.1	743,340.7	0.00	1.00
07/15/2025 16:00	1	1.2	8.5	14.5	18.2	742,912.7	0.00	1.00
07/15/2025 17:00	1	1.3	8.4	14.5	18.3	792,554.4	0.00	1.00
07/15/2025 18:00	1	1.3	9.9	14.4	23.8	738,225.1	0.00	1.00
07/15/2025 19:00	2	1.3	11.1	14.5	30.3	741,842.9	0.00	1.00
07/15/2025 20:00	1	1.3	11.0	14.4	26.9	732,326.0	0.00	1.00
07/15/2025 21:00	1	1.0	8.8	14.4	20.8	744,545.5	0.00	1.00
07/15/2025 22:00	1	1.2	8.7	14.4	19.2	733,590.1	0.00	1.00
07/15/2025 23:00	1	1.2	8.8	14.3	19.1	723,512.5	0.00	1.00
Average/Sum#:	1	1.2	9.0	14.4	20.0	737,291.1	0.00 #	24.00 #
Minimum:	1	1.0	8.3	14.3	18.0	723,512.5	0.00	1.00
Maximum:	2	1.3	11.1	14.5	30.3	792,554.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/16/2025 00:00	1	1.3	8.8	14.3	19.0	724,135.0	0.00	1.00
07/16/2025 01:00	1	1.3	8.9	14.3	19.4	724,965.0	0.00	1.00
07/16/2025 02:00	1	1.3	9.4	14.3	19.2	725,587.4	0.00	1.00
07/16/2025 03:00	1	1.4	9.2	14.3	19.3	726,209.9	0.00	1.00
07/16/2025 04:00	1	1.4	9.0	14.3	19.2	743,431.4	0.00	1.00
07/16/2025 05:00	1	1.3	9.3	14.5	25.7	884,134.6	0.00	1.00
07/16/2025 06:00	1	1.3	9.2	14.3	19.8	726,417.4	0.00	1.00
07/16/2025 07:00	1	1.4	9.1	14.3	19.8	727,247.3	0.00	1.00
07/16/2025 08:00	1	1.4	10.6	14.3	25.1	725,794.9	0.00	1.00
07/16/2025 09:00	2	1.3	11.0	14.4	30.6	735,696.9	0.00	1.00
07/16/2025 10:00	1	1.3	10.9	14.4	27.5	734,854.2	0.00	1.00
07/16/2025 11:00	1	1.1	8.9	14.4	19.9	769,195.1	0.00	1.00
07/16/2025 12:00	1	1.2	9.2	14.5	24.0	786,563.1	0.00	1.00
07/16/2025 13:00	1	1.2	9.0	14.6	21.2	861,867.9	0.00	1.00
07/16/2025 14:00	1	1.3	8.8	14.6	19.5	807,743.0	0.00	1.00
07/16/2025 15:00	1	1.3	8.8	14.6	21.4	799,700.4	0.00	1.00
07/16/2025 16:00	1	1.2	8.8	14.5	19.5	744,838.5	0.00	1.00
07/16/2025 17:00	1	1.2	8.5	14.5	18.6	753,397.4	0.00	1.00
07/16/2025 18:00	1	1.3	8.7	14.4	19.0	733,590.1	0.00	1.00
07/16/2025 19:00	1	1.3	8.6	14.4	18.8	732,536.7	0.00	1.00
07/16/2025 20:00	1	1.3	8.7	14.4	19.0	733,379.4	0.00	1.00
07/16/2025 21:00	1	1.3	8.7	14.4	18.9	734,222.2	0.00	1.00
07/16/2025 22:00	1	1.3	8.8	14.4	18.7	734,432.8	0.00	1.00
07/16/2025 23:00	1	1.3	8.8	14.3	18.6	723,097.6	0.00	1.00
Average/Sum#:	1	1.3	9.2	14.4	20.9	753,876.6	0.00 #	24.00 #
Minimum:	1	1.1	8.5	14.3	18.6	723,097.6	0.00	1.00
Maximum:	2	1.4	11.0	14.6	30.6	884,134.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/17/2025 00:00	1	1.4	8.9	14.3	18.6	723,305.1	0.00	1.00
07/17/2025 01:00	1	1.4	8.9	14.3	18.9	729,114.7	0.00	1.00
07/17/2025 02:00	1	1.4	9.4	14.3	18.9	724,342.5	0.00	1.00
07/17/2025 03:00	1	1.3	9.5	14.3	21.8	725,379.9	0.00	1.00
07/17/2025 04:00	1	1.5	9.4	14.3	18.8	725,794.9	0.00	1.00
07/17/2025 05:00	1	1.5	9.4	14.3	19.0	725,379.9	0.00	1.00
07/17/2025 06:00	1	1.5	9.3	14.3	19.5	724,965.0	0.00	1.00
07/17/2025 07:00	1	1.5	9.2	14.3	19.6	724,757.5	0.00	1.00
07/17/2025 08:00	1	1.4	9.1	14.3	19.8	724,757.5	0.00	1.00
07/17/2025 09:00	1	1.4	8.9	14.4	19.4	737,593.0	0.00	1.00
07/17/2025 10:00	1	1.3	8.7	14.4	19.3	734,854.2	0.00	1.00
07/17/2025 11:00	1	1.2	8.5	14.4	19.2	734,011.5	0.00	1.00
07/17/2025 12:00	1	1.2	8.5	14.5	19.0	776,506.4	0.00	1.00
07/17/2025 13:00	1	1.3	8.7	14.6	22.0	866,867.4	0.00	1.00
07/17/2025 14:00	1	1.3	8.5	14.6	22.8	906,863.3	0.00	1.00
07/17/2025 15:00	1	1.2	8.6	14.6	23.8	925,774.4	0.00	1.00
07/17/2025 16:00	1	1.2	9.1	14.5	20.3	743,768.6	0.00	1.00
07/17/2025 17:00	1	1.3	8.8	14.5	21.4	791,056.6	0.00	1.00
07/17/2025 18:00	1	1.2	9.3	14.5	20.6	743,768.6	0.00	1.00
07/17/2025 19:00	1	1.5	9.2	14.5	18.5	740,987.0	0.00	1.00
07/17/2025 20:00	2	1.4	11.4	14.5	29.3	742,912.7	0.00	1.00
07/17/2025 21:00	1	1.4	11.1	14.4	26.0	732,536.7	0.00	1.00
07/17/2025 22:00	1	1.3	10.7	14.4	26.9	740,542.6	0.00	1.00
07/17/2025 23:00	1	1.3	8.9	14.5	20.8	840,484.2	0.00	1.00
Average/Sum#:	1	1.4	9.3	14.4	21.0	761,930.2	0.00 #	24.00 #
Minimum:	1	1.2	8.5	14.3	18.5	723,305.1	0.00	1.00
Maximum:	2	1.5	11.4	14.6	29.3	925,774.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/18/2025 00:00	1	1.2	8.8	14.4	20.2	741,174.6	0.00	1.00
07/18/2025 01:00	1	1.2	8.8	14.3	19.2	724,342.5	0.00	1.00
07/18/2025 02:00	1	1.3	9.3	14.3	19.1	724,965.0	0.00	1.00
07/18/2025 03:00	1	1.4	9.2	14.3	19.5	725,587.4	0.00	1.00
07/18/2025 04:00	1	1.3	9.0	14.3	20.0	743,846.4	0.00	1.00
07/18/2025 05:00	1	1.3	9.4	14.3	21.8	768,745.1	0.00	1.00
07/18/2025 06:00	1	1.3	9.1	14.3	21.0	735,754.4	0.00	1.00
07/18/2025 07:00	1	1.3	9.7	14.3	22.2	731,397.1	0.00	1.00
07/18/2025 08:00	1	1.3	10.3	14.3	26.1	730,567.2	0.00	1.00
07/18/2025 09:00	2	1.3	10.6	14.4	25.3	739,699.8	0.00	1.00
07/18/2025 10:00	2	1.2	10.2	14.4	25.2	737,803.7	0.00	1.00
07/18/2025 11:00	1	1.1	8.8	14.5	19.4	748,048.1	0.00	1.00
07/18/2025 12:00	1	1.2	8.4	14.5	18.5	745,908.3	0.00	1.00
07/18/2025 13:00	1	1.2	8.6	14.5	18.5	744,838.5	0.00	1.00
07/18/2025 14:00	1	1.2	8.7	14.5	18.6	743,554.6	0.00	1.00
07/18/2025 15:00	1	1.1	8.4	14.5	18.7	742,270.8	0.00	1.00
07/18/2025 16:00	1	1.2	8.5	14.5	18.4	741,842.9	0.00	1.00
07/18/2025 17:00	1	1.2	8.5	14.5	18.3	759,816.6	0.00	1.00
07/18/2025 18:00	2	1.3	9.6	14.4	22.1	733,379.4	0.00	1.00
07/18/2025 19:00	2	1.1	10.0	14.5	24.3	740,773.0	0.00	1.00
07/18/2025 20:00	1	1.2	8.7	14.4	18.2	730,429.9	0.00	1.00
07/18/2025 21:00	1	1.3	8.6	14.4	18.4	731,904.7	0.00	1.00
07/18/2025 22:00	1	1.3	8.6	14.4	18.5	740,753.3	0.00	1.00
07/18/2025 23:00	2	1.3	9.0	14.5	24.1	862,951.3	0.00	1.00
Average/Sum#:	1	1.2	9.1	14.4	20.7	744,598.1	0.00 #	24.00 #
Minimum:	1	1.1	8.4	14.3	18.2	724,342.5	0.00	1.00
Maximum:	2	1.4	10.6	14.5	26.1	862,951.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/19/2025 00:00	1	1.2	8.8	14.3	18.8	724,965.0	0.00	1.00
07/19/2025 01:00	1	1.3	8.9	14.3	18.8	725,172.5	0.00	1.00
07/19/2025 02:00	1	1.3	9.3	14.3	19.1	724,757.5	0.00	1.00
07/19/2025 03:00	2	1.3	9.2	14.3	20.5	725,379.9	0.00	1.00
07/19/2025 04:00	1	1.4	9.2	14.3	19.5	726,209.9	0.00	1.00
07/19/2025 05:00	3	1.4	11.1	14.3	28.9	726,624.9	0.00	1.00
07/19/2025 06:00	2	1.3	11.2	14.3	28.9	726,832.4	0.00	1.00
07/19/2025 07:00	2	1.2	10.2	14.3	23.9	726,832.4	0.00	1.00
07/19/2025 08:00	1	1.3	9.1	14.4	19.5	736,329.0	0.00	1.00
07/19/2025 09:00	1	1.4	9.1	14.4	18.9	734,854.2	0.00	1.00
07/19/2025 10:00	1	1.4	8.8	14.4	18.8	732,958.1	0.00	1.00
07/19/2025 11:00	1	1.3	8.6	14.4	18.4	734,643.5	0.00	1.00
07/19/2025 12:00	1	1.3	8.5	14.5	18.2	745,694.4	0.00	1.00
07/19/2025 13:00	1	1.3	8.6	14.5	18.1	744,838.5	0.00	1.00
07/19/2025 14:00	1	1.3	8.7	14.5	18.2	743,982.6	0.00	1.00
07/19/2025 15:00	1	1.2	8.6	14.5	18.4	743,340.7	0.00	1.00
07/19/2025 16:00	1	1.3	8.7	14.5	18.4	744,624.5	0.00	1.00
07/19/2025 17:00	1	1.3	8.6	14.5	18.3	758,746.7	0.00	1.00
07/19/2025 18:00	1	1.4	9.0	14.5	18.6	743,554.6	0.00	1.00
07/19/2025 19:00	1	1.3	8.7	14.5	18.0	740,559.0	0.00	1.00
07/19/2025 20:00	1	1.3	8.6	14.4	17.9	731,272.6	0.00	1.00
07/19/2025 21:00	1	1.3	8.6	14.4	18.3	731,272.6	0.00	1.00
07/19/2025 22:00	1	1.3	8.7	14.4	18.2	731,904.7	0.00	1.00
07/19/2025 23:00	1	1.4	8.7	14.4	18.2	732,326.0	0.00	1.00
Average/Sum#:	1	1.3	9.1	14.4	19.7	734,903.2	0.00 #	24.00 #
Minimum:	1	1.2	8.5	14.3	17.9	724,757.5	0.00	1.00
Maximum:	3	1.4	11.2	14.5	28.9	758,746.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/20/2025 00:00	1	1.4	8.7	14.3	18.2	722,060.1	0.00	1.00
07/20/2025 01:00	1	1.4	8.8	14.3	18.2	722,475.1	0.00	1.00
07/20/2025 02:00	1	1.4	9.2	14.3	18.6	722,890.1	0.00	1.00
07/20/2025 03:00	1	1.5	9.1	14.3	19.1	723,720.0	0.00	1.00
07/20/2025 04:00	2	1.4	9.5	14.3	20.8	724,757.5	0.00	1.00
07/20/2025 05:00	1	1.4	9.3	14.3	18.7	724,965.0	0.00	1.00
07/20/2025 06:00	2	1.3	9.6	14.3	22.8	725,172.5	0.00	1.00
07/20/2025 07:00	1	1.4	9.2	14.3	19.4	725,379.9	0.00	1.00
07/20/2025 08:00	1	1.4	9.1	14.3	19.3	724,550.0	0.00	1.00
07/20/2025 09:00	1	1.4	9.0	14.4	18.5	734,222.2	0.00	1.00
07/20/2025 10:00	2	1.3	9.0	14.4	20.9	732,326.0	0.00	1.00
07/20/2025 11:00	1	1.2	8.6	14.4	18.6	732,747.4	0.00	1.00
07/20/2025 12:00	1	1.3	8.4	14.5	18.2	743,554.6	0.00	1.00
07/20/2025 13:00	1	1.2	8.5	14.5	18.1	743,340.7	0.00	1.00
07/20/2025 14:00	1	1.2	8.5	14.5	18.2	742,484.8	0.00	1.00
07/20/2025 15:00	1	1.2	8.5	14.5	18.3	741,628.9	0.00	1.00
07/20/2025 16:00	1	1.2	8.4	14.5	18.3	742,056.8	0.00	1.00
07/20/2025 17:00	1	1.2	8.4	14.5	18.2	749,331.9	0.00	1.00
07/20/2025 18:00	1	1.2	8.5	14.4	18.3	731,483.3	0.00	1.00
07/20/2025 19:00	1	1.3	8.5	14.4	17.9	730,851.3	0.00	1.00
07/20/2025 20:00	1	1.3	8.6	14.4	18.3	732,536.7	0.00	1.00
07/20/2025 21:00	1	1.4	8.7	14.3	18.2	722,267.6	0.00	1.00
07/20/2025 22:00	1	1.4	8.8	14.3	18.2	722,890.1	0.00	1.00
07/20/2025 23:00	1	1.4	9.0	14.3	19.0	723,927.5	0.00	1.00
Average/Sum#:	1	1.3	8.8	14.4	18.8	730,900.8	0.00 #	24.00 #
Minimum:	1	1.2	8.4	14.3	17.9	722,060.1	0.00	1.00
Maximum:	2	1.5	9.6	14.5	22.8	749,331.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/21/2025 00:00	1	1.4	8.9	14.3	18.3	723,305.1	0.00	1.00
07/21/2025 01:00	1	1.4	9.0	14.3	18.3	723,305.1	0.00	1.00
07/21/2025 02:00	1	1.4	9.4	14.3	18.5	723,512.5	0.00	1.00
07/21/2025 03:00	1	1.5	9.2	14.3	18.9	723,927.5	0.00	1.00
07/21/2025 04:00	1	1.4	9.0	14.4	21.1	786,260.3	0.00	1.00
07/21/2025 05:00	1	1.4	9.4	14.3	21.1	771,234.9	0.00	1.00
07/21/2025 06:00	1	1.5	9.2	14.3	19.4	725,587.4	0.00	1.00
07/21/2025 07:00	1	1.5	9.1	14.3	19.1	726,002.4	0.00	1.00
07/21/2025 08:00	1	1.5	9.0	14.3	18.9	724,757.5	0.00	1.00
07/21/2025 09:00	1	1.5	9.0	14.4	18.8	734,643.5	0.00	1.00
07/21/2025 10:00	1	1.5	8.9	14.4	18.8	733,590.1	0.00	1.00
07/21/2025 11:00	1	1.4	8.6	14.4	18.9	734,222.2	0.00	1.00
07/21/2025 12:00	1	1.3	8.4	14.4	18.6	733,590.1	0.00	1.00
07/21/2025 13:00	1	1.2	8.4	14.4	18.3	733,590.1	0.00	1.00
07/21/2025 14:00	2	1.3	10.3	14.4	25.5	732,536.7	0.00	1.00
07/21/2025 15:00	2	1.3	10.6	14.4	24.4	731,272.6	0.00	1.00
07/21/2025 16:00	2	1.3	10.5	14.4	26.8	730,851.3	0.00	1.00
07/21/2025 17:00	2	1.2	10.6	14.4	25.9	730,851.3	0.00	1.00
07/21/2025 18:00	2	1.3	10.6	14.4	24.7	731,694.0	0.00	1.00
07/21/2025 19:00	2	1.3	10.7	14.4	26.9	732,536.7	0.00	1.00
07/21/2025 20:00	2	1.2	10.7	14.4	28.0	733,590.1	0.00	1.00
07/21/2025 21:00	2	1.4	10.7	14.3	25.2	723,097.6	0.00	1.00
07/21/2025 22:00	2	1.3	10.7	14.3	25.0	723,927.5	0.00	1.00
07/21/2025 23:00	2	1.4	10.7	14.3	27.6	724,342.5	0.00	1.00
Average/Sum#:	1	1.4	9.7	14.4	22.0	733,009.5	0.00 #	24.00 #
Minimum:	1	1.2	8.4	14.3	18.3	723,097.6	0.00	1.00
Maximum:	2	1.5	10.7	14.4	28.0	786,260.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/22/2025 00:00	2	1.3	10.7	14.3	24.4	725,587.4	0.00	1.00
07/22/2025 01:00	2	1.3	10.7	14.3	27.7	726,417.4	0.00	1.00
07/22/2025 02:00	2	1.5	11.2	14.3	23.7	726,624.9	0.00	1.00
07/22/2025 03:00	2	1.6	11.0	14.3	24.1	725,794.9	0.00	1.00
07/22/2025 04:00	2	1.3	10.8	14.3	28.1	724,965.0	0.00	1.00
07/22/2025 05:00	2	1.3	10.8	14.3	26.7	724,965.0	0.00	1.00
07/22/2025 06:00	2	1.3	10.8	14.3	26.1	724,965.0	0.00	1.00
07/22/2025 07:00	2	1.4	10.8	14.3	24.9	724,550.0	0.00	1.00
07/22/2025 08:00	2	1.3	10.7	14.3	28.0	724,757.5	0.00	1.00
07/22/2025 09:00	2	1.3	10.7	14.3	26.9	723,927.5	0.00	1.00
07/22/2025 10:00	2	1.4	10.8	14.4	25.2	734,432.8	0.00	1.00
07/22/2025 11:00	2	1.3	10.7	14.4	27.5	736,118.3	0.00	1.00
07/22/2025 12:00	2	1.3	10.6	14.4	24.5	736,118.3	0.00	1.00
07/22/2025 13:00	2	1.3	10.7	14.4	28.2	735,275.6	0.00	1.00
07/22/2025 14:00	2	1.2	10.9	14.5	28.2	745,480.4	0.00	1.00
07/22/2025 15:00	2	1.3	11.0	14.5	25.3	744,196.6	0.00	1.00
07/22/2025 16:00	2	1.3	11.0	14.5	28.4	744,196.6	0.00	1.00
07/22/2025 17:00	2	1.3	10.9	14.4	26.2	733,379.4	0.00	1.00
07/22/2025 18:00	2	1.3	10.8	14.4	26.2	734,643.5	0.00	1.00
07/22/2025 19:00	2	1.3	10.7	14.4	27.3	734,432.8	0.00	1.00
07/22/2025 20:00	2	1.3	10.7	14.4	26.9	735,696.9	0.00	1.00
07/22/2025 21:00	2	1.3	10.7	14.3	25.5	726,002.4	0.00	1.00
07/22/2025 22:00	2	1.3	10.8	14.3	26.1	729,944.7	0.00	1.00
07/22/2025 23:00	3	1.2	10.8	14.3	29.6	729,944.7	0.00	1.00
Average/Sum#:	2	1.3	10.8	14.4	26.5	731,350.7	0.00 #	24.00 #
Minimum:	2	1.2	10.6	14.3	23.7	723,927.5	0.00	1.00
Maximum:	3	1.6	11.2	14.5	29.6	745,480.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/23/2025 00:00	2	1.3	10.8	14.3	26.4	726,624.9	0.00	1.00
07/23/2025 01:00	2	1.4	10.5	14.3	22.9	728,284.8	0.00	1.00
07/23/2025 02:00	1	1.4	9.5	14.3	18.4	728,492.3	0.00	1.00
07/23/2025 03:00	1	1.6	9.3	14.3	19.0	728,492.3	0.00	1.00
07/23/2025 04:00	1	1.6	9.3	14.3	18.3	728,907.3	0.00	1.00
07/23/2025 05:00	2	1.5	9.3	14.3	20.7	728,077.3	0.00	1.00
07/23/2025 06:00	2	1.4	9.3	14.3	21.2	727,869.8	0.00	1.00
07/23/2025 07:00	2	1.3	9.5	14.3	22.9	732,642.0	0.00	1.00
07/23/2025 08:00	2	1.2	9.7	14.3	26.2	726,417.4	0.00	1.00
07/23/2025 09:00	2	1.2	10.0	14.3	23.0	725,587.4	0.00	1.00
07/23/2025 10:00	2	1.1	8.8	14.4	20.3	735,064.9	0.00	1.00
07/23/2025 11:00	2	1.3	9.5	14.4	23.5	735,486.2	0.00	1.00
07/23/2025 12:00	2	1.2	9.7	14.4	21.7	736,118.3	0.00	1.00
07/23/2025 13:00	1	1.2	8.4	14.5	18.6	778,646.1	0.00	1.00
07/23/2025 14:00	1	1.3	8.7	14.4	18.7	735,486.2	0.00	1.00
07/23/2025 15:00	1	1.3	8.6	14.5	18.4	745,266.4	0.00	1.00
07/23/2025 16:00	1	1.3	8.6	14.5	18.3	745,266.4	0.00	1.00
07/23/2025 17:00	1	1.3	8.5	14.5	18.3	765,593.8	0.00	1.00
07/23/2025 18:00	2	1.2	8.9	14.5	24.5	848,187.2	0.00	1.00
07/23/2025 19:00	1	1.4	8.9	14.6	22.4	905,124.3	0.00	1.00
07/23/2025 20:00	2	1.2	8.9	14.4	24.6	795,319.5	0.00	1.00
07/23/2025 21:00	1	1.3	8.6	14.6	22.6	921,644.3	0.00	1.00
07/23/2025 22:00	1	1.3	8.7	14.6	23.1	923,383.3	0.00	1.00
07/23/2025 23:00	2	1.1	9.0	14.4	26.4	840,405.2	0.00	1.00
Average/Sum#:	2	1.3	9.2	14.4	21.7	770,516.2	0.00 #	24.00 #
Minimum:	1	1.1	8.4	14.3	18.3	725,587.4	0.00	1.00
Maximum:	2	1.6	10.8	14.6	26.4	923,383.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/24/2025 00:00	1	1.3	8.9	14.3	19.2	731,189.6	0.00	1.00
07/24/2025 01:00	1	1.3	8.9	14.3	18.4	727,869.8	0.00	1.00
07/24/2025 02:00	1	1.4	9.6	14.3	18.7	728,907.3	0.00	1.00
07/24/2025 03:00	2	1.5	9.5	14.3	19.7	729,322.2	0.00	1.00
07/24/2025 04:00	1	1.6	9.3	14.3	18.3	738,659.2	0.00	1.00
07/24/2025 05:00	2	1.3	9.5	14.4	23.6	795,530.2	0.00	1.00
07/24/2025 06:00	1	1.6	9.4	14.3	18.9	728,907.3	0.00	1.00
07/24/2025 07:00	1	1.6	9.2	14.3	19.1	729,114.7	0.00	1.00
07/24/2025 08:00	2	1.4	10.8	14.3	28.4	728,077.3	0.00	1.00
07/24/2025 09:00	2	1.4	11.1	14.4	27.8	737,803.7	0.00	1.00
07/24/2025 10:00	2	1.4	11.1	14.4	27.5	736,750.3	0.00	1.00
07/24/2025 11:00	2	1.4	10.9	14.4	26.7	736,539.6	0.00	1.00
07/24/2025 12:00	2	1.3	10.7	14.5	25.6	747,406.2	0.00	1.00
07/24/2025 13:00	2	1.3	10.7	14.5	28.1	747,192.2	0.00	1.00
07/24/2025 14:00	2	1.3	10.7	14.5	25.2	746,764.2	0.00	1.00
07/24/2025 15:00	2	1.3	10.8	14.5	27.8	745,266.4	0.00	1.00
07/24/2025 16:00	2	1.3	10.9	14.5	25.6	744,410.5	0.00	1.00
07/24/2025 17:00	2	1.2	10.1	14.5	26.4	776,720.4	0.00	1.00
07/24/2025 18:00	1	1.1	8.4	14.4	18.5	736,750.3	0.00	1.00
07/24/2025 19:00	1	1.3	8.5	14.4	17.9	732,536.7	0.00	1.00
07/24/2025 20:00	1	1.3	8.5	14.4	17.8	733,800.8	0.00	1.00
07/24/2025 21:00	2	1.4	10.0	14.4	23.5	734,643.5	0.00	1.00
07/24/2025 22:00	2	1.3	10.7	14.4	28.7	735,064.9	0.00	1.00
07/24/2025 23:00	2	1.3	10.7	14.4	23.9	735,696.9	0.00	1.00
Average/Sum#:	2	1.4	10.0	14.4	23.1	740,205.2	0.00 #	24.00 #
Minimum:	1	1.1	8.4	14.3	17.8	727,869.8	0.00	1.00
Maximum:	2	1.6	11.1	14.5	28.7	795,530.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/25/2025 00:00	2	1.3	10.8	14.3	27.3	725,379.9	0.00	1.00
07/25/2025 01:00	2	1.3	10.8	14.3	26.5	726,209.9	0.00	1.00
07/25/2025 02:00	2	1.1	11.1	14.3	30.9	726,417.4	0.00	1.00
07/25/2025 03:00	2	1.5	10.9	14.3	22.8	727,247.3	0.00	1.00
07/25/2025 04:00	3	1.3	10.9	14.3	29.4	728,077.3	0.00	1.00
07/25/2025 05:00	2	1.2	9.7	14.3	21.4	728,492.3	0.00	1.00
07/25/2025 06:00	2	1.4	9.6	14.3	21.3	728,284.8	0.00	1.00
07/25/2025 07:00	2	1.5	9.3	14.3	20.7	727,869.8	0.00	1.00
07/25/2025 08:00	2	1.2	9.1	14.3	20.5	727,039.9	0.00	1.00
07/25/2025 09:00	1	1.4	8.9	14.4	18.7	737,382.4	0.00	1.00
07/25/2025 10:00	1	1.4	8.8	14.4	18.7	736,118.3	0.00	1.00
07/25/2025 11:00	1	1.3	8.5	14.4	18.6	736,539.6	0.00	1.00
07/25/2025 12:00	1	1.3	8.4	14.5	18.4	747,834.1	0.00	1.00
07/25/2025 13:00	1	1.2	8.3	14.5	18.3	747,192.2	0.00	1.00
07/25/2025 14:00	1	1.3	8.4	14.5	17.6	746,336.3	0.00	1.00
07/25/2025 15:00	1	1.3	8.4	14.5	17.8	745,480.4	0.00	1.00
07/25/2025 16:00	1	1.3	8.5	14.5	17.9	745,480.4	0.00	1.00
07/25/2025 17:00	1	1.3	8.5	14.4	17.7	734,432.8	0.00	1.00
07/25/2025 18:00	1	1.3	8.5	14.4	17.7	734,432.8	0.00	1.00
07/25/2025 19:00	1	1.4	8.5	14.4	17.6	734,011.5	0.00	1.00
07/25/2025 20:00	1	1.4	8.8	14.4	19.5	739,699.8	0.00	1.00
07/25/2025 21:00	1	1.2	8.9	14.3	19.5	724,965.0	0.00	1.00
07/25/2025 22:00	1	1.4	8.9	14.3	17.9	726,002.4	0.00	1.00
07/25/2025 23:00	1	1.5	9.0	14.3	17.8	726,209.9	0.00	1.00
Average/Sum#:	1	1.3	9.2	14.4	20.6	733,630.7	0.00 #	24.00 #
Minimum:	1	1.1	8.3	14.3	17.6	724,965.0	0.00	1.00
Maximum:	3	1.5	11.1	14.5	30.9	747,834.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/26/2025 00:00	1	1.5	9.0	14.3	17.7	726,417.4	0.00	1.00
07/26/2025 01:00	1	1.5	9.2	14.3	18.6	727,039.9	0.00	1.00
07/26/2025 02:00	1	1.1	9.6	14.3	24.7	727,869.8	0.00	1.00
07/26/2025 03:00	1	1.5	9.4	14.3	18.8	727,869.8	0.00	1.00
07/26/2025 04:00	1	1.6	9.3	14.3	19.4	728,492.3	0.00	1.00
07/26/2025 05:00	1	1.4	9.3	14.3	19.4	728,492.3	0.00	1.00
07/26/2025 06:00	1	1.6	9.3	14.3	18.7	728,077.3	0.00	1.00
07/26/2025 07:00	1	1.6	9.2	14.3	18.5	727,454.8	0.00	1.00
07/26/2025 08:00	1	1.6	9.2	14.3	18.9	726,417.4	0.00	1.00
07/26/2025 09:00	1	1.6	9.0	14.3	18.6	725,172.5	0.00	1.00
07/26/2025 10:00	1	1.6	8.9	14.4	18.6	734,643.5	0.00	1.00
07/26/2025 11:00	1	1.5	8.9	14.4	18.7	734,222.2	0.00	1.00
07/26/2025 12:00	1	1.4	8.4	14.4	18.3	732,958.1	0.00	1.00
07/26/2025 13:00	1	1.3	8.3	14.4	17.9	734,854.2	0.00	1.00
07/26/2025 14:00	1	1.3	8.4	14.4	17.9	735,486.2	0.00	1.00
07/26/2025 15:00	1	1.3	8.4	14.4	18.0	734,222.2	0.00	1.00
07/26/2025 16:00	1	1.3	8.4	14.4	18.1	734,222.2	0.00	1.00
07/26/2025 17:00	1	1.3	8.5	14.5	18.2	774,366.7	0.00	1.00
07/26/2025 18:00	2	1.2	8.6	14.4	19.9	735,064.9	0.00	1.00
07/26/2025 19:00	1	1.3	8.5	14.4	17.9	734,432.8	0.00	1.00
07/26/2025 20:00	1	1.4	8.6	14.4	17.8	735,275.6	0.00	1.00
07/26/2025 21:00	1	1.5	8.7	14.3	17.8	723,720.0	0.00	1.00
07/26/2025 22:00	1	1.5	8.8	14.3	17.7	723,927.5	0.00	1.00
07/26/2025 23:00	1	1.5	8.9	14.3	17.6	724,965.0	0.00	1.00
Average/Sum#:	1	1.4	8.9	14.4	18.7	731,902.7	0.00 #	24.00 #
Minimum:	1	1.1	8.3	14.3	17.6	723,720.0	0.00	1.00
Maximum:	2	1.6	9.6	14.5	24.7	774,366.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/27/2025 00:00	1	1.5	8.9	14.3	17.7	725,587.4	0.00	1.00
07/27/2025 01:00	1	1.5	8.9	14.3	17.7	726,002.4	0.00	1.00
07/27/2025 02:00	1	1.5	9.5	14.3	18.8	727,247.3	0.00	1.00
07/27/2025 03:00	2	1.6	9.5	14.3	19.3	727,247.3	0.00	1.00
07/27/2025 04:00	2	1.4	9.3	14.3	21.1	727,869.8	0.00	1.00
07/27/2025 05:00	2	1.4	11.0	14.3	27.5	728,284.8	0.00	1.00
07/27/2025 06:00	2	1.4	10.2	14.3	22.5	727,662.3	0.00	1.00
07/27/2025 07:00	1	1.5	9.2	14.3	18.7	727,662.3	0.00	1.00
07/27/2025 08:00	2	1.5	10.1	14.3	24.6	727,454.8	0.00	1.00
07/27/2025 09:00	2	1.3	10.8	14.3	26.6	726,832.4	0.00	1.00
07/27/2025 10:00	2	1.3	10.8	14.4	28.0	736,961.0	0.00	1.00
07/27/2025 11:00	2	1.4	10.7	14.4	26.2	737,593.0	0.00	1.00
07/27/2025 12:00	2	1.2	10.4	14.4	27.0	736,961.0	0.00	1.00
07/27/2025 13:00	2	1.2	10.3	14.4	24.6	736,329.0	0.00	1.00
07/27/2025 14:00	2	1.3	10.4	14.4	23.6	735,486.2	0.00	1.00
07/27/2025 15:00	2	1.3	10.5	14.4	26.7	734,432.8	0.00	1.00
07/27/2025 16:00	2	1.2	10.5	14.4	26.4	734,432.8	0.00	1.00
07/27/2025 17:00	2	1.2	9.9	14.5	23.6	774,580.7	0.00	1.00
07/27/2025 18:00	1	1.2	8.5	14.4	18.5	739,699.8	0.00	1.00
07/27/2025 19:00	1	1.2	8.5	14.4	18.6	740,963.9	0.00	1.00
07/27/2025 20:00	1	1.3	8.5	14.4	17.8	734,854.2	0.00	1.00
07/27/2025 21:00	1	1.4	8.6	14.4	17.7	735,064.9	0.00	1.00
07/27/2025 22:00	1	1.4	8.7	14.3	17.9	724,550.0	0.00	1.00
07/27/2025 23:00	1	1.4	8.8	14.3	18.4	725,172.5	0.00	1.00
Average/Sum#:	2	1.4	9.7	14.4	22.1	733,288.9	0.00 #	24.00 #
Minimum:	1	1.2	8.5	14.3	17.7	724,550.0	0.00	1.00
Maximum:	2	1.6	11.0	14.5	28.0	774,580.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/28/2025 00:00	1	1.4	8.9	14.3	18.3	725,172.5	0.00	1.00
07/28/2025 01:00	1	1.4	9.0	14.3	18.2	725,587.4	0.00	1.00
07/28/2025 02:00	1	1.4	9.4	14.3	18.6	725,587.4	0.00	1.00
07/28/2025 03:00	1	1.4	9.3	14.3	19.2	726,417.4	0.00	1.00
07/28/2025 04:00	1	1.5	9.1	14.3	18.3	726,832.4	0.00	1.00
07/28/2025 05:00	1	1.4	9.1	14.3	18.5	726,832.4	0.00	1.00
07/28/2025 06:00	1	1.4	9.0	14.3	18.8	726,832.4	0.00	1.00
07/28/2025 07:00	1	1.4	8.9	14.3	18.9	727,869.8	0.00	1.00
07/28/2025 08:00	1	1.3	8.9	14.3	18.9	726,624.9	0.00	1.00
07/28/2025 09:00	1	1.4	8.7	14.4	18.2	737,803.7	0.00	1.00
07/28/2025 10:00	1	1.4	8.7	14.4	18.8	752,130.0	0.00	1.00
07/28/2025 11:00	1	1.3	8.4	14.4	17.9	737,803.7	0.00	1.00
07/28/2025 12:00	1	1.4	8.1	14.6	20.9	929,252.3	0.00	1.00
07/28/2025 13:00	1	1.4	8.1	14.6	18.1	933,164.9	0.00	1.00
07/28/2025 14:00	1	1.3	8.2	14.6	21.9	932,947.5	0.00	1.00
07/28/2025 15:00	1	1.1	8.3	14.4	20.9	796,372.9	0.00	1.00
07/28/2025 16:00	1	1.2	8.3	14.4	18.3	781,836.0	0.00	1.00
07/28/2025 17:00	1	1.3	8.4	14.5	22.6	869,370.5	0.00	1.00
07/28/2025 18:00	1	1.4	8.2	14.6	21.4	928,382.8	0.00	1.00
07/28/2025 19:00	2	1.2	9.0	14.4	22.1	768,141.7	0.00	1.00
07/28/2025 20:00	2	1.4	10.7	14.4	26.1	733,379.4	0.00	1.00
07/28/2025 21:00	1	1.2	8.7	14.4	18.8	744,124.1	0.00	1.00
07/28/2025 22:00	1	1.3	8.6	14.4	17.8	740,331.9	0.00	1.00
07/28/2025 23:00	2	1.3	9.0	14.6	26.6	916,210.1	0.00	1.00
Average/Sum#:	1	1.3	8.8	14.4	19.9	784,958.7	0.00 #	24.00 #
Minimum:	1	1.1	8.1	14.3	17.8	725,172.5	0.00	1.00
Maximum:	2	1.5	10.7	14.6	26.6	933,164.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/29/2025 00:00	1	1.3	9.1	14.4	20.5	780,361.2	0.00	1.00
07/29/2025 01:00	1	1.4	8.9	14.4	19.6	763,506.8	0.00	1.00
07/29/2025 02:00	1	1.5	9.5	14.5	20.9	830,641.5	0.00	1.00
07/29/2025 03:00	1	1.4	9.1	14.4	20.1	762,032.0	0.00	1.00
07/29/2025 04:00	2	1.3	9.0	14.5	23.9	851,396.8	0.00	1.00
07/29/2025 05:00	2	1.2	9.1	14.4	24.0	832,399.3	0.00	1.00
07/29/2025 06:00	2	1.2	9.0	14.4	20.4	743,702.8	0.00	1.00
07/29/2025 07:00	1	1.3	8.8	14.4	18.9	758,661.1	0.00	1.00
07/29/2025 08:00	2	1.2	8.9	14.4	20.6	738,225.1	0.00	1.00
07/29/2025 09:00	1	1.3	9.0	14.6	23.7	866,650.0	0.00	1.00
07/29/2025 10:00	1	1.3	8.4	14.6	22.7	924,252.8	0.00	1.00
07/29/2025 11:00	1	1.4	8.3	14.6	20.6	920,340.1	0.00	1.00
07/29/2025 12:00	1	1.2	8.1	14.6	23.2	931,208.6	0.00	1.00
07/29/2025 13:00	1	1.3	8.3	14.6	21.7	932,947.5	0.00	1.00
07/29/2025 14:00	1	1.3	8.5	14.6	23.0	928,600.2	0.00	1.00
07/29/2025 15:00	1	1.2	8.2	14.4	18.6	782,257.3	0.00	1.00
07/29/2025 16:00	1	1.3	8.6	14.5	18.5	764,737.9	0.00	1.00
07/29/2025 17:00	1	1.4	8.5	14.6	18.8	807,308.3	0.00	1.00
07/29/2025 18:00	1	1.3	8.4	14.6	22.6	905,559.0	0.00	1.00
07/29/2025 19:00	2	1.2	9.1	14.3	21.9	728,699.8	0.00	1.00
07/29/2025 20:00	2	1.3	10.8	14.4	27.8	734,854.2	0.00	1.00
07/29/2025 21:00	2	1.1	8.9	14.5	22.1	800,899.3	0.00	1.00
07/29/2025 22:00	1	1.3	8.6	14.4	17.7	736,539.6	0.00	1.00
07/29/2025 23:00	1	1.3	9.0	14.4	22.5	810,277.9	0.00	1.00
Average/Sum#:	1	1.3	8.8	14.5	21.4	818,169.1	0.00 #	24.00 #
Minimum:	1	1.1	8.1	14.3	17.7	728,699.8	0.00	1.00
Maximum:	2	1.5	10.8	14.6	27.8	932,947.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/30/2025 00:00	1	1.4	8.8	14.3	18.2	726,002.4	0.00	1.00
07/30/2025 01:00	1	1.4	8.8	14.3	18.1	727,039.9	0.00	1.00
07/30/2025 02:00	2	1.5	10.7	14.3	24.8	727,454.8	0.00	1.00
07/30/2025 03:00	2	1.2	11.0	14.3	32.0	727,662.3	0.00	1.00
07/30/2025 04:00	2	1.3	9.9	14.4	22.8	779,729.2	0.00	1.00
07/30/2025 05:00	1	1.4	9.3	14.3	21.1	765,425.2	0.00	1.00
07/30/2025 06:00	2	1.4	11.0	14.3	28.6	727,869.8	0.00	1.00
07/30/2025 07:00	3	1.3	11.0	14.3	28.9	728,699.8	0.00	1.00
07/30/2025 08:00	2	1.4	10.9	14.3	24.8	726,624.9	0.00	1.00
07/30/2025 09:00	2	1.3	10.9	14.4	27.2	736,118.3	0.00	1.00
07/30/2025 10:00	2	1.3	10.7	14.4	27.0	734,643.5	0.00	1.00
07/30/2025 11:00	2	1.3	10.7	14.4	25.5	735,907.6	0.00	1.00
07/30/2025 12:00	2	1.3	10.6	14.5	27.0	747,620.1	0.00	1.00
07/30/2025 13:00	2	1.1	9.6	14.5	23.2	747,192.2	0.00	1.00
07/30/2025 14:00	1	1.2	8.5	14.5	17.7	746,336.3	0.00	1.00
07/30/2025 15:00	1	1.2	8.5	14.5	17.8	744,624.5	0.00	1.00
07/30/2025 16:00	1	1.2	8.5	14.5	17.9	747,834.1	0.00	1.00
07/30/2025 17:00	1	1.3	8.5	14.5	18.1	773,938.7	0.00	1.00
07/30/2025 18:00	1	1.4	8.7	14.5	18.9	759,602.6	0.00	1.00
07/30/2025 19:00	1	1.3	8.6	14.4	18.6	741,596.0	0.00	1.00
07/30/2025 20:00	1	1.4	8.6	14.4	17.6	734,643.5	0.00	1.00
07/30/2025 21:00	1	1.4	8.6	14.4	17.6	735,696.9	0.00	1.00
07/30/2025 22:00	1	1.4	8.8	14.3	17.7	725,587.4	0.00	1.00
07/30/2025 23:00	1	1.5	8.8	14.3	17.8	726,002.4	0.00	1.00
Average/Sum#:	2	1.3	9.6	14.4	22.0	740,577.2	0.00 #	24.00 #
Minimum:	1	1.1	8.5	14.3	17.6	725,587.4	0.00	1.00
Maximum:	3	1.5	11.0	14.5	32.0	779,729.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/31/2025 00:00	1	1.5	8.9	14.3	17.7	726,209.9	0.00	1.00
07/31/2025 01:00	1	1.5	8.9	14.3	17.7	726,832.4	0.00	1.00
07/31/2025 02:00	1	1.5	9.3	14.3	18.0	727,039.9	0.00	1.00
07/31/2025 03:00	1	1.5	9.0	14.3	18.8	727,454.8	0.00	1.00
07/31/2025 04:00	1	1.4	8.9	14.3	18.0	728,077.3	0.00	1.00
07/31/2025 05:00	1	1.4	8.9	14.3	18.2	727,869.8	0.00	1.00
07/31/2025 06:00	1	1.4	9.0	14.3	18.6	727,454.8	0.00	1.00
07/31/2025 07:00	1	1.4	8.9	14.3	18.8	728,077.3	0.00	1.00
07/31/2025 08:00	2	1.4	10.5	14.3	26.5	727,039.9	0.00	1.00
07/31/2025 09:00	2	1.1	9.0	14.4	20.6	736,750.3	0.00	1.00
07/31/2025 10:00	1	1.2	8.5	14.4	18.5	735,275.6	0.00	1.00
07/31/2025 11:00	1	1.3	8.5	14.4	17.8	735,907.6	0.00	1.00
07/31/2025 12:00	1	1.3	8.3	14.5	17.8	756,393.0	0.00	1.00
07/31/2025 13:00	1	1.3	8.2	14.6	17.7	834,914.1	0.00	1.00
07/31/2025 14:00	1	1.3	8.4	14.5	20.6	871,082.3	0.00	1.00
07/31/2025 15:00	1	1.3	8.7	14.6	23.5	922,948.6	0.00	1.00
07/31/2025 16:00	1	1.3	8.6	14.5	18.4	744,624.5	0.00	1.00
07/31/2025 17:00	1	1.3	8.4	14.6	18.4	807,308.3	0.00	1.00
07/31/2025 18:00	2	1.1	8.6	14.5	24.1	860,811.6	0.00	1.00
07/31/2025 19:00	2	1.3	9.6	14.5	24.8	785,065.3	0.00	1.00
07/31/2025 20:00	1	1.1	8.8	14.6	23.5	860,346.3	0.00	1.00
07/31/2025 21:00	1	1.3	9.0	14.6	23.5	902,515.9	0.00	1.00
07/31/2025 22:00	1	1.4	8.9	14.6	23.9	925,991.7	0.00	1.00
07/31/2025 23:00	2	1.1	8.6	14.4	20.4	743,281.4	0.00	1.00
Average/Sum#:	1	1.3	8.9	14.4	20.2	782,053.0	0.00 #	24.00 #
Minimum:	1	1.1	8.2	14.3	17.7	726,209.9	0.00	1.00
Maximum:	2	1.5	10.5	14.6	26.5	925,991.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/01/2025 00:00	1	1.3	8.5	14.4	18.1	736,329.0	0.00	1.00
08/01/2025 01:00	2	1.4	9.5	14.4	21.2	738,014.4	0.00	1.00
08/01/2025 02:00	2	1.3	11.1	14.3	27.2	727,662.3	0.00	1.00
08/01/2025 03:00	2	1.4	10.8	14.3	26.6	728,699.8	0.00	1.00
08/01/2025 04:00	2	1.3	10.5	14.3	27.3	735,961.9	0.00	1.00
08/01/2025 05:00	2	1.2	9.5	14.3	23.2	741,149.1	0.00	1.00
08/01/2025 06:00	2	1.4	10.7	14.3	24.8	727,869.8	0.00	1.00
08/01/2025 07:00	2	1.4	10.7	14.3	26.3	728,284.8	0.00	1.00
08/01/2025 08:00	2	1.2	10.7	14.4	27.7	738,225.1	0.00	1.00
08/01/2025 09:00	2	1.3	10.6	14.4	25.4	736,961.0	0.00	1.00
08/01/2025 10:00	2	1.4	10.5	14.4	25.9	735,696.9	0.00	1.00
08/01/2025 11:00	2	1.2	10.1	14.4	25.4	736,750.3	0.00	1.00
08/01/2025 12:00	1	1.1	8.2	14.5	17.6	748,262.0	0.00	1.00
08/01/2025 13:00	1	1.2	8.1	14.6	17.8	818,611.5	0.00	1.00
08/01/2025 14:00	1	1.4	8.5	14.6	20.7	902,950.6	0.00	1.00
08/01/2025 15:00	1	1.0	8.4	14.5	19.8	759,388.6	0.00	1.00
08/01/2025 16:00	1	1.2	8.3	14.5	17.6	745,694.4	0.00	1.00
08/01/2025 17:00	1	1.3	8.3	14.5	18.0	797,689.7	0.00	1.00
08/01/2025 18:00	2	1.2	8.4	14.5	23.6	868,086.7	0.00	1.00
08/01/2025 19:00	1	1.2	9.0	14.3	19.5	726,002.4	0.00	1.00
08/01/2025 20:00	2	1.3	10.6	14.4	28.2	736,329.0	0.00	1.00
08/01/2025 21:00	1	1.1	8.5	14.5	19.3	792,982.3	0.00	1.00
08/01/2025 22:00	2	1.2	8.9	14.4	21.8	771,934.0	0.00	1.00
08/01/2025 23:00	1	1.3	8.9	14.5	21.7	836,632.7	0.00	1.00
Average/Sum#:	2	1.3	9.5	14.4	22.7	763,173.7	0.00 #	24.00 #
Minimum:	1	1.0	8.1	14.3	17.6	726,002.4	0.00	1.00
Maximum:	2	1.4	11.1	14.6	28.2	902,950.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/02/2025 00:00	1	1.3	8.7	14.3	18.1	728,699.8	0.00	1.00
08/02/2025 01:00	1	1.3	9.0	14.4	22.6	823,550.8	0.00	1.00
08/02/2025 02:00	2	1.5	10.7	14.3	24.2	756,710.7	0.00	1.00
08/02/2025 03:00	2	1.4	10.8	14.3	24.7	756,503.2	0.00	1.00
08/02/2025 04:00	2	1.4	10.8	14.3	26.9	757,540.7	0.00	1.00
08/02/2025 05:00	2	1.3	10.7	14.3	27.0	757,125.7	0.00	1.00
08/02/2025 06:00	2	1.2	9.6	14.3	22.2	761,690.4	0.00	1.00
08/02/2025 07:00	1	1.4	9.0	14.3	18.6	757,540.7	0.00	1.00
08/02/2025 08:00	1	1.5	9.0	14.4	18.1	767,299.0	0.00	1.00
08/02/2025 09:00	1	1.5	8.9	14.4	17.7	766,034.9	0.00	1.00
08/02/2025 10:00	1	1.5	8.8	14.4	18.7	764,560.2	0.00	1.00
08/02/2025 11:00	1	1.4	8.5	14.4	17.6	764,770.8	0.00	1.00
08/02/2025 12:00	1	1.3	8.3	14.5	17.6	776,934.4	0.00	1.00
08/02/2025 13:00	1	1.2	8.3	14.5	17.4	777,148.3	0.00	1.00
08/02/2025 14:00	1	1.2	8.3	14.5	17.5	776,506.4	0.00	1.00
08/02/2025 15:00	1	1.3	8.5	14.5	17.7	774,152.7	0.00	1.00
08/02/2025 16:00	1	1.3	8.6	14.5	17.5	773,296.8	0.00	1.00
08/02/2025 17:00	1	1.4	8.6	14.6	17.5	801,656.7	0.00	1.00
08/02/2025 18:00	1	1.3	8.5	14.5	17.6	773,724.8	0.00	1.00
08/02/2025 19:00	1	1.3	8.4	14.5	17.4	772,227.0	0.00	1.00
08/02/2025 20:00	1	1.3	8.5	14.4	17.4	760,978.6	0.00	1.00
08/02/2025 21:00	1	1.4	8.5	14.4	17.4	761,189.3	0.00	1.00
08/02/2025 22:00	1	1.4	8.5	14.4	17.3	762,032.0	0.00	1.00
08/02/2025 23:00	1	1.4	8.7	14.4	17.3	763,296.1	0.00	1.00
Average/Sum#:	1	1.4	9.0	14.4	19.4	768,132.1	0.00 #	24.00 #
Minimum:	1	1.2	8.3	14.3	17.3	728,699.8	0.00	1.00
Maximum:	2	1.5	10.8	14.6	27.0	823,550.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/03/2025 00:00	1	1.5	8.7	14.4	17.4	763,928.1	0.00	1.00
08/03/2025 01:00	1	1.5	8.8	14.3	17.3	753,390.9	0.00	1.00
08/03/2025 02:00	1	1.5	9.2	14.3	17.6	753,598.4	0.00	1.00
08/03/2025 03:00	2	1.5	9.5	14.3	21.8	754,635.8	0.00	1.00
08/03/2025 04:00	2	1.2	10.5	14.3	25.3	755,050.8	0.00	1.00
08/03/2025 05:00	1	1.4	9.6	14.3	20.9	754,635.8	0.00	1.00
08/03/2025 06:00	2	1.3	9.6	14.3	22.3	754,220.9	0.00	1.00
08/03/2025 07:00	1	1.3	9.0	14.3	19.3	754,013.4	0.00	1.00
08/03/2025 08:00	1	1.3	8.7	14.4	18.6	763,506.8	0.00	1.00
08/03/2025 09:00	1	1.4	8.7	14.4	17.7	762,453.4	0.00	1.00
08/03/2025 10:00	2	1.4	9.7	14.4	22.8	761,610.6	0.00	1.00
08/03/2025 11:00	2	1.3	10.6	14.4	27.3	763,506.8	0.00	1.00
08/03/2025 12:00	2	1.3	10.5	14.5	24.7	775,864.5	0.00	1.00
08/03/2025 13:00	1	1.1	8.5	14.5	18.2	775,436.6	0.00	1.00
08/03/2025 14:00	1	1.2	8.4	14.5	17.5	774,794.6	0.00	1.00
08/03/2025 15:00	1	1.2	8.4	14.5	17.6	772,868.9	0.00	1.00
08/03/2025 16:00	1	1.3	8.4	14.5	17.6	772,227.0	0.00	1.00
08/03/2025 17:00	1	1.3	8.5	14.5	18.0	827,217.9	0.00	1.00
08/03/2025 18:00	2	1.3	9.8	14.4	24.4	767,299.0	0.00	1.00
08/03/2025 19:00	2	1.3	10.8	14.5	27.3	771,585.1	0.00	1.00
08/03/2025 20:00	2	1.2	10.8	14.4	27.3	760,978.6	0.00	1.00
08/03/2025 21:00	2	1.3	10.9	14.4	25.6	761,821.3	0.00	1.00
08/03/2025 22:00	1	1.3	8.9	14.4	18.1	762,664.0	0.00	1.00
08/03/2025 23:00	1	1.4	9.0	14.4	18.4	763,085.4	0.00	1.00
Average/Sum#:	1	1.3	9.4	14.4	21.0	765,849.8	0.00 #	24.00 #
Minimum:	1	1.1	8.4	14.3	17.3	753,390.9	0.00	1.00
Maximum:	2	1.5	10.9	14.5	27.3	827,217.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/04/2025 00:00	1	1.5	9.1	14.4	17.9	763,085.4	0.00	1.00
08/04/2025 01:00	1	1.5	9.1	14.4	17.8	763,506.8	0.00	1.00
08/04/2025 02:00	1	1.5	9.5	14.3	18.0	752,560.9	0.00	1.00
08/04/2025 03:00	1	1.5	9.3	14.3	18.9	752,975.9	0.00	1.00
08/04/2025 04:00	1	1.5	9.2	14.3	17.8	753,390.9	0.00	1.00
08/04/2025 05:00	1	1.4	9.3	14.3	19.6	754,013.4	0.00	1.00
08/04/2025 06:00	2	1.3	9.2	14.5	26.8	935,060.1	0.00	1.00
08/04/2025 07:00	1	1.2	9.3	14.4	21.1	782,046.7	0.00	1.00
08/04/2025 08:00	1	1.4	9.0	14.4	18.2	761,821.3	0.00	1.00
08/04/2025 09:00	1	1.5	8.9	14.4	17.8	761,610.6	0.00	1.00
08/04/2025 10:00	1	1.5	8.8	14.4	17.9	761,189.3	0.00	1.00
08/04/2025 11:00	1	1.5	8.7	14.4	17.9	762,664.0	0.00	1.00
08/04/2025 12:00	1	1.4	8.5	14.5	17.8	774,794.6	0.00	1.00
08/04/2025 13:00	1	1.3	8.5	14.5	17.7	775,222.6	0.00	1.00
08/04/2025 14:00	1	1.3	8.5	14.5	17.7	776,292.4	0.00	1.00
08/04/2025 15:00	1	1.3	8.6	14.5	17.6	773,724.8	0.00	1.00
08/04/2025 16:00	1	1.3	8.6	14.5	17.6	772,013.0	0.00	1.00
08/04/2025 17:00	1	1.4	8.7	14.6	19.4	824,045.7	0.00	1.00
08/04/2025 18:00	1	1.3	8.9	14.5	18.5	777,148.3	0.00	1.00
08/04/2025 19:00	1	1.5	8.8	14.4	17.6	760,346.6	0.00	1.00
08/04/2025 20:00	1	1.5	8.8	14.4	17.6	760,978.6	0.00	1.00
08/04/2025 21:00	1	1.5	8.7	14.4	17.5	761,400.0	0.00	1.00
08/04/2025 22:00	1	1.5	8.7	14.4	17.5	762,453.4	0.00	1.00
08/04/2025 23:00	1	1.5	8.8	14.4	17.4	763,296.1	0.00	1.00
Average/Sum#:	1	1.4	8.9	14.4	18.5	774,401.7	0.00 #	24.00 #
Minimum:	1	1.2	8.5	14.3	17.4	752,560.9	0.00	1.00
Maximum:	2	1.5	9.5	14.6	26.8	935,060.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/05/2025 00:00	1	1.6	8.9	14.4	17.5	763,928.1	0.00	1.00
08/05/2025 01:00	1	1.5	8.9	14.4	17.4	764,138.8	0.00	1.00
08/05/2025 02:00	1	1.5	9.3	14.3	17.7	752,975.9	0.00	1.00
08/05/2025 03:00	1	1.5	9.2	14.3	18.2	753,183.4	0.00	1.00
08/05/2025 04:00	1	1.5	9.1	14.3	17.7	753,805.9	0.00	1.00
08/05/2025 05:00	1	1.5	9.2	14.4	21.1	845,882.9	0.00	1.00
08/05/2025 06:00	2	1.1	9.6	14.4	25.7	810,488.6	0.00	1.00
08/05/2025 07:00	1	1.3	9.2	14.4	19.1	765,824.3	0.00	1.00
08/05/2025 08:00	1	1.4	9.2	14.4	18.7	762,664.0	0.00	1.00
08/05/2025 09:00	1	1.5	8.9	14.4	18.2	762,032.0	0.00	1.00
08/05/2025 10:00	1	1.5	8.7	14.4	18.2	761,400.0	0.00	1.00
08/05/2025 11:00	1	1.5	8.6	14.4	18.3	763,296.1	0.00	1.00
08/05/2025 12:00	1	1.4	8.4	14.5	17.9	775,650.5	0.00	1.00
08/05/2025 13:00	1	1.4	8.4	14.5	17.8	775,864.5	0.00	1.00
08/05/2025 14:00	1	1.4	8.5	14.5	17.8	775,436.6	0.00	1.00
08/05/2025 15:00	1	1.4	8.5	14.5	17.7	773,724.8	0.00	1.00
08/05/2025 16:00	1	1.5	8.5	14.6	19.3	812,959.9	0.00	1.00
08/05/2025 17:00	1	1.2	8.5	14.6	20.1	850,564.7	0.00	1.00
08/05/2025 18:00	1	1.3	8.2	14.6	24.4	959,683.9	0.00	1.00
08/05/2025 19:00	1	1.3	8.2	14.5	22.2	912,165.0	0.00	1.00
08/05/2025 20:00	1	1.4	8.2	14.5	19.6	915,588.6	0.00	1.00
08/05/2025 21:00	1	1.2	8.1	14.5	23.2	943,191.0	0.00	1.00
08/05/2025 22:00	1	1.3	8.4	14.5	23.3	901,252.4	0.00	1.00
08/05/2025 23:00	1	1.3	8.5	14.4	18.2	761,400.0	0.00	1.00
Average/Sum#:	1	1.4	8.7	14.4	19.6	809,045.9	0.00 #	24.00 #
Minimum:	1	1.1	8.1	14.3	17.4	752,975.9	0.00	1.00
Maximum:	2	1.6	9.6	14.6	25.7	959,683.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/06/2025 00:00	1	1.4	8.6	14.4	17.9	762,664.0	0.00	1.00
08/06/2025 01:00	1	1.4	8.7	14.4	17.9	762,664.0	0.00	1.00
08/06/2025 02:00	1	1.4	9.1	14.4	18.3	763,928.1	0.00	1.00
08/06/2025 03:00	1	1.5	9.0	14.3	18.6	752,353.5	0.00	1.00
08/06/2025 04:00	1	1.5	9.0	14.4	17.9	764,349.5	0.00	1.00
08/06/2025 05:00	1	1.5	8.8	14.4	20.7	816,809.0	0.00	1.00
08/06/2025 06:00	2	1.2	9.0	14.5	26.6	926,715.2	0.00	1.00
08/06/2025 07:00	1	1.3	9.0	14.4	20.2	788,999.1	0.00	1.00
08/06/2025 08:00	1	1.4	8.7	14.4	17.7	762,242.7	0.00	1.00
08/06/2025 09:00	1	1.5	8.6	14.4	17.5	761,400.0	0.00	1.00
08/06/2025 10:00	1	1.5	8.6	14.5	17.5	772,868.9	0.00	1.00
08/06/2025 11:00	1	1.5	8.5	14.5	17.5	774,794.6	0.00	1.00
08/06/2025 12:00	1	1.4	8.3	14.5	17.4	775,436.6	0.00	1.00
08/06/2025 13:00	1	1.4	8.3	14.5	17.4	774,794.6	0.00	1.00
08/06/2025 14:00	1	1.4	8.4	14.5	17.4	772,440.9	0.00	1.00
08/06/2025 15:00	1	1.5	8.6	14.5	17.4	773,296.8	0.00	1.00
08/06/2025 16:00	1	1.5	8.7	14.6	18.1	791,875.1	0.00	1.00
08/06/2025 17:00	1	1.4	8.6	14.6	19.8	832,523.1	0.00	1.00
08/06/2025 18:00	2	1.2	8.8	14.5	26.3	893,977.4	0.00	1.00
08/06/2025 19:00	1	1.3	8.5	14.4	18.7	788,999.1	0.00	1.00
08/06/2025 20:00	1	1.3	8.3	14.4	17.9	771,723.3	0.00	1.00
08/06/2025 21:00	1	1.3	8.5	14.4	19.7	807,960.4	0.00	1.00
08/06/2025 22:00	1	1.2	8.2	14.4	19.5	819,969.2	0.00	1.00
08/06/2025 23:00	1	1.3	8.1	14.5	20.8	912,165.0	0.00	1.00
Average/Sum#:	1	1.4	8.6	14.5	19.1	796,872.9	0.00 #	24.00 #
Minimum:	1	1.2	8.1	14.3	17.4	752,353.5	0.00	1.00
Maximum:	2	1.5	9.1	14.6	26.6	926,715.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/07/2025 00:00	1	1.2	8.3	14.4	20.8	833,031.4	0.00	1.00
08/07/2025 01:00	2	1.1	8.4	14.4	21.3	808,592.4	0.00	1.00
08/07/2025 02:00	1	1.2	8.8	14.3	18.0	753,183.4	0.00	1.00
08/07/2025 03:00	1	1.3	8.8	14.3	18.9	753,805.9	0.00	1.00
08/07/2025 04:00	1	1.3	8.5	14.3	18.1	777,667.1	0.00	1.00
08/07/2025 05:00	1	1.3	8.9	14.4	22.3	830,292.5	0.00	1.00
08/07/2025 06:00	1	1.4	8.7	14.3	18.3	754,428.3	0.00	1.00
08/07/2025 07:00	2	1.4	9.7	14.3	24.4	755,880.8	0.00	1.00
08/07/2025 08:00	2	1.4	10.3	14.3	24.5	754,843.3	0.00	1.00
08/07/2025 09:00	2	1.3	10.1	14.3	26.4	753,805.9	0.00	1.00
08/07/2025 10:00	2	1.3	10.1	14.3	23.5	754,013.4	0.00	1.00
08/07/2025 11:00	2	1.4	10.0	14.3	25.6	755,880.8	0.00	1.00
08/07/2025 12:00	2	1.3	9.6	14.3	23.1	755,880.8	0.00	1.00
08/07/2025 13:00	1	1.3	9.5	14.3	21.5	756,710.7	0.00	1.00
08/07/2025 14:00	1	1.3	8.7	14.4	17.8	824,604.2	0.00	1.00
08/07/2025 15:00	1	1.2	7.9	14.4	17.7	811,120.6	0.00	1.00
08/07/2025 16:00	1	1.2	8.2	14.4	17.9	762,453.4	0.00	1.00
08/07/2025 17:00	1	1.2	8.0	14.5	17.4	806,890.5	0.00	1.00
08/07/2025 18:00	1	1.3	8.1	14.5	20.8	873,650.0	0.00	1.00
08/07/2025 19:00	1	1.3	8.3	14.5	18.4	819,300.9	0.00	1.00
08/07/2025 20:00	1	1.4	8.4	14.5	17.7	792,768.3	0.00	1.00
08/07/2025 21:00	1	1.4	8.3	14.5	17.3	770,729.2	0.00	1.00
08/07/2025 22:00	1	1.3	8.2	14.4	17.2	759,293.2	0.00	1.00
08/07/2025 23:00	1	1.3	8.2	14.4	17.3	759,714.5	0.00	1.00
Average/Sum#:	1	1.3	8.8	14.4	20.3	782,439.2	0.00 #	24.00 #
Minimum:	1	1.1	7.9	14.3	17.2	753,183.4	0.00	1.00
Maximum:	2	1.4	10.3	14.5	26.4	873,650.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/08/2025 00:00	1	1.3	8.3	14.4	17.2	760,346.6	0.00	1.00
08/08/2025 01:00	1	1.4	8.3	14.4	17.1	760,767.9	0.00	1.00
08/08/2025 02:00	1	1.4	8.7	14.4	17.3	760,978.6	0.00	1.00
08/08/2025 03:00	1	1.3	8.6	14.4	19.0	761,400.0	0.00	1.00
08/08/2025 04:00	1	1.3	8.5	14.4	17.8	763,296.1	0.00	1.00
08/08/2025 05:00	1	1.3	8.7	14.4	21.1	810,067.2	0.00	1.00
08/08/2025 06:00	2	1.4	10.4	14.3	27.5	751,731.0	0.00	1.00
08/08/2025 07:00	2	1.3	10.4	14.4	24.0	763,506.8	0.00	1.00
08/08/2025 08:00	2	1.4	10.5	14.4	26.5	760,978.6	0.00	1.00
08/08/2025 09:00	2	1.2	10.4	14.4	25.7	759,082.5	0.00	1.00
08/08/2025 10:00	1	1.2	9.1	14.5	21.3	770,301.2	0.00	1.00
08/08/2025 11:00	1	1.1	8.0	14.5	17.3	773,082.9	0.00	1.00
08/08/2025 12:00	1	1.1	8.0	14.5	17.2	773,082.9	0.00	1.00
08/08/2025 13:00	1	1.1	7.8	14.5	17.3	791,056.6	0.00	1.00
08/08/2025 14:00	1	1.2	8.1	14.5	17.6	794,694.1	0.00	1.00
08/08/2025 15:00	1	1.2	8.1	14.6	17.6	790,570.9	0.00	1.00
08/08/2025 16:00	1	1.2	7.9	14.6	17.7	847,086.8	0.00	1.00
08/08/2025 17:00	1	1.3	8.2	14.5	18.3	839,628.3	0.00	1.00
08/08/2025 18:00	1	1.0	8.1	14.4	20.1	768,984.5	0.00	1.00
08/08/2025 19:00	1	1.1	8.0	14.3	17.5	751,523.5	0.00	1.00
08/08/2025 20:00	1	1.3	8.3	14.4	17.5	787,103.0	0.00	1.00
08/08/2025 21:00	1	1.4	8.5	14.5	17.4	776,934.4	0.00	1.00
08/08/2025 22:00	1	1.4	8.4	14.4	17.2	760,978.6	0.00	1.00
08/08/2025 23:00	1	1.4	8.4	14.4	17.1	758,871.8	0.00	1.00
Average/Sum#:	1	1.3	8.7	14.4	19.3	776,502.3	0.00 #	24.00 #
Minimum:	1	1.0	7.8	14.3	17.1	751,523.5	0.00	1.00
Maximum:	2	1.4	10.5	14.6	27.5	847,086.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/09/2025 00:00	1	1.3	8.2	14.4	17.3	758,661.1	0.00	1.00
08/09/2025 01:00	1	1.3	8.3	14.4	17.2	759,082.5	0.00	1.00
08/09/2025 02:00	1	1.3	8.5	14.4	17.1	759,503.8	0.00	1.00
08/09/2025 03:00	1	1.4	8.4	14.4	17.3	759,714.5	0.00	1.00
08/09/2025 04:00	1	1.3	8.3	14.4	17.1	760,767.9	0.00	1.00
08/09/2025 05:00	1	1.4	8.4	14.4	17.3	760,557.2	0.00	1.00
08/09/2025 06:00	1	1.4	8.3	14.4	17.5	760,135.9	0.00	1.00
08/09/2025 07:00	1	1.3	8.3	14.4	17.3	760,978.6	0.00	1.00
08/09/2025 08:00	1	1.3	8.2	14.4	17.1	758,661.1	0.00	1.00
08/09/2025 09:00	1	1.3	8.2	14.5	16.9	769,231.4	0.00	1.00
08/09/2025 10:00	1	1.3	8.1	14.5	16.9	769,231.4	0.00	1.00
08/09/2025 11:00	1	1.2	7.9	14.5	16.9	771,585.1	0.00	1.00
08/09/2025 12:00	1	1.2	7.7	14.6	16.9	784,267.2	0.00	1.00
08/09/2025 13:00	1	1.0	7.4	14.6	16.8	785,136.6	0.00	1.00
08/09/2025 14:00	1	1.0	7.5	14.6	17.1	792,092.5	0.00	1.00
08/09/2025 15:00	1	0.9	7.3	14.6	17.4	783,397.7	0.00	1.00
08/09/2025 16:00	1	1.0	7.5	14.6	17.8	832,957.8	0.00	1.00
08/09/2025 17:00	1	1.1	7.9	14.4	17.7	764,981.5	0.00	1.00
08/09/2025 18:00	1	0.9	7.3	14.6	17.3	782,093.5	0.00	1.00
08/09/2025 19:00	1	1.2	8.1	14.6	17.5	843,174.2	0.00	1.00
08/09/2025 20:00	1	1.3	8.3	14.5	17.7	775,436.6	0.00	1.00
08/09/2025 21:00	1	1.3	8.1	14.5	17.0	768,161.5	0.00	1.00
08/09/2025 22:00	1	1.3	8.2	14.5	17.0	767,947.5	0.00	1.00
08/09/2025 23:00	1	1.4	8.2	14.4	17.1	757,397.0	0.00	1.00
Average/Sum#:	1	1.2	8.0	14.5	17.2	774,381.4	0.00 #	24.00 #
Minimum:	1	0.9	7.3	14.4	16.8	757,397.0	0.00	1.00
Maximum:	1	1.4	8.5	14.6	17.8	843,174.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/10/2025 00:00	1	1.4	8.3	14.4	16.9	757,818.4	0.00	1.00
08/10/2025 01:00	1	1.4	8.3	14.4	16.9	758,450.4	0.00	1.00
08/10/2025 02:00	1	1.4	8.7	14.4	17.2	758,871.8	0.00	1.00
08/10/2025 03:00	1	1.4	8.6	14.4	17.8	759,925.2	0.00	1.00
08/10/2025 04:00	2	1.3	10.5	14.4	28.1	761,189.3	0.00	1.00
08/10/2025 05:00	2	1.3	10.5	14.4	24.8	761,400.0	0.00	1.00
08/10/2025 06:00	2	1.4	10.5	14.4	26.6	761,189.3	0.00	1.00
08/10/2025 07:00	2	1.2	10.5	14.4	28.0	761,189.3	0.00	1.00
08/10/2025 08:00	2	1.3	10.5	14.4	24.6	758,239.7	0.00	1.00
08/10/2025 09:00	2	1.3	10.5	14.5	26.0	768,803.4	0.00	1.00
08/10/2025 10:00	1	1.1	8.4	14.5	20.3	768,375.5	0.00	1.00
08/10/2025 11:00	1	1.2	8.0	14.5	17.2	771,157.1	0.00	1.00
08/10/2025 12:00	1	1.2	7.9	14.5	17.1	771,585.1	0.00	1.00
08/10/2025 13:00	1	1.2	7.6	14.6	17.3	876,866.3	0.00	1.00
08/10/2025 14:00	1	1.4	8.1	14.6	19.5	940,120.7	0.00	1.00
08/10/2025 15:00	1	1.3	8.0	14.5	18.1	835,776.8	0.00	1.00
08/10/2025 16:00	1	1.3	7.9	14.6	18.3	857,085.8	0.00	1.00
08/10/2025 17:00	1	1.1	7.9	14.6	20.0	860,346.3	0.00	1.00
08/10/2025 18:00	1	1.3	8.3	14.6	23.1	951,858.6	0.00	1.00
08/10/2025 19:00	1	1.3	8.3	14.5	19.4	844,977.6	0.00	1.00
08/10/2025 20:00	1	1.2	8.0	14.4	17.6	781,625.3	0.00	1.00
08/10/2025 21:00	1	1.4	8.3	14.4	18.0	807,328.3	0.00	1.00
08/10/2025 22:00	1	1.3	8.2	14.4	17.5	763,085.4	0.00	1.00
08/10/2025 23:00	1	1.4	8.3	14.4	17.9	762,032.0	0.00	1.00
Average/Sum#:	1	1.3	8.8	14.5	20.3	799,970.7	0.00 #	24.00 #
Minimum:	1	1.1	7.6	14.4	16.9	757,818.4	0.00	1.00
Maximum:	2	1.4	10.5	14.6	28.1	951,858.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/11/2025 00:00	1	1.3	8.4	14.4	17.5	757,397.0	0.00	1.00
08/11/2025 01:00	1	1.4	8.5	14.4	17.3	757,607.7	0.00	1.00
08/11/2025 02:00	1	1.4	8.9	14.4	17.8	757,818.4	0.00	1.00
08/11/2025 03:00	2	1.3	8.8	14.3	19.8	746,751.3	0.00	1.00
08/11/2025 04:00	1	1.4	8.6	14.4	20.4	810,699.2	0.00	1.00
08/11/2025 05:00	2	1.2	8.9	14.4	23.6	863,580.1	0.00	1.00
08/11/2025 06:00	1	1.2	8.6	14.3	18.2	747,788.7	0.00	1.00
08/11/2025 07:00	1	1.3	8.6	14.4	18.4	759,925.2	0.00	1.00
08/11/2025 08:00	1	1.4	8.5	14.4	18.0	757,818.4	0.00	1.00
08/11/2025 09:00	1	1.4	8.4	14.4	17.7	756,343.6	0.00	1.00
08/11/2025 10:00	1	1.4	8.3	14.5	17.6	767,305.6	0.00	1.00
08/11/2025 11:00	1	1.4	8.2	14.5	17.8	769,017.4	0.00	1.00
08/11/2025 12:00	1	1.3	8.0	14.5	17.7	769,017.4	0.00	1.00
08/11/2025 13:00	1	1.2	7.9	14.5	17.3	786,777.1	0.00	1.00
08/11/2025 14:00	1	1.2	7.7	14.6	17.3	850,130.0	0.00	1.00
08/11/2025 15:00	1	1.2	7.8	14.5	17.7	773,724.8	0.00	1.00
08/11/2025 16:00	1	1.1	7.7	14.5	17.5	818,445.0	0.00	1.00
08/11/2025 17:00	1	1.4	7.9	14.5	17.6	866,588.9	0.00	1.00
08/11/2025 18:00	1	1.5	7.6	14.6	17.4	946,859.1	0.00	1.00
08/11/2025 19:00	1	1.5	7.8	14.5	19.3	899,112.7	0.00	1.00
08/11/2025 20:00	1	1.3	7.8	14.5	19.9	925,431.3	0.00	1.00
08/11/2025 21:00	1	1.4	8.0	14.5	20.4	922,863.7	0.00	1.00
08/11/2025 22:00	2	1.2	8.2	14.4	22.8	860,419.9	0.00	1.00
08/11/2025 23:00	2	1.2	8.4	14.4	22.0	844,197.5	0.00	1.00
Average/Sum#:	1	1.3	8.2	14.5	18.8	813,150.8	0.00 #	24.00 #
Minimum:	1	1.1	7.6	14.3	17.3	746,751.3	0.00	1.00
Maximum:	2	1.5	8.9	14.6	23.6	946,859.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/12/2025 00:00	1	1.2	8.4	14.5	22.5	878,357.4	0.00	1.00
08/12/2025 01:00	1	1.3	8.6	14.4	20.8	843,776.1	0.00	1.00
08/12/2025 02:00	1	1.3	9.0	14.3	18.8	761,483.0	0.00	1.00
08/12/2025 03:00	1	1.4	8.7	14.4	18.7	794,687.5	0.00	1.00
08/12/2025 04:00	2	1.3	8.7	14.4	23.7	869,268.5	0.00	1.00
08/12/2025 05:00	1	1.3	8.6	14.5	24.3	922,007.8	0.00	1.00
08/12/2025 06:00	1	1.4	8.9	14.3	19.4	780,779.4	0.00	1.00
08/12/2025 07:00	2	1.5	10.3	14.3	26.3	755,465.8	0.00	1.00
08/12/2025 08:00	2	1.3	10.6	14.3	25.9	752,975.9	0.00	1.00
08/12/2025 09:00	2	1.3	10.5	14.4	28.5	762,242.7	0.00	1.00
08/12/2025 10:00	2	1.2	10.3	14.4	26.0	760,978.6	0.00	1.00
08/12/2025 11:00	2	1.4	10.2	14.4	24.4	762,032.0	0.00	1.00
08/12/2025 12:00	2	1.2	9.9	14.5	25.4	773,296.8	0.00	1.00
08/12/2025 13:00	1	1.0	7.8	14.5	18.5	808,816.3	0.00	1.00
08/12/2025 14:00	1	1.3	8.0	14.5	17.9	881,566.9	0.00	1.00
08/12/2025 15:00	1	1.4	7.9	14.5	18.0	873,222.0	0.00	1.00
08/12/2025 16:00	1	1.4	8.0	14.5	19.7	886,488.3	0.00	1.00
08/12/2025 17:00	1	1.4	8.1	14.5	19.7	938,911.6	0.00	1.00
08/12/2025 18:00	1	1.3	8.0	14.5	22.7	930,138.7	0.00	1.00
08/12/2025 19:00	1	1.4	8.1	14.5	21.3	929,710.8	0.00	1.00
08/12/2025 20:00	1	1.3	8.4	14.5	22.2	873,650.0	0.00	1.00
08/12/2025 21:00	2	1.2	8.5	14.4	22.4	830,081.9	0.00	1.00
08/12/2025 22:00	2	1.2	8.6	14.4	22.9	837,877.0	0.00	1.00
08/12/2025 23:00	1	1.3	8.4	14.3	17.8	752,560.9	0.00	1.00
Average/Sum#:	1	1.3	8.9	14.4	22.0	831,682.3	0.00 #	24.00 #
Minimum:	1	1.0	7.8	14.3	17.8	752,560.9	0.00	1.00
Maximum:	2	1.5	10.6	14.5	28.5	938,911.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/13/2025 00:00	1	1.4	8.5	14.3	17.6	754,220.9	0.00	1.00
08/13/2025 01:00	1	1.4	8.6	14.3	17.6	754,635.8	0.00	1.00
08/13/2025 02:00	1	1.4	9.0	14.3	17.8	755,050.8	0.00	1.00
08/13/2025 03:00	2	1.5	9.0	14.3	19.5	754,843.3	0.00	1.00
08/13/2025 04:00	2	1.4	10.4	14.3	25.3	755,465.8	0.00	1.00
08/13/2025 05:00	2	1.4	10.4	14.3	25.3	755,880.8	0.00	1.00
08/13/2025 06:00	2	1.3	10.4	14.3	28.7	756,295.7	0.00	1.00
08/13/2025 07:00	2	1.2	10.4	14.3	26.6	756,503.2	0.00	1.00
08/13/2025 08:00	2	1.3	10.4	14.3	24.8	755,880.8	0.00	1.00
08/13/2025 09:00	2	1.4	10.4	14.3	27.3	754,220.9	0.00	1.00
08/13/2025 10:00	2	1.4	10.3	14.4	25.0	765,192.2	0.00	1.00
08/13/2025 11:00	2	1.3	10.2	14.4	26.9	766,456.3	0.00	1.00
08/13/2025 12:00	2	1.1	10.1	14.4	20.5	765,824.3	0.00	1.00
08/13/2025 13:00	2	1.5	10.1	14.4	24.0	764,138.8	0.00	1.00
08/13/2025 14:00	1	1.0	8.2	14.5	19.7	773,938.7	0.00	1.00
08/13/2025 15:00	1	1.1	8.1	14.4	17.7	761,400.0	0.00	1.00
08/13/2025 16:00	1	1.2	8.0	14.5	17.6	771,371.1	0.00	1.00
08/13/2025 17:00	1	1.2	8.1	14.5	17.7	801,969.2	0.00	1.00
08/13/2025 18:00	1	1.3	8.2	14.4	17.9	760,346.6	0.00	1.00
08/13/2025 19:00	1	1.3	8.2	14.4	17.5	758,661.1	0.00	1.00
08/13/2025 20:00	1	1.3	8.3	14.4	17.5	759,293.2	0.00	1.00
08/13/2025 21:00	1	1.4	8.4	14.3	17.6	747,581.2	0.00	1.00
08/13/2025 22:00	1	1.4	8.5	14.3	17.5	749,448.6	0.00	1.00
08/13/2025 23:00	1	1.4	8.6	14.3	17.4	751,523.5	0.00	1.00
Average/Sum#:	1	1.3	9.2	14.4	21.0	760,422.6	0.00 #	24.00 #
Minimum:	1	1.0	8.0	14.3	17.4	747,581.2	0.00	1.00
Maximum:	2	1.5	10.4	14.5	28.7	801,969.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/14/2025 00:00	1	1.4	8.6	14.3	17.4	752,768.4	0.00	1.00
08/14/2025 01:00	1	1.5	8.7	14.3	17.4	753,183.4	0.00	1.00
08/14/2025 02:00	1	1.5	9.0	14.3	17.8	753,598.4	0.00	1.00
08/14/2025 03:00	1	1.5	8.9	14.3	18.4	754,220.9	0.00	1.00
08/14/2025 04:00	2	1.5	9.2	14.3	21.2	755,880.8	0.00	1.00
08/14/2025 05:00	2	1.3	10.5	14.3	25.7	756,918.2	0.00	1.00
08/14/2025 06:00	2	1.3	10.5	14.3	27.1	757,125.7	0.00	1.00
08/14/2025 07:00	2	1.3	10.4	14.3	27.1	756,503.2	0.00	1.00
08/14/2025 08:00	2	1.4	10.4	14.3	24.3	755,673.3	0.00	1.00
08/14/2025 09:00	2	1.3	10.4	14.3	28.0	753,390.9	0.00	1.00
08/14/2025 10:00	2	1.3	10.4	14.4	25.0	763,296.1	0.00	1.00
08/14/2025 11:00	2	1.3	10.4	14.4	25.9	763,296.1	0.00	1.00
08/14/2025 12:00	2	1.4	10.2	14.4	26.1	763,085.4	0.00	1.00
08/14/2025 13:00	2	1.2	10.2	14.5	26.5	775,650.5	0.00	1.00
08/14/2025 14:00	1	1.2	8.9	14.5	18.6	775,436.6	0.00	1.00
08/14/2025 15:00	1	1.2	8.2	14.5	17.7	773,296.8	0.00	1.00
08/14/2025 16:00	1	1.2	8.1	14.5	17.6	770,515.2	0.00	1.00
08/14/2025 17:00	1	1.2	8.1	14.5	17.6	788,060.9	0.00	1.00
08/14/2025 18:00	1	1.3	8.2	14.5	17.6	771,585.1	0.00	1.00
08/14/2025 19:00	1	1.2	8.1	14.4	17.4	758,239.7	0.00	1.00
08/14/2025 20:00	1	1.3	8.2	14.4	17.3	758,661.1	0.00	1.00
08/14/2025 21:00	1	1.3	8.3	14.4	17.4	760,346.6	0.00	1.00
08/14/2025 22:00	1	1.3	8.3	14.4	17.5	759,925.2	0.00	1.00
08/14/2025 23:00	1	1.4	8.4	14.4	17.4	760,346.6	0.00	1.00
Average/Sum#:	1	1.3	9.2	14.4	21.0	762,125.2	0.00 #	24.00 #
Minimum:	1	1.2	8.1	14.3	17.3	752,768.4	0.00	1.00
Maximum:	2	1.5	10.5	14.5	28.0	788,060.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/15/2025 00:00	1	1.4	8.4	14.4	17.4	760,346.6	0.00	1.00
08/15/2025 01:00	1	1.4	8.4	14.3	17.4	749,863.6	0.00	1.00
08/15/2025 02:00	2	1.5	10.3	14.3	21.0	750,071.1	0.00	1.00
08/15/2025 03:00	2	1.3	10.6	14.3	28.7	751,316.0	0.00	1.00
08/15/2025 04:00	2	1.3	10.5	14.3	26.7	752,975.9	0.00	1.00
08/15/2025 05:00	2	1.3	10.3	14.3	24.2	762,935.4	0.00	1.00
08/15/2025 06:00	2	1.4	9.5	14.3	23.0	780,779.4	0.00	1.00
08/15/2025 07:00	2	1.3	10.5	14.4	27.1	763,717.4	0.00	1.00
08/15/2025 08:00	2	1.4	10.4	14.4	25.3	762,032.0	0.00	1.00
08/15/2025 09:00	2	1.4	10.4	14.4	25.7	760,767.9	0.00	1.00
08/15/2025 10:00	2	1.2	10.2	14.4	26.6	759,714.5	0.00	1.00
08/15/2025 11:00	2	1.3	10.3	14.5	23.9	772,440.9	0.00	1.00
08/15/2025 12:00	2	1.1	8.9	14.5	22.0	772,440.9	0.00	1.00
08/15/2025 13:00	1	1.2	8.3	14.5	17.5	772,440.9	0.00	1.00
08/15/2025 14:00	1	1.3	8.4	14.6	17.4	784,484.5	0.00	1.00
08/15/2025 15:00	1	1.3	8.3	14.6	17.6	784,267.2	0.00	1.00
08/15/2025 16:00	1	1.2	8.2	14.5	17.6	771,157.1	0.00	1.00
08/15/2025 17:00	1	1.3	8.2	14.5	17.5	773,082.9	0.00	1.00
08/15/2025 18:00	1	1.3	8.2	14.5	17.5	772,440.9	0.00	1.00
08/15/2025 19:00	1	1.3	8.2	14.4	17.9	760,767.9	0.00	1.00
08/15/2025 20:00	2	1.3	10.1	14.4	26.4	761,821.3	0.00	1.00
08/15/2025 21:00	2	1.3	10.1	14.4	23.3	762,664.0	0.00	1.00
08/15/2025 22:00	2	1.3	10.2	14.4	27.0	763,717.4	0.00	1.00
08/15/2025 23:00	1	1.2	9.1	14.4	20.8	788,156.4	0.00	1.00
Average/Sum#:	2	1.3	9.4	14.4	22.1	766,433.4	0.00 #	24.00 #
Minimum:	1	1.1	8.2	14.3	17.4	749,863.6	0.00	1.00
Maximum:	2	1.5	10.6	14.6	28.7	788,156.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/16/2025 00:00	1	1.3	8.6	14.5	22.6	914,090.8	0.00	1.00
08/16/2025 01:00	2	1.3	9.6	14.3	24.1	753,390.9	0.00	1.00
08/16/2025 02:00	2	1.5	10.5	14.3	23.6	754,635.8	0.00	1.00
08/16/2025 03:00	2	1.6	10.3	14.3	22.7	755,050.8	0.00	1.00
08/16/2025 04:00	2	1.3	10.2	14.3	24.9	755,258.3	0.00	1.00
08/16/2025 05:00	2	1.3	10.2	14.3	26.2	755,258.3	0.00	1.00
08/16/2025 06:00	2	1.3	10.2	14.3	25.3	756,088.3	0.00	1.00
08/16/2025 07:00	2	1.4	10.2	14.3	25.6	756,295.7	0.00	1.00
08/16/2025 08:00	2	1.3	10.2	14.4	24.8	765,824.3	0.00	1.00
08/16/2025 09:00	2	1.3	10.2	14.4	26.7	764,981.5	0.00	1.00
08/16/2025 10:00	2	1.2	10.1	14.4	25.6	764,138.8	0.00	1.00
08/16/2025 11:00	2	1.3	10.0	14.4	23.4	765,613.6	0.00	1.00
08/16/2025 12:00	2	1.4	9.9	14.4	25.6	765,613.6	0.00	1.00
08/16/2025 13:00	2	1.2	10.0	14.4	24.5	766,245.6	0.00	1.00
08/16/2025 14:00	2	1.2	9.2	14.5	23.1	825,934.1	0.00	1.00
08/16/2025 15:00	2	1.3	9.6	14.4	23.3	765,613.6	0.00	1.00
08/16/2025 16:00	2	1.3	9.8	14.4	23.5	763,296.1	0.00	1.00
08/16/2025 17:00	2	1.2	9.4	14.4	23.3	781,625.3	0.00	1.00
08/16/2025 18:00	2	1.4	9.5	14.4	21.9	770,669.9	0.00	1.00
08/16/2025 19:00	2	1.3	9.3	14.5	24.6	820,798.7	0.00	1.00
08/16/2025 20:00	2	1.3	10.0	14.4	25.1	761,821.3	0.00	1.00
08/16/2025 21:00	2	1.3	9.7	14.4	23.6	765,824.3	0.00	1.00
08/16/2025 22:00	2	1.3	9.7	14.4	23.7	767,509.7	0.00	1.00
08/16/2025 23:00	1	1.3	8.5	14.5	21.8	899,540.6	0.00	1.00
Average/Sum#:	2	1.3	9.8	14.4	24.1	779,796.7	0.00 #	24.00 #
Minimum:	1	1.2	8.5	14.3	21.8	753,390.9	0.00	1.00
Maximum:	2	1.6	10.5	14.5	26.7	914,090.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/17/2025 00:00	2	1.3	9.1	14.4	22.6	759,925.2	0.00	1.00
08/17/2025 01:00	2	1.2	10.2	14.4	26.8	760,767.9	0.00	1.00
08/17/2025 02:00	2	1.3	10.8	14.4	24.0	760,346.6	0.00	1.00
08/17/2025 03:00	2	1.2	10.6	14.4	30.3	760,557.2	0.00	1.00
08/17/2025 04:00	2	1.4	10.6	14.4	24.6	761,189.3	0.00	1.00
08/17/2025 05:00	2	1.3	10.5	14.3	27.7	750,693.5	0.00	1.00
08/17/2025 06:00	2	1.4	10.5	14.3	25.7	751,523.5	0.00	1.00
08/17/2025 07:00	2	1.2	10.4	14.4	27.4	763,296.1	0.00	1.00
08/17/2025 08:00	2	1.3	10.4	14.4	24.7	761,400.0	0.00	1.00
08/17/2025 09:00	2	1.3	10.4	14.4	26.0	760,978.6	0.00	1.00
08/17/2025 10:00	2	1.3	10.3	14.4	27.9	761,821.3	0.00	1.00
08/17/2025 11:00	2	1.4	10.2	14.4	25.0	764,138.8	0.00	1.00
08/17/2025 12:00	2	1.3	10.1	14.4	26.3	764,349.5	0.00	1.00
08/17/2025 13:00	2	1.3	10.2	14.4	24.3	765,192.2	0.00	1.00
08/17/2025 14:00	2	1.3	10.5	14.5	28.5	776,720.4	0.00	1.00
08/17/2025 15:00	2	1.4	10.7	14.5	25.4	776,078.5	0.00	1.00
08/17/2025 16:00	2	1.3	10.0	14.5	26.6	803,039.0	0.00	1.00
08/17/2025 17:00	1	1.3	9.6	14.6	24.4	894,908.0	0.00	1.00
08/17/2025 18:00	1	1.3	8.9	14.6	26.0	963,161.8	0.00	1.00
08/17/2025 19:00	1	1.3	8.6	14.6	23.2	963,379.2	0.00	1.00
08/17/2025 20:00	2	1.3	8.6	14.6	26.8	961,640.2	0.00	1.00
08/17/2025 21:00	1	1.3	8.6	14.6	24.8	960,770.8	0.00	1.00
08/17/2025 22:00	1	1.2	8.6	14.6	25.9	960,118.7	0.00	1.00
08/17/2025 23:00	1	1.3	8.6	14.5	23.7	927,143.1	0.00	1.00
Average/Sum#:	2	1.3	9.9	14.5	25.8	818,047.5	0.00 #	24.00 #
Minimum:	1	1.2	8.6	14.3	22.6	750,693.5	0.00	1.00
Maximum:	2	1.4	10.8	14.6	30.3	963,379.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 **To:** 09/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/18/2025 00:00	2	1.3	10.6	14.3	28.4	753,805.9	0.00	1.00
08/18/2025 01:00	2	1.3	10.5	14.3	25.5	754,220.9	0.00	1.00
08/18/2025 02:00	2	1.1	11.0	14.3	29.2	754,428.3	0.00	1.00
08/18/2025 03:00	2	1.2	10.8	14.3	30.7	754,220.9	0.00	1.00
08/18/2025 04:00	2	1.4	10.0	14.4	22.8	800,165.2	0.00	1.00
08/18/2025 05:00	2	1.3	9.5	14.4	27.3	885,280.2	0.00	1.00
08/18/2025 06:00	2	1.3	10.9	14.3	27.4	756,295.7	0.00	1.00
08/18/2025 07:00	3	1.3	10.8	14.3	30.4	756,710.7	0.00	1.00
08/18/2025 08:00	2	1.3	10.9	14.4	27.4	766,456.3	0.00	1.00
08/18/2025 09:00	2	1.3	10.9	14.4	29.0	765,824.3	0.00	1.00
08/18/2025 10:00	2	1.3	10.9	14.4	28.5	765,613.6	0.00	1.00
08/18/2025 11:00	1	1.4	8.5	14.5	19.1	934,204.2	0.00	1.00
08/18/2025 12:00	1	1.4	8.4	14.5	22.6	941,693.2	0.00	1.00
08/18/2025 13:00	1	1.3	8.3	14.6	22.4	965,987.6	0.00	1.00
08/18/2025 14:00	1	1.3	8.4	14.6	24.0	969,248.1	0.00	1.00
08/18/2025 15:00	1	1.2	8.5	14.6	25.5	970,987.1	0.00	1.00
08/18/2025 16:00	2	1.3	9.7	14.5	25.4	855,890.2	0.00	1.00
08/18/2025 17:00	2	1.3	9.3	14.5	23.8	865,091.1	0.00	1.00
08/18/2025 18:00	1	1.3	8.3	14.6	24.9	971,639.2	0.00	1.00
08/18/2025 19:00	1	1.2	8.8	14.6	25.9	967,291.8	0.00	1.00
08/18/2025 20:00	2	1.4	9.4	14.6	28.2	964,248.7	0.00	1.00
08/18/2025 21:00	2	1.3	9.3	14.6	27.2	935,556.0	0.00	1.00
08/18/2025 22:00	2	1.3	9.7	14.5	25.4	864,877.1	0.00	1.00
08/18/2025 23:00	2	1.3	10.3	14.4	27.7	786,471.0	0.00	1.00
Average/Sum#:	2	1.3	9.7	14.5	26.2	854,425.3	0.00 #	24.00 #
Minimum:	1	1.1	8.3	14.3	19.1	753,805.9	0.00	1.00
Maximum:	3	1.4	11.0	14.6	30.7	971,639.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/19/2025 00:00	2	1.4	10.8	14.4	28.1	763,717.4	0.00	1.00
08/19/2025 01:00	2	1.4	10.8	14.4	27.2	764,349.5	0.00	1.00
08/19/2025 02:00	2	1.3	11.2	14.4	27.3	764,770.8	0.00	1.00
08/19/2025 03:00	2	1.6	11.0	14.4	23.9	764,981.5	0.00	1.00
08/19/2025 04:00	2	1.3	10.1	14.4	26.7	813,227.4	0.00	1.00
08/19/2025 05:00	2	1.4	9.9	14.4	26.4	820,601.2	0.00	1.00
08/19/2025 06:00	2	1.4	10.7	14.4	28.2	798,269.1	0.00	1.00
08/19/2025 07:00	2	1.4	11.1	14.4	29.4	767,931.1	0.00	1.00
08/19/2025 08:00	2	1.3	11.0	14.4	30.4	766,245.6	0.00	1.00
08/19/2025 09:00	2	1.4	10.9	14.4	27.7	764,770.8	0.00	1.00
08/19/2025 10:00	2	1.3	10.7	14.4	30.0	763,928.1	0.00	1.00
08/19/2025 11:00	2	1.2	9.8	14.5	24.9	813,951.6	0.00	1.00
08/19/2025 12:00	1	1.4	8.1	14.6	18.4	970,117.6	0.00	1.00
08/19/2025 13:00	1	1.4	8.2	14.6	21.9	969,682.9	0.00	1.00
08/19/2025 14:00	1	1.3	8.3	14.6	24.0	968,378.7	0.00	1.00
08/19/2025 15:00	1	1.3	8.4	14.6	22.6	966,205.0	0.00	1.00
08/19/2025 16:00	2	1.3	8.7	14.6	24.8	935,990.7	0.00	1.00
08/19/2025 17:00	2	1.3	9.3	14.5	24.1	865,733.0	0.00	1.00
08/19/2025 18:00	1	1.3	8.6	14.6	24.9	965,770.2	0.00	1.00
08/19/2025 19:00	1	1.3	8.6	14.6	23.7	960,988.1	0.00	1.00
08/19/2025 20:00	1	1.2	8.5	14.5	25.1	947,470.5	0.00	1.00
08/19/2025 21:00	1	1.3	8.4	14.5	22.8	947,042.6	0.00	1.00
08/19/2025 22:00	2	1.3	8.6	14.5	24.9	932,920.4	0.00	1.00
08/19/2025 23:00	2	1.4	9.4	14.4	24.9	867,583.0	0.00	1.00
Average/Sum#:	2	1.3	9.6	14.5	25.5	861,026.1	0.00 #	24.00 #
Minimum:	1	1.2	8.1	14.4	18.4	763,717.4	0.00	1.00
Maximum:	2	1.6	11.2	14.6	30.4	970,117.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/20/2025 00:00	2	1.2	10.1	14.3	27.9	766,462.7	0.00	1.00
08/20/2025 01:00	2	1.3	10.7	14.3	26.8	756,503.2	0.00	1.00
08/20/2025 02:00	2	1.1	11.4	14.4	33.2	767,299.0	0.00	1.00
08/20/2025 03:00	2	1.5	11.2	14.3	25.3	755,050.8	0.00	1.00
08/20/2025 04:00	2	1.4	10.8	14.4	27.9	776,779.6	0.00	1.00
08/20/2025 05:00	2	1.4	10.0	14.4	24.5	841,247.9	0.00	1.00
08/20/2025 06:00	2	1.2	9.4	14.5	27.4	908,955.4	0.00	1.00
08/20/2025 07:00	2	1.2	9.2	14.5	29.7	892,479.5	0.00	1.00
08/20/2025 08:00	1	1.2	9.4	14.7	27.0	983,335.1	0.00	1.00
08/20/2025 09:00	1	1.4	9.6	14.6	27.8	964,466.0	0.00	1.00
08/20/2025 10:00	1	1.3	9.6	14.7	27.4	968,978.2	0.00	1.00
08/20/2025 11:00	1	1.3	8.8	14.6	25.5	968,161.3	0.00	1.00
08/20/2025 12:00	1	1.3	8.7	14.6	24.3	967,509.2	0.00	1.00
08/20/2025 13:00	2	1.3	9.2	14.4	28.0	950,801.9	0.00	1.00
08/20/2025 14:00	3	2.1	14.0	12.5	39.1	982,072.9	0.00	1.00
08/20/2025 15:00	2	1.8	11.8	13.2	33.6	963,221.1	0.00	1.00
08/20/2025 16:00	2	1.6	10.6	13.6	30.1	960,285.4	0.00	1.00
08/20/2025 17:00	2	1.6	11.4	13.3	34.6	964,363.1	0.00	1.00
08/20/2025 18:00	3	2.0	13.6	12.6	40.3	969,156.5	0.00	1.00
08/20/2025 19:00	2	1.7	10.5	13.7	29.2	965,444.2	0.00	1.00
08/20/2025 20:00	2	1.5	10.4	13.8	32.1	974,798.7	0.00	1.00
08/20/2025 21:00	2	1.6	10.3	13.8	29.8	973,062.8	0.00	1.00
08/20/2025 22:00	1	1.3	8.3	14.6	23.2	965,770.2	0.00	1.00
08/20/2025 23:00	2	1.2	8.3	14.6	26.0	950,989.2	0.00	1.00
Average/Sum#:	2	1.4	10.3	14.1	29.2	914,049.7	0.00 #	24.00 #
Minimum:	1	1.1	8.3	12.5	23.2	755,050.8	0.00	1.00
Maximum:	3	2.1	14.0	14.7	40.3	983,335.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/21/2025 00:00	2	1.2	9.1	14.6	27.1	945,772.3	0.00	1.00
08/21/2025 01:00	2	1.3	9.5	14.6	28.0	924,470.1	0.00	1.00
08/21/2025 02:00	2	1.3	9.7	14.6	26.2	957,945.0	0.00	1.00
08/21/2025 03:00	2	1.3	10.0	14.4	32.4	940,899.9	0.00	1.00
08/21/2025 04:00	2	2.0	13.5	13.0	38.2	978,358.4	0.00	1.00
08/21/2025 05:00	3	2.0	14.7	12.6	45.6	988,790.4	0.00	1.00
08/21/2025 06:00	2	1.6	11.7	13.7	36.4	953,081.3	0.00	1.00
08/21/2025 07:00	2	1.3	10.6	14.4	28.7	768,352.4	0.00	1.00
08/21/2025 08:00	2	1.4	10.5	14.5	27.5	773,296.8	0.00	1.00
08/21/2025 09:00	2	1.3	10.3	14.5	26.3	772,654.9	0.00	1.00
08/21/2025 10:00	1	1.3	8.5	14.5	18.6	780,785.9	0.00	1.00
08/21/2025 11:00	2	1.2	8.9	14.5	24.2	884,990.5	0.00	1.00
08/21/2025 12:00	2	1.7	11.0	13.6	30.0	937,211.5	0.00	1.00
08/21/2025 13:00	3	2.2	14.7	12.2	45.0	980,004.2	0.00	1.00
08/21/2025 14:00	4	2.2	14.9	12.0	47.2	967,367.5	0.00	1.00
08/21/2025 15:00	3	2.0	14.8	12.3	46.2	965,921.9	0.00	1.00
08/21/2025 16:00	2	2.0	13.3	12.9	36.9	969,552.5	0.00	1.00
08/21/2025 17:00	3	2.0	12.7	13.0	37.6	974,198.1	0.00	1.00
08/21/2025 18:00	4	2.3	15.0	11.8	49.8	954,383.5	0.00	1.00
08/21/2025 19:00	0	0.0	0.0	0.0	49.4	384,618.2	0.00	1.00
08/21/2025 20:00	3	1.9	14.6	12.3	44.7	962,100.2	0.00	1.00
08/21/2025 21:00	3	1.9	13.0	12.8	37.3	966,205.0	0.00	1.00
08/21/2025 22:00	2	1.7	11.3	13.4	31.8	964,074.8	0.00	1.00
08/21/2025 23:00	2	1.8	12.0	13.2	34.7	967,845.1	0.00	1.00
Average/Sum#:	2	1.7	11.9	13.5	35.4	925,141.8	0.00 #	24.00 #
Minimum:	1	1.2	8.5	11.8	18.6	768,352.4	0.00	1.00
Maximum:	4	2.3	15.0	14.6	49.8	988,790.4	0.00	1.00
%SI	4.17	4.17	4.17	4.17	0.00	4.17	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 **To:** 09/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/22/2025 00:00	2	1.6	10.5	13.8	29.9	972,869.9	0.00	1.00
08/22/2025 01:00	2	1.5	9.8	14.2	28.5	899,936.7	0.00	1.00
08/22/2025 02:00	2	1.4	10.9	14.4	26.0	765,192.2	0.00	1.00
08/22/2025 03:00	2	1.5	10.7	14.4	23.5	765,613.6	0.00	1.00
08/22/2025 04:00	2	1.4	9.8	14.4	26.8	875,799.6	0.00	1.00
08/22/2025 05:00	2	1.6	11.2	13.9	32.7	984,420.5	0.00	1.00
08/22/2025 06:00	2	1.5	10.6	14.2	31.7	895,031.3	0.00	1.00
08/22/2025 07:00	2	1.3	10.5	14.4	28.3	766,034.9	0.00	1.00
08/22/2025 08:00	2	1.3	10.5	14.5	26.2	774,794.6	0.00	1.00
08/22/2025 09:00	2	1.3	10.6	14.5	28.8	772,227.0	0.00	1.00
08/22/2025 10:00	1	1.3	8.7	14.5	18.9	771,157.1	0.00	1.00
08/22/2025 11:00	1	1.3	8.4	14.6	21.8	868,823.7	0.00	1.00
08/22/2025 12:00	1	1.2	9.1	14.5	23.3	862,309.4	0.00	1.00
08/22/2025 13:00	1	1.3	8.9	14.4	25.7	933,526.1	0.00	1.00
08/22/2025 14:00	3	2.1	14.4	12.1	43.6	967,934.1	0.00	1.00
08/22/2025 15:00	3	2.1	14.5	12.3	43.4	961,941.0	0.00	1.00
08/22/2025 16:00	4	2.3	14.9	11.9	48.9	959,510.0	0.00	1.00
08/22/2025 17:00	4	2.3	15.2	11.9	50.2	968,335.2	0.00	1.00
08/22/2025 18:00	3	2.0	14.7	12.3	45.2	960,985.6	0.00	1.00
08/22/2025 19:00	3	2.0	14.5	12.5	43.9	966,585.4	0.00	1.00
08/22/2025 20:00	4	2.2	15.6	12.1	49.7	977,893.5	0.00	1.00
08/22/2025 21:00	4	2.3	15.9	11.9	51.1	972,899.9	0.00	1.00
08/22/2025 22:00	4	2.2	15.3	12.1	48.6	977,582.3	0.00	1.00
08/22/2025 23:00	3	2.0	13.7	12.6	42.2	970,146.4	0.00	1.00
Average/Sum#:	2	1.7	12.0	13.4	35.0	899,647.9	0.00 #	24.00 #
Minimum:	1	1.2	8.4	11.9	18.9	765,192.2	0.00	1.00
Maximum:	4	2.3	15.9	14.6	51.1	984,420.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/23/2025 00:00	2	1.8	11.9	13.5	33.4	950,639.6	0.00	1.00
08/23/2025 01:00	2	1.7	11.6	13.5	34.7	945,828.1	0.00	1.00
08/23/2025 02:00	2	1.6	12.0	13.6	35.3	955,783.2	0.00	1.00
08/23/2025 03:00	2	1.7	11.8	13.6	32.9	953,719.7	0.00	1.00
08/23/2025 04:00	2	1.6	11.5	13.7	34.6	961,640.2	0.00	1.00
08/23/2025 05:00	3	1.9	13.4	13.1	40.1	974,222.6	0.00	1.00
08/23/2025 06:00	2	1.4	10.4	14.3	29.7	846,553.3	0.00	1.00
08/23/2025 07:00	2	1.2	10.5	14.4	27.7	763,928.1	0.00	1.00
08/23/2025 08:00	2	1.4	10.5	14.5	25.5	773,724.8	0.00	1.00
08/23/2025 09:00	2	1.4	9.7	14.4	25.6	866,318.9	0.00	1.00
08/23/2025 10:00	2	1.6	10.6	13.8	29.8	972,484.2	0.00	1.00
08/23/2025 11:00	1	1.2	8.7	14.6	22.6	884,256.9	0.00	1.00
08/23/2025 12:00	2	1.7	10.8	13.6	30.5	968,914.6	0.00	1.00
08/23/2025 13:00	4	2.2	15.0	12.0	47.2	967,829.1	0.00	1.00
08/23/2025 14:00	4	2.3	15.1	11.7	51.2	955,768.9	0.00	1.00
08/23/2025 15:00	4	2.3	15.2	12.0	47.6	955,212.0	0.00	1.00
08/23/2025 16:00	4	2.2	15.3	12.0	50.5	969,675.6	0.00	1.00
08/23/2025 17:00	3	2.0	13.7	12.8	39.9	973,982.0	0.00	1.00
08/23/2025 18:00	3	1.8	13.3	13.0	40.8	975,064.8	0.00	1.00
08/23/2025 19:00	2	1.6	11.6	13.6	35.0	972,103.7	0.00	1.00
08/23/2025 20:00	2	1.7	11.4	13.6	34.0	971,916.1	0.00	1.00
08/23/2025 21:00	3	1.9	13.8	12.8	42.3	971,784.1	0.00	1.00
08/23/2025 22:00	3	2.0	14.2	12.7	44.7	986,987.6	0.00	1.00
08/23/2025 23:00	3	2.0	14.4	12.6	43.3	980,210.9	0.00	1.00
Average/Sum#:	3	1.8	12.4	13.3	36.6	937,439.5	0.00 #	24.00 #
Minimum:	1	1.2	8.7	11.7	22.6	763,928.1	0.00	1.00
Maximum:	4	2.3	15.3	14.6	51.2	986,987.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/24/2025 00:00	2	1.6	11.0	13.8	33.2	978,849.1	0.00	1.00
08/24/2025 01:00	2	1.6	10.5	13.9	31.2	976,595.2	0.00	1.00
08/24/2025 02:00	2	1.7	11.4	13.8	30.4	967,855.1	0.00	1.00
08/24/2025 03:00	2	1.7	11.2	13.8	32.9	969,591.0	0.00	1.00
08/24/2025 04:00	2	1.4	10.0	14.4	26.8	815,334.2	0.00	1.00
08/24/2025 05:00	2	1.2	9.6	14.5	27.2	881,139.0	0.00	1.00
08/24/2025 06:00	2	1.4	10.2	14.4	27.0	792,580.7	0.00	1.00
08/24/2025 07:00	2	1.2	10.5	14.4	27.6	765,613.6	0.00	1.00
08/24/2025 08:00	2	1.3	10.4	14.4	24.6	763,928.1	0.00	1.00
08/24/2025 09:00	2	1.3	10.4	14.4	28.2	762,664.0	0.00	1.00
08/24/2025 10:00	2	1.4	10.3	14.5	24.4	773,296.8	0.00	1.00
08/24/2025 11:00	2	1.2	10.3	14.5	28.8	773,938.7	0.00	1.00
08/24/2025 12:00	1	1.2	8.7	14.6	19.3	808,177.8	0.00	1.00
08/24/2025 13:00	1	1.3	8.2	14.6	20.1	862,954.7	0.00	1.00
08/24/2025 14:00	1	1.2	9.1	14.4	25.7	921,095.9	0.00	1.00
08/24/2025 15:00	2	1.8	11.8	13.2	32.3	954,150.9	0.00	1.00
08/24/2025 16:00	3	2.0	13.7	12.5	40.3	945,391.9	0.00	1.00
08/24/2025 17:00	3	1.9	12.7	12.9	37.2	957,741.2	0.00	1.00
08/24/2025 18:00	3	1.9	13.3	12.8	40.2	949,298.5	0.00	1.00
08/24/2025 19:00	3	2.0	14.2	12.5	42.9	956,477.7	0.00	1.00
08/24/2025 20:00	2	1.7	11.7	13.4	33.5	956,588.6	0.00	1.00
08/24/2025 21:00	2	1.7	11.0	13.7	32.0	958,977.5	0.00	1.00
08/24/2025 22:00	2	1.7	11.4	13.6	33.9	953,719.7	0.00	1.00
08/24/2025 23:00	2	1.7	11.5	13.6	33.8	955,783.2	0.00	1.00
Average/Sum#:	2	1.5	11.0	13.9	30.6	891,739.3	0.00 #	24.00 #
Minimum:	1	1.2	8.2	12.5	19.3	762,664.0	0.00	1.00
Maximum:	3	2.0	14.2	14.6	42.9	978,849.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/25/2025 00:00	2	1.6	11.2	13.8	33.9	971,326.9	0.00	1.00
08/25/2025 01:00	2	1.6	11.1	13.8	32.5	970,169.7	0.00	1.00
08/25/2025 02:00	2	1.6	11.4	13.8	33.2	970,169.7	0.00	1.00
08/25/2025 03:00	2	1.6	11.1	13.9	32.9	981,877.3	0.00	1.00
08/25/2025 04:00	2	1.7	11.1	13.8	32.4	974,798.7	0.00	1.00
08/25/2025 05:00	2	1.6	11.9	13.5	36.7	983,394.8	0.00	1.00
08/25/2025 06:00	3	1.9	13.4	13.0	40.2	982,518.7	0.00	1.00
08/25/2025 07:00	2	1.3	10.2	14.3	29.6	851,325.5	0.00	1.00
08/25/2025 08:00	2	1.7	10.6	14.4	20.1	765,824.3	0.00	1.00
08/25/2025 09:00	2	1.3	9.9	14.5	26.1	821,440.7	0.00	1.00
08/25/2025 10:00	1	1.3	9.1	14.6	25.0	926,426.5	0.00	1.00
08/25/2025 11:00	2	1.2	9.4	14.5	24.9	800,043.4	0.00	1.00
08/25/2025 12:00	1	1.3	8.6	14.6	22.7	963,161.8	0.00	1.00
08/25/2025 13:00	3	1.9	12.8	12.9	37.9	970,921.9	0.00	1.00
08/25/2025 14:00	2	1.6	11.0	13.4	31.6	956,771.2	0.00	1.00
08/25/2025 15:00	2	1.7	11.4	13.3	32.7	961,119.7	0.00	1.00
08/25/2025 16:00	2	1.8	11.6	13.1	33.1	949,818.7	0.00	1.00
08/25/2025 17:00	3	2.1	14.4	12.1	45.4	962,331.9	0.00	1.00
08/25/2025 18:00	4	2.2	14.7	12.1	46.9	970,890.8	0.00	1.00
08/25/2025 19:00	2	1.7	11.0	13.5	30.8	968,405.1	0.00	1.00
08/25/2025 20:00	2	1.7	11.7	13.2	33.3	959,664.2	0.00	1.00
08/25/2025 21:00	2	1.7	10.2	13.7	28.1	962,781.4	0.00	1.00
08/25/2025 22:00	2	1.6	10.4	13.8	32.0	976,534.6	0.00	1.00
08/25/2025 23:00	2	1.7	11.2	13.5	31.8	951,194.8	0.00	1.00
Average/Sum#:	2	1.6	11.2	13.6	32.2	939,704.7	0.00 #	24.00 #
Minimum:	1	1.2	8.6	12.1	20.1	765,824.3	0.00	1.00
Maximum:	4	2.2	14.7	14.6	46.9	983,394.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/26/2025 00:00	2	1.7	11.2	13.6	32.7	959,535.0	0.00	1.00
08/26/2025 01:00	2	1.6	11.1	13.7	33.1	964,303.0	0.00	1.00
08/26/2025 02:00	2	1.4	11.5	13.8	35.3	973,834.3	0.00	1.00
08/26/2025 03:00	2	1.7	11.4	13.7	34.2	977,997.2	0.00	1.00
08/26/2025 04:00	2	1.7	11.9	13.5	35.6	981,729.2	0.00	1.00
08/26/2025 05:00	3	2.1	14.6	12.5	44.8	983,377.1	0.00	1.00
08/26/2025 06:00	3	1.9	13.5	13.0	40.8	969,864.5	0.00	1.00
08/26/2025 07:00	2	1.7	11.9	13.5	35.7	982,654.5	0.00	1.00
08/26/2025 08:00	2	1.6	10.9	13.8	32.8	973,641.4	0.00	1.00
08/26/2025 09:00	1	2.1	11.0	13.8	25.5	940,852.4	0.02	0.33
08/26/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2025 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2025 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2025 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2025 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2025 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2025 17:00	0	0.6	4.7	20.4	0.0	1,722,735.9	0.08	0.08
08/26/2025 18:00	0	2.2	5.0	20.3	0.0	1,401,377.6	0.17	0.17
08/26/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2025 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	2	1.7	10.7	14.6	29.2	1,069,325.2	0.27 #	9.58 #
Minimum:	1	0.6	4.7	12.5	0.0	940,852.4	0.00	0.00
Maximum:	3	2.2	14.6	20.4	44.8	1,722,735.9	0.17	1.00
%SI	58.33	50.00	50.00	50.00	50.00	50.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/27/2025 00:00	0	4.2	6.2	20.0	0.0	1,109,233.8	0.10	0.10
08/27/2025 01:00	3	8.5	16.4	14.8	18.2	797,633.6	0.90	1.00
08/27/2025 02:00	2	1.3	11.4	14.4	27.2	763,296.1	0.00	1.00
08/27/2025 03:00	2	1.2	11.1	14.4	27.3	763,506.8	0.00	1.00
08/27/2025 04:00	2	1.3	10.5	14.4	25.8	780,782.6	0.00	1.00
08/27/2025 05:00	2	1.2	10.2	14.4	28.0	786,892.3	0.00	1.00
08/27/2025 06:00	2	1.3	10.5	14.4	24.9	763,928.1	0.00	1.00
08/27/2025 07:00	2	1.3	10.4	14.4	27.7	764,349.5	0.00	1.00
08/27/2025 08:00	2	1.2	10.3	14.4	27.1	763,085.4	0.00	1.00
08/27/2025 09:00	2	1.3	10.2	14.5	24.2	774,152.7	0.00	1.00
08/27/2025 10:00	2	1.3	10.2	14.5	28.5	774,366.7	0.00	1.00
08/27/2025 11:00	2	1.3	10.3	14.5	27.0	776,078.5	0.00	1.00
08/27/2025 12:00	1	1.2	9.1	14.6	23.4	869,475.8	0.00	1.00
08/27/2025 13:00	1	1.3	8.7	14.6	25.3	967,291.8	0.00	1.00
08/27/2025 14:00	1	1.2	8.7	14.6	24.5	966,857.1	0.00	1.00
08/27/2025 15:00	2	1.3	8.8	14.6	27.1	966,857.1	0.00	1.00
08/27/2025 16:00	2	1.2	9.1	14.6	25.8	909,906.4	0.00	1.00
08/27/2025 17:00	1	1.3	9.1	14.5	25.2	946,186.7	0.00	1.00
08/27/2025 18:00	2	1.6	10.5	13.9	30.2	986,963.7	0.00	1.00
08/27/2025 19:00	2	1.5	10.5	13.9	32.5	983,246.7	0.00	1.00
08/27/2025 20:00	2	1.6	10.9	13.8	32.8	977,691.9	0.00	1.00
08/27/2025 21:00	2	1.5	10.4	14.1	30.8	890,327.2	0.00	1.00
08/27/2025 22:00	2	1.3	10.2	14.4	24.7	762,874.7	0.00	1.00
08/27/2025 23:00	2	1.3	10.2	14.4	29.0	764,138.8	0.00	1.00
Average/Sum#:	2	1.7	10.2	14.6	25.7	858,713.5	1.00 #	23.10 #
Minimum:	1	1.2	6.2	13.8	0.0	762,874.7	0.00	0.10
Maximum:	3	8.5	16.4	20.0	32.8	1,109,233.8	0.90	1.00
%SI	4.17	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/28/2025 00:00	2	1.4	10.3	14.4	23.6	765,192.2	0.00	1.00
08/28/2025 01:00	2	1.2	9.4	14.5	27.6	902,322.3	0.00	1.00
08/28/2025 02:00	2	1.6	11.3	14.0	31.5	993,725.8	0.00	1.00
08/28/2025 03:00	2	1.5	10.6	14.2	33.0	975,766.0	0.00	1.00
08/28/2025 04:00	2	1.3	9.8	14.5	28.7	849,899.0	0.00	1.00
08/28/2025 05:00	2	1.2	10.5	14.4	27.2	774,251.5	0.00	1.00
08/28/2025 06:00	2	1.4	10.2	14.5	25.0	829,999.6	0.00	1.00
08/28/2025 07:00	2	1.3	10.5	14.4	29.4	766,245.6	0.00	1.00
08/28/2025 08:00	2	1.3	10.6	14.4	26.7	764,981.5	0.00	1.00
08/28/2025 09:00	2	1.3	10.7	14.4	29.5	763,928.1	0.00	1.00
08/28/2025 10:00	2	1.2	10.7	14.5	28.9	774,580.7	0.00	1.00
08/28/2025 11:00	2	1.3	10.6	14.5	26.8	776,506.4	0.00	1.00
08/28/2025 12:00	2	1.3	10.4	14.5	27.7	776,934.4	0.00	1.00
08/28/2025 13:00	1	1.2	8.2	14.6	18.8	830,132.0	0.00	1.00
08/28/2025 14:00	2	1.3	9.4	14.5	24.4	826,790.0	0.00	1.00
08/28/2025 15:00	2	1.3	9.4	14.5	24.9	848,615.2	0.00	1.00
08/28/2025 16:00	2	1.3	9.7	14.4	27.0	876,010.2	0.00	1.00
08/28/2025 17:00	2	1.6	10.7	13.8	30.1	974,798.7	0.00	1.00
08/28/2025 18:00	2	1.5	10.6	13.9	32.8	986,963.7	0.00	1.00
08/28/2025 19:00	2	1.7	11.2	13.8	32.3	980,199.3	0.00	1.00
08/28/2025 20:00	2	1.7	11.9	13.6	34.1	970,603.0	0.00	1.00
08/28/2025 21:00	2	1.6	11.1	13.7	33.4	968,107.0	0.00	1.00
08/28/2025 22:00	2	1.6	10.8	13.8	32.0	974,605.8	0.00	1.00
08/28/2025 23:00	2	1.6	10.8	13.8	32.0	973,255.7	0.00	1.00
Average/Sum#:	2	1.4	10.4	14.2	28.6	871,850.6	0.00 #	24.00 #
Minimum:	1	1.2	8.2	13.6	18.8	763,928.1	0.00	1.00
Maximum:	2	1.7	11.9	14.6	34.1	993,725.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/29/2025 00:00	2	1.5	10.7	13.9	33.5	984,420.5	0.00	1.00
08/29/2025 01:00	2	1.5	10.1	14.2	29.2	903,206.9	0.00	1.00
08/29/2025 02:00	2	1.4	10.8	14.4	25.7	764,560.2	0.00	1.00
08/29/2025 03:00	2	1.5	10.7	14.4	23.6	765,613.6	0.00	1.00
08/29/2025 04:00	3	1.3	10.6	14.4	30.5	765,402.9	0.00	1.00
08/29/2025 05:00	2	1.3	10.5	14.4	26.8	765,613.6	0.00	1.00
08/29/2025 06:00	2	1.3	10.5	14.4	25.7	765,824.3	0.00	1.00
08/29/2025 07:00	2	1.3	10.4	14.4	27.0	764,981.5	0.00	1.00
08/29/2025 08:00	2	1.3	10.4	14.4	26.8	764,138.8	0.00	1.00
08/29/2025 09:00	2	1.3	10.4	14.4	27.7	763,506.8	0.00	1.00
08/29/2025 10:00	2	1.3	10.4	14.5	26.8	774,794.6	0.00	1.00
08/29/2025 11:00	2	1.3	10.4	14.5	27.7	775,650.5	0.00	1.00
08/29/2025 12:00	2	1.2	9.9	14.5	25.9	775,008.6	0.00	1.00
08/29/2025 13:00	1	1.2	8.6	14.6	18.9	785,354.0	0.00	1.00
08/29/2025 14:00	1	1.3	8.5	14.6	17.9	784,484.5	0.00	1.00
08/29/2025 15:00	1	1.4	8.5	14.6	18.1	784,049.8	0.00	1.00
08/29/2025 16:00	1	1.4	8.6	14.6	18.5	790,353.5	0.00	1.00
08/29/2025 17:00	1	1.4	8.6	14.7	21.8	876,873.4	0.00	1.00
08/29/2025 18:00	2	1.1	8.8	14.5	22.0	780,785.9	0.00	1.00
08/29/2025 19:00	2	1.3	10.3	14.5	27.0	773,510.8	0.00	1.00
08/29/2025 20:00	2	1.2	10.1	14.5	25.8	778,860.1	0.00	1.00
08/29/2025 21:00	2	1.2	10.0	14.5	27.0	791,056.6	0.00	1.00
08/29/2025 22:00	2	1.2	10.1	14.5	26.2	774,580.7	0.00	1.00
08/29/2025 23:00	2	1.3	10.3	14.5	25.3	772,654.9	0.00	1.00
Average/Sum#:	2	1.3	9.9	14.5	25.2	792,720.3	0.00 #	24.00 #
Minimum:	1	1.1	8.5	13.9	17.9	763,506.8	0.00	1.00
Maximum:	3	1.5	10.8	14.7	33.5	984,420.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/30/2025 00:00	2	1.4	10.4	14.4	26.5	761,610.6	0.00	1.00
08/30/2025 01:00	2	1.3	10.4	14.4	25.1	762,242.7	0.00	1.00
08/30/2025 02:00	2	1.2	10.9	14.4	28.5	762,453.4	0.00	1.00
08/30/2025 03:00	2	1.2	10.7	14.4	29.6	763,296.1	0.00	1.00
08/30/2025 04:00	2	1.4	10.6	14.4	26.3	762,874.7	0.00	1.00
08/30/2025 05:00	2	1.3	10.6	14.4	25.9	763,928.1	0.00	1.00
08/30/2025 06:00	2	1.3	10.5	14.4	27.9	764,770.8	0.00	1.00
08/30/2025 07:00	2	1.2	10.5	14.4	27.7	763,928.1	0.00	1.00
08/30/2025 08:00	2	1.3	10.4	14.4	25.3	761,821.3	0.00	1.00
08/30/2025 09:00	2	1.3	10.6	14.5	26.1	772,013.0	0.00	1.00
08/30/2025 10:00	2	1.3	10.5	14.6	28.2	783,832.4	0.00	1.00
08/30/2025 11:00	1	1.2	8.3	14.6	18.2	786,223.5	0.00	1.00
08/30/2025 12:00	1	1.2	8.2	14.6	17.9	786,440.9	0.00	1.00
08/30/2025 13:00	1	1.2	8.1	14.6	17.8	784,049.8	0.00	1.00
08/30/2025 14:00	1	1.3	8.1	14.6	17.9	783,397.7	0.00	1.00
08/30/2025 15:00	1	1.3	8.1	14.6	18.0	782,745.6	0.00	1.00
08/30/2025 16:00	1	1.2	8.1	14.6	18.9	816,220.4	0.00	1.00
08/30/2025 17:00	2	1.3	9.7	14.4	27.6	868,215.1	0.00	1.00
08/30/2025 18:00	2	1.8	12.3	13.2	34.9	941,345.9	0.00	1.00
08/30/2025 19:00	3	1.9	14.1	12.6	39.4	888,640.9	0.00	1.00
08/30/2025 20:00	3	1.9	13.5	12.9	36.9	908,441.9	0.00	1.00
08/30/2025 21:00	3	1.7	12.7	13.3	36.9	939,136.8	0.00	1.00
08/30/2025 22:00	2	1.8	12.3	13.4	35.3	948,372.0	0.00	1.00
08/30/2025 23:00	2	1.4	10.9	14.0	32.2	868,691.4	0.00	1.00
Average/Sum#:	2	1.4	10.4	14.2	27.0	813,528.9	0.00 #	24.00 #
Minimum:	1	1.2	8.1	12.6	17.8	761,610.6	0.00	1.00
Maximum:	3	1.9	14.1	14.6	39.4	948,372.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/31/2025 00:00	2	1.3	10.4	14.5	27.5	771,157.1	0.00	1.00
08/31/2025 01:00	2	1.3	10.4	14.5	25.8	771,799.0	0.00	1.00
08/31/2025 02:00	2	1.1	11.1	14.5	32.2	772,654.9	0.00	1.00
08/31/2025 03:00	2	1.5	10.8	14.5	24.7	772,654.9	0.00	1.00
08/31/2025 04:00	2	1.3	10.6	14.5	25.8	772,868.9	0.00	1.00
08/31/2025 05:00	2	1.2	10.6	14.5	29.3	773,296.8	0.00	1.00
08/31/2025 06:00	2	1.3	10.6	14.5	27.7	774,152.7	0.00	1.00
08/31/2025 07:00	2	1.3	10.6	14.5	27.2	773,938.7	0.00	1.00
08/31/2025 08:00	2	1.3	10.6	14.5	28.4	771,585.1	0.00	1.00
08/31/2025 09:00	2	1.2	10.1	14.5	26.6	770,729.2	0.00	1.00
08/31/2025 10:00	1	1.2	8.4	14.6	17.9	782,528.2	0.00	1.00
08/31/2025 11:00	1	1.3	8.2	14.6	18.0	784,484.5	0.00	1.00
08/31/2025 12:00	1	1.2	8.1	14.6	18.7	839,478.9	0.00	1.00
08/31/2025 13:00	2	1.4	9.7	14.4	27.3	864,212.1	0.00	1.00
08/31/2025 14:00	2	1.6	10.9	13.7	30.8	970,579.5	0.00	1.00
08/31/2025 15:00	2	1.6	10.9	13.7	31.4	969,818.7	0.00	1.00
08/31/2025 16:00	2	1.7	11.1	13.6	32.3	963,849.7	0.00	1.00
08/31/2025 17:00	3	1.7	12.4	13.2	36.8	918,047.9	0.00	1.00
08/31/2025 18:00	2	1.8	12.3	13.3	34.0	902,558.8	0.00	1.00
08/31/2025 19:00	3	1.8	13.2	13.1	37.1	924,010.3	0.00	1.00
08/31/2025 20:00	1	1.4	8.8	14.5	20.0	801,755.2	0.00	1.00
08/31/2025 21:00	2	1.4	10.0	14.5	27.4	790,414.6	0.00	1.00
08/31/2025 22:00	2	1.1	9.6	14.6	26.5	859,259.5	0.00	1.00
08/31/2025 23:00	2	1.6	11.7	13.7	33.4	970,579.5	0.00	1.00
Average/Sum#:	2	1.4	10.5	14.2	27.8	836,100.6	0.00 #	24.00 #
Minimum:	1	1.1	8.1	13.1	17.9	770,729.2	0.00	1.00
Maximum:	3	1.8	13.2	14.6	37.1	970,579.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/01/2025 00:00	2	1.6	11.7	13.7	34.8	975,524.7	0.00	1.00
09/01/2025 01:00	2	1.7	11.6	13.7	34.4	970,959.9	0.00	1.00
09/01/2025 02:00	2	1.7	11.9	13.7	34.0	969,057.9	0.00	1.00
09/01/2025 03:00	2	1.6	11.4	13.8	36.6	980,585.0	0.00	1.00
09/01/2025 04:00	2	1.6	11.3	13.8	34.8	980,392.1	0.00	1.00
09/01/2025 05:00	2	1.6	11.2	13.9	34.4	987,941.9	0.00	1.00
09/01/2025 06:00	2	1.6	10.6	14.1	31.3	966,451.1	0.00	1.00
09/01/2025 07:00	2	1.3	10.5	14.5	29.4	779,074.1	0.00	1.00
09/01/2025 08:00	2	1.3	10.5	14.5	27.3	772,654.9	0.00	1.00
09/01/2025 09:00	2	1.2	10.4	14.5	28.8	772,227.0	0.00	1.00
09/01/2025 10:00	1	1.4	9.7	14.4	24.3	872,218.0	0.00	1.00
09/01/2025 11:00	2	1.6	11.2	13.6	31.6	972,478.9	0.00	1.00
09/01/2025 12:00	3	2.0	13.9	12.5	39.2	891,267.0	0.00	1.00
09/01/2025 13:00	4	2.0	14.0	12.3	41.9	879,138.6	0.00	1.00
09/01/2025 14:00	2	1.7	12.4	13.2	35.3	971,579.9	0.00	1.00
09/01/2025 15:00	2	1.7	11.5	13.5	33.4	967,479.8	0.00	1.00
09/01/2025 16:00	3	2.2	13.7	12.6	40.8	973,281.3	0.00	1.00
09/01/2025 17:00	4	2.2	15.3	12.0	50.9	973,060.7	0.00	1.00
09/01/2025 18:00	4	2.3	15.3	11.8	52.6	971,237.9	0.00	1.00
09/01/2025 19:00	4	2.3	15.5	11.8	53.2	974,247.6	0.00	1.00
09/01/2025 20:00	4	2.3	15.5	11.9	51.8	975,943.1	0.00	1.00
09/01/2025 21:00	4	2.2	15.2	12.1	49.7	983,184.5	0.00	1.00
09/01/2025 22:00	3	1.9	13.9	12.6	43.2	976,746.1	0.00	1.00
09/01/2025 23:00	3	2.0	13.3	12.8	39.6	978,039.5	0.00	1.00
Average/Sum#:	3	1.8	12.6	13.2	38.1	938,115.5	0.00 #	24.00 #
Minimum:	1	1.2	9.7	11.8	24.3	772,227.0	0.00	1.00
Maximum:	4	2.3	15.5	14.5	53.2	987,941.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/02/2025 00:00	2	1.6	11.1	13.7	33.7	971,150.1	0.00	1.00
09/02/2025 01:00	2	1.7	11.4	13.6	34.2	964,975.2	0.00	1.00
09/02/2025 02:00	2	1.7	11.8	13.6	32.9	960,848.2	0.00	1.00
09/02/2025 03:00	2	1.7	11.5	13.7	35.3	972,671.7	0.00	1.00
09/02/2025 04:00	3	2.0	14.0	12.8	44.4	983,956.8	0.00	1.00
09/02/2025 05:00	4	2.2	16.1	12.0	54.1	980,292.4	0.00	1.00
09/02/2025 06:00	4	2.1	15.2	12.4	48.8	981,957.8	0.00	1.00
09/02/2025 07:00	4	2.2	16.1	12.1	52.1	971,202.0	0.00	1.00
09/02/2025 08:00	4	2.2	15.2	12.1	50.4	985,363.1	0.00	1.00
09/02/2025 09:00	3	1.9	13.1	12.8	38.9	975,503.5	0.00	1.00
09/02/2025 10:00	2	1.7	11.7	13.3	33.8	945,623.6	0.00	1.00
09/02/2025 11:00	3	2.0	13.7	12.5	41.3	962,346.7	0.00	1.00
09/02/2025 12:00	4	2.2	14.9	11.9	47.5	969,704.6	0.00	1.00
09/02/2025 13:00	3	2.2	14.6	12.0	45.5	965,982.7	0.00	1.00
09/02/2025 14:00	4	2.3	15.0	11.7	50.1	965,146.5	0.00	1.00
09/02/2025 15:00	4	2.3	14.9	11.7	49.7	961,722.9	0.00	1.00
09/02/2025 16:00	4	2.3	14.9	11.7	49.5	964,402.2	0.00	1.00
09/02/2025 17:00	4	2.3	15.0	11.8	49.3	976,805.9	0.00	1.00
09/02/2025 18:00	4	2.3	15.0	11.7	50.2	969,016.6	0.00	1.00
09/02/2025 19:00	4	2.3	15.2	11.8	49.6	975,451.5	0.00	1.00
09/02/2025 20:00	4	2.3	15.3	11.9	49.1	980,507.9	0.00	1.00
09/02/2025 21:00	4	2.3	15.2	12.0	48.8	987,524.2	0.00	1.00
09/02/2025 22:00	4	2.2	15.2	12.0	49.1	984,908.5	0.00	1.00
09/02/2025 23:00	4	2.2	15.2	12.2	48.2	986,615.2	0.00	1.00
Average/Sum#:	3	2.1	14.2	12.4	45.3	972,653.3	0.00 #	24.00 #
Minimum:	2	1.6	11.1	11.7	32.9	945,623.6	0.00	1.00
Maximum:	4	2.3	16.1	13.7	54.1	987,524.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/03/2025 00:00	3	1.8	13.2	13.0	40.6	975,411.5	0.00	1.00
09/03/2025 01:00	2	1.6	11.0	13.8	34.0	973,448.6	0.00	1.00
09/03/2025 02:00	2	1.6	11.5	13.8	32.4	975,184.5	0.00	1.00
09/03/2025 03:00	2	1.5	11.1	13.9	35.3	981,681.7	0.00	1.00
09/03/2025 04:00	3	1.9	13.1	13.1	39.8	988,619.1	0.00	1.00
09/03/2025 05:00	3	2.0	14.3	12.7	43.8	993,166.7	0.00	1.00
09/03/2025 06:00	2	1.7	11.7	13.7	35.4	992,832.7	0.00	1.00
09/03/2025 07:00	2	1.6	10.9	13.9	33.0	983,442.3	0.00	1.00
09/03/2025 08:00	2	1.6	11.0	13.8	32.9	975,956.0	0.00	1.00
09/03/2025 09:00	2	1.6	11.3	13.7	34.1	972,861.9	0.00	1.00
09/03/2025 10:00	2	1.7	11.7	13.6	35.3	968,727.1	0.00	1.00
09/03/2025 11:00	2	1.6	12.2	13.3	36.6	947,966.0	0.00	1.00
09/03/2025 12:00	3	1.9	13.2	12.9	37.6	957,741.2	0.00	1.00
09/03/2025 13:00	2	1.8	11.9	13.2	34.9	978,338.1	0.00	1.00
09/03/2025 14:00	3	2.2	14.8	12.2	46.0	978,430.1	0.00	1.00
09/03/2025 15:00	4	2.2	15.2	11.9	49.5	973,204.3	0.00	1.00
09/03/2025 16:00	4	2.2	14.9	12.0	48.3	968,444.6	0.00	1.00
09/03/2025 17:00	4	2.3	15.3	11.8	52.0	977,106.9	0.00	1.00
09/03/2025 18:00	4	2.3	15.6	11.9	52.2	980,964.3	0.00	1.00
09/03/2025 19:00	3	2.0	14.1	12.7	43.7	992,331.7	0.00	1.00
09/03/2025 20:00	3	2.0	14.4	12.5	45.6	984,355.3	0.00	1.00
09/03/2025 21:00	4	2.2	15.6	12.2	49.7	979,531.9	0.00	1.00
09/03/2025 22:00	3	2.0	15.0	12.6	46.2	964,041.8	0.00	1.00
09/03/2025 23:00	2	1.6	11.7	13.6	35.5	966,475.9	0.00	1.00
Average/Sum#:	3	1.9	13.1	13.0	40.6	976,261.0	0.00 #	24.00 #
Minimum:	2	1.5	10.9	11.8	32.4	947,966.0	0.00	1.00
Maximum:	4	2.3	15.6	13.9	52.2	993,166.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/04/2025 00:00	2	1.6	11.2	13.7	33.5	966,775.6	0.00	1.00
09/04/2025 01:00	2	1.6	11.1	13.7	32.9	964,683.4	0.00	1.00
09/04/2025 02:00	2	1.7	11.4	13.8	30.7	976,920.4	0.00	1.00
09/04/2025 03:00	2	1.6	11.1	13.8	34.8	972,291.3	0.00	1.00
09/04/2025 04:00	3	1.8	13.1	13.1	41.9	992,832.7	0.00	1.00
09/04/2025 05:00	3	2.0	14.8	12.5	46.8	994,136.9	0.00	1.00
09/04/2025 06:00	2	1.6	11.4	13.7	34.9	978,567.8	0.00	1.00
09/04/2025 07:00	2	1.6	10.8	13.9	31.3	984,420.5	0.00	1.00
09/04/2025 08:00	2	1.6	10.8	13.8	33.0	975,763.1	0.00	1.00
09/04/2025 09:00	2	1.6	11.0	13.7	34.1	969,248.1	0.00	1.00
09/04/2025 10:00	2	1.7	11.5	13.6	33.4	973,792.1	0.00	1.00
09/04/2025 11:00	2	1.8	11.7	13.5	34.1	963,038.4	0.00	1.00
09/04/2025 12:00	2	1.8	12.4	13.2	35.9	942,590.8	0.00	1.00
09/04/2025 13:00	2	1.9	12.9	12.9	36.4	915,973.7	0.00	1.00
09/04/2025 14:00	3	1.8	13.5	12.9	37.8	916,144.9	0.00	1.00
09/04/2025 15:00	3	1.8	13.4	13.0	39.0	926,354.9	0.00	1.00
09/04/2025 16:00	3	2.0	14.2	12.7	42.4	958,931.1	0.00	1.00
09/04/2025 17:00	2	1.8	12.3	13.3	36.5	973,552.6	0.00	1.00
09/04/2025 18:00	3	2.0	13.9	12.8	43.0	980,406.4	0.00	1.00
09/04/2025 19:00	3	1.9	13.7	12.8	42.0	977,532.3	0.00	1.00
09/04/2025 20:00	2	1.6	11.3	13.6	34.2	974,354.8	0.00	1.00
09/04/2025 21:00	2	1.6	11.1	13.7	35.5	985,224.8	0.00	1.00
09/04/2025 22:00	2	1.6	10.9	13.7	32.8	981,611.0	0.00	1.00
09/04/2025 23:00	2	1.6	10.8	13.8	33.1	987,142.8	0.00	1.00
Average/Sum#:	2	1.7	12.1	13.4	36.3	968,012.1	0.00 #	24.00 #
Minimum:	2	1.6	10.8	12.5	30.7	915,973.7	0.00	1.00
Maximum:	3	2.0	14.8	13.9	46.8	994,136.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/05/2025 00:00	2	1.6	10.7	13.8	32.9	986,949.9	0.00	1.00
09/05/2025 01:00	2	1.6	10.7	13.7	32.7	972,291.3	0.00	1.00
09/05/2025 02:00	2	1.4	11.2	13.7	36.0	970,769.7	0.00	1.00
09/05/2025 03:00	2	1.8	10.9	13.7	32.2	970,579.5	0.00	1.00
09/05/2025 04:00	2	1.7	10.8	13.8	32.6	984,442.5	0.00	1.00
09/05/2025 05:00	2	1.7	11.8	13.4	36.7	988,359.2	0.00	1.00
09/05/2025 06:00	3	1.7	12.2	13.3	39.1	980,940.3	0.00	1.00
09/05/2025 07:00	2	1.5	10.8	13.8	34.9	984,249.7	0.00	1.00
09/05/2025 08:00	2	1.6	10.8	13.8	33.4	984,828.3	0.00	1.00
09/05/2025 09:00	2	1.6	11.0	13.7	33.4	977,426.7	0.00	1.00
09/05/2025 10:00	2	1.7	11.0	13.7	33.3	972,481.5	0.00	1.00
09/05/2025 11:00	2	1.6	11.1	13.7	34.4	972,671.7	0.00	1.00
09/05/2025 12:00	2	1.6	11.3	13.6	34.0	963,849.7	0.00	1.00
09/05/2025 13:00	2	1.7	11.5	13.5	34.0	958,412.0	0.00	1.00
09/05/2025 14:00	2	1.7	11.8	13.4	34.9	950,563.1	0.00	1.00
09/05/2025 15:00	2	1.9	12.3	13.2	34.2	934,943.4	0.00	1.00
09/05/2025 16:00	3	1.9	12.8	13.0	37.2	933,982.1	0.00	1.00
09/05/2025 17:00	2	1.7	11.9	13.3	34.7	941,479.3	0.00	1.00
09/05/2025 18:00	2	1.6	11.2	13.5	33.3	953,045.3	0.00	1.00
09/05/2025 19:00	2	1.7	10.9	13.6	32.7	957,283.9	0.00	1.00
09/05/2025 20:00	2	1.6	10.8	13.7	33.0	962,781.4	0.00	1.00
09/05/2025 21:00	2	1.7	10.7	13.8	31.5	969,205.3	0.00	1.00
09/05/2025 22:00	2	1.7	10.6	13.8	31.0	966,119.3	0.00	1.00
09/05/2025 23:00	2	1.6	10.5	13.8	32.0	963,611.9	0.00	1.00
Average/Sum#:	2	1.7	11.2	13.6	33.9	966,719.5	0.00 #	24.00 #
Minimum:	2	1.4	10.5	13.0	31.0	933,982.1	0.00	1.00
Maximum:	3	1.9	12.8	13.8	39.1	988,359.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/06/2025 00:00	2	1.6	10.4	13.9	32.5	975,812.7	0.00	1.00
09/06/2025 01:00	2	1.6	10.4	13.9	30.9	974,443.3	0.00	1.00
09/06/2025 02:00	2	1.5	10.8	13.9	33.0	972,878.2	0.00	1.00
09/06/2025 03:00	2	1.4	10.5	13.9	33.4	971,900.0	0.00	1.00
09/06/2025 04:00	2	1.6	10.3	14.0	31.3	985,588.6	0.00	1.00
09/06/2025 05:00	2	1.6	10.3	14.0	31.5	986,779.4	0.00	1.00
09/06/2025 06:00	2	1.5	9.9	14.2	31.2	904,024.5	0.00	1.00
09/06/2025 07:00	2	1.3	10.2	14.3	25.6	749,448.6	0.00	1.00
09/06/2025 08:00	2	1.3	10.2	14.3	27.8	749,033.6	0.00	1.00
09/06/2025 09:00	2	1.3	10.2	14.4	26.9	760,135.9	0.00	1.00
09/06/2025 10:00	2	1.3	9.7	14.5	24.5	828,287.8	0.00	1.00
09/06/2025 11:00	2	1.6	10.8	13.7	31.6	974,193.3	0.00	1.00
09/06/2025 12:00	2	1.6	11.2	13.5	35.8	960,632.7	0.00	1.00
09/06/2025 13:00	2	1.4	9.5	14.5	27.6	929,496.8	0.00	1.00
09/06/2025 14:00	2	1.7	11.7	13.5	34.8	956,561.4	0.00	1.00
09/06/2025 15:00	2	1.7	12.2	13.5	36.5	958,782.1	0.00	1.00
09/06/2025 16:00	2	1.7	12.0	13.5	36.3	956,006.3	0.00	1.00
09/06/2025 17:00	2	1.7	11.5	13.6	35.4	961,223.4	0.00	1.00
09/06/2025 18:00	2	1.6	11.2	13.7	35.1	966,775.6	0.00	1.00
09/06/2025 19:00	2	1.6	11.0	13.8	33.5	970,941.2	0.00	1.00
09/06/2025 20:00	2	1.5	10.8	13.9	34.4	979,529.7	0.00	1.00
09/06/2025 21:00	2	1.6	10.6	13.9	32.1	977,377.7	0.00	1.00
09/06/2025 22:00	2	1.5	10.6	14.0	32.9	988,367.2	0.00	1.00
09/06/2025 23:00	2	1.5	10.5	14.0	34.7	987,771.8	0.00	1.00
Average/Sum#:	2	1.5	10.7	13.9	32.1	934,416.3	0.00 #	24.00 #
Minimum:	2	1.3	9.5	13.5	24.5	749,033.6	0.00	1.00
Maximum:	2	1.7	12.2	14.5	36.5	988,367.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/07/2025 00:00	2	1.5	10.4	14.0	32.8	987,573.3	0.00	1.00
09/07/2025 01:00	2	1.5	10.3	14.0	31.8	985,985.6	0.00	1.00
09/07/2025 02:00	2	1.6	10.9	14.0	32.2	982,611.6	0.00	1.00
09/07/2025 03:00	2	1.5	10.6	14.0	34.1	980,825.4	0.00	1.00
09/07/2025 04:00	2	1.5	10.4	14.1	33.4	995,047.9	0.00	1.00
09/07/2025 05:00	2	1.5	10.4	14.1	33.6	995,047.9	0.00	1.00
09/07/2025 06:00	2	1.5	10.0	14.2	31.6	903,615.7	0.00	1.00
09/07/2025 07:00	2	1.3	10.5	14.4	28.2	762,032.0	0.00	1.00
09/07/2025 08:00	2	1.3	10.5	14.4	26.8	761,189.3	0.00	1.00
09/07/2025 09:00	3	1.3	10.5	14.4	30.5	760,767.9	0.00	1.00
09/07/2025 10:00	2	1.3	10.6	14.4	27.7	759,925.2	0.00	1.00
09/07/2025 11:00	2	1.3	10.5	14.5	29.1	772,013.0	0.00	1.00
09/07/2025 12:00	1	1.4	10.1	14.4	25.4	859,577.2	0.00	1.00
09/07/2025 13:00	2	1.6	11.5	13.6	34.0	968,164.3	0.00	1.00
09/07/2025 14:00	2	1.7	11.7	13.5	34.6	958,967.2	0.00	1.00
09/07/2025 15:00	2	1.7	11.9	13.5	36.4	963,038.4	0.00	1.00
09/07/2025 16:00	3	1.9	12.9	13.1	38.4	964,917.5	0.00	1.00
09/07/2025 17:00	3	1.9	13.3	12.7	41.9	976,800.4	0.00	1.00
09/07/2025 18:00	2	1.7	11.6	13.5	35.2	961,002.8	0.00	1.00
09/07/2025 19:00	2	1.6	11.2	13.7	34.3	970,008.9	0.00	1.00
09/07/2025 20:00	2	1.7	11.0	13.7	32.4	965,254.0	0.00	1.00
09/07/2025 21:00	2	1.5	10.8	13.8	35.1	974,798.7	0.00	1.00
09/07/2025 22:00	2	1.5	10.6	13.8	32.4	966,119.3	0.00	1.00
09/07/2025 23:00	2	1.7	10.6	13.9	31.5	978,942.8	0.00	1.00
Average/Sum#:	2	1.5	11.0	13.9	32.6	923,092.8	0.00 #	24.00 #
Minimum:	1	1.3	10.0	12.7	25.4	759,925.2	0.00	1.00
Maximum:	3	1.9	13.3	14.5	41.9	995,047.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/08/2025 00:00	2	1.6	10.7	13.9	33.8	973,660.7	0.00	1.00
09/08/2025 01:00	2	1.6	10.6	13.9	32.0	971,704.4	0.00	1.00
09/08/2025 02:00	2	1.5	11.0	13.9	32.9	971,900.0	0.00	1.00
09/08/2025 03:00	2	1.6	10.7	13.9	31.8	972,095.7	0.00	1.00
09/08/2025 04:00	2	1.6	10.6	14.0	32.6	984,794.8	0.00	1.00
09/08/2025 05:00	2	1.6	11.5	13.6	36.2	986,923.5	0.00	1.00
09/08/2025 06:00	2	1.6	10.4	14.0	32.8	983,405.5	0.00	1.00
09/08/2025 07:00	2	1.5	10.5	13.9	32.1	975,421.4	0.00	1.00
09/08/2025 08:00	2	1.5	10.1	14.0	31.4	945,895.2	0.00	1.00
09/08/2025 09:00	2	1.4	10.1	14.4	28.0	764,770.8	0.00	1.00
09/08/2025 10:00	2	1.2	10.0	14.4	26.7	759,714.5	0.00	1.00
09/08/2025 11:00	2	1.4	10.1	14.4	25.6	761,189.3	0.00	1.00
09/08/2025 12:00	2	1.3	10.2	14.4	27.0	761,189.3	0.00	1.00
09/08/2025 13:00	2	1.3	9.6	14.5	25.2	821,654.6	0.00	1.00
09/08/2025 14:00	2	1.7	11.1	13.6	31.7	952,218.9	0.00	1.00
09/08/2025 15:00	2	1.7	11.4	13.5	34.0	952,490.2	0.00	1.00
09/08/2025 16:00	2	1.8	12.0	13.2	35.4	959,130.6	0.00	1.00
09/08/2025 17:00	3	2.0	13.8	12.5	43.6	962,835.8	0.00	1.00
09/08/2025 18:00	2	1.7	11.2	13.4	33.3	959,327.4	0.00	1.00
09/08/2025 19:00	2	1.6	10.8	13.6	32.7	959,535.0	0.00	1.00
09/08/2025 20:00	2	1.6	10.5	13.7	31.6	963,161.8	0.00	1.00
09/08/2025 21:00	2	1.6	10.9	13.6	34.5	966,475.9	0.00	1.00
09/08/2025 22:00	2	1.8	11.5	13.4	33.9	973,386.9	0.00	1.00
09/08/2025 23:00	2	1.7	10.3	13.8	30.7	968,048.0	0.00	1.00
Average/Sum#:	2	1.6	10.8	13.8	32.1	927,122.1	0.00 #	24.00 #
Minimum:	2	1.2	9.6	12.5	25.2	759,714.5	0.00	1.00
Maximum:	3	2.0	13.8	14.5	43.6	986,923.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/09/2025 00:00	2	1.6	10.2	13.8	30.2	968,240.9	0.00	1.00
09/09/2025 01:00	2	1.5	10.1	13.8	31.4	969,205.3	0.00	1.00
09/09/2025 02:00	2	1.6	10.6	13.8	30.5	968,819.5	0.00	1.00
09/09/2025 03:00	2	1.7	10.3	13.8	28.7	969,205.3	0.00	1.00
09/09/2025 04:00	2	1.6	10.2	13.9	31.1	980,507.9	0.00	1.00
09/09/2025 05:00	3	1.8	12.5	13.1	38.4	984,756.6	0.00	1.00
09/09/2025 06:00	2	1.5	10.0	14.0	29.8	948,475.2	0.00	1.00
09/09/2025 07:00	2	1.6	9.4	14.2	26.5	924,668.0	0.00	1.00
09/09/2025 08:00	2	1.6	10.5	13.9	32.0	980,703.5	0.00	1.00
09/09/2025 09:00	2	1.6	10.6	13.8	33.8	971,519.8	0.00	1.00
09/09/2025 10:00	2	1.6	10.6	13.8	31.7	972,291.3	0.00	1.00
09/09/2025 11:00	2	1.7	10.7	13.7	33.2	961,830.4	0.00	1.00
09/09/2025 12:00	2	1.4	9.4	14.4	27.4	923,624.1	0.00	1.00
09/09/2025 13:00	2	1.7	11.0	13.7	33.3	966,014.8	0.00	1.00
09/09/2025 14:00	2	1.6	11.1	13.6	35.0	953,907.3	0.00	1.00
09/09/2025 15:00	2	1.7	11.1	13.6	33.4	952,781.7	0.00	1.00
09/09/2025 16:00	2	1.6	11.0	13.6	33.2	951,656.2	0.00	1.00
09/09/2025 17:00	2	1.6	10.8	13.7	33.8	961,450.0	0.00	1.00
09/09/2025 18:00	2	1.6	10.5	13.7	31.9	957,836.3	0.00	1.00
09/09/2025 19:00	2	1.7	10.4	13.8	30.2	969,205.3	0.00	1.00
09/09/2025 20:00	2	1.5	10.4	13.8	33.6	966,890.8	0.00	1.00
09/09/2025 21:00	2	1.6	10.4	13.8	30.7	966,312.1	0.00	1.00
09/09/2025 22:00	2	1.6	10.3	13.8	32.7	964,576.2	0.00	1.00
09/09/2025 23:00	2	1.6	10.3	13.8	31.2	963,033.2	0.00	1.00
Average/Sum#:	2	1.6	10.5	13.8	31.8	962,396.3	0.00 #	24.00 #
Minimum:	2	1.4	9.4	13.1	26.5	923,624.1	0.00	1.00
Maximum:	3	1.8	12.5	14.4	38.4	984,756.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/10/2025 00:00	2	1.6	10.2	13.9	31.6	974,638.9	0.00	1.00
09/10/2025 01:00	2	1.6	10.2	13.9	31.6	973,269.5	0.00	1.00
09/10/2025 02:00	2	1.6	10.7	13.9	31.2	972,682.6	0.00	1.00
09/10/2025 03:00	2	1.6	10.5	13.9	32.9	972,486.9	0.00	1.00
09/10/2025 04:00	2	1.6	10.3	13.9	32.5	972,878.2	0.00	1.00
09/10/2025 05:00	2	1.6	10.3	13.9	31.9	976,204.0	0.00	1.00
09/10/2025 06:00	2	1.5	10.4	13.8	32.3	970,362.5	0.00	1.00
09/10/2025 07:00	2	1.5	9.8	14.1	30.1	886,702.3	0.00	1.00
09/10/2025 08:00	2	1.4	9.4	14.3	24.0	852,777.9	0.00	1.00
09/10/2025 09:00	2	1.6	10.6	13.8	31.9	963,804.7	0.00	1.00
09/10/2025 10:00	2	1.4	9.7	14.4	25.6	800,586.6	0.00	1.00
09/10/2025 11:00	2	1.3	10.0	14.4	27.7	757,607.7	0.00	1.00
09/10/2025 12:00	2	1.3	10.0	14.4	24.7	756,765.0	0.00	1.00
09/10/2025 13:00	2	1.3	10.1	14.4	27.0	755,500.9	0.00	1.00
09/10/2025 14:00	2	1.3	9.7	14.5	25.2	820,156.8	0.00	1.00
09/10/2025 15:00	2	1.5	11.0	13.8	33.4	968,048.0	0.00	1.00
09/10/2025 16:00	2	1.6	11.1	13.7	34.5	967,726.6	0.00	1.00
09/10/2025 17:00	2	1.5	10.9	13.7	33.3	958,787.3	0.00	1.00
09/10/2025 18:00	2	1.5	10.8	13.8	33.2	968,819.5	0.00	1.00
09/10/2025 19:00	2	1.6	10.5	13.8	32.1	964,769.1	0.00	1.00
09/10/2025 20:00	2	1.5	10.3	13.9	31.6	972,095.7	0.00	1.00
09/10/2025 21:00	2	1.6	10.3	13.9	31.9	968,769.9	0.00	1.00
09/10/2025 22:00	2	1.5	10.3	13.9	32.7	967,204.9	0.00	1.00
09/10/2025 23:00	2	1.6	10.3	14.0	32.0	979,237.7	0.00	1.00
Average/Sum#:	2	1.5	10.3	14.0	30.6	921,745.1	0.00 #	24.00 #
Minimum:	2	1.3	9.4	13.7	24.0	755,500.9	0.00	1.00
Maximum:	2	1.6	11.1	14.5	34.5	979,237.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/11/2025 00:00	2	1.5	10.3	14.0	33.2	977,649.9	0.00	1.00
09/11/2025 01:00	2	1.5	10.3	14.0	32.4	977,253.0	0.00	1.00
09/11/2025 02:00	2	1.5	10.7	14.0	33.6	976,260.7	0.00	1.00
09/11/2025 03:00	2	1.5	10.5	14.0	33.3	977,054.5	0.00	1.00
09/11/2025 04:00	2	1.6	10.3	14.0	32.4	976,260.7	0.00	1.00
09/11/2025 05:00	2	1.5	10.3	14.0	33.6	974,276.0	0.00	1.00
09/11/2025 06:00	2	1.6	10.3	14.1	31.6	988,200.8	0.00	1.00
09/11/2025 07:00	2	1.5	10.3	14.0	32.6	977,649.9	0.00	1.00
09/11/2025 08:00	2	1.6	10.3	14.0	31.8	980,230.0	0.00	1.00
09/11/2025 09:00	2	1.6	10.5	13.9	32.2	973,269.5	0.00	1.00
09/11/2025 10:00	2	1.6	10.7	13.8	32.9	976,341.7	0.00	1.00
09/11/2025 11:00	2	1.6	10.2	14.0	30.6	945,498.2	0.00	1.00
09/11/2025 12:00	2	1.4	9.7	14.4	28.2	863,790.8	0.00	1.00
09/11/2025 13:00	2	1.6	11.0	13.6	32.8	958,034.3	0.00	1.00
09/11/2025 14:00	2	1.7	11.2	13.5	33.7	952,120.1	0.00	1.00
09/11/2025 15:00	2	1.7	11.4	13.5	35.2	955,821.2	0.00	1.00
09/11/2025 16:00	2	1.7	11.5	13.6	34.5	963,099.3	0.00	1.00
09/11/2025 17:00	2	1.7	11.4	13.6	34.7	956,908.7	0.00	1.00
09/11/2025 18:00	2	1.6	11.3	13.7	34.5	964,683.4	0.00	1.00
09/11/2025 19:00	2	1.6	11.1	13.7	34.8	960,118.7	0.00	1.00
09/11/2025 20:00	2	1.6	10.4	13.9	31.1	965,639.8	0.00	1.00
09/11/2025 21:00	2	1.5	10.1	14.0	30.4	966,734.2	0.00	1.00
09/11/2025 22:00	2	1.6	10.4	13.8	32.1	962,068.8	0.00	1.00
09/11/2025 23:00	2	1.6	10.4	13.9	30.8	975,617.1	0.00	1.00
Average/Sum#:	2	1.6	10.6	13.9	32.6	964,357.6	0.00 #	24.00 #
Minimum:	2	1.4	9.7	13.5	28.2	863,790.8	0.00	1.00
Maximum:	2	1.7	11.5	14.4	35.2	988,200.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/12/2025 00:00	2	1.6	10.4	13.9	32.5	973,660.7	0.00	1.00
09/12/2025 01:00	2	1.6	10.3	13.9	31.9	971,313.2	0.00	1.00
09/12/2025 02:00	2	1.6	10.8	13.9	31.9	969,748.1	0.00	1.00
09/12/2025 03:00	2	1.4	10.5	14.0	34.9	980,626.9	0.00	1.00
09/12/2025 04:00	2	1.6	10.4	14.0	30.9	980,825.4	0.00	1.00
09/12/2025 05:00	2	1.6	10.3	14.0	32.3	979,436.1	0.00	1.00
09/12/2025 06:00	2	1.6	10.3	14.0	30.7	978,840.7	0.00	1.00
09/12/2025 07:00	2	1.4	9.9	14.2	31.2	897,688.3	0.00	1.00
09/12/2025 08:00	2	1.4	9.5	14.4	24.6	863,790.8	0.00	1.00
09/12/2025 09:00	2	1.5	10.6	13.8	32.0	967,662.3	0.00	1.00
09/12/2025 10:00	2	1.4	9.8	14.3	27.5	840,743.6	0.00	1.00
09/12/2025 11:00	2	1.3	9.9	14.4	24.7	756,975.7	0.00	1.00
09/12/2025 12:00	2	1.3	10.1	14.5	27.1	768,375.5	0.00	1.00
09/12/2025 13:00	2	1.3	9.9	14.5	25.7	778,860.1	0.00	1.00
09/12/2025 14:00	2	1.6	10.9	13.7	30.0	918,084.9	0.00	1.00
09/12/2025 15:00	2	1.6	11.7	13.4	35.3	947,824.3	0.00	1.00
09/12/2025 16:00	2	1.7	11.8	13.3	33.6	939,317.0	0.00	1.00
09/12/2025 17:00	2	1.8	11.7	13.3	33.5	937,335.0	0.00	1.00
09/12/2025 18:00	2	1.6	11.2	13.5	33.8	946,568.3	0.00	1.00
09/12/2025 19:00	2	1.7	11.0	13.6	32.3	952,218.9	0.00	1.00
09/12/2025 20:00	2	1.6	10.7	13.7	31.5	960,499.0	0.00	1.00
09/12/2025 21:00	2	1.6	10.6	13.8	31.8	970,362.5	0.00	1.00
09/12/2025 22:00	2	1.5	10.4	13.8	32.4	966,119.3	0.00	1.00
09/12/2025 23:00	2	1.6	10.4	13.9	30.8	976,008.3	0.00	1.00
Average/Sum#:	2	1.5	10.5	13.9	31.0	925,953.5	0.00 #	24.00 #
Minimum:	2	1.3	9.5	13.3	24.6	756,975.7	0.00	1.00
Maximum:	2	1.8	11.8	14.5	35.3	980,825.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/13/2025 00:00	2	1.6	10.3	13.9	32.3	973,269.5	0.00	1.00
09/13/2025 01:00	2	1.6	10.2	13.9	29.7	970,921.9	0.00	1.00
09/13/2025 02:00	2	1.6	10.7	14.0	31.3	982,413.1	0.00	1.00
09/13/2025 03:00	2	1.5	10.4	14.0	34.3	979,833.1	0.00	1.00
09/13/2025 04:00	2	1.6	10.3	14.0	31.7	979,039.2	0.00	1.00
09/13/2025 05:00	2	1.6	10.3	14.0	31.7	980,031.5	0.00	1.00
09/13/2025 06:00	2	1.4	9.9	14.1	32.5	950,743.0	0.00	1.00
09/13/2025 07:00	2	1.3	10.1	14.3	27.1	751,523.5	0.00	1.00
09/13/2025 08:00	2	1.3	10.1	14.4	24.9	762,453.4	0.00	1.00
09/13/2025 09:00	2	1.4	10.2	14.4	26.5	760,978.6	0.00	1.00
09/13/2025 10:00	2	1.3	10.2	14.4	26.7	760,346.6	0.00	1.00
09/13/2025 11:00	2	1.3	10.2	14.4	26.3	760,767.9	0.00	1.00
09/13/2025 12:00	2	1.4	10.2	14.5	26.2	771,371.1	0.00	1.00
09/13/2025 13:00	2	1.3	10.1	14.5	26.2	769,873.3	0.00	1.00
09/13/2025 14:00	2	1.2	10.2	14.5	25.4	769,445.3	0.00	1.00
09/13/2025 15:00	2	1.3	10.2	14.5	26.5	769,231.4	0.00	1.00
09/13/2025 16:00	2	1.3	10.1	14.3	26.0	848,420.7	0.00	1.00
09/13/2025 17:00	2	1.7	11.4	13.4	32.9	947,824.3	0.00	1.00
09/13/2025 18:00	2	1.6	11.0	13.6	33.3	961,973.7	0.00	1.00
09/13/2025 19:00	2	1.6	10.8	13.7	32.5	964,683.4	0.00	1.00
09/13/2025 20:00	2	1.6	10.6	13.8	32.6	971,326.9	0.00	1.00
09/13/2025 21:00	2	1.6	10.5	13.8	31.3	966,119.3	0.00	1.00
09/13/2025 22:00	2	1.6	10.4	13.9	32.2	975,812.7	0.00	1.00
09/13/2025 23:00	2	1.5	10.4	13.9	32.3	974,443.3	0.00	1.00
Average/Sum#:	2	1.5	10.4	14.1	29.7	887,618.6	0.00 #	24.00 #
Minimum:	2	1.2	9.9	13.4	24.9	751,523.5	0.00	1.00
Maximum:	2	1.7	11.4	14.5	34.3	982,413.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/14/2025 00:00	2	1.6	10.4	13.9	32.5	972,878.2	0.00	1.00
09/14/2025 01:00	2	1.6	10.3	14.0	32.7	987,970.2	0.00	1.00
09/14/2025 02:00	2	1.6	10.8	14.0	32.2	986,779.4	0.00	1.00
09/14/2025 03:00	2	1.5	10.4	14.0	33.2	986,184.0	0.00	1.00
09/14/2025 04:00	2	1.6	10.3	14.0	32.0	984,794.8	0.00	1.00
09/14/2025 05:00	2	1.6	10.2	14.0	32.5	983,603.9	0.00	1.00
09/14/2025 06:00	2	1.4	9.9	14.2	31.2	893,804.9	0.00	1.00
09/14/2025 07:00	2	1.3	10.1	14.4	26.1	762,242.7	0.00	1.00
09/14/2025 08:00	2	1.3	10.0	14.4	25.0	760,767.9	0.00	1.00
09/14/2025 09:00	2	1.4	10.1	14.4	26.3	760,135.9	0.00	1.00
09/14/2025 10:00	2	1.3	10.1	14.4	26.7	760,346.6	0.00	1.00
09/14/2025 11:00	2	1.4	10.2	14.4	26.3	763,928.1	0.00	1.00
09/14/2025 12:00	2	1.2	10.3	14.5	27.7	772,440.9	0.00	1.00
09/14/2025 13:00	2	1.3	10.3	14.5	25.7	769,659.3	0.00	1.00
09/14/2025 14:00	2	1.4	10.4	14.5	27.9	769,231.4	0.00	1.00
09/14/2025 15:00	2	1.3	10.6	14.5	26.9	768,161.5	0.00	1.00
09/14/2025 16:00	2	1.4	10.5	14.3	28.2	846,345.8	0.00	1.00
09/14/2025 17:00	2	1.8	12.2	13.4	35.5	950,380.5	0.00	1.00
09/14/2025 18:00	2	1.7	11.9	13.5	35.5	949,714.3	0.00	1.00
09/14/2025 19:00	2	1.6	11.4	13.6	34.9	955,032.8	0.00	1.00
09/14/2025 20:00	2	1.7	10.6	13.7	31.7	963,352.0	0.00	1.00
09/14/2025 21:00	2	1.5	10.5	13.7	32.6	962,971.6	0.00	1.00
09/14/2025 22:00	2	1.5	10.3	13.7	30.9	958,216.7	0.00	1.00
09/14/2025 23:00	2	1.6	10.3	13.8	30.8	969,976.8	0.00	1.00
Average/Sum#:	2	1.5	10.5	14.1	30.2	884,955.0	0.00 #	24.00 #
Minimum:	2	1.2	9.9	13.4	25.0	760,135.9	0.00	1.00
Maximum:	2	1.8	12.2	14.5	35.5	987,970.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/15/2025 00:00	2	1.7	10.3	13.8	30.8	966,312.1	0.00	1.00
09/15/2025 01:00	2	1.6	10.2	13.9	30.5	978,355.9	0.00	1.00
09/15/2025 02:00	2	1.4	10.8	13.9	33.2	974,834.5	0.00	1.00
09/15/2025 03:00	2	1.5	10.5	13.9	35.0	973,269.5	0.00	1.00
09/15/2025 04:00	2	1.6	10.3	14.0	32.3	985,985.6	0.00	1.00
09/15/2025 05:00	2	1.6	10.3	14.1	33.0	997,263.2	0.00	1.00
09/15/2025 06:00	2	1.5	10.3	14.1	33.1	995,249.3	0.00	1.00
09/15/2025 07:00	2	1.5	10.4	14.0	34.0	986,581.0	0.00	1.00
09/15/2025 08:00	2	1.6	10.6	13.9	32.6	981,486.0	0.00	1.00
09/15/2025 09:00	2	1.6	10.8	13.7	34.8	959,928.5	0.00	1.00
09/15/2025 10:00	2	1.3	9.3	14.4	28.1	918,146.4	0.00	1.00
09/15/2025 11:00	2	1.7	11.1	13.5	33.7	955,636.2	0.00	1.00
09/15/2025 12:00	2	1.7	11.7	13.3	33.6	941,118.9	0.00	1.00
09/15/2025 13:00	2	1.9	12.4	13.1	34.9	928,048.4	0.00	1.00
09/15/2025 14:00	3	2.1	14.1	12.4	42.8	952,797.2	0.00	1.00
09/15/2025 15:00	3	1.9	13.3	12.9	40.7	943,362.2	0.00	1.00
09/15/2025 16:00	3	1.9	13.7	12.7	40.4	940,560.7	0.00	1.00
09/15/2025 17:00	2	1.6	10.9	13.6	32.6	969,665.0	0.00	1.00
09/15/2025 18:00	2	1.7	10.9	13.6	32.0	972,666.5	0.00	1.00
09/15/2025 19:00	2	1.6	10.2	13.9	30.7	979,138.4	0.00	1.00
09/15/2025 20:00	2	1.6	10.1	13.9	32.0	976,595.2	0.00	1.00
09/15/2025 21:00	2	1.6	10.0	13.9	30.5	974,834.5	0.00	1.00
09/15/2025 22:00	2	1.5	10.0	13.9	31.1	972,486.9	0.00	1.00
09/15/2025 23:00	2	1.5	10.0	13.9	31.0	972,486.9	0.00	1.00
Average/Sum#:	2	1.6	10.9	13.7	33.5	966,533.7	0.00 #	24.00 #
Minimum:	2	1.3	9.3	12.4	28.1	918,146.4	0.00	1.00
Maximum:	3	2.1	14.1	14.4	42.8	997,263.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/16/2025 00:00	2	1.6	10.0	14.0	30.6	986,581.0	0.00	1.00
09/16/2025 01:00	2	1.6	10.1	14.0	32.1	988,962.6	0.00	1.00
09/16/2025 02:00	2	1.6	10.7	14.0	30.9	988,168.7	0.00	1.00
09/16/2025 03:00	2	1.5	10.3	14.0	35.6	984,397.8	0.00	1.00
09/16/2025 04:00	2	1.5	10.2	14.1	33.5	996,054.9	0.00	1.00
09/16/2025 05:00	2	1.6	10.5	14.0	33.0	986,779.4	0.00	1.00
09/16/2025 06:00	2	1.6	10.5	14.0	32.5	988,565.6	0.00	1.00
09/16/2025 07:00	2	1.6	10.7	13.9	34.6	981,290.4	0.00	1.00
09/16/2025 08:00	2	1.6	11.0	13.8	34.8	974,798.7	0.00	1.00
09/16/2025 09:00	2	1.7	11.5	13.6	35.0	960,660.6	0.00	1.00
09/16/2025 10:00	2	1.7	11.9	13.4	35.5	947,641.7	0.00	1.00
09/16/2025 11:00	3	1.8	12.5	13.2	37.0	935,654.8	0.00	1.00
09/16/2025 12:00	3	1.9	13.2	12.9	37.9	911,009.6	0.00	1.00
09/16/2025 13:00	3	1.9	13.7	12.7	38.5	896,973.0	0.00	1.00
09/16/2025 14:00	3	2.0	14.0	12.5	38.8	879,855.2	0.00	1.00
09/16/2025 15:00	2	1.7	11.1	13.4	31.9	938,694.8	0.00	1.00
09/16/2025 16:00	2	1.6	10.8	13.5	31.6	958,597.1	0.00	1.00
09/16/2025 17:00	2	1.6	10.3	13.6	30.3	953,344.5	0.00	1.00
09/16/2025 18:00	2	1.6	10.2	13.6	31.5	953,532.1	0.00	1.00
09/16/2025 19:00	2	1.6	10.9	13.5	33.1	951,194.8	0.00	1.00
09/16/2025 20:00	2	1.8	11.8	13.3	35.1	938,416.1	0.00	1.00
09/16/2025 21:00	2	1.6	11.2	13.5	34.0	951,009.7	0.00	1.00
09/16/2025 22:00	2	1.6	11.0	13.7	34.3	965,824.6	0.00	1.00
09/16/2025 23:00	2	1.6	11.0	13.7	34.5	967,916.8	0.00	1.00
Average/Sum#:	2	1.7	11.2	13.6	34.0	957,746.9	0.00 #	24.00 #
Minimum:	2	1.5	10.0	12.5	30.3	879,855.2	0.00	1.00
Maximum:	3	2.0	14.0	14.1	38.8	996,054.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/17/2025 00:00	2	1.6	11.0	13.7	33.7	965,254.0	0.00	1.00
09/17/2025 01:00	2	1.6	11.0	13.7	34.3	963,922.6	0.00	1.00
09/17/2025 02:00	2	1.6	11.4	13.8	34.0	973,255.7	0.00	1.00
09/17/2025 03:00	2	1.5	11.0	13.8	34.6	972,098.4	0.00	1.00
09/17/2025 04:00	2	1.6	10.7	13.9	32.0	980,899.1	0.00	1.00
09/17/2025 05:00	2	1.6	10.5	14.0	34.8	990,550.3	0.00	1.00
09/17/2025 06:00	2	1.6	10.5	14.0	33.4	986,581.0	0.00	1.00
09/17/2025 07:00	2	1.6	10.8	13.9	33.8	980,312.2	0.00	1.00
09/17/2025 08:00	2	1.6	11.1	13.7	34.8	966,965.8	0.00	1.00
09/17/2025 09:00	2	1.6	11.6	13.5	36.3	951,009.7	0.00	1.00
09/17/2025 10:00	3	1.8	12.4	13.2	38.2	930,141.5	0.00	1.00
09/17/2025 11:00	3	1.8	13.0	12.9	37.2	907,586.0	0.00	1.00
09/17/2025 12:00	3	2.0	13.6	12.6	37.9	887,981.0	0.00	1.00
09/17/2025 13:00	3	2.1	14.0	12.4	39.9	877,881.6	0.00	1.00
09/17/2025 14:00	2	1.6	11.2	13.4	32.5	958,049.3	0.00	1.00
09/17/2025 15:00	2	1.7	11.1	13.4	33.8	949,467.6	0.00	1.00
09/17/2025 16:00	2	1.6	10.6	13.6	32.5	950,343.0	0.00	1.00
09/17/2025 17:00	3	2.0	14.0	12.5	41.5	876,105.6	0.00	1.00
09/17/2025 18:00	3	2.0	14.2	12.5	41.2	871,377.8	0.00	1.00
09/17/2025 19:00	3	1.9	13.5	12.9	38.6	900,567.7	0.00	1.00
09/17/2025 20:00	3	1.8	12.7	13.2	36.8	924,806.1	0.00	1.00
09/17/2025 21:00	3	1.7	12.2	13.4	36.4	945,633.2	0.00	1.00
09/17/2025 22:00	2	1.7	11.9	13.5	35.4	948,789.0	0.00	1.00
09/17/2025 23:00	3	1.7	11.8	13.5	36.9	943,052.3	0.00	1.00
Average/Sum#:	2	1.7	11.9	13.4	35.9	941,776.3	0.00 #	24.00 #
Minimum:	2	1.5	10.5	12.4	32.0	871,377.8	0.00	1.00
Maximum:	3	2.1	14.2	14.0	41.5	990,550.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/18/2025 00:00	2	1.7	11.7	13.6	35.7	949,780.2	0.00	1.00
09/18/2025 01:00	2	1.6	11.4	13.7	34.7	959,357.9	0.00	1.00
09/18/2025 02:00	2	1.7	11.7	13.7	33.3	958,977.5	0.00	1.00
09/18/2025 03:00	2	1.7	11.4	13.7	33.9	956,124.5	0.00	1.00
09/18/2025 04:00	2	1.6	11.2	13.8	34.8	968,048.0	0.00	1.00
09/18/2025 05:00	2	1.6	11.0	13.8	34.9	966,890.8	0.00	1.00
09/18/2025 06:00	2	1.6	11.0	13.8	35.5	977,306.1	0.00	1.00
09/18/2025 07:00	3	1.8	13.1	13.2	40.7	973,002.7	0.00	1.00
09/18/2025 08:00	2	1.6	11.4	13.7	35.9	965,634.4	0.00	1.00
09/18/2025 09:00	3	1.6	12.3	13.4	38.6	951,476.1	0.00	1.00
09/18/2025 10:00	3	1.7	12.3	13.4	36.9	947,276.5	0.00	1.00
09/18/2025 11:00	3	1.8	12.4	13.2	36.1	929,252.3	0.00	1.00
09/18/2025 12:00	3	1.8	12.7	13.0	36.0	909,367.1	0.00	1.00
09/18/2025 13:00	3	2.0	13.7	12.7	38.8	899,311.0	0.00	1.00
09/18/2025 14:00	3	1.9	13.0	13.0	36.5	912,140.6	0.00	1.00
09/18/2025 15:00	3	2.0	13.5	12.8	39.9	928,334.5	0.00	1.00
09/18/2025 16:00	3	1.7	12.4	13.3	37.5	933,010.5	0.00	1.00
09/18/2025 17:00	2	1.8	12.4	13.3	35.4	931,028.4	0.00	1.00
09/18/2025 18:00	2	1.7	11.8	13.5	35.5	944,532.7	0.00	1.00
09/18/2025 19:00	2	1.7	11.6	13.5	35.6	942,312.0	0.00	1.00
09/18/2025 20:00	2	1.7	11.5	13.6	34.1	953,532.1	0.00	1.00
09/18/2025 21:00	2	1.7	11.3	13.6	34.3	951,093.4	0.00	1.00
09/18/2025 22:00	2	1.7	11.2	13.6	34.9	949,405.0	0.00	1.00
09/18/2025 23:00	2	1.6	11.2	13.7	33.4	961,830.4	0.00	1.00
Average/Sum#:	2	1.7	12.0	13.4	36.0	946,626.0	0.00 #	24.00 #
Minimum:	2	1.6	11.0	12.7	33.3	899,311.0	0.00	1.00
Maximum:	3	2.0	13.7	13.8	40.7	977,306.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/19/2025 00:00	2	1.6	10.9	13.7	34.2	960,689.2	0.00	1.00
09/19/2025 01:00	2	1.5	10.4	13.7	31.9	962,020.6	0.00	1.00
09/19/2025 02:00	2	1.6	10.8	13.7	30.5	961,830.4	0.00	1.00
09/19/2025 03:00	2	1.5	10.4	13.7	32.7	962,020.6	0.00	1.00
09/19/2025 04:00	2	1.6	10.2	13.7	29.7	962,781.4	0.00	1.00
09/19/2025 05:00	2	1.6	10.0	13.7	28.8	960,118.7	0.00	1.00
09/19/2025 06:00	2	1.7	10.3	13.6	30.5	964,600.0	0.00	1.00
09/19/2025 07:00	2	1.6	9.9	13.8	29.7	969,783.9	0.00	1.00
09/19/2025 08:00	2	1.5	9.9	13.8	32.1	971,134.1	0.00	1.00
09/19/2025 09:00	2	1.6	9.9	13.7	29.9	959,738.3	0.00	1.00
09/19/2025 10:00	2	1.7	10.0	13.7	29.0	960,689.2	0.00	1.00
09/19/2025 11:00	2	1.6	10.1	13.7	30.4	962,401.0	0.00	1.00
09/19/2025 12:00	2	1.7	10.0	13.7	29.6	962,781.4	0.00	1.00
09/19/2025 13:00	2	1.7	10.4	13.6	31.0	956,533.6	0.00	1.00
09/19/2025 14:00	2	1.7	11.0	13.4	33.2	950,928.3	0.00	1.00
09/19/2025 15:00	2	1.6	10.7	13.5	32.4	948,604.0	0.00	1.00
09/19/2025 16:00	2	1.7	10.7	13.5	31.4	953,970.6	0.00	1.00
09/19/2025 17:00	2	1.7	10.6	13.6	31.6	959,910.2	0.00	1.00
09/19/2025 18:00	2	1.7	10.4	13.6	31.3	957,846.7	0.00	1.00
09/19/2025 19:00	2	1.6	10.3	13.6	30.4	954,282.4	0.00	1.00
09/19/2025 20:00	2	1.6	10.6	13.5	33.5	961,187.9	0.00	1.00
09/19/2025 21:00	3	1.9	13.2	12.7	39.7	972,625.3	0.00	1.00
09/19/2025 22:00	2	1.7	11.2	13.4	32.5	967,178.8	0.00	1.00
09/19/2025 23:00	2	1.6	10.1	13.7	30.3	962,401.0	0.00	1.00
Average/Sum#:	2	1.6	10.5	13.6	31.5	961,085.7	0.00 #	24.00 #
Minimum:	2	1.5	9.9	12.7	28.8	948,604.0	0.00	1.00
Maximum:	3	1.9	13.2	13.8	39.7	972,625.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/20/2025 00:00	2	1.6	10.1	13.7	30.7	960,879.4	0.00	1.00
09/20/2025 01:00	2	1.6	9.9	13.8	30.4	971,519.8	0.00	1.00
09/20/2025 02:00	2	1.8	10.5	13.8	28.0	970,941.2	0.00	1.00
09/20/2025 03:00	2	1.5	10.3	13.8	34.2	969,205.3	0.00	1.00
09/20/2025 04:00	2	1.6	10.1	13.9	31.0	979,921.0	0.00	1.00
09/20/2025 05:00	2	1.5	10.0	13.9	31.5	977,377.7	0.00	1.00
09/20/2025 06:00	2	1.5	10.0	13.9	32.5	975,030.2	0.00	1.00
09/20/2025 07:00	2	1.5	10.0	13.9	30.1	980,312.2	0.00	1.00
09/20/2025 08:00	2	1.6	10.1	13.8	29.3	970,555.4	0.00	1.00
09/20/2025 09:00	2	1.6	10.3	13.7	31.4	965,444.2	0.00	1.00
09/20/2025 10:00	2	1.6	10.7	13.6	32.5	959,910.2	0.00	1.00
09/20/2025 11:00	2	1.7	10.9	13.5	32.7	952,490.2	0.00	1.00
09/20/2025 12:00	2	1.7	11.5	13.4	35.0	948,919.8	0.00	1.00
09/20/2025 13:00	2	1.7	11.6	13.4	35.0	949,285.0	0.00	1.00
09/20/2025 14:00	2	1.8	11.8	13.3	34.0	942,380.2	0.00	1.00
09/20/2025 15:00	3	1.7	12.0	13.2	36.4	933,164.9	0.00	1.00
09/20/2025 16:00	3	1.9	12.9	12.8	38.3	942,028.7	0.00	1.00
09/20/2025 17:00	2	1.7	11.6	13.3	34.7	945,623.6	0.00	1.00
09/20/2025 18:00	2	1.7	11.5	13.4	35.0	948,372.0	0.00	1.00
09/20/2025 19:00	2	1.6	11.1	13.5	33.2	943,792.5	0.00	1.00
09/20/2025 20:00	2	1.6	10.8	13.7	32.4	963,161.8	0.00	1.00
09/20/2025 21:00	2	1.6	10.8	13.6	34.3	950,155.4	0.00	1.00
09/20/2025 22:00	2	1.6	10.7	13.7	32.4	965,444.2	0.00	1.00
09/20/2025 23:00	2	1.6	10.6	13.7	31.7	954,602.9	0.00	1.00
Average/Sum#:	2	1.6	10.8	13.6	32.8	959,188.2	0.00 #	24.00 #
Minimum:	2	1.5	9.9	12.8	28.0	933,164.9	0.00	1.00
Maximum:	3	1.9	12.9	13.9	38.3	980,312.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/21/2025 00:00	2	1.7	10.5	13.8	32.1	966,312.1	0.00	1.00
09/21/2025 01:00	2	1.5	10.4	13.8	33.2	965,733.5	0.00	1.00
09/21/2025 02:00	2	1.5	10.9	13.8	32.2	965,347.8	0.00	1.00
09/21/2025 03:00	2	1.5	10.6	13.9	35.1	978,551.5	0.00	1.00
09/21/2025 04:00	2	1.5	10.4	13.9	32.6	977,182.1	0.00	1.00
09/21/2025 05:00	2	1.5	10.3	13.9	32.7	975,225.8	0.00	1.00
09/21/2025 06:00	2	1.6	10.2	13.9	31.8	974,638.9	0.00	1.00
09/21/2025 07:00	2	1.6	10.2	13.9	31.2	979,921.0	0.00	1.00
09/21/2025 08:00	2	1.6	10.4	13.8	31.2	971,905.6	0.00	1.00
09/21/2025 09:00	2	1.6	10.6	13.7	32.2	964,493.2	0.00	1.00
09/21/2025 10:00	2	1.6	10.9	13.6	34.4	959,535.0	0.00	1.00
09/21/2025 11:00	2	1.8	11.6	13.3	34.3	937,515.1	0.00	1.00
09/21/2025 12:00	3	1.7	12.1	13.1	35.9	925,590.4	0.00	1.00
09/21/2025 13:00	2	1.9	12.3	13.0	34.4	916,994.3	0.00	1.00
09/21/2025 14:00	3	1.8	12.6	12.9	35.1	909,297.8	0.00	1.00
09/21/2025 15:00	3	1.9	12.9	12.8	36.9	900,438.8	0.00	1.00
09/21/2025 16:00	3	1.9	13.0	12.8	37.3	902,467.6	0.00	1.00
09/21/2025 17:00	3	1.8	12.7	12.9	35.3	908,099.5	0.00	1.00
09/21/2025 18:00	3	1.8	12.1	13.2	35.5	929,608.0	0.00	1.00
09/21/2025 19:00	2	1.7	11.4	13.4	32.5	939,059.9	0.00	1.00
09/21/2025 20:00	2	1.7	11.1	13.5	32.5	947,123.5	0.00	1.00
09/21/2025 21:00	2	1.6	11.0	13.5	33.6	945,087.9	0.00	1.00
09/21/2025 22:00	2	1.7	10.8	13.5	31.2	942,312.0	0.00	1.00
09/21/2025 23:00	2	1.6	10.6	13.6	32.9	950,530.6	0.00	1.00
Average/Sum#:	2	1.7	11.2	13.5	33.6	947,207.2	0.00 #	24.00 #
Minimum:	2	1.5	10.2	12.8	31.2	900,438.8	0.00	1.00
Maximum:	3	1.9	13.0	13.9	37.3	979,921.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10								
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/22/2025 00:00	2	1.6	10.7	13.6	32.3	947,529.1	0.00	1.00
09/22/2025 01:00	2	1.6	10.6	13.7	31.9	958,026.5	0.00	1.00
09/22/2025 02:00	2	1.4	11.0	13.7	34.7	956,314.7	0.00	1.00
09/22/2025 03:00	2	1.6	10.8	13.7	32.2	955,934.3	0.00	1.00
09/22/2025 04:00	2	1.7	10.5	13.8	30.4	965,733.5	0.00	1.00
09/22/2025 05:00	2	1.6	10.4	13.9	33.1	974,834.5	0.00	1.00
09/22/2025 06:00	2	1.6	10.3	13.9	31.6	974,052.0	0.00	1.00
09/22/2025 07:00	2	1.6	10.5	13.8	32.2	969,976.8	0.00	1.00
09/22/2025 08:00	2	1.7	10.8	13.6	32.7	952,594.1	0.00	1.00
09/22/2025 09:00	2	1.6	11.0	13.6	33.5	959,535.0	0.00	1.00
09/22/2025 10:00	2	1.5	10.1	14.2	29.1	814,500.9	0.00	1.00
09/22/2025 11:00	2	1.3	10.0	14.5	26.0	766,021.8	0.00	1.00
09/22/2025 12:00	2	1.3	9.2	14.3	24.5	844,063.4	0.00	1.00
09/22/2025 13:00	2	1.7	10.3	13.6	29.1	954,470.0	0.00	1.00
09/22/2025 14:00	3	1.9	12.8	12.8	36.3	902,636.6	0.00	1.00
09/22/2025 15:00	3	2.0	13.4	12.6	37.4	885,671.1	0.00	1.00
09/22/2025 16:00	3	2.1	13.7	12.4	39.5	889,642.5	0.00	1.00
09/22/2025 17:00	2	1.7	10.9	13.4	31.2	948,737.2	0.00	1.00
09/22/2025 18:00	2	1.6	10.2	13.6	30.4	953,719.7	0.00	1.00
09/22/2025 19:00	2	1.6	10.2	13.6	30.5	949,217.4	0.00	1.00
09/22/2025 20:00	2	1.6	10.1	13.7	30.0	958,406.9	0.00	1.00
09/22/2025 21:00	2	1.7	10.0	13.7	29.3	958,977.5	0.00	1.00
09/22/2025 22:00	2	1.6	10.0	13.7	31.2	956,124.5	0.00	1.00
09/22/2025 23:00	2	1.6	10.0	13.8	30.6	967,855.1	0.00	1.00
Average/Sum#:	2	1.6	10.7	13.6	31.7	931,857.3	0.00 #	24.00 #
Minimum:	2	1.3	9.2	12.4	24.5	766,021.8	0.00	1.00
Maximum:	3	2.1	13.7	14.5	39.5	974,834.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/23/2025 00:00	2	1.6	10.0	13.8	29.6	964,190.5	0.00	1.00
09/23/2025 01:00	2	1.6	10.0	13.8	30.4	962,454.6	0.00	1.00
09/23/2025 02:00	2	1.8	10.4	13.8	27.3	961,683.1	0.00	1.00
09/23/2025 03:00	2	1.5	10.2	13.8	33.9	963,226.1	0.00	1.00
09/23/2025 04:00	2	1.5	10.1	13.9	32.5	975,617.1	0.00	1.00
09/23/2025 05:00	2	1.6	10.5	13.8	32.1	972,291.3	0.00	1.00
09/23/2025 06:00	2	1.5	10.3	13.9	34.5	983,051.1	0.00	1.00
09/23/2025 07:00	2	1.6	10.6	13.8	32.6	977,499.0	0.00	1.00
09/23/2025 08:00	2	1.6	11.0	13.6	35.4	959,535.0	0.00	1.00
09/23/2025 09:00	2	1.7	11.4	13.4	34.3	945,268.0	0.00	1.00
09/23/2025 10:00	3	1.7	12.1	13.2	37.6	934,409.8	0.00	1.00
09/23/2025 11:00	3	1.9	12.9	12.9	36.8	912,207.8	0.00	1.00
09/23/2025 12:00	3	2.0	13.7	12.5	39.0	881,485.4	0.00	1.00
09/23/2025 13:00	2	1.6	10.8	13.4	31.6	937,234.0	0.00	1.00
09/23/2025 14:00	2	1.7	10.5	13.6	32.5	958,972.3	0.00	1.00
09/23/2025 15:00	2	1.7	11.0	13.4	31.6	953,849.7	0.00	1.00
09/23/2025 16:00	2	1.8	11.4	13.2	34.0	949,171.2	0.00	1.00
09/23/2025 17:00	3	2.1	13.9	12.4	43.4	957,469.3	0.00	1.00
09/23/2025 18:00	3	2.0	12.8	12.8	39.7	955,553.9	0.00	1.00
09/23/2025 19:00	3	1.9	13.4	12.9	38.7	916,316.1	0.00	1.00
09/23/2025 20:00	3	1.8	12.6	13.2	38.2	937,611.1	0.00	1.00
09/23/2025 21:00	2	1.7	11.8	13.4	35.4	947,824.3	0.00	1.00
09/23/2025 22:00	2	1.7	11.1	13.6	33.9	956,533.6	0.00	1.00
09/23/2025 23:00	2	1.7	11.0	13.7	32.7	966,585.4	0.00	1.00
Average/Sum#:	2	1.7	11.4	13.4	34.5	951,251.7	0.00 #	24.00 #
Minimum:	2	1.5	10.0	12.4	27.3	881,485.4	0.00	1.00
Maximum:	3	2.1	13.9	13.9	43.4	983,051.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/24/2025 00:00	2	1.6	11.0	13.7	35.1	965,063.8	0.00	1.00
09/24/2025 01:00	2	1.6	10.9	13.7	33.1	961,830.4	0.00	1.00
09/24/2025 02:00	2	1.7	11.2	13.7	32.5	957,646.1	0.00	1.00
09/24/2025 03:00	2	1.7	10.8	13.8	31.1	965,347.8	0.00	1.00
09/24/2025 04:00	2	1.7	10.6	13.8	31.2	964,962.0	0.00	1.00
09/24/2025 05:00	2	1.7	10.8	13.7	31.8	968,297.2	0.00	1.00
09/24/2025 06:00	2	1.6	10.5	13.8	32.7	968,240.9	0.00	1.00
09/24/2025 07:00	2	1.6	10.6	13.8	33.1	971,326.9	0.00	1.00
09/24/2025 08:00	2	1.7	10.9	13.7	33.0	974,573.7	0.00	1.00
09/24/2025 09:00	2	1.7	11.7	13.4	34.7	960,057.8	0.00	1.00
09/24/2025 10:00	2	1.6	11.3	13.6	35.7	957,096.3	0.00	1.00
09/24/2025 11:00	2	1.7	11.1	13.6	32.8	955,032.8	0.00	1.00
09/24/2025 12:00	2	1.7	11.4	13.6	36.1	961,411.0	0.00	1.00
09/24/2025 13:00	2	1.7	12.0	13.4	35.7	942,711.7	0.00	1.00
09/24/2025 14:00	3	1.8	12.6	13.2	38.4	926,762.4	0.00	1.00
09/24/2025 15:00	3	1.7	12.7	13.4	39.8	941,798.8	0.00	1.00
09/24/2025 16:00	3	1.8	13.1	13.2	39.7	942,590.8	0.00	1.00
09/24/2025 17:00	3	1.7	11.7	13.4	35.9	937,416.6	0.00	1.00
09/24/2025 18:00	2	1.6	11.2	13.6	35.1	952,781.7	0.00	1.00
09/24/2025 19:00	2	1.7	11.1	13.6	32.9	950,343.0	0.00	1.00
09/24/2025 20:00	2	1.6	11.0	13.7	35.6	965,634.4	0.00	1.00
09/24/2025 21:00	2	1.6	10.8	13.8	32.7	972,098.4	0.00	1.00
09/24/2025 22:00	2	1.6	10.8	13.8	33.3	971,134.1	0.00	1.00
09/24/2025 23:00	2	1.6	10.6	13.7	32.0	958,597.1	0.00	1.00
Average/Sum#:	2	1.7	11.3	13.6	34.3	958,031.5	0.00 #	24.00 #
Minimum:	2	1.6	10.5	13.2	31.1	926,762.4	0.00	1.00
Maximum:	3	1.8	13.1	13.8	39.8	974,573.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/25/2025 00:00	2	1.6	10.6	13.8	31.9	970,555.4	0.00	1.00
09/25/2025 01:00	2	1.5	10.5	13.8	32.6	968,240.9	0.00	1.00
09/25/2025 02:00	2	1.5	11.0	13.8	32.1	968,626.7	0.00	1.00
09/25/2025 03:00	2	1.5	10.7	13.8	35.3	969,398.2	0.00	1.00
09/25/2025 04:00	2	1.7	10.7	13.8	31.4	970,748.3	0.00	1.00
09/25/2025 05:00	2	1.6	10.5	13.8	31.8	969,783.9	0.00	1.00
09/25/2025 06:00	2	1.7	10.4	13.8	31.6	976,341.7	0.00	1.00
09/25/2025 07:00	2	1.5	10.3	13.8	33.0	975,184.5	0.00	1.00
09/25/2025 08:00	2	1.6	10.5	13.7	31.4	965,444.2	0.00	1.00
09/25/2025 09:00	2	1.6	10.6	13.7	31.7	967,346.2	0.00	1.00
09/25/2025 10:00	2	1.7	10.8	13.6	33.3	956,721.1	0.00	1.00
09/25/2025 11:00	2	1.7	11.0	13.5	32.2	949,159.1	0.00	1.00
09/25/2025 12:00	2	1.7	11.3	13.3	34.4	931,749.1	0.00	1.00
09/25/2025 13:00	2	1.8	11.7	13.3	33.5	938,956.6	0.00	1.00
09/25/2025 14:00	2	1.8	11.9	13.2	34.9	929,608.0	0.00	1.00
09/25/2025 15:00	3	1.8	12.3	13.2	36.0	930,852.9	0.00	1.00
09/25/2025 16:00	3	1.9	12.9	12.8	37.0	895,705.0	0.00	1.00
09/25/2025 17:00	2	1.8	12.3	13.1	34.1	913,476.3	0.00	1.00
09/25/2025 18:00	2	1.6	11.0	13.5	34.4	943,237.3	0.00	1.00
09/25/2025 19:00	2	1.6	10.8	13.7	32.1	959,357.9	0.00	1.00
09/25/2025 20:00	2	1.7	10.7	13.8	31.4	964,962.0	0.00	1.00
09/25/2025 21:00	2	1.6	10.5	13.8	32.9	963,033.2	0.00	1.00
09/25/2025 22:00	2	1.5	10.5	13.9	32.6	972,682.6	0.00	1.00
09/25/2025 23:00	2	1.6	10.4	13.9	31.4	973,269.5	0.00	1.00
Average/Sum#:	2	1.7	11.0	13.6	33.0	955,185.0	0.00 #	24.00 #
Minimum:	2	1.5	10.3	12.8	31.4	895,705.0	0.00	1.00
Maximum:	3	1.9	12.9	13.9	37.0	976,341.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1

From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/26/2025 00:00	2	1.7	10.4	13.9	31.5	974,834.5	0.00	1.00
09/26/2025 01:00	2	1.5	10.4	13.9	34.4	972,682.6	0.00	1.00
09/26/2025 02:00	2	1.6	10.7	14.0	32.1	984,993.2	0.00	1.00
09/26/2025 03:00	2	1.6	10.4	14.0	33.7	984,199.4	0.00	1.00
09/26/2025 04:00	2	1.6	10.4	14.0	33.5	986,382.5	0.00	1.00
09/26/2025 05:00	2	1.5	10.3	14.0	34.3	984,596.3	0.00	1.00
09/26/2025 06:00	2	1.5	10.3	14.0	33.8	981,619.3	0.00	1.00
09/26/2025 07:00	2	1.4	10.0	14.2	31.1	893,804.9	0.00	1.00
09/26/2025 08:00	2	1.3	10.3	14.4	28.5	760,978.6	0.00	1.00
09/26/2025 09:00	2	1.3	10.4	14.4	27.0	758,871.8	0.00	1.00
09/26/2025 10:00	2	1.4	10.4	14.4	27.0	755,500.9	0.00	1.00
09/26/2025 11:00	2	1.3	10.4	14.4	28.3	753,815.5	0.00	1.00
09/26/2025 12:00	2	1.4	10.4	14.5	25.4	763,668.1	0.00	1.00
09/26/2025 13:00	2	1.2	9.9	14.4	28.5	845,461.5	0.00	1.00
09/26/2025 14:00	3	1.7	12.6	13.1	36.8	922,956.9	0.00	1.00
09/26/2025 15:00	3	1.9	13.0	12.9	36.1	904,333.6	0.00	1.00
09/26/2025 16:00	3	1.9	13.2	12.9	37.5	908,099.5	0.00	1.00
09/26/2025 17:00	3	1.9	13.0	12.9	37.2	902,279.5	0.00	1.00
09/26/2025 18:00	2	1.8	12.5	13.0	34.1	901,913.3	0.00	1.00
09/26/2025 19:00	2	1.7	11.6	13.4	34.2	936,321.1	0.00	1.00
09/26/2025 20:00	2	1.7	11.2	13.5	34.5	943,792.5	0.00	1.00
09/26/2025 21:00	2	1.6	11.0	13.6	32.5	952,781.7	0.00	1.00
09/26/2025 22:00	2	1.6	10.8	13.6	33.2	946,591.2	0.00	1.00
09/26/2025 23:00	2	1.6	10.7	13.7	32.7	957,075.5	0.00	1.00
Average/Sum#:	2	1.6	11.0	13.8	32.4	903,231.4	0.00 #	24.00 #
Minimum:	2	1.2	9.9	12.9	25.4	753,815.5	0.00	1.00
Maximum:	3	1.9	13.2	14.5	37.5	986,382.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/27/2025 00:00	2	1.7	10.7	13.7	32.1	955,363.7	0.00	1.00
09/27/2025 01:00	2	1.5	10.8	13.7	33.0	955,363.7	0.00	1.00
09/27/2025 02:00	2	1.8	11.2	13.7	29.6	954,412.7	0.00	1.00
09/27/2025 03:00	3	1.6	11.0	13.8	35.1	965,926.4	0.00	1.00
09/27/2025 04:00	2	1.6	10.9	13.8	32.3	965,926.4	0.00	1.00
09/27/2025 05:00	2	1.6	10.8	13.8	34.5	966,890.8	0.00	1.00
09/27/2025 06:00	2	1.6	10.7	13.8	32.9	965,926.4	0.00	1.00
09/27/2025 07:00	2	1.3	10.1	14.3	29.3	836,593.8	0.00	1.00
09/27/2025 08:00	2	1.3	10.2	14.4	28.2	759,082.5	0.00	1.00
09/27/2025 09:00	2	1.2	10.4	14.5	29.0	770,087.2	0.00	1.00
09/27/2025 10:00	2	1.3	10.3	14.5	26.5	769,445.3	0.00	1.00
09/27/2025 11:00	2	1.4	10.3	14.5	25.2	769,231.4	0.00	1.00
09/27/2025 12:00	2	1.4	10.3	14.5	27.3	769,445.3	0.00	1.00
09/27/2025 13:00	2	1.2	9.5	14.5	22.9	767,733.5	0.00	1.00
09/27/2025 14:00	2	1.3	10.2	14.5	26.0	767,733.5	0.00	1.00
09/27/2025 15:00	2	1.3	9.7	14.4	27.1	861,894.6	0.00	1.00
09/27/2025 16:00	2	1.7	11.5	13.4	34.2	939,242.5	0.00	1.00
09/27/2025 17:00	2	1.6	11.0	13.6	32.6	955,032.8	0.00	1.00
09/27/2025 18:00	2	1.6	10.8	13.7	33.9	956,695.1	0.00	1.00
09/27/2025 19:00	2	1.6	10.6	13.8	33.1	964,190.5	0.00	1.00
09/27/2025 20:00	2	1.5	10.4	13.9	32.9	974,834.5	0.00	1.00
09/27/2025 21:00	2	1.6	10.3	13.9	31.9	972,095.7	0.00	1.00
09/27/2025 22:00	2	1.6	10.3	13.9	31.4	970,921.9	0.00	1.00
09/27/2025 23:00	2	1.5	10.4	13.9	33.1	974,052.0	0.00	1.00
Average/Sum#:	2	1.5	10.5	14.0	30.6	896,171.8	0.00 #	24.00 #
Minimum:	2	1.2	9.5	13.4	22.9	759,082.5	0.00	1.00
Maximum:	3	1.8	11.5	14.5	35.1	974,834.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/28/2025 00:00	2	1.5	10.3	13.9	32.0	974,247.6	0.00	1.00
09/28/2025 01:00	2	1.5	10.2	13.9	32.6	972,095.7	0.00	1.00
09/28/2025 02:00	2	1.6	10.7	14.0	31.6	984,199.4	0.00	1.00
09/28/2025 03:00	2	1.5	10.5	14.0	35.4	985,191.7	0.00	1.00
09/28/2025 04:00	2	1.5	10.3	14.0	33.5	985,390.2	0.00	1.00
09/28/2025 05:00	2	1.5	10.3	14.0	32.3	984,794.8	0.00	1.00
09/28/2025 06:00	2	1.6	10.3	14.0	31.9	982,413.1	0.00	1.00
09/28/2025 07:00	2	1.5	9.9	14.1	31.2	956,583.2	0.00	1.00
09/28/2025 08:00	2	1.3	10.1	14.4	28.7	766,245.6	0.00	1.00
09/28/2025 09:00	2	1.3	10.2	14.4	25.1	760,767.9	0.00	1.00
09/28/2025 10:00	2	1.5	10.2	14.4	23.9	760,557.2	0.00	1.00
09/28/2025 11:00	2	1.3	10.3	14.4	28.4	760,135.9	0.00	1.00
09/28/2025 12:00	1	1.5	9.7	14.3	23.9	858,172.6	0.00	1.00
09/28/2025 13:00	2	1.6	10.5	13.8	31.9	976,727.5	0.00	1.00
09/28/2025 14:00	2	1.4	9.1	14.4	27.3	941,742.6	0.00	1.00
09/28/2025 15:00	2	1.6	10.6	13.8	32.4	970,748.3	0.00	1.00
09/28/2025 16:00	2	1.6	10.5	13.8	31.3	969,783.9	0.00	1.00
09/28/2025 17:00	2	1.5	10.4	13.9	32.4	981,290.4	0.00	1.00
09/28/2025 18:00	2	1.6	10.4	13.9	32.1	977,964.6	0.00	1.00
09/28/2025 19:00	2	1.5	10.4	13.9	33.0	978,160.3	0.00	1.00
09/28/2025 20:00	2	1.5	10.4	13.9	32.1	975,421.4	0.00	1.00
09/28/2025 21:00	2	1.5	10.4	13.9	32.9	977,182.1	0.00	1.00
09/28/2025 22:00	2	1.6	10.3	13.9	31.2	976,008.3	0.00	1.00
09/28/2025 23:00	2	1.6	10.2	13.9	32.6	975,225.8	0.00	1.00
Average/Sum#:	2	1.5	10.3	14.0	30.8	934,627.1	0.00 #	24.00 #
Minimum:	1	1.3	9.1	13.8	23.9	760,135.9	0.00	1.00
Maximum:	2	1.6	10.7	14.4	35.4	985,390.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/29/2025 00:00	2	1.6	10.2	13.9	32.2	973,269.5	0.00	1.00
09/29/2025 01:00	2	1.5	10.2	13.9	31.4	973,856.4	0.00	1.00
09/29/2025 02:00	2	1.6	10.7	13.9	32.3	975,225.8	0.00	1.00
09/29/2025 03:00	2	1.5	10.5	13.9	33.6	975,617.1	0.00	1.00
09/29/2025 04:00	2	1.6	10.3	13.9	31.8	977,573.4	0.00	1.00
09/29/2025 05:00	2	1.5	10.3	13.9	33.5	977,769.0	0.00	1.00
09/29/2025 06:00	2	1.6	10.3	13.9	30.9	977,377.7	0.00	1.00
09/29/2025 07:00	2	1.6	10.3	13.9	31.9	976,008.3	0.00	1.00
09/29/2025 08:00	2	1.2	8.9	14.5	25.7	886,488.3	0.00	1.00
09/29/2025 09:00	2	1.7	10.6	13.8	30.8	973,062.8	0.00	1.00
09/29/2025 10:00	2	1.7	10.7	13.8	30.7	975,570.2	0.00	1.00
09/29/2025 11:00	2	1.7	10.6	13.8	31.3	975,570.2	0.00	1.00
09/29/2025 12:00	2	1.6	10.6	13.8	31.7	974,991.6	0.00	1.00
09/29/2025 13:00	2	1.6	10.6	13.8	31.9	974,413.0	0.00	1.00
09/29/2025 14:00	2	1.5	10.6	13.8	33.6	978,849.1	0.00	1.00
09/29/2025 15:00	2	1.7	10.8	13.8	32.0	974,991.6	0.00	1.00
09/29/2025 16:00	2	1.7	11.2	13.7	34.4	961,069.6	0.00	1.00
09/29/2025 17:00	2	1.7	11.0	13.8	34.3	957,054.1	0.00	1.00
09/29/2025 18:00	2	1.6	11.1	13.8	34.4	953,003.6	0.00	1.00
09/29/2025 19:00	2	1.5	11.1	13.8	36.3	950,496.2	0.00	1.00
09/29/2025 20:00	2	1.6	11.0	13.8	34.4	949,724.7	0.00	1.00
09/29/2025 21:00	2	1.5	10.9	13.9	35.4	963,096.6	0.00	1.00
09/29/2025 22:00	2	1.6	10.6	13.8	32.2	947,988.9	0.00	1.00
09/29/2025 23:00	2	1.6	10.4	13.9	32.3	960,553.4	0.00	1.00
Average/Sum#:	2	1.6	10.6	13.9	32.5	965,150.9	0.00 #	24.00 #
Minimum:	2	1.2	8.9	13.7	25.7	886,488.3	0.00	1.00
Maximum:	2	1.7	11.2	14.5	36.3	978,849.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

> 10

	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/30/2025 00:00	2	1.6	10.5	13.9	32.6	960,749.0	0.00	1.00
09/30/2025 01:00	2	1.6	10.5	13.9	32.8	959,770.9	0.00	1.00
09/30/2025 02:00	2	1.6	10.9	13.9	32.5	958,792.7	0.00	1.00
09/30/2025 03:00	2	1.7	10.6	13.9	31.2	958,010.2	0.00	1.00
09/30/2025 04:00	2	1.5	10.5	13.9	34.7	958,401.4	0.00	1.00
09/30/2025 05:00	2	1.6	11.1	13.7	34.4	966,775.6	0.00	1.00
09/30/2025 06:00	3	1.8	11.8	13.5	36.6	960,632.7	0.00	1.00
09/30/2025 07:00	2	1.6	10.6	13.9	31.8	960,553.4	0.00	1.00
09/30/2025 08:00	2	1.3	9.2	14.4	28.9	922,781.4	0.00	1.00
09/30/2025 09:00	2	1.7	10.9	13.8	33.3	953,196.5	0.00	1.00
09/30/2025 10:00	2	1.6	11.1	13.8	35.5	959,368.6	0.00	1.00
09/30/2025 11:00	2	1.6	11.3	13.7	35.6	949,657.8	0.00	1.00
09/30/2025 12:00	3	1.6	11.6	13.7	37.5	951,749.9	0.00	1.00
09/30/2025 13:00	2	1.7	11.6	13.7	35.6	949,087.2	0.00	1.00
09/30/2025 14:00	2	1.4	10.0	14.4	30.7	919,199.8	0.00	1.00
09/30/2025 15:00	2	1.6	11.6	13.8	36.7	958,404.2	0.00	1.00
09/30/2025 16:00	3	1.7	12.1	13.6	37.3	959,722.6	0.00	1.00
09/30/2025 17:00	2	1.6	11.3	13.8	36.5	953,003.6	0.00	1.00
09/30/2025 18:00	2	1.7	11.2	13.9	34.4	962,705.3	0.00	1.00
09/30/2025 19:00	3	1.6	11.3	13.9	37.3	962,118.4	0.00	1.00
09/30/2025 20:00	2	1.6	11.2	13.9	35.4	959,770.9	0.00	1.00
09/30/2025 21:00	2	1.7	11.1	13.9	34.9	959,379.6	0.00	1.00
09/30/2025 22:00	2	2.3	13.2	14.5	26.6	798,759.6	0.17	1.00
09/30/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	2	1.6	11.1	13.9	34.0	947,938.8	0.17 #	23.00 #
Minimum:	2	1.3	9.2	13.5	26.6	798,759.6	0.00	0.00
Maximum:	3	2.3	13.2	14.5	37.5	966,775.6	0.17	1.00
%SI	4.17	4.17	4.17	4.17	4.17	4.17	0.00	0.00