

DOCKETED	
Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	266728
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q3 2025 - Part 3s
Description:	N/A
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public Agency
Submission Date:	10/21/2025 3:34:28 PM
Docketed Date:	10/21/2025

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/01/2025 00:00	0	1.7	8.9	14.4	9.7	913,722.1	0.00	1.00
07/01/2025 01:00	0	1.7	8.9	14.4	9.9	933,526.1	0.00	1.00
07/01/2025 02:00	0	1.7	9.2	14.4	9.9	956,700.9	0.00	1.00
07/01/2025 03:00	0	1.6	9.2	14.4	10.2	955,858.2	0.00	1.00
07/01/2025 04:00	0	1.6	9.1	14.4	10.1	954,383.5	0.00	1.00
07/01/2025 05:00	0	1.7	9.0	14.3	7.4	804,433.1	0.00	1.00
07/01/2025 06:00	0	1.7	8.8	14.3	7.3	792,813.7	0.00	1.00
07/01/2025 07:00	0	1.7	8.9	14.3	7.5	793,436.2	0.00	1.00
07/01/2025 08:00	0	1.7	8.9	14.3	7.9	791,361.3	0.00	1.00
07/01/2025 09:00	0	1.7	8.8	14.4	8.2	807,749.7	0.00	1.00
07/01/2025 10:00	0	1.7	8.8	14.4	8.2	820,390.5	0.00	1.00
07/01/2025 11:00	0	1.6	8.6	14.4	7.8	848,832.4	0.00	1.00
07/01/2025 12:00	0	1.7	8.2	14.5	9.0	978,068.6	0.00	1.00
07/01/2025 13:00	0	1.6	8.1	14.5	10.1	1,011,662.3	0.00	1.00
07/01/2025 14:00	0	1.6	8.2	14.5	11.3	1,007,382.8	0.00	1.00
07/01/2025 15:00	0	1.6	8.2	14.5	11.6	1,007,810.8	0.00	1.00
07/01/2025 16:00	0	1.6	8.3	14.4	9.4	894,760.8	0.00	1.00
07/01/2025 17:00	0	1.7	8.5	14.4	9.1	879,591.8	0.00	1.00
07/01/2025 18:00	0	1.6	8.1	14.5	10.4	1,009,736.5	0.00	1.00
07/01/2025 19:00	0	1.6	8.3	14.3	8.9	878,714.0	0.00	1.00
07/01/2025 20:00	0	1.6	8.4	14.3	8.7	849,665.6	0.00	1.00
07/01/2025 21:00	0	1.7	8.4	14.3	9.6	900,292.8	0.00	1.00
07/01/2025 22:00	0	1.7	8.5	14.2	7.4	801,624.2	0.00	1.00
07/01/2025 23:00	0	1.6	8.6	14.4	9.8	950,169.8	0.00	1.00
Average/Sum#:	0	1.7	8.6	14.4	9.1	897,612.0	0.00 #	24.00 #
Minimum:	0	1.6	8.1	14.2	7.3	791,361.3	0.00	1.00
Maximum:	0	1.7	9.2	14.5	11.6	1,011,662.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/02/2025 00:00	0	1.7	8.7	14.2	7.3	784,659.7	0.00	1.00
07/02/2025 01:00	0	1.7	8.8	14.2	7.1	781,185.1	0.00	1.00
07/02/2025 02:00	0	1.7	9.1	14.3	7.6	791,983.8	0.00	1.00
07/02/2025 03:00	0	1.7	9.1	14.3	7.1	792,191.3	0.00	1.00
07/02/2025 04:00	0	1.7	9.0	14.3	7.3	792,606.2	0.00	1.00
07/02/2025 05:00	0	1.7	9.0	14.3	7.2	793,228.7	0.00	1.00
07/02/2025 06:00	0	1.7	8.9	14.3	7.1	793,643.7	0.00	1.00
07/02/2025 07:00	0	1.7	8.8	14.3	7.3	792,398.7	0.00	1.00
07/02/2025 08:00	0	1.7	8.8	14.3	7.8	791,776.3	0.00	1.00
07/02/2025 09:00	0	1.7	8.8	14.4	8.4	802,272.0	0.00	1.00
07/02/2025 10:00	0	1.6	8.7	14.4	7.8	800,586.6	0.00	1.00
07/02/2025 11:00	0	1.7	8.7	14.4	7.7	800,586.6	0.00	1.00
07/02/2025 12:00	0	1.7	8.5	14.4	7.6	799,322.5	0.00	1.00
07/02/2025 13:00	0	1.7	8.2	14.4	7.9	799,111.8	0.00	1.00
07/02/2025 14:00	0	1.6	8.2	14.5	8.9	839,628.3	0.00	1.00
07/02/2025 15:00	0	1.6	8.3	14.5	11.5	1,012,090.2	0.00	1.00
07/02/2025 16:00	0	1.6	8.2	14.4	7.6	805,221.5	0.00	1.00
07/02/2025 17:00	0	1.6	7.9	14.5	7.2	808,174.4	0.00	1.00
07/02/2025 18:00	0	1.5	8.4	14.4	9.6	880,645.2	0.00	1.00
07/02/2025 19:00	0	1.7	8.4	14.4	8.0	798,058.4	0.00	1.00
07/02/2025 20:00	0	1.7	8.4	14.3	8.4	786,589.1	0.00	1.00
07/02/2025 21:00	0	1.6	8.6	14.3	8.0	787,834.0	0.00	1.00
07/02/2025 22:00	0	1.7	8.6	14.3	7.5	787,626.5	0.00	1.00
07/02/2025 23:00	0	1.7	8.7	14.3	7.2	788,664.0	0.00	1.00
Average/Sum#:	0	1.7	8.6	14.4	7.9	808,753.5	0.00 #	24.00 #
Minimum:	0	1.5	7.9	14.2	7.1	781,185.1	0.00	1.00
Maximum:	0	1.7	9.1	14.5	11.5	1,012,090.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/03/2025 00:00	0	1.7	8.8	14.3	7.0	788,456.5	0.00	1.00
07/03/2025 01:00	0	1.7	8.8	14.3	7.1	788,664.0	0.00	1.00
07/03/2025 02:00	0	1.7	9.2	14.3	7.2	789,908.9	0.00	1.00
07/03/2025 03:00	0	1.7	9.1	14.3	6.3	790,323.9	0.00	1.00
07/03/2025 04:00	0	1.7	9.1	14.3	7.0	790,323.9	0.00	1.00
07/03/2025 05:00	0	1.7	9.1	14.2	6.9	779,345.5	0.00	1.00
07/03/2025 06:00	0	1.7	9.0	14.3	7.4	790,531.3	0.00	1.00
07/03/2025 07:00	0	1.7	8.9	14.3	7.7	789,078.9	0.00	1.00
07/03/2025 08:00	0	1.7	8.9	14.3	8.1	788,664.0	0.00	1.00
07/03/2025 09:00	0	1.7	8.8	14.3	8.2	788,041.5	0.00	1.00
07/03/2025 10:00	0	1.7	8.8	14.3	8.4	787,834.0	0.00	1.00
07/03/2025 11:00	0	1.6	8.7	14.4	8.0	797,637.0	0.00	1.00
07/03/2025 12:00	0	1.7	8.8	14.4	8.2	797,637.0	0.00	1.00
07/03/2025 13:00	0	1.7	8.8	14.4	8.0	796,583.6	0.00	1.00
07/03/2025 14:00	0	1.7	8.9	14.4	8.5	796,794.3	0.00	1.00
07/03/2025 15:00	0	1.7	8.9	14.4	8.7	796,372.9	0.00	1.00
07/03/2025 16:00	0	1.7	8.8	14.4	8.6	797,426.4	0.00	1.00
07/03/2025 17:00	0	1.7	8.8	14.4	8.7	798,479.8	0.00	1.00
07/03/2025 18:00	0	1.7	8.8	14.4	8.5	799,322.5	0.00	1.00
07/03/2025 19:00	0	1.7	8.9	14.3	8.3	789,078.9	0.00	1.00
07/03/2025 20:00	0	1.7	8.8	14.3	8.0	789,908.9	0.00	1.00
07/03/2025 21:00	0	1.7	8.9	14.3	7.4	789,908.9	0.00	1.00
07/03/2025 22:00	0	1.7	9.0	14.3	7.3	791,153.8	0.00	1.00
07/03/2025 23:00	0	1.7	8.9	14.3	6.8	793,021.2	0.00	1.00
Average/Sum#:	0	1.7	8.9	14.3	7.8	791,854.1	0.00 #	24.00 #
Minimum:	0	1.6	8.7	14.2	6.3	779,345.5	0.00	1.00
Maximum:	0	1.7	9.2	14.4	8.7	799,322.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/04/2025 00:00	0	1.7	9.1	14.4	8.6	898,131.7	0.00	1.00
07/04/2025 01:00	-1	1.7	9.1	14.3	6.6	774,139.8	0.00	1.00
07/04/2025 02:00	0	1.7	9.5	14.3	6.8	806,093.0	0.00	1.00
07/04/2025 03:00	-1	1.7	9.2	14.2	6.0	758,702.0	0.00	1.00
07/04/2025 04:00	-1	1.7	9.1	14.2	6.2	758,906.4	0.00	1.00
07/04/2025 05:00	0	1.7	9.1	14.2	6.8	759,110.8	0.00	1.00
07/04/2025 06:00	0	1.7	9.1	14.2	7.1	758,906.4	0.00	1.00
07/04/2025 07:00	0	1.7	9.0	14.3	7.5	769,782.5	0.00	1.00
07/04/2025 08:00	0	1.7	9.0	14.3	8.2	769,160.0	0.00	1.00
07/04/2025 09:00	0	1.7	9.0	14.3	8.5	768,537.6	0.00	1.00
07/04/2025 10:00	0	1.7	9.0	14.3	8.7	767,915.1	0.00	1.00
07/04/2025 11:00	0	1.7	9.0	14.4	8.4	778,254.4	0.00	1.00
07/04/2025 12:00	0	1.7	9.1	14.4	8.7	777,411.7	0.00	1.00
07/04/2025 13:00	0	1.7	9.2	14.4	8.3	776,779.6	0.00	1.00
07/04/2025 14:00	0	1.7	9.1	14.4	8.7	776,990.3	0.00	1.00
07/04/2025 15:00	0	1.7	9.1	14.4	9.1	776,990.3	0.00	1.00
07/04/2025 16:00	0	1.7	9.0	14.4	8.6	777,201.0	0.00	1.00
07/04/2025 17:00	0	1.7	9.0	14.4	9.4	796,162.3	0.00	1.00
07/04/2025 18:00	0	1.6	9.2	14.4	10.6	842,512.0	0.00	1.00
07/04/2025 19:00	0	1.7	9.1	14.3	8.2	767,915.1	0.00	1.00
07/04/2025 20:00	0	1.7	9.1	14.3	8.3	768,537.6	0.00	1.00
07/04/2025 21:00	0	1.7	9.1	14.3	7.8	770,405.0	0.00	1.00
07/04/2025 22:00	0	1.7	9.1	14.3	7.4	769,782.5	0.00	1.00
07/04/2025 23:00	0	1.7	9.1	14.3	7.2	770,405.0	0.00	1.00
Average/Sum#:	0	1.7	9.1	14.3	8.0	780,780.5	0.00 #	24.00 #
Minimum:	-1	1.6	9.0	14.2	6.0	758,702.0	0.00	1.00
Maximum:	0	1.7	9.5	14.4	10.6	898,131.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/05/2025 00:00	0	1.7	9.1	14.2	6.6	759,519.6	0.00	1.00
07/05/2025 01:00	-1	1.7	9.1	14.2	6.1	759,928.3	0.00	1.00
07/05/2025 02:00	-1	1.7	9.4	14.2	5.7	759,928.3	0.00	1.00
07/05/2025 03:00	-1	1.7	9.3	14.2	5.6	760,950.3	0.00	1.00
07/05/2025 04:00	-1	1.7	9.3	14.2	6.2	761,154.7	0.00	1.00
07/05/2025 05:00	-1	1.7	9.3	14.2	6.2	761,563.5	0.00	1.00
07/05/2025 06:00	0	1.7	9.2	14.2	7.3	761,154.7	0.00	1.00
07/05/2025 07:00	0	1.7	9.1	14.2	7.8	761,359.1	0.00	1.00
07/05/2025 08:00	0	1.7	9.1	14.3	8.5	771,857.4	0.00	1.00
07/05/2025 09:00	0	1.7	9.0	14.3	8.3	770,197.5	0.00	1.00
07/05/2025 10:00	0	1.7	9.0	14.3	8.9	769,575.0	0.00	1.00
07/05/2025 11:00	0	1.7	9.0	14.3	7.9	767,707.6	0.00	1.00
07/05/2025 12:00	0	1.7	8.9	14.4	7.9	778,675.8	0.00	1.00
07/05/2025 13:00	0	1.7	9.0	14.4	7.1	778,465.1	0.00	1.00
07/05/2025 14:00	0	1.7	9.0	14.4	7.9	778,254.4	0.00	1.00
07/05/2025 15:00	0	1.7	9.2	14.4	8.6	778,254.4	0.00	1.00
07/05/2025 16:00	0	1.6	9.2	14.4	8.1	777,411.7	0.00	1.00
07/05/2025 17:00	0	1.6	9.1	14.4	8.1	776,569.0	0.00	1.00
07/05/2025 18:00	0	1.6	9.2	14.5	9.7	865,091.1	0.00	1.00
07/05/2025 19:00	0	1.6	9.2	14.4	7.7	778,043.7	0.00	1.00
07/05/2025 20:00	0	1.7	9.2	14.4	8.4	778,465.1	0.00	1.00
07/05/2025 21:00	0	1.7	9.0	14.3	8.1	767,292.6	0.00	1.00
07/05/2025 22:00	0	1.7	8.9	14.3	7.8	767,707.6	0.00	1.00
07/05/2025 23:00	0	1.7	8.9	14.3	7.6	768,537.6	0.00	1.00
Average/Sum#:	0	1.7	9.1	14.3	7.6	773,236.0	0.00 #	24.00 #
Minimum:	-1	1.6	8.9	14.2	5.6	759,519.6	0.00	1.00
Maximum:	0	1.7	9.4	14.5	9.7	865,091.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/06/2025 00:00	0	1.7	9.0	14.3	7.2	768,952.5	0.00	1.00
07/06/2025 01:00	0	1.7	8.9	14.3	7.0	768,952.5	0.00	1.00
07/06/2025 02:00	0	1.7	9.3	14.3	6.8	769,367.5	0.00	1.00
07/06/2025 03:00	0	1.7	9.3	14.2	6.4	757,884.4	0.00	1.00
07/06/2025 04:00	-1	1.7	9.2	14.2	6.4	758,497.6	0.00	1.00
07/06/2025 05:00	-1	1.7	9.1	14.2	6.4	758,497.6	0.00	1.00
07/06/2025 06:00	0	1.7	9.0	14.2	6.7	758,497.6	0.00	1.00
07/06/2025 07:00	0	1.7	8.9	14.3	7.2	768,745.1	0.00	1.00
07/06/2025 08:00	0	1.7	8.9	14.3	7.4	768,122.6	0.00	1.00
07/06/2025 09:00	0	1.7	8.9	14.3	8.2	767,500.1	0.00	1.00
07/06/2025 10:00	0	1.7	8.9	14.4	8.0	777,622.4	0.00	1.00
07/06/2025 11:00	0	1.7	8.9	14.4	7.9	775,936.9	0.00	1.00
07/06/2025 12:00	0	1.7	8.8	14.4	8.1	775,094.2	0.00	1.00
07/06/2025 13:00	0	1.7	8.9	14.4	8.4	783,942.8	0.00	1.00
07/06/2025 14:00	0	1.6	8.8	14.5	9.7	834,920.9	0.00	1.00
07/06/2025 15:00	0	1.6	9.2	14.4	9.3	774,462.2	0.00	1.00
07/06/2025 16:00	0	1.6	8.9	14.5	9.8	859,955.7	0.00	1.00
07/06/2025 17:00	0	1.6	8.5	14.4	8.3	856,838.3	0.00	1.00
07/06/2025 18:00	2	1.5	0.0	14.4	11.2	941,321.3	0.00	1.00
07/06/2025 19:00	3	1.6	0.0	14.4	10.2	951,433.9	0.00	1.00
07/06/2025 20:00	0	0.0	0.0	0.0	9.7	296,228.1	0.00	1.00
07/06/2025 21:00	0	0.0	0.0	0.0	8.7	293,869.3	0.00	1.00
07/06/2025 22:00	0	0.0	0.0	0.0	9.0	260,911.4	0.00	1.00
07/06/2025 23:00	0	0.0	0.0	0.0	11.0	283,582.2	0.00	0.72
Average/Sum#:	0	1.7	8.1	14.3	8.3	798,827.3	0.00 #	23.72 #
Minimum:	-1	1.5	0.0	14.2	6.4	757,884.4	0.00	0.72
Maximum:	3	1.7	9.3	14.5	11.2	951,433.9	0.00	1.00
%SI	16.67	16.67	16.67	16.67	0.00	16.67	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/07/2025 00:00	0	0.0	0.0	0.0	8.9	272,705.5	0.00	1.00
07/07/2025 01:00	0	1.8	9.3	14.3	8.4	765,840.2	0.00	1.00
07/07/2025 02:00	0	1.7	9.3	14.3	7.8	766,462.7	0.00	1.00
07/07/2025 03:00	0	1.7	9.3	14.3	8.1	798,830.9	0.00	1.00
07/07/2025 04:00	0	1.7	9.2	14.3	7.3	768,122.6	0.00	1.00
07/07/2025 05:00	0	1.7	9.1	14.3	7.1	768,537.6	0.00	1.00
07/07/2025 06:00	0	1.7	9.0	14.3	7.3	768,122.6	0.00	1.00
07/07/2025 07:00	0	1.7	8.9	14.3	7.7	767,707.6	0.00	1.00
07/07/2025 08:00	0	1.7	8.8	14.3	7.6	766,877.7	0.00	1.00
07/07/2025 09:00	0	1.7	8.8	14.3	7.7	765,010.3	0.00	1.00
07/07/2025 10:00	0	1.7	8.7	14.4	7.5	776,358.3	0.00	1.00
07/07/2025 11:00	0	1.7	8.7	14.4	7.6	774,883.5	0.00	1.00
07/07/2025 12:00	0	1.6	8.6	14.4	7.6	789,420.5	0.00	1.00
07/07/2025 13:00	0	1.7	8.2	14.3	7.4	802,358.2	0.00	1.00
07/07/2025 14:00	0	1.7	8.4	14.4	9.2	876,010.2	0.00	1.00
07/07/2025 15:00	0	1.7	8.4	14.3	7.5	769,990.0	0.00	1.00
07/07/2025 16:00	0	1.6	8.6	14.5	9.1	838,130.5	0.00	1.00
07/07/2025 17:00	0	1.7	8.4	14.4	8.8	878,117.1	0.00	1.00
07/07/2025 18:00	0	1.7	8.3	14.4	10.3	948,063.0	0.00	1.00
07/07/2025 19:00	0	1.7	8.3	14.4	10.4	948,484.4	0.00	1.00
07/07/2025 20:00	0	1.7	8.4	14.4	10.3	947,220.3	0.00	1.00
07/07/2025 21:00	0	1.7	8.7	14.3	9.3	890,955.8	0.00	1.00
07/07/2025 22:00	0	1.7	8.7	14.3	8.2	851,948.0	0.00	1.00
07/07/2025 23:00	0	1.7	8.6	14.3	9.5	935,565.8	0.00	1.00
Average/Sum#:	0	1.7	8.7	14.3	8.4	824,479.0	0.00 #	24.00 #
Minimum:	0	1.6	8.2	14.3	7.1	765,010.3	0.00	1.00
Maximum:	0	1.8	9.3	14.5	10.4	948,484.4	0.00	1.00
%SI	4.17	4.17	4.17	4.17	0.00	4.17	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/08/2025 00:00	0	1.7	8.7	14.3	9.1	937,225.7	0.00	1.00
07/08/2025 01:00	0	1.7	8.8	14.3	8.5	934,320.9	0.00	1.00
07/08/2025 02:00	-1	1.7	9.0	14.3	7.7	934,943.4	0.00	1.00
07/08/2025 03:00	0	1.7	9.1	14.2	4.4	767,490.8	0.00	1.00
07/08/2025 04:00	-1	1.7	8.8	14.3	5.5	876,846.6	0.00	1.00
07/08/2025 05:00	-1	1.7	9.1	14.3	5.4	832,651.5	0.00	1.00
07/08/2025 06:00	-1	1.7	8.8	14.2	5.7	758,088.8	0.00	1.00
07/08/2025 07:00	0	1.7	8.7	14.3	6.8	768,330.1	0.00	1.00
07/08/2025 08:00	0	1.7	8.7	14.3	8.2	767,292.6	0.00	1.00
07/08/2025 09:00	0	1.7	8.7	14.3	7.8	766,877.7	0.00	1.00
07/08/2025 10:00	0	1.6	8.7	14.4	8.5	777,622.4	0.00	1.00
07/08/2025 11:00	-1	1.7	8.7	14.4	6.6	776,779.6	0.00	1.00
07/08/2025 12:00	0	1.7	8.6	14.4	6.8	776,358.3	0.00	1.00
07/08/2025 13:00	0	1.7	8.6	14.4	6.7	775,726.2	0.00	1.00
07/08/2025 14:00	0	1.7	8.6	14.4	7.5	775,094.2	0.00	1.00
07/08/2025 15:00	0	1.7	8.6	14.4	7.9	774,883.5	0.00	1.00
07/08/2025 16:00	0	1.7	8.7	14.4	8.1	774,462.2	0.00	1.00
07/08/2025 17:00	0	1.7	8.8	14.5	8.4	804,536.8	0.00	1.00
07/08/2025 18:00	0	1.6	8.8	14.5	9.5	908,527.5	0.00	1.00
07/08/2025 19:00	0	1.7	8.9	14.3	8.9	857,757.6	0.00	1.00
07/08/2025 20:00	0	1.7	8.9	14.3	8.3	780,364.4	0.00	1.00
07/08/2025 21:00	0	1.7	8.8	14.3	7.7	766,462.7	0.00	1.00
07/08/2025 22:00	0	1.7	8.8	14.3	7.5	773,309.8	0.00	1.00
07/08/2025 23:00	0	1.7	8.7	14.3	7.2	794,681.1	0.00	1.00
Average/Sum#:	0	1.7	8.8	14.3	7.4	810,859.8	0.00 #	24.00 #
Minimum:	-1	1.6	8.6	14.2	4.4	758,088.8	0.00	1.00
Maximum:	0	1.7	9.1	14.5	9.5	937,225.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/09/2025 00:00	-1	1.7	8.7	14.3	5.7	769,782.5	0.00	1.00
07/09/2025 01:00	-1	1.7	8.7	14.2	4.3	758,906.4	0.00	1.00
07/09/2025 02:00	-1	1.7	8.9	14.2	3.7	759,519.6	0.00	1.00
07/09/2025 03:00	-1	1.7	8.9	14.2	3.6	759,519.6	0.00	1.00
07/09/2025 04:00	-1	1.7	8.9	14.2	3.1	759,928.3	0.00	1.00
07/09/2025 05:00	-1	1.7	9.0	14.2	4.2	765,242.5	0.00	1.00
07/09/2025 06:00	-1	1.7	8.8	14.2	4.8	759,519.6	0.00	1.00
07/09/2025 07:00	-1	1.7	8.7	14.2	6.7	758,702.0	0.00	1.00
07/09/2025 08:00	0	1.4	8.6	14.3	8.4	769,367.5	0.00	1.00
07/09/2025 09:00	0	1.8	8.6	14.3	6.3	768,537.6	0.00	1.00
07/09/2025 10:00	0	1.7	8.6	14.3	7.6	766,670.2	0.00	1.00
07/09/2025 11:00	-1	1.7	8.6	14.3	6.4	765,217.7	0.00	1.00
07/09/2025 12:00	0	1.7	8.6	14.4	7.0	776,147.6	0.00	1.00
07/09/2025 13:00	-1	1.7	8.6	14.4	6.8	774,883.5	0.00	1.00
07/09/2025 14:00	0	1.7	8.6	14.4	7.8	773,830.1	0.00	1.00
07/09/2025 15:00	0	1.6	8.6	14.4	7.8	773,198.1	0.00	1.00
07/09/2025 16:00	0	1.6	8.6	14.5	8.6	817,375.2	0.00	1.00
07/09/2025 17:00	0	1.7	8.1	14.3	6.1	802,773.2	0.00	1.00
07/09/2025 18:00	0	1.7	8.2	14.4	8.6	909,087.1	0.00	1.00
07/09/2025 19:00	0	1.6	8.4	14.4	8.9	930,997.9	0.00	1.00
07/09/2025 20:00	0	1.7	8.4	14.3	7.2	841,158.6	0.00	1.00
07/09/2025 21:00	0	1.7	8.3	14.3	8.7	904,442.6	0.00	1.00
07/09/2025 22:00	0	1.7	8.3	14.3	7.8	862,322.4	0.00	1.00
07/09/2025 23:00	0	1.7	8.4	14.3	8.4	886,183.6	0.00	1.00
Average/Sum#:	0	1.7	8.6	14.3	6.6	800,554.7	0.00 #	24.00 #
Minimum:	-1	1.4	8.1	14.2	3.1	758,702.0	0.00	1.00
Maximum:	0	1.8	9.0	14.5	8.9	930,997.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/10/2025 00:00	0	1.7	8.4	14.2	6.5	761,563.5	0.00	1.00
07/10/2025 01:00	0	1.7	8.4	14.2	6.7	758,293.2	0.00	1.00
07/10/2025 02:00	-1	1.3	8.8	14.3	7.9	767,500.1	0.00	1.00
07/10/2025 03:00	0	1.7	8.7	14.3	6.1	783,891.7	0.00	1.00
07/10/2025 04:00	-1	1.7	8.9	14.3	5.9	801,735.7	0.00	1.00
07/10/2025 05:00	-1	1.7	8.8	14.3	5.8	786,589.1	0.00	1.00
07/10/2025 06:00	-1	1.7	8.6	14.3	5.8	767,707.6	0.00	1.00
07/10/2025 07:00	0	1.7	8.5	14.3	6.3	766,255.2	0.00	1.00
07/10/2025 08:00	0	1.7	8.5	14.3	6.4	765,425.2	0.00	1.00
07/10/2025 09:00	0	1.7	8.5	14.4	6.5	775,304.9	0.00	1.00
07/10/2025 10:00	0	1.7	8.5	14.4	6.6	774,462.2	0.00	1.00
07/10/2025 11:00	0	1.7	8.5	14.4	6.5	773,408.8	0.00	1.00
07/10/2025 12:00	-1	1.6	8.3	14.4	5.1	772,776.7	0.00	1.00
07/10/2025 13:00	0	1.6	8.1	14.5	5.9	783,139.6	0.00	1.00
07/10/2025 14:00	0	1.6	8.0	14.5	7.5	814,807.5	0.00	1.00
07/10/2025 15:00	0	1.7	8.2	14.4	7.9	826,289.6	0.00	1.00
07/10/2025 16:00	0	1.6	8.3	14.4	6.6	777,833.1	0.00	1.00
07/10/2025 17:00	0	1.7	7.9	14.5	8.3	948,112.4	0.00	1.00
07/10/2025 18:00	0	1.7	7.9	14.4	8.0	933,526.1	0.00	1.00
07/10/2025 19:00	0	1.7	8.0	14.4	9.0	935,422.2	0.00	1.00
07/10/2025 20:00	0	1.7	8.1	14.4	8.1	912,668.7	0.00	1.00
07/10/2025 21:00	0	1.7	7.9	14.4	8.8	932,472.7	0.00	1.00
07/10/2025 22:00	0	1.7	8.1	14.4	9.1	930,155.2	0.00	1.00
07/10/2025 23:00	0	1.7	8.3	14.3	8.4	886,183.6	0.00	1.00
Average/Sum#:	0	1.7	8.3	14.4	7.1	822,313.5	0.00 #	24.00 #
Minimum:	-1	1.3	7.9	14.2	5.1	758,293.2	0.00	1.00
Maximum:	0	1.7	8.9	14.5	9.1	948,112.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/11/2025 00:00	0	1.7	8.5	14.4	7.0	777,622.4	0.00	1.00
07/11/2025 01:00	0	1.7	8.5	14.4	7.0	778,254.4	0.00	1.00
07/11/2025 02:00	0	1.8	8.8	14.4	6.7	779,729.2	0.00	1.00
07/11/2025 03:00	0	1.7	8.7	14.4	8.3	850,939.2	0.00	1.00
07/11/2025 04:00	0	1.6	8.7	14.5	9.3	923,505.6	0.00	1.00
07/11/2025 05:00	0	1.7	8.8	14.4	8.0	843,354.7	0.00	1.00
07/11/2025 06:00	0	1.7	8.6	14.3	6.4	771,027.4	0.00	1.00
07/11/2025 07:00	0	1.7	8.5	14.4	7.1	776,569.0	0.00	1.00
07/11/2025 08:00	0	1.7	8.5	14.4	7.0	776,569.0	0.00	1.00
07/11/2025 09:00	0	1.7	8.4	14.4	7.2	775,094.2	0.00	1.00
07/11/2025 10:00	0	1.6	8.1	14.5	7.5	865,305.0	0.00	1.00
07/11/2025 11:00	0	1.7	7.8	14.4	8.1	935,211.5	0.00	1.00
07/11/2025 12:00	0	1.7	7.8	14.4	7.8	897,921.0	0.00	1.00
07/11/2025 13:00	0	1.7	7.7	14.5	9.6	955,601.5	0.00	1.00
07/11/2025 14:00	0	1.6	7.7	14.5	10.0	956,029.4	0.00	1.00
07/11/2025 15:00	0	1.6	7.7	14.5	9.9	950,038.2	0.00	1.00
07/11/2025 16:00	0	1.6	7.7	14.4	8.7	897,289.0	0.00	1.00
07/11/2025 17:00	0	1.7	8.3	14.3	11.3	947,600.2	0.00	1.00
07/11/2025 18:00	1	2.3	13.9	12.2	28.8	998,578.0	0.00	1.00
07/11/2025 19:00	2	2.3	14.3	11.8	33.9	999,980.8	0.00	1.00
07/11/2025 20:00	1	2.0	12.6	12.9	21.6	1,002,761.0	0.00	1.00
07/11/2025 21:00	1	2.2	13.7	12.4	25.7	996,457.6	0.00	1.00
07/11/2025 22:00	0	1.8	10.7	13.6	16.4	1,004,369.6	0.00	1.00
07/11/2025 23:00	0	1.9	12.2	13.2	19.4	1,007,860.8	0.00	1.00
Average/Sum#:	0	1.8	9.4	14.0	12.2	894,486.2	0.00 #	24.00 #
Minimum:	0	1.6	7.7	11.8	6.4	771,027.4	0.00	1.00
Maximum:	2	2.3	14.3	14.5	33.9	1,007,860.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/12/2025 00:00	0	1.6	8.6	14.3	7.3	834,311.4	0.00	1.00
07/12/2025 01:00	0	1.7	8.4	14.3	6.6	765,425.2	0.00	1.00
07/12/2025 02:00	0	1.7	8.6	14.3	6.7	766,255.2	0.00	1.00
07/12/2025 03:00	0	1.7	8.6	14.3	6.5	766,462.7	0.00	1.00
07/12/2025 04:00	0	1.7	8.5	14.3	6.4	767,292.6	0.00	1.00
07/12/2025 05:00	0	1.7	8.5	14.3	6.3	767,085.1	0.00	1.00
07/12/2025 06:00	0	1.7	8.5	14.3	6.1	766,462.7	0.00	1.00
07/12/2025 07:00	0	1.7	8.5	14.3	6.1	765,840.2	0.00	1.00
07/12/2025 08:00	0	1.7	8.4	14.3	6.6	765,425.2	0.00	1.00
07/12/2025 09:00	0	1.7	8.4	14.4	6.8	776,147.6	0.00	1.00
07/12/2025 10:00	0	1.7	8.3	14.4	6.8	775,515.6	0.00	1.00
07/12/2025 11:00	0	1.7	8.3	14.4	6.5	774,251.5	0.00	1.00
07/12/2025 12:00	0	1.6	8.2	14.4	6.6	772,987.4	0.00	1.00
07/12/2025 13:00	0	1.6	7.8	14.5	5.8	784,637.4	0.00	1.00
07/12/2025 14:00	0	1.6	7.7	14.5	8.4	917,728.3	0.00	1.00
07/12/2025 15:00	0	1.7	7.8	14.4	7.4	863,369.4	0.00	1.00
07/12/2025 16:00	0	1.5	7.8	14.4	7.6	852,624.7	0.00	1.00
07/12/2025 17:00	0	1.7	7.7	14.4	6.4	843,986.8	0.00	1.00
07/12/2025 18:00	0	1.7	7.9	14.4	7.7	887,597.7	0.00	1.00
07/12/2025 19:00	0	1.7	8.0	14.4	9.1	939,846.5	0.00	1.00
07/12/2025 20:00	0	1.6	8.1	14.3	7.2	827,049.3	0.00	1.00
07/12/2025 21:00	0	1.7	8.2	14.2	6.5	766,673.3	0.00	1.00
07/12/2025 22:00	0	1.7	8.3	14.2	6.5	783,637.8	0.00	1.00
07/12/2025 23:00	0	1.7	8.2	14.4	9.0	949,327.1	0.00	1.00
Average/Sum#:	0	1.7	8.2	14.4	7.0	811,664.2	0.00 #	24.00 #
Minimum:	0	1.5	7.7	14.2	5.8	765,425.2	0.00	1.00
Maximum:	0	1.7	8.6	14.5	9.1	949,327.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/13/2025 00:00	0	1.7	8.6	14.3	7.9	868,962.0	0.00	1.00
07/13/2025 01:00	0	1.7	8.6	14.4	8.7	897,499.7	0.00	1.00
07/13/2025 02:00	0	1.6	8.8	14.4	9.6	951,012.6	0.00	1.00
07/13/2025 03:00	-1	1.5	9.0	14.3	7.0	818,334.8	0.00	1.00
07/13/2025 04:00	-1	1.7	8.7	14.3	5.6	795,926.1	0.00	1.00
07/13/2025 05:00	-1	1.7	8.7	14.3	5.9	799,660.8	0.00	1.00
07/13/2025 06:00	0	1.7	8.6	14.3	6.1	767,707.6	0.00	1.00
07/13/2025 07:00	0	1.7	8.5	14.3	6.9	766,877.7	0.00	1.00
07/13/2025 08:00	0	1.7	8.6	14.3	7.4	766,462.7	0.00	1.00
07/13/2025 09:00	0	1.7	8.5	14.3	7.0	764,802.8	0.00	1.00
07/13/2025 10:00	0	1.6	8.5	14.4	6.9	776,147.6	0.00	1.00
07/13/2025 11:00	0	1.7	8.3	14.4	6.3	775,304.9	0.00	1.00
07/13/2025 12:00	0	1.7	8.2	14.4	7.0	793,002.1	0.00	1.00
07/13/2025 13:00	0	1.6	7.8	14.5	8.0	953,461.7	0.00	1.00
07/13/2025 14:00	0	1.6	7.7	14.5	8.8	965,230.2	0.00	1.00
07/13/2025 15:00	0	1.6	7.7	14.5	8.5	965,658.2	0.00	1.00
07/13/2025 16:00	0	1.6	7.6	14.5	7.8	965,444.2	0.00	1.00
07/13/2025 17:00	0	1.6	7.7	14.4	6.6	888,229.7	0.00	0.92
07/13/2025 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2025 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2025 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2025 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2025 22:00	0	1.7	8.3	14.3	5.9	825,181.9	0.00	0.28
07/13/2025 23:00	0	1.7	8.4	14.4	9.2	932,051.3	0.00	1.00
Average/Sum#:	0	1.7	8.3	14.4	7.4	851,847.9	0.00 #	19.20 #
Minimum:	-1	1.5	7.6	14.3	5.6	764,802.8	0.00	0.00
Maximum:	0	1.7	9.0	14.5	9.6	965,658.2	0.00	1.00
%SI	16.67	16.67	16.67	16.67	16.67	16.67	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/14/2025 00:00	0	1.7	8.3	14.4	9.3	949,327.1	0.00	0.50
07/14/2025 01:00	-1	1.7	8.5	14.2	6.0	760,950.3	0.00	0.02
07/14/2025 02:00	-1	1.7	8.6	14.2	5.8	758,497.6	0.00	0.48
07/14/2025 03:00	0	1.7	8.7	14.2	6.3	762,994.2	0.00	1.00
07/14/2025 04:00	0	1.9	9.0	14.4	7.4	875,799.6	0.00	1.00
07/14/2025 05:00	0	1.7	9.3	14.4	8.4	881,698.6	0.00	1.00
07/14/2025 06:00	0	1.7	8.9	14.3	7.4	816,259.9	0.00	1.00
07/14/2025 07:00	0	1.7	8.8	14.3	6.8	766,047.7	0.00	1.00
07/14/2025 08:00	0	1.7	8.8	14.4	7.3	777,833.1	0.00	1.00
07/14/2025 09:00	0	1.7	8.7	14.4	7.7	776,569.0	0.00	1.00
07/14/2025 10:00	0	1.7	8.7	14.4	7.2	774,883.5	0.00	1.00
07/14/2025 11:00	-1	1.7	8.5	14.5	6.7	786,135.2	0.00	1.00
07/14/2025 12:00	-1	1.6	8.3	14.5	6.6	784,423.4	0.00	1.00
07/14/2025 13:00	-1	1.6	7.7	14.5	6.1	782,925.6	0.00	1.00
07/14/2025 14:00	-1	1.6	7.7	14.5	7.9	813,309.7	0.00	1.00
07/14/2025 15:00	-1	1.6	8.0	14.4	6.3	779,729.2	0.00	1.00
07/14/2025 16:00	-1	1.6	7.7	14.5	6.7	794,908.1	0.00	1.00
07/14/2025 17:00	-1	1.6	8.1	14.5	7.3	821,868.6	0.00	1.00
07/14/2025 18:00	-1	1.6	8.2	14.4	6.5	796,162.3	0.00	1.00
07/14/2025 19:00	-1	1.7	8.2	14.4	6.8	773,830.1	0.00	1.00
07/14/2025 20:00	-1	1.7	8.5	14.4	7.7	775,304.9	0.00	1.00
07/14/2025 21:00	-1	1.7	8.7	14.4	7.4	777,411.7	0.00	1.00
07/14/2025 22:00	-1	1.7	8.7	14.3	7.1	767,292.6	0.00	1.00
07/14/2025 23:00	-2	1.7	8.7	14.3	6.4	769,782.5	0.00	1.00
Average/Sum#:	-1	1.7	8.5	14.4	7.0	796,831.0	0.00 #	22.00 #
Minimum:	-2	1.6	7.7	14.2	5.8	758,497.6	0.00	0.02
Maximum:	0	1.9	9.3	14.5	9.3	949,327.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/15/2025 00:00	-2	1.7	8.7	14.3	6.0	770,819.9	0.00	1.00
07/15/2025 01:00	-2	1.7	8.7	14.3	5.6	771,649.9	0.00	1.00
07/15/2025 02:00	-2	1.7	9.0	14.3	4.9	771,649.9	0.00	1.00
07/15/2025 03:00	-2	1.7	8.9	14.2	4.1	761,767.9	0.00	1.00
07/15/2025 04:00	-3	1.7	8.9	14.2	3.5	760,950.3	0.00	1.00
07/15/2025 05:00	-3	1.7	8.9	14.2	4.2	761,563.5	0.00	1.00
07/15/2025 06:00	-1	1.5	8.8	14.2	5.9	760,950.3	0.00	1.00
07/15/2025 07:00	-2	1.7	8.8	14.3	5.5	771,442.4	0.00	1.00
07/15/2025 08:00	-1	1.7	8.7	14.3	6.9	768,330.1	0.00	1.00
07/15/2025 09:00	-1	1.7	8.7	14.3	7.0	766,877.7	0.00	1.00
07/15/2025 10:00	-1	1.7	8.6	14.3	6.8	765,010.3	0.00	1.00
07/15/2025 11:00	-2	1.7	8.6	14.4	6.4	775,304.9	0.00	1.00
07/15/2025 12:00	-2	1.7	8.6	14.4	6.1	774,462.2	0.00	1.00
07/15/2025 13:00	-2	1.7	8.5	14.4	5.7	774,251.5	0.00	1.00
07/15/2025 14:00	-2	1.7	8.4	14.4	6.0	772,987.4	0.00	1.00
07/15/2025 15:00	-1	1.7	8.5	14.4	6.6	772,776.7	0.00	1.00
07/15/2025 16:00	-1	1.7	8.5	14.4	6.7	772,355.4	0.00	1.00
07/15/2025 17:00	-1	1.7	8.3	14.4	7.2	822,918.7	0.00	1.00
07/15/2025 18:00	-1	1.7	8.7	14.3	6.9	769,160.0	0.00	1.00
07/15/2025 19:00	-1	1.7	8.7	14.4	6.7	774,462.2	0.00	1.00
07/15/2025 20:00	-1	1.7	8.7	14.3	6.7	765,217.7	0.00	1.00
07/15/2025 21:00	-1	1.7	8.7	14.3	6.9	777,874.5	0.00	1.00
07/15/2025 22:00	-2	1.7	8.6	14.3	5.9	766,047.7	0.00	1.00
07/15/2025 23:00	-2	1.7	8.7	14.3	5.2	766,877.7	0.00	1.00
Average/Sum#:	-2	1.7	8.7	14.3	6.0	771,487.9	0.00 #	24.00 #
Minimum:	-3	1.5	8.3	14.2	3.5	760,950.3	0.00	1.00
Maximum:	-1	1.7	9.0	14.4	7.2	822,918.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/16/2025 00:00	-3	1.7	8.7	14.3	4.0	767,500.1	0.00	1.00
07/16/2025 01:00	-3	1.7	8.7	14.2	3.4	756,453.7	0.00	1.00
07/16/2025 02:00	-3	1.7	9.0	14.2	3.0	756,658.1	0.00	1.00
07/16/2025 03:00	-3	1.7	8.9	14.2	2.6	757,271.2	0.00	1.00
07/16/2025 04:00	-3	1.7	8.9	14.2	2.6	775,666.5	0.00	1.00
07/16/2025 05:00	-2	1.7	8.9	14.3	6.0	908,592.3	0.00	1.00
07/16/2025 06:00	-2	1.7	8.7	14.2	4.5	757,475.6	0.00	1.00
07/16/2025 07:00	-2	1.7	8.7	14.2	5.8	757,066.9	0.00	1.00
07/16/2025 08:00	-1	1.7	8.5	14.3	6.9	767,292.6	0.00	1.00
07/16/2025 09:00	-1	1.7	8.5	14.3	6.3	766,462.7	0.00	1.00
07/16/2025 10:00	-1	1.7	8.5	14.3	6.6	766,047.7	0.00	1.00
07/16/2025 11:00	-2	1.7	8.4	14.3	5.7	800,075.8	0.00	1.00
07/16/2025 12:00	-1	1.7	8.6	14.4	7.3	820,179.9	0.00	1.00
07/16/2025 13:00	-2	1.6	8.8	14.5	7.4	895,903.1	0.00	1.00
07/16/2025 14:00	-2	1.6	8.9	14.4	7.0	824,604.2	0.00	1.00
07/16/2025 15:00	-1	1.7	8.6	14.5	7.8	834,065.0	0.00	1.00
07/16/2025 16:00	-1	1.7	8.6	14.4	6.8	774,040.8	0.00	1.00
07/16/2025 17:00	-1	1.7	8.5	14.4	7.4	783,521.4	0.00	1.00
07/16/2025 18:00	-1	1.7	8.6	14.4	7.5	776,569.0	0.00	1.00
07/16/2025 19:00	-1	1.7	8.6	14.3	7.4	765,010.3	0.00	1.00
07/16/2025 20:00	-1	1.7	8.7	14.3	7.1	766,047.7	0.00	1.00
07/16/2025 21:00	-1	1.7	8.7	14.3	6.9	766,877.7	0.00	1.00
07/16/2025 22:00	-2	1.7	8.7	14.3	6.3	766,877.7	0.00	1.00
07/16/2025 23:00	-2	1.7	8.7	14.3	5.5	766,255.2	0.00	1.00
Average/Sum#:	-2	1.7	8.7	14.3	5.9	786,521.5	0.00 #	24.00 #
Minimum:	-3	1.6	8.4	14.2	2.6	756,453.7	0.00	1.00
Maximum:	-1	1.7	9.0	14.5	7.8	908,592.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/17/2025 00:00	-2	1.7	8.8	14.2	4.5	754,818.5	0.00	1.00
07/17/2025 01:00	-3	1.7	8.8	14.2	4.2	760,745.9	0.00	1.00
07/17/2025 02:00	-3	1.7	9.1	14.2	3.3	755,227.3	0.00	1.00
07/17/2025 03:00	-3	1.7	9.0	14.2	2.8	755,840.5	0.00	1.00
07/17/2025 04:00	-3	1.7	8.9	14.2	2.5	756,249.3	0.00	1.00
07/17/2025 05:00	-3	1.7	8.9	14.2	2.7	755,636.1	0.00	1.00
07/17/2025 06:00	-3	1.7	8.9	14.2	3.4	755,431.7	0.00	1.00
07/17/2025 07:00	-2	1.7	8.9	14.2	4.6	755,022.9	0.00	1.00
07/17/2025 08:00	-1	1.7	8.8	14.2	6.5	754,818.5	0.00	1.00
07/17/2025 09:00	-2	1.7	8.8	14.3	6.3	768,537.6	0.00	1.00
07/17/2025 10:00	-1	1.7	8.6	14.3	6.9	765,425.2	0.00	1.00
07/17/2025 11:00	-2	1.7	8.6	14.3	5.4	762,312.9	0.00	1.00
07/17/2025 12:00	-2	1.7	8.5	14.4	6.7	808,171.1	0.00	1.00
07/17/2025 13:00	-1	1.6	8.4	14.5	7.8	902,964.2	0.00	1.00
07/17/2025 14:00	-1	1.7	8.2	14.4	8.6	927,205.6	0.00	1.00
07/17/2025 15:00	-1	1.7	8.2	14.4	9.4	946,377.6	0.00	1.00
07/17/2025 16:00	-1	1.6	8.9	14.4	7.7	773,198.1	0.00	1.00
07/17/2025 17:00	-1	1.6	8.5	14.5	8.0	833,851.1	0.00	1.00
07/17/2025 18:00	-1	1.7	9.0	14.4	8.4	774,462.2	0.00	1.00
07/17/2025 19:00	-1	1.7	9.0	14.4	8.5	773,830.1	0.00	1.00
07/17/2025 20:00	-1	1.7	8.9	14.4	7.9	775,515.6	0.00	1.00
07/17/2025 21:00	-1	1.7	8.7	14.3	7.6	764,595.3	0.00	1.00
07/17/2025 22:00	-1	1.7	8.6	14.3	7.3	773,517.3	0.00	1.00
07/17/2025 23:00	-1	1.7	8.7	14.4	8.3	877,063.6	0.00	1.00
Average/Sum#:	-2	1.7	8.7	14.3	6.2	792,950.8	0.00 #	24.00 #
Minimum:	-3	1.6	8.2	14.2	2.5	754,818.5	0.00	1.00
Maximum:	-1	1.7	9.1	14.5	9.4	946,377.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/18/2025 00:00	-2	1.7	8.6	14.3	6.0	772,479.8	0.00	1.00
07/18/2025 01:00	-2	1.7	8.6	14.3	5.6	767,915.1	0.00	1.00
07/18/2025 02:00	-2	1.7	8.8	14.3	4.9	767,707.6	0.00	1.00
07/18/2025 03:00	-2	1.7	8.8	14.2	4.2	757,066.9	0.00	1.00
07/18/2025 04:00	-3	1.7	8.8	14.2	4.2	776,892.8	0.00	1.00
07/18/2025 05:00	-3	1.7	8.9	14.2	4.6	802,441.8	0.00	1.00
07/18/2025 06:00	-2	1.7	8.8	14.2	5.1	768,512.8	0.00	1.00
07/18/2025 07:00	-2	1.7	8.6	14.2	5.8	762,381.0	0.00	1.00
07/18/2025 08:00	-1	1.7	8.6	14.3	6.6	773,102.3	0.00	1.00
07/18/2025 09:00	-2	1.7	8.6	14.3	5.9	771,857.4	0.00	1.00
07/18/2025 10:00	-1	1.7	8.6	14.3	6.5	769,367.5	0.00	1.00
07/18/2025 11:00	-2	1.7	8.6	14.4	5.6	778,043.7	0.00	1.00
07/18/2025 12:00	-2	1.7	8.5	14.4	5.5	774,672.8	0.00	1.00
07/18/2025 13:00	-2	1.7	8.6	14.4	6.4	772,987.4	0.00	1.00
07/18/2025 14:00	-1	1.7	8.6	14.4	7.5	772,144.7	0.00	1.00
07/18/2025 15:00	-1	1.7	8.3	14.4	6.6	771,512.6	0.00	1.00
07/18/2025 16:00	-1	1.7	8.3	14.4	6.5	771,512.6	0.00	1.00
07/18/2025 17:00	-1	1.6	8.3	14.4	6.4	789,631.2	0.00	1.00
07/18/2025 18:00	-2	1.7	8.3	14.3	5.9	763,972.8	0.00	1.00
07/18/2025 19:00	-1	1.7	8.6	14.4	6.7	773,198.1	0.00	1.00
07/18/2025 20:00	-1	1.7	8.5	14.3	6.5	763,142.9	0.00	1.00
07/18/2025 21:00	-2	1.7	8.5	14.3	6.2	765,217.7	0.00	1.00
07/18/2025 22:00	-2	1.7	8.5	14.3	5.7	774,139.8	0.00	1.00
07/18/2025 23:00	-2	1.7	8.6	14.4	7.7	900,659.9	0.00	1.00
Average/Sum#:	-2	1.7	8.6	14.3	5.9	777,523.4	0.00 #	24.00 #
Minimum:	-3	1.6	8.3	14.2	4.2	757,066.9	0.00	1.00
Maximum:	-1	1.7	8.9	14.4	7.7	900,659.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/19/2025 00:00	-2	1.7	8.6	14.3	5.0	768,537.6	0.00	1.00
07/19/2025 01:00	-2	1.7	8.6	14.2	4.5	757,271.2	0.00	1.00
07/19/2025 02:00	-3	1.7	8.9	14.2	3.9	756,453.7	0.00	1.00
07/19/2025 03:00	-3	1.7	8.9	14.2	3.3	756,658.1	0.00	1.00
07/19/2025 04:00	-3	1.7	8.8	14.2	2.7	756,862.5	0.00	1.00
07/19/2025 05:00	-3	1.7	8.8	14.2	2.8	757,475.6	0.00	1.00
07/19/2025 06:00	-3	1.7	8.8	14.2	3.2	757,066.9	0.00	1.00
07/19/2025 07:00	-2	1.7	8.7	14.2	4.8	756,249.3	0.00	1.00
07/19/2025 08:00	-1	1.7	8.6	14.3	6.5	767,292.6	0.00	1.00
07/19/2025 09:00	-2	1.7	8.6	14.3	6.0	765,840.2	0.00	1.00
07/19/2025 10:00	-2	1.7	8.6	14.3	6.1	765,010.3	0.00	1.00
07/19/2025 11:00	-2	1.7	8.5	14.4	4.7	775,936.9	0.00	1.00
07/19/2025 12:00	-2	1.7	8.5	14.4	5.3	774,462.2	0.00	1.00
07/19/2025 13:00	-2	1.7	8.6	14.4	6.1	772,987.4	0.00	1.00
07/19/2025 14:00	-1	1.7	8.5	14.5	7.1	784,209.4	0.00	1.00
07/19/2025 15:00	-1	1.6	8.4	14.5	6.8	784,423.4	0.00	1.00
07/19/2025 16:00	-2	1.6	8.4	14.5	6.5	784,209.4	0.00	1.00
07/19/2025 17:00	-2	1.6	8.4	14.5	6.4	800,685.3	0.00	1.00
07/19/2025 18:00	-1	1.6	8.7	14.4	7.1	774,251.5	0.00	1.00
07/19/2025 19:00	-1	1.7	8.6	14.4	7.0	773,408.8	0.00	1.00
07/19/2025 20:00	-1	1.7	8.5	14.3	6.5	763,557.8	0.00	1.00
07/19/2025 21:00	-2	1.7	8.6	14.3	6.2	764,180.3	0.00	1.00
07/19/2025 22:00	-2	1.7	8.6	14.3	5.9	764,802.8	0.00	1.00
07/19/2025 23:00	-2	1.7	8.7	14.3	5.6	764,802.8	0.00	1.00
Average/Sum#:	-2	1.7	8.6	14.3	5.4	768,609.8	0.00 #	24.00 #
Minimum:	-3	1.6	8.4	14.2	2.7	756,249.3	0.00	1.00
Maximum:	-1	1.7	8.9	14.5	7.1	800,685.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/20/2025 00:00	-2	1.7	8.7	14.3	5.2	765,425.2	0.00	1.00
07/20/2025 01:00	-2	1.7	8.8	14.3	4.3	765,840.2	0.00	1.00
07/20/2025 02:00	-3	1.7	9.1	14.3	3.9	765,632.7	0.00	1.00
07/20/2025 03:00	-2	1.7	9.0	14.2	3.3	755,431.7	0.00	1.00
07/20/2025 04:00	-3	1.7	8.9	14.2	2.9	755,840.5	0.00	1.00
07/20/2025 05:00	-3	1.7	8.9	14.2	3.3	755,840.5	0.00	1.00
07/20/2025 06:00	-3	1.7	8.8	14.2	4.2	756,249.3	0.00	1.00
07/20/2025 07:00	-2	1.7	8.7	14.2	5.3	756,044.9	0.00	1.00
07/20/2025 08:00	-1	1.7	8.7	14.3	6.6	766,670.2	0.00	1.00
07/20/2025 09:00	-2	1.7	8.6	14.3	6.1	765,632.7	0.00	1.00
07/20/2025 10:00	-1	1.7	8.6	14.3	6.7	764,387.8	0.00	1.00
07/20/2025 11:00	-2	1.7	8.6	14.3	5.3	762,935.4	0.00	1.00
07/20/2025 12:00	-2	1.7	8.5	14.4	5.5	772,987.4	0.00	1.00
07/20/2025 13:00	-2	1.7	8.5	14.4	5.4	771,723.3	0.00	1.00
07/20/2025 14:00	-2	1.7	8.4	14.4	5.9	771,301.9	0.00	1.00
07/20/2025 15:00	-2	1.7	8.4	14.4	6.1	771,301.9	0.00	1.00
07/20/2025 16:00	-2	1.7	8.3	14.4	6.0	771,934.0	0.00	1.00
07/20/2025 17:00	-2	1.7	8.3	14.4	6.1	779,097.1	0.00	1.00
07/20/2025 18:00	-1	1.7	8.4	14.4	6.5	774,883.5	0.00	1.00
07/20/2025 19:00	-1	1.7	8.5	14.3	6.3	764,180.3	0.00	1.00
07/20/2025 20:00	-2	1.7	8.6	14.3	5.8	765,632.7	0.00	1.00
07/20/2025 21:00	-2	1.7	8.6	14.3	5.0	766,047.7	0.00	1.00
07/20/2025 22:00	-3	1.7	8.7	14.2	4.0	754,818.5	0.00	1.00
07/20/2025 23:00	-3	1.7	8.8	14.2	3.5	755,840.5	0.00	1.00
Average/Sum#:	-2	1.7	8.6	14.3	5.1	764,820.0	0.00 #	24.00 #
Minimum:	-3	1.7	8.3	14.2	2.9	754,818.5	0.00	1.00
Maximum:	-1	1.7	9.1	14.4	6.7	779,097.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/21/2025 00:00	-3	1.7	8.8	14.2	3.1	755,022.9	0.00	1.00
07/21/2025 01:00	-3	1.7	8.8	14.2	2.8	755,227.3	0.00	1.00
07/21/2025 02:00	-3	1.7	9.0	14.2	2.5	755,431.7	0.00	1.00
07/21/2025 03:00	-3	1.7	8.8	14.2	2.3	756,044.9	0.00	1.00
07/21/2025 04:00	-3	1.7	8.7	14.3	3.1	820,617.2	0.00	1.00
07/21/2025 05:00	-3	1.7	9.0	14.3	3.7	816,674.9	0.00	1.00
07/21/2025 06:00	-3	1.7	8.7	14.2	3.9	756,249.3	0.00	1.00
07/21/2025 07:00	-2	1.7	8.7	14.2	4.9	756,249.3	0.00	1.00
07/21/2025 08:00	-1	1.7	8.6	14.3	6.6	766,877.7	0.00	1.00
07/21/2025 09:00	-1	1.7	8.5	14.3	6.6	766,255.2	0.00	1.00
07/21/2025 10:00	-1	1.7	8.5	14.3	6.2	765,217.7	0.00	1.00
07/21/2025 11:00	-2	1.7	8.4	14.3	5.9	763,557.8	0.00	1.00
07/21/2025 12:00	-1	1.7	8.4	14.3	6.3	762,312.9	0.00	1.00
07/21/2025 13:00	-2	1.7	8.5	14.3	4.8	761,897.9	0.00	1.00
07/21/2025 14:00	-2	1.7	8.5	14.3	4.6	761,275.5	0.00	1.00
07/21/2025 15:00	-1	1.7	8.5	14.3	6.4	761,690.4	0.00	1.00
07/21/2025 16:00	-1	1.7	8.5	14.3	6.7	762,727.9	0.00	1.00
07/21/2025 17:00	-1	1.7	8.5	14.3	7.0	763,142.9	0.00	1.00
07/21/2025 18:00	-1	1.7	8.6	14.3	6.9	764,180.3	0.00	1.00
07/21/2025 19:00	-1	1.7	8.6	14.3	6.5	765,217.7	0.00	1.00
07/21/2025 20:00	-2	1.7	8.6	14.3	5.8	765,840.2	0.00	1.00
07/21/2025 21:00	-2	1.7	8.7	14.3	4.9	765,840.2	0.00	1.00
07/21/2025 22:00	-3	1.7	8.7	14.3	4.0	766,462.7	0.00	1.00
07/21/2025 23:00	-3	1.7	8.7	14.2	3.6	755,840.5	0.00	1.00
Average/Sum#:	-2	1.7	8.6	14.3	5.0	766,244.0	0.00 #	24.00 #
Minimum:	-3	1.7	8.4	14.2	2.3	755,022.9	0.00	1.00
Maximum:	-1	1.7	9.0	14.3	7.0	820,617.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/22/2025 00:00	-3	1.7	8.7	14.2	3.3	756,862.5	0.00	1.00
07/22/2025 01:00	-3	1.7	8.7	14.2	3.4	757,680.0	0.00	1.00
07/22/2025 02:00	-3	1.7	8.9	14.2	3.2	757,271.2	0.00	1.00
07/22/2025 03:00	-2	1.7	8.9	14.2	3.0	756,862.5	0.00	1.00
07/22/2025 04:00	-3	1.7	8.8	14.2	3.1	755,840.5	0.00	1.00
07/22/2025 05:00	-3	1.7	8.8	14.2	3.0	756,453.7	0.00	1.00
07/22/2025 06:00	-3	1.7	8.8	14.2	3.2	755,636.1	0.00	1.00
07/22/2025 07:00	-2	1.7	8.7	14.2	4.3	756,249.3	0.00	1.00
07/22/2025 08:00	-1	1.7	8.7	14.2	6.7	756,249.3	0.00	1.00
07/22/2025 09:00	-1	1.7	8.6	14.3	7.0	767,707.6	0.00	1.00
07/22/2025 10:00	-1	1.7	8.6	14.3	6.7	766,255.2	0.00	1.00
07/22/2025 11:00	-1	1.7	8.5	14.3	6.6	765,632.7	0.00	1.00
07/22/2025 12:00	-1	1.7	8.5	14.3	6.8	765,217.7	0.00	1.00
07/22/2025 13:00	-2	1.7	8.7	14.3	5.2	763,765.3	0.00	1.00
07/22/2025 14:00	-2	1.7	8.7	14.4	5.1	774,883.5	0.00	1.00
07/22/2025 15:00	-2	1.7	8.7	14.4	6.5	774,462.2	0.00	1.00
07/22/2025 16:00	-1	1.7	8.7	14.4	7.3	774,462.2	0.00	1.00
07/22/2025 17:00	-1	1.7	8.7	14.4	7.6	775,515.6	0.00	1.00
07/22/2025 18:00	-1	1.7	8.6	14.3	7.4	766,047.7	0.00	1.00
07/22/2025 19:00	-1	1.7	8.6	14.3	7.4	766,877.7	0.00	1.00
07/22/2025 20:00	-1	1.7	8.6	14.3	6.9	768,745.1	0.00	1.00
07/22/2025 21:00	-1	1.7	8.6	14.3	6.3	769,367.5	0.00	1.00
07/22/2025 22:00	-2	1.7	8.7	14.2	5.6	761,359.1	0.00	1.00
07/22/2025 23:00	-2	1.7	8.7	14.2	4.8	760,745.9	0.00	1.00
Average/Sum#:	-2	1.7	8.7	14.3	5.4	763,756.3	0.00 #	24.00 #
Minimum:	-3	1.7	8.5	14.2	3.0	755,636.1	0.00	1.00
Maximum:	-1	1.7	8.9	14.4	7.6	775,515.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/23/2025 00:00	-3	1.7	8.7	14.2	3.8	758,702.0	0.00	1.00
07/23/2025 01:00	-3	1.7	8.7	14.2	3.2	759,110.8	0.00	1.00
07/23/2025 02:00	-3	1.7	8.9	14.2	2.7	758,293.2	0.00	1.00
07/23/2025 03:00	-3	1.7	8.9	14.2	2.6	758,497.6	0.00	1.00
07/23/2025 04:00	-4	1.7	8.9	14.2	2.1	758,702.0	0.00	1.00
07/23/2025 05:00	-3	1.7	8.9	14.2	2.8	759,723.9	0.00	1.00
07/23/2025 06:00	-2	1.7	8.9	14.2	4.6	758,497.6	0.00	1.00
07/23/2025 07:00	-2	1.7	8.8	14.2	4.9	763,403.0	0.00	1.00
07/23/2025 08:00	-1	1.7	8.7	14.2	6.6	757,271.2	0.00	1.00
07/23/2025 09:00	-1	1.7	8.7	14.3	7.0	768,745.1	0.00	1.00
07/23/2025 10:00	-1	1.7	8.6	14.3	7.3	767,707.6	0.00	1.00
07/23/2025 11:00	-1	1.7	8.6	14.3	6.4	767,085.1	0.00	1.00
07/23/2025 12:00	-2	1.7	8.6	14.3	5.9	766,255.2	0.00	1.00
07/23/2025 13:00	-2	1.7	8.5	14.4	6.5	810,067.2	0.00	1.00
07/23/2025 14:00	-1	1.7	8.6	14.4	7.1	776,569.0	0.00	1.00
07/23/2025 15:00	-1	1.7	8.6	14.4	7.7	775,515.6	0.00	1.00
07/23/2025 16:00	-1	1.7	8.6	14.4	7.4	775,936.9	0.00	1.00
07/23/2025 17:00	-1	1.7	8.5	14.4	7.8	797,426.4	0.00	1.00
07/23/2025 18:00	-1	1.7	8.4	14.5	9.1	899,326.7	0.00	1.00
07/23/2025 19:00	-1	1.6	8.7	14.5	10.7	944,688.9	0.00	1.00
07/23/2025 20:00	-1	1.7	8.7	14.4	9.1	842,301.3	0.00	1.00
07/23/2025 21:00	0	1.7	8.4	14.4	10.7	946,588.3	0.00	1.00
07/23/2025 22:00	0	1.7	8.5	14.4	10.8	949,748.5	0.00	1.00
07/23/2025 23:00	-1	1.7	8.8	14.3	9.8	877,261.6	0.00	1.00
Average/Sum#:	-2	1.7	8.7	14.3	6.5	804,059.4	0.00 #	24.00 #
Minimum:	-4	1.6	8.4	14.2	2.1	757,271.2	0.00	1.00
Maximum:	0	1.7	8.9	14.5	10.8	949,748.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/24/2025 00:00	-1	1.7	8.7	14.3	7.7	774,554.7	0.00	1.00
07/24/2025 01:00	-1	1.7	8.6	14.2	7.8	758,906.4	0.00	1.00
07/24/2025 02:00	-1	1.7	8.9	14.2	7.7	758,702.0	0.00	1.00
07/24/2025 03:00	-1	1.7	8.9	14.2	8.0	759,315.2	0.00	1.00
07/24/2025 04:00	-1	1.7	8.9	14.2	8.1	770,147.9	0.00	1.00
07/24/2025 05:00	-1	1.7	9.0	14.3	9.2	829,746.7	0.00	1.00
07/24/2025 06:00	-1	1.7	8.8	14.2	7.6	759,519.6	0.00	1.00
07/24/2025 07:00	-1	1.7	8.8	14.2	7.5	758,906.4	0.00	1.00
07/24/2025 08:00	-1	1.7	8.7	14.3	7.2	769,782.5	0.00	1.00
07/24/2025 09:00	-1	1.7	8.6	14.3	7.7	768,745.1	0.00	1.00
07/24/2025 10:00	-1	1.7	8.7	14.3	7.8	767,500.1	0.00	1.00
07/24/2025 11:00	-1	1.7	8.6	14.3	7.2	766,047.7	0.00	1.00
07/24/2025 12:00	-2	1.6	8.6	14.4	6.8	776,569.0	0.00	1.00
07/24/2025 13:00	-2	1.7	8.5	14.4	6.1	775,936.9	0.00	1.00
07/24/2025 14:00	-1	1.7	8.5	14.4	7.0	775,515.6	0.00	1.00
07/24/2025 15:00	-1	1.7	8.6	14.4	7.6	775,094.2	0.00	1.00
07/24/2025 16:00	-1	1.6	8.5	14.4	7.4	774,883.5	0.00	1.00
07/24/2025 17:00	-1	1.6	8.4	14.4	7.5	810,699.2	0.00	1.00
07/24/2025 18:00	-1	1.7	8.2	14.3	6.7	768,330.1	0.00	1.00
07/24/2025 19:00	-1	1.7	8.4	14.4	7.6	776,358.3	0.00	1.00
07/24/2025 20:00	-1	1.7	8.5	14.3	7.7	766,047.7	0.00	1.00
07/24/2025 21:00	-1	1.7	8.5	14.3	7.8	767,292.6	0.00	1.00
07/24/2025 22:00	-1	1.7	8.5	14.3	7.8	767,707.6	0.00	1.00
07/24/2025 23:00	-1	1.7	8.5	14.3	7.7	767,707.6	0.00	1.00
Average/Sum#:	-1	1.7	8.6	14.3	7.6	772,667.4	0.00 #	24.00 #
Minimum:	-2	1.6	8.2	14.2	6.1	758,702.0	0.00	1.00
Maximum:	-1	1.7	9.0	14.4	9.2	829,746.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/25/2025 00:00	-1	1.7	8.6	14.3	7.9	767,915.1	0.00	1.00
07/25/2025 01:00	-1	1.7	8.7	14.3	7.7	768,745.1	0.00	1.00
07/25/2025 02:00	-1	1.7	8.9	14.2	7.6	757,680.0	0.00	1.00
07/25/2025 03:00	-1	1.7	8.8	14.2	7.5	757,884.4	0.00	1.00
07/25/2025 04:00	-1	1.7	8.8	14.2	7.8	758,497.6	0.00	1.00
07/25/2025 05:00	-1	1.7	8.8	14.2	7.6	758,906.4	0.00	1.00
07/25/2025 06:00	-1	1.7	8.8	14.2	7.4	758,906.4	0.00	1.00
07/25/2025 07:00	-1	1.7	8.7	14.2	7.4	757,884.4	0.00	1.00
07/25/2025 08:00	-1	1.7	8.7	14.3	6.9	769,160.0	0.00	1.00
07/25/2025 09:00	-1	1.7	8.5	14.3	7.4	768,745.1	0.00	1.00
07/25/2025 10:00	-1	1.7	8.5	14.3	7.7	767,707.6	0.00	1.00
07/25/2025 11:00	-1	1.7	8.4	14.3	6.8	766,462.7	0.00	1.00
07/25/2025 12:00	-1	1.7	8.4	14.4	6.6	776,779.6	0.00	1.00
07/25/2025 13:00	-2	1.7	8.4	14.4	5.9	775,515.6	0.00	1.00
07/25/2025 14:00	-2	1.7	8.4	14.4	5.5	775,304.9	0.00	1.00
07/25/2025 15:00	-2	1.7	8.4	14.4	6.1	775,936.9	0.00	1.00
07/25/2025 16:00	-1	1.7	8.4	14.4	6.7	775,515.6	0.00	1.00
07/25/2025 17:00	-1	1.7	8.4	14.4	6.6	776,147.6	0.00	1.00
07/25/2025 18:00	-1	1.7	8.4	14.3	6.9	765,840.2	0.00	1.00
07/25/2025 19:00	-1	1.7	8.4	14.3	7.2	766,877.7	0.00	1.00
07/25/2025 20:00	-1	1.7	8.5	14.3	7.3	772,479.8	0.00	1.00
07/25/2025 21:00	-1	1.7	8.6	14.3	7.1	768,330.1	0.00	1.00
07/25/2025 22:00	-1	1.7	8.6	14.2	7.0	757,680.0	0.00	1.00
07/25/2025 23:00	-1	1.7	8.6	14.2	7.2	757,271.2	0.00	1.00
Average/Sum#:	-1	1.7	8.6	14.3	7.1	766,757.3	0.00 #	24.00 #
Minimum:	-2	1.7	8.4	14.2	5.5	757,271.2	0.00	1.00
Maximum:	-1	1.7	8.9	14.4	7.9	776,779.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/26/2025 00:00	-1	1.7	8.6	14.2	7.2	757,884.4	0.00	1.00
07/26/2025 01:00	-1	1.7	8.6	14.2	7.3	757,884.4	0.00	1.00
07/26/2025 02:00	-1	1.7	8.8	14.2	7.2	757,680.0	0.00	1.00
07/26/2025 03:00	-1	1.7	8.8	14.2	7.2	757,884.4	0.00	1.00
07/26/2025 04:00	-1	1.7	8.7	14.2	7.5	758,702.0	0.00	1.00
07/26/2025 05:00	-1	1.7	8.7	14.2	7.4	758,702.0	0.00	1.00
07/26/2025 06:00	-1	1.7	8.7	14.2	7.4	758,702.0	0.00	1.00
07/26/2025 07:00	-1	1.7	8.7	14.2	7.3	758,088.8	0.00	1.00
07/26/2025 08:00	-1	1.7	8.6	14.3	6.7	768,745.1	0.00	1.00
07/26/2025 09:00	-1	1.7	8.5	14.3	7.0	767,292.6	0.00	1.00
07/26/2025 10:00	-1	1.7	8.5	14.3	7.1	765,425.2	0.00	1.00
07/26/2025 11:00	-1	1.7	8.5	14.3	6.8	763,142.9	0.00	1.00
07/26/2025 12:00	-1	1.7	8.4	14.3	6.8	762,312.9	0.00	1.00
07/26/2025 13:00	-2	1.7	8.4	14.3	5.0	763,765.3	0.00	1.00
07/26/2025 14:00	-2	1.7	8.4	14.4	4.8	776,569.0	0.00	1.00
07/26/2025 15:00	-2	1.7	8.3	14.4	5.9	776,569.0	0.00	1.00
07/26/2025 16:00	-1	1.7	8.3	14.4	6.3	775,936.9	0.00	1.00
07/26/2025 17:00	-1	1.7	8.3	14.4	7.3	806,485.6	0.00	1.00
07/26/2025 18:00	-1	1.7	8.4	14.3	6.7	766,255.2	0.00	1.00
07/26/2025 19:00	-1	1.7	8.4	14.3	7.2	766,670.2	0.00	1.00
07/26/2025 20:00	-1	1.7	8.5	14.3	7.1	767,500.1	0.00	1.00
07/26/2025 21:00	-1	1.7	8.5	14.3	7.0	767,915.1	0.00	1.00
07/26/2025 22:00	-1	1.7	8.6	14.3	7.0	766,877.7	0.00	1.00
07/26/2025 23:00	-1	1.7	8.6	14.2	7.2	756,249.3	0.00	1.00
Average/Sum#:	-1	1.7	8.5	14.3	6.9	765,968.3	0.00 #	24.00 #
Minimum:	-2	1.7	8.3	14.2	4.8	756,249.3	0.00	1.00
Maximum:	-1	1.7	8.8	14.4	7.5	806,485.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/27/2025 00:00	-1	1.7	8.6	14.2	7.2	757,066.9	0.00	1.00
07/27/2025 01:00	-1	1.7	8.6	14.2	7.3	757,066.9	0.00	1.00
07/27/2025 02:00	-1	1.7	8.8	14.2	7.3	758,088.8	0.00	1.00
07/27/2025 03:00	-1	1.7	8.8	14.2	7.3	757,680.0	0.00	1.00
07/27/2025 04:00	-1	1.7	8.7	14.2	7.5	757,884.4	0.00	1.00
07/27/2025 05:00	-1	1.7	8.7	14.2	7.4	757,271.2	0.00	1.00
07/27/2025 06:00	-1	1.7	8.7	14.2	7.3	758,088.8	0.00	1.00
07/27/2025 07:00	-1	1.7	8.7	14.2	7.1	758,293.2	0.00	1.00
07/27/2025 08:00	-1	1.7	8.6	14.3	6.7	769,367.5	0.00	1.00
07/27/2025 09:00	-1	1.7	8.5	14.3	7.1	768,745.1	0.00	1.00
07/27/2025 10:00	-1	1.7	8.5	14.3	7.1	767,915.1	0.00	1.00
07/27/2025 11:00	-2	1.7	8.4	14.3	6.0	767,292.6	0.00	1.00
07/27/2025 12:00	-2	1.7	8.4	14.3	5.6	766,462.7	0.00	1.00
07/27/2025 13:00	-2	1.7	8.3	14.4	4.7	776,147.6	0.00	1.00
07/27/2025 14:00	-2	1.7	8.3	14.4	5.4	775,936.9	0.00	1.00
07/27/2025 15:00	-1	1.7	8.3	14.4	6.1	776,147.6	0.00	1.00
07/27/2025 16:00	-1	1.7	8.3	14.4	6.1	776,358.3	0.00	1.00
07/27/2025 17:00	-1	1.7	8.2	14.4	7.1	808,803.1	0.00	1.00
07/27/2025 18:00	-1	1.7	8.4	14.4	6.6	782,889.4	0.00	1.00
07/27/2025 19:00	-1	1.7	8.4	14.3	7.2	783,061.8	0.00	0.45
07/27/2025 20:00	-1	1.7	8.4	14.3	7.4	767,915.1	0.00	1.00
07/27/2025 21:00	-1	1.7	8.5	14.3	7.2	768,330.1	0.00	1.00
07/27/2025 22:00	-1	1.7	8.5	14.3	7.0	768,537.6	0.00	1.00
07/27/2025 23:00	-1	1.7	8.5	14.3	7.0	768,745.1	0.00	1.00
Average/Sum#:	-1	1.7	8.5	14.3	6.8	768,920.7	0.00 #	23.45 #
Minimum:	-2	1.7	8.2	14.2	4.7	757,066.9	0.00	0.45
Maximum:	-1	1.7	8.8	14.4	7.5	808,803.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/28/2025 00:00	-1	1.7	8.6	14.3	7.1	769,160.0	0.00	1.00
07/28/2025 01:00	-2	1.7	8.6	14.3	5.9	769,160.0	0.00	1.00
07/28/2025 02:00	-2	1.7	8.8	14.2	5.9	758,088.8	0.00	1.00
07/28/2025 03:00	-2	1.7	8.8	14.2	6.0	757,680.0	0.00	1.00
07/28/2025 04:00	-2	1.7	8.7	14.2	6.3	758,088.8	0.00	1.00
07/28/2025 05:00	-2	1.7	8.7	14.2	5.9	757,884.4	0.00	1.00
07/28/2025 06:00	-2	1.7	8.6	14.2	5.5	758,906.4	0.00	1.00
07/28/2025 07:00	-2	1.7	8.6	14.3	5.4	770,197.5	0.00	1.00
07/28/2025 08:00	-2	1.7	8.5	14.3	4.9	769,782.5	0.00	1.00
07/28/2025 09:00	-2	1.7	8.5	14.3	5.4	770,612.4	0.00	1.00
07/28/2025 10:00	-2	1.7	8.5	14.4	5.4	797,637.0	0.00	1.00
07/28/2025 11:00	-2	1.7	8.3	14.4	3.6	780,150.5	0.00	1.00
07/28/2025 12:00	-2	1.7	7.8	14.4	5.9	948,484.4	0.00	1.00
07/28/2025 13:00	-2	1.7	7.9	14.4	6.1	951,223.2	0.00	1.00
07/28/2025 14:00	-1	1.7	7.9	14.4	7.1	951,855.3	0.00	1.00
07/28/2025 15:00	-1	1.7	8.0	14.3	6.8	827,879.3	0.00	1.00
07/28/2025 16:00	-1	1.7	7.9	14.3	6.4	812,525.1	0.00	1.00
07/28/2025 17:00	-1	1.6	7.8	14.4	7.2	903,188.1	0.00	1.00
07/28/2025 18:00	-1	1.7	7.9	14.4	8.2	949,748.5	0.00	1.00
07/28/2025 19:00	-1	1.7	8.2	14.3	6.5	802,150.7	0.00	1.00
07/28/2025 20:00	-1	1.7	8.4	14.4	7.0	777,411.7	0.00	1.00
07/28/2025 21:00	-1	1.7	8.5	14.4	7.7	789,420.5	0.00	1.00
07/28/2025 22:00	-1	1.7	8.6	14.4	7.5	785,206.9	0.00	1.00
07/28/2025 23:00	-1	1.6	8.6	14.5	10.5	953,889.7	0.00	1.00
Average/Sum#:	-2	1.7	8.4	14.3	6.4	819,597.2	0.00 #	24.00 #
Minimum:	-2	1.6	7.8	14.2	3.6	757,680.0	0.00	1.00
Maximum:	-1	1.7	8.8	14.5	10.5	953,889.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/29/2025 00:00	-1	1.7	8.9	14.3	8.6	814,807.5	0.00	1.00
07/29/2025 01:00	-1	1.7	8.7	14.3	8.1	797,378.5	0.00	1.00
07/29/2025 02:00	-1	1.7	9.2	14.4	9.2	866,951.0	0.00	1.00
07/29/2025 03:00	-1	1.7	8.9	14.3	7.8	795,926.1	0.00	1.00
07/29/2025 04:00	-1	1.7	8.7	14.4	9.3	888,861.8	0.00	1.00
07/29/2025 05:00	-1	1.6	8.9	14.4	9.1	882,752.0	0.00	1.00
07/29/2025 06:00	-1	1.7	8.7	14.3	7.0	776,214.6	0.00	1.00
07/29/2025 07:00	-1	1.7	8.8	14.3	7.2	791,153.8	0.00	1.00
07/29/2025 08:00	-2	1.7	8.7	14.4	6.4	782,468.0	0.00	1.00
07/29/2025 09:00	-1	1.6	8.5	14.5	7.7	906,387.8	0.00	1.00
07/29/2025 10:00	-1	1.7	8.2	14.4	7.3	948,905.8	0.00	1.00
07/29/2025 11:00	-1	1.6	8.1	14.4	7.4	940,057.2	0.00	1.00
07/29/2025 12:00	-1	1.7	7.9	14.4	7.7	949,327.1	0.00	1.00
07/29/2025 13:00	-1	1.6	7.8	14.4	7.7	951,012.6	0.00	1.00
07/29/2025 14:00	-1	1.7	7.8	14.4	8.6	946,588.3	0.00	1.00
07/29/2025 15:00	-1	1.7	8.0	14.3	7.4	813,355.1	0.00	1.00
07/29/2025 16:00	-1	1.6	8.3	14.5	8.7	808,388.3	0.00	1.00
07/29/2025 17:00	-1	1.6	8.2	14.5	7.9	841,554.1	0.00	1.00
07/29/2025 18:00	-1	1.7	8.1	14.4	8.7	926,152.2	0.00	1.00
07/29/2025 19:00	-1	1.7	8.3	14.3	6.9	773,102.3	0.00	1.00
07/29/2025 20:00	-1	1.7	8.5	14.4	7.9	779,729.2	0.00	1.00
07/29/2025 21:00	-1	1.7	8.5	14.4	8.6	837,245.0	0.00	1.00
07/29/2025 22:00	-1	1.7	8.5	14.3	7.6	769,575.0	0.00	1.00
07/29/2025 23:00	-1	1.7	8.6	14.4	8.8	858,734.4	0.00	1.00
Average/Sum#:	-1	1.7	8.5	14.4	8.0	851,942.8	0.00 #	24.00 #
Minimum:	-2	1.6	7.8	14.3	6.4	769,575.0	0.00	1.00
Maximum:	-1	1.7	9.2	14.5	9.3	951,012.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/30/2025 00:00	-1	1.7	8.6	14.3	7.4	769,575.0	0.00	1.00
07/30/2025 01:00	-1	1.7	8.6	14.2	7.2	757,884.4	0.00	1.00
07/30/2025 02:00	-1	1.7	8.8	14.2	7.3	758,497.6	0.00	1.00
07/30/2025 03:00	-1	1.7	8.8	14.2	7.2	758,906.4	0.00	1.00
07/30/2025 04:00	-1	1.7	8.8	14.3	8.2	814,185.0	0.00	1.00
07/30/2025 05:00	-1	1.7	8.9	14.2	8.2	797,536.4	0.00	1.00
07/30/2025 06:00	-1	1.7	8.7	14.2	6.9	759,110.8	0.00	1.00
07/30/2025 07:00	-1	1.7	8.6	14.2	7.1	758,497.6	0.00	1.00
07/30/2025 08:00	-1	1.7	8.6	14.3	6.5	768,537.6	0.00	1.00
07/30/2025 09:00	-1	1.7	8.6	14.3	6.9	767,500.1	0.00	1.00
07/30/2025 10:00	-1	1.7	8.5	14.3	7.0	766,462.7	0.00	1.00
07/30/2025 11:00	-2	1.7	8.5	14.4	6.1	776,990.3	0.00	1.00
07/30/2025 12:00	-2	1.7	8.5	14.4	5.8	776,569.0	0.00	1.00
07/30/2025 13:00	-2	1.7	8.5	14.4	5.8	776,779.6	0.00	1.00
07/30/2025 14:00	-2	1.7	8.5	14.4	6.1	775,726.2	0.00	1.00
07/30/2025 15:00	-1	1.7	8.4	14.4	6.7	775,304.9	0.00	1.00
07/30/2025 16:00	-1	1.7	8.4	14.4	6.6	778,254.4	0.00	1.00
07/30/2025 17:00	-1	1.7	8.1	14.4	6.6	806,696.3	0.00	1.00
07/30/2025 18:00	-1	1.7	8.5	14.4	6.9	790,684.6	0.00	1.00
07/30/2025 19:00	-1	1.7	8.5	14.3	7.3	774,762.2	0.00	1.00
07/30/2025 20:00	-1	1.7	8.5	14.3	7.3	767,915.1	0.00	1.00
07/30/2025 21:00	-1	1.7	8.5	14.3	7.3	768,952.5	0.00	1.00
07/30/2025 22:00	-1	1.7	8.6	14.3	7.3	769,367.5	0.00	1.00
07/30/2025 23:00	-1	1.7	8.6	14.2	7.2	758,293.2	0.00	1.00
Average/Sum#:	-1	1.7	8.6	14.3	7.0	773,874.6	0.00 #	24.00 #
Minimum:	-2	1.7	8.1	14.2	5.8	757,884.4	0.00	1.00
Maximum:	-1	1.7	8.9	14.4	8.2	814,185.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/31/2025 00:00	-1	1.7	8.6	14.2	7.3	758,702.0	0.00	1.00
07/31/2025 01:00	-1	1.7	8.6	14.2	7.2	758,497.6	0.00	1.00
07/31/2025 02:00	-1	1.7	8.9	14.2	7.3	758,906.4	0.00	1.00
07/31/2025 03:00	-1	1.7	8.9	14.2	7.3	759,315.2	0.00	1.00
07/31/2025 04:00	-1	1.7	8.8	14.2	7.5	759,519.6	0.00	1.00
07/31/2025 05:00	-1	1.7	8.8	14.2	7.3	759,723.9	0.00	1.00
07/31/2025 06:00	-1	1.7	8.7	14.2	7.1	759,723.9	0.00	1.00
07/31/2025 07:00	-1	1.7	8.7	14.2	7.0	759,110.8	0.00	1.00
07/31/2025 08:00	-1	1.7	8.6	14.3	6.4	770,819.9	0.00	1.00
07/31/2025 09:00	-1	1.7	8.5	14.3	6.7	769,160.0	0.00	1.00
07/31/2025 10:00	-1	1.7	8.4	14.3	6.4	767,915.1	0.00	1.00
07/31/2025 11:00	-2	1.7	8.4	14.4	5.5	778,465.1	0.00	1.00
07/31/2025 12:00	-2	1.6	8.3	14.4	5.8	785,417.6	0.00	1.00
07/31/2025 13:00	-2	1.7	7.8	14.4	5.7	854,731.5	0.00	1.00
07/31/2025 14:00	-1	1.7	7.8	14.4	7.1	906,980.3	0.00	1.00
07/31/2025 15:00	-1	1.7	7.9	14.4	9.4	946,588.3	0.00	1.00
07/31/2025 16:00	-1	1.6	8.3	14.4	7.5	774,672.8	0.00	1.00
07/31/2025 17:00	-1	1.7	8.0	14.4	7.3	826,711.0	0.00	1.00
07/31/2025 18:00	-1	1.7	7.9	14.4	8.2	895,814.2	0.00	1.00
07/31/2025 19:00	-1	1.7	8.4	14.3	7.5	806,922.9	0.00	1.00
07/31/2025 20:00	-1	1.6	8.4	14.5	8.9	904,462.0	0.00	1.00
07/31/2025 21:00	-1	1.7	8.2	14.5	9.7	947,042.6	0.00	1.00
07/31/2025 22:00	-1	1.6	8.2	14.5	10.3	966,942.0	0.00	1.00
07/31/2025 23:00	-1	1.7	8.5	14.3	7.4	776,422.1	0.00	1.00
Average/Sum#:	-1	1.7	8.4	14.3	7.4	814,690.3	0.00 #	24.00 #
Minimum:	-2	1.6	7.8	14.2	5.5	758,497.6	0.00	1.00
Maximum:	-1	1.7	8.9	14.5	10.3	966,942.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/01/2025 00:00	-1	1.7	8.4	14.3	7.4	769,160.0	0.00	1.00
08/01/2025 01:00	-1	1.7	8.5	14.3	7.6	770,405.0	0.00	1.00
08/01/2025 02:00	-1	1.7	8.7	14.2	7.4	759,315.2	0.00	1.00
08/01/2025 03:00	-1	1.7	8.7	14.2	7.0	759,928.3	0.00	1.00
08/01/2025 04:00	-1	1.7	8.6	14.2	7.4	767,082.0	0.00	1.00
08/01/2025 05:00	-1	1.7	8.8	14.2	7.6	772,191.8	0.00	1.00
08/01/2025 06:00	-1	1.7	8.6	14.2	7.2	759,315.2	0.00	1.00
08/01/2025 07:00	-1	1.7	8.5	14.2	7.2	759,110.8	0.00	1.00
08/01/2025 08:00	-1	1.7	8.5	14.3	6.3	769,990.0	0.00	1.00
08/01/2025 09:00	-1	1.7	8.5	14.3	6.9	768,952.5	0.00	1.00
08/01/2025 10:00	-1	1.7	8.4	14.3	7.0	767,292.6	0.00	1.00
08/01/2025 11:00	-1	1.7	8.4	14.4	6.5	778,465.1	0.00	1.00
08/01/2025 12:00	-1	1.7	8.3	14.4	7.2	777,411.7	0.00	1.00
08/01/2025 13:00	-1	1.6	8.2	14.5	7.2	854,392.4	0.00	1.00
08/01/2025 14:00	-1	1.7	8.1	14.4	8.2	923,202.7	0.00	1.00
08/01/2025 15:00	-1	1.6	8.2	14.4	7.4	787,945.7	0.00	1.00
08/01/2025 16:00	-1	1.6	8.0	14.5	7.2	785,921.2	0.00	1.00
08/01/2025 17:00	-1	1.6	7.9	14.5	7.7	844,549.7	0.00	1.00
08/01/2025 18:00	-1	1.7	8.1	14.4	8.9	903,609.4	0.00	1.00
08/01/2025 19:00	-1	1.7	8.1	14.2	7.0	759,315.2	0.00	1.00
08/01/2025 20:00	-1	1.7	8.3	14.3	7.5	769,160.0	0.00	1.00
08/01/2025 21:00	-1	1.7	8.4	14.3	8.4	816,467.4	0.00	1.00
08/01/2025 22:00	-1	1.7	8.5	14.3	8.1	806,508.0	0.00	1.00
08/01/2025 23:00	-1	1.7	8.5	14.3	8.9	859,417.5	0.00	1.00
Average/Sum#:	-1	1.7	8.4	14.3	7.5	795,379.6	0.00 #	24.00 #
Minimum:	-1	1.6	7.9	14.2	6.3	759,110.8	0.00	1.00
Maximum:	-1	1.7	8.8	14.5	8.9	923,202.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/02/2025 00:00	-1	1.7	8.5	14.2	7.5	760,950.3	0.00	1.00
08/02/2025 01:00	-1	1.7	8.8	14.3	9.2	859,417.5	0.00	1.00
08/02/2025 02:00	-1	1.7	8.7	14.2	7.5	788,952.0	0.00	1.00
08/02/2025 03:00	-1	1.7	8.7	14.2	7.5	789,360.7	0.00	1.00
08/02/2025 04:00	-1	1.7	8.6	14.2	7.7	789,156.4	0.00	1.00
08/02/2025 05:00	-1	1.7	8.7	14.2	7.7	789,973.9	0.00	1.00
08/02/2025 06:00	-1	1.7	8.8	14.2	7.7	794,470.5	0.00	1.00
08/02/2025 07:00	-1	1.7	8.7	14.2	7.7	788,543.2	0.00	1.00
08/02/2025 08:00	-1	1.7	8.6	14.3	6.9	800,075.8	0.00	1.00
08/02/2025 09:00	-1	1.7	8.6	14.3	7.0	799,038.4	0.00	1.00
08/02/2025 10:00	-1	1.7	8.5	14.3	6.9	797,793.4	0.00	1.00
08/02/2025 11:00	-2	1.7	8.5	14.4	6.1	808,381.7	0.00	1.00
08/02/2025 12:00	-1	1.7	8.4	14.4	6.7	807,539.0	0.00	1.00
08/02/2025 13:00	-2	1.7	8.3	14.4	6.3	806,485.6	0.00	1.00
08/02/2025 14:00	-1	1.7	8.2	14.4	6.6	805,642.9	0.00	1.00
08/02/2025 15:00	-1	1.7	8.3	14.4	8.4	805,642.9	0.00	1.00
08/02/2025 16:00	-1	1.6	8.4	14.5	8.5	816,519.3	0.00	1.00
08/02/2025 17:00	-1	1.6	8.4	14.5	9.0	836,204.8	0.00	1.00
08/02/2025 18:00	-1	1.6	8.2	14.4	7.5	804,378.8	0.00	1.00
08/02/2025 19:00	-1	1.7	8.4	14.4	7.8	806,696.3	0.00	1.00
08/02/2025 20:00	-1	1.7	8.5	14.4	8.0	807,539.0	0.00	1.00
08/02/2025 21:00	-1	1.7	8.5	14.3	7.9	795,926.1	0.00	1.00
08/02/2025 22:00	-1	1.7	8.5	14.3	8.0	796,963.5	0.00	1.00
08/02/2025 23:00	-1	1.7	8.6	14.3	8.2	798,000.9	0.00	1.00
Average/Sum#:	-1	1.7	8.5	14.3	7.6	802,235.5	0.00 #	24.00 #
Minimum:	-2	1.6	8.2	14.2	6.1	760,950.3	0.00	1.00
Maximum:	-1	1.7	8.8	14.5	9.2	859,417.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/03/2025 00:00	-1	1.7	8.6	14.3	7.6	797,378.5	0.00	1.00
08/03/2025 01:00	-1	1.7	8.5	14.3	7.7	798,623.4	0.00	1.00
08/03/2025 02:00	-1	1.7	8.8	14.3	7.6	799,660.8	0.00	1.00
08/03/2025 03:00	-1	1.7	8.7	14.2	7.3	787,316.8	0.00	1.00
08/03/2025 04:00	-1	1.7	8.7	14.2	7.4	787,316.8	0.00	1.00
08/03/2025 05:00	-1	1.7	8.7	14.2	7.4	788,134.4	0.00	1.00
08/03/2025 06:00	-1	1.7	8.6	14.2	7.5	787,316.8	0.00	1.00
08/03/2025 07:00	-1	1.7	8.6	14.3	7.4	798,415.9	0.00	1.00
08/03/2025 08:00	-1	1.7	8.5	14.3	7.2	798,000.9	0.00	1.00
08/03/2025 09:00	-1	1.7	8.5	14.3	7.5	796,756.0	0.00	1.00
08/03/2025 10:00	-1	1.7	8.5	14.3	7.5	795,096.1	0.00	1.00
08/03/2025 11:00	-1	1.7	8.5	14.4	6.9	807,117.7	0.00	1.00
08/03/2025 12:00	-1	1.7	8.4	14.4	6.8	806,064.3	0.00	1.00
08/03/2025 13:00	-1	1.7	8.4	14.4	6.8	804,800.2	0.00	1.00
08/03/2025 14:00	-1	1.7	8.4	14.4	7.1	804,168.1	0.00	1.00
08/03/2025 15:00	-1	1.7	8.3	14.4	7.9	804,378.8	0.00	1.00
08/03/2025 16:00	-1	1.7	8.4	14.4	8.2	803,536.1	0.00	1.00
08/03/2025 17:00	-1	1.7	8.2	14.4	8.5	861,684.0	0.00	1.00
08/03/2025 18:00	-1	1.7	8.5	14.3	8.3	799,245.9	0.00	1.00
08/03/2025 19:00	-1	1.7	8.6	14.4	8.1	807,117.7	0.00	1.00
08/03/2025 20:00	-1	1.7	8.6	14.3	7.9	795,718.6	0.00	1.00
08/03/2025 21:00	-1	1.7	8.7	14.3	7.9	796,963.5	0.00	1.00
08/03/2025 22:00	-1	1.7	8.8	14.3	8.1	796,756.0	0.00	1.00
08/03/2025 23:00	-1	1.7	8.8	14.3	8.4	797,171.0	0.00	1.00
Average/Sum#:	-1	1.7	8.6	14.3	7.6	800,780.8	0.00 #	24.00 #
Minimum:	-1	1.7	8.2	14.2	6.8	787,316.8	0.00	1.00
Maximum:	-1	1.7	8.8	14.4	8.5	861,684.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/04/2025 00:00	-1	1.7	8.8	14.3	8.4	796,963.5	0.00	1.00
08/04/2025 01:00	-1	1.7	8.9	14.3	8.3	796,756.0	0.00	0.48
08/04/2025 02:00	-1	1.7	8.9	14.3	8.5	798,415.9	0.00	0.78
08/04/2025 03:00	-1	1.7	8.9	14.3	8.3	798,000.9	0.00	0.65
08/04/2025 04:00	-1	1.7	8.9	14.3	8.5	798,000.9	0.00	1.00
08/04/2025 05:00	-1	1.7	8.9	14.3	8.3	799,660.8	0.00	1.00
08/04/2025 06:00	0	1.7	8.8	14.4	11.5	975,240.8	0.00	0.97
08/04/2025 07:00	-1	1.7	9.0	14.3	8.6	815,637.5	0.00	1.00
08/04/2025 08:00	-1	1.7	8.8	14.3	8.2	796,133.5	0.00	1.00
08/04/2025 09:00	-1	1.7	8.8	14.3	8.4	795,718.6	0.00	1.00
08/04/2025 10:00	-1	1.7	8.7	14.3	8.2	795,096.1	0.00	1.00
08/04/2025 11:00	-1	1.7	8.6	14.3	7.8	793,851.2	0.00	1.00
08/04/2025 12:00	-1	1.7	8.6	14.4	7.4	805,642.9	0.00	1.00
08/04/2025 13:00	-1	1.7	8.5	14.4	7.2	805,010.9	0.00	1.00
08/04/2025 14:00	-1	1.7	8.4	14.4	7.6	806,274.9	0.00	1.00
08/04/2025 15:00	-1	1.7	8.5	14.4	8.4	804,800.2	0.00	1.00
08/04/2025 16:00	-1	1.7	8.5	14.4	8.6	803,536.1	0.00	1.00
08/04/2025 17:00	-1	1.7	8.5	14.5	9.5	863,807.2	0.00	1.00
08/04/2025 18:00	-1	1.7	8.8	14.4	8.7	809,435.2	0.00	1.00
08/04/2025 19:00	-1	1.7	8.7	14.4	8.8	806,274.9	0.00	1.00
08/04/2025 20:00	-1	1.7	8.7	14.4	8.5	807,328.3	0.00	1.00
08/04/2025 21:00	-1	1.7	8.7	14.3	8.5	795,718.6	0.00	1.00
08/04/2025 22:00	-1	1.7	8.7	14.3	8.5	796,963.5	0.00	1.00
08/04/2025 23:00	-1	1.7	8.7	14.3	8.5	796,548.5	0.00	1.00
Average/Sum#:	-1	1.7	8.7	14.3	8.5	810,867.4	0.00 #	22.88 #
Minimum:	-1	1.7	8.4	14.3	7.2	793,851.2	0.00	0.48
Maximum:	0	1.7	9.0	14.5	11.5	975,240.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/05/2025 00:00	-1	1.7	8.7	14.3	8.4	797,378.5	0.00	1.00
08/05/2025 01:00	-1	1.7	8.8	14.3	8.5	797,793.4	0.00	1.00
08/05/2025 02:00	-1	1.7	9.0	14.3	8.4	797,586.0	0.00	1.00
08/05/2025 03:00	-1	1.7	9.0	14.3	8.3	798,415.9	0.00	1.00
08/05/2025 04:00	-1	1.7	9.0	14.3	8.5	799,038.4	0.00	1.00
08/05/2025 05:00	-1	1.7	8.8	14.3	9.6	883,071.2	0.00	1.00
08/05/2025 06:00	-1	1.7	9.2	14.3	9.4	846,968.2	0.00	1.00
08/05/2025 07:00	-1	1.7	8.8	14.3	8.5	798,623.4	0.00	1.00
08/05/2025 08:00	-1	1.7	8.8	14.3	8.2	797,378.5	0.00	1.00
08/05/2025 09:00	-1	1.7	8.7	14.3	8.2	795,926.1	0.00	1.00
08/05/2025 10:00	-1	1.7	9.0	14.3	8.5	795,511.1	0.00	1.00
08/05/2025 11:00	-1	1.7	8.9	14.4	8.0	807,117.7	0.00	1.00
08/05/2025 12:00	-1	1.7	8.8	14.4	7.7	806,696.3	0.00	1.00
08/05/2025 13:00	-1	1.7	8.7	14.4	7.8	805,642.9	0.00	1.00
08/05/2025 14:00	-1	1.7	8.8	14.4	7.7	805,221.5	0.00	1.00
08/05/2025 15:00	-1	1.7	8.8	14.4	8.7	804,800.2	0.00	1.00
08/05/2025 16:00	-1	1.6	8.7	14.5	9.0	845,191.6	0.00	1.00
08/05/2025 17:00	-1	1.7	8.3	14.5	8.7	884,134.6	0.00	1.00
08/05/2025 18:00	-1	1.7	8.3	14.4	10.1	983,036.0	0.00	1.00
08/05/2025 19:00	-1	1.7	8.5	14.4	9.8	952,908.7	0.00	1.00
08/05/2025 20:00	-1	1.7	8.3	14.4	10.0	956,700.9	0.00	1.00
08/05/2025 21:00	-1	1.7	8.1	14.4	10.1	984,089.4	0.00	1.00
08/05/2025 22:00	-1	1.7	8.6	14.4	10.4	941,321.3	0.00	1.00
08/05/2025 23:00	-1	1.7	8.6	14.3	8.2	795,303.6	0.00	1.00
Average/Sum#:	-1	1.7	8.7	14.4	8.8	844,994.0	0.00 #	24.00 #
Minimum:	-1	1.6	8.1	14.3	7.7	795,303.6	0.00	1.00
Maximum:	-1	1.7	9.2	14.5	10.4	984,089.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/06/2025 00:00	-1	1.7	8.6	14.3	8.4	796,548.5	0.00	1.00
08/06/2025 01:00	-1	1.7	8.7	14.3	8.5	796,756.0	0.00	1.00
08/06/2025 02:00	-1	1.7	8.9	14.3	8.4	796,963.5	0.00	1.00
08/06/2025 03:00	-1	1.7	8.9	14.3	8.4	796,756.0	0.00	1.00
08/06/2025 04:00	-1	1.7	8.9	14.3	8.5	796,756.0	0.00	1.00
08/06/2025 05:00	-1	1.7	8.8	14.3	8.9	852,362.9	0.00	1.00
08/06/2025 06:00	-1	1.7	9.1	14.4	10.9	966,181.6	0.00	1.00
08/06/2025 07:00	-1	1.7	8.9	14.3	8.3	821,862.1	0.00	1.00
08/06/2025 08:00	-1	1.7	8.8	14.3	8.0	795,511.1	0.00	1.00
08/06/2025 09:00	-1	1.7	8.7	14.4	8.4	807,539.0	0.00	1.00
08/06/2025 10:00	-1	1.7	8.6	14.4	8.1	806,064.3	0.00	1.00
08/06/2025 11:00	-1	1.7	8.6	14.4	7.8	804,378.8	0.00	1.00
08/06/2025 12:00	-1	1.7	8.6	14.4	8.1	804,378.8	0.00	1.00
08/06/2025 13:00	-1	1.7	8.6	14.4	8.2	804,378.8	0.00	1.00
08/06/2025 14:00	-1	1.7	8.5	14.4	8.0	804,378.8	0.00	1.00
08/06/2025 15:00	-1	1.6	8.6	14.5	8.5	815,663.4	0.00	1.00
08/06/2025 16:00	-1	1.6	8.5	14.5	8.5	823,794.4	0.00	1.00
08/06/2025 17:00	-1	1.6	8.3	14.5	8.6	864,663.1	0.00	1.00
08/06/2025 18:00	-1	1.6	8.6	14.4	9.9	930,365.9	0.00	1.00
08/06/2025 19:00	-1	1.7	8.6	14.3	8.4	823,729.5	0.00	1.00
08/06/2025 20:00	-1	1.7	8.4	14.3	7.4	806,508.0	0.00	1.00
08/06/2025 21:00	-1	1.7	8.5	14.3	8.1	843,855.9	0.00	1.00
08/06/2025 22:00	-1	1.7	8.4	14.3	8.1	857,135.2	0.00	1.00
08/06/2025 23:00	-1	1.7	8.4	14.4	9.8	952,276.6	0.00	1.00
Average/Sum#:	-1	1.7	8.6	14.4	8.5	832,033.7	0.00 #	24.00 #
Minimum:	-1	1.6	8.3	14.3	7.4	795,511.1	0.00	1.00
Maximum:	-1	1.7	9.1	14.5	10.9	966,181.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/07/2025 00:00	-1	1.7	8.5	14.3	8.5	870,414.4	0.00	1.00
08/07/2025 01:00	-1	1.7	8.5	14.3	8.5	844,478.4	0.00	1.00
08/07/2025 02:00	-1	1.7	8.6	14.2	7.5	786,908.0	0.00	1.00
08/07/2025 03:00	-1	1.7	8.6	14.2	7.4	786,908.0	0.00	1.00
08/07/2025 04:00	-1	1.7	8.5	14.2	8.0	812,252.6	0.00	1.00
08/07/2025 05:00	-1	1.7	8.7	14.3	8.8	866,057.2	0.00	1.00
08/07/2025 06:00	-1	1.7	8.5	14.2	7.1	787,725.6	0.00	1.00
08/07/2025 07:00	-1	1.7	8.4	14.2	7.1	786,908.0	0.00	1.00
08/07/2025 08:00	-1	1.7	8.3	14.2	6.6	786,703.6	0.00	1.00
08/07/2025 09:00	-1	1.7	8.2	14.2	6.9	786,294.9	0.00	1.00
08/07/2025 10:00	-1	1.7	8.1	14.2	6.5	785,681.7	0.00	1.00
08/07/2025 11:00	-1	1.7	8.1	14.3	6.7	796,963.5	0.00	1.00
08/07/2025 12:00	-1	1.7	8.0	14.3	6.6	796,756.0	0.00	1.00
08/07/2025 13:00	-1	1.7	8.0	14.3	6.4	795,926.1	0.00	1.00
08/07/2025 14:00	-1	1.7	7.9	14.3	7.5	855,060.3	0.00	1.00
08/07/2025 15:00	-1	1.7	8.0	14.3	7.8	842,818.5	0.00	1.00
08/07/2025 16:00	-1	1.7	8.2	14.4	8.2	805,642.9	0.00	1.00
08/07/2025 17:00	-1	1.6	8.1	14.5	8.4	853,750.5	0.00	1.00
08/07/2025 18:00	-1	1.7	8.0	14.4	8.6	910,140.5	0.00	1.00
08/07/2025 19:00	-1	1.7	8.4	14.4	8.8	855,995.6	0.00	1.00
08/07/2025 20:00	-1	1.7	8.5	14.4	8.1	830,081.9	0.00	1.00
08/07/2025 21:00	-1	1.7	8.4	14.4	7.6	805,432.2	0.00	1.00
08/07/2025 22:00	-1	1.7	8.4	14.4	7.8	805,221.5	0.00	1.00
08/07/2025 23:00	-1	1.7	8.4	14.4	7.7	805,853.6	0.00	1.00
Average/Sum#:	-1	1.7	8.3	14.3	7.6	819,165.6	0.00 #	24.00 #
Minimum:	-1	1.6	7.9	14.2	6.4	785,681.7	0.00	1.00
Maximum:	-1	1.7	8.7	14.5	8.8	910,140.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/08/2025 00:00	-1	1.7	8.5	14.3	7.8	794,473.6	0.00	1.00
08/08/2025 01:00	-1	1.7	8.6	14.3	7.7	794,888.6	0.00	1.00
08/08/2025 02:00	-1	1.7	8.8	14.3	7.7	795,096.1	0.00	1.00
08/08/2025 03:00	-1	1.7	8.8	14.3	7.6	795,096.1	0.00	1.00
08/08/2025 04:00	-1	1.7	8.7	14.3	7.9	796,756.0	0.00	1.00
08/08/2025 05:00	-1	1.7	8.8	14.3	8.5	845,308.3	0.00	1.00
08/08/2025 06:00	-1	1.7	8.6	14.3	6.9	796,548.5	0.00	1.00
08/08/2025 07:00	-1	1.7	8.6	14.3	7.6	795,511.1	0.00	1.00
08/08/2025 08:00	-1	1.7	8.6	14.4	7.5	806,696.3	0.00	1.00
08/08/2025 09:00	-1	1.7	8.5	14.4	8.1	804,800.2	0.00	1.00
08/08/2025 10:00	-1	1.7	8.4	14.4	7.7	804,378.8	0.00	1.00
08/08/2025 11:00	-1	1.7	8.2	14.4	7.3	803,746.8	0.00	1.00
08/08/2025 12:00	-1	1.7	8.2	14.4	7.4	802,061.3	0.00	1.00
08/08/2025 13:00	-1	1.6	7.8	14.5	6.5	831,283.4	0.00	1.00
08/08/2025 14:00	-1	1.6	8.0	14.4	7.2	822,286.7	0.00	1.00
08/08/2025 15:00	-1	1.6	8.0	14.5	7.7	819,728.9	0.00	1.00
08/08/2025 16:00	-1	1.7	7.8	14.5	8.4	881,566.9	0.00	1.00
08/08/2025 17:00	-1	1.7	7.9	14.4	8.2	876,220.9	0.00	1.00
08/08/2025 18:00	-1	1.7	8.1	14.3	7.4	800,283.3	0.00	1.00
08/08/2025 19:00	-1	1.7	8.0	14.3	7.6	798,000.9	0.00	1.00
08/08/2025 20:00	-1	1.6	8.2	14.4	8.3	839,351.8	0.00	1.00
08/08/2025 21:00	-1	1.6	8.3	14.5	7.4	822,938.5	0.00	1.00
08/08/2025 22:00	-1	1.7	8.4	14.4	7.5	806,064.3	0.00	1.00
08/08/2025 23:00	-1	1.7	8.6	14.4	7.6	804,378.8	0.00	1.00
Average/Sum#:	-1	1.7	8.4	14.4	7.6	814,061.1	0.00 #	24.00 #
Minimum:	-1	1.6	7.8	14.3	6.5	794,473.6	0.00	1.00
Maximum:	-1	1.7	8.8	14.5	8.5	881,566.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/09/2025 00:00	-1	1.7	8.4	14.4	7.6	805,432.2	0.00	1.00
08/09/2025 01:00	-1	1.7	8.5	14.3	7.6	793,436.2	0.00	1.00
08/09/2025 02:00	-1	1.7	8.8	14.3	7.7	793,851.2	0.00	1.00
08/09/2025 03:00	-1	1.7	8.7	14.3	7.6	794,058.7	0.00	1.00
08/09/2025 04:00	-1	1.7	8.6	14.3	7.6	794,473.6	0.00	1.00
08/09/2025 05:00	-1	1.7	8.7	14.3	7.6	795,303.6	0.00	1.00
08/09/2025 06:00	-1	1.7	8.7	14.3	7.1	794,681.1	0.00	1.00
08/09/2025 07:00	-1	1.7	8.6	14.3	7.7	793,436.2	0.00	1.00
08/09/2025 08:00	-1	1.7	8.5	14.4	7.4	804,800.2	0.00	1.00
08/09/2025 09:00	-1	1.7	8.5	14.4	8.2	803,746.8	0.00	1.00
08/09/2025 10:00	-1	1.7	8.4	14.4	7.9	803,114.7	0.00	1.00
08/09/2025 11:00	-1	1.6	8.2	14.4	7.4	802,482.7	0.00	1.00
08/09/2025 12:00	-1	1.6	7.8	14.5	6.7	812,667.8	0.00	1.00
08/09/2025 13:00	-1	1.6	7.5	14.5	6.3	811,383.9	0.00	1.00
08/09/2025 14:00	-1	1.6	7.7	14.5	7.3	821,654.6	0.00	1.00
08/09/2025 15:00	-1	1.6	7.6	14.5	6.9	810,528.1	0.00	1.00
08/09/2025 16:00	-1	1.6	7.7	14.5	8.3	872,152.2	0.00	1.00
08/09/2025 17:00	-1	1.7	7.9	14.4	8.1	808,381.7	0.00	1.00
08/09/2025 18:00	-1	1.6	7.5	14.5	6.6	811,597.9	0.00	1.00
08/09/2025 19:00	0	1.6	8.0	14.5	9.3	884,776.5	0.00	1.00
08/09/2025 20:00	-1	1.7	8.6	14.4	8.6	809,224.5	0.00	1.00
08/09/2025 21:00	-1	1.7	8.5	14.4	8.2	802,693.4	0.00	1.00
08/09/2025 22:00	-1	1.7	8.5	14.4	8.3	803,536.1	0.00	1.00
08/09/2025 23:00	-1	1.7	8.5	14.4	8.1	803,746.8	0.00	1.00
Average/Sum#:	-1	1.7	8.3	14.4	7.7	809,631.7	0.00 #	24.00 #
Minimum:	-1	1.6	7.5	14.3	6.3	793,436.2	0.00	1.00
Maximum:	0	1.7	8.8	14.5	9.3	884,776.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/10/2025 00:00	-1	1.7	8.6	14.3	8.2	792,191.3	0.00	1.00
08/10/2025 01:00	-1	1.7	8.7	14.3	8.3	792,398.7	0.00	1.00
08/10/2025 02:00	-1	1.7	8.8	14.3	8.3	793,228.7	0.00	1.00
08/10/2025 03:00	-1	1.7	8.8	14.3	8.2	793,436.2	0.00	1.00
08/10/2025 04:00	-1	1.7	8.8	14.3	8.3	794,266.1	0.00	1.00
08/10/2025 05:00	-1	1.7	8.8	14.3	8.1	794,888.6	0.00	1.00
08/10/2025 06:00	-1	1.7	8.8	14.3	7.6	794,888.6	0.00	1.00
08/10/2025 07:00	-1	1.7	8.7	14.3	7.9	793,436.2	0.00	1.00
08/10/2025 08:00	-1	1.7	8.7	14.4	8.0	804,168.1	0.00	1.00
08/10/2025 09:00	-1	1.7	8.6	14.4	8.4	803,325.4	0.00	1.00
08/10/2025 10:00	-1	1.7	8.5	14.4	8.1	802,272.0	0.00	1.00
08/10/2025 11:00	-1	1.7	8.1	14.4	7.4	801,429.3	0.00	1.00
08/10/2025 12:00	-1	1.6	7.8	14.5	6.9	811,383.9	0.00	1.00
08/10/2025 13:00	-1	1.6	7.7	14.5	8.3	919,868.0	0.00	1.00
08/10/2025 14:00	-1	1.6	8.0	14.5	10.1	995,614.3	0.00	1.00
08/10/2025 15:00	-1	1.6	8.0	14.5	8.5	892,265.6	0.00	1.00
08/10/2025 16:00	-1	1.6	8.0	14.5	8.4	904,034.1	0.00	1.00
08/10/2025 17:00	-1	1.6	7.6	14.5	7.5	904,034.1	0.00	1.00
08/10/2025 18:00	-1	1.6	7.8	14.5	9.2	1,001,177.6	0.00	1.00
08/10/2025 19:00	-1	1.7	8.2	14.4	7.5	880,645.2	0.00	1.00
08/10/2025 20:00	-1	1.7	8.2	14.3	6.3	816,674.9	0.00	1.00
08/10/2025 21:00	-1	1.7	8.3	14.4	7.6	856,416.9	0.00	1.00
08/10/2025 22:00	-1	1.7	8.4	14.4	7.3	809,645.8	0.00	1.00
08/10/2025 23:00	-1	1.7	8.5	14.3	7.5	796,963.5	0.00	1.00
Average/Sum#:	-1	1.7	8.4	14.4	8.0	839,527.2	0.00 #	24.00 #
Minimum:	-1	1.6	7.6	14.3	6.3	792,191.3	0.00	1.00
Maximum:	-1	1.7	8.8	14.5	10.1	1,001,177.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/11/2025 00:00	-1	1.7	8.6	14.3	7.7	792,398.7	0.00	1.00
08/11/2025 01:00	-1	1.7	8.7	14.3	7.9	791,776.3	0.00	1.00
08/11/2025 02:00	-1	1.7	9.0	14.3	7.7	791,361.3	0.00	1.00
08/11/2025 03:00	-1	1.7	8.9	14.3	7.3	791,983.8	0.00	1.00
08/11/2025 04:00	-1	1.7	8.7	14.3	7.7	846,553.3	0.00	1.00
08/11/2025 05:00	-1	1.7	8.9	14.4	9.0	915,196.8	0.00	1.00
08/11/2025 06:00	-1	1.7	8.7	14.3	6.9	792,813.7	0.00	1.00
08/11/2025 07:00	-1	1.7	8.7	14.3	6.7	792,606.2	0.00	1.00
08/11/2025 08:00	-1	1.7	8.7	14.3	7.0	791,153.8	0.00	1.00
08/11/2025 09:00	-2	1.7	8.7	14.3	6.4	790,323.9	0.00	1.00
08/11/2025 10:00	-2	1.7	8.6	14.4	6.0	800,797.2	0.00	1.00
08/11/2025 11:00	-2	1.7	8.5	14.4	5.9	799,954.5	0.00	1.00
08/11/2025 12:00	-2	1.6	8.4	14.4	6.1	799,111.8	0.00	1.00
08/11/2025 13:00	-2	1.7	8.2	14.5	6.6	831,283.4	0.00	1.00
08/11/2025 14:00	-2	1.6	7.8	14.5	6.3	884,134.6	0.00	1.00
08/11/2025 15:00	-1	1.7	8.0	14.4	5.9	802,272.0	0.00	1.00
08/11/2025 16:00	-1	1.6	7.5	14.5	6.1	862,309.4	0.00	1.00
08/11/2025 17:00	-1	1.7	7.7	14.3	6.6	885,146.1	0.00	1.00
08/11/2025 18:00	-1	1.7	7.7	14.4	7.8	968,077.7	0.00	1.00
08/11/2025 19:00	-1	1.7	8.1	14.4	7.4	938,582.4	0.00	1.00
08/11/2025 20:00	-1	1.7	8.0	14.4	8.0	965,760.2	0.00	1.00
08/11/2025 21:00	-1	1.7	8.2	14.4	8.6	964,706.8	0.00	1.00
08/11/2025 22:00	-1	1.7	8.4	14.3	7.9	899,255.3	0.00	1.00
08/11/2025 23:00	-1	1.7	8.5	14.3	8.0	881,826.3	0.00	1.00
Average/Sum#:	-1	1.7	8.4	14.4	7.1	849,141.1	0.00 #	24.00 #
Minimum:	-2	1.6	7.5	14.3	5.9	790,323.9	0.00	1.00
Maximum:	-1	1.7	9.0	14.5	9.0	968,077.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/12/2025 00:00	-1	1.7	8.6	14.4	8.8	917,514.3	0.00	1.00
08/12/2025 01:00	-1	1.7	8.7	14.3	8.3	881,411.3	0.00	1.00
08/12/2025 02:00	-1	1.8	8.9	14.2	6.4	795,492.5	0.00	1.00
08/12/2025 03:00	-1	1.7	8.7	14.3	7.1	829,954.2	0.00	1.00
08/12/2025 04:00	-1	1.7	8.8	14.3	8.3	908,384.8	0.00	1.00
08/12/2025 05:00	-1	1.7	8.9	14.3	9.6	949,260.1	0.00	1.00
08/12/2025 06:00	-2	1.7	8.8	14.2	6.6	815,114.1	0.00	1.00
08/12/2025 07:00	-1	1.7	8.6	14.2	6.5	786,294.9	0.00	1.00
08/12/2025 08:00	-1	1.7	8.6	14.3	6.8	796,756.0	0.00	1.00
08/12/2025 09:00	-1	1.7	8.6	14.3	6.5	795,926.1	0.00	1.00
08/12/2025 10:00	-2	1.7	8.5	14.3	6.0	794,266.1	0.00	1.00
08/12/2025 11:00	-2	1.7	8.4	14.3	5.6	793,643.7	0.00	1.00
08/12/2025 12:00	-2	1.7	8.4	14.4	5.4	803,746.8	0.00	1.00
08/12/2025 13:00	-2	1.7	8.1	14.4	5.9	841,458.6	0.00	1.00
08/12/2025 14:00	-2	1.7	7.8	14.4	6.4	922,570.7	0.00	1.00
08/12/2025 15:00	-1	1.7	7.9	14.4	6.9	912,036.6	0.00	1.00
08/12/2025 16:00	-1	1.6	7.8	14.4	7.2	935,422.2	0.00	1.00
08/12/2025 17:00	-1	1.6	7.8	14.5	8.3	1,011,876.2	0.00	1.00
08/12/2025 18:00	-1	1.7	8.0	14.4	8.2	976,504.9	0.00	1.00
08/12/2025 19:00	-1	1.7	8.1	14.4	8.2	969,552.5	0.00	1.00
08/12/2025 20:00	-1	1.7	8.5	14.4	8.0	914,986.2	0.00	1.00
08/12/2025 21:00	-1	1.7	8.6	14.4	7.6	881,277.3	0.00	1.00
08/12/2025 22:00	-1	1.7	8.5	14.3	7.9	874,771.7	0.00	1.00
08/12/2025 23:00	-1	1.7	8.5	14.3	6.4	798,415.9	0.00	1.00
Average/Sum#:	-1	1.7	8.4	14.3	7.2	871,109.9	0.00 #	24.00 #
Minimum:	-2	1.6	7.8	14.2	5.4	786,294.9	0.00	1.00
Maximum:	-1	1.8	8.9	14.5	9.6	1,011,876.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/13/2025 00:00	-1	1.7	8.6	14.2	6.5	787,930.0	0.00	1.00
08/13/2025 01:00	-1	1.7	8.6	14.2	6.6	788,134.4	0.00	1.00
08/13/2025 02:00	-2	1.7	8.8	14.2	6.5	788,134.4	0.00	1.00
08/13/2025 03:00	-1	1.7	8.8	14.2	6.5	788,543.2	0.00	1.00
08/13/2025 04:00	-2	1.7	8.7	14.2	6.1	788,134.4	0.00	1.00
08/13/2025 05:00	-2	1.7	8.7	14.2	6.2	788,543.2	0.00	1.00
08/13/2025 06:00	-2	1.7	8.7	14.2	6.3	788,952.0	0.00	1.00
08/13/2025 07:00	-2	1.7	8.7	14.2	6.3	788,747.6	0.00	1.00
08/13/2025 08:00	-1	1.7	8.6	14.2	6.6	788,134.4	0.00	1.00
08/13/2025 09:00	-2	1.7	8.5	14.3	6.1	799,660.8	0.00	1.00
08/13/2025 10:00	-2	1.7	8.5	14.3	5.9	798,623.4	0.00	1.00
08/13/2025 11:00	-2	1.7	8.4	14.3	5.5	798,208.4	0.00	1.00
08/13/2025 12:00	-2	1.7	8.4	14.4	5.4	808,592.4	0.00	1.00
08/13/2025 13:00	-2	1.7	8.3	14.4	5.0	806,485.6	0.00	1.00
08/13/2025 14:00	-2	1.7	8.3	14.4	5.2	804,378.8	0.00	1.00
08/13/2025 15:00	-2	1.7	8.2	14.4	5.9	804,168.1	0.00	1.00
08/13/2025 16:00	-2	1.7	8.3	14.4	6.1	804,168.1	0.00	1.00
08/13/2025 17:00	-2	1.7	8.2	14.4	6.2	836,191.6	0.00	1.00
08/13/2025 18:00	-2	1.7	8.5	14.3	6.2	793,228.7	0.00	1.00
08/13/2025 19:00	-2	1.7	8.4	14.3	6.2	793,643.7	0.00	1.00
08/13/2025 20:00	-1	1.7	8.5	14.3	6.6	794,266.1	0.00	1.00
08/13/2025 21:00	-1	1.7	8.5	14.3	6.6	794,058.7	0.00	1.00
08/13/2025 22:00	-1	1.7	8.6	14.2	6.6	783,637.8	0.00	1.00
08/13/2025 23:00	-1	1.7	8.6	14.2	6.6	785,681.7	0.00	1.00
Average/Sum#:	-2	1.7	8.5	14.3	6.2	795,843.6	0.00 #	24.00 #
Minimum:	-2	1.7	8.2	14.2	5.0	783,637.8	0.00	1.00
Maximum:	-1	1.7	8.8	14.4	6.6	836,191.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/14/2025 00:00	-1	1.7	8.6	14.2	6.8	786,294.9	0.00	1.00
08/14/2025 01:00	-1	1.7	8.7	14.2	6.7	787,112.4	0.00	1.00
08/14/2025 02:00	-2	1.7	8.9	14.2	6.5	786,703.6	0.00	1.00
08/14/2025 03:00	-1	1.7	8.8	14.2	6.7	787,521.2	0.00	1.00
08/14/2025 04:00	-1	1.7	8.8	14.2	6.9	788,543.2	0.00	1.00
08/14/2025 05:00	-1	1.7	8.8	14.2	6.7	789,156.4	0.00	1.00
08/14/2025 06:00	-1	1.7	8.8	14.2	6.6	789,565.1	0.00	1.00
08/14/2025 07:00	-2	1.7	8.7	14.2	6.3	788,952.0	0.00	1.00
08/14/2025 08:00	-2	1.7	8.7	14.2	6.3	789,156.4	0.00	1.00
08/14/2025 09:00	-2	1.7	8.6	14.3	6.2	798,830.9	0.00	1.00
08/14/2025 10:00	-2	1.7	8.6	14.3	6.2	797,171.0	0.00	1.00
08/14/2025 11:00	-2	1.7	8.5	14.3	6.0	795,511.1	0.00	1.00
08/14/2025 12:00	-2	1.7	8.5	14.4	5.7	806,274.9	0.00	1.00
08/14/2025 13:00	-2	1.7	8.4	14.4	5.3	805,642.9	0.00	1.00
08/14/2025 14:00	-2	1.7	8.5	14.4	5.8	805,221.5	0.00	1.00
08/14/2025 15:00	-1	1.7	8.5	14.4	6.7	804,589.5	0.00	1.00
08/14/2025 16:00	-2	1.7	8.3	14.4	6.3	803,536.1	0.00	1.00
08/14/2025 17:00	-1	1.7	8.2	14.4	6.6	823,129.4	0.00	1.00
08/14/2025 18:00	-2	1.7	8.2	14.4	5.4	802,904.1	0.00	1.00
08/14/2025 19:00	-2	1.7	8.4	14.4	6.0	805,010.9	0.00	1.00
08/14/2025 20:00	-2	1.7	8.4	14.3	5.9	793,851.2	0.00	1.00
08/14/2025 21:00	-2	1.7	8.6	14.3	6.4	795,096.1	0.00	1.00
08/14/2025 22:00	-2	1.7	8.6	14.3	6.3	795,096.1	0.00	1.00
08/14/2025 23:00	-2	1.7	8.7	14.3	6.4	794,266.1	0.00	1.00
Average/Sum#:	-2	1.7	8.6	14.3	6.3	796,630.7	0.00 #	24.00 #
Minimum:	-2	1.7	8.2	14.2	5.3	786,294.9	0.00	1.00
Maximum:	-1	1.7	8.9	14.4	6.9	823,129.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/15/2025 00:00	-2	1.7	8.7	14.3	6.5	794,888.6	0.00	1.00
08/15/2025 01:00	-2	1.7	8.7	14.3	6.4	794,888.6	0.00	1.00
08/15/2025 02:00	-2	1.7	8.9	14.3	6.5	795,303.6	0.00	1.00
08/15/2025 03:00	-2	1.7	8.9	14.2	6.1	784,250.9	0.00	1.00
08/15/2025 04:00	-2	1.7	8.9	14.3	6.7	796,756.0	0.00	1.00
08/15/2025 05:00	-1	1.7	8.9	14.2	6.9	796,514.5	0.00	1.00
08/15/2025 06:00	-2	1.7	8.8	14.3	6.2	826,841.8	0.00	1.00
08/15/2025 07:00	-2	1.7	8.7	14.3	6.0	796,756.0	0.00	1.00
08/15/2025 08:00	-2	1.7	8.7	14.3	6.1	796,133.5	0.00	1.00
08/15/2025 09:00	-2	1.7	8.6	14.3	6.2	794,681.1	0.00	1.00
08/15/2025 10:00	-2	1.7	8.5	14.4	5.5	806,485.6	0.00	1.00
08/15/2025 11:00	-2	1.7	8.5	14.4	6.1	804,378.8	0.00	1.00
08/15/2025 12:00	-2	1.7	8.6	14.4	6.7	803,325.4	0.00	1.00
08/15/2025 13:00	-2	1.6	8.6	14.5	7.0	814,807.5	0.00	1.00
08/15/2025 14:00	-2	1.6	8.5	14.5	6.7	813,737.6	0.00	1.00
08/15/2025 15:00	-1	1.6	8.1	14.5	6.6	813,523.7	0.00	1.00
08/15/2025 16:00	-2	1.6	8.1	14.5	6.2	814,379.6	0.00	1.00
08/15/2025 17:00	-2	1.6	8.2	14.5	6.2	815,663.4	0.00	1.00
08/15/2025 18:00	-2	1.7	8.2	14.4	6.2	804,589.5	0.00	1.00
08/15/2025 19:00	-2	1.7	8.4	14.4	6.4	808,381.7	0.00	1.00
08/15/2025 20:00	-2	1.7	8.4	14.3	6.1	797,171.0	0.00	1.00
08/15/2025 21:00	-2	1.7	8.5	14.3	6.1	798,000.9	0.00	1.00
08/15/2025 22:00	-2	1.7	8.5	14.3	6.1	798,830.9	0.00	1.00
08/15/2025 23:00	-2	1.7	8.5	14.3	6.5	824,144.5	0.00	1.00
Average/Sum#:	-2	1.7	8.6	14.4	6.3	803,934.8	0.00 #	24.00 #
Minimum:	-2	1.6	8.1	14.2	5.5	784,250.9	0.00	1.00
Maximum:	-1	1.7	8.9	14.5	7.0	826,841.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/16/2025 00:00	-1	1.7	8.5	14.4	8.4	953,330.1	0.00	1.00
08/16/2025 01:00	-2	1.7	8.4	14.3	6.0	800,075.8	0.00	1.00
08/16/2025 02:00	-2	1.7	8.6	14.3	5.7	800,698.3	0.00	1.00
08/16/2025 03:00	-2	1.7	8.6	14.2	5.7	788,747.6	0.00	1.00
08/16/2025 04:00	-2	1.7	8.5	14.2	6.0	788,747.6	0.00	1.00
08/16/2025 05:00	-2	1.7	8.5	14.2	5.7	788,952.0	0.00	1.00
08/16/2025 06:00	-2	1.7	8.5	14.2	5.7	789,360.7	0.00	1.00
08/16/2025 07:00	-2	1.7	8.4	14.3	5.8	800,698.3	0.00	1.00
08/16/2025 08:00	-2	1.7	8.4	14.3	6.1	800,490.8	0.00	1.00
08/16/2025 09:00	-2	1.7	8.4	14.3	6.1	799,453.4	0.00	1.00
08/16/2025 10:00	-2	1.7	8.3	14.3	5.6	798,415.9	0.00	1.00
08/16/2025 11:00	-2	1.7	8.3	14.3	5.3	797,586.0	0.00	1.00
08/16/2025 12:00	-2	1.7	8.3	14.3	5.2	797,171.0	0.00	1.00
08/16/2025 13:00	-2	1.7	8.2	14.4	5.0	809,224.5	0.00	1.00
08/16/2025 14:00	-2	1.6	8.1	14.4	5.2	861,262.6	0.00	1.00
08/16/2025 15:00	-2	1.7	8.2	14.3	5.4	796,963.5	0.00	1.00
08/16/2025 16:00	-2	1.7	8.2	14.4	5.4	808,592.4	0.00	1.00
08/16/2025 17:00	-2	1.7	8.1	14.4	5.7	827,132.3	0.00	1.00
08/16/2025 18:00	-2	1.7	8.2	14.3	5.3	805,055.5	0.00	1.00
08/16/2025 19:00	-2	1.7	8.2	14.4	6.5	860,419.9	0.00	1.00
08/16/2025 20:00	-2	1.7	8.3	14.3	5.8	796,341.0	0.00	1.00
08/16/2025 21:00	-2	1.7	8.3	14.3	5.8	800,698.3	0.00	1.00
08/16/2025 22:00	-2	1.7	8.3	14.3	5.7	803,188.2	0.00	1.00
08/16/2025 23:00	-1	1.7	8.4	14.4	8.1	938,582.4	0.00	1.00
Average/Sum#:	-2	1.7	8.3	14.3	5.9	817,132.8	0.00 #	24.00 #
Minimum:	-2	1.6	8.1	14.2	5.0	788,747.6	0.00	1.00
Maximum:	-1	1.7	8.6	14.4	8.4	953,330.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/17/2025 00:00	-2	1.7	8.5	14.3	6.2	794,266.1	0.00	1.00
08/17/2025 01:00	-2	1.7	8.6	14.3	6.5	795,096.1	0.00	1.00
08/17/2025 02:00	-2	1.7	8.9	14.3	6.7	794,473.6	0.00	1.00
08/17/2025 03:00	-1	1.7	8.9	14.3	6.5	794,681.1	0.00	1.00
08/17/2025 04:00	-2	1.7	8.8	14.3	6.7	794,888.6	0.00	1.00
08/17/2025 05:00	-2	1.7	8.8	14.3	6.7	795,718.6	0.00	1.00
08/17/2025 06:00	-2	1.7	8.8	14.2	6.2	784,659.7	0.00	1.00
08/17/2025 07:00	-2	1.7	8.7	14.3	6.3	796,133.5	0.00	1.00
08/17/2025 08:00	-1	1.7	8.6	14.3	6.6	795,303.6	0.00	1.00
08/17/2025 09:00	-1	1.7	8.6	14.3	6.6	794,888.6	0.00	1.00
08/17/2025 10:00	-2	1.7	8.5	14.3	6.1	795,718.6	0.00	1.00
08/17/2025 11:00	-2	1.7	8.5	14.3	6.0	796,341.0	0.00	1.00
08/17/2025 12:00	-2	1.7	8.5	14.3	5.7	795,718.6	0.00	1.00
08/17/2025 13:00	-2	1.7	8.5	14.4	5.9	807,960.4	0.00	1.00
08/17/2025 14:00	-2	1.7	8.6	14.4	5.5	807,539.0	0.00	1.00
08/17/2025 15:00	-2	1.7	8.7	14.4	6.3	806,907.0	0.00	1.00
08/17/2025 16:00	-2	1.7	8.6	14.4	6.8	837,245.0	0.00	1.00
08/17/2025 17:00	-2	1.6	8.6	14.5	8.2	942,763.1	0.00	1.00
08/17/2025 18:00	-1	1.6	8.5	14.5	9.5	1,006,740.9	0.00	1.00
08/17/2025 19:00	-1	1.6	8.6	14.5	10.1	1,006,740.9	0.00	1.00
08/17/2025 20:00	-1	1.7	8.6	14.4	10.2	989,777.8	0.00	1.00
08/17/2025 21:00	-1	1.7	8.6	14.4	9.9	989,988.5	0.00	1.00
08/17/2025 22:00	-1	1.7	8.6	14.4	9.8	989,145.8	0.00	1.00
08/17/2025 23:00	-1	1.7	8.7	14.4	9.5	972,080.6	0.00	1.00
Average/Sum#:	-2	1.7	8.6	14.4	7.3	853,532.4	0.00 #	24.00 #
Minimum:	-2	1.6	8.5	14.2	5.5	784,659.7	0.00	1.00
Maximum:	-1	1.7	8.9	14.5	10.2	1,006,740.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/18/2025 00:00	-2	1.7	8.7	14.2	6.3	790,587.1	0.00	1.00
08/18/2025 01:00	-1	1.7	8.6	14.2	6.5	790,178.3	0.00	1.00
08/18/2025 02:00	-2	1.7	8.9	14.2	6.5	790,587.1	0.00	1.00
08/18/2025 03:00	-2	1.7	8.8	14.2	6.4	790,587.1	0.00	1.00
08/18/2025 04:00	-1	1.7	8.8	14.3	7.3	838,876.2	0.00	1.00
08/18/2025 05:00	-1	1.7	9.0	14.3	8.9	927,888.8	0.00	1.00
08/18/2025 06:00	-2	1.7	8.7	14.2	6.0	790,995.9	0.00	1.00
08/18/2025 07:00	-2	1.7	8.7	14.2	6.3	790,791.5	0.00	1.00
08/18/2025 08:00	-2	1.7	8.6	14.3	6.5	802,565.7	0.00	1.00
08/18/2025 09:00	-2	1.7	8.6	14.3	6.5	801,943.2	0.00	1.00
08/18/2025 10:00	-2	1.7	8.6	14.3	6.0	800,905.8	0.00	1.00
08/18/2025 11:00	-1	1.7	8.2	14.4	7.7	974,187.4	0.00	1.00
08/18/2025 12:00	-1	1.7	8.3	14.4	7.7	980,507.9	0.00	1.00
08/18/2025 13:00	-2	1.7	8.2	14.4	7.5	988,513.7	0.00	1.00
08/18/2025 14:00	-2	1.7	8.2	14.4	7.6	990,831.2	0.00	1.00
08/18/2025 15:00	-1	1.7	8.3	14.4	8.9	994,834.1	0.00	1.00
08/18/2025 16:00	-1	1.7	8.6	14.4	8.0	895,392.9	0.00	1.00
08/18/2025 17:00	-2	1.7	8.2	14.3	6.5	887,013.5	0.00	1.00
08/18/2025 18:00	-1	1.7	8.2	14.4	8.7	996,098.2	0.00	1.00
08/18/2025 19:00	-1	1.7	8.5	14.4	9.4	994,623.5	0.00	1.00
08/18/2025 20:00	-1	1.6	8.7	14.5	10.4	1,007,382.8	0.00	1.00
08/18/2025 21:00	-1	1.6	8.9	14.5	9.9	977,854.6	0.00	1.00
08/18/2025 22:00	-1	1.7	8.8	14.4	8.9	905,926.9	0.00	1.00
08/18/2025 23:00	-1	1.7	8.8	14.3	7.3	824,974.4	0.00	1.00
Average/Sum#:	-1	1.7	8.6	14.3	7.6	888,918.7	0.00 #	24.00 #
Minimum:	-2	1.6	8.2	14.2	6.0	790,178.3	0.00	1.00
Maximum:	-1	1.7	9.0	14.5	10.4	1,007,382.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/19/2025 00:00	-1	1.7	8.7	14.3	6.8	801,320.8	0.00	1.00
08/19/2025 01:00	-1	1.7	8.8	14.3	6.9	802,358.2	0.00	1.00
08/19/2025 02:00	-2	1.7	9.1	14.3	6.9	802,565.7	0.00	1.00
08/19/2025 03:00	-2	1.7	9.0	14.3	6.9	802,150.7	0.00	1.00
08/19/2025 04:00	-1	1.7	8.9	14.3	8.0	851,533.0	0.00	1.00
08/19/2025 05:00	-1	1.7	9.4	14.3	8.0	860,040.0	0.00	1.00
08/19/2025 06:00	-2	1.7	9.0	14.3	7.0	834,933.9	0.00	1.00
08/19/2025 07:00	-2	1.7	8.8	14.3	6.4	802,980.7	0.00	1.00
08/19/2025 08:00	-2	1.7	8.7	14.3	6.8	801,735.7	0.00	1.00
08/19/2025 09:00	-2	1.7	8.7	14.3	6.5	800,905.8	0.00	1.00
08/19/2025 10:00	-2	1.7	8.6	14.4	5.8	812,384.7	0.00	1.00
08/19/2025 11:00	-2	1.7	8.3	14.4	5.5	848,411.1	0.00	1.00
08/19/2025 12:00	-2	1.7	8.0	14.4	7.4	991,673.9	0.00	1.00
08/19/2025 13:00	-1	1.7	8.1	14.4	8.0	990,199.2	0.00	1.00
08/19/2025 14:00	-1	1.7	8.1	14.4	8.3	987,671.0	0.00	1.00
08/19/2025 15:00	-1	1.7	8.2	14.4	9.1	987,249.6	0.00	1.00
08/19/2025 16:00	-1	1.7	8.2	14.4	8.4	959,650.5	0.00	1.00
08/19/2025 17:00	-1	1.7	8.3	14.3	7.5	887,428.5	0.00	1.00
08/19/2025 18:00	-1	1.7	8.3	14.4	9.2	989,356.4	0.00	1.00
08/19/2025 19:00	-1	1.7	8.4	14.4	8.9	988,513.7	0.00	1.00
08/19/2025 20:00	-1	1.7	8.2	14.4	8.9	990,831.2	0.00	1.00
08/19/2025 21:00	-1	1.7	8.3	14.4	9.2	991,252.6	0.00	1.00
08/19/2025 22:00	-1	1.7	8.5	14.3	9.4	962,539.4	0.00	1.00
08/19/2025 23:00	-1	1.7	8.6	14.3	8.1	909,214.8	0.00	1.00
Average/Sum#:	-1	1.7	8.6	14.3	7.7	894,037.5	0.00 #	24.00 #
Minimum:	-2	1.7	8.0	14.3	5.5	800,905.8	0.00	1.00
Maximum:	-1	1.7	9.4	14.4	9.4	991,673.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/20/2025 00:00	-2	1.7	8.5	14.2	6.4	804,076.9	0.00	1.00
08/20/2025 01:00	-2	1.7	8.5	14.2	6.0	792,631.0	0.00	1.00
08/20/2025 02:00	-2	1.7	8.9	14.3	6.5	803,188.2	0.00	1.00
08/20/2025 03:00	-2	1.7	8.9	14.3	6.7	802,980.7	0.00	1.00
08/20/2025 04:00	-1	1.7	8.8	14.3	7.0	813,770.1	0.00	1.00
08/20/2025 05:00	-1	1.7	8.9	14.3	8.5	880,996.4	0.00	1.00
08/20/2025 06:00	-2	1.7	8.8	14.4	8.2	950,591.2	0.00	1.00
08/20/2025 07:00	-1	1.7	9.0	14.4	9.0	933,315.4	0.00	1.00
08/20/2025 08:00	-1	1.6	8.6	14.5	8.5	1,012,518.2	0.00	1.00
08/20/2025 09:00	-1	1.6	8.5	14.5	8.9	1,013,374.0	0.00	1.00
08/20/2025 10:00	-1	1.6	8.8	14.6	10.0	1,034,676.2	0.00	1.00
08/20/2025 11:00	-2	1.6	8.2	14.4	7.7	994,202.1	0.00	1.00
08/20/2025 12:00	-1	1.6	7.9	14.4	7.8	987,460.3	0.00	1.00
08/20/2025 13:00	-1	1.7	8.5	14.3	10.4	1,001,962.2	0.00	1.00
08/20/2025 14:00	2	2.2	14.0	12.5	24.2	1,052,174.4	0.00	1.00
08/20/2025 15:00	1	2.0	11.9	13.2	18.5	1,041,829.6	0.00	1.00
08/20/2025 16:00	0	1.9	10.7	13.6	15.9	1,046,015.1	0.00	1.00
08/20/2025 17:00	1	2.0	11.4	13.3	18.4	1,045,087.0	0.00	1.00
08/20/2025 18:00	2	2.1	13.5	12.6	23.3	1,043,237.4	0.00	1.00
08/20/2025 19:00	0	1.8	10.6	13.7	15.0	1,055,598.0	0.00	1.00
08/20/2025 20:00	0	1.8	10.6	13.7	14.7	1,052,364.6	0.00	1.00
08/20/2025 21:00	0	1.8	10.5	13.7	14.5	1,049,892.0	0.00	1.00
08/20/2025 22:00	-1	1.7	8.0	14.4	7.9	994,412.8	0.00	1.00
08/20/2025 23:00	-1	1.7	8.2	14.4	8.4	976,715.6	0.00	1.00
Average/Sum#:	-1	1.8	9.6	14.0	11.4	965,961.2	0.00 #	24.00 #
Minimum:	-2	1.6	7.9	12.5	6.0	792,631.0	0.00	1.00
Maximum:	2	2.2	14.0	14.6	24.2	1,055,598.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/21/2025 00:00	-1	1.6	8.3	14.5	9.0	993,474.6	0.00	1.00
08/21/2025 01:00	-1	1.6	8.6	14.5	8.8	970,365.6	0.00	1.00
08/21/2025 02:00	-1	1.6	8.6	14.5	9.5	1,003,745.3	0.00	1.00
08/21/2025 03:00	0	1.7	9.2	14.3	11.5	994,907.6	0.00	1.00
08/21/2025 04:00	1	2.0	13.6	13.0	22.5	1,055,843.5	0.00	1.00
08/21/2025 05:00	2	2.1	14.7	12.7	26.7	1,069,320.0	0.00	1.00
08/21/2025 06:00	0	1.8	11.6	13.6	17.3	1,013,374.0	0.00	1.00
08/21/2025 07:00	-2	1.7	8.7	14.3	5.7	803,810.6	0.00	1.00
08/21/2025 08:00	-2	1.7	8.5	14.4	6.2	809,645.8	0.00	1.00
08/21/2025 09:00	-2	1.7	8.5	14.4	6.2	807,328.3	0.00	1.00
08/21/2025 10:00	-2	1.6	8.4	14.4	6.1	815,334.2	0.00	1.00
08/21/2025 11:00	-1	1.7	7.9	14.4	7.0	920,885.2	0.00	1.00
08/21/2025 12:00	0	1.9	11.1	13.5	16.8	1,003,195.9	0.00	1.00
08/21/2025 13:00	4	2.3	14.3	12.2	28.4	1,048,947.6	0.00	1.00
08/21/2025 14:00	4	2.3	14.3	12.1	29.7	1,046,364.7	0.00	1.00
08/21/2025 15:00	4	2.1	14.4	12.3	28.2	1,039,488.6	0.00	1.00
08/21/2025 16:00	2	2.1	13.2	12.8	22.6	1,036,028.7	0.00	1.00
08/21/2025 17:00	2	2.1	12.3	13.0	22.7	1,054,803.5	0.00	1.00
08/21/2025 18:00	5	2.2	13.9	12.0	31.4	1,045,686.3	0.00	1.00
08/21/2025 19:00	2	2.1	13.9	12.6	24.4	1,049,177.1	0.00	1.00
08/21/2025 20:00	3	2.2	14.1	12.4	26.2	1,048,979.1	0.00	1.00
08/21/2025 21:00	2	2.1	13.1	12.8	21.5	1,050,568.3	0.00	1.00
08/21/2025 22:00	1	1.9	11.5	13.4	17.8	1,056,100.1	0.00	1.00
08/21/2025 23:00	1	2.0	12.2	13.2	18.6	1,053,567.5	0.00	1.00
Average/Sum#:	1	1.9	11.5	13.4	17.7	991,289.3	0.00 #	24.00 #
Minimum:	-2	1.6	7.9	12.0	5.7	803,810.6	0.00	1.00
Maximum:	5	2.3	14.7	14.5	31.4	1,069,320.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/22/2025 00:00	0	1.8	10.5	13.8	15.3	1,063,714.9	0.00	1.00
08/22/2025 01:00	-1	1.7	9.7	14.0	11.9	958,001.7	0.00	1.00
08/22/2025 02:00	-2	1.7	8.7	14.3	6.3	798,415.9	0.00	1.00
08/22/2025 03:00	-2	1.7	8.7	14.3	6.5	799,038.4	0.00	1.00
08/22/2025 04:00	-1	1.7	9.2	14.3	10.6	925,813.9	0.00	1.00
08/22/2025 05:00	0	1.8	11.5	13.8	16.4	1,055,614.0	0.00	1.00
08/22/2025 06:00	-1	1.7	10.7	14.0	12.6	973,680.6	0.00	1.00
08/22/2025 07:00	-2	1.7	8.5	14.3	5.4	797,586.0	0.00	1.00
08/22/2025 08:00	-2	1.7	8.5	14.4	6.5	808,381.7	0.00	1.00
08/22/2025 09:00	-2	1.7	8.6	14.4	6.2	805,853.6	0.00	1.00
08/22/2025 10:00	-2	1.7	8.5	14.4	6.6	805,642.9	0.00	1.00
08/22/2025 11:00	-1	1.6	8.0	14.5	7.1	907,243.7	0.00	1.00
08/22/2025 12:00	-1	1.7	8.0	14.4	7.1	906,769.6	0.00	1.00
08/22/2025 13:00	-1	1.7	8.8	14.3	11.2	1,011,506.6	0.00	1.00
08/22/2025 14:00	4	2.3	13.6	12.1	28.1	1,034,537.9	0.00	1.00
08/22/2025 15:00	3	2.1	14.2	12.3	27.0	1,032,004.6	0.00	1.00
08/22/2025 16:00	5	2.3	13.8	12.0	31.5	1,041,685.7	0.00	1.00
08/22/2025 17:00	6	2.3	14.0	11.9	32.3	1,038,784.5	0.00	1.00
08/22/2025 18:00	3	2.1	14.5	12.4	27.0	1,047,368.0	0.00	1.00
08/22/2025 19:00	3	2.1	14.3	12.5	25.6	1,044,675.2	0.00	1.00
08/22/2025 20:00	4	2.3	14.9	12.1	30.5	1,051,655.7	0.00	1.00
08/22/2025 21:00	5	2.3	14.5	12.0	32.4	1,058,149.6	0.00	1.00
08/22/2025 22:00	4	2.2	14.4	12.2	29.4	1,056,817.9	0.00	1.00
08/22/2025 23:00	2	2.1	13.3	12.7	23.1	1,047,275.6	0.00	1.00
Average/Sum#:	1	1.9	11.2	13.4	17.4	961,259.1	0.00 #	24.00 #
Minimum:	-2	1.6	8.0	11.9	5.4	797,586.0	0.00	1.00
Maximum:	6	2.3	14.9	14.5	32.4	1,063,714.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/23/2025 00:00	1	1.9	11.5	13.5	17.4	1,031,694.7	0.00	1.00
08/23/2025 01:00	1	1.9	11.4	13.5	17.3	1,027,068.3	0.00	1.00
08/23/2025 02:00	0	1.8	11.7	13.6	17.8	1,039,824.6	0.00	1.00
08/23/2025 03:00	0	1.9	11.5	13.6	17.2	1,036,635.5	0.00	1.00
08/23/2025 04:00	0	1.8	11.2	13.7	16.8	1,044,376.3	0.00	1.00
08/23/2025 05:00	1	2.0	13.0	13.1	21.5	1,048,838.6	0.00	1.00
08/23/2025 06:00	-2	1.7	9.3	14.2	8.7	897,075.2	0.00	1.00
08/23/2025 07:00	-2	1.7	8.4	14.3	5.8	795,511.1	0.00	1.00
08/23/2025 08:00	-2	1.7	8.5	14.4	6.2	807,539.0	0.00	1.00
08/23/2025 09:00	-1	1.7	8.6	14.3	9.1	917,514.3	0.00	1.00
08/23/2025 10:00	0	1.8	10.8	13.7	14.8	1,047,609.7	0.00	1.00
08/23/2025 11:00	-1	1.6	8.3	14.4	7.9	922,149.3	0.00	1.00
08/23/2025 12:00	1	1.9	11.1	13.5	17.2	1,042,057.9	0.00	1.00
08/23/2025 13:00	5	2.3	13.9	12.0	29.9	1,033,992.3	0.00	1.00
08/23/2025 14:00	6	2.3	13.8	11.9	32.9	1,039,697.4	0.00	1.00
08/23/2025 15:00	5	2.3	13.9	12.1	31.0	1,037,961.4	0.00	1.00
08/23/2025 16:00	5	2.3	14.1	12.0	32.4	1,040,147.1	0.00	1.00
08/23/2025 17:00	2	2.1	13.6	12.7	24.2	1,040,428.5	0.00	1.00
08/23/2025 18:00	2	2.0	13.3	12.9	22.3	1,043,501.4	0.00	1.00
08/23/2025 19:00	0	1.8	11.5	13.6	17.1	1,063,461.2	0.00	1.00
08/23/2025 20:00	0	1.8	11.4	13.6	18.2	1,067,025.5	0.00	1.00
08/23/2025 21:00	2	2.1	13.6	12.8	24.0	1,054,456.8	0.00	1.00
08/23/2025 22:00	2	2.1	14.0	12.7	25.5	1,067,650.0	0.00	1.00
08/23/2025 23:00	2	2.1	14.2	12.7	25.3	1,071,491.1	0.00	1.00
Average/Sum#:	1	1.9	11.8	13.3	19.2	1,009,071.1	0.00 #	24.00 #
Minimum:	-2	1.6	8.3	11.9	5.8	795,511.1	0.00	1.00
Maximum:	6	2.3	14.2	14.4	32.9	1,071,491.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/24/2025 00:00	0	1.8	10.8	13.7	15.5	1,053,315.6	0.00	1.00
08/24/2025 01:00	0	1.8	10.3	13.9	15.4	1,066,390.3	0.00	1.00
08/24/2025 02:00	0	1.8	11.1	13.8	16.4	1,057,157.0	0.00	1.00
08/24/2025 03:00	0	1.8	11.0	13.8	16.4	1,056,578.4	0.00	1.00
08/24/2025 04:00	-1	1.7	8.7	14.3	7.5	864,189.8	0.00	1.00
08/24/2025 05:00	-1	1.7	8.6	14.4	9.0	934,368.8	0.00	1.00
08/24/2025 06:00	-1	1.7	8.6	14.3	7.1	837,423.8	0.00	1.00
08/24/2025 07:00	-1	1.7	8.5	14.3	6.6	807,545.4	0.00	1.00
08/24/2025 08:00	-1	1.7	8.5	14.3	6.9	807,545.4	0.00	1.00
08/24/2025 09:00	-2	1.7	8.5	14.3	6.3	806,300.5	0.00	1.00
08/24/2025 10:00	-2	1.7	8.5	14.4	6.1	819,337.1	0.00	1.00
08/24/2025 11:00	-2	1.7	8.5	14.4	6.1	819,337.1	0.00	1.00
08/24/2025 12:00	-2	1.7	8.4	14.4	6.7	843,776.1	0.00	1.00
08/24/2025 13:00	-1	1.6	8.2	14.5	8.0	925,859.3	0.00	1.00
08/24/2025 14:00	-1	1.7	8.6	14.3	10.0	985,570.6	0.00	1.00
08/24/2025 15:00	1	2.0	11.9	13.2	18.8	1,032,225.9	0.00	1.00
08/24/2025 16:00	3	2.1	13.1	12.5	23.8	1,015,819.4	0.00	1.00
08/24/2025 17:00	2	2.1	12.2	12.9	21.9	1,032,546.0	0.00	1.00
08/24/2025 18:00	2	2.0	12.9	12.8	22.4	1,024,194.2	0.00	1.00
08/24/2025 19:00	2	2.1	14.1	12.6	25.1	1,043,072.4	0.00	1.00
08/24/2025 20:00	0	1.9	11.6	13.4	17.1	1,039,484.4	0.00	1.00
08/24/2025 21:00	0	1.8	10.8	13.6	16.1	1,031,758.1	0.00	1.00
08/24/2025 22:00	1	1.9	11.1	13.6	17.2	1,035,697.5	0.00	1.00
08/24/2025 23:00	1	1.9	11.2	13.6	17.8	1,039,261.8	0.00	1.00
Average/Sum#:	0	1.8	10.2	13.8	13.5	957,448.1	0.00 #	24.00 #
Minimum:	-2	1.6	8.2	12.5	6.1	806,300.5	0.00	1.00
Maximum:	3	2.1	14.1	14.5	25.1	1,066,390.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/25/2025 00:00	0	1.8	10.9	13.7	16.9	1,042,474.3	0.00	1.00
08/25/2025 01:00	0	1.8	10.8	13.8	16.7	1,056,578.4	0.00	1.00
08/25/2025 02:00	0	1.8	11.1	13.8	16.3	1,056,192.7	0.00	1.00
08/25/2025 03:00	0	1.8	10.9	13.8	16.3	1,054,649.7	0.00	1.00
08/25/2025 04:00	0	1.8	10.8	13.8	17.0	1,062,171.8	0.00	1.00
08/25/2025 05:00	1	1.9	11.5	13.5	18.4	1,065,745.3	0.00	1.00
08/25/2025 06:00	2	2.0	13.1	13.0	22.3	1,057,577.0	0.00	1.00
08/25/2025 07:00	-1	1.7	9.2	14.2	8.8	904,433.3	0.00	1.00
08/25/2025 08:00	-2	1.7	8.3	14.3	6.1	799,245.9	0.00	1.00
08/25/2025 09:00	-2	1.7	8.4	14.4	6.8	858,313.1	0.00	1.00
08/25/2025 10:00	-1	1.6	8.4	14.5	8.5	987,055.4	0.00	1.00
08/25/2025 11:00	-2	1.7	8.2	14.4	6.1	839,141.1	0.00	1.00
08/25/2025 12:00	-1	1.6	7.9	14.5	8.6	1,027,924.2	0.00	1.00
08/25/2025 13:00	2	2.1	12.7	12.8	21.6	1,035,014.3	0.00	1.00
08/25/2025 14:00	0	1.9	10.9	13.4	16.1	1,038,023.7	0.00	1.00
08/25/2025 15:00	1	2.0	11.2	13.2	17.5	1,026,534.7	0.00	1.00
08/25/2025 16:00	1	2.0	11.3	13.1	18.5	1,027,946.1	0.00	1.00
08/25/2025 17:00	4	2.2	13.5	12.1	27.5	1,029,713.8	0.00	1.00
08/25/2025 18:00	4	2.2	13.9	12.1	28.6	1,040,295.7	0.00	1.00
08/25/2025 19:00	0	1.9	11.0	13.4	15.7	1,040,032.2	0.00	1.00
08/25/2025 20:00	1	2.0	11.6	13.2	17.4	1,042,185.3	0.00	1.00
08/25/2025 21:00	0	1.8	10.3	13.7	14.7	1,052,745.0	0.00	1.00
08/25/2025 22:00	0	1.8	10.3	13.7	15.9	1,048,560.6	0.00	1.00
08/25/2025 23:00	1	1.9	11.0	13.5	16.9	1,033,175.2	0.00	1.00
Average/Sum#:	0	1.9	10.7	13.6	15.8	1,009,405.4	0.00 #	24.00 #
Minimum:	-2	1.6	7.9	12.1	6.1	799,245.9	0.00	1.00
Maximum:	4	2.2	13.9	14.5	28.6	1,065,745.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/26/2025 00:00	1	1.9	10.8	13.6	16.8	1,040,387.3	0.00	1.00
08/26/2025 01:00	0	1.8	10.8	13.7	16.7	1,046,658.7	0.00	1.00
08/26/2025 02:00	0	1.8	11.0	13.8	16.2	1,054,456.8	0.00	1.00
08/26/2025 03:00	1	1.8	11.0	13.6	17.2	1,038,886.6	0.00	1.00
08/26/2025 04:00	1	1.9	11.6	13.5	19.2	1,060,378.6	0.00	1.00
08/26/2025 05:00	3	2.2	14.0	12.6	27.6	1,068,481.0	0.00	1.00
08/26/2025 06:00	5	2.3	14.9	12.1	33.8	1,067,528.6	0.00	1.00
08/26/2025 07:00	0	1.9	12.0	13.4	17.9	1,055,369.7	0.00	1.00
08/26/2025 08:00	0	1.8	10.8	13.8	16.3	1,059,664.4	0.00	1.00
08/26/2025 09:00	3	1.9	10.7	13.8	18.5	1,019,931.9	0.02	0.33
08/26/2025 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2025 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2025 12:00	0	6.1	12.9	15.5	5.7	979,645.6	0.90	0.90
08/26/2025 13:00	-2	1.7	8.5	14.3	6.0	854,230.3	0.02	1.00
08/26/2025 14:00	-2	1.6	8.7	14.5	6.7	847,759.3	0.00	1.00
08/26/2025 15:00	-1	1.6	8.1	14.5	8.1	988,767.2	0.00	1.00
08/26/2025 16:00	-1	1.6	8.0	14.5	8.8	1,029,422.0	0.00	1.00
08/26/2025 17:00	-1	1.6	7.9	14.5	9.1	1,031,989.7	0.00	1.00
08/26/2025 18:00	3	2.0	11.9	13.0	24.9	1,006,786.9	0.00	1.00
08/26/2025 19:00	5	2.3	14.3	12.0	32.0	1,062,919.5	0.00	1.00
08/26/2025 20:00	5	2.3	14.4	12.0	30.9	1,059,842.2	0.00	1.00
08/26/2025 21:00	5	2.3	14.4	12.0	31.2	1,058,611.2	0.00	1.00
08/26/2025 22:00	4	2.2	14.6	12.1	31.1	1,068,151.0	0.00	1.00
08/26/2025 23:00	0	1.9	11.9	13.3	16.2	1,051,754.0	0.00	1.00
Average/Sum#:	1	2.1	11.5	13.5	18.7	1,025,073.8	0.94 #	21.23 #
Minimum:	-2	1.6	7.9	12.0	5.7	847,759.3	0.00	0.00
Maximum:	5	6.1	14.9	15.5	33.8	1,068,481.0	0.90	1.00
%SI	12.50	8.33	8.33	8.33	8.33	8.33	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/27/2025 00:00	-2	1.6	8.5	14.4	8.5	997,573.0	0.00	1.00
08/27/2025 01:00	-2	1.7	8.7	14.3	7.1	851,533.0	0.00	1.00
08/27/2025 02:00	-1	1.7	8.9	14.3	6.8	813,147.6	0.00	1.00
08/27/2025 03:00	-1	1.7	8.9	14.3	7.0	811,695.2	0.00	1.00
08/27/2025 04:00	-1	1.7	8.8	14.3	7.9	830,576.6	0.00	1.00
08/27/2025 05:00	-1	1.7	8.9	14.3	7.8	836,178.8	0.00	1.00
08/27/2025 06:00	-1	1.7	8.8	14.3	7.2	812,110.2	0.00	1.00
08/27/2025 07:00	-1	1.7	8.8	14.3	6.9	812,317.6	0.00	1.00
08/27/2025 08:00	-1	1.7	8.7	14.3	7.3	812,110.2	0.00	1.00
08/27/2025 09:00	-1	1.7	8.6	14.3	6.9	811,695.2	0.00	1.00
08/27/2025 10:00	-2	1.7	8.6	14.4	6.4	822,708.0	0.00	1.00
08/27/2025 11:00	-2	1.7	8.6	14.4	6.0	819,547.8	0.00	1.00
08/27/2025 12:00	-2	1.6	8.1	14.5	6.5	923,077.6	0.00	1.00
08/27/2025 13:00	-1	1.6	7.8	14.5	7.6	1,025,356.5	0.00	1.00
08/27/2025 14:00	-1	1.6	7.9	14.5	8.1	1,024,500.6	0.00	1.00
08/27/2025 15:00	-1	1.6	7.9	14.5	8.6	1,023,644.7	0.00	1.00
08/27/2025 16:00	-1	1.6	8.1	14.4	7.9	950,380.5	0.00	1.00
08/27/2025 17:00	-1	1.7	8.6	14.3	10.4	994,077.6	0.00	1.00
08/27/2025 18:00	0	1.8	10.4	13.8	15.0	1,063,136.2	0.00	1.00
08/27/2025 19:00	0	1.8	10.3	13.9	14.7	1,074,998.1	0.00	1.00
08/27/2025 20:00	0	1.8	10.8	13.8	15.6	1,063,522.0	0.00	1.00
08/27/2025 21:00	-1	1.7	9.9	14.0	12.1	954,230.8	0.00	1.00
08/27/2025 22:00	-2	1.7	8.4	14.3	6.2	800,698.3	0.00	1.00
08/27/2025 23:00	-1	1.7	8.5	14.3	6.6	801,320.8	0.00	1.00
Average/Sum#:	-1	1.7	8.8	14.3	8.5	905,422.4	0.00 #	24.00 #
Minimum:	-2	1.6	7.8	13.8	6.0	800,698.3	0.00	1.00
Maximum:	0	1.8	10.8	14.5	15.6	1,074,998.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/28/2025 00:00	-1	1.7	8.6	14.3	6.9	801,943.2	0.00	1.00
08/28/2025 01:00	-1	1.7	8.9	14.3	10.6	940,130.6	0.00	1.00
08/28/2025 02:00	0	1.8	11.0	13.9	16.7	1,072,063.7	0.00	1.00
08/28/2025 03:00	0	1.7	10.3	14.1	14.7	1,048,012.4	0.00	1.00
08/28/2025 04:00	-1	1.7	8.9	14.3	8.2	876,224.1	0.00	1.00
08/28/2025 05:00	-1	1.7	8.7	14.3	6.8	812,110.2	0.00	1.00
08/28/2025 06:00	-1	1.7	8.7	14.3	7.9	854,645.3	0.00	1.00
08/28/2025 07:00	-2	1.7	8.6	14.3	6.4	801,943.2	0.00	1.00
08/28/2025 08:00	-2	1.7	8.6	14.3	6.6	801,320.8	0.00	1.00
08/28/2025 09:00	-2	1.7	8.6	14.3	6.0	800,490.8	0.00	1.00
08/28/2025 10:00	-2	1.7	8.6	14.4	5.9	810,909.9	0.00	1.00
08/28/2025 11:00	-2	1.7	8.5	14.4	5.5	809,856.5	0.00	1.00
08/28/2025 12:00	-2	1.7	8.4	14.4	5.9	809,224.5	0.00	1.00
08/28/2025 13:00	-2	1.7	8.1	14.5	6.3	868,514.6	0.00	1.00
08/28/2025 14:00	-2	1.7	8.2	14.4	6.7	871,586.0	0.00	1.00
08/28/2025 15:00	-2	1.6	8.0	14.4	6.3	885,490.9	0.00	1.00
08/28/2025 16:00	-1	1.7	8.7	14.2	9.1	910,769.4	0.00	1.00
08/28/2025 17:00	0	1.8	11.2	13.7	15.9	1,055,027.4	0.00	1.00
08/28/2025 18:00	0	1.8	11.1	13.8	15.0	1,063,329.1	0.00	1.00
08/28/2025 19:00	0	1.8	11.5	13.7	16.3	1,051,794.0	0.00	1.00
08/28/2025 20:00	0	1.9	11.7	13.6	17.3	1,046,015.1	0.00	1.00
08/28/2025 21:00	0	1.9	11.3	13.7	16.9	1,055,978.4	0.00	1.00
08/28/2025 22:00	0	1.8	11.2	13.7	16.9	1,049,892.0	0.00	1.00
08/28/2025 23:00	0	1.8	11.2	13.8	16.8	1,063,329.1	0.00	1.00
Average/Sum#:	-1	1.7	9.5	14.1	10.5	923,358.4	0.00 #	24.00 #
Minimum:	-2	1.6	8.0	13.6	5.5	800,490.8	0.00	1.00
Maximum:	0	1.9	11.7	14.5	17.3	1,072,063.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/29/2025 00:00	0	1.8	11.1	13.8	16.5	1,060,050.2	0.00	1.00
08/29/2025 01:00	-1	1.7	9.9	14.1	12.2	964,638.6	0.00	1.00
08/29/2025 02:00	-2	1.7	8.7	14.3	6.5	801,113.3	0.00	1.00
08/29/2025 03:00	-1	1.7	8.7	14.3	6.5	801,528.2	0.00	1.00
08/29/2025 04:00	-1	1.7	8.7	14.3	6.8	801,528.2	0.00	1.00
08/29/2025 05:00	-1	1.7	8.7	14.3	6.9	802,358.2	0.00	1.00
08/29/2025 06:00	-1	1.7	8.7	14.3	6.8	802,773.2	0.00	1.00
08/29/2025 07:00	-2	1.7	8.6	14.3	6.5	801,735.7	0.00	1.00
08/29/2025 08:00	-1	1.7	8.6	14.3	6.9	801,320.8	0.00	1.00
08/29/2025 09:00	-1	1.7	8.5	14.3	6.7	800,490.8	0.00	1.00
08/29/2025 10:00	-2	1.7	8.5	14.3	6.0	799,245.9	0.00	1.00
08/29/2025 11:00	-2	1.7	8.5	14.4	5.4	810,067.2	0.00	1.00
08/29/2025 12:00	-2	1.7	8.5	14.4	5.1	808,803.1	0.00	1.00
08/29/2025 13:00	-2	1.6	8.5	14.4	5.5	807,960.4	0.00	1.00
08/29/2025 14:00	-2	1.6	8.5	14.5	5.8	819,728.9	0.00	1.00
08/29/2025 15:00	-2	1.6	8.1	14.5	5.5	817,375.2	0.00	1.00
08/29/2025 16:00	-2	1.6	8.2	14.5	6.1	825,078.2	0.00	1.00
08/29/2025 17:00	-2	1.6	8.2	14.6	7.1	923,383.3	0.00	1.00
08/29/2025 18:00	-2	1.6	8.5	14.4	5.7	816,809.0	0.00	1.00
08/29/2025 19:00	-2	1.7	8.5	14.4	5.4	809,435.2	0.00	1.00
08/29/2025 20:00	-2	1.7	8.3	14.4	5.7	816,176.9	0.00	1.00
08/29/2025 21:00	-2	1.7	8.4	14.4	6.3	829,239.1	0.00	1.00
08/29/2025 22:00	-2	1.7	8.5	14.3	6.3	800,490.8	0.00	1.00
08/29/2025 23:00	-2	1.7	8.5	14.3	6.4	798,623.4	0.00	1.00
Average/Sum#:	-2	1.7	8.7	14.3	6.9	829,998.1	0.00 #	24.00 #
Minimum:	-2	1.6	8.1	13.8	5.1	798,623.4	0.00	1.00
Maximum:	0	1.8	11.1	14.6	16.5	1,060,050.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/30/2025 00:00	-2	1.7	8.5	14.3	6.5	799,453.4	0.00	1.00
08/30/2025 01:00	-1	1.7	8.6	14.3	6.7	799,868.3	0.00	1.00
08/30/2025 02:00	-2	1.7	8.8	14.3	6.6	800,490.8	0.00	1.00
08/30/2025 03:00	-1	1.7	8.7	14.3	6.4	799,660.8	0.00	1.00
08/30/2025 04:00	-2	1.7	8.7	14.3	6.6	800,075.8	0.00	1.00
08/30/2025 05:00	-1	1.7	8.8	14.3	7.0	801,113.3	0.00	1.00
08/30/2025 06:00	-2	1.7	8.7	14.3	6.7	800,905.8	0.00	1.00
08/30/2025 07:00	-2	1.7	8.6	14.3	6.2	800,283.3	0.00	1.00
08/30/2025 08:00	-2	1.7	8.6	14.3	5.5	799,038.4	0.00	1.00
08/30/2025 09:00	-2	1.7	8.7	14.4	6.2	809,856.5	0.00	1.00
08/30/2025 10:00	-2	1.6	8.7	14.4	5.5	807,960.4	0.00	1.00
08/30/2025 11:00	-2	1.6	8.5	14.4	5.5	807,749.7	0.00	1.00
08/30/2025 12:00	-2	1.6	8.3	14.5	5.4	819,087.0	0.00	1.00
08/30/2025 13:00	-2	1.6	8.1	14.5	5.3	819,087.0	0.00	1.00
08/30/2025 14:00	-2	1.6	7.9	14.5	4.8	816,733.3	0.00	1.00
08/30/2025 15:00	-2	1.6	7.8	14.5	5.1	815,663.4	0.00	1.00
08/30/2025 16:00	-2	1.6	7.8	14.5	5.6	850,540.9	0.00	1.00
08/30/2025 17:00	-1	1.7	8.6	14.2	8.7	910,565.0	0.00	1.00
08/30/2025 18:00	1	1.9	12.6	13.2	19.2	997,012.1	0.00	1.00
08/30/2025 19:00	2	2.1	14.3	12.6	21.9	941,933.0	0.00	1.00
08/30/2025 20:00	1	2.1	13.4	12.9	20.3	974,003.1	0.00	1.00
08/30/2025 21:00	1	2.0	12.3	13.2	18.4	997,012.1	0.00	1.00
08/30/2025 22:00	1	1.9	11.8	13.3	17.4	1,005,806.2	0.00	1.00
08/30/2025 23:00	-1	1.7	10.1	14.0	12.7	946,887.5	0.00	1.00
Average/Sum#:	-1	1.7	9.5	14.1	9.2	855,032.8	0.00 #	24.00 #
Minimum:	-2	1.6	7.8	12.6	4.8	799,038.4	0.00	1.00
Maximum:	2	2.1	14.3	14.5	21.9	1,005,806.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/31/2025 00:00	-2	1.7	8.5	14.4	6.1	809,645.8	0.00	1.00
08/31/2025 01:00	-2	1.7	8.6	14.4	6.5	809,856.5	0.00	1.00
08/31/2025 02:00	-2	1.7	8.9	14.4	6.8	810,277.9	0.00	1.00
08/31/2025 03:00	-1	1.7	8.8	14.3	6.8	798,415.9	0.00	1.00
08/31/2025 04:00	-1	1.7	8.7	14.3	6.9	798,830.9	0.00	1.00
08/31/2025 05:00	-2	1.7	8.7	14.3	6.7	798,830.9	0.00	1.00
08/31/2025 06:00	-2	1.7	8.7	14.3	6.6	799,453.4	0.00	1.00
08/31/2025 07:00	-2	1.7	8.7	14.4	5.7	810,488.6	0.00	1.00
08/31/2025 08:00	-2	1.7	8.7	14.4	6.3	808,803.1	0.00	1.00
08/31/2025 09:00	-2	1.7	8.6	14.4	5.9	807,117.7	0.00	1.00
08/31/2025 10:00	-2	1.6	8.5	14.5	6.3	818,659.0	0.00	1.00
08/31/2025 11:00	-2	1.6	8.1	14.5	5.2	815,663.4	0.00	1.00
08/31/2025 12:00	-1	1.6	8.0	14.5	6.8	878,357.4	0.00	1.00
08/31/2025 13:00	-1	1.7	8.6	14.2	8.8	904,024.5	0.00	1.00
08/31/2025 14:00	0	1.9	11.2	13.6	15.7	1,044,326.8	0.00	1.00
08/31/2025 15:00	0	1.9	11.1	13.6	15.7	1,044,514.4	0.00	1.00
08/31/2025 16:00	0	1.9	11.3	13.6	16.0	1,051,830.5	0.00	1.00
08/31/2025 17:00	1	2.0	12.3	13.2	18.7	1,048,587.8	0.00	1.00
08/31/2025 18:00	1	2.0	11.9	13.3	17.9	1,057,700.1	0.00	1.00
08/31/2025 19:00	1	2.0	12.8	13.0	19.5	983,212.0	0.00	1.00
08/31/2025 20:00	-2	1.6	8.7	14.4	5.2	844,197.5	0.00	1.00
08/31/2025 21:00	-2	1.7	8.4	14.4	5.9	827,343.0	0.00	1.00
08/31/2025 22:00	-2	1.7	8.5	14.5	7.7	903,606.1	0.00	1.00
08/31/2025 23:00	1	1.9	11.6	13.6	18.2	1,040,950.1	0.00	1.00
Average/Sum#:	-1	1.8	9.5	14.1	9.7	888,112.2	0.00 #	24.00 #
Minimum:	-2	1.6	8.0	13.0	5.2	798,415.9	0.00	1.00
Maximum:	1	2.0	12.8	14.5	19.5	1,057,700.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/01/2025 00:00	0	1.9	11.7	13.6	18.0	1,044,702.0	0.00	1.00
09/01/2025 01:00	0	1.9	11.7	13.7	17.8	1,056,358.8	0.00	1.00
09/01/2025 02:00	0	1.8	11.8	13.7	17.6	1,054,456.8	0.00	1.00
09/01/2025 03:00	0	1.8	11.6	13.7	17.1	1,049,701.8	0.00	1.00
09/01/2025 04:00	0	1.8	11.5	13.8	17.2	1,058,892.9	0.00	1.00
09/01/2025 05:00	0	1.8	11.4	13.8	17.2	1,057,349.9	0.00	1.00
09/01/2025 06:00	0	1.8	10.7	14.0	14.8	1,033,022.3	0.00	1.00
09/01/2025 07:00	-2	1.7	8.7	14.3	4.7	802,980.7	0.00	1.00
09/01/2025 08:00	-2	1.7	8.6	14.4	5.2	809,435.2	0.00	1.00
09/01/2025 09:00	-2	1.6	8.5	14.4	5.2	809,013.8	0.00	1.00
09/01/2025 10:00	-2	1.7	8.7	14.3	7.8	923,531.5	0.00	1.00
09/01/2025 11:00	0	1.9	11.4	13.5	15.8	1,039,097.0	0.00	1.00
09/01/2025 12:00	3	2.2	14.2	12.5	23.2	944,087.7	0.00	1.00
09/01/2025 13:00	4	2.2	13.7	12.3	24.7	933,437.9	0.00	1.00
09/01/2025 14:00	1	2.0	12.1	13.1	18.3	1,038,831.3	0.00	1.00
09/01/2025 15:00	0	1.9	11.1	13.4	16.2	1,037,293.3	0.00	1.00
09/01/2025 16:00	3	2.2	12.6	12.6	25.2	1,046,372.2	0.00	1.00
09/01/2025 17:00	5	2.3	13.7	12.0	31.4	1,043,839.9	0.00	1.00
09/01/2025 18:00	6	2.3	13.6	11.9	31.8	1,046,088.1	0.00	1.00
09/01/2025 19:00	5	2.3	13.7	11.8	31.5	1,041,364.5	0.00	1.00
09/01/2025 20:00	5	2.3	13.9	11.9	31.1	1,046,240.2	0.00	1.00
09/01/2025 21:00	4	2.2	14.3	12.1	29.4	1,054,301.2	0.00	1.00
09/01/2025 22:00	3	2.1	13.3	12.6	24.5	1,052,641.9	0.00	1.00
09/01/2025 23:00	2	2.1	13.0	12.8	21.8	1,051,920.8	0.00	1.00
Average/Sum#:	1	2.0	11.9	13.2	19.5	1,003,123.4	0.00 #	24.00 #
Minimum:	-2	1.6	8.5	11.8	4.7	802,980.7	0.00	1.00
Maximum:	6	2.3	14.3	14.4	31.8	1,058,892.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/02/2025 00:00	0	1.9	10.9	13.6	16.3	1,039,824.6	0.00	1.00
09/02/2025 01:00	1	1.9	10.9	13.6	17.7	1,038,323.8	0.00	1.00
09/02/2025 02:00	0	1.9	11.3	13.6	16.7	1,040,012.2	0.00	1.00
09/02/2025 03:00	1	1.9	11.1	13.6	17.2	1,035,134.8	0.00	1.00
09/02/2025 04:00	3	2.1	13.0	12.8	25.9	1,051,244.5	0.00	1.00
09/02/2025 05:00	5	2.2	14.8	12.1	33.2	1,057,257.9	0.00	1.00
09/02/2025 06:00	4	2.1	14.4	12.4	28.8	1,046,079.1	0.00	1.00
09/02/2025 07:00	5	2.2	14.6	12.2	31.1	1,042,336.6	0.00	1.00
09/02/2025 08:00	4	2.2	14.0	12.1	29.1	1,051,966.9	0.00	1.00
09/02/2025 09:00	1	2.0	12.7	12.8	20.1	1,051,075.5	0.00	1.00
09/02/2025 10:00	0	1.9	11.3	13.3	15.4	1,017,338.2	0.00	1.00
09/02/2025 11:00	2	2.2	12.6	12.5	22.3	1,027,557.4	0.00	1.00
09/02/2025 12:00	5	2.3	13.2	11.9	28.5	1,032,850.3	0.00	1.00
09/02/2025 13:00	4	2.3	13.6	12.1	26.9	1,044,497.3	0.00	1.00
09/02/2025 14:00	5	2.3	13.3	11.8	30.4	1,040,010.1	0.00	1.00
09/02/2025 15:00	5	2.3	13.2	11.8	30.0	1,036,247.9	0.00	1.00
09/02/2025 16:00	5	2.3	13.2	11.8	30.0	1,038,806.2	0.00	1.00
09/02/2025 17:00	5	2.3	13.3	11.8	29.9	1,041,063.5	0.00	1.00
09/02/2025 18:00	5	2.3	13.4	11.8	30.2	1,046,782.0	0.00	1.00
09/02/2025 19:00	5	2.3	13.5	11.9	29.8	1,052,935.2	0.00	1.00
09/02/2025 20:00	5	2.3	13.6	12.0	30.2	1,060,303.8	0.00	1.00
09/02/2025 21:00	5	2.3	13.9	12.0	30.6	1,060,303.8	0.00	1.00
09/02/2025 22:00	4	2.2	14.2	12.1	30.6	1,070,018.4	0.00	1.00
09/02/2025 23:00	4	2.2	14.5	12.2	29.9	1,060,910.4	0.00	1.00
Average/Sum#:	3	2.2	13.1	12.4	26.3	1,045,120.0	0.00 #	24.00 #
Minimum:	0	1.9	10.9	11.8	15.4	1,017,338.2	0.00	1.00
Maximum:	5	2.3	14.8	13.6	33.2	1,070,018.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/03/2025 00:00	2	2.0	12.8	13.0	22.4	1,054,976.8	0.00	1.00
09/03/2025 01:00	0	1.8	10.7	13.8	15.5	1,061,786.1	0.00	1.00
09/03/2025 02:00	0	1.8	11.1	13.8	16.3	1,062,364.7	0.00	1.00
09/03/2025 03:00	0	1.8	10.7	13.8	15.6	1,055,421.2	0.00	1.00
09/03/2025 04:00	1	2.0	12.8	13.1	22.1	1,068,502.2	0.00	1.00
09/03/2025 05:00	2	2.1	14.2	12.7	25.2	1,066,815.0	0.00	1.00
09/03/2025 06:00	0	1.9	11.5	13.6	16.9	1,063,648.8	0.00	1.00
09/03/2025 07:00	0	1.8	10.5	13.9	14.6	1,067,759.8	0.00	1.00
09/03/2025 08:00	0	1.8	10.5	13.8	15.1	1,057,542.8	0.00	1.00
09/03/2025 09:00	0	1.8	10.7	13.7	16.0	1,051,984.2	0.00	1.00
09/03/2025 10:00	0	1.9	10.9	13.5	14.9	1,030,029.2	0.00	1.00
09/03/2025 11:00	0	2.0	11.5	13.3	16.4	1,009,409.9	0.00	1.00
09/03/2025 12:00	1	2.0	12.7	12.9	19.5	1,022,960.0	0.00	1.00
09/03/2025 13:00	1	2.0	11.6	13.2	17.2	1,051,611.2	0.00	1.00
09/03/2025 14:00	3	2.3	13.8	12.2	26.7	1,047,373.5	0.00	1.00
09/03/2025 15:00	5	2.3	13.6	12.0	29.4	1,052,302.6	0.00	1.00
09/03/2025 16:00	4	2.3	13.9	12.1	28.4	1,048,854.6	0.00	1.00
09/03/2025 17:00	5	2.3	13.7	11.9	31.8	1,056,130.5	0.00	1.00
09/03/2025 18:00	5	2.3	13.9	12.0	31.6	1,061,227.0	0.00	1.00
09/03/2025 19:00	2	2.0	14.1	12.7	23.5	1,068,151.0	0.00	1.00
09/03/2025 20:00	2	2.1	14.3	12.6	24.9	1,069,635.9	0.00	1.00
09/03/2025 21:00	4	2.2	15.1	12.3	30.1	1,063,214.7	0.00	1.00
09/03/2025 22:00	3	2.1	14.6	12.7	26.8	1,047,275.6	0.00	1.00
09/03/2025 23:00	0	1.9	11.4	13.6	16.6	1,051,267.7	0.00	1.00
Average/Sum#:	2	2.0	12.5	13.0	21.6	1,053,760.2	0.00 #	24.00 #
Minimum:	0	1.8	10.5	11.9	14.6	1,009,409.9	0.00	1.00
Maximum:	5	2.3	15.1	13.9	31.8	1,069,635.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/04/2025 00:00	0	1.9	10.9	13.7	16.5	1,055,027.4	0.00	1.00
09/04/2025 01:00	0	1.8	10.8	13.7	16.4	1,054,456.8	0.00	1.00
09/04/2025 02:00	0	1.8	11.1	13.7	16.3	1,051,794.0	0.00	1.00
09/04/2025 03:00	0	1.8	10.9	13.8	16.2	1,062,364.7	0.00	1.00
09/04/2025 04:00	0	1.8	11.3	13.6	17.4	1,068,526.2	0.00	1.00
09/04/2025 05:00	3	2.1	14.5	12.5	27.0	1,068,151.0	0.00	1.00
09/04/2025 06:00	0	1.8	11.1	13.7	15.7	1,064,156.9	0.00	1.00
09/04/2025 07:00	0	1.8	10.5	13.9	15.0	1,073,824.3	0.00	1.00
09/04/2025 08:00	0	1.8	10.5	13.8	15.9	1,061,593.2	0.00	1.00
09/04/2025 09:00	0	1.8	10.5	13.7	15.5	1,051,413.6	0.00	1.00
09/04/2025 10:00	0	1.8	10.6	13.6	15.3	1,036,447.9	0.00	1.00
09/04/2025 11:00	0	1.9	10.9	13.5	15.3	1,032,805.1	0.00	1.00
09/04/2025 12:00	0	2.0	11.8	13.2	16.4	1,005,015.2	0.00	1.00
09/04/2025 13:00	1	2.0	12.6	12.9	18.3	977,255.5	0.00	1.00
09/04/2025 14:00	1	2.0	12.7	13.0	19.0	985,985.6	0.00	1.00
09/04/2025 15:00	1	2.0	13.0	12.9	19.0	973,831.9	0.00	1.00
09/04/2025 16:00	2	2.1	13.2	12.7	22.3	1,021,557.2	0.00	1.00
09/04/2025 17:00	0	1.9	11.9	13.3	17.2	1,052,474.7	0.00	1.00
09/04/2025 18:00	2	2.1	13.0	12.8	23.8	1,050,230.2	0.00	1.00
09/04/2025 19:00	2	2.1	13.2	12.8	23.3	1,051,751.7	0.00	1.00
09/04/2025 20:00	0	1.9	10.8	13.6	16.6	1,059,709.4	0.00	1.00
09/04/2025 21:00	0	1.9	10.6	13.6	16.3	1,057,833.4	0.00	1.00
09/04/2025 22:00	0	1.8	10.5	13.7	16.3	1,070,053.0	0.00	1.00
09/04/2025 23:00	0	1.8	10.4	13.7	16.1	1,061,303.9	0.00	1.00
Average/Sum#:	1	1.9	11.6	13.4	17.8	1,043,648.5	0.00 #	24.00 #
Minimum:	0	1.8	10.4	12.5	15.0	973,831.9	0.00	1.00
Maximum:	3	2.1	14.5	13.9	27.0	1,073,824.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/05/2025 00:00	0	1.8	10.3	13.7	16.0	1,061,303.9	0.00	1.00
09/05/2025 01:00	0	1.8	10.3	13.7	16.0	1,060,733.3	0.00	1.00
09/05/2025 02:00	0	1.8	10.7	13.7	16.1	1,059,972.5	0.00	1.00
09/05/2025 03:00	0	1.8	10.6	13.7	15.9	1,060,923.5	0.00	1.00
09/05/2025 04:00	0	1.8	10.5	13.7	16.1	1,059,972.5	0.00	1.00
09/05/2025 05:00	1	1.9	11.5	13.4	19.0	1,072,898.4	0.00	1.00
09/05/2025 06:00	1	1.9	11.8	13.3	18.7	1,063,646.3	0.00	1.00
09/05/2025 07:00	0	1.8	10.3	13.8	15.5	1,072,008.6	0.00	1.00
09/05/2025 08:00	0	1.8	10.3	13.7	16.1	1,057,309.7	0.00	1.00
09/05/2025 09:00	0	1.8	10.4	13.7	15.8	1,061,684.3	0.00	1.00
09/05/2025 10:00	1	1.9	10.6	13.6	16.6	1,050,517.3	0.00	1.00
09/05/2025 11:00	0	1.8	10.4	13.6	15.0	1,033,258.8	0.00	1.00
09/05/2025 12:00	0	1.8	10.5	13.6	14.6	1,036,635.5	0.00	1.00
09/05/2025 13:00	0	1.9	10.7	13.5	14.9	1,028,548.7	0.00	1.00
09/05/2025 14:00	0	1.9	11.0	13.4	15.1	1,015,565.1	0.00	1.00
09/05/2025 15:00	1	2.0	11.4	13.2	16.3	997,367.8	0.00	1.00
09/05/2025 16:00	1	2.0	11.9	13.0	17.7	993,092.7	0.00	1.00
09/05/2025 17:00	0	1.9	11.2	13.3	15.8	1,005,445.8	0.00	1.00
09/05/2025 18:00	0	1.9	10.6	13.5	15.2	1,026,698.2	0.00	1.00
09/05/2025 19:00	0	1.9	10.4	13.6	15.5	1,037,010.7	0.00	1.00
09/05/2025 20:00	0	1.8	10.2	13.7	15.6	1,046,848.9	0.00	1.00
09/05/2025 21:00	0	1.8	10.1	13.8	15.5	1,055,806.9	0.00	1.00
09/05/2025 22:00	0	1.8	10.1	13.8	15.3	1,054,842.5	0.00	1.00
09/05/2025 23:00	0	1.8	10.1	13.8	15.2	1,053,299.5	0.00	1.00
Average/Sum#:	0	1.9	10.7	13.6	16.0	1,044,391.3	0.00 #	24.00 #
Minimum:	0	1.8	10.1	13.0	14.6	993,092.7	0.00	1.00
Maximum:	1	2.0	11.9	13.8	19.0	1,072,898.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/06/2025 00:00	0	1.8	10.0	13.8	15.2	1,052,335.1	0.00	1.00
09/06/2025 01:00	0	1.8	10.0	13.9	15.1	1,065,607.8	0.00	1.00
09/06/2025 02:00	0	1.8	10.4	13.9	15.0	1,063,260.2	0.00	1.00
09/06/2025 03:00	0	1.8	10.2	13.9	14.9	1,062,673.3	0.00	1.00
09/06/2025 04:00	0	1.8	10.1	13.9	14.9	1,062,086.4	0.00	1.00
09/06/2025 05:00	0	1.8	10.1	13.9	14.9	1,062,477.7	0.00	1.00
09/06/2025 06:00	-1	1.7	9.2	14.1	11.0	964,840.0	0.00	1.00
09/06/2025 07:00	-2	1.7	8.0	14.2	4.8	785,477.3	0.00	1.00
09/06/2025 08:00	-2	1.7	8.0	14.3	5.2	796,756.0	0.00	1.00
09/06/2025 09:00	-2	1.7	8.0	14.3	5.0	797,793.4	0.00	1.00
09/06/2025 10:00	-2	1.7	7.9	14.4	5.2	869,479.1	0.00	1.00
09/06/2025 11:00	0	1.9	10.9	13.6	15.1	1,035,885.1	0.00	1.00
09/06/2025 12:00	0	1.8	10.9	13.6	14.2	1,028,381.4	0.00	1.00
09/06/2025 13:00	-1	1.6	8.8	14.3	9.5	976,233.6	0.00	1.00
09/06/2025 14:00	0	1.9	11.4	13.5	15.9	1,027,438.4	0.00	1.00
09/06/2025 15:00	0	1.9	11.8	13.4	16.6	1,014,652.2	0.00	1.00
09/06/2025 16:00	0	1.9	11.7	13.4	16.2	1,014,834.8	0.00	1.00
09/06/2025 17:00	0	1.9	11.3	13.6	15.4	1,037,198.3	0.00	1.00
09/06/2025 18:00	0	1.9	11.2	13.7	15.8	1,048,750.8	0.00	1.00
09/06/2025 19:00	0	1.8	11.0	13.8	16.1	1,057,928.6	0.00	1.00
09/06/2025 20:00	0	1.8	10.9	13.8	15.9	1,055,035.4	0.00	1.00
09/06/2025 21:00	0	1.8	10.8	13.9	15.5	1,066,977.2	0.00	1.00
09/06/2025 22:00	0	1.8	10.7	13.9	15.2	1,064,629.6	0.00	1.00
09/06/2025 23:00	0	1.8	10.6	13.9	15.2	1,063,847.1	0.00	1.00
Average/Sum#:	0	1.8	10.2	13.9	13.2	1,003,107.5	0.00 #	24.00 #
Minimum:	-2	1.6	7.9	13.4	4.8	785,477.3	0.00	1.00
Maximum:	0	1.9	11.8	14.4	16.6	1,066,977.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/07/2025 00:00	0	1.8	10.5	13.9	15.0	1,064,238.4	0.00	1.00
09/07/2025 01:00	0	1.8	10.5	13.9	15.0	1,063,260.2	0.00	1.00
09/07/2025 02:00	0	1.8	10.7	14.0	15.0	1,076,685.1	0.00	1.00
09/07/2025 03:00	0	1.8	10.6	14.0	15.1	1,074,700.4	0.00	1.00
09/07/2025 04:00	0	1.8	10.6	13.9	15.4	1,066,390.3	0.00	1.00
09/07/2025 05:00	0	1.8	10.1	14.0	14.8	1,072,120.4	0.00	1.00
09/07/2025 06:00	-1	1.7	9.5	14.1	10.9	973,096.9	0.00	1.00
09/07/2025 07:00	-2	1.7	8.1	14.3	4.3	798,000.9	0.00	1.00
09/07/2025 08:00	-2	1.7	8.1	14.3	5.1	797,378.5	0.00	1.00
09/07/2025 09:00	-2	1.7	8.2	14.3	4.7	796,963.5	0.00	1.00
09/07/2025 10:00	-2	1.7	8.2	14.3	4.3	795,718.6	0.00	1.00
09/07/2025 11:00	-3	1.7	8.3	14.4	3.9	806,907.0	0.00	1.00
09/07/2025 12:00	-2	1.7	8.7	14.3	7.3	910,252.2	0.00	1.00
09/07/2025 13:00	0	1.9	11.4	13.5	14.8	1,026,513.1	0.00	1.00
09/07/2025 14:00	0	1.9	11.6	13.4	14.9	1,012,826.3	0.00	1.00
09/07/2025 15:00	0	1.9	11.5	13.4	15.4	1,011,730.7	0.00	1.00
09/07/2025 16:00	1	2.0	12.2	13.0	18.4	1,014,067.4	0.00	1.00
09/07/2025 17:00	1	2.1	12.8	12.7	20.8	1,050,949.7	0.00	1.00
09/07/2025 18:00	0	1.9	11.1	13.5	15.1	1,039,467.1	0.00	1.00
09/07/2025 19:00	0	1.9	10.6	13.6	14.9	1,034,009.2	0.00	1.00
09/07/2025 20:00	0	1.8	10.5	13.7	15.3	1,047,229.3	0.00	1.00
09/07/2025 21:00	0	1.8	10.4	13.7	15.6	1,049,511.6	0.00	1.00
09/07/2025 22:00	0	1.8	10.4	13.7	15.6	1,049,892.0	0.00	1.00
09/07/2025 23:00	0	1.9	10.4	13.8	15.6	1,061,979.0	0.00	1.00
Average/Sum#:	-1	1.8	10.2	13.8	12.8	987,245.3	0.00 #	24.00 #
Minimum:	-3	1.7	8.1	12.7	3.9	795,718.6	0.00	1.00
Maximum:	1	2.1	12.8	14.4	20.8	1,076,685.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/08/2025 00:00	0	1.8	10.3	13.9	15.3	1,064,825.3	0.00	1.00
09/08/2025 01:00	0	1.8	10.2	13.9	15.0	1,064,434.0	0.00	1.00
09/08/2025 02:00	0	1.8	10.5	13.9	14.9	1,064,825.3	0.00	1.00
09/08/2025 03:00	0	1.8	10.4	13.9	14.8	1,064,629.6	0.00	1.00
09/08/2025 04:00	0	1.8	10.2	13.9	14.7	1,062,282.1	0.00	1.00
09/08/2025 05:00	0	1.9	11.1	13.6	17.0	1,078,281.0	0.00	1.00
09/08/2025 06:00	0	1.8	10.1	14.0	14.4	1,076,089.7	0.00	1.00
09/08/2025 07:00	0	1.8	10.1	13.9	13.9	1,064,825.3	0.00	1.00
09/08/2025 08:00	0	1.8	9.6	14.0	13.0	1,030,243.8	0.00	1.00
09/08/2025 09:00	-2	1.6	8.0	14.3	4.1	801,943.2	0.00	1.00
09/08/2025 10:00	-2	1.7	7.9	14.3	3.9	796,548.5	0.00	1.00
09/08/2025 11:00	-2	1.7	7.9	14.4	3.7	807,117.7	0.00	1.00
09/08/2025 12:00	-3	1.7	8.1	14.4	3.4	807,328.3	0.00	1.00
09/08/2025 13:00	-2	1.7	8.0	14.5	4.9	881,139.0	0.00	1.00
09/08/2025 14:00	0	1.9	10.9	13.6	14.3	1,030,820.1	0.00	1.00
09/08/2025 15:00	0	1.9	11.3	13.5	15.2	1,027,993.6	0.00	1.00
09/08/2025 16:00	1	2.0	11.7	13.2	18.3	1,036,672.0	0.00	1.00
09/08/2025 17:00	2	2.1	12.9	12.6	23.1	1,041,092.5	0.00	1.00
09/08/2025 18:00	0	1.9	10.9	13.4	15.2	1,038,206.3	0.00	1.00
09/08/2025 19:00	0	1.9	10.4	13.6	15.0	1,038,699.0	0.00	1.00
09/08/2025 20:00	0	1.8	10.1	13.7	14.9	1,044,756.7	0.00	1.00
09/08/2025 21:00	0	1.9	10.5	13.6	15.9	1,048,078.6	0.00	1.00
09/08/2025 22:00	1	1.9	11.2	13.4	17.7	1,054,274.2	0.00	1.00
09/08/2025 23:00	0	1.8	10.0	13.8	14.9	1,053,878.1	0.00	1.00
Average/Sum#:	0	1.8	10.1	13.8	13.2	1,003,291.0	0.00 #	24.00 #
Minimum:	-3	1.6	7.9	12.6	3.4	796,548.5	0.00	1.00
Maximum:	2	2.1	12.9	14.5	23.1	1,078,281.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/09/2025 00:00	0	1.8	9.9	13.8	14.7	1,053,106.6	0.00	1.00
09/09/2025 01:00	0	1.8	9.9	13.8	15.0	1,059,664.4	0.00	1.00
09/09/2025 02:00	0	1.8	10.2	13.8	14.4	1,056,192.7	0.00	1.00
09/09/2025 03:00	0	1.8	10.0	13.8	14.5	1,055,228.3	0.00	1.00
09/09/2025 04:00	0	1.8	9.9	13.8	14.6	1,051,370.7	0.00	1.00
09/09/2025 05:00	1	2.0	12.1	13.1	20.3	1,062,357.3	0.00	1.00
09/09/2025 06:00	0	1.8	9.6	14.0	12.8	1,030,045.3	0.00	1.00
09/09/2025 07:00	-1	1.7	8.9	14.1	10.9	984,374.5	0.00	1.00
09/09/2025 08:00	0	1.8	10.0	13.8	15.1	1,049,249.1	0.00	1.00
09/09/2025 09:00	0	1.8	10.1	13.8	15.7	1,056,771.3	0.00	1.00
09/09/2025 10:00	0	1.8	10.2	13.8	14.0	1,052,913.8	0.00	1.00
09/09/2025 11:00	0	1.8	10.2	13.7	14.9	1,041,333.1	0.00	1.00
09/09/2025 12:00	-1	1.6	8.5	14.3	9.6	975,403.6	0.00	1.00
09/09/2025 13:00	0	1.9	10.8	13.6	14.5	1,027,818.7	0.00	1.00
09/09/2025 14:00	0	1.9	10.9	13.6	14.8	1,029,694.6	0.00	1.00
09/09/2025 15:00	0	1.9	10.9	13.6	14.8	1,028,569.0	0.00	1.00
09/09/2025 16:00	0	1.9	10.9	13.6	14.7	1,028,006.2	0.00	1.00
09/09/2025 17:00	0	1.8	10.9	13.7	15.1	1,040,191.9	0.00	1.00
09/09/2025 18:00	0	1.8	10.7	13.7	14.9	1,037,909.6	0.00	1.00
09/09/2025 19:00	0	1.8	10.6	13.8	14.9	1,051,563.6	0.00	1.00
09/09/2025 20:00	0	1.8	10.5	13.8	14.9	1,049,827.7	0.00	1.00
09/09/2025 21:00	0	1.8	10.5	13.8	15.2	1,052,335.1	0.00	1.00
09/09/2025 22:00	0	1.8	10.6	13.8	15.2	1,051,756.5	0.00	1.00
09/09/2025 23:00	0	1.8	10.5	13.8	15.0	1,050,406.4	0.00	1.00
Average/Sum#:	0	1.8	10.3	13.8	14.6	1,040,670.4	0.00 #	24.00 #
Minimum:	-1	1.6	8.5	13.1	9.6	975,403.6	0.00	1.00
Maximum:	1	2.0	12.1	14.3	20.3	1,062,357.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/10/2025 00:00	0	1.8	10.5	13.8	14.9	1,047,899.0	0.00	1.00
09/10/2025 01:00	0	1.8	10.5	13.9	14.9	1,061,695.2	0.00	1.00
09/10/2025 02:00	0	1.8	10.8	13.9	14.8	1,061,695.2	0.00	1.00
09/10/2025 03:00	0	1.9	10.6	13.9	14.8	1,061,108.3	0.00	1.00
09/10/2025 04:00	0	1.8	10.6	13.9	14.6	1,061,890.8	0.00	1.00
09/10/2025 05:00	0	1.8	10.6	13.9	14.9	1,064,825.3	0.00	1.00
09/10/2025 06:00	0	1.8	10.7	13.8	14.9	1,057,735.7	0.00	1.00
09/10/2025 07:00	-1	1.7	9.5	14.1	10.5	963,228.9	0.00	1.00
09/10/2025 08:00	-1	1.7	8.3	14.3	8.2	915,646.9	0.00	1.00
09/10/2025 09:00	0	1.8	10.6	13.8	14.3	1,052,528.0	0.00	1.00
09/10/2025 10:00	-2	1.7	8.3	14.3	5.0	844,893.3	0.00	1.00
09/10/2025 11:00	-2	1.7	8.0	14.3	3.7	792,191.3	0.00	1.00
09/10/2025 12:00	-2	1.7	8.1	14.3	3.8	791,568.8	0.00	1.00
09/10/2025 13:00	-3	1.7	8.2	14.3	3.6	791,568.8	0.00	1.00
09/10/2025 14:00	-2	1.7	8.0	14.4	4.4	862,316.0	0.00	1.00
09/10/2025 15:00	0	1.9	10.9	13.7	14.1	1,033,915.4	0.00	1.00
09/10/2025 16:00	0	1.9	11.2	13.6	14.7	1,030,632.5	0.00	1.00
09/10/2025 17:00	-1	1.8	11.0	13.7	13.8	1,037,148.8	0.00	1.00
09/10/2025 18:00	-1	1.8	10.9	13.7	14.1	1,035,056.6	0.00	1.00
09/10/2025 19:00	0	1.8	10.7	13.8	14.2	1,047,127.5	0.00	1.00
09/10/2025 20:00	0	1.8	10.5	13.9	14.1	1,057,586.9	0.00	1.00
09/10/2025 21:00	0	1.8	10.5	13.9	14.6	1,055,630.6	0.00	1.00
09/10/2025 22:00	0	1.8	10.5	13.9	14.5	1,057,391.3	0.00	1.00
09/10/2025 23:00	0	1.8	10.5	13.9	14.5	1,055,434.9	0.00	1.00
Average/Sum#:	-1	1.8	10.0	14.0	11.9	993,363.2	0.00 #	24.00 #
Minimum:	-3	1.7	8.0	13.6	3.6	791,568.8	0.00	1.00
Maximum:	0	1.9	11.2	14.4	14.9	1,064,825.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/11/2025 00:00	0	1.8	10.4	13.9	14.3	1,052,696.1	0.00	1.00
09/11/2025 01:00	0	1.8	10.4	13.9	14.3	1,053,087.4	0.00	1.00
09/11/2025 02:00	-1	1.8	10.7	14.0	14.3	1,067,555.6	0.00	1.00
09/11/2025 03:00	-1	1.8	10.6	14.0	14.1	1,066,761.7	0.00	1.00
09/11/2025 04:00	-1	1.8	10.5	14.0	14.2	1,066,166.3	0.00	1.00
09/11/2025 05:00	0	1.8	10.4	13.9	14.4	1,056,021.8	0.00	1.00
09/11/2025 06:00	-1	1.8	10.1	14.0	13.7	1,065,174.0	0.00	1.00
09/11/2025 07:00	-1	1.8	10.0	14.0	13.4	1,065,174.0	0.00	1.00
09/11/2025 08:00	0	1.8	10.0	13.9	13.9	1,050,739.8	0.00	1.00
09/11/2025 09:00	0	1.8	10.1	13.8	14.0	1,041,534.0	0.00	1.00
09/11/2025 10:00	0	1.8	10.0	13.9	13.7	1,055,043.7	0.00	1.00
09/11/2025 11:00	-1	1.8	9.7	13.9	11.6	1,008,092.0	0.00	1.00
09/11/2025 12:00	-2	1.7	8.4	14.3	6.6	910,667.2	0.00	1.00
09/11/2025 13:00	-1	1.9	10.8	13.6	13.1	1,031,007.7	0.00	1.00
09/11/2025 14:00	-1	1.9	10.8	13.6	13.2	1,025,567.5	0.00	1.00
09/11/2025 15:00	-1	1.9	10.9	13.6	13.1	1,023,691.6	0.00	1.00
09/11/2025 16:00	0	1.8	11.1	13.5	14.5	1,017,260.2	0.00	1.00
09/11/2025 17:00	-1	1.9	11.2	13.6	14.1	1,029,319.4	0.00	1.00
09/11/2025 18:00	0	1.9	11.2	13.6	14.3	1,028,006.2	0.00	1.00
09/11/2025 19:00	0	1.9	11.2	13.6	15.7	1,028,756.6	0.00	1.00
09/11/2025 20:00	0	1.9	11.1	13.6	15.2	1,039,637.0	0.00	1.00
09/11/2025 21:00	0	1.9	11.0	13.6	15.6	1,046,765.5	0.00	1.00
09/11/2025 22:00	0	1.8	10.5	13.7	14.9	1,044,376.3	0.00	1.00
09/11/2025 23:00	0	1.8	10.2	13.8	14.9	1,051,370.7	0.00	1.00
Average/Sum#:	-1	1.8	10.5	13.8	13.8	1,038,519.7	0.00 #	24.00 #
Minimum:	-2	1.7	8.4	13.5	6.6	910,667.2	0.00	1.00
Maximum:	0	1.9	11.2	14.3	15.7	1,067,555.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/12/2025 00:00	0	1.8	10.1	13.8	14.9	1,051,177.9	0.00	1.00
09/12/2025 01:00	0	1.8	10.0	13.8	15.0	1,045,198.7	0.00	1.00
09/12/2025 02:00	0	1.8	10.3	13.9	14.8	1,058,956.3	0.00	1.00
09/12/2025 03:00	0	1.8	10.2	13.9	14.6	1,060,717.0	0.00	1.00
09/12/2025 04:00	0	1.8	10.2	13.8	14.7	1,049,249.1	0.00	1.00
09/12/2025 05:00	0	1.8	10.0	13.9	14.2	1,054,456.8	0.00	1.00
09/12/2025 06:00	0	1.8	10.0	13.9	14.0	1,054,456.8	0.00	1.00
09/12/2025 07:00	-1	1.7	9.1	14.1	9.9	957,388.8	0.00	1.00
09/12/2025 08:00	-1	1.7	8.2	14.2	8.0	898,914.7	0.00	1.00
09/12/2025 09:00	0	1.8	10.0	13.8	14.4	1,049,249.1	0.00	1.00
09/12/2025 10:00	-2	1.7	8.6	14.2	6.9	888,490.7	0.00	1.00
09/12/2025 11:00	-3	1.7	7.9	14.4	3.2	801,850.6	0.00	1.00
09/12/2025 12:00	-3	1.7	8.1	14.4	2.8	801,429.3	0.00	1.00
09/12/2025 13:00	-3	1.7	8.0	14.4	2.8	814,280.8	0.00	1.00
09/12/2025 14:00	0	1.8	10.4	13.7	13.2	982,562.0	0.00	1.00
09/12/2025 15:00	0	1.9	11.3	13.4	14.4	1,007,531.2	0.00	1.00
09/12/2025 16:00	0	1.9	11.3	13.3	14.7	996,616.6	0.00	1.00
09/12/2025 17:00	0	2.0	11.3	13.3	14.5	995,895.9	0.00	1.00
09/12/2025 18:00	0	1.9	11.1	13.5	14.3	1,017,630.4	0.00	1.00
09/12/2025 19:00	0	1.9	11.0	13.6	14.7	1,028,569.0	0.00	1.00
09/12/2025 20:00	0	1.8	10.8	13.7	14.6	1,038,670.4	0.00	1.00
09/12/2025 21:00	0	1.8	10.7	13.7	14.6	1,038,099.8	0.00	1.00
09/12/2025 22:00	0	1.8	10.7	13.7	15.0	1,037,148.8	0.00	1.00
09/12/2025 23:00	0	1.8	10.6	13.8	14.9	1,049,056.2	0.00	1.00
Average/Sum#:	-1	1.8	10.0	13.8	12.3	990,733.2	0.00 #	24.00 #
Minimum:	-3	1.7	7.9	13.3	2.8	801,429.3	0.00	1.00
Maximum:	0	2.0	11.3	14.4	15.0	1,060,717.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/13/2025 00:00	0	1.8	10.6	13.8	15.1	1,045,584.4	0.00	1.00
09/13/2025 01:00	0	1.8	10.5	13.9	14.9	1,058,760.7	0.00	1.00
09/13/2025 02:00	0	1.8	10.8	13.9	14.7	1,056,413.1	0.00	1.00
09/13/2025 03:00	-1	1.8	10.6	13.9	14.7	1,055,826.2	0.00	1.00
09/13/2025 04:00	0	1.8	10.5	14.0	14.6	1,068,548.0	0.00	1.00
09/13/2025 05:00	0	1.8	10.4	14.0	14.6	1,068,746.4	0.00	1.00
09/13/2025 06:00	-1	1.8	10.0	14.0	12.9	1,019,725.0	0.00	1.00
09/13/2025 07:00	-2	1.7	8.2	14.2	4.2	785,068.5	0.00	1.00
09/13/2025 08:00	-2	1.7	8.1	14.3	4.9	796,756.0	0.00	1.00
09/13/2025 09:00	-2	1.7	8.1	14.3	4.7	796,341.0	0.00	1.00
09/13/2025 10:00	-2	1.7	8.1	14.3	4.2	795,096.1	0.00	1.00
09/13/2025 11:00	-3	1.7	8.1	14.3	3.6	793,643.7	0.00	1.00
09/13/2025 12:00	-3	1.7	8.1	14.4	3.4	805,010.9	0.00	1.00
09/13/2025 13:00	-3	1.7	8.1	14.4	3.3	804,800.2	0.00	1.00
09/13/2025 14:00	-3	1.6	8.1	14.4	3.0	804,168.1	0.00	1.00
09/13/2025 15:00	-3	1.6	8.1	14.4	3.3	804,378.8	0.00	1.00
09/13/2025 16:00	-1	1.8	8.9	14.2	7.8	896,053.2	0.00	1.00
09/13/2025 17:00	0	1.9	11.0	13.4	15.1	1,014,469.6	0.00	1.00
09/13/2025 18:00	0	1.9	10.6	13.5	14.7	1,022,626.9	0.00	1.00
09/13/2025 19:00	0	1.9	10.4	13.7	15.0	1,043,805.7	0.00	1.00
09/13/2025 20:00	0	1.8	10.3	13.7	15.5	1,041,903.7	0.00	1.00
09/13/2025 21:00	0	1.8	10.3	13.8	15.5	1,053,299.5	0.00	1.00
09/13/2025 22:00	0	1.8	10.2	13.8	15.6	1,049,056.2	0.00	1.00
09/13/2025 23:00	0	1.8	10.2	13.9	15.7	1,063,455.9	0.00	1.00
Average/Sum#:	-1	1.8	9.5	14.0	10.5	947,647.4	0.00 #	24.00 #
Minimum:	-3	1.6	8.1	13.4	3.0	785,068.5	0.00	1.00
Maximum:	0	1.9	11.0	14.4	15.7	1,068,746.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/14/2025 00:00	0	1.8	10.1	13.9	15.5	1,061,695.2	0.00	1.00
09/14/2025 01:00	0	1.8	10.1	13.9	15.6	1,059,543.2	0.00	1.00
09/14/2025 02:00	0	1.8	10.4	13.9	15.5	1,057,978.2	0.00	1.00
09/14/2025 03:00	0	1.8	10.4	13.9	15.3	1,057,586.9	0.00	1.00
09/14/2025 04:00	0	1.8	10.2	13.9	15.3	1,056,413.1	0.00	1.00
09/14/2025 05:00	0	1.8	10.1	13.9	15.3	1,056,413.1	0.00	1.00
09/14/2025 06:00	-1	1.7	9.3	14.1	10.9	952,354.1	0.00	1.00
09/14/2025 07:00	-2	1.7	8.1	14.3	4.9	795,511.1	0.00	1.00
09/14/2025 08:00	-2	1.7	8.2	14.3	5.7	795,511.1	0.00	1.00
09/14/2025 09:00	-2	1.7	8.2	14.3	5.4	794,681.1	0.00	1.00
09/14/2025 10:00	-2	1.7	8.2	14.3	5.0	794,681.1	0.00	1.00
09/14/2025 11:00	-2	1.7	8.3	14.4	4.3	806,274.9	0.00	1.00
09/14/2025 12:00	-3	1.7	8.3	14.4	4.1	805,432.2	0.00	1.00
09/14/2025 13:00	-3	1.7	8.3	14.4	3.9	804,800.2	0.00	1.00
09/14/2025 14:00	-3	1.7	8.4	14.4	3.9	803,746.8	0.00	1.00
09/14/2025 15:00	-3	1.7	8.4	14.4	3.9	803,746.8	0.00	1.00
09/14/2025 16:00	-1	1.7	9.2	14.2	9.1	894,009.3	0.00	1.00
09/14/2025 17:00	0	1.9	11.5	13.4	15.9	1,012,643.7	0.00	1.00
09/14/2025 18:00	0	1.9	11.2	13.5	16.1	1,019,666.0	0.00	1.00
09/14/2025 19:00	0	1.9	10.7	13.6	16.0	1,029,319.4	0.00	1.00
09/14/2025 20:00	0	1.8	10.1	13.7	14.1	1,042,093.9	0.00	1.00
09/14/2025 21:00	0	1.9	10.0	13.7	14.4	1,042,854.7	0.00	1.00
09/14/2025 22:00	0	1.8	10.1	13.7	15.3	1,043,235.1	0.00	1.00
09/14/2025 23:00	0	1.8	10.0	13.7	15.0	1,040,001.7	0.00	1.00
Average/Sum#:	-1	1.8	9.5	14.0	10.9	942,924.7	0.00 #	24.00 #
Minimum:	-3	1.7	8.1	13.4	3.9	794,681.1	0.00	1.00
Maximum:	0	1.9	11.5	14.4	16.1	1,061,695.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/15/2025 00:00	0	1.8	10.0	13.8	15.0	1,052,720.9	0.00	1.00
09/15/2025 01:00	0	1.8	10.0	13.8	15.1	1,049,634.9	0.00	1.00
09/15/2025 02:00	0	1.8	10.4	13.8	15.1	1,047,127.5	0.00	1.00
09/15/2025 03:00	0	1.8	10.2	13.9	14.9	1,060,130.1	0.00	1.00
09/15/2025 04:00	0	1.8	10.1	13.9	15.0	1,055,043.7	0.00	1.00
09/15/2025 05:00	0	1.8	10.0	14.0	14.9	1,061,204.7	0.00	1.00
09/15/2025 06:00	0	1.8	10.0	14.0	14.6	1,062,197.0	0.00	1.00
09/15/2025 07:00	0	1.8	10.1	13.9	14.3	1,053,283.0	0.00	1.00
09/15/2025 08:00	0	1.8	10.2	13.8	15.2	1,047,320.3	0.00	1.00
09/15/2025 09:00	0	1.8	10.3	13.7	14.2	1,037,529.2	0.00	1.00
09/15/2025 10:00	-1	1.7	8.4	14.3	8.2	970,631.4	0.00	1.00
09/15/2025 11:00	0	1.9	10.8	13.5	13.3	1,021,146.5	0.00	1.00
09/15/2025 12:00	0	1.9	11.2	13.3	13.9	1,003,643.9	0.00	1.00
09/15/2025 13:00	1	2.0	11.8	13.0	15.9	974,891.5	0.00	1.00
09/15/2025 14:00	2	2.2	13.5	12.4	22.4	1,016,918.4	0.00	1.00
09/15/2025 15:00	2	2.1	12.6	12.8	20.8	996,467.6	0.00	1.00
09/15/2025 16:00	2	2.0	13.2	12.7	21.4	1,002,351.8	0.00	1.00
09/15/2025 17:00	0	1.9	10.7	13.5	13.8	1,039,467.1	0.00	1.00
09/15/2025 18:00	0	1.9	10.7	13.5	14.7	1,041,872.9	0.00	1.00
09/15/2025 19:00	0	1.8	10.0	13.8	13.5	1,051,563.6	0.00	1.00
09/15/2025 20:00	0	1.8	9.9	13.8	14.9	1,047,320.3	0.00	1.00
09/15/2025 21:00	0	1.8	9.9	13.8	14.5	1,046,934.6	0.00	1.00
09/15/2025 22:00	0	1.8	9.8	13.9	14.2	1,059,934.5	0.00	1.00
09/15/2025 23:00	0	1.8	9.8	13.9	14.6	1,057,586.9	0.00	1.00
Average/Sum#:	0	1.9	10.6	13.6	15.2	1,035,705.1	0.00 #	24.00 #
Minimum:	-1	1.7	8.4	12.4	8.2	970,631.4	0.00	1.00
Maximum:	2	2.2	13.5	14.3	22.4	1,062,197.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/16/2025 00:00	0	1.8	9.8	13.9	15.2	1,056,804.4	0.00	1.00
09/16/2025 01:00	0	1.8	9.9	13.9	14.8	1,059,347.6	0.00	1.00
09/16/2025 02:00	0	1.8	10.3	13.9	15.0	1,058,369.4	0.00	1.00
09/16/2025 03:00	0	1.8	10.2	13.9	14.7	1,056,608.7	0.00	1.00
09/16/2025 04:00	0	1.8	10.1	14.0	15.1	1,066,960.2	0.00	1.00
09/16/2025 05:00	0	1.8	10.2	13.9	15.1	1,054,652.4	0.00	1.00
09/16/2025 06:00	0	1.8	10.3	13.9	15.5	1,054,652.4	0.00	1.00
09/16/2025 07:00	0	1.8	10.3	13.9	15.2	1,060,325.7	0.00	1.00
09/16/2025 08:00	0	1.8	10.5	13.7	15.0	1,040,762.5	0.00	1.00
09/16/2025 09:00	0	1.9	10.6	13.6	15.1	1,035,134.8	0.00	1.00
09/16/2025 10:00	0	1.9	10.9	13.4	15.2	1,012,278.5	0.00	1.00
09/16/2025 11:00	1	2.0	11.6	13.1	16.1	982,298.6	0.00	1.00
09/16/2025 12:00	1	2.0	12.8	12.9	18.3	968,525.4	0.00	1.00
09/16/2025 13:00	2	2.1	13.4	12.7	19.8	952,418.0	0.00	1.00
09/16/2025 14:00	2	2.1	13.8	12.6	20.8	942,593.0	0.00	1.00
09/16/2025 15:00	0	1.9	10.8	13.4	13.4	1,015,382.5	0.00	1.00
09/16/2025 16:00	0	1.9	10.5	13.5	13.5	1,039,837.2	0.00	1.00
09/16/2025 17:00	0	1.9	10.0	13.6	12.8	1,037,573.5	0.00	1.00
09/16/2025 18:00	0	1.9	9.8	13.6	12.3	1,035,322.4	0.00	1.00
09/16/2025 19:00	0	1.9	10.3	13.5	14.4	1,023,737.3	0.00	1.00
09/16/2025 20:00	1	1.9	10.8	13.3	16.6	997,877.9	0.00	1.00
09/16/2025 21:00	1	1.9	10.5	13.5	15.8	1,022,256.8	0.00	1.00
09/16/2025 22:00	0	1.9	10.3	13.7	15.4	1,043,805.7	0.00	1.00
09/16/2025 23:00	0	1.8	10.4	13.7	15.5	1,044,186.1	0.00	1.00
Average/Sum#:	0	1.9	10.8	13.5	15.4	1,027,571.3	0.00 #	24.00 #
Minimum:	0	1.8	9.8	12.6	12.3	942,593.0	0.00	1.00
Maximum:	2	2.1	13.8	14.0	20.8	1,066,960.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/17/2025 00:00	0	1.8	10.4	13.7	15.4	1,043,044.9	0.00	1.00
09/17/2025 01:00	0	1.8	10.4	13.7	15.7	1,040,762.5	0.00	1.00
09/17/2025 02:00	0	1.8	10.8	13.7	15.9	1,043,995.9	0.00	1.00
09/17/2025 03:00	0	1.8	10.6	13.8	15.6	1,056,192.7	0.00	1.00
09/17/2025 04:00	0	1.8	10.3	13.9	15.2	1,063,455.9	0.00	1.00
09/17/2025 05:00	0	1.8	10.2	13.9	15.5	1,053,087.4	0.00	1.00
09/17/2025 06:00	0	1.8	10.2	14.0	15.1	1,065,967.9	0.00	1.00
09/17/2025 07:00	0	1.8	10.3	13.9	14.5	1,059,151.9	0.00	1.00
09/17/2025 08:00	0	1.9	10.4	13.7	15.3	1,043,615.5	0.00	1.00
09/17/2025 09:00	0	1.9	10.7	13.5	15.5	1,022,626.9	0.00	1.00
09/17/2025 10:00	1	2.0	11.4	13.2	16.1	992,032.4	0.00	1.00
09/17/2025 11:00	1	2.0	12.6	12.9	18.1	964,759.5	0.00	1.00
09/17/2025 12:00	2	2.1	13.5	12.6	19.8	939,623.1	0.00	1.00
09/17/2025 13:00	3	2.2	14.0	12.4	22.1	926,697.5	0.00	1.00
09/17/2025 14:00	0	1.8	10.9	13.4	14.4	1,039,301.8	0.00	1.00
09/17/2025 15:00	0	1.9	10.8	13.4	15.2	1,031,450.4	0.00	1.00
09/17/2025 16:00	0	1.8	10.3	13.6	14.1	1,035,509.9	0.00	1.00
09/17/2025 17:00	3	2.1	14.0	12.5	23.5	932,186.7	0.00	1.00
09/17/2025 18:00	2	2.1	14.0	12.6	21.5	939,953.1	0.00	1.00
09/17/2025 19:00	1	2.1	13.0	12.9	19.1	962,020.6	0.00	1.00
09/17/2025 20:00	1	2.0	12.0	13.2	17.1	989,364.7	0.00	1.00
09/17/2025 21:00	1	1.9	11.2	13.4	16.8	1,003,696.8	0.00	1.00
09/17/2025 22:00	1	1.9	11.0	13.5	16.6	1,018,925.8	0.00	1.00
09/17/2025 23:00	1	1.9	11.0	13.5	17.3	1,016,890.1	0.00	1.00
Average/Sum#:	1	1.9	11.4	13.4	16.9	1,011,846.4	0.00 #	24.00 #
Minimum:	0	1.8	10.2	12.4	14.1	926,697.5	0.00	1.00
Maximum:	3	2.2	14.0	14.0	23.5	1,065,967.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/18/2025 00:00	1	1.9	11.0	13.6	17.1	1,028,756.6	0.00	1.00
09/18/2025 01:00	1	1.9	10.8	13.6	16.9	1,027,255.9	0.00	1.00
09/18/2025 02:00	0	1.8	11.1	13.6	17.1	1,028,006.2	0.00	1.00
09/18/2025 03:00	0	1.8	10.9	13.7	16.1	1,037,719.4	0.00	1.00
09/18/2025 04:00	0	1.8	10.7	13.7	16.3	1,033,535.0	0.00	1.00
09/18/2025 05:00	1	1.8	10.4	13.8	16.8	1,039,991.0	0.00	1.00
09/18/2025 06:00	1	1.8	10.5	13.8	17.4	1,049,056.2	0.00	1.00
09/18/2025 07:00	1	2.0	12.4	13.2	20.5	1,042,896.7	0.00	1.00
09/18/2025 08:00	0	1.9	10.7	13.7	15.5	1,041,333.1	0.00	1.00
09/18/2025 09:00	1	1.9	11.3	13.4	16.9	1,021,955.8	0.00	1.00
09/18/2025 10:00	0	1.9	11.4	13.4	16.3	1,011,730.7	0.00	1.00
09/18/2025 11:00	1	2.0	11.6	13.2	16.3	994,166.5	0.00	1.00
09/18/2025 12:00	1	2.0	12.0	13.0	16.8	976,798.3	0.00	1.00
09/18/2025 13:00	2	2.1	13.2	12.7	20.5	965,110.2	0.00	1.00
09/18/2025 14:00	1	2.0	12.5	13.0	17.2	977,145.0	0.00	1.00
09/18/2025 15:00	1	2.1	12.9	12.8	19.8	996,805.7	0.00	1.00
09/18/2025 16:00	0	1.9	11.8	13.3	16.8	1,010,130.7	0.00	1.00
09/18/2025 17:00	0	1.9	11.7	13.3	16.5	1,004,905.2	0.00	1.00
09/18/2025 18:00	0	1.9	11.0	13.5	15.7	1,022,441.9	0.00	1.00
09/18/2025 19:00	0	1.9	10.9	13.5	15.8	1,020,406.2	0.00	1.00
09/18/2025 20:00	0	1.9	10.8	13.6	15.7	1,033,071.2	0.00	1.00
09/18/2025 21:00	0	1.9	10.7	13.6	16.0	1,031,758.1	0.00	1.00
09/18/2025 22:00	1	1.9	10.6	13.6	16.5	1,031,007.7	0.00	1.00
09/18/2025 23:00	1	1.8	10.5	13.6	16.4	1,029,694.6	0.00	1.00
Average/Sum#:	1	1.9	11.3	13.4	17.0	1,018,986.6	0.00 #	24.00 #
Minimum:	0	1.8	10.4	12.7	15.5	965,110.2	0.00	1.00
Maximum:	2	2.1	13.2	13.8	20.5	1,049,056.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/19/2025 00:00	0	1.8	10.4	13.6	15.8	1,028,944.2	0.00	1.00
09/19/2025 01:00	0	1.9	10.0	13.6	14.9	1,030,069.8	0.00	1.00
09/19/2025 02:00	0	1.8	10.3	13.6	14.8	1,030,257.4	0.00	1.00
09/19/2025 03:00	0	1.8	10.0	13.7	14.2	1,044,566.5	0.00	1.00
09/19/2025 04:00	0	1.8	9.9	13.7	14.5	1,044,946.9	0.00	1.00
09/19/2025 05:00	0	1.8	9.8	13.7	14.2	1,045,707.7	0.00	1.00
09/19/2025 06:00	0	1.9	10.0	13.6	14.7	1,044,139.2	0.00	1.00
09/19/2025 07:00	0	1.8	9.6	13.8	13.6	1,048,477.6	0.00	1.00
09/19/2025 08:00	0	1.8	9.6	13.7	13.3	1,038,099.8	0.00	1.00
09/19/2025 09:00	0	1.8	9.6	13.7	12.9	1,039,621.3	0.00	1.00
09/19/2025 10:00	0	1.8	9.7	13.7	12.7	1,038,670.4	0.00	1.00
09/19/2025 11:00	0	1.8	9.7	13.7	13.0	1,040,191.9	0.00	1.00
09/19/2025 12:00	0	1.9	9.6	13.7	14.1	1,038,099.8	0.00	1.00
09/19/2025 13:00	0	1.9	9.8	13.6	14.9	1,025,755.1	0.00	1.00
09/19/2025 14:00	0	1.9	10.2	13.5	14.6	1,030,399.3	0.00	1.00
09/19/2025 15:00	0	1.9	10.0	13.5	13.4	1,020,406.2	0.00	1.00
09/19/2025 16:00	0	1.9	10.1	13.5	13.7	1,026,143.0	0.00	1.00
09/19/2025 17:00	0	1.8	10.0	13.6	13.5	1,033,258.8	0.00	1.00
09/19/2025 18:00	0	1.9	9.9	13.6	13.4	1,032,696.1	0.00	1.00
09/19/2025 19:00	0	1.9	9.8	13.6	13.3	1,029,507.0	0.00	1.00
09/19/2025 20:00	1	1.9	10.0	13.5	15.3	1,028,363.7	0.00	1.00
09/19/2025 21:00	2	2.1	12.7	12.7	21.1	1,035,251.4	0.00	1.00
09/19/2025 22:00	0	1.9	10.8	13.4	15.2	1,039,484.4	0.00	1.00
09/19/2025 23:00	0	1.8	9.8	13.7	13.0	1,041,523.3	0.00	1.00
Average/Sum#:	0	1.9	10.1	13.6	14.3	1,035,607.5	0.00 #	24.00 #
Minimum:	0	1.8	9.6	12.7	12.7	1,020,406.2	0.00	1.00
Maximum:	2	2.1	12.7	13.8	21.1	1,048,477.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/20/2025 00:00	0	1.8	9.8	13.7	12.8	1,039,621.3	0.00	1.00
09/20/2025 01:00	0	1.8	9.7	13.8	13.0	1,053,299.5	0.00	1.00
09/20/2025 02:00	0	1.8	10.1	13.8	13.5	1,048,477.6	0.00	1.00
09/20/2025 03:00	0	1.8	10.0	13.8	13.9	1,048,670.5	0.00	1.00
09/20/2025 04:00	0	1.8	9.9	13.8	13.7	1,046,741.7	0.00	1.00
09/20/2025 05:00	0	1.8	9.8	13.9	13.8	1,061,499.5	0.00	1.00
09/20/2025 06:00	0	1.8	9.8	13.9	13.7	1,060,325.7	0.00	1.00
09/20/2025 07:00	0	1.8	9.7	13.8	13.0	1,048,670.5	0.00	1.00
09/20/2025 08:00	0	1.8	9.8	13.8	13.1	1,052,142.3	0.00	1.00
09/20/2025 09:00	0	1.8	9.9	13.7	13.1	1,044,186.1	0.00	1.00
09/20/2025 10:00	0	1.9	10.1	13.6	12.8	1,034,009.2	0.00	1.00
09/20/2025 11:00	0	1.9	10.2	13.5	12.7	1,022,626.9	0.00	1.00
09/20/2025 12:00	0	1.9	10.7	13.4	13.8	1,011,183.0	0.00	1.00
09/20/2025 13:00	0	1.9	10.7	13.4	13.9	1,011,365.6	0.00	1.00
09/20/2025 14:00	0	2.0	10.9	13.3	14.3	1,000,220.4	0.00	1.00
09/20/2025 15:00	0	2.0	11.1	13.2	14.8	992,210.2	0.00	1.00
09/20/2025 16:00	1	2.1	12.0	12.8	18.3	1,001,708.6	0.00	1.00
09/20/2025 17:00	0	1.9	10.9	13.3	14.3	1,009,590.1	0.00	1.00
09/20/2025 18:00	0	1.9	10.6	13.4	14.9	1,003,149.0	0.00	1.00
09/20/2025 19:00	0	1.9	10.5	13.5	14.2	1,016,705.1	0.00	1.00
09/20/2025 20:00	0	1.9	10.2	13.7	13.7	1,040,572.3	0.00	1.00
09/20/2025 21:00	0	1.9	10.2	13.6	14.2	1,028,944.2	0.00	1.00
09/20/2025 22:00	0	1.9	10.2	13.6	15.2	1,032,696.1	0.00	1.00
09/20/2025 23:00	0	1.8	10.1	13.7	14.5	1,037,909.6	0.00	1.00
Average/Sum#:	0	1.9	10.3	13.6	14.0	1,031,105.2	0.00 #	24.00 #
Minimum:	0	1.8	9.7	12.8	12.7	992,210.2	0.00	1.00
Maximum:	1	2.1	12.0	13.9	18.3	1,061,499.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/21/2025 00:00	0	1.8	10.1	13.8	14.8	1,049,634.9	0.00	1.00
09/21/2025 01:00	0	1.8	10.1	13.8	14.9	1,049,634.9	0.00	1.00
09/21/2025 02:00	0	1.8	10.4	13.8	14.3	1,050,792.1	0.00	1.00
09/21/2025 03:00	0	1.8	10.3	13.8	14.5	1,051,177.9	0.00	1.00
09/21/2025 04:00	0	1.8	10.2	13.9	14.3	1,063,064.6	0.00	1.00
09/21/2025 05:00	0	1.8	10.1	13.9	14.2	1,062,869.0	0.00	1.00
09/21/2025 06:00	0	1.8	10.0	13.9	14.1	1,063,064.6	0.00	1.00
09/21/2025 07:00	0	1.8	10.0	13.8	13.4	1,049,827.7	0.00	1.00
09/21/2025 08:00	0	1.8	10.0	13.8	13.9	1,051,949.4	0.00	1.00
09/21/2025 09:00	0	1.8	10.1	13.7	13.7	1,041,142.9	0.00	1.00
09/21/2025 10:00	0	1.9	10.2	13.5	13.6	1,018,370.6	0.00	1.00
09/21/2025 11:00	0	1.9	10.8	13.3	14.4	998,058.1	0.00	1.00
09/21/2025 12:00	0	2.0	11.4	13.1	14.8	981,771.9	0.00	1.00
09/21/2025 13:00	0	2.0	11.6	13.0	15.2	973,851.4	0.00	1.00
09/21/2025 14:00	1	2.0	12.0	12.9	15.8	963,218.9	0.00	1.00
09/21/2025 15:00	1	2.1	12.4	12.8	16.9	953,187.0	0.00	1.00
09/21/2025 16:00	1	2.1	12.6	12.8	17.6	954,201.4	0.00	1.00
09/21/2025 17:00	1	2.0	12.2	12.9	16.4	962,705.3	0.00	1.00
09/21/2025 18:00	0	2.0	11.4	13.2	14.9	990,965.3	0.00	1.00
09/21/2025 19:00	0	1.9	10.7	13.4	13.8	1,007,713.8	0.00	1.00
09/21/2025 20:00	0	1.9	10.5	13.5	14.3	1,020,221.2	0.00	1.00
09/21/2025 21:00	0	1.9	10.4	13.5	14.1	1,019,110.8	0.00	1.00
09/21/2025 22:00	0	1.9	10.3	13.5	14.6	1,017,075.2	0.00	1.00
09/21/2025 23:00	0	1.9	10.2	13.6	14.9	1,031,945.7	0.00	1.00
Average/Sum#:	0	1.9	10.8	13.5	14.7	1,017,731.4	0.00 #	24.00 #
Minimum:	0	1.8	10.0	12.8	13.4	953,187.0	0.00	1.00
Maximum:	1	2.1	12.6	13.9	17.6	1,063,064.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/22/2025 00:00	0	1.9	10.2	13.6	14.9	1,028,756.6	0.00	1.00
09/22/2025 01:00	0	1.9	10.2	13.7	14.9	1,041,142.9	0.00	1.00
09/22/2025 02:00	0	1.8	10.6	13.7	14.8	1,038,670.4	0.00	1.00
09/22/2025 03:00	0	1.8	10.4	13.7	14.5	1,035,817.4	0.00	1.00
09/22/2025 04:00	0	1.8	10.2	13.8	14.7	1,043,269.9	0.00	1.00
09/22/2025 05:00	0	1.8	10.0	13.9	14.2	1,053,674.2	0.00	1.00
09/22/2025 06:00	0	1.8	10.0	13.9	14.1	1,052,109.2	0.00	1.00
09/22/2025 07:00	0	1.8	10.1	13.8	13.7	1,045,005.8	0.00	1.00
09/22/2025 08:00	0	1.8	10.2	13.6	14.4	1,027,068.3	0.00	1.00
09/22/2025 09:00	0	1.9	10.3	13.5	13.7	1,019,110.8	0.00	1.00
09/22/2025 10:00	-2	1.7	8.7	14.2	6.3	876,636.0	0.00	1.00
09/22/2025 11:00	-3	1.7	7.9	14.4	2.7	805,221.5	0.00	1.00
09/22/2025 12:00	-1	1.7	8.3	14.3	5.5	912,742.1	0.00	1.00
09/22/2025 13:00	-1	1.9	10.5	13.6	12.6	1,036,260.3	0.00	1.00
09/22/2025 14:00	1	2.1	12.8	12.8	17.8	956,230.2	0.00	1.00
09/22/2025 15:00	1	2.1	13.4	12.6	18.9	935,993.3	0.00	1.00
09/22/2025 16:00	2	2.2	13.5	12.5	20.5	949,956.7	0.00	1.00
09/22/2025 17:00	-1	1.8	10.7	13.4	12.6	1,026,520.5	0.00	1.00
09/22/2025 18:00	0	1.9	10.2	13.6	12.4	1,035,885.1	0.00	1.00
09/22/2025 19:00	0	1.9	10.1	13.6	13.0	1,031,382.9	0.00	1.00
09/22/2025 20:00	0	1.8	10.0	13.7	13.1	1,042,474.3	0.00	1.00
09/22/2025 21:00	0	1.8	9.9	13.7	13.0	1,043,044.9	0.00	1.00
09/22/2025 22:00	0	1.8	9.8	13.7	13.3	1,036,007.6	0.00	1.00
09/22/2025 23:00	0	1.8	9.8	13.8	14.4	1,049,634.9	0.00	1.00
Average/Sum#:	0	1.9	10.3	13.6	13.3	1,005,109.0	0.00 #	24.00 #
Minimum:	-3	1.7	7.9	12.5	2.7	805,221.5	0.00	1.00
Maximum:	2	2.2	13.5	14.4	20.5	1,053,674.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/23/2025 00:00	0	1.8	9.8	13.8	14.3	1,048,863.4	0.00	1.00
09/23/2025 01:00	0	1.8	9.8	13.8	13.9	1,047,899.0	0.00	1.00
09/23/2025 02:00	0	1.8	10.2	13.8	14.2	1,048,477.6	0.00	1.00
09/23/2025 03:00	0	1.8	10.1	13.8	13.7	1,051,370.7	0.00	1.00
09/23/2025 04:00	0	1.8	10.0	13.9	14.5	1,061,695.2	0.00	1.00
09/23/2025 05:00	0	1.8	10.3	13.8	15.2	1,051,370.7	0.00	1.00
09/23/2025 06:00	0	1.8	10.0	13.9	14.7	1,056,608.7	0.00	1.00
09/23/2025 07:00	0	1.8	10.2	13.8	14.3	1,049,442.0	0.00	1.00
09/23/2025 08:00	0	1.9	10.5	13.6	15.3	1,032,133.3	0.00	1.00
09/23/2025 09:00	0	1.9	10.7	13.4	15.1	1,014,104.4	0.00	1.00
09/23/2025 10:00	1	2.0	11.4	13.2	15.9	995,411.5	0.00	1.00
09/23/2025 11:00	1	2.0	12.5	12.9	17.6	968,354.2	0.00	1.00
09/23/2025 12:00	2	2.1	13.6	12.6	19.7	944,077.9	0.00	1.00
09/23/2025 13:00	0	1.9	10.7	13.4	13.3	1,015,930.3	0.00	1.00
09/23/2025 14:00	0	1.9	10.4	13.5	13.4	1,027,808.5	0.00	1.00
09/23/2025 15:00	0	1.9	10.7	13.3	14.4	1,020,041.0	0.00	1.00
09/23/2025 16:00	1	2.0	11.1	13.2	16.4	1,027,601.8	0.00	1.00
09/23/2025 17:00	3	2.2	13.0	12.4	23.0	1,027,873.8	0.00	1.00
09/23/2025 18:00	2	2.1	11.8	12.8	20.6	1,022,841.7	0.00	1.00
09/23/2025 19:00	1	2.0	12.7	12.9	18.3	956,885.3	0.00	1.00
09/23/2025 20:00	1	2.0	11.8	13.2	17.7	984,384.9	0.00	1.00
09/23/2025 21:00	1	1.9	11.2	13.4	16.8	1,011,365.6	0.00	1.00
09/23/2025 22:00	0	1.8	10.6	13.6	14.9	1,028,756.6	0.00	1.00
09/23/2025 23:00	0	1.9	10.6	13.6	15.8	1,029,131.8	0.00	1.00
Average/Sum#:	1	1.9	11.0	13.4	16.0	1,021,767.9	0.00 #	24.00 #
Minimum:	0	1.8	9.8	12.4	13.3	944,077.9	0.00	1.00
Maximum:	3	2.2	13.6	13.9	23.0	1,061,695.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/24/2025 00:00	0	1.8	10.5	13.7	15.8	1,038,290.0	0.00	1.00
09/24/2025 01:00	0	1.8	10.4	13.7	15.6	1,040,762.5	0.00	1.00
09/24/2025 02:00	0	1.8	10.8	13.7	15.9	1,043,235.1	0.00	1.00
09/24/2025 03:00	0	1.8	10.7	13.7	15.3	1,039,431.1	0.00	1.00
09/24/2025 04:00	0	1.8	10.5	13.8	15.4	1,052,528.0	0.00	1.00
09/24/2025 05:00	0	1.8	10.7	13.7	15.9	1,053,886.2	0.00	1.00
09/24/2025 06:00	0	1.8	10.4	13.8	14.7	1,053,878.1	0.00	1.00
09/24/2025 07:00	0	1.9	10.2	13.8	15.0	1,052,335.1	0.00	1.00
09/24/2025 08:00	1	1.9	10.4	13.6	16.2	1,039,824.6	0.00	1.00
09/24/2025 09:00	1	1.9	11.2	13.4	16.9	1,034,919.7	0.00	1.00
09/24/2025 10:00	0	1.9	10.6	13.6	16.0	1,035,509.9	0.00	1.00
09/24/2025 11:00	0	1.9	10.5	13.6	16.0	1,034,196.8	0.00	1.00
09/24/2025 12:00	0	1.9	10.7	13.5	15.9	1,025,957.9	0.00	1.00
09/24/2025 13:00	0	1.9	11.3	13.3	16.1	1,003,824.1	0.00	1.00
09/24/2025 14:00	1	2.0	11.7	13.2	17.1	990,609.6	0.00	1.00
09/24/2025 15:00	0	1.9	11.7	13.4	16.7	1,007,166.0	0.00	1.00
09/24/2025 16:00	1	2.0	12.2	13.2	19.3	1,011,595.6	0.00	1.00
09/24/2025 17:00	0	1.9	11.1	13.4	16.0	1,013,921.8	0.00	1.00
09/24/2025 18:00	0	1.9	10.6	13.6	15.4	1,028,756.6	0.00	1.00
09/24/2025 19:00	0	1.9	10.5	13.6	15.5	1,029,882.2	0.00	1.00
09/24/2025 20:00	1	1.9	10.4	13.6	16.1	1,024,066.8	0.00	1.00
09/24/2025 21:00	0	1.8	10.3	13.7	14.4	1,035,817.4	0.00	1.00
09/24/2025 22:00	0	1.8	10.3	13.7	14.7	1,035,437.0	0.00	1.00
09/24/2025 23:00	0	1.8	10.2	13.7	15.0	1,037,339.0	0.00	1.00
Average/Sum#:	0	1.9	10.7	13.6	15.9	1,031,798.8	0.00 #	24.00 #
Minimum:	0	1.8	10.2	13.2	14.4	990,609.6	0.00	1.00
Maximum:	1	2.0	12.2	13.8	19.3	1,053,886.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/25/2025 00:00	0	1.8	10.1	13.7	15.2	1,036,388.0	0.00	1.00
09/25/2025 01:00	0	1.8	10.1	13.7	15.2	1,035,246.8	0.00	1.00
09/25/2025 02:00	0	1.8	10.4	13.8	14.6	1,047,127.5	0.00	1.00
09/25/2025 03:00	0	1.8	10.3	13.8	15.4	1,045,584.4	0.00	1.00
09/25/2025 04:00	0	1.8	10.3	13.7	15.6	1,037,909.6	0.00	1.00
09/25/2025 05:00	0	1.8	10.1	13.7	14.8	1,037,909.6	0.00	1.00
09/25/2025 06:00	0	1.9	10.1	13.7	14.8	1,044,186.1	0.00	1.00
09/25/2025 07:00	0	1.8	10.0	13.7	14.4	1,038,860.6	0.00	1.00
09/25/2025 08:00	0	1.8	10.1	13.7	15.0	1,041,523.3	0.00	1.00
09/25/2025 09:00	0	1.9	10.1	13.6	14.2	1,029,507.0	0.00	1.00
09/25/2025 10:00	0	1.9	10.2	13.6	14.5	1,031,007.7	0.00	1.00
09/25/2025 11:00	0	1.9	10.4	13.4	14.9	1,009,722.2	0.00	1.00
09/25/2025 12:00	0	1.9	10.6	13.3	14.7	1,001,661.9	0.00	1.00
09/25/2025 13:00	1	2.0	10.8	13.2	15.2	987,764.0	0.00	1.00
09/25/2025 14:00	1	2.0	11.1	13.2	15.8	989,364.7	0.00	1.00
09/25/2025 15:00	1	2.0	11.5	13.1	16.6	977,909.5	0.00	1.00
09/25/2025 16:00	2	2.1	12.4	12.9	19.5	976,057.2	0.00	1.00
09/25/2025 17:00	1	2.0	11.8	13.1	17.8	987,390.1	0.00	1.00
09/25/2025 18:00	0	1.9	10.6	13.5	14.9	1,019,480.9	0.00	1.00
09/25/2025 19:00	0	1.9	10.3	13.7	15.5	1,039,431.1	0.00	1.00
09/25/2025 20:00	0	1.8	10.3	13.8	15.7	1,048,863.4	0.00	1.00
09/25/2025 21:00	0	1.8	10.2	13.8	15.5	1,049,056.2	0.00	1.00
09/25/2025 22:00	0	1.8	10.1	13.8	15.2	1,045,005.8	0.00	1.00
09/25/2025 23:00	0	1.8	10.2	13.8	15.1	1,045,198.7	0.00	1.00
Average/Sum#:	0	1.9	10.5	13.6	15.4	1,025,089.8	0.00 #	24.00 #
Minimum:	0	1.8	10.0	12.9	14.2	976,057.2	0.00	1.00
Maximum:	2	2.1	12.4	13.8	19.5	1,049,056.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/26/2025 00:00	0	1.8	10.1	13.9	15.2	1,060,325.7	0.00	1.00
09/26/2025 01:00	0	1.8	10.1	13.9	15.1	1,059,151.9	0.00	1.00
09/26/2025 02:00	0	1.8	10.4	13.9	15.3	1,057,391.3	0.00	1.00
09/26/2025 03:00	0	1.8	10.3	13.9	14.9	1,054,652.4	0.00	1.00
09/26/2025 04:00	0	1.8	10.2	13.9	15.2	1,052,891.7	0.00	1.00
09/26/2025 05:00	0	1.8	10.2	13.9	14.9	1,051,913.6	0.00	1.00
09/26/2025 06:00	0	1.8	10.1	14.0	14.9	1,066,166.3	0.00	1.00
09/26/2025 07:00	-1	1.7	9.3	14.1	9.9	951,347.2	0.00	1.00
09/26/2025 08:00	-2	1.7	8.1	14.3	5.3	796,133.5	0.00	1.00
09/26/2025 09:00	-2	1.7	8.2	14.3	4.9	796,756.0	0.00	1.00
09/26/2025 10:00	-2	1.7	8.2	14.3	4.7	794,888.6	0.00	1.00
09/26/2025 11:00	-2	1.7	8.3	14.4	4.9	806,274.9	0.00	1.00
09/26/2025 12:00	-2	1.7	8.2	14.4	4.4	806,696.3	0.00	1.00
09/26/2025 13:00	-1	1.7	9.3	14.0	10.0	873,057.7	0.00	1.00
09/26/2025 14:00	1	2.0	12.1	13.1	17.7	981,771.9	0.00	1.00
09/26/2025 15:00	1	2.0	12.7	12.9	18.8	960,822.4	0.00	1.00
09/26/2025 16:00	1	2.1	13.0	12.8	19.4	951,327.3	0.00	1.00
09/26/2025 17:00	1	2.1	12.7	12.9	18.7	963,218.9	0.00	1.00
09/26/2025 18:00	1	2.0	12.1	13.0	17.5	975,238.2	0.00	1.00
09/26/2025 19:00	0	1.9	11.3	13.4	15.9	1,010,087.4	0.00	1.00
09/26/2025 20:00	0	1.9	10.8	13.5	15.6	1,020,036.1	0.00	1.00
09/26/2025 21:00	0	1.9	10.6	13.5	15.5	1,016,335.0	0.00	1.00
09/26/2025 22:00	0	1.9	10.7	13.6	16.2	1,030,632.5	0.00	1.00
09/26/2025 23:00	1	1.9	10.7	13.6	16.4	1,029,694.6	0.00	1.00
Average/Sum#:	0	1.8	10.3	13.7	13.4	965,283.8	0.00 #	24.00 #
Minimum:	-2	1.7	8.1	12.8	4.4	794,888.6	0.00	1.00
Maximum:	1	2.1	13.0	14.4	19.4	1,066,166.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/27/2025 00:00	0	1.9	10.7	13.7	16.4	1,042,664.5	0.00	1.00
09/27/2025 01:00	0	1.8	10.7	13.7	16.6	1,041,903.7	0.00	1.00
09/27/2025 02:00	0	1.8	11.0	13.7	16.5	1,041,713.5	0.00	1.00
09/27/2025 03:00	0	1.9	10.8	13.7	15.5	1,037,148.8	0.00	1.00
09/27/2025 04:00	0	1.8	10.6	13.8	15.9	1,050,406.4	0.00	1.00
09/27/2025 05:00	0	1.8	10.5	13.8	16.0	1,050,792.1	0.00	1.00
09/27/2025 06:00	0	1.8	10.5	13.8	15.9	1,051,756.5	0.00	1.00
09/27/2025 07:00	-1	1.7	8.9	14.2	8.3	888,899.5	0.00	1.00
09/27/2025 08:00	-2	1.7	8.2	14.3	5.6	800,075.8	0.00	1.00
09/27/2025 09:00	-2	1.7	8.3	14.4	5.5	811,542.0	0.00	1.00
09/27/2025 10:00	-2	1.7	8.2	14.4	5.2	811,331.3	0.00	1.00
09/27/2025 11:00	-2	1.7	8.2	14.4	5.1	810,909.9	0.00	1.00
09/27/2025 12:00	-2	1.7	8.2	14.4	5.0	811,331.3	0.00	1.00
09/27/2025 13:00	-2	1.7	8.2	14.4	5.0	810,067.2	0.00	1.00
09/27/2025 14:00	-2	1.7	8.3	14.4	5.0	810,277.9	0.00	1.00
09/27/2025 15:00	-1	1.7	8.7	14.3	8.5	917,514.3	0.00	1.00
09/27/2025 16:00	0	1.9	11.4	13.4	16.6	1,014,652.2	0.00	1.00
09/27/2025 17:00	0	1.9	11.2	13.5	16.3	1,020,036.1	0.00	1.00
09/27/2025 18:00	0	1.8	11.1	13.7	16.5	1,039,621.3	0.00	1.00
09/27/2025 19:00	0	1.8	10.9	13.8	16.0	1,048,284.7	0.00	1.00
09/27/2025 20:00	0	1.8	10.8	13.8	15.5	1,047,899.0	0.00	1.00
09/27/2025 21:00	0	1.8	10.6	13.9	15.3	1,058,760.7	0.00	1.00
09/27/2025 22:00	0	1.8	10.6	13.9	15.4	1,058,956.3	0.00	1.00
09/27/2025 23:00	0	1.8	10.7	13.9	15.6	1,063,651.5	0.00	1.00
Average/Sum#:	-1	1.8	9.9	14.0	12.2	964,174.9	0.00 #	24.00 #
Minimum:	-2	1.7	8.2	13.4	5.0	800,075.8	0.00	1.00
Maximum:	0	1.9	11.4	14.4	16.6	1,063,651.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/28/2025 00:00	0	1.8	10.7	13.8	15.3	1,049,634.9	0.00	1.00
09/28/2025 01:00	0	1.8	10.7	13.9	15.4	1,063,847.1	0.00	1.00
09/28/2025 02:00	0	1.8	11.0	13.9	15.2	1,060,717.0	0.00	1.00
09/28/2025 03:00	0	1.8	10.8	13.9	15.1	1,060,717.0	0.00	1.00
09/28/2025 04:00	0	1.8	10.7	13.9	15.2	1,060,325.7	0.00	1.00
09/28/2025 05:00	0	1.8	10.6	13.9	15.2	1,059,738.8	0.00	1.00
09/28/2025 06:00	0	1.8	10.5	13.9	15.0	1,056,608.7	0.00	1.00
09/28/2025 07:00	-1	1.8	10.0	14.0	13.2	1,024,289.7	0.00	1.00
09/28/2025 08:00	-2	1.7	8.3	14.3	5.3	806,300.5	0.00	1.00
09/28/2025 09:00	-2	1.7	8.2	14.3	5.4	800,905.8	0.00	1.00
09/28/2025 10:00	-2	1.7	8.2	14.3	5.2	800,283.3	0.00	1.00
09/28/2025 11:00	-2	1.7	8.2	14.3	4.9	800,283.3	0.00	1.00
09/28/2025 12:00	-1	1.7	8.7	14.2	8.0	908,929.9	0.00	1.00
09/28/2025 13:00	0	1.8	10.9	13.7	14.6	1,042,093.9	0.00	1.00
09/28/2025 14:00	-1	1.7	8.7	14.3	9.4	1,001,339.7	0.00	1.00
09/28/2025 15:00	0	1.8	10.7	13.8	14.6	1,050,213.5	0.00	1.00
09/28/2025 16:00	0	1.8	10.7	13.8	14.3	1,049,634.9	0.00	1.00
09/28/2025 17:00	0	1.8	10.6	13.8	14.5	1,048,670.5	0.00	1.00
09/28/2025 18:00	0	1.8	10.6	13.8	15.0	1,045,584.4	0.00	1.00
09/28/2025 19:00	0	1.8	10.6	13.8	15.1	1,046,356.0	0.00	1.00
09/28/2025 20:00	0	1.8	10.5	13.9	14.8	1,058,760.7	0.00	1.00
09/28/2025 21:00	0	1.8	10.5	13.8	14.7	1,044,041.4	0.00	1.00
09/28/2025 22:00	0	1.8	10.5	13.9	14.8	1,057,000.0	0.00	1.00
09/28/2025 23:00	0	1.8	10.4	13.9	14.8	1,055,826.2	0.00	1.00
Average/Sum#:	0	1.8	10.1	14.0	12.7	1,002,171.0	0.00 #	24.00 #
Minimum:	-2	1.7	8.2	13.7	4.9	800,283.3	0.00	1.00
Maximum:	0	1.8	11.0	14.3	15.4	1,063,847.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/29/2025 00:00	0	1.8	10.4	13.9	14.8	1,057,978.2	0.00	1.00
09/29/2025 01:00	0	1.8	10.4	13.9	14.8	1,057,195.6	0.00	1.00
09/29/2025 02:00	0	1.8	10.7	13.9	14.5	1,058,173.8	0.00	1.00
09/29/2025 03:00	0	1.8	10.6	13.8	14.5	1,043,655.7	0.00	1.00
09/29/2025 04:00	0	1.8	10.6	13.8	15.1	1,046,741.7	0.00	1.00
09/29/2025 05:00	0	1.8	10.6	13.8	15.0	1,048,477.6	0.00	1.00
09/29/2025 06:00	0	1.8	10.6	13.8	14.9	1,048,477.6	0.00	1.00
09/29/2025 07:00	0	1.8	10.4	13.8	14.7	1,044,620.1	0.00	1.00
09/29/2025 08:00	-1	1.7	8.1	14.4	7.2	934,158.1	0.00	1.00
09/29/2025 09:00	0	1.8	10.1	13.7	15.7	1,041,523.3	0.00	1.00
09/29/2025 10:00	0	1.8	10.1	13.7	14.8	1,040,382.1	0.00	1.00
09/29/2025 11:00	0	1.8	10.6	13.8	14.4	1,055,228.3	0.00	1.00
09/29/2025 12:00	0	1.8	10.6	13.8	14.3	1,054,456.8	0.00	1.00
09/29/2025 13:00	0	1.8	10.5	13.8	14.4	1,054,842.5	0.00	1.00
09/29/2025 14:00	0	1.8	10.8	13.7	14.9	1,043,615.5	0.00	1.00
09/29/2025 15:00	0	1.8	10.9	13.7	15.3	1,039,050.8	0.00	1.00
09/29/2025 16:00	0	1.8	11.2	13.7	16.3	1,039,050.8	0.00	1.00
09/29/2025 17:00	0	1.8	11.0	13.8	16.4	1,036,133.5	0.00	1.00
09/29/2025 18:00	0	1.8	11.0	13.8	16.2	1,033,819.0	0.00	1.00
09/29/2025 19:00	0	1.8	11.0	13.8	16.0	1,031,504.5	0.00	1.00
09/29/2025 20:00	0	1.8	10.9	13.8	15.9	1,030,540.1	0.00	1.00
09/29/2025 21:00	0	1.8	10.8	13.8	15.4	1,029,382.8	0.00	1.00
09/29/2025 22:00	0	1.8	10.7	13.8	15.4	1,030,925.8	0.00	1.00
09/29/2025 23:00	0	1.8	10.5	13.8	15.0	1,030,154.3	0.00	1.00
Average/Sum#:	0	1.8	10.5	13.8	14.8	1,038,753.7	0.00 #	24.00 #
Minimum:	-1	1.7	8.1	13.7	7.2	934,158.1	0.00	1.00
Maximum:	0	1.8	11.2	14.4	16.4	1,058,173.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/30/2025 00:00	0	1.8	10.5	13.8	15.2	1,028,804.2	0.00	1.00
09/30/2025 01:00	0	1.8	10.5	13.8	15.2	1,029,382.8	0.00	1.00
09/30/2025 02:00	0	1.8	10.8	13.8	15.2	1,029,189.9	0.00	1.00
09/30/2025 03:00	0	1.8	10.7	13.8	14.9	1,028,418.4	0.00	1.00
09/30/2025 04:00	0	1.8	10.6	13.8	15.2	1,029,189.9	0.00	1.00
09/30/2025 05:00	0	1.9	11.1	13.6	16.9	1,034,384.4	0.00	1.00
09/30/2025 06:00	1	1.9	11.3	13.4	17.6	1,026,337.9	0.00	1.00
09/30/2025 07:00	0	1.8	10.2	13.8	14.9	1,030,154.3	0.00	1.00
09/30/2025 08:00	-1	1.7	8.5	14.3	10.4	978,930.9	0.00	1.00
09/30/2025 09:00	0	1.8	10.2	13.8	14.8	1,032,854.6	0.00	1.00
09/30/2025 10:00	0	1.8	10.8	13.7	14.9	1,023,644.7	0.00	1.00
09/30/2025 11:00	0	1.8	11.0	13.7	15.3	1,025,546.7	0.00	1.00
09/30/2025 12:00	0	1.8	11.2	13.7	15.5	1,026,307.5	0.00	1.00
09/30/2025 13:00	0	1.8	11.2	13.7	15.1	1,024,025.1	0.00	1.00
09/30/2025 14:00	-1	1.7	8.8	14.3	9.5	974,158.7	0.00	1.00
09/30/2025 15:00	0	1.8	11.2	13.7	14.8	1,019,270.2	0.00	1.00
09/30/2025 16:00	0	1.9	11.6	13.5	16.7	1,019,666.0	0.00	1.00
09/30/2025 17:00	0	1.8	10.6	13.8	14.5	1,030,925.8	0.00	1.00
09/30/2025 18:00	0	1.8	10.4	13.8	15.3	1,027,646.9	0.00	1.00
09/30/2025 19:00	0	1.8	10.4	13.8	16.2	1,028,804.2	0.00	1.00
09/30/2025 20:00	1	1.8	10.4	13.8	16.5	1,029,382.8	0.00	1.00
09/30/2025 21:00	0	1.8	10.3	13.8	16.2	1,029,575.7	0.00	1.00
09/30/2025 22:00	-1	3.4	11.9	14.4	8.7	843,986.8	0.17	1.00
09/30/2025 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	1.9	10.6	13.8	14.8	1,015,243.0	0.17 #	23.00 #
Minimum:	-1	1.7	8.5	13.4	8.7	843,986.8	0.00	0.00
Maximum:	1	3.4	11.9	14.4	17.6	1,034,384.4	0.17	1.00
%SI	4.17	4.17	4.17	4.17	4.17	4.17	0.00	0.00

AQ-54 thru 63 & 71

AQ54-63 & 71: Fuel use emission and operational data -
Hourly/Daily/Quarterly

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

Sample Spreadsheet Listing

Date/Time	CT1_GasFlow_CT_scfh_1M		CT1_CO_Ppmvdc_1M		CT1_NOx_Ppmvdc_1M		CT1_CO_LbPerHr_1M		CT1_NOx_LbPerHr_1M		CT1_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
08/26/25 9:14	432001.8		0.9		1.94		1.04		3.59		0	
08/26/25 9:15	432498.6		1		2.02		1.14		3.75		0	
08/26/25 9:16	431285.6		1		2.02		1.14		3.75		0	
08/26/25 9:17	430788.8		1		1.85		1.14		3.44		0	
08/26/25 9:18	431320.2		1		1.69		1.14		3.14		0	
08/26/25 9:19	150805		1		1.43		0.4		0.93		1	
08/26/25 9:20	23272.3		0		1.02		1.56		0.09		0	
08/26/25 9:21	22463.6		0		0		0		0		0	
08/26/25 9:22	21712.7		0		0		0		0		0	
08/26/25 9:23	21088.9		0		0		0		0		0	
08/26/25 9:24	20886.7		0		0		0		0		0	

Sample Spreadsheet Listing

Date/Time	CT1_GasFlow_CT_scfh_1M		CT1_CO_Ppmvdc_1M		CT1_NOx_Ppmvdc_1M		CT1_CO_LbPerHr_1M		CT1_NOx_LbPerHr_1M		CT1_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
08/26/25 17:49	49149.7		0		0		0		0		0	
08/26/25 17:50	49161.2		0		0		0		0		0	
08/26/25 17:51	49299.8		0		0		0		0		0	
08/26/25 17:52	49259.4		0		0		0		0		0	
08/26/25 17:53	56491.2		0		0		0		0		0	
08/26/25 17:54	50218.3		-0.1		0		0		0		1	
08/26/25 17:55	52938.9		-0.1		0		0		0		1	
08/26/25 17:56	58264.5		14.6		0.1		0		0		1	
08/26/25 17:57	65762		955.3		5.41		148.41		1.38		1	
08/26/25 17:58	70446.5		648.7		6.94		108.03		1.9		1	
08/26/25 17:59	49652.2		0		10.33		33.32		1.99		0	
08/26/25 18:00	49363.4		0		6.69		16.56		1.28		0	
08/26/25 18:01	49288.3		0		0.1		0		0		0	
08/26/25 18:02	49374.9		0		0		0		0		0	
08/26/25 18:03	49155.4		0		0		0		0		0	

Sample Spreadsheet Listing

Date/Time	CT1_GasFlow_CT_scfh_1M		CT1_CO_Ppmvdc_1M		CT1_NOx_Ppmvdc_1M		CT1_CO_LbPerHr_1M		CT1_NOx_LbPerHr_1M		CT1_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
08/26/25 17:49	49149.7		0		0		0		0		0	
08/26/25 17:50	49161.2		0		0		0		0		0	
08/26/25 17:51	49299.8		0		0		0		0		0	
08/26/25 17:52	49259.4		0		0		0		0		0	
08/26/25 17:53	56491.2		0		0		0		0		0	
08/26/25 17:54	50218.3		-0.1		0		0		0		1	
08/26/25 17:55	52938.9		-0.1		0		0		0		1	
08/26/25 17:56	58264.5		14.6		0.1		0		0		1	
08/26/25 17:57	65762		955.3		5.41		148.41		1.38		1	
08/26/25 17:58	70446.5		648.7		6.94		108.03		1.9		1	
08/26/25 17:59	49652.2		0		10.33		33.32		1.99		0	
08/26/25 18:00	49363.4		0		6.69		16.56		1.28		0	
08/26/25 18:01	49288.3		0		0.1		0		0		0	
08/26/25 18:02	49374.9		0		0		0		0		0	
08/26/25 18:03	49155.4		0		0		0		0		0	

Sample Spreadsheet Listing

Date/Time	CT1_GasFlow_CT_scfh_1M		CT1_CO_Ppmvdc_1M		CT1_NOx_Ppmvdc_1M		CT1_CO_LbPerHr_1M		CT1_NOx_LbPerHr_1M		CT1_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
08/26/25 18:08	48670.2		0		0		0		0		0	
08/26/25 18:09	48600.9		0		0		0		0		0	
08/26/25 18:10	48439.2		0		0		0		0		0	
08/26/25 18:11	48317.9		0		0		0		0		0	
08/26/25 18:12	48156.2		0		0		0		0		0	
08/26/25 18:13	49421.2		0		0		0		0		1	
08/26/25 18:14	51616.1		0		0		0		0		1	
08/26/25 18:15	56832		9.5		0.1		0		0		1	
08/26/25 18:16	64000.3		989.1		11.8		149.66		2.94		1	
08/26/25 18:17	70810.4		693.8		14.58		116.16		4.02		1	
08/26/25 18:18	48127.3		0		20.95		37.07		3.92		1	
08/26/25 18:19	47653.6		0		14.23		18.09		2.64		0	
08/26/25 18:20	47630.5		0		11.8		29.89		2.19		0	
08/26/25 18:21	47630.5		0		0.1		0		0		0	
08/26/25 18:22	47549.7		0		0.1		0		0		0	
08/26/25 18:23	47763.4		0		0.1		0		0		0	

Sample Spreadsheet Listing

Date/Time	CT1_GasFlow_CT_scfh_1M		CT1_CO_Ppmvdc_1M		CT1_NOx_Ppmvdc_1M		CT1_CO_LbPerHr_1M		CT1_NOx_LbPerHr_1M		CT1_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
08/26/25 18:08	48670.2		0		0		0		0		0	
08/26/25 18:09	48600.9		0		0		0		0		0	
08/26/25 18:10	48439.2		0		0		0		0		0	
08/26/25 18:11	48317.9		0		0		0		0		0	
08/26/25 18:12	48156.2		0		0		0		0		0	
08/26/25 18:13	49421.2		0		0		0		0		1	
08/26/25 18:14	51616.1		0		0		0		0		1	
08/26/25 18:15	56832		9.5		0.1		0		0		1	
08/26/25 18:16	64000.3		989.1		11.8		149.66		2.94		1	
08/26/25 18:17	70810.4		693.8		14.58		116.16		4.02		1	
08/26/25 18:18	48127.3		0		20.95		37.07		3.92		1	
08/26/25 18:19	47653.6		0		14.23		18.09		2.64		0	
08/26/25 18:20	47630.5		0		11.8		29.89		2.19		0	
08/26/25 18:21	47630.5		0		0.1		0		0		0	
08/26/25 18:22	47549.7		0		0.1		0		0		0	
08/26/25 18:23	47763.4		0		0.1		0		0		0	

Sample Spreadsheet Listing

Date/Time	CT1_GasFlow_CT_scfh_1M		CT1_CO_Ppmvdc_1M		CT1_NOx_Ppmvdc_1M		CT1_CO_LbPerHr_1M		CT1_NOx_LbPerHr_1M		CT1_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
08/26/25 18:36	47676.7		0		0		0		0		0	
08/26/25 18:37	47491.9		0		0		0		0		0	
08/26/25 18:38	47549.7		0		0		0		0		0	
08/26/25 18:39	47486.1		0		0		0		0		0	
08/26/25 18:40	47330.2		0		0		0		0		0	
08/26/25 18:41	49415.4		0.2		0		0		0		1	
08/26/25 18:42	54261.6		0.9		0		0		0		1	
08/26/25 18:43	60915.8		1188.9		25.57		171.11		6.06		1	
08/26/25 18:44	69389.5		843		18.44		138.31		4.98		1	
08/26/25 18:45	54631.3		439.4		26.08		56.75		5.54		1	
08/26/25 18:46	46694.8		0		23.6		22.92		4.29		0	
08/26/25 18:47	46845		0		8.26		15.3		1.51		0	
08/26/25 18:48	46845		0		0.2		0		0		0	
08/26/25 18:49	46902.7		0		0.2		0		0		0	
08/26/25 18:50	47012.5		0		0.1		0		0		0	

Sample Spreadsheet Listing

Date/Time	CT1_GasFlow_CT_scfh_1M		CT1_CO_Ppmvdc_1M		CT1_NOx_Ppmvdc_1M		CT1_CO_LbPerHr_1M		CT1_NOx_LbPerHr_1M		CT1_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
08/26/25 18:36	47676.7		0		0		0		0		0	
08/26/25 18:37	47491.9		0		0		0		0		0	
08/26/25 18:38	47549.7		0		0		0		0		0	
08/26/25 18:39	47486.1		0		0		0		0		0	
08/26/25 18:40	47330.2		0		0		0		0		0	
08/26/25 18:41	49415.4		0.2		0		0		0		1	
08/26/25 18:42	54261.6		0.9		0		0		0		1	
08/26/25 18:43	60915.8		1188.9		25.57		171.11		6.06		1	
08/26/25 18:44	69389.5		843		18.44		138.31		4.98		1	
08/26/25 18:45	54631.3		439.4		26.08		56.75		5.54		1	
08/26/25 18:46	46694.8		0		23.6		22.92		4.29		0	
08/26/25 18:47	46845		0		8.26		15.3		1.51		0	
08/26/25 18:48	46845		0		0.2		0		0		0	
08/26/25 18:49	46902.7		0		0.2		0		0		0	
08/26/25 18:50	47012.5		0		0.1		0		0		0	

Sample Spreadsheet Listing

Date/Time	CT1_GasFlow_CT_scfh_1M		CT1_CO_Ppmvdc_1M		CT1_NOx_Ppmvdc_1M		CT1_CO_LbPerHr_1M		CT1_NOx_LbPerHr_1M		CT1_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
08/27/25 0:49	49201.7		0		0		0		0		0	
08/27/25 0:50	49334.5		0		0		0		0		0	
08/27/25 0:51	49403.8		0		0		0		0		0	
08/27/25 0:52	49323		0		0		0		0		0	
08/27/25 0:53	49115		0		0		0		0		0	
08/27/25 0:54	50824.8		-0.1		0		0		0		1	
08/27/25 0:55	55220.5		-0.1		0		0		0		1	
08/27/25 0:56	61349		1339.3		33.93		194.27		8.1		1	
08/27/25 0:57	69609		1031.7		19.67		169.74		5.33		1	
08/27/25 0:58	79145.5		600.5		26.22		112.37		8.08		1	
08/27/25 0:59	97843		306.5		28.94		70.88		11.01		1	
08/27/25 1:00	137178.9		195.5		37.01		63.41		19.76		1	
08/27/25 1:01	150036.7		115.4		52.66		40.91		30.73		1	
08/27/25 1:02	163142.9		810.1		55.87		312.46		35.46		1	
08/27/25 1:03	182695.4		1778.5		51.54		767.96		36.63		1	
08/27/25 1:04	204696.9		662.6		52.34		320.68		41.69		1	
08/27/25 1:05	225832		71.5		49.56		38.15		43.54		1	
08/27/25 1:06	247954.8		4.4		52.27		2.56		50.42		1	
08/27/25 1:07	272220.7		1.6		70.59		1.02		74.76		1	
08/27/25 1:08	296694.4		1.4		43.3		1		49.97		1	
08/27/25 1:09	316454.8		1.5		19.2		1.12		23.64		1	
08/27/25 1:10	333991.3		1.6		9.89		1.3		12.85		1	
08/27/25 1:11	347617.4		1.6		8.68		1.35		11.73		1	
08/27/25 1:12	350915.6		1.5		7.31		1.24		9.98		1	
08/27/25 1:13	351718.5		1.3		6.25		1.1		8.55		1	
08/27/25 1:14	351579.8		1.3		5.45		1.04		7.46		1	
08/27/25 1:15	354762.5		1.1		5.02		0.96		6.93		1	
08/27/25 1:16	373315.7		1		4.11		0.87		5.97		1	
08/27/25 1:17	391701.3		0.9		3.5		0.85		5.34		1	
08/27/25 1:18	402936		0.8		3.09		0.8		4.84		1	
08/27/25 1:19	406835		0.8		3.14		0.73		4.97		1	
08/27/25 1:20	407325.9		0.7		3.09		0.63		4.9		1	

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
08/27/25 1:21	406892.8			0.7			3.28			0.63			5.19			1		
08/27/25 1:22	406563.5			0.7			3.28			0.63			5.18			1		
08/27/25 1:23	405367.8			0.7			3.28			0.63			5.17			1		
08/27/25 1:24	405240.7			0.7			3.37			0.63			5.31			1		
08/27/25 1:25	405079			0.7			3.37			0.63			5.31			1		
08/27/25 1:26	404137.5			0.6			3.47			0.54			5.45			1		
08/27/25 1:27	388605.3			0.6			3.65			0.52			5.52			1		
08/27/25 1:28	368440.6			0.6			4.24			0.48			6.08			1		
08/27/25 1:29	358563.3			0.6			4.36			0.54			6.08			1		
08/27/25 1:30	354774.1			0.7			4.27			0.61			5.89			1		
08/27/25 1:31	352717.8			0.7			4.18			0.61			5.73			1		
08/27/25 1:32	351452.8			0.7			4.08			0.6			5.58			1		
08/27/25 1:33	350586.3			0.6			3			0.53			4.09			1		
08/27/25 1:34	348345.2			0.7			2.54			0.6			3.44			1		
08/27/25 1:35	347207.3			0.7			2.45			0.6			3.31			1		
08/27/25 1:36	347016.7			0.7			2.45			0.6			3.31			1		
08/27/25 1:37	346346.6			0.7			2.45			0.59			3.3			1		
08/27/25 1:38	346895.3			0.6			2.45			0.52			3.31			1		
08/27/25 1:39	346202.2			0.6			2.45			0.52			3.3			1		
08/27/25 1:40	346595			0.6			2.45			0.52			3.3			1		
08/27/25 1:41	345688.1			0.6			2.45			0.52			3.3			1		
08/27/25 1:42	343920.6			0.7			2.45			0.59			3.28			1		
08/27/25 1:43	344186.3			0.7			2.18			0.59			2.92			1		
08/27/25 1:44	343799.3			0.7			1.54			0.59			2.06			1		
08/27/25 1:45	343533.6			0.7			1.45			0.59			1.94			1		
08/27/25 1:46	343591.4			0.7			1.36			0.59			1.82			1		
08/27/25 1:47	343117.7			0.7			1.18			0.59			1.57			1		
08/27/25 1:48	343487.4			0.7			1.09			0.59			1.46			1		
08/27/25 1:49	343221.7			0.7			1			0.59			1.33			1		
08/27/25 1:50	343770.4			0.7			1			0.59			1.34			1		
08/27/25 1:51	343412.3			0.7			0.91			0.59			1.21			1		
08/27/25 1:52	343591.4			0.6			0.91			0.52			1.21			1		
08/27/25 1:53	343360.3			0.7			0.91			0.59			1.21			1		
08/27/25 1:54	343903.3			0.7			0.91			0.59			1.21			0		
08/27/25 1:55	343649.1			0.7			0.91			0.59			1.21			0		

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
08/27/25 1:56	343406.5			0.6			0.82			0.52			1.09			0		
08/27/25 1:57	343135			0.6			0.82			0.52			1.09			0		
08/27/25 1:58	343181.2			0.6			0.82			0.52			1.09			0		

Sample Spreadsheet Listing

Date/Time	CT1_GasFlow_CT_scfh_1M		CT1_CO_Ppmvdc_1M		CT1_NOx_Ppmvdc_1M		CT1_CO_LbPerHr_1M		CT1_NOx_LbPerHr_1M		CT1_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
09/30/25 22:45	339288.1		0.8		1.36		0.65		1.79		0	
09/30/25 22:46	341240.5		0.8		1.36		0.66		1.8		0	
09/30/25 22:47	339767.5		0.8		1.27		0.65		1.67		0	
09/30/25 22:48	322681.5		0.8		1.27		0.62		1.59		0	
09/30/25 22:49	307680.7		0.9		1.34		0.65		1.6		0	
09/30/25 22:50	301396.3		0.9		1.43		0.63		1.67		1	
09/30/25 22:51	282277		0.9		1.36		0.6		1.49		1	
09/30/25 22:52	263180.9		0.9		1.48		0.57		1.5		1	
09/30/25 22:53	241422		0.8		2.38		0.43		2.22		1	
09/30/25 22:54	221419		0.7		5.11		0.36		4.38		1	
09/30/25 22:55	198914.9		0.5		10.51		0.25		8.09		1	
09/30/25 22:56	177242.6		13.8		12.64		5.77		8.67		1	
09/30/25 22:57	160272.2		233.4		15.23		87.93		9.44		1	
09/30/25 22:58	143446.1		1074.1		16.61		362.1		9.22		1	
09/30/25 22:59	79567.1		1948.5		17.52		364.19		5.39		1	
09/30/25 23:00	79584.5		0		29.5		1153.23		9.09		0	
09/30/25 23:01	79382.3		0		0.2		0		0		0	
09/30/25 23:02	79723.1		0		0.1		0		0		0	
09/30/25 23:03	79879		0		0.1		0		0		0	
09/30/25 23:04	79307.2		0		0.1		0		0		0	

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
08/26/25 9:14	472701			1.3			0.93			1.54			1.86			0		
08/26/25 9:15	472585.4			1.2			0.83			1.42			1.67			0		
08/26/25 9:16	472383.3			1.2			0.83			1.42			1.67			0		
08/26/25 9:17	473359.4			1.1			0.91			1.32			1.85			0		
08/26/25 9:18	470783.2			1.1			1			1.32			2.01			0		
08/26/25 9:19	144930.6			1.1			1.08			0.41			0.68			1		
08/26/25 9:20	0			0			0.71			0			0			0		
08/26/25 9:21	0			0			0			0			0			0		
08/26/25 9:22	0			0			0			0			0			0		
08/26/25 9:23	0			0			0			0			0			0		
08/26/25 9:24	0			0			0			0			0			0		

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M		CT2_CO_Ppmvdc_1M		CT2_NOx_Ppmvdc_1M		CT2_CO_LbPerHr_1M		CT2_NOx_LbPerHr_1M		CT2_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
08/26/25 12:01	0		0		0		0		0		0	
08/26/25 12:02	0		0		0		0		0		0	
08/26/25 12:03	0		0		0		0		0		0	
08/26/25 12:04	0		0		0		0		0		0	
08/26/25 12:05	0		0		0		0		0		0	
08/26/25 12:06	9039.7		0		0		0		0		1	
08/26/25 12:07	22781.3		0.4		0		0		0		1	
08/26/25 12:08	37123.6		1068.9		1.97		93.79		0.28		1	
08/26/25 12:09	49998.8		845.2		3.69		99.89		0.72		1	
08/26/25 12:10	62388.7		495		5.9		73.02		1.43		1	
08/26/25 12:11	79416.9		270.6		8.71		50.81		2.69		1	
08/26/25 12:12	124482.9		191.5		12.6		56.36		6.11		1	
08/26/25 12:13	148719.8		161.9		22.18		56.9		12.83		1	
08/26/25 12:14	171189.2		433.3		27.93		175.35		18.6		1	
08/26/25 12:15	193017.4		1469.7		31.34		670.45		23.53		1	
08/26/25 12:16	218091.9		623.2		30.59		321.28		25.95		1	
08/26/25 12:17	240555.5		96.2		32.24		54.69		30.17		1	
08/26/25 12:18	265370.1		5.7		34.66		3.55		35.78		1	
08/26/25 12:19	291975.3		1.6		27.21		1.13		30.9		1	
08/26/25 12:20	316293		1.4		14.46		1.03		17.79		1	
08/26/25 12:21	339034		1.2		10.8		0.95		14.25		1	
08/26/25 12:22	359470.2		1.2		8.1		1.05		11.33		1	
08/26/25 12:23	378647.1		1.3		7.03		1.17		10.35		1	
08/26/25 12:24	400319.4		1.3		5.81		1.25		9.05		1	
08/26/25 12:25	423932.5		1.3		5.54		1.25		9.14		1	
08/26/25 12:26	443854.6		1.1		5.54		1.14		9.56		1	
08/26/25 12:27	451513.8		0.9		5.44		0.98		9.55		1	
08/26/25 12:28	454563.7		0.8		5.44		0.89		9.62		1	
08/26/25 12:29	453379.6		0.9		6.08		0.99		10.73		1	
08/26/25 12:30	450716.7		0.9		6.18		0.98		10.83		1	
08/26/25 12:31	452235.9		0.9		6.08		0.99		10.71		1	
08/26/25 12:32	451352.1		0.8		6.08		0.89		10.68		1	

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
08/26/25 12:33	449197.6			0.8			5.81			0.9			10.15			1		
08/26/25 12:34	449278.5			0.8			3.93			0.9			6.87			1		
08/26/25 12:35	439609.1			0.8			2.9			0.88			4.96			1		
08/26/25 12:36	448602.6			0.8			2.9			0.89			5.07			1		
08/26/25 12:37	450277.7			0.8			3.93			0.9			6.89			1		
08/26/25 12:38	454702.3			0.8			4.15			0.89			7.34			1		
08/26/25 12:39	460062.6			0.7			2.9			0.81			5.2			1		
08/26/25 12:40	461593.3			0.7			2.62			0.82			4.71			1		
08/26/25 12:41	465422.9			0.7			3.13			0.81			5.68			1		
08/26/25 12:42	464631.6			0.8			3.6			0.91			6.5			1		
08/26/25 12:43	465186.1			0.8			3.09			0.9			5.58			1		
08/26/25 12:44	465243.9			0.8			2.4			0.91			4.34			1		
08/26/25 12:45	466254.7			0.7			2.18			0.8			3.95			1		
08/26/25 12:46	465971.7			0.7			2.21			0.81			4.01			1		
08/26/25 12:47	466630.2			0.7			2.4			0.81			4.35			1		
08/26/25 12:48	466739.9			0.8			2.58			0.92			4.69			1		
08/26/25 12:49	465359.4			0.7			2.58			0.81			4.67			1		
08/26/25 12:50	465538.4			0.6			2.36			0.7			4.27			1		
08/26/25 12:51	466277.8			0.6			1.84			0.71			3.34			1		
08/26/25 12:52	466289.3			0.7			1.63			0.8			2.96			1		
08/26/25 12:53	465758			0.7			1.63			0.8			2.96			1		
08/26/25 12:54	466381.8			0.8			1.72			0.9			3.13			1		
08/26/25 12:55	464989.8			0.8			1.82			0.9			3.28			1		
08/26/25 12:56	466121.8			0.7			1.84			0.81			3.34			1		
08/26/25 12:57	467669.8			0.7			1.94			0.82			3.52			1		
08/26/25 12:58	465648.2			0.7			1.94			0.81			3.51			1		
08/26/25 12:59	467346.4			0.8			1.94			0.92			3.52			1		
08/26/25 13:00	464648.9			0.8			1.75			0.91			3.17			1		
08/26/25 13:01	466347.1			0.7			1.54			0.8			2.8			0		
08/26/25 13:02	465717.5			0.7			1.48			0.81			2.67			0		
08/26/25 13:03	466277.8			0.7			1.38			0.81			2.51			0		
08/26/25 13:04	463314.5			0.8			1.36			0.89			2.45			0		
08/26/25 13:05	447337.6			0.8			1.38			0.88			2.41			0		

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M		CT2_CO_Ppmvdc_1M		CT2_NOx_Ppmvdc_1M		CT2_CO_LbPerHr_1M		CT2_NOx_LbPerHr_1M		CT2_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
09/30/25 22:45	364460.8		1.1		1.52		0.92		2.14		0	
09/30/25 22:46	365078.8		1.1		1.52		0.92		2.15		0	
09/30/25 22:47	360902.6		1		1.52		0.83		2.12		0	
09/30/25 22:48	340044.8		1.1		1.52		0.86		2		0	
09/30/25 22:49	324108.2		1.1		1.52		0.82		1.91		0	
09/30/25 22:50	315594.1		1.2		1.61		0.86		1.96		1	
09/30/25 22:51	298028.7		1.1		1.84		0.77		2.13		1	
09/30/25 22:52	275137.7		1		2.67		0.66		2.85		1	
09/30/25 22:53	248492		0.9		4.84		0.51		4.65		1	
09/30/25 22:54	227304.9		0.7		10.75		0.39		9.45		1	
09/30/25 22:55	203044.9		4.8		21.71		2.31		17.05		1	
09/30/25 22:56	179530		122.2		25.65		51.58		17.81		1	
09/30/25 22:57	160462.8		671		30.09		253.08		18.68		1	
09/30/25 22:58	141280		1344.7		33.6		446.39		18.36		1	
09/30/25 22:59	44944.6		1865.4		39.59		197.08		6.88		1	
09/30/25 23:00	0		0		46.13		0		0		0	
09/30/25 23:01	0		0		0.2		0		0		0	
09/30/25 23:02	0		0		0.2		0		0		0	
09/30/25 23:03	0		0		0.1		0		0		0	
09/30/25 23:04	0		0		0.1		0		0		0	

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:03 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
07/01/2025	31.73	98.46	11.97	23.85	39.80
07/02/2025	30.00	87.48	10.82	21.66	36.08
07/03/2025	29.34	90.63	10.58	21.29	35.52
07/04/2025	28.43	91.68	10.47	21.00	35.02
07/05/2025	29.49	89.85	10.40	20.84	34.75
07/06/2025	27.58	82.04	10.87	21.74	36.27
07/07/2025	27.55	90.23	11.08	22.15	36.93
07/08/2025	27.63	91.83	10.88	21.77	36.32
07/09/2025	32.73	91.73	10.77	21.59	35.96
07/10/2025	35.81	93.68	11.02	21.97	36.72
07/11/2025	33.93	109.41	12.70	25.42	42.39
07/12/2025	34.15	86.90	10.87	21.71	36.26
07/13/2025	30.41	84.96	10.34	20.57	34.32
07/14/2025	31.13	80.58	10.14	20.29	33.80
07/15/2025	32.42	84.46	10.36	20.78	34.62
07/16/2025	32.92	87.69	10.56	21.17	35.35
07/17/2025	33.20	90.06	10.67	21.35	35.62
07/18/2025	32.79	85.47	10.46	20.94	34.90
07/19/2025	32.33	86.02	10.33	20.66	34.48
07/20/2025	32.42	86.41	10.32	20.64	34.45
07/21/2025	32.15	87.92	10.38	20.76	34.67
07/22/2025	31.82	86.27	10.32	20.66	34.57
07/23/2025	32.74	90.27	10.79	21.65	36.09
07/24/2025	31.92	87.95	10.40	20.84	34.77
07/25/2025	32.21	86.65	10.32	20.68	34.56
07/26/2025	31.87	89.55	10.34	20.71	34.60
07/27/2025	31.62	86.52	10.22	20.47	34.21
07/28/2025	35.69	106.26	11.26	22.59	37.59
07/29/2025	36.00	98.47	11.87	23.70	39.55
07/30/2025	31.75	87.60	10.42	20.86	34.80
07/31/2025	32.58	91.50	10.90	21.90	36.43
Monthly Avg/Sum:	986.34 sum	2,788.53 sum	332.83 sum	666.21 sum	1,111.40 sum
Daily Min:	27.55	80.58	10.14	20.29	33.80
Daily Max:	36.00	109.41	12.70	25.42	42.39
Jul 2025 - Jul 2025	986.34 sum	2,788.53 sum	332.83 sum	666.21 sum	1,111.40 sum
QTD:	986.34 sum	2,788.53 sum	332.83 sum	666.21 sum	1,111.40 sum
YTD 2025:	5,840.55 sum	12,647.10 sum	1,423.57 sum	2,849.67 sum	4,754.64 sum

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:03 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
08/01/2025	32.18	87.70	10.67	21.42	35.66
08/02/2025	32.34	91.15	10.82	21.58	35.96
08/03/2025	32.61	90.49	10.83	21.52	35.92
08/04/2025	32.88	91.94	10.66	21.16	35.34
08/05/2025	33.60	97.42	11.33	22.59	37.66
08/06/2025	42.35	126.94	13.20	25.91	43.88
08/07/2025	37.43	105.63	11.74	23.31	39.08
08/08/2025	37.97	100.92	11.60	22.95	38.47
08/09/2025	34.50	87.46	10.75	21.51	35.86
08/10/2025	37.05	105.07	12.00	23.88	39.99
08/11/2025	39.11	119.65	13.05	26.03	43.48
08/12/2025	40.76	121.27	13.44	26.68	44.79
08/13/2025	40.01	113.88	12.64	24.88	42.03
08/14/2025	32.88	90.02	10.80	21.49	35.84
08/15/2025	39.35	111.56	12.38	24.53	41.17
08/16/2025	38.03	117.18	11.99	23.82	39.98
08/17/2025	32.82	95.29	11.46	22.76	38.04
08/18/2025	37.81	110.08	12.64	25.19	42.18
08/19/2025	37.30	111.16	12.65	25.11	42.14
08/20/2025	46.59	157.07	15.22	30.26	50.71
08/21/2025	44.28	172.65	18.43	36.47	61.41
08/22/2025	41.67	170.38	17.71	35.24	59.09
08/23/2025	42.47	171.96	17.99	35.83	60.03
08/24/2025	48.96	155.53	16.36	32.46	54.55
08/25/2025	55.15	169.26	17.90	35.42	59.72
08/26/2025	102.38	133.67	12.61	24.83	41.99
08/27/2025	86.37	141.20	14.19	28.00	47.34
08/28/2025	49.38	143.85	15.22	30.02	50.66
08/29/2025	43.48	125.78	13.59	26.74	45.29
08/30/2025	40.33	134.12	14.16	27.88	47.09
08/31/2025	42.75	134.79	14.44	28.49	48.01
Monthly Avg/Sum:	1,334.79 sum	3,785.07 sum	412.47 sum	817.96 sum	1,373.36 sum
Daily Min:	32.18	87.46	10.66	21.16	35.34
Daily Max:	102.38	172.65	18.43	36.47	61.41
Jul 2025 - Aug 2025	2,321.13 sum	6,573.60 sum	745.30 sum	1,484.17 sum	2,484.76 sum
QTD:	2,321.13 sum	6,573.60 sum	745.30 sum	1,484.17 sum	2,484.76 sum
YTD 2025:	7,175.34 sum	16,432.17 sum	1,836.04 sum	3,667.63 sum	6,128.00 sum

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:03 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
09/01/2025	47.33	181.27	18.80	37.27	62.67
09/02/2025	51.67	211.77	21.51	42.63	71.65
09/03/2025	41.83	174.90	18.23	36.40	60.87
09/04/2025	47.04	153.52	16.79	33.43	56.06
09/05/2025	56.50	147.72	16.41	32.65	54.69
09/06/2025	49.49	123.51	14.28	28.54	47.63
09/07/2025	46.12	123.20	14.18	28.34	47.32
09/08/2025	52.31	132.88	14.95	29.79	49.82
09/09/2025	52.11	130.89	15.01	29.99	50.06
09/10/2025	53.40	120.78	13.95	27.94	46.61
09/11/2025	53.74	130.41	14.92	29.77	49.59
09/12/2025	48.92	122.58	14.18	28.37	47.34
09/13/2025	46.96	114.15	13.28	26.54	44.25
09/14/2025	45.48	114.35	13.25	26.51	44.16
09/15/2025	52.16	133.33	15.25	30.51	50.85
09/16/2025	55.35	151.51	16.56	33.04	55.29
09/17/2025	49.90	163.71	17.20	34.24	57.35
09/18/2025	40.41	136.01	15.40	30.86	51.45
09/19/2025	50.64	133.22	15.33	30.74	51.15
09/20/2025	50.13	133.24	15.29	30.55	51.01
09/21/2025	42.29	133.59	15.35	30.60	51.07
09/22/2025	46.41	129.07	14.81	29.61	49.40
09/23/2025	56.38	158.82	17.17	34.09	57.24
09/24/2025	45.70	134.12	15.28	30.55	50.90
09/25/2025	46.11	133.12	15.25	30.47	50.80
09/26/2025	45.29	122.35	14.05	28.16	46.91
09/27/2025	47.98	117.00	13.59	27.10	45.24
09/28/2025	56.90	121.69	14.07	28.18	46.95
09/29/2025	57.41	129.31	14.88	29.81	49.60
09/30/2025	106.90	125.61	13.94	27.94	46.57
Monthly Avg/Sum:	1,542.86 sum	4,137.63 sum	463.16 sum	924.62 sum	1,544.50 sum
Daily Min:	40.41	114.15	13.25	26.51	44.16
Daily Max:	106.90	211.77	21.51	42.63	71.65
Jul 2025 - Sep 2025	3,863.99 sum	10,711.23 sum	1,208.46 sum	2,408.79 sum	4,029.26 sum
QTD:	3,863.99 sum	10,711.23 sum	1,208.46 sum	2,408.79 sum	4,029.26 sum
YTD 2025:	8,718.20 sum	20,569.80 sum	2,299.20 sum	4,592.25 sum	7,672.50 sum

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
07/01/2025	31.73	98.46	11.97	23.85	39.80
07/02/2025	30.00	87.48	10.82	21.66	36.08
07/03/2025	29.34	90.63	10.58	21.29	35.52
07/04/2025	28.43	91.68	10.47	21.00	35.02
07/05/2025	29.49	89.85	10.40	20.84	34.75
07/06/2025	27.58	82.04	10.87	21.74	36.27
07/07/2025	27.55	90.23	11.08	22.15	36.93
07/08/2025	27.63	91.83	10.88	21.77	36.32
07/09/2025	32.73	91.73	10.77	21.59	35.96
07/10/2025	35.81	93.68	11.02	21.97	36.72
07/11/2025	33.93	109.41	12.70	25.42	42.39
07/12/2025	34.15	86.90	10.87	21.71	36.26
07/13/2025	30.41	84.96	10.34	20.57	34.32
07/14/2025	31.13	80.58	10.14	20.29	33.80
07/15/2025	32.42	84.46	10.36	20.78	34.62
07/16/2025	32.92	87.69	10.56	21.17	35.35
07/17/2025	33.20	90.06	10.67	21.35	35.62
07/18/2025	32.79	85.47	10.46	20.94	34.90
07/19/2025	32.33	86.02	10.33	20.66	34.48
07/20/2025	32.42	86.41	10.32	20.64	34.45
07/21/2025	32.15	87.92	10.38	20.76	34.67
07/22/2025	31.82	86.27	10.32	20.66	34.57
07/23/2025	32.74	90.27	10.79	21.65	36.09
07/24/2025	31.92	87.95	10.40	20.84	34.77
07/25/2025	32.21	86.65	10.32	20.68	34.56
07/26/2025	31.87	89.55	10.34	20.71	34.60
07/27/2025	31.62	86.52	10.22	20.47	34.21
07/28/2025	35.69	106.26	11.26	22.59	37.59
07/29/2025	36.00	98.47	11.87	23.70	39.55
07/30/2025	31.75	87.60	10.42	20.86	34.80
07/31/2025	32.58	91.50	10.90	21.90	36.43
Monthly Avg/Sum:	986.34 sum	2,788.53 sum	332.83 sum	666.21 sum	1,111.40 sum
Daily Min:	27.55	80.58	10.14	20.29	33.80
Daily Max:	36.00	109.41	12.70	25.42	42.39
Jul 2025 - Jul 2025	986.34 sum	2,788.53 sum	332.83 sum	666.21 sum	1,111.40 sum
QTD:	986.34 sum	2,788.53 sum	332.83 sum	666.21 sum	1,111.40 sum
YTD 2025:	5,840.55 sum	12,647.10 sum	1,423.57 sum	2,849.67 sum	4,754.64 sum

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
08/01/2025	32.18	87.70	10.67	21.42	35.66
08/02/2025	32.34	91.15	10.82	21.58	35.96
08/03/2025	32.61	90.49	10.83	21.52	35.92
08/04/2025	32.88	91.94	10.66	21.16	35.34
08/05/2025	33.60	97.42	11.33	22.59	37.66
08/06/2025	42.35	126.94	13.20	25.91	43.88
08/07/2025	37.43	105.63	11.74	23.31	39.08
08/08/2025	37.97	100.92	11.60	22.95	38.47
08/09/2025	34.50	87.46	10.75	21.51	35.86
08/10/2025	37.05	105.07	12.00	23.88	39.99
08/11/2025	39.11	119.65	13.05	26.03	43.48
08/12/2025	40.76	121.27	13.44	26.68	44.79
08/13/2025	40.01	113.88	12.64	24.88	42.03
08/14/2025	32.88	90.02	10.80	21.49	35.84
08/15/2025	39.35	111.56	12.38	24.53	41.17
08/16/2025	38.03	117.18	11.99	23.82	39.98
08/17/2025	32.82	95.29	11.46	22.76	38.04
08/18/2025	37.81	110.08	12.64	25.19	42.18
08/19/2025	37.30	111.16	12.65	25.11	42.14
08/20/2025	46.59	157.07	15.22	30.26	50.71
08/21/2025	44.28	172.65	18.43	36.47	61.41
08/22/2025	41.67	170.38	17.71	35.24	59.09
08/23/2025	42.47	171.96	17.99	35.83	60.03
08/24/2025	48.96	155.53	16.36	32.46	54.55
08/25/2025	55.15	169.26	17.90	35.42	59.72
08/26/2025	102.38	133.67	12.61	24.83	41.99
08/27/2025	86.37	141.20	14.19	28.00	47.34
08/28/2025	49.38	143.85	15.22	30.02	50.66
08/29/2025	43.48	125.78	13.59	26.74	45.29
08/30/2025	40.33	134.12	14.16	27.88	47.09
08/31/2025	42.75	134.79	14.44	28.49	48.01
Monthly Avg/Sum:	1,334.79 sum	3,785.07 sum	412.47 sum	817.96 sum	1,373.36 sum
Daily Min:	32.18	87.46	10.66	21.16	35.34
Daily Max:	102.38	172.65	18.43	36.47	61.41
Jul 2025 - Aug 2025	2,321.13 sum	6,573.60 sum	745.30 sum	1,484.17 sum	2,484.76 sum
QTD:	2,321.13 sum	6,573.60 sum	745.30 sum	1,484.17 sum	2,484.76 sum
YTD 2025:	7,175.34 sum	16,432.17 sum	1,836.04 sum	3,667.63 sum	6,128.00 sum

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:20 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
09/01/2025	47.33	181.27	18.80	37.27	62.67
09/02/2025	51.67	211.77	21.51	42.63	71.65
09/03/2025	41.83	174.90	18.23	36.40	60.87
09/04/2025	47.04	153.52	16.79	33.43	56.06
09/05/2025	56.50	147.72	16.41	32.65	54.69
09/06/2025	49.49	123.51	14.28	28.54	47.63
09/07/2025	46.12	123.20	14.18	28.34	47.32
09/08/2025	52.31	132.88	14.95	29.79	49.82
09/09/2025	52.11	130.89	15.01	29.99	50.06
09/10/2025	53.40	120.78	13.95	27.94	46.61
09/11/2025	53.74	130.41	14.92	29.77	49.59
09/12/2025	48.92	122.58	14.18	28.37	47.34
09/13/2025	46.96	114.15	13.28	26.54	44.25
09/14/2025	45.48	114.35	13.25	26.51	44.16
09/15/2025	52.16	133.33	15.25	30.51	50.85
09/16/2025	55.35	151.51	16.56	33.04	55.29
09/17/2025	49.90	163.71	17.20	34.24	57.35
09/18/2025	40.41	136.01	15.40	30.86	51.45
09/19/2025	50.64	133.22	15.33	30.74	51.15
09/20/2025	50.13	133.24	15.29	30.55	51.01
09/21/2025	42.29	133.59	15.35	30.60	51.07
09/22/2025	46.41	129.07	14.81	29.61	49.40
09/23/2025	56.38	158.82	17.17	34.09	57.24
09/24/2025	45.70	134.12	15.28	30.55	50.90
09/25/2025	46.11	133.12	15.25	30.47	50.80
09/26/2025	45.29	122.35	14.05	28.16	46.91
09/27/2025	47.98	117.00	13.59	27.10	45.24
09/28/2025	56.90	121.69	14.07	28.18	46.95
09/29/2025	57.41	129.31	14.88	29.81	49.60
09/30/2025	106.90	125.61	13.94	27.94	46.57
Monthly Avg/Sum:	1,542.86 sum	4,137.63 sum	463.16 sum	924.62 sum	1,544.50 sum
Daily Min:	40.41	114.15	13.25	26.51	44.16
Daily Max:	106.90	211.77	21.51	42.63	71.65
Jul 2025 - Sep 2025	3,863.99 sum	10,711.23 sum	1,208.46 sum	2,408.79 sum	4,029.26 sum
QTD:	3,863.99 sum	10,711.23 sum	1,208.46 sum	2,408.79 sum	4,029.26 sum
YTD 2025:	8,718.20 sum	20,569.80 sum	2,299.20 sum	4,592.25 sum	7,672.50 sum

Monthly Summary By Day Report



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO_SUSD, LbPerHr	NOX_SUSD, LbPerHr	CO_SUSD, LbPerHr	NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/01/2025	0.0	0.0	0.0	0.0
07/02/2025	0.0	0.0	0.0	0.0
07/03/2025	0.0	0.0	0.0	0.0
07/04/2025	0.0	0.0	0.0	0.0
07/05/2025	0.0	0.0	0.0	0.0
07/06/2025	0.0	0.0	0.0	0.0
07/07/2025	0.0	0.0	0.0	0.0
07/08/2025	0.0	0.0	0.0	0.0
07/09/2025	0.0	0.0	0.0	0.0
07/10/2025	0.0	0.0	0.0	0.0
07/11/2025	0.0	0.0	0.0	0.0
07/12/2025	0.0	0.0	0.0	0.0
07/13/2025	0.0	0.0	4.2	11.9
07/14/2025	0.0	0.0	1.4	3.6
07/15/2025	0.0	0.0	0.0	0.0
07/16/2025	0.0	0.0	0.0	0.0
07/17/2025	0.0	0.0	0.0	0.0
07/18/2025	0.0	0.0	0.0	0.0
07/19/2025	0.0	0.0	0.0	0.0
07/20/2025	0.0	0.0	0.0	0.0
07/21/2025	0.0	0.0	0.0	0.0
07/22/2025	0.0	0.0	0.0	0.0
07/23/2025	0.0	0.0	0.0	0.0
07/24/2025	0.0	0.0	0.0	0.0
07/25/2025	0.0	0.0	0.0	0.0
07/26/2025	0.0	0.0	0.0	0.0
07/27/2025	0.0	0.0	0.4	1.1
07/28/2025	0.0	0.0	0.0	0.0
07/29/2025	0.0	0.0	0.0	0.0
07/30/2025	0.0	0.0	0.0	0.0
07/31/2025	0.0	0.0	0.0	0.0
Monthly Avg/Sum:	0.0 sum	0.0 sum	6.0 sum	16.6 sum
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	0.0	0.0	4.2	11.9
Jul 2025 - Jul 2025	0.0 sum	0.0 sum	6.0 sum	16.6 sum
QTD:	0.0 sum	0.0 sum	6.0 sum	16.6 sum
YTD 2025:	959.1 sum	204.7 sum	615.3 sum	97.5 sum

Monthly Summary By Day Report



From: 07/01/2025 00:00 **To:** 09/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2025 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO_SUSD, LbPerHr	NOX_SUSD, LbPerHr	CO_SUSD, LbPerHr	NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/01/2025	0.0	0.0	0.0	0.0
08/02/2025	0.0	0.0	0.0	0.0
08/03/2025	0.0	0.0	0.0	0.0
08/04/2025	0.0	0.0	0.9	2.4
08/05/2025	0.0	0.0	0.0	0.0
08/06/2025	0.0	0.0	0.0	0.0
08/07/2025	0.0	0.0	0.0	0.0
08/08/2025	0.0	0.0	0.0	0.0
08/09/2025	0.0	0.0	0.0	0.0
08/10/2025	0.0	0.0	0.0	0.0
08/11/2025	0.0	0.0	0.0	0.0
08/12/2025	0.0	0.0	0.0	0.0
08/13/2025	0.0	0.0	0.0	0.0
08/14/2025	0.0	0.0	0.0	0.0
08/15/2025	0.0	0.0	0.0	0.0
08/16/2025	0.0	0.0	0.0	0.0
08/17/2025	0.0	0.0	0.0	0.0
08/18/2025	0.0	0.0	0.0	0.0
08/19/2025	0.0	0.0	0.0	0.0
08/20/2025	0.0	0.0	0.0	0.0
08/21/2025	0.0	0.0	0.0	0.0
08/22/2025	0.0	0.0	0.0	0.0
08/23/2025	0.0	0.0	0.0	0.0
08/24/2025	0.0	0.0	0.0	0.0
08/25/2025	0.0	0.0	0.0	0.0
08/26/2025	17.7	0.8	28.2	7.7
08/27/2025	35.4	10.6	0.0	0.0
08/28/2025	0.0	0.0	0.0	0.0
08/29/2025	0.0	0.0	0.0	0.0
08/30/2025	0.0	0.0	0.0	0.0
08/31/2025	0.0	0.0	0.0	0.0
Monthly Avg/Sum:	53.1 sum	11.4 sum	29.1 sum	10.1 sum
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	35.4	10.6	28.2	7.7
Jul 2025 - Aug 2025	53.1 sum	11.4 sum	35.1 sum	26.7 sum
QTD:	53.1 sum	11.4 sum	35.1 sum	26.7 sum
YTD 2025:	1,012.2 sum	216.1 sum	644.4 sum	107.6 sum

Monthly Summary By Day Report



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO_SUSD, LbPerHr	NOX_SUSD, LbPerHr	CO_SUSD, LbPerHr	NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/01/2025	0.0	0.0	0.0	0.0
09/02/2025	0.0	0.0	0.0	0.0
09/03/2025	0.0	0.0	0.0	0.0
09/04/2025	0.0	0.0	0.0	0.0
09/05/2025	0.0	0.0	0.0	0.0
09/06/2025	0.0	0.0	0.0	0.0
09/07/2025	0.0	0.0	0.0	0.0
09/08/2025	0.0	0.0	0.0	0.0
09/09/2025	0.0	0.0	0.0	0.0
09/10/2025	0.0	0.0	0.0	0.0
09/11/2025	0.0	0.0	0.0	0.0
09/12/2025	0.0	0.0	0.0	0.0
09/13/2025	0.0	0.0	0.0	0.0
09/14/2025	0.0	0.0	0.0	0.0
09/15/2025	0.0	0.0	0.0	0.0
09/16/2025	0.0	0.0	0.0	0.0
09/17/2025	0.0	0.0	0.0	0.0
09/18/2025	0.0	0.0	0.0	0.0
09/19/2025	0.0	0.0	0.0	0.0
09/20/2025	0.0	0.0	0.0	0.0
09/21/2025	0.0	0.0	0.0	0.0
09/22/2025	0.0	0.0	0.0	0.0
09/23/2025	0.0	0.0	0.0	0.0
09/24/2025	0.0	0.0	0.0	0.0
09/25/2025	0.0	0.0	0.0	0.0
09/26/2025	0.0	0.0	0.0	0.0
09/27/2025	0.0	0.0	0.0	0.0
09/28/2025	0.0	0.0	0.0	0.0
09/29/2025	0.0	0.0	0.0	0.0
09/30/2025	32.9	1.0	15.9	1.6
Monthly Avg/Sum:	32.9 sum	1.0 sum	15.9 sum	1.6 sum
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	32.9	1.0	15.9	1.6
Jul 2025 - Sep 2025	86.0 sum	12.4 sum	51.0 sum	28.3 sum
QTD:	86.0 sum	12.4 sum	51.0 sum	28.3 sum
YTD 2025:	1,045.1 sum	217.1 sum	660.3 sum	109.2 sum

Tons 12 Month Rolling Summary

CT1 and CT2 Combined



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

* = Excess Emission

Date	Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2	
	CO, Ton		NOx, Ton		PM10, Ton		SO2, Ton		VOC, Ton	
	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)	1 Day(s)
	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Jul 2025	0.4934	5.2959	1.3940	12.2696	0.3331	2.8103	0.1665	1.4052	0.5558	4.6841
Aug 2025	0.6675	5.4425	1.8924	12.7838	0.4089	2.8727	0.2062	1.4389	0.6865	4.7941
Sep 2025	0.7718	5.7686	2.0691	13.3092	0.4625	2.9817	0.2315	1.4930	0.7721	4.9774
Sum/Avg	5.7686		13.3092		2.9817		1.4930		4.9774	
Limit Value										

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/01/2025 00:00	0.6	1.1	1	0.49	0.24582	0.82
07/01/2025 01:00	0.7	1.2	1	0.50	0.25116	0.84
07/01/2025 02:00	0.7	1.3	1	0.51	0.25716	0.86
07/01/2025 03:00	0.7	1.3	0	0.51	0.25728	0.86
07/01/2025 04:00	0.7	1.2	1	0.51	0.25722	0.86
07/01/2025 05:00	0.7	1.0	1	0.44	0.21984	0.73
07/01/2025 06:00	0.7	1.2	1	0.43	0.21666	0.72
07/01/2025 07:00	0.7	1.2	1	0.43	0.21684	0.72
07/01/2025 08:00	0.7	1.2	1	0.43	0.21642	0.72
07/01/2025 09:00	0.6	1.2	1	0.44	0.21756	0.73
07/01/2025 10:00	0.6	1.2	1	0.44	0.22074	0.74
07/01/2025 11:00	0.6	1.1	1	0.46	0.22944	0.76
07/01/2025 12:00	0.6	1.3	0	0.52	0.25878	0.86
07/01/2025 13:00	0.6	1.2	1	0.53	0.26298	0.88
07/01/2025 14:00	0.6	1.3	1	0.53	0.26274	0.88
07/01/2025 15:00	0.6	1.2	1	0.53	0.26250	0.88
07/01/2025 16:00	0.6	1.2	1	0.48	0.23958	0.80
07/01/2025 17:00	0.6	1.2	1	0.48	0.23760	0.79
07/01/2025 18:00	0.6	1.3	1	0.52	0.26232	0.87
07/01/2025 19:00	0.6	1.0	1	0.48	0.23910	0.80
07/01/2025 20:00	0.7	1.1	1	0.46	0.23190	0.77
07/01/2025 21:00	0.6	1.1	1	0.49	0.24588	0.82
07/01/2025 22:00	0.7	1.0	1	0.44	0.22200	0.74
07/01/2025 23:00	0.6	1.2	1	0.51	0.25626	0.85
Average/Sum#:	0.6	1.2	1	0.48	0.24116	0.80
Minimum:	0.6	1.0	0	0.43	0.21642	0.72
Maximum:	0.7	1.3	1	0.53	0.26298	0.88
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/02/2025 00:00	0.7	1.2	1	0.44	0.21756	0.73
07/02/2025 01:00	0.6	1.2	1	0.43	0.21696	0.72
07/02/2025 02:00	0.7	1.0	1	0.43	0.21684	0.72
07/02/2025 03:00	0.8	1.3	1	0.43	0.21678	0.72
07/02/2025 04:00	0.7	1.2	1	0.43	0.21708	0.72
07/02/2025 05:00	0.7	1.2	1	0.43	0.21690	0.72
07/02/2025 06:00	0.7	1.1	1	0.43	0.21690	0.72
07/02/2025 07:00	0.7	1.1	1	0.43	0.21672	0.72
07/02/2025 08:00	0.7	1.2	1	0.43	0.21636	0.72
07/02/2025 09:00	0.6	1.2	1	0.43	0.21594	0.72
07/02/2025 10:00	0.6	1.3	1	0.43	0.21570	0.72
07/02/2025 11:00	0.6	1.0	1	0.43	0.21630	0.72
07/02/2025 12:00	0.6	1.0	1	0.43	0.21642	0.72
07/02/2025 13:00	0.6	0.9	1	0.43	0.21624	0.72
07/02/2025 14:00	0.6	0.9	1	0.45	0.22290	0.74
07/02/2025 15:00	0.6	1.2	0	0.52	0.25986	0.87
07/02/2025 16:00	0.6	1.1	1	0.44	0.21804	0.73
07/02/2025 17:00	0.6	0.9	1	0.43	0.21576	0.72
07/02/2025 18:00	0.6	1.1	1	0.47	0.23382	0.78
07/02/2025 19:00	0.6	1.1	1	0.43	0.21450	0.72
07/02/2025 20:00	0.6	1.1	1	0.43	0.21468	0.72
07/02/2025 21:00	0.6	1.2	1	0.43	0.21492	0.72
07/02/2025 22:00	0.6	1.1	1	0.43	0.21510	0.72
07/02/2025 23:00	0.6	1.2	1	0.43	0.21534	0.72
Average/Sum#:	0.6	1.1	1	0.44	0.21907	0.73
Minimum:	0.6	0.9	0	0.43	0.21450	0.72
Maximum:	0.8	1.3	1	0.52	0.25986	0.87
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/03/2025 00:00	0.6	1.2	1	0.43	0.21552	0.72
07/03/2025 01:00	0.6	1.2	1	0.43	0.21570	0.72
07/03/2025 02:00	0.6	0.9	1	0.43	0.21582	0.72
07/03/2025 03:00	0.7	1.2	1	0.43	0.21600	0.72
07/03/2025 04:00	0.6	1.2	1	0.43	0.21600	0.72
07/03/2025 05:00	0.6	1.3	1	0.43	0.21624	0.72
07/03/2025 06:00	0.6	1.3	1	0.43	0.21576	0.72
07/03/2025 07:00	0.6	1.3	1	0.43	0.21576	0.72
07/03/2025 08:00	0.6	1.3	1	0.43	0.21558	0.72
07/03/2025 09:00	0.6	1.3	1	0.43	0.21528	0.72
07/03/2025 10:00	0.6	1.3	1	0.43	0.21492	0.72
07/03/2025 11:00	0.6	1.3	1	0.43	0.21558	0.72
07/03/2025 12:00	0.6	1.2	1	0.43	0.21552	0.72
07/03/2025 13:00	0.6	1.2	1	0.43	0.21558	0.72
07/03/2025 14:00	0.6	1.2	1	0.43	0.21540	0.72
07/03/2025 15:00	0.6	1.3	1	0.43	0.21510	0.72
07/03/2025 16:00	0.6	1.3	1	0.43	0.21510	0.72
07/03/2025 17:00	0.6	1.3	1	0.43	0.21486	0.72
07/03/2025 18:00	0.6	1.3	1	0.43	0.21492	0.72
07/03/2025 19:00	0.6	1.3	1	0.43	0.21528	0.72
07/03/2025 20:00	0.6	1.4	1	0.43	0.21546	0.72
07/03/2025 21:00	0.6	1.4	1	0.43	0.21576	0.72
07/03/2025 22:00	0.6	1.4	1	0.43	0.21606	0.72
07/03/2025 23:00	0.6	1.3	1	0.43	0.21654	0.72
Average/Sum#:	0.6	1.3	1	0.43	0.21557	0.72
Minimum:	0.6	0.9	1	0.43	0.21486	0.72
Maximum:	0.7	1.4	1	0.43	0.21654	0.72
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/04/2025 00:00	0.6	1.2	1	0.48	0.24186	0.81
07/04/2025 01:00	0.6	1.2	1	0.42	0.21162	0.71
07/04/2025 02:00	0.6	1.3	1	0.44	0.22026	0.73
07/04/2025 03:00	0.7	1.3	1	0.42	0.21048	0.70
07/04/2025 04:00	0.6	1.4	1	0.42	0.21060	0.70
07/04/2025 05:00	0.6	1.4	1	0.42	0.21066	0.70
07/04/2025 06:00	0.6	1.3	1	0.42	0.21048	0.70
07/04/2025 07:00	0.6	1.4	1	0.42	0.21048	0.70
07/04/2025 08:00	0.6	1.3	1	0.42	0.21012	0.70
07/04/2025 09:00	0.6	1.3	1	0.42	0.20988	0.70
07/04/2025 10:00	0.6	1.4	1	0.42	0.20958	0.70
07/04/2025 11:00	0.6	1.4	1	0.42	0.21024	0.70
07/04/2025 12:00	0.6	1.4	1	0.42	0.21024	0.70
07/04/2025 13:00	0.6	1.4	1	0.42	0.21018	0.70
07/04/2025 14:00	0.6	1.4	1	0.42	0.21000	0.70
07/04/2025 15:00	0.6	1.4	1	0.42	0.20988	0.70
07/04/2025 16:00	0.6	1.4	1	0.42	0.20994	0.70
07/04/2025 17:00	0.6	1.4	1	0.43	0.21498	0.72
07/04/2025 18:00	0.6	1.1	1	0.45	0.22644	0.75
07/04/2025 19:00	0.6	1.1	1	0.42	0.20970	0.70
07/04/2025 20:00	0.6	1.3	1	0.42	0.21000	0.70
07/04/2025 21:00	0.6	1.4	1	0.42	0.21048	0.70
07/04/2025 22:00	0.6	1.2	1	0.42	0.21048	0.70
07/04/2025 23:00	0.6	1.3	1	0.42	0.21072	0.70
Average/Sum#:	0.6	1.3	1	0.43	0.21289	0.71
Minimum:	0.6	1.1	1	0.42	0.20958	0.70
Maximum:	0.7	1.4	1	0.48	0.24186	0.81
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 **To:** 09/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/05/2025 00:00	0.6	1.4	1	0.42	0.21090	0.70
07/05/2025 01:00	0.6	1.2	1	0.42	0.21120	0.70
07/05/2025 02:00	0.6	1.3	1	0.42	0.21144	0.70
07/05/2025 03:00	0.7	1.4	1	0.42	0.21144	0.70
07/05/2025 04:00	0.7	1.3	1	0.42	0.21156	0.71
07/05/2025 05:00	0.7	1.2	1	0.42	0.21162	0.71
07/05/2025 06:00	0.7	1.1	1	0.42	0.21162	0.71
07/05/2025 07:00	0.7	1.2	1	0.42	0.21180	0.71
07/05/2025 08:00	0.6	1.3	1	0.42	0.21120	0.70
07/05/2025 09:00	0.6	1.4	1	0.42	0.21084	0.70
07/05/2025 10:00	0.6	1.2	1	0.42	0.21054	0.70
07/05/2025 11:00	0.6	1.4	1	0.42	0.21060	0.70
07/05/2025 12:00	0.6	1.4	1	0.42	0.21060	0.70
07/05/2025 13:00	0.6	1.3	1	0.42	0.21084	0.70
07/05/2025 14:00	0.6	1.3	1	0.42	0.21066	0.70
07/05/2025 15:00	0.6	1.4	1	0.42	0.21018	0.70
07/05/2025 16:00	0.6	1.4	1	0.42	0.21000	0.70
07/05/2025 17:00	0.6	1.4	1	0.42	0.20976	0.70
07/05/2025 18:00	0.6	1.3	1	0.46	0.22758	0.76
07/05/2025 19:00	0.6	1.1	1	0.42	0.20916	0.70
07/05/2025 20:00	0.6	1.3	1	0.42	0.20922	0.70
07/05/2025 21:00	0.6	1.3	1	0.42	0.20952	0.70
07/05/2025 22:00	0.6	1.3	1	0.42	0.20976	0.70
07/05/2025 23:00	0.6	1.3	1	0.42	0.20982	0.70
Average/Sum#:	0.6	1.3	1	0.42	0.21133	0.70
Minimum:	0.6	1.1	1	0.42	0.20916	0.70
Maximum:	0.7	1.4	1	0.46	0.22758	0.76
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/06/2025 00:00	0.6	1.3	1	0.42	0.21006	0.70
07/06/2025 01:00	0.7	1.3	1	0.42	0.21036	0.70
07/06/2025 02:00	0.6	1.3	1	0.42	0.21036	0.70
07/06/2025 03:00	0.7	1.2	1	0.42	0.21048	0.70
07/06/2025 04:00	0.7	1.2	2	0.42	0.21072	0.70
07/06/2025 05:00	0.7	1.2	1	0.42	0.21090	0.70
07/06/2025 06:00	0.7	1.2	1	0.42	0.21078	0.70
07/06/2025 07:00	0.7	1.2	1	0.42	0.21060	0.70
07/06/2025 08:00	0.7	1.2	1	0.42	0.21012	0.70
07/06/2025 09:00	0.6	1.3	1	0.42	0.20970	0.70
07/06/2025 10:00	0.6	1.3	1	0.42	0.20910	0.70
07/06/2025 11:00	0.6	1.3	1	0.42	0.20976	0.70
07/06/2025 12:00	0.6	1.2	1	0.42	0.20958	0.70
07/06/2025 13:00	0.6	1.2	1	0.42	0.21234	0.71
07/06/2025 14:00	0.6	1.3	1	0.44	0.22158	0.74
07/06/2025 15:00	0.7	1.3	1	0.42	0.20946	0.70
07/06/2025 16:00	0.6	1.3	1	0.46	0.22752	0.76
07/06/2025 17:00	0.6	1.1	1	0.46	0.23160	0.77
07/06/2025 18:00	0.6	1.1	1	0.51	0.25410	0.85
07/06/2025 19:00	0.6	1.2	1	0.51	0.25614	0.85
07/06/2025 20:00	0.6	1.2	1	0.51	0.25590	0.85
07/06/2025 21:00	0.6	1.2	1	0.51	0.25404	0.85
07/06/2025 22:00	0.7	1.2	1	0.45	0.22542	0.75
07/06/2025 23:00	0.6	1.3	1	0.50	0.24810	0.83
Average/Sum#:	0.6	1.2	1	0.44	0.22203	0.74
Minimum:	0.6	1.1	1	0.42	0.20910	0.70
Maximum:	0.7	1.3	2	0.51	0.25614	0.85
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/07/2025 00:00	0.6	1.2	1	0.47	0.23604	0.79
07/07/2025 01:00	0.7	1.1	1	0.42	0.20934	0.70
07/07/2025 02:00	0.6	1.2	1	0.42	0.20928	0.70
07/07/2025 03:00	0.7	1.3	1	0.44	0.21804	0.73
07/07/2025 04:00	0.7	1.1	1	0.42	0.20988	0.70
07/07/2025 05:00	0.6	1.2	1	0.42	0.20994	0.70
07/07/2025 06:00	0.6	1.2	1	0.42	0.20976	0.70
07/07/2025 07:00	0.6	1.2	1	0.42	0.20982	0.70
07/07/2025 08:00	0.6	1.2	1	0.42	0.20952	0.70
07/07/2025 09:00	0.6	1.2	1	0.42	0.20904	0.70
07/07/2025 10:00	0.6	1.3	1	0.42	0.20880	0.70
07/07/2025 11:00	0.6	1.3	1	0.42	0.20922	0.70
07/07/2025 12:00	0.6	1.0	1	0.43	0.21348	0.71
07/07/2025 13:00	0.6	1.0	1	0.44	0.21966	0.73
07/07/2025 14:00	0.6	1.2	1	0.47	0.23460	0.78
07/07/2025 15:00	0.6	0.9	1	0.42	0.21144	0.70
07/07/2025 16:00	0.6	1.1	1	0.45	0.22260	0.74
07/07/2025 17:00	0.6	1.2	1	0.48	0.23754	0.79
07/07/2025 18:00	0.6	1.3	1	0.51	0.25608	0.85
07/07/2025 19:00	0.6	1.3	1	0.51	0.25512	0.85
07/07/2025 20:00	0.6	1.3	1	0.51	0.25512	0.85
07/07/2025 21:00	0.6	1.2	1	0.49	0.24324	0.81
07/07/2025 22:00	0.6	1.1	1	0.46	0.23220	0.77
07/07/2025 23:00	0.6	1.2	1	0.51	0.25518	0.85
Average/Sum#:	0.6	1.2	1	0.45	0.22437	0.75
Minimum:	0.6	0.9	1	0.42	0.20880	0.70
Maximum:	0.7	1.3	1	0.51	0.25608	0.85
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/08/2025 00:00	0.6	1.2	1	0.51	0.25566	0.85
07/08/2025 01:00	0.6	1.2	1	0.51	0.25518	0.85
07/08/2025 02:00	0.6	1.1	1	0.51	0.25524	0.85
07/08/2025 03:00	0.7	1.3	1	0.43	0.21318	0.71
07/08/2025 04:00	0.6	1.1	1	0.48	0.23958	0.80
07/08/2025 05:00	0.7	1.2	1	0.46	0.22752	0.76
07/08/2025 06:00	0.7	1.3	1	0.42	0.21048	0.70
07/08/2025 07:00	0.7	1.3	1	0.42	0.21042	0.70
07/08/2025 08:00	0.6	1.3	1	0.42	0.21000	0.70
07/08/2025 09:00	0.6	1.4	1	0.42	0.20976	0.70
07/08/2025 10:00	0.6	1.3	1	0.42	0.20940	0.70
07/08/2025 11:00	0.6	1.2	2	0.42	0.20988	0.70
07/08/2025 12:00	0.6	1.2	1	0.42	0.20988	0.70
07/08/2025 13:00	0.6	1.1	1	0.42	0.20976	0.70
07/08/2025 14:00	0.6	1.1	1	0.42	0.20952	0.70
07/08/2025 15:00	0.6	1.2	1	0.42	0.20934	0.70
07/08/2025 16:00	0.6	1.2	1	0.42	0.20922	0.70
07/08/2025 17:00	0.6	1.3	1	0.43	0.21396	0.71
07/08/2025 18:00	0.6	1.1	1	0.48	0.23958	0.80
07/08/2025 19:00	0.6	1.1	1	0.47	0.23388	0.78
07/08/2025 20:00	0.6	1.3	1	0.43	0.21300	0.71
07/08/2025 21:00	0.6	1.5	1	0.42	0.20928	0.70
07/08/2025 22:00	0.6	1.2	1	0.42	0.21102	0.70
07/08/2025 23:00	0.6	1.2	1	0.43	0.21702	0.72
Average/Sum#:	0.6	1.2	1	0.44	0.22049	0.74
Minimum:	0.6	1.1	1	0.42	0.20922	0.70
Maximum:	0.7	1.5	2	0.51	0.25566	0.85
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/09/2025 00:00	0.6	1.3	1	0.42	0.21024	0.70
07/09/2025 01:00	0.6	1.4	1	0.42	0.21060	0.70
07/09/2025 02:00	0.6	1.4	1	0.42	0.21096	0.70
07/09/2025 03:00	0.7	1.2	1	0.42	0.21102	0.70
07/09/2025 04:00	0.7	1.3	1	0.42	0.21114	0.70
07/09/2025 05:00	0.7	1.2	1	0.42	0.21246	0.71
07/09/2025 06:00	0.7	1.3	1	0.42	0.21078	0.70
07/09/2025 07:00	0.7	0.9	1	0.42	0.21084	0.70
07/09/2025 08:00	0.8	1.4	1	0.42	0.21048	0.70
07/09/2025 09:00	0.7	1.3	1	0.42	0.21030	0.70
07/09/2025 10:00	0.7	1.2	1	0.42	0.20982	0.70
07/09/2025 11:00	0.6	1.4	1	0.42	0.20982	0.70
07/09/2025 12:00	0.7	1.5	1	0.42	0.21006	0.70
07/09/2025 13:00	0.7	1.4	1	0.42	0.20970	0.70
07/09/2025 14:00	0.7	1.2	1	0.42	0.20928	0.70
07/09/2025 15:00	0.7	1.3	1	0.42	0.20904	0.70
07/09/2025 16:00	0.7	1.4	1	0.43	0.21678	0.72
07/09/2025 17:00	0.7	1.3	1	0.44	0.22044	0.73
07/09/2025 18:00	0.7	1.2	1	0.49	0.24504	0.82
07/09/2025 19:00	0.7	1.2	1	0.50	0.25020	0.83
07/09/2025 20:00	0.7	1.1	1	0.46	0.22962	0.77
07/09/2025 21:00	0.7	1.2	1	0.49	0.24720	0.82
07/09/2025 22:00	0.8	1.1	1	0.47	0.23562	0.79
07/09/2025 23:00	0.7	1.2	1	0.48	0.24222	0.81
Average/Sum#:	0.7	1.3	1	0.44	0.21890	0.73
Minimum:	0.6	0.9	1	0.42	0.20904	0.70
Maximum:	0.8	1.5	1	0.50	0.25020	0.83
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/10/2025 00:00	0.8	1.2	1	0.42	0.21150	0.71
07/10/2025 01:00	0.8	1.3	1	0.42	0.21048	0.70
07/10/2025 02:00	0.8	1.2	1	0.42	0.20994	0.70
07/10/2025 03:00	0.9	1.2	1	0.43	0.21450	0.72
07/10/2025 04:00	0.8	1.3	1	0.44	0.21942	0.73
07/10/2025 05:00	0.8	1.0	1	0.43	0.21516	0.72
07/10/2025 06:00	0.8	1.2	1	0.42	0.20982	0.70
07/10/2025 07:00	0.8	1.3	1	0.42	0.20970	0.70
07/10/2025 08:00	0.7	1.4	1	0.42	0.20910	0.70
07/10/2025 09:00	0.7	1.4	1	0.42	0.20868	0.70
07/10/2025 10:00	0.7	1.4	1	0.42	0.20856	0.70
07/10/2025 11:00	0.7	1.4	1	0.42	0.20922	0.70
07/10/2025 12:00	0.7	1.3	1	0.42	0.20922	0.70
07/10/2025 13:00	0.7	1.3	1	0.42	0.20922	0.70
07/10/2025 14:00	0.7	1.3	1	0.43	0.21738	0.72
07/10/2025 15:00	0.7	1.3	1	0.45	0.22386	0.75
07/10/2025 16:00	0.7	1.2	1	0.42	0.21066	0.70
07/10/2025 17:00	0.7	1.2	1	0.51	0.25290	0.84
07/10/2025 18:00	0.7	1.2	1	0.50	0.25248	0.84
07/10/2025 19:00	0.7	1.2	1	0.50	0.25218	0.84
07/10/2025 20:00	0.7	1.1	1	0.49	0.24558	0.82
07/10/2025 21:00	0.7	1.3	1	0.50	0.25134	0.84
07/10/2025 22:00	0.7	1.2	1	0.50	0.25038	0.83
07/10/2025 23:00	0.7	1.3	1	0.48	0.24204	0.81
Average/Sum#:	0.7	1.3	1	0.45	0.22306	0.74
Minimum:	0.7	1.0	1	0.42	0.20856	0.70
Maximum:	0.9	1.4	1	0.51	0.25290	0.84
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 **To:** 09/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/11/2025 00:00	0.8	1.3	1	0.42	0.20904	0.70
07/11/2025 01:00	0.8	1.4	1	0.42	0.20922	0.70
07/11/2025 02:00	0.8	1.4	1	0.42	0.20958	0.70
07/11/2025 03:00	0.8	1.4	1	0.46	0.22914	0.76
07/11/2025 04:00	0.7	1.2	1	0.49	0.24474	0.82
07/11/2025 05:00	0.8	1.2	1	0.45	0.22698	0.76
07/11/2025 06:00	0.8	1.1	1	0.42	0.21030	0.70
07/11/2025 07:00	0.8	1.2	1	0.42	0.20922	0.70
07/11/2025 08:00	0.8	1.3	1	0.42	0.20898	0.70
07/11/2025 09:00	0.8	1.3	1	0.42	0.20856	0.70
07/11/2025 10:00	0.7	1.3	1	0.46	0.22818	0.76
07/11/2025 11:00	0.7	1.3	1	0.51	0.25380	0.85
07/11/2025 12:00	0.7	1.2	1	0.49	0.24294	0.81
07/11/2025 13:00	0.7	1.2	1	0.51	0.25410	0.85
07/11/2025 14:00	0.7	1.2	1	0.51	0.25350	0.85
07/11/2025 15:00	0.7	1.2	1	0.51	0.25278	0.84
07/11/2025 16:00	0.7	1.3	1	0.48	0.24168	0.81
07/11/2025 17:00	0.8	1.2	1	0.51	0.25392	0.85
07/11/2025 18:00	0.2	1.5	2	0.71	0.35592	1.19
07/11/2025 19:00	0.2	1.4	3	0.75	0.37254	1.24
07/11/2025 20:00	0.3	1.2	2	0.65	0.32574	1.09
07/11/2025 21:00	0.2	1.4	2	0.69	0.34404	1.15
07/11/2025 22:00	0.7	1.2	1	0.59	0.29316	0.98
07/11/2025 23:00	0.6	1.3	1	0.62	0.31212	1.04
Average/Sum#:	0.7	1.3	1	0.51	0.25626	0.86
Minimum:	0.2	1.1	1	0.42	0.20856	0.70
Maximum:	0.8	1.5	3	0.75	0.37254	1.24
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/12/2025 00:00	0.8	1.1	1	0.45	0.22674	0.76
07/12/2025 01:00	0.7	1.1	1	0.42	0.20886	0.70
07/12/2025 02:00	0.7	1.1	1	0.42	0.20904	0.70
07/12/2025 03:00	0.8	1.2	1	0.42	0.20922	0.70
07/12/2025 04:00	0.7	1.1	1	0.42	0.20958	0.70
07/12/2025 05:00	0.7	1.1	1	0.42	0.20940	0.70
07/12/2025 06:00	0.7	1.1	1	0.42	0.20922	0.70
07/12/2025 07:00	0.7	1.0	1	0.42	0.20922	0.70
07/12/2025 08:00	0.7	1.0	1	0.42	0.20892	0.70
07/12/2025 09:00	0.7	1.0	1	0.42	0.20874	0.70
07/12/2025 10:00	0.7	1.1	1	0.42	0.20868	0.70
07/12/2025 11:00	0.7	1.0	1	0.42	0.20910	0.70
07/12/2025 12:00	0.7	1.0	1	0.42	0.20916	0.70
07/12/2025 13:00	0.7	0.9	1	0.42	0.20946	0.70
07/12/2025 14:00	0.7	1.0	1	0.48	0.23928	0.80
07/12/2025 15:00	0.7	1.1	1	0.46	0.23196	0.77
07/12/2025 16:00	0.7	1.1	1	0.45	0.22746	0.76
07/12/2025 17:00	0.7	1.1	1	0.46	0.22752	0.76
07/12/2025 18:00	0.7	1.3	1	0.48	0.23892	0.80
07/12/2025 19:00	0.6	1.2	1	0.51	0.25260	0.84
07/12/2025 20:00	0.7	1.1	1	0.45	0.22566	0.75
07/12/2025 21:00	0.7	1.0	1	0.42	0.21240	0.71
07/12/2025 22:00	0.7	1.0	1	0.43	0.21678	0.72
07/12/2025 23:00	0.6	1.3	1	0.51	0.25554	0.85
Average/Sum#:	0.7	1.1	1	0.44	0.21973	0.73
Minimum:	0.6	0.9	1	0.42	0.20868	0.70
Maximum:	0.8	1.3	1	0.51	0.25554	0.85
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/13/2025 00:00	0.7	1.3	1	0.47	0.23712	0.79
07/13/2025 01:00	0.7	1.3	1	0.48	0.24126	0.80
07/13/2025 02:00	0.7	1.0	1	0.51	0.25566	0.85
07/13/2025 03:00	0.8	1.2	1	0.45	0.22332	0.74
07/13/2025 04:00	0.7	1.1	1	0.43	0.21726	0.72
07/13/2025 05:00	0.7	1.2	1	0.44	0.21840	0.73
07/13/2025 06:00	0.7	1.1	1	0.42	0.20946	0.70
07/13/2025 07:00	0.7	1.1	1	0.42	0.20964	0.70
07/13/2025 08:00	0.7	1.2	1	0.42	0.20934	0.70
07/13/2025 09:00	0.7	1.2	1	0.42	0.20892	0.70
07/13/2025 10:00	0.7	1.2	1	0.42	0.20880	0.70
07/13/2025 11:00	0.7	1.2	1	0.42	0.20934	0.70
07/13/2025 12:00	0.7	1.0	1	0.43	0.21384	0.71
07/13/2025 13:00	0.7	1.2	1	0.50	0.25014	0.83
07/13/2025 14:00	0.7	1.4	1	0.51	0.25494	0.85
07/13/2025 15:00	0.7	1.2	1	0.51	0.25488	0.85
07/13/2025 16:00	0.7	1.3	1	0.51	0.25440	0.85
07/13/2025 17:00	0.7	1.2	1	0.48	0.23964	0.80
07/13/2025 18:00	0.7	1.2	1	0.51	0.25626	0.85
07/13/2025 19:00	0.7	1.3	1	0.51	0.25572	0.85
07/13/2025 20:00	0.7	1.5	1	0.51	0.25566	0.85
07/13/2025 21:00	0.7	1.4	1	0.51	0.25254	0.84
07/13/2025 22:00	0.7	1.1	1	0.48	0.24120	0.80
07/13/2025 23:00	0.6	1.3	1	0.50	0.25074	0.84
Average/Sum#:	0.7	1.2	1	0.47	0.23452	0.78
Minimum:	0.6	1.0	1	0.42	0.20880	0.70
Maximum:	0.8	1.5	1	0.51	0.25626	0.85
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/14/2025 00:00	0.7	1.2	1	0.49	0.24318	0.81
07/14/2025 01:00	0.7	1.1	1	0.43	0.21258	0.71
07/14/2025 02:00	0.7	1.1	1	0.42	0.21024	0.70
07/14/2025 03:00	0.8	1.1	1	0.42	0.21150	0.71
07/14/2025 04:00	0.7	1.2	1	0.47	0.23538	0.78
07/14/2025 05:00	0.7	1.2	1	0.47	0.23676	0.79
07/14/2025 06:00	0.7	1.2	1	0.45	0.22260	0.74
07/14/2025 07:00	0.7	1.2	2	0.42	0.20940	0.70
07/14/2025 08:00	0.7	1.1	1	0.42	0.20898	0.70
07/14/2025 09:00	0.7	1.2	1	0.42	0.20868	0.70
07/14/2025 10:00	0.7	1.1	1	0.42	0.20838	0.69
07/14/2025 11:00	0.7	1.0	1	0.42	0.20892	0.70
07/14/2025 12:00	0.7	1.0	1	0.42	0.20898	0.70
07/14/2025 13:00	0.7	1.0	1	0.42	0.20910	0.70
07/14/2025 14:00	0.7	0.9	1	0.43	0.21582	0.72
07/14/2025 15:00	0.7	1.0	1	0.42	0.21096	0.70
07/14/2025 16:00	0.7	0.9	1	0.42	0.21114	0.70
07/14/2025 17:00	0.7	0.9	1	0.43	0.21660	0.72
07/14/2025 18:00	0.7	1.0	1	0.43	0.21510	0.72
07/14/2025 19:00	0.7	1.1	1	0.42	0.20814	0.69
07/14/2025 20:00	0.7	1.1	1	0.42	0.20808	0.69
07/14/2025 21:00	0.7	1.2	1	0.42	0.20844	0.69
07/14/2025 22:00	0.7	1.1	1	0.42	0.20910	0.70
07/14/2025 23:00	0.7	1.1	1	0.42	0.20982	0.70
Average/Sum#:	0.7	1.1	1	0.43	0.21450	0.72
Minimum:	0.7	0.9	1	0.42	0.20808	0.69
Maximum:	0.8	1.2	2	0.49	0.24318	0.81
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/15/2025 00:00	0.7	1.1	1	0.42	0.21024	0.70
07/15/2025 01:00	0.7	1.1	1	0.42	0.21054	0.70
07/15/2025 02:00	0.7	1.1	1	0.42	0.21054	0.70
07/15/2025 03:00	0.8	1.1	1	0.42	0.21084	0.70
07/15/2025 04:00	0.7	1.1	1	0.42	0.21096	0.70
07/15/2025 05:00	0.7	1.2	1	0.42	0.21090	0.70
07/15/2025 06:00	0.7	1.2	1	0.42	0.21066	0.70
07/15/2025 07:00	0.7	1.1	1	0.42	0.21060	0.70
07/15/2025 08:00	0.7	1.1	1	0.42	0.20970	0.70
07/15/2025 09:00	0.7	1.1	1	0.42	0.20904	0.70
07/15/2025 10:00	0.7	1.2	1	0.42	0.20874	0.70
07/15/2025 11:00	0.7	1.1	1	0.42	0.20922	0.70
07/15/2025 12:00	0.6	1.1	1	0.42	0.20904	0.70
07/15/2025 13:00	0.6	1.1	1	0.42	0.20910	0.70
07/15/2025 14:00	0.6	1.1	1	0.42	0.20892	0.70
07/15/2025 15:00	0.6	1.1	1	0.42	0.20844	0.69
07/15/2025 16:00	0.6	1.1	1	0.42	0.20832	0.69
07/15/2025 17:00	0.6	1.2	1	0.44	0.22224	0.74
07/15/2025 18:00	0.7	1.2	1	0.42	0.21024	0.70
07/15/2025 19:00	0.7	1.2	2	0.42	0.20802	0.69
07/15/2025 20:00	0.7	1.2	1	0.42	0.20856	0.70
07/15/2025 21:00	0.7	1.0	1	0.42	0.21204	0.71
07/15/2025 22:00	0.7	1.1	1	0.42	0.20892	0.70
07/15/2025 23:00	0.7	1.1	1	0.42	0.20922	0.70
Average/Sum#:	0.7	1.1	1	0.42	0.21021	0.70
Minimum:	0.6	1.0	1	0.42	0.20802	0.69
Maximum:	0.8	1.2	2	0.44	0.22224	0.74
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/16/2025 00:00	0.7	1.2	1	0.42	0.20940	0.70
07/16/2025 01:00	0.7	1.1	1	0.42	0.20964	0.70
07/16/2025 02:00	0.7	1.2	1	0.42	0.20982	0.70
07/16/2025 03:00	0.8	1.3	1	0.42	0.21000	0.70
07/16/2025 04:00	0.7	1.2	1	0.43	0.21498	0.72
07/16/2025 05:00	0.6	1.2	1	0.50	0.24792	0.83
07/16/2025 06:00	0.8	1.2	1	0.42	0.21006	0.70
07/16/2025 07:00	0.8	1.3	1	0.42	0.21030	0.70
07/16/2025 08:00	0.8	1.3	1	0.42	0.20988	0.70
07/16/2025 09:00	0.7	1.2	2	0.42	0.20952	0.70
07/16/2025 10:00	0.7	1.1	1	0.42	0.20928	0.70
07/16/2025 11:00	0.6	1.0	1	0.44	0.21906	0.73
07/16/2025 12:00	0.6	1.1	1	0.44	0.22056	0.74
07/16/2025 13:00	0.6	1.2	1	0.48	0.23790	0.79
07/16/2025 14:00	0.7	1.3	1	0.45	0.22296	0.74
07/16/2025 15:00	0.6	1.2	1	0.44	0.22074	0.74
07/16/2025 16:00	0.6	1.1	1	0.42	0.20886	0.70
07/16/2025 17:00	0.6	1.1	1	0.42	0.21126	0.70
07/16/2025 18:00	0.6	1.1	1	0.42	0.20892	0.70
07/16/2025 19:00	0.6	1.2	1	0.42	0.20862	0.70
07/16/2025 20:00	0.7	1.2	1	0.42	0.20886	0.70
07/16/2025 21:00	0.7	1.2	1	0.42	0.20910	0.70
07/16/2025 22:00	0.7	1.2	1	0.42	0.20916	0.70
07/16/2025 23:00	0.7	1.2	1	0.42	0.20910	0.70
Average/Sum#:	0.7	1.2	1	0.43	0.21441	0.72
Minimum:	0.6	1.0	1	0.42	0.20862	0.70
Maximum:	0.8	1.3	2	0.50	0.24792	0.83
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/17/2025 00:00	0.7	1.2	1	0.42	0.20916	0.70
07/17/2025 01:00	0.7	1.2	1	0.42	0.21084	0.70
07/17/2025 02:00	0.7	1.2	1	0.42	0.20946	0.70
07/17/2025 03:00	0.8	1.2	1	0.42	0.20976	0.70
07/17/2025 04:00	0.7	1.3	1	0.42	0.20988	0.70
07/17/2025 05:00	0.7	1.4	1	0.42	0.20976	0.70
07/17/2025 06:00	0.8	1.3	1	0.42	0.20964	0.70
07/17/2025 07:00	0.7	1.3	1	0.42	0.20958	0.70
07/17/2025 08:00	0.7	1.3	1	0.42	0.20958	0.70
07/17/2025 09:00	0.7	1.3	1	0.42	0.21006	0.70
07/17/2025 10:00	0.7	1.2	1	0.42	0.20928	0.70
07/17/2025 11:00	0.7	1.1	1	0.42	0.20904	0.70
07/17/2025 12:00	0.6	1.1	1	0.44	0.21774	0.73
07/17/2025 13:00	0.7	1.2	1	0.48	0.23928	0.80
07/17/2025 14:00	0.6	1.2	1	0.50	0.25032	0.83
07/17/2025 15:00	0.6	1.1	1	0.51	0.25554	0.85
07/17/2025 16:00	0.6	1.1	1	0.42	0.20856	0.70
07/17/2025 17:00	0.6	1.2	1	0.44	0.22182	0.74
07/17/2025 18:00	0.6	1.1	1	0.42	0.20856	0.70
07/17/2025 19:00	0.6	1.4	1	0.42	0.20778	0.69
07/17/2025 20:00	0.7	1.3	2	0.42	0.20832	0.69
07/17/2025 21:00	0.7	1.3	1	0.42	0.20862	0.70
07/17/2025 22:00	0.7	1.2	1	0.42	0.21090	0.70
07/17/2025 23:00	0.7	1.2	1	0.47	0.23568	0.79
Average/Sum#:	0.7	1.2	1	0.43	0.21622	0.72
Minimum:	0.6	1.1	1	0.42	0.20778	0.69
Maximum:	0.8	1.4	2	0.51	0.25554	0.85
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/18/2025 00:00	0.7	1.1	1	0.42	0.21108	0.70
07/18/2025 01:00	0.7	1.1	1	0.42	0.20946	0.70
07/18/2025 02:00	0.7	1.1	1	0.42	0.20964	0.70
07/18/2025 03:00	0.8	1.2	1	0.42	0.20982	0.70
07/18/2025 04:00	0.7	1.2	1	0.43	0.21510	0.72
07/18/2025 05:00	0.7	1.2	1	0.44	0.22230	0.74
07/18/2025 06:00	0.7	1.2	1	0.43	0.21276	0.71
07/18/2025 07:00	0.7	1.2	1	0.42	0.21150	0.71
07/18/2025 08:00	0.7	1.2	1	0.42	0.21126	0.70
07/18/2025 09:00	0.7	1.2	2	0.42	0.21066	0.70
07/18/2025 10:00	0.7	1.1	2	0.42	0.21012	0.70
07/18/2025 11:00	0.7	1.0	1	0.42	0.20976	0.70
07/18/2025 12:00	0.6	1.1	1	0.42	0.20916	0.70
07/18/2025 13:00	0.6	1.1	1	0.42	0.20886	0.70
07/18/2025 14:00	0.6	1.1	1	0.42	0.20850	0.70
07/18/2025 15:00	0.6	1.0	1	0.42	0.20814	0.69
07/18/2025 16:00	0.6	1.1	1	0.42	0.20802	0.69
07/18/2025 17:00	0.6	1.1	1	0.43	0.21306	0.71
07/18/2025 18:00	0.7	1.2	2	0.42	0.20886	0.70
07/18/2025 19:00	0.6	1.1	2	0.42	0.20772	0.69
07/18/2025 20:00	0.7	1.1	1	0.42	0.20802	0.69
07/18/2025 21:00	0.7	1.2	1	0.42	0.20844	0.69
07/18/2025 22:00	0.7	1.2	1	0.42	0.21096	0.70
07/18/2025 23:00	0.7	1.2	2	0.48	0.24198	0.81
Average/Sum#:	0.7	1.1	1	0.42	0.21188	0.71
Minimum:	0.6	1.0	1	0.42	0.20772	0.69
Maximum:	0.8	1.2	2	0.48	0.24198	0.81
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/19/2025 00:00	0.7	1.1	1	0.42	0.20964	0.70
07/19/2025 01:00	0.7	1.2	1	0.42	0.20970	0.70
07/19/2025 02:00	0.7	1.2	1	0.42	0.20958	0.70
07/19/2025 03:00	0.8	1.2	2	0.42	0.20976	0.70
07/19/2025 04:00	0.7	1.2	1	0.42	0.21000	0.70
07/19/2025 05:00	0.7	1.2	3	0.42	0.21012	0.70
07/19/2025 06:00	0.7	1.1	2	0.42	0.21018	0.70
07/19/2025 07:00	0.7	1.1	2	0.42	0.21018	0.70
07/19/2025 08:00	0.7	1.2	1	0.42	0.20970	0.70
07/19/2025 09:00	0.7	1.3	1	0.42	0.20928	0.70
07/19/2025 10:00	0.7	1.2	1	0.42	0.20874	0.70
07/19/2025 11:00	0.7	1.2	1	0.42	0.20922	0.70
07/19/2025 12:00	0.6	1.2	1	0.42	0.20910	0.70
07/19/2025 13:00	0.6	1.2	1	0.42	0.20886	0.70
07/19/2025 14:00	0.6	1.2	1	0.42	0.20862	0.70
07/19/2025 15:00	0.7	1.1	1	0.42	0.20844	0.69
07/19/2025 16:00	0.6	1.2	1	0.42	0.20880	0.70
07/19/2025 17:00	0.6	1.2	1	0.43	0.21276	0.71
07/19/2025 18:00	0.6	1.3	1	0.42	0.20850	0.70
07/19/2025 19:00	0.7	1.2	1	0.42	0.20766	0.69
07/19/2025 20:00	0.7	1.2	1	0.42	0.20826	0.69
07/19/2025 21:00	0.7	1.2	1	0.42	0.20826	0.69
07/19/2025 22:00	0.7	1.2	1	0.42	0.20844	0.69
07/19/2025 23:00	0.7	1.3	1	0.42	0.20856	0.70
Average/Sum#:	0.7	1.2	1	0.42	0.20927	0.70
Minimum:	0.6	1.1	1	0.42	0.20766	0.69
Maximum:	0.8	1.3	3	0.43	0.21276	0.71
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/20/2025 00:00	0.7	1.2	1	0.42	0.20880	0.70
07/20/2025 01:00	0.7	1.3	1	0.42	0.20892	0.70
07/20/2025 02:00	0.7	1.2	1	0.42	0.20904	0.70
07/20/2025 03:00	0.8	1.3	1	0.42	0.20928	0.70
07/20/2025 04:00	0.7	1.3	2	0.42	0.20958	0.70
07/20/2025 05:00	0.7	1.3	1	0.42	0.20964	0.70
07/20/2025 06:00	0.7	1.2	2	0.42	0.20970	0.70
07/20/2025 07:00	0.7	1.3	1	0.42	0.20976	0.70
07/20/2025 08:00	0.7	1.3	1	0.42	0.20952	0.70
07/20/2025 09:00	0.7	1.3	1	0.42	0.20910	0.70
07/20/2025 10:00	0.7	1.2	2	0.42	0.20856	0.70
07/20/2025 11:00	0.7	1.1	1	0.42	0.20868	0.70
07/20/2025 12:00	0.6	1.2	1	0.42	0.20850	0.70
07/20/2025 13:00	0.6	1.1	1	0.42	0.20844	0.69
07/20/2025 14:00	0.6	1.1	1	0.42	0.20820	0.69
07/20/2025 15:00	0.7	1.1	1	0.42	0.20796	0.69
07/20/2025 16:00	0.6	1.1	1	0.42	0.20808	0.69
07/20/2025 17:00	0.6	1.1	1	0.42	0.21012	0.70
07/20/2025 18:00	0.7	1.1	1	0.42	0.20832	0.69
07/20/2025 19:00	0.7	1.2	1	0.42	0.20814	0.69
07/20/2025 20:00	0.7	1.2	1	0.42	0.20862	0.70
07/20/2025 21:00	0.7	1.2	1	0.42	0.20886	0.70
07/20/2025 22:00	0.7	1.3	1	0.42	0.20904	0.70
07/20/2025 23:00	0.7	1.2	1	0.42	0.20934	0.70
Average/Sum#:	0.7	1.2	1	0.42	0.20893	0.70
Minimum:	0.6	1.1	1	0.42	0.20796	0.69
Maximum:	0.8	1.3	2	0.42	0.21012	0.70
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/21/2025 00:00	0.7	1.3	1	0.42	0.20916	0.70
07/21/2025 01:00	0.7	1.3	1	0.42	0.20916	0.70
07/21/2025 02:00	0.7	1.3	1	0.42	0.20922	0.70
07/21/2025 03:00	0.8	1.3	1	0.42	0.20934	0.70
07/21/2025 04:00	0.7	1.3	1	0.45	0.22392	0.75
07/21/2025 05:00	0.7	1.2	1	0.45	0.22302	0.74
07/21/2025 06:00	0.7	1.3	1	0.42	0.20982	0.70
07/21/2025 07:00	0.7	1.3	1	0.42	0.20994	0.70
07/21/2025 08:00	0.7	1.3	1	0.42	0.20958	0.70
07/21/2025 09:00	0.7	1.4	1	0.42	0.20922	0.70
07/21/2025 10:00	0.7	1.4	1	0.42	0.20892	0.70
07/21/2025 11:00	0.6	1.2	1	0.42	0.20910	0.70
07/21/2025 12:00	0.6	1.2	1	0.42	0.20892	0.70
07/21/2025 13:00	0.6	1.1	1	0.42	0.20892	0.70
07/21/2025 14:00	0.6	1.2	2	0.42	0.20862	0.70
07/21/2025 15:00	0.6	1.2	2	0.42	0.20826	0.69
07/21/2025 16:00	0.6	1.2	2	0.42	0.20814	0.69
07/21/2025 17:00	0.7	1.1	2	0.42	0.20814	0.69
07/21/2025 18:00	0.7	1.2	2	0.42	0.20838	0.69
07/21/2025 19:00	0.7	1.2	2	0.42	0.20862	0.70
07/21/2025 20:00	0.7	1.1	2	0.42	0.20892	0.70
07/21/2025 21:00	0.7	1.3	2	0.42	0.20910	0.70
07/21/2025 22:00	0.7	1.2	2	0.42	0.20934	0.70
07/21/2025 23:00	0.7	1.2	2	0.42	0.20946	0.70
Average/Sum#:	0.7	1.2	1	0.42	0.21022	0.70
Minimum:	0.6	1.1	1	0.42	0.20814	0.69
Maximum:	0.8	1.4	2	0.45	0.22392	0.75
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/22/2025 00:00	0.7	1.2	2	0.42	0.20982	0.70
07/22/2025 01:00	0.7	1.2	2	0.42	0.21006	0.70
07/22/2025 02:00	0.7	1.4	2	0.42	0.21012	0.70
07/22/2025 03:00	0.8	1.4	2	0.42	0.20988	0.70
07/22/2025 04:00	0.7	1.1	2	0.42	0.20964	0.70
07/22/2025 05:00	0.7	1.2	2	0.42	0.20964	0.70
07/22/2025 06:00	0.7	1.1	2	0.42	0.20964	0.70
07/22/2025 07:00	0.7	1.3	2	0.42	0.20952	0.70
07/22/2025 08:00	0.7	1.2	2	0.42	0.20958	0.70
07/22/2025 09:00	0.7	1.2	2	0.42	0.20934	0.70
07/22/2025 10:00	0.7	1.2	2	0.42	0.20916	0.70
07/22/2025 11:00	0.7	1.2	2	0.42	0.20964	0.70
07/22/2025 12:00	0.7	1.2	2	0.42	0.20964	0.70
07/22/2025 13:00	0.6	1.2	2	0.42	0.20940	0.70
07/22/2025 14:00	0.6	1.1	2	0.42	0.20904	0.70
07/22/2025 15:00	0.6	1.2	2	0.42	0.20868	0.70
07/22/2025 16:00	0.6	1.2	2	0.42	0.20868	0.70
07/22/2025 17:00	0.6	1.2	2	0.42	0.20886	0.70
07/22/2025 18:00	0.6	1.2	2	0.42	0.20922	0.70
07/22/2025 19:00	0.6	1.2	2	0.42	0.20916	0.70
07/22/2025 20:00	0.6	1.1	2	0.42	0.20952	0.70
07/22/2025 21:00	0.7	1.1	2	0.42	0.20994	0.70
07/22/2025 22:00	0.7	1.2	2	0.42	0.21108	0.70
07/22/2025 23:00	0.7	1.1	3	0.42	0.21108	0.70
Average/Sum#:	0.7	1.2	2	0.42	0.20960	0.70
Minimum:	0.6	1.1	2	0.42	0.20868	0.70
Maximum:	0.8	1.4	3	0.42	0.21108	0.70
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/23/2025 00:00	0.7	1.1	2	0.42	0.21012	0.70
07/23/2025 01:00	0.7	1.2	2	0.42	0.21060	0.70
07/23/2025 02:00	0.7	1.3	1	0.42	0.21066	0.70
07/23/2025 03:00	0.8	1.4	1	0.42	0.21066	0.70
07/23/2025 04:00	0.7	1.4	1	0.42	0.21078	0.70
07/23/2025 05:00	0.7	1.4	2	0.42	0.21054	0.70
07/23/2025 06:00	0.7	1.2	2	0.42	0.21048	0.70
07/23/2025 07:00	0.7	1.2	2	0.42	0.21186	0.71
07/23/2025 08:00	0.7	1.1	2	0.42	0.21006	0.70
07/23/2025 09:00	0.7	1.1	2	0.42	0.20982	0.70
07/23/2025 10:00	0.7	1.0	2	0.42	0.20934	0.70
07/23/2025 11:00	0.6	1.2	2	0.42	0.20946	0.70
07/23/2025 12:00	0.7	1.1	2	0.42	0.20964	0.70
07/23/2025 13:00	0.7	1.1	1	0.44	0.21834	0.73
07/23/2025 14:00	0.7	1.2	1	0.42	0.20946	0.70
07/23/2025 15:00	0.7	1.2	1	0.42	0.20898	0.70
07/23/2025 16:00	0.7	1.2	1	0.42	0.20898	0.70
07/23/2025 17:00	0.6	1.2	1	0.43	0.21468	0.72
07/23/2025 18:00	0.7	1.1	2	0.48	0.23784	0.79
07/23/2025 19:00	0.7	1.3	1	0.50	0.24984	0.83
07/23/2025 20:00	0.7	1.1	2	0.45	0.22650	0.76
07/23/2025 21:00	0.7	1.2	1	0.51	0.25440	0.85
07/23/2025 22:00	0.7	1.2	1	0.51	0.25488	0.85
07/23/2025 23:00	0.7	1.0	2	0.48	0.23934	0.80
Average/Sum#:	0.7	1.2	2	0.44	0.21905	0.73
Minimum:	0.6	1.0	1	0.42	0.20898	0.70
Maximum:	0.8	1.4	2	0.51	0.25488	0.85
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/24/2025 00:00	0.7	1.1	1	0.42	0.21144	0.70
07/24/2025 01:00	0.7	1.2	1	0.42	0.21048	0.70
07/24/2025 02:00	0.8	1.3	1	0.42	0.21078	0.70
07/24/2025 03:00	0.9	1.4	2	0.42	0.21090	0.70
07/24/2025 04:00	0.8	1.4	1	0.43	0.21360	0.71
07/24/2025 05:00	0.7	1.2	2	0.45	0.22656	0.76
07/24/2025 06:00	0.8	1.4	1	0.42	0.21078	0.70
07/24/2025 07:00	0.8	1.4	1	0.42	0.21084	0.70
07/24/2025 08:00	0.7	1.2	2	0.42	0.21054	0.70
07/24/2025 09:00	0.7	1.3	2	0.42	0.21012	0.70
07/24/2025 10:00	0.7	1.3	2	0.42	0.20982	0.70
07/24/2025 11:00	0.7	1.3	2	0.42	0.20976	0.70
07/24/2025 12:00	0.7	1.2	2	0.42	0.20958	0.70
07/24/2025 13:00	0.7	1.2	2	0.42	0.20952	0.70
07/24/2025 14:00	0.7	1.2	2	0.42	0.20940	0.70
07/24/2025 15:00	0.7	1.2	2	0.42	0.20898	0.70
07/24/2025 16:00	0.6	1.2	2	0.42	0.20874	0.70
07/24/2025 17:00	0.6	1.1	2	0.44	0.21780	0.73
07/24/2025 18:00	0.7	1.0	1	0.42	0.20982	0.70
07/24/2025 19:00	0.7	1.2	1	0.42	0.20862	0.70
07/24/2025 20:00	0.7	1.2	1	0.42	0.20898	0.70
07/24/2025 21:00	0.7	1.3	2	0.42	0.20922	0.70
07/24/2025 22:00	0.7	1.2	2	0.42	0.20934	0.70
07/24/2025 23:00	0.7	1.2	2	0.42	0.20952	0.70
Average/Sum#:	0.7	1.2	2	0.42	0.21105	0.70
Minimum:	0.6	1.0	1	0.42	0.20862	0.70
Maximum:	0.9	1.4	2	0.45	0.22656	0.76
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/25/2025 00:00	0.7	1.2	2	0.42	0.20976	0.70
07/25/2025 01:00	0.7	1.2	2	0.42	0.21000	0.70
07/25/2025 02:00	0.7	1.0	2	0.42	0.21006	0.70
07/25/2025 03:00	0.8	1.4	2	0.42	0.21030	0.70
07/25/2025 04:00	0.7	1.1	3	0.42	0.21054	0.70
07/25/2025 05:00	0.8	1.1	2	0.42	0.21066	0.70
07/25/2025 06:00	0.8	1.3	2	0.42	0.21060	0.70
07/25/2025 07:00	0.8	1.3	2	0.42	0.21048	0.70
07/25/2025 08:00	0.7	1.1	2	0.42	0.21024	0.70
07/25/2025 09:00	0.7	1.3	1	0.42	0.21000	0.70
07/25/2025 10:00	0.7	1.3	1	0.42	0.20964	0.70
07/25/2025 11:00	0.7	1.2	1	0.42	0.20976	0.70
07/25/2025 12:00	0.6	1.2	1	0.42	0.20970	0.70
07/25/2025 13:00	0.6	1.1	1	0.42	0.20952	0.70
07/25/2025 14:00	0.6	1.2	1	0.42	0.20928	0.70
07/25/2025 15:00	0.6	1.2	1	0.42	0.20904	0.70
07/25/2025 16:00	0.7	1.2	1	0.42	0.20904	0.70
07/25/2025 17:00	0.7	1.2	1	0.42	0.20916	0.70
07/25/2025 18:00	0.7	1.2	1	0.42	0.20916	0.70
07/25/2025 19:00	0.7	1.3	1	0.42	0.20904	0.70
07/25/2025 20:00	0.7	1.3	1	0.42	0.21066	0.70
07/25/2025 21:00	0.7	1.1	1	0.42	0.20964	0.70
07/25/2025 22:00	0.7	1.3	1	0.42	0.20994	0.70
07/25/2025 23:00	0.7	1.3	1	0.42	0.21000	0.70
Average/Sum#:	0.7	1.2	1	0.42	0.20984	0.70
Minimum:	0.6	1.0	1	0.42	0.20904	0.70
Maximum:	0.8	1.4	3	0.42	0.21066	0.70
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/26/2025 00:00	0.7	1.3	1	0.42	0.21006	0.70
07/26/2025 01:00	0.7	1.4	1	0.42	0.21024	0.70
07/26/2025 02:00	0.7	1.0	1	0.42	0.21048	0.70
07/26/2025 03:00	0.8	1.3	1	0.42	0.21048	0.70
07/26/2025 04:00	0.8	1.5	1	0.42	0.21066	0.70
07/26/2025 05:00	0.7	1.2	1	0.42	0.21066	0.70
07/26/2025 06:00	0.7	1.4	1	0.42	0.21054	0.70
07/26/2025 07:00	0.7	1.4	1	0.42	0.21036	0.70
07/26/2025 08:00	0.7	1.4	1	0.42	0.21006	0.70
07/26/2025 09:00	0.7	1.4	1	0.42	0.20970	0.70
07/26/2025 10:00	0.7	1.4	1	0.42	0.20922	0.70
07/26/2025 11:00	0.7	1.4	1	0.42	0.20910	0.70
07/26/2025 12:00	0.7	1.3	1	0.42	0.20874	0.70
07/26/2025 13:00	0.7	1.2	1	0.42	0.20928	0.70
07/26/2025 14:00	0.7	1.2	1	0.42	0.20946	0.70
07/26/2025 15:00	0.7	1.1	1	0.42	0.20910	0.70
07/26/2025 16:00	0.7	1.2	1	0.42	0.20910	0.70
07/26/2025 17:00	0.7	1.2	1	0.43	0.21714	0.72
07/26/2025 18:00	0.7	1.1	2	0.42	0.20934	0.70
07/26/2025 19:00	0.7	1.2	1	0.42	0.20916	0.70
07/26/2025 20:00	0.7	1.3	1	0.42	0.20940	0.70
07/26/2025 21:00	0.7	1.3	1	0.42	0.20928	0.70
07/26/2025 22:00	0.7	1.3	1	0.42	0.20934	0.70
07/26/2025 23:00	0.7	1.3	1	0.42	0.20964	0.70
Average/Sum#:	0.7	1.3	1	0.42	0.21002	0.70
Minimum:	0.7	1.0	1	0.42	0.20874	0.70
Maximum:	0.8	1.5	2	0.43	0.21714	0.72
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/27/2025 00:00	0.7	1.4	1	0.42	0.20982	0.70
07/27/2025 01:00	0.7	1.4	1	0.42	0.20994	0.70
07/27/2025 02:00	0.7	1.4	1	0.42	0.21030	0.70
07/27/2025 03:00	0.8	1.4	2	0.42	0.21030	0.70
07/27/2025 04:00	0.8	1.2	2	0.42	0.21048	0.70
07/27/2025 05:00	0.8	1.3	2	0.42	0.21060	0.70
07/27/2025 06:00	0.8	1.3	2	0.42	0.21042	0.70
07/27/2025 07:00	0.7	1.4	1	0.42	0.21042	0.70
07/27/2025 08:00	0.7	1.4	2	0.42	0.21036	0.70
07/27/2025 09:00	0.7	1.2	2	0.42	0.21018	0.70
07/27/2025 10:00	0.7	1.2	2	0.42	0.20988	0.70
07/27/2025 11:00	0.7	1.3	2	0.42	0.21006	0.70
07/27/2025 12:00	0.7	1.1	2	0.42	0.20988	0.70
07/27/2025 13:00	0.7	1.1	2	0.42	0.20970	0.70
07/27/2025 14:00	0.7	1.2	2	0.42	0.20946	0.70
07/27/2025 15:00	0.7	1.2	2	0.42	0.20916	0.70
07/27/2025 16:00	0.7	1.1	2	0.42	0.20916	0.70
07/27/2025 17:00	0.7	1.1	2	0.43	0.21720	0.72
07/27/2025 18:00	0.7	1.1	1	0.42	0.21066	0.70
07/27/2025 19:00	0.7	1.1	1	0.42	0.21102	0.70
07/27/2025 20:00	0.7	1.2	1	0.42	0.20928	0.70
07/27/2025 21:00	0.7	1.2	1	0.42	0.20934	0.70
07/27/2025 22:00	0.7	1.3	1	0.42	0.20952	0.70
07/27/2025 23:00	0.7	1.3	1	0.42	0.20970	0.70
Average/Sum#:	0.7	1.2	2	0.42	0.21029	0.70
Minimum:	0.7	1.1	1	0.42	0.20916	0.70
Maximum:	0.8	1.4	2	0.43	0.21720	0.72
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/28/2025 00:00	0.7	1.3	1	0.42	0.20970	0.70
07/28/2025 01:00	0.7	1.3	1	0.42	0.20982	0.70
07/28/2025 02:00	0.7	1.3	1	0.42	0.20982	0.70
07/28/2025 03:00	0.8	1.3	1	0.42	0.21006	0.70
07/28/2025 04:00	0.7	1.3	1	0.42	0.21018	0.70
07/28/2025 05:00	0.8	1.3	1	0.42	0.21018	0.70
07/28/2025 06:00	0.7	1.3	1	0.42	0.21018	0.70
07/28/2025 07:00	0.7	1.2	1	0.42	0.21048	0.70
07/28/2025 08:00	0.7	1.2	1	0.42	0.21012	0.70
07/28/2025 09:00	0.7	1.2	1	0.42	0.21012	0.70
07/28/2025 10:00	0.7	1.3	1	0.43	0.21420	0.71
07/28/2025 11:00	0.7	1.2	1	0.42	0.21012	0.70
07/28/2025 12:00	0.7	1.3	1	0.51	0.25650	0.86
07/28/2025 13:00	0.7	1.3	1	0.52	0.25758	0.86
07/28/2025 14:00	0.7	1.2	1	0.52	0.25752	0.86
07/28/2025 15:00	0.7	1.0	1	0.45	0.22680	0.76
07/28/2025 16:00	0.7	1.1	1	0.45	0.22266	0.74
07/28/2025 17:00	0.7	1.2	1	0.49	0.24378	0.81
07/28/2025 18:00	0.6	1.3	1	0.51	0.25626	0.85
07/28/2025 19:00	0.7	1.1	2	0.44	0.21876	0.73
07/28/2025 20:00	0.7	1.2	2	0.42	0.20886	0.70
07/28/2025 21:00	0.7	1.1	1	0.42	0.21192	0.71
07/28/2025 22:00	0.7	1.2	1	0.42	0.21084	0.70
07/28/2025 23:00	0.7	1.2	2	0.51	0.25290	0.84
Average/Sum#:	0.7	1.2	1	0.45	0.22289	0.74
Minimum:	0.6	1.0	1	0.42	0.20886	0.70
Maximum:	0.8	1.3	2	0.52	0.25758	0.86
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/29/2025 00:00	0.7	1.2	1	0.44	0.22224	0.74
07/29/2025 01:00	0.7	1.2	1	0.43	0.21744	0.72
07/29/2025 02:00	0.7	1.4	1	0.47	0.23292	0.78
07/29/2025 03:00	0.8	1.3	1	0.43	0.21702	0.72
07/29/2025 04:00	0.7	1.2	2	0.48	0.23874	0.80
07/29/2025 05:00	0.7	1.1	2	0.47	0.23706	0.79
07/29/2025 06:00	0.7	1.1	2	0.42	0.21180	0.71
07/29/2025 07:00	0.7	1.2	1	0.43	0.21606	0.72
07/29/2025 08:00	0.7	1.1	2	0.42	0.21024	0.70
07/29/2025 09:00	0.7	1.3	1	0.48	0.23922	0.80
07/29/2025 10:00	0.6	1.2	1	0.51	0.25512	0.85
07/29/2025 11:00	0.6	1.3	1	0.51	0.25404	0.85
07/29/2025 12:00	0.6	1.2	1	0.51	0.25704	0.86
07/29/2025 13:00	0.7	1.2	1	0.52	0.25752	0.86
07/29/2025 14:00	0.7	1.2	1	0.51	0.25632	0.85
07/29/2025 15:00	0.7	1.1	1	0.45	0.22278	0.74
07/29/2025 16:00	0.7	1.2	1	0.43	0.21444	0.71
07/29/2025 17:00	0.7	1.3	1	0.45	0.22284	0.74
07/29/2025 18:00	0.6	1.2	1	0.50	0.24996	0.83
07/29/2025 19:00	0.7	1.0	2	0.42	0.21072	0.70
07/29/2025 20:00	0.7	1.2	2	0.42	0.20928	0.70
07/29/2025 21:00	0.7	1.1	2	0.45	0.22458	0.75
07/29/2025 22:00	0.7	1.2	1	0.42	0.20976	0.70
07/29/2025 23:00	0.7	1.2	1	0.46	0.23076	0.77
Average/Sum#:	0.7	1.2	1	0.46	0.22991	0.77
Minimum:	0.6	1.0	1	0.42	0.20928	0.70
Maximum:	0.8	1.4	2	0.52	0.25752	0.86
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/30/2025 00:00	0.7	1.2	1	0.42	0.20994	0.70
07/30/2025 01:00	0.7	1.3	1	0.42	0.21024	0.70
07/30/2025 02:00	0.7	1.3	2	0.42	0.21036	0.70
07/30/2025 03:00	0.8	1.0	2	0.42	0.21042	0.70
07/30/2025 04:00	0.7	1.1	2	0.44	0.22206	0.74
07/30/2025 05:00	0.7	1.2	1	0.44	0.22134	0.74
07/30/2025 06:00	0.8	1.2	2	0.42	0.21048	0.70
07/30/2025 07:00	0.8	1.2	3	0.42	0.21072	0.70
07/30/2025 08:00	0.8	1.2	2	0.42	0.21012	0.70
07/30/2025 09:00	0.8	1.2	2	0.42	0.20964	0.70
07/30/2025 10:00	0.7	1.2	2	0.42	0.20922	0.70
07/30/2025 11:00	0.7	1.2	2	0.42	0.20958	0.70
07/30/2025 12:00	0.6	1.2	2	0.42	0.20964	0.70
07/30/2025 13:00	0.6	1.0	2	0.42	0.20952	0.70
07/30/2025 14:00	0.6	1.1	1	0.42	0.20928	0.70
07/30/2025 15:00	0.6	1.1	1	0.42	0.20880	0.70
07/30/2025 16:00	0.6	1.2	1	0.42	0.20970	0.70
07/30/2025 17:00	0.6	1.2	1	0.43	0.21702	0.72
07/30/2025 18:00	0.6	1.3	1	0.43	0.21300	0.71
07/30/2025 19:00	0.7	1.1	1	0.42	0.21120	0.70
07/30/2025 20:00	0.7	1.3	1	0.42	0.20922	0.70
07/30/2025 21:00	0.7	1.3	1	0.42	0.20952	0.70
07/30/2025 22:00	0.7	1.3	1	0.42	0.20982	0.70
07/30/2025 23:00	0.7	1.3	1	0.42	0.20994	0.70
Average/Sum#:	0.7	1.2	2	0.42	0.21128	0.70
Minimum:	0.6	1.0	1	0.42	0.20880	0.70
Maximum:	0.8	1.3	3	0.44	0.22206	0.74
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 **To:** 09/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/31/2025 00:00	0.7	1.3	1	0.42	0.21000	0.70
07/31/2025 01:00	0.7	1.3	1	0.42	0.21018	0.70
07/31/2025 02:00	0.7	1.3	1	0.42	0.21024	0.70
07/31/2025 03:00	0.8	1.3	1	0.42	0.21036	0.70
07/31/2025 04:00	0.7	1.3	1	0.42	0.21054	0.70
07/31/2025 05:00	0.7	1.3	1	0.42	0.21048	0.70
07/31/2025 06:00	0.7	1.3	1	0.42	0.21036	0.70
07/31/2025 07:00	0.7	1.2	1	0.42	0.21054	0.70
07/31/2025 08:00	0.7	1.3	2	0.42	0.21024	0.70
07/31/2025 09:00	0.7	1.0	2	0.42	0.20982	0.70
07/31/2025 10:00	0.7	1.1	1	0.42	0.20940	0.70
07/31/2025 11:00	0.7	1.2	1	0.42	0.20958	0.70
07/31/2025 12:00	0.6	1.2	1	0.42	0.21210	0.71
07/31/2025 13:00	0.6	1.2	1	0.46	0.23046	0.77
07/31/2025 14:00	0.6	1.2	1	0.49	0.24426	0.81
07/31/2025 15:00	0.7	1.2	1	0.51	0.25476	0.85
07/31/2025 16:00	0.6	1.2	1	0.42	0.20880	0.70
07/31/2025 17:00	0.6	1.2	1	0.45	0.22284	0.74
07/31/2025 18:00	0.6	1.1	2	0.48	0.24138	0.80
07/31/2025 19:00	0.6	1.2	2	0.44	0.22014	0.73
07/31/2025 20:00	0.7	1.1	1	0.47	0.23748	0.79
07/31/2025 21:00	0.7	1.2	1	0.50	0.24912	0.83
07/31/2025 22:00	0.7	1.3	1	0.51	0.25560	0.85
07/31/2025 23:00	0.7	1.0	2	0.42	0.21168	0.71
Average/Sum#:	0.7	1.2	1	0.44	0.22127	0.74
Minimum:	0.6	1.0	1	0.42	0.20880	0.70
Maximum:	0.8	1.3	2	0.51	0.25560	0.85
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/01/2025 00:00	0.7	1.2	1	0.42	0.20970	0.70
08/01/2025 01:00	0.7	1.3	2	0.42	0.21018	0.70
08/01/2025 02:00	0.7	1.1	2	0.42	0.21042	0.70
08/01/2025 03:00	0.8	1.2	2	0.42	0.21072	0.70
08/01/2025 04:00	0.7	1.2	2	0.43	0.21282	0.71
08/01/2025 05:00	0.7	1.1	2	0.43	0.21432	0.71
08/01/2025 06:00	0.7	1.3	2	0.42	0.21048	0.70
08/01/2025 07:00	0.7	1.2	2	0.42	0.21060	0.70
08/01/2025 08:00	0.7	1.1	2	0.42	0.21024	0.70
08/01/2025 09:00	0.7	1.1	2	0.42	0.20988	0.70
08/01/2025 10:00	0.7	1.2	2	0.42	0.20952	0.70
08/01/2025 11:00	0.7	1.1	2	0.42	0.20982	0.70
08/01/2025 12:00	0.6	1.0	1	0.42	0.20982	0.70
08/01/2025 13:00	0.7	1.1	1	0.45	0.22596	0.75
08/01/2025 14:00	0.6	1.3	1	0.50	0.24924	0.83
08/01/2025 15:00	0.7	1.0	1	0.43	0.21294	0.71
08/01/2025 16:00	0.6	1.1	1	0.42	0.20910	0.70
08/01/2025 17:00	0.6	1.1	1	0.45	0.22368	0.75
08/01/2025 18:00	0.6	1.1	2	0.49	0.24342	0.81
08/01/2025 19:00	0.7	1.1	1	0.42	0.20994	0.70
08/01/2025 20:00	0.7	1.2	2	0.42	0.20970	0.70
08/01/2025 21:00	0.7	1.0	1	0.44	0.22236	0.74
08/01/2025 22:00	0.7	1.1	2	0.44	0.21984	0.73
08/01/2025 23:00	0.7	1.2	1	0.47	0.23460	0.78
Average/Sum#:	0.7	1.1	2	0.43	0.21664	0.72
Minimum:	0.6	1.0	1	0.42	0.20910	0.70
Maximum:	0.8	1.3	2	0.50	0.24924	0.83
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/02/2025 00:00	0.7	1.1	1	0.42	0.21072	0.70
08/02/2025 01:00	0.6	1.2	1	0.47	0.23454	0.78
08/02/2025 02:00	0.7	1.3	2	0.44	0.21882	0.73
08/02/2025 03:00	0.8	1.3	2	0.44	0.21876	0.73
08/02/2025 04:00	0.7	1.2	2	0.44	0.21906	0.73
08/02/2025 05:00	0.7	1.2	2	0.44	0.21894	0.73
08/02/2025 06:00	0.7	1.1	2	0.44	0.22026	0.73
08/02/2025 07:00	0.7	1.2	1	0.44	0.21906	0.73
08/02/2025 08:00	0.7	1.3	1	0.44	0.21852	0.73
08/02/2025 09:00	0.7	1.4	1	0.44	0.21816	0.73
08/02/2025 10:00	0.7	1.4	1	0.44	0.21774	0.73
08/02/2025 11:00	0.6	1.3	1	0.44	0.21780	0.73
08/02/2025 12:00	0.6	1.2	1	0.44	0.21786	0.73
08/02/2025 13:00	0.6	1.2	1	0.44	0.21792	0.73
08/02/2025 14:00	0.6	1.1	1	0.44	0.21774	0.73
08/02/2025 15:00	0.6	1.2	1	0.43	0.21708	0.72
08/02/2025 16:00	0.6	1.2	1	0.43	0.21684	0.72
08/02/2025 17:00	0.7	1.3	1	0.44	0.22128	0.74
08/02/2025 18:00	0.6	1.2	1	0.43	0.21696	0.72
08/02/2025 19:00	0.6	1.2	1	0.43	0.21654	0.72
08/02/2025 20:00	0.7	1.2	1	0.43	0.21672	0.72
08/02/2025 21:00	0.7	1.3	1	0.43	0.21678	0.72
08/02/2025 22:00	0.7	1.3	1	0.43	0.21702	0.72
08/02/2025 23:00	0.7	1.3	1	0.43	0.21738	0.72
Average/Sum#:	0.7	1.2	1	0.44	0.21844	0.73
Minimum:	0.6	1.1	1	0.42	0.21072	0.70
Maximum:	0.8	1.4	2	0.47	0.23454	0.78
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/03/2025 00:00	0.7	1.3	1	0.44	0.21756	0.73
08/03/2025 01:00	0.7	1.3	1	0.44	0.21786	0.73
08/03/2025 02:00	0.7	1.3	1	0.44	0.21792	0.73
08/03/2025 03:00	0.8	1.4	2	0.44	0.21822	0.73
08/03/2025 04:00	0.7	1.1	2	0.44	0.21834	0.73
08/03/2025 05:00	0.7	1.2	1	0.44	0.21822	0.73
08/03/2025 06:00	0.7	1.1	2	0.44	0.21810	0.73
08/03/2025 07:00	0.7	1.1	1	0.44	0.21804	0.73
08/03/2025 08:00	0.7	1.2	1	0.43	0.21744	0.72
08/03/2025 09:00	0.7	1.2	1	0.43	0.21714	0.72
08/03/2025 10:00	0.6	1.3	2	0.43	0.21690	0.72
08/03/2025 11:00	0.6	1.2	2	0.43	0.21744	0.72
08/03/2025 12:00	0.6	1.2	2	0.44	0.21756	0.73
08/03/2025 13:00	0.6	1.0	1	0.43	0.21744	0.72
08/03/2025 14:00	0.6	1.1	1	0.43	0.21726	0.72
08/03/2025 15:00	0.6	1.2	1	0.43	0.21672	0.72
08/03/2025 16:00	0.6	1.2	1	0.43	0.21654	0.72
08/03/2025 17:00	0.6	1.2	1	0.46	0.23196	0.77
08/03/2025 18:00	0.7	1.2	2	0.44	0.21852	0.73
08/03/2025 19:00	0.7	1.2	2	0.43	0.21636	0.72
08/03/2025 20:00	0.7	1.1	2	0.43	0.21672	0.72
08/03/2025 21:00	0.7	1.2	2	0.43	0.21696	0.72
08/03/2025 22:00	0.7	1.2	1	0.43	0.21720	0.72
08/03/2025 23:00	0.7	1.3	1	0.43	0.21732	0.72
Average/Sum#:	0.7	1.2	1	0.44	0.21807	0.73
Minimum:	0.6	1.0	1	0.43	0.21636	0.72
Maximum:	0.8	1.4	2	0.46	0.23196	0.77
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/04/2025 00:00	0.7	1.3	1	0.43	0.21732	0.72
08/04/2025 01:00	0.7	1.4	1	0.43	0.21744	0.72
08/04/2025 02:00	0.7	1.3	1	0.44	0.21762	0.73
08/04/2025 03:00	0.8	1.3	1	0.44	0.21774	0.73
08/04/2025 04:00	0.7	1.3	1	0.44	0.21786	0.73
08/04/2025 05:00	0.7	1.3	1	0.44	0.21804	0.73
08/04/2025 06:00	0.6	1.2	2	0.52	0.26220	0.87
08/04/2025 07:00	0.7	1.1	1	0.45	0.22272	0.74
08/04/2025 08:00	0.7	1.2	1	0.43	0.21696	0.72
08/04/2025 09:00	0.7	1.3	1	0.43	0.21690	0.72
08/04/2025 10:00	0.7	1.4	1	0.43	0.21678	0.72
08/04/2025 11:00	0.7	1.3	1	0.43	0.21720	0.72
08/04/2025 12:00	0.7	1.3	1	0.43	0.21726	0.72
08/04/2025 13:00	0.7	1.2	1	0.43	0.21738	0.72
08/04/2025 14:00	0.7	1.2	1	0.44	0.21768	0.73
08/04/2025 15:00	0.7	1.2	1	0.43	0.21696	0.72
08/04/2025 16:00	0.7	1.2	1	0.43	0.21648	0.72
08/04/2025 17:00	0.6	1.3	1	0.45	0.22746	0.76
08/04/2025 18:00	0.7	1.2	1	0.44	0.21792	0.73
08/04/2025 19:00	0.6	1.3	1	0.43	0.21654	0.72
08/04/2025 20:00	0.7	1.4	1	0.43	0.21672	0.72
08/04/2025 21:00	0.7	1.4	1	0.43	0.21684	0.72
08/04/2025 22:00	0.7	1.4	1	0.43	0.21714	0.72
08/04/2025 23:00	0.7	1.4	1	0.43	0.21738	0.72
Average/Sum#:	0.7	1.3	1	0.44	0.21977	0.73
Minimum:	0.6	1.1	1	0.43	0.21648	0.72
Maximum:	0.8	1.4	2	0.52	0.26220	0.87
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/05/2025 00:00	0.7	1.4	1	0.44	0.21756	0.73
08/05/2025 01:00	0.7	1.4	1	0.44	0.21762	0.73
08/05/2025 02:00	0.7	1.3	1	0.44	0.21774	0.73
08/05/2025 03:00	0.8	1.4	1	0.44	0.21780	0.73
08/05/2025 04:00	0.7	1.3	1	0.44	0.21798	0.73
08/05/2025 05:00	0.7	1.3	1	0.48	0.24090	0.80
08/05/2025 06:00	0.7	1.0	2	0.46	0.23082	0.77
08/05/2025 07:00	0.7	1.2	1	0.44	0.21810	0.73
08/05/2025 08:00	0.7	1.3	1	0.43	0.21720	0.72
08/05/2025 09:00	0.7	1.4	1	0.43	0.21702	0.72
08/05/2025 10:00	0.6	1.4	1	0.43	0.21684	0.72
08/05/2025 11:00	0.6	1.3	1	0.43	0.21738	0.72
08/05/2025 12:00	0.6	1.3	1	0.44	0.21750	0.73
08/05/2025 13:00	0.6	1.3	1	0.44	0.21756	0.73
08/05/2025 14:00	0.6	1.3	1	0.43	0.21744	0.72
08/05/2025 15:00	0.6	1.3	1	0.43	0.21696	0.72
08/05/2025 16:00	0.6	1.4	1	0.45	0.22440	0.75
08/05/2025 17:00	0.6	1.1	1	0.47	0.23478	0.78
08/05/2025 18:00	0.6	1.2	1	0.53	0.26490	0.88
08/05/2025 19:00	0.6	1.2	1	0.51	0.25578	0.85
08/05/2025 20:00	0.6	1.3	1	0.51	0.25674	0.86
08/05/2025 21:00	0.6	1.2	1	0.53	0.26448	0.88
08/05/2025 22:00	0.7	1.2	1	0.51	0.25272	0.84
08/05/2025 23:00	0.7	1.2	1	0.43	0.21684	0.72
Average/Sum#:	0.7	1.3	1	0.46	0.22863	0.76
Minimum:	0.6	1.0	1	0.43	0.21684	0.72
Maximum:	0.8	1.4	2	0.53	0.26490	0.88
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/06/2025 00:00	0.7	1.3	1	0.43	0.21720	0.72
08/06/2025 01:00	0.7	1.3	1	0.43	0.21720	0.72
08/06/2025 02:00	0.7	1.3	1	0.44	0.21756	0.73
08/06/2025 03:00	0.8	1.3	1	0.44	0.21756	0.73
08/06/2025 04:00	0.7	1.4	1	0.44	0.21768	0.73
08/06/2025 05:00	0.7	1.3	1	0.47	0.23262	0.78
08/06/2025 06:00	0.7	1.2	2	0.52	0.25986	0.87
08/06/2025 07:00	0.8	1.2	1	0.45	0.22470	0.75
08/06/2025 08:00	0.7	1.3	1	0.43	0.21708	0.72
08/06/2025 09:00	0.7	1.4	1	0.43	0.21684	0.72
08/06/2025 10:00	0.7	1.4	1	0.43	0.21672	0.72
08/06/2025 11:00	0.7	1.4	1	0.43	0.21726	0.72
08/06/2025 12:00	0.7	1.3	1	0.43	0.21744	0.72
08/06/2025 13:00	0.7	1.3	1	0.43	0.21726	0.72
08/06/2025 14:00	0.7	1.3	1	0.43	0.21660	0.72
08/06/2025 15:00	0.7	1.4	1	0.43	0.21684	0.72
08/06/2025 16:00	0.7	1.4	1	0.44	0.21858	0.73
08/06/2025 17:00	0.7	1.3	1	0.46	0.22980	0.77
08/06/2025 18:00	0.7	1.1	2	0.50	0.25068	0.84
08/06/2025 19:00	0.7	1.2	1	0.45	0.22470	0.75
08/06/2025 20:00	0.7	1.2	1	0.44	0.21978	0.73
08/06/2025 21:00	0.8	1.2	1	0.46	0.23010	0.77
08/06/2025 22:00	0.8	1.1	1	0.47	0.23352	0.78
08/06/2025 23:00	0.7	1.2	1	0.51	0.25578	0.85
Average/Sum#:	0.7	1.3	1	0.45	0.22514	0.75
Minimum:	0.7	1.1	1	0.43	0.21660	0.72
Maximum:	0.8	1.4	2	0.52	0.25986	0.87
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/07/2025 00:00	0.7	1.1	1	0.47	0.23724	0.79
08/07/2025 01:00	0.7	1.0	2	0.46	0.23028	0.77
08/07/2025 02:00	0.7	1.1	1	0.44	0.21780	0.73
08/07/2025 03:00	0.8	1.2	1	0.44	0.21798	0.73
08/07/2025 04:00	0.8	1.2	1	0.45	0.22488	0.75
08/07/2025 05:00	0.8	1.1	1	0.47	0.23646	0.79
08/07/2025 06:00	0.8	1.2	1	0.44	0.21816	0.73
08/07/2025 07:00	0.8	1.3	2	0.44	0.21858	0.73
08/07/2025 08:00	0.8	1.2	2	0.44	0.21828	0.73
08/07/2025 09:00	0.8	1.1	2	0.44	0.21798	0.73
08/07/2025 10:00	0.8	1.2	2	0.44	0.21804	0.73
08/07/2025 11:00	0.7	1.2	2	0.44	0.21858	0.73
08/07/2025 12:00	0.7	1.2	2	0.44	0.21858	0.73
08/07/2025 13:00	0.7	1.2	1	0.44	0.21882	0.73
08/07/2025 14:00	0.7	1.2	1	0.47	0.23484	0.78
08/07/2025 15:00	0.7	1.1	1	0.46	0.23100	0.77
08/07/2025 16:00	0.7	1.1	1	0.43	0.21714	0.72
08/07/2025 17:00	0.7	1.1	1	0.45	0.22626	0.75
08/07/2025 18:00	0.7	1.2	1	0.49	0.24498	0.82
08/07/2025 19:00	0.7	1.2	1	0.46	0.22974	0.77
08/07/2025 20:00	0.7	1.3	1	0.44	0.22230	0.74
08/07/2025 21:00	0.7	1.3	1	0.43	0.21612	0.72
08/07/2025 22:00	0.7	1.2	1	0.43	0.21624	0.72
08/07/2025 23:00	0.7	1.2	1	0.43	0.21636	0.72
Average/Sum#:	0.7	1.2	1	0.45	0.22361	0.75
Minimum:	0.7	1.0	1	0.43	0.21612	0.72
Maximum:	0.8	1.3	2	0.49	0.24498	0.82
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/08/2025 00:00	0.7	1.2	1	0.43	0.21654	0.72
08/08/2025 01:00	0.7	1.3	1	0.43	0.21666	0.72
08/08/2025 02:00	0.7	1.3	1	0.43	0.21672	0.72
08/08/2025 03:00	0.8	1.2	1	0.43	0.21684	0.72
08/08/2025 04:00	0.8	1.2	1	0.43	0.21738	0.72
08/08/2025 05:00	0.8	1.1	1	0.46	0.23070	0.77
08/08/2025 06:00	1.0	1.2	2	0.43	0.21738	0.72
08/08/2025 07:00	0.8	1.2	2	0.43	0.21744	0.72
08/08/2025 08:00	0.8	1.2	2	0.43	0.21672	0.72
08/08/2025 09:00	0.8	1.1	2	0.43	0.21618	0.72
08/08/2025 10:00	0.8	1.1	1	0.43	0.21600	0.72
08/08/2025 11:00	0.7	1.0	1	0.43	0.21678	0.72
08/08/2025 12:00	0.7	1.1	1	0.43	0.21678	0.72
08/08/2025 13:00	0.7	1.1	1	0.44	0.22182	0.74
08/08/2025 14:00	0.7	1.1	1	0.45	0.22284	0.74
08/08/2025 15:00	0.7	1.1	1	0.44	0.21822	0.73
08/08/2025 16:00	0.7	1.1	1	0.47	0.23382	0.78
08/08/2025 17:00	0.7	1.2	1	0.47	0.23544	0.78
08/08/2025 18:00	0.7	0.9	1	0.44	0.21900	0.73
08/08/2025 19:00	0.7	1.0	1	0.43	0.21732	0.72
08/08/2025 20:00	0.8	1.2	1	0.45	0.22416	0.75
08/08/2025 21:00	0.8	1.3	1	0.44	0.21786	0.73
08/08/2025 22:00	0.8	1.3	1	0.43	0.21672	0.72
08/08/2025 23:00	0.9	1.3	1	0.43	0.21612	0.72
Average/Sum#:	0.8	1.2	1	0.44	0.21981	0.73
Minimum:	0.7	0.9	1	0.43	0.21600	0.72
Maximum:	1.0	1.3	2	0.47	0.23544	0.78
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/09/2025 00:00	0.9	1.2	1	0.43	0.21606	0.72
08/09/2025 01:00	0.8	1.2	1	0.43	0.21618	0.72
08/09/2025 02:00	0.8	1.2	1	0.43	0.21630	0.72
08/09/2025 03:00	0.9	1.2	1	0.43	0.21636	0.72
08/09/2025 04:00	0.8	1.2	1	0.43	0.21666	0.72
08/09/2025 05:00	0.8	1.2	1	0.43	0.21660	0.72
08/09/2025 06:00	0.8	1.3	1	0.43	0.21648	0.72
08/09/2025 07:00	0.8	1.2	1	0.43	0.21672	0.72
08/09/2025 08:00	0.7	1.2	1	0.43	0.21606	0.72
08/09/2025 09:00	0.7	1.2	1	0.43	0.21570	0.72
08/09/2025 10:00	0.7	1.2	1	0.43	0.21570	0.72
08/09/2025 11:00	0.7	1.1	1	0.43	0.21636	0.72
08/09/2025 12:00	0.7	1.1	1	0.43	0.21648	0.72
08/09/2025 13:00	0.7	1.0	1	0.43	0.21672	0.72
08/09/2025 14:00	0.7	1.0	1	0.44	0.21864	0.73
08/09/2025 15:00	0.7	0.9	1	0.43	0.21624	0.72
08/09/2025 16:00	0.7	0.9	1	0.46	0.22992	0.77
08/09/2025 17:00	0.7	1.0	1	0.44	0.21786	0.73
08/09/2025 18:00	0.7	0.9	1	0.43	0.21588	0.72
08/09/2025 19:00	0.7	1.2	1	0.47	0.23274	0.78
08/09/2025 20:00	0.7	1.2	1	0.43	0.21744	0.72
08/09/2025 21:00	0.7	1.2	1	0.43	0.21540	0.72
08/09/2025 22:00	0.7	1.2	1	0.43	0.21534	0.72
08/09/2025 23:00	0.7	1.2	1	0.43	0.21570	0.72
Average/Sum#:	0.7	1.1	1	0.43	0.21765	0.73
Minimum:	0.7	0.9	1	0.43	0.21534	0.72
Maximum:	0.9	1.3	1	0.47	0.23274	0.78
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/10/2025 00:00	0.7	1.3	1	0.43	0.21582	0.72
08/10/2025 01:00	0.8	1.3	1	0.43	0.21600	0.72
08/10/2025 02:00	0.7	1.3	1	0.43	0.21612	0.72
08/10/2025 03:00	0.8	1.3	1	0.43	0.21642	0.72
08/10/2025 04:00	0.7	1.2	2	0.43	0.21678	0.72
08/10/2025 05:00	0.8	1.2	2	0.43	0.21684	0.72
08/10/2025 06:00	0.8	1.2	2	0.43	0.21678	0.72
08/10/2025 07:00	0.8	1.1	2	0.43	0.21678	0.72
08/10/2025 08:00	0.7	1.2	2	0.43	0.21594	0.72
08/10/2025 09:00	0.7	1.2	2	0.43	0.21558	0.72
08/10/2025 10:00	0.7	1.0	1	0.43	0.21546	0.72
08/10/2025 11:00	0.7	1.1	1	0.43	0.21624	0.72
08/10/2025 12:00	0.7	1.1	1	0.43	0.21636	0.72
08/10/2025 13:00	0.7	1.1	1	0.48	0.24204	0.81
08/10/2025 14:00	0.7	1.3	1	0.52	0.25950	0.87
08/10/2025 15:00	0.7	1.2	1	0.47	0.23436	0.78
08/10/2025 16:00	0.7	1.2	1	0.47	0.23658	0.79
08/10/2025 17:00	0.7	1.1	1	0.47	0.23748	0.79
08/10/2025 18:00	0.7	1.2	1	0.53	0.26274	0.88
08/10/2025 19:00	0.7	1.2	1	0.47	0.23694	0.79
08/10/2025 20:00	0.7	1.1	1	0.45	0.22260	0.74
08/10/2025 21:00	0.7	1.2	1	0.46	0.22992	0.77
08/10/2025 22:00	0.7	1.2	1	0.43	0.21732	0.72
08/10/2025 23:00	0.7	1.2	1	0.43	0.21702	0.72
Average/Sum#:	0.7	1.2	1	0.45	0.22532	0.75
Minimum:	0.7	1.0	1	0.43	0.21546	0.72
Maximum:	0.8	1.3	2	0.53	0.26274	0.88
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/11/2025 00:00	0.7	1.2	1	0.43	0.21570	0.72
08/11/2025 01:00	0.7	1.3	1	0.43	0.21576	0.72
08/11/2025 02:00	0.7	1.3	1	0.43	0.21582	0.72
08/11/2025 03:00	0.8	1.2	2	0.43	0.21594	0.72
08/11/2025 04:00	0.7	1.3	1	0.46	0.23088	0.77
08/11/2025 05:00	0.7	1.1	2	0.49	0.24594	0.82
08/11/2025 06:00	0.7	1.1	1	0.43	0.21624	0.72
08/11/2025 07:00	0.7	1.2	1	0.43	0.21642	0.72
08/11/2025 08:00	0.7	1.3	1	0.43	0.21582	0.72
08/11/2025 09:00	0.7	1.3	1	0.43	0.21540	0.72
08/11/2025 10:00	0.7	1.3	1	0.43	0.21516	0.72
08/11/2025 11:00	0.7	1.3	1	0.43	0.21564	0.72
08/11/2025 12:00	0.7	1.2	1	0.43	0.21564	0.72
08/11/2025 13:00	0.7	1.2	1	0.44	0.22062	0.74
08/11/2025 14:00	0.7	1.2	1	0.47	0.23466	0.78
08/11/2025 15:00	0.7	1.1	1	0.43	0.21696	0.72
08/11/2025 16:00	0.7	1.1	1	0.46	0.22950	0.77
08/11/2025 17:00	0.7	1.2	1	0.49	0.24300	0.81
08/11/2025 18:00	0.7	1.4	1	0.52	0.26136	0.87
08/11/2025 19:00	0.7	1.4	1	0.50	0.25212	0.84
08/11/2025 20:00	0.6	1.2	1	0.52	0.25950	0.87
08/11/2025 21:00	0.6	1.3	1	0.52	0.25878	0.86
08/11/2025 22:00	0.7	1.1	2	0.49	0.24504	0.82
08/11/2025 23:00	0.7	1.1	2	0.48	0.24042	0.80
Average/Sum#:	0.7	1.2	1	0.46	0.22968	0.77
Minimum:	0.6	1.1	1	0.43	0.21516	0.72
Maximum:	0.8	1.4	2	0.52	0.26136	0.87
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/12/2025 00:00	0.7	1.1	1	0.49	0.24630	0.82
08/12/2025 01:00	0.7	1.2	1	0.48	0.24030	0.80
08/12/2025 02:00	0.7	1.2	1	0.44	0.22020	0.73
08/12/2025 03:00	0.8	1.3	1	0.45	0.22632	0.75
08/12/2025 04:00	0.7	1.2	2	0.50	0.24756	0.83
08/12/2025 05:00	0.6	1.2	1	0.52	0.25854	0.86
08/12/2025 06:00	0.8	1.2	1	0.45	0.22578	0.75
08/12/2025 07:00	0.8	1.3	2	0.44	0.21846	0.73
08/12/2025 08:00	0.8	1.2	2	0.44	0.21774	0.73
08/12/2025 09:00	0.7	1.2	2	0.43	0.21708	0.72
08/12/2025 10:00	0.7	1.1	2	0.43	0.21672	0.72
08/12/2025 11:00	0.7	1.2	2	0.43	0.21702	0.72
08/12/2025 12:00	0.7	1.1	2	0.43	0.21684	0.72
08/12/2025 13:00	0.7	1.0	1	0.45	0.22680	0.76
08/12/2025 14:00	0.7	1.2	1	0.49	0.24720	0.82
08/12/2025 15:00	0.6	1.3	1	0.49	0.24486	0.82
08/12/2025 16:00	0.7	1.3	1	0.50	0.24858	0.83
08/12/2025 17:00	0.6	1.3	1	0.53	0.26328	0.88
08/12/2025 18:00	0.6	1.2	1	0.52	0.26082	0.87
08/12/2025 19:00	0.6	1.2	1	0.52	0.26070	0.87
08/12/2025 20:00	0.7	1.3	1	0.49	0.24498	0.82
08/12/2025 21:00	0.7	1.1	2	0.47	0.23640	0.79
08/12/2025 22:00	0.7	1.1	2	0.48	0.23862	0.80
08/12/2025 23:00	0.7	1.1	1	0.44	0.21762	0.73
Average/Sum#:	0.7	1.2	1	0.47	0.23578	0.79
Minimum:	0.6	1.0	1	0.43	0.21672	0.72
Maximum:	0.8	1.3	2	0.53	0.26328	0.88
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/13/2025 00:00	0.7	1.2	1	0.44	0.21810	0.73
08/13/2025 01:00	0.7	1.3	1	0.44	0.21822	0.73
08/13/2025 02:00	0.7	1.3	1	0.44	0.21834	0.73
08/13/2025 03:00	0.8	1.4	2	0.44	0.21828	0.73
08/13/2025 04:00	0.7	1.3	2	0.44	0.21846	0.73
08/13/2025 05:00	0.7	1.2	2	0.44	0.21858	0.73
08/13/2025 06:00	0.7	1.2	2	0.44	0.21870	0.73
08/13/2025 07:00	0.7	1.1	2	0.44	0.21876	0.73
08/13/2025 08:00	0.7	1.2	2	0.44	0.21858	0.73
08/13/2025 09:00	0.7	1.2	2	0.44	0.21810	0.73
08/13/2025 10:00	0.7	1.2	2	0.44	0.21792	0.73
08/13/2025 11:00	0.7	1.2	2	0.44	0.21828	0.73
08/13/2025 12:00	0.7	1.0	2	0.44	0.21810	0.73
08/13/2025 13:00	0.7	1.3	2	0.44	0.21762	0.73
08/13/2025 14:00	0.7	1.0	1	0.43	0.21702	0.72
08/13/2025 15:00	0.6	1.0	1	0.43	0.21684	0.72
08/13/2025 16:00	0.7	1.1	1	0.43	0.21630	0.72
08/13/2025 17:00	0.6	1.1	1	0.45	0.22488	0.75
08/13/2025 18:00	0.7	1.2	1	0.43	0.21654	0.72
08/13/2025 19:00	0.7	1.2	1	0.43	0.21606	0.72
08/13/2025 20:00	0.7	1.2	1	0.43	0.21624	0.72
08/13/2025 21:00	0.7	1.2	1	0.43	0.21618	0.72
08/13/2025 22:00	0.7	1.3	1	0.43	0.21672	0.72
08/13/2025 23:00	0.7	1.3	1	0.43	0.21732	0.72
Average/Sum#:	0.7	1.2	1	0.44	0.21792	0.73
Minimum:	0.6	1.0	1	0.43	0.21606	0.72
Maximum:	0.8	1.4	2	0.45	0.22488	0.75
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/14/2025 00:00	0.7	1.3	1	0.44	0.21768	0.73
08/14/2025 01:00	0.7	1.3	1	0.44	0.21780	0.73
08/14/2025 02:00	0.7	1.3	1	0.44	0.21792	0.73
08/14/2025 03:00	0.8	1.3	1	0.44	0.21810	0.73
08/14/2025 04:00	0.7	1.3	2	0.44	0.21858	0.73
08/14/2025 05:00	0.7	1.2	2	0.44	0.21888	0.73
08/14/2025 06:00	0.7	1.2	2	0.44	0.21894	0.73
08/14/2025 07:00	0.7	1.2	2	0.44	0.21876	0.73
08/14/2025 08:00	0.7	1.2	2	0.44	0.21852	0.73
08/14/2025 09:00	0.7	1.2	2	0.44	0.21786	0.73
08/14/2025 10:00	0.7	1.2	2	0.43	0.21738	0.72
08/14/2025 11:00	0.7	1.2	2	0.43	0.21738	0.72
08/14/2025 12:00	0.7	1.2	2	0.43	0.21732	0.72
08/14/2025 13:00	0.7	1.2	2	0.44	0.21750	0.73
08/14/2025 14:00	0.6	1.1	1	0.43	0.21744	0.72
08/14/2025 15:00	0.6	1.1	1	0.43	0.21684	0.72
08/14/2025 16:00	0.6	1.1	1	0.43	0.21606	0.72
08/14/2025 17:00	0.6	1.1	1	0.44	0.22098	0.74
08/14/2025 18:00	0.6	1.2	1	0.43	0.21636	0.72
08/14/2025 19:00	0.7	1.1	1	0.43	0.21594	0.72
08/14/2025 20:00	0.7	1.2	1	0.43	0.21606	0.72
08/14/2025 21:00	0.7	1.2	1	0.43	0.21654	0.72
08/14/2025 22:00	0.7	1.2	1	0.43	0.21642	0.72
08/14/2025 23:00	0.7	1.3	1	0.43	0.21654	0.72
Average/Sum#:	0.7	1.2	1	0.44	0.21758	0.73
Minimum:	0.6	1.1	1	0.43	0.21594	0.72
Maximum:	0.8	1.3	2	0.44	0.22098	0.74
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/15/2025 00:00	0.7	1.3	1	0.43	0.21654	0.72
08/15/2025 01:00	0.7	1.3	1	0.43	0.21684	0.72
08/15/2025 02:00	0.7	1.3	2	0.43	0.21690	0.72
08/15/2025 03:00	0.8	1.2	2	0.43	0.21726	0.72
08/15/2025 04:00	0.7	1.2	2	0.44	0.21774	0.73
08/15/2025 05:00	0.7	1.2	2	0.44	0.22062	0.74
08/15/2025 06:00	0.8	1.3	2	0.45	0.22578	0.75
08/15/2025 07:00	0.7	1.1	2	0.44	0.21750	0.73
08/15/2025 08:00	0.7	1.2	2	0.43	0.21702	0.72
08/15/2025 09:00	0.7	1.2	2	0.43	0.21666	0.72
08/15/2025 10:00	0.7	1.1	2	0.43	0.21636	0.72
08/15/2025 11:00	0.7	1.2	2	0.43	0.21660	0.72
08/15/2025 12:00	0.6	1.0	2	0.43	0.21660	0.72
08/15/2025 13:00	0.6	1.1	1	0.43	0.21660	0.72
08/15/2025 14:00	0.7	1.2	1	0.43	0.21654	0.72
08/15/2025 15:00	0.7	1.2	1	0.43	0.21648	0.72
08/15/2025 16:00	0.6	1.1	1	0.43	0.21624	0.72
08/15/2025 17:00	0.6	1.2	1	0.43	0.21678	0.72
08/15/2025 18:00	0.6	1.2	1	0.43	0.21660	0.72
08/15/2025 19:00	0.6	1.2	1	0.43	0.21666	0.72
08/15/2025 20:00	0.7	1.2	2	0.43	0.21696	0.72
08/15/2025 21:00	0.7	1.2	2	0.43	0.21720	0.72
08/15/2025 22:00	0.7	1.2	2	0.44	0.21750	0.73
08/15/2025 23:00	0.7	1.1	1	0.45	0.22446	0.75
Average/Sum#:	0.7	1.2	2	0.43	0.21769	0.72
Minimum:	0.6	1.0	1	0.43	0.21624	0.72
Maximum:	0.8	1.3	2	0.45	0.22578	0.75
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/16/2025 00:00	0.6	1.2	1	0.51	0.25632	0.85
08/16/2025 01:00	0.7	1.1	2	0.44	0.21786	0.73
08/16/2025 02:00	0.7	1.3	2	0.44	0.21822	0.73
08/16/2025 03:00	0.8	1.4	2	0.44	0.21834	0.73
08/16/2025 04:00	0.7	1.2	2	0.44	0.21840	0.73
08/16/2025 05:00	0.7	1.2	2	0.44	0.21840	0.73
08/16/2025 06:00	0.7	1.2	2	0.44	0.21864	0.73
08/16/2025 07:00	0.7	1.2	2	0.44	0.21870	0.73
08/16/2025 08:00	0.7	1.2	2	0.44	0.21810	0.73
08/16/2025 09:00	0.6	1.2	2	0.44	0.21786	0.73
08/16/2025 10:00	0.6	1.1	2	0.44	0.21762	0.73
08/16/2025 11:00	0.6	1.2	2	0.44	0.21804	0.73
08/16/2025 12:00	0.6	1.3	2	0.44	0.21804	0.73
08/16/2025 13:00	0.6	1.1	2	0.44	0.21822	0.73
08/16/2025 14:00	0.6	1.1	2	0.46	0.23160	0.77
08/16/2025 15:00	0.6	1.2	2	0.44	0.21804	0.73
08/16/2025 16:00	0.6	1.2	2	0.43	0.21738	0.72
08/16/2025 17:00	0.6	1.1	2	0.45	0.22260	0.74
08/16/2025 18:00	0.6	1.2	2	0.44	0.21948	0.73
08/16/2025 19:00	0.6	1.2	2	0.46	0.23016	0.77
08/16/2025 20:00	0.6	1.2	2	0.43	0.21696	0.72
08/16/2025 21:00	0.6	1.2	2	0.44	0.21810	0.73
08/16/2025 22:00	0.6	1.2	2	0.44	0.21858	0.73
08/16/2025 23:00	0.6	1.2	1	0.50	0.25224	0.84
Average/Sum#:	0.6	1.2	2	0.45	0.22241	0.74
Minimum:	0.6	1.1	1	0.43	0.21696	0.72
Maximum:	0.8	1.4	2	0.51	0.25632	0.85
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/17/2025 00:00	0.7	1.1	2	0.43	0.21642	0.72
08/17/2025 01:00	0.7	1.1	2	0.43	0.21666	0.72
08/17/2025 02:00	0.7	1.2	2	0.43	0.21654	0.72
08/17/2025 03:00	0.8	1.1	2	0.43	0.21660	0.72
08/17/2025 04:00	0.7	1.2	2	0.43	0.21678	0.72
08/17/2025 05:00	0.7	1.2	2	0.43	0.21708	0.72
08/17/2025 06:00	0.7	1.2	2	0.43	0.21732	0.72
08/17/2025 07:00	0.7	1.1	2	0.43	0.21738	0.72
08/17/2025 08:00	0.7	1.2	2	0.43	0.21684	0.72
08/17/2025 09:00	0.7	1.2	2	0.43	0.21672	0.72
08/17/2025 10:00	0.6	1.2	2	0.43	0.21696	0.72
08/17/2025 11:00	0.6	1.3	2	0.44	0.21762	0.73
08/17/2025 12:00	0.6	1.2	2	0.44	0.21768	0.73
08/17/2025 13:00	0.6	1.2	2	0.44	0.21792	0.73
08/17/2025 14:00	0.6	1.2	2	0.44	0.21780	0.73
08/17/2025 15:00	0.6	1.2	2	0.44	0.21762	0.73
08/17/2025 16:00	0.6	1.2	2	0.45	0.22518	0.75
08/17/2025 17:00	0.6	1.2	1	0.49	0.24702	0.82
08/17/2025 18:00	0.6	1.2	1	0.53	0.26586	0.89
08/17/2025 19:00	0.6	1.2	1	0.53	0.26592	0.89
08/17/2025 20:00	0.6	1.2	2	0.53	0.26544	0.88
08/17/2025 21:00	0.6	1.2	1	0.53	0.26520	0.88
08/17/2025 22:00	0.6	1.1	1	0.53	0.26502	0.88
08/17/2025 23:00	0.6	1.2	1	0.52	0.25998	0.87
Average/Sum#:	0.6	1.2	2	0.46	0.23057	0.77
Minimum:	0.6	1.1	1	0.43	0.21642	0.72
Maximum:	0.8	1.3	2	0.53	0.26592	0.89
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/18/2025 00:00	0.7	1.2	2	0.44	0.21798	0.73
08/18/2025 01:00	0.7	1.2	2	0.44	0.21810	0.73
08/18/2025 02:00	0.7	1.0	2	0.44	0.21816	0.73
08/18/2025 03:00	0.8	1.1	2	0.44	0.21810	0.73
08/18/2025 04:00	0.7	1.2	2	0.46	0.22788	0.76
08/18/2025 05:00	0.7	1.2	2	0.50	0.25212	0.84
08/18/2025 06:00	0.7	1.2	2	0.44	0.21870	0.73
08/18/2025 07:00	0.7	1.2	3	0.44	0.21882	0.73
08/18/2025 08:00	0.7	1.2	2	0.44	0.21828	0.73
08/18/2025 09:00	0.7	1.2	2	0.44	0.21810	0.73
08/18/2025 10:00	0.7	1.2	2	0.44	0.21804	0.73
08/18/2025 11:00	0.6	1.3	1	0.52	0.26196	0.87
08/18/2025 12:00	0.6	1.3	1	0.53	0.26406	0.88
08/18/2025 13:00	0.6	1.3	1	0.53	0.26664	0.89
08/18/2025 14:00	0.6	1.2	1	0.54	0.26754	0.89
08/18/2025 15:00	0.6	1.1	1	0.54	0.26802	0.89
08/18/2025 16:00	0.6	1.2	2	0.48	0.24000	0.80
08/18/2025 17:00	0.6	1.2	2	0.49	0.24258	0.81
08/18/2025 18:00	0.6	1.3	1	0.54	0.26820	0.89
08/18/2025 19:00	0.6	1.1	1	0.53	0.26700	0.89
08/18/2025 20:00	0.6	1.3	2	0.53	0.26616	0.89
08/18/2025 21:00	0.7	1.2	2	0.52	0.25824	0.86
08/18/2025 22:00	0.7	1.2	2	0.49	0.24252	0.81
08/18/2025 23:00	0.7	1.1	2	0.45	0.22398	0.75
Average/Sum#:	0.7	1.2	2	0.48	0.24088	0.80
Minimum:	0.6	1.0	1	0.44	0.21798	0.73
Maximum:	0.8	1.3	3	0.54	0.26820	0.89
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 **To:** 09/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/19/2025 00:00	0.7	1.2	2	0.44	0.21750	0.73
08/19/2025 01:00	0.7	1.3	2	0.44	0.21768	0.73
08/19/2025 02:00	0.7	1.2	2	0.44	0.21780	0.73
08/19/2025 03:00	0.8	1.4	2	0.44	0.21786	0.73
08/19/2025 04:00	0.7	1.2	2	0.46	0.23160	0.77
08/19/2025 05:00	0.7	1.3	2	0.47	0.23370	0.78
08/19/2025 06:00	0.7	1.3	2	0.45	0.22734	0.76
08/19/2025 07:00	0.7	1.3	2	0.44	0.21870	0.73
08/19/2025 08:00	0.7	1.2	2	0.44	0.21822	0.73
08/19/2025 09:00	0.7	1.3	2	0.44	0.21780	0.73
08/19/2025 10:00	0.7	1.2	2	0.44	0.21756	0.73
08/19/2025 11:00	0.7	1.1	2	0.46	0.22824	0.76
08/19/2025 12:00	0.7	1.3	1	0.54	0.26778	0.89
08/19/2025 13:00	0.6	1.3	1	0.54	0.26766	0.89
08/19/2025 14:00	0.6	1.2	1	0.53	0.26730	0.89
08/19/2025 15:00	0.6	1.2	1	0.53	0.26670	0.89
08/19/2025 16:00	0.6	1.2	2	0.52	0.25836	0.86
08/19/2025 17:00	0.6	1.2	2	0.49	0.24276	0.81
08/19/2025 18:00	0.6	1.2	1	0.53	0.26658	0.89
08/19/2025 19:00	0.6	1.2	1	0.53	0.26526	0.88
08/19/2025 20:00	0.6	1.1	1	0.53	0.26568	0.89
08/19/2025 21:00	0.6	1.2	1	0.53	0.26556	0.89
08/19/2025 22:00	0.6	1.2	2	0.52	0.26160	0.87
08/19/2025 23:00	0.6	1.3	2	0.49	0.24708	0.82
Average/Sum#:	0.7	1.2	2	0.49	0.24193	0.81
Minimum:	0.6	1.1	1	0.44	0.21750	0.73
Maximum:	0.8	1.4	2	0.54	0.26778	0.89
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/20/2025 00:00	0.7	1.1	2	0.44	0.22164	0.74
08/20/2025 01:00	0.7	1.2	2	0.44	0.21876	0.73
08/20/2025 02:00	0.8	1.0	2	0.44	0.21852	0.73
08/20/2025 03:00	0.9	1.4	2	0.44	0.21834	0.73
08/20/2025 04:00	0.8	1.3	2	0.44	0.22122	0.74
08/20/2025 05:00	0.7	1.3	2	0.48	0.23958	0.80
08/20/2025 06:00	1.1	1.1	2	0.51	0.25488	0.85
08/20/2025 07:00	0.7	1.2	2	0.50	0.25026	0.83
08/20/2025 08:00	0.7	1.2	1	0.53	0.26712	0.89
08/20/2025 09:00	0.7	1.3	1	0.53	0.26622	0.89
08/20/2025 10:00	0.7	1.3	1	0.53	0.26322	0.88
08/20/2025 11:00	0.7	1.2	1	0.53	0.26724	0.89
08/20/2025 12:00	0.7	1.2	1	0.53	0.26706	0.89
08/20/2025 13:00	0.8	1.2	2	0.54	0.27078	0.90
08/20/2025 14:00	0.2	1.5	3	0.72	0.36144	1.20
08/20/2025 15:00	0.4	1.4	2	0.65	0.32496	1.08
08/20/2025 16:00	0.6	1.3	2	0.61	0.30714	1.02
08/20/2025 17:00	0.5	1.3	2	0.64	0.32112	1.07
08/20/2025 18:00	0.2	1.5	3	0.70	0.35244	1.17
08/20/2025 19:00	0.7	1.4	2	0.61	0.30456	1.02
08/20/2025 20:00	0.8	1.3	2	0.61	0.30324	1.01
08/20/2025 21:00	0.9	1.3	2	0.61	0.30270	1.01
08/20/2025 22:00	0.8	1.2	1	0.53	0.26658	0.89
08/20/2025 23:00	0.7	1.1	2	0.53	0.26250	0.88
Average/Sum#:	0.7	1.3	2	0.55	0.27298	0.91
Minimum:	0.2	1.0	1	0.44	0.21834	0.73
Maximum:	1.1	1.5	3	0.72	0.36144	1.20
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/21/2025 00:00	0.7	1.1	2	0.52	0.26106	0.87
08/21/2025 01:00	0.7	1.2	2	0.51	0.25518	0.85
08/21/2025 02:00	0.7	1.2	2	0.53	0.26442	0.88
08/21/2025 03:00	0.9	1.2	2	0.54	0.26796	0.89
08/21/2025 04:00	0.4	1.5	2	0.68	0.33864	1.13
08/21/2025 05:00	0.3	1.5	3	0.72	0.35958	1.20
08/21/2025 06:00	0.8	1.3	2	0.60	0.30066	1.00
08/21/2025 07:00	0.8	1.2	2	0.44	0.21882	0.73
08/21/2025 08:00	0.8	1.3	2	0.43	0.21684	0.72
08/21/2025 09:00	0.7	1.2	2	0.43	0.21666	0.72
08/21/2025 10:00	0.7	1.2	1	0.44	0.21894	0.73
08/21/2025 11:00	0.7	1.1	2	0.50	0.24816	0.83
08/21/2025 12:00	0.6	1.4	2	0.60	0.29976	1.00
08/21/2025 13:00	0.1	1.5	3	0.75	0.37356	1.25
08/21/2025 14:00	0.1	1.5	4	0.75	0.37722	1.26
08/21/2025 15:00	0.1	1.4	3	0.73	0.36396	1.21
08/21/2025 16:00	0.2	1.5	2	0.68	0.33984	1.13
08/21/2025 17:00	0.4	1.4	3	0.67	0.33720	1.12
08/21/2025 18:00	0.1	1.5	4	0.76	0.38052	1.27
08/21/2025 19:00	0.0	0.0	0	0.70	0.35220	1.17
08/21/2025 20:00	0.1	1.3	3	0.73	0.36252	1.21
08/21/2025 21:00	0.3	1.4	3	0.69	0.34290	1.14
08/21/2025 22:00	0.6	1.3	2	0.63	0.31680	1.06
08/21/2025 23:00	0.5	1.4	2	0.65	0.32652	1.09
Average/Sum#:	0.5	1.3	2	0.61	0.30583	1.02
Minimum:	0.1	1.1	1	0.43	0.21666	0.72
Maximum:	0.9	1.5	4	0.76	0.38052	1.27
%SI	4.17	4.17	4.17	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/22/2025 00:00	0.9	1.3	2	0.61	0.30264	1.01
08/22/2025 01:00	1.0	1.3	2	0.53	0.26418	0.88
08/22/2025 02:00	0.7	1.3	2	0.44	0.21792	0.73
08/22/2025 03:00	0.8	1.4	2	0.44	0.21804	0.73
08/22/2025 04:00	0.8	1.3	2	0.50	0.24942	0.83
08/22/2025 05:00	0.9	1.3	2	0.60	0.30192	1.01
08/22/2025 06:00	0.9	1.3	2	0.53	0.26274	0.88
08/22/2025 07:00	0.7	1.2	2	0.44	0.21816	0.73
08/22/2025 08:00	0.8	1.2	2	0.43	0.21726	0.72
08/22/2025 09:00	0.7	1.2	2	0.43	0.21654	0.72
08/22/2025 10:00	0.7	1.2	1	0.43	0.21624	0.72
08/22/2025 11:00	0.7	1.2	1	0.48	0.23982	0.80
08/22/2025 12:00	0.7	1.2	1	0.48	0.24180	0.81
08/22/2025 13:00	0.8	1.1	1	0.53	0.26586	0.89
08/22/2025 14:00	0.1	1.4	3	0.75	0.37320	1.24
08/22/2025 15:00	0.1	1.4	3	0.72	0.36246	1.21
08/22/2025 16:00	0.1	1.5	4	0.76	0.37836	1.26
08/22/2025 17:00	0.1	1.5	4	0.76	0.38184	1.27
08/22/2025 18:00	0.1	1.4	3	0.72	0.36210	1.21
08/22/2025 19:00	0.1	1.4	3	0.71	0.35574	1.19
08/22/2025 20:00	0.1	1.5	4	0.75	0.37704	1.26
08/22/2025 21:00	0.1	1.5	4	0.77	0.38364	1.28
08/22/2025 22:00	0.1	1.5	4	0.75	0.37692	1.26
08/22/2025 23:00	0.3	1.4	3	0.71	0.35280	1.18
Average/Sum#:	0.5	1.3	2	0.59	0.29736	0.99
Minimum:	0.1	1.1	1	0.43	0.21624	0.72
Maximum:	1.0	1.5	4	0.77	0.38364	1.28
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 **To:** 09/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/23/2025 00:00	0.6	1.4	2	0.62	0.30822	1.03
08/23/2025 01:00	0.6	1.3	2	0.61	0.30666	1.02
08/23/2025 02:00	0.6	1.3	2	0.61	0.30570	1.02
08/23/2025 03:00	0.7	1.4	2	0.61	0.30504	1.02
08/23/2025 04:00	0.7	1.3	2	0.61	0.30336	1.01
08/23/2025 05:00	0.4	1.4	3	0.67	0.33294	1.11
08/23/2025 06:00	0.8	1.3	2	0.49	0.24480	0.82
08/23/2025 07:00	0.8	1.1	2	0.44	0.21756	0.73
08/23/2025 08:00	0.7	1.3	2	0.43	0.21696	0.72
08/23/2025 09:00	0.8	1.3	2	0.49	0.24672	0.82
08/23/2025 10:00	0.8	1.3	2	0.61	0.30252	1.01
08/23/2025 11:00	0.7	1.2	1	0.49	0.24408	0.81
08/23/2025 12:00	0.7	1.4	2	0.62	0.30990	1.03
08/23/2025 13:00	0.1	1.5	4	0.75	0.37740	1.26
08/23/2025 14:00	0.1	1.5	4	0.77	0.38526	1.28
08/23/2025 15:00	0.1	1.5	4	0.74	0.37248	1.24
08/23/2025 16:00	0.1	1.5	4	0.76	0.37812	1.26
08/23/2025 17:00	0.2	1.5	3	0.69	0.34566	1.15
08/23/2025 18:00	0.3	1.4	3	0.68	0.33750	1.13
08/23/2025 19:00	0.6	1.3	2	0.62	0.31092	1.04
08/23/2025 20:00	0.7	1.4	2	0.62	0.31086	1.04
08/23/2025 21:00	0.3	1.4	3	0.69	0.34488	1.15
08/23/2025 22:00	0.3	1.4	3	0.71	0.35460	1.18
08/23/2025 23:00	0.2	1.5	3	0.71	0.35646	1.19
Average/Sum#:	0.5	1.4	3	0.63	0.31328	1.04
Minimum:	0.1	1.1	1	0.43	0.21696	0.72
Maximum:	0.8	1.5	4	0.77	0.38526	1.28
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/24/2025 00:00	0.9	1.3	2	0.61	0.30450	1.02
08/24/2025 01:00	1.0	1.3	2	0.60	0.29952	1.00
08/24/2025 02:00	0.9	1.5	2	0.60	0.30108	1.00
08/24/2025 03:00	0.9	1.4	2	0.60	0.30162	1.01
08/24/2025 04:00	0.8	1.2	2	0.46	0.23220	0.77
08/24/2025 05:00	0.7	1.1	2	0.49	0.24708	0.82
08/24/2025 06:00	0.7	1.2	2	0.45	0.22572	0.75
08/24/2025 07:00	0.7	1.1	2	0.44	0.21804	0.73
08/24/2025 08:00	0.7	1.2	2	0.44	0.21756	0.73
08/24/2025 09:00	0.7	1.2	2	0.43	0.21720	0.72
08/24/2025 10:00	0.7	1.3	2	0.43	0.21684	0.72
08/24/2025 11:00	0.7	1.1	2	0.43	0.21702	0.72
08/24/2025 12:00	0.6	1.1	1	0.45	0.22308	0.74
08/24/2025 13:00	0.7	1.2	1	0.48	0.23820	0.79
08/24/2025 14:00	0.8	1.1	1	0.52	0.26232	0.87
08/24/2025 15:00	0.5	1.4	2	0.64	0.32190	1.07
08/24/2025 16:00	0.2	1.4	3	0.70	0.34794	1.16
08/24/2025 17:00	0.4	1.4	3	0.67	0.33570	1.12
08/24/2025 18:00	0.3	1.4	3	0.67	0.33690	1.12
08/24/2025 19:00	0.2	1.4	3	0.70	0.35202	1.17
08/24/2025 20:00	0.6	1.3	2	0.63	0.31434	1.05
08/24/2025 21:00	0.7	1.4	2	0.61	0.30252	1.01
08/24/2025 22:00	0.6	1.3	2	0.61	0.30504	1.02
08/24/2025 23:00	0.7	1.4	2	0.61	0.30570	1.02
Average/Sum#:	0.7	1.3	2	0.55	0.27684	0.92
Minimum:	0.2	1.1	1	0.43	0.21684	0.72
Maximum:	1.0	1.5	3	0.70	0.35202	1.17
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/25/2025 00:00	0.7	1.3	2	0.60	0.30216	1.01
08/25/2025 01:00	0.8	1.3	2	0.60	0.30180	1.01
08/25/2025 02:00	0.9	1.3	2	0.60	0.30180	1.01
08/25/2025 03:00	1.0	1.4	2	0.60	0.30114	1.00
08/25/2025 04:00	0.9	1.4	2	0.61	0.30324	1.01
08/25/2025 05:00	0.7	1.3	2	0.64	0.31884	1.06
08/25/2025 06:00	0.4	1.4	3	0.68	0.34008	1.13
08/25/2025 07:00	0.8	1.2	2	0.49	0.24618	0.82
08/25/2025 08:00	0.7	1.6	2	0.44	0.21810	0.73
08/25/2025 09:00	0.7	1.2	2	0.46	0.23034	0.77
08/25/2025 10:00	0.6	1.3	1	0.51	0.25572	0.85
08/25/2025 11:00	0.6	1.1	2	0.45	0.22434	0.75
08/25/2025 12:00	0.6	1.2	1	0.53	0.26586	0.89
08/25/2025 13:00	0.4	1.4	3	0.68	0.34032	1.13
08/25/2025 14:00	0.5	1.2	2	0.63	0.31440	1.05
08/25/2025 15:00	0.4	1.3	2	0.64	0.32004	1.07
08/25/2025 16:00	0.4	1.4	2	0.65	0.32460	1.08
08/25/2025 17:00	0.1	1.4	3	0.74	0.37104	1.24
08/25/2025 18:00	0.1	1.4	4	0.75	0.37434	1.25
08/25/2025 19:00	0.6	1.4	2	0.63	0.31398	1.05
08/25/2025 20:00	0.4	1.3	2	0.65	0.32376	1.08
08/25/2025 21:00	0.7	1.4	2	0.61	0.30372	1.01
08/25/2025 22:00	0.8	1.3	2	0.61	0.30378	1.01
08/25/2025 23:00	0.6	1.3	2	0.62	0.30840	1.03
Average/Sum#:	0.6	1.3	2	0.60	0.30033	1.00
Minimum:	0.1	1.1	1	0.44	0.21810	0.73
Maximum:	1.0	1.6	4	0.75	0.37434	1.25
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/26/2025 00:00	0.7	1.4	2	0.61	0.30690	1.02
08/26/2025 01:00	0.7	1.3	2	0.61	0.30420	1.01
08/26/2025 02:00	0.8	1.2	2	0.61	0.30294	1.01
08/26/2025 03:00	0.9	1.4	2	0.62	0.30852	1.03
08/26/2025 04:00	0.8	1.4	2	0.64	0.31830	1.06
08/26/2025 05:00	0.2	1.5	3	0.72	0.36192	1.21
08/26/2025 06:00	0.5	1.4	3	0.67	0.33570	1.12
08/26/2025 07:00	0.7	1.4	2	0.64	0.31860	1.06
08/26/2025 08:00	0.8	1.3	2	0.61	0.30288	1.01
08/26/2025 09:00	0.9	1.8	1	0.59	0.29268	0.98
08/26/2025 10:00	0.0	0.0	0	0.00	0.00000	0.00
08/26/2025 11:00	0.0	0.0	0	0.00	0.00000	0.00
08/26/2025 12:00	0.0	0.0	0	0.00	0.00000	0.00
08/26/2025 13:00	0.0	0.0	0	0.00	0.00000	0.00
08/26/2025 14:00	0.0	0.0	0	0.00	0.00000	0.00
08/26/2025 15:00	0.0	0.0	0	0.00	0.00000	0.00
08/26/2025 16:00	0.0	0.0	0	0.00	0.00000	0.00
08/26/2025 17:00	0.0	0.0	0	0.08	0.03774	0.13
08/26/2025 18:00	0.0	0.0	0	0.07	0.03684	0.12
08/26/2025 19:00	0.0	0.0	0	0.00	0.00000	0.00
08/26/2025 20:00	0.0	0.0	0	0.00	0.00000	0.00
08/26/2025 21:00	0.0	0.0	0	0.00	0.00000	0.00
08/26/2025 22:00	0.0	0.0	0	0.00	0.00000	0.00
08/26/2025 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.6	1.2	2	0.54	0.26894	0.90
Minimum:	0.0	0.0	1	0.07	0.03684	0.12
Maximum:	0.9	1.8	3	0.72	0.36192	1.21
%SI	50.00	50.00	58.33	50.00	50.00	50.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/27/2025 00:00	0.0	0.0	0	0.09	0.04374	0.15
08/27/2025 01:00	0.6	0.9	3	0.43	0.21318	0.71
08/27/2025 02:00	0.6	1.2	2	0.43	0.21738	0.72
08/27/2025 03:00	0.7	1.1	2	0.43	0.21744	0.72
08/27/2025 04:00	0.6	1.2	2	0.44	0.22236	0.74
08/27/2025 05:00	0.6	1.1	2	0.45	0.22410	0.75
08/27/2025 06:00	0.6	1.2	2	0.44	0.21756	0.73
08/27/2025 07:00	0.6	1.2	2	0.44	0.21768	0.73
08/27/2025 08:00	0.6	1.1	2	0.43	0.21732	0.72
08/27/2025 09:00	0.6	1.2	2	0.43	0.21708	0.72
08/27/2025 10:00	0.6	1.2	2	0.43	0.21714	0.72
08/27/2025 11:00	0.6	1.2	2	0.44	0.21762	0.73
08/27/2025 12:00	0.6	1.1	1	0.48	0.24000	0.80
08/27/2025 13:00	0.6	1.2	1	0.53	0.26700	0.89
08/27/2025 14:00	0.5	1.1	1	0.53	0.26688	0.89
08/27/2025 15:00	0.5	1.2	2	0.53	0.26688	0.89
08/27/2025 16:00	0.5	1.1	2	0.50	0.25116	0.84
08/27/2025 17:00	0.6	1.2	1	0.53	0.26532	0.88
08/27/2025 18:00	0.8	1.4	2	0.61	0.30270	1.01
08/27/2025 19:00	0.8	1.2	2	0.60	0.30156	1.01
08/27/2025 20:00	0.7	1.3	2	0.61	0.30414	1.01
08/27/2025 21:00	0.7	1.3	2	0.53	0.26526	0.88
08/27/2025 22:00	0.6	1.2	2	0.43	0.21726	0.72
08/27/2025 23:00	0.6	1.1	2	0.44	0.21762	0.73
Average/Sum#:	0.6	1.1	2	0.47	0.23368	0.78
Minimum:	0.0	0.0	1	0.09	0.04374	0.15
Maximum:	0.8	1.4	3	0.61	0.30414	1.01
%SI	0.00	0.00	4.17	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/28/2025 00:00	0.6	1.2	2	0.44	0.21792	0.73
08/28/2025 01:00	0.8	1.1	2	0.51	0.25302	0.84
08/28/2025 02:00	0.9	1.4	2	0.60	0.30042	1.00
08/28/2025 03:00	1.0	1.3	2	0.57	0.28644	0.95
08/28/2025 04:00	0.7	1.2	2	0.48	0.23832	0.79
08/28/2025 05:00	0.6	1.1	2	0.44	0.22050	0.74
08/28/2025 06:00	0.6	1.3	2	0.47	0.23274	0.78
08/28/2025 07:00	0.6	1.2	2	0.44	0.21822	0.73
08/28/2025 08:00	0.6	1.2	2	0.44	0.21786	0.73
08/28/2025 09:00	0.6	1.2	2	0.44	0.21756	0.73
08/28/2025 10:00	0.6	1.1	2	0.43	0.21720	0.72
08/28/2025 11:00	0.6	1.2	2	0.44	0.21774	0.73
08/28/2025 12:00	0.6	1.2	2	0.44	0.21786	0.73
08/28/2025 13:00	0.6	1.1	1	0.46	0.22914	0.76
08/28/2025 14:00	0.6	1.2	2	0.46	0.23184	0.77
08/28/2025 15:00	0.6	1.2	2	0.48	0.23796	0.79
08/28/2025 16:00	0.7	1.2	2	0.50	0.24948	0.83
08/28/2025 17:00	0.7	1.4	2	0.61	0.30324	1.01
08/28/2025 18:00	0.8	1.3	2	0.61	0.30270	1.01
08/28/2025 19:00	0.7	1.4	2	0.61	0.30492	1.02
08/28/2025 20:00	0.5	1.4	2	0.62	0.31044	1.03
08/28/2025 21:00	0.7	1.3	2	0.61	0.30540	1.02
08/28/2025 22:00	0.7	1.4	2	0.61	0.30318	1.01
08/28/2025 23:00	0.7	1.3	2	0.61	0.30276	1.01
Average/Sum#:	0.7	1.2	2	0.51	0.25570	0.85
Minimum:	0.5	1.1	1	0.43	0.21720	0.72
Maximum:	1.0	1.4	2	0.62	0.31044	1.03
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/29/2025 00:00	0.8	1.3	2	0.60	0.30192	1.01
08/29/2025 01:00	0.8	1.3	2	0.53	0.26514	0.88
08/29/2025 02:00	0.7	1.3	2	0.44	0.21774	0.73
08/29/2025 03:00	0.7	1.4	2	0.44	0.21804	0.73
08/29/2025 04:00	0.6	1.2	3	0.44	0.21798	0.73
08/29/2025 05:00	0.6	1.1	2	0.44	0.21804	0.73
08/29/2025 06:00	0.6	1.2	2	0.44	0.21810	0.73
08/29/2025 07:00	0.6	1.2	2	0.44	0.21786	0.73
08/29/2025 08:00	0.6	1.2	2	0.44	0.21762	0.73
08/29/2025 09:00	0.6	1.1	2	0.43	0.21744	0.72
08/29/2025 10:00	0.6	1.2	2	0.43	0.21726	0.72
08/29/2025 11:00	0.6	1.2	2	0.44	0.21750	0.73
08/29/2025 12:00	0.6	1.1	2	0.43	0.21732	0.72
08/29/2025 13:00	0.6	1.1	1	0.43	0.21678	0.72
08/29/2025 14:00	0.6	1.3	1	0.43	0.21654	0.72
08/29/2025 15:00	0.6	1.3	1	0.43	0.21642	0.72
08/29/2025 16:00	0.6	1.3	1	0.44	0.21816	0.73
08/29/2025 17:00	0.6	1.4	1	0.48	0.23820	0.79
08/29/2025 18:00	0.6	1.0	2	0.44	0.21894	0.73
08/29/2025 19:00	0.6	1.2	2	0.43	0.21690	0.72
08/29/2025 20:00	0.6	1.1	2	0.44	0.21840	0.73
08/29/2025 21:00	0.6	1.2	2	0.44	0.22182	0.74
08/29/2025 22:00	0.6	1.1	2	0.43	0.21720	0.72
08/29/2025 23:00	0.6	1.2	2	0.43	0.21666	0.72
Average/Sum#:	0.6	1.2	2	0.45	0.22408	0.75
Minimum:	0.6	1.0	1	0.43	0.21642	0.72
Maximum:	0.8	1.4	3	0.60	0.30192	1.01
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/30/2025 00:00	0.6	1.2	2	0.43	0.21690	0.72
08/30/2025 01:00	0.6	1.2	2	0.43	0.21708	0.72
08/30/2025 02:00	0.7	1.1	2	0.43	0.21714	0.72
08/30/2025 03:00	0.8	1.1	2	0.43	0.21738	0.72
08/30/2025 04:00	0.7	1.3	2	0.43	0.21726	0.72
08/30/2025 05:00	0.7	1.2	2	0.44	0.21756	0.73
08/30/2025 06:00	0.7	1.2	2	0.44	0.21780	0.73
08/30/2025 07:00	0.7	1.1	2	0.44	0.21756	0.73
08/30/2025 08:00	0.7	1.2	2	0.43	0.21696	0.72
08/30/2025 09:00	0.7	1.2	2	0.43	0.21648	0.72
08/30/2025 10:00	0.7	1.2	2	0.43	0.21636	0.72
08/30/2025 11:00	0.7	1.1	1	0.43	0.21702	0.72
08/30/2025 12:00	0.6	1.2	1	0.43	0.21708	0.72
08/30/2025 13:00	0.6	1.1	1	0.43	0.21642	0.72
08/30/2025 14:00	0.6	1.2	1	0.43	0.21624	0.72
08/30/2025 15:00	0.6	1.2	1	0.43	0.21606	0.72
08/30/2025 16:00	0.6	1.2	1	0.45	0.22530	0.75
08/30/2025 17:00	0.6	1.1	2	0.49	0.24726	0.82
08/30/2025 18:00	0.4	1.4	2	0.64	0.31758	1.06
08/30/2025 19:00	0.1	1.4	3	0.65	0.32316	1.08
08/30/2025 20:00	0.1	1.4	3	0.64	0.31842	1.06
08/30/2025 21:00	0.3	1.3	3	0.63	0.31272	1.04
08/30/2025 22:00	0.4	1.4	2	0.62	0.31164	1.04
08/30/2025 23:00	0.7	1.2	2	0.53	0.26262	0.88
Average/Sum#:	0.6	1.2	2	0.48	0.24125	0.80
Minimum:	0.1	1.1	1	0.43	0.21606	0.72
Maximum:	0.8	1.4	3	0.65	0.32316	1.08
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 **To:** 09/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/31/2025 00:00	0.7	1.2	2	0.43	0.21624	0.72
08/31/2025 01:00	0.6	1.2	2	0.43	0.21642	0.72
08/31/2025 02:00	0.7	1.0	2	0.43	0.21666	0.72
08/31/2025 03:00	0.7	1.4	2	0.43	0.21666	0.72
08/31/2025 04:00	0.6	1.2	2	0.43	0.21672	0.72
08/31/2025 05:00	0.6	1.1	2	0.43	0.21684	0.72
08/31/2025 06:00	0.6	1.2	2	0.43	0.21708	0.72
08/31/2025 07:00	0.6	1.2	2	0.43	0.21702	0.72
08/31/2025 08:00	0.6	1.2	2	0.43	0.21636	0.72
08/31/2025 09:00	0.6	1.1	2	0.43	0.21612	0.72
08/31/2025 10:00	0.6	1.2	1	0.43	0.21600	0.72
08/31/2025 11:00	0.6	1.2	1	0.43	0.21654	0.72
08/31/2025 12:00	0.6	1.2	1	0.46	0.23172	0.77
08/31/2025 13:00	0.7	1.2	2	0.49	0.24612	0.82
08/31/2025 14:00	0.6	1.3	2	0.61	0.30618	1.02
08/31/2025 15:00	0.6	1.3	2	0.61	0.30594	1.02
08/31/2025 16:00	0.6	1.4	2	0.62	0.30828	1.03
08/31/2025 17:00	0.3	1.3	3	0.62	0.30972	1.03
08/31/2025 18:00	0.3	1.4	2	0.60	0.30054	1.00
08/31/2025 19:00	0.2	1.4	3	0.63	0.31578	1.05
08/31/2025 20:00	0.6	1.3	1	0.45	0.22482	0.75
08/31/2025 21:00	0.7	1.3	2	0.44	0.22164	0.74
08/31/2025 22:00	0.6	1.1	2	0.47	0.23718	0.79
08/31/2025 23:00	0.7	1.3	2	0.61	0.30618	1.02
Average/Sum#:	0.6	1.2	2	0.49	0.24637	0.82
Minimum:	0.2	1.0	1	0.43	0.21600	0.72
Maximum:	0.7	1.4	3	0.63	0.31578	1.05
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/01/2025 00:00	0.6	1.3	2	0.62	0.30774	1.03
09/01/2025 01:00	0.7	1.4	2	0.61	0.30630	1.02
09/01/2025 02:00	0.7	1.4	2	0.61	0.30570	1.02
09/01/2025 03:00	0.8	1.3	2	0.61	0.30504	1.02
09/01/2025 04:00	0.8	1.3	2	0.61	0.30498	1.02
09/01/2025 05:00	0.9	1.4	2	0.61	0.30300	1.01
09/01/2025 06:00	0.9	1.4	2	0.58	0.28794	0.96
09/01/2025 07:00	0.7	1.2	2	0.44	0.21846	0.73
09/01/2025 08:00	0.6	1.2	2	0.43	0.21666	0.72
09/01/2025 09:00	0.6	1.1	2	0.43	0.21654	0.72
09/01/2025 10:00	0.7	1.2	1	0.50	0.24840	0.83
09/01/2025 11:00	0.6	1.3	2	0.62	0.31104	1.04
09/01/2025 12:00	0.1	1.4	3	0.66	0.32802	1.09
09/01/2025 13:00	0.0	1.4	4	0.66	0.33126	1.10
09/01/2025 14:00	0.3	1.3	2	0.66	0.32778	1.09
09/01/2025 15:00	0.4	1.3	2	0.63	0.31368	1.05
09/01/2025 16:00	0.2	1.6	3	0.71	0.35394	1.18
09/01/2025 17:00	0.1	1.5	4	0.76	0.37944	1.26
09/01/2025 18:00	0.1	1.5	4	0.77	0.38724	1.29
09/01/2025 19:00	0.1	1.5	4	0.78	0.38844	1.29
09/01/2025 20:00	0.1	1.5	4	0.77	0.38484	1.28
09/01/2025 21:00	0.1	1.5	4	0.76	0.37908	1.26
09/01/2025 22:00	0.2	1.4	3	0.71	0.35520	1.18
09/01/2025 23:00	0.3	1.4	3	0.69	0.34710	1.16
Average/Sum#:	0.4	1.4	3	0.63	0.31699	1.06
Minimum:	0.0	1.1	1	0.43	0.21654	0.72
Maximum:	0.9	1.6	4	0.78	0.38844	1.29
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/02/2025 00:00	0.7	1.3	2	0.61	0.30636	1.02
09/02/2025 01:00	0.6	1.3	2	0.62	0.30864	1.03
09/02/2025 02:00	0.6	1.4	2	0.61	0.30732	1.02
09/02/2025 03:00	0.9	1.4	2	0.61	0.30684	1.02
09/02/2025 04:00	0.4	1.4	3	0.70	0.34920	1.16
09/02/2025 05:00	0.1	1.5	4	0.76	0.38226	1.27
09/02/2025 06:00	0.1	1.4	4	0.73	0.36570	1.22
09/02/2025 07:00	0.1	1.5	4	0.75	0.37446	1.25
09/02/2025 08:00	0.1	1.4	4	0.76	0.37992	1.27
09/02/2025 09:00	0.3	1.4	3	0.69	0.34620	1.15
09/02/2025 10:00	0.4	1.4	2	0.63	0.31488	1.05
09/02/2025 11:00	0.2	1.4	3	0.71	0.35418	1.18
09/02/2025 12:00	0.1	1.4	4	0.76	0.38238	1.27
09/02/2025 13:00	0.1	1.5	3	0.75	0.37668	1.26
09/02/2025 14:00	0.1	1.5	4	0.78	0.38904	1.30
09/02/2025 15:00	0.1	1.5	4	0.78	0.38766	1.29
09/02/2025 16:00	0.1	1.5	4	0.78	0.38874	1.30
09/02/2025 17:00	0.1	1.5	4	0.78	0.38946	1.30
09/02/2025 18:00	0.1	1.5	4	0.78	0.39060	1.30
09/02/2025 19:00	0.1	1.5	4	0.78	0.38892	1.30
09/02/2025 20:00	0.1	1.5	4	0.77	0.38664	1.29
09/02/2025 21:00	0.1	1.5	4	0.77	0.38508	1.28
09/02/2025 22:00	0.1	1.4	4	0.77	0.38406	1.28
09/02/2025 23:00	0.1	1.5	4	0.75	0.37608	1.25
Average/Sum#:	0.2	1.4	3	0.73	0.36339	1.21
Minimum:	0.1	1.3	2	0.61	0.30636	1.02
Maximum:	0.9	1.5	4	0.78	0.39060	1.30
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/03/2025 00:00	0.4	1.4	3	0.68	0.33762	1.13
09/03/2025 01:00	0.7	1.3	2	0.61	0.30282	1.01
09/03/2025 02:00	0.8	1.3	2	0.61	0.30336	1.01
09/03/2025 03:00	0.9	1.3	2	0.60	0.30108	1.00
09/03/2025 04:00	0.4	1.4	3	0.68	0.33786	1.13
09/03/2025 05:00	0.2	1.4	3	0.71	0.35682	1.19
09/03/2025 06:00	0.7	1.4	2	0.63	0.31320	1.04
09/03/2025 07:00	0.9	1.4	2	0.60	0.30162	1.01
09/03/2025 08:00	0.8	1.3	2	0.61	0.30360	1.01
09/03/2025 09:00	0.7	1.3	2	0.61	0.30690	1.02
09/03/2025 10:00	0.5	1.3	2	0.62	0.30984	1.03
09/03/2025 11:00	0.3	1.3	2	0.63	0.31566	1.05
09/03/2025 12:00	0.2	1.4	3	0.67	0.33570	1.12
09/03/2025 13:00	0.4	1.4	2	0.66	0.33006	1.10
09/03/2025 14:00	0.1	1.5	3	0.75	0.37296	1.24
09/03/2025 15:00	0.1	1.5	4	0.77	0.38376	1.28
09/03/2025 16:00	0.1	1.5	4	0.76	0.37764	1.26
09/03/2025 17:00	0.1	1.5	4	0.78	0.38958	1.30
09/03/2025 18:00	0.1	1.5	4	0.77	0.38682	1.29
09/03/2025 19:00	0.1	1.4	3	0.71	0.35652	1.19
09/03/2025 20:00	0.1	1.4	3	0.72	0.36228	1.21
09/03/2025 21:00	0.1	1.5	4	0.75	0.37338	1.24
09/03/2025 22:00	0.2	1.5	3	0.70	0.35058	1.17
09/03/2025 23:00	0.6	1.3	2	0.62	0.30912	1.03
Average/Sum#:	0.4	1.4	3	0.68	0.33828	1.13
Minimum:	0.1	1.3	2	0.60	0.30108	1.00
Maximum:	0.9	1.5	4	0.78	0.38958	1.30
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/04/2025 00:00	0.7	1.3	2	0.61	0.30498	1.02
09/04/2025 01:00	0.7	1.3	2	0.61	0.30432	1.01
09/04/2025 02:00	0.7	1.4	2	0.61	0.30390	1.01
09/04/2025 03:00	0.9	1.3	2	0.60	0.30246	1.01
09/04/2025 04:00	0.5	1.4	3	0.68	0.33930	1.13
09/04/2025 05:00	0.2	1.4	3	0.73	0.36588	1.22
09/04/2025 06:00	0.8	1.3	2	0.62	0.30870	1.03
09/04/2025 07:00	0.9	1.3	2	0.60	0.30192	1.01
09/04/2025 08:00	0.8	1.3	2	0.61	0.30354	1.01
09/04/2025 09:00	0.7	1.3	2	0.61	0.30576	1.02
09/04/2025 10:00	0.6	1.4	2	0.62	0.31146	1.04
09/04/2025 11:00	0.5	1.4	2	0.62	0.31224	1.04
09/04/2025 12:00	0.3	1.4	2	0.64	0.31800	1.06
09/04/2025 13:00	0.2	1.4	2	0.64	0.32106	1.07
09/04/2025 14:00	0.1	1.4	3	0.64	0.32112	1.07
09/04/2025 15:00	0.1	1.3	3	0.64	0.32064	1.07
09/04/2025 16:00	0.2	1.4	3	0.69	0.34452	1.15
09/04/2025 17:00	0.4	1.4	2	0.65	0.32418	1.08
09/04/2025 18:00	0.2	1.4	3	0.70	0.34794	1.16
09/04/2025 19:00	0.2	1.4	3	0.69	0.34692	1.16
09/04/2025 20:00	0.6	1.3	2	0.62	0.31164	1.04
09/04/2025 21:00	0.7	1.3	2	0.62	0.31080	1.04
09/04/2025 22:00	0.8	1.3	2	0.62	0.30966	1.03
09/04/2025 23:00	0.8	1.3	2	0.61	0.30708	1.02
Average/Sum#:	0.5	1.4	2	0.64	0.31867	1.06
Minimum:	0.1	1.3	2	0.60	0.30192	1.01
Maximum:	0.9	1.4	3	0.73	0.36588	1.22
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/05/2025 00:00	0.8	1.4	2	0.61	0.30702	1.02
09/05/2025 01:00	0.9	1.3	2	0.61	0.30672	1.02
09/05/2025 02:00	0.9	1.1	2	0.61	0.30624	1.02
09/05/2025 03:00	1.0	1.4	2	0.61	0.30618	1.02
09/05/2025 04:00	0.9	1.4	2	0.61	0.30624	1.02
09/05/2025 05:00	0.7	1.4	2	0.65	0.32478	1.08
09/05/2025 06:00	0.6	1.3	3	0.65	0.32664	1.09
09/05/2025 07:00	0.9	1.2	2	0.61	0.30618	1.02
09/05/2025 08:00	0.9	1.3	2	0.61	0.30636	1.02
09/05/2025 09:00	0.7	1.3	2	0.62	0.30834	1.03
09/05/2025 10:00	0.7	1.4	2	0.61	0.30678	1.02
09/05/2025 11:00	0.7	1.3	2	0.61	0.30684	1.02
09/05/2025 12:00	0.6	1.3	2	0.62	0.30828	1.03
09/05/2025 13:00	0.5	1.3	2	0.62	0.31074	1.04
09/05/2025 14:00	0.4	1.4	2	0.62	0.31236	1.04
09/05/2025 15:00	0.3	1.4	2	0.63	0.31542	1.05
09/05/2025 16:00	0.3	1.4	3	0.65	0.32328	1.08
09/05/2025 17:00	0.4	1.4	2	0.63	0.31350	1.05
09/05/2025 18:00	0.6	1.3	2	0.62	0.30900	1.03
09/05/2025 19:00	0.6	1.4	2	0.61	0.30618	1.02
09/05/2025 20:00	0.7	1.3	2	0.61	0.30372	1.01
09/05/2025 21:00	0.8	1.4	2	0.60	0.30150	1.01
09/05/2025 22:00	0.9	1.4	2	0.60	0.30054	1.00
09/05/2025 23:00	0.9	1.3	2	0.60	0.29976	1.00
Average/Sum#:	0.7	1.3	2	0.62	0.30928	1.03
Minimum:	0.3	1.1	2	0.60	0.29976	1.00
Maximum:	1.0	1.4	3	0.65	0.32664	1.09
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/06/2025 00:00	1.0	1.3	2	0.60	0.29928	1.00
09/06/2025 01:00	1.0	1.3	2	0.60	0.29886	1.00
09/06/2025 02:00	1.1	1.3	2	0.60	0.29838	0.99
09/06/2025 03:00	1.2	1.2	2	0.60	0.29808	0.99
09/06/2025 04:00	1.1	1.4	2	0.60	0.29796	0.99
09/06/2025 05:00	1.1	1.4	2	0.60	0.29832	0.99
09/06/2025 06:00	1.0	1.3	2	0.53	0.26538	0.88
09/06/2025 07:00	0.7	1.2	2	0.43	0.21672	0.72
09/06/2025 08:00	0.7	1.2	2	0.43	0.21660	0.72
09/06/2025 09:00	0.7	1.2	2	0.43	0.21648	0.72
09/06/2025 10:00	0.7	1.2	2	0.46	0.23226	0.77
09/06/2025 11:00	0.8	1.3	2	0.61	0.30732	1.02
09/06/2025 12:00	0.5	1.3	2	0.62	0.31146	1.04
09/06/2025 13:00	0.7	1.3	2	0.52	0.26064	0.87
09/06/2025 14:00	0.5	1.4	2	0.62	0.31014	1.03
09/06/2025 15:00	0.4	1.3	2	0.62	0.31086	1.04
09/06/2025 16:00	0.4	1.4	2	0.62	0.30996	1.03
09/06/2025 17:00	0.5	1.3	2	0.61	0.30744	1.02
09/06/2025 18:00	0.6	1.3	2	0.61	0.30498	1.02
09/06/2025 19:00	0.7	1.4	2	0.60	0.30204	1.01
09/06/2025 20:00	0.8	1.3	2	0.60	0.30042	1.00
09/06/2025 21:00	0.9	1.3	2	0.60	0.29976	1.00
09/06/2025 22:00	1.0	1.3	2	0.60	0.29880	1.00
09/06/2025 23:00	1.0	1.3	2	0.60	0.29862	1.00
Average/Sum#:	0.8	1.3	2	0.57	0.28587	0.95
Minimum:	0.4	1.2	2	0.43	0.21648	0.72
Maximum:	1.2	1.4	2	0.62	0.31146	1.04
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/07/2025 00:00	1.1	1.3	2	0.60	0.29856	1.00
09/07/2025 01:00	1.1	1.3	2	0.60	0.29808	0.99
09/07/2025 02:00	1.1	1.4	2	0.59	0.29706	0.99
09/07/2025 03:00	1.1	1.3	2	0.59	0.29652	0.99
09/07/2025 04:00	1.1	1.3	2	0.59	0.29646	0.99
09/07/2025 05:00	1.4	1.3	2	0.59	0.29646	0.99
09/07/2025 06:00	1.1	1.3	2	0.53	0.26526	0.88
09/07/2025 07:00	0.8	1.2	2	0.43	0.21702	0.72
09/07/2025 08:00	0.7	1.2	2	0.43	0.21678	0.72
09/07/2025 09:00	0.7	1.2	3	0.43	0.21666	0.72
09/07/2025 10:00	0.7	1.2	2	0.43	0.21642	0.72
09/07/2025 11:00	0.6	1.2	2	0.43	0.21648	0.72
09/07/2025 12:00	0.7	1.3	1	0.49	0.24480	0.82
09/07/2025 13:00	0.5	1.3	2	0.62	0.30966	1.03
09/07/2025 14:00	0.5	1.3	2	0.62	0.31092	1.04
09/07/2025 15:00	0.4	1.4	2	0.62	0.31224	1.04
09/07/2025 16:00	0.3	1.4	3	0.66	0.32976	1.10
09/07/2025 17:00	0.3	1.4	3	0.70	0.35094	1.17
09/07/2025 18:00	0.5	1.3	2	0.62	0.31158	1.04
09/07/2025 19:00	0.6	1.3	2	0.61	0.30600	1.02
09/07/2025 20:00	0.7	1.4	2	0.61	0.30450	1.02
09/07/2025 21:00	0.7	1.3	2	0.61	0.30324	1.01
09/07/2025 22:00	0.8	1.3	2	0.60	0.30054	1.00
09/07/2025 23:00	0.9	1.4	2	0.60	0.30024	1.00
Average/Sum#:	0.8	1.3	2	0.57	0.28401	0.95
Minimum:	0.3	1.2	1	0.43	0.21642	0.72
Maximum:	1.4	1.4	3	0.70	0.35094	1.17
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/08/2025 00:00	1.0	1.3	2	0.60	0.29862	1.00
09/08/2025 01:00	1.0	1.3	2	0.60	0.29802	0.99
09/08/2025 02:00	1.0	1.3	2	0.60	0.29808	0.99
09/08/2025 03:00	1.1	1.4	2	0.60	0.29814	0.99
09/08/2025 04:00	1.1	1.4	2	0.60	0.29772	0.99
09/08/2025 05:00	0.8	1.3	2	0.63	0.31566	1.05
09/08/2025 06:00	1.1	1.3	2	0.59	0.29730	0.99
09/08/2025 07:00	1.0	1.3	2	0.60	0.29916	1.00
09/08/2025 08:00	0.9	1.3	2	0.57	0.28596	0.95
09/08/2025 09:00	0.7	1.3	2	0.44	0.21780	0.73
09/08/2025 10:00	0.6	1.1	2	0.43	0.21636	0.72
09/08/2025 11:00	0.6	1.3	2	0.43	0.21678	0.72
09/08/2025 12:00	0.6	1.2	2	0.43	0.21678	0.72
09/08/2025 13:00	0.6	1.2	2	0.46	0.23040	0.77
09/08/2025 14:00	0.7	1.4	2	0.61	0.30456	1.02
09/08/2025 15:00	0.5	1.4	2	0.62	0.30882	1.03
09/08/2025 16:00	0.4	1.4	2	0.65	0.32358	1.08
09/08/2025 17:00	0.2	1.4	3	0.71	0.35436	1.18
09/08/2025 18:00	0.6	1.3	2	0.63	0.31524	1.05
09/08/2025 19:00	0.7	1.3	2	0.61	0.30690	1.02
09/08/2025 20:00	0.7	1.3	2	0.61	0.30384	1.01
09/08/2025 21:00	0.7	1.3	2	0.62	0.30912	1.03
09/08/2025 22:00	0.6	1.4	2	0.64	0.31986	1.07
09/08/2025 23:00	0.9	1.4	2	0.60	0.30114	1.00
Average/Sum#:	0.8	1.3	2	0.58	0.28893	0.96
Minimum:	0.2	1.1	2	0.43	0.21636	0.72
Maximum:	1.1	1.4	3	0.71	0.35436	1.18
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/09/2025 00:00	0.9	1.4	2	0.60	0.30120	1.00
09/09/2025 01:00	0.9	1.3	2	0.60	0.30150	1.01
09/09/2025 02:00	0.9	1.3	2	0.60	0.30138	1.00
09/09/2025 03:00	1.0	1.4	2	0.60	0.30150	1.01
09/09/2025 04:00	1.0	1.4	2	0.60	0.30072	1.00
09/09/2025 05:00	0.5	1.4	3	0.67	0.33654	1.12
09/09/2025 06:00	0.9	1.3	2	0.57	0.28674	0.96
09/09/2025 07:00	0.9	1.4	2	0.54	0.27144	0.90
09/09/2025 08:00	0.9	1.4	2	0.60	0.30078	1.00
09/09/2025 09:00	0.8	1.3	2	0.60	0.30222	1.01
09/09/2025 10:00	0.8	1.4	2	0.60	0.30246	1.01
09/09/2025 11:00	0.7	1.4	2	0.61	0.30342	1.01
09/09/2025 12:00	0.8	1.3	2	0.53	0.26304	0.88
09/09/2025 13:00	0.7	1.4	2	0.61	0.30474	1.02
09/09/2025 14:00	0.6	1.3	2	0.61	0.30510	1.02
09/09/2025 15:00	0.6	1.4	2	0.61	0.30474	1.02
09/09/2025 16:00	0.6	1.3	2	0.61	0.30438	1.01
09/09/2025 17:00	0.7	1.3	2	0.61	0.30330	1.01
09/09/2025 18:00	0.8	1.3	2	0.60	0.30216	1.01
09/09/2025 19:00	0.8	1.4	2	0.60	0.30150	1.01
09/09/2025 20:00	0.9	1.3	2	0.60	0.30078	1.00
09/09/2025 21:00	0.9	1.3	2	0.60	0.30060	1.00
09/09/2025 22:00	0.9	1.3	2	0.60	0.30006	1.00
09/09/2025 23:00	1.0	1.3	2	0.60	0.29958	1.00
Average/Sum#:	0.8	1.3	2	0.60	0.30000	1.00
Minimum:	0.5	1.3	2	0.53	0.26304	0.88
Maximum:	1.0	1.4	3	0.67	0.33654	1.12
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/10/2025 00:00	1.0	1.3	2	0.60	0.29892	1.00
09/10/2025 01:00	1.1	1.4	2	0.60	0.29850	1.00
09/10/2025 02:00	1.1	1.3	2	0.60	0.29832	0.99
09/10/2025 03:00	1.1	1.4	2	0.60	0.29826	0.99
09/10/2025 04:00	1.0	1.3	2	0.60	0.29838	0.99
09/10/2025 05:00	1.0	1.3	2	0.60	0.29940	1.00
09/10/2025 06:00	1.0	1.3	2	0.60	0.30186	1.01
09/10/2025 07:00	1.0	1.3	2	0.53	0.26418	0.88
09/10/2025 08:00	0.8	1.2	2	0.49	0.24660	0.82
09/10/2025 09:00	0.9	1.4	2	0.60	0.29982	1.00
09/10/2025 10:00	0.8	1.3	2	0.46	0.22800	0.76
09/10/2025 11:00	0.7	1.2	2	0.43	0.21576	0.72
09/10/2025 12:00	0.6	1.2	2	0.43	0.21552	0.72
09/10/2025 13:00	0.6	1.2	2	0.43	0.21516	0.72
09/10/2025 14:00	0.6	1.2	2	0.46	0.22998	0.77
09/10/2025 15:00	0.8	1.2	2	0.60	0.30114	1.00
09/10/2025 16:00	0.7	1.3	2	0.61	0.30528	1.02
09/10/2025 17:00	0.7	1.3	2	0.60	0.30246	1.01
09/10/2025 18:00	0.7	1.3	2	0.60	0.30138	1.00
09/10/2025 19:00	0.8	1.4	2	0.60	0.30012	1.00
09/10/2025 20:00	0.9	1.3	2	0.60	0.29814	0.99
09/10/2025 21:00	1.0	1.4	2	0.59	0.29712	0.99
09/10/2025 22:00	1.0	1.3	2	0.59	0.29664	0.99
09/10/2025 23:00	1.0	1.4	2	0.59	0.29604	0.99
Average/Sum#:	0.9	1.3	2	0.56	0.27946	0.93
Minimum:	0.6	1.2	2	0.43	0.21516	0.72
Maximum:	1.1	1.4	2	0.61	0.30528	1.02
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/11/2025 00:00	1.0	1.3	2	0.59	0.29556	0.99
09/11/2025 01:00	1.1	1.3	2	0.59	0.29544	0.98
09/11/2025 02:00	1.1	1.3	2	0.59	0.29514	0.98
09/11/2025 03:00	1.1	1.3	2	0.59	0.29538	0.98
09/11/2025 04:00	1.0	1.4	2	0.59	0.29514	0.98
09/11/2025 05:00	1.0	1.3	2	0.59	0.29454	0.98
09/11/2025 06:00	1.0	1.4	2	0.59	0.29442	0.98
09/11/2025 07:00	1.0	1.3	2	0.59	0.29556	0.99
09/11/2025 08:00	1.1	1.3	2	0.59	0.29634	0.99
09/11/2025 09:00	0.9	1.4	2	0.60	0.29850	1.00
09/11/2025 10:00	0.8	1.3	2	0.61	0.30372	1.01
09/11/2025 11:00	0.8	1.3	2	0.57	0.28584	0.95
09/11/2025 12:00	0.8	1.2	2	0.49	0.24600	0.82
09/11/2025 13:00	0.6	1.3	2	0.61	0.30642	1.02
09/11/2025 14:00	0.6	1.4	2	0.62	0.30870	1.03
09/11/2025 15:00	0.5	1.3	2	0.62	0.30990	1.03
09/11/2025 16:00	0.6	1.3	2	0.62	0.30804	1.03
09/11/2025 17:00	0.6	1.4	2	0.61	0.30606	1.02
09/11/2025 18:00	0.6	1.3	2	0.61	0.30432	1.01
09/11/2025 19:00	0.7	1.3	2	0.61	0.30288	1.01
09/11/2025 20:00	0.8	1.3	2	0.59	0.29616	0.99
09/11/2025 21:00	1.0	1.3	2	0.58	0.29226	0.97
09/11/2025 22:00	0.9	1.3	2	0.60	0.29928	1.00
09/11/2025 23:00	0.9	1.4	2	0.60	0.29922	1.00
Average/Sum#:	0.9	1.3	2	0.59	0.29687	0.99
Minimum:	0.5	1.2	2	0.49	0.24600	0.82
Maximum:	1.1	1.4	2	0.62	0.30990	1.03
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/12/2025 00:00	1.0	1.3	2	0.60	0.29862	1.00
09/12/2025 01:00	1.0	1.3	2	0.60	0.29790	0.99
09/12/2025 02:00	1.1	1.3	2	0.59	0.29742	0.99
09/12/2025 03:00	1.2	1.2	2	0.59	0.29646	0.99
09/12/2025 04:00	1.1	1.4	2	0.59	0.29652	0.99
09/12/2025 05:00	1.1	1.3	2	0.59	0.29610	0.99
09/12/2025 06:00	1.1	1.4	2	0.59	0.29592	0.99
09/12/2025 07:00	1.0	1.2	2	0.53	0.26352	0.88
09/12/2025 08:00	0.9	1.3	2	0.49	0.24600	0.82
09/12/2025 09:00	0.9	1.3	2	0.60	0.30102	1.00
09/12/2025 10:00	0.8	1.3	2	0.49	0.24312	0.81
09/12/2025 11:00	0.7	1.2	2	0.43	0.21558	0.72
09/12/2025 12:00	0.7	1.2	2	0.43	0.21546	0.72
09/12/2025 13:00	0.6	1.2	2	0.44	0.21840	0.73
09/12/2025 14:00	0.6	1.3	2	0.58	0.28962	0.97
09/12/2025 15:00	0.4	1.3	2	0.62	0.31146	1.04
09/12/2025 16:00	0.4	1.4	2	0.63	0.31278	1.04
09/12/2025 17:00	0.4	1.4	2	0.62	0.31212	1.04
09/12/2025 18:00	0.5	1.3	2	0.61	0.30690	1.02
09/12/2025 19:00	0.6	1.4	2	0.61	0.30456	1.02
09/12/2025 20:00	0.7	1.3	2	0.61	0.30300	1.01
09/12/2025 21:00	0.7	1.4	2	0.60	0.30186	1.01
09/12/2025 22:00	0.8	1.3	2	0.60	0.30054	1.00
09/12/2025 23:00	0.9	1.3	2	0.60	0.29934	1.00
Average/Sum#:	0.8	1.3	2	0.57	0.28434	0.95
Minimum:	0.4	1.2	2	0.43	0.21546	0.72
Maximum:	1.2	1.4	2	0.63	0.31278	1.04
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/13/2025 00:00	1.0	1.3	2	0.60	0.29850	1.00
09/13/2025 01:00	1.0	1.3	2	0.60	0.29778	0.99
09/13/2025 02:00	1.1	1.3	2	0.59	0.29700	0.99
09/13/2025 03:00	1.2	1.3	2	0.59	0.29622	0.99
09/13/2025 04:00	1.1	1.3	2	0.59	0.29598	0.99
09/13/2025 05:00	1.1	1.3	2	0.59	0.29628	0.99
09/13/2025 06:00	1.1	1.2	2	0.57	0.28326	0.94
09/13/2025 07:00	0.7	1.2	2	0.43	0.21732	0.72
09/13/2025 08:00	0.7	1.2	2	0.43	0.21714	0.72
09/13/2025 09:00	0.7	1.3	2	0.43	0.21672	0.72
09/13/2025 10:00	0.7	1.2	2	0.43	0.21654	0.72
09/13/2025 11:00	0.6	1.1	2	0.43	0.21666	0.72
09/13/2025 12:00	0.6	1.3	2	0.43	0.21630	0.72
09/13/2025 13:00	0.6	1.2	2	0.43	0.21588	0.72
09/13/2025 14:00	0.6	1.2	2	0.43	0.21576	0.72
09/13/2025 15:00	0.6	1.2	2	0.43	0.21570	0.72
09/13/2025 16:00	0.7	1.2	2	0.49	0.24534	0.82
09/13/2025 17:00	0.4	1.3	2	0.62	0.31146	1.04
09/13/2025 18:00	0.6	1.3	2	0.62	0.30768	1.03
09/13/2025 19:00	0.7	1.3	2	0.61	0.30432	1.01
09/13/2025 20:00	0.7	1.3	2	0.60	0.30216	1.01
09/13/2025 21:00	0.9	1.3	2	0.60	0.30054	1.00
09/13/2025 22:00	0.9	1.4	2	0.60	0.29928	1.00
09/13/2025 23:00	1.0	1.3	2	0.60	0.29886	1.00
Average/Sum#:	0.8	1.3	2	0.53	0.26595	0.89
Minimum:	0.4	1.1	2	0.43	0.21570	0.72
Maximum:	1.2	1.4	2	0.62	0.31146	1.04
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 **To:** 09/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/14/2025 00:00	1.0	1.3	2	0.60	0.29838	0.99
09/14/2025 01:00	1.1	1.3	2	0.60	0.29868	1.00
09/14/2025 02:00	1.2	1.4	2	0.60	0.29832	0.99
09/14/2025 03:00	1.2	1.3	2	0.60	0.29814	0.99
09/14/2025 04:00	1.2	1.4	2	0.60	0.29772	0.99
09/14/2025 05:00	1.1	1.3	2	0.59	0.29736	0.99
09/14/2025 06:00	1.0	1.2	2	0.52	0.26238	0.87
09/14/2025 07:00	0.7	1.2	2	0.43	0.21708	0.72
09/14/2025 08:00	0.7	1.2	2	0.43	0.21666	0.72
09/14/2025 09:00	0.6	1.3	2	0.43	0.21648	0.72
09/14/2025 10:00	0.6	1.2	2	0.43	0.21654	0.72
09/14/2025 11:00	0.6	1.3	2	0.44	0.21756	0.73
09/14/2025 12:00	0.6	1.1	2	0.43	0.21660	0.72
09/14/2025 13:00	0.6	1.2	2	0.43	0.21582	0.72
09/14/2025 14:00	0.6	1.3	2	0.43	0.21570	0.72
09/14/2025 15:00	0.6	1.2	2	0.43	0.21540	0.72
09/14/2025 16:00	0.7	1.3	2	0.49	0.24474	0.82
09/14/2025 17:00	0.4	1.4	2	0.62	0.31230	1.04
09/14/2025 18:00	0.5	1.4	2	0.62	0.30792	1.03
09/14/2025 19:00	0.6	1.3	2	0.61	0.30546	1.02
09/14/2025 20:00	0.7	1.4	2	0.61	0.30390	1.01
09/14/2025 21:00	0.7	1.3	2	0.61	0.30378	1.01
09/14/2025 22:00	0.8	1.3	2	0.60	0.30228	1.01
09/14/2025 23:00	0.9	1.3	2	0.60	0.30174	1.01
Average/Sum#:	0.8	1.3	2	0.53	0.26587	0.89
Minimum:	0.4	1.1	2	0.43	0.21540	0.72
Maximum:	1.2	1.4	2	0.62	0.31230	1.04
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/15/2025 00:00	0.9	1.4	2	0.60	0.30060	1.00
09/15/2025 01:00	1.0	1.3	2	0.60	0.30006	1.00
09/15/2025 02:00	1.0	1.2	2	0.60	0.29898	1.00
09/15/2025 03:00	1.2	1.3	2	0.60	0.29850	1.00
09/15/2025 04:00	1.2	1.3	2	0.60	0.29808	0.99
09/15/2025 05:00	1.2	1.4	2	0.59	0.29712	0.99
09/15/2025 06:00	1.6	1.3	2	0.59	0.29652	0.99
09/15/2025 07:00	1.3	1.3	2	0.60	0.29826	0.99
09/15/2025 08:00	0.9	1.4	2	0.60	0.30102	1.00
09/15/2025 09:00	0.7	1.3	2	0.61	0.30282	1.01
09/15/2025 10:00	0.8	1.2	2	0.52	0.26148	0.87
09/15/2025 11:00	0.6	1.3	2	0.62	0.30984	1.03
09/15/2025 12:00	0.4	1.4	2	0.63	0.31338	1.04
09/15/2025 13:00	0.2	1.4	2	0.63	0.31716	1.06
09/15/2025 14:00	0.1	1.4	3	0.71	0.35484	1.18
09/15/2025 15:00	0.3	1.4	3	0.66	0.33066	1.10
09/15/2025 16:00	0.1	1.4	3	0.68	0.33792	1.13
09/15/2025 17:00	0.6	1.3	2	0.62	0.31014	1.03
09/15/2025 18:00	0.6	1.3	2	0.62	0.31110	1.04
09/15/2025 19:00	0.9	1.3	2	0.60	0.30030	1.00
09/15/2025 20:00	1.0	1.3	2	0.60	0.29952	1.00
09/15/2025 21:00	1.1	1.4	2	0.60	0.29898	1.00
09/15/2025 22:00	1.2	1.3	2	0.60	0.29826	0.99
09/15/2025 23:00	1.2	1.3	2	0.60	0.29826	0.99
Average/Sum#:	0.8	1.3	2	0.61	0.30558	1.02
Minimum:	0.1	1.2	2	0.52	0.26148	0.87
Maximum:	1.6	1.4	3	0.71	0.35484	1.18
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/16/2025 00:00	1.4	1.4	2	0.60	0.29826	0.99
09/16/2025 01:00	1.2	1.3	2	0.60	0.29898	1.00
09/16/2025 02:00	1.2	1.4	2	0.60	0.29874	1.00
09/16/2025 03:00	1.2	1.3	2	0.60	0.29760	0.99
09/16/2025 04:00	1.3	1.3	2	0.59	0.29676	0.99
09/16/2025 05:00	1.3	1.3	2	0.60	0.29832	0.99
09/16/2025 06:00	1.3	1.3	2	0.60	0.29886	1.00
09/16/2025 07:00	1.1	1.3	2	0.60	0.30096	1.00
09/16/2025 08:00	0.8	1.3	2	0.61	0.30324	1.01
09/16/2025 09:00	0.6	1.4	2	0.61	0.30726	1.02
09/16/2025 10:00	0.5	1.4	2	0.62	0.31140	1.04
09/16/2025 11:00	0.3	1.3	3	0.63	0.31566	1.05
09/16/2025 12:00	0.1	1.4	3	0.64	0.31932	1.06
09/16/2025 13:00	0.1	1.4	3	0.64	0.32226	1.07
09/16/2025 14:00	0.1	1.4	3	0.65	0.32382	1.08
09/16/2025 15:00	0.5	1.3	2	0.62	0.30846	1.03
09/16/2025 16:00	0.5	1.3	2	0.62	0.31080	1.04
09/16/2025 17:00	0.6	1.3	2	0.61	0.30492	1.02
09/16/2025 18:00	0.7	1.3	2	0.61	0.30498	1.02
09/16/2025 19:00	0.6	1.3	2	0.62	0.30840	1.03
09/16/2025 20:00	0.5	1.4	2	0.62	0.31248	1.04
09/16/2025 21:00	0.7	1.3	2	0.62	0.30834	1.03
09/16/2025 22:00	0.7	1.3	2	0.61	0.30468	1.02
09/16/2025 23:00	0.7	1.3	2	0.61	0.30534	1.02
Average/Sum#:	0.8	1.3	2	0.61	0.30666	1.02
Minimum:	0.1	1.3	2	0.59	0.29676	0.99
Maximum:	1.4	1.4	3	0.65	0.32382	1.08
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/17/2025 00:00	0.8	1.3	2	0.61	0.30450	1.02
09/17/2025 01:00	0.8	1.3	2	0.61	0.30408	1.01
09/17/2025 02:00	0.8	1.4	2	0.61	0.30276	1.01
09/17/2025 03:00	0.9	1.3	2	0.60	0.30240	1.01
09/17/2025 04:00	1.0	1.4	2	0.60	0.30084	1.00
09/17/2025 05:00	1.3	1.3	2	0.60	0.29946	1.00
09/17/2025 06:00	1.4	1.4	2	0.60	0.29826	0.99
09/17/2025 07:00	1.1	1.3	2	0.60	0.30066	1.00
09/17/2025 08:00	0.7	1.3	2	0.61	0.30504	1.02
09/17/2025 09:00	0.6	1.3	2	0.62	0.30834	1.03
09/17/2025 10:00	0.4	1.4	3	0.63	0.31380	1.05
09/17/2025 11:00	0.2	1.4	3	0.64	0.31812	1.06
09/17/2025 12:00	0.1	1.4	3	0.65	0.32292	1.08
09/17/2025 13:00	0.1	1.4	3	0.65	0.32694	1.09
09/17/2025 14:00	0.5	1.3	2	0.63	0.31482	1.05
09/17/2025 15:00	0.5	1.3	2	0.62	0.31200	1.04
09/17/2025 16:00	0.6	1.3	2	0.61	0.30396	1.01
09/17/2025 17:00	0.1	1.4	3	0.64	0.32244	1.07
09/17/2025 18:00	0.1	1.4	3	0.64	0.32070	1.07
09/17/2025 19:00	0.1	1.4	3	0.63	0.31566	1.05
09/17/2025 20:00	0.3	1.4	3	0.62	0.31200	1.04
09/17/2025 21:00	0.5	1.4	3	0.62	0.31074	1.04
09/17/2025 22:00	0.6	1.3	2	0.62	0.30762	1.03
09/17/2025 23:00	0.6	1.3	3	0.61	0.30576	1.02
Average/Sum#:	0.6	1.4	2	0.62	0.30974	1.03
Minimum:	0.1	1.3	2	0.60	0.29826	0.99
Maximum:	1.4	1.4	3	0.65	0.32694	1.09
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/18/2025 00:00	0.6	1.4	2	0.61	0.30378	1.01
09/18/2025 01:00	0.7	1.3	2	0.61	0.30264	1.01
09/18/2025 02:00	0.7	1.4	2	0.61	0.30252	1.01
09/18/2025 03:00	0.8	1.4	2	0.60	0.30162	1.01
09/18/2025 04:00	0.8	1.3	2	0.60	0.30114	1.00
09/18/2025 05:00	1.0	1.3	2	0.60	0.30078	1.00
09/18/2025 06:00	1.4	1.4	2	0.61	0.30402	1.01
09/18/2025 07:00	0.5	1.4	3	0.66	0.32826	1.09
09/18/2025 08:00	0.7	1.3	2	0.61	0.30462	1.02
09/18/2025 09:00	0.5	1.3	3	0.63	0.31266	1.04
09/18/2025 10:00	0.5	1.4	3	0.62	0.31128	1.04
09/18/2025 11:00	0.4	1.3	3	0.63	0.31350	1.05
09/18/2025 12:00	0.2	1.4	3	0.63	0.31476	1.05
09/18/2025 13:00	0.1	1.4	3	0.65	0.32310	1.08
09/18/2025 14:00	0.2	1.4	3	0.63	0.31572	1.05
09/18/2025 15:00	0.2	1.4	3	0.66	0.32946	1.10
09/18/2025 16:00	0.4	1.3	3	0.62	0.31068	1.04
09/18/2025 17:00	0.4	1.4	2	0.62	0.31002	1.03
09/18/2025 18:00	0.6	1.4	2	0.61	0.30624	1.02
09/18/2025 19:00	0.6	1.4	2	0.61	0.30552	1.02
09/18/2025 20:00	0.6	1.3	2	0.61	0.30498	1.02
09/18/2025 21:00	0.6	1.3	2	0.61	0.30420	1.01
09/18/2025 22:00	0.7	1.4	2	0.61	0.30366	1.01
09/18/2025 23:00	0.7	1.3	2	0.61	0.30342	1.01
Average/Sum#:	0.6	1.4	2	0.62	0.30911	1.03
Minimum:	0.1	1.3	2	0.60	0.30078	1.00
Maximum:	1.4	1.4	3	0.66	0.32946	1.10
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 **To:** 09/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/19/2025 00:00	0.7	1.3	2	0.61	0.30306	1.01
09/19/2025 01:00	0.8	1.2	2	0.61	0.30348	1.01
09/19/2025 02:00	0.8	1.3	2	0.61	0.30342	1.01
09/19/2025 03:00	0.9	1.3	2	0.61	0.30348	1.01
09/19/2025 04:00	0.9	1.3	2	0.61	0.30372	1.01
09/19/2025 05:00	1.0	1.4	2	0.61	0.30288	1.01
09/19/2025 06:00	0.8	1.4	2	0.62	0.30852	1.03
09/19/2025 07:00	1.1	1.4	2	0.60	0.30168	1.01
09/19/2025 08:00	1.0	1.2	2	0.60	0.30210	1.01
09/19/2025 09:00	1.0	1.3	2	0.61	0.30276	1.01
09/19/2025 10:00	0.9	1.4	2	0.61	0.30306	1.01
09/19/2025 11:00	0.8	1.3	2	0.61	0.30360	1.01
09/19/2025 12:00	0.9	1.4	2	0.61	0.30372	1.01
09/19/2025 13:00	0.8	1.4	2	0.61	0.30594	1.02
09/19/2025 14:00	0.6	1.3	2	0.62	0.31248	1.04
09/19/2025 15:00	0.6	1.3	2	0.62	0.30756	1.03
09/19/2025 16:00	0.6	1.4	2	0.62	0.30930	1.03
09/19/2025 17:00	0.6	1.3	2	0.61	0.30702	1.02
09/19/2025 18:00	0.7	1.4	2	0.61	0.30636	1.02
09/19/2025 19:00	0.8	1.3	2	0.61	0.30522	1.02
09/19/2025 20:00	0.7	1.3	2	0.62	0.31164	1.04
09/19/2025 21:00	0.3	1.4	3	0.70	0.34944	1.16
09/19/2025 22:00	0.7	1.4	2	0.64	0.31782	1.06
09/19/2025 23:00	1.0	1.3	2	0.61	0.30360	1.01
Average/Sum#:	0.8	1.3	2	0.62	0.30758	1.03
Minimum:	0.3	1.2	2	0.60	0.30168	1.01
Maximum:	1.1	1.4	3	0.70	0.34944	1.16
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/20/2025 00:00	1.0	1.3	2	0.61	0.30312	1.01
09/20/2025 01:00	1.1	1.3	2	0.60	0.30222	1.01
09/20/2025 02:00	1.2	1.5	2	0.60	0.30204	1.01
09/20/2025 03:00	1.2	1.2	2	0.60	0.30150	1.01
09/20/2025 04:00	1.3	1.4	2	0.60	0.30054	1.00
09/20/2025 05:00	1.3	1.3	2	0.60	0.29976	1.00
09/20/2025 06:00	1.3	1.2	2	0.60	0.29904	1.00
09/20/2025 07:00	1.2	1.3	2	0.60	0.30066	1.00
09/20/2025 08:00	1.1	1.3	2	0.60	0.30192	1.01
09/20/2025 09:00	0.8	1.3	2	0.61	0.30456	1.02
09/20/2025 10:00	0.6	1.3	2	0.61	0.30702	1.02
09/20/2025 11:00	0.6	1.4	2	0.62	0.30882	1.03
09/20/2025 12:00	0.5	1.4	2	0.62	0.31182	1.04
09/20/2025 13:00	0.5	1.3	2	0.62	0.31194	1.04
09/20/2025 14:00	0.4	1.4	2	0.63	0.31380	1.05
09/20/2025 15:00	0.4	1.3	3	0.63	0.31482	1.05
09/20/2025 16:00	0.3	1.4	3	0.67	0.33432	1.11
09/20/2025 17:00	0.5	1.4	2	0.63	0.31488	1.05
09/20/2025 18:00	0.5	1.3	2	0.62	0.31164	1.04
09/20/2025 19:00	0.6	1.3	2	0.61	0.30600	1.02
09/20/2025 20:00	0.7	1.3	2	0.61	0.30384	1.01
09/20/2025 21:00	0.7	1.3	2	0.61	0.30390	1.01
09/20/2025 22:00	0.8	1.3	2	0.61	0.30456	1.02
09/20/2025 23:00	0.9	1.3	2	0.60	0.30114	1.00
Average/Sum#:	0.8	1.3	2	0.61	0.30683	1.02
Minimum:	0.3	1.2	2	0.60	0.29904	1.00
Maximum:	1.3	1.5	3	0.67	0.33432	1.11
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/21/2025 00:00	1.0	1.4	2	0.60	0.30060	1.00
09/21/2025 01:00	1.0	1.2	2	0.60	0.30042	1.00
09/21/2025 02:00	1.0	1.3	2	0.60	0.30030	1.00
09/21/2025 03:00	1.2	1.2	2	0.60	0.30012	1.00
09/21/2025 04:00	1.2	1.3	2	0.60	0.29970	1.00
09/21/2025 05:00	1.2	1.2	2	0.60	0.29910	1.00
09/21/2025 06:00	1.2	1.3	2	0.60	0.29892	1.00
09/21/2025 07:00	1.0	1.3	2	0.60	0.30054	1.00
09/21/2025 08:00	0.9	1.3	2	0.60	0.30234	1.01
09/21/2025 09:00	0.7	1.3	2	0.61	0.30426	1.01
09/21/2025 10:00	0.6	1.3	2	0.61	0.30690	1.02
09/21/2025 11:00	0.5	1.4	2	0.62	0.31218	1.04
09/21/2025 12:00	0.3	1.3	3	0.63	0.31632	1.05
09/21/2025 13:00	0.2	1.4	2	0.63	0.31740	1.06
09/21/2025 14:00	0.2	1.3	3	0.64	0.31872	1.06
09/21/2025 15:00	0.1	1.4	3	0.64	0.31956	1.07
09/21/2025 16:00	0.1	1.4	3	0.64	0.32028	1.07
09/21/2025 17:00	0.2	1.3	3	0.64	0.31830	1.06
09/21/2025 18:00	0.3	1.4	3	0.63	0.31362	1.05
09/21/2025 19:00	0.5	1.4	2	0.62	0.30858	1.03
09/21/2025 20:00	0.6	1.4	2	0.61	0.30708	1.02
09/21/2025 21:00	0.6	1.3	2	0.61	0.30642	1.02
09/21/2025 22:00	0.6	1.4	2	0.61	0.30552	1.02
09/21/2025 23:00	0.7	1.3	2	0.61	0.30402	1.01
Average/Sum#:	0.7	1.3	2	0.61	0.30755	1.03
Minimum:	0.1	1.2	2	0.60	0.29892	1.00
Maximum:	1.2	1.4	3	0.64	0.32028	1.07
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/22/2025 00:00	0.8	1.3	2	0.61	0.30306	1.01
09/22/2025 01:00	0.8	1.3	2	0.60	0.30222	1.01
09/22/2025 02:00	0.9	1.2	2	0.60	0.30168	1.01
09/22/2025 03:00	1.0	1.4	2	0.60	0.30156	1.01
09/22/2025 04:00	1.0	1.4	2	0.60	0.30042	1.00
09/22/2025 05:00	1.2	1.3	2	0.60	0.29898	1.00
09/22/2025 06:00	1.3	1.3	2	0.60	0.29874	1.00
09/22/2025 07:00	1.0	1.4	2	0.60	0.30174	1.01
09/22/2025 08:00	0.7	1.4	2	0.61	0.30468	1.02
09/22/2025 09:00	0.6	1.3	2	0.61	0.30690	1.02
09/22/2025 10:00	0.8	1.3	2	0.48	0.23910	0.80
09/22/2025 11:00	0.8	1.2	2	0.43	0.21480	0.72
09/22/2025 12:00	0.8	1.1	2	0.49	0.24408	0.81
09/22/2025 13:00	0.7	1.4	2	0.61	0.30528	1.02
09/22/2025 14:00	0.2	1.4	3	0.64	0.32034	1.07
09/22/2025 15:00	0.1	1.4	3	0.64	0.32208	1.07
09/22/2025 16:00	0.1	1.5	3	0.66	0.33132	1.10
09/22/2025 17:00	0.5	1.4	2	0.62	0.31176	1.04
09/22/2025 18:00	0.6	1.3	2	0.61	0.30504	1.02
09/22/2025 19:00	0.7	1.3	2	0.61	0.30360	1.01
09/22/2025 20:00	0.8	1.3	2	0.60	0.30234	1.01
09/22/2025 21:00	0.9	1.4	2	0.61	0.30252	1.01
09/22/2025 22:00	1.0	1.3	2	0.60	0.30162	1.01
09/22/2025 23:00	1.0	1.3	2	0.60	0.30108	1.00
Average/Sum#:	0.8	1.3	2	0.59	0.29687	0.99
Minimum:	0.1	1.1	2	0.43	0.21480	0.72
Maximum:	1.3	1.5	3	0.66	0.33132	1.10
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/23/2025 00:00	1.0	1.3	2	0.60	0.29994	1.00
09/23/2025 01:00	1.1	1.4	2	0.60	0.29940	1.00
09/23/2025 02:00	1.1	1.5	2	0.60	0.29916	1.00
09/23/2025 03:00	1.1	1.2	2	0.60	0.29964	1.00
09/23/2025 04:00	1.2	1.3	2	0.60	0.29922	1.00
09/23/2025 05:00	1.0	1.3	2	0.60	0.30246	1.01
09/23/2025 06:00	1.4	1.3	2	0.60	0.30150	1.01
09/23/2025 07:00	1.1	1.3	2	0.61	0.30408	1.01
09/23/2025 08:00	0.7	1.3	2	0.61	0.30690	1.02
09/23/2025 09:00	0.6	1.4	2	0.62	0.31062	1.04
09/23/2025 10:00	0.4	1.3	3	0.63	0.31524	1.05
09/23/2025 11:00	0.2	1.4	3	0.64	0.31974	1.07
09/23/2025 12:00	0.1	1.4	3	0.65	0.32442	1.08
09/23/2025 13:00	0.5	1.2	2	0.62	0.30798	1.03
09/23/2025 14:00	0.6	1.3	2	0.61	0.30672	1.02
09/23/2025 15:00	0.5	1.3	2	0.63	0.31344	1.04
09/23/2025 16:00	0.5	1.4	2	0.64	0.32022	1.07
09/23/2025 17:00	0.2	1.4	3	0.71	0.35658	1.19
09/23/2025 18:00	0.4	1.4	3	0.68	0.33912	1.13
09/23/2025 19:00	0.2	1.4	3	0.64	0.32118	1.07
09/23/2025 20:00	0.4	1.4	3	0.63	0.31632	1.05
09/23/2025 21:00	0.6	1.4	2	0.62	0.31146	1.04
09/23/2025 22:00	0.8	1.4	2	0.61	0.30594	1.02
09/23/2025 23:00	0.8	1.4	2	0.61	0.30492	1.02
Average/Sum#:	0.7	1.4	2	0.62	0.31193	1.04
Minimum:	0.1	1.2	2	0.60	0.29916	1.00
Maximum:	1.4	1.5	3	0.71	0.35658	1.19
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 **To:** 09/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/24/2025 00:00	0.9	1.3	2	0.61	0.30444	1.01
09/24/2025 01:00	0.9	1.3	2	0.61	0.30342	1.01
09/24/2025 02:00	0.9	1.4	2	0.60	0.30210	1.01
09/24/2025 03:00	1.0	1.4	2	0.60	0.30030	1.00
09/24/2025 04:00	1.0	1.4	2	0.60	0.30018	1.00
09/24/2025 05:00	0.9	1.4	2	0.61	0.30546	1.02
09/24/2025 06:00	1.0	1.3	2	0.60	0.30120	1.00
09/24/2025 07:00	0.9	1.3	2	0.60	0.30216	1.01
09/24/2025 08:00	0.8	1.4	2	0.61	0.30744	1.02
09/24/2025 09:00	0.6	1.4	2	0.63	0.31548	1.05
09/24/2025 10:00	0.6	1.3	2	0.61	0.30612	1.02
09/24/2025 11:00	0.6	1.4	2	0.61	0.30546	1.02
09/24/2025 12:00	0.6	1.4	2	0.62	0.30750	1.03
09/24/2025 13:00	0.4	1.3	2	0.62	0.30978	1.03
09/24/2025 14:00	0.3	1.4	3	0.63	0.31266	1.04
09/24/2025 15:00	0.4	1.4	3	0.62	0.30948	1.03
09/24/2025 16:00	0.4	1.4	3	0.64	0.31800	1.06
09/24/2025 17:00	0.5	1.3	3	0.62	0.30804	1.03
09/24/2025 18:00	0.6	1.3	2	0.61	0.30474	1.02
09/24/2025 19:00	0.6	1.4	2	0.61	0.30396	1.01
09/24/2025 20:00	0.7	1.3	2	0.61	0.30462	1.02
09/24/2025 21:00	0.7	1.3	2	0.60	0.30240	1.01
09/24/2025 22:00	0.8	1.4	2	0.60	0.30210	1.01
09/24/2025 23:00	0.8	1.3	2	0.60	0.30240	1.01
Average/Sum#:	0.7	1.4	2	0.61	0.30581	1.02
Minimum:	0.3	1.3	2	0.60	0.30018	1.00
Maximum:	1.0	1.4	3	0.64	0.31800	1.06
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 **To:** 09/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/25/2025 00:00	0.8	1.4	2	0.60	0.30192	1.01
09/25/2025 01:00	0.9	1.3	2	0.60	0.30120	1.00
09/25/2025 02:00	0.9	1.3	2	0.60	0.30132	1.00
09/25/2025 03:00	1.0	1.3	2	0.60	0.30156	1.01
09/25/2025 04:00	0.8	1.4	2	0.60	0.30198	1.01
09/25/2025 05:00	0.9	1.3	2	0.60	0.30168	1.01
09/25/2025 06:00	0.9	1.4	2	0.61	0.30372	1.01
09/25/2025 07:00	0.9	1.3	2	0.61	0.30336	1.01
09/25/2025 08:00	0.9	1.3	2	0.61	0.30456	1.02
09/25/2025 09:00	0.7	1.3	2	0.61	0.30516	1.02
09/25/2025 10:00	0.6	1.4	2	0.61	0.30600	1.02
09/25/2025 11:00	0.6	1.3	2	0.62	0.30774	1.03
09/25/2025 12:00	0.5	1.3	2	0.62	0.31026	1.03
09/25/2025 13:00	0.4	1.4	2	0.63	0.31266	1.04
09/25/2025 14:00	0.4	1.4	2	0.63	0.31362	1.05
09/25/2025 15:00	0.3	1.4	3	0.63	0.31404	1.05
09/25/2025 16:00	0.2	1.4	3	0.64	0.31788	1.06
09/25/2025 17:00	0.3	1.4	2	0.62	0.31218	1.04
09/25/2025 18:00	0.6	1.3	2	0.61	0.30582	1.02
09/25/2025 19:00	0.7	1.3	2	0.61	0.30264	1.01
09/25/2025 20:00	0.9	1.4	2	0.60	0.30018	1.00
09/25/2025 21:00	0.9	1.3	2	0.60	0.29958	1.00
09/25/2025 22:00	1.0	1.3	2	0.60	0.29832	0.99
09/25/2025 23:00	1.1	1.3	2	0.60	0.29850	1.00
Average/Sum#:	0.7	1.3	2	0.61	0.30525	1.02
Minimum:	0.2	1.3	2	0.60	0.29832	0.99
Maximum:	1.1	1.4	3	0.64	0.31788	1.06
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/26/2025 00:00	1.1	1.4	2	0.60	0.29898	1.00
09/26/2025 01:00	1.2	1.3	2	0.60	0.29832	0.99
09/26/2025 02:00	1.2	1.4	2	0.60	0.29778	0.99
09/26/2025 03:00	1.3	1.4	2	0.60	0.29754	0.99
09/26/2025 04:00	1.2	1.4	2	0.60	0.29820	0.99
09/26/2025 05:00	1.2	1.3	2	0.60	0.29766	0.99
09/26/2025 06:00	1.3	1.3	2	0.59	0.29676	0.99
09/26/2025 07:00	1.2	1.2	2	0.52	0.26238	0.87
09/26/2025 08:00	0.9	1.2	2	0.43	0.21672	0.72
09/26/2025 09:00	0.9	1.2	2	0.43	0.21612	0.72
09/26/2025 10:00	0.8	1.2	2	0.43	0.21516	0.72
09/26/2025 11:00	0.8	1.2	2	0.43	0.21468	0.72
09/26/2025 12:00	0.8	1.3	2	0.43	0.21414	0.71
09/26/2025 13:00	1.0	1.1	2	0.48	0.24078	0.80
09/26/2025 14:00	0.3	1.3	3	0.63	0.31542	1.05
09/26/2025 15:00	0.2	1.4	3	0.63	0.31698	1.06
09/26/2025 16:00	0.1	1.4	3	0.64	0.31830	1.06
09/26/2025 17:00	0.1	1.4	3	0.63	0.31626	1.05
09/26/2025 18:00	0.2	1.4	2	0.62	0.31218	1.04
09/26/2025 19:00	0.5	1.3	2	0.62	0.30768	1.03
09/26/2025 20:00	0.6	1.3	2	0.61	0.30600	1.02
09/26/2025 21:00	0.7	1.3	2	0.61	0.30474	1.02
09/26/2025 22:00	0.7	1.3	2	0.61	0.30276	1.01
09/26/2025 23:00	0.7	1.3	2	0.60	0.30192	1.01
Average/Sum#:	0.8	1.3	2	0.56	0.28198	0.94
Minimum:	0.1	1.1	2	0.43	0.21414	0.71
Maximum:	1.3	1.4	3	0.64	0.31830	1.06
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/27/2025 00:00	0.8	1.4	2	0.60	0.30138	1.00
09/27/2025 01:00	0.8	1.3	2	0.60	0.30138	1.00
09/27/2025 02:00	0.8	1.4	2	0.60	0.30108	1.00
09/27/2025 03:00	0.9	1.3	3	0.60	0.30048	1.00
09/27/2025 04:00	0.9	1.4	2	0.60	0.30048	1.00
09/27/2025 05:00	1.0	1.3	2	0.60	0.30078	1.00
09/27/2025 06:00	1.0	1.3	2	0.60	0.30048	1.00
09/27/2025 07:00	0.9	1.2	2	0.48	0.24192	0.81
09/27/2025 08:00	0.8	1.2	2	0.43	0.21618	0.72
09/27/2025 09:00	0.7	1.1	2	0.43	0.21594	0.72
09/27/2025 10:00	0.7	1.2	2	0.43	0.21576	0.72
09/27/2025 11:00	0.7	1.3	2	0.43	0.21570	0.72
09/27/2025 12:00	0.7	1.3	2	0.43	0.21576	0.72
09/27/2025 13:00	0.7	1.1	2	0.43	0.21528	0.72
09/27/2025 14:00	0.7	1.2	2	0.43	0.21528	0.72
09/27/2025 15:00	0.8	1.1	2	0.49	0.24546	0.82
09/27/2025 16:00	0.5	1.3	2	0.62	0.30864	1.03
09/27/2025 17:00	0.6	1.3	2	0.61	0.30546	1.02
09/27/2025 18:00	0.7	1.3	2	0.60	0.30180	1.01
09/27/2025 19:00	0.8	1.3	2	0.60	0.29994	1.00
09/27/2025 20:00	0.9	1.3	2	0.60	0.29898	1.00
09/27/2025 21:00	1.0	1.4	2	0.60	0.29814	0.99
09/27/2025 22:00	1.1	1.4	2	0.60	0.29778	0.99
09/27/2025 23:00	1.1	1.3	2	0.60	0.29874	1.00
Average/Sum#:	0.8	1.3	2	0.54	0.27137	0.90
Minimum:	0.5	1.1	2	0.43	0.21528	0.72
Maximum:	1.1	1.4	3	0.62	0.30864	1.03
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 **To:** 09/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2025 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/28/2025 00:00	1.1	1.3	2	0.60	0.29880	1.00
09/28/2025 01:00	1.4	1.3	2	0.60	0.29814	0.99
09/28/2025 02:00	1.2	1.4	2	0.60	0.29754	0.99
09/28/2025 03:00	1.2	1.3	2	0.60	0.29784	0.99
09/28/2025 04:00	1.2	1.3	2	0.60	0.29790	0.99
09/28/2025 05:00	1.2	1.3	2	0.60	0.29772	0.99
09/28/2025 06:00	1.2	1.4	2	0.59	0.29700	0.99
09/28/2025 07:00	1.2	1.3	2	0.57	0.28500	0.95
09/28/2025 08:00	0.8	1.2	2	0.44	0.21822	0.73
09/28/2025 09:00	0.7	1.2	2	0.43	0.21666	0.72
09/28/2025 10:00	0.7	1.3	2	0.43	0.21660	0.72
09/28/2025 11:00	0.7	1.2	2	0.43	0.21648	0.72
09/28/2025 12:00	0.8	1.3	1	0.50	0.24816	0.83
09/28/2025 13:00	0.8	1.3	2	0.61	0.30384	1.01
09/28/2025 14:00	0.9	1.3	2	0.54	0.26820	0.89
09/28/2025 15:00	0.8	1.3	2	0.60	0.30198	1.01
09/28/2025 16:00	0.8	1.4	2	0.60	0.30168	1.01
09/28/2025 17:00	0.9	1.3	2	0.60	0.30096	1.00
09/28/2025 18:00	0.9	1.4	2	0.60	0.29994	1.00
09/28/2025 19:00	0.9	1.3	2	0.60	0.30000	1.00
09/28/2025 20:00	1.0	1.2	2	0.60	0.29916	1.00
09/28/2025 21:00	1.0	1.3	2	0.60	0.29970	1.00
09/28/2025 22:00	1.1	1.3	2	0.60	0.29934	1.00
09/28/2025 23:00	1.1	1.3	2	0.60	0.29910	1.00
Average/Sum#:	1.0	1.3	2	0.56	0.28167	0.94
Minimum:	0.7	1.2	1	0.43	0.21648	0.72
Maximum:	1.4	1.4	2	0.61	0.30384	1.01
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/29/2025 00:00	1.1	1.3	2	0.60	0.29850	1.00
09/29/2025 01:00	1.1	1.3	2	0.60	0.29868	1.00
09/29/2025 02:00	1.1	1.3	2	0.60	0.29910	1.00
09/29/2025 03:00	1.1	1.3	2	0.60	0.29922	1.00
09/29/2025 04:00	1.0	1.3	2	0.60	0.29982	1.00
09/29/2025 05:00	1.0	1.3	2	0.60	0.29988	1.00
09/29/2025 06:00	1.0	1.3	2	0.60	0.29976	1.00
09/29/2025 07:00	1.0	1.3	2	0.60	0.29934	1.00
09/29/2025 08:00	0.8	1.1	2	0.50	0.24858	0.83
09/29/2025 09:00	1.1	1.4	2	0.61	0.30270	1.01
09/29/2025 10:00	0.9	1.4	2	0.61	0.30348	1.01
09/29/2025 11:00	0.9	1.4	2	0.61	0.30348	1.01
09/29/2025 12:00	0.9	1.3	2	0.61	0.30330	1.01
09/29/2025 13:00	0.9	1.4	2	0.61	0.30312	1.01
09/29/2025 14:00	0.8	1.3	2	0.61	0.30450	1.02
09/29/2025 15:00	0.8	1.4	2	0.61	0.30330	1.01
09/29/2025 16:00	0.8	1.4	2	0.61	0.30318	1.01
09/29/2025 17:00	0.8	1.4	2	0.60	0.29772	0.99
09/29/2025 18:00	0.8	1.3	2	0.59	0.29646	0.99
09/29/2025 19:00	0.8	1.3	2	0.59	0.29568	0.99
09/29/2025 20:00	0.9	1.3	2	0.59	0.29544	0.98
09/29/2025 21:00	0.9	1.3	2	0.59	0.29538	0.98
09/29/2025 22:00	0.9	1.3	2	0.59	0.29490	0.98
09/29/2025 23:00	1.0	1.4	2	0.59	0.29460	0.98
Average/Sum#:	0.9	1.3	2	0.60	0.29751	0.99
Minimum:	0.8	1.1	2	0.50	0.24858	0.83
Maximum:	1.1	1.4	2	0.61	0.30450	1.02
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 10/01/2025 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/30/2025 00:00	1.0	1.4	2	0.59	0.29466	0.98
09/30/2025 01:00	1.0	1.3	2	0.59	0.29436	0.98
09/30/2025 02:00	1.0	1.4	2	0.59	0.29406	0.98
09/30/2025 03:00	1.1	1.4	2	0.59	0.29382	0.98
09/30/2025 04:00	1.0	1.3	2	0.59	0.29394	0.98
09/30/2025 05:00	0.9	1.3	2	0.61	0.30498	1.02
09/30/2025 06:00	0.7	1.4	3	0.62	0.31146	1.04
09/30/2025 07:00	1.0	1.4	2	0.59	0.29460	0.98
09/30/2025 08:00	1.0	1.2	2	0.53	0.26280	0.88
09/30/2025 09:00	0.8	1.4	2	0.59	0.29652	0.99
09/30/2025 10:00	0.7	1.3	2	0.60	0.29844	0.99
09/30/2025 11:00	0.7	1.4	2	0.60	0.29958	1.00
09/30/2025 12:00	0.7	1.3	3	0.60	0.30024	1.00
09/30/2025 13:00	0.7	1.4	2	0.60	0.29940	1.00
09/30/2025 14:00	0.9	1.3	2	0.52	0.26178	0.87
09/30/2025 15:00	0.7	1.3	2	0.60	0.29814	0.99
09/30/2025 16:00	0.6	1.4	3	0.61	0.30696	1.02
09/30/2025 17:00	0.8	1.3	2	0.59	0.29646	0.99
09/30/2025 18:00	0.8	1.4	2	0.59	0.29526	0.98
09/30/2025 19:00	0.8	1.3	3	0.59	0.29508	0.98
09/30/2025 20:00	0.9	1.3	2	0.59	0.29436	0.98
09/30/2025 21:00	0.9	1.4	2	0.59	0.29424	0.98
09/30/2025 22:00	1.0	1.3	2	0.45	0.22398	0.75
09/30/2025 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.9	1.3	2	0.58	0.29153	0.97
Minimum:	0.6	1.2	2	0.45	0.22398	0.75
Maximum:	1.1	1.4	3	0.62	0.31146	1.04
%SI	4.17	4.17	4.17	4.17	4.17	4.17