

DOCKETED	
Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	266732
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q3 2025 - Part 7s
Description:	N/A
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public Agency
Submission Date:	10/21/2025 3:34:28 PM
Docketed Date:	10/21/2025

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/13/2025 00:00	4,110.1	0.0	4,110.1	101,900.0	418.8	0.5	0.3	0.8
07/13/2025 01:00	4,180.1	0.0	4,180.1	101,900.0	426.0	0.5	0.3	0.9
07/13/2025 02:00	4,430.2	0.1	4,430.2	101,900.0	451.4	0.5	0.3	0.9
07/13/2025 03:00	3,870.0	0.0	3,870.0	101,900.0	394.4	0.5	0.2	0.8
07/13/2025 04:00	3,764.4	0.0	3,764.4	101,900.0	383.6	0.5	0.2	0.8
07/13/2025 05:00	3,781.8	0.0	3,781.8	101,900.0	385.4	0.5	0.2	0.8
07/13/2025 06:00	3,630.8	0.0	3,630.8	101,900.0	370.0	0.4	0.2	0.7
07/13/2025 07:00	3,627.4	9.6	3,627.4	101,900.0	369.6	0.4	0.2	0.7
07/13/2025 08:00	3,625.5	6.1	3,625.5	101,900.0	369.4	0.4	0.2	0.7
07/13/2025 09:00	3,617.6	36.6	3,617.6	101,900.0	368.6	0.4	0.2	0.7
07/13/2025 10:00	3,615.0	80.5	3,615.0	101,900.0	368.4	0.5	0.2	0.8
07/13/2025 11:00	3,611.6	103.9	3,611.6	101,900.0	368.0	0.5	0.2	0.8
07/13/2025 12:00	3,694.3	111.5	3,694.3	101,900.0	376.4	0.5	0.2	0.8
07/13/2025 13:00	4,372.8	101.4	4,372.8	101,900.0	445.6	0.5	0.3	0.9
07/13/2025 14:00	4,427.1	73.2	4,427.1	101,900.0	451.1	0.5	0.3	0.9
07/13/2025 15:00	4,428.4	61.2	4,428.4	101,900.0	451.3	0.5	0.3	0.9
07/13/2025 16:00	4,427.9	69.2	4,427.9	101,900.0	451.2	0.5	0.3	0.9
07/13/2025 17:00	4,137.6	55.2	4,137.6	101,900.0	421.6	0.5	0.3	0.9
07/13/2025 18:00	0.0	0.0	0.0	101,900.0	0.0	0.0	0.0	0.0
07/13/2025 19:00	0.0	0.0	0.0	101,900.0	0.0	0.0	0.0	0.0
07/13/2025 20:00	0.0	0.0	0.0	101,900.0	0.0	0.0	0.0	0.0
07/13/2025 21:00	0.0	0.0	0.0	101,900.0	0.0	0.0	0.0	0.0
07/13/2025 22:00	3,903.3	0.0	3,903.3	101,900.0	397.7	0.5	0.2	0.8
07/13/2025 23:00	4,341.7	0.0	4,341.7	101,900.0	442.4	0.5	0.3	0.9
Average/Sum#:	3,979.9	35.4	3,979.9	101,900.0	405.5	0.5	0.2	0.8
Minimum:	3,611.6	0.0	3,611.6	101,900.0	368.0	0.4	0.2	0.7
Maximum:	4,430.2	111.5	4,430.2	101,900.0	451.4	0.5	0.3	0.9
%SI	16.67	16.67	16.67	0.00	16.67	16.67	16.67	16.67

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/14/2025 00:00	4,422.2	0.0	4,422.2	101,900.0	450.6	0.5	0.3	0.9
07/14/2025 01:00	3,653.4	0.0	3,653.4	101,900.0	372.3	0.5	0.2	0.7
07/14/2025 02:00	3,641.6	0.0	3,641.6	101,900.0	371.1	0.4	0.2	0.7
07/14/2025 03:00	3,663.1	0.0	3,663.1	101,900.0	373.3	0.4	0.2	0.7
07/14/2025 04:00	4,079.8	0.0	4,079.8	101,900.0	415.7	0.5	0.2	0.8
07/14/2025 05:00	4,106.9	0.0	4,106.9	101,900.0	418.5	0.5	0.3	0.8
07/14/2025 06:00	3,861.1	0.2	3,861.1	101,900.0	393.4	0.5	0.2	0.8
07/14/2025 07:00	3,623.3	11.9	3,623.3	101,900.0	369.2	0.4	0.2	0.7
07/14/2025 08:00	3,623.0	65.7	3,623.0	101,900.0	369.2	0.5	0.2	0.8
07/14/2025 09:00	3,617.3	58.9	3,617.3	101,900.0	368.6	0.4	0.2	0.8
07/14/2025 10:00	3,609.3	83.5	3,609.3	101,900.0	367.8	0.5	0.2	0.8
07/14/2025 11:00	3,605.8	114.2	3,605.8	101,900.0	367.4	0.5	0.2	0.8
07/14/2025 12:00	3,598.0	112.6	3,598.0	101,900.0	366.6	0.5	0.2	0.8
07/14/2025 13:00	3,590.9	110.2	3,590.9	101,900.0	365.9	0.5	0.2	0.8
07/14/2025 14:00	3,730.6	83.4	3,730.6	101,900.0	380.1	0.5	0.2	0.8
07/14/2025 15:00	3,632.2	70.4	3,632.2	101,900.0	370.1	0.5	0.2	0.8
07/14/2025 16:00	3,645.9	79.8	3,645.9	101,900.0	371.5	0.5	0.2	0.8
07/14/2025 17:00	3,769.1	72.8	3,769.1	101,900.0	384.1	0.5	0.2	0.8
07/14/2025 18:00	3,708.8	72.8	3,708.8	101,900.0	377.9	0.5	0.2	0.8
07/14/2025 19:00	3,604.1	31.8	3,604.1	101,900.0	367.3	0.4	0.2	0.7
07/14/2025 20:00	3,611.4	0.1	3,611.4	101,900.0	368.0	0.4	0.2	0.7
07/14/2025 21:00	3,621.6	0.0	3,621.6	101,900.0	369.0	0.4	0.2	0.7
07/14/2025 22:00	3,629.5	0.0	3,629.5	101,900.0	369.8	0.4	0.2	0.7
07/14/2025 23:00	3,640.6	0.3	3,640.6	101,900.0	371.0	0.4	0.2	0.7
Average/Sum#:	3,720.4	40.4	3,720.4	101,900.0	379.1	0.5	0.2	0.8
Minimum:	3,590.9	0.0	3,590.9	101,900.0	365.9	0.4	0.2	0.7
Maximum:	4,422.2	114.2	4,422.2	101,900.0	450.6	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/15/2025 00:00	3,645.7	0.0	3,645.7	101,900.0	371.5	0.4	0.2	0.2	0.7	0.7
07/15/2025 01:00	3,650.0	0.0	3,650.0	101,900.0	371.9	0.4	0.2	0.2	0.7	0.7
07/15/2025 02:00	3,649.6	0.0	3,649.6	101,900.0	371.9	0.4	0.2	0.2	0.7	0.7
07/15/2025 03:00	3,657.1	0.0	3,657.1	101,900.0	372.7	0.4	0.2	0.2	0.7	0.7
07/15/2025 04:00	3,653.7	0.0	3,653.7	101,900.0	372.3	0.4	0.2	0.2	0.7	0.7
07/15/2025 05:00	3,656.7	0.0	3,656.7	101,900.0	372.6	0.4	0.2	0.2	0.7	0.7
07/15/2025 06:00	3,653.5	0.0	3,653.5	101,900.0	372.3	0.4	0.2	0.2	0.7	0.7
07/15/2025 07:00	3,648.5	0.0	3,648.5	101,900.0	371.8	0.4	0.2	0.2	0.7	0.7
07/15/2025 08:00	3,633.8	0.0	3,633.8	101,900.0	370.3	0.4	0.2	0.2	0.7	0.7
07/15/2025 09:00	3,626.7	0.2	3,626.7	101,900.0	369.6	0.4	0.2	0.2	0.7	0.7
07/15/2025 10:00	3,618.7	31.2	3,618.7	101,900.0	368.7	0.4	0.2	0.2	0.7	0.7
07/15/2025 11:00	3,611.3	73.4	3,611.3	101,900.0	368.0	0.4	0.2	0.2	0.8	0.8
07/15/2025 12:00	3,607.9	97.5	3,607.9	101,900.0	367.6	0.5	0.2	0.2	0.8	0.8
07/15/2025 13:00	3,606.3	82.3	3,606.3	101,900.0	367.5	0.4	0.2	0.2	0.8	0.8
07/15/2025 14:00	3,600.2	34.7	3,600.2	101,900.0	366.9	0.4	0.2	0.2	0.7	0.7
07/15/2025 15:00	3,600.0	2.0	3,600.0	101,900.0	366.8	0.4	0.2	0.2	0.7	0.7
07/15/2025 16:00	3,597.4	4.0	3,597.4	101,900.0	366.6	0.4	0.2	0.2	0.7	0.7
07/15/2025 17:00	3,833.2	0.0	3,833.2	101,900.0	390.6	0.5	0.2	0.2	0.8	0.8
07/15/2025 18:00	3,637.5	2.4	3,637.5	101,900.0	370.7	0.4	0.2	0.2	0.7	0.7
07/15/2025 19:00	3,607.7	0.0	3,607.7	101,900.0	367.6	0.4	0.2	0.2	0.7	0.7
07/15/2025 20:00	3,619.0	0.0	3,619.0	101,900.0	368.8	0.4	0.2	0.2	0.7	0.7
07/15/2025 21:00	3,678.7	0.0	3,678.7	101,900.0	374.9	0.4	0.2	0.2	0.8	0.8
07/15/2025 22:00	3,623.3	0.0	3,623.3	101,900.0	369.2	0.4	0.2	0.2	0.7	0.7
07/15/2025 23:00	3,627.2	0.0	3,627.2	101,900.0	369.6	0.4	0.2	0.2	0.7	0.7
Average/Sum#:	3,639.3	13.7	3,639.3	101,900.0	370.9	0.4	0.2	0.2	0.7	0.7
Minimum:	3,597.4	0.0	3,597.4	101,900.0	366.6	0.4	0.2	0.2	0.7	0.7
Maximum:	3,833.2	97.5	3,833.2	101,900.0	390.6	0.5	0.2	0.2	0.8	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/16/2025 00:00	3,630.1	0.0	3,630.1	101,900.0	369.9	0.4	0.2	0.7
07/16/2025 01:00	3,631.9	0.0	3,631.9	101,900.0	370.1	0.4	0.2	0.7
07/16/2025 02:00	3,633.1	0.0	3,633.1	101,900.0	370.2	0.4	0.2	0.7
07/16/2025 03:00	3,636.1	0.0	3,636.1	101,900.0	370.5	0.4	0.2	0.7
07/16/2025 04:00	3,724.5	0.0	3,724.5	101,900.0	379.5	0.5	0.2	0.8
07/16/2025 05:00	4,297.0	0.0	4,297.0	101,900.0	437.9	0.5	0.3	0.9
07/16/2025 06:00	3,637.1	0.0	3,637.1	101,900.0	370.6	0.4	0.2	0.7
07/16/2025 07:00	3,635.0	0.0	3,635.0	101,900.0	370.4	0.4	0.2	0.7
07/16/2025 08:00	3,628.9	0.0	3,628.9	101,900.0	369.8	0.4	0.2	0.7
07/16/2025 09:00	3,625.4	2.2	3,625.4	101,900.0	369.4	0.4	0.2	0.7
07/16/2025 10:00	3,623.2	33.2	3,623.2	101,900.0	369.2	0.4	0.2	0.7
07/16/2025 11:00	3,784.1	76.0	3,784.1	101,900.0	385.6	0.5	0.2	0.8
07/16/2025 12:00	3,820.6	92.1	3,820.6	101,900.0	389.3	0.5	0.2	0.8
07/16/2025 13:00	4,109.3	78.2	4,109.3	101,900.0	418.7	0.5	0.3	0.9
07/16/2025 14:00	3,841.1	18.7	3,841.1	101,900.0	391.4	0.5	0.2	0.8
07/16/2025 15:00	3,825.6	0.0	3,825.6	101,900.0	389.8	0.5	0.2	0.8
07/16/2025 16:00	3,605.5	0.0	3,605.5	101,900.0	367.4	0.4	0.2	0.7
07/16/2025 17:00	3,649.2	0.0	3,649.2	101,900.0	371.9	0.4	0.2	0.7
07/16/2025 18:00	3,617.1	0.1	3,617.1	101,900.0	368.6	0.4	0.2	0.7
07/16/2025 19:00	3,617.9	0.0	3,617.9	101,900.0	368.7	0.4	0.2	0.7
07/16/2025 20:00	3,622.9	0.0	3,622.9	101,900.0	369.2	0.4	0.2	0.7
07/16/2025 21:00	3,626.7	0.0	3,626.7	101,900.0	369.6	0.4	0.2	0.7
07/16/2025 22:00	3,626.8	0.0	3,626.8	101,900.0	369.6	0.4	0.2	0.7
07/16/2025 23:00	3,623.9	0.0	3,623.9	101,900.0	369.3	0.4	0.2	0.7
Average/Sum#:	3,711.4	12.5	3,711.4	101,900.0	378.2	0.4	0.2	0.7
Minimum:	3,605.5	0.0	3,605.5	101,900.0	367.4	0.4	0.2	0.7
Maximum:	4,297.0	92.1	4,297.0	101,900.0	437.9	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/17/2025 00:00	3,624.3	0.0	3,624.3	101,900.0	369.3	0.4	0.2	0.7
07/17/2025 01:00	3,652.3	0.0	3,652.3	101,900.0	372.2	0.4	0.2	0.7
07/17/2025 02:00	3,626.2	0.0	3,626.2	101,900.0	369.5	0.4	0.2	0.7
07/17/2025 03:00	3,628.7	0.0	3,628.7	101,900.0	369.8	0.4	0.2	0.7
07/17/2025 04:00	3,630.6	0.0	3,630.6	101,900.0	370.0	0.4	0.2	0.7
07/17/2025 05:00	3,628.2	0.0	3,628.2	101,900.0	369.7	0.4	0.2	0.7
07/17/2025 06:00	3,626.7	0.0	3,626.7	101,900.0	369.6	0.4	0.2	0.7
07/17/2025 07:00	3,625.4	0.0	3,625.4	101,900.0	369.4	0.4	0.2	0.7
07/17/2025 08:00	3,624.6	3.7	3,624.6	101,900.0	369.3	0.4	0.2	0.7
07/17/2025 09:00	3,635.4	17.8	3,635.4	101,900.0	370.4	0.4	0.2	0.7
07/17/2025 10:00	3,620.2	17.8	3,620.2	101,900.0	368.9	0.4	0.2	0.7
07/17/2025 11:00	3,605.9	77.6	3,605.9	101,900.0	367.4	0.4	0.2	0.8
07/17/2025 12:00	3,764.0	99.1	3,764.0	101,900.0	383.6	0.5	0.2	0.8
07/17/2025 13:00	4,141.0	81.4	4,141.0	101,900.0	422.0	0.5	0.3	0.9
07/17/2025 14:00	4,319.3	25.1	4,319.3	101,900.0	440.1	0.5	0.3	0.9
07/17/2025 15:00	4,408.1	0.2	4,408.1	101,900.0	449.2	0.5	0.3	0.9
07/17/2025 16:00	3,601.2	6.7	3,601.2	101,900.0	367.0	0.4	0.2	0.7
07/17/2025 17:00	3,824.2	0.1	3,824.2	101,900.0	389.7	0.5	0.2	0.8
07/17/2025 18:00	3,607.4	7.2	3,607.4	101,900.0	367.6	0.4	0.2	0.7
07/17/2025 19:00	3,604.8	0.0	3,604.8	101,900.0	367.3	0.4	0.2	0.7
07/17/2025 20:00	3,612.4	0.0	3,612.4	101,900.0	368.1	0.4	0.2	0.7
07/17/2025 21:00	3,615.8	0.0	3,615.8	101,900.0	368.5	0.4	0.2	0.7
07/17/2025 22:00	3,658.8	0.0	3,658.8	101,900.0	372.8	0.4	0.2	0.7
07/17/2025 23:00	4,085.0	0.0	4,085.0	101,900.0	416.3	0.5	0.2	0.8
Average/Sum#:	3,740.4	14.0	3,740.4	101,900.0	381.2	0.4	0.2	0.7
Minimum:	3,601.2	0.0	3,601.2	101,900.0	367.0	0.4	0.2	0.7
Maximum:	4,408.1	99.1	4,408.1	101,900.0	449.2	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/18/2025 00:00	3,653.7	0.0	3,653.7	101,900.0	372.3	0.4	0.2	0.7
07/18/2025 01:00	3,632.3	0.0	3,632.3	101,900.0	370.1	0.4	0.2	0.7
07/18/2025 02:00	3,631.3	0.0	3,631.3	101,900.0	370.0	0.4	0.2	0.7
07/18/2025 03:00	3,635.0	0.0	3,635.0	101,900.0	370.4	0.4	0.2	0.7
07/18/2025 04:00	3,730.6	0.0	3,730.6	101,900.0	380.1	0.5	0.2	0.8
07/18/2025 05:00	3,852.6	0.0	3,852.6	101,900.0	392.6	0.5	0.2	0.8
07/18/2025 06:00	3,690.2	0.0	3,690.2	101,900.0	376.0	0.5	0.2	0.8
07/18/2025 07:00	3,660.9	0.0	3,660.9	101,900.0	373.0	0.4	0.2	0.7
07/18/2025 08:00	3,656.5	18.8	3,656.5	101,900.0	372.6	0.4	0.2	0.7
07/18/2025 09:00	3,650.9	22.8	3,650.9	101,900.0	372.0	0.4	0.2	0.7
07/18/2025 10:00	3,639.2	19.4	3,639.2	101,900.0	370.8	0.4	0.2	0.7
07/18/2025 11:00	3,623.8	78.1	3,623.8	101,900.0	369.3	0.5	0.2	0.8
07/18/2025 12:00	3,608.5	97.0	3,608.5	101,900.0	367.7	0.5	0.2	0.8
07/18/2025 13:00	3,600.1	72.8	3,600.1	101,900.0	366.9	0.4	0.2	0.7
07/18/2025 14:00	3,596.5	32.6	3,596.5	101,900.0	366.5	0.4	0.2	0.7
07/18/2025 15:00	3,593.6	3.6	3,593.6	101,900.0	366.2	0.4	0.2	0.7
07/18/2025 16:00	3,593.4	3.2	3,593.4	101,900.0	366.2	0.4	0.2	0.7
07/18/2025 17:00	3,677.7	1.3	3,677.7	101,900.0	374.8	0.5	0.2	0.7
07/18/2025 18:00	3,613.4	10.6	3,613.4	101,900.0	368.2	0.4	0.2	0.7
07/18/2025 19:00	3,601.7	0.0	3,601.7	101,900.0	367.0	0.4	0.2	0.7
07/18/2025 20:00	3,609.1	0.0	3,609.1	101,900.0	367.8	0.4	0.2	0.7
07/18/2025 21:00	3,619.7	0.0	3,619.7	101,900.0	368.8	0.4	0.2	0.7
07/18/2025 22:00	3,661.4	0.0	3,661.4	101,900.0	373.1	0.4	0.2	0.7
07/18/2025 23:00	4,195.3	0.1	4,195.3	101,900.0	427.5	0.5	0.3	0.9
Average/Sum#:	3,667.8	15.0	3,667.8	101,900.0	373.7	0.4	0.2	0.7
Minimum:	3,593.4	0.0	3,593.4	101,900.0	366.2	0.4	0.2	0.7
Maximum:	4,195.3	97.0	4,195.3	101,900.0	427.5	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/19/2025 00:00	3,634.8	0.0	3,634.8	101,900.0	370.4	0.4	0.2	0.7
07/19/2025 01:00	3,635.6	0.0	3,635.6	101,900.0	370.5	0.4	0.2	0.7
07/19/2025 02:00	3,632.0	0.0	3,632.0	101,900.0	370.1	0.4	0.2	0.7
07/19/2025 03:00	3,632.5	0.0	3,632.5	101,900.0	370.2	0.4	0.2	0.7
07/19/2025 04:00	3,634.1	0.0	3,634.1	101,900.0	370.3	0.4	0.2	0.7
07/19/2025 05:00	3,637.3	0.0	3,637.3	101,900.0	370.6	0.4	0.2	0.7
07/19/2025 06:00	3,635.4	0.0	3,635.4	101,900.0	370.4	0.4	0.2	0.7
07/19/2025 07:00	3,631.5	0.0	3,631.5	101,900.0	370.0	0.4	0.2	0.7
07/19/2025 08:00	3,629.1	0.0	3,629.1	101,900.0	369.8	0.4	0.2	0.7
07/19/2025 09:00	3,622.4	10.2	3,622.4	101,900.0	369.1	0.4	0.2	0.7
07/19/2025 10:00	3,618.0	11.8	3,618.0	101,900.0	368.7	0.4	0.2	0.7
07/19/2025 11:00	3,614.8	73.8	3,614.8	101,900.0	368.3	0.4	0.2	0.8
07/19/2025 12:00	3,607.8	91.6	3,607.8	101,900.0	367.6	0.5	0.2	0.8
07/19/2025 13:00	3,600.8	86.2	3,600.8	101,900.0	366.9	0.4	0.2	0.8
07/19/2025 14:00	3,596.8	31.8	3,596.8	101,900.0	366.5	0.4	0.2	0.7
07/19/2025 15:00	3,598.1	14.1	3,598.1	101,900.0	366.6	0.4	0.2	0.7
07/19/2025 16:00	3,596.5	31.5	3,596.5	101,900.0	366.5	0.4	0.2	0.7
07/19/2025 17:00	3,672.3	13.6	3,672.3	101,900.0	374.2	0.4	0.2	0.8
07/19/2025 18:00	3,606.3	19.6	3,606.3	101,900.0	367.5	0.4	0.2	0.7
07/19/2025 19:00	3,602.6	0.0	3,602.6	101,900.0	367.1	0.4	0.2	0.7
07/19/2025 20:00	3,611.3	0.0	3,611.3	101,900.0	368.0	0.4	0.2	0.7
07/19/2025 21:00	3,614.5	0.0	3,614.5	101,900.0	368.3	0.4	0.2	0.7
07/19/2025 22:00	3,617.7	0.3	3,617.7	101,900.0	368.6	0.4	0.2	0.7
07/19/2025 23:00	3,617.4	0.0	3,617.4	101,900.0	368.6	0.4	0.2	0.7
Average/Sum#:	3,620.8	16.0	3,620.8	101,900.0	369.0	0.4	0.2	0.7
Minimum:	3,596.5	0.0	3,596.5	101,900.0	366.5	0.4	0.2	0.7
Maximum:	3,672.3	91.6	3,672.3	101,900.0	374.2	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/20/2025 00:00	3,620.2	0.0	3,620.2	101,900.0	368.9	0.4	0.2	0.7
07/20/2025 01:00	3,622.5	0.0	3,622.5	101,900.0	369.1	0.4	0.2	0.7
07/20/2025 02:00	3,621.4	0.0	3,621.4	101,900.0	369.0	0.4	0.2	0.7
07/20/2025 03:00	3,626.6	0.0	3,626.6	101,900.0	369.6	0.4	0.2	0.7
07/20/2025 04:00	3,629.2	0.0	3,629.2	101,900.0	369.8	0.4	0.2	0.7
07/20/2025 05:00	3,629.4	0.0	3,629.4	101,900.0	369.8	0.4	0.2	0.7
07/20/2025 06:00	3,631.0	0.0	3,631.0	101,900.0	370.0	0.4	0.2	0.7
07/20/2025 07:00	3,629.8	0.1	3,629.8	101,900.0	369.9	0.4	0.2	0.7
07/20/2025 08:00	3,626.3	28.0	3,626.3	101,900.0	369.5	0.4	0.2	0.7
07/20/2025 09:00	3,621.5	29.7	3,621.5	101,900.0	369.0	0.4	0.2	0.7
07/20/2025 10:00	3,615.2	8.8	3,615.2	101,900.0	368.4	0.4	0.2	0.7
07/20/2025 11:00	3,608.4	76.2	3,608.4	101,900.0	367.7	0.4	0.2	0.8
07/20/2025 12:00	3,600.7	97.4	3,600.7	101,900.0	366.9	0.5	0.2	0.8
07/20/2025 13:00	3,594.9	89.0	3,594.9	101,900.0	366.3	0.4	0.2	0.8
07/20/2025 14:00	3,593.2	22.6	3,593.2	101,900.0	366.1	0.4	0.2	0.7
07/20/2025 15:00	3,592.8	3.7	3,592.8	101,900.0	366.1	0.4	0.2	0.7
07/20/2025 16:00	3,596.1	5.9	3,596.1	101,900.0	366.4	0.4	0.2	0.7
07/20/2025 17:00	3,629.2	0.0	3,629.2	101,900.0	369.8	0.4	0.2	0.7
07/20/2025 18:00	3,609.4	0.5	3,609.4	101,900.0	367.8	0.4	0.2	0.7
07/20/2025 19:00	3,614.8	0.0	3,614.8	101,900.0	368.3	0.4	0.2	0.7
07/20/2025 20:00	3,621.0	0.0	3,621.0	101,900.0	369.0	0.4	0.2	0.7
07/20/2025 21:00	3,623.6	0.0	3,623.6	101,900.0	369.2	0.4	0.2	0.7
07/20/2025 22:00	3,624.4	0.0	3,624.4	101,900.0	369.3	0.4	0.2	0.7
07/20/2025 23:00	3,628.8	0.0	3,628.8	101,900.0	369.8	0.4	0.2	0.7
Average/Sum#:	3,617.1	15.1	3,617.1	101,900.0	368.6	0.4	0.2	0.7
Minimum:	3,592.8	0.0	3,592.8	101,900.0	366.1	0.4	0.2	0.7
Maximum:	3,631.0	97.4	3,631.0	101,900.0	370.0	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/21/2025 00:00	3,624.8	0.0	3,624.8	101,900.0	369.4	0.4	0.2	0.7
07/21/2025 01:00	3,625.7	0.0	3,625.7	101,900.0	369.5	0.4	0.2	0.7
07/21/2025 02:00	3,627.4	0.0	3,627.4	101,900.0	369.6	0.4	0.2	0.7
07/21/2025 03:00	3,630.1	0.0	3,630.1	101,900.0	369.9	0.4	0.2	0.7
07/21/2025 04:00	3,881.5	0.0	3,881.5	101,900.0	395.5	0.5	0.2	0.8
07/21/2025 05:00	3,862.4	0.0	3,862.4	101,900.0	393.6	0.5	0.2	0.8
07/21/2025 06:00	3,631.3	0.0	3,631.3	101,900.0	370.0	0.4	0.2	0.7
07/21/2025 07:00	3,631.1	0.0	3,631.1	101,900.0	370.0	0.4	0.2	0.7
07/21/2025 08:00	3,627.5	0.0	3,627.5	101,900.0	369.6	0.4	0.2	0.7
07/21/2025 09:00	3,623.7	0.0	3,623.7	101,900.0	369.3	0.4	0.2	0.7
07/21/2025 10:00	3,619.1	0.0	3,619.1	101,900.0	368.8	0.4	0.2	0.7
07/21/2025 11:00	3,611.5	63.5	3,611.5	101,900.0	368.0	0.4	0.2	0.8
07/21/2025 12:00	3,605.1	71.9	3,605.1	101,900.0	367.4	0.5	0.2	0.7
07/21/2025 13:00	3,603.4	58.3	3,603.4	101,900.0	367.2	0.4	0.2	0.7
07/21/2025 14:00	3,600.7	0.0	3,600.7	101,900.0	366.9	0.4	0.2	0.7
07/21/2025 15:00	3,602.4	0.0	3,602.4	101,900.0	367.1	0.4	0.2	0.7
07/21/2025 16:00	3,607.2	0.0	3,607.2	101,900.0	367.6	0.4	0.2	0.7
07/21/2025 17:00	3,609.2	0.0	3,609.2	101,900.0	367.8	0.4	0.2	0.7
07/21/2025 18:00	3,614.0	0.0	3,614.0	101,900.0	368.3	0.4	0.2	0.7
07/21/2025 19:00	3,618.9	0.0	3,618.9	101,900.0	368.8	0.4	0.2	0.7
07/21/2025 20:00	3,622.2	0.0	3,622.2	101,900.0	369.1	0.4	0.2	0.7
07/21/2025 21:00	3,622.2	0.0	3,622.2	101,900.0	369.1	0.4	0.2	0.7
07/21/2025 22:00	3,625.4	0.0	3,625.4	101,900.0	369.4	0.4	0.2	0.7
07/21/2025 23:00	3,628.7	0.0	3,628.7	101,900.0	369.8	0.4	0.2	0.7
Average/Sum#:	3,639.8	8.1	3,639.8	101,900.0	370.9	0.4	0.2	0.7
Minimum:	3,600.7	0.0	3,600.7	101,900.0	366.9	0.4	0.2	0.7
Maximum:	3,881.5	71.9	3,881.5	101,900.0	395.5	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/22/2025 00:00	3,634.0	0.0	3,634.0	101,900.0	370.3	0.4	0.2	0.2	0.7	0.7
07/22/2025 01:00	3,637.8	0.0	3,637.8	101,900.0	370.7	0.4	0.2	0.2	0.7	0.7
07/22/2025 02:00	3,636.0	0.0	3,636.0	101,900.0	370.5	0.4	0.2	0.2	0.7	0.7
07/22/2025 03:00	3,633.9	0.0	3,633.9	101,900.0	370.3	0.4	0.2	0.2	0.7	0.7
07/22/2025 04:00	3,629.2	0.0	3,629.2	101,900.0	369.8	0.4	0.2	0.2	0.7	0.7
07/22/2025 05:00	3,632.1	0.0	3,632.1	101,900.0	370.1	0.4	0.2	0.2	0.7	0.7
07/22/2025 06:00	3,628.5	0.0	3,628.5	101,900.0	369.7	0.4	0.2	0.2	0.7	0.7
07/22/2025 07:00	3,631.5	0.0	3,631.5	101,900.0	370.0	0.4	0.2	0.2	0.7	0.7
07/22/2025 08:00	3,631.5	0.0	3,631.5	101,900.0	370.0	0.4	0.2	0.2	0.7	0.7
07/22/2025 09:00	3,631.0	0.0	3,631.0	101,900.0	370.0	0.4	0.2	0.2	0.7	0.7
07/22/2025 10:00	3,624.1	0.0	3,624.1	101,900.0	369.3	0.4	0.2	0.2	0.7	0.7
07/22/2025 11:00	3,621.6	57.4	3,621.6	101,900.0	369.0	0.4	0.2	0.2	0.8	0.8
07/22/2025 12:00	3,619.3	71.4	3,619.3	101,900.0	368.8	0.5	0.2	0.2	0.8	0.8
07/22/2025 13:00	3,612.4	53.0	3,612.4	101,900.0	368.1	0.4	0.2	0.2	0.7	0.7
07/22/2025 14:00	3,609.3	0.0	3,609.3	101,900.0	367.8	0.4	0.2	0.2	0.7	0.7
07/22/2025 15:00	3,607.1	0.0	3,607.1	101,900.0	367.6	0.4	0.2	0.2	0.7	0.7
07/22/2025 16:00	3,607.2	0.0	3,607.2	101,900.0	367.6	0.4	0.2	0.2	0.7	0.7
07/22/2025 17:00	3,612.4	0.0	3,612.4	101,900.0	368.1	0.4	0.2	0.2	0.7	0.7
07/22/2025 18:00	3,623.6	0.0	3,623.6	101,900.0	369.2	0.4	0.2	0.2	0.7	0.7
07/22/2025 19:00	3,627.1	0.0	3,627.1	101,900.0	369.6	0.4	0.2	0.2	0.7	0.7
07/22/2025 20:00	3,635.7	0.0	3,635.7	101,900.0	370.5	0.4	0.2	0.2	0.7	0.7
07/22/2025 21:00	3,638.4	0.0	3,638.4	101,900.0	370.8	0.4	0.2	0.2	0.7	0.7
07/22/2025 22:00	3,655.4	0.0	3,655.4	101,900.0	372.5	0.4	0.2	0.2	0.7	0.7
07/22/2025 23:00	3,652.6	0.0	3,652.6	101,900.0	372.2	0.4	0.2	0.2	0.7	0.7
Average/Sum#:	3,628.0	7.6	3,628.0	101,900.0	369.7	0.4	0.2	0.2	0.7	0.7
Minimum:	3,607.1	0.0	3,607.1	101,900.0	367.6	0.4	0.2	0.2	0.7	0.7
Maximum:	3,655.4	71.4	3,655.4	101,900.0	372.5	0.5	0.2	0.2	0.8	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/23/2025 00:00	3,642.3	0.0	3,642.3	101,900.0	371.2	0.4	0.2	0.2	0.7	0.7
07/23/2025 01:00	3,644.6	0.0	3,644.6	101,900.0	371.4	0.4	0.2	0.2	0.7	0.7
07/23/2025 02:00	3,641.3	0.0	3,641.3	101,900.0	371.0	0.4	0.2	0.2	0.7	0.7
07/23/2025 03:00	3,642.2	0.0	3,642.2	101,900.0	371.1	0.4	0.2	0.2	0.7	0.7
07/23/2025 04:00	3,642.6	0.0	3,642.6	101,900.0	371.2	0.4	0.2	0.2	0.7	0.7
07/23/2025 05:00	3,647.6	0.0	3,647.6	101,900.0	371.7	0.4	0.2	0.2	0.7	0.7
07/23/2025 06:00	3,642.2	0.0	3,642.2	101,900.0	371.1	0.4	0.2	0.2	0.7	0.7
07/23/2025 07:00	3,665.2	0.0	3,665.2	101,900.0	373.5	0.4	0.2	0.2	0.7	0.7
07/23/2025 08:00	3,636.0	0.5	3,636.0	101,900.0	370.5	0.4	0.2	0.2	0.7	0.7
07/23/2025 09:00	3,635.7	2.8	3,635.7	101,900.0	370.5	0.4	0.2	0.2	0.7	0.7
07/23/2025 10:00	3,630.6	0.0	3,630.6	101,900.0	370.0	0.4	0.2	0.2	0.7	0.7
07/23/2025 11:00	3,628.4	9.5	3,628.4	101,900.0	369.7	0.4	0.2	0.2	0.7	0.7
07/23/2025 12:00	3,624.1	68.0	3,624.1	101,900.0	369.3	0.5	0.2	0.2	0.8	0.8
07/23/2025 13:00	3,773.6	58.6	3,773.6	101,900.0	384.5	0.5	0.2	0.2	0.8	0.8
07/23/2025 14:00	3,617.6	0.0	3,617.6	101,900.0	368.6	0.4	0.2	0.2	0.7	0.7
07/23/2025 15:00	3,612.0	0.0	3,612.0	101,900.0	368.1	0.4	0.2	0.2	0.7	0.7
07/23/2025 16:00	3,614.5	0.0	3,614.5	101,900.0	368.3	0.4	0.2	0.2	0.7	0.7
07/23/2025 17:00	3,714.5	0.0	3,714.5	101,900.0	378.5	0.5	0.2	0.2	0.8	0.8
07/23/2025 18:00	4,124.7	0.0	4,124.7	101,900.0	420.3	0.5	0.3	0.3	0.8	0.8
07/23/2025 19:00	4,333.1	0.0	4,333.1	101,900.0	441.5	0.5	0.3	0.3	0.9	0.9
07/23/2025 20:00	3,923.8	0.0	3,923.8	101,900.0	399.8	0.5	0.2	0.2	0.8	0.8
07/23/2025 21:00	4,409.4	0.0	4,409.4	101,900.0	449.3	0.5	0.3	0.3	0.9	0.9
07/23/2025 22:00	4,424.2	0.0	4,424.2	101,900.0	450.8	0.5	0.3	0.3	0.9	0.9
07/23/2025 23:00	4,149.2	0.0	4,149.2	101,900.0	422.8	0.5	0.3	0.3	0.8	0.8
Average/Sum#:	3,792.5	5.8	3,792.5	101,900.0	386.4	0.4	0.2	0.2	0.8	0.8
Minimum:	3,612.0	0.0	3,612.0	101,900.0	368.1	0.4	0.2	0.2	0.7	0.7
Maximum:	4,424.2	68.0	4,424.2	101,900.0	450.8	0.5	0.3	0.3	0.9	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/24/2025 00:00	3,663.1	0.0	3,663.1	101,900.0	373.3	0.4	0.2	0.7
07/24/2025 01:00	3,644.1	0.0	3,644.1	101,900.0	371.3	0.4	0.2	0.7
07/24/2025 02:00	3,643.1	0.0	3,643.1	101,900.0	371.2	0.4	0.2	0.7
07/24/2025 03:00	3,645.6	0.0	3,645.6	101,900.0	371.5	0.4	0.2	0.7
07/24/2025 04:00	3,697.3	0.0	3,697.3	101,900.0	376.8	0.5	0.2	0.8
07/24/2025 05:00	3,924.7	0.0	3,924.7	101,900.0	399.9	0.5	0.2	0.8
07/24/2025 06:00	3,646.9	0.0	3,646.9	101,900.0	371.6	0.4	0.2	0.7
07/24/2025 07:00	3,644.0	0.0	3,644.0	101,900.0	371.3	0.4	0.2	0.7
07/24/2025 08:00	3,640.6	0.0	3,640.6	101,900.0	371.0	0.4	0.2	0.7
07/24/2025 09:00	3,636.1	0.0	3,636.1	101,900.0	370.5	0.4	0.2	0.7
07/24/2025 10:00	3,630.2	0.0	3,630.2	101,900.0	369.9	0.4	0.2	0.7
07/24/2025 11:00	3,623.5	56.3	3,623.5	101,900.0	369.2	0.4	0.2	0.8
07/24/2025 12:00	3,616.8	82.0	3,616.8	101,900.0	368.6	0.5	0.2	0.8
07/24/2025 13:00	3,614.0	60.0	3,614.0	101,900.0	368.3	0.4	0.2	0.7
07/24/2025 14:00	3,612.1	0.0	3,612.1	101,900.0	368.1	0.4	0.2	0.7
07/24/2025 15:00	3,610.0	0.0	3,610.0	101,900.0	367.9	0.4	0.2	0.7
07/24/2025 16:00	3,609.4	0.0	3,609.4	101,900.0	367.8	0.4	0.2	0.7
07/24/2025 17:00	3,776.3	0.0	3,776.3	101,900.0	384.8	0.5	0.2	0.8
07/24/2025 18:00	3,633.8	0.0	3,633.8	101,900.0	370.3	0.4	0.2	0.7
07/24/2025 19:00	3,616.5	0.0	3,616.5	101,900.0	368.5	0.4	0.2	0.7
07/24/2025 20:00	3,623.5	0.0	3,623.5	101,900.0	369.2	0.4	0.2	0.7
07/24/2025 21:00	3,629.2	0.0	3,629.2	101,900.0	369.8	0.4	0.2	0.7
07/24/2025 22:00	3,630.6	0.0	3,630.6	101,900.0	370.0	0.4	0.2	0.7
07/24/2025 23:00	3,631.3	0.0	3,631.3	101,900.0	370.0	0.4	0.2	0.7
Average/Sum#:	3,651.8	8.3	3,651.8	101,900.0	372.1	0.4	0.2	0.7
Minimum:	3,609.4	0.0	3,609.4	101,900.0	367.8	0.4	0.2	0.7
Maximum:	3,924.7	82.0	3,924.7	101,900.0	399.9	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/25/2025 00:00	3,631.7	0.0	3,631.7	101,900.0	370.1	0.4	0.2	0.7
07/25/2025 01:00	3,635.5	0.0	3,635.5	101,900.0	370.5	0.4	0.2	0.7
07/25/2025 02:00	3,637.9	0.0	3,637.9	101,900.0	370.7	0.4	0.2	0.7
07/25/2025 03:00	3,638.8	0.0	3,638.8	101,900.0	370.8	0.4	0.2	0.7
07/25/2025 04:00	3,641.7	0.0	3,641.7	101,900.0	371.1	0.4	0.2	0.7
07/25/2025 05:00	3,643.5	0.0	3,643.5	101,900.0	371.3	0.4	0.2	0.7
07/25/2025 06:00	3,643.4	0.0	3,643.4	101,900.0	371.3	0.4	0.2	0.7
07/25/2025 07:00	3,639.0	0.0	3,639.0	101,900.0	370.8	0.4	0.2	0.7
07/25/2025 08:00	3,637.7	0.0	3,637.7	101,900.0	370.7	0.4	0.2	0.7
07/25/2025 09:00	3,635.6	0.0	3,635.6	101,900.0	370.5	0.4	0.2	0.7
07/25/2025 10:00	3,631.2	0.0	3,631.2	101,900.0	370.0	0.4	0.2	0.7
07/25/2025 11:00	3,625.1	59.3	3,625.1	101,900.0	369.4	0.4	0.2	0.8
07/25/2025 12:00	3,618.7	74.0	3,618.7	101,900.0	368.7	0.5	0.2	0.8
07/25/2025 13:00	3,612.6	56.2	3,612.6	101,900.0	368.1	0.4	0.2	0.7
07/25/2025 14:00	3,611.4	0.0	3,611.4	101,900.0	368.0	0.4	0.2	0.7
07/25/2025 15:00	3,613.9	0.0	3,613.9	101,900.0	368.3	0.4	0.2	0.7
07/25/2025 16:00	3,612.2	0.0	3,612.2	101,900.0	368.1	0.4	0.2	0.7
07/25/2025 17:00	3,614.9	0.0	3,614.9	101,900.0	368.4	0.4	0.2	0.7
07/25/2025 18:00	3,622.2	0.0	3,622.2	101,900.0	369.1	0.4	0.2	0.7
07/25/2025 19:00	3,627.1	0.0	3,627.1	101,900.0	369.6	0.4	0.2	0.7
07/25/2025 20:00	3,653.6	0.0	3,653.6	101,900.0	372.3	0.4	0.2	0.7
07/25/2025 21:00	3,634.1	0.0	3,634.1	101,900.0	370.3	0.4	0.2	0.7
07/25/2025 22:00	3,637.4	0.0	3,637.4	101,900.0	370.7	0.4	0.2	0.7
07/25/2025 23:00	3,635.7	0.0	3,635.7	101,900.0	370.5	0.4	0.2	0.7
Average/Sum#:	3,630.6	7.9	3,630.6	101,900.0	370.0	0.4	0.2	0.7
Minimum:	3,611.4	0.0	3,611.4	101,900.0	368.0	0.4	0.2	0.7
Maximum:	3,653.6	74.0	3,653.6	101,900.0	372.3	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/26/2025 00:00	3,638.6	0.0	3,638.6	101,900.0	370.8	0.4	0.2	0.7
07/26/2025 01:00	3,638.7	0.0	3,638.7	101,900.0	370.8	0.4	0.2	0.7
07/26/2025 02:00	3,637.6	0.0	3,637.6	101,900.0	370.7	0.4	0.2	0.7
07/26/2025 03:00	3,639.2	0.0	3,639.2	101,900.0	370.8	0.4	0.2	0.7
07/26/2025 04:00	3,642.8	0.0	3,642.8	101,900.0	371.2	0.4	0.2	0.7
07/26/2025 05:00	3,642.9	0.0	3,642.9	101,900.0	371.2	0.4	0.2	0.7
07/26/2025 06:00	3,642.5	0.0	3,642.5	101,900.0	371.2	0.4	0.2	0.7
07/26/2025 07:00	3,639.9	0.0	3,639.9	101,900.0	370.9	0.4	0.2	0.7
07/26/2025 08:00	3,635.8	0.0	3,635.8	101,900.0	370.5	0.4	0.2	0.7
07/26/2025 09:00	3,628.9	0.0	3,628.9	101,900.0	369.8	0.4	0.2	0.7
07/26/2025 10:00	3,620.4	0.0	3,620.4	101,900.0	368.9	0.4	0.2	0.7
07/26/2025 11:00	3,609.2	49.5	3,609.2	101,900.0	367.8	0.4	0.2	0.7
07/26/2025 12:00	3,605.4	47.9	3,605.4	101,900.0	367.4	0.4	0.2	0.7
07/26/2025 13:00	3,612.8	33.8	3,612.8	101,900.0	368.1	0.4	0.2	0.7
07/26/2025 14:00	3,617.4	0.0	3,617.4	101,900.0	368.6	0.4	0.2	0.7
07/26/2025 15:00	3,617.5	0.0	3,617.5	101,900.0	368.6	0.4	0.2	0.7
07/26/2025 16:00	3,614.4	0.0	3,614.4	101,900.0	368.3	0.4	0.2	0.7
07/26/2025 17:00	3,756.9	0.0	3,756.9	101,900.0	382.8	0.5	0.2	0.8
07/26/2025 18:00	3,624.4	0.0	3,624.4	101,900.0	369.3	0.4	0.2	0.7
07/26/2025 19:00	3,625.9	0.0	3,625.9	101,900.0	369.5	0.4	0.2	0.7
07/26/2025 20:00	3,630.5	0.0	3,630.5	101,900.0	369.9	0.4	0.2	0.7
07/26/2025 21:00	3,631.6	0.0	3,631.6	101,900.0	370.1	0.4	0.2	0.7
07/26/2025 22:00	3,626.9	0.0	3,626.9	101,900.0	369.6	0.4	0.2	0.7
07/26/2025 23:00	3,630.6	0.0	3,630.6	101,900.0	370.0	0.4	0.2	0.7
Average/Sum#:	3,633.8	5.5	3,633.8	101,900.0	370.3	0.4	0.2	0.7
Minimum:	3,605.4	0.0	3,605.4	101,900.0	367.4	0.4	0.2	0.7
Maximum:	3,756.9	49.5	3,756.9	101,900.0	382.8	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/27/2025 00:00	3,634.9	0.0	3,634.9	101,900.0	370.4	0.4	0.2	0.7
07/27/2025 01:00	3,635.0	0.0	3,635.0	101,900.0	370.4	0.4	0.2	0.7
07/27/2025 02:00	3,640.2	0.0	3,640.2	101,900.0	370.9	0.4	0.2	0.7
07/27/2025 03:00	3,638.3	0.0	3,638.3	101,900.0	370.7	0.4	0.2	0.7
07/27/2025 04:00	3,639.2	0.0	3,639.2	101,900.0	370.8	0.4	0.2	0.7
07/27/2025 05:00	3,636.3	0.0	3,636.3	101,900.0	370.5	0.4	0.2	0.7
07/27/2025 06:00	3,639.9	0.0	3,639.9	101,900.0	370.9	0.4	0.2	0.7
07/27/2025 07:00	3,640.4	0.0	3,640.4	101,900.0	371.0	0.4	0.2	0.7
07/27/2025 08:00	3,639.1	0.0	3,639.1	101,900.0	370.8	0.4	0.2	0.7
07/27/2025 09:00	3,635.7	0.0	3,635.7	101,900.0	370.5	0.4	0.2	0.7
07/27/2025 10:00	3,631.9	0.0	3,631.9	101,900.0	370.1	0.4	0.2	0.7
07/27/2025 11:00	3,629.3	51.4	3,629.3	101,900.0	369.8	0.4	0.2	0.8
07/27/2025 12:00	3,625.0	71.4	3,625.0	101,900.0	369.4	0.5	0.2	0.8
07/27/2025 13:00	3,615.4	58.7	3,615.4	101,900.0	368.4	0.4	0.2	0.7
07/27/2025 14:00	3,614.5	0.0	3,614.5	101,900.0	368.3	0.4	0.2	0.7
07/27/2025 15:00	3,615.5	0.0	3,615.5	101,900.0	368.4	0.4	0.2	0.7
07/27/2025 16:00	3,615.8	0.0	3,615.8	101,900.0	368.5	0.4	0.2	0.7
07/27/2025 17:00	3,767.4	0.0	3,767.4	101,900.0	383.9	0.5	0.2	0.8
07/27/2025 18:00	3,646.3	0.0	3,646.3	101,900.0	371.6	0.4	0.2	0.7
07/27/2025 19:00	3,704.1	0.0	3,704.1	101,900.0	377.4	0.5	0.2	0.8
07/27/2025 20:00	3,632.4	0.0	3,632.4	101,900.0	370.1	0.4	0.2	0.7
07/27/2025 21:00	3,634.1	0.0	3,634.1	101,900.0	370.3	0.4	0.2	0.7
07/27/2025 22:00	3,635.2	0.0	3,635.2	101,900.0	370.4	0.4	0.2	0.7
07/27/2025 23:00	3,636.1	0.0	3,636.1	101,900.0	370.5	0.4	0.2	0.7
Average/Sum#:	3,640.9	7.6	3,640.9	101,900.0	371.0	0.4	0.2	0.7
Minimum:	3,614.5	0.0	3,614.5	101,900.0	368.3	0.4	0.2	0.7
Maximum:	3,767.4	71.4	3,767.4	101,900.0	383.9	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/28/2025 00:00	3,638.3	0.0	3,638.3	101,900.0	370.7	0.4	0.2	0.7
07/28/2025 01:00	3,638.3	0.0	3,638.3	101,900.0	370.7	0.4	0.2	0.7
07/28/2025 02:00	3,640.3	0.0	3,640.3	101,900.0	370.9	0.4	0.2	0.7
07/28/2025 03:00	3,638.3	0.0	3,638.3	101,900.0	370.7	0.4	0.2	0.7
07/28/2025 04:00	3,640.3	0.0	3,640.3	101,900.0	370.9	0.4	0.2	0.7
07/28/2025 05:00	3,639.3	0.0	3,639.3	101,900.0	370.8	0.4	0.2	0.7
07/28/2025 06:00	3,643.8	0.0	3,643.8	101,900.0	371.3	0.4	0.2	0.7
07/28/2025 07:00	3,643.1	0.0	3,643.1	101,900.0	371.2	0.4	0.2	0.7
07/28/2025 08:00	3,640.9	0.2	3,640.9	101,900.0	371.0	0.4	0.2	0.7
07/28/2025 09:00	3,644.6	0.0	3,644.6	101,900.0	371.4	0.4	0.2	0.7
07/28/2025 10:00	3,715.0	0.0	3,715.0	101,900.0	378.6	0.5	0.2	0.8
07/28/2025 11:00	3,634.3	60.0	3,634.3	101,900.0	370.3	0.5	0.2	0.8
07/28/2025 12:00	4,418.1	82.8	4,418.1	101,900.0	450.2	0.5	0.3	0.9
07/28/2025 13:00	4,431.0	65.3	4,431.0	101,900.0	451.5	0.5	0.3	0.9
07/28/2025 14:00	4,433.9	0.8	4,433.9	101,900.0	451.8	0.5	0.3	0.9
07/28/2025 15:00	3,915.9	0.0	3,915.9	101,900.0	399.0	0.5	0.2	0.8
07/28/2025 16:00	3,842.5	0.3	3,842.5	101,900.0	391.6	0.5	0.2	0.8
07/28/2025 17:00	4,207.3	7.5	4,207.3	101,900.0	428.7	0.5	0.3	0.9
07/28/2025 18:00	4,424.1	0.8	4,424.1	101,900.0	450.8	0.5	0.3	0.9
07/28/2025 19:00	3,793.7	0.0	3,793.7	101,900.0	386.6	0.5	0.2	0.8
07/28/2025 20:00	3,621.3	0.0	3,621.3	101,900.0	369.0	0.4	0.2	0.7
07/28/2025 21:00	3,677.6	0.0	3,677.6	101,900.0	374.7	0.4	0.2	0.8
07/28/2025 22:00	3,657.9	0.0	3,657.9	101,900.0	372.7	0.4	0.2	0.7
07/28/2025 23:00	4,375.2	0.0	4,375.2	101,900.0	445.8	0.5	0.3	0.9
Average/Sum#:	3,856.5	9.1	3,856.5	101,900.0	393.0	0.4	0.2	0.8
Minimum:	3,621.3	0.0	3,621.3	101,900.0	369.0	0.4	0.2	0.7
Maximum:	4,433.9	82.8	4,433.9	101,900.0	451.8	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/29/2025 00:00	3,854.2	0.0	3,854.2	101,900.0	392.7	0.5	0.2	0.8
07/29/2025 01:00	3,771.7	0.0	3,771.7	101,900.0	384.3	0.5	0.2	0.8
07/29/2025 02:00	4,038.0	0.0	4,038.0	101,900.0	411.5	0.5	0.2	0.8
07/29/2025 03:00	3,764.4	0.0	3,764.4	101,900.0	383.6	0.5	0.2	0.8
07/29/2025 04:00	4,140.0	0.0	4,140.0	101,900.0	421.9	0.5	0.3	0.8
07/29/2025 05:00	4,111.8	0.0	4,111.8	101,900.0	419.0	0.5	0.3	0.8
07/29/2025 06:00	3,670.8	0.0	3,670.8	101,900.0	374.1	0.4	0.2	0.7
07/29/2025 07:00	3,742.0	0.0	3,742.0	101,900.0	381.3	0.5	0.2	0.8
07/29/2025 08:00	3,644.3	7.0	3,644.3	101,900.0	371.4	0.4	0.2	0.7
07/29/2025 09:00	4,157.1	23.6	4,157.1	101,900.0	423.6	0.5	0.3	0.9
07/29/2025 10:00	4,420.4	0.1	4,420.4	101,900.0	450.4	0.5	0.3	0.9
07/29/2025 11:00	4,378.9	70.4	4,378.9	101,900.0	446.2	0.5	0.3	0.9
07/29/2025 12:00	4,421.8	93.8	4,421.8	101,900.0	450.6	0.6	0.3	0.9
07/29/2025 13:00	4,429.4	68.9	4,429.4	101,900.0	451.4	0.5	0.3	0.9
07/29/2025 14:00	4,409.3	14.2	4,409.3	101,900.0	449.3	0.5	0.3	0.9
07/29/2025 15:00	3,846.9	1.1	3,846.9	101,900.0	392.0	0.5	0.2	0.8
07/29/2025 16:00	3,707.6	9.4	3,707.6	101,900.0	377.8	0.5	0.2	0.8
07/29/2025 17:00	3,859.6	12.9	3,859.6	101,900.0	393.3	0.5	0.2	0.8
07/29/2025 18:00	4,314.5	1.8	4,314.5	101,900.0	439.6	0.5	0.3	0.9
07/29/2025 19:00	3,656.7	0.0	3,656.7	101,900.0	372.6	0.4	0.2	0.7
07/29/2025 20:00	3,632.2	0.0	3,632.2	101,900.0	370.1	0.4	0.2	0.7
07/29/2025 21:00	3,899.7	0.0	3,899.7	101,900.0	397.4	0.5	0.2	0.8
07/29/2025 22:00	3,640.2	0.0	3,640.2	101,900.0	370.9	0.4	0.2	0.7
07/29/2025 23:00	3,999.6	0.0	3,999.6	101,900.0	407.6	0.5	0.2	0.8
Average/Sum#:	3,979.6	12.6	3,979.6	101,900.0	405.5	0.5	0.2	0.8
Minimum:	3,632.2	0.0	3,632.2	101,900.0	370.1	0.4	0.2	0.7
Maximum:	4,429.4	93.8	4,429.4	101,900.0	451.4	0.6	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/30/2025 00:00	3,640.0	0.0	3,640.0	101,900.0	370.9	0.4	0.2	0.7
07/30/2025 01:00	3,638.9	0.0	3,638.9	101,900.0	370.8	0.4	0.2	0.7
07/30/2025 02:00	3,642.2	0.0	3,642.2	101,900.0	371.1	0.4	0.2	0.7
07/30/2025 03:00	3,643.3	0.0	3,643.3	101,900.0	371.3	0.4	0.2	0.7
07/30/2025 04:00	3,850.6	0.0	3,850.6	101,900.0	392.4	0.5	0.2	0.8
07/30/2025 05:00	3,829.1	0.0	3,829.1	101,900.0	390.2	0.5	0.2	0.8
07/30/2025 06:00	3,644.9	0.0	3,644.9	101,900.0	371.4	0.4	0.2	0.7
07/30/2025 07:00	3,641.7	0.0	3,641.7	101,900.0	371.1	0.4	0.2	0.7
07/30/2025 08:00	3,635.1	0.0	3,635.1	101,900.0	370.4	0.4	0.2	0.7
07/30/2025 09:00	3,630.0	0.1	3,630.0	101,900.0	369.9	0.4	0.2	0.7
07/30/2025 10:00	3,624.8	0.0	3,624.8	101,900.0	369.4	0.4	0.2	0.7
07/30/2025 11:00	3,619.3	51.3	3,619.3	101,900.0	368.8	0.4	0.2	0.7
07/30/2025 12:00	3,617.6	90.9	3,617.6	101,900.0	368.6	0.5	0.2	0.8
07/30/2025 13:00	3,617.8	67.6	3,617.8	101,900.0	368.7	0.4	0.2	0.8
07/30/2025 14:00	3,612.9	8.6	3,612.9	101,900.0	368.2	0.4	0.2	0.7
07/30/2025 15:00	3,610.9	0.0	3,610.9	101,900.0	368.0	0.4	0.2	0.7
07/30/2025 16:00	3,624.7	0.0	3,624.7	101,900.0	369.4	0.4	0.2	0.7
07/30/2025 17:00	3,757.4	2.5	3,757.4	101,900.0	382.9	0.5	0.2	0.8
07/30/2025 18:00	3,683.3	0.0	3,683.3	101,900.0	375.3	0.4	0.2	0.8
07/30/2025 19:00	3,664.1	0.0	3,664.1	101,900.0	373.4	0.4	0.2	0.7
07/30/2025 20:00	3,631.6	0.0	3,631.6	101,900.0	370.1	0.4	0.2	0.7
07/30/2025 21:00	3,637.0	0.0	3,637.0	101,900.0	370.6	0.4	0.2	0.7
07/30/2025 22:00	3,639.2	0.0	3,639.2	101,900.0	370.8	0.4	0.2	0.7
07/30/2025 23:00	3,641.3	0.0	3,641.3	101,900.0	371.0	0.4	0.2	0.7
Average/Sum#:	3,657.4	9.2	3,657.4	101,900.0	372.7	0.4	0.2	0.7
Minimum:	3,610.9	0.0	3,610.9	101,900.0	368.0	0.4	0.2	0.7
Maximum:	3,850.6	90.9	3,850.6	101,900.0	392.4	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/31/2025 00:00	3,642.8	0.0	3,642.8	101,900.0	371.2	0.4	0.2	0.7
07/31/2025 01:00	3,641.8	0.0	3,641.8	101,900.0	371.1	0.4	0.2	0.7
07/31/2025 02:00	3,643.3	0.0	3,643.3	101,900.0	371.3	0.4	0.2	0.7
07/31/2025 03:00	3,645.8	0.0	3,645.8	101,900.0	371.5	0.4	0.2	0.7
07/31/2025 04:00	3,646.9	0.0	3,646.9	101,900.0	371.6	0.4	0.2	0.7
07/31/2025 05:00	3,648.1	0.0	3,648.1	101,900.0	371.7	0.4	0.2	0.7
07/31/2025 06:00	3,647.6	0.0	3,647.6	101,900.0	371.7	0.4	0.2	0.7
07/31/2025 07:00	3,645.2	0.0	3,645.2	101,900.0	371.4	0.4	0.2	0.7
07/31/2025 08:00	3,645.3	0.1	3,645.3	101,900.0	371.5	0.4	0.2	0.7
07/31/2025 09:00	3,638.1	0.2	3,638.1	101,900.0	370.7	0.4	0.2	0.7
07/31/2025 10:00	3,632.1	0.0	3,632.1	101,900.0	370.1	0.4	0.2	0.7
07/31/2025 11:00	3,625.7	57.7	3,625.7	101,900.0	369.5	0.4	0.2	0.8
07/31/2025 12:00	3,658.2	89.0	3,658.2	101,900.0	372.8	0.5	0.2	0.8
07/31/2025 13:00	3,981.4	69.8	3,981.4	101,900.0	405.7	0.5	0.2	0.8
07/31/2025 14:00	4,224.9	15.9	4,224.9	101,900.0	430.5	0.5	0.3	0.9
07/31/2025 15:00	4,409.6	0.0	4,409.6	101,900.0	449.3	0.5	0.3	0.9
07/31/2025 16:00	3,608.6	1.5	3,608.6	101,900.0	367.7	0.4	0.2	0.7
07/31/2025 17:00	3,851.0	12.2	3,851.0	101,900.0	392.4	0.5	0.2	0.8
07/31/2025 18:00	4,172.7	5.8	4,172.7	101,900.0	425.2	0.5	0.3	0.9
07/31/2025 19:00	3,816.8	0.0	3,816.8	101,900.0	388.9	0.5	0.2	0.8
07/31/2025 20:00	4,147.8	0.0	4,147.8	101,900.0	422.7	0.5	0.3	0.8
07/31/2025 21:00	4,343.9	0.0	4,343.9	101,900.0	442.6	0.5	0.3	0.9
07/31/2025 22:00	4,435.0	0.0	4,435.0	101,900.0	451.9	0.5	0.3	0.9
07/31/2025 23:00	3,672.5	0.0	3,672.5	101,900.0	374.2	0.4	0.2	0.7
Average/Sum#:	3,834.4	10.5	3,834.4	101,900.0	390.7	0.4	0.2	0.8
Minimum:	3,608.6	0.0	3,608.6	101,900.0	367.7	0.4	0.2	0.7
Maximum:	4,435.0	89.0	4,435.0	101,900.0	451.9	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/01/2025 00:00	3,638.0	0.0	3,638.0	101,900.0	370.7	0.4	0.2	0.7
08/01/2025 01:00	3,643.9	0.0	3,643.9	101,900.0	371.3	0.4	0.2	0.7
08/01/2025 02:00	3,646.0	0.0	3,646.0	101,900.0	371.5	0.4	0.2	0.7
08/01/2025 03:00	3,648.6	0.0	3,648.6	101,900.0	371.8	0.4	0.2	0.7
08/01/2025 04:00	3,682.6	0.0	3,682.6	101,900.0	375.3	0.5	0.2	0.7
08/01/2025 05:00	3,707.7	0.0	3,707.7	101,900.0	377.8	0.5	0.2	0.8
08/01/2025 06:00	3,645.6	0.0	3,645.6	101,900.0	371.5	0.4	0.2	0.7
08/01/2025 07:00	3,645.0	0.0	3,645.0	101,900.0	371.4	0.4	0.2	0.7
08/01/2025 08:00	3,642.1	0.0	3,642.1	101,900.0	371.1	0.4	0.2	0.7
08/01/2025 09:00	3,637.0	0.0	3,637.0	101,900.0	370.6	0.4	0.2	0.7
08/01/2025 10:00	3,628.8	0.1	3,628.8	101,900.0	369.8	0.4	0.2	0.7
08/01/2025 11:00	3,625.8	66.8	3,625.8	101,900.0	369.5	0.5	0.2	0.8
08/01/2025 12:00	3,621.2	96.0	3,621.2	101,900.0	369.0	0.5	0.2	0.8
08/01/2025 13:00	3,918.5	76.3	3,918.5	101,900.0	399.3	0.5	0.2	0.8
08/01/2025 14:00	4,300.1	24.7	4,300.1	101,900.0	438.2	0.5	0.3	0.9
08/01/2025 15:00	3,670.5	0.1	3,670.5	101,900.0	374.0	0.4	0.2	0.7
08/01/2025 16:00	3,604.2	8.1	3,604.2	101,900.0	367.3	0.4	0.2	0.7
08/01/2025 17:00	3,873.0	10.4	3,873.0	101,900.0	394.7	0.5	0.2	0.8
08/01/2025 18:00	4,209.3	3.5	4,209.3	101,900.0	428.9	0.5	0.3	0.9
08/01/2025 19:00	3,645.9	0.0	3,645.9	101,900.0	371.5	0.4	0.2	0.7
08/01/2025 20:00	3,638.3	0.0	3,638.3	101,900.0	370.7	0.4	0.2	0.7
08/01/2025 21:00	3,861.8	0.0	3,861.8	101,900.0	393.5	0.5	0.2	0.8
08/01/2025 22:00	3,814.6	0.0	3,814.6	101,900.0	388.7	0.5	0.2	0.8
08/01/2025 23:00	4,064.5	0.0	4,064.5	101,900.0	414.2	0.5	0.2	0.8
Average/Sum#:	3,750.5	11.9	3,750.5	101,900.0	382.2	0.4	0.2	0.8
Minimum:	3,604.2	0.0	3,604.2	101,900.0	367.3	0.4	0.2	0.7
Maximum:	4,300.1	96.0	4,300.1	101,900.0	438.2	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/02/2025 00:00	3,653.4	0.0	3,653.4	101,900.0	372.3	0.4	0.2	0.7
08/02/2025 01:00	4,065.1	0.0	4,065.1	101,900.0	414.2	0.5	0.2	0.8
08/02/2025 02:00	3,655.7	0.0	3,655.7	105,600.0	386.0	0.5	0.2	0.8
08/02/2025 03:00	3,656.8	0.0	3,656.8	105,600.0	386.2	0.5	0.2	0.8
08/02/2025 04:00	3,655.8	0.0	3,655.8	105,600.0	386.1	0.5	0.2	0.8
08/02/2025 05:00	3,660.3	0.0	3,660.3	105,600.0	386.5	0.5	0.2	0.8
08/02/2025 06:00	3,680.9	0.0	3,680.9	105,600.0	388.7	0.5	0.2	0.8
08/02/2025 07:00	3,653.8	0.0	3,653.8	105,600.0	385.8	0.5	0.2	0.8
08/02/2025 08:00	3,651.7	1.7	3,651.7	105,600.0	385.6	0.5	0.2	0.8
08/02/2025 09:00	3,646.5	4.8	3,646.5	105,600.0	385.1	0.5	0.2	0.8
08/02/2025 10:00	3,641.1	1.2	3,641.1	105,600.0	384.5	0.5	0.2	0.8
08/02/2025 11:00	3,633.6	68.1	3,633.6	105,600.0	383.7	0.5	0.2	0.8
08/02/2025 12:00	3,629.3	90.6	3,629.3	105,600.0	383.3	0.5	0.2	0.8
08/02/2025 13:00	3,625.0	65.2	3,625.0	105,600.0	382.8	0.5	0.2	0.8
08/02/2025 14:00	3,621.1	10.7	3,621.1	105,600.0	382.4	0.5	0.2	0.8
08/02/2025 15:00	3,620.9	0.0	3,620.9	105,600.0	382.4	0.5	0.2	0.8
08/02/2025 16:00	3,613.9	0.2	3,613.9	105,600.0	381.6	0.5	0.2	0.8
08/02/2025 17:00	3,700.9	7.0	3,700.9	105,600.0	390.8	0.5	0.2	0.8
08/02/2025 18:00	3,615.3	4.2	3,615.3	105,600.0	381.8	0.5	0.2	0.8
08/02/2025 19:00	3,625.7	0.0	3,625.7	105,600.0	382.9	0.5	0.2	0.8
08/02/2025 20:00	3,630.2	0.0	3,630.2	105,600.0	383.3	0.5	0.2	0.8
08/02/2025 21:00	3,633.0	0.0	3,633.0	105,600.0	383.6	0.5	0.2	0.8
08/02/2025 22:00	3,637.1	0.0	3,637.1	105,600.0	384.1	0.5	0.2	0.8
08/02/2025 23:00	3,641.6	0.0	3,641.6	105,600.0	384.6	0.5	0.2	0.8
Average/Sum#:	3,660.4	10.6	3,660.4	105,291.7	385.3	0.5	0.2	0.8
Minimum:	3,613.9	0.0	3,613.9	101,900.0	372.3	0.4	0.2	0.7
Maximum:	4,065.1	90.6	4,065.1	105,600.0	414.2	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/03/2025 00:00	3,639.4	0.0	3,639.4	105,600.0	384.3	0.5	0.2	0.8
08/03/2025 01:00	3,645.3	0.0	3,645.3	105,600.0	384.9	0.5	0.2	0.8
08/03/2025 02:00	3,649.4	0.0	3,649.4	105,600.0	385.4	0.5	0.2	0.8
08/03/2025 03:00	3,647.6	0.0	3,647.6	105,600.0	385.2	0.5	0.2	0.8
08/03/2025 04:00	3,647.5	0.0	3,647.5	105,600.0	385.2	0.5	0.2	0.8
08/03/2025 05:00	3,651.7	0.0	3,651.7	105,600.0	385.6	0.5	0.2	0.8
08/03/2025 06:00	3,648.1	0.0	3,648.1	105,600.0	385.2	0.5	0.2	0.8
08/03/2025 07:00	3,643.5	0.0	3,643.5	105,600.0	384.8	0.5	0.2	0.8
08/03/2025 08:00	3,641.7	0.0	3,641.7	105,600.0	384.6	0.5	0.2	0.8
08/03/2025 09:00	3,636.8	0.0	3,636.8	105,600.0	384.0	0.5	0.2	0.8
08/03/2025 10:00	3,629.1	0.0	3,629.1	105,600.0	383.2	0.5	0.2	0.8
08/03/2025 11:00	3,628.1	61.4	3,628.1	105,600.0	383.1	0.5	0.2	0.8
08/03/2025 12:00	3,622.9	83.4	3,622.9	105,600.0	382.6	0.5	0.2	0.8
08/03/2025 13:00	3,617.6	64.3	3,617.6	105,600.0	382.0	0.5	0.2	0.8
08/03/2025 14:00	3,614.7	9.7	3,614.7	105,600.0	381.7	0.5	0.2	0.8
08/03/2025 15:00	3,616.0	0.0	3,616.0	105,600.0	381.8	0.5	0.2	0.8
08/03/2025 16:00	3,611.5	0.0	3,611.5	105,600.0	381.4	0.5	0.2	0.8
08/03/2025 17:00	3,873.3	0.0	3,873.3	105,600.0	409.0	0.5	0.2	0.8
08/03/2025 18:00	3,647.4	0.0	3,647.4	105,600.0	385.2	0.5	0.2	0.8
08/03/2025 19:00	3,628.2	0.0	3,628.2	105,600.0	383.1	0.5	0.2	0.8
08/03/2025 20:00	3,632.0	0.0	3,632.0	105,600.0	383.5	0.5	0.2	0.8
08/03/2025 21:00	3,637.3	0.0	3,637.3	105,600.0	384.1	0.5	0.2	0.8
08/03/2025 22:00	3,636.0	0.0	3,636.0	105,600.0	384.0	0.5	0.2	0.8
08/03/2025 23:00	3,637.9	0.0	3,637.9	105,600.0	384.2	0.5	0.2	0.8
Average/Sum#:	3,645.1	9.1	3,645.1	105,600.0	384.9	0.5	0.2	0.8
Minimum:	3,611.5	0.0	3,611.5	105,600.0	381.4	0.5	0.2	0.8
Maximum:	3,873.3	83.4	3,873.3	105,600.0	409.0	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/04/2025 00:00	3,637.0	0.0	3,637.0	105,600.0	384.1	0.5	0.2	0.8
08/04/2025 01:00	3,636.6	0.0	3,636.6	105,600.0	384.0	0.5	0.2	0.8
08/04/2025 02:00	3,644.0	0.0	3,644.0	105,600.0	384.8	0.5	0.2	0.8
08/04/2025 03:00	3,642.5	0.0	3,642.5	105,600.0	384.6	0.5	0.2	0.8
08/04/2025 04:00	3,642.4	0.0	3,642.4	105,600.0	384.6	0.5	0.2	0.8
08/04/2025 05:00	3,649.7	0.0	3,649.7	105,600.0	385.4	0.5	0.2	0.8
08/04/2025 06:00	4,383.2	0.0	4,383.2	105,600.0	462.9	0.6	0.3	0.9
08/04/2025 07:00	3,722.7	0.0	3,722.7	105,600.0	393.1	0.5	0.2	0.8
08/04/2025 08:00	3,633.2	0.0	3,633.2	105,600.0	383.7	0.5	0.2	0.8
08/04/2025 09:00	3,631.8	0.0	3,631.8	105,600.0	383.5	0.5	0.2	0.8
08/04/2025 10:00	3,629.2	0.0	3,629.2	105,600.0	383.2	0.5	0.2	0.8
08/04/2025 11:00	3,622.9	58.0	3,622.9	105,600.0	382.6	0.5	0.2	0.8
08/04/2025 12:00	3,620.8	71.8	3,620.8	105,600.0	382.4	0.5	0.2	0.8
08/04/2025 13:00	3,618.2	48.0	3,618.2	105,600.0	382.1	0.5	0.2	0.8
08/04/2025 14:00	3,624.0	1.4	3,624.0	105,600.0	382.7	0.5	0.2	0.8
08/04/2025 15:00	3,617.4	0.0	3,617.4	105,600.0	382.0	0.5	0.2	0.8
08/04/2025 16:00	3,611.4	0.0	3,611.4	105,600.0	381.4	0.5	0.2	0.8
08/04/2025 17:00	3,822.9	0.0	3,822.9	105,600.0	403.7	0.5	0.2	0.8
08/04/2025 18:00	3,638.2	0.0	3,638.2	105,600.0	384.2	0.5	0.2	0.8
08/04/2025 19:00	3,624.4	0.0	3,624.4	105,600.0	382.7	0.5	0.2	0.8
08/04/2025 20:00	3,628.8	0.0	3,628.8	105,600.0	383.2	0.5	0.2	0.8
08/04/2025 21:00	3,632.1	0.0	3,632.1	105,600.0	383.5	0.5	0.2	0.8
08/04/2025 22:00	3,637.0	0.0	3,637.0	105,600.0	384.1	0.5	0.2	0.8
08/04/2025 23:00	3,635.6	0.0	3,635.6	105,600.0	383.9	0.5	0.2	0.8
Average/Sum#:	3,674.4	7.5	3,674.4	105,600.0	388.0	0.5	0.2	0.8
Minimum:	3,611.4	0.0	3,611.4	105,600.0	381.4	0.5	0.2	0.8
Maximum:	4,383.2	71.8	4,383.2	105,600.0	462.9	0.6	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/05/2025 00:00	3,639.6	0.0	3,639.6	105,600.0	384.3	0.5	0.2	0.8			
08/05/2025 01:00	3,640.7	0.0	3,640.7	105,600.0	384.5	0.5	0.2	0.8			
08/05/2025 02:00	3,640.1	0.0	3,640.1	105,600.0	384.4	0.5	0.2	0.8			
08/05/2025 03:00	3,643.5	0.0	3,643.5	105,600.0	384.8	0.5	0.2	0.8			
08/05/2025 04:00	3,646.9	0.0	3,646.9	105,600.0	385.1	0.5	0.2	0.8			
08/05/2025 05:00	4,030.0	0.0	4,030.0	105,600.0	425.6	0.5	0.3	0.9			
08/05/2025 06:00	3,865.9	0.0	3,865.9	105,600.0	408.2	0.5	0.2	0.8			
08/05/2025 07:00	3,644.5	0.0	3,644.5	105,600.0	384.9	0.5	0.2	0.8			
08/05/2025 08:00	3,639.6	0.0	3,639.6	105,600.0	384.3	0.5	0.2	0.8			
08/05/2025 09:00	3,632.2	0.0	3,632.2	105,600.0	383.6	0.5	0.2	0.8			
08/05/2025 10:00	3,631.0	0.0	3,631.0	105,600.0	383.4	0.5	0.2	0.8			
08/05/2025 11:00	3,627.6	61.9	3,627.6	105,600.0	383.1	0.5	0.2	0.8			
08/05/2025 12:00	3,625.8	82.3	3,625.8	105,600.0	382.9	0.5	0.2	0.8			
08/05/2025 13:00	3,621.0	57.5	3,621.0	105,600.0	382.4	0.5	0.2	0.8			
08/05/2025 14:00	3,618.9	0.0	3,618.9	105,600.0	382.2	0.5	0.2	0.8			
08/05/2025 15:00	3,617.8	0.0	3,617.8	105,600.0	382.0	0.5	0.2	0.8			
08/05/2025 16:00	3,740.1	0.0	3,740.1	105,600.0	395.0	0.5	0.2	0.8			
08/05/2025 17:00	3,912.7	0.1	3,912.7	105,600.0	413.2	0.5	0.2	0.8			
08/05/2025 18:00	4,418.1	0.0	4,418.1	105,600.0	466.6	0.6	0.3	0.9			
08/05/2025 19:00	4,283.1	0.0	4,283.1	105,600.0	452.3	0.5	0.3	0.9			
08/05/2025 20:00	4,300.6	0.0	4,300.6	105,600.0	454.1	0.5	0.3	0.9			
08/05/2025 21:00	4,423.7	0.0	4,423.7	105,600.0	467.1	0.6	0.3	0.9			
08/05/2025 22:00	4,231.0	0.0	4,231.0	105,600.0	446.8	0.5	0.3	0.9			
08/05/2025 23:00	3,629.5	0.0	3,629.5	105,600.0	383.3	0.5	0.2	0.8			
Average/Sum#:	3,821.0	8.4	3,821.0	105,600.0	403.5	0.5	0.2	0.8			
Minimum:	3,617.8	0.0	3,617.8	105,600.0	382.0	0.5	0.2	0.8			
Maximum:	4,423.7	82.3	4,423.7	105,600.0	467.1	0.6	0.3	0.9			
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/06/2025 00:00	3,635.1	0.0	3,635.1	105,600.0	383.9	0.5	0.2	0.8
08/06/2025 01:00	3,636.0	0.0	3,636.0	105,600.0	384.0	0.5	0.2	0.8
08/06/2025 02:00	3,637.0	0.0	3,637.0	105,600.0	384.1	0.5	0.2	0.8
08/06/2025 03:00	3,636.5	0.0	3,636.5	105,600.0	384.0	0.5	0.2	0.8
08/06/2025 04:00	3,636.5	0.0	3,636.5	105,600.0	384.0	0.5	0.2	0.8
08/06/2025 05:00	3,890.0	0.0	3,890.0	105,600.0	410.8	0.5	0.2	0.8
08/06/2025 06:00	4,342.8	0.0	4,342.8	105,600.0	458.6	0.5	0.3	0.9
08/06/2025 07:00	3,751.2	0.0	3,751.2	105,600.0	396.1	0.5	0.2	0.8
08/06/2025 08:00	3,631.0	0.0	3,631.0	105,600.0	383.4	0.5	0.2	0.8
08/06/2025 09:00	3,629.6	0.0	3,629.6	105,600.0	383.3	0.5	0.2	0.8
08/06/2025 10:00	3,623.2	0.0	3,623.2	105,600.0	382.6	0.5	0.2	0.8
08/06/2025 11:00	3,615.9	48.9	3,615.9	105,600.0	381.8	0.5	0.2	0.8
08/06/2025 12:00	3,615.9	72.8	3,615.9	105,600.0	381.8	0.5	0.2	0.8
08/06/2025 13:00	3,615.1	35.3	3,615.1	105,600.0	381.8	0.5	0.2	0.8
08/06/2025 14:00	3,615.5	0.0	3,615.5	105,600.0	381.8	0.5	0.2	0.8
08/06/2025 15:00	3,609.6	0.0	3,609.6	105,600.0	381.2	0.5	0.2	0.8
08/06/2025 16:00	3,645.8	0.0	3,645.8	105,600.0	385.0	0.5	0.2	0.8
08/06/2025 17:00	3,826.4	0.1	3,826.4	105,600.0	404.1	0.5	0.2	0.8
08/06/2025 18:00	4,181.4	0.0	4,181.4	105,600.0	441.6	0.5	0.3	0.9
08/06/2025 19:00	3,759.9	0.0	3,759.9	105,600.0	397.0	0.5	0.2	0.8
08/06/2025 20:00	3,680.7	0.0	3,680.7	105,600.0	388.7	0.5	0.2	0.8
08/06/2025 21:00	3,851.5	0.0	3,851.5	105,600.0	406.7	0.5	0.2	0.8
08/06/2025 22:00	3,911.6	0.0	3,911.6	105,600.0	413.1	0.5	0.2	0.8
08/06/2025 23:00	4,280.1	0.0	4,280.1	105,600.0	452.0	0.5	0.3	0.9
Average/Sum#:	3,760.8	6.5	3,760.8	105,600.0	397.1	0.5	0.2	0.8
Minimum:	3,609.6	0.0	3,609.6	105,600.0	381.2	0.5	0.2	0.8
Maximum:	4,342.8	72.8	4,342.8	105,600.0	458.6	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/07/2025 00:00	3,972.1	0.0	3,972.1	105,600.0	419.5	0.5	0.3	0.8
08/07/2025 01:00	3,854.6	0.0	3,854.6	105,600.0	407.0	0.5	0.2	0.8
08/07/2025 02:00	3,646.3	0.0	3,646.3	105,600.0	385.0	0.5	0.2	0.8
08/07/2025 03:00	3,646.2	0.0	3,646.2	105,600.0	385.0	0.5	0.2	0.8
08/07/2025 04:00	3,763.3	0.0	3,763.3	105,600.0	397.4	0.5	0.2	0.8
08/07/2025 05:00	3,952.6	0.0	3,952.6	105,600.0	417.4	0.5	0.3	0.8
08/07/2025 06:00	3,649.3	0.0	3,649.3	105,600.0	385.4	0.5	0.2	0.8
08/07/2025 07:00	3,646.0	0.0	3,646.0	105,600.0	385.0	0.5	0.2	0.8
08/07/2025 08:00	3,645.1	5.7	3,645.1	105,600.0	384.9	0.5	0.2	0.8
08/07/2025 09:00	3,643.4	0.4	3,643.4	105,600.0	384.7	0.5	0.2	0.8
08/07/2025 10:00	3,640.5	0.0	3,640.5	105,600.0	384.4	0.5	0.2	0.8
08/07/2025 11:00	3,636.9	65.8	3,636.9	105,600.0	384.1	0.5	0.2	0.8
08/07/2025 12:00	3,636.7	88.3	3,636.7	105,600.0	384.0	0.5	0.2	0.8
08/07/2025 13:00	3,632.2	63.7	3,632.2	105,600.0	383.6	0.5	0.2	0.8
08/07/2025 14:00	3,902.1	2.0	3,902.1	105,600.0	412.1	0.5	0.2	0.8
08/07/2025 15:00	3,846.6	0.0	3,846.6	105,600.0	406.2	0.5	0.2	0.8
08/07/2025 16:00	3,621.4	0.0	3,621.4	105,600.0	382.4	0.5	0.2	0.8
08/07/2025 17:00	3,778.8	1.7	3,778.8	105,600.0	399.0	0.5	0.2	0.8
08/07/2025 18:00	4,091.3	1.4	4,091.3	105,600.0	432.0	0.5	0.3	0.9
08/07/2025 19:00	3,847.6	0.0	3,847.6	105,600.0	406.3	0.5	0.2	0.8
08/07/2025 20:00	3,731.0	0.0	3,731.0	105,600.0	394.0	0.5	0.2	0.8
08/07/2025 21:00	3,620.3	0.0	3,620.3	105,600.0	382.3	0.5	0.2	0.8
08/07/2025 22:00	3,619.5	0.0	3,619.5	105,600.0	382.2	0.5	0.2	0.8
08/07/2025 23:00	3,622.3	0.0	3,622.3	105,600.0	382.5	0.5	0.2	0.8
Average/Sum#:	3,735.3	9.5	3,735.3	105,600.0	394.4	0.5	0.2	0.8
Minimum:	3,619.5	0.0	3,619.5	105,600.0	382.2	0.5	0.2	0.8
Maximum:	4,091.3	88.3	4,091.3	105,600.0	432.0	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/08/2025 00:00	3,626.4	0.0	3,626.4	105,600.0	382.9	0.5	0.2	0.8
08/08/2025 01:00	3,628.2	0.0	3,628.2	105,600.0	383.1	0.5	0.2	0.8
08/08/2025 02:00	3,628.4	0.0	3,628.4	105,600.0	383.2	0.5	0.2	0.8
08/08/2025 03:00	3,629.2	0.0	3,629.2	105,600.0	383.2	0.5	0.2	0.8
08/08/2025 04:00	3,636.2	0.0	3,636.2	105,600.0	384.0	0.5	0.2	0.8
08/08/2025 05:00	3,857.9	0.0	3,857.9	105,600.0	407.4	0.5	0.2	0.8
08/08/2025 06:00	3,635.1	0.0	3,635.1	105,600.0	383.9	0.5	0.2	0.8
08/08/2025 07:00	3,630.7	0.0	3,630.7	105,600.0	383.4	0.5	0.2	0.8
08/08/2025 08:00	3,626.2	0.0	3,626.2	105,600.0	382.9	0.5	0.2	0.8
08/08/2025 09:00	3,617.8	0.6	3,617.8	105,600.0	382.0	0.5	0.2	0.8
08/08/2025 10:00	3,615.4	0.0	3,615.4	105,600.0	381.8	0.5	0.2	0.8
08/08/2025 11:00	3,612.7	62.8	3,612.7	105,600.0	381.5	0.5	0.2	0.8
08/08/2025 12:00	3,605.0	84.5	3,605.0	105,600.0	380.7	0.5	0.2	0.8
08/08/2025 13:00	3,678.6	66.4	3,678.6	105,600.0	388.5	0.5	0.2	0.8
08/08/2025 14:00	3,696.1	7.6	3,696.1	105,600.0	390.3	0.5	0.2	0.8
08/08/2025 15:00	3,627.7	0.0	3,627.7	105,600.0	383.1	0.5	0.2	0.8
08/08/2025 16:00	3,901.7	0.0	3,901.7	105,600.0	412.0	0.5	0.2	0.8
08/08/2025 17:00	3,938.3	10.8	3,938.3	105,600.0	415.9	0.5	0.3	0.8
08/08/2025 18:00	3,652.7	13.4	3,652.7	105,600.0	385.7	0.5	0.2	0.8
08/08/2025 19:00	3,641.7	0.0	3,641.7	105,600.0	384.6	0.5	0.2	0.8
08/08/2025 20:00	3,772.3	0.0	3,772.3	105,600.0	398.4	0.5	0.2	0.8
08/08/2025 21:00	3,642.5	0.0	3,642.5	105,600.0	384.6	0.5	0.2	0.8
08/08/2025 22:00	3,623.0	0.0	3,623.0	105,600.0	382.6	0.5	0.2	0.8
08/08/2025 23:00	3,615.3	0.0	3,615.3	105,600.0	381.8	0.5	0.2	0.8
Average/Sum#:	3,672.5	10.3	3,672.5	105,600.0	387.8	0.5	0.2	0.8
Minimum:	3,605.0	0.0	3,605.0	105,600.0	380.7	0.5	0.2	0.8
Maximum:	3,938.3	84.5	3,938.3	105,600.0	415.9	0.5	0.3	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/09/2025 00:00	3,620.7	0.0	3,620.7	105,600.0	382.3	0.5	0.2	0.8
08/09/2025 01:00	3,621.5	0.0	3,621.5	105,600.0	382.4	0.5	0.2	0.8
08/09/2025 02:00	3,623.5	0.0	3,623.5	105,600.0	382.6	0.5	0.2	0.8
08/09/2025 03:00	3,623.9	0.0	3,623.9	105,600.0	382.7	0.5	0.2	0.8
08/09/2025 04:00	3,625.9	0.0	3,625.9	105,600.0	382.9	0.5	0.2	0.8
08/09/2025 05:00	3,630.0	0.0	3,630.0	105,600.0	383.3	0.5	0.2	0.8
08/09/2025 06:00	3,626.8	0.0	3,626.8	105,600.0	383.0	0.5	0.2	0.8
08/09/2025 07:00	3,621.5	3.0	3,621.5	105,600.0	382.4	0.5	0.2	0.8
08/09/2025 08:00	3,617.7	41.3	3,617.7	105,600.0	382.0	0.5	0.2	0.8
08/09/2025 09:00	3,612.8	2.9	3,612.8	105,600.0	381.5	0.5	0.2	0.8
08/09/2025 10:00	3,609.9	0.0	3,609.9	105,600.0	381.2	0.5	0.2	0.8
08/09/2025 11:00	3,606.6	64.0	3,606.6	105,600.0	380.9	0.5	0.2	0.8
08/09/2025 12:00	3,596.5	97.1	3,596.5	105,600.0	379.8	0.5	0.2	0.8
08/09/2025 13:00	3,591.1	69.3	3,591.1	105,600.0	379.2	0.5	0.2	0.8
08/09/2025 14:00	3,636.7	32.7	3,636.7	105,600.0	384.0	0.5	0.2	0.8
08/09/2025 15:00	3,587.5	8.0	3,587.5	105,600.0	378.8	0.5	0.2	0.8
08/09/2025 16:00	3,860.3	7.2	3,860.3	105,600.0	407.6	0.5	0.2	0.8
08/09/2025 17:00	3,633.5	20.7	3,633.5	105,600.0	383.7	0.5	0.2	0.8
08/09/2025 18:00	3,591.4	24.7	3,591.4	105,600.0	379.3	0.5	0.2	0.8
08/09/2025 19:00	3,915.9	0.0	3,915.9	105,600.0	413.5	0.5	0.2	0.8
08/09/2025 20:00	3,637.0	0.0	3,637.0	105,600.0	384.1	0.5	0.2	0.8
08/09/2025 21:00	3,608.1	0.0	3,608.1	105,600.0	381.0	0.5	0.2	0.8
08/09/2025 22:00	3,611.9	0.0	3,611.9	105,600.0	381.4	0.5	0.2	0.8
08/09/2025 23:00	3,612.8	0.0	3,612.8	105,600.0	381.5	0.5	0.2	0.8
Average/Sum#:	3,638.5	15.5	3,638.5	105,600.0	384.2	0.5	0.2	0.8
Minimum:	3,587.5	0.0	3,587.5	105,600.0	378.8	0.5	0.2	0.8
Maximum:	3,915.9	97.1	3,915.9	105,600.0	413.5	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/10/2025 00:00	3,615.2	0.0	3,615.2	105,600.0	381.8	0.5	0.2	0.8
08/10/2025 01:00	3,616.9	0.0	3,616.9	105,600.0	381.9	0.5	0.2	0.8
08/10/2025 02:00	3,620.0	0.0	3,620.0	105,600.0	382.3	0.5	0.2	0.8
08/10/2025 03:00	3,621.2	0.0	3,621.2	105,600.0	382.4	0.5	0.2	0.8
08/10/2025 04:00	3,624.8	0.0	3,624.8	105,600.0	382.8	0.5	0.2	0.8
08/10/2025 05:00	3,627.8	0.0	3,627.8	105,600.0	383.1	0.5	0.2	0.8
08/10/2025 06:00	3,627.6	0.0	3,627.6	105,600.0	383.1	0.5	0.2	0.8
08/10/2025 07:00	3,621.3	0.0	3,621.3	105,600.0	382.4	0.5	0.2	0.8
08/10/2025 08:00	3,614.4	25.8	3,614.4	105,600.0	381.7	0.5	0.2	0.8
08/10/2025 09:00	3,611.2	2.2	3,611.2	105,600.0	381.3	0.5	0.2	0.8
08/10/2025 10:00	3,606.5	0.0	3,606.5	105,600.0	380.8	0.5	0.2	0.8
08/10/2025 11:00	3,602.1	61.7	3,602.1	105,600.0	380.4	0.5	0.2	0.8
08/10/2025 12:00	3,590.9	82.3	3,590.9	105,600.0	379.2	0.5	0.2	0.8
08/10/2025 13:00	4,071.2	71.8	4,071.2	105,600.0	429.9	0.5	0.3	0.9
08/10/2025 14:00	4,406.7	24.4	4,406.7	105,600.0	465.3	0.6	0.3	0.9
08/10/2025 15:00	3,949.1	4.9	3,949.1	105,600.0	417.0	0.5	0.3	0.8
08/10/2025 16:00	4,000.8	1.2	4,000.8	105,600.0	422.5	0.5	0.3	0.8
08/10/2025 17:00	4,000.6	28.4	4,000.6	105,600.0	422.5	0.5	0.3	0.9
08/10/2025 18:00	4,430.7	11.7	4,430.7	105,600.0	467.9	0.6	0.3	0.9
08/10/2025 19:00	3,958.8	0.0	3,958.8	105,600.0	418.0	0.5	0.3	0.8
08/10/2025 20:00	3,727.2	0.0	3,727.2	105,600.0	393.6	0.5	0.2	0.8
08/10/2025 21:00	3,849.2	0.0	3,849.2	105,600.0	406.5	0.5	0.2	0.8
08/10/2025 22:00	3,638.8	0.0	3,638.8	105,600.0	384.3	0.5	0.2	0.8
08/10/2025 23:00	3,637.4	0.0	3,637.4	105,600.0	384.1	0.5	0.2	0.8
Average/Sum#:	3,777.9	13.1	3,777.9	105,600.0	399.0	0.5	0.2	0.8
Minimum:	3,590.9	0.0	3,590.9	105,600.0	379.2	0.5	0.2	0.8
Maximum:	4,430.7	82.3	4,430.7	105,600.0	467.9	0.6	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/11/2025 00:00	3,616.7	0.0	3,616.7	105,600.0	381.9	0.5	0.2	0.8
08/11/2025 01:00	3,613.6	0.0	3,613.6	105,600.0	381.6	0.5	0.2	0.8
08/11/2025 02:00	3,611.3	0.0	3,611.3	105,600.0	381.4	0.5	0.2	0.8
08/11/2025 03:00	3,614.4	0.0	3,614.4	105,600.0	381.7	0.5	0.2	0.8
08/11/2025 04:00	3,863.2	0.0	3,863.2	105,600.0	408.0	0.5	0.2	0.8
08/11/2025 05:00	4,113.3	0.0	4,113.3	105,600.0	434.4	0.5	0.3	0.9
08/11/2025 06:00	3,618.3	0.0	3,618.3	105,600.0	382.1	0.5	0.2	0.8
08/11/2025 07:00	3,617.0	0.0	3,617.0	105,600.0	382.0	0.5	0.2	0.8
08/11/2025 08:00	3,610.5	0.0	3,610.5	105,600.0	381.3	0.5	0.2	0.8
08/11/2025 09:00	3,606.6	0.0	3,606.6	105,600.0	380.9	0.5	0.2	0.8
08/11/2025 10:00	3,599.7	0.0	3,599.7	105,600.0	380.1	0.5	0.2	0.8
08/11/2025 11:00	3,595.9	60.4	3,595.9	105,600.0	379.7	0.5	0.2	0.8
08/11/2025 12:00	3,592.3	85.4	3,592.3	105,600.0	379.3	0.5	0.2	0.8
08/11/2025 13:00	3,679.4	63.3	3,679.4	105,600.0	388.5	0.5	0.2	0.8
08/11/2025 14:00	3,913.1	5.3	3,913.1	105,600.0	413.2	0.5	0.2	0.8
08/11/2025 15:00	3,605.8	0.0	3,605.8	105,600.0	380.8	0.5	0.2	0.8
08/11/2025 16:00	3,816.1	0.0	3,816.1	105,600.0	403.0	0.5	0.2	0.8
08/11/2025 17:00	4,040.2	0.4	4,040.2	105,600.0	426.6	0.5	0.3	0.9
08/11/2025 18:00	4,351.5	0.0	4,351.5	105,600.0	459.5	0.6	0.3	0.9
08/11/2025 19:00	4,218.5	0.0	4,218.5	105,600.0	445.5	0.5	0.3	0.9
08/11/2025 20:00	4,340.9	0.0	4,340.9	105,600.0	458.4	0.5	0.3	0.9
08/11/2025 21:00	4,336.4	0.0	4,336.4	105,600.0	457.9	0.6	0.3	0.9
08/11/2025 22:00	4,103.7	0.0	4,103.7	105,600.0	433.4	0.5	0.3	0.9
08/11/2025 23:00	4,024.3	0.1	4,024.3	105,600.0	425.0	0.5	0.3	0.8
Average/Sum#:	3,837.6	9.0	3,837.6	105,600.0	405.3	0.5	0.2	0.8
Minimum:	3,592.3	0.0	3,592.3	105,600.0	379.3	0.5	0.2	0.8
Maximum:	4,351.5	85.4	4,351.5	105,600.0	459.5	0.6	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/12/2025 00:00	4,124.1	0.0	4,124.1	105,600.0	435.5	0.5	0.3	0.3	0.9	0.9
08/12/2025 01:00	4,022.5	0.0	4,022.5	105,600.0	424.8	0.5	0.3	0.3	0.8	0.8
08/12/2025 02:00	3,685.3	0.0	3,685.3	105,600.0	389.2	0.5	0.2	0.2	0.8	0.8
08/12/2025 03:00	3,788.3	0.0	3,788.3	105,600.0	400.0	0.5	0.2	0.2	0.8	0.8
08/12/2025 04:00	4,145.8	0.0	4,145.8	105,600.0	437.8	0.5	0.3	0.3	0.9	0.9
08/12/2025 05:00	4,332.2	0.0	4,332.2	105,600.0	457.5	0.5	0.3	0.3	0.9	0.9
08/12/2025 06:00	3,776.1	0.0	3,776.1	105,600.0	398.8	0.5	0.2	0.2	0.8	0.8
08/12/2025 07:00	3,643.4	0.0	3,643.4	105,600.0	384.7	0.5	0.2	0.2	0.8	0.8
08/12/2025 08:00	3,636.3	0.0	3,636.3	105,600.0	384.0	0.5	0.2	0.2	0.8	0.8
08/12/2025 09:00	3,632.4	0.0	3,632.4	105,600.0	383.6	0.5	0.2	0.2	0.8	0.8
08/12/2025 10:00	3,625.4	0.0	3,625.4	105,600.0	382.8	0.5	0.2	0.2	0.8	0.8
08/12/2025 11:00	3,621.9	57.0	3,621.9	105,600.0	382.5	0.5	0.2	0.2	0.8	0.8
08/12/2025 12:00	3,613.0	63.6	3,613.0	105,600.0	381.5	0.5	0.2	0.2	0.8	0.8
08/12/2025 13:00	3,781.9	45.6	3,781.9	105,600.0	399.4	0.5	0.2	0.2	0.8	0.8
08/12/2025 14:00	4,146.4	0.0	4,146.4	105,600.0	437.9	0.5	0.3	0.3	0.9	0.9
08/12/2025 15:00	4,099.5	0.0	4,099.5	105,600.0	432.9	0.5	0.3	0.3	0.9	0.9
08/12/2025 16:00	4,204.2	0.0	4,204.2	105,600.0	444.0	0.5	0.3	0.3	0.9	0.9
08/12/2025 17:00	4,477.9	0.0	4,477.9	105,600.0	472.9	0.6	0.3	0.3	0.9	0.9
08/12/2025 18:00	4,388.9	0.0	4,388.9	105,600.0	463.5	0.6	0.3	0.3	0.9	0.9
08/12/2025 19:00	4,358.0	0.0	4,358.0	105,600.0	460.2	0.6	0.3	0.3	0.9	0.9
08/12/2025 20:00	4,112.8	0.0	4,112.8	105,600.0	434.3	0.5	0.3	0.3	0.9	0.9
08/12/2025 21:00	3,961.2	0.0	3,961.2	105,600.0	418.3	0.5	0.3	0.3	0.8	0.8
08/12/2025 22:00	3,992.8	0.0	3,992.8	105,600.0	421.6	0.5	0.3	0.3	0.8	0.8
08/12/2025 23:00	3,643.6	0.0	3,643.6	105,600.0	384.8	0.5	0.2	0.2	0.8	0.8
Average/Sum#:	3,950.6	6.9	3,950.6	105,600.0	417.2	0.5	0.3	0.3	0.8	0.8
Minimum:	3,613.0	0.0	3,613.0	105,600.0	381.5	0.5	0.2	0.2	0.8	0.8
Maximum:	4,477.9	63.6	4,477.9	105,600.0	472.9	0.6	0.3	0.3	0.9	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/13/2025 00:00	3,650.4	0.0	3,650.4	105,600.0	385.5	0.5	0.2	0.2	0.8	0.8
08/13/2025 01:00	3,651.1	0.0	3,651.1	105,600.0	385.6	0.5	0.2	0.2	0.8	0.8
08/13/2025 02:00	3,651.5	0.0	3,651.5	105,600.0	385.6	0.5	0.2	0.2	0.8	0.8
08/13/2025 03:00	3,653.6	0.0	3,653.6	105,600.0	385.8	0.5	0.2	0.2	0.8	0.8
08/13/2025 04:00	3,651.5	0.0	3,651.5	105,600.0	385.6	0.5	0.2	0.2	0.8	0.8
08/13/2025 05:00	3,653.0	0.0	3,653.0	105,600.0	385.8	0.5	0.2	0.2	0.8	0.8
08/13/2025 06:00	3,655.6	0.0	3,655.6	105,600.0	386.0	0.5	0.2	0.2	0.8	0.8
08/13/2025 07:00	3,654.3	0.0	3,654.3	105,600.0	385.9	0.5	0.2	0.2	0.8	0.8
08/13/2025 08:00	3,651.5	0.0	3,651.5	105,600.0	385.6	0.5	0.2	0.2	0.8	0.8
08/13/2025 09:00	3,649.3	0.0	3,649.3	105,600.0	385.4	0.5	0.2	0.2	0.8	0.8
08/13/2025 10:00	3,645.2	0.0	3,645.2	105,600.0	384.9	0.5	0.2	0.2	0.8	0.8
08/13/2025 11:00	3,642.9	48.6	3,642.9	105,600.0	384.7	0.5	0.2	0.2	0.8	0.8
08/13/2025 12:00	3,634.8	36.6	3,634.8	105,600.0	383.8	0.5	0.2	0.2	0.8	0.8
08/13/2025 13:00	3,624.8	46.2	3,624.8	105,600.0	382.8	0.5	0.2	0.2	0.8	0.8
08/13/2025 14:00	3,615.8	0.0	3,615.8	105,600.0	381.8	0.5	0.2	0.2	0.8	0.8
08/13/2025 15:00	3,614.8	0.0	3,614.8	105,600.0	381.7	0.5	0.2	0.2	0.8	0.8
08/13/2025 16:00	3,614.9	0.0	3,614.9	105,600.0	381.7	0.5	0.2	0.2	0.8	0.8
08/13/2025 17:00	3,758.8	0.0	3,758.8	105,600.0	396.9	0.5	0.2	0.2	0.8	0.8
08/13/2025 18:00	3,619.8	0.0	3,619.8	105,600.0	382.3	0.5	0.2	0.2	0.8	0.8
08/13/2025 19:00	3,622.0	0.0	3,622.0	105,600.0	382.5	0.5	0.2	0.2	0.8	0.8
08/13/2025 20:00	3,625.0	0.0	3,625.0	105,600.0	382.8	0.5	0.2	0.2	0.8	0.8
08/13/2025 21:00	3,624.0	0.0	3,624.0	105,600.0	382.7	0.5	0.2	0.2	0.8	0.8
08/13/2025 22:00	3,630.5	0.0	3,630.5	105,600.0	383.4	0.5	0.2	0.2	0.8	0.8
08/13/2025 23:00	3,640.3	0.0	3,640.3	105,600.0	384.4	0.5	0.2	0.2	0.8	0.8
Average/Sum#:	3,643.1	5.5	3,643.1	105,600.0	384.7	0.5	0.2	0.2	0.8	0.8
Minimum:	3,614.8	0.0	3,614.8	105,600.0	381.7	0.5	0.2	0.2	0.8	0.8
Maximum:	3,758.8	48.6	3,758.8	105,600.0	396.9	0.5	0.2	0.2	0.8	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/14/2025 00:00	3,643.3	0.0	3,643.3	105,600.0	384.7	0.5	0.2	0.8
08/14/2025 01:00	3,647.2	0.0	3,647.2	105,600.0	385.1	0.5	0.2	0.8
08/14/2025 02:00	3,645.1	0.0	3,645.1	105,600.0	384.9	0.5	0.2	0.8
08/14/2025 03:00	3,649.1	0.0	3,649.1	105,600.0	385.3	0.5	0.2	0.8
08/14/2025 04:00	3,653.0	0.0	3,653.0	105,600.0	385.8	0.5	0.2	0.8
08/14/2025 05:00	3,656.2	0.0	3,656.2	105,600.0	386.1	0.5	0.2	0.8
08/14/2025 06:00	3,658.1	0.0	3,658.1	105,600.0	386.3	0.5	0.2	0.8
08/14/2025 07:00	3,655.7	0.0	3,655.7	105,600.0	386.0	0.5	0.2	0.8
08/14/2025 08:00	3,655.8	0.0	3,655.8	105,600.0	386.1	0.5	0.2	0.8
08/14/2025 09:00	3,645.4	0.0	3,645.4	105,600.0	385.0	0.5	0.2	0.8
08/14/2025 10:00	3,637.9	0.0	3,637.9	105,600.0	384.2	0.5	0.2	0.8
08/14/2025 11:00	3,630.5	67.6	3,630.5	105,600.0	383.4	0.5	0.2	0.8
08/14/2025 12:00	3,624.0	50.3	3,624.0	105,600.0	382.7	0.5	0.2	0.8
08/14/2025 13:00	3,621.2	45.4	3,621.2	105,600.0	382.4	0.5	0.2	0.8
08/14/2025 14:00	3,619.7	0.0	3,619.7	105,600.0	382.2	0.5	0.2	0.8
08/14/2025 15:00	3,616.6	0.0	3,616.6	105,600.0	381.9	0.5	0.2	0.8
08/14/2025 16:00	3,611.4	0.0	3,611.4	105,600.0	381.4	0.5	0.2	0.8
08/14/2025 17:00	3,699.6	0.0	3,699.6	105,600.0	390.7	0.5	0.2	0.8
08/14/2025 18:00	3,609.3	0.0	3,609.3	105,600.0	381.1	0.5	0.2	0.8
08/14/2025 19:00	3,618.2	0.0	3,618.2	105,600.0	382.1	0.5	0.2	0.8
08/14/2025 20:00	3,623.2	0.0	3,623.2	105,600.0	382.6	0.5	0.2	0.8
08/14/2025 21:00	3,628.6	0.0	3,628.6	105,600.0	383.2	0.5	0.2	0.8
08/14/2025 22:00	3,628.8	0.0	3,628.8	105,600.0	383.2	0.5	0.2	0.8
08/14/2025 23:00	3,625.4	0.0	3,625.4	105,600.0	382.8	0.5	0.2	0.8
Average/Sum#:	3,637.6	6.8	3,637.6	105,600.0	384.1	0.5	0.2	0.8
Minimum:	3,609.3	0.0	3,609.3	105,600.0	381.1	0.5	0.2	0.8
Maximum:	3,699.6	67.6	3,699.6	105,600.0	390.7	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/15/2025 00:00	3,627.8	0.0	3,627.8	105,600.0	383.1	0.5	0.2	0.8
08/15/2025 01:00	3,627.5	0.0	3,627.5	105,600.0	383.1	0.5	0.2	0.8
08/15/2025 02:00	3,629.4	0.0	3,629.4	105,600.0	383.3	0.5	0.2	0.8
08/15/2025 03:00	3,633.8	0.0	3,633.8	105,600.0	383.7	0.5	0.2	0.8
08/15/2025 04:00	3,635.9	0.0	3,635.9	105,600.0	384.0	0.5	0.2	0.8
08/15/2025 05:00	3,690.4	0.0	3,690.4	105,600.0	389.7	0.5	0.2	0.8
08/15/2025 06:00	3,773.6	0.0	3,773.6	105,600.0	398.5	0.5	0.2	0.8
08/15/2025 07:00	3,636.2	0.0	3,636.2	105,600.0	384.0	0.5	0.2	0.8
08/15/2025 08:00	3,633.3	0.0	3,633.3	105,600.0	383.7	0.5	0.2	0.8
08/15/2025 09:00	3,626.5	0.0	3,626.5	105,600.0	383.0	0.5	0.2	0.8
08/15/2025 10:00	3,625.1	0.0	3,625.1	105,600.0	382.8	0.5	0.2	0.8
08/15/2025 11:00	3,616.0	45.1	3,616.0	105,600.0	381.8	0.5	0.2	0.8
08/15/2025 12:00	3,610.5	39.9	3,610.5	105,600.0	381.3	0.5	0.2	0.8
08/15/2025 13:00	3,606.1	45.1	3,606.1	105,600.0	380.8	0.5	0.2	0.8
08/15/2025 14:00	3,601.6	0.0	3,601.6	105,600.0	380.3	0.5	0.2	0.8
08/15/2025 15:00	3,600.3	0.0	3,600.3	105,600.0	380.2	0.5	0.2	0.8
08/15/2025 16:00	3,604.5	0.0	3,604.5	105,600.0	380.6	0.5	0.2	0.8
08/15/2025 17:00	3,610.1	0.8	3,610.1	105,600.0	381.2	0.5	0.2	0.8
08/15/2025 18:00	3,616.3	0.0	3,616.3	105,600.0	381.9	0.5	0.2	0.8
08/15/2025 19:00	3,633.8	0.0	3,633.8	105,600.0	383.7	0.5	0.2	0.8
08/15/2025 20:00	3,638.7	0.0	3,638.7	105,600.0	384.2	0.5	0.2	0.8
08/15/2025 21:00	3,641.6	0.0	3,641.6	105,600.0	384.6	0.5	0.2	0.8
08/15/2025 22:00	3,645.5	0.0	3,645.5	105,600.0	385.0	0.5	0.2	0.8
08/15/2025 23:00	3,761.8	0.0	3,761.8	105,600.0	397.2	0.5	0.2	0.8
Average/Sum#:	3,638.6	5.5	3,638.6	105,600.0	384.2	0.5	0.2	0.8
Minimum:	3,600.3	0.0	3,600.3	105,600.0	380.2	0.5	0.2	0.8
Maximum:	3,773.6	45.1	3,773.6	105,600.0	398.5	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/16/2025 00:00	4,285.0	0.0	4,285.0	105,600.0	452.5	0.5	0.3	0.9
08/16/2025 01:00	3,651.2	0.0	3,651.2	105,600.0	385.6	0.5	0.2	0.8
08/16/2025 02:00	3,654.3	0.0	3,654.3	105,600.0	385.9	0.5	0.2	0.8
08/16/2025 03:00	3,654.4	0.0	3,654.4	105,600.0	385.9	0.5	0.2	0.8
08/16/2025 04:00	3,654.7	0.0	3,654.7	105,600.0	385.9	0.5	0.2	0.8
08/16/2025 05:00	3,655.7	0.0	3,655.7	105,600.0	386.0	0.5	0.2	0.8
08/16/2025 06:00	3,656.9	0.0	3,656.9	105,600.0	386.2	0.5	0.2	0.8
08/16/2025 07:00	3,654.3	0.0	3,654.3	105,600.0	385.9	0.5	0.2	0.8
08/16/2025 08:00	3,653.5	0.0	3,653.5	105,600.0	385.8	0.5	0.2	0.8
08/16/2025 09:00	3,648.9	0.0	3,648.9	105,600.0	385.3	0.5	0.2	0.8
08/16/2025 10:00	3,643.7	0.0	3,643.7	105,600.0	384.8	0.5	0.2	0.8
08/16/2025 11:00	3,640.6	46.9	3,640.6	105,600.0	384.4	0.5	0.2	0.8
08/16/2025 12:00	3,638.4	26.1	3,638.4	105,600.0	384.2	0.5	0.2	0.8
08/16/2025 13:00	3,637.0	36.1	3,637.0	105,600.0	384.1	0.5	0.2	0.8
08/16/2025 14:00	3,871.1	0.0	3,871.1	105,600.0	408.8	0.5	0.2	0.8
08/16/2025 15:00	3,637.2	0.0	3,637.2	105,600.0	384.1	0.5	0.2	0.8
08/16/2025 16:00	3,634.9	0.0	3,634.9	105,600.0	383.8	0.5	0.2	0.8
08/16/2025 17:00	3,718.0	0.0	3,718.0	105,600.0	392.6	0.5	0.2	0.8
08/16/2025 18:00	3,674.7	0.0	3,674.7	105,600.0	388.0	0.5	0.2	0.8
08/16/2025 19:00	3,867.2	0.0	3,867.2	105,600.0	408.4	0.5	0.2	0.8
08/16/2025 20:00	3,634.2	0.0	3,634.2	105,600.0	383.8	0.5	0.2	0.8
08/16/2025 21:00	3,654.7	0.0	3,654.7	105,600.0	385.9	0.5	0.2	0.8
08/16/2025 22:00	3,665.4	0.0	3,665.4	105,600.0	387.1	0.5	0.2	0.8
08/16/2025 23:00	4,218.7	0.0	4,218.7	105,600.0	445.5	0.5	0.3	0.9
Average/Sum#:	3,721.0	4.5	3,721.0	105,600.0	392.9	0.5	0.2	0.8
Minimum:	3,634.2	0.0	3,634.2	105,600.0	383.8	0.5	0.2	0.8
Maximum:	4,285.0	46.9	4,285.0	105,600.0	452.5	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/17/2025 00:00	3,624.6	0.0	3,624.6	105,600.0	382.8	0.5	0.2	0.8
08/17/2025 01:00	3,628.6	0.0	3,628.6	105,600.0	383.2	0.5	0.2	0.8
08/17/2025 02:00	3,625.8	0.0	3,625.8	105,600.0	382.9	0.5	0.2	0.8
08/17/2025 03:00	3,626.6	0.0	3,626.6	105,600.0	383.0	0.5	0.2	0.8
08/17/2025 04:00	3,627.4	0.0	3,627.4	105,600.0	383.1	0.5	0.2	0.8
08/17/2025 05:00	3,631.9	0.0	3,631.9	105,600.0	383.5	0.5	0.2	0.8
08/17/2025 06:00	3,635.7	0.0	3,635.7	105,600.0	383.9	0.5	0.2	0.8
08/17/2025 07:00	3,633.8	0.0	3,633.8	105,600.0	383.7	0.5	0.2	0.8
08/17/2025 08:00	3,630.0	0.0	3,630.0	105,600.0	383.3	0.5	0.2	0.8
08/17/2025 09:00	3,627.9	0.0	3,627.9	105,600.0	383.1	0.5	0.2	0.8
08/17/2025 10:00	3,631.7	0.0	3,631.7	105,600.0	383.5	0.5	0.2	0.8
08/17/2025 11:00	3,634.0	35.2	3,634.0	105,600.0	383.8	0.5	0.2	0.8
08/17/2025 12:00	3,631.6	19.8	3,631.6	105,600.0	383.5	0.5	0.2	0.8
08/17/2025 13:00	3,631.6	25.4	3,631.6	105,600.0	383.5	0.5	0.2	0.8
08/17/2025 14:00	3,630.1	0.0	3,630.1	105,600.0	383.3	0.5	0.2	0.8
08/17/2025 15:00	3,626.5	0.0	3,626.5	105,600.0	383.0	0.5	0.2	0.8
08/17/2025 16:00	3,763.4	0.0	3,763.4	105,600.0	397.4	0.5	0.2	0.8
08/17/2025 17:00	4,172.2	0.0	4,172.2	105,600.0	440.6	0.5	0.3	0.9
08/17/2025 18:00	4,455.3	0.0	4,455.3	105,600.0	470.5	0.6	0.3	0.9
08/17/2025 19:00	4,455.6	0.0	4,455.6	105,600.0	470.5	0.6	0.3	0.9
08/17/2025 20:00	4,448.6	0.0	4,448.6	105,600.0	469.8	0.6	0.3	0.9
08/17/2025 21:00	4,449.7	0.0	4,449.7	105,600.0	469.9	0.6	0.3	0.9
08/17/2025 22:00	4,445.6	0.0	4,445.6	105,600.0	469.5	0.6	0.3	0.9
08/17/2025 23:00	4,369.4	0.0	4,369.4	105,600.0	461.4	0.6	0.3	0.9
Average/Sum#:	3,859.9	3.4	3,859.9	105,600.0	407.6	0.5	0.2	0.8
Minimum:	3,624.6	0.0	3,624.6	105,600.0	382.8	0.5	0.2	0.8
Maximum:	4,455.6	35.2	4,455.6	105,600.0	470.5	0.6	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/18/2025 00:00	3,663.2	0.0	3,663.2	105,600.0	386.8	0.5	0.2	0.8
08/18/2025 01:00	3,661.3	0.0	3,661.3	105,600.0	386.6	0.5	0.2	0.8
08/18/2025 02:00	3,663.1	0.0	3,663.1	105,600.0	386.8	0.5	0.2	0.8
08/18/2025 03:00	3,662.9	0.0	3,662.9	105,600.0	386.8	0.5	0.2	0.8
08/18/2025 04:00	3,829.0	0.0	3,829.0	105,600.0	404.3	0.5	0.2	0.8
08/18/2025 05:00	4,234.8	0.0	4,234.8	105,600.0	447.2	0.5	0.3	0.9
08/18/2025 06:00	3,664.6	0.0	3,664.6	105,600.0	387.0	0.5	0.2	0.8
08/18/2025 07:00	3,664.0	0.0	3,664.0	105,600.0	386.9	0.5	0.2	0.8
08/18/2025 08:00	3,662.8	0.0	3,662.8	105,600.0	386.8	0.5	0.2	0.8
08/18/2025 09:00	3,660.0	0.0	3,660.0	105,600.0	386.5	0.5	0.2	0.8
08/18/2025 10:00	3,655.5	0.0	3,655.5	105,600.0	386.0	0.5	0.2	0.8
08/18/2025 11:00	4,379.1	29.6	4,379.1	105,600.0	462.4	0.6	0.3	0.9
08/18/2025 12:00	4,407.6	27.3	4,407.6	105,600.0	465.4	0.6	0.3	0.9
08/18/2025 13:00	4,442.8	25.4	4,442.8	105,600.0	469.2	0.6	0.3	0.9
08/18/2025 14:00	4,453.4	0.0	4,453.4	105,600.0	470.3	0.6	0.3	0.9
08/18/2025 15:00	4,471.5	0.0	4,471.5	105,600.0	472.2	0.6	0.3	0.9
08/18/2025 16:00	4,024.8	0.0	4,024.8	105,600.0	425.0	0.5	0.3	0.9
08/18/2025 17:00	4,048.0	0.0	4,048.0	105,600.0	427.5	0.5	0.3	0.9
08/18/2025 18:00	4,477.2	0.0	4,477.2	105,600.0	472.8	0.6	0.3	0.9
08/18/2025 19:00	4,470.8	0.0	4,470.8	105,600.0	472.1	0.6	0.3	0.9
08/18/2025 20:00	4,458.2	0.0	4,458.2	105,600.0	470.8	0.6	0.3	0.9
08/18/2025 21:00	4,328.1	0.0	4,328.1	105,600.0	457.0	0.5	0.3	0.9
08/18/2025 22:00	4,072.2	0.0	4,072.2	105,600.0	430.0	0.5	0.3	0.9
08/18/2025 23:00	3,765.4	0.0	3,765.4	105,600.0	397.6	0.5	0.2	0.8
Average/Sum#:	4,034.2	3.4	4,034.2	105,600.0	426.0	0.5	0.3	0.9
Minimum:	3,655.5	0.0	3,655.5	105,600.0	386.0	0.5	0.2	0.8
Maximum:	4,477.2	29.6	4,477.2	105,600.0	472.8	0.6	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/19/2025 00:00	3,657.0	0.0	3,657.0	105,600.0	386.2	0.5	0.2	0.2	0.8	0.8
08/19/2025 01:00	3,661.6	0.0	3,661.6	105,600.0	386.7	0.5	0.2	0.2	0.8	0.8
08/19/2025 02:00	3,663.3	0.0	3,663.3	105,600.0	386.8	0.5	0.2	0.2	0.8	0.8
08/19/2025 03:00	3,661.3	0.0	3,661.3	105,600.0	386.6	0.5	0.2	0.2	0.8	0.8
08/19/2025 04:00	3,886.6	0.0	3,886.6	105,600.0	410.4	0.5	0.2	0.2	0.8	0.8
08/19/2025 05:00	3,925.3	0.0	3,925.3	105,600.0	414.5	0.5	0.2	0.2	0.8	0.8
08/19/2025 06:00	3,810.6	0.0	3,810.6	105,600.0	402.4	0.5	0.2	0.2	0.8	0.8
08/19/2025 07:00	3,664.6	0.0	3,664.6	105,600.0	387.0	0.5	0.2	0.2	0.8	0.8
08/19/2025 08:00	3,659.0	0.0	3,659.0	105,600.0	386.4	0.5	0.2	0.2	0.8	0.8
08/19/2025 09:00	3,655.7	0.0	3,655.7	105,600.0	386.0	0.5	0.2	0.2	0.8	0.8
08/19/2025 10:00	3,651.1	0.0	3,651.1	105,600.0	385.6	0.5	0.2	0.2	0.8	0.8
08/19/2025 11:00	3,813.5	1.3	3,813.5	105,600.0	402.7	0.5	0.2	0.2	0.8	0.8
08/19/2025 12:00	4,457.1	21.6	4,457.1	105,600.0	470.7	0.6	0.3	0.3	0.9	0.9
08/19/2025 13:00	4,450.4	29.4	4,450.4	105,600.0	470.0	0.6	0.3	0.3	0.9	0.9
08/19/2025 14:00	4,439.6	0.0	4,439.6	105,600.0	468.8	0.6	0.3	0.3	0.9	0.9
08/19/2025 15:00	4,437.5	0.0	4,437.5	105,600.0	468.6	0.6	0.3	0.3	0.9	0.9
08/19/2025 16:00	4,313.0	0.0	4,313.0	105,600.0	455.5	0.5	0.3	0.3	0.9	0.9
08/19/2025 17:00	4,050.4	0.0	4,050.4	105,600.0	427.7	0.5	0.3	0.3	0.9	0.9
08/19/2025 18:00	4,447.4	0.0	4,447.4	105,600.0	469.6	0.6	0.3	0.3	0.9	0.9
08/19/2025 19:00	4,443.5	0.0	4,443.5	105,600.0	469.2	0.6	0.3	0.3	0.9	0.9
08/19/2025 20:00	4,453.4	0.0	4,453.4	105,600.0	470.3	0.6	0.3	0.3	0.9	0.9
08/19/2025 21:00	4,455.5	0.0	4,455.5	105,600.0	470.5	0.6	0.3	0.3	0.9	0.9
08/19/2025 22:00	4,392.6	0.0	4,392.6	105,600.0	463.9	0.6	0.3	0.3	0.9	0.9
08/19/2025 23:00	4,149.5	0.0	4,149.5	105,600.0	438.2	0.5	0.3	0.3	0.9	0.9
Average/Sum#:	4,050.0	2.2	4,050.0	105,600.0	427.7	0.5	0.3	0.3	0.9	0.9
Minimum:	3,651.1	0.0	3,651.1	105,600.0	385.6	0.5	0.2	0.2	0.8	0.8
Maximum:	4,457.1	29.4	4,457.1	105,600.0	470.7	0.6	0.3	0.3	0.9	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/20/2025 00:00	3,725.6	0.0	3,725.6	105,600.0	393.4	0.5	0.2	0.2	0.8	0.8
08/20/2025 01:00	3,671.9	0.0	3,671.9	105,600.0	387.8	0.5	0.2	0.2	0.8	0.8
08/20/2025 02:00	3,665.6	0.0	3,665.6	105,600.0	387.1	0.5	0.2	0.2	0.8	0.8
08/20/2025 03:00	3,664.7	0.0	3,664.7	105,600.0	387.0	0.5	0.2	0.2	0.8	0.8
08/20/2025 04:00	3,714.1	0.0	3,714.1	105,600.0	392.2	0.5	0.2	0.2	0.8	0.8
08/20/2025 05:00	4,020.4	0.0	4,020.4	105,600.0	424.6	0.5	0.3	0.3	0.8	0.8
08/20/2025 06:00	4,273.0	0.1	4,273.0	105,600.0	451.2	0.5	0.3	0.3	0.9	0.9
08/20/2025 07:00	4,195.0	0.0	4,195.0	105,600.0	443.0	0.5	0.3	0.3	0.9	0.9
08/20/2025 08:00	4,480.9	0.0	4,480.9	105,600.0	473.2	0.6	0.3	0.3	0.9	0.9
08/20/2025 09:00	4,484.6	0.0	4,484.6	105,600.0	473.6	0.6	0.3	0.3	0.9	0.9
08/20/2025 10:00	4,507.7	0.0	4,507.7	105,600.0	476.0	0.6	0.3	0.3	1.0	1.0
08/20/2025 11:00	4,469.1	0.0	4,469.1	105,600.0	471.9	0.6	0.3	0.3	0.9	0.9
08/20/2025 12:00	4,438.6	9.6	4,438.6	105,600.0	468.7	0.6	0.3	0.3	0.9	0.9
08/20/2025 13:00	4,538.8	149.1	4,573.1	105,600.0	482.9	0.6	0.3	0.3	1.0	1.0
08/20/2025 14:00	4,648.3	1,463.4	6,111.7	105,600.0	645.4	0.8	0.4	0.4	1.3	1.3
08/20/2025 15:00	4,625.9	921.8	5,547.7	105,600.0	585.8	0.7	0.4	0.4	1.2	1.2
08/20/2025 16:00	4,619.2	661.4	5,280.6	105,600.0	557.6	0.7	0.3	0.3	1.1	1.1
08/20/2025 17:00	4,617.6	874.9	5,492.5	105,600.0	580.0	0.7	0.3	0.3	1.2	1.2
08/20/2025 18:00	4,631.5	1,356.4	5,987.9	105,600.0	632.3	0.8	0.4	0.4	1.3	1.3
08/20/2025 19:00	4,662.5	592.8	5,255.3	105,600.0	555.0	0.7	0.3	0.3	1.1	1.1
08/20/2025 20:00	4,688.7	550.6	5,239.3	105,600.0	553.3	0.7	0.3	0.3	1.1	1.1
08/20/2025 21:00	4,693.8	533.3	5,227.1	105,600.0	552.0	0.7	0.3	0.3	1.1	1.1
08/20/2025 22:00	4,469.2	4.6	4,469.3	105,600.0	472.0	0.6	0.3	0.3	0.9	0.9
08/20/2025 23:00	4,389.9	0.0	4,389.9	105,600.0	463.6	0.6	0.3	0.3	0.9	0.9
Average/Sum#:	4,329.0	296.6	4,620.2	105,600.0	487.9	0.6	0.3	0.3	1.0	1.0
Minimum:	3,664.7	0.0	3,664.7	105,600.0	387.0	0.5	0.2	0.2	0.8	0.8
Maximum:	4,693.8	1,463.4	6,111.7	105,600.0	645.4	0.8	0.4	0.4	1.3	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/21/2025 00:00	4,396.4	0.0	4,396.4	105,600.0	464.3	0.6	0.3	0.3	0.9	0.9
08/21/2025 01:00	4,294.8	0.0	4,294.8	105,600.0	453.5	0.5	0.3	0.3	0.9	0.9
08/21/2025 02:00	4,442.3	0.0	4,442.3	105,600.0	469.1	0.6	0.3	0.3	0.9	0.9
08/21/2025 03:00	4,513.4	119.2	4,540.8	105,600.0	479.5	0.6	0.3	0.3	1.0	1.0
08/21/2025 04:00	4,662.3	1,105.6	5,767.9	105,600.0	609.1	0.7	0.4	0.4	1.2	1.2
08/21/2025 05:00	4,701.2	1,361.9	6,063.1	105,600.0	640.3	0.8	0.4	0.4	1.3	1.3
08/21/2025 06:00	4,661.3	590.4	5,115.9	105,600.0	540.2	0.7	0.3	0.3	1.1	1.1
08/21/2025 07:00	3,668.1	0.0	3,668.1	105,600.0	387.4	0.5	0.2	0.2	0.8	0.8
08/21/2025 08:00	3,639.0	0.0	3,639.0	105,600.0	384.3	0.5	0.2	0.2	0.8	0.8
08/21/2025 09:00	3,629.0	0.0	3,629.0	105,600.0	383.2	0.5	0.2	0.2	0.8	0.8
08/21/2025 10:00	3,665.1	0.0	3,665.1	105,600.0	387.0	0.5	0.2	0.2	0.8	0.8
08/21/2025 11:00	4,139.5	0.1	4,139.5	105,600.0	437.1	0.5	0.3	0.3	0.9	0.9
08/21/2025 12:00	4,599.3	731.5	5,133.3	105,600.0	542.1	0.7	0.3	0.3	1.1	1.1
08/21/2025 13:00	4,629.8	1,681.0	6,310.8	105,600.0	666.4	0.8	0.4	0.4	1.3	1.3
08/21/2025 14:00	4,613.8	1,753.4	6,367.2	105,600.0	672.4	0.8	0.4	0.4	1.3	1.3
08/21/2025 15:00	4,620.2	1,561.3	6,181.5	105,600.0	652.8	0.8	0.4	0.4	1.3	1.3
08/21/2025 16:00	4,602.2	1,201.3	5,803.5	105,600.0	612.8	0.7	0.4	0.4	1.2	1.2
08/21/2025 17:00	4,606.3	1,156.1	5,762.4	105,600.0	608.5	0.7	0.4	0.4	1.2	1.2
08/21/2025 18:00	4,605.4	1,830.5	6,435.9	105,600.0	679.6	0.8	0.4	0.4	1.4	1.4
08/21/2025 19:00	4,641.2	1,380.2	6,021.4	105,600.0	635.9	0.8	0.4	0.4	1.3	1.3
08/21/2025 20:00	4,662.2	1,503.6	6,165.8	105,600.0	651.1	0.8	0.4	0.4	1.3	1.3
08/21/2025 21:00	4,678.0	1,206.0	5,884.0	105,600.0	621.4	0.7	0.4	0.4	1.2	1.2
08/21/2025 22:00	4,710.6	766.9	5,477.5	105,600.0	578.4	0.7	0.3	0.3	1.2	1.2
08/21/2025 23:00	4,729.9	879.9	5,609.8	105,600.0	592.4	0.7	0.4	0.4	1.2	1.2
Average/Sum#:	4,421.3	784.5	5,188.1	105,600.0	547.9	0.7	0.3	0.3	1.1	1.1
Minimum:	3,629.0	0.0	3,629.0	105,600.0	383.2	0.5	0.2	0.2	0.8	0.8
Maximum:	4,729.9	1,830.5	6,435.9	105,600.0	679.6	0.8	0.4	0.4	1.4	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/22/2025 00:00	4,750.8	471.7	5,222.5	105,600.0	551.5	0.7	0.3	0.3	1.1	1.1
08/22/2025 01:00	4,439.6	248.3	4,571.2	105,600.0	482.7	0.6	0.3	0.3	1.0	1.0
08/22/2025 02:00	3,643.5	0.0	3,643.5	105,600.0	384.8	0.5	0.2	0.2	0.8	0.8
08/22/2025 03:00	3,647.2	0.0	3,647.2	105,600.0	385.1	0.5	0.2	0.2	0.8	0.8
08/22/2025 04:00	4,197.2	123.4	4,225.6	105,600.0	446.2	0.5	0.3	0.3	0.9	0.9
08/22/2025 05:00	4,682.5	500.1	5,182.6	105,600.0	547.3	0.7	0.3	0.3	1.1	1.1
08/22/2025 06:00	4,418.2	340.4	4,646.3	105,600.0	490.6	0.6	0.3	0.3	1.0	1.0
08/22/2025 07:00	3,640.5	0.0	3,640.5	105,600.0	384.4	0.5	0.2	0.2	0.8	0.8
08/22/2025 08:00	3,633.4	0.0	3,633.4	105,600.0	383.7	0.5	0.2	0.2	0.8	0.8
08/22/2025 09:00	3,622.2	0.0	3,622.2	105,600.0	382.5	0.5	0.2	0.2	0.8	0.8
08/22/2025 10:00	3,621.0	0.0	3,621.0	105,600.0	382.4	0.5	0.2	0.2	0.8	0.8
08/22/2025 11:00	4,015.4	0.3	4,015.4	105,600.0	424.0	0.5	0.3	0.3	0.8	0.8
08/22/2025 12:00	4,075.3	34.5	4,075.3	105,600.0	430.4	0.5	0.3	0.3	0.9	0.9
08/22/2025 13:00	4,572.8	191.9	4,616.9	105,600.0	487.5	0.6	0.3	0.3	1.0	1.0
08/22/2025 14:00	4,575.2	1,720.7	6,295.9	105,600.0	664.8	0.8	0.4	0.4	1.3	1.3
08/22/2025 15:00	4,581.8	1,555.9	6,137.7	105,600.0	648.1	0.8	0.4	0.4	1.3	1.3
08/22/2025 16:00	4,579.6	1,831.1	6,410.7	105,600.0	677.0	0.8	0.4	0.4	1.4	1.4
08/22/2025 17:00	4,592.9	1,872.0	6,464.9	105,600.0	682.7	0.8	0.4	0.4	1.4	1.4
08/22/2025 18:00	4,608.3	1,547.9	6,156.2	105,600.0	650.1	0.8	0.4	0.4	1.3	1.3
08/22/2025 19:00	4,637.2	1,431.1	6,068.3	105,600.0	640.8	0.8	0.4	0.4	1.3	1.3
08/22/2025 20:00	4,676.8	1,723.0	6,399.8	105,600.0	675.8	0.8	0.4	0.4	1.4	1.4
08/22/2025 21:00	4,682.3	1,830.2	6,512.5	105,600.0	687.7	0.8	0.4	0.4	1.4	1.4
08/22/2025 22:00	4,683.3	1,674.2	6,357.5	105,600.0	671.4	0.8	0.4	0.4	1.3	1.3
08/22/2025 23:00	4,676.2	1,262.5	5,938.7	105,600.0	627.1	0.8	0.4	0.4	1.3	1.3
Average/Sum#:	4,302.2	765.0	5,046.1	105,600.0	532.9	0.7	0.3	0.3	1.1	1.1
Minimum:	3,621.0	0.0	3,621.0	105,600.0	382.4	0.5	0.2	0.2	0.8	0.8
Maximum:	4,750.8	1,872.0	6,512.5	105,600.0	687.7	0.8	0.4	0.4	1.4	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/23/2025 00:00	4,505.8	773.3	5,279.1	105,600.0	557.5	0.7	0.3	0.3	1.1	1.1
08/23/2025 01:00	4,521.7	733.7	5,255.4	105,600.0	555.0	0.7	0.3	0.3	1.1	1.1
08/23/2025 02:00	4,544.5	704.9	5,249.4	105,600.0	554.3	0.7	0.3	0.3	1.1	1.1
08/23/2025 03:00	4,557.9	675.1	5,233.0	105,600.0	552.6	0.7	0.3	0.3	1.1	1.1
08/23/2025 04:00	4,594.2	605.5	5,199.7	105,600.0	549.1	0.7	0.3	0.3	1.1	1.1
08/23/2025 05:00	4,633.2	1,024.3	5,657.5	105,600.0	597.4	0.7	0.4	0.4	1.2	1.2
08/23/2025 06:00	4,119.3	132.4	4,156.4	105,600.0	438.9	0.5	0.3	0.3	0.9	0.9
08/23/2025 07:00	3,630.5	0.0	3,630.5	105,600.0	383.4	0.5	0.2	0.2	0.8	0.8
08/23/2025 08:00	3,629.5	1.4	3,629.5	105,600.0	383.3	0.5	0.2	0.2	0.8	0.8
08/23/2025 09:00	4,162.4	110.2	4,187.7	105,600.0	442.2	0.5	0.3	0.3	0.9	0.9
08/23/2025 10:00	4,662.9	552.7	5,215.6	105,600.0	550.8	0.7	0.3	0.3	1.1	1.1
08/23/2025 11:00	4,144.8	7.6	4,145.0	105,600.0	437.7	0.5	0.3	0.3	0.9	0.9
08/23/2025 12:00	4,586.4	761.4	5,332.6	105,600.0	563.1	0.7	0.3	0.3	1.1	1.1
08/23/2025 13:00	4,566.1	1,797.1	6,363.2	105,600.0	672.0	0.8	0.4	0.4	1.3	1.3
08/23/2025 14:00	4,561.9	1,908.7	6,470.6	105,600.0	683.3	0.8	0.4	0.4	1.4	1.4
08/23/2025 15:00	4,555.8	1,760.7	6,316.5	105,600.0	667.0	0.8	0.4	0.4	1.3	1.3
08/23/2025 16:00	4,583.0	1,818.9	6,401.9	105,600.0	676.0	0.8	0.4	0.4	1.4	1.4
08/23/2025 17:00	4,630.6	1,268.7	5,899.3	105,600.0	623.0	0.7	0.4	0.4	1.2	1.2
08/23/2025 18:00	4,661.7	1,110.9	5,772.6	105,600.0	609.6	0.7	0.4	0.4	1.2	1.2
08/23/2025 19:00	4,696.2	671.7	5,367.9	105,600.0	566.9	0.7	0.3	0.3	1.1	1.1
08/23/2025 20:00	4,709.3	676.8	5,386.1	105,600.0	568.8	0.7	0.3	0.3	1.1	1.1
08/23/2025 21:00	4,715.5	1,190.5	5,906.0	105,600.0	623.7	0.7	0.4	0.4	1.2	1.2
08/23/2025 22:00	4,723.9	1,329.8	6,053.7	105,600.0	639.3	0.8	0.4	0.4	1.3	1.3
08/23/2025 23:00	4,737.4	1,338.4	6,075.8	105,600.0	641.6	0.8	0.4	0.4	1.3	1.3
Average/Sum#:	4,476.4	873.1	5,341.0	105,600.0	564.0	0.7	0.3	0.3	1.1	1.1
Minimum:	3,629.5	0.0	3,629.5	105,600.0	383.3	0.5	0.2	0.2	0.8	0.8
Maximum:	4,737.4	1,908.7	6,470.6	105,600.0	683.3	0.8	0.4	0.4	1.4	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/24/2025 00:00	4,749.8	494.3	5,244.1	105,600.0	553.8	0.7	0.3	1.1
08/24/2025 01:00	4,760.8	401.0	5,161.8	105,600.0	545.1	0.7	0.3	1.1
08/24/2025 02:00	4,707.3	482.8	5,190.1	105,600.0	548.1	0.7	0.3	1.1
08/24/2025 03:00	4,673.0	514.1	5,187.1	105,600.0	547.8	0.7	0.3	1.1
08/24/2025 04:00	3,943.8	4.0	3,943.9	105,600.0	416.5	0.5	0.3	0.8
08/24/2025 05:00	4,199.6	0.0	4,199.6	105,600.0	443.5	0.5	0.3	0.9
08/24/2025 06:00	3,822.0	0.0	3,822.0	105,600.0	403.6	0.5	0.2	0.8
08/24/2025 07:00	3,685.7	0.0	3,685.7	105,600.0	389.2	0.5	0.2	0.8
08/24/2025 08:00	3,685.4	0.0	3,685.4	105,600.0	389.2	0.5	0.2	0.8
08/24/2025 09:00	3,680.0	0.0	3,680.0	105,600.0	388.6	0.5	0.2	0.8
08/24/2025 10:00	3,683.2	0.0	3,683.2	105,600.0	388.9	0.5	0.2	0.8
08/24/2025 11:00	3,682.9	0.0	3,682.9	105,600.0	388.9	0.5	0.2	0.8
08/24/2025 12:00	3,792.2	34.3	3,792.2	105,600.0	400.5	0.5	0.2	0.8
08/24/2025 13:00	4,097.2	42.9	4,097.2	105,600.0	432.7	0.5	0.3	0.9
08/24/2025 14:00	4,465.7	142.5	4,498.5	105,600.0	475.0	0.6	0.3	1.0
08/24/2025 15:00	4,543.1	953.0	5,496.1	105,600.0	580.4	0.7	0.3	1.2
08/24/2025 16:00	4,517.4	1,383.6	5,901.0	105,600.0	623.1	0.7	0.4	1.2
08/24/2025 17:00	4,528.0	1,183.7	5,711.7	105,600.0	603.2	0.7	0.4	1.2
08/24/2025 18:00	4,580.6	1,156.4	5,737.0	105,600.0	605.8	0.7	0.4	1.2
08/24/2025 19:00	4,594.8	1,392.1	5,986.9	105,600.0	632.2	0.8	0.4	1.3
08/24/2025 20:00	4,634.1	757.3	5,391.4	105,600.0	569.3	0.7	0.3	1.1
08/24/2025 21:00	4,605.4	602.7	5,208.1	105,600.0	550.0	0.7	0.3	1.1
08/24/2025 22:00	4,553.7	674.7	5,228.4	105,600.0	552.1	0.7	0.3	1.1
08/24/2025 23:00	4,603.7	642.9	5,246.6	105,600.0	554.0	0.7	0.3	1.1
Average/Sum#:	4,282.9	452.6	4,727.5	105,600.0	499.2	0.6	0.3	1.0
Minimum:	3,680.0	0.0	3,680.0	105,600.0	388.6	0.5	0.2	0.8
Maximum:	4,760.8	1,392.1	5,986.9	105,600.0	632.2	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/25/2025 00:00	4,630.0	560.6	5,190.6	105,600.0	548.1	0.7	0.3	1.1
08/25/2025 01:00	4,655.3	531.8	5,187.1	105,600.0	547.8	0.7	0.3	1.1
08/25/2025 02:00	4,678.9	507.0	5,185.9	105,600.0	547.6	0.7	0.3	1.1
08/25/2025 03:00	4,706.4	471.2	5,177.6	105,600.0	546.8	0.7	0.3	1.1
08/25/2025 04:00	4,725.6	488.9	5,214.5	105,600.0	550.7	0.7	0.3	1.1
08/25/2025 05:00	4,739.5	714.5	5,454.0	105,600.0	575.9	0.7	0.3	1.2
08/25/2025 06:00	4,737.7	1,039.9	5,777.6	105,600.0	610.1	0.7	0.4	1.2
08/25/2025 07:00	4,160.3	111.9	4,190.5	105,600.0	442.5	0.5	0.3	0.9
08/25/2025 08:00	3,648.0	0.0	3,648.0	105,600.0	385.2	0.5	0.2	0.8
08/25/2025 09:00	3,858.3	0.0	3,858.3	105,600.0	407.4	0.5	0.2	0.8
08/25/2025 10:00	4,368.6	1.9	4,368.6	105,600.0	461.3	0.6	0.3	0.9
08/25/2025 11:00	3,771.9	0.0	3,771.9	105,600.0	398.3	0.5	0.2	0.8
08/25/2025 12:00	4,549.0	32.6	4,549.0	105,600.0	480.4	0.6	0.3	1.0
08/25/2025 13:00	4,612.1	1,209.1	5,797.0	105,600.0	612.2	0.7	0.4	1.2
08/25/2025 14:00	4,584.2	799.4	5,383.6	105,600.0	568.5	0.7	0.3	1.1
08/25/2025 15:00	4,572.1	893.5	5,465.6	105,600.0	577.2	0.7	0.3	1.2
08/25/2025 16:00	4,555.2	989.3	5,544.5	105,600.0	585.5	0.7	0.4	1.2
08/25/2025 17:00	4,570.7	1,695.7	6,266.4	105,600.0	661.7	0.8	0.4	1.3
08/25/2025 18:00	4,621.9	1,708.9	6,330.8	105,600.0	668.5	0.8	0.4	1.3
08/25/2025 19:00	4,631.8	761.8	5,393.6	105,600.0	569.6	0.7	0.3	1.1
08/25/2025 20:00	4,651.3	898.3	5,549.6	105,600.0	586.0	0.7	0.4	1.2
08/25/2025 21:00	4,678.8	562.9	5,241.7	105,600.0	553.5	0.7	0.3	1.1
08/25/2025 22:00	4,679.3	541.3	5,220.6	105,600.0	551.3	0.7	0.3	1.1
08/25/2025 23:00	4,567.0	719.5	5,286.5	105,600.0	558.3	0.7	0.3	1.1
Average/Sum#:	4,498.1	635.0	5,127.2	105,600.0	541.4	0.7	0.3	1.1
Minimum:	3,648.0	0.0	3,648.0	105,600.0	385.2	0.5	0.2	0.8
Maximum:	4,739.5	1,708.9	6,330.8	105,600.0	668.5	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/26/2025 00:00	4,603.4	648.9	5,252.3	105,600.0	554.6	0.7	0.3	1.1
08/26/2025 01:00	4,625.8	585.3	5,211.1	105,600.0	550.3	0.7	0.3	1.1
08/26/2025 02:00	4,667.8	509.2	5,177.0	105,600.0	546.7	0.7	0.3	1.1
08/26/2025 03:00	4,685.7	558.3	5,244.0	105,600.0	553.8	0.7	0.3	1.1
08/26/2025 04:00	4,686.2	739.6	5,425.8	105,600.0	573.0	0.7	0.3	1.1
08/26/2025 05:00	4,697.8	1,435.2	6,133.0	105,600.0	647.6	0.8	0.4	1.3
08/26/2025 06:00	4,716.7	1,779.2	6,495.9	105,600.0	686.0	0.8	0.4	1.4
08/26/2025 07:00	4,696.0	777.6	5,473.6	105,600.0	578.0	0.7	0.3	1.2
08/26/2025 08:00	4,673.2	529.6	5,202.8	105,600.0	549.4	0.7	0.3	1.1
08/26/2025 09:00	4,538.9	469.0	5,007.9	105,600.0	528.8	0.7	0.3	1.1
08/26/2025 10:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
08/26/2025 11:00	0.0	0.0	0.0	105,600.0	0.0	0.0	0.0	0.0
08/26/2025 12:00	3,658.6	0.0	3,658.6	105,600.0	386.3	0.0	0.0	0.0
08/26/2025 13:00	3,898.6	0.0	3,898.6	105,600.0	411.7	0.5	0.2	0.8
08/26/2025 14:00	3,751.6	0.0	3,751.6	105,600.0	396.2	0.5	0.2	0.8
08/26/2025 15:00	4,375.6	0.0	4,375.6	105,600.0	462.1	0.6	0.3	0.9
08/26/2025 16:00	4,555.4	0.0	4,555.4	105,600.0	481.1	0.6	0.3	1.0
08/26/2025 17:00	4,567.3	0.0	4,567.3	105,600.0	482.3	0.6	0.3	1.0
08/26/2025 18:00	4,645.1	1,171.1	5,500.0	105,600.0	580.8	0.7	0.4	1.2
08/26/2025 19:00	4,683.5	1,857.9	6,541.4	105,600.0	690.8	0.8	0.4	1.4
08/26/2025 20:00	4,714.2	1,808.3	6,522.5	105,600.0	688.8	0.8	0.4	1.4
08/26/2025 21:00	4,721.4	1,793.6	6,515.0	105,600.0	688.0	0.8	0.4	1.4
08/26/2025 22:00	4,733.0	1,767.3	6,500.3	105,600.0	686.4	0.8	0.4	1.4
08/26/2025 23:00	4,738.8	789.1	5,527.9	105,600.0	583.7	0.7	0.4	1.2
Average/Sum#:	4,528.8	782.7	5,297.2	105,600.0	559.4	0.7	0.3	1.1
Minimum:	3,658.6	0.0	3,658.6	105,600.0	386.3	0.5	0.2	0.8
Maximum:	4,738.8	1,857.9	6,541.4	105,600.0	690.8	0.8	0.4	1.4
%SI	8.33	8.33	8.33	0.00	8.33	12.50	12.50	12.50

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/27/2025 00:00	4,483.7	3.7	4,483.8	105,600.0	473.5	0.6	0.3	0.9
08/27/2025 01:00	3,885.9	0.0	3,885.9	105,600.0	410.4	0.5	0.2	0.8
08/27/2025 02:00	3,710.9	0.0	3,710.9	105,600.0	391.9	0.5	0.2	0.8
08/27/2025 03:00	3,704.7	0.0	3,704.7	105,600.0	391.2	0.5	0.2	0.8
08/27/2025 04:00	3,791.0	0.0	3,791.0	105,600.0	400.3	0.5	0.2	0.8
08/27/2025 05:00	3,816.3	0.0	3,816.3	105,600.0	403.0	0.5	0.2	0.8
08/27/2025 06:00	3,706.2	0.0	3,706.2	105,600.0	391.4	0.5	0.2	0.8
08/27/2025 07:00	3,707.4	0.0	3,707.4	105,600.0	391.5	0.5	0.2	0.8
08/27/2025 08:00	3,706.9	0.0	3,706.9	105,600.0	391.4	0.5	0.2	0.8
08/27/2025 09:00	3,704.6	0.0	3,704.6	105,600.0	391.2	0.5	0.2	0.8
08/27/2025 10:00	3,697.9	0.0	3,697.9	105,600.0	390.5	0.5	0.2	0.8
08/27/2025 11:00	3,684.1	0.0	3,684.1	105,600.0	389.0	0.5	0.2	0.8
08/27/2025 12:00	4,085.2	25.2	4,085.2	105,600.0	431.4	0.5	0.3	0.9
08/27/2025 13:00	4,537.5	29.4	4,537.5	105,600.0	479.2	0.6	0.3	1.0
08/27/2025 14:00	4,534.5	0.0	4,534.5	105,600.0	478.8	0.6	0.3	1.0
08/27/2025 15:00	4,530.1	0.0	4,530.1	105,600.0	478.4	0.6	0.3	1.0
08/27/2025 16:00	4,271.4	0.0	4,271.4	105,600.0	451.1	0.5	0.3	0.9
08/27/2025 17:00	4,511.5	112.0	4,537.3	105,600.0	479.1	0.6	0.3	1.0
08/27/2025 18:00	4,725.1	494.4	5,219.5	105,600.0	551.2	0.7	0.3	1.1
08/27/2025 19:00	4,746.6	456.7	5,203.3	105,600.0	549.5	0.7	0.3	1.1
08/27/2025 20:00	4,683.5	538.4	5,221.9	105,600.0	551.4	0.7	0.3	1.1
08/27/2025 21:00	4,393.6	300.1	4,552.7	105,600.0	480.8	0.6	0.3	1.0
08/27/2025 22:00	3,654.0	0.0	3,654.0	105,600.0	385.9	0.5	0.2	0.8
08/27/2025 23:00	3,656.9	0.0	3,656.9	105,600.0	386.2	0.5	0.2	0.8
Average/Sum#:	4,080.4	81.7	4,150.2	105,600.0	438.3	0.6	0.2	0.9
Minimum:	3,654.0	0.0	3,654.0	105,600.0	385.9	0.5	0.2	0.8
Maximum:	4,746.6	538.4	5,221.9	105,600.0	551.4	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/28/2025 00:00	3,659.9	0.0	3,659.9	105,600.0	386.5	0.5	0.2	0.8
08/28/2025 01:00	4,270.7	89.6	4,290.4	105,600.0	453.1	0.6	0.3	0.9
08/28/2025 02:00	4,761.7	427.8	5,189.5	105,600.0	548.0	0.7	0.3	1.1
08/28/2025 03:00	4,699.3	297.7	4,928.5	105,600.0	520.4	0.6	0.3	1.1
08/28/2025 04:00	3,999.0	0.0	3,999.0	105,600.0	422.3	0.5	0.3	0.8
08/28/2025 05:00	3,706.3	0.0	3,706.3	105,600.0	391.4	0.5	0.2	0.8
08/28/2025 06:00	3,900.4	0.0	3,900.4	105,600.0	411.9	0.5	0.2	0.8
08/28/2025 07:00	3,659.7	0.0	3,659.7	105,600.0	386.5	0.5	0.2	0.8
08/28/2025 08:00	3,657.2	0.0	3,657.2	105,600.0	386.2	0.5	0.2	0.8
08/28/2025 09:00	3,653.2	0.0	3,653.2	105,600.0	385.8	0.5	0.2	0.8
08/28/2025 10:00	3,644.9	0.0	3,644.9	105,600.0	384.9	0.5	0.2	0.8
08/28/2025 11:00	3,639.8	0.0	3,639.8	105,600.0	384.4	0.5	0.2	0.8
08/28/2025 12:00	3,637.4	17.3	3,637.4	105,600.0	384.1	0.5	0.2	0.8
08/28/2025 13:00	3,843.3	21.5	3,843.3	105,600.0	405.9	0.5	0.2	0.8
08/28/2025 14:00	3,917.6	0.0	3,917.6	105,600.0	413.7	0.5	0.2	0.8
08/28/2025 15:00	3,980.2	0.0	3,980.2	105,600.0	420.3	0.5	0.3	0.8
08/28/2025 16:00	4,180.0	142.0	4,219.8	105,600.0	445.6	0.5	0.3	0.9
08/28/2025 17:00	4,677.8	575.2	5,253.0	105,600.0	554.7	0.7	0.3	1.1
08/28/2025 18:00	4,690.9	529.7	5,220.6	105,600.0	551.3	0.7	0.3	1.1
08/28/2025 19:00	4,629.0	608.0	5,237.0	105,600.0	553.0	0.7	0.3	1.1
08/28/2025 20:00	4,545.8	734.3	5,280.1	105,600.0	557.6	0.7	0.3	1.1
08/28/2025 21:00	4,616.6	640.9	5,257.5	105,600.0	555.2	0.7	0.3	1.1
08/28/2025 22:00	4,658.0	569.0	5,227.0	105,600.0	552.0	0.7	0.3	1.1
08/28/2025 23:00	4,688.7	531.9	5,220.6	105,600.0	551.3	0.7	0.3	1.1
Average/Sum#:	4,138.2	216.0	4,342.6	105,600.0	458.6	0.6	0.3	0.9
Minimum:	3,637.4	0.0	3,637.4	105,600.0	384.1	0.5	0.2	0.8
Maximum:	4,761.7	734.3	5,280.1	105,600.0	557.6	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/29/2025 00:00	4,715.5	488.9	5,204.4	105,600.0	549.6	0.7	0.3	1.1
08/29/2025 01:00	4,416.6	229.0	4,535.7	105,600.0	479.0	0.6	0.3	1.0
08/29/2025 02:00	3,656.7	0.0	3,656.7	105,600.0	386.1	0.5	0.2	0.8
08/29/2025 03:00	3,658.6	0.0	3,658.6	105,600.0	386.3	0.5	0.2	0.8
08/29/2025 04:00	3,658.2	0.0	3,658.2	105,600.0	386.3	0.5	0.2	0.8
08/29/2025 05:00	3,662.3	0.0	3,662.3	105,600.0	386.7	0.5	0.2	0.8
08/29/2025 06:00	3,663.7	0.0	3,663.7	105,600.0	386.9	0.5	0.2	0.8
08/29/2025 07:00	3,658.8	0.0	3,658.8	105,600.0	386.4	0.5	0.2	0.8
08/29/2025 08:00	3,657.1	0.0	3,657.1	105,600.0	386.2	0.5	0.2	0.8
08/29/2025 09:00	3,653.8	0.0	3,653.8	105,600.0	385.8	0.5	0.2	0.8
08/29/2025 10:00	3,647.9	0.0	3,647.9	105,600.0	385.2	0.5	0.2	0.8
08/29/2025 11:00	3,641.2	0.0	3,641.2	105,600.0	384.5	0.5	0.2	0.8
08/29/2025 12:00	3,635.2	18.3	3,635.2	105,600.0	383.9	0.5	0.2	0.8
08/29/2025 13:00	3,631.9	27.2	3,631.9	105,600.0	383.5	0.5	0.2	0.8
08/29/2025 14:00	3,628.3	0.0	3,628.3	105,600.0	383.1	0.5	0.2	0.8
08/29/2025 15:00	3,617.1	0.0	3,617.1	105,600.0	382.0	0.5	0.2	0.8
08/29/2025 16:00	3,651.7	0.0	3,651.7	105,600.0	385.6	0.5	0.2	0.8
08/29/2025 17:00	4,023.1	0.0	4,023.1	105,600.0	424.8	0.5	0.3	0.8
08/29/2025 18:00	3,671.8	0.0	3,671.8	105,600.0	387.7	0.5	0.2	0.8
08/29/2025 19:00	3,638.4	0.0	3,638.4	105,600.0	384.2	0.5	0.2	0.8
08/29/2025 20:00	3,668.5	0.0	3,668.5	105,600.0	387.4	0.5	0.2	0.8
08/29/2025 21:00	3,726.8	0.0	3,726.8	105,600.0	393.6	0.5	0.2	0.8
08/29/2025 22:00	3,653.2	0.0	3,653.2	105,600.0	385.8	0.5	0.2	0.8
08/29/2025 23:00	3,644.8	0.0	3,644.8	105,600.0	384.9	0.5	0.2	0.8
Average/Sum#:	3,745.1	31.8	3,770.4	105,600.0	398.1	0.5	0.2	0.8
Minimum:	3,617.1	0.0	3,617.1	105,600.0	382.0	0.5	0.2	0.8
Maximum:	4,715.5	488.9	5,204.4	105,600.0	549.6	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/30/2025 00:00	3,648.3	0.0	3,648.3	105,600.0	385.3	0.5	0.2	0.8			
08/30/2025 01:00	3,650.5	0.0	3,650.5	105,600.0	385.5	0.5	0.2	0.8			
08/30/2025 02:00	3,653.1	0.0	3,653.1	105,600.0	385.8	0.5	0.2	0.8			
08/30/2025 03:00	3,649.9	0.0	3,649.9	105,600.0	385.4	0.5	0.2	0.8			
08/30/2025 04:00	3,651.8	0.0	3,651.8	105,600.0	385.6	0.5	0.2	0.8			
08/30/2025 05:00	3,656.3	0.0	3,656.3	105,600.0	386.1	0.5	0.2	0.8			
08/30/2025 06:00	3,655.4	0.0	3,655.4	105,600.0	386.0	0.5	0.2	0.8			
08/30/2025 07:00	3,652.6	0.0	3,652.6	105,600.0	385.7	0.5	0.2	0.8			
08/30/2025 08:00	3,647.1	0.0	3,647.1	105,600.0	385.1	0.5	0.2	0.8			
08/30/2025 09:00	3,640.1	0.0	3,640.1	105,600.0	384.4	0.5	0.2	0.8			
08/30/2025 10:00	3,632.1	0.0	3,632.1	105,600.0	383.5	0.5	0.2	0.8			
08/30/2025 11:00	3,630.4	0.0	3,630.4	105,600.0	383.4	0.5	0.2	0.8			
08/30/2025 12:00	3,624.8	20.3	3,624.8	105,600.0	382.8	0.5	0.2	0.8			
08/30/2025 13:00	3,624.6	25.4	3,624.6	105,600.0	382.8	0.5	0.2	0.8			
08/30/2025 14:00	3,614.4	0.0	3,614.4	105,600.0	381.7	0.5	0.2	0.8			
08/30/2025 15:00	3,609.8	0.0	3,609.8	105,600.0	381.2	0.5	0.2	0.8			
08/30/2025 16:00	3,763.8	0.0	3,763.8	105,600.0	397.5	0.5	0.2	0.8			
08/30/2025 17:00	4,177.8	152.6	4,219.0	105,600.0	445.5	0.5	0.3	0.9			
08/30/2025 18:00	4,359.8	949.0	5,308.8	105,600.0	560.6	0.7	0.3	1.1			
08/30/2025 19:00	4,111.1	1,295.4	5,406.5	105,600.0	570.9	0.7	0.3	1.1			
08/30/2025 20:00	4,223.6	1,164.8	5,388.4	105,600.0	569.0	0.7	0.3	1.1			
08/30/2025 21:00	4,361.7	947.2	5,308.9	105,600.0	560.6	0.7	0.3	1.1			
08/30/2025 22:00	4,406.4	879.3	5,285.7	105,600.0	558.2	0.7	0.3	1.1			
08/30/2025 23:00	4,306.0	385.1	4,517.8	105,600.0	477.1	0.6	0.3	1.0			
Average/Sum#:	3,831.3	242.5	4,060.0	105,600.0	428.7	0.5	0.2	0.9			
Minimum:	3,609.8	0.0	3,609.8	105,600.0	381.2	0.5	0.2	0.8			
Maximum:	4,406.4	1,295.4	5,406.5	105,600.0	570.9	0.7	0.3	1.1			
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/31/2025 00:00	3,639.1	0.0	3,639.1	105,600.0	384.3	0.5	0.2	0.8			
08/31/2025 01:00	3,639.8	0.0	3,639.8	105,600.0	384.4	0.5	0.2	0.8			
08/31/2025 02:00	3,641.8	0.0	3,641.8	105,600.0	384.6	0.5	0.2	0.8			
08/31/2025 03:00	3,643.7	0.0	3,643.7	105,600.0	384.8	0.5	0.2	0.8			
08/31/2025 04:00	3,646.0	0.0	3,646.0	105,600.0	385.0	0.5	0.2	0.8			
08/31/2025 05:00	3,645.8	0.0	3,645.8	105,600.0	385.0	0.5	0.2	0.8			
08/31/2025 06:00	3,648.6	0.0	3,648.6	105,600.0	385.3	0.5	0.2	0.8			
08/31/2025 07:00	3,643.4	0.0	3,643.4	105,600.0	384.7	0.5	0.2	0.8			
08/31/2025 08:00	3,635.6	0.0	3,635.6	105,600.0	383.9	0.5	0.2	0.8			
08/31/2025 09:00	3,627.4	0.0	3,627.4	105,600.0	383.1	0.5	0.2	0.8			
08/31/2025 10:00	3,623.2	0.0	3,623.2	105,600.0	382.6	0.5	0.2	0.8			
08/31/2025 11:00	3,609.8	0.0	3,609.8	105,600.0	381.2	0.5	0.2	0.8			
08/31/2025 12:00	3,886.0	29.7	3,886.9	105,600.0	410.5	0.5	0.2	0.8			
08/31/2025 13:00	4,148.9	170.2	4,188.0	105,600.0	442.3	0.5	0.3	0.9			
08/31/2025 14:00	4,620.5	651.6	5,272.1	105,600.0	556.7	0.7	0.3	1.1			
08/31/2025 15:00	4,626.9	646.1	5,273.0	105,600.0	556.8	0.7	0.3	1.1			
08/31/2025 16:00	4,629.1	680.2	5,309.3	105,600.0	560.7	0.7	0.3	1.1			
08/31/2025 17:00	4,635.7	947.2	5,582.9	105,600.0	589.6	0.7	0.4	1.2			
08/31/2025 18:00	4,668.1	890.6	5,558.7	105,600.0	587.0	0.7	0.4	1.2			
08/31/2025 19:00	4,317.3	1,053.7	5,371.0	105,600.0	567.2	0.7	0.3	1.1			
08/31/2025 20:00	3,791.0	29.8	3,794.6	105,600.0	400.7	0.5	0.2	0.8			
08/31/2025 21:00	3,718.4	0.0	3,718.4	105,600.0	392.7	0.5	0.2	0.8			
08/31/2025 22:00	3,999.4	0.0	3,999.4	105,600.0	422.3	0.5	0.3	0.8			
08/31/2025 23:00	4,545.5	723.8	5,254.8	105,600.0	554.9	0.7	0.3	1.1			
Average/Sum#:	3,968.0	242.6	4,202.2	105,600.0	443.8	0.6	0.2	0.9			
Minimum:	3,609.8	0.0	3,609.8	105,600.0	381.2	0.5	0.2	0.8			
Maximum:	4,668.1	1,053.7	5,582.9	105,600.0	589.6	0.7	0.4	1.2			
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/01/2025 00:00	4,577.7	696.1	5,273.8	105,600.0	556.9	0.7	0.3	0.3	1.1	1.1
09/01/2025 01:00	4,605.1	654.8	5,259.9	105,600.0	555.4	0.7	0.3	0.3	1.1	1.1
09/01/2025 02:00	4,627.6	622.7	5,250.3	105,600.0	554.4	0.7	0.3	0.3	1.1	1.1
09/01/2025 03:00	4,639.0	587.3	5,226.3	105,600.0	551.9	0.7	0.3	0.3	1.1	1.1
09/01/2025 04:00	4,652.8	546.0	5,198.8	105,600.0	549.0	0.7	0.3	0.3	1.1	1.1
09/01/2025 05:00	4,683.8	507.3	5,191.1	105,600.0	548.2	0.7	0.3	0.3	1.1	1.1
09/01/2025 06:00	4,636.4	374.6	4,928.6	105,600.0	520.5	0.6	0.3	0.3	1.1	1.1
09/01/2025 07:00	3,664.8	2.0	3,664.8	105,600.0	387.0	0.5	0.2	0.2	0.8	0.8
09/01/2025 08:00	3,638.7	0.0	3,638.7	105,600.0	384.2	0.5	0.2	0.2	0.8	0.8
09/01/2025 09:00	3,636.2	0.0	3,636.2	105,600.0	384.0	0.5	0.2	0.2	0.8	0.8
09/01/2025 10:00	4,171.2	156.6	4,215.0	105,600.0	445.1	0.5	0.3	0.3	0.9	0.9
09/01/2025 11:00	4,580.8	736.6	5,317.4	105,600.0	561.5	0.7	0.3	0.3	1.1	1.1
09/01/2025 12:00	4,110.8	1,373.2	5,484.0	105,600.0	579.1	0.7	0.3	0.3	1.2	1.2
09/01/2025 13:00	4,101.5	1,449.4	5,550.9	105,600.0	586.2	0.7	0.4	0.4	1.2	1.2
09/01/2025 14:00	4,591.2	1,011.6	5,602.8	105,600.0	591.7	0.7	0.4	0.4	1.2	1.2
09/01/2025 15:00	4,582.1	798.0	5,380.1	105,600.0	568.1	0.7	0.3	0.3	1.1	1.1
09/01/2025 16:00	4,573.9	1,431.6	6,005.5	105,600.0	634.2	0.8	0.4	0.4	1.3	1.3
09/01/2025 17:00	4,578.8	1,845.2	6,424.0	105,600.0	678.4	0.8	0.4	0.4	1.4	1.4
09/01/2025 18:00	4,578.1	1,932.5	6,510.6	105,600.0	687.5	0.8	0.4	0.4	1.4	1.4
09/01/2025 19:00	4,606.2	1,946.5	6,552.7	105,600.0	692.0	0.8	0.4	0.4	1.4	1.4
09/01/2025 20:00	4,638.0	1,873.0	6,511.0	105,600.0	687.6	0.8	0.4	0.4	1.4	1.4
09/01/2025 21:00	4,667.4	1,748.5	6,415.9	105,600.0	677.5	0.8	0.4	0.4	1.4	1.4
09/01/2025 22:00	4,676.6	1,364.8	6,041.4	105,600.0	638.0	0.8	0.4	0.4	1.3	1.3
09/01/2025 23:00	4,679.7	1,211.9	5,891.6	105,600.0	622.2	0.7	0.4	0.4	1.2	1.2
Average/Sum#:	4,437.4	952.9	5,382.1	105,600.0	568.4	0.7	0.3	0.3	1.2	1.2
Minimum:	3,636.2	0.0	3,636.2	105,600.0	384.0	0.5	0.2	0.2	0.8	0.8
Maximum:	4,683.8	1,946.5	6,552.7	105,600.0	692.0	0.8	0.4	0.4	1.4	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/02/2025 00:00	4,611.3	637.9	5,249.2	105,600.0	554.3	0.7	0.3	0.3	1.1	1.1
09/02/2025 01:00	4,537.3	704.6	5,241.9	105,600.0	553.5	0.7	0.3	0.3	1.1	1.1
09/02/2025 02:00	4,566.5	683.4	5,249.9	105,600.0	554.4	0.7	0.3	0.3	1.1	1.1
09/02/2025 03:00	4,583.6	641.5	5,225.1	105,600.0	551.8	0.7	0.3	0.3	1.1	1.1
09/02/2025 04:00	4,588.8	1,299.7	5,888.5	105,600.0	621.8	0.7	0.4	0.4	1.2	1.2
09/02/2025 05:00	4,626.4	1,807.1	6,433.5	105,600.0	679.4	0.8	0.4	0.4	1.4	1.4
09/02/2025 06:00	4,623.7	1,524.7	6,148.4	105,600.0	649.3	0.8	0.4	0.4	1.3	1.3
09/02/2025 07:00	4,545.1	1,725.4	6,270.5	105,600.0	662.2	0.8	0.4	0.4	1.3	1.3
09/02/2025 08:00	4,654.7	1,747.1	6,401.8	105,600.0	676.0	0.8	0.4	0.4	1.4	1.4
09/02/2025 09:00	4,668.4	1,218.8	5,887.2	105,600.0	621.7	0.7	0.4	0.4	1.2	1.2
09/02/2025 10:00	4,463.5	883.2	5,346.7	105,600.0	564.6	0.7	0.3	0.3	1.1	1.1
09/02/2025 11:00	4,515.0	1,453.5	5,968.5	105,600.0	630.3	0.8	0.4	0.4	1.3	1.3
09/02/2025 12:00	4,592.3	1,836.1	6,428.4	105,600.0	678.8	0.8	0.4	0.4	1.4	1.4
09/02/2025 13:00	4,592.7	1,763.8	6,356.5	105,600.0	671.2	0.8	0.4	0.4	1.3	1.3
09/02/2025 14:00	4,583.2	1,960.9	6,544.1	105,600.0	691.1	0.8	0.4	0.4	1.4	1.4
09/02/2025 15:00	4,566.7	1,954.6	6,521.3	105,600.0	688.6	0.8	0.4	0.4	1.4	1.4
09/02/2025 16:00	4,583.8	1,953.0	6,536.8	105,600.0	690.3	0.8	0.4	0.4	1.4	1.4
09/02/2025 17:00	4,610.2	1,940.6	6,550.8	105,600.0	691.8	0.8	0.4	0.4	1.4	1.4
09/02/2025 18:00	4,630.5	1,957.0	6,587.5	105,600.0	695.6	0.8	0.4	0.4	1.4	1.4
09/02/2025 19:00	4,665.0	1,887.9	6,552.9	105,600.0	692.0	0.8	0.4	0.4	1.4	1.4
09/02/2025 20:00	4,697.3	1,828.4	6,525.7	105,600.0	689.1	0.8	0.4	0.4	1.4	1.4
09/02/2025 21:00	4,725.1	1,800.9	6,526.0	105,600.0	689.1	0.8	0.4	0.4	1.4	1.4
09/02/2025 22:00	4,744.7	1,767.0	6,511.7	105,600.0	687.6	0.8	0.4	0.4	1.4	1.4
09/02/2025 23:00	4,708.5	1,674.0	6,382.5	105,600.0	674.0	0.8	0.4	0.4	1.3	1.3
Average/Sum#:	4,611.8	1,527.1	6,139.0	105,600.0	648.3	0.8	0.4	0.4	1.3	1.3
Minimum:	4,463.5	637.9	5,225.1	105,600.0	551.8	0.7	0.3	0.3	1.1	1.1
Maximum:	4,744.7	1,960.9	6,587.5	105,600.0	695.6	0.8	0.4	0.4	1.4	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/03/2025 00:00	4,664.8	1,098.4	5,763.2	105,600.0	608.6	0.7	0.4	1.2
09/03/2025 01:00	4,678.2	534.6	5,212.8	105,600.0	550.5	0.7	0.3	1.1
09/03/2025 02:00	4,689.8	526.0	5,215.8	105,600.0	550.8	0.7	0.3	1.1
09/03/2025 03:00	4,707.9	474.3	5,182.2	105,600.0	547.2	0.7	0.3	1.1
09/03/2025 04:00	4,725.7	1,037.9	5,763.6	105,600.0	608.6	0.7	0.4	1.2
09/03/2025 05:00	4,738.6	1,311.0	6,049.6	105,600.0	638.8	0.8	0.4	1.3
09/03/2025 06:00	4,746.6	622.6	5,369.2	105,600.0	567.0	0.7	0.3	1.1
09/03/2025 07:00	4,724.0	444.2	5,168.2	105,600.0	545.8	0.7	0.3	1.1
09/03/2025 08:00	4,674.3	518.1	5,192.4	105,600.0	548.3	0.7	0.3	1.1
09/03/2025 09:00	4,608.9	629.2	5,238.1	105,600.0	553.1	0.7	0.3	1.1
09/03/2025 10:00	4,520.6	750.1	5,270.7	105,600.0	556.6	0.7	0.3	1.1
09/03/2025 11:00	4,400.1	905.0	5,305.1	105,600.0	560.2	0.7	0.3	1.1
09/03/2025 12:00	4,453.8	1,205.7	5,659.5	105,600.0	597.6	0.7	0.4	1.2
09/03/2025 13:00	4,642.9	956.8	5,599.7	105,600.0	591.3	0.7	0.4	1.2
09/03/2025 14:00	4,631.8	1,669.7	6,301.5	105,600.0	665.4	0.8	0.4	1.3
09/03/2025 15:00	4,630.2	1,846.5	6,476.7	105,600.0	683.9	0.8	0.4	1.4
09/03/2025 16:00	4,620.9	1,761.9	6,382.8	105,600.0	674.0	0.8	0.4	1.3
09/03/2025 17:00	4,630.4	1,942.2	6,572.6	105,600.0	694.1	0.8	0.4	1.4
09/03/2025 18:00	4,665.2	1,866.4	6,531.6	105,600.0	689.7	0.8	0.4	1.4
09/03/2025 19:00	4,700.2	1,356.6	6,056.8	105,600.0	639.6	0.8	0.4	1.3
09/03/2025 20:00	4,719.4	1,419.5	6,138.9	105,600.0	648.3	0.8	0.4	1.3
09/03/2025 21:00	4,660.1	1,662.7	6,322.8	105,600.0	667.7	0.8	0.4	1.3
09/03/2025 22:00	4,550.4	1,388.0	5,938.4	105,600.0	627.1	0.8	0.4	1.3
09/03/2025 23:00	4,589.6	716.9	5,306.5	105,600.0	560.4	0.7	0.3	1.1
Average/Sum#:	4,640.6	1,110.2	5,750.8	105,600.0	607.3	0.7	0.4	1.2
Minimum:	4,400.1	444.2	5,168.2	105,600.0	545.8	0.7	0.3	1.1
Maximum:	4,746.6	1,942.2	6,572.6	105,600.0	694.1	0.8	0.4	1.4
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/04/2025 00:00	4,612.8	640.0	5,252.8	105,600.0	554.7	0.7	0.3	1.1			
09/04/2025 01:00	4,638.1	611.9	5,250.0	105,600.0	554.4	0.7	0.3	1.1			
09/04/2025 02:00	4,653.1	583.6	5,236.7	105,600.0	553.0	0.7	0.3	1.1			
09/04/2025 03:00	4,689.6	526.5	5,216.1	105,600.0	550.8	0.7	0.3	1.1			
09/04/2025 04:00	4,723.6	670.0	5,393.6	105,600.0	569.6	0.7	0.3	1.1			
09/04/2025 05:00	4,745.1	1,459.4	6,204.5	105,600.0	655.2	0.8	0.4	1.3			
09/04/2025 06:00	4,754.7	543.2	5,297.9	105,600.0	559.5	0.7	0.3	1.1			
09/04/2025 07:00	4,741.5	456.0	5,197.5	105,600.0	548.9	0.7	0.3	1.1			
09/04/2025 08:00	4,697.7	514.3	5,212.0	105,600.0	550.4	0.7	0.3	1.1			
09/04/2025 09:00	4,639.2	596.0	5,235.2	105,600.0	552.8	0.7	0.3	1.1			
09/04/2025 10:00	4,560.0	672.2	5,232.2	105,600.0	552.5	0.7	0.3	1.1			
09/04/2025 11:00	4,492.7	792.4	5,285.1	105,600.0	558.1	0.7	0.3	1.1			
09/04/2025 12:00	4,357.9	993.6	5,351.5	105,600.0	565.1	0.7	0.3	1.1			
09/04/2025 13:00	4,280.1	1,126.5	5,406.6	105,600.0	570.9	0.7	0.3	1.1			
09/04/2025 14:00	4,265.3	1,120.7	5,386.0	105,600.0	568.8	0.7	0.3	1.1			
09/04/2025 15:00	4,268.7	1,119.0	5,387.7	105,600.0	568.9	0.7	0.3	1.1			
09/04/2025 16:00	4,436.4	1,356.5	5,792.9	105,600.0	611.7	0.7	0.4	1.2			
09/04/2025 17:00	4,618.5	912.6	5,531.1	105,600.0	584.1	0.7	0.4	1.2			
09/04/2025 18:00	4,577.8	1,304.7	5,882.5	105,600.0	621.2	0.7	0.4	1.2			
09/04/2025 19:00	4,657.7	1,233.0	5,890.7	105,600.0	622.1	0.7	0.4	1.2			
09/04/2025 20:00	4,696.0	653.5	5,349.5	105,600.0	564.9	0.7	0.3	1.1			
09/04/2025 21:00	4,731.9	607.8	5,339.7	105,600.0	563.9	0.7	0.3	1.1			
09/04/2025 22:00	4,761.1	566.1	5,327.2	105,600.0	562.6	0.7	0.3	1.1			
09/04/2025 23:00	4,773.2	541.0	5,314.2	105,000.0	558.0	0.7	0.3	1.1			
Average/Sum#:	4,598.9	816.7	5,415.6	105,575.0	571.8	0.7	0.3	1.1			
Minimum:	4,265.3	456.0	5,197.5	105,000.0	548.9	0.7	0.3	1.1			
Maximum:	4,773.2	1,459.4	6,204.5	105,600.0	655.2	0.8	0.4	1.3			
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/05/2025 00:00	4,781.1	533.2	5,314.3	105,000.0	558.0	0.7	0.3	1.1
09/05/2025 01:00	4,785.2	526.1	5,311.3	105,000.0	557.7	0.7	0.3	1.1
09/05/2025 02:00	4,790.0	517.4	5,307.4	105,000.0	557.3	0.7	0.3	1.1
09/05/2025 03:00	4,792.3	519.9	5,312.2	105,000.0	557.8	0.7	0.3	1.1
09/05/2025 04:00	4,795.5	511.8	5,307.3	105,000.0	557.3	0.7	0.3	1.1
09/05/2025 05:00	4,799.5	797.1	5,596.6	105,000.0	587.6	0.7	0.4	1.2
09/05/2025 06:00	4,804.9	817.2	5,622.1	105,000.0	590.3	0.7	0.4	1.2
09/05/2025 07:00	4,789.6	503.9	5,293.5	105,000.0	555.8	0.7	0.3	1.1
09/05/2025 08:00	4,754.9	539.6	5,294.5	105,000.0	555.9	0.7	0.3	1.1
09/05/2025 09:00	4,716.2	600.4	5,316.6	105,000.0	558.2	0.7	0.3	1.1
09/05/2025 10:00	4,663.6	669.4	5,333.0	105,000.0	560.0	0.7	0.3	1.1
09/05/2025 11:00	4,603.4	642.6	5,246.0	105,000.0	550.8	0.7	0.3	1.1
09/05/2025 12:00	4,538.2	724.5	5,262.7	105,000.0	552.6	0.7	0.3	1.1
09/05/2025 13:00	4,486.2	807.0	5,293.2	105,000.0	555.8	0.7	0.3	1.1
09/05/2025 14:00	4,440.0	857.1	5,297.1	105,000.0	556.2	0.7	0.3	1.1
09/05/2025 15:00	4,366.3	974.4	5,340.7	105,000.0	560.8	0.7	0.3	1.1
09/05/2025 16:00	4,379.2	1,077.2	5,456.4	105,000.0	572.9	0.7	0.3	1.1
09/05/2025 17:00	4,417.1	897.2	5,314.3	105,000.0	558.0	0.7	0.3	1.1
09/05/2025 18:00	4,533.8	750.4	5,284.2	105,000.0	554.8	0.7	0.3	1.1
09/05/2025 19:00	4,591.9	672.6	5,264.5	105,000.0	552.8	0.7	0.3	1.1
09/05/2025 20:00	4,641.0	600.8	5,241.8	105,000.0	550.4	0.7	0.3	1.1
09/05/2025 21:00	4,685.3	528.3	5,213.6	105,000.0	547.4	0.7	0.3	1.1
09/05/2025 22:00	4,708.4	500.1	5,208.5	105,000.0	546.9	0.7	0.3	1.1
09/05/2025 23:00	4,729.4	471.4	5,200.8	105,000.0	546.1	0.7	0.3	1.1
Average/Sum#:	4,649.7	668.3	5,318.0	105,000.0	558.4	0.7	0.3	1.1
Minimum:	4,366.3	471.4	5,200.8	105,000.0	546.1	0.7	0.3	1.1
Maximum:	4,804.9	1,077.2	5,622.1	105,000.0	590.3	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/06/2025 00:00	4,747.7	448.4	5,196.1	105,000.0	545.6	0.7	0.3	0.3	1.1	1.1
09/06/2025 01:00	4,764.4	422.8	5,187.2	105,000.0	544.7	0.7	0.3	0.3	1.1	1.1
09/06/2025 02:00	4,779.9	395.9	5,175.8	105,000.0	543.5	0.7	0.3	0.3	1.1	1.1
09/06/2025 03:00	4,791.7	381.4	5,173.1	105,000.0	543.2	0.7	0.3	0.3	1.1	1.1
09/06/2025 04:00	4,798.1	372.4	5,170.5	105,000.0	542.9	0.7	0.3	0.3	1.1	1.1
09/06/2025 05:00	4,801.0	371.6	5,172.6	105,000.0	543.1	0.7	0.3	0.3	1.1	1.1
09/06/2025 06:00	4,467.9	183.5	4,563.3	105,000.0	479.1	0.6	0.3	0.3	1.0	1.0
09/06/2025 07:00	3,660.4	0.0	3,660.4	105,000.0	384.3	0.5	0.2	0.2	0.8	0.8
09/06/2025 08:00	3,657.3	0.0	3,657.3	105,000.0	384.0	0.5	0.2	0.2	0.8	0.8
09/06/2025 09:00	3,661.8	0.0	3,661.8	105,000.0	384.5	0.5	0.2	0.2	0.8	0.8
09/06/2025 10:00	3,930.6	4.3	3,930.7	105,000.0	412.7	0.5	0.2	0.2	0.8	0.8
09/06/2025 11:00	4,620.4	638.6	5,259.0	105,000.0	552.2	0.7	0.3	0.3	1.1	1.1
09/06/2025 12:00	4,571.0	649.9	5,220.9	105,000.0	548.2	0.7	0.3	0.3	1.1	1.1
09/06/2025 13:00	4,426.9	192.5	4,480.8	105,000.0	470.5	0.6	0.3	0.3	1.0	1.0
09/06/2025 14:00	4,494.8	793.0	5,287.8	105,000.0	555.2	0.7	0.3	0.3	1.1	1.1
09/06/2025 15:00	4,447.5	844.6	5,292.1	105,000.0	555.7	0.7	0.3	0.3	1.1	1.1
09/06/2025 16:00	4,473.1	820.7	5,293.8	105,000.0	555.8	0.7	0.3	0.3	1.1	1.1
09/06/2025 17:00	4,550.5	715.0	5,265.5	105,000.0	552.9	0.7	0.3	0.3	1.1	1.1
09/06/2025 18:00	4,608.1	643.5	5,251.6	105,000.0	551.4	0.7	0.3	0.3	1.1	1.1
09/06/2025 19:00	4,670.5	553.3	5,223.8	105,000.0	548.5	0.7	0.3	0.3	1.1	1.1
09/06/2025 20:00	4,716.4	493.1	5,209.5	105,000.0	547.0	0.7	0.3	0.3	1.1	1.1
09/06/2025 21:00	4,740.6	454.0	5,194.6	105,000.0	545.4	0.7	0.3	0.3	1.1	1.1
09/06/2025 22:00	4,767.0	415.5	5,182.5	105,000.0	544.2	0.7	0.3	0.3	1.1	1.1
09/06/2025 23:00	4,792.0	387.4	5,179.4	105,000.0	543.8	0.7	0.3	0.3	1.1	1.1
Average/Sum#:	4,497.5	424.2	4,912.1	105,000.0	515.8	0.7	0.3	0.3	1.0	1.0
Minimum:	3,657.3	0.0	3,657.3	105,000.0	384.0	0.5	0.2	0.2	0.8	0.8
Maximum:	4,801.0	844.6	5,293.8	105,000.0	555.8	0.7	0.3	0.3	1.1	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/07/2025 00:00	4,807.9	373.5	5,181.4	105,000.0	544.0	0.7	0.3	0.3	1.1	1.1	1.1
09/07/2025 01:00	4,805.2	371.3	5,176.5	105,000.0	543.5	0.7	0.3	0.3	1.1	1.1	1.1
09/07/2025 02:00	4,811.5	355.3	5,166.8	105,000.0	542.5	0.7	0.3	0.3	1.1	1.1	1.1
09/07/2025 03:00	4,815.6	341.1	5,156.7	105,000.0	541.5	0.7	0.3	0.3	1.1	1.1	1.1
09/07/2025 04:00	4,821.8	369.4	5,191.2	105,000.0	545.1	0.7	0.3	0.3	1.1	1.1	1.1
09/07/2025 05:00	4,832.8	311.8	5,144.6	105,000.0	540.2	0.7	0.3	0.3	1.1	1.1	1.1
09/07/2025 06:00	4,491.2	201.7	4,602.1	105,000.0	483.2	0.6	0.3	0.3	1.0	1.0	1.0
09/07/2025 07:00	3,663.2	0.0	3,663.2	105,000.0	384.6	0.5	0.2	0.2	0.8	0.8	0.8
09/07/2025 08:00	3,659.9	0.0	3,659.9	105,000.0	384.3	0.5	0.2	0.2	0.8	0.8	0.8
09/07/2025 09:00	3,658.4	0.0	3,658.4	105,000.0	384.1	0.5	0.2	0.2	0.8	0.8	0.8
09/07/2025 10:00	3,652.4	0.0	3,652.4	105,000.0	383.5	0.5	0.2	0.2	0.8	0.8	0.8
09/07/2025 11:00	3,647.7	0.0	3,647.7	105,000.0	383.0	0.5	0.2	0.2	0.8	0.8	0.8
09/07/2025 12:00	4,143.3	153.2	4,178.5	105,000.0	438.7	0.5	0.3	0.3	0.9	0.9	0.9
09/07/2025 13:00	4,511.2	771.9	5,283.1	105,000.0	554.7	0.7	0.3	0.3	1.1	1.1	1.1
09/07/2025 14:00	4,465.2	817.5	5,282.7	105,000.0	554.7	0.7	0.3	0.3	1.1	1.1	1.1
09/07/2025 15:00	4,434.2	843.2	5,277.4	105,000.0	554.1	0.7	0.3	0.3	1.1	1.1	1.1
09/07/2025 16:00	4,462.9	1,108.5	5,571.4	105,000.0	585.0	0.7	0.4	0.4	1.2	1.2	1.2
09/07/2025 17:00	4,705.4	1,288.3	5,993.7	105,000.0	629.3	0.8	0.4	0.4	1.3	1.3	1.3
09/07/2025 18:00	4,604.5	745.2	5,349.7	105,000.0	561.7	0.7	0.3	0.3	1.1	1.1	1.1
09/07/2025 19:00	4,575.7	673.6	5,249.3	105,000.0	551.2	0.7	0.3	0.3	1.1	1.1	1.1
09/07/2025 20:00	4,622.5	621.3	5,243.8	105,000.0	550.6	0.7	0.3	0.3	1.1	1.1	1.1
09/07/2025 21:00	4,649.6	605.3	5,254.9	105,000.0	551.8	0.7	0.3	0.3	1.1	1.1	1.1
09/07/2025 22:00	4,687.5	569.7	5,257.2	105,000.0	552.0	0.7	0.3	0.3	1.1	1.1	1.1
09/07/2025 23:00	4,719.2	524.5	5,243.7	105,000.0	550.6	0.7	0.3	0.3	1.1	1.1	1.1
Average/Sum#:	4,427.0	460.3	4,878.6	105,000.0	512.2	0.7	0.3	0.3	1.0	1.0	1.0
Minimum:	3,647.7	0.0	3,647.7	105,000.0	383.0	0.5	0.2	0.2	0.8	0.8	0.8
Maximum:	4,832.8	1,288.3	5,993.7	105,000.0	629.3	0.8	0.4	0.4	1.3	1.3	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/08/2025 00:00	4,742.7	440.7	5,183.4	105,000.0	544.3	0.7	0.3	1.1			
09/08/2025 01:00	4,759.9	422.1	5,182.0	105,000.0	544.1	0.7	0.3	1.1			
09/08/2025 02:00	4,769.7	414.0	5,183.7	105,000.0	544.3	0.7	0.3	1.1			
09/08/2025 03:00	4,778.3	404.3	5,182.6	105,000.0	544.2	0.7	0.3	1.1			
09/08/2025 04:00	4,791.3	380.4	5,171.7	105,000.0	543.0	0.7	0.3	1.1			
09/08/2025 05:00	4,805.9	668.2	5,474.1	105,000.0	574.8	0.7	0.3	1.1			
09/08/2025 06:00	4,800.7	362.9	5,163.6	105,000.0	542.2	0.7	0.3	1.1			
09/08/2025 07:00	4,761.6	422.0	5,183.6	105,000.0	544.3	0.7	0.3	1.1			
09/08/2025 08:00	4,664.5	363.2	4,944.2	105,000.0	519.1	0.6	0.3	1.1			
09/08/2025 09:00	3,680.6	0.0	3,680.6	105,000.0	386.5	0.5	0.2	0.8			
09/08/2025 10:00	3,656.1	0.0	3,656.1	105,000.0	383.9	0.5	0.2	0.8			
09/08/2025 11:00	3,648.5	0.0	3,648.5	105,000.0	383.1	0.5	0.2	0.8			
09/08/2025 12:00	3,649.7	2.5	3,649.7	105,000.0	383.2	0.5	0.2	0.8			
09/08/2025 13:00	3,922.2	9.8	3,922.2	105,000.0	411.8	0.5	0.2	0.8			
09/08/2025 14:00	4,530.1	718.1	5,233.8	105,000.0	549.5	0.7	0.3	1.1			
09/08/2025 15:00	4,520.7	769.6	5,290.3	105,000.0	555.5	0.7	0.3	1.1			
09/08/2025 16:00	4,525.8	1,025.6	5,551.4	105,000.0	582.9	0.7	0.3	1.2			
09/08/2025 17:00	4,582.4	1,426.9	6,009.3	105,000.0	631.0	0.8	0.4	1.3			
09/08/2025 18:00	4,665.4	749.9	5,415.3	105,000.0	568.6	0.7	0.3	1.1			
09/08/2025 19:00	4,626.3	646.9	5,273.2	105,000.0	553.7	0.7	0.3	1.1			
09/08/2025 20:00	4,656.5	575.0	5,231.5	105,000.0	549.3	0.7	0.3	1.1			
09/08/2025 21:00	4,675.0	646.3	5,321.3	105,000.0	558.7	0.7	0.3	1.1			
09/08/2025 22:00	4,688.5	810.4	5,498.9	105,000.0	577.4	0.7	0.3	1.2			
09/08/2025 23:00	4,722.8	481.1	5,203.9	105,000.0	546.4	0.7	0.3	1.1			
Average/Sum#:	4,484.4	489.2	4,969.0	105,000.0	521.7	0.7	0.3	1.1			
Minimum:	3,648.5	0.0	3,648.5	105,000.0	383.1	0.5	0.2	0.8			
Maximum:	4,805.9	1,426.9	6,009.3	105,000.0	631.0	0.8	0.4	1.3			
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/09/2025 00:00	4,730.1	469.7	5,199.8	105,000.0	546.0	0.7	0.3	1.1
09/09/2025 01:00	4,728.8	503.4	5,232.2	105,000.0	549.4	0.7	0.3	1.1
09/09/2025 02:00	4,719.4	495.4	5,214.8	105,000.0	547.6	0.7	0.3	1.1
09/09/2025 03:00	4,720.5	489.7	5,210.2	105,000.0	547.1	0.7	0.3	1.1
09/09/2025 04:00	4,742.2	449.5	5,191.7	105,000.0	545.1	0.7	0.3	1.1
09/09/2025 05:00	4,737.2	1,025.3	5,762.5	105,000.0	605.1	0.7	0.4	1.2
09/09/2025 06:00	4,686.0	333.1	4,942.5	105,000.0	519.0	0.6	0.3	1.1
09/09/2025 07:00	4,553.9	211.1	4,655.2	105,000.0	488.8	0.6	0.3	1.0
09/09/2025 08:00	4,709.2	472.2	5,181.4	105,000.0	544.0	0.7	0.3	1.1
09/09/2025 09:00	4,680.9	537.2	5,218.1	105,000.0	547.9	0.7	0.3	1.1
09/09/2025 10:00	4,652.9	546.1	5,199.0	105,000.0	545.9	0.7	0.3	1.1
09/09/2025 11:00	4,617.2	596.9	5,214.1	105,000.0	547.5	0.7	0.3	1.1
09/09/2025 12:00	4,439.8	139.2	4,477.4	105,000.0	470.1	0.6	0.3	1.0
09/09/2025 13:00	4,574.9	642.8	5,217.7	105,000.0	547.9	0.7	0.3	1.1
09/09/2025 14:00	4,561.8	665.5	5,227.3	105,000.0	548.9	0.7	0.3	1.1
09/09/2025 15:00	4,565.0	657.0	5,222.0	105,000.0	548.3	0.7	0.3	1.1
09/09/2025 16:00	4,573.3	645.9	5,219.2	105,000.0	548.0	0.7	0.3	1.1
09/09/2025 17:00	4,607.1	601.4	5,208.5	105,000.0	546.9	0.7	0.3	1.1
09/09/2025 18:00	4,648.7	548.3	5,197.0	105,000.0	545.7	0.7	0.3	1.1
09/09/2025 19:00	4,674.1	518.0	5,192.1	105,000.0	545.2	0.7	0.3	1.1
09/09/2025 20:00	4,693.2	490.5	5,183.7	105,000.0	544.3	0.7	0.3	1.1
09/09/2025 21:00	4,707.0	489.1	5,196.1	105,000.0	545.6	0.7	0.3	1.1
09/09/2025 22:00	4,718.1	475.4	5,193.5	105,000.0	545.3	0.7	0.3	1.1
09/09/2025 23:00	4,733.0	453.3	5,186.3	105,000.0	544.6	0.7	0.3	1.1
Average/Sum#:	4,657.3	519.0	5,164.3	105,000.0	542.3	0.7	0.3	1.1
Minimum:	4,439.8	139.2	4,477.4	105,000.0	470.1	0.6	0.3	1.0
Maximum:	4,742.2	1,025.3	5,762.5	105,000.0	605.1	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:								
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/10/2025 00:00	4,739.5	434.8	5,174.3	105,000.0	543.3	0.7	0.3	1.1
09/10/2025 01:00	4,748.7	419.6	5,168.3	105,000.0	542.7	0.7	0.3	1.1
09/10/2025 02:00	4,754.2	414.3	5,168.5	105,000.0	542.7	0.7	0.3	1.1
09/10/2025 03:00	4,751.8	413.9	5,165.7	105,000.0	542.4	0.7	0.3	1.1
09/10/2025 04:00	4,744.8	424.4	5,169.2	105,000.0	542.8	0.7	0.3	1.1
09/10/2025 05:00	4,745.0	438.7	5,183.7	105,000.0	544.3	0.7	0.3	1.1
09/10/2025 06:00	4,748.0	474.9	5,222.9	105,000.0	548.4	0.7	0.3	1.1
09/10/2025 07:00	4,435.4	217.0	4,554.8	105,000.0	478.3	0.6	0.3	1.0
09/10/2025 08:00	4,179.8	100.4	4,202.9	105,000.0	441.3	0.5	0.3	0.9
09/10/2025 09:00	4,700.4	496.3	5,196.7	105,000.0	545.7	0.7	0.3	1.1
09/10/2025 10:00	3,876.3	21.0	3,877.8	105,000.0	407.2	0.5	0.2	0.8
09/10/2025 11:00	3,636.2	0.0	3,636.2	105,000.0	381.8	0.5	0.2	0.8
09/10/2025 12:00	3,633.3	0.0	3,633.3	105,000.0	381.5	0.5	0.2	0.8
09/10/2025 13:00	3,633.0	0.0	3,633.0	105,000.0	381.5	0.5	0.2	0.8
09/10/2025 14:00	3,897.8	0.0	3,897.8	105,000.0	409.3	0.5	0.2	0.8
09/10/2025 15:00	4,574.4	614.6	5,176.7	105,000.0	543.6	0.7	0.3	1.1
09/10/2025 16:00	4,576.6	655.6	5,232.2	105,000.0	549.4	0.7	0.3	1.1
09/10/2025 17:00	4,601.5	592.1	5,193.6	105,000.0	545.3	0.7	0.3	1.1
09/10/2025 18:00	4,627.2	555.6	5,182.8	105,000.0	544.2	0.7	0.3	1.1
09/10/2025 19:00	4,667.4	502.6	5,170.0	105,000.0	542.9	0.7	0.3	1.1
09/10/2025 20:00	4,722.2	426.5	5,148.7	105,000.0	540.6	0.7	0.3	1.1
09/10/2025 21:00	4,733.7	405.5	5,139.2	105,000.0	539.6	0.6	0.3	1.1
09/10/2025 22:00	4,734.8	412.7	5,147.5	105,000.0	540.5	0.7	0.3	1.1
09/10/2025 23:00	4,753.1	384.8	5,137.9	105,000.0	539.5	0.6	0.3	1.1
Average/Sum#:	4,467.3	350.2	4,808.9	105,000.0	505.0	0.6	0.3	1.0
Minimum:	3,633.0	0.0	3,633.0	105,000.0	381.5	0.5	0.2	0.8
Maximum:	4,754.2	655.6	5,232.2	105,000.0	549.4	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/11/2025 00:00	4,765.4	359.6	5,125.0	105,000.0	538.1	0.6	0.3	1.1			
09/11/2025 01:00	4,770.3	356.5	5,126.8	105,000.0	538.3	0.6	0.3	1.1			
09/11/2025 02:00	4,781.9	341.4	5,123.3	105,000.0	537.9	0.6	0.3	1.1			
09/11/2025 03:00	4,788.1	330.5	5,118.6	105,000.0	537.5	0.6	0.3	1.1			
09/11/2025 04:00	4,788.5	327.5	5,116.0	105,000.0	537.2	0.6	0.3	1.1			
09/11/2025 05:00	4,793.9	347.2	5,141.1	105,000.0	539.8	0.6	0.3	1.1			
09/11/2025 06:00	4,797.1	314.3	5,111.4	105,000.0	536.7	0.6	0.3	1.1			
09/11/2025 07:00	4,772.9	338.2	5,111.1	105,000.0	536.7	0.6	0.3	1.1			
09/11/2025 08:00	4,734.7	380.8	5,115.5	105,000.0	537.1	0.6	0.3	1.1			
09/11/2025 09:00	4,695.2	447.2	5,142.4	105,000.0	540.0	0.6	0.3	1.1			
09/11/2025 10:00	4,664.9	470.9	5,135.8	105,000.0	539.3	0.6	0.3	1.1			
09/11/2025 11:00	4,574.0	427.8	4,907.7	105,000.0	515.3	0.6	0.3	1.1			
09/11/2025 12:00	4,148.4	136.1	4,179.7	105,000.0	438.9	0.5	0.3	0.9			
09/11/2025 13:00	4,558.5	676.2	5,234.7	105,000.0	549.6	0.7	0.3	1.1			
09/11/2025 14:00	4,530.8	675.6	5,206.4	105,000.0	546.7	0.7	0.3	1.1			
09/11/2025 15:00	4,520.6	677.0	5,197.6	105,000.0	545.7	0.7	0.3	1.1			
09/11/2025 16:00	4,508.1	726.9	5,235.0	105,000.0	549.7	0.7	0.3	1.1			
09/11/2025 17:00	4,509.2	716.9	5,226.1	105,000.0	548.7	0.7	0.3	1.1			
09/11/2025 18:00	4,545.6	673.1	5,218.7	105,000.0	548.0	0.7	0.3	1.1			
09/11/2025 19:00	4,571.1	651.8	5,222.9	105,000.0	548.4	0.7	0.3	1.1			
09/11/2025 20:00	4,626.3	652.0	5,278.3	105,000.0	554.2	0.7	0.3	1.1			
09/11/2025 21:00	4,661.9	652.4	5,314.3	105,000.0	558.0	0.7	0.3	1.1			
09/11/2025 22:00	4,664.4	565.5	5,229.9	105,000.0	549.1	0.7	0.3	1.1			
09/11/2025 23:00	4,699.8	491.6	5,191.4	105,000.0	545.1	0.7	0.3	1.1			
Average/Sum#:	4,644.7	489.0	5,125.4	105,000.0	538.2	0.6	0.3	1.1			
Minimum:	4,148.4	136.1	4,179.7	105,000.0	438.9	0.5	0.3	0.9			
Maximum:	4,797.1	726.9	5,314.3	105,000.0	558.0	0.7	0.3	1.1			
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/12/2025 00:00	4,716.6	473.4	5,190.0	105,000.0	545.0	0.7	0.3	1.1
09/12/2025 01:00	4,727.5	433.7	5,161.2	105,000.0	541.9	0.7	0.3	1.1
09/12/2025 02:00	4,739.5	415.8	5,155.3	105,000.0	541.3	0.7	0.3	1.1
09/12/2025 03:00	4,747.0	417.0	5,164.0	105,000.0	542.2	0.7	0.3	1.1
09/12/2025 04:00	4,755.3	426.0	5,181.3	105,000.0	544.0	0.7	0.3	1.1
09/12/2025 05:00	4,767.1	366.7	5,133.8	105,000.0	539.0	0.6	0.3	1.1
09/12/2025 06:00	4,774.4	359.4	5,133.8	105,000.0	539.0	0.6	0.3	1.1
09/12/2025 07:00	4,430.9	185.9	4,527.6	105,000.0	475.4	0.6	0.3	1.0
09/12/2025 08:00	4,165.0	101.2	4,188.3	105,000.0	439.8	0.5	0.3	0.9
09/12/2025 09:00	4,651.6	529.0	5,180.6	105,000.0	544.0	0.7	0.3	1.1
09/12/2025 10:00	4,100.4	141.2	4,139.9	105,000.0	434.7	0.5	0.3	0.9
09/12/2025 11:00	3,624.3	0.0	3,624.3	105,000.0	380.6	0.5	0.2	0.8
09/12/2025 12:00	3,623.2	0.0	3,623.2	105,000.0	380.4	0.5	0.2	0.8
09/12/2025 13:00	3,680.7	0.0	3,680.7	105,000.0	386.5	0.5	0.2	0.8
09/12/2025 14:00	4,413.3	633.9	4,920.4	105,000.0	516.6	0.6	0.3	1.1
09/12/2025 15:00	4,396.1	859.1	5,255.2	105,000.0	551.8	0.7	0.3	1.1
09/12/2025 16:00	4,359.2	908.7	5,267.9	105,000.0	553.1	0.7	0.3	1.1
09/12/2025 17:00	4,364.3	899.3	5,263.6	105,000.0	552.7	0.7	0.3	1.1
09/12/2025 18:00	4,491.1	746.5	5,237.6	105,000.0	549.9	0.7	0.3	1.1
09/12/2025 19:00	4,545.7	676.5	5,222.2	105,000.0	548.3	0.7	0.3	1.1
09/12/2025 20:00	4,593.1	607.4	5,200.5	105,000.0	546.1	0.7	0.3	1.1
09/12/2025 21:00	4,623.3	575.0	5,198.3	105,000.0	545.8	0.7	0.3	1.1
09/12/2025 22:00	4,655.3	537.6	5,192.9	105,000.0	545.3	0.7	0.3	1.1
09/12/2025 23:00	4,695.6	484.6	5,180.2	105,000.0	543.9	0.7	0.3	1.1
Average/Sum#:	4,443.4	449.1	4,876.0	105,000.0	512.0	0.6	0.3	1.0
Minimum:	3,623.2	0.0	3,623.2	105,000.0	380.4	0.5	0.2	0.8
Maximum:	4,774.4	908.7	5,267.9	105,000.0	553.1	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/13/2025 00:00	4,715.8	447.1	5,162.9	105,000.0	542.1	0.7	0.3	1.1			
09/13/2025 01:00	4,733.3	421.0	5,154.3	105,000.0	541.2	0.7	0.3	1.1			
09/13/2025 02:00	4,748.1	394.9	5,143.0	105,000.0	540.0	0.6	0.3	1.1			
09/13/2025 03:00	4,768.6	371.0	5,139.6	105,000.0	539.7	0.7	0.3	1.1			
09/13/2025 04:00	4,779.6	348.3	5,127.9	105,000.0	538.4	0.6	0.3	1.1			
09/13/2025 05:00	4,789.0	339.7	5,128.7	105,000.0	538.5	0.6	0.3	1.1			
09/13/2025 06:00	4,690.5	264.0	4,893.8	105,000.0	513.8	0.6	0.3	1.0			
09/13/2025 07:00	3,657.9	0.0	3,657.9	105,000.0	384.1	0.5	0.2	0.8			
09/13/2025 08:00	3,656.8	0.0	3,656.8	105,000.0	384.0	0.5	0.2	0.8			
09/13/2025 09:00	3,655.4	0.0	3,655.4	105,000.0	383.8	0.5	0.2	0.8			
09/13/2025 10:00	3,649.3	0.0	3,649.3	105,000.0	383.2	0.5	0.2	0.8			
09/13/2025 11:00	3,642.7	0.0	3,642.7	105,000.0	382.5	0.5	0.2	0.8			
09/13/2025 12:00	3,638.8	0.0	3,638.8	105,000.0	382.1	0.5	0.2	0.8			
09/13/2025 13:00	3,638.5	11.4	3,638.5	105,000.0	382.0	0.5	0.2	0.8			
09/13/2025 14:00	3,635.2	0.0	3,635.2	105,000.0	381.7	0.5	0.2	0.8			
09/13/2025 15:00	3,636.3	0.0	3,636.3	105,000.0	381.8	0.5	0.2	0.8			
09/13/2025 16:00	4,072.0	258.9	4,175.6	105,000.0	438.4	0.5	0.3	0.9			
09/13/2025 17:00	4,441.5	850.1	5,291.6	105,000.0	555.6	0.7	0.3	1.1			
09/13/2025 18:00	4,530.8	731.7	5,262.5	105,000.0	552.6	0.7	0.3	1.1			
09/13/2025 19:00	4,612.0	615.1	5,227.1	105,000.0	548.8	0.7	0.3	1.1			
09/13/2025 20:00	4,650.1	566.7	5,216.8	105,000.0	547.8	0.7	0.3	1.1			
09/13/2025 21:00	4,676.0	525.0	5,201.0	105,000.0	546.1	0.7	0.3	1.1			
09/13/2025 22:00	4,706.7	473.0	5,179.7	105,000.0	543.9	0.7	0.3	1.1			
09/13/2025 23:00	4,731.7	445.0	5,176.7	105,000.0	543.6	0.7	0.3	1.1			
Average/Sum#:	4,269.0	294.3	4,553.8	105,000.0	478.2	0.6	0.3	1.0			
Minimum:	3,635.2	0.0	3,635.2	105,000.0	381.7	0.5	0.2	0.8			
Maximum:	4,789.0	850.1	5,291.6	105,000.0	555.6	0.7	0.3	1.1			
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/14/2025 00:00	4,749.6	418.6	5,168.2	105,000.0	542.7	0.7	0.3	1.1
09/14/2025 01:00	4,762.5	396.0	5,158.5	105,000.0	541.6	0.7	0.3	1.1
09/14/2025 02:00	4,769.8	380.5	5,150.3	105,000.0	540.8	0.6	0.3	1.1
09/14/2025 03:00	4,773.8	375.1	5,148.9	105,000.0	540.6	0.6	0.3	1.1
09/14/2025 04:00	4,780.1	363.0	5,143.1	105,000.0	540.0	0.7	0.3	1.1
09/14/2025 05:00	4,788.9	353.7	5,142.6	105,000.0	540.0	0.6	0.3	1.1
09/14/2025 06:00	4,410.5	178.6	4,503.4	105,000.0	472.9	0.6	0.3	1.0
09/14/2025 07:00	3,651.8	0.0	3,651.8	105,000.0	383.4	0.5	0.2	0.8
09/14/2025 08:00	3,651.1	0.0	3,651.1	105,000.0	383.4	0.5	0.2	0.8
09/14/2025 09:00	3,647.8	0.0	3,647.8	105,000.0	383.0	0.5	0.2	0.8
09/14/2025 10:00	3,647.6	0.0	3,647.6	105,000.0	383.0	0.5	0.2	0.8
09/14/2025 11:00	3,644.4	0.0	3,644.4	105,000.0	382.7	0.5	0.2	0.8
09/14/2025 12:00	3,640.8	0.5	3,640.8	105,000.0	382.3	0.5	0.2	0.8
09/14/2025 13:00	3,638.0	12.2	3,638.0	105,000.0	382.0	0.5	0.2	0.8
09/14/2025 14:00	3,633.8	0.0	3,633.8	105,000.0	381.5	0.5	0.2	0.8
09/14/2025 15:00	3,633.0	0.0	3,633.0	105,000.0	381.5	0.5	0.2	0.8
09/14/2025 16:00	4,055.3	275.0	4,165.3	105,000.0	437.4	0.5	0.3	0.9
09/14/2025 17:00	4,408.2	874.0	5,282.2	105,000.0	554.6	0.7	0.3	1.1
09/14/2025 18:00	4,468.7	778.9	5,247.6	105,000.0	551.0	0.7	0.3	1.1
09/14/2025 19:00	4,532.6	693.0	5,225.6	105,000.0	548.7	0.7	0.3	1.1
09/14/2025 20:00	4,620.5	597.5	5,218.0	105,000.0	547.9	0.7	0.3	1.1
09/14/2025 21:00	4,627.1	594.9	5,222.0	105,000.0	548.3	0.7	0.3	1.1
09/14/2025 22:00	4,651.8	571.7	5,223.5	105,000.0	548.5	0.7	0.3	1.1
09/14/2025 23:00	4,676.6	531.4	5,208.0	105,000.0	546.8	0.7	0.3	1.1
Average/Sum#:	4,244.3	308.1	4,541.5	105,000.0	476.9	0.6	0.3	1.0
Minimum:	3,633.0	0.0	3,633.0	105,000.0	381.5	0.5	0.2	0.8
Maximum:	4,788.9	874.0	5,282.2	105,000.0	554.6	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/15/2025 00:00	4,700.9	497.5	5,198.4	105,000.0	545.8	0.7	0.3	1.1
09/15/2025 01:00	4,713.8	469.2	5,183.0	105,000.0	544.2	0.7	0.3	1.1
09/15/2025 02:00	4,731.0	439.5	5,170.5	105,000.0	542.9	0.7	0.3	1.1
09/15/2025 03:00	4,742.1	418.6	5,160.7	105,000.0	541.9	0.7	0.3	1.1
09/15/2025 04:00	4,757.9	378.7	5,136.6	105,000.0	539.3	0.6	0.3	1.1
09/15/2025 05:00	4,781.6	311.1	5,092.7	105,000.0	534.7	0.6	0.3	1.1
09/15/2025 06:00	4,783.2	313.5	5,096.7	105,000.0	535.2	0.6	0.3	1.1
09/15/2025 07:00	4,740.6	387.1	5,127.7	105,000.0	538.4	0.6	0.3	1.1
09/15/2025 08:00	4,665.9	505.5	5,171.4	105,000.0	543.0	0.7	0.3	1.1
09/15/2025 09:00	4,608.2	587.3	5,195.5	105,000.0	545.5	0.7	0.3	1.1
09/15/2025 10:00	4,415.9	146.5	4,455.5	105,000.0	467.8	0.6	0.3	1.0
09/15/2025 11:00	4,496.7	758.4	5,255.1	105,000.0	551.8	0.7	0.3	1.1
09/15/2025 12:00	4,403.3	901.7	5,305.0	105,000.0	557.0	0.7	0.3	1.1
09/15/2025 13:00	4,311.3	1,044.6	5,355.9	105,000.0	562.4	0.7	0.3	1.1
09/15/2025 14:00	4,506.5	1,504.8	6,011.3	105,000.0	631.2	0.8	0.4	1.3
09/15/2025 15:00	4,444.2	1,168.8	5,613.0	105,000.0	589.4	0.7	0.4	1.2
09/15/2025 16:00	4,406.0	1,310.5	5,716.5	105,000.0	600.2	0.7	0.4	1.2
09/15/2025 17:00	4,644.4	704.7	5,349.1	105,000.0	561.7	0.7	0.3	1.1
09/15/2025 18:00	4,662.7	699.4	5,362.1	105,000.0	563.0	0.7	0.3	1.1
09/15/2025 19:00	4,702.4	490.3	5,192.7	105,000.0	545.2	0.7	0.3	1.1
09/15/2025 20:00	4,718.8	453.1	5,171.9	105,000.0	543.0	0.7	0.3	1.1
09/15/2025 21:00	4,728.4	440.7	5,169.1	105,000.0	542.8	0.7	0.3	1.1
09/15/2025 22:00	4,748.7	411.5	5,160.2	105,000.0	541.8	0.7	0.3	1.1
09/15/2025 23:00	4,751.0	397.2	5,148.2	105,000.0	540.6	0.6	0.3	1.1
Average/Sum#:	4,631.9	614.2	5,241.6	105,000.0	550.4	0.7	0.3	1.1
Minimum:	4,311.3	146.5	4,455.5	105,000.0	467.8	0.6	0.3	1.0
Maximum:	4,783.2	1,504.8	6,011.3	105,000.0	631.2	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/16/2025 00:00	4,778.3	366.2	5,144.5	105,000.0	540.2	0.6	0.3	1.1
09/16/2025 01:00	4,766.0	391.5	5,157.5	105,000.0	541.5	0.7	0.3	1.1
09/16/2025 02:00	4,769.0	383.8	5,152.8	105,000.0	541.0	0.7	0.3	1.1
09/16/2025 03:00	4,798.7	344.9	5,143.6	105,000.0	540.1	0.6	0.3	1.1
09/16/2025 04:00	4,812.2	307.7	5,119.9	105,000.0	537.6	0.6	0.3	1.1
09/16/2025 05:00	4,761.9	372.1	5,134.0	105,000.0	539.1	0.6	0.3	1.1
09/16/2025 06:00	4,750.3	384.0	5,134.3	105,000.0	539.1	0.6	0.3	1.1
09/16/2025 07:00	4,711.4	450.8	5,162.2	105,000.0	542.0	0.7	0.3	1.1
09/16/2025 08:00	4,638.1	573.7	5,211.8	105,000.0	547.2	0.7	0.3	1.1
09/16/2025 09:00	4,541.3	713.7	5,255.0	105,000.0	551.8	0.7	0.3	1.1
09/16/2025 10:00	4,429.7	850.5	5,280.2	105,000.0	554.4	0.7	0.3	1.1
09/16/2025 11:00	4,326.8	1,001.5	5,328.3	105,000.0	559.5	0.7	0.3	1.1
09/16/2025 12:00	4,224.8	1,163.6	5,388.4	105,000.0	565.8	0.7	0.3	1.1
09/16/2025 13:00	4,153.8	1,277.9	5,431.7	105,000.0	570.3	0.7	0.3	1.1
09/16/2025 14:00	4,109.1	1,332.3	5,441.4	105,000.0	571.3	0.7	0.3	1.1
09/16/2025 15:00	4,506.9	789.3	5,296.2	105,000.0	556.1	0.7	0.3	1.1
09/16/2025 16:00	4,608.9	742.3	5,351.2	105,000.0	561.9	0.7	0.3	1.1
09/16/2025 17:00	4,609.8	657.5	5,267.3	105,000.0	553.1	0.7	0.3	1.1
09/16/2025 18:00	4,615.0	641.4	5,256.4	105,000.0	551.9	0.7	0.3	1.1
09/16/2025 19:00	4,529.5	739.3	5,268.8	105,000.0	553.2	0.7	0.3	1.1
09/16/2025 20:00	4,409.2	865.0	5,274.2	105,000.0	553.8	0.7	0.3	1.1
09/16/2025 21:00	4,512.4	748.4	5,260.8	105,000.0	552.4	0.7	0.3	1.1
09/16/2025 22:00	4,601.9	624.4	5,226.3	105,000.0	548.8	0.7	0.3	1.1
09/16/2025 23:00	4,592.0	636.2	5,228.2	105,000.0	549.0	0.7	0.3	1.1
Average/Sum#:	4,564.9	681.6	5,246.5	105,000.0	550.9	0.7	0.3	1.1
Minimum:	4,109.1	307.7	5,119.9	105,000.0	537.6	0.6	0.3	1.1
Maximum:	4,812.2	1,332.3	5,441.4	105,000.0	571.3	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/17/2025 00:00	4,615.2	607.8	5,223.0	105,000.0	548.4	0.7	0.3	1.1
09/17/2025 01:00	4,632.6	579.1	5,211.7	105,000.0	547.2	0.7	0.3	1.1
09/17/2025 02:00	4,657.3	570.1	5,227.4	105,000.0	548.9	0.7	0.3	1.1
09/17/2025 03:00	4,671.9	543.5	5,215.4	105,000.0	547.6	0.7	0.3	1.1
09/17/2025 04:00	4,711.9	465.2	5,177.1	105,000.0	543.6	0.7	0.3	1.1
09/17/2025 05:00	4,753.8	372.9	5,126.7	105,000.0	538.3	0.6	0.3	1.1
09/17/2025 06:00	4,749.5	365.9	5,115.4	105,000.0	537.1	0.6	0.3	1.1
09/17/2025 07:00	4,682.6	473.8	5,156.4	105,000.0	541.4	0.7	0.3	1.1
09/17/2025 08:00	4,590.3	635.0	5,225.3	105,000.0	548.7	0.7	0.3	1.1
09/17/2025 09:00	4,497.3	765.2	5,262.5	105,000.0	552.6	0.7	0.3	1.1
09/17/2025 10:00	4,363.6	948.6	5,312.2	105,000.0	557.8	0.7	0.3	1.1
09/17/2025 11:00	4,249.7	1,117.6	5,367.3	105,000.0	563.6	0.7	0.3	1.1
09/17/2025 12:00	4,141.6	1,281.9	5,423.5	105,000.0	569.5	0.7	0.3	1.1
09/17/2025 13:00	4,078.1	1,399.6	5,477.7	105,000.0	575.2	0.7	0.3	1.2
09/17/2025 14:00	4,588.6	832.4	5,421.0	105,000.0	569.2	0.7	0.3	1.1
09/17/2025 15:00	4,597.3	782.5	5,379.8	105,000.0	564.9	0.7	0.3	1.1
09/17/2025 16:00	4,599.7	657.6	5,257.3	105,000.0	552.0	0.7	0.3	1.1
09/17/2025 17:00	4,092.5	1,353.1	5,445.6	105,000.0	571.8	0.7	0.3	1.1
09/17/2025 18:00	4,094.6	1,330.8	5,425.4	105,000.0	569.7	0.7	0.3	1.1
09/17/2025 19:00	4,216.7	1,136.1	5,352.8	105,000.0	562.0	0.7	0.3	1.1
09/17/2025 20:00	4,319.5	978.3	5,297.8	105,000.0	556.3	0.7	0.3	1.1
09/17/2025 21:00	4,384.0	851.1	5,235.1	105,000.0	549.7	0.7	0.3	1.1
09/17/2025 22:00	4,456.9	786.5	5,243.4	105,000.0	550.6	0.7	0.3	1.1
09/17/2025 23:00	4,490.2	743.6	5,233.8	105,000.0	549.5	0.7	0.3	1.1
Average/Sum#:	4,468.1	815.8	5,283.9	105,000.0	554.8	0.7	0.3	1.1
Minimum:	4,078.1	365.9	5,115.4	105,000.0	537.1	0.6	0.3	1.1
Maximum:	4,753.8	1,399.6	5,477.7	105,000.0	575.2	0.7	0.3	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/18/2025 00:00	4,525.9	697.4	5,223.3	105,000.0	548.4	0.7	0.3	0.3	1.1	1.1
09/18/2025 01:00	4,554.7	660.3	5,215.0	105,000.0	547.6	0.7	0.3	0.3	1.1	1.1
09/18/2025 02:00	4,565.7	652.9	5,218.6	105,000.0	548.0	0.7	0.3	0.3	1.1	1.1
09/18/2025 03:00	4,588.2	607.8	5,196.0	105,000.0	545.6	0.7	0.3	0.3	1.1	1.1
09/18/2025 04:00	4,608.6	566.4	5,175.0	105,000.0	543.4	0.7	0.3	0.3	1.1	1.1
09/18/2025 05:00	4,630.7	504.6	5,135.3	105,000.0	539.2	0.6	0.3	0.3	1.1	1.1
09/18/2025 06:00	4,636.7	543.2	5,179.9	105,000.0	543.9	0.7	0.3	0.3	1.1	1.1
09/18/2025 07:00	4,602.7	982.4	5,585.1	105,000.0	586.4	0.7	0.4	0.4	1.2	1.2
09/18/2025 08:00	4,556.7	657.4	5,214.1	105,000.0	547.5	0.7	0.3	0.3	1.1	1.1
09/18/2025 09:00	4,493.5	837.4	5,330.9	105,000.0	559.7	0.7	0.3	0.3	1.1	1.1
09/18/2025 10:00	4,407.5	870.0	5,277.5	105,000.0	554.1	0.7	0.3	0.3	1.1	1.1
09/18/2025 11:00	4,349.3	974.6	5,323.9	105,000.0	559.0	0.7	0.3	0.3	1.1	1.1
09/18/2025 12:00	4,299.1	1,067.5	5,366.6	105,000.0	563.5	0.7	0.3	0.3	1.1	1.1
09/18/2025 13:00	4,247.3	1,256.3	5,503.6	105,000.0	577.9	0.7	0.3	0.3	1.2	1.2
09/18/2025 14:00	4,267.9	1,100.3	5,368.2	105,000.0	563.7	0.7	0.3	0.3	1.1	1.1
09/18/2025 15:00	4,392.8	1,222.3	5,615.1	105,000.0	589.6	0.7	0.4	0.4	1.2	1.2
09/18/2025 16:00	4,416.5	922.7	5,339.2	105,000.0	560.6	0.7	0.3	0.3	1.1	1.1
09/18/2025 17:00	4,394.2	916.8	5,311.0	105,000.0	557.7	0.7	0.3	0.3	1.1	1.1
09/18/2025 18:00	4,477.6	784.4	5,262.0	105,000.0	552.5	0.7	0.3	0.3	1.1	1.1
09/18/2025 19:00	4,510.2	741.4	5,251.6	105,000.0	551.4	0.7	0.3	0.3	1.1	1.1
09/18/2025 20:00	4,526.7	718.1	5,244.8	105,000.0	550.7	0.7	0.3	0.3	1.1	1.1
09/18/2025 21:00	4,551.0	687.0	5,238.0	105,000.0	550.0	0.7	0.3	0.3	1.1	1.1
09/18/2025 22:00	4,569.2	665.1	5,234.3	105,000.0	549.6	0.7	0.3	0.3	1.1	1.1
09/18/2025 23:00	4,578.1	649.9	5,228.0	105,000.0	548.9	0.7	0.3	0.3	1.1	1.1
Average/Sum#:	4,489.6	803.6	5,293.2	105,000.0	555.8	0.7	0.3	0.3	1.1	1.1
Minimum:	4,247.3	504.6	5,135.3	105,000.0	539.2	0.6	0.3	0.3	1.1	1.1
Maximum:	4,636.7	1,256.3	5,615.1	105,000.0	589.6	0.7	0.4	0.4	1.2	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:					> 4.73		> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/19/2025 00:00	4,592.7	630.7	5,223.4	105,000.0	548.5	0.7	0.3	0.3	1.1	1.1
09/19/2025 01:00	4,617.5	611.6	5,229.1	105,000.0	549.1	0.7	0.3	0.3	1.1	1.1
09/19/2025 02:00	4,637.6	592.9	5,230.5	105,000.0	549.2	0.7	0.3	0.3	1.1	1.1
09/19/2025 03:00	4,668.4	562.1	5,230.5	105,000.0	549.2	0.7	0.3	0.3	1.1	1.1
09/19/2025 04:00	4,680.2	552.3	5,232.5	105,000.0	549.4	0.7	0.3	0.3	1.1	1.1
09/19/2025 05:00	4,692.7	543.6	5,236.3	105,000.0	549.8	0.7	0.3	0.3	1.1	1.1
09/19/2025 06:00	4,693.5	607.4	5,300.9	105,000.0	556.6	0.7	0.3	0.3	1.1	1.1
09/19/2025 07:00	4,707.3	469.5	5,176.8	105,000.0	543.6	0.7	0.3	0.3	1.1	1.1
09/19/2025 08:00	4,695.4	502.6	5,198.0	105,000.0	545.8	0.7	0.3	0.3	1.1	1.1
09/19/2025 09:00	4,677.3	528.4	5,205.7	105,000.0	546.6	0.7	0.3	0.3	1.1	1.1
09/19/2025 10:00	4,658.7	542.1	5,200.8	105,000.0	546.1	0.7	0.3	0.3	1.1	1.1
09/19/2025 11:00	4,640.9	567.8	5,208.7	105,000.0	546.9	0.7	0.3	0.3	1.1	1.1
09/19/2025 12:00	4,639.6	558.5	5,198.1	105,000.0	545.8	0.7	0.3	0.3	1.1	1.1
09/19/2025 13:00	4,582.9	624.6	5,207.5	105,000.0	546.8	0.7	0.3	0.3	1.1	1.1
09/19/2025 14:00	4,528.2	774.9	5,303.1	105,000.0	556.8	0.7	0.3	0.3	1.1	1.1
09/19/2025 15:00	4,546.0	705.9	5,251.9	105,000.0	551.4	0.7	0.3	0.3	1.1	1.1
09/19/2025 16:00	4,558.8	721.7	5,280.5	105,000.0	554.5	0.7	0.3	0.3	1.1	1.1
09/19/2025 17:00	4,561.6	684.2	5,245.8	105,000.0	550.8	0.7	0.3	0.3	1.1	1.1
09/19/2025 18:00	4,587.4	655.6	5,243.0	105,000.0	550.5	0.7	0.3	0.3	1.1	1.1
09/19/2025 19:00	4,608.6	617.8	5,226.4	105,000.0	548.8	0.7	0.3	0.3	1.1	1.1
09/19/2025 20:00	4,595.5	697.3	5,292.8	105,000.0	555.7	0.7	0.3	0.3	1.1	1.1
09/19/2025 21:00	4,618.4	1,285.5	5,903.9	105,000.0	619.9	0.7	0.4	0.4	1.2	1.2
09/19/2025 22:00	4,668.7	752.9	5,421.6	105,000.0	569.3	0.7	0.3	0.3	1.1	1.1
09/19/2025 23:00	4,673.9	541.0	5,214.9	105,000.0	547.6	0.7	0.3	0.3	1.1	1.1
Average/Sum#:	4,630.5	638.8	5,269.3	105,000.0	553.3	0.7	0.3	0.3	1.1	1.1
Minimum:	4,528.2	469.5	5,176.8	105,000.0	543.6	0.7	0.3	0.3	1.1	1.1
Maximum:	4,707.3	1,285.5	5,903.9	105,000.0	619.9	0.7	0.4	0.4	1.2	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/20/2025 00:00	4,690.2	515.4	5,205.6	105,000.0	546.6	0.7	0.3	1.1
09/20/2025 01:00	4,715.1	485.4	5,200.5	105,000.0	546.1	0.7	0.3	1.1
09/20/2025 02:00	4,726.3	451.0	5,177.3	105,000.0	543.6	0.7	0.3	1.1
09/20/2025 03:00	4,734.1	444.4	5,178.5	105,000.0	543.7	0.7	0.3	1.1
09/20/2025 04:00	4,749.2	419.1	5,168.3	105,000.0	542.7	0.7	0.3	1.1
09/20/2025 05:00	4,770.9	396.3	5,167.2	105,000.0	542.6	0.7	0.3	1.1
09/20/2025 06:00	4,777.9	384.4	5,162.3	105,000.0	542.0	0.7	0.3	1.1
09/20/2025 07:00	4,752.2	425.8	5,178.0	105,000.0	543.7	0.7	0.3	1.1
09/20/2025 08:00	4,704.6	490.4	5,195.0	105,000.0	545.5	0.7	0.3	1.1
09/20/2025 09:00	4,630.1	598.5	5,228.6	105,000.0	549.0	0.7	0.3	1.1
09/20/2025 10:00	4,568.9	681.0	5,249.9	105,000.0	551.2	0.7	0.3	1.1
09/20/2025 11:00	4,522.7	740.5	5,263.2	105,000.0	552.6	0.7	0.3	1.1
09/20/2025 12:00	4,454.7	819.6	5,274.3	105,000.0	553.8	0.7	0.3	1.1
09/20/2025 13:00	4,427.7	847.8	5,275.5	105,000.0	553.9	0.7	0.3	1.1
09/20/2025 14:00	4,386.6	900.4	5,287.0	105,000.0	555.1	0.7	0.3	1.1
09/20/2025 15:00	4,346.6	966.9	5,313.5	105,000.0	557.9	0.7	0.3	1.1
09/20/2025 16:00	4,424.5	1,218.4	5,642.9	105,000.0	592.5	0.7	0.4	1.2
09/20/2025 17:00	4,471.5	864.8	5,336.3	105,000.0	560.3	0.7	0.3	1.1
09/20/2025 18:00	4,399.3	832.9	5,232.2	105,000.0	549.4	0.7	0.3	1.1
09/20/2025 19:00	4,506.1	725.9	5,232.0	105,000.0	549.4	0.7	0.3	1.1
09/20/2025 20:00	4,571.8	638.5	5,210.3	105,000.0	547.1	0.7	0.3	1.1
09/20/2025 21:00	4,578.9	645.1	5,224.0	105,000.0	548.5	0.7	0.3	1.1
09/20/2025 22:00	4,602.0	640.8	5,242.8	105,000.0	550.5	0.7	0.3	1.1
09/20/2025 23:00	4,633.0	564.0	5,197.0	105,000.0	545.7	0.7	0.3	1.1
Average/Sum#:	4,589.4	654.1	5,243.4	105,000.0	550.6	0.7	0.3	1.1
Minimum:	4,346.6	384.4	5,162.3	105,000.0	542.0	0.7	0.3	1.1
Maximum:	4,777.9	1,218.4	5,642.9	105,000.0	592.5	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/21/2025 00:00	4,658.3	524.5	5,182.8	105,000.0	544.2	0.7	0.3	0.3	1.1	1.1
09/21/2025 01:00	4,676.0	506.4	5,182.4	105,000.0	544.2	0.7	0.3	0.3	1.1	1.1
09/21/2025 02:00	4,702.5	486.2	5,188.7	105,000.0	544.8	0.7	0.3	0.3	1.1	1.1
09/21/2025 03:00	4,725.1	464.9	5,190.0	105,000.0	545.0	0.7	0.3	0.3	1.1	1.1
09/21/2025 04:00	4,738.4	437.2	5,175.6	105,000.0	543.4	0.7	0.3	0.3	1.1	1.1
09/21/2025 05:00	4,753.4	420.8	5,174.2	105,000.0	543.3	0.7	0.3	0.3	1.1	1.1
09/21/2025 06:00	4,756.2	418.6	5,174.8	105,000.0	543.4	0.7	0.3	0.3	1.1	1.1
09/21/2025 07:00	4,717.0	466.6	5,183.6	105,000.0	544.3	0.7	0.3	0.3	1.1	1.1
09/21/2025 08:00	4,653.2	541.3	5,194.5	105,000.0	545.4	0.7	0.3	0.3	1.1	1.1
09/21/2025 09:00	4,594.0	618.9	5,212.9	105,000.0	547.4	0.7	0.3	0.3	1.1	1.1
09/21/2025 10:00	4,521.9	719.1	5,241.0	105,000.0	550.3	0.7	0.3	0.3	1.1	1.1
09/21/2025 11:00	4,395.7	880.0	5,275.7	105,000.0	553.9	0.7	0.3	0.3	1.1	1.1
09/21/2025 12:00	4,307.8	1,018.1	5,325.9	105,000.0	559.2	0.7	0.3	0.3	1.1	1.1
09/21/2025 13:00	4,275.9	1,074.1	5,350.0	105,000.0	561.8	0.7	0.3	0.3	1.1	1.1
09/21/2025 14:00	4,240.7	1,118.4	5,359.1	105,000.0	562.7	0.7	0.3	0.3	1.1	1.1
09/21/2025 15:00	4,205.6	1,164.3	5,369.9	105,000.0	563.8	0.7	0.3	0.3	1.1	1.1
09/21/2025 16:00	4,189.6	1,185.4	5,375.0	105,000.0	564.4	0.7	0.3	0.3	1.1	1.1
09/21/2025 17:00	4,237.5	1,118.9	5,356.4	105,000.0	562.4	0.7	0.3	0.3	1.1	1.1
09/21/2025 18:00	4,344.5	962.0	5,306.5	105,000.0	557.2	0.7	0.3	0.3	1.1	1.1
09/21/2025 19:00	4,458.2	798.4	5,256.6	105,000.0	551.9	0.7	0.3	0.3	1.1	1.1
09/21/2025 20:00	4,494.1	756.0	5,250.1	105,000.0	551.3	0.7	0.3	0.3	1.1	1.1
09/21/2025 21:00	4,502.4	742.0	5,244.4	105,000.0	550.7	0.7	0.3	0.3	1.1	1.1
09/21/2025 22:00	4,536.8	697.6	5,234.4	105,000.0	549.6	0.7	0.3	0.3	1.1	1.1
09/21/2025 23:00	4,573.8	665.7	5,239.5	105,000.0	550.1	0.7	0.3	0.3	1.1	1.1
Average/Sum#:	4,510.8	741.1	5,251.8	105,000.0	551.4	0.7	0.3	0.3	1.1	1.1
Minimum:	4,189.6	418.6	5,174.2	105,000.0	543.3	0.7	0.3	0.3	1.1	1.1
Maximum:	4,756.2	1,185.4	5,375.0	105,000.0	564.4	0.7	0.3	0.3	1.1	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/22/2025 00:00	4,594.0	629.3	5,223.3	105,000.0	548.4	0.7	0.3	0.3	1.1	1.1	1.1
09/22/2025 01:00	4,607.6	605.9	5,213.5	105,000.0	547.4	0.7	0.3	0.3	1.1	1.1	1.1
09/22/2025 02:00	4,625.5	575.3	5,200.8	105,000.0	546.1	0.7	0.3	0.3	1.1	1.1	1.1
09/22/2025 03:00	4,640.7	546.1	5,186.8	105,000.0	544.6	0.7	0.3	0.3	1.1	1.1	1.1
09/22/2025 04:00	4,660.5	491.0	5,151.5	105,000.0	540.9	0.6	0.3	0.3	1.1	1.1	1.1
09/22/2025 05:00	4,702.3	427.4	5,129.7	105,000.0	538.6	0.6	0.3	0.3	1.1	1.1	1.1
09/22/2025 06:00	4,718.0	404.1	5,122.1	105,000.0	537.8	0.6	0.3	0.3	1.1	1.1	1.1
09/22/2025 07:00	4,650.2	509.6	5,159.8	105,000.0	541.8	0.7	0.3	0.3	1.1	1.1	1.1
09/22/2025 08:00	4,572.0	642.6	5,214.6	105,000.0	547.5	0.7	0.3	0.3	1.1	1.1	1.1
09/22/2025 09:00	4,531.2	713.2	5,244.4	105,000.0	550.7	0.7	0.3	0.3	1.1	1.1	1.1
09/22/2025 10:00	4,029.5	184.5	4,084.9	105,000.0	428.9	0.5	0.3	0.3	0.9	0.9	0.9
09/22/2025 11:00	3,640.0	0.0	3,640.0	105,000.0	382.2	0.5	0.2	0.2	0.8	0.8	0.8
09/22/2025 12:00	4,142.7	165.9	4,189.2	105,000.0	439.9	0.5	0.3	0.3	0.9	0.9	0.9
09/22/2025 13:00	4,593.0	668.2	5,261.2	105,000.0	552.4	0.7	0.3	0.3	1.1	1.1	1.1
09/22/2025 14:00	4,192.4	1,194.6	5,387.0	105,000.0	565.6	0.7	0.3	0.3	1.1	1.1	1.1
09/22/2025 15:00	4,122.0	1,280.9	5,402.9	105,000.0	567.3	0.7	0.3	0.3	1.1	1.1	1.1
09/22/2025 16:00	4,147.4	1,402.2	5,549.6	105,000.0	582.7	0.7	0.3	0.3	1.2	1.2	1.2
09/22/2025 17:00	4,566.5	787.9	5,354.4	105,000.0	562.2	0.7	0.3	0.3	1.1	1.1	1.1
09/22/2025 18:00	4,593.2	665.9	5,259.1	105,000.0	552.2	0.7	0.3	0.3	1.1	1.1	1.1
09/22/2025 19:00	4,618.7	617.7	5,236.4	105,000.0	549.8	0.7	0.3	0.3	1.1	1.1	1.1
09/22/2025 20:00	4,633.9	585.8	5,219.7	105,000.0	548.1	0.7	0.3	0.3	1.1	1.1	1.1
09/22/2025 21:00	4,647.5	575.5	5,223.0	105,000.0	548.4	0.7	0.3	0.3	1.1	1.1	1.1
09/22/2025 22:00	4,667.6	519.7	5,187.3	105,000.0	544.7	0.7	0.3	0.3	1.1	1.1	1.1
09/22/2025 23:00	4,682.1	500.5	5,182.6	105,000.0	544.2	0.7	0.3	0.3	1.1	1.1	1.1
Average/Sum#:	4,482.4	612.2	5,084.3	105,000.0	533.9	0.7	0.3	0.3	1.1	1.1	1.1
Minimum:	3,640.0	0.0	3,640.0	105,000.0	382.2	0.5	0.2	0.2	0.8	0.8	0.8
Maximum:	4,718.0	1,402.2	5,549.6	105,000.0	582.7	0.7	0.3	0.3	1.2	1.2	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/23/2025 00:00	4,704.7	474.6	5,179.3	105,000.0	543.8	0.7	0.3	0.3	1.1	1.1	1.1
09/23/2025 01:00	4,712.6	461.3	5,173.9	105,000.0	543.3	0.7	0.3	0.3	1.1	1.1	1.1
09/23/2025 02:00	4,729.3	448.0	5,177.3	105,000.0	543.6	0.7	0.3	0.3	1.1	1.1	1.1
09/23/2025 03:00	4,734.8	456.2	5,191.0	105,000.0	545.1	0.7	0.3	0.3	1.1	1.1	1.1
09/23/2025 04:00	4,754.4	414.2	5,168.6	105,000.0	542.7	0.7	0.3	0.3	1.1	1.1	1.1
09/23/2025 05:00	4,670.2	521.6	5,191.8	105,000.0	545.1	0.7	0.3	0.3	1.1	1.1	1.1
09/23/2025 06:00	4,704.5	439.0	5,143.5	105,000.0	540.1	0.6	0.3	0.3	1.1	1.1	1.1
09/23/2025 07:00	4,642.4	539.5	5,181.9	105,000.0	544.1	0.7	0.3	0.3	1.1	1.1	1.1
09/23/2025 08:00	4,562.6	677.8	5,240.4	105,000.0	550.2	0.7	0.3	0.3	1.1	1.1	1.1
09/23/2025 09:00	4,476.3	813.5	5,289.8	105,000.0	555.4	0.7	0.3	0.3	1.1	1.1	1.1
09/23/2025 10:00	4,351.1	979.0	5,330.1	105,000.0	559.7	0.7	0.3	0.3	1.1	1.1	1.1
09/23/2025 11:00	4,233.9	1,153.5	5,387.4	105,000.0	565.7	0.7	0.3	0.3	1.1	1.1	1.1
09/23/2025 12:00	4,124.8	1,325.1	5,449.9	105,000.0	572.2	0.7	0.3	0.3	1.1	1.1	1.1
09/23/2025 13:00	4,528.9	770.1	5,299.0	105,000.0	556.4	0.7	0.3	0.3	1.1	1.1	1.1
09/23/2025 14:00	4,575.4	714.0	5,289.4	105,000.0	555.4	0.7	0.3	0.3	1.1	1.1	1.1
09/23/2025 15:00	4,552.3	839.3	5,391.6	105,000.0	566.1	0.7	0.3	0.3	1.1	1.1	1.1
09/23/2025 16:00	4,566.6	936.0	5,502.6	105,000.0	577.8	0.7	0.3	0.3	1.2	1.2	1.2
09/23/2025 17:00	4,568.3	1,507.7	6,076.0	105,000.0	638.0	0.8	0.4	0.4	1.3	1.3	1.3
09/23/2025 18:00	4,544.9	1,217.4	5,762.3	105,000.0	605.0	0.7	0.4	0.4	1.2	1.2	1.2
09/23/2025 19:00	4,181.7	1,142.1	5,323.8	105,000.0	559.0	0.7	0.3	0.3	1.1	1.1	1.1
09/23/2025 20:00	4,298.6	972.9	5,271.5	105,000.0	553.5	0.7	0.3	0.3	1.1	1.1	1.1
09/23/2025 21:00	4,428.7	846.3	5,275.0	105,000.0	553.9	0.7	0.3	0.3	1.1	1.1	1.1
09/23/2025 22:00	4,569.0	653.7	5,222.7	105,000.0	548.4	0.7	0.3	0.3	1.1	1.1	1.1
09/23/2025 23:00	4,588.0	636.7	5,224.7	105,000.0	548.6	0.7	0.3	0.3	1.1	1.1	1.1
Average/Sum#:	4,533.5	789.1	5,322.6	105,000.0	558.9	0.7	0.3	0.3	1.1	1.1	1.1
Minimum:	4,124.8	414.2	5,143.5	105,000.0	540.1	0.6	0.3	0.3	1.1	1.1	1.1
Maximum:	4,754.4	1,507.7	6,076.0	105,000.0	638.0	0.8	0.4	0.4	1.3	1.3	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/24/2025 00:00	4,609.9	589.5	5,199.4	105,000.0	545.9	0.7	0.3	0.3	1.1	1.1	1.1
09/24/2025 01:00	4,631.1	580.2	5,211.3	105,000.0	547.2	0.7	0.3	0.3	1.1	1.1	1.1
09/24/2025 02:00	4,638.0	585.7	5,223.7	105,000.0	548.5	0.7	0.3	0.3	1.1	1.1	1.1
09/24/2025 03:00	4,662.8	541.9	5,204.7	105,000.0	546.5	0.7	0.3	0.3	1.1	1.1	1.1
09/24/2025 04:00	4,673.8	523.0	5,196.8	105,000.0	545.7	0.7	0.3	0.3	1.1	1.1	1.1
09/24/2025 05:00	4,680.3	596.9	5,277.2	105,000.0	554.1	0.7	0.3	0.3	1.1	1.1	1.1
09/24/2025 06:00	4,688.8	514.6	5,203.4	105,000.0	546.4	0.7	0.3	0.3	1.1	1.1	1.1
09/24/2025 07:00	4,674.6	521.2	5,195.8	105,000.0	545.6	0.7	0.3	0.3	1.1	1.1	1.1
09/24/2025 08:00	4,636.7	642.6	5,279.3	105,000.0	554.3	0.7	0.3	0.3	1.1	1.1	1.1
09/24/2025 09:00	4,595.1	802.8	5,397.9	105,000.0	566.8	0.7	0.3	0.3	1.1	1.1	1.1
09/24/2025 10:00	4,548.4	708.8	5,257.2	105,000.0	552.0	0.7	0.3	0.3	1.1	1.1	1.1
09/24/2025 11:00	4,573.9	676.9	5,250.8	105,000.0	551.3	0.7	0.3	0.3	1.1	1.1	1.1
09/24/2025 12:00	4,529.2	751.1	5,280.3	105,000.0	554.4	0.7	0.3	0.3	1.1	1.1	1.1
09/24/2025 13:00	4,420.6	885.1	5,305.7	105,000.0	557.1	0.7	0.3	0.3	1.1	1.1	1.1
09/24/2025 14:00	4,340.3	964.2	5,304.5	105,000.0	557.0	0.7	0.3	0.3	1.1	1.1	1.1
09/24/2025 15:00	4,365.7	887.5	5,253.2	105,000.0	551.6	0.7	0.3	0.3	1.1	1.1	1.1
09/24/2025 16:00	4,391.3	1,025.6	5,416.9	105,000.0	568.8	0.7	0.3	0.3	1.1	1.1	1.1
09/24/2025 17:00	4,479.0	809.5	5,288.5	105,000.0	555.3	0.7	0.3	0.3	1.1	1.1	1.1
09/24/2025 18:00	4,528.8	694.5	5,223.3	105,000.0	548.4	0.7	0.3	0.3	1.1	1.1	1.1
09/24/2025 19:00	4,545.6	683.3	5,228.9	105,000.0	549.0	0.7	0.3	0.3	1.1	1.1	1.1
09/24/2025 20:00	4,541.4	657.4	5,198.8	105,000.0	545.9	0.7	0.3	0.3	1.1	1.1	1.1
09/24/2025 21:00	4,600.1	586.3	5,186.4	105,000.0	544.6	0.7	0.3	0.3	1.1	1.1	1.1
09/24/2025 22:00	4,609.7	575.4	5,185.1	105,000.0	544.4	0.7	0.3	0.3	1.1	1.1	1.1
09/24/2025 23:00	4,613.0	581.6	5,194.6	105,000.0	545.4	0.7	0.3	0.3	1.1	1.1	1.1
Average/Sum#:	4,565.8	682.7	5,248.5	105,000.0	551.1	0.7	0.3	0.3	1.1	1.1	1.1
Minimum:	4,340.3	514.6	5,185.1	105,000.0	544.4	0.7	0.3	0.3	1.1	1.1	1.1
Maximum:	4,688.8	1,025.6	5,416.9	105,000.0	568.8	0.7	0.3	0.3	1.1	1.1	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/25/2025 00:00	4,626.8	562.7	5,189.5	105,000.0	544.9	0.7	0.3	0.3	1.1	1.1
09/25/2025 01:00	4,642.8	540.9	5,183.7	105,000.0	544.3	0.7	0.3	0.3	1.1	1.1
09/25/2025 02:00	4,649.4	521.1	5,170.5	105,000.0	542.9	0.7	0.3	0.3	1.1	1.1
09/25/2025 03:00	4,652.5	510.7	5,163.2	105,000.0	542.1	0.7	0.3	0.3	1.1	1.1
09/25/2025 04:00	4,642.7	554.0	5,196.7	105,000.0	545.7	0.7	0.3	0.3	1.1	1.1
09/25/2025 05:00	4,659.0	538.2	5,197.2	105,000.0	545.7	0.7	0.3	0.3	1.1	1.1
09/25/2025 06:00	4,665.5	563.0	5,228.5	105,000.0	549.0	0.7	0.3	0.3	1.1	1.1
09/25/2025 07:00	4,674.9	527.0	5,201.9	105,000.0	546.2	0.7	0.3	0.3	1.1	1.1
09/25/2025 08:00	4,650.6	564.9	5,215.5	105,000.0	547.6	0.7	0.3	0.3	1.1	1.1
09/25/2025 09:00	4,601.2	625.2	5,226.4	105,000.0	548.8	0.7	0.3	0.3	1.1	1.1
09/25/2025 10:00	4,539.6	694.4	5,234.0	105,000.0	549.6	0.7	0.3	0.3	1.1	1.1
09/25/2025 11:00	4,477.8	789.3	5,267.1	105,000.0	553.0	0.7	0.3	0.3	1.1	1.1
09/25/2025 12:00	4,401.2	892.8	5,294.0	105,000.0	555.9	0.7	0.3	0.3	1.1	1.1
09/25/2025 13:00	4,371.0	918.8	5,289.8	105,000.0	555.4	0.7	0.3	0.3	1.1	1.1
09/25/2025 14:00	4,342.5	955.8	5,298.3	105,000.0	556.3	0.7	0.3	0.3	1.1	1.1
09/25/2025 15:00	4,304.0	1,000.9	5,304.9	105,000.0	557.0	0.7	0.3	0.3	1.1	1.1
09/25/2025 16:00	4,271.3	1,158.8	5,430.1	105,000.0	570.2	0.7	0.3	0.3	1.1	1.1
09/25/2025 17:00	4,322.3	1,033.9	5,356.2	105,000.0	562.4	0.7	0.3	0.3	1.1	1.1
09/25/2025 18:00	4,525.1	721.2	5,246.3	105,000.0	550.9	0.7	0.3	0.3	1.1	1.1
09/25/2025 19:00	4,609.1	595.5	5,204.6	105,000.0	546.5	0.7	0.3	0.3	1.1	1.1
09/25/2025 20:00	4,656.5	522.1	5,178.6	105,000.0	543.8	0.7	0.3	0.3	1.1	1.1
09/25/2025 21:00	4,674.0	506.1	5,180.1	105,000.0	543.9	0.7	0.3	0.3	1.1	1.1
09/25/2025 22:00	4,703.3	456.6	5,159.9	105,000.0	541.8	0.7	0.3	0.3	1.1	1.1
09/25/2025 23:00	4,721.6	439.0	5,160.6	105,000.0	541.9	0.7	0.3	0.3	1.1	1.1
Average/Sum#:	4,557.7	674.7	5,232.4	105,000.0	549.4	0.7	0.3	0.3	1.1	1.1
Minimum:	4,271.3	439.0	5,159.9	105,000.0	541.8	0.7	0.3	0.3	1.1	1.1
Maximum:	4,721.6	1,158.8	5,430.1	105,000.0	570.2	0.7	0.3	0.3	1.1	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/26/2025 00:00	4,733.9	428.3	5,162.2	105,000.0	542.0	0.7	0.3	1.1			
09/26/2025 01:00	4,751.2	405.1	5,156.3	105,000.0	541.4	0.7	0.3	1.1			
09/26/2025 02:00	4,767.5	379.8	5,147.3	105,000.0	540.5	0.7	0.3	1.1			
09/26/2025 03:00	4,767.6	366.4	5,134.0	105,000.0	539.1	0.6	0.3	1.1			
09/26/2025 04:00	4,764.9	360.9	5,125.8	105,000.0	538.2	0.6	0.3	1.1			
09/26/2025 05:00	4,777.5	343.2	5,120.7	105,000.0	537.7	0.6	0.3	1.1			
09/26/2025 06:00	4,795.2	320.8	5,116.0	105,000.0	537.2	0.6	0.3	1.1			
09/26/2025 07:00	4,413.7	163.2	4,498.6	105,000.0	472.4	0.6	0.3	1.0			
09/26/2025 08:00	3,654.4	0.0	3,654.4	105,000.0	383.7	0.5	0.2	0.8			
09/26/2025 09:00	3,656.7	0.0	3,656.7	105,000.0	384.0	0.5	0.2	0.8			
09/26/2025 10:00	3,648.9	0.0	3,648.9	105,000.0	383.1	0.5	0.2	0.8			
09/26/2025 11:00	3,645.1	0.0	3,645.1	105,000.0	382.7	0.5	0.2	0.8			
09/26/2025 12:00	3,646.4	0.0	3,646.4	105,000.0	382.9	0.5	0.2	0.8			
09/26/2025 13:00	4,048.3	335.5	4,189.2	105,000.0	439.9	0.6	0.3	0.9			
09/26/2025 14:00	4,282.7	1,043.1	5,325.8	105,000.0	559.2	0.7	0.3	1.1			
09/26/2025 15:00	4,221.3	1,124.7	5,346.0	105,000.0	561.3	0.7	0.3	1.1			
09/26/2025 16:00	4,193.5	1,165.8	5,359.3	105,000.0	562.7	0.7	0.3	1.1			
09/26/2025 17:00	4,226.1	1,132.5	5,358.6	105,000.0	562.7	0.7	0.3	1.1			
09/26/2025 18:00	4,311.9	1,046.0	5,357.9	105,000.0	562.6	0.7	0.3	1.1			
09/26/2025 19:00	4,441.9	827.0	5,268.9	105,000.0	553.2	0.7	0.3	1.1			
09/26/2025 20:00	4,503.7	745.4	5,249.1	105,000.0	551.2	0.7	0.3	1.1			
09/26/2025 21:00	4,533.2	697.0	5,230.2	105,000.0	549.2	0.7	0.3	1.1			
09/26/2025 22:00	4,572.8	659.3	5,232.1	105,000.0	549.4	0.7	0.3	1.1			
09/26/2025 23:00	4,592.5	635.4	5,227.9	105,000.0	548.9	0.7	0.3	1.1			
Average/Sum#:	4,331.3	507.5	4,827.4	105,000.0	506.9	0.6	0.3	1.0			
Minimum:	3,645.1	0.0	3,645.1	105,000.0	382.7	0.5	0.2	0.8			
Maximum:	4,795.2	1,165.8	5,359.3	105,000.0	562.7	0.7	0.3	1.1			
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73		> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/27/2025 00:00	4,604.4	617.0	5,221.4	105,000.0	548.2	0.7	0.3	0.3	1.1	1.1
09/27/2025 01:00	4,614.3	602.5	5,216.8	105,000.0	547.8	0.7	0.3	0.3	1.1	1.1
09/27/2025 02:00	4,620.8	595.6	5,216.4	105,000.0	547.7	0.7	0.3	0.3	1.1	1.1
09/27/2025 03:00	4,636.6	557.1	5,193.7	105,000.0	545.3	0.7	0.3	0.3	1.1	1.1
09/27/2025 04:00	4,663.4	523.3	5,186.7	105,000.0	544.6	0.7	0.3	0.3	1.1	1.1
09/27/2025 05:00	4,669.6	518.5	5,188.1	105,000.0	544.8	0.7	0.3	0.3	1.1	1.1
09/27/2025 06:00	4,686.2	507.2	5,193.4	105,000.0	545.3	0.7	0.3	0.3	1.1	1.1
09/27/2025 07:00	4,107.9	121.2	4,141.8	105,000.0	434.9	0.5	0.3	0.3	0.9	0.9
09/27/2025 08:00	3,672.7	0.0	3,672.7	105,000.0	385.6	0.5	0.2	0.2	0.8	0.8
09/27/2025 09:00	3,669.0	0.0	3,669.0	105,000.0	385.2	0.5	0.2	0.2	0.8	0.8
09/27/2025 10:00	3,667.3	0.0	3,667.3	105,000.0	385.1	0.5	0.2	0.2	0.8	0.8
09/27/2025 11:00	3,665.7	0.0	3,665.7	105,000.0	384.9	0.5	0.2	0.2	0.8	0.8
09/27/2025 12:00	3,667.2	0.0	3,667.2	105,000.0	385.1	0.5	0.2	0.2	0.8	0.8
09/27/2025 13:00	3,661.6	0.0	3,661.6	105,000.0	384.5	0.5	0.2	0.2	0.8	0.8
09/27/2025 14:00	3,663.3	0.0	3,663.3	105,000.0	384.6	0.5	0.2	0.2	0.8	0.8
09/27/2025 15:00	4,166.1	166.4	4,211.0	105,000.0	442.2	0.5	0.3	0.3	0.9	0.9
09/27/2025 16:00	4,468.6	824.1	5,292.7	105,000.0	555.7	0.7	0.3	0.3	1.1	1.1
09/27/2025 17:00	4,540.6	709.3	5,249.9	105,000.0	551.2	0.7	0.3	0.3	1.1	1.1
09/27/2025 18:00	4,625.6	580.5	5,206.1	105,000.0	546.6	0.7	0.3	0.3	1.1	1.1
09/27/2025 19:00	4,665.9	510.7	5,176.6	105,000.0	543.5	0.7	0.3	0.3	1.1	1.1
09/27/2025 20:00	4,700.3	474.2	5,174.5	105,000.0	543.3	0.7	0.3	0.3	1.1	1.1
09/27/2025 21:00	4,731.8	422.7	5,154.5	105,000.0	541.2	0.6	0.3	0.3	1.1	1.1
09/27/2025 22:00	4,742.0	413.6	5,155.6	105,000.0	541.3	0.7	0.3	0.3	1.1	1.1
09/27/2025 23:00	4,751.2	426.5	5,177.7	105,000.0	543.7	0.7	0.3	0.3	1.1	1.1
Average/Sum#:	4,319.3	357.1	4,667.7	105,000.0	490.1	0.6	0.3	0.3	1.0	1.0
Minimum:	3,661.6	0.0	3,661.6	105,000.0	384.5	0.5	0.2	0.2	0.8	0.8
Maximum:	4,751.2	824.1	5,292.7	105,000.0	555.7	0.7	0.3	0.3	1.1	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/28/2025 00:00	4,750.8	431.7	5,182.5	105,000.0	544.2	0.7	0.3	1.1
09/28/2025 01:00	4,756.3	422.4	5,178.7	105,000.0	543.8	0.7	0.3	1.1
09/28/2025 02:00	4,765.5	398.7	5,164.2	105,000.0	542.2	0.7	0.3	1.1
09/28/2025 03:00	4,773.1	390.4	5,163.5	105,000.0	542.2	0.7	0.3	1.1
09/28/2025 04:00	4,777.1	384.9	5,162.0	105,000.0	542.0	0.7	0.3	1.1
09/28/2025 05:00	4,781.0	378.5	5,159.5	105,000.0	541.7	0.7	0.3	1.1
09/28/2025 06:00	4,779.8	364.2	5,144.0	105,000.0	540.1	0.6	0.3	1.1
09/28/2025 07:00	4,691.0	290.8	4,914.9	105,000.0	516.1	0.6	0.3	1.0
09/28/2025 08:00	3,701.3	0.0	3,701.3	105,000.0	388.6	0.5	0.2	0.8
09/28/2025 09:00	3,675.8	0.0	3,675.8	105,000.0	386.0	0.5	0.2	0.8
09/28/2025 10:00	3,673.8	0.0	3,673.8	105,000.0	385.7	0.5	0.2	0.8
09/28/2025 11:00	3,673.7	0.0	3,673.7	105,000.0	385.7	0.5	0.2	0.8
09/28/2025 12:00	4,197.0	136.9	4,235.3	105,000.0	444.7	0.5	0.3	0.9
09/28/2025 13:00	4,686.0	531.8	5,217.8	105,000.0	547.9	0.7	0.3	1.1
09/28/2025 14:00	4,550.8	140.5	4,595.8	105,000.0	482.6	0.6	0.3	1.0
09/28/2025 15:00	4,663.6	522.1	5,185.7	105,000.0	544.5	0.7	0.3	1.1
09/28/2025 16:00	4,663.6	519.1	5,182.7	105,000.0	544.2	0.7	0.3	1.1
09/28/2025 17:00	4,684.3	494.0	5,178.3	105,000.0	543.7	0.7	0.3	1.1
09/28/2025 18:00	4,698.8	464.5	5,163.3	105,000.0	542.1	0.7	0.3	1.1
09/28/2025 19:00	4,701.2	465.0	5,166.2	105,000.0	542.5	0.7	0.3	1.1
09/28/2025 20:00	4,718.0	436.2	5,154.2	105,000.0	541.2	0.7	0.3	1.1
09/28/2025 21:00	4,709.4	445.4	5,154.8	105,000.0	541.3	0.7	0.3	1.1
09/28/2025 22:00	4,720.0	425.7	5,145.7	105,000.0	540.3	0.6	0.3	1.1
09/28/2025 23:00	4,735.4	404.3	5,139.7	105,000.0	539.7	0.6	0.3	1.1
Average/Sum#:	4,522.0	335.3	4,846.4	105,000.0	508.9	0.6	0.3	1.0
Minimum:	3,673.7	0.0	3,673.7	105,000.0	385.7	0.5	0.2	0.8
Maximum:	4,781.0	531.8	5,217.8	105,000.0	547.9	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

					> 4.73			> 1		> 1.8	
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr			
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/29/2025 00:00	4,740.6	409.5	5,150.1	105,000.0	540.8	0.7	0.3	1.1			
09/29/2025 01:00	4,737.0	409.7	5,146.7	105,000.0	540.4	0.6	0.3	1.1			
09/29/2025 02:00	4,731.9	419.4	5,151.3	105,000.0	540.9	0.7	0.3	1.1			
09/29/2025 03:00	4,724.8	428.5	5,153.3	105,000.0	541.1	0.6	0.3	1.1			
09/29/2025 04:00	4,722.7	445.8	5,168.5	105,000.0	542.7	0.7	0.3	1.1			
09/29/2025 05:00	4,723.9	453.4	5,177.3	105,000.0	543.6	0.7	0.3	1.1			
09/29/2025 06:00	4,725.0	452.0	5,177.0	105,000.0	543.6	0.7	0.3	1.1			
09/29/2025 07:00	4,726.0	432.5	5,158.5	105,000.0	541.6	0.6	0.3	1.1			
09/29/2025 08:00	4,222.1	5.9	4,222.4	105,000.0	443.4	0.5	0.3	0.9			
09/29/2025 09:00	4,688.0	527.7	5,215.7	105,000.0	547.6	0.7	0.3	1.1			
09/29/2025 10:00	4,684.5	525.3	5,209.8	105,000.0	547.0	0.7	0.3	1.1			
09/29/2025 11:00	4,692.2	518.7	5,210.9	105,000.0	547.1	0.7	0.3	1.1			
09/29/2025 12:00	4,698.4	508.5	5,206.9	105,000.0	546.7	0.7	0.3	1.1			
09/29/2025 13:00	4,709.4	499.3	5,208.7	105,000.0	546.9	0.7	0.3	1.1			
09/29/2025 14:00	4,675.2	550.7	5,225.9	105,000.0	548.7	0.7	0.3	1.1			
09/29/2025 15:00	4,643.1	560.2	5,203.3	105,000.0	546.3	0.7	0.3	1.1			
09/29/2025 16:00	4,610.2	592.7	5,202.9	105,000.0	546.3	0.7	0.3	1.1			
09/29/2025 17:00	4,600.3	515.5	5,115.8	105,000.0	537.2	0.6	0.3	1.1			
09/29/2025 18:00	4,592.2	512.3	5,104.5	105,000.0	536.0	0.6	0.3	1.1			
09/29/2025 19:00	4,594.2	499.6	5,093.8	105,000.0	534.8	0.6	0.3	1.1			
09/29/2025 20:00	4,599.6	488.8	5,088.4	105,000.0	534.3	0.6	0.3	1.1			
09/29/2025 21:00	4,608.0	475.1	5,083.1	105,000.0	533.7	0.6	0.3	1.1			
09/29/2025 22:00	4,614.3	475.9	5,090.2	105,000.0	534.5	0.6	0.3	1.1			
09/29/2025 23:00	4,634.3	452.3	5,086.6	105,000.0	534.1	0.6	0.3	1.1			
Average/Sum#:	4,654.1	465.0	5,118.8	105,000.0	537.5	0.7	0.3	1.1			
Minimum:	4,222.1	5.9	4,222.4	105,000.0	443.4	0.5	0.3	0.9			
Maximum:	4,740.6	592.7	5,225.9	105,000.0	548.7	0.7	0.3	1.1			
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			

Fuel Gas and Emissions Daily Summary

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:10 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:

	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	> 4.73	> 1	> 1.8
	GasFlow, _CT, 100scfh	GasFlow, _DB, 100scfh	GasFlowTotal, 100scfh	GCVGas, BtuPer100scf	HI, MBtuPerHr	PM10_Norm, LbPerHr	SO2_Norm, LbPerHr	VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/30/2025 00:00	4,641.8	437.8	5,079.6	105,000.0	533.4	0.6	0.3	1.1
09/30/2025 01:00	4,646.0	437.1	5,083.1	105,000.0	533.7	0.6	0.3	1.1
09/30/2025 02:00	4,653.6	428.5	5,082.1	105,000.0	533.6	0.6	0.3	1.1
09/30/2025 03:00	4,654.6	423.2	5,077.8	105,000.0	533.2	0.6	0.3	1.1
09/30/2025 04:00	4,652.9	428.6	5,081.5	105,000.0	533.6	0.6	0.3	1.1
09/30/2025 05:00	4,648.1	603.5	5,251.6	105,000.0	551.4	0.7	0.3	1.1
09/30/2025 06:00	4,647.3	706.4	5,353.7	105,000.0	562.1	0.7	0.3	1.1
09/30/2025 07:00	4,639.1	447.9	5,087.0	105,000.0	534.1	0.6	0.3	1.1
09/30/2025 08:00	4,467.9	102.5	4,493.5	105,000.0	471.8	0.6	0.3	1.0
09/30/2025 09:00	4,604.2	495.9	5,100.1	105,000.0	535.5	0.6	0.3	1.1
09/30/2025 10:00	4,565.1	560.2	5,125.3	105,000.0	538.2	0.6	0.3	1.1
09/30/2025 11:00	4,544.7	590.2	5,134.9	105,000.0	539.2	0.6	0.3	1.1
09/30/2025 12:00	4,522.4	617.0	5,139.4	105,000.0	539.6	0.6	0.3	1.1
09/30/2025 13:00	4,517.5	610.2	5,127.7	105,000.0	538.4	0.6	0.3	1.1
09/30/2025 14:00	4,437.9	124.4	4,471.5	105,000.0	469.5	0.6	0.3	1.0
09/30/2025 15:00	4,530.9	573.2	5,104.1	105,000.0	535.9	0.6	0.3	1.1
09/30/2025 16:00	4,551.9	696.0	5,247.9	105,000.0	551.0	0.7	0.3	1.1
09/30/2025 17:00	4,574.8	515.6	5,090.4	105,000.0	534.5	0.6	0.3	1.1
09/30/2025 18:00	4,595.9	478.4	5,074.3	105,000.0	532.8	0.6	0.3	1.1
09/30/2025 19:00	4,606.6	473.2	5,079.8	105,000.0	533.4	0.6	0.3	1.1
09/30/2025 20:00	4,604.7	478.5	5,083.2	105,000.0	533.7	0.6	0.3	1.1
09/30/2025 21:00	4,622.4	461.1	5,083.5	105,000.0	533.8	0.6	0.3	1.1
09/30/2025 22:00	3,785.8	108.9	3,815.2	105,000.0	400.6	0.5	0.3	0.9
09/30/2025 23:00	0.0	0.0	0.0	105,000.0	0.0	0.0	0.0	0.0
Average/Sum#:	4,552.9	469.5	5,011.6	105,000.0	526.2	0.6	0.3	1.1
Minimum:	3,785.8	102.5	3,815.2	105,000.0	400.6	0.5	0.3	0.9
Maximum:	4,654.6	706.4	5,353.7	105,000.0	562.1	0.7	0.3	1.1
%SI	4.17	4.17	4.17	0.00	4.17	4.17	4.17	4.17

AQ-36 thru AQ-38, AQ-41, & AQ-117

AQ-36 thru AQ-38, AQ-41, & AQ-117: PCAPCD notifications/
corrective action: breakdowns, excess emissions, CEMS inoperable, or a
negative declaration when no excess emissions occurred.

Verification: The Project owner shall include the identification of all
breakdowns, PCAPCD notification, resulting excess emission (if any) and
corrective actions taken (if any) as part of the Quarterly Air Quality
Report required in Condition of Certification AQ-SC6

CO LbPerHr 3-Hour Rolling Excess Emissions

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:17 Location: Roseville, CA

Tag Name: CT1_CO_3Hr_LbPerHr_1H
Total Operating Time: 2,195.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 13.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,195.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO Ppmvdc 3-Hour Block Excess Emissions



CT1

From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:17 Location: Roseville, CA

Tag Name: CT1_CO_Ppmvdc_3H
Total Operating Time: 2,195.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 13.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,195.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO LbPerHr SUSd 1-Hour Block Excess Emissions



CT1

From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:17 Location: Roseville, CA

Tag Name: CT1_CO_SUSd_LbPerHr_1H
Total Operating Time: 2,195.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 13.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,195.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NH3 Slip Ppmvdc 1-Hour Block Excess Emissions



CT1

From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:17 Location: Roseville, CA

Tag Name: CT1_NH3Slip_Ppmvdc_1H
Total Operating Time: 2,195.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 13.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,195.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx LbPerHr 1-Hour Block Excess Emissions



CT1

From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:17 Location: Roseville, CA

Tag Name: CT1_NOx_Norm_LbPerHr_1H
Total Operating Time: 2,195.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 13.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,195.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx Ppmvdc 1-Hour Block Excess Emissions



CT1

From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:17 Location: Roseville, CA

Tag Name: CT1_NOx_Ppmvdc_1H
Total Operating Time: 2,195.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 13.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,195.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx LbPerHr SUSd 1-Hour Block Excess Emissions



CT1

From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:17 Location: Roseville, CA

Tag Name: CT1_NOx_SUSd_LbPerHr_1H
Total Operating Time: 2,195.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 13.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,195.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

PM10 LbPerHr 1-Hour Block Excess Emissions

CT1



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:17 Location: Roseville, CA

Tag Name: CT1_PM10_Norm_LbPerHr_1H
Total Operating Time: 2,195.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 13.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,195.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

S02 LbPerHr 1-Hour Block Excess Emissions



CT1

From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:17 Location: Roseville, CA

Tag Name: CT1_S02_Norm_LbPerHr_1H
Total Operating Time: 2,195.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 13.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,195.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

VOC LbPerHr 1-Hour Block Excess Emissions



CT1

From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:17 Location: Roseville, CA

Tag Name: CT1_VOC_Norm_LbPerHr_1H
Total Operating Time: 2,195.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 13.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,195.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO LbPerHr 3-Hour Rolling Excess Emissions

CT2

From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:19 Location: Roseville, CA



Tag Name: CT2_CO_3Hr_LbPerHr_1H
Total Operating Time: 2,201.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 7.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,201.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO Ppmvdc 3-Hour Block Excess Emissions

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:19 Location: Roseville, CA

Tag Name: CT2_CO_Ppmvdc_3H
Total Operating Time: 2,201.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 7.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,201.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO LbPerHr SUSd 1-Hour Block Excess Emissions



CT2

From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:19 Location: Roseville, CA

Tag Name: CT2_CO_SUSd_LbPerHr_1H
Total Operating Time: 2,201.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 7.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,201.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NH3 Slip Ppmvdc 1-Hour Block Excess Emissions



CT2

From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:19 Location: Roseville, CA

Tag Name: CT2_NH3Slip_Ppmvdc_1H
Total Operating Time: 2,201.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 7.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,201.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx LbPerHr 1-Hour Block Excess Emissions



CT2

From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:19 Location: Roseville, CA

Tag Name: CT2_NOx_Norm_LbPerHr_1H
Total Operating Time: 2,201.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 7.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,201.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx Ppmvdc 1-Hour Block Excess Emissions

CT2

From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:19 Location: Roseville, CA



Tag Name: CT2_NOx_Ppmvdc_1H
Total Operating Time: 2,201.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 7.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,201.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx LbPerHr SUSd 1-Hour Block Excess Emissions



CT2

From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:19 Location: Roseville, CA

Tag Name: CT2_NOx_SUSd_LbPerHr_1H
Total Operating Time: 2,201.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 7.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,201.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

PM10 LbPerHr 1-Hour Block Excess Emissions

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:19 Location: Roseville, CA

Tag Name: CT2_PM10_Norm_LbPerHr_1H
Total Operating Time: 2,201.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 7.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,201.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

S02 LbPerHr 1-Hour Block Excess Emissions

CT2



From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:19 Location: Roseville, CA

Tag Name: CT2_S02_Norm_LbPerHr_1H
Total Operating Time: 2,201.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 7.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,201.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

VOC LbPerHr 1-Hour Block Excess Emissions

CT2

From: 07/01/2025 00:00 To: 09/30/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 10/01/2025 08:19 Location: Roseville, CA



Tag Name: CT2_VOC_Norm_LbPerHr_1H
Total Operating Time: 2,201.00 Hour(s) No Exclusions Allowed
Non-Operating Time: 7.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	2,201.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 07/01/2025 00:00 **To:** 09/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2025 08:15 **Location:** Roseville, CA

Tag Name: ALL_CO_Lb_1D
Total Operating Time: 92.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 0.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	92.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 07/01/2025 00:00 **To:** 09/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2025 08:15 **Location:** Roseville, CA

Tag Name: ALL_NOX_Lb_1D
Total Operating Time: 92.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 0.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	92.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 07/01/2025 00:00 **To:** 09/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2025 08:15 **Location:** Roseville, CA

Tag Name: ALL_PM10_Lb_1D
Total Operating Time: 92.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 0.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	92.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 07/01/2025 00:00 **To:** 09/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2025 08:15 **Location:** Roseville, CA

Tag Name: ALL_SO2_Lb_1D
Total Operating Time: 92.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 0.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	92.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



From: 07/01/2025 00:00 **To:** 09/30/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2025 08:15 **Location:** Roseville, CA

Tag Name: ALL_VOC_Lb_1D
Total Operating Time: 92.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 0.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	92.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

AQ-40

AQ-40 The Project owner shall comply with the applicable requirements for quality assurance testing and maintenance of the continuous emission monitor equipment in accordance with the procedures and guidance specified in 40 CFR Part 60, Appendix F.

Verification: The Project owner shall include all CEMS quality assurance test failures that required corrective action as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

Cylinder Gas Audit

10/08/2025

Page 1

Facility: ROSEVILLE ENERGY

Unit/Stack: CT1

Parameter/Scale: CO / High

Test Date: 07/09/2025

Test Result: **Pass**

Instrument Name: CT1_CODualRg_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
07/09/2025	07:34	L	200	50.200	49.000	25.1 %
07/09/2025	07:39	M	200	109.000	111.100	54.5 %
07/09/2025	07:51	L	200	50.200	49.000	25.1 %
07/09/2025	07:56	M	200	109.000	111.000	54.5 %
07/09/2025	08:08	L	200	50.200	49.100	25.1 %
07/09/2025	08:13	M	200	109.000	110.600	54.5 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	50.200	49.033	Std	2.3
M	109.000	110.900	Std	1.7

Cylinder Gas Audit

10/08/2025

Page 2

Facility: ROSEVILLE ENERGY

Unit/Stack: CT2

Parameter/Scale: CO / High

Test Date: 07/09/2025

Test Result: **Pass**

Instrument Name: CT2_CODualRg_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
07/09/2025	08:38	L	200	49.900	51.700	25.0 %
07/09/2025	08:43	M	200	109.100	113.500	54.6 %
07/09/2025	08:55	L	200	49.900	50.900	25.0 %
07/09/2025	09:00	M	200	109.100	113.500	54.6 %
07/09/2025	09:12	L	200	49.900	52.100	25.0 %
07/09/2025	09:17	M	200	109.100	114.700	54.6 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	49.900	51.567	Std	3.3
M	109.100	113.900	Std	4.4

Cylinder Gas Audit

10/08/2025

Page 3

Facility: ROSEVILLE ENERGY

Unit/Stack: CT1

Parameter/Scale: CO / Low

Test Date: 07/09/2025

Test Result: **Pass**

Instrument Name: CT1_CODualRg_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
07/09/2025	11:49	L	10	2.600	2.300	26.0 %
07/09/2025	11:54	M	10	5.700	5.700	57.0 %
07/09/2025	12:01	L	10	2.600	2.300	26.0 %
07/09/2025	12:06	M	10	5.700	5.700	57.0 %
07/09/2025	12:13	L	10	2.600	2.300	26.0 %
07/09/2025	12:18	M	10	5.700	5.700	57.0 %

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Specification Used	Results
L	2.600		2.300	Std	11.5
M	5.700		5.700	Std	0.0

Cylinder Gas Audit

10/08/2025

Page 4

Facility: ROSEVILLE ENERGY

Unit/Stack: CT2

Parameter/Scale: CO / Low

Test Date: 07/09/2025

Test Result: **Pass**

Instrument Name: CT2_CODualRg_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
07/09/2025	12:41	L	10	2.600	2.400	26.0 %
07/09/2025	12:46	M	10	5.700	5.700	57.0 %
07/09/2025	12:53	L	10	2.600	2.300	26.0 %
07/09/2025	12:58	M	10	5.700	5.500	57.0 %
07/09/2025	13:05	L	10	2.600	2.400	26.0 %
07/09/2025	13:10	M	10	5.700	5.600	57.0 %

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Specification Used	Results
L	2.600		2.367	Std	9.0
M	5.700		5.600	Std	1.8

Linearity Report

10/08/2025

Page 1

ORIS Code: 56298 Facility Name: ROSEVILLE ENERGY
EDR Site ID: CT001 Component ID: A15 ReasonForTest: QA
Component Type: NOXA Grace Period: 0
Instrument Name: CT1_NOXDualRg_P_Instrum Test End Date/Time: 07/09/2025 Scale: High
Performance Spec: 5 % Test No.: 140 Highest Error: 0.9
Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
07/09/2025	0734	L	200.0	51.7	51.2		25.9 %
07/09/2025	0739	M	200.0	111.5	112.0		55.8 %
07/09/2025	0744	H	200.0	180.6	181.2		90.3 %
07/09/2025	0751	L	200.0	51.7	51.2		25.9 %
07/09/2025	0756	M	200.0	111.5	111.9		55.8 %
07/09/2025	0801	H	200.0	180.6	181.0		90.3 %
07/09/2025	0808	L	200.0	51.7	51.3		25.9 %
07/09/2025	0813	M	200.0	111.5	111.9		55.8 %
07/09/2025	0818	H	200.0	180.6	180.8		90.3 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	51.700	51.233	No	0.9
M	111.500	111.933	No	0.4
H	180.600	181.000	No	0.2

Linearity Report

10/08/2025

Page 2

ORIS Code: 56298 Facility Name: ROSEVILLE ENERGY
EDR Site ID: CT002 Component ID: A21 ReasonForTest: QA
Component Type: NOXA Grace Period: 0
Instrument Name: CT2_NOXDualRg_P_Instrum Test End Date/Time: 07/09/2025 Scale: High
Performance Spec: 5 % Test No.: 141 Highest Error: 0.7
Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
07/09/2025	0838	L	200.0	51.1	51.0		25.6 %
07/09/2025	0843	M	200.0	111.3	112.0		55.7 %
07/09/2025	0848	H	200.0	181.2	181.6		90.6 %
07/09/2025	0855	L	200.0	51.1	50.2		25.6 %
07/09/2025	0900	M	200.0	111.3	111.4		55.7 %
07/09/2025	0905	H	200.0	181.2	181.2		90.6 %
07/09/2025	0912	L	200.0	51.1	51.0		25.6 %
07/09/2025	0917	M	200.0	111.3	111.1		55.7 %
07/09/2025	0922	H	200.0	181.2	181.1		90.6 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	51.100	50.733	No	0.7
M	111.300	111.500	No	0.2
H	181.200	181.300	No	0.1

Linearity Report

10/08/2025

Page 3

ORIS Code: 56298 Facility Name: ROSEVILLE ENERGY
EDR Site ID: CT002 Component ID: A22 ReasonForTest: QA
Component Type: O2D Grace Period: 0
Instrument Name: CT2_O2D_P_Instrument Test End Date/Time: 07/09/2025 Scale: High
Performance Spec: 5 % Test No.: 142 Highest Error: 0.0
Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
07/09/2025	1036	L	21.0	5.0	5.0		23.8 %
07/09/2025	1041	M	21.0	11.0	11.0		52.4 %
07/09/2025	1046	H	21.0	18.0	18.0		85.7 %
07/09/2025	1053	L	21.0	5.0	5.0		23.8 %
07/09/2025	1058	M	21.0	11.0	11.0		52.4 %
07/09/2025	1103	H	21.0	18.0	18.0		85.7 %
07/09/2025	1110	L	21.0	5.0	5.0		23.8 %
07/09/2025	1115	M	21.0	11.0	11.0		52.4 %
07/09/2025	1120	H	21.0	18.0	18.0		85.7 %

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Alt Perf Spec	Results
L	5.000		5.000	No	0.0
M	11.000		11.000	No	0.0
H	18.000		18.000	No	0.0

Linearity Report

10/08/2025

Page 4

ORIS Code: 56298 Facility Name: ROSEVILLE ENERGY
EDR Site ID: CT001 Component ID: A16 ReasonForTest: QA
Component Type: O2D Grace Period: 0
Instrument Name: CT1_O2D_P_Instrument Test End Date/Time: 07/09/2025 Scale: High
Performance Spec: 5 % Test No.: 141 Highest Error: 4.0
Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
07/09/2025	0937	L	18.0	5.0	4.8		27.8 %
07/09/2025	0942	M	18.0	11.0	10.9		61.1 %
07/09/2025	0947	H	18.0	18.0	18.0		100.0 %
07/09/2025	0954	L	18.0	5.0	4.8		27.8 %
07/09/2025	0959	M	18.0	11.0	10.9		61.1 %
07/09/2025	1004	H	18.0	18.0	18.0		100.0 %
07/09/2025	1011	L	18.0	5.0	4.8		27.8 %
07/09/2025	1016	M	18.0	11.0	10.9		61.1 %
07/09/2025	1021	H	18.0	18.0	18.0		100.0 %

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Alt Perf Spec	Results
L	5.000		4.800	No	4.0
M	11.000		10.900	No	0.9
H	18.000		18.000	No	0.0