

DOCKETED

Docket Number:	79-AFC-04C
Project Title:	Compliance - Application for Certification of DWR Bottlerock Geothermal Project
TN #:	266860
Document Title:	BRP_CEC Response DR 3 (Dimensions for Equipment) Oct 24 2025
Description:	BRP_CEC Response DR 3 (Dimensions for Equipment) Oct 24 2025
Filer:	John C Casteel
Organization:	Mayacma Geothermal LLC
Submitter Role:	Applicant
Submission Date:	10/27/2025 12:58:56 PM
Docketed Date:	10/27/2025



Bottle Rock Power, LLC
c/o AltaRock Energy, Inc.
P.O. Box 31025
Seattle, WA 98103-8099
Phone: (206) 729-2400

October 22, 2025

Anwar Ali, PhD
Senior Environmental Planner
Compliance Project Manager
Compliance, Monitoring and Enforcement Unit
California Energy Commission

RE: Response to Data Requests Set No. 32 – Bottle Rock Geothermal Power Plant (79-AFC-04C)

Anwar,

On behalf of Bottle Rock Power, LLC and Open Mountain Energy, please find below responses to Data Request Set. No. 3 (Equipment Dimensions) Bottle Rock Geothermal Power Plant (79-AFC-04C). These responses provide clarification and additional details as requested in Data Request Set No. 3. Please let us know if you wish to discuss these responses.

1. New steam vent stack is a vertical vessel with a diameter of 10 feet and approximate height of 26ft,
2. The associated vent stack H₂S abatement skid, and caustic tank is 18 feet x 10 feet, and up to approximately 10ft in height.
3. The adjacent air compressor package for the new facility (air operated valve controls) (including compressor, refrigerated dryer, and air receiver inside of a simple shed /shelter) is 24 feet x 14 feet, and up to ~13ft in height.

Please let us know if you have any further questions.

Regards,

A handwritten signature in black ink, appearing to read "John Demeter".

John Demeter
Interim CEO

Cc: