

DOCKETED	
Docket Number:	01-AFC-06C
Project Title:	Magnolia Power Project-Compliance
TN #:	266886
Document Title:	Errata for the Magnolia Power Project (01-AFC-06C) Staff Assessment for Efficiency Upgrades
Description:	Errata for the Magnolia Power Project (01-AFC-06C) Staff Assessment for Efficiency Upgrades
Filer:	Ashley Gutierrez
Organization:	California Energy Commission
Submitter Role:	Commission Staff
Submission Date:	10/28/2025 5:05:26 PM
Docketed Date:	10/29/2025

ATTACHMENT A - ERRATA SHEET #1

On October 24, 2025, Southern California Public Power Authority and the City of Burbank provided minor editorial comments ([TN 266839](#)) regarding the Magnolia Power Project (01-AFC-06C) CEC Staff Analysis for the Petition to Amend the Final Commission Decision to Install Efficiency Upgrades, docketed on October 2, 2025.

The changes set forth below to the Staff Assessment (TN 266274) are necessary to correct typographical errors or for clarity. Deleted text is shown in ~~strikethrough~~ and new text is shown as **bold underline**.

Page 1 and Page 6 is revised as follows:

1. On December ~~2331~~, 2024, the Southern California Public Power Authority (SCPPA) filed a Post-Certification Petition for Changes in Project Design, Operation or Performance and Amendments to the Commission Decision (~~TN 060806~~) ([TN 260806](#)) with the California Energy Commission (CEC) for the Magnolia Power Project (MPP), pursuant to California Code of Regulations, title 20, section 1769.

Page 10 Subsection Air Quality, Paragraph 1 is revised as follows:

2. See footnote 2 above **on page 2 of the PDF** for a more detailed explanation of why the MW increase analyzed for a worst-case air quality impacts analysis at 22 degrees Fahrenheit is different from the MW increase at 77 degrees Fahrenheit or higher.

Page 11, Subsection Efficiency, the heading of the subsection is revised as follows:

3. The heading of the subsection has been updated to reflect the correct spelling "Effici**ency**".

Page 19, Subsection CEC Staff Recommendations and Conclusions, fourth paragraph, first sentence is revised as follows:

4. Staff has recommended new and modified COCs for consistency with the new draft Authority **Permit** to Construct permit ([TN 266758](#)) issued by South Coast Air Quality Management District on ~~July 22~~ **October 16**, 2025, which reflects the same proposed changes to the MPP.

Page 28, Subsection Operation, first paragraph, first sentence is revised as follows:

5. After completion of the recommissioning period, the gas turbine maximum hourly fuel firing rate will increase from ~~1,783~~ **1,787** MMBtu/hr to 2,103 MMBtu/hr (HHV) and the annual operating hours of the gas turbine will increase from 8,322 hours per year (hrs/yr) to 8,508 hrs/yr in COC AQ-2b.

The City of Burbank Water and Power suggests that throughout the Staff Analysis, staff should consider referring to the SCAQMD MPP permit to operate as the "*SCAQMD Facility Permit to Operate*".

6. The suggested edit was not accepted by staff because the CEC staff's description, "SCAQMD MPP Permit" is facility specific and denotes the Magnolia Power Project.