

DOCKETED	
Docket Number:	01-AFC-25C
Project Title:	Malburg Generating Station-Compliance
TN #:	268351
Document Title:	Malburg Generating Station Quarterly Compliance Report Q4 2025
Description:	N/A
Filer:	Elyse Engel
Organization:	Jacobs Engineering Group Inc.
Submitter Role:	Applicant
Submission Date:	1/29/2026 10:32:01 AM
Docketed Date:	1/29/2026



January 29, 2026

**NOTICE OF INTENT TO FILE
2025 Q4 Compliance Report for the
Malburg Generating Station (01-AFC-25C)**

Dear Dr. Ali:

Attached please find the Quarterly Compliance Report for the Malburg Generating Station (01-AFC-25C), covering the operational period of October 1, 2025, through December 31, 2025. This report addresses all quarterly requirements identified in the Final Commission Decision for the Malburg Generating Station (Transaction Number [TN] #28746), as most recently amended on June 20, 2019, by the Errata to Staff Analysis of Petition to Amend the Final Commission Decision (TN #228444).

If you have any questions or need more information, please contact Matt Richards, Utilities Operations Manager, at MRichards@cityofvernonca.gov or (323) 583-8811 x378.

Thank you,

Todd Dusenberry
General Manager of Vernon Public Utilities

Copies: Lisa Umeda
Matt Richards
Richard Corbi
Elyse Engel
Document Control

Enclosure: MGS 2025 Q4 Compliance Report




Malburg Generating Station Quarterly Compliance Report (Fourth Quarter 2025)

Submitted to
California Energy Commission

Submitted by
City of Vernon, Public Utilities Department

Document no: 250723113916_66a5cfb3

January 29, 2026



Contents

Acronyms and Abbreviations.....	ii
1. Introduction	1
1.1 Project Location and Description.....	1
1.2 Organization of the Quarterly Compliance Report	1
2. Required Quarterly Compliance Report Documentation.....	1

Appendices

A	MGS Emission Calculations
B	Cooling Tower Blowdown Reports
C	Operation Logs
D	Diesel Fuel Oil Purchase Records
E	Excess Emission Reports
F	MGS RECLAIM Annual Emission Allocation Information

Tables

2-1	Required Quarterly Compliance Report Documentation	1
-----	--	---

Acronyms and Abbreviations

CEC	California Energy Commission
CEMS	continuous emissions monitoring system
CO	carbon monoxide
COCs	Conditions of Certification
CTGs	combustion turbine generators
DAHS	data acquisition and handling system
gr/scf	grain per standard cubic foot
HRSGs	heat recovery steam generators
lb/day	pounds per day
lb/hr	pounds per hour
MGS	Malburg Generating Station
NH ₃	ammonia
NO _x	nitrogen oxides
PM ₁₀	particulate matter with aerodynamic diameter less than or equal to 10 microns
PM _{2.5}	particulate matter with aerodynamic diameter less than or equal to 2.5 microns
ppm	parts per million
ppmv	parts per million by volume
ppmw	parts per million by weight
QCR	Quarterly Compliance Report
SO _x	sulfur oxides
STG	steam turbine generator
TDS	total dissolved solids
TN	Transaction Number
VOC	volatile organic compound

1. Introduction

This Quarterly Compliance Report (QCR) has been prepared to meet the California Energy Commission's (CEC) quarterly reporting requirements for the Malburg Generating Station (MGS). This QCR fulfills various Conditions of Certification (COCs) described in the CEC's Final Commission Decision for the MGS (Transaction Number [TN] #28746), as most recently amended on June 20, 2019, by the Errata to Staff Analysis of Petition to Amend the Final Commission Decision (TN #228444).

1.1 Project Location and Description

The MGS is located at 4963 S Soto Street in Vernon, California. The property is approximately 3.4 acres in size, located in an industrial land use area near the geographic center of metropolitan Los Angeles County. MGS consists of two Siemens SGT-800 frame type natural gas combustion turbine generators (CTGs), two associated natural gas combustion duct burners, two heat recovery steam generators (HRSGs), a steam turbine generator (STG), a cooling tower, a diesel-fired emergency firewater pump, and support equipment.

The commissioning of MGS was completed in October 2005 and the power plant began commercial operation on October 17, 2005.

1.2 Organization of the Quarterly Compliance Report

A summary of the compliance demonstration for each applicable COC is provided in Section 2 and includes references to Appendices and Tables as appropriate.

2. Required Quarterly Compliance Report Documentation

COC requirements associated with this QCR are summarized in the table below.

Table 2-1. Required Quarterly Compliance Report Documentation

Condition of Certification	Response
AQ-C6	The weekly total dissolved solids (TDS) results for the fourth quarter of 2025 are provided in Appendix A, Table 2; the weekly sample reports collected for the same period are provided in Appendix B.
AQ-C7	Daily particulate matter with aerodynamic diameter less than or equal to 10 microns (PM ₁₀) emissions from cooling tower operation during the fourth quarter of 2025 are provided in Appendix A, Tables 3 through 5. As shown, emissions were below the specified limit of 6.2 pounds per day (lb/day).
AQ-C8	Testing times for the diesel-fired emergency firewater pump during the fourth quarter of 2025 are provided in Appendix C, Table 2. MGS refrained from testing the diesel-fired emergency firewater pump in the same hour the CTGs were either started or shutdown.
AQ-C9	The CTG startup and shutdown details for the fourth quarter of 2025, including the duration and date of occurrence, are provided in Appendix C, Table 1.

Malburg Generating Station Quarterly Compliance Report (Fourth Quarter 2025)

Condition of Certification	Response
AQ-C11	All ammonia (NH ₃), nitrogen oxides (NO _x), sulfur oxides (SO _x), carbon monoxide (CO), PM ₁₀ , and volatile organic compound (VOC) emissions from MGS operation during the fourth quarter of 2025 are provided in Appendix A, Table 1B. Annual emissions of these same pollutants are provided in Appendix A, Table 1A.
AQ-2	Low sulfur diesel fuel was last purchased on March 18, 2025. The fuel purchase record is provided in Appendix D and demonstrates that the fuel does not contain sulfur compounds in excess of 15 parts per million by weight (ppmw).
AQ-3	See the response for COC AQ-2.
AQ-5	Monthly emissions of CO, PM ₁₀ , particulate matter with aerodynamic diameter less than or equal to 2.5 microns (PM _{2.5}), VOC, and SO _x from CTG and duct burner operation during the fourth quarter of 2025 are presented in Appendix A, Tables 7 through 9. Fuel usage for each turbine-duct burner pair is provided in Appendix A, Table 6. As shown, emissions were below the monthly limits specified in Condition A63.4 of the site's Title V Permit.
AQ-6	See the response for COC AQ-C9.
AQ-9	See the response for COC AQ-C11. Additionally, quarterly NO _x excess emission reports from the data acquisition and handling system (DAHS) are provided in Appendix E. As demonstrated in these reports, there were no incidents in which the maximum corrected NO _x emissions concentration for either CTG exceeded the emissions concentration limit of 2.0 parts per million by volume (ppmv). All continuous emissions monitoring system (CEMS) data for MGS' CTGs are stored electronically onsite.
AQ-10	See the response for COC AQ-C11. Additionally, quarterly CO excess emission reports from the DAHS are provided in Appendix E. As demonstrated in these reports, there were no incidents in which the maximum corrected CO emissions concentration for either CTG exceeded the emissions concentration limit of 2.0 ppmv. All CEMS data for MGS' CTGs are stored electronically onsite.
AQ-11	See the response for COC AQ-C11. Additionally, quarterly VOC excess emission reports from the DAHS are provided in Appendix E. As demonstrated in these reports, there were no incidents in which the maximum corrected VOC emissions concentration for either CTG exceeded the emissions concentration limit of 2.0 ppmv. All CEMS data for MGS' CTGs are stored electronically onsite.
AQ-12	See the response for COC AQ-C11. Additionally, compliance with the specified limit of 5 parts per million (ppm) is demonstrated through annual or quarterly source testing. The most recent NH ₃ compliance source testing for CTG 1 and CTG 2 was performed on February 11 and 12, 2025. The test reports with results were submitted to the CEC on March 26, 2025, and indicated compliance with the emission limit (0.8 ppm for CTG 1 and 0.4 ppm for CTG 2). NH ₃ emissions are also calculated via the CEMS on an hourly basis and compared to the NH ₃ concentration limit of 5 ppm as an indicator of process functionality.

Malburg Generating Station Quarterly Compliance Report (Fourth Quarter 2025)

Condition of Certification	Response
AQ-13	See the response for COC AQ-C11. Additionally, the most recent triennial compliance source tests indicated compliance with the Rule 475 particulate matter emission limits of 5 kilograms per hour (11 pounds per hour [lb/hr]) or 23 milligrams per cubic meter (0.01 grain per standard cubic foot [gr/scf]) for both CTGs (0.36 lb/hr and 0.0001 gr/scf for CTG 1 and 0.57 lb/hr and 0.0007 gr/scf for CTG 2). CTG 1 was most recently tested on November 19 and 20, 2025; the test report with results was submitted to the CEC on January 15, 2026. CTG 2 was most recently tested on August 19 and 20, 2025; the test report with results was submitted to the CEC on September 29, 2025.
AQ-14	See the response for COC AQ-2.
AQ-15	Year-to-date hours of operation for the diesel-fired emergency firewater pump are provided in Appendix A, Table 10. As shown, the year-to-date 2025 hours for maintenance and testing did not exceed 50 hours and the total operational hours did not exceed 200 hours.
AQ-27	See the response for COC AQ-5. As shown, fuel consumption per turbine-duct burner pair did not exceed the specified limit of 405 million cubic feet per month.
AQ-32	The NOx Regional Clean Air Incentives Market (RECLAIM) annual emission allocation information for the MGS facility, received from the SCAQMD for compliance year 2025 – 2026, is provided in Appendix F.
AQ-36	See the responses for COCs AQ-5 and AQ-6.

Appendix A

MGS Emission Calculations



Malburg Generating Station
 Quarterly Compliance Report
 Appendix A, Table 1

Reporting Period: **Quarter 4 2025**

Table 1A. Annual Emissions - Calendar Year 2025

Source	Annual Emissions (lb/year)					
	NOx	CO	VOC	SOx	PM ₁₀ /PM _{2.5}	NH ₃
CTG 1 & Duct Burner	10,205	4,067	2,129	382	8,316	12,648
CTG 2 & Duct Burner	9,380	3,418	2,013	361	7,862	11,999
Cooling Tower	--	--	--	--	430.93	--
Diesel Firewater Pump	158	4.6	1.1	0.07	1.0	0.27
Total	19,743	7,490	4,143	743	16,609	24,647

Table 1B. Quarterly Emissions - October 1, 2025 through December 31, 2025

Source	Quarterly Emissions (lb/quarter)					
	NOx	CO	VOC	SOx	PM ₁₀ /PM _{2.5}	NH ₃
CTG 1 & Duct Burner	1,648	687	339	61	1,323	2,016
CTG 2 & Duct Burner	2,108	765	451	81	1,762	2,675
Cooling Tower	--	--	--	--	79	--
Diesel Firewater Pump	32	0.93	0.23	0.01	0.21	0.05
Total	3,788	1,453	790	141	3,163	4,692

Malburg Generating Station
 Quarterly Compliance Report
 Appendix A, Table 2

Reporting Period: **Quarter 4 2025**

Table 2. Cooling Tower Total Dissolved Solids (TDS) Sampling Results ^[1,2]

Sampling Period		TDS (ppm)
Start Date	End Date	
9/29/2025	10/5/2025	4,050
10/6/2025	10/12/2025	4,120
10/13/2025	10/19/2025	3,400
10/20/2025	10/26/2025	4,400
10/27/2025	11/2/2025	4,300
11/3/2025	11/9/2025	3,900
11/10/2025	11/16/2025	4,100
11/17/2025	11/23/2025	4,100
11/24/2025	11/30/2025	4,080
12/1/2025	12/7/2025	--
12/8/2025	12/14/2025	--
12/15/2025	12/21/2025	--
12/22/2025	12/28/2025	--
12/29/2025	1/4/2026	--

^[1] Sampling results taken from Positive Lab's Weekly Cooling Tower Blowdown Reports, as provided in Appendix B of the QCR.

^[2] MGS was primarily offline during December 2025; therefore, cooling tower TDS samples were not collected during this time.

**Malburg Generating Station
Quarterly Compliance Report
Appendix A, Table 3**

Reporting Period: **October 2025**

Cooling Tower Total Dissolved Solids (TDS) Sampling Results

Data Source: Positive Lab's Weekly Cooling Tower Blowdown Reports, as provided in Appendix B of the QCR

Sample Date	Period		TDS (ppm)
	Start Date	End Date	
9/29/2025	9/29/2025	10/5/2025	4,050
10/7/2025	10/6/2025	10/12/2025	4,120
10/14/2025	10/13/2025	10/19/2025	3,400
10/21/2025	10/20/2025	10/26/2025	4,400
10/27/2025	10/27/2025	11/2/2025	4,300

Methodology (per Condition of Certification [COC] AQ-C7)

PM_{10} Emissions (lb/day) = Circulation Rate (gal/day) x Density of Water (lb/gal) x Total Dissolved Solids (ppm) / 1,000,000 x Drift Factor (%) / 100 x Correction Factor

Constants

Parameter	Value
Circulation Rate per Pump (gal/min) ^[1]	13,500
Number of Pumps	2
Total Circulation Rate (gal/min)	27,000
Water Density (lb/gal)	8.334
Drift Factor (%) ^[2]	0.0005
Correction Factor (unitless) ^[3]	0.2

^[1] Source: M3-10 Main Circulating Water System P&ID.

^[2] Per COC AQ-C4.

^[3] Source: SPX Cooling Technologies' Cooling Tower Drift Mass Distribution.

Cooling Tower Daily PM₁₀ Emissions

Date	Circulation Rate (gal/day) ^[1]	TDS (ppm)	PM₁₀ Emissions (lb/day)	Above 6.2 lb/day PM₁₀ Limit? ^[2]
10/1/2025	38,880,000	4,050	1.31	No
10/2/2025	38,880,000	4,050	1.31	No
10/3/2025	38,880,000	4,050	1.31	No
10/4/2025	38,880,000	4,050	1.31	No
10/5/2025	38,880,000	4,050	1.31	No
10/6/2025	38,880,000	4,120	1.33	No
10/7/2025	38,880,000	4,120	1.33	No
10/8/2025	38,880,000	4,120	1.33	No
10/9/2025	38,880,000	4,120	1.33	No
10/10/2025	38,880,000	4,120	1.33	No
10/11/2025	38,880,000	4,120	1.33	No
10/12/2025	38,880,000	4,120	1.33	No
10/13/2025	38,880,000	3,400	1.10	No
10/14/2025	38,880,000	3,400	1.10	No
10/15/2025	38,880,000	3,400	1.10	No
10/16/2025	38,880,000	3,400	1.10	No
10/17/2025	38,880,000	3,400	1.10	No
10/18/2025	38,880,000	3,400	1.10	No
10/19/2025	38,880,000	3,400	1.10	No
10/20/2025	38,880,000	4,400	1.43	No
10/21/2025	38,880,000	4,400	1.43	No
10/22/2025	38,880,000	4,400	1.43	No
10/23/2025	38,880,000	4,400	1.43	No
10/24/2025	38,880,000	4,400	1.43	No
10/25/2025	38,880,000	4,400	1.43	No
10/26/2025	38,880,000	4,400	1.43	No
10/27/2025	38,880,000	4,300	1.39	No
10/28/2025	38,880,000	4,300	1.39	No
10/29/2025	38,880,000	4,300	1.39	No
10/30/2025	38,880,000	4,300	1.39	No
10/31/2025	38,880,000	4,300	1.39	No

^[1] Maximum daily circulation rate conservatively used to estimate PM₁₀ emissions when the cooling tower is operated for any part of the day. Circulation rate is zero for days the cooling tower is not operated at all.

^[2] Daily emissions limit established in COC AQ-C7.

**Malburg Generating Station
Quarterly Compliance Report
Appendix A, Table 4**

Reporting Period: **November 2025**

Cooling Tower Total Dissolved Solids (TDS) Sampling Results

Data Source: Positive Lab's Weekly Cooling Tower Blowdown Reports, as provided in Appendix B of the QCR

Sample Date	Period		TDS (ppm)
	Start Date	End Date	
10/27/2025	10/27/2025	11/2/2025	4,300
11/5/2025	11/3/2025	11/9/2025	3,900
11/10/2025	11/10/2025	11/16/2025	4,100
11/18/2025	11/17/2025	11/23/2025	4,100
11/24/2025	11/24/2025	11/30/2025	4,080

Methodology (per Condition of Certification [COC] AQ-C7)

PM_{10} Emissions (lb/day) = Circulation Rate (gal/day) x Density of Water (lb/gal) x Total Dissolved Solids (ppm) / 1,000,000 x Drift Factor (%) / 100 x Correction Factor

Constants

Parameter	Value
Circulation Rate per Pump (gal/min) ^[1]	13,500
Number of Pumps	2
Total Circulation Rate (gal/min)	27,000
Water Density (lb/gal)	8.334
Drift Factor (%) ^[2]	0.0005
Correction Factor (unitless) ^[3]	0.2

^[1] Source: M3-10 Main Circulating Water System P&ID.

^[2] Per COC AQ-C4.

^[3] Source: SPX Cooling Technologies' Cooling Tower Drift Mass Distribution.

Cooling Tower Daily PM₁₀ Emissions

Date	Circulation Rate (gal/day) ^[1]	TDS (ppm)	PM₁₀ Emissions (lb/day)	Above 6.2 lb/day PM₁₀ Limit? ^[2]
11/1/2025	38,880,000	4,300	1.39	No
11/2/2025	38,880,000	4,300	1.39	No
11/3/2025	38,880,000	3,900	1.26	No
11/4/2025	38,880,000	3,900	1.26	No
11/5/2025	38,880,000	3,900	1.26	No
11/6/2025	38,880,000	3,900	1.26	No
11/7/2025	38,880,000	3,900	1.26	No
11/8/2025	38,880,000	3,900	1.26	No
11/9/2025	38,880,000	3,900	1.26	No
11/10/2025	38,880,000	4,100	1.33	No
11/11/2025	38,880,000	4,100	1.33	No
11/12/2025	38,880,000	4,100	1.33	No
11/13/2025	38,880,000	4,100	1.33	No
11/14/2025	38,880,000	4,100	1.33	No
11/15/2025	38,880,000	4,100	1.33	No
11/16/2025	38,880,000	4,100	1.33	No
11/17/2025	38,880,000	4,100	1.33	No
11/18/2025	38,880,000	4,100	1.33	No
11/19/2025	38,880,000	4,100	1.33	No
11/20/2025	38,880,000	4,100	1.33	No
11/21/2025	38,880,000	4,100	1.33	No
11/22/2025	38,880,000	4,100	1.33	No
11/23/2025	38,880,000	4,100	1.33	No
11/24/2025	38,880,000	4,080	1.32	No
11/25/2025	38,880,000	4,080	1.32	No
11/26/2025	38,880,000	4,080	1.32	No
11/27/2025	38,880,000	4,080	1.32	No
11/28/2025	38,880,000	4,080	1.32	No
11/29/2025	0	4,080	0.00	No
11/30/2025	0	4,080	0.00	No

^[1] Maximum daily circulation rate conservatively used to estimate PM₁₀ emissions when the cooling tower is operated for any part of the day. Circulation rate is zero for days the cooling tower is not operated at all.

^[2] Daily emissions limit established in COC AQ-C7.

**Malburg Generating Station
Quarterly Compliance Report
Appendix A, Table 5**

Reporting Period: December 2025

Cooling Tower Total Dissolved Solids (TDS) Sampling Results

Data Source: Positive Lab's Weekly Cooling Tower Blowdown Reports, as provided in Appendix B of the QCR

Sample Date	Period		TDS (ppm)
	Start Date	End Date	
11/24/2025	11/24/2025	11/30/2025	4,080
--	12/1/2025	12/7/2025	--
--	12/8/2025	12/14/2025	--
--	12/15/2025	12/21/2025	--
--	12/22/2025	12/28/2025	--
--	12/29/2025	1/4/2026	--

Methodology (per Condition of Certification [COC] AQ-C7)

PM_{10} Emissions (lb/day) = Circulation Rate (gal/day) x Density of Water (lb/gal) x Total Dissolved Solids (ppm) / 1,000,000 x Drift Factor (%) / 100 x Correction Factor

Constants

Parameter	Value
Circulation Rate per Pump (gal/min) ^[1]	13,500
Number of Pumps	2
Total Circulation Rate (gal/min)	27,000
Water Density (lb/gal)	8.334
Drift Factor (%) ^[2]	0.0005
Correction Factor (unitless) ^[3]	0.2

^[1] Source: M3-10 Main Circulating Water System P&ID.

^[2] Per COC AQ-C4.

^[3] Source: SPX Cooling Technologies' Cooling Tower Drift Mass

Cooling Tower Daily PM₁₀ Emissions

Date	Circulation Rate (gal/day) ^[1]	TDS (ppm) ^[3]	PM ₁₀ Emissions (lb/day)	Above 6.2 lb/day PM ₁₀ Limit? ^[2]
12/1/2025	0	--	0.00	No
12/2/2025	0	--	0.00	No
12/3/2025	0	--	0.00	No
12/4/2025	0	--	0.00	No
12/5/2025	0	--	0.00	No
12/6/2025	0	--	0.00	No
12/7/2025	0	--	0.00	No
12/8/2025	0	--	0.00	No
12/9/2025	0	--	0.00	No
12/10/2025	0	--	0.00	No
12/11/2025	0	--	0.00	No
12/12/2025	0	--	0.00	No
12/13/2025	0	--	0.00	No
12/14/2025	0	--	0.00	No
12/15/2025	0	--	0.00	No
12/16/2025	0	--	0.00	No
12/17/2025	0	--	0.00	No
12/18/2025	0	--	0.00	No
12/19/2025	0	--	0.00	No
12/20/2025	38,880,000	4,080	1.32	No
12/21/2025	0	--	0.00	No
12/22/2025	0	--	0.00	No
12/23/2025	0	--	0.00	No
12/24/2025	0	--	0.00	No
12/25/2025	0	--	0.00	No
12/26/2025	0	--	0.00	No
12/27/2025	0	--	0.00	No
12/28/2025	0	--	0.00	No
12/29/2025	0	--	0.00	No
12/30/2025	0	--	0.00	No
12/31/2025	0	--	0.00	No

^[1] Maximum daily circulation rate conservatively used to estimate PM₁₀ emissions when the cooling tower is operated for any part of the day. Circulation rate is zero for days the cooling tower is not operated at all.

^[2] Daily emissions limit established in COC AQ-C7.

^[3] MGS was primarily offline during December 2025 for outage maintenance; therefore, a Cooling Tower Blowdown Report was not prepared during this time. For the day that MGS did operate during December 2025, sample results were assumed to be best represented by the results sampled on November 24, 2025.

**Malburg Generating Station
Quarterly Compliance Report
Appendix A, Tables 6, 7, 8 & 9**

Reporting Period: **Quarter 4 2025**

Table 6. Monthly Turbine-Duct Burner Fuel Flow

Source	October		November		December	
	Fuel Flow (MMscf/month) ^[1]	Above 405 MMscf/month Limit? ^[2]	Fuel Flow (MMscf/month) ^[1]	Above 405 MMscf/month Limit? ^[2]	Fuel Flow (MMscf/month) ^[1]	Above 405 MMscf/month Limit? ^[2]
CTG 1	35.9		181.0		1	
CTG 1 Duct Burner	0.07		1.62		0.00	
Total CTG 1 & Duct Burner	36.0	No	182.6	No	1	No
CTG 2	226		65		0.6	
CTG 2 Duct Burner	0.99		0.09		0.00	
Total CTG 2 & Duct Burner	227	No	65	No	0.6	No

^[1] CTG and Duct Burner fuel flow data obtained from 'U1/U2_MonthlySummary_MassEmissionsAndFuel' and 'All_12MonthSummary_GasUsage' RegPerfect Reports.

^[2] Monthly fuel flow limit is per Condition of Certification (COC) AQ-27.

Table 7. Monthly Emissions - October 2025

Source	Monthly Emissions (lb/month) ^[1]					
	NO _x ^[2]	CO	VOC	SO _x	PM ₁₀ /PM _{2.5}	NH ₃ ^[3]
CTG 1 & Duct Burner	322	172	55	10	217	328
CTG 2 & Duct Burner	1,560	470	350.2	62.4	1,367	2,077
Monthly Emission Limits ^[4]	N/A	7,633	3,236	227	4,876	N/A
Exceeds Limit?	N/A	No	No	No	No	N/A

^[1] Unless otherwise noted, monthly emissions data obtained from 'U1/U2_MonthlySummary_MassEmissionsAndFuel' RegPerfect Report.

^[2] Monthly NO_x emissions are as submitted to SCAQMD, based on the 'U1_U2MonthlyRECLAIMNOxSummaryByDay' RegPerfect Report.

^[3] Monthly NH₃ emissions are calculated using monthly fuel usage and default emission factors from the SCAQMD's AER Combustion Default Emission Factors - December 2024. The emission factors are 9.1 lbs/MMscf and 18.0 lbs/MMscf for the CTGs and Duct Burners, respectively.

^[4] Monthly emission limits are per COC AQ-5.

Table 8. Monthly Emissions - November 2025

Source	Monthly Emissions (lb/month) ^[1]					
	NO _x ^[2]	CO	VOC	SO _x	PM ₁₀ /PM _{2.5}	NH ₃ ^[3]
CTG 1 & Duct Burner	1,255	437	281	51	1,098	1,676
CTG 2 & Duct Burner	514	237	100	18	391	593
Monthly Emission Limits ^[4]	N/A	7,633	3,236	227	4,876	N/A
Exceeds Limit?	N/A	No	No	No	No	N/A

^[1] Unless otherwise noted, monthly emissions data obtained from 'U1/U2_MonthlySummary_MassEmissionsAndFuel' RegPerfect Report.

^[2] Monthly NO_x emissions are as submitted to SCAQMD, based on the 'U1_U2MonthlyRECLAIMNOxSummaryByDay' RegPerfect Report.

^[3] Monthly NH₃ emissions are calculated using monthly fuel usage and default emission factors from the SCAQMD's AER Combustion Default Emission Factors - December 2024. The emission factors are 9.1 lbs/MMscf and 18.0 lbs/MMscf for the CTGs and Duct Burners, respectively.

^[4] Monthly emission limits are per COC AQ-5.

Table 9. Monthly Emissions - December 2025

Source	Monthly Emissions (lb/month) ^[1]					
	NO _x ^[2]	CO	VOC	SO _x	PM ₁₀ /PM _{2.5}	NH ₃ ^[3]
CTG 1 & Duct Burner	71	78	2	0	8	12
CTG 2 & Duct Burner	35	58	1	0.2	4	6
Monthly Emission Limits ^[4]	N/A	7,633	3,236	227	4,876	N/A
Exceeds Limit?	N/A	No	No	No	No	N/A

^[1] Unless otherwise noted, monthly emissions data obtained from 'U1/U2_MonthlySummary_MassEmissionsAndFuel' RegPerfect Report.

^[2] Monthly NO_x emissions are as submitted to SCAQMD, based on the 'U1_U2MonthlyRECLAIMNOxSummaryByDay' RegPerfect Report.

^[3] Monthly NH₃ emissions are calculated using monthly fuel usage and default emission factors from the SCAQMD's AER Combustion Default Emission Factors - December 2024. The emission factors are 9.1 lbs/MMscf and 18.0 lbs/MMscf for the CTGs and Duct Burners, respectively.

^[4] Monthly emission limits are per COC AQ-5.

Malburg Generating Station
Quarterly Compliance Report
Appendix A, Table 10

Reporting Period: **Quarter 4 2025**

Methodology

Emissions (lb/month) = Fuel Usage (gal/month) / 1,000 (gal/Mgal) x Emission Factor (lb/Mgal)

Emission Factors

Pollutant	Emission Factor (lb/Mgal)	Reference
NOx	469	Emission factor provided in the facility's Title V Permit.
CO	13.62	Emission factor converted from the factor provided in the facility's Title V Permit (0.4 g/bhp-hr), based on the unit's power rating (173 hp) and maximum fuel throughput (11.2 gal/hr).
VOC	3.41	Emission factor converted from the factor provided in the facility's Title V Permit (0.1 g/bhp-hr), based on the unit's power rating (173 hp) and maximum fuel throughput (11.2 gal/hr).
SOx	0.21	Default for Diesel/Distillate Oil, ICEs given in the SCAQMD's AER Combustion Default Emission Factors - December 2024.
PM ₁₀ /PM _{2.5}	3.065	Emission factor converted from the factor provided in the facility's Title V Permit (0.09 g/bhp-hr), based on the unit's power rating (173 hp) and maximum fuel throughput (11.2 gal/hr).
NH ₃	0.80	Default for diesel combustion equipment without an SNCR or SCR given in the SCAQMD's AER Combustion Default Emission Factors - December 2024.

Table 10. Monthly Diesel Fire Pump Hours of Operation, Fuel Usage, and Emissions

Month	Monthly Hours of Operation ^[1]			Fuel Usage (gal/month) ^[2]	Monthly Emissions (lb/month)					
	Maintenance	Testing	Emergency		NOx	CO	VOC	SOx	PM ₁₀ /PM _{2.5}	NH ₃
January	0.0	2.0	0.0	22.4	10.5	0.31	0.08	0.00	0.07	0.02
February	0.0	7.2	0.0	80.6	37.8	1.10	0.27	0.02	0.25	0.06
March	0.0	2.0	0.0	22.4	10.5	0.31	0.08	0.00	0.07	0.02
April	0.0	2.5	0.0	28.0	13.1	0.38	0.10	0.01	0.09	0.02
May	0.0	1.2	0.0	13.4	6.3	0.18	0.05	0.00	0.04	0.01
June	0.0	2.0	0.0	22.4	10.5	0.31	0.08	0.00	0.07	0.02
July	0.0	2.5	0.0	28.0	13.1	0.38	0.10	0.01	0.09	0.02
August	0.0	2.0	0.0	22.4	10.5	0.31	0.08	0.00	0.07	0.02
September	0.0	2.5	0.0	28.0	13.1	0.38	0.10	0.01	0.09	0.02
October	0.0	2.0	0.0	22.4	10.5	0.31	0.08	0.00	0.07	0.02
November	0.0	2.0	0.0	22.4	10.5	0.31	0.08	0.00	0.07	0.02
December	0.0	2.1	0.0	23.5	11.0	0.32	0.08	0.00	0.07	0.02
Q1 Total	0.0	11.2	0.0	125.4	58.8	1.7	0.4	0.0	0.4	0.1
Q2 Total	0.0	5.7	0.0	63.8	29.9	0.9	0.2	0.0	0.2	0.1
Q3 Total	0.0	7.0	0.0	78.4	36.8	1.1	0.3	0.0	0.2	0.1
Q4 Total	0.0	6.1	0.0	68.3	32.0	0.9	0.2	0.0	0.2	0.1
Annual Total	0.0	30.0	0.0	336.0	157.6	4.6	1.1	0.1	1.0	0.3
Annual Limit for Maintenance and Testing ^[3]			50							
Total Annual Limit ^[3]			200							
Exceeds Limits?			No							

^[1] Monthly hours of operation calculated from Device 385/403 run timer readings.

^[2] Fuel usage (gal/month) calculated by multiplying the hours of operation by the unit's maximum fuel throughput (11.2 gal/hour).

^[3] Annual limits for hours of operation are per Condition of Certification (COC) AQ-15.

Appendix B

Cooling Tower Blowdown Reports





781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

October 06, 2025

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2509230
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on September 29, 2025.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. Analytes flagged ANC are not offered by ELAP for certification. Analytes flagged ANA are offered by ELAP; however, they are not PLS certified.

The laboratory report may not be reproduced, except in full, without the written approval of the laboratory. The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) are provided on the final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

City of Vernon
 4963 Soto St.
 Vernon, CA 90058

File #: 74548
 Report Date: 10/06/25
 Submitted: 09/29/25
PLS Report No.: 2509230

Attn: Matt Richards Phone: (323) 476-3626 FAX: (323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2509230-01) Sampled: 09/29/25 08:30 Received: 09/29/25										
Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4050		1	mg/L	5.0	- SM 2540C	10/03/25	10/03/25	ss	BJ50320

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
Batch BJ50320 - -										
Blank										
Prepared & Analyzed: 10/03/25										
Total Dissolved Solids	ND	5.0	mg/L							
LCS										
Prepared & Analyzed: 10/03/25										
Total Dissolved Solids	53.0	5.0	mg/L	50.0		106	80-120			
Duplicate										
Source: 2509230-01 Prepared & Analyzed: 10/03/25										
Total Dissolved Solids	4050	5.0	mg/L		4050			0.0988	5	

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the reported limit(s)
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, LACSD No. 10138

Rick Owen Parker

 Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

DATE: 9-29-25 PAGE: 1 OF 1

FILE NO.: _____ LAB NO.: 2509230

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO:

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED OBSERVED TEMP: 14°C

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: CORRECTED TEMP: 0.1°C

SAMPLER NAME: JOHN BARIE SIGNATURE: THERMO ID: 57

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS								SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE									
	<u>9-29-25</u>	<u>0830</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X								

Relinquished by (Signature & Name): <u>MA</u>	Received by (Signature & Name): <u>John Barie</u>	Date: <u>9-29-25</u>	Time: <u>0830</u>	SAMPLE DISPOSITION 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION:

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER

Arrived at the lab: 9-29-25 0910



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

October 13, 2025

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2510050
Project Name: Malburg Generating Station Weekly


Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on October 07, 2025.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. Analytes flagged ANC are not offered by ELAP for certification. Analytes flagged ANA are offered by ELAP; however, they are not PLS certified.

The laboratory report may not be reproduced, except in full, without the written approval of the laboratory. The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) are provided on the final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

City of Vernon
 4963 Soto St.
 Vernon, CA 90058

File #:74548
 Report Date: 10/13/25
 Submitted: 10/07/25
PLS Report No.: 2510050

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2510050-01) Sampled: 10/07/25 08:20 Received: 10/07/25

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4120		1	mg/L	5.0	- SM 2540C	10/10/25	10/10/25	ss	BJ51029

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
Batch BJ51029 --										
Blank										
Prepared & Analyzed: 10/10/25										
Total Dissolved Solids	ND	5.0	mg/L							
LCS										
Prepared & Analyzed: 10/10/25										
Total Dissolved Solids	59.0	5.0	mg/L	50.0		118	80-120			
Duplicate										
Source: 2510078-01 Prepared & Analyzed: 10/10/25										
Total Dissolved Solids	3910	5.0	mg/L		3900			0.341	5	

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the reported limit(s)
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, LACSD No. 10138

Rick Owen Parker

 Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
 [213] 745-5312 FAX [213] 745-6372

DATE: 10/25 PAGE: 1 OF

FILE NO.: LAB NO.: 2510050

CLIENT NAME: **CITY OF VERNON** PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO:

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: OBSERVED TEMP 1.9°C

SAMPLER NAME: JOHN BARIE SIGNATURE: CORRECTED TEMP 0.9°C

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal THERMO ID: 67

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: **Y N** GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS								SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE									
	<u>10/25</u>	<u>0820</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X								

Relinquished by (Signature & Name): <u>MA</u>	Received by (Signature & Name): <u>Jo Tombrant</u>	Date: <u>10/25</u>	Time: <u>0820</u>	SAMPLE DISPOSITION 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION:

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER

Arrived at the lab 10/25 0950



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

October 22, 2025

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2510096
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on October 14, 2025.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. Analytes flagged ANC are not offered by ELAP for certification. Analytes flagged ANA are offered by ELAP; however, they are not PLS certified.

The laboratory report may not be reproduced, except in full, without the written approval of the laboratory. The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) are provided on the final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

City of Vernon
 4963 Soto St.
 Vernon, CA 90058

File #:74548
 Report Date: 10/22/25
 Submitted: 10/14/25
PLS Report No.: 2510096

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2510096-01) Sampled: 10/14/25 08:40 Received: 10/14/25

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	3400		1	mg/L	5.0	- SM 2540C	10/20/25	10/21/25	ss	BJ52207

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
Batch BJ52207 --										
Blank										
Total Dissolved Solids	ND	5.0	mg/L							
LCS										
Total Dissolved Solids	51.0	5.0	mg/L	50.0		102	80-120			
Duplicate Source: 2510096-01										
Total Dissolved Solids	3490	5.0	mg/L		3400			2.37	5	
Duplicate Source: 2510162-01										
Total Dissolved Solids	133	5.0	mg/L		140			4.88	5	

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the reported limit(s)
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, LACSD No. 10138

Rick Owen Parker

 Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

DATE: 10/14/15 PAGE: 1 OF 1

FILE NO.: _____ LAB NO.: 2510096

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO:

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED OBSERVED TEMP: 6.9°C

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: CORRECTED TEMP: 0.4°C

SAMPLER NAME: JOHN BARIE SIGNATURE: [Signature] THERMO ID: 67

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS								SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE									
	<u>10/14/15</u>	<u>0840</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X								

Relinquished by (Signature & Name): <u>[Signature]</u>	Received by (Signature & Name): <u>[Signature]</u>	Date: <u>10/14/15</u>	Time: <u>0840</u>	SAMPLE DISPOSITION 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION:

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER

Arrived at the lab 10/14/15 0930



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

October 27, 2025

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2510242
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on October 21, 2025.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. Analytes flagged ANC are not offered by ELAP for certification. Analytes flagged ANA are offered by ELAP; however, they are not PLS certified.

The laboratory report may not be reproduced, except in full, without the written approval of the laboratory. The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) are provided on the final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager

Certificate of Analysis

Page 2 of 2

 City of Vernon
 4963 Soto St.
 Vernon, CA 90058

Attn: Matt Richards

Phone: (323) 476-3626 FAX:(323) 476-3640

File #:74548

Report Date: 10/27/25

Submitted: 10/21/25

PLS Report No.: 2510242
Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2510242-01) Sampled: 10/21/25 08:20 Received: 10/21/25										
Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4400		1	mg/L	5.0	- SM 2540C	10/24/25	10/24/25	ss	BJ52416

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
Batch BJ52416 - -										
Blank										
Prepared & Analyzed: 10/24/25										
Total Dissolved Solids	ND	5.0	mg/L							
LCS										
Prepared & Analyzed: 10/24/25										
Total Dissolved Solids	44.0	5.0	mg/L	50.0		88.0	80-120			
Duplicate										
Source: 2510254-01 Prepared & Analyzed: 10/24/25										
Total Dissolved Solids	93.3	5.0	mg/L		95.0			1.77	5	

Notes and Definitions

NA Not Applicable
 ND Analyte NOT DETECTED at or above the reported limit(s)
 NR Not Reported
 MDL Method Detection Limit
 PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, LACSD No. 10138



Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

DATE: 10-24-05 PAGE: 1 OF 1

FILE NO.: _____ LAB NO.: 2510242

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO:

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED OBSERVED TEMP: 21.0°C

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: CORRECTED TEMP: 1.0°C

SAMPLER NAME: JOHN BARIE SIGNATURE: [Signature] THERMO ID: 67

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS								SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE									
	<u>10-24-05</u>	<u>8:20</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X								

Relinquished by (Signature & Name): <u>MA</u>	Received by (Signature & Name): <u>Jo John Doe</u>	Date: <u>10-24-05</u>	Time: <u>0820</u>	SAMPLE DISPOSITION 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION:

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER

Arrived at the lab 10-24-05 0900



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

November 03, 2025

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2510306
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on October 27, 2025.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. Analytes flagged ANC are not offered by ELAP for certification. Analytes flagged ANA are offered by ELAP; however, they are not PLS certified.

The laboratory report may not be reproduced, except in full, without the written approval of the laboratory. The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) are provided on the final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager

Certificate of Analysis

Page 2 of 2

City of Vernon
4963 Soto St.
Vernon, CA 90058

File #:74548
Report Date: 11/03/25
Submitted: 10/27/25
PLS Report No.: 2510306

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2510306-01) Sampled: 10/27/25 08:30 Received: 10/27/25										
Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4300		1	mg/L	5.0	- SM 2540C	10/31/25	10/31/25	ss	BJ53114

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
Batch BJ53114 - -										
Blank										
Prepared & Analyzed: 10/31/25										
Total Dissolved Solids	ND	5.0	mg/L							
LCS										
Prepared & Analyzed: 10/31/25										
Total Dissolved Solids	49.0	5.0	mg/L	50.0		98.0	80-120			
Duplicate										
Source: 2510306-01 Prepared & Analyzed: 10/31/25										
Total Dissolved Solids	4350	5.0	mg/L		4300			0.963	5	

Notes and Definitions

NA Not Applicable
 ND Analyte NOT DETECTED at or above the reported limit(s)
 NR Not Reported
 MDL Method Detection Limit
 PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, LACSD No. 10138



Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

DATE: 10-27-25 PAGE: 1 OF 1

FILE NO.: _____ LAB NO.: 2510306

CLIENT NAME: CITY OF VERNON PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY P.O.NO. AIRBILL NO:

ADDRESS: 4963 SOTO ST. VERNON CA 90058 ANALYSES REQUESTED OBSERVED TEMP: 1.5°C

PROJECT MANAGER MATT RICHARDS PHONE NO: FAX NO: CORRECTED TEMP: 0.8°C

SAMPLER NAME: JOHN BARIE SIGNATURE: [Signature] THERMO ID: 67

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: Y N GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS								SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE									
	<u>10/27/25</u>	<u>0830</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X								

Relinquished by (Signature & Name): <u>[Signature]</u>	Received by (Signature & Name): <u>[Signature]</u>	Date: <u>10/27/25</u>	Time: <u>0830</u>	SAMPLE DISPOSITION 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION:

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER

Arrived at the lab 10/27/25 0905



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

November 06, 2025

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2511028
Project Name: Malburg Generating Station Weekly


Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on November 05, 2025.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. Analytes flagged ANC are not offered by ELAP for certification. Analytes flagged ANA are offered by ELAP; however, they are not PLS certified.

The laboratory report may not be reproduced, except in full, without the written approval of the laboratory. The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) are provided on the final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

City of Vernon
 4963 Soto St.
 Vernon, CA 90058

File #:74548
 Report Date: 11/06/25
 Submitted: 11/05/25
PLS Report No.: 2511028

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2511028-01) Sampled: 11/05/25 08:40 Received: 11/05/25

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	3900		1	mg/L	5.0	- SM 2540C	11/06/25	11/06/25	ss	BK50615

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	Limit	RPD	RPD Limit	Qualifier
Batch BK50615 - -										
Blank										
Prepared & Analyzed: 11/06/25										
Total Dissolved Solids	ND	5.0	mg/L							
LCS										
Prepared & Analyzed: 11/06/25										
Total Dissolved Solids	52.0	5.0	mg/L	50.0		104	80-120			
Duplicate										
Source: 2511028-01 Prepared & Analyzed: 11/06/25										
Total Dissolved Solids	3970	5.0	mg/L		3900			1.57	5	

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the reported limit(s)
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, LACSD No. 10138

Rick Owen Paslier

 Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

DATE: 11-5-25 PAGE: 1 OF 1

FILE NO.: _____ LAB NO.: 2511028

CLIENT NAME: **CITY OF VERNON** PROJECT NAME/NO. **MALBURG GENERATING STATION WEEKLY** P.O.NO. _____ AIRBILL NO: _____

ADDRESS: **4963 SOTO ST. VERNON CA 90058** ANALYSES REQUESTED

PROJECT MANAGER **MATT RICHARDS** PHONE NO: _____ FAX NO: _____ OBSERVED TEMP 1.9°C

SAMPLER NAME: **JOHN BARIE** SIGNATURE: *[Signature]* CORRECTED TEMP 0.9°C

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal THERMO ID: 67

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: **Y N** GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS								SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE									
	<u>11-5-25</u>	<u>0840</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X								

Relinquished by (Signature & Name): <i>MA</i>	Received by (Signature & Name): <i>J. John Barie</i>	Date: <u>11-5-25</u>	Time: <u>0840</u>	SAMPLE DISPOSITION 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION:

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER

Arrived at the lab 11-5-25 0930



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

November 17, 2025

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2511049
Project Name: Malburg Generating Station Weekly


Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on November 10, 2025.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. Analytes flagged ANC are not offered by ELAP for certification. Analytes flagged ANA are offered by ELAP; however, they are not PLS certified.

The laboratory report may not be reproduced, except in full, without the written approval of the laboratory. The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) are provided on the final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager

Certificate of Analysis

Page 2 of 2

 City of Vernon
 4963 Soto St.
 Vernon, CA 90058

Attn: Matt Richards

Phone: (323) 476-3626 FAX:(323) 476-3640

File #:74548

Report Date: 11/17/25

Submitted: 11/10/25

PLS Report No.: 2511049
Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2511049-01) Sampled: 11/10/25 08:10 Received: 11/10/25										
Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4100		1	mg/L	5.0	- SM 2540C	11/14/25	11/14/25	ss	BK51415

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
Batch BK51415 - -										
Blank										
Prepared & Analyzed: 11/14/25										
Total Dissolved Solids	ND	5.0	mg/L							
LCS										
Prepared & Analyzed: 11/14/25										
Total Dissolved Solids	43.0	5.0	mg/L	50.0		86.0	80-120			
Duplicate										
Source: 2511049-01 Prepared & Analyzed: 11/14/25										
Total Dissolved Solids	4070	5.0	mg/L		4100			0.792	5	

Notes and Definitions

NA Not Applicable
 ND Analyte NOT DETECTED at or above the reported limit(s)
 NR Not Reported
 MDL Method Detection Limit
 PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, LACSD No. 10138



Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

DATE: 11-10-25 PAGE: 1 OF 1

FILE NO.: _____ LAB NO.: 2511049

CLIENT NAME: **CITY OF VERNON** PROJECT NAME/NO. **MALBURG GENERATING STATION WEEKLY** P.O.NO. _____ AIRBILL NO: _____

ADDRESS: **4963 SOTO ST. VERNON CA 90058** ANALYSES REQUESTED

PROJECT MANAGER **MATT RICHARDS** PHONE NO: _____ FAX NO: _____ OBSERVED TEMP: 14°C

SAMPLER NAME: **JOHN BARIE** SIGNATURE: [Signature] CORRECTED TEMP: DMC

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal THERMO ID: [Signature]

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: **Y N** GLOBAL ID#: -----

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS							SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE								
	<u>11-10-25</u>	<u>0810</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X							

Relinquished by (Signature & Name): <u>[Signature]</u>	Received by (Signature & Name): <u>[Signature]</u>	Date: <u>11-10-25</u>	Time: <u>0810</u>	SAMPLE DISPOSITION 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION:

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER

Arrived at the lab 11/10/25 1005



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

November 24, 2025

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2511146
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on November 18, 2025.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. Analytes flagged ANC are not offered by ELAP for certification. Analytes flagged ANA are offered by ELAP; however, they are not PLS certified.

The laboratory report may not be reproduced, except in full, without the written approval of the laboratory. The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) are provided on the final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

City of Vernon
 4963 Soto St.
 Vernon, CA 90058

File #:74548
 Report Date: 11/24/25
 Submitted: 11/18/25
PLS Report No.: 2511146

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2511146-01) Sampled: 11/18/25 08:25 Received: 11/18/25

Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4100		1	mg/L	5.0	- SM 2540C	11/21/25	11/21/25	ss	BK52124

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
Batch BK52124 - -										
Blank Prepared & Analyzed: 11/21/25										
Total Dissolved Solids	ND	5.0	mg/L							
LCS Prepared & Analyzed: 11/21/25										
Total Dissolved Solids	42.0	5.0	mg/L	50.0		84.0	80-120			
Duplicate Source: 2511212-01 Prepared & Analyzed: 11/21/25										
Total Dissolved Solids	2030	5.0	mg/L		2060			1.30	5	

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the reported limit(s)
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, LACSD No. 10138

Rich Owen Parker

 Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

DATE: 11/18/25 PAGE: 1 OF 1

FILE NO.: _____ LAB NO.: 2511146

CLIENT NAME: CITY OF VERNON			PROJECT NAME/NO. MALBURG GENERATING STATION WEEKLY				P.O.NO.		AIRBILL NO:			
ADDRESS: 4963 SOTO ST. VERNON CA 90058			ANALYSES REQUESTED								OBSERVED TEMP <u>2.3°C</u>	
PROJECT MANAGER MATT RICHARDS			PHONE NO:		FAX NO:				CORRECTED TEMP: <u>6.5°C</u>			
SAMPLER NAME: JOHN BARIE			SIGNATURE:						THERMO ID: <u>67</u>			
TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC.) N=Normal												
CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other												
UST PROJECT: Y N GLOBAL ID#: -----												
SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS	SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE		
	<u>11/18/25</u>	<u>0825</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X	

Relinquished by (Signature & Name): <u>MA</u>	Received by (Signature & Name): 	Date:	Time:	SAMPLE DISPOSITION 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION:

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER

Arrived at the lab 11/18/25 1330



781 East Washington Blvd., Los Angeles, CA 90021
(213) 745-5312 FAX (213) 745-6372

December 01, 2025

Matt Richards
City of Vernon
4963 Soto St.
Vernon, CA 90058

Report No.: 2511269
Project Name: Malburg Generating Station Weekly

Dear Matt Richards,

This report contains the analytical results for the sample(s) received under chain of custody(s) by Positive Lab Service on November 24, 2025.

The test results in this report are performed in compliance with ELAP accreditation requirements for the certified parameters. Analytes flagged ANC are not offered by ELAP for certification. Analytes flagged ANA are offered by ELAP; however, they are not PLS certified.

The laboratory report may not be reproduced, except in full, without the written approval of the laboratory. The issuance of the final Certificate of Analysis takes precedence over any previous Preliminary Report. Preliminary data should not be used for regulatory purposes. Authorized signature(s) are provided on the final report only.

If you have any questions in reference to this report, please contact your Positive Lab Service coordinator.


Project Manager



781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

Certificate of Analysis

Page 2 of 2

City of Vernon
 4963 Soto St.
 Vernon, CA 90058

File #:74548
 Report Date: 12/01/25
 Submitted: 11/24/25
PLS Report No.: 2511269

Attn: Matt Richards Phone: (323) 476-3626 FAX:(323) 476-3640

Project: Malburg Generating Station Weekly

Sample ID: Cooling Tower Blowdown Water (2511269-01) Sampled: 11/24/25 08:00 Received: 11/24/25										
Analyte	Results	Flag	D.F.	Units	PQL	Prep/Test Method	Prepared	Analyzed	By	Batch
Total Dissolved Solids	4080		1	mg/L	5.0	- SM 2540C	12/01/25	12/01/25	ss	BL50118

Quality Control Data

Analyte	Result	PQL	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Qualifier
Batch BL50118 - -										
Blank										
Prepared & Analyzed: 12/01/25										
Total Dissolved Solids	ND	5.0	mg/L							
LCS										
Prepared & Analyzed: 12/01/25										
Total Dissolved Solids	44.0	5.0	mg/L	50.0		88.0	80-120			
Duplicate										
Source: 2511269-01 Prepared & Analyzed: 12/01/25										
Total Dissolved Solids	4080	5.0	mg/L		4080			0.00	5	

Notes and Definitions

- NA Not Applicable
- ND Analyte NOT DETECTED at or above the reported limit(s)
- NR Not Reported
- MDL Method Detection Limit
- PQL Practical Quantitation Limit

Environmental Laboratory Accreditation Program Certificate No. 1131, LACSD No. 10138



 Authorized Signature(s)



CHAIN OF CUSTODY AND ANALYSIS REQUEST

781 East Washington Blvd., Los Angeles, CA 90021
 (213) 745-5312 FAX (213) 745-6372

DATE: _____ PAGE: _____ OF _____

FILE NO.: _____ LAB NO.: 2511269

CLIENT NAME: **CITY OF VERNON** PROJECT NAME/NO. **MALBURG GENERATING STATION WEEKLY** P.O.NO. _____ AIRBILL NO: _____

ADDRESS: **4963 SOTO ST. VERNON CA 90058** ANALYSES REQUESTED _____ OBSERVED TEMP _____

PROJECT MANAGER **MATT RICHARDS** PHONE NO: _____ FAX NO: _____ CORRECTED TEMP: _____

SAMPLER NAME: **JOHN BARBE** *John Barbe* SIGNATURE: *John Barbe* THERMO ID: _____

TAT (Turn-Around-Time): 0=Same Day; 1=24 Hour; 2=48Hour; (ETC) N=Normal

CONTAINER TYPES: B=Brass; E=Encore/Easy Draw; P=Plastic; G=Glass; V=VOA Vial; O=Other

UST PROJECT: **Y N** GLOBAL ID#: _____

SAMPLE ID	DATE SAMPLED	TIME SAMPLED	SAMPLE DESCRIPTION	MATRIX				TAT	CONTAINER		TDS							SAMPLE CONDITIONS/ CONTAINER/COMMENTS
				WATER	SOIL	SLUDGE	OTHER		#	TYPE								
	<u>11/24/25</u>	<u>8:00</u>	COOLING TOWER BLOWDOWN	X				N	1	P	X							

Relinquished by (Signature & Name): <i>N/A</i>	Received by (Signature & Name): <i>John Barbe Lisa Gotsman</i>	Date: <u>11/24/25</u>	Time: <u>8:00</u>	SAMPLE DISPOSITION 1. Samples returned to client? Yes No 2. Samples will not be stored over 30 days, unless additional storage time is requested 3. Storage time requested: _____ days, By: _____ Date: _____
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	
Relinquished by (Signature & Name):	Received by (Signature & Name):	Date:	Time:	

SPECIAL INSTRUCTION: **Arrived at the lab 11/24/25 9:58**

PRESERVATIVE 1-HNO3 2-H2SO4 3-HCL 4- ZINC ACETATE 5-NaOH 6-NH4 BUFFER 7- OTHER

OBSERV. TEMP: 2.6 °C
 CORREC. TEMP: 1.6 °C
 THERMOID: 67 BY: LB

Appendix C

Operation Logs



Malburg Generating Station
Appendix C, Table 1
Combustion Turbine Generator (CTG) Startup and Shutdown Events
During Quarter 4, 2025

CTG 1

Date	Event Type ^[1]	Event Start	Event End	Duration (hrs:min)
10/13/2025	Cold Start	22:44	00:03	1:19
10/15/2025	Stop	08:16	08:25	0:09
10/28/2025	Cold Start	15:43	16:55	1:12
11/24/2025	Stop	16:41	16:51	0:10
12/20/2025	Cold Start / Trip ^[2]	14:53	14:53	2:07
12/20/2025		15:21	17:28	
12/20/2025	Stop	19:55	20:04	0:09

CTG 2

Date	Event Type ^[1]	Event Start	Event End	Duration (hrs:min)
10/30/2025	Stop	08:32	08:41	0:09
11/13/2025	Cold Start	14:43	16:01	1:18
11/17/2025	Stop	23:57	00:04	0:07
11/24/2025	Cold Start	15:43	16:59	1:16
11/28/2025	Stop	21:57	22:06	0:09
12/19/2025	Cold Start / Trip ^[2]	17:39	17:40	1:14
12/20/2025		18:43	19:56	
12/20/2025	Stop	20:46	20:54	0:08

^[1] A startup event is defined as initiation of combustion until the system becomes emissions compliant, for consistency with the Title V Permit definitions.

^[2] On December 19 and 20, 2025, flame ignition testing was conducted which caused intentional trips of the units within minutes of startup. When units were next restarted, they were still considered "cold" having never sufficiently warmed during the flame ignition testing. As a result, the combined testing and subsequent startup activities are considered one cold start with a trip.

Malburg Generating Station
Appendix C, Table 2
Diesel Firewater Pump Testing Times
During Quarter 4, 2025

Date	Time (hh:mm)	Start Hours	End Hours	Event Type	Hours of Operation
10/7/2025	10:15	431.5	432.0	Testing	0.5
10/14/2025	13:27	432.0	432.5	Testing	0.5
10/21/2025	7:27	432.5	433.0	Testing	0.5
10/28/2025	9:57	433.0	433.5	Testing	0.5
11/4/2025	9:53	433.5	434.0	Testing	0.5
11/11/2025	12:03	434.0	434.5	Testing	0.5
11/18/2025	15:10	434.5	435.0	Testing	0.5
11/26/2025	9:46	435.0	435.5	Testing	0.5
12/4/2025	9:12	435.5	436.0	Testing	0.5
12/13/2025	8:26	436.0	436.6	Testing	0.6
12/23/2025	9:47	436.6	437.1	Testing	0.5
12/30/2025	9:49	437.1	437.6	Testing	0.5

Appendix D

Diesel Fuel Oil Purchase Records





SALES ORDER/DELIVERY TICKET

ORDER NUMBER: OD-0000163065

Page: 1 of 2

TERMS NET 30 DAYS

SALES REP: TODD CRIPPS

PHONE: (714) 938-5714

PO# 250060

SCHEDULED DELIVERY FROM: 03/18/2025 12:00AM

SCHEDULED DELIVERY TO:

ROM:

SHIP VIA: SC COMMERCIAL (LUBES)

WHSE WH - SANTA FE SPRINGS

SC Commercial, LLC, DBA SC Fuels
PO BOX 14237
ORANGE, CA 92863-1237
(888) 723-8357

PLEASE REMIT ALL PAYMENTS TO:

PO BOX 14237
ORANGE, CA 92863-1237

ACCT NO (Bill-to) 10001045

CITY OF VERNON
4305 SANTA FE AVE
ATTN: DEPARTMENT D
Los Angeles, CA 90058

ACCT NO (Ship-to) 220001

CITY OF VERNON-SOTO ST-L
4963 SOTO ST
Los Angeles, CA 90058

HM	ITEM CODE	ITEM DESCRIPTION	QTY ORDERED	QTY DEL	PACKAGE DESC	EXTENDED QTY
----	-----------	------------------	-------------	---------	--------------	--------------

O:TODD/POC:ROB 323-583-8811 X257/HRS:8A-2P


MTO

R99 RENEWABLE DSL DYED 2.00 2 55 GAL DRUM 110.00 GALS

X UN1202 (NA1993), DIESEL FUEL, 3,PG III - 15PPM OR LESS SULFUR.
CARB DYED DIESEL. NONTAXABLE USE ONLY, PENALTY FOR TAXABLE USE MAY CONTAIN UP TO5% BIODIESEL.

250054981	CH GST ADVANTAGE EP 32	1.00	<u>1</u>	55 GAL DRUM	55.00 GALS
DRUMDEPOSIT	DRUM DEPOSIT	3.00	<u>3</u>		3.00
RCF LUBES	REG COMPLIANCE FEE	1.00	<u>1</u>		1.00
FSC LUBES	LUBES FUEL SURCHARGE LUBES	1.00	<u>1</u>		1.00

www.SCFuels.com "Your Single Choice for Petroleum Products"
 24-HOUR EMERGENCY RESPONSE CALL CHEMTREC 1-800-424-9300

Received by	 <small>customer signature</small>	Date:	3/17/25	Arrived Destination	1:24	AM PM
Printed Name	 <small>customer first and last name</small>			Completed	1:36	AM PM
Driver's Signature				Truck #	924	
				Drum Credit		

www.scfuels.com

FOR CHEMICAL EMERGENCY

THIS IS TO CERTIFY THAT THE ABOVE NAME MATERIALS ARE PROPERLY CLASSIFIED, DESCRIBED, PACKAGED, MARKED AND LABELED AND ARE IN PROPER CONDITION FOR TRANSPORTATION ACCORDING TO APPLICABLE REGULATIONS OF THE DEPARTMENT OF TRANSPORTATION

Appendix E

Excess Emission Reports



Startup/Shutdown Excess Emissions Report

U1 CO Startup/Shutdown



From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** Malburg Generating Station

Generated: 01/12/2026 09:04 **Location:** Vernon, California

Tag Name: U1_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 688.62 Hours

Non-Operating Time: 1,519.38 Hours Report Time: 2,208.00 Hours

Unit Operation

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

Startup/Shutdown Excess Emissions Report

U1 CO Startup/Shutdown



From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** Malburg Generating Station

Generated: 01/12/2026 09:04 **Location:** Vernon, California

Tag Name: U1_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 688.62 Hours

Non-Operating Time: 1,519.38 Hours Report Time: 2,208.00 Hours



No invalid events were found in the reporting period.

Startup/Shutdown Excess Emissions Report

U1 NOx Startup/Shutdown



From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** Malburg Generating Station

Generated: 01/12/2026 09:06 **Location:** Vernon, California

Tag Name: U1_NOXRECLM_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 688.62 Hours

Non-Operating Time: 1,519.38 Hours Report Time: 2,208.00 Hours

Unit Operation

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

Startup/Shutdown Excess Emissions Report

U1 NOx Startup/Shutdown



From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** Malburg Generating Station

Generated: 01/12/2026 09:06 **Location:** Vernon, California

Tag Name: U1_NOXRECLM_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 688.62 Hours

Non-Operating Time: 1,519.38 Hours Report Time: 2,208.00 Hours

No invalid events were found in the reporting period.

Startup/Shutdown Excess Emissions Report

U1 VOC Startup/Shutdown



From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** Malburg Generating Station

Generated: 01/12/2026 09:06 **Location:** Vernon, California

Tag Name: U1_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 688.62 Hours

Non-Operating Time: 1,519.38 Hours Report Time: 2,208.00 Hours

Unit Operation

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

Startup/Shutdown Excess Emissions Report

U1 VOC Startup/Shutdown



From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** Malburg Generating Station

Generated: 01/12/2026 09:06 **Location:** Vernon, California

Tag Name: U1_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 688.62 Hours

Non-Operating Time: 1,519.38 Hours Report Time: 2,208.00 Hours



No invalid events were found in the reporting period.

Excess Emission Report



Unit 1 - CO ppmvdc 1-hour during Normal Operation

From: 10/01/2025 00:00 To: 12/31/2025 23:59 Facility Name: Malburg Generating Station
Generated: 01/12/2026 09:12 Location: Vernon, California

Tag Name: U1_CONormal_Ppmvdc_1H

Total Operating Time: 693.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 1,515.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	693.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



Unit 1 - NOx ppmvdc 1-hour during Normal Operation

From: 10/01/2025 00:00 To: 12/31/2025 23:59 Facility Name: Malburg Generating Station
Generated: 01/12/2026 09:14 Location: Vernon, California

Tag Name: U1_NOxNormal_Ppmvdc_1H

Total Operating Time: 693.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 1,515.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	693.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

Unit 1 - VOC ppmvdc 1-hour during Normal Operation

From: 10/01/2025 00:00 To: 12/31/2025 23:59 Facility Name: Malburg Generating Station
Generated: 01/12/2026 09:14 Location: Vernon, California



Tag Name: U1_VOCNormal_Ppmvdc_1H

Total Operating Time: 693.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 1,515.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	693.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report



Unit 1 - CO ppmvdc 3-hour Rolling during Normal Operation

From: 10/01/2025 00:00 To: 12/31/2025 23:59 Facility Name: Malburg Generating Station
Generated: 01/12/2026 09:15 Location: Vernon, California

Tag Name: U1_CO_3HrRoll_Ppmvdc_1H

Total Operating Time: 693.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 1,515.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	693.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Quad K Excess Emissions Report

U1 NOX 4-Hour Events

From: 10/01/2025 00:00 To: 12/31/2025 23:59
Generated: 01/12/2026 09:15

Facility Name: Malburg Generating Station
Location: Vernon, California



Tag Name: U1_NOx4H_Ppmvdc_1H

Total Operating Time: 693.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 1,515.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	693.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Startup/Shutdown Event Report

U2 CO Startup/Shutdown Events



From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** Malburg Generating Station

Generated: 01/14/2026 13:35 **Location:** Vernon, California

Tag Name: U2_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 913.68 Hours

Non-Operating Time: 1,294.32 Hours Report Time: 2,208.00 Hours

Unit Operation

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

Startup/Shutdown Event Report

U2 CO Startup/Shutdown Events



From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** Malburg Generating Station

Generated: 01/14/2026 13:35

Location: Vernon, California

Tag Name: U2_CO_LbPerHr_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 913.68 Hours

Non-Operating Time: 1,294.32 Hours

Report Time: 2,208.00 Hours

No invalid events were found in the reporting period.

Startup/Shutdown Excess Emissions Report

U2 NOx Startup/Shutdown



From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** Malburg Generating Station

Generated: 01/12/2026 09:11 **Location:** Vernon, California

Tag Name: U2_NOXRECLM_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 913.68 Hours

Non-Operating Time: 1,294.32 Hours Report Time: 2,208.00 Hours

Unit Operation

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

Startup/Shutdown Excess Emissions Report

U2 NOx Startup/Shutdown



From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** Malburg Generating Station

Generated: 01/12/2026 09:11 **Location:** Vernon, California

Tag Name: U2_NOXRECLM_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 913.68 Hours

Non-Operating Time: 1,294.32 Hours Report Time: 2,208.00 Hours



No invalid events were found in the reporting period.

Startup/Shutdown Event Report

U2 VOC Startup/Shutdown Events



From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** Malburg Generating Station

Generated: 01/12/2026 09:12 **Location:** Vernon, California

Tag Name: U2_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 913.68 Hours

Non-Operating Time: 1,294.32 Hours Report Time: 2,208.00 Hours

Unit Operation

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description

No excess emissions were found in the reporting period.

Startup/Shutdown Event Report

U2 VOC Startup/Shutdown Events



From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** Malburg Generating Station

Generated: 01/12/2026 09:12

Location: Vernon, California

Tag Name: U2_VOC_LbPerHr_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 913.68 Hours

Non-Operating Time: 1,294.32 Hours

Report Time: 2,208.00 Hours



No invalid events were found in the reporting period.

Excess Emission Report

Unit 2 - CO ppmvdc 1-hour during Normal Operation

From: 10/01/2025 00:00 To: 12/31/2025 23:59 Facility Name: Malburg Generating Station
Generated: 01/12/2026 09:16 Location: Vernon, California



Tag Name: U2_CONormal_Ppmvdc_1H

Total Operating Time: 919.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 1,289.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	919.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

Unit 2 - NOx ppmvdc 1-hour during Normal Operation

From: 10/01/2025 00:00 To: 12/31/2025 23:59 Facility Name: Malburg Generating Station
Generated: 01/12/2026 09:17 Location: Vernon, California



Tag Name: U2_NOxNormal_Ppmvdc_1H

Total Operating Time: 919.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 1,289.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	919.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

Unit 2 - VOC ppmvdc 1-hour during Normal Operation

From: 10/01/2025 00:00 To: 12/31/2025 23:59 Facility Name: Malburg Generating Station
Generated: 01/12/2026 09:17 Location: Vernon, California



Tag Name: U2_VOCNormal_Ppmvdc_1H

Total Operating Time: 919.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 1,289.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	919.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

Unit 2 - CO ppmvdc 3-hour Rolling during Normal Operation

From: 10/01/2025 00:00 To: 12/31/2025 23:59 Facility Name: Malburg Generating Station
Generated: 01/12/2026 09:17 Location: Vernon, California



Tag Name: U2_CO_3HrRoll_Ppmvdc_1H

Total Operating Time: 919.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 1,289.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	919.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Quad K Excess Emissions Report

U2 NOX 4-Hour Events

From: 10/01/2025 00:00 To: 12/31/2025 23:59
Generated: 01/12/2026 09:18

Facility Name: Malburg Generating Station
Location: Vernon, California



Tag Name: U2_NOx4H_Ppmvdc_1H

Total Operating Time: 919.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 1,289.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	919.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Appendix F
MGS RECLAIM Annual Emission
Allocation Information





FACILITY PERMIT TO OPERATE VERNON PUBLIC UTILITIES

SECTION B: RECLAIM ANNUAL EMISSION ALLOCATION

The annual allocation of NOx RECLAIM Trading Credits (RTCs) for this facility is calculated pursuant to Rule 2002. Total NOx emission shall not exceed such annual allocations unless the operator obtains RTCs corresponding to the facility's increased emissions in compliance with Rules 2005 and 2007.

The level of Starting Allocation plus Non-Tradable Credits used to determine compliance with Rule 2005(c)(4) and applicability of Rule 2005(e) - Trading Zone Restrictions is listed on the last page of this Section.

The following table lists the annual allocations that were issued to this facility and the amounts of RTCs held by this facility on the day of printing this Section.

RECLAIM POLLUTANT ANNUAL ALLOCATION (POUNDS)

Year Begin End (month/year)	Zone	NOx RTC Initially Allocated	NOx RTC ¹ Holding as of 07/01/2025 (pounds)	Non-Tradable ² Non-Usable RTCs (pounds)
7/2022 6/2023	Coastal	28480	7859	0
1/2023 12/2023	Coastal	0	15191	0
7/2023 6/2024	Coastal	28480	8668	0
1/2023 12/2023	Inland	0	10367	0
1/2024 12/2024	Coastal	0	35596	0
7/2024 6/2025	Coastal	28480	17597	0
1/2025 12/2025	Coastal	0	35596	0
7/2025 6/2026	Coastal	28480	17597	0
1/2026 12/2026	Coastal	0	15663	0
7/2026 6/2027	Coastal	28480	15663	0
1/2027 12/2027	Coastal	0	15663	0
7/2027 6/2028	Coastal	28480	15663	0
1/2028 12/2028	Coastal	0	15663	0
7/2028 6/2029	Coastal	28480	15663	0
1/2029 12/2029	Coastal	0	15663	0
7/2029 6/2030	Coastal	28480	15663	0
1/2030 12/2030	Coastal	0	15663	0

Footnotes:

1. This number may change due to pending trades, emissions reported under Quarterly Certification of Emissions Report (QCER) and Annual Permit Emission Program (APEP) Report required pursuant to Rule 2004, or deductions made pursuant to Rule 2010(b). The most recent total RTC information can be obtained from the District's RTC Listing.
2. The use of such credits is subject to restrictions set forth in paragraph (f)(1) of Rule 2002.



FACILITY PERMIT TO OPERATE VERNON PUBLIC UTILITIES

SECTION B: RECLAIM ANNUAL EMISSION ALLOCATION

The annual allocation of NOx RECLAIM Trading Credits (RTCs) for this facility is calculated pursuant to Rule 2002. Total NOx emission shall not exceed such annual allocations unless the operator obtains RTCs corresponding to the facility's increased emissions in compliance with Rules 2005 and 2007.

The level of Starting Allocation plus Non-Tradable Credits used to determine compliance with Rule 2005(c)(4) and applicability of Rule 2005(e) - Trading Zone Restrictions is listed on the last page of this Section.

The following table lists the annual allocations that were issued to this facility and the amounts of RTCs held by this facility on the day of printing this Section.

RECLAIM POLLUTANT ANNUAL ALLOCATION (POUNDS)

Year Begin End (month/year)	Zone	NOx RTC Initially Allocated	NOx RTC ¹ Holding as of 07/01/2025 (pounds)	Non-Tradable ² Non-Usable RTCs (pounds)
7/2030 6/2031	Coastal	28480	15663	0
1/2031 12/2031	Coastal	0	15663	0
7/2031 6/2032	Coastal	28480	15663	0
1/2032 12/2032	Coastal	0	15663	0
7/2032 6/2033	Coastal	28480	15663	0
1/2033 12/2033	Coastal	0	15663	0
7/2033 6/2034	Coastal	28480	15663	0
1/2034 12/2034	Coastal	0	15663	0
7/2034 6/2035	Coastal	28480	15663	0
1/2035 12/2035	Coastal	0	15663	0
7/2035 6/2036	Coastal	28480	15663	0
1/2036 12/2036	Coastal	0	15663	0
7/2036 6/2037	Coastal	28480	15663	0
1/2037 12/2037	Coastal	0	15663	0
7/2037 6/2038	Coastal	28480	15663	0
1/2038 12/2038	Coastal	0	15663	0
7/2038 6/2039	Coastal	28480	15663	0

Footnotes:

1. This number may change due to pending trades, emissions reported under Quarterly Certification of Emissions Report (QCER) and Annual Permit Emission Program (APEP) Report required pursuant to Rule 2004, or deductions made pursuant to Rule 2010(b). The most recent total RTC information can be obtained from the District's RTC Listing.
2. The use of such credits is subject to restrictions set forth in paragraph (f)(1) of Rule 2002.



FACILITY PERMIT TO OPERATE VERNON PUBLIC UTILITIES

SECTION B: RECLAIM ANNUAL EMISSION ALLOCATION

The annual allocation of NO_x RECLAIM Trading Credits (RTCs) for this facility is calculated pursuant to Rule 2002. Total NO_x emission shall not exceed such annual allocations unless the operator obtains RTCs corresponding to the facility's increased emissions in compliance with Rules 2005 and 2007.

The level of Starting Allocation plus Non-Tradable Credits used to determine compliance with Rule 2005(c)(4) and applicability of Rule 2005(e) - Trading Zone Restrictions is listed on the last page of this Section.

The following table lists the annual allocations that were issued to this facility and the amounts of RTCs held by this facility on the day of printing this Section.

RECLAIM POLLUTANT ANNUAL ALLOCATION (POUNDS)

Year Begin End (month/year)	Zone	NO _x RTC Initially Allocated	NO _x RTC ¹	Non-Tradable ²
			Holding as of 07/01/2025 (pounds)	Non-Usable RTCs (pounds)
1/2039 12/2039	Coastal	0	15663	0
7/2039 6/2040	Coastal	28480	15663	0
1/2040 12/2040	Coastal	0	15663	0

Footnotes:

1. This number may change due to pending trades, emissions reported under Quarterly Certification of Emissions Report (QCER) and Annual Permit Emission Program (APEP) Report required pursuant to Rule 2004, or deductions made pursuant to Rule 2010(b). The most recent total RTC information can be obtained from the District's RTC Listing.
2. The use of such credits is subject to restrictions set forth in paragraph (f)(1) of Rule 2002.



FACILITY PERMIT TO OPERATE VERNON PUBLIC UTILITIES

SECTION B: RECLAIM ANNUAL EMISSION ALLOCATION

The annual allocation of RECLAIM Trading Credits (RTCs) for this facility is calculated pursuant to Rule 2002. If the facility submits a permit application to increase in an annual allocation to a level greater than the facility's starting Allocation plus Non-Tradable credits as listed below, the application will be evaluated for compliance with Rule 2005 (c)(4). Rule 2005 (e) - Trading Zone Restrictions applies if an annual allocation is increased to a level greater than the facility's Starting Allocation plus Non-Tradable Credits:

Year		Zone	NOx RTC	Non-Tradable
Begin	End		Starting Allocation	Credits(NTC)
(month/year)			(pounds)	(pounds)
7/1994	6/1995	Coastal	296280	7720