

DOCKETED	
Docket Number:	21-TPG-01
Project Title:	Roseville Energy Park Temporary Power Generators
TN #:	268363
Document Title:	RPEAK (REPR-20-03 AND 04) Quarterly CEMS Report - Fourth Quarter 2025 - Part 4s
Description:	N/A
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public Agency
Submission Date:	1/29/2026 1:42:19 PM
Docketed Date:	1/29/2026

III. Emissions Deviations

CO LbPerHr 1-Hour Block Excess Emissions

CT5

From: 10/01/2025 00:00 To: 12/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/01/2026 09:15 Location: Roseville, CA



Tag Name: CT5_CO_Norm_LbPerHr_1H

Total Operating Time: 22.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 2,138.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	22.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO Ppmvdc 1-Hour Block Excess Emissions

CT5

From: 10/01/2025 00:00 To: 12/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/01/2026 09:15 Location: Roseville, CA



Tag Name: CT5_CO_Norm_Ppmvdc_1H

Total Operating Time: 22.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 2,138.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	22.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO Lbs SUSd 1-Hour Block Excess Emissions

CT5

From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/01/2026 09:15 **Location:** Roseville, CA



Tag Name: CT5_CO_SUSD_Lbs_1H

Total Operating Time: 22.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 2,138.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	22.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Startup/Shutdown Event Report

CT5 - CO Lbs Per Startup/Shutdown



From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 01/01/2026 09:15 **Location:** Roseville, CA

Tag Name: CT5_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 15.53 Hours
 Non-Operating Time: 2,144.47 Hours **Report Time:** 2,160.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
10/07/2025 15:55 10/07/2025 16:06 Startup	12	0.54	19.40		
10/07/2025 21:02 10/07/2025 21:09 Shutdown	8	0.12	21.60		
10/09/2025 16:26 10/09/2025 16:40 Startup	15	0.72	19.40		
10/09/2025 20:28 10/09/2025 20:35 Shutdown	8	0.17	21.60		
11/03/2025 16:21 11/03/2025 16:30 Startup	10	0.67	19.40		
11/03/2025 18:28 11/03/2025 18:35 Shutdown	8	0.12	21.60		
11/30/2025 19:29 11/30/2025 19:48 Startup	20	1.06	19.40		
11/30/2025 20:59 11/30/2025 21:06 Shutdown	8	0.17	21.60		
12/12/2025 07:51 12/12/2025 08:01 Startup	11	1.16	19.40		
12/12/2025 09:58 12/12/2025 10:04 Shutdown	7	0.13	21.60		

No excess emissions were found in the reporting period.

Startup/Shutdown Event Report

CT5 - CO Lbs Per Startup/Shutdown



From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 01/01/2026 09:15

Location: Roseville, CA

Tag Name: CT5_CO_LbPerHr_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 15.53 Hours

Non-Operating Time: 2,144.47 Hours

Report Time: 2,160.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Startup/Shutdown Event Report

CT5 - CO Lbs Per Startup/Shutdown



From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 01/01/2026 09:15 **Location:** Roseville, CA

Tag Name: CT5_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 15.53 Hours
 Non-Operating Time: 2,144.47 Hours Report Time: 2,160.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary

1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Heat Input MBtuPerHr 1-Hour Block Excess Emissions



CT5

From: 10/01/2025 00:00 To: 12/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/01/2026 09:15 Location: Roseville, CA

Tag Name: CT5_HI_MBtuPerHr_1H

Total Operating Time: 22.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: -13.00 Hour(s) Report Time: 9.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	22.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NH3 Slip Ppmvdc 1-Hour Block Excess Emissions



CT5

From: 10/01/2025 00:00 To: 12/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/01/2026 09:15 Location: Roseville, CA

Tag Name: CT5_NH3Slip_Ppmvdc_1H

Total Operating Time: 22.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 2.00 Hour(s) Report Time: 24.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	22.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx LbPerHr 1-Hour Block Excess Emissions



CT5

From: 10/01/2025 00:00 To: 12/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/01/2026 09:15 Location: Roseville, CA

Tag Name: CT5_NOx_Norm_LbPerHr_1H

Total Operating Time: 22.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: -12.00 Hour(s) Report Time: 10.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	22.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx Ppmvdc 1-Hour Block Excess Emissions

CT5

From: 10/01/2025 00:00 To: 12/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/01/2026 09:15 Location: Roseville, CA



Tag Name: CT5_NOx_Norm_Ppmvdc_1H

Total Operating Time: 22.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: -12.00 Hour(s) Report Time: 10.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	22.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx Lbs SUSd 1-Hour Block Excess Emissions



CT5

From: 10/01/2025 00:00 To: 12/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/01/2026 09:18 Location: Roseville, CA

Tag Name: CT5_NOx_SUSd_Lbs_1H

Total Operating Time: 22.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 2.00 Hour(s) Report Time: 24.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Tag Value	Limit	Reason Code	Action Code
1	11/30/25 19:00	11/30/25 19:59	1	27.41	6.50	2 - Control equipment problems	3 - RETURN TO NORMAL OPERATIONS

Total Operating Time:	22.00 Hour(s)
Total Duration (Online only):	1.00 Hour(s)
Time in exceedance as a percentage of operating time:	4.55 %
Time in compliance as a percentage of operating time:	95.45 %

Report Code	Type	Text	Duration	Duration Percent
2	Reason	Control equipment problems	1	100.00
3	Action	RETURN TO NORMAL OPERATIONS	1	100.00

Startup/Shutdown Event Report

CT5 - NOx Lbs Per Startup/Shutdown



From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 01/01/2026 09:18 **Location:** Roseville, CA

Tag Name: CT5_NOx_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 15.53 Hours
 Non-Operating Time: 8.47 Hours **Report Time:** 24.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
10/07/2025 15:55 10/07/2025 16:06 Startup	12	1.22	3.10		
10/07/2025 21:02 10/07/2025 21:09 Shutdown	8	0.13	3.40		
10/09/2025 16:26 10/09/2025 16:40 Startup	15	2.43	3.10		
10/09/2025 20:28 10/09/2025 20:35 Shutdown	8	0.15	3.40		
11/03/2025 16:21 11/03/2025 16:30 Startup	10	1.27	3.10		
11/03/2025 18:28 11/03/2025 18:35 Shutdown	8	0.14	3.40		
11/30/2025 19:29 11/30/2025 19:48 Startup	20	27.41 *	3.10		
11/30/2025 20:59 11/30/2025 21:06 Shutdown	8	0.16	3.40		
12/12/2025 07:51 12/12/2025 08:01 Startup	11	1.24	3.10		
12/12/2025 09:58 12/12/2025 10:04 Shutdown	7	0.11	3.40		

Total Duration of Excess Emission	20	Minute(s)
Time of Excess Emission as a percentage of operating time	2.15	%
Time in compliance as percentage of operating time	97.85	%

Startup/Shutdown Event Report

CT5 - NOx Lbs Per Startup/Shutdown



From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 01/01/2026 09:18

Location: Roseville, CA

Tag Name: CT5_NOX_LbPerHr_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 15.53 Hours

Non-Operating Time: 8.47 Hours

Report Time: 24.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Startup/Shutdown Event Report

CT5 - NOx Lbs Per Startup/Shutdown



From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 01/01/2026 09:18 **Location:** Roseville, CA

Tag Name: CT5_NOx_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 15.53 Hours
 Non-Operating Time: 8.47 Hours **Report Time:** 24.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	CMS Performance Summary
<ol style="list-style-type: none"> 1. Duration of excess emission in event reporting period due to: <ol style="list-style-type: none"> a. Startup/shutdown 0 b. Control equipment problems 0 c. Process problems 0 d. Other known causes 0 e. Unknown causes 20 2. Total Duration of Excess Emission in Minute(s) 20 3. Time of Excess Emission as a percentage of operating time 2.15 4. Time in compliance as percentage of operating time 97.85 	<ol style="list-style-type: none"> 1. CMS downtime in event reporting period due to: <ol style="list-style-type: none"> a. Monitor equipment malfunctions 0 b. Non-Monitor equipment malfunctions 0 c. Quality assurance calibration 0 d. Other known causes 0 e. Unknown causes 0 2. Total CMS Downtime in Minute(s) 0 3. Total Downtime as a percentage of operating time 0.00 4. Total Availability as a percentage of operating time 100.00

PM10 LbPerHr 1-Hour Block Excess Emissions

CT5

From: 10/01/2025 00:00 To: 12/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/01/2026 09:18 Location: Roseville, CA



Tag Name: CT5_PM10_LbPerHr_1H

Total Operating Time: 22.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 2,138.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	22.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

S02 LbPerHr 1-Hour Block Excess Emissions



CT5

From: 10/01/2025 00:00 To: 12/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/01/2026 09:20 Location: Roseville, CA

Tag Name: CT5_SO2_P60_LbPerHr_1H

Total Operating Time: 22.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 2,138.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	22.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

VOC LbPerHr 1-Hour Block Excess Emissions



CT5

From: 10/01/2025 00:00 To: 12/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/01/2026 09:20 Location: Roseville, CA

Tag Name: CT5_VOC_Norm_LbPerHr_1H

Total Operating Time: 22.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 2,138.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	22.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

VOC SUSL Lb 1-Hour Block Excess Emissions



CT5

From: 10/01/2025 00:00 To: 12/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/01/2026 09:20 Location: Roseville, CA

Tag Name: CT5_VOC_SUSL_Lbs_1H

Total Operating Time: 22.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 2,138.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	22.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Startup/Shutdown Event Report

CT5 - VOC Lbs Per Startup/Shutdown



From: 10/01/2025 00:00 To: 12/31/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/01/2026 09:20 Location: Roseville, CA

Tag Name: CT5_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 15.53 Hours
 Non-Operating Time: 2,144.47 Hours Report Time: 2,160.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
10/07/2025 15:55 10/07/2025 16:06 Startup	12	0.05	0.80		
10/07/2025 21:02 10/07/2025 21:09 Shutdown	8	0.03	0.90		
10/09/2025 16:26 10/09/2025 16:40 Startup	15	0.08	0.80		
10/09/2025 20:28 10/09/2025 20:35 Shutdown	8	0.03	0.90		
11/03/2025 16:21 11/03/2025 16:30 Startup	10	0.05	0.80		
11/03/2025 18:28 11/03/2025 18:35 Shutdown	8	0.02	0.90		
11/30/2025 19:29 11/30/2025 19:48 Startup	20	0.13	0.80		
11/30/2025 20:59 11/30/2025 21:06 Shutdown	8	0.03	0.90		
12/12/2025 07:51 12/12/2025 08:01 Startup	11	0.05	0.80		
12/12/2025 09:58 12/12/2025 10:04 Shutdown	7	0.02	0.90		

No excess emissions were found in the reporting period.

Startup/Shutdown Event Report

CT5 - VOC Lbs Per Startup/Shutdown



From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 01/01/2026 09:20

Location: Roseville, CA

Tag Name: CT5_VOC_LbPerHr_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 15.53 Hours

Non-Operating Time: 2,144.47 Hours

Report Time: 2,160.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Startup/Shutdown Event Report

CT5 - VOC Lbs Per Startup/Shutdown



From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 01/01/2026 09:20 **Location:** Roseville, CA

Tag Name: CT5_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 15.53 Hours
 Non-Operating Time: 2,144.47 Hours Report Time: 2,160.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	CMS Performance Summary
<ol style="list-style-type: none"> 1. Duration of excess emission in event reporting period due to: <ol style="list-style-type: none"> a. Startup/shutdown 0 b. Control equipment problems 0 c. Process problems 0 d. Other known causes 0 e. Unknown causes 0 2. Total Duration of Excess Emission in Minute(s) 0 3. Time of Excess Emission as a percentage of operating time 0.00 4. Time in compliance as percentage of operating time 100.00 	<ol style="list-style-type: none"> 1. CMS downtime in event reporting period due to: <ol style="list-style-type: none"> a. Monitor equipment malfunctions 0 b. Non-Monitor equipment malfunctions 0 c. Quality assurance calibration 0 d. Other known causes 0 e. Unknown causes 0 2. Total CMS Downtime in Minute(s) 0 3. Total Downtime as a percentage of operating time 0.00 4. Total Availability as a percentage of operating time 100.00

CO LbPerHr 1-Hour Block Excess Emissions

CT6

From: 10/01/2025 00:00 To: 12/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/01/2026 09:30 Location: Roseville, CA



Tag Name: CT6_CO_Norm_LbPerHr_1H

Total Operating Time: 29.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 2,131.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	29.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO Ppmvdc 1-Hour Block Excess Emissions

CT6

From: 10/01/2025 00:00 To: 12/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/01/2026 09:30 Location: Roseville, CA



Tag Name: CT6_CO_Norm_Ppmvdc_1H

Total Operating Time: 29.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 2,131.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	29.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

CO Lbs SUSd 1-Hour Block Excess Emissions

CT6

From: 10/01/2025 00:00 To: 12/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/01/2026 09:30 Location: Roseville, CA



Tag Name: CT6_CO_SUSD_Lbs_1H

Total Operating Time: 29.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 2,131.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	29.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Startup/Shutdown Event Report

CT6 - CO Lbs Per Startup/Shutdown



From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 01/01/2026 09:30 **Location:** Roseville, CA

Tag Name: CT6_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 20.23 Hours
 Non-Operating Time: 2,139.77 Hours **Report Time:** 2,160.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
10/07/2025 14:55 10/07/2025 15:04 Startup	10	0.61	19.40		
10/07/2025 20:02 10/07/2025 20:09 Shutdown	8	0.13	21.60		
10/08/2025 14:55 10/08/2025 15:06 Startup	12	0.61	19.40		
10/08/2025 19:58 10/08/2025 20:05 Shutdown	8	0.13	21.60		
10/09/2025 16:26 10/09/2025 16:39 Startup	14	0.60	19.40		
10/09/2025 20:28 10/09/2025 20:35 Shutdown	8	0.17	21.60		
11/03/2025 16:21 11/03/2025 16:32 Startup	12	0.79	19.40		
11/03/2025 18:28 11/03/2025 18:35 Shutdown	8	0.12	21.60		
11/30/2025 19:37 11/30/2025 19:48 Startup	12	1.02	19.40		
11/30/2025 20:59 11/30/2025 21:06 Shutdown	8	0.21	21.60		
12/12/2025 12:55 12/12/2025 12:55 Startup	1	0.00	19.40		
12/12/2025 13:13 12/12/2025 13:24 Startup	12	1.00	19.40		
12/12/2025 14:58 12/12/2025 15:04 Shutdown	7	0.17	21.60		

Startup/Shutdown Event Report

CT6 - CO Lbs Per Startup/Shutdown



From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 01/01/2026 09:30

Location: Roseville, CA

Tag Name: CT6_CO_LbPerHr_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 20.23 Hours

Non-Operating Time: 2,139.77 Hours Report Time: 2,160.00 Hours

No excess emissions were found in the reporting period.

Startup/Shutdown Event Report

CT6 - CO Lbs Per Startup/Shutdown



From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 01/01/2026 09:30

Location: Roseville, CA

Tag Name: CT6_CO_LbPerHr_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 20.23 Hours

Non-Operating Time: 2,139.77 Hours

Report Time: 2,160.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Startup/Shutdown Event Report

CT6 - CO Lbs Per Startup/Shutdown



From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 01/01/2026 09:30 **Location:** Roseville, CA

Tag Name: CT6_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 20.23 Hours
 Non-Operating Time: 2,139.77 Hours Report Time: 2,160.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary

1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Heat Input MBtuPerHr 1-Hour Block Excess Emissions



CT6

From: 10/01/2025 00:00 To: 12/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/01/2026 09:30 Location: Roseville, CA

Tag Name: CT6_HI_MBtuPerHr_1H

Total Operating Time: 29.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 533.00 Hour(s) Report Time: 562.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	29.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NH3 Slip Ppmvdc 1-Hour Block Excess Emissions



CT6

From: 10/01/2025 00:00 To: 12/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/01/2026 09:32 Location: Roseville, CA

Tag Name: CT6_NH3Slip_Ppmvdc_1H

Total Operating Time: 29.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 2,131.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	29.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx LbPerHr 1-Hour Block Excess Emissions



CT6

From: 10/01/2025 00:00 To: 12/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/01/2026 09:32 Location: Roseville, CA

Tag Name: CT6_NOx_Norm_LbPerHr_1H

Total Operating Time: 29.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: -16.00 Hour(s) Report Time: 13.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	29.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx Ppmvdc 1-Hour Block Excess Emissions



CT6

From: 10/01/2025 00:00 To: 12/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/01/2026 09:32 Location: Roseville, CA

Tag Name: CT6_NOx_Norm_Ppmvdc_1H

Total Operating Time: 29.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: -16.00 Hour(s) Report Time: 13.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	29.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

NOx Lbs SUSd 1-Hour Block Excess Emissions



CT6

From: 10/01/2025 00:00 To: 12/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/01/2026 09:32 Location: Roseville, CA

Tag Name: CT6_NOx_SUSd_Lbs_1H

Total Operating Time: 29.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 2,131.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	29.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Startup/Shutdown Event Report

CT6 - NOx Lbs Per Startup/Shutdown



From: 10/01/2025 00:00 To: 12/31/2025 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 01/01/2026 09:32 Location: Roseville, CA

Tag Name: CT6_NOx_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 20.23 Hours
 Non-Operating Time: 2,139.77 Hours Report Time: 2,160.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
10/07/2025 14:55 10/07/2025 15:04 Startup	10	1.00	3.10		
10/07/2025 20:02 10/07/2025 20:09 Shutdown	8	0.12	3.40		
10/08/2025 14:55 10/08/2025 15:06 Startup	12	1.15	3.10		
10/08/2025 19:58 10/08/2025 20:05 Shutdown	8	0.11	3.40		
10/09/2025 16:26 10/09/2025 16:39 Startup	14	2.08	3.10		
10/09/2025 20:28 10/09/2025 20:35 Shutdown	8	0.14	3.40		
11/03/2025 16:21 11/03/2025 16:32 Startup	12	1.26	3.10		
11/03/2025 18:28 11/03/2025 18:35 Shutdown	8	0.13	3.40		
11/30/2025 19:37 11/30/2025 19:48 Startup	12	1.31	3.10		
11/30/2025 20:59 11/30/2025 21:06 Shutdown	8	0.15	3.40		
12/12/2025 12:55 12/12/2025 12:55 Startup	1	0.00	3.10		
12/12/2025 13:13 12/12/2025 13:24 Startup	12	0.90	3.10		
12/12/2025 14:58 12/12/2025 15:04 Shutdown	7	0.09	3.40		

Startup/Shutdown Event Report

CT6 - NOx Lbs Per Startup/Shutdown



From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 01/01/2026 09:32

Location: Roseville, CA

Tag Name: CT6_NOX_LbPerHr_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 20.23 Hours

Non-Operating Time: 2,139.77 Hours Report Time: 2,160.00 Hours

No excess emissions were found in the reporting period.

Startup/Shutdown Event Report

CT6 - NOx Lbs Per Startup/Shutdown



From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 01/01/2026 09:32

Location: Roseville, CA

Tag Name: CT6_NOX_LbPerHr_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 20.23 Hours

Non-Operating Time: 2,139.77 Hours

Report Time: 2,160.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Startup/Shutdown Event Report

CT6 - NOx Lbs Per Startup/Shutdown



From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 01/01/2026 09:32 **Location:** Roseville, CA

Tag Name: CT6_NOx_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 20.23 Hours
 Non-Operating Time: 2,139.77 Hours Report Time: 2,160.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary

1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

PM10 LbPerHr 1-Hour Block Excess Emissions



CT6

From: 10/01/2025 00:00 To: 12/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/01/2026 09:32 Location: Roseville, CA

Tag Name: CT6_PM10_LbPerHr_1H

Total Operating Time: 29.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 2,131.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	29.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

S02 LbPerHr 1-Hour Block Excess Emissions



CT6

From: 10/01/2025 00:00 To: 12/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/01/2026 09:35 Location: Roseville, CA

Tag Name: CT6_SO2_P60_LbPerHr_1H

Total Operating Time: 29.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 2,131.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	29.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

VOC LbPerHr 1-Hour Block Excess Emissions



CT6

From: 10/01/2025 00:00 To: 12/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/01/2026 09:35 Location: Roseville, CA

Tag Name: CT6_VOC_Norm_LbPerHr_1H

Total Operating Time: 29.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 2,131.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	29.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

VOC SUSL Lb 1-Hour Block Excess Emissions



CT6

From: 10/01/2025 00:00 To: 12/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 01/01/2026 09:35 Location: Roseville, CA

Tag Name: CT6_VOC_SUSL_Lbs_1H

Total Operating Time: 29.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 2,131.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	29.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Startup/Shutdown Event Report

CT6 - VOC Lbs Per Startup/Shutdown



From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 01/01/2026 09:35 **Location:** Roseville, CA

Tag Name: CT6_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 20.23 Hours
 Non-Operating Time: 2,139.77 Hours **Report Time:** 2,160.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
10/07/2025 14:55 10/07/2025 15:04 Startup	10	0.04	0.80		
10/07/2025 20:02 10/07/2025 20:09 Shutdown	8	0.03	0.90		
10/08/2025 14:55 10/08/2025 15:06 Startup	12	0.05	0.80		
10/08/2025 19:58 10/08/2025 20:05 Shutdown	8	0.02	0.90		
10/09/2025 16:26 10/09/2025 16:39 Startup	14	0.07	0.80		
10/09/2025 20:28 10/09/2025 20:35 Shutdown	8	0.03	0.90		
11/03/2025 16:21 11/03/2025 16:32 Startup	12	0.06	0.80		
11/03/2025 18:28 11/03/2025 18:35 Shutdown	8	0.02	0.90		
11/30/2025 19:37 11/30/2025 19:48 Startup	12	0.06	0.80		
11/30/2025 20:59 11/30/2025 21:06 Shutdown	8	0.03	0.90		
12/12/2025 12:55 12/12/2025 12:55 Startup	1	0.00	0.80		
12/12/2025 13:13 12/12/2025 13:24 Startup	12	0.05	0.80		
12/12/2025 14:58 12/12/2025 15:04 Shutdown	7	0.02	0.90		

Startup/Shutdown Event Report

CT6 - VOC Lbs Per Startup/Shutdown



From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 01/01/2026 09:35

Location: Roseville, CA

Tag Name: CT6_VOC_LbPerHr_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 20.23 Hours

Non-Operating Time: 2,139.77 Hours Report Time: 2,160.00 Hours

No excess emissions were found in the reporting period.

Startup/Shutdown Event Report

CT6 - VOC Lbs Per Startup/Shutdown



From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 01/01/2026 09:35

Location: Roseville, CA

Tag Name: CT6_VOC_LbPerHr_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 20.23 Hours

Non-Operating Time: 2,139.77 Hours

Report Time: 2,160.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Startup/Shutdown Event Report

CT6 - VOC Lbs Per Startup/Shutdown



From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 01/01/2026 09:35 **Location:** Roseville, CA

Tag Name: CT6_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 20.23 Hours
 Non-Operating Time: 2,139.77 Hours Report Time: 2,160.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	CMS Performance Summary
<ol style="list-style-type: none"> 1. Duration of excess emission in event reporting period due to: <ol style="list-style-type: none"> a. Startup/shutdown 0 b. Control equipment problems 0 c. Process problems 0 d. Other known causes 0 e. Unknown causes 0 2. Total Duration of Excess Emission in Minute(s) 0 3. Time of Excess Emission as a percentage of operating time 0.00 4. Time in compliance as percentage of operating time 100.00 	<ol style="list-style-type: none"> 1. CMS downtime in event reporting period due to: <ol style="list-style-type: none"> a. Monitor equipment malfunctions 0 b. Non-Monitor equipment malfunctions 0 c. Quality assurance calibration 0 d. Other known causes 0 e. Unknown causes 0 2. Total CMS Downtime in Minute(s) 0 3. Total Downtime as a percentage of operating time 0.00 4. Total Availability as a percentage of operating time 100.00

CO Invalid Data

CT5

From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/01/2026 09:40 **Location:** Roseville, CA



Tag Name: CT5_CO_Ppm_1H

Total Operating Time: 22.00 Hour(s)

Non-Operating Time: 2,138.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	22.00 Hour(s)
Total Monitor Downtime (Online only):	0.00 Hour(s)
Percent Monitor Availability:	100.00 %
Percent Monitor Downtime:	0.00 %

NOx Invalid Data



CT5

From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/01/2026 09:40 **Location:** Roseville, CA

Tag Name: CT5_NOx_Ppm_1H

Total Operating Time: 22.00 Hour(s)

Non-Operating Time: 2,138.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	22.00 Hour(s)
Total Monitor Downtime (Online only):	0.00 Hour(s)
Percent Monitor Availability:	100.00 %
Percent Monitor Downtime:	0.00 %

NOx SCR Invalid Data



CT5

From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/01/2026 09:40 **Location:** Roseville, CA

Tag Name: CT5_NOx_SCR_Ppm_1H

Total Operating Time: 22.00 Hour(s)

Non-Operating Time: 2,138.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	22.00 Hour(s)
Total Monitor Downtime (Online only):	0.00 Hour(s)
Percent Monitor Availability:	100.00 %
Percent Monitor Downtime:	0.00 %

O2 Invalid Data

CT5

From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/01/2026 09:40 **Location:** Roseville, CA



Tag Name: CT5_O2Dry_Pct_1H

Total Operating Time: 22.00 Hour(s)

Non-Operating Time: 2,138.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	22.00 Hour(s)
Total Monitor Downtime (Online only):	0.00 Hour(s)
Percent Monitor Availability:	100.00 %
Percent Monitor Downtime:	0.00 %

CO Invalid Data

CT6

From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/01/2026 09:45 **Location:** Roseville, CA



Tag Name: CT6_CO_Ppm_1H

Total Operating Time: 29.00 Hour(s)

Non-Operating Time: 2,131.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	29.00 Hour(s)
Total Monitor Downtime (Online only):	0.00 Hour(s)
Percent Monitor Availability:	100.00 %
Percent Monitor Downtime:	0.00 %

NOx Invalid Data

CT6

From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/01/2026 09:45 **Location:** Roseville, CA



Tag Name: CT6_NOx_Ppm_1H

Total Operating Time: 29.00 Hour(s)

Non-Operating Time: 2,131.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	29.00 Hour(s)
Total Monitor Downtime (Online only):	0.00 Hour(s)
Percent Monitor Availability:	100.00 %
Percent Monitor Downtime:	0.00 %

NOx SCR Invalid Data



CT6

From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/01/2026 09:45 **Location:** Roseville, CA

Tag Name: CT6_NOx_SCR_Ppm_1H

Total Operating Time: 29.00 Hour(s)

Non-Operating Time: 2,131.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	29.00 Hour(s)
Total Monitor Downtime (Online only):	0.00 Hour(s)
Percent Monitor Availability:	100.00 %
Percent Monitor Downtime:	0.00 %

O2 Invalid Data

CT6

From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/01/2026 09:45 **Location:** Roseville, CA



Tag Name: CT6_O2Dry_Pct_1H

Total Operating Time: 29.00 Hour(s)

Non-Operating Time: 2,131.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	29.00 Hour(s)
Total Monitor Downtime (Online only):	0.00 Hour(s)
Percent Monitor Availability:	100.00 %
Percent Monitor Downtime:	0.00 %

CO Ppmvdc EDS/CMS Summary Report



CT5

From: 10/01/2025 00:00 To: 12/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/01/2026 09:50 Location: Roseville, CA
 Description: Electric Utility

CMS Data from: CT5_CO_Norm_Ppmvdc_1H, CT5_UnitOn_TF_1H
 EDS Data from: CT5_CO_Norm_Ppmvdc_1H, CT5_UnitOn_TF_1H
 Emission Limitation: 4.0
 No Value Exclusions Allowed
 Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, T300
 Date of Latest CMS Certification or Audit: 04/01/2024 00:00
 Process Unit(s) Description:
 Operating time for EDS: 22.00 Hour(s)
 Operating time for CMS: 22.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	0
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	0
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	4
2. Total CMS Downtime	4
3. Total Downtime as a percentage of operating time	18.18
4. Total Availability as a percentage of operating time	81.82

CO Lb/Hr EDS/CMS Summary Report

CT5

From: 10/01/2025 00:00 To: 12/31/2025 23:59
 Generated: 01/01/2026 09:50

Facility Name: ROSEVILLE ENERGY
 Location: Roseville, CA
 Description: Electric Utility



CMS Data from: CT5_CO_Norm_LbPerHr_1H, CT5_UnitOn_TF_1H
 EDS Data from: CT5_CO_Norm_LbPerHr_1H, CT5_UnitOn_TF_1H
 Emission Limitation: 2.64
 No Value Exclusions Allowed
 Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, T300
 Date of Latest CMS Certification or Audit: 04/01/2024 00:00
 Process Unit(s) Description:
 Operating time for EDS: 22.00 Hour(s)
 Operating time for CMS: 22.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	4
2. Total CMS Downtime	4
3. Total Downtime as a percentage of operating time	18.18
4. Total Availability as a percentage of operating time	81.82

CO SUSD Lb/Hr EDS/CMS Summary Report



CT5

From: 10/01/2025 00:00 To: 12/31/2025 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 01/01/2026 09:50 Location: Roseville, CA
 Description: Electric Utility

CMS Data from: CT5_CO_SUSD_Lbs_1H, CT5_UnitOn_TF_1H
 EDS Data from: CT5_CO_SUSD_Lbs_1H, CT5_UnitOn_TF_1H
 Emission Limitation: 41.00
 No Value Exclusions Allowed
 Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, T300
 Date of Latest CMS Certification or Audit: 04/01/2024 00:00
 Process Unit(s) Description:
 Operating time for EDS: 22.00 Hour(s)
 Operating time for CMS: 22.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	0
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	0
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	3
2. Total CMS Downtime	3
3. Total Downtime as a percentage of operating time	13.64
4. Total Availability as a percentage of operating time	86.36

NOx Ppmvdc EDS/CMS Summary Report



CT5

From: 10/01/2025 00:00 To: 12/31/2025 23:59
 Generated: 01/01/2026 09:50

Facility Name: ROSEVILLE ENERGY
 Location: Roseville, CA
 Description: Electric Utility

CMS Data from: CT5_NOx_Norm_Ppmvdc_1H, CT5_UnitOn_TF_1H
 EDS Data from: CT5_NOx_Norm_Ppmvdc_1H, CT5_UnitOn_TF_1H
 Emission Limitation: 2.5
 No Value Exclusions Allowed
 Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, T200H
 Date of Latest CMS Certification or Audit: 04/01/2024 00:00
 Process Unit(s) Description:
 Operating time for EDS: 22.00 Hour(s)
 Operating time for CMS: 22.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	0
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	0
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	4
2. Total CMS Downtime	4
3. Total Downtime as a percentage of operating time	18.18
4. Total Availability as a percentage of operating time	81.82

NOx Lb/Hr EDS/CMS Summary Report



CT5

From: 10/01/2025 00:00 To: 12/31/2025 23:59
 Generated: 01/01/2026 09:50

Facility Name: ROSEVILLE ENERGY
 Location: Roseville, CA
 Description: Electric Utility

CMS Data from: CT5_NOx_Norm_LbPerHr_1H, CT5_UnitOn_TF_1H
 EDS Data from: CT5_NOx_Norm_LbPerHr_1H, CT5_UnitOn_TF_1H
 Emission Limitation: 2.71
 No Value Exclusions Allowed
 Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, T200H
 Date of Latest CMS Certification or Audit: 04/01/2024 00:00
 Process Unit(s) Description:
 Operating time for EDS: 22.00 Hour(s)
 Operating time for CMS: 22.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	0
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	0
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	4
2. Total CMS Downtime	4
3. Total Downtime as a percentage of operating time	18.18
4. Total Availability as a percentage of operating time	81.82

NOx SUSD Lb/Hr EDS/CMS Summary Report



CT5

From: 10/01/2025 00:00 To: 12/31/2025 23:59
 Generated: 01/01/2026 09:50

Facility Name: ROSEVILLE ENERGY
 Location: Roseville, CA
 Description: Electric Utility

CMS Data from: CT5_NOx_SUSD_Lbs_1H, CT5_UnitOn_TF_1H
 EDS Data from: CT5_NOx_SUSD_Lbs_1H, CT5_UnitOn_TF_1H
 Emission Limitation: 6.50
 No Value Exclusions Allowed
 Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, T200H
 Date of Latest CMS Certification or Audit: 04/01/2024 00:00
 Process Unit(s) Description:
 Operating time for EDS: 22.00 Hour(s)
 Operating time for CMS: 22.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	1
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	1
4. Time of Excess Emission as a percentage of operating time	4.55
5. Time in compliance as percentage of operating time	95.45

CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	3
2. Total CMS Downtime	3
3. Total Downtime as a percentage of operating time	13.64
4. Total Availability as a percentage of operating time	86.36

CO Ppmvdc EDS/CMS Summary Report



CT6

From: 10/01/2025 00:00 To: 12/31/2025 23:59
 Generated: 01/01/2026 09:50

Facility Name: ROSEVILLE ENERGY
 Location: Roseville, CA
 Description: Electric Utility

CMS Data from: CT6_CO_Norm_Ppmvdc_1H, CT6_UnitOn_TF_1H
 EDS Data from: CT6_CO_Norm_Ppmvdc_1H, CT6_UnitOn_TF_1H
 Emission Limitation: 4.0
 No Value Exclusions Allowed
 Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, T300
 Date of Latest CMS Certification or Audit: 04/01/2024 00:00
 Process Unit(s) Description:
 Operating time for EDS: 29.00 Hour(s)
 Operating time for CMS: 29.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	0
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	0
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	6
2. Total CMS Downtime	6
3. Total Downtime as a percentage of operating time	20.69
4. Total Availability as a percentage of operating time	79.31

CO Lb/Hr EDS/CMS Summary Report

CT6



From: 10/01/2025 00:00 To: 12/31/2025 23:59
 Generated: 01/01/2026 09:50

Facility Name: ROSEVILLE ENERGY
 Location: Roseville, CA
 Description: Electric Utility

CMS Data from: CT6_CO_Norm_LbPerHr_1H, CT6_UnitOn_TF_1H
 EDS Data from: CT6_CO_Norm_LbPerHr_1H, CT6_UnitOn_TF_1H
 Emission Limitation: 2.64
 No Value Exclusions Allowed
 Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, T300
 Date of Latest CMS Certification or Audit: 04/01/2024 00:00
 Process Unit(s) Description:
 Operating time for EDS: 29.00 Hour(s)
 Operating time for CMS: 29.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	0
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	0
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	6
2. Total CMS Downtime	6
3. Total Downtime as a percentage of operating time	20.69
4. Total Availability as a percentage of operating time	79.31

CO SUSD Lb/Hr EDS/CMS Summary Report



CT6

From: 10/01/2025 00:00 **To:** 12/31/2025 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 01/01/2026 09:50 **Location:** Roseville, CA
Description: Electric Utility

CMS Data from: CT6_CO_SUSD_Lbs_1H, CT6_UnitOn_TF_1H
EDS Data from: CT6_CO_SUSD_Lbs_1H, CT6_UnitOn_TF_1H
Emission Limitation: 41.00
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, T300
Date of Latest CMS Certification or Audit: 04/01/2024 00:00
Process Unit(s) Description:
Operating time for EDS: 29.00 Hour(s)
Operating time for CMS: 29.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	0
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	0
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	4
2. Total CMS Downtime	4
3. Total Downtime as a percentage of operating time	13.79
4. Total Availability as a percentage of operating time	86.21

NOx Ppmvdc EDS/CMS Summary Report



CT6

From: 10/01/2025 00:00 To: 12/31/2025 23:59
 Generated: 01/01/2026 09:50

Facility Name: ROSEVILLE ENERGY
 Location: Roseville, CA
 Description: Electric Utility

CMS Data from: CT6_NOx_Norm_Ppmvdc_1H, CT6_UnitOn_TF_1H
 EDS Data from: CT6_NOx_Norm_Ppmvdc_1H, CT6_UnitOn_TF_1H
 Emission Limitation: 2.5
 No Value Exclusions Allowed
 Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, T200H
 Date of Latest CMS Certification or Audit: 04/01/2024 00:00
 Process Unit(s) Description:
 Operating time for EDS: 29.00 Hour(s)
 Operating time for CMS: 29.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	0
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	0
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	6
2. Total CMS Downtime	6
3. Total Downtime as a percentage of operating time	20.69
4. Total Availability as a percentage of operating time	79.31

NOx Lb/Hr EDS/CMS Summary Report



CT6

From: 10/01/2025 00:00 To: 12/31/2025 23:59
 Generated: 01/01/2026 09:50

Facility Name: ROSEVILLE ENERGY
 Location: Roseville, CA
 Description: Electric Utility

CMS Data from: CT6_NOx_Norm_LbPerHr_1H, CT6_UnitOn_TF_1H
 EDS Data from: CT6_NOx_Norm_LbPerHr_1H, CT6_UnitOn_TF_1H
 Emission Limitation: 2.71
 No Value Exclusions Allowed
 Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, T200H
 Date of Latest CMS Certification or Audit: 04/01/2024 00:00
 Process Unit(s) Description:
 Operating time for EDS: 29.00 Hour(s)
 Operating time for CMS: 29.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	0
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	0
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	6
2. Total CMS Downtime	6
3. Total Downtime as a percentage of operating time	20.69
4. Total Availability as a percentage of operating time	79.31

NOx SUSD Lb/Hr EDS/CMS Summary Report



CT6

From: 10/01/2025 00:00 To: 12/31/2025 23:59
 Generated: 01/01/2026 09:50

Facility Name: ROSEVILLE ENERGY
 Location: Roseville, CA
 Description: Electric Utility

CMS Data from: CT6_NOx_SUSD_Lbs_1H, CT6_UnitOn_TF_1H
 EDS Data from: CT6_NOx_SUSD_Lbs_1H, CT6_UnitOn_TF_1H
 Emission Limitation: 6.50
 No Value Exclusions Allowed
 Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, T200H
 Date of Latest CMS Certification or Audit: 04/01/2024 00:00
 Process Unit(s) Description:
 Operating time for EDS: 29.00 Hour(s)
 Operating time for CMS: 29.00 Hour(s)

Emission Data Summary

1. Duration of excess emission in reporting period due to:	0
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in reporting period due to:	0
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	4
2. Total CMS Downtime	4
3. Total Downtime as a percentage of operating time	13.79
4. Total Availability as a percentage of operating time	86.21

Cylinder Gas Audit

01/05/2026

Page 1

Facility: ROSEVILLE ENERGY

Unit/Stack: CT5

Parameter/Scale: CO / High

Test Date: 11/18/2025

Test Result: **Pass**

Instrument Name: CT5_CODualRg_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
11/18/2025	07:55	L	1000	245.400	254.700	24.5 %
11/18/2025	08:00	M	1000	559.500	548.400	56.0 %
11/18/2025	08:07	L	1000	245.400	254.700	24.5 %
11/18/2025	08:12	M	1000	559.500	550.600	56.0 %
11/18/2025	08:19	L	1000	245.400	254.900	24.5 %
11/18/2025	08:24	M	1000	559.500	550.200	56.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	245.400	254.767	Std	3.8
M	559.500	549.733	Std	1.7

Cylinder Gas Audit

01/05/2026

Page 2

Facility:	ROSEVILLE ENERGY	Instrument Name:	CT6_CODualRg_P_Instrum
Unit/Stack:	CT6	Test Date:	11/18/2025
Parameter/Scale:	CO / High	Test Result:	Pass
		Performance Spec:	15 Pct
		Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
11/18/2025	08:25	L	1000	250.000	254.400	25.0 %
11/18/2025	08:30	M	1000	571.000	579.100	57.1 %
11/18/2025	08:37	L	1000	250.000	254.300	25.0 %
11/18/2025	08:42	M	1000	571.000	578.300	57.1 %
11/18/2025	08:49	L	1000	250.000	255.400	25.0 %
11/18/2025	08:54	M	1000	571.000	576.500	57.1 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	250.000	254.700	Std	1.9
M	571.000	577.967	Std	1.2

Cylinder Gas Audit

01/05/2026

Page 3

Facility: ROSEVILLE ENERGY

Instrument Name: CT5_CODualRg_P_Instrum

Unit/Stack: CT5

Test Date: 11/18/2025

Performance Spec: 15 Pct

Parameter/Scale: CO / Low

Test Result: **Pass**

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
11/18/2025	13:22	L	20	5.100	5.000	25.5 %
11/18/2025	13:27	M	20	11.100	11.000	55.5 %
11/18/2025	13:39	L	20	5.100	5.000	25.5 %
11/18/2025	13:44	M	20	11.100	11.000	55.5 %
11/18/2025	13:56	L	20	5.100	5.000	25.5 %
11/18/2025	14:01	M	20	11.100	11.000	55.5 %

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Specification Used	Results
L	5.100		5.000	Std	2.0
M	11.100		11.000	Std	0.9

Cylinder Gas Audit

01/05/2026

Page 4

Facility: ROSEVILLE ENERGY

Instrument Name: CT6_CODualRg_P_Instrum

Unit/Stack: CT6

Test Date: 11/18/2025

Performance Spec: 15 Pct

Parameter/Scale: CO / Low

Test Result: **Pass**

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
11/18/2025	12:55	L	20	5.000	5.400	25.0 %
11/18/2025	13:00	M	20	11.200	11.500	56.0 %
11/18/2025	13:12	L	20	5.000	5.400	25.0 %
11/18/2025	13:17	M	20	11.200	11.500	56.0 %
11/18/2025	13:29	L	20	5.000	5.400	25.0 %
11/18/2025	13:34	M	20	11.200	11.600	56.0 %

Summary Statistics:

Cal Gas Level	Reference	Mean	CEMS Mean	Specification Used	Results
L	5.000		5.400	Std	8.0
M	11.200		11.533	Std	3.0

No linearity tests were performed on CT5 and CT6 during Q4 2025 due to the units running under 168 hours during the reporting quarter. Last completed linearity Q3 2025.