

DOCKETED

Docket Number:	02-AFC-03C
Project Title:	Donald Von Raesfeld-Compliance (Formerly Pico Power)
TN #:	268442
Document Title:	Section XII - Unit 2 - second half of report (file 6 of 6)
Description:	Section XII - Unit 2 - second half of report (file 6 of 6)
Filer:	Melissa Meslo
Organization:	City of Santa Clara dba Silicon Valley Power
Submitter Role:	Public Agency
Submission Date:	2/2/2026 12:37:54 PM
Docketed Date:	2/2/2026

Annual Compliance Report for Year 2025

Section XII

AQ-39 The Owner/Operator shall contact the BAAQMD Technical Services Division regarding requirements for the continuous emission monitors, sampling ports, platforms, and source tests required by Conditions AQ-27, AQ-30, AQ-31, AQ-32, AQ-33, AQ-38, and AQ-45. All source testing and monitoring shall be conducted in accordance with the BAAQMD Manual of Procedures. (Regulation 1-501).

Verification: The project Owner/Operator shall submit documentation of compliance with this Condition of Certification as part of the Quarterly Air Quality Report required by the verification of Condition AQ-34.

(Double click the Icon to open the data)

2025 Source Test and RATA



Unit 2 (second half
of report).pdf