

DOCKETED

Docket Number:	25-BSTD-03
Project Title:	2028 Energy Code Pre-Rulemaking.
TN #:	269262
Document Title:	Joe Sanchez Comments - adiabatic gas coolers not only opportunity for efficiency
Description:	N/A
Filer:	System
Organization:	Joe Sanchez
Submitter Role:	Public
Submission Date:	3/20/2026 10:29:10 AM
Docketed Date:	3/20/2026

Comment Received From: Joe Sanchez
Submitted On: 3/20/2026
Docket Number: 25-BSTD-03

adiabatic gas coolers not only opportunity for efficiency

CO₂ is a really unique refrigerant in that its high pressure creates many opportunities for efficiency gains in comparison to other refrigerant architectures. While Adiabatic gas coolers are great for improving efficiency, it also limits the adoption of this low gwp solution.

the standard should consider and allow other opportunities in lieu of gas cooler.. such as using parallel compression, ejectors and using heat exchangers on the discharge of the gas cooler. All of these technologies are already being implemented globally.. especially in hot climates.