

**DOCKETED**

<b>Docket Number:</b>	24-BSTD-05
<b>Project Title:</b>	2025 Energy Code Compliance Initiatives
<b>TN #:</b>	269408
<b>Document Title:</b>	Re Ducts In Conditioned Space
<b>Description:</b>	N/A
<b>Filer:</b>	System
<b>Organization:</b>	Avery Ray Colter
<b>Submitter Role:</b>	Other Interested Person
<b>Submission Date:</b>	4/3/2026 2:39:32 PM
<b>Docketed Date:</b>	4/3/2026

*Comment Received From: Avery Ray Colter*  
*Submitted On: 4/3/2026*  
*Docket Number: 24-BSTD-05*

## **Re Ducts In Conditioned Space**

Mike's comment is of interest to me, as I have tended to take the inclusive tack on this: I consider ducts in indirectly-conditioned space eligible for the setting, especially as this is the only way I know to prevent the calculation engine from choking on an HVAC duct not having sufficient roof above it. Drop soffits and joists with conditioned spaces above and below get the ducts in conditioned space setting by this logic.