

**DOCKETED**

<b>Docket Number:</b>	25-BSTD-03
<b>Project Title:</b>	2028 Energy Code Pre-Rulemaking.
<b>TN #:</b>	269498
<b>Document Title:</b>	SubZero Constructors, Inc. Comments - Proposed Code Change 120_6(a)3D & Table 120_6-A-2
<b>Description:</b>	N/A
<b>Filer:</b>	System
<b>Organization:</b>	SubZero Constructors, Inc.
<b>Submitter Role:</b>	Public
<b>Submission Date:</b>	4/15/2026 4:19:03 PM
<b>Docketed Date:</b>	4/15/2026

*Comment Received From: SubZero Constructors, Inc.*  
*Submitted On: 4/15/2026*  
*Docket Number: 25-BSTD-03*

## **Proposed Code Change 120\_6(a)3D & Table 120\_6-A-2**

Only one manufacturer certifies RWH evaporator coils according to AHRI 420. Adherence to this requirement severely limits stakeholders'™ ability to build in CA competitively. CEC should change the rule to either a) state a single rating condition similar to that for fan-powered condensers, b) state several rating conditions similar to those in Table 1 of AHRI 420, and clearly define that testing and certification are NOT required.