

DOCKETED

Docket Number:	26-SPPE-01
Project Title:	RB Inyokern Data Center (RBIDC)
TN #:	269655
Document Title:	Request Full Water Impact Review
Description:	N/A
Filer:	System
Organization:	Jennifer M Slayton
Submitter Role:	Public
Submission Date:	4/28/2026 9:16:48 AM
Docketed Date:	4/28/2026

Comment Received From: Jennifer M Slayton
Submitted On: 4/28/2026
Docket Number: 26-SPPE-01

Request Full Water Impact Review

I am a resident of Ridgecrest and the Indian Wells Valley. I am writing to express extreme concern about the proposed RB Inyokern Data Center currently under review under CEC Docket 26-SPPE-01.

The Indian Wells Valley groundwater basin is formally designated as critically overdrafted. Current pumping is 20,840 acre-feet per year against the reported sustainable yield of only 7,650. A facility of this size, using evaporative cooling in desert conditions, can consume roughly 500,000 gallons of water per day – close to 8 percent of the basin's entire sustainable annual yield, used by a single facility every day.

This basin has no surface water. No river. No backup. The aquifer is the only source of water for 38,000 residents and Naval Air Weapons Station China Lake. Phase 2 of the water rights adjudication goes to trial June 1, 2026. The pipeline currently proposed to address this project has no appropriated funding or complete design, is considered by many to be unfeasible and depends on a State Water Project that delivered only 5% of contracted water in 2022 and sits at 30% for 2026. There is no margin for new large-scale groundwater demand at this time.

I respectfully request a full environmental review with specific attention to water supply impacts, and that any approval require demonstrated water-neutral or dry cooling technology before construction begins.

I am also requesting to be noticed on any new documents posted or actions taken related to this application.

Flat out - under any scenario, we don't have the water for this!
Jennifer Slayton
Ridgecrest and Indian Wells Valley Resident