

DOCKETED	
Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	269698
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q1 2026 - Part 3s
Description:	N/A
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public Agency
Submission Date:	4/29/2026 9:55:04 AM
Docketed Date:	4/29/2026

AQ-51

AQ-51 The ammonia slip shall not exceed 10 ppmv @ 15% O₂ averaged over one hour. The SCR catalyst shall be replaced, repaired or otherwise reconditioned within 24 months of the ammonia slip reaching 7 ppm @ 15% O₂ averaged over 24 hours. The SCR ammonia injection grid replacement, repair or reconditioning scheduled event may be cancelled if the Project owner can demonstrate to the CPM that, subsequent to the initial exceedance, the ammonia slip consistently remains below 7 ppm @ 15% O₂ averaged over 24 hours and that the initial exceedance does not accurately indicate expected future operating conditions.

Compliance with ammonia slip limits shall be demonstrated by using the following calculation procedure:

$$\text{Ammonia slip ppmv @ 15\% O}_2 = ((a - (b \times c / 1,000,000)) \times 1,000,000 / b) \times d,$$

Where

a = ammonia injection rate (lb/hr)/17(lb/lb mol)

b = dry exhaust gas flow rate (lb/hr)/ (29(lb/lb mol)

c = change in measured NOX conc. Ppmv @ 15% O₂ across catalyst, and

d = correction factor

The correction factor shall be derived annually during compliance testing by comparing the measured and calculated ammonia slip.

Verification: The Project owner shall include the ammonia slip concentrations averaged on an hourly and 24 hour basis calculated via the protocol provided as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6. The Project owner shall notify the CPM within 10 days of an exceedance of the 7 ppm ammonia slip limit herein. The Project owner shall notify the CPM no less than 30 days prior to the scheduled date of the SCR catalyst replacement, repair or reconditioning event. If the Project owner finds that the exceedance of the 7 ppm slip limit does not accurately reflect the expected future operations provided for in this condition, the Project owner shall submit all relevant information to the CPM no less than 30 days prior to the scheduled date of the SCR catalyst replacement, repair or reconditioning event in order to cancel the event.

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/01/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/02/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/03/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/04/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/05/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/06/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/07/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 **To:** 03/31/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/08/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/09/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/10/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/11/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/12/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/13/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/14/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/15/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/16/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/17/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/18/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/19/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/20/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/21/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/22/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/23/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/24/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/25/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/26/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/27/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/28/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/29/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/30/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/31/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/01/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1 NH3Slip, Ppmvdc	Unit CT1 NOx, Ppm	Unit CT1 NOx, _SCR, Ppm	Unit CT1 O2, Dry, Pct	Unit CT1 NH3Inj, LbPerHr	Unit CT1 ExhaustFlow, LbPerHr	Unit CT1 SUSD, Hr	Unit CT1 OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/02/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/03/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/04/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/05/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/06/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/07/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/08/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/09/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 **To:** 03/31/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/10/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/11/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/12/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/13/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/14/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/15/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/16/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/17/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/18/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/19/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/20/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/21/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/22/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/23/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/24/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/25/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/26/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/27/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/28/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/01/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/02/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/03/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/04/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/05/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/06/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/07/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/08/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/09/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/10/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/11/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2026 06:00	0	12.9	14.5	18.9	0.0	716,209.0	0.25	0.25
03/11/2026 07:00	2	15.0	21.6	15.1	12.0	845,265.4	0.93	1.00
03/11/2026 08:00	1	1.7	9.9	14.3	21.2	912,119.6	0.00	1.00
03/11/2026 09:00	1	1.7	8.4	14.2	13.6	724,364.2	0.00	1.00
03/11/2026 10:00	1	1.7	8.4	14.2	10.8	683,281.5	0.03	0.13
03/11/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	1	6.6	12.6	15.3	11.5	776,247.9	1.21 #	3.38 #
Minimum:	1	1.7	8.4	14.2	0.0	683,281.5	0.00	0.00
Maximum:	2	15.0	21.6	18.9	21.2	912,119.6	0.93	1.00
%SI	83.33	79.17	79.17	79.17	79.17	79.17	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/12/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/13/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2026 15:00	0	23.3	26.5	18.1	0.0	768,834.0	0.25	0.25
03/13/2026 16:00	1	4.1	9.7	14.5	13.4	960,522.8	0.85	1.00
03/13/2026 17:00	1	1.6	9.1	14.5	21.9	979,994.3	0.00	1.00
03/13/2026 18:00	1	1.6	8.9	14.5	21.4	979,780.4	0.00	1.00
03/13/2026 19:00	1	1.7	8.8	14.4	18.8	957,122.3	0.12	1.00
03/13/2026 20:00	0	10.0	23.9	15.5	0.0	549,037.7	0.15	0.15
03/13/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	1	7.1	14.5	15.3	12.6	865,881.9	1.37 #	4.40 #
Minimum:	1	1.6	8.8	14.4	0.0	549,037.7	0.00	0.00
Maximum:	1	23.3	26.5	18.1	21.9	979,994.3	0.85	1.00
%SI	83.33	75.00	75.00	75.00	75.00	75.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/14/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/15/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2026 10:00	0	17.5	19.7	18.5	0.0	755,465.8	0.25	0.25
03/15/2026 11:00	1	6.9	12.5	14.5	14.7	955,815.4	0.87	1.00
03/15/2026 12:00	1	1.6	9.4	14.5	23.4	978,710.5	0.00	1.00
03/15/2026 13:00	1	1.6	9.1	14.5	23.4	966,086.1	0.00	1.00
03/15/2026 14:00	1	1.8	9.0	14.5	18.7	930,566.7	0.17	1.00
03/15/2026 15:00	0	13.4	30.9	16.1	0.0	499,839.9	0.12	0.12
03/15/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	1	7.1	15.1	15.4	13.4	847,747.4	1.41 #	4.37 #
Minimum:	1	1.6	9.0	14.5	0.0	499,839.9	0.00	0.00
Maximum:	1	17.5	30.9	18.5	23.4	978,710.5	0.87	1.00
%SI	83.33	75.00	75.00	75.00	75.00	75.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/16/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/17/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/18/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/19/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/20/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/21/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/22/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/23/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/24/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/25/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/26/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/27/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/28/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/29/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/30/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/31/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/01/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/01/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/02/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/02/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/03/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/03/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/04/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/04/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/05/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/05/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/06/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/06/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/07/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/07/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/08/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/08/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/09/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/09/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/10/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/10/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/11/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/11/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/12/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/12/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/13/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/13/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/14/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/14/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/15/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/15/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/16/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/16/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/17/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/17/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/18/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/18/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/19/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/19/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/20/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/20/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/21/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/21/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/22/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/22/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/23/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/23/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/24/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/24/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/25/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/25/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/26/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/26/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/27/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/27/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/28/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/28/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/29/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/29/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/30/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/30/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/31/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
01/31/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/01/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/01/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/02/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/02/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/03/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/03/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/04/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/04/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/05/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/05/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/06/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/06/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/07/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/07/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/08/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/08/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/09/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/09/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/10/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/10/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/11/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/11/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/12/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/12/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/13/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/13/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/14/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/14/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/15/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/15/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/16/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/16/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/17/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/17/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/18/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/18/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/19/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/19/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/20/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/20/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/21/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/21/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/22/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/22/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/23/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/23/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/24/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/24/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/25/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/25/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/26/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/26/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/27/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/27/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/28/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
02/28/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/01/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/01/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/02/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/02/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/03/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/03/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/04/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/04/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/05/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/05/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/06/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/06/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/07/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/07/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/08/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/08/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/09/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/09/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/10/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/10/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/11/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2026 12:00	0	20.0	22.7	18.3	0.0	773,724.8	0.27	0.27
03/11/2026 13:00	0	6.0	9.6	14.5	5.2	1,005,885.0	1.00	1.00
03/11/2026 14:00	-2	1.6	8.6	14.5	7.4	1,024,286.6	0.00	1.00
03/11/2026 15:00	-2	1.6	8.6	14.6	7.2	1,027,720.4	0.07	0.97
03/11/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/11/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	-2	7.3	12.4	15.5	5.0	957,904.2	1.34 #	3.24 #
Minimum:	-2	1.6	8.6	14.5	0.0	773,724.8	0.00	0.00
Maximum:	-2	20.0	22.7	18.3	7.4	1,027,720.4	1.00	1.00
%SI	91.67	83.33	83.33	83.33	83.33	83.33	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/12/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2026 06:00	0	13.0	15.9	18.9	0.0	734,696.2	0.20	0.20
03/12/2026 07:00	-3	6.4	11.8	14.4	5.3	970,184.5	0.88	1.00
03/12/2026 08:00	3	0.8	8.9	14.3	14.0	992,210.2	0.00	1.00
03/12/2026 09:00	-2	1.7	8.6	14.4	5.0	1,007,685.7	0.00	1.00
03/12/2026 10:00	-2	1.7	8.3	14.4	5.3	1,003,893.4	0.07	1.00
03/12/2026 11:00	0	15.6	24.0	15.5	0.0	633,232.0	0.20	0.20
03/12/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/12/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	-1	6.5	12.9	15.3	4.9	890,317.0	1.35 #	4.40 #
Minimum:	-3	0.8	8.3	14.3	0.0	633,232.0	0.00	0.00
Maximum:	3	15.6	24.0	18.9	14.0	1,007,685.7	0.88	1.00
%SI	83.33	75.00	75.00	75.00	75.00	75.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/13/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/13/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/14/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/14/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/15/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/15/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/16/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/16/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/17/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2026 10:00	0	17.1	21.4	18.0	0.0	736,655.9	0.27	0.27
03/17/2026 11:00	-1	5.7	9.3	14.2	3.8	808,573.6	0.85	1.00
03/17/2026 12:00	-3	1.7	8.4	14.3	3.9	813,977.6	0.00	1.00
03/17/2026 13:00	-2	1.7	7.9	14.3	2.7	811,695.2	0.00	1.00
03/17/2026 14:00	-3	1.7	7.7	14.4	3.1	822,708.0	0.00	1.00
03/17/2026 15:00	-2	1.7	7.7	14.4	3.3	821,865.3	0.00	1.00
03/17/2026 16:00	-2	1.7	7.6	14.4	3.4	821,654.6	0.03	1.00
03/17/2026 17:00	0	13.7	22.6	15.7	0.0	581,742.0	0.18	0.18
03/17/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/17/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	-2	5.6	11.6	15.0	2.5	777,359.0	1.33 #	6.45 #
Minimum:	-3	1.7	7.6	14.2	0.0	581,742.0	0.00	0.00
Maximum:	-1	17.1	22.6	18.0	3.9	822,708.0	0.85	1.00
%SI	75.00	66.67	66.67	66.67	66.67	66.67	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/18/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2026 08:00	0	17.6	19.2	17.9	0.0	755,009.3	0.27	0.27
03/18/2026 09:00	-3	4.6	9.1	14.2	4.2	810,413.1	0.63	1.00
03/18/2026 10:00	-3	1.7	8.4	14.3	3.4	815,845.0	0.00	1.00
03/18/2026 11:00	-3	1.7	8.2	14.3	3.9	814,600.0	0.00	1.00
03/18/2026 12:00	-2	1.7	7.8	14.3	2.6	813,147.6	0.00	0.93
03/18/2026 13:00	-1	1.7	7.6	14.4	4.2	820,811.9	0.07	1.00
03/18/2026 14:00	0	18.2	26.7	15.9	0.0	588,304.7	0.13	0.13
03/18/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/18/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	-2	6.7	12.4	15.0	2.6	774,018.8	1.10 #	5.33 #
Minimum:	-3	1.7	7.6	14.2	0.0	588,304.7	0.00	0.00
Maximum:	-1	18.2	26.7	17.9	4.2	820,811.9	0.63	1.00
%SI	79.17	70.83	70.83	70.83	70.83	70.83	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/19/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/19/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/20/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/20/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/21/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/21/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/22/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/22/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/23/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/23/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/24/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/24/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/25/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/25/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/26/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2026 08:00	0	18.0	24.2	18.3	0.0	795,319.5	0.27	0.27
03/26/2026 09:00	-2	6.7	10.6	14.3	5.5	821,654.6	0.92	1.00
03/26/2026 10:00	-2	1.7	9.5	14.3	3.9	822,069.6	0.00	1.00
03/26/2026 11:00	-3	1.7	9.3	14.3	4.1	820,409.7	0.00	1.00
03/26/2026 12:00	-3	3.0	11.5	14.5	3.1	804,322.9	0.17	1.00
03/26/2026 13:00	0	24.4	34.3	17.6	0.0	459,794.6	0.03	0.03
03/26/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/26/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	-3	9.3	16.6	15.6	2.8	753,928.5	1.39 #	4.30 #
Minimum:	-3	1.7	9.3	14.3	0.0	459,794.6	0.00	0.00
Maximum:	-2	24.4	34.3	18.3	5.5	822,069.6	0.92	1.00
%SI	83.33	75.00	75.00	75.00	75.00	75.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/27/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/27/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/28/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/28/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/29/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/29/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/30/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/30/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT2



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:20 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 10							
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NH3Slip, Ppmvdc	NOx, Ppm	NOx, _SCR, Ppm	O2, Dry, Pct	NH3Inj, LbPerHr	ExhaustFlow, LbPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/31/2026 00:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 01:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 02:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 03:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 04:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 05:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 06:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 07:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 14:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 15:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 16:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 17:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 18:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 19:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 20:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 21:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 22:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
03/31/2026 23:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

AQ-54 thru 63 & 71

AQ54-63 & 71: Fuel use emission and operational data -
Hourly/Daily/Quarterly

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

Sample Spreadsheet Listing

Date/Time	CT1_GasFlow_CT_scfh_1M		CT1_CO_Ppmvdc_1M		CT1_NOx_Ppmvdc_1M		CT1_CO_LbPerHr_1M		CT1_NOx_LbPerHr_1M		CT1_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
03/11/26 6:40	0		0		0		0		0		0	
03/11/26 6:41	0		0		0		0		0		0	
03/11/26 6:42	0		0		0		0		0		0	
03/11/26 6:43	0		0		0		0		0		0	
03/11/26 6:44	0		0		0		0		0		0	
03/11/26 6:45	2362.5		0.1		0		0		0		1	
03/11/26 6:46	23474.5		0.1		0		0		0		1	
03/11/26 6:47	37285.4		1724.8		3.93		179.53		0.67		1	
03/11/26 6:48	50368.4		1509		4.99		203.69		1.11		1	
03/11/26 6:49	63330.2		976.3		9.37		161.5		2.55		1	
03/11/26 6:50	89692.8		644.7		16.46		146.76		6.17		1	
03/11/26 6:51	133204.9		505.4		22.48		166.88		12.21		1	
03/11/26 6:52	140916.1		395.8		33.28		137.58		19.04		1	
03/11/26 6:53	138386.1		1123.8		37.76		384.11		21.24		1	
03/11/26 6:54	136999.9		2037.7		35.99		690.57		20.07		1	
03/11/26 6:55	135862		2107.7		41.91		709.6		23.22		1	
03/11/26 6:56	135168.8		2107.5		44.35		704.81		24.41		1	
03/11/26 6:57	134435.2		2107.3		50.25		700.97		27.51		1	
03/11/26 6:58	133799.8		2182.2		57.74		721.47		31.42		1	
03/11/26 6:59	133366.6		2182.2		64.27		719.02		34.85		1	
03/11/26 7:00	133020.1		2182.2		65.74		716.09		35.51		1	
03/11/26 7:01	132812.1		2182.2		66.59		714.63		35.89		1	
03/11/26 7:02	132569.5		2182.2		66.38		715.12		35.8		1	
03/11/26 7:03	132176.7		2182.4		64.9		711.77		34.84		1	
03/11/26 7:04	133314.6		2182.4		62.79		716.65		33.94		1	
03/11/26 7:05	147408.6		2182.2		61.74		787.9		36.69		1	
03/11/26 7:06	159954.5		2036.5		61.56		794.56		39.53		1	
03/11/26 7:07	161814.4		1797.1		60.56		710.81		39.42		1	
03/11/26 7:08	166435.4		1697.1		57.36		689.11		38.33		1	
03/11/26 7:09	185069.4		1696.9		56.54		764.25		41.91		1	
03/11/26 7:10	194022.5		969.4		51.18		456.98		39.71		1	
03/11/26 7:11	203275.9		176.6		49.61		87.09		40.27		1	

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/11/26 7:12	222643.6			78.3			48.25			42.16			42.77			1		
03/11/26 7:13	229557.6			20.5			48.89			11.35			44.59			1		
03/11/26 7:14	234144			12.4			58.89			6.98			54.74			1		
03/11/26 7:15	251368.6			10.9			57.91			6.61			57.62			1		
03/11/26 7:16	270251			9			54.15			5.82			57.93			1		
03/11/26 7:17	272006.9			6.7			31.34			4.37			33.73			1		
03/11/26 7:18	286279.9			5.5			22.1			3.8			24.99			1		
03/11/26 7:19	303660.5			4.7			16.88			3.44			20.23			1		
03/11/26 7:20	306762.3			4.2			9.11			3.05			10.96			1		
03/11/26 7:21	306617.9			3.9			6.94			2.86			8.38			1		
03/11/26 7:22	306479.3			3.7			6.07			2.75			7.35			1		
03/11/26 7:23	306773.8			3.6			5.81			2.62			7.05			1		
03/11/26 7:24	306438.8			3.4			5.37			2.53			6.52			1		
03/11/26 7:25	318620.8			3.3			5.02			2.5			6.33			1		
03/11/26 7:26	331542.2			3.2			4.93			2.53			6.47			1		
03/11/26 7:27	335995.6			3.1			4.69			2.51			6.19			1		
03/11/26 7:28	338999.3			3.1			4.6			2.5			6.05			1		
03/11/26 7:29	350297.5			3			4.6			2.44			6.25			1		
03/11/26 7:30	364039.1			2.7			4.31			2.34			6.1			1		
03/11/26 7:31	370029			2.4			4.11			2.11			5.91			1		
03/11/26 7:32	374817.5			2.1			4.05			1.87			5.9			1		
03/11/26 7:33	391071.7			1.8			3.52			1.71			5.35			1		
03/11/26 7:34	401388			1.8			3.4			1.69			5.29			1		
03/11/26 7:35	405841.5			1.6			3.49			1.54			5.49			1		
03/11/26 7:36	419854.5			1.4			3.84			1.42			6.27			1		
03/11/26 7:37	434323.8			1.4			3.72			1.4			6.28			1		
03/11/26 7:38	441353.5			1.4			3.54			1.42			6.07			1		
03/11/26 7:39	453489.3			1.4			2.72			1.46			4.8			1		
03/11/26 7:40	459230.8			1.4			2.45			1.48			4.37			1		
03/11/26 7:41	456319.6			1.3	X		2.23	X		1.41	X		3.95	X		1		
03/11/26 7:42	455551.4			1.4	X		2.11	X		1.47	X		3.73	X		1		
03/11/26 7:43	456839.5			1.2	X		1.91	X		1.27	X		3.38	X		1		
03/11/26 7:44	456718.2			1.2	X		1.88	X		1.25	X		3.33	X		1		
03/11/26 7:45	458260.4			1.4			2.45			1.47			4.36			1		
03/11/26 7:46	458029.4			1.1			1.91			1.18			3.39			1		

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/11/26 7:47	457769.4			1.1			1.88			1.16			3.34			1		
03/11/26 7:48	458393.3			1.1			1.79			1.16			3.18			1		
03/11/26 7:49	458433.7			1.1			1.7			1.16			3.02			1		
03/11/26 7:50	458341.3			1			1.7			1.06			3.02			1		
03/11/26 7:51	458260.5			1			1.79			1.06			3.18			1		
03/11/26 7:52	458555			1			1.79			1.06			3.18			1		
03/11/26 7:53	458162.3			1			1.79			1.06			3.18			1		
03/11/26 7:54	458601.3			1			1.7			1.06			3.02			1		
03/11/26 7:55	458462.6			1			1.7			1.06			3.02			1		
03/11/26 7:56	458728.3			1			1.7			1.06			3.03			0		
03/11/26 7:57	458526.2			0.9			1.7			0.97			3.02			0		
03/11/26 7:58	459444.6			0.9			1.61			0.97			2.87			0		
03/11/26 7:59	458520.4			0.9			1.61			0.97			2.86			0		
03/11/26 8:00	458514.6			0.9			1.61			0.97			2.86			0		

Sample Spreadsheet Listing

Date/Time	CT1_GasFlow_CT_scfh_1M		CT1_CO_Ppmvdc_1M		CT1_NOx_Ppmvdc_1M		CT1_CO_LbPerHr_1M		CT1_NOx_LbPerHr_1M		CT1_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
03/11/26 10:01	335885.9		0.9		1.5		0.71		1.99		0	
03/11/26 10:02	335706.8		0.9		1.5		0.71		1.99		0	
03/11/26 10:03	335972.5		0.9		1.52		0.72		2.03		0	
03/11/26 10:04	336434.6		0.9		1.5		0.71		2		0	
03/11/26 10:05	336509.7		0.9		1.5		0.71		2		0	
03/11/26 10:06	326753.8		0.9		1.5		0.69		1.94		1	
03/11/26 10:07	194444.1		0.9		1.59		0.42		1.24		1	
03/11/26 10:08	42951.8		0		6.94		8.03		1.35		0	
03/11/26 10:09	42882.5		0		17.7		286.75		3.44		0	
03/11/26 10:10	41860.1		0		0.1		0		0		0	
03/11/26 10:11	40843.5		0		0.1		0		0		0	
03/11/26 10:12	41865.9		0		0.1		0		0		0	

Sample Spreadsheet Listing

Date/Time	CT1_GasFlow_CT_scfh_1M		CT1_CO_Ppmvdc_1M		CT1_NOx_Ppmvdc_1M		CT1_CO_LbPerHr_1M		CT1_NOx_LbPerHr_1M		CT1_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
03/13/26 15:40	32768.4		0		0		0		0		0	
03/13/26 15:41	32658.6		0		0		0		0		0	
03/13/26 15:42	32699.1		0		0		0		0		0	
03/13/26 15:43	32808.8		0		0		0		0		0	
03/13/26 15:44	53037.1		0		0		0		0		0	
03/13/26 15:45	40115.7		0.1		0		0		0		1	
03/13/26 15:46	44696.2		0.8		0		0		0		1	
03/13/26 15:47	53019.7		1764.1		12.98		222.32		2.69		1	
03/13/26 15:48	64635.7		1303.9		12.59		198.77		3.16		1	
03/13/26 15:49	75050.1		746.4		18.68		132.15		5.44		1	
03/13/26 15:50	101591.8		454.9		22.48		109.05		8.87		1	
03/13/26 15:51	139934.2		340.6		30.84		112.76		16.8		1	
03/13/26 15:52	146588.3		236.4		41.3		81.98		23.57		1	
03/13/26 15:53	160578.3		1405.3		41.49		533.84		25.94		1	
03/13/26 15:54	179576.2		1888.9		44.7		800.4		31.17		1	
03/13/26 15:55	201352.5		1029.4		55.89		489.89		43.78		1	
03/13/26 15:56	223047.9		100.7		58.87		53		50.98		1	
03/13/26 15:57	245141.9		6.6		60.2		3.83		57.31		1	
03/13/26 15:58	268997.5		2.1		78.31		1.36		81.79		1	
03/13/26 15:59	293194		1.8		49.13		1.27		55.93		1	
03/13/26 16:00	313543.6		1.8		21.84		1.3		26.59		1	
03/13/26 16:01	331380.5		1.8		11.28		1.42		14.51		1	
03/13/26 16:02	348680.2		1.8		10.09		1.48		13.66		1	
03/13/26 16:03	365829.8		1.7		8.68		1.5		12.33		1	
03/13/26 16:04	387230.5		1.6		6.96		1.45		10.46		1	
03/13/26 16:05	407146.8		1.4		5.27		1.37		8.34		1	
03/13/26 16:06	432729.7		1.3		4.61		1.32		7.74		1	
03/13/26 16:07	440677.7		1.1		4.7		1.15		8.05		1	
03/13/26 16:08	436386		1		5.26		1.03		8.92		1	
03/13/26 16:09	434121.8		1		4.63		1.02		7.81		1	
03/13/26 16:10	434283.4		0.9		4.36		0.93		7.35		1	
03/13/26 16:11	434393.2		0.9		4.33		0.94		7.31		1	

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/13/26 16:12	433723.1			0.8			4.27			0.84			7.19			1		
03/13/26 16:13	433185.9			0.8			4.33			0.85			7.3			1		
03/13/26 16:14	433116.7			0.8			4.33			0.85			7.3			1		
03/13/26 16:15	432920.3			0.8			4.24			0.85			7.13			1		
03/13/26 16:16	432978			0.8			4.24			0.85			7.13			1		
03/13/26 16:17	432695			0.8			4.24			0.85			7.13			1		
03/13/26 16:18	432937.6			0.7			4.24			0.75			7.13			1		
03/13/26 16:19	433451.6			0.7			4.24			0.75			7.14			1		
03/13/26 16:20	433220.6			0.7			4.33			0.76			7.31			1		
03/13/26 16:21	432510.2			0.7			4.43			0.75			7.44			1		
03/13/26 16:22	432654.5			0.7			4.52			0.75			7.59			1		
03/13/26 16:23	432417.7			0.7			4.61			0.75			7.74			1		
03/13/26 16:24	432920.3			0.7			4.61			0.75			7.75			1		
03/13/26 16:25	433318.8			0.7			3.87			0.75			6.51			1		
03/13/26 16:26	433209.1			0.7			2.77			0.76			4.66			1		
03/13/26 16:27	432897.2			0.7			2.49			0.75			4.19			1		
03/13/26 16:28	432423.5			0.7			2.58			0.75			4.34			1		
03/13/26 16:29	432954.9			0.7			2.86			0.76			4.82			1		
03/13/26 16:30	432591			0.7			3.04			0.75			5.12			1		
03/13/26 16:31	432544.8			0.7			3.23			0.75			5.42			1		
03/13/26 16:32	432648.8			0.7			2.77			0.75			4.65			1		
03/13/26 16:33	432822.1			0.7			2.21			0.75			3.72			1		
03/13/26 16:34	433711.6			0.7			2.12			0.75			3.57			1		
03/13/26 16:35	433561.4			0.7			2.03			0.75			3.41			1		
03/13/26 16:36	432498.6			0.7			2.12			0.75			3.57			1		
03/13/26 16:37	432394.6			0.7			2.21			0.75			3.71			1		
03/13/26 16:38	432412			0.7			2.3			0.75			3.87			1		
03/13/26 16:39	433463.3			0.7			2.21			0.75			3.73			1		
03/13/26 16:40	433411.3			0.7			2.12			0.75			3.57			1		
03/13/26 16:41	433290			0.7			1.94			0.76			3.26			1		
03/13/26 16:42	433058.9			0.7			1.75			0.75			2.95			1		
03/13/26 16:43	432550.6			0.7			1.66			0.75			2.79			1		
03/13/26 16:44	432539			0.7			1.66			0.75			2.79			1		
03/13/26 16:45	432868.3			0.7			1.66			0.75			2.79			1		
03/13/26 16:46	433792.5			0.7			1.66			0.75			2.79			1		

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/13/26 16:47	433301.5			0.7			1.66			0.75			2.79			1		
03/13/26 16:48	434012			0.7			1.75			0.76			2.95			1		
03/13/26 16:49	433278.4			0.7			1.75			0.75			2.95			1		
03/13/26 16:50	433515.3			0.7			1.66			0.75			2.79			1		
03/13/26 16:51	433336.1			0.7			1.66			0.75			2.79			0		
03/13/26 16:52	433168.6			0.7			1.57			0.75			2.64			0		
03/13/26 16:53	433700			0.7			1.57			0.75			2.64			0		
03/13/26 16:54	432902.9			0.7			1.57			0.75			2.63			0		
03/13/26 16:55	432787.4			0.7			1.57			0.75			2.64			0		

Sample Spreadsheet Listing

Date/Time	CT1_GasFlow_CT_scfh_1M		CT1_CO_Ppmvdc_1M		CT1_NOx_Ppmvdc_1M		CT1_CO_LbPerHr_1M		CT1_NOx_LbPerHr_1M		CT1_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
03/13/26 19:48	438800.4		0.8		1.45		0.85		2.48		0	
03/13/26 19:49	439129.7		0.8		1.45		0.85		2.48		0	
03/13/26 19:50	439666.9		0.8		1.45		0.85		2.48		0	
03/13/26 19:51	439834.4		0.8		1.54		0.85		2.64		0	
03/13/26 19:52	439678.4		0.9		1.54		0.95		2.64		0	
03/13/26 19:53	440435.1		0.9		1.54		0.95		2.65		1	
03/13/26 19:54	429021.3		0.8		1.45		0.83		2.43		1	
03/13/26 19:55	407897.8		0.8		1.54		0.79		2.45		1	
03/13/26 19:56	386173.5		0.8		1.79		0.74		2.69		1	
03/13/26 19:57	363484.6		0.8		2.38		0.68		3.36		1	
03/13/26 19:58	342944.4		0.9		2.43		0.71		3.25		1	
03/13/26 19:59	319672.1		1		2.43		0.72		3.03		1	
03/13/26 20:00	294632.3		1		2.43		0.67		2.79		1	
03/13/26 20:01	273300.8		0.9		2.68		0.58		2.85		1	
03/13/26 20:02	251605.4		0.8		3.6		0.5		3.54		1	
03/13/26 20:03	227871		0.8		4.57		0.41		4.08		1	
03/13/26 20:04	207290.4		0.6		13.66		0.31		11.08		1	
03/13/26 20:05	183573.3		2		19.09		0.87		13.85		1	
03/13/26 20:06	163651.2		110.7		21.16		43.14		13.57		1	
03/13/26 20:07	147321.9		984.6		23.01		345.79		13.3		1	
03/13/26 20:08	99622.1		1782.8		23.6		420.63		9.16		1	
03/13/26 20:09	54723.7		0		30.01		327.32		6.51		0	
03/13/26 20:10	52858		0		0.4		0		0		0	
03/13/26 20:11	50391.5		0		0.3		0		0		0	
03/13/26 20:12	49178.5		0		0.2		0		0		0	
03/13/26 20:13	49115		0		0.2		0		0		0	

Sample Spreadsheet Listing

Date/Time	CT1_GasFlow_CT_scfh_1M		CT1_CO_Ppmvdc_1M		CT1_NOx_Ppmvdc_1M		CT1_CO_LbPerHr_1M		CT1_NOx_LbPerHr_1M		CT1_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
03/15/26 10:40	47988.7		0		0		0		0		0	
03/15/26 10:41	48260.1		0		0		0		0		0	
03/15/26 10:42	48508.5		0		0		0		0		0	
03/15/26 10:43	48866.6		0		0		0		0		0	
03/15/26 10:44	44632.7		0		0		0		0		0	
03/15/26 10:45	41894.8		0.1		0		0		0		1	
03/15/26 10:46	38267.3		0.8		0		0		0		1	
03/15/26 10:47	48450.8		1813.7		17.7		207.46		3.33		1	
03/15/26 10:48	59933.8		1385.3		12.98		195.98		3.02		1	
03/15/26 10:49	71099.2		821.1		18.68		137.66		5.16		1	
03/15/26 10:50	97617.8		525.7		23.6		121.09		8.95		1	
03/15/26 10:51	138386.1		393.4		29.77		128.49		16		1	
03/15/26 10:52	146958		286.3		43.27		99.26		24.69		1	
03/15/26 10:53	150735.7		1330.7		44.54		473.33		26.07		1	
03/15/26 10:54	150106		1874.9		43.62		663.97		25.42		1	
03/15/26 10:55	151654.1		1874.9		46.31		670.68		27.26		1	
03/15/26 10:56	165441.9		1875.1		50.24		732.03		32.28		1	
03/15/26 10:57	185837.6		1768.1		54.45		775.36		39.3		1	
03/15/26 10:58	208387.9		633.1		56.05		311.2		45.34		1	
03/15/26 10:59	228766.3		49.3		54.02		26.61		47.98		1	
03/15/26 11:00	252344.8		5.3		63.4		3.17		62.12		1	
03/15/26 11:01	279290.7		3.1		69.97		2.05		75.89		1	
03/15/26 11:02	301205.6		2.7		35.77		1.93		41.84		1	
03/15/26 11:03	320417.3		2.5		15.27		1.9		19		1	
03/15/26 11:04	338698.9		2.4		9.98		1.94		13.12		1	
03/15/26 11:05	354693.2		2.3		9.72		1.89		13.38		1	
03/15/26 11:06	374182.1		2.1		8.33		1.84		12.1		1	
03/15/26 11:07	395063.1		2		7.15		1.83		10.97		1	
03/15/26 11:08	416255.9		1.7		5.99		1.67		9.68		1	
03/15/26 11:09	440331.1		1.5		5.36		1.51		9.16		1	
03/15/26 11:10	448233		1.3		5.72		1.36		9.95		1	
03/15/26 11:11	444547.7		1.2		6.35		1.22		10.96		1	

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/15/26 11:12	443323.2			1.1			6.08			1.14			10.47			1		
03/15/26 11:13	443086.3			1			5.9			1.04			10.15			1		
03/15/26 11:14	442942			1			5.72			1.04			9.84			1		
03/15/26 11:15	442947.8			0.9			5.63			0.95			9.68			1		
03/15/26 11:16	442635.8			0.9			5.54			0.95			9.52			1		
03/15/26 11:17	442612.8			0.9			5.54			0.95			9.52			1		
03/15/26 11:18	441382.4			0.8			5.54			0.85			9.49			1		
03/15/26 11:19	440516			0.8			5.54			0.85			9.47			1		
03/15/26 11:20	440088.5			0.8			5.54			0.85			9.46			1		
03/15/26 11:21	439378			0.8			5.54			0.85			9.45			1		
03/15/26 11:22	438413.5			0.8			5.54			0.85			9.43			1		
03/15/26 11:23	440053.9			0.8			5.62			0.86			9.61			1		
03/15/26 11:24	439817			0.8			5.62			0.86			9.6			1		
03/15/26 11:25	439308.8			0.8			5.54			0.85			9.44			1		
03/15/26 11:26	439389.6			0.7			3.9			0.75			6.66			1		
03/15/26 11:27	439470.5			0.7			2.81			0.75			4.8			1		
03/15/26 11:28	438009.1			0.7			2.95			0.76			5.02			1		
03/15/26 11:29	437997.5			0.8			3.32			0.86			5.64			1		
03/15/26 11:30	437703			0.8			3.87			0.86			6.58			1		
03/15/26 11:31	438679.1			0.8			3.87			0.86			6.6			1		
03/15/26 11:32	440076.9			0.8			2.95			0.86			5.04			1		
03/15/26 11:33	439626.4			0.7			2.67			0.77			4.56			1		
03/15/26 11:34	439418.5			0.7			2.54			0.75			4.34			1		
03/15/26 11:35	439060.3			0.7			2.49			0.76			4.24			1		
03/15/26 11:36	437252.4			0.7			2.54			0.75			4.32			1		
03/15/26 11:37	436732.6			0.7			2.63			0.75			4.46			1		
03/15/26 11:38	438228.6			0.7			2.58			0.76			4.39			1		
03/15/26 11:39	437887.8			0.7			2.4			0.76			4.08			1		
03/15/26 11:40	439545.6			0.7			2.21			0.76			3.78			1		
03/15/26 11:41	438032.2			0.7			2.12			0.76			3.61			1		
03/15/26 11:42	437651			0.7			1.91			0.75			3.24			1		
03/15/26 11:43	439591.8			0.7			1.84			0.76			3.15			1		
03/15/26 11:44	438026.4			0.7			1.72			0.75			2.93			1		
03/15/26 11:45	437084.9			0.7			1.75			0.76			2.97			1		
03/15/26 11:46	436825			0.7			1.75			0.76			2.97			1		

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/15/26 11:47	436420.7			0.7			1.72			0.75			2.92			1		
03/15/26 11:48	435767.9			0.7			1.75			0.76			2.96			1		
03/15/26 11:49	437512.4			0.7			1.75			0.76			2.98			1		
03/15/26 11:50	437778			0.7			1.66			0.76			2.82			1		
03/15/26 11:51	436611.3			0.7			1.66			0.76			2.81			1		
03/15/26 11:52	435762.2			0.7			1.66			0.76			2.81			0		
03/15/26 11:53	437957.1			0.7			1.66			0.76			2.82			0		
03/15/26 11:54	436131.8			0.7			1.57			0.76			2.65			0		
03/15/26 11:55	437396.8			0.7			1.57			0.76			2.66			0		
03/15/26 11:56	437518.1			0.7			1.57			0.76			2.66			0		

Sample Spreadsheet Listing

Date/Time	CT1_GasFlow_CT_scfh_1M		CT1_CO_Ppmvdc_1M		CT1_NOx_Ppmvdc_1M		CT1_CO_LbPerHr_1M		CT1_NOx_LbPerHr_1M		CT1_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
03/15/26 14:45	422396		0.7		1.57		0.74		2.6		0	
03/15/26 14:46	421674		0.7		1.57		0.74		2.59		0	
03/15/26 14:47	422401.8		0.7		1.5		0.76		2.49		0	
03/15/26 14:48	423470.4		0.7		1.5		0.76		2.49		0	
03/15/26 14:49	422881.2		0.7		1.48		0.74		2.45		0	
03/15/26 14:50	423505		0.7		1.48		0.74		2.45		1	
03/15/26 14:51	423014		0.7		1.48		0.74		2.45		1	
03/15/26 14:52	413142.5		0.7		1.57		0.73		2.54		1	
03/15/26 14:53	395964.2		0.7		1.78		0.71		2.77		1	
03/15/26 14:54	374280.3		0.7		2.12		0.66		3.1		1	
03/15/26 14:55	353052.8		0.8		2.77		0.68		3.84		1	
03/15/26 14:56	330306.1		0.8		2.82		0.62		3.64		1	
03/15/26 14:57	305485.8		0.9		2.82		0.64		3.38		1	
03/15/26 14:58	282230.8		0.8		2.41		0.54		2.67		1	
03/15/26 14:59	261442.3		0.7		3.28		0.47		3.37		1	
03/15/26 15:00	240041.5		0.7		4		0.38		3.76		1	
03/15/26 15:01	217162		0.5		6.5		0.26		5.52		1	
03/15/26 15:02	194449.9		0.4		17.59		0.2		13.41		1	
03/15/26 15:03	171911.2		4.9		21.79		2.04		14.85		1	
03/15/26 15:04	153791.3		164.9		25.11		60.77		15.23		1	
03/15/26 15:05	136173.9		1023.9		26.31		330.96		14		1	
03/15/26 15:06	49860.1		1945.2		26.73		237.74		5.38		1	
03/15/26 15:07	49097.7		0		41.3		655.87		8.06		0	
03/15/26 15:08	49178.5		0		0.1		0		0		0	
03/15/26 15:09	49265.2		0		0.1		0		0		0	
03/15/26 15:10	49710		0		0.1		0		0		0	
03/15/26 15:11	50131.6		0		0.1		0		0		0	

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M		CT2_CO_Ppmvdc_1M		CT2_NOx_Ppmvdc_1M		CT2_CO_LbPerHr_1M		CT2_NOx_LbPerHr_1M		CT2_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
03/11/26 12:39	0		0		0		0		0		0	
03/11/26 12:40	0		0		0		0		0		0	
03/11/26 12:41	0		0		0		0		0		0	
03/11/26 12:42	0		0		0		0		0		0	
03/11/26 12:43	13805.1		0		0		0		0		0	
03/11/26 12:44	0		0		0		0		0		1	
03/11/26 12:45	0		0		0		0		0		1	
03/11/26 12:46	17369		1669.7		0		76.25		0		1	
03/11/26 12:47	37476		1148.5		4.92		109.01		0.77		1	
03/11/26 12:48	51396.6		825.3		10.76		105.49		2.26		1	
03/11/26 12:49	65276.8		509.8		15.93		82.5		4.24		1	
03/11/26 12:50	97513.8		395.9		21.63		92.95		8.36		1	
03/11/26 12:51	145023		279.1		29.76		96.9		17		1	
03/11/26 12:52	153566		216.8		44.88		79.99		27.25		1	
03/11/26 12:53	169629.6		1172.6		43.39		478.23		29.13		1	
03/11/26 12:54	191082.4		1833.8		47.75		838.22		35.92		1	
03/11/26 12:55	213944.6		1026.3		55.49		521.03		46.36		1	
03/11/26 12:56	236310		284.5		60.4		159.45		55.72		1	
03/11/26 12:57	257814.8		29.1		63.39		17.88		64.06		1	
03/11/26 12:58	283952.1		3.1		62.82		2.11		69.96		1	
03/11/26 12:59	309465.6		2		40.35		1.47		48.92		1	
03/11/26 13:00	333558.1		1.8		25.6		1.44		33.44		1	
03/11/26 13:01	352977.7		1.8		19.64		1.48		27.09		1	
03/11/26 13:02	373789.3		1.9		15.62		1.7		22.85		1	
03/11/26 13:03	393237.8		1.9		12.58		1.77		19.25		1	
03/11/26 13:04	414806.1		1.8		10.74		1.82		17.45		1	
03/11/26 13:05	435970.1		1.8		9.48		1.85		16.14		1	
03/11/26 13:06	444247.4		1.6		8.76		1.69		15.18		1	
03/11/26 13:07	446563.6		1.5		8.17		1.54		14.24		1	
03/11/26 13:08	446835.1		1.3		7.81		1.35		13.64		1	
03/11/26 13:09	446113.1		1.2		7.44		1.25		12.99		1	
03/11/26 13:10	444992.5		1.1		7.01		1.17		12.19		1	

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/11/26 13:11	443935.5			1.1			6.81			1.15			11.84			1		
03/11/26 13:12	444004.8			1			6.72			1.06			11.7			1		
03/11/26 13:13	443548.5			1			6.55			1.07			11.35			1		
03/11/26 13:14	443577.3			0.9			6.44			0.96			11.22			1		
03/11/26 13:15	443057.4			0.9			6.64			0.97			11.5			1		
03/11/26 13:16	442381.6			0.9			6.54			0.95			11.3			1		
03/11/26 13:17	441648.1			0.8			6.54			0.86			11.27			1		
03/11/26 13:18	442427.9			0.8			6.72			0.86			11.6			1		
03/11/26 13:19	441105.1			0.8			6.81			0.86			11.73			1		
03/11/26 13:20	452767.3			0.8			6.91			0.89			12.25			1		
03/11/26 13:21	457324.7			0.8			6.82			0.91			12.27			1		
03/11/26 13:22	458503			0.7			6.91			0.81			12.48			1		
03/11/26 13:23	458763			0.7			7.1			0.81			12.83			1		
03/11/26 13:24	459617.9			0.7			7.28			0.81			13.17			1		
03/11/26 13:25	459069.1			0.7			7.38			0.81			13.3			1		
03/11/26 13:26	458809.2			0.7			7.38			0.81			13.27			1		
03/11/26 13:27	458404.8			0.7			7.19			0.8			12.91			1		
03/11/26 13:28	458682.1			0.7			4.78			0.82			8.62			1		
03/11/26 13:29	457809.9			0.6			2.86			0.71			5.14			1		
03/11/26 13:30	457197.6			0.6			2.77			0.7			4.95			1		
03/11/26 13:31	457446			0.6			2.77			0.71			4.97			1		
03/11/26 13:32	456504.5			0.6			2.86			0.7			5.12			1		
03/11/26 13:33	455996.2			0.7			2.95			0.8			5.29			1		
03/11/26 13:34	456573.8			0.7			3.13			0.8			5.6			1		
03/11/26 13:35	457636.6			0.6			3.32			0.7			5.96			1		
03/11/26 13:36	456955			0.6			3.41			0.7			6.08			1		
03/11/26 13:37	455210.6			0.6			3.78			0.7			6.73			1		
03/11/26 13:38	455603.4			0.6			3.96			0.7			7.1			1		
03/11/26 13:39	455770.9			0.7			3.18			0.71			5.68			1		
03/11/26 13:40	456181			0.7			2.62			0.71			4.7			1		
03/11/26 13:41	456446.7			0.6			2.3			0.7			4.12			1		
03/11/26 13:42	455129.8			0.6			2.21			0.7			3.94			1		
03/11/26 13:43	454996.9			0.7			2.25			0.71			3.99			1		
03/11/26 13:44	455389.6			0.6			2.3			0.7			4.12			1		
03/11/26 13:45	454159.3			0.6			2.4			0.7			4.26			1		

Date/Time	CT2_GasFlow_CT_scfh_1M		CT2_CO_Ppmvdc_1M		CT2_NOx_Ppmvdc_1M		CT2_CO_LbPerHr_1M		CT2_NOx_LbPerHr_1M		CT2_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
03/11/26 13:46	455020		0.6		2.49		0.7		4.43		1	
03/11/26 13:47	454332.6		0.6		2.4		0.7		4.26		1	
03/11/26 13:48	455164.4		0.6		2.21		0.7		3.94		1	
03/11/26 13:49	454892.9		0.6		1.94		0.7		3.45		1	
03/11/26 13:50	454812		0.6		1.75		0.7		3.12		1	
03/11/26 13:51	455245.2		0.6		1.57		0.7		2.8		1	
03/11/26 13:52	455441.7		0.6		1.57		0.7		2.79		1	
03/11/26 13:53	454274.8		0.6		1.57		0.7		2.78		1	
03/11/26 13:54	455291.5		0.7		1.59		0.71		2.84		1	
03/11/26 13:55	454055.4		0.7		1.69		0.71		3		1	
03/11/26 13:56	454269		0.7		1.69		0.71		3		1	
03/11/26 13:57	454754.3		0.6		1.75		0.7		3.13		1	
03/11/26 13:58	453674.2		0.6		1.75		0.7		3.11		1	
03/11/26 13:59	454113.1		0.6		1.66		0.7		2.95		1	
03/11/26 14:00	453610.6		0.6		1.66		0.7		2.95		0	
03/11/26 14:01	454234.4		0.7		1.69		0.71		3		0	
03/11/26 14:02	454165.1		0.6		1.57		0.7		2.78		0	
03/11/26 14:03	453922.5		0.6		1.57		0.7		2.79		0	
03/11/26 14:04	455147.1		0.6		1.48		0.7		2.63		0	

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M		CT2_CO_Ppmvdc_1M		CT2_NOx_Ppmvdc_1M		CT2_CO_LbPerHr_1M		CT2_NOx_LbPerHr_1M		CT2_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
03/11/26 15:49	454737		0.7		1.5		0.71		2.68		0	
03/11/26 15:50	455227.9		0.7		1.5		0.71		2.68		0	
03/11/26 15:51	454274.8		0.7		1.5		0.71		2.67		0	
03/11/26 15:52	454263.3		0.7		1.5		0.71		2.68		0	
03/11/26 15:53	456533.3		0.7		1.5		0.71		2.68		0	
03/11/26 15:54	454338.4		0.7		1.5		0.71		2.67		1	
03/11/26 15:55	443213.4		0.7		1.5		0.69		2.61		1	
03/11/26 15:56	401567.1		0.6		1.57		0.62		2.48		1	
03/11/26 15:57	176855.6		0.7		2		0.31		1.41		1	
03/11/26 15:58	0		0		4.99		0.11		0.09		0	
03/11/26 15:59	0		0		5.9		1.45		0.13		0	
03/11/26 16:00	0		0		0.1		0		0		0	
03/11/26 16:01	0		0		0.1		0		0		0	
03/11/26 16:02	0		0		0.1		0		0		0	

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M		CT2_CO_Ppmvdc_1M		CT2_NOx_Ppmvdc_1M		CT2_CO_LbPerHr_1M		CT2_NOx_LbPerHr_1M		CT2_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
03/12/26 6:43	0		0		0		0		0		0	
03/12/26 6:44	0		0		0		0		0		0	
03/12/26 6:45	0		0		0		0		0		0	
03/12/26 6:46	0		0		0		0		0		0	
03/12/26 6:47	0		0		0		0		0		0	
03/12/26 6:48	2091		0		0		0		0		1	
03/12/26 6:49	0		0.3		0		0		0		1	
03/12/26 6:50	25051.4		1245.9		18.68		73.63		1.82		1	
03/12/26 6:51	42224		1118.4		13.28		111.41		2.18		1	
03/12/26 6:52	56185.1		805.7		19.01		106.77		4.15		1	
03/12/26 6:53	70966.4		522.3		21.91		87.45		6.04		1	
03/12/26 6:54	108788.9		468.9		27.53		120.39		11.63		1	
03/12/26 6:55	153542.9		356.2		36.38		129.01		21.69		1	
03/12/26 6:56	160572.5		310.7		50.05		117.66		31.2		1	
03/12/26 6:57	178016.6		1731.5		51.13		727.1		35.34		1	
03/12/26 6:58	200919.3		1774.5		51.89		841.31		40.48		1	
03/12/26 6:59	222845.7		1056.4		49.06		555.48		42.46		1	
03/12/26 7:00	244096.4		300.4		47.89		172.99		45.39		1	
03/12/26 7:01	266069		34.8		45.85		21.83		47.36		1	
03/12/26 7:02	291986.8		4.2		44.14		2.89		50.05		1	
03/12/26 7:03	317766		2.5		24.84		1.86		30.65		1	
03/12/26 7:04	341829.6		2.2		15.99		1.77		21.22		1	
03/12/26 7:05	362554.7		2.1		12.84		1.78		18.08		1	
03/12/26 7:06	382182.1		2		10.62		1.82		15.76		1	
03/12/26 7:07	402791.6		2		7.75		1.92		12.13		1	
03/12/26 7:08	423175.8		1.9		6.77		1.91		11.12		1	
03/12/26 7:09	441087.8		1.7		5.81		1.74		9.95		1	
03/12/26 7:10	446043.8		1.4		5.72		1.48		9.91		1	
03/12/26 7:11	446020.7		1.3		5.72		1.39		9.91		1	
03/12/26 7:12	446130.4		1.2		5.64		1.3		9.76		1	
03/12/26 7:13	445697.2		1.1		5.55		1.2		9.6		1	
03/12/26 7:14	445102.3		1.1		5.55		1.2		9.59		1	

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/12/26 7:15	445778.1			1.1			5.63			1.13			9.75			1		
03/12/26 7:16	454309.5			1.1			5.63			1.15			9.93			1		
03/12/26 7:17	458087.1			1			5.54			1.06			9.86			1		
03/12/26 7:18	459727.6			1			5.54			1.07			9.89			1		
03/12/26 7:19	459600.5			1			5.9			1.07			10.53			1		
03/12/26 7:20	460189.7			1			6.08			1.07			10.86			1		
03/12/26 7:21	459184.7			1			6.17			1.07			11			1		
03/12/26 7:22	458641.7			1			6.26			1.06			11.15			1		
03/12/26 7:23	458150.7			1			6.35			1.07			11.32			1		
03/12/26 7:24	457711.7			1			5.27			1.06			9.39			1		
03/12/26 7:25	457578.9			1			2.86			1.07			5.1			1		
03/12/26 7:26	458058.3			1			2.41			1.07			4.31			1		
03/12/26 7:27	457625			1			2.5			1.07			4.48			1		
03/12/26 7:28	455164.4			1			2.68			1.06			4.78			1		
03/12/26 7:29	456579.6			0.9			3.22			0.97			5.76			1		
03/12/26 7:30	457163			0.9			3.31			0.97			5.93			1		
03/12/26 7:31	456516			0.9			3.4			0.97			6.09			1		
03/12/26 7:32	455562.9			0.9			3.49			0.97			6.24			1		
03/12/26 7:33	457111			0.9			3.67			0.98			6.6			1		
03/12/26 7:34	455499.4			0.9			2.95			0.98			5.3			1		
03/12/26 7:35	455274.2			0.9			2.41			0.97			4.33			1		
03/12/26 7:36	455170.2			1			2.32			1.07			4.17			1		
03/12/26 7:37	455828.7			1			2.23			1.07			4.02			1		
03/12/26 7:38	455436			1			2.32			1.07			4.18			1		
03/12/26 7:39	456198.3			1			2.5			1.08			4.51			1		
03/12/26 7:40	456290.7			1			2.59			1.08			4.67			1		
03/12/26 7:41	454685			0.9			2.41			0.98			4.34			1		
03/12/26 7:42	455355			0.9			1.88			0.98			3.38			1		
03/12/26 7:43	454107.3			0.9			1.79			0.97			3.21			1		
03/12/26 7:44	455487.8			0.9			1.7			0.98			3.06			1		
03/12/26 7:45	455678.5			0.9			1.7			0.98			3.06			1		
03/12/26 7:46	455880.6			0.9			1.79			0.98			3.22			1		
03/12/26 7:47	454477			0.9			1.88			0.98			3.37			1		
03/12/26 7:48	455331.9			0.9			1.88			0.98			3.38			1		
03/12/26 7:49	454736.9			0.9			1.88			0.98			3.37			1		

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/12/26 7:50	453679.9			0.9			1.79			0.97			3.2			1		
03/12/26 7:51	455967.3			0.9			1.7			0.98			3.06			1		
03/12/26 7:52	455378.1			0.9			1.61			0.98			2.89			1		
03/12/26 7:53	454505.9			0.9			1.43			0.97			2.56			0		
03/12/26 7:54	453668.3			0.9			1.43			0.97			2.56			0		
03/12/26 7:55	454234.4			0.9			1.43			0.97			2.56			0		
03/12/26 7:56	452368.7			0.9			1.43			0.97			2.55			0		
03/12/26 7:57	454361.5			0.9			1.52			0.97			2.72			0		

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M		CT2_CO_Ppmvdc_1M		CT2_NOx_Ppmvdc_1M		CT2_CO_LbPerHr_1M		CT2_NOx_LbPerHr_1M		CT2_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
03/12/26 10:51	453552.8		0.6		1.54		0.68		2.73		0	
03/12/26 10:52	454563.7		0.6		1.45		0.68		2.57		0	
03/12/26 10:53	453466.2		0.6		1.45		0.69		2.58		0	
03/12/26 10:54	452570.9		0.6		1.57		0.69		2.77		0	
03/12/26 10:55	453391.1		0.6		1.57		0.69		2.77		0	
03/12/26 10:56	451577.3		0.6		1.54		0.68		2.72		1	
03/12/26 10:57	440296.4		0.6		1.63		0.67		2.82		1	
03/12/26 10:58	420108.7		0.6		2		0.63		3.28		1	
03/12/26 10:59	395917.9		0.7		2.68		0.67		4.15		1	
03/12/26 11:00	374026.1		0.8		2.99		0.71		4.38		1	
03/12/26 11:01	351626		0.8		3.61		0.66		4.95		1	
03/12/26 11:02	324893.8		0.8		3.61		0.61		4.56		1	
03/12/26 11:03	300275.7		0.8		4.2		0.57		4.94		1	
03/12/26 11:04	276454.6		0.7		5.81		0.49		6.29		1	
03/12/26 11:05	251530.3		0.6		9.83		0.35		9.69		1	
03/12/26 11:06	229430.6		0.4		19.31		0.23		17.38		1	
03/12/26 11:07	204361.9		5.8		32.21		2.8		25.72		1	
03/12/26 11:08	181707.6		144.6		36.97		63.25		26.62		1	
03/12/26 11:09	161387		793.7		41.15		305.23		26.05		1	
03/12/26 11:10	142406.4		1464.2		46.53		497.21		26		1	
03/12/26 11:11	44915.7		1809.1		49.56		198.84		8.96		1	
03/12/26 11:12	0		0		47.2		17.46		0.59		0	
03/12/26 11:13	0		0		0.3		0		0		0	
03/12/26 11:14	0		0		0.2		0		0		0	
03/12/26 11:15	0		0		0.2		0		0		0	
03/12/26 11:16	0		0		5.9		0.92		0.06		0	

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M		CT2_CO_Ppmvdc_1M		CT2_NOx_Ppmvdc_1M		CT2_CO_LbPerHr_1M		CT2_NOx_LbPerHr_1M		CT2_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
03/17/26 10:39	0		0		0		0		0		0	
03/17/26 10:40	0		0		0		0		0		0	
03/17/26 10:41	0		0		0		0		0		0	
03/17/26 10:42	0		0		0		0		0		0	
03/17/26 10:43	0		0		0		0		0		0	
03/17/26 10:44	6815.9		0		0		0		0		1	
03/17/26 10:45	0		0		0		0		0		1	
03/17/26 10:46	13054.2		1475		23.6		60.09		1.58		1	
03/17/26 10:47	36875.2		1213.4		14.26		115.98		2.24		1	
03/17/26 10:48	50974.9		835.8		15.73		107.39		3.33		1	
03/17/26 10:49	64029.2		533.7		17.41		86.13		4.62		1	
03/17/26 10:50	95971.5		388.9		18.24		91.83		7.09		1	
03/17/26 10:51	143527		275.1		24.83		96.18		14.29		1	
03/17/26 10:52	177063.6		218.9		35.2		94.04		24.88		1	
03/17/26 10:53	200226.1		720.9		40.58		348.87		32.32		1	
03/17/26 10:54	205713.5		341		44.32		168.56		36.05		1	
03/17/26 10:55	227050.8		251.1		44.87		137.65		40.48		1	
03/17/26 10:56	248601.8		44.9		49.38		26.82		48.55		1	
03/17/26 10:57	273433.7		2.9		51.83		1.9		56.08		1	
03/17/26 10:58	299178.2		1.1		35.72		0.76		42.13		1	
03/17/26 10:59	325604.3		1		21.32		0.81		27.3		1	
03/17/26 11:00	345387.8		1.1		17.26		0.94		23.43		1	
03/17/26 11:01	366031.9		1.4		13.68		1.2		19.71		1	
03/17/26 11:02	378901.3		1.5		11.71		1.31		17.42		1	
03/17/26 11:03	383048.6		1.5		10.41		1.35		15.65		1	
03/17/26 11:04	384342.4		1.3		10.59		1.19		15.95		1	
03/17/26 11:05	383891.9		1.2		10.33		1.11		15.58		1	
03/17/26 11:06	381991.5		1.1		9.63		1.02		14.37		1	
03/17/26 11:07	381281		1.1		9.86		1.05		14.82		1	
03/17/26 11:08	381731.6		1		9.28		0.94		13.84		1	
03/17/26 11:09	382447.8		1		8.89		0.89		13.42		1	
03/17/26 11:10	380507		1		8.37		0.88		12.53		1	

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/17/26 11:11	380218.3			0.9			8.28			0.8			12.39			1		
03/17/26 11:12	379686.8			0.9			8.19			0.8			12.18			1		
03/17/26 11:13	379513.5			0.9			8.01			0.8			11.98			1		
03/17/26 11:14	379513.5			0.9			7.84			0.8			11.7			1		
03/17/26 11:15	378739.5			0.9			7.66			0.8			11.42			1		
03/17/26 11:16	379392.2			0.9			7.69			0.81			11.5			1		
03/17/26 11:17	376896.9			0.9			7.49			0.8			11.13			1		
03/17/26 11:18	376400.2			0.9			7.4			0.79			10.98			1		
03/17/26 11:19	376163.3			0.9			7.42			0.81			11.01			1		
03/17/26 11:20	376810.3			0.8			7.42			0.73			11.02			1		
03/17/26 11:21	375978.5			0.8			7.42			0.72			10.98			1		
03/17/26 11:22	375504.8			0.8			7.42			0.72			10.98			1		
03/17/26 11:23	376284.7			0.8			7.22			0.72			10.72			1		
03/17/26 11:24	376024.7			0.8			6.96			0.71			10.32			1		
03/17/26 11:25	375031.2			0.8			4.2			0.72			6.21			1		
03/17/26 11:26	375204.5			0.8			2.68			0.72			3.97			1		
03/17/26 11:27	374586.4			0.8			2.68			0.72			3.96			1		
03/17/26 11:28	375452.8			0.8			2.86			0.72			4.24			1		
03/17/26 11:29	375175.6			0.8			3.04			0.72			4.5			1		
03/17/26 11:30	374453.6			0.8			3.22			0.72			4.76			1		
03/17/26 11:31	375089			0.8			3.31			0.72			4.9			1		
03/17/26 11:32	374343.8			0.8			3.49			0.72			5.16			1		
03/17/26 11:33	374494			0.8			3.67			0.72			5.42			1		
03/17/26 11:34	374632.7			0.8			3.75			0.72			5.55			1		
03/17/26 11:35	374130.1			0.8			3.49			0.72			5.15			1		
03/17/26 11:36	373968.4			0.8			2.86			0.72			4.22			1		
03/17/26 11:37	374361.2			0.8			2.68			0.72			3.96			1		
03/17/26 11:38	373916.4			0.8			2.5			0.72			3.7			1		
03/17/26 11:39	373333			0.8			2.29			0.71			3.37			1		
03/17/26 11:40	373535.2			0.8			2.15			0.72			3.16			1		
03/17/26 11:41	374026.1			0.8			1.88			0.72			2.77			1		
03/17/26 11:42	373413.9			0.8			1.7			0.72			2.5			1		
03/17/26 11:43	374107			0.8			1.41			0.71			2.08			1		
03/17/26 11:44	374470.9			0.8			1.34			0.72			1.98			1		
03/17/26 11:45	372957.5			0.8			1.16			0.72			1.71			1		

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/17/26 11:46	372980.6			0.8			1.16			0.72			1.71			1		
03/17/26 11:47	373512			0.8			1.07			0.72			1.58			1		
03/17/26 11:48	372478.2			0.8			0.98			0.72			1.45			1		
03/17/26 11:49	373084.6			0.8			1.07			0.72			1.58			1		
03/17/26 11:50	373668			0.8			1.07			0.72			1.58			1		
03/17/26 11:51	372738.1			0.8			1.16			0.72			1.71			0		
03/17/26 11:52	371652.2			0.8			1.16			0.72			1.7			0		
03/17/26 11:53	373714.3			0.8			1.25			0.72			1.85			0		
03/17/26 11:54	372096.9			0.8			1.25			0.72			1.84			0		
03/17/26 11:55	372761.2			0.8			1.34			0.72			1.97			0		

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M		CT2_CO_Ppmvdc_1M		CT2_NOx_Ppmvdc_1M		CT2_CO_LbPerHr_1M		CT2_NOx_LbPerHr_1M		CT2_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
03/17/26 16:53	370704.8		0.7		1.54		0.65		2.27		0	
03/17/26 16:54	369283.9		0.7		1.63		0.65		2.39		0	
03/17/26 16:55	367932.3		0.7		1.72		0.64		2.51		0	
03/17/26 16:56	369312.8		0.7		1.82		0.65		2.66		0	
03/17/26 16:57	370820.4		0.7		1.7		0.64		2.5		0	
03/17/26 16:58	367880.3		0.7		1.54		0.64		2.25		1	
03/17/26 16:59	355640.5		0.7		1.27		0.62		1.79		1	
03/17/26 17:00	336278.7		0.7		1.07		0.58		1.43		1	
03/17/26 17:01	312059.1		0.7		0.98		0.54		1.22		1	
03/17/26 17:02	288324.7		0.6		1.18		0.44		1.36		1	
03/17/26 17:03	266109.5		0.6		2.53		0.36		2.69		1	
03/17/26 17:04	240122.3		0.5		5.9		0.29		5.68		1	
03/17/26 17:05	217681.8		0.3		16.2		0.17		14.17		1	
03/17/26 17:06	192018.2		8.3		29.03		3.89		22.49		1	
03/17/26 17:07	169462.1		203.7		34.19		84.99		23.48		1	
03/17/26 17:08	149898.1		954.7		38.43		354.77		23.5		1	
03/17/26 17:09	133199.1		1622.3		43.21		538.19		23.59		1	
03/17/26 17:10	0		1902.2		47.4		32.36		1.33		1	
03/17/26 17:11	0		0		80.63		75.71		2.35		0	
03/17/26 17:12	0		0		0.3		0		0		0	
03/17/26 17:13	0		0		0.2		0		0		0	
03/17/26 17:14	0		0		0.2		0		0		0	
03/17/26 17:15	0		0		0.2		0		0		0	

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/18/26 8:39	0			0			0			0			0			0		
03/18/26 8:40	0			0			0			0			0			0		
03/18/26 8:41	0			0			0			0			0			0		
03/18/26 8:42	0			0			0			0			0			0		
03/18/26 8:43	0			0			0			0			0			0		
03/18/26 8:44	0			0			0			0			0			1		
03/18/26 8:45	0			0			0			0			0			1		
03/18/26 8:46	9426.8			1209.5			35.4			36.28			1.75			1		
03/18/26 8:47	35038.4			1201.8			14.07			102.76			1.98			1		
03/18/26 8:48	48918.6			983.9			18.74			120.03			3.76			1		
03/18/26 8:49	62007.5			609.2			23.31			93.82			5.91			1		
03/18/26 8:50	87902.2			440.6			27.62			95.28			9.83			1		
03/18/26 8:51	136150.8			350.2			35.91			114.44			19.32			1		
03/18/26 8:52	168006.5			266.1			48.04			107.83			32.03			1		
03/18/26 8:53	204766.2			698.4			55.5			342.07			44.73			1		
03/18/26 8:54	231660.2			465.2			55.02			257.53			50.12			1		
03/18/26 8:55	258086.3			49.5			53.87			30.63			54.85			1		
03/18/26 8:56	281901.6			2.6			49.58			1.76			55.15			1		
03/18/26 8:57	306277.1			1.2			27.67			0.89			33.34			1		
03/18/26 8:58	330242.6			1.2			18.07			0.96			23.39			1		
03/18/26 8:59	350026			1.2			15.36			1.01			21.1			1		
03/18/26 9:00	366569.1			1.4			12.05			1.25			17.35			1		
03/18/26 9:01	374407.3			1.6			10.54			1.43			15.47			1		
03/18/26 9:02	381142.4			1.5			9.49			1.4			14.2			1		
03/18/26 9:03	383464.5			1.4			9.15			1.25			13.79			1		
03/18/26 9:04	383724.4			1.3			8.72			1.18			13.17			1		
03/18/26 9:05	383135.2			1.2			8.59			1.11			12.93			1		
03/18/26 9:06	381419.7			1.1			8.07			1.03			12.1			1		
03/18/26 9:07	381714.3			1			7.9			0.95			11.83			1		
03/18/26 9:08	381026.9			1			7.81			0.95			11.69			1		
03/18/26 9:09	380478.2			1.1			7.75			0.96			11.6			1		
03/18/26 9:10	379796.6			1			7.46			0.87			11.16			1		

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/18/26 9:11	378959			1			7.38			0.86			10.99			1		
03/18/26 9:12	378843.5			1			7.4			0.87			10.98			1		
03/18/26 9:13	379392.2			0.9			7.31			0.8			10.92			1		
03/18/26 9:14	375851.4			0.9			7.29			0.78			10.79			1		
03/18/26 9:15	371941			0.9			7.04			0.78			10.32			1		
03/18/26 9:16	377474.5			0.9			6.87			0.8			10.21			1		
03/18/26 9:17	377919.3			0.8			7.22			0.72			10.73			1		
03/18/26 9:18	376804.5			0.8			7.22			0.71			10.7			1		
03/18/26 9:19	377260.8			0.9			7.11			0.78			10.55			1		
03/18/26 9:20	377076			0.9			7.22			0.79			10.7			1		
03/18/26 9:21	376411.7			0.9			7.04			0.79			10.41			1		
03/18/26 9:22	376741			0.8			4.93			0.71			7.29			1		
03/18/26 9:23	377884.6			0.8			2.64			0.72			3.93			1		
03/18/26 9:24	376943.1			0.8			2.38			0.71			3.53			1		
03/18/26 9:25	376538.8			0.8			2.29			0.71			3.39			1		
03/18/26 9:26	376781.4			0.8			2.23			0.72			3.31			1		
03/18/26 9:27	376925.8			0.8			1.94			0.71			2.87			1		
03/18/26 9:28	375637.7			0.8			1.67			0.71			2.47			1		
03/18/26 9:29	375793.7			0.8			1.5			0.71			2.21			1		
03/18/26 9:30	375978.5			0.8			1.32			0.71			1.95			1		
03/18/26 9:31	374909.9			0.8			1.23			0.71			1.82			1		
03/18/26 9:32	374638.4			0.8			1.23			0.71			1.82			1		
03/18/26 9:33	374673.1			0.8			1.23			0.71			1.82			1		
03/18/26 9:34	374436.3			0.8			1.32			0.71			1.95			1		
03/18/26 9:35	374967.6			0.8			1.34			0.72			1.98			1		
03/18/26 9:36	375626.1			0.8			1.41			0.71			2.08			1		
03/18/26 9:37	373858.6			0.8			1.43			0.72			2.11			1		
03/18/26 9:38	375522.2			0.8			1.52			0.72			2.25			0		
03/18/26 9:39	373864.4			0.8			1.61			0.72			2.36			0		
03/18/26 9:40	374719.3			0.8			1.61			0.72			2.37			0		
03/18/26 9:41	374961.9			0.8			1.59			0.71			2.34			0		
03/18/26 9:42	374424.7			0.8			1.61			0.72			2.37			0		

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/18/26 13:51	371259.4			0.6			1.43			0.56			2.11			0		
03/18/26 13:52	371738.8			0.6			1.36			0.57			2.01			0		
03/18/26 13:53	371813.9			0.6			1.45			0.57			2.14			0		
03/18/26 13:54	372108.5			0.6			1.43			0.56			2.11			0		
03/18/26 13:55	371374.9			0.6			1.54			0.57			2.28			0		
03/18/26 13:56	368868			0.6			1.72			0.57			2.52			1		
03/18/26 13:57	355386.4			0.6			1.82			0.54			2.56			1		
03/18/26 13:58	333719.8			0.6			1.97			0.5			2.61			1		
03/18/26 13:59	309650.4			0.7			2.06			0.54			2.54			1		
03/18/26 14:00	285875.6			0.6			3.13			0.45			3.57			1		
03/18/26 14:01	263931.8			0.6			5.14			0.37			5.43			1		
03/18/26 14:02	237499.9			0.5			9.8			0.29			9.34			1		
03/18/26 14:03	214799.5			0.3			20.76			0.17			17.97			1		
03/18/26 14:04	190626.1			13			32.75			6.1			25.26			1		
03/18/26 14:05	167746.6			240.6			36.88			99.94			25.21			1		
03/18/26 14:06	148078.6			993.7			43.01			366.57			26.11			1		
03/18/26 14:07	121727.6			1620.2			44.77			496.88			22.6			1		
03/18/26 14:08	0			0			46.11			35.76			1.46			0		
03/18/26 14:09	0			0			41.3			148.9			1.31			0		
03/18/26 14:10	0			0			0.3			0			0			0		
03/18/26 14:11	0			0			0.2			0			0			0		
03/18/26 14:12	0			0			0.2			0			0			0		

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M		CT2_CO_Ppmvdc_1M		CT2_NOx_Ppmvdc_1M		CT2_CO_LbPerHr_1M		CT2_NOx_LbPerHr_1M		CT2_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
03/26/26 8:39	0		0		0		0		0		0	
03/26/26 8:40	0		0		0		0		0		0	
03/26/26 8:41	0		0		0		0		0		0	
03/26/26 8:42	0		0		0		0		0		0	
03/26/26 8:43	4805.8		0		0		0		0		0	
03/26/26 8:44	5897.5		-0.1		0		0		0		1	
03/26/26 8:45	0		0		0		0		0		1	
03/26/26 8:46	23197.2		1421.9		15.73		98.03		1.79		1	
03/26/26 8:47	42079.6		1127.7		14.33		127.99		2.68		1	
03/26/26 8:48	55440		737.2		17.37		106.93		4.15		1	
03/26/26 8:49	69909.3		498		21.24		89.28		6.27		1	
03/26/26 8:50	109181.7		408.2		25.29		111.03		11.32		1	
03/26/26 8:51	150059.8		296.7		32.2		109.26		19.52		1	
03/26/26 8:52	154883		267.7		38.86		101.64		24.28		1	
03/26/26 8:53	173309		1722.4		34.02		729.08		23.7		1	
03/26/26 8:54	194380.6		1872.1		36.69		885.92		28.57		1	
03/26/26 8:55	215261.6		1054.7		44.97		551.25		38.68		1	
03/26/26 8:56	237956.3		281.7		55.91		162.35		53.04		1	
03/26/26 8:57	260379.4		29		58.5		18.24		60.56		1	
03/26/26 8:58	287568		3.2		53.79		2.25		61.38		1	
03/26/26 8:59	312359.5		2		32.98		1.51		40.82		1	
03/26/26 9:00	336954.5		1.8		21.13		1.46		28.16		1	
03/26/26 9:01	355617.4		1.8		18.4		1.5		25.87		1	
03/26/26 9:02	368238.4		1.8		14.88		1.59		21.64		1	
03/26/26 9:03	369751.8		1.9		13.51		1.67		19.73		1	
03/26/26 9:04	369393.6		1.8		13.1		1.62		19.12		1	
03/26/26 9:05	367429.8		1.6		12.41		1.45		18		1	
03/26/26 9:06	368619.6		1.6		11.8		1.38		17.2		1	
03/26/26 9:07	367868.7		1.4		11.28		1.23		16.4		1	
03/26/26 9:08	370392.9		1.3		11.36		1.17		16.62		1	
03/26/26 9:09	378404.5		1.2		10.04		1.12		15		1	
03/26/26 9:10	381645		1.1		9.16		1.05		13.81		1	

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/26/26 9:11	381223.3			1.1			9.16			0.97			13.79			1		
03/26/26 9:12	381206			1			9.42			0.89			14.19			1		
03/26/26 9:13	380801.6			1			9.42			0.89			14.17			1		
03/26/26 9:14	381021.1			1			9.25			0.89			13.91			1		
03/26/26 9:15	380709.2			1			8.98			0.89			13.51			1		
03/26/26 9:16	380564.8			0.9			8.63			0.8			12.97			1		
03/26/26 9:17	380131.6			0.9			8.54			0.8			12.83			1		
03/26/26 9:18	380120			0.9			8.37			0.8			12.57			1		
03/26/26 9:19	378716.4			0.9			8.4			0.81			12.59			1		
03/26/26 9:20	378624			0.9			8.19			0.8			12.26			1		
03/26/26 9:21	379623.3			0.9			8.31			0.82			12.48			1		
03/26/26 9:22	378855			0.8			8.31			0.73			12.45			1		
03/26/26 9:23	378924.4			0.8			8.31			0.73			12.47			1		
03/26/26 9:24	379149.6			0.8			8.1			0.72			12.15			1		
03/26/26 9:25	378468			0.8			8.31			0.73			12.44			1		
03/26/26 9:26	377272.4			0.8			8.19			0.72			12.22			1		
03/26/26 9:27	378901.3			0.8			5.64			0.72			8.45			1		
03/26/26 9:28	377520.8			0.8			2.73			0.72			4.08			1		
03/26/26 9:29	377590.1			0.8			2.5			0.73			3.74			1		
03/26/26 9:30	377543.8			0.8			2.59			0.73			3.87			1		
03/26/26 9:31	377902			0.8			2.86			0.73			4.28			1		
03/26/26 9:32	377480.3			0.8			3.04			0.73			4.54			1		
03/26/26 9:33	377076			0.8			3.22			0.73			4.8			1		
03/26/26 9:34	376741			0.8			3.4			0.73			5.06			1		
03/26/26 9:35	376625.4			0.8			3.67			0.73			5.46			1		
03/26/26 9:36	376382.9			0.8			3.75			0.73			5.59			1		
03/26/26 9:37	377006.7			0.8			3.13			0.73			4.67			1		
03/26/26 9:38	376192.2			0.7			2.68			0.65			3.99			1		
03/26/26 9:39	376296.2			0.7			2.15			0.65			3.19			1		
03/26/26 9:40	376325.1			0.7			2.06			0.65			3.06			1		
03/26/26 9:41	376856.5			0.7			2.06			0.65			3.07			1		
03/26/26 9:42	376273.1			0.7			2.06			0.65			3.06			1		
03/26/26 9:43	377647.8			0.7			2.06			0.65			3.07			1		
03/26/26 9:44	376943.1			0.8			2.06			0.73			3.07			1		
03/26/26 9:45	375528			0.8			1.97			0.73			2.92			1		

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/26/26 9:46	376816.1			0.7			1.79			0.65			2.67			1		
03/26/26 9:47	376030.5			0.7			1.5			0.64			2.23			1		
03/26/26 9:48	377047.1			0.7			1.32			0.64			1.97			1		
03/26/26 9:49	377526.5			0.7			1.16			0.65			1.74			1		
03/26/26 9:50	377272.4			0.7			1.07			0.65			1.6			1		
03/26/26 9:51	375828.3			0.7			0.98			0.65			1.46			1		
03/26/26 9:52	375863			0.7			0.98			0.65			1.46			1		
03/26/26 9:53	376931.5			0.7			0.89			0.65			1.33			1		
03/26/26 9:54	377179.9			0.7			0.98			0.65			1.47			1		
03/26/26 9:55	377463			0.7			0.98			0.65			1.47			0		
03/26/26 9:56	376400.2			0.8			0.98			0.73			1.47			0		
03/26/26 9:57	376845			0.7			1.07			0.65			1.6			0		
03/26/26 9:58	375504.8			0.7			1.07			0.65			1.6			0		
03/26/26 9:59	375637.7			0.7			1.14			0.64			1.7			0		

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M		CT2_CO_Ppmvdc_1M		CT2_NOx_Ppmvdc_1M		CT2_CO_LbPerHr_1M		CT2_NOx_LbPerHr_1M		CT2_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
03/26/26 12:45	374632.7		0.7		1.54		0.66		2.29		0	
03/26/26 12:46	376007.4		0.7		1.54		0.66		2.29		0	
03/26/26 12:47	373864.4		0.7		1.54		0.65		2.28		0	
03/26/26 12:48	374551.8		0.7		1.54		0.65		2.29		0	
03/26/26 12:49	374187.9		0.7		1.54		0.65		2.28		0	
03/26/26 12:50	369832.6		0.7		1.52		0.63		2.21		1	
03/26/26 12:51	350372.6		0.7		1.54		0.61		2.14		1	
03/26/26 12:52	326343.6		0.7		1.61		0.56		2.08		1	
03/26/26 12:53	302528.4		0.7		2		0.53		2.4		1	
03/26/26 12:54	278285.7		0.7		3.09		0.51		3.44		1	
03/26/26 12:55	254262.4		0.6		4.93		0.36		5		1	
03/26/26 12:56	230701.4		0.4		11.06		0.24		10.23		1	
03/26/26 12:57	205834.8		2.4		23.6		1.23		19.59		1	
03/26/26 12:58	181956		81.3		30.01		36.61		22.24		1	
03/26/26 12:59	162675.1		591.6		34.68		240.08		23.16		1	
03/26/26 13:00	143371		1336		39.99		483.88		23.84		1	
03/26/26 13:01	66784.4		1719		46.44		312.45		13.89		1	
03/26/26 13:02	0		0		49.28		47.11		2.03		0	
03/26/26 13:03	0		0		0.4		0		0		0	
03/26/26 13:04	0		0		0.3		0		0		0	
03/26/26 13:05	0		0		0.3		0		0		0	
03/26/26 13:06	0		0		0.2		0		0		0	