

DOCKETED	
Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	269693
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q1 2026 - Part 1s
Description:	N/A
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public Agency
Submission Date:	4/29/2026 9:55:04 AM
Docketed Date:	4/29/2026



REP

**Roseville Energy Park
(03-AFC-01C)**

Quarterly Air Quality Report

2026-Q1

Reporting Period: January 1, 2026 – March 31, 2026

Prepared on: April 1, 2026

Submitted to:

California Energy Commission

QUARTERLY AIR QUALITY REPORT

Part I. Identification

- a. Quarterly emission report period: **JANUARY 1, 2026 – MARCH 31, 2026**
- b. Reporting date: **APRIL 1, 2026**
- c. Person completing report: **JULIE MANFREDI**
- d. Plant name: **ROSEVILLE ENERGY PARK**
- e. Plant location:

**5120 PHILLIP ROAD
ROSEVILLE, CA 95747**

- f. Person responsible for review and integrity of report: **NATHAN RIBORDY**
- g. Mailing address of report reviewer:

**5120 PHILLIP ROAD
ROSEVILLE, CA 95747**

- h. Telephone number of report reviewer: **916-746-1673**

Part II. Measuring Instrumentation Information:

Monitor	Type	Manufacturer	Serial No.	Model No.	Available for Operation
Combustion Turbine Generator #1 (CT1)	Natl Gas Fired, Combined Cycle with Dry Low Nox Combustors	Siemens	B005712	SGT800	2007
CT1 SCR Catalyst	Ammonia Injection System within the Heat Recovery Steam Generator	Peerless	70373		2007
CT1 Oxidation Catalyst			017421-CV		2007
Combustion Turbine Generator #2 (CT2)	Natl Gas Fired, Combined Cycle with Dry Low Nox Combustors	Siemens	B005713	SGT800	2007
CT2 SCR Catalyst	Ammonia Injection System within the Heat Recovery Steam Generator	Peerless	70373		2007
CT2 Oxidation Catalyst			017421-CV		2007
EMERGENCY GENERATOR ENGINE	Diesel Engine	Caterpillar	AFN01451	3412CDITA	2007
FIRE PUMP ENGINE	Diesel Engine	Clarke	CD6068B003958	JU6H-UF60	2007

Part III. Excess Emissions by Pollutant

SEE ATTACHED

Part IV. CEMS Span and Range

Combined-Cycle Turbine CEMS Span and Range

GAS	SPAN VALUE	RANGE
SCR Inlet NOx	30 ppm	0-30 ppm
	200 ppm	0-200 ppm
Stack NOx	10 ppm	0-10 ppm
	200 ppm	0-200 ppm
Oxygen	20.9%	0-25%
CO	10 ppm	0-10 ppm
	200 ppm	0-200 ppm

Part V. Types of Fuels Combusted

NATURAL GAS

Part VI. Continuous Emissions Monitoring System Operation Changes and Failures

SEE ATTACHED

Part VII. Certification of Report Integrity by Reviewer

**THIS IS TO CERTIFY THAT TO THE BEST OF MY
KNOWLEDGE THE INFORMATION PROVIDED IN THE
ABOVE REPORT IS BOTH COMPLETE AND ACCURATE.**

NAME: NATHAN RIBORDY



[Nathan Ribordy \(Apr 29, 2026 07:26:56 PDT\)](#)

TITLE: POWER GENERATION SUPERINTENDENT

DATE: APRIL 22, 2026

LIST OF ATTACHMENTS

I. PERMIT CONDITIONS (OTHER)

REP CONDITION #	DESCRIPTION
AQ-20	Sulfur content of fuel
AQ-21	Startup and shutdown emission limits
AQ-47, AQ-69, AQ-90 & AQ-103	No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.
AQ-48, AQ-91 & AQ-104	Stack emissions opacity, nuisance complaints for more than 3 minutes
AQ-86	Diesel Fire pump maintenance and testing log, limited to 50 hours per year
AQ-87	Diesel Fire pump operation limited to 24 hours.
AQ-88 & AQ-101	Sulfur content of diesel fuel
AQ-89 & AQ-102	Diesel engine operation and maintenance records
AQ-99	Emergency Generator maintenance and testing log, limited to 50 hours per year. Logs kept for 5 years.
AQ-100	Emergency Generator operation limited to 24 hours.

II. EMISSIONS OVERVIEW

REP CONDITION #	DESCRIPTION
AQ-15	Selective catalytic reduction (SCR) system and an oxidation catalyst on the gas turbine
AQ-32	NOX & CO Hourly/Daily/Quarterly Emissions
AQ-33	SOX - Hourly/Daily/Quarterly Emissions
AQ-51	Ammonia slip exceedances
AQ-54 thru AQ-63 & AQ-71 (AQ-SC6)	Fuel use emission and operational data - Hourly/Daily/Quarterly
AQ-70	PM10 emissions rate from cooling tower shall not exceed lbs per day or quarter limits

III. EMISSIONS DEVIATIONS

REP CONDITION #	DESCRIPTION
AQ-34	Records: occurrence, duration, and type of any startup, shutdown, or malfunction; performance testing, evaluations, calibrations, checks, adjustments, any period during which a continuous monitoring system or monitoring device was inoperative, maintenance of any continuous emission monitor; emission measurements, total daily and rolling twelve-month average hours of operation, hourly quantity of fuel used, and gross three-hour average operating load.
AQ-36 thru AQ-38, AQ-41, & AQ-117	PCAPCD notifications/corrective action: breakdowns, excess emissions, CEMS inoperable, or a negative declaration when no excess emissions occurred.
AQ-40	CEMS quality assurance test failures

I. Permit Conditions (Other)

AQ-20

AQ-20 The gas turbine engine shall be fired exclusively on pipeline quality natural gas with sulfur content no greater than 0.50 grains of sulfur compounds per 100 dry scf of natural gas.

Verification: The Project owner shall submit to the CPM the most recent fuel testing analysis performed as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

AQ20 ROSEVILLE ENERGY PARK

1Q26

Fuel Quality Analysis BTU values

<http://www.pge.com/pij>

	JAN	FEB	MAR
1	1057.78	1058.69	1055.07
2	1055.48	1056.59	1055.54
3	1058.68	1055.92	1051.97
4	1058.75	1055.53	1054.33
5	1058.50	1055.47	1054.94
6	1058.03	1053.59	1049.00
7	1060.31	1054.07	1047.39
8	1057.97	1050.52	1046.16
9	1057.50	1051.30	1040.81
10	1054.22	1050.46	1039.42
11	1056.19	1046.17	1040.39
12	1058.96	1047.12	1039.74
13	1057.94	1,047.21	1038.02
14	1055.68	1047.30	1038.64
15	1055.73	1048.47	1042.88
16	1055.57	1049.46	1045.93
17	1058.51	1056.04	1046.65
18	1053.79	1054.94	1044.79
19	1055.72	1053.10	1043.55
20	1056.34	1053.44	1040.65
21	1054.69	1054.61	1039.95
22	1054.07	1057.29	1039.40
23	1053.10	1058.99	1039.30
24	1054.08	1056.87	1041.43
25	1054.45	1057.21	1040.14
26	1056.30	1057.63	1041.14
27	1056.91	1056.74	1041.78
28	1055.40	1054.78	1043.15
29	1055.23	N/A	1044.22
30	1057.39	N/A	1062.16
31	1059.27	N/A	1047.25

baseline/operations/gas_quality/p01_2_weeks.shtml



Survey Results

Note: Starting Q4 2022, we began breaking sulfur data down monthly. Data will still be updated on a quarterly basis just with additional granularit

Jump to:

[2021 - 2026](#)

[2016 - 2020](#)

[2011 - 2015](#)

[2006 - 2010](#)

2021 - 2026

2026

Date	Total Sulfur Maximum		Total Sulfur Average all sites	
	PPMv	gr/100 scf	PPMv	gr/100 scf
2026				
First Quarter	4.1	0.24	3.0	0.18
First Quarter - January	3.8	0.22	3.2	0.19
First Quarter - February	3.8	0.23	3.0	0.18
First Quarter - March	4.1	0.24	2.8	0.17

AQ-21

AQ-21 Startup is defined as the period beginning with the turbine light-off until the unit meets the lb/hr and ppmv emission limits in Conditions of Certification AQ-52, -54 and -55. Shutdown is defined as the period beginning with initiation of turbine shutdown sequence and ending with cessation of firing of the gas turbine engine. Startup and shutdown durations shall not exceed 3.0 hours and one hour, respectively, per occurrence.

Verification: The Project owner shall identify and submit to the CPM as part of the Quarterly Air Quality Report all startups and shutdowns for all units including the maximum hourly emission rate, total emissions and duration.

Startup / Shutdown Events

CT1



From: 01/01/2026 00:00 **To:** 03/31/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/23/2026 17:00 **Location:** Roseville, CA

Unit offline

Tag Name: CT1_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
01/01/2026 00:00	03/11/2026 05:00	1662
03/11/2026 11:00	03/13/2026 14:00	52
03/13/2026 21:00	03/15/2026 09:00	37
03/15/2026 16:00	03/31/2026 23:00	392

Startup / Shutdown Events

CT1



From: 01/01/2026 00:00 **To:** 03/31/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/23/2026 17:00 **Location:** Roseville, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,160.00 Hour(s)
Total Offline:	2,143.00 Hour(s)
Offline Percentage:	99.21 %
Total Online:	17.00 Hour(s)
Online Percentage:	0.79 %

Startup / Shutdown Events

CT1



From: 01/01/2026 00:00 **To:** 03/31/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/23/2026 17:00 **Location:** Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	03/11/2026 06:45	03/11/2026 07:55	Cold Startup	71
2	03/11/2026 10:06	03/11/2026 10:07	Shutdown	2
3	03/13/2026 15:45	03/13/2026 16:50	Cold Startup	66
4	03/13/2026 19:53	03/13/2026 20:08	Shutdown	16
5	03/15/2026 10:45	03/15/2026 11:51	Cold Startup	67
6	03/15/2026 14:50	03/15/2026 15:06	Shutdown	17

Startup / Shutdown Events

CT1



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
Generated: 04/23/2026 17:00 Location: Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	3	204	27.98
Warm Startup	0		0.00
Shutdown	3	35	4.80
Total Process Events:	6	239	32.78

Total Report Time: 2,159.98 Hour(s)
Total Operating Time: 12.15 Hour(s)
Total Startup Time: 204 Minute(s)
Total Shutdown Time: 35 Minute(s)
Total Startup/Shutdown Time: 239 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time: 32.78 %

Startup / Shutdown Events

CT2



From: 01/01/2026 00:00 **To:** 03/31/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/23/2026 17:00 **Location:** Roseville, CA

Unit offline

Tag Name: CT2_UnitOn_TF_1H

Offline Periods		
Start Time	End Time	Duration in Hour(s)
01/01/2026 00:00	03/11/2026 11:00	1668
03/11/2026 16:00	03/12/2026 05:00	14
03/12/2026 12:00	03/17/2026 09:00	118
03/17/2026 18:00	03/18/2026 07:00	14
03/18/2026 15:00	03/26/2026 07:00	185
03/26/2026 14:00	03/31/2026 23:00	130

Startup / Shutdown Events

CT2



From: 01/01/2026 00:00 **To:** 03/31/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/23/2026 17:00 **Location:** Roseville, CA

Operating Time Summary

Available Data for Report (excludes missing data):	2,160.00 Hour(s)
Total Offline:	2,129.00 Hour(s)
Offline Percentage:	98.56 %
Total Online:	31.00 Hour(s)
Online Percentage:	1.44 %

Startup / Shutdown Events

CT2



From: 01/01/2026 00:00 **To:** 03/31/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/23/2026 17:00 **Location:** Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	03/11/2026 12:44	03/11/2026 13:59	Cold Startup	76
2	03/11/2026 15:54	03/11/2026 15:57	Shutdown	4
3	03/12/2026 06:48	03/12/2026 07:52	Cold Startup	65
4	03/12/2026 10:56	03/12/2026 11:11	Shutdown	16
5	03/17/2026 10:44	03/17/2026 11:50	Cold Startup	67
6	03/17/2026 16:58	03/17/2026 17:10	Shutdown	13
7	03/18/2026 08:44	03/18/2026 09:37	Cold Startup	54
8	03/18/2026 13:56	03/18/2026 14:07	Shutdown	12
9	03/26/2026 08:44	03/26/2026 09:54	Cold Startup	71
10	03/26/2026 12:50	03/26/2026 13:01	Shutdown	12

Startup / Shutdown Events

CT2



From: 01/01/2026 00:00 **To:** 03/31/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 04/23/2026 17:00 **Location:** Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	5	333	23.40
Warm Startup	0		0.00
Shutdown	5	57	4.01
Total Process Events:	10	390	27.41

Total Report Time: 2,159.98 Hour(s)
Total Operating Time: 23.72 Hour(s)
Total Startup Time: 333 Minute(s)
Total Shutdown Time: 57 Minute(s)
Total Startup/Shutdown Time: 390 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time: 27.41 %

Monthly Summary By Day Report

Units CT1 and CT2

From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:03 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
01/01/2026	0.00	0.00	0.00	0.00	0.00
01/02/2026	0.00	0.00	0.00	0.00	0.00
01/03/2026	0.00	0.00	0.00	0.00	0.00
01/04/2026	0.00	0.00	0.00	0.00	0.00
01/05/2026	0.00	0.00	0.00	0.00	0.00
01/06/2026	0.00	0.00	0.00	0.00	0.00
01/07/2026	0.00	0.00	0.00	0.00	0.00
01/08/2026	0.00	0.00	0.00	0.00	0.00
01/09/2026	0.00	0.00	0.00	0.00	0.00
01/10/2026	0.00	0.00	0.00	0.00	0.00
01/11/2026	0.00	0.00	0.00	0.00	0.00
01/12/2026	0.00	0.00	0.00	0.00	0.00
01/13/2026	0.00	0.00	0.00	0.00	0.00
01/14/2026	0.00	0.00	0.00	0.00	0.00
01/15/2026	4.63	9.67	0.67	1.23	2.26
01/16/2026	0.00	0.00	0.00	0.00	0.00
01/17/2026	0.00	0.00	0.00	0.00	0.00
01/18/2026	0.00	0.00	0.00	0.00	0.00
01/19/2026	9.96	18.07	0.71	1.36	2.41
01/20/2026	8.33	15.51	0.99	1.85	3.32
01/21/2026	0.00	0.00	0.00	0.00	0.00
01/22/2026	0.00	0.00	0.00	0.00	0.00
01/23/2026	34.02	68.73	4.84	8.87	16.28
01/24/2026	5.23	6.82	0.43	0.76	1.43
01/25/2026	16.64	38.47	2.61	4.72	8.69
01/26/2026	17.72	47.69	3.28	6.05	10.98
01/27/2026	19.64	55.13	3.98	7.23	13.38
01/28/2026	0.00	0.00	0.00	0.00	0.00
01/29/2026	0.00	0.00	0.00	0.00	0.00
01/30/2026	0.00	0.00	0.00	0.00	0.00
01/31/2026	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum:	116.17 sum	260.09 sum	17.51 sum	32.07 sum	58.75 sum
Daily Min:	0.00	0.00	0.00	0.00	0.00
Daily Max:	34.02	68.73	4.84	8.87	16.28
Jan 2026 - Jan 2026	116.17 sum	260.09 sum	17.51 sum	32.07 sum	58.75 sum
QTD:	116.17 sum	260.09 sum	17.51 sum	32.07 sum	58.75 sum
YTD 2026:	116.17 sum	260.09 sum	17.51 sum	32.07 sum	58.75 sum

Monthly Summary By Day Report

Units CT1 and CT2

From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:03 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
02/01/2026	0.00	0.00	0.00	0.00	0.00
02/02/2026	0.00	0.00	0.00	0.00	0.00
02/03/2026	0.00	0.00	0.00	0.00	0.00
02/04/2026	6.88	16.90	1.15	2.16	3.88
02/05/2026	6.43	16.65	1.17	2.13	3.87
02/06/2026	0.00	0.00	0.00	0.00	0.00
02/07/2026	0.00	0.00	0.00	0.00	0.00
02/08/2026	0.00	0.00	0.00	0.00	0.00
02/09/2026	0.00	0.00	0.00	0.00	0.00
02/10/2026	0.00	0.00	0.00	0.00	0.00
02/11/2026	0.00	0.00	0.00	0.00	0.00
02/12/2026	0.00	0.00	0.00	0.00	0.00
02/13/2026	0.00	0.00	0.00	0.00	0.00
02/14/2026	0.00	0.00	0.00	0.00	0.00
02/15/2026	0.00	0.00	0.00	0.00	0.00
02/16/2026	0.00	0.00	0.00	0.00	0.00
02/17/2026	0.00	0.00	0.00	0.00	0.00
02/18/2026	0.00	0.00	0.00	0.00	0.00
02/19/2026	0.00	0.00	0.00	0.00	0.00
02/20/2026	0.00	0.00	0.00	0.00	0.00
02/21/2026	0.00	0.00	0.00	0.00	0.00
02/22/2026	0.00	0.00	0.00	0.00	0.00
02/23/2026	0.00	0.00	0.00	0.00	0.00
02/24/2026	0.00	0.00	0.00	0.00	0.00
02/25/2026	0.00	0.00	0.00	0.00	0.00
02/26/2026	0.00	0.00	0.00	0.00	0.00
02/27/2026	0.00	0.00	0.00	0.00	0.00
02/28/2026	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum:	13.31 sum	33.55 sum	2.32 sum	4.29 sum	7.75 sum
Daily Min:	0.00	0.00	0.00	0.00	0.00
Daily Max:	6.88	16.90	1.17	2.16	3.88
Jan 2026 - Feb 2026	129.48 sum	293.64 sum	19.83 sum	36.36 sum	66.50 sum
QTD:	129.48 sum	293.64 sum	19.83 sum	36.36 sum	66.50 sum
YTD 2026:	129.48 sum	293.64 sum	19.83 sum	36.36 sum	66.50 sum

Monthly Summary By Day Report

Units CT1 and CT2

From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 08:03 Location: Roseville, CA



Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
03/01/2026	0.00	0.00	0.00	0.00	0.00
03/02/2026	0.00	0.00	0.00	0.00	0.00
03/03/2026	0.00	0.00	0.00	0.00	0.00
03/04/2026	0.00	0.00	0.00	0.00	0.00
03/05/2026	0.00	0.00	0.00	0.00	0.00
03/06/2026	0.00	0.00	0.00	0.00	0.00
03/07/2026	0.00	0.00	0.00	0.00	0.00
03/08/2026	0.00	0.00	0.00	0.00	0.00
03/09/2026	0.00	0.00	0.00	0.00	0.00
03/10/2026	0.00	0.00	0.00	0.00	0.00
03/11/2026	305.93	49.78	1.60	3.20	5.35
03/12/2026	78.53	22.72	1.19	2.35	3.93
03/13/2026	64.55	22.23	1.12	2.28	3.79
03/14/2026	0.00	0.00	0.00	0.00	0.00
03/15/2026	98.33	24.60	1.10	2.22	3.68
03/16/2026	0.00	0.00	0.00	0.00	0.00
03/17/2026	51.65	26.05	1.45	2.92	4.85
03/18/2026	43.40	22.47	1.22	2.41	4.03
03/19/2026	0.00	0.00	0.00	0.00	0.00
03/20/2026	0.00	0.00	0.00	0.00	0.00
03/21/2026	0.00	0.00	0.00	0.00	0.00
03/22/2026	0.00	0.00	0.00	0.00	0.00
03/23/2026	0.00	0.00	0.00	0.00	0.00
03/24/2026	0.00	0.00	0.00	0.00	0.00
03/25/2026	0.00	0.00	0.00	0.00	0.00
03/26/2026	70.95	23.66	0.97	1.93	3.21
03/27/2026	0.00	0.00	0.00	0.00	0.00
03/28/2026	0.00	0.00	0.00	0.00	0.00
03/29/2026	0.00	0.00	0.00	0.00	0.00
03/30/2026	0.00	0.00	0.00	0.00	0.00
03/31/2026	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum:	713.34 sum	191.51 sum	8.65 sum	17.31 sum	28.84 sum
Daily Min:	0.00	0.00	0.00	0.00	0.00
Daily Max:	305.93	49.78	1.60	3.20	5.35
Jan 2026 - Mar 2026	842.82 sum	485.15 sum	28.48 sum	53.67 sum	95.34 sum
QTD:	842.82 sum	485.15 sum	28.48 sum	53.67 sum	95.34 sum
YTD 2026:	842.82 sum	485.15 sum	28.48 sum	53.67 sum	95.34 sum

Monthly Summary By Day Report



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO_SUSD, LbPerHr	NOX_SUSD, LbPerHr	CO_SUSD, LbPerHr	NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
01/01/2026	0.0	0.0	0.0	0.0
01/02/2026	0.0	0.0	0.0	0.0
01/03/2026	0.0	0.0	0.0	0.0
01/04/2026	0.0	0.0	0.0	0.0
01/05/2026	0.0	0.0	0.0	0.0
01/06/2026	0.0	0.0	0.0	0.0
01/07/2026	0.0	0.0	0.0	0.0
01/08/2026	0.0	0.0	0.0	0.0
01/09/2026	0.0	0.0	0.0	0.0
01/10/2026	0.0	0.0	0.0	0.0
01/11/2026	0.0	0.0	0.0	0.0
01/12/2026	0.0	0.0	0.0	0.0
01/13/2026	0.0	0.0	0.0	0.0
01/14/2026	0.0	0.0	0.0	0.0
01/15/2026	0.0	0.0	0.0	0.0
01/16/2026	0.0	0.0	0.0	0.0
01/17/2026	0.0	0.0	0.0	0.0
01/18/2026	0.0	0.0	0.0	0.0
01/19/2026	0.0	0.0	0.0	0.0
01/20/2026	0.0	0.0	0.0	0.0
01/21/2026	0.0	0.0	0.0	0.0
01/22/2026	0.0	0.0	0.0	0.0
01/23/2026	0.0	0.0	0.0	0.0
01/24/2026	0.0	0.0	0.0	0.0
01/25/2026	0.0	0.0	0.0	0.0
01/26/2026	0.0	0.0	0.0	0.0
01/27/2026	0.0	0.0	0.0	0.0
01/28/2026	0.0	0.0	0.0	0.0
01/29/2026	0.0	0.0	0.0	0.0
01/30/2026	0.0	0.0	0.0	0.0
01/31/2026	0.0	0.0	0.0	0.0
Monthly Avg/Sum:	0.0 sum	0.0 sum	0.0 sum	0.0 sum
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	0.0	0.0	0.0	0.0
Jan 2026 - Jan 2026	0.0 sum	0.0 sum	0.0 sum	0.0 sum
QTD:	0.0 sum	0.0 sum	0.0 sum	0.0 sum
YTD 2026:	0.0 sum	0.0 sum	0.0 sum	0.0 sum

Monthly Summary By Day Report



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO_SUSD, LbPerHr	NOX_SUSD, LbPerHr	CO_SUSD, LbPerHr	NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
02/01/2026	0.0	0.0	0.0	0.0
02/02/2026	0.0	0.0	0.0	0.0
02/03/2026	0.0	0.0	0.0	0.0
02/04/2026	0.0	0.0	0.0	0.0
02/05/2026	0.0	0.0	0.0	0.0
02/06/2026	0.0	0.0	0.0	0.0
02/07/2026	0.0	0.0	0.0	0.0
02/08/2026	0.0	0.0	0.0	0.0
02/09/2026	0.0	0.0	0.0	0.0
02/10/2026	0.0	0.0	0.0	0.0
02/11/2026	0.0	0.0	0.0	0.0
02/12/2026	0.0	0.0	0.0	0.0
02/13/2026	0.0	0.0	0.0	0.0
02/14/2026	0.0	0.0	0.0	0.0
02/15/2026	0.0	0.0	0.0	0.0
02/16/2026	0.0	0.0	0.0	0.0
02/17/2026	0.0	0.0	0.0	0.0
02/18/2026	0.0	0.0	0.0	0.0
02/19/2026	0.0	0.0	0.0	0.0
02/20/2026	0.0	0.0	0.0	0.0
02/21/2026	0.0	0.0	0.0	0.0
02/22/2026	0.0	0.0	0.0	0.0
02/23/2026	0.0	0.0	0.0	0.0
02/24/2026	0.0	0.0	0.0	0.0
02/25/2026	0.0	0.0	0.0	0.0
02/26/2026	0.0	0.0	0.0	0.0
02/27/2026	0.0	0.0	0.0	0.0
02/28/2026	0.0	0.0	0.0	0.0
Monthly Avg/Sum:	0.0 sum	0.0 sum	0.0 sum	0.0 sum
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	0.0	0.0	0.0	0.0
Jan 2026 - Feb 2026	0.0 sum	0.0 sum	0.0 sum	0.0 sum
QTD:	0.0 sum	0.0 sum	0.0 sum	0.0 sum
YTD 2026:	0.0 sum	0.0 sum	0.0 sum	0.0 sum

Monthly Summary By Day Report



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY
 Generated: 04/01/2026 08:03 Location: Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1	Unit CT1	Unit CT2	Unit CT2
	CO_SUSD, LbPerHr	NOX_SUSD, LbPerHr	CO_SUSD, LbPerHr	NOX_SUSD, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
03/01/2026	0.0	0.0	0.0	0.0
03/02/2026	0.0	0.0	0.0	0.0
03/03/2026	0.0	0.0	0.0	0.0
03/04/2026	0.0	0.0	0.0	0.0
03/05/2026	0.0	0.0	0.0	0.0
03/06/2026	0.0	0.0	0.0	0.0
03/07/2026	0.0	0.0	0.0	0.0
03/08/2026	0.0	0.0	0.0	0.0
03/09/2026	0.0	0.0	0.0	0.0
03/10/2026	0.0	0.0	0.0	0.0
03/11/2026	232.1	19.7	45.4	16.1
03/12/2026	0.0	0.0	70.3	15.2
03/13/2026	65.5	13.8	0.0	0.0
03/14/2026	0.0	0.0	0.0	0.0
03/15/2026	98.2	15.7	0.0	0.0
03/16/2026	0.0	0.0	0.0	0.0
03/17/2026	0.0	0.0	41.3	14.9
03/18/2026	0.0	0.0	41.9	13.5
03/19/2026	0.0	0.0	0.0	0.0
03/20/2026	0.0	0.0	0.0	0.0
03/21/2026	0.0	0.0	0.0	0.0
03/22/2026	0.0	0.0	0.0	0.0
03/23/2026	0.0	0.0	0.0	0.0
03/24/2026	0.0	0.0	0.0	0.0
03/25/2026	0.0	0.0	0.0	0.0
03/26/2026	0.0	0.0	71.2	17.0
03/27/2026	0.0	0.0	0.0	0.0
03/28/2026	0.0	0.0	0.0	0.0
03/29/2026	0.0	0.0	0.0	0.0
03/30/2026	0.0	0.0	0.0	0.0
03/31/2026	0.0	0.0	0.0	0.0
Monthly Avg/Sum:	395.8 sum	49.2 sum	270.1 sum	76.7 sum
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	232.1	19.7	71.2	17.0
Jan 2026 - Mar 2026	395.8 sum	49.2 sum	270.1 sum	76.7 sum
QTD:	395.8 sum	49.2 sum	270.1 sum	76.7 sum
YTD 2026:	395.8 sum	49.2 sum	270.1 sum	76.7 sum

Sample Spreadsheet Listing

Date/Time	CT1_GasFlow_CT_scfh_1M		CT1_CO_Ppmvdc_1M		CT1_NOx_Ppmvdc_1M		CT1_CO_LbPerHr_1M		CT1_NOx_LbPerHr_1M		CT1_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
03/11/26 6:40	0		0		0		0		0		0	
03/11/26 6:41	0		0		0		0		0		0	
03/11/26 6:42	0		0		0		0		0		0	
03/11/26 6:43	0		0		0		0		0		0	
03/11/26 6:44	0		0		0		0		0		0	
03/11/26 6:45	2362.5		0.1		0		0		0		1	
03/11/26 6:46	23474.5		0.1		0		0		0		1	
03/11/26 6:47	37285.4		1724.8		3.93		179.53		0.67		1	
03/11/26 6:48	50368.4		1509		4.99		203.69		1.11		1	
03/11/26 6:49	63330.2		976.3		9.37		161.5		2.55		1	
03/11/26 6:50	89692.8		644.7		16.46		146.76		6.17		1	
03/11/26 6:51	133204.9		505.4		22.48		166.88		12.21		1	
03/11/26 6:52	140916.1		395.8		33.28		137.58		19.04		1	
03/11/26 6:53	138386.1		1123.8		37.76		384.11		21.24		1	
03/11/26 6:54	136999.9		2037.7		35.99		690.57		20.07		1	
03/11/26 6:55	135862		2107.7		41.91		709.6		23.22		1	
03/11/26 6:56	135168.8		2107.5		44.35		704.81		24.41		1	
03/11/26 6:57	134435.2		2107.3		50.25		700.97		27.51		1	
03/11/26 6:58	133799.8		2182.2		57.74		721.47		31.42		1	
03/11/26 6:59	133366.6		2182.2		64.27		719.02		34.85		1	
03/11/26 7:00	133020.1		2182.2		65.74		716.09		35.51		1	
03/11/26 7:01	132812.1		2182.2		66.59		714.63		35.89		1	
03/11/26 7:02	132569.5		2182.2		66.38		715.12		35.8		1	
03/11/26 7:03	132176.7		2182.4		64.9		711.77		34.84		1	
03/11/26 7:04	133314.6		2182.4		62.79		716.65		33.94		1	
03/11/26 7:05	147408.6		2182.2		61.74		787.9		36.69		1	
03/11/26 7:06	159954.5		2036.5		61.56		794.56		39.53		1	
03/11/26 7:07	161814.4		1797.1		60.56		710.81		39.42		1	
03/11/26 7:08	166435.4		1697.1		57.36		689.11		38.33		1	
03/11/26 7:09	185069.4		1696.9		56.54		764.25		41.91		1	
03/11/26 7:10	194022.5		969.4		51.18		456.98		39.71		1	
03/11/26 7:11	203275.9		176.6		49.61		87.09		40.27		1	

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/11/26 7:12	222643.6			78.3			48.25			42.16			42.77			1		
03/11/26 7:13	229557.6			20.5			48.89			11.35			44.59			1		
03/11/26 7:14	234144			12.4			58.89			6.98			54.74			1		
03/11/26 7:15	251368.6			10.9			57.91			6.61			57.62			1		
03/11/26 7:16	270251			9			54.15			5.82			57.93			1		
03/11/26 7:17	272006.9			6.7			31.34			4.37			33.73			1		
03/11/26 7:18	286279.9			5.5			22.1			3.8			24.99			1		
03/11/26 7:19	303660.5			4.7			16.88			3.44			20.23			1		
03/11/26 7:20	306762.3			4.2			9.11			3.05			10.96			1		
03/11/26 7:21	306617.9			3.9			6.94			2.86			8.38			1		
03/11/26 7:22	306479.3			3.7			6.07			2.75			7.35			1		
03/11/26 7:23	306773.8			3.6			5.81			2.62			7.05			1		
03/11/26 7:24	306438.8			3.4			5.37			2.53			6.52			1		
03/11/26 7:25	318620.8			3.3			5.02			2.5			6.33			1		
03/11/26 7:26	331542.2			3.2			4.93			2.53			6.47			1		
03/11/26 7:27	335995.6			3.1			4.69			2.51			6.19			1		
03/11/26 7:28	338999.3			3.1			4.6			2.5			6.05			1		
03/11/26 7:29	350297.5			3			4.6			2.44			6.25			1		
03/11/26 7:30	364039.1			2.7			4.31			2.34			6.1			1		
03/11/26 7:31	370029			2.4			4.11			2.11			5.91			1		
03/11/26 7:32	374817.5			2.1			4.05			1.87			5.9			1		
03/11/26 7:33	391071.7			1.8			3.52			1.71			5.35			1		
03/11/26 7:34	401388			1.8			3.4			1.69			5.29			1		
03/11/26 7:35	405841.5			1.6			3.49			1.54			5.49			1		
03/11/26 7:36	419854.5			1.4			3.84			1.42			6.27			1		
03/11/26 7:37	434323.8			1.4			3.72			1.4			6.28			1		
03/11/26 7:38	441353.5			1.4			3.54			1.42			6.07			1		
03/11/26 7:39	453489.3			1.4			2.72			1.46			4.8			1		
03/11/26 7:40	459230.8			1.4			2.45			1.48			4.37			1		
03/11/26 7:41	456319.6			1.3	X		2.23	X		1.41	X		3.95	X		1		
03/11/26 7:42	455551.4			1.4	X		2.11	X		1.47	X		3.73	X		1		
03/11/26 7:43	456839.5			1.2	X		1.91	X		1.27	X		3.38	X		1		
03/11/26 7:44	456718.2			1.2	X		1.88	X		1.25	X		3.33	X		1		
03/11/26 7:45	458260.4			1.4			2.45			1.47			4.36			1		
03/11/26 7:46	458029.4			1.1			1.91			1.18			3.39			1		

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/11/26 7:47	457769.4			1.1			1.88			1.16			3.34			1		
03/11/26 7:48	458393.3			1.1			1.79			1.16			3.18			1		
03/11/26 7:49	458433.7			1.1			1.7			1.16			3.02			1		
03/11/26 7:50	458341.3			1			1.7			1.06			3.02			1		
03/11/26 7:51	458260.5			1			1.79			1.06			3.18			1		
03/11/26 7:52	458555			1			1.79			1.06			3.18			1		
03/11/26 7:53	458162.3			1			1.79			1.06			3.18			1		
03/11/26 7:54	458601.3			1			1.7			1.06			3.02			1		
03/11/26 7:55	458462.6			1			1.7			1.06			3.02			1		
03/11/26 7:56	458728.3			1			1.7			1.06			3.03			0		
03/11/26 7:57	458526.2			0.9			1.7			0.97			3.02			0		
03/11/26 7:58	459444.6			0.9			1.61			0.97			2.87			0		
03/11/26 7:59	458520.4			0.9			1.61			0.97			2.86			0		
03/11/26 8:00	458514.6			0.9			1.61			0.97			2.86			0		

Sample Spreadsheet Listing

Date/Time	CT1_GasFlow_CT_scfh_1M		CT1_CO_Ppmvdc_1M		CT1_NOx_Ppmvdc_1M		CT1_CO_LbPerHr_1M		CT1_NOx_LbPerHr_1M		CT1_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
03/11/26 10:01	335885.9		0.9		1.5		0.71		1.99		0	
03/11/26 10:02	335706.8		0.9		1.5		0.71		1.99		0	
03/11/26 10:03	335972.5		0.9		1.52		0.72		2.03		0	
03/11/26 10:04	336434.6		0.9		1.5		0.71		2		0	
03/11/26 10:05	336509.7		0.9		1.5		0.71		2		0	
03/11/26 10:06	326753.8		0.9		1.5		0.69		1.94		1	
03/11/26 10:07	194444.1		0.9		1.59		0.42		1.24		1	
03/11/26 10:08	42951.8		0		6.94		8.03		1.35		0	
03/11/26 10:09	42882.5		0		17.7		286.75		3.44		0	
03/11/26 10:10	41860.1		0		0.1		0		0		0	
03/11/26 10:11	40843.5		0		0.1		0		0		0	
03/11/26 10:12	41865.9		0		0.1		0		0		0	

Sample Spreadsheet Listing

Date/Time	CT1_GasFlow_CT_scfh_1M		CT1_CO_Ppmvdc_1M		CT1_NOx_Ppmvdc_1M		CT1_CO_LbPerHr_1M		CT1_NOx_LbPerHr_1M		CT1_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
03/13/26 15:40	32768.4		0		0		0		0		0	
03/13/26 15:41	32658.6		0		0		0		0		0	
03/13/26 15:42	32699.1		0		0		0		0		0	
03/13/26 15:43	32808.8		0		0		0		0		0	
03/13/26 15:44	53037.1		0		0		0		0		0	
03/13/26 15:45	40115.7		0.1		0		0		0		1	
03/13/26 15:46	44696.2		0.8		0		0		0		1	
03/13/26 15:47	53019.7		1764.1		12.98		222.32		2.69		1	
03/13/26 15:48	64635.7		1303.9		12.59		198.77		3.16		1	
03/13/26 15:49	75050.1		746.4		18.68		132.15		5.44		1	
03/13/26 15:50	101591.8		454.9		22.48		109.05		8.87		1	
03/13/26 15:51	139934.2		340.6		30.84		112.76		16.8		1	
03/13/26 15:52	146588.3		236.4		41.3		81.98		23.57		1	
03/13/26 15:53	160578.3		1405.3		41.49		533.84		25.94		1	
03/13/26 15:54	179576.2		1888.9		44.7		800.4		31.17		1	
03/13/26 15:55	201352.5		1029.4		55.89		489.89		43.78		1	
03/13/26 15:56	223047.9		100.7		58.87		53		50.98		1	
03/13/26 15:57	245141.9		6.6		60.2		3.83		57.31		1	
03/13/26 15:58	268997.5		2.1		78.31		1.36		81.79		1	
03/13/26 15:59	293194		1.8		49.13		1.27		55.93		1	
03/13/26 16:00	313543.6		1.8		21.84		1.3		26.59		1	
03/13/26 16:01	331380.5		1.8		11.28		1.42		14.51		1	
03/13/26 16:02	348680.2		1.8		10.09		1.48		13.66		1	
03/13/26 16:03	365829.8		1.7		8.68		1.5		12.33		1	
03/13/26 16:04	387230.5		1.6		6.96		1.45		10.46		1	
03/13/26 16:05	407146.8		1.4		5.27		1.37		8.34		1	
03/13/26 16:06	432729.7		1.3		4.61		1.32		7.74		1	
03/13/26 16:07	440677.7		1.1		4.7		1.15		8.05		1	
03/13/26 16:08	436386		1		5.26		1.03		8.92		1	
03/13/26 16:09	434121.8		1		4.63		1.02		7.81		1	
03/13/26 16:10	434283.4		0.9		4.36		0.93		7.35		1	
03/13/26 16:11	434393.2		0.9		4.33		0.94		7.31		1	

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/13/26 16:12	433723.1			0.8			4.27			0.84			7.19			1		
03/13/26 16:13	433185.9			0.8			4.33			0.85			7.3			1		
03/13/26 16:14	433116.7			0.8			4.33			0.85			7.3			1		
03/13/26 16:15	432920.3			0.8			4.24			0.85			7.13			1		
03/13/26 16:16	432978			0.8			4.24			0.85			7.13			1		
03/13/26 16:17	432695			0.8			4.24			0.85			7.13			1		
03/13/26 16:18	432937.6			0.7			4.24			0.75			7.13			1		
03/13/26 16:19	433451.6			0.7			4.24			0.75			7.14			1		
03/13/26 16:20	433220.6			0.7			4.33			0.76			7.31			1		
03/13/26 16:21	432510.2			0.7			4.43			0.75			7.44			1		
03/13/26 16:22	432654.5			0.7			4.52			0.75			7.59			1		
03/13/26 16:23	432417.7			0.7			4.61			0.75			7.74			1		
03/13/26 16:24	432920.3			0.7			4.61			0.75			7.75			1		
03/13/26 16:25	433318.8			0.7			3.87			0.75			6.51			1		
03/13/26 16:26	433209.1			0.7			2.77			0.76			4.66			1		
03/13/26 16:27	432897.2			0.7			2.49			0.75			4.19			1		
03/13/26 16:28	432423.5			0.7			2.58			0.75			4.34			1		
03/13/26 16:29	432954.9			0.7			2.86			0.76			4.82			1		
03/13/26 16:30	432591			0.7			3.04			0.75			5.12			1		
03/13/26 16:31	432544.8			0.7			3.23			0.75			5.42			1		
03/13/26 16:32	432648.8			0.7			2.77			0.75			4.65			1		
03/13/26 16:33	432822.1			0.7			2.21			0.75			3.72			1		
03/13/26 16:34	433711.6			0.7			2.12			0.75			3.57			1		
03/13/26 16:35	433561.4			0.7			2.03			0.75			3.41			1		
03/13/26 16:36	432498.6			0.7			2.12			0.75			3.57			1		
03/13/26 16:37	432394.6			0.7			2.21			0.75			3.71			1		
03/13/26 16:38	432412			0.7			2.3			0.75			3.87			1		
03/13/26 16:39	433463.3			0.7			2.21			0.75			3.73			1		
03/13/26 16:40	433411.3			0.7			2.12			0.75			3.57			1		
03/13/26 16:41	433290			0.7			1.94			0.76			3.26			1		
03/13/26 16:42	433058.9			0.7			1.75			0.75			2.95			1		
03/13/26 16:43	432550.6			0.7			1.66			0.75			2.79			1		
03/13/26 16:44	432539			0.7			1.66			0.75			2.79			1		
03/13/26 16:45	432868.3			0.7			1.66			0.75			2.79			1		
03/13/26 16:46	433792.5			0.7			1.66			0.75			2.79			1		

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/13/26 16:47	433301.5			0.7			1.66			0.75			2.79			1		
03/13/26 16:48	434012			0.7			1.75			0.76			2.95			1		
03/13/26 16:49	433278.4			0.7			1.75			0.75			2.95			1		
03/13/26 16:50	433515.3			0.7			1.66			0.75			2.79			1		
03/13/26 16:51	433336.1			0.7			1.66			0.75			2.79			0		
03/13/26 16:52	433168.6			0.7			1.57			0.75			2.64			0		
03/13/26 16:53	433700			0.7			1.57			0.75			2.64			0		
03/13/26 16:54	432902.9			0.7			1.57			0.75			2.63			0		
03/13/26 16:55	432787.4			0.7			1.57			0.75			2.64			0		

Sample Spreadsheet Listing

Date/Time	CT1_GasFlow_CT_scfh_1M		CT1_CO_Ppmvdc_1M		CT1_NOx_Ppmvdc_1M		CT1_CO_LbPerHr_1M		CT1_NOx_LbPerHr_1M		CT1_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
03/13/26 19:48	438800.4		0.8		1.45		0.85		2.48		0	
03/13/26 19:49	439129.7		0.8		1.45		0.85		2.48		0	
03/13/26 19:50	439666.9		0.8		1.45		0.85		2.48		0	
03/13/26 19:51	439834.4		0.8		1.54		0.85		2.64		0	
03/13/26 19:52	439678.4		0.9		1.54		0.95		2.64		0	
03/13/26 19:53	440435.1		0.9		1.54		0.95		2.65		1	
03/13/26 19:54	429021.3		0.8		1.45		0.83		2.43		1	
03/13/26 19:55	407897.8		0.8		1.54		0.79		2.45		1	
03/13/26 19:56	386173.5		0.8		1.79		0.74		2.69		1	
03/13/26 19:57	363484.6		0.8		2.38		0.68		3.36		1	
03/13/26 19:58	342944.4		0.9		2.43		0.71		3.25		1	
03/13/26 19:59	319672.1		1		2.43		0.72		3.03		1	
03/13/26 20:00	294632.3		1		2.43		0.67		2.79		1	
03/13/26 20:01	273300.8		0.9		2.68		0.58		2.85		1	
03/13/26 20:02	251605.4		0.8		3.6		0.5		3.54		1	
03/13/26 20:03	227871		0.8		4.57		0.41		4.08		1	
03/13/26 20:04	207290.4		0.6		13.66		0.31		11.08		1	
03/13/26 20:05	183573.3		2		19.09		0.87		13.85		1	
03/13/26 20:06	163651.2		110.7		21.16		43.14		13.57		1	
03/13/26 20:07	147321.9		984.6		23.01		345.79		13.3		1	
03/13/26 20:08	99622.1		1782.8		23.6		420.63		9.16		1	
03/13/26 20:09	54723.7		0		30.01		327.32		6.51		0	
03/13/26 20:10	52858		0		0.4		0		0		0	
03/13/26 20:11	50391.5		0		0.3		0		0		0	
03/13/26 20:12	49178.5		0		0.2		0		0		0	
03/13/26 20:13	49115		0		0.2		0		0		0	

Sample Spreadsheet Listing

Date/Time	CT1_GasFlow_CT_scfh_1M		CT1_CO_Ppmvdc_1M		CT1_NOx_Ppmvdc_1M		CT1_CO_LbPerHr_1M		CT1_NOx_LbPerHr_1M		CT1_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
03/15/26 10:40	47988.7		0		0		0		0		0	
03/15/26 10:41	48260.1		0		0		0		0		0	
03/15/26 10:42	48508.5		0		0		0		0		0	
03/15/26 10:43	48866.6		0		0		0		0		0	
03/15/26 10:44	44632.7		0		0		0		0		0	
03/15/26 10:45	41894.8		0.1		0		0		0		1	
03/15/26 10:46	38267.3		0.8		0		0		0		1	
03/15/26 10:47	48450.8		1813.7		17.7		207.46		3.33		1	
03/15/26 10:48	59933.8		1385.3		12.98		195.98		3.02		1	
03/15/26 10:49	71099.2		821.1		18.68		137.66		5.16		1	
03/15/26 10:50	97617.8		525.7		23.6		121.09		8.95		1	
03/15/26 10:51	138386.1		393.4		29.77		128.49		16		1	
03/15/26 10:52	146958		286.3		43.27		99.26		24.69		1	
03/15/26 10:53	150735.7		1330.7		44.54		473.33		26.07		1	
03/15/26 10:54	150106		1874.9		43.62		663.97		25.42		1	
03/15/26 10:55	151654.1		1874.9		46.31		670.68		27.26		1	
03/15/26 10:56	165441.9		1875.1		50.24		732.03		32.28		1	
03/15/26 10:57	185837.6		1768.1		54.45		775.36		39.3		1	
03/15/26 10:58	208387.9		633.1		56.05		311.2		45.34		1	
03/15/26 10:59	228766.3		49.3		54.02		26.61		47.98		1	
03/15/26 11:00	252344.8		5.3		63.4		3.17		62.12		1	
03/15/26 11:01	279290.7		3.1		69.97		2.05		75.89		1	
03/15/26 11:02	301205.6		2.7		35.77		1.93		41.84		1	
03/15/26 11:03	320417.3		2.5		15.27		1.9		19		1	
03/15/26 11:04	338698.9		2.4		9.98		1.94		13.12		1	
03/15/26 11:05	354693.2		2.3		9.72		1.89		13.38		1	
03/15/26 11:06	374182.1		2.1		8.33		1.84		12.1		1	
03/15/26 11:07	395063.1		2		7.15		1.83		10.97		1	
03/15/26 11:08	416255.9		1.7		5.99		1.67		9.68		1	
03/15/26 11:09	440331.1		1.5		5.36		1.51		9.16		1	
03/15/26 11:10	448233		1.3		5.72		1.36		9.95		1	
03/15/26 11:11	444547.7		1.2		6.35		1.22		10.96		1	

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/15/26 11:12	443323.2			1.1			6.08			1.14			10.47			1		
03/15/26 11:13	443086.3			1			5.9			1.04			10.15			1		
03/15/26 11:14	442942			1			5.72			1.04			9.84			1		
03/15/26 11:15	442947.8			0.9			5.63			0.95			9.68			1		
03/15/26 11:16	442635.8			0.9			5.54			0.95			9.52			1		
03/15/26 11:17	442612.8			0.9			5.54			0.95			9.52			1		
03/15/26 11:18	441382.4			0.8			5.54			0.85			9.49			1		
03/15/26 11:19	440516			0.8			5.54			0.85			9.47			1		
03/15/26 11:20	440088.5			0.8			5.54			0.85			9.46			1		
03/15/26 11:21	439378			0.8			5.54			0.85			9.45			1		
03/15/26 11:22	438413.5			0.8			5.54			0.85			9.43			1		
03/15/26 11:23	440053.9			0.8			5.62			0.86			9.61			1		
03/15/26 11:24	439817			0.8			5.62			0.86			9.6			1		
03/15/26 11:25	439308.8			0.8			5.54			0.85			9.44			1		
03/15/26 11:26	439389.6			0.7			3.9			0.75			6.66			1		
03/15/26 11:27	439470.5			0.7			2.81			0.75			4.8			1		
03/15/26 11:28	438009.1			0.7			2.95			0.76			5.02			1		
03/15/26 11:29	437997.5			0.8			3.32			0.86			5.64			1		
03/15/26 11:30	437703			0.8			3.87			0.86			6.58			1		
03/15/26 11:31	438679.1			0.8			3.87			0.86			6.6			1		
03/15/26 11:32	440076.9			0.8			2.95			0.86			5.04			1		
03/15/26 11:33	439626.4			0.7			2.67			0.77			4.56			1		
03/15/26 11:34	439418.5			0.7			2.54			0.75			4.34			1		
03/15/26 11:35	439060.3			0.7			2.49			0.76			4.24			1		
03/15/26 11:36	437252.4			0.7			2.54			0.75			4.32			1		
03/15/26 11:37	436732.6			0.7			2.63			0.75			4.46			1		
03/15/26 11:38	438228.6			0.7			2.58			0.76			4.39			1		
03/15/26 11:39	437887.8			0.7			2.4			0.76			4.08			1		
03/15/26 11:40	439545.6			0.7			2.21			0.76			3.78			1		
03/15/26 11:41	438032.2			0.7			2.12			0.76			3.61			1		
03/15/26 11:42	437651			0.7			1.91			0.75			3.24			1		
03/15/26 11:43	439591.8			0.7			1.84			0.76			3.15			1		
03/15/26 11:44	438026.4			0.7			1.72			0.75			2.93			1		
03/15/26 11:45	437084.9			0.7			1.75			0.76			2.97			1		
03/15/26 11:46	436825			0.7			1.75			0.76			2.97			1		

Date/Time	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/15/26 11:47	436420.7			0.7			1.72			0.75			2.92			1		
03/15/26 11:48	435767.9			0.7			1.75			0.76			2.96			1		
03/15/26 11:49	437512.4			0.7			1.75			0.76			2.98			1		
03/15/26 11:50	437778			0.7			1.66			0.76			2.82			1		
03/15/26 11:51	436611.3			0.7			1.66			0.76			2.81			1		
03/15/26 11:52	435762.2			0.7			1.66			0.76			2.81			0		
03/15/26 11:53	437957.1			0.7			1.66			0.76			2.82			0		
03/15/26 11:54	436131.8			0.7			1.57			0.76			2.65			0		
03/15/26 11:55	437396.8			0.7			1.57			0.76			2.66			0		
03/15/26 11:56	437518.1			0.7			1.57			0.76			2.66			0		

Sample Spreadsheet Listing

Date/Time	CT1_GasFlow_CT_scfh_1M		CT1_CO_Ppmvdc_1M		CT1_NOx_Ppmvdc_1M		CT1_CO_LbPerHr_1M		CT1_NOx_LbPerHr_1M		CT1_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
03/15/26 14:45	422396		0.7		1.57		0.74		2.6		0	
03/15/26 14:46	421674		0.7		1.57		0.74		2.59		0	
03/15/26 14:47	422401.8		0.7		1.5		0.76		2.49		0	
03/15/26 14:48	423470.4		0.7		1.5		0.76		2.49		0	
03/15/26 14:49	422881.2		0.7		1.48		0.74		2.45		0	
03/15/26 14:50	423505		0.7		1.48		0.74		2.45		1	
03/15/26 14:51	423014		0.7		1.48		0.74		2.45		1	
03/15/26 14:52	413142.5		0.7		1.57		0.73		2.54		1	
03/15/26 14:53	395964.2		0.7		1.78		0.71		2.77		1	
03/15/26 14:54	374280.3		0.7		2.12		0.66		3.1		1	
03/15/26 14:55	353052.8		0.8		2.77		0.68		3.84		1	
03/15/26 14:56	330306.1		0.8		2.82		0.62		3.64		1	
03/15/26 14:57	305485.8		0.9		2.82		0.64		3.38		1	
03/15/26 14:58	282230.8		0.8		2.41		0.54		2.67		1	
03/15/26 14:59	261442.3		0.7		3.28		0.47		3.37		1	
03/15/26 15:00	240041.5		0.7		4		0.38		3.76		1	
03/15/26 15:01	217162		0.5		6.5		0.26		5.52		1	
03/15/26 15:02	194449.9		0.4		17.59		0.2		13.41		1	
03/15/26 15:03	171911.2		4.9		21.79		2.04		14.85		1	
03/15/26 15:04	153791.3		164.9		25.11		60.77		15.23		1	
03/15/26 15:05	136173.9		1023.9		26.31		330.96		14		1	
03/15/26 15:06	49860.1		1945.2		26.73		237.74		5.38		1	
03/15/26 15:07	49097.7		0		41.3		655.87		8.06		0	
03/15/26 15:08	49178.5		0		0.1		0		0		0	
03/15/26 15:09	49265.2		0		0.1		0		0		0	
03/15/26 15:10	49710		0		0.1		0		0		0	
03/15/26 15:11	50131.6		0		0.1		0		0		0	

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M		CT2_CO_Ppmvdc_1M		CT2_NOx_Ppmvdc_1M		CT2_CO_LbPerHr_1M		CT2_NOx_LbPerHr_1M		CT2_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
03/11/26 12:39	0		0		0		0		0		0	
03/11/26 12:40	0		0		0		0		0		0	
03/11/26 12:41	0		0		0		0		0		0	
03/11/26 12:42	0		0		0		0		0		0	
03/11/26 12:43	13805.1		0		0		0		0		0	
03/11/26 12:44	0		0		0		0		0		1	
03/11/26 12:45	0		0		0		0		0		1	
03/11/26 12:46	17369		1669.7		0		76.25		0		1	
03/11/26 12:47	37476		1148.5		4.92		109.01		0.77		1	
03/11/26 12:48	51396.6		825.3		10.76		105.49		2.26		1	
03/11/26 12:49	65276.8		509.8		15.93		82.5		4.24		1	
03/11/26 12:50	97513.8		395.9		21.63		92.95		8.36		1	
03/11/26 12:51	145023		279.1		29.76		96.9		17		1	
03/11/26 12:52	153566		216.8		44.88		79.99		27.25		1	
03/11/26 12:53	169629.6		1172.6		43.39		478.23		29.13		1	
03/11/26 12:54	191082.4		1833.8		47.75		838.22		35.92		1	
03/11/26 12:55	213944.6		1026.3		55.49		521.03		46.36		1	
03/11/26 12:56	236310		284.5		60.4		159.45		55.72		1	
03/11/26 12:57	257814.8		29.1		63.39		17.88		64.06		1	
03/11/26 12:58	283952.1		3.1		62.82		2.11		69.96		1	
03/11/26 12:59	309465.6		2		40.35		1.47		48.92		1	
03/11/26 13:00	333558.1		1.8		25.6		1.44		33.44		1	
03/11/26 13:01	352977.7		1.8		19.64		1.48		27.09		1	
03/11/26 13:02	373789.3		1.9		15.62		1.7		22.85		1	
03/11/26 13:03	393237.8		1.9		12.58		1.77		19.25		1	
03/11/26 13:04	414806.1		1.8		10.74		1.82		17.45		1	
03/11/26 13:05	435970.1		1.8		9.48		1.85		16.14		1	
03/11/26 13:06	444247.4		1.6		8.76		1.69		15.18		1	
03/11/26 13:07	446563.6		1.5		8.17		1.54		14.24		1	
03/11/26 13:08	446835.1		1.3		7.81		1.35		13.64		1	
03/11/26 13:09	446113.1		1.2		7.44		1.25		12.99		1	
03/11/26 13:10	444992.5		1.1		7.01		1.17		12.19		1	

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/11/26 13:11	443935.5			1.1			6.81			1.15			11.84			1		
03/11/26 13:12	444004.8			1			6.72			1.06			11.7			1		
03/11/26 13:13	443548.5			1			6.55			1.07			11.35			1		
03/11/26 13:14	443577.3			0.9			6.44			0.96			11.22			1		
03/11/26 13:15	443057.4			0.9			6.64			0.97			11.5			1		
03/11/26 13:16	442381.6			0.9			6.54			0.95			11.3			1		
03/11/26 13:17	441648.1			0.8			6.54			0.86			11.27			1		
03/11/26 13:18	442427.9			0.8			6.72			0.86			11.6			1		
03/11/26 13:19	441105.1			0.8			6.81			0.86			11.73			1		
03/11/26 13:20	452767.3			0.8			6.91			0.89			12.25			1		
03/11/26 13:21	457324.7			0.8			6.82			0.91			12.27			1		
03/11/26 13:22	458503			0.7			6.91			0.81			12.48			1		
03/11/26 13:23	458763			0.7			7.1			0.81			12.83			1		
03/11/26 13:24	459617.9			0.7			7.28			0.81			13.17			1		
03/11/26 13:25	459069.1			0.7			7.38			0.81			13.3			1		
03/11/26 13:26	458809.2			0.7			7.38			0.81			13.27			1		
03/11/26 13:27	458404.8			0.7			7.19			0.8			12.91			1		
03/11/26 13:28	458682.1			0.7			4.78			0.82			8.62			1		
03/11/26 13:29	457809.9			0.6			2.86			0.71			5.14			1		
03/11/26 13:30	457197.6			0.6			2.77			0.7			4.95			1		
03/11/26 13:31	457446			0.6			2.77			0.71			4.97			1		
03/11/26 13:32	456504.5			0.6			2.86			0.7			5.12			1		
03/11/26 13:33	455996.2			0.7			2.95			0.8			5.29			1		
03/11/26 13:34	456573.8			0.7			3.13			0.8			5.6			1		
03/11/26 13:35	457636.6			0.6			3.32			0.7			5.96			1		
03/11/26 13:36	456955			0.6			3.41			0.7			6.08			1		
03/11/26 13:37	455210.6			0.6			3.78			0.7			6.73			1		
03/11/26 13:38	455603.4			0.6			3.96			0.7			7.1			1		
03/11/26 13:39	455770.9			0.7			3.18			0.71			5.68			1		
03/11/26 13:40	456181			0.7			2.62			0.71			4.7			1		
03/11/26 13:41	456446.7			0.6			2.3			0.7			4.12			1		
03/11/26 13:42	455129.8			0.6			2.21			0.7			3.94			1		
03/11/26 13:43	454996.9			0.7			2.25			0.71			3.99			1		
03/11/26 13:44	455389.6			0.6			2.3			0.7			4.12			1		
03/11/26 13:45	454159.3			0.6			2.4			0.7			4.26			1		

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/11/26 13:46	455020			0.6			2.49			0.7			4.43			1		
03/11/26 13:47	454332.6			0.6			2.4			0.7			4.26			1		
03/11/26 13:48	455164.4			0.6			2.21			0.7			3.94			1		
03/11/26 13:49	454892.9			0.6			1.94			0.7			3.45			1		
03/11/26 13:50	454812			0.6			1.75			0.7			3.12			1		
03/11/26 13:51	455245.2			0.6			1.57			0.7			2.8			1		
03/11/26 13:52	455441.7			0.6			1.57			0.7			2.79			1		
03/11/26 13:53	454274.8			0.6			1.57			0.7			2.78			1		
03/11/26 13:54	455291.5			0.7			1.59			0.71			2.84			1		
03/11/26 13:55	454055.4			0.7			1.69			0.71			3			1		
03/11/26 13:56	454269			0.7			1.69			0.71			3			1		
03/11/26 13:57	454754.3			0.6			1.75			0.7			3.13			1		
03/11/26 13:58	453674.2			0.6			1.75			0.7			3.11			1		
03/11/26 13:59	454113.1			0.6			1.66			0.7			2.95			1		
03/11/26 14:00	453610.6			0.6			1.66			0.7			2.95			0		
03/11/26 14:01	454234.4			0.7			1.69			0.71			3			0		
03/11/26 14:02	454165.1			0.6			1.57			0.7			2.78			0		
03/11/26 14:03	453922.5			0.6			1.57			0.7			2.79			0		
03/11/26 14:04	455147.1			0.6			1.48			0.7			2.63			0		

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M		CT2_CO_Ppmvdc_1M		CT2_NOx_Ppmvdc_1M		CT2_CO_LbPerHr_1M		CT2_NOx_LbPerHr_1M		CT2_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
03/11/26 15:49	454737		0.7		1.5		0.71		2.68		0	
03/11/26 15:50	455227.9		0.7		1.5		0.71		2.68		0	
03/11/26 15:51	454274.8		0.7		1.5		0.71		2.67		0	
03/11/26 15:52	454263.3		0.7		1.5		0.71		2.68		0	
03/11/26 15:53	456533.3		0.7		1.5		0.71		2.68		0	
03/11/26 15:54	454338.4		0.7		1.5		0.71		2.67		1	
03/11/26 15:55	443213.4		0.7		1.5		0.69		2.61		1	
03/11/26 15:56	401567.1		0.6		1.57		0.62		2.48		1	
03/11/26 15:57	176855.6		0.7		2		0.31		1.41		1	
03/11/26 15:58	0		0		4.99		0.11		0.09		0	
03/11/26 15:59	0		0		5.9		1.45		0.13		0	
03/11/26 16:00	0		0		0.1		0		0		0	
03/11/26 16:01	0		0		0.1		0		0		0	
03/11/26 16:02	0		0		0.1		0		0		0	

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M		CT2_CO_Ppmvdc_1M		CT2_NOx_Ppmvdc_1M		CT2_CO_LbPerHr_1M		CT2_NOx_LbPerHr_1M		CT2_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
03/12/26 6:43	0		0		0		0		0		0	
03/12/26 6:44	0		0		0		0		0		0	
03/12/26 6:45	0		0		0		0		0		0	
03/12/26 6:46	0		0		0		0		0		0	
03/12/26 6:47	0		0		0		0		0		0	
03/12/26 6:48	2091		0		0		0		0		1	
03/12/26 6:49	0		0.3		0		0		0		1	
03/12/26 6:50	25051.4		1245.9		18.68		73.63		1.82		1	
03/12/26 6:51	42224		1118.4		13.28		111.41		2.18		1	
03/12/26 6:52	56185.1		805.7		19.01		106.77		4.15		1	
03/12/26 6:53	70966.4		522.3		21.91		87.45		6.04		1	
03/12/26 6:54	108788.9		468.9		27.53		120.39		11.63		1	
03/12/26 6:55	153542.9		356.2		36.38		129.01		21.69		1	
03/12/26 6:56	160572.5		310.7		50.05		117.66		31.2		1	
03/12/26 6:57	178016.6		1731.5		51.13		727.1		35.34		1	
03/12/26 6:58	200919.3		1774.5		51.89		841.31		40.48		1	
03/12/26 6:59	222845.7		1056.4		49.06		555.48		42.46		1	
03/12/26 7:00	244096.4		300.4		47.89		172.99		45.39		1	
03/12/26 7:01	266069		34.8		45.85		21.83		47.36		1	
03/12/26 7:02	291986.8		4.2		44.14		2.89		50.05		1	
03/12/26 7:03	317766		2.5		24.84		1.86		30.65		1	
03/12/26 7:04	341829.6		2.2		15.99		1.77		21.22		1	
03/12/26 7:05	362554.7		2.1		12.84		1.78		18.08		1	
03/12/26 7:06	382182.1		2		10.62		1.82		15.76		1	
03/12/26 7:07	402791.6		2		7.75		1.92		12.13		1	
03/12/26 7:08	423175.8		1.9		6.77		1.91		11.12		1	
03/12/26 7:09	441087.8		1.7		5.81		1.74		9.95		1	
03/12/26 7:10	446043.8		1.4		5.72		1.48		9.91		1	
03/12/26 7:11	446020.7		1.3		5.72		1.39		9.91		1	
03/12/26 7:12	446130.4		1.2		5.64		1.3		9.76		1	
03/12/26 7:13	445697.2		1.1		5.55		1.2		9.6		1	
03/12/26 7:14	445102.3		1.1		5.55		1.2		9.59		1	

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/12/26 7:15	445778.1			1.1			5.63			1.13			9.75			1		
03/12/26 7:16	454309.5			1.1			5.63			1.15			9.93			1		
03/12/26 7:17	458087.1			1			5.54			1.06			9.86			1		
03/12/26 7:18	459727.6			1			5.54			1.07			9.89			1		
03/12/26 7:19	459600.5			1			5.9			1.07			10.53			1		
03/12/26 7:20	460189.7			1			6.08			1.07			10.86			1		
03/12/26 7:21	459184.7			1			6.17			1.07			11			1		
03/12/26 7:22	458641.7			1			6.26			1.06			11.15			1		
03/12/26 7:23	458150.7			1			6.35			1.07			11.32			1		
03/12/26 7:24	457711.7			1			5.27			1.06			9.39			1		
03/12/26 7:25	457578.9			1			2.86			1.07			5.1			1		
03/12/26 7:26	458058.3			1			2.41			1.07			4.31			1		
03/12/26 7:27	457625			1			2.5			1.07			4.48			1		
03/12/26 7:28	455164.4			1			2.68			1.06			4.78			1		
03/12/26 7:29	456579.6			0.9			3.22			0.97			5.76			1		
03/12/26 7:30	457163			0.9			3.31			0.97			5.93			1		
03/12/26 7:31	456516			0.9			3.4			0.97			6.09			1		
03/12/26 7:32	455562.9			0.9			3.49			0.97			6.24			1		
03/12/26 7:33	457111			0.9			3.67			0.98			6.6			1		
03/12/26 7:34	455499.4			0.9			2.95			0.98			5.3			1		
03/12/26 7:35	455274.2			0.9			2.41			0.97			4.33			1		
03/12/26 7:36	455170.2			1			2.32			1.07			4.17			1		
03/12/26 7:37	455828.7			1			2.23			1.07			4.02			1		
03/12/26 7:38	455436			1			2.32			1.07			4.18			1		
03/12/26 7:39	456198.3			1			2.5			1.08			4.51			1		
03/12/26 7:40	456290.7			1			2.59			1.08			4.67			1		
03/12/26 7:41	454685			0.9			2.41			0.98			4.34			1		
03/12/26 7:42	455355			0.9			1.88			0.98			3.38			1		
03/12/26 7:43	454107.3			0.9			1.79			0.97			3.21			1		
03/12/26 7:44	455487.8			0.9			1.7			0.98			3.06			1		
03/12/26 7:45	455678.5			0.9			1.7			0.98			3.06			1		
03/12/26 7:46	455880.6			0.9			1.79			0.98			3.22			1		
03/12/26 7:47	454477			0.9			1.88			0.98			3.37			1		
03/12/26 7:48	455331.9			0.9			1.88			0.98			3.38			1		
03/12/26 7:49	454736.9			0.9			1.88			0.98			3.37			1		

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/12/26 7:50	453679.9			0.9			1.79			0.97			3.2			1		
03/12/26 7:51	455967.3			0.9			1.7			0.98			3.06			1		
03/12/26 7:52	455378.1			0.9			1.61			0.98			2.89			1		
03/12/26 7:53	454505.9			0.9			1.43			0.97			2.56			0		
03/12/26 7:54	453668.3			0.9			1.43			0.97			2.56			0		
03/12/26 7:55	454234.4			0.9			1.43			0.97			2.56			0		
03/12/26 7:56	452368.7			0.9			1.43			0.97			2.55			0		
03/12/26 7:57	454361.5			0.9			1.52			0.97			2.72			0		

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M		CT2_CO_Ppmvdc_1M		CT2_NOx_Ppmvdc_1M		CT2_CO_LbPerHr_1M		CT2_NOx_LbPerHr_1M		CT2_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
03/12/26 10:51	453552.8		0.6		1.54		0.68		2.73		0	
03/12/26 10:52	454563.7		0.6		1.45		0.68		2.57		0	
03/12/26 10:53	453466.2		0.6		1.45		0.69		2.58		0	
03/12/26 10:54	452570.9		0.6		1.57		0.69		2.77		0	
03/12/26 10:55	453391.1		0.6		1.57		0.69		2.77		0	
03/12/26 10:56	451577.3		0.6		1.54		0.68		2.72		1	
03/12/26 10:57	440296.4		0.6		1.63		0.67		2.82		1	
03/12/26 10:58	420108.7		0.6		2		0.63		3.28		1	
03/12/26 10:59	395917.9		0.7		2.68		0.67		4.15		1	
03/12/26 11:00	374026.1		0.8		2.99		0.71		4.38		1	
03/12/26 11:01	351626		0.8		3.61		0.66		4.95		1	
03/12/26 11:02	324893.8		0.8		3.61		0.61		4.56		1	
03/12/26 11:03	300275.7		0.8		4.2		0.57		4.94		1	
03/12/26 11:04	276454.6		0.7		5.81		0.49		6.29		1	
03/12/26 11:05	251530.3		0.6		9.83		0.35		9.69		1	
03/12/26 11:06	229430.6		0.4		19.31		0.23		17.38		1	
03/12/26 11:07	204361.9		5.8		32.21		2.8		25.72		1	
03/12/26 11:08	181707.6		144.6		36.97		63.25		26.62		1	
03/12/26 11:09	161387		793.7		41.15		305.23		26.05		1	
03/12/26 11:10	142406.4		1464.2		46.53		497.21		26		1	
03/12/26 11:11	44915.7		1809.1		49.56		198.84		8.96		1	
03/12/26 11:12	0		0		47.2		17.46		0.59		0	
03/12/26 11:13	0		0		0.3		0		0		0	
03/12/26 11:14	0		0		0.2		0		0		0	
03/12/26 11:15	0		0		0.2		0		0		0	
03/12/26 11:16	0		0		5.9		0.92		0.06		0	

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M		CT2_CO_Ppmvdc_1M		CT2_NOx_Ppmvdc_1M		CT2_CO_LbPerHr_1M		CT2_NOx_LbPerHr_1M		CT2_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
03/17/26 10:39	0		0		0		0		0		0	
03/17/26 10:40	0		0		0		0		0		0	
03/17/26 10:41	0		0		0		0		0		0	
03/17/26 10:42	0		0		0		0		0		0	
03/17/26 10:43	0		0		0		0		0		0	
03/17/26 10:44	6815.9		0		0		0		0		1	
03/17/26 10:45	0		0		0		0		0		1	
03/17/26 10:46	13054.2		1475		23.6		60.09		1.58		1	
03/17/26 10:47	36875.2		1213.4		14.26		115.98		2.24		1	
03/17/26 10:48	50974.9		835.8		15.73		107.39		3.33		1	
03/17/26 10:49	64029.2		533.7		17.41		86.13		4.62		1	
03/17/26 10:50	95971.5		388.9		18.24		91.83		7.09		1	
03/17/26 10:51	143527		275.1		24.83		96.18		14.29		1	
03/17/26 10:52	177063.6		218.9		35.2		94.04		24.88		1	
03/17/26 10:53	200226.1		720.9		40.58		348.87		32.32		1	
03/17/26 10:54	205713.5		341		44.32		168.56		36.05		1	
03/17/26 10:55	227050.8		251.1		44.87		137.65		40.48		1	
03/17/26 10:56	248601.8		44.9		49.38		26.82		48.55		1	
03/17/26 10:57	273433.7		2.9		51.83		1.9		56.08		1	
03/17/26 10:58	299178.2		1.1		35.72		0.76		42.13		1	
03/17/26 10:59	325604.3		1		21.32		0.81		27.3		1	
03/17/26 11:00	345387.8		1.1		17.26		0.94		23.43		1	
03/17/26 11:01	366031.9		1.4		13.68		1.2		19.71		1	
03/17/26 11:02	378901.3		1.5		11.71		1.31		17.42		1	
03/17/26 11:03	383048.6		1.5		10.41		1.35		15.65		1	
03/17/26 11:04	384342.4		1.3		10.59		1.19		15.95		1	
03/17/26 11:05	383891.9		1.2		10.33		1.11		15.58		1	
03/17/26 11:06	381991.5		1.1		9.63		1.02		14.37		1	
03/17/26 11:07	381281		1.1		9.86		1.05		14.82		1	
03/17/26 11:08	381731.6		1		9.28		0.94		13.84		1	
03/17/26 11:09	382447.8		1		8.89		0.89		13.42		1	
03/17/26 11:10	380507		1		8.37		0.88		12.53		1	

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/17/26 11:11	380218.3			0.9			8.28			0.8			12.39			1		
03/17/26 11:12	379686.8			0.9			8.19			0.8			12.18			1		
03/17/26 11:13	379513.5			0.9			8.01			0.8			11.98			1		
03/17/26 11:14	379513.5			0.9			7.84			0.8			11.7			1		
03/17/26 11:15	378739.5			0.9			7.66			0.8			11.42			1		
03/17/26 11:16	379392.2			0.9			7.69			0.81			11.5			1		
03/17/26 11:17	376896.9			0.9			7.49			0.8			11.13			1		
03/17/26 11:18	376400.2			0.9			7.4			0.79			10.98			1		
03/17/26 11:19	376163.3			0.9			7.42			0.81			11.01			1		
03/17/26 11:20	376810.3			0.8			7.42			0.73			11.02			1		
03/17/26 11:21	375978.5			0.8			7.42			0.72			10.98			1		
03/17/26 11:22	375504.8			0.8			7.42			0.72			10.98			1		
03/17/26 11:23	376284.7			0.8			7.22			0.72			10.72			1		
03/17/26 11:24	376024.7			0.8			6.96			0.71			10.32			1		
03/17/26 11:25	375031.2			0.8			4.2			0.72			6.21			1		
03/17/26 11:26	375204.5			0.8			2.68			0.72			3.97			1		
03/17/26 11:27	374586.4			0.8			2.68			0.72			3.96			1		
03/17/26 11:28	375452.8			0.8			2.86			0.72			4.24			1		
03/17/26 11:29	375175.6			0.8			3.04			0.72			4.5			1		
03/17/26 11:30	374453.6			0.8			3.22			0.72			4.76			1		
03/17/26 11:31	375089			0.8			3.31			0.72			4.9			1		
03/17/26 11:32	374343.8			0.8			3.49			0.72			5.16			1		
03/17/26 11:33	374494			0.8			3.67			0.72			5.42			1		
03/17/26 11:34	374632.7			0.8			3.75			0.72			5.55			1		
03/17/26 11:35	374130.1			0.8			3.49			0.72			5.15			1		
03/17/26 11:36	373968.4			0.8			2.86			0.72			4.22			1		
03/17/26 11:37	374361.2			0.8			2.68			0.72			3.96			1		
03/17/26 11:38	373916.4			0.8			2.5			0.72			3.7			1		
03/17/26 11:39	373333			0.8			2.29			0.71			3.37			1		
03/17/26 11:40	373535.2			0.8			2.15			0.72			3.16			1		
03/17/26 11:41	374026.1			0.8			1.88			0.72			2.77			1		
03/17/26 11:42	373413.9			0.8			1.7			0.72			2.5			1		
03/17/26 11:43	374107			0.8			1.41			0.71			2.08			1		
03/17/26 11:44	374470.9			0.8			1.34			0.72			1.98			1		
03/17/26 11:45	372957.5			0.8			1.16			0.72			1.71			1		

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/17/26 11:46	372980.6			0.8			1.16			0.72			1.71			1		
03/17/26 11:47	373512			0.8			1.07			0.72			1.58			1		
03/17/26 11:48	372478.2			0.8			0.98			0.72			1.45			1		
03/17/26 11:49	373084.6			0.8			1.07			0.72			1.58			1		
03/17/26 11:50	373668			0.8			1.07			0.72			1.58			1		
03/17/26 11:51	372738.1			0.8			1.16			0.72			1.71			0		
03/17/26 11:52	371652.2			0.8			1.16			0.72			1.7			0		
03/17/26 11:53	373714.3			0.8			1.25			0.72			1.85			0		
03/17/26 11:54	372096.9			0.8			1.25			0.72			1.84			0		
03/17/26 11:55	372761.2			0.8			1.34			0.72			1.97			0		

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M		CT2_CO_Ppmvdc_1M		CT2_NOx_Ppmvdc_1M		CT2_CO_LbPerHr_1M		CT2_NOx_LbPerHr_1M		CT2_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
03/17/26 16:53	370704.8		0.7		1.54		0.65		2.27		0	
03/17/26 16:54	369283.9		0.7		1.63		0.65		2.39		0	
03/17/26 16:55	367932.3		0.7		1.72		0.64		2.51		0	
03/17/26 16:56	369312.8		0.7		1.82		0.65		2.66		0	
03/17/26 16:57	370820.4		0.7		1.7		0.64		2.5		0	
03/17/26 16:58	367880.3		0.7		1.54		0.64		2.25		1	
03/17/26 16:59	355640.5		0.7		1.27		0.62		1.79		1	
03/17/26 17:00	336278.7		0.7		1.07		0.58		1.43		1	
03/17/26 17:01	312059.1		0.7		0.98		0.54		1.22		1	
03/17/26 17:02	288324.7		0.6		1.18		0.44		1.36		1	
03/17/26 17:03	266109.5		0.6		2.53		0.36		2.69		1	
03/17/26 17:04	240122.3		0.5		5.9		0.29		5.68		1	
03/17/26 17:05	217681.8		0.3		16.2		0.17		14.17		1	
03/17/26 17:06	192018.2		8.3		29.03		3.89		22.49		1	
03/17/26 17:07	169462.1		203.7		34.19		84.99		23.48		1	
03/17/26 17:08	149898.1		954.7		38.43		354.77		23.5		1	
03/17/26 17:09	133199.1		1622.3		43.21		538.19		23.59		1	
03/17/26 17:10	0		1902.2		47.4		32.36		1.33		1	
03/17/26 17:11	0		0		80.63		75.71		2.35		0	
03/17/26 17:12	0		0		0.3		0		0		0	
03/17/26 17:13	0		0		0.2		0		0		0	
03/17/26 17:14	0		0		0.2		0		0		0	
03/17/26 17:15	0		0		0.2		0		0		0	

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/18/26 8:39	0			0			0			0			0			0		
03/18/26 8:40	0			0			0			0			0			0		
03/18/26 8:41	0			0			0			0			0			0		
03/18/26 8:42	0			0			0			0			0			0		
03/18/26 8:43	0			0			0			0			0			0		
03/18/26 8:44	0			0			0			0			0			1		
03/18/26 8:45	0			0			0			0			0			1		
03/18/26 8:46	9426.8			1209.5			35.4			36.28			1.75			1		
03/18/26 8:47	35038.4			1201.8			14.07			102.76			1.98			1		
03/18/26 8:48	48918.6			983.9			18.74			120.03			3.76			1		
03/18/26 8:49	62007.5			609.2			23.31			93.82			5.91			1		
03/18/26 8:50	87902.2			440.6			27.62			95.28			9.83			1		
03/18/26 8:51	136150.8			350.2			35.91			114.44			19.32			1		
03/18/26 8:52	168006.5			266.1			48.04			107.83			32.03			1		
03/18/26 8:53	204766.2			698.4			55.5			342.07			44.73			1		
03/18/26 8:54	231660.2			465.2			55.02			257.53			50.12			1		
03/18/26 8:55	258086.3			49.5			53.87			30.63			54.85			1		
03/18/26 8:56	281901.6			2.6			49.58			1.76			55.15			1		
03/18/26 8:57	306277.1			1.2			27.67			0.89			33.34			1		
03/18/26 8:58	330242.6			1.2			18.07			0.96			23.39			1		
03/18/26 8:59	350026			1.2			15.36			1.01			21.1			1		
03/18/26 9:00	366569.1			1.4			12.05			1.25			17.35			1		
03/18/26 9:01	374407.3			1.6			10.54			1.43			15.47			1		
03/18/26 9:02	381142.4			1.5			9.49			1.4			14.2			1		
03/18/26 9:03	383464.5			1.4			9.15			1.25			13.79			1		
03/18/26 9:04	383724.4			1.3			8.72			1.18			13.17			1		
03/18/26 9:05	383135.2			1.2			8.59			1.11			12.93			1		
03/18/26 9:06	381419.7			1.1			8.07			1.03			12.1			1		
03/18/26 9:07	381714.3			1			7.9			0.95			11.83			1		
03/18/26 9:08	381026.9			1			7.81			0.95			11.69			1		
03/18/26 9:09	380478.2			1.1			7.75			0.96			11.6			1		
03/18/26 9:10	379796.6			1			7.46			0.87			11.16			1		

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/18/26 9:11	378959			1			7.38			0.86			10.99			1		
03/18/26 9:12	378843.5			1			7.4			0.87			10.98			1		
03/18/26 9:13	379392.2			0.9			7.31			0.8			10.92			1		
03/18/26 9:14	375851.4			0.9			7.29			0.78			10.79			1		
03/18/26 9:15	371941			0.9			7.04			0.78			10.32			1		
03/18/26 9:16	377474.5			0.9			6.87			0.8			10.21			1		
03/18/26 9:17	377919.3			0.8			7.22			0.72			10.73			1		
03/18/26 9:18	376804.5			0.8			7.22			0.71			10.7			1		
03/18/26 9:19	377260.8			0.9			7.11			0.78			10.55			1		
03/18/26 9:20	377076			0.9			7.22			0.79			10.7			1		
03/18/26 9:21	376411.7			0.9			7.04			0.79			10.41			1		
03/18/26 9:22	376741			0.8			4.93			0.71			7.29			1		
03/18/26 9:23	377884.6			0.8			2.64			0.72			3.93			1		
03/18/26 9:24	376943.1			0.8			2.38			0.71			3.53			1		
03/18/26 9:25	376538.8			0.8			2.29			0.71			3.39			1		
03/18/26 9:26	376781.4			0.8			2.23			0.72			3.31			1		
03/18/26 9:27	376925.8			0.8			1.94			0.71			2.87			1		
03/18/26 9:28	375637.7			0.8			1.67			0.71			2.47			1		
03/18/26 9:29	375793.7			0.8			1.5			0.71			2.21			1		
03/18/26 9:30	375978.5			0.8			1.32			0.71			1.95			1		
03/18/26 9:31	374909.9			0.8			1.23			0.71			1.82			1		
03/18/26 9:32	374638.4			0.8			1.23			0.71			1.82			1		
03/18/26 9:33	374673.1			0.8			1.23			0.71			1.82			1		
03/18/26 9:34	374436.3			0.8			1.32			0.71			1.95			1		
03/18/26 9:35	374967.6			0.8			1.34			0.72			1.98			1		
03/18/26 9:36	375626.1			0.8			1.41			0.71			2.08			1		
03/18/26 9:37	373858.6			0.8			1.43			0.72			2.11			1		
03/18/26 9:38	375522.2			0.8			1.52			0.72			2.25			0		
03/18/26 9:39	373864.4			0.8			1.61			0.72			2.36			0		
03/18/26 9:40	374719.3			0.8			1.61			0.72			2.37			0		
03/18/26 9:41	374961.9			0.8			1.59			0.71			2.34			0		
03/18/26 9:42	374424.7			0.8			1.61			0.72			2.37			0		

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/18/26 13:51	371259.4			0.6			1.43			0.56			2.11			0		
03/18/26 13:52	371738.8			0.6			1.36			0.57			2.01			0		
03/18/26 13:53	371813.9			0.6			1.45			0.57			2.14			0		
03/18/26 13:54	372108.5			0.6			1.43			0.56			2.11			0		
03/18/26 13:55	371374.9			0.6			1.54			0.57			2.28			0		
03/18/26 13:56	368868			0.6			1.72			0.57			2.52			1		
03/18/26 13:57	355386.4			0.6			1.82			0.54			2.56			1		
03/18/26 13:58	333719.8			0.6			1.97			0.5			2.61			1		
03/18/26 13:59	309650.4			0.7			2.06			0.54			2.54			1		
03/18/26 14:00	285875.6			0.6			3.13			0.45			3.57			1		
03/18/26 14:01	263931.8			0.6			5.14			0.37			5.43			1		
03/18/26 14:02	237499.9			0.5			9.8			0.29			9.34			1		
03/18/26 14:03	214799.5			0.3			20.76			0.17			17.97			1		
03/18/26 14:04	190626.1			13			32.75			6.1			25.26			1		
03/18/26 14:05	167746.6			240.6			36.88			99.94			25.21			1		
03/18/26 14:06	148078.6			993.7			43.01			366.57			26.11			1		
03/18/26 14:07	121727.6			1620.2			44.77			496.88			22.6			1		
03/18/26 14:08	0			0			46.11			35.76			1.46			0		
03/18/26 14:09	0			0			41.3			148.9			1.31			0		
03/18/26 14:10	0			0			0.3			0			0			0		
03/18/26 14:11	0			0			0.2			0			0			0		
03/18/26 14:12	0			0			0.2			0			0			0		

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M		CT2_CO_Ppmvdc_1M		CT2_NOx_Ppmvdc_1M		CT2_CO_LbPerHr_1M		CT2_NOx_LbPerHr_1M		CT2_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
03/26/26 8:39	0		0		0		0		0		0	
03/26/26 8:40	0		0		0		0		0		0	
03/26/26 8:41	0		0		0		0		0		0	
03/26/26 8:42	0		0		0		0		0		0	
03/26/26 8:43	4805.8		0		0		0		0		0	
03/26/26 8:44	5897.5		-0.1		0		0		0		1	
03/26/26 8:45	0		0		0		0		0		1	
03/26/26 8:46	23197.2		1421.9		15.73		98.03		1.79		1	
03/26/26 8:47	42079.6		1127.7		14.33		127.99		2.68		1	
03/26/26 8:48	55440		737.2		17.37		106.93		4.15		1	
03/26/26 8:49	69909.3		498		21.24		89.28		6.27		1	
03/26/26 8:50	109181.7		408.2		25.29		111.03		11.32		1	
03/26/26 8:51	150059.8		296.7		32.2		109.26		19.52		1	
03/26/26 8:52	154883		267.7		38.86		101.64		24.28		1	
03/26/26 8:53	173309		1722.4		34.02		729.08		23.7		1	
03/26/26 8:54	194380.6		1872.1		36.69		885.92		28.57		1	
03/26/26 8:55	215261.6		1054.7		44.97		551.25		38.68		1	
03/26/26 8:56	237956.3		281.7		55.91		162.35		53.04		1	
03/26/26 8:57	260379.4		29		58.5		18.24		60.56		1	
03/26/26 8:58	287568		3.2		53.79		2.25		61.38		1	
03/26/26 8:59	312359.5		2		32.98		1.51		40.82		1	
03/26/26 9:00	336954.5		1.8		21.13		1.46		28.16		1	
03/26/26 9:01	355617.4		1.8		18.4		1.5		25.87		1	
03/26/26 9:02	368238.4		1.8		14.88		1.59		21.64		1	
03/26/26 9:03	369751.8		1.9		13.51		1.67		19.73		1	
03/26/26 9:04	369393.6		1.8		13.1		1.62		19.12		1	
03/26/26 9:05	367429.8		1.6		12.41		1.45		18		1	
03/26/26 9:06	368619.6		1.6		11.8		1.38		17.2		1	
03/26/26 9:07	367868.7		1.4		11.28		1.23		16.4		1	
03/26/26 9:08	370392.9		1.3		11.36		1.17		16.62		1	
03/26/26 9:09	378404.5		1.2		10.04		1.12		15		1	
03/26/26 9:10	381645		1.1		9.16		1.05		13.81		1	

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/26/26 9:11	381223.3			1.1			9.16			0.97			13.79			1		
03/26/26 9:12	381206			1			9.42			0.89			14.19			1		
03/26/26 9:13	380801.6			1			9.42			0.89			14.17			1		
03/26/26 9:14	381021.1			1			9.25			0.89			13.91			1		
03/26/26 9:15	380709.2			1			8.98			0.89			13.51			1		
03/26/26 9:16	380564.8			0.9			8.63			0.8			12.97			1		
03/26/26 9:17	380131.6			0.9			8.54			0.8			12.83			1		
03/26/26 9:18	380120			0.9			8.37			0.8			12.57			1		
03/26/26 9:19	378716.4			0.9			8.4			0.81			12.59			1		
03/26/26 9:20	378624			0.9			8.19			0.8			12.26			1		
03/26/26 9:21	379623.3			0.9			8.31			0.82			12.48			1		
03/26/26 9:22	378855			0.8			8.31			0.73			12.45			1		
03/26/26 9:23	378924.4			0.8			8.31			0.73			12.47			1		
03/26/26 9:24	379149.6			0.8			8.1			0.72			12.15			1		
03/26/26 9:25	378468			0.8			8.31			0.73			12.44			1		
03/26/26 9:26	377272.4			0.8			8.19			0.72			12.22			1		
03/26/26 9:27	378901.3			0.8			5.64			0.72			8.45			1		
03/26/26 9:28	377520.8			0.8			2.73			0.72			4.08			1		
03/26/26 9:29	377590.1			0.8			2.5			0.73			3.74			1		
03/26/26 9:30	377543.8			0.8			2.59			0.73			3.87			1		
03/26/26 9:31	377902			0.8			2.86			0.73			4.28			1		
03/26/26 9:32	377480.3			0.8			3.04			0.73			4.54			1		
03/26/26 9:33	377076			0.8			3.22			0.73			4.8			1		
03/26/26 9:34	376741			0.8			3.4			0.73			5.06			1		
03/26/26 9:35	376625.4			0.8			3.67			0.73			5.46			1		
03/26/26 9:36	376382.9			0.8			3.75			0.73			5.59			1		
03/26/26 9:37	377006.7			0.8			3.13			0.73			4.67			1		
03/26/26 9:38	376192.2			0.7			2.68			0.65			3.99			1		
03/26/26 9:39	376296.2			0.7			2.15			0.65			3.19			1		
03/26/26 9:40	376325.1			0.7			2.06			0.65			3.06			1		
03/26/26 9:41	376856.5			0.7			2.06			0.65			3.07			1		
03/26/26 9:42	376273.1			0.7			2.06			0.65			3.06			1		
03/26/26 9:43	377647.8			0.7			2.06			0.65			3.07			1		
03/26/26 9:44	376943.1			0.8			2.06			0.73			3.07			1		
03/26/26 9:45	375528			0.8			1.97			0.73			2.92			1		

Date/Time	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc	Value	SI	Modc
03/26/26 9:46	376816.1			0.7			1.79			0.65			2.67			1		
03/26/26 9:47	376030.5			0.7			1.5			0.64			2.23			1		
03/26/26 9:48	377047.1			0.7			1.32			0.64			1.97			1		
03/26/26 9:49	377526.5			0.7			1.16			0.65			1.74			1		
03/26/26 9:50	377272.4			0.7			1.07			0.65			1.6			1		
03/26/26 9:51	375828.3			0.7			0.98			0.65			1.46			1		
03/26/26 9:52	375863			0.7			0.98			0.65			1.46			1		
03/26/26 9:53	376931.5			0.7			0.89			0.65			1.33			1		
03/26/26 9:54	377179.9			0.7			0.98			0.65			1.47			1		
03/26/26 9:55	377463			0.7			0.98			0.65			1.47			0		
03/26/26 9:56	376400.2			0.8			0.98			0.73			1.47			0		
03/26/26 9:57	376845			0.7			1.07			0.65			1.6			0		
03/26/26 9:58	375504.8			0.7			1.07			0.65			1.6			0		
03/26/26 9:59	375637.7			0.7			1.14			0.64			1.7			0		

Sample Spreadsheet Listing

Date/Time	CT2_GasFlow_CT_scfh_1M		CT2_CO_Ppmvdc_1M		CT2_NOx_Ppmvdc_1M		CT2_CO_LbPerHr_1M		CT2_NOx_LbPerHr_1M		CT2_SUSD_TF_1M	
	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc	Value	SI Modc
03/26/26 12:45	374632.7		0.7		1.54		0.66		2.29		0	
03/26/26 12:46	376007.4		0.7		1.54		0.66		2.29		0	
03/26/26 12:47	373864.4		0.7		1.54		0.65		2.28		0	
03/26/26 12:48	374551.8		0.7		1.54		0.65		2.29		0	
03/26/26 12:49	374187.9		0.7		1.54		0.65		2.28		0	
03/26/26 12:50	369832.6		0.7		1.52		0.63		2.21		1	
03/26/26 12:51	350372.6		0.7		1.54		0.61		2.14		1	
03/26/26 12:52	326343.6		0.7		1.61		0.56		2.08		1	
03/26/26 12:53	302528.4		0.7		2		0.53		2.4		1	
03/26/26 12:54	278285.7		0.7		3.09		0.51		3.44		1	
03/26/26 12:55	254262.4		0.6		4.93		0.36		5		1	
03/26/26 12:56	230701.4		0.4		11.06		0.24		10.23		1	
03/26/26 12:57	205834.8		2.4		23.6		1.23		19.59		1	
03/26/26 12:58	181956		81.3		30.01		36.61		22.24		1	
03/26/26 12:59	162675.1		591.6		34.68		240.08		23.16		1	
03/26/26 13:00	143371		1336		39.99		483.88		23.84		1	
03/26/26 13:01	66784.4		1719		46.44		312.45		13.89		1	
03/26/26 13:02	0		0		49.28		47.11		2.03		0	
03/26/26 13:03	0		0		0.4		0		0		0	
03/26/26 13:04	0		0		0.3		0		0		0	
03/26/26 13:05	0		0		0.3		0		0		0	
03/26/26 13:06	0		0		0.2		0		0		0	

AQ-47/69/90/103

AQ-47/69/90/103: No emissions are permitted, from any source, which are a nuisance per PCAPCD Rule 205, Nuisance.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-47/69/90/103 of Roseville Energy Park's 1Q26 QAQR, there were no violations of PCAPCD's Rule 205 for nuisance.

AQ-48/91/104

AQ-48/91/104: Stack emission opacity as dark as Ringelmann No. 1 (20% opacity) for periods aggregating more than 3 minutes in any one hour is prohibited and is in violation of PCAPCD Rule 202, Visible Emissions.

Verification: The Project owner shall report all violations of this condition as noticed by the PCAPCD as well as any offsite nuisance complaints as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

In regards to AQ-48/91/104 of Roseville Energy Park's 1Q26 QAQR, there were no violations of PCAPCD's Rule 202 for opacity.

AQ-86

AQ-86 Operation for maintenance and testing of the emergency diesel engine and generator shall be limited to 50 hours per year.

Verification: The Project owner shall include all necessary operational data to demonstrate compliance with the limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

DATE	INITIALS	START	END	REASON	HOURS TOTAL	MINUTES YTD
10/26/2024	XAB	1258	1328	BI-WEEKLY TEST RUN	158	740
11-9-24	XAB	1420	1450	BI-WEEKLY TEST RUN	158	770
11-23-24	XAB	1617	1647	BI-WEEKLY TEST RUN	159	800
12-7-24	XAB	1415	1445	BI-WEEKLY TEST RUN	159	830
12-22-24	XAB	0903	0933	BI-WEEKLY TEST RUN	160	860
2025					160	
1-6-25	AD	10570	11:00	BI-weekly Test Run	160	30
1-17-25	DC	09:00	09:30	BI-weekly Test Run	161	60
2-2-25	DWN	1500	1530	BI-weekly Test Run	161	90
2-12-25	XAB	1601	1605	POWER LOSS TO MAINS	161	94
2-15-25	XAB	1408	1438	BI-WEEKLY TEST RUN	162	124
3-1-25	AD	12:50	13:20	BI-weekly Test Run	162	154
3-15-25	XAB	1258	1328	BI-WEEKLY TEST RUN	163	184
3-29-25	AD	14:00	14:30	BI-weekly Test Run	163	214
4-12-25	XAB	1444	1514	BI-WEEKLY TEST RUN	164	244
4-24-25	LA	0401	0431	BI-WEEKLY Test Run	164	274
4-28-25	DC			DIESEL DELIVERY 143 Gallons		
5-11-25	XAB	0843	0913	BI-WEEKLY TEST RUN	165	304
5-24-25	AL	11:03	11:33	BI-WEEKLY TEST RUN	165	334
6/8/25	DE	1424	1454	BI-WEEKLY TEST RUN	166	364
6/22/25	AD	08:00	08:30	BI-weekly Test Run	166	394
7/6/25	XAB	0755	0825	BI-WEEKLY TEST RUN	167	424
7/19/25	AD	12:00	12:30	BI-weekly test Run	167	454
8/3/25	XAB	0833	0903	BI-WEEKLY TEST RUN	168	484
8-15-25	DWN	1455	1525	BI-weekly Test Run	168	514
8/30/25	XAB	0805	0835	BI-WEEKLY TEST RUN	169	544
9-14-25	XAB	1155	1225	BI-WEEKLY TEST RUN	169	574
9-27-25	XAB	1345	1415	BI-WEEKLY TEST RUN	170	604
10-9-25	AD	0840	0908	load testing	170	632
10-26-25	XAB	0809	0839	BI-WEEKLY TEST RUN	171	662
10-28-25	XAB	1129	1136	Annual service of load Bank	171	669
10-29-25	XAB	1145	1150	Annual service of load Bank	171	674
10-29-25	XAB	1201	1205	Annual service of load Bank	173	808
11-9-25	XAB	1347	1417	BI-WEEKLY TEST RUN	174	838
11-23-25	XAB	1409	1509	BI-WEEKLY TEST RUN	174	858
12-7-25	XAB	1350	1420	BI-WEEKLY TEST RUN	175	898

DATE	INITIALS	START	END	REASON	HOURS TOTAL	MINUTES YTD
12-19-25	RL	1041	1114	BI-WEEKLY TEST RUN / PLACE LOADS	175	943
2026						2026
1-4-26	XAB	0935	1005	BI-WEEKLY TEST RUN	176	30
1-17-26	XAB	1042	1112	BI-WEEKLY TEST RUN	176	60
2-1-26	XAB	1045	1115	BI-WEEKLY TEST RUN	177	90
2-14-26	XAB	1526	1556	BI-WEEKLY TEST RUN	177	120
3-1-26	XAB	1322	1352	BI-WEEKLY TEST RUN	178	150
3-14-26	XAB	1321	1351	BI-WEEKLY TEST RUN	178	180
3-29-26	XAB	1500	1530	BI-WEEKLY TEST RUN	179	210
4-1-26	CngC	Diesel	Added	200 gals		
4-11-26	XAB	0751	0821	BI-WEEKLY TEST RUN	179	240

AQ-87

AQ-87 Operation for other than maintenance and testing purposes shall be limited to involuntary interruptions of electrical power. Operation shall not exceed 24 hours without prior authorization by the Air Pollution Control Officer.

Verification: The Project owner shall include all necessary operational data to demonstrate compliance with the limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

DATE	START	REASON	STOP	TOTAL HRS	YTD HRS	INITIAL
6-14-25	1516	weekly test run	1546	311.7	12	JB
6-22-25	12:30	weekly test run	13:00	312.2	12.5	JB
6/29/25	1339	WEEKLY TEST RUN	1409	312.7	13	SL
7/6/25	1314	WEEKLY TEST RUN	1344	313.2	13.5	SL
7/13/25	09:21	WEEKLY TEST RUN	09:51	313.7	14	AL
7-20-25	1445	WEEKLY TEST RUN	1515	314.2	14.5	AL
7-27-25	1525	WEEKLY TEST RUN	1555	314.7	15.0	AB
8-4-25	1345	WEEKLY TEST RUN	1415	315.2	15.5	RC
8-10-25	0723	Weekly Test Run	0753	315.7	16	AL
8/17/25	1835	- WEEKLY TEST RUN	1905	316.2	16.5	DE
8/24/25	1133	WEEKLY TEST RUN	1203	316.7	17.0	SL
8/31/25	1336	WEEKLY TEST RUN	1406	317.2	17.5	SL
9/3/25	1038	DIESEL FUEL DELIVERY		317.7	18	EO
9/7/25	10:46	Weekly Test Run	1116	317.7	18	AL
9-14-25	6235	WEEKLY TEST RUN	1305	318.2	18.5	AL
9-21-25	1306	WEEKLY TEST RUN	1426	318.7	19.0	RC
9-28-25	1445	WEEKLY TEST RUN	1515	319.2	19.5	SL
10-12-25	2302	WEEKLY TEST RUN	2332	319.7	20.0	SL
10/19/25	1400	WEEKLY TEST RUN	1430	320.2	20.5	SL
10/26/25	1532	WEEKLY TEST RUN	1602	320.7	21.0	SL
11/2/25	10:05	WEEKLY TEST RUN	10:35	321.2	21.5	AL
11-9-25	1425	WEEKLY TEST RUN	1455	321.7	22	AL
11/17/25	1201	WEEKLY TEST RUN	1231	322.2	22.5	SL
11-23-25	1602	WEEKLY TEST RUN	1632	322.7	23.0	SL
11-30-25	09:29	WEEKLY TEST RUN	09:59	323.2	23.5	AL
12-7-25	1430	WEEKLY TEST RUN	1500	323.7	24	AL
12-13-25	1243	WEEKLY TEST RUN	1313	324.2	24.5	AL
12-19-25	1121	WEEKLY TEST RUN/PLATE CORRECT OBSERVATION	1151	324.7	25.0	RC
12-27-25	1312	weekly test run	1342	325.2	25.5	JB

2026

1-4-26	1010	WEEKLY TEST RUN	1040	325.7	26	AL
1/12/26	1435	WEEKLY TEST RUN	1505	326.2	26.5	SL
1/19/26	1403	WEEKLY TEST RUN	1433	326.7	27	SL
1/24/26	15:02	WEEKLY TEST RUN	15:32	327.2	27.5	AL
2-1-26	1123	WEEKLY TEST RUN	1153	327.7	28	AL
2-8-26	1400	Weekly Test Run	1430	328.2	28.5	AL

DATE	START	REASON	STOP	TOTAL HRS.	YTD HRS	INITIALS
2-15-26	1448	WEEKLY TEST RUN	1518	328.7	29	SL
2-22-26	1350	weekly Test Run	1420	329.2	30	JB
3-1-26	1359	WEEKLY TEST RUN	1429	329.7	31	SL
3/7/26	1536	WEEKLY TEST RUN	1606	330.2	32	SL
3/15/26	1447	WEEKLY TEST RUN	1517	330.7	33	SL
3-22-26	1314	weekly test run	1344	331.2	34	JB
3-29-26	1535	WEEKLY TEST RUN	1605	331.7	35	SL
4-1-26	Diesel Added - 84 gal					
4/4/26	1555	WEEKLY TEST RUN	1625	332.2	36	SL

AQ-88/101

AQ-88 The Sulfur content of the Diesel fuel used shall not exceed 15 ppm by weight.

Verification: The Project owner shall include a summary of diesel fuel purchase records showing amounts delivered, date delivered and fuel type with the Quarterly Air Quality Report as required in Condition of Certification AQ-SC6.

AQ-89/102

AQ-89/102: Records of operation and maintenance shall be kept by the owner or operator for a period of five years and shall be made available to the PCAPCD by request. Information required for reporting to the PCAPCD includes, but is not limited to:

- A. Hours of operation the engine was run for maintenance and testing
- B. Hours of operation the engine was run during interruption of electrical power
- C. Records of sulfur content of the diesel fuel used

Verification: The Project shall include all necessary operational data to demonstrate compliance with the limits provided as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

DATE	INITIALS	START	END	REASON	HOURS TOTAL	MINUTES YTD
10/26/2024	XAB	1258	1328	BI-WEEKLY TEST RUN	158	740
11-9-24	XAB	1420	1450	BI-WEEKLY TEST RUN	158	770
11-23-24	XAB	1617	1647	BI-WEEKLY TEST RUN	159	800
12-7-24	XAB	1415	1445	BI-WEEKLY TEST RUN	159	830
12-22-24	XAB	0903	0933	BI-WEEKLY TEST RUN	160	860
2025					160	
1-6-25	AD	10570	11:00	BI-weekly Test Run	160	30
1-17-25	DC	09:00	09:30	BI-weekly Test Run	161	60
2-2-25	DWN	1500	1530	BI-weekly Test Run	161	90
2-12-25	XAB	1601	1605	POWER LOSS TO MAINS	161	94
2-15-25	XAB	1408	1438	BI-WEEKLY TEST RUN	162	124
3-1-25	AD	12:50	13:20	BI-weekly Test Run	162	154
3-15-25	XAB	1258	1328	BI-WEEKLY TEST RUN	163	184
3-29-25	AD	14:00	14:30	BI-weekly Test Run	163	214
4-12-25	XAB	1444	1514	BI-WEEKLY TEST RUN	164	244
4-24-25	LA	0401	0431	BI-WEEKLY Test Run	164	274
4-28-25	DC			DIESEL DELIVERY 143 Gallons		
5-11-25	XAB	0843	0913	BI-WEEKLY TEST RUN	165	304
5-24-25	AL	11:03	11:33	BI-WEEKLY TEST RUN	165	334
6/8/25	DE	1424	1454	BI-WEEKLY TEST RUN	166	364
6/22/25	AD	08:00	08:30	BI-weekly Test Run	166	394
7/6/25	XAB	0755	0825	BI-WEEKLY TEST RUN	167	424
7/19/25	AD	12:00	12:30	BI-weekly test Run	167	454
8/3/25	XAB	0833	0903	BI-WEEKLY TEST RUN	168	484
8-15-25	DWN	1455	1525	BI-weekly Test Run	168	514
8/30/25	XAB	0805	0835	BI-WEEKLY TEST RUN	169	544
9-14-25	XAB	1155	1225	BI-WEEKLY TEST RUN	169	574
9-27-25	XAB	1345	1415	BI-WEEKLY TEST RUN	170	604
10-9-25	AD	0840	0908	load testing	170	632
10-26-25	XAB	0809	0839	BI-WEEKLY TEST RUN	171	662
10-28-25	XAB	1129	1136	Annual service of load Bank	171	669
10-28-25	XAB	1145	1151	Annual service of load Bank	171	674
10-28-25	XAB	1201	1205	Annual service of load Bank	173	808
11-9-25	XAB	1347	1417	BI WEEKLY TEST RUN	174	838
11-23-25	XAB	1409	1509	BI-WEEKLY TEST RUN	174	858
12-7-25	XAB	1350	1420	BI-WEEKLY TEST RUN	175	898

DATE	INITIALS	START	END	REASON	HOURS TOTAL	MINUTES YTD
12-19-25	RL	1041	1114	BI-WEEKLY TEST RUN / PLACE LOADS	175	943
2026						2026
1-4-26	XAB	0935	1005	BI WEEKLY TEST RUN	176	30
1-17-26	XAB	1042	1112	BI-WEEKLY TEST RUN	176	60
2-1-26	XAB	1045	1115	BI-WEEKLY TEST RUN	177	90
2-14-26	XAB	1526	1556	BI-WEEKLY TEST RUN	177	120
3-1-26	XAB	1322	1352	BI-WEEKLY TEST RUN	178	150
3-14-26	XAB	1321	1351	BI-WEEKLY TEST RUN	178	180
3-29-26	XAB	1500	1530	BI-WEEKLY TEST RUN	179	210
4-1-26	CngC	Diesel	Added	200 gals		
4-11-26	XAB	0751	0821	BI-WEEKLY TEST RUN	179	240

AQ-99

AQ-99 Operation for maintenance and testing of the emergency diesel engine and generator shall be limited to 50 hours per year.

Verification: The Project shall include all necessary operational data to demonstrate compliance with the limits provided as part of the Quarterly Air Quality Report in Condition of Certification AQ-SC6

DATE	INITIALS	START	END	REASON	HOURS TOTAL	MINUTES YTD
10/26/2024	XAB	1258	1328	BI-WEEKLY TEST RUN	158	740
11-9-24	XAB	1420	1450	BI-WEEKLY TEST RUN	158	770
11-23-24	XAB	1617	1647	BI-WEEKLY TEST RUN	159	800
12-7-24	XAB	1415	1445	BI-WEEKLY TEST RUN	159	830
12-22-24	XAB	0903	0933	BI-WEEKLY TEST RUN	160	860
2025					160	
1-6-25	AD	10570	11:00	BI-weekly Test Run	160	30
1-17-25	DC	09:00	09:30	BI-weekly Test Run	161	60
2-2-25	DWN	1500	1530	BI-weekly Test Run	161	90
2-12-25	XAB	1601	1605	POWER LOSS TO MAINS	161	94
2-15-25	XAB	1408	1438	BI-WEEKLY TEST RUN	162	124
3-1-25	AD	12:50	13:20	BI-weekly Test Run	162	154
3-15-25	XAB	1258	1328	BI-WEEKLY TEST RUN	163	184
3-29-25	AD	14:00	14:30	BI-weekly Test Run	163	214
4-12-25	XAB	1444	1514	BI-WEEKLY TEST RUN	164	244
4-24-25	LA	0401	0431	BI-WEEKLY Test Run	164	274
4-28-25	DC			DIESEL DELIVERY 143 Gallons		
5-11-25	XAB	0843	0913	BI-WEEKLY TEST RUN	165	304
5-24-25	AL	11:03	11:33	BI-WEEKLY TEST RUN	165	334
6/8/25	DE	1424	1454	BI-WEEKLY TEST RUN	166	364
6/22/25	AD	08:00	08:30	BI-weekly Test Run	166	394
7/6/25	XAB	0755	0825	BI-WEEKLY TEST RUN	167	424
7/19/25	AD	12:00	12:30	BI-weekly test Run	167	454
8/3/25	XAB	0833	0903	BI-WEEKLY TEST RUN	168	484
8-15-25	DWN	1455	1525	BI-weekly Test Run	168	514
8/30/25	XAB	0805	0835	BI-WEEKLY TEST RUN	169	544
9-14-25	XAB	1155	1225	BI-WEEKLY TEST RUN	169	574
9-27-25	XAB	1345	1415	BI-WEEKLY TEST RUN	170	604
10-9-25	AD	0840	0908	load testing	170	632
10-26-25	XAB	0809	0839	BI-WEEKLY TEST RUN	171	662
10-28-25	DWN	1129	1136	Annual service of load Bank	171	669
10-29-25	DWN	1145	1151	Annual service of load Bank	171	674
10-29-25	DWN	1201	1205	Annual service of load Bank	173	808
11-9-25	XAB	1347	1417	BI-WEEKLY TEST RUN	174	838
11-23-25	XAB	1409	1509	BI-WEEKLY TEST RUN	174	858
12-7-25	XAB	1350	1420	BI-WEEKLY TEST RUN	175	898

DATE	INITIALS	START	END	REASON	HOURS TOTAL	MINUTES YTD
12-19-25	RL	1041	1114	BI-WEEKLY TEST RUN / PLACE LOADS	175	943
2026						2026
1-4-26	XAB	0935	1005	BI-WEEKLY TEST RUN	176	50
1-17-26	XAB	1042	1112	BI-WEEKLY TEST RUN	176	60
2-1-26	XAB	1045	1115	BI-WEEKLY TEST RUN	177	90
2-14-26	XAB	1526	1556	BI-WEEKLY TEST RUN	177	120
3-1-26	XAB	1322	1352	BI-WEEKLY TEST RUN	178	150
3-14-26	XAB	1321	1351	BI-WEEKLY TEST RUN	178	180
3-29-26	XAB	1500	1530	BI-WEEKLY TEST RUN	179	210
4-1-26	CngC	Diesel	Added	200 gals		
4-11-26	XAB	0751	0821	BI-WEEKLY TEST RUN	179	240

AQ-100

AQ-100 In regards to the Emergency diesel Generator; Operation for other than maintenance and testing purposes shall be limited to involuntary interruptions of electrical power. Operation shall not exceed 24 hours without prior authorization by the Air Pollution Control Officer.

Verification: The Project owner shall include all necessary operational data to demonstrate compliance with the limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

DATE	INITIALS	START	END	REASON	HOURS TOTAL	MINUTES YTD
10/26/2024	XAB	1258	1328	BI-WEEKLY TEST RUN	158	740
11-9-24	XAB	1420	1450	BI-WEEKLY TEST RUN	158	770
11-23-24	XAB	1617	1647	BI-WEEKLY TEST RUN	159	800
12-7-24	XAB	1415	1445	BI-WEEKLY TEST RUN	159	830
12-22-24	XAB	0903	0933	BI-WEEKLY TEST RUN	160	860
2025					160	
1-6-25	AD	10570	11:00	BI-weekly Test Run	160	30
1-17-25	DC	09:00	09:30	BI-weekly Test Run	161	60
2-2-25	DWN	1500	1530	BI-weekly Test Run	161	90
2-12-25	XAB	1601	1605	POWER LOSS TO MAINS	161	94
2-15-25	XAB	1408	1438	BI-WEEKLY TEST RUN	162	124
3-1-25	AD	12:50	13:20	BI-weekly Test Run	162	154
3-15-25	XAB	1258	1328	BI-WEEKLY TEST RUN	163	184
3-29-25	AD	14:00	14:30	BI-weekly Test Run	163	214
4-12-25	XAB	1444	1514	BI-WEEKLY TEST RUN	164	244
4-24-25	LA	0401	0431	BI-WEEKLY Test Run	164	274
4-28-25	DC			DIESEL DELIVERY 143 Gallons		
5-11-25	XAB	0843	0913	BI-WEEKLY TEST RUN	165	304
5-24-25	AL	11:03	11:33	BI-WEEKLY TEST RUN	165	334
6/8/25	DE	1424	1454	BI-WEEKLY TEST RUN	166	364
6/22/25	AD	08:00	08:30	BI-weekly Test Run	166	394
7/6/25	XAB	0755	0825	BI-WEEKLY TEST RUN	167	424
7/19/25	AD	12:00	12:30	BI-weekly test Run	167	454
8/3/25	XAB	0833	0903	BI-WEEKLY TEST RUN	168	484
8-15-25	DWN	1455	1525	BI-weekly Test Run	168	514
8/30/25	XAB	0805	0835	BI-WEEKLY TEST RUN	169	544
9-14-25	XAB	1155	1225	BI-WEEKLY TEST RUN	169	574
9-27-25	XAB	1345	1415	BI-WEEKLY TEST RUN	170	604
10-9-25	AD	0840	0908	load testing	170	632
10-26-25	XAB	0809	0839	BI-WEEKLY TEST RUN	171	662
10-28-25	XAB	1129	1136	Annual service of load Bank	171	669
10-29-25	XAB	1145	1150	Annual service of load Bank	171	674
10-29-25	XAB	1201	1205	Annual service of load Bank	173	808
11-9-25	XAB	1347	1417	BI WEEKLY TEST RUN	174	838
11-23-25	XAB	1409	1509	BI-WEEKLY TEST RUN	174	858
12-7-25	XAB	1350	1420	BI-WEEKLY TEST RUN	175	898

DATE	INITIALS	START	END	REASON	HOURS TOTAL	MINUTES YTD
12-19-25	RL	1041	1114	BI-WEEKLY TEST RUN / PLACE LOADS	175	943
2026						2026
1-4-26	XAB	0935	1005	BI WEEKLY TEST RUN	176	50
1-17-26	XAB	1042	1112	BI-WEEKLY TEST RUN	176	60
2-1-26	XAB	1045	1115	BI-WEEKLY TEST RUN	177	90
2-14-26	XAB	1526	1556	BI-WEEKLY TEST RUN	177	120
3-1-26	XAB	1322	1352	BI-WEEKLY TEST RUN	178	150
3-14-26	XAB	1321	1351	BI-WEEKLY TEST RUN	178	180
3-29-26	XAB	1500	1530	BI-WEEKLY TEST RUN	179	210
4-1-26	CngC	Diesel	Added	200 gals		
4-11-26	XAB	0751	0821	BI-WEEKLY TEST RUN	179	240