

**DOCKETED**

<b>Docket Number:</b>	21-TPG-01
<b>Project Title:</b>	Roseville Energy Park Temporary Power Generators
<b>TN #:</b>	269687
<b>Document Title:</b>	RPEAK (REPR-20-03 AND 04) Quarterly CEMS Report - First Quarter 2026 - Part 4s
<b>Description:</b>	N/A
<b>Filer:</b>	Roseville Electric Compliance
<b>Organization:</b>	Roseville Electric
<b>Submitter Role:</b>	Public Agency
<b>Submission Date:</b>	4/29/2026 10:11:05 AM
<b>Docketed Date:</b>	4/29/2026

# CRR-14

**CRR-14:** Unless determined necessary on an ongoing basis, improvements to the site such as concrete pads, gravel lining, and temporary or permanent fencing must be removed.

**Verification:** Within one month of cessation of operation, the project operator must provide a final report documenting removal of project facilities (this may or may not be coincidental to the quarterly report).

Facility is currently operational.

## **III. Emissions Deviations**

# CO LbPerHr 1-Hour Block Excess Emissions

CT5

From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 04/01/2026 09:15 Location: Roseville, CA



Tag Name: CT5\_CO\_Norm\_LbPerHr\_1H

Total Operating Time: 78.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 2,082.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	78.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

# CO Ppmvdc 1-Hour Block Excess Emissions

CT5

**From:** 01/01/2026 00:00 **To:** 03/31/2026 23:59 **Facility Name:** ROSEVILLE ENERGY  
**Generated:** 04/01/2026 09:15 **Location:** Roseville, CA



**Tag Name:** CT5\_CO\_Norm\_Ppmvdc\_1H

**Total Operating Time:** 78.00 Hour(s)

**No Exclusions Allowed**

Non-Operating Time: 2,082.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

<b>Total Operating Time:</b>	<b>78.00 Hour(s)</b>
<b>Total Duration (Online only):</b>	<b>0.00 Hour(s)</b>
<b>Time in exceedance as a percentage of operating time:</b>	<b>0.00 %</b>
<b>Time in compliance as a percentage of operating time:</b>	<b>100.00 %</b>

# CO Lbs SUSd 1-Hour Block Excess Emissions

CT5

**From:** 01/01/2026 00:00 **To:** 03/31/2026 23:59 **Facility Name:** ROSEVILLE ENERGY  
**Generated:** 04/01/2026 09:15 **Location:** Roseville, CA



**Tag Name:** CT5\_CO\_SUSD\_Lbs\_1H

**Total Operating Time:** 78.00 Hour(s)

**No Exclusions Allowed**

Non-Operating Time: 2,082.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

<b>Total Operating Time:</b>	<b>78.00 Hour(s)</b>
<b>Total Duration (Online only):</b>	<b>0.00 Hour(s)</b>
<b>Time in exceedance as a percentage of operating time:</b>	<b>0.00 %</b>
<b>Time in compliance as a percentage of operating time:</b>	<b>100.00 %</b>

# Startup/Shutdown Event Report

## CT5 - CO Lbs Per Startup/Shutdown



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 09:15 Location: Roseville, CA

Tag Name: CT5\_CO\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

Total Operating Time: 61.67 Hours  
 Non-Operating Time: 2,098.33 Hours Report Time: 2,160.00 Hours

### Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
01/15/2026 12:51 01/15/2026 12:59 Startup	9	0.74	19.40		
01/15/2026 16:58 01/15/2026 17:05 Shutdown	8	0.11	21.60		
01/19/2026 18:32 01/19/2026 18:57 Startup	26	1.42	19.40		
01/19/2026 19:57 01/19/2026 20:04 Shutdown	8	0.14	21.60		
01/20/2026 16:57 01/20/2026 17:08 Startup	12	0.93	19.40		
01/20/2026 19:57 01/20/2026 20:04 Shutdown	8	0.14	21.60		
01/23/2026 08:50 01/23/2026 08:52 Startup	3	0.44	19.40		
01/23/2026 08:52 01/23/2026 08:57 Shutdown	6	0.79	21.60		
01/23/2026 09:06 01/23/2026 09:16 Startup	11	0.66	19.40		
01/23/2026 23:57 01/24/2026 00:04 Shutdown	8	0.13	21.60		
01/24/2026 20:41 01/24/2026 20:50 Startup	10	0.90	19.40		
01/24/2026 21:59 01/24/2026 22:06 Shutdown	8	0.13	21.60		
01/25/2026 13:44 01/25/2026 13:54 Startup	11	0.68	19.40		

# Startup/Shutdown Event Report

## CT5 - CO Lbs Per Startup/Shutdow



**From:** 01/01/2026 00:00 **To:** 03/31/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 04/01/2026 09:15 **Location:** Roseville, CA

**Tag Name:** CT5\_CO\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 61.67 Hours  
 Non-Operating Time: 2,098.33 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
01/25/2026 21:58 01/25/2026 22:05 Shutdown	8	0.14	21.60		
01/26/2026 09:51 01/26/2026 10:01 Startup	11	0.91	19.40		
01/26/2026 11:42 01/26/2026 11:49 Shutdown	8	0.12	21.60		
01/26/2026 15:51 01/26/2026 16:00 Startup	10	0.52	19.40		
01/26/2026 21:57 01/26/2026 22:04 Shutdown	8	0.14	21.60		
01/27/2026 09:52 01/27/2026 10:01 Startup	10	0.80	19.40		
01/27/2026 21:58 01/27/2026 22:05 Shutdown	8	0.12	21.60		
02/04/2026 08:46 02/04/2026 08:57 Startup	12	1.04	19.40		
02/04/2026 16:00 02/04/2026 16:07 Shutdown	8	0.09	21.60		

No excess emissions were found in the reporting period.

# Startup/Shutdown Event Report

## CT5 - CO Lbs Per Startup/Shutdown



**From:** 01/01/2026 00:00 **To:** 03/31/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 04/01/2026 09:15

**Location:** Roseville, CA

**Tag Name:** CT5\_CO\_LbPerHr\_1M

SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 61.67 Hours

Non-Operating Time: 2,098.33 Hours

Report Time: 2,160.00 Hours

### Event Invalid Information

No invalid events were found in the reporting period.

# Startup/Shutdown Event Report

## CT5 - CO Lbs Per Startup/Shutdown



**From:** 01/01/2026 00:00 **To:** 03/31/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 04/01/2026 09:15 **Location:** Roseville, CA

**Tag Name:** CT5\_CO\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 61.67 Hours  
 Non-Operating Time: 2,098.33 Hours Report Time: 2,160.00 Hours

### Periodic Excess and Invalid Summary

Emission Data Summary
-----------------------

1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary
-------------------------

1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

# Heat Input MBtuPerHr 1-Hour Block Excess Emissions



CT5

From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 04/01/2026 09:15 Location: Roseville, CA

Tag Name: CT5\_HI\_MBtuPerHr\_1H

Total Operating Time: 78.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: -69.00 Hour(s) Report Time: 9.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	78.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

# NH3 Slip Ppmvdc 1-Hour Block Excess Emissions



CT5

From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 04/01/2026 09:15 Location: Roseville, CA

Tag Name: CT5\_NH3Slip\_Ppmvdc\_1H

Total Operating Time: 78.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: -54.00 Hour(s) Report Time: 24.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	78.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

# NOx LbPerHr 1-Hour Block Excess Emissions



CT5

From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY  
 Generated: 04/01/2026 09:15 Location: Roseville, CA

Tag Name: CT5\_NOx\_Norm\_LbPerHr\_1H

Total Operating Time: 78.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: -68.00 Hour(s) Report Time: 10.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Tag Value	Limit	Reason Code	Action Code
1	01/26/26 11:00	01/26/26 11:59	1	4.63	2.71	3 - Process Problems	19 - SHUT DOWN UNIT FOR REPAIR

Total Operating Time:	78.00 Hour(s)
Total Duration (Online only):	1.00 Hour(s)
Time in exceedance as a percentage of operating time:	1.28 %
Time in compliance as a percentage of operating time:	98.72 %

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Process Problems	1	100.00
19	Action	SHUT DOWN UNIT FOR REPAIR	1	100.00

# NOx Ppmvdc 1-Hour Block Excess Emissions

CT5

From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY  
 Generated: 04/01/2026 09:15 Location: Roseville, CA



Tag Name: CT5\_NOx\_Norm\_Ppmvdc\_1H

Total Operating Time: 78.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: -68.00 Hour(s) Report Time: 10.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Tag Value	Limit	Reason Code	Action Code
1	01/26/26 11:00	01/26/26 11:59	1	4.5	2.5	3 - Process Problems	19 - SHUT DOWN UNIT FOR REPAIR

Total Operating Time:	78.00 Hour(s)
Total Duration (Online only):	1.00 Hour(s)
Time in exceedance as a percentage of operating time:	1.28 %
Time in compliance as a percentage of operating time:	98.72 %

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Process Problems	1	100.00
19	Action	SHUT DOWN UNIT FOR REPAIR	1	100.00

# NOx Lbs SUSd 1-Hour Block Excess Emissions



CT5

From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY  
 Generated: 04/01/2026 09:18 Location: Roseville, CA

Tag Name: CT5\_NOx\_SUSd\_Lbs\_1H

Total Operating Time: 78.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: -54.00 Hour(s) Report Time: 24.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Tag Value	Limit	Reason Code	Action Code
1	01/19/26 18:00	01/19/26 18:59	1	8.59	6.50	2 - Control equipment problems	

Total Operating Time:	78.00 Hour(s)
Total Duration (Online only):	1.00 Hour(s)
Time in exceedance as a percentage of operating time:	1.28 %
Time in compliance as a percentage of operating time:	98.72 %

Report Code	Type	Text	Duration	Duration Percent
2	Reason	Control equipment problems	1	100.00

# Startup/Shutdown Event Report

## CT5 - NOx Lbs Per Startup/Shutdown



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 09:18 Location: Roseville, CA

Tag Name: CT5\_NOx\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

Total Operating Time: 61.67 Hours  
 Non-Operating Time: -37.67 Hours Report Time: 24.00 Hours

### Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
01/15/2026 12:51 01/15/2026 12:59 Startup	9	0.76	3.10		
01/15/2026 16:58 01/15/2026 17:05 Shutdown	8	0.10	3.40		
01/19/2026 18:32 01/19/2026 18:57 Startup	26	8.59 *	3.10		
01/19/2026 19:57 01/19/2026 20:04 Shutdown	8	0.14	3.40		
01/20/2026 16:57 01/20/2026 17:08 Startup	12	1.15	3.10		
01/20/2026 19:57 01/20/2026 20:04 Shutdown	8	0.13	3.40		
01/23/2026 08:50 01/23/2026 08:52 Startup	3	0.03	3.10		
01/23/2026 08:52 01/23/2026 08:57 Shutdown	6	0.26	3.40		
01/23/2026 09:06 01/23/2026 09:16 Startup	11	1.16	3.10		
01/23/2026 23:57 01/24/2026 00:04 Shutdown	8	0.13	3.40		
01/24/2026 20:41 01/24/2026 20:50 Startup	10	0.64	3.10		
01/24/2026 21:59 01/24/2026 22:06 Shutdown	8	0.16	3.40		
01/25/2026 13:44 01/25/2026 13:54 Startup	11	1.13	3.10		

# Startup/Shutdown Event Report

## CT5 - NOx Lbs Per Startup/Shutdown



**From:** 01/01/2026 00:00 **To:** 03/31/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 04/01/2026 09:18 **Location:** Roseville, CA

**Tag Name:** CT5\_NOx\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 61.67 Hours  
 Non-Operating Time: -37.67 Hours **Report Time:** 24.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
01/25/2026 21:58 01/25/2026 22:05 Shutdown	8	0.15	3.40		
01/26/2026 09:51 01/26/2026 10:01 Startup	11	0.81	3.10		
01/26/2026 11:42 01/26/2026 11:49 Shutdown	8	0.09	3.40		
01/26/2026 15:51 01/26/2026 16:00 Startup	10	0.99	3.10		
01/26/2026 21:57 01/26/2026 22:04 Shutdown	8	0.14	3.40		
01/27/2026 09:52 01/27/2026 10:01 Startup	10	1.16	3.10		
01/27/2026 21:58 01/27/2026 22:05 Shutdown	8	0.12	3.40		
02/04/2026 08:46 02/04/2026 08:57 Startup	12	1.18	3.10		
02/04/2026 16:00 02/04/2026 16:07 Shutdown	8	0.12	3.40		

<b>Total Duration of Excess Emission</b>	<b>26 Minute(s)</b>
<b>Time of Excess Emission as a percentage of operating time</b>	<b>0.70 %</b>
<b>Time in compliance as percentage of operating time</b>	<b>99.30 %</b>

# Startup/Shutdown Event Report

## CT5 - NOx Lbs Per Startup/Shutdown



**From:** 01/01/2026 00:00 **To:** 03/31/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 04/01/2026 09:18 **Location:** Roseville, CA

**Tag Name:** CT5\_NOX\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 61.67 Hours

Non-Operating Time: -37.67 Hours Report Time: 24.00 Hours

### Event Invalid Information

No invalid events were found in the reporting period.

# Startup/Shutdown Event Report

## CT5 - NOx Lbs Per Startup/Shutdown



**From:** 01/01/2026 00:00 **To:** 03/31/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 04/01/2026 09:18 **Location:** Roseville, CA

**Tag Name:** CT5\_NOx\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 61.67 Hours  
 Non-Operating Time: -37.67 Hours **Report Time:** 24.00 Hours

### Periodic Excess and Invalid Summary

Emission Data Summary
-----------------------

1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	26
2. Total Duration of Excess Emission in Minute(s)	26
3. Time of Excess Emission as a percentage of operating time	0.70
4. Time in compliance as percentage of operating time	99.30

CMS Performance Summary
-------------------------

1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

# PM10 LbPerHr 1-Hour Block Excess Emissions



CT5

From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 04/01/2026 09:18 Location: Roseville, CA

Tag Name: CT5\_PM10\_LbPerHr\_1H

Total Operating Time: 78.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 2,082.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	78.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

# S02 LbPerHr 1-Hour Block Excess Emissions



CT5

From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 04/01/2026 09:20 Location: Roseville, CA

Tag Name: CT5\_SO2\_P60\_LbPerHr\_1H

Total Operating Time: 78.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 2,082.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	78.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

# VOC LbPerHr 1-Hour Block Excess Emissions



CT5

From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 04/01/2026 09:20 Location: Roseville, CA

Tag Name: CT5\_VOC\_Norm\_LbPerHr\_1H

Total Operating Time: 78.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 2,082.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	78.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

# VOC SUSD Lb 1-Hour Block Excess Emissions



CT5

From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 04/01/2026 09:20 Location: Roseville, CA

Tag Name: CT5\_VOC\_SUSD\_Lbs\_1H

Total Operating Time: 78.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 2,082.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	78.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

# Startup/Shutdown Event Report

## CT5 - VOC Lbs Per Startup/Shutdown



**From:** 01/01/2026 00:00 **To:** 03/31/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 04/01/2026 09:20 **Location:** Roseville, CA

**Tag Name:** CT5\_VOC\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 61.67 Hours  
 Non-Operating Time: 2,098.33 Hours Report Time: 2,160.00 Hours

### Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
01/15/2026 12:51 01/15/2026 12:59 Startup	9	0.05	0.80		
01/15/2026 16:58 01/15/2026 17:05 Shutdown	8	0.02	0.90		
01/19/2026 18:32 01/19/2026 18:57 Startup	26	0.19	0.80		
01/19/2026 19:57 01/19/2026 20:04 Shutdown	8	0.03	0.90		
01/20/2026 16:57 01/20/2026 17:08 Startup	12	0.05	0.80		
01/20/2026 19:57 01/20/2026 20:04 Shutdown	8	0.02	0.90		
01/23/2026 08:50 01/23/2026 08:52 Startup	3	0.00	0.80		
01/23/2026 08:52 01/23/2026 08:57 Shutdown	6	0.01	0.90		
01/23/2026 09:06 01/23/2026 09:16 Startup	11	0.05	0.80		
01/23/2026 23:57 01/24/2026 00:04 Shutdown	8	0.02	0.90		
01/24/2026 20:41 01/24/2026 20:50 Startup	10	0.05	0.80		
01/24/2026 21:59 01/24/2026 22:06 Shutdown	8	0.03	0.90		
01/25/2026 13:44 01/25/2026 13:54 Startup	11	0.05	0.80		

# Startup/Shutdown Event Report

## CT5 - VOC Lbs Per Startup/Shutdown



**From:** 01/01/2026 00:00 **To:** 03/31/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 04/01/2026 09:20 **Location:** Roseville, CA

**Tag Name:** CT5\_VOC\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 61.67 Hours  
 Non-Operating Time: 2,098.33 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
01/25/2026 21:58 01/25/2026 22:05 Shutdown	8	0.02	0.90		
01/26/2026 09:51 01/26/2026 10:01 Startup	11	0.06	0.80		
01/26/2026 11:42 01/26/2026 11:49 Shutdown	8	0.02	0.90		
01/26/2026 15:51 01/26/2026 16:00 Startup	10	0.05	0.80		
01/26/2026 21:57 01/26/2026 22:04 Shutdown	8	0.02	0.90		
01/27/2026 09:52 01/27/2026 10:01 Startup	10	0.05	0.80		
01/27/2026 21:58 01/27/2026 22:05 Shutdown	8	0.02	0.90		
02/04/2026 08:46 02/04/2026 08:57 Startup	12	0.06	0.80		
02/04/2026 16:00 02/04/2026 16:07 Shutdown	8	0.02	0.90		

No excess emissions were found in the reporting period.

# Startup/Shutdown Event Report

## CT5 - VOC Lbs Per Startup/Shutdown



**From:** 01/01/2026 00:00 **To:** 03/31/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 04/01/2026 09:20

**Location:** Roseville, CA

**Tag Name:** CT5\_VOC\_LbPerHr\_1M

SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 61.67 Hours

Non-Operating Time: 2,098.33 Hours

Report Time: 2,160.00 Hours

### Event Invalid Information

No invalid events were found in the reporting period.

# Startup/Shutdown Event Report

## CT5 - VOC Lbs Per Startup/Shutdown



**From:** 01/01/2026 00:00 **To:** 03/31/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 04/01/2026 09:20 **Location:** Roseville, CA

**Tag Name:** CT5\_VOC\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 61.67 Hours

Non-Operating Time: 2,098.33 Hours Report Time: 2,160.00 Hours

### Periodic Excess and Invalid Summary

#### Emission Data Summary

1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

#### CMS Performance Summary

1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

# CO LbPerHr 1-Hour Block Excess Emissions

CT6

From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 04/01/2026 09:30 Location: Roseville, CA



Tag Name: CT6\_CO\_Norm\_LbPerHr\_1H

Total Operating Time: 76.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 2,084.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	76.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

# CO Ppmvdc 1-Hour Block Excess Emissions

CT6

From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 04/01/2026 09:30 Location: Roseville, CA



Tag Name: CT6\_CO\_Norm\_Ppmvdc\_1H

Total Operating Time: 76.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 2,084.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	76.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

# CO Lbs SUSd 1-Hour Block Excess Emissions

CT6

From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 04/01/2026 09:30 Location: Roseville, CA



Tag Name: CT6\_CO\_SUSD\_Lbs\_1H

Total Operating Time: 76.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 2,084.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	76.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

# Startup/Shutdown Event Report

## CT6 - CO Lbs Per Startup/Shutdown



**From:** 01/01/2026 00:00 **To:** 03/31/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 04/01/2026 09:30 **Location:** Roseville, CA

**Tag Name:** CT6\_CO\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 62.63 Hours  
 Non-Operating Time: 2,097.37 Hours Report Time: 2,160.00 Hours

### Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
01/19/2026 16:51 01/19/2026 17:01 Startup	11	1.32	19.40		
01/19/2026 19:57 01/19/2026 20:04 Shutdown	8	0.22	21.60		
01/20/2026 16:46 01/20/2026 16:58 Startup	13	1.05	19.40		
01/20/2026 19:57 01/20/2026 20:04 Shutdown	8	0.15	21.60		
01/23/2026 09:19 01/23/2026 09:30 Startup	12	1.23	19.40		
01/23/2026 23:57 01/24/2026 00:04 Shutdown	8	0.15	21.60		
01/24/2026 20:37 01/24/2026 20:48 Startup	12	0.90	19.40		
01/24/2026 21:59 01/24/2026 22:06 Shutdown	8	0.14	21.60		
01/25/2026 13:55 01/25/2026 14:04 Startup	10	0.83	19.40		
01/25/2026 14:04 01/25/2026 14:09 Shutdown	6	0.13	21.60		
01/25/2026 14:23 01/25/2026 14:32 Startup	10	0.46	19.40		
01/25/2026 21:58 01/25/2026 22:05 Shutdown	8	0.15	21.60		
01/26/2026 09:46 01/26/2026 09:56 Startup	11	0.92	19.40		

# Startup/Shutdown Event Report

## CT6 - CO Lbs Per Startup/Shutdown



**From:** 01/01/2026 00:00 **To:** 03/31/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 04/01/2026 09:30 **Location:** Roseville, CA

**Tag Name:** CT6\_CO\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 62.63 Hours  
 Non-Operating Time: 2,097.37 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
01/26/2026 21:57 01/26/2026 22:04 Shutdown	8	0.15	21.60		
01/27/2026 09:51 01/27/2026 10:01 Startup	11	0.83	19.40		
01/27/2026 21:58 01/27/2026 22:05 Shutdown	8	0.14	21.60		
02/05/2026 08:51 02/05/2026 09:04 Startup	14	1.18	19.40		
02/05/2026 16:00 02/05/2026 16:07 Shutdown	8	0.11	21.60		

No excess emissions were found in the reporting period.

# Startup/Shutdown Event Report

## CT6 - CO Lbs Per Startup/Shutdown



**From:** 01/01/2026 00:00 **To:** 03/31/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 04/01/2026 09:30

**Location:** Roseville, CA

**Tag Name:** CT6\_CO\_LbPerHr\_1M

SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 62.63 Hours

Non-Operating Time: 2,097.37 Hours

Report Time: 2,160.00 Hours

### Event Invalid Information

No invalid events were found in the reporting period.

# Startup/Shutdown Event Report

## CT6 - CO Lbs Per Startup/Shutdown



**From:** 01/01/2026 00:00 **To:** 03/31/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 04/01/2026 09:30 **Location:** Roseville, CA

**Tag Name:** CT6\_CO\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 62.63 Hours  
 Non-Operating Time: 2,097.37 Hours Report Time: 2,160.00 Hours

### Periodic Excess and Invalid Summary

Emission Data Summary	CMS Performance Summary
<ol style="list-style-type: none"> <li>1. Duration of excess emission in event reporting period due to:                             <ol style="list-style-type: none"> <li>a. Startup/shutdown <span style="float: right;">0</span></li> <li>b. Control equipment problems <span style="float: right;">0</span></li> <li>c. Process problems <span style="float: right;">0</span></li> <li>d. Other known causes <span style="float: right;">0</span></li> <li>e. Unknown causes <span style="float: right;">0</span></li> </ol> </li> <li>2. Total Duration of Excess Emission in Minute(s) <span style="float: right;">0</span></li> <li>3. Time of Excess Emission as a percentage of operating time <span style="float: right;">0.00</span></li> <li>4. Time in compliance as percentage of operating time <span style="float: right;">100.00</span></li> </ol>	<ol style="list-style-type: none"> <li>1. CMS downtime in event reporting period due to:                             <ol style="list-style-type: none"> <li>a. Monitor equipment malfunctions <span style="float: right;">0</span></li> <li>b. Non-Monitor equipment malfunctions <span style="float: right;">0</span></li> <li>c. Quality assurance calibration <span style="float: right;">0</span></li> <li>d. Other known causes <span style="float: right;">0</span></li> <li>e. Unknown causes <span style="float: right;">0</span></li> </ol> </li> <li>2. Total CMS Downtime in Minute(s) <span style="float: right;">0</span></li> <li>3. Total Downtime as a percentage of operating time <span style="float: right;">0.00</span></li> <li>4. Total Availability as a percentage of operating time <span style="float: right;">100.00</span></li> </ol>

# Heat Input MBtuPerHr 1-Hour Block Excess Emissions



CT6

From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 04/01/2026 09:30 Location: Roseville, CA

Tag Name: CT6\_HI\_MBtuPerHr\_1H

Total Operating Time: 76.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 486.00 Hour(s) Report Time: 562.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	76.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

# NH3 Slip Ppmvdc 1-Hour Block Excess Emissions



CT6

From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 04/01/2026 09:32 Location: Roseville, CA

Tag Name: CT6\_NH3Slip\_Ppmvdc\_1H

Total Operating Time: 76.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 2,084.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	76.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

# NOx LbPerHr 1-Hour Block Excess Emissions



CT6

From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 04/01/2026 09:32 Location: Roseville, CA

Tag Name: CT6\_NOx\_Norm\_LbPerHr\_1H

Total Operating Time: 76.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: -63.00 Hour(s) Report Time: 13.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	76.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

# NOx Ppmvdc 1-Hour Block Excess Emissions



CT6

From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 04/01/2026 09:32 Location: Roseville, CA

Tag Name: CT6\_NOx\_Norm\_Ppmvdc\_1H

Total Operating Time: 76.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: -63.00 Hour(s) Report Time: 13.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	76.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

# NOx Lbs SUSD 1-Hour Block Excess Emissions



CT6

From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 04/01/2026 09:32 Location: Roseville, CA

Tag Name: CT6\_NOx\_SUSD\_Lbs\_1H

Total Operating Time: 76.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 2,084.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	76.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

# Startup/Shutdown Event Report

## CT6 - NOx Lbs Per Startup/Shutdown



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 09:32 Location: Roseville, CA

Tag Name: CT6\_NOx\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

Total Operating Time: 62.63 Hours  
 Non-Operating Time: 2,097.37 Hours Report Time: 2,160.00 Hours

### Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
01/19/2026 16:51 01/19/2026 17:01 Startup	11	0.96	3.10		
01/19/2026 19:57 01/19/2026 20:04 Shutdown	8	0.14	3.40		
01/20/2026 16:46 01/20/2026 16:58 Startup	13	0.98	3.10		
01/20/2026 19:57 01/20/2026 20:04 Shutdown	8	0.13	3.40		
01/23/2026 09:19 01/23/2026 09:30 Startup	12	1.06	3.10		
01/23/2026 23:57 01/24/2026 00:04 Shutdown	8	0.13	3.40		
01/24/2026 20:37 01/24/2026 20:48 Startup	12	0.99	3.10		
01/24/2026 21:59 01/24/2026 22:06 Shutdown	8	0.14	3.40		
01/25/2026 13:55 01/25/2026 14:04 Startup	10	0.49	3.10		
01/25/2026 14:04 01/25/2026 14:09 Shutdown	6	0.35	3.40		
01/25/2026 14:23 01/25/2026 14:32 Startup	10	0.88	3.10		
01/25/2026 21:58 01/25/2026 22:05 Shutdown	8	0.13	3.40		
01/26/2026 09:46 01/26/2026 09:56 Startup	11	0.86	3.10		

# Startup/Shutdown Event Report

## CT6 - NOx Lbs Per Startup/Shutdown



**From:** 01/01/2026 00:00 **To:** 03/31/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 04/01/2026 09:32

**Location:** Roseville, CA

**Tag Name:** CT6\_NOx\_LbPerHr\_1M

SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 62.63 Hours

Non-Operating Time: 2,097.37 Hours

Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
01/26/2026 21:57 01/26/2026 22:04 Shutdown	8	0.13	3.40		
01/27/2026 09:51 01/27/2026 10:01 Startup	11	0.98	3.10		
01/27/2026 21:58 01/27/2026 22:05 Shutdown	8	0.11	3.40		
02/05/2026 08:51 02/05/2026 09:04 Startup	14	1.06	3.10		
02/05/2026 16:00 02/05/2026 16:07 Shutdown	8	0.11	3.40		

No excess emissions were found in the reporting period.

# Startup/Shutdown Event Report

## CT6 - NOx Lbs Per Startup/Shutdown



**From:** 01/01/2026 00:00 **To:** 03/31/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 04/01/2026 09:32

**Location:** Roseville, CA

**Tag Name:** CT6\_NOX\_LbPerHr\_1M

SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 62.63 Hours

Non-Operating Time: 2,097.37 Hours

Report Time: 2,160.00 Hours

### Event Invalid Information

No invalid events were found in the reporting period.

# Startup/Shutdown Event Report

## CT6 - NOx Lbs Per Startup/Shutdown



**From:** 01/01/2026 00:00 **To:** 03/31/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 04/01/2026 09:32 **Location:** Roseville, CA

**Tag Name:** CT6\_NOx\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 62.63 Hours  
 Non-Operating Time: 2,097.37 Hours Report Time: 2,160.00 Hours

### Periodic Excess and Invalid Summary

Emission Data Summary	CMS Performance Summary
<ol style="list-style-type: none"> <li>1. Duration of excess emission in event reporting period due to:                             <ol style="list-style-type: none"> <li>a. Startup/shutdown 0</li> <li>b. Control equipment problems 0</li> <li>c. Process problems 0</li> <li>d. Other known causes 0</li> <li>e. Unknown causes 0</li> </ol> </li> <li>2. Total Duration of Excess Emission in Minute(s) 0</li> <li>3. Time of Excess Emission as a percentage of operating time 0.00</li> <li>4. Time in compliance as percentage of operating time 100.00</li> </ol>	<ol style="list-style-type: none"> <li>1. CMS downtime in event reporting period due to:                             <ol style="list-style-type: none"> <li>a. Monitor equipment malfunctions 0</li> <li>b. Non-Monitor equipment malfunctions 0</li> <li>c. Quality assurance calibration 0</li> <li>d. Other known causes 0</li> <li>e. Unknown causes 0</li> </ol> </li> <li>2. Total CMS Downtime in Minute(s) 0</li> <li>3. Total Downtime as a percentage of operating time 0.00</li> <li>4. Total Availability as a percentage of operating time 100.00</li> </ol>

# PM10 LbPerHr 1-Hour Block Excess Emissions



CT6

From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 04/01/2026 09:32 Location: Roseville, CA

Tag Name: CT6\_PM10\_LbPerHr\_1H

Total Operating Time: 76.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 2,084.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	76.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

# S02 LbPerHr 1-Hour Block Excess Emissions



CT6

From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 04/01/2026 09:35 Location: Roseville, CA

Tag Name: CT6\_SO2\_P60\_LbPerHr\_1H

Total Operating Time: 76.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 2,084.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	76.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

# VOC LbPerHr 1-Hour Block Excess Emissions



CT6

From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 04/01/2026 09:35 Location: Roseville, CA

Tag Name: CT6\_VOC\_Norm\_LbPerHr\_1H

Total Operating Time: 76.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 2,084.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	76.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

# VOC SUSL Lb 1-Hour Block Excess Emissions



CT6

From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY  
Generated: 04/01/2026 09:35 Location: Roseville, CA

Tag Name: CT6\_VOC\_SUSL\_Lbs\_1H

Total Operating Time: 76.00 Hour(s)

No Exclusions Allowed

Non-Operating Time: 2,084.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	76.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

# Startup/Shutdown Event Report

## CT6 - VOC Lbs Per Startup/Shutdown



From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY

Generated: 04/01/2026 09:35 Location: Roseville, CA

Tag Name: CT6\_VOC\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

Total Operating Time: 62.63 Hours  
 Non-Operating Time: 2,097.37 Hours Report Time: 2,160.00 Hours

### Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
01/19/2026 16:51 01/19/2026 17:01 Startup	11	0.05	0.80		
01/19/2026 19:57 01/19/2026 20:04 Shutdown	8	0.03	0.90		
01/20/2026 16:46 01/20/2026 16:58 Startup	13	0.06	0.80		
01/20/2026 19:57 01/20/2026 20:04 Shutdown	8	0.02	0.90		
01/23/2026 09:19 01/23/2026 09:30 Startup	12	0.05	0.80		
01/23/2026 23:57 01/24/2026 00:04 Shutdown	8	0.02	0.90		
01/24/2026 20:37 01/24/2026 20:48 Startup	12	0.05	0.80		
01/24/2026 21:59 01/24/2026 22:06 Shutdown	8	0.03	0.90		
01/25/2026 13:55 01/25/2026 14:04 Startup	10	0.01	0.80		
01/25/2026 14:04 01/25/2026 14:09 Shutdown	6	0.01	0.90		
01/25/2026 14:23 01/25/2026 14:32 Startup	10	0.05	0.80		
01/25/2026 21:58 01/25/2026 22:05 Shutdown	8	0.02	0.90		
01/26/2026 09:46 01/26/2026 09:56 Startup	11	0.05	0.80		

# Startup/Shutdown Event Report

## CT6 - VOC Lbs Per Startup/Shutdown



**From:** 01/01/2026 00:00 **To:** 03/31/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 04/01/2026 09:35

**Location:** Roseville, CA

**Tag Name:** CT6\_VOC\_LbPerHr\_1M

SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 62.63 Hours

Non-Operating Time: 2,097.37 Hours

Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
01/26/2026 21:57 01/26/2026 22:04 Shutdown	8	0.02	0.90		
01/27/2026 09:51 01/27/2026 10:01 Startup	11	0.05	0.80		
01/27/2026 21:58 01/27/2026 22:05 Shutdown	8	0.02	0.90		
02/05/2026 08:51 02/05/2026 09:04 Startup	14	0.05	0.80		
02/05/2026 16:00 02/05/2026 16:07 Shutdown	8	0.02	0.90		

No excess emissions were found in the reporting period.

# Startup/Shutdown Event Report

## CT6 - VOC Lbs Per Startup/Shutdown



**From:** 01/01/2026 00:00 **To:** 03/31/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 04/01/2026 09:35

**Location:** Roseville, CA

**Tag Name:** CT6\_VOC\_LbPerHr\_1M

SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 62.63 Hours

Non-Operating Time: 2,097.37 Hours

Report Time: 2,160.00 Hours

### Event Invalid Information

No invalid events were found in the reporting period.

# Startup/Shutdown Event Report

## CT6 - VOC Lbs Per Startup/Shutdown



**From:** 01/01/2026 00:00 **To:** 03/31/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 04/01/2026 09:35 **Location:** Roseville, CA

**Tag Name:** CT6\_VOC\_LbPerHr\_1M SI = SampleInvalid, \* = Excess Emission

**Total Operating Time:** 62.63 Hours  
 Non-Operating Time: 2,097.37 Hours Report Time: 2,160.00 Hours

### Periodic Excess and Invalid Summary

Emission Data Summary
-----------------------

1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary
-------------------------

1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

# CO Invalid Data

CT5

**From:** 01/01/2026 00:00 **To:** 03/31/2026 23:59 **Facility Name:** ROSEVILLE ENERGY  
**Generated:** 04/01/2026 09:40 **Location:** Roseville, CA



**Tag Name:** CT5\_CO\_Ppm\_1H

**Total Operating Time:** 78.00 Hour(s)

Non-Operating Time: 2,082.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

<b>Total Operating Time:</b>	<b>78.00 Hour(s)</b>
<b>Total Monitor Downtime (Online only):</b>	<b>0.00 Hour(s)</b>
<b>Percent Monitor Availability:</b>	<b>100.00 %</b>
<b>Percent Monitor Downtime:</b>	<b>0.00 %</b>

# NOx Invalid Data

CT5

**From:** 01/01/2026 00:00 **To:** 03/31/2026 23:59 **Facility Name:** ROSEVILLE ENERGY  
**Generated:** 04/01/2026 09:40 **Location:** Roseville, CA



**Tag Name:** CT5\_NOx\_Ppm\_1H

**Total Operating Time:** 78.00 Hour(s)

Non-Operating Time: 2,082.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

<b>Total Operating Time:</b>	<b>78.00 Hour(s)</b>
<b>Total Monitor Downtime (Online only):</b>	<b>0.00 Hour(s)</b>
<b>Percent Monitor Availability:</b>	<b>100.00 %</b>
<b>Percent Monitor Downtime:</b>	<b>0.00 %</b>

# NOx SCR Invalid Data



CT5

**From:** 01/01/2026 00:00 **To:** 03/31/2026 23:59 **Facility Name:** ROSEVILLE ENERGY  
**Generated:** 04/01/2026 09:40 **Location:** Roseville, CA

---

**Tag Name:** CT5\_NOx\_SCR\_Ppm\_1H

**Total Operating Time:** 78.00 Hour(s)

Non-Operating Time: 2,082.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

<b>Total Operating Time:</b>	<b>78.00 Hour(s)</b>
<b>Total Monitor Downtime (Online only):</b>	<b>0.00 Hour(s)</b>
<b>Percent Monitor Availability:</b>	<b>100.00 %</b>
<b>Percent Monitor Downtime:</b>	<b>0.00 %</b>

# O2 Invalid Data

CT5

**From:** 01/01/2026 00:00 **To:** 03/31/2026 23:59 **Facility Name:** ROSEVILLE ENERGY  
**Generated:** 04/01/2026 09:40 **Location:** Roseville, CA



**Tag Name:** CT5\_O2Dry\_Pct\_1H

**Total Operating Time:** 78.00 Hour(s)

Non-Operating Time: 2,082.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

<b>Total Operating Time:</b>	<b>78.00 Hour(s)</b>
<b>Total Monitor Downtime (Online only):</b>	<b>0.00 Hour(s)</b>
<b>Percent Monitor Availability:</b>	<b>100.00 %</b>
<b>Percent Monitor Downtime:</b>	<b>0.00 %</b>

# CO Invalid Data

CT6

**From:** 01/01/2026 00:00 **To:** 03/31/2026 23:59 **Facility Name:** ROSEVILLE ENERGY  
**Generated:** 04/01/2026 09:45 **Location:** Roseville, CA



**Tag Name:** CT6\_CO\_Ppm\_1H

**Total Operating Time:** 76.00 Hour(s)

Non-Operating Time: 2,084.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

<b>Total Operating Time:</b>	<b>76.00 Hour(s)</b>
<b>Total Monitor Downtime (Online only):</b>	<b>0.00 Hour(s)</b>
<b>Percent Monitor Availability:</b>	<b>100.00 %</b>
<b>Percent Monitor Downtime:</b>	<b>0.00 %</b>

# NOx Invalid Data

CT6

**From:** 01/01/2026 00:00 **To:** 03/31/2026 23:59 **Facility Name:** ROSEVILLE ENERGY  
**Generated:** 04/01/2026 09:45 **Location:** Roseville, CA



**Tag Name:** CT6\_NOx\_Ppm\_1H

**Total Operating Time:** 76.00 Hour(s)

Non-Operating Time: 2,084.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

<b>Total Operating Time:</b>	<b>76.00 Hour(s)</b>
<b>Total Monitor Downtime (Online only):</b>	<b>0.00 Hour(s)</b>
<b>Percent Monitor Availability:</b>	<b>100.00 %</b>
<b>Percent Monitor Downtime:</b>	<b>0.00 %</b>

# NOx SCR Invalid Data

CT6

From: 01/01/2026 00:00 To: 03/31/2026 23:59  
Generated: 04/01/2026 09:45

Facility Name: ROSEVILLE ENERGY  
Location: Roseville, CA



Tag Name: CT6\_NOx\_SCR\_Ppm\_1H

Total Operating Time: 76.00 Hour(s)

Non-Operating Time: 2,084.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	76.00 Hour(s)
Total Monitor Downtime (Online only):	0.00 Hour(s)
Percent Monitor Availability:	100.00 %
Percent Monitor Downtime:	0.00 %

# O2 Invalid Data

CT6

**From:** 01/01/2026 00:00 **To:** 03/31/2026 23:59 **Facility Name:** ROSEVILLE ENERGY  
**Generated:** 04/01/2026 09:45 **Location:** Roseville, CA



**Tag Name:** CT6\_O2Dry\_Pct\_1H

**Total Operating Time:** 76.00 Hour(s)

Non-Operating Time: 2,084.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

<b>Total Operating Time:</b>	<b>76.00 Hour(s)</b>
<b>Total Monitor Downtime (Online only):</b>	<b>0.00 Hour(s)</b>
<b>Percent Monitor Availability:</b>	<b>100.00 %</b>
<b>Percent Monitor Downtime:</b>	<b>0.00 %</b>

# CO Ppmvdc EDS/CMS Summary Report



CT5

From: 01/01/2026 00:00 To: 03/31/2026 23:59  
 Generated: 04/01/2026 09:50

Facility Name: ROSEVILLE ENERGY  
 Location: Roseville, CA  
 Description: Electric Utility

CMS Data from: CT5\_CO\_Norm\_Ppmvdc\_1H, CT5\_UnitOn\_TF\_1H  
 EDS Data from: CT5\_CO\_Norm\_Ppmvdc\_1H, CT5\_UnitOn\_TF\_1H  
 Emission Limitation: 4.0  
 No Value Exclusions Allowed  
 Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, T300  
 Date of Latest CMS Certification or Audit: 04/01/2024 00:00  
 Process Unit(s) Description:  
 Operating time for EDS: 78.00 Hour(s)  
 Operating time for CMS: 78.00 Hour(s)

<b>Emission Data Summary</b>
------------------------------

1. Duration of excess emission in reporting period due to:	0
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

<b>CMS Performance Summary</b>
--------------------------------

1. CMS downtime in reporting period due to:	0
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	15
2. Total CMS Downtime	15
3. Total Downtime as a percentage of operating time	19.23
4. Total Availability as a percentage of operating time	80.77

# CO Lb/Hr EDS/CMS Summary Report

CT5

From: 01/01/2026 00:00 To: 03/31/2026 23:59  
 Generated: 04/01/2026 09:50

Facility Name: ROSEVILLE ENERGY  
 Location: Roseville, CA  
 Description: Electric Utility



CMS Data from: CT5\_CO\_Norm\_LbPerHr\_1H, CT5\_UnitOn\_TF\_1H  
 EDS Data from: CT5\_CO\_Norm\_LbPerHr\_1H, CT5\_UnitOn\_TF\_1H  
 Emission Limitation: 2.64  
 No Value Exclusions Allowed  
 Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, T300  
 Date of Latest CMS Certification or Audit: 04/01/2024 00:00  
 Process Unit(s) Description:  
 Operating time for EDS: 78.00 Hour(s)  
 Operating time for CMS: 78.00 Hour(s)

<b>Emission Data Summary</b>
------------------------------

1. Duration of excess emission in reporting period due to:	0
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

<b>CMS Performance Summary</b>
--------------------------------

1. CMS downtime in reporting period due to:	0
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	15
2. Total CMS Downtime	15
3. Total Downtime as a percentage of operating time	19.23
4. Total Availability as a percentage of operating time	80.77

# CO SUSD Lb/Hr EDS/CMS Summary Report



CT5

From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY  
 Generated: 04/01/2026 09:50 Location: Roseville, CA  
 Description: Electric Utility

CMS Data from: CT5\_CO\_SUSD\_Lbs\_1H, CT5\_UnitOn\_TF\_1H  
 EDS Data from: CT5\_CO\_SUSD\_Lbs\_1H, CT5\_UnitOn\_TF\_1H  
 Emission Limitation: 41.00  
 No Value Exclusions Allowed  
 Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, T300  
 Date of Latest CMS Certification or Audit: 04/01/2024 00:00  
 Process Unit(s) Description:  
 Operating time for EDS: 78.00 Hour(s)  
 Operating time for CMS: 78.00 Hour(s)

<b>Emission Data Summary</b>
------------------------------

1. Duration of excess emission in reporting period due to:	0
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

<b>CMS Performance Summary</b>
--------------------------------

1. CMS downtime in reporting period due to:	0
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	14
2. Total CMS Downtime	14
3. Total Downtime as a percentage of operating time	17.95
4. Total Availability as a percentage of operating time	82.05

# NOx Ppmvdc EDS/CMS Summary Report



CT5

From: 01/01/2026 00:00 To: 03/31/2026 23:59  
 Generated: 04/01/2026 09:50

Facility Name: ROSEVILLE ENERGY  
 Location: Roseville, CA  
 Description: Electric Utility

CMS Data from: CT5\_NOx\_Norm\_Ppmvdc\_1H, CT5\_UnitOn\_TF\_1H  
 EDS Data from: CT5\_NOx\_Norm\_Ppmvdc\_1H, CT5\_UnitOn\_TF\_1H  
 Emission Limitation: 2.5  
 No Value Exclusions Allowed  
 Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, T200H  
 Date of Latest CMS Certification or Audit: 04/01/2024 00:00  
 Process Unit(s) Description:  
 Operating time for EDS: 78.00 Hour(s)  
 Operating time for CMS: 78.00 Hour(s)

<b>Emission Data Summary</b>
------------------------------

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	1
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	1
4. Time of Excess Emission as a percentage of operating time	1.28
5. Time in compliance as percentage of operating time	98.72

<b>CMS Performance Summary</b>
--------------------------------

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	15
2. Total CMS Downtime	15
3. Total Downtime as a percentage of operating time	19.23
4. Total Availability as a percentage of operating time	80.77

# NOx Lb/Hr EDS/CMS Summary Report



CT5

From: 01/01/2026 00:00 To: 03/31/2026 23:59  
 Generated: 04/01/2026 09:50

Facility Name: ROSEVILLE ENERGY  
 Location: Roseville, CA  
 Description: Electric Utility

CMS Data from: CT5\_NOx\_Norm\_LbPerHr\_1H, CT5\_UnitOn\_TF\_1H  
 EDS Data from: CT5\_NOx\_Norm\_LbPerHr\_1H, CT5\_UnitOn\_TF\_1H  
 Emission Limitation: 2.71  
 No Value Exclusions Allowed  
 Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, T200H  
 Date of Latest CMS Certification or Audit: 04/01/2024 00:00  
 Process Unit(s) Description:  
 Operating time for EDS: 78.00 Hour(s)  
 Operating time for CMS: 78.00 Hour(s)

<b>Emission Data Summary</b>
------------------------------

1. Duration of excess emission in reporting period due to:	0
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	1
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	1
4. Time of Excess Emission as a percentage of operating time	1.28
5. Time in compliance as percentage of operating time	98.72

<b>CMS Performance Summary</b>
--------------------------------

1. CMS downtime in reporting period due to:	0
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	15
2. Total CMS Downtime	15
3. Total Downtime as a percentage of operating time	19.23
4. Total Availability as a percentage of operating time	80.77

# NOx SUSD Lb/Hr EDS/CMS Summary Report



CT5

From: 01/01/2026 00:00 To: 03/31/2026 23:59  
 Generated: 04/01/2026 09:50

Facility Name: ROSEVILLE ENERGY  
 Location: Roseville, CA  
 Description: Electric Utility

CMS Data from: CT5\_NOx\_SUSD\_Lbs\_1H, CT5\_UnitOn\_TF\_1H  
 EDS Data from: CT5\_NOx\_SUSD\_Lbs\_1H, CT5\_UnitOn\_TF\_1H  
 Emission Limitation: 6.50  
 No Value Exclusions Allowed  
 Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, T200H  
 Date of Latest CMS Certification or Audit: 04/01/2024 00:00  
 Process Unit(s) Description:  
 Operating time for EDS: 78.00 Hour(s)  
 Operating time for CMS: 78.00 Hour(s)

<b>Emission Data Summary</b>
------------------------------

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	1
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	1
4. Time of Excess Emission as a percentage of operating time	1.28
5. Time in compliance as percentage of operating time	98.72

<b>CMS Performance Summary</b>
--------------------------------

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	14
2. Total CMS Downtime	14
3. Total Downtime as a percentage of operating time	17.95
4. Total Availability as a percentage of operating time	82.05

# CO Ppmvdc EDS/CMS Summary Report



CT6

From: 01/01/2026 00:00 To: 03/31/2026 23:59  
 Generated: 04/01/2026 09:50

Facility Name: ROSEVILLE ENERGY  
 Location: Roseville, CA  
 Description: Electric Utility

CMS Data from: CT6\_CO\_Norm\_Ppmvdc\_1H, CT6\_UnitOn\_TF\_1H  
 EDS Data from: CT6\_CO\_Norm\_Ppmvdc\_1H, CT6\_UnitOn\_TF\_1H  
 Emission Limitation: 4.0  
 No Value Exclusions Allowed  
 Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, T300  
 Date of Latest CMS Certification or Audit: 04/01/2024 00:00  
 Process Unit(s) Description:  
 Operating time for EDS: 76.00 Hour(s)  
 Operating time for CMS: 76.00 Hour(s)

<b>Emission Data Summary</b>
------------------------------

1. Duration of excess emission in reporting period due to:	0
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

<b>CMS Performance Summary</b>
--------------------------------

1. CMS downtime in reporting period due to:	0
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	12
2. Total CMS Downtime	12
3. Total Downtime as a percentage of operating time	15.79
4. Total Availability as a percentage of operating time	84.21

# CO Lb/Hr EDS/CMS Summary Report

CT6

From: 01/01/2026 00:00 To: 03/31/2026 23:59  
 Generated: 04/01/2026 09:50

Facility Name: ROSEVILLE ENERGY  
 Location: Roseville, CA  
 Description: Electric Utility



CMS Data from: CT6\_CO\_Norm\_LbPerHr\_1H, CT6\_UnitOn\_TF\_1H  
 EDS Data from: CT6\_CO\_Norm\_LbPerHr\_1H, CT6\_UnitOn\_TF\_1H  
 Emission Limitation: 2.64  
 No Value Exclusions Allowed  
 Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, T300  
 Date of Latest CMS Certification or Audit: 04/01/2024 00:00  
 Process Unit(s) Description:  
 Operating time for EDS: 76.00 Hour(s)  
 Operating time for CMS: 76.00 Hour(s)

### Emission Data Summary

1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

### CMS Performance Summary

1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	12
2. Total CMS Downtime	12
3. Total Downtime as a percentage of operating time	15.79
4. Total Availability as a percentage of operating time	84.21

# CO SUSD Lb/Hr EDS/CMS Summary Report



CT6

From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY  
 Generated: 04/01/2026 09:50 Location: Roseville, CA  
 Description: Electric Utility

CMS Data from: CT6\_CO\_SUSD\_Lbs\_1H, CT6\_UnitOn\_TF\_1H  
 EDS Data from: CT6\_CO\_SUSD\_Lbs\_1H, CT6\_UnitOn\_TF\_1H  
 Emission Limitation: 41.00  
 No Value Exclusions Allowed  
 Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, T300  
 Date of Latest CMS Certification or Audit: 04/01/2024 00:00  
 Process Unit(s) Description:  
 Operating time for EDS: 76.00 Hour(s)  
 Operating time for CMS: 76.00 Hour(s)

<b>Emission Data Summary</b>
------------------------------

1. Duration of excess emission in reporting period due to:	0
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

<b>CMS Performance Summary</b>
--------------------------------

1. CMS downtime in reporting period due to:	0
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	13
2. Total CMS Downtime	13
3. Total Downtime as a percentage of operating time	17.11
4. Total Availability as a percentage of operating time	82.89

# NOx Ppmvdc EDS/CMS Summary Report



CT6

From: 01/01/2026 00:00 To: 03/31/2026 23:59  
 Generated: 04/01/2026 09:50

Facility Name: ROSEVILLE ENERGY  
 Location: Roseville, CA  
 Description: Electric Utility

CMS Data from: CT6\_NOx\_Norm\_Ppmvdc\_1H, CT6\_UnitOn\_TF\_1H  
 EDS Data from: CT6\_NOx\_Norm\_Ppmvdc\_1H, CT6\_UnitOn\_TF\_1H  
 Emission Limitation: 2.5  
 No Value Exclusions Allowed  
 Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, T200H  
 Date of Latest CMS Certification or Audit: 04/01/2024 00:00  
 Process Unit(s) Description:  
 Operating time for EDS: 76.00 Hour(s)  
 Operating time for CMS: 76.00 Hour(s)

<b>Emission Data Summary</b>
------------------------------

1. Duration of excess emission in reporting period due to:	0
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

<b>CMS Performance Summary</b>
--------------------------------

1. CMS downtime in reporting period due to:	0
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	12
2. Total CMS Downtime	12
3. Total Downtime as a percentage of operating time	15.79
4. Total Availability as a percentage of operating time	84.21

# NOx Lb/Hr EDS/CMS Summary Report



CT6

From: 01/01/2026 00:00 To: 03/31/2026 23:59  
 Generated: 04/01/2026 09:50

Facility Name: ROSEVILLE ENERGY  
 Location: Roseville, CA  
 Description: Electric Utility

CMS Data from: CT6\_NOx\_Norm\_LbPerHr\_1H, CT6\_UnitOn\_TF\_1H  
 EDS Data from: CT6\_NOx\_Norm\_LbPerHr\_1H, CT6\_UnitOn\_TF\_1H  
 Emission Limitation: 2.71  
 No Value Exclusions Allowed  
 Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, T200H  
 Date of Latest CMS Certification or Audit: 04/01/2024 00:00  
 Process Unit(s) Description:  
 Operating time for EDS: 76.00 Hour(s)  
 Operating time for CMS: 76.00 Hour(s)

<b>Emission Data Summary</b>
------------------------------

1. Duration of excess emission in reporting period due to:	0
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

<b>CMS Performance Summary</b>
--------------------------------

1. CMS downtime in reporting period due to:	0
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	12
2. Total CMS Downtime	12
3. Total Downtime as a percentage of operating time	15.79
4. Total Availability as a percentage of operating time	84.21

# NOx SUSD Lb/Hr EDS/CMS Summary Report



CT6

From: 01/01/2026 00:00 To: 03/31/2026 23:59 Facility Name: ROSEVILLE ENERGY  
 Generated: 04/01/2026 09:50 Location: Roseville, CA  
 Description: Electric Utility

CMS Data from: CT6\_NOx\_SUSD\_Lbs\_1H, CT6\_UnitOn\_TF\_1H  
 EDS Data from: CT6\_NOx\_SUSD\_Lbs\_1H, CT6\_UnitOn\_TF\_1H  
 Emission Limitation: 6.50  
 No Value Exclusions Allowed  
 Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, T200H  
 Date of Latest CMS Certification or Audit: 04/01/2024 00:00  
 Process Unit(s) Description:  
 Operating time for EDS: 76.00 Hour(s)  
 Operating time for CMS: 76.00 Hour(s)

<b>Emission Data Summary</b>
------------------------------

1. Duration of excess emission in reporting period due to:	0
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

<b>CMS Performance Summary</b>
--------------------------------

1. CMS downtime in reporting period due to:	0
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	13
2. Total CMS Downtime	13
3. Total Downtime as a percentage of operating time	17.11
4. Total Availability as a percentage of operating time	82.89

# Cylinder Gas Audit

04/13/2026

Page 1

Facility: ROSEVILLE ENERGY

Instrument Name: CT5\_CODualRg\_P\_Instrum

Unit/Stack: CT5

Test Date: 02/04/2026

Performance Spec: 15 Pct

Parameter/Scale: CO / Low

Test Result: **Pass**

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
02/04/2026	10:37	L	20	5.100	5.100	25.5 %
02/04/2026	10:42	M	20	11.100	11.200	55.5 %
02/04/2026	10:54	L	20	5.100	5.000	25.5 %
02/04/2026	10:59	M	20	11.100	11.100	55.5 %
02/04/2026	11:11	L	20	5.100	5.100	25.5 %
02/04/2026	11:16	M	20	11.100	11.100	55.5 %

**Summary Statistics:**

Cal Gas Level	Reference	Mean	CEMS Mean	Specification Used	Results
L	5.100		5.067	Std	<b>0.7</b>
M	11.100		11.133	Std	<b>0.3</b>

# Cylinder Gas Audit

04/13/2026

Page 2

Facility: ROSEVILLE ENERGY

Instrument Name: CT5\_CODualRg\_P\_Instrum

Unit/Stack: CT5

Test Date: 02/04/2026

Performance Spec: 15 Pct

Parameter/Scale: CO / High

Test Result: **Pass**

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
02/04/2026	13:36	L	1000	245.400	259.100	24.5 %
02/04/2026	13:41	M	1000	559.500	557.600	56.0 %
02/04/2026	13:48	L	1000	245.400	258.300	24.5 %
02/04/2026	13:53	M	1000	559.500	557.200	56.0 %
02/04/2026	14:00	L	1000	245.400	259.800	24.5 %
02/04/2026	14:05	M	1000	559.500	556.800	56.0 %

**Summary Statistics:**

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	245.400	259.067	Std	<b>5.6</b>
M	559.500	557.200	Std	<b>0.4</b>

# Cylinder Gas Audit

04/13/2026

Page 1

Facility: ROSEVILLE ENERGY

Instrument Name: CT6\_CODualRg\_P\_Instrum

Unit/Stack: CT6

Test Date: 02/05/2026

Performance Spec: 15 Pct

Parameter/Scale: CO / Low

Test Result: **Pass**

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
02/05/2026	10:52	L	20	5.000	5.400	25.0 %
02/05/2026	10:57	M	20	11.200	11.300	56.0 %
02/05/2026	11:09	L	20	5.000	5.400	25.0 %
02/05/2026	11:14	M	20	11.200	11.200	56.0 %
02/05/2026	11:26	L	20	5.000	5.400	25.0 %
02/05/2026	11:31	M	20	11.200	11.200	56.0 %

**Summary Statistics:**

Cal Gas Level	Reference	Mean	CEMS Mean	Specification Used	Results
L	5.000		5.400	Std	<b>8.0</b>
M	11.200		11.233	Std	<b>0.3</b>

# Cylinder Gas Audit

04/13/2026

Page 2

Facility:	ROSEVILLE ENERGY	Instrument Name:	CT6_CODualRg_P_Instrum
Unit/Stack:	CT6	Test Date:	02/05/2026
Parameter/Scale:	CO / High	Test Result:	<b>Pass</b>
		Performance Spec:	15 Pct
		Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
02/05/2026	13:42	L	1000	253.000	257.500	25.3 %
02/05/2026	13:47	M	1000	571.000	572.600	57.1 %
02/05/2026	13:54	L	1000	253.000	259.800	25.3 %
02/05/2026	13:59	M	1000	571.000	571.000	57.1 %
02/05/2026	14:06	L	1000	253.000	259.000	25.3 %
02/05/2026	14:11	M	1000	571.000	574.100	57.1 %

**Summary Statistics:**

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	253.000	258.767	Std	<b>2.3</b>
M	571.000	572.567	Std	<b>0.3</b>

# Linearity Report

04/13/2026

Page 1

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY
EDR Site ID:	CT005	Component ID:	5NO
		Component Type:	NOXA
Instrument Name:	CT5_NOXDualRg_P_Instrum	Test End Date/Time:	02/04/2026
Performance Spec:	5 %	Test No.:	5
		Status (Pass/Fail):	<b>Passed</b>
		ReasonForTest:	QA
		Grace Period:	0
		Scale:	High
		Highest Error:	1.2

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
02/04/2026	1222	L	500.0	121.2	122.4		24.2 %
02/04/2026	1227	M	500.0	276.6	279.9		55.3 %
02/04/2026	1232	H	500.0	452.1	452.2		90.4 %
02/04/2026	1239	L	500.0	121.2	118.5		24.2 %
02/04/2026	1244	M	500.0	276.6	278.4		55.3 %
02/04/2026	1249	H	500.0	452.1	452.5		90.4 %
02/04/2026	1256	L	500.0	121.2	118.3		24.2 %
02/04/2026	1301	M	500.0	276.6	278.1		55.3 %
02/04/2026	1306	H	500.0	452.1	452.7		90.4 %

**Summary Statistics:**

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	121.200	119.733	No	<b>1.2</b>
M	276.600	278.800	No	<b>0.8</b>
H	452.100	452.467	No	<b>0.1</b>

# Linearity Report

04/13/2026

Page 2

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY
EDR Site ID:	CT005	Component ID:	502
		Component Type:	O2D
		ReasonForTest:	QA
		Grace Period:	0
Instrument Name:	CT5_O2D_P_Instrument	Test End Date/Time:	02/04/2026
Performance Spec:	5 %	Test No.:	6
		Scale:	High
		Highest Error:	1.1
		Status (Pass/Fail):	<b>Passed</b>

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
02/04/2026	1037	L	25.0	6.3	6.2		25.2 %
02/04/2026	1042	M	25.0	13.8	13.8		55.2 %
02/04/2026	1047	H	25.0	22.5	22.5		90.0 %
02/04/2026	1054	L	25.0	6.3	6.3		25.2 %
02/04/2026	1059	M	25.0	13.8	13.8		55.2 %
02/04/2026	1104	H	25.0	22.5	22.5		90.0 %
02/04/2026	1111	L	25.0	6.3	6.2		25.2 %
02/04/2026	1116	M	25.0	13.8	13.8		55.2 %
02/04/2026	1121	H	25.0	22.5	22.5		90.0 %

**Summary Statistics:**

Cal Gas Level	Reference	Mean	CEMS Mean	Alt Perf Spec	Results
L	6.300	6.233	6.233	No	<b>1.1</b>
M	13.800	13.800	13.800	No	<b>0.0</b>
H	22.500	22.500	22.500	No	<b>0.0</b>

# Linearity Report

04/13/2026

Page 1

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY
EDR Site ID:	CT006	Component ID:	602
		Component Type:	O2D
		ReasonForTest:	QA
		Grace Period:	0
Instrument Name:	CT6_O2D_P_Instrument	Test End Date/Time:	02/05/2026
Performance Spec:	5 %	Test No.:	11
		Scale:	High
		Highest Error:	0.0
		Status (Pass/Fail):	<b>Passed</b>

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
02/05/2026	1052	L	25.0	6.3	6.3		25.2 %
02/05/2026	1057	M	25.0	13.8	13.8		55.2 %
02/05/2026	1102	H	25.0	22.5	22.5		90.0 %
02/05/2026	1109	L	25.0	6.3	6.3		25.2 %
02/05/2026	1114	M	25.0	13.8	13.8		55.2 %
02/05/2026	1119	H	25.0	22.5	22.5		90.0 %
02/05/2026	1126	L	25.0	6.3	6.3		25.2 %
02/05/2026	1131	M	25.0	13.8	13.8		55.2 %
02/05/2026	1136	H	25.0	22.5	22.5		90.0 %

**Summary Statistics:**

Cal Gas Level	Reference	Mean	CEMS Mean	Alt Perf Spec	Results
L	6.300	6.300	6.300	No	<b>0.0</b>
M	13.800	13.800	13.800	No	<b>0.0</b>
H	22.500	22.500	22.500	No	<b>0.0</b>

# Linearity Report

04/13/2026

Page 2

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY
EDR Site ID:	CT006	Component ID:	6NO
		Component Type:	NOXA
Instrument Name:	CT6_NOXDualRg_P_Instrum	Test End Date/Time:	02/05/2026
Performance Spec:	5 %	Test No.:	12
		Status (Pass/Fail):	<b>Passed</b>
		ReasonForTest:	QA
		Grace Period:	0
		Scale:	High
		Highest Error:	0.8

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
02/05/2026	1223	L	500.0	126.1	126.8		25.2 %
02/05/2026	1228	M	500.0	278.2	277.7		55.6 %
02/05/2026	1233	H	500.0	439.3	439.5		87.9 %
02/05/2026	1240	L	500.0	126.1	125.1		25.2 %
02/05/2026	1245	M	500.0	278.2	275.3		55.6 %
02/05/2026	1250	H	500.0	439.3	440.5		87.9 %
02/05/2026	1257	L	500.0	126.1	124.9		25.2 %
02/05/2026	1302	M	500.0	278.2	274.6		55.6 %
02/05/2026	1307	H	500.0	439.3	440.7		87.9 %

**Summary Statistics:**

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	126.100	125.600	No	<b>0.4</b>
M	278.200	275.867	No	<b>0.8</b>
H	439.300	440.233	No	<b>0.2</b>