

DOCKETED

Docket Number:	85-AFC-03C
Project Title:	Compliance - Application for Certification for Midway-Sunset Cogeneration Project
TN #:	269995
Document Title:	MSCC 85-AFC-03C 1st Quarter 2025 AQR
Description:	1st Quarter 2025 AQR 2 of 3
Filer:	Stephanie Urias
Organization:	Midway Sunset Cogeneration Company
Submitter Role:	Applicant
Submission Date:	5/15/2026 10:04:23 AM
Docketed Date:	5/15/2026

UNIT A CEM REPORT

Average Data

Plant: Midway Sunset

Interval: 1 Hour

Type: Roll

Report Period: 01/01/2025 00:00 Through 03/31/2025 23:59

Time Online Criteria: 1 minute(s)

Source Parameter Unit		UNIT_A										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/01/25	00:00	0.0 FI	0.001 FIU	-44.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FI	0.001 FI	-0.5 FI	21.0 F	199.8 F
01/01/25	01:00	0.0 FI	0.001 FIU	-51.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FI	0.001 FI	-0.5 FI	20.9 F	199.8 F
01/01/25	02:00	0.0 FI	0.001 FIU	-45.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FI	0.001 FI	-0.6 FI	21.0 F	199.8 F
01/01/25	03:00	0.0 FI	0.001 FIU	-44.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FI	0.001 FI	-0.3 FI	21.0 F	199.8 F
01/01/25	04:00	0.0 FI	0.001 FIU	-43.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FI	0.001 FI	-0.6 FI	21.0 F	199.8 F
01/01/25	05:00	0.0 FI	0.001 FIU	-41.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FI	0.001 FI	-0.9 FI	21.0 F	199.8 F
01/01/25	06:00	0.0 FI	0.001 FIU	-48.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FI	0.001 FI	-0.9 FI	21.0 F	199.8 F
01/01/25	07:00	0.0 FIC	0.015 FIU	6.6 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	8.2 F	14.2 FC	199.8 F
01/01/25	08:00	0.0 FI	0.001 FIU	-40.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FI	0.001 FI	-1.0 FI	21.0 F	199.8 F
01/01/25	09:00	0.0 FI	0.001 FIU	-35.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FI	0.001 FI	-0.5 FI	21.0 F	199.8 F
01/01/25	10:00	0.0 FI	0.001 FIU	-37.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FI	0.001 FI	-0.3 FI	21.0 F	199.7 F
01/01/25	11:00	0.0 FI	0.001 FIU	-37.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FI	0.001 FI	-0.6 FI	21.0 F	199.7 F
01/01/25	12:00	0.0 FI	0.001 FIU	-41.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FI	0.001 FI	-0.5 FI	21.0 F	199.7 F
01/01/25	13:00	0.0 FI	0.001 FIU	-37.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FI	0.001 FI	-0.8 FI	21.0 F	199.7 F
01/01/25	14:00	0.0 FI	0.001 FIU	-41.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FI	0.001 FI	-0.7 FI	21.0 F	199.7 F
01/01/25	15:00	0.0 FI	0.001 FIU	-40.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FI	0.001 FI	-0.6 FI	21.0 F	199.7 F
01/01/25	16:00	0.0 FI	0.001 FIU	-37.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FI	0.001 FI	-0.4 FI	21.0 F	199.7 F
01/01/25	17:00	0.0 FI	0.001 FIU	-41.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FI	0.001 FI	-1.0 FI	21.0 F	199.7 F
01/01/25	18:00	0.0 FI	0.001 FIU	-40.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FI	0.001 FI	-0.9 FI	21.0 F	199.7 F
01/01/25	19:00	0.0 FI	0.001 FIU	-39.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FI	0.001 FI	-1.1 FI	21.0 F	199.7 F
01/01/25	20:00	0.0 FI	0.001 FIU	-36.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FI	0.001 FI	-0.6 FI	21.0 F	199.7 F
01/01/25	21:00	48.7 U	0.097 E	43.5 E	0.0	0.0	0.0	64.4 EU	0.111 E	30.3 E	16.2	199.8
01/01/25	22:00	20.1 U	0.024	10.8	0.0	0.0	0.0	13.1 U	0.016	4.3	15.0	199.7
01/01/25	23:00	19.0 D	0.022	9.9	0.0	0.0	0.0	13.5 D	0.016	4.3	14.7	199.7
01/02/25	00:00	69.1 ED	0.253 E	111.9 E	0.0	0.0	0.0	30.5 ED	0.079 E	21.1 E	16.5	199.7
01/02/25	01:00	0.0 FID	0.001 FI	-41.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	21.0 F	199.7 F
01/02/25	02:00	0.0 FID	0.001 FI	-40.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.8 F
01/02/25	03:00	0.0 FID	0.001 FI	-40.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.8 F
01/02/25	04:00	0.0 FID	0.001 FI	-37.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.8 F
01/02/25	05:00	0.0 FID	0.001 FI	-40.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.7 F
01/02/25	06:00	0.0 FID	0.001 FI	-39.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.8 F

UNIT SHUTDOWN
CONTINUED



UNIT START UP

UNIT SHUTDOWN



Source		UNIT_A										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/02/25	07:00	0.0 FIC	0.015 FI	6.6 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.3 FC	199.8 F
01/02/25	08:00	0.0 FID	0.001 FI	-18.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
01/02/25	09:00	0.0 FID	0.001 FI	-18.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
01/02/25	10:00	0.0 FID	0.001 FI	-18.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
01/02/25	11:00	0.0 FID	0.001 FI	-18.4 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
01/02/25	12:00	0.0 FID	0.001 FI	-18.5 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.2 FI	21.0 F	199.7 F
01/02/25	13:00	0.0 FID	0.001 FI	-17.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
01/02/25	14:00	0.0 FID	0.001 FI	-18.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
01/02/25	15:00	0.0 FID	0.001 FI	-17.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
01/02/25	16:00	0.0 FID	0.001 FI	-17.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
01/02/25	17:00	0.0 FID	0.001 FI	-18.6 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	-0.3 FI	21.0 F	199.7 F
01/02/25	18:00	0.0 FID	0.001 FI	-18.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.6 FI	21.0 F	199.7 F
01/02/25	19:00	0.0 FID	0.001 FI	-17.5 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.2 FI	21.1 F	199.7 F
01/02/25	20:00	0.0 FID	0.001 FI	-18.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
01/02/25	21:00	0.0 FID	0.001 FI	-18.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
01/02/25	22:00	0.0 FID	0.001 FI	-18.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.4 FI	21.0 F	199.7 F
01/02/25	23:00	0.0 FID	0.001 FI	-18.1 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
01/03/25	00:00	0.0 FID	0.001 FI	-16.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
01/03/25	01:00	0.0 FID	0.001 FI	-18.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
01/03/25	02:00	0.0 FID	0.001 FI	-16.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.1 F	199.7 F
01/03/25	03:00	0.0 FID	0.001 FI	-16.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
01/03/25	04:00	0.0 FID	0.001 FI	-18.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
01/03/25	05:00	0.0 FID	0.001 FI	-16.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
01/03/25	06:00	0.0 FID	0.001 FI	-17.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
01/03/25	07:00	0.0 FIC	0.015 FI	6.6 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.3 FC	199.7 F
01/03/25	08:00	0.0 FID	0.001 FI	-43.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.7 F
01/03/25	09:00	0.0 FID	0.001 FI	-38.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.7 F
01/03/25	10:00	0.0 FID	0.001 FI	-39.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.7 F
01/03/25	11:00	0.0 FID	0.001 FI	-41.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.7 F
01/03/25	12:00	0.0 FID	0.001 FI	-42.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.7 F
01/03/25	13:00	0.0 FID	0.001 FI	-38.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.7 F
01/03/25	14:00	0.0 FID	0.001 FI	-37.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.7 F
01/03/25	15:00	0.0 FID	0.001 FI	-39.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.7 F
01/03/25	16:00	0.0 FID	0.001 FI	-41.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.6 FI	21.0 F	199.7 F
01/03/25	17:00	0.0 FID	0.001 FI	-37.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.7 F
01/03/25	18:00	0.0 FID	0.001 FI	-40.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.7 F
01/03/25	19:00	0.0 FID	0.001 FI	-40.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.7 F

Source		UNIT_A										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/03/25	20:00	0.0 FID	0.001 FI	-38.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.7 F
01/03/25	21:00	0.0 FID	0.001 FI	-40.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.7 F
01/03/25	22:00	0.0 FID	0.001 FI	-41.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.4 FI	21.0 F	199.7 F
01/03/25	23:00	0.0 FID	0.001 FI	-348.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-10.5 FI	20.9 F	199.7 F
01/04/25	00:00	0.0 FID	0.001 FI	-37.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.5 FI	21.0 F	199.7 F
01/04/25	01:00	0.0 FID	0.001 FI	-41.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.5 FI	21.0 F	199.8 F
01/04/25	02:00	0.0 FID	0.001 FI	-36.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.7 F
01/04/25	03:00	0.0 FID	0.001 FI	-36.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.6 FI	21.0 F	199.7 F
01/04/25	04:00	0.0 FID	0.001 FI	-37.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.8 FI	21.0 F	199.8 F
01/04/25	05:00	0.0 FID	0.001 FI	-33.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.7 FI	21.0 F	199.8 F
01/04/25	06:00	0.0 FID	0.001 FI	-40.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.8 FI	21.0 F	199.7 F
01/04/25	07:00	0.0 FIC	0.015 FI	6.6 FI	0.0 F	0.0 F	0.0 FIC	0.1 FIC	0.023 F	6.3 F	14.3 FC	199.7 F
01/04/25	08:00	0.0 FID	0.001 FI	-23.5 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
01/04/25	09:00	0.0 FID	0.001 FI	-28.0 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	-0.2 FI	21.0 F	199.8 F
01/04/25	10:00	0.0 FID	0.001 FI	-24.8 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	-0.2 FI	21.0 F	199.8 F
01/04/25	11:00	0.0 FID	0.001 FI	-22.3 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
01/04/25	12:00	0.0 FID	0.001 FI	-25.6 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
01/04/25	13:00	0.0 FID	0.001 FI	-23.8 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
01/04/25	14:00	0.0 FID	0.001 FI	-23.6 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
01/04/25	15:00	0.0 FID	0.001 FI	-27.7 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
01/04/25	16:00	0.0 FID	0.001 FI	-23.3 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
01/04/25	17:00	0.0 FID	0.001 FI	-23.6 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	-0.2 FI	21.0 F	199.7 F
01/04/25	18:00	0.0 FID	0.001 FI	-26.6 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
01/04/25	19:00	0.0 FID	0.001 FI	-22.4 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
01/04/25	20:00	0.0 FID	0.001 FI	-25.0 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
01/04/25	21:00	0.0 FID	0.001 FI	-26.1 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
01/04/25	22:00	39.9 UD	0.116 E	52.2 E	0.0	0.0	0.0	50.4 EUD	0.078 E	21.3 E	16.2	199.8
01/04/25	23:00	45.9 UD	0.080 E	35.9 E	0.0	0.0	0.0	46.7 EUD	0.069 E	18.9 E	15.8	199.8
01/05/25	00:00	40.5 UD	0.108 E	48.0 E	0.0	0.0	0.0	20.3 EUD	0.041 E	11.0 E	15.7	199.7
01/05/25	01:00	0.0 FIU	0.001 FI	-30.1 FI	0.0 F	0.0 F	0.0 FI	0.3 FIU	0.001 FI	0.0 FI	21.0 F	199.7 F
01/05/25	02:00	0.0 FIU	0.001 FID	-28.4 FI	0.0 F	0.0 F	0.0 FI	0.3 FIU	0.001 FI	0.0 FI	21.0 F	199.7 F
01/05/25	03:00	0.0 FIU	0.001 FI	-25.2 FI	0.0 F	0.0 F	0.0 FI	0.3 FIU	0.001 FI	0.0 FI	21.0 F	199.7 F
01/05/25	04:00	0.0 FIU	0.001 FI	-25.1 FI	0.0 F	0.0 F	0.0 FI	0.3 FIU	0.001 FI	0.0 FI	21.0 F	199.7 F
01/05/25	05:00	0.0 FIU	0.001 FI	-24.9 FI	0.0 F	0.0 F	0.0 FI	0.3 FIU	0.001 FI	0.0 FI	21.0 F	199.7 F
01/05/25	06:00	0.0 FIU	0.001 FI	-24.3 FI	0.0 F	0.0 F	0.0 FI	0.3 FIU	0.001 FI	0.0 FI	21.0 F	199.7 F
01/05/25	07:00	0.0 FIC	0.015 FI	6.6 FI	0.0 F	0.0 F	0.0 FIC	0.1 FIC	0.023 F	6.2 F	14.3 FC	199.8 F
01/05/25	08:00	0.0 FIU	0.001 FI	-24.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-0.4 FI	21.0 F	199.7 F

UNIT START UP
UNIT SHUTDOWN\UNIT START UP
UNIT SHUTDOWN

Source		UNIT_A										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/05/25	09:00	0.0 FIU	0.001 FI	-23.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FIU	0.001 FI	-0.5 FI	21.0 F	199.7 F
01/05/25	10:00	0.0 FIU	0.001 FI	-22.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-0.4 FI	21.0 F	199.7 F
01/05/25	11:00	0.0 FIU	0.001 FI	-24.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-0.4 FI	21.0 F	199.7 F
01/05/25	12:00	0.0 FIU	0.001 FI	-22.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-0.4 FI	21.0 F	199.7 F
01/05/25	13:00	0.0 FIU	0.001 FI	-23.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-0.4 FI	21.0 F	199.7 F
01/05/25	14:00	0.0 FIU	0.001 FI	-24.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-0.3 FI	21.0 F	199.7 F
01/05/25	15:00	0.0 FIU	0.001 FI	-22.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-0.2 FI	21.0 F	199.7 F
01/05/25	16:00	0.0 FIU	0.001 FI	-23.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-0.4 FI	21.0 F	199.7 F
01/05/25	17:00	0.0 FIU	0.001 FI	-23.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-0.1 FI	21.0 F	199.8 F
01/05/25	18:00	0.0 FIU	0.001 FI	-23.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-0.3 FI	21.0 F	199.7 F
01/05/25	19:00	0.0 FIU	0.001 FI	-24.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-0.3 FI	21.0 F	199.7 F
01/05/25	20:00	0.0 FIU	0.001 FI	-47.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-0.7 FI	21.0 F	199.8 F
01/05/25	21:00	72.8 EU	0.201 E	90.5 E	0.0	0.0	0.0	76.3 EU	0.122 E	33.4 E	16.8	199.8
01/05/25	22:00	14.7 U	0.017	7.6	0.0	0.0	0.0	14.0 U	0.016	4.3	14.9	199.7
01/05/25	23:00	23.7 D	0.029	12.7	0.0	0.0	0.0	13.0 D	0.016	4.2	14.8	199.7
01/06/25	00:00	88.8 ED	0.257 E	113.9 E	0.0	0.0	0.0	30.8 ED	0.080 E	21.7 E	16.6	199.7
01/06/25	01:00	0.0 FID	0.001 FI	-25.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.7 F
01/06/25	02:00	0.0 FID	0.001 FI	-24.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.7 F
01/06/25	03:00	0.0 FID	0.001 FI	-22.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.8 F
01/06/25	04:00	0.0 FID	0.001 FI	-24.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.8 F
01/06/25	05:00	0.0 FID	0.001 FI	-22.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.8 F
01/06/25	06:00	0.0 FID	0.001 FI	-22.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.8 F
01/06/25	07:00	0.0 FIC	0.015 FI	6.6 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.3 FC	199.8 F
01/06/25	08:00	0.0 FID	0.001 FI	-36.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.0 FI	21.0 F	199.7 F
01/06/25	09:00	0.0 FID	0.001 FI	-39.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.6 FI	21.0 F	199.7 F
01/06/25	10:00	0.0 FID	0.001 FI	-48.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.2 FI	21.0 F	199.7 F
01/06/25	11:00	0.0 FID	0.001 FI	-40.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.3 FI	21.0 F	199.7 F
01/06/25	12:00	0.0 FID	0.001 FI	-44.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.6 FI	21.0 F	199.7 F
01/06/25	13:00	0.0 FID	0.001 FI	-47.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.9 FI	21.0 F	199.7 F
01/06/25	14:00	0.0 FID	0.001 FI	-43.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.5 FI	21.0 F	199.7 F
01/06/25	15:00	0.0 FID	0.001 FI	-41.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.3 FI	21.0 F	199.7 F
01/06/25	16:00	0.0 FID	0.001 FI	-42.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.1 FI	21.0 F	199.7 F
01/06/25	17:00	0.0 FID	0.001 FI	-37.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	21.0 F	199.7 F
01/06/25	18:00	0.0 FID	0.001 FI	-44.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.1 FI	21.0 F	199.7 F
01/06/25	19:00	0.0 FID	0.001 FI	-46.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.8 FI	21.0 F	199.7 F
01/06/25	20:00	0.0 FID	0.001 FI	-39.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	21.0 F	199.7 F
01/06/25	21:00	0.0 FID	0.001 FI	-42.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.4 FI	21.0 F	199.7 F

UNIT START UP

UNIT SHUTDOWN

Source Parameter Unit	UNIT_A										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/06/25 22:00	0.0 FID	0.001 FI	-45.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.9 FI	21.0 F	199.7 F
01/06/25 23:00	0.0 FID	0.001 FI	-39.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.2 FI	21.0 F	199.7 F
01/07/25 00:00	0.0 FID	0.001 FI	-46.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.6 FI	21.0 F	199.7 F
01/07/25 01:00	0.0 FID	0.001 FI	-44.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.0 FI	21.0 F	199.8 F
01/07/25 02:00	0.0 FID	0.001 FI	-43.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.2 FI	21.0 F	199.7 F
01/07/25 03:00	0.0 FID	0.001 FI	-49.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.6 FI	21.0 F	199.8 F
01/07/25 04:00	0.0 FID	0.001 FI	-43.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.6 FI	21.0 F	199.8 F
01/07/25 05:00	0.0 FID	0.001 FI	-44.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.7 FI	21.0 F	199.8 F
01/07/25 06:00	0.0 FID	0.001 FI	-45.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.2 FI	21.0 F	199.7 F
01/07/25 07:00	0.0 FIC	0.015 FI	6.6 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.7 F
01/07/25 08:00	0.0 FID	0.001 FI	-77.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.9 FI	20.9 F	199.8 F
01/07/25 09:00	0.0 FID	0.001 FI	-77.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.2 FI	20.9 F	199.8 F
01/07/25 10:00	0.0 FID	0.001 FI	-66.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.5 FI	20.9 F	199.7 F
01/07/25 11:00	0.0 FID	0.001 FI	-67.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.6 FI	20.9 F	199.7 F
01/07/25 12:00	0.0 FID	0.001 FI	-72.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.4 FI	20.9 F	199.8 F
01/07/25 13:00	0.0 FID	0.001 FI	-61.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.0 FI	20.9 F	199.7 F
01/07/25 14:00	0.0 FID	0.001 FI	-55.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.2 FI	20.9 F	199.8 F
01/07/25 15:00	0.0 FID	0.001 FI	-63.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	20.9 F	199.7 F
01/07/25 16:00	0.0 FID	0.001 FI	-67.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.2 FI	20.9 F	199.7 F
01/07/25 17:00	0.0 FID	0.001 FI	-67.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-2.9 FI	20.9 F	199.7 F
01/07/25 18:00	0.0 FID	0.001 FI	-64.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.8 FI	20.9 F	199.7 F
01/07/25 19:00	0.0 FID	0.001 FI	-62.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.9 FI	20.9 F	199.8 F
01/07/25 20:00	0.0 FID	0.001 FI	-75.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.3 FI	20.9 F	199.7 F
01/07/25 21:00	0.0 FID	0.001 FI	-69.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	20.9 F	199.8 F
01/07/25 22:00	0.0 FID	0.001 FI	-53.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.6 FI	20.9 F	199.8 F
01/07/25 23:00	0.0 FID	0.001 FI	93.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.5 FI	20.9 F	199.8 F
01/08/25 00:00	0.0 FID	0.001 FI	-50.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	20.9 F	199.8 F
01/08/25 01:00	0.0 FID	0.001 FI	-57.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	20.9 F	199.8 F
01/08/25 02:00	0.0 FID	0.001 FI	-61.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	20.9 F	199.8 F
01/08/25 03:00	0.0 FID	0.001 FI	-57.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.0 FI	20.9 F	199.8 F
01/08/25 04:00	0.0 FID	0.001 FI	-62.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.4 FI	20.9 F	199.7 F
01/08/25 05:00	0.0 FID	0.001 FI	-59.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.1 FI	20.9 F	199.8 F
01/08/25 06:00	0.0 FID	0.001 FI	-56.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	20.9 F	199.7 F
01/08/25 07:00	0.0 FIC	0.015 FI	6.5 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.2 FC	199.8 F
01/08/25 08:00	0.0 FID	0.001 FI	1,682.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	242.3 FIE	20.9 F	199.8 F
01/08/25 09:00	0.0 FID	0.001 FI	1,441.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	201.0 FIE	20.9 F	199.8 F
01/08/25 10:00	0.0 FID	0.001 FI	397.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	58.9 FIE	20.9 F	199.8 F

Source		UNIT_A										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/08/25	11:00	0.0 FID	0.001 FI	541.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	73.9 FIE	20.9 F	199.8 F
01/08/25	12:00	0.0 FID	0.001 FI	-5,658.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-791.6 FI	20.9 F	199.8 F
01/08/25	13:00	0.0 FID	0.001 FI	452.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	66.7 FIE	20.9 F	199.7 F
01/08/25	14:00	0.0 FID	0.001 FI	1,053.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	127.0 FIE	20.9 F	199.7 F
01/08/25	15:00	0.0 FID	0.001 FI	37,758.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4,940.0 FIE	20.9 F	199.7 F
01/08/25	16:00	0.0 FID	0.001 FI	930.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	131.0 FIE	20.9 F	199.7 F
01/08/25	17:00	0.0 FID	0.001 FI	576.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	77.4 FIE	20.9 F	199.8 F
01/08/25	18:00	0.0 FID	0.001 FI	1,258.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	174.5 FIE	20.9 F	199.8 F
01/08/25	19:00	0.0 FID	0.001 FI	392.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	59.0 FIE	20.9 F	199.8 F
01/08/25	20:00	0.0 FID	0.001 FI	1,153.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	171.6 FIE	20.9 F	199.8 F
01/08/25	21:00	0.0 FID	0.001 FI	541.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	84.5 FIE	20.9 F	199.8 F
01/08/25	22:00	0.0 FID	0.001 FI	1,246.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	197.1 FIE	20.9 F	199.8 F
01/08/25	23:00	0.0 FID	0.001 FI	-589.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-85.7 FI	20.9 F	199.8 F
01/09/25	00:00	0.0 FID	0.001 FI	-838.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-124.6 FI	20.9 F	199.8 F
01/09/25	01:00	0.0 FID	0.001 FI	580.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	91.1 FIE	20.9 F	199.8 F
01/09/25	02:00	0.0 FID	0.001 FI	-1,101.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-144.7 FI	20.9 F	199.8 F
01/09/25	03:00	0.0 FID	0.001 FI	-639.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-95.4 FI	20.9 F	199.8 F
01/09/25	04:00	0.0 FID	0.001 FI	-138.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-18.8 FI	20.9 F	199.8 F
01/09/25	05:00	0.0 FID	0.001 FI	-46.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-6.0 FI	21.0 F	199.8 F
01/09/25	06:00	0.0 FID	0.001 FI	-42.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-5.5 FI	21.0 F	199.8 F
01/09/25	07:00	0.0 FIC	0.015 FI	6.5 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.1 F	14.2 FC	199.8 F
01/09/25	08:00	0.0 FID	0.026 FI	18.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.9 FI	20.8 F	199.8 F
01/09/25	09:00	0.0 FID	0.026 FI	10.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.6 FI	20.8 F	199.7 F
01/09/25	10:00	0.0 FID	0.013 FI	9.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.2 FI	20.8 F	199.7 F
01/09/25	11:00	0.0 FID	0.026 FI	11.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.8 FI	20.8 F	199.7 F
01/09/25	12:00	0.0 FID	0.026 FI	10.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.7 FI	20.8 F	199.7 F
01/09/25	13:00	0.0 FID	0.026 FI	10.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.1 FI	20.8 F	199.7 F
01/09/25	14:00	0.0 FID	0.026 FI	10.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.6 FI	20.8 F	199.7 F
01/09/25	15:00	0.0 FID	0.013 FI	9.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.4 FI	20.8 F	199.7 F
01/09/25	16:00	0.0 FID	0.026 FI	10.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.4 FI	20.8 F	199.7 F
01/09/25	17:00	0.0 FID	0.013 FI	10.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.7 FI	20.8 F	199.7 F
01/09/25	18:00	0.0 FID	0.013 FI	9.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.6 FI	20.8 F	199.7 F
01/09/25	19:00	0.0 FID	0.013 FI	9.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.4 FI	20.8 F	199.7 F
01/09/25	20:00	0.0 FID	0.013 FI	9.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.7 FI	20.8 F	199.7 F
01/09/25	21:00	0.0 FID	0.026 FI	9.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.5 FI	20.8 F	199.7 F
01/09/25	22:00	0.0 FID	0.026 FI	11.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.5 FI	20.8 F	199.7 F
01/09/25	23:00	0.0 FID	0.013 FI	9.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.8 FI	20.8 F	199.7 F

Source		UNIT_A										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/10/25	00:00	0.0 FID	0.013 FI	10.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.5 FI	20.8 F	199.7 F
01/10/25	01:00	0.0 FID	0.001 FI	27.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.7 FIE	20.9 F	199.8 F
01/10/25	02:00	0.0 FID	0.001 FI	24.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.8 FIE	20.9 F	199.8 F
01/10/25	03:00	0.0 FID	0.001 FI	28.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	6.9 FIE	20.9 F	199.8 F
01/10/25	04:00	0.0 FID	0.001 FI	43.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	8.4 FIE	20.9 F	199.8 F
01/10/25	05:00	0.0 FID	0.001 FI	39.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	8.9 FIE	20.9 F	199.8 F
01/10/25	06:00	0.0 FID	0.001 FI	49.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	9.6 FIE	20.9 F	199.8 F
01/10/25	07:00	0.0 FIC	0.015 FI	6.5 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.2 FC	199.8 F
01/10/25	08:00	0.0 FID	0.001 FI	139.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.3 FI	20.9 F	199.8 F
01/10/25	09:00	0.0 FID	0.001 FI	50.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.9 F	199.7 F
01/10/25	10:00	0.0 FID	0.001 FI	42.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.9 F	199.7 F
01/10/25	11:00	0.0 FID	0.053 FI	32.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.0 FI	20.8 F	199.7 F
01/10/25	12:00	0.0 FID	0.053 FI	31.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.8 F	199.7 F
01/10/25	13:00	0.0 FID	0.053 FI	35.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.8 F	199.7 F
01/10/25	14:00	0.0 FID	0.053 FI	35.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.8 F	199.7 F
01/10/25	15:00	0.0 FID	0.001 FI	63.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.1 FI	20.9 F	199.7 F
01/10/25	16:00	0.0 FID	0.001 FI	93.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.6 FI	20.9 F	199.7 F
01/10/25	17:00	0.0 FID	0.001 FI	-1,228.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-21.9 FI	20.9 F	199.8 F
01/10/25	18:00	0.0 FID	0.001 FI	-252.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	20.9 F	199.7 F
01/10/25	19:00	0.0 FID	0.001 FI	-202.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	20.9 F	199.7 F
01/10/25	20:00	0.0 FID	0.001 FI	-109.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	20.9 F	199.8 F
01/10/25	21:00	0.0 FID	0.001 FI	-109.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	20.9 F	199.8 F
01/10/25	22:00	0.0 FID	0.001 FI	-108.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	20.9 F	199.8 F
01/10/25	23:00	0.0 FID	0.001 FI	-127.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.7 FI	20.9 F	199.8 F
01/11/25	00:00	0.0 FID	0.001 FI	-137.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	20.9 F	199.7 F
01/11/25	01:00	0.0 FID	0.001 FI	-102.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	20.9 F	199.8 F
01/11/25	02:00	0.0 FID	0.001 FI	-249.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.4 FI	20.9 F	199.8 F
01/11/25	03:00	0.0 FID	0.001 FI	-125.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	20.9 F	199.8 F
01/11/25	04:00	0.0 FID	0.001 FI	-155.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.8 FI	20.9 F	199.8 F
01/11/25	05:00	0.0 FID	0.001 FI	241.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.6 FI	20.9 F	199.8 F
01/11/25	06:00	0.0 FID	0.001 FI	78.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.9 F	199.7 F
01/11/25	07:00	0.0 FIC	0.015 FI	6.5 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.2 FC	199.7 F
01/11/25	08:00	0.0 FID	0.053 FI	41.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.8 F	199.7 F
01/11/25	09:00	0.0 FID	0.053 FI	33.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.8 F	199.7 F
01/11/25	10:00	0.0 FID	0.053 FI	32.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.8 F	199.7 F
01/11/25	11:00	0.0 FID	0.053 FI	31.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.8 F	199.7 F
01/11/25	12:00	0.0 FID	0.053 FI	30.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.8 F	199.7 F

Source		UNIT_A										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/11/25	13:00	0.0 FID	0.053 FI	31.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.8 F	199.7 F
01/11/25	14:00	0.0 FID	0.053 FI	29.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.8 F	199.7 F
01/11/25	15:00	0.0 FID	0.053 FI	28.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.8 F	199.7 F
01/11/25	16:00	0.0 FID	0.053 FI	31.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.8 F	199.7 F
01/11/25	17:00	0.0 FID	0.001 FI	48.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.9 F	199.7 F
01/11/25	18:00	0.0 FID	0.001 FI	74.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.9 F	199.7 F
01/11/25	19:00	0.0 FID	0.001 FI	105.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.6 FI	20.9 F	199.7 F
01/11/25	20:00	0.0 FID	0.001 FI	119.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.9 F	199.7 F
01/11/25	21:00	0.0 FID	0.001 FI	114.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.9 F	199.7 F
01/11/25	22:00	0.0 FID	0.001 FI	107.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.1 FI	20.9 F	199.7 F
01/11/25	23:00	0.0 FID	0.053 FI	28.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.7 F
01/12/25	00:00	0.0 FID	0.001 FI	107.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.5 FI	20.9 F	199.7 F
01/12/25	01:00	0.0 FID	0.001 FI	111.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.9 F	199.7 F
01/12/25	02:00	0.0 FID	0.001 FI	264.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.3 FI	20.9 F	199.7 F
01/12/25	03:00	0.0 FID	0.001 FI	199.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.9 FI	20.9 F	199.7 F
01/12/25	04:00	0.0 FID	0.001 FI	125.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.9 F	199.7 F
01/12/25	05:00	0.0 FID	0.001 FI	1,686.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	8.7 FIE	20.9 F	199.8 F
01/12/25	06:00	0.0 FID	0.001 FI	-31,323.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-249.3 FI	20.9 F	199.8 F
01/12/25	07:00	0.0 FIC	0.015 FI	6.5 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.2 FC	199.7 F
01/12/25	08:00	0.0 FID	0.001 FI	-50.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	20.9 F	199.7 F
01/12/25	09:00	0.0 FID	0.001 FI	-47.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	20.9 F	199.7 F
01/12/25	10:00	0.0 FID	0.001 FI	-50.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	20.9 F	199.7 F
01/12/25	11:00	0.0 FID	0.001 FI	-59.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	20.9 F	199.7 F
01/12/25	12:00	0.0 FID	0.001 FI	-63.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	20.9 F	199.7 F
01/12/25	13:00	0.0 FID	0.001 FI	-82.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	20.9 F	199.7 F
01/12/25	14:00	0.0 FID	0.001 FI	-63.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	20.9 F	199.7 F
01/12/25	15:00	0.0 FID	0.001 FI	-60.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	20.9 F	199.7 F
01/12/25	16:00	0.0 FID	0.001 FI	-67.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	20.9 F	199.7 F
01/12/25	17:00	0.0 FID	0.001 FI	-57.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	20.9 F	199.7 F
01/12/25	18:00	0.0 FID	0.001 FI	-50.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	20.9 F	199.7 F
01/12/25	19:00	0.0 FID	0.001 FI	-50.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	20.9 F	199.7 F
01/12/25	20:00	0.0 FID	0.001 FI	-38.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.7 F
01/12/25	21:00	0.0 FID	0.001 FI	-38.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.7 F
01/12/25	22:00	0.0 FID	0.001 FI	-42.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.8 F
01/12/25	23:00	0.0 FID	0.001 FI	962.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	6.9 FIE	20.9 F	199.8 F
01/13/25	00:00	0.0 FID	0.001 FI	-40.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.8 F
01/13/25	01:00	0.0 FID	0.001 FI	-39.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.8 F

Source Parameter Unit	UNIT_A										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/13/25 02:00	0.0 FID	0.001 FI	-44.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.8 F
01/13/25 03:00	0.0 FID	0.001 FI	-48.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	20.9 F	199.8 F
01/13/25 04:00	0.0 FID	0.001 FI	-39.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.8 F
01/13/25 05:00	0.0 FID	0.001 FI	-41.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.8 F
01/13/25 06:00	0.0 FID	0.001 FI	-40.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.8 F
01/13/25 07:00	0.0 FIC	0.014 FI	6.5 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.8 F
01/13/25 08:00	0.0 FID	0.001 FI	-35.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.0 FI	21.0 F	199.8 F
01/13/25 09:00	0.0 FID	0.001 FI	-50.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	20.9 F	199.7 F
01/13/25 10:00	0.0 FID	0.001 FI	-49.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	20.9 F	199.7 F
01/13/25 11:00	0.0 FID	0.001 FI	-42.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.7 F
01/13/25 12:00	0.0 FID	0.001 FI	-40.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.7 F
01/13/25 13:00	0.0 FID	0.001 FI	-35.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	21.0 F	199.7 F
01/13/25 14:00	0.0 FID	0.001 FI	-38.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.7 F
01/13/25 15:00	0.0 FID	0.001 FI	-43.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	21.0 F	199.7 F
01/13/25 16:00	0.0 FID	0.001 FI	-43.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	21.0 F	199.7 F
01/13/25 17:00	0.0 FID	0.001 FI	-42.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	21.0 F	199.7 F
01/13/25 18:00	0.0 FID	0.001 FI	-38.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.7 F
01/13/25 19:00	0.0 FID	0.001 FI	-40.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	21.0 F	199.7 F
01/13/25 20:00	0.0 FID	0.001 FI	-41.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	21.0 F	199.7 F
01/13/25 21:00	0.0 FID	0.001 FI	-34.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.7 F
01/13/25 22:00	0.0 FID	0.001 FI	-38.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	21.0 F	199.7 F
01/13/25 23:00	0.0 FID	0.001 FI	-39.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.7 F
01/14/25 00:00	0.0 FID	0.001 FI	-36.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	21.0 F	199.7 F
01/14/25 01:00	0.0 FID	0.001 FI	-38.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.7 F
01/14/25 02:00	0.0 FID	0.001 FI	-42.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.7 F
01/14/25 03:00	0.0 FID	0.001 FI	-34.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.7 F
01/14/25 04:00	0.0 FID	0.001 FI	-34.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.0 FI	21.0 F	199.7 F
01/14/25 05:00	0.0 FID	0.001 FI	-36.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.8 F
01/14/25 06:00	0.0 FID	0.001 FI	-31.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.8 F
01/14/25 07:00	0.0 FIC	0.015 FI	6.6 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.2 FC	199.7 F
01/14/25 08:00	0.0 FID	0.001 FI	-126.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
01/14/25 09:00	0.0 FID	0.001 FI	-836.9 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
01/14/25 10:00	0.0 FID	0.001 FI	103.7 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.1 FI	20.9 F	199.7 F
01/14/25 11:00	0.0 FID	0.001 FI	120.3 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
01/14/25 12:00	0.0 FID	0.001 FI	169.8 FIE	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
01/14/25 13:00	0.0 FID	0.001 FI	182.4 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
01/14/25 14:00	0.0 FID	0.001 FI	621.4 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.1 FI	20.9 F	199.7 F

Source		UNIT_A										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/14/25	15:00	0.0 FID	0.001 FI	453.8 FIE	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.1 FI	20.9 F	199.7 F
01/14/25	16:00	0.0 FID	0.001 FI	-42,793.3 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
01/14/25	17:00	0.0 FID	0.001 FI	-106.3 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
01/14/25	18:00	0.0 FID	0.001 FI	-77.4 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	20.9 F	199.7 F
01/14/25	19:00	0.0 FID	0.001 FI	-100.2 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
01/14/25	20:00	0.0 FID	0.001 FI	-71.7 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
01/14/25	21:00	0.0 FID	0.001 FI	-76.0 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
01/14/25	22:00	0.0 FID	0.001 FI	-70.5 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
01/14/25	23:00	0.0 FID	0.001 FI	-70.3 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	-0.1 FI	20.9 F	199.7 F
01/15/25	00:00	0.0 FID	0.001 FI	-74.1 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
01/15/25	01:00	0.0 FID	0.001 FI	-96.1 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
01/15/25	02:00	0.0 FID	0.001 FI	-111.4 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
01/15/25	03:00	0.0 FID	0.001 FI	50.9 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
01/15/25	04:00	0.0 FID	0.001 FI	58.4 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
01/15/25	05:00	0.0 FID	0.001 FI	142.7 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.1 FI	20.9 F	199.7 F
01/15/25	06:00	0.0 FID	0.001 FI	157.7 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
01/15/25	07:00	0.0 FIC	0.015 FI	6.5 FI	0.0 F	0.0 F	0.0 FIC	0.1 FIC	0.023 F	6.1 F	14.2 FC	199.7 F
01/15/25	08:00	0.0 FID	0.066 FIE	40.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.7 F
01/15/25	09:00	0.0 FID	0.066 FIE	29.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.7 F
01/15/25	10:00	0.0 FID	0.066 FIE	29.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.7 F
01/15/25	11:00	0.0 FID	0.066 FIE	31.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.7 F
01/15/25	12:00	0.0 FID	0.066 FIE	29.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.7 F
01/15/25	13:00	0.0 FID	0.066 FIE	31.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.7 F
01/15/25	14:00	0.0 FID	0.066 FIE	30.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.7 F
01/15/25	15:00	0.0 FID	0.066 FIE	29.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.7 F
01/15/25	16:00	0.0 FID	0.066 FIE	32.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.7 F
01/15/25	17:00	0.0 FID	0.066 FIE	32.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.7 F
01/15/25	18:00	0.0 FID	0.066 FIE	29.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.7 F
01/15/25	19:00	0.0 FID	0.066 FIE	28.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.7 F
01/15/25	20:00	0.0 FID	0.066 FIE	32.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.7 F
01/15/25	21:00	0.0 FID	0.053 FI	27.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.7 F
01/15/25	22:00	0.0 FID	0.066 FIE	31.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.7 F
01/15/25	23:00	0.0 FID	0.053 FI	28.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.7 F
01/16/25	00:00	0.0 FID	0.053 FI	31.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.7 F
01/16/25	01:00	0.0 FID	0.066 FIE	32.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.7 F
01/16/25	02:00	0.0 FID	0.053 FI	29.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.7 F
01/16/25	03:00	0.0 FID	0.053 FI	38.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.7 F

Source		UNIT_A										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/16/25	04:00	0.0 FID	0.001 FI	58.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.9 F	199.7 F
01/16/25	05:00	0.0 FID	0.001 FI	72.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.9 F	199.7 F
01/16/25	06:00	0.0 FID	0.001 FI	60.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.9 F	199.7 F
01/16/25	07:00	0.0 FIC	0.015 FI	6.6 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.2 FC	199.7 F
01/16/25	08:00	0.0 FID	0.001 FI	68.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.9 FI	20.9 F	199.7 F
01/16/25	09:00	0.0 FID	0.053 FI	37.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.7 FI	20.8 F	199.7 F
01/16/25	10:00	0.0 FID	0.053 FI	37.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.8 F	199.7 F
01/16/25	11:00	0.0 FID	0.053 FI	37.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.7 FI	20.8 F	199.7 F
01/16/25	12:00	0.0 FID	0.053 FI	30.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.8 F	199.7 F
01/16/25	13:00	0.0 FID	0.053 FI	35.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.8 F	199.7 F
01/16/25	14:00	0.0 FID	0.053 FI	35.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.8 F	199.7 F
01/16/25	15:00	0.0 FID	0.053 FI	38.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.8 FI	20.8 F	199.7 F
01/16/25	16:00	0.0 FID	0.053 FI	36.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.8 F	199.7 F
01/16/25	17:00	0.0 FID	0.053 FI	33.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.9 FI	20.8 F	199.7 F
01/16/25	18:00	0.0 FID	0.053 FI	35.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.8 FI	20.8 F	199.7 F
01/16/25	19:00	0.0 FID	0.053 FI	40.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.7 FI	20.8 F	199.7 F
01/16/25	20:00	0.0 FID	0.053 FI	35.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.7 FI	20.8 F	199.7 F
01/16/25	21:00	0.0 FID	0.001 FI	57.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.6 FI	20.9 F	199.7 F
01/16/25	22:00	0.0 FID	0.001 FI	-396.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-10.5 FI	20.9 F	199.7 F
01/16/25	23:00	0.0 FID	0.001 FI	-281.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-8.7 FI	20.9 F	199.7 F
01/17/25	00:00	0.0 FID	0.001 FI	-233.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.5 FI	20.9 F	199.7 F
01/17/25	01:00	0.0 FID	0.001 FI	-307.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-8.4 FI	20.9 F	199.7 F
01/17/25	02:00	0.0 FID	0.001 FI	-257.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-10.4 FI	20.9 F	199.7 F
01/17/25	03:00	0.0 FID	0.001 FI	-113.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.0 FI	20.9 F	199.7 F
01/17/25	04:00	0.0 FID	0.001 FI	-126.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.5 FI	20.9 F	199.7 F
01/17/25	05:00	0.0 FID	0.001 FI	-178.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.5 FI	20.9 F	199.7 F
01/17/25	06:00	0.0 FID	0.001 FI	-159.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.8 FI	20.9 F	199.7 F
01/17/25	07:00	0.0 FIC	0.015 FI	6.5 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.2 FC	199.7 F
01/17/25	08:00	0.0 FIM	0.014 FI	6.4 FI	0.0 F	0.0 F	0.0 FIM	0.0 FIM	0.024 F	6.4 F	14.2 FMC	199.7 F
01/17/25	09:00	0.0 FID	0.001 FI	394.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.9 F	199.7 F
01/17/25	10:00	0.0 FID	0.001 FI	63.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.9 F	199.7 F
01/17/25	11:00	0.0 FID	0.001 FI	52.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.9 F	199.7 F
01/17/25	12:00	0.0 FID	0.001 FI	57.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.9 F	199.7 F
01/17/25	13:00	0.0 FID	0.001 FI	91.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.9 F	199.7 F
01/17/25	14:00	0.0 FID	0.001 FI	89.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.9 F	199.7 F
01/17/25	15:00	0.0 FID	0.001 FI	159.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
01/17/25	16:00	0.0 FID	0.001 FI	164.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.9 F	199.7 F

Source		UNIT_A										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/17/25	17:00	0.0 FID	0.001 FI	-911.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.7 FI	20.9 F	199.7 F
01/17/25	18:00	0.0 FID	0.001 FI	-135.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.4 FI	20.9 F	199.7 F
01/17/25	19:00	0.0 FID	0.001 FI	-159.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	20.9 F	199.7 F
01/17/25	20:00	0.0 FID	0.001 FI	-118.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	20.9 F	199.7 F
01/17/25	21:00	0.0 FID	0.001 FI	-80.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	20.9 F	199.7 F
01/17/25	22:00	0.0 FID	0.001 FI	-88.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	20.9 F	199.7 F
01/17/25	23:00	0.0 FID	0.001 FI	-106.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	20.9 F	199.7 F
01/18/25	00:00	0.0 FID	0.001 FI	-86.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	20.9 F	199.7 F
01/18/25	01:00	0.0 FID	0.001 FI	-139.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	20.9 F	199.7 F
01/18/25	02:00	0.0 FID	0.001 FI	-104.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	20.9 F	199.7 F
01/18/25	03:00	0.0 FID	0.001 FI	-97.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	20.9 F	199.7 F
01/18/25	04:00	0.0 FID	0.001 FI	-209.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	20.9 F	199.7 F
01/18/25	05:00	0.0 FID	0.001 FI	-117.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	20.9 F	199.7 F
01/18/25	06:00	0.0 FID	0.001 FI	-101.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	20.9 F	199.7 F
01/18/25	07:00	0.0 FIC	0.015 FI	6.6 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.2 FC	199.7 F
01/18/25	08:00	0.0 FID	0.001 FI	-690.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-10.1 FI	20.9 F	199.7 F
01/18/25	09:00	0.0 FID	0.001 FI	115.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.3 FI	20.9 F	199.7 F
01/18/25	10:00	0.0 FID	0.066 FIE	52.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.8 F	199.7 F
01/18/25	11:00	0.0 FID	0.066 FIE	52.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.0 FI	20.8 F	199.7 F
01/18/25	12:00	0.0 FID	0.066 FIE	53.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.5 FI	20.8 F	199.7 F
01/18/25	13:00	0.0 FID	0.066 FIE	54.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.1 FI	20.8 F	199.7 F
01/18/25	14:00	0.0 FID	0.066 FIE	49.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.0 FI	20.8 F	199.7 F
01/18/25	15:00	0.0 FID	0.066 FIE	48.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.8 F	199.7 F
01/18/25	16:00	0.0 FID	0.066 FIE	51.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.1 FI	20.8 F	199.7 F
01/18/25	17:00	0.0 FID	0.001 FI	55.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.9 F	199.7 F
01/18/25	18:00	0.0 FID	0.066 FIE	54.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.8 F	199.7 F
01/18/25	19:00	0.0 FID	0.066 FIE	49.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.8 F	199.7 F
01/18/25	20:00	0.0 FID	0.001 FI	84.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.9 F	199.7 F
01/18/25	21:00	0.0 FID	0.001 FI	216.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	6.0 FIE	20.9 F	199.7 F
01/18/25	22:00	0.0 FID	0.001 FI	345.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.2 FIE	20.9 F	199.7 F
01/18/25	23:00	0.0 FID	0.001 FI	-1,479.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-21.1 FI	20.9 F	199.7 F
01/19/25	00:00	0.0 FID	0.001 FI	-227.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.3 FI	20.9 F	199.7 F
01/19/25	01:00	0.0 FID	0.001 FI	-213.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.1 FI	20.9 F	199.7 F
01/19/25	02:00	0.0 FID	0.001 FI	-184.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.2 FI	20.9 F	199.7 F
01/19/25	03:00	0.0 FID	0.001 FI	-207.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.0 FI	20.9 F	199.7 F
01/19/25	04:00	0.0 FID	0.001 FI	-208.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.9 FI	20.9 F	199.7 F
01/19/25	05:00	0.0 FID	0.001 FI	-222.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.6 FI	20.9 F	199.7 F

Source		UNIT_A										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/19/25	06:00	0.0 FID	0.001 FI	-487.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-10.6 FI	20.9 F	199.7 F
01/19/25	07:00	0.0 FIC	0.015 FI	6.5 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.7 F
01/19/25	08:00	0.0 FID	0.001 FI	131.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	8.7 FIE	20.9 F	199.7 F
01/19/25	09:00	0.0 FID	0.053 FI	51.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.3 FI	20.8 F	199.7 F
01/19/25	10:00	0.0 FID	0.053 FI	34.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.1 FI	20.8 F	199.7 F
01/19/25	11:00	0.0 FID	0.053 FI	35.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.1 FI	20.8 F	199.7 F
01/19/25	12:00	0.0 FID	0.053 FI	33.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.1 FI	20.8 F	199.7 F
01/19/25	13:00	0.0 FID	0.053 FI	33.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.5 FI	20.8 F	199.7 F
01/19/25	14:00	0.0 FID	0.053 FI	35.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.6 FI	20.8 F	199.7 F
01/19/25	15:00	0.0 FID	0.053 FI	31.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.6 FI	20.8 F	199.7 F
01/19/25	16:00	0.0 FID	0.053 FI	35.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.6 FI	20.8 F	199.7 F
01/19/25	17:00	0.0 FID	0.053 FI	45.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.9 FI	20.8 F	199.7 F
01/19/25	18:00	0.0 FID	0.001 FI	61.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.9 FI	20.9 F	199.7 F
01/19/25	19:00	0.0 FID	0.001 FI	111.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	6.2 FIE	20.9 F	199.7 F
01/19/25	20:00	0.0 FID	0.001 FI	115.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	8.0 FIE	20.9 F	199.7 F
01/19/25	21:00	0.0 FID	0.001 FI	73.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.4 FI	20.9 F	199.7 F
01/19/25	22:00	0.0 FID	0.001 FI	129.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	8.6 FIE	20.9 F	199.7 F
01/19/25	23:00	0.0 FID	0.053 FI	29.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.1 FI	20.8 F	199.7 F
01/20/25	00:00	0.0 FID	0.001 FI	159.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	9.2 FIE	20.9 F	199.7 F
01/20/25	01:00	0.0 FID	0.001 FI	115.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	7.5 FIE	20.9 F	199.7 F
01/20/25	02:00	0.0 FID	0.001 FI	132.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	9.2 FIE	20.9 F	199.7 F
01/20/25	03:00	0.0 FID	0.001 FI	94.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.3 FIE	20.9 F	199.7 F
01/20/25	04:00	0.0 FID	0.001 FI	165.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	9.0 FIE	20.9 F	199.7 F
01/20/25	05:00	0.0 FID	0.053 FI	30.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.6 FI	20.8 F	199.7 F
01/20/25	06:00	0.0 FID	0.001 FI	169.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	9.2 FIE	20.9 F	199.7 F
01/20/25	07:00	0.0 FIC	0.015 FI	6.5 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.4 F	14.2 FC	199.7 F
01/20/25	08:00	0.0 FID	0.001 FI	-897.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-57.6 FI	20.9 F	199.7 F
01/20/25	09:00	0.0 FID	0.001 FI	201.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	9.5 FIE	20.9 F	199.7 F
01/20/25	10:00	0.0 FID	0.001 FI	112.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	6.5 FIE	20.9 F	199.7 F
01/20/25	11:00	0.0 FID	0.001 FI	110.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	6.2 FIE	20.9 F	199.7 F
01/20/25	12:00	0.0 FID	0.001 FI	107.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.6 FIE	20.9 F	199.7 F
01/20/25	13:00	0.0 FID	0.001 FI	120.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	6.7 FIE	20.9 F	199.7 F
01/20/25	14:00	0.0 FID	0.001 FI	102.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.2 FIE	20.9 F	199.7 F
01/20/25	15:00	0.0 FID	0.001 FI	122.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.9 FIE	20.9 F	199.7 F
01/20/25	16:00	0.0 FID	0.001 FI	113.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	6.6 FIE	20.9 F	199.7 F
01/20/25	17:00	0.0 FID	0.001 FI	123.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	6.4 FIE	20.9 F	199.7 F
01/20/25	18:00	0.0 FID	0.001 FI	147.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	8.7 FIE	20.9 F	199.7 F

Source		UNIT_A										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/20/25	19:00	0.0 FID	0.001 FI	170.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	10.5 FIE	20.9 F	199.7 F
01/20/25	20:00	0.0 FID	0.001 FI	-888.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-48.0 FI	20.9 F	199.7 F
01/20/25	21:00	0.0 FID	0.001 FI	-173.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-7.5 FI	20.9 F	199.7 F
01/20/25	22:00	0.0 FID	0.001 FI	-263.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-14.1 FI	20.9 F	199.7 F
01/20/25	23:00	0.0 FID	0.001 FI	-307.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-13.2 FI	20.9 F	199.7 F
01/21/25	00:00	0.0 FID	0.001 FI	-267.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-11.0 FI	20.9 F	199.7 F
01/21/25	01:00	0.0 FID	0.001 FI	-106.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-5.5 FI	20.9 F	199.7 F
01/21/25	02:00	0.0 FID	0.001 FI	-75.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.6 FI	20.9 F	199.8 F
01/21/25	03:00	0.0 FID	0.001 FI	-54.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.9 FI	20.9 F	199.8 F
01/21/25	04:00	0.0 FID	0.001 FI	-52.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.0 FI	20.9 F	199.8 F
01/21/25	05:00	0.0 FID	0.001 FI	-53.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.4 FI	20.9 F	199.7 F
01/21/25	06:00	0.0 FID	0.001 FI	-47.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.7 FI	21.0 F	199.7 F
01/21/25	07:00	0.0 FIC	0.015 FI	6.6 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.024 F	6.4 F	14.2 FC	199.7 F
01/21/25	08:00	0.0 FID	0.001 FI	61.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.1 FI	20.9 F	199.7 F
01/21/25	09:00	0.0 FID	0.053 FI	36.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.1 FI	20.8 F	199.7 F
01/21/25	10:00	0.0 FID	0.053 FI	23.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.8 F	199.7 F
01/21/25	11:00	0.0 FID	0.053 FI	22.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.8 F	199.7 F
01/21/25	12:00	0.0 FID	0.053 FI	30.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.8 F	199.7 F
01/21/25	13:00	0.0 FID	0.053 FI	30.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.8 F	199.7 F
01/21/25	14:00	0.0 FID	0.053 FI	34.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.8 F	199.7 F
01/21/25	15:00	0.0 FID	0.053 FI	44.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.1 FI	20.8 F	199.7 F
01/21/25	16:00	0.0 FID	0.053 FI	45.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.8 F	199.7 F
01/21/25	17:00	0.0 FID	0.001 FI	86.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.9 F	199.7 F
01/21/25	18:00	0.0 FID	0.001 FI	116.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.3 FI	20.9 F	199.7 F
01/21/25	19:00	0.0 FID	0.001 FI	94.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.9 F	199.7 F
01/21/25	20:00	0.0 FID	0.001 FI	169.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.6 FI	20.9 F	199.7 F
01/21/25	21:00	0.0 FID	0.001 FI	164.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.4 FI	20.9 F	199.7 F
01/21/25	22:00	0.0 FID	0.001 FI	147.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.0 FI	20.9 F	199.7 F
01/21/25	23:00	0.0 FID	0.001 FI	126.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.5 FI	20.9 F	199.7 F
01/22/25	00:00	0.0 FID	0.001 FI	123.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.4 FI	20.9 F	199.7 F
01/22/25	01:00	0.0 FID	0.001 FI	108.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.7 FI	20.9 F	199.7 F
01/22/25	02:00	0.0 FID	0.001 FI	117.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.8 FI	20.9 F	199.7 F
01/22/25	03:00	0.0 FID	0.001 FI	113.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.2 FI	20.9 F	199.7 F
01/22/25	04:00	0.0 FID	0.001 FI	100.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.9 F	199.7 F
01/22/25	05:00	0.0 FID	0.001 FI	106.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.9 FI	20.9 F	199.7 F
01/22/25	06:00	0.0 FID	0.001 FI	85.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.5 FI	20.9 F	199.7 F
01/22/25	07:00	0.0 FIC	0.015 FI	6.5 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.4 F	14.2 FC	199.7 F

Source		UNIT_A										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/22/25	08:00	0.0 FID	0.001 FI	221.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	10.0 FIE	20.9 F	199.7 F
01/22/25	09:00	0.0 FIM	0.015 FI	6.5 FI	0.0 F	0.0 F	0.0 FIM	0.0 FIM	0.023 F	6.3 F	14.2 FMC	199.7 F
01/22/25	10:00	0.0 FID	0.053 FI	39.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.7 F
01/22/25	11:00	0.0 FID	0.053 FI	29.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.7 F
01/22/25	12:00	0.0 FID	0.053 FI	27.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.7 F
01/22/25	13:00	0.0 FID	0.053 FI	31.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.8 F	199.7 F
01/22/25	14:00	0.0 FID	0.053 FI	29.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.7 F
01/22/25	15:00	0.0 FID	0.053 FI	30.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.7 F
01/22/25	16:00	0.0 FID	0.053 FI	34.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.7 F
01/22/25	17:00	0.0 FID	0.053 FI	40.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.8 F	199.7 F
01/22/25	18:00	0.0 FID	0.001 FI	62.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.9 F	199.7 F
01/22/25	19:00	0.0 FID	0.001 FI	78.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.9 F	199.7 F
01/22/25	20:00	0.0 FID	0.001 FI	78.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.9 F	199.7 F
01/22/25	21:00	0.0 FID	0.001 FI	77.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.9 F	199.7 F
01/22/25	22:00	0.0 FID	0.001 FI	121.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.9 F	199.7 F
01/22/25	23:00	0.0 FID	0.053 FI	28.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.7 F
01/23/25	00:00	0.0 FID	0.001 FI	141.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.9 F	199.7 F
01/23/25	01:00	0.0 FID	0.001 FI	148.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.9 F	199.7 F
01/23/25	02:00	0.0 FID	0.001 FI	327.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.5 FI	20.9 F	199.8 F
01/23/25	03:00	0.0 FID	0.001 FI	302.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.9 F	199.7 F
01/23/25	04:00	0.0 FID	0.001 FI	256.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.7 FI	20.9 F	199.7 F
01/23/25	05:00	0.0 FID	0.001 FI	141.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.9 F	199.7 F
01/23/25	06:00	0.0 FID	0.001 FI	238.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.9 F	199.7 F
01/23/25	07:00	0.0 FIC	0.015 FI	6.5 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.7 F
01/23/25	08:00	0.0 FIM	0.001 FI	0.6 FI	0.0 F	0.0 F	0.0 FIM	0.0 FIM	0.001 FI	0.2 FI	15.9 FM	199.8 F
01/23/25	09:00	0.0 FIM	0.010 FI	4.3 FI	0.0 F	0.0 F	0.0 FIM	0.0 FIM	0.023 F	6.1 F	1.8 FMC	199.8 F
01/23/25	10:00	0.0 FIC	0.020 FI	9.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.030 F	8.3 F	16.0 FC	199.8 F
01/23/25	11:00	0.0 FID	0.066 FIE	32.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.7 F
01/23/25	12:00	0.0 FID	0.066 FIE	36.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.7 F
01/23/25	13:00	0.0 FID	0.066 FIE	38.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.7 F
01/23/25	14:00	0.0 FID	0.066 FIE	44.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.7 F
01/23/25	15:00	0.0 FID	0.066 FIE	48.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.7 F
01/23/25	16:00	0.0 FID	0.066 FIE	47.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.7 F
01/23/25	17:00	0.0 FID	0.066 FIE	61.8 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.8 F	199.7 F
01/23/25	18:00	0.0 FID	0.001 FI	99.3 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
01/23/25	19:00	0.0 FID	0.001 FI	115.2 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.1 FI	20.9 F	199.7 F
01/23/25	20:00	0.0 FID	0.001 FI	110.9 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.7 F

Source		UNIT_A										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/23/25	21:00	0.0 FID	0.001 FI	138.9 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
01/23/25	22:00	0.0 FID	0.001 FI	155.3 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.1 FI	20.9 F	199.7 F
01/23/25	23:00	0.0 FID	0.001 FI	151.4 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
01/24/25	00:00	0.0 FID	0.001 FI	220.5 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
01/24/25	01:00	0.0 FID	0.001 FI	535.6 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.4 FI	20.9 F	199.7 F
01/24/25	02:00	0.0 FID	0.001 FI	269.2 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
01/24/25	03:00	0.0 FID	0.001 FI	1,006.3 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.6 FI	20.9 F	199.7 F
01/24/25	04:00	0.0 FID	0.001 FI	8,769.6 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
01/24/25	05:00	0.0 FID	0.066 FIE	45.6 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.8 F	199.7 F
01/24/25	06:00	0.0 FID	0.001 FI	-2,033.3 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
01/24/25	07:00	0.0 FIC	0.015 FI	6.5 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.7 F
01/24/25	08:00	0.0 FID	0.001 FI	131.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.9 F	199.7 F
01/24/25	09:00	0.0 FID	0.001 FI	73.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.9 F	199.7 F
01/24/25	10:00	0.0 FID	0.053 FI	43.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.7 F
01/24/25	11:00	0.0 FID	0.053 FI	40.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.7 F
01/24/25	12:00	0.0 FID	0.001 FI	49.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.9 F	199.7 F
01/24/25	13:00	0.0 FID	0.001 FI	56.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.9 F	199.7 F
01/24/25	14:00	0.0 FID	0.001 FI	46.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.9 F	199.7 F
01/24/25	15:00	0.0 FID	0.001 FI	52.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.9 F	199.7 F
01/24/25	16:00	0.0 FID	0.001 FI	63.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.9 F	199.7 F
01/24/25	17:00	0.0 FID	0.001 FI	69.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.9 F	199.7 F
01/24/25	18:00	0.0 FID	0.001 FI	117.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.9 F	199.7 F
01/24/25	19:00	0.0 FID	0.001 FI	131.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.9 F	199.7 F
01/24/25	20:00	0.0 FID	0.001 FI	112.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.9 F	199.7 F
01/24/25	21:00	0.0 FID	0.001 FI	272.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.9 F	199.7 F
01/24/25	22:00	0.0 FID	0.001 FI	174.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.9 F	199.7 F
01/24/25	23:00	0.0 FID	0.001 FI	129.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.9 F	199.7 F
01/25/25	00:00	0.0 FID	0.001 FI	297.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.9 F	199.7 F
01/25/25	01:00	0.0 FID	0.001 FI	185.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.9 F	199.7 F
01/25/25	02:00	0.0 FID	0.001 FI	224.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.9 F	199.7 F
01/25/25	03:00	0.0 FID	0.001 FI	266.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.7 FI	20.9 F	199.7 F
01/25/25	04:00	0.0 FID	0.001 FI	244.2 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.6 FI	20.9 F	199.7 F
01/25/25	05:00	0.0 FID	0.001 FI	376.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.9 F	199.7 F
01/25/25	06:00	0.0 FID	0.001 FI	223.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.9 F	199.7 F
01/25/25	07:00	0.0 FIC	0.014 FI	6.4 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.7 F
01/25/25	08:00	0.0 FID	0.001 FI	-57.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	20.9 F	199.7 F
01/25/25	09:00	0.0 FID	0.001 FI	-490.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.9 FI	20.9 F	199.7 F

Source		UNIT_A										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/25/25	10:00	0.0 FID	0.001 FI	-415.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	20.9 F	199.7 F
01/25/25	11:00	0.0 FID	0.001 FI	771.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.8 FIE	20.9 F	199.7 F
01/25/25	12:00	0.0 FID	0.001 FI	228.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.8 FI	20.9 F	199.7 F
01/25/25	13:00	0.0 FID	0.001 FI	152.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.0 FI	20.9 F	199.7 F
01/25/25	14:00	0.0 FID	0.001 FI	118.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.1 FI	20.9 F	199.7 F
01/25/25	15:00	0.0 FID	0.001 FI	110.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.0 FI	20.9 F	199.7 F
01/25/25	16:00	0.0 FID	0.001 FI	43.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.9 F	199.7 F
01/25/25	17:00	0.0 FID	0.001 FI	43.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.9 F	199.7 F
01/25/25	18:00	0.0 FID	0.001 FI	51.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.9 F	199.7 F
01/25/25	19:00	0.0 FID	0.001 FI	53.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.9 F	199.7 F
01/25/25	20:00	0.0 FID	0.001 FI	62.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.9 F	199.7 F
01/25/25	21:00	0.0 FID	0.001 FI	92.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.9 F	199.7 F
01/25/25	22:00	0.0 FID	0.001 FI	77.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.9 F	199.7 F
01/25/25	23:00	0.0 FID	0.001 FI	163.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.9 F	199.7 F
01/26/25	00:00	0.0 FID	0.001 FI	200.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.9 F	199.7 F
01/26/25	01:00	0.0 FID	0.001 FI	709.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.0 FI	20.9 F	199.7 F
01/26/25	02:00	0.0 FID	0.001 FI	-1,527.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-14.4 FI	20.9 F	199.7 F
01/26/25	03:00	0.0 FID	0.001 FI	128.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.9 F	199.7 F
01/26/25	04:00	0.0 FID	0.001 FI	200.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.9 F	199.7 F
01/26/25	05:00	0.0 FID	0.001 FI	131.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.9 FI	20.9 F	199.7 F
01/26/25	06:00	0.0 FID	0.001 FI	83.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.9 F	199.7 F
01/26/25	07:00	0.0 FIC	0.015 FI	6.5 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.7 F
01/26/25	08:00	0.0 FID	0.001 FI	76.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.8 FI	20.9 F	199.7 F
01/26/25	09:00	0.0 FID	0.001 FI	63.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.7 FI	20.9 F	199.7 F
01/26/25	10:00	0.0 FID	0.001 FI	54.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.8 FI	20.9 F	199.7 F
01/26/25	11:00	0.0 FID	0.001 FI	59.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.9 FI	20.9 F	199.7 F
01/26/25	12:00	0.0 FID	0.001 FI	42.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.8 FI	20.9 F	199.7 F
01/26/25	13:00	0.0 FID	0.001 FI	44.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.7 FI	20.9 F	199.7 F
01/26/25	14:00	0.0 FID	0.001 FI	52.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.8 FI	20.9 F	199.7 F
01/26/25	15:00	0.0 FID	0.001 FI	46.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.8 FI	20.9 F	199.7 F
01/26/25	16:00	0.0 FID	0.001 FI	45.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.2 FI	20.9 F	199.7 F
01/26/25	17:00	0.0 FID	0.001 FI	46.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.1 FI	20.9 F	199.7 F
01/26/25	18:00	0.0 FID	0.001 FI	53.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.4 FI	20.9 F	199.7 F
01/26/25	19:00	0.0 FID	0.001 FI	51.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.3 FI	20.9 F	199.7 F
01/26/25	20:00	0.0 FID	0.001 FI	51.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.1 FI	20.9 F	199.7 F
01/26/25	21:00	0.0 FID	0.001 FI	49.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.6 FI	20.9 F	199.7 F
01/26/25	22:00	0.0 FID	0.001 FI	49.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.5 FI	20.9 F	199.7 F

Source		UNIT_A										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/26/25	23:00	0.0 FID	0.053 FI	20.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.8 F	199.7 F
01/27/25	00:00	0.0 FID	0.001 FI	49.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.0 FI	20.9 F	199.7 F
01/27/25	01:00	0.0 FID	0.001 FI	51.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.4 FI	20.9 F	199.7 F
01/27/25	02:00	0.0 FID	0.001 FI	50.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.8 FI	20.9 F	199.7 F
01/27/25	03:00	0.0 FID	0.001 FI	66.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.6 FI	20.9 F	199.7 F
01/27/25	04:00	0.0 FID	0.001 FI	73.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.4 FI	20.9 F	199.7 F
01/27/25	05:00	0.0 FID	0.001 FI	62.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.3 FI	20.9 F	199.7 F
01/27/25	06:00	0.0 FID	0.001 FI	64.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.6 FI	20.9 F	199.7 F
01/27/25	07:00	0.0 FIC	0.014 FI	6.4 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.7 F
01/27/25	08:00	0.0 FID	0.053 FI	40.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.8 F	199.7 F
01/27/25	09:00	0.0 FID	0.053 FI	32.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.7 F
01/27/25	10:00	0.0 FID	0.053 FI	33.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.7 F
01/27/25	11:00	0.0 FID	0.053 FI	30.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.8 F	199.7 F
01/27/25	12:00	0.0 FID	0.053 FI	30.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.8 F	199.7 F
01/27/25	13:00	0.0 FID	0.053 FI	31.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.7 F
01/27/25	14:00	0.0 FID	0.053 FI	28.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.7 F
01/27/25	15:00	0.0 FID	0.053 FI	28.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.7 F
01/27/25	16:00	0.0 FID	0.053 FI	28.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.7 F
01/27/25	17:00	0.0 FID	0.053 FI	29.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.7 F
01/27/25	18:00	0.0 FID	0.053 FI	27.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.8 F	199.7 F
01/27/25	19:00	0.0 FID	0.053 FI	32.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.7 F
01/27/25	20:00	0.0 FID	0.053 FI	28.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.7 F
01/27/25	21:00	0.0 FID	0.053 FI	15.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.7 F
01/27/25	22:00	0.0 FID	0.053 FI	28.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.7 F
01/27/25	23:00	0.0 FID	0.053 FI	28.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.7 F
01/28/25	00:00	0.0 FID	0.053 FI	32.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.8 F	199.7 F
01/28/25	01:00	0.0 FID	0.053 FI	31.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.7 F
01/28/25	02:00	0.0 FID	0.001 FI	50.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.9 F	199.7 F
01/28/25	03:00	0.0 FID	0.001 FI	73.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.9 F	199.7 F
01/28/25	04:00	0.0 FID	0.001 FI	78.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.9 F	199.7 F
01/28/25	05:00	0.0 FID	0.001 FI	72.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.9 F	199.7 F
01/28/25	06:00	0.0 FID	0.001 FI	71.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.9 F	199.7 F
01/28/25	07:00	0.0 FIC	0.015 FI	6.5 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.7 F
01/28/25	08:00	0.0 FID	0.001 FI	109.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.6 FI	20.9 F	199.7 F
01/28/25	09:00	0.0 FID	0.001 FI	55.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.1 FI	20.9 F	199.7 F
01/28/25	10:00	0.0 FID	0.053 FI	41.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.5 FI	20.8 F	199.7 F
01/28/25	11:00	0.0 FID	0.053 FI	36.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.4 FI	20.8 F	199.7 F

Source		UNIT_A										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/28/25	12:00	0.0 FID	0.053 FI	42.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.5 FI	20.8 F	199.7 F
01/28/25	13:00	0.0 FID	0.053 FI	39.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.9 FI	20.8 F	199.7 F
01/28/25	14:00	0.0 FID	0.053 FI	39.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.8 FI	20.8 F	199.7 F
01/28/25	15:00	0.0 FID	0.001 FI	47.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.7 FI	20.9 F	199.7 F
01/28/25	16:00	0.0 FID	0.053 FI	43.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.7 FI	20.8 F	199.7 F
01/28/25	17:00	0.0 FID	0.053 FI	42.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.1 FI	20.8 F	199.7 F
01/28/25	18:00	0.0 FID	0.001 FI	44.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.8 FI	20.9 F	199.7 F
01/28/25	19:00	0.0 FID	0.001 FI	77.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.5 FI	20.9 F	199.7 F
01/28/25	20:00	0.0 FID	0.001 FI	166.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	6.0 FIE	20.9 F	199.7 F
01/28/25	21:00	0.0 FID	0.001 FI	725.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	19.0 FIE	20.9 F	199.7 F
01/28/25	22:00	0.0 FID	0.001 FI	185.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.9 FI	20.9 F	199.7 F
01/28/25	23:00	0.0 FID	0.001 FI	238.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	9.6 FIE	20.9 F	199.7 F
01/29/25	00:00	0.0 FID	0.001 FI	-2,069.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-50.8 FI	20.9 F	199.7 F
01/29/25	01:00	0.0 FID	0.001 FI	265.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	7.7 FIE	20.9 F	199.7 F
01/29/25	02:00	0.0 FID	0.001 FI	-728.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-17.0 FI	20.9 F	199.7 F
01/29/25	03:00	0.0 FID	0.001 FI	1,473.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	41.2 FIE	20.9 F	199.7 F
01/29/25	04:00	0.0 FID	0.001 FI	362.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	9.6 FIE	20.9 F	199.7 F
01/29/25	05:00	0.0 FID	0.001 FI	308.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	13.7 FIE	20.9 F	199.7 F
01/29/25	06:00	0.0 FID	0.001 FI	389.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	10.4 FIE	20.9 F	199.7 F
01/29/25	07:00	0.0 FIC	0.015 FI	6.6 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.024 F	6.5 F	14.2 FC	199.7 F
01/29/25	08:00	0.0 FID	0.001 FI	87.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	9.9 FIE	20.9 F	199.7 F
01/29/25	09:00	0.0 FID	0.001 FI	43.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.5 FI	20.9 F	199.7 F
01/29/25	10:00	0.0 FID	0.040 FI	35.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.0 FI	20.8 F	199.7 F
01/29/25	11:00	0.0 FID	0.040 FI	36.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.0 FI	20.8 F	199.7 F
01/29/25	12:00	0.0 FID	0.040 FI	34.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.6 FI	20.8 F	199.7 F
01/29/25	13:00	0.0 FID	0.040 FI	33.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.0 FI	20.8 F	199.7 F
01/29/25	14:00	0.0 FID	0.001 FI	38.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.3 FI	20.9 F	199.7 F
01/29/25	15:00	0.0 FID	0.001 FI	36.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.7 FI	20.9 F	199.7 F
01/29/25	16:00	0.0 FID	0.001 FI	39.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.1 FIE	20.9 F	199.7 F
01/29/25	17:00	0.0 FID	0.001 FI	63.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	6.1 FIE	20.9 F	199.7 F
01/29/25	18:00	0.0 FID	0.001 FI	148.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	14.7 FIE	20.9 F	199.7 F
01/29/25	19:00	0.0 FID	0.001 FI	126.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	11.0 FIE	20.9 F	199.7 F
01/29/25	20:00	0.0 FID	0.001 FI	394.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	36.6 FIE	20.9 F	199.7 F
01/29/25	21:00	0.0 FID	0.001 FI	1,650.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	125.5 FIE	20.9 F	199.7 F
01/29/25	22:00	0.0 FID	0.001 FI	296.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	26.0 FIE	20.9 F	199.7 F
01/29/25	23:00	0.0 FID	0.001 FI	404.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	39.5 FIE	20.9 F	199.7 F
01/30/25	00:00	0.0 FID	0.001 FI	-2,775.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-263.5 FI	20.9 F	199.7 F

Source		UNIT_A										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/30/25	01:00	0.0 FID	0.001 FI	-734.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-82.4 FI	20.9 F	199.7 F
01/30/25	02:00	0.0 FID	0.001 FI	-216.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-18.7 FI	20.9 F	199.7 F
01/30/25	03:00	0.0 FID	0.001 FI	4,721.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	465.4 FIE	20.9 F	199.7 F
01/30/25	04:00	0.0 FID	0.001 FI	293.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	32.1 FIE	20.9 F	199.7 F
01/30/25	05:00	0.0 FID	0.001 FI	-376.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-32.7 FI	20.9 F	199.7 F
01/30/25	06:00	0.0 FIM	0.001 FI	5,940.7 FIE	0.0 F	0.0 F	0.0 FIM	0.0 FIM	0.001 FI	609.4 FIE	20.9 FM	199.8 F
01/30/25	07:00	0.0 FIC	0.015 FI	6.5 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.7 F
01/30/25	08:00	0.0 FID	0.001 FI	298.9 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.3 FI	20.9 F	199.7 F
01/30/25	09:00	0.0 FID	0.001 FI	58.6 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.1 FI	20.9 F	199.7 F
01/30/25	10:00	0.0 FID	0.053 FI	40.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.7 F
01/30/25	11:00	0.0 FID	0.001 FI	42.0 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
01/30/25	12:00	0.0 FID	0.053 FI	41.0 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.8 F	199.7 F
01/30/25	13:00	0.0 FID	0.001 FI	46.0 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
01/30/25	14:00	0.0 FID	0.053 FI	40.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.7 F
01/30/25	15:00	0.0 FID	0.053 FI	39.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.7 F
01/30/25	16:00	0.0 FID	0.001 FI	42.6 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
01/30/25	17:00	0.0 FID	0.001 FI	42.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
01/30/25	18:00	0.0 FID	0.040 FI	37.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.7 F
01/30/25	19:00	0.0 FID	0.001 FI	46.9 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
01/30/25	20:00	0.0 FID	0.001 FI	43.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
01/30/25	21:00	0.0 FID	0.001 FI	41.8 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
01/30/25	22:00	0.0 FID	0.001 FI	42.7 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
01/30/25	23:00	0.0 FID	0.040 FI	17.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.7 F
01/31/25	00:00	0.0 FID	0.001 FI	42.8 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
01/31/25	01:00	0.0 FID	0.001 FI	40.9 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
01/31/25	02:00	0.0 FID	0.001 FI	76.8 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.1 FI	20.9 F	199.7 F
01/31/25	03:00	0.0 FID	0.001 FI	90.1 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
01/31/25	04:00	0.0 FID	0.001 FI	134.7 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
01/31/25	05:00	0.0 FID	0.001 FI	115.5 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.2 FI	20.9 F	199.7 F
01/31/25	06:00	0.0 FID	0.001 FI	112.2 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
01/31/25	07:00	0.0 FIC	0.015 FI	6.5 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.7 F
01/31/25	08:00	0.0 FID	0.001 FI	1,001.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	6.4 FIE	20.9 F	199.7 F
01/31/25	09:00	0.0 FID	0.001 FI	73.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.9 F	199.7 F
01/31/25	10:00	0.0 FID	0.001 FI	68.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.9 F	199.7 F
01/31/25	11:00	0.0 FID	0.001 FI	61.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.9 F	199.7 F
01/31/25	12:00	0.0 FID	0.001 FI	74.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.9 F	199.7 F
01/31/25	13:00	0.0 FID	0.001 FI	67.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.9 F	199.7 F

Source		UNIT_A										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/31/25	14:00	0.0 FID	0.001 FI	71.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.9 F	199.7 F
01/31/25	15:00	0.0 FID	0.001 FI	69.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.9 F	199.7 F
01/31/25	16:00	0.0 FID	0.001 FI	63.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.9 F	199.7 F
01/31/25	17:00	0.0 FID	0.001 FI	54.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.9 F	199.7 F
01/31/25	18:00	0.0 FID	0.001 FI	64.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.9 F	199.7 F
01/31/25	19:00	0.0 FID	0.001 FI	73.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.9 F	199.7 F
01/31/25	20:00	0.0 FID	0.001 FI	59.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.9 F	199.7 F
01/31/25	21:00	0.0 FID	0.001 FI	59.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.9 F	199.7 F
01/31/25	22:00	0.0 FID	0.001 FI	65.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.9 F	199.7 F
01/31/25	23:00	0.0 FID	0.001 FI	64.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.9 F	199.7 F
02/01/25	00:00	0.0 FID	0.001 FI	71.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.9 F	199.7 F
02/01/25	01:00	0.0 FID	0.001 FI	54.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.9 F	199.7 F
02/01/25	02:00	0.0 FID	0.001 FI	69.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.9 F	199.7 F
02/01/25	03:00	0.0 FID	0.001 FI	57.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.9 F	199.7 F
02/01/25	04:00	0.0 FID	0.001 FI	58.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.9 F	199.7 F
02/01/25	05:00	0.0 FID	0.001 FI	52.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.9 F	199.7 F
02/01/25	06:00	0.0 FID	0.001 FI	60.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.9 F	199.7 F
02/01/25	07:00	0.0 FIC	0.014 FI	6.5 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.7 F
02/01/25	08:00	0.0 FID	0.001 FI	-29.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
02/01/25	09:00	0.0 FID	0.001 FI	-29.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
02/01/25	10:00	0.0 FID	0.001 FI	-30.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
02/01/25	11:00	0.0 FID	0.001 FI	-30.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
02/01/25	12:00	0.0 FID	0.001 FI	-29.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
02/01/25	13:00	0.0 FID	0.001 FI	-29.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
02/01/25	14:00	0.0 FID	0.001 FI	-28.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
02/01/25	15:00	0.0 FID	0.001 FI	-30.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
02/01/25	16:00	0.0 FID	0.001 FI	-30.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.7 F
02/01/25	17:00	0.0 FID	0.001 FI	-29.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
02/01/25	18:00	0.0 FID	0.001 FI	-27.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
02/01/25	19:00	0.0 FID	0.001 FI	-30.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
02/01/25	20:00	0.0 FID	0.001 FI	-28.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
02/01/25	21:00	0.0 FID	0.001 FI	-29.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
02/01/25	22:00	0.0 FID	0.001 FI	-26.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
02/01/25	23:00	0.0 FID	0.001 FI	-32.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
02/02/25	00:00	0.0 FID	0.001 FI	-27.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
02/02/25	01:00	0.0 FID	0.001 FI	-29.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.7 F
02/02/25	02:00	0.0 FID	0.001 FI	-29.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.7 F

Source		UNIT_A										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/02/25	03:00	0.0 FID	0.001 FI	-27.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
02/02/25	04:00	0.0 FID	0.001 FI	-28.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
02/02/25	05:00	0.0 FID	0.001 FI	-28.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
02/02/25	06:00	0.0 FID	0.001 FI	-26.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
02/02/25	07:00	0.0 FIC	0.015 FI	6.6 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.4 F	14.2 FC	199.7 F
02/02/25	08:00	0.0 FID	0.001 FI	-29.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.7 F
02/02/25	09:00	0.0 FID	0.001 FI	-29.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.7 F
02/02/25	10:00	0.0 FID	0.001 FI	-31.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.7 F
02/02/25	11:00	0.0 FID	0.001 FI	-30.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.7 F
02/02/25	12:00	0.0 FID	0.001 FI	-31.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.7 F
02/02/25	13:00	0.0 FID	0.001 FI	-32.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.7 F
02/02/25	14:00	0.0 FID	0.001 FI	-29.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
02/02/25	15:00	0.0 FID	0.001 FI	-26.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.7 F
02/02/25	16:00	0.0 FID	0.001 FI	-30.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.7 F
02/02/25	17:00	0.0 FID	0.001 FI	-27.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.7 F
02/02/25	18:00	0.0 FID	0.001 FI	-29.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.7 F
02/02/25	19:00	0.0 FID	0.001 FI	-32.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.7 F
02/02/25	20:00	0.0 FID	0.001 FI	-28.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.7 F
02/02/25	21:00	0.0 FID	0.001 FI	-29.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.7 F
02/02/25	22:00	0.0 FID	0.001 FI	-32.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.7 F
02/02/25	23:00	0.0 FID	0.001 FI	-81.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	20.9 F	199.7 F
02/03/25	00:00	0.0 FID	0.001 FI	-30.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.7 F
02/03/25	01:00	0.0 FID	0.001 FI	-31.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
02/03/25	02:00	0.0 FID	0.001 FI	-26.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
02/03/25	03:00	0.0 FID	0.001 FI	-32.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.7 F
02/03/25	04:00	0.0 FID	0.001 FI	-29.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
02/03/25	05:00	0.0 FID	0.001 FI	-28.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.7 F
02/03/25	06:00	0.0 FID	0.001 FI	-95.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.0 FI	20.9 F	199.7 F
02/03/25	07:00	0.0 FIC	0.015 FI	6.6 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.024 F	6.5 F	14.2 FC	199.7 F
02/03/25	08:00	0.0 FID	0.001 FI	-21.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.7 F
02/03/25	09:00	0.0 FID	0.001 FI	-25.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.7 F
02/03/25	10:00	0.0 FID	0.001 FI	-22.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.7 F
02/03/25	11:00	0.0 FID	0.001 FI	-21.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.7 F
02/03/25	12:00	0.0 FID	0.001 FI	-21.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.7 F
02/03/25	13:00	0.0 FID	0.001 FI	-22.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.7 F
02/03/25	14:00	0.0 FID	0.001 FI	-22.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	21.0 F	199.7 F
02/03/25	15:00	0.0 FID	0.001 FI	-21.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.7 F

Source	Parameter Unit	UNIT_A										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/03/25	16:00	0.0 FID	0.001 FI	-22.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.7 F
02/03/25	17:00	0.0 FID	0.001 FI	-21.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.7 F
02/03/25	18:00	0.0 FID	0.001 FI	-21.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.7 F
02/03/25	19:00	0.0 FID	0.001 FI	-20.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.7 F
02/03/25	20:00	0.0 FID	0.001 FI	-22.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	21.0 F	199.7 F
02/03/25	21:00	0.0 FID	0.001 FI	-22.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.7 F
02/03/25	22:00	0.0 FID	0.001 FI	-19.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.7 F
02/03/25	23:00	0.0 FID	0.001 FI	-20.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.7 F
02/04/25	00:00	0.0 FID	0.001 FI	-21.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.7 F
02/04/25	01:00	0.0 FID	0.001 FI	-20.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.7 F
02/04/25	02:00	0.0 FID	0.001 FI	-20.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.7 F
02/04/25	03:00	0.0 FID	0.001 FI	-19.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.7 F
02/04/25	04:00	0.0 FID	0.001 FI	-19.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.7 F
02/04/25	05:00	0.0 FID	0.001 FI	-20.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.7 F
02/04/25	06:00	0.0 FID	0.001 FI	-20.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.7 F
02/04/25	07:00	0.0 FIC	0.015 FI	6.5 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.024 F	6.4 F	14.3 FC	199.7 F
02/04/25	08:00	0.0 FID	0.001 FI	-93.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-7.9 FI	20.9 F	199.7 F
02/04/25	09:00	0.0 FID	0.001 FI	81.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.3 FIE	20.9 F	199.7 F
02/04/25	10:00	0.0 FID	0.001 FI	-82.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-5.2 FI	20.9 F	199.7 F
02/04/25	11:00	0.0 FID	0.001 FI	-92.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-6.8 FI	20.9 F	199.7 F
02/04/25	12:00	0.0 FID	0.001 FI	-100.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-6.7 FI	20.9 F	199.7 F
02/04/25	13:00	0.0 FID	0.001 FI	-105.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-7.5 FI	20.9 F	199.7 F
02/04/25	14:00	0.0 FID	0.001 FI	-104.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-8.3 FI	20.9 F	199.7 F
02/04/25	15:00	0.0 FID	0.001 FI	-93.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-6.4 FI	20.9 F	199.7 F
02/04/25	16:00	0.0 FID	0.001 FI	-84.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-6.3 FI	20.9 F	199.7 F
02/04/25	17:00	0.0 FID	0.001 FI	-83.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-7.1 FI	20.9 F	199.7 F
02/04/25	18:00	0.0 FID	0.001 FI	-76.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.9 FI	20.9 F	199.8 F
02/04/25	19:00	0.0 FID	0.001 FI	-90.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-7.0 FI	20.9 F	199.8 F
02/04/25	20:00	0.0 FID	0.001 FI	-84.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-6.6 FI	20.9 F	199.8 F
02/04/25	21:00	0.0 FID	0.001 FI	-90.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-6.1 FI	20.9 F	199.8 F
02/04/25	22:00	0.0 FID	0.001 FI	-87.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-7.5 FI	20.9 F	199.8 F
02/04/25	23:00	0.0 FID	0.001 FI	-88.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-6.7 FI	20.9 F	199.8 F
02/05/25	00:00	0.0 FID	0.001 FI	-99.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-6.8 FI	20.9 F	199.7 F
02/05/25	01:00	0.0 FID	0.001 FI	-97.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-8.1 FI	20.9 F	199.7 F
02/05/25	02:00	0.0 FID	0.001 FI	-109.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-8.2 FI	20.9 F	199.7 F
02/05/25	03:00	0.0 FID	0.001 FI	-97.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-7.5 FI	20.9 F	199.7 F
02/05/25	04:00	0.0 FID	0.001 FI	-83.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-6.7 FI	20.9 F	199.7 F

Source		UNIT_A										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/05/25	05:00	0.0 FID	0.001 FI	-101.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-7.6 FI	20.9 F	199.7 F
02/05/25	06:00	0.0 FID	0.001 FI	-97.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-6.7 FI	20.9 F	199.7 F
02/05/25	07:00	0.0 FIC	0.015 FI	6.7 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.4 F	14.2 FC	199.7 F
02/05/25	08:00	0.0 FID	0.001 FI	-23.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	21.0 F	199.7 F
02/05/25	09:00	0.0 FID	0.001 FI	-22.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.8 F
02/05/25	10:00	0.0 FID	0.001 FI	-23.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.7 F
02/05/25	11:00	0.0 FID	0.001 FI	-22.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.7 F
02/05/25	12:00	0.0 FID	0.001 FI	-22.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	21.0 F	199.7 F
02/05/25	13:00	0.0 FID	0.001 FI	-23.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	21.0 F	199.7 F
02/05/25	14:00	0.0 FID	0.001 FI	-23.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	21.0 F	199.7 F
02/05/25	15:00	0.0 FID	0.001 FI	-23.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	21.0 F	199.7 F
02/05/25	16:00	0.0 FID	0.001 FI	-22.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	21.0 F	199.7 F
02/05/25	17:00	0.0 FID	0.001 FI	-24.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.7 F
02/05/25	18:00	0.0 FID	0.001 FI	-23.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	21.0 F	199.7 F
02/05/25	19:00	0.0 FID	0.001 FI	-25.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	21.0 F	199.7 F
02/05/25	20:00	0.0 FID	0.001 FI	-23.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	21.0 F	199.7 F
02/05/25	21:00	0.0 FID	0.001 FI	-22.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	21.0 F	199.7 F
02/05/25	22:00	0.0 FID	0.001 FI	-44.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.7 FI	21.0 F	199.7 F
02/05/25	23:00	0.0 FID	0.001 FI	-21.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	21.0 F	199.7 F
02/06/25	00:00	0.0 FID	0.001 FI	-21.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	21.0 F	199.7 F
02/06/25	01:00	0.0 FID	0.001 FI	-20.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.8 F
02/06/25	02:00	0.0 FID	0.001 FI	-20.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	21.0 F	199.8 F
02/06/25	03:00	0.0 FID	0.001 FI	-20.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	21.0 F	199.7 F
02/06/25	04:00	0.0 FID	0.001 FI	-20.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.8 F
02/06/25	05:00	0.0 FID	0.001 FI	-21.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	21.0 F	199.8 F
02/06/25	06:00	0.0 FID	0.001 FI	-20.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.8 F
02/06/25	07:00	0.0 FIC	0.015 FI	6.6 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.024 F	6.4 F	14.3 FC	199.8 F
02/06/25	08:00	0.0 FID	0.001 FI	-27.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	21.0 F	199.7 F
02/06/25	09:00	0.0 FID	0.001 FI	-27.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	21.0 F	199.7 F
02/06/25	10:00	0.0 FID	0.001 FI	-27.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	21.0 F	199.7 F
02/06/25	11:00	0.0 FID	0.001 FI	-27.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.7 F
02/06/25	12:00	0.0 FID	0.001 FI	-28.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	21.0 F	199.7 F
02/06/25	13:00	0.0 FID	0.001 FI	-28.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.7 F
02/06/25	14:00	0.0 FID	0.001 FI	-28.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.9 FI	21.0 F	199.8 F
02/06/25	15:00	0.0 FID	0.001 FI	-26.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.7 FI	21.0 F	199.8 F
02/06/25	16:00	0.0 FID	0.001 FI	-26.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.7 F
02/06/25	17:00	0.0 FID	0.001 FI	-27.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	21.0 F	199.7 F

Source Parameter Unit		UNIT_A										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/06/25	18:00	0.0 FID	0.001 FI	-26.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.7 FI	21.0 F	199.7 F
02/06/25	19:00	0.0 FID	0.001 FI	-28.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.2 FI	21.0 F	199.7 F
02/06/25	20:00	0.0 FID	0.001 FI	-27.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	21.0 F	199.7 F
02/06/25	21:00	0.0 FID	0.001 FI	-26.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	21.0 F	199.7 F
02/06/25	22:00	0.0 FID	0.001 FI	-29.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.2 FI	21.0 F	199.7 F
02/06/25	23:00	0.0 FID	0.001 FI	-79.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.7 FI	20.9 F	199.7 F
02/07/25	00:00	0.0 FID	0.001 FI	-27.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	21.0 F	199.7 F
02/07/25	01:00	0.0 FID	0.001 FI	-28.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	21.0 F	199.7 F
02/07/25	02:00	0.0 FID	0.001 FI	-26.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.9 FI	21.0 F	199.7 F
02/07/25	03:00	0.0 FID	0.001 FI	-27.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.9 FI	21.0 F	199.7 F
02/07/25	04:00	0.0 FID	0.001 FI	-27.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	21.0 F	199.7 F
02/07/25	05:00	0.0 FID	0.001 FI	-26.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	21.0 F	199.7 F
02/07/25	06:00	0.0 FID	0.001 FI	-27.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.8 F
02/07/25	07:00	0.0 FIC	0.015 FI	6.6 FI	0.0 F	0.0 F	0.0 FIC	0.1 FIC	0.023 F	6.3 F	14.2 FC	199.7 F
02/07/25	08:00	0.0 FID	0.001 FI	-29.0 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
02/07/25	09:00	0.0 FID	0.001 FI	-30.6 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
02/07/25	10:00	0.0 FID	0.001 FI	-30.8 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
02/07/25	11:00	0.0 FID	0.001 FI	-30.0 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
02/07/25	12:00	0.0 FID	0.001 FI	-32.3 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
02/07/25	13:00	0.0 FID	0.001 FI	-27.4 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
02/07/25	14:00	0.0 FID	0.001 FI	-30.1 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
02/07/25	15:00	0.0 FID	0.001 FI	-30.0 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
02/07/25	16:00	0.0 FID	0.001 FI	-30.1 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
02/07/25	17:00	0.0 FID	0.001 FI	-30.5 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
02/07/25	18:00	0.0 FID	0.001 FI	-31.4 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
02/07/25	19:00	0.0 FID	0.001 FI	-30.7 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
02/07/25	20:00	0.0 FID	0.001 FI	-28.7 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
02/07/25	21:00	0.0 FID	0.001 FI	-29.4 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
02/07/25	22:00	0.0 FID	0.001 FI	-31.2 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
02/07/25	23:00	0.0 FID	0.001 FI	-28.8 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
02/08/25	00:00	0.0 FID	0.001 FI	-32.2 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
02/08/25	01:00	0.0 FID	0.001 FI	-28.4 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
02/08/25	02:00	0.0 FID	0.001 FI	-31.2 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
02/08/25	03:00	0.0 FID	0.001 FI	-29.6 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
02/08/25	04:00	0.0 FID	0.001 FI	-29.1 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
02/08/25	05:00	0.0 FID	0.001 FI	-28.8 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
02/08/25	06:00	0.0 FID	0.001 FI	-29.2 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	21.0 F	199.7 F

Source		UNIT_A										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/08/25	07:00	0.0 FIC	0.015 FI	6.6 FI	0.0 F	0.0 F	0.0 FIC	0.1 FIC	0.024 F	6.4 F	14.3 FC	199.7 F
02/08/25	08:00	0.0 FID	0.001 FI	-67.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.3 FI	20.9 F	199.7 F
02/08/25	09:00	0.0 FID	0.001 FI	-74.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	20.9 F	199.7 F
02/08/25	10:00	0.0 FID	0.001 FI	-69.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	20.9 F	199.8 F
02/08/25	11:00	0.0 FID	0.001 FI	-73.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	20.9 F	199.8 F
02/08/25	12:00	0.0 FID	0.001 FI	-79.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	20.9 F	199.8 F
02/08/25	13:00	0.0 FID	0.001 FI	-65.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.9 FI	20.9 F	199.8 F
02/08/25	14:00	0.0 FID	0.001 FI	-69.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	20.9 F	199.7 F
02/08/25	15:00	0.0 FID	0.001 FI	-68.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	20.9 F	199.7 F
02/08/25	16:00	0.0 FID	0.001 FI	-62.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	20.9 F	199.7 F
02/08/25	17:00	0.0 FID	0.001 FI	-74.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	20.9 F	199.8 F
02/08/25	18:00	0.0 FID	0.001 FI	-68.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	20.9 F	199.8 F
02/08/25	19:00	0.0 FID	0.001 FI	-68.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	20.9 F	199.8 F
02/08/25	20:00	0.0 FID	0.001 FI	-67.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	20.9 F	199.8 F
02/08/25	21:00	0.0 FID	0.001 FI	-56.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	20.9 F	199.8 F
02/08/25	22:00	0.0 FID	0.001 FI	-56.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	20.9 F	199.8 F
02/08/25	23:00	0.0 FID	0.001 FI	-75.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	20.9 F	199.8 F
02/09/25	00:00	0.0 FID	0.001 FI	-60.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	20.9 F	199.8 F
02/09/25	01:00	0.0 FID	0.001 FI	-50.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	21.0 F	199.8 F
02/09/25	02:00	0.0 FID	0.001 FI	-43.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.8 F
02/09/25	03:00	0.0 FID	0.001 FI	-31.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.8 F
02/09/25	04:00	0.0 FID	0.001 FI	-27.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.8 F
02/09/25	05:00	0.0 FID	0.001 FI	-28.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.8 F
02/09/25	06:00	0.0 FID	0.001 FI	-25.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.8 F
02/09/25	07:00	0.0 FIC	0.015 FI	6.5 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.024 F	6.5 F	14.2 FC	199.8 F
02/09/25	08:00	0.0 FID	0.001 FI	3,238.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	78.2 FIE	20.9 F	199.8 F
02/09/25	09:00	0.0 FID	0.001 FI	532.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	24.7 FIE	20.9 F	199.8 F
02/09/25	10:00	0.0 FID	0.001 FI	201.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	6.1 FIE	20.9 F	199.8 F
02/09/25	11:00	0.0 FID	0.001 FI	94.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.2 FI	20.9 F	199.8 F
02/09/25	12:00	0.0 FID	0.001 FI	60.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.1 FI	20.9 F	199.7 F
02/09/25	13:00	0.0 FID	0.001 FI	68.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.1 FI	20.9 F	199.7 F
02/09/25	14:00	0.0 FID	0.001 FI	67.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.0 FI	20.9 F	199.7 F
02/09/25	15:00	0.0 FID	0.001 FI	66.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.7 FI	20.9 F	199.7 F
02/09/25	16:00	0.0 FID	0.001 FI	81.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.4 FI	20.9 F	199.7 F
02/09/25	17:00	0.0 FID	0.001 FI	78.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.4 FI	20.9 F	199.7 F
02/09/25	18:00	0.0 FID	0.001 FI	104.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.0 FI	20.9 F	199.7 F
02/09/25	19:00	0.0 FID	0.001 FI	235.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	6.5 FIE	20.9 F	199.7 F

Source		UNIT_A										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/09/25	20:00	0.0 FID	0.001 FI	1,484.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	61.3 FIE	20.9 F	199.7 F
02/09/25	21:00	0.0 FID	0.001 FI	703.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	25.3 FIE	20.9 F	199.7 F
02/09/25	22:00	0.0 FID	0.001 FI	12,467.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	410.0 FIE	20.9 F	199.7 F
02/09/25	23:00	0.0 FID	0.001 FI	578.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	23.2 FIE	20.9 F	199.7 F
02/10/25	00:00	0.0 FID	0.001 FI	-1,598.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-46.5 FI	20.9 F	199.7 F
02/10/25	01:00	0.0 FID	0.001 FI	-657.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-18.7 FI	20.9 F	199.7 F
02/10/25	02:00	0.0 FID	0.001 FI	-1,041.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-38.1 FI	20.9 F	199.7 F
02/10/25	03:00	0.0 FID	0.001 FI	-1,435.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-50.9 FI	20.9 F	199.7 F
02/10/25	04:00	0.0 FID	0.001 FI	599.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	16.8 FIE	20.9 F	199.7 F
02/10/25	05:00	0.0 FID	0.001 FI	858.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	43.1 FIE	20.9 F	199.7 F
02/10/25	06:00	0.0 FID	0.001 FI	11,885.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	439.2 FIE	20.9 F	199.7 F
02/10/25	07:00	0.0 FIC	0.014 FI	6.5 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.2 FC	199.7 F
02/10/25	08:00	0.0 FID	0.053 FI	42.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.6 FI	20.8 F	199.7 F
02/10/25	09:00	0.0 FID	0.053 FI	44.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.8 F	199.7 F
02/10/25	10:00	0.0 FID	0.053 FI	39.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.8 F	199.7 F
02/10/25	11:00	0.0 FID	0.053 FI	38.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.8 F	199.7 F
02/10/25	12:00	0.0 FID	0.053 FI	37.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.0 FI	20.8 F	199.7 F
02/10/25	13:00	0.0 FID	0.053 FI	30.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.8 F	199.7 F
02/10/25	14:00	0.0 FID	0.053 FI	36.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.8 F	199.7 F
02/10/25	15:00	0.0 FID	0.053 FI	30.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.8 F	199.7 F
02/10/25	16:00	0.0 FID	0.053 FI	31.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.8 F	199.7 F
02/10/25	17:00	0.0 FID	0.053 FI	36.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.8 F	199.7 F
02/10/25	18:00	0.0 FID	0.053 FI	43.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.8 FI	20.8 F	199.7 F
02/10/25	19:00	0.0 FID	0.053 FI	46.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.7 FI	20.8 F	199.7 F
02/10/25	20:00	0.0 FID	0.001 FI	52.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.6 FI	20.9 F	199.7 F
02/10/25	21:00	0.0 FID	0.001 FI	58.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.9 F	199.7 F
02/10/25	22:00	0.0 FID	0.001 FI	63.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.0 FI	20.9 F	199.7 F
02/10/25	23:00	0.0 FID	0.053 FI	26.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.0 FI	20.8 F	199.7 F
02/11/25	00:00	0.0 FID	0.001 FI	56.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.7 FI	20.9 F	199.7 F
02/11/25	01:00	0.0 FID	0.001 FI	57.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.8 FI	20.9 F	199.7 F
02/11/25	02:00	0.0 FID	0.001 FI	68.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.5 FI	20.9 F	199.8 F
02/11/25	03:00	0.0 FID	0.001 FI	65.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.6 FI	20.9 F	199.7 F
02/11/25	04:00	0.0 FID	0.001 FI	54.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.7 FI	20.9 F	199.7 F
02/11/25	05:00	0.0 FID	0.001 FI	63.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.9 F	199.7 F
02/11/25	06:00	0.0 FID	0.001 FI	51.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.9 F	199.7 F
02/11/25	07:00	0.0 FIC	0.015 FI	6.5 FI	0.0 F	0.0 F	0.0 FIC	0.1 FIC	0.023 F	6.3 F	14.2 FC	199.7 F
02/11/25	08:00	0.0 FID	0.001 FI	-47.2 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	21.0 F	199.7 F

Source Parameter Unit	UNIT_A										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/11/25 09:00	0.0 FID	0.001 FI	-55.0 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
02/11/25 10:00	0.0 FID	0.001 FI	-50.6 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
02/11/25 11:00	0.0 FID	0.001 FI	-51.9 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
02/11/25 12:00	0.0 FID	0.001 FI	-60.7 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
02/11/25 13:00	0.0 FID	0.001 FI	-56.6 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
02/11/25 14:00	0.0 FID	0.001 FI	-46.9 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
02/11/25 15:00	0.0 FID	0.001 FI	-41.7 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
02/11/25 16:00	0.0 FID	0.001 FI	-39.8 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
02/11/25 17:00	0.0 FID	0.001 FI	-36.9 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
02/11/25 18:00	0.0 FID	0.001 FI	-35.9 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
02/11/25 19:00	0.0 FID	0.001 FI	-32.0 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
02/11/25 20:00	0.0 FID	0.001 FI	-33.9 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
02/11/25 21:00	0.0 FID	0.001 FI	-34.4 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
02/11/25 22:00	0.0 FID	0.001 FI	-37.2 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
02/11/25 23:00	0.0 FID	0.001 FI	-43.0 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
02/12/25 00:00	0.0 FID	0.001 FI	-67.0 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
02/12/25 01:00	0.0 FID	0.001 FI	-55.3 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
02/12/25 02:00	0.0 FID	0.001 FI	-75.2 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
02/12/25 03:00	0.0 FID	0.001 FI	-75.5 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
02/12/25 04:00	0.0 FID	0.001 FI	-96.8 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
02/12/25 05:00	0.0 FID	0.001 FI	-178.7 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
02/12/25 06:00	0.0 FID	0.001 FI	-157.8 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
02/12/25 07:00	0.0 FIC	0.015 FI	6.5 FI	0.0 F	0.0 F	0.0 FIC	0.2 FIC	0.023 F	6.3 F	14.2 FC	199.7 F
02/12/25 08:00	0.0 FID	0.001 FI	98.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	6.6 FIE	20.9 F	199.7 F
02/12/25 09:00	0.0 FID	0.001 FI	78.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	6.3 FIE	20.9 F	199.7 F
02/12/25 10:00	0.0 FID	0.001 FI	74.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.3 FI	20.9 F	199.7 F
02/12/25 11:00	0.0 FID	0.001 FI	64.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.2 FIE	20.9 F	199.7 F
02/12/25 12:00	0.0 FID	0.001 FI	67.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.5 FIE	20.9 F	199.7 F
02/12/25 13:00	0.0 FID	0.001 FI	63.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.7 FI	20.9 F	199.7 F
02/12/25 14:00	0.0 FID	0.001 FI	67.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.2 FIE	20.9 F	199.7 F
02/12/25 15:00	0.0 FID	0.001 FI	65.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.5 FI	20.9 F	199.7 F
02/12/25 16:00	0.0 FID	0.001 FI	68.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.4 FI	20.9 F	199.7 F
02/12/25 17:00	0.0 FID	0.001 FI	53.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.4 FI	20.9 F	199.7 F
02/12/25 18:00	0.0 FID	0.001 FI	63.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.3 FIE	20.9 F	199.7 F
02/12/25 19:00	0.0 FID	0.001 FI	67.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.5 FI	20.9 F	199.7 F
02/12/25 20:00	0.0 FID	0.001 FI	59.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.8 FI	20.9 F	199.7 F
02/12/25 21:00	0.0 FID	0.001 FI	73.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.2 FIE	20.9 F	199.7 F

Source	Parameter Unit	UNIT_A										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/12/25	22:00	0.0 FID	0.001 FI	72.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.1 FIE	20.9 F	199.7 F
02/12/25	23:00	0.0 FID	0.001 FI	77.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.8 FIE	20.9 F	199.7 F
02/13/25	00:00	0.0 FID	0.001 FI	65.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.9 FIE	20.9 F	199.7 F
02/13/25	01:00	0.0 FID	0.001 FI	61.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.2 FI	20.9 F	199.7 F
02/13/25	02:00	0.0 FID	0.001 FI	61.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.3 FIE	20.9 F	199.7 F
02/13/25	03:00	0.0 FID	0.001 FI	75.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.8 FI	20.9 F	199.7 F
02/13/25	04:00	0.0 FID	0.001 FI	48.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.0 FI	20.9 F	199.7 F
02/13/25	05:00	0.0 FID	0.001 FI	61.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.8 FI	20.9 F	199.7 F
02/13/25	06:00	0.0 FID	0.001 FI	76.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.3 FI	20.9 F	199.7 F
02/13/25	07:00	0.0 FIC	0.015 FI	6.5 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.024 F	6.4 F	14.2 FC	199.7 F
02/13/25	08:00	0.0 FID	0.001 FI	-35.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.1 FI	21.0 F	199.7 F
02/13/25	09:00	0.0 FID	0.001 FI	-31.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.4 FI	21.0 F	199.7 F
02/13/25	10:00	0.0 FID	0.001 FI	-30.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.2 FI	21.0 F	199.7 F
02/13/25	11:00	0.0 FID	0.001 FI	-30.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.7 FI	21.0 F	199.8 F
02/13/25	12:00	0.0 FID	0.001 FI	-30.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.2 FI	21.0 F	199.8 F
02/13/25	13:00	0.0 FID	0.001 FI	-31.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.4 FI	21.0 F	199.8 F
02/13/25	14:00	0.0 FID	0.001 FI	-28.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.4 FI	21.0 F	199.7 F
02/13/25	15:00	0.0 FID	0.001 FI	-28.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.9 FI	21.0 F	199.7 F
02/13/25	16:00	0.0 FID	0.001 FI	-30.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.1 FI	21.0 F	199.7 F
02/13/25	17:00	0.0 FID	0.001 FI	-32.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.7 FI	21.0 F	199.7 F
02/13/25	18:00	0.0 FID	0.001 FI	-30.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.1 FI	21.0 F	199.7 F
02/13/25	19:00	0.0 FID	0.001 FI	-30.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.4 FI	21.0 F	199.7 F
02/13/25	20:00	0.0 FID	0.001 FI	-30.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.4 FI	21.0 F	199.7 F
02/13/25	21:00	0.0 FID	0.001 FI	-29.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.1 FI	21.0 F	199.7 F
02/13/25	22:00	0.0 FID	0.001 FI	-31.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.5 FI	21.0 F	199.7 F
02/13/25	23:00	0.0 FID	0.001 FI	-29.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.5 FI	21.0 F	199.7 F
02/14/25	00:00	0.0 FID	0.001 FI	-31.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.3 FI	21.0 F	199.7 F
02/14/25	01:00	0.0 FID	0.001 FI	-29.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.2 FI	21.0 F	199.7 F
02/14/25	02:00	0.0 FID	0.001 FI	-30.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.9 FI	21.0 F	199.8 F
02/14/25	03:00	0.0 FID	0.001 FI	-29.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	21.0 F	199.7 F
02/14/25	04:00	0.0 FID	0.001 FI	-29.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.2 FI	21.0 F	199.8 F
02/14/25	05:00	0.0 FID	0.001 FI	-29.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	21.0 F	199.7 F
02/14/25	06:00	0.0 FID	0.001 FI	-30.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.0 FI	21.0 F	199.7 F
02/14/25	07:00	0.0 FIC	0.015 FI	6.6 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.4 F	14.2 FC	199.7 F
02/14/25	08:00	0.0 FID	0.001 FI	-85.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.8 FI	20.9 F	199.8 F
02/14/25	09:00	0.0 FID	0.001 FI	-71.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.7 FI	20.9 F	199.8 F
02/14/25	10:00	0.0 FID	0.001 FI	-83.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.3 FI	20.9 F	199.7 F

Source		UNIT_A										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/14/25	11:00	0.0 FID	0.001 FI	-77.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.9 FI	20.9 F	199.7 F
02/14/25	12:00	0.0 FID	0.001 FI	-84.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.5 FI	20.9 F	199.7 F
02/14/25	13:00	0.0 FID	0.001 FI	-81.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.0 FI	20.9 F	199.7 F
02/14/25	14:00	0.0 FID	0.001 FI	-70.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.9 FI	20.9 F	199.7 F
02/14/25	15:00	0.0 FID	0.001 FI	-95.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.6 FI	20.9 F	199.7 F
02/14/25	16:00	0.0 FID	0.001 FI	-98.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.0 FI	20.9 F	199.7 F
02/14/25	17:00	0.0 FID	0.001 FI	-98.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.9 FI	20.9 F	199.7 F
02/14/25	18:00	0.0 FID	0.001 FI	-89.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.9 FI	20.9 F	199.7 F
02/14/25	19:00	0.0 FID	0.001 FI	-90.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.8 FI	20.9 F	199.7 F
02/14/25	20:00	0.0 FID	0.001 FI	-102.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.6 FI	20.9 F	199.7 F
02/14/25	21:00	0.0 FID	0.001 FI	-79.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.3 FI	20.9 F	199.8 F
02/14/25	22:00	0.0 FID	0.001 FI	-78.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.0 FI	20.9 F	199.8 F
02/14/25	23:00	0.0 FID	0.001 FI	-73.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.1 FI	20.9 F	199.8 F
02/15/25	00:00	0.0 FID	0.001 FI	-67.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.9 FI	20.9 F	199.8 F
02/15/25	01:00	0.0 FID	0.001 FI	-95.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.4 FI	20.9 F	199.8 F
02/15/25	02:00	0.0 FID	0.001 FI	-81.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	20.9 F	199.8 F
02/15/25	03:00	0.0 FID	0.001 FI	-73.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.0 FI	20.9 F	199.8 F
02/15/25	04:00	0.0 FID	0.001 FI	-79.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.0 FI	20.9 F	199.8 F
02/15/25	05:00	0.0 FID	0.001 FI	-80.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.1 FI	20.9 F	199.8 F
02/15/25	06:00	0.0 FID	0.001 FI	-81.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.7 FI	20.9 F	199.8 F
02/15/25	07:00	0.0 FIC	0.015 FI	6.6 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.8 F
02/15/25	08:00	0.0 FID	0.001 FI	-30.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.7 F
02/15/25	09:00	0.0 FID	0.001 FI	-33.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.7 F
02/15/25	10:00	0.0 FID	0.001 FI	-34.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.7 F
02/15/25	11:00	0.0 FID	0.001 FI	-30.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.7 F
02/15/25	12:00	0.0 FID	0.001 FI	-33.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.7 F
02/15/25	13:00	0.0 FID	0.001 FI	-30.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.7 F
02/15/25	14:00	0.0 FID	0.001 FI	-31.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.7 F
02/15/25	15:00	0.0 FID	0.001 FI	-32.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.7 F
02/15/25	16:00	0.0 FID	0.001 FI	-31.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.7 F
02/15/25	17:00	0.0 FID	0.001 FI	-31.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.7 F
02/15/25	18:00	0.0 FID	0.001 FI	-33.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.7 F
02/15/25	19:00	0.0 FID	0.001 FI	-29.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.7 F
02/15/25	20:00	0.0 FID	0.001 FI	-32.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.7 F
02/15/25	21:00	0.0 FID	0.001 FI	-38.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.7 F
02/15/25	22:00	0.0 FID	0.001 FI	-30.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.7 F
02/15/25	23:00	0.0 FID	0.001 FI	-29.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.7 F

Source Parameter Unit	UNIT_A											
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)	
02/16/25 00:00	0.0 FID	0.001 FI	-34.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.7 F	
02/16/25 01:00	0.0 FID	0.001 FI	-29.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.7 F	
02/16/25 02:00	0.0 FID	0.001 FI	-31.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.7 F	
02/16/25 03:00	0.0 FID	0.001 FI	-34.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.8 F	
02/16/25 04:00	0.0 FID	0.001 FI	-29.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.8 F	
02/16/25 05:00	0.0 FID	0.001 FI	-30.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.8 F	
02/16/25 06:00	0.0 FID	0.001 FI	-30.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.8 F	
02/16/25 07:00	0.0 FIC	0.015 FI	6.6 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.3 FC	199.8 F	
02/16/25 08:00	0.0 FID	0.001 FI	-25.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.8 F	
02/16/25 09:00	0.0 FID	0.001 FI	-26.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	21.0 F	199.8 F	
02/16/25 10:00	0.0 FID	0.001 FI	-26.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	21.0 F	199.8 F	
02/16/25 11:00	0.0 FID	0.001 FI	-25.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.7 F	
02/16/25 12:00	0.0 FID	0.001 FI	-26.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	21.0 F	199.7 F	
02/16/25 13:00	0.0 FID	0.001 FI	-25.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	21.0 F	199.7 F	
02/16/25 14:00	0.0 FID	0.001 FI	-27.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	21.0 F	199.7 F	
02/16/25 15:00	0.0 FID	0.001 FI	-26.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.7 F	
02/16/25 16:00	0.0 FID	0.001 FI	-23.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.7 F	
02/16/25 17:00	0.0 FID	0.001 FI	-25.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.7 F	
02/16/25 18:00	0.0 FID	0.001 FI	-25.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.7 F	
02/16/25 19:00	0.0 FID	0.001 FI	-26.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	21.0 F	199.8 F	
02/16/25 20:00	0.0 FID	0.001 FI	-27.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	21.0 F	199.7 F	
02/16/25 21:00	34.3 U	0.081 E	36.1 E	0.0	0.0	0.0	55.3 EU	0.085 E	23.2 E	16.2	199.8	UNIT START UP
02/16/25 22:00	16.4 U	0.020	8.8	0.0	0.0	0.0	13.2 U	0.016	4.3	15.1	199.7	
02/16/25 23:00	17.2	0.021	9.2	0.0	0.0	0.0	13.1	0.016	4.3	15.1	199.7	
02/17/25 00:00	16.9	0.020	9.0	0.0	0.0	0.0	13.1	0.015	4.3	15.0	199.7	
02/17/25 01:00	18.5	0.022	9.9	0.0	0.0	0.0	13.1	0.016	4.3	15.0	199.7	
02/17/25 02:00	19.1	0.023	10.2	0.0	0.0	0.0	13.3	0.016	4.3	14.9	199.7	
02/17/25 03:00	19.1 D	0.023	10.2	0.0	0.0	0.0	13.4 D	0.016	4.3	14.9	199.7	
02/17/25 04:00	19.8 D	0.026	11.7	0.0	0.0	0.0	13.3 D	0.016	4.3	14.9	199.7	UNIT SHUTDOWN
02/17/25 05:00	40.6 U	0.095 E	41.9 E	0.0	0.0	0.0	37.9 EU	0.058 E	15.6 E	16.1	199.7	UNIT START UP
02/17/25 06:00	14.7 UD	0.017	7.4	0.0	0.0	0.0	13.9 UD	0.016	4.3	14.9	199.7	
02/17/25 07:00	89.6 ECD	0.264 E	117.3 E	0.0	0.0	0.0 C	32.6 ECD	0.087 E	23.5 E	16.6 C	199.7	UNIT SHUTDOWN
02/17/25 08:00	0.0 FID	0.001 FI	-20.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.7 F	
02/17/25 09:00	0.0 FID	0.001 FI	-19.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F	
02/17/25 10:00	0.0 FID	0.001 FI	-18.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F	
02/17/25 11:00	0.0 FID	0.001 FI	-18.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.7 F	
02/17/25 12:00	0.0 FID	0.001 FI	-17.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.7 F	

Source Parameter Unit		UNIT_A											
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)	
02/17/25	13:00	48.8 U	0.106 E	46.6 E	0.0	0.0	0.0	59.8 EU	0.105 E	28.3 E	16.3	199.7	UNIT START UP *SEE DEVIATION REPORT CC-2267 Rev.1 & VARIANCE REPORT CC-2270 Rev.1 Sec 6
02/17/25	14:00	5.6 U	0.006	2.7	0.0	0.0	0.0	15.8 U	0.017	4.6	14.8	199.7	
02/17/25	15:00	1.3	0.001	0.7	0.0	0.0	0.0	24.6 E	0.026 E	7.1 E	14.7	199.7	
02/17/25	16:00	2.7	0.003	1.3	0.0	0.0	0.0	14.5	0.016	4.2	14.8	199.7	
02/17/25	17:00	1.6	0.002	0.7	0.0	0.0	0.0	18.4 E	0.020 E	5.3 E	14.8	199.7	
02/17/25	18:00	4.6	0.005	2.2	0.0	0.0	0.0	14.8	0.016	4.2	14.8	199.7	
02/17/25	19:00	7.9	0.009	3.8	0.0	0.0	0.0	14.1	0.016	4.2	14.9	199.7	
02/17/25	20:00	9.1	0.010	4.3	0.0	0.0	0.0	14.9	0.016	4.3	14.8	199.7	
02/17/25	21:00	10.3	0.012	5.4	0.0	0.0	0.0	13.8	0.016	4.4	14.9	199.7	
02/17/25	22:00	27.2 D	0.039	17.2	0.0	0.0	0.0	11.8 D	0.016	4.4	14.9	199.7	
02/17/25	23:00	60.2 ED	0.265 E	118.6 E	0.0	0.0	0.0	62.4 ED	0.183 E	49.8 E	17.5	199.7	UNIT SHUTDOWN
02/18/25	00:00	0.0 FID	0.001 FI	-18.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.7 F	
02/18/25	01:00	0.0 FID	0.001 FI	-18.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.5 FI	21.0 F	199.7 F	
02/18/25	02:00	0.0 FID	0.001 FI	-18.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F	
02/18/25	03:00	0.0 FID	0.001 FI	-17.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F	
02/18/25	04:00	0.0 FID	0.001 FI	-19.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.7 F	
02/18/25	05:00	0.0 FID	0.001 FI	-18.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.7 F	
02/18/25	06:00	0.0 FID	0.001 FI	-17.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.7 F	
02/18/25	07:00	0.0 FIC	0.015 FI	6.6 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.024 F	6.4 F	14.3 FC	199.7 F	
02/18/25	08:00	0.0 FID	0.001 FI	-29.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	21.0 F	199.7 F	
02/18/25	09:00	0.0 FID	0.001 FI	-26.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	21.0 F	199.7 F	
02/18/25	10:00	0.0 FID	0.001 FI	-27.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	21.0 F	199.7 F	
02/18/25	11:00	0.0 FID	0.001 FI	-28.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	21.0 F	199.7 F	
02/18/25	12:00	0.0 FID	0.001 FI	-27.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	21.0 F	199.7 F	
02/18/25	13:00	41.0 U	0.091 E	40.2 E	0.0	0.0	0.0	67.8 EU	0.113 E	30.3 E	16.2	199.7	UNIT START UP
02/18/25	14:00	3.2 U	0.003	1.6	0.0	0.0	0.0	14.9 U	0.016	4.3	14.8	199.7	*SEE DEVIATION REPORT CC-2268 Rev.1 & VARIANCE REPORT CC-2270 Rev.1 Sec 6
02/18/25	15:00	23.0	0.029	12.9	0.0	0.0	0.0	15.2	0.018 E	4.9	15.0	199.7	
02/18/25	16:00	19.9 D	0.025	11.0	0.0	0.0	0.0	15.2 D	0.018 E	4.9	15.0	199.7	
02/18/25	17:00	24.7 D	0.063 E	28.1 E	0.0	0.0	0.0	17.1 D	0.029 E	8.0 E	15.4	199.7	
02/18/25	18:00	0.0 FID	0.001 FI	-32.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.5 FI	21.0 F	199.7 F	UNIT SHUTDOWN
02/18/25	19:00	0.0 FID	0.001 FI	-32.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	21.0 F	199.7 F	
02/18/25	20:00	0.0 FID	0.001 FI	-29.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.9 FI	21.0 F	199.7 F	
02/18/25	21:00	0.0 FID	0.001 FI	-28.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.0 FI	21.0 F	199.7 F	
02/18/25	22:00	54.7 U	0.349 E	156.9 E	0.0	0.0	0.0	10.3 U	0.072 E	19.6 E	17.6	199.7	
02/18/25	23:00	26.2 U	0.032	14.4	0.0	0.0	0.0	39.9 EU	0.051 E	13.7 E	15.1	199.8	UNIT START UP
02/19/25	00:00	20.3	0.026	11.6	0.0	0.0	0.0	13.2	0.017	4.5	15.0	199.7	
02/19/25	01:00	23.3	0.030	13.5	0.0	0.0	0.0	12.9	0.017	4.6	15.0	199.7	

Source Parameter Unit		UNIT_A											
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)	
02/19/25	02:00	46.6 U	0.086 E	38.7 E	0.0	0.0	0.0	47.3 EU	0.068 E	18.6 E	15.8	199.7	UNIT SHUTDOWN\UNIT START UP UNIT SHUTDOWN\UNIT START UP
02/19/25	03:00	36.7 U	0.092 E	41.1 E	0.0	0.0	0.0	17.1 U	0.033 E	9.2 E	16.0	199.7	
02/19/25	04:00	17.9 U	0.021	9.4	0.0	0.0	0.0	27.2 EU	0.034 E	9.3 E	14.9	199.8	
02/19/25	05:00	7.8	0.009	3.9	0.0	0.0	0.0	14.1	0.016	4.3	14.8	199.8	UNIT SHUTDOWN 
02/19/25	06:00	7.8 D	0.009	4.0	0.0	0.0	0.0	14.3 D	0.016	4.4	14.9	199.7	
02/19/25	07:00	2.8 ICD	0.012	5.5	0.0	0.0	0.0 C	3.9 ICD	0.017	4.5	14.9 C	199.7	
02/19/25	08:00	0.0 FID	0.001 FI	-81.1 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	20.9 F	199.7 F	
02/19/25	09:00	0.0 FID	0.001 FI	-88.5 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	20.9 F	199.7 F	
02/19/25	10:00	0.0 FID	0.001 FI	-80.1 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	20.9 F	199.7 F	
02/19/25	11:00	0.0 FID	0.001 FI	-84.1 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	20.9 F	199.7 F	
02/19/25	12:00	0.0 FID	0.001 FI	-79.2 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	20.9 F	199.7 F	
02/19/25	13:00	0.2 FID	0.001 FI	-88.5 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	20.9 F	199.7 F	
02/19/25	14:00	0.0 FID	0.001 FI	-67.1 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	20.9 F	199.7 F	
02/19/25	15:00	0.0 FID	0.001 FI	-66.1 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	-0.2 FI	20.9 F	199.7 F	
02/19/25	16:00	0.0 FID	0.001 FI	-69.2 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	-0.1 FI	20.9 F	199.7 F	
02/19/25	17:00	0.0 FID	0.001 FI	-65.7 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	20.9 F	199.7 F	
02/19/25	18:00	0.0 FID	0.001 FI	-85.6 FI	0.0 F	0.0 F	0.0 FI	0.6 FID	0.001 FI	0.0 FI	20.9 F	199.7 F	
02/19/25	19:00	0.0 FID	0.001 FI	-72.4 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	20.9 F	199.7 F	
02/19/25	20:00	0.0 FID	0.001 FI	-73.2 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	20.9 F	199.8 F	
02/19/25	21:00	0.0 FID	0.001 FI	-93.0 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	20.9 F	199.8 F	
02/19/25	22:00	0.1 FID	0.001 FI	-104.0 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	20.9 F	199.7 F	
02/19/25	23:00	0.0 FID	0.001 FI	-66.8 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	20.9 F	199.7 F	
02/20/25	00:00	49.5 U	0.313 E	140.7 E	0.0	0.0	0.0	9.9 U	0.068 E	18.7 E	17.6	199.7	UNIT START UP *SEE DEVIATION REPORT CC-2271 Rev.1 & VARIANCE REPORT CC-2270 Rev.1 Sec 6
02/20/25	01:00	26.5 U	0.035	15.9	0.0	0.0	0.0	43.2 EU	0.059 E	16.2 E	15.3	199.8	
02/20/25	02:00	10.9	0.014	6.1	0.0	0.0	0.0	23.2 E	0.028 E	7.7 E	15.0	199.7	
02/20/25	03:00	19.6	0.026	11.5	0.0	0.0	0.0	21.2 E	0.028 E	7.6 E	15.2	199.7	
02/20/25	04:00	21.4	0.028	12.5	0.0	0.0	0.0	21.2 E	0.028 E	7.6 E	15.2	199.8	
02/20/25	05:00	4.2	0.005	2.2	0.0	0.0	0.0	25.0 E	0.029 E	7.9 E	14.8	199.7	UNIT SHUTDOWN 
02/20/25	06:00	7.9 D	0.010	4.3	0.0	0.0	0.0	24.7 ED	0.029 E	7.9 E	14.9	199.7	
02/20/25	07:00	79.2 ECD	0.260 E	115.3 E	0.0	0.0	0.0 C	41.3 ECD	0.115 E	31.0 E	16.8 C	199.7	
02/20/25	08:00	0.0 FID	0.001 FI	-19.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.7 F	
02/20/25	09:00	0.0 FID	0.001 FI	-17.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F	
02/20/25	10:00	0.0 FID	0.001 FI	-15.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.4 FI	21.0 F	199.7 F	
02/20/25	11:00	0.0 FID	0.001 FI	-16.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.9 FI	21.0 F	199.7 F	
02/20/25	12:00	0.0 FID	0.001 FI	-16.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.7 F	
02/20/25	13:00	44.3 U	0.091 E	40.8 E	0.0	0.0	0.0	67.4 EU	0.110 E	29.8 E	16.1	199.7	UNIT START UP
02/20/25	14:00	3.1 U	0.003	1.6	0.0	0.0	0.0	15.4 U	0.017	4.5	14.8	199.7	

Source	Parameter Unit	UNIT_A										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/20/25	15:00	21.8	0.029	12.6	0.0	0.0	0.0	12.7	0.016	4.4	15.3	199.7
02/20/25	16:00	24.4	0.034	15.2	0.0	0.0	0.0	12.7	0.016	4.5	15.1	199.7
02/20/25	17:00	32.0	0.039	17.6	0.0	0.0	0.0	15.5	0.019 E	5.1 E	15.1	199.7
02/20/25	18:00	59.1 EU	0.087 E	39.0 E	0.0	0.0	0.0	45.4 EU	0.057 E	15.5 E	15.7	199.7
02/20/25	19:00	27.7 UD	0.076 E	33.8 E	0.0	0.0	0.0	20.7 EUD	0.036 E	9.8 E	15.9	199.7
02/20/25	20:00	25.1 UD	0.031	13.9	0.0	0.0	0.0	44.6 EUD	0.063 E	17.0 E	15.1	199.8
02/20/25	21:00	66.8 ED	0.210 E	94.3 E	0.0	0.0	0.0	34.1 ED	0.082 E	22.4 E	16.7	199.7
02/20/25	22:00	0.0 FID	0.001 FI	-19.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.8 F
02/20/25	23:00	0.0 FID	0.001 FI	-16.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
02/21/25	00:00	0.0 FID	0.001 FI	-15.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.7 F
02/21/25	01:00	0.0 FID	0.001 FI	-15.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
02/21/25	02:00	0.0 FID	0.001 FI	-16.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
02/21/25	03:00	0.0 FID	0.001 FI	-16.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
02/21/25	04:00	0.0 FID	0.001 FI	-14.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
02/21/25	05:00	0.0 FID	0.001 FI	-15.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
02/21/25	06:00	0.0 FID	0.001 FI	-16.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.7 F
02/21/25	07:00	0.0 FIC	0.015 FI	6.6 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.4 F	14.2 FC	199.7 F
02/21/25	08:00	0.0 FID	0.001 FID	-47.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.7 F
02/21/25	09:00	0.0 FID	0.001 FID	-55.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	21.0 F	199.7 F
02/21/25	10:00	0.1 FID	0.001 FI	-49.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.7 F
02/21/25	11:00	3.9 FID	0.001 FI	-51.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.7 F
02/21/25	12:00	0.0 FID	0.001 FI	-50.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	21.0 F	199.7 F
02/21/25	13:00	0.0 FID	0.001 FI	-57.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.9 FI	21.0 F	199.7 F
02/21/25	14:00	2.2 FID	0.001 FI	-120.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.7 F
02/21/25	15:00	0.0 FID	0.001 FI	-116.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.9 FI	21.0 F	199.7 F
02/21/25	16:00	0.0 FID	0.001 FI	-138.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.2 FI	21.0 F	199.7 F
02/21/25	17:00	0.2 FID	0.001 FI	-53.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	21.0 F	199.7 F
02/21/25	18:00	0.0 FID	0.001 FI	-52.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.7 F
02/21/25	19:00	3.4 FID	0.001 FI	-571.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-7.0 FI	20.9 F	199.7 F
02/21/25	20:00	0.0 FID	0.001 FI	-50.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.7 F
02/21/25	21:00	0.0 FID	0.001 FI	-46.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.7 F
02/21/25	22:00	0.0 FID	0.001 FI	-48.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.7 F
02/21/25	23:00	0.0 FID	0.001 FI	-50.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.8 F
02/22/25	00:00	0.0 FID	0.001 FI	-45.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	21.0 F	199.8 F
02/22/25	01:00	0.0 FID	0.001 FI	-42.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.7 F
02/22/25	02:00	0.0 FID	0.001 FI	-54.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	21.0 F	199.7 F
02/22/25	03:00	0.0 FID	0.001 FI	-45.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.8 F

UNIT SHUTDOWN\UNIT START UP

UNIT SHUTDOWN\UNIT START UP

UNIT SHUTDOWN

Source	Parameter Unit	UNIT_A										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/22/25	04:00	0.0 FID	0.001 FI	-45.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.8 F
02/22/25	05:00	0.0 FID	0.001 FI	-43.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.7 F
02/22/25	06:00	0.0 FID	0.001 FI	-50.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.7 F
02/22/25	07:00	0.0 FIC	0.015 FI	6.7 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.3 FC	199.8 F
02/22/25	08:00	0.0 FID	0.001 FID	-109.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.1 FI	21.0 F	199.7 F
02/22/25	09:00	0.0 FID	0.001 FID	-94.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.5 FI	21.0 F	199.7 F
02/22/25	10:00	2.0 FID	0.001 FI	-73.6 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-2.8 FI	21.0 F	199.7 F
02/22/25	11:00	0.1 FID	0.001 FI	-71.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.0 FI	21.0 F	199.7 F
02/22/25	12:00	0.3 FID	0.001 FI	-54.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	21.0 F	199.7 F
02/22/25	13:00	13.7 FID	0.001 FI	-100.4 FI	0.0 F	0.0 F	0.0 FI	0.6 FID	0.001 FI	-2.8 FI	21.0 F	199.7 F
02/22/25	14:00	1.4 FID	0.001 FI	-124.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-3.5 FI	21.0 F	199.7 F
02/22/25	15:00	0.0 FID	0.001 FI	-34.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.7 F
02/22/25	16:00	0.0 FID	0.001 FI	-26.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.7 F
02/22/25	17:00	0.0 FID	0.001 FI	-29.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.7 F
02/22/25	18:00	0.0 FID	0.001 FI	-26.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.7 F
02/22/25	19:00	0.0 FID	0.001 FI	-28.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.7 F
02/22/25	20:00	1.8 FID	0.001 FI	-28.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.7 F
02/22/25	21:00	0.0 FID	0.001 FI	-30.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.7 F
02/22/25	22:00	0.0 FID	0.001 FI	-27.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.7 F
02/22/25	23:00	0.0 FID	0.001 FI	-30.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.8 F
02/23/25	00:00	0.0 FID	0.001 FI	-28.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.8 F
02/23/25	01:00	0.0 FID	0.001 FI	-29.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.7 F
02/23/25	02:00	0.0 FID	0.001 FI	-28.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.7 F
02/23/25	03:00	0.0 FID	0.001 FI	-26.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.7 F
02/23/25	04:00	0.0 FID	0.001 FI	-29.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.7 F
02/23/25	05:00	0.0 FID	0.001 FI	-28.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.7 F
02/23/25	06:00	0.0 FID	0.001 FI	-29.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.7 F
02/23/25	07:00	0.0 FIC	0.015 FI	6.6 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.024 F	6.4 F	14.3 FC	199.7 F
02/23/25	08:00	0.0 FID	0.001 FID	-33.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.5 FI	21.0 F	199.7 F
02/23/25	09:00	0.0 FID	0.001 FID	-28.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.0 FI	21.0 F	199.7 F
02/23/25	10:00	0.0 FID	0.001 FI	-29.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.7 FI	21.0 F	199.7 F
02/23/25	11:00	0.1 FID	0.001 FI	-28.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.1 FI	21.0 F	199.7 F
02/23/25	12:00	0.1 FID	0.001 FI	-29.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.4 FI	21.0 F	199.7 F
02/23/25	13:00	0.0 FID	0.001 FI	-31.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.1 FI	21.0 F	199.7 F
02/23/25	14:00	0.0 FID	0.001 FI	-31.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.3 FI	21.0 F	199.7 F
02/23/25	15:00	0.0 FID	0.001 FI	-29.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.0 FI	21.0 F	199.7 F
02/23/25	16:00	0.0 FID	0.001 FI	-28.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.9 FI	21.0 F	199.7 F

Source Parameter Unit	UNIT_A										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/23/25 17:00	0.0 FID	0.001 FI	-28.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.9 FI	21.0 F	199.7 F
02/23/25 18:00	0.0 FID	0.001 FI	-28.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.8 FI	21.0 F	199.7 F
02/23/25 19:00	0.0 FID	0.001 FI	-30.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.4 FI	21.0 F	199.7 F
02/23/25 20:00	4.0 FID	0.001 FI	-28.7 FI	0.0 F	0.0 F	0.0 FI	0.7 FID	0.001 FI	-3.2 FI	21.0 F	199.7 F
02/23/25 21:00	4.4 FID	0.001 FI	-28.7 FI	0.0 F	0.0 F	0.0 FI	0.6 FID	0.001 FI	-2.8 FI	21.0 F	199.7 F
02/23/25 22:00	0.0 FID	0.001 FI	-29.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.4 FI	21.0 F	199.7 F
02/23/25 23:00	0.0 FID	0.001 FI	-29.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.1 FI	21.0 F	199.7 F
02/24/25 00:00	0.0 FID	0.001 FI	-31.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.2 FI	21.0 F	199.7 F
02/24/25 01:00	0.0 FID	0.001 FI	-30.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.7 FI	21.0 F	199.7 F
02/24/25 02:00	0.0 FID	0.001 FI	-31.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.3 FI	21.0 F	199.7 F
02/24/25 03:00	0.0 FID	0.001 FI	-27.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.0 FI	21.0 F	199.7 F
02/24/25 04:00	0.0 FID	0.001 FI	-28.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.8 FI	21.0 F	199.7 F
02/24/25 05:00	0.0 FID	0.001 FI	-28.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.9 FI	21.0 F	199.7 F
02/24/25 06:00	0.0 FID	0.001 FI	-27.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.9 FI	21.0 F	199.7 F
02/24/25 07:00	0.0 FIC	0.015 FI	6.6 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.4 F	14.2 FC	199.7 F
02/24/25 08:00	1.8 FID	0.001 FID	148.9 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	6.4 FIE	20.9 F	199.7 F
02/24/25 09:00	6.1 FID	0.001 FID	199.1 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	5.9 FIE	20.9 F	199.7 F
02/24/25 10:00	0.1 FID	0.001 FI	342.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.3 FIE	20.9 F	199.7 F
02/24/25 11:00	0.7 FID	0.001 FI	297.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	9.3 FIE	20.9 F	199.7 F
02/24/25 12:00	0.0 FID	0.001 FI	144.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.8 FIE	20.9 F	199.7 F
02/24/25 13:00	0.0 FID	0.001 FI	244.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	8.6 FIE	20.9 F	199.7 F
02/24/25 14:00	0.0 FID	0.001 FI	348.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.7 FI	20.9 F	199.7 F
02/24/25 15:00	0.0 FID	0.001 FI	360.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.3 FIE	20.9 F	199.7 F
02/24/25 16:00	0.0 FID	0.001 FI	304.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	7.4 FIE	20.9 F	199.7 F
02/24/25 17:00	0.0 FID	0.001 FI	86.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.7 FI	20.9 F	199.7 F
02/24/25 18:00	0.0 FID	0.001 FI	99.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.2 FI	20.9 F	199.7 F
02/24/25 19:00	0.0 FID	0.001 FI	77.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.7 FI	20.9 F	199.7 F
02/24/25 20:00	2.4 FID	0.001 FI	69.5 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	3.1 FI	20.9 F	199.7 F
02/24/25 21:00	0.0 FID	0.001 FI	80.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.9 FI	20.9 F	199.7 F
02/24/25 22:00	0.0 FID	0.001 FI	75.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.2 FI	20.9 F	199.7 F
02/24/25 23:00	0.0 FID	0.001 FI	70.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.7 FI	20.9 F	199.7 F
02/25/25 00:00	0.0 FID	0.001 FI	84.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.1 FI	20.9 F	199.7 F
02/25/25 01:00	0.0 FID	0.001 FI	76.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.0 FI	20.9 F	199.7 F
02/25/25 02:00	0.0 FID	0.001 FI	75.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.5 FI	20.9 F	199.7 F
02/25/25 03:00	0.0 FID	0.001 FI	80.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.7 FI	20.9 F	199.7 F
02/25/25 04:00	0.0 FID	0.001 FI	71.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.1 FI	20.9 F	199.7 F
02/25/25 05:00	0.0 FID	0.001 FI	61.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.2 FI	20.9 F	199.7 F

Source Parameter Unit	UNIT_A										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/25/25 06:00	0.0 FID	0.001 FI	71.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.5 FI	20.9 F	199.7 F
02/25/25 07:00	0.0 FIC	0.015 FI	6.5 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.7 F
02/25/25 08:00	0.0 FID	0.001 FID	-53.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.6 FI	20.9 F	199.7 F
02/25/25 09:00	0.0 FID	0.001 FID	-54.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.7 FI	20.9 F	199.7 F
02/25/25 10:00	0.0 FID	0.001 FI	-101.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.9 FI	20.9 F	199.7 F
02/25/25 11:00	3.7 FID	0.001 FI	-104.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-2.6 FI	21.0 F	199.7 F
02/25/25 12:00	51.2 FID	0.001 FI	-58.7 FI	0.0 F	0.0 F	0.0 FI	1.7 FID	0.001 FI	-3.1 FI	21.0 F	199.7 F
02/25/25 13:00	20.4 UD	0.214 E	94.3 E	0.0	0.0	0.0	9.6 UD	0.088 E	18.3 E	17.7	199.7
02/25/25 14:00	0.0 FIU	0.001 FI	-63.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-3.9 FI	21.0 F	199.7 F
02/25/25 15:00	0.0 FIU	0.001 FI	-51.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-3.1 FI	21.0 F	199.7 F
02/25/25 16:00	0.0 FIU	0.001 FI	-53.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-2.4 FI	21.0 F	199.7 F
02/25/25 17:00	0.0 FIU	0.001 FI	-47.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-3.0 FI	21.0 F	199.7 F
02/25/25 18:00	0.0 FIU	0.001 FI	-46.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-2.3 FI	21.0 F	199.7 F
02/25/25 19:00	0.0 FIU	0.001 FI	-54.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-2.6 FI	20.9 F	199.7 F
02/25/25 20:00	0.0 FIU	0.001 FI	-45.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-2.9 FI	21.0 F	199.7 F
02/25/25 21:00	48.7 U	0.087 E	38.8 E	0.0	0.0	0.0	63.1 EU	0.105 E	28.4 E	16.0	199.7
02/25/25 22:00	28.7 UD	0.037	16.6	0.0	0.0	0.0	12.3 UD	0.016	4.3	15.2	199.7
02/25/25 23:00	46.5 D	0.062 E	27.7 E	0.0	0.0	0.0	13.3 D	0.018	4.7	15.2	199.7
02/26/25 00:00	0.0 FID	0.001 FI	-51.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.1 FI	21.0 F	199.7 F
02/26/25 01:00	0.0 FID	0.001 FI	-52.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.2 FI	21.0 F	199.7 F
02/26/25 02:00	0.0 FID	0.001 FI	-47.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.1 FI	21.0 F	199.8 F
02/26/25 03:00	0.0 FID	0.001 FI	-51.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.4 FI	21.0 F	199.7 F
02/26/25 04:00	0.0 FID	0.001 FI	-51.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.9 FI	21.0 F	199.7 F
02/26/25 05:00	0.0 FID	0.001 FI	-50.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.2 FI	21.0 F	199.7 F
02/26/25 06:00	0.0 FID	0.001 FI	-47.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.2 FI	21.0 F	199.7 F
02/26/25 07:00	0.0 FIC	0.015 FI	6.6 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.3 FC	199.7 F
02/26/25 08:00	0.0 FID	0.001 FID	-34.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.7 F
02/26/25 09:00	0.0 FID	0.001 FID	-35.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.7 F
02/26/25 10:00	0.0 FID	0.001 FI	-34.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.7 F
02/26/25 11:00	0.0 FID	0.001 FI	-34.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.7 F
02/26/25 12:00	0.0 FID	0.001 FI	-34.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.7 F
02/26/25 13:00	0.0 FID	0.001 FI	-34.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.7 F
02/26/25 14:00	0.0 FID	0.001 FI	-35.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.7 F
02/26/25 15:00	0.0 FID	0.001 FI	-33.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.7 F
02/26/25 16:00	0.0 FID	0.001 FI	-34.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.7 F
02/26/25 17:00	0.0 FID	0.001 FI	-34.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.7 F
02/26/25 18:00	0.0 FID	0.001 FI	-37.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.7 F

FULL SPEED NO LOAD

UNIT START UP

UNIT SHUTDOWN

Source		UNIT_A										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/26/25	19:00	0.0 FID	0.001 FI	-36.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.9 FI	21.0 F	199.7 F
02/26/25	20:00	0.0 FID	0.001 FI	-33.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.7 F
02/26/25	21:00	0.0 FID	0.001 FI	-38.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.3 FI	21.0 F	199.7 F
02/26/25	22:00	0.0 FID	0.001 FI	-35.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.3 FI	21.0 F	199.7 F
02/26/25	23:00	0.0 FID	0.001 FI	-34.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.1 FI	21.0 F	199.7 F
02/27/25	00:00	0.0 FID	0.001 FI	-35.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.7 F
02/27/25	01:00	0.0 FID	0.001 FI	-38.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.7 F
02/27/25	02:00	0.0 FID	0.001 FI	-35.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.0 FI	21.0 F	199.7 F
02/27/25	03:00	0.0 FID	0.001 FI	-39.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.9 FI	21.0 F	199.7 F
02/27/25	04:00	0.0 FID	0.001 FI	-42.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.7 F
02/27/25	05:00	0.0 FID	0.001 FI	-36.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.7 F
02/27/25	06:00	0.0 FID	0.001 FI	-38.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.0 FI	21.0 F	199.8 F
02/27/25	07:00	0.0 FIC	0.015 FI	6.6 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.4 F	14.2 FC	199.7 F
02/27/25	08:00	0.0 FID	0.001 FID	-46.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.9 FI	21.0 F	199.7 F
02/27/25	09:00	0.0 FID	0.001 FID	-54.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.7 FI	21.0 F	199.7 F
02/27/25	10:00	0.0 FID	0.001 FI	-49.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.2 FI	21.0 F	199.7 F
02/27/25	11:00	0.0 FID	0.001 FI	-49.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.6 FI	21.0 F	199.7 F
02/27/25	12:00	0.0 FID	0.001 FI	-44.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.2 FI	21.0 F	199.7 F
02/27/25	13:00	0.0 FID	0.001 FI	-48.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.2 FI	21.0 F	199.8 F
02/27/25	14:00	0.0 FID	0.001 FI	-46.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.8 FI	21.0 F	199.7 F
02/27/25	15:00	0.0 FID	0.001 FI	-44.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.8 FI	21.0 F	199.7 F
02/27/25	16:00	0.0 FID	0.001 FI	-49.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.0 FI	21.0 F	199.7 F
02/27/25	17:00	0.0 FID	0.001 FI	-40.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.6 FI	21.0 F	199.8 F
02/27/25	18:00	0.0 FID	0.001 FI	-38.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.8 FI	21.0 F	199.8 F
02/27/25	19:00	0.0 FID	0.001 FI	-43.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.3 FI	21.0 F	199.8 F
02/27/25	20:00	0.0 FID	0.001 FI	-37.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.4 FI	21.0 F	199.8 F
02/27/25	21:00	0.0 FID	0.001 FI	-25.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.0 FI	21.0 F	199.8 F
02/27/25	22:00	0.0 FID	0.001 FI	-23.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.8 F
02/27/25	23:00	0.0 FID	0.001 FI	-31.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.1 FI	21.0 F	199.8 F
02/28/25	00:00	0.0 FID	0.001 FI	-20.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.8 F
02/28/25	01:00	0.0 FID	0.001 FI	-17.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.1 F	199.8 F
02/28/25	02:00	0.0 FID	0.001 FI	-18.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	21.1 F	199.8 F
02/28/25	03:00	0.0 FID	0.001 FI	-18.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.1 F	199.8 F
02/28/25	04:00	0.0 FID	0.001 FI	-19.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.8 F
02/28/25	05:00	0.0 FID	0.001 FI	-18.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.1 F	199.8 F
02/28/25	06:00	0.0 FID	0.001 FI	-20.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	21.0 F	199.8 F
02/28/25	07:00	0.0 FIC	0.015 FI	6.6 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.024 F	6.4 F	14.3 FC	199.7 F

Source		UNIT_A										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/28/25	08:00	0.0 FID	0.001 FI	60.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.2 FI	20.9 F	199.7 F
02/28/25	09:00	0.0 FID	0.053 FI	33.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.9 FI	20.8 F	199.7 F
02/28/25	10:00	0.0 FID	0.053 FI	24.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.8 F	199.7 F
02/28/25	11:00	0.0 FID	0.053 FI	23.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.8 F	199.7 F
02/28/25	12:00	0.0 FID	0.053 FI	24.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.8 F	199.7 F
02/28/25	13:00	0.0 FID	0.053 FI	22.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.8 F	199.7 F
02/28/25	14:00	0.0 FID	0.053 FI	23.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.8 F	199.7 F
02/28/25	15:00	0.0 FID	0.053 FI	23.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.5 FI	20.8 F	199.7 F
02/28/25	16:00	0.0 FID	0.053 FI	25.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.8 F	199.7 F
02/28/25	17:00	0.0 FID	0.053 FI	31.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.7 FI	20.8 F	199.7 F
02/28/25	18:00	0.0 FID	0.053 FI	30.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.8 FI	20.8 F	199.7 F
02/28/25	19:00	0.0 FID	0.053 FI	33.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.6 FI	20.8 F	199.7 F
02/28/25	20:00	0.0 FID	0.053 FI	34.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.3 FI	20.8 F	199.7 F
02/28/25	21:00	0.0 FID	0.053 FI	36.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.2 FI	20.8 F	199.7 F
02/28/25	22:00	0.0 FID	0.053 FI	36.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.0 FI	20.8 F	199.7 F
02/28/25	23:00	0.0 FID	0.053 FI	21.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.8 F	199.7 F
03/01/25	00:00	0.0 FID	0.001 FI	47.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.8 FI	20.9 F	199.7 F
03/01/25	01:00	0.0 FID	0.053 FI	45.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.5 FI	20.8 F	199.7 F
03/01/25	02:00	0.0 FID	0.053 FI	44.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.7 FI	20.8 F	199.7 F
03/01/25	03:00	0.0 FID	0.053 FI	43.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.6 FI	20.8 F	199.7 F
03/01/25	04:00	0.0 FID	0.053 FI	40.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.0 FI	20.8 F	199.7 F
03/01/25	05:00	0.0 FID	0.053 FI	47.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.3 FI	20.8 F	199.7 F
03/01/25	06:00	0.0 FID	0.053 FI	38.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.9 FI	20.8 F	199.7 F
03/01/25	07:00	0.0 FIC	0.014 FI	6.4 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.7 F
03/01/25	08:00	0.0 FID	0.053 FID	46.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.1 FI	20.8 F	199.7 F
03/01/25	09:00	0.0 FID	0.053 FID	31.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.9 FI	20.8 F	199.7 F
03/01/25	10:00	0.0 FID	0.053 FI	27.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.0 FI	20.8 F	199.7 F
03/01/25	11:00	0.0 FID	0.053 FI	27.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.2 FI	20.8 F	199.7 F
03/01/25	12:00	0.0 FID	0.053 FI	35.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.2 FI	20.8 F	199.7 F
03/01/25	13:00	0.0 FID	0.053 FI	38.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.2 FI	20.8 F	199.7 F
03/01/25	14:00	0.0 FID	0.001 FI	73.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.8 FI	20.9 F	199.7 F
03/01/25	15:00	0.0 FID	0.001 FI	45.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.9 FI	20.9 F	199.7 F
03/01/25	16:00	0.0 FID	0.001 FI	74.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.8 FI	20.9 F	199.7 F
03/01/25	17:00	0.0 FID	0.001 FI	160.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	8.8 FIE	20.9 F	199.7 F
03/01/25	18:00	0.0 FID	0.001 FI	71.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.3 FI	20.9 F	199.7 F
03/01/25	19:00	0.0 FID	0.001 FI	65.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.8 FI	20.9 F	199.7 F
03/01/25	20:00	0.0 FID	0.001 FI	62.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.4 FI	20.9 F	199.7 F

Source		UNIT_A										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/01/25	21:00	0.0 FID	0.053 FI	42.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.2 FI	20.8 F	199.7 F
03/01/25	22:00	0.0 FID	0.053 FI	40.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.9 FI	20.8 F	199.7 F
03/01/25	23:00	0.0 FID	0.053 FI	39.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.9 FI	20.8 F	199.7 F
03/02/25	00:00	0.0 FID	0.053 FI	27.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.9 FI	20.8 F	199.7 F
03/02/25	01:00	0.0 FID	0.053 FI	27.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.1 FI	20.8 F	199.7 F
03/02/25	02:00	0.0 FID	0.053 FI	26.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.1 FI	20.8 F	199.7 F
03/02/25	03:00	0.0 FID	0.053 FI	26.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.0 FI	20.8 F	199.7 F
03/02/25	04:00	0.0 FID	0.053 FI	24.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.1 FI	20.8 F	199.7 F
03/02/25	05:00	0.0 FID	0.053 FI	27.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.8 FI	20.8 F	199.7 F
03/02/25	06:00	0.0 FID	0.040 FI	26.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.8 F	199.7 F
03/02/25	07:00	0.0 FIC	0.014 FI	6.5 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.1 FC	199.7 F
03/02/25	08:00	0.0 FID	0.053 FID	30.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.2 FI	20.8 F	199.7 F
03/02/25	09:00	0.0 FID	0.053 FID	29.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.3 FI	20.8 F	199.7 F
03/02/25	10:00	0.0 FID	0.053 FI	28.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.7 FI	20.8 F	199.7 F
03/02/25	11:00	0.0 FID	0.053 FI	31.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.5 FI	20.8 F	199.7 F
03/02/25	12:00	0.0 FID	0.053 FI	29.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.3 FI	20.8 F	199.7 F
03/02/25	13:00	0.0 FID	0.053 FI	27.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.1 FI	20.8 F	199.7 F
03/02/25	14:00	0.0 FID	0.053 FI	30.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.2 FI	20.8 F	199.7 F
03/02/25	15:00	0.0 FID	0.053 FI	30.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.4 FI	20.8 F	199.7 F
03/02/25	16:00	0.0 FID	0.053 FI	28.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.7 FI	20.8 F	199.7 F
03/02/25	17:00	0.0 FID	0.053 FI	30.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.5 FI	20.8 F	199.7 F
03/02/25	18:00	0.0 FID	0.053 FI	29.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.6 FI	20.8 F	199.7 F
03/02/25	19:00	0.0 FID	0.053 FI	30.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.5 FI	20.8 F	199.7 F
03/02/25	20:00	0.0 FID	0.053 FI	39.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.2 FI	20.8 F	199.7 F
03/02/25	21:00	0.0 FID	0.066 FIE	54.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.5 FI	20.8 F	199.7 F
03/02/25	22:00	0.0 FID	0.001 FI	50.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.4 FI	20.9 F	199.7 F
03/02/25	23:00	0.0 FID	0.053 FI	47.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.1 FI	20.8 F	199.7 F
03/03/25	00:00	0.0 FID	0.001 FI	49.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.6 FI	20.9 F	199.7 F
03/03/25	01:00	0.0 FID	0.053 FI	48.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.5 FI	20.8 F	199.7 F
03/03/25	02:00	0.0 FID	0.001 FI	52.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.5 FI	20.9 F	199.7 F
03/03/25	03:00	0.0 FID	0.001 FI	49.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.2 FI	20.9 F	199.7 F
03/03/25	04:00	0.0 FID	0.053 FI	44.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.4 FI	20.8 F	199.7 F
03/03/25	05:00	0.0 FID	0.053 FI	43.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.1 FI	20.8 F	199.7 F
03/03/25	06:00	0.0 FID	0.053 FI	45.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.2 FI	20.8 F	199.7 F
03/03/25	07:00	0.0 FIC	0.015 FI	6.5 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.7 F
03/03/25	08:00	0.0 FID	0.001 FID	65.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.6 FI	20.9 F	199.7 F
03/03/25	09:00	0.0 FID	0.001 FID	64.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.8 FI	20.9 F	199.7 F

Source Parameter Unit		UNIT_A										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/03/25	10:00	0.0 FID	0.053 FI	47.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.7 FI	20.8 F	199.7 F
03/03/25	11:00	0.0 FID	0.053 FI	42.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.6 FI	20.8 F	199.7 F
03/03/25	12:00	0.0 FID	0.053 FI	43.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.6 FI	20.8 F	199.7 F
03/03/25	13:00	0.0 FID	0.053 FI	43.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.0 FI	20.8 F	199.7 F
03/03/25	14:00	0.0 FID	0.053 FI	43.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.8 F	199.7 F
03/03/25	15:00	0.0 FID	0.001 FI	50.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.4 FI	20.9 F	199.7 F
03/03/25	16:00	0.0 FID	0.053 FI	46.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.7 FI	20.8 F	199.7 F
03/03/25	17:00	0.0 FID	0.001 FI	55.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.1 FI	20.9 F	199.7 F
03/03/25	18:00	0.0 FID	0.001 FI	50.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.9 F	199.7 F
03/03/25	19:00	0.0 FID	0.001 FI	50.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.9 F	199.7 F
03/03/25	20:00	0.0 FID	0.001 FI	60.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.6 FI	20.9 F	199.7 F
03/03/25	21:00	0.0 FID	0.001 FI	74.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.7 FI	20.9 F	199.7 F
03/03/25	22:00	0.0 FID	0.001 FI	77.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.9 FI	20.9 F	199.7 F
03/03/25	23:00	0.0 FID	0.001 FI	76.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.9 FI	20.9 F	199.7 F
03/04/25	00:00	0.0 FID	0.001 FI	75.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.6 FI	20.9 F	199.7 F
03/04/25	01:00	0.0 FID	0.001 FI	77.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.4 FI	20.9 F	199.7 F
03/04/25	02:00	0.0 FID	0.001 FI	126.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.9 FI	20.9 F	199.7 F
03/04/25	03:00	0.0 FID	0.001 FI	92.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.9 FI	20.9 F	199.7 F
03/04/25	04:00	0.0 FID	0.001 FI	90.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.8 FI	20.9 F	199.7 F
03/04/25	05:00	0.0 FID	0.001 FI	90.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.2 FI	20.9 F	199.7 F
03/04/25	06:00	0.0 FID	0.001 FI	104.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.9 FI	20.9 F	199.7 F
03/04/25	07:00	0.0 FIC	0.015 FI	6.6 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.024 F	6.5 F	14.2 FC	199.7 F
03/04/25	08:00	0.0 FID	0.053 FID	28.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.5 FI	20.8 F	199.7 F
03/04/25	09:00	0.0 FID	0.053 FID	25.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.0 FI	20.8 F	199.7 F
03/04/25	10:00	0.0 FID	0.053 FI	24.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.5 FI	20.8 F	199.7 F
03/04/25	11:00	0.0 FID	0.053 FI	26.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.8 F	199.7 F
03/04/25	12:00	0.0 FID	0.053 FI	24.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.8 F	199.7 F
03/04/25	13:00	0.0 FID	0.053 FI	24.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.5 FI	20.8 F	199.7 F
03/04/25	14:00	0.0 FID	0.053 FI	23.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.8 F	199.7 F
03/04/25	15:00	0.0 FID	0.053 FI	26.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.8 F	199.7 F
03/04/25	16:00	0.0 FID	0.053 FI	23.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.8 F	199.7 F
03/04/25	17:00	0.0 FID	0.053 FI	26.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.5 FI	20.8 F	199.7 F
03/04/25	18:00	0.0 FID	0.053 FI	23.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.1 FI	20.8 F	199.7 F
03/04/25	19:00	0.0 FID	0.053 FI	22.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.8 F	199.7 F
03/04/25	20:00	0.0 FID	0.053 FI	24.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.5 FI	20.8 F	199.7 F
03/04/25	21:00	0.0 FID	0.053 FI	25.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.8 F	199.7 F
03/04/25	22:00	0.0 FID	0.053 FI	23.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.8 F	199.7 F

Source Parameter Unit		UNIT_A										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/04/25	23:00	0.0 FID	0.053 FI	33.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.5 FI	20.8 F	199.7 F
03/05/25	00:00	0.0 FID	0.053 FI	42.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.8 FI	20.8 F	199.7 F
03/05/25	01:00	0.0 FID	0.053 FI	37.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.1 FI	20.8 F	199.7 F
03/05/25	02:00	0.0 FID	0.053 FI	33.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.6 FI	20.8 F	199.7 F
03/05/25	03:00	0.0 FID	0.053 FI	29.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.5 FI	20.8 F	199.7 F
03/05/25	04:00	0.0 FID	0.053 FI	25.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.8 F	199.7 F
03/05/25	05:00	0.0 FID	0.053 FI	25.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.0 FI	20.8 F	199.7 F
03/05/25	06:00	0.0 FID	0.053 FI	25.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.8 F	199.7 F
03/05/25	07:00	0.0 FIC	0.014 FI	6.4 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.1 FC	199.7 F
03/05/25	08:00	0.0 FID	0.053 FI	37.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.8 F	199.7 F
03/05/25	09:00	0.0 FID	0.053 FID	35.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.8 F	199.7 F
03/05/25	10:00	0.0 FID	0.053 FID	33.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.8 F	199.7 F
03/05/25	11:00	0.0 FID	0.053 FI	36.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.8 F	199.7 F
03/05/25	12:00	0.0 FID	0.053 FI	35.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.8 F	199.7 F
03/05/25	13:00	0.0 FID	0.053 FI	35.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.8 F	199.7 F
03/05/25	14:00	0.0 FID	0.053 FI	35.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.7 F
03/05/25	15:00	0.0 FID	0.053 FI	36.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.8 F	199.7 F
03/05/25	16:00	0.0 FID	0.053 FI	36.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.8 F	199.7 F
03/05/25	17:00	0.0 FID	0.053 FI	33.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.7 F
03/05/25	18:00	0.0 FID	0.053 FI	33.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.8 F	199.7 F
03/05/25	19:00	0.0 FID	0.053 FI	35.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.8 F	199.7 F
03/05/25	20:00	0.0 FID	0.053 FI	35.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.8 F	199.7 F
03/05/25	21:00	0.0 FID	0.053 FI	33.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.8 F	199.8 F
03/05/25	22:00	0.0 FID	0.053 FI	30.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.8 F	199.7 F
03/05/25	23:00	0.0 FID	0.053 FI	32.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.8 F	199.7 F
03/06/25	00:00	0.0 FID	0.066 FIE	39.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.8 F	199.7 F
03/06/25	01:00	0.0 FID	0.053 FID	37.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.8 F	199.7 F
03/06/25	02:00	0.0 FID	0.053 FID	35.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.7 F
03/06/25	03:00	0.0 FID	0.053 FI	34.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.8 F	199.7 F
03/06/25	04:00	0.0 FID	0.053 FI	34.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.8 F	199.7 F
03/06/25	05:00	0.0 FID	0.053 FI	34.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.8 F	199.7 F
03/06/25	06:00	0.0 FID	0.053 FI	33.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.8 F	199.7 F
03/06/25	07:00	0.0 FIC	0.015 FI	6.5 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.7 F
03/06/25	08:00	0.0 FID	0.001 FI	-31.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
03/06/25	09:00	0.0 FID	0.001 FI	-28.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
03/06/25	10:00	0.0 FID	0.001 FI	-32.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
03/06/25	11:00	0.0 FID	0.001 FI	-30.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.7 F

Source		UNIT_A										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/06/25	12:00	0.0 FID	0.001 FI	-33.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
03/06/25	13:00	0.0 FID	0.001 FI	-31.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
03/06/25	14:00	0.0 FID	0.001 FI	-34.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
03/06/25	15:00	0.0 FID	0.001 FI	-33.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
03/06/25	16:00	0.0 FID	0.001 FI	-34.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
03/06/25	17:00	0.0 FID	0.001 FI	-31.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
03/06/25	18:00	0.0 FID	0.001 FI	-31.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/06/25	19:00	0.0 FID	0.001 FI	-32.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
03/06/25	20:00	0.0 FID	0.001 FI	-29.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
03/06/25	21:00	0.0 FID	0.001 FI	-34.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
03/06/25	22:00	0.0 FID	0.001 FI	-29.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/06/25	23:00	0.0 FID	0.001 FI	-24.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
03/07/25	00:00	0.0 FID	0.001 FI	-25.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/07/25	01:00	0.0 FID	0.001 FI	-23.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
03/07/25	02:00	0.0 FID	0.001 FI	-26.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
03/07/25	03:00	0.0 FID	0.001 FI	-29.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
03/07/25	04:00	0.0 FID	0.001 FI	-29.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/07/25	05:00	0.0 FID	0.001 FI	-25.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/07/25	06:00	0.0 FIM	0.001 FI	-29.3 FI	0.0 F	0.0 F	0.0 FIM	0.1 FIM	0.001 FI	0.0 FI	21.0 FM	199.7 F
03/07/25	07:00	0.0 FIC	0.015 FI	6.6 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.4 F	14.2 FC	199.8 F
03/07/25	08:00	0.0 FID	0.040 FID	20.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.3 FI	20.8 F	199.7 F
03/07/25	09:00	0.0 FID	0.040 FID	20.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.0 FI	20.8 F	199.7 F
03/07/25	10:00	0.0 FID	0.040 FI	18.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.2 FI	20.8 F	199.7 F
03/07/25	11:00	0.0 FID	0.040 FI	19.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.5 FI	20.8 F	199.7 F
03/07/25	12:00	0.0 FID	0.040 FI	19.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.3 FI	20.8 F	199.7 F
03/07/25	13:00	0.0 FID	0.040 FI	17.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.2 FI	20.8 F	199.7 F
03/07/25	14:00	0.0 FID	0.040 FI	19.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.3 FI	20.8 F	199.7 F
03/07/25	15:00	0.0 FID	0.040 FI	20.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.1 FI	20.8 F	199.7 F
03/07/25	16:00	0.0 FID	0.040 FI	18.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.3 FI	20.8 F	199.7 F
03/07/25	17:00	0.0 FID	0.040 FI	21.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.9 FI	20.8 F	199.7 F
03/07/25	18:00	0.0 FID	0.040 FI	25.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.6 FI	20.8 F	199.7 F
03/07/25	19:00	0.0 FID	0.040 FI	29.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.1 FI	20.8 F	199.7 F
03/07/25	20:00	0.0 FID	0.040 FI	36.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.1 FI	20.8 F	199.7 F
03/07/25	21:00	0.0 FID	0.040 FI	33.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.2 FI	20.8 F	199.7 F
03/07/25	22:00	0.0 FID	0.001 FI	32.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.3 FI	20.9 F	199.7 F
03/07/25	23:00	0.0 FID	0.040 FI	30.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.8 FI	20.8 F	199.8 F
03/08/25	00:00	0.0 FID	0.040 FI	32.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.4 FI	20.8 F	199.7 F

Source Parameter Unit		UNIT_A										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/08/25	01:00	0.0 FID	0.040 FI	30.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.2 FI	20.8 F	199.7 F
03/08/25	02:00	0.0 FID	0.040 FI	33.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.0 FI	20.8 F	199.8 F
03/08/25	03:00	0.0 FID	0.001 FI	38.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.8 FI	20.9 F	199.8 F
03/08/25	04:00	0.0 FID	0.001 FI	35.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.7 FI	20.9 F	199.8 F
03/08/25	05:00	0.0 FID	0.001 FI	40.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.5 FI	20.9 F	199.8 F
03/08/25	06:00	0.0 FID	0.040 FI	33.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.5 FI	20.8 F	199.8 F
03/08/25	07:00	0.0 FIC	0.015 FI	6.7 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.8 F
03/08/25	08:00	0.0 FID	0.079 FIE	41.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.8 F	199.8 F
03/08/25	09:00	0.0 FID	0.066 FIE	35.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.8 F	199.7 F
03/08/25	10:00	0.0 FID	0.066 FIE	36.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.8 F	199.7 F
03/08/25	11:00	0.0 FID	0.066 FIE	34.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.8 F	199.7 F
03/08/25	12:00	0.0 FID	0.066 FIE	37.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.8 F	199.7 F
03/08/25	13:00	0.0 FID	0.066 FIE	38.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.8 F	199.7 F
03/08/25	14:00	0.0 FID	0.079 FIE	38.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.8 F	199.7 F
03/08/25	15:00	0.0 FID	0.066 FIE	37.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.8 F	199.7 F
03/08/25	16:00	0.0 FID	0.066 FIE	37.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.8 F	199.7 F
03/08/25	17:00	0.0 FID	0.066 FIE	38.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.8 F	199.7 F
03/08/25	18:00	0.0 FID	0.066 FIE	36.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.8 F	199.7 F
03/08/25	19:00	0.0 FID	0.066 FIE	43.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.8 F	199.7 F
03/08/25	20:00	0.0 FID	0.001 FI	74.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.9 F	199.7 F
03/08/25	21:00	0.0 FID	0.001 FI	68.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.5 FI	20.9 F	199.7 F
03/08/25	22:00	0.0 FID	0.001 FI	84.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.0 FI	20.9 F	199.7 F
03/08/25	23:00	0.0 FID	0.001 FI	110.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.0 FI	20.9 F	199.7 F
03/09/25	00:00	0.0 FID	0.001 FI	97.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.9 F	199.7 F
03/09/25	01:00	0.0 FID	0.001 FI	111.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.5 FI	20.9 F	199.7 F
03/09/25	02:00	0.0 FID	0.001 FI	116.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.9 F	199.7 F
03/09/25	03:00	0.0 FID	0.001 FI	121.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.9 FI	20.9 F	199.7 F
03/09/25	04:00	0.0 FID	0.001 FI	122.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.1 FI	20.9 F	199.7 F
03/09/25	05:00	0.0 FID	0.001 FI	115.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.9 F	199.7 F
03/09/25	06:00	0.0 FID	0.001 FI	109.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.9 F	199.8 F
03/09/25	07:00	0.0 FIC	0.015 FI	6.6 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.8 F
03/09/25	08:00	0.0 FID	0.053 FI	22.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.9 FI	20.8 F	199.7 F
03/09/25	09:00	0.0 FID	0.053 FI	19.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.2 FI	20.8 F	199.7 F
03/09/25	10:00	0.0 FID	0.053 FI	19.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.8 FI	20.8 F	199.7 F
03/09/25	11:00	0.0 FID	0.053 FI	17.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.7 FI	20.8 F	199.7 F
03/09/25	12:00	0.0 FID	0.053 FI	18.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.8 FI	20.8 F	199.7 F
03/09/25	13:00	0.0 FID	0.053 FI	20.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.9 FI	20.8 F	199.7 F

Source		UNIT_A										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/09/25	14:00	0.0 FID	0.053 FI	22.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.1 FI	20.8 F	199.7 F
03/09/25	15:00	0.0 FID	0.053 FI	24.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.4 FI	20.8 F	199.7 F
03/09/25	16:00	0.0 FID	0.053 FI	28.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.1 FI	20.8 F	199.7 F
03/09/25	17:00	0.0 FID	0.053 FI	26.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.6 FI	20.8 F	199.7 F
03/09/25	18:00	0.0 FID	0.053 FI	27.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.7 FI	20.8 F	199.7 F
03/09/25	19:00	0.0 FID	0.053 FI	28.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.6 FI	20.8 F	199.7 F
03/09/25	20:00	0.0 FID	0.053 FI	28.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.8 FI	20.8 F	199.7 F
03/09/25	21:00	0.0 FID	0.053 FI	29.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.6 FI	20.8 F	199.7 F
03/09/25	22:00	0.0 FID	0.053 FI	28.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.3 FI	20.8 F	199.7 F
03/09/25	23:00	0.0 FID	0.053 FI	26.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.5 FI	20.8 F	199.7 F
03/10/25	00:00	0.0 FID	0.053 FI	25.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.4 FI	20.8 F	199.7 F
03/10/25	01:00	0.0 FID	0.053 FI	26.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.3 FI	20.8 F	199.7 F
03/10/25	02:00	0.0 FID	0.053 FI	24.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.1 FI	20.8 F	199.7 F
03/10/25	03:00	0.0 FID	0.053 FI	27.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.7 FI	20.8 F	199.7 F
03/10/25	04:00	0.0 FID	0.053 FI	27.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.3 FI	20.8 F	199.7 F
03/10/25	05:00	0.0 FID	0.053 FI	24.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.7 FI	20.8 F	199.7 F
03/10/25	06:00	0.0 FIC	0.015 FI	6.6 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.7 F
03/10/25	07:00	0.0 FID	0.001 FI	1,201.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.7 FI	20.9 F	199.7 F
03/10/25	08:00	0.0 FID	0.001 FID	135.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.9 F	199.7 F
03/10/25	09:00	0.0 FID	0.001 FID	88.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.9 F	199.7 F
03/10/25	10:00	0.0 FID	0.001 FI	79.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.9 F	199.7 F
03/10/25	11:00	0.0 FID	0.001 FI	63.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.9 F	199.7 F
03/10/25	12:00	0.0 FID	0.001 FI	69.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.9 F	199.7 F
03/10/25	13:00	0.0 FID	0.001 FI	84.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.9 F	199.7 F
03/10/25	14:00	0.0 FID	0.001 FI	84.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.9 F	199.7 F
03/10/25	15:00	0.0 FID	0.001 FI	87.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.9 F	199.7 F
03/10/25	16:00	0.0 FID	0.001 FI	99.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.9 F	199.7 F
03/10/25	17:00	0.0 FID	0.001 FI	110.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.9 F	199.7 F
03/10/25	18:00	0.0 FID	0.001 FI	85.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.9 F	199.7 F
03/10/25	19:00	0.0 FID	0.001 FI	90.4 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
03/10/25	20:00	0.0 FID	0.001 FI	-354.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.9 FI	20.9 F	199.7 F
03/10/25	21:00	0.0 FID	0.001 FI	-170.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	20.9 F	199.7 F
03/10/25	22:00	0.0 FID	0.001 FI	-91.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	20.9 F	199.7 F
03/10/25	23:00	0.0 FID	0.001 FI	-185.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	20.9 F	199.7 F
03/11/25	00:00	0.0 FID	0.001 FI	-166.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.4 FI	20.9 F	199.7 F
03/11/25	01:00	0.0 FID	0.001 FI	-178.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	20.9 F	199.7 F
03/11/25	02:00	0.0 FID	0.001 FI	-225.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.9 F	199.7 F

Source		UNIT_A										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/11/25	03:00	0.0 FID	0.001 FI	-478.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	20.9 F	199.7 F
03/11/25	04:00	0.0 FID	0.001 FI	-5,672.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-23.1 FI	20.9 F	199.7 F
03/11/25	05:00	0.0 FID	0.001 FI	217.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.1 FI	20.9 F	199.7 F
03/11/25	06:00	0.0 FIC	0.015 FI	6.6 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.7 F
03/11/25	07:00	0.0 FID	0.001 FI	50.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.9 F	199.7 F
03/11/25	08:00	0.0 FID	0.001 FID	47.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.9 F	199.7 F
03/11/25	09:00	0.0 FID	0.053 FID	41.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.8 F	199.7 F
03/11/25	10:00	0.0 FID	0.053 FI	35.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.8 F	199.7 F
03/11/25	11:00	0.0 FID	0.053 FI	34.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.8 F	199.7 F
03/11/25	12:00	0.0 FID	0.053 FI	34.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.8 F	199.7 F
03/11/25	13:00	0.0 FID	0.053 FI	35.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.8 F	199.7 F
03/11/25	14:00	0.0 FID	0.053 FI	34.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.8 F	199.7 F
03/11/25	15:00	0.0 FID	0.053 FI	35.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.8 F	199.7 F
03/11/25	16:00	0.0 FID	0.053 FI	34.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.1 FI	20.8 F	199.7 F
03/11/25	17:00	0.0 FID	0.053 FI	34.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.8 F	199.7 F
03/11/25	18:00	0.0 FID	0.053 FI	35.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.0 FI	20.8 F	199.7 F
03/11/25	19:00	0.0 FID	0.053 FI	39.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.8 F	199.7 F
03/11/25	20:00	0.0 FID	0.053 FI	35.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.1 FI	20.8 F	199.7 F
03/11/25	21:00	0.0 FID	0.053 FI	28.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.0 FI	20.8 F	199.7 F
03/11/25	22:00	0.0 FID	0.053 FI	32.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.8 F	199.7 F
03/11/25	23:00	0.0 FID	0.053 FI	34.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.8 F	199.7 F
03/12/25	00:00	0.0 FID	0.053 FI	29.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.8 F	199.7 F
03/12/25	01:00	0.0 FID	0.053 FI	32.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.8 F	199.7 F
03/12/25	02:00	0.0 FID	0.053 FI	33.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.8 F	199.7 F
03/12/25	03:00	0.0 FID	0.053 FI	29.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.8 F	199.7 F
03/12/25	04:00	0.0 FID	0.053 FI	34.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.8 F	199.7 F
03/12/25	05:00	0.0 FID	0.053 FI	33.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.1 FI	20.8 F	199.7 F
03/12/25	06:00	0.0 FIC	0.015 FI	6.8 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.024 F	6.5 F	14.2 FC	199.7 F
03/12/25	07:00	0.0 FID	0.001 FI	-47.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
03/12/25	08:00	0.0 FID	0.001 FI	-49.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
03/12/25	09:00	0.0 FID	0.001 FI	-50.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
03/12/25	10:00	0.0 FID	0.001 FI	-47.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
03/12/25	11:00	0.0 FID	0.001 FI	-45.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
03/12/25	12:00	0.0 FID	0.001 FI	-53.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
03/12/25	13:00	0.0 FID	0.001 FI	-46.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
03/12/25	14:00	0.0 FID	0.001 FI	-54.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	20.9 F	199.7 F
03/12/25	15:00	0.0 FID	0.001 FI	-49.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.7 F

Source Parameter Unit		UNIT_A										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/12/25	16:00	0.0 FID	0.001 FI	-49.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
03/12/25	17:00	0.0 FID	0.001 FI	-45.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
03/12/25	18:00	0.0 FID	0.001 FI	-44.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
03/12/25	19:00	0.0 FID	0.001 FI	-44.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
03/12/25	20:00	190.7 EU	0.683 E	308.7 E	0.0	0.0	0.0	34.0 EU	0.123 E	34.0 E	18.4	199.7
03/12/25	21:00	19.6 U	0.023	10.3	0.0	0.0	0.0	31.7 EU	0.039 E	10.6 E	15.0	199.7
03/12/25	22:00	7.8	0.009	4.0	0.0	0.0	0.0	14.1	0.016	4.4	14.9	199.7
03/12/25	23:00	30.8	0.039	17.2	0.0	0.0	0.0	13.1	0.016	4.4	15.3	199.7
03/13/25	00:00	23.5 D	0.029	12.8	0.0	0.0	0.0	13.2 D	0.016	4.4	15.2	199.7
03/13/25	01:00	84.7 ED	0.283 E	127.9 E	0.0	0.0	0.0	33.5 ED	0.098 E	27.0 E	16.9	199.7
03/13/25	02:00	0.0 FID	0.001 FI	-56.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
03/13/25	03:00	0.0 FID	0.001 FI	-54.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	20.9 F	199.7 F
03/13/25	04:00	0.0 FID	0.001 FI	-52.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
03/13/25	05:00	0.0 FID	0.001 FI	-46.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
03/13/25	06:00	0.0 FIC	0.015 FI	6.7 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.024 F	6.4 F	14.3 FC	199.7 F
03/13/25	07:00	0.0 FID	0.001 FI	-30.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.7 F
03/13/25	08:00	0.0 FID	0.001 FI	-26.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.7 F
03/13/25	09:00	0.0 FID	0.001 FI	-30.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.7 F
03/13/25	10:00	0.0 FID	0.001 FI	-29.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.7 F
03/13/25	11:00	0.0 FID	0.001 FI	-29.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.7 F
03/13/25	12:00	0.0 FID	0.001 FI	-29.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.7 F
03/13/25	13:00	0.0 FID	0.001 FI	-28.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.7 F
03/13/25	14:00	0.0 FID	0.001 FI	-27.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.7 F
03/13/25	15:00	0.0 FID	0.001 FI	-28.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.7 F
03/13/25	16:00	0.0 FID	0.001 FI	-28.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.7 F
03/13/25	17:00	0.0 FID	0.001 FI	-27.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	21.0 F	199.7 F
03/13/25	18:00	0.0 FID	0.001 FI	-28.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.8 F
03/13/25	19:00	0.0 FID	0.001 FI	-25.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.7 F
03/13/25	20:00	0.0 FID	0.001 FI	-28.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.0 FI	21.0 F	199.7 F
03/13/25	21:00	0.0 FID	0.001 FI	-29.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	21.0 F	199.7 F
03/13/25	22:00	0.0 FID	0.001 FI	-28.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.8 F
03/13/25	23:00	0.0 FID	0.001 FI	-29.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.0 FI	21.0 F	199.8 F
03/14/25	00:00	0.0 FID	0.001 FI	-28.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.8 F
03/14/25	01:00	0.0 FID	0.001 FI	-25.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.8 F
03/14/25	02:00	0.0 FID	0.001 FI	-25.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.8 F
03/14/25	03:00	0.0 FID	0.001 FI	-21.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.7 F
03/14/25	04:00	0.0 FID	0.001 FI	-20.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.8 F



UNIT START UP

UNIT SHUTDOWN



Source		UNIT_A										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/14/25	05:00	0.0 FIM	0.001 FI	-21.5 FI	0.0 F	0.0 F	0.0 FIM	0.0 FIM	0.001 FI	-0.7 FI	21.0 FM	199.8 F
03/14/25	06:00	0.0 FIC	0.015 FI	6.7 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.3 FC	199.8 F
03/14/25	07:00	0.0 FID	0.001 FI	95.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.4 FI	20.9 F	199.7 F
03/14/25	08:00	0.0 FID	0.001 FI	85.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.5 FI	20.9 F	199.7 F
03/14/25	09:00	0.0 FID	0.001 FI	59.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.0 FI	20.9 F	199.7 F
03/14/25	10:00	0.0 FID	0.001 FI	47.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.9 FI	20.9 F	199.7 F
03/14/25	11:00	0.0 FID	0.001 FI	45.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.9 FI	20.9 F	199.7 F
03/14/25	12:00	0.0 FID	0.001 FI	44.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.7 FI	20.9 F	199.7 F
03/14/25	13:00	0.0 FID	0.001 FI	46.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.2 FI	20.9 F	199.7 F
03/14/25	14:00	0.0 FID	0.001 FI	45.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.9 FI	20.9 F	199.7 F
03/14/25	15:00	0.0 FID	0.001 FI	45.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.8 FI	20.9 F	199.8 F
03/14/25	16:00	0.0 FID	0.001 FI	46.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.2 FI	20.9 F	199.8 F
03/14/25	17:00	0.0 FID	0.053 FI	41.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.0 FI	20.8 F	199.7 F
03/14/25	18:00	0.0 FID	0.053 FI	42.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.7 FI	20.8 F	199.7 F
03/14/25	19:00	0.0 FID	0.001 FI	46.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.5 FI	20.9 F	199.7 F
03/14/25	20:00	0.0 FID	0.053 FI	38.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.7 FI	20.8 F	199.7 F
03/14/25	21:00	0.0 FID	0.001 FI	42.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.9 FI	20.9 F	199.7 F
03/14/25	22:00	0.0 FID	0.040 FI	40.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.3 FI	20.8 F	199.7 F
03/14/25	23:00	0.0 FID	0.053 FI	20.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.8 F	199.7 F
03/15/25	00:00	0.0 FID	0.001 FI	45.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.8 FI	20.9 F	199.7 F
03/15/25	01:00	0.0 FID	0.001 FI	42.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.8 FI	20.9 F	199.7 F
03/15/25	02:00	0.0 FID	0.001 FI	47.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.7 FI	20.9 F	199.7 F
03/15/25	03:00	0.0 FID	0.001 FI	48.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.4 FI	20.9 F	199.7 F
03/15/25	04:00	0.0 FID	0.001 FI	43.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.4 FI	20.9 F	199.7 F
03/15/25	05:00	0.0 FID	0.053 FI	41.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.5 FI	20.8 F	199.7 F
03/15/25	06:00	0.0 FIC	0.015 FI	6.6 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.7 F
03/15/25	07:00	0.0 FID	0.001 FID	-297.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-10.7 FI	20.9 F	199.7 F
03/15/25	08:00	0.0 FID	0.001 FID	38,773.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1,189.5 FIE	20.9 F	199.7 F
03/15/25	09:00	0.0 FID	0.001 FI	-17,181.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-755.0 FI	20.9 F	199.7 F
03/15/25	10:00	0.0 FID	0.001 FI	-576.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-22.0 FI	20.9 F	199.7 F
03/15/25	11:00	0.0 FID	0.001 FI	518.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	16.7 FIE	20.9 F	199.7 F
03/15/25	12:00	0.0 FID	0.001 FI	20,107.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	658.8 FIE	20.9 F	199.7 F
03/15/25	13:00	0.0 FID	0.001 FI	519.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	17.0 FIE	20.9 F	199.7 F
03/15/25	14:00	0.0 FID	0.001 FI	1,095.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	29.7 FIE	20.9 F	199.7 F
03/15/25	15:00	0.0 FID	0.001 FI	8,749.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	323.0 FIE	20.9 F	199.7 F
03/15/25	16:00	0.0 FID	0.001 FI	582.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	23.1 FIE	20.9 F	199.7 F
03/15/25	17:00	0.0 FID	0.001 FI	337.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	12.7 FIE	20.9 F	199.7 F

Source Parameter Unit	UNIT_A										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/15/25 18:00	0.0 FID	0.001 FI	1,156.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	47.9 FIE	20.9 F	199.7 F
03/15/25 19:00	0.0 FID	0.001 FI	4,228.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	177.1 FIE	20.9 F	199.7 F
03/15/25 20:00	0.0 FID	0.001 FI	293.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	10.5 FIE	20.9 F	199.7 F
03/15/25 21:00	0.0 FID	0.001 FI	916.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	45.1 FIE	20.9 F	199.7 F
03/15/25 22:00	0.0 FID	0.001 FI	561.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	20.2 FIE	20.9 F	199.7 F
03/15/25 23:00	0.0 FID	0.001 FI	574.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	18.7 FIE	20.9 F	199.7 F
03/16/25 00:00	0.0 FID	0.001 FI	1,055.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	48.0 FIE	20.9 F	199.7 F
03/16/25 01:00	0.0 FID	0.001 FI	418.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	12.9 FIE	20.9 F	199.7 F
03/16/25 02:00	0.0 FID	0.001 FI	270.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	7.6 FIE	20.9 F	199.7 F
03/16/25 03:00	0.0 FID	0.001 FI	394.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	15.5 FIE	20.9 F	199.7 F
03/16/25 04:00	0.0 FID	0.001 FI	668.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	24.1 FIE	20.9 F	199.7 F
03/16/25 05:00	0.0 FID	0.001 FI	378.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	11.9 FIE	20.9 F	199.7 F
03/16/25 06:00	0.0 FIC	0.015 FI	6.7 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.7 F
03/16/25 07:00	0.0 FID	0.001 FI	-37.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.7 F
03/16/25 08:00	0.0 FID	0.001 FI	-45.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.0 FI	21.0 F	199.7 F
03/16/25 09:00	0.0 FID	0.001 FI	-48.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	21.0 F	199.7 F
03/16/25 10:00	0.0 FID	0.001 FI	-47.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	21.0 F	199.7 F
03/16/25 11:00	0.0 FID	0.001 FI	-47.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	21.0 F	199.7 F
03/16/25 12:00	0.0 FID	0.001 FI	-41.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.9 FI	21.0 F	199.7 F
03/16/25 13:00	0.0 FID	0.001 FI	-50.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.2 FI	21.0 F	199.7 F
03/16/25 14:00	0.0 FID	0.001 FI	-48.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.2 FI	21.0 F	199.7 F
03/16/25 15:00	0.0 FID	0.001 FI	-41.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	21.0 F	199.7 F
03/16/25 16:00	0.0 FID	0.001 FI	-47.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.9 FI	21.0 F	199.7 F
03/16/25 17:00	0.0 FID	0.001 FI	-53.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	21.0 F	199.7 F
03/16/25 18:00	0.0 FID	0.001 FI	-50.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.1 FI	21.0 F	199.7 F
03/16/25 19:00	0.0 FID	0.001 FI	-48.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.0 FI	21.0 F	199.7 F
03/16/25 20:00	0.2 FID	0.001 FI	-52.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	21.0 F	199.7 F
03/16/25 21:00	0.0 FID	0.001 FI	-43.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	21.0 F	199.7 F
03/16/25 22:00	0.0 FID	0.001 FI	-39.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.7 F
03/16/25 23:00	0.0 FID	0.001 FI	-49.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.7 FI	21.0 F	199.7 F
03/17/25 00:00	0.0 FID	0.001 FI	-42.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	21.0 F	199.7 F
03/17/25 01:00	0.0 FID	0.001 FI	-57.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.7 F
03/17/25 02:00	0.0 FID	0.001 FI	-44.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.7 F
03/17/25 03:00	0.0 FID	0.001 FI	-40.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.7 F
03/17/25 04:00	0.0 FID	0.001 FI	-55.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	21.0 F	199.7 F
03/17/25 05:00	0.0 FID	0.001 FI	-42.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	21.0 F	199.7 F
03/17/25 06:00	0.0 FIC	0.015 FI	6.8 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.7 F

Source		UNIT_A										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/17/25	07:00	0.0 FID	0.001 FID	-34.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.0 FI	21.0 F	199.7 F
03/17/25	08:00	0.0 FID	0.001 FID	-35.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.7 FI	21.0 F	199.7 F
03/17/25	09:00	0.0 FID	0.001 FI	-31.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.3 FI	21.0 F	199.7 F
03/17/25	10:00	0.0 FID	0.001 FI	-32.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.6 FI	21.0 F	199.7 F
03/17/25	11:00	0.0 FID	0.001 FI	-32.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.4 FI	21.0 F	199.7 F
03/17/25	12:00	0.0 FID	0.001 FI	-32.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.1 FI	21.0 F	199.7 F
03/17/25	13:00	0.0 FID	0.001 FI	-33.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.4 FI	21.0 F	199.7 F
03/17/25	14:00	0.0 FID	0.001 FI	-33.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.8 FI	21.0 F	199.7 F
03/17/25	15:00	0.0 FID	0.001 FI	-33.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.1 FI	21.0 F	199.7 F
03/17/25	16:00	0.0 FID	0.001 FI	-34.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.8 FI	21.0 F	199.7 F
03/17/25	17:00	0.0 FID	0.001 FI	-30.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.3 FI	21.0 F	199.7 F
03/17/25	18:00	0.0 FID	0.001 FI	-33.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.2 FI	21.0 F	199.7 F
03/17/25	19:00	0.0 FID	0.001 FI	-33.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.6 FI	21.0 F	199.7 F
03/17/25	20:00	0.0 FID	0.001 FI	-36.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.7 FI	21.0 F	199.7 F
03/17/25	21:00	0.0 FID	0.001 FI	-31.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.2 FI	21.0 F	199.7 F
03/17/25	22:00	0.0 FID	0.001 FI	-34.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.9 FI	21.0 F	199.7 F
03/17/25	23:00	0.0 FID	0.001 FI	-37.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.4 FI	21.0 F	199.7 F
03/18/25	00:00	0.0 FID	0.001 FI	-31.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.5 FI	21.0 F	199.7 F
03/18/25	01:00	0.0 FID	0.001 FI	-33.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.8 FI	21.0 F	199.7 F
03/18/25	02:00	0.0 FID	0.001 FI	-30.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.9 FI	21.0 F	199.7 F
03/18/25	03:00	0.0 FID	0.001 FI	-31.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.1 FI	21.0 F	199.7 F
03/18/25	04:00	0.0 FID	0.001 FI	-33.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.6 FI	21.0 F	199.7 F
03/18/25	05:00	0.0 FID	0.001 FI	-30.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.9 FI	21.0 F	199.7 F
03/18/25	06:00	0.0 FIC	0.015 FI	6.8 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.024 F	6.5 F	14.3 FC	199.7 F
03/18/25	07:00	0.0 FID	0.001 FI	-46.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.0 FI	21.0 F	199.7 F
03/18/25	08:00	0.0 FID	0.001 FI	-44.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.6 FI	21.0 F	199.7 F
03/18/25	09:00	0.0 FID	0.001 FI	-37.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	21.0 F	199.7 F
03/18/25	10:00	0.0 FID	0.001 FI	-50.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.8 FI	20.9 F	199.7 F
03/18/25	11:00	0.0 FID	0.001 FI	-42.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.1 FI	21.0 F	199.7 F
03/18/25	12:00	0.0 FID	0.001 FI	-43.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.9 FI	21.0 F	199.7 F
03/18/25	13:00	0.0 FID	0.001 FI	-46.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.8 FI	21.0 F	199.7 F
03/18/25	14:00	0.0 FID	0.001 FI	-45.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.2 FI	21.0 F	199.7 F
03/18/25	15:00	0.0 FID	0.001 FI	-43.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.7 FI	21.0 F	199.7 F
03/18/25	16:00	0.0 FID	0.001 FI	-41.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.4 FI	21.0 F	199.7 F
03/18/25	17:00	0.0 FID	0.001 FI	-41.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	21.0 F	199.7 F
03/18/25	18:00	0.0 FID	0.001 FI	-37.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.4 FI	21.0 F	199.7 F
03/18/25	19:00	0.0 FID	0.001 FI	-45.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.0 FI	21.0 F	199.7 F

Source		UNIT_A										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/18/25	20:00	0.0 FID	0.001 FI	-44.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.6 FI	21.0 F	199.7 F
03/18/25	21:00	0.0 FID	0.001 FI	-40.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.4 FI	21.0 F	199.7 F
03/18/25	22:00	0.3 FID	0.001 FI	-44.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.2 FI	21.0 F	199.7 F
03/18/25	23:00	36.6 U	0.060 E	26.8 E	0.0	0.0	0.0	41.8 EU	0.062 E	17.1 E	15.6	199.7
03/19/25	00:00	36.6 UD	0.046	20.4	0.0	0.0	0.0	13.0 UD	0.016	4.4	15.3	199.7
03/19/25	01:00	98.4 ED	0.339 E	149.6 E	0.0	0.0	0.0	36.9 ED	0.112 E	30.1 E	17.2	199.7
03/19/25	02:00	0.0 FID	0.001 FI	78.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.3 FI	20.9 F	199.7 F
03/19/25	03:00	0.0 FID	0.001 FI	-44.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.1 FI	21.0 F	199.7 F
03/19/25	04:00	0.0 FID	0.001 FI	-44.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.3 FI	21.0 F	199.7 F
03/19/25	05:00	0.0 FID	0.001 FI	-41.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.5 FI	21.0 F	199.7 F
03/19/25	06:00	0.0 FIC	0.015 FI	6.6 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.024 F	6.4 F	14.3 FC	199.7 F
03/19/25	07:00	0.0 FID	0.001 FI	-21.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.7 F
03/19/25	08:00	0.0 FID	0.001 FI	-19.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.7 F
03/19/25	09:00	0.0 FIM	0.001 FI	-172.4 FI	0.0 F	0.0 F	0.0 FIM	0.0 FIM	0.001 FI	-1.1 FI	21.1 FM	199.8 F
03/19/25	10:00	0.0 FIM	0.001 FI	-106.2 FI	0.0 F	0.0 F	0.0 FIM	0.0 FIM	0.001 FI	0.0 FI	21.1 FM	199.8 F
03/19/25	11:00	0.0 FIM	0.013 FI	5.8 FI	0.0 F	0.0 F	0.0 FIM	0.0 FIM	0.024 F	6.5 F	12.7 FMC	199.7 F
03/19/25	12:00	0.0 FIC	0.017 FI	7.6 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.3 FC	199.7 F
03/19/25	13:00	0.0 FID	0.001 FI	-171.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.7 F
03/19/25	14:00	0.0 FID	0.001 FI	-139.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.7 F
03/19/25	15:00	0.0 FID	0.001 FI	-166.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	21.0 F	199.7 F
03/19/25	16:00	0.0 FID	0.001 FI	-149.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.7 F
03/19/25	17:00	0.0 FID	0.001 FI	-128.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.7 F
03/19/25	18:00	0.0 FID	0.001 FI	-114.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	21.0 F	199.7 F
03/19/25	19:00	0.0 FID	0.001 FI	-139.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	20.9 F	199.7 F
03/19/25	20:00	0.0 FID	0.001 FI	-119.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.7 F
03/19/25	21:00	0.0 FID	0.001 FI	-118.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	20.9 F	199.7 F
03/19/25	22:00	0.0 FID	0.001 FI	-101.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.7 F
03/19/25	23:00	0.0 FID	0.001 FI	-102.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.7 F
03/20/25	00:00	0.0 FID	0.001 FI	-132.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	20.9 F	199.7 F
03/20/25	01:00	0.0 FID	0.001 FI	-76.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.7 F
03/20/25	02:00	0.0 FID	0.001 FI	-56.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.7 F
03/20/25	03:00	0.0 FID	0.001 FI	-61.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.7 F
03/20/25	04:00	0.0 FID	0.001 FI	-52.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.7 F
03/20/25	05:00	0.0 FID	0.001 FI	-49.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.7 F
03/20/25	06:00	0.0 FIC	0.015 FI	6.9 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.2 FC	199.7 F
03/20/25	07:00	0.0 FID	0.001 FID	283.6 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.2 FI	20.9 F	199.7 F
03/20/25	08:00	0.0 FID	0.001 FID	182.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.9 F	199.7 F

UNIT START UP

UNIT SHUTDOWN

Source		UNIT_A										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/20/25	09:00	0.0 FID	0.001 FI	152.7 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
03/20/25	10:00	0.0 FID	0.001 FI	143.6 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.2 FI	20.9 F	199.7 F
03/20/25	11:00	0.0 FID	0.001 FI	133.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.9 F	199.7 F
03/20/25	12:00	0.0 FID	0.146 FIE	123.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.7 F
03/20/25	13:00	0.0 FID	0.001 FI	127.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
03/20/25	14:00	0.0 FID	0.001 FI	126.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
03/20/25	15:00	0.0 FID	0.132 FIE	113.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.7 F
03/20/25	16:00	0.0 FID	0.132 FIE	115.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.7 F
03/20/25	17:00	0.0 FID	0.001 FI	134.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.9 F	199.7 F
03/20/25	18:00	0.0 FID	0.132 FIE	98.9 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.8 F	199.7 F
03/20/25	19:00	0.0 FID	0.132 FIE	55.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.7 F
03/20/25	20:00	0.0 FID	0.132 FIE	95.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.7 F
03/20/25	21:00	0.0 FID	0.119 FIE	46.8 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.8 F	199.7 F
03/20/25	22:00	0.0 FID	0.119 FIE	103.4 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.1 FI	20.8 F	199.7 F
03/20/25	23:00	0.0 FID	0.001 FI	112.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.9 F	199.7 F
03/21/25	00:00	0.0 FID	0.119 FIE	100.7 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.8 F	199.7 F
03/21/25	01:00	0.0 FID	0.119 FIE	97.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.7 F
03/21/25	02:00	0.0 FID	0.119 FIE	103.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.7 F
03/21/25	03:00	0.0 FID	0.119 FIE	94.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.7 F
03/21/25	04:00	0.0 FID	0.001 FI	125.4 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.1 FI	20.9 F	199.7 F
03/21/25	05:00	0.0 FID	0.119 FIE	87.9 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.8 F	199.7 F
03/21/25	06:00	0.0 FIC	0.015 FI	6.8 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.022 F	6.1 F	14.1 FC	199.8 F
03/21/25	07:00	0.0 FID	0.001 FID	142.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.3 FIE	20.9 F	199.8 F
03/21/25	08:00	0.0 FID	0.132 FIE	101.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.7 FI	20.8 F	199.7 F
03/21/25	09:00	0.0 FID	0.132 FIE	99.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.1 FI	20.8 F	199.7 F
03/21/25	10:00	0.0 FID	0.132 FIE	100.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.5 FI	20.8 F	199.7 F
03/21/25	11:00	0.0 FID	0.119 FIE	93.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.0 FI	20.8 F	199.7 F
03/21/25	12:00	0.0 FID	0.119 FIE	94.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.7 FI	20.8 F	199.7 F
03/21/25	13:00	0.0 FID	0.001 FI	126.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.3 FI	20.9 F	199.7 F
03/21/25	14:00	0.0 FID	0.119 FIE	99.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.3 FI	20.8 F	199.7 F
03/21/25	15:00	0.0 FID	0.119 FIE	96.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.0 FI	20.8 F	199.7 F
03/21/25	16:00	0.0 FID	0.119 FIE	86.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.0 FI	20.8 F	199.7 F
03/21/25	17:00	0.0 FID	0.119 FIE	94.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.3 FI	20.8 F	199.7 F
03/21/25	18:00	0.0 FID	0.001 FI	104.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.9 FI	20.9 F	199.7 F
03/21/25	19:00	0.0 FID	0.106 FIE	98.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.7 FI	20.8 F	199.7 F
03/21/25	20:00	0.0 FID	0.119 FIE	100.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.7 FI	20.8 F	199.7 F
03/21/25	21:00	0.0 FID	0.106 FIE	70.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.3 FI	20.8 F	199.7 F

Source		UNIT_A										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/21/25	22:00	0.0 FID	0.106 FIE	87.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.0 FI	20.8 F	199.7 F
03/21/25	23:00	0.0 FID	0.119 FIE	86.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.5 FI	20.8 F	199.7 F
03/22/25	00:00	0.0 FID	0.106 FIE	79.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.9 FI	20.8 F	199.7 F
03/22/25	01:00	0.0 FID	0.106 FIE	68.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.6 FI	20.8 F	199.7 F
03/22/25	02:00	0.0 FID	0.119 FIE	91.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.7 FI	20.8 F	199.7 F
03/22/25	03:00	0.0 FID	0.106 FIE	83.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.2 FI	20.8 F	199.7 F
03/22/25	04:00	0.0 FID	0.001 FI	101.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.5 FI	20.9 F	199.7 F
03/22/25	05:00	0.0 FID	0.001 FI	107.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.4 FI	20.9 F	199.7 F
03/22/25	06:00	0.0 FIC	0.015 FI	6.9 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.2 FC	199.7 F
03/22/25	07:00	0.0 FID	0.001 FI	-199.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-8.4 FI	20.9 F	199.7 F
03/22/25	08:00	0.0 FID	0.002 FI	0.7 FI	0.0 F	0.0 F	0.0 FIM	0.0 FID	0.089 F	24.5 F	15.8 FMC	199.8 F
03/22/25	09:00	0.0 FIM	0.001 FI	0.1 FI	0.0 F	0.0 F	0.0 FIM	0.0 FIM	0.086 F	23.3 F	2.3 FMC	199.8 F
03/22/25	10:00	0.0 FIM	0.007 FI	2.9 FI	0.0 F	0.0 F	0.0 FIM	9.2 FIM	0.043 F	11.7 F	1.9 FMC	199.7 F
03/22/25	11:00	0.1 FIM	0.011 FI	4.8 FI	0.0 F	0.0 F	0.0 FIM	7.2 FIM	0.054 F	14.8 F	11.4 FMC	199.7 F
03/22/25	12:00	1.4 FIM	0.001 FI	0.6 FI	0.0 F	0.0 F	0.0 FIM	0.2 FIM	0.020 F	5.5 F	10.8 FMC	199.7 F
03/22/25	13:00	0.0 FIM	0.012 FI	5.1 FI	0.0 F	0.0 F	0.0 FIM	0.0 FIM	0.047 F	12.9 F	4.7 FMC	199.7 F
03/22/25	14:00	0.0 FIM	0.015 FI	6.9 FI	0.0 F	0.0 F	0.0 FIM	0.0 FIM	0.024 F	6.6 F	14.1 FMC	199.7 F
03/22/25	15:00	0.0 FID	0.119 FIE	43.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.8 F	199.7 F
03/22/25	16:00	0.0 FID	0.106 FIE	41.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.7 F
03/22/25	17:00	0.0 FID	0.106 FIE	40.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.7 F
03/22/25	18:00	0.0 FID	0.106 FIE	39.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.7 F
03/22/25	19:00	0.0 FID	0.106 FIE	37.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.7 F
03/22/25	20:00	0.0 FID	0.106 FIE	35.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.7 F
03/22/25	21:00	0.0 FID	0.106 FIE	40.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.8 F	199.7 F
03/22/25	22:00	0.0 FID	0.106 FIE	39.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.7 F
03/22/25	23:00	0.0 FID	0.106 FIE	37.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.7 F
03/23/25	00:00	0.0 FID	0.106 FIE	37.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.7 F
03/23/25	01:00	0.0 FID	0.106 FIE	38.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.8 F	199.7 F
03/23/25	02:00	0.0 FID	0.106 FIE	37.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.7 F
03/23/25	03:00	0.0 FID	0.106 FIE	37.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.8 F	199.7 F
03/23/25	04:00	0.0 FID	0.106 FIE	35.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.8 F	199.7 F
03/23/25	05:00	0.0 FID	0.106 FIE	36.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.7 F
03/23/25	06:00	0.0 FIC	0.015 FI	6.9 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.026 F	7.0 F	14.2 FC	199.7 F
03/23/25	07:00	0.0 FID	0.001 FID	-48.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-9.2 FI	21.0 F	199.7 F
03/23/25	08:00	0.0 FID	0.001 FID	-47.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-7.3 FI	21.0 F	199.7 F
03/23/25	09:00	0.0 FID	0.001 FI	-42.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-7.5 FI	21.0 F	199.7 F
03/23/25	10:00	0.0 FID	0.001 FI	-46.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-9.4 FI	21.0 F	199.7 F

Source	Parameter Unit	UNIT_A										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/23/25	11:00	0.0 FID	0.001 FI	-44.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-8.1 FI	21.0 F	199.7 F
03/23/25	12:00	0.0 FID	0.001 FI	-43.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-7.2 FI	21.0 F	199.7 F
03/23/25	13:00	0.0 FID	0.001 FI	-41.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-6.7 FI	21.0 F	199.7 F
03/23/25	14:00	0.0 FID	0.001 FI	-45.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-7.6 FI	21.0 F	199.7 F
03/23/25	15:00	0.0 FID	0.001 FI	-40.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-6.8 FI	21.0 F	199.7 F
03/23/25	16:00	0.0 FID	0.001 FI	-42.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-7.4 FI	21.0 F	199.7 F
03/23/25	17:00	0.0 FID	0.001 FI	-42.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-6.9 FI	21.0 F	199.7 F
03/23/25	18:00	0.0 FID	0.001 FI	-41.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-7.2 FI	21.0 F	199.7 F
03/23/25	19:00	0.0 FID	0.001 FI	-43.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-7.7 FI	21.0 F	199.7 F
03/23/25	20:00	0.0 FID	0.001 FI	-42.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-6.7 FI	21.0 F	199.7 F
03/23/25	21:00	0.0 FID	0.001 FI	-47.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-8.7 FI	21.0 F	199.7 F
03/23/25	22:00	0.0 FID	0.001 FI	-46.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-8.2 FI	21.0 F	199.7 F
03/23/25	23:00	0.0 FID	0.001 FI	-45.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-7.9 FI	21.0 F	199.7 F
03/24/25	00:00	0.0 FID	0.001 FI	-40.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-7.9 FI	21.0 F	199.7 F
03/24/25	01:00	0.0 FID	0.001 FI	-45.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-8.4 FI	21.0 F	199.7 F
03/24/25	02:00	0.0 FID	0.001 FI	-39.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-7.2 FI	21.0 F	199.7 F
03/24/25	03:00	0.0 FID	0.001 FI	-43.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-7.9 FI	21.0 F	199.7 F
03/24/25	04:00	0.0 FID	0.001 FI	-46.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-8.4 FI	21.0 F	199.7 F
03/24/25	05:00	0.0 FIM	0.001 FI	-40.2 FI	0.0 F	0.0 F	0.0 FIM	0.0 FIM	0.001 FI	-7.2 FI	21.0 FM	199.7 F
03/24/25	06:00	0.0 FIC	0.015 FI	6.9 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.024 F	6.5 F	14.2 FC	199.7 F
03/24/25	07:00	0.0 FID	0.001 FID	-115.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.6 FI	20.9 F	199.7 F
03/24/25	08:00	0.0 FID	0.001 FID	-91.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.4 FI	20.9 F	199.7 F
03/24/25	09:00	0.0 FID	0.001 FI	-96.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.0 FI	20.9 F	199.7 F
03/24/25	10:00	0.0 FID	0.001 FI	-96.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.7 FI	20.9 F	199.7 F
03/24/25	11:00	0.0 FID	0.001 FI	-92.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.8 FI	20.9 F	199.7 F
03/24/25	12:00	0.0 FID	0.001 FI	-105.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.1 FI	20.9 F	199.7 F
03/24/25	13:00	0.0 FID	0.001 FI	-125.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-5.3 FI	20.9 F	199.7 F
03/24/25	14:00	0.0 FID	0.001 FI	-92.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.9 FI	20.9 F	199.7 F
03/24/25	15:00	0.0 FID	0.001 FI	-99.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.5 FI	20.9 F	199.7 F
03/24/25	16:00	0.0 FID	0.001 FI	-107.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.8 FI	20.9 F	199.7 F
03/24/25	17:00	0.0 FID	0.001 FI	-102.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.9 FI	20.9 F	199.7 F
03/24/25	18:00	0.0 FID	0.001 FI	-100.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.1 FI	20.9 F	199.7 F
03/24/25	19:00	0.0 FID	0.001 FI	-93.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.3 FI	20.9 F	199.7 F
03/24/25	20:00	0.0 FID	0.001 FI	-101.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.7 FI	20.9 F	199.7 F
03/24/25	21:00	0.0 FID	0.001 FI	-109.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.8 FI	20.9 F	199.7 F
03/24/25	22:00	0.0 FID	0.001 FI	-99.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.5 FI	20.9 F	199.7 F
03/24/25	23:00	0.0 FID	0.001 FI	-88.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.9 FI	20.9 F	199.7 F

Source Parameter Unit		UNIT_A										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/25/25	00:00	0.0 FID	0.001 FI	-108.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.2 FI	20.9 F	199.7 F
03/25/25	01:00	0.0 FID	0.001 FI	-95.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.3 FI	20.9 F	199.7 F
03/25/25	02:00	0.0 FID	0.001 FI	-88.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.1 FI	20.9 F	199.7 F
03/25/25	03:00	0.0 FID	0.001 FI	-139.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-5.2 FI	20.9 F	199.7 F
03/25/25	04:00	0.0 FID	0.001 FI	-105.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.9 FI	20.9 F	199.7 F
03/25/25	05:00	0.0 FID	0.001 FI	-106.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.8 FI	20.9 F	199.7 F
03/25/25	06:00	0.0 FIC	0.015 FI	6.9 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.024 F	6.5 F	14.2 FC	199.7 F
03/25/25	07:00	0.0 FID	0.001 FI	-37.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.7 F
03/25/25	08:00	0.0 FID	0.001 FI	-38.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.7 F
03/25/25	09:00	0.0 FID	0.001 FI	-40.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.7 F
03/25/25	10:00	0.0 FID	0.001 FI	-38.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	21.0 F	199.7 F
03/25/25	11:00	0.0 FID	0.001 FI	-36.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.7 F
03/25/25	12:00	0.0 FID	0.001 FI	-39.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.7 F
03/25/25	13:00	0.0 FID	0.001 FI	-35.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	21.0 F	199.7 F
03/25/25	14:00	0.0 FID	0.001 FI	-37.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.7 F
03/25/25	15:00	0.0 FID	0.001 FI	-38.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.7 F
03/25/25	16:00	0.0 FID	0.001 FI	-35.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.7 F
03/25/25	17:00	0.0 FID	0.001 FI	-36.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.7 F
03/25/25	18:00	0.0 FID	0.001 FI	-36.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.7 F
03/25/25	19:00	0.0 FID	0.001 FI	-34.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.7 F
03/25/25	20:00	0.0 FID	0.001 FI	-38.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.7 F
03/25/25	21:00	0.0 FID	0.001 FI	-36.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.7 F
03/25/25	22:00	0.0 FID	0.001 FI	-35.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.7 F
03/25/25	23:00	0.0 FID	0.001 FI	-40.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.7 F
03/26/25	00:00	0.0 FID	0.001 FI	-38.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.7 F
03/26/25	01:00	0.0 FID	0.001 FI	-39.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.7 F
03/26/25	02:00	0.0 FID	0.001 FI	-37.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.7 F
03/26/25	03:00	0.0 FID	0.001 FI	-34.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.7 F
03/26/25	04:00	0.0 FID	0.001 FI	-37.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.7 F
03/26/25	05:00	0.0 FID	0.001 FI	-36.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.7 F
03/26/25	06:00	0.0 FIC	0.016 FI	7.0 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.024 F	6.6 F	14.3 FC	199.7 F
03/26/25	07:00	0.0 FID	0.001 FID	-52.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	21.0 F	199.7 F
03/26/25	08:00	0.0 FID	0.001 FID	-52.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.7 F
03/26/25	09:00	0.0 FID	0.001 FI	-50.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.7 FI	21.0 F	199.7 F
03/26/25	10:00	0.0 FID	0.001 FI	-51.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.7 F
03/26/25	11:00	0.0 FIM	0.001 FI	-55.6 FI	0.0 F	0.0 F	0.0 FIM	0.0 FIM	0.001 FI	-1.5 FI	21.0 FM	199.7 F
03/26/25	12:00	0.7 FIM	0.002 FI	0.8 FI	0.0 F	0.0 F	0.0 FIM	0.3 FIM	0.026 F	7.1 F	14.8 FMC	199.7 F

Source Parameter Unit		UNIT_A										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/26/25	13:00	0.0 FIM	0.044 FI	19.2 FI	0.0 F	0.0 F	0.0 FIM	8.8 FIM	0.034 F	9.0 F	18.8 FMC	199.8 F
03/26/25	14:00	0.0 FIM	0.014 FI	6.0 FI	0.0 F	0.0 F	0.0 FIM	0.0 FIM	0.026 F	7.0 F	7.6 FMC	199.7 F
03/26/25	15:00	0.0 FID	0.001 FI	-73.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.7 F
03/26/25	16:00	0.0 FID	0.001 FI	-83.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.7 F
03/26/25	17:00	0.0 FID	0.001 FI	-92.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	20.9 F	199.7 F
03/26/25	18:00	0.0 FID	0.001 FI	-111.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	20.9 F	199.7 F
03/26/25	19:00	0.0 FID	0.001 FI	-115.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	20.9 F	199.7 F
03/26/25	20:00	0.0 FID	0.001 FI	-115.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	20.9 F	199.7 F
03/26/25	21:00	0.0 FID	0.001 FI	-105.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	20.9 F	199.7 F
03/26/25	22:00	0.0 FID	0.001 FI	-133.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.0 FI	20.9 F	199.7 F
03/26/25	23:00	0.0 FID	0.001 FI	-121.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	20.9 F	199.7 F
03/27/25	00:00	0.0 FID	0.001 FI	-136.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.7 FI	20.9 F	199.7 F
03/27/25	01:00	0.0 FID	0.001 FI	-158.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	20.9 F	199.7 F
03/27/25	02:00	0.0 FID	0.001 FI	-126.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	20.9 F	199.7 F
03/27/25	03:00	0.0 FID	0.001 FI	-152.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	20.9 F	199.7 F
03/27/25	04:00	0.0 FID	0.001 FI	-129.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	20.9 F	199.7 F
03/27/25	05:00	0.0 FID	0.001 FI	-109.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	20.9 F	199.7 F
03/27/25	06:00	0.0 FIC	0.015 FI	6.9 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.024 F	6.6 F	14.2 FC	199.7 F
03/27/25	07:00	0.0 FID	0.001 FID	-30.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.7 F
03/27/25	08:00	0.0 FID	0.001 FID	-30.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.7 F
03/27/25	09:00	0.0 FID	0.001 FI	-31.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.7 F
03/27/25	10:00	0.0 FID	0.001 FI	-30.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.7 F
03/27/25	11:00	0.0 FID	0.001 FI	-29.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.7 F
03/27/25	12:00	0.0 FID	0.001 FI	-30.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.7 F
03/27/25	13:00	0.0 FID	0.001 FI	-30.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.7 F
03/27/25	14:00	0.0 FID	0.001 FI	-29.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.7 F
03/27/25	15:00	0.0 FID	0.001 FI	-31.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.7 F
03/27/25	16:00	0.0 FID	0.001 FI	-28.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.7 F
03/27/25	17:00	0.0 FID	0.001 FI	-30.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.7 F
03/27/25	18:00	0.0 FID	0.001 FI	-31.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.7 F
03/27/25	19:00	0.0 FID	0.001 FI	-27.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.7 F
03/27/25	20:00	0.0 FID	0.001 FI	-32.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.7 F
03/27/25	21:00	0.0 FID	0.001 FI	-30.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.7 F
03/27/25	22:00	0.0 FID	0.001 FI	-30.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.7 F
03/27/25	23:00	0.0 FID	0.001 FI	-29.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.7 F
03/28/25	00:00	0.0 FID	0.001 FI	-31.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.7 F
03/28/25	01:00	0.0 FID	0.001 FI	-30.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.7 F

Source Parameter Unit		UNIT_A										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/28/25	02:00	0.0 FID	0.001 FI	-31.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.7 F
03/28/25	03:00	0.0 FID	0.001 FI	-54.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.7 F
03/28/25	04:00	0.0 FID	0.001 FI	-28.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.7 F
03/28/25	05:00	0.0 FID	0.001 FI	-30.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.7 F
03/28/25	06:00	0.0 FIC	0.015 FI	6.9 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.025 F	6.9 F	14.2 FC	199.7 F
03/28/25	07:00	0.0 FID	0.001 FID	-59.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-5.3 FI	21.0 F	199.7 F
03/28/25	08:00	0.0 FID	0.001 FID	-60.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.7 FI	21.0 F	199.7 F
03/28/25	09:00	0.0 FID	0.001 FI	-57.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.6 FI	21.0 F	199.7 F
03/28/25	10:00	0.0 FID	0.001 FI	-56.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.5 FI	21.0 F	199.7 F
03/28/25	11:00	0.0 FID	0.001 FI	-60.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-5.0 FI	21.0 F	199.7 F
03/28/25	12:00	0.0 FID	0.001 FI	-57.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.5 FI	21.0 F	199.7 F
03/28/25	13:00	0.0 FID	0.001 FI	-55.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.4 FI	21.0 F	199.7 F
03/28/25	14:00	0.0 FID	0.001 FI	-58.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.6 FI	21.0 F	199.7 F
03/28/25	15:00	0.0 FID	0.001 FI	-55.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.6 FI	21.0 F	199.7 F
03/28/25	16:00	0.0 FID	0.001 FI	-61.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-5.3 FI	21.0 F	199.7 F
03/28/25	17:00	0.0 FID	0.001 FI	-56.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.5 FI	21.0 F	199.7 F
03/28/25	18:00	0.0 FID	0.001 FI	-55.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.5 FI	21.0 F	199.7 F
03/28/25	19:00	0.0 FID	0.001 FI	-59.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.7 FI	21.0 F	199.7 F
03/28/25	20:00	0.0 FID	0.001 FI	-60.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-5.1 FI	21.0 F	199.7 F
03/28/25	21:00	0.0 FID	0.001 FI	-55.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.5 FI	21.0 F	199.7 F
03/28/25	22:00	0.0 FID	0.001 FI	-60.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-5.4 FI	21.0 F	199.7 F
03/28/25	23:00	40.1	0.262 E	116.9 E	0.0	0.0	0.0	9.8	0.069 E	18.7 E	17.6	199.7
03/29/25	00:00	30.0	0.040	17.5	0.0	0.0	0.0	39.6 E	0.055 E	14.8 E	15.4	199.7
03/29/25	01:00	44.5 D	0.071 E	31.9 E	0.0	0.0	0.0	15.2 D	0.024 E	6.6 E	15.4	199.7
03/29/25	02:00	2.3 I	0.001	1,998.9 E	0.0	0.0	0.0	0.2 I	0.001	83.2 E	20.9	199.7
03/29/25	03:00	0.0 FI	0.001 FI	-64.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FI	0.001 FI	-5.2 FI	21.0 F	199.7 F
03/29/25	04:00	0.0 FI	0.001 FI	-61.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FI	0.001 FI	-5.9 FI	21.0 F	199.7 F
03/29/25	05:00	0.0 FI	0.001 FI	-51.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FI	0.001 FI	-3.9 FI	21.0 F	199.7 F
03/29/25	06:00	0.0 FIC	0.015 FI	6.9 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.026 F	7.0 F	14.2 FC	199.7 F
03/29/25	07:00	0.0 FI	0.001 FI	-152.5 FI	0.0 F	0.0 F	0.0 FI	0.3 FI	0.001 FI	-0.1 FI	20.9 F	199.7 F
03/29/25	08:00	0.0 FI	0.001 FI	-108.2 FI	0.0 F	0.0 F	0.0 FI	0.4 FI	0.001 FI	0.0 FI	20.9 F	199.7 F
03/29/25	09:00	0.0 FI	0.001 FI	-108.3 FI	0.0 F	0.0 F	0.0 FI	0.3 FI	0.001 FI	0.0 FI	20.9 F	199.7 F
03/29/25	10:00	0.0 FI	0.001 FI	-127.5 FI	0.0 F	0.0 F	0.0 FI	0.3 FI	0.001 FI	-0.1 FI	20.9 F	199.7 F
03/29/25	11:00	0.0 FI	0.001 FI	-110.6 FI	0.0 F	0.0 F	0.0 FI	0.3 FI	0.001 FI	0.0 FI	20.9 F	199.7 F
03/29/25	12:00	0.0 FI	0.001 FI	-143.8 FI	0.0 F	0.0 F	0.0 FI	0.3 FI	0.001 FI	-0.1 FI	20.9 F	199.7 F
03/29/25	13:00	0.0 FI	0.001 FI	-116.0 FI	0.0 F	0.0 F	0.0 FI	0.3 FI	0.001 FI	0.0 FI	20.9 F	199.7 F
03/29/25	14:00	0.0 FI	0.001 FI	-112.2 FI	0.0 F	0.0 F	0.0 FI	0.3 FI	0.001 FI	0.0 FI	20.9 F	199.7 F

UNIT START UP

UNIT SHUTDOWN

Source		UNIT_A										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/29/25	15:00	0.0 FI	0.001 FI	-107.7 FI	0.0 F	0.0 F	0.0 FI	0.2 FI	0.001 FI	-0.1 FI	20.9 F	199.7 F
03/29/25	16:00	0.0 FI	0.001 FI	-110.7 FI	0.0 F	0.0 F	0.0 FI	0.3 FI	0.001 FI	0.0 FI	20.9 F	199.7 F
03/29/25	17:00	0.0 FI	0.001 FI	-146.2 FI	0.0 F	0.0 F	0.0 FI	0.3 FI	0.001 FI	0.0 FI	20.9 F	199.7 F
03/29/25	18:00	0.0 FI	0.001 FI	-161.8 FI	0.0 F	0.0 F	0.0 FI	0.3 FI	0.001 FI	0.0 FI	20.9 F	199.7 F
03/29/25	19:00	0.0 FI	0.001 FI	-135.4 FI	0.0 F	0.0 F	0.0 FI	0.3 FI	0.001 FI	0.0 FI	20.9 F	199.7 F
03/29/25	20:00	0.0 FI	0.001 FI	-104.0 FI	0.0 F	0.0 F	0.0 FI	0.3 FI	0.001 FI	-0.4 FI	20.9 F	199.7 F
03/29/25	21:00	0.0 FI	0.001 FI	-140.4 FI	0.0 F	0.0 F	0.0 FI	0.3 FI	0.001 FI	-0.2 FI	20.9 F	199.7 F
03/29/25	22:00	0.0 FI	0.001 FI	-131.7 FI	0.0 F	0.0 F	0.0 FI	0.3 FI	0.001 FI	-0.1 FI	20.9 F	199.7 F
03/29/25	23:00	0.0 FI	0.001 FI	-161.8 FI	0.0 F	0.0 F	0.0 FI	0.3 FI	0.001 FI	0.0 FI	20.9 F	199.7 F
03/30/25	00:00	0.0 FI	0.001 FI	-106.1 FI	0.0 F	0.0 F	0.0 FI	0.3 FI	0.001 FI	0.0 FI	20.9 F	199.7 F
03/30/25	01:00	0.0 FI	0.001 FI	-133.2 FI	0.0 F	0.0 F	0.0 FI	0.3 FI	0.001 FI	0.0 FI	20.9 F	199.7 F
03/30/25	02:00	0.0 FI	0.001 FI	-135.9 FI	0.0 F	0.0 F	0.0 FI	0.3 FI	0.001 FI	-0.1 FI	20.9 F	199.7 F
03/30/25	03:00	0.0 FI	0.001 FI	-122.4 FI	0.0 F	0.0 F	0.0 FI	0.3 FI	0.001 FI	0.0 FI	20.9 F	199.7 F
03/30/25	04:00	0.0 FI	0.001 FI	-111.0 FI	0.0 F	0.0 F	0.0 FI	0.3 FI	0.001 FI	0.0 FI	20.9 F	199.7 F
03/30/25	05:00	0.0 FI	0.001 FI	-127.6 FI	0.0 F	0.0 F	0.0 FI	0.3 FI	0.001 FI	-0.1 FI	20.9 F	199.7 F
03/30/25	06:00	0.0 FIC	0.015 FI	6.8 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.024 F	6.5 F	14.2 FC	199.7 F
03/30/25	07:00	0.0 FI	0.001 FID	-48.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FI	0.001 FI	-1.1 FI	21.0 F	199.7 F
03/30/25	08:00	0.0 FI	0.001 FID	-50.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FI	0.001 FI	-1.3 FI	21.0 F	199.7 F
03/30/25	09:00	0.0 FI	0.001 FI	-44.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FI	0.001 FI	-1.5 FI	21.0 F	199.7 F
03/30/25	10:00	0.0 FI	0.001 FI	-44.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FI	0.001 FI	-0.6 FI	21.0 F	199.7 F
03/30/25	11:00	0.0 FI	0.001 FI	-48.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FI	0.001 FI	-1.4 FI	21.0 F	199.7 F
03/30/25	12:00	0.0 FI	0.001 FI	-45.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FI	0.001 FI	-1.2 FI	21.0 F	199.7 F
03/30/25	13:00	0.0 FI	0.001 FI	-44.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FI	0.001 FI	-0.9 FI	21.0 F	199.7 F
03/30/25	14:00	0.0 FI	0.001 FI	-44.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FI	0.001 FI	-1.3 FI	21.0 F	199.7 F
03/30/25	15:00	0.0 FI	0.001 FI	-43.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FI	0.001 FI	-1.1 FI	21.0 F	199.7 F
03/30/25	16:00	0.0 FI	0.001 FI	-46.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FI	0.001 FI	-1.8 FI	21.0 F	199.7 F
03/30/25	17:00	0.0 FI	0.001 FI	-43.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FI	0.001 FI	-1.6 FI	21.0 F	199.7 F
03/30/25	18:00	0.0 FI	0.001 FI	-40.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FI	0.001 FI	-1.0 FI	21.0 F	199.7 F
03/30/25	19:00	0.0 FI	0.001 FI	-50.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FI	0.001 FI	-1.3 FI	21.0 F	199.7 F
03/30/25	20:00	69.2 EUD	0.149 E	66.3 E	0.0	0.0	0.0	86.4 EUD	0.132 E	35.7 E	17.0	199.7
03/30/25	21:00	18.7 UD	0.140 E	62.4 E	0.0	0.0	0.0	19.7 EUD	0.040 E	11.0 E	16.2	199.7
03/30/25	22:00	0.0 FIU	0.001 FI	-54.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-2.3 FI	21.0 F	199.7 F
03/30/25	23:00	0.0 FIU	0.001 FI	-45.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-1.7 FI	21.0 F	199.7 F
03/31/25	00:00	0.0 FIU	0.001 FI	-44.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-1.0 FI	21.0 F	199.7 F
03/31/25	01:00	0.0 FIU	0.001 FI	-45.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-1.2 FI	21.0 F	199.7 F
03/31/25	02:00	0.0 FIU	0.001 FI	-45.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-1.7 FI	21.0 F	199.7 F
03/31/25	03:00	0.0 FIU	0.001 FI	-44.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-1.3 FI	21.0 F	199.7 F

UNIT START UP
UNIT SHUTDOWN

UNIT B CEM REPORT

Average Data

Plant: Midway Sunset

Interval: 1 Hour

Type: Roll

Report Period: 01/01/2025 00:00 Through 03/31/2025 23:59

Time Online Criteria: 1 minute(s)

Source	Parameter Unit	UNIT_B										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/01/25	00:00	0.0 FI	0.001 FIU	-12.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-1.5 FI	21.0 F	199.8 F
01/01/25	01:00	0.0 FI	0.001 FIU	-12.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-0.9 FI	21.0 F	199.8 F
01/01/25	02:00	0.0 FI	0.001 FIU	-11.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-1.3 FI	21.0 F	199.8 F
01/01/25	03:00	0.0 FI	0.001 FIU	-11.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-1.1 FI	21.0 F	199.8 F
01/01/25	04:00	0.0 FI	0.001 FIU	-11.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-1.2 FI	21.0 F	199.8 F
01/01/25	05:00	0.0 FI	0.001 FIU	-11.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-1.0 FI	21.0 F	199.8 F
01/01/25	06:00	0.0 FI	0.001 FIU	-11.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-1.2 FI	21.0 F	199.8 F
01/01/25	07:00	0.0 FIC	0.011 FIU	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.8 F
01/01/25	08:00	0.0 FI	0.001 FIU	-23.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-1.4 FI	20.9 F	199.8 F
01/01/25	09:00	0.0 FI	0.001 FIU	-27.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-1.6 FI	20.9 F	199.8 F
01/01/25	10:00	0.0 FI	0.001 FIU	-22.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-0.8 FI	20.9 F	199.8 F
01/01/25	11:00	0.0 FI	0.001 FIU	-23.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-1.9 FI	20.9 F	199.8 F
01/01/25	12:00	0.0 FI	0.001 FIU	-27.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-1.4 FI	20.9 F	199.8 F
01/01/25	13:00	0.0 FI	0.001 FIU	-28.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-1.7 FI	20.9 F	199.8 F
01/01/25	14:00	0.0 FI	0.001 FIU	-34.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-1.6 FI	20.9 F	199.8 F
01/01/25	15:00	0.0 FI	0.001 FIU	-19.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-1.7 FI	20.9 F	199.8 F
01/01/25	16:00	0.0 FI	0.001 FIU	-24.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-1.5 FI	20.9 F	199.8 F
01/01/25	17:00	0.0 FI	0.001 FIU	-35.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-1.8 FI	20.9 F	199.8 F
01/01/25	18:00	0.0 FI	0.001 FIU	-28.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-1.6 FI	20.9 F	199.8 F
01/01/25	19:00	0.0 FI	0.001 FIU	-23.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-1.2 FI	20.9 F	199.8 F
01/01/25	20:00	0.0 FI	0.001 FIU	-32.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-2.2 FI	20.9 F	199.8 F
01/01/25	21:00	41.1 U	0.074 E	33.3 E	0.0	0.0	0.0	65.4 EU	0.104 E	28.5 E	16.0	199.8
01/01/25	22:00	16.7 U	0.021	9.3	0.0	0.0	0.0	12.6 U	0.016	4.3	15.1	199.8
01/01/25	23:00	17.1 D	0.022	9.7	0.0	0.0	0.0	12.4 D	0.016	4.3	15.0	199.9
01/02/25	00:00	85.4 ED	0.215 E	95.0 E	0.0	0.0	0.0	38.0 ED	0.092 E	24.6 E	16.4	199.9
01/02/25	01:00	0.0 FID	0.001 FI	-29.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.9 FI	20.9 F	199.9 F
01/02/25	02:00	0.0 FID	0.001 FI	-33.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.2 FI	20.9 F	199.9 F
01/02/25	03:00	0.0 FID	0.001 FI	-32.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.6 FI	20.9 F	199.8 F
01/02/25	04:00	0.0 FID	0.001 FI	-60.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.8 FI	20.9 F	199.8 F
01/02/25	05:00	0.0 FID	0.001 FI	-67.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-3.1 FI	20.9 F	199.8 F
01/02/25	06:00	0.0 FID	0.001 FI	-40.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.2 FI	20.9 F	199.8 F

UNIT SHUTDOWN
CONTINUED



UNIT START UP

UNIT SHUTDOWN



Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/02/25 07:00	0.0 FIC	0.011 FI	5.0 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.2 FC	199.8 F
01/02/25 08:00	0.0 FID	0.001 FI	-38.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	20.9 F	199.8 F
01/02/25 09:00	0.0 FID	0.001 FI	-51.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.2 FI	20.9 F	199.8 F
01/02/25 10:00	0.0 FID	0.001 FI	-43.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.7 FI	20.9 F	199.8 F
01/02/25 11:00	0.0 FID	0.001 FI	-32.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	20.9 F	199.8 F
01/02/25 12:00	0.0 FID	0.001 FI	-40.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.4 FI	20.9 F	199.8 F
01/02/25 13:00	0.0 FID	0.001 FI	-48.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.7 FI	20.9 F	199.8 F
01/02/25 14:00	0.0 FID	0.001 FI	-39.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.7 FI	20.9 F	199.8 F
01/02/25 15:00	0.0 FID	0.001 FI	-47.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.6 FI	20.9 F	199.8 F
01/02/25 16:00	0.0 FID	0.001 FI	-30.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.9 FI	20.9 F	199.8 F
01/02/25 17:00	0.0 FID	0.001 FI	-30.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	20.9 F	199.8 F
01/02/25 18:00	0.0 FID	0.001 FI	-56.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.7 FI	20.9 F	199.8 F
01/02/25 19:00	0.0 FID	0.001 FI	-39.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.8 FI	20.9 F	199.8 F
01/02/25 20:00	0.0 FID	0.001 FI	-32.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.7 FI	20.9 F	199.8 F
01/02/25 21:00	43.1 U	0.085 E	37.6 E	0.0	0.0	0.0	67.6 EU	0.111 E	30.0 E	16.2	199.8
01/02/25 22:00	17.1 U	0.022	9.9	0.0	0.0	0.0	12.2 U	0.016	4.3	15.1	199.8
01/02/25 23:00	17.0	0.023	10.0	0.0	0.0	0.0	12.1	0.016	4.3	15.1	199.8
01/03/25 00:00	16.6	0.022	9.7	0.0	0.0	0.0	12.0	0.016	4.3	15.1	199.8
01/03/25 01:00	16.4	0.022	9.6	0.0	0.0	0.0	12.1	0.016	4.3	15.1	199.8
01/03/25 02:00	16.6	0.022	9.7	0.0	0.0	0.0	12.0	0.016	4.3	15.1	199.8
01/03/25 03:00	16.5	0.022	9.7	0.0	0.0	0.0	12.1	0.016	4.3	15.1	199.9
01/03/25 04:00	16.5	0.022	9.7	0.0	0.0	0.0	12.0	0.016	4.3	15.1	199.9
01/03/25 05:00	16.4	0.022	9.6	0.0	0.0	0.0	12.0	0.016	4.3	15.1	199.9
01/03/25 06:00	16.7	0.022	9.7	0.0	0.0	0.0	12.1	0.016	4.3	15.1	199.9
01/03/25 07:00	17.4 C	0.023	10.2	0.0	0.0	0.0 C	12.1 C	0.016	4.3	15.1 C	199.9
01/03/25 08:00	16.9	0.022	9.9	0.0	0.0	0.0	12.1	0.016	4.3	15.2	199.9
01/03/25 09:00	16.7	0.022	9.8	0.0	0.0	0.0	12.1	0.016	4.3	15.2	199.9
01/03/25 10:00	18.4	0.024	10.8	0.0	0.0	0.0	12.0	0.016	4.3	15.2	199.9
01/03/25 11:00	16.7	0.022	9.8	0.0	0.0	0.0	12.1	0.016	4.3	15.2	199.9
01/03/25 12:00	16.3	0.021	9.3	0.0	0.0	0.0	12.4	0.016	4.3	15.3	199.9
01/03/25 13:00	16.2	0.021	9.5	0.0	0.0	0.0	12.2	0.016	4.3	15.2	199.9
01/03/25 14:00	16.9	0.022	10.0	0.0	0.0	0.0	12.1	0.016	4.3	15.3	199.9
01/03/25 15:00	13.2	0.016	7.2	0.0	0.0	0.0	12.9	0.015	4.2	15.1	199.9
01/03/25 16:00	11.3	0.014	6.5	0.0	0.0	0.0	13.0	0.016	4.5	15.1	199.9
01/03/25 17:00	16.8	0.022	9.9	0.0	0.0	0.0	12.0	0.016	4.3	15.2	199.8
01/03/25 18:00	17.5	0.023	10.3	0.0	0.0	0.0	12.1	0.016	4.3	15.2	199.8
01/03/25 19:00	16.9	0.023	9.9	0.0	0.0	0.0	12.0	0.016	4.3	15.2	199.8



UNIT START UP

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/03/25 20:00	16.9	0.022	9.9	0.0	0.0	0.0	12.0	0.016	4.3	15.2	199.8
01/03/25 21:00	16.8	0.022	9.8	0.0	0.0	0.0	12.1	0.016	4.3	15.2	199.8
01/03/25 22:00	17.0	0.022	9.9	0.0	0.0	0.0	12.1	0.016	4.3	15.2	199.8
01/03/25 23:00	18.6	0.025	10.9	0.0	0.0	0.0	12.1	0.016	4.3	15.2	199.8
01/04/25 00:00	17.4	0.023	10.1	0.0	0.0	0.0	12.2	0.016	4.3	15.2	199.8
01/04/25 01:00	16.9	0.022	9.9	0.0	0.0	0.0	12.1	0.016	4.3	15.2	199.8
01/04/25 02:00	16.9	0.022	9.9	0.0	0.0	0.0	12.1	0.016	4.3	15.1	199.8
01/04/25 03:00	16.8	0.022	9.8	0.0	0.0	0.0	12.1	0.016	4.3	15.2	199.8
01/04/25 04:00	16.9	0.022	9.9	0.0	0.0	0.0	12.1	0.016	4.3	15.1	199.8
01/04/25 05:00	16.9	0.022	9.9	0.0	0.0	0.0	12.1	0.016	4.3	15.1	199.8
01/04/25 06:00	18.9	0.025	11.1	0.0	0.0	0.0	12.1	0.016	4.3	15.1	199.8
01/04/25 07:00	17.4 C	0.023	10.2	0.0	0.0	0.0 C	12.1 C	0.016	4.3	15.1 C	199.8
01/04/25 08:00	17.1	0.022	9.9	0.0	0.0	0.0	12.2	0.016	4.3	15.1	199.8
01/04/25 09:00	17.0	0.022	9.9	0.0	0.0	0.0	12.1	0.016	4.3	15.1	199.8
01/04/25 10:00	17.1	0.022	9.9	0.0	0.0	0.0	12.1	0.016	4.3	15.1	199.8
01/04/25 11:00	16.8	0.022	9.8	0.0	0.0	0.0	12.1	0.016	4.3	15.1	199.8
01/04/25 12:00	16.8	0.022	9.8	0.0	0.0	0.0	12.2	0.016	4.3	15.1	199.8
01/04/25 13:00	17.0	0.022	9.9	0.0	0.0	0.0	12.1	0.016	4.3	15.1	199.8
01/04/25 14:00	17.3	0.023	10.1	0.0	0.0	0.0	12.1	0.016	4.3	15.1	199.8
01/04/25 15:00	18.2	0.023	10.5	0.0	0.0	0.0	12.3	0.016	4.3	15.1	199.8
01/04/25 16:00	16.8	0.022	9.8	0.0	0.0	0.0	12.1	0.016	4.3	15.1	199.8
01/04/25 17:00	16.8	0.022	9.8	0.0	0.0	0.0	12.1	0.016	4.3	15.1	199.8
01/04/25 18:00	16.9	0.022	9.8	0.0	0.0	0.0	12.1	0.016	4.3	15.1	199.8
01/04/25 19:00	17.2	0.023	10.1	0.0	0.0	0.0	12.0	0.016	4.3	15.1	199.9
01/04/25 20:00	17.1	0.023	10.0	0.0	0.0	0.0	12.1	0.016	4.3	15.1	199.9
01/04/25 21:00	16.9	0.022	9.9	0.0	0.0	0.0	12.1	0.016	4.3	15.1	199.9
01/04/25 22:00	17.2	0.022	9.9	0.0	0.0	0.0	12.2	0.016	4.3	15.1	199.9
01/04/25 23:00	13.6	0.015	6.5	0.0	0.0	0.0	24.4 E	0.026 E	6.9 E	14.9	199.9
Primary Reignition											
01/05/25 00:00	12.8	0.016	7.0	0.0	0.0	0.0	13.3	0.016	4.4	15.1	199.9
01/05/25 01:00	17.0	0.022	10.0	0.0	0.0	0.0	12.1	0.016	4.3	15.1	199.9
01/05/25 02:00	16.8	0.022	9.9	0.0	0.0	0.0	12.1	0.016	4.3	15.1	199.9
01/05/25 03:00	16.9	0.022	9.9	0.0	0.0	0.0	12.1	0.016	4.3	15.1	199.9
01/05/25 04:00	16.7	0.022	9.8	0.0	0.0	0.0	12.0	0.016	4.3	15.1	199.9
01/05/25 05:00	16.9	0.022	9.9	0.0	0.0	0.0	12.1	0.016	4.3	15.1	199.9
01/05/25 06:00	17.5 D	0.023	10.2	0.0	0.0	0.0	12.1 D	0.016	4.3	15.1	199.9
01/05/25 07:00	91.2 ECD	0.234 E	104.4 E	0.0	0.0	0.0 C	39.6 ECD	0.097 E	26.4 E	16.5 C	199.8
UNIT SHUTDOWN											
01/05/25 08:00	0.0 FID	0.001 FI	-30.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	20.9 F	199.8 F

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/05/25 09:00	0.0 FID	0.001 FI	-42.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.6 FI	20.9 F	199.8 F
01/05/25 10:00	0.0 FID	0.001 FI	-29.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	20.9 F	199.8 F
01/05/25 11:00	0.0 FID	0.001 FI	-124.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-9.5 FI	20.9 F	199.8 F
01/05/25 12:00	0.0 FID	0.001 FI	-24.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.8 FI	20.9 F	199.8 F
01/05/25 13:00	0.0 FID	0.001 FI	-46.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.6 FI	20.9 F	199.8 F
01/05/25 14:00	0.0 FID	0.001 FI	-41.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.2 FI	20.9 F	199.8 F
01/05/25 15:00	0.0 FID	0.001 FI	-20.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	20.9 F	199.8 F
01/05/25 16:00	0.0 FID	0.001 FI	-28.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	20.9 F	199.8 F
01/05/25 17:00	0.0 FID	0.001 FI	-31.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.2 FI	20.9 F	199.8 F
01/05/25 18:00	0.0 FID	0.001 FI	-49.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.3 FI	20.9 F	199.8 F
01/05/25 19:00	0.0 FID	0.001 FI	-77.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-3.8 FI	20.9 F	199.8 F
01/05/25 20:00	0.0 FID	0.001 FI	-226.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-7.0 FI	20.9 F	199.8 F
01/05/25 21:00	69.6 EU	0.174 E	76.9 E	0.0	0.0	0.0	84.1 EU	0.133 E	35.7 E	17.2	199.8
01/05/25 22:00	18.2 U	0.022	10.0	0.0	0.0	0.0	13.6 U	0.016	4.4	15.1	199.9
01/05/25 23:00	19.5 D	0.023	10.4	0.0	0.0	0.0	13.2 D	0.016	4.3	15.1	199.9
01/06/25 00:00	80.3 ED	0.195 E	87.0 E	0.0	0.0	0.0	37.7 ED	0.087 E	23.6 E	16.3	199.8
01/06/25 01:00	0.0 FID	0.001 FI	-23.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.0 FI	20.9 F	199.9 F
01/06/25 02:00	0.0 FID	0.001 FI	-89.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.2 FI	20.9 F	199.8 F
01/06/25 03:00	0.0 FID	0.001 FI	-29.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.7 FI	20.9 F	199.9 F
01/06/25 04:00	0.0 FID	0.001 FI	-46.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.9 FI	20.9 F	199.8 F
01/06/25 05:00	0.0 FID	0.001 FI	-59.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.7 FI	20.9 F	199.9 F
01/06/25 06:00	0.0 FID	0.001 FI	-32.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	20.9 F	199.8 F
01/06/25 07:00	0.0 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.8 F
01/06/25 08:00	0.0 FID	0.001 FI	-32.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.0 FI	20.9 F	199.8 F
01/06/25 09:00	0.0 FID	0.001 FI	-32.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.7 FI	20.9 F	199.8 F
01/06/25 10:00	0.0 FID	0.001 FI	-37.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.8 FI	20.9 F	199.8 F
01/06/25 11:00	0.0 FID	0.001 FI	-29.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	20.9 F	199.8 F
01/06/25 12:00	0.0 FID	0.001 FI	-35.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.7 FI	20.9 F	199.8 F
01/06/25 13:00	0.0 FID	0.001 FI	-28.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	20.9 F	199.8 F
01/06/25 14:00	0.0 FID	0.001 FI	-38.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	20.9 F	199.8 F
01/06/25 15:00	0.0 FID	0.001 FI	-36.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.4 FI	20.9 F	199.8 F
01/06/25 16:00	0.0 FID	0.001 FI	-26.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	20.9 F	199.8 F
01/06/25 17:00	0.0 FID	0.001 FI	-29.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	20.9 F	199.8 F
01/06/25 18:00	0.0 FID	0.001 FI	-30.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	20.9 F	199.8 F
01/06/25 19:00	0.0 FID	0.001 FI	-39.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.0 FI	20.9 F	199.8 F
01/06/25 20:00	0.0 FID	0.001 FI	-38.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.9 FI	20.9 F	199.8 F
01/06/25 21:00	0.0 FID	0.001 FI	-29.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	20.9 F	199.8 F

UNIT START UP

UNIT SHUTDOWN

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/06/25 22:00	0.0 FID	0.001 FI	-36.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.7 FI	20.9 F	199.8 F
01/06/25 23:00	0.0 FID	0.001 FI	-31.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.7 FI	20.9 F	199.8 F
01/07/25 00:00	0.0 FID	0.001 FI	-23.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.8 F
01/07/25 01:00	0.0 FID	0.001 FI	-37.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	20.9 F	199.8 F
01/07/25 02:00	0.0 FID	0.001 FI	-26.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	21.0 F	199.8 F
01/07/25 03:00	0.0 FID	0.001 FI	-27.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	20.9 F	199.8 F
01/07/25 04:00	0.0 FID	0.001 FI	-38.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	20.9 F	199.8 F
01/07/25 05:00	0.0 FID	0.001 FI	-30.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	20.9 F	199.8 F
01/07/25 06:00	0.0 FID	0.001 FI	89.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.7 FIE	20.9 F	199.8 F
01/07/25 07:00	0.0 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.8 F
01/07/25 08:00	0.0 FID	0.001 FI	-12.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.8 F
01/07/25 09:00	0.0 FID	0.001 FI	-12.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.8 F
01/07/25 10:00	0.0 FID	0.001 FI	-12.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.5 FI	21.0 F	199.8 F
01/07/25 11:00	0.0 FID	0.001 FI	-13.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.8 F
01/07/25 12:00	0.0 FID	0.001 FI	-11.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.3 FI	21.0 F	199.8 F
01/07/25 13:00	0.0 FID	0.001 FI	-10.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.8 F
01/07/25 14:00	0.0 FID	0.001 FI	-10.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.4 FI	21.0 F	199.8 F
01/07/25 15:00	0.0 FID	0.001 FI	-11.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.8 F
01/07/25 16:00	0.0 FID	0.001 FI	-12.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.0 F	199.8 F
01/07/25 17:00	0.0 FID	0.001 FI	-10.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.8 F
01/07/25 18:00	0.0 FID	0.001 FI	-11.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.3 FI	21.0 F	199.8 F
01/07/25 19:00	0.0 FID	0.001 FI	-10.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.8 F
01/07/25 20:00	0.0 FID	0.001 FI	-8.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.4 FI	21.0 F	199.8 F
01/07/25 21:00	0.0 FID	0.001 FI	-10.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.8 F
01/07/25 22:00	0.0 FID	0.001 FI	-9.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
01/07/25 23:00	0.0 FID	0.001 FI	-9.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F
01/08/25 00:00	0.0 FID	0.001 FI	-8.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.9 F
01/08/25 01:00	0.0 FID	0.001 FI	-10.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F
01/08/25 02:00	0.0 FID	0.001 FI	-8.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.9 F
01/08/25 03:00	0.0 FID	0.001 FI	-9.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
01/08/25 04:00	0.0 FID	0.001 FI	-10.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.9 F
01/08/25 05:00	0.0 FID	0.001 FI	-9.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
01/08/25 06:00	0.0 FID	0.001 FI	-10.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.9 F
01/08/25 07:00	0.0 FIC	0.011 FI	5.0 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.9 F
01/08/25 08:00	0.0 FID	0.001 FI	182.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	12.9 FIE	20.9 F	199.9 F
01/08/25 09:00	0.0 FID	0.001 FI	245.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	13.5 FIE	20.9 F	199.9 F
01/08/25 10:00	0.0 FID	0.001 FI	-118.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-6.4 FI	20.9 F	199.9 F

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/08/25 11:00	0.0 FID	0.001 FI	289.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	24.3 FIE	20.9 F	199.9 F
01/08/25 12:00	0.0 FID	0.001 FI	125.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	6.8 FIE	20.9 F	199.9 F
01/08/25 13:00	0.0 FID	0.001 FI	-1,119.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-106.7 FI	20.9 F	199.9 F
01/08/25 14:00	0.0 FID	0.001 FI	-261.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-17.9 FI	20.9 F	199.9 F
01/08/25 15:00	0.0 FID	0.001 FI	4,886.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	420.8 FIE	20.9 F	199.9 F
01/08/25 16:00	0.0 FID	0.001 FI	-208.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-9.2 FI	20.9 F	199.9 F
01/08/25 17:00	0.0 FID	0.001 FI	-405.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-32.9 FI	20.9 F	199.9 F
01/08/25 18:00	0.0 FID	0.001 FI	580.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	25.7 FIE	20.9 F	199.9 F
01/08/25 19:00	0.0 FID	0.001 FI	2,644.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	120.5 FIE	20.9 F	199.9 F
01/08/25 20:00	0.0 FID	0.001 FI	-78.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-6.7 FI	20.9 F	199.9 F
01/08/25 21:00	0.0 FID	0.001 FI	-117.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-8.2 FI	20.9 F	199.9 F
01/08/25 22:00	0.0 FID	0.001 FI	-258.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-19.5 FI	20.9 F	199.9 F
01/08/25 23:00	0.0 FID	0.001 FI	-210.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-12.4 FI	20.9 F	199.9 F
01/09/25 00:00	0.0 FID	0.001 FI	-1,385.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-83.4 FI	20.9 F	199.9 F
01/09/25 01:00	0.0 FID	0.001 FI	-91.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.6 FI	20.9 F	199.9 F
01/09/25 02:00	0.0 FID	0.001 FI	-50.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.3 FI	20.9 F	199.9 F
01/09/25 03:00	0.0 FID	0.001 FI	-32.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.9 F
01/09/25 04:00	0.0 FID	0.001 FI	-36.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	21.0 F	199.9 F
01/09/25 05:00	0.0 FID	0.001 FI	-37.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.9 F
01/09/25 06:00	0.0 FID	0.001 FI	-33.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	21.0 F	199.9 F
01/09/25 07:00	0.0 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.9 F
01/09/25 08:00	0.0 FID	0.001 FI	-5,819.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-5,135.2 FI	20.9 F	199.9 F
01/09/25 09:00	0.2 FID	0.001 FI	0.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.4 FI	20.9 F	199.9 F
01/09/25 10:00	0.3 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.5 FI	20.9 F	199.9 F
01/09/25 11:00	0.4 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.4 FI	20.9 F	199.9 F
01/09/25 12:00	0.3 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.8 F	199.9 F
01/09/25 13:00	0.3 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.1 FI	20.8 F	199.9 F
01/09/25 14:00	0.3 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.9 FI	20.8 F	199.9 F
01/09/25 15:00	0.3 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.7 FI	20.8 F	199.9 F
01/09/25 16:00	0.3 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.1 FI	20.8 F	199.9 F
01/09/25 17:00	0.3 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.3 FIE	20.9 F	199.9 F
01/09/25 18:00	0.4 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.1 FI	20.8 F	199.9 F
01/09/25 19:00	0.2 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.7 FI	20.9 F	199.9 F
01/09/25 20:00	0.2 FID	0.001 FI	0.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.8 FI	20.9 F	199.9 F
01/09/25 21:00	0.2 FID	0.001 FI	0.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.1 FI	20.9 F	199.9 F
01/09/25 22:00	0.1 FID	0.001 FI	0.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.4 FIE	20.9 F	199.9 F
01/09/25 23:00	0.2 FID	0.001 FI	0.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	7.4 FIE	20.9 F	199.9 F

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/10/25 00:00	0.1 FID	0.001 FI	0.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.4 FIE	20.9 F	199.9 F
01/10/25 01:00	0.1 FID	0.001 FI	0.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.4 FI	20.9 F	199.9 F
01/10/25 02:00	0.1 FID	0.001 FI	1.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	11.5 FIE	20.9 F	199.9 F
01/10/25 03:00	0.0 FID	0.001 FI	15.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	22.9 FIE	20.9 F	199.9 F
01/10/25 04:00	0.0 FID	0.001 FI	-19.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-17.8 FI	20.9 F	199.9 F
01/10/25 05:00	0.0 FID	0.001 FI	-14.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.9 FI	20.9 F	199.9 F
01/10/25 06:00	0.0 FID	0.001 FI	-18.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-5.2 FI	20.9 F	199.9 F
01/10/25 07:00	0.0 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.1 FC	199.9 F
01/10/25 08:00	0.0 FID	0.013 FI	2.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.8 F	199.9 F
01/10/25 09:00	0.0 FID	0.001 FI	0.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.7 F	199.9 F
01/10/25 10:00	0.0 FID	0.001 FI	0.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.7 F	199.8 F
01/10/25 11:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.7 F	199.9 F
01/10/25 12:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.7 F	199.9 F
01/10/25 13:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.7 F	199.9 F
01/10/25 14:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.7 F	199.8 F
01/10/25 15:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.7 F	199.8 F
01/10/25 16:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.7 F	199.9 F
01/10/25 17:00	0.0 FID	0.001 FI	0.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.7 F	199.9 F
01/10/25 18:00	0.0 FID	0.013 FI	3.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.8 F	199.9 F
01/10/25 19:00	0.0 FID	0.013 FI	9.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.0 FI	20.8 F	199.8 F
01/10/25 20:00	0.0 FID	0.026 FI	15.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.8 F	199.9 F
01/10/25 21:00	0.0 FID	0.026 FI	15.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.8 F	199.9 F
01/10/25 22:00	0.0 FID	0.026 FI	16.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.8 F	199.9 F
01/10/25 23:00	0.0 FID	0.026 FI	15.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.8 F	199.8 F
01/11/25 00:00	0.0 FID	0.026 FI	13.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.1 FI	20.8 F	199.8 F
01/11/25 01:00	0.0 FID	0.026 FI	14.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.0 FI	20.8 F	199.8 F
01/11/25 02:00	0.0 FID	0.026 FI	13.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.0 FI	20.8 F	199.9 F
01/11/25 03:00	0.0 FID	0.026 FI	13.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.0 FI	20.8 F	199.8 F
01/11/25 04:00	0.0 FID	0.026 FI	13.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.8 F	199.8 F
01/11/25 05:00	0.0 FID	0.026 FI	12.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.8 F	199.9 F
01/11/25 06:00	0.0 FID	0.013 FI	4.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.8 F	199.8 F
01/11/25 07:00	0.0 FIC	0.011 FI	5.0 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.1 FC	199.8 F
01/11/25 08:00	0.0 FID	0.001 FI	-165.3 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-2.0 FI	20.9 F	199.8 F
01/11/25 09:00	0.0 FID	0.001 FI	18.9 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.2 FI	20.9 F	199.8 F
01/11/25 10:00	0.0 FID	0.001 FI	6.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.3 FI	20.9 F	199.8 F
01/11/25 11:00	0.0 FID	0.001 FI	3.1 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.4 FI	20.9 F	199.8 F
01/11/25 12:00	0.0 FID	0.001 FI	3.0 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.1 FI	20.9 F	199.8 F

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/11/25 13:00	0.0 FID	0.001 FI	0.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.2 FI	20.9 F	199.8 F
01/11/25 14:00	0.0 FID	0.001 FI	4.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.1 FI	20.9 F	199.8 F
01/11/25 15:00	0.0 FID	0.001 FI	14.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.8 FI	20.9 F	199.9 F
01/11/25 16:00	0.0 FID	0.001 FI	-46.7 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.2 FI	20.9 F	199.8 F
01/11/25 17:00	0.0 FID	0.001 FI	-31.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.1 FI	20.9 F	199.8 F
01/11/25 18:00	0.0 FID	0.001 FI	-22.4 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.2 FI	20.9 F	199.8 F
01/11/25 19:00	0.0 FID	0.001 FI	-26.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.4 FI	20.9 F	199.8 F
01/11/25 20:00	0.0 FID	0.001 FI	-20.5 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
01/11/25 21:00	0.0 FID	0.001 FI	-27.9 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.2 FI	20.9 F	199.9 F
01/11/25 22:00	0.0 FID	0.001 FI	-27.4 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	20.9 F	199.9 F
01/11/25 23:00	0.0 FID	0.001 FI	-21.3 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
01/12/25 00:00	0.0 FID	0.001 FI	-24.1 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	-0.1 FI	20.9 F	199.9 F
01/12/25 01:00	0.0 FID	0.001 FI	-29.4 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.3 FI	20.9 F	199.9 F
01/12/25 02:00	0.0 FID	0.001 FI	-19.3 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
01/12/25 03:00	0.0 FID	0.001 FI	-20.1 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
01/12/25 04:00	0.0 FID	0.001 FI	-18.4 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
01/12/25 05:00	0.0 FID	0.001 FI	-21.9 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
01/12/25 06:00	0.0 FID	0.001 FI	-20.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
01/12/25 07:00	0.0 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.1 FIC	0.023 F	6.3 F	14.2 FC	199.9 F
01/12/25 08:00	0.0 FID	0.001 FI	-7.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
01/12/25 09:00	0.0 FID	0.001 FI	-6.1 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
01/12/25 10:00	0.0 FID	0.001 FI	-6.0 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
01/12/25 11:00	0.0 FID	0.001 FI	-5.2 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
01/12/25 12:00	0.0 FID	0.001 FI	-5.3 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
01/12/25 13:00	0.0 FID	0.001 FI	-5.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
01/12/25 14:00	0.0 FID	0.001 FI	-4.7 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
01/12/25 15:00	0.0 FID	0.001 FI	-5.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
01/12/25 16:00	0.0 FID	0.001 FI	-5.9 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
01/12/25 17:00	0.0 FID	0.001 FI	-7.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
01/12/25 18:00	0.0 FID	0.001 FI	-7.5 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
01/12/25 19:00	0.0 FID	0.001 FI	-9.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
01/12/25 20:00	0.0 FID	0.001 FI	-8.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
01/12/25 21:00	0.0 FID	0.001 FI	-8.0 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
01/12/25 22:00	0.0 FID	0.001 FI	-8.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
01/12/25 23:00	0.0 FID	0.001 FI	-8.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
01/13/25 00:00	0.0 FID	0.001 FI	-9.0 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
01/13/25 01:00	0.0 FID	0.001 FI	-7.9 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.0 F	199.9 F

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/13/25 02:00	0.0 FID	0.001 FI	-9.2 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
01/13/25 03:00	0.0 FID	0.001 FI	-9.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
01/13/25 04:00	0.0 FID	0.001 FI	-7.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
01/13/25 05:00	0.0 FID	0.001 FI	-8.0 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
01/13/25 06:00	0.0 FID	0.001 FI	-7.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
01/13/25 07:00	0.0 FIC	0.013 FI	5.7 FI	0.0 F	0.0 F	0.0 FIC	0.1 FIC	0.023 F	6.3 F	14.2 FC	199.9 F
01/13/25 08:00	0.0 FID	0.001 FI	-23.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-35.5 FI	20.9 F	199.9 F
01/13/25 09:00	0.2 FID	0.001 FI	2.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	36.5 FIE	20.9 F	199.9 F
01/13/25 10:00	0.3 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	21.9 FIE	20.9 F	199.8 F
01/13/25 11:00	0.3 FID	0.001 FI	4.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	81.9 FIE	20.9 F	199.8 F
01/13/25 12:00	0.2 FID	0.001 FI	2.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	31.9 FIE	20.9 F	199.8 F
01/13/25 13:00	0.1 FID	0.001 FI	-2.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-23.4 FI	20.9 F	199.8 F
01/13/25 14:00	0.1 FID	0.001 FI	6.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	22.2 FIE	20.9 F	199.8 F
01/13/25 15:00	0.1 FID	0.001 FI	-5.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-25.4 FI	20.9 F	199.8 F
01/13/25 16:00	0.1 FID	0.001 FI	-18.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-91.4 FI	20.9 F	199.8 F
01/13/25 17:00	0.0 FID	0.001 FI	-12.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-44.1 FI	20.9 F	199.8 F
01/13/25 18:00	0.0 FID	0.001 FI	-14.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-24.2 FI	20.9 F	199.8 F
01/13/25 19:00	0.0 FID	0.001 FI	-8.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-19.1 FI	20.9 F	199.8 F
01/13/25 20:00	0.0 FID	0.001 FI	-12.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-39.2 FI	20.9 F	199.8 F
01/13/25 21:00	0.0 FID	0.001 FI	-86.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-112.4 FI	20.9 F	199.8 F
01/13/25 22:00	0.0 FID	0.001 FI	40.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	81.3 FIE	20.9 F	199.8 F
01/13/25 23:00	0.0 FID	0.001 FI	-18.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-24.4 FI	20.9 F	199.8 F
01/14/25 00:00	0.0 FID	0.001 FI	-19.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-20.0 FI	20.9 F	199.8 F
01/14/25 01:00	0.0 FID	0.001 FI	-11.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-11.0 FI	20.9 F	199.8 F
01/14/25 02:00	0.0 FID	0.001 FI	-62.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-71.1 FI	20.9 F	199.8 F
01/14/25 03:00	0.0 FID	0.001 FI	-29.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-37.0 FI	20.9 F	199.8 F
01/14/25 04:00	0.0 FID	0.001 FI	-5.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-13.3 FI	20.9 F	199.8 F
01/14/25 05:00	0.0 FID	0.001 FI	-22.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-42.1 FI	20.9 F	199.8 F
01/14/25 06:00	0.0 FIM	0.001 FI	-13.1 FI	0.0 F	0.0 F	0.0 FIM	0.0 FIM	0.001 FI	-12.7 FI	20.9 FM	199.8 F
01/14/25 07:00	0.0 FIC	0.013 FI	5.7 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.2 FC	199.8 F
01/14/25 08:00	0.0 FID	0.001 FI	-18.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-7.9 FI	20.9 F	199.8 F
01/14/25 09:00	0.0 FID	0.001 FI	-34.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-44.0 FI	20.9 F	199.8 F
01/14/25 10:00	0.2 FID	0.001 FI	0.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	7.5 FIE	20.9 F	199.8 F
01/14/25 11:00	0.3 FID	0.001 FI	0.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	11.4 FIE	20.9 F	199.8 F
01/14/25 12:00	0.2 FID	0.001 FI	0.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	14.2 FIE	20.9 F	199.8 F
01/14/25 13:00	0.2 FID	0.001 FI	1.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	13.7 FIE	20.9 F	199.8 F
01/14/25 14:00	0.1 FID	0.001 FI	3.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	12.1 FIE	20.9 F	199.9 F

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/14/25 15:00	0.1 FID	0.001 FI	16.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	54.0 FIE	20.9 F	199.8 F
01/14/25 16:00	0.1 FID	0.001 FI	-48.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-100.8 FI	20.9 F	199.9 F
01/14/25 17:00	0.0 FID	0.001 FI	-11.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-9.2 FI	20.9 F	199.8 F
01/14/25 18:00	0.0 FID	0.001 FI	-14.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.0 FI	20.9 F	199.9 F
01/14/25 19:00	0.0 FID	0.001 FI	-17.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-5.7 FI	20.9 F	199.9 F
01/14/25 20:00	0.0 FID	0.001 FI	-18.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.2 FI	20.9 F	199.9 F
01/14/25 21:00	0.0 FID	0.001 FI	-21.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-5.4 FI	20.9 F	199.8 F
01/14/25 22:00	0.0 FID	0.001 FI	-20.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.5 FI	20.9 F	199.8 F
01/14/25 23:00	0.0 FID	0.001 FI	-22.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-8.4 FI	20.9 F	199.8 F
01/15/25 00:00	0.0 FID	0.001 FI	-25.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-5.9 FI	20.9 F	199.8 F
01/15/25 01:00	0.0 FID	0.001 FI	-28.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-6.1 FI	20.9 F	199.8 F
01/15/25 02:00	0.0 FID	0.001 FI	-22.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-7.8 FI	20.9 F	199.8 F
01/15/25 03:00	0.3 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.4 FI	20.8 F	199.8 F
01/15/25 04:00	0.4 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.4 FIE	20.9 F	199.8 F
01/15/25 05:00	0.3 FID	0.001 FI	0.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	7.3 FIE	20.9 F	199.8 F
01/15/25 06:00	0.2 FID	0.001 FI	0.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	9.3 FIE	20.9 F	199.8 F
01/15/25 07:00	0.0 FIC	0.013 FI	5.8 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.2 FC	199.8 F
01/15/25 08:00	0.0 FID	0.001 FI	-43.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.1 FI	20.9 F	199.8 F
01/15/25 09:00	0.0 FID	0.001 FI	24.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.3 FI	20.9 F	199.8 F
01/15/25 10:00	0.0 FID	0.001 FI	6.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.0 FI	20.9 F	199.8 F
01/15/25 11:00	0.0 FID	0.001 FI	4.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.7 FI	20.9 F	199.8 F
01/15/25 12:00	0.0 FID	0.001 FI	3.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.4 FI	20.9 F	199.8 F
01/15/25 13:00	0.0 FID	0.001 FI	2.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.8 FI	20.9 F	199.8 F
01/15/25 14:00	0.0 FID	0.001 FI	4.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.6 FI	20.9 F	199.8 F
01/15/25 15:00	0.0 FID	0.001 FI	5.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.0 FI	20.9 F	199.8 F
01/15/25 16:00	0.0 FID	0.001 FI	4.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.8 FI	20.9 F	199.8 F
01/15/25 17:00	0.0 FID	0.001 FI	3.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.6 FI	20.9 F	199.8 F
01/15/25 18:00	0.0 FID	0.001 FI	3.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.9 F	199.8 F
01/15/25 19:00	0.0 FID	0.001 FI	5.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.6 FI	20.9 F	199.8 F
01/15/25 20:00	0.0 FID	0.001 FI	8.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.4 FI	20.9 F	199.8 F
01/15/25 21:00	0.0 FID	0.001 FI	11.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.0 FI	20.9 F	199.8 F
01/15/25 22:00	0.0 FID	0.001 FI	31.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.8 FI	20.9 F	199.8 F
01/15/25 23:00	0.0 FID	0.001 FI	15.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.9 FI	20.9 F	199.8 F
01/16/25 00:00	0.0 FID	0.001 FI	195.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	23.5 FIE	20.9 F	199.8 F
01/16/25 01:00	0.0 FID	0.001 FI	-144.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-15.1 FI	20.9 F	199.8 F
01/16/25 02:00	0.0 FID	0.001 FI	165.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	12.6 FIE	20.9 F	199.8 F
01/16/25 03:00	0.0 FID	0.001 FI	-67.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.5 FI	20.9 F	199.8 F

Source		UNIT_B										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/16/25	04:00	0.0 FID	0.001 FI	-41.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.7 FI	20.9 F	199.8 F
01/16/25	05:00	0.0 FID	0.001 FI	-45.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.1 FI	20.9 F	199.8 F
01/16/25	06:00	0.0 FID	0.001 FI	-43.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.7 FI	20.9 F	199.8 F
01/16/25	07:00	0.0 FIC	0.011 FI	4.9 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.2 FC	199.8 F
01/16/25	08:00	0.0 FID	0.013 FI	3.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
01/16/25	09:00	0.0 FID	0.001 FI	0.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
01/16/25	10:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.7 F	199.8 F
01/16/25	11:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.7 F	199.8 F
01/16/25	12:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.7 F	199.8 F
01/16/25	13:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.7 F	199.8 F
01/16/25	14:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.7 F	199.8 F
01/16/25	15:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.7 F	199.8 F
01/16/25	16:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.7 F	199.8 F
01/16/25	17:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.7 F	199.8 F
01/16/25	18:00	0.0 FID	0.001 FI	0.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.7 F	199.8 F
01/16/25	19:00	0.0 FID	0.001 FI	1.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
01/16/25	20:00	0.0 FID	0.013 FI	3.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
01/16/25	21:00	0.0 FID	0.013 FI	3.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
01/16/25	22:00	0.0 FID	0.013 FI	4.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
01/16/25	23:00	0.0 FID	0.013 FI	4.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
01/17/25	00:00	0.0 FID	0.013 FI	5.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
01/17/25	01:00	0.0 FID	0.013 FI	7.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
01/17/25	02:00	0.0 FID	0.026 FI	15.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
01/17/25	03:00	0.0 FID	0.026 FI	14.4 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
01/17/25	04:00	0.0 FID	0.026 FI	15.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
01/17/25	05:00	0.0 FID	0.026 FI	16.0 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
01/17/25	06:00	0.0 FID	0.026 FI	15.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
01/17/25	07:00	0.0 FIC	0.011 FI	5.0 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.2 FC	199.8 F
01/17/25	08:00	0.0 FIM	0.012 FI	5.3 FI	0.0 F	0.0 F	0.0 FIM	0.1 FIM	0.026 F	7.1 F	15.0 FMC	199.8 F
01/17/25	09:00	0.0 FIC	0.021 FI	9.9 FI	0.0 F	0.0 F	0.0 FIC	0.4 FIC	0.001 FI	0.3 FI	20.1 FC	199.8 F
01/17/25	10:00	0.2 FID	0.001 FI	0.1 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
01/17/25	11:00	0.3 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
01/17/25	12:00	0.2 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.1 FI	20.8 F	199.8 F
01/17/25	13:00	0.3 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
01/17/25	14:00	0.2 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
01/17/25	15:00	0.2 FID	0.001 FI	0.1 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
01/17/25	16:00	0.2 FID	0.001 FI	0.3 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.0 FI	20.9 F	199.8 F

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/17/25 17:00	0.0 FID	0.001 FI	207.7 FIE	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
01/17/25 18:00	0.0 FID	0.001 FI	-33.6 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
01/17/25 19:00	0.0 FID	0.001 FI	-34.0 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
01/17/25 20:00	0.0 FID	0.001 FI	-22.5 FI	0.0 F	0.0 F	0.0 FI	0.6 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
01/17/25 21:00	0.0 FID	0.001 FI	-15.8 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
01/17/25 22:00	0.0 FID	0.001 FI	-32.5 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
01/17/25 23:00	0.0 FID	0.001 FI	-23.8 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
01/18/25 00:00	0.0 FID	0.001 FI	-22.3 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
01/18/25 01:00	0.0 FID	0.001 FI	-22.9 FI	0.0 F	0.0 F	0.0 FI	0.6 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
01/18/25 02:00	0.0 FID	0.001 FI	-33.9 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	-0.1 FI	20.9 F	199.8 F
01/18/25 03:00	0.0 FID	0.001 FI	-22.5 FI	0.0 F	0.0 F	0.0 FI	0.6 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
01/18/25 04:00	0.0 FID	0.001 FI	-36.1 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
01/18/25 05:00	0.0 FID	0.001 FI	-25.8 FI	0.0 F	0.0 F	0.0 FI	0.6 FID	0.001 FI	-0.1 FI	20.9 F	199.8 F
01/18/25 06:00	0.0 FID	0.001 FI	-24.2 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
01/18/25 07:00	0.0 FIC	0.011 FI	4.9 FI	0.0 F	0.0 F	0.0 FIC	0.1 FIC	0.023 F	6.2 F	14.2 FC	199.8 F
01/18/25 08:00	0.0 FID	0.001 FI	9.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.9 F	199.8 F
01/18/25 09:00	0.0 FID	0.001 FI	2.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.8 F	199.8 F
01/18/25 10:00	0.1 FID	0.001 FI	0.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.8 F	199.8 F
01/18/25 11:00	0.1 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.8 F
01/18/25 12:00	0.1 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.8 F
01/18/25 13:00	0.2 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.8 F
01/18/25 14:00	0.1 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.8 F
01/18/25 15:00	0.2 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.8 F	199.8 F
01/18/25 16:00	0.1 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.8 F
01/18/25 17:00	0.2 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.8 F	199.8 F
01/18/25 18:00	0.1 FID	0.001 FI	0.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.8 F
01/18/25 19:00	0.0 FID	0.001 FI	1.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.8 F	199.8 F
01/18/25 20:00	0.0 FID	0.001 FI	1.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.8 F
01/18/25 21:00	0.0 FID	0.001 FI	3.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.9 F	199.8 F
01/18/25 22:00	0.0 FID	0.001 FI	6.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.5 FI	20.9 F	199.8 F
01/18/25 23:00	0.0 FID	0.001 FI	12.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	3.0 FI	20.9 F	199.8 F
01/19/25 00:00	0.0 FID	0.001 FI	15.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	1.0 FI	20.9 F	199.8 F
01/19/25 01:00	0.0 FID	0.001 FI	15.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	1.3 FI	20.9 F	199.8 F
01/19/25 02:00	0.0 FID	0.001 FI	13.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.4 FI	20.9 F	199.8 F
01/19/25 03:00	0.0 FID	0.001 FI	23.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.7 FI	20.9 F	199.8 F
01/19/25 04:00	0.0 FID	0.001 FI	22.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.7 FI	20.9 F	199.8 F
01/19/25 05:00	0.0 FID	0.001 FI	21.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.5 FI	20.9 F	199.8 F

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/19/25 06:00	0.0 FID	0.001 FI	301.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	24.0 FIE	20.9 F	199.8 F
01/19/25 07:00	0.0 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.2 FC	199.8 F
01/19/25 08:00	0.0 FID	0.001 FI	-895.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-57.3 FI	20.9 F	199.8 F
01/19/25 09:00	0.0 FID	0.001 FI	21.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	1.5 FI	20.9 F	199.8 F
01/19/25 10:00	0.0 FID	0.001 FI	1.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.8 F	199.8 F
01/19/25 11:00	0.1 FID	0.001 FI	0.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.8 F	199.8 F
01/19/25 12:00	0.1 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.8 F	199.8 F
01/19/25 13:00	0.1 FID	0.001 FI	0.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.8 F	199.8 F
01/19/25 14:00	0.0 FID	0.001 FI	0.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.8 F	199.8 F
01/19/25 15:00	0.0 FID	0.001 FI	1.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.8 F	199.8 F
01/19/25 16:00	0.0 FID	0.001 FI	7.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.9 FI	20.9 F	199.8 F
01/19/25 17:00	0.0 FID	0.001 FI	53.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	6.2 FIE	20.9 F	199.8 F
01/19/25 18:00	0.0 FID	0.001 FI	141.3 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	5.4 FIE	20.9 F	199.8 F
01/19/25 19:00	0.0 FID	0.001 FI	88.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	6.3 FIE	20.9 F	199.8 F
01/19/25 20:00	0.0 FID	0.001 FI	1,738.9 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	69.6 FIE	20.9 F	199.8 F
01/19/25 21:00	0.0 FID	0.001 FI	-114.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-6.3 FI	20.9 F	199.8 F
01/19/25 22:00	0.0 FID	0.001 FI	485.8 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	12.4 FIE	20.9 F	199.8 F
01/19/25 23:00	0.0 FID	0.001 FI	-60.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.3 FI	20.9 F	199.8 F
01/20/25 00:00	0.0 FID	0.001 FI	-187.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-8.3 FI	20.9 F	199.8 F
01/20/25 01:00	0.0 FID	0.001 FI	-85.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.5 FI	20.9 F	199.8 F
01/20/25 02:00	0.0 FID	0.001 FI	-505.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-25.9 FI	20.9 F	199.8 F
01/20/25 03:00	0.0 FID	0.001 FI	-1,333.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-52.7 FI	20.9 F	199.8 F
01/20/25 04:00	0.0 FID	0.001 FI	-146.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-6.8 FI	20.9 F	199.8 F
01/20/25 05:00	0.0 FID	0.001 FI	276.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	16.1 FIE	20.9 F	199.8 F
01/20/25 06:00	0.0 FID	0.001 FI	-193.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-7.2 FI	20.9 F	199.8 F
01/20/25 07:00	0.0 FIC	0.011 FI	5.0 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.8 F
01/20/25 08:00	0.0 FID	0.013 FI	9.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.7 FI	20.8 F	199.8 F
01/20/25 09:00	0.0 FID	0.013 FI	4.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.0 FI	20.8 F	199.8 F
01/20/25 10:00	0.0 FID	0.001 FI	0.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.8 F	199.8 F
01/20/25 11:00	0.0 FID	0.001 FI	0.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.8 F	199.8 F
01/20/25 12:00	0.0 FID	0.001 FI	0.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.8 F	199.8 F
01/20/25 13:00	0.0 FID	0.001 FI	0.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.8 F	199.8 F
01/20/25 14:00	0.0 FID	0.001 FI	0.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.8 F	199.8 F
01/20/25 15:00	0.0 FID	0.001 FI	1.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.8 F	199.8 F
01/20/25 16:00	0.0 FID	0.001 FI	1.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.1 FI	20.8 F	199.8 F
01/20/25 17:00	0.0 FID	0.001 FI	2.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.8 F	199.8 F
01/20/25 18:00	0.0 FID	0.013 FI	5.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.8 F	199.8 F

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/20/25 19:00	0.0 FID	0.013 FI	9.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.1 FI	20.8 F	199.8 F
01/20/25 20:00	0.0 FID	0.013 FI	8.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.8 F	199.8 F
01/20/25 21:00	0.0 FID	0.013 FI	8.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.1 FI	20.8 F	199.8 F
01/20/25 22:00	0.0 FID	0.013 FI	11.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.1 FI	20.8 F	199.8 F
01/20/25 23:00	0.0 FID	0.013 FI	15.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.0 FI	20.8 F	199.8 F
01/21/25 00:00	0.0 FID	0.013 FI	9.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.8 F	199.8 F
01/21/25 01:00	0.0 FID	0.013 FI	9.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.7 FI	20.8 F	199.8 F
01/21/25 02:00	0.0 FID	0.013 FI	10.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.7 FI	20.8 F	199.8 F
01/21/25 03:00	0.0 FID	0.001 FI	16.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.1 FI	20.9 F	199.8 F
01/21/25 04:00	0.0 FID	0.001 FI	25.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.4 FI	20.9 F	199.8 F
01/21/25 05:00	0.0 FID	0.001 FI	29.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.1 FI	20.9 F	199.8 F
01/21/25 06:00	0.0 FID	0.001 FI	35.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.3 FI	20.9 F	199.8 F
01/21/25 07:00	0.0 FIC	0.012 FI	5.2 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.024 F	6.5 F	14.2 FC	199.8 F
01/21/25 08:00	0.0 FID	0.001 FI	23.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	11.5 FIE	20.9 F	199.8 F
01/21/25 09:00	0.0 FID	0.001 FI	5.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.8 FI	20.9 F	199.8 F
01/21/25 10:00	0.2 FID	0.001 FI	0.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.6 FI	20.8 F	199.8 F
01/21/25 11:00	0.1 FID	0.001 FI	0.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.9 FI	20.8 F	199.8 F
01/21/25 12:00	0.1 FID	0.001 FI	0.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.3 FI	20.8 F	199.8 F
01/21/25 13:00	0.0 FID	0.001 FI	2.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.4 FI	20.8 F	199.8 F
01/21/25 14:00	0.0 FID	0.001 FI	5.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.9 FIE	20.9 F	199.8 F
01/21/25 15:00	0.0 FID	0.001 FI	9.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	6.1 FIE	20.9 F	199.8 F
01/21/25 16:00	0.0 FID	0.001 FI	19.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	11.3 FIE	20.9 F	199.8 F
01/21/25 17:00	0.0 FID	0.001 FI	109.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	42.8 FIE	20.9 F	199.8 F
01/21/25 18:00	0.0 FID	0.001 FI	-54.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-13.4 FI	20.9 F	199.8 F
01/21/25 19:00	0.0 FID	0.001 FI	-41.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-11.1 FI	20.9 F	199.8 F
01/21/25 20:00	0.0 FID	0.001 FI	-60.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-12.6 FI	20.9 F	199.8 F
01/21/25 21:00	0.0 FID	0.001 FI	-303.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-67.9 FI	20.9 F	199.8 F
01/21/25 22:00	0.0 FID	0.001 FI	-54.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-10.2 FI	20.9 F	199.8 F
01/21/25 23:00	0.0 FID	0.001 FI	-58.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-12.5 FI	20.9 F	199.8 F
01/22/25 00:00	0.0 FID	0.001 FI	-150.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-29.5 FI	20.9 F	199.8 F
01/22/25 01:00	0.0 FID	0.001 FI	-36.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-7.8 FI	20.9 F	199.8 F
01/22/25 02:00	0.0 FID	0.001 FI	-107.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-26.0 FI	20.9 F	199.8 F
01/22/25 03:00	0.0 FID	0.001 FI	203.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	46.0 FIE	20.9 F	199.8 F
01/22/25 04:00	0.0 FID	0.001 FI	-54.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-13.0 FI	20.9 F	199.8 F
01/22/25 05:00	0.0 FID	0.001 FI	-289.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-57.5 FI	20.9 F	199.8 F
01/22/25 06:00	0.0 FID	0.001 FI	-137.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-35.0 FI	20.9 F	199.8 F
01/22/25 07:00	0.0 FIC	0.011 FI	5.0 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.2 FC	199.8 F

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/22/25 08:00	0.0 FID	0.001 FI	27.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.9 F	199.8 F
01/22/25 09:00	0.0 FID	0.001 FI	6.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.3 FI	20.9 F	199.8 F
01/22/25 10:00	0.0 FID	0.001 FI	1.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.8 F
01/22/25 11:00	0.1 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.2 FI	20.8 F	199.8 F
01/22/25 12:00	0.1 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.8 F
01/22/25 13:00	0.1 FID	0.001 FI	0.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.8 F
01/22/25 14:00	0.1 FID	0.001 FI	0.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.8 F
01/22/25 15:00	0.1 FID	0.001 FI	0.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.8 F
01/22/25 16:00	0.1 FID	0.001 FI	0.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.8 F	199.8 F
01/22/25 17:00	0.0 FID	0.001 FI	2.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.8 F	199.8 F
01/22/25 18:00	0.0 FID	0.001 FI	5.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.9 F	199.8 F
01/22/25 19:00	0.0 FID	0.001 FI	13.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.4 FI	20.9 F	199.8 F
01/22/25 20:00	0.0 FID	0.001 FI	14.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.3 FI	20.9 F	199.8 F
01/22/25 21:00	0.0 FID	0.001 FI	26.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.9 F	199.8 F
01/22/25 22:00	0.0 FID	0.001 FI	23.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.6 FI	20.9 F	199.8 F
01/22/25 23:00	0.0 FID	0.013 FI	9.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.4 FI	20.8 F	199.8 F
01/23/25 00:00	0.0 FID	0.001 FI	26.1 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	1.1 FI	20.9 F	199.8 F
01/23/25 01:00	0.0 FID	0.001 FI	26.1 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.6 FI	20.9 F	199.8 F
01/23/25 02:00	0.0 FID	0.001 FI	36.8 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	1.3 FI	20.9 F	199.8 F
01/23/25 03:00	0.0 FID	0.001 FI	74.0 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	3.1 FI	20.9 F	199.8 F
01/23/25 04:00	0.0 FID	0.001 FI	157.0 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	6.1 FIE	20.9 F	199.8 F
01/23/25 05:00	0.0 FID	0.001 FI	39.7 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.6 FI	20.9 F	199.8 F
01/23/25 06:00	0.0 FID	0.001 FI	77.0 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	3.2 FI	20.9 F	199.8 F
01/23/25 07:00	0.0 FIC	0.011 FI	5.0 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.8 F
01/23/25 08:00	0.0 FID	0.001 FI	-46.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-19.9 FI	20.9 F	199.8 F
01/23/25 09:00	0.0 FIM	0.001 FI	25.6 FIE	0.0 F	0.0 F	0.0 FIM	0.0 FIM	0.001 FI	22.4 FIE	20.9 FM	199.8 F
01/23/25 10:00	0.0 FIM	0.012 FI	5.3 FI	0.0 F	0.0 F	0.0 FIM	0.0 FIM	0.028 FIE	7.5 FIE	3.3 FM	199.8 F
01/23/25 11:00	0.0 FIM	0.009 FI	4.0 FI	0.0 F	0.0 F	0.0 FIM	0.0 FIM	0.018 F	5.0 FI	7.6 FMC	199.8 F
01/23/25 12:00	0.0 FID	0.001 FI	12.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	1.0 FI	20.9 F	199.8 F
01/23/25 13:00	0.0 FID	0.001 FI	11.3 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.5 FI	20.9 F	199.8 F
01/23/25 14:00	0.0 FID	0.001 FI	-46.4 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.6 FI	20.9 F	199.8 F
01/23/25 15:00	0.0 FID	0.001 FI	60.0 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	1.0 FI	20.9 F	199.8 F
01/23/25 16:00	0.0 FID	0.001 FI	-25.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.3 FI	20.9 F	199.8 F
01/23/25 17:00	0.0 FID	0.001 FI	-33.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	20.9 F	199.8 F
01/23/25 18:00	0.0 FID	0.001 FI	-24.4 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	20.9 F	199.8 F
01/23/25 19:00	0.0 FID	0.001 FI	-21.6 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
01/23/25 20:00	0.0 FID	0.001 FI	-22.7 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.0 F	199.8 F

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/23/25 21:00	0.0 FID	0.001 FI	-23.8 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
01/23/25 22:00	0.0 FID	0.001 FI	-23.5 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
01/23/25 23:00	0.0 FID	0.001 FI	-19.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
01/24/25 00:00	0.0 FID	0.001 FI	-20.0 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
01/24/25 01:00	0.0 FID	0.001 FI	-23.3 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.3 FI	21.0 F	199.8 F
01/24/25 02:00	0.0 FID	0.001 FI	-21.4 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
01/24/25 03:00	0.0 FID	0.001 FI	-19.7 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
01/24/25 04:00	0.0 FID	0.001 FI	-20.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
01/24/25 05:00	0.0 FID	0.001 FI	-20.7 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
01/24/25 06:00	0.0 FID	0.001 FI	-19.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
01/24/25 07:00	0.0 FIC	0.011 FI	5.0 FI	0.0 F	0.0 F	0.0 FIC	0.1 FIC	0.023 F	6.4 F	14.2 FC	199.8 F
01/24/25 08:00	0.0 FID	0.001 FI	99.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	44.9 FIE	20.9 F	199.8 F
01/24/25 09:00	0.0 FID	0.001 FI	6.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	7.7 FIE	20.9 F	199.8 F
01/24/25 10:00	0.0 FID	0.001 FI	0.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.7 FIE	20.9 F	199.8 F
01/24/25 11:00	0.0 FID	0.001 FI	0.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	6.3 FIE	20.9 F	199.8 F
01/24/25 12:00	0.0 FID	0.001 FI	1.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	6.6 FIE	20.9 F	199.8 F
01/24/25 13:00	0.0 FID	0.001 FI	3.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	8.5 FIE	20.9 F	199.8 F
01/24/25 14:00	0.0 FID	0.001 FI	3.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	7.9 FIE	20.9 F	199.8 F
01/24/25 15:00	0.0 FID	0.001 FI	5.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	13.3 FIE	20.9 F	199.8 F
01/24/25 16:00	0.0 FID	0.001 FI	6.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	8.8 FIE	20.9 F	199.8 F
01/24/25 17:00	0.0 FID	0.001 FI	24.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	22.3 FIE	20.9 F	199.8 F
01/24/25 18:00	0.0 FID	0.001 FI	-185.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-72.8 FI	20.9 F	199.8 F
01/24/25 19:00	0.0 FID	0.001 FI	85.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	31.8 FIE	20.9 F	199.8 F
01/24/25 20:00	0.0 FID	0.001 FI	-89.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-18.4 FI	20.9 F	199.8 F
01/24/25 21:00	0.0 FID	0.001 FI	-51.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-18.4 FI	20.9 F	199.8 F
01/24/25 22:00	0.0 FID	0.001 FI	-58.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-17.3 FI	20.9 F	199.8 F
01/24/25 23:00	0.0 FID	0.001 FI	-54.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-15.5 FI	20.9 F	199.8 F
01/25/25 00:00	0.0 FID	0.001 FI	-108.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-29.8 FI	20.9 F	199.8 F
01/25/25 01:00	0.0 FID	0.001 FI	-826.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-262.2 FI	20.9 F	199.8 F
01/25/25 02:00	0.0 FID	0.001 FI	-82.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-26.5 FI	20.9 F	199.8 F
01/25/25 03:00	0.0 FID	0.001 FI	-323.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-97.8 FI	20.9 F	199.8 F
01/25/25 04:00	0.0 FID	0.001 FI	-370.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-122.9 FI	20.9 F	199.8 F
01/25/25 05:00	0.0 FID	0.001 FI	569.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	174.8 FIE	20.9 F	199.8 F
01/25/25 06:00	0.0 FID	0.001 FI	-166.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-62.4 FI	20.9 F	199.8 F
01/25/25 07:00	0.0 FIC	0.011 FI	4.9 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.2 FC	199.8 F
01/25/25 08:00	0.0 FID	0.001 FI	-9.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	21.0 F	199.8 F
01/25/25 09:00	0.0 FID	0.001 FI	-2.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	20.9 F	199.8 F

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/25/25 10:00	0.1 FID	0.001 FI	-2.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-2.1 FI	20.9 F	199.8 F
01/25/25 11:00	0.2 FID	0.001 FI	-1.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.8 FI	20.9 F	199.8 F
01/25/25 12:00	0.1 FID	0.001 FI	-3.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-5.1 FI	20.9 F	199.8 F
01/25/25 13:00	0.2 FID	0.001 FI	1.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	1.9 FI	20.9 F	199.8 F
01/25/25 14:00	0.3 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.5 FI	20.9 F	199.8 F
01/25/25 15:00	0.4 FID	0.001 FI	0.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.9 F	199.8 F
01/25/25 16:00	0.6 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.6 FI	20.9 F	199.8 F
01/25/25 17:00	0.7 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.9 F	199.8 F
01/25/25 18:00	0.7 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	1.4 FI	20.9 F	199.8 F
01/25/25 19:00	0.6 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.9 F	199.8 F
01/25/25 20:00	0.7 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.9 FI	20.9 F	199.8 F
01/25/25 21:00	0.6 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.9 FI	20.9 F	199.8 F
01/25/25 22:00	0.5 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.7 FI	20.9 F	199.8 F
01/25/25 23:00	0.4 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.2 FI	20.9 F	199.8 F
01/26/25 00:00	0.4 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-439.1 FI	20.9 F	199.8 F
01/26/25 01:00	0.3 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	7.5 FIE	20.9 F	199.8 F
01/26/25 02:00	0.4 FID	0.001 FI	-0.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	20.9 F	199.8 F
01/26/25 03:00	0.4 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-42.3 FI	20.9 F	199.8 F
01/26/25 04:00	0.3 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-10.6 FI	20.9 F	199.8 F
01/26/25 05:00	0.5 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-8.2 FI	20.9 F	199.8 F
01/26/25 06:00	0.5 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	3.5 FI	20.9 F	199.8 F
01/26/25 07:00	0.2 FIC	0.011 FI	5.0 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.1 FC	199.8 F
01/26/25 08:00	0.0 FID	0.001 FI	11.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.1 FI	20.9 F	199.8 F
01/26/25 09:00	0.0 FID	0.001 FI	4.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.7 FI	20.9 F	199.8 F
01/26/25 10:00	0.0 FID	0.001 FI	1.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.8 F	199.8 F
01/26/25 11:00	0.1 FID	0.001 FI	1.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.2 FI	20.9 F	199.8 F
01/26/25 12:00	0.1 FID	0.001 FI	0.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.7 FI	20.8 F	199.8 F
01/26/25 13:00	0.1 FID	0.001 FI	0.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.8 F	199.8 F
01/26/25 14:00	0.0 FID	0.001 FI	0.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.8 F	199.8 F
01/26/25 15:00	0.0 FID	0.001 FI	0.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.9 FI	20.9 F	199.8 F
01/26/25 16:00	0.0 FID	0.001 FI	0.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.8 F	199.8 F
01/26/25 17:00	0.0 FID	0.001 FI	1.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.0 FI	20.9 F	199.8 F
01/26/25 18:00	0.0 FID	0.001 FI	1.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.5 FI	20.9 F	199.8 F
01/26/25 19:00	0.0 FID	0.001 FI	0.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.8 F	199.8 F
01/26/25 20:00	0.0 FID	0.001 FI	1.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.8 FI	20.9 F	199.8 F
01/26/25 21:00	0.0 FID	0.001 FI	3.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.7 FI	20.9 F	199.8 F
01/26/25 22:00	0.1 FID	0.001 FI	1.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.9 F	199.8 F

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/26/25 23:00	0.0 FID	0.001 FI	2.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.1 FI	20.9 F	199.8 F
01/27/25 00:00	0.0 FID	0.001 FI	1.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.6 FI	20.9 F	199.8 F
01/27/25 01:00	0.0 FID	0.001 FI	1.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.5 FI	20.9 F	199.8 F
01/27/25 02:00	0.0 FID	0.001 FI	2.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.2 FI	20.9 F	199.8 F
01/27/25 03:00	0.0 FID	0.001 FI	2.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.6 FI	20.8 F	199.8 F
01/27/25 04:00	0.0 FID	0.001 FI	3.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.1 FI	20.9 F	199.8 F
01/27/25 05:00	0.0 FID	0.001 FI	2.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.8 FI	20.9 F	199.8 F
01/27/25 06:00	0.0 FID	0.001 FI	4.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.6 FI	20.9 F	199.8 F
01/27/25 07:00	0.0 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.2 FC	199.8 F
01/27/25 08:00	0.0 FID	0.013 FI	6.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.5 FI	20.8 F	199.8 F
01/27/25 09:00	0.0 FID	0.007 FI	3.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.1 FI	20.7 F	199.8 F
01/27/25 10:00	0.0 FID	0.001 FI	1.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.7 F	199.8 F
01/27/25 11:00	0.0 FID	0.001 FI	0.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.0 FI	20.7 F	199.8 F
01/27/25 12:00	0.0 FID	0.001 FI	0.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.7 F	199.8 F
01/27/25 13:00	0.0 FID	0.001 FI	0.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.0 FI	20.7 F	199.8 F
01/27/25 14:00	0.0 FID	0.001 FI	0.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.0 FI	20.7 F	199.8 F
01/27/25 15:00	0.0 FID	0.001 FI	0.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.1 FI	20.7 F	199.8 F
01/27/25 16:00	0.0 FID	0.001 FI	0.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.7 F	199.8 F
01/27/25 17:00	0.0 FID	0.001 FI	0.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.7 F	199.8 F
01/27/25 18:00	0.0 FID	0.001 FI	0.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.7 F	199.8 F
01/27/25 19:00	0.0 FID	0.001 FI	0.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.1 FI	20.7 F	199.8 F
01/27/25 20:00	0.0 FID	0.007 FI	2.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.7 F	199.8 F
01/27/25 21:00	0.0 FID	0.013 FI	4.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.8 FI	20.8 F	199.8 F
01/27/25 22:00	0.0 FID	0.013 FI	4.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.0 FI	20.8 F	199.8 F
01/27/25 23:00	0.0 FID	0.026 FI	6.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.6 FI	20.8 F	199.8 F
01/28/25 00:00	0.0 FID	0.026 FI	6.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.8 F	199.8 F
01/28/25 01:00	0.0 FID	0.026 FI	8.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.8 FI	20.8 F	199.8 F
01/28/25 02:00	0.0 FID	0.026 FI	10.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.5 FI	20.8 F	199.8 F
01/28/25 03:00	0.0 FID	0.026 FI	10.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.9 FI	20.8 F	199.8 F
01/28/25 04:00	0.0 FID	0.026 FI	9.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.6 FI	20.8 F	199.9 F
01/28/25 05:00	0.0 FID	0.026 FI	11.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.7 FI	20.8 F	199.9 F
01/28/25 06:00	0.0 FID	0.026 FI	9.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.9 FI	20.8 F	199.9 F
01/28/25 07:00	0.0 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.2 FC	199.9 F
01/28/25 08:00	0.0 FID	0.001 FI	13.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.7 FI	20.9 F	199.8 F
01/28/25 09:00	0.0 FID	0.001 FI	3.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.6 FI	20.8 F	199.8 F
01/28/25 10:00	0.0 FID	0.001 FI	0.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.1 FI	20.8 F	199.8 F
01/28/25 11:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.5 FI	20.8 F	199.8 F

Source		UNIT_B										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/28/25	12:00	0.1 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.9 FI	20.8 F	199.8 F
01/28/25	13:00	0.0 FID	0.001 FI	0.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.6 FI	20.8 F	199.8 F
01/28/25	14:00	0.0 FID	0.001 FI	0.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.9 FI	20.8 F	199.9 F
01/28/25	15:00	0.0 FID	0.001 FI	2.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.2 FI	20.8 F	199.9 F
01/28/25	16:00	0.0 FID	0.013 FI	4.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.3 FI	20.8 F	199.9 F
01/28/25	17:00	0.0 FID	0.013 FI	6.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.8 FI	20.8 F	199.9 F
01/28/25	18:00	0.0 FID	0.013 FI	10.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.6 FI	20.8 F	199.9 F
01/28/25	19:00	0.0 FID	0.013 FI	9.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.8 FI	20.8 F	199.9 F
01/28/25	20:00	0.0 FID	0.001 FI	17.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.5 FI	20.9 F	199.9 F
01/28/25	21:00	0.0 FID	0.001 FI	21.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.0 FIE	20.9 F	199.9 F
01/28/25	22:00	0.0 FID	0.001 FI	20.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.4 FI	20.9 F	199.8 F
01/28/25	23:00	0.0 FID	0.001 FI	16.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.2 FIE	20.9 F	199.8 F
01/29/25	00:00	0.0 FID	0.001 FI	29.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.1 FIE	20.9 F	199.9 F
01/29/25	01:00	0.0 FID	0.001 FI	24.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	6.2 FIE	20.9 F	199.9 F
01/29/25	02:00	0.0 FID	0.001 FI	18.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.2 FI	20.9 F	199.9 F
01/29/25	03:00	0.0 FID	0.001 FI	31.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	6.8 FIE	20.9 F	199.9 F
01/29/25	04:00	0.0 FID	0.001 FI	23.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.0 FI	20.9 F	199.9 F
01/29/25	05:00	0.0 FID	0.001 FI	21.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.9 FI	20.9 F	199.9 F
01/29/25	06:00	0.0 FID	0.001 FI	20.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.6 FI	20.9 F	199.9 F
01/29/25	07:00	0.0 FIC	0.011 FI	5.2 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.4 F	14.1 FC	199.9 F
01/29/25	08:00	0.0 FID	0.013 FI	6.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.8 F	199.9 F
01/29/25	09:00	0.0 FID	0.001 FI	0.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.9 F
01/29/25	10:00	0.1 FID	0.001 FI	0.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.9 F
01/29/25	11:00	0.1 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
01/29/25	12:00	0.1 FID	0.001 FI	0.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.9 F
01/29/25	13:00	0.1 FID	0.001 FI	0.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.8 F
01/29/25	14:00	0.1 FID	0.001 FI	0.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.8 F	199.9 F
01/29/25	15:00	0.0 FID	0.001 FI	0.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.9 F
01/29/25	16:00	0.0 FID	0.001 FI	1.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.9 F
01/29/25	17:00	0.0 FID	0.001 FI	3.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.9 F
01/29/25	18:00	0.0 FID	0.001 FI	7.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.9 F	199.9 F
01/29/25	19:00	0.0 FID	0.013 FI	9.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.5 FI	20.8 F	199.9 F
01/29/25	20:00	0.0 FID	0.013 FI	11.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.8 F	199.9 F
01/29/25	21:00	0.0 FID	0.001 FI	14.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.5 FI	20.9 F	199.9 F
01/29/25	22:00	0.0 FID	0.001 FI	15.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.3 FI	20.9 F	199.9 F
01/29/25	23:00	0.0 FID	0.001 FI	12.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.9 F	199.9 F
01/30/25	00:00	0.0 FID	0.001 FI	23.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	1.1 FI	20.9 F	199.9 F

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/30/25 01:00	0.0 FID	0.001 FI	17.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.9 F	199.9 F
01/30/25 02:00	0.0 FID	0.001 FI	17.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.9 F	199.9 F
01/30/25 03:00	0.0 FID	0.001 FI	20.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.9 F	199.9 F
01/30/25 04:00	0.0 FID	0.001 FI	13.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.4 FI	20.9 F	199.9 F
01/30/25 05:00	0.0 FID	0.001 FI	17.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.9 F	199.9 F
01/30/25 06:00	0.0 FIM	0.013 FI	11.4 FI	0.0 F	0.0 F	0.0 FIM	0.0 FIM	0.001 FI	0.6 FI	20.8 FM	199.9 F
01/30/25 07:00	0.0 FIC	0.011 FI	5.0 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.9 F
01/30/25 08:00	0.0 FID	0.013 FI	6.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.6 FI	20.8 F	199.9 F
01/30/25 09:00	0.0 FID	0.001 FI	1.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.8 F	199.8 F
01/30/25 10:00	0.0 FID	0.001 FI	0.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.1 FI	20.8 F	199.8 F
01/30/25 11:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.7 F	199.8 F
01/30/25 12:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.7 F	199.8 F
01/30/25 13:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.7 F	199.8 F
01/30/25 14:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.7 F	199.8 F
01/30/25 15:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.7 F	199.8 F
01/30/25 16:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.7 F	199.8 F
01/30/25 17:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.7 F	199.8 F
01/30/25 18:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.7 F	199.8 F
01/30/25 19:00	0.0 FID	0.001 FI	0.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.8 F	199.8 F
01/30/25 20:00	0.0 FID	0.001 FI	1.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.8 F	199.8 F
01/30/25 21:00	0.0 FID	0.001 FI	2.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.1 FI	20.8 F	199.8 F
01/30/25 22:00	0.0 FID	0.001 FI	2.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.0 FI	20.8 F	199.8 F
01/30/25 23:00	0.0 FID	0.013 FI	3.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.8 F	199.8 F
01/31/25 00:00	0.0 FID	0.001 FI	2.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.8 F	199.8 F
01/31/25 01:00	0.0 FID	0.013 FI	2.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.0 FI	20.8 F	199.9 F
01/31/25 02:00	0.0 FID	0.013 FI	3.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.1 FI	20.8 F	199.9 F
01/31/25 03:00	0.0 FID	0.013 FI	3.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.8 F	199.9 F
01/31/25 04:00	0.0 FID	0.013 FI	3.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.8 F	199.8 F
01/31/25 05:00	0.0 FID	0.013 FI	3.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.8 F	199.8 F
01/31/25 06:00	0.0 FID	0.013 FI	3.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.1 FI	20.8 F	199.9 F
01/31/25 07:00	0.0 FIC	0.011 FI	5.0 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.1 FC	199.9 F
01/31/25 08:00	0.0 FID	0.007 FI	4.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.7 F	199.9 F
01/31/25 09:00	0.0 FID	0.007 FI	2.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.7 F	199.8 F
01/31/25 10:00	0.0 FID	0.001 FI	0.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.7 F	199.8 F
01/31/25 11:00	0.0 FID	0.001 FI	0.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.7 F	199.8 F
01/31/25 12:00	0.0 FID	0.001 FI	0.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.7 F	199.8 F
01/31/25 13:00	0.0 FID	0.001 FI	0.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.7 F	199.8 F

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/31/25 14:00	0.0 FID	0.001 FI	0.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.7 F	199.8 F
01/31/25 15:00	0.0 FID	0.001 FI	0.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.7 F	199.8 F
01/31/25 16:00	0.0 FID	0.001 FI	0.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.6 F	199.8 F
01/31/25 17:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.7 F	199.8 F
01/31/25 18:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.7 F	199.8 F
01/31/25 19:00	0.0 FID	0.001 FI	0.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.7 F	199.8 F
01/31/25 20:00	0.0 FID	0.001 FI	0.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.7 F	199.8 F
01/31/25 21:00	0.0 FID	0.001 FI	0.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.7 F	199.8 F
01/31/25 22:00	0.0 FID	0.001 FI	0.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.7 F	199.8 F
01/31/25 23:00	0.0 FID	0.001 FI	0.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.7 F	199.8 F
02/01/25 00:00	0.0 FID	0.001 FI	0.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.7 F	199.8 F
02/01/25 01:00	0.0 FID	0.001 FI	0.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.7 F	199.9 F
02/01/25 02:00	0.0 FID	0.001 FI	0.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.7 F	199.9 F
02/01/25 03:00	0.0 FID	0.001 FI	0.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.7 F	199.9 F
02/01/25 04:00	0.0 FID	0.001 FI	1.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.7 F	199.9 F
02/01/25 05:00	0.0 FID	0.007 FI	2.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.7 F	199.9 F
02/01/25 06:00	0.0 FID	0.007 FI	1.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.7 F	199.9 F
02/01/25 07:00	0.0 FIC	0.011 FI	4.9 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.022 F	6.1 F	14.0 FC	199.9 F
02/01/25 08:00	0.0 FID	0.001 FI	0.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.7 F	199.8 F
02/01/25 09:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.7 F	199.8 F
02/01/25 10:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.7 F	199.8 F
02/01/25 11:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.7 F	199.8 F
02/01/25 12:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.7 F	199.8 F
02/01/25 13:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.7 F	199.8 F
02/01/25 14:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.7 F	199.8 F
02/01/25 15:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.7 F	199.8 F
02/01/25 16:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.7 F	199.8 F
02/01/25 17:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.7 F	199.8 F
02/01/25 18:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.7 F	199.8 F
02/01/25 19:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.7 F	199.8 F
02/01/25 20:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.7 F	199.8 F
02/01/25 21:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.7 F	199.8 F
02/01/25 22:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.7 F	199.8 F
02/01/25 23:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.7 F	199.8 F
02/02/25 00:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.7 F	199.8 F
02/02/25 01:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.7 F	199.8 F
02/02/25 02:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.7 F	199.8 F

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/02/25 03:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.7 F	199.8 F
02/02/25 04:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.7 F	199.8 F
02/02/25 05:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.7 F	199.8 F
02/02/25 06:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.7 F	199.8 F
02/02/25 07:00	0.0 FIC	0.011 FI	4.8 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.1 F	14.1 FC	199.8 F
02/02/25 08:00	0.0 FID	0.001 FI	-33.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	20.9 F	199.8 F
02/02/25 09:00	0.0 FID	0.001 FI	-73.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-2.6 FI	20.9 F	199.8 F
02/02/25 10:00	0.0 FID	0.001 FI	-55.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-3.0 FI	20.9 F	199.8 F
02/02/25 11:00	0.0 FID	0.001 FI	-41.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.0 FI	20.9 F	199.8 F
02/02/25 12:00	0.0 FID	0.001 FI	-43.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.9 FI	20.9 F	199.8 F
02/02/25 13:00	0.0 FID	0.001 FI	-45.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.5 FI	20.9 F	199.8 F
02/02/25 14:00	0.0 FID	0.001 FI	-35.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.2 FI	20.9 F	199.8 F
02/02/25 15:00	0.0 FID	0.001 FI	-36.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.5 FI	20.9 F	199.8 F
02/02/25 16:00	0.0 FID	0.001 FI	-89.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-5.3 FI	20.9 F	199.8 F
02/02/25 17:00	0.0 FID	0.001 FI	-38.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	20.9 F	199.8 F
02/02/25 18:00	0.0 FID	0.001 FI	-43.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	20.9 F	199.8 F
02/02/25 19:00	0.0 FID	0.001 FI	-54.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.0 FI	20.9 F	199.8 F
02/02/25 20:00	0.0 FID	0.001 FI	-29.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.2 FI	20.9 F	199.8 F
02/02/25 21:00	0.0 FID	0.001 FI	-47.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	20.9 F	199.8 F
02/02/25 22:00	0.0 FID	0.001 FI	-46.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.2 FI	20.9 F	199.8 F
02/02/25 23:00	0.0 FID	0.001 FI	24.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.9 F	199.8 F
02/03/25 00:00	0.0 FID	0.001 FI	-30.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.9 FI	20.9 F	199.8 F
02/03/25 01:00	0.0 FID	0.001 FI	-44.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.1 FI	20.9 F	199.8 F
02/03/25 02:00	0.0 FID	0.001 FI	-26.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.5 FI	20.9 F	199.9 F
02/03/25 03:00	0.0 FID	0.001 FI	-29.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.2 FI	20.9 F	199.9 F
02/03/25 04:00	0.0 FID	0.001 FI	-39.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	20.9 F	199.9 F
02/03/25 05:00	0.0 FID	0.001 FI	-22.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.9 FI	20.9 F	199.9 F
02/03/25 06:00	0.0 FID	0.001 FI	-29.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	20.9 F	199.9 F
02/03/25 07:00	0.0 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	8.3 F	14.2 FC	199.9 F
02/03/25 08:00	0.0 FID	0.001 FI	-17.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	21.0 F	199.9 F
02/03/25 09:00	0.0 FID	0.001 FI	-8.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.2 FI	20.9 F	199.8 F
02/03/25 10:00	0.0 FID	0.001 FI	-8.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.5 FI	20.9 F	199.8 F
02/03/25 11:00	0.1 FID	0.001 FI	-6.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.8 FI	20.9 F	199.8 F
02/03/25 12:00	0.0 FID	0.001 FI	-7.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-6.8 FI	20.9 F	199.9 F
02/03/25 13:00	0.0 FID	0.001 FI	-8.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.7 FI	20.9 F	199.8 F
02/03/25 14:00	0.0 FID	0.001 FI	-7.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-5.2 FI	20.9 F	199.8 F
02/03/25 15:00	0.0 FID	0.001 FI	-4.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	20.9 F	199.8 F

Source	Parameter Unit	UNIT_B										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/03/25	16:00	0.0 FID	0.001 FI	-9.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.1 FI	20.9 F	199.8 F
02/03/25	17:00	0.1 FID	0.001 FI	-2.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.8 FI	20.9 F	199.8 F
02/03/25	18:00	0.0 FID	0.001 FI	-3.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.5 FI	20.9 F	199.8 F
02/03/25	19:00	0.1 FID	0.001 FI	-3.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.8 FI	20.9 F	199.8 F
02/03/25	20:00	0.1 FID	0.001 FI	-1.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	20.9 F	199.8 F
02/03/25	21:00	0.1 FID	0.001 FI	-1.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.6 FI	20.9 F	199.8 F
02/03/25	22:00	0.0 FID	0.001 FI	-1.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.8 FI	20.9 F	199.8 F
02/03/25	23:00	0.0 FID	0.001 FI	-2.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.0 FI	20.9 F	199.8 F
02/04/25	00:00	0.1 FID	0.001 FI	-2.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-3.5 FI	20.9 F	199.8 F
02/04/25	01:00	0.1 FID	0.001 FI	-3.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.9 FI	20.9 F	199.8 F
02/04/25	02:00	0.0 FID	0.001 FI	-4.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.5 FI	20.9 F	199.8 F
02/04/25	03:00	0.0 FID	0.001 FI	-3.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	20.9 F	199.8 F
02/04/25	04:00	0.0 FID	0.001 FI	-4.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.9 FI	20.9 F	199.8 F
02/04/25	05:00	0.0 FID	0.001 FI	-7.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-2.5 FI	20.9 F	199.8 F
02/04/25	06:00	0.0 FID	0.001 FI	-7.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.0 FI	20.9 F	199.8 F
02/04/25	07:00	0.0 FIC	0.011 FI	4.9 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.8 F
02/04/25	08:00	0.0 FID	0.013 FI	9.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.8 FI	20.8 F	199.8 F
02/04/25	09:00	0.0 FID	0.013 FI	4.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.8 F	199.8 F
02/04/25	10:00	0.0 FID	0.013 FI	4.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.0 FI	20.8 F	199.8 F
02/04/25	11:00	0.0 FID	0.013 FI	4.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.8 F	199.8 F
02/04/25	12:00	0.0 FID	0.013 FI	4.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.5 FI	20.8 F	199.8 F
02/04/25	13:00	0.0 FID	0.013 FI	5.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.8 F	199.8 F
02/04/25	14:00	0.0 FID	0.013 FI	4.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.7 FI	20.8 F	199.8 F
02/04/25	15:00	0.0 FID	0.013 FI	5.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.6 FI	20.8 F	199.8 F
02/04/25	16:00	0.0 FID	0.013 FI	7.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.2 FI	20.8 F	199.8 F
02/04/25	17:00	0.0 FID	0.013 FI	6.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.2 FI	20.8 F	199.8 F
02/04/25	18:00	0.0 FID	0.013 FI	6.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.3 FI	20.8 F	199.8 F
02/04/25	19:00	0.0 FID	0.013 FI	5.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.2 FI	20.8 F	199.8 F
02/04/25	20:00	0.0 FID	0.013 FI	5.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.6 FI	20.8 F	199.8 F
02/04/25	21:00	0.0 FID	0.013 FI	5.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.0 FI	20.8 F	199.8 F
02/04/25	22:00	0.0 FID	0.013 FI	4.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.8 F	199.8 F
02/04/25	23:00	0.0 FID	0.013 FI	6.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.8 FI	20.8 F	199.8 F
02/05/25	00:00	0.0 FID	0.013 FI	4.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.1 FI	20.8 F	199.8 F
02/05/25	01:00	0.0 FID	0.013 FI	4.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.3 FI	20.8 F	199.8 F
02/05/25	02:00	0.0 FID	0.013 FI	5.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.5 FI	20.8 F	199.8 F
02/05/25	03:00	0.0 FID	0.013 FI	5.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.4 FI	20.8 F	199.8 F
02/05/25	04:00	0.0 FID	0.013 FI	5.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.8 F	199.8 F

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/05/25 05:00	0.0 FID	0.013 FI	5.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.0 FI	20.6 F	199.8 F
02/05/25 06:00	0.0 FID	0.013 FI	6.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.6 FI	20.6 F	199.8 F
02/05/25 07:00	0.0 FIC	0.012 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.024 F	6.4 F	14.3 FC	199.8 F
02/05/25 08:00	0.0 FID	0.001 FI	-19.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.0 FI	20.9 F	199.8 F
02/05/25 09:00	0.0 FID	0.001 FI	-24.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	20.9 F	199.8 F
02/05/25 10:00	0.0 FID	0.001 FI	-26.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.6 FI	20.9 F	199.8 F
02/05/25 11:00	0.0 FID	0.001 FI	-25.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	20.9 F	199.8 F
02/05/25 12:00	0.0 FID	0.001 FI	-44.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.6 FI	20.9 F	199.9 F
02/05/25 13:00	0.0 FID	0.001 FI	-26.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.0 FI	20.9 F	199.9 F
02/05/25 14:00	0.0 FID	0.001 FI	-28.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.1 FI	20.9 F	199.8 F
02/05/25 15:00	0.0 FID	0.001 FI	-24.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.2 FI	20.9 F	199.8 F
02/05/25 16:00	0.0 FID	0.001 FI	-21.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	20.9 F	199.8 F
02/05/25 17:00	0.0 FID	0.001 FI	-31.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-2.1 FI	20.9 F	199.8 F
02/05/25 18:00	0.0 FID	0.001 FI	-28.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.7 FI	20.9 F	199.8 F
02/05/25 19:00	0.0 FID	0.001 FI	-26.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.1 FI	20.9 F	199.8 F
02/05/25 20:00	0.0 FID	0.001 FI	-25.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.2 FI	20.9 F	199.8 F
02/05/25 21:00	0.0 FID	0.001 FI	-20.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.8 F
02/05/25 22:00	0.0 FID	0.001 FI	-19.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.8 F
02/05/25 23:00	0.0 FID	0.001 FI	-18.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.7 FI	21.0 F	199.8 F
02/06/25 00:00	0.0 FID	0.001 FI	-19.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.4 FI	21.0 F	199.8 F
02/06/25 01:00	0.0 FID	0.001 FI	-15.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.8 F
02/06/25 02:00	0.0 FID	0.001 FI	-19.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.4 FI	21.0 F	199.8 F
02/06/25 03:00	0.0 FID	0.001 FI	-26.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.8 F
02/06/25 04:00	0.0 FID	0.001 FI	-19.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.6 FI	21.0 F	199.8 F
02/06/25 05:00	0.0 FID	0.001 FI	-17.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	21.0 F	199.8 F
02/06/25 06:00	0.0 FID	0.001 FI	-19.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.6 FI	21.0 F	199.8 F
02/06/25 07:00	0.0 FIC	0.012 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.2 FC	199.8 F
02/06/25 08:00	0.0 FID	0.007 FI	3.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.7 F	199.8 F
02/06/25 09:00	0.0 FID	0.001 FI	1.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.7 F	199.8 F
02/06/25 10:00	0.0 FID	0.001 FI	0.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.7 F	199.8 F
02/06/25 11:00	0.0 FID	0.001 FI	0.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.7 F	199.8 F
02/06/25 12:00	0.0 FID	0.001 FI	0.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.7 F	199.8 F
02/06/25 13:00	0.0 FID	0.001 FI	0.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.7 F	199.8 F
02/06/25 14:00	0.0 FID	0.001 FI	0.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.7 F	199.8 F
02/06/25 15:00	0.0 FID	0.001 FI	0.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.7 F	199.8 F
02/06/25 16:00	0.0 FID	0.001 FI	0.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.7 F	199.8 F
02/06/25 17:00	0.0 FID	0.001 FI	0.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.7 F	199.8 F

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/06/25 18:00	0.0 FID	0.001 FI	0.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.7 F	199.8 F
02/06/25 19:00	0.0 FID	0.001 FI	0.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.7 F	199.8 F
02/06/25 20:00	0.0 FID	0.001 FI	1.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.7 F	199.8 F
02/06/25 21:00	0.0 FID	0.001 FI	0.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.7 F	199.8 F
02/06/25 22:00	0.0 FID	0.001 FI	0.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.7 F	199.8 F
02/06/25 23:00	0.0 FID	0.001 FI	0.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.7 F	199.8 F
02/07/25 00:00	0.0 FID	0.001 FI	0.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.7 F	199.8 F
02/07/25 01:00	0.0 FID	0.001 FI	0.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.7 F	199.8 F
02/07/25 02:00	0.0 FID	0.001 FI	1.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.7 F	199.8 F
02/07/25 03:00	0.0 FID	0.001 FI	0.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.7 F	199.8 F
02/07/25 04:00	0.0 FID	0.001 FI	1.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.7 F	199.8 F
02/07/25 05:00	0.0 FID	0.001 FI	1.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.7 F	199.8 F
02/07/25 06:00	0.0 FID	0.001 FI	0.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.7 F	199.8 F
02/07/25 07:00	0.0 FIC	0.013 FI	5.6 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.022 F	6.1 F	14.1 FC	199.8 F
02/07/25 08:00	0.0 FID	0.001 FI	25.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.1 FI	20.9 F	199.8 F
02/07/25 09:00	0.0 FID	0.028 FI	20.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.1 FI	20.8 F	199.8 F
02/07/25 10:00	0.0 FID	0.001 FI	25.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.1 FI	20.9 F	199.8 F
02/07/25 11:00	0.0 FID	0.001 FI	26.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.8 FI	20.9 F	199.8 F
02/07/25 12:00	0.0 FID	0.001 FI	23.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.9 FI	20.9 F	199.8 F
02/07/25 13:00	0.0 FID	0.001 FI	24.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.1 FI	20.9 F	199.8 F
02/07/25 14:00	0.0 FID	0.026 FI	19.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.6 FI	20.8 F	199.8 F
02/07/25 15:00	0.0 FID	0.001 FI	30.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.0 FI	20.9 F	199.8 F
02/07/25 16:00	0.0 FID	0.001 FI	24.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.9 FI	20.9 F	199.8 F
02/07/25 17:00	0.0 FID	0.001 FI	29.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.9 FI	20.9 F	199.8 F
02/07/25 18:00	0.0 FID	0.001 FI	24.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.8 FI	20.9 F	199.8 F
02/07/25 19:00	0.0 FID	0.001 FI	31.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.6 FI	20.9 F	199.8 F
02/07/25 20:00	0.0 FID	0.001 FI	34.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.2 FI	20.9 F	199.8 F
02/07/25 21:00	0.0 FID	0.001 FI	30.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.5 FI	20.9 F	199.8 F
02/07/25 22:00	0.0 FID	0.001 FI	49.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.5 FIE	20.9 F	199.8 F
02/07/25 23:00	0.0 FID	0.001 FI	29.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.8 FI	20.9 F	199.8 F
02/08/25 00:00	0.0 FID	0.001 FI	34.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.3 FI	20.9 F	199.8 F
02/08/25 01:00	0.0 FID	0.001 FI	26.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.9 FI	20.9 F	199.8 F
02/08/25 02:00	0.0 FID	0.001 FI	47.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	7.4 FIE	20.9 F	199.8 F
02/08/25 03:00	0.0 FID	0.001 FI	79.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	10.7 FIE	20.9 F	199.8 F
02/08/25 04:00	0.0 FID	0.001 FI	137.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	11.3 FIE	20.9 F	199.8 F
02/08/25 05:00	0.0 FID	0.001 FI	-548.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-63.4 FI	20.9 F	199.8 F
02/08/25 06:00	0.0 FID	0.001 FI	-979.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-86.8 FI	20.9 F	199.8 F

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/08/25 07:00	0.0 FIC	0.012 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.8 F
02/08/25 08:00	0.0 FID	0.013 FI	6.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
02/08/25 09:00	0.0 FID	0.013 FI	4.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
02/08/25 10:00	0.0 FID	0.001 FI	3.2 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
02/08/25 11:00	0.0 FID	0.001 FI	1.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
02/08/25 12:00	0.0 FID	0.001 FI	1.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
02/08/25 13:00	0.0 FID	0.001 FI	1.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
02/08/25 14:00	0.0 FID	0.001 FI	1.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
02/08/25 15:00	0.0 FID	0.001 FI	1.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
02/08/25 16:00	0.0 FID	0.013 FI	4.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
02/08/25 17:00	0.0 FID	0.013 FI	5.0 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
02/08/25 18:00	0.0 FID	0.013 FI	9.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.1 FI	20.8 F	199.8 F
02/08/25 19:00	0.0 FID	0.013 FI	11.9 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.1 FI	20.8 F	199.8 F
02/08/25 20:00	0.0 FID	0.013 FI	16.1 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
02/08/25 21:00	0.0 FID	0.013 FI	14.8 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
02/08/25 22:00	0.0 FID	0.026 FI	15.4 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.1 FI	20.8 F	199.8 F
02/08/25 23:00	39.5 U	0.074 E	33.1 E	0.0	0.0	0.0	70.5 EU	0.113 E	30.6 E	16.0	199.8
02/09/25 00:00	17.3 U	0.020	8.8	0.0	0.0	0.0	14.0 U	0.016	4.3	15.0	199.9
02/09/25 01:00	15.8	0.018	8.0	0.0	0.0	0.0	14.0	0.016	4.3	15.0	199.9
02/09/25 02:00	16.9	0.020	9.0	0.0	0.0	0.0	13.2	0.016	4.3	15.1	199.9
02/09/25 03:00	12.6	0.014	6.4	0.0	0.0	0.0	14.1	0.016	4.4	15.0	199.9
02/09/25 04:00	10.7	0.012	5.4	0.0	0.0	0.0	14.0	0.016	4.3	14.9	199.9
02/09/25 05:00	11.1	0.013	5.7	0.0	0.0	0.0	14.0	0.016	4.3	15.0	199.9
02/09/25 06:00	11.9 D	0.014	6.1	0.0	0.0	0.0	13.8 D	0.016	4.3	15.0	199.9
02/09/25 07:00	97.4 ECD	0.275 E	122.5 E	0.0	0.0	0.0 C	40.7 ECD	0.108 E	29.2 E	16.7 C	199.9
02/09/25 08:00	0.0 FID	0.001 FI	-25.9 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	-0.2 FI	20.9 F	199.9 F
02/09/25 09:00	0.0 FID	0.001 FI	-19.4 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	-0.1 FI	20.9 F	199.9 F
02/09/25 10:00	0.0 FID	0.001 FI	-17.2 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
02/09/25 11:00	0.0 FID	0.001 FI	-15.2 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
02/09/25 12:00	0.0 FID	0.001 FI	-16.7 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
02/09/25 13:00	0.0 FID	0.001 FI	-15.5 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	-0.1 FI	20.9 F	199.9 F
02/09/25 14:00	0.0 FID	0.001 FI	-15.7 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/09/25 15:00	0.0 FID	0.001 FI	-18.7 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	-0.2 FI	20.9 F	199.9 F
02/09/25 16:00	0.0 FID	0.001 FI	-15.2 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	20.9 F	199.9 F
02/09/25 17:00	0.0 FID	0.001 FI	-18.6 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	-0.1 FI	20.9 F	199.9 F
02/09/25 18:00	0.0 FID	0.001 FI	-17.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.4 FI	20.9 F	199.9 F
02/09/25 19:00	0.0 FID	0.001 FI	-15.1 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.0 F	199.9 F

UNIT START UP

UNIT SHUTDOWN

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/09/25 20:00	0.0 FID	0.001 FI	-14.6 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/09/25 21:00	0.0 FID	0.001 FI	-18.1 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/09/25 22:00	0.0 FID	0.001 FI	-16.7 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/09/25 23:00	0.0 FID	0.001 FI	-19.0 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/10/25 00:00	0.0 FID	0.001 FI	-16.1 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/10/25 01:00	0.0 FID	0.001 FI	-16.2 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/10/25 02:00	0.0 FID	0.001 FI	-16.8 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/10/25 03:00	0.0 FID	0.001 FI	-15.3 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/10/25 04:00	0.0 FID	0.001 FI	-16.3 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/10/25 05:00	0.0 FID	0.001 FI	-16.0 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/10/25 06:00	0.0 FIM	0.001 FI	-15.5 FI	0.0 F	0.0 F	0.0 FIM	0.3 FIM	0.001 FI	0.0 FI	21.0 FM	199.9 F
02/10/25 07:00	0.0 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.1 FIC	0.023 F	6.3 F	14.2 FC	199.9 F
02/10/25 08:00	0.0 FID	0.013 FI	6.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
02/10/25 09:00	0.0 FID	0.013 FI	5.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
02/10/25 10:00	0.0 FID	0.013 FI	5.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
02/10/25 11:00	0.0 FID	0.013 FI	6.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
02/10/25 12:00	0.0 FID	0.026 FI	8.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
02/10/25 13:00	0.0 FID	0.013 FI	5.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
02/10/25 14:00	0.0 FID	0.013 FI	6.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.2 FI	20.8 F	199.9 F
02/10/25 15:00	0.0 FID	0.013 FI	6.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
02/10/25 16:00	0.0 FID	0.013 FI	5.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
02/10/25 17:00	0.0 FID	0.013 FI	7.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
02/10/25 18:00	0.0 FID	0.026 FI	10.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
02/10/25 19:00	0.0 FID	0.026 FI	11.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
02/10/25 20:00	0.0 FID	0.026 FI	13.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
02/10/25 21:00	0.0 FID	0.026 FI	14.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
02/10/25 22:00	0.0 FID	0.026 FI	18.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
02/10/25 23:00	0.0 FID	0.026 FI	18.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
02/11/25 00:00	0.0 FID	0.026 FI	16.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
02/11/25 01:00	0.0 FID	0.026 FI	17.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
02/11/25 02:00	0.0 FID	0.026 FI	17.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
02/11/25 03:00	0.0 FID	0.026 FI	17.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
02/11/25 04:00	0.0 FID	0.026 FI	19.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
02/11/25 05:00	0.0 FID	0.026 FI	15.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
02/11/25 06:00	0.0 FID	0.026 FI	17.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
02/11/25 07:00	0.0 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.1 FIC	0.023 F	6.3 F	14.2 FC	199.9 F
02/11/25 08:00	0.0 FID	0.001 FI	-9.4 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/11/25 09:00	0.0 FID	0.001 FI	-10.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.3 FI	20.9 F	199.9 F
02/11/25 10:00	0.0 FID	0.001 FI	-11.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.4 FI	20.9 F	199.9 F
02/11/25 11:00	0.0 FID	0.001 FI	-8.5 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.2 FI	20.9 F	199.9 F
02/11/25 12:00	0.0 FID	0.001 FI	-7.1 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.2 FI	20.9 F	199.9 F
02/11/25 13:00	0.0 FID	0.001 FI	-10.4 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.3 FI	20.9 F	199.9 F
02/11/25 14:00	0.0 FID	0.001 FI	-8.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.5 FI	21.0 F	199.9 F
02/11/25 15:00	0.0 FID	0.001 FI	-11.9 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.4 FI	20.9 F	199.9 F
02/11/25 16:00	0.0 FID	0.001 FI	38.5 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.7 FI	20.9 F	199.9 F
02/11/25 17:00	0.0 FID	0.001 FI	-9.9 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/11/25 18:00	0.0 FID	0.001 FI	-9.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
02/11/25 19:00	0.0 FID	0.001 FI	-9.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
02/11/25 20:00	0.0 FID	0.001 FI	-10.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F
02/11/25 21:00	0.0 FID	0.001 FI	-12.6 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
02/11/25 22:00	0.0 FID	0.001 FI	-11.3 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/11/25 23:00	0.0 FID	0.001 FI	-9.3 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.5 FI	20.9 F	199.9 F
02/12/25 00:00	0.0 FID	0.001 FI	-6.3 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.3 FI	20.9 F	199.8 F
02/12/25 01:00	0.1 FID	0.001 FI	-2.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.7 FI	20.9 F	199.8 F
02/12/25 02:00	0.1 FID	0.001 FI	-1.8 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
02/12/25 03:00	0.1 FID	0.001 FI	-0.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.7 FI	20.9 F	199.8 F
02/12/25 04:00	0.1 FID	0.001 FI	-2.5 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-1.7 FI	20.9 F	199.8 F
02/12/25 05:00	0.2 FID	0.001 FI	-1.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-2.1 FI	20.9 F	199.8 F
02/12/25 06:00	0.2 FID	0.001 FI	-1.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.9 FI	20.9 F	199.8 F
02/12/25 07:00	0.0 FIC	0.011 FI	5.0 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.2 FC	199.8 F
02/12/25 08:00	0.0 FID	0.013 FI	4.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.8 F	199.8 F
02/12/25 09:00	0.0 FID	0.013 FI	3.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.8 F	199.8 F
02/12/25 10:00	0.0 FID	0.001 FI	1.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.8 F	199.8 F
02/12/25 11:00	0.0 FID	0.001 FI	1.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.8 F	199.8 F
02/12/25 12:00	0.0 FID	0.001 FI	0.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.8 F	199.8 F
02/12/25 13:00	0.0 FID	0.001 FI	0.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.8 F	199.8 F
02/12/25 14:00	0.0 FID	0.001 FI	0.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.8 F	199.8 F
02/12/25 15:00	0.0 FID	0.001 FI	0.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.7 F	199.8 F
02/12/25 16:00	0.0 FID	0.001 FI	0.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.8 F	199.8 F
02/12/25 17:00	0.0 FID	0.001 FI	0.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.7 F	199.8 F
02/12/25 18:00	0.0 FID	0.001 FI	0.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.7 F	199.8 F
02/12/25 19:00	0.0 FID	0.001 FI	0.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.7 F	199.8 F
02/12/25 20:00	0.0 FID	0.001 FI	0.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.8 F	199.8 F
02/12/25 21:00	0.0 FID	0.001 FI	0.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.8 F

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/12/25 22:00	0.0 FID	0.001 FI	0.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.8 F	199.8 F
02/12/25 23:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.7 F	199.8 F
02/13/25 00:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.8 F	199.8 F
02/13/25 01:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.8 F	199.8 F
02/13/25 02:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.7 F	199.8 F
02/13/25 03:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.8 F	199.8 F
02/13/25 04:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.8 F
02/13/25 05:00	0.0 FID	0.001 FI	0.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.8 F	199.8 F
02/13/25 06:00	0.0 FID	0.001 FI	0.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.8 F	199.8 F
02/13/25 07:00	0.0 FIC	0.011 FI	4.9 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.1 FC	199.8 F
02/13/25 08:00	0.0 FID	0.001 FI	-44.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	20.9 F	199.8 F
02/13/25 09:00	0.0 FID	0.001 FI	-46.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.1 FI	20.9 F	199.8 F
02/13/25 10:00	0.0 FID	0.001 FI	-28.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.8 FI	20.9 F	199.8 F
02/13/25 11:00	0.0 FID	0.001 FI	-29.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.4 FI	20.9 F	199.8 F
02/13/25 12:00	0.0 FID	0.001 FI	-16.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.0 FI	20.9 F	199.8 F
02/13/25 13:00	0.0 FID	0.001 FI	-33.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.6 FI	20.9 F	199.8 F
02/13/25 14:00	0.0 FID	0.001 FI	-24.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.4 FI	20.9 F	199.8 F
02/13/25 15:00	0.0 FID	0.001 FI	-33.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.2 FI	20.9 F	199.8 F
02/13/25 16:00	0.0 FID	0.001 FI	-58.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-3.1 FI	20.9 F	199.8 F
02/13/25 17:00	0.0 FID	0.001 FI	-23.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.6 FI	20.9 F	199.8 F
02/13/25 18:00	0.0 FID	0.001 FI	-37.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.5 FI	20.9 F	199.8 F
02/13/25 19:00	0.0 FID	0.001 FI	-65.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-2.7 FI	20.9 F	199.8 F
02/13/25 20:00	0.0 FID	0.001 FI	-74.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-4.4 FI	20.9 F	199.8 F
02/13/25 21:00	0.0 FID	0.001 FI	99.1 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	3.1 FI	20.9 F	199.8 F
02/13/25 22:00	0.0 FID	0.001 FI	-37.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.0 FI	20.9 F	199.8 F
02/13/25 23:00	0.0 FID	0.001 FI	-98.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-4.6 FI	20.9 F	199.8 F
02/14/25 00:00	0.0 FID	0.001 FI	-41.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-2.6 FI	20.9 F	199.8 F
02/14/25 01:00	0.0 FID	0.001 FI	-55.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.9 FI	20.9 F	199.8 F
02/14/25 02:00	0.0 FID	0.001 FI	-95.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-4.1 FI	20.9 F	199.8 F
02/14/25 03:00	0.0 FID	0.001 FI	-68.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-5.1 FI	20.9 F	199.8 F
02/14/25 04:00	0.0 FID	0.001 FI	-88.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.8 FI	20.9 F	199.8 F
02/14/25 05:00	0.0 FID	0.001 FI	467.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	14.5 FIE	20.9 F	199.8 F
02/14/25 06:00	0.0 FID	0.001 FI	-75.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-3.7 FI	20.9 F	199.8 F
02/14/25 07:00	0.0 FIC	0.011 FI	5.0 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.8 F
02/14/25 08:00	0.0 FID	0.001 FI	-20.0 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	20.9 F	199.8 F
02/14/25 09:00	0.0 FID	0.001 FI	-22.0 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	-0.1 FI	20.9 F	199.8 F
02/14/25 10:00	0.0 FID	0.001 FI	-18.0 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.0 FI	20.9 F	199.8 F

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/14/25 11:00	0.0 FID	0.001 FI	-26.6 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
02/14/25 12:00	0.0 FID	0.001 FI	-21.1 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.3 FI	20.9 F	199.8 F
02/14/25 13:00	0.0 FID	0.001 FI	-21.9 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	-0.1 FI	20.9 F	199.8 F
02/14/25 14:00	0.0 FID	0.001 FI	-20.6 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
02/14/25 15:00	0.0 FID	0.001 FI	-17.9 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
02/14/25 16:00	0.0 FID	0.001 FI	-22.5 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	20.9 F	199.8 F
02/14/25 17:00	0.0 FID	0.001 FI	-19.6 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	-0.1 FI	20.9 F	199.8 F
02/14/25 18:00	0.0 FID	0.001 FI	-15.1 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
02/14/25 19:00	0.0 FID	0.001 FI	-17.2 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	-0.1 FI	20.9 F	199.8 F
02/14/25 20:00	0.0 FID	0.001 FI	-22.4 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	-0.1 FI	20.9 F	199.8 F
02/14/25 21:00	0.0 FID	0.001 FI	-21.6 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	-0.3 FI	20.9 F	199.8 F
02/14/25 22:00	0.0 FID	0.001 FI	-20.3 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	20.9 F	199.8 F
02/14/25 23:00	0.0 FID	0.001 FI	-14.3 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
02/15/25 00:00	0.0 FID	0.001 FI	-21.7 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
02/15/25 01:00	0.0 FID	0.001 FI	-22.4 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.2 FI	20.9 F	199.8 F
02/15/25 02:00	0.0 FID	0.001 FI	-19.4 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
02/15/25 03:00	0.0 FID	0.001 FI	-12.4 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
02/15/25 04:00	0.0 FID	0.001 FI	-16.1 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
02/15/25 05:00	0.0 FID	0.001 FI	-17.2 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
02/15/25 06:00	0.0 FID	0.001 FI	-17.8 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
02/15/25 07:00	0.0 FIC	0.012 FI	5.2 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.8 F
02/15/25 08:00	0.0 FID	0.001 FI	31.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.9 F	199.8 F
02/15/25 09:00	0.0 FID	0.001 FI	17.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.1 FI	20.9 F	199.8 F
02/15/25 10:00	0.0 FID	0.001 FI	17.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	1.0 FI	20.9 F	199.8 F
02/15/25 11:00	0.0 FID	0.001 FI	18.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.8 FI	20.9 F	199.8 F
02/15/25 12:00	0.0 FID	0.001 FI	14.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.9 F	199.8 F
02/15/25 13:00	0.0 FID	0.013 FI	13.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.8 F	199.8 F
02/15/25 14:00	0.0 FID	0.013 FI	12.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.8 F	199.8 F
02/15/25 15:00	0.0 FID	0.001 FI	19.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.7 FI	20.9 F	199.8 F
02/15/25 16:00	0.0 FID	0.001 FI	15.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.0 FI	20.9 F	199.8 F
02/15/25 17:00	0.0 FID	0.001 FI	19.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.7 FI	20.9 F	199.8 F
02/15/25 18:00	0.0 FID	0.001 FI	17.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.9 F	199.8 F
02/15/25 19:00	0.0 FID	0.001 FI	17.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.9 F	199.8 F
02/15/25 20:00	0.0 FID	0.001 FI	31.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.7 FI	20.9 F	199.8 F
02/15/25 21:00	0.0 FID	0.001 FI	55.3 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.7 FI	20.9 F	199.8 F
02/15/25 22:00	0.0 FID	0.001 FI	69.3 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	2.3 FI	20.9 F	199.8 F
02/15/25 23:00	40.9 U	0.083 E	37.2 E	0.0	0.0	0.0	70.0 EU	0.114 E	31.0 E	16.2	199.8


UNIT START UP

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/16/25 00:00	14.9 U	0.019	8.6	0.0	0.0	0.0	12.7 U	0.016	4.4	15.1	199.8
02/16/25 01:00	17.6	0.023	10.3	0.0	0.0	0.0	12.0	0.016	4.3	15.1	199.9
02/16/25 02:00	17.8	0.023	10.3	0.0	0.0	0.0	12.1	0.016	4.3	15.0	199.9
02/16/25 03:00	16.9	0.022	9.9	0.0	0.0	0.0	12.0	0.016	4.3	15.0	199.9
02/16/25 04:00	16.8	0.022	9.8	0.0	0.0	0.0	12.0	0.016	4.3	15.0	199.9
02/16/25 05:00	19.2	0.024	10.5	0.0	0.0	0.0	12.8	0.016	4.3	15.1	199.9
02/16/25 06:00	17.1 D	0.020	8.9	0.0	0.0	0.0	13.7 D	0.016	4.3	15.0	199.9
02/16/25 07:00	99.9 ECD	0.305 E	135.8 E	0.0	0.0	0.0 C	39.9 ECD	0.110 E	29.7 E	16.8 C	199.9
02/16/25 08:00	0.0 FID	0.001 FI	-22.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.5 FI	20.9 F	199.8 F
02/16/25 09:00	0.0 FID	0.001 FI	-25.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.4 FI	20.9 F	199.8 F
02/16/25 10:00	0.0 FID	0.001 FI	-15.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	20.9 F	199.8 F
02/16/25 11:00	0.0 FID	0.001 FI	-19.5 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.6 FI	20.9 F	199.8 F
02/16/25 12:00	0.0 FID	0.001 FI	-24.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.3 FI	20.9 F	199.8 F
02/16/25 13:00	0.0 FID	0.001 FI	0.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	13.1 F	199.8 F
02/16/25 14:00	0.0 FID	0.001 FI	0.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	14.4 F	199.8 F
02/16/25 15:00	0.0 FID	0.001 FI	-14.5 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	20.9 F	199.8 F
02/16/25 16:00	0.0 FID	0.001 FI	-18.4 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.4 FI	20.9 F	199.8 F
02/16/25 17:00	0.0 FID	0.001 FI	-14.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.6 FI	20.9 F	199.8 F
02/16/25 18:00	0.0 FID	0.001 FI	-18.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.6 FI	20.9 F	199.8 F
02/16/25 19:00	0.0 FID	0.001 FI	-13.5 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	20.9 F	199.8 F
02/16/25 20:00	0.0 FID	0.001 FI	-15.0 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	20.9 F	199.8 F
02/16/25 21:00	0.0 FID	0.001 FI	-18.5 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.4 FI	20.9 F	199.8 F
02/16/25 22:00	0.0 FID	0.001 FI	-19.1 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.4 FI	20.9 F	199.8 F
02/16/25 23:00	0.0 FID	0.001 FI	-18.4 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.2 FI	20.9 F	199.8 F
02/17/25 00:00	0.0 FID	0.001 FI	-16.9 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.4 FI	20.9 F	199.8 F
02/17/25 01:00	0.0 FID	0.001 FI	-34.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.2 FI	20.9 F	199.8 F
02/17/25 02:00	0.0 FID	0.001 FI	-17.8 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.2 FI	20.9 F	199.8 F
02/17/25 03:00	0.0 FID	0.001 FI	-17.9 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.3 FI	20.9 F	199.8 F
02/17/25 04:00	0.1 FID	0.001 FI	-16.5 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.2 FI	20.9 F	199.8 F
02/17/25 05:00	0.0 FID	0.001 FI	-18.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.4 FI	20.9 F	199.8 F
02/17/25 06:00	0.0 FID	0.001 FI	-19.2 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.2 FI	20.9 F	199.8 F
02/17/25 07:00	0.0 FIC	0.011 FI	5.0 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.8 F
02/17/25 08:00	0.0 FID	0.001 FI	-13.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.8 F
02/17/25 09:00	0.0 FID	0.001 FI	-13.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.0 FI	21.0 F	199.8 F
02/17/25 10:00	0.0 FID	0.001 FI	-13.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.8 F
02/17/25 11:00	0.0 FID	0.001 FI	-14.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.8 F
02/17/25 12:00	0.0 FID	0.001 FI	-15.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.8 F

UNIT SHUTDOWN

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/17/25 13:00	0.0 FID	0.001 FI	-13.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.8 F
02/17/25 14:00	0.0 FID	0.001 FI	-12.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	21.0 F	199.8 F
02/17/25 15:00	0.0 FID	0.001 FI	-13.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.7 FI	21.0 F	199.8 F
02/17/25 16:00	0.0 FID	0.001 FI	-12.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	21.0 F	199.8 F
02/17/25 17:00	0.0 FID	0.001 FI	-12.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.8 F
02/17/25 18:00	0.0 FID	0.001 FI	-12.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	21.0 F	199.8 F
02/17/25 19:00	0.0 FID	0.001 FI	-12.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.8 F
02/17/25 20:00	0.0 FID	0.001 FI	-13.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.8 F
02/17/25 21:00	0.0 FID	0.001 FI	-11.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	21.0 F	199.8 F
02/17/25 22:00	76.3 EU	0.217 E	97.3 E	0.0	0.0	0.0	57.7 EU	0.136 E	37.7 E	17.5	199.8
02/17/25 23:00	16.7 U	0.020	8.9	0.0	0.0	0.0	32.0 EU	0.039 E	10.5 E	15.1	199.9
02/18/25 00:00	16.6	0.021	9.6	0.0	0.0	0.0	12.3	0.016	4.3	15.0	199.8
02/18/25 01:00	17.4	0.023	10.2	0.0	0.0	0.0	12.1	0.016	4.3	15.0	199.8
02/18/25 02:00	17.3	0.023	10.1	0.0	0.0	0.0	12.1	0.016	4.3	15.0	199.8
02/18/25 03:00	16.9	0.022	9.9	0.0	0.0	0.0	12.1	0.016	4.3	15.0	199.8
02/18/25 04:00	17.2	0.022	9.9	0.0	0.0	0.0	12.2	0.016	4.3	15.0	199.8
02/18/25 05:00	17.5	0.022	9.8	0.0	0.0	0.0	12.6	0.016	4.3	15.0	199.8
02/18/25 06:00	14.4 D	0.017	7.4	0.0	0.0	0.0	13.7 D	0.016	4.3	15.0	199.9
02/18/25 07:00	9.3 CD	0.009	3.9	0.0	0.0	0.0 C	15.0 CD	0.016	4.3	14.7 C	199.8
02/18/25 08:00	0.0 FID	0.001 FI	-6.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.0 F	199.8 F
02/18/25 09:00	0.0 FID	0.001 FI	-6.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.3 FI	21.0 F	199.8 F
02/18/25 10:00	0.0 FID	0.001 FI	-6.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.0 F	199.8 F
02/18/25 11:00	0.0 FID	0.001 FI	-5.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
02/18/25 12:00	0.0 FID	0.001 FI	-5.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.0 F	199.8 F
02/18/25 13:00	0.0 FID	0.001 FI	-6.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.0 F	199.8 F
02/18/25 14:00	0.0 FID	0.001 FI	-5.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.0 F	199.8 F
02/18/25 15:00	0.0 FID	0.001 FI	-5.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.0 F	199.8 F
02/18/25 16:00	0.0 FID	0.001 FI	-5.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.0 F	199.8 F
02/18/25 17:00	0.0 FID	0.001 FI	-5.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
02/18/25 18:00	0.0 FID	0.001 FI	-6.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.8 F
02/18/25 19:00	0.0 FID	0.001 FI	-6.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.0 F	199.8 F
02/18/25 20:00	0.0 FID	0.001 FI	-6.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.0 F	199.8 F
02/18/25 21:00	0.0 FID	0.001 FI	-5.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
02/18/25 22:00	0.0 FID	0.001 FI	-4.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.8 F
02/18/25 23:00	0.0 FID	0.001 FI	-5.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.3 FI	21.0 F	199.8 F
02/19/25 00:00	0.0 FID	0.001 FI	-6.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.3 FI	21.0 F	199.8 F
02/19/25 01:00	0.0 FID	0.001 FI	-5.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.0 F	199.8 F

UNIT START UP

UNIT SHUTDOWN

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/19/25 02:00	0.1 FID	0.001 FI	-6.1 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.3 FI	21.0 F	199.8 F
02/19/25 03:00	0.2 FID	0.001 FI	-5.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.0 F	199.8 F
02/19/25 04:00	0.0 FID	0.001 FI	-5.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.3 FI	21.0 F	199.8 F
02/19/25 05:00	0.0 FID	0.001 FI	-5.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.8 F
02/19/25 06:00	0.0 FID	0.001 FI	-5.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
02/19/25 07:00	0.0 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.1 FIC	0.023 F	6.3 F	14.2 FC	199.8 F
02/19/25 08:00	0.0 FID	0.001 FI	32.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.8 FI	20.9 F	199.8 F
02/19/25 09:00	0.0 FID	0.001 FI	26.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.0 FI	20.9 F	199.8 F
02/19/25 10:00	0.0 FID	0.001 FI	22.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.9 FI	20.9 F	199.8 F
02/19/25 11:00	0.0 FID	0.001 FI	37.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.8 FI	20.9 F	199.8 F
02/19/25 12:00	0.0 FID	0.001 FI	30.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.1 FI	20.9 F	199.8 F
02/19/25 13:00	0.2 FID	0.001 FI	29.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.6 FI	20.9 F	199.8 F
02/19/25 14:00	0.0 FID	0.001 FI	26.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.9 FI	20.9 F	199.8 F
02/19/25 15:00	0.0 FID	0.001 FI	28.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.3 FI	20.9 F	199.8 F
02/19/25 16:00	0.0 FID	0.001 FI	29.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.0 FI	20.9 F	199.8 F
02/19/25 17:00	0.0 FID	0.001 FI	29.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.7 FI	20.9 F	199.8 F
02/19/25 18:00	0.0 FID	0.001 FI	31.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.2 FI	20.9 F	199.8 F
02/19/25 19:00	0.0 FID	0.026 FI	11.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.8 F	199.8 F
02/19/25 20:00	0.0 FID	0.001 FI	35.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.5 FI	20.9 F	199.8 F
02/19/25 21:00	0.0 FID	0.001 FI	46.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.9 FI	20.9 F	199.8 F
02/19/25 22:00	0.0 FID	0.001 FI	34.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.6 FI	20.9 F	199.8 F
02/19/25 23:00	0.0 FID	0.001 FI	25.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.6 FI	20.9 F	199.8 F
02/20/25 00:00	0.0 FID	0.001 FI	33.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.0 FI	20.9 F	199.8 F
02/20/25 01:00	0.0 FID	0.001 FI	34.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.8 FI	20.9 F	199.8 F
02/20/25 02:00	0.0 FID	0.001 FI	28.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.2 FI	20.9 F	199.8 F
02/20/25 03:00	0.0 FID	0.001 FI	22.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.3 FI	20.9 F	199.8 F
02/20/25 04:00	0.0 FID	0.001 FI	27.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.8 FI	20.9 F	199.8 F
02/20/25 05:00	0.0 FID	0.001 FI	25.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.7 FI	20.9 F	199.8 F
02/20/25 06:00	0.0 FID	0.001 FI	35.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.9 FI	20.9 F	199.8 F
02/20/25 07:00	0.0 FIC	0.011 FI	5.0 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.8 F
02/20/25 08:00	0.0 FID	0.001 FI	-7.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.8 F
02/20/25 09:00	0.0 FID	0.001 FI	-7.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.8 F
02/20/25 10:00	0.0 FID	0.001 FI	-8.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.0 F	199.8 F
02/20/25 11:00	0.0 FID	0.001 FI	-7.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.1 F	199.8 F
02/20/25 12:00	0.0 FID	0.001 FI	-7.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.1 F	199.8 F
02/20/25 13:00	0.0 FID	0.001 FI	-7.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.3 FI	21.1 F	199.8 F
02/20/25 14:00	0.0 FID	0.001 FI	-7.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.3 FI	21.0 F	199.8 F

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/20/25 15:00	0.0 FID	0.001 FI	-8.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.0 F	199.8 F
02/20/25 16:00	0.0 FID	0.001 FI	-7.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.1 F	199.8 F
02/20/25 17:00	0.0 FID	0.001 FI	-8.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.1 F	199.8 F
02/20/25 18:00	0.1 FID	0.001 FI	-7.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.3 FI	21.0 F	199.8 F
02/20/25 19:00	0.1 FID	0.001 FI	-7.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.1 F	199.8 F
02/20/25 20:00	0.0 FID	0.001 FI	-8.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.4 FI	21.0 F	199.8 F
02/20/25 21:00	0.0 FID	0.001 FI	-8.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
02/20/25 22:00	0.0 FID	0.001 FI	-7.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.1 F	199.8 F
02/20/25 23:00	0.0 FID	0.001 FI	-6.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.1 F	199.8 F
02/21/25 00:00	0.0 FID	0.001 FI	-7.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.1 F	199.8 F
02/21/25 01:00	0.0 FID	0.001 FI	-8.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
02/21/25 02:00	0.0 FID	0.001 FI	-7.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.1 F	199.9 F
02/21/25 03:00	0.0 FID	0.001 FI	-7.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
02/21/25 04:00	0.0 FID	0.001 FI	-7.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
02/21/25 05:00	0.0 FID	0.001 FI	-7.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.3 FI	21.1 F	199.9 F
02/21/25 06:00	0.0 FIM	0.001 FI	-8.4 FI	0.0 F	0.0 F	0.0 FIM	0.1 FIM	0.001 FI	-0.1 FI	21.0 FM	199.9 F
02/21/25 07:00	0.0 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.1 FIC	0.023 F	6.3 F	14.2 FC	199.8 F
02/21/25 08:00	0.0 FID	0.001 FI	620.3 FIE	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.3 FI	20.9 F	199.8 F
02/21/25 09:00	0.0 FID	0.001 FI	47.0 FIE	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
02/21/25 10:00	0.0 FID	0.001 FI	191.0 FIE	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.1 FI	20.9 F	199.8 F
02/21/25 11:00	0.0 FID	0.001 FI	39.9 FIE	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
02/21/25 12:00	0.0 FID	0.001 FI	104.9 FIE	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
02/21/25 13:00	0.0 FID	0.001 FI	65.7 FIE	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
02/21/25 14:00	0.0 FID	0.001 FI	29.3 FIE	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.2 FI	20.9 F	199.8 F
02/21/25 15:00	0.0 FID	0.001 FI	-255.7 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	-0.4 FI	20.9 F	199.8 F
02/21/25 16:00	0.0 FID	0.001 FI	185.4 FIE	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.8 FI	20.9 F	199.8 F
02/21/25 17:00	0.0 FID	0.001 FI	36.1 FIE	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
02/21/25 18:00	0.0 FID	0.001 FI	30.4 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
02/21/25 19:00	0.0 FID	0.001 FI	149.2 FIE	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.1 FI	20.9 F	199.8 F
02/21/25 20:00	0.0 FID	0.001 FI	102.9 FIE	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.3 FI	20.9 F	199.8 F
02/21/25 21:00	0.0 FID	0.001 FI	72.0 FIE	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.2 FI	20.9 F	199.8 F
02/21/25 22:00	0.0 FID	0.001 FI	84.4 FIE	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	1.2 FI	20.9 F	199.8 F
02/21/25 23:00	0.0 FID	0.001 FI	45.0 FIE	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
02/22/25 00:00	0.0 FID	0.001 FI	56.3 FIE	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
02/22/25 01:00	0.0 FID	0.001 FI	59.8 FIE	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
02/22/25 02:00	0.0 FID	0.001 FI	-291.3 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	-0.3 FI	20.9 F	199.8 F
02/22/25 03:00	0.0 FID	0.001 FI	72.9 FIE	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.1 FI	20.9 F	199.8 F

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/22/25 04:00	0.0 FID	0.001 FI	32.9 FIE	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
02/22/25 05:00	0.0 FID	0.001 FI	123.7 FIE	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.6 FI	20.9 F	199.8 F
02/22/25 06:00	0.0 FID	0.001 FI	78.0 FIE	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
02/22/25 07:00	0.0 FIC	0.011 FI	5.0 FI	0.0 F	0.0 F	0.0 FIC	0.1 FIC	0.023 F	6.3 F	14.2 FC	199.8 F
02/22/25 08:00	0.0 FID	0.001 FI	-888.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-19.1 FI	20.9 F	199.8 F
02/22/25 09:00	0.0 FID	0.001 FI	116.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.4 FIE	20.9 F	199.8 F
02/22/25 10:00	0.0 FID	0.001 FI	-670.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-16.6 FI	20.9 F	199.8 F
02/22/25 11:00	0.0 FID	0.001 FI	80.4 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	1.6 FI	20.9 F	199.8 F
02/22/25 12:00	0.0 FID	0.001 FI	195.6 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	5.2 FIE	20.9 F	199.8 F
02/22/25 13:00	0.0 FID	0.001 FI	906.8 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	30.0 FIE	20.9 F	199.8 F
02/22/25 14:00	0.0 FID	0.001 FI	4,532.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	42.5 FIE	20.9 F	199.8 F
02/22/25 15:00	0.0 FID	0.001 FI	95.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.7 FI	20.9 F	199.8 F
02/22/25 16:00	0.0 FID	0.001 FI	208.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	11.3 FIE	20.9 F	199.9 F
02/22/25 17:00	0.0 FID	0.001 FI	99.4 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	3.8 FI	20.9 F	199.9 F
02/22/25 18:00	0.0 FID	0.001 FI	-203.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-9.5 FI	20.9 F	199.8 F
02/22/25 19:00	0.0 FID	0.001 FI	124.9 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	2.8 FI	20.9 F	199.8 F
02/22/25 20:00	0.0 FID	0.001 FI	193.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	10.6 FIE	20.9 F	199.8 F
02/22/25 21:00	33.2 U	0.114 E	50.7 E	0.0	0.0	0.0	61.4 EU	0.088 E	23.9 E	16.5	199.9
02/22/25 22:00	13.9 U	0.018	8.0	0.0	0.0	0.0	12.4 U	0.016	4.4	15.0	199.9
02/22/25 23:00	17.4	0.023	10.0	0.0	0.0	0.0	12.2	0.016	4.3	15.1	199.8
02/23/25 00:00	18.0	0.024	10.5	0.0	0.0	0.0	12.2	0.016	4.4	15.1	199.8
02/23/25 01:00	18.4	0.024	10.8	0.0	0.0	0.0	12.0	0.016	4.3	15.1	199.8
02/23/25 02:00	16.6	0.022	9.8	0.0	0.0	0.0	12.0	0.016	4.3	15.1	199.8
02/23/25 03:00	16.6	0.022	9.8	0.0	0.0	0.0	12.0	0.016	4.3	15.1	199.8
02/23/25 04:00	16.4	0.022	9.6	0.0	0.0	0.0	12.0	0.016	4.3	15.1	199.8
02/23/25 05:00	16.9	0.022	9.9	0.0	0.0	0.0	12.0	0.016	4.3	15.1	199.8
02/23/25 06:00	19.0 D	0.025	11.1	0.0	0.0	0.0	12.0 D	0.016	4.3	15.1	199.8
02/23/25 07:00	94.7 ECD	0.281 E	126.8 E	0.0	0.0	0.0 C	37.8 ECD	0.102 E	28.0 E	16.7 C	199.8
02/23/25 08:00	0.0 FID	0.001 FI	-10.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.3 FI	21.0 F	199.8 F
02/23/25 09:00	0.0 FID	0.001 FI	-11.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.7 FI	21.0 F	199.8 F
02/23/25 10:00	0.0 FID	0.001 FI	-9.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.0 FI	21.0 F	199.8 F
02/23/25 11:00	0.0 FID	0.001 FI	-9.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.6 FI	21.0 F	199.8 F
02/23/25 12:00	0.0 FID	0.001 FI	-11.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.2 FI	21.0 F	199.8 F
02/23/25 13:00	0.0 FID	0.001 FI	-10.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.3 FI	21.0 F	199.8 F
02/23/25 14:00	0.0 FID	0.001 FI	-8.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.2 FI	21.0 F	199.8 F
02/23/25 15:00	0.0 FID	0.001 FI	-9.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.0 FI	21.0 F	199.8 F
02/23/25 16:00	0.0 FID	0.001 FI	-10.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.0 FI	21.0 F	199.8 F

UNIT START UP

UNIT SHUTDOWN

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/23/25 17:00	0.0 FID	0.001 FI	-8.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.0 FI	21.0 F	199.8 F
02/23/25 18:00	0.0 FID	0.001 FI	-8.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.1 FI	21.0 F	199.8 F
02/23/25 19:00	0.0 FID	0.001 FI	-9.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	21.0 F	199.8 F
02/23/25 20:00	0.0 FID	0.001 FI	-8.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.3 FI	21.0 F	199.8 F
02/23/25 21:00	0.0 FID	0.001 FI	-9.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.1 FI	21.0 F	199.8 F
02/23/25 22:00	0.0 FID	0.001 FI	-9.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.0 FI	21.0 F	199.9 F
02/23/25 23:00	0.0 FID	0.001 FI	-21.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.7 FI	20.9 F	199.9 F
02/24/25 00:00	0.0 FID	0.001 FI	-10.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.5 FI	21.0 F	199.8 F
02/24/25 01:00	0.0 FID	0.001 FI	-9.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.4 FI	21.0 F	199.8 F
02/24/25 02:00	0.0 FID	0.001 FI	-9.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.5 FI	21.0 F	199.8 F
02/24/25 03:00	0.0 FID	0.001 FI	-8.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.1 FI	21.0 F	199.8 F
02/24/25 04:00	0.0 FID	0.001 FI	-8.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.0 FI	21.0 F	199.9 F
02/24/25 05:00	0.0 FID	0.001 FI	-8.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.6 FI	21.0 F	199.9 F
02/24/25 06:00	0.0 FID	0.001 FI	-9.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.0 FI	21.0 F	199.9 F
02/24/25 07:00	0.0 FIC	0.011 FI	5.0 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.4 F	14.2 FC	199.8 F
02/24/25 08:00	0.0 FID	0.001 FI	-79.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-12.7 FI	20.9 F	199.8 F
02/24/25 09:00	0.0 FID	0.001 FI	-73.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-11.9 FI	20.9 F	199.8 F
02/24/25 10:00	0.0 FID	0.001 FI	-156.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-20.3 FI	20.9 F	199.8 F
02/24/25 11:00	0.0 FID	0.001 FI	-108.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-12.7 FI	20.9 F	199.8 F
02/24/25 12:00	0.0 FID	0.001 FI	-794.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-78.3 FI	20.9 F	199.8 F
02/24/25 13:00	0.0 FID	0.001 FI	-87.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-12.3 FI	20.9 F	199.8 F
02/24/25 14:00	0.0 FID	0.001 FI	-59.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-8.4 FI	20.9 F	199.8 F
02/24/25 15:00	0.0 FID	0.001 FI	-124.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-18.3 FI	20.9 F	199.8 F
02/24/25 16:00	0.0 FID	0.001 FI	-88.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-16.5 FI	20.9 F	199.8 F
02/24/25 17:00	0.0 FID	0.001 FI	-322.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-42.4 FI	20.9 F	199.8 F
02/24/25 18:00	0.0 FID	0.001 FI	-229.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-31.3 FI	20.9 F	199.8 F
02/24/25 19:00	0.0 FID	0.001 FI	-229.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-29.9 FI	20.9 F	199.8 F
02/24/25 20:00	0.0 FID	0.001 FI	-56.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-9.0 FI	20.9 F	199.8 F
02/24/25 21:00	0.1 FID	0.001 FI	122.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	14.7 FIE	20.9 F	199.8 F
02/24/25 22:00	0.0 FID	0.001 FI	824.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	129.2 FIE	20.9 F	199.8 F
02/24/25 23:00	0.0 FID	0.001 FI	-173.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-25.3 FI	20.9 F	199.8 F
02/25/25 00:00	0.0 FID	0.001 FI	-44.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-7.6 FI	20.9 F	199.8 F
02/25/25 01:00	0.0 FID	0.001 FI	218.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	34.6 FIE	20.9 F	199.8 F
02/25/25 02:00	0.0 FID	0.001 FI	23.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.8 FI	20.9 F	199.8 F
02/25/25 03:00	0.0 FID	0.001 FI	-139.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-23.3 FI	20.9 F	199.8 F
02/25/25 04:00	0.0 FID	0.001 FI	-146.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-18.1 FI	20.9 F	199.8 F
02/25/25 05:00	0.0 FID	0.001 FI	-488.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-89.1 FI	20.9 F	199.8 F

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/25/25 06:00	0.0 FID	0.001 FI	-186.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-27.5 FI	20.9 F	199.8 F
02/25/25 07:00	0.0 FIC	0.011 FI	5.0 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.8 F
02/25/25 08:00	0.0 FID	0.001 FI	-25.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	20.9 F	199.8 F
02/25/25 09:00	0.0 FID	0.001 FI	-29.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	20.9 F	199.8 F
02/25/25 10:00	0.0 FID	0.001 FI	-27.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.5 FI	20.9 F	199.8 F
02/25/25 11:00	0.0 FID	0.001 FI	-22.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	20.9 F	199.8 F
02/25/25 12:00	0.0 FID	0.001 FI	-21.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.3 FI	20.9 F	199.8 F
02/25/25 13:00	0.0 FID	0.001 FI	-17.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.5 FI	20.9 F	199.8 F
02/25/25 14:00	0.4 FID	0.001 FI	-25.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.3 FI	20.9 F	199.8 F
02/25/25 15:00	0.1 FID	0.001 FI	-19.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.4 FI	20.9 F	199.8 F
02/25/25 16:00	0.0 FID	0.001 FI	-27.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.4 FI	20.9 F	199.8 F
02/25/25 17:00	0.1 FID	0.001 FI	-19.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.4 FI	20.9 F	199.8 F
02/25/25 18:00	0.1 FID	0.001 FI	-32.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.7 FI	20.9 F	199.8 F
02/25/25 19:00	0.5 FID	0.001 FI	-22.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	20.9 F	199.8 F
02/25/25 20:00	1.2 FID	0.001 FI	-18.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	20.9 F	199.8 F
02/25/25 21:00	0.7 FID	0.001 FI	-20.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	20.9 F	199.8 F
02/25/25 22:00	0.9 FID	0.001 FI	-20.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.5 FI	20.9 F	199.8 F
02/25/25 23:00	0.9 FID	0.001 FI	-24.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	20.9 F	199.8 F
02/26/25 00:00	1.5 FID	0.001 FI	-27.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	20.9 F	199.8 F
02/26/25 01:00	1.5 FID	0.001 FI	-22.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	20.9 F	199.8 F
02/26/25 02:00	1.1 FID	0.001 FI	-17.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	20.9 F	199.8 F
02/26/25 03:00	0.8 FID	0.001 FI	-27.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	20.9 F	199.8 F
02/26/25 04:00	1.7 FID	0.001 FI	-27.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	20.9 F	199.8 F
02/26/25 05:00	1.2 FID	0.001 FI	-22.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	20.9 F	199.8 F
02/26/25 06:00	1.2 FID	0.001 FI	-33.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	20.9 F	199.8 F
02/26/25 07:00	0.9 FIC	0.013 FI	5.8 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.8 F
02/26/25 08:00	0.9 FID	0.001 FI	-84.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
02/26/25 09:00	0.5 FID	0.001 FI	-173.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
02/26/25 10:00	0.3 FID	0.001 FI	-62.2 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
02/26/25 11:00	0.1 FID	0.001 FI	-124.8 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.4 FI	20.9 F	199.8 F
02/26/25 12:00	0.1 FID	0.001 FI	-131.5 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	-0.2 FI	20.9 F	199.8 F
02/26/25 13:00	0.3 FID	0.001 FI	-388.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-4.0 FI	20.9 F	199.8 F
02/26/25 14:00	0.3 FID	0.001 FI	-153.4 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
02/26/25 15:00	0.0 FID	0.001 FI	-54.8 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
02/26/25 16:00	0.5 FID	0.001 FI	-583.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-2.3 FI	20.9 F	199.8 F
02/26/25 17:00	0.9 FID	0.001 FI	-434.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-7.3 FI	20.9 F	199.8 F
02/26/25 18:00	0.0 FID	0.001 FI	-204.3 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	-0.2 FI	20.9 F	199.8 F

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/26/25 19:00	0.4 FID	0.001 FI	-1,018.9 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.2 FI	20.9 F	199.8 F
02/26/25 20:00	0.0 FID	0.001 FI	-256.5 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.3 FI	20.9 F	199.8 F
02/26/25 21:00	0.0 FID	0.001 FI	-4,035.5 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	-0.5 FI	20.9 F	199.8 F
02/26/25 22:00	0.0 FID	0.001 FI	-914.9 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
02/26/25 23:00	0.1 FID	0.001 FI	-210.5 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	-0.1 FI	20.9 F	199.8 F
02/27/25 00:00	0.0 FID	0.001 FI	-469.4 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	-0.2 FI	20.9 F	199.8 F
02/27/25 01:00	0.0 FID	0.001 FI	-120.1 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	-0.1 FI	20.9 F	199.9 F
02/27/25 02:00	0.1 FID	0.001 FI	-126.9 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
02/27/25 03:00	0.8 FID	0.001 FI	-158.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
02/27/25 04:00	1.9 FID	0.001 FI	-129.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
02/27/25 05:00	2.4 FID	0.001 FI	-216.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	20.9 F	199.9 F
02/27/25 06:00	2.0 FID	0.001 FI	-6,753.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-6.9 FI	20.9 F	199.8 F
02/27/25 07:00	1.4 FIC	0.012 FI	5.2 FI	0.0 F	0.0 F	0.0 FIC	0.1 FIC	0.023 F	6.3 F	14.2 FC	199.8 F
02/27/25 08:00	0.0 FID	0.053 FI	40.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.8 F	199.8 F
02/27/25 09:00	15.3 FID	0.066 FIE	48.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.8 F	199.9 F
02/27/25 10:00	7.7 FID	0.001 FI	60.9 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.7 FI	20.9 F	199.9 F
02/27/25 11:00	0.0 FID	0.053 FI	30.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.8 F	199.9 F
02/27/25 12:00	0.0 FID	0.053 FI	46.9 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.4 FI	20.8 F	199.9 F
02/27/25 13:00	0.0 FID	0.001 FI	66.8 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.7 FI	20.9 F	199.9 F
02/27/25 14:00	0.0 FID	0.001 FI	227.7 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	2.2 FI	20.9 F	199.9 F
02/27/25 15:00	0.0 FID	0.001 FI	-206.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.7 FI	20.9 F	199.9 F
02/27/25 16:00	0.0 FID	0.001 FI	-450.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-3.9 FI	20.9 F	199.9 F
02/27/25 17:00	0.0 FID	0.001 FI	-121.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.0 FI	20.9 F	199.9 F
02/27/25 18:00	0.0 FID	0.001 FI	-93.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.6 FI	20.9 F	199.9 F
02/27/25 19:00	0.0 FID	0.001 FI	-106.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.4 FI	20.9 F	199.9 F
02/27/25 20:00	0.0 FID	0.001 FI	-65.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.4 FI	21.0 F	199.9 F
02/27/25 21:00	34.6 U	0.064 E	28.5 E	0.0	0.0	0.0	69.2 EU	0.113 E	30.7 E	16.0	199.9
02/27/25 22:00	9.9 U	0.011	5.0	0.0	0.0	0.0	13.9 U	0.016	4.3	14.8	199.9
02/27/25 23:00	16.4	0.020	8.8	0.0	0.0	0.0	13.2	0.016	4.3	15.1	199.9
02/28/25 00:00	15.7	0.020	9.1	0.0	0.0	0.0	12.3	0.016	4.3	15.0	199.9
02/28/25 01:00	18.5	0.024	10.9	0.0	0.0	0.0	11.9	0.016	4.3	15.0	199.9
02/28/25 02:00	16.6	0.022	9.7	0.0	0.0	0.0	12.0	0.016	4.3	15.0	199.9
02/28/25 03:00	17.9	0.024	10.5	0.0	0.0	0.0	12.0	0.016	4.3	15.1	199.9
02/28/25 04:00	20.2	0.025	11.1	0.0	0.0	0.0	12.7	0.016	4.3	15.1	199.9
02/28/25 05:00	13.4	0.015	6.8	0.0	0.0	0.0	14.1	0.016	4.4	14.9	199.9
02/28/25 06:00	12.3 D	0.014	6.3	0.0	0.0	0.0	13.8 D	0.016	4.3	14.9	199.9
02/28/25 07:00	97.3 ECD	0.316 E	142.6 E	0.0	0.0	0.0 C	36.6 ECD	0.107 E	29.2 E	16.8 C	199.9

UNIT START UP

UNIT SHUTDOWN

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/28/25 08:00	0.0 FID	0.001 FI	-8.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
02/28/25 09:00	0.0 FID	0.001 FI	-9.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
02/28/25 10:00	0.0 FID	0.001 FI	-7.8 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/28/25 11:00	0.0 FID	0.001 FI	-8.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F
02/28/25 12:00	0.0 FID	0.001 FI	-8.0 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/28/25 13:00	0.0 FID	0.001 FI	-7.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/28/25 14:00	0.0 FID	0.001 FI	-8.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/28/25 15:00	0.0 FID	0.001 FI	-7.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/28/25 16:00	0.0 FID	0.001 FI	-7.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/28/25 17:00	0.0 FID	0.001 FI	-7.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/28/25 18:00	0.0 FID	0.001 FI	-6.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.1 F	199.9 F
02/28/25 19:00	0.0 FID	0.001 FI	-7.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/28/25 20:00	0.0 FID	0.001 FI	-7.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/28/25 21:00	40.5 U	0.090 E	40.2 E	0.0	0.0	0.0	68.8 EU	0.115 E	31.3 E	16.4	199.9
02/28/25 22:00	14.1 U	0.017	7.6	0.0	0.0	0.0	13.1 U	0.016	4.3	15.1	199.9
02/28/25 23:00	18.2	0.023	10.4	0.0	0.0	0.0	12.5	0.016	4.3	15.2	199.9
03/01/25 00:00	20.1	0.025	11.1	0.0	0.0	0.0	12.8	0.016	4.3	15.2	199.9
03/01/25 01:00	18.6	0.023	10.2	0.0	0.0	0.0	13.0	0.016	4.3	15.2	199.9
03/01/25 02:00	16.8	0.022	9.9	0.0	0.0	0.0	12.1	0.016	4.3	15.2	199.9
03/01/25 03:00	17.0	0.023	10.0	0.0	0.0	0.0	12.0	0.016	4.3	15.2	199.9
03/01/25 04:00	17.3	0.023	10.2	0.0	0.0	0.0	12.0	0.016	4.3	15.1	199.9
03/01/25 05:00	18.2	0.023	10.0	0.0	0.0	0.0	12.8	0.016	4.3	15.2	199.9
03/01/25 06:00	16.7 D	0.022	9.8	0.0	0.0	0.0	12.2 D	0.016	4.4	15.1	199.9
03/01/25 07:00	99.0 ECD	0.322 E	145.2 E	0.0	0.0	0.0 C	37.0 ECD	0.107 E	29.3 E	17.0 C	199.9
03/01/25 08:00	0.0 FID	0.001 FI	-6.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.9 F
03/01/25 09:00	0.0 FID	0.001 FI	-5.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.1 F	199.9 F
03/01/25 10:00	0.0 FID	0.001 FI	-5.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.1 F	199.9 F
03/01/25 11:00	0.0 FID	0.001 FI	-6.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.0 FI	21.0 F	199.9 F
03/01/25 12:00	0.0 FID	0.001 FI	-5.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.9 F
03/01/25 13:00	0.0 FID	0.001 FI	-5.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.9 F
03/01/25 14:00	0.0 FID	0.001 FI	-4.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.1 F	199.9 F
03/01/25 15:00	0.0 FID	0.001 FI	-4.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.1 F	199.9 F
03/01/25 16:00	0.0 FID	0.001 FI	-4.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.1 F	199.9 F
03/01/25 17:00	0.0 FID	0.001 FI	-4.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.1 F	199.9 F
03/01/25 18:00	0.0 FID	0.001 FI	-4.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.1 F	199.9 F
03/01/25 19:00	0.0 FID	0.001 FI	-4.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.1 F	199.9 F
03/01/25 20:00	0.0 FID	0.001 FI	-4.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.9 F

UNIT START UP

UNIT SHUTDOWN

Source		UNIT_B										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/01/25	21:00	0.0 FID	0.001 FI	-4.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.1 F	199.9 F
03/01/25	22:00	0.0 FID	0.001 FI	-4.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.1 F	199.9 F
03/01/25	23:00	0.0 FID	0.001 FI	-4.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.1 F	199.9 F
03/02/25	00:00	0.0 FID	0.001 FI	-4.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.8 F
03/02/25	01:00	0.0 FID	0.001 FI	-4.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.3 FI	21.1 F	199.8 F
03/02/25	02:00	0.0 FID	0.001 FI	-4.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.8 F
03/02/25	03:00	0.0 FID	0.001 FI	-3.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.8 F
03/02/25	04:00	0.0 FID	0.001 FI	-4.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.8 F
03/02/25	05:00	0.0 FID	0.001 FI	-4.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.1 F	199.8 F
03/02/25	06:00	0.0 FID	0.001 FI	-3.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.1 F	199.8 F
03/02/25	07:00	0.0 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.4 F	14.2 FC	199.8 F
03/02/25	08:00	0.0 FID	0.001 FI	-10.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	21.0 F	199.8 F
03/02/25	09:00	0.0 FID	0.001 FI	-11.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.8 F
03/02/25	10:00	0.0 FID	0.001 FI	-10.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.8 F
03/02/25	11:00	0.0 FID	0.001 FI	-10.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.8 F
03/02/25	12:00	0.0 FID	0.001 FI	-10.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.8 F
03/02/25	13:00	0.0 FID	0.001 FI	-10.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.8 F
03/02/25	14:00	0.0 FID	0.001 FI	-11.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.8 F
03/02/25	15:00	0.0 FID	0.001 FI	-10.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.8 F
03/02/25	16:00	0.0 FID	0.001 FI	-10.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.8 F
03/02/25	17:00	0.0 FID	0.001 FI	-11.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.6 FI	21.0 F	199.8 F
03/02/25	18:00	0.0 FID	0.001 FI	-10.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.8 F
03/02/25	19:00	0.0 FID	0.001 FI	-9.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.8 F
03/02/25	20:00	0.0 FID	0.001 FI	-10.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.8 F
03/02/25	21:00	44.7 U	0.085 E	38.3 E	0.0	0.0	0.0	70.4 EU	0.114 E	31.3 E	16.2	199.9
03/02/25	22:00	17.2 U	0.020	8.8	0.0	0.0	0.0	13.7 U	0.016	4.3	15.0	199.9
03/02/25	23:00	14.4	0.016	7.3	0.0	0.0	0.0	14.2	0.016	4.5	15.0	199.9
03/03/25	00:00	12.4	0.016	7.0	0.0	0.0	0.0	13.0	0.017	4.5	15.0	199.9
03/03/25	01:00	16.1	0.021	9.5	0.0	0.0	0.0	12.0	0.016	4.3	15.1	199.9
03/03/25	02:00	20.3	0.026	11.6	0.0	0.0	0.0	12.3	0.016	4.3	15.1	199.9
03/03/25	03:00	16.4	0.021	9.5	0.0	0.0	0.0	12.2	0.016	4.3	15.1	199.9
03/03/25	04:00	18.0	0.023	10.5	0.0	0.0	0.0	12.1	0.016	4.3	15.1	199.9
03/03/25	05:00	20.5	0.026	11.6	0.0	0.0	0.0	12.3	0.016	4.3	15.2	199.9
03/03/25	06:00	18.0 D	0.022	9.6	0.0	0.0	0.0	13.3 D	0.016	4.4	15.2	199.9
03/03/25	07:00	105.7 ECD	0.332 E	149.8 E	0.0	0.0	0.0 C	40.6 ECD	0.115 E	31.6 E	17.0 C	199.9
03/03/25	08:00	0.0 FID	0.001 FI	-23.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.4 FI	20.9 F	199.9 F
03/03/25	09:00	0.0 FID	0.001 FI	-21.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.6 FI	20.9 F	199.9 F

UNIT START UP

UNIT SHUTDOWN

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/03/25 10:00	0.0 FID	0.001 FI	-22.7 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.2 FI	20.9 F	199.9 F
03/03/25 11:00	0.0 FID	0.001 FI	-20.8 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.4 FI	20.9 F	199.9 F
03/03/25 12:00	0.0 FID	0.001 FI	-14.0 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.2 FI	20.9 F	199.9 F
03/03/25 13:00	0.0 FID	0.001 FI	-17.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.5 FI	20.9 F	199.9 F
03/03/25 14:00	0.0 FID	0.001 FI	-15.5 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.3 FI	20.9 F	199.9 F
03/03/25 15:00	0.0 FID	0.001 FI	-20.0 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.2 FI	20.9 F	199.9 F
03/03/25 16:00	0.0 FID	0.001 FI	-18.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	20.9 F	199.9 F
03/03/25 17:00	0.0 FID	0.001 FI	-16.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.4 FI	20.9 F	199.8 F
03/03/25 18:00	0.0 FID	0.001 FI	-17.4 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.3 FI	20.9 F	199.8 F
03/03/25 19:00	0.0 FID	0.001 FI	-17.9 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.2 FI	20.9 F	199.8 F
03/03/25 20:00	0.0 FID	0.001 FI	-17.6 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
03/03/25 21:00	44.6 U	0.089 E	39.8 E	0.0	0.0	0.0	79.7 EU	0.122 E	33.2 E	16.2	199.9
03/03/25 22:00	11.8 U	0.013	6.0	0.0	0.0	0.0	13.9 U	0.016	4.3	14.9	199.9
03/03/25 23:00	11.0	0.013	5.5	0.0	0.0	0.0	14.2	0.016	4.4	15.0	199.9
03/04/25 00:00	21.9	0.026	11.8	0.0	0.0	0.0	59.3 E	0.074 E	20.1 E	15.0	199.9
03/04/25 01:00	10.2	0.012	5.5	0.0	0.0	0.0	13.7	0.016	4.5	14.9	199.9
03/04/25 02:00	16.1	0.021	9.2	0.0	0.0	0.0	12.2	0.016	4.3	15.0	199.9
03/04/25 03:00	18.5	0.024	10.5	0.0	0.0	0.0	12.4	0.016	4.3	15.1	199.9
03/04/25 04:00	15.3	0.017	7.7	0.0	0.0	0.0	13.8	0.015	4.2	15.0	199.9
03/04/25 05:00	14.6	0.017	7.4	0.0	0.0	0.0	13.9	0.016	4.3	15.0	199.9
03/04/25 06:00	12.3 D	0.014	6.2	0.0	0.0	0.0	14.0 D	0.016	4.3	15.0	199.9
03/04/25 07:00	95.3 ECD	0.299 E	133.7 E	0.0	0.0	0.0 C	40.2 ECD	0.112 E	30.6 E	16.9 C	199.9
03/04/25 08:00	0.0 FID	0.026 FI	14.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.022 FIE	4.2 FI	20.8 F	199.9 F
03/04/25 09:00	0.0 FID	0.026 FI	13.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.022 FIE	4.9 FI	20.8 F	199.8 F
03/04/25 10:00	0.0 FID	0.013 FI	13.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.2 FI	20.8 F	199.8 F
03/04/25 11:00	0.0 FID	0.026 FI	11.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.022 FIE	4.5 FI	20.8 F	199.8 F
03/04/25 12:00	0.0 FID	0.026 FI	13.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.022 FIE	4.7 FI	20.8 F	199.8 F
03/04/25 13:00	0.0 FID	0.013 FI	11.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.7 FI	20.8 F	199.9 F
03/04/25 14:00	0.0 FID	0.013 FI	13.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.4 FI	20.8 F	199.8 F
03/04/25 15:00	0.0 FID	0.013 FI	11.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.022 FIE	5.0 FI	20.8 F	199.8 F
03/04/25 16:00	0.0 FID	0.013 FI	11.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.1 FI	20.8 F	199.9 F
03/04/25 17:00	0.0 FID	0.013 FI	11.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.1 FI	20.8 F	199.8 F
03/04/25 18:00	0.0 FID	0.013 FI	13.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.7 FI	20.8 F	199.9 F
03/04/25 19:00	0.0 FID	0.013 FI	12.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.022 FIE	4.6 FI	20.8 F	199.8 F
03/04/25 20:00	0.0 FID	0.026 FI	17.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.022 FIE	5.5 FIE	20.8 F	199.9 F
03/04/25 21:00	38.9 U	0.069 E	30.5 E	0.0	0.0	0.0	68.0 EU	0.110 E	29.6 E	16.0	199.9
03/04/25 22:00	10.9 U	0.012	5.5	0.0	0.0	0.0	13.8 U	0.016	4.2	14.9	199.9

UNIT START UP

*SEE DEVIATION REPORT CC-2273 Sec 6

UNIT SHUTDOWN

UNIT START UP

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/04/25 23:00	16.4	0.019	8.6	0.0	0.0	0.0	13.4	0.016	4.3	15.1	199.9
03/05/25 00:00	12.5	0.014	6.3	0.0	0.0	0.0	14.1	0.016	4.4	15.0	199.9
03/05/25 01:00	9.9	0.011	5.0	0.0	0.0	0.0	14.2	0.016	4.4	14.9	199.9
03/05/25 02:00	8.7	0.010	4.4	0.0	0.0	0.0	14.0	0.016	4.3	14.9	199.9
03/05/25 03:00	7.0	0.008	3.4	0.0	0.0	0.0	14.4	0.016	4.3	14.8	199.9
03/05/25 04:00	6.1	0.007	3.0	0.0	0.0	0.0	14.6	0.016	4.4	14.8	199.9
03/05/25 05:00	5.6	0.006	2.7	0.0	0.0	0.0	15.1	0.016	4.5	14.8	199.9
03/05/25 06:00	10.2	0.012	5.2	0.0	0.0	0.0	13.9	0.016	4.3	15.0	199.8
03/05/25 07:00	7.3 CD	0.008	3.5	0.0	0.0	0.0 C	14.6 CD	0.017	4.5	14.8 C	199.8
03/05/25 08:00	95.0 ED	0.301 E	132.5 E	0.0	0.0	0.0	40.5 ED	0.113 E	30.4 E	17.0	199.8
UNIT SHUTDOWN											
03/05/25 09:00	0.0 FID	0.001 FI	-4.0 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.1 F	199.8 F
03/05/25 10:00	0.0 FID	0.001 FI	-3.5 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.1 F	199.8 F
03/05/25 11:00	0.0 FID	0.001 FI	-3.5 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.1 F	199.8 F
03/05/25 12:00	0.0 FID	0.001 FI	-3.2 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.0 FI	21.1 F	199.8 F
03/05/25 13:00	0.0 FID	0.001 FI	-3.6 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.1 F	199.8 F
03/05/25 14:00	0.0 FID	0.001 FI	-3.4 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.1 F	199.8 F
03/05/25 15:00	0.0 FID	0.001 FI	-3.2 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.1 F	199.8 F
03/05/25 16:00	0.0 FID	0.001 FI	-2.7 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.1 F	199.8 F
03/05/25 17:00	0.0 FID	0.001 FI	-2.7 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.1 F	199.8 F
03/05/25 18:00	0.0 FID	0.001 FI	-2.3 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.0 FI	21.1 F	199.8 F
03/05/25 19:00	0.0 FID	0.001 FI	-2.7 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.0 FI	21.1 F	199.8 F
03/05/25 20:00	0.0 FID	0.001 FI	-2.0 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.0 FI	21.1 F	199.8 F
03/05/25 21:00	41.4 U	0.081 E	36.4 E	0.0	0.0	0.0	74.0 EU	0.116 E	31.6 E	16.2	199.8
03/05/25 22:00	12.8 U	0.015	6.7	0.0	0.0	0.0	13.4 U	0.016	4.3	15.1	199.8
03/05/25 23:00	17.4 D	0.021	9.3	0.0	0.0	0.0	13.6 D	0.016	4.4	15.2	199.8
03/06/25 00:00	96.0 ED	0.338 E	151.9 E	0.0	0.0	0.0	36.1 ED	0.108 E	29.5 E	17.2	199.8
UNIT SHUTDOWN											
03/06/25 01:00	0.0 FID	0.001 FI	-4.1 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.1 F	199.8 F
03/06/25 02:00	0.0 FID	0.001 FI	-3.8 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.1 F	199.9 F
03/06/25 03:00	0.0 FID	0.001 FI	-3.3 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.0 FI	21.1 F	199.9 F
03/06/25 04:00	0.0 FID	0.001 FI	-3.1 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.1 F	199.9 F
03/06/25 05:00	0.0 FID	0.001 FI	-3.1 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.1 F	199.9 F
03/06/25 06:00	0.0 FID	0.001 FI	-3.1 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.1 F	199.9 F
03/06/25 07:00	0.0 FIC	0.011 FI	5.0 FI	0.0 F	0.0 F	0.0 FIC	0.1 FIC	0.023 F	6.3 F	14.2 FC	199.9 F
03/06/25 08:00	0.0 FID	0.001 FI	36.3 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.6 FI	20.9 F	199.8 F
03/06/25 09:00	0.0 FID	0.001 FI	39.6 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.8 FI	20.9 F	199.8 F
03/06/25 10:00	0.0 FID	0.001 FI	59.7 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.4 FI	20.9 F	199.9 F
03/06/25 11:00	0.0 FID	0.001 FI	204.0 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	5.0 FIE	20.9 F	199.9 F

UNIT SHUTDOWN

UNIT START UP

UNIT SHUTDOWN

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/06/25 12:00	0.0 FID	0.001 FI	50.8 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.7 FI	20.9 F	199.9 F
03/06/25 13:00	0.0 FID	0.001 FI	38.7 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	1.0 FI	20.9 F	199.8 F
03/06/25 14:00	0.0 FID	0.001 FI	-1,947.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-16.6 FI	20.9 F	199.8 F
03/06/25 15:00	0.0 FID	0.001 FI	68.9 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.6 FI	20.9 F	199.8 F
03/06/25 16:00	0.0 FID	0.001 FI	113.5 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	1.1 FI	20.9 F	199.8 F
03/06/25 17:00	0.0 FID	0.001 FI	70.3 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	1.0 FI	20.9 F	199.8 F
03/06/25 18:00	0.0 FID	0.001 FI	116.3 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	1.1 FI	20.9 F	199.9 F
03/06/25 19:00	0.0 FID	0.001 FI	285.9 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	2.0 FI	20.9 F	199.9 F
03/06/25 20:00	0.0 FID	0.026 FI	21.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.3 FI	20.8 F	199.9 F
03/06/25 21:00	47.5 U	0.093 E	41.7 E	0.0	0.0	0.0	76.0 EU	0.119 E	32.3 E	16.1	199.9
03/06/25 22:00	17.4 U	0.021	9.4	0.0	0.0	0.0	12.6 U	0.015	4.2	15.0	199.9
03/06/25 23:00	15.4	0.020	8.9	0.0	0.0	0.0	12.4	0.016	4.4	15.0	199.9
03/07/25 00:00	19.6	0.025	11.2	0.0	0.0	0.0	12.2	0.016	4.3	15.1	199.9
03/07/25 01:00	17.2	0.022	9.9	0.0	0.0	0.0	12.3	0.016	4.3	15.0	199.9
03/07/25 02:00	17.0	0.022	9.8	0.0	0.0	0.0	12.2	0.016	4.3	15.0	199.9
03/07/25 03:00	17.9	0.023	10.3	0.0	0.0	0.0	12.2	0.016	4.3	15.1	199.9
03/07/25 04:00	16.4	0.019	8.7	0.0	0.0	0.0	13.7	0.016	4.3	15.0	199.9
03/07/25 05:00	13.1	0.015	6.7	0.0	0.0	0.0	14.0	0.016	4.4	15.0	199.8
03/07/25 06:00	7.0 MD	0.008	3.4	0.0	0.0	0.0 M	14.8 MD	0.017	4.5	14.9 M	199.8
03/07/25 07:00	6.3 CD	0.009	4.0	0.0	0.0	0.0 C	15.0 CD	0.016	4.4	14.7 C	199.8
03/07/25 08:00	0.0 FID	0.001 FI	-10.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
03/07/25 09:00	0.0 FID	0.001 FI	-9.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.0 F	199.8 F
03/07/25 10:00	0.0 FID	0.001 FI	-8.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
03/07/25 11:00	0.0 FID	0.001 FI	-8.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
03/07/25 12:00	0.0 FID	0.001 FI	-9.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/07/25 13:00	0.0 FID	0.001 FI	-8.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
03/07/25 14:00	0.0 FID	0.001 FI	-8.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/07/25 15:00	0.0 FID	0.001 FI	-7.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
03/07/25 16:00	0.0 FID	0.001 FI	-8.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
03/07/25 17:00	0.0 FID	0.001 FI	-8.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
03/07/25 18:00	0.0 FID	0.001 FI	-11.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
03/07/25 19:00	0.0 FID	0.001 FI	-9.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/07/25 20:00	0.0 FID	0.001 FI	-9.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/07/25 21:00	38.8 U	0.067 E	29.9 E	0.0	0.0	0.0	76.6 EU	0.119 E	32.5 E	16.0	199.9
03/07/25 22:00	13.6 U	0.016	7.2	0.0	0.0	0.0	13.5 U	0.016	4.4	15.1	199.9
03/07/25 23:00	14.2	0.016	7.2	0.0	0.0	0.0	13.6	0.015	4.2	15.0	199.9
03/08/25 00:00	11.6	0.013	5.9	0.0	0.0	0.0	14.1	0.016	4.4	15.0	199.9

UNIT START UP

UNIT SHUTDOWN

UNIT START UP

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/08/25 01:00	11.9	0.014	6.1	0.0	0.0	0.0	13.9	0.016	4.4	15.0	199.9
03/08/25 02:00	11.9	0.013	6.0	0.0	0.0	0.0	14.0	0.016	4.3	15.0	199.9
03/08/25 03:00	10.4	0.012	5.2	0.0	0.0	0.0	13.9	0.016	4.3	15.0	199.9
03/08/25 04:00	10.6	0.012	5.3	0.0	0.0	0.0	14.1	0.016	4.4	15.0	199.9
03/08/25 05:00	12.8	0.015	6.5	0.0	0.0	0.0	13.9	0.016	4.4	15.1	199.9
03/08/25 06:00	14.3 D	0.017	7.4	0.0	0.0	0.0	13.6 D	0.016	4.3	15.1	199.9
03/08/25 07:00	97.9 ECD	0.316 E	142.6 E	0.0	0.0	0.0 C	40.4 ECD	0.116 E	31.8 E	17.0 C	199.9
UNIT SHUTDOWN											
03/08/25 08:00	0.0 FID	0.001 FI	-9.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/08/25 09:00	0.0 FID	0.001 FI	-7.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
03/08/25 10:00	0.0 FID	0.001 FI	-7.4 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/08/25 11:00	0.0 FID	0.001 FI	-7.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/08/25 12:00	0.0 FID	0.001 FI	-6.7 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/08/25 13:00	0.0 FID	0.001 FI	-8.2 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
03/08/25 14:00	0.0 FID	0.001 FI	-6.7 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/08/25 15:00	0.0 FID	0.001 FI	-7.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/08/25 16:00	0.0 FID	0.001 FI	-8.8 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/08/25 17:00	0.0 FID	0.001 FI	-8.7 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/08/25 18:00	0.0 FID	0.001 FI	-9.5 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/08/25 19:00	0.0 FID	0.001 FI	-10.6 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/08/25 20:00	0.0 FID	0.001 FI	-10.6 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.1 F	199.9 F
UNIT START UP											
03/08/25 21:00	34.8 U	0.059 E	26.5 E	0.0	0.0	0.0	72.3 EU	0.114 E	31.0 E	16.0	199.9
03/08/25 22:00	12.0 U	0.014	6.1	0.0	0.0	0.0	13.9 U	0.016	4.3	15.1	199.9
03/08/25 23:00	12.9	0.015	6.6	0.0	0.0	0.0	13.9	0.016	4.3	15.1	199.9
03/09/25 00:00	16.4	0.021	9.3	0.0	0.0	0.0	12.9	0.016	4.4	15.1	199.9
03/09/25 01:00	19.4	0.024	10.8	0.0	0.0	0.0	12.6	0.016	4.3	15.1	199.9
03/09/25 02:00	17.6	0.022	9.9	0.0	0.0	0.0	12.5	0.016	4.3	15.1	199.9
03/09/25 03:00	17.8	0.023	10.2	0.0	0.0	0.0	12.3	0.016	4.3	15.1	199.9
03/09/25 04:00	12.3	0.014	6.4	0.0	0.0	0.0	13.9	0.016	4.4	15.1	199.9
03/09/25 05:00	10.8	0.012	5.4	0.0	0.0	0.0	13.7	0.015	4.2	15.0	199.9
03/09/25 06:00	13.9 D	0.016	7.3	0.0	0.0	0.0	13.6 D	0.016	4.4	15.1	199.9
03/09/25 07:00	92.6 ECD	0.302 E	134.3 E	0.0	0.0	0.0 C	40.0 ECD	0.115 E	31.0 E	17.0 C	199.9
UNIT SHUTDOWN											
03/09/25 08:00	0.0 FID	0.001 FI	-16.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.0 FI	20.9 F	199.9 F
03/09/25 09:00	0.0 FID	0.001 FI	-11.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.3 FI	20.9 F	199.9 F
03/09/25 10:00	0.0 FID	0.001 FI	-9.5 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.4 FI	21.0 F	199.9 F
03/09/25 11:00	0.0 FID	0.001 FI	-10.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.4 FI	20.9 F	199.9 F
03/09/25 12:00	0.0 FID	0.001 FI	-8.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	20.9 F	199.9 F
03/09/25 13:00	0.0 FID	0.001 FI	-10.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	20.9 F	199.9 F

UNIT SHUTDOWN

UNIT START UP

UNIT SHUTDOWN

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/09/25 14:00	0.0 FID	0.001 FI	-9.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.4 FI	20.9 F	199.9 F
03/09/25 15:00	0.0 FID	0.001 FI	-9.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.5 FI	20.9 F	199.9 F
03/09/25 16:00	0.0 FID	0.001 FI	-7.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	20.9 F	199.9 F
03/09/25 17:00	0.0 FID	0.001 FI	-7.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
03/09/25 18:00	0.0 FID	0.001 FI	-10.2 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.3 FI	20.9 F	199.9 F
03/09/25 19:00	0.0 FID	0.001 FI	-7.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	20.9 F	199.9 F
03/09/25 20:00	0.0 FID	0.001 FI	-9.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.3 FI	20.9 F	199.9 F
03/09/25 21:00	39.6 U	0.070 E	31.3 E	0.0	0.0	0.0	69.6 EU	0.111 E	30.2 E	16.0	199.9
03/09/25 22:00	10.4 U	0.012	5.3	0.0	0.0	0.0	13.7 U	0.016	4.3	15.0	199.9
03/09/25 23:00	9.2	0.011	4.7	0.0	0.0	0.0	13.9	0.016	4.3	15.0	199.9
03/10/25 00:00	14.5	0.018	8.0	0.0	0.0	0.0	13.1	0.016	4.4	15.1	199.9
03/10/25 01:00	17.1	0.022	9.8	0.0	0.0	0.0	12.4	0.016	4.3	15.1	199.9
03/10/25 02:00	13.1	0.015	6.8	0.0	0.0	0.0	13.7	0.016	4.3	15.0	199.9
03/10/25 03:00	9.7	0.011	4.9	0.0	0.0	0.0	14.1	0.016	4.3	15.0	199.9
03/10/25 04:00	9.6	0.011	4.8	0.0	0.0	0.0	14.1	0.016	4.3	15.0	199.9
03/10/25 05:00	6.7	0.007	3.2	0.0	0.0	0.0	15.1	0.016	4.3	14.8	199.9
03/10/25 06:00	8.9 CD	0.010	4.5	0.0	0.0	0.0 C	14.4 CD	0.017	4.6	14.9 C	199.9
03/10/25 07:00	102.0 ED	0.327 E	144.2 E	0.0	0.0	0.0	39.0 ED	0.112 E	30.1 E	17.0	199.9
03/10/25 08:00	0.0 FID	0.001 FI	-17.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/10/25 09:00	0.0 FID	0.001 FI	-17.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
03/10/25 10:00	0.0 FID	0.001 FI	-14.1 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
03/10/25 11:00	0.0 FID	0.001 FI	-18.1 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F
03/10/25 12:00	0.0 FID	0.001 FI	-12.3 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
03/10/25 13:00	0.0 FID	0.001 FI	-12.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
03/10/25 14:00	0.0 FID	0.001 FI	-12.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/10/25 15:00	0.0 FID	0.001 FI	-14.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
03/10/25 16:00	0.0 FID	0.001 FI	-12.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
03/10/25 17:00	0.0 FID	0.001 FI	-11.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/10/25 18:00	0.0 FID	0.001 FI	-11.8 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/10/25 19:00	0.0 FID	0.001 FI	-10.2 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/10/25 20:00	39.0 U	0.076 E	33.8 E	0.0	0.0	0.0	67.5 EU	0.107 E	28.9 E	16.1	199.9
03/10/25 21:00	17.3 U	0.021	9.4	0.0	0.0	0.0	12.9 U	0.016	4.3	15.2	199.9
03/10/25 22:00	21.7	0.026	11.7	0.0	0.0	0.0	13.2	0.016	4.3	15.2	199.9
03/10/25 23:00	19.6	0.024	10.6	0.0	0.0	0.0	13.2	0.016	4.3	15.2	199.9
03/11/25 00:00	13.3	0.016	7.0	0.0	0.0	0.0	13.6	0.016	4.4	15.1	199.9
03/11/25 01:00	17.8	0.022	9.6	0.0	0.0	0.0	13.1	0.016	4.3	15.2	199.9
03/11/25 02:00	17.8	0.022	9.7	0.0	0.0	0.0	13.2	0.016	4.4	15.2	199.9

UNIT START UP

UNIT SHUTDOWN

UNIT START UP

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/11/25 03:00	17.1	0.021	9.4	0.0	0.0	0.0	13.1	0.016	4.4	15.2	199.9
03/11/25 04:00	19.1	0.023	10.3	0.0	0.0	0.0	13.1	0.016	4.3	15.2	199.9
03/11/25 05:00	17.9	0.021	9.4	0.0	0.0	0.0	13.4	0.016	4.3	15.1	199.9
03/11/25 06:00	11.2 CD	0.012	5.2	0.0	0.0	0.0 C	14.3 CD	0.017	4.6	14.9 C	199.9
03/11/25 07:00	102.7 ED	0.342 E	152.0 E	0.0	0.0	0.0	35.9 ED	0.107 E	29.0 E	17.0	199.8
UNIT SHUTDOWN											
03/11/25 08:00	0.0 FID	0.001 FI	-363.8 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	-0.6 FI	20.9 F	199.9 F
03/11/25 09:00	0.0 FID	0.001 FI	310.2 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	1.7 FI	20.9 F	199.9 F
03/11/25 10:00	0.0 FID	0.001 FI	-327.5 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-3.2 FI	20.9 F	199.9 F
03/11/25 11:00	0.0 FID	0.001 FI	77.2 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.2 FI	20.9 F	199.8 F
03/11/25 12:00	0.0 FID	0.001 FI	57.8 FIE	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.1 FI	20.9 F	199.8 F
03/11/25 13:00	0.0 FID	0.001 FI	75.0 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.6 FI	20.9 F	199.8 F
03/11/25 14:00	0.0 FID	0.001 FI	-243.9 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
03/11/25 15:00	0.0 FID	0.001 FI	2,092.4 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	1.2 FI	20.9 F	199.8 F
03/11/25 16:00	0.0 FID	0.001 FI	285.4 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.8 FI	20.9 F	199.8 F
03/11/25 17:00	0.0 FID	0.001 FI	-60.3 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.3 FI	20.9 F	199.8 F
03/11/25 18:00	0.0 FID	0.001 FI	66.3 FIE	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.1 FI	20.9 F	199.8 F
03/11/25 19:00	0.0 FID	0.013 FI	15.6 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
03/11/25 20:00	43.8 U	0.076 E	34.9 E	0.0	0.0	0.0	74.6 EU	0.112 E	30.6 E	15.9	199.8
03/11/25 21:00	12.2 U	0.014	6.1	0.0	0.0	0.0	13.1 U	0.015	4.0	14.7	199.8
03/11/25 22:00	6.4 D	0.007	3.2	0.0	0.0	0.0	14.7 D	0.017	4.5	14.8	199.8
03/11/25 23:00	98.5 ED	0.310 E	138.1 E	0.0	0.0	0.0	38.4 ED	0.115 E	31.1 E	16.8	199.8
UNIT SHUTDOWN											
03/12/25 00:00	0.0 FID	0.001 FI	61.0 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.2 FI	20.9 F	199.8 F
03/12/25 01:00	0.0 FID	0.001 FI	89.7 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.5 FI	20.9 F	199.8 F
03/12/25 02:00	0.0 FID	0.001 FI	64.5 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.4 FI	20.9 F	199.8 F
03/12/25 03:00	0.0 FID	0.001 FI	423.0 FIE	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	1.2 FI	20.9 F	199.8 F
03/12/25 04:00	0.0 FID	0.001 FI	265.2 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
03/12/25 05:00	0.0 FIM	0.001 FI	-13,364.9 FI	0.0 F	0.0 F	0.0 FIM	0.3 FIM	0.001 FI	-16.4 FI	20.9 FM	199.8 F
03/12/25 06:00	0.0 FIC	0.011 FI	5.0 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.8 F
03/12/25 07:00	0.0 FID	0.001 FI	191.5 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	1.3 FI	20.9 F	199.8 F
03/12/25 08:00	0.0 FID	0.001 FI	-527.9 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-2.1 FI	20.9 F	199.8 F
03/12/25 09:00	0.0 FID	0.001 FI	-206.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.6 FI	20.9 F	199.8 F
03/12/25 10:00	0.0 FID	0.001 FI	-61.0 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.4 FI	20.9 F	199.8 F
03/12/25 11:00	0.0 FID	0.001 FI	-77.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.9 FI	20.9 F	199.8 F
03/12/25 12:00	0.0 FID	0.001 FI	-86.6 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.8 FI	20.9 F	199.8 F
03/12/25 13:00	0.0 FID	0.001 FI	-99.7 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-1.0 FI	20.9 F	199.8 F
03/12/25 14:00	0.0 FID	0.001 FI	-71.5 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.6 FI	20.9 F	199.8 F
03/12/25 15:00	0.0 FID	0.001 FI	-63.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	20.9 F	199.8 F

UNIT SHUTDOWN

UNIT START UP

UNIT SHUTDOWN

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/12/25 16:00	0.0 FID	0.001 FI	328.8 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	2.0 FI	20.9 F	199.8 F
03/12/25 17:00	0.0 FID	0.001 FI	-51.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	20.9 F	199.8 F
03/12/25 18:00	0.0 FID	0.001 FI	-43.8 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.5 FI	20.9 F	199.8 F
03/12/25 19:00	0.0 FID	0.001 FI	-141.1 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
03/12/25 20:00	0.0 FID	0.001 FI	-74.1 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.3 FI	20.9 F	199.8 F
03/12/25 21:00	0.0 FID	0.001 FI	-605.4 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	-0.4 FI	20.9 F	199.8 F
03/12/25 22:00	0.0 FID	0.001 FI	98.0 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.5 FI	20.9 F	199.8 F
03/12/25 23:00	0.0 FID	0.001 FI	188.5 FIE	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.7 FI	20.9 F	199.8 F
03/13/25 00:00	0.0 FID	0.001 FI	42.5 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
03/13/25 01:00	0.0 FID	0.001 FI	-302.0 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-4.3 FI	20.9 F	199.8 F
03/13/25 02:00	0.0 FID	0.001 FI	-129.7 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-1.4 FI	20.9 F	199.8 F
03/13/25 03:00	0.0 FID	0.001 FI	220.9 FIE	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	2.0 FI	20.9 F	199.8 F
03/13/25 04:00	0.0 FID	0.001 FI	149.8 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	2.9 FI	20.9 F	199.8 F
03/13/25 05:00	0.0 FID	0.001 FI	-265.6 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-1.8 FI	20.9 F	199.8 F
03/13/25 06:00	0.0 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.8 F
03/13/25 07:00	0.0 FID	0.001 FI	-7.7 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
03/13/25 08:00	0.0 FID	0.001 FI	-7.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
03/13/25 09:00	0.0 FID	0.001 FI	-7.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
03/13/25 10:00	0.0 FID	0.001 FI	-6.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.1 F	199.8 F
03/13/25 11:00	0.0 FID	0.001 FI	-7.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
03/13/25 12:00	0.0 FID	0.001 FI	-8.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
03/13/25 13:00	0.0 FID	0.001 FI	-8.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.0 F	199.8 F
03/13/25 14:00	0.0 FID	0.001 FI	-8.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.0 F	199.8 F
03/13/25 15:00	0.0 FID	0.001 FI	-9.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
03/13/25 16:00	0.0 FID	0.001 FI	-9.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
03/13/25 17:00	0.0 FID	0.001 FI	-7.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.0 F	199.8 F
03/13/25 18:00	0.0 FID	0.001 FI	-7.6 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
03/13/25 19:00	0.0 FID	0.001 FI	-7.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/13/25 20:00	56.6 EU	0.111 E	50.0 E	0.0	0.0	0.0	127.0 EU	0.217 E	59.5 E	16.5	199.9
03/13/25 21:00	12.4 U	0.014	6.3	0.0	0.0	0.0	16.2 U	0.018 E	4.9	15.0	199.9
03/13/25 22:00	12.7 D	0.015	6.5	0.0	0.0	0.0	14.0 D	0.016	4.4	15.0	199.9
03/13/25 23:00	105.1 ED	0.336 E	151.2 E	0.0	0.0	0.0	45.5 ED	0.129 E	35.4 E	17.0	199.9
03/14/25 00:00	0.0 FID	0.001 FI	-10.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
03/14/25 01:00	0.0 FID	0.001 FI	-7.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/14/25 02:00	0.0 FID	0.001 FI	-8.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.1 F	199.9 F
03/14/25 03:00	0.0 FID	0.001 FI	-8.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.1 F	199.9 F
03/14/25 04:00	0.0 FID	0.001 FI	-9.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F

UNIT START UP

UNIT SHUTDOWN

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/14/25 05:00	0.0 FID	0.001 FI	-8.9 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/14/25 06:00	0.0 FIC	0.012 FI	5.2 FI	0.0 F	0.0 F	0.0 FIC	0.1 FIC	0.024 F	6.5 F	14.4 FC	199.9 F
03/14/25 07:00	0.0 FID	0.001 FI	-8.6 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/14/25 08:00	0.0 FID	0.001 FI	-9.8 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
03/14/25 09:00	0.0 FID	0.001 FI	-9.9 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/14/25 10:00	0.0 FID	0.001 FI	-7.5 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.2 FI	21.0 F	199.8 F
03/14/25 11:00	0.0 FID	0.001 FI	-7.3 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
03/14/25 12:00	0.0 FID	0.001 FI	-5.8 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
03/14/25 13:00	0.0 FID	0.001 FI	-5.7 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
03/14/25 14:00	0.0 FID	0.001 FI	-4.2 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
03/14/25 15:00	0.0 FID	0.001 FI	-5.6 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.2 FI	21.0 F	199.8 F
03/14/25 16:00	0.0 FID	0.001 FI	-6.8 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
03/14/25 17:00	0.0 FID	0.001 FI	-7.5 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
03/14/25 18:00	0.0 FID	0.001 FI	-7.3 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/14/25 19:00	0.0 FID	0.001 FI	-7.1 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
03/14/25 20:00	37.1 U	0.068 E	30.4 E	0.0	0.0	0.0	73.2 EU	0.121 E	32.9 E	16.1	199.8
03/14/25 21:00	15.1 U	0.018	8.2	0.0	0.0	0.0	13.1 U	0.016	4.3	15.1	199.8
03/14/25 22:00	17.5	0.022	9.8	0.0	0.0	0.0	12.7	0.016	4.3	15.2	199.8
03/14/25 23:00	17.5	0.023	10.1	0.0	0.0	0.0	12.5	0.016	4.4	15.2	199.9
03/15/25 00:00	18.0	0.023	10.4	0.0	0.0	0.0	12.3	0.016	4.3	15.2	199.9
03/15/25 01:00	19.0	0.024	11.0	0.0	0.0	0.0	12.3	0.016	4.3	15.1	199.9
03/15/25 02:00	17.6	0.023	10.1	0.0	0.0	0.0	12.3	0.016	4.3	15.2	199.9
03/15/25 03:00	17.3	0.023	10.2	0.0	0.0	0.0	12.3	0.016	4.3	15.2	199.9
03/15/25 04:00	22.5	0.029	12.6	0.0	0.0	0.0	12.2	0.016	4.3	15.2	199.9
03/15/25 05:00	18.5 D	0.024	10.6	0.0	0.0	0.0	12.2 D	0.016	4.3	15.2	199.9
03/15/25 06:00	19.6 CD	0.035	15.5	0.0	0.0	0.0 C	12.3 CD	0.016	4.3	15.1 C	199.9
03/15/25 07:00	0.0 FID	0.001 FI	-3.0 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.1 F	199.8 F
03/15/25 08:00	0.0 FID	0.001 FI	-2.8 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.1 F	199.8 F
03/15/25 09:00	0.0 FID	0.001 FI	-3.0 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.1 F	199.8 F
03/15/25 10:00	0.0 FID	0.001 FI	-2.7 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.1 F	199.8 F
03/15/25 11:00	0.0 FID	0.001 FI	-2.9 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.1 F	199.8 F
03/15/25 12:00	0.0 FID	0.001 FI	-2.7 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.1 F	199.8 F
03/15/25 13:00	0.0 FID	0.001 FI	-2.6 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.1 F	199.8 F
03/15/25 14:00	0.0 FID	0.001 FI	-2.7 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.1 F	199.8 F
03/15/25 15:00	0.0 FID	0.001 FI	-2.7 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.1 F	199.8 F
03/15/25 16:00	0.0 FID	0.001 FI	-2.6 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.1 F	199.8 F
03/15/25 17:00	0.0 FID	0.001 FI	-2.7 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.1 F	199.8 F

UNIT START UP

UNIT SHUTDOWN

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/15/25 18:00	0.0 FID	0.001 FI	-2.7 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.1 F	199.8 F
03/15/25 19:00	0.0 FID	0.001 FI	-2.6 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.1 F	199.8 F
03/15/25 20:00	46.2 U	0.080 E	35.5 E	0.0	0.0	0.0	73.8 EU	0.121 E	32.8 E	16.3	199.8
03/15/25 21:00	21.8 U	0.026	11.8	0.0	0.0	0.0	13.1 U	0.016	4.3	15.3	199.8
03/15/25 22:00	18.4	0.023	10.3	0.0	0.0	0.0	12.7	0.016	4.3	15.2	199.8
03/15/25 23:00	19.6	0.025	11.1	0.0	0.0	0.0	12.4	0.016	4.3	15.2	199.8
03/16/25 00:00	19.1	0.025	11.0	0.0	0.0	0.0	12.4	0.016	4.3	15.2	199.8
03/16/25 01:00	17.3	0.022	10.0	0.0	0.0	0.0	12.3	0.016	4.3	15.2	199.8
03/16/25 02:00	17.4	0.023	10.0	0.0	0.0	0.0	12.3	0.016	4.3	15.2	199.9
03/16/25 03:00	17.4	0.023	10.0	0.0	0.0	0.0	12.3	0.016	4.3	15.2	199.9
03/16/25 04:00	21.5	0.027	12.2	0.0	0.0	0.0	12.4	0.016	4.3	15.2	199.9
03/16/25 05:00	19.9 D	0.025	11.0	0.0	0.0	0.0	12.8 D	0.016	4.3	15.3	199.9
03/16/25 06:00	7.9 CD	0.008	3.5	0.0	0.0	0.0 C	15.1 CD	0.016	4.5	15.0 C	199.9
03/16/25 07:00	0.0 FID	0.001 FI	-5.5 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/16/25 08:00	0.0 FID	0.001 FI	-4.8 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.1 F	199.9 F
03/16/25 09:00	0.0 FID	0.001 FI	-5.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/16/25 10:00	0.0 FID	0.001 FI	-5.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/16/25 11:00	0.0 FID	0.001 FI	-5.2 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/16/25 12:00	0.0 FID	0.001 FI	-5.0 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.1 F	199.8 F
03/16/25 13:00	0.0 FID	0.001 FI	-5.2 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
03/16/25 14:00	0.0 FID	0.001 FI	-5.4 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.1 F	199.8 F
03/16/25 15:00	0.0 FID	0.001 FI	-5.1 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
03/16/25 16:00	0.0 FID	0.001 FI	-4.7 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.1 F	199.8 F
03/16/25 17:00	0.0 FID	0.001 FI	-5.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
03/16/25 18:00	0.0 FID	0.001 FI	-4.5 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/16/25 19:00	0.0 FID	0.001 FI	-4.6 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.1 F	199.8 F
03/16/25 20:00	35.9 U	0.085 E	29.2 E	0.0	0.0	0.0	77.9 EU	0.126 E	34.5 E	16.1	199.8
03/16/25 21:00	15.9 U	0.020	8.9	0.0	0.0	0.0	12.9 U	0.016	4.3	15.2	199.8
03/16/25 22:00	20.5	0.026	11.7	0.0	0.0	0.0	12.4	0.016	4.3	15.3	199.9
03/16/25 23:00	18.3	0.022	9.9	0.0	0.0	0.0	13.1	0.016	4.3	15.3	199.9
03/17/25 00:00	17.5	0.023	10.0	0.0	0.0	0.0	12.5	0.016	4.3	15.3	199.8
03/17/25 01:00	17.4	0.023	10.0	0.0	0.0	0.0	12.4	0.016	4.3	15.3	199.9
03/17/25 02:00	20.2	0.026	11.7	0.0	0.0	0.0	12.4	0.016	4.3	15.3	199.9
03/17/25 03:00	18.7	0.024	10.7	0.0	0.0	0.0	12.4	0.016	4.3	15.3	199.9
03/17/25 04:00	18.7	0.022	10.1	0.0	0.0	0.0	13.2	0.016	4.3	15.3	199.9
03/17/25 05:00	19.1 D	0.023	10.3	0.0	0.0	0.0	13.2 D	0.016	4.4	15.4	199.9
03/17/25 06:00	92.8 ECD	0.322 E	141.9 E	0.0	0.0	0.0 C	39.4 ECD	0.119 E	32.0 E	17.2 C	199.8

UNIT START UP

UNIT SHUTDOWN

UNIT START UP

UNIT SHUTDOWN

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/17/25 07:00	0.0 FID	0.001 FI	13.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.5 FI	20.9 F	199.8 F
03/17/25 08:00	0.0 FID	0.013 FI	8.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.8 F
03/17/25 09:00	0.0 FID	0.013 FI	6.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.1 FI	20.8 F	199.8 F
03/17/25 10:00	0.0 FID	0.013 FI	7.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.2 FI	20.8 F	199.8 F
03/17/25 11:00	0.0 FID	0.013 FI	6.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.8 F
03/17/25 12:00	0.0 FID	0.013 FI	7.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.8 F
03/17/25 13:00	0.0 FID	0.013 FI	8.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.8 F
03/17/25 14:00	0.0 FID	0.013 FI	7.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
03/17/25 15:00	0.0 FID	0.013 FI	6.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.8 F
03/17/25 16:00	0.0 FID	0.013 FI	7.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.1 FI	20.8 F	199.8 F
03/17/25 17:00	0.0 FID	0.013 FI	7.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.8 F
03/17/25 18:00	0.0 FID	0.013 FI	6.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
03/17/25 19:00	0.0 FID	0.013 FI	6.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.8 F
03/17/25 20:00	38.5 U	0.069 E	30.6 E	0.0	0.0	0.0	70.8 EU	0.112 E	30.3 E	15.9	199.9
03/17/25 21:00	19.4 U	0.023	10.5	0.0	0.0	0.0	12.9 U	0.015	4.2	15.0	199.9
03/17/25 22:00	18.5 D	0.024	10.6	0.0	0.0	0.0	12.5 D	0.016	4.3	15.0	199.9
03/17/25 23:00	68.0 ED	0.305 E	137.4 E	0.0	0.0	0.0	44.2 ED	0.128 E	35.2 E	16.9	199.8
03/18/25 00:00	0.0 FID	0.013 FI	8.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.8 F
03/18/25 01:00	0.0 FID	0.013 FI	8.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.8 F
03/18/25 02:00	0.0 FID	0.013 FI	7.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.8 F	199.9 F
03/18/25 03:00	0.0 FID	0.013 FI	6.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
03/18/25 04:00	0.0 FID	0.013 FI	6.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.9 F
03/18/25 05:00	0.0 FID	0.013 FI	8.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.8 F
03/18/25 06:00	0.0 FIC	0.011 FI	4.8 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.1 FC	199.8 F
03/18/25 07:00	0.0 FID	0.026 FI	12.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.0 FI	20.8 F	199.8 F
03/18/25 08:00	0.0 FID	0.026 FI	10.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.0 FI	20.8 F	199.8 F
03/18/25 09:00	0.0 FID	0.026 FI	13.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.8 F	199.8 F
03/18/25 10:00	0.0 FID	0.026 FI	12.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.8 F	199.8 F
03/18/25 11:00	0.0 FID	0.026 FI	12.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.1 FI	20.8 F	199.8 F
03/18/25 12:00	0.0 FID	0.026 FI	12.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.0 FI	20.8 F	199.8 F
03/18/25 13:00	0.0 FID	0.026 FI	12.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.8 F	199.8 F
03/18/25 14:00	0.0 FID	0.026 FI	11.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.8 F	199.8 F
03/18/25 15:00	0.0 FID	0.026 FI	12.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.8 F	199.8 F
03/18/25 16:00	0.0 FID	0.026 FI	11.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.8 F	199.9 F
03/18/25 17:00	0.0 FID	0.026 FI	11.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.8 F	199.9 F
03/18/25 18:00	0.0 FID	0.026 FI	12.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.8 F	199.9 F
03/18/25 19:00	0.0 FID	0.026 FI	11.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.8 F	199.9 F

UNIT START UP

UNIT SHUTDOWN

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/18/25 20:00	39.6 U	0.068 E	30.3 E	0.0	0.0	0.0	71.2 EU	0.109 E	29.3 E	15.9	199.9
03/18/25 21:00	18.9 U	0.024	10.5	0.0	0.0	0.0	12.5 U	0.016	4.3	15.0	199.9
03/18/25 22:00	19.3 D	0.025	11.0	0.0	0.0	0.0	12.5 D	0.016	4.3	15.0	199.9
03/18/25 23:00	100.3 ED	0.272 E	120.8 E	0.0	0.0	0.0	36.0 ED	0.087 E	23.6 E	16.7	199.9
03/19/25 00:00	0.0 FID	0.026 FI	14.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.8 F	199.9 F
03/19/25 01:00	0.0 FID	0.026 FI	12.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.8 F	199.9 F
03/19/25 02:00	0.0 FID	0.013 FI	6.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.7 F	199.9 F
03/19/25 03:00	0.0 FID	0.026 FI	12.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.1 FI	20.8 F	199.9 F
03/19/25 04:00	0.0 FID	0.026 FI	16.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.8 F	199.9 F
03/19/25 05:00	0.0 FID	0.026 FI	14.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.8 F	199.9 F
03/19/25 06:00	0.0 FIC	0.011 FI	4.9 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.2 FC	199.9 F
03/19/25 07:00	0.0 FID	0.001 FI	25.9 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.1 FI	20.9 F	199.8 F
03/19/25 08:00	0.0 FID	0.001 FI	17.6 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
03/19/25 09:00	0.0 FID	0.001 FI	22.6 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.1 FI	20.9 F	199.8 F
03/19/25 10:00	0.0 FID	0.001 FI	19.6 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
03/19/25 11:00	0.0 FID	0.013 FI	16.8 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
03/19/25 12:00	0.0 FID	0.001 FI	25.6 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.1 FI	20.9 F	199.8 F
03/19/25 13:00	0.0 FID	0.001 FI	27.3 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.1 FI	20.9 F	199.8 F
03/19/25 14:00	0.0 FID	0.001 FI	24.2 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.1 FI	20.9 F	199.8 F
03/19/25 15:00	0.0 FID	0.001 FI	22.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.1 FI	20.9 F	199.8 F
03/19/25 16:00	0.0 FID	0.001 FI	23.1 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
03/19/25 17:00	0.0 FID	0.001 FI	28.5 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.1 FI	20.9 F	199.8 F
03/19/25 18:00	0.0 FID	0.001 FI	26.6 FIE	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
03/19/25 19:00	0.0 FID	0.001 FI	20.3 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
03/19/25 20:00	39.1 U	0.079 E	34.8 E	0.0	0.0	0.0	73.8 EU	0.116 E	31.4 E	16.1	199.9
03/19/25 21:00	12.7 U	0.015	6.7	0.0	0.0	0.0	13.3 U	0.016	4.2	15.1	199.9
03/19/25 22:00	11.7	0.014	6.1	0.0	0.0	0.0	13.6	0.016	4.3	15.1	199.9
03/19/25 23:00	15.2	0.019	8.5	0.0	0.0	0.0	12.9	0.016	4.4	15.1	199.9
03/20/25 00:00	17.0	0.022	9.7	0.0	0.0	0.0	12.3	0.016	4.3	15.1	199.9
03/20/25 01:00	16.9	0.022	9.7	0.0	0.0	0.0	12.3	0.016	4.3	15.1	199.9
03/20/25 02:00	17.6	0.022	10.0	0.0	0.0	0.0	12.4	0.016	4.3	15.1	199.9
03/20/25 03:00	20.0	0.025	11.2	0.0	0.0	0.0	12.6	0.016	4.3	15.1	199.9
03/20/25 04:00	16.8	0.021	9.6	0.0	0.0	0.0	12.6	0.016	4.4	15.1	199.9
03/20/25 05:00	17.5 D	0.023	10.0	0.0	0.0	0.0	12.3 D	0.016	4.3	15.1	199.9
03/20/25 06:00	22.1 CD	0.024	10.9	0.0	0.0	0.0 C	12.6 CD	0.016	4.3	15.1 C	199.9
03/20/25 07:00	0.0 FID	0.001 FI	-62.0 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	-0.3 FI	20.9 F	199.9 F
03/20/25 08:00	0.0 FID	0.001 FI	-27.6 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.2 FI	20.9 F	199.8 F

UNIT START UP

UNIT SHUTDOWN

UNIT START UP

UNIT SHUTDOWN

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/20/25 09:00	0.0 FID	0.001 FI	-26.7 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	-0.1 FI	20.9 F	199.8 F
03/20/25 10:00	0.0 FID	0.001 FI	-21.7 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
03/20/25 11:00	0.0 FID	0.001 FI	-22.9 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
03/20/25 12:00	0.0 FID	0.001 FI	-79.0 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	-0.2 FI	20.9 F	199.8 F
03/20/25 13:00	0.0 FID	0.001 FI	-13.3 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
03/20/25 14:00	0.0 FID	0.001 FI	-21.3 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	-0.1 FI	20.9 F	199.8 F
03/20/25 15:00	0.0 FID	0.001 FI	-27.2 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	20.9 F	199.8 F
03/20/25 16:00	0.0 FID	0.001 FI	-18.9 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
03/20/25 17:00	0.0 FID	0.001 FI	-19.3 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.2 FI	20.9 F	199.8 F
03/20/25 18:00	0.0 FID	0.001 FI	-43.6 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	-0.2 FI	20.9 F	199.8 F
03/20/25 19:00	0.0 FID	0.001 FI	-50.9 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
03/20/25 20:00	42.4 U	0.086 E	38.2 E	0.0	0.0	0.0	61.7 EU	0.096 E	28.0 E	16.1	199.8
03/20/25 21:00	19.2 U	0.024	10.9	0.0	0.0	0.0	12.4 U	0.016	4.3	15.1	199.8
03/20/25 22:00	19.8	0.025	11.3	0.0	0.0	0.0	12.3	0.016	4.3	15.1	199.8
03/20/25 23:00	18.2	0.023	10.3	0.0	0.0	0.0	12.5	0.016	4.3	15.1	199.8
03/21/25 00:00	19.5	0.025	11.2	0.0	0.0	0.0	12.2	0.016	4.3	15.1	199.8
03/21/25 01:00	17.1	0.022	9.8	0.0	0.0	0.0	12.3	0.016	4.3	15.1	199.8
03/21/25 02:00	17.0	0.022	9.7	0.0	0.0	0.0	12.3	0.016	4.3	15.1	199.8
03/21/25 03:00	16.8	0.022	9.7	0.0	0.0	0.0	12.2	0.016	4.3	15.1	199.9
03/21/25 04:00	20.9	0.026	11.6	0.0	0.0	0.0	12.5	0.016	4.3	15.1	199.9
03/21/25 05:00	14.7 MD	0.020	8.7	0.0	0.0	0.0 M	12.6 MD	0.016	4.4	15.1 M	199.9
03/21/25 06:00	86.4 ECD	0.277 E	122.6 E	0.0	0.0	0.0 C	38.9 ECD	0.113 E	30.4 E	16.9 C	199.9
03/21/25 07:00	0.0 FID	0.001 FI	-3.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.1 F	199.8 F
03/21/25 08:00	0.0 FID	0.001 FI	-3.4 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.1 F	199.8 F
03/21/25 09:00	0.0 FID	0.001 FI	-3.2 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.1 F	199.8 F
03/21/25 10:00	0.0 FID	0.001 FI	-2.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.1 F	199.8 F
03/21/25 11:00	0.0 FID	0.001 FI	-2.9 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.1 F	199.8 F
03/21/25 12:00	0.0 FID	0.001 FI	-2.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.1 F	199.8 F
03/21/25 13:00	0.0 FID	0.001 FI	-2.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.1 F	199.8 F
03/21/25 14:00	0.0 FID	0.001 FI	-2.9 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.1 F	199.8 F
03/21/25 15:00	0.0 FID	0.001 FI	-2.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.1 F	199.8 F
03/21/25 16:00	0.0 FID	0.001 FI	-2.6 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.1 F	199.8 F
03/21/25 17:00	0.0 FID	0.001 FI	-2.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.1 F	199.9 F
03/21/25 18:00	0.0 FID	0.001 FI	-2.5 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.1 F	199.9 F
03/21/25 19:00	0.0 FID	0.001 FI	-2.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.1 F	199.9 F
03/21/25 20:00	39.8 U	0.077 E	34.6 E	0.0	0.0	0.0	66.9 EU	0.104 E	28.2 E	16.2	199.9
03/21/25 21:00	23.1 U	0.029	12.8	0.0	0.0	0.0	12.6 U	0.016	4.3	15.3	199.9

UNIT START UP

UNIT SHUTDOWN

UNIT START UP

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/21/25 22:00	18.6	0.024	10.6	0.0	0.0	0.0	12.5	0.016	4.3	15.2	199.9
03/21/25 23:00	19.8	0.025	11.3	0.0	0.0	0.0	12.4	0.016	4.3	15.2	199.9
03/22/25 00:00	17.4	0.022	10.0	0.0	0.0	0.0	12.3	0.016	4.3	15.2	199.9
03/22/25 01:00	17.5	0.023	10.0	0.0	0.0	0.0	12.4	0.016	4.3	15.2	199.9
03/22/25 02:00	17.5	0.023	10.0	0.0	0.0	0.0	12.4	0.016	4.3	15.2	199.8
03/22/25 03:00	12.4	0.014	6.5	0.0	0.0	0.0	13.6	0.016	4.3	15.1	199.8
03/22/25 04:00	14.0	0.017	7.4	0.0	0.0	0.0	20.9 E	0.025 E	6.7 E	15.1	199.8
03/22/25 05:00	16.6 D	0.020	9.0	0.0	0.0	0.0	13.3 D	0.016	4.3	15.2	199.8
03/22/25 06:00	89.1 ECD	0.275 E	124.0 E	0.0	0.0	0.0 C	37.9 ECD	0.102 E	28.0 E	17.0 C	199.8
03/22/25 07:00	0.0 FID	0.001 FI	-4.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.1 F	199.8 F
03/22/25 08:00	0.0 FID	0.001 FI	-3.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.8 F
03/22/25 09:00	0.0 FID	0.001 FI	-3.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.1 F	199.8 F
03/22/25 10:00	0.0 FID	0.001 FI	-2.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.1 F	199.8 F
03/22/25 11:00	0.0 FID	0.001 FI	-3.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.1 F	199.8 F
03/22/25 12:00	0.0 FID	0.001 FI	-3.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.1 F	199.8 F
03/22/25 13:00	0.0 FID	0.001 FI	-3.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.8 F
03/22/25 14:00	0.0 FID	0.001 FI	-2.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.1 F	199.8 F
03/22/25 15:00	0.0 FID	0.001 FI	-2.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.1 F	199.8 F
03/22/25 16:00	0.0 FID	0.001 FI	-2.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.1 F	199.8 F
03/22/25 17:00	0.0 FID	0.001 FI	-1.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.1 F	199.8 F
03/22/25 18:00	0.0 FID	0.001 FI	-1.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	21.1 F	199.8 F
03/22/25 19:00	0.0 FID	0.001 FI	-2.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.1 F	199.8 F
03/22/25 20:00	39.3 U	0.071 E	31.5 E	0.0	0.0	0.0	66.8 EU	0.107 E	29.1 E	16.1	199.8
03/22/25 21:00	17.6 U	0.023	10.0	0.0	0.0	0.0	12.4 U	0.016	4.3	15.2	199.8
03/22/25 22:00	20.8	0.027	11.9	0.0	0.0	0.0	12.4	0.016	4.3	15.2	199.8
03/22/25 23:00	17.7	0.022	9.9	0.0	0.0	0.0	12.7	0.016	4.3	15.2	199.8
03/23/25 00:00	17.3	0.022	9.6	0.0	0.0	0.0	12.7	0.016	4.3	15.2	199.8
03/23/25 01:00	10.2	0.012	5.4	0.0	0.0	0.0	13.9	0.016	4.4	15.1	199.8
03/23/25 02:00	9.9	0.012	5.4	0.0	0.0	0.0	14.1	0.016	4.4	15.0	199.8
03/23/25 03:00	19.7	0.024	10.7	0.0	0.0	0.0	13.0	0.016	4.3	15.3	199.8
03/23/25 04:00	17.8	0.022	10.0	0.0	0.0	0.0	12.8	0.016	4.3	15.2	199.8
03/23/25 05:00	21.1 D	0.026	11.4	0.0	0.0	0.0	13.0 D	0.016	4.3	15.3	199.8
03/23/25 06:00	81.3 ECD	0.248 E	110.5 E	0.0	0.0	0.0 C	36.1 ECD	0.096 E	26.1 E	16.8 C	199.8
03/23/25 07:00	0.0 FID	0.001 FI	-12.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.4 FI	21.0 F	199.8 F
03/23/25 08:00	0.0 FID	0.001 FI	-10.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.6 FI	20.9 F	199.8 F
03/23/25 09:00	0.0 FID	0.001 FI	-9.3 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.2 FI	20.9 F	199.8 F
03/23/25 10:00	0.0 FID	0.001 FI	-11.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.4 FI	20.9 F	199.8 F

Primary Reignition

UNIT SHUTDOWN

UNIT START UP

UNIT SHUTDOWN

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/23/25 11:00	0.0 FID	0.001 FI	-7.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
03/23/25 12:00	0.0 FID	0.001 FI	-8.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.3 FI	20.9 F	199.8 F
03/23/25 13:00	0.0 FID	0.001 FI	-8.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.3 FI	20.9 F	199.8 F
03/23/25 14:00	0.0 FID	0.001 FI	-6.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.3 FI	21.0 F	199.8 F
03/23/25 15:00	0.0 FID	0.001 FI	-5.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.4 FI	21.0 F	199.8 F
03/23/25 16:00	0.0 FID	0.001 FI	-6.5 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.3 FI	21.0 F	199.8 F
03/23/25 17:00	0.0 FID	0.001 FI	-7.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.5 FI	21.0 F	199.8 F
03/23/25 18:00	0.0 FID	0.001 FI	-5.8 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
03/23/25 19:00	0.0 FID	0.001 FI	-5.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.4 FI	21.0 F	199.8 F
03/23/25 20:00	38.3 U	0.066 E	29.8 E	0.0	0.0	0.0	62.0 EU	0.095 E	26.1 E	15.9	199.8
03/23/25 21:00	6.7 U	0.008	3.5	0.0	0.0	0.0	13.6 U	0.016	4.3	14.8	199.8
03/23/25 22:00	19.6	0.024	10.7	0.0	0.0	0.0	12.5	0.016	4.2	15.3	199.8
03/23/25 23:00	18.0	0.023	10.3	0.0	0.0	0.0	12.4	0.018	4.3	15.2	199.8
03/24/25 00:00	17.9	0.023	10.3	0.0	0.0	0.0	12.3	0.016	4.3	15.2	199.8
03/24/25 01:00	17.4	0.022	10.0	0.0	0.0	0.0	12.3	0.016	4.3	15.1	199.8
03/24/25 02:00	18.2	0.024	10.5	0.0	0.0	0.0	12.2	0.016	4.3	15.2	199.8
03/24/25 03:00	17.7	0.023	10.2	0.0	0.0	0.0	12.3	0.016	4.3	15.2	199.8
03/24/25 04:00	18.2	0.022	9.8	0.0	0.0	0.0	12.9	0.016	4.2	15.2	199.8
03/24/25 05:00	16.9 D	0.020	9.2	0.0	0.0	0.0	13.1 D	0.016	4.3	15.2	199.8
03/24/25 06:00	80.9 ECD	0.274 E	121.6 E	0.0	0.0	0.0 C	33.7 ECD	0.097 E	26.2 E	16.9 C	199.8
03/24/25 07:00	0.0 FID	0.001 FI	-16.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.5 FI	20.9 F	199.8 F
03/24/25 08:00	0.0 FID	0.001 FI	-24.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.6 FI	20.9 F	199.8 F
03/24/25 09:00	0.0 FID	0.001 FI	-16.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.6 FI	20.9 F	199.8 F
03/24/25 10:00	0.0 FID	0.001 FI	-15.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.8 FI	20.9 F	199.8 F
03/24/25 11:00	0.0 FID	0.001 FI	-18.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.5 FI	20.9 F	199.8 F
03/24/25 12:00	0.0 FID	0.001 FI	-17.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.2 FI	20.9 F	199.8 F
03/24/25 13:00	0.0 FID	0.001 FI	-13.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.9 FI	20.9 F	199.8 F
03/24/25 14:00	0.0 FID	0.001 FI	-19.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.0 FI	20.9 F	199.8 F
03/24/25 15:00	0.0 FID	0.001 FI	-13.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.0 FI	20.9 F	199.8 F
03/24/25 16:00	0.0 FID	0.001 FI	-16.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.9 FI	20.9 F	199.8 F
03/24/25 17:00	0.0 FID	0.001 FI	-15.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.7 FI	20.9 F	199.8 F
03/24/25 18:00	0.0 FID	0.001 FI	-20.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.7 FI	20.9 F	199.8 F
03/24/25 19:00	0.0 FID	0.001 FI	-15.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.6 FI	20.9 F	199.8 F
03/24/25 20:00	33.4 U	0.061 E	27.4 E	0.0	0.0	0.0	70.6 EU	0.112 E	30.7 E	15.9	199.8
03/24/25 21:00	3.9 U	0.004	1.9	0.0	0.0	0.0	14.2 U	0.016	4.4	14.8	199.8
03/24/25 22:00	12.0 D	0.015	6.5	0.0	0.0	0.0	13.0 D	0.016	4.3	15.2	199.8
03/24/25 23:00	75.5 ED	0.251 E	111.2 E	0.0	0.0	0.0	33.1 ED	0.093 E	25.2 E	16.8	199.8

UNIT START UP

UNIT SHUTDOWN

UNIT START UP

UNIT SHUTDOWN

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/25/25 00:00	0.0 FID	0.001 FI	-37.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.4 FI	20.9 F	199.8 F
03/25/25 01:00	0.0 FID	0.001 FI	-22.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.5 FI	20.9 F	199.8 F
03/25/25 02:00	0.0 FID	0.001 FI	-27.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.9 FI	20.9 F	199.8 F
03/25/25 03:00	0.0 FID	0.001 FI	-14.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.3 FI	20.9 F	199.8 F
03/25/25 04:00	0.0 FID	0.001 FI	-20.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.8 FI	20.9 F	199.8 F
03/25/25 05:00	0.0 FID	0.001 FI	-25.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.3 FI	20.9 F	199.8 F
03/25/25 06:00	0.0 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.024 F	6.4 F	14.3 FC	199.8 F
03/25/25 07:00	0.0 FID	0.001 FI	-7.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.1 F	199.8 F
03/25/25 08:00	0.2 FIM	0.001 FI	-120.2 FI	0.0 F	0.0 F	0.0 FIM	0.3 FIM	0.001 FI	-0.9 FI	21.2 FM	199.8 F
03/25/25 09:00	0.0 FIM	0.001 FI	-131.9 FI	0.0 F	0.0 F	0.0 FIM	0.0 FIM	0.001 FI	-0.5 FI	21.1 FM	199.9 F
03/25/25 10:00	0.0 FIM	0.001 FI	-106.5 FI	0.0 F	0.0 F	0.0 FIM	0.0 FIM	0.001 FI	-1.0 FI	21.0 FM	199.9 F
03/25/25 11:00	0.0 FIM	0.010 FI	4.3 FI	0.0 F	0.0 F	0.0 FIM	0.0 FIM	0.018 F	5.0 F	6.8 FMC	199.9 F
03/25/25 12:00	0.0 FIC	0.035 FI	15.8 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.080 F	16.4 F	18.5 FC	199.8 F
03/25/25 13:00	0.0 FID	0.001 FI	-40.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.1 F	199.8 F
03/25/25 14:00	0.0 FID	0.001 FI	-39.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.1 F	199.8 F
03/25/25 15:00	0.0 FID	0.001 FI	-31.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.1 F	199.8 F
03/25/25 16:00	0.0 FID	0.001 FI	-29.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.1 F	199.8 F
03/25/25 17:00	0.0 FID	0.001 FI	-27.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.1 F	199.8 F
03/25/25 18:00	0.0 FID	0.001 FI	-23.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.1 F	199.8 F
03/25/25 19:00	0.0 FID	0.001 FI	-22.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.0 FI	21.1 F	199.8 F
03/25/25 20:00	34.4 U	0.060 E	26.9 E	0.0	0.0	0.0	71.9 EU	0.117 E	32.0 E	16.0	199.8
03/25/25 21:00	14.0 U	0.018	7.9	0.0	0.0	0.0	12.1 U	0.015	4.1	15.2	199.8
03/25/25 22:00	18.0	0.024	10.4	0.0	0.0	0.0	11.8	0.015	4.2	15.4	199.8
03/25/25 23:00	12.9	0.016	7.1	0.0	0.0	0.0	12.8	0.016	4.3	15.2	199.8
03/26/25 00:00	17.1	0.022	9.9	0.0	0.0	0.0	12.3	0.016	4.3	15.3	199.8
03/26/25 01:00	17.6	0.023	10.2	0.0	0.0	0.0	12.2	0.016	4.2	15.4	199.8
03/26/25 02:00	17.7	0.023	10.2	0.0	0.0	0.0	12.1	0.016	4.2	15.4	199.8
03/26/25 03:00	18.3	0.024	10.6	0.0	0.0	0.0	12.3	0.016	4.3	15.4	199.8
03/26/25 04:00	18.5	0.024	10.7	0.0	0.0	0.0	12.3	0.016	4.3	15.4	199.8
03/26/25 05:00	12.5 D	0.015	6.8	0.0	0.0	0.0	13.0 D	0.016	4.3	15.3	199.8
03/26/25 06:00	78.1 ECD	0.258 E	116.0 E	0.0	0.0	0.0 C	33.0 ECD	0.093 E	25.6 E	16.9 C	199.8
03/26/25 07:00	0.0 FID	0.001 FI	-37.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.8 F
03/26/25 08:00	0.0 FID	0.001 FI	-33.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.8 F
03/26/25 09:00	0.0 FID	0.001 FI	-37.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	21.0 F	199.8 F
03/26/25 10:00	0.0 FID	0.001 FI	-38.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	21.0 F	199.8 F
03/26/25 11:00	0.0 FID	0.001 FI	-34.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	21.0 F	199.8 F
03/26/25 12:00	0.0 FID	0.001 FI	-32.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.0 FI	21.0 F	199.8 F

UNIT START UP

UNIT SHUTDOWN

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/26/25 13:00	0.0 FID	0.001 FI	-36.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	21.0 F	199.8 F
03/26/25 14:00	0.0 FID	0.001 FI	-30.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	21.0 F	199.8 F
03/26/25 15:00	0.0 FID	0.001 FI	-28.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.8 F
03/26/25 16:00	0.0 FID	0.001 FI	-28.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.8 F
03/26/25 17:00	0.0 FID	0.001 FI	-26.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.8 F
03/26/25 18:00	0.0 FID	0.001 FI	-25.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	21.0 F	199.8 F
03/26/25 19:00	0.0 FID	0.001 FI	-25.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	21.0 F	199.8 F
03/26/25 20:00	41.6 U	0.074 E	33.3 E	0.0	0.0	0.0	71.3 EU	0.117 E	32.0 E	16.1	199.8
03/26/25 21:00	16.9 U	0.021	9.6	0.0	0.0	0.0	12.7 U	0.016	4.3	15.2	199.8
03/26/25 22:00	18.4	0.023	10.5	0.0	0.0	0.0	12.4	0.016	4.3	15.2	199.8
03/26/25 23:00	15.5	0.020	8.8	0.0	0.0	0.0	12.6	0.016	4.3	15.2	199.8
03/27/25 00:00	18.3	0.023	10.4	0.0	0.0	0.0	12.3	0.016	4.3	15.2	199.8
03/27/25 01:00	17.5	0.023	10.1	0.0	0.0	0.0	12.3	0.016	4.3	15.2	199.8
03/27/25 02:00	17.8	0.023	10.2	0.0	0.0	0.0	12.3	0.016	4.3	15.2	199.8
03/27/25 03:00	17.9	0.023	10.2	0.0	0.0	0.0	12.4	0.016	4.3	15.2	199.8
03/27/25 04:00	17.5	0.023	10.1	0.0	0.0	0.0	12.4	0.016	4.3	15.2	199.8
03/27/25 05:00	19.4 D	0.025	11.2	0.0	0.0	0.0	12.3 D	0.016	4.3	15.2	199.8
03/27/25 06:00	90.5 ECD	0.266 E	117.3 E	0.0	0.0	0.0 C	34.3 ECD	0.094 E	25.2 E	16.8 C	199.8
03/27/25 07:00	0.0 FID	0.053 FI	35.5 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
03/27/25 08:00	0.0 FID	0.053 FI	36.7 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.1 FI	20.8 F	199.8 F
03/27/25 09:00	0.0 FID	0.053 FI	33.6 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
03/27/25 10:00	0.0 FID	0.053 FI	32.0 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.1 FI	20.8 F	199.8 F
03/27/25 11:00	0.0 FID	0.053 FI	34.9 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
03/27/25 12:00	0.0 FID	0.053 FI	34.4 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.2 FI	20.8 F	199.8 F
03/27/25 13:00	0.0 FID	0.040 FI	34.0 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
03/27/25 14:00	0.0 FID	0.053 FI	34.6 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
03/27/25 15:00	0.0 FID	0.001 FI	39.8 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.9 F	199.8 F
03/27/25 16:00	0.0 FID	0.040 FI	30.8 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
03/27/25 17:00	0.0 FID	0.001 FI	48.2 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.1 FI	20.9 F	199.8 F
03/27/25 18:00	0.0 FID	0.001 FI	48.9 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.1 FI	20.9 F	199.8 F
03/27/25 19:00	0.0 FID	0.040 FI	29.5 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.1 FI	20.8 F	199.8 F
03/27/25 20:00	40.5 U	0.076 E	33.6 E	0.0	0.0	0.0	70.8 EU	0.117 E	31.4 E	16.0	199.8
03/27/25 21:00	16.7 U	0.021	9.4	0.0	0.0	0.0	12.5 U	0.016	4.3	15.1	199.8
03/27/25 22:00	13.2	0.016	7.0	0.0	0.0	0.0	13.0	0.015	4.2	15.0	199.8
03/27/25 23:00	16.8	0.021	9.5	0.0	0.0	0.0	12.5	0.016	4.4	15.1	199.8
03/28/25 00:00	17.2	0.022	9.9	0.0	0.0	0.0	12.2	0.016	4.3	15.1	199.8
03/28/25 01:00	17.5	0.023	10.1	0.0	0.0	0.0	12.3	0.016	4.3	15.1	199.8

UNIT START UP

UNIT SHUTDOWN

UNIT START UP

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/28/25 02:00	17.3	0.023	10.0	0.0	0.0	0.0	12.2	0.016	4.3	15.1	199.8
03/28/25 03:00	17.1	0.022	9.9	0.0	0.0	0.0	12.2	0.016	4.3	15.1	199.8
03/28/25 04:00	20.8	0.027	11.9	0.0	0.0	0.0	12.3	0.016	4.3	15.1	199.8
03/28/25 05:00	19.1 D	0.025	10.9	0.0	0.0	0.0	12.4 D	0.016	4.3	15.1	199.8
03/28/25 06:00	82.8 ECD	0.270 E	119.1 E	0.0	0.0	0.0 C	33.8 ECD	0.095 E	25.5 E	16.8 C	199.8
03/28/25 07:00	0.0 FID	0.001 FI	-11.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	21.1 F	199.8 F
03/28/25 08:00	0.0 FID	0.001 FI	-12.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	21.1 F	199.8 F
03/28/25 09:00	0.0 FID	0.001 FI	-12.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	21.1 F	199.8 F
03/28/25 10:00	0.0 FID	0.001 FI	-11.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	21.1 F	199.8 F
03/28/25 11:00	0.0 FID	0.001 FI	-11.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	21.1 F	199.8 F
03/28/25 12:00	0.0 FID	0.001 FI	-12.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	21.1 F	199.8 F
03/28/25 13:00	0.0 FID	0.001 FI	-11.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.0 FI	21.1 F	199.8 F
03/28/25 14:00	0.0 FID	0.001 FI	-11.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.1 F	199.8 F
03/28/25 15:00	0.0 FID	0.001 FI	-11.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.1 F	199.8 F
03/28/25 16:00	0.0 FID	0.001 FI	-11.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.1 F	199.8 F
03/28/25 17:00	0.0 FID	0.001 FI	-11.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	21.1 F	199.8 F
03/28/25 18:00	0.0 FID	0.001 FI	-11.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.0 FI	21.1 F	199.8 F
03/28/25 19:00	0.0 FID	0.001 FI	-11.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.1 F	199.8 F
03/28/25 20:00	41.6 U	0.074 E	33.1 E	0.0	0.0	0.0	72.6 EU	0.118 E	32.0 E	16.2	199.8
03/28/25 21:00	16.4 U	0.020	8.9	0.0	0.0	0.0	13.3 U	0.016	4.3	15.3	199.8
03/28/25 22:00	18.8	0.024	10.7	0.0	0.0	0.0	12.7	0.016	4.4	15.2	199.8
03/28/25 23:00	18.5 D	0.024	10.7	0.0	0.0	0.0	12.2 D	0.016	4.3	15.1	199.8
03/29/25 00:00	44.7 D	0.122 E	54.4 E	0.0	0.0	0.0	20.6 ED	0.046 E	12.6 E	16.0	199.8
03/29/25 01:00	54.6 U	0.105 E	46.7 E	0.0	0.0	0.0	118.7 EU	0.205 E	55.5 E	16.5	199.8
03/29/25 02:00	15.2 U	0.019	8.5	0.0	0.0	0.0	13.0 U	0.016	4.4	15.1	199.9
03/29/25 03:00	20.0	0.026	11.6	0.0	0.0	0.0	12.1	0.016	4.3	15.1	199.9
03/29/25 04:00	18.9	0.025	11.3	0.0	0.0	0.0	12.1	0.016	4.3	15.1	199.9
03/29/25 05:00	20.0 D	0.026	11.5	0.0	0.0	0.0	12.3 D	0.016	4.3	15.1	199.9
03/29/25 06:00	99.3 ECD	0.327 E	144.6 E	0.0	0.0	0.0 C	35.7 ECD	0.105 E	28.1 E	17.2 C	199.9
03/29/25 07:00	0.0 FID	0.001 FI	-12.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.1 F	199.8 F
03/29/25 08:00	0.0 FID	0.001 FI	-13.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.5 FI	21.1 F	199.8 F
03/29/25 09:00	0.0 FID	0.001 FI	-11.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.1 F	199.9 F
03/29/25 10:00	0.0 FID	0.001 FI	-12.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.1 F	199.9 F
03/29/25 11:00	0.0 FID	0.001 FI	-13.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.1 F	199.9 F
03/29/25 12:00	0.0 FID	0.001 FI	-11.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.1 F	199.9 F
03/29/25 13:00	0.0 FID	0.001 FI	-12.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.1 F	199.9 F
03/29/25 14:00	0.0 FID	0.001 FI	-13.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.1 F	199.9 F

UNIT SHUTDOWN

UNIT START UP

UNIT SHUTDOWN

UNIT START UP

UNIT SHUTDOWN

Source Parameter Unit	UNIT_B										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/29/25 15:00	0.0 FID	0.001 FI	-12.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.4 FI	21.1 F	199.9 F
03/29/25 16:00	0.0 FID	0.001 FI	-11.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.1 F	199.9 F
03/29/25 17:00	0.0 FID	0.001 FI	-11.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.1 F	199.9 F
03/29/25 18:00	0.0 FID	0.001 FI	-11.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.1 F	199.9 F
03/29/25 19:00	0.0 FID	0.001 FI	-12.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.1 F	199.8 F
03/29/25 20:00	42.0 U	0.079 E	35.1 E	0.0	0.0	0.0	74.3 EU	0.118 E	31.9 E	16.2	199.8
03/29/25 21:00	17.2 U	0.022	9.8	0.0	0.0	0.0	12.3 U	0.016	4.2	15.2	199.8
03/29/25 22:00	19.0	0.024	10.8	0.0	0.0	0.0	12.5	0.016	4.3	15.2	199.8
03/29/25 23:00	20.0	0.025	11.0	0.0	0.0	0.0	12.8	0.016	4.3	15.2	199.8
03/30/25 00:00	17.3	0.022	9.9	0.0	0.0	0.0	12.6	0.016	4.4	15.2	199.8
03/30/25 01:00	20.1	0.026	11.6	0.0	0.0	0.0	12.3	0.016	4.3	15.2	199.9
03/30/25 02:00	18.7	0.024	10.8	0.0	0.0	0.0	12.3	0.016	4.3	15.2	199.9
03/30/25 03:00	18.7	0.024	10.7	0.0	0.0	0.0	12.4	0.016	4.3	15.2	199.8
03/30/25 04:00	17.6	0.023	10.0	0.0	0.0	0.0	12.4	0.016	4.3	15.2	199.8
03/30/25 05:00	18.9 D	0.024	10.7	0.0	0.0	0.0	12.5 D	0.016	4.3	15.2	199.8
03/30/25 06:00	104.9 ECD	0.322 E	141.8 E	0.0	0.0	0.0 C	34.8 ECD	0.100 E	26.6 E	17.2 C	199.8
03/30/25 07:00	0.0 FID	0.001 FI	-52.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.4 FI	20.9 F	199.8 F
03/30/25 08:00	0.0 FID	0.001 FI	-65.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.8 FI	20.9 F	199.8 F
03/30/25 09:00	0.0 FID	0.001 FI	-77.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.6 FI	20.9 F	199.8 F
03/30/25 10:00	0.0 FID	0.001 FI	-88.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.4 FI	20.9 F	199.8 F
03/30/25 11:00	0.0 FID	0.001 FI	-81.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.7 FI	20.9 F	199.8 F
03/30/25 12:00	0.0 FID	0.001 FI	-87.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.9 FI	20.9 F	199.8 F
03/30/25 13:00	0.0 FID	0.001 FI	-55.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.3 FI	20.9 F	199.8 F
03/30/25 14:00	0.0 FID	0.001 FI	-74.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.0 FI	20.9 F	199.8 F
03/30/25 15:00	0.0 FID	0.001 FI	-63.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.8 FI	20.9 F	199.8 F
03/30/25 16:00	0.0 FID	0.001 FI	-63.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.2 FI	20.9 F	199.8 F
03/30/25 17:00	0.0 FID	0.001 FI	-52.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.9 FI	20.9 F	199.8 F
03/30/25 18:00	0.0 FID	0.001 FI	-80.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.1 FI	20.9 F	199.8 F
03/30/25 19:00	0.0 FID	0.001 FI	-52.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.4 FI	20.9 F	199.8 F
03/30/25 20:00	36.8 U	0.071 E	31.4 E	0.0	0.0	0.0	64.3 EU	0.099 E	26.8 E	15.9	199.8
03/30/25 21:00	13.6 U	0.016	7.3	0.0	0.0	0.0	12.9 U	0.015	4.2	15.1	199.8
03/30/25 22:00	17.7	0.023	10.0	0.0	0.0	0.0	12.4	0.016	4.3	15.2	199.8
03/30/25 23:00	17.9	0.023	10.3	0.0	0.0	0.0	12.3	0.016	4.3	15.1	199.8
03/31/25 00:00	16.9	0.022	9.8	0.0	0.0	0.0	12.3	0.016	4.3	15.2	199.8
03/31/25 01:00	17.5	0.023	10.1	0.0	0.0	0.0	12.2	0.016	4.3	15.2	199.8
03/31/25 02:00	17.9	0.023	10.4	0.0	0.0	0.0	12.3	0.016	4.3	15.2	199.8
03/31/25 03:00	18.1	0.023	10.5	0.0	0.0	0.0	12.3	0.016	4.3	15.2	199.8

UNIT START UP

UNIT SHUTDOWN

UNIT START UP

[illegible]