

DOCKETED

Docket Number:	85-AFC-03C
Project Title:	Compliance - Application for Certification for Midway-Sunset Cogeneration Project
TN #:	269996
Document Title:	MSCC 85-AFC-03C 1st Quarter 2025 AQR 3 of 3
Description:	1st Quarter 2025 AQR 3 of 3
Filer:	Stephanie Urias
Organization:	Midway Sunset Cogeneration Company
Submitter Role:	Applicant
Submission Date:	5/15/2026 10:04:23 AM
Docketed Date:	5/15/2026

UNIT C CEM REPORT

Source		UNIT_C										
Parameter Unit		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/02/25	07:00	0.0 FIC	0.011 FI	4.9 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.1 FC	199.9 F
01/02/25	08:00	0.0 FIU	0.001 FI	50.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	6.7 FIE	20.9 F	199.9 F
01/02/25	09:00	0.0 FIU	0.040 FI	32.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	3.9 FI	20.8 F	199.9 F
01/02/25	10:00	0.0 FIU	0.040 FI	26.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	3.1 FI	20.8 F	199.9 F
01/02/25	11:00	0.0 FIU	0.040 FI	25.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	3.2 FI	20.8 F	199.9 F
01/02/25	12:00	0.0 FIU	0.040 FI	24.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	3.3 FI	20.8 F	199.9 F
01/02/25	13:00	0.0 FIU	0.040 FI	23.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	3.2 FI	20.8 F	199.9 F
01/02/25	14:00	0.0 FIU	0.040 FI	25.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	3.3 FI	20.8 F	199.9 F
01/02/25	15:00	0.0 FIU	0.040 FI	25.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	3.4 FI	20.8 F	199.9 F
01/02/25	16:00	0.0 FIU	0.040 FI	26.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	3.8 FI	20.8 F	199.9 F
01/02/25	17:00	0.0 FIU	0.040 FI	25.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	3.5 FI	20.8 F	199.9 F
01/02/25	18:00	0.0 FIU	0.040 FI	26.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	3.7 FI	20.8 F	199.9 F
01/02/25	19:00	0.0 FIU	0.040 FI	26.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	3.5 FI	20.8 F	199.9 F
01/02/25	20:00	0.0 FIU	0.040 FI	25.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	3.5 FI	20.8 F	199.9 F
01/02/25	21:00	0.0 FIU	0.040 FI	25.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	3.5 FI	20.8 F	199.9 F
01/02/25	22:00	0.0 FIU	0.040 FI	23.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	3.4 FI	20.8 F	199.9 F
01/02/25	23:00	0.0 FIU	0.040 FI	24.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	3.3 FI	20.8 F	199.9 F
01/03/25	00:00	0.0 FIU	0.040 FI	23.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	3.5 FI	20.8 F	199.9 F
01/03/25	01:00	0.0 FIU	0.040 FI	24.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	3.0 FI	20.8 F	199.9 F
01/03/25	02:00	0.0 FIU	0.040 FI	23.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	3.2 FI	20.8 F	199.9 F
01/03/25	03:00	0.0 FIU	0.040 FI	23.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	3.2 FI	20.8 F	199.9 F
01/03/25	04:00	0.0 FIU	0.040 FI	22.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	2.9 FI	20.8 F	199.9 F
01/03/25	05:00	0.0 FIU	0.040 FI	23.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	3.1 FI	20.8 F	199.9 F
01/03/25	06:00	0.0 FIU	0.040 FI	23.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	4.0 FI	20.8 F	199.9 F
01/03/25	07:00	0.0 FIC	0.011 FI	5.0 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.1 FC	199.9 F
01/03/25	08:00	0.0 FIU	0.001 FI	-481.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-18.1 FI	20.9 F	199.9 F
01/03/25	09:00	0.0 FIU	0.001 FI	3,085.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	109.1 FIE	20.9 F	199.9 F
01/03/25	10:00	0.0 FIU	0.001 FI	187.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	6.2 FIE	20.9 F	199.9 F
01/03/25	11:00	0.0 FIU	0.001 FI	234.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	8.7 FIE	20.9 F	199.9 F
01/03/25	12:00	0.0 FIU	0.001 FI	152.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	4.8 FI	20.9 F	199.9 F
01/03/25	13:00	0.0 FIU	0.001 FI	119.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	4.2 FI	20.9 F	199.9 F
01/03/25	14:00	0.0 FIU	0.001 FI	133.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	5.5 FIE	20.9 F	199.9 F
01/03/25	15:00	0.0 FIU	0.001 FI	133.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	4.8 FI	20.9 F	199.9 F
01/03/25	16:00	0.0 FIU	0.001 FI	161.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	5.0 FIE	20.9 F	199.9 F
01/03/25	17:00	0.0 FIU	0.001 FI	76.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	3.1 FI	20.9 F	199.9 F
01/03/25	18:00	0.0 FIU	0.001 FI	77.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	2.3 FI	20.9 F	199.9 F
01/03/25	19:00	0.0 FIU	0.001 FI	83.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	3.3 FI	20.9 F	199.9 F

Source	Parameter Unit	UNIT_C										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/03/25	20:00	0.0 FIU	0.001 FI	82.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	2.4 FI	20.9 F	199.9 F
01/03/25	21:00	0.0 FIU	0.001 FI	68.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	2.0 FI	20.9 F	199.9 F
01/03/25	22:00	0.0 FIU	0.001 FI	71.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	2.5 FI	20.9 F	199.9 F
01/03/25	23:00	0.0 FIU	0.053 FI	26.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	1.3 FI	20.8 F	199.9 F
01/04/25	00:00	0.0 FIU	0.001 FI	72.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	2.2 FI	20.9 F	199.9 F
01/04/25	01:00	0.0 FIU	0.001 FI	74.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	3.0 FI	20.9 F	199.9 F
01/04/25	02:00	0.0 FIU	0.001 FI	72.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	2.0 FI	20.9 F	199.9 F
01/04/25	03:00	0.0 FIU	0.001 FI	75.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	2.4 FI	20.9 F	199.9 F
01/04/25	04:00	0.0 FIU	0.001 FI	68.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	2.4 FI	20.9 F	199.9 F
01/04/25	05:00	0.0 FIU	0.001 FI	62.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	1.9 FI	20.9 F	199.9 F
01/04/25	06:00	0.0 FIU	0.001 FI	71.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	2.9 FI	20.9 F	199.9 F
01/04/25	07:00	0.0 FIC	0.012 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.024 F	6.4 F	14.2 FC	199.9 F
01/04/25	08:00	0.0 FIU	0.001 FI	-31.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-3.3 FI	21.0 F	199.9 F
01/04/25	09:00	0.0 FIU	0.001 FI	-34.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-3.1 FI	21.0 F	199.9 F
01/04/25	10:00	0.0 FIU	0.001 FI	-33.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-3.6 FI	21.0 F	199.9 F
01/04/25	11:00	0.0 FIU	0.001 FI	-34.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-3.4 FI	21.0 F	199.9 F
01/04/25	12:00	0.0 FIU	0.001 FI	-34.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-3.7 FI	21.0 F	199.9 F
01/04/25	13:00	0.0 FIU	0.001 FI	-35.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-2.7 FI	21.0 F	199.9 F
01/04/25	14:00	0.0 FIU	0.001 FI	-33.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-3.3 FI	21.0 F	199.9 F
01/04/25	15:00	0.0 FIU	0.001 FI	-33.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-3.5 FI	21.0 F	199.9 F
01/04/25	16:00	0.0 FIU	0.001 FI	-32.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-2.7 FI	21.0 F	199.9 F
01/04/25	17:00	0.0 FIU	0.001 FI	-30.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-2.8 FI	21.0 F	199.9 F
01/04/25	18:00	0.0 FIU	0.001 FI	-28.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-3.2 FI	21.0 F	199.9 F
01/04/25	19:00	0.0 FIU	0.001 FI	-26.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-2.2 FI	21.0 F	199.9 F
01/04/25	20:00	0.0 FIU	0.001 FI	-24.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-2.5 FI	21.0 F	199.9 F
01/04/25	21:00	0.0 FIU	0.001 FI	-23.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FIU	0.001 FI	-2.1 FI	21.0 F	199.9 F
01/04/25	22:00	57.9 EU	0.140 E	82.5 E	0.0	0.0	0.0	57.3 EU	0.085 E	23.0 E	16.0	199.9
01/04/25	23:00	27.3 UD	0.030	13.3	0.0	0.0	0.0	15.1 UD	0.016	4.3	14.7	199.9
01/05/25	00:00	66.6 ED	0.108 E	48.0 E	0.0	0.0	0.0	28.3 ED	0.057 E	15.5 E	15.4	199.9
01/05/25	01:00	0.0 FID	0.001 FI	-34.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.5 FI	21.0 F	199.9 F
01/05/25	02:00	0.0 FID	0.001 FI	-33.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.5 FI	21.0 F	199.9 F
01/05/25	03:00	0.0 FID	0.001 FI	-34.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.1 FI	21.0 F	199.9 F
01/05/25	04:00	0.0 FID	0.001 FI	-33.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.3 FI	21.0 F	199.9 F
01/05/25	05:00	0.0 FID	0.001 FI	-32.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.8 FI	21.0 F	199.9 F
01/05/25	06:00	0.0 FID	0.001 FI	-31.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.4 FI	21.0 F	199.9 F
01/05/25	07:00	0.0 FIC	0.011 FI	5.0 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.024 F	6.4 F	14.2 FC	199.9 F
01/05/25	08:00	0.0 FID	0.001 FI	-144.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.7 FI	20.9 F	199.9 F

UNIT START UP

UNIT SHUTDOWN

Source		UNIT_C										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/05/25	09:00	0.0 FID	0.001 FI	-174.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.0 FI	20.9 F	199.9 F
01/05/25	10:00	0.0 FID	0.001 FI	-160.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	20.9 F	199.9 F
01/05/25	11:00	0.0 FID	0.001 FI	-194.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	20.9 F	199.9 F
01/05/25	12:00	0.0 FID	0.001 FI	-255.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.7 FI	20.9 F	199.9 F
01/05/25	13:00	0.0 FID	0.001 FI	-325.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.4 FI	20.9 F	199.9 F
01/05/25	14:00	0.0 FID	0.001 FI	-237.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.8 FI	20.9 F	199.9 F
01/05/25	15:00	0.0 FID	0.001 FI	-226.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.6 FI	20.9 F	199.9 F
01/05/25	16:00	0.0 FID	0.001 FI	-143.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.1 FI	20.9 F	199.9 F
01/05/25	17:00	0.0 FID	0.001 FI	-115.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	20.9 F	199.9 F
01/05/25	18:00	0.0 FID	0.001 FI	-125.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.0 FI	20.9 F	199.9 F
01/05/25	19:00	0.0 FID	0.001 FI	-142.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	20.9 F	199.8 F
01/05/25	20:00	0.0 FID	0.001 FI	-182.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.7 FI	20.9 F	199.9 F
01/05/25	21:00	0.0 FID	0.001 FI	-152.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.3 FI	20.9 F	199.9 F
01/05/25	22:00	0.0 FID	0.001 FI	-141.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.7 FI	20.9 F	199.9 F
01/05/25	23:00	0.0 FID	0.001 FI	-129.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	20.9 F	199.9 F
01/06/25	00:00	0.0 FID	0.001 FI	-127.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.1 FI	20.9 F	199.9 F
01/06/25	01:00	0.0 FID	0.001 FI	-117.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.6 FI	20.9 F	199.9 F
01/06/25	02:00	0.0 FID	0.001 FI	-118.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	20.9 F	199.9 F
01/06/25	03:00	0.0 FID	0.001 FI	-87.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	20.9 F	199.9 F
01/06/25	04:00	0.0 FID	0.001 FI	-91.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	20.9 F	199.9 F
01/06/25	05:00	0.0 FID	0.001 FI	-66.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	20.9 F	199.9 F
01/06/25	06:00	0.0 FID	0.001 FI	-54.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	20.9 F	199.9 F
01/06/25	07:00	0.0 FIC	0.012 FI	5.2 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.024 F	6.4 F	14.2 FC	199.9 F
01/06/25	08:00	0.0 FID	0.001 FI	48.0 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
01/06/25	09:00	0.0 FID	0.040 FI	26.2 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
01/06/25	10:00	0.0 FID	0.040 FI	24.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
01/06/25	11:00	0.0 FID	0.040 FI	23.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
01/06/25	12:00	0.0 FID	0.040 FI	22.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
01/06/25	13:00	0.0 FID	0.040 FI	22.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
01/06/25	14:00	0.0 FID	0.040 FI	23.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
01/06/25	15:00	0.0 FID	0.040 FI	23.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
01/06/25	16:00	0.0 FID	0.040 FI	22.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
01/06/25	17:00	0.0 FID	0.040 FI	23.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
01/06/25	18:00	0.0 FID	0.040 FI	22.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
01/06/25	19:00	0.0 FID	0.040 FI	26.0 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
01/06/25	20:00	0.0 FID	0.040 FI	24.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
01/06/25	21:00	0.0 FID	0.040 FI	23.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.8 F

Source		UNIT_C										
Parameter Unit		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/06/25	22:00	0.0 FID	0.040 FI	23.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
01/06/25	23:00	0.0 FID	0.040 FI	24.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
01/07/25	00:00	0.0 FID	0.040 FI	24.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
01/07/25	01:00	0.0 FID	0.040 FI	25.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
01/07/25	02:00	0.0 FID	0.040 FI	24.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
01/07/25	03:00	0.0 FID	0.040 FI	23.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
01/07/25	04:00	0.0 FID	0.040 FI	25.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
01/07/25	05:00	0.0 FID	0.040 FI	23.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.8 F
01/07/25	06:00	0.0 FID	0.040 FI	24.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
01/07/25	07:00	0.0 FIC	0.012 FI	5.2 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.1 FC	199.9 F
01/07/25	08:00	0.0 FID	0.001 FI	-46.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.0 FI	21.0 F	199.9 F
01/07/25	09:00	0.0 FID	0.001 FI	-42.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.2 FI	21.0 F	199.9 F
01/07/25	10:00	0.0 FID	0.001 FI	-45.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.9 FI	21.0 F	199.9 F
01/07/25	11:00	0.0 FID	0.001 FI	-44.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.2 FI	21.0 F	199.8 F
01/07/25	12:00	0.0 FID	0.001 FI	-42.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.3 FI	21.0 F	199.9 F
01/07/25	13:00	0.0 FID	0.001 FI	-42.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.2 FI	21.0 F	199.9 F
01/07/25	14:00	0.0 FID	0.001 FI	-43.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.2 FI	21.0 F	199.9 F
01/07/25	15:00	0.0 FID	0.001 FI	-42.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.2 FI	21.0 F	199.9 F
01/07/25	16:00	0.0 FID	0.001 FI	-40.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.9 FI	21.0 F	199.9 F
01/07/25	17:00	0.0 FID	0.001 FI	-42.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.5 FI	21.0 F	199.9 F
01/07/25	18:00	0.0 FID	0.001 FI	-38.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.0 FI	21.0 F	199.9 F
01/07/25	19:00	0.0 FID	0.001 FI	-39.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.0 FI	21.0 F	199.9 F
01/07/25	20:00	0.0 FID	0.001 FI	-38.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	21.0 F	199.9 F
01/07/25	21:00	0.0 FID	0.001 FI	-37.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.5 FI	21.0 F	199.9 F
01/07/25	22:00	0.0 FID	0.001 FI	-39.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.1 FI	21.0 F	199.9 F
01/07/25	23:00	0.0 FID	0.001 FI	-37.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.2 FI	21.0 F	199.9 F
01/08/25	00:00	0.0 FID	0.001 FI	-38.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.3 FI	21.0 F	199.9 F
01/08/25	01:00	0.0 FID	0.001 FI	-40.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.2 FI	21.0 F	199.9 F
01/08/25	02:00	0.0 FID	0.001 FI	-36.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.2 FI	21.0 F	199.9 F
01/08/25	03:00	0.0 FID	0.001 FI	-36.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	21.0 F	199.9 F
01/08/25	04:00	0.0 FID	0.001 FI	-39.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.9 FI	21.0 F	199.9 F
01/08/25	05:00	0.0 FID	0.001 FI	-36.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.3 FI	21.0 F	199.9 F
01/08/25	06:00	0.0 FID	0.001 FI	-36.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.4 FI	21.0 F	199.9 F
01/08/25	07:00	0.0 FIC	0.012 FI	5.2 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.024 F	6.4 F	14.2 FC	199.9 F
01/08/25	08:00	0.0 FID	0.001 FI	284.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.9 F	199.9 F
01/08/25	09:00	0.0 FID	0.001 FI	125.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.9 F	199.9 F
01/08/25	10:00	0.0 FID	0.001 FI	134.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.9 F	199.9 F

Source		UNIT_C										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/08/25	11:00	0.0 FID	0.001 FI	114.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.9 F	199.9 F
01/08/25	12:00	0.0 FID	0.001 FI	114.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.9 F	199.9 F
01/08/25	13:00	0.0 FID	0.001 FI	108.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.1 FI	20.9 F	199.9 F
01/08/25	14:00	0.0 FID	0.001 FI	108.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.9 F	199.9 F
01/08/25	15:00	0.0 FID	0.001 FI	107.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.9 F	199.9 F
01/08/25	16:00	0.0 FID	0.001 FI	126.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.9 F	199.9 F
01/08/25	17:00	0.0 FID	0.001 FI	157.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.9 F	199.9 F
01/08/25	18:00	0.0 FID	0.001 FI	129.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.9 F	199.9 F
01/08/25	19:00	0.0 FID	0.001 FI	277.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.3 FI	20.9 F	199.9 F
01/08/25	20:00	0.0 FID	0.001 FI	155.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.9 F	199.9 F
01/08/25	21:00	0.0 FID	0.001 FI	-689.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.5 FI	20.9 F	199.9 F
01/08/25	22:00	0.0 FID	0.001 FI	-87.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	20.9 F	199.9 F
01/08/25	23:00	0.0 FID	0.001 FI	-56.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
01/09/25	00:00	0.0 FID	0.001 FI	-53.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.9 F
01/09/25	01:00	0.0 FID	0.001 FI	-50.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F
01/09/25	02:00	0.0 FID	0.001 FI	-51.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
01/09/25	03:00	0.0 FID	0.001 FI	-46.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F
01/09/25	04:00	0.0 FID	0.001 FI	-47.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.9 F
01/09/25	05:00	0.0 FID	0.001 FI	-47.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
01/09/25	06:00	0.0 FID	0.001 FI	-47.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F
01/09/25	07:00	0.0 FIC	0.012 FI	5.2 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.024 F	6.4 F	14.2 FC	199.9 F
01/09/25	08:00	0.0 FID	0.001 FI	1,425.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	9.7 FIE	20.9 F	199.9 F
01/09/25	09:00	0.0 FID	0.001 FI	47.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.9 F	199.9 F
01/09/25	10:00	0.0 FID	0.026 FI	22.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.8 F	199.9 F
01/09/25	11:00	0.0 FID	0.026 FI	21.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.9 F
01/09/25	12:00	0.0 FID	0.026 FI	17.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
01/09/25	13:00	0.0 FID	0.026 FI	16.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
01/09/25	14:00	0.0 FID	0.026 FI	17.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
01/09/25	15:00	0.0 FID	0.026 FI	17.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.9 F
01/09/25	16:00	0.0 FID	0.026 FI	17.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
01/09/25	17:00	0.0 FID	0.026 FI	20.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.9 F
01/09/25	18:00	0.0 FID	0.001 FI	29.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.9 F	199.9 F
01/09/25	19:00	0.0 FID	0.001 FI	202.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.9 F	199.9 F
01/09/25	20:00	0.0 FID	0.001 FI	-242.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	20.9 F	199.9 F
01/09/25	21:00	0.0 FID	0.001 FI	12,513.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	99.9 FIE	20.9 F	199.9 F
01/09/25	22:00	0.0 FID	0.001 FI	42,453.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	217.6 FIE	20.9 F	199.9 F
01/09/25	23:00	0.0 FID	0.001 FI	-239.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	20.9 F	199.9 F

Source Parameter Unit		UNIT_C										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/10/25	00:00	0.0 FID	0.001 FI	-187.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	20.9 F	199.9 F
01/10/25	01:00	0.0 FID	0.001 FI	-100.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	20.9 F	199.9 F
01/10/25	02:00	0.0 FID	0.001 FI	-114.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	20.9 F	199.9 F
01/10/25	03:00	0.0 FID	0.001 FI	-153.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	20.9 F	199.9 F
01/10/25	04:00	0.0 FID	0.001 FI	-89.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	20.9 F	199.9 F
01/10/25	05:00	0.0 FID	0.001 FI	-71.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	20.9 F	199.9 F
01/10/25	06:00	0.0 FID	0.001 FI	-66.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	20.9 F	199.9 F
01/10/25	07:00	0.0 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.4 F	14.1 FC	199.9 F
01/10/25	08:00	0.0 FID	0.001 FI	45.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.9 F	199.9 F
01/10/25	09:00	0.0 FID	0.026 FI	21.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
01/10/25	10:00	0.0 FID	0.026 FI	20.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
01/10/25	11:00	0.0 FID	0.026 FI	14.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
01/10/25	12:00	0.0 FID	0.026 FI	12.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.9 F
01/10/25	13:00	0.0 FID	0.026 FI	14.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
01/10/25	14:00	0.0 FID	0.026 FI	17.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
01/10/25	15:00	0.0 FID	0.040 FI	22.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
01/10/25	16:00	0.0 FID	0.040 FI	29.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
01/10/25	17:00	0.0 FID	0.001 FI	90.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.9 F	199.9 F
01/10/25	18:00	0.0 FID	0.001 FI	104.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.9 F	199.9 F
01/10/25	19:00	0.0 FID	0.001 FI	126.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.9 F	199.9 F
01/10/25	20:00	0.0 FID	0.001 FI	143.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
01/10/25	21:00	0.0 FID	0.001 FI	197.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.0 FI	20.9 F	199.9 F
01/10/25	22:00	0.0 FID	0.001 FI	167.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.9 F	199.9 F
01/10/25	23:00	0.0 FID	0.001 FI	137.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.9 F	199.9 F
01/11/25	00:00	0.0 FID	0.001 FI	136.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.9 F	199.9 F
01/11/25	01:00	0.0 FID	0.001 FI	107.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.9 F	199.9 F
01/11/25	02:00	0.0 FID	0.001 FI	121.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.9 F	199.9 F
01/11/25	03:00	0.0 FID	0.001 FI	94.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.9 F	199.9 F
01/11/25	04:00	0.0 FID	0.001 FI	91.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.9 F	199.9 F
01/11/25	05:00	0.0 FID	0.001 FI	59.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.9 F	199.9 F
01/11/25	06:00	0.0 FID	0.040 FI	26.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
01/11/25	07:00	0.0 FIC	0.011 FI	5.2 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.4 F	14.1 FC	199.9 F
01/11/25	08:00	0.0 FID	0.053 FI	45.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.7 FI	20.8 F	199.9 F
01/11/25	09:00	0.0 FID	0.053 FI	40.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.8 F	199.9 F
01/11/25	10:00	0.0 FID	0.053 FI	30.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.8 F	199.8 F
01/11/25	11:00	0.0 FID	0.053 FI	28.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.8 F	189.9 F
01/11/25	12:00	0.0 FID	0.053 FI	26.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.8 F	199.9 F

Source		UNIT_C										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/11/25	13:00	0.0 FID	0.053 FI	29.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.8 F	199.9 F
01/11/25	14:00	0.0 FID	0.053 FI	36.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.8 F	199.9 F
01/11/25	15:00	0.0 FID	0.053 FI	40.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.8 F	199.9 F
01/11/25	16:00	0.0 FID	0.001 FI	48.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.9 F	199.9 F
01/11/25	17:00	0.0 FID	0.001 FI	111.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.1 FI	20.9 F	199.9 F
01/11/25	18:00	0.0 FID	0.001 FI	359.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	7.4 FIE	20.9 F	199.9 F
01/11/25	19:00	0.0 FID	0.001 FI	827.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	18.0 FIE	20.9 F	199.9 F
01/11/25	20:00	0.0 FID	0.001 FI	775.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	19.8 FIE	20.9 F	199.9 F
01/11/25	21:00	0.0 FID	0.001 FI	843.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	16.1 FIE	20.9 F	199.9 F
01/11/25	22:00	0.0 FID	0.001 FI	1,059.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	25.7 FIE	20.9 F	199.9 F
01/11/25	23:00	0.0 FID	0.001 FI	284.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.9 FIE	20.9 F	199.9 F
01/12/25	00:00	0.0 FID	0.001 FI	235.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	6.1 FIE	20.9 F	199.9 F
01/12/25	01:00	0.0 FID	0.001 FI	2,172.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	56.7 FIE	20.9 F	199.9 F
01/12/25	02:00	0.0 FID	0.001 FI	792.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	16.9 FIE	20.9 F	199.9 F
01/12/25	03:00	0.0 FID	0.001 FI	-1,864.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-33.4 FI	20.9 F	199.9 F
01/12/25	04:00	0.0 FID	0.001 FI	5,771.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	140.3 FIE	20.9 F	199.9 F
01/12/25	05:00	0.0 FID	0.001 FI	-484.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-8.4 FI	20.9 F	199.9 F
01/12/25	06:00	0.0 FID	0.001 FI	-215.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.4 FI	20.9 F	199.9 F
01/12/25	07:00	0.0 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.9 F
01/12/25	08:00	0.0 FID	0.001 FI	-109.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.5 FI	20.9 F	199.9 F
01/12/25	09:00	0.0 FID	0.001 FI	-147.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.3 FI	20.9 F	199.9 F
01/12/25	10:00	0.0 FID	0.001 FI	-154.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-5.7 FI	20.9 F	199.9 F
01/12/25	11:00	0.0 FID	0.001 FI	-440.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-11.5 FI	20.9 F	199.9 F
01/12/25	12:00	0.0 FID	0.001 FI	-42,803.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1,216.7 FI	20.9 F	199.9 F
01/12/25	13:00	0.0 FID	0.001 FI	612.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	13.4 FIE	20.9 F	199.9 F
01/12/25	14:00	0.0 FID	0.001 FI	1,077.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	25.9 FIE	20.9 F	199.9 F
01/12/25	15:00	0.0 FID	0.001 FI	-1,220.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-43.9 FI	20.9 F	199.9 F
01/12/25	16:00	0.0 FID	0.001 FI	-577.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-10.6 FI	20.9 F	199.9 F
01/12/25	17:00	0.0 FID	0.001 FI	-159.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.2 FI	20.9 F	199.9 F
01/12/25	18:00	0.0 FID	0.001 FI	-106.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.6 FI	20.9 F	199.9 F
01/12/25	19:00	0.0 FID	0.001 FI	-98.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	20.9 F	199.9 F
01/12/25	20:00	0.0 FID	0.001 FI	-85.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.0 FI	20.9 F	199.9 F
01/12/25	21:00	0.0 FID	0.001 FI	-74.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.1 FI	20.9 F	199.9 F
01/12/25	22:00	0.0 FID	0.001 FI	-93.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.1 FI	20.9 F	199.9 F
01/12/25	23:00	0.0 FID	0.001 FI	-93.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.4 FI	20.9 F	199.9 F
01/13/25	00:00	0.0 FID	0.001 FI	-82.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.1 FI	20.9 F	199.9 F
01/13/25	01:00	0.0 FID	0.001 FI	-87.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.7 FI	20.9 F	199.9 F

Source		UNIT_C										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/13/25	02:00	0.0 FID	0.001 FI	-88.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.4 FI	20.9 F	199.9 F
01/13/25	03:00	0.0 FID	0.001 FI	-92.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	20.9 F	199.9 F
01/13/25	04:00	0.0 FID	0.001 FI	-91.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.1 FI	20.9 F	199.9 F
01/13/25	05:00	0.0 FID	0.001 FI	-90.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.9 FI	20.9 F	199.9 F
01/13/25	06:00	0.0 FID	0.001 FI	-77.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.0 FI	20.9 F	199.9 F
01/13/25	07:00	0.0 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.024 F	6.4 F	14.2 FC	199.9 F
01/13/25	08:00	0.0 FID	0.001 FI	161.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.9 F	199.9 F
01/13/25	09:00	0.0 FID	0.001 FI	60.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.9 F	199.9 F
01/13/25	10:00	0.0 FID	0.001 FI	48.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.9 F	199.9 F
01/13/25	11:00	0.0 FID	0.001 FI	48.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
01/13/25	12:00	0.0 FID	0.001 FI	57.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.9 F	199.9 F
01/13/25	13:00	0.0 FID	0.001 FI	86.6 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
01/13/25	14:00	0.0 FID	0.001 FI	97.2 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.4 FI	20.9 F	199.9 F
01/13/25	15:00	0.0 FID	0.001 FI	103.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.9 F	199.9 F
01/13/25	16:00	0.0 FID	0.001 FI	77.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.9 F	199.9 F
01/13/25	17:00	0.0 FID	0.001 FI	92.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.9 F	199.9 F
01/13/25	18:00	0.0 FID	0.001 FI	141.9 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.3 FI	20.9 F	199.9 F
01/13/25	19:00	0.0 FID	0.001 FI	148.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.9 F	199.9 F
01/13/25	20:00	0.0 FID	0.001 FI	106.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
01/13/25	21:00	0.0 FID	0.001 FI	162.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.9 F	199.9 F
01/13/25	22:00	0.0 FID	0.001 FI	141.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.9 F	199.9 F
01/13/25	23:00	0.0 FID	0.001 FI	151.1 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.2 FI	20.9 F	199.9 F
01/14/25	00:00	0.0 FID	0.001 FI	117.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.9 F	199.9 F
01/14/25	01:00	0.0 FID	0.001 FI	141.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.9 F	199.9 F
01/14/25	02:00	0.0 FID	0.001 FI	119.1 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
01/14/25	03:00	0.0 FID	0.001 FI	98.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.9 F	199.9 F
01/14/25	04:00	0.0 FID	0.001 FI	213.6 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.3 FI	20.9 F	199.9 F
01/14/25	05:00	0.0 FID	0.001 FI	233.3 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
01/14/25	06:00	0.0 FID	0.001 FI	351.0 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.2 FI	20.9 F	199.9 F
01/14/25	07:00	0.0 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.024 F	6.4 F	14.2 FC	199.9 F
01/14/25	08:00	0.0 FID	0.001 FI	-113.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-16.6 FI	20.9 F	199.9 F
01/14/25	09:00	0.0 FID	0.001 FI	218.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	29.8 FIE	20.9 F	199.9 F
01/14/25	10:00	0.0 FID	0.001 FI	52.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	8.9 FIE	20.9 F	199.9 F
01/14/25	11:00	0.0 FID	0.001 FI	45.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	8.5 FIE	20.9 F	199.9 F
01/14/25	12:00	0.0 FID	0.001 FI	54.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	8.3 FIE	20.9 F	199.9 F
01/14/25	13:00	0.0 FID	0.001 FI	57.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	9.5 FIE	20.9 F	199.9 F
01/14/25	14:00	0.0 FID	0.001 FI	79.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	14.2 FIE	20.9 F	199.9 F

Source	Parameter Unit	UNIT_C										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/14/25	15:00	0.0 FID	0.040 FI	25.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.6 FI	20.8 F	199.9 F
01/14/25	16:00	0.0 FID	0.001 FI	298.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	48.1 FIE	20.9 F	199.9 F
01/14/25	17:00	0.0 FID	0.001 FI	-163.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-21.8 FI	20.9 F	199.9 F
01/14/25	18:00	0.0 FID	0.001 FI	68.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	9.9 FIE	20.9 F	199.9 F
01/14/25	19:00	0.0 FID	0.001 FI	-76.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-9.1 FI	20.9 F	199.9 F
01/14/25	20:00	0.0 FID	0.001 FI	-84.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-10.8 FI	20.9 F	199.9 F
01/14/25	21:00	0.0 FID	0.001 FI	-85.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-10.2 FI	20.9 F	199.9 F
01/14/25	22:00	0.0 FID	0.001 FI	-88.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-10.8 FI	20.9 F	199.9 F
01/14/25	23:00	0.0 FID	0.001 FI	-89.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-11.8 FI	20.9 F	199.9 F
01/15/25	00:00	0.0 FID	0.001 FI	-89.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-10.6 FI	20.9 F	199.9 F
01/15/25	01:00	0.0 FID	0.001 FI	-97.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-12.8 FI	20.9 F	199.9 F
01/15/25	02:00	0.0 FID	0.001 FI	-137.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-18.6 FI	20.9 F	199.9 F
01/15/25	03:00	0.0 FID	0.001 FI	39.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	6.3 FIE	20.9 F	199.9 F
01/15/25	04:00	0.0 FID	0.001 FI	63.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	11.0 FIE	20.9 F	199.9 F
01/15/25	05:00	0.0 FID	0.001 FI	85.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	13.1 FIE	20.9 F	199.9 F
01/15/25	06:00	0.0 FID	0.001 FI	110.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	18.5 FIE	20.9 F	199.9 F
01/15/25	07:00	0.0 FIC	0.012 FI	5.2 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.024 F	6.4 F	14.2 FC	199.9 F
01/15/25	08:00	0.0 FID	0.001 FI	55.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.6 FI	20.9 F	199.9 F
01/15/25	09:00	0.0 FID	0.040 FI	27.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.1 FI	20.8 F	199.9 F
01/15/25	10:00	0.0 FID	0.040 FI	21.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.8 F	199.9 F
01/15/25	11:00	0.0 FID	0.026 FI	18.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.8 F	199.9 F
01/15/25	12:00	0.0 FID	0.040 FI	19.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.8 F	199.9 F
01/15/25	13:00	0.0 FID	0.026 FI	19.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.8 F	199.9 F
01/15/25	14:00	0.0 FID	0.026 FI	19.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.8 F	199.9 F
01/15/25	15:00	0.0 FID	0.026 FI	19.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.8 F	199.9 F
01/15/25	16:00	0.0 FID	0.026 FI	20.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.1 FI	20.8 F	199.9 F
01/15/25	17:00	0.0 FID	0.026 FI	20.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.0 FI	20.8 F	199.9 F
01/15/25	18:00	0.0 FID	0.026 FI	20.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.0 FI	20.8 F	199.9 F
01/15/25	19:00	0.0 FID	0.026 FI	22.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.0 FI	20.8 F	199.9 F
01/15/25	20:00	0.0 FID	0.040 FI	23.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.8 F	199.9 F
01/15/25	21:00	0.0 FID	0.026 FI	26.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.1 FI	20.8 F	199.9 F
01/15/25	22:00	0.0 FID	0.001 FI	35.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.6 FI	20.9 F	199.9 F
01/15/25	23:00	0.0 FID	0.040 FI	19.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.8 F	199.9 F
01/16/25	00:00	0.0 FID	0.001 FI	2,078.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	62.8 FIE	20.9 F	199.9 F
01/16/25	01:00	0.0 FID	0.001 FI	-1,447.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-52.5 FI	20.9 F	199.9 F
01/16/25	02:00	0.0 FID	0.001 FI	-1,271.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-24.3 FI	20.9 F	199.9 F
01/16/25	03:00	0.0 FID	0.001 FI	-566.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-17.1 FI	20.9 F	199.9 F

Source		UNIT_C										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/16/25	04:00	0.0 FID	0.001 FI	-421.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-10.5 FI	20.9 F	199.9 F
01/16/25	05:00	0.0 FID	0.001 FI	-211.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-5.9 FI	20.9 F	199.9 F
01/16/25	06:00	0.0 FID	0.001 FI	-305.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-8.6 FI	20.9 F	199.9 F
01/16/25	07:00	0.0 FIC	0.012 FI	5.2 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.9 F
01/16/25	08:00	0.0 FID	0.001 FI	107.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	7.2 FIE	20.9 F	199.9 F
01/16/25	09:00	0.0 FID	0.040 FI	37.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.0 FI	20.8 F	199.9 F
01/16/25	10:00	0.0 FID	0.040 FI	24.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.6 FI	20.8 F	199.9 F
01/16/25	11:00	0.0 FID	0.040 FI	23.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.8 F	199.9 F
01/16/25	12:00	0.0 FID	0.040 FI	21.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.1 FI	20.8 F	199.9 F
01/16/25	13:00	0.0 FID	0.040 FI	22.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.8 F	199.9 F
01/16/25	14:00	0.0 FID	0.040 FI	22.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.8 F	199.9 F
01/16/25	15:00	0.0 FID	0.040 FI	23.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.8 F	199.9 F
01/16/25	16:00	0.0 FID	0.040 FI	24.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.1 FI	20.8 F	199.9 F
01/16/25	17:00	0.0 FID	0.040 FI	25.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.8 FI	20.8 F	199.9 F
01/16/25	18:00	0.0 FID	0.040 FI	28.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.8 F	199.9 F
01/16/25	19:00	0.0 FID	0.001 FI	188.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	9.1 FIE	20.9 F	199.9 F
01/16/25	20:00	0.0 FID	0.001 FI	-213.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-7.1 FI	20.9 F	199.9 F
01/16/25	21:00	0.0 FID	0.001 FI	-177.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-8.9 FI	20.9 F	199.9 F
01/16/25	22:00	0.0 FID	0.001 FI	-155.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-6.8 FI	20.9 F	199.9 F
01/16/25	23:00	0.0 FID	0.001 FI	-157.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.7 FI	20.9 F	199.9 F
01/17/25	00:00	0.0 FID	0.001 FI	-132.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-5.9 FI	20.9 F	199.9 F
01/17/25	01:00	0.0 FID	0.001 FI	-107.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-5.7 FI	20.9 F	199.9 F
01/17/25	02:00	0.0 FID	0.001 FI	-128.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.4 FI	20.9 F	199.9 F
01/17/25	03:00	0.0 FID	0.001 FI	-110.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.6 FI	20.9 F	199.9 F
01/17/25	04:00	0.0 FID	0.001 FI	-99.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.6 FI	20.9 F	199.9 F
01/17/25	05:00	0.0 FID	0.001 FI	-99.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.3 FI	20.9 F	199.9 F
01/17/25	06:00	0.0 FID	0.001 FI	-126.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.4 FI	20.9 F	199.9 F
01/17/25	07:00	0.0 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.024 F	6.4 F	14.2 FC	199.9 F
01/17/25	08:00	0.0 FID	0.001 FI	-449.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-62.2 FI	20.9 F	199.9 F
01/17/25	09:00	0.0 FID	0.001 FI	73.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	13.2 FIE	20.9 F	199.9 F
01/17/25	10:00	0.0 FID	0.040 FI	27.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.022 FIE	5.1 FIE	20.8 F	199.9 F
01/17/25	11:00	0.0 FID	0.040 FI	24.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.022 FIE	5.2 FIE	20.8 F	199.9 F
01/17/25	12:00	0.0 FID	0.040 FI	26.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.022 FIE	5.5 FIE	20.8 F	199.9 F
01/17/25	13:00	0.0 FID	0.040 FI	32.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.022 FIE	5.5 FIE	20.8 F	199.9 F
01/17/25	14:00	0.0 FID	0.001 FI	36.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	6.6 FIE	20.9 F	199.9 F
01/17/25	15:00	0.0 FID	0.001 FI	37.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	6.7 FIE	20.9 F	199.9 F
01/17/25	16:00	0.0 FID	0.001 FI	41.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	6.0 FIE	20.9 F	199.9 F

Source		UNIT_C										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/17/25	17:00	0.0 FID	0.001 FI	153.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	26.0 FIE	20.9 F	199.9 F
01/17/25	18:00	0.0 FID	0.001 FI	-217.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-32.2 FI	20.9 F	199.9 F
01/17/25	19:00	0.0 FID	0.001 FI	-166.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-21.4 FI	20.9 F	199.9 F
01/17/25	20:00	0.0 FID	0.001 FI	-153.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-19.8 FI	20.9 F	199.9 F
01/17/25	21:00	0.0 FID	0.001 FI	-142.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-19.8 FI	20.9 F	199.9 F
01/17/25	22:00	0.0 FID	0.001 FI	-243.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-32.6 FI	20.9 F	199.9 F
01/17/25	23:00	0.0 FID	0.001 FI	-191.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-26.8 FI	20.9 F	199.9 F
01/18/25	00:00	0.0 FID	0.001 FI	-180.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-25.1 FI	20.9 F	199.9 F
01/18/25	01:00	0.0 FID	0.001 FI	-150.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-19.1 FI	20.9 F	199.9 F
01/18/25	02:00	0.0 FID	0.001 FI	-252.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-36.8 FI	20.9 F	199.9 F
01/18/25	03:00	0.0 FID	0.001 FI	-197.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-24.6 FI	20.9 F	199.9 F
01/18/25	04:00	0.0 FID	0.001 FI	-462.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-55.4 FI	20.9 F	199.9 F
01/18/25	05:00	0.0 FID	0.001 FI	-565.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-78.7 FI	20.9 F	199.9 F
01/18/25	06:00	0.0 FID	0.001 FI	-344.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-43.7 FI	20.9 F	199.9 F
01/18/25	07:00	0.0 FIC	0.013 FI	5.8 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.9 F
01/18/25	08:00	0.0 FID	0.001 FI	262.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	7.1 FIE	20.9 F	199.9 F
01/18/25	09:00	0.0 FID	0.001 FI	56.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.0 FI	20.9 F	199.9 F
01/18/25	10:00	0.0 FID	0.040 FI	30.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.0 FI	20.8 F	199.9 F
01/18/25	11:00	0.0 FID	0.040 FI	20.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.1 FI	20.8 F	199.9 F
01/18/25	12:00	0.0 FID	0.040 FI	19.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.8 F	199.9 F
01/18/25	13:00	0.0 FID	0.040 FI	18.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.9 F
01/18/25	14:00	0.0 FID	0.040 FI	18.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.8 F	199.9 F
01/18/25	15:00	0.0 FID	0.040 FI	18.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.8 F	199.9 F
01/18/25	16:00	0.0 FID	0.040 FI	20.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.8 F	199.9 F
01/18/25	17:00	0.0 FID	0.040 FI	22.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.8 F	199.9 F
01/18/25	18:00	0.0 FID	0.001 FI	36.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.9 F	199.9 F
01/18/25	19:00	0.0 FID	0.001 FI	56.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.7 FI	20.9 F	199.9 F
01/18/25	20:00	0.0 FID	0.001 FI	76.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.9 F	199.9 F
01/18/25	21:00	0.0 FID	0.001 FI	117.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.6 FI	20.9 F	199.9 F
01/18/25	22:00	0.0 FID	0.001 FI	492.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	9.5 FIE	20.9 F	199.9 F
01/18/25	23:00	0.0 FID	0.001 FI	-623.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-12.8 FI	20.9 F	199.9 F
01/19/25	00:00	0.0 FID	0.001 FI	-365.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-9.7 FI	20.9 F	199.9 F
01/19/25	01:00	0.0 FID	0.001 FI	-235.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-6.1 FI	20.9 F	199.9 F
01/19/25	02:00	0.0 FID	0.001 FI	-434.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-8.9 FI	20.9 F	199.9 F
01/19/25	03:00	0.0 FID	0.001 FI	-315.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-10.2 FI	20.9 F	199.9 F
01/19/25	04:00	0.0 FID	0.001 FI	-1,210.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-24.2 FI	20.9 F	199.9 F
01/19/25	05:00	0.0 FID	0.001 FI	-355.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-7.0 FI	20.9 F	199.9 F

Source		UNIT_C										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/19/25	06:00	0.0 FID	0.001 FI	-1,277.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-38.3 FI	20.9 F	199.9 F
01/19/25	07:00	0.0 FIC	0.012 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.9 F
01/19/25	08:00	0.0 FID	0.001 FI	-350.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	20.9 F	199.9 F
01/19/25	09:00	0.0 FID	0.001 FI	65.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.9 F	199.9 F
01/19/25	10:00	0.0 FID	0.026 FI	24.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
01/19/25	11:00	0.0 FID	0.026 FI	19.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
01/19/25	12:00	0.0 FID	0.026 FI	17.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
01/19/25	13:00	0.0 FID	0.026 FI	17.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
01/19/25	14:00	0.0 FID	0.026 FI	19.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.9 F
01/19/25	15:00	0.0 FID	0.026 FI	26.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
01/19/25	16:00	0.0 FID	0.001 FI	38.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.9 F	199.9 F
01/19/25	17:00	0.0 FID	0.001 FI	150.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.9 F	199.9 F
01/19/25	18:00	0.0 FID	0.001 FI	351.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.9 F	199.9 F
01/19/25	19:00	0.0 FID	0.001 FI	-4,513.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-6.7 FI	20.9 F	199.9 F
01/19/25	20:00	0.0 FID	0.001 FI	1,119.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	6.9 FIE	20.9 F	199.9 F
01/19/25	21:00	0.0 FID	0.001 FI	-5,800.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-9.7 FI	20.9 F	199.9 F
01/19/25	22:00	0.0 FID	0.001 FI	-742.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	20.9 F	199.9 F
01/19/25	23:00	0.0 FID	0.001 FI	-342.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	20.9 F	199.9 F
01/20/25	00:00	0.0 FID	0.001 FI	-249.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	20.9 F	199.9 F
01/20/25	01:00	0.0 FID	0.001 FI	-386.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.6 FI	20.9 F	199.9 F
01/20/25	02:00	0.0 FID	0.001 FI	-423.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	20.9 F	199.9 F
01/20/25	03:00	0.0 FID	0.001 FI	-247.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	20.9 F	199.9 F
01/20/25	04:00	0.0 FID	0.001 FI	-333.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.0 FI	20.9 F	199.9 F
01/20/25	05:00	0.0 FID	0.001 FI	-1,050.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.0 FI	20.9 F	199.9 F
01/20/25	06:00	0.0 FID	0.001 FI	-1,016.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	20.9 F	199.9 F
01/20/25	07:00	0.0 FIC	0.013 FI	5.8 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.1 FC	199.9 F
01/20/25	08:00	0.0 FID	0.001 FI	473.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.1 FIE	20.9 F	199.9 F
01/20/25	09:00	0.0 FID	0.001 FI	74.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.9 F	199.9 F
01/20/25	10:00	0.0 FID	0.001 FI	36.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.9 F	199.9 F
01/20/25	11:00	0.0 FID	0.040 FI	28.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.8 F
01/20/25	12:00	0.0 FID	0.040 FI	27.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.8 F
01/20/25	13:00	0.0 FID	0.040 FI	27.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.9 F	199.9 F
01/20/25	14:00	0.0 FID	0.040 FI	29.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.9 F
01/20/25	15:00	0.0 FID	0.040 FI	31.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.8 F	199.9 F
01/20/25	16:00	0.0 FID	0.001 FI	41.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.9 F	199.9 F
01/20/25	17:00	0.0 FID	0.001 FI	82.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.9 F	199.9 F
01/20/25	18:00	0.0 FID	0.001 FI	1,455.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	12.5 FIE	20.9 F	199.9 F

Source		UNIT_C										
Parameter Unit		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/20/25	19:00	0.0 FID	0.001 FI	2,075.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	10.6 FIE	20.9 F	199.9 F
01/20/25	20:00	0.0 FID	0.001 FI	2,619.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	27.6 FIE	20.9 F	199.9 F
01/20/25	21:00	0.0 FID	0.001 FI	1,544.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	14.0 FIE	20.9 F	199.9 F
01/20/25	22:00	0.0 FID	0.001 FI	22,864.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	206.7 FIE	20.9 F	199.9 F
01/20/25	23:00	0.0 FID	0.001 FI	3,024.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	27.3 FIE	20.9 F	199.9 F
01/21/25	00:00	0.0 FID	0.001 FI	1,057.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	10.6 FIE	20.9 F	199.9 F
01/21/25	01:00	0.0 FID	0.001 FI	-214.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.5 FI	20.9 F	199.9 F
01/21/25	02:00	0.0 FID	0.001 FI	-83.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	20.9 F	199.9 F
01/21/25	03:00	0.0 FID	0.001 FI	-61.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	20.9 F	199.9 F
01/21/25	04:00	0.0 FID	0.001 FI	-70.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	20.9 F	199.9 F
01/21/25	05:00	0.0 FID	0.001 FI	-58.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	20.9 F	199.9 F
01/21/25	06:00	0.0 FID	0.001 FI	-61.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	20.9 F	199.9 F
01/21/25	07:00	0.0 FIC	0.012 FI	5.3 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.4 F	14.2 FC	199.9 F
01/21/25	08:00	0.0 FID	0.001 FI	1,081.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	38.0 FIE	20.9 F	199.9 F
01/21/25	09:00	0.0 FID	0.001 FI	50.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.9 F	199.9 F
01/21/25	10:00	0.0 FID	0.028 FI	22.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.8 F	199.9 F
01/21/25	11:00	0.0 FID	0.026 FI	24.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.8 F	199.9 F
01/21/25	12:00	0.0 FID	0.001 FI	33.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.9 F	199.9 F
01/21/25	13:00	0.0 FID	0.001 FI	46.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.9 F	199.9 F
01/21/25	14:00	0.0 FID	0.001 FI	100.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.0 FI	20.9 F	199.9 F
01/21/25	15:00	0.0 FID	0.001 FI	198.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.5 FI	20.9 F	199.9 F
01/21/25	16:00	0.0 FID	0.001 FI	370.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	8.6 FIE	20.9 F	199.9 F
01/21/25	17:00	0.0 FID	0.001 FI	-105.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	20.9 F	199.9 F
01/21/25	18:00	0.0 FID	0.001 FI	-84.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.0 FI	20.9 F	199.9 F
01/21/25	19:00	0.0 FID	0.001 FI	-91.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.0 FI	20.9 F	199.9 F
01/21/25	20:00	0.0 FID	0.001 FI	-96.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.7 FI	20.9 F	199.9 F
01/21/25	21:00	0.0 FID	0.001 FI	-82.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.0 FI	20.9 F	199.9 F
01/21/25	22:00	0.0 FID	0.001 FI	-85.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.9 FI	20.9 F	199.9 F
01/21/25	23:00	0.0 FID	0.001 FI	58.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.9 F	199.9 F
01/22/25	00:00	0.0 FID	0.001 FI	-114.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.3 FI	20.9 F	199.9 F
01/22/25	01:00	0.0 FID	0.001 FI	-152.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.0 FI	20.9 F	199.9 F
01/22/25	02:00	0.0 FID	0.001 FI	-128.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	20.9 F	199.9 F
01/22/25	03:00	0.0 FID	0.001 FI	-156.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.6 FI	20.9 F	199.9 F
01/22/25	04:00	0.0 FID	0.001 FI	-274.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-7.2 FI	20.9 F	199.9 F
01/22/25	05:00	0.0 FID	0.001 FI	-336.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-6.2 FI	20.9 F	199.9 F
01/22/25	06:00	0.0 FID	0.001 FI	-3,613.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-84.8 FI	20.9 F	199.9 F
01/22/25	07:00	0.0 FIC	0.012 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.9 F

Source		UNIT_C										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/22/25	08:00	0.0 FID	0.001 FI	-73.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-11.5 FI	20.9 F	199.9 F
01/22/25	09:00	0.0 FID	0.001 FI	-132.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-22.7 FI	20.9 F	199.9 F
01/22/25	10:00	0.0 FID	0.001 FI	131.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	24.8 FIE	20.9 F	199.9 F
01/22/25	11:00	0.0 FID	0.001 FI	57.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	11.6 FIE	20.9 F	199.9 F
01/22/25	12:00	0.0 FID	0.001 FI	49.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	11.3 FIE	20.9 F	199.9 F
01/22/25	13:00	0.0 FID	0.001 FI	63.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	11.4 FIE	20.9 F	199.9 F
01/22/25	14:00	0.0 FID	0.001 FI	75.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	15.7 FIE	20.9 F	199.9 F
01/22/25	15:00	0.0 FID	0.001 FI	221.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	43.4 FIE	20.9 F	199.9 F
01/22/25	16:00	0.0 FID	0.001 FI	213.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	39.4 FIE	20.9 F	199.9 F
01/22/25	17:00	0.0 FID	0.001 FI	-252.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-45.5 FI	20.9 F	199.9 F
01/22/25	18:00	0.0 FID	0.001 FI	-84.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-14.1 FI	20.9 F	199.9 F
01/22/25	19:00	0.0 FID	0.001 FI	-75.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-11.8 FI	20.9 F	199.9 F
01/22/25	20:00	0.0 FID	0.001 FI	-62.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-11.1 FI	20.9 F	199.9 F
01/22/25	21:00	0.0 FID	0.001 FI	-60.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-9.8 FI	20.9 F	199.9 F
01/22/25	22:00	0.0 FID	0.001 FI	-50.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-8.1 FI	20.9 F	199.9 F
01/22/25	23:00	0.0 FID	0.001 FI	-53.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-8.4 FI	20.9 F	199.9 F
01/23/25	00:00	0.0 FID	0.001 FI	-51.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-8.1 FI	20.9 F	199.9 F
01/23/25	01:00	0.0 FID	0.001 FI	-48.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-7.6 FI	20.9 F	199.9 F
01/23/25	02:00	0.0 FID	0.001 FI	-43.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-7.1 FI	21.0 F	199.9 F
01/23/25	03:00	0.0 FID	0.001 FI	-43.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-6.3 FI	21.0 F	199.9 F
01/23/25	04:00	0.0 FID	0.001 FI	-46.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-7.3 FI	21.0 F	199.9 F
01/23/25	05:00	0.0 FID	0.001 FI	-38.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-6.7 FI	21.0 F	199.9 F
01/23/25	06:00	0.0 FID	0.001 FI	-43.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-6.2 FI	21.0 F	199.9 F
01/23/25	07:00	0.0 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.024 F	6.4 F	14.2 FC	199.9 F
01/23/25	08:00	0.0 FID	0.001 FI	-58.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.5 FI	20.9 F	199.9 F
01/23/25	09:00	0.0 FID	0.001 FI	-428.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-26.7 FI	20.9 F	199.9 F
01/23/25	10:00	0.0 FID	0.001 FI	53.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.8 FI	20.9 F	199.9 F
01/23/25	11:00	0.0 FID	0.001 FI	33.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.9 FI	20.9 F	199.9 F
01/23/25	12:00	0.0 FID	0.001 FI	43.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.3 FI	20.9 F	199.9 F
01/23/25	13:00	0.0 FID	0.001 FI	65.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.6 FIE	20.9 F	199.9 F
01/23/25	14:00	0.0 FID	0.001 FI	144.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	7.4 FIE	20.9 F	199.9 F
01/23/25	15:00	0.0 FID	0.001 FI	2,065.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	103.1 FIE	20.9 F	199.9 F
01/23/25	16:00	0.0 FID	0.001 FI	-233.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-14.8 FI	20.9 F	199.9 F
01/23/25	17:00	0.0 FID	0.001 FI	-63.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.0 FI	20.9 F	199.9 F
01/23/25	18:00	0.0 FID	0.001 FI	-38.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.2 FI	21.0 F	199.9 F
01/23/25	19:00	0.0 FID	0.001 FI	-37.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.9 FI	21.0 F	199.9 F
01/23/25	20:00	0.0 FID	0.001 FI	-39.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.9 FI	21.0 F	199.9 F

Source		UNIT_C										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/23/25	21:00	0.0 FID	0.001 FI	-40.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.3 FI	21.0 F	199.9 F
01/23/25	22:00	0.0 FID	0.001 FI	-38.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	21.0 F	199.9 F
01/23/25	23:00	0.0 FID	0.001 FI	-35.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	21.0 F	199.9 F
01/24/25	00:00	0.0 FID	0.001 FI	-35.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	21.0 F	199.9 F
01/24/25	01:00	0.0 FID	0.001 FI	-33.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	21.0 F	199.9 F
01/24/25	02:00	0.0 FID	0.001 FI	-30.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	21.0 F	199.9 F
01/24/25	03:00	0.0 FID	0.001 FI	-30.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	21.0 F	199.9 F
01/24/25	04:00	0.0 FID	0.001 FI	-28.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.9 F
01/24/25	05:00	0.0 FID	0.001 FI	-29.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	21.0 F	199.9 F
01/24/25	06:00	0.0 FID	0.001 FI	-28.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	21.0 F	199.9 F
01/24/25	07:00	0.0 FIC	0.013 FI	5.9 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.9 F
01/24/25	08:00	0.0 FIM	0.010 FI	4.5 FI	0.0 F	0.0 F	0.0 FIM	0.0 FIM	0.023 FIE	6.2 FIE	4.5 FM	199.9 F
01/24/25	09:00	0.0 FIM	0.010 FI	4.4 FI	0.0 F	0.0 F	0.0 FIM	0.0 FIM	0.023 F	6.2 F	4.4 FMC	199.9 F
01/24/25	10:00	0.0 FID	0.001 FI	-49.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.2 FI	20.9 F	199.9 F
01/24/25	11:00	0.0 FID	0.001 FI	-55.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	20.9 F	199.9 F
01/24/25	12:00	0.0 FID	0.001 FI	-57.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	20.9 F	199.9 F
01/24/25	13:00	0.0 FID	0.001 FI	-52.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	20.9 F	199.9 F
01/24/25	14:00	0.0 FID	0.001 FI	-50.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.2 FI	20.9 F	199.9 F
01/24/25	15:00	0.0 FID	0.001 FI	-45.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	20.9 F	199.9 F
01/24/25	16:00	0.0 FID	0.001 FI	-41.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.1 FI	20.9 F	199.9 F
01/24/25	17:00	0.0 FID	0.001 FI	-30.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.9 F
01/24/25	18:00	0.0 FID	0.001 FI	-27.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.9 F
01/24/25	19:00	0.0 FID	0.001 FI	-27.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.9 F
01/24/25	20:00	0.0 FID	0.001 FI	-29.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.9 F
01/24/25	21:00	0.0 FID	0.001 FI	-26.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.9 F
01/24/25	22:00	0.0 FID	0.001 FI	-27.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.9 F
01/24/25	23:00	0.0 FID	0.001 FI	-28.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.9 F
01/25/25	00:00	0.0 FID	0.001 FI	-27.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.9 F
01/25/25	01:00	0.0 FID	0.001 FI	-27.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.9 F
01/25/25	02:00	0.0 FID	0.001 FI	-30.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.9 F
01/25/25	03:00	0.0 FID	0.001 FI	-27.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.9 F
01/25/25	04:00	0.0 FID	0.001 FI	-28.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.9 F
01/25/25	05:00	0.0 FID	0.001 FI	-27.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F
01/25/25	06:00	0.0 FID	0.001 FI	-28.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.9 F
01/25/25	07:00	0.0 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.9 F
01/25/25	08:00	0.0 FID	0.001 FI	-161.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	20.9 F	199.9 F
01/25/25	09:00	0.0 FID	0.001 FI	196.9 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.9 F

Source		UNIT_C										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/25/25	10:00	0.0 FID	0.001 FI	150.3 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.5 FI	20.9 F	199.9 F
01/25/25	11:00	0.0 FID	0.001 FI	74.7 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
01/25/25	12:00	0.0 FID	0.001 FI	94.7 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
01/25/25	13:00	0.0 FID	0.001 FI	55.3 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
01/25/25	14:00	0.0 FID	0.001 FI	42.0 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.1 FI	20.9 F	199.9 F
01/25/25	15:00	0.0 FID	0.001 FI	47.2 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.1 FI	20.9 F	199.9 F
01/25/25	16:00	0.0 FID	0.026 FI	17.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
01/25/25	17:00	0.0 FID	0.026 FI	19.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
01/25/25	18:00	0.0 FID	0.026 FI	23.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
01/25/25	19:00	0.0 FID	0.001 FI	27.1 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.1 FI	20.9 F	199.9 F
01/25/25	20:00	0.0 FID	0.001 FI	26.9 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
01/25/25	21:00	0.0 FID	0.001 FI	35.2 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
01/25/25	22:00	0.0 FID	0.001 FI	36.7 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
01/25/25	23:00	0.0 FID	0.001 FI	43.5 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
01/26/25	00:00	0.0 FID	0.001 FI	53.4 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
01/26/25	01:00	0.0 FID	0.001 FI	80.0 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
01/26/25	02:00	0.0 FID	0.001 FI	91.2 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
01/26/25	03:00	0.0 FID	0.001 FI	76.8 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
01/26/25	04:00	0.0 FID	0.001 FI	72.0 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
01/26/25	05:00	0.0 FID	0.001 FI	58.9 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
01/26/25	06:00	0.0 FID	0.001 FI	39.8 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.1 FI	20.9 F	199.9 F
01/26/25	07:00	0.0 FIC	0.011 FI	5.0 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.1 FC	199.9 F
01/26/25	08:00	0.0 FID	0.001 FI	37.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.9 F	199.9 F
01/26/25	09:00	0.0 FID	0.026 FI	28.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.9 F
01/26/25	10:00	0.0 FID	0.026 FI	26.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
01/26/25	11:00	0.0 FID	0.026 FI	23.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
01/26/25	12:00	0.0 FID	0.026 FI	22.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.9 F
01/26/25	13:00	0.0 FID	0.026 FI	17.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
01/26/25	14:00	0.0 FID	0.026 FI	19.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.9 F
01/26/25	15:00	0.0 FID	0.026 FI	22.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.9 F
01/26/25	16:00	0.0 FID	0.026 FI	18.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
01/26/25	17:00	0.0 FID	0.026 FI	20.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
01/26/25	18:00	0.0 FID	0.026 FI	25.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.9 F
01/26/25	19:00	0.0 FID	0.026 FI	24.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
01/26/25	20:00	0.0 FID	0.026 FI	26.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.9 F
01/26/25	21:00	0.0 FID	0.026 FI	26.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
01/26/25	22:00	0.0 FID	0.026 FI	26.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.9 F

Source		UNIT_C										
Parameter Unit		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/26/25	23:00	0.0 FID	0.026 FI	27.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.9 F
01/27/25	00:00	0.0 FID	0.026 FI	25.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
01/27/25	01:00	0.0 FID	0.026 FI	26.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
01/27/25	02:00	0.0 FID	0.026 FI	12.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
01/27/25	03:00	0.0 FID	0.001 FI	30.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.9 F	199.9 F
01/27/25	04:00	0.0 FID	0.001 FI	31.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.9 F	199.9 F
01/27/25	05:00	0.0 FID	0.001 FI	29.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
01/27/25	06:00	0.0 FID	0.001 FI	37.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.9 F	199.9 F
01/27/25	07:00	0.0 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.1 FC	199.9 F
01/27/25	08:00	0.0 FID	0.001 FI	53.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	6.5 FIE	20.9 F	199.9 F
01/27/25	09:00	0.0 FID	0.040 FI	33.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.9 FI	20.8 F	199.9 F
01/27/25	10:00	0.0 FID	0.040 FI	20.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.1 FI	20.8 F	199.9 F
01/27/25	11:00	0.0 FID	0.040 FI	20.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.6 FI	20.8 F	199.9 F
01/27/25	12:00	0.0 FID	0.040 FI	19.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.4 FI	20.8 F	199.9 F
01/27/25	13:00	0.0 FID	0.040 FI	18.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.1 FI	20.8 F	199.9 F
01/27/25	14:00	0.0 FID	0.040 FI	19.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.3 FI	20.8 F	199.9 F
01/27/25	15:00	0.0 FID	0.040 FI	19.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.2 FI	20.8 F	199.9 F
01/27/25	16:00	0.0 FID	0.040 FI	19.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.1 FI	20.8 F	199.9 F
01/27/25	17:00	0.0 FID	0.040 FI	19.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.7 FI	20.8 F	199.9 F
01/27/25	18:00	0.0 FID	0.040 FI	19.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.2 FI	20.8 F	199.9 F
01/27/25	19:00	0.0 FID	0.040 FI	21.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.7 FI	20.8 F	199.9 F
01/27/25	20:00	0.0 FID	0.040 FI	21.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.1 FI	20.8 F	199.9 F
01/27/25	21:00	0.0 FID	0.040 FI	24.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.7 FI	20.8 F	199.9 F
01/27/25	22:00	0.0 FID	0.001 FI	45.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.7 FI	20.9 F	199.9 F
01/27/25	23:00	0.0 FID	0.001 FI	92.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	7.3 FIE	20.9 F	199.9 F
01/28/25	00:00	0.0 FID	0.001 FI	128.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	13.0 FIE	20.9 F	199.9 F
01/28/25	01:00	0.0 FID	0.001 FI	120.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	13.6 FIE	20.9 F	199.9 F
01/28/25	02:00	0.0 FID	0.001 FI	182.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	17.4 FIE	20.9 F	199.9 F
01/28/25	03:00	0.0 FID	0.001 FI	184.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	15.9 FIE	20.9 F	199.9 F
01/28/25	04:00	0.0 FID	0.001 FI	201.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	23.5 FIE	20.9 F	199.9 F
01/28/25	05:00	0.0 FID	0.001 FI	246.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	18.8 FIE	20.9 F	199.9 F
01/28/25	06:00	0.0 FID	0.001 FI	232.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	25.6 FIE	20.9 F	199.9 F
01/28/25	07:00	0.0 FIC	0.011 FI	5.0 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.1 FC	199.9 F
01/28/25	08:00	0.0 FID	0.001 FI	31.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.0 FI	20.9 F	199.9 F
01/28/25	09:00	0.0 FID	0.026 FI	17.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.2 FI	20.8 F	199.9 F
01/28/25	10:00	0.0 FID	0.026 FI	10.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.8 F	199.9 F
01/28/25	11:00	0.0 FID	0.026 FI	9.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.8 F	199.9 F

Source		UNIT_C										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/28/25	12:00	0.0 FID	0.026 FI	10.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.8 F	199.9 F
01/28/25	13:00	0.0 FID	0.026 FI	11.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.8 F	199.9 F
01/28/25	14:00	0.0 FID	0.026 FI	13.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.8 F	199.9 F
01/28/25	15:00	0.0 FID	0.026 FI	15.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.1 FI	20.8 F	199.9 F
01/28/25	16:00	0.0 FID	0.026 FI	18.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.0 FI	20.8 F	199.9 F
01/28/25	17:00	0.0 FID	0.026 FI	24.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.5 FI	20.8 F	199.9 F
01/28/25	18:00	0.0 FID	0.001 FI	37.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.5 FI	20.9 F	199.9 F
01/28/25	19:00	0.0 FID	0.001 FI	34.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.9 F	199.9 F
01/28/25	20:00	0.0 FID	0.001 FI	45.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.7 FI	20.9 F	199.9 F
01/28/25	21:00	0.0 FID	0.001 FI	46.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.2 FI	20.9 F	199.9 F
01/28/25	22:00	0.0 FID	0.001 FI	43.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.4 FI	20.9 F	199.9 F
01/28/25	23:00	0.0 FID	0.001 FI	43.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.9 FI	20.9 F	199.9 F
01/29/25	00:00	0.0 FID	0.001 FI	46.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.5 FI	20.9 F	199.9 F
01/29/25	01:00	0.0 FID	0.001 FI	43.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.0 FI	20.9 F	199.9 F
01/29/25	02:00	0.0 FID	0.001 FI	48.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.1 FI	20.9 F	199.9 F
01/29/25	03:00	0.0 FID	0.001 FI	47.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.3 FI	20.9 F	199.9 F
01/29/25	04:00	0.0 FID	0.001 FI	50.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.5 FI	20.9 F	199.9 F
01/29/25	05:00	0.0 FID	0.001 FI	45.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.0 FI	20.9 F	199.9 F
01/29/25	06:00	0.0 FID	0.001 FI	48.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.3 FI	20.9 F	199.9 F
01/29/25	07:00	0.0 FIC	0.012 FI	5.2 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.4 F	14.1 FC	199.9 F
01/29/25	08:00	0.0 FID	0.001 FI	67.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.8 FI	20.9 F	199.9 F
01/29/25	09:00	0.0 FID	0.026 FI	24.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.0 FI	20.8 F	199.9 F
01/29/25	10:00	0.0 FID	0.026 FI	18.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.8 F	199.9 F
01/29/25	11:00	0.0 FID	0.026 FI	17.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.8 F	199.9 F
01/29/25	12:00	0.0 FID	0.026 FI	17.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.8 F	199.9 F
01/29/25	13:00	0.0 FID	0.026 FI	20.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.5 FI	20.8 F	199.9 F
01/29/25	14:00	0.0 FID	0.026 FI	21.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.1 FI	20.8 F	199.9 F
01/29/25	15:00	0.0 FID	0.040 FI	27.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.8 FI	20.8 F	199.9 F
01/29/25	16:00	0.0 FID	0.001 FI	37.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.0 FI	20.9 F	199.9 F
01/29/25	17:00	0.0 FID	0.001 FI	59.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.9 FI	20.9 F	199.9 F
01/29/25	18:00	0.0 FID	0.001 FI	108.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	7.1 FIE	20.9 F	199.9 F
01/29/25	19:00	0.0 FID	0.001 FI	135.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	9.5 FIE	20.9 F	199.9 F
01/29/25	20:00	0.0 FID	0.001 FI	176.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	10.0 FIE	20.9 F	199.9 F
01/29/25	21:00	0.0 FID	0.001 FI	192.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	12.4 FIE	20.9 F	199.9 F
01/29/25	22:00	0.0 FID	0.001 FI	165.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	11.6 FIE	20.9 F	199.9 F
01/29/25	23:00	0.0 FID	0.001 FI	185.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	8.2 FIE	20.9 F	199.9 F
01/30/25	00:00	0.0 FID	0.001 FI	257.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	14.6 FIE	20.9 F	199.9 F

Source Parameter Unit		UNIT_C										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/30/25	01:00	0.0 FID	0.001 FI	226.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	12.7 FIE	20.9 F	199.9 F
01/30/25	02:00	0.0 FID	0.001 FI	171.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	10.0 FIE	20.9 F	199.9 F
01/30/25	03:00	0.0 FID	0.001 FI	216.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	17.2 FIE	20.9 F	199.9 F
01/30/25	04:00	0.0 FID	0.001 FI	212.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	11.9 FIE	20.9 F	199.9 F
01/30/25	05:00	0.0 FID	0.001 FI	165.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	11.3 FIE	20.9 F	199.9 F
01/30/25	06:00	0.0 FIM	0.001 FI	121.3 FIE	0.0 F	0.0 F	0.0 FIM	0.0 FIM	0.001 FI	7.4 FIE	20.9 FM	199.9 F
01/30/25	07:00	0.0 FIC	0.011 FI	5.0 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.1 FC	199.9 F
01/30/25	08:00	0.0 FID	0.001 FI	40.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.9 F	199.9 F
01/30/25	09:00	0.0 FID	0.026 FI	20.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.8 F	199.9 F
01/30/25	10:00	0.0 FID	0.026 FI	11.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
01/30/25	11:00	0.0 FID	0.026 FI	11.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.8 F	199.9 F
01/30/25	12:00	0.0 FID	0.026 FI	11.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.8 F	199.9 F
01/30/25	13:00	0.0 FID	0.026 FI	10.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.8 F	199.9 F
01/30/25	14:00	0.0 FID	0.026 FI	11.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.8 F
01/30/25	15:00	0.0 FID	0.026 FI	10.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.8 F	199.9 F
01/30/25	16:00	0.0 FID	0.026 FI	11.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.9 F
01/30/25	17:00	0.0 FID	0.026 FI	11.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.9 F
01/30/25	18:00	0.0 FID	0.026 FI	11.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.9 F
01/30/25	19:00	0.0 FID	0.026 FI	11.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.9 F
01/30/25	20:00	0.0 FID	0.026 FI	11.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.8 F	199.9 F
01/30/25	21:00	0.0 FID	0.026 FI	17.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.0 FI	20.8 F	199.9 F
01/30/25	22:00	0.0 FID	0.001 FI	25.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.9 F	199.9 F
01/30/25	23:00	0.0 FID	0.001 FI	32.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.9 F	199.9 F
01/31/25	00:00	0.0 FID	0.001 FI	31.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.9 FI	20.9 F	199.9 F
01/31/25	01:00	0.0 FID	0.001 FI	36.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.9 F	199.9 F
01/31/25	02:00	0.0 FID	0.001 FI	36.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.9 F	199.9 F
01/31/25	03:00	0.0 FID	0.001 FI	37.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.9 F	199.9 F
01/31/25	04:00	0.0 FID	0.001 FI	32.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.9 F	199.9 F
01/31/25	05:00	0.0 FID	0.001 FI	36.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.9 F	199.9 F
01/31/25	06:00	0.0 FID	0.001 FI	35.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.9 F	199.9 F
01/31/25	07:00	0.0 FIC	0.011 FI	5.0 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.1 FC	199.9 F
01/31/25	08:00	0.0 FID	0.001 FI	49.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.1 FIE	20.9 F	199.9 F
01/31/25	09:00	0.0 FID	0.040 FI	25.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.7 FI	20.8 F	199.9 F
01/31/25	10:00	0.0 FID	0.040 FI	20.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.5 FI	20.8 F	199.9 F
01/31/25	11:00	0.0 FID	0.040 FI	17.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.0 FI	20.8 F	199.9 F
01/31/25	12:00	0.0 FID	0.040 FI	17.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.8 FI	20.8 F	199.8 F
01/31/25	13:00	0.0 FID	0.040 FI	19.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.1 FI	20.8 F	199.9 F

Source		UNIT_C										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
01/31/25	14:00	0.0 FID	0.040 FI	18.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.0 FI	20.8 F	199.9 F
01/31/25	15:00	0.0 FID	0.040 FI	17.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.2 FI	20.8 F	199.9 F
01/31/25	16:00	0.0 FID	0.040 FI	18.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.7 FI	20.8 F	199.9 F
01/31/25	17:00	0.0 FID	0.040 FI	17.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.0 FI	20.8 F	199.9 F
01/31/25	18:00	0.0 FID	0.026 FI	17.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.2 FI	20.8 F	199.9 F
01/31/25	19:00	0.0 FID	0.026 FI	16.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.2 FI	20.8 F	199.9 F
01/31/25	20:00	0.0 FID	0.026 FI	17.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.5 FI	20.8 F	199.9 F
01/31/25	21:00	0.0 FID	0.040 FI	19.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.4 FI	20.8 F	199.9 F
01/31/25	22:00	0.0 FID	0.026 FI	18.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.1 FI	20.8 F	199.9 F
01/31/25	23:00	0.0 FID	0.040 FI	11.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.3 FI	20.8 F	199.9 F
02/01/25	00:00	0.0 FID	0.026 FI	21.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.7 FI	20.8 F	199.9 F
02/01/25	01:00	0.1 FID	0.040 FI	22.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.2 FI	20.8 F	199.9 F
02/01/25	02:00	0.1 FID	0.001 FI	31.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.8 FI	20.9 F	199.9 F
02/01/25	03:00	0.0 FID	0.001 FI	35.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.4 FI	20.9 F	199.9 F
02/01/25	04:00	0.4 FID	0.001 FI	55.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	6.1 FIE	20.9 F	199.9 F
02/01/25	05:00	0.0 FID	0.001 FI	48.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.3 FI	20.9 F	199.9 F
02/01/25	06:00	0.9 FID	0.001 FI	37.9 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	4.6 FI	20.9 F	199.9 F
02/01/25	07:00	9.5 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	1.1 FIC	0.023 F	6.3 F	14.1 FC	199.9 F
02/01/25	08:00	1.1 FID	0.001 FI	280.3 FIE	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	48.7 FIE	20.9 F	199.9 F
02/01/25	09:00	5.1 FID	0.001 FI	58.5 FIE	0.0 F	0.0 F	0.0 FI	1.5 FID	0.001 FI	11.2 FIE	20.9 F	199.9 F
02/01/25	10:00	1.9 FID	0.001 FI	50.9 FIE	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	8.4 FIE	20.9 F	199.9 F
02/01/25	11:00	0.4 FID	0.001 FI	54.6 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	9.6 FIE	20.9 F	199.9 F
02/01/25	12:00	1.7 FID	0.001 FI	50.3 FIE	0.0 F	0.0 F	0.0 FI	0.8 FID	0.001 FI	10.5 FIE	20.9 F	199.9 F
02/01/25	13:00	0.0 FID	0.001 FI	48.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	9.8 FIE	20.9 F	199.9 F
02/01/25	14:00	0.0 FID	0.001 FI	48.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	9.3 FIE	20.9 F	199.9 F
02/01/25	15:00	0.0 FID	0.001 FI	52.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	10.3 FIE	20.9 F	199.9 F
02/01/25	16:00	0.0 FID	0.001 FI	115.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	12.5 FIE	20.9 F	199.9 F
02/01/25	17:00	0.3 FID	0.001 FI	58.4 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	11.7 FIE	20.9 F	199.9 F
02/01/25	18:00	0.6 FID	0.001 FI	48.9 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	9.1 FIE	20.9 F	199.9 F
02/01/25	19:00	0.0 FID	0.001 FI	53.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	9.9 FIE	20.9 F	199.9 F
02/01/25	20:00	0.0 FID	0.001 FI	50.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	9.3 FIE	20.9 F	199.9 F
02/01/25	21:00	0.0 FID	0.001 FI	50.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	9.4 FIE	20.9 F	199.9 F
02/01/25	22:00	0.0 FID	0.001 FI	48.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	9.2 FIE	20.9 F	199.9 F
02/01/25	23:00	0.0 FID	0.001 FI	47.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	9.2 FIE	20.9 F	199.9 F
02/02/25	00:00	0.0 FID	0.001 FI	46.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	9.0 FIE	20.9 F	199.9 F
02/02/25	01:00	4.7 FID	0.001 FI	45.0 FIE	0.0 F	0.0 F	0.0 FI	1.6 FID	0.001 FI	9.5 FIE	20.9 F	199.9 F
02/02/25	02:00	4.8 FID	0.001 FI	40.0 FIE	0.0 F	0.0 F	0.0 FI	1.4 FID	0.001 FI	8.2 FIE	20.9 F	199.9 F

Source		UNIT_C										
Parameter Unit		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/02/25	03:00	0.0 FID	0.001 FI	46.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	8.1 FIE	20.9 F	199.9 F
02/02/25	04:00	0.0 FID	0.001 FI	46.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	10.8 FIE	20.9 F	199.9 F
02/02/25	05:00	0.0 FID	0.001 FI	42.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	8.2 FIE	20.9 F	199.9 F
02/02/25	06:00	0.1 FID	0.001 FI	46.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	9.4 FIE	20.9 F	199.9 F
02/02/25	07:00	0.0 FIC	0.011 FI	5.0 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.1 FC	199.9 F
02/02/25	08:00	16.0 FID	0.001 FI	-43.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/02/25	09:00	5.1 FID	0.001 FI	-44.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F
02/02/25	10:00	0.0 FID	0.001 FI	-45.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.9 F
02/02/25	11:00	0.0 FID	0.001 FI	-44.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F
02/02/25	12:00	3.3 FID	0.001 FI	-48.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
02/02/25	13:00	0.0 FID	0.001 FI	-46.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F
02/02/25	14:00	0.0 FID	0.001 FI	-48.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F
02/02/25	15:00	0.0 FID	0.001 FI	-42.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
02/02/25	16:00	0.0 FID	0.001 FI	-42.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F
02/02/25	17:00	0.0 FID	0.001 FI	-36.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/02/25	18:00	0.0 FID	0.001 FI	-38.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.9 F
02/02/25	19:00	0.0 FID	0.001 FI	-36.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
02/02/25	20:00	0.0 FID	0.001 FI	-36.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/02/25	21:00	0.0 FID	0.001 FI	-39.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
02/02/25	22:00	15.8 FID	0.001 FI	-39.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
02/02/25	23:00	4.3 FID	0.001 FI	-38.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F
02/03/25	00:00	0.2 FID	0.001 FI	-37.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
02/03/25	01:00	0.5 FID	0.001 FI	-38.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F
02/03/25	02:00	37.9 FID	0.001 FI	-38.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F
02/03/25	03:00	2.8 FID	0.001 FI	-35.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
02/03/25	04:00	0.0 FID	0.001 FI	-35.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
02/03/25	05:00	0.0 FID	0.001 FI	-32.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/03/25	06:00	0.0 FID	0.001 FI	-30.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
02/03/25	07:00	0.0 FIC	0.012 FI	5.2 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.024 F	6.4 F	14.2 FC	199.9 F
02/03/25	08:00	0.0 FID	0.001 FI	-108.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-13.4 FI	20.9 F	199.9 F
02/03/25	09:00	1.5 FID	0.001 FI	-249.4 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-30.1 FI	20.9 F	199.9 F
02/03/25	10:00	0.0 FID	0.001 FI	-212.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-22.8 FI	20.9 F	199.9 F
02/03/25	11:00	0.1 FID	0.001 FI	-134.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-18.2 FI	20.9 F	199.9 F
02/03/25	12:00	0.6 FID	0.001 FI	-89.0 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-8.4 FI	20.9 F	199.9 F
02/03/25	13:00	8.8 FID	0.001 FI	-350.1 FI	0.0 F	0.0 F	0.0 FI	1.2 FID	0.001 FI	-25.3 FI	20.9 F	199.9 F
02/03/25	14:00	0.0 FID	0.001 FI	-840.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-24.8 FI	20.9 F	199.9 F
02/03/25	15:00	0.0 FID	0.001 FI	-632.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-21.5 FI	20.9 F	199.9 F

Source Parameter Unit		UNIT_C										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/03/25	16:00	6.4 FID	0.001 FI	-511.5 FI	0.0 F	0.0 F	0.0 FI	0.5 FID	0.001 FI	-17.7 FI	20.9 F	199.9 F
02/03/25	17:00	1.5 FID	0.001 FI	-379.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-15.6 FI	20.9 F	199.9 F
02/03/25	18:00	0.0 FID	0.001 FI	-248.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-13.0 FI	20.9 F	199.9 F
02/03/25	19:00	0.0 FID	0.001 FI	-281.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-12.6 FI	20.9 F	199.9 F
02/03/25	20:00	0.0 FID	0.001 FI	-242.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-11.0 FI	20.9 F	199.9 F
02/03/25	21:00	25.2 FID	0.001 FI	-225.1 FI	0.0 F	0.0 F	0.0 FI	2.7 FID	0.001 FI	-12.8 FI	20.9 F	199.9 F
02/03/25	22:00	0.0 FID	0.001 FI	-244.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-15.2 FI	20.9 F	199.9 F
02/03/25	23:00	0.0 FID	0.001 FI	-231.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-12.9 FI	20.9 F	199.8 F
02/04/25	00:00	21.3 FID	0.001 FI	-216.5 FI	0.0 F	0.0 F	0.0 FI	3.0 FID	0.001 FI	-17.5 FI	20.9 F	199.9 F
02/04/25	01:00	19.7 FID	0.001 FI	-212.5 FI	0.0 F	0.0 F	0.0 FI	2.4 FID	0.001 FI	-15.6 FI	20.9 F	199.9 F
02/04/25	02:00	22.1 FID	0.001 FI	-201.4 FI	0.0 F	0.0 F	0.0 FI	2.2 FID	0.001 FI	-13.4 FI	20.9 F	199.9 F
02/04/25	03:00	13.1 FID	0.001 FI	-179.1 FI	0.0 F	0.0 F	0.0 FI	1.4 FID	0.001 FI	-13.1 FI	20.9 F	199.9 F
02/04/25	04:00	2.6 FID	0.001 FI	-202.6 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	-17.9 FI	20.9 F	199.9 F
02/04/25	05:00	0.0 FID	0.001 FI	-169.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-11.9 FI	20.9 F	199.9 F
02/04/25	06:00	0.0 FIM	0.001 FI	-152.1 FI	0.0 F	0.0 F	0.0 FIM	0.0 FIM	0.001 FI	-14.1 FI	20.9 FM	199.9 F
02/04/25	07:00	0.0 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.1 FC	199.9 F
02/04/25	08:00	5.6 FID	0.001 FI	452.3 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	18.7 FIE	20.9 F	199.9 F
02/04/25	09:00	3.7 FID	0.001 FI	341.4 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	9.0 FIE	20.9 F	199.9 F
02/04/25	10:00	0.0 FID	0.001 FI	735.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	8.2 FIE	20.9 F	199.9 F
02/04/25	11:00	8.5 FID	0.001 FI	429.2 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	5.8 FIE	20.9 F	199.8 F
02/04/25	12:00	0.0 FID	0.001 FI	309.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.4 FIE	20.9 F	199.8 F
02/04/25	13:00	0.0 FID	0.001 FI	367.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.7 FIE	20.9 F	199.8 F
02/04/25	14:00	0.0 FID	0.001 FI	422.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	13.7 FIE	20.9 F	199.9 F
02/04/25	15:00	0.0 FID	0.001 FI	427.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	10.1 FIE	20.9 F	199.9 F
02/04/25	16:00	0.0 FID	0.001 FI	324.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	9.0 FIE	20.9 F	199.9 F
02/04/25	17:00	0.9 FID	0.001 FI	1,352.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	32.8 FIE	20.9 F	199.9 F
02/04/25	18:00	0.0 FID	0.001 FI	1,453.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	24.9 FIE	20.9 F	199.9 F
02/04/25	19:00	0.0 FID	0.001 FI	-535.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-5.2 FI	20.9 F	199.8 F
02/04/25	20:00	0.0 FID	0.001 FI	-512.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-13.6 FI	20.9 F	199.8 F
02/04/25	21:00	0.0 FID	0.001 FI	-3,830.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-53.5 FI	20.9 F	199.8 F
02/04/25	22:00	0.0 FID	0.001 FI	952.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	15.6 FIE	20.9 F	199.8 F
02/04/25	23:00	0.0 FID	0.001 FI	487.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	9.8 FIE	20.9 F	199.8 F
02/05/25	00:00	0.0 FID	0.001 FI	257.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.5 FI	20.9 F	199.9 F
02/05/25	01:00	0.0 FID	0.001 FI	264.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.8 FI	20.9 F	199.9 F
02/05/25	02:00	0.0 FID	0.001 FI	276.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.4 FIE	20.9 F	199.9 F
02/05/25	03:00	0.0 FID	0.001 FI	245.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.3 FI	20.9 F	199.9 F
02/05/25	04:00	0.2 FID	0.001 FI	197.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.8 FI	20.9 F	199.9 F

Source Parameter Unit		UNIT_C										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/05/25	05:00	5.0 FID	0.001 FI	333.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	7.0 FIE	20.9 F	199.9 F
02/05/25	06:00	0.4 FID	0.001 FI	243.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.8 FIE	20.9 F	199.9 F
02/05/25	07:00	0.0 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.9 F
02/05/25	08:00	0.0 FID	0.001 FI	-35.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.9 F
02/05/25	09:00	0.0 FID	0.001 FI	-33.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.9 F
02/05/25	10:00	0.0 FID	0.001 FI	-31.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.0 FI	21.0 F	199.9 F
02/05/25	11:00	1.7 FID	0.001 FI	-33.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.9 F
02/05/25	12:00	4.4 FID	0.001 FI	-29.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.9 F
02/05/25	13:00	0.0 FID	0.001 FI	-33.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.9 F
02/05/25	14:00	0.0 FID	0.001 FI	-29.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.9 F
02/05/25	15:00	0.0 FID	0.001 FI	-28.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.9 F
02/05/25	16:00	2.6 FID	0.001 FI	-27.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.9 F
02/05/25	17:00	6.8 FID	0.001 FI	-27.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.4 FI	21.0 F	199.9 F
02/05/25	18:00	6.2 FID	0.001 FI	-28.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.4 FI	21.0 F	199.9 F
02/05/25	19:00	0.0 FID	0.001 FI	-23.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.9 F
02/05/25	20:00	0.0 FID	0.001 FI	-23.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F
02/05/25	21:00	0.0 FID	0.001 FI	-22.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.9 F
02/05/25	22:00	0.0 FID	0.001 FI	-23.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.9 F
02/05/25	23:00	0.0 FID	0.001 FI	-22.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.9 F
02/06/25	00:00	0.0 FID	0.001 FI	-23.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.9 F
02/06/25	01:00	0.0 FID	0.001 FI	-23.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.9 F
02/06/25	02:00	0.0 FID	0.001 FI	-22.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.9 F
02/06/25	03:00	0.0 FID	0.001 FI	-22.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.9 F
02/06/25	04:00	0.0 FID	0.001 FI	-21.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F
02/06/25	05:00	0.0 FID	0.001 FI	-21.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.9 F
02/06/25	06:00	0.0 FID	0.001 FI	-21.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F
02/06/25	07:00	0.0 FIC	0.012 FI	5.3 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.9 F
02/06/25	08:00	0.0 FID	0.053 FI	44.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.4 FI	20.8 F	199.9 F
02/06/25	09:00	0.0 FID	0.053 FI	35.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.3 FI	20.8 F	199.9 F
02/06/25	10:00	0.8 FID	0.053 FI	35.8 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	3.1 FI	20.8 F	199.9 F
02/06/25	11:00	0.0 FID	0.053 FI	37.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.5 FI	20.8 F	199.9 F
02/06/25	12:00	1.4 FID	0.053 FI	35.4 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	2.5 FI	20.8 F	199.9 F
02/06/25	13:00	0.1 FID	0.053 FI	36.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.9 FI	20.8 F	199.9 F
02/06/25	14:00	0.1 FID	0.053 FI	37.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.6 FI	20.8 F	199.9 F
02/06/25	15:00	0.4 FID	0.040 FI	35.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.3 FI	20.8 F	199.9 F
02/06/25	16:00	0.0 FID	0.053 FI	35.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.1 FI	20.8 F	199.9 F
02/06/25	17:00	0.0 FID	0.053 FI	36.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.7 FI	20.8 F	199.9 F

Source Parameter Unit	UNIT_C										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/06/25 18:00	0.0 FID	0.053 FI	35.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.6 FI	20.8 F	199.9 F
02/06/25 19:00	0.0 FID	0.053 FI	35.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.0 FI	20.8 F	199.9 F
02/06/25 20:00	0.0 FID	0.040 FI	32.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.2 FI	20.8 F	199.9 F
02/06/25 21:00	0.0 FID	0.040 FI	33.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.6 FI	20.8 F	199.9 F
02/06/25 22:00	0.0 FID	0.040 FI	31.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.8 FI	20.8 F	199.9 F
02/06/25 23:00	0.0 FID	0.040 FI	30.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.1 FI	20.8 F	199.9 F
02/07/25 00:00	0.0 FID	0.040 FI	34.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.5 FI	20.8 F	199.9 F
02/07/25 01:00	0.0 FID	0.040 FI	30.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.0 FI	20.8 F	199.9 F
02/07/25 02:00	0.0 FID	0.040 FI	32.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.4 FI	20.8 F	199.9 F
02/07/25 03:00	0.0 FID	0.053 FI	33.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.1 FI	20.8 F	199.9 F
02/07/25 04:00	0.0 FID	0.040 FI	32.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.0 FI	20.8 F	199.9 F
02/07/25 05:00	0.0 FID	0.040 FI	33.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.3 FI	20.8 F	199.9 F
02/07/25 06:00	0.0 FID	0.040 FI	30.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.8 FI	20.8 F	199.9 F
02/07/25 07:00	0.0 FIC	0.011 FI	5.0 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.1 FC	199.9 F
02/07/25 08:00	0.0 FID	0.001 FI	-43.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.4 FI	21.0 F	199.9 F
02/07/25 09:00	0.0 FID	0.001 FI	-40.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.5 FI	21.0 F	199.9 F
02/07/25 10:00	0.0 FID	0.001 FI	-44.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.1 FI	21.0 F	199.9 F
02/07/25 11:00	5.8 FID	0.001 FI	-45.9 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	-2.3 FI	21.0 F	199.9 F
02/07/25 12:00	1.0 FID	0.001 FI	-40.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.1 FI	21.0 F	199.9 F
02/07/25 13:00	0.0 FID	0.001 FI	-116.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	21.0 F	199.9 F
02/07/25 14:00	0.0 FID	0.001 FI	-48.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.9 FI	21.0 F	199.9 F
02/07/25 15:00	0.0 FID	0.001 FI	-43.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.0 FI	21.0 F	199.9 F
02/07/25 16:00	0.0 FID	0.001 FI	-41.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.9 FI	21.0 F	199.9 F
02/07/25 17:00	0.0 FID	0.001 FI	-41.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	21.0 F	199.9 F
02/07/25 18:00	0.0 FID	0.001 FI	-39.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	21.0 F	199.9 F
02/07/25 19:00	0.0 FID	0.001 FI	-38.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	21.0 F	199.9 F
02/07/25 20:00	0.0 FID	0.001 FI	-37.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	21.0 F	199.9 F
02/07/25 21:00	0.0 FID	0.001 FI	-39.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	21.0 F	199.9 F
02/07/25 22:00	1.5 FID	0.001 FI	-37.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.7 FI	21.0 F	199.9 F
02/07/25 23:00	0.0 FID	0.001 FI	-223.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-11.1 FI	20.9 F	199.9 F
02/08/25 00:00	0.0 FID	0.001 FI	-38.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.9 F
02/08/25 01:00	0.0 FID	0.001 FI	-38.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	21.0 F	199.9 F
02/08/25 02:00	0.0 FID	0.001 FI	-36.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.1 FI	21.0 F	199.9 F
02/08/25 03:00	0.0 FID	0.001 FI	-37.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.0 FI	21.0 F	199.9 F
02/08/25 04:00	0.0 FID	0.001 FI	-35.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	21.0 F	199.9 F
02/08/25 05:00	0.0 FID	0.001 FI	-34.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.2 FI	21.0 F	199.9 F
02/08/25 06:00	0.0 FID	0.001 FI	-34.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	21.0 F	199.9 F

Source		UNIT_C										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/08/25	07:00	0.0 FIC	0.011 FI	5.0 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.9 F
02/08/25	08:00	0.0 FID	0.001 FI	231.2 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.1 FI	20.9 F	199.9 F
02/08/25	09:00	0.0 FID	0.001 FI	220.9 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
02/08/25	10:00	0.0 FID	0.001 FI	480.0 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.2 FI	20.9 F	199.9 F
02/08/25	11:00	0.0 FID	0.001 FI	516.0 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
02/08/25	12:00	0.0 FID	0.001 FI	-1,120.8 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
02/08/25	13:00	0.0 FID	0.001 FI	-591.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
02/08/25	14:00	0.0 FID	0.001 FI	-357.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
02/08/25	15:00	0.0 FID	0.001 FI	-346.8 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	-0.1 FI	20.9 F	199.9 F
02/08/25	16:00	0.0 FID	0.001 FI	-315.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.4 FI	20.9 F	199.9 F
02/08/25	17:00	0.0 FID	0.001 FI	14,501.5 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
02/08/25	18:00	71.6 FID	0.001 FI	-202.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
02/08/25	19:00	4.9 FID	0.001 FI	-144.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
02/08/25	20:00	0.0 FID	0.001 FI	-124.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
02/08/25	21:00	0.0 FID	0.001 FI	-139.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
02/08/25	22:00	0.0 FID	0.001 FI	-175.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
02/08/25	23:00	0.0 FID	0.001 FI	-917.4 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
02/09/25	00:00	0.0 FID	0.001 FI	-83.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
02/09/25	01:00	0.0 FID	0.001 FI	-50.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/09/25	02:00	0.0 FID	0.001 FI	-50.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/09/25	03:00	0.0 FID	0.001 FI	-50.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/09/25	04:00	0.0 FID	0.001 FI	-48.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/09/25	05:00	0.0 FID	0.001 FI	-46.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/09/25	06:00	0.0 FID	0.001 FI	-44.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/09/25	07:00	0.0 FIC	0.012 FI	5.2 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.9 F
02/09/25	08:00	0.0 FID	0.001 FI	-558.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-22.6 FI	20.9 F	199.9 F
02/09/25	09:00	5.4 FID	0.001 FI	1,640.6 FIE	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	55.1 FIE	20.9 F	199.9 F
02/09/25	10:00	2.0 FID	0.001 FI	185.0 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	7.6 FIE	20.9 F	199.9 F
02/09/25	11:00	4.9 FID	0.001 FI	262.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.0 FI	20.9 F	199.9 F
02/09/25	12:00	0.0 FID	0.001 FI	104.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.9 FI	20.9 F	199.9 F
02/09/25	13:00	0.0 FID	0.001 FI	71.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.0 FI	20.9 F	199.9 F
02/09/25	14:00	0.0 FID	0.001 FI	68.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.9 FI	20.9 F	199.9 F
02/09/25	15:00	0.0 FID	0.001 FI	54.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.4 FI	20.9 F	199.9 F
02/09/25	16:00	0.0 FID	0.001 FI	70.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.3 FI	20.9 F	199.9 F
02/09/25	17:00	0.0 FID	0.001 FI	58.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.8 FI	20.9 F	199.9 F
02/09/25	18:00	0.0 FID	0.001 FI	72.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.6 FI	20.9 F	199.9 F
02/09/25	19:00	0.0 FID	0.001 FI	116.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.9 FIE	20.9 F	199.9 F

Source Parameter Unit		UNIT_C										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/09/25	20:00	0.0 FID	0.001 FI	94.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.5 FI	20.9 F	199.9 F
02/09/25	21:00	0.0 FID	0.001 FI	86.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.0 FI	20.9 F	199.9 F
02/09/25	22:00	0.0 FID	0.001 FI	110.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.8 FIE	20.9 F	199.9 F
02/09/25	23:00	0.0 FID	0.001 FI	102.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.4 FIE	20.9 F	199.9 F
02/10/25	00:00	0.0 FID	0.001 FI	183.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	9.6 FIE	20.9 F	199.9 F
02/10/25	01:00	0.0 FID	0.001 FI	862.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	32.9 FIE	20.9 F	199.9 F
02/10/25	02:00	0.0 FID	0.001 FI	546.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	23.0 FIE	20.9 F	199.9 F
02/10/25	03:00	0.0 FID	0.001 FI	841.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	32.0 FIE	20.9 F	199.9 F
02/10/25	04:00	0.0 FID	0.001 FI	-1,859.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-84.2 FI	20.9 F	199.9 F
02/10/25	05:00	0.0 FID	0.001 FI	888.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	28.6 FIE	20.9 F	199.9 F
02/10/25	06:00	0.0 FIM	0.001 FI	1,343.9 FIE	0.0 F	0.0 F	0.0 FIM	0.0 FIM	0.001 FI	57.1 FIE	20.9 FM	199.9 F
02/10/25	07:00	0.0 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.2 FC	199.9 F
02/10/25	08:00	0.0 FID	0.001 FI	301.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	8.7 FIE	20.9 F	199.9 F
02/10/25	09:00	0.0 FID	0.001 FI	178.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.6 FI	20.9 F	199.9 F
02/10/25	10:00	0.1 FID	0.001 FI	131.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.0 FI	20.9 F	199.9 F
02/10/25	11:00	0.0 FID	0.001 FI	208.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.8 FIE	20.9 F	199.9 F
02/10/25	12:00	0.0 FID	0.001 FI	177.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.4 FI	20.9 F	199.9 F
02/10/25	13:00	0.0 FID	0.001 FI	141.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.8 FI	20.9 F	199.9 F
02/10/25	14:00	0.0 FID	0.001 FI	111.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.5 FI	20.9 F	199.9 F
02/10/25	15:00	0.0 FID	0.001 FI	101.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.1 FI	20.9 F	199.9 F
02/10/25	16:00	0.0 FID	0.001 FI	120.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.1 FI	20.9 F	199.9 F
02/10/25	17:00	0.0 FID	0.001 FI	144.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	162.5 FIE	20.9 F	199.9 F
02/10/25	18:00	0.0 FID	0.001 FI	219.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	370.3 FIE	20.9 F	199.9 F
02/10/25	19:00	0.0 FID	0.001 FI	229.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.7 FI	20.9 F	199.9 F
02/10/25	20:00	0.0 FID	0.001 FI	289.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	8.4 FIE	20.9 F	199.9 F
02/10/25	21:00	0.0 FID	0.001 FI	-774.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-21.0 FI	20.9 F	199.9 F
02/10/25	22:00	0.0 FID	0.001 FI	-793.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-17.7 FI	20.9 F	199.9 F
02/10/25	23:00	0.0 FID	0.001 FI	4,598.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	160.5 FIE	20.9 F	199.9 F
02/11/25	00:00	0.0 FID	0.001 FI	-1,720.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-42.0 FI	20.9 F	199.9 F
02/11/25	01:00	0.2 FID	0.001 FI	-386.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-11.0 FI	20.9 F	199.9 F
02/11/25	02:00	0.1 FID	0.001 FI	-373.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-7.1 FI	20.9 F	199.9 F
02/11/25	03:00	0.0 FID	0.001 FI	-7,823.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-207.0 FI	20.9 F	199.9 F
02/11/25	04:00	0.0 FID	0.001 FI	205.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.8 FI	20.9 F	199.9 F
02/11/25	05:00	0.0 FID	0.001 FI	195.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	7.8 FIE	20.9 F	199.9 F
02/11/25	06:00	0.0 FID	0.001 FI	278.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.7 FIE	20.9 F	199.9 F
02/11/25	07:00	0.1 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.2 FC	199.9 F
02/11/25	08:00	0.0 FID	0.001 FI	-97.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-17.3 FI	20.9 F	199.9 F

Source		UNIT_C										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/11/25	09:00	0.0 FID	0.001 FI	-82.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-12.1 FI	20.9 F	199.9 F
02/11/25	10:00	0.2 FID	0.001 FI	-85.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-12.1 FI	20.9 F	199.9 F
02/11/25	11:00	3.4 FID	0.001 FI	-68.3 FI	0.0 F	0.0 F	0.0 FI	1.0 FID	0.001 FI	-9.6 FI	20.9 F	199.9 F
02/11/25	12:00	0.0 FID	0.001 FI	-84.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-10.1 FI	20.9 F	199.9 F
02/11/25	13:00	0.0 FID	0.001 FI	-85.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-13.2 FI	20.9 F	199.9 F
02/11/25	14:00	0.0 FID	0.001 FI	-82.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-11.4 FI	20.9 F	199.9 F
02/11/25	15:00	0.0 FID	0.001 FI	-69.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-9.1 FI	20.9 F	199.9 F
02/11/25	16:00	0.0 FID	0.001 FI	-84.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-9.0 FI	20.9 F	199.9 F
02/11/25	17:00	0.0 FID	0.001 FI	-101.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-13.2 FI	20.9 F	199.9 F
02/11/25	18:00	0.0 FID	0.001 FI	-79.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-11.8 FI	20.9 F	199.9 F
02/11/25	19:00	0.0 FID	0.001 FI	-75.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-12.9 FI	20.9 F	199.9 F
02/11/25	20:00	0.0 FID	0.001 FI	-109.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-17.0 FI	20.9 F	199.9 F
02/11/25	21:00	0.0 FID	0.001 FI	-83.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-13.9 FI	20.9 F	199.9 F
02/11/25	22:00	0.0 FID	0.001 FI	-85.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-15.7 FI	20.9 F	199.9 F
02/11/25	23:00	0.0 FID	0.001 FI	99.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	20.9 FIE	20.9 F	199.9 F
02/12/25	00:00	0.0 FID	0.001 FI	29.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	6.3 FIE	20.9 F	199.9 F
02/12/25	01:00	0.0 FID	0.001 FI	25.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	6.9 FIE	20.9 F	199.9 F
02/12/25	02:00	0.0 FID	0.001 FI	31.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	7.8 FIE	20.9 F	199.9 F
02/12/25	03:00	0.0 FID	0.001 FI	30.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	8.2 FIE	20.9 F	199.9 F
02/12/25	04:00	0.0 FID	0.001 FI	31.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	8.3 FIE	20.9 F	199.9 F
02/12/25	05:00	0.0 FID	0.026 FI	12.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.022 FIE	3.1 FI	20.8 F	199.9 F
02/12/25	06:00	0.0 FID	0.001 FI	29.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	7.4 FIE	20.9 F	199.9 F
02/12/25	07:00	0.0 FIC	0.011 FI	5.0 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.1 FC	199.9 F
02/12/25	08:00	0.0 FID	0.001 FI	35.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.9 F	199.9 F
02/12/25	09:00	0.0 FID	0.040 FI	31.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
02/12/25	10:00	0.0 FID	0.040 FI	28.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
02/12/25	11:00	0.0 FID	0.040 FI	30.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
02/12/25	12:00	0.0 FID	0.040 FI	31.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
02/12/25	13:00	0.0 FID	0.040 FI	27.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
02/12/25	14:00	0.0 FID	0.040 FI	25.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
02/12/25	15:00	0.0 FID	0.040 FI	27.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
02/12/25	16:00	0.0 FID	0.040 FI	28.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.9 F
02/12/25	17:00	0.0 FID	0.040 FI	27.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.9 F
02/12/25	18:00	0.0 FID	0.040 FI	26.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.9 F
02/12/25	19:00	0.0 FID	0.040 FI	25.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
02/12/25	20:00	0.0 FID	0.040 FI	25.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
02/12/25	21:00	0.0 FID	0.040 FI	26.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F

Source		UNIT_C										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/12/25	22:00	0.0 FID	0.040 FI	27.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
02/12/25	23:00	0.0 FID	0.040 FI	25.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
02/13/25	00:00	0.0 FID	0.026 FI	23.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
02/13/25	01:00	0.0 FID	0.040 FI	26.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
02/13/25	02:00	0.0 FID	0.026 FI	26.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
02/13/25	03:00	0.0 FID	0.040 FI	27.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
02/13/25	04:00	0.0 FID	0.026 FI	26.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
02/13/25	05:00	0.0 FID	0.040 FI	27.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
02/13/25	06:00	0.0 FID	0.040 FI	26.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
02/13/25	07:00	0.0 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.1 FC	199.9 F
02/13/25	08:00	0.0 FID	0.001 FI	-30.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.9 F
02/13/25	09:00	0.0 FID	0.001 FI	-34.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	21.0 F	199.9 F
02/13/25	10:00	0.0 FID	0.001 FI	-30.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	21.0 F	199.9 F
02/13/25	11:00	0.0 FID	0.001 FI	-27.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	21.0 F	199.9 F
02/13/25	12:00	0.0 FID	0.001 FI	-25.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	21.0 F	199.9 F
02/13/25	13:00	0.0 FID	0.001 FI	-28.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.9 F
02/13/25	14:00	0.0 FID	0.001 FI	-29.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	21.0 F	199.9 F
02/13/25	15:00	0.0 FID	0.001 FI	-29.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.0 FI	21.0 F	199.9 F
02/13/25	16:00	0.0 FID	0.001 FI	-32.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.9 F
02/13/25	17:00	0.0 FID	0.001 FI	-30.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.9 F
02/13/25	18:00	0.0 FID	0.001 FI	-32.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.9 F
02/13/25	19:00	0.0 FID	0.001 FI	-32.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.9 F
02/13/25	20:00	0.0 FID	0.001 FI	-33.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.9 F
02/13/25	21:00	0.0 FID	0.001 FI	-33.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	21.0 F	199.9 F
02/13/25	22:00	0.0 FID	0.001 FI	-33.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	21.0 F	199.9 F
02/13/25	23:00	0.0 FID	0.001 FI	-32.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	21.0 F	199.9 F
02/14/25	00:00	0.0 FID	0.001 FI	-33.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.9 F
02/14/25	01:00	0.0 FID	0.001 FI	-31.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	21.0 F	199.9 F
02/14/25	02:00	0.0 FID	0.001 FI	-32.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	21.0 F	199.9 F
02/14/25	03:00	0.0 FID	0.001 FI	-31.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.9 F
02/14/25	04:00	0.0 FID	0.001 FI	-33.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.9 F
02/14/25	05:00	0.0 FID	0.001 FI	-33.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	21.0 F	199.9 F
02/14/25	06:00	0.0 FID	0.001 FI	-32.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	21.0 F	199.9 F
02/14/25	07:00	0.0 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.1 F	14.2 FC	199.9 F
02/14/25	08:00	0.0 FID	0.001 FI	-35.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/14/25	09:00	0.0 FID	0.001 FI	-58.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/14/25	10:00	0.0 FID	0.001 FI	-47.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F

Source		UNIT_C										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/14/25	11:00	0.0 FID	0.001 FI	-78.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/14/25	12:00	0.0 FID	0.001 FI	-44.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
02/14/25	13:00	0.0 FID	0.001 FI	-34.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
02/14/25	14:00	0.0 FID	0.001 FI	-35.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/14/25	15:00	0.0 FID	0.001 FI	-35.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/14/25	16:00	0.0 FID	0.001 FI	-35.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/14/25	17:00	0.0 FID	0.001 FI	-36.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/14/25	18:00	0.0 FID	0.001 FI	-35.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/14/25	19:00	0.0 FID	0.001 FI	-33.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/14/25	20:00	0.0 FID	0.001 FI	-32.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/14/25	21:00	0.0 FID	0.001 FI	-31.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/14/25	22:00	0.0 FID	0.001 FI	-32.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/14/25	23:00	0.0 FID	0.001 FI	-30.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/15/25	00:00	0.0 FID	0.001 FI	-31.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/15/25	01:00	0.0 FID	0.001 FI	-32.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/15/25	02:00	0.0 FID	0.001 FI	-32.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/15/25	03:00	0.0 FID	0.001 FI	-32.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/15/25	04:00	0.0 FID	0.001 FI	-32.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/15/25	05:00	0.0 FID	0.001 FI	-32.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/15/25	06:00	0.0 FID	0.001 FI	-32.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/15/25	07:00	0.0 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.2 FC	199.9 F
02/15/25	08:00	0.0 FID	0.001 FI	-102.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-5.5 FI	20.9 F	199.9 F
02/15/25	09:00	0.0 FID	0.001 FI	-139.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-8.6 FI	20.9 F	199.9 F
02/15/25	10:00	0.0 FID	0.001 FI	-111.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-6.7 FI	20.9 F	199.9 F
02/15/25	11:00	0.0 FID	0.001 FI	-133.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-8.8 FI	20.9 F	199.9 F
02/15/25	12:00	0.5 FID	0.001 FI	-160.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-9.0 FI	20.9 F	199.9 F
02/15/25	13:00	0.0 FID	0.001 FI	-203.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-10.3 FI	20.9 F	199.9 F
02/15/25	14:00	0.0 FID	0.001 FI	-177.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-10.0 FI	20.9 F	199.9 F
02/15/25	15:00	0.0 FID	0.001 FI	-146.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-8.5 FI	20.9 F	199.9 F
02/15/25	16:00	0.0 FID	0.001 FI	-126.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-7.2 FI	20.9 F	199.9 F
02/15/25	17:00	0.0 FID	0.001 FI	-128.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-7.0 FI	20.9 F	199.9 F
02/15/25	18:00	0.0 FID	0.001 FI	-111.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-8.2 FI	20.9 F	199.9 F
02/15/25	19:00	0.0 FID	0.001 FI	-120.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-7.2 FI	20.9 F	199.9 F
02/15/25	20:00	0.0 FID	0.001 FI	-97.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-5.4 FI	20.9 F	199.9 F
02/15/25	21:00	0.0 FID	0.001 FI	-100.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-5.4 FI	20.9 F	199.9 F
02/15/25	22:00	0.0 FID	0.001 FI	-84.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-6.1 FI	20.9 F	199.9 F
02/15/25	23:00	0.0 FID	0.001 FI	87.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.4 FI	20.9 F	199.9 F

Source Parameter Unit	UNIT_C										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/16/25 00:00	0.0 FID	0.001 FI	-76.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.9 FI	20.9 F	199.9 F
02/16/25 01:00	0.0 FID	0.001 FI	-62.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.6 FI	20.9 F	199.9 F
02/16/25 02:00	0.0 FID	0.001 FI	-61.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.3 FI	20.9 F	199.9 F
02/16/25 03:00	0.0 FID	0.001 FI	-71.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-4.2 FI	20.9 F	199.9 F
02/16/25 04:00	0.0 FID	0.001 FI	-69.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.3 FI	20.9 F	199.9 F
02/16/25 05:00	0.0 FID	0.001 FI	-59.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.0 FI	20.9 F	199.9 F
02/16/25 06:00	0.0 FID	0.001 FI	-47.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.4 FI	21.0 F	199.9 F
02/16/25 07:00	0.0 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.9 F
02/16/25 08:00	0.0 FID	0.026 FI	21.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.8 F	199.9 F
02/16/25 09:00	0.0 FID	0.026 FI	17.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.8 F	199.9 F
02/16/25 10:00	0.0 FID	0.026 FI	16.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.8 F	199.9 F
02/16/25 11:00	0.0 FID	0.026 FI	14.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.8 F	199.9 F
02/16/25 12:00	0.0 FID	0.026 FI	12.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.9 F
02/16/25 13:00	0.0 FID	0.026 FI	13.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.9 F
02/16/25 14:00	0.0 FID	0.026 FI	13.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.9 F
02/16/25 15:00	0.0 FID	0.026 FI	15.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.8 F	199.9 F
02/16/25 16:00	0.0 FID	0.026 FI	14.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.9 F
02/16/25 17:00	0.0 FID	0.026 FI	13.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.8 F	199.9 F
02/16/25 18:00	0.0 FID	0.013 FI	14.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.8 F	199.9 F
02/16/25 19:00	0.0 FID	0.013 FI	13.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.8 F	199.9 F
02/16/25 20:00	0.0 FID	0.026 FI	13.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.9 F
02/16/25 21:00	0.0 FID	0.026 FI	13.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.8 F	199.9 F
02/16/25 22:00	0.0 FID	0.013 FI	12.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.9 F
02/16/25 23:00	0.0 FID	0.013 FI	12.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.8 F	199.9 F
02/17/25 00:00	0.0 FID	0.013 FI	12.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.8 F	199.9 F
02/17/25 01:00	0.0 FID	0.026 FI	14.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.8 F	199.9 F
02/17/25 02:00	0.0 FID	0.026 FI	14.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.9 F
02/17/25 03:00	0.0 FID	0.026 FI	15.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.9 F
02/17/25 04:00	0.0 FID	0.026 FI	13.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.9 F
02/17/25 05:00	0.0 FID	0.026 FI	14.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.9 F
02/17/25 06:00	0.0 FID	0.026 FI	14.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.8 F	199.9 F
02/17/25 07:00	0.0 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.2 FC	199.9 F
02/17/25 08:00	0.0 FID	0.001 FI	-250.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	20.9 F	199.9 F
02/17/25 09:00	0.0 FID	0.001 FI	-231.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.0 FI	20.9 F	199.9 F
02/17/25 10:00	0.0 FID	0.001 FI	-192.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	20.9 F	199.9 F
02/17/25 11:00	0.0 FID	0.001 FI	-329.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.4 FI	20.9 F	199.9 F
02/17/25 12:00	0.0 FID	0.001 FI	-272.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	20.9 F	199.9 F

Source	Parameter Unit	UNIT_C										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/17/25	13:00	0.0 FID	0.001 FI	-298.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	20.9 F	199.9 F
02/17/25	14:00	0.0 FID	0.001 FI	-271.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	20.9 F	199.9 F
02/17/25	15:00	0.0 FID	0.001 FI	-231.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	20.9 F	199.9 F
02/17/25	16:00	0.0 FID	0.001 FI	-271.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.0 FI	20.9 F	199.9 F
02/17/25	17:00	0.0 FID	0.001 FI	-275.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	20.9 F	199.9 F
02/17/25	18:00	0.0 FID	0.001 FI	-253.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	20.9 F	199.9 F
02/17/25	19:00	0.0 FID	0.001 FI	-175.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	20.9 F	199.9 F
02/17/25	20:00	0.0 FID	0.001 FI	-254.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.7 FI	20.9 F	199.9 F
02/17/25	21:00	0.0 FID	0.001 FI	-233.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	20.9 F	199.9 F
02/17/25	22:00	0.0 FID	0.001 FI	-237.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	20.9 F	199.9 F
02/17/25	23:00	0.0 FID	0.001 FI	-200.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	20.9 F	199.9 F
02/18/25	00:00	0.0 FID	0.001 FI	-150.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	20.9 F	199.9 F
02/18/25	01:00	0.0 FID	0.001 FI	-176.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	20.9 F	199.9 F
02/18/25	02:00	0.0 FID	0.001 FI	-176.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	20.9 F	199.9 F
02/18/25	03:00	0.0 FID	0.001 FI	-209.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	20.9 F	199.9 F
02/18/25	04:00	0.0 FID	0.001 FI	-176.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	20.9 F	199.9 F
02/18/25	05:00	0.0 FID	0.001 FI	-217.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	20.9 F	199.9 F
02/18/25	06:00	0.0 FID	0.001 FI	-155.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	20.9 F	199.9 F
02/18/25	07:00	0.0 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.2 F	14.1 FC	199.9 F
02/18/25	08:00	0.0 FID	0.053 FI	43.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.9 FI	20.8 F	199.9 F
02/18/25	09:00	0.0 FID	0.053 FI	42.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.7 FI	20.8 F	199.9 F
02/18/25	10:00	0.0 FID	0.053 FI	41.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.5 FI	20.8 F	199.9 F
02/18/25	11:00	0.0 FID	0.053 FI	41.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.1 FI	20.8 F	199.9 F
02/18/25	12:00	0.0 FID	0.053 FI	44.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.8 FI	20.8 F	199.9 F
02/18/25	13:00	0.0 FID	0.053 FI	41.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.4 FI	20.8 F	199.9 F
02/18/25	14:00	0.0 FID	0.053 FI	39.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	3.2 FI	20.8 F	199.9 F
02/18/25	15:00	12.2 FID	0.053 FI	41.6 FIE	0.0 F	0.0 F	0.0 FI	1.3 FID	0.001 FI	3.3 FI	20.8 F	199.9 F
02/18/25	16:00	66.2 EUD	0.837 E	368.2 E	0.0	0.0	0.0	5.6 UD	0.055 E	14.8 E	18.3	199.9
02/18/25	17:00	33.1 U	0.106 E	47.3 E	0.0	0.0	0.0	94.5 EU	0.137 E	37.1 E	16.2	199.9
02/18/25	18:00	32.7 CU	0.038	17.1	0.0	0.0	0.0 C	53.5 ECU	0.065 E	17.7 E	15.4 C	199.9
02/18/25	19:00	19.0	0.022	9.7	0.0	0.0	0.0	17.6	0.020 E	5.5 E	15.4	199.9
02/18/25	20:00	18.2	0.021	9.2	0.0	0.0	0.0	17.1	0.019 E	5.2 E	15.4	199.9
02/18/25	21:00	5.4	0.006	2.5	0.0	0.0	0.0	18.3 E	0.020 E	5.3 E	15.0	199.9
02/18/25	22:00	3.9 D	0.004	1.8	0.0	0.0	0.0	17.3 D	0.018	4.8	14.8	199.9
02/18/25	23:00	71.5 ED	0.196 E	86.6 E	0.0	0.0	0.0	66.7 ED	0.134 E	35.9 E	16.7	199.9
02/19/25	00:00	0.0 FID	0.001 FI	-15.8 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/19/25	01:00	0.0 FID	0.001 FI	-16.1 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.0 FI	21.0 F	199.9 F

FULL SPEED NO LOAD

UNIT START UP

*SEE DEVIATION REPORT CC-2269 Rev.1 & VARIANCE REPORT CC-2270 Rev.1 Sec 6

UNIT SHUTDOWN



Source	Parameter Unit	UNIT_C										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/19/25	02:00	0.9 FID	0.001 FI	-15.6 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/19/25	03:00	0.6 FID	0.001 FI	-14.5 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/19/25	04:00	0.0 FID	0.001 FI	-15.1 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/19/25	05:00	0.0 FID	0.001 FI	-14.9 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/19/25	06:00	0.0 FID	0.001 FI	-15.8 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/19/25	07:00	0.3 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.1 FIC	0.024 F	6.5 F	14.2 FC	199.9 F
02/19/25	08:00	0.0 FID	0.001 FI	-31.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.9 F
02/19/25	09:00	0.0 FID	0.001 FI	-28.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.9 F
02/19/25	10:00	0.0 FID	0.001 FI	-30.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.9 F
02/19/25	11:00	0.0 FID	0.001 FI	-31.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F
02/19/25	12:00	0.0 FID	0.001 FI	-31.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F
02/19/25	13:00	43.9 U	0.157 E	70.4 E	0.0	0.0	0.0	95.3 EU	0.157 E	43.1 E	16.6	199.9
02/19/25	14:00	3.3 U	0.004	1.6	0.0	0.0	0.0	38.0 EU	0.041 E	11.0 E	14.9	199.9
02/19/25	15:00	2.0	0.002	0.9	0.0	0.0	0.0	15.1	0.016	4.4	14.8	199.9
02/19/25	16:00	14.6	0.018	8.0	0.0	0.0	0.0	12.6	0.015	4.1	15.2	199.9
02/19/25	17:00	27.6	0.038	17.1	0.0	0.0	0.0	11.7	0.016	4.4	15.1	199.9
02/19/25	18:00	16.4	0.020	8.9	0.0	0.0	0.0	14.8	0.017	4.5	15.0	199.9
02/19/25	19:00	13.7	0.017	7.7	0.0	0.0	0.0	13.8	0.017	4.5	15.0	199.9
02/19/25	20:00	14.6	0.017	7.6	0.0	0.0	0.0	14.1	0.016	4.3	15.1	199.9
02/19/25	21:00	6.5	0.007	3.3	0.0	0.0	0.0	14.4	0.016	4.4	14.9	199.9
02/19/25	22:00	5.9	0.007	2.9	0.0	0.0	0.0	14.3	0.016	4.3	14.9	199.9
02/19/25	23:00	21.3	0.027	12.2	0.0	0.0	0.0	12.0	0.015	4.2	15.1	199.9
02/20/25	00:00	22.3 D	0.029	12.9	0.0	0.0	0.0	11.9 D	0.016	4.2	15.1	199.9
02/20/25	01:00	73.9 ED	0.209 E	92.8 E	0.0	0.0	0.0	54.3 ED	0.130 E	35.1 E	17.0	199.8
02/20/25	02:00	0.0 FID	0.001 FI	-29.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.9 F
02/20/25	03:00	0.0 FID	0.001 FI	-29.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F
02/20/25	04:00	0.0 FID	0.001 FI	-28.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.9 F
02/20/25	05:00	0.0 FID	0.001 FI	-28.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.9 F
02/20/25	06:00	0.0 FID	0.001 FI	-26.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.9 F
02/20/25	07:00	0.0 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.9 F
02/20/25	08:00	0.0 FID	0.001 FI	-25.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/20/25	09:00	0.0 FID	0.001 FI	-24.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
02/20/25	10:00	0.0 FID	0.001 FI	-25.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/20/25	11:00	0.0 FID	0.001 FI	-23.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
02/20/25	12:00	0.0 FID	0.001 FI	-24.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/20/25	13:00	0.0 FID	0.001 FI	-25.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/20/25	14:00	0.0 FID	0.001 FI	-25.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F



UNIT START UP

UNIT SHUTDOWN



Source Parameter Unit	UNIT_C										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/20/25 15:00	0.0 FID	0.001 FI	-25.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/20/25 16:00	0.0 FID	0.001 FI	-25.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/20/25 17:00	0.0 FID	0.001 FI	-24.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F
02/20/25 18:00	1.3 FID	0.001 FI	-23.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
02/20/25 19:00	1.5 FID	0.001 FI	-24.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/20/25 20:00	19.6 FID	0.001 FI	-32.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
02/20/25 21:00	31.2 U	0.072 E	32.2 E	0.0	0.0	0.0	83.0 EU	0.115 E	31.1 E	15.7	199.9
02/20/25 22:00	8.4 U	0.009	4.2	0.0	0.0	0.0	14.1 U	0.016	4.3	15.0	199.9
02/20/25 23:00	19.8	0.024	10.7	0.0	0.0	0.0	13.4	0.016	4.4	15.2	199.9
02/21/25 00:00	20.6	0.026	11.5	0.0	0.0	0.0	12.2	0.015	4.2	15.1	199.9
02/21/25 01:00	25.1	0.033	14.5	0.0	0.0	0.0	12.0	0.016	4.3	15.1	199.9
02/21/25 02:00	18.7	0.024	10.7	0.0	0.0	0.0	12.3	0.016	4.3	15.1	199.9
02/21/25 03:00	17.7	0.023	10.1	0.0	0.0	0.0	12.3	0.016	4.3	15.1	199.9
02/21/25 04:00	18.6	0.024	10.6	0.0	0.0	0.0	12.3	0.016	4.3	15.1	199.9
02/21/25 05:00	15.9	0.018	8.0	0.0	0.0	0.0	13.8	0.016	4.3	15.2	199.9
02/21/25 06:00	18.8 MD	0.020	9.1	0.0	0.0	0.0 M	14.0 MD	0.016	4.4	15.2 M	199.9
02/21/25 07:00	21.6 CD	0.067 E	30.1 E	0.0	0.0	0.0 C	16.0 CD	0.021 E	5.8 E	15.0 C	199.9
02/21/25 08:00	0.0 FID	0.001 FI	-22.9 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/21/25 09:00	0.0 FID	0.001 FI	-23.0 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/21/25 10:00	0.0 FID	0.001 FI	-23.0 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/21/25 11:00	0.0 FID	0.001 FI	-23.8 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
02/21/25 12:00	0.0 FID	0.001 FI	-23.7 FI	0.0 F	0.0 F	0.0 FI	0.4 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/21/25 13:00	0.0 FID	0.001 FI	-24.0 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/21/25 14:00	0.0 FID	0.001 FI	-22.8 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/21/25 15:00	0.0 FID	0.001 FI	-22.2 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/21/25 16:00	0.0 FID	0.001 FI	-21.7 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/21/25 17:00	0.0 FID	0.001 FI	-21.4 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/21/25 18:00	0.0 FID	0.001 FI	-21.0 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/21/25 19:00	0.0 FID	0.001 FI	-19.5 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/21/25 20:00	0.0 FID	0.001 FI	-20.2 FI	0.0 F	0.0 F	0.0 FI	0.3 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/21/25 21:00	48.4 U	0.172 E	76.7 E	0.0	0.0	0.0	91.5 EU	0.146 E	39.7 E	16.6	199.9
02/21/25 22:00	16.9 U	0.021	9.5	0.0	0.0	0.0	12.5 U	0.016	4.2	15.1	199.9
02/21/25 23:00	17.9	0.023	10.4	0.0	0.0	0.0	12.2	0.016	4.3	15.1	199.9
02/22/25 00:00	20.4	0.026	11.5	0.0	0.0	0.0	12.2	0.015	4.2	15.1	199.9
02/22/25 01:00	20.3	0.026	11.7	0.0	0.0	0.0	12.4	0.016	4.4	15.1	199.9
02/22/25 02:00	20.5	0.027	11.8	0.0	0.0	0.0	12.3	0.016	4.3	15.1	199.9
02/22/25 03:00	20.9	0.027	12.1	0.0	0.0	0.0	12.1	0.015	4.3	15.0	199.9



UNIT START UP

UNIT SHUTDOWN



UNIT START UP

Source Parameter Unit	UNIT_C										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/22/25 04:00	21.0	0.027	12.1	0.0	0.0	0.0	12.1	0.016	4.3	15.1	199.9
02/22/25 05:00	12.1	0.014	6.3	0.0	0.0	0.0	13.7	0.016	4.3	15.1	199.9
02/22/25 06:00	16.7 D	0.021	9.3	0.0	0.0	0.0	12.5 D	0.016	4.3	15.1	199.9
02/22/25 07:00	92.3 ECD	0.279 E	125.6 E	0.0	0.0	0.0 C	43.1 ECD	0.116 E	31.8 E	16.9 C	199.9
02/22/25 08:00	0.0 FID	0.001 FI	-28.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.9 F
02/22/25 09:00	0.0 FID	0.001 FI	-29.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F
02/22/25 10:00	0.0 FID	0.001 FI	-31.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.9 F
02/22/25 11:00	0.0 FID	0.001 FI	-31.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.9 F
02/22/25 12:00	0.0 FID	0.001 FI	-29.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
02/22/25 13:00	0.0 FID	0.001 FI	-29.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F
02/22/25 14:00	0.0 FID	0.001 FI	-28.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F
02/22/25 15:00	0.0 FID	0.001 FI	-26.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
02/22/25 16:00	0.0 FID	0.001 FI	-26.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
02/22/25 17:00	0.0 FID	0.001 FI	-25.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.9 F
02/22/25 18:00	0.0 FID	0.001 FI	-24.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
02/22/25 19:00	0.0 FID	0.001 FI	-23.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.9 F
02/22/25 20:00	0.0 FID	0.001 FI	-24.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
02/22/25 21:00	40.1 U	0.252 E	112.3 E	0.0	0.0	0.0	82.4 EU	0.117 E	31.8 E	16.8	199.9
02/22/25 22:00	20.0 U	0.026	11.4	0.0	0.0	0.0	12.3 U	0.016	4.2	15.1	199.9
02/22/25 23:00	18.8	0.024	10.7	0.0	0.0	0.0	12.3	0.016	4.3	15.1	199.9
02/23/25 00:00	20.7	0.027	11.9	0.0	0.0	0.0	12.6	0.016	4.4	15.1	199.9
02/23/25 01:00	21.6	0.028	12.5	0.0	0.0	0.0	12.4	0.016	4.4	15.1	199.9
02/23/25 02:00	17.7	0.023	10.2	0.0	0.0	0.0	12.1	0.016	4.3	15.0	199.9
02/23/25 03:00	18.1	0.024	10.5	0.0	0.0	0.0	12.1	0.016	4.3	15.0	199.9
02/23/25 04:00	17.0	0.022	9.9	0.0	0.0	0.0	12.0	0.016	4.3	15.0	199.9
02/23/25 05:00	17.6	0.023	10.2	0.0	0.0	0.0	12.0	0.016	4.3	15.0	199.9
02/23/25 06:00	19.4 D	0.025	11.3	0.0	0.0	0.0	12.2 D	0.016	4.3	15.0	199.9
02/23/25 07:00	94.5 ECD	0.333 E	147.0 E	0.0	0.0	0.0 C	39.6 ECD	0.116 E	31.1 E	17.2 C	199.9
02/23/25 08:00	0.0 FID	0.001 FI	-28.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
02/23/25 09:00	0.0 FID	0.001 FI	-27.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
02/23/25 10:00	0.0 FID	0.001 FI	-26.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F
02/23/25 11:00	0.0 FID	0.001 FI	-27.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
02/23/25 12:00	0.0 FID	0.001 FI	-26.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
02/23/25 13:00	0.0 FID	0.001 FI	-25.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
02/23/25 14:00	0.0 FID	0.001 FI	-25.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/23/25 15:00	0.0 FID	0.001 FI	-25.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
02/23/25 16:00	0.0 FID	0.001 FI	-25.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F

UNIT SHUTDOWN



UNIT START UP

UNIT SHUTDOWN



Source Parameter Unit	UNIT_C										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/23/25 17:00	0.0 FID	0.001 FI	-24.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F
02/23/25 18:00	0.0 FID	0.001 FI	-23.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/23/25 19:00	0.0 FID	0.001 FI	-22.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/23/25 20:00	0.0 FID	0.001 FI	-23.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
02/23/25 21:00	45.6 U	0.168 E	75.1 E	0.0	0.0	0.0	113.3 EU	0.190 E	52.0 E	16.7	199.9
02/23/25 22:00	19.3 U	0.024	10.9	0.0	0.0	0.0	12.7 U	0.016	4.3	15.1	199.9
02/23/25 23:00	19.9	0.026	11.4	0.0	0.0	0.0	12.2	0.016	4.3	15.1	199.9
02/24/25 00:00	22.1	0.029	12.7	0.0	0.0	0.0	12.0	0.016	4.2	15.1	199.9
02/24/25 01:00	21.2	0.027	12.1	0.0	0.0	0.0	12.2	0.016	4.3	15.1	199.9
02/24/25 02:00	20.3	0.026	11.5	0.0	0.0	0.0	12.4	0.016	4.3	15.1	199.9
02/24/25 03:00	19.8	0.026	11.4	0.0	0.0	0.0	12.2	0.016	4.3	15.1	199.9
02/24/25 04:00	21.0	0.027	12.1	0.0	0.0	0.0	12.2	0.016	4.3	15.1	199.9
02/24/25 05:00	19.6	0.025	10.9	0.0	0.0	0.0	12.7	0.016	4.3	15.2	199.9
02/24/25 06:00	10.4 D	0.012	5.4	0.0	0.0	0.0	14.0 D	0.016	4.3	15.0	199.9
02/24/25 07:00	100.0 ECD	0.304 E	138.8 E	0.0	0.0	0.0 C	48.2 ECD	0.131 E	35.8 E	17.0 C	199.9
02/24/25 08:00	0.0 FID	0.001 FI	-19.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/24/25 09:00	0.0 FID	0.001 FI	-21.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/24/25 10:00	0.0 FID	0.001 FI	-21.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/24/25 11:00	0.0 FID	0.001 FI	-22.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/24/25 12:00	0.0 FID	0.001 FI	-21.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/24/25 13:00	0.0 FID	0.001 FI	-21.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
02/24/25 14:00	0.0 FID	0.001 FI	-19.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/24/25 15:00	0.0 FID	0.001 FI	-19.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/24/25 16:00	0.0 FID	0.001 FI	-18.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/24/25 17:00	0.0 FID	0.001 FI	-18.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/24/25 18:00	0.0 FID	0.001 FI	-17.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/24/25 19:00	0.0 FID	0.001 FI	-17.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/24/25 20:00	0.0 FID	0.001 FI	-18.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
02/24/25 21:00	47.1 U	0.141 E	63.4 E	0.0	0.0	0.0	87.0 EU	0.134 E	36.8 E	16.3	199.9
02/24/25 22:00	22.1 U	0.029	12.7	0.0	0.0	0.0	11.5 U	0.015	4.0	15.1	199.9
02/24/25 23:00	20.0	0.026	11.5	0.0	0.0	0.0	11.9	0.016	4.2	15.1	199.9
02/25/25 00:00	20.5	0.027	11.9	0.0	0.0	0.0	12.3	0.016	4.4	15.1	199.9
02/25/25 01:00	20.2	0.026	11.7	0.0	0.0	0.0	12.3	0.016	4.3	15.1	199.9
02/25/25 02:00	19.4	0.025	11.2	0.0	0.0	0.0	12.3	0.016	4.4	15.1	199.9
02/25/25 03:00	22.5	0.029	13.0	0.0	0.0	0.0	12.2	0.016	4.3	15.1	199.9
02/25/25 04:00	21.4	0.028	12.4	0.0	0.0	0.0	12.2	0.016	4.3	15.1	199.9
02/25/25 05:00	12.2	0.014	6.2	0.0	0.0	0.0	13.7	0.015	4.3	15.0	199.9

UNIT START UP

UNIT SHUTDOWN

UNIT START UP



Source Parameter Unit	UNIT_C											
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)	
02/25/25 06:00	8.2 D	0.009	4.2	0.0	0.0	0.0	13.8 D	0.016	4.3	15.0	199.9	
02/25/25 07:00	93.2 ECD	0.292 E	129.7 E	0.0	0.0	0.0 C	41.4 ECD	0.115 E	31.2 E	17.0 C	199.9	UNIT SHUTDOWN
02/25/25 08:00	0.0 FID	0.001 FI	-31.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.7 FI	21.0 F	199.9 F	
02/25/25 09:00	0.0 FID	0.001 FI	-31.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.8 FI	21.0 F	199.9 F	
02/25/25 10:00	0.0 FID	0.001 FI	-31.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.0 FI	21.0 F	199.9 F	
02/25/25 11:00	0.0 FID	0.001 FI	-32.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.3 FI	21.0 F	199.9 F	
02/25/25 12:00	0.0 FID	0.001 FI	-31.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.3 FI	21.0 F	199.9 F	
02/25/25 13:00	0.0 FID	0.001 FI	-31.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.0 FI	21.0 F	199.9 F	
02/25/25 14:00	0.0 FID	0.001 FI	-30.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.7 FI	21.0 F	199.9 F	
02/25/25 15:00	0.0 FID	0.001 FI	-30.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	21.0 F	199.9 F	
02/25/25 16:00	0.0 FID	0.001 FI	-30.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.9 FI	21.0 F	199.9 F	
02/25/25 17:00	0.0 FID	0.001 FI	-28.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.3 FI	21.0 F	199.9 F	
02/25/25 18:00	0.0 FID	0.001 FI	-28.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.2 FI	21.0 F	199.9 F	
02/25/25 19:00	0.0 FID	0.001 FI	-28.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.7 FI	21.0 F	199.9 F	
02/25/25 20:00	0.0 FID	0.001 FI	-28.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.2 FI	21.0 F	199.9 F	
02/25/25 21:00	0.0 FID	0.001 FI	-29.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.9 FI	21.0 F	199.9 F	
02/25/25 22:00	0.0 FID	0.001 FI	-28.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.0 FI	21.0 F	199.9 F	
02/25/25 23:00	34.9 U	0.163 E	72.6 E	0.0	0.0	0.0	59.1 EU	0.086 E	23.2 E	16.3	199.9	UNIT START UP
02/26/25 00:00	15.0 U	0.018	7.8	0.0	0.0	0.0	13.5 U	0.016	4.3	15.2	199.9	
02/26/25 01:00	17.2	0.022	9.5	0.0	0.0	0.0	13.0	0.016	4.4	15.2	199.9	
02/26/25 02:00	21.2	0.027	12.2	0.0	0.0	0.0	11.9	0.015	4.2	15.1	199.9	
02/26/25 03:00	21.5	0.028	12.5	0.0	0.0	0.0	12.0	0.016	4.3	15.1	199.9	
02/26/25 04:00	21.8	0.028	12.6	0.0	0.0	0.0	12.3	0.016	4.4	15.1	199.9	
02/26/25 05:00	64.9 EUD	0.191 E	84.4 E	0.0	0.0	0.0	87.2 EUD	0.147 E	39.5 E	16.5	199.9	UNIT SHUTDOWN\UNIT START UP
02/26/25 06:00	15.2 UD	0.017	7.6	0.0	0.0	0.0	13.8 UD	0.016	4.3	15.1	199.9	
02/26/25 07:00	8.3 CD	0.026	11.6	0.0	0.0	0.0 C	15.6 CD	0.017	4.5	14.9 C	199.9	UNIT SHUTDOWN
02/26/25 08:00	0.0 FID	0.001 FI	-20.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F	
02/26/25 09:00	0.0 FID	0.001 FI	-18.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F	
02/26/25 10:00	0.0 FID	0.001 FI	-19.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F	
02/26/25 11:00	0.0 FID	0.001 FI	-19.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F	
02/26/25 12:00	0.0 FID	0.001 FI	-19.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F	
02/26/25 13:00	0.0 FID	0.001 FI	-18.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F	
02/26/25 14:00	0.0 FID	0.001 FI	-18.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F	
02/26/25 15:00	0.0 FID	0.001 FI	-18.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F	
02/26/25 16:00	0.0 FID	0.001 FI	-17.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F	
02/26/25 17:00	0.0 FID	0.001 FI	-17.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F	
02/26/25 18:00	0.0 FID	0.001 FI	-17.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F	



Source	Parameter Unit	UNIT_C										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
02/26/25	19:00	0.0 FID	0.001 FI	-17.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/26/25	20:00	0.0 FID	0.001 FI	-17.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
02/26/25	21:00	47.8 U	0.177 E	78.7 E	0.0	0.0	0.0	80.5 EU	0.135 E	36.7 E	16.6	199.9
02/26/25	22:00	5.6 U	0.006	2.8	0.0	0.0	0.0	14.5 U	0.017	4.4	15.0	199.9
02/26/25	23:00	7.6	0.009	3.9	0.0	0.0	0.0	13.8	0.015	4.2	15.0	199.9
02/27/25	00:00	22.0	0.028	12.3	0.0	0.0	0.0	12.1	0.015	4.1	15.1	199.9
02/27/25	01:00	23.3	0.030	13.5	0.0	0.0	0.0	11.8	0.015	4.2	15.1	199.9
02/27/25	02:00	18.3	0.023	10.2	0.0	0.0	0.0	12.6	0.016	4.3	15.1	199.9
02/27/25	03:00	13.2	0.015	6.8	0.0	0.0	0.0	13.8	0.016	4.3	15.1	199.9
02/27/25	04:00	14.8	0.017	7.6	0.0	0.0	0.0	13.8	0.016	4.3	15.1	199.9
02/27/25	05:00	10.3	0.012	5.2	0.0	0.0	0.0	14.0	0.016	4.3	15.1	199.9
02/27/25	06:00	16.4 D	0.019	6.5	0.0	0.0	0.0	13.7 D	0.016	4.3	15.2	199.9
02/27/25	07:00	100.7 ECD	0.329 E	148.0 E	0.0	0.0	0.0 C	41.0 ECD	0.117 E	32.1 E	17.1 C	199.9
02/27/25	08:00	0.0 FID	0.001 FI	-30.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.0 FI	21.0 F	199.9 F
02/27/25	09:00	0.0 FID	0.001 FI	-31.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.9 F
02/27/25	10:00	0.0 FID	0.001 FI	-28.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.9 F
02/27/25	11:00	0.0 FID	0.001 FI	-27.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.9 F
02/27/25	12:00	0.0 FID	0.001 FI	-26.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	21.0 F	199.9 F
02/27/25	13:00	0.0 FID	0.001 FI	-26.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	21.0 F	199.9 F
02/27/25	14:00	0.0 FID	0.001 FI	-24.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.0 FI	21.0 F	199.9 F
02/27/25	15:00	0.0 FID	0.001 FI	-22.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.9 F
02/27/25	16:00	0.0 FID	0.001 FI	-19.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.1 F	199.9 F
02/27/25	17:00	0.2 FID	0.001 FI	-18.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.1 F	199.9 F
02/27/25	18:00	0.0 FID	0.001 FI	-18.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.1 F	199.9 F
02/27/25	19:00	0.0 FID	0.001 FI	-17.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.1 F	199.9 F
02/27/25	20:00	0.0 FID	0.001 FI	-17.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.1 F	199.9 F
02/27/25	21:00	0.0 FID	0.001 FI	-17.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.1 F	199.9 F
02/27/25	22:00	0.0 FID	0.001 FI	-17.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.1 F	199.9 F
02/27/25	23:00	0.0 FID	0.001 FI	-17.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.1 F	199.9 F
02/28/25	00:00	0.0 FID	0.001 FI	-17.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.1 F	199.9 F
02/28/25	01:00	0.0 FID	0.001 FI	-17.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.1 F	199.9 F
02/28/25	02:00	0.0 FID	0.001 FI	-17.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.1 F	199.9 F
02/28/25	03:00	0.0 FID	0.001 FI	-17.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.1 F	199.9 F
02/28/25	04:00	0.0 FID	0.001 FI	-18.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.1 F	199.9 F
02/28/25	05:00	0.0 FID	0.001 FI	-17.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.1 F	199.9 F
02/28/25	06:00	0.0 FID	0.001 FI	-18.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.1 F	199.9 F
02/28/25	07:00	0.0 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.024 F	6.4 F	14.2 FC	199.9 F

UNIT START UP

UNIT SHUTDOWN



Source Parameter Unit	UNIT_C											
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)	
02/28/25 08:00	0.0 FID	0.001 FI	186.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	11.5 FIE	20.9 F	199.9 F	
02/28/25 09:00	0.0 FID	0.001 FI	53.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	4.2 FI	20.9 F	199.9 F	
02/28/25 10:00	0.0 FID	0.026 FI	21.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.8 F	199.9 F	
02/28/25 11:00	0.0 FID	0.026 FI	14.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.4 FI	20.8 F	199.9 F	
02/28/25 12:00	0.0 FID	0.026 FI	14.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.6 FI	20.8 F	199.9 F	
02/28/25 13:00	0.0 FID	0.026 FI	17.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.5 FI	20.8 F	199.9 F	
02/28/25 14:00	0.0 FID	0.001 FI	21.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.7 FI	20.9 F	199.9 F	
02/28/25 15:00	0.0 FID	0.001 FI	32.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.0 FI	20.9 F	199.9 F	
02/28/25 16:00	0.0 FID	0.001 FI	36.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.1 FI	20.9 F	199.9 F	
02/28/25 17:00	0.0 FID	0.001 FI	37.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.6 FI	20.9 F	199.9 F	
02/28/25 18:00	0.0 FID	0.001 FI	38.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.4 FI	20.9 F	199.9 F	
02/28/25 19:00	0.0 FID	0.001 FI	55.1 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	2.6 FI	20.9 F	199.9 F	
02/28/25 20:00	0.0 FID	0.001 FI	68.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	5.0 FIE	20.9 F	199.9 F	
02/28/25 21:00	32.4 U	0.135 E	59.8 E	0.0	0.0	0.0	117.9 EU	0.230 E	62.0 E	16.8	199.9	
02/28/25 22:00	19.7 U	0.024	10.6	0.0	0.0	0.0	26.8 EU	0.032 E	8.6 E	15.1	199.9	
02/28/25 23:00	21.1	0.027	11.9	0.0	0.0	0.0	12.5	0.016	4.3	15.1	199.9	
03/01/25 00:00	20.7	0.025	11.3	0.0	0.0	0.0	13.3	0.016	4.4	15.1	199.9	
03/01/25 01:00	20.2	0.024	11.0	0.0	0.0	0.0	13.5	0.016	4.5	15.1	199.9	
03/01/25 02:00	17.3	0.022	10.0	0.0	0.0	0.0	12.0	0.016	4.3	15.0	199.9	
03/01/25 03:00	16.7	0.022	9.7	0.0	0.0	0.0	12.1	0.016	4.3	15.0	199.9	
03/01/25 04:00	23.2	0.030	13.5	0.0	0.0	0.0	12.4	0.016	4.4	15.0	199.9	
03/01/25 05:00	24.2	0.029	13.2	0.0	0.0	0.0	13.7	0.017	4.6	15.1	199.9	
03/01/25 06:00	21.2 D	0.028	12.4	0.0	0.0	0.0	11.9 D	0.016	4.2	14.9	199.9	
03/01/25 07:00	95.9 ECD	0.301 E	135.7 E	0.0	0.0	0.0 C	40.0 ECD	0.112 E	30.8 E	16.9 C	199.9	
03/01/25 08:00	0.0 FID	0.001 FI	-28.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.9 F	
03/01/25 09:00	0.0 FID	0.001 FI	-27.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	21.0 F	199.9 F	
03/01/25 10:00	0.0 FID	0.001 FI	-26.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.9 F	
03/01/25 11:00	0.0 FID	0.001 FI	-28.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.0 FI	21.0 F	199.9 F	
03/01/25 12:00	0.0 FID	0.001 FI	-28.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	21.0 F	199.9 F	
03/01/25 13:00	0.0 FID	0.001 FI	-28.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	21.0 F	199.9 F	
03/01/25 14:00	0.0 FID	0.001 FI	-27.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	21.0 F	199.9 F	
03/01/25 15:00	0.0 FID	0.001 FI	-23.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.9 F	
03/01/25 16:00	0.0 FID	0.001 FI	-24.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.9 F	
03/01/25 17:00	0.0 FID	0.001 FI	-24.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.9 F	
03/01/25 18:00	0.0 FID	0.001 FI	-24.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.9 F	
03/01/25 19:00	0.0 FID	0.001 FI	-23.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.9 F	
03/01/25 20:00	0.0 FID	0.001 FI	-23.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.0 FI	21.0 F	199.9 F	

UNIT START UP

UNIT SHUTDOWN



Source Parameter Unit	UNIT_C											SCRTEMP (DEG_F)	
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)			
03/01/25 21:00	40.8 U	0.127 E	56.7 E	0.0	0.0	0.0	73.8 EU	0.120 E	32.7 E	16.3	199.9		UNIT START UP
03/01/25 22:00	21.8 U	0.027	11.9	0.0	0.0	0.0	12.6 U	0.015	4.2	15.2	199.9		
03/01/25 23:00	17.7	0.021	9.2	0.0	0.0	0.0	13.2	0.016	4.2	15.2	199.9		
03/02/25 00:00	16.1	0.020	9.0	0.0	0.0	0.0	12.8	0.016	4.3	15.1	199.9		
03/02/25 01:00	22.4	0.029	12.9	0.0	0.0	0.0	12.1	0.016	4.3	15.1	199.9		
03/02/25 02:00	18.5	0.023	10.2	0.0	0.0	0.0	12.9	0.016	4.4	15.1	199.9		
03/02/25 03:00	18.1	0.024	10.5	0.0	0.0	0.0	11.7	0.015	4.2	15.0	199.9		
03/02/25 04:00	18.2	0.024	10.5	0.0	0.0	0.0	12.2	0.016	4.3	15.0	199.9		
03/02/25 05:00	14.9	0.017	7.8	0.0	0.0	0.0	13.6	0.016	4.3	15.0	199.9		
03/02/25 06:00	19.3 D	0.024	10.8	0.0	0.0	0.0	12.8 D	0.016	4.3	15.1	199.9		
03/02/25 07:00	98.9 ECD	0.294 E	131.7 E	0.0	0.0	0.0 C	43.6 ECD	0.117 E	32.0 E	16.9 C	199.9		UNIT SHUTDOWN
03/02/25 08:00	0.0 FID	0.001 FI	-16.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F		
03/02/25 09:00	0.0 FID	0.001 FI	-15.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F		
03/02/25 10:00	0.0 FID	0.001 FI	-14.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F		
03/02/25 11:00	0.0 FID	0.001 FI	-15.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F		
03/02/25 12:00	0.0 FID	0.001 FI	-15.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F		
03/02/25 13:00	0.0 FID	0.001 FI	-15.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F		
03/02/25 14:00	0.0 FID	0.001 FI	-14.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F		
03/02/25 15:00	0.0 FID	0.001 FI	-15.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F		
03/02/25 16:00	0.0 FID	0.001 FI	-14.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F		
03/02/25 17:00	0.0 FID	0.001 FI	-14.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.8 F		
03/02/25 18:00	0.0 FID	0.001 FI	-14.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F		
03/02/25 19:00	0.0 FID	0.001 FI	-14.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F		
03/02/25 20:00	0.0 FID	0.001 FI	-14.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.9 F		
03/02/25 21:00	0.0 FID	0.001 FI	-14.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F		
03/02/25 22:00	0.0 FID	0.001 FI	-14.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F		
03/02/25 23:00	0.0 FID	0.001 FI	-14.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F		
03/03/25 00:00	0.0 FID	0.001 FI	-14.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F		
03/03/25 01:00	0.0 FID	0.001 FI	-14.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F		
03/03/25 02:00	78.0 EU	0.435 E	193.5 E	0.0	0.0	0.0	98.6 EU	0.155 E	41.9 E	17.5	199.9		UNIT START UP
03/03/25 03:00	20.8 U	0.027	11.8	0.0	0.0	0.0	17.9 EU	0.022 E	5.8 E	15.1	199.9		
03/03/25 04:00	22.9	0.030	13.1	0.0	0.0	0.0	12.7	0.016	4.5	15.1	199.9		
03/03/25 05:00	24.8	0.031	13.9	0.0	0.0	0.0	13.1	0.016	4.5	15.1	199.9		
03/03/25 06:00	23.2 D	0.028	12.3	0.0	0.0	0.0	14.3 D	0.017	4.8	15.2	199.9		
03/03/25 07:00	104.9 ECD	0.315 E	139.4 E	0.0	0.0	0.0 C	45.1 ECD	0.124 E	33.2 E	17.1 C	199.9		UNIT SHUTDOWN
03/03/25 08:00	0.0 FID	0.001 FI	-22.8 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.0 F	199.9 F		
03/03/25 09:00	0.0 FID	0.001 FI	-21.9 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.0 F	199.9 F		



Source Parameter Unit	UNIT_C										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/03/25 10:00	0.0 FID	0.001 FI	-22.1 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/03/25 11:00	0.0 FID	0.001 FI	-22.3 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/03/25 12:00	0.0 FID	0.001 FI	-22.0 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/03/25 13:00	0.0 FID	0.001 FI	-22.1 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/03/25 14:00	0.0 FID	0.001 FI	-21.4 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/03/25 15:00	0.0 FID	0.001 FI	-21.8 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/03/25 16:00	0.0 FID	0.001 FI	-21.6 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/03/25 17:00	0.0 FID	0.001 FI	-21.1 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/03/25 18:00	0.0 FID	0.001 FI	-20.5 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/03/25 19:00	0.0 FID	0.001 FI	-20.5 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/03/25 20:00	0.0 FID	0.001 FI	-20.4 FI	0.0 F	0.0 F	0.0 FI	0.2 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/03/25 21:00	50.3 U	0.164 E	72.9 E	0.0	0.0	0.0	84.8 EU	0.138 E	37.3 E	16.5	199.9
03/03/25 22:00	14.1 U	0.016	7.1	0.0	0.0	0.0	14.6 U	0.016	4.4	15.0	199.9
03/03/25 23:00	13.7	0.015	6.8	0.0	0.0	0.0	14.2	0.016	4.3	15.0	199.9
03/04/25 00:00	19.6	0.024	10.6	0.0	0.0	0.0	14.4	0.017	4.6	14.9	199.9
03/04/25 01:00	17.7	0.022	9.6	0.0	0.0	0.0	13.2	0.016	4.3	15.0	199.9
03/04/25 02:00	23.3	0.030	13.2	0.0	0.0	0.0	12.2	0.015	4.2	15.0	199.9
03/04/25 03:00	20.7	0.026	11.6	0.0	0.0	0.0	12.5	0.016	4.3	15.0	199.9
03/04/25 04:00	12.7	0.015	6.4	0.0	0.0	0.0	14.2	0.016	4.3	15.0	199.9
03/04/25 05:00	19.2	0.022	9.6	0.0	0.0	0.0	14.2	0.016	4.4	15.1	199.9
03/04/25 06:00	15.9 D	0.018	8.0	0.0	0.0	0.0	14.3 D	0.016	4.4	15.0	199.9
03/04/25 07:00	102.7 ECD	0.317 E	142.5 E	0.0	0.0	0.0 C	47.7 ECD	0.130 E	35.5 E	17.1 C	199.9
03/04/25 08:00	0.0 FID	0.001 FI	-27.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F
03/04/25 09:00	0.0 FID	0.001 FI	-25.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
03/04/25 10:00	0.0 FID	0.001 FI	-28.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
03/04/25 11:00	0.0 FID	0.001 FI	-27.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
03/04/25 12:00	0.0 FID	0.001 FI	-27.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/04/25 13:00	0.0 FID	0.001 FI	-27.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
03/04/25 14:00	0.0 FID	0.001 FI	-28.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/04/25 15:00	0.0 FID	0.001 FI	-26.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/04/25 16:00	0.0 FID	0.001 FI	-25.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
03/04/25 17:00	0.0 FID	0.001 FI	-23.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/04/25 18:00	0.0 FID	0.001 FI	-22.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/04/25 19:00	0.0 FID	0.001 FI	-23.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/04/25 20:00	0.0 FID	0.001 FI	-24.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/04/25 21:00	0.0 FID	0.001 FI	-22.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/04/25 22:00	0.0 FID	0.001 FI	-23.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F

UNIT START UP

UNIT SHUTDOWN



Source Parameter Unit	UNIT_C											
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)	
03/04/25 23:00	0.0 FID	0.001 FI	-24.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F	
03/05/25 00:00	0.0 FID	0.001 FI	-24.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F	
03/05/25 01:00	0.0 FID	0.001 FI	-24.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F	
03/05/25 02:00	45.1 U	0.178 E	78.7 E	0.0	0.0	0.0	65.1 EU	0.098 E	26.4 E	16.5	199.9	
03/05/25 03:00	6.1 U	0.007	3.0	0.0	0.0	0.0	15.0 U	0.016	4.4	14.9	199.9	
03/05/25 04:00	5.2	0.006	2.5	0.0	0.0	0.0	14.9	0.016	4.4	14.8	199.9	
03/05/25 05:00	5.5	0.006	2.6	0.0	0.0	0.0	15.0	0.016	4.3	14.8	199.9	
03/05/25 06:00	11.7	0.013	5.9	0.0	0.0	0.0	14.3	0.016	4.4	15.1	199.9	
03/05/25 07:00	8.1 CD	0.008	3.4	0.0	0.0	0.0 C	14.4 CD	0.016	4.4	14.9 C	199.9	
03/05/25 08:00	92.0 ED	0.274 E	122.8 E	0.0	0.0	0.0	42.8 ED	0.115 E	31.2 E	16.9	199.8	
03/05/25 09:00	0.0 FID	0.001 FI	-27.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.7 FI	21.0 F	199.9 F	
03/05/25 10:00	0.0 FID	0.001 FI	-28.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	21.0 F	199.9 F	
03/05/25 11:00	0.0 FID	0.001 FI	-26.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	21.0 F	199.9 F	
03/05/25 12:00	0.0 FID	0.001 FI	-26.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	21.0 F	199.9 F	
03/05/25 13:00	0.0 FID	0.001 FI	-25.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.8 F	
03/05/25 14:00	0.0 FID	0.001 FI	-27.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.9 F	
03/05/25 15:00	0.0 FID	0.001 FI	-26.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	21.0 F	199.9 F	
03/05/25 16:00	0.0 FID	0.001 FI	-24.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	21.0 F	199.9 F	
03/05/25 17:00	0.0 FID	0.001 FI	-25.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.9 F	
03/05/25 18:00	0.0 FID	0.001 FI	-23.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	21.0 F	199.9 F	
03/05/25 19:00	0.0 FID	0.001 FI	-26.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.9 F	
03/05/25 20:00	0.0 FID	0.001 FI	-25.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	21.0 F	199.9 F	
03/05/25 21:00	47.3 U	0.141 E	62.3 E	0.0	0.0	0.0	79.1 EU	0.131 E	35.2 E	16.4	199.9	
03/05/25 22:00	19.5 U	0.023	10.2	0.0	0.0	0.0	14.0 U	0.016	4.4	15.1	199.9	
03/05/25 23:00	21.3 D	0.025	11.2	0.0	0.0	0.0	13.9 D	0.016	4.5	15.2	199.9	
03/06/25 00:00	101.7 ED	0.348 E	155.0 E	0.0	0.0	0.0	38.7 ED	0.112 E	30.5 E	17.2	199.8	
03/06/25 01:00	0.0 FID	0.001 FI	-29.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	21.0 F	199.9 F	
03/06/25 02:00	0.0 FID	0.001 FI	-28.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.1 FI	21.0 F	199.9 F	
03/06/25 03:00	0.0 FID	0.001 FI	-27.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.9 F	
03/06/25 04:00	0.0 FID	0.001 FI	-27.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	21.0 F	199.9 F	
03/06/25 05:00	0.0 FID	0.001 FI	-27.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.9 F	
03/06/25 06:00	0.0 FID	0.001 FI	-27.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.9 F	
03/06/25 07:00	0.0 FIC	0.013 FI	5.9 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.4 F	14.2 FC	199.9 F	
03/06/25 08:00	0.0 FID	0.001 FI	-46.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	21.0 F	199.9 F	
03/06/25 09:00	0.0 FID	0.001 FI	-45.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	21.0 F	199.9 F	
03/06/25 10:00	0.0 FID	0.001 FI	-48.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.0 FI	21.0 F	199.9 F	
03/06/25 11:00	0.0 FID	0.001 FI	-48.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.9 F	

UNIT START UP

UNIT SHUTDOWN

UNIT START UP

UNIT SHUTDOWN

Source Parameter Unit	UNIT_C											
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)	
03/06/25 12:00	0.0 FID	0.001 FI	-47.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.0 FI	21.0 F	199.9 F	
03/06/25 13:00	0.0 FID	0.001 FI	-47.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.8 F	
03/06/25 14:00	0.0 FID	0.001 FI	-46.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	21.0 F	199.9 F	
03/06/25 15:00	0.0 FID	0.001 FI	-44.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.0 FI	21.0 F	199.9 F	
03/06/25 16:00	0.0 FID	0.001 FI	-43.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	21.0 F	199.9 F	
03/06/25 17:00	0.0 FID	0.001 FI	-44.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.0 FI	21.0 F	199.9 F	
03/06/25 18:00	0.0 FID	0.001 FI	-42.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.9 F	
03/06/25 19:00	0.0 FID	0.001 FI	-40.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.9 F	
03/06/25 20:00	0.0 FID	0.001 FI	-42.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.9 F	
03/06/25 21:00	51.6 U	0.159 E	71.4 E	0.0	0.0	0.0	79.5 EU	0.130 E	35.5 E	16.4	199.9	
03/06/25 22:00	17.8 U	0.022	9.6	0.0	0.0	0.0	13.4 U	0.016	4.4	15.1	199.9	
03/06/25 23:00	24.0	0.031	13.6	0.0	0.0	0.0	12.2	0.015	4.2	15.0	199.9	
03/07/25 00:00	23.4	0.030	13.3	0.0	0.0	0.0	12.0	0.015	4.2	15.0	199.9	
03/07/25 01:00	19.4	0.025	11.0	0.0	0.0	0.0	12.4	0.016	4.3	15.0	199.9	
03/07/25 02:00	16.9	0.022	9.6	0.0	0.0	0.0	12.2	0.016	4.3	15.0	199.9	
03/07/25 03:00	19.6	0.025	11.1	0.0	0.0	0.0	12.5	0.016	4.4	15.0	199.9	
03/07/25 04:00	14.8	0.017	7.7	0.0	0.0	0.0	14.0	0.016	4.4	15.0	199.9	
03/07/25 05:00	15.9	0.018	8.1	0.0	0.0	0.0	14.3	0.016	4.4	15.0	199.9	
03/07/25 06:00	7.8 D	0.009	3.8	0.0	0.0	0.0	14.5 D	0.016	4.3	14.9	199.9	
03/07/25 07:00	7.9 CD	0.030	13.4	0.0	0.0	0.0 C	15.9 CD	0.017	4.7	14.8 C	199.9	
03/07/25 08:00	0.0 FID	0.001 FI	-30.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.9 F	
03/07/25 09:00	0.0 FID	0.001 FI	-29.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F	
03/07/25 10:00	0.0 FID	0.001 FI	-28.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F	
03/07/25 11:00	0.0 FID	0.001 FI	-29.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F	
03/07/25 12:00	0.0 FID	0.001 FI	-28.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F	
03/07/25 13:00	0.0 FID	0.001 FI	-29.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F	
03/07/25 14:00	0.0 FID	0.001 FI	-28.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.9 F	
03/07/25 15:00	0.0 FID	0.001 FI	-28.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F	
03/07/25 16:00	0.0 FID	0.001 FI	-27.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F	
03/07/25 17:00	0.0 FID	0.001 FI	-27.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F	
03/07/25 18:00	0.0 FID	0.001 FI	-25.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F	
03/07/25 19:00	0.0 FID	0.001 FI	-24.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F	
03/07/25 20:00	0.0 FID	0.001 FI	-24.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F	
03/07/25 21:00	0.4 FID	0.001 FI	-23.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F	
03/07/25 22:00	0.0 FID	0.001 FI	-23.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F	
03/07/25 23:00	0.0 FID	0.001 FI	-21.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F	
03/08/25 00:00	0.0 FID	0.001 FI	-21.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F	

UNIT START UP

UNIT SHUTDOWN



Source		UNIT_C										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/08/25	01:00	0.0 FID	0.001 FI	-20.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
03/08/25	02:00	0.0 FID	0.001 FI	-19.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/08/25	03:00	0.0 FID	0.001 FI	-19.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/08/25	04:00	0.0 FID	0.001 FI	-19.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/08/25	05:00	0.0 FID	0.001 FI	-19.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
03/08/25	06:00	0.0 FID	0.001 FI	-19.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/08/25	07:00	0.0 FIC	0.012 FI	5.2 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.9 F
03/08/25	08:00	0.0 FID	0.001 FI	45.1 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
03/08/25	09:00	0.0 FID	0.026 FI	21.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
03/08/25	10:00	0.0 FID	0.026 FI	18.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
03/08/25	11:00	0.0 FID	0.026 FI	17.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
03/08/25	12:00	0.0 FID	0.026 FI	17.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
03/08/25	13:00	0.0 FID	0.026 FI	17.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
03/08/25	14:00	0.0 FID	0.026 FI	17.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
03/08/25	15:00	0.0 FID	0.026 FI	18.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
03/08/25	16:00	0.0 FID	0.026 FI	20.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.8 F	199.9 F
03/08/25	17:00	0.0 FID	0.001 FI	29.4 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
03/08/25	18:00	0.0 FID	0.001 FI	139.0 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
03/08/25	19:00	0.0 FID	0.001 FI	239.8 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
03/08/25	20:00	0.0 FID	0.001 FI	259.9 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
03/08/25	21:00	0.0 FID	0.001 FI	262.6 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
03/08/25	22:00	0.0 FID	0.001 FI	273.4 FIE	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
03/08/25	23:00	0.0 FID	0.001 FI	-434.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
03/09/25	00:00	0.0 FID	0.001 FI	-6,036.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
03/09/25	01:00	0.0 FID	0.001 FI	-448.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.3 FI	20.9 F	199.9 F
03/09/25	02:00	0.0 FID	0.001 FI	-303.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
03/09/25	03:00	0.0 FID	0.001 FI	-224.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
03/09/25	04:00	0.0 FID	0.001 FI	-151.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	20.9 F	199.9 F
03/09/25	05:00	0.0 FID	0.001 FI	-183.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	20.9 F	199.9 F
03/09/25	06:00	0.0 FID	0.001 FI	-158.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	20.9 F	199.9 F
03/09/25	07:00	0.0 FIC	0.013 FI	5.7 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.024 F	6.4 F	14.2 FC	199.9 F
03/09/25	08:00	0.0 FID	0.001 FI	42.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.9 F	199.9 F
03/09/25	09:00	0.0 FID	0.026 FI	17.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.9 F
03/09/25	10:00	0.0 FID	0.026 FI	14.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.9 F
03/09/25	11:00	0.0 FID	0.028 FI	15.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.9 F
03/09/25	12:00	0.0 FID	0.026 FI	17.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.9 F
03/09/25	13:00	0.0 FID	0.001 FI	26.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.9 F	199.9 F

Source Parameter Unit	UNIT_C											
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)	
03/09/25 14:00	0.0 FID	0.001 FI	27.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.9 F	199.9 F	
03/09/25 15:00	0.0 FID	0.001 FI	34.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.9 F	199.9 F	
03/09/25 16:00	0.0 FID	0.001 FI	54.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.0 FI	20.9 F	199.9 F	
03/09/25 17:00	0.0 FID	0.001 FI	102.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.9 F	199.9 F	
03/09/25 18:00	0.0 FID	0.001 FI	76.6 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.9 F	199.9 F	
03/09/25 19:00	0.0 FID	0.001 FI	158.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.0 FI	20.9 F	199.9 F	
03/09/25 20:00	0.0 FID	0.001 FI	140.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.5 FI	20.9 F	199.9 F	
03/09/25 21:00	0.0 FID	0.001 FI	97.7 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.9 F	199.9 F	
03/09/25 22:00	0.0 FID	0.001 FI	68.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.9 F	199.9 F	
03/09/25 23:00	0.0 FID	0.001 FI	59.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.9 F	199.9 F	
03/10/25 00:00	0.0 FID	0.001 FI	56.4 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.9 F	199.9 F	
03/10/25 01:00	0.0 FID	0.001 FI	49.9 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.6 FI	20.9 F	199.9 F	
03/10/25 02:00	0.0 FID	0.001 FI	50.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.9 F	199.9 F	
03/10/25 03:00	0.0 FID	0.001 FI	61.0 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.7 FI	20.9 F	199.9 F	
03/10/25 04:00	0.0 FID	0.001 FI	51.5 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.8 FI	20.9 F	199.9 F	
03/10/25 05:00	36.1 U	0.091 E	40.4 E	0.0	0.0	0.0	83.5 EU	0.126 E	34.1 E	15.8	199.9	
03/10/25 06:00	14.4 CUD	0.014	6.1	0.0	0.0	0.0 C	13.8 CUD	0.015	4.2	15.0 C	199.9	
03/10/25 07:00	96.1 ED	0.299 E	132.5 E	0.0	0.0	0.0	45.1 ED	0.125 E	33.8 E	17.1	199.9	
03/10/25 08:00	0.0 FID	0.001 FI	-18.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F	
03/10/25 09:00	0.0 FID	0.001 FI	-16.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F	
03/10/25 10:00	0.0 FID	0.001 FI	-16.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F	
03/10/25 11:00	0.0 FID	0.001 FI	-17.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F	
03/10/25 12:00	0.0 FID	0.001 FI	-17.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F	
03/10/25 13:00	0.0 FID	0.001 FI	-17.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F	
03/10/25 14:00	0.0 FID	0.001 FI	-16.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F	
03/10/25 15:00	0.0 FID	0.001 FI	-15.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.9 F	
03/10/25 16:00	0.0 FID	0.001 FI	-16.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F	
03/10/25 17:00	0.0 FID	0.001 FI	-15.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F	
03/10/25 18:00	0.0 FID	0.001 FI	-14.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F	
03/10/25 19:00	0.0 FID	0.001 FI	-14.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F	
03/10/25 20:00	48.2 U	0.137 E	61.0 E	0.0	0.0	0.0	85.3 EU	0.136 E	36.9 E	16.3	199.9	
03/10/25 21:00	23.8 U	0.029	12.8	0.0	0.0	0.0	13.3 U	0.016	4.3	15.3	199.9	
03/10/25 22:00	22.7	0.028	12.4	0.0	0.0	0.0	13.9	0.017	4.5	15.3	199.9	
03/10/25 23:00	22.5	0.026	11.8	0.0	0.0	0.0	13.9	0.016	4.5	15.2	199.9	
03/11/25 00:00	13.9	0.016	7.3	0.0	0.0	0.0	14.6	0.017	4.6	15.1	199.9	
03/11/25 01:00	19.4	0.023	10.4	0.0	0.0	0.0	13.9	0.017	4.5	15.2	199.9	
03/11/25 02:00	20.4	0.025	11.0	0.0	0.0	0.0	13.8	0.016	4.5	15.2	199.9	

UNIT START UP

UNIT SHUTDOWN

UNIT START UP



Source Parameter Unit		UNIT_C										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/11/25	03:00	23.4	0.029	12.7	0.0	0.0	0.0	13.5	0.016	4.5	15.2	199.9
03/11/25	04:00	20.8	0.025	11.2	0.0	0.0	0.0	13.8	0.016	4.5	15.2	199.9
03/11/25	05:00	16.5	0.019	8.6	0.0	0.0	0.0	14.0	0.016	4.4	15.1	199.9
03/11/25	06:00	13.8 CD	0.013	5.6	0.0	0.0	0.0 C	13.5 CD	0.015	4.2	15.0 C	199.9
03/11/25	07:00	99.7 ED	0.313 E	140.8 E	0.0	0.0	0.0	40.5 ED	0.114 E	31.1 E	17.0	199.9
03/11/25	08:00	0.0 FID	0.001 FI	-28.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/11/25	09:00	0.0 FID	0.001 FI	-29.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.9 F
03/11/25	10:00	0.0 FID	0.001 FI	-27.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
03/11/25	11:00	0.0 FID	0.001 FI	-27.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
03/11/25	12:00	0.0 FID	0.001 FI	-28.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/11/25	13:00	0.0 FID	0.001 FI	-27.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/11/25	14:00	0.0 FID	0.001 FI	-26.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/11/25	15:00	0.0 FID	0.001 FI	-26.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/11/25	16:00	0.0 FID	0.001 FI	-24.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
03/11/25	17:00	0.0 FID	0.001 FI	-25.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
03/11/25	18:00	0.0 FID	0.001 FI	-24.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
03/11/25	19:00	0.0 FID	0.001 FI	-25.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
03/11/25	20:00	0.0 FID	0.001 FI	-24.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
03/11/25	21:00	0.0 FID	0.001 FI	-24.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
03/11/25	22:00	0.0 FID	0.001 FI	-24.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
03/11/25	23:00	0.0 FID	0.001 FI	-25.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.8 F
03/12/25	00:00	0.0 FID	0.001 FI	-24.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
03/12/25	01:00	0.0 FID	0.001 FI	-24.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
03/12/25	02:00	0.0 FID	0.001 FI	-25.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
03/12/25	03:00	0.0 FID	0.001 FI	-25.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
03/12/25	04:00	0.0 FID	0.001 FI	-25.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/12/25	05:00	0.0 FID	0.001 FI	-25.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/12/25	06:00	0.0 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.024 F	6.4 F	14.2 FC	199.9 F
03/12/25	07:00	0.0 FID	0.001 FI	-22.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/12/25	08:00	0.0 FID	0.001 FI	-22.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/12/25	09:00	0.0 FID	0.001 FI	-21.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/12/25	10:00	0.0 FID	0.001 FI	-22.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/12/25	11:00	0.0 FID	0.001 FI	-22.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/12/25	12:00	0.0 FID	0.001 FI	-22.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/12/25	13:00	0.0 FID	0.001 FI	-22.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
03/12/25	14:00	0.0 FID	0.001 FI	-23.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/12/25	15:00	0.0 FID	0.001 FI	-20.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F

UNIT SHUTDOWN

Source		UNIT_C										
Parameter Unit		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/12/25	16:00	0.0 FID	0.001 FI	-20.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/12/25	17:00	0.0 FID	0.001 FI	-21.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/12/25	18:00	0.0 FID	0.001 FI	-20.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/12/25	19:00	0.0 FID	0.001 FI	-20.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/12/25	20:00	0.0 FID	0.001 FI	-20.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/12/25	21:00	0.0 FID	0.001 FI	-20.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/12/25	22:00	0.0 FID	0.001 FI	-22.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/12/25	23:00	0.0 FID	0.001 FI	-22.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/13/25	00:00	0.0 FID	0.001 FI	-22.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/13/25	01:00	0.0 FID	0.001 FI	-23.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/13/25	02:00	0.0 FID	0.001 FI	-22.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/13/25	03:00	0.0 FID	0.001 FI	-22.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/13/25	04:00	0.0 FID	0.001 FI	-21.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/13/25	05:00	0.0 FID	0.001 FI	-21.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/13/25	06:00	0.0 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.4 F	14.2 FC	199.8 F
03/13/25	07:00	0.0 FID	0.001 FI	-24.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.7 FI	21.0 F	199.8 F
03/13/25	08:00	0.0 FID	0.001 FI	-24.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	21.0 F	199.8 F
03/13/25	09:00	0.0 FID	0.001 FI	-25.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	21.0 F	199.9 F
03/13/25	10:00	0.0 FID	0.001 FI	-26.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	21.0 F	199.8 F
03/13/25	11:00	0.0 FID	0.001 FI	-26.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.0 FI	21.0 F	199.8 F
03/13/25	12:00	0.0 FID	0.001 FI	-26.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	21.0 F	199.8 F
03/13/25	13:00	0.0 FID	0.001 FI	-28.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.9 F
03/13/25	14:00	0.0 FID	0.001 FI	-27.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.9 F
03/13/25	15:00	0.0 FID	0.001 FI	-26.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.9 F
03/13/25	16:00	0.0 FID	0.001 FI	-26.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.9 F
03/13/25	17:00	0.0 FID	0.001 FI	-25.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	21.0 F	199.8 F
03/13/25	18:00	0.0 FID	0.001 FI	-24.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	21.0 F	199.9 F
03/13/25	19:00	0.0 FID	0.001 FI	-25.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.0 FI	21.0 F	199.9 F
03/13/25	20:00	0.0 FID	0.001 FI	-24.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.9 F
03/13/25	21:00	0.0 FID	0.001 FI	-24.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	21.0 F	199.9 F
03/13/25	22:00	0.0 FID	0.001 FI	-23.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	21.0 F	199.9 F
03/13/25	23:00	0.0 FID	0.001 FI	-22.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	21.0 F	199.9 F
03/14/25	00:00	0.0 FID	0.001 FI	-20.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.0 FI	21.0 F	199.9 F
03/14/25	01:00	0.0 FID	0.001 FI	-20.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	21.0 F	199.9 F
03/14/25	02:00	0.0 FID	0.001 FI	-20.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.9 F
03/14/25	03:00	0.0 FID	0.001 FI	-20.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	21.0 F	199.9 F
03/14/25	04:00	0.0 FID	0.001 FI	-20.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	21.0 F	199.9 F

Source		UNIT_C										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/14/25	05:00	0.0 FID	0.001 FI	-20.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.9 F
03/14/25	06:00	0.0 FIC	0.013 FI	5.9 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.9 F
03/14/25	07:00	0.0 FID	0.001 FI	50.3 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.9 F	199.9 F
03/14/25	08:00	0.0 FID	0.001 FI	44.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.5 FI	20.9 F	199.9 F
03/14/25	09:00	0.0 FID	0.001 FI	34.2 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.9 F	199.9 F
03/14/25	10:00	0.0 FID	0.040 FI	24.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.9 F
03/14/25	11:00	0.0 FID	0.026 FI	20.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.8 F
03/14/25	12:00	0.0 FID	0.026 FI	19.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.8 F
03/14/25	13:00	0.0 FID	0.026 FI	17.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.8 F
03/14/25	14:00	0.0 FID	0.026 FI	17.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.8 F
03/14/25	15:00	0.0 FID	0.026 FI	18.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.8 F
03/14/25	16:00	0.0 FID	0.026 FI	17.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.8 F
03/14/25	17:00	0.0 FID	0.026 FI	17.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.9 F
03/14/25	18:00	0.0 FID	0.026 FI	18.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.9 F
03/14/25	19:00	0.0 FID	0.026 FI	18.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.1 FI	20.8 F	199.8 F
03/14/25	20:00	49.0 U	0.147 E	66.0 E	0.0	0.0	0.0	83.4 EU	0.134 E	36.6 E	16.2	199.9
03/14/25	21:00	16.3 U	0.020	8.7	0.0	0.0	0.0	13.8 U	0.017	4.5	15.0	199.9
03/14/25	22:00	18.9	0.024	10.5	0.0	0.0	0.0	12.7	0.016	4.3	15.0	199.9
03/14/25	23:00	20.0	0.026	11.3	0.0	0.0	0.0	12.8	0.016	4.4	15.0	199.9
03/15/25	00:00	17.9	0.023	10.2	0.0	0.0	0.0	12.5	0.016	4.3	14.9	199.9
03/15/25	01:00	20.3	0.026	11.5	0.0	0.0	0.0	12.7	0.016	4.4	14.9	199.9
03/15/25	02:00	16.7	0.021	9.5	0.0	0.0	0.0	12.6	0.016	4.3	14.9	199.9
03/15/25	03:00	17.9	0.023	10.1	0.0	0.0	0.0	12.6	0.016	4.3	14.9	199.9
03/15/25	04:00	19.7	0.025	11.1	0.0	0.0	0.0	12.7	0.016	4.3	14.9	199.9
03/15/25	05:00	21.1 D	0.027	11.9	0.0	0.0	0.0	12.9 D	0.016	4.4	14.9	199.9
03/15/25	06:00	17.6 CD	0.024	10.7	0.0	0.0	0.0 C	12.6 CD	0.016	4.3	14.9 C	199.9
03/15/25	07:00	0.0 FID	0.001 FI	-18.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/15/25	08:00	0.0 FID	0.001 FI	-17.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/15/25	09:00	0.0 FID	0.001 FI	-17.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/15/25	10:00	0.0 FID	0.001 FI	-17.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/15/25	11:00	0.0 FID	0.001 FI	-18.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/15/25	12:00	0.0 FID	0.001 FI	-18.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/15/25	13:00	0.0 FID	0.001 FI	-17.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/15/25	14:00	0.0 FID	0.001 FI	-18.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/15/25	15:00	0.0 FID	0.001 FI	-17.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/15/25	16:00	0.0 FID	0.001 FI	-17.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/15/25	17:00	0.0 FID	0.001 FI	-16.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F

UNIT START UP

UNIT SHUTDOWN

Source	Parameter Unit	UNIT_C										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/15/25	18:00	0.0 FID	0.001 FI	-15.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/15/25	19:00	0.0 FID	0.001 FI	-15.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/15/25	20:00	0.0 FID	0.001 FI	-15.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/15/25	21:00	0.0 FID	0.001 FI	-15.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/15/25	22:00	0.0 FID	0.001 FI	-16.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/15/25	23:00	0.0 FID	0.001 FI	-15.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/16/25	00:00	0.0 FID	0.001 FI	-16.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/16/25	01:00	0.0 FID	0.001 FI	-16.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/16/25	02:00	0.0 FID	0.001 FI	-16.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/16/25	03:00	0.0 FID	0.001 FI	-16.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/16/25	04:00	0.0 FID	0.001 FI	-15.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/16/25	05:00	0.0 FID	0.001 FI	-15.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/16/25	06:00	0.0 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.3 F	14.2 FC	199.9 F
03/16/25	07:00	0.0 FID	0.001 FI	-78.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	20.9 F	199.9 F
03/16/25	08:00	0.0 FID	0.001 FI	-84.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	20.9 F	199.9 F
03/16/25	09:00	0.0 FID	0.001 FI	-88.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	20.9 F	199.9 F
03/16/25	10:00	0.0 FID	0.001 FI	-81.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	20.9 F	199.9 F
03/16/25	11:00	0.0 FID	0.001 FI	-102.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	20.9 F	199.9 F
03/16/25	12:00	0.0 FID	0.001 FI	-95.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	20.9 F	199.8 F
03/16/25	13:00	0.0 FID	0.001 FI	-88.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.6 FI	20.9 F	199.8 F
03/16/25	14:00	0.0 FID	0.001 FI	-80.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.4 FI	20.9 F	199.8 F
03/16/25	15:00	0.0 FID	0.001 FI	-85.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	20.9 F	199.9 F
03/16/25	16:00	0.0 FID	0.001 FI	-83.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	20.9 F	199.8 F
03/16/25	17:00	0.0 FID	0.001 FI	-80.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	20.9 F	199.9 F
03/16/25	18:00	0.0 FID	0.001 FI	-79.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	20.9 F	199.8 F
03/16/25	19:00	0.0 FID	0.001 FI	-75.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.2 FI	20.9 F	199.9 F
03/16/25	20:00	80.0 EU	0.409 E	183.3 E	0.0	0.0	0.0	39.5 EU	0.114 E	31.1 E	17.8	199.9
03/16/25	21:00	19.2 U	0.024	10.8	0.0	0.0	0.0	38.5 EU	0.049 E	13.2 E	15.2	199.9
03/16/25	22:00	19.9	0.025	11.2	0.0	0.0	0.0	12.6	0.016	4.4	15.1	199.9
03/16/25	23:00	18.9	0.023	10.1	0.0	0.0	0.0	13.8	0.017	4.5	15.2	199.9
03/17/25	00:00	17.1	0.022	9.7	0.0	0.0	0.0	12.5	0.016	4.3	15.1	199.9
03/17/25	01:00	17.0	0.022	9.7	0.0	0.0	0.0	12.4	0.016	4.3	15.0	199.9
03/17/25	02:00	18.5	0.024	10.5	0.0	0.0	0.0	12.6	0.016	4.4	15.0	199.9
03/17/25	03:00	18.4	0.023	10.4	0.0	0.0	0.0	12.6	0.016	4.4	15.0	199.9
03/17/25	04:00	18.6	0.022	9.9	0.0	0.0	0.0	13.4	0.016	4.3	15.1	199.9
03/17/25	05:00	20.0 D	0.024	10.7	0.0	0.0	0.0	13.3 D	0.018	4.4	15.2	199.9
03/17/25	06:00	98.2 ECD	0.321 E	141.8 E	0.0	0.0	0.0 C	41.7 ECD	0.120 E	32.1 E	17.1 C	199.9

UNIT START UP

UNIT SHUTDOWN



Source Parameter Unit	UNIT_C										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/17/25 07:00	0.0 FID	0.001 FI	-29.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
03/17/25 08:00	0.0 FID	0.001 FI	-27.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
03/17/25 09:00	0.0 FID	0.001 FI	-27.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/17/25 10:00	0.0 FID	0.001 FI	-26.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
03/17/25 11:00	0.0 FID	0.001 FI	-27.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
03/17/25 12:00	0.0 FID	0.001 FI	-28.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/17/25 13:00	0.0 FID	0.001 FI	-28.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/17/25 14:00	0.0 FID	0.001 FI	-30.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/17/25 15:00	0.0 FID	0.001 FI	-29.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/17/25 16:00	0.0 FID	0.001 FI	-28.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/17/25 17:00	0.0 FID	0.001 FI	-30.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/17/25 18:00	0.0 FID	0.001 FI	-31.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/17/25 19:00	0.0 FID	0.001 FI	-33.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/17/25 20:00	0.0 FID	0.001 FI	-33.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/17/25 21:00	0.0 FID	0.001 FI	-33.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/17/25 22:00	0.0 FID	0.001 FI	-30.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/17/25 23:00	0.0 FID	0.001 FI	-31.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/18/25 00:00	0.0 FID	0.001 FI	-29.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/18/25 01:00	0.0 FID	0.001 FI	-27.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/18/25 02:00	0.0 FID	0.001 FI	-28.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/18/25 03:00	0.0 FID	0.001 FI	-27.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/18/25 04:00	0.0 FID	0.001 FI	-28.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/18/25 05:00	0.0 FID	0.001 FI	-27.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/18/25 06:00	0.0 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.4 F	14.2 FC	199.9 F
03/18/25 07:00	0.0 FID	0.001 FI	-45.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	21.0 F	199.9 F
03/18/25 08:00	0.0 FID	0.001 FI	-42.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	21.0 F	199.9 F
03/18/25 09:00	0.0 FID	0.001 FI	-46.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.7 FI	20.9 F	199.9 F
03/18/25 10:00	0.0 FID	0.001 FI	-44.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	20.9 F	199.9 F
03/18/25 11:00	0.0 FID	0.001 FI	-45.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.9 F
03/18/25 12:00	0.0 FID	0.001 FI	-48.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	20.9 F	199.9 F
03/18/25 13:00	0.0 FID	0.001 FI	-47.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.0 FI	20.9 F	199.9 F
03/18/25 14:00	0.0 FID	0.001 FI	-48.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.0 FI	20.9 F	199.9 F
03/18/25 15:00	0.0 FID	0.001 FI	-48.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	20.9 F	199.9 F
03/18/25 16:00	0.0 FID	0.001 FI	-49.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	20.9 F	199.9 F
03/18/25 17:00	0.0 FID	0.001 FI	-42.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.9 F
03/18/25 18:00	0.0 FID	0.001 FI	-42.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.0 FI	21.0 F	199.9 F
03/18/25 19:00	0.0 FID	0.001 FI	-40.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.9 F

Source Parameter Unit		UNIT_C										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/18/25	20:00	0.0 FID	0.001 FI	-39.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.9 F
03/18/25	21:00	0.0 FID	0.001 FI	-39.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.9 F
03/18/25	22:00	0.0 FID	0.001 FI	-43.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	21.0 F	199.9 F
03/18/25	23:00	0.0 FID	0.001 FI	-40.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.0 FI	21.0 F	199.9 F
03/19/25	00:00	0.0 FID	0.001 FI	-44.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.9 FI	20.9 F	199.9 F
03/19/25	01:00	0.0 FID	0.001 FI	-41.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.9 F
03/19/25	02:00	0.0 FID	0.001 FI	60.8 FIE	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	1.9 FI	20.9 F	199.9 F
03/19/25	03:00	0.0 FID	0.001 FI	-41.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.9 F
03/19/25	04:00	0.0 FID	0.001 FI	-38.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	21.0 F	199.9 F
03/19/25	05:00	0.0 FID	0.001 FI	-31.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.9 F
03/19/25	06:00	0.0 FIC	0.011 FI	5.1 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.4 F	14.1 FC	199.9 F
03/19/25	07:00	0.0 FID	0.026 FI	17.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.9 F
03/19/25	08:00	0.0 FID	0.026 FI	13.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.9 F
03/19/25	09:00	0.0 FID	0.026 FI	13.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.9 F
03/19/25	10:00	0.0 FID	0.026 FI	12.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.9 F
03/19/25	11:00	0.0 FID	0.026 FI	12.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.9 F
03/19/25	12:00	0.0 FID	0.026 FI	12.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.9 F
03/19/25	13:00	0.0 FID	0.026 FI	12.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.9 F
03/19/25	14:00	0.0 FID	0.026 FI	12.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.9 F
03/19/25	15:00	0.0 FID	0.026 FI	12.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.9 F
03/19/25	16:00	0.0 FID	0.026 FI	12.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.9 F
03/19/25	17:00	0.0 FID	0.026 FI	11.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.8 F
03/19/25	18:00	0.0 FID	0.026 FI	12.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.8 F
03/19/25	19:00	0.0 FID	0.026 FI	11.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.9 F
03/19/25	20:00	0.0 FID	0.026 FI	12.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.8 F	199.9 F
03/19/25	21:00	0.0 FID	0.026 FI	11.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.8 F	199.9 F
03/19/25	22:00	0.0 FID	0.026 FI	11.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.9 F
03/19/25	23:00	0.0 FID	0.026 FI	12.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.3 FI	20.8 F	199.9 F
03/20/25	00:00	0.0 FID	0.026 FI	11.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.4 FI	20.8 F	199.9 F
03/20/25	01:00	0.0 FID	0.026 FI	11.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.2 FI	20.8 F	199.9 F
03/20/25	02:00	38.8 U	0.119 E	52.7 E	0.0	0.0	0.0	89.0 EU	0.137 E	36.7 E	16.1	199.9
03/20/25	03:00	18.3 U	0.023	10.1	0.0	0.0	0.0	12.8 U	0.016	4.3	15.0	199.9
03/20/25	04:00	23.4	0.029	13.2	0.0	0.0	0.0	12.2	0.015	4.2	14.9	199.9
03/20/25	05:00	18.1 D	0.023	10.3	0.0	0.0	0.0	12.4 D	0.016	4.2	14.9	199.9
03/20/25	06:00	23.8 CD	0.036	15.8	0.0	0.0	0.0 C	13.5 CD	0.016	4.4	15.0 C	199.9
03/20/25	07:00	0.0 FID	0.001 FI	-23.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F
03/20/25	08:00	0.0 FID	0.001 FI	-21.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F

UNIT START UP

UNIT SHUTDOWN

Source Parameter Unit	UNIT_C										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/20/25 09:00	0.0 FID	0.001 FI	-21.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/20/25 10:00	0.0 FID	0.001 FI	-20.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/20/25 11:00	0.0 FID	0.001 FI	-21.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
03/20/25 12:00	0.0 FID	0.001 FI	-21.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/20/25 13:00	0.0 FID	0.001 FI	-22.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/20/25 14:00	0.0 FID	0.001 FI	-22.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
03/20/25 15:00	0.0 FID	0.001 FI	-21.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/20/25 16:00	0.0 FID	0.001 FI	-20.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
03/20/25 17:00	0.0 FID	0.001 FI	-19.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
03/20/25 18:00	0.0 FID	0.001 FI	-20.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/20/25 19:00	0.0 FID	0.001 FI	-19.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/20/25 20:00	0.2 FID	0.001 FI	-19.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/20/25 21:00	0.0 FID	0.001 FI	-19.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/20/25 22:00	0.0 FID	0.001 FI	-20.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/20/25 23:00	0.0 FID	0.001 FI	-58.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	20.9 F	199.9 F
03/21/25 00:00	0.0 FID	0.001 FI	-20.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.8 F
03/21/25 01:00	0.0 FID	0.001 FI	-21.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.8 F
03/21/25 02:00	0.0 FID	0.001 FI	-21.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/21/25 03:00	0.0 FID	0.001 FI	-20.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/21/25 04:00	66.8 EU	0.346 E	153.2 E	0.0	0.0	0.0	108.8 EU	0.185 E	49.8 E	17.3	199.9
03/21/25 05:00	23.0 UD	0.029	12.7	0.0	0.0	0.0	30.3 EUD	0.036 E	9.8 E	15.1	199.9
03/21/25 06:00	101.5 ECD	0.324 E	144.6 E	0.0	0.0	0.0 C	43.4 ECD	0.110 E	30.0 E	17.2 C	199.9
03/21/25 07:00	0.0 FID	0.001 FI	-45.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.5 FI	21.0 F	199.9 F
03/21/25 08:00	0.0 FID	0.001 FI	-44.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	21.0 F	199.8 F
03/21/25 09:00	0.0 FID	0.001 FI	-40.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.2 FI	21.0 F	199.8 F
03/21/25 10:00	0.0 FID	0.001 FI	-41.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	21.0 F	199.9 F
03/21/25 11:00	0.0 FID	0.001 FI	-44.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.7 FI	21.0 F	199.9 F
03/21/25 12:00	0.0 FID	0.001 FI	-46.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	20.9 F	199.8 F
03/21/25 13:00	0.0 FID	0.001 FI	-43.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	21.0 F	199.8 F
03/21/25 14:00	0.0 FID	0.001 FI	-40.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.7 FI	21.0 F	199.8 F
03/21/25 15:00	0.0 FID	0.001 FI	-39.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.9 FI	21.0 F	199.8 F
03/21/25 16:00	0.0 FID	0.001 FI	-36.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.2 FI	21.0 F	199.9 F
03/21/25 17:00	0.0 FID	0.001 FI	-36.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	21.0 F	199.9 F
03/21/25 18:00	0.0 FID	0.001 FI	-36.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.0 FI	21.0 F	199.9 F
03/21/25 19:00	0.0 FID	0.001 FI	-37.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.1 FI	21.0 F	199.9 F
03/21/25 20:00	0.2 FID	0.001 FI	-36.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	21.0 F	199.9 F
03/21/25 21:00	0.0 FID	0.001 FI	-36.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.0 FI	21.0 F	199.9 F

UNIT START UP

UNIT SHUTDOWN

Source		UNIT_C										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/21/25	22:00	0.0 FID	0.001 FI	-38.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	21.0 F	199.9 F
03/21/25	23:00	0.0 FID	0.001 FI	-38.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	21.0 F	199.9 F
03/22/25	00:00	0.0 FID	0.001 FI	-39.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.9 F
03/22/25	01:00	0.0 FID	0.001 FI	-38.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	21.0 F	199.9 F
03/22/25	02:00	0.0 FID	0.001 FI	-38.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	21.0 F	199.9 F
03/22/25	03:00	0.0 FID	0.001 FI	-36.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	21.0 F	199.8 F
03/22/25	04:00	0.0 FID	0.001 FI	-39.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	21.0 F	199.8 F
03/22/25	05:00	0.0 FID	0.001 FI	-40.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	21.0 F	199.8 F
03/22/25	06:00	0.0 FIC	0.011 FI	5.0 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.024 F	6.4 F	14.2 FC	199.8 F
03/22/25	07:00	0.0 FID	0.001 FI	-24.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/22/25	08:00	0.0 FID	0.001 FI	-24.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/22/25	09:00	0.0 FID	0.001 FI	-25.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/22/25	10:00	0.0 FID	0.001 FI	-24.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/22/25	11:00	0.0 FID	0.001 FI	-24.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/22/25	12:00	0.0 FID	0.001 FI	-25.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/22/25	13:00	0.0 FID	0.001 FI	-25.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/22/25	14:00	0.0 FID	0.001 FI	-25.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/22/25	15:00	0.0 FID	0.001 FI	-24.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/22/25	16:00	0.0 FID	0.001 FI	-23.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/22/25	17:00	0.0 FID	0.001 FI	-22.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/22/25	18:00	0.0 FID	0.001 FI	-22.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/22/25	19:00	0.0 FID	0.001 FI	-22.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/22/25	20:00	0.3 FID	0.001 FI	-22.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/22/25	21:00	0.0 FID	0.001 FI	-23.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/22/25	22:00	0.0 FID	0.001 FI	-22.5 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/22/25	23:00	0.0 FID	0.001 FI	-23.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/23/25	00:00	58.8 EUD	0.299 E	133.5 E	0.0	0.0	0.0	121.3 EUD	0.198 E	53.8 E	17.2	199.9
03/23/25	01:00	22.2 UD	0.026	11.7	0.0	0.0	0.0	29.5 EUD	0.031 E	8.3 E	15.1	199.9
03/23/25	02:00	34.9 U	0.071 E	31.8 E	0.0	0.0	0.0	41.8 EU	0.060 E	16.2 E	15.7	199.9
03/23/25	03:00	20.6 U	0.025	11.0	0.0	0.0	0.0	13.6 U	0.016	4.4	15.2	199.9
03/23/25	04:00	17.9	0.023	9.9	0.0	0.0	0.0	13.1	0.016	4.4	15.2	199.9
03/23/25	05:00	22.0 D	0.026	11.8	0.0	0.0	0.0	13.8 D	0.016	4.5	15.2	199.9
03/23/25	06:00	100.4 ECD	0.299 E	133.4 E	0.0	0.0	0.0 C	36.8 ECD	0.099 E	26.8 E	17.0 C	199.9
03/23/25	07:00	0.0 FID	0.001 FI	-20.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.9 F
03/23/25	08:00	0.0 FID	0.001 FI	-20.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/23/25	09:00	0.0 FID	0.001 FI	-19.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/23/25	10:00	0.0 FID	0.001 FI	-20.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F

UNIT START UP
UNIT SHUTDOWN
UNIT START UP

UNIT SHUTDOWN



Source Parameter Unit		UNIT_C										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/23/25	11:00	0.0 FID	0.001 FI	-20.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.2 FI	21.0 F	199.8 F
03/23/25	12:00	0.0 FID	0.001 FI	-20.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/23/25	13:00	0.0 FID	0.001 FI	-20.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/23/25	14:00	0.0 FID	0.001 FI	-19.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/23/25	15:00	0.0 FID	0.001 FI	-20.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/23/25	16:00	0.0 FID	0.001 FI	-19.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/23/25	17:00	0.0 FID	0.001 FI	-18.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/23/25	18:00	0.0 FID	0.001 FI	-17.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/23/25	19:00	0.0 FID	0.001 FI	-17.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/23/25	20:00	0.0 FID	0.001 FI	-18.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F
03/23/25	21:00	40.9 U	0.182 E	81.0 E	0.0	0.0	0.0	55.3 EU	0.084 E	22.8 E	16.4	199.9
03/23/25	22:00	19.2 U	0.023	10.3	0.0	0.0	0.0	13.3 U	0.016	4.4	15.2	199.9
03/23/25	23:00	17.8	0.023	10.0	0.0	0.0	0.0	12.5	0.016	4.3	15.1	199.9
03/24/25	00:00	18.5	0.024	10.5	0.0	0.0	0.0	12.5	0.016	4.3	15.1	199.9
03/24/25	01:00	19.9	0.025	11.3	0.0	0.0	0.0	12.6	0.016	4.4	15.1	199.9
03/24/25	02:00	20.4	0.026	11.6	0.0	0.0	0.0	12.6	0.016	4.3	15.1	199.9
03/24/25	03:00	20.1	0.026	11.4	0.0	0.0	0.0	12.6	0.016	4.3	15.1	199.9
03/24/25	04:00	22.3	0.027	12.0	0.0	0.0	0.0	13.4	0.016	4.4	15.2	199.9
03/24/25	05:00	20.7 D	0.025	11.1	0.0	0.0	0.0	13.5 D	0.016	4.4	15.2	199.9
03/24/25	06:00	89.5 ECD	0.282 E	124.9 E	0.0	0.0	0.0 C	36.8 ECD	0.101 E	27.1 E	16.9 C	199.9
03/24/25	07:00	0.0 FID	0.001 FI	-21.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.9 FI	21.0 F	199.9 F
03/24/25	08:00	0.0 FID	0.001 FI	-20.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	21.0 F	199.9 F
03/24/25	09:00	0.0 FID	0.001 FI	-20.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.9 F
03/24/25	10:00	0.0 FID	0.001 FI	-20.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	21.0 F	199.8 F
03/24/25	11:00	0.0 FID	0.001 FI	-20.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	21.0 F	199.8 F
03/24/25	12:00	0.0 FID	0.001 FI	-20.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	21.0 F	199.8 F
03/24/25	13:00	0.0 FID	0.001 FI	-19.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.8 FI	21.0 F	199.8 F
03/24/25	14:00	0.0 FID	0.001 FI	-19.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	21.0 F	199.8 F
03/24/25	15:00	0.0 FID	0.001 FI	-18.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.7 FI	21.0 F	199.8 F
03/24/25	16:00	0.0 FID	0.001 FI	-18.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.7 FI	21.0 F	199.9 F
03/24/25	17:00	0.0 FID	0.001 FI	-18.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	21.0 F	199.9 F
03/24/25	18:00	0.0 FID	0.001 FI	-18.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	21.0 F	199.9 F
03/24/25	19:00	0.0 FID	0.001 FI	-18.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.9 F
03/24/25	20:00	0.3 FID	0.001 FI	-18.6 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-1.1 FI	21.0 F	199.9 F
03/24/25	21:00	0.0 FID	0.001 FI	-18.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	21.0 F	199.9 F
03/24/25	22:00	0.0 FID	0.001 FI	-17.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.3 FI	21.0 F	199.9 F
03/24/25	23:00	0.0 FID	0.001 FI	-18.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	21.0 F	199.9 F

UNIT START UP

UNIT SHUTDOWN

Source Parameter Unit	UNIT_C											
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)	
03/25/25 00:00	0.0 FID	0.001 FI	-18.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	21.0 F	199.9 F	
03/25/25 01:00	0.0 FID	0.001 FI	-18.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.5 FI	21.0 F	199.9 F	
03/25/25 02:00	0.0 FID	0.001 FI	-18.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	21.0 F	199.9 F	
03/25/25 03:00	0.0 FID	0.001 FI	-19.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	21.0 F	199.9 F	
03/25/25 04:00	0.0 FID	0.001 FI	-19.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	21.0 F	199.9 F	
03/25/25 05:00	0.0 FID	0.001 FI	-19.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.4 FI	21.0 F	199.9 F	
03/25/25 08:00	0.0 FIC	0.012 FI	5.2 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.4 F	14.2 FC	199.9 F	
03/25/25 07:00	0.0 FID	0.001 FI	-38.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.1 FI	21.0 F	199.9 F	
03/25/25 08:00	0.0 FID	0.001 FI	-40.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.6 FI	21.0 F	199.9 F	
03/25/25 09:00	0.0 FID	0.001 FI	-42.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.1 FI	21.0 F	199.9 F	
03/25/25 10:00	0.0 FID	0.001 FI	-40.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.3 FI	21.0 F	199.9 F	
03/25/25 11:00	0.0 FID	0.001 FI	-41.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.4 FI	21.0 F	199.9 F	
03/25/25 12:00	0.0 FID	0.001 FI	-39.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.2 FI	21.0 F	199.9 F	
03/25/25 13:00	0.0 FID	0.001 FI	-40.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.2 FI	21.0 F	199.9 F	
03/25/25 14:00	0.0 FID	0.001 FI	-36.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.4 FI	21.0 F	199.9 F	
03/25/25 15:00	0.0 FID	0.001 FI	-37.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.0 FI	21.0 F	199.9 F	
03/25/25 16:00	0.0 FID	0.001 FI	-36.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.1 FI	21.0 F	199.9 F	
03/25/25 17:00	0.0 FID	0.001 FI	-34.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.3 FI	21.0 F	199.9 F	
03/25/25 18:00	0.0 FID	0.001 FI	-36.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.7 FI	21.0 F	199.9 F	
03/25/25 19:00	0.0 FID	0.001 FI	-34.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.3 FI	21.0 F	199.9 F	
03/25/25 20:00	0.0 FID	0.001 FI	-37.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.2 FI	21.0 F	199.9 F	
03/25/25 21:00	0.0 FID	0.001 FI	-36.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.9 FI	21.0 F	199.9 F	
03/25/25 22:00	0.0 FID	0.001 FI	-37.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.3 FI	21.0 F	199.9 F	
03/25/25 23:00	33.6 U	0.140 E	62.9 E	0.0	0.0	0.0	61.5 EU	0.090 E	24.6 E	16.3	199.9	
03/26/25 00:00	17.7 U	0.023	10.1	0.0	0.0	0.0	12.3 U	0.016	4.2	15.2	199.9	
03/26/25 01:00	17.9	0.023	10.2	0.0	0.0	0.0	12.3	0.016	4.3	15.2	199.9	
03/26/25 02:00	17.5	0.022	10.0	0.0	0.0	0.0	12.4	0.016	4.3	15.2	199.9	
03/26/25 03:00	19.4	0.025	11.1	0.0	0.0	0.0	12.5	0.016	4.3	15.2	199.9	
03/26/25 04:00	20.4	0.026	11.6	0.0	0.0	0.0	12.5	0.016	4.3	15.2	199.9	
03/26/25 05:00	15.9 D	0.019	8.6	0.0	0.0	0.0	13.1 D	0.016	4.3	15.2	199.9	
03/26/25 06:00	82.2 ECD	0.259 E	116.5 E	0.0	0.0	0.0 C	35.9 ECD	0.098 E	26.6 E	16.8 C	199.9	
03/26/25 07:00	0.0 FID	0.001 FI	-19.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.8 FI	21.0 F	199.9 F	
03/26/25 08:00	0.0 FID	0.001 FI	-16.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.9 F	
03/26/25 09:00	0.0 FID	0.001 FI	-18.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.9 F	
03/26/25 10:00	0.0 FID	0.001 FI	-17.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.9 F	
03/26/25 11:00	0.0 FID	0.001 FI	-17.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.9 F	
03/26/25 12:00	0.0 FID	0.001 FI	-18.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.8 F	

UNIT START UP

UNIT SHUTDOWN

Source Parameter Unit	UNIT_C										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/26/25 13:00	0.0 FID	0.001 FI	-17.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.8 F
03/26/25 14:00	0.0 FID	0.001 FI	-17.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.8 F
03/26/25 15:00	0.0 FID	0.001 FI	-16.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.9 F
03/26/25 16:00	0.0 FID	0.001 FI	-16.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.9 F
03/26/25 17:00	0.0 FID	0.001 FI	-15.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.9 F
03/26/25 18:00	0.0 FID	0.001 FI	-16.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.9 F
03/26/25 19:00	0.0 FID	0.001 FI	-15.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.9 F
03/26/25 20:00	0.0 FID	0.001 FI	-15.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.8 F
03/26/25 21:00	0.0 FID	0.001 FI	-16.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.8 F
03/26/25 22:00	0.0 FID	0.001 FI	-16.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.6 FI	21.0 F	199.9 F
03/26/25 23:00	0.0 FID	0.001 FI	-16.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.9 F
03/27/25 00:00	0.0 FID	0.001 FI	-15.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.8 F
03/27/25 01:00	0.0 FID	0.001 FI	-16.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.8 F
03/27/25 02:00	0.0 FID	0.001 FI	-16.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.8 F
03/27/25 03:00	33.5 U	0.109 E	48.3 E	0.0	0.0	0.0	58.8 EU	0.091 E	24.7 E	16.1	199.9
03/27/25 04:00	16.8 U	0.021	9.6	0.0	0.0	0.0	12.4 U	0.016	4.3	15.1	199.9
03/27/25 05:00	19.8 D	0.025	11.1	0.0	0.0	0.0	12.8 D	0.016	4.4	15.1	199.9
03/27/25 06:00	93.5 ECD	0.307 E	136.3 E	0.0	0.0	0.0 C	36.0 ECD	0.101 E	27.4 E	17.1 C	199.8
03/27/25 07:00	0.0 FID	0.001 FI	-21.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-1.6 FI	21.0 F	199.9 F
03/27/25 08:00	0.0 FIM	0.001 FI	-195.4 FI	0.0 F	0.0 F	0.0 FIM	0.0 FIM	0.001 FI	-1.2 FI	21.1 FM	199.9 F
03/27/25 09:00	0.0 FIM	0.001 FI	-146.1 FI	0.0 F	0.0 F	0.0 FIM	0.0 FIM	0.001 FI	-1.0 FI	21.0 FM	199.9 F
03/27/25 10:00	0.0 FIM	0.012 FI	5.3 FI	0.0 F	0.0 F	0.0 FIM	0.0 FIM	0.004 FI	1.2 FI	18.3 FMC	199.9 F
03/27/25 11:00	0.0 FIM	0.011 FI	5.0 FI	0.0 F	0.0 F	0.0 FIM	0.0 FIM	0.022 F	5.9 F	10.1 FMC	199.9 F
03/27/25 12:00	0.0 FIC	0.034 FI	15.5 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.058 F	15.9 F	18.4 FC	199.9 F
03/27/25 13:00	0.0 FID	0.001 FI	-77.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.9 F
03/27/25 14:00	0.0 FID	0.001 FI	-71.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.8 F
03/27/25 15:00	0.0 FID	0.001 FI	-66.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.8 F
03/27/25 16:00	0.0 FID	0.001 FI	-61.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.7 FI	21.0 F	199.9 F
03/27/25 17:00	0.0 FID	0.001 FI	-57.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.3 FI	21.0 F	199.9 F
03/27/25 18:00	0.0 FID	0.001 FI	-57.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.9 F
03/27/25 19:00	0.0 FID	0.001 FI	-52.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.9 F
03/27/25 20:00	0.0 FID	0.001 FI	-53.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.4 FI	21.0 F	199.9 F
03/27/25 21:00	0.0 FID	0.001 FI	-53.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.5 FI	21.0 F	199.8 F
03/27/25 22:00	43.6 U	0.229 E	102.3 E	0.0	0.0	0.0	74.6 EU	0.106 E	28.7 E	16.6	199.9
03/27/25 23:00	22.5 U	0.029	12.6	0.0	0.0	0.0	12.9 U	0.016	4.4	15.2	199.9
03/28/25 00:00	20.8	0.027	11.9	0.0	0.0	0.0	12.5	0.016	4.3	15.1	199.9
03/28/25 01:00	20.3	0.026	11.5	0.0	0.0	0.0	12.5	0.016	4.3	15.1	199.9

UNIT START UP

UNIT SHUTDOWN

UNIT START UP



Source		UNIT_C										
Parameter Unit		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
03/28/25	02:00	21.9	0.028	12.4	0.0	0.0	0.0	12.6	0.016	4.4	15.1	199.9
03/28/25	03:00	19.2	0.025	10.9	0.0	0.0	0.0	12.4	0.016	4.3	15.1	199.9
03/28/25	04:00	19.5	0.025	11.0	0.0	0.0	0.0	12.6	0.016	4.3	15.1	199.9
03/28/25	05:00	22.2 D	0.028	12.5	0.0	0.0	0.0	12.7 D	0.016	4.4	15.0	199.9
03/28/25	06:00	93.5 ECD	0.304 E	135.7 E	0.0	0.0	0.0 C	40.2 ECD	0.109 E	29.6 E	17.0 C	199.9
03/28/25	07:00	0.0 FID	0.001 FI	-49.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/28/25	08:00	0.0 FID	0.001 FI	-48.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/28/25	09:00	0.0 FID	0.001 FI	-45.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/28/25	10:00	0.0 FID	0.001 FI	-47.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/28/25	11:00	0.0 FID	0.001 FI	-45.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.8 F
03/28/25	12:00	0.0 FID	0.001 FI	-45.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/28/25	13:00	0.0 FID	0.001 FI	-42.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/28/25	14:00	0.0 FID	0.001 FI	-40.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/28/25	15:00	0.0 FID	0.001 FI	-43.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/28/25	16:00	0.0 FID	0.001 FI	-42.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.8 F
03/28/25	17:00	0.0 FID	0.001 FI	-42.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/28/25	18:00	0.0 FID	0.001 FI	-100.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	20.9 F	199.9 F
03/28/25	19:00	0.0 FID	0.001 FI	-40.1 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/28/25	20:00	0.0 FID	0.001 FI	-38.8 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/28/25	21:00	43.1 U	0.180 E	80.2 E	0.0	0.0	0.0	67.9 EU	0.100 E	26.9 E	16.4	199.9
03/28/25	22:00	24.4 U	0.031	13.7	0.0	0.0	0.0	12.4 U	0.016	4.3	15.1	199.9
03/28/25	23:00	27.1 D	0.035	15.5	0.0	0.0	0.0	19.9 ED	0.025 E	6.9 E	15.0	199.9
03/29/25	00:00	95.0 ED	0.303 E	136.2 E	0.0	0.0	0.0	39.2 ED	0.108 E	29.5 E	17.0	199.9
03/29/25	01:00	0.0 FID	0.001 FI	-40.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F
03/29/25	02:00	0.0 FID	0.001 FI	-39.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/29/25	03:00	0.0 FID	0.001 FI	-37.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/29/25	04:00	0.0 FID	0.001 FI	-38.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/29/25	05:00	0.0 FID	0.001 FI	-33.6 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.9 F
03/29/25	06:00	0.0 FIC	0.012 FI	5.3 FI	0.0 F	0.0 F	0.0 FIC	0.0 FIC	0.023 F	6.4 F	14.2 FC	199.9 F
03/29/25	07:00	0.0 FID	0.001 FI	-43.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.0 FI	21.0 F	199.9 F
03/29/25	08:00	0.0 FID	0.001 FI	-44.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.7 FI	21.0 F	199.9 F
03/29/25	09:00	0.0 FID	0.001 FI	-45.0 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.9 FI	21.0 F	199.9 F
03/29/25	10:00	0.0 FID	0.001 FI	-41.4 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.8 FI	21.0 F	199.9 F
03/29/25	11:00	0.0 FID	0.001 FI	-44.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.1 FI	21.0 F	199.9 F
03/29/25	12:00	0.0 FID	0.001 FI	-43.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.1 FI	21.0 F	199.9 F
03/29/25	13:00	0.0 FID	0.001 FI	-44.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.8 FI	21.0 F	199.9 F
03/29/25	14:00	0.0 FID	0.001 FI	-43.9 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.6 FI	21.0 F	199.9 F

UNIT SHUTDOWN

UNIT START UP

UNIT SHUTDOWN



Source Parameter Unit	UNIT_C											
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)	
03/29/25 15:00	0.0 FID	0.001 FI	-41.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.8 FI	21.0 F	199.9 F	
03/29/25 16:00	0.0 FID	0.001 FI	-42.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.7 FI	21.0 F	199.9 F	
03/29/25 17:00	0.0 FID	0.001 FI	-40.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.0 FI	21.0 F	199.9 F	
03/29/25 18:00	0.0 FID	0.001 FI	-40.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.7 FI	21.0 F	199.9 F	
03/29/25 19:00	0.0 FID	0.001 FI	-39.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.7 FI	21.0 F	199.8 F	
03/29/25 20:00	0.0 FID	0.001 FI	-39.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.9 FI	21.0 F	199.9 F	
03/29/25 21:00	0.0 FID	0.001 FI	-38.8 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-3.2 FI	21.0 F	199.9 F	
03/29/25 22:00	0.0 FID	0.001 FI	-41.3 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-2.6 FI	21.0 F	199.8 F	
03/29/25 23:00	43.6 U	0.183 E	82.1 E	0.0	0.0	0.0	96.0 EU	0.142 E	38.8 E	16.4	199.9	
03/30/25 00:00	20.7 U	0.026	11.6	0.0	0.0	0.0	12.5 U	0.016	4.3	15.1	199.9	
03/30/25 01:00	21.0	0.026	11.9	0.0	0.0	0.0	12.7	0.016	4.4	15.0	199.9	
03/30/25 02:00	19.6	0.025	11.1	0.0	0.0	0.0	12.6	0.016	4.4	15.0	199.9	
03/30/25 03:00	18.9	0.024	10.6	0.0	0.0	0.0	12.6	0.016	4.3	15.0	199.9	
03/30/25 04:00	17.3	0.022	9.7	0.0	0.0	0.0	12.5	0.016	4.3	15.0	199.9	
03/30/25 05:00	18.1 D	0.023	10.2	0.0	0.0	0.0	12.7 D	0.016	4.3	15.0	199.9	
03/30/25 06:00	92.9 ECD	0.267 E	118.4 E	0.0	0.0	0.0 C	43.0 ECD	0.110 E	29.8 E	16.8 C	199.9	
03/30/25 07:00	0.0 FID	0.001 FI	-42.1 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F	
03/30/25 08:00	0.0 FID	0.001 FI	-37.5 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F	
03/30/25 09:00	0.0 FID	0.001 FI	-39.3 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F	
03/30/25 10:00	0.0 FID	0.001 FI	-41.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.9 F	
03/30/25 11:00	0.0 FID	0.001 FI	-38.2 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	0.0 FI	21.0 F	199.9 F	
03/30/25 12:00	0.0 FID	0.001 FI	-39.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F	
03/30/25 13:00	0.0 FID	0.001 FI	-35.7 FI	0.0 F	0.0 F	0.0 FI	0.0 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F	
03/30/25 14:00	0.0 FID	0.001 FI	-37.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	-0.1 FI	21.0 F	199.9 F	
03/30/25 15:00	0.0 FID	0.001 FI	-36.2 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F	
03/30/25 16:00	0.0 FID	0.001 FI	-36.0 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F	
03/30/25 17:00	0.0 FID	0.001 FI	-35.7 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F	
03/30/25 18:00	0.0 FID	0.001 FI	-33.9 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F	
03/30/25 19:00	0.0 FID	0.001 FI	-34.4 FI	0.0 F	0.0 F	0.0 FI	0.1 FID	0.001 FI	0.0 FI	21.0 F	199.9 F	
03/30/25 20:00	53.4 U	0.265 E	118.0 E	0.0	0.0	0.0	90.3 EU	0.149 E	40.3 E	17.0	199.9	
03/30/25 21:00	16.5 U	0.020	8.7	0.0	0.0	0.0	13.5 U	0.016	4.3	15.1	199.9	
03/30/25 22:00	21.6	0.027	12.1	0.0	0.0	0.0	12.6	0.016	4.3	15.2	199.9	
03/30/25 23:00	21.1	0.027	12.0	0.0	0.0	0.0	12.5	0.016	4.3	15.1	199.9	
03/31/25 00:00	18.1	0.023	10.3	0.0	0.0	0.0	12.5	0.016	4.3	15.1	199.9	
03/31/25 01:00	18.2	0.023	10.4	0.0	0.0	0.0	12.6	0.016	4.4	15.1	199.9	
03/31/25 02:00	17.9	0.023	10.2	0.0	0.0	0.0	12.6	0.016	4.4	15.1	199.9	
03/31/25 03:00	18.6	0.024	10.6	0.0	0.0	0.0	12.5	0.016	4.3	15.1	199.9	

UNIT START UP

UNIT SHUTDOWN

UNIT START UP

Average Data

Plant: Midway Sunset
Interval: 12 Month

Type: Roll

Report Period: 04/01/2024 00:00 Through 03/31/2025 23:59
Time Online Criteria: 1 minute(s)

Source	UNIT_C
Parameter Unit	GASMMSCF (MMSCF)
04/24	255.4
05/24	293.3
06/24	357.9
07/24	455.8
08/24	498.3
09/24	573.0
10/24	519.4
11/24	533.7
12/24	536.6
01/25	526.9
02/25	588.2
03/25	693.9

Average	486.0
Minimum	255.4
Maximum	693.9
Summation	5,832.4
Geometric Mean	468.4
Included Data Points	12
Total number of Data Points	12

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/24/25 05:44

C = Calibration

S = Substituted

*** = Suspect**