

DOCKETED

Docket Number:	85-AFC-03C
Project Title:	Compliance - Application for Certification for Midway-Sunset Cogeneration Project
TN #:	270336
Document Title:	MSCC 85-AFC-03C 4th Quarter 2025 AQR 3 of 3
Description:	N/A
Filer:	Stephanie Urias
Organization:	Midway Sunset Cogeneration Company
Submitter Role:	Applicant
Submission Date:	5/28/2026 3:34:03 PM
Docketed Date:	5/28/2026

UNIT C CEM REPORT

Average Data

Plant: Midway Sunset

Interval: 1 Hour

Type: Roll

Report Period: 10/01/2025 00:00 Through 12/31/2025 23:59

Time Online Criteria: 1 minute(s)

Source Parameter Unit	UNIT_C										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
10/01/25 00:00	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F
10/01/25 01:00	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F
10/01/25 02:00	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F
10/01/25 03:00	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F
10/01/25 04:00	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F
10/01/25 05:00	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F
10/01/25 06:00	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F
10/01/25 07:00	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F
10/01/25 08:00	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F
10/01/25 09:00	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F
10/01/25 10:00	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F
10/01/25 11:00	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F
10/01/25 12:00	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F
10/01/25 13:00	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F
10/01/25 14:00	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F
10/01/25 15:00	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F
10/01/25 16:00	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F
10/01/25 17:00	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F
10/01/25 18:00	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F
10/01/25 19:00	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F
10/01/25 20:00	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F
10/01/25 21:00	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F
10/01/25 22:00	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F
10/01/25 23:00	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F
10/02/25 00:00	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F
10/02/25 01:00	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F
10/02/25 02:00	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F
10/02/25 03:00	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F
10/02/25 04:00	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F
10/02/25 05:00	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F
10/02/25 06:00	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	0.0 F	0.0 F

UNIT SHUTDOWN
CONTINUED

Source Parameter Unit	UNIT_C										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
10/22/25 08:00	0.0 FI	0.000 FI	0.0 FI	0.0 FI	0.0 FI	0.0 FI	0.0 FI	0.000 FI	0.0 FI	0.0 FI	0.0 FI
10/22/25 09:00	0.0 FI	6.614 FI	10.0 FI	0.0 FI	0.0 FI	0.0 FI	0.0 FI	0.000 FI	1.6 FI	21.0 FI	199.9 F
10/22/25 10:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.5 F	21.0 F	199.9 F
10/22/25 11:00	0.0 F	6.614 F	15.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.7 F	21.0 F	199.9 F
10/22/25 12:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.2 F	21.0 F	199.9 F
10/22/25 13:00	0.0 F	6.614 F	14.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.4 F	21.0 F	199.9 F
10/22/25 14:00	0.0 F	6.614 F	17.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.1 F	21.0 F	199.9 F
10/22/25 15:00	0.0 F	6.614 F	5.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.7 F	21.0 F	199.9 F
10/22/25 16:00	0.0 F	6.614 F	3.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.0 F	21.0 F	199.9 F
10/22/25 17:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	21.0 F	199.9 F
10/22/25 18:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.9 F	21.0 F	199.9 F
10/22/25 19:00	0.0 F	6.614 F	9.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.9 F	21.0 F	198.9 F
10/22/25 20:00	0.0 F	6.614 F	11.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.5 F	21.0 F	199.9 F
10/22/25 21:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	21.0 F	199.9 F
10/22/25 22:00	0.0 F	6.614 F	13.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.9 F	21.0 F	199.9 F
10/22/25 23:00	0.0 F	6.614 F	2.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	21.0 F	199.9 F
10/23/25 00:00	0.0 F	6.614 F	5.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.7 F	21.0 F	199.9 F
10/23/25 01:00	0.0 F	6.614 F	15.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.3 F	21.0 F	199.9 F
10/23/25 02:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.6 F	21.0 F	199.9 F
10/23/25 03:00	0.0 F	6.614 F	18.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.0 F	21.0 F	199.9 F
10/23/25 04:00	0.0 F	6.614 F	12.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.4 F	21.0 F	199.9 F
10/23/25 05:00	0.0 F	6.614 F	2.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.3 F	21.0 F	199.9 F
10/23/25 08:00	0.0 FC	0.012 FC	14.5 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.023 FC	3.8 FC	14.2 FC	199.9 F
10/23/25 07:00	0.0 F	6.614 F	4.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.0 F	20.9 F	199.9 F
10/23/25 08:00	0.0 F	6.614 F	54.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.3 F	20.9 F	199.9 F
10/23/25 09:00	0.0 F	6.614 F	13.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.6 F	20.9 F	199.9 F
10/23/25 10:00	0.0 F	6.614 F	5.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.1 F	20.9 F	199.9 F
10/23/25 11:00	0.0 F	6.614 F	27.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.1 F	20.9 F	199.9 F
10/23/25 12:00	0.0 F	6.614 F	35.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.9 F	20.9 F	199.9 F
10/23/25 13:00	0.0 F	6.614 F	47.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.8 F	20.9 F	199.9 F
10/23/25 14:00	0.0 F	6.614 F	26.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.2 F	20.9 F	199.9 F
10/23/25 15:00	0.0 F	6.614 F	41.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.8 F	20.9 F	199.9 F
10/23/25 16:00	0.0 F	6.614 F	41.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.1 F	20.9 F	199.9 F
10/23/25 17:00	0.0 F	6.614 F	43.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.3 F	20.9 F	199.9 F
10/23/25 18:00	0.0 F	6.614 F	15.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.1 F	20.9 F	199.9 F
10/23/25 19:00	0.0 F	6.614 F	24.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	20.9 F	199.9 F
10/23/25 20:00	0.0 F	6.614 F	28.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.6 F	20.9 F	199.9 F

Source		UNIT_C										
Parameter Unit		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
10/23/25	21:00	0.0 F	6.614 F	33.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.5 F	20.9 F	199.9 F
10/23/25	22:00	0.0 F	6.614 F	20.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.9 F	20.9 F	199.9 F
10/23/25	23:00	0.0 F	5.292 F	24.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.7 F	20.9 F	199.9 F
10/24/25	00:00	0.0 F	6.614 F	38.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.6 F	20.9 F	199.9 F
10/24/25	01:00	0.0 F	6.614 F	27.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.6 F	20.9 F	199.9 F
10/24/25	02:00	0.0 F	6.614 F	37.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.1 F	20.9 F	199.9 F
10/24/25	03:00	0.0 F	6.614 F	67.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.1 F	20.9 F	199.9 F
10/24/25	04:00	0.0 F	6.614 F	5.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.0 F	20.9 F	199.9 F
10/24/25	05:00	0.0 F	6.614 F	31.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.9 F	20.9 F	199.9 F
10/24/25	06:00	0.0 FC	0.011 FC	25.1 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.023 FC	3.5 FC	14.2 FC	199.9 F
10/24/25	07:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
10/24/25	08:00	0.0 F	5.292 F	5.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	21.0 F	199.8 F
10/24/25	09:00	0.0 F	5.292 F	0.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.8 F
10/24/25	10:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.8 F
10/24/25	11:00	0.0 F	6.614 F	0.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
10/24/25	12:00	0.0 F	6.614 F	6.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.8 F	21.0 F	199.9 F
10/24/25	13:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
10/24/25	14:00	0.0 F	6.614 F	8.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
10/24/25	15:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
10/24/25	16:00	0.0 F	5.292 F	0.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
10/24/25	17:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
10/24/25	18:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
10/24/25	19:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
10/24/25	20:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
10/24/25	21:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
10/24/25	22:00	0.0 F	6.614 F	0.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.8 F
10/24/25	23:00	0.0 F	6.614 F	6.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	21.0 F	199.9 F
10/25/25	00:00	0.0 F	5.292 F	0.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
10/25/25	01:00	0.0 F	5.292 F	15.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	21.0 F	199.9 F
10/25/25	02:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
10/25/25	03:00	0.0 F	5.292 F	10.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
10/25/25	04:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
10/25/25	05:00	0.0 F	5.292 F	1.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
10/25/25	06:00	0.0 FC	0.011 FC	5.0 FC	0.0 F	0.0 F	0.0 FC	0.1 FC	0.023 FC	5.7 FC	14.2 FC	199.9 F
10/25/25	07:00	0.0 F	6.614 F	2.3 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	8.6 F	20.9 F	199.9 F
10/25/25	08:00	0.0 F	6.614 F	15.2 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	12.5 F	20.9 F	199.9 F
10/25/25	09:00	0.0 F	6.614 F	27.2 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	13.2 F	20.9 F	199.9 F

Source		UNIT_C										
Parameter Unit		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
10/25/25	10:00	0.0 F	6.614 F	17.6 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	13.9 F	20.9 F	199.9 F
10/25/25	11:00	0.0 F	6.614 F	6.1 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	12.3 F	20.9 F	199.9 F
10/25/25	12:00	0.0 F	6.614 F	27.2 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	13.1 F	21.0 F	199.9 F
10/25/25	13:00	0.0 F	6.614 F	9.2 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	9.9 F	21.0 F	199.9 F
10/25/25	14:00	0.0 F	6.614 F	9.6 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	13.0 F	21.0 F	199.9 F
10/25/25	15:00	0.0 F	6.614 F	13.0 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	9.7 F	21.0 F	199.9 F
10/25/25	16:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	11.7 F	21.0 F	199.9 F
10/25/25	17:00	0.0 F	6.614 F	0.2 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	10.4 F	21.0 F	199.9 F
10/25/25	18:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	11.3 F	21.0 F	199.9 F
10/25/25	19:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	11.8 F	21.0 F	199.9 F
10/25/25	20:00	0.0 F	6.614 F	5.7 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	12.1 F	21.0 F	199.9 F
10/25/25	21:00	0.0 F	6.614 F	0.6 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	9.9 F	21.0 F	199.9 F
10/25/25	22:00	0.0 F	6.614 F	0.9 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	13.6 F	21.0 F	199.9 F
10/25/25	23:00	0.0 F	6.614 F	36.4 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	9.3 F	20.9 F	199.9 F
10/26/25	00:00	0.0 F	6.614 F	2.2 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	8.9 F	21.0 F	199.9 F
10/26/25	01:00	0.0 F	6.614 F	26.2 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	10.3 F	21.0 F	199.9 F
10/26/25	02:00	0.0 F	5.292 F	10.6 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	10.4 F	21.0 F	199.9 F
10/26/25	03:00	0.0 F	5.292 F	4.4 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	9.6 F	21.0 F	199.9 F
10/26/25	04:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	11.3 F	21.0 F	199.9 F
10/26/25	05:00	0.0 F	6.614 F	28.7 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	10.9 F	20.9 F	199.9 F
10/26/25	06:00	0.0 FC	0.011 FC	6.3 FC	0.0 F	0.0 F	0.0 FC	0.1 FC	0.023 FC	6.3 FC	14.2 FC	199.9 F
10/26/25	07:00	0.0 F	5.292 F	4.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.2 F	21.0 F	199.9 F
10/26/25	08:00	0.0 F	5.292 F	21.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	21.0 F	199.9 F
10/26/25	09:00	0.0 F	5.292 F	1.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.6 F	21.0 F	199.9 F
10/26/25	10:00	0.0 F	5.292 F	16.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	21.0 F	199.9 F
10/26/25	11:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	21.0 F	199.9 F
10/26/25	12:00	0.0 F	5.292 F	1.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.8 F	21.0 F	199.9 F
10/26/25	13:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.9 F	21.0 F	199.9 F
10/26/25	14:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	21.0 F	199.9 F
10/26/25	15:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.9 F	21.0 F	199.9 F
10/26/25	16:00	0.0 F	5.292 F	1.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.6 F	21.0 F	199.9 F
10/26/25	17:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.8 F	21.0 F	199.9 F
10/26/25	18:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.0 F	21.0 F	199.9 F
10/26/25	19:00	0.0 F	5.292 F	15.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	21.0 F	199.9 F
10/26/25	20:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.8 F	21.0 F	199.9 F
10/26/25	21:00	0.0 F	5.292 F	1.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.4 F	21.0 F	199.9 F
10/26/25	22:00	0.0 F	5.292 F	14.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.6 F	21.0 F	199.9 F

Source		UNIT_C										
Parameter Unit		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
10/26/25	23:00	0.0 F	5.292 F	3.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	20.9 F	199.9 F
10/27/25	00:00	0.0 F	5.292 F	4.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.5 F	21.0 F	199.9 F
10/27/25	01:00	0.0 F	5.292 F	14.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.8 F	21.0 F	199.9 F
10/27/25	02:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	21.0 F	199.9 F
10/27/25	03:00	0.0 F	5.292 F	5.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.1 F	21.0 F	199.9 F
10/27/25	04:00	0.0 F	5.292 F	3.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.4 F	21.0 F	199.9 F
10/27/25	05:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.0 F	21.0 F	199.9 F
10/27/25	06:00	0.0 FC	0.012 FC	1.8 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.023 FC	14.8 FC	14.2 FC	199.9 F
10/27/25	07:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
10/27/25	08:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
10/27/25	09:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
10/27/25	10:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
10/27/25	11:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
10/27/25	12:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
10/27/25	13:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
10/27/25	14:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
10/27/25	15:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
10/27/25	16:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
10/27/25	17:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
10/27/25	18:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
10/27/25	19:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
10/27/25	20:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
10/27/25	21:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
10/27/25	22:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
10/27/25	23:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
10/28/25	00:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
10/28/25	01:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
10/28/25	02:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
10/28/25	03:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
10/28/25	04:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
10/28/25	05:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
10/28/25	06:00	0.0 FC	0.012 FC	2.4 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.023 FC	2.9 FC	14.2 FC	199.9 F
10/28/25	07:00	0.0 F	5.292 F	3.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.9 F	21.0 F	199.9 F
10/28/25	08:00	0.0 F	5.292 F	2.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	21.0 F	199.9 F
10/28/25	09:00	0.0 F	5.292 F	16.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.4 F	21.0 F	199.9 F
10/28/25	10:00	0.0 F	5.292 F	25.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.8 F	21.0 F	199.9 F
10/28/25	11:00	0.0 F	5.292 F	15.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.8 F	21.0 F	199.9 F

Source		UNIT_C										
Parameter Unit		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
10/28/25	12:00	0.0 F	5.292 F	14.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.8 F	21.0 F	199.9 F
10/28/25	13:00	0.0 F	5.292 F	5.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.5 F	21.0 F	199.9 F
10/28/25	14:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.6 F	21.0 F	199.9 F
10/28/25	15:00	0.0 F	5.292 F	5.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.3 F	21.0 F	199.9 F
10/28/25	16:00	0.0 F	5.292 F	4.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.8 F	21.0 F	199.9 F
10/28/25	17:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.1 F	21.0 F	199.9 F
10/28/25	18:00	0.0 F	5.292 F	0.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.4 F	21.0 F	199.9 F
10/28/25	19:00	0.0 F	5.292 F	5.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.8 F	21.0 F	199.9 F
10/28/25	20:00	0.0 F	5.292 F	10.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.5 F	21.0 F	199.9 F
10/28/25	21:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	21.0 F	199.9 F
10/28/25	22:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	21.0 F	199.9 F
10/28/25	23:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	21.0 F	199.9 F
10/29/25	00:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.6 F	21.0 F	199.9 F
10/29/25	01:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.8 F	21.0 F	199.9 F
10/29/25	02:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.9 F	21.0 F	199.9 F
10/29/25	03:00	0.0 F	5.292 F	1.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.6 F	21.0 F	199.9 F
10/29/25	04:00	0.0 F	5.292 F	11.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.0 F	21.0 F	199.9 F
10/29/25	05:00	0.0 F	5.292 F	1.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.1 F	21.0 F	199.9 F
10/29/25	06:00	0.0 FC	0.011 FC	14.9 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.023 FC	4.5 FC	14.2 FC	199.9 F
10/29/25	07:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
10/29/25	08:00	0.0 F	5.292 F	2.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
10/29/25	09:00	0.0 F	5.292 F	1.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
10/29/25	10:00	0.0 F	5.292 F	2.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.6 F	21.0 F	199.9 F
10/29/25	11:00	0.0 F	5.292 F	0.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.9 F	21.0 F	199.9 F
10/29/25	12:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
10/29/25	13:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
10/29/25	14:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
10/29/25	15:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
10/29/25	16:00	0.0 F	5.292 F	0.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.6 F	21.0 F	199.9 F
10/29/25	17:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	21.0 F	199.9 F
10/29/25	18:00	0.0 F	5.292 F	1.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
10/29/25	19:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
10/29/25	20:00	0.0 F	5.292 F	12.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.6 F	21.0 F	199.9 F
10/29/25	21:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
10/29/25	22:00	0.0 F	5.292 F	0.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
10/29/25	23:00	0.0 F	5.292 F	4.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
10/30/25	00:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F

Source Parameter Unit		UNIT_C										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
10/30/25	01:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F	
10/30/25	02:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	21.0 F	199.9 F	
10/30/25	03:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.6 F	21.0 F	199.9 F	
10/30/25	04:00	0.0 F	5.292 F	3.5 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	21.0 F	199.9 F	
10/30/25	05:00	0.0 F	5.292 F	3.7 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F	
10/30/25	06:00	0.0 FC	0.011 FC	10.8 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.023 FC	3.1 FC	14.2 FC	199.9 F
10/30/25	07:00	0.0 F	6.614 F	24.8 F	0.0 F	0.0 F	0.0 F	0.000 F	4.3 F	20.9 F	199.9 F	
10/30/25	08:00	0.0 F	6.614 F	52.1 F	0.0 F	0.0 F	0.0 F	0.000 F	5.9 F	20.9 F	199.9 F	
10/30/25	09:00	0.0 F	6.614 F	26.0 F	0.0 F	0.0 F	0.1 F	0.000 F	6.3 F	20.9 F	199.9 F	
10/30/25	10:00	0.0 F	6.614 F	63.8 F	0.0 F	0.0 F	0.0 F	0.000 F	3.8 F	20.9 F	199.9 F	
10/30/25	11:00	0.0 F	6.614 F	32.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.2 F	20.9 F	199.9 F	
10/30/25	12:00	0.0 F	6.614 F	38.5 F	0.0 F	0.0 F	0.0 F	0.000 F	3.8 F	20.9 F	199.9 F	
10/30/25	13:00	0.0 F	6.614 F	24.3 F	0.0 F	0.0 F	0.0 F	0.000 F	3.4 F	20.9 F	199.9 F	
10/30/25	14:00	0.0 F	6.614 F	36.7 F	0.0 F	0.0 F	0.0 F	0.000 F	3.0 F	20.9 F	199.9 F	
10/30/25	15:00	0.0 F	6.614 F	50.1 F	0.0 F	0.0 F	0.0 F	0.000 F	4.1 F	20.9 F	199.9 F	
10/30/25	16:00	0.0 F	6.614 F	38.6 F	0.0 F	0.0 F	0.0 F	0.000 F	3.2 F	20.9 F	199.9 F	
10/30/25	17:00	0.0 F	6.614 F	9.9 F	0.0 F	0.0 F	0.0 F	0.000 F	3.3 F	20.9 F	199.9 F	
10/30/25	18:00	0.0 F	6.614 F	20.3 F	0.0 F	0.0 F	0.0 F	0.000 F	6.2 F	20.9 F	199.9 F	
10/30/25	19:00	0.0 F	6.614 F	7.5 F	0.0 F	0.0 F	0.0 F	0.000 F	4.4 F	20.9 F	199.9 F	
10/30/25	20:00	0.0 F	6.614 F	19.1 F	0.0 F	0.0 F	0.0 F	0.000 F	5.2 F	20.9 F	199.9 F	
10/30/25	21:00	0.0 F	6.614 F	54.9 F	0.0 F	0.0 F	0.0 F	0.000 F	3.6 F	20.9 F	199.9 F	
10/30/25	22:00	0.0 F	6.614 F	19.6 F	0.0 F	0.0 F	0.0 F	0.000 F	5.3 F	20.9 F	199.9 F	
10/30/25	23:00	0.0 F	6.614 F	18.8 F	0.0 F	0.0 F	0.0 F	0.000 F	4.8 F	20.9 F	199.9 F	
10/31/25	00:00	0.0 F	6.614 F	52.9 F	0.0 F	0.0 F	0.0 F	0.000 F	5.2 F	20.9 F	199.9 F	
10/31/25	01:00	0.0 F	6.614 F	28.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.5 F	20.9 F	199.9 F	
10/31/25	02:00	0.0 F	6.614 F	68.2 F	0.0 F	0.0 F	0.0 F	0.000 F	5.6 F	20.9 F	199.9 F	
10/31/25	03:00	0.0 F	6.614 F	18.2 F	0.0 F	0.0 F	0.0 F	0.000 F	3.1 F	20.9 F	199.9 F	
10/31/25	04:00	0.0 F	6.614 F	67.3 F	0.0 F	0.0 F	0.0 F	0.000 F	4.6 F	20.9 F	199.9 F	
10/31/25	05:00	0.0 FM	6.614 FM	39.0 FM	0.0 F	0.0 F	0.0 FM	0.0 FM	0.000 FM	6.1 FM	20.9 FM	199.9 F
10/31/25	06:00	0.0 FC	0.012 FC	4.4 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.023 FC	3.9 FC	14.2 FC	199.9 F
10/31/25	07:00	0.0 F	5.292 F	6.4 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	21.0 F	199.9 F	
10/31/25	08:00	0.0 F	5.292 F	7.3 F	0.0 F	0.0 F	0.0 F	0.000 F	0.8 F	21.0 F	199.9 F	
10/31/25	09:00	0.0 F	6.614 F	8.3 F	0.0 F	0.0 F	0.0 F	0.000 F	0.9 F	21.0 F	199.9 F	
10/31/25	10:00	0.0 F	6.614 F	12.7 F	0.0 F	0.0 F	0.0 F	0.000 F	1.6 F	21.0 F	199.9 F	
10/31/25	11:00	0.0 F	6.614 F	11.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.0 F	21.0 F	199.9 F	
10/31/25	12:00	0.0 F	5.292 F	17.3 F	0.0 F	0.0 F	0.0 F	0.000 F	1.0 F	21.0 F	199.9 F	
10/31/25	13:00	0.0 F	5.292 F	2.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.6 F	21.0 F	199.9 F	

Source		UNIT_C										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
10/31/25	14:00	0.0 F	5.292 F	23.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.3 F	21.0 F	199.9 F
10/31/25	15:00	0.0 F	5.292 F	13.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.9 F	21.0 F	199.9 F
10/31/25	16:00	0.0 F	5.292 F	10.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.8 F	21.0 F	199.9 F
10/31/25	17:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
10/31/25	18:00	0.0 F	5.292 F	25.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.5 F	21.0 F	199.9 F
10/31/25	19:00	0.0 F	5.292 F	31.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.4 F	21.0 F	199.9 F
10/31/25	20:00	0.0 F	5.292 F	17.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.7 F	21.0 F	199.9 F
10/31/25	21:00	0.0 F	5.292 F	24.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	21.0 F	199.9 F
10/31/25	22:00	0.0 F	5.292 F	18.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.3 F	21.0 F	199.9 F
10/31/25	23:00	0.0 F	5.292 F	33.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.6 F	21.0 F	199.9 F
11/01/25	00:00	0.0 F	5.292 F	13.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	21.0 F	199.9 F
11/01/25	01:00	0.0 F	5.292 F	6.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.1 F	21.0 F	199.9 F
11/01/25	02:00	0.0 F	5.292 F	0.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	21.0 F	199.9 F
11/01/25	03:00	0.0 F	5.292 F	11.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	20.9 F	199.9 F
11/01/25	04:00	0.0 F	5.292 F	25.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.4 F	21.0 F	199.9 F
11/01/25	05:00	0.0 F	5.292 F	28.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.6 F	20.9 F	199.9 F
11/01/25	06:00	0.0 FC	0.012 FC	14.8 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.023 FC	3.5 FC	14.2 FC	199.9 F
11/01/25	07:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/01/25	08:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.6 F	21.0 F	199.9 F
11/01/25	09:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/01/25	10:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.6 F	21.0 F	199.9 F
11/01/25	11:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
11/01/25	12:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
11/01/25	13:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	21.0 F	199.9 F
11/01/25	14:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.6 F	21.0 F	199.9 F
11/01/25	15:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	21.0 F	199.9 F
11/01/25	16:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
11/01/25	17:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
11/01/25	18:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
11/01/25	19:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
11/01/25	20:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	21.0 F	199.9 F
11/01/25	21:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	21.0 F	199.9 F
11/01/25	22:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.6 F	21.0 F	199.9 F
11/01/25	23:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.6 F	21.0 F	199.9 F
11/02/25	00:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	21.0 F	199.9 F
11/02/25	01:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.0 F	21.0 F	199.9 F
11/02/25	02:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.6 F	21.0 F	199.9 F

Source	UNIT_C											
	Parameter Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
11/02/25	03:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	21.0 F	199.9 F
11/02/25	04:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.6 F	21.0 F	199.9 F
11/02/25	05:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
11/02/25	06:00	0.0 FC	0.012 FC	7.0 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.023 FC	3.6 FC	14.2 FC	199.9 F
11/02/25	07:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
11/02/25	08:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	21.0 F	199.9 F
11/02/25	09:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	21.0 F	199.9 F
11/02/25	10:00	0.0 F	7.937 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.6 F	21.0 F	199.9 F
11/02/25	11:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.8 F	21.0 F	199.9 F
11/02/25	12:00	0.0 F	7.937 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.6 F	21.0 F	199.9 F
11/02/25	13:00	0.0 F	7.937 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	21.0 F	199.9 F
11/02/25	14:00	0.0 F	7.937 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	21.0 F	199.9 F
11/02/25	15:00	0.0 F	7.937 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.8 F	21.0 F	199.9 F
11/02/25	16:00	0.0 F	7.937 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
11/02/25	17:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
11/02/25	18:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	21.0 F	199.9 F
11/02/25	19:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.6 F	21.0 F	199.9 F
11/02/25	20:00	0.0 F	7.937 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.6 F	21.0 F	199.9 F
11/02/25	21:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	21.0 F	199.9 F
11/02/25	22:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	21.0 F	199.9 F
11/02/25	23:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	21.0 F	199.9 F
11/03/25	00:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	21.0 F	199.9 F
11/03/25	01:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/03/25	02:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	21.0 F	199.9 F
11/03/25	03:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	21.0 F	199.9 F
11/03/25	04:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.6 F	21.0 F	199.9 F
11/03/25	05:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.6 F	20.9 F	199.9 F
11/03/25	06:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/03/25	07:00	0.0 FC	0.011 FC	2.7 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.023 FC	3.1 FC	14.2 FC	199.9 F
11/03/25	08:00	0.0 F	6.614 F	5.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.4 F	21.0 F	199.9 F
11/03/25	09:00	0.0 F	6.614 F	20.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.1 F	21.0 F	199.9 F
11/03/25	10:00	0.0 F	6.614 F	5.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.1 F	21.0 F	199.9 F
11/03/25	11:00	0.0 F	6.614 F	10.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.2 F	21.0 F	199.9 F
11/03/25	12:00	0.0 F	6.614 F	3.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.0 F	21.0 F	199.9 F
11/03/25	13:00	0.0 F	6.614 F	9.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	21.0 F	199.9 F
11/03/25	14:00	0.0 F	6.614 F	2.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.1 F	21.0 F	199.9 F
11/03/25	15:00	0.0 F	5.292 F	40.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.3 F	21.0 F	199.9 F

Source Parameter Unit	UNIT_C										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
11/03/25 16:00	0.0 F	5.292 F	12.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	21.0 F	199.9 F
11/03/25 17:00	0.0 F	6.614 F	0.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	21.0 F	199.9 F
11/03/25 18:00	0.0 F	5.292 F	24.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.5 F	21.0 F	199.9 F
11/03/25 19:00	0.0 F	5.292 F	6.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.1 F	21.0 F	199.9 F
11/03/25 20:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.0 F	21.0 F	199.9 F
11/03/25 21:00	0.0 F	5.292 F	1.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.6 F	21.0 F	199.9 F
11/03/25 22:00	0.0 F	5.292 F	15.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.6 F	21.0 F	199.9 F
11/03/25 23:00	0.0 F	5.292 F	4.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.4 F	20.9 F	199.9 F
11/04/25 00:00	0.0 F	6.614 F	2.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.1 F	21.0 F	199.9 F
11/04/25 01:00	0.0 F	6.614 F	12.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.1 F	21.0 F	199.9 F
11/04/25 02:00	0.0 F	5.292 F	7.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.3 F	21.0 F	199.9 F
11/04/25 03:00	0.0 F	5.292 F	5.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.6 F	21.0 F	199.9 F
11/04/25 04:00	0.0 F	5.292 F	14.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.8 F	21.0 F	199.9 F
11/04/25 05:00	0.0 F	5.292 F	26.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.4 F	20.9 F	199.9 F
11/04/25 06:00	0.0 F	5.292 F	8.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.8 F	21.0 F	199.9 F
11/04/25 07:00	0.0 FC	0.011 FC	11.3 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.023 FC	3.8 FC	14.2 FC	199.9 F
11/04/25 08:00	0.0 F	5.292 F	9.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.4 F	21.0 F	199.9 F
11/04/25 09:00	0.0 F	5.292 F	21.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.1 F	21.0 F	199.9 F
11/04/25 10:00	0.0 F	6.614 F	5.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.5 F	21.0 F	199.9 F
11/04/25 11:00	0.0 F	6.614 F	2.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.9 F	21.0 F	199.9 F
11/04/25 12:00	0.0 F	6.614 F	12.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.5 F	21.0 F	199.9 F
11/04/25 13:00	0.0 F	6.614 F	9.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.0 F	21.0 F	199.9 F
11/04/25 14:00	0.0 F	6.614 F	5.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.5 F	21.0 F	199.9 F
11/04/25 15:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	21.0 F	199.9 F
11/04/25 16:00	0.0 F	6.614 F	3.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.8 F	21.0 F	199.9 F
11/04/25 17:00	0.0 F	5.292 F	4.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.2 F	21.0 F	199.9 F
11/04/25 18:00	0.0 F	6.614 F	35.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.7 F	21.0 F	199.9 F
11/04/25 19:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.0 F	21.0 F	199.9 F
11/04/25 20:00	0.0 F	6.614 F	20.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.7 F	21.0 F	199.9 F
11/04/25 21:00	0.0 F	5.292 F	9.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.6 F	21.0 F	199.9 F
11/04/25 22:00	0.0 F	5.292 F	2.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.9 F	21.0 F	199.9 F
11/04/25 23:00	0.0 F	5.292 F	4.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.5 F	21.0 F	199.9 F
11/05/25 00:00	0.0 F	5.292 F	14.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.9 F	21.0 F	199.9 F
11/05/25 01:00	0.0 F	5.292 F	14.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.1 F	21.0 F	199.9 F
11/05/25 02:00	0.0 F	5.292 F	8.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.8 F	21.0 F	199.9 F
11/05/25 03:00	0.0 F	5.292 F	5.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.5 F	21.0 F	199.9 F
11/05/25 04:00	0.0 F	5.292 F	9.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.8 F	21.0 F	199.9 F

Source Parameter Unit		UNIT_C										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
11/05/25	05:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.8 F	21.0 F	199.9 F	
11/05/25	06:00	0.0 F	6.614 F	1.5 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	21.0 F	199.9 F	
11/05/25	07:00	0.0 FC	0.011 FC	28.6 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.023 FC	4.9 FC	14.2 FC	199.9 F
11/05/25	08:00	0.0 F	3.969 F	46.7 F	0.0 F	0.0 F	0.0 F	0.000 F	3.7 F	20.9 F	199.9 F	
11/05/25	09:00	0.0 F	0.040 F	49.4 F	0.0 F	0.0 F	0.0 F	0.000 F	3.5 F	20.8 F	199.9 F	
11/05/25	10:00	0.0 F	0.040 F	37.9 F	0.0 F	0.0 F	0.0 F	0.000 F	4.4 F	20.8 F	199.9 F	
11/05/25	11:00	0.0 F	0.040 F	45.1 F	0.0 F	0.0 F	0.0 F	0.000 F	3.6 F	20.8 F	199.9 F	
11/05/25	12:00	0.0 F	0.040 F	37.9 F	0.0 F	0.0 F	0.0 F	0.000 F	4.1 F	20.8 F	199.9 F	
11/05/25	13:00	0.0 F	0.040 F	39.8 F	0.0 F	0.0 F	0.0 F	0.000 F	4.1 F	20.8 F	199.9 F	
11/05/25	14:00	0.0 F	0.053 F	57.4 F	0.0 F	0.0 F	0.0 F	0.000 F	5.2 F	20.8 F	199.9 F	
11/05/25	15:00	0.0 F	0.053 F	53.6 F	0.0 F	0.0 F	0.0 F	0.000 F	4.8 F	20.8 F	199.8 F	
11/05/25	16:00	0.0 F	0.053 F	59.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.4 F	20.8 F	199.8 F	
11/05/25	17:00	0.0 F	0.053 F	58.8 F	0.0 F	0.0 F	0.0 F	0.000 F	4.9 F	20.8 F	199.8 F	
11/05/25	18:00	0.0 F	0.040 F	65.3 F	0.0 F	0.0 F	0.0 F	0.000 F	7.0 F	20.8 F	199.8 F	
11/05/25	19:00	0.0 F	0.053 F	42.5 F	0.0 F	0.0 F	0.0 F	0.000 F	5.2 F	20.8 F	199.8 F	
11/05/25	20:00	0.0 F	0.040 F	64.6 F	0.0 F	0.0 F	0.0 F	0.000 F	9.0 F	20.8 F	199.9 F	
11/05/25	21:00	0.0 F	0.040 F	42.2 F	0.0 F	0.0 F	0.0 F	0.000 F	3.1 F	20.8 F	199.9 F	
11/05/25	22:00	0.0 F	0.040 F	47.4 F	0.0 F	0.0 F	0.0 F	0.000 F	4.2 F	20.8 F	199.9 F	
11/05/25	23:00	0.0 F	0.040 F	51.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.1 F	20.8 F	199.9 F	
11/06/25	00:00	0.0 F	0.040 F	73.1 F	0.0 F	0.0 F	0.0 F	0.000 F	7.7 F	20.8 F	199.9 F	
11/06/25	01:00	0.0 F	0.040 F	51.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.8 F	20.8 F	199.9 F	
11/06/25	02:00	0.0 F	0.040 F	48.2 F	0.0 F	0.0 F	0.0 F	0.000 F	5.0 F	20.8 F	199.9 F	
11/06/25	03:00	0.0 F	0.040 F	51.8 F	0.0 F	0.0 F	0.0 F	0.000 F	5.7 F	20.8 F	199.9 F	
11/06/25	04:00	0.0 F	0.040 F	43.6 F	0.0 F	0.0 F	0.0 F	0.000 F	4.7 F	20.8 F	199.9 F	
11/06/25	05:00	0.0 F	0.040 F	46.6 F	0.0 F	0.0 F	0.0 F	0.000 F	4.6 F	20.8 F	199.9 F	
11/06/25	06:00	0.0 F	0.040 F	50.6 F	0.0 F	0.0 F	0.0 F	0.000 F	5.3 F	20.8 F	199.9 F	
11/06/25	07:00	0.0 FC	0.011 FC	15.2 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.023 FC	6.1 FC	14.1 FC	199.9 F
11/06/25	08:00	0.0 F	6.614 F	23.5 F	0.0 F	0.0 F	0.0 F	0.000 F	4.7 F	20.9 F	199.9 F	
11/06/25	09:00	0.0 F	6.614 F	48.8 F	0.0 F	0.0 F	0.0 F	0.000 F	4.4 F	20.9 F	199.9 F	
11/06/25	10:00	0.0 F	6.614 F	5.7 F	0.0 F	0.0 F	0.0 F	10.868 F	2.0 F	20.9 F	199.9 F	
11/06/25	11:00	0.0 F	6.614 F	28.4 F	0.0 F	0.0 F	0.0 F	8.694 F	36.2 F	20.9 F	199.9 F	
11/06/25	12:00	0.0 F	6.614 F	11.8 F	0.0 F	0.0 F	0.0 F	0.000 F	3.3 F	20.9 F	199.9 F	
11/06/25	13:00	0.0 F	5.292 F	13.6 F	0.0 F	0.0 F	0.0 F	0.000 F	1.7 F	20.9 F	199.9 F	
11/06/25	14:00	0.0 F	5.292 F	37.7 F	0.0 F	0.0 F	0.0 F	0.000 F	3.3 F	20.9 F	199.9 F	
11/06/25	15:00	0.0 F	6.614 F	28.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.3 F	20.9 F	199.9 F	
11/06/25	16:00	0.0 F	5.292 F	16.3 F	0.0 F	0.0 F	0.0 F	0.000 F	2.6 F	20.9 F	199.9 F	
11/06/25	17:00	0.0 F	5.292 F	28.9 F	0.0 F	0.0 F	0.0 F	0.000 F	2.1 F	20.9 F	199.9 F	

Source		UNIT_C										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
11/06/25	18:00	0.0 F	5.292 F	21.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.3 F	20.9 F	199.9 F
11/06/25	19:00	0.0 F	5.292 F	19.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.8 F	20.9 F	199.9 F
11/06/25	20:00	0.0 F	5.292 F	1.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.9 F	20.9 F	199.9 F
11/06/25	21:00	0.0 F	5.292 F	2.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.1 F	20.9 F	199.9 F
11/06/25	22:00	0.0 F	5.292 F	20.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.7 F	20.9 F	199.9 F
11/06/25	23:00	0.0 F	6.614 F	28.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.0 F	20.9 F	199.9 F
11/07/25	00:00	0.0 F	6.614 F	20.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.9 F	20.9 F	199.9 F
11/07/25	01:00	0.0 F	6.614 F	13.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.5 F	20.9 F	199.9 F
11/07/25	02:00	0.0 F	6.614 F	28.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.7 F	20.9 F	199.9 F
11/07/25	03:00	0.0 F	6.614 F	24.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.0 F	20.9 F	199.9 F
11/07/25	04:00	0.0 F	6.614 F	27.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.0 F	20.9 F	199.9 F
11/07/25	05:00	0.0 F	6.614 F	16.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.4 F	20.9 F	199.9 F
11/07/25	06:00	0.0 F	6.614 F	13.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.2 F	20.9 F	199.9 F
11/07/25	07:00	0.0 FC	0.011 FC	15.0 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.023 FC	4.6 FC	14.2 FC	199.9 F
11/07/25	08:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	4.4 F	21.0 F	199.9 F
11/07/25	09:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	4.6 F	21.0 F	199.9 F
11/07/25	10:00	0.0 F	5.292 F	6.1 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	5.5 F	21.0 F	199.9 F
11/07/25	11:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	3.8 F	21.0 F	199.9 F
11/07/25	12:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	4.6 F	21.0 F	199.9 F
11/07/25	13:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	3.5 F	21.0 F	199.9 F
11/07/25	14:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	4.5 F	20.9 F	199.9 F
11/07/25	15:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	5.1 F	21.0 F	199.9 F
11/07/25	16:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	3.6 F	21.0 F	199.9 F
11/07/25	17:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	3.4 F	21.0 F	199.9 F
11/07/25	18:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	3.7 F	21.0 F	199.9 F
11/07/25	19:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	3.7 F	21.0 F	199.9 F
11/07/25	20:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	4.6 F	21.0 F	199.9 F
11/07/25	21:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	3.9 F	21.0 F	199.9 F
11/07/25	22:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	3.2 F	21.0 F	199.9 F
11/07/25	23:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	3.4 F	21.0 F	199.9 F
11/08/25	00:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	3.6 F	21.0 F	199.9 F
11/08/25	01:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	3.3 F	21.0 F	199.9 F
11/08/25	02:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	3.8 F	21.0 F	199.9 F
11/08/25	03:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	3.8 F	21.0 F	199.9 F
11/08/25	04:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	4.0 F	21.0 F	199.9 F
11/08/25	05:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	6.5 F	21.0 F	199.9 F
11/08/25	06:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	3.6 F	21.0 F	199.9 F

Source		UNIT_C										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
11/08/25	07:00	0.0 FC	0.012 FC	29.5 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.023 FC	5.2 FC	14.2 FC	199.9 F
11/08/25	08:00	0.0 F	7.937 F	120.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.1 F	20.9 F	199.9 F
11/08/25	09:00	0.0 F	7.937 F	74.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.8 F	20.9 F	199.9 F
11/08/25	10:00	0.0 F	7.937 F	102.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.2 F	20.9 F	199.9 F
11/08/25	11:00	0.0 F	7.937 F	88.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.2 F	20.9 F	199.9 F
11/08/25	12:00	0.0 F	7.937 F	83.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.6 F	20.9 F	199.9 F
11/08/25	13:00	0.0 F	7.937 F	92.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.4 F	20.9 F	199.9 F
11/08/25	14:00	0.0 F	7.937 F	113.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	7.3 F	20.9 F	199.9 F
11/08/25	15:00	0.0 F	7.937 F	49.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.9 F	20.9 F	199.9 F
11/08/25	16:00	0.0 F	7.937 F	90.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.3 F	20.9 F	199.9 F
11/08/25	17:00	0.0 F	7.937 F	101.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.0 F	20.9 F	199.9 F
11/08/25	18:00	0.0 F	7.937 F	52.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.9 F	20.9 F	199.9 F
11/08/25	19:00	0.0 F	7.937 F	60.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.2 F	20.9 F	199.9 F
11/08/25	20:00	0.0 F	7.937 F	95.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.2 F	20.9 F	199.9 F
11/08/25	21:00	0.0 F	7.937 F	89.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.4 F	20.9 F	199.9 F
11/08/25	22:00	0.0 F	6.614 F	109.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.7 F	20.9 F	199.9 F
11/08/25	23:00	0.0 F	6.614 F	84.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.8 F	20.9 F	199.9 F
11/09/25	00:00	0.0 F	6.614 F	70.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.2 F	20.9 F	199.9 F
11/09/25	01:00	0.0 F	6.614 F	63.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.7 F	20.9 F	199.9 F
11/09/25	02:00	0.0 F	6.614 F	81.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.7 F	20.9 F	199.9 F
11/09/25	03:00	0.0 F	6.614 F	67.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.4 F	20.9 F	199.9 F
11/09/25	04:00	0.0 F	7.937 F	97.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.9 F	20.9 F	199.9 F
11/09/25	05:00	0.0 F	7.937 F	107.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.8 F	20.9 F	199.9 F
11/09/25	06:00	0.0 F	7.937 F	55.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.1 F	20.9 F	199.9 F
11/09/25	07:00	0.0 FC	0.011 FC	35.4 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.023 FC	3.9 FC	14.2 FC	199.9 F
11/09/25	08:00	0.0 F	5.292 F	19.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.4 F	20.9 F	199.9 F
11/09/25	09:00	0.0 F	5.292 F	25.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.0 F	20.9 F	199.9 F
11/09/25	10:00	0.0 F	5.292 F	7.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.1 F	21.0 F	199.9 F
11/09/25	11:00	0.0 F	5.292 F	19.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.6 F	21.0 F	199.9 F
11/09/25	12:00	0.0 F	5.292 F	27.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.7 F	21.0 F	199.9 F
11/09/25	13:00	0.0 F	5.292 F	54.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.3 F	20.9 F	199.9 F
11/09/25	14:00	0.0 F	5.292 F	4.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.2 F	21.0 F	199.9 F
11/09/25	15:00	0.0 F	5.292 F	7.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.5 F	21.0 F	199.9 F
11/09/25	16:00	0.0 F	5.292 F	33.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.3 F	20.9 F	199.9 F
11/09/25	17:00	0.0 F	5.292 F	14.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.4 F	21.0 F	199.9 F
11/09/25	18:00	0.0 F	5.292 F	10.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	21.0 F	199.9 F
11/09/25	19:00	0.0 F	5.292 F	0.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.1 F	21.0 F	199.9 F

Source	Parameter Unit	UNIT_C										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
11/09/25	20:00	0.0 F	5.292 F	0.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.9 F	20.9 F	199.9 F
11/09/25	21:00	0.0 F	5.292 F	10.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.2 F	21.0 F	199.9 F
11/09/25	22:00	0.0 F	5.292 F	8.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.3 F	21.0 F	199.9 F
11/09/25	23:00	0.0 F	5.292 F	10.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.9 F	20.9 F	199.9 F
11/10/25	00:00	0.0 F	5.292 F	18.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.5 F	20.9 F	199.9 F
11/10/25	01:00	0.0 F	5.292 F	13.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	21.0 F	199.9 F
11/10/25	02:00	0.0 F	5.292 F	24.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.1 F	21.0 F	199.9 F
11/10/25	03:00	0.0 F	5.292 F	11.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.6 F	21.0 F	199.9 F
11/10/25	04:00	0.0 F	5.292 F	14.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.2 F	21.0 F	199.9 F
11/10/25	05:00	0.0 F	5.292 F	30.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.2 F	20.9 F	199.9 F
11/10/25	06:00	0.0 F	5.292 F	22.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.2 F	20.9 F	199.9 F
11/10/25	07:00	0.0 FC	0.013 FC	3.9 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.023 FC	3.7 FC	14.2 FC	199.9 F
11/10/25	08:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
11/10/25	09:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
11/10/25	10:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
11/10/25	11:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
11/10/25	12:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
11/10/25	13:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
11/10/25	14:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
11/10/25	15:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
11/10/25	16:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
11/10/25	17:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
11/10/25	18:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/10/25	19:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
11/10/25	20:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
11/10/25	21:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/10/25	22:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
11/10/25	23:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
11/11/25	00:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
11/11/25	01:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/11/25	02:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
11/11/25	03:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
11/11/25	04:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
11/11/25	05:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
11/11/25	06:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
11/11/25	07:00	0.0 FMC	0.012 FMC	35.7 FMC	0.0 F	0.0 F	0.0 FMC	0.0 FMC	0.023 FMC	3.6 FMC	14.2 FMC	199.9 F
11/11/25	08:00	0.0 F	6.614 F	68.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.1 F	20.9 F	199.9 F

Source Parameter Unit		UNIT_C										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
11/11/25	09:00	0.0 F	6.614 F	80.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.6 F	20.9 F	199.8 F
11/11/25	10:00	0.0 F	6.614 F	76.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.0 F	20.9 F	199.9 F
11/11/25	11:00	0.0 F	6.614 F	69.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.2 F	20.9 F	199.9 F
11/11/25	12:00	0.0 F	6.614 F	67.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.1 F	20.9 F	199.8 F
11/11/25	13:00	0.0 F	6.614 F	68.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.0 F	20.9 F	199.9 F
11/11/25	14:00	0.0 F	6.614 F	66.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.8 F	20.9 F	199.9 F
11/11/25	15:00	0.0 F	6.614 F	84.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.5 F	20.9 F	199.9 F
11/11/25	16:00	0.0 F	6.614 F	84.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.0 F	20.9 F	199.9 F
11/11/25	17:00	0.0 F	6.614 F	52.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.3 F	20.9 F	199.9 F
11/11/25	18:00	0.0 F	6.614 F	96.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	6.1 F	20.9 F	199.9 F
11/11/25	19:00	0.0 F	6.614 F	72.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.7 F	20.9 F	199.9 F
11/11/25	20:00	0.0 F	6.614 F	67.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.9 F	20.9 F	199.9 F
11/11/25	21:00	0.0 F	6.614 F	56.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.7 F	20.9 F	199.9 F
11/11/25	22:00	0.0 F	6.614 F	92.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	6.7 F	20.9 F	199.9 F
11/11/25	23:00	0.0 F	7.937 F	79.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.2 F	20.9 F	199.9 F
11/12/25	00:00	0.0 F	6.614 F	102.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	6.2 F	20.9 F	199.9 F
11/12/25	01:00	0.0 F	6.614 F	109.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	7.1 F	20.9 F	199.9 F
11/12/25	02:00	0.0 F	6.614 F	96.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.4 F	20.9 F	199.9 F
11/12/25	03:00	0.0 F	6.614 F	57.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.0 F	20.9 F	199.9 F
11/12/25	04:00	0.0 F	6.614 F	42.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.0 F	20.9 F	199.9 F
11/12/25	05:00	0.0 F	6.614 F	70.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.1 F	20.9 F	199.9 F
11/12/25	06:00	0.0 F	6.614 F	92.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	6.5 F	20.9 F	199.9 F
11/12/25	07:00	0.0 FC	0.011 FC	34.1 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.023 FC	4.1 FC	14.2 FC	199.9 F
11/12/25	08:00	0.0 F	6.614 F	57.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.1 F	20.9 F	199.9 F
11/12/25	09:00	0.0 F	5.292 F	77.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.7 F	20.9 F	199.9 F
11/12/25	10:00	0.0 F	5.292 F	100.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	10.5 F	20.9 F	199.9 F
11/12/25	11:00	0.0 F	5.292 F	66.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	7.1 F	20.9 F	199.9 F
11/12/25	12:00	0.0 F	5.292 F	86.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	7.3 F	20.9 F	199.9 F
11/12/25	13:00	0.0 F	5.292 F	93.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	8.5 F	20.9 F	199.9 F
11/12/25	14:00	0.0 F	6.614 F	66.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.8 F	20.9 F	199.9 F
11/12/25	15:00	0.0 F	5.292 F	97.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	8.5 F	20.9 F	199.9 F
11/12/25	16:00	0.0 F	5.292 F	63.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	6.0 F	20.9 F	199.9 F
11/12/25	17:00	0.0 F	5.292 F	122.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	11.7 F	20.9 F	199.9 F
11/12/25	18:00	0.0 F	5.292 F	89.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	7.2 F	20.9 F	199.9 F
11/12/25	19:00	0.0 F	5.292 F	87.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	8.3 F	20.9 F	199.9 F
11/12/25	20:00	0.0 F	5.292 F	73.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.8 F	20.9 F	199.9 F
11/12/25	21:00	0.0 F	5.292 F	75.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	6.5 F	20.9 F	199.9 F

Source	Parameter Unit	UNIT_C										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
11/12/25	22:00	0.0 F	5.292 F	74.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	7.4 F	20.9 F	199.9 F
11/12/25	23:00	0.0 F	5.292 F	133.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	10.9 F	20.9 F	199.9 F
11/13/25	00:00	0.0 F	5.292 F	89.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	7.6 F	20.9 F	199.9 F
11/13/25	01:00	0.0 F	5.292 F	97.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	8.5 F	20.9 F	199.9 F
11/13/25	02:00	0.0 F	5.292 F	110.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	8.1 F	20.9 F	199.9 F
11/13/25	03:00	0.0 F	5.292 F	111.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	9.8 F	20.9 F	199.9 F
11/13/25	04:00	0.0 F	5.292 F	86.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	7.1 F	20.9 F	199.9 F
11/13/25	05:00	0.0 F	5.292 F	75.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.1 F	20.9 F	199.9 F
11/13/25	06:00	0.0 F	5.292 F	95.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	8.6 F	20.9 F	199.9 F
11/13/25	07:00	0.0 FC	0.011 FC	52.2 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.023 FC	7.1 FC	14.2 FC	199.9 F
11/13/25	08:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/13/25	09:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/13/25	10:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/13/25	11:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/13/25	12:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/13/25	13:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/13/25	14:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/13/25	15:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/13/25	16:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/13/25	17:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/13/25	18:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/13/25	19:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/13/25	20:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/13/25	21:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/13/25	22:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	21.0 F	199.9 F
11/13/25	23:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/14/25	00:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/14/25	01:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/14/25	02:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/14/25	03:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/14/25	04:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/14/25	05:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/14/25	06:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/14/25	07:00	0.0 FC	0.011 FC	4.8 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.023 FC	2.8 FC	14.2 FC	199.9 F
11/14/25	08:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/14/25	09:00	0.0 F	5.292 F	0.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/14/25	10:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F

Source		UNIT_C										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
11/14/25	11:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/14/25	12:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/14/25	13:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/14/25	14:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/14/25	15:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/14/25	16:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/14/25	17:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/14/25	18:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/14/25	19:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/14/25	20:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/14/25	21:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/14/25	22:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/14/25	23:00	0.0 F	5.292 F	0.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/15/25	00:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/15/25	01:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/15/25	02:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/15/25	03:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
11/15/25	04:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/15/25	05:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/15/25	06:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/15/25	07:00	0.0 FC	0.012 FC	2.0 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.023 FC	2.7 FC	14.2 FC	199.9 F
11/15/25	08:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/15/25	09:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/15/25	10:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/15/25	11:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/15/25	12:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/15/25	13:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	21.0 F	199.9 F
11/15/25	14:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	21.0 F	199.9 F
11/15/25	15:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/15/25	16:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/15/25	17:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/15/25	18:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/15/25	19:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/15/25	20:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/15/25	21:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/15/25	22:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/15/25	23:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	20.9 F	199.9 F

Source Parameter Unit	UNIT_C										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
11/16/25 00:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	21.0 F	199.9 F
11/16/25 01:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/16/25 02:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.8 F
11/16/25 03:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/16/25 04:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/16/25 05:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/16/25 06:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/16/25 07:00	0.0 FC	0.011 FC	5.9 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.023 FC	5.0 FC	14.2 FC	199.9 F
11/16/25 08:00	0.0 F	5.292 F	37.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	7.2 F	20.9 F	199.9 F
11/16/25 09:00	0.0 F	5.292 F	15.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.3 F	20.9 F	199.9 F
11/16/25 10:00	0.0 F	5.292 F	31.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.0 F	20.9 F	199.9 F
11/16/25 11:00	0.0 F	5.292 F	29.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.4 F	20.9 F	199.9 F
11/16/25 12:00	0.0 F	5.292 F	19.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.5 F	20.9 F	199.9 F
11/16/25 13:00	0.0 F	5.292 F	26.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.2 F	20.9 F	199.8 F
11/16/25 14:00	0.0 F	5.292 F	4.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.3 F	20.9 F	199.9 F
11/16/25 15:00	0.0 F	5.292 F	12.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.9 F	20.9 F	199.9 F
11/16/25 16:00	0.0 F	5.292 F	20.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.2 F	20.9 F	199.9 F
11/16/25 17:00	0.0 F	5.292 F	5.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.4 F	20.9 F	199.9 F
11/16/25 18:00	0.0 F	5.292 F	10.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.4 F	20.9 F	199.9 F
11/16/25 19:00	0.0 F	5.292 F	31.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	7.2 F	20.9 F	199.9 F
11/16/25 20:00	0.0 F	5.292 F	5.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.8 F	20.9 F	199.9 F
11/16/25 21:00	0.0 F	5.292 F	3.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.0 F	20.9 F	199.9 F
11/16/25 22:00	0.0 F	5.292 F	14.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.5 F	20.9 F	199.9 F
11/16/25 23:00	0.0 F	5.292 F	2.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.1 F	20.9 F	199.9 F
11/17/25 00:00	0.0 F	5.292 F	7.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.0 F	20.9 F	199.9 F
11/17/25 01:00	0.0 F	5.292 F	11.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	7.6 F	20.9 F	199.8 F
11/17/25 02:00	0.0 F	5.292 F	9.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.7 F	20.9 F	199.9 F
11/17/25 03:00	0.0 F	5.292 F	3.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.6 F	20.9 F	199.9 F
11/17/25 04:00	0.0 F	5.292 F	12.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.2 F	20.9 F	199.9 F
11/17/25 05:00	0.0 F	5.292 F	4.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.8 F	20.9 F	199.9 F
11/17/25 06:00	0.0 F	5.292 F	2.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.4 F	20.9 F	199.9 F
11/17/25 07:00	0.0 FC	0.011 FC	2.0 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.023 FC	3.9 FC	14.2 FC	199.9 F
11/17/25 08:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.8 F	21.0 F	199.9 F
11/17/25 09:00	0.0 F	6.614 F	7.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.5 F	21.0 F	199.9 F
11/17/25 10:00	0.0 F	6.614 F	15.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.7 F	21.0 F	199.9 F
11/17/25 11:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.5 F	21.0 F	199.9 F
11/17/25 12:00	0.0 F	6.614 F	5.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.3 F	21.0 F	199.9 F

Source	Parameter Unit	UNIT_C										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
11/17/25	13:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.5 F	21.0 F	199.9 F
11/17/25	14:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.5 F	21.0 F	199.9 F
11/17/25	15:00	0.0 F	6.614 F	3.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.5 F	20.9 F	199.9 F
11/17/25	16:00	0.0 F	6.614 F	12.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.4 F	21.0 F	199.9 F
11/17/25	17:00	0.0 F	6.614 F	11.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.0 F	21.0 F	199.9 F
11/17/25	18:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.4 F	21.0 F	199.9 F
11/17/25	19:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	21.0 F	199.9 F
11/17/25	20:00	0.0 F	6.614 F	2.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.9 F	21.0 F	199.9 F
11/17/25	21:00	0.0 F	6.614 F	7.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.4 F	21.0 F	199.9 F
11/17/25	22:00	0.0 F	6.614 F	8.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	21.0 F	199.9 F
11/17/25	23:00	0.0 F	6.614 F	2.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	21.0 F	199.9 F
11/18/25	00:00	0.0 F	6.614 F	0.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.0 F	21.0 F	199.9 F
11/18/25	01:00	0.0 F	6.614 F	5.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.7 F	21.0 F	199.9 F
11/18/25	02:00	0.0 F	6.614 F	2.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.6 F	21.0 F	199.9 F
11/18/25	03:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	21.0 F	199.9 F
11/18/25	04:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	21.0 F	199.9 F
11/18/25	05:00	0.0 F	6.614 F	19.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.0 F	21.0 F	199.9 F
11/18/25	06:00	0.0 F	6.614 F	18.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.5 F	21.0 F	199.9 F
11/18/25	07:00	0.0 FC	0.011 FC	1.9 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.023 FC	3.1 FC	14.2 FC	199.9 F
11/18/25	08:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/18/25	09:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/18/25	10:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
11/18/25	11:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	21.0 F	199.9 F
11/18/25	12:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	21.0 F	199.9 F
11/18/25	13:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
11/18/25	14:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/18/25	15:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/18/25	16:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/18/25	17:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/18/25	18:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	21.0 F	199.9 F
11/18/25	19:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/18/25	20:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/18/25	21:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
11/18/25	22:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	21.0 F	199.9 F
11/18/25	23:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/19/25	00:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/19/25	01:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F

Source	Parameter Unit	UNIT_C										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
11/19/25	02:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/19/25	03:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/19/25	04:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/19/25	05:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/19/25	06:00	0.2 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	21.0 F	199.9 F
11/19/25	07:00	2.6 FC	0.012 FC	7.6 FC	0.0 F	0.0 F	0.0 FC	0.6 FC	0.023 FC	3.8 FC	14.2 FC	199.9 F
11/19/25	08:00	0.0 F	6.614 F	39.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.7 F	20.9 F	199.9 F
11/19/25	09:00	0.0 FM	0.002 FM	9.2 FM	0.0 F	0.0 F	0.0 FM	0.0 FM	0.000 FM	2.6 FM	18.6 FM	199.9 F
11/19/25	10:00	0.0 FM	0.009 FM	21.5 FM	0.0 F	0.0 F	0.0 FM	0.0 FM	0.018 FM	4.1 FM	3.8 FM	199.8 F
11/19/25	11:00	0.0 FMC	0.007 FMC	5.9 FMC	0.0 F	0.0 F	0.0 FMC	0.0 FMC	0.015 FMC	3.0 FMC	8.9 FMC	199.8 F
11/19/25	12:00	0.0 FC	0.014 FC	20.8 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.027 FC	2.7 FC	15.3 FC	199.9 F
11/19/25	13:00	0.0 F	0.066 F	24.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	20.8 F	199.9 F
11/19/25	14:00	0.1 F	0.053 F	22.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	20.8 F	199.9 F
11/19/25	15:00	0.0 F	0.053 F	23.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	20.8 F	199.9 F
11/19/25	16:00	0.0 F	0.053 F	20.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	20.8 F	199.9 F
11/19/25	17:00	0.5 F	0.053 F	21.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	20.8 F	199.9 F
11/19/25	18:00	0.0 F	0.053 F	20.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	20.8 F	199.9 F
11/19/25	19:00	0.0 F	0.053 F	20.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	20.8 F	199.9 F
11/19/25	20:00	0.0 F	0.053 F	21.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	20.8 F	199.9 F
11/19/25	21:00	0.0 F	0.053 F	20.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	20.8 F	199.9 F
11/19/25	22:00	0.0 F	0.053 F	21.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	20.8 F	199.9 F
11/19/25	23:00	0.0 F	0.053 F	22.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	20.8 F	199.9 F
11/20/25	00:00	0.0 F	0.053 F	20.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	20.8 F	199.9 F
11/20/25	01:00	0.0 F	0.053 F	20.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	20.8 F	199.9 F
11/20/25	02:00	0.0 F	0.053 F	20.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	20.8 F	199.9 F
11/20/25	03:00	0.0 F	0.053 F	20.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	20.8 F	199.9 F
11/20/25	04:00	0.0 F	0.066 F	22.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	20.8 F	199.9 F
11/20/25	05:00	0.0 F	0.053 F	20.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	20.8 F	199.9 F
11/20/25	06:00	0.0 F	0.053 F	22.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	20.8 F	199.9 F
11/20/25	07:00	0.0 FC	0.011 FC	15.2 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.023 FC	3.4 FC	14.1 FC	199.9 F
11/20/25	08:00	0.0 F	5.292 F	44.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	20.9 F	199.9 F
11/20/25	09:00	0.0 F	5.292 F	54.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.3 F	20.9 F	199.9 F
11/20/25	10:00	0.0 F	5.292 F	55.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.7 F	20.9 F	199.9 F
11/20/25	11:00	0.0 F	5.292 F	58.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.9 F	20.9 F	199.9 F
11/20/25	12:00	0.0 F	5.292 F	63.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.1 F	20.9 F	199.9 F
11/20/25	13:00	0.0 F	5.292 F	58.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	6.3 F	20.9 F	199.9 F
11/20/25	14:00	0.0 F	5.292 F	29.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.5 F	20.9 F	199.9 F

Source		UNIT_C										
Parameter Unit		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
11/20/25	15:00	0.0 F	5.292 F	51.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.5 F	20.9 F	199.9 F
11/20/25	16:00	0.0 F	5.292 F	52.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.6 F	20.9 F	199.9 F
11/20/25	17:00	0.0 F	5.292 F	74.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	9.0 F	20.9 F	199.9 F
11/20/25	18:00	0.0 F	5.292 F	62.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.7 F	20.9 F	199.9 F
11/20/25	19:00	0.0 F	5.292 F	34.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.6 F	20.9 F	199.9 F
11/20/25	20:00	0.0 F	5.292 F	54.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.6 F	20.9 F	199.9 F
11/20/25	21:00	0.0 F	5.292 F	64.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	6.8 F	20.9 F	199.9 F
11/20/25	22:00	0.0 F	5.292 F	84.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.7 F	20.9 F	199.9 F
11/20/25	23:00	0.0 F	5.292 F	90.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.2 F	20.9 F	199.9 F
11/21/25	00:00	0.0 F	5.292 F	36.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.6 F	20.9 F	199.9 F
11/21/25	01:00	0.0 F	5.292 F	40.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.6 F	20.9 F	199.9 F
11/21/25	02:00	0.0 F	5.292 F	53.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.0 F	20.9 F	199.9 F
11/21/25	03:00	0.0 F	5.292 F	37.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.2 F	20.9 F	199.9 F
11/21/25	04:00	0.0 F	5.292 F	36.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.1 F	20.9 F	199.9 F
11/21/25	05:00	0.0 F	5.292 F	47.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.4 F	20.9 F	199.9 F
11/21/25	06:00	0.0 FM	5.292 FM	47.8 FM	0.0 F	0.0 F	0.0 FM	0.0 FM	0.000 FM	2.6 FM	20.9 FM	199.9 F
11/21/25	07:00	0.0 FC	0.011 FC	30.9 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.024 FC	4.8 FC	14.2 FC	199.9 F
11/21/25	08:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/21/25	09:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	21.0 F	199.9 F
11/21/25	10:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/21/25	11:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.6 F	21.0 F	199.9 F
11/21/25	12:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/21/25	13:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
11/21/25	14:00	0.0 F	6.614 F	7.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.5 F	21.0 F	199.9 F
11/21/25	15:00	0.0 F	6.614 F	4.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.9 F	21.0 F	199.9 F
11/21/25	16:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	21.0 F	199.9 F
11/21/25	17:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/21/25	18:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/21/25	19:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.9 F	21.0 F	199.9 F
11/21/25	20:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/21/25	21:00	0.0 F	6.614 F	1.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	21.0 F	199.9 F
11/21/25	22:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/21/25	23:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/22/25	00:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/22/25	01:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
11/22/25	02:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
11/22/25	03:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F

Source		UNIT_C										
Parameter Unit		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
11/22/25	04:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	21.0 F	199.9 F
11/22/25	05:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/22/25	06:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
11/22/25	07:00	0.0 FC	0.011 FC	2.8 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.024 FC	3.1 FC	14.2 FC	199.9 F
11/22/25	08:00	0.0 F	5.292 F	5.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/22/25	09:00	0.0 F	5.292 F	7.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/22/25	10:00	0.0 F	5.292 F	4.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/22/25	11:00	0.0 F	5.292 F	7.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	21.0 F	199.9 F
11/22/25	12:00	0.0 F	5.292 F	3.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/22/25	13:00	0.0 F	6.614 F	9.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
11/22/25	14:00	0.0 F	5.292 F	1.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/22/25	15:00	0.0 F	6.614 F	6.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/22/25	16:00	0.0 F	5.292 F	0.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/22/25	17:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/22/25	18:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/22/25	19:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/22/25	20:00	0.0 F	5.292 F	6.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/22/25	21:00	0.0 F	5.292 F	0.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/22/25	22:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/22/25	23:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/23/25	00:00	0.0 F	5.292 F	21.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.4 F	21.0 F	199.9 F
11/23/25	01:00	0.0 F	5.292 F	1.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
11/23/25	02:00	0.0 F	5.292 F	2.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
11/23/25	03:00	0.0 F	5.292 F	0.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/23/25	04:00	0.0 F	5.292 F	10.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	21.0 F	199.9 F
11/23/25	05:00	0.0 F	5.292 F	6.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/23/25	06:00	0.0 F	5.292 F	2.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/23/25	07:00	0.0 FC	0.011 FC	3.6 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.024 FC	2.6 FC	14.2 FC	199.9 F
11/23/25	08:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	21.0 F	199.9 F
11/23/25	09:00	0.0 F	6.614 F	10.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
11/23/25	10:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.7 F	21.0 F	199.9 F
11/23/25	11:00	0.0 F	6.614 F	0.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.4 F	21.0 F	199.9 F
11/23/25	12:00	0.0 F	6.614 F	3.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.6 F	21.0 F	199.9 F
11/23/25	13:00	0.0 F	6.614 F	1.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.8 F	21.0 F	199.9 F
11/23/25	14:00	0.0 F	6.614 F	1.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	21.0 F	199.9 F
11/23/25	15:00	0.0 F	6.614 F	2.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
11/23/25	16:00	0.0 F	6.614 F	5.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	21.0 F	199.9 F

Source	Parameter Unit	UNIT_C										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
11/23/25	17:00	0.0 F	6.614 F	6.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
11/23/25	18:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
11/23/25	19:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.4 F	21.0 F	199.9 F
11/23/25	20:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	21.0 F	199.9 F
11/23/25	21:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.6 F	21.0 F	199.9 F
11/23/25	22:00	0.0 F	5.292 F	0.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/23/25	23:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
11/24/25	00:00	0.0 F	5.292 F	1.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.4 F	21.0 F	199.9 F
11/24/25	01:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	21.0 F	199.9 F
11/24/25	02:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
11/24/25	03:00	0.0 F	5.292 F	1.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	21.0 F	199.9 F
11/24/25	04:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.6 F	21.0 F	199.9 F
11/24/25	05:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/24/25	06:00	0.0 F	5.292 F	1.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.0 F	21.0 F	199.9 F
11/24/25	07:00	0.0 FC	0.011 FC	6.2 FC	0.0 F	0.0 F	0.0 FC	0.1 FC	0.024 FC	8.9 FC	14.2 FC	199.9 F
11/24/25	08:00	0.0 F	6.614 F	52.2 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	13.5 F	20.9 F	199.9 F
11/24/25	09:00	0.0 F	6.614 F	47.6 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	14.8 F	20.9 F	199.9 F
11/24/25	10:00	0.0 F	6.614 F	30.1 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	13.0 F	20.9 F	199.9 F
11/24/25	11:00	0.0 F	6.614 F	27.8 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	17.5 F	20.9 F	199.9 F
11/24/25	12:00	0.0 F	6.614 F	53.6 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	11.7 F	20.9 F	199.9 F
11/24/25	13:00	0.0 F	6.614 F	42.0 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	13.3 F	20.9 F	199.9 F
11/24/25	14:00	0.0 F	6.614 F	40.6 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	12.9 F	20.9 F	199.9 F
11/24/25	15:00	0.0 F	6.614 F	19.7 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	12.3 F	20.9 F	199.9 F
11/24/25	16:00	0.0 F	6.614 F	42.1 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	11.9 F	20.9 F	199.9 F
11/24/25	17:00	0.0 F	6.614 F	54.8 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	13.7 F	20.9 F	199.9 F
11/24/25	18:00	0.0 F	6.614 F	49.8 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	14.6 F	20.9 F	199.9 F
11/24/25	19:00	0.0 F	6.614 F	22.3 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	14.1 F	20.9 F	199.9 F
11/24/25	20:00	0.0 F	6.614 F	26.6 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	13.9 F	20.9 F	199.9 F
11/24/25	21:00	0.0 F	6.614 F	42.4 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	15.2 F	20.9 F	199.9 F
11/24/25	22:00	0.0 F	6.614 F	38.4 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	10.6 F	20.9 F	199.9 F
11/24/25	23:00	0.0 F	6.614 F	44.7 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	10.5 F	20.9 F	199.9 F
11/25/25	00:00	0.0 F	6.614 F	21.1 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	10.7 F	20.9 F	199.9 F
11/25/25	01:00	0.0 F	6.614 F	40.0 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	12.4 F	20.9 F	199.9 F
11/25/25	02:00	0.0 F	6.614 F	21.7 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	10.1 F	20.9 F	199.9 F
11/25/25	03:00	0.0 F	6.614 F	60.1 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	10.7 F	20.9 F	199.9 F
11/25/25	04:00	0.0 F	6.614 F	82.6 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	11.8 F	20.9 F	199.9 F
11/25/25	05:00	0.0 F	6.614 F	41.6 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	12.1 F	20.9 F	199.9 F

Source	Parameter Unit	UNIT_C										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
11/25/25	06:00	0.0 F	6.614 F	32.4 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	13.9 F	20.9 F	199.9 F
11/25/25	07:00	0.0 FC	0.012 FC	12.1 FC	0.0 F	0.0 F	0.0 FC	0.1 FC	0.024 FC	7.4 FC	14.2 FC	199.9 F
11/25/25	08:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	3.7 F	21.0 F	199.9 F
11/25/25	09:00	0.0 F	6.614 F	24.5 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	5.4 F	21.0 F	199.9 F
11/25/25	10:00	0.0 F	6.614 F	26.3 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	5.4 F	21.0 F	199.9 F
11/25/25	11:00	0.0 F	6.614 F	9.1 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	4.0 F	21.0 F	199.9 F
11/25/25	12:00	0.0 F	6.614 F	15.3 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	4.7 F	21.0 F	199.9 F
11/25/25	13:00	0.0 F	6.614 F	11.7 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	4.6 F	21.0 F	199.9 F
11/25/25	14:00	0.0 F	6.614 F	7.5 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	6.1 F	21.0 F	199.9 F
11/25/25	15:00	0.0 F	6.614 F	5.7 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	4.6 F	21.0 F	199.9 F
11/25/25	16:00	0.0 F	6.614 F	4.1 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	5.0 F	21.0 F	199.9 F
11/25/25	17:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	5.1 F	21.0 F	199.9 F
11/25/25	18:00	0.0 F	6.614 F	3.8 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	5.7 F	21.0 F	199.9 F
11/25/25	19:00	0.0 F	6.614 F	24.5 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	6.5 F	21.0 F	199.9 F
11/25/25	20:00	0.0 F	6.614 F	30.2 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	3.6 F	21.0 F	199.9 F
11/25/25	21:00	0.0 F	6.614 F	8.5 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	5.7 F	21.0 F	199.9 F
11/25/25	22:00	0.0 F	6.614 F	12.5 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	4.5 F	21.0 F	199.9 F
11/25/25	23:00	0.0 F	6.614 F	7.4 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	4.8 F	20.9 F	199.9 F
11/26/25	00:00	0.0 F	6.614 F	2.9 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	6.3 F	21.0 F	199.9 F
11/26/25	01:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	6.7 F	21.0 F	199.9 F
11/26/25	02:00	0.0 F	6.614 F	23.3 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	6.0 F	21.0 F	199.9 F
11/26/25	03:00	0.0 F	6.614 F	22.7 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	4.0 F	21.0 F	199.9 F
11/26/25	04:00	0.0 F	6.614 F	0.9 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	5.3 F	21.0 F	199.9 F
11/26/25	05:00	0.0 F	6.614 F	3.7 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	5.6 F	21.0 F	199.9 F
11/26/25	06:00	0.0 F	6.614 F	8.9 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	4.5 F	21.0 F	199.9 F
11/26/25	07:00	0.0 FC	0.012 FC	1.7 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.024 FC	3.7 FC	14.2 FC	199.9 F
11/26/25	08:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/26/25	09:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
11/26/25	10:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/26/25	11:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/26/25	12:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/26/25	13:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/26/25	14:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/26/25	15:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/26/25	16:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/26/25	17:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/26/25	18:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F

Source		UNIT_C										
Parameter Unit		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
11/26/25	19:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/26/25	20:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	21.0 F	199.9 F
11/26/25	21:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/26/25	22:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/26/25	23:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/27/25	00:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/27/25	01:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/27/25	02:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/27/25	03:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/27/25	04:00	0.0 F	6.614 F	1.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/27/25	05:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/27/25	06:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/27/25	07:00	0.0 FC	0.011 FC	3.1 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.024 FC	2.8 FC	14.2 FC	199.9 F
11/27/25	08:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/27/25	09:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/27/25	10:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/27/25	11:00	0.0 F	6.614 F	1.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/27/25	12:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/27/25	13:00	0.0 F	6.614 F	3.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/27/25	14:00	0.0 F	6.614 F	11.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/27/25	15:00	0.0 F	6.614 F	3.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/27/25	16:00	0.0 F	6.614 F	0.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/27/25	17:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/27/25	18:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	21.0 F	199.9 F
11/27/25	19:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/27/25	20:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/27/25	21:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
11/27/25	22:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/27/25	23:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/28/25	00:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
11/28/25	01:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/28/25	02:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	21.0 F	199.9 F
11/28/25	03:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/28/25	04:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/28/25	05:00	0.0 F	5.292 F	7.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
11/28/25	06:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
11/28/25	07:00	0.0 FC	0.012 FC	35.8 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.024 FC	4.6 FC	14.2 FC	199.9 F

Source Parameter Unit	UNIT_C										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
11/28/25 08:00	0.0 F	6.614 F	42.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.9 F	20.9 F	199.9 F
11/28/25 09:00	0.0 F	6.614 F	99.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.9 F	20.9 F	199.9 F
11/28/25 10:00	0.0 F	6.614 F	75.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.0 F	20.9 F	199.9 F
11/28/25 11:00	0.0 F	6.614 F	77.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.0 F	20.9 F	199.9 F
11/28/25 12:00	0.0 F	6.614 F	108.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	6.2 F	20.9 F	199.9 F
11/28/25 13:00	0.0 F	6.614 F	144.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	6.9 F	20.9 F	199.9 F
11/28/25 14:00	0.0 F	6.614 F	117.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.2 F	20.9 F	199.9 F
11/28/25 15:00	0.0 F	6.614 F	81.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.3 F	20.9 F	199.9 F
11/28/25 16:00	0.0 F	6.614 F	102.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	6.1 F	20.9 F	199.9 F
11/28/25 17:00	0.0 F	6.614 F	76.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.0 F	20.9 F	199.9 F
11/28/25 18:00	0.0 F	6.614 F	134.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	6.5 F	20.9 F	199.9 F
11/28/25 19:00	0.0 F	6.614 F	113.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.6 F	20.9 F	199.9 F
11/28/25 20:00	0.0 F	6.614 F	86.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.4 F	20.9 F	199.9 F
11/28/25 21:00	0.0 F	6.614 F	53.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.8 F	20.9 F	199.9 F
11/28/25 22:00	0.0 F	6.614 F	73.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.5 F	20.9 F	199.9 F
11/28/25 23:00	0.0 F	6.614 F	120.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.4 F	20.9 F	199.9 F
11/29/25 00:00	0.0 F	6.614 F	108.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.6 F	20.9 F	199.9 F
11/29/25 01:00	0.0 F	6.614 F	90.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.4 F	20.9 F	199.9 F
11/29/25 02:00	0.0 F	6.614 F	87.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.6 F	20.9 F	199.9 F
11/29/25 03:00	0.0 F	6.614 F	65.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.8 F	20.9 F	199.9 F
11/29/25 04:00	0.0 F	6.614 F	88.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.5 F	20.9 F	199.9 F
11/29/25 05:00	0.0 F	6.614 F	118.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	6.0 F	20.9 F	199.9 F
11/29/25 06:00	0.0 F	6.614 F	101.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.2 F	20.9 F	199.9 F
11/29/25 07:00	0.0 FC	0.011 FC	43.8 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.023 FC	4.1 FC	14.1 FC	199.9 F
11/29/25 08:00	0.0 F	6.614 F	73.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.4 F	20.9 F	199.9 F
11/29/25 09:00	0.0 F	6.614 F	78.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.3 F	20.9 F	199.9 F
11/29/25 10:00	0.0 F	6.614 F	90.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.8 F	20.9 F	199.9 F
11/29/25 11:00	0.0 F	6.614 F	100.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.6 F	20.9 F	199.9 F
11/29/25 12:00	0.0 F	6.614 F	45.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.3 F	20.9 F	199.9 F
11/29/25 13:00	0.0 F	6.614 F	102.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.9 F	20.9 F	199.9 F
11/29/25 14:00	0.0 F	6.614 F	43.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.5 F	20.9 F	199.9 F
11/29/25 15:00	0.0 F	7.937 F	42.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.1 F	20.9 F	199.9 F
11/29/25 16:00	0.0 F	6.614 F	133.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.1 F	20.9 F	199.9 F
11/29/25 17:00	0.0 F	6.614 F	91.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.1 F	20.9 F	199.9 F
11/29/25 18:00	0.0 F	6.614 F	76.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.3 F	20.9 F	199.9 F
11/29/25 19:00	0.0 F	6.614 F	77.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	3.5 F	20.9 F	199.9 F
11/29/25 20:00	0.0 F	6.614 F	69.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.6 F	20.9 F	199.9 F

Source		UNIT_C										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
11/29/25	21:00	0.0 F	6.614 F	102.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.2 F	20.9 F	199.9 F
11/29/25	22:00	0.0 F	6.614 F	66.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.0 F	20.9 F	199.9 F
11/29/25	23:00	0.0 F	6.614 F	98.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.1 F	20.9 F	199.9 F
11/30/25	00:00	0.0 F	6.614 F	76.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	7.8 F	20.9 F	199.9 F
11/30/25	01:00	0.0 F	6.614 F	88.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.8 F	20.9 F	199.9 F
11/30/25	02:00	0.0 F	6.614 F	67.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	6.6 F	20.9 F	199.9 F
11/30/25	03:00	0.0 F	6.614 F	85.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.7 F	20.9 F	199.9 F
11/30/25	04:00	0.0 F	6.614 F	52.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.9 F	20.9 F	199.9 F
11/30/25	05:00	0.0 F	6.614 F	70.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.4 F	20.9 F	199.9 F
11/30/25	06:00	0.0 F	6.614 F	53.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.3 F	20.9 F	199.9 F
11/30/25	07:00	0.0 FC	0.012 FC	49.7 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.024 FC	3.8 FC	14.2 FC	199.9 F
11/30/25	08:00	0.0 F	7.937 F	77.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	6.7 F	20.9 F	199.9 F
11/30/25	09:00	0.0 F	7.937 F	35.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.4 F	20.9 F	199.9 F
11/30/25	10:00	0.0 F	7.937 F	47.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.4 F	20.9 F	199.9 F
11/30/25	11:00	0.0 F	7.937 F	28.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.9 F	20.9 F	199.9 F
11/30/25	12:00	0.0 F	7.937 F	54.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.3 F	20.9 F	199.9 F
11/30/25	13:00	0.0 F	7.937 F	68.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	20.9 F	199.9 F
11/30/25	14:00	0.0 F	7.937 F	65.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.5 F	20.9 F	199.9 F
11/30/25	15:00	0.0 F	7.937 F	55.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.5 F	20.9 F	199.9 F
11/30/25	16:00	0.0 F	7.937 F	69.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.4 F	20.9 F	199.9 F
11/30/25	17:00	0.0 F	7.937 F	44.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.2 F	20.9 F	199.9 F
11/30/25	18:00	0.0 F	7.937 F	56.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.0 F	20.9 F	199.9 F
11/30/25	19:00	0.0 F	7.937 F	57.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.2 F	20.9 F	199.9 F
11/30/25	20:00	0.0 F	7.937 F	32.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.9 F	20.9 F	199.9 F
11/30/25	21:00	0.0 F	7.937 F	82.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.4 F	20.9 F	199.9 F
11/30/25	22:00	0.0 F	7.937 F	101.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.3 F	20.9 F	199.9 F
11/30/25	23:00	0.0 F	7.937 F	78.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.5 F	20.9 F	199.9 F
12/01/25	00:00	0.0 F	7.937 F	103.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.9 F	20.9 F	199.9 F
12/01/25	01:00	0.0 F	7.937 F	77.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.1 F	20.9 F	199.9 F
12/01/25	02:00	0.0 F	7.937 F	65.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.5 F	20.9 F	199.9 F
12/01/25	03:00	0.0 F	7.937 F	57.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.2 F	20.9 F	199.9 F
12/01/25	04:00	0.0 F	7.937 F	29.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.3 F	20.9 F	199.9 F
12/01/25	05:00	0.0 F	7.937 F	67.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.1 F	20.9 F	199.9 F
12/01/25	06:00	0.0 F	7.937 F	62.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.5 F	20.9 F	199.9 F
12/01/25	07:00	0.0 FC	0.012 FC	24.0 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.024 FC	3.5 FC	14.2 FC	199.9 F
12/01/25	08:00	0.0 F	7.937 F	3.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.9 F	21.0 F	199.9 F
12/01/25	09:00	0.0 F	7.937 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.8 F	21.0 F	199.9 F

Source		UNIT_C										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
12/01/25	10:00	0.0 F	7.937 F	13.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.6 F	21.0 F	199.9 F
12/01/25	11:00	0.0 F	7.937 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.1 F	21.0 F	199.9 F
12/01/25	12:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.1 F	21.0 F	199.9 F
12/01/25	13:00	0.0 F	7.937 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.9 F	21.0 F	199.9 F
12/01/25	14:00	0.0 F	6.614 F	15.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.3 F	21.0 F	199.9 F
12/01/25	15:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.0 F	21.0 F	199.9 F
12/01/25	16:00	0.0 F	6.614 F	16.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.0 F	21.0 F	199.9 F
12/01/25	17:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.4 F	21.0 F	199.9 F
12/01/25	18:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	21.0 F	199.9 F
12/01/25	19:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.5 F	21.0 F	199.9 F
12/01/25	20:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.0 F	21.0 F	199.9 F
12/01/25	21:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.4 F	21.0 F	199.9 F
12/01/25	22:00	0.0 F	6.614 F	0.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.4 F	21.0 F	199.9 F
12/01/25	23:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.8 F	20.9 F	199.9 F
12/02/25	00:00	0.0 F	7.937 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.9 F	21.0 F	199.9 F
12/02/25	01:00	0.0 F	7.937 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.0 F	21.0 F	199.9 F
12/02/25	02:00	0.0 F	7.937 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	21.0 F	199.9 F
12/02/25	03:00	0.0 F	7.937 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
12/02/25	04:00	0.0 F	7.937 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.9 F	21.0 F	199.9 F
12/02/25	05:00	0.0 F	7.937 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
12/02/25	06:00	0.0 F	7.937 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
12/02/25	07:00	0.0 FC	0.011 FC	31.5 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.024 FC	4.8 FC	14.2 FC	199.9 F
12/02/25	08:00	0.0 F	3.989 F	63.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.3 F	20.9 F	199.9 F
12/02/25	09:00	0.0 F	0.040 F	50.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.8 F	20.8 F	199.9 F
12/02/25	10:00	0.0 F	0.040 F	44.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	20.8 F	199.9 F
12/02/25	11:00	0.0 F	0.040 F	33.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.9 F	20.8 F	199.9 F
12/02/25	12:00	0.0 F	0.040 F	37.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.8 F	20.8 F	199.9 F
12/02/25	13:00	0.0 F	0.040 F	30.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	20.8 F	199.9 F
12/02/25	14:00	0.0 F	0.040 F	37.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	20.8 F	199.8 F
12/02/25	15:00	0.0 F	0.040 F	37.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.4 F	20.8 F	199.9 F
12/02/25	16:00	0.0 F	0.040 F	36.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	20.8 F	199.9 F
12/02/25	17:00	0.0 F	0.040 F	35.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.5 F	20.8 F	199.9 F
12/02/25	18:00	0.0 F	0.040 F	41.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	20.8 F	199.9 F
12/02/25	19:00	0.0 F	0.040 F	43.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.1 F	20.8 F	199.9 F
12/02/25	20:00	0.0 F	0.040 F	36.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.6 F	20.8 F	199.9 F
12/02/25	21:00	0.0 F	0.040 F	34.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.5 F	20.8 F	199.9 F
12/02/25	22:00	0.0 F	0.040 F	33.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.0 F	20.8 F	199.9 F

Source		UNIT_C										
Parameter Unit		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
12/02/25	23:00	0.0 F	0.040 F	30.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	20.8 F	199.9 F
12/03/25	00:00	0.0 F	0.040 F	36.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	20.8 F	199.9 F
12/03/25	01:00	0.0 F	0.040 F	28.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.7 F	20.8 F	199.9 F
12/03/25	02:00	0.0 F	0.040 F	32.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	20.8 F	199.9 F
12/03/25	03:00	0.0 F	0.040 F	36.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.4 F	20.8 F	199.9 F
12/03/25	04:00	0.0 F	0.040 F	44.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.3 F	20.8 F	199.9 F
12/03/25	05:00	0.0 F	0.040 F	50.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.4 F	20.8 F	199.9 F
12/03/25	06:00	0.0 F	3.969 F	66.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.5 F	20.9 F	199.9 F
12/03/25	07:00	0.0 FC	0.011 FC	40.3 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.024 FC	3.7 FC	14.1 FC	199.9 F
12/03/25	08:00	0.0 F	0.040 F	30.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	20.8 F	199.9 F
12/03/25	09:00	0.0 F	0.040 F	26.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	20.8 F	199.9 F
12/03/25	10:00	0.0 F	0.040 F	26.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	20.8 F	199.9 F
12/03/25	11:00	0.0 F	0.040 F	24.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	20.8 F	199.9 F
12/03/25	12:00	0.0 F	0.040 F	26.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	20.8 F	199.9 F
12/03/25	13:00	0.0 F	0.040 F	24.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.1 F	20.8 F	199.9 F
12/03/25	14:00	0.0 F	0.040 F	24.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	20.8 F	199.9 F
12/03/25	15:00	0.0 F	0.040 F	30.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	20.8 F	199.9 F
12/03/25	16:00	0.0 F	0.040 F	25.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	20.8 F	199.9 F
12/03/25	17:00	0.0 F	0.040 F	25.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	20.8 F	199.9 F
12/03/25	18:00	0.0 F	0.040 F	30.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	20.8 F	199.9 F
12/03/25	19:00	0.0 F	0.040 F	27.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	20.8 F	199.9 F
12/03/25	20:00	0.0 F	0.040 F	25.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	20.8 F	199.9 F
12/03/25	21:00	0.0 F	0.040 F	40.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	20.8 F	199.9 F
12/03/25	22:00	0.0 F	0.040 F	27.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	20.8 F	199.9 F
12/03/25	23:00	0.0 F	0.040 F	31.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	20.8 F	199.9 F
12/04/25	00:00	0.0 F	0.040 F	33.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	20.8 F	199.9 F
12/04/25	01:00	0.0 F	0.053 F	39.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	20.8 F	199.9 F
12/04/25	02:00	0.0 F	0.040 F	41.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.1 F	20.8 F	199.9 F
12/04/25	03:00	0.0 F	0.053 F	51.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	20.8 F	199.9 F
12/04/25	04:00	0.0 F	0.053 F	47.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	20.8 F	199.9 F
12/04/25	05:00	0.0 F	0.040 F	45.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	20.8 F	199.9 F
12/04/25	06:00	0.0 F	0.053 F	44.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	20.8 F	199.9 F
12/04/25	07:00	0.0 FC	0.011 FC	32.8 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.024 FC	3.1 FC	14.1 FC	199.9 F
12/04/25	08:00	0.0 F	5.292 F	103.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.5 F	20.9 F	199.9 F
12/04/25	09:00	0.0 F	5.292 F	64.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.6 F	20.9 F	199.9 F
12/04/25	10:00	0.0 F	0.040 F	42.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.5 F	20.8 F	199.9 F
12/04/25	11:00	0.0 F	0.040 F	37.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.6 F	20.8 F	199.9 F

Source	Parameter Unit	UNIT_C										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
12/04/25	12:00	0.0 F	0.040 F	37.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.0 F	20.8 F	199.9 F
12/04/25	13:00	0.0 F	0.040 F	38.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	20.8 F	199.9 F
12/04/25	14:00	0.0 F	0.040 F	42.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	20.8 F	199.9 F
12/04/25	15:00	0.0 F	0.040 F	43.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	20.8 F	199.9 F
12/04/25	16:00	0.0 F	0.040 F	47.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	20.8 F	199.9 F
12/04/25	17:00	0.0 F	0.040 F	32.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.8 F	20.8 F	199.9 F
12/04/25	18:00	0.0 F	0.040 F	45.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.9 F	20.8 F	199.9 F
12/04/25	19:00	0.0 F	0.040 F	37.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.4 F	20.8 F	199.9 F
12/04/25	20:00	0.0 F	0.040 F	41.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	20.8 F	199.9 F
12/04/25	21:00	0.0 F	0.040 F	28.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	20.8 F	199.9 F
12/04/25	22:00	0.0 F	0.040 F	36.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.6 F	20.8 F	199.9 F
12/04/25	23:00	0.0 F	5.292 F	101.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.7 F	20.9 F	199.9 F
12/05/25	00:00	0.0 F	5.292 F	73.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.0 F	20.9 F	199.9 F
12/05/25	01:00	0.0 F	5.292 F	76.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.9 F	20.9 F	199.9 F
12/05/25	02:00	0.0 F	5.292 F	101.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.1 F	20.9 F	199.9 F
12/05/25	03:00	0.0 F	5.292 F	93.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.4 F	20.9 F	199.9 F
12/05/25	04:00	0.0 F	5.292 F	73.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.6 F	20.9 F	199.9 F
12/05/25	05:00	0.0 F	5.292 F	101.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.7 F	20.9 F	199.9 F
12/05/25	06:00	0.0 F	5.292 F	72.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.7 F	20.9 F	199.9 F
12/05/25	07:00	0.0 FC	0.011 FC	35.9 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.023 FC	3.4 FC	14.1 FC	199.9 F
12/05/25	08:00	0.0 F	5.292 F	75.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.4 F	20.9 F	199.9 F
12/05/25	09:00	0.0 F	3.969 F	53.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.3 F	20.9 F	199.8 F
12/05/25	10:00	0.0 F	3.969 F	48.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.9 F	20.9 F	199.9 F
12/05/25	11:00	0.0 F	3.969 F	47.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.2 F	20.9 F	199.9 F
12/05/25	12:00	0.0 F	3.969 F	47.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.3 F	20.9 F	199.9 F
12/05/25	13:00	0.0 F	3.969 F	52.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	20.9 F	199.9 F
12/05/25	14:00	0.0 F	3.969 F	38.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.7 F	20.9 F	199.8 F
12/05/25	15:00	0.0 F	0.040 F	46.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.6 F	20.8 F	199.8 F
12/05/25	16:00	0.0 F	3.969 F	56.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.3 F	20.9 F	199.9 F
12/05/25	17:00	0.0 F	3.969 F	65.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.4 F	20.9 F	199.9 F
12/05/25	18:00	0.0 F	3.969 F	40.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	20.9 F	199.8 F
12/05/25	19:00	0.0 F	2.646 F	43.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.1 F	20.9 F	199.9 F
12/05/25	20:00	0.0 F	3.969 F	41.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.1 F	20.9 F	199.9 F
12/05/25	21:00	0.0 F	2.646 F	38.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	20.9 F	199.9 F
12/05/25	22:00	0.0 F	3.969 F	46.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.6 F	20.9 F	199.9 F
12/05/25	23:00	0.0 F	3.969 F	58.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.8 F	20.9 F	199.9 F
12/06/25	00:00	0.0 F	3.969 F	32.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.9 F	20.9 F	199.9 F

Source		UNIT_C										
Parameter Unit		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
12/06/25	01:00	0.0 F	3.969 F	38.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.0 F	20.9 F	199.9 F
12/06/25	02:00	0.0 F	3.969 F	52.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.1 F	20.9 F	199.9 F
12/06/25	03:00	0.0 F	3.969 F	59.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.7 F	20.9 F	199.9 F
12/06/25	04:00	0.0 F	3.969 F	43.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.3 F	20.9 F	199.9 F
12/06/25	05:00	0.0 F	3.969 F	28.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.8 F	20.9 F	199.9 F
12/06/25	06:00	0.0 F	3.969 F	39.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.6 F	20.9 F	199.9 F
12/06/25	07:00	0.0 FC	0.011 FC	28.0 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.023 FC	4.2 FC	14.1 FC	199.9 F
12/06/25	08:00	0.0 F	0.040 F	25.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	20.8 F	199.9 F
12/06/25	09:00	0.0 F	0.040 F	20.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	20.8 F	199.9 F
12/06/25	10:00	0.0 F	0.040 F	16.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	20.8 F	199.9 F
12/06/25	11:00	0.0 F	0.040 F	15.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	20.8 F	199.9 F
12/06/25	12:00	0.0 F	0.040 F	13.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.6 F	20.8 F	199.9 F
12/06/25	13:00	0.0 F	0.026 F	12.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	20.8 F	199.9 F
12/06/25	14:00	0.0 F	0.026 F	12.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.8 F	20.8 F	199.9 F
12/06/25	15:00	0.0 F	0.026 F	12.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	20.8 F	199.9 F
12/06/25	16:00	0.0 F	0.026 F	12.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.8 F	20.8 F	199.9 F
12/06/25	17:00	0.0 F	0.026 F	13.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.0 F	20.8 F	199.9 F
12/06/25	18:00	0.0 F	0.026 F	14.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	20.8 F	199.9 F
12/06/25	19:00	0.0 F	0.040 F	15.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.6 F	20.8 F	199.9 F
12/06/25	20:00	0.0 F	0.040 F	17.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	20.8 F	199.9 F
12/06/25	21:00	0.0 F	0.040 F	26.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	20.8 F	199.9 F
12/06/25	22:00	0.0 F	0.040 F	35.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	20.8 F	199.9 F
12/06/25	23:00	0.0 F	0.040 F	20.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.8 F	20.8 F	199.9 F
12/07/25	00:00	0.0 F	0.040 F	41.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.7 F	20.8 F	199.9 F
12/07/25	01:00	0.0 F	0.040 F	36.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	20.8 F	199.9 F
12/07/25	02:00	0.0 F	0.040 F	38.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.5 F	20.8 F	199.9 F
12/07/25	03:00	0.0 F	0.040 F	43.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.5 F	20.8 F	199.9 F
12/07/25	04:00	0.0 F	0.040 F	52.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.9 F	20.8 F	199.9 F
12/07/25	05:00	0.0 F	0.040 F	52.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.1 F	20.8 F	199.9 F
12/07/25	06:00	0.0 F	0.040 F	34.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	20.8 F	199.9 F
12/07/25	07:00	0.0 FC	0.011 FC	28.6 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.023 FC	5.0 FC	14.1 FC	199.9 F
12/07/25	08:00	0.0 F	5.292 F	67.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.8 F	20.9 F	199.9 F
12/07/25	09:00	0.0 F	0.040 F	49.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.8 F	20.8 F	199.9 F
12/07/25	10:00	0.0 F	0.040 F	33.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	20.8 F	199.9 F
12/07/25	11:00	0.0 F	0.040 F	23.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	20.8 F	199.9 F
12/07/25	12:00	0.0 F	0.040 F	36.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.5 F	20.8 F	199.9 F
12/07/25	13:00	0.0 F	0.040 F	20.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.8 F	20.8 F	199.9 F

Source		UNIT_C										
Parameter Unit		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
12/07/25	14:00	0.0 F	0.040 F	28.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	20.8 F	199.9 F
12/07/25	15:00	0.0 F	0.040 F	26.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.8 F	20.8 F	199.9 F
12/07/25	16:00	0.0 F	0.040 F	31.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	20.8 F	199.9 F
12/07/25	17:00	0.0 F	0.040 F	37.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.9 F	20.8 F	199.9 F
12/07/25	18:00	0.0 F	0.040 F	24.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	20.8 F	199.9 F
12/07/25	19:00	0.0 F	0.040 F	27.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	20.8 F	199.9 F
12/07/25	20:00	0.0 F	0.040 F	28.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.9 F	20.8 F	199.9 F
12/07/25	21:00	0.0 F	0.040 F	43.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	20.8 F	199.9 F
12/07/25	22:00	0.0 F	0.040 F	66.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.9 F	20.8 F	199.9 F
12/07/25	23:00	0.0 F	0.040 F	54.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.4 F	20.8 F	199.9 F
12/08/25	00:00	0.0 F	0.040 F	48.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.8 F	20.8 F	199.9 F
12/08/25	01:00	0.0 F	0.040 F	50.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.0 F	20.8 F	199.9 F
12/08/25	02:00	0.0 F	0.040 F	62.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.6 F	20.8 F	199.9 F
12/08/25	03:00	0.0 F	5.292 F	48.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.5 F	20.9 F	199.9 F
12/08/25	04:00	0.0 F	5.292 F	62.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.3 F	20.9 F	199.9 F
12/08/25	05:00	0.0 F	5.292 F	59.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.5 F	20.9 F	199.9 F
12/08/25	06:00	0.0 F	5.292 F	64.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.4 F	20.9 F	199.9 F
12/08/25	07:00	0.0 FC	0.011 FC	50.1 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.023 FC	3.5 FC	14.1 FC	199.9 F
12/08/25	08:00	0.0 F	0.053 F	62.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.5 F	20.8 F	199.9 F
12/08/25	09:00	0.0 F	0.053 F	43.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.3 F	20.8 F	199.9 F
12/08/25	10:00	0.0 F	0.053 F	36.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.5 F	20.8 F	199.9 F
12/08/25	11:00	0.0 F	0.040 F	26.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.1 F	20.8 F	199.9 F
12/08/25	12:00	0.0 F	0.040 F	21.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.9 F	20.8 F	199.9 F
12/08/25	13:00	0.0 F	0.040 F	21.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.0 F	20.8 F	199.9 F
12/08/25	14:00	0.0 F	0.040 F	19.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.0 F	20.8 F	199.9 F
12/08/25	15:00	0.0 F	0.040 F	21.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.9 F	20.8 F	199.9 F
12/08/25	16:00	0.0 F	0.040 F	22.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	20.8 F	199.9 F
12/08/25	17:00	0.0 F	0.040 F	18.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.8 F	20.8 F	199.9 F
12/08/25	18:00	0.0 F	0.040 F	18.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.8 F	20.8 F	199.9 F
12/08/25	19:00	0.0 F	0.040 F	21.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	20.8 F	199.9 F
12/08/25	20:00	0.0 F	0.040 F	29.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.1 F	20.8 F	199.9 F
12/08/25	21:00	0.0 F	0.053 F	28.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.0 F	20.8 F	199.9 F
12/08/25	22:00	0.0 F	0.053 F	34.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	20.8 F	199.9 F
12/08/25	23:00	0.0 F	0.053 F	35.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.4 F	20.8 F	199.9 F
12/09/25	00:00	0.0 F	0.053 F	42.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.3 F	20.8 F	199.9 F
12/09/25	01:00	0.0 F	0.053 F	38.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.6 F	20.8 F	199.9 F
12/09/25	02:00	0.0 F	0.053 F	54.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.6 F	20.8 F	199.9 F

Source		UNIT_C										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
12/09/25	03:00	0.0 F	0.053 F	45.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.9 F	20.8 F	199.9 F
12/09/25	04:00	0.0 F	0.053 F	65.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.4 F	20.8 F	199.9 F
12/09/25	05:00	0.0 F	0.053 F	62.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.5 F	20.8 F	199.9 F
12/09/25	06:00	0.0 F	0.053 F	80.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.2 F	20.8 F	199.9 F
12/09/25	07:00	0.0 FC	0.011 FC	46.6 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.024 FC	7.8 FC	14.1 FC	199.9 F
12/09/25	08:00	0.0 F	0.053 F	45.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.022 F	5.6 F	20.8 F	199.9 F
12/09/25	09:00	0.0 F	0.053 F	34.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.022 F	5.0 F	20.8 F	199.9 F
12/09/25	10:00	0.0 F	0.040 F	30.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.022 F	4.4 F	20.8 F	199.9 F
12/09/25	11:00	0.0 F	0.040 F	26.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.022 F	3.5 F	20.8 F	199.9 F
12/09/25	12:00	0.0 F	0.040 F	18.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.022 F	3.2 F	20.8 F	199.8 F
12/09/25	13:00	0.0 F	0.040 F	17.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.8 F	20.8 F	199.9 F
12/09/25	14:00	0.0 F	0.040 F	17.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.0 F	20.8 F	199.8 F
12/09/25	15:00	0.0 F	0.040 F	17.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.0 F	20.8 F	199.8 F
12/09/25	16:00	0.0 F	0.040 F	15.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.6 F	20.8 F	199.9 F
12/09/25	17:00	0.0 F	0.040 F	16.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.6 F	20.8 F	199.9 F
12/09/25	18:00	0.0 F	0.040 F	16.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.022 F	2.8 F	20.8 F	199.9 F
12/09/25	19:00	0.0 F	0.040 F	15.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.6 F	20.8 F	199.9 F
12/09/25	20:00	0.0 F	0.040 F	16.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.7 F	20.8 F	199.9 F
12/09/25	21:00	0.0 F	0.040 F	16.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.8 F	20.8 F	199.9 F
12/09/25	22:00	0.0 F	0.040 F	29.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.6 F	20.8 F	199.9 F
12/09/25	23:00	0.0 F	0.053 F	30.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.2 F	20.8 F	199.9 F
12/10/25	00:00	0.0 F	0.053 F	39.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.022 F	5.8 F	20.8 F	199.9 F
12/10/25	01:00	0.0 F	0.053 F	40.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.6 F	20.8 F	199.9 F
12/10/25	02:00	0.0 F	0.053 F	42.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.022 F	6.1 F	20.8 F	199.9 F
12/10/25	03:00	0.0 F	0.053 F	62.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	7.8 F	20.8 F	199.9 F
12/10/25	04:00	0.0 F	0.053 F	64.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.022 F	9.8 F	20.8 F	199.9 F
12/10/25	05:00	0.0 F	0.053 F	42.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.022 F	6.0 F	20.8 F	199.9 F
12/10/25	06:00	0.0 F	0.053 F	58.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	6.3 F	20.8 F	199.9 F
12/10/25	07:00	0.0 FC	0.011 FC	32.9 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.024 FC	5.0 FC	14.1 FC	199.9 F
12/10/25	08:00	0.0 F	3.969 F	51.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.1 F	20.9 F	199.9 F
12/10/25	09:00	0.0 F	0.026 F	42.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	20.8 F	199.9 F
12/10/25	10:00	0.0 F	0.026 F	30.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.8 F	20.8 F	199.9 F
12/10/25	11:00	0.0 F	0.026 F	28.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.6 F	20.8 F	199.9 F
12/10/25	12:00	0.0 F	0.026 F	26.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.8 F	20.8 F	199.9 F
12/10/25	13:00	0.0 F	0.026 F	20.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.0 F	20.8 F	199.9 F
12/10/25	14:00	0.0 F	0.026 F	26.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	20.8 F	199.9 F
12/10/25	15:00	0.0 F	0.026 F	28.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.6 F	20.8 F	199.9 F

Source		UNIT_C										
Parameter Unit		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
12/10/25	16:00	0.0 F	0.026 F	25.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.9 F	20.8 F	199.9 F
12/10/25	17:00	0.0 F	0.026 F	28.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.1 F	20.8 F	199.9 F
12/10/25	18:00	0.0 F	0.026 F	27.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.8 F	20.8 F	199.9 F
12/10/25	19:00	0.0 F	0.026 F	18.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	20.8 F	199.9 F
12/10/25	20:00	0.0 F	0.026 F	18.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	20.8 F	199.9 F
12/10/25	21:00	0.0 F	0.026 F	20.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	20.8 F	199.9 F
12/10/25	22:00	0.0 F	0.026 F	26.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	20.8 F	199.9 F
12/10/25	23:00	0.0 F	0.013 F	13.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.3 F	20.8 F	199.9 F
12/11/25	00:00	0.0 F	0.013 F	18.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.9 F	20.8 F	199.9 F
12/11/25	01:00	0.0 F	0.026 F	19.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	20.8 F	199.9 F
12/11/25	02:00	0.0 F	0.026 F	23.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	20.8 F	199.9 F
12/11/25	03:00	0.0 F	2.646 F	51.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.0 F	20.9 F	199.9 F
12/11/25	04:00	0.0 F	2.646 F	52.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.5 F	20.9 F	199.9 F
12/11/25	05:00	0.0 F	2.646 F	30.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.0 F	20.9 F	199.9 F
12/11/25	06:00	0.0 F	2.646 F	37.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.4 F	20.9 F	199.9 F
12/11/25	07:00	0.0 FC	0.013 FC	22.7 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.024 FC	3.8 FC	14.2 FC	199.9 F
12/11/25	08:00	0.0 F	0.026 F	22.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	20.8 F	199.9 F
12/11/25	09:00	0.0 F	0.026 F	19.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	20.8 F	199.9 F
12/11/25	10:00	0.0 F	0.026 F	17.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	20.8 F	199.9 F
12/11/25	11:00	0.0 F	0.026 F	17.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	20.8 F	199.8 F
12/11/25	12:00	0.0 F	0.026 F	20.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	20.8 F	199.8 F
12/11/25	13:00	0.0 F	0.026 F	21.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	20.8 F	199.8 F
12/11/25	14:00	0.0 F	0.026 F	18.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	20.8 F	199.9 F
12/11/25	15:00	0.0 F	0.026 F	23.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	20.8 F	199.9 F
12/11/25	16:00	0.0 F	0.026 F	23.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	20.8 F	199.8 F
12/11/25	17:00	0.0 F	0.026 F	17.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	20.8 F	199.9 F
12/11/25	18:00	0.0 F	0.026 F	14.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	20.8 F	199.9 F
12/11/25	19:00	0.0 F	0.026 F	14.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	20.8 F	199.9 F
12/11/25	20:00	0.0 F	0.026 F	20.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	20.8 F	199.9 F
12/11/25	21:00	0.0 F	0.026 F	17.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	20.8 F	199.9 F
12/11/25	22:00	0.0 F	0.026 F	17.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	20.8 F	199.9 F
12/11/25	23:00	0.0 F	0.026 F	17.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	20.8 F	199.9 F
12/12/25	00:00	0.0 F	0.026 F	23.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.9 F	20.8 F	199.9 F
12/12/25	01:00	0.0 F	0.026 F	30.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.5 F	20.8 F	199.9 F
12/12/25	02:00	0.0 F	0.026 F	19.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	20.8 F	199.9 F
12/12/25	03:00	0.0 F	0.026 F	23.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	20.8 F	199.9 F
12/12/25	04:00	0.0 F	2.646 F	35.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.4 F	20.9 F	199.9 F

Source		UNIT_C										
Parameter Unit		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
12/12/25	05:00	0.0 F	0.026 F	33.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	20.8 F	199.9 F
12/12/25	06:00	0.0 F	0.026 F	38.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	20.8 F	199.9 F
12/12/25	07:00	0.0 FC	0.011 FC	30.6 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.024 FC	5.9 FC	14.2 FC	199.9 F
12/12/25	08:00	0.0 F	0.026 F	15.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.6 F	20.8 F	199.9 F
12/12/25	09:00	0.0 F	0.026 F	15.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.5 F	20.8 F	199.9 F
12/12/25	10:00	0.0 F	0.026 F	14.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.8 F	20.8 F	199.9 F
12/12/25	11:00	0.0 F	0.026 F	15.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.4 F	20.8 F	199.9 F
12/12/25	12:00	0.0 F	0.026 F	15.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	20.8 F	199.9 F
12/12/25	13:00	0.0 F	0.026 F	16.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.5 F	20.8 F	199.8 F
12/12/25	14:00	0.0 F	0.026 F	23.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.2 F	20.8 F	199.8 F
12/12/25	15:00	0.0 F	0.026 F	21.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.9 F	20.8 F	199.8 F
12/12/25	16:00	0.0 F	0.026 F	18.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.2 F	20.8 F	199.8 F
12/12/25	17:00	0.0 F	0.026 F	14.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.6 F	20.8 F	199.8 F
12/12/25	18:00	0.0 F	0.026 F	13.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.5 F	20.8 F	199.8 F
12/12/25	19:00	0.0 F	0.026 F	13.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.4 F	20.8 F	199.9 F
12/12/25	20:00	0.0 F	0.026 F	15.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.7 F	20.8 F	199.9 F
12/12/25	21:00	0.0 F	0.026 F	13.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.9 F	20.8 F	199.9 F
12/12/25	22:00	0.0 F	0.026 F	12.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	20.8 F	199.9 F
12/12/25	23:00	0.0 F	0.026 F	14.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.8 F	20.8 F	199.9 F
12/13/25	00:00	0.0 F	0.026 F	12.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.4 F	20.8 F	199.9 F
12/13/25	01:00	0.0 F	0.026 F	12.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.6 F	20.8 F	199.9 F
12/13/25	02:00	0.0 F	0.026 F	12.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	20.8 F	199.9 F
12/13/25	03:00	0.0 F	0.026 F	16.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.7 F	20.8 F	199.9 F
12/13/25	04:00	0.0 F	0.026 F	14.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	20.8 F	199.9 F
12/13/25	05:00	0.0 F	0.026 F	14.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.6 F	20.8 F	199.9 F
12/13/25	06:00	0.0 F	0.026 F	15.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.3 F	20.8 F	199.9 F
12/13/25	07:00	0.0 FC	0.011 FC	28.8 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.024 FC	5.2 FC	14.1 FC	199.9 F
12/13/25	08:00	0.0 F	5.292 F	123.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	6.6 F	20.9 F	199.9 F
12/13/25	09:00	0.0 F	5.292 F	78.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	6.0 F	20.9 F	199.9 F
12/13/25	10:00	0.0 F	5.292 F	68.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.5 F	20.9 F	199.9 F
12/13/25	11:00	0.0 F	5.292 F	77.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	6.5 F	20.9 F	199.8 F
12/13/25	12:00	0.0 F	5.292 F	96.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	6.7 F	20.9 F	199.8 F
12/13/25	13:00	0.0 F	6.614 F	72.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	6.8 F	20.9 F	199.8 F
12/13/25	14:00	0.0 F	6.614 F	48.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.5 F	20.9 F	199.8 F
12/13/25	15:00	0.0 F	6.614 F	80.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	6.7 F	20.9 F	199.8 F
12/13/25	16:00	0.0 F	5.292 F	55.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.0 F	20.9 F	199.8 F
12/13/25	17:00	0.0 F	5.292 F	55.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	6.7 F	20.9 F	199.8 F

Source Parameter Unit	UNIT_C										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
12/13/25 18:00	0.0 F	5.292 F	60.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.9 F	20.9 F	199.8 F
12/13/25 19:00	0.0 F	5.292 F	48.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.1 F	20.9 F	199.9 F
12/13/25 20:00	0.0 F	5.292 F	50.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.0 F	20.9 F	199.9 F
12/13/25 21:00	0.0 F	5.292 F	38.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.3 F	20.9 F	199.9 F
12/13/25 22:00	0.0 F	5.292 F	72.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.2 F	20.9 F	199.9 F
12/13/25 23:00	0.0 F	5.292 F	75.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.8 F	20.9 F	199.9 F
12/14/25 00:00	0.0 F	5.292 F	52.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.2 F	20.9 F	199.9 F
12/14/25 01:00	0.0 F	5.292 F	61.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.4 F	20.9 F	199.9 F
12/14/25 02:00	0.0 F	5.292 F	61.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	7.1 F	20.9 F	199.9 F
12/14/25 03:00	0.0 F	5.292 F	85.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.8 F	20.9 F	199.9 F
12/14/25 04:00	0.0 F	5.292 F	71.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.1 F	20.9 F	199.9 F
12/14/25 05:00	0.0 F	5.292 F	46.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.9 F	20.9 F	199.9 F
12/14/25 06:00	0.0 F	5.292 F	82.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.5 F	20.9 F	199.9 F
12/14/25 07:00	0.0 FC	0.011 FC	17.9 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.024 FC	4.1 FC	14.2 FC	199.9 F
12/14/25 08:00	0.0 F	3.969 F	47.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.7 F	20.9 F	199.9 F
12/14/25 09:00	0.0 F	3.969 F	55.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	20.9 F	199.9 F
12/14/25 10:00	0.0 F	5.292 F	82.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.7 F	20.9 F	199.9 F
12/14/25 11:00	0.0 F	5.292 F	66.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.7 F	20.9 F	199.9 F
12/14/25 12:00	0.0 F	5.292 F	103.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.9 F	20.9 F	199.8 F
12/14/25 13:00	0.0 F	5.292 F	97.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.4 F	20.9 F	199.9 F
12/14/25 14:00	0.0 F	5.292 F	65.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.5 F	20.9 F	199.9 F
12/14/25 15:00	0.0 F	5.292 F	61.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.3 F	20.9 F	199.8 F
12/14/25 16:00	0.0 F	5.292 F	109.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	20.9 F	199.8 F
12/14/25 17:00	0.0 F	5.292 F	70.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.7 F	20.9 F	199.9 F
12/14/25 18:00	0.0 F	5.292 F	100.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.2 F	20.9 F	199.9 F
12/14/25 19:00	0.0 F	3.969 F	61.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.7 F	20.9 F	199.9 F
12/14/25 20:00	0.0 F	3.969 F	44.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.4 F	20.9 F	199.9 F
12/14/25 21:00	0.0 F	3.969 F	91.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.0 F	20.9 F	199.9 F
12/14/25 22:00	0.0 F	3.969 F	63.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.8 F	20.9 F	199.9 F
12/14/25 23:00	0.0 F	3.969 F	79.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	6.2 F	20.9 F	199.9 F
12/15/25 00:00	0.0 F	5.292 F	72.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.8 F	20.9 F	199.9 F
12/15/25 01:00	0.0 F	3.969 F	54.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.3 F	20.9 F	199.9 F
12/15/25 02:00	0.0 F	3.969 F	41.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.2 F	20.9 F	199.9 F
12/15/25 03:00	0.0 F	3.969 F	41.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.6 F	20.9 F	199.9 F
12/15/25 04:00	0.0 F	5.292 F	47.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.8 F	20.9 F	199.9 F
12/15/25 05:00	0.0 F	5.292 F	67.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	6.2 F	20.9 F	199.9 F
12/15/25 06:00	0.0 F	5.292 F	19.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.9 F	20.9 F	199.9 F

Source		UNIT_C										
Parameter Unit		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
12/15/25	07:00	0.0 FC	0.011 FC	43.5 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.024 FC	4.6 FC	14.2 FC	199.9 F
12/15/25	08:00	0.0 F	0.040 F	42.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	20.8 F	199.9 F
12/15/25	09:00	0.0 F	0.026 F	21.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	20.8 F	199.9 F
12/15/25	10:00	0.0 F	0.026 F	18.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	20.8 F	199.9 F
12/15/25	11:00	0.0 F	0.040 F	23.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	20.8 F	199.8 F
12/15/25	12:00	0.0 F	0.040 F	27.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	20.8 F	199.8 F
12/15/25	13:00	0.0 F	0.040 F	27.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	20.8 F	199.9 F
12/15/25	14:00	0.0 F	0.040 F	27.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	20.8 F	199.8 F
12/15/25	15:00	0.0 F	0.040 F	31.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	20.8 F	199.9 F
12/15/25	16:00	0.0 F	0.040 F	27.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	20.8 F	199.9 F
12/15/25	17:00	0.0 F	0.026 F	30.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	20.8 F	199.9 F
12/15/25	18:00	0.0 F	0.026 F	20.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	20.8 F	199.9 F
12/15/25	19:00	0.0 F	0.026 F	18.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	20.8 F	199.9 F
12/15/25	20:00	0.0 F	0.026 F	21.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	20.8 F	199.9 F
12/15/25	21:00	0.0 F	0.026 F	17.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	20.8 F	199.9 F
12/15/25	22:00	0.0 F	0.026 F	21.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	20.8 F	199.9 F
12/15/25	23:00	0.0 F	0.026 F	25.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.0 F	20.8 F	199.9 F
12/16/25	00:00	0.0 F	0.040 F	38.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	20.8 F	199.9 F
12/16/25	01:00	0.0 F	3.969 F	48.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.5 F	20.9 F	199.9 F
12/16/25	02:00	0.0 F	3.969 F	77.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	20.9 F	199.9 F
12/16/25	03:00	0.0 F	3.969 F	50.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.1 F	20.9 F	199.9 F
12/16/25	04:00	0.0 F	3.969 F	55.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.0 F	20.9 F	199.9 F
12/16/25	05:00	0.0 F	3.969 F	51.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.2 F	20.9 F	199.9 F
12/16/25	06:00	0.0 F	0.040 F	57.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	20.8 F	199.9 F
12/16/25	07:00	0.0 FC	0.011 FC	30.4 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.023 FC	3.4 FC	14.1 FC	199.9 F
12/16/25	08:00	0.0 F	0.040 F	27.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	20.8 F	199.9 F
12/16/25	09:00	0.0 F	0.040 F	17.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.8 F	20.8 F	199.9 F
12/16/25	10:00	0.0 F	0.040 F	19.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.0 F	20.8 F	199.9 F
12/16/25	11:00	0.0 F	0.040 F	20.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.9 F	20.8 F	199.9 F
12/16/25	12:00	0.0 F	0.040 F	17.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.8 F	20.8 F	199.9 F
12/16/25	13:00	0.0 F	0.040 F	22.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.8 F	20.8 F	199.9 F
12/16/25	14:00	0.0 F	0.040 F	20.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.0 F	20.8 F	199.8 F
12/16/25	15:00	0.0 F	0.040 F	22.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	20.8 F	199.9 F
12/16/25	16:00	0.0 F	0.040 F	21.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.0 F	20.8 F	199.9 F
12/16/25	17:00	0.0 F	0.040 F	20.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.9 F	20.8 F	199.9 F
12/16/25	18:00	0.0 F	0.026 F	21.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.9 F	20.8 F	199.9 F
12/16/25	19:00	0.0 F	0.026 F	23.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.9 F	20.8 F	199.9 F

Source		UNIT_C										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
12/16/25	20:00	0.0 F	0.026 F	20.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.6 F	20.8 F	199.9 F
12/16/25	21:00	0.0 F	0.026 F	20.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.8 F	20.8 F	199.9 F
12/16/25	22:00	0.0 F	0.026 F	21.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	20.8 F	199.9 F
12/16/25	23:00	0.0 F	0.040 F	19.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.9 F	20.8 F	199.9 F
12/17/25	00:00	0.0 F	0.026 F	15.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	20.8 F	199.9 F
12/17/25	01:00	0.0 F	0.026 F	17.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.8 F	20.8 F	199.9 F
12/17/25	02:00	0.0 F	0.026 F	16.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.8 F	20.8 F	199.9 F
12/17/25	03:00	0.0 F	0.040 F	17.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	20.8 F	199.9 F
12/17/25	04:00	0.0 F	0.026 F	26.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.8 F	20.8 F	199.9 F
12/17/25	05:00	0.0 F	0.026 F	20.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	20.8 F	199.9 F
12/17/25	06:00	0.0 F	0.026 F	23.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	20.8 F	199.9 F
12/17/25	07:00	0.0 FC	0.011 FC	10.0 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.023 FC	3.7 FC	14.1 FC	199.9 F
12/17/25	08:00	0.0 F	5.292 F	41.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.1 F	20.9 F	199.9 F
12/17/25	09:00	0.0 F	5.292 F	54.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.1 F	20.9 F	199.9 F
12/17/25	10:00	0.0 F	5.292 F	54.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.1 F	20.9 F	199.9 F
12/17/25	11:00	0.0 F	6.614 F	66.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.1 F	20.9 F	199.9 F
12/17/25	12:00	0.0 F	6.614 F	54.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.2 F	20.9 F	199.9 F
12/17/25	13:00	0.0 F	5.292 F	26.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.5 F	20.9 F	199.9 F
12/17/25	14:00	0.0 F	6.614 F	26.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.6 F	20.9 F	199.8 F
12/17/25	15:00	0.0 F	5.292 F	45.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.8 F	20.9 F	199.8 F
12/17/25	16:00	0.0 F	5.292 F	47.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.5 F	20.9 F	199.8 F
12/17/25	17:00	0.0 F	5.292 F	61.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.4 F	20.9 F	199.8 F
12/17/25	18:00	0.0 F	5.292 F	51.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.4 F	20.9 F	199.9 F
12/17/25	19:00	0.0 F	5.292 F	56.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.2 F	20.9 F	199.9 F
12/17/25	20:00	0.0 F	5.292 F	29.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	5.6 F	20.9 F	199.9 F
12/17/25	21:00	0.0 F	5.292 F	50.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.3 F	20.9 F	199.9 F
12/17/25	22:00	0.0 F	5.292 F	43.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.3 F	20.9 F	199.9 F
12/17/25	23:00	0.0 F	5.292 F	52.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.2 F	20.9 F	199.9 F
12/18/25	00:00	0.0 F	5.292 F	43.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.0 F	20.9 F	199.9 F
12/18/25	01:00	0.0 F	5.292 F	81.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.6 F	20.9 F	199.9 F
12/18/25	02:00	0.0 F	5.292 F	22.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.6 F	20.9 F	199.9 F
12/18/25	03:00	0.0 F	5.292 F	36.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.9 F	20.9 F	199.9 F
12/18/25	04:00	0.0 F	5.292 F	47.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.0 F	20.9 F	199.9 F
12/18/25	05:00	0.0 F	5.292 F	70.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.9 F	20.9 F	199.8 F
12/18/25	06:00	0.0 F	5.292 F	74.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.8 F	20.9 F	199.9 F
12/18/25	07:00	0.0 FC	0.011 FC	39.6 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.024 FC	5.0 FC	14.2 FC	199.9 F
12/18/25	08:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.6 F	21.0 F	199.9 F

Source Parameter Unit		UNIT_C										
		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
12/18/25	09:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.7 F	21.0 F	199.9 F
12/18/25	10:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.6 F	21.0 F	199.9 F
12/18/25	11:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.9 F	21.0 F	199.9 F
12/18/25	12:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.6 F	21.0 F	199.9 F
12/18/25	13:00	0.0 F	6.614 F	18.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.5 F	21.0 F	199.9 F
12/18/25	14:00	0.0 F	6.614 F	1.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.7 F	21.0 F	199.9 F
12/18/25	15:00	0.0 F	6.614 F	14.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.3 F	21.0 F	199.9 F
12/18/25	16:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.0 F	21.0 F	199.9 F
12/18/25	17:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.8 F	21.0 F	199.9 F
12/18/25	18:00	0.0 F	6.614 F	4.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.5 F	21.0 F	199.9 F
12/18/25	19:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.8 F	21.0 F	199.9 F
12/18/25	20:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.0 F	21.0 F	199.9 F
12/18/25	21:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.7 F	21.0 F	199.9 F
12/18/25	22:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.1 F	21.0 F	199.9 F
12/18/25	23:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.1 F	21.0 F	199.9 F
12/19/25	00:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.3 F	21.0 F	199.9 F
12/19/25	01:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.4 F	21.0 F	199.9 F
12/19/25	02:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.5 F	21.0 F	199.9 F
12/19/25	03:00	0.0 F	6.614 F	0.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.1 F	21.0 F	199.9 F
12/19/25	04:00	0.0 F	6.614 F	5.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.2 F	21.0 F	199.9 F
12/19/25	05:00	0.0 F	6.614 F	0.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.6 F	21.0 F	199.9 F
12/19/25	06:00	0.0 F	6.614 F	2.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.4 F	21.0 F	199.9 F
12/19/25	07:00	0.0 FC	0.012 FC	9.9 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.024 FC	3.1 FC	14.2 FC	199.9 F
12/19/25	08:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.9 F	21.0 F	199.9 F
12/19/25	09:00	0.0 F	6.614 F	8.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.0 F	21.0 F	199.9 F
12/19/25	10:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.4 F	21.0 F	199.9 F
12/19/25	11:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
12/19/25	12:00	0.0 F	6.614 F	12.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.0 F	21.0 F	199.9 F
12/19/25	13:00	0.0 F	6.614 F	0.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	21.0 F	199.9 F
12/19/25	14:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	21.0 F	199.9 F
12/19/25	15:00	0.0 F	6.614 F	8.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.1 F	21.0 F	199.9 F
12/19/25	16:00	0.0 F	6.614 F	3.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.9 F	21.0 F	199.9 F
12/19/25	17:00	0.0 F	6.614 F	5.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.6 F	21.0 F	199.9 F
12/19/25	18:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	21.0 F	199.9 F
12/19/25	19:00	0.0 F	6.614 F	12.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.0 F	21.0 F	199.9 F
12/19/25	20:00	0.0 F	6.614 F	10.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.4 F	21.0 F	199.9 F
12/19/25	21:00	0.0 F	5.292 F	12.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.8 F	21.0 F	199.9 F

Source		UNIT_C										
Parameter Unit		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
12/19/25	22:00	0.0 F	6.614 F	1.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.0 F	21.0 F	199.9 F
12/19/25	23:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	21.0 F	199.9 F
12/20/25	00:00	0.0 F	5.292 F	7.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.4 F	21.0 F	199.9 F
12/20/25	01:00	0.0 F	5.292 F	5.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.0 F	21.0 F	199.9 F
12/20/25	02:00	0.0 F	5.292 F	3.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.0 F	21.0 F	199.9 F
12/20/25	03:00	0.0 F	5.292 F	9.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.8 F	21.0 F	199.9 F
12/20/25	04:00	0.0 F	5.292 F	0.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.9 F	21.0 F	199.9 F
12/20/25	05:00	0.0 F	5.292 F	5.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.8 F	21.0 F	199.9 F
12/20/25	06:00	0.0 F	5.292 F	5.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.1 F	21.0 F	199.9 F
12/20/25	07:00	0.0 FC	0.011 FC	2.1 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.024 FC	3.0 FC	14.1 FC	199.9 F
12/20/25	08:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	2.174 F	0.0 F	21.0 F	199.9 F
12/20/25	09:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	2.174 F	0.0 F	21.0 F	199.9 F
12/20/25	10:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	2.174 F	0.0 F	21.0 F	199.9 F
12/20/25	11:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	2.174 F	0.0 F	21.0 F	199.9 F
12/20/25	12:00	0.0 F	5.292 F	0.1 F	0.0 F	0.0 F	0.0 F	0.0 F	2.174 F	0.1 F	21.0 F	199.9 F
12/20/25	13:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	2.174 F	0.0 F	21.0 F	199.9 F
12/20/25	14:00	0.0 F	5.292 F	3.5 F	0.0 F	0.0 F	0.0 F	0.0 F	2.174 F	0.5 F	21.0 F	199.9 F
12/20/25	15:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	2.174 F	0.0 F	21.0 F	199.9 F
12/20/25	16:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	2.174 F	0.0 F	21.0 F	199.9 F
12/20/25	17:00	0.0 F	5.292 F	0.4 F	0.0 F	0.0 F	0.0 F	0.0 F	2.174 F	0.1 F	21.0 F	199.9 F
12/20/25	18:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	2.174 F	0.0 F	21.0 F	199.9 F
12/20/25	19:00	0.0 F	5.292 F	8.0 F	0.0 F	0.0 F	0.0 F	0.0 F	2.174 F	0.9 F	21.0 F	199.9 F
12/20/25	20:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	2.174 F	0.0 F	21.0 F	199.9 F
12/20/25	21:00	0.0 F	5.292 F	9.6 F	0.0 F	0.0 F	0.0 F	0.0 F	2.174 F	2.7 F	21.0 F	199.9 F
12/20/25	22:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	2.174 F	0.0 F	21.0 F	199.9 F
12/20/25	23:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	2.174 F	0.0 F	21.0 F	199.9 F
12/21/25	00:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	2.174 F	0.0 F	21.0 F	199.9 F
12/21/25	01:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	2.174 F	0.0 F	21.0 F	199.9 F
12/21/25	02:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	2.174 F	0.0 F	21.0 F	199.9 F
12/21/25	03:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	2.174 F	0.0 F	21.0 F	199.9 F
12/21/25	04:00	0.0 F	5.292 F	6.1 F	0.0 F	0.0 F	0.0 F	0.0 F	2.174 F	0.9 F	21.0 F	199.9 F
12/21/25	05:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	2.174 F	0.0 F	21.0 F	199.9 F
12/21/25	06:00	0.0 F	5.292 F	12.1 F	0.0 F	0.0 F	0.0 F	0.0 F	2.174 F	1.6 F	21.0 F	199.9 F
12/21/25	07:00	0.0 FC	0.011 FC	2.4 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.024 FC	6.5 FC	14.2 FC	199.9 F
12/21/25	08:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	2.2 F	21.0 F	199.9 F
12/21/25	09:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	1.9 F	21.0 F	199.9 F
12/21/25	10:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	2.1 F	21.0 F	199.9 F

Source		UNIT_C										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
12/21/25	11:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	2.3 F	21.0 F	199.9 F
12/21/25	12:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	2.3 F	21.0 F	199.9 F
12/21/25	13:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.9 F	21.0 F	199.9 F
12/21/25	14:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.6 F	21.0 F	199.9 F
12/21/25	15:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.7 F	21.0 F	199.9 F
12/21/25	16:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	2.3 F	21.0 F	199.9 F
12/21/25	17:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.8 F	21.0 F	199.9 F
12/21/25	18:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	2.3 F	21.0 F	199.9 F
12/21/25	19:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	2.2 F	21.0 F	199.9 F
12/21/25	20:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	2.1 F	21.0 F	199.9 F
12/21/25	21:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	2.0 F	21.0 F	199.8 F
12/21/25	22:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.4 F	21.0 F	199.9 F
12/21/25	23:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	2.4 F	21.0 F	199.9 F
12/22/25	00:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	2.5 F	21.0 F	199.9 F
12/22/25	01:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.6 F	21.0 F	199.9 F
12/22/25	02:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	2.9 F	21.0 F	199.9 F
12/22/25	03:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	3.0 F	21.0 F	199.9 F
12/22/25	04:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	2.1 F	21.0 F	199.9 F
12/22/25	05:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	2.3 F	21.0 F	199.9 F
12/22/25	06:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	2.5 F	21.0 F	199.9 F
12/22/25	07:00	0.0 FC	0.011 FC	1.7 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.024 FC	3.1 FC	14.2 FC	199.9 F
12/22/25	08:00	0.0 F	3.969 F	4.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
12/22/25	09:00	0.0 F	3.969 F	3.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.5 F	21.0 F	199.9 F
12/22/25	10:00	0.0 F	3.969 F	1.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
12/22/25	11:00	0.0 F	3.969 F	11.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.0 F	21.0 F	199.9 F
12/22/25	12:00	0.0 F	3.969 F	12.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	21.0 F	199.9 F
12/22/25	13:00	0.0 F	3.969 F	6.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
12/22/25	14:00	0.0 F	3.969 F	13.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	21.0 F	199.9 F
12/22/25	15:00	0.0 F	3.969 F	12.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.1 F	21.0 F	199.9 F
12/22/25	16:00	0.0 F	3.969 F	0.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
12/22/25	17:00	0.0 F	3.969 F	0.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.8 F
12/22/25	18:00	0.0 F	3.969 F	1.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	20.9 F	199.9 F
12/22/25	19:00	0.0 F	3.969 F	0.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	21.0 F	199.9 F
12/22/25	20:00	0.0 F	3.969 F	10.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	21.0 F	199.9 F
12/22/25	21:00	0.0 F	3.969 F	5.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
12/22/25	22:00	0.0 F	3.969 F	9.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.6 F	20.9 F	199.9 F
12/22/25	23:00	0.0 F	3.969 F	7.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.0 F	20.9 F	199.9 F

Source Parameter Unit	UNIT_C										
	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
12/23/25 00:00	0.0 F	3.969 F	7.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	21.0 F	199.9 F
12/23/25 01:00	0.0 F	3.969 F	6.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.8 F	21.0 F	199.9 F
12/23/25 02:00	0.0 F	3.969 F	9.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.0 F	21.0 F	199.9 F
12/23/25 03:00	0.0 F	3.969 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	21.0 F	199.9 F
12/23/25 04:00	0.0 F	3.969 F	0.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
12/23/25 05:00	0.0 F	3.969 F	18.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	20.9 F	199.9 F
12/23/25 06:00	0.0 F	3.969 F	15.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.5 F	20.9 F	199.9 F
12/23/25 07:00	0.0 FC	0.011 FC	7.9 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.024 FC	3.8 FC	14.2 FC	199.9 F
12/23/25 08:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.0 F	21.0 F	199.9 F
12/23/25 09:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.0 F	21.0 F	199.9 F
12/23/25 10:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.0 F	21.0 F	199.9 F
12/23/25 11:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.9 F	21.0 F	199.9 F
12/23/25 12:00	0.0 F	6.614 F	8.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.9 F	21.0 F	199.9 F
12/23/25 13:00	0.0 F	5.292 F	1.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.8 F	21.0 F	199.9 F
12/23/25 14:00	0.0 F	5.292 F	1.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.4 F	21.0 F	199.9 F
12/23/25 15:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.2 F	21.0 F	199.9 F
12/23/25 16:00	0.0 F	5.292 F	2.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.5 F	21.0 F	199.9 F
12/23/25 17:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.7 F	21.0 F	199.9 F
12/23/25 18:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.9 F	21.0 F	199.9 F
12/23/25 19:00	0.0 F	5.292 F	10.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	21.0 F	199.9 F
12/23/25 20:00	0.0 F	5.292 F	1.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.8 F	21.0 F	199.9 F
12/23/25 21:00	0.0 F	6.614 F	3.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.3 F	21.0 F	199.9 F
12/23/25 22:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.8 F	21.0 F	199.9 F
12/23/25 23:00	0.0 F	5.292 F	4.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.0 F	21.0 F	199.9 F
12/24/25 00:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.1 F	21.0 F	199.9 F
12/24/25 01:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	21.0 F	199.9 F
12/24/25 02:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.7 F	21.0 F	199.9 F
12/24/25 03:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.9 F	21.0 F	199.9 F
12/24/25 04:00	0.0 F	5.292 F	1.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.0 F	21.0 F	199.9 F
12/24/25 05:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.6 F	21.0 F	199.9 F
12/24/25 06:00	0.0 F	5.292 F	1.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.3 F	21.0 F	199.9 F
12/24/25 07:00	0.0 FC	0.011 FC	1.8 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.024 FC	3.5 FC	14.2 FC	199.9 F
12/24/25 08:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	21.0 F	199.9 F
12/24/25 09:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
12/24/25 10:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	21.0 F	199.9 F
12/24/25 11:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	21.0 F	199.9 F
12/24/25 12:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F

Source		UNIT_C										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
12/24/25	13:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	21.0 F	199.9 F
12/24/25	14:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.6 F	21.0 F	199.9 F
12/24/25	15:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	21.0 F	199.9 F
12/24/25	16:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.6 F	21.0 F	199.9 F
12/24/25	17:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	21.0 F	199.9 F
12/24/25	18:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	21.0 F	199.9 F
12/24/25	19:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.7 F	21.0 F	199.9 F
12/24/25	20:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
12/24/25	21:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	21.0 F	199.9 F
12/24/25	22:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	21.0 F	199.9 F
12/24/25	23:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
12/25/25	00:00	0.0 F	5.292 F	0.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
12/25/25	01:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	21.0 F	199.9 F
12/25/25	02:00	0.0 F	5.292 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.6 F	21.0 F	199.9 F
12/25/25	03:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	21.0 F	199.9 F
12/25/25	04:00	0.0 F	5.292 F	0.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	21.0 F	199.9 F
12/25/25	05:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	21.0 F	199.9 F
12/25/25	06:00	0.0 F	6.614 F	0.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	21.0 F	199.9 F
12/25/25	07:00	0.0 FC	0.011 FC	1.8 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.024 FC	3.5 FC	14.2 FC	199.9 F
12/25/25	08:00	0.0 F	6.614 F	0.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.6 F	21.0 F	199.9 F
12/25/25	09:00	0.0 F	6.614 F	5.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	3.1 F	21.0 F	199.9 F
12/25/25	10:00	0.0 F	6.614 F	1.5 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	2.9 F	21.0 F	199.9 F
12/25/25	11:00	0.0 F	6.614 F	2.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.2 F	21.0 F	199.9 F
12/25/25	12:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	2.5 F	21.0 F	199.9 F
12/25/25	13:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.3 F	21.0 F	199.9 F
12/25/25	14:00	0.0 F	6.614 F	7.3 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	3.4 F	21.0 F	199.9 F
12/25/25	15:00	0.0 F	6.614 F	3.2 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	3.8 F	21.0 F	199.9 F
12/25/25	16:00	0.0 F	6.614 F	1.3 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	4.5 F	21.0 F	199.9 F
12/25/25	17:00	0.0 F	6.614 F	1.5 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	5.9 F	21.0 F	199.9 F
12/25/25	18:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	3.5 F	21.0 F	199.9 F
12/25/25	19:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	4.1 F	21.0 F	199.9 F
12/25/25	20:00	0.0 F	6.614 F	13.9 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	3.0 F	21.0 F	199.9 F
12/25/25	21:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.9 F	21.0 F	199.9 F
12/25/25	22:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	3.4 F	21.0 F	199.9 F
12/25/25	23:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	5.1 F	21.0 F	199.9 F
12/26/25	00:00	0.0 F	6.614 F	4.4 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	3.5 F	21.0 F	199.9 F
12/26/25	01:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	4.7 F	21.0 F	199.8 F

Source		UNIT_C										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
12/26/25	02:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	4.9 F	21.0 F	199.9 F
12/26/25	03:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	3.2 F	21.0 F	199.9 F
12/26/25	04:00	0.0 F	6.614 F	0.5 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	3.8 F	21.0 F	199.9 F
12/26/25	05:00	0.0 F	6.614 F	0.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	3.4 F	21.0 F	199.8 F
12/26/25	06:00	0.0 FM	6.614 FM	6.9 FM	0.0 F	0.0 F	0.0 FM	0.1 FM	0.000 FM	4.9 FM	21.0 FM	199.9 F
12/26/25	07:00	0.0 FC	0.012 FC	12.7 FC	0.0 F	0.0 F	0.0 FC	0.1 FC	0.024 FC	5.9 FC	14.2 FC	199.9 F
12/26/25	08:00	0.0 F	5.292 F	84.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	7.8 F	20.9 F	199.9 F
12/26/25	09:00	0.0 F	5.292 F	65.4 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	8.1 F	20.9 F	199.9 F
12/26/25	10:00	0.0 F	5.292 F	87.6 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	6.1 F	20.9 F	199.9 F
12/26/25	11:00	0.0 F	5.292 F	77.2 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	4.6 F	20.9 F	199.9 F
12/26/25	12:00	0.0 F	5.292 F	84.5 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	11.0 F	20.9 F	199.9 F
12/26/25	13:00	0.0 F	5.292 F	51.3 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	9.8 F	20.9 F	199.9 F
12/26/25	14:00	0.0 F	5.292 F	83.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	4.7 F	20.9 F	199.9 F
12/26/25	15:00	0.0 F	5.292 F	74.5 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	6.6 F	20.9 F	199.9 F
12/26/25	16:00	0.0 F	5.292 F	95.8 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	16.7 F	20.9 F	199.9 F
12/26/25	17:00	0.0 F	5.292 F	83.7 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	7.5 F	20.9 F	199.9 F
12/26/25	18:00	0.0 F	5.292 F	88.3 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	7.1 F	20.9 F	199.9 F
12/26/25	19:00	0.0 F	5.292 F	52.2 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	7.7 F	20.9 F	199.9 F
12/26/25	20:00	0.0 F	5.292 F	52.6 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	5.7 F	20.9 F	199.9 F
12/26/25	21:00	0.0 F	5.292 F	58.6 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	6.7 F	20.9 F	199.9 F
12/26/25	22:00	0.0 F	5.292 F	87.6 F	0.0 F	0.0 F	0.0 F	0.2 F	0.000 F	8.3 F	20.9 F	199.9 F
12/26/25	23:00	0.0 F	5.292 F	72.1 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	9.8 F	20.9 F	199.9 F
12/27/25	00:00	0.0 F	5.292 F	95.0 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	11.3 F	20.9 F	199.9 F
12/27/25	01:00	0.0 F	5.292 F	66.7 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	7.9 F	20.9 F	199.9 F
12/27/25	02:00	0.0 F	5.292 F	59.3 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	14.2 F	20.9 F	199.9 F
12/27/25	03:00	0.0 F	5.292 F	67.2 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	11.9 F	20.9 F	199.9 F
12/27/25	04:00	0.0 F	5.292 F	92.6 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	9.0 F	20.9 F	199.9 F
12/27/25	05:00	0.0 F	5.292 F	55.1 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	9.9 F	20.9 F	199.9 F
12/27/25	06:00	0.0 F	5.292 F	49.7 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	6.2 F	20.9 F	199.9 F
12/27/25	07:00	0.0 FC	0.011 FC	35.7 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.024 FC	3.7 FC	14.2 FC	199.9 F
12/27/25	08:00	0.0 F	5.292 F	28.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.1 F	20.9 F	199.9 F
12/27/25	09:00	0.0 F	6.614 F	13.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.7 F	21.0 F	199.9 F
12/27/25	10:00	0.0 F	6.614 F	1.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.7 F	20.9 F	199.9 F
12/27/25	11:00	0.0 F	5.292 F	19.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.7 F	20.9 F	199.9 F
12/27/25	12:00	0.0 F	5.292 F	19.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.0 F	21.0 F	199.9 F
12/27/25	13:00	0.0 F	6.614 F	6.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.6 F	21.0 F	199.9 F
12/27/25	14:00	0.0 F	6.614 F	18.4 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	3.3 F	20.9 F	199.9 F

Source		UNIT_C										
Parameter Unit		COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
12/27/25	15:00	0.0 F	6.614 F	4.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.2 F	21.0 F	199.9 F
12/27/25	16:00	0.0 F	6.614 F	40.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.7 F	21.0 F	199.9 F
12/27/25	17:00	0.0 F	6.614 F	9.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.6 F	21.0 F	199.9 F
12/27/25	18:00	0.0 F	5.292 F	22.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.7 F	20.9 F	199.9 F
12/27/25	19:00	0.0 F	5.292 F	20.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.6 F	21.0 F	199.9 F
12/27/25	20:00	0.0 F	6.614 F	22.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.4 F	21.0 F	199.9 F
12/27/25	21:00	0.0 F	5.292 F	7.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.3 F	20.9 F	199.9 F
12/27/25	22:00	0.0 F	5.292 F	35.7 F	0.0 F	0.0 F	0.0 F	0.1 F	0.000 F	4.9 F	21.0 F	199.9 F
12/27/25	23:00	0.0 F	6.614 F	11.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.5 F	21.0 F	199.9 F
12/28/25	00:00	0.0 F	6.614 F	8.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.2 F	21.0 F	199.9 F
12/28/25	01:00	0.0 F	6.614 F	7.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.9 F	21.0 F	199.9 F
12/28/25	02:00	0.0 F	6.614 F	32.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.6 F	21.0 F	199.9 F
12/28/25	03:00	0.0 F	6.614 F	43.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.1 F	21.0 F	199.9 F
12/28/25	04:00	0.0 F	6.614 F	36.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.4 F	20.9 F	199.9 F
12/28/25	05:00	0.0 F	6.614 F	25.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.2 F	20.9 F	199.9 F
12/28/25	06:00	0.0 F	6.614 F	34.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.7 F	21.0 F	199.9 F
12/28/25	07:00	0.0 FC	0.011 FC	4.9 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.024 FC	3.7 FC	14.2 FC	199.9 F
12/28/25	08:00	0.0 F	5.292 F	15.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.8 F	20.9 F	199.9 F
12/28/25	09:00	0.0 F	5.292 F	19.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.4 F	20.9 F	199.9 F
12/28/25	10:00	0.0 F	5.292 F	28.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.6 F	20.9 F	199.9 F
12/28/25	11:00	0.0 F	5.292 F	41.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.3 F	20.9 F	199.9 F
12/28/25	12:00	0.0 F	5.292 F	47.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.4 F	20.9 F	199.9 F
12/28/25	13:00	0.0 F	5.292 F	9.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.8 F	20.9 F	199.9 F
12/28/25	14:00	0.0 F	5.292 F	18.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.0 F	20.9 F	199.9 F
12/28/25	15:00	0.0 F	5.292 F	74.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.7 F	20.9 F	199.9 F
12/28/25	16:00	0.0 F	5.292 F	13.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.9 F	20.9 F	199.9 F
12/28/25	17:00	0.0 F	5.292 F	3.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.1 F	20.9 F	199.9 F
12/28/25	18:00	0.0 F	5.292 F	42.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.4 F	20.9 F	199.9 F
12/28/25	19:00	0.0 F	5.292 F	46.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.6 F	20.9 F	199.9 F
12/28/25	20:00	0.0 F	5.292 F	27.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.7 F	20.9 F	199.9 F
12/28/25	21:00	0.0 F	5.292 F	31.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.7 F	20.9 F	199.9 F
12/28/25	22:00	0.0 F	5.292 F	16.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	20.9 F	199.9 F
12/28/25	23:00	0.0 F	5.292 F	19.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.4 F	20.9 F	199.9 F
12/29/25	00:00	0.0 F	5.292 F	20.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.2 F	20.9 F	199.9 F
12/29/25	01:00	0.0 F	5.292 F	18.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.9 F	20.9 F	199.9 F
12/29/25	02:00	0.0 F	5.292 F	26.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.2 F	20.9 F	199.9 F
12/29/25	03:00	0.0 F	5.292 F	30.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.0 F	20.9 F	199.9 F

Source		UNIT_C										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
12/29/25	04:00	0.0 F	5.292 F	26.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.4 F	21.0 F	199.9 F
12/29/25	05:00	0.0 F	5.292 F	22.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.0 F	20.9 F	199.9 F
12/29/25	06:00	0.0 F	5.292 F	17.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.3 F	21.0 F	199.9 F
12/29/25	07:00	0.0 FC	0.012 FC	15.6 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.024 FC	3.5 FC	14.2 FC	199.9 F
12/29/25	08:00	0.0 F	0.053 F	23.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	20.8 F	199.9 F
12/29/25	09:00	0.0 F	0.053 F	24.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	20.8 F	199.9 F
12/29/25	10:00	0.0 F	0.053 F	24.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	20.8 F	199.9 F
12/29/25	11:00	0.0 F	0.053 F	21.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	20.8 F	199.9 F
12/29/25	12:00	0.0 F	0.040 F	15.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	20.8 F	199.9 F
12/29/25	13:00	0.0 F	0.040 F	15.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	20.8 F	199.9 F
12/29/25	14:00	0.0 F	0.020 F	16.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	20.7 F	199.9 F
12/29/25	15:00	0.0 F	0.040 F	19.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	20.8 F	199.9 F
12/29/25	16:00	0.0 F	0.040 F	16.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	20.8 F	199.9 F
12/29/25	17:00	0.0 F	0.040 F	15.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	20.8 F	199.9 F
12/29/25	18:00	0.0 F	0.040 F	15.3 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.1 F	20.8 F	199.9 F
12/29/25	19:00	0.0 F	0.040 F	16.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	20.8 F	199.9 F
12/29/25	20:00	0.0 F	0.040 F	15.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	20.8 F	199.9 F
12/29/25	21:00	0.0 F	0.040 F	20.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	20.8 F	199.9 F
12/29/25	22:00	0.0 F	0.053 F	29.8 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.6 F	20.8 F	199.9 F
12/29/25	23:00	0.0 F	0.053 F	34.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	20.8 F	199.9 F
12/30/25	00:00	0.0 F	0.053 F	29.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	20.8 F	199.9 F
12/30/25	01:00	0.0 F	0.053 F	30.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	20.8 F	199.9 F
12/30/25	02:00	0.0 F	0.053 F	25.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	20.8 F	199.9 F
12/30/25	03:00	0.0 F	0.053 F	28.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.3 F	20.8 F	199.9 F
12/30/25	04:00	0.0 F	0.053 F	25.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	20.8 F	199.9 F
12/30/25	05:00	0.0 F	0.053 F	31.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.4 F	20.8 F	199.9 F
12/30/25	06:00	0.0 F	0.053 F	22.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.2 F	20.8 F	199.9 F
12/30/25	07:00	0.0 FC	0.011 FC	25.7 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.023 FC	3.7 FC	14.1 FC	199.9 F
12/30/25	08:00	0.0 F	0.026 F	51.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.0 F	20.8 F	199.9 F
12/30/25	09:00	0.0 F	2.646 F	51.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.1 F	20.9 F	199.9 F
12/30/25	10:00	0.0 F	2.646 F	49.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.9 F	20.9 F	199.9 F
12/30/25	11:00	0.0 F	2.646 F	58.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.4 F	20.9 F	199.9 F
12/30/25	12:00	0.0 F	2.646 F	41.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.6 F	20.9 F	199.9 F
12/30/25	13:00	0.0 F	0.026 F	40.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.5 F	20.8 F	199.9 F
12/30/25	14:00	0.0 F	3.969 F	39.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.6 F	20.9 F	199.9 F
12/30/25	15:00	0.0 F	0.040 F	35.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.1 F	20.8 F	199.9 F
12/30/25	16:00	0.0 F	3.969 F	63.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.6 F	20.9 F	199.9 F

Source		UNIT_C										
Parameter	Unit	COLB/HR (LB/HR)	COLB/MM (LB/MMBTU)	COPPMC (PPMC)	NH3FLOW (LB/HR)	NH3MOLE (LB/HR)	NH3SLIP (PPM)	NOXLB/HR (LB/HR)	NOXLB/MM (LB/MMBTU)	NOXPPMC (PPMC)	O2 (%)	SCRTEMP (DEG_F)
12/30/25	17:00	0.0 F	2.646 F	32.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	20.9 F	199.9 F
12/30/25	18:00	0.0 F	0.026 F	45.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.3 F	20.8 F	199.9 F
12/30/25	19:00	0.0 F	2.646 F	35.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.9 F	20.9 F	199.9 F
12/30/25	20:00	0.0 F	2.646 F	34.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.8 F	20.9 F	199.9 F
12/30/25	21:00	0.0 F	2.646 F	46.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.6 F	20.9 F	199.9 F
12/30/25	22:00	0.0 F	2.646 F	37.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.6 F	20.9 F	199.9 F
12/30/25	23:00	0.0 F	2.646 F	36.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.7 F	20.9 F	199.9 F
12/31/25	00:00	0.0 F	2.646 F	42.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.1 F	20.9 F	199.9 F
12/31/25	01:00	0.0 F	2.646 F	41.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	0.5 F	20.9 F	199.9 F
12/31/25	02:00	0.0 F	3.969 F	47.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.9 F	20.9 F	199.9 F
12/31/25	03:00	0.0 F	3.969 F	48.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	3.4 F	20.9 F	199.9 F
12/31/25	04:00	0.0 F	3.969 F	49.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.6 F	20.9 F	199.9 F
12/31/25	05:00	0.0 F	3.969 F	41.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	2.0 F	20.9 F	199.9 F
12/31/25	06:00	0.0 F	2.646 F	28.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	1.8 F	20.9 F	199.8 F
12/31/25	07:00	0.0 FC	0.011 FC	58.8 FC	0.0 F	0.0 F	0.0 FC	0.0 FC	0.023 FC	8.8 FC	14.1 FC	199.8 F
12/31/25	08:00	0.0 F	0.053 F	50.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.022 F	7.1 F	20.8 F	199.8 F
12/31/25	09:00	0.0 F	0.053 F	43.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.022 F	6.5 F	20.8 F	199.9 F
12/31/25	10:00	0.0 F	0.053 F	40.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.022 F	5.3 F	20.8 F	199.9 F
12/31/25	11:00	0.0 F	0.053 F	38.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.022 F	5.7 F	20.8 F	199.8 F
12/31/25	12:00	0.0 F	0.053 F	34.7 F	0.0 F	0.0 F	0.0 F	0.0 F	0.022 F	4.3 F	20.8 F	199.8 F
12/31/25	13:00	0.0 F	0.053 F	40.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.022 F	5.1 F	20.8 F	199.8 F
12/31/25	14:00	0.0 F	0.053 F	43.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.022 F	5.7 F	20.8 F	199.9 F
12/31/25	15:00	0.0 F	0.053 F	36.9 F	0.0 F	0.0 F	0.0 F	0.0 F	0.000 F	4.3 F	20.8 F	199.9 F
12/31/25	16:00	0.0 F	0.053 F	34.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.022 F	4.4 F	20.8 F	199.8 F
12/31/25	17:00	0.0 F	0.053 F	36.1 F	0.0 F	0.0 F	0.0 F	0.0 F	0.022 F	5.1 F	20.8 F	199.8 F
12/31/25	18:00	0.0 F	0.053 F	34.2 F	0.0 F	0.0 F	0.0 F	0.0 F	0.022 F	4.0 F	20.8 F	199.8 F
12/31/25	19:00	0.0 F	0.053 F	36.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.022 F	4.5 F	20.8 F	199.9 F
12/31/25	20:00	0.0 F	0.053 F	39.0 F	0.0 F	0.0 F	0.0 F	0.0 F	0.022 F	5.0 F	20.8 F	199.9 F
12/31/25	21:00	0.0 F	0.053 F	33.6 F	0.0 F	0.0 F	0.0 F	0.0 F	0.022 F	4.3 F	20.8 F	199.9 F
12/31/25	22:00	0.0 F	0.053 F	36.4 F	0.0 F	0.0 F	0.0 F	0.0 F	0.022 F	4.6 F	20.8 F	199.8 F
12/31/25	23:00	0.0 F	0.053 F	35.5 F	0.0 F	0.0 F	0.0 F	0.0 F	0.022 F	4.7 F	20.8 F	199.9 F



Average	0.0	0.000	0.0	0.0	0.0	0.0	0.0	0.0	0.000	0.0	0.0	0.0
Minimum	0.0	0.000	0.0	0.0	0.0	0.0	0.0	0.0	0.000	0.0	0.0	0.0
Maximum	0.0	0.000	0.0	0.0	0.0	0.0	0.0	0.0	0.000	0.0	0.0	0.0

Average Data

Plant: Midway Sunset

Interval: 12 Month

Type: Roll

Report Period: 01/01/2025 00:00 Through 12/31/2025 23:59

Time Online Criteria: 1 minute(s)

Source

UNIT_C
GASMMSCF (MMSCF)

01/25	526.9
02/25	588.2
03/25	693.9
04/25	687.4
05/25	634.0
06/25	569.3
07/25	463.8
08/25	373.4
09/25	289.8
10/25	205.6
11/25	191.2
12/25	188.4

Average 451.0

Minimum 188.4

Maximum 693.9

Summation 5,411.9

Geometric Mean 405.6

Included Data Points 12

Total number of Data Points 12

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 01/15/26 09:35

C = Calibration

S = Substituted

*** = Suspect**