



DOCKET

12-BSTD-1

DATE APR 26 2012

RECD. APR 26 2012

April 26, 2012

Comments regarding the PROPOSED 2013 REVISIONS TO THE CALIFORNIA BUILDING ENERGY EFFICIENCY STANDARDS and GREEN BUILDING STANDARDS CODE, TITLE 24, PARTS 1, 6 and 11, DOCKET NO. 12-BSTD-1, CEC-400-2012-002 (Process Boilers)

To the CALIFORNIA ENERGY COMMISSION:

Enovity administers the boiler efficiency program on behalf of PG&E, and has done so since 2006. With our expertise in the energy analysis of boiler systems, Enovity provides the following comments regarding the analysis for the proposed process boiler measures conducted in the CASE Report for Process Boilers, dated October 2011.

1) The analysis conducted for these measures is based on a PV averaged natural gas cost of \$1.22 per therm. We recommend that this assumed gas cost be reviewed, as current natural gas costs for industrial customers and future projections (such as those from the DOE EIA) appear to contradict this assumption and point towards lower gas costs. This assumption will impact the cost/benefit results. With the current and projected low natural gas costs, we have concluded that certain boiler energy efficiency measures are not as cost-effective as they were in recent years.

2) The analysis for the combustion fan VFD measure does not take into account the realization that many burner control manufacturers require O₂ trim control to be installed with a fan VFD (i.e., a packaged burner control system with parallel positioning controls, O₂ trim and fan VFDs). The requirement to install O₂ trim control increases the measure cost and also the combined effectiveness since O₂ may not provide much incremental natural gas energy savings. (See the comments below regarding O₂ trim control.) It is our experience that the packaged control upgrade for burner parallel position controls with O₂ trim and a combustion fan VFD is typically cost effective for larger boilers with high annual runtime. The end result is that the 10 hp requirement may be too low of a cutoff and may result in a cost burden for many new process boiler installations.

3) While parallel positioning controls is a good measure for boiler energy efficiency, we are concerned that the calculated energy savings may be over estimated. Our primary concern is that the base case assumption of 6.5% to 10% excess O₂ is unreasonably high, particular for new boilers with single point mechanical linkage control. In many cases, older boilers have been found to operate in this range of excess O₂, but newly installed boilers will likely operate with a lower range of excess O₂. Over time the linkage controls will likely not achieve the same excess O₂ levels as originally installed. Additionally, in our experience we have found many existing

(older) boilers operating with excess O₂ levels below the assumed range of 6.5% to 10%. It depends on the type of burner, the NO_x levels, the burner and boiler condition, if the boiler is located indoors or outdoors, and how the linkage controls were configured during tuning. From our measure workpaper for the PG&E Boiler Efficiency Program, we reported on an average savings of 0.26 therms per MBtuh for burner control upgrades (as a retrofit measure). Comparatively, the analysis in the CASE Report appears to have an average savings of 0.34 therms per MBtuh as an incremental analysis for newly installed process boilers. The analysis in the CASE Report is based on a weighted average reduction of 3.8% excess O₂ (from 8.8% to 5%). From our experience (based on actual pre and post measurements), an average 3.8% reduction in the excess O₂ is likely too high to assume across all boilers. It can be achieved for some existing boilers, but may not be appropriate as an average for all newly installed boilers.

4) The analysis for the O₂ trim control measure does not account for the impact of boiler NO_x regulations. Maintaining 3% O₂ is not possible for most low or ultra NO_x burners (or may require a more expensive external NO_x treatment system in order to achieve this level of O₂). Also, many ultra low NO_x burners are equipped standard with O₂ trim control in order to maintain their ultra low NO_x levels.

5) The statewide energy savings for O₂ trim does not indicate that savings were only applied to new boilers that are not low or ultra low NO_x, as was the case with parallel positioning controls.

6) We recommend that O₂ trim only be required for boilers located outdoors or in which the combustion air temperature/humidity tracks ambient air conditions (assuming it is indeed a cost effective measure to mandate for certain size boilers). For process boilers in which the combustion air temperature is relatively constant, O₂ trim control will likely not provide as much incremental energy savings. This was demonstrated in the analysis of an actual installation that was analyzed by Enovity and PECEI prior to the CASE Report. In cases where the combustion air conditions are relatively constant, parallel positioning controls can be configured to provide a lower excess air level than compared to boilers in which the combustion air conditions will vary from the actual conditions during the configuration and tuning. O₂ trim control will compensate for changes in the combustion air temperature and humidity and is most advantageous in this application.

Thank you,

A handwritten signature in black ink, appearing to read "E. Koepfel".

Eric Koepfel, P.E.
Technical Director, Enovity, Inc.