

<b>DOCKETED</b>	
<b>Docket Number:</b>	21-ESR-01
<b>Project Title:</b>	Resource Planning and Reliability
<b>TN #:</b>	270570
<b>Document Title:</b>	California Energy Resource and Reliability Outlook 2026
<b>Description:</b>	N/A
<b>Filer:</b>	J Padilla
<b>Organization:</b>	California Energy Commission
<b>Submitter Role:</b>	Commission Staff
<b>Submission Date:</b>	6/11/2026 3:50:51 PM
<b>Docketed Date:</b>	6/11/2026



# California Energy Resource and Reliability Outlook 2026

Moderator, Dhruv Bhatnagar, Supervisor – Supply Planning Unit, EAD

June 9, 2026

# Housekeeping



- Workshop is being conducted remotely via Zoom
- Workshop is being recorded
- Attendees may participate in the workshop by:
  - Asking questions during public Q&A periods: questions can be entered in the Q&A section of the Zoom application or by using the raise hand feature
  - Making comments during public comment period, and
  - Submitting written comments by 5 pm on June 23rd, 2026

# CERRO Workshop Overview



<b>Opening Remarks</b>	<b>9:00 – 9:05</b>
<b>Comments from the Commissioner(s)</b>	<b>9:05 – 9:15</b>
<b>Introduction – CERRO Overview</b>	<b>9:15 – 9:25</b>
<b>Session 1</b>	<b>9:25 – 10:55</b>
Mid-Term Resource Adequacy Analysis	
Long-Term Reliability and System Planning	
<b>Session 2</b>	<b>10:55 – 12:15</b>
Wildfire Risk Analysis	
Weak Grid Analysis	
<b>Public Comments</b>	<b>12:15 – 12:35</b>
<b>Closing Remarks &amp; Adjourn</b>	<b>12:35 – 12:40</b>

# Commissioner's Opening Comments





# California Energy Resource and Reliability Outlook 2026

Aleecia Gutierrez

CERRO Workshop

June 9, 2026

# California Energy Resource and Reliability Outlook

Statewide assessment of electric, fossil gas, and petroleum resource planning and reliability



- A **comprehensive picture of planning and reliability** throughout California. Topics include:
  - 2026 Summer Conditions
  - Summer 2026 Electric Reliability Analysis
  - Emerging Loads and Demand Flexibility
  - **Electric Resource Planning (Mid-term and Long-term)**
  - Maintaining Reliability Through Extreme Events
  - Western Interconnection and Coordination
  - Gas System Reliability
  - Petroleum Market and Short-Term Outlook
  - Fossil Gas Plant Performance Updates

# Report Highlights





# Clean Energy Highlights

- The entire state has run on **100% clean energy** for some part of the day **almost every day this year**.
- As of November 2025, the state has more than **16,900 MW of battery energy storage capacity**, up from 770 MW in 2019.
- In June 2025, the CEC approved **the world's largest battery energy storage project** under its Opt-In consolidated permitting authority.
- As of September 2025, there are more than **201,000 public/shared EV chargers** in the state, 68% more than the number of gasoline nozzles.




*Darden Clean Energy Solar + Storage Project*

# 2026 Summer Conditions: Demand


Electricity demand continues to increase and peak in the summer months



### California ISO Coincident Monthly Peaks for Summer 2026



### Noncoincident Annual Peaks for 2026




Source: CEC 2025 IEPR Planning Forecast

# 2026 Summer Conditions: Weather

Climate forecasting predicts above normal temperatures; early fire forecasts indicate above normal fire potential in June/July




## Seasonal Temperature Outlook for July–September



Source: CPC Seasonal Temperature Outlook for July–September 2026, valid March 19, 2026

## Significant Fire Potential Outlook for June – July 2026



Source: WFTIIC Significant Fire Potential Outlook, valid April 2, 2026

# Summer Electric Reliability Outlook



California meets the reliability standard in 2026, with surplus available in most cases

Cautiously optimistic summer outlook: No shortfalls expected under average conditions and extreme events, Tight conditions may occur if there is a coincident fire impacting transmission assets

## Loss of Load Expectation Analysis

Scenario	2026 LOLE (days/year)	Effective Statewide Margins	Effective CAISO Margins
2025 IEPR Planning	0	7-8	5-6
2025 IEPR Pln. w/ Known Loads	0	6-7	6-6.5
2024 IEPR Planning	0	7-8	5-6
2025 IEPR Local Reliability with Known Loads	0	6-7	6-6.5

*\*Surplus is defined by adding firm load. Deficit by adding perfect generation*

## Stack Analysis

	2026 2 <sup>nd</sup> Quarterly Report
<b>Surplus/Shortfalls (MW)</b>	
Average Conditions	6,600
2020 Equivalent Event	4,500
2022 Equivalent Event	2,900



Coincident Fire Risk


System conditions	Surplus/Shortfalls
Average Conditions	<b>2,600 MW</b>
2020 Equivalent Event	<b>500 MW</b>
2022 Equivalent Event	<b>-1,100 MW</b>

# Emerging Loads and Demand Flexibility

2025 IEPR Forecast results show continued peak demand growth




## Statewide Data Center Maximum Demand Forecast, including Existing Load



Source: CEC staff based on utility data as of December 2025

## Data Center Share of California ISO Peak Demand




Source: CEC staff based on utility data as of December 2025

# Gas System Reliability: Peak Day Gas Balance & Storage Inventory






The gas system is anticipated to meet Summer 2026 forecasted peak gas demand

Summer peak day gas balance for PG&E and SoCalGas



Projected storage inventory levels for PG&E and SoCalGas and over the summer injection season



Source: CEC staff based on utility data



# Electric Resource Planning Issues – Mid-Term System Reliability

Alyssa Tavares

California Energy Resource and Reliability Outlook Workshop  
June 9, 2026



# Overview: Mid-term (5-10 year) Probabilistic Assessment


- Objective: Assess system reliability under ordered procurement – is existing and ordered procurement sufficient to meet the reliability criterion in future years, and by how much
- Evaluates California statewide system including Investor-Owned Utilities (IOUs) and Publicly-Owned Utilities (POUs)
- Multiple load scenarios
  - Base forecast
  - Base forecast + Known Loads
  - Prior-year forecast comparison
  - Local reliability



# Probabilistic Loss of Load Expectation (LOLE)

- Reliability standard: less than 0.1 days/year LOLE (1-in-10)
- Captures key risks:
  - Resource availability uncertainty
  - Demand variability (hourly/weather-driven)
  - Outage events
  - Import limitations

Illustrative Example of LOLE



Source: 2023 SPP Loss of Load Expectation Report

# Resource Adequacy

## Overall Approach



### Demand Forecast

- 17 weather year dependent loads
- Includes extreme (tail-risk) conditions
- Annual forecast with load modifiers

### Supply Inputs

- Energy Information Administration (EIA)
- Quarterly Fuel and Energy Report (QFER)
- CAISO Master Capability Generating List
- CPUC procurement requirements (NQC)

*Supply includes both fully deliverable (CAISO NQC list) and energy only resources*

### Model Topology

- 7 California BAs – PG&E, SCE, SDG&E, LADWP, BANC, IID, TIDC
- Imports/exports constrained to CAISO transfer limits

### RA Model

- Simulation Design: 17 weather years x 24 outage draws
- Co-optimizes energy + reserves under system conditions

### Results

- LOLE
- Surplus/Deficit

# Resource Adequacy

## Demand



### Stochastic Loads



- Chronological; 17 weather year patterns.

### Scenarios



- Base Case, 2025 IEPR Planning Forecast
- 2025 IEPR Planning Forecast with Known Loads
- 2024 IEPR Planning Forecast
- 2025 IEPR Local Reliability Forecast

### Load Modifiers



- Additional Achievable Modifiers:
  - Additional Achievable Energy Efficiency (AAEE)
  - Additional Achievable Fuel Substitution (AAFS)
  - Additional Achievable Transportation Electrification Light-Duty Vehicle (AATE LDV)
  - Additional Achievable Transportation Electrification Medium- and Heavy-Duty Vehicle (AATE MDHD)
- Other Modifiers:
  - Climate Change, Data Centers, Storage, Electric Vehicles

# Resource Adequacy

## Supply



Category	CAISO (MW)	Non-CAISO (MW)	CPUC Procurement (MW)		
			2026	2027	2028
Natural Gas	25,385	9,949	0	0	0
Utility Scale PV	22,273	1,957	2,700	2,700	2,700
Distributed PV	16,712	1,825	0	0	0
Batteries	16,701	556	2,364	2,364	0
Pumped Storage Hydro	2,658	1,682	0	0	0
Land Based Wind	6,612	135	0	0	0
Geothermal	2,020	950	0	0	0
Demand Response	2,466	302	0	0	0
Nuclear	2,393	0	0	0	0
LDES	0	0	0	0	1,110
Other	366	88	0	0	0

**Includes CPUC Procurement Orders as of December 2025**

- CPUC Procurement Order D.23-02-040 (MTR)
  - 2,000 MW NQC in 2026 and 2,000 MW NQC in 2027
- CPUC Procurement Order D.21-06-036 (MTR) ordered 11,500 MW NQC from 2023-2028
  - 2,000 MW NQC in 2028
- **Does Not** include Feb 2026 CPUC IRP Decision (R.25-06-019)
  - Procurement of 6,000 MW NQC by June 2032




# Resource Adequacy

## California Transmission System



- California-centric
  - Out of state – modeled as generic imports
- 7 Regions
  - Investor-owned utilities (IOUs)
    - PG&E, SCE, SDG&E
  - Publicly-owned utilities (POUs)
    - BANC, TIDC, LADWP, IID
- Import Limits
  - Total CAISO Import Limit: 11,665 MW
  - Resource Adequacy Import Limit: 5,500 MW
    - Morning and Afternoon peaks (H6-9, H17-23)
    - Across entire year



# Resource Adequacy

## LOLE - Results



LOLE Scenarios (days/year)	2031	2036
Base Scenario, 2025 IEPR Planning	0.005	1.64
2025 IEPR Planning with Known Loads	0.15	9.89
2024 IEPR Planning	0.38	> 10
2025 IEPR Local Reliability with Known Loads	0.64	> 10

Scenarios – Effective Surplus/Deficit (GW) *	2031	2036
Base Scenario, 2025 IEPR Planning	3 – 4 Surplus	6 – 7 Deficit
2025 IEPR Local Reliability with Known Loads	4 – 5 Deficit	> 10 Deficit

- In 2026, all scenarios meet 0.1 days/year LOLE reliability criterion
- By 2031, higher load scenarios no longer meet the 0.1 days/year reliability criterion under ordered procurement through 2028
  - 2031: Base scenario continues to meet the reliability criterion. The inclusion of known loads leads to the exceedance of the criterion. Including the 6 GW procurement, all scenarios should meet the criterion.
  - 2036: As expected, no scenarios meet the criterion.
  - CPUC procurement decision D.25-06-019 ordered an additional 6,000 MW NQC procurement by June 2032 (not included in this analysis). This analysis confirms the prudence of that decision.

\*Amount of surplus or deficit capacity to achieve 0.1 days/year LOLE criteria for each study year.



# Resource Adequacy

## Results – Distribution of Unserved Energy

		2031 + 3GW Fixed Load											
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Hour	0	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	1	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	2	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	3	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	4	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	5	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	6	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	7	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	8	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	9	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	10	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	11	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	12	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	13	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	14	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	15	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	16	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	17	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	18	0%	0%	0%	0%	0%	0%	0%	0%	7%	0%	0%	0%
	19	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	20	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	21	0%	0%	0%	0%	0%	0%	0%	0%	9%	0%	0%	0%
	22	0%	0%	0%	0%	0%	0%	0%	0%	76%	0%	0%	0%
	23	0%	0%	0%	0%	0%	0%	0%	0%	9%	0%	0%	0%
		Month											

		2036 + 7GW Perfect Generation											
		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Hour	0	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	1	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	2	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	3	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	4	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	5	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	6	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	7	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	8	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	9	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	10	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	11	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	12	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	13	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	14	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	15	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	16	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	17	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	18	0%	0%	0%	0%	0%	0%	0%	0%	14%	0%	0%	0%
	19	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	20	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	21	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
	22	0%	0%	0%	0%	0%	0%	0%	0%	58%	0%	0%	0%
	23	0%	0%	0%	0%	0%	0%	0%	0%	27%	0%	0%	0%
		Month											

Source: CEC Staff



# Resource Adequacy

## *Future Considerations*

- Summer remains greatest risk season, which is a change from prior demand forecasts moving risk to winter periods
- Need for continued resource development in the state.
  - Findings consistent with the February 2026 CPUC IRP decision (R.25-06-019) ordering procurement of 6,000 MW NQC by June 2032.
  - Need to continue to monitor demand forecast uncertainty- highest demand scenarios may results in a need for additional procurement
- Future Analysis
  - Wildfire Risks to Power System
  - Weak Grid Analysis
  - Winter Reliability Risks



**Thank you**



# **Long-Term Reliability and System Planning – Resource Availability and California’s Future Electric System**

Hannah Craig

California Energy Resource and Reliability Outlook Workshop

June 9, 2026

# CERRO Modeling Goals



- Support the state's effort to meet climate goals, which requires reliability analysis of different scenarios of clean energy development:
  - Evaluate the risks and uncertainties that could shape how the clean energy transition unfolds.
  - Estimate the types of resources most impactful to that transition, the volume of resources required, and the risk associated with each type of resource.
  - Understand how different assumptions could impact California's electric system reliability through 2045:
    - Resource costs and availability
    - Policy and tax incentives enabling resource development
    - Land use constraints limiting resource availability

# Long-term System Scenarios



## Feasibility Scenarios

**Base:** Allowed to build all emerging resources at their default prices.

**No CCS:** Removes the availability of Carbon Capture & Storage (CCS) retrofits from the portfolio.

**No Emerging Resources:** Removes the availability of emerging resources from the portfolio.

## Cost Reduction Scenarios

**Tax Credits Extension:** Maintains the tax credit regime from Inflation Reduction Act.

**Low-Cost LDES:** Models 70% cost reduction for Long Duration Energy Storage (LDES).


**No CCS – Low-Cost OSW:** Models the Advanced cost for Offshore Wind (OSW) from NLR's ATB.

## Land Use Scenarios

**No Emerging – High Wind Potential:** Adds 35 GW of low-quality in-state wind as a candidate resource.

**No Emerging – TCR Land Use Screen:** Reduced wind and solar potentials due to Terrestrial Climate Resilience (TCR) higher conservation land use screen.


# Demand Assumptions



- 2025 IEPR Demand Forecast – Planning
- Lower electrification assumptions than SB100 or 2024 IEPR Forecast, due to slower adoption following federal actions in 2025.
- 70% increase in total demand by 2045.
- Winter peaking by 2045.

Source: CEC Staff

# Build Costs for Candidate Resources



- Costs sourced from National Laboratory of the Rockies Advanced Technology Baseline (ATB) 2024 (most recent).
- Wind, solar, lithium batteries, and CCS retrofits are the lowest-cost resources.
- OSW costs vary by CA region depending on transmission.
- CCS costs include estimates for cost of carbon transport and storage.\*
- Investment Tax Credit expires in 2035 for energy storage, geothermal, and biomass.

Source: CEC Staff, based on data from NLR ATB 2024

**CEC is seeking stakeholder feedback on build costs and resource availability**

\*Sourced from “Geospatial Modeling of Geologic Carbon Dioxide Storage Potential” by Electric Power Research Institute

# Resource Portfolio Targets



## ➤ State Goals


- SB 100/SB 1020: Percent of retail sales must be from renewable and zero-carbon resources.
- AB 1279: 85% statewide anthropogenic GHG emissions reductions and carbon neutrality by 2045
- 2045 electric sector GHG emissions from CA 2022 Scoping Plan

## ➤ Reliability Requirements

- 22.5% statewide planning Reserve Margin (PRM) in the capacity expansion model
- 0.1 loss of load expectation (LOLE) target in the reliability model
- No unserved load in the dispatch model

Year	SB100 Retail Sales Target	GHG Emissions	Planning Reserve Margin
2030	[60% RPS]	30 MMT	22.5%
2035	90%	25 MMT	22.5%
2040	95%	16.9 MMT	22.5%
2045	100%	6.9 MMT	22.5%

# Modeling Process



# Modeling Results for 2035



---




# 2035 Results Across Scenarios

## Mid-term Resource Buildout: All Scenarios Follow Current Trends



- 10-year outlook shows high loads and high buildout to reliably meet interim GHG targets:
  - Load increases by 40%.
  - Gas generation reduced by 50%.
  - 10 GW of buildout per year, mostly solar and storage.
- Cost trajectory impacted more by federal action than emerging resources:
  - IRA Subsidies scenario has more renewables, more buildout, but 20% lower modeled costs.
  - CCS is only emerging resource deployed.
  - Minimal cost impact without CCS.
  - Other scenarios look similar to Base and No CCS.



Source: CEC Staff

# 2035 Results Across Scenarios

## Annual Generation by Fuel and Monthly Gas Generation





### ➤ Annual Generation Mix:

- Similar across scenarios
- Solar/wind provide 67% of energy
- CCS Retrofits provide only 5% of generation in Base scenario

### ➤ Monthly Gas Patterns:

- Some gas generation remains in all hours.
- Gas use in winter is similar to today.
- Gas use in spring/summer is much lower.
- Solar/wind + storage most effective at reducing summer gas use.




Source: CEC Staff



# 2035 Reliability Implications

## Reliability Met Through Continued Solar and Storage Buildout

- Unserved energy is limited and all scenarios meet 0.1 days of unserved energy per year target.
- Risk occurs during September monsoonal event:
  - High loads (~1 in 5 event)
  - Clouds reduce solar generation
  - Batteries deplete
  - Unserved energy appears at night
- No unserved energy in winter or during peak load/net load hours
- This assumes high buildout of resources to meet GHG goals.



Source: CEC Staff


# Modeling Results 2045



# Feasibility Scenarios

## Meeting Demand Long-term Reliant on Clean Firm Resources

- Low-GHG firm resources selected in all scenarios, demonstrating need and cost-competitiveness even at high costs per kW:
  - 10 GW of CCS in Base
  - 10 GW of EGS in No CCS
  - 3 GW of geothermal and biomass in No Emerging
- Removing CCS raises modeled costs by 15% with current CCS assumptions.
- Removing other emerging resources raises costs by 1%
- EGS costs 10x solar per kW but generates power in winter when it is most needed.




Source: CEC Staff



# Feasibility Scenarios

## Gas Generation Maintained in Winter to Meet Demand

- Emerging resources contribute significantly to overall generation mix:
  - 11% from CCS in Base Scenario
  - 15% from Geothermal in No CCS Scenario
- Fossil gas from unretrofitted plants must decline from levels seen today:
  - Less than 3% of total generation
  - Down from 34% today
  - Highly concentrated in specific winter days
- Seasonal variations:
  - Most gas use in winter
  - Little to no gas use in spring/summer without CCS
  - Need to evaluate implications, feasibility and requirements of no gas generation for multiple months





Source: CEC Staff

# Feasibility Scenarios

## Reliability Requirements add Summer Peak and Winter Resource Needs

- CCS Retrofits add low GHG energy but not new capacity.
- Reliability constraints lead to adding ~30GW of solar + storage to Base scenario.
- Load growth to 2045 will require 150+ GW of new generation capacity to meet reliability targets, not just clean energy targets.
- In 2045, unserved energy occurs at night during energy-constrained events in summer and winter.



Source: CEC Staff

# Cost Reduction Scenarios – Subsidies & LDES


Cost Reductions Alter Portfolios, but Long-Term Capacity Needs Remain

## ➤ Effect of IRA Tax Credits:

- Modeled costs 15% lower
- Renewables more attractive
- Less CCS and geothermal

## ➤ Low-Cost LDES:

- 70% lower capex costs
- Builds 30 GW of 12-hour batteries
- 0 GW of 24-hour batteries
- Higher solar build
- Similar CCS build
- Modeled costs 5% lower





Source: CEC Staff

# Cost Reduction Scenarios – LDES

LDES can Deliver Summer, but not Winter, Clean Firm Capacity



- LDES in Summer:
  - Sun shines 12-16 hours
  - LDES is 70% efficient
  - LDES fleet can get to 70-100% charged
- LDES in Winter:
  - Sun shines 6-8 hours
  - Efficient lithium batteries charge first.
  - Large LDES fleet 0-25% charged most of winter
  - Adding hours of battery energy capacity does not solve energy limitations
  - Natural gas plants provide winter energy.




Source: CEC Staff

# Cost Reduction Scenarios – OSW

## Offshore Wind Alters the Portfolio, but Delivers Limited Firm Capacity

- 5 GW of OSW are deployed under the ATB Advanced Cost projection, which is 25% below the Moderate projection used in other scenarios.
- Capex costs include the costs of construction and transmission, but not the cost of port upgrades or other infrastructure.
- “Breakeven” price point – deployed but minimal impact on portfolio costs.
- Capital cost comparison:
  - \$3,700/kW for OSW (Advanced Cost)
  - \$1,100/kW for onshore wind
  - \$7,000/kW for EGS




Source: CEC Staff

# Wind and Land Use Scenarios

Low Quality Wind Provides a Complementary Resource; Land Screen Pushes Solar

- Low-quality wind provides much less energy per kW than solar, but complementary profile results in significant deployment.
  - 32 of 35 GW available deployed
  - Modeled costs reduced by 6%
- TCR screen reduces total land available for development by about 40%.
  - 2 GW less wind available
  - 3 GW more solar built
  - 1% increase in costs




Source: CEC Staff

# Wind and Land Use Scenarios

## Wind Delivers Generation on Low-Solar Days



- Low-solar days see high gas burn.
- Low-solar days tend to be cloudy, stormy, windy days
- Complementary wind profile reduces need to overbuild solar and curtail it all in summer.
- Resource diversity is very impactful for winter loads, even from intermittent sources like wind.



Source: CEC Staff

# Conclusions





# Conclusions

## Maintaining Reliability While Meeting Climate Goals Under Future Uncertainty

- Meeting GHG goals will require significant increase in electric demand and consequent deployment of clean energy resources.
  - Build rates of 7-10 GW/year every year until 2045
  - Critical summer peak and winter night capacity needs
- High demands and low renewable output in winter means firm technologies/resource diversity is strongly valued to meet reliability even at current cost projections.
  - EGS built at \$7,000/kW
  - CCS reduces portfolio costs by 15%
  - 32 GW of marginal wind deployed without clean firm resource available
  - OOS Wind selected in all scenarios
- IRA repeal will raise overall costs, making clean firm technologies more cost-competitive relative to large renewable and storage builds to meet reliability.
  - Modeled cost increases of 15-20%
  - Higher CCS uptake in base scenario.

# Questions for Stakeholders



- Do you have any feedback or additional data you can share on reasonable assumptions on resource availability and costs, particularly for emerging resources?
- Do you have any inputs or data you can share on resource performance assumptions, particularly for emerging resources?
- What long-term concerns about reliability and achieving the state's electric sector goals keep you up at night? What issues/topics might benefit from CEC analysis in the future?