

DOCKETED

Docket Number:	25-BSTD-03
Project Title:	2028 Energy Code Pre-Rulemaking.
TN #:	270994
Document Title:	Presentations - June 23, 2026 (Day 1) - 2028 Energy Code Staff Pre-Rulemaking Workshop
Description:	Presentations from the June 23, 2026, 2028 Energy Code staff pre-rulemaking workshop.
Filer:	Michael Shewmaker
Organization:	California Energy Commission
Submitter Role:	Commission Staff
Submission Date:	6/25/2026 10:46:36 AM
Docketed Date:	6/25/2026



2028 Energy Code, Pre-Rulemaking

Presenter: Payam Bozorgchami P.E., Building Standards Branch

Date: June 23, 2026



Housekeeping Rules

Public Comments

Zoom App/Online

- Click “raise hand”

Telephone

- Press *9 to raise hand
- Press *6 to Mute/Unmute

When called upon

- CEC will open your line
- Unmute on your end
- Spell name and state affiliation, if any
- 2 minutes or less per speaker, 1 speaker per entity

Agenda for Today's Workshop




	Topics	Presenter
1	Introduction & 2028 Overview	Payam Bozorgchami
2	Construction Forecast	Payam Bozorgchami; NORESO
4	Updates to Solar (PV) and Battery Energy Storage Systems (BESS)	Muhammad Saeed; NORESO
5	Nonresidential Existing Building Performance Foundations	Hab Tewelde; NORESO
6	Nonresidential AC to Heat Pump (5 to 20 tons)	Hab Tewelde; NORESO
7	Adjourn	- - - -

California Energy Commission's Authority & Process



Public Resources Code (PRC 25402): Reduction of wasteful, uneconomic, inefficient, or unnecessary consumption of energy

- Warren Alquist Act Signed into law in 1974
- Mandates updates to Building Efficiency Standards and requires the building departments to enforce them through the permit process



Assembly Bill 130 (2025)



Limits updates to building standards affecting residential units before 2031 code cycle (effective date no sooner than Jan 1, 2032)

- All 2028 Energy Code updates will exclude buildings of Group R Occupancy including its common or public use areas
 - Residential Group R is defined Part 2 of Title 24
- Residential energy metrics will remain unchanged until 2031 Energy Code, including compliance metrics and weather files
- September 2025, CA Building Standards Commission Information Bulletin 25-03:
 - <https://www.dgs.ca.gov/BSC/News/Page-Content/Building-Standards-Commission-News-List-Folder/IB-25-03-AB-130>

Proposed Definition for Group R Occupancies

Will provided exceptions through the Energy Code



- **GROUP R OCCUPANCIES** residential Group R and common and public use areas as defined in Chapter 2 of the CBC, serving residential units, and structures accessory to residential units designated and constructed in accordance with the CRC, are also subject to Assembly Bill 130-2025.


Proposed Definition for Group R Occupancies

Our understanding of Multifamily Occupancy in a Mixed Occupancy Building.



R-Occupancy (2025 Energy Code Stringency)

- 1st floor Amenities (A-2 lobby, R-2 corridors and stairs to multifamily occupancy, B leasing office). 2-5 floors supporting dwelling units and circulation to those dwelling units




All of the non-R Occupancies that are not a sub occupancy nor share common areas with the R Occupancy and will be subject to 2028 stringency.

Proposed Definition for Group R Occupancies

Our understanding of Hotel/Motel in a Mixed Occupancy Building.



There is access to the restaurant from the hotel as sub-occupancy



One of the non-R Occupancies that is not a sub occupancy to the R Occupancy has access to common area of the R occupancy via a fire rated door and will be subject to 2028 stringency.

2028 Energy Code Drivers and Themes



State Goals

- Contribute to the state's GHG reduction goals
- Increase building energy efficiency cost-effectively

2028 Energy Code Areas of Interest – Nonresidential Buildings

- Continue to encourage efficient building decarbonization where possible
- Promote demand flexibility
- Covered process loads
- Existing buildings
- Compliance improvements



2025 Restructured Standards

To Be The New Structure for the 2028 Energy Code



HOME



PROCEEDINGS ▾

RULES AND REGULATIONS ▾

PROGRAMS AND TOPICS ▾

2025 Energy Code for
Residential and
Nonresidential Buildings

2025 ENERGY CODE >



Restructured 2025 Energy Code – California Code of Regulations – Title 24, Part 6 (For Information Only)

FIND IT: <https://www.energy.ca.gov/programs-and-topics/programs/building-energy-efficiency-standards/2025-building-energy-efficiency>

Organized by Building System



Chapter	Section	Subject.	Title
1	100.0-100.2	(a)(b)(c) 1.2.3. A.B.C. i.ii.iii a.b.c.	General Provisions All building types
2	110.0-110.12		Mandatory All building types
3	120.0-120.10		Mandatory Nonresidential, Covered Process
4	130.0-130.5		Mandatory Lighting & Electrical Nonresidential, Covered Process
5	140.0-140.10		Prescriptive and Performance Nonresidential, Covered Process
6	141.0-141.1		Additions, Alterations and Repairs Nonresidential, Covered Process
7	150.0		Mandatory Single-family
8	150.1		Prescriptive and Performance Single-family
9	150.2		Additions, Alterations and Repairs Single-family
10	160.0-160.9		Mandatory Multifamily
11	170.0-170.2		Prescriptive and Performance Multifamily
12	180.0-180.4		Additions, Alterations and Repairs Multifamily

CURRENT 2025 STRUCTURE

Chapter	Section	Subject.	Title
1	100-102	1.2.3... 1.2.3... 1.2.3... 1.2.3... 1.2.3...	General Provisions All building types
2	200		Definitions All building types
3	300-303		Envelope All building types, Nonresidential, Single-family, Multifamily
4	400-403		HVAC and Ventilation All building types, Nonresidential, Single-family, Multifamily
5	500-503		Plumbing All building types, Nonresidential, Single-family, Multifamily
6	600-603		Electrical and Lighting All building types, Nonresidential, Single-family, Multifamily
7	700-703		Renewables and Storage All building types, Nonresidential, Single-family, Multifamily
8	800-803		Pool and Spa All building types, Nonresidential, Single-family, Multifamily
9	900-911		Process Systems and Equipment Covered Process
10	1000-10001		Design Review and Commissioning Nonresidential

NEW 2028 STRUCTURE



Restructured Energy Code

- In response to industry feedback, we published the 2025 Restructured Code
 - Better aligns the Energy Code with other Parts of Title 24
 - Improves usability and navigation
 - Will be used as the basis for the 2028 Energy Code

Current Code Format

(a) **Roof deck, ceiling and rafter roof insulation.** The opaque portions of roof decks separating attic spaces from ambient air, and ceilings or rafter roofs separating conditioned spaces from unconditioned spaces or ambient air, shall meet the requirements of Items 1 through 4 below:

1. In Climate Zones 4 and 8 through 16, roof decks in newly constructed attics that are above conditioned space shall be insulated to achieve an area-weighted average U-factor not exceeding U-0.184.

Exception 1 to Section 150.0(a)1:

- i. The space-conditioning system air handler and ducts are located entirely in conditioned space below the ceiling separating the occupiable space from the attic; or
- ii. The space-conditioning system air handler is located in unconditioned space and has 12 linear feet or less of supply duct, including the length of the air handler and the plenum, located in unconditioned space, with all other portions of the supply ducts located in conditioned space below the ceiling separating the occupiable space from the attic; or
- iii. The space-conditioning system is a ductless system.

Exception 2 to Section 150.0(a)1: Space-conditioning duct systems buried within insulation in an attic that complies using Section 150.1(b) and is verified according to RA 3.1.4.1.



Restructured Code Format

302.2 [Section 150.0] Mandatory requirements (Newly Constructed, Additions, Alterations).

302.2.1 [Section 150.0(a)] Roof deck, ceiling and rafter roof insulation.

The opaque portions of roof decks separating attic spaces from ambient air, and ceilings or rafter roofs separating conditioned spaces from unconditioned spaces or ambient air, shall meet the requirements below:

302.2.1.1 [Section 150.0(a)1] Attics above conditioned space.

In Climate Zones 4 and 8 through 16, roof decks in newly constructed attics that are above conditioned space shall be insulated to achieve an area-weighted average U-factor not exceeding U-0.184.

Exception 1 to Section 302.2.1.1: The space-conditioning system air handler and ducts are located entirely in conditioned space below the ceiling separating the occupiable space from the attic; or

The space-conditioning system air handler is located in unconditioned space and has 12 linear feet or less of supply duct, including the length of the air handler and the plenum, located in unconditioned space, with all other portions of the supply ducts located in conditioned space below the ceiling separating the occupiable space from the attic; or

The space-conditioning system is a ductless system.

Exception 2 to Section 302.2.1.1: Space-conditioning duct systems buried within insulation in an attic that complies using [Sections 102.5.2](#) and [102.5.5 \[Section 150.1\(b\)\]](#) and is verified according to RA 3.1.4.1.

IOU CASE team and Consultants


Thank You!!



Overview Schedule for the 2028 California Energy Code




IOU CASE Team Schedule



Overview Schedule for the 2028 California Energy Code

2028 Energy Code





Comments for Today's workshop

Due Date: July 17, 2026, by 5:00 PM

Comments to be submitted to:

- <https://efiling.energy.ca.gov/Ecomment/Ecomment.aspx?doCKETnumber=25-BSTD-03>
- Thank you for participating!
- Contact Information: Payam.Bozorgchami@energy.ca.gov



Nonresidential Construction Forecast

Fatemeh Yousefi, NORESO

June 23, 2026



Content

- Purpose of the Construction Forecast
- Data Sources
- Overview of the Development Process
- Methodology and Processing Steps
- Results and Key Insights



Purpose

- Construction forecast estimates the floor area of the existing and future building stock at the building type and climate zone level

- The construction forecast is used to scale prototype level results to statewide results

$$\text{Statewide Savings} = \text{Prototype Savings per Floor Area} \times \text{Forecasted Construction Floor Area}$$

- It is used during measure evaluations and cost-effectiveness analyses for the 2028 Energy Code



Data Sources

- 2025 forecast from Energy Assessments Division (EAD)
- 2025 Dodge building datasets
 - New construction starts data (CAS)
 - New construction completions data (CASC)
 - Building stock data (BSD)
 - Data Center data
- 2025 Department of General Services (DGS) state-owned building dataset
- 2022 University of California (UC)-owned building dataset
- 2020 United States (US) Census Bureau



CALIFORNIA
ENERGY COMMISSION



Office
of the
President



Key Terms

➤ Broad Building Types (12):

General building classification aligned with EAD/BSD

➤ Detailed Building Types (24):

More granular classifications, generally aligned with Energy Code building prototypes

Broad Building Types (EAD/BSD)	Detailed Building Types
Office	Small Office
Retail	Medium Office
School	Large Office
Hotel	Strip Mall
Hospital	Medium Retail
Restaurant	Large Retail
Refrigerate Warehouse	Grocery
Warehouse	K-8 School
Manufacturing Labs	High School
Manufacturing Plants	Large School
Parking	Hotel
Miscellaneous	Hospital
	Restaurant
	Assembly
	Vehicle Service
	CEH
	Non-Refrigerated Warehouse
	Refrigerated Warehouse
	Laboratory
	Manufacturing
	Enclosed Parking
	Open Parking
	Data Center
	Miscellaneous



Overview of the Process


Two sets of floor area estimates for all 16 climate zones: Existing Buildings and New Construction





Process Steps


Construction Forecast for Broad Building Types





Process Steps

Broad-to-Detailed Building Type Shares





Major Updates from 2025 to 2028

Recent Data

Updated Mapping

Some of the mapping updates

Schools

Dodge: Colleges/community colleges = [Large Schools](#); primary schools and junior high schools = [K-8 Schools](#); senior high, vocational, and special-needs schools = [High school](#).
State owned: educational buildings with facilities under CSU or UC = [Large Schools](#); other = [High school](#).

Warehouses

Refrigerated and non-refrigerated warehouse records were remapped; Dodge Mfg War records reclassified.

EAD Alignment

Libraries, museums, laboratories, and special schools moved from “school” to “miscellaneous”.

Miscellaneous

Dodge Animal/Fish/Plant records before 1997 included under Miscellaneous Detailed Building Type.


Laboratory

33% of Dodge BSD “Mfg Labs” floor area added to the Laboratory Detailed Building Type.



Results


Total Building Stock Distribution by Detailed Building Type





Results




Total Building Stock Distribution by Climate Zone





Results

New-construction trends may differ from trends in existing buildings at the climate-zone level.





Results

% Distribution of 2028 Nonresidential New Construction Floor Area

Office, Retail, Warehouse, and School represent over 55% of nonresidential new construction floor area.

Detailed Building Type	Climate Zone																Total
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	
Large Office	0.0%	0.0%	1.6%	0.8%	0.0%	0.8%	0.6%	1.2%	2.8%	0.4%	0.0%	1.9%	0.0%	0.1%	0.0%	0.0%	10.3%
Medium Office	0.1%	0.4%	0.8%	0.6%	0.2%	0.9%	0.5%	1.2%	1.5%	0.9%	0.2%	0.2%	0.3%	0.2%	0.2%	0.1%	8.3%
Small Office	0.0%	0.1%	0.2%	0.0%	0.1%	0.1%	0.0%	0.2%	0.4%	0.1%	0.1%	0.2%	0.2%	0.1%	0.0%	0.0%	1.8%
Large Retail	0.0%	0.0%	1.1%	0.2%	0.0%	0.5%	0.6%	0.7%	1.1%	0.6%	0.2%	0.5%	0.0%	0.0%	0.1%	0.0%	5.7%
Medium Retail	0.1%	0.3%	0.5%	0.4%	0.1%	0.4%	0.3%	0.6%	1.2%	1.2%	0.1%	1.3%	0.7%	0.3%	0.2%	0.1%	7.8%
Strip Mall	0.0%	0.0%	0.1%	0.2%	0.1%	0.3%	0.0%	0.5%	0.4%	0.4%	0.0%	0.1%	0.0%	0.2%	0.0%	0.0%	2.3%
Large School	0.0%	0.1%	0.7%	0.3%	0.1%	0.4%	0.3%	0.6%	0.7%	0.2%	0.1%	0.2%	0.1%	0.1%	0.0%	0.0%	3.9%
High School	0.0%	0.1%	0.4%	0.3%	0.1%	0.2%	0.2%	0.2%	0.5%	0.3%	0.1%	0.4%	0.4%	0.1%	0.0%	0.0%	3.3%
K-8 School	0.0%	0.1%	0.3%	0.1%	0.0%	0.2%	0.2%	0.3%	0.7%	0.5%	0.2%	0.8%	0.2%	0.1%	0.1%	0.1%	3.8%
Non-refrigerated Warehouse	0.0%	0.3%	1.2%	0.6%	0.1%	0.9%	0.4%	1.2%	1.8%	1.3%	0.3%	1.5%	0.5%	0.3%	0.2%	0.1%	10.7%
Hotel	0.0%	0.1%	0.5%	0.3%	0.1%	0.3%	0.3%	0.5%	0.7%	0.3%	0.1%	0.4%	0.1%	0.1%	0.1%	0.0%	3.9%
Assembly	0.1%	0.3%	0.3%	0.4%	0.0%	0.5%	0.3%	0.7%	1.3%	0.5%	0.1%	0.8%	0.2%	0.1%	0.1%	0.0%	5.6%
Hospital	0.0%	0.1%	0.6%	0.3%	0.1%	0.2%	0.3%	0.3%	0.6%	0.5%	0.1%	0.6%	0.2%	0.1%	0.1%	0.0%	4.0%
Laboratory	0.0%	0.0%	1.4%	0.2%	0.0%	0.1%	0.4%	0.2%	0.1%	0.3%	0.0%	0.5%	0.2%	0.0%	0.0%	0.0%	3.5%
Restaurant	0.0%	0.0%	0.2%	0.1%	0.0%	0.2%	0.1%	0.3%	0.5%	0.3%	0.0%	0.2%	0.1%	0.1%	0.0%	0.0%	2.2%
Enclosed Parking Garage	0.0%	0.0%	0.8%	0.9%	0.0%	0.5%	0.6%	1.2%	1.2%	0.1%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	5.4%
Open Parking Garage	0.0%	0.3%	1.1%	1.2%	0.1%	0.8%	1.0%	1.6%	1.6%	0.9%	0.4%	0.6%	0.1%	0.2%	0.1%	0.1%	10.1%
Grocery	0.0%	0.0%	0.1%	0.1%	0.0%	0.0%	0.0%	0.0%	0.1%	0.1%	0.0%	0.1%	0.0%	0.0%	0.0%	0.0%	0.6%
Refrigerated Warehouse	0.0%	0.0%	0.1%	0.1%	0.0%	0.0%	0.0%	0.0%	0.1%	0.0%	0.0%	0.0%	0.1%	0.0%	0.0%	0.0%	0.5%
CEH	0.0%	0.0%	0.1%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.7%	0.0%	0.0%	0.0%	0.2%	0.0%	0.0%	1.3%
Vehicle Service	0.0%	0.0%	0.0%	0.3%	0.0%	0.3%	0.0%	0.4%	0.3%	0.2%	0.2%	0.3%	0.1%	0.0%	0.0%	0.0%	2.2%
Data Center	0.0%	0.0%	0.1%	0.6%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.1%	0.0%	0.0%	0.0%	0.0%	0.8%
Manufacturing	0.0%	0.0%	0.1%	0.1%	0.0%	0.1%	0.0%	0.1%	0.1%	0.2%	0.0%	0.1%	0.1%	0.0%	0.0%	0.0%	0.9%
Miscellaneous	0.0%	0.0%	0.0%	0.0%	0.0%	0.2%	0.0%	0.3%	0.7%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	1.2%
Total	0.4%	2.4%	12.0%	8.0%	1.1%	7.9%	6.3%	12.3%	18.3%	10.0%	2.2%	11.0%	3.7%	2.3%	1.3%	0.8%	100.0%

64%



Results

% Distribution of 2028 Nonresidential Existing Floor Area

Office, Retail, Warehouse, and School represent 55% of nonresidential existing floor area.

Detailed Building Type	Climate Zone																Total
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	
Large Office	0.0%	0.0%	1.4%	0.7%	0.0%	1.1%	0.8%	1.8%	3.2%	0.7%	0.0%	0.9%	0.1%	0.2%	0.0%	0.0%	11.1%
Medium Office	0.0%	0.3%	0.8%	0.4%	0.1%	0.5%	0.5%	0.6%	0.9%	0.7%	0.2%	1.0%	0.3%	0.1%	0.1%	0.0%	6.7%
Small Office	0.0%	0.1%	0.2%	0.1%	0.1%	0.1%	0.1%	0.1%	0.2%	0.3%	0.1%	0.4%	0.2%	0.1%	0.1%	0.0%	2.4%
Large Retail	0.0%	0.1%	0.7%	0.3%	0.0%	0.4%	0.3%	0.5%	0.7%	0.6%	0.1%	0.7%	0.3%	0.1%	0.1%	0.0%	5.0%
Medium Retail	0.0%	0.1%	0.5%	0.3%	0.1%	0.5%	0.4%	0.8%	1.2%	0.8%	0.1%	0.7%	0.3%	0.2%	0.1%	0.1%	6.0%
Strip Mall	0.0%	0.1%	0.4%	0.2%	0.1%	0.5%	0.3%	0.6%	0.9%	0.8%	0.1%	0.5%	0.3%	0.2%	0.1%	0.1%	5.2%
Large School	0.0%	0.1%	0.6%	0.2%	0.1%	0.4%	0.2%	0.3%	0.5%	0.2%	0.0%	0.4%	0.1%	0.0%	0.0%	0.0%	3.1%
High School	0.0%	0.1%	0.3%	0.2%	0.0%	0.3%	0.2%	0.5%	0.7%	0.5%	0.1%	0.4%	0.3%	0.1%	0.1%	0.0%	3.9%
K-8 School	0.0%	0.1%	0.3%	0.2%	0.0%	0.2%	0.2%	0.4%	0.6%	0.6%	0.1%	0.5%	0.3%	0.1%	0.1%	0.0%	3.9%
Non-refrigerated Warehouse	0.0%	0.2%	1.1%	0.6%	0.1%	1.0%	0.5%	1.5%	2.2%	2.1%	0.4%	1.5%	0.6%	0.4%	0.3%	0.1%	12.8%
Hotel	0.0%	0.1%	0.5%	0.2%	0.1%	0.3%	0.4%	0.5%	0.7%	0.4%	0.1%	0.4%	0.1%	0.1%	0.1%	0.0%	3.9%
Assembly	0.0%	0.2%	0.7%	0.3%	0.1%	0.5%	0.3%	0.8%	1.1%	0.8%	0.2%	0.6%	0.3%	0.2%	0.1%	0.1%	6.2%
Hospital	0.0%	0.1%	0.5%	0.3%	0.1%	0.3%	0.3%	0.5%	0.8%	0.4%	0.1%	0.6%	0.3%	0.1%	0.1%	0.0%	4.5%
Laboratory	0.0%	0.0%	0.5%	0.4%	0.0%	0.1%	0.2%	0.2%	0.2%	0.2%	0.0%	0.2%	0.1%	0.0%	0.0%	0.0%	2.0%
Restaurant	0.0%	0.0%	0.2%	0.1%	0.0%	0.2%	0.1%	0.3%	0.4%	0.4%	0.0%	0.2%	0.1%	0.1%	0.0%	0.0%	2.1%
Enclosed Parking Garage	0.0%	0.0%	0.5%	0.3%	0.0%	0.3%	0.3%	0.7%	0.8%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	3.0%
Open Parking Garage	0.0%	0.1%	0.6%	0.5%	0.0%	0.5%	0.4%	1.0%	1.2%	0.4%	0.1%	0.5%	0.1%	0.1%	0.0%	0.1%	5.5%
Grocery	0.0%	0.0%	0.1%	0.0%	0.0%	0.0%	0.0%	0.0%	0.1%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.4%
Refrigerated Warehouse	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.1%	0.1%	0.0%	0.0%	0.0%	0.2%
CEH	0.0%	0.0%	0.0%	0.0%	0.1%	0.1%	0.0%	0.0%	0.0%	0.1%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.4%
Vehicle Service	0.0%	0.1%	0.2%	0.1%	0.0%	0.3%	0.2%	0.4%	0.7%	0.5%	0.1%	0.4%	0.2%	0.1%	0.1%	0.0%	3.4%
Data Center	0.0%	0.0%	0.0%	0.1%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.1%
Manufacturing	0.0%	0.2%	0.5%	0.7%	0.0%	0.7%	0.3%	1.2%	1.7%	0.5%	0.1%	0.5%	0.2%	0.2%	0.0%	0.1%	7.0%
Miscellaneous	0.0%	0.1%	0.1%	0.1%	0.0%	0.1%	0.0%	0.1%	0.2%	0.1%	0.0%	0.2%	0.1%	0.0%	0.0%	0.0%	1.1%
Total	0.4%	2.2%	10.6%	6.3%	1.0%	8.5%	6.1%	12.8%	19.1%	11.1%	2.1%	10.7%	4.1%	2.6%	1.5%	0.9%	100.0%

64%



Comments for Today's Workshop

Due Date: July 17, 2026, by 5:00PM

Comments to be submitted to:

[https://efiling.energy.ca.gov/Ecomment/Ecomment.aspx?
docketnumber=25-BSTD-03](https://efiling.energy.ca.gov/Ecomment/Ecomment.aspx?docketnumber=25-BSTD-03)

Thank you for participating in today's workshop!

Questions?



Broad-to-Detail Building Type mapping

Broad Building Types (EAD/BSD)		Detailed Building Types
Office		Small Office, Medium Office, Large Office
Retail	Here is the order for today's presentations.	Strip Mall, Medium Retail, Large Retail, Grocery
Restaurant	1. Introduction & 2028 Overview	Restaurant
School	2. Overview of Compliance Forums	K-8 School, High School, Large School
	3. Compliance Forum Proposals:	
Hotel	a. Clarification of Automatic Demand Response	Hotel
	b. Alternative to Verification Worksheet	
Hospital	c. Rater Photo Verification	Hospital
	d. Revision to ATTCP Quality Assurance	
Warehouse	e. Sampling and Installation Certificate	Non-refrigerated Warehouse
	4. Updates to ATTCP Program Requirements	
Refrigerated Warehouse	5. Commissioning with Acceptance Test Technician (ATT)	Refrigerated Warehouse, (Non-Refrigerated Warehouse)
Manufacturing Labs and Manufacturing Plants		Manufacturing, Laboratory
Parking Garage		Enclosed Parking, Open Parking
Miscellaneous		Miscellaneous, Assembly, Vehicle Service, CEH, (Small Office), (Medium Office), (Large Office), (High School), (Laboratory), (Non-refrigerated Warehouse).



2028 PV and BESS Update

Muhammad Saeed, PE (CEC) | Eric Shadd, PE (NORESO)



History of PV and BESS Updates

Energy Code	Non-Residential PV+BESS Requirements Buildings Covered	Non-Residential PV+BESS Requirements Sizing Methodology
2019	None	None
2022	Grocery, Office, Financial institutions, unleased tenant space, retail, school, warehouse, Auditorium, Convention Center, Hotel/Motel, Library, Medical Office Building/Clinic, Restaurant, Theater	PV Sized to limit exports to 20% and paired BESS to limit exports to 10% of annual PV production
2025	Above mentioned + Events & Exhibits, Religious Worship, Sports & Recreation	



Purpose of 2028 PV and BESS Update

REVISED PROTOTYPES




CHANGES TO ENERGY ACCOUNTING



CHANGES TO PV AND BATTERY COST



SYSTEM SIZING APPROACH



Standalone PV Sizing





Overview of Comparison of approaches

Proposed (2028) vs. Current (2025)


	2022 & 2025	2028
PV Sizing	Target PV exports to 20% of annual generation	Sized for each season's median load day. Smallest selected.



2028 Proposed Standalone PV Sizing

Size to the *Seasonal Median-Load-Day Minimum*

Median Load Day - Medium Office - Summer - CZ 3



- Median Load Day**
 - Day with median total energy use during daylight hours for the season
- Fit PV**
 - Peak PV output matches building prototype load
 - PV generation is 1 week average.
- PV Size**
 - Select the smallest size of all the seasons

*NOTE: from 4 am to 5 am, loads quadruple, so even though it appears to be a slight bump, it quadruples the LSC at that hour.

Proposed 2028 Size & Comparison to 2025

Standalone PV [W/ft²]



Climate Zone	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Exhibits & Events	1.49	1.23	1.10	1.39	1.25	1.08	1.38	1.19	1.02	1.76	1.36	1.16	1.48	1.27	1.18	1.07
Library	1.77	1.98	1.91	1.97	1.79	1.93	2.16	2.75	2.35	1.92	1.87	2.21	2.18	2.08	2.25	1.96
Religious Worship	0.72	1.01	0.68	0.78	0.73	0.60	0.82	0.95	0.66	1.10	0.91	0.83	0.62	0.71	1.04	0.62
Sports & Recreation	1.23	1.20	1.10	1.44	0.99	1.67	1.39	1.05	1.73	1.42	1.22	1.15	1.52	0.94	1.21	1.41
Large Office	2.96	2.73	2.66	2.74	2.65	2.99	2.67	2.77	2.65	3.09	2.85	2.76	3.31	2.80	2.96	2.33
Medium Office	3.15	2.76	2.87	3.05	2.85	2.74	3.02	3.60	3.29	3.32	3.01	3.11	3.17	2.87	3.93	3.36
Small Office	4.00	3.22	3.38	3.86	3.56	3.38	3.37	3.70	3.36	3.95	3.57	3.61	3.96	3.47	4.05	4.34
Restaurant	4.60	4.74	5.06	5.55	4.24	4.78	5.68	5.48	5.70	5.72	5.23	4.94	5.11	5.62	6.32	5.70
Large Retail	1.79	1.93	2.05	1.94	1.73	2.06	1.91	2.17	2.07	2.24	2.47	2.03	2.40	2.21	2.70	2.11
Medium Retail	2.28	2.09	2.04	1.93	2.08	2.15	2.07	2.42	2.65	2.35	2.55	3.06	2.33	2.30	2.90	2.11
Strip Mall	3.95	3.58	3.35	3.81	3.75	3.90	3.36	3.70	3.99	4.67	3.79	3.72	3.76	4.29	4.02	4.12
High School	0.72	0.50	0.46	0.79	0.52	0.83	0.60	1.02	1.01	1.20	1.43	0.67	1.45	1.72	2.63	0.54
K - 8 School	0.12	0.46	0.50	0.58	0.50	0.42	0.51	1.02	1.17	1.13	1.38	0.57	1.50	1.74	2.33	0.18
Large School	1.59	1.42	1.36	1.40	1.35	1.59	1.27	1.52	1.33	1.62	1.61	1.60	1.39	1.41	2.02	1.15
Warehouse	1.00	0.85	0.79	0.95	0.90	0.82	0.74	1.02	0.89	0.99	0.91	0.96	1.03	0.92	1.04	0.94

Proposed (2028)
Current (2025)

≤ 10%	≤ 30%	≤ 50%	≤ 70%	≤ 90%	>100%<	≥ 110%	≥ 130%	≥ 150%	≥ 170%	≥ 190%	≥ 210%
-------	-------	-------	-------	-------	--------	--------	--------	--------	--------	--------	--------

Proposed 2028 vs. Current 2025: Exports

Standalone PV



Climate Zone	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Exhibits & Events	(20%)	(30%)	(29%)	(27%)	(27%)	(31%)	(26%)	(32%)	(33%)	(23%)	(29%)	(31%)	(26%)	(27%)	(28%)	(26%)
Library	3%	(7%)	(2%)	(4%)	(1%)	(1%)	(2%)	0%	(1%)	(5%)	(6%)	(3%)	(6%)	(3%)	(5%)	(2%)
Religious Worship	(49%)	(44%)	(47%)	(42%)	(47%)	(49%)	(42%)	(46%)	(46%)	(38%)	(39%)	(43%)	(41%)	(36%)	(33%)	(43%)
Sports & Recreation	(20%)	(8%)	(5%)	(4%)	(8%)	2%	(4%)	(11%)	(4%)	(8%)	(11%)	(10%)	(7%)	(9%)	(14%)	(3%)
Large Office	2%	2%	4%	3%	4%	3%	2%	2%	3%	4%	3%	2%	5%	3%	1%	2%
Medium Office	3%	2%	4%	3%	4%	2%	3%	5%	4%	4%	3%	3%	4%	2%	4%	7%
Small Office	7%	4%	6%	6%	6%	4%	4%	5%	5%	7%	5%	4%	6%	5%	4%	11%
Restaurant	(16%)	(18%)	(15%)	(17%)	(16%)	(16%)	(14%)	(16%)	(15%)	(15%)	(18%)	(18%)	(17%)	(14%)	(14%)	(14%)
Large Retail	(10%)	(17%)	(8%)	(10%)	(10%)	(8%)	(9%)	(9%)	(9%)	(9%)	(9%)	(10%)	(9%)	(9%)	(9%)	(8%)
Medium Retail	(6%)	(15%)	(6%)	(10%)	(6%)	(6%)	(7%)	(8%)	(6%)	(8%)	(9%)	(2%)	(9%)	(8%)	(7%)	(7%)
Strip Mall	5%	2%	2%	2%	4%	3%	1%	1%	2%	6%	0%	2%	0%	4%	0%	5%
High School	(9%)	(18%)	(16%)	(10%)	(13%)	(9%)	(15%)	(6%)	(5%)	(2%)	2%	(13%)	2%	5%	5%	(11%)
K - 8 School	(35%)	(18%)	(12%)	(13%)	(12%)	(20%)	(17%)	(5%)	(2%)	(1%)	3%	(12%)	3%	5%	3%	(23%)
Large School	4%	3%	5%	3%	4%	5%	3%	4%	3%	4%	5%	4%	3%	3%	2%	3%
Warehouse	7%	5%	6%	7%	6%	7%	5%	9%	7%	9%	5%	6%	7%	6%	6%	7%

Less Exports

More Exports

➤ Value = 2028 % exports – 2025 % exports

Proposed 2028 vs. Current 2025: Electricity Savings

Standalone PV



Climate Zone	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Exhibits & Events	(51%)	(78%)	(73%)	(74%)	(72%)	(80%)	(70%)	(83%)	(86%)	(69%)	(80%)	(79%)	(73%)	(76%)	(74%)	(62%)
Library	26%	(25%)	(14%)	(26%)	(15%)	(17%)	(17%)	(13%)	(18%)	(34%)	(34%)	(21%)	(28%)	(26%)	(33%)	(18%)
Religious Worship	(82%)	(90%)	(85%)	(90%)	(100%)	(110%)	(99%)	(111%)	(108%)	(96%)	(86%)	(90%)	(91%)	(78%)	(78%)	(72%)
Sports & Recreation	(26%)	(18%)	(12%)	(13%)	(18%)	(4%)	(14%)	(34%)	(16%)	(25%)	(29%)	(23%)	(22%)	(25%)	(41%)	(9%)
Large Office	8%	(7%)	3%	(8%)	3%	(2%)	(9%)	(6%)	(10%)	0%	(5%)	(7%)	5%	(7%)	(15%)	(5%)
Medium Office	9%	(5%)	7%	(0%)	6%	(6%)	(1%)	9%	4%	4%	(1%)	1%	2%	(4%)	3%	15%
Small Office	20%	2%	14%	12%	17%	5%	5%	9%	4%	13%	7%	8%	12%	6%	4%	28%
Restaurant	(22%)	(28%)	(20%)	(25%)	(27%)	(26%)	(21%)	(27%)	(25%)	(27%)	(30%)	(28%)	(30%)	(26%)	(29%)	(18%)
Large Retail	(24%)	(31%)	(20%)	(32%)	(29%)	(26%)	(30%)	(31%)	(31%)	(29%)	(26%)	(29%)	(26%)	(28%)	(29%)	(22%)
Medium Retail	(13%)	(25%)	(18%)	(30%)	(18%)	(21%)	(24%)	(25%)	(18%)	(26%)	(23%)	(9%)	(26%)	(25%)	(25%)	(21%)
Strip Mall	10%	2%	5%	3%	10%	9%	(1%)	(1%)	5%	12%	(3%)	1%	(2%)	8%	(7%)	12%
High School	(13%)	(33%)	(26%)	(26%)	(24%)	(26%)	(32%)	(17%)	(18%)	(12%)	(4%)	(28%)	(4%)	4%	5%	(20%)
K - 8 School	(33%)	(31%)	(23%)	(29%)	(24%)	(38%)	(33%)	(16%)	(12%)	(13%)	(5%)	(28%)	(2%)	4%	(2%)	(31%)
Large School	12%	(7%)	5%	(8%)	5%	(0%)	(12%)	(3%)	(10%)	1%	1%	0%	(7%)	(8%)	(12%)	(4%)
Warehouse	35%	30%	34%	38%	40%	33%	24%	44%	36%	42%	30%	36%	37%	35%	26%	36%

Lower Savings

Higher Savings

➤ Value = 2028 % savings – 2025 % savings

Standalone PV: Proposed 2028 vs Current 2025 Analysis



2028 vs. 2025: 5-day Workweek


Small Office Example




Climate Zone	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
PV Size - Proposed ÷ Current	154%	103%	131%	123%	137%	108%	108%	118%	107%	126%	114%	115%	127%	111%	107%	168%
Electricity Savings	20%	2%	14%	12%	17%	5%	5%	9%	4%	13%	7%	8%	12%	6%	4%	28%
Exports Increase	7%	4%	6%	6%	6%	4%	4%	5%	5%	7%	5%	4%	6%	5%	4%	11%

- 2025: Unoccupied weekends → Smaller PV (less than typical load)
- 2028: **Larger PV** → More Savings, Higher Exports

Current (2025) - Week of March 15



Proposed (2028) - Week of March 15



■ Building Load ■ PV → Load ■ PV → Exports

2028 vs. 2025: 7-day workweek


Medium Retail Example




Climate Zone	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
PV Size - Proposed ÷ Current	73%	60%	68%	53%	68%	66%	60%	63%	73%	62%	62%	84%	58%	62%	63%	66%
Electricity Savings	(13%)	(25%)	(18%)	(30%)	(18%)	(21%)	(24%)	(25%)	(18%)	(26%)	(23%)	(9%)	(26%)	(25%)	(25%)	(21%)
Exports Increase	(6%)	(15%)	(6%)	(10%)	(6%)	(6%)	(7%)	(8%)	(6%)	(8%)	(9%)	(2%)	(9%)	(8%)	(7%)	(7%)

- 2025: Daily consistent loads → Larger PV (higher than typical load)
- 2028: **Smaller PV** (min of seasons) → Lower Savings, Less Exports

Current (2025) - Week of March 15



Proposed (2028)- Week of March 15





2028 vs. 2025: Strip Mall vs Other Retail

Strip mall is mostly retail sales area

Climate Zone	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Large Retail	1.79	1.93	2.05	1.94	1.73	2.06	1.91	2.17	2.07	2.24	2.47	2.03	2.40	2.21	2.70	2.11
Medium Retail	2.28	2.09	2.04	1.93	2.08	2.15	2.07	2.42	2.65	2.35	2.55	3.06	2.33	2.30	2.90	2.11
Strip Mall	3.95	3.58	3.35	3.81	3.75	3.90	3.36	3.70	3.99	4.67	3.79	3.72	3.76	4.29	4.02	4.12

- Strip Mall prototype is assumed to have less support spaces than other retail prototypes
- Retail sales has high load
- With higher load, the PV size increases for that prototype compared to other retail

Space Type	Large Retail	Medium Retail	Strip Mall	LPD [W/sf]	EPD [W/sf]
Retail Sales Area (Retail Merchandise Sales)	68%	83%	100%	0.95	1
Office Area (>250 square feet)	1%	-	-	0.6	1.5
Storage, Commercial/Industrial (Warehouse)	19%	17%	-	0.4	0.2
Lobby, Main Entry	8%	1%	-	0.7	0.5
Restrooms	3%	-	-	0.65	0

2028 vs. 2025: School Prototype Changes


Example: New K – 8 vs Previous Small School




Climate Zone	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
High School	0.72	0.50	0.46	0.79	0.52	0.83	0.60	1.02	1.01	1.20	1.43	0.67	1.45	1.72	2.63	0.54
K - 8 School	0.12	0.46	0.50	0.58	0.50	0.42	0.51	1.02	1.17	1.13	1.38	0.57	1.50	1.74	2.33	0.18

- New summer break low loads → Generally lower than current requirement
- More exterior walls → Warmer climate zones high AC load

Small School – Current (2025) - Week of July 12



K – 8 School – Proposed (2028) - Week of July 12



PV Cost-effectiveness






PV System Life-cycle Costs

Standalone (No BESS)

Standalone PV Life-cycle Costs



- Removed ITC tax credit
- Revised PV forecast accounts for 2025 SEIA price updates
- Apply assumptions for customer acquisition cost, inverter pricing from previous study
- Prices set in 2029 dollars
- Apply NREL conservative¹ forecast through 2029
- Curve has high “tail” of prices for small systems < 50 kW

¹ NREL’s “Conservative” solar photovoltaic (PV) cost projection model assumed technology improves incrementally, but no massive transformative breakthroughs or regulatory leaps take hold.



BCR: Standalone PV

Cost-effective everywhere

Climate Zone	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Exhibits & Events	1.24	1.52	1.57	1.64	1.62	1.68	1.61	1.63	1.70	1.62	1.52	1.57	1.56	1.79	1.74	1.62
Library	1.50	1.80	1.86	1.96	1.93	1.97	1.91	1.88	1.98	1.95	1.77	1.85	1.83	2.10	2.03	1.91
Religious Worship	1.21	1.44	1.48	1.59	1.54	1.55	1.53	1.56	1.59	1.61	1.46	1.51	1.45	1.68	1.68	1.52
Sports & Recreation	1.18	1.38	1.42	1.51	1.45	1.47	1.46	1.45	1.52	1.51	1.39	1.43	1.42	1.60	1.56	1.50
Large Office	2.24	2.70	2.76	2.93	2.89	2.94	2.86	2.88	2.98	2.95	2.70	2.78	2.76	3.10	3.10	2.79
Medium Office	1.66	2.01	2.04	2.18	2.13	2.17	2.13	2.15	2.23	2.21	2.02	2.07	2.07	2.33	2.33	2.08
Small Office	1.21	1.49	1.53	1.61	1.58	1.61	1.57	1.59	1.64	1.63	1.49	1.53	1.53	1.73	1.73	1.51
Restaurant	1.40	1.68	1.75	1.85	1.80	1.86	1.79	1.80	1.89	1.85	1.68	1.73	1.71	1.98	1.93	1.78
Large Retail	2.35	2.79	2.91	3.07	3.00	3.11	2.98	3.01	3.14	3.10	2.84	2.90	2.90	3.33	3.25	3.00
Medium Retail	1.74	2.03	2.13	2.22	2.22	2.27	2.18	2.19	2.28	2.25	2.06	2.08	2.10	2.42	2.35	2.18
Strip Mall	1.58	1.89	1.96	2.07	2.04	2.09	2.01	2.03	2.13	2.04	1.91	1.96	1.95	2.23	2.12	2.02
High School	1.82	2.04	2.09	2.22	2.19	2.16	2.13	2.17	2.27	2.27	2.11	2.14	2.18	2.44	2.53	2.26
K - 8 School	1.28	1.64	1.66	1.80	1.71	1.76	1.71	1.76	1.82	1.84	1.73	1.70	1.78	2.00	2.10	1.67
Large School	1.77	2.14	2.18	2.33	2.27	2.31	2.23	2.29	2.35	2.36	2.18	2.22	2.23	2.50	2.54	2.21
Warehouse	1.43	1.69	1.71	1.84	1.80	1.78	1.74	1.74	1.82	1.79	1.70	1.74	1.76	1.98	1.95	1.80

BCR <

1.00

< BCR

Battery Energy Storage System (BESS) Sizing





Overview of Comparison of Approaches

Proposed (2028) vs. Current (2025)


	2022 & 2025	2028
Sizing	Limit PV exports to 10% of annual generation	Reduce peak LSC hours for each season's median load day. Smallest selected.
Round-trip efficiency	80%	89%
Discharge Power	Total capacity / 4	Total capacity / 4
Discharge control	Peak Time-of-Use (4 pm – 9 pm)	At peak LSC hours of each season's typical load day
Charge control	Surplus PV	Fraction of PV generation to fully charge BESS for each season's median load day



2028 Proposed PV Sizing **Review**

Size to the *Seasonal Median-Load-Day Minimum*

Median Load Day - Medium Office - Summer - CZ 3



Median Load Day

- Day with median total energy use for the season

Fit PV



- Peak PV output matches building load
- PV generation is 1 week average.



2028 Proposed PV with BESS Sizing

Size to the *Seasonal Median-Load-Day Minimum*

Median Load Day - Medium Office - Summer - CZ 3



Proposed PV Sizes

PV with BESS [W/ft²]



Climate Zone	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Exhibits & Events	2.09	1.39	1.31	1.56	1.50	1.18	1.58	1.36	1.25	1.88	1.47	1.38	1.60	1.45	1.43	1.24
Library	1.82	2.52	2.43	2.48	2.34	2.35	2.54	3.25	3.07	2.59	2.82	2.96	2.89	2.42	2.94	2.17
Religious Worship	1.50	2.30	1.64	1.85	1.55	1.53	1.92	2.03	1.99	2.07	2.66	2.87	2.13	1.64	2.29	1.37
Sports & Recreation	1.80	1.89	1.63	2.32	1.63	1.75	2.22	1.86	2.30	2.02	2.06	1.79	1.88	1.64	2.09	1.97
Large Office	3.51	3.19	3.05	3.18	2.95	3.31	3.16	3.20	3.05	3.48	3.31	3.28	3.92	3.28	3.31	2.68
Medium Office	3.69	3.18	3.12	3.64	3.36	3.14	3.41	4.17	3.68	3.90	3.47	3.49	3.51	3.23	4.24	3.99
Small Office	4.80	3.70	3.72	4.50	4.24	3.98	3.87	4.28	3.85	4.44	4.17	4.20	4.47	3.99	4.77	4.93
Restaurant	5.72	5.80	6.15	6.71	5.31	6.00	7.19	6.78	6.75	6.92	6.24	5.93	6.33	7.00	8.07	7.57
Large Retail	2.37	2.51	2.58	2.39	2.33	2.50	2.47	2.75	2.63	2.82	3.14	2.61	3.06	2.73	3.38	2.77
Medium Retail	2.85	2.62	2.69	2.57	2.82	2.83	2.70	3.00	3.21	2.93	3.43	3.91	2.92	2.91	3.86	2.77
Strip Mall	4.68	4.35	4.34	4.87	4.71	4.70	4.04	4.67	5.11	5.56	4.62	4.58	4.75	5.21	5.11	5.27
High School	0.85	0.61	0.58	0.86	0.65	0.83	0.76	1.08	1.09	1.39	1.57	0.84	1.62	1.85	3.05	0.59
K - 8 School	0.22	0.49	0.50	0.67	0.56	0.44	0.52	1.06	1.22	1.48	1.56	0.73	1.80	1.85	2.85	0.23
Large School	1.92	1.78	1.68	1.68	1.62	1.92	1.54	1.82	1.60	1.90	1.88	1.89	1.65	1.70	2.30	1.37
Warehouse	1.26	1.01	0.95	1.22	1.14	0.99	0.96	1.28	1.12	1.21	1.15	1.18	1.34	1.17	1.23	1.10

Proposed (2028)	≤ 10%	≤ 30%	≤ 50%	≤ 70%	≤ 90%	>100%<	≥ 110%	≥ 130%	≥ 150%	≥ 170%	≥ 190%	≥ 210%
Current (2025)												

➤ Slightly larger than Standalone PV to charge the BESS

Proposed 2028 Size & Comparison to 2025

BESS [Wh/ft²]



Climate Zone	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Exhibits & Events	1.44	1.53	1.52	0.90	1.53	0.99	1.39	1.14	1.57	1.38	1.84	1.71	1.60	1.58	1.64	1.43
Library	0.47	1.99	2.28	2.45	1.94	1.77	1.77	1.71	1.39	2.67	3.26	2.38	2.61	2.19	2.90	1.17
Religious Worship	3.95	4.81	4.39	5.11	3.84	4.33	4.50	4.34	4.95	4.44	5.60	4.29	4.64	4.97	4.84	3.73
Sports & Recreation	2.84	3.42	2.87	3.52	3.39	2.55	3.46	3.18	3.14	2.90	3.46	3.33	2.85	3.23	3.24	3.21
Large Office	2.11	2.02	1.89	1.98	1.65	1.68	2.13	1.90	1.93	1.77	1.75	2.33	2.11	2.18	1.87	1.81
Medium Office	2.31	1.93	1.54	2.87	2.30	1.96	1.87	2.17	1.84	1.87	2.06	1.76	1.72	1.87	1.34	2.84
Small Office	2.54	2.47	2.05	3.04	3.22	3.12	2.68	2.96	2.33	2.48	2.91	2.86	2.36	2.82	2.51	2.88
Restaurant	5.73	6.31	5.76	5.17	6.33	6.15	6.62	5.96	5.98	5.65	5.30	5.30	6.18	6.57	6.93	11.06
Large Retail	2.83	2.82	2.77	2.45	2.78	2.13	2.93	3.11	2.86	3.02	3.02	2.94	2.92	2.92	3.14	3.04
Medium Retail	2.85	2.67	3.26	3.44	3.40	3.42	3.32	3.09	3.04	3.16	3.92	4.90	2.74	2.94	4.10	3.63
Strip Mall	3.21	3.94	5.29	5.08	4.91	3.46	3.63	4.66	4.62	3.72	3.99	5.01	4.99	4.66	4.86	6.50
High School	0.62	0.49	0.50	0.50	0.59	0.34	0.66	0.46	0.63	1.76	1.59	0.86	1.78	1.15	2.02	0.26
K - 8 School	0.46	0.30	0.21	0.45	0.38	0.18	0.28	0.43	0.60	2.06	1.81	0.93	2.36	1.12	2.20	0.30
Large School	1.33	1.46	1.46	1.31	1.30	1.44	1.48	1.53	1.40	1.26	1.15	1.30	1.33	1.49	1.40	1.22
Warehouse	1.10	0.95	0.89	1.04	1.18	0.72	1.09	0.66	0.73	0.94	1.12	1.06	1.27	1.20	0.98	1.00

Proposed (2028)
Current (2025)

≤ 10%	≤ 30%	≤ 50%	≤ 70%	≤ 90%	>100%<	≥ 110%	≥ 130%	≥ 150%	≥ 170%	≥ 190%	≥ 210%
-------	-------	-------	-------	-------	--------	--------	--------	--------	--------	--------	--------

Proposed 2028 vs. Current 2025: Exports

PV with BESS



Climate Zone	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Exhibits & Events	(14%)	(31%)	(29%)	(27%)	(27%)	(32%)	(27%)	(33%)	(34%)	(25%)	(33%)	(32%)	(29%)	(29%)	(30%)	(27%)
Library	3%	(6%)	(1%)	(5%)	(0%)	(1%)	(2%)	1%	3%	(5%)	(5%)	(0%)	(5%)	(4%)	(5%)	(3%)
Religious Worship	(37%)	(28%)	(30%)	(32%)	(32%)	(36%)	(30%)	(37%)	(33%)	(32%)	(25%)	(20%)	(28%)	(28%)	(28%)	(32%)
Sports & Recreation	(13%)	(4%)	(1%)	2%	(3%)	(2%)	2%	(8%)	(2%)	(6%)	(7%)	(7%)	(7%)	(7%)	(12%)	1%
Large Office	5%	2%	5%	3%	4%	4%	3%	3%	3%	5%	4%	3%	8%	4%	1%	3%
Medium Office	5%	3%	4%	4%	5%	2%	3%	6%	5%	6%	4%	4%	4%	3%	5%	9%
Small Office	10%	4%	6%	7%	8%	5%	4%	5%	5%	7%	5%	5%	7%	5%	6%	14%
Restaurant	(13%)	(17%)	(11%)	(14%)	(15%)	(13%)	(9%)	(14%)	(13%)	(13%)	(17%)	(16%)	(15%)	(11%)	(12%)	(6%)
Large Retail	(7%)	(12%)	(5%)	(10%)	(8%)	(6%)	(8%)	(8%)	(8%)	(8%)	(7%)	(9%)	(7%)	(8%)	(7%)	(4%)
Medium Retail	(2%)	(11%)	(3%)	(9%)	(2%)	(4%)	(5%)	(7%)	(4%)	(7%)	(5%)	3%	(7%)	(6%)	(5%)	(4%)
Strip Mall	9%	6%	6%	6%	9%	7%	2%	2%	6%	9%	2%	3%	2%	7%	3%	11%
High School	(8%)	(16%)	(14%)	(10%)	(11%)	(10%)	(13%)	(6%)	(6%)	(2%)	2%	(12%)	1%	4%	6%	(11%)
K - 8 School	(30%)	(18%)	(14%)	(12%)	(12%)	(20%)	(18%)	(5%)	(2%)	(0%)	2%	(11%)	3%	4%	5%	(21%)
Large School	7%	4%	7%	4%	5%	7%	2%	4%	3%	5%	6%	5%	3%	4%	3%	3%
Warehouse	10%	6%	8%	11%	10%	9%	7%	14%	11%	12%	8%	8%	11%	9%	7%	9%

Less Exports More Exports

➤ Value = 2028 % exports – 2025 % exports

Proposed 2028 vs Current 2025: Electricity Savings

PV with BESS



Climate Zone	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Exhibits & Events	(35%)	(74%)	(67%)	(70%)	(66%)	(77%)	(65%)	(80%)	(81%)	(67%)	(78%)	(74%)	(71%)	(72%)	(70%)	(58%)
Library	27%	(14%)	(3%)	(16%)	(3%)	(8%)	(9%)	(4%)	(4%)	(21%)	(17%)	(6%)	(16%)	(19%)	(23%)	(13%)
Religious Worship	(65%)	(59%)	(57%)	(65%)	(74%)	(83%)	(72%)	(87%)	(78%)	(77%)	(56%)	(46%)	(65%)	(61%)	(64%)	(56%)
Sports & Recreation	(14%)	(2%)	2%	6%	0%	(3%)	5%	(17%)	(4%)	(13%)	(13%)	(9%)	(16%)	(11%)	(28%)	3%
Large Office	18%	2%	12%	2%	10%	5%	2%	2%	(1%)	8%	5%	4%	17%	4%	(9%)	3%
Medium Office	18%	2%	11%	10%	16%	1%	6%	19%	11%	14%	6%	7%	7%	3%	8%	25%
Small Office	30%	9%	19%	22%	28%	14%	12%	17%	12%	20%	15%	16%	19%	14%	13%	37%
Restaurant	(16%)	(22%)	(14%)	(18%)	(20%)	(18%)	(12%)	(20%)	(19%)	(20%)	(25%)	(23%)	(24%)	(17%)	(20%)	(6%)
Large Retail	(14%)	(20%)	(9%)	(23%)	(16%)	(17%)	(20%)	(20%)	(20%)	(19%)	(15%)	(19%)	(16%)	(19%)	(19%)	(9%)
Medium Retail	(4%)	(16%)	(6%)	(19%)	(4%)	(9%)	(13%)	(15%)	(8%)	(16%)	(10%)	5%	(17%)	(14%)	(11%)	(9%)
Strip Mall	18%	11%	18%	17%	23%	20%	8%	10%	19%	23%	6%	11%	8%	19%	6%	27%
High School	(10%)	(30%)	(22%)	(24%)	(20%)	(26%)	(27%)	(16%)	(16%)	(7%)	(1%)	(23%)	0%	7%	13%	(19%)
K - 8 School	(30%)	(30%)	(23%)	(27%)	(22%)	(38%)	(33%)	(15%)	(11%)	(4%)	(1%)	(24%)	5%	6%	8%	(30%)
Large School	23%	7%	18%	3%	16%	13%	(3%)	8%	(0%)	11%	9%	11%	2%	4%	(4%)	5%
Warehouse	49%	41%	46%	57%	58%	47%	40%	62%	53%	59%	45%	50%	56%	52%	36%	45%

Lower Savings

Higher Savings

➤ Value = 2028 % savings – 2025 % savings

PV with BESS: Proposed 2028 vs Current 2025 Analysis



2028 vs. 2025: 5-day Workweek


Small Office Example




Climate Zone	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
BESS Size - Proposed ÷ Current	New	42%	42%	51%	66%	53%	45%	50%	39%	42%	49%	48%	40%	48%	35%	59%
Electricity Savings	30%	9%	19%	22%	28%	14%	12%	17%	12%	20%	15%	16%	19%	14%	13%	37%
Exports Increase	10%	4%	6%	7%	8%	5%	4%	5%	5%	7%	5%	5%	7%	5%	6%	14%

- 2025: Unoccupied weekends → Large BESS (must absorb full ½ day of exports)
- 2028: Low evening loads, no export limit → **Smaller BESS**

Current (2025) - Week of March 15



Proposed (2028) - Week of March 15



Building Load
 PV → Load
 PV → BESS
 BESS → Load
 PV → Exports
 BESS State of Charge

2028 vs. 2025: 7-day Workweek


Medium Retail Example




Climate Zone	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
BESS Size - Proposed ÷ Current	134%	131%	170%	169%	176%	169%	168%	143%	138%	138%	157%	224%	113%	115%	137%	169%
Electricity Savings	(4%)	(16%)	(6%)	(19%)	(4%)	(9%)	(13%)	(15%)	(8%)	(16%)	(10%)	5%	(17%)	(14%)	(11%)	(9%)
Exports Increase	(2%)	(11%)	(3%)	(9%)	(2%)	(4%)	(5%)	(7%)	(4%)	(7%)	(5%)	3%	(7%)	(6%)	(5%)	(4%)

- 2025: Constant load → Small BESS (only trims peak PV generation)
- 2028: Before- & after-hours shopping, dining, exercise, worship, etc. → **Larger BESS**

Current (2025) - Week of March 15



Proposed (2028) - Week of March 15



2028 vs. 2025: Warehouse

6-day week, early start




Climate Zone	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
BESS Size - Proposed ÷ Current	New	207%	212%	226%	281%	157%	237%	143%	159%	204%	244%	230%	276%	261%	161%	238%
Electricity Savings	49%	41%	46%	57%	58%	47%	40%	62%	53%	59%	45%	50%	56%	52%	36%	45%
Exports Increase	10%	6%	8%	11%	10%	9%	7%	14%	11%	12%	8%	8%	11%	9%	7%	9%


➤ 2025: Warehouse already had low PV exports → Small BESS

➤ 2028: Early weekday morning loads → Larger BESS

Current (2025) - Week of March 15



Proposed (2028) - Week of March 15



Building Load
 PV → Load
 PV → BESS
 BESS → Load
 PV → Exports
 BESS State of Charge

PV with BESS Cost-effectiveness





Comparison of Cost-effectiveness Parameters

Peak Time-of-Use vs. Peak LSC by Season

Parameter	2025	2028
Sizing constraint	Limit surplus PV to 10% exports	Reduce peak LSC of for each season's median load day
Round-trip efficiency	80%	89%
Discharge Power	Total capacity / 4	Total capacity / 4
Minimum State of Charge	20% of Total Capacity	20% of Total Capacity
Maximum State of Charge	80% of Total Capacity	80% of Total Capacity
Discharge control	Peak Time-of-Use (4 pm – 9 pm)	Reduce peak LSC for each season's typical load day, excluding hours where PV was 40% of load.
Charge control	Surplus PV	PV fraction for each season's median load day.

- Increased round-trip efficiency in 2028
- **Conservatively predictive BESS control**
 - Reduces peak LSC instead of TOU
 - PV charge fraction & BESS discharge hour change seasonally, based on that season's typical load day


PV System Life-cycle Costs

BESS-Coupled

- Installing PV and storage together reduces hardware, labor, and permitting and interconnection costs
- Reduces PV system costs by 15%



Standalone PV vs. BESS-Coupled PV Life-cycle Costs



References:



Cole, W. & Frazier, A. W. (2020). Cost Projections for Utility-Scale Battery Storage: 2020 Update. NREL.

SEIA 2026. Solar Market Insight Report, March 2026



BESS System Life-cycle Costs

- Projected BESS costs are reduced due to current prices
- Costs based on NREL and market studies



> 100 kWh:

NREL, Annual Technology Baseline, 2024

< 100 kWh:

Enphase Energy, enphase.com

SolarTech, solartechonline.com



BCR: PV with BESS

Has a BCR > 1.00 for nearly all cases

Climate Zone	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Exhibits & Events	1.20	1.41	1.47	1.65	1.56	1.60	1.55	1.59	1.59	1.64	1.39	1.45	1.50	1.64	1.61	1.51
Library	1.61	1.75	1.75	1.85	1.91	1.91	1.88	1.91	2.04	1.80	1.64	1.80	1.75	1.97	1.91	1.94
Religious Worship	0.91	1.09	1.05	1.18	1.13	1.11	1.14	1.22	1.28	1.36	1.20	1.24	1.16	1.23	1.38	1.15
Sports & Recreation	1.02	1.22	1.22	1.29	1.25	1.33	1.24	1.26	1.34	1.33	1.22	1.20	1.25	1.31	1.38	1.35
Large Office	2.29	2.80	2.83	3.00	3.01	3.05	2.92	2.97	3.13	3.10	2.81	2.82	2.84	3.14	3.24	2.87
Medium Office	1.70	2.07	2.13	2.18	2.21	2.21	2.20	2.21	2.33	2.30	2.06	2.15	2.15	2.37	2.48	2.09
Small Office	1.23	1.49	1.56	1.61	1.56	1.57	1.57	1.60	1.67	1.66	1.50	1.55	1.58	1.69	1.76	1.51
Restaurant	1.31	1.59	1.65	1.76	1.68	1.75	1.67	1.75	1.81	1.78	1.62	1.68	1.64	1.89	1.86	1.56
Large Retail	2.18	2.59	2.72	2.95	2.87	3.00	2.74	2.84	3.02	2.95	2.75	2.77	2.79	3.13	3.17	2.84
Medium Retail	1.60	1.88	1.93	2.03	2.08	2.06	1.96	2.03	2.15	2.08	1.89	1.82	2.01	2.22	2.21	2.01
Strip Mall	1.51	1.78	1.73	1.91	1.86	1.98	1.88	1.95	2.07	1.99	1.81	1.82	1.81	2.07	2.00	1.82
High School	1.84	2.02	2.04	2.30	2.14	2.29	2.07	2.30	2.37	2.15	2.03	2.06	2.14	2.52	2.61	2.40
K - 8 School	1.08	1.66	1.73	1.80	1.71	1.83	1.74	1.85	1.91	1.69	1.64	1.57	1.70	2.04	2.10	1.52
Large School	1.80	2.14	2.17	2.35	2.31	2.30	2.24	2.35	2.39	2.43	2.25	2.25	2.25	2.44	2.60	2.25
Warehouse	1.37	1.62	1.62	1.73	1.67	1.72	1.59	1.71	1.77	1.71	1.61	1.65	1.63	1.83	1.87	1.71

BCR <

1.00

< BCR

Input Requests





Input Request

Market

- For commercial PV system and commercial BESS costs, what are the customer acquisition costs?
- What is the expected useful life of a commercial BESS system, under typical charging and discharge cycles?
- What is the minimum capacity commercial BESS that is available and practical for commercial buildings?



Input Request

Performance

- How are commercial PV systems sized?
- What is a typical minimum and maximum state of charge for BESS installed in commercial buildings?
- What is a typical roundtrip efficiency for BESS installed in commercial buildings?
- What are typical BESS charging and discharging control strategies (TOU, energy arbitrage, peak shaving, traditional predictive, AI predictive, etc.).
 - If possible, please provide a ranking of the stage of adoption of these technologies: 1 (innovators), 2 (early adopters), 3 (early majority), 4 (late majority), 5 (laggards).



Thanks for listening!

Muhammad Saeed (CEC) | Eric Shadd (NORESO)



Comments for Today's Workshop

Due Date: June 17, 2026, by 5:00PM

Comments to be submitted to:

[https://efiling.energy.ca.gov/Ecomment/Ecomment.aspx?
docketnumber=25-BSTD-03](https://efiling.energy.ca.gov/Ecomment/Ecomment.aspx?docketnumber=25-BSTD-03)

Thank you for participating in today's workshop!

Questions?



Existing Building Performance: HVAC Upgrades and Commissioning

June 23, 2026

Hab Tewelde, P.E. (CEC)

W. Michael Goodrum, P.E. (NORESCO)



Agenda

- Background
- Proposed Measures
- Existing Code Requirements
- Proposed Code Changes
- Market
- Cost-effectiveness
- Statewide Impact
- Stakeholder Input



Terms & Abbreviations

Pneumatic Control Uses compressed air pressure to operate HVAC valves and dampers

Direct Digital Control (DDC) Uses digital controllers and programmed logic to monitor and control HVAC equipment

Existing Building Commissioning (EBCx)
Evaluates, improves, verifies, and documents existing HVAC system operation with recommendations for ongoing improvement

Chilled Water (CHW) Plant consists of one or more chillers to provide cooling for air handling systems

Condenser Water (CW) serves the chilled water plant to reject heat from the chilled water loop, typically through a cooling tower

Heating Hot Water (HHW) Plant -consists of one or more boilers to provide heating for air handling systems

Air Handling Unit (AHU) conditions and distributes air

Packaged Rooftop Unit (RTU) provides heating, cooling, and air distribution


Fan Coil Unit (FCU) typically connected to chilled water and hot water plants; provides heating, cooling, and air distribution

Variable Air Volume (VAV) box controls flow, and may adjust temperature, air distributed from AHU to zones



Why Existing Buildings?


California Energy Use by Sector



Source: California Electricity and Natural Gas Consumption Dashboards

~24 % of California energy use from
nonresidential buildings

California Commercial Building Energy Use by Vintage



SOURCE: ComStock

~80 % nonresidential energy use
from buildings constructed prior to 2000

Proposing two requirements to enhance energy performance of existing buildings



DDC Upgrades

- Enables energy saving sequences not available for vintage pneumatic controls (or when no HVAC controls in place)
- Creates a stronger foundation for right-sizing, controls modernization, and future building performance work
- Positive statewide first year energy savings

Existing Building Commissioning

- Captures quick wins for energy efficiency
- Investigates key aspects for future HVAC electrification
- Provides foundation for more efficient future HVAC replacements
- Low to moderate cost to perform
- Positive statewide first year energy savings



DDC Upgrades

Existing Code Requirements

- Requirements for nonresidential and hotel/motel buildings covered in **Section 100.3**
- **Section 401.2.2.10:** Direct Digital Controls (DDC)
 - Specific requirements for DDC capability
- DDC to the zone per **Table 401.2-D**
 - Additions/Alterations specifically addressed
- **Section 401.2.2.12:** HVAC hot water temperature
 - Design for HHW supply temp $\leq 130^{\circ}\text{F}$

Summary of Additions/Alterations Requirements in Table 401.2-D

Zone terminal units (VAV boxes)	Existing zones served by same AHU, CHW, or HHW systems with DDC
AHU or FCU	Existing AHU/FCU served by same CHW, or HHW systems with DDC
New AHU + zones	Capacity ≥ 300 kBtu/h Zones > 3 New zones $> 75\%$ of all zones
CHW Plant	Capacity ≥ 300 kBtu/h All chillers new/upgraded
HHW Plant	Capacity ≥ 300 kBtu/h All boilers new/upgraded



DDC Upgrades

Proposed Changes Summary

2028 proposed changes for nonresidential buildings

1 Terminal Units (example = VAV boxes)

- Expand DDC at zone level
- Extend to AHU when majority of zones are DDC

2 Airside System (example = Air Handling Unit)


- Include DDC for any medium - large AHU/RTU replacements
- Clarify DDC for any size AHU / RTU served by chiller/boiler plant with DDC
- Extend DDC to all zones in AHU when already in most zones

3 Central Plants (chillers or boilers)

- Extend DDC to full plant when majority is replaced

Additional Exceptions

- Building types
- Climate zones for specific equipment



Source: BuildUp MN



DDC Upgrades

Proposed Code Changes shown in underlined text

Summary of Additions/Alterations Requirements in Table 401.2-D

- Requirements for nonresidential buildings covered in **Section 100.3**
 - **Exceptions:** Healthcare, Hotel/Motel
- DDC to the zone per **Table 401.2-D**
 - Additions/Alterations modified
 - **Exceptions:** Chiller plant upgrades CZ 1, 3, 5, 16
 - **Exceptions:** Boiler plant upgrades CZ 6, 7
- **Section 401.2.2.12:** HVAC hot water temperature
 - Design for HHW supply temp $\leq 130^{\circ}\text{F}$
 - New/replacement terminal units designed for existing HHW supply temp, capable of operating at HHW supply temp $< 130^{\circ}\text{F}$

Zone terminal units (VAV boxes)	<u>Any new/replaced terminal unit</u> <u>If > 50% of terminal units served by AHU are DDC, provide DDC at AHU</u>
AHU or FCU	<u>Capacity > 150 kBtu/h</u> <u>Any capacity existing AHU/FCU served by same CHW, or HHW systems with DDC</u>
New AHU + zones	<u>Capacity ≥ 150 kBtu/h</u> <u>Zones > 3</u> <u>New zones > 75% of all zones</u> <u>When > 85% of zones are new, DDC to all zones</u>
CHW Plant	<u>Capacity ≥ 300 kBtu/h</u> <u>When > 50% of capacity new, DDC for entire plant, including pumps</u>
HHW Plant	<u>Capacity ≥ 300 kBtu/h</u> <u>When > 50% of capacity new, DDC for entire plant, including pumps</u>



Commissioning for Existing Buildings

Existing Code Requirements

- Commissioning requirements incorporated for equipment additions/alterations
 - Section 1001.2.6: Functional performance testing
 - Section 401.2.7: Mechanical system acceptance
- No current requirements specific to existing buildings
 - Section 1001.5: Additions and alterations to existing buildings
 - RESERVED


Commissioning for Existing Buildings

Proposed Changes Summary

- Performed upon new/replacement space-conditioning equipment
- Process based on ASHRAE Standard 230
- General requirements included for all space-conditioning equipment
- Specific requirements included by space-conditioning equipment type

The goals of EBCx for buildings:

- Document what exists
- Correct obvious operating issues
- Identify next step improvements
- Collect information for future equipment decisions



ASHRAE Standard 230



Commissioning for Existing Buildings

Proposed Code Changes shown in underlined text – General Requirements

- **Section 401.3.4.1 Heating and cooling loads**
 - When sizing new/replacement space-conditioning equipment for nonres alteration, existing HVAC energy use/trend data used in load calculations and submitted to AHJ
 - **Exceptions:** Healthcare, Hotel/Motel
- **Section 401.5.2.2.1.3 & 401.5.2.2.2.3 Existing Building Commissioning**
 - Requires EBCx performed according to Section 1001.5.2.1.1
 - **Exceptions:** Healthcare, Hotel/Motel
- **Section 1001.5.2 Alterations**
 - Alterations to components of existing nonresidential comply
 - **Exceptions:** Healthcare, Hotel/Motel
 - EBCx in accordance with ASHRAE Standard 230
 - EBCx results documented in EBCx report, delivered to owner/rep prior to final inspection
 - Expected remaining useful life and replacement schedule for chillers, boilers, AHUs > 150 kBtu/h, packaged RTUs
 - Benefits of installing devices for pneumatic to DDC interface
 - Compatibility/capability for ASHRAE Guideline 36 sequences (2025 JA18)
 - List of identified issues and corrective actions taken

Commissioning for Existing Buildings

Proposed Code Changes shown in underlined text – Equipment Specific Requirements



Summary of Equipment Specific Requirements in Table 1001.5-A

Equipment	EBCx Evaluation	EBCx Strategies
<u>Zone terminal units (VAV boxes) served by same AHU</u>	<u>Zone heating/cooling overlap between central and perimeter systems, implement deadband</u>	<u>Occupancy based schedules</u> <u>Occupancy based temp setpoint resets</u>
<u>AHU/RTU or FCU > 150 kBtu/h</u>	<u>Outdoor air ventilation per 401.2.1.2</u> <u>Visually inspect outdoor air/economizer dampers and linkages for restrictions</u>	<u>Occupancy based schedules</u> <u>Occupancy based temp setpoint resets</u> <u>Supply air temp reset</u> <u>Static pressure reset</u>
<u>CHW Plant > 300 kBtu/h</u>	<i>For all AHU/RTUs or FCUs served by plant:</i> <u>Outdoor air ventilation per 401.2.1.2</u> <u>Visually inspect outdoor air/economizer dampers and linkages for restrictions</u>	<u>CHW supply temp reset</u> <u>CW temp reset</u> <u>Pump differential pressure reset</u>
<u>HHW Plant > 300 kBtu/h</u>	<u>Capability of plant to meet zone heating loads at HHW supply temp down to 130°F</u> <i>For all AHU/RTUs or FCUs served by plant:</i> <u>Outdoor air ventilation per 401.2.1.2</u> <u>Visually inspect outdoor air/economizer dampers and linkages for restrictions</u>	<u>HHW supply temp reset</u> <u>Pump differential pressure reset</u>



Existing Building Market



~45 % of nonresidential
buildings candidates for DDC

2022 Commercial End Use Survey



50 % of office floor area
covered by audit/RCx ordinances

Market Readiness

DDC Widely Available: Capability to be implemented for individual equipment, systems, or for entire building

Strong Network: Existing HVAC controls suppliers, designers and contractors, commissioning consultants

Active Commissioning: Commissioning consultants serving existing energy code requirements

Adjacent Regulation: Existing ordinances in six local jurisdictions require regular energy audits and RCx



Cost-Effectiveness Summary

DDC Upgrades – Airside Systems

- 10% Reduction in HVAC system energy based on previous CASE reports
- Office Building prototype as representative
- Installation costs from RS Means and other industry sources
- Incremental maintenance costs based on typical maintenance contract

Measures	30-Year LSC Savings		
	Total Energy (PV\$/ft ²)	Cost (\$/ft ²)	BCR
DDC – AHUs + VAV	\$1.07	\$0.41	BCR > 1 in all CZ



Cost-Effectiveness Summary

DDC Upgrades – Chilled Water and Hot Water Plants

- Modest Estimate for cooling/heating energy savings potential
 - 15% reduction for control upgrades with some existing strategies
- Installation costs from RS Means and other industry sources
- Incremental maintenance costs based on typical maintenance contract

Measures	30-Year LSC Savings		
	Total Energy	Cost	BCR
	(PV\$/ft ²)	(\$/ft ²)	
DDC – Chiller	\$0.60	\$0.256	BCR > 1 in all but CZ 1, 3, 5, 16
DDC - Boiler	\$0.69	\$0.295	BCR > 1 in all but CZ 6, 7

No requirements in climate zones where BCR < 1

Cost-Effectiveness Summary

EBCx



Meta-Study of EBCx across nearly 1,300 buildings basis for savings and cost estimates (Crowe 2020)

- 6% Reduction in HVAC system energy
- Office Building prototype as representative
- Installation costs from meta-study
- No incremental maintenance costs included
 - Did not include possible maintenance savings either

Measures	30-Year LSC Savings		
	Total Energy (PV\$/ft ²)	Cost (\$/ft ²)	BCR
EBCx	\$0.64	\$0.366	BCR > 1 in all CZ



Statewide First Year Savings

Measures	Electricity LSC Savings (\$PV)	Natural Gas LSC Savings (\$PV)	GHG Emissions Savings (MT CO ₂ e/year)
DDC – AHUs + VAV	\$7,553,646	\$3,167,958	33,590
DDC – Chillers	\$1,062,524	\$0	1,587
DDC – Boilers	\$0	\$257,409	23,055
EBCx	\$4,532,187	\$1,900,775	20,154

No savings included for climate zones where BCR < 1



Requested Stakeholder Input

OPEN QUESTIONS FOR THE 2028 RULEMAKING PROCESS – DDC Upgrades

Q1 Pneumatic Control Market Presence

What percentage of buildings with HVAC controls rely on pneumatic controls for all, or part, of the system?

Q2 DDC to Zone Level Upgrades

When upgrading terminal units (such as VAV boxes), would it be advantageous to upgrade all terminal units served by the same AHU to DDC or to make DDC upgrades by zones as replacement warrants?

Q3 Trend Data Collection

What percentage of buildings with DDC have enabled trend data collection and storage?

Q4 Trend Data Storage

For those buildings with trend data collection and storage, how many hours'/days' worth of trend data are typically stored?



Requested Stakeholder Input

OPEN QUESTIONS FOR THE 2028 RULEMAKING PROCESS - EBCx

Q1 EBCx Market Presence

What percentage of buildings have already completed EBCx?

Q2 EBCx Improvement/Correction Scope

What operational improvements do you expect a Cx Agent to make during the EBCx study?

Q3 Additional EBCx Testing Requirements

Are there any EBCx-specific testing requirements that should accompany the proposed changes to Section 1001.5 in the Reference Appendices?



Comments for Today's workshop

Due Date: July 17, 2026, by 5:00 PM

Comments to be submitted to:

[https://efiling.energy.ca.gov/Ecomment/Ecomment.aspx?
docketnumber=25-BSTD-03](https://efiling.energy.ca.gov/Ecomment/Ecomment.aspx?docketnumber=25-BSTD-03)

Thank you for participating!

Questions?

Appendix





Cost-Effectiveness Summary – All Climate Zones

DDC Upgrades – Airside Systems

Climate Zone	Benefit: Total Incremental LSC Savings + Other Savings	Cost: Total Incremental First Costs + Maintenance Costs	Benefit Cost Ratio
	(PV\$/ft ²)	(\$/ft ²)	(BCR)
1	\$0.844	\$0.41	2.06
2	\$0.961	\$0.41	2.34
3	\$0.769	\$0.41	1.88
4	\$0.872	\$0.41	2.13
5	\$0.830	\$0.41	2.02
6	\$0.841	\$0.41	2.05
7	\$0.867	\$0.41	2.11
8	\$1.044	\$0.41	2.55
9	\$0.990	\$0.41	2.41
10	\$1.086	\$0.41	2.65
11	\$1.193	\$0.41	2.91
12	\$1.034	\$0.41	2.52
13	\$1.132	\$0.41	2.76
14	\$1.240	\$0.41	3.02
15	\$1.384	\$0.41	3.38
16	\$1.332	\$0.41	3.25



Cost-Effectiveness Summary – All Climate Zones

DDC Upgrades – Chiller Systems

Climate Zone	Benefit: Total Incremental LSC Savings + Other Savings (PV\$/ft ²)	Cost: Total Incremental First Costs + Maintenance Costs (\$/ft ²)	Benefit Cost Ratio (BCR)
1	\$0.032	\$0.256	0.13
2	\$0.315	\$0.256	1.23
3	\$0.198	\$0.256	0.77
4	\$0.377	\$0.256	1.47
5	\$0.244	\$0.256	0.95
6	\$0.501	\$0.256	1.96
7	\$0.524	\$0.256	2.05
8	\$0.690	\$0.256	2.70
9	\$0.657	\$0.256	2.57
10	\$0.728	\$0.256	2.84
11	\$0.659	\$0.256	2.57
12	\$0.493	\$0.256	1.93
13	\$0.703	\$0.256	2.75
14	\$0.644	\$0.256	2.52
15	\$1.231	\$0.256	4.81
16	\$0.199	\$0.256	0.78



Cost-Effectiveness Summary – All Climate Zones

DDC Upgrades – Boiler Systems

Climate Zone	Benefit: Total Incremental LSC Savings + Other Savings	Cost: Total Incremental First Costs + Maintenance Costs	Benefit Cost Ratio
	(PV\$/ft ²)	(\$/ft ²)	(BCR)
1	\$0.78	\$0.295	2.66
2	\$0.65	\$0.295	2.21
3	\$0.50	\$0.295	1.7
4	\$0.46	\$0.295	1.56
5	\$0.54	\$0.295	1.84
6	\$0.28	\$0.295	0.94
7	\$0.25	\$0.295	0.84
8	\$0.31	\$0.295	1.04
9	\$0.34	\$0.295	1.16
10	\$0.37	\$0.295	1.25
11	\$0.66	\$0.295	2.23
12	\$0.60	\$0.295	2.03
13	\$0.52	\$0.295	1.77
14	\$0.68	\$0.295	2.31
15	\$0.29	\$0.295	1.00
16	\$1.32	\$0.295	4.49

Cost-Effectiveness Summary – All Climate Zones

EBCx



Climate Zone	Benefit: Total Incremental LSC Savings + Other Savings	Cost: Total Incremental First Costs + Maintenance Costs	Benefit Cost Ratio
	(PV\$/ft ²)	(\$/ft ²)	(BCR)
1	\$0.506	\$0.366	1.38
2	\$0.577	\$0.366	1.58
3	\$0.461	\$0.366	1.26
4	\$0.523	\$0.366	1.43
5	\$0.498	\$0.366	1.36
6	\$0.505	\$0.366	1.38
7	\$0.520	\$0.366	1.42
8	\$0.626	\$0.366	1.71
9	\$0.594	\$0.366	1.62
10	\$0.652	\$0.366	1.78
11	\$0.716	\$0.366	1.96
12	\$0.620	\$0.366	1.70
13	\$0.679	\$0.366	1.86
14	\$0.744	\$0.366	2.03
15	\$0.830	\$0.366	2.27
16	\$0.799	\$0.366	2.18



Expanding the Heat Pump Alteration Requirement to Large Single-Zone RTUs

Habtom Tewelde, P.E. | CEC

Nasim Mirian, PhD. , John Arent, Rahul Athalye | NORESO



Presentation Roadmap

1

Existing Code Requirements

2025 Energy Code §141.0(b) baseline

2

Proposed Measure & Exceptions

Scope, capacity range, prescriptive and alternate paths

3

Market Characterization

Market Size, Installation practices

4

Code Sections Affected

§141.0(b) / §401.5.2.2, ACM, Reference Appx

5

Energy Savings Methodology

Prototypes, vintages, baseline, modeling

6

First-Year Energy Impacts

Site, source, GHG, therms

7

30-Year Cost Savings (LSC)

Present-value statewide benefit

8

Incremental Cost

Equipment + labor by capacity

9

Cost-Effectiveness

BCR by climate zone and vintage

10

Stakeholder Input Requested

Open questions for the rulemaking

11

Contact & References

Project team and citations



Terms & Abbreviations

SZVAVHP: Single Zone Variable Air Volume Heat Pump

SZVAVDFHP: Single Zone Variable Air Volume Dual Fuel Heat Pump

SZVAVAC: Single Zone Variable Air Volume Air Conditioner with Gas Furnace for Heating

SZVAVAC1(Gas Pathway): Single Zone Variable Air Volume Air Conditioner with Gas Furnace for Heating and Energy efficiency Measures

BCR: Benefit-Cost Ratio

DX: Direct Expansion

ERR: Energy Recovery Ratio

GHG: Greenhouse Gas

kBtu: Thousands of British Thermal Units

LSC: Long-term System Cost (30-year \$)

Ton: nominal rated capacity (1 ton = 12 kBtu/h)



Existing Code Requirements

2025 ENERGY CODE — STARTING POINT

2025 Energy Code §141.0(b)

Single-Zone HP Alteration Requirement (Small Capacity)

Applicability: Single-zone packaged AC alterations with rated capacity $\leq 65,000 \text{ Btu/h}$ (≤ 5.4 tons).

Compliance options:

- Heat pump (default prescriptive path)
- Alternative gas-pack with prescribed efficiency add-ons
- CZ 16 dual-fuel option (gas backup permitted)

Coverage in California stock: Does not address the 65–240 kBtu/h capacity range, which accounts for approximately 40% of cooling capacity sold in 2024.

THE GAP

Large Single-Zone RTUs Are Not Yet Covered

65 — 240 kBtu/h

(5.4 — 20 tons)

$\approx 40\%$ of all cooling capacity installed in 2024 falls within this range— and 78 % of replacements are still gas packs (Sathe 2025).



What Is Being Proposed

EXTEND §141.0(b) TO LARGER CAPACITY — RETAIL & RESTAURANT

1 SCOPE

65,000 – 240,000 Btu/h
(5.4 – 20 tons)
Retail & restaurant

Vintages:

Pre-1978, 1978-1997

2 DEFAULT PATH

Replace gas-pack with
SZVAVHP

3 ALTERNATIVE

Gas pack :
85 % Energy Recovery
Ratio heat recovery
3-stage DX, 2-stage gas
25 % no-load fan

4 EXCEPTIONS

CZ 16: dual-fuel HP
CZ 15: not required

Panel capacity
exception

KEY BENEFITS



GHG Reduction

8,798 MT CO₂e saved per year statewide



LSC Savings

69.7 million dollars statewide reduction



Natural Gas Savings

2.0 million therms reduced annually



Market Ready


Available 65,000 – 240,000 Btu/h units from major
manufacturers



Proposed Code Language — §141.0(b) Extension

ALTERATION TRIGGER • COMPLIANCE PATHS • EXCEPTIONS

Code Trigger — Decision Flow



Proposed Exceptions

EX 1 CZ 16 — Dual-Fuel HP

Heat pump with gas backup permitted (SZVAVDFHP rating). Severe heating loads make HP-only impractical.

EX 2 CZ 15 — Not Required

Federal HP cooling minimum below gas-pack cooling-only minimum. Cooling-dominated Palm Springs profile.

EX 3 Electrical Service

Where alteration would exceed main service panel or transformer capacity. PE-stamped CEC Article 220 calc required.



Gas Pathway — Alternative Compliance

For Projects Using Gas Furnaces

Gas-pack RTUs are permitted when their performance is equal to or better than the heat-pump scenario.

HEAT RECOVERY

ERR = 85 %

Pre-condition outside air;
cuts both heating and
cooling loads

COOLING STAGES

Three stages

3-stage DX coil; replaces
2-stage baseline; reduces
part-load short-cycling

GAS HEAT STAGES

Two stages

Two-stage burner;
improves turndown vs.
single-stage 81% AFUE
baseline

FAN CONTROL

25 % no-load

25 % no-load speed + 15
% power reduction; no
extra Table 141.0-D
allowance



Proposed Code Language — §141.0(b) Extension

ALTERATION TRIGGER • COMPLIANCE PATHS • EXCEPTIONS

For Buildings Newly Constructed Between 1978 and 1997																
Building Type	CZ 1	CZ 2	CZ 3	CZ 4	CZ 5	CZ 6	CZ 7	CZ 8	CZ 9	CZ 10	CZ 11	CZ 12	CZ 13	CZ 14	CZ 15	CZ 16
Sit-Down Restaurant	NR	NR	NR	NR	NR	SZVAVHP or SZVAVAC 1	NR	SZVAVHP or SZVAVAC 1	SZVAVHP or SZVAVAC 1	SZVAVHP or SZVAVAC 1	NR	NR	SZVAVHP or SZVAVAC 1	SZVAVHP or SZVAVAC 1	NR	SZVAVDFHP or SZVAVAC1
Large Retail	NR	SZVAVHP or SZVAVAC 1	NR	SZVAVHP or SZVAVAC 1	NR	NR	NR	SZVAVHP or SZVAVAC 1	SZVAVHP or SZVAVAC 1	SZVAVHP or SZVAVAC 1	SZVAVHP or SZVAVAC 1	SZVAVHP or SZVAVAC 1	SZVAVHP or SZVAVAC 1	SZVAVHP or SZVAVAC 1	NR	SZVAVDFHP or SZVAVAC1

For Buildings Newly Constructed Before 1978																
Building Type	CZ 1	CZ 2	CZ 3	CZ 4	CZ 5	CZ 6	CZ 7	CZ 8	CZ 9	CZ 10	CZ 11	CZ 12	CZ 13	CZ 14	CZ 15	CZ 16
Sit-Down Restaurant	NR	NR	NR	NR	NR	SZVAVHP or SZVAVAC 1	SZVAVHP or SZVAVAC 1	SZVAVHP or SZVAVAC 1	SZVAVHP or SZVAVAC 1	SZVAVHP or SZVAVAC 1	NR	NR	SZVAVHP or SZVAVAC 1	NR	NR	SZVAVDFHP or SZVAVAC1
Large Retail	NR	NR	NR	SZVAVHP or SZVAVAC 1	NR	NR	NR	NR	SZVAVHP or SZVAVAC 1	SZVAVHP or SZVAVAC 1	NR	NR	SZVAVHP or SZVAVAC 1	SZVAVHP or SZVAVAC 1	NR	SZVAVDFHP or SZVAVAC1



Market Characterization

MARKET PENETRATION SIGNALS | V&E 2024 + Sathe 2025



54 %

of CA commercial floor
area
served by single-zone RTUs

Comstock + CSS 2014



79 %

of RTU installations
are alteration (replacement)
projects

Sathe 2025



78 %

of alterations still use
conventional gas-pack
units

Sathe 2025



40 %

of CA single-zone RTU
market by capacity
falls in the 5.4 – 20 ton band

Sathe 2025

Market Readiness

Current HP penetration: $\approx 19\%$ of large-RTU replacements (Sathe 2025) — HP share grew $9\% \rightarrow 20\%$ from 2018–2020

Emergency replacements: $\approx 85\%$ of CA RTU replacements are emergency; contractors default to in-stock equipment

Equipment availability: All major manufacturers offer 5.4–20 ton HP units; several offer direct-fit roof-curb replacements

Adjacent regulation: Zero-NOx furnaces only from 2029; ultra-low NOx for ≤ 175 kBtu/h heating — both accelerate HP adoption



Code Sections Affected by the Proposal


ENERGY CODE | ACM REFERENCE MANUAL | COMPLIANCE TOOLS

DOCUMENT	CODE LOCATION	PROPOSED CHANGE
T24 Part 6 (restructured)	§401.5.2.2.1.2 (\$141.0(b)2.C)	Extend alteration requirement to single-zone packaged RTUs with rated cooling capacity $\geq 65,000$ and $\leq 240,000$ Btu/h in retail and restaurant occupancies.
T24 Part 6 (restructured)	Table 401.5-C (new)	New table specifies SZVAVHP requirement by climate zone and vintage; identifies CZs where measure does not apply (CZ 15 retail/restaurant; CZs 7,8 retail pre-1978; CZ 7 restaurant 1978-97).
T24 Part 6 (restructured)	§401.5.2.2.1.2 Exception	Exception applies if alteration requires both larger capacity than existing AND exceeds main service panel or service transformer capacity (PE-stamped load calc required, per CEC Article 220).
T24 Part 6	Table 141.0-D	Gas-pathway alt-compliance with heat recovery (ERR = 85 %), three-stage DX cooling, two-stage gas heat, 25 % no-load fan, no extra Table 141.0-D fan allowance.
Nonresidential ACM	ACM §5.1.4	Standard-design HVAC for alterations updated: SZVAVHP becomes baseline system for retail and sit-down restaurants in cost-effective CZs (≤ 20 ton range).
Joint Appendices	CBECC / Reference Appendices	No new JA tests. CBECC-Com updates to recognize SZVAVHP and the SZVAVAC1 gas pathway. Modeled via AirLoopHVAC:UnitarySystem in EnergyPlus.



Methodology: Selecting Building Types and Vintages (Scope)

RETAIL & RESTAURANT



California statewide saturation and distribution of single-zone RTU conditioned floor area, by building type



Methodology: Selecting Building Types and Vintages

RETAIL & RESTAURANT

Floor area % considering demolished area ((BSD1970 -Demolished) +NEW+ ADD))						Total %
Building Type	Proposed vintage bins					
	Pre-1978	1978-1997	1998-2007	2008-2018	New Construction (2019+)	
Retail - All Sizes	37.5%	33.1%	18.1%	9.7%	1.7%	100.0%
Retail > 50,000 sf	31.5%	25.8%	25.5%	15.2%	2.0%	100.0%
Restaurant - All Sizes	49.6%	28.9%	13.2%	5.8%	2.5%	100.0%
Restaurant > 3,500 sf	48.7%	27.9%	13.4%	6.8%	3.2%	100.0%
Warehouse - All Sizes	22.9%	37.5%	21.1%	11.2%	7.2%	100.0%
Warehouse > 50,000 sf	12.3%	29.6%	29.3%	17.2%	11.5%	100.0%

Source: Dodge Data & Analytics (2023)


70%+ of retail and restaurant floor area is pre-1997 — large stock at or near RTU replacement age



Methodology — Prototypes & Vintages

BUILDING TYPE SELECTION | DODGE 2023 STOCK DATA

Large Retail




INCLUDED

240,023 sf · 1 story

≈ 470 M sf statewide

Sit-Down Restaurant




INCLUDED

5,503 sf · ≥ 3,500 sf

≈ 195 M sf statewide

Warehouse



EXCLUDED

52,050 sf · 1 story


≈ 1,208 M sf statewide

*No viable gas-pathway
alternative that meets HP
performance.*

Vintage Bins Modeled — Selected from Dodge 2023 Stock Distribution

← older stock

newer stock →





Methodology — Baseline Conditions

EXISTING BUILDING REPRESENTATION | ENVELOPE • LIGHTING

Modeled Envelope/Lighting Specifications

Vintage	Component	Value	Source
Both	Roof	Title 24 1992	30-year replacement
Pre-1978	Wall	U-0.352	Minimum insulation pre-Title 24
1978-1997	Wall	U-0.152	Low code-minimum levels of insulation
Both	Window	U-0.74 SHGC-0.52	Single and double-pane mix
Both	Lighting	Title 24-2016	Space-by-space LPDs

- Envelope per original vintage
- Roof per 1992 T24
 - 30-yr replacement
- Lighting per 2016 T24 LPDs

Baseline reflects realistic existing conditions, so savings represent what would actually occur at replacement.



Methodology — Baseline Conditions

EXISTING BUILDING REPRESENTATION | HVAC

Modeled System Specifications:

- Existing HVAC for both vintage bins is modeled from minimum code requirements of 2008 Title 24
 - Based on 15 year expected useful life
-
- **Two-stage control** for DX units
 - **Constant Volume** fan
 - **Economizer** required (Per 2008 T24 §144)
 - No Demand Control Ventilation (per T24 2008 §121-A)
 - No Heat Recovery
 - **Gas furnace** has minimum efficiency (81% AFUE)
 - Single-stage burner

Baseline reflects realistic existing conditions, so savings represent what actually occurs at replacement.



Methodology — Modeling Approach

PROTOTYPE SIMULATION • CBECC 2025 + EnergyPlus v25.1 • 16 CZs

BASELINE

2008-T24 SZAC + gas
furnace
Reflects realistic stock

ADOPTION

35 % naturally occurring
(HP 9 %→20 % 2018–
2020 + zero-NOx pull)

SCALING

1/15 of stock annually
(15-yr life, CEC 2029
forecast)

CZ 16

Dual-fuel HP
modeled
(electric resistance
also evaluated)

- Most projects do not include electric resistance heat – reverse cycle used for defrost
- Without resistance heat, replacement HP units do not carry any additional weight



Methodology — Modeling Approach

PROTOTYPE SIMULATION · CBECC 2025 + EnergyPlus v25.1 · 16 CZs

SIMULATION MATRIX

2

Prototypes

Retail · Restaurant

16

Climate zones

All CA CZs

2

Vintage bins

Pre-1978 · 1978-1997

3

Compliance paths

SZVAVHP · SZVAVAC · SZAC

192

Total number of cases

Prototype × vintage × CZ × path

Analysis Pipeline

1. INPUTS

- CEC nonresidential prototypes
- 2008-T24 baseline envelope/HVAC
- CEC LSC + source + GHG hourly factors
- 2028 CZ-CA weather
- Equipment costs: Manufacturer outreach and professional cost estimating (RSMeans 2026)

2. SIMULATION ENGINE

CBECC 2025 EnergyPlus v25.1

- AirLoopHVAC:UnitarySystem
- Explicit no-load fan-speed control
- Timed reverse-cycle defrost (no elec. backup CZs 1–15)

3. OUTPUTS


- Site energy (kBtu/sf-yr)
- Source energy (CEC factors)
- LSC (\$, 30-yr PV)
- GHG (MT CO₂e/yr)
- Therms saved · BCR by CZ



Energy Impact Results — First Year

STATEWIDE • ANNUAL • WEIGHTED BY FLOOR AREA AND REPLACEMENT RATE

Where Does the Energy Savings Come From?



Net LSC by Prototype × Vintage (Table 19, \$M Present Value)

\$26.1M			
\$15.4M		\$16.1M	\$12.1M
Retail pre-1978	Retail 1978-97	Restaurant pre-1978	Restaurant 1978-97

STATEWIDE NET LSC (First Year)

\$69.7 M

Net PV LSC benefit from first-year compliant alterations, statewide.

Horizon: 30 year LSC (replaces TDV for 2025+)

Discount: 3 % annual real

Adoption: 35 % (HP momentum + zero NOx pull)


Stock: 1/15 of applicable RTU stock / yr



Incremental Cost

HP PREMIUM OVER GAS-PACK | EQUIPMENT + LABOR | RSMEANS 2026

Incremental Cost by Capacity (Table 14, Region 5: CZ 11-13)



Measure Costs:

- Cost basis: Manufacturer outreach and professional cost estimating team (RSMeans 2026). Labor costs vary across five cost regions. A 15-year useful life was assumed, with equivalent maintenance costs for heat pumps and gas-pack systems.
- Larger units have higher incremental cost; HP Equipment cost premiums are very low for all unit sizes below 15 tons
- Labor costs vary slightly with climate zone; equipment costs are constant across climates

⚠ 12.5 TON ANOMALY

Gas-pack 12.5 T pricing high → compresses HP premium. Source data verified.



Cost-Effectiveness — $\text{BCR} \geq 1.0$ Across Most CZs

BENEFIT-COST RATIO | LSC FRAMEWORK | ALL VINTAGES

BCR Range by Building Type & Vintage

CZ 15 EXCLUSION PALM SPRINGS

Cooling-dominated load profile; federal HP min cooling efficiency is slightly below gas-pack cooling-only minimum, eroding seasonal cooling performance.

Result: Net LSC negative in CZ 15.

Action: CZ 15 excluded from the proposed requirement.

Building Type	BCR Range	Cost-Effective CZs	Excluded CZs
Retail Pre-1978	1.4 – 5.7	1–6, 9–14, 16	7, 8, 15
Retail 1978–1997	1.2 – 6.0	All CZs except CZ 15	15
Restaurant Pre-1978	1.6 – 12.1	All CZs except CZ 15	15
Restaurant 1978–1997	1.4 – 9.9	1–6, 8–14, 16	7, 15


BCR threshold for cost-effectiveness is 1.0. Restaurants reach $\text{BCR} > 12$ in milder climates due to high operating-hour leverage.



Proposed Code Language — §141.0(b) Extension

ALTERATION TRIGGER • COMPLIANCE PATHS • EXCEPTIONS

Code Trigger — Decision Flow



Proposed Exceptions

EX 1 CZ 16 — Dual-Fuel HP

Heat pump with gas backup permitted (SZVDFHP rating). Severe heating loads make HP-only impractical.

EX 2 CZ 15 — Not Required

Federal HP cooling minimum below gas-pack cooling-only minimum. Cooling-dominated Palm Springs profile.

EX 3 Electrical Service

Where alteration would exceed main service panel or transformer capacity. PE-stamped CEC Article 220 calc required.



Stakeholder Input Requested

OPEN QUESTIONS FOR THE 2028 RULEMAKING PROCESS

Q1 Dual-fuel HP availability in CZ 16

Incremental cost for SZVAVDFHP is \$1,500–\$4,210 per unit. Considering current and projected product offerings, is there sufficient single-zone variable-capacity dual-fuel heat pump (SZVAVDFHP) availability in the 65,000–240,000 Btu/h range to support the CZ 16 compliance pathway by the 2029 effective date?

- A.** Yes — sufficient products are available today across the full 65,000–240,000 Btu/h range.
- B.** Partially — products are available in the lower capacity range (≈65,000–135,000 Btu/h) but limited above ~135,000 Btu/h.
- C.** Not yet, but availability is expected to be sufficient by the 2029 effective date.
- D.** No — insufficient availability is anticipated to remain a barrier through 2029.
- E.** Unsure / insufficient information to assess.

Q2 Electrical-service exception

The current draft requires a PE-stamped load calculation per California Electrical Code (Title 24, Part 3) Article 220. Which compliance-trigger mechanism do you consider most appropriate for identifying buildings subject to this pathway?

- A.** PE-stamped Article 220 load calculation, as currently drafted.
- B.** A numerical connected/calculated load threshold (e.g., a fixed kW or kVA cutoff) requiring no stamp.
- C.** A service/panel rating test (e.g., based on existing service ampacity or main breaker rating).
- D.** A simpler administrative trigger (e.g., building type + floor area, or nameplate-based screening).
- E.** Other / combination — please specify.



Contact & Acknowledgments

QUESTIONS · COMMENTS · DATA REQUESTS

Project Team

Nasim Mirian, Ph.D.

Senior Building Performance Analyst — Technical Lead

John Arent, P.E.

Senior Engineer

Rahul Athalye

Technical Director, Codes and Standards

ACKNOWLEDGMENTS

California Energy Commission

Gypsy Achong, Habtom Tewelde, Bill Pennington,
Payam Bozorgchami, Michael Shewmaker, Ram
Narayanamurthy, Gabriel Taylor, Ronald Balneg



Comments for Today's Workshop

Due Date: July 17, 2026, by 5:00PM

Comments to be submitted to:

[https://efiling.energy.ca.gov/Ecomment/Ecomment.aspx?
docketnumber=25-BSTD-03](https://efiling.energy.ca.gov/Ecomment/Ecomment.aspx?docketnumber=25-BSTD-03)

Thank you for participating in today's workshop!

Questions?