


DOCKETED

Docket Number:	09-AFC-03C
Project Title:	MARIPOSA ENERGY PROJECT - Compliance
TN #:	271313
Document Title:	Mariposa Energy (Diamond Generation) Comments - Mariposa (#G1015) 2026 Q2 QCR
Description:	N/A
Filer:	System
Organization:	Mariposa Energy (Diamond Generation)
Submitter Role:	Public
Submission Date:	7/8/2026 8:41:38 AM
Docketed Date:	7/8/2026

Comment Received From: Mariposa Energy (Diamond Generation)
Submitted On: 7/8/2026
Docket Number: 09-AFC-03C

Mariposa (#G1015) 2026 Q2 QCR

Additional submitted attachment is included below.



Mariposa

Energy Project

July 6, 2026

Anwar Ali
Compliance Project Manager
California Energy Commission
Siting, Transmission, & Environmental Protection (“STEP”) Division
1516 Ninth Street, MS-2000
Sacramento, CA 95814

Reference: Mariposa Energy, LLC (09-AFC-3C) Compliance with Air Quality Conditions of Certification (CEC #G1015)

Subject: CEC Condition of Certification AQ-SC8:
Quarterly Compliance Report for Quarter-Ending June 30, 2026

Dear Mr. Ali,

To demonstrate ongoing compliance with the California Energy Commission (“CEC”) and Bay Area Air District (“BAAD”) regulations, Mariposa Energy, LLC (previously Mariposa Energy Project) is submitting its Quarterly Compliance Report (“QCR”) including Attachment 1, “Compliance Summary”, for quarter-ending June 30, 2026. As required, a copy of the report is also being sent to the BAAD. This QCR is being submitted to satisfy the requirements of:

- CEC - Mariposa Energy Project “Commission Decision”, (Docket No. 09-AFC-3) – Cond. AQ-SC8.
- BAAD - Permit to Operate, Plant #19730, Condition #24955, Part 33.
- United States Environmental Protection Agency, Code of Federal regulations, Title 40, Part 60, Subpart KKKK, Section 4375 (40 CFR 60.4375).

The QCR contains the following attachments:

Attachment 1: Compliance Summary: Table identifying each condition relevant to the QCR, operational limits, compliance status (including supporting data), and reference location within the QCR.

Attachment 2: Condition AQ-11 Monthly Natural Gas Fuel Analyses: Monthly analytical results for natural gas analysis as provided by the natural gas supplier (Pacific Gas and Electric) to demonstrate compliance with the natural gas sulfur content limit, as required by AQ-11.

Attachment 3: Condition AQ-12 Heat Input Limits: 1-hr for all CTGs Report: Report demonstrating compliance with maximum 1-hr heat input for combustion turbine generator (CTG) Unit 600 (S-1), Unit 700 (S-2), Unit 800 (S-3), and Unit 900 (S-4).

- Attachment 4: Condition AQ-13 Heat Input Limits: Daily Maximums for all CTGs Report: Report demonstrating compliance with daily total heat input for CTG Unit 600 (S-1), Unit 700 (S-2), Unit 800 (S-3), and Unit 900 (S-4), Condition AQ-14 Heat Input Limit: Rolling 12-Month combined CTG Heat Input Report: Report demonstrating compliance with annual (rolling 12-month) combined heat input limit to CTG Units 600 (S-1), 700 (S-2), 800 (S-3), and 900 (S-4), and Condition AQ-15a/b Operating Hour Limits: Rolling 12-Month individual and combined CTG Hours Report: Report demonstrating compliance with annual (rolling 12-month) individual and combined hours of operation limits for CTG Units 600 (S-1), 700 (S-2), 800 (S-3), and 900 (S-4).
- Attachment 5: Condition AQ-16 SCR/Oxidation Catalyst Operation Report: Report demonstrating the CTG Units 600 (S-1), 700 (S-2), 800 (S-3), and 900 (S-4) emissions are abated by properly operating SCR and Oxidation Catalyst systems.
- Attachment 6: Condition AQ-17a/b NO_x Emissions Limits: Hourly Mass Rate and Hourly Average Concentration Report: Report of hourly (rolling 60-minute) NO_x concentrations and emissions from CTG Units 600 (S-1), 700 (S-2), 800 (S-3), and 900 (S-4), Condition AQ-17c/d CO Emission Limits: Hourly Mass Rate/Rolling 3-Hr Concentration Report: Report demonstrating compliance with hourly (rolling 60-minute) CO mass emissions and rolling 3-hour CO concentrations from CTG Units 600 (S-1), 700 (S-2), 800 (S-3), and 900 (S-4), Condition AQ-17e NH₃ Emission Limits: Rolling 3-Hr Slip Calculation Report: Report demonstrating compliance with rolling 3-hr ammonia emission concentration limit as calculated by source test-derived correlation as required by AQ-25, and Condition AQ-17f/g Hourly Mass Emission Limits: POC & SO₂ Report: Report demonstrating compliance with hourly POC and SO₂ emission limits for Combustion Turbine Generator (CTG) units 600 (S-1), 700 (S-2), 800 (S-3), and 900 (S-4).
- Attachment 7: Condition AQ-18 Startup and Shutdown Emission Limits Report: Report of startup and shutdown emissions for CTG Units 600 (S-1), 700 (S-2), 800 (S-3), and 900 (S-4).
- Attachment 8: Condition AQ-19 Daily Emission Limits: NO_x, CO, POC, and SO₂ Emissions Report: Report demonstrating compliance with daily NO_x, CO, POC and SO₂ limits for all CTG units combined.
- Attachment 9: Condition AQ-20 Cumulative Rolling 12-month CTG Emissions: NO_x, CO, POC, PM₁₀, SO₂ Emissions Report: Report demonstrating compliance with consecutive 12-month NO_x, CO, POC, PM₁₀ and SO₂ limits for all CTG units combined, and Condition AQ-31 Facility SAM 12-month Tons Limit Emissions Report: Report demonstrating compliance with consecutive 12-month sulfuric acid emissions limit for all CTG units combined.
- Attachment 10: Exceedances / Violations
NOV A63623 issued April 9, 2026, failure to meet fuel sulfur content and SO₂ limits during Unit 800 RATA conducted February 20, 2025 (NST-10130) per permit conditions 24955.11 and 24955.17g.
- Attachment 11: Condition AQ-38 40 CFR Part 72.9(c)(1) SO₂ Allowances and 40 CFR Part 75 CEM Requirements Report: Report demonstrating compliance with Condition AQ-38


requiring holding of SO₂ allowances and compliance with CEM requirements of 40 CFR Part 75.

Attachment 12: Conditions AQ-39, AQ-40 S-6 Emergency Fire Pump Operation Report (BAAQMD Condition 22850, parts 1 & 2): Report demonstrating compliance with specified IC engine operating limitations.

Attachment 13: Condition AQ-41 S-6 Emergency Fire Pump Totalizing Meter Report (BAAQMD Condition 22850, part 3): Photographic record demonstrating the installation and use of hour-meter for tracking engine operation.

If you have any questions regarding this submittal, please contact Wayne Forsyth by email at w.forsyth@dgc-us.com or phone (213) 473-0093, or Jason Smith by email at j.smith@dgc-ops.com or phone (925) 666-5409.

Best regards,

A handwritten signature in black ink, appearing to read 'Jason Smith', with a stylized flourish at the end.

Jason Smith
EH&S Coordinator
Mariposa Energy, LLC

cc: Davis Zhu (BAAQMD)

Attachment 1

Compliance Summary

Mariposa Energy, LLC

Quarterly Compliance Report

Quarter Ending June 30, 2026

Mariposa Energy, LLC

Quarterly Compliance Report

Quarter Ending June 30, 2026

This report documents compliance with the California Energy Commission's Conditions of Certification AQ-SC8 and Bay Area Air Quality Management District Permit condition 24955

Attached are summaries of relevant permit conditions and compliance status as well as the required documentation.

Attachment 1: Compliance Summary

Attachment 2: Condition AQ-11 Monthly Natural Gas Sulfur Content - PGE

Attachment 3: Condition AQ-12 Heat Input Limits: 1-hr Maximums for all CTGs Report

Attachment 4: Condition AQ-13 Heat Input Limits: Daily Maximums for all CTGs Report, Condition AQ-14 Heat Input Limit: Rolling 12-Month combined CTG Heat Input and Condition AQ-15a/b Operating Hour Limits: Rolling 12-Month Individual and Combined CTG Hours Report

Attachment 5: Condition AQ-16 SCR/Oxidation Catalyst Operation Report

Attachment 6: Condition AQ-17a/b NOx Emission Limits: Hourly mass rate and hourly average concentration Report, Condition AQ-17c/d CO Emission Limits: Hourly Mass Rate/Rolling 3-Hr Concentration Report, Condition AQ-17e NH3 Emission Limits: Rolling 3-Hr Slip Calculation Report and Condition AQ-17f/g Hourly Mass Emission Limits: POC & SO2 Report

Attachment 7: Condition AQ-18 Startup and Shutdown Emission Limits Report

Attachment 8: Condition AQ-19 Daily Emission Limits: NOx, CO, POC, SO2 Emissions Report

Attachment 9: Condition AQ-20 Cumulative Rolling 12-month CTG Emissions: NOx, CO, POC, PM10, SO2 Emissions Report and Condition AQ-31 Facility SAM 12-month Tons Limit Emissions Report

Attachment 10: Exceedances / Violations

Attachment 11: Condition AQ-38 40 CFR Part 72.9(c)(1) SO2 Allowances and 40 CFR Part 75 CEM Requirements Report

Attachment 12: Conditions AQ-39, AQ-40 S-6 Emergency Fire Pump Operation Report (BAAQMD Condition 24955, parts 1 & 2)

Attachment 13: Condition AQ-41 S-6 Emergency Fire Pump Totalizing Meter Report (BAAQMD Condition 22850, part 3)

Mariposa Energy, LLC
CEC Quarterly Air Compliance Report

COMPLIANCE SUMMARY

Condition	Condition Description	Verification or Limit	Status	Section
AQ-11	Fire the Gas Turbines (S-1, S-2, S-3, and S-4) exclusively on PUC-regulated natural gas with a maximum sulfur content of 1 grain per 100 standard cubic feet.	1 grain sulfur per 100 scf. The result of the natural gas fuel sulfur monitoring data and other fuel sulfur content data are to be submitted to District and CEC in the Quarterly Report.	<u>Sulfur Content</u> (gr/100 scf) April 2026: 0.26 May 2026: 0.25 June 2026: 0.23 In Compliance Q2 2026 Note: NOV issued by BAAD on 4/9/2026. See attachment 10.	Attachment 2
AQ-12	Hourly Heat input rate to each Gas Turbine (S-1, S-2, S-3, and S-4).	500 MMBtu (HHV)/hr per turbine.	<u>Maximum MMBtu/hr</u> S-1: 447 S-2: 457 S-3: 457 S-4: 448 In Compliance	Attachment 3
AQ-13	Daily heat input rate to each Gas Turbine (S-1, S-2, S-3, and S-4).	12,000 MMBtu (HHV)/day per turbine.	<u>Maximum MMBtu/day</u> S-1: 2659 S-2: 2704 S-3: 2690 S-4: 2545 In Compliance	Attachment 4
AQ-14	Combined annual cumulative heat input rate for the gas turbines (S-1 + S-2 + S-3 + S-4).	8,128,900 MMBtu (HHV) per year (combined cumulative).	<u>MMBTU/yr (12-mo)</u> Ending 4/2026: 249,880 Ending 5/2026: 251,286 Ending 6/2026: 235,525 In Compliance	Attachment 4
AQ-15a	Maximum annual hours of operation per turbine.	5,200 hours per year per turbine.	<u>Maximum Hr/yr</u> S-1: 186 (5/2026) S-2: 188 (5/2026) S-3: 192 (5/2026) S-4: 154 (6/2026) In Compliance	Attachment 4

Mariposa Energy, LLC
CEC Quarterly Air Compliance Report

COMPLIANCE SUMMARY

Condition	Condition Description	Verification or Limit	Status	Section
AQ-15b	Combined annual hours of operation for the gas turbines (S-1 + S-2 + S-3 + S-4).	16,900 hours per year total – four units combined turbine hours of operation.	<u>Combined Hours/yr</u> 12 mo Ending 4/26: 693 12 mo Ending 5/26: 718 12 mo Ending 6/26: 675 In Compliance	Attachment 4
AQ-16	The owner/operator shall ensure that each Gas Turbine (S-1, S-2, S-3, S-4) is abated by the properly operated and properly maintained Selective Catalytic Reduction (SCR) System A-2, A-4, A-6, or A-8 and Oxidation Catalyst System A-1, A-3, A-5, or A-7 whenever fuel is combusted at those sources and the corresponding SCR catalyst bed (A-2, A-4, A-6 or A-8) has reached minimum operating temperature.	The owner/operator shall make the site available for inspection by representatives of the District, ARB, and the Commission upon request. A summary of significant operation and maintenance events and monitoring records shall be included in the quarterly operation report.	In Compliance	Attachment 5
AQ-17	The owner/operator shall ensure that the Gas Turbines (S-1, S-2, S-3, S-4) comply with requirements (a) through (i). Requirements (a) through (f) do not apply during a gas turbine start-up, and shutdown.			
	a. Hourly Nitrogen Oxide mass emissions limit (calculated as NO ₂), per turbine unit basis, after abatement.	4.4 lb/hr maximum (as NO ₂), from each turbine exhaust point, after abatement.	<u>Max NOx lb/hr:</u> S-1: 3.9 S-2: 3.9 S-3: 3.7 S-4: 3.4 In Compliance	Attachment 6
	b. Hourly average Nitrogen Oxide emission concentration limit , per turbine.	2.5 ppmv maximum (as NO ₂), dry, corrected to 15% O ₂ , averaged over any 1-hour period.	<u>Max NOx, ppmvd @ 15%O₂:</u> S-1: 2.4 S-2: 2.3 S-3: 2.2 S-4: 2.3 In Compliance	Attachment 6
	c. Hourly Carbon Monoxide mass emissions limit , per turbine basis, after abatement.	2.14 lb/hr CO maximum, from each turbine exhaust point.	<u>Max CO lb/hr:</u> S-1: 1.9 S-2: 1.9 S-3: 1.9 S-4: 0.8 In Compliance	Attachment 6

Mariposa Energy, LLC
CEC Quarterly Air Compliance Report

COMPLIANCE SUMMARY

Condition	Condition Description	Verification or Limit	Status	Section
	d. Rolling 3-hour average Carbon Monoxide emission concentration per turbine basis, after abatement.	2.0 ppmv CO (maximum), dry, corrected to 15% O ₂ , averaged over any rolling 3-hour period.	<u>Max CO, ppmvd @ 15% O₂:</u> S-1: 1.9 S-2: 1.9 S-3: 1.8 S-4: 0.8 In Compliance	Attachment 6
AQ-17 cont'd	e. Rolling 3-hour average Ammonia (NH₃) emission concentrations , per turbine unit basis, after abatement systems.	5 ppmv, dry, corrected to 15% O₂ , averaged over any rolling 3-hour period. Verified by the continuous recording of the ammonia injection rate to each SCR System A-2, A-4, A-6, and A-8. The correlation between the gas turbine heat input rates, A-2, A-4, A-6, and A-8 SCR System ammonia injection rates, and corresponding ammonia emission concentration at emission points P-1, P-2, P-3 and P-4 shall be determined in accordance with AQ-25 or a District approved alternative method.	<u>Max NH₃, ppmvd @ 15% O₂:</u> S-1: 3.4 S-2: 3.0 S-3: 2.4 S-4: 2.8 In Compliance	Attachment 6
	f. Hourly Precursor Organic Compound (POC) mass emissions limit (as CH ₄), per turbine unit basis.	0.612 lb/hr maximum (as CH ₄), from each turbine exhaust point.	<u>Max POC lb/hr:</u> S-1: 0.3 S-2: 0.3 S-3: 0.3 S-4: 0.3 In Compliance	Attachment 6
	g. Hourly Sulfur dioxide (SO₂) mass emissions limit , per turbine unit basis, after abatement.	1.347 lb/hr maximum (as SO ₂) from each turbine exhaust point.	<u>Max SO₂ lb/hr:</u> S-1: 0.6 S-2: 0.3 S-3: 0.3 S-4: 0.3 In Compliance Q2 2026 Note: NOV issued by BAAD on 4/9/2026. See attachment 10.	Attachment 6

Mariposa Energy, LLC
CEC Quarterly Air Compliance Report

COMPLIANCE SUMMARY

Condition	Condition Description	Verification or Limit	Status	Section
AQ-18	Maximum startup emissions of NO _x (as NO ₂), CO, and POC (as CH ₄) (lb/startup).	NO _x (NO ₂): 14.2 lb/startup	<u>Max NO_x Startup Emissions, lb</u> S-1: 5.59 S-2: 5.63 S-3: 6.38 S-4: 6.02 In Compliance	Attachment 7
AQ-18 cont'd		CO: 14.1 lb/startup	<u>Max CO Startup Emissions, lb</u> S-1: 1.59 S-2: 1.59 S-3: 1.39 S-4: 0.83 In Compliance	Attachment 7
		POC (as CH ₄): 1.1 lb/startup	<u>Max POC Startup Emissions, lb</u> S-1: 0.0 S-2: 0.1 S-3: 0.1 S-4: 0.0 In Compliance	Attachment 7
		NO _x (NO ₂): 18.5 lb/hour	<u>Max NO_x Emissions, lb/hr</u> S-1: 6.8 S-2: 6.8 S-3: 7.4 S-4: 6.9 In Compliance	Attachment 6
	Maximum hourly emissions of NO _x (as NO ₂), CO, and POC (as CH ₄) <u>with</u> <u>startup</u> .	CO: 17.3 lb/hour	<u>Max CO Emissions, lb/hr</u> S-1: 2.2 S-2: 2.0 S-3: 2.4 S-4: 1.3 In Compliance	Attachment 6

Mariposa Energy, LLC
CEC Quarterly Air Compliance Report

COMPLIANCE SUMMARY

Condition	Condition Description	Verification or Limit	Status	Section
AQ-18 cont'd		POC (as CH ₄): 1.4 lb/hour	<u>Max POC Emissions lb/hr</u> S-1: 0.3 S-2: 0.3 S-3: 0.3 S-4: 0.2 In Compliance	Attachment 6
	Maximum shutdown emissions of NO _x (as NO ₂), CO, and POC (as CH ₄) (lb/shutdown).	NO _x (NO ₂): 3.2 lb/shutdown	<u>Max Shutdown Emissions, lb</u> S-1: 0.96 S-2: 0.78 S-3: 0.75 S-4: 0.94 In Compliance	Attachment 7
		CO: 2.7 lb/shutdown	<u>Max Shutdown Emissions, lb</u> S-1: 0.25 S-2: 0.30 S-3: 0.26 S-4: 0.00 In Compliance	Attachment 7
		POC (as CH ₄): 0.12 lb/shutdown	<u>Max Shutdown Emissions lb</u> S-1: 0.00 S-2: 0.00 S-3: 0.01 S-4: 0.00 In Compliance	Attachment 7
AQ-19	Calendar day Cumulative combined emission limits from the Gas Turbines (S-1 + S-2 + S-3 + S-4), including emissions generated during gas turbine start-ups, shutdowns and testing.			
	a. Maximum daily NO _x (as NO ₂) emissions.	NO _x (as NO ₂): 1100 lb/day	Max lb/day NO _x : 112	Attachment 8
	b. Maximum daily CO emissions.	CO: 934 lb/day	Max lb/day CO: 39	
	c. Maximum daily POC emissions.	POC (as CH ₄): 95 lb/day	Max lb/day POC: 7	
	d. Maximum daily SO ₂ emissions.	SO ₂ : 130 lb/day	Max lb/day SO ₂ : 8 In Compliance	

Mariposa Energy, LLC
CEC Quarterly Air Compliance Report

COMPLIANCE SUMMARY

Condition	Condition Description	Verification or Limit	Status	Section
AQ-20	Cumulative combined annual (any consecutive twelve-month period) emissions from the Gas Turbines (S-1 + S-2 + S-3 + S-4):			
	a. Maximum annual NOx (as NO ₂) emissions.	NOx (as NO ₂): 45.6 ton/year	<u>Cumulative Ton/Yr</u> Ending 4/30/2026: 1.4 Ending 5/31/2026: 1.4 Ending 6/30/2026: 1.3 In Compliance	Attachment 9
AQ-20 cont'd	b. Maximum annual CO emissions.	CO: 27.2 ton/year	Ending 4/30/2026: 0.5 Ending 5/31/2026: 0.5 Ending 6/30/2026: 0.5 In Compliance	Attachment 9
	c. Maximum annual POC (as CH ₄) emissions.	POC (as CH ₄): 5.6 ton/year	Ending 4/30/2026: 0.1 Ending 5/31/2026: 0.1 Ending 6/30/2026: 0.1 In Compliance	Attachment 9
	d. Maximum annual PM10 emissions. Emissions of PM10 from each gas turbine shall be calculated by multiplying turbine fuel usage times an emission factor determined by source testing of the turbine conducted in accordance with Part 26. The emission factor for each turbine shall be based on the average of the emissions rates observed during the 4 most recent source tests on that turbine (or, prior to the completion of 4 source tests on a turbine, on the average of the emission rates observed during all source tests on the turbine).	PM10: 18.6 ton/year	Ending 4/30/2026: 0.1 Ending 5/31/2026: 0.1 Ending 6/30/2026: 0.1 In Compliance	Attachment 9
	e. Maximum annual SO ₂ emissions.	SO ₂ : 2.9 ton/year	Ending 4/30/2026: 0.1 Ending 5/31/2026: 0.1 Ending 6/30/2026: 0.1 In Compliance	Attachment 9

Mariposa Energy, LLC
CEC Quarterly Air Compliance Report

COMPLIANCE SUMMARY

Condition	Condition Description	Verification or Limit	Status	Section
AQ-31	Cumulative combined annual Sulfuric Acid Mist (SAM) emissions. (Any consecutive 12-month period) emissions from the gas turbines (S-1 + S-2 + S-3 + S-4).	7.0-ton Sulfuric Acid Mist in any consecutive 12-month.	Cumulative Ton/Year Ending 4/30/2026: 0.1 Ending 5/31/2026: 0.1 Ending 6/30/2026: 0.1 In Compliance	Attachment 9
AQ-35	The owner/operator of the MEP shall notify the District and the CEC CPM of any violations of these permit conditions. Notification shall be submitted in a timely manner, in accordance with all applicable District Rules, Regulations, and the Manual of Procedures. Notwithstanding the notification and reporting requirements given in any District Rule, Regulation, or the Manual of Procedures, the owner/operator shall submit written notification (facsimile is acceptable) to the Enforcement Division within 96 hours of the violation of any permit condition.	A summary of significant operation and maintenance events and monitoring records shall be included in the quarterly operation report.	No violations of any permit conditions requiring District and CEC notification were found during the 2nd Quarter of 2026 In Compliance Q2 2026 Note: NOV issued by BAAD on 4/9/2026. See attachment 10.	Attachment 10
AQ-38	The owner/operator shall ensure that the MEP complies with the requirement to hold SO ₂ allowances in 40 CFR 72.9c(1) and the continuous emission monitoring requirements of 40 CFR Part 75.	The project owner shall submit to the CPM and District the results of audits of the monitoring system demonstrating compliance with this condition as part of the quarterly operation report.	Attachment 11 provides the CAMD Balance Report (2/10/2026) for SO ₂ allowances as well as the 1Q 2026 Monthly CEMS Reports summary pages as submitted to BAAQMD. In Compliance	Attachment 11
AQ-39	Cumulative combined annual (any consecutive twelve-month period) operating hours for reliability-related testing of S-6 Emergency Standby Diesel Fire Pump Engine:			
	The owner/operator shall not exceed 50 hours per year per engine for reliability-related testing.	A summary of significant operation and maintenance events and monitoring records shall be included in the quarterly operation report.	Ending 4/30/2026: 27.3 Ending 5/31/2026: 27.6 Ending 6/30/2026: 28.1 In Compliance	Attachment 12

Mariposa Energy, LLC
CEC Quarterly Air Compliance Report

COMPLIANCE SUMMARY

Condition	Condition Description	Verification or Limit	Status	Section
AQ-40	S-6 Emergency Standby Diesel Fire Pump Engine cumulative combined annual (any consecutive twelve-month period) total operating hours, including mitigation of emergency conditions, emissions and reliability testing:			
	The owner/operator shall operate each emergency standby engine only for the following purposes: to mitigate emergency conditions, for emission testing to demonstrate compliance with a District, State, or Federal emission limit, or for reliability-related activities (maintenance and other testing, but excluding emission testing). Operation while mitigating emergency conditions or while emission testing to show compliance with District, State or Federal emissions limits is not limited.	A summary of significant operation and maintenance events and monitoring records shall be included in the quarterly operation report.	S-6 <u>12-Mo Hrs Ending 4/30/26:</u> Total Hrs Operated: 27.3 Hrs Op as allowed: 27.3 <u>12-Mo Hrs Ending 5/31/26:</u> Total Hrs Operated: 27.6 Hrs Op as allowed: 27.6 <u>12-Mo Hrs Ending 6/30/26:</u> Total Hrs Operated: 28.1 Hrs Op as allowed: 28.1 In Compliance	Attachment 12
AQ-41	S-6 Emergency Standby Diesel Fire Pump Engine Non-Resettable Totalizing Hour Meter			
	The owner/operator shall operate each emergency standby engine only when a non-resettable totalizing meter (with a minimum display capability of 9,999 hours) that measures the hours of operation for the engines is installed, operated and properly maintained.	The project owner shall make the site available for inspection by representatives of the District, ARB and the Commission. The project owner shall include a photograph of each totalizing meter in the quarterly operation report.	A photograph of each totalizing meter is included in the quarterly compliance report. In Compliance	Attachment 13

Attachment 2

Monthly Natural Gas Sulfur Content – PGE

[Subscription Services](#)[Contact Us / Weekend on Call](#)[Rates and Tariffs](#)[About CGT](#)[Products](#)[Tools & Services](#)[Operations](#)[Reference Library](#)[INSIDetracc Login](#) [Gas Quality Information](#)[Therm Factor Heating Values](#)[Sulfur Information](#)[Gas System Sulfur Survey Results](#)

Jump to:

[2021 - 2026](#)[2016 - 2020](#)[2011 - 2015](#)[2006 - 2010](#)

2021 - 2026

2026

Date	Total Sulfur Maximum		Total Sulfur Average all sites	
	PPMv	gr/100 scf	PPMv	gr/100 scf
2026				
Second Quarter	4.4	0.26	2.9	0.17
Second Quarter - April	4.4	0.26	2.7	0.16
Second Quarter - May	4.2	0.25	2.9	0.17
Second Quarter - June	3.9	0.23	2.9	0.17

Attachment 3

Condition AQ-12: Heat Input Report – Max 1-hour

Mariposa Energy
Byron California
Facility Daily Operations Report
April 1, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
April 2, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
April 3, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
April 4, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
April 5, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
April 6, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
April 7, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
April 8, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
April 9, 2026

Facility 12-Month Rolling Operational Limits	
Heat Input mmBtu - 8,128,900	Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
April 10, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
April 11, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
April 12, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
April 13, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
April 14, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
April 15, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	7.2	0.05	7.7	0.05	5.5	0.03	7.6	0.05	28.0	0.18
06	259.7	1.00	264.7	1.00	261.8	1.00	261.1	1.00	1047.3	4.00
07	262.5	1.00	267.6	1.00	263.0	1.00	262.2	1.00	1055.3	4.00
08	259.1	1.00	263.5	1.00	263.0	1.00	262.5	1.00	1048.1	4.00
09	260.8	1.00	265.2	1.00	262.0	1.00	261.4	1.00	1049.4	4.00
10	261.8	1.00	266.1	1.00	262.3	1.00	261.4	1.00	1051.6	4.00
11	264.2	1.00	268.6	1.00	264.5	1.00	264.2	1.00	1061.5	4.00
12	20.2	0.15	21.1	0.15	21.0	0.15	20.8	0.15	83.1	0.60
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	1595.5	6.20	1624.5	6.20	1603.1	6.18	1601.2	6.20	6424.3	24.78

Mariposa Energy
Byron California
Facility Daily Operations Report
April 16, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
April 17, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
April 18, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
April 19, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
April 20, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	177.7	0.68	180.7	0.68	180.5	0.68	179.0	0.68	717.9	2.72
23	162.6	0.63	152.8	0.63	165.9	0.63	151.6	0.63	632.9	2.52
Daily Total	340.3	1.31	333.5	1.31	346.4	1.31	330.6	1.31	1350.8	5.24

Mariposa Energy
Byron California
Facility Daily Operations Report
April 21, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
April 22, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
April 23, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
April 24, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
April 25, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
April 26, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
April 27, 2026

Facility 12-Month Rolling Operational Limits	
Heat Input mmBtu - 8,128,900	Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
April 28, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
April 29, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
April 30, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
May 1, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	4.2	0.03	4.4	0.03	4.4	0.03	4.5	0.03	17.5	0.12
02	268.6	1.00	275.1	1.00	274.4	1.00	273.3	1.00	1091.4	4.00
03	378.7	1.00	383.9	1.00	378.7	1.00	272.8	1.00	1414.1	4.00
04	274.9	1.00	280.2	1.00	280.4	1.00	276.3	1.00	1111.8	4.00
05	265.5	1.00	270.7	1.00	270.4	1.00	273.4	1.00	1080.0	4.00
06	263.1	1.00	267.8	1.00	267.4	1.00	270.2	1.00	1068.5	4.00
07	266.4	1.00	272.0	1.00	271.9	1.00	274.2	1.00	1084.5	4.00
08	266.3	1.00	271.6	1.00	271.4	1.00	273.6	1.00	1082.9	4.00
09	20.3	0.15	21.2	0.15	21.2	0.15	21.2	0.15	83.9	0.60
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	2.0	0.02	2.2	0.02	2.1	0.02	2.1	0.02	8.4	0.08
22	379.3	1.00	379.6	1.00	371.9	1.00	330.0	1.00	1460.8	4.00
23	269.6	1.00	274.8	1.00	275.7	1.00	272.9	1.00	1093.0	4.00
Daily Total	2658.9	9.20	2703.5	9.20	2689.9	9.20	2544.5	9.20	10596.8	36.80

Mariposa Energy
Byron California
Facility Daily Operations Report
May 2, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	269.0	1.00	273.8	1.00	274.5	1.00	272.1	1.00	1089.4	4.00
01	270.9	1.00	275.3	1.00	276.2	1.00	274.1	1.00	1096.5	4.00
02	268.4	1.00	273.5	1.00	274.3	1.00	271.8	1.00	1088.0	4.00
03	268.9	1.00	273.7	1.00	274.5	1.00	272.0	1.00	1089.1	4.00
04	269.8	1.00	274.5	1.00	275.4	1.00	272.9	1.00	1092.6	4.00
05	267.6	1.00	272.2	1.00	273.0	1.00	270.5	1.00	1083.3	4.00
06	267.9	1.00	272.5	1.00	273.3	1.00	270.8	1.00	1084.5	4.00
07	267.7	1.00	272.2	1.00	273.1	1.00	270.5	1.00	1083.5	4.00
08	19.9	0.15	20.7	0.15	21.1	0.15	20.7	0.15	82.4	0.60
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	2170.1	8.15	2208.4	8.15	2215.4	8.15	2195.4	8.15	8789.3	32.60

Mariposa Energy
Byron California
Facility Daily Operations Report
May 3, 2026

Facility 12-Month Rolling Operational Limits	
Heat Input mmBtu - 8,128,900	Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
May 4, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	205.1	0.78	209.8	0.78	209.3	0.78	207.9	0.78	832.1	3.12
13	108.1	0.43	112.8	0.42	96.3	0.43	95.3	0.42	412.5	1.70
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	313.2	1.21	322.6	1.20	305.6	1.21	303.2	1.20	1244.6	4.82

Mariposa Energy
Byron California
Facility Daily Operations Report
May 5, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	5.2	0.03	5.4	0.03	5.2	0.03	5.3	0.03	21.1	0.12
07	268.2	1.00	276.8	1.00	277.1	1.00	271.2	1.00	1093.3	4.00
08	269.4	1.00	279.3	1.00	279.6	1.00	273.1	1.00	1101.4	4.00
09	263.7	1.00	268.4	1.00	268.4	1.00	267.3	1.00	1067.8	4.00
10	262.5	1.00	281.8	1.00	281.7	1.00	265.6	1.00	1091.6	4.00
11	323.1	1.00	327.0	1.00	328.2	1.00	298.6	1.00	1276.9	4.00
12	265.2	1.00	269.1	1.00	280.8	1.00	266.6	1.00	1081.7	4.00
13	22.1	0.15	22.9	0.15	23.0	0.15	24.5	0.17	92.5	0.62
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	1679.4	6.18	1730.7	6.18	1744.0	6.18	1672.2	6.20	6826.3	24.74

Mariposa Energy
Byron California
Facility Daily Operations Report
May 6, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
May 7, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
May 8, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
May 9, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
May 10, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
May 11, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	7.4	0.05	4.8	0.03	6.9	0.05	6.9	0.05	26.0	0.18
18	284.1	0.72	287.7	0.72	287.7	0.72	274.0	0.72	1133.5	2.88
19	447.0	1.00	456.9	1.00	456.9	1.00	394.3	1.00	1755.1	4.00
20	245.8	0.65	253.3	0.65	257.5	0.67	234.6	0.67	991.2	2.64
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	984.3	2.42	1002.7	2.40	1009.0	2.44	909.8	2.44	3905.8	9.70

Mariposa Energy
Byron California
Facility Daily Operations Report
May 12, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
May 13, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	8.0	0.05	8.3	0.05	8.1	0.05	4.1	0.05	28.5	0.20
02	257.4	1.00	262.3	1.00	261.8	1.00	2.4	0.03	783.9	3.03
03	350.5	1.00	353.4	1.00	353.3	1.00	244.8	0.70	1302.0	3.70
04	437.9	1.00	448.2	1.00	448.2	1.00	447.9	1.00	1782.2	4.00
05	257.6	1.00	262.5	1.00	262.7	1.00	260.4	1.00	1043.2	4.00
06	20.0	0.15	21.2	0.15	20.9	0.15	20.8	0.15	82.9	0.60
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	1331.4	4.20	1355.9	4.20	1355.0	4.20	980.4	2.93	5022.7	15.53

Mariposa Energy
Byron California
Facility Daily Operations Report
May 14, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
May 15, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
May 16, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
May 17, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
May 18, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
May 19, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
May 20, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
May 21, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
May 22, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
May 23, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
May 24, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
May 25, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
May 26, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	200.2	0.77	201.6	0.77	200.7	0.77	195.3	0.77	797.8	3.08
13	79.0	0.37	80.9	0.37	80.4	0.37	77.6	0.37	317.9	1.48
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	279.2	1.14	282.5	1.14	281.1	1.14	272.9	1.14	1115.7	4.56

Mariposa Energy
Byron California
Facility Daily Operations Report
May 27, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
May 28, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	301.2	0.77	292.3	0.77	305.2	0.77	268.7	0.77	1167.4	3.08
23	89.2	0.40	93.0	0.40	95.8	0.42	95.9	0.42	373.9	1.64
Daily Total	390.4	1.17	385.3	1.17	401.0	1.19	364.6	1.19	1541.3	4.72

Mariposa Energy
Byron California
Facility Daily Operations Report
May 29, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
May 30, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
May 31, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
June 1, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
June 2, 2026

Facility 12-Month Rolling Operational Limits	
Heat Input mmBtu - 8,128,900	Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
June 3, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
June 4, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
June 5, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	153.1	0.58	154.7	0.58	154.7	0.58	154.2	0.58	616.7	2.32
03	272.5	1.00	275.8	1.00	275.8	1.00	275.0	1.00	1099.1	4.00
04	323.3	1.00	13.3	0.12	13.5	0.12	13.3	0.12	363.4	1.36
05	13.3	0.12	Down	0.00	Down	0.00	Down	0.00	13.3	0.12
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	5.7	0.07	Down	0.00	Down	0.00	Down	0.00	5.7	0.07
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	767.9	2.77	443.8	1.70	444.0	1.70	442.5	1.70	2098.2	7.87

Mariposa Energy
Byron California
Facility Daily Operations Report
June 6, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
June 7, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
June 8, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
June 9, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
June 10, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
June 11, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
June 12, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
June 13, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
June 14, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
June 15, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
June 16, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
June 17, 2026

Facility 12-Month Rolling Operational Limits	
Heat Input mmBtu - 8,128,900	Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
June 18, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
June 19, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
June 20, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
June 21, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
June 22, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
June 23, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
June 24, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
June 25, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
June 26, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
June 27, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
June 28, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
June 29, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Mariposa Energy
Byron California
Facility Daily Operations Report
June 30, 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Hour	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
00	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Daily Total	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00

Attachment 4
Condition AQ-13: Heat Input Report – Daily
Condition AQ-14 Heat Input Limit:
Rolling 12-Month Combined CTG Heat Input Report
and
Condition AQ-15a/b Operating Hour Limits:
Rolling 12-Month Individual and Combined CTG Hours Report

Mariposa Energy
Byron California
Facility Monthly Operations Report
April - 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Day	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	1595.5	6.20	1624.5	6.20	1603.1	6.18	1601.2	6.20	6424.3	24.78
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	340.3	1.31	333.5	1.31	346.4	1.31	330.6	1.31	1350.8	5.24
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
24	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
25	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
26	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
27	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
28	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
29	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
30	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Monthly Total	1935.8	7.5	1958.0	7.5	1949.5	7.5	1931.8	7.5	7775.1	30.02
12-Month Rolling	67487.6	181.3	66393.8	180.7	68274.7	186.2	47723.9	144.9	249880.0	692.7

Mariposa Energy
Byron California
Facility Monthly Operations Report
May - 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Day	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
01	2658.9	9.20	2703.5	9.20	2689.9	9.20	2544.5	9.20	10596.8	36.80
02	2170.1	8.15	2208.4	8.15	2215.4	8.15	2195.4	8.15	8789.3	32.60
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	313.2	1.21	322.6	1.20	305.6	1.21	303.2	1.20	1244.6	4.82
05	1679.4	6.18	1730.7	6.18	1744.0	6.18	1672.2	6.20	6826.3	24.74
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	984.3	2.42	1002.7	2.40	1009.0	2.44	909.8	2.44	3905.8	9.70
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	1331.4	4.20	1355.9	4.20	1355.0	4.20	980.4	2.93	5022.7	15.53
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
24	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
25	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
26	279.2	1.14	282.5	1.14	281.1	1.14	272.9	1.14	1115.7	4.56
27	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
28	390.4	1.17	385.3	1.17	401.0	1.19	364.6	1.19	1541.3	4.72
29	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
30	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
31	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Monthly Total	9806.9	33.7	9991.6	33.6	10001.0	33.7	9243.0	32.5	39042.5	133.47
12-Month Rolling	66755.0	185.6	66920.3	187.9	68337.5	192.0	49273.6	152.6	251286.4	717.7

Mariposa Energy
Byron California
Facility Monthly Operations Report
June - 2026

Facility 12-Month Rolling Operational Limits
Heat Input mmBtu - 8,128,900 Unit Op Hours - 16,900

Day	Unit 600		Unit 700		Unit 800		Unit 900		Facility Totals	
	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours	Heat Input mmBtu	Unit Op Hours
01	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
02	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
03	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
04	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
05	767.9	2.77	443.8	1.70	444.0	1.70	442.5	1.70	2098.2	7.87
06	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
07	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
08	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
09	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
10	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
11	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
12	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
13	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
14	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
15	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
16	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
17	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
18	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
19	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
20	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
21	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
22	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
23	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
24	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
25	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
26	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
27	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
28	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
29	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
30	Down	0.00	Down	0.00	Down	0.00	Down	0.00	Down	0.00
Monthly Total	767.9	2.8	443.8	1.7	444.0	1.7	442.5	1.7	2098.2	7.87
12-Month Rolling	61084.6	170.7	60549.6	169.8	64174.4	180.5	49716.1	154.3	235524.7	674.9

Attachment 5

Condition AQ-16: SCR/Oxidation Catalyst Operation Report

Condition AQ-16: SCR/Oxidation Catalyst Operation Report

Permit to Operate Condition 24955 part 16 (AQ-16) states:

The owner/operator shall ensure that each Gas Turbine (S-1, S-2, S-3, S-4) is abated by the properly operated and properly maintained Selective Catalytic Reduction (SCR) System A-2, A-4, A-6 or A-8 and. Oxidation Catalyst System A-1, A-3, A-5, or A-7 whenever fuel is combusted at those sources and the corresponding SCR catalyst bed (A-2, A-4, A-6 or A-8) has reached minimum operating temperature.

The emission reports presented in Attachments 7, 8, 12, and 13 demonstrate that the gas turbines are operating properly as abated by the Catalytic Reduction (SCR) System A-2, A-4, A-6 or A-8 and Oxidation Catalyst System A-1, A-3, A-5, or A-7 and demonstrate compliance with Condition 24955 parts AQ-17a, 17b, 17c, 17d, 19, and 20.

Demonstration of operation above the minimum catalyst bed temperature is demonstrated by compliance with BAAQMD ATC Condition 24955, parts AQ-17a, 17b, 17c, 17d, 19, and 20.

Attachment 6

Condition AQ-17a/b NO_x Emission Limits:

Hourly Mass Rate and Hourly Average

Concentration Report

Condition AQ-17c/d CO Emission Limits:

Hourly Mass Rate/Rolling 3-Hr Concentration Report

Condition AQ-17e NH₃ Emission Limits:

Rolling 3-Hr Slip Calculation Report

Condition AQ-17f/g Hourly Mass Emission Limits:

POC & SO₂ Report

Mariposa Energy
Byron California
Unit 600 Monthly BAAQMD Emissions Report
April - 2026

NOx ppm @15% O2 (Norm Ops) - 2.5 SO2 lbs (Norm Ops) - 1.35 Hourly Emission Limits NOx lbs (Norm Ops) - 4.4 NOx lbs (SU/SD) - 18.5 CO lbs (Norm Ops) - 2.14 CO lbs (SU/SD) - 17.3 POC lbs (Norm Ops) - 0.61 POC lbs (SU/SD) - 1.4 3-Hour Rolling Emission Limit CO ppm @15% O2 (Norm Ops) - 2.0 NH3 Slip ppm @15% O2 (Norm Ops) - 5										
Day	Max 1-Hr Norm Ops NOx lbs	Max 1-Hr SU/SD NOx lbs	Max 1-Hr Norm Ops NOx ppm @15% O2	Max 1-Hr Norm Ops CO lbs	Max 1-Hr SU/SD CO lbs	Max 3-Hr Rolling Norm Ops CO ppm @15% O2	Max 3-Hr Rolling Norm Ops NH3 Slip ppm @15% O2	Max 1-Hr Norm Ops POC lbs	Max 1-Hr SU/SD POC lbs	Max 1-Hr SO2 lbs
04/01/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/02/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/03/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/04/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/05/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/06/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/07/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/08/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/09/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/10/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/11/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/12/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/13/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/14/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/15/2026	2.2	5.1	2.3	1.0	1.8	1.7	3.2	0.2	0.2	0.4
04/16/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/17/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/18/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/19/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/20/2026	1.0	5.4	1.0	0.5	1.5	1.6	NSD	0.1	0.1	0.3
04/21/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/22/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/23/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/24/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/25/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/26/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/27/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/28/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/29/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/30/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
Monthly Max	2.2	5.4	2.3	1.0	1.8	1.7	3.2	0.2	0.2	0.4

Mariposa Energy
Byron California
Unit 600 Monthly BAAQMD Emissions Report
May - 2026

NOx ppm @15% O2 (Norm Ops) - 2.5 SO2 lbs (Norm Ops) - 1.35 Hourly Emission Limits NOx lbs (Norm Ops) - 4.4 NOx lbs (SU/SD) - 18.5 CO lbs (Norm Ops) - 2.14 CO lbs (SU/SD) - 17.3 POC lbs (Norm Ops) - 0.61 POC lbs (SU/SD) - 1.4 3-Hour Rolling Emission Limit CO ppm @15% O2 (Norm Ops) - 2.0 NH3 Slip ppm @15% O2 (Norm Ops) - 5										
Day	Max 1-Hr Norm Ops NOx lbs	Max 1-Hr SU/SD NOx lbs	Max 1-Hr Norm Ops NOx ppm @15% O2	Max 1-Hr Norm Ops CO lbs	Max 1-Hr SU/SD CO lbs	Max 3-Hr Rolling Norm Ops CO ppm @15% O2	Max 3-Hr Rolling Norm Ops NH3 Slip ppm @15% O2	Max 1-Hr Norm Ops POC lbs	Max 1-Hr SU/SD POC lbs	Max 1-Hr SO2 lbs
05/01/2026	3.2	6.5	2.3	1.5	1.7	1.8	3.3	0.3	0.3	0.5
05/02/2026	2.2	1.0	2.2	1.0	0.1	1.7	3.3	0.2	0.0	0.4
05/03/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/04/2026	1.0	6.8	1.0	0.5	1.0	1.6	NSD	0.1	0.1	0.3
05/05/2026	2.6	4.1	2.3	1.4	1.1	1.7	3.3	0.2	0.2	0.5
05/06/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/07/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/08/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/09/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/10/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/11/2026	3.9	5.5	2.4	1.9	1.4	1.8	2.6	0.3	0.2	0.6
05/12/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/13/2026	3.9	4.0	2.4	1.9	1.9	1.9	3.4	0.3	0.2	0.6
05/14/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/15/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/16/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/17/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/18/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/19/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/20/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/21/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/22/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/23/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/24/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/25/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/26/2026	1.0	6.3	1.0	0.5	1.9	1.8	NSD	0.1	0.1	0.3
05/27/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/28/2026	1.9	6.1	1.2	0.9	2.1	1.8	NSD	0.2	0.2	0.4
05/29/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/30/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/31/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
Monthly Max	3.9	6.8	2.4	1.9	2.1	1.9	3.4	0.3	0.3	0.6

Mariposa Energy
Byron California
Unit 600 Monthly BAAQMD Emissions Report
June - 2026

NOx ppm @15% O2 (Norm Ops) - 2.5 SO2 lbs (Norm Ops) - 1.35 Hourly Emission Limits NOx lbs (Norm Ops) - 4.4 NOx lbs (SU/SD) - 18.5 CO lbs (Norm Ops) - 2.14 CO lbs (SU/SD) - 17.3 POC lbs (Norm Ops) - 0.61 POC lbs (SU/SD) - 1.4 3-Hour Rolling Emission Limit CO ppm @15% O2 (Norm Ops) - 2.0 NH3 Slip ppm @15% O2 (Norm Ops) - 5										
Day	Max 1-Hr Norm Ops NOx lbs	Max 1-Hr SU/SD NOx lbs	Max 1-Hr Norm Ops NOx ppm @15% O2	Max 1-Hr Norm Ops CO lbs	Max 1-Hr SU/SD CO lbs	Max 3-Hr Rolling Norm Ops CO ppm @15% O2	Max 3-Hr Rolling Norm Ops NH3 Slip ppm @15% O2	Max 1-Hr Norm Ops POC lbs	Max 1-Hr SU/SD POC lbs	Max 1-Hr SO2 lbs
06/01/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/02/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/03/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/04/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/05/2026	2.6	4.5	2.2	1.3	2.2	1.9	2.5	0.2	0.1	0.5
06/06/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/07/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/08/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/09/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/10/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/11/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/12/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/13/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/14/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/15/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/16/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/17/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/18/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/19/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/20/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/21/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/22/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/23/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/24/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/25/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/26/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/27/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/28/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/29/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/30/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
Monthly Max	2.6	4.5	2.2	1.3	2.2	1.9	2.5	0.2	0.1	0.5

Mariposa Energy
Byron California
Unit 700 Monthly BAAQMD Emissions Report
April - 2026

NOx ppm @15% O2 (Norm Ops) - 2.5 SO2 lbs (Norm Ops) - 1.35 Hourly Emission Limits NOx lbs (Norm Ops) - 4.4 NOx lbs (SU/SD) - 18.5 CO lbs (Norm Ops) - 2.14 CO lbs (SU/SD) - 17.3 POC lbs (Norm Ops) - 0.61 POC lbs (SU/SD) - 1.4 3-Hour Rolling Emission Limit CO ppm @15% O2 (Norm Ops) - 2.0 NH3 Slip ppm @15% O2 (Norm Ops) - 5										
Day	Max 1-Hr Norm Ops NOx lbs	Max 1-Hr SU/SD NOx lbs	Max 1-Hr Norm Ops NOx ppm @15% O2	Max 1-Hr Norm Ops CO lbs	Max 1-Hr SU/SD CO lbs	Max 3-Hr Rolling Norm Ops CO ppm @15% O2	Max 3-Hr Rolling Norm Ops NH3 Slip ppm @15% O2	Max 1-Hr Norm Ops POC lbs	Max 1-Hr SU/SD POC lbs	Max 1-Hr SO2 lbs
04/01/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/02/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/03/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/04/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/05/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/06/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/07/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/08/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/09/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/10/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/11/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/12/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/13/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/14/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/15/2026	2.2	5.2	2.2	1.1	1.7	1.8	2.5	0.2	0.2	0.2
04/16/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/17/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/18/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/19/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/20/2026	1.2	5.4	1.2	0.6	1.3	1.7	NSD	0.1	0.1	0.1
04/21/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/22/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/23/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/24/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/25/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/26/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/27/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/28/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/29/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/30/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
Monthly Max	2.2	5.4	2.2	1.1	1.7	1.8	2.5	0.2	0.2	0.2

Mariposa Energy
Byron California
Unit 700 Monthly BAAQMD Emissions Report
May - 2026

NOx ppm @15% O2 (Norm Ops) - 2.5 SO2 lbs (Norm Ops) - 1.35 Hourly Emission Limits NOx lbs (Norm Ops) - 4.4 NOx lbs (SU/SD) - 18.5 CO lbs (Norm Ops) - 2.14 CO lbs (SU/SD) - 17.3 POC lbs (Norm Ops) - 0.61 POC lbs (SU/SD) - 1.4 3-Hour Rolling Emission Limit CO ppm @15% O2 (Norm Ops) - 2.0 NH3 Slip ppm @15% O2 (Norm Ops) - 5										
Day	Max 1-Hr Norm Ops NOx lbs	Max 1-Hr SU/SD NOx lbs	Max 1-Hr Norm Ops NOx ppm @15% O2	Max 1-Hr Norm Ops CO lbs	Max 1-Hr SU/SD CO lbs	Max 3-Hr Rolling Norm Ops CO ppm @15% O2	Max 3-Hr Rolling Norm Ops NH3 Slip ppm @15% O2	Max 1-Hr Norm Ops POC lbs	Max 1-Hr SU/SD POC lbs	Max 1-Hr SO2 lbs
05/01/2026	2.6	6.4	2.3	1.5	1.6	1.8	2.8	0.3	0.3	0.2
05/02/2026	2.2	0.8	2.1	1.0	0.1	1.7	2.5	0.2	0.0	0.2
05/03/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/04/2026	1.0	6.8	1.0	0.6	1.1	1.7	NSD	0.2	0.2	0.1
05/05/2026	2.3	4.3	2.2	1.3	1.0	1.8	2.8	0.2	0.2	0.2
05/06/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/07/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/08/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/09/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/10/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/11/2026	3.9	5.6	2.3	1.9	1.5	1.8	2.3	0.3	0.2	0.3
05/12/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/13/2026	3.7	3.9	2.2	1.9	1.5	1.9	3.0	0.3	0.2	0.3
05/14/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/15/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/16/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/17/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/18/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/19/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/20/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/21/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/22/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/23/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/24/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/25/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/26/2026	1.0	5.9	1.0	0.4	1.5	1.9	NSD	0.1	0.1	0.1
05/27/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/28/2026	0.9	6.7	0.6	0.5	2.0	1.8	NSD	0.2	0.2	0.2
05/29/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/30/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/31/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
Monthly Max	3.9	6.8	2.3	1.9	2.0	1.9	3.0	0.3	0.3	0.3

Mariposa Energy
Byron California
Unit 700 Monthly BAAQMD Emissions Report
June - 2026

NOx ppm @15% O2 (Norm Ops) - 2.5 SO2 lbs (Norm Ops) - 1.35 Hourly Emission Limits NOx lbs (Norm Ops) - 4.4 NOx lbs (SU/SD) - 18.5 CO lbs (Norm Ops) - 2.14 CO lbs (SU/SD) - 17.3 POC lbs (Norm Ops) - 0.61 POC lbs (SU/SD) - 1.4 3-Hour Rolling Emission Limit CO ppm @15% O2 (Norm Ops) - 2.0 NH3 Slip ppm @15% O2 (Norm Ops) - 5										
Day	Max 1-Hr Norm Ops NOx lbs	Max 1-Hr SU/SD NOx lbs	Max 1-Hr Norm Ops NOx ppm @15% O2	Max 1-Hr Norm Ops CO lbs	Max 1-Hr SU/SD CO lbs	Max 3-Hr Rolling Norm Ops CO ppm @15% O2	Max 3-Hr Rolling Norm Ops NH3 Slip ppm @15% O2	Max 1-Hr Norm Ops POC lbs	Max 1-Hr SU/SD POC lbs	Max 1-Hr SO2 lbs
06/01/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/02/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/03/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/04/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/05/2026	1.8	4.3	1.8	1.0	2.0	1.8	0.9	0.2	0.2	0.2
06/06/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/07/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/08/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/09/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/10/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/11/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/12/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/13/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/14/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/15/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/16/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/17/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/18/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/19/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/20/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/21/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/22/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/23/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/24/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/25/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/26/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/27/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/28/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/29/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/30/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
Monthly Max	1.8	4.3	1.8	1.0	2.0	1.8	0.9	0.2	0.2	0.2

Mariposa Energy
Byron California
Unit 800 Monthly BAAQMD Emissions Report
April - 2026

NOx ppm @15% O2 (Norm Ops) - 2.5 SO2 lbs (Norm Ops) - 1.35 Hourly Emission Limits NOx lbs (Norm Ops) - 4.4 NOx lbs (SU/SD) - 18.5 CO lbs (Norm Ops) - 2.14 CO lbs (SU/SD) - 17.3 POC lbs (Norm Ops) - 0.61 POC lbs (SU/SD) - 1.4 3-Hour Rolling Emission Limit CO ppm @15% O2 (Norm Ops) - 2.0 NH3 Slip ppm @15% O2 (Norm Ops) - 5										
Day	Max 1-Hr Norm Ops NOx lbs	Max 1-Hr SU/SD NOx lbs	Max 1-Hr Norm Ops NOx ppm @15% O2	Max 1-Hr Norm Ops CO lbs	Max 1-Hr SU/SD CO lbs	Max 3-Hr Rolling Norm Ops CO ppm @15% O2	Max 3-Hr Rolling Norm Ops NH3 Slip ppm @15% O2	Max 1-Hr Norm Ops POC lbs	Max 1-Hr SU/SD POC lbs	Max 1-Hr SO2 lbs
04/01/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/02/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/03/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/04/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/05/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/06/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/07/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/08/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/09/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/10/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/11/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/12/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/13/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/14/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/15/2026	2.2	5.7	2.2	1.1	1.1	1.8	2.0	0.2	0.2	0.2
04/16/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/17/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/18/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/19/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/20/2026	1.0	5.6	0.9	0.5	1.3	1.6	NSD	0.1	0.1	0.1
04/21/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/22/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/23/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/24/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/25/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/26/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/27/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/28/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/29/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/30/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
Monthly Max	2.2	5.7	2.2	1.1	1.3	1.8	2.0	0.2	0.2	0.2

Mariposa Energy
Byron California
Unit 800 Monthly BAAQMD Emissions Report
May - 2026

NOx ppm @15% O2 (Norm Ops) - 2.5 SO2 lbs (Norm Ops) - 1.35 Hourly Emission Limits NOx lbs (Norm Ops) - 4.4 NOx lbs (SU/SD) - 18.5 CO lbs (Norm Ops) - 2.14 CO lbs (SU/SD) - 17.3 POC lbs (Norm Ops) - 0.61 POC lbs (SU/SD) - 1.4 3-Hour Rolling Emission Limit CO ppm @15% O2 (Norm Ops) - 2.0 NH3 Slip ppm @15% O2 (Norm Ops) - 5										
Day	Max 1-Hr Norm Ops NOx lbs	Max 1-Hr SU/SD NOx lbs	Max 1-Hr Norm Ops NOx ppm @15% O2	Max 1-Hr Norm Ops CO lbs	Max 1-Hr SU/SD CO lbs	Max 3-Hr Rolling Norm Ops CO ppm @15% O2	Max 3-Hr Rolling Norm Ops NH3 Slip ppm @15% O2	Max 1-Hr Norm Ops POC lbs	Max 1-Hr SU/SD POC lbs	Max 1-Hr SO2 lbs
05/01/2026	2.5	7.0	2.2	1.4	1.5	1.8	2.1	0.3	0.3	0.2
05/02/2026	2.2	0.8	2.2	1.0	0.1	1.8	2.1	0.2	0.0	0.2
05/03/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/04/2026	1.0	7.4	1.0	0.5	1.0	1.5	NSD	0.2	0.2	0.1
05/05/2026	2.4	5.2	2.2	1.2	1.1	1.7	2.4	0.2	0.2	0.2
05/06/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/07/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/08/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/09/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/10/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/11/2026	1.8	6.4	0.9	0.9	1.5	1.6	Maint	0.3	0.2	0.3
05/12/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/13/2026	3.7	4.9	2.2	1.9	1.9	1.8	2.3	0.3	0.2	0.3
05/14/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/15/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/16/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/17/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/18/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/19/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/20/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/21/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/22/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/23/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/24/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/25/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/26/2026	1.0	6.8	1.0	0.6	2.2	1.8	NSD	0.1	0.1	0.1
05/27/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/28/2026	2.0	7.2	1.2	1.0	2.1	1.8	NSD	0.2	0.2	0.2
05/29/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/30/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/31/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
Monthly Max	3.7	7.4	2.2	1.9	2.2	1.8	2.4	0.3	0.3	0.3

Mariposa Energy
Byron California
Unit 800 Monthly BAAQMD Emissions Report
June - 2026

NOx ppm @15% O2 (Norm Ops) - 2.5 SO2 lbs (Norm Ops) - 1.35 Hourly Emission Limits NOx lbs (Norm Ops) - 4.4 NOx lbs (SU/SD) - 18.5 CO lbs (Norm Ops) - 2.14 CO lbs (SU/SD) - 17.3 POC lbs (Norm Ops) - 0.61 POC lbs (SU/SD) - 1.4 3-Hour Rolling Emission Limit CO ppm @15% O2 (Norm Ops) - 2.0 NH3 Slip ppm @15% O2 (Norm Ops) - 5										
Day	Max 1-Hr Norm Ops NOx lbs	Max 1-Hr SU/SD NOx lbs	Max 1-Hr Norm Ops NOx ppm @15% O2	Max 1-Hr Norm Ops CO lbs	Max 1-Hr SU/SD CO lbs	Max 3-Hr Rolling Norm Ops CO ppm @15% O2	Max 3-Hr Rolling Norm Ops NH3 Slip ppm @15% O2	Max 1-Hr Norm Ops POC lbs	Max 1-Hr SU/SD POC lbs	Max 1-Hr SO2 lbs
06/01/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/02/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/03/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/04/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/05/2026	1.9	5.3	1.9	1.1	2.4	1.8	0.8	0.2	0.1	0.2
06/06/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/07/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/08/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/09/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/10/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/11/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/12/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/13/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/14/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/15/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/16/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/17/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/18/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/19/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/20/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/21/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/22/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/23/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/24/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/25/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/26/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/27/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/28/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/29/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/30/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
Monthly Max	1.9	5.3	1.9	1.1	2.4	1.8	0.8	0.2	0.1	0.2

Mariposa Energy
Byron California
Unit 900 Monthly BAAQMD Emissions Report
April - 2026

NOx ppm @15% O2 (Norm Ops) - 2.5 SO2 lbs (Norm Ops) - 1.35 Hourly Emission Limits NOx lbs (Norm Ops) - 4.4 NOx lbs (SU/SD) - 18.5 CO lbs (Norm Ops) - 2.14 CO lbs (SU/SD) - 17.3 POC lbs (Norm Ops) - 0.61 POC lbs (SU/SD) - 1.4 3-Hour Rolling Emission Limit CO ppm @15% O2 (Norm Ops) - 2.0 NH3 Slip ppm @15% O2 (Norm Ops) - 5										
Day	Max 1-Hr Norm Ops NOx lbs	Max 1-Hr SU/SD NOx lbs	Max 1-Hr Norm Ops NOx ppm @15% O2	Max 1-Hr Norm Ops CO lbs	Max 1-Hr SU/SD CO lbs	Max 3-Hr Rolling Norm Ops CO ppm @15% O2	Max 3-Hr Rolling Norm Ops NH3 Slip ppm @15% O2	Max 1-Hr Norm Ops POC lbs	Max 1-Hr SU/SD POC lbs	Max 1-Hr SO2 lbs
04/01/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/02/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/03/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/04/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/05/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/06/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/07/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/08/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/09/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/10/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/11/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/12/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/13/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/14/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/15/2026	2.2	5.5	2.2	0.2	1.3	0.5	2.4	0.2	0.2	0.2
04/16/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/17/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/18/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/19/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/20/2026	1.0	5.9	1.0	0.1	0.4	0.3	NSD	0.1	0.1	0.1
04/21/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/22/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/23/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/24/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/25/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/26/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/27/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/28/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/29/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
04/30/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
Monthly Max	2.2	5.9	2.2	0.2	1.3	0.5	2.4	0.2	0.2	0.2

Mariposa Energy
Byron California
Unit 900 Monthly BAAQMD Emissions Report
May - 2026

NOx ppm @15% O2 (Norm Ops) - 2.5 SO2 lbs (Norm Ops) - 1.35 Hourly Emission Limits NOx lbs (Norm Ops) - 4.4 NOx lbs (SU/SD) - 18.5 CO lbs (Norm Ops) - 2.14 CO lbs (SU/SD) - 17.3 POC lbs (Norm Ops) - 0.61 POC lbs (SU/SD) - 1.4 3-Hour Rolling Emission Limit CO ppm @15% O2 (Norm Ops) - 2.0 NH3 Slip ppm @15% O2 (Norm Ops) - 5										
Day	Max 1-Hr Norm Ops NOx lbs	Max 1-Hr SU/SD NOx lbs	Max 1-Hr Norm Ops NOx ppm @15% O2	Max 1-Hr Norm Ops CO lbs	Max 1-Hr SU/SD CO lbs	Max 3-Hr Rolling Norm Ops CO ppm @15% O2	Max 3-Hr Rolling Norm Ops NH3 Slip ppm @15% O2	Max 1-Hr Norm Ops POC lbs	Max 1-Hr SU/SD POC lbs	Max 1-Hr SO2 lbs
05/01/2026	2.1	5.2	2.1	0.4	0.5	0.6	2.2	0.2	0.2	0.2
05/02/2026	2.0	1.1	2.0	0.4	0.0	0.6	2.4	0.2	0.0	0.2
05/03/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/04/2026	0.9	6.9	0.9	0.1	0.3	0.5	NSD	0.2	0.2	0.1
05/05/2026	2.1	5.2	2.1	0.4	0.2	0.6	2.8	0.2	0.2	0.2
05/06/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/07/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/08/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/09/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/10/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/11/2026	3.4	4.8	2.3	0.8	0.4	0.7	2.3	0.3	0.2	0.2
05/12/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/13/2026	1.6	4.7	1.7	0.2	0.6	0.8	Maint	0.3	0.2	0.3
05/14/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/15/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/16/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/17/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/18/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/19/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/20/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/21/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/22/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/23/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/24/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/25/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/26/2026	0.9	5.2	0.9	0.1	0.8	0.5	NSD	0.1	0.1	0.1
05/27/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/28/2026	1.4	6.1	1.0	0.3	0.7	0.4	NSD	0.2	0.2	0.2
05/29/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/30/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
05/31/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
Monthly Max	3.4	6.9	2.3	0.8	0.8	0.8	2.8	0.3	0.2	0.3

Mariposa Energy
Byron California
Unit 900 Monthly BAAQMD Emissions Report
June - 2026

NOx ppm @15% O2 (Norm Ops) - 2.5 SO2 lbs (Norm Ops) - 1.35 Hourly Emission Limits NOx lbs (Norm Ops) - 4.4 NOx lbs (SU/SD) - 18.5 CO lbs (Norm Ops) - 2.14 CO lbs (SU/SD) - 17.3 POC lbs (Norm Ops) - 0.61 POC lbs (SU/SD) - 1.4 3-Hour Rolling Emission Limit CO ppm @15% O2 (Norm Ops) - 2.0 NH3 Slip ppm @15% O2 (Norm Ops) - 5										
Day	Max 1-Hr Norm Ops NOx lbs	Max 1-Hr SU/SD NOx lbs	Max 1-Hr Norm Ops NOx ppm @15% O2	Max 1-Hr Norm Ops CO lbs	Max 1-Hr SU/SD CO lbs	Max 3-Hr Rolling Norm Ops CO ppm @15% O2	Max 3-Hr Rolling Norm Ops NH3 Slip ppm @15% O2	Max 1-Hr Norm Ops POC lbs	Max 1-Hr SU/SD POC lbs	Max 1-Hr SO2 lbs
06/01/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/02/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/03/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/04/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/05/2026	1.8	3.7	1.8	0.3	1.3	0.5	1.1	0.2	0.1	0.2
06/06/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/07/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/08/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/09/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/10/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/11/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/12/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/13/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/14/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/15/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/16/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/17/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/18/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/19/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/20/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/21/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/22/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/23/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/24/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/25/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/26/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/27/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/28/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/29/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
06/30/2026	N/A	Down	Down	N/A	Down	N/A	Down	Down	Down	Down
Monthly Max	1.8	3.7	1.8	0.3	1.3	0.5	1.1	0.2	0.1	0.2

Attachment 7

Condition AQ-18 Startup and Shutdown Emission Limits Report

Events

Mariposa Energy
for 4/1/2026 thru 6/30/2026

Limits						
Unit 600: NOx lbs/Startup Event	14.2	Unit 700: CO lbs/Startup Event	14.1	Unit 800: POC lbs/Startup Event	1.1	
Unit 600: NOx lbs/Shutdown Event	3.2	Unit 700: CO lbs/Shutdown Event	2.7	Unit 800: POC lbs/Shutdown Event	0.12	
Unit 600: CO lbs/Startup Event	14.1	Unit 700: POC lbs/Startup Event	1.1	Unit 900: NOx lbs/Startup Event	14.2	
Unit 600: CO lbs/Shutdown Event	2.7	Unit 700: POC lbs/Shutdown Event	0.12	Unit 900: NOx lbs/Shutdown Event	3.2	
Unit 600: POC lbs/Startup Event	1.1	Unit 800: NOx lbs/Startup Event	14.2	Unit 900: CO lbs/Startup Event	14.1	
Unit 600: POC lbs/Shutdown Event	0.12	Unit 800: NOx lbs/Shutdown Event	3.2	Unit 900: CO lbs/Shutdown Event	2.7	
Unit 700: NOx lbs/Startup Event	14.2	Unit 800: CO lbs/Startup Event	14.1	Unit 900: POC lbs/Startup Event	1.1	
Unit 700: NOx lbs/Shutdown Event	3.2	Unit 800: CO lbs/Shutdown Event	2.7	Unit 900: POC lbs/Shutdown Event	0.12	
Parameter	Start	End	Duration	NOx Lbs	CO Lbs	POC Lbs
Unit 700 Startup	4/15/2026 5:57 AM	6:15 AM	0:19	4.69	1.59	0
Unit 600 Startup	4/15/2026 5:58 AM	6:13 AM	0:16	4.59	0.52	0
Unit 800 Startup	4/15/2026 5:58 AM	6:14 AM	0:17	5.07	0.54	0
Unit 900 Startup	4/15/2026 5:58 AM	6:14 AM	0:17	4.97	0.23	0
Unit 600 Shutdown	4/15/2026 12:03 PM	12:08 PM	0:06	0.33	0.06	0
Unit 700 Shutdown	4/15/2026 12:03 PM	12:08 PM	0:06	0.14	0.1	0
Unit 800 Shutdown	4/15/2026 12:03 PM	12:08 PM	0:06	0.37	0.08	0
Unit 900 Shutdown	4/15/2026 12:05 PM	12:08 PM	0:04	0.14	0	0
Unit 600 Startup	4/20/2026 10:19 PM	10:39 PM	0:21	4.6	0.91	0
Unit 700 Startup	4/20/2026 10:19 PM	10:38 PM	0:20	4.57	0.82	0
Unit 800 Startup	4/20/2026 10:19 PM	10:33 PM	0:15	4.67	0.69	0
Unit 900 Startup	4/20/2026 10:19 PM	10:34 PM	0:16	5	0.28	0
Unit 600 Shutdown	4/20/2026 11:24 PM	11:37 PM	0:14	0.94	0.25	0
Unit 800 Shutdown	4/20/2026 11:25 PM	11:37 PM	0:13	0.63	0.26	0.01
Unit 900 Shutdown	4/20/2026 11:30 PM	11:37 PM	0:08	0.78	0	0
Unit 700 Shutdown	4/20/2026 11:32 PM	11:37 PM	0:06	0.58	0.1	0
Unit 600 Startup	5/1/2026 1:58 AM	2:13 AM	0:16	3.55	1.14	0

Parameter	Start	End	Duration	NOx Lbs	CO Lbs	POC Lbs
Unit 700 Startup	5/1/2026 1:58 AM	2:13 AM	0:16	3.55	1.03	0
Unit 800 Startup	5/1/2026 1:58 AM	2:12 AM	0:15	4.57	0.94	0
Unit 900 Startup	5/1/2026 1:58 AM	2:08 AM	0:11	2.91	0.49	0
Unit 600 Shutdown	5/1/2026 9:03 AM	9:08 AM	0:06	0.96	0.06	0
Unit 700 Shutdown	5/1/2026 9:03 AM	9:08 AM	0:06	0.78	0.1	0
Unit 800 Shutdown	5/1/2026 9:03 AM	9:08 AM	0:06	0.75	0.1	0
Unit 900 Shutdown	5/1/2026 9:05 AM	9:08 AM	0:04	0.89	0	0
Unit 600 Startup	5/1/2026 9:59 PM	10:09 PM	0:11	4.2	0.8	0
Unit 700 Startup	5/1/2026 9:59 PM	10:09 PM	0:11	4.29	0.8	0.1
Unit 800 Startup	5/1/2026 9:59 PM	10:09 PM	0:11	4.79	0.74	0.1
Unit 900 Startup	5/1/2026 9:59 PM	10:09 PM	0:11	3.41	0.38	0
Unit 600 Shutdown	5/2/2026 8:03 AM	8:08 AM	0:06	0.85	0.06	0
Unit 700 Shutdown	5/2/2026 8:03 AM	8:08 AM	0:06	0.74	0.12	0
Unit 800 Shutdown	5/2/2026 8:03 AM	8:08 AM	0:06	0.69	0.1	0
Unit 900 Shutdown	5/2/2026 8:05 AM	8:08 AM	0:04	0.94	0	0
Unit 600 Startup	5/4/2026 12:13 PM	12:28 PM	0:16	5.59	0.5	0
Unit 700 Startup	5/4/2026 12:13 PM	12:28 PM	0:16	5.63	0.5	0
Unit 800 Startup	5/4/2026 12:13 PM	12:29 PM	0:17	6.38	0.51	0
Unit 900 Startup	5/4/2026 12:13 PM	12:29 PM	0:17	6.02	0.15	0
Unit 700 Shutdown	5/4/2026 1:11 PM	1:24 PM	0:14	0.31	0.3	0
Unit 600 Shutdown	5/4/2026 1:12 PM	1:25 PM	0:14	0.45	0.23	0
Unit 800 Shutdown	5/4/2026 1:15 PM	1:25 PM	0:11	0.49	0.18	0
Unit 900 Shutdown	5/4/2026 1:22 PM	1:24 PM	0:03	0.14	0	0
Unit 600 Startup	5/5/2026 6:58 AM	7:11 AM	0:14	3.39	0.51	0
Unit 700 Startup	5/5/2026 6:58 AM	7:10 AM	0:13	3.54	0.47	0
Unit 800 Startup	5/5/2026 6:58 AM	7:11 AM	0:14	4.41	0.52	0
Unit 900 Startup	5/5/2026 6:58 AM	7:11 AM	0:14	4.63	0.17	0

Parameter	Start	End	Duration	NOx Lbs	CO Lbs	POC Lbs
Unit 700 Shutdown	5/5/2026 1:03 PM	1:08 PM	0:06	0.17	0.09	0
Unit 800 Shutdown	5/5/2026 1:03 PM	1:08 PM	0:06	0.16	0.09	0
Unit 600 Shutdown	5/5/2026 1:04 PM	1:08 PM	0:05	0.13	0.05	0
Unit 900 Shutdown	5/5/2026 1:06 PM	1:09 PM	0:04	0.57	0	0
Unit 600 Startup	5/11/2026 5:44 PM	5:46 PM	0:03	1.14	0.2	0
Unit 700 Startup	5/11/2026 5:44 PM	5:46 PM	0:03	Down	Down	Down
Unit 800 Startup	5/11/2026 5:44 PM	5:46 PM	0:03	0.94	0.36	0
Unit 900 Startup	5/11/2026 5:44 PM	5:46 PM	0:03	1.03	0.2	0
Unit 600 Startup	5/11/2026 6:17 PM	6:27 PM	0:11	3.29	0.37	0
Unit 700 Startup	5/11/2026 6:17 PM	6:28 PM	0:12	3.4	0.42	0
Unit 800 Startup	5/11/2026 6:17 PM	6:30 PM	0:14	4.09	0.53	0
Unit 900 Startup	5/11/2026 6:17 PM	6:27 PM	0:11	2.84	0.11	0
Unit 600 Shutdown	5/11/2026 8:30 PM	8:38 PM	0:09	0.44	0.14	0
Unit 700 Shutdown	5/11/2026 8:31 PM	8:38 PM	0:08	0.29	0.19	0
Unit 800 Shutdown	5/11/2026 8:31 PM	8:39 PM	0:09	0.45	0.17	0
Unit 900 Shutdown	5/11/2026 8:36 PM	8:39 PM	0:04	0.52	0	0
Unit 600 Startup	5/13/2026 1:57 AM	2:09 AM	0:13	3.2	1.59	0
Unit 700 Startup	5/13/2026 1:57 AM	2:09 AM	0:13	3.15	1.42	0
Unit 900 Startup	5/13/2026 1:57 AM	2:01 AM	0:05	1.28	0.64	0
Unit 800 Startup	5/13/2026 1:58 AM	2:11 AM	0:14	4.07	0.41	0
Unit 900 Startup	5/13/2026 3:18 AM	3:27 AM	0:10	2.94	0.23	0
Unit 600 Shutdown	5/13/2026 6:03 AM	6:08 AM	0:06	0.53	0.06	0
Unit 700 Shutdown	5/13/2026 6:03 AM	6:08 AM	0:06	0.22	0.14	0
Unit 800 Shutdown	5/13/2026 6:03 AM	6:08 AM	0:06	0.09	0.09	0
Unit 900 Shutdown	5/13/2026 6:05 AM	6:08 AM	0:04	0.07	0	0
Unit 600 Startup	5/26/2026 12:14 PM	12:28 PM	0:15	5.06	1.04	0
Unit 700 Startup	5/26/2026 12:14 PM	12:28 PM	0:15	4.75	0.82	0

Parameter	Start	End	Duration	NOx Lbs	CO Lbs	POC Lbs
Unit 800 Startup	5/26/2026 12:14 PM	12:29 PM	0:16	5.52	1.23	0
Unit 900 Startup	5/26/2026 12:14 PM	12:29 PM	0:16	4.04	0.53	0
Unit 600 Shutdown	5/26/2026 1:16 PM	1:21 PM	0:06	0.58	0.06	0
Unit 700 Shutdown	5/26/2026 1:16 PM	1:21 PM	0:06	0.55	0.09	0
Unit 800 Shutdown	5/26/2026 1:16 PM	1:21 PM	0:06	0.46	0.09	0
Unit 900 Shutdown	5/26/2026 1:19 PM	1:21 PM	0:03	0.51	0	0
Unit 600 Startup	5/28/2026 10:14 PM	10:28 PM	0:15	3.63	0.9	0
Unit 700 Startup	5/28/2026 10:14 PM	10:43 PM	0:30	4.81	1.23	0
Unit 800 Startup	5/28/2026 10:14 PM	10:27 PM	0:14	4.63	0.83	0
Unit 900 Startup	5/28/2026 10:14 PM	10:27 PM	0:14	4.33	0.31	0
Unit 600 Shutdown	5/28/2026 11:18 PM	11:23 PM	0:06	0.43	0.1	0
Unit 700 Shutdown	5/28/2026 11:18 PM	11:23 PM	0:06	0.36	0.14	0
Unit 800 Shutdown	5/28/2026 11:19 PM	11:24 PM	0:06	0.48	0.14	0
Unit 900 Shutdown	5/28/2026 11:21 PM	11:24 PM	0:04	0.77	0	0
Unit 600 Startup	6/5/2026 2:25 AM	2:36 AM	0:12	3.47	1.23	0
Unit 700 Startup	6/5/2026 2:25 AM	2:36 AM	0:12	3.41	1.19	0
Unit 800 Startup	6/5/2026 2:25 AM	2:37 AM	0:13	4.47	1.39	0
Unit 900 Startup	6/5/2026 2:25 AM	2:35 AM	0:11	2.79	0.83	0
Unit 700 Shutdown	6/5/2026 3:54 AM	4:06 AM	0:13	0.53	0.24	0
Unit 800 Shutdown	6/5/2026 4:01 AM	4:06 AM	0:06	0.17	0.08	0
Unit 900 Shutdown	6/5/2026 4:03 AM	4:06 AM	0:04	0.29	0	0
Unit 600 Shutdown	6/5/2026 5:01 AM	5:06 AM	0:06	0.22	0.1	0
Unit 600 Startup	6/5/2026 1:18 PM	1:21 PM	0:04	1.24	0.09	0
Total (94 Events)			16:00	213.43	37.49	0.21

Attachment 8

**Condition AQ-19 Daily Emission Limits:
NO_x, CO, POC, SO₂ Emissions Report**

Mariposa Energy
Byron California
Facility Monthly Mass Emissions Report
April - 2026

Facility 12-Month Rolling Emission Limits					
NOx lbs - 1,100	SO2 lbs - 130	NOx tons - 45.6	POC tons - 5.6	Formaldehyde lbs- 3,725.26	
CO lbs - 934	POC lbs - 95	CO tons - 27.2	PM10 tons - 18.6	PAHs lbs - 1.063	
		SO2 tons - 2.9	Benzene lbs - 107.94	SAM tons - 7	

Day	NOx lbs	CO lbs	NH3 Slip lbs	60-SO2 lbs	75-SO2 lbs	POC lbs	PM10 lbs	Benzene lbs	Formaldehyde lbs	PAHs lbs	SAM lbs
01	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
02	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
03	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
04	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
05	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
06	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
07	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
08	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
09	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
10	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
11	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
12	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
13	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
14	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
15	69.73	24.42	21.07	5.15	4.80	4.48	7.38	0.00	0.00	0.0000	4.52
16	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
17	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
18	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
19	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
20	30.64	6.86	4.73	1.09	0.80	0.94	1.56	0.00	0.00	0.0000	0.94
21	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
22	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
23	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
24	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
25	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
26	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
27	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
28	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
29	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
30	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
Monthly Total	100.4	31.3	25.80	6.24	5.60	5.4	8.9	0.00	0.00	0.000	5.46
12-Month Rolling	1.4 tons	0.5 tons	0.5 tons	0.1 tons	0.1 tons	0.1 tons	0.1 tons	0.00 lbs	0.00 lbs	0.000 lbs	0.1 tons

Mariposa Energy
Byron California
Facility Monthly Mass Emissions Report
May - 2026

Facility 12-Month Rolling Emission Limits					
NOx lbs - 1,100	SO2 lbs - 130	NOx tons - 45.6	POC tons - 5.6	Formaldehyde lbs- 3,725.26	
CO lbs - 934	POC lbs - 95	CO tons - 27.2	PM10 tons - 18.6	PAHs lbs - 1.063	
		SO2 tons - 2.9	Benzene lbs - 107.94	SAM tons - 7	

Day	NOx lbs	CO lbs	NH3 Slip lbs	60-SO2 lbs	75-SO2 lbs	POC lbs	PM10 lbs	Benzene lbs	Formaldehyde lbs	PAHs lbs	SAM lbs
01	111.63	39.27	36.96	8.43	7.20	7.43	12.17	0.00	0.00	0.0000	7.40
02	70.48	25.50	28.58	6.95	6.40	6.15	10.10	0.00	0.00	0.0000	6.16
03	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
04	31.69	5.16	4.93	0.99	1.00	0.89	1.45	0.00	0.00	0.0000	0.87
05	66.92	22.09	23.56	5.45	4.80	4.81	7.89	0.00	0.00	0.0000	4.75
06	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
07	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
08	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
09	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
10	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
11	54.08	14.98	15.14	3.11	1.90	2.75	4.51	0.00	0.00	0.0000	2.74
12	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
13	51.63	23.50	16.71	4.09	3.30	3.52	5.79	0.00	0.00	0.0000	3.50
14	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
15	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
16	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
17	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
18	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
19	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
20	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
21	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
22	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
23	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
24	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
25	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
26	29.71	7.59	4.29	0.90	0.80	0.80	1.30	0.00	0.00	0.0000	0.77
27	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
28	33.57	8.94	7.21	1.24	0.80	1.08	1.77	0.00	0.00	0.0000	1.09
29	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
30	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
31	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
Monthly Total 12-Month Rolling	449.7 1.4 tons	147.0 0.5 tons	137.38 0.5 tons	31.16 0.1 tons	26.20 0.1 tons	27.4 0.1 tons	45.0 0.1 tons	0.00 0.00 lbs	0.00 0.00 lbs	0.000 0.000 lbs	27.28 0.1 tons

Mariposa Energy
Byron California
Facility Monthly Mass Emissions Report
June - 2026

Facility 12-Month Rolling Emission Limits					
NOx lbs - 1,100	SO2 lbs - 130	NOx tons - 45.6	POC tons - 5.6	Formaldehyde lbs- 3,725.26	
CO lbs - 934	POC lbs - 95	CO tons - 27.2	PM10 tons - 18.6	PAHs lbs - 1.063	
		SO2 tons - 2.9	Benzene lbs - 107.94	SAM tons - 7	

Day	NOx lbs	CO lbs	NH3 Slip lbs	60-SO2 lbs	75-SO2 lbs	POC lbs	PM10 lbs	Benzene lbs	Formaldehyde lbs	PAHs lbs	SAM lbs
01	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
02	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
03	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
04	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
05	31.00	13.47	7.59	1.88	1.40	1.46	2.44	0.00	0.00	0.0000	1.40
06	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
07	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
08	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
09	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
10	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
11	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
12	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
13	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
14	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
15	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
16	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
17	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
18	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
19	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
20	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
21	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
22	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
23	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
24	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
25	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
26	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
27	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
28	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
29	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
30	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down	Down
Monthly Total 12-Month Rolling	31.0 1.3 tons	13.5 0.5 tons	7.59 0.4 tons	1.88 0.1 tons	1.40 0.1 tons	1.5 0.1 tons	2.4 0.1 tons	0.00 0.00 lbs	0.00 0.00 lbs	0.000 0.000 lbs	1.40 0.1 tons

Attachment 9

**Condition AQ-20 Cumulative Rolling 12-month CTG Emissions:
NO_x, CO, POC, PM₁₀, SO₂ Emissions Report**

And

Condition AQ-31 Sulfuric Acid Emissions Report

Mariposa Energy

Byron California

Facility 12-Month Rolling Report

June 2026 12-Month Rolling

Facility 12-Month Rolling Operational Limits	Facility 12-Month Rolling Emission Limits		
Unit Op Hours - 16,900	NOx tons - 45.6	POC tons - 5.6	Formaldehyde lbs - 3,725.26
Heat Input mmBtu - 8,128,900	CO tons - 27.2	PM10 tons - 18.6	PAHs lbs - 1.063
	SO2 tons - 2.9	Benzene lbs - 107.94	SAM tons - 7

Month	Op Hours	Op Time	12MRT Op Time	Fuel Flow kscf	Heat Input mmBtu	12MRT Heat Input mmBtu	MWH	NOx lbs	CO lbs	75 SO2 lbs	YTM 75 SO2 lbs	60 SO2 lbs	POC lbs	PM10 lbs	Benzene lbs	Formaldehyde lbs	PAHs lbs	SAM lbs	12MRT NOx tons	12MRT CO tons	12MRT SO2 tons	12MRT POC tons	12MRT PM10 tons	12MRT Benzene lbs	12MRT Formaldehyde lbs	12MRT PAHs lbs	12MRT SAM tons	YTM CO2 tons	YTM CO2e Metric Tons
Jul 2025	14	14.43	1486.4	5517.5	5810.1	546163.6	606.9	74.5	27.6	3.50	144.50	5.60	4.1	6.9	0.00	0.00	0.000	3.80	2.9	1.1	0.2	0.2	0.3	0.00	0.00	0.000	0.2	13020.5	11824.3
Aug 2025	104	104.37	1414.9	38486.3	40602.6	510897.3	4161.5	474.8	177.6	26.00	170.50	32.83	28.5	46.7	0.00	0.00	0.000	28.19	2.8	1.1	0.2	0.2	0.3	0.00	0.00	0.000	0.2	15433.4	14015.3
Sep 2025	79	78.78	1313.6	29735.7	31133.4	469692.7	3230.1	343.9	125.3	20.20	190.70	26.04	21.9	36.0	0.00	0.00	0.000	21.22	2.6	1.0	0.2	0.2	0.3	0.00	0.00	0.000	0.2	17283.7	15695.5
Oct 2025	0	0.34	1057.3	27.7	29.0	366652.0	0.1	5.7	4.3	0.00	190.70	0.02	0.0	0.0	0.00	0.00	0.000	0.03	2.1	0.8	0.2	0.1	0.2	0.00	0.00	0.000	0.1	17285.4	15697.0
Nov 2025	24	24.07	928.3	8142.0	8540.7	322399.8	866.2	115.0	34.4	5.50	196.20	6.58	6.0	9.8	0.00	0.00	0.000	6.18	1.9	0.7	0.1	0.1	0.2	0.00	0.00	0.000	0.1	17793.0	16157.9
Dec 2025	3	3.06	847.2	763.3	802.1	300202.6	76.0	12.3	3.8	0.50	196.70	0.48	0.6	0.9	0.00	0.00	0.000	0.55	1.7	0.6	0.1	0.1	0.2	0.00	0.00	0.000	0.1	17840.7	16201.3
Jan 2026	101	100.76	871.7	41018.6	43356.5	321441.5	4590.9	450.5	168.5	27.50	27.50	35.03	30.4	50.0	0.00	0.00	0.000	30.30	1.8	0.7	0.1	0.1	0.2	0.00	0.00	0.000	0.1	2576.9	2340.2
Feb 2026	27	27.05	601.0	8386.2	8830.3	221033.2	893.0	116.6	36.5	5.20	32.70	7.29	6.2	10.2	0.00	0.00	0.000	6.12	1.3	0.5	0.1	0.1	0.1	0.00	0.00	0.000	0.1	3102.2	2817.3
Mar 2026	151	150.70	713.0	45328.4	47504.2	257893.6	4763.0	494.0	173.9	29.60	62.30	37.13	33.4	55.0	0.00	0.00	0.000	33.88	1.5	0.5	0.1	0.1	0.1	0.00	0.00	0.000	0.1	5925.9	5381.5
Apr 2026	30	30.02	692.7	7461.9	7775.1	249880.0	731.8	100.4	31.3	5.60	67.90	6.24	5.4	8.9	0.00	0.00	0.000	5.46	1.4	0.5	0.1	0.1	0.1	0.00	0.00	0.000	0.1	6387.8	5801.0
May 2026	133	133.47	717.7	37433.8	39042.5	251286.4	3788.8	449.7	147.0	26.20	94.10	31.16	27.4	45.0	0.00	0.00	0.000	27.28	1.4	0.5	0.1	0.1	0.1	0.00	0.00	0.000	0.1	8708.0	7908.2
Jun 2026	8	7.87	674.9	1998.2	2098.2	235524.7	196.4	31.0	13.5	1.40	95.50	1.88	1.5	2.4	0.00	0.00	0.000	1.40	1.3	0.5	0.1	0.1	0.1	0.00	0.00	0.000	0.1	8832.7	8021.5

Attachment 10

Exceedances / Violations

Attachment 10

Mariposa Energy has had no exceedances or violations during Q2 2026.

On March 9, 2026, during a visit by the Bay Area Air District (BAAD) to observe 2026 RATA/Source testing, Mariposa was informed of a pending NOV due to failure to meet the fuel sulfur content limit during the 2025 Unit 800 RATA conducted on February 20, 2025. At this time Mariposa was requested to submit a deviation report regarding the event. See attached deviation report submitted March 17, 2026

On April 9, 2026, Mariposa Energy, LLC was issued NOV A63623 citing failure to meet fuel sulfur content and SO₂ limits, permit conditions 24955.11 and 24955.17g respectively, on February 20, 2025, during the Unit 800 RATA testing (BAAD ID# NST-10130). See attached NOV A63623 and Mariposa 10-day response letter dated April 17, 2026.

Permit Condition 24955.11 states:

The owner/operator shall fire the Gas Turbines (S-1, S-2, S-3, and S-4) exclusively on PUC-regulated natural gas with a maximum sulfur content of 1 grain per 100 standard cubic feet. To demonstrate compliance with this limit, the operator of S-1, S-2, S-3 and S-4 shall sample and analyze the gas from each supply source at least monthly to determine the sulfur content of the gas. PG&E monthly sulfur data may be used provided that such data can be demonstrated to be representative of the gas delivered to the MEP. (Basis: BACT for SO₂ and PM₁₀)

Permit Condition 24955.17g states:

Sulfur dioxide (SO₂) mass emissions at each exhaust point P-1, P-2, P-3, and P-4 shall not exceed 1.35 pounds per hour. (Basis: BACT for SO₂)
(Basis: Regulation 2, Rule 2, Section 419)



Mariposa

Energy Project

March 17, 2026

Compliance and Enforcement
Bay Area Air Quality Management District
375 Beale Street Suite 600
San Francisco, CA 94105
Attn: Title V Reports

Subject: Mariposa Energy, LLC, Facility (B9730) – “10 and 30-Day Deviation Report for Emissions Deviation at Source # 3 (S-3)”

To Whom It May Concern:

This letter provides information consistent with the 10- and 30-day deviation reporting contemplated by Permit Condition #24955.33 . . .” for the event described below.

DEVIATION INFORMATION

1. **Permit Number of emission unit or control affected:** Permit Condition #11
2. **Deviation:** Fuel sample testing results, from samples collected at S-3 during RATA Testing, reflected sulfur content greater than 1 grain per 100 standard cubic feet
3. **Associated equipment and/or operation (if any):** S-1, S-2, S-3, and S-4
4. **Description and identification of permit condition(s) and/or applicable requirements deviated:**
The owner/operator shall fire the Gas Turbines (S-1, S-2, S-3, and S-4) exclusively on PUC-regulated natural gas with a maximum sulfur content of 1 grain per 100 standard cubic feet. To demonstrate compliance with this limit, the operator of S-1, S-2, S-3, and S-4 shall sample and analyze the gas from each supply source at least monthly to determine the sulfur content of the gas. PG&E monthly sulfur data may be used provided that such data can be demonstrated to be representative of the gas delivered to the MEP. (Basis: BACT for SO₂ and PM₁₀)
5. **Date when deviation was discovered:** MEP was notified in a phone call and email by Kevin Crosby of Montrose on 3/11/2025 that the analysis of the fuel sample taken from unit 800 (S-3) on 2/20/2025 reflected a high sulfur content.
6. **Date of deviation (Note date deviation was corrected or that deviation has not been corrected)**
February 20, 2025



Mariposa

Energy Project

7. **Probable cause(s) of deviation:** Sample container contamination, lab contamination or other issues during sample analysis, or gas supply line contamination from gas supply company (PG&E).
8. **Preventative or corrective action taken:** Retest of sample that demonstrated the sulfur content was less than 1 grain per 100 standard cubic feet. The cause of the outlier sulfur test result is unknown. It could have been the result of a contamination of the sample containers, or a contamination at testing lab during sample analysis or some other analysis issue. The facility also confirmed that the pipeline quality natural gas provided to the Mariposa Energy facility from PG&E had a sulfur content of less than 1 grain per 100 scf.

Summary and actions taken during and after event.

On Monday, March 9, 2026, Lily Law, Jose Orozco, and Kristopher Huckabay were on-site to observe the 2026 RATA/Source testing at Mariposa Energy, LLC. Lily and Jose remained on-site for approximately two hours observing the testing. Before leaving the site, Lily asked about the high sulfur result from the S-3 fuel sample collected during the 2025 RATA/Source test and whether an explanation of what may have occurred has been identified. Jason Smith explained that the outlier result was not replicated and that while no conclusive explanation had been identified, he believed the result reflected either an issue during the sampling process or during the analysis process that produced an erroneously high test result. Consistent with further discussions with the District, the facility is submitting this deviation report.

Mariposa Energy, LLC (Mariposa), conducted their annual RATA/Source testing on S-1 on February 28, 2025, S-2 on February 26, 2025, S-3 on February 20, 2025, S-4 on February 24, 2025, and subsequent S-3 retest on April 10, 2025.

During the Annual/Biennial Source Testing for each unit, a gas sample is taken at the “common” main gas supply header to determine the elements in the gas supply from the gas provided to each source. Mariposa has no control over the sulfur content of this gas supply, but the specification from PG&E is for less than [0.5 grains per 100 scf].

S-1 gas inlet sample was taken on February 28, 2025, and analyzed on March 06, 2025. S-2 gas inlet sample was taken on February 26, 2025, and analyzed on February 28, 2025. S-3 gas inlet sample was taken on February 20, 2025, and analyzed on February 26, 2025. S-4 gas inlet sample was taken on February 24, 2025, and analyzed on February 27, 2025.

On March 11, 2025, Mariposa received the S-3 gas sample test results and observed the sulfur results showed the sulfur exceeded 1 grain per 100 standard cubic feet.

Mariposa discussed the S-3 sulfur test results with the source testing company and the testing lab to confirm the sulfur results. The group determined that because the facility’s main gas supply to all sources is common, and each source sample had been collected within days of each other, that the most likely scenarios were that



Mariposa

Energy Project

either the; 1) main gas supplier provided contaminated gas, 2) the sampling container was contaminated, 3) or the lab contaminated the sample during the analysis process. At this time, Mariposa contacted the Source Testing company to retest the main gas on S-3 at the earliest available time, which was conducted on April 10, 2025.

On April 10, 2025, S-3 was brought online, and a gas supply sample was taken and analyzed on April 14, 2025. The results demonstrated that the sulfur content was less than 1 grain per 100 standard cubic feet and that the initial gas test was an outlier result.

The RATA/Source Test report for S-3 was provided to the BAAQMD and the CEC April 24, 2025, and identified the initial and subsequent gas supply tests.

Additionally, the PG&E Pipe Ranger on-line monitoring program also did not demonstrate out-of-limits sulfur content. PG&E results are posted quarterly.

Note: PG&E gas supply limits to Mariposa are 0.5 grains per 100 standard cubic feet.

In closing, Mariposa believes that the supporting evidence of conducting the exact same tests on S-1, S-2, S-3, S-4, and the retest of S-3 on April 10, 2025 demonstrates that the initial gas supply test (from a common main gas supply header) could not have had a sulfur content exceeding 1 grain per 100 standard cubic feet.

If you have any questions or concerns regarding this submittal, please contact Jason Smith at j.smith@dgc-ops.com or (209) 694 6628 or Wayne Forsyth at w.forsyth@dgc-us.com or (213) 473-0093.

Sincerely,

Jason Smith
Jason Smith
EH&S Coordinator
Mariposa Energy, LLC



BAY AREA AIR QUALITY MANAGEMENT DISTRICT
375 Beale Street, Suite 600, San Francisco, CA 94105
(415) 749-5000

NOTICE OF VIOLATION

No. **A63623**

ISSUED TO: Mariposa Energy, LLC ☒ P ☐ G ☐ N# 19730
ADDRESS: 633 W Fifth St #2700
CITY: Los Angeles STATE: CA ZIP: 90071
PHONE: (209) 694-6628
☐ N# Mailing Address on F61

OCCURRENCE
NAME: Mariposa Energy, LLC
ADDRESS: 4887 Bruns Road ☐ Same As Above
CITY: Byron ZIP: 94514
SOURCE: S# 3 NAME: GE LM6000 PC-SPRINT Combustion Turbine
EMISSION PT: P# NAME:
DATE: 2/20/2025 TIME: HRS

☐ REG 2 RULE 1 SEC 301 No Authority to Construct	☐ REG 2 RULE 1 SEC 302 No Permit to Operate
☐ REG 1 SEC 301 H & S CODE - 41700 Public Nuisance	☒ REG 2 RULE <u>6</u> SEC 307 Failure to Meet Permit Condition
☐ REG 5 SEC 301 Prohibited Open Burning	☐ REG 6 RULE 1 SEC 301 Excessive Visible Emissions
☐ REG <u> </u> RULE <u> </u> SECTION <u> </u> CODE <u> </u>	
☐ REG <u> </u> RULE <u> </u> SECTION <u> </u> CODE <u> </u>	

Details: Failure to meet fuel sulfur content and SO2 limits in NST-10130, per permit condition 24955.11 and 24955.17g

RECIPIENT NAME: Jason Smith
TITLE: EHS Coordinator

SIGNING THIS NOTICE IS NOT
AN ADMISSION OF GUILT X [Signature] 4/17/26

→ WITHIN 10 DAYS, RETURN A COPY OF THIS NOTICE WITH A WRITTEN DESCRIPTION OF THE IMMEDIATE CORRECTIVE ACTION YOU HAVE TAKEN TO PREVENT CONTINUED OR RECURRENT VIOLATION. **THIS VIOLATION IS SUBJECT TO SUBSTANTIAL PENALTY.** YOUR RESPONSE DOES NOT PRECLUDE FURTHER LEGAL ACTION.

ISSUED BY: Lily Law INSP # 919
DATE: 4/9/2026 TIME: 11:35 HRS ☒ MAILED

PLEASE PRESS HARD

Sent Via E-mail

Continued On Reverse

INSTRUCTIONS

PERMIT VIOLATIONS - (REG 2, RULE 1, SECTION 301 AND/OR 302)

Within 30 days, a permit application must be submitted to the District's Permit Division. The permit application must reference the Violation Notice Number Shown on the front of this notice. If either the Violation Notice Number is not referenced or no permit application is received, then this matter will be referred to the District's Legal Department for legal action. Your response does not preclude further legal action.

If there are any questions regarding the submission of a Permit Application, call the Permit Services Division at (415) 749-4990.

ALL OTHER VIOLATIONS

Within 10 days, return a copy of this notice with a written description of the corrective action you have taken to prevent continued or recurrent violation. Immediate corrective action must be taken to stop the violation. This violation is subject to substantial penalty. Your response does not preclude further legal action.

A variance should be sought if it is necessary to continue to operate in violation of District Regulations. For information on eligibility for, or filing of, a variance, call (415) 749-5073.



Mariposa

Energy Project

April 17, 2026

Compliance and Enforcement
Bay Area Air District
375 Beale Street Suite 600
San Francisco, CA 94105
Attn: Ms. Law

Subject: Mariposa Energy, LLC, Facility (B9730) – Response to NOV A63623

Dear Ms. Law and Board Compliance and Enforcement Staff:

On behalf of Mariposa Energy, LLC (MEP), located at 4887 Bruns Road, Byron, CA, MEP submits this 10-day response letter (letter) to the above-referenced Notice of Violation A63623 (NOV) issued on April 9, 2026 (copy enclosed).

As mentioned in MEP's prior March 17, 2026 deviation report, (copy enclosed), and further described in this letter, the alleged permit exceedance that is the basis for the NOV was the result of a sampling container, sampling handling or analytical error and not an actual exceedance of the sulfur content identified in permit condition #11 of 1 grain/100 scf. Below, we describe additional actions taken to address the sampling result, including an explanation of why the sampling result should not be considered a deviation or violation of the permit condition.

CORRECTIVE ACTION TAKEN TO PREVENT CONTINUED OR RECURRENT VIOLATION

As discussed in the deviation report, MEP determined that the reported sample result indicating the PUC-regulated natural gas supply from PG&E exceeded 1 grain/100 scf was not representative of the actual gas quality and is considered an outlier. This determination is substantiated by three additional samples collected from the same inlet gas header supplying all MEP units during the same timeframe, which did not indicate similar results. Those results support a reasonable conclusion that contamination likely occurred during the original gas sampling and/or testing process.

To further evaluate the anomalous sulfur result, the Facility arranged for a subsequent gas sample to be collected and analyzed under comparable unit operating conditions. The results of this retest demonstrate that the sulfur content of the PG&E PUC-regulated inlet natural gas was below the permit limit of 1 grain /100 scf.

In addition, MEP confirmed that the pipeline-quality natural gas supplied by PG&E is regulated by the CPUC and is required to meet a total sulfur content specification of less than 1 grain /100 scf. MEP also reviewed PG&E "Pipe



Mariposa

Energy Project

Ranger” monthly sulfur content data, which indicated that sulfur levels during the relevant timeframe were within applicable air permit limits.

The cause of the outlier sulfur test result is unknown, but as detailed in the enclosed deviation letter there are multiple lines of evidence that the sulfur levels in the inlet gas were not in exceedance of the permit condition at the time and, therefore, not subject to recurrence.

It should also be noted that the Facility does not have the ability to control or influence the quality of the natural gas supply, including the sulfur content of the gas provided by PG&E.

THE SAMPLING RESULT WAS AN OUTLIER THAT SHOULD NOT HAVE RESULTED IN THE ISSUANCE OF AN NOV

As noted, MEP has multiple bases for its determination that the sample result reflecting sulfur in the inlet gas in excess of 1 grain/100 scf was not accurate.

First, the RATA/Source testing on the four units at the Facility in February 2025 involved taking a gas sample from the main gas supply header which is common to all four units. Three (3) of the four (4) samples taken from this header reflected sulfur levels that were typical of historical sulfur levels and well below 1 grain/100 scf.

Second, the retest of the inlet gas to the unit associated with the outlier sample, conducted under similar operating conditions, demonstrate that the sulfur content was well below 1 grain / 100 scf and consistent with the other testing of pipeline-quality natural gas.

Third, the inlet gas provided by PG&E is subject to regulation by the CPUC and is required to have less than 1 grain /100 scf of total sulfur. Compliant levels in the pipeline gas can be confirmed using PG&E’s on-line monitoring program which reflects that the sulfur content during the relevant time period (and after) were below 1 grain / 100 scf.

Fourth, the facility has been in operation since 2012 and has never recorded a sulfur test resulting in a content above 1 grain / 100 scf.

Finally, we note that the permit conditions contemplate that the Facility procures the gas from PG&E and that PG&E provide gas with a sulfur content that is less than or equal to 1 grain/100 scf.

Therefore, MEP believes that the subsequent unit testing and other evidence demonstrates that the gas supply testing that was reported with the outlier sulfur level did not have an actual sulfur content exceeding 1 grain / 100 scf and thus there was no violation of the permit conditions cited in the NOV. In light of these facts, MEP respectfully requests that the District reconsider the issuance of the NOV and/or notify MEP that the NOV has been withdrawn.



Mariposa

Energy Project

If you have any questions or concerns regarding this response, please contact Jason Smith at j.smith@dgc-ops.com or (209) 694 6628 or Wayne Forsyth at w.forsyth@dgc-us.com or (213) 473-0093.

A handwritten signature in black ink, appearing to read 'Jason Smith', with a stylized flourish at the end.

Jason Smith
EH&S Coordinator
Mariposa Energy, LLC

Attachment 11

**Condition AQ-38 40 CFR Part 72.9(c)(1) SO₂ Allowances
And 40 CFR Part 75 CEM Requirements Report**

✓ Draft Compliance has executed.

- Mariposa Energy Project (057483FACLT)

Compliance Accounts

☐	Account Number	Account Name	State	Allowances Held	Total User Specified Allowances for Deduction (optional)	Emissions (tons)	Excess Emissions	Compliance Status	Compliance Run Date	Last Updated By	Last Updated Date
☐	057483FACLT	Mariposa Energy Project	CA	2	0	0	0	Draft	02/10/2026 01:05:38 PM	Forsyth, Wayne	02/10/2026 01:05:38 PM

Showing 1 to 1 of 1 entries

First page

Previous page

1

Next page

Last page

Download Report (CSV)

Why can't I run final compliance?

Run Draft Compliance

Attachment 12

**Conditions AQ-39, AQ-40
S-6 Emergency Fire Pump Operation Report
(BAAQMD Condition 24955, parts 1 & 2)**

Conditions AQ-39 and AQ-40, S-6 Emergency Standby Diesel Fire Pump Engine Operation Report

S-6 Diesel Fire Pump Driver Operation Log

Engine Model: JU6H-UFADM8 (Clark Fire Pump Engine Model Designation)
6068HFC28A,B,C (John Deere Engine Model Designation)

Year: 2011 Model Year EPA Engine Family: BJDXL06.8120

Size: 175 BHP Fuel Type: CARB Diesel

Facility: Mariposa Energy Center, BAAQMD Plant 19730 (B9730)

Source No: 6

Location: Diesel Fire Pump Room, Mariposa Energy

Summary					
Year	Months	Stop Timer Reading	Start Timer Reading	Total Actual Maintenance and Testing Hours	12-Month Running Total Hours
2025	April	331.2	329.2	2.0	27.6
2025	May	333.2	331.2	2.0	27.6
2025	June	335.2	333.2	2.0	27.1
2025	July	337.7	335.7	2.0	27.1
2025	August	340.1	337.7	2.4	27.5
2025	September	342.7	340.1	2.6	28.1
2025	October	344.8	342.7	2.1	27.0
2025	November	346.8	344.8	2.0	27.0
2025	December	349.3	346.8	2.5	27.0
2026	January	351.3	349.3	2.0	27.0
2026	February	353.8	351.3	2.5	27.1
2026	March	356.3	353.8	2.5	27.1
2026	April	358.5	356.3	2.2	27.3
2026	May	360.8	358.5	2.3	27.6
2026	June	363.3	360.8	2.5	28.1

Attachment 13

Conditions AQ-39, AQ-40

**Condition AQ-41 S-6 Emergency Fire Pump Totalizing Meter Report (BAAQMD
Condition 22850, part 3)**

Attachment 13
S-6 Emergency Fire Pump Totalizing Meter Report

To demonstrate compliance with CEC Condition AQ-41 (BAAQMD Condition 22850, Part 3), the following photographs are provided as evidence of compliance.



S-6 Emergency Fire Pump



S-6 Control Unit



S-6 Controller, Showing Fire Pump Operating Hours



S-6 Fire Pump Engine Hours