DOCKETED	
Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	271648
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q2 2026 - Part 3s
Description:	N/A
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public Agency
Submission Date:	7/27/2026 2:13:28 PM
Docketed Date:	7/27/2026

Replace the dates with the ones you need

4/1/2026 0:00
6/30/2026 0:00

1D

TOWER AVG.

	519-AIT-9504-1
4/1/26 0:00	1776.2
4/2/26 0:00	2030.0
4/3/26 0:00	1895.1
4/4/26 0:00	1921.5
4/5/26 0:00	1935.3
4/6/26 0:00	2173.3
4/7/26 0:00	2229.2
4/8/26 0:00	2245.8
4/9/26 0:00	2373.0
4/10/26 0:00	2300.6
4/11/26 0:00	2265.1
4/12/26 0:00	2041.7
4/13/26 0:00	2055.3
4/14/26 0:00	2067.4
4/15/26 0:00	2376.2
4/16/26 0:00	2267.3
4/17/26 0:00	2970.5
4/18/26 0:00	3591.3
4/19/26 0:00	4491.0
4/20/26 0:00	5300.4
4/21/26 0:00	5136.8
4/22/26 0:00	4981.8
4/23/26 0:00	3555.9
4/24/26 0:00	3326.7
4/25/26 0:00	3180.0
4/26/26 0:00	3076.8
4/27/26 0:00	2983.3
4/28/26 0:00	2909.2
4/29/26 0:00	2855.1
4/30/26 0:00	2791.7
5/1/26 0:00	2758.1
5/2/26 0:00	2607.4
5/3/26 0:00	2602.1
5/4/26 0:00	2586.5
5/5/26 0:00	2503.8
5/6/26 0:00	2480.1
5/7/26 0:00	2452.3
5/8/26 0:00	2296.1
5/9/26 0:00	2568.7
5/10/26 0:00	2680.5
5/11/26 0:00	2885.7
5/12/26 0:00	2619.2
5/13/26 0:00	2773.7
5/14/26 0:00	2794.5
5/15/26 0:00	2871.0
5/16/26 0:00	2581.4
5/17/26 0:00	2576.0
5/18/26 0:00	2585.7
5/19/26 0:00	2280.4

3528

5/20/26 0:00	2803.9
5/21/26 0:00	3165.6
5/22/26 0:00	3227.1
5/23/26 0:00	3619.7
5/24/26 0:00	3436.4
5/25/26 0:00	3430.1
5/26/26 0:00	3760.4
5/27/26 0:00	3600.7
5/28/26 0:00	3634.4
5/29/26 0:00	3963.3
5/30/26 0:00	3918.4
5/31/26 0:00	4021.2
6/1/26 0:00	4429.7
6/2/26 0:00	4165.3
6/3/26 0:00	4200.1
6/4/26 0:00	4131.2
6/5/26 0:00	4326.9
6/6/26 0:00	4217.5
6/7/26 0:00	4668.1
6/8/26 0:00	4354.2
6/9/26 0:00	4541.8
6/10/26 0:00	4541.3
6/11/26 0:00	4402.1
6/12/26 0:00	5224.8
6/13/26 0:00	4995.1
6/14/26 0:00	5934.0
6/15/26 0:00	5817.2
6/16/26 0:00	5673.7
6/17/26 0:00	5907.1
6/18/26 0:00	5425.4
6/19/26 0:00	5607.8
6/20/26 0:00	5094.3
6/21/26 0:00	5638.2
6/22/26 0:00	4706.1
6/23/26 0:00	4784.0
6/24/26 0:00	4827.5
6/25/26 0:00	4504.8
6/26/26 0:00	4398.3
6/27/26 0:00	4515.5
6/28/26 0:00	4202.2
6/29/26 0:00	4303.7
6/30/26 0:00	4365.4

ROSEVILLE ENERGY PARK COOLING TOWER EMISSIONS

POLLUTANT	LBS PER DAY	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4
PM-10	16.3	1471	1487	1504	1504

Whereas compliance with the PM-10 emission limit shall be demonstrated as;
Cooling tower recirculation rate * total dissolved solids of blowdown * design drift rate

	53814	Gallons per minute
	* 8.33	Pounds per gallon
	* 1440	Minutes per day
Circ pump flow rate	**64,550,969**	Pounds per day

	3528	Average daily conductivity umhos
	0.00000064	Conversion to TDS ppm
Total dissolved solids	**0.00225792**	

Design drift rate	**0.005%**
PM-10 pounds per day	**7.29**
	91 Days in quarter
PM-10 pounds this quarter	**663**

2Q26

fill only these

Monthly Summary By Day Report

Units CT1 and CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/01/2026 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
04/01/2026	60.13	22.83	1.20	2.41	4.02
04/02/2026	0.00	0.00	0.00	0.00	0.00
04/03/2026	0.00	0.00	0.00	0.00	0.00
04/04/2026	0.00	0.00	0.00	0.00	0.00
04/05/2026	0.00	0.00	0.00	0.00	0.00
04/06/2026	0.00	0.00	0.00	0.00	0.00
04/07/2026	0.00	0.00	0.00	0.00	0.00
04/08/2026	72.41	31.37	1.96	3.98	6.59
04/09/2026	68.92	23.99	1.30	2.59	4.33
04/10/2026	0.00	0.00	0.00	0.00	0.00
04/11/2026	0.00	0.00	0.00	0.00	0.00
04/12/2026	0.00	0.00	0.00	0.00	0.00
04/13/2026	0.00	0.00	0.00	0.00	0.00
04/14/2026	153.06	54.38	3.19	6.37	10.61
04/15/2026	33.77	12.81	0.33	0.67	1.12
04/16/2026	159.26	100.59	8.12	16.22	27.08
04/17/2026	37.97	126.24	13.59	27.13	45.14
04/18/2026	38.46	125.04	13.43	26.81	44.65
04/19/2026	37.39	127.24	13.68	27.36	45.54
04/20/2026	84.12	123.21	13.06	26.08	43.38
04/21/2026	0.00	0.00	0.00	0.00	0.00
04/22/2026	0.00	0.00	0.00	0.00	0.00
04/23/2026	0.00	0.00	0.00	0.00	0.00
04/24/2026	0.00	0.00	0.00	0.00	0.00
04/25/2026	0.00	0.00	0.00	0.00	0.00
04/26/2026	0.00	0.00	0.00	0.00	0.00
04/27/2026	0.00	0.00	0.00	0.00	0.00
04/28/2026	0.00	0.00	0.00	0.00	0.00
04/29/2026	0.00	0.00	0.00	0.00	0.00
04/30/2026	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum:	745.49 sum	747.70 sum	69.86 sum	139.62 sum	232.46 sum
Daily Min:	0.00	0.00	0.00	0.00	0.00
Daily Max:	159.26	127.24	13.68	27.36	45.54
Apr 2026 - Apr 2026	745.49 sum	747.70 sum	69.86 sum	139.62 sum	232.46 sum
QTD:	745.49 sum	747.70 sum	69.86 sum	139.62 sum	232.46 sum
YTD 2026:	1,588.31 sum	1,232.85 sum	98.34 sum	193.29 sum	327.80 sum

Monthly Summary By Day Report

Units CT1 and CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/01/2026 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
05/01/2026	0.00	0.00	0.00	0.00	0.00
05/02/2026	0.00	0.00	0.00	0.00	0.00
05/03/2026	0.00	0.00	0.00	0.00	0.00
05/04/2026	0.00	0.00	0.00	0.00	0.00
05/05/2026	0.00	0.00	0.00	0.00	0.00
05/06/2026	0.00	0.00	0.00	0.00	0.00
05/07/2026	0.00	0.00	0.00	0.00	0.00
05/08/2026	121.00	54.18	3.30	6.55	10.95
05/09/2026	54.94	23.96	1.42	2.86	4.74
05/10/2026	49.92	27.61	1.74	3.50	5.81
05/11/2026	78.26	31.35	2.00	4.02	6.70
05/12/2026	155.40	76.43	5.44	10.87	18.13
05/13/2026	3.77	8.64	0.62	1.25	2.11
05/14/2026	0.00	0.00	0.00	0.00	0.00
05/15/2026	140.03	70.26	5.04	10.07	16.80
05/16/2026	0.00	0.00	0.00	0.00	0.00
05/17/2026	0.00	0.00	0.00	0.00	0.00
05/18/2026	48.03	15.84	0.27	0.54	0.90
05/19/2026	100.59	73.72	6.35	12.76	21.20
05/20/2026	18.03	64.32	6.23	12.38	20.83
05/21/2026	17.08	61.41	6.40	12.58	21.26
05/22/2026	13.11	48.41	5.25	10.38	17.34
05/23/2026	94.70	72.76	6.65	13.24	22.03
05/24/2026	17.39	51.18	5.52	11.01	18.31
05/25/2026	17.65	50.89	5.52	10.93	18.25
05/26/2026	17.20	48.29	5.66	11.25	18.75
05/27/2026	79.52	70.02	6.51	12.89	21.52
05/28/2026	113.74	81.63	7.55	15.13	25.13
05/29/2026	15.62	51.46	5.52	11.04	18.26
05/30/2026	15.64	51.37	5.52	10.99	18.25
05/31/2026	15.59	50.82	5.52	10.91	18.18
Monthly Avg/Sum:	1,187.21 sum	1,084.55 sum	98.03 sum	195.15 sum	325.45 sum
Daily Min:	0.00	0.00	0.00	0.00	0.00
Daily Max:	155.40	81.63	7.55	15.13	25.13
Apr 2026 - May 2026	1,932.70 sum	1,832.25 sum	167.89 sum	334.77 sum	557.91 sum
QTD:	1,932.70 sum	1,832.25 sum	167.89 sum	334.77 sum	557.91 sum
YTD 2026:	2,775.52 sum	2,317.40 sum	196.37 sum	388.44 sum	653.25 sum

Monthly Summary By Day Report

Units CT1 and CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/01/2026 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
06/01/2026	15.70	51.18	5.62	11.08	18.49
06/02/2026	15.91	52.38	5.67	11.21	18.73
06/03/2026	90.32	93.44	7.80	15.55	26.01
06/04/2026	12.96	47.56	5.24	10.38	17.32
06/05/2026	13.41	49.33	5.30	10.55	17.61
06/06/2026	13.12	47.92	5.17	10.32	17.23
06/07/2026	13.56	48.05	5.19	10.32	17.20
06/08/2026	13.23	49.17	5.33	10.58	17.65
06/09/2026	13.72	49.59	5.38	10.68	17.82
06/10/2026	37.59	131.76	13.33	26.67	44.43
06/11/2026	20.85	136.06	14.66	29.29	48.84
06/12/2026	44.48	145.76	14.34	28.48	47.86
06/13/2026	25.42	115.49	12.37	24.76	41.28
06/14/2026	30.50	104.71	11.37	22.66	37.87
06/15/2026	29.73	103.89	11.21	22.39	37.40
06/16/2026	51.43	168.68	17.19	34.14	57.31
06/17/2026	55.90	171.87	17.75	35.10	59.19
06/18/2026	42.16	117.99	12.82	25.57	42.66
06/19/2026	43.82	72.55	7.71	15.34	25.52
06/20/2026	13.88	50.92	5.53	10.85	18.18
06/21/2026	14.13	52.89	5.73	11.38	19.00
06/22/2026	14.21	51.90	5.64	11.18	18.68
06/23/2026	14.16	53.38	5.76	11.47	19.20
06/24/2026	14.44	52.63	5.70	11.31	18.86
06/25/2026	14.12	50.80	5.51	10.95	18.24
06/26/2026	14.82	50.89	5.49	10.87	18.11
06/27/2026	15.41	51.04	5.52	10.84	18.12
06/28/2026	15.99	50.91	5.47	10.81	18.11
06/29/2026	16.39	50.89	5.46	10.90	18.28
06/30/2026	16.56	55.53	6.02	12.06	20.13
Monthly Avg/Sum:	747.92 sum	2,329.16 sum	245.28 sum	487.69 sum	815.33 sum
Daily Min:	12.96	47.56	5.17	10.32	17.20
Daily Max:	90.32	171.87	17.75	35.10	59.19
Apr 2026 - Jun 2026	2,680.62 sum	4,161.41 sum	413.17 sum	822.46 sum	1,373.24 sum
QTD:	2,680.62 sum	4,161.41 sum	413.17 sum	822.46 sum	1,373.24 sum
YTD 2026:	3,523.44 sum	4,646.56 sum	441.65 sum	876.13 sum	1,468.58 sum

Monthly Summary By Day Report

Units CT1 and CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
04/01/2026	60.13	22.83	1.20	2.41	4.02
04/02/2026	0.00	0.00	0.00	0.00	0.00
04/03/2026	0.00	0.00	0.00	0.00	0.00
04/04/2026	0.00	0.00	0.00	0.00	0.00
04/05/2026	0.00	0.00	0.00	0.00	0.00
04/06/2026	0.00	0.00	0.00	0.00	0.00
04/07/2026	0.00	0.00	0.00	0.00	0.00
04/08/2026	72.41	31.37	1.96	3.98	6.59
04/09/2026	68.92	23.99	1.30	2.59	4.33
04/10/2026	0.00	0.00	0.00	0.00	0.00
04/11/2026	0.00	0.00	0.00	0.00	0.00
04/12/2026	0.00	0.00	0.00	0.00	0.00
04/13/2026	0.00	0.00	0.00	0.00	0.00
04/14/2026	153.06	54.38	3.19	6.37	10.61
04/15/2026	33.77	12.81	0.33	0.67	1.12
04/16/2026	159.26	100.59	8.12	16.22	27.08
04/17/2026	37.97	126.24	13.59	27.13	45.14
04/18/2026	38.46	125.04	13.43	26.81	44.65
04/19/2026	37.39	127.24	13.68	27.36	45.54
04/20/2026	84.12	123.21	13.06	26.08	43.38
04/21/2026	0.00	0.00	0.00	0.00	0.00
04/22/2026	0.00	0.00	0.00	0.00	0.00
04/23/2026	0.00	0.00	0.00	0.00	0.00
04/24/2026	0.00	0.00	0.00	0.00	0.00
04/25/2026	0.00	0.00	0.00	0.00	0.00
04/26/2026	0.00	0.00	0.00	0.00	0.00
04/27/2026	0.00	0.00	0.00	0.00	0.00
04/28/2026	0.00	0.00	0.00	0.00	0.00
04/29/2026	0.00	0.00	0.00	0.00	0.00
04/30/2026	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum:	745.49 sum	747.70 sum	69.86 sum	139.62 sum	232.46 sum
Daily Min:	0.00	0.00	0.00	0.00	0.00
Daily Max:	159.26	127.24	13.68	27.36	45.54
Apr 2026 - Apr 2026	745.49 sum	747.70 sum	69.86 sum	139.62 sum	232.46 sum
QTD:	745.49 sum	747.70 sum	69.86 sum	139.62 sum	232.46 sum
YTD 2026:	1,588.31 sum	1,232.85 sum	98.34 sum	193.29 sum	327.80 sum

Monthly Summary By Day Report

Units CT1 and CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
05/01/2026	0.00	0.00	0.00	0.00	0.00
05/02/2026	0.00	0.00	0.00	0.00	0.00
05/03/2026	0.00	0.00	0.00	0.00	0.00
05/04/2026	0.00	0.00	0.00	0.00	0.00
05/05/2026	0.00	0.00	0.00	0.00	0.00
05/06/2026	0.00	0.00	0.00	0.00	0.00
05/07/2026	0.00	0.00	0.00	0.00	0.00
05/08/2026	121.00	54.18	3.30	6.55	10.95
05/09/2026	54.94	23.96	1.42	2.86	4.74
05/10/2026	49.92	27.61	1.74	3.50	5.81
05/11/2026	78.26	31.35	2.00	4.02	6.70
05/12/2026	155.40	76.43	5.44	10.87	18.13
05/13/2026	3.77	8.64	0.62	1.25	2.11
05/14/2026	0.00	0.00	0.00	0.00	0.00
05/15/2026	140.03	70.26	5.04	10.07	16.80
05/16/2026	0.00	0.00	0.00	0.00	0.00
05/17/2026	0.00	0.00	0.00	0.00	0.00
05/18/2026	48.03	15.84	0.27	0.54	0.90
05/19/2026	100.59	73.72	6.35	12.76	21.20
05/20/2026	18.03	64.32	6.23	12.38	20.83
05/21/2026	17.08	61.41	6.40	12.58	21.26
05/22/2026	13.11	48.41	5.25	10.38	17.34
05/23/2026	94.70	72.76	6.65	13.24	22.03
05/24/2026	17.39	51.18	5.52	11.01	18.31
05/25/2026	17.65	50.89	5.52	10.93	18.25
05/26/2026	17.20	48.29	5.66	11.25	18.75
05/27/2026	79.52	70.02	6.51	12.89	21.52
05/28/2026	113.74	81.63	7.55	15.13	25.13
05/29/2026	15.62	51.46	5.52	11.04	18.26
05/30/2026	15.64	51.37	5.52	10.99	18.25
05/31/2026	15.59	50.82	5.52	10.91	18.18
Monthly Avg/Sum:	1,187.21 sum	1,084.55 sum	98.03 sum	195.15 sum	325.45 sum
Daily Min:	0.00	0.00	0.00	0.00	0.00
Daily Max:	155.40	81.63	7.55	15.13	25.13
Apr 2026 - May 2026	1,932.70 sum	1,832.25 sum	167.89 sum	334.77 sum	557.91 sum
QTD:	1,932.70 sum	1,832.25 sum	167.89 sum	334.77 sum	557.91 sum
YTD 2026:	2,775.52 sum	2,317.40 sum	196.37 sum	388.44 sum	653.25 sum

Monthly Summary By Day Report

Units CT1 and CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
06/01/2026	15.70	51.18	5.62	11.08	18.49
06/02/2026	15.91	52.38	5.67	11.21	18.73
06/03/2026	90.32	93.44	7.80	15.55	26.01
06/04/2026	12.96	47.56	5.24	10.38	17.32
06/05/2026	13.41	49.33	5.30	10.55	17.61
06/06/2026	13.12	47.92	5.17	10.32	17.23
06/07/2026	13.56	48.05	5.19	10.32	17.20
06/08/2026	13.23	49.17	5.33	10.58	17.65
06/09/2026	13.72	49.59	5.38	10.68	17.82
06/10/2026	37.59	131.76	13.33	26.67	44.43
06/11/2026	20.85	136.06	14.66	29.29	48.84
06/12/2026	44.48	145.76	14.34	28.48	47.86
06/13/2026	25.42	115.49	12.37	24.76	41.28
06/14/2026	30.50	104.71	11.37	22.66	37.87
06/15/2026	29.73	103.89	11.21	22.39	37.40
06/16/2026	51.43	168.68	17.19	34.14	57.31
06/17/2026	55.90	171.87	17.75	35.10	59.19
06/18/2026	42.16	117.99	12.82	25.57	42.66
06/19/2026	43.82	72.55	7.71	15.34	25.52
06/20/2026	13.88	50.92	5.53	10.85	18.18
06/21/2026	14.13	52.89	5.73	11.38	19.00
06/22/2026	14.21	51.90	5.64	11.18	18.68
06/23/2026	14.16	53.38	5.76	11.47	19.20
06/24/2026	14.44	52.63	5.70	11.31	18.86
06/25/2026	14.12	50.80	5.51	10.95	18.24
06/26/2026	14.82	50.89	5.49	10.87	18.11
06/27/2026	15.41	51.04	5.52	10.84	18.12
06/28/2026	15.99	50.91	5.47	10.81	18.11
06/29/2026	16.39	50.89	5.46	10.90	18.28
06/30/2026	16.56	55.53	6.02	12.06	20.13
Monthly Avg/Sum:	747.92 sum	2,329.16 sum	245.28 sum	487.69 sum	815.33 sum
Daily Min:	12.96	47.56	5.17	10.32	17.20
Daily Max:	90.32	171.87	17.75	35.10	59.19
Apr 2026 - Jun 2026	2,680.62 sum	4,161.41 sum	413.17 sum	822.46 sum	1,373.24 sum
QTD:	2,680.62 sum	4,161.41 sum	413.17 sum	822.46 sum	1,373.24 sum
YTD 2026:	3,523.44 sum	4,646.56 sum	441.65 sum	876.13 sum	1,468.58 sum

Monthly Summary By Day Report

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)
04/01/2026	0.0	0.0	47.3	13.7
04/02/2026	0.0	0.0	0.0	0.0
04/03/2026	0.0	0.0	0.0	0.0
04/04/2026	0.0	0.0	0.0	0.0
04/05/2026	0.0	0.0	0.0	0.0
04/06/2026	0.0	0.0	0.0	0.0
04/07/2026	0.0	0.0	0.0	0.0
04/08/2026	0.0	0.0	68.6	16.0
04/09/2026	0.0	0.0	67.4	14.8
04/10/2026	0.0	0.0	0.0	0.0
04/11/2026	0.0	0.0	0.0	0.0
04/12/2026	0.0	0.0	0.0	0.0
04/13/2026	0.0	0.0	0.0	0.0
04/14/2026	71.6	13.7	75.5	16.0
04/15/2026	0.0	0.0	35.7	12.5
04/16/2026	103.8	24.0	38.3	6.9
04/17/2026	0.0	0.0	0.0	0.0
04/18/2026	0.0	0.0	0.0	0.0
04/19/2026	0.0	0.0	0.0	0.0
04/20/2026	18.2	1.0	24.1	1.7
04/21/2026	0.0	0.0	0.0	0.0
04/22/2026	0.0	0.0	0.0	0.0
04/23/2026	0.0	0.0	0.0	0.0
04/24/2026	0.0	0.0	0.0	0.0
04/25/2026	0.0	0.0	0.0	0.0
04/26/2026	0.0	0.0	0.0	0.0
04/27/2026	0.0	0.0	0.0	0.0
04/28/2026	0.0	0.0	0.0	0.0
04/29/2026	0.0	0.0	0.0	0.0
04/30/2026	0.0	0.0	0.0	0.0
Monthly Avg/Sum:	193.6 sum	38.7 sum	356.9 sum	81.6 sum
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	103.8	24.0	75.5	16.0
Apr 2026 - Apr 2026	193.6 sum	38.7 sum	356.9 sum	81.6 sum
QTD:	193.6 sum	38.7 sum	356.9 sum	81.6 sum
YTD 2026:	589.4 sum	87.9 sum	627.0 sum	158.3 sum

Monthly Summary By Day Report

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)
05/01/2026	0.0	0.0	0.0	0.0
05/02/2026	0.0	0.0	0.0	0.0
05/03/2026	0.0	0.0	0.0	0.0
05/04/2026	0.0	0.0	0.0	0.0
05/05/2026	0.0	0.0	0.0	0.0
05/06/2026	0.0	0.0	0.0	0.0
05/07/2026	0.0	0.0	0.0	0.0
05/08/2026	67.2	12.7	43.4	14.4
05/09/2026	0.0	0.0	57.9	13.8
05/10/2026	0.0	0.0	45.2	15.0
05/11/2026	0.0	0.0	73.9	15.3
05/12/2026	79.0	14.2	57.5	13.6
05/13/2026	0.0	0.0	0.0	0.0
05/14/2026	0.0	0.0	0.0	0.0
05/15/2026	98.4	13.5	72.6	15.1
05/16/2026	0.0	0.0	0.0	0.0
05/17/2026	0.0	0.0	0.0	0.0
05/18/2026	0.0	0.0	46.2	15.2
05/19/2026	50.9	13.0	23.0	2.4
05/20/2026	0.0	0.0	0.0	0.0
05/21/2026	0.0	0.0	0.0	0.0
05/22/2026	0.0	0.0	0.0	0.0
05/23/2026	20.8	1.4	58.1	13.4
05/24/2026	0.0	0.0	0.0	0.0
05/25/2026	0.0	0.0	0.0	0.0
05/26/2026	0.0	0.0	0.0	0.0
05/27/2026	55.7	11.0	0.0	0.0
05/28/2026	93.5	13.7	0.0	0.0
05/29/2026	0.0	0.0	0.0	0.0
05/30/2026	0.0	0.0	0.0	0.0
05/31/2026	0.0	0.0	0.0	0.0
Monthly Avg/Sum:	465.5 sum	79.5 sum	477.8 sum	118.2 sum
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	98.4	14.2	73.9	15.3
Apr 2026 - May 2026	659.1 sum	118.2 sum	834.7 sum	199.8 sum
QTD:	659.1 sum	118.2 sum	834.7 sum	199.8 sum
YTD 2026:	1,054.9 sum	167.4 sum	1,104.8 sum	276.5 sum

Monthly Summary By Day Report

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)
06/01/2026	0.0	0.0	0.0	0.0
06/02/2026	0.0	0.0	0.0	0.0
06/03/2026	49.4	12.9	18.4	2.0
06/04/2026	0.0	0.0	0.0	0.0
06/05/2026	0.0	0.0	0.0	0.0
06/06/2026	0.0	0.0	0.0	0.0
06/07/2026	0.0	0.0	0.0	0.0
06/08/2026	0.0	0.0	0.0	0.0
06/09/2026	0.0	0.0	0.0	0.0
06/10/2026	0.0	0.0	21.9	11.2
06/11/2026	0.0	0.0	0.0	0.0
06/12/2026	0.0	0.0	0.0	0.0
06/13/2026	0.0	0.0	0.0	0.0
06/14/2026	0.0	0.0	0.0	0.0
06/15/2026	0.0	0.0	0.0	0.0
06/16/2026	0.0	0.0	0.0	0.0
06/17/2026	0.0	0.0	0.0	0.0
06/18/2026	0.0	0.0	0.0	0.0
06/19/2026	17.4	1.3	0.0	0.0
06/20/2026	0.0	0.0	0.0	0.0
06/21/2026	0.0	0.0	0.0	0.0
06/22/2026	0.0	0.0	0.0	0.0
06/23/2026	0.0	0.0	0.0	0.0
06/24/2026	0.0	0.0	0.0	0.0
06/25/2026	0.0	0.0	0.0	0.0
06/26/2026	0.0	0.0	0.0	0.0
06/27/2026	0.0	0.0	0.0	0.0
06/28/2026	0.0	0.0	0.0	0.0
06/29/2026	0.0	0.0	0.0	0.0
06/30/2026	0.0	0.0	0.0	0.0
Monthly Avg/Sum:	66.8 sum	14.2 sum	40.3 sum	13.2 sum
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	49.4	12.9	21.9	11.2
Apr 2026 - Jun 2026	725.9 sum	132.4 sum	875.0 sum	213.0 sum
QTD:	725.9 sum	132.4 sum	875.0 sum	213.0 sum
YTD 2026:	1,121.7 sum	181.6 sum	1,145.1 sum	289.7 sum

Tons 12 Month Rolling Summary

CT1 and CT2 Combined

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/01/2026 08:20 **Location:** Roseville, CA

* = Excess Emission

	Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2	
	CO, Ton		NOx, Ton		PM10, Ton		SO2, Ton		VOC, Ton	
	1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)	
Date	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Apr 2026	0.3728	3.6946	0.3738	7.9810	0.0698	1.7251	0.0350	0.8657	0.1163	2.8859
May 2026	0.5937	3.7674	0.5422	7.4867	0.0976	1.6073	0.0492	0.8073	0.1630	2.6892
Jun 2026	0.3743	3.7226	1.1646	7.7370	0.2439	1.6487	0.1229	0.8290	0.4076	2.7589
Sum/Avg	3.7226		7.7370		1.6487		0.8290		2.7589	
Limit										

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/01/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/02/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/03/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/04/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/05/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/06/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/07/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/08/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/08/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/08/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/08/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/08/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/08/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/08/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/08/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/08/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/08/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/08/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/08/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/08/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/08/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/08/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/08/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/08/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/08/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/08/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/08/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/08/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/08/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/08/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/08/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/09/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/09/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/09/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/09/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/09/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/09/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/09/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/09/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/09/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/09/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/09/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/09/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/09/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/09/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/09/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/09/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/09/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/09/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/09/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/09/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/09/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/09/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/09/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/09/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/10/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/11/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/12/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/13/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/14/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/14/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/14/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/14/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/14/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/14/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/14/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/14/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/14/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/14/2026 09:00	0.0	0.0	0	0.23	0.11364	0.38
04/14/2026 10:00	0.9	1.6	1	0.46	0.23136	0.77
04/14/2026 11:00	0.7	1.5	1	0.53	0.26352	0.88
04/14/2026 12:00	0.5	1.6	3	0.76	0.38010	1.27
04/14/2026 13:00	0.7	1.4	1	0.48	0.24180	0.81
04/14/2026 14:00	0.0	0.0	0	0.12	0.06126	0.20
04/14/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/14/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/14/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/14/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/14/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/14/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/14/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/14/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/14/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.5	1.0	2	0.43	0.21528	0.72
Minimum:	0.0	0.0	1	0.12	0.06126	0.20
Maximum:	0.9	1.6	3	0.76	0.38010	1.27
%SI	75.00	75.00	83.33	75.00	75.00	75.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/15/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/16/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/16/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/16/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/16/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/16/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/16/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/16/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/16/2026 07:00	0.0	0.0	0	0.22	0.10776	0.36
04/16/2026 08:00	0.8	1.5	2	0.54	0.27162	0.91
04/16/2026 09:00	0.8	1.5	1	0.55	0.27264	0.91
04/16/2026 10:00	0.9	1.5	2	0.55	0.27294	0.91
04/16/2026 11:00	0.7	1.5	1	0.55	0.27444	0.91
04/16/2026 12:00	0.7	1.5	1	0.55	0.27516	0.92
04/16/2026 13:00	0.7	1.5	1	0.55	0.27486	0.92
04/16/2026 14:00	0.7	1.5	1	0.50	0.24996	0.83
04/16/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/16/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/16/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/16/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/16/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/16/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/16/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/16/2026 22:00	0.0	0.0	0	0.28	0.14178	0.47
04/16/2026 23:00	0.8	1.5	2	0.43	0.21384	0.71
Average/Sum#:	0.6	1.2	1	0.47	0.23550	0.79
Minimum:	0.0	0.0	1	0.22	0.10776	0.36
Maximum:	0.9	1.5	2	0.55	0.27516	0.92
%SI	58.33	58.33	66.67	58.33	58.33	58.33

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/17/2026 00:00	0.7	1.5	1	0.51	0.25614	0.85
04/17/2026 01:00	0.8	1.5	1	0.54	0.27144	0.90
04/17/2026 02:00	0.8	1.5	1	0.54	0.27186	0.91
04/17/2026 03:00	0.8	1.5	1	0.55	0.27300	0.91
04/17/2026 04:00	0.8	1.5	1	0.55	0.27270	0.91
04/17/2026 05:00	0.8	1.5	1	0.55	0.27354	0.91
04/17/2026 06:00	0.8	1.5	1	0.55	0.27378	0.91
04/17/2026 07:00	0.8	1.5	1	0.55	0.27414	0.91
04/17/2026 08:00	0.8	1.5	1	0.55	0.27396	0.91
04/17/2026 09:00	0.8	1.5	1	0.55	0.27396	0.91
04/17/2026 10:00	0.7	1.5	1	0.55	0.27444	0.91
04/17/2026 11:00	0.7	1.5	1	0.55	0.27594	0.92
04/17/2026 12:00	0.7	1.5	1	0.55	0.27618	0.92
04/17/2026 13:00	0.7	1.5	1	0.55	0.27564	0.92
04/17/2026 14:00	0.7	1.5	1	0.55	0.27492	0.92
04/17/2026 15:00	0.7	1.5	1	0.55	0.27438	0.91
04/17/2026 16:00	0.7	1.5	1	0.55	0.27462	0.92
04/17/2026 17:00	0.7	1.5	1	0.55	0.27426	0.91
04/17/2026 18:00	0.8	1.5	1	0.55	0.27402	0.91
04/17/2026 19:00	0.8	1.5	1	0.55	0.27378	0.91
04/17/2026 20:00	0.8	1.5	1	0.55	0.27372	0.91
04/17/2026 21:00	0.8	1.5	1	0.55	0.27384	0.91
04/17/2026 22:00	0.8	1.5	1	0.55	0.27384	0.91
04/17/2026 23:00	0.8	1.5	1	0.55	0.27402	0.91
Average/Sum#:	0.8	1.5	1	0.55	0.27326	0.91
Minimum:	0.7	1.5	1	0.51	0.25614	0.85
Maximum:	0.8	1.5	1	0.55	0.27618	0.92
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/18/2026 00:00	0.8	1.5	1	0.55	0.27444	0.91
04/18/2026 01:00	0.8	1.5	1	0.55	0.27420	0.91
04/18/2026 02:00	0.8	1.5	1	0.55	0.27420	0.91
04/18/2026 03:00	0.9	1.5	1	0.55	0.27396	0.91
04/18/2026 04:00	0.8	1.5	1	0.55	0.27366	0.91
04/18/2026 05:00	0.8	1.5	1	0.55	0.27384	0.91
04/18/2026 06:00	0.8	1.5	1	0.55	0.27384	0.91
04/18/2026 07:00	0.9	1.5	1	0.49	0.24588	0.82
04/18/2026 08:00	0.9	1.5	1	0.43	0.21330	0.71
04/18/2026 09:00	0.8	1.5	1	0.50	0.24876	0.83
04/18/2026 10:00	0.8	1.5	1	0.55	0.27492	0.92
04/18/2026 11:00	0.7	1.5	1	0.55	0.27654	0.92
04/18/2026 12:00	0.7	1.5	1	0.55	0.27636	0.92
04/18/2026 13:00	0.7	1.5	1	0.55	0.27624	0.92
04/18/2026 14:00	0.7	1.5	1	0.55	0.27624	0.92
04/18/2026 15:00	0.7	1.5	1	0.55	0.27612	0.92
04/18/2026 16:00	0.7	1.5	1	0.55	0.27564	0.92
04/18/2026 17:00	0.7	1.5	1	0.55	0.27558	0.92
04/18/2026 18:00	0.7	1.5	1	0.55	0.27498	0.92
04/18/2026 19:00	0.7	1.5	1	0.55	0.27504	0.92
04/18/2026 20:00	0.8	1.5	1	0.55	0.27420	0.91
04/18/2026 21:00	0.9	1.5	1	0.55	0.27450	0.92
04/18/2026 22:00	0.9	1.5	1	0.55	0.27480	0.92
04/18/2026 23:00	0.9	1.5	1	0.55	0.27486	0.92
Average/Sum#:	0.8	1.5	1	0.54	0.27009	0.90
Minimum:	0.7	1.5	1	0.43	0.21330	0.71
Maximum:	0.9	1.5	1	0.55	0.27654	0.92
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/19/2026 00:00	0.8	1.5	1	0.55	0.27432	0.91
04/19/2026 01:00	0.8	1.5	1	0.55	0.27420	0.91
04/19/2026 02:00	0.8	1.5	1	0.55	0.27414	0.91
04/19/2026 03:00	0.9	1.5	1	0.55	0.27390	0.91
04/19/2026 04:00	0.8	1.5	1	0.55	0.27402	0.91
04/19/2026 05:00	0.8	1.5	1	0.55	0.27414	0.91
04/19/2026 06:00	0.8	1.5	1	0.55	0.27480	0.92
04/19/2026 07:00	0.8	1.5	1	0.55	0.27570	0.92
04/19/2026 08:00	0.8	1.5	1	0.55	0.27534	0.92
04/19/2026 09:00	0.7	1.5	1	0.55	0.27570	0.92
04/19/2026 10:00	0.7	1.5	1	0.55	0.27594	0.92
04/19/2026 11:00	0.7	1.5	1	0.55	0.27678	0.92
04/19/2026 12:00	0.7	1.5	1	0.55	0.27678	0.92
04/19/2026 13:00	0.7	1.5	1	0.55	0.27708	0.92
04/19/2026 14:00	0.7	1.5	1	0.55	0.27648	0.92
04/19/2026 15:00	0.7	1.5	1	0.55	0.27636	0.92
04/19/2026 16:00	0.7	1.5	1	0.55	0.27606	0.92
04/19/2026 17:00	0.7	1.5	1	0.55	0.27540	0.92
04/19/2026 18:00	0.7	1.5	1	0.55	0.27504	0.92
04/19/2026 19:00	0.7	1.5	1	0.55	0.27492	0.92
04/19/2026 20:00	0.7	1.5	1	0.55	0.27510	0.92
04/19/2026 21:00	0.7	1.5	1	0.55	0.27492	0.92
04/19/2026 22:00	0.7	1.5	1	0.55	0.27480	0.92
04/19/2026 23:00	0.7	1.5	1	0.55	0.27480	0.92
Average/Sum#:	0.7	1.5	1	0.55	0.27528	0.92
Minimum:	0.7	1.5	1	0.55	0.27390	0.91
Maximum:	0.9	1.5	1	0.55	0.27708	0.92
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/20/2026 00:00	0.7	1.5	1	0.55	0.27492	0.92
04/20/2026 01:00	0.8	1.5	1	0.55	0.27414	0.91
04/20/2026 02:00	0.8	1.5	1	0.55	0.27384	0.91
04/20/2026 03:00	0.9	1.5	1	0.55	0.27336	0.91
04/20/2026 04:00	0.8	1.5	1	0.55	0.27360	0.91
04/20/2026 05:00	0.8	1.5	1	0.55	0.27366	0.91
04/20/2026 06:00	0.8	1.5	1	0.55	0.27468	0.92
04/20/2026 07:00	0.8	1.5	1	0.55	0.27492	0.92
04/20/2026 08:00	0.7	1.5	1	0.55	0.27516	0.92
04/20/2026 09:00	0.8	1.5	1	0.55	0.27552	0.92
04/20/2026 10:00	0.8	1.5	1	0.55	0.27660	0.92
04/20/2026 11:00	0.8	1.5	1	0.55	0.27654	0.92
04/20/2026 12:00	0.8	1.5	1	0.55	0.27636	0.92
04/20/2026 13:00	0.7	1.5	1	0.55	0.27648	0.92
04/20/2026 14:00	0.7	1.5	1	0.55	0.27606	0.92
04/20/2026 15:00	0.8	1.5	1	0.55	0.27396	0.91
04/20/2026 16:00	0.8	1.5	1	0.55	0.27360	0.91
04/20/2026 17:00	0.8	1.5	1	0.55	0.27354	0.91
04/20/2026 18:00	0.8	1.5	1	0.55	0.27330	0.91
04/20/2026 19:00	1.0	1.5	1	0.55	0.27348	0.91
04/20/2026 20:00	1.0	1.5	1	0.55	0.27306	0.91
04/20/2026 21:00	0.8	1.5	1	0.55	0.27348	0.91
04/20/2026 22:00	0.8	1.5	1	0.50	0.25164	0.84
04/20/2026 23:00	0.0	0.0	0	0.12	0.05760	0.19
Average/Sum#:	0.8	1.4	1	0.53	0.26456	0.88
Minimum:	0.0	0.0	1	0.12	0.05760	0.19
Maximum:	1.0	1.5	1	0.55	0.27660	0.92
%SI	0.00	0.00	4.17	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/21/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/22/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/23/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/24/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/25/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/26/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/27/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/28/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/29/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
04/30/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/01/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/02/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/03/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/04/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/05/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/06/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/07/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/08/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/08/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/08/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/08/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/08/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/08/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/08/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/08/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/08/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/08/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/08/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/08/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/08/2026 12:00	0.0	0.0	0	0.41	0.20514	0.68
05/08/2026 13:00	0.8	1.6	1	0.50	0.24804	0.83
05/08/2026 14:00	0.5	1.5	2	0.71	0.35436	1.18
05/08/2026 15:00	0.8	1.4	1	0.40	0.20136	0.67
05/08/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/08/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/08/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/08/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/08/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/08/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/08/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/08/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.5	1.1	1	0.51	0.25223	0.84
Minimum:	0.0	0.0	1	0.40	0.20136	0.67
Maximum:	0.8	1.6	2	0.71	0.35436	1.18
%SI	83.33	83.33	87.50	83.33	83.33	83.33

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/09/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/09/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/09/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/09/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/09/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/09/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/09/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/09/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/09/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/09/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/09/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/09/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/09/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/09/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/09/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/09/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/09/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/09/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/09/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/09/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/09/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/09/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/09/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/09/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/10/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/10/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/10/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/10/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/10/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/10/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/10/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/10/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/10/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/10/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/10/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/10/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/10/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/10/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/10/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/10/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/10/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/10/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/10/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/10/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/10/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/10/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/10/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/10/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/11/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/11/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/11/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/11/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/11/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/11/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/11/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/11/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/11/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/11/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/11/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/11/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/11/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/11/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/11/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/11/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/11/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/11/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/11/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/11/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/11/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/11/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/11/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/11/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/12/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/12/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/12/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/12/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/12/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/12/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/12/2026 06:00	0.0	0.0	0	0.07	0.03426	0.11
05/12/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/12/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/12/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/12/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/12/2026 11:00	0.0	0.0	0	0.21	0.10356	0.35
05/12/2026 12:00	0.8	1.1	-1	0.43	0.21426	0.71
05/12/2026 13:00	0.8	1.6	1	0.47	0.23346	0.78
05/12/2026 14:00	1.0	1.5	2	0.63	0.31260	1.04
05/12/2026 15:00	0.5	1.5	2	0.69	0.34302	1.14
05/12/2026 16:00	0.9	1.5	1	0.55	0.27330	0.91
05/12/2026 17:00	0.8	1.5	1	0.40	0.20046	0.67
05/12/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/12/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/12/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/12/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/12/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/12/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.6	1.1	1	0.43	0.21437	0.71
Minimum:	0.0	0.0	-1	0.07	0.03426	0.11
Maximum:	1.0	1.6	2	0.69	0.34302	1.14
%SI	66.67	66.67	75.00	66.67	66.67	66.67

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/13/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/14/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/15/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/15/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/15/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/15/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/15/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/15/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/15/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/15/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/15/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/15/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/15/2026 10:00	0.0	0.0	0	0.35	0.17250	0.58
05/15/2026 11:00	0.6	1.5	1	0.52	0.26196	0.87
05/15/2026 12:00	1.0	1.5	2	0.61	0.30624	1.02
05/15/2026 13:00	0.2	1.5	3	0.73	0.36288	1.21
05/15/2026 14:00	0.6	1.5	2	0.64	0.31812	1.06
05/15/2026 15:00	0.7	1.5	1	0.47	0.23538	0.78
05/15/2026 16:00	0.0	0.0	0	0.22	0.10770	0.36
05/15/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/15/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/15/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/15/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/15/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/15/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/15/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.4	1.1	2	0.51	0.25211	0.84
Minimum:	0.0	0.0	1	0.22	0.10770	0.36
Maximum:	1.0	1.5	3	0.73	0.36288	1.21
%SI	70.83	70.83	79.17	70.83	70.83	70.83

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/16/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/17/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/18/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/19/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/19/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/19/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/19/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/19/2026 04:00	0.0	0.0	0	0.43	0.21444	0.71
05/19/2026 05:00	0.8	1.4	1	0.45	0.22386	0.75
05/19/2026 06:00	0.8	1.5	1	0.42	0.21156	0.71
05/19/2026 07:00	0.7	1.5	1	0.45	0.22734	0.76
05/19/2026 08:00	0.7	1.5	1	0.42	0.21246	0.71
05/19/2026 09:00	0.7	1.5	1	0.43	0.21312	0.71
05/19/2026 10:00	0.6	1.5	1	0.43	0.21276	0.71
05/19/2026 11:00	0.6	1.5	1	0.43	0.21528	0.72
05/19/2026 12:00	0.6	1.5	1	0.43	0.21522	0.72
05/19/2026 13:00	0.6	1.5	1	0.48	0.23754	0.79
05/19/2026 14:00	0.6	1.5	1	0.43	0.21576	0.72
05/19/2026 15:00	0.6	1.5	1	0.44	0.21990	0.73
05/19/2026 16:00	0.6	1.5	1	0.48	0.24078	0.80
05/19/2026 17:00	0.6	1.5	1	0.46	0.22794	0.76
05/19/2026 18:00	0.6	1.5	1	0.43	0.21540	0.72
05/19/2026 19:00	0.7	1.5	1	0.43	0.21468	0.72
05/19/2026 20:00	0.7	1.5	1	0.43	0.21324	0.71
05/19/2026 21:00	0.7	1.5	1	0.43	0.21354	0.71
05/19/2026 22:00	0.7	1.5	1	0.43	0.21438	0.71
05/19/2026 23:00	0.7	1.5	1	0.43	0.21420	0.71
Average/Sum#:	0.6	1.4	1	0.44	0.21867	0.73
Minimum:	0.0	0.0	1	0.42	0.21156	0.71
Maximum:	0.8	1.5	1	0.48	0.24078	0.80
%SI	16.67	16.67	20.83	16.67	16.67	16.67

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/20/2026 00:00	0.7	1.5	1	0.43	0.21552	0.72
05/20/2026 01:00	0.7	1.5	1	0.43	0.21630	0.72
05/20/2026 02:00	0.7	1.5	1	0.43	0.21402	0.71
05/20/2026 03:00	0.8	1.5	1	0.43	0.21336	0.71
05/20/2026 04:00	0.7	1.5	1	0.43	0.21450	0.72
05/20/2026 05:00	0.7	1.5	1	0.43	0.21498	0.72
05/20/2026 06:00	0.8	1.5	1	0.43	0.21468	0.72
05/20/2026 07:00	0.7	1.5	1	0.43	0.21486	0.72
05/20/2026 08:00	0.7	1.5	1	0.43	0.21462	0.72
05/20/2026 09:00	0.7	1.5	1	0.43	0.21432	0.71
05/20/2026 10:00	0.6	1.5	1	0.42	0.21234	0.71
05/20/2026 11:00	0.6	1.5	1	0.43	0.21366	0.71
05/20/2026 12:00	0.6	1.5	1	0.43	0.21420	0.71
05/20/2026 13:00	0.6	1.5	1	0.44	0.21990	0.73
05/20/2026 14:00	0.6	1.5	1	0.43	0.21390	0.71
05/20/2026 15:00	0.6	1.5	1	0.43	0.21378	0.71
05/20/2026 16:00	0.6	1.5	1	0.46	0.23238	0.77
05/20/2026 17:00	0.6	1.5	1	0.51	0.25260	0.84
05/20/2026 18:00	0.6	1.5	1	0.48	0.24180	0.81
05/20/2026 19:00	0.6	1.5	1	0.51	0.25572	0.85
05/20/2026 20:00	0.6	1.5	1	0.52	0.25896	0.86
05/20/2026 21:00	0.6	1.5	1	0.52	0.25932	0.86
05/20/2026 22:00	0.7	1.5	1	0.52	0.25896	0.86
05/20/2026 23:00	0.7	1.5	1	0.52	0.25956	0.87
Average/Sum#:	0.7	1.5	1	0.46	0.22726	0.76
Minimum:	0.6	1.5	1	0.42	0.21234	0.71
Maximum:	0.8	1.5	1	0.52	0.25956	0.87
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/21/2026 00:00	0.7	1.5	1	0.47	0.23658	0.79
05/21/2026 01:00	0.6	1.5	1	0.50	0.24906	0.83
05/21/2026 02:00	0.7	1.5	1	0.44	0.21960	0.73
05/21/2026 03:00	0.7	1.5	1	0.49	0.24558	0.82
05/21/2026 04:00	0.7	1.5	1	0.52	0.26016	0.87
05/21/2026 05:00	0.7	1.5	1	0.47	0.23412	0.78
05/21/2026 06:00	0.7	1.5	1	0.43	0.21642	0.72
05/21/2026 07:00	0.7	1.5	1	0.43	0.21642	0.72
05/21/2026 08:00	0.7	1.5	1	0.43	0.21486	0.72
05/21/2026 09:00	0.6	1.5	1	0.43	0.21534	0.72
05/21/2026 10:00	0.6	1.5	1	0.43	0.21570	0.72
05/21/2026 11:00	0.6	1.5	1	0.43	0.21522	0.72
05/21/2026 12:00	0.6	1.5	1	0.43	0.21654	0.72
05/21/2026 13:00	0.6	1.5	1	0.43	0.21588	0.72
05/21/2026 14:00	0.6	1.5	1	0.43	0.21594	0.72
05/21/2026 15:00	0.6	1.5	1	0.47	0.23700	0.79
05/21/2026 16:00	0.6	1.5	1	0.45	0.22746	0.76
05/21/2026 17:00	0.6	1.5	1	0.49	0.24438	0.81
05/21/2026 18:00	0.6	1.5	1	0.48	0.23934	0.80
05/21/2026 19:00	0.6	1.5	1	0.44	0.21948	0.73
05/21/2026 20:00	0.6	1.5	1	0.43	0.21642	0.72
05/21/2026 21:00	0.7	1.5	1	0.43	0.21630	0.72
05/21/2026 22:00	0.7	1.5	1	0.43	0.21600	0.72
05/21/2026 23:00	0.7	1.5	1	0.43	0.21576	0.72
Average/Sum#:	0.6	1.5	1	0.45	0.22582	0.75
Minimum:	0.6	1.5	1	0.43	0.21486	0.72
Maximum:	0.7	1.5	1	0.52	0.26016	0.87
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/22/2026 00:00	0.7	1.5	1	0.43	0.21534	0.72
05/22/2026 01:00	0.7	1.5	1	0.43	0.21606	0.72
05/22/2026 02:00	0.7	1.5	1	0.43	0.21600	0.72
05/22/2026 03:00	0.8	1.5	1	0.43	0.21648	0.72
05/22/2026 04:00	0.8	1.5	1	0.43	0.21618	0.72
05/22/2026 05:00	0.7	1.5	1	0.43	0.21594	0.72
05/22/2026 06:00	0.7	1.5	1	0.43	0.21588	0.72
05/22/2026 07:00	0.7	1.5	1	0.43	0.21624	0.72
05/22/2026 08:00	0.7	1.5	1	0.43	0.21564	0.72
05/22/2026 09:00	0.6	1.5	1	0.43	0.21486	0.72
05/22/2026 10:00	0.6	1.5	1	0.43	0.21438	0.71
05/22/2026 11:00	0.6	1.5	1	0.43	0.21504	0.72
05/22/2026 12:00	0.6	1.5	1	0.43	0.21564	0.72
05/22/2026 13:00	0.6	1.5	1	0.43	0.21606	0.72
05/22/2026 14:00	0.6	1.5	1	0.43	0.21612	0.72
05/22/2026 15:00	0.6	1.5	1	0.43	0.21564	0.72
05/22/2026 16:00	0.6	1.5	1	0.43	0.21594	0.72
05/22/2026 17:00	0.6	1.5	1	0.45	0.22644	0.75
05/22/2026 18:00	0.6	1.5	1	0.47	0.23574	0.79
05/22/2026 19:00	0.6	1.5	0	0.43	0.21414	0.71
05/22/2026 20:00	0.6	1.5	1	0.43	0.21402	0.71
05/22/2026 21:00	0.7	1.5	1	0.43	0.21402	0.71
05/22/2026 22:00	0.7	1.5	1	0.43	0.21450	0.72
05/22/2026 23:00	0.7	1.5	1	0.43	0.21558	0.72
Average/Sum#:	0.7	1.5	1	0.43	0.21675	0.72
Minimum:	0.6	1.5	0	0.43	0.21402	0.71
Maximum:	0.8	1.5	1	0.47	0.23574	0.79
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/23/2026 00:00	0.6	1.5	1	0.50	0.24930	0.83
05/23/2026 01:00	0.7	1.5	0	0.43	0.21684	0.72
05/23/2026 02:00	0.7	1.5	1	0.43	0.21252	0.71
05/23/2026 03:00	0.7	1.5	0	0.44	0.22158	0.74
05/23/2026 04:00	0.6	1.5	1	0.52	0.25980	0.87
05/23/2026 05:00	0.7	1.4	0	0.40	0.19836	0.66
05/23/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/23/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/23/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/23/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/23/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/23/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/23/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/23/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/23/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/23/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/23/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/23/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/23/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/23/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/23/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/23/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/23/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/23/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.7	1.5	1	0.45	0.22640	0.76
Minimum:	0.6	1.4	0	0.40	0.19836	0.66
Maximum:	0.7	1.5	1	0.52	0.25980	0.87
%SI	75.00	75.00	75.00	75.00	75.00	75.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/24/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/24/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/25/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/25/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/26/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/26/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/27/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/27/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/27/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/27/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/27/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/27/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/27/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/27/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/27/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/27/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/27/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/27/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/27/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/27/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/27/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/27/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/27/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/27/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/27/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/27/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/27/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/27/2026 21:00	0.0	0.0	0	0.15	0.07560	0.25
05/27/2026 22:00	0.6	1.3	0	0.44	0.21972	0.73
05/27/2026 23:00	0.5	1.5	1	0.52	0.25812	0.86
Average/Sum#:	0.4	0.9	1	0.37	0.18448	0.61
Minimum:	0.0	0.0	0	0.15	0.07560	0.25
Maximum:	0.6	1.5	1	0.52	0.25812	0.86
%SI	87.50	87.50	91.67	87.50	87.50	87.50

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/28/2026 00:00	0.7	1.5	1	0.51	0.25686	0.86
05/28/2026 01:00	0.7	1.5	1	0.44	0.22014	0.73
05/28/2026 02:00	0.6	1.5	1	0.37	0.18552	0.62
05/28/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/28/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/28/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/28/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/28/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/28/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/28/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/28/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/28/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/28/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/28/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/28/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/28/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/28/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/28/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/28/2026 18:00	0.0	0.0	0	0.21	0.10698	0.36
05/28/2026 19:00	0.6	1.5	1	0.43	0.21564	0.72
05/28/2026 20:00	0.5	1.5	1	0.52	0.25758	0.86
05/28/2026 21:00	0.5	1.5	1	0.52	0.25956	0.87
05/28/2026 22:00	0.6	1.5	1	0.51	0.25644	0.85
05/28/2026 23:00	0.7	1.4	0	0.37	0.18468	0.62
Average/Sum#:	0.5	1.3	1	0.43	0.21593	0.72
Minimum:	0.0	0.0	0	0.21	0.10698	0.36
Maximum:	0.7	1.5	1	0.52	0.25956	0.87
%SI	62.50	62.50	66.67	62.50	62.50	62.50

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/29/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/29/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/30/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/30/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
05/31/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/31/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/01/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
06/01/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/02/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
06/02/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
06/02/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
06/02/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
06/02/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
06/02/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
06/02/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
06/02/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/02/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
06/02/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
06/02/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
06/02/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
06/02/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
06/02/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
06/02/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
06/02/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
06/02/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
06/02/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
06/02/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
06/02/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
06/02/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
06/02/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
06/02/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
06/02/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/03/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
06/03/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
06/03/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
06/03/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
06/03/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
06/03/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
06/03/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
06/03/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/03/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
06/03/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
06/03/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
06/03/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
06/03/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
06/03/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
06/03/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
06/03/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
06/03/2026 16:00	0.0	0.0	0	0.19	0.09540	0.32
06/03/2026 17:00	0.5	1.5	1	0.48	0.23832	0.79
06/03/2026 18:00	0.5	1.5	1	0.52	0.25968	0.87
06/03/2026 19:00	0.7	1.5	1	0.48	0.23760	0.79
06/03/2026 20:00	0.6	1.5	1	0.46	0.23016	0.77
06/03/2026 21:00	0.6	1.5	1	0.50	0.24942	0.83
06/03/2026 22:00	0.6	1.5	1	0.50	0.25248	0.84
06/03/2026 23:00	0.7	1.5	1	0.43	0.21606	0.72
Average/Sum#:	0.5	1.3	1	0.45	0.22239	0.74
Minimum:	0.0	0.0	1	0.19	0.09540	0.32
Maximum:	0.7	1.5	1	0.52	0.25968	0.87
%SI	66.67	66.67	70.83	66.67	66.67	66.67

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/04/2026 00:00	0.7	1.5	1	0.43	0.21522	0.72
06/04/2026 01:00	0.6	1.5	1	0.46	0.23040	0.77
06/04/2026 02:00	0.7	1.4	0	0.44	0.22044	0.73
06/04/2026 03:00	0.7	1.5	1	0.44	0.21762	0.73
06/04/2026 04:00	0.7	1.5	1	0.43	0.21696	0.72
06/04/2026 05:00	0.7	1.5	1	0.43	0.21672	0.72
06/04/2026 06:00	0.7	1.5	1	0.43	0.21624	0.72
06/04/2026 07:00	0.7	0.9	-1	0.43	0.21642	0.72
06/04/2026 08:00	0.8	1.6	1	0.43	0.21660	0.72
06/04/2026 09:00	0.6	1.5	1	0.43	0.21534	0.72
06/04/2026 10:00	0.6	1.5	1	0.43	0.21516	0.72
06/04/2026 11:00	0.6	1.5	1	0.43	0.21558	0.72
06/04/2026 12:00	0.6	1.5	1	0.43	0.21600	0.72
06/04/2026 13:00	0.6	1.5	1	0.43	0.21564	0.72
06/04/2026 14:00	0.6	1.5	1	0.43	0.21582	0.72
06/04/2026 15:00	0.6	1.5	1	0.43	0.21564	0.72
06/04/2026 16:00	0.6	1.5	1	0.43	0.21474	0.72
06/04/2026 17:00	0.6	1.5	1	0.44	0.21816	0.73
06/04/2026 18:00	0.6	1.5	1	0.43	0.21378	0.71
06/04/2026 19:00	0.6	1.5	1	0.43	0.21384	0.71
06/04/2026 20:00	0.6	1.5	1	0.43	0.21432	0.71
06/04/2026 21:00	0.7	1.5	1	0.43	0.21744	0.72
06/04/2026 22:00	0.7	1.5	1	0.43	0.21432	0.71
06/04/2026 23:00	0.7	1.5	1	0.43	0.21594	0.72
Average/Sum#:	0.7	1.5	1	0.43	0.21660	0.72
Minimum:	0.6	0.9	-1	0.43	0.21378	0.71
Maximum:	0.8	1.6	1	0.46	0.23040	0.77
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/05/2026 00:00	0.7	1.5	1	0.43	0.21528	0.72
06/05/2026 01:00	0.7	1.5	1	0.43	0.21498	0.72
06/05/2026 02:00	0.7	1.6	1	0.43	0.21474	0.72
06/05/2026 03:00	0.8	1.5	1	0.43	0.21522	0.72
06/05/2026 04:00	0.7	1.5	1	0.50	0.24810	0.83
06/05/2026 05:00	0.7	1.5	1	0.48	0.24096	0.80
06/05/2026 06:00	0.8	1.5	1	0.43	0.21552	0.72
06/05/2026 07:00	0.7	1.5	1	0.43	0.21588	0.72
06/05/2026 08:00	0.7	1.5	1	0.43	0.21576	0.72
06/05/2026 09:00	0.7	1.5	1	0.43	0.21540	0.72
06/05/2026 10:00	0.6	1.5	1	0.43	0.21540	0.72
06/05/2026 11:00	0.6	1.5	1	0.43	0.21624	0.72
06/05/2026 12:00	0.6	1.5	1	0.43	0.21702	0.72
06/05/2026 13:00	0.6	1.5	1	0.43	0.21678	0.72
06/05/2026 14:00	0.6	1.5	1	0.43	0.21642	0.72
06/05/2026 15:00	0.6	1.5	1	0.43	0.21462	0.72
06/05/2026 16:00	0.6	1.5	1	0.43	0.21360	0.71
06/05/2026 17:00	0.6	1.5	1	0.46	0.22752	0.76
06/05/2026 18:00	0.6	1.5	1	0.48	0.24120	0.80
06/05/2026 19:00	0.6	1.5	1	0.44	0.22188	0.74
06/05/2026 20:00	0.6	1.5	1	0.43	0.21336	0.71
06/05/2026 21:00	0.7	1.5	1	0.43	0.21492	0.72
06/05/2026 22:00	0.7	1.5	1	0.44	0.21816	0.73
06/05/2026 23:00	0.7	1.5	1	0.44	0.21870	0.73
Average/Sum#:	0.7	1.5	1	0.44	0.21990	0.73
Minimum:	0.6	1.5	1	0.43	0.21336	0.71
Maximum:	0.8	1.6	1	0.50	0.24810	0.83
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/06/2026 00:00	0.7	1.5	1	0.43	0.21468	0.72
06/06/2026 01:00	0.7	1.5	1	0.43	0.21468	0.72
06/06/2026 02:00	0.7	1.5	1	0.43	0.21504	0.72
06/06/2026 03:00	0.8	1.5	2	0.43	0.21630	0.72
06/06/2026 04:00	0.7	1.5	1	0.43	0.21624	0.72
06/06/2026 05:00	0.7	1.5	1	0.43	0.21504	0.72
06/06/2026 06:00	0.7	1.5	1	0.43	0.21498	0.72
06/06/2026 07:00	0.7	1.5	1	0.43	0.21678	0.72
06/06/2026 08:00	0.7	1.5	1	0.43	0.21636	0.72
06/06/2026 09:00	0.7	1.5	1	0.43	0.21636	0.72
06/06/2026 10:00	0.7	1.5	1	0.43	0.21678	0.72
06/06/2026 11:00	0.6	1.5	1	0.43	0.21666	0.72
06/06/2026 12:00	0.6	1.5	1	0.43	0.21636	0.72
06/06/2026 13:00	0.6	1.5	1	0.43	0.21498	0.72
06/06/2026 14:00	0.6	1.5	1	0.43	0.21456	0.72
06/06/2026 15:00	0.6	1.5	1	0.43	0.21414	0.71
06/06/2026 16:00	0.6	1.5	1	0.43	0.21390	0.71
06/06/2026 17:00	0.6	1.5	1	0.43	0.21390	0.71
06/06/2026 18:00	0.6	1.5	1	0.43	0.21372	0.71
06/06/2026 19:00	0.6	1.5	1	0.43	0.21354	0.71
06/06/2026 20:00	0.6	1.5	1	0.43	0.21474	0.72
06/06/2026 21:00	0.7	1.5	1	0.43	0.21534	0.72
06/06/2026 22:00	0.7	1.5	1	0.43	0.21558	0.72
06/06/2026 23:00	0.7	1.5	1	0.43	0.21612	0.72
Average/Sum#:	0.7	1.5	1	0.43	0.21528	0.72
Minimum:	0.6	1.5	1	0.43	0.21354	0.71
Maximum:	0.8	1.5	2	0.43	0.21678	0.72
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/07/2026 00:00	0.7	1.5	1	0.43	0.21564	0.72
06/07/2026 01:00	0.7	1.5	1	0.43	0.21588	0.72
06/07/2026 02:00	0.8	1.5	1	0.43	0.21636	0.72
06/07/2026 03:00	0.9	1.5	1	0.43	0.21708	0.72
06/07/2026 04:00	0.8	1.5	1	0.43	0.21654	0.72
06/07/2026 05:00	0.8	1.5	1	0.43	0.21678	0.72
06/07/2026 06:00	0.8	1.5	1	0.43	0.21642	0.72
06/07/2026 07:00	0.7	1.5	1	0.43	0.21702	0.72
06/07/2026 08:00	0.7	1.5	1	0.43	0.21708	0.72
06/07/2026 09:00	0.7	1.5	1	0.43	0.21708	0.72
06/07/2026 10:00	0.7	1.5	1	0.43	0.21654	0.72
06/07/2026 11:00	0.7	1.5	1	0.43	0.21642	0.72
06/07/2026 12:00	0.6	1.5	1	0.43	0.21528	0.72
06/07/2026 13:00	0.6	1.5	1	0.43	0.21546	0.72
06/07/2026 14:00	0.6	1.5	1	0.43	0.21480	0.72
06/07/2026 15:00	0.6	1.5	1	0.43	0.21438	0.71
06/07/2026 16:00	0.6	1.5	1	0.43	0.21420	0.71
06/07/2026 17:00	0.6	1.5	1	0.43	0.21378	0.71
06/07/2026 18:00	0.6	1.5	1	0.43	0.21372	0.71
06/07/2026 19:00	0.6	1.5	1	0.43	0.21366	0.71
06/07/2026 20:00	0.6	1.5	1	0.43	0.21390	0.71
06/07/2026 21:00	0.7	1.5	1	0.43	0.21366	0.71
06/07/2026 22:00	0.7	1.5	1	0.43	0.21426	0.71
06/07/2026 23:00	0.7	1.5	1	0.43	0.21546	0.72
Average/Sum#:	0.7	1.5	1	0.43	0.21548	0.72
Minimum:	0.6	1.5	1	0.43	0.21366	0.71
Maximum:	0.9	1.5	1	0.43	0.21708	0.72
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/08/2026 00:00	0.7	1.5	1	0.43	0.21600	0.72
06/08/2026 01:00	0.7	1.5	1	0.43	0.21618	0.72
06/08/2026 02:00	0.7	1.6	1	0.43	0.21624	0.72
06/08/2026 03:00	0.8	1.5	2	0.43	0.21636	0.72
06/08/2026 04:00	0.8	1.5	1	0.43	0.21654	0.72
06/08/2026 05:00	0.7	1.5	1	0.44	0.21918	0.73
06/08/2026 06:00	0.7	1.4	1	0.43	0.21516	0.72
06/08/2026 07:00	0.7	1.5	1	0.43	0.21534	0.72
06/08/2026 08:00	0.7	1.5	1	0.43	0.21486	0.72
06/08/2026 09:00	0.7	1.5	1	0.43	0.21534	0.72
06/08/2026 10:00	0.7	1.5	1	0.43	0.21582	0.72
06/08/2026 11:00	0.6	1.5	1	0.43	0.21606	0.72
06/08/2026 12:00	0.6	1.5	1	0.43	0.21528	0.72
06/08/2026 13:00	0.6	1.5	1	0.43	0.21426	0.71
06/08/2026 14:00	0.6	1.5	1	0.43	0.21420	0.71
06/08/2026 15:00	0.6	1.5	1	0.43	0.21414	0.71
06/08/2026 16:00	0.6	1.5	1	0.43	0.21468	0.72
06/08/2026 17:00	0.6	1.5	1	0.44	0.22236	0.74
06/08/2026 18:00	0.6	1.5	1	0.48	0.24006	0.80
06/08/2026 19:00	0.6	1.5	1	0.43	0.21546	0.72
06/08/2026 20:00	0.6	1.5	1	0.43	0.21732	0.72
06/08/2026 21:00	0.6	1.5	1	0.46	0.22944	0.76
06/08/2026 22:00	0.6	1.5	1	0.52	0.25884	0.86
06/08/2026 23:00	0.6	1.5	1	0.50	0.24924	0.83
Average/Sum#:	0.7	1.5	1	0.44	0.22077	0.74
Minimum:	0.6	1.4	1	0.43	0.21414	0.71
Maximum:	0.8	1.6	2	0.52	0.25884	0.86
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/09/2026 00:00	0.7	1.5	1	0.45	0.22398	0.75
06/09/2026 01:00	0.7	1.5	1	0.43	0.21714	0.72
06/09/2026 02:00	0.7	1.5	1	0.43	0.21702	0.72
06/09/2026 03:00	0.8	1.5	1	0.43	0.21708	0.72
06/09/2026 04:00	0.7	1.5	1	0.45	0.22272	0.74
06/09/2026 05:00	0.7	1.5	1	0.46	0.23190	0.77
06/09/2026 06:00	0.7	1.5	1	0.43	0.21708	0.72
06/09/2026 07:00	0.7	1.5	1	0.43	0.21696	0.72
06/09/2026 08:00	0.7	1.5	1	0.43	0.21708	0.72
06/09/2026 09:00	0.7	1.5	1	0.43	0.21732	0.72
06/09/2026 10:00	0.6	1.5	1	0.43	0.21714	0.72
06/09/2026 11:00	0.6	1.5	1	0.43	0.21642	0.72
06/09/2026 12:00	0.6	1.5	1	0.43	0.21642	0.72
06/09/2026 13:00	0.6	1.5	1	0.43	0.21648	0.72
06/09/2026 14:00	0.6	1.5	1	0.43	0.21606	0.72
06/09/2026 15:00	0.6	1.5	1	0.43	0.21564	0.72
06/09/2026 16:00	0.6	1.5	1	0.43	0.21534	0.72
06/09/2026 17:00	0.6	1.5	1	0.45	0.22260	0.74
06/09/2026 18:00	0.7	1.5	1	0.48	0.24138	0.80
06/09/2026 19:00	0.6	1.5	1	0.52	0.25956	0.87
06/09/2026 20:00	0.6	1.5	1	0.49	0.24402	0.81
06/09/2026 21:00	0.7	1.5	1	0.43	0.21426	0.71
06/09/2026 22:00	0.7	1.5	1	0.48	0.24072	0.80
06/09/2026 23:00	1.0	1.5	1	0.45	0.22452	0.75
Average/Sum#:	0.7	1.5	1	0.45	0.22329	0.74
Minimum:	0.6	1.5	1	0.43	0.21426	0.71
Maximum:	1.0	1.5	1	0.52	0.25956	0.87
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/10/2026 00:00	1.2	1.5	1	0.43	0.21648	0.72
06/10/2026 01:00	0.8	1.5	1	0.43	0.21732	0.72
06/10/2026 02:00	0.8	1.5	1	0.44	0.21750	0.73
06/10/2026 03:00	0.8	1.5	1	0.44	0.21942	0.73
06/10/2026 04:00	0.7	1.5	1	0.51	0.25470	0.85
06/10/2026 05:00	0.8	1.4	1	0.45	0.22662	0.76
06/10/2026 06:00	0.8	1.5	1	0.48	0.24066	0.80
06/10/2026 07:00	0.3	1.5	3	0.72	0.35940	1.20
06/10/2026 08:00	0.2	1.5	3	0.72	0.36228	1.21
06/10/2026 09:00	0.1	1.5	3	0.73	0.36408	1.21
06/10/2026 10:00	0.2	1.5	3	0.72	0.36180	1.21
06/10/2026 11:00	0.2	1.5	3	0.72	0.36180	1.21
06/10/2026 12:00	0.2	1.5	3	0.73	0.36264	1.21
06/10/2026 13:00	0.2	1.5	3	0.73	0.36300	1.21
06/10/2026 14:00	0.1	1.5	3	0.73	0.36318	1.21
06/10/2026 15:00	0.1	1.5	3	0.73	0.36366	1.21
06/10/2026 16:00	0.1	1.5	3	0.73	0.36468	1.22
06/10/2026 17:00	0.1	1.5	3	0.73	0.36498	1.22
06/10/2026 18:00	0.1	1.5	3	0.73	0.36306	1.21
06/10/2026 19:00	0.8	1.5	1	0.58	0.28974	0.97
06/10/2026 20:00	0.7	1.5	0	0.43	0.21264	0.71
06/10/2026 21:00	0.6	1.5	1	0.42	0.21102	0.70
06/10/2026 22:00	0.7	1.5	1	0.42	0.21108	0.70
06/10/2026 23:00	0.7	1.5	1	0.42	0.21150	0.71
Average/Sum#:	0.5	1.5	2	0.59	0.29514	0.98
Minimum:	0.1	1.4	0	0.42	0.21102	0.70
Maximum:	1.2	1.5	3	0.73	0.36498	1.22
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/11/2026 00:00	0.7	1.5	1	0.42	0.21138	0.70
06/11/2026 01:00	0.7	1.5	1	0.42	0.21156	0.71
06/11/2026 02:00	0.7	1.5	1	0.42	0.21186	0.71
06/11/2026 03:00	0.8	1.5	1	0.42	0.21204	0.71
06/11/2026 04:00	0.8	1.5	1	0.42	0.21234	0.71
06/11/2026 05:00	0.9	1.5	1	0.50	0.24948	0.83
06/11/2026 06:00	0.9	1.5	2	0.63	0.31524	1.05
06/11/2026 07:00	0.2	1.5	3	0.73	0.36324	1.21
06/11/2026 08:00	0.2	1.5	3	0.72	0.36012	1.20
06/11/2026 09:00	0.2	1.5	3	0.72	0.36006	1.20
06/11/2026 10:00	0.2	1.5	3	0.72	0.36162	1.21
06/11/2026 11:00	0.2	1.5	3	0.73	0.36486	1.22
06/11/2026 12:00	0.1	1.5	3	0.73	0.36546	1.22
06/11/2026 13:00	0.1	1.5	3	0.73	0.36642	1.22
06/11/2026 14:00	0.1	1.5	3	0.73	0.36660	1.22
06/11/2026 15:00	0.1	1.5	3	0.73	0.36648	1.22
06/11/2026 16:00	0.1	1.5	3	0.73	0.36702	1.22
06/11/2026 17:00	0.1	1.5	3	0.73	0.36714	1.22
06/11/2026 18:00	0.1	1.5	3	0.73	0.36510	1.22
06/11/2026 19:00	0.7	1.5	1	0.58	0.28932	0.96
06/11/2026 20:00	0.7	1.5	0	0.42	0.21246	0.71
06/11/2026 21:00	0.7	1.5	1	0.45	0.22698	0.76
06/11/2026 22:00	0.7	1.5	1	0.46	0.23226	0.77
06/11/2026 23:00	0.7	1.5	1	0.42	0.21096	0.70
Average/Sum#:	0.4	1.5	2	0.60	0.29875	1.00
Minimum:	0.1	1.5	0	0.42	0.21096	0.70
Maximum:	0.9	1.5	3	0.73	0.36714	1.22
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/12/2026 00:00	0.7	1.5	1	0.42	0.21090	0.70
06/12/2026 01:00	0.7	1.5	1	0.43	0.21600	0.72
06/12/2026 02:00	0.7	1.5	1	0.43	0.21348	0.71
06/12/2026 03:00	0.7	1.5	1	0.47	0.23358	0.78
06/12/2026 04:00	0.7	1.5	1	0.44	0.21792	0.73
06/12/2026 05:00	0.7	1.5	1	0.45	0.22458	0.75
06/12/2026 06:00	0.8	1.5	1	0.42	0.21168	0.71
06/12/2026 07:00	0.7	1.5	1	0.42	0.21162	0.71
06/12/2026 08:00	0.7	1.5	1	0.42	0.21114	0.70
06/12/2026 09:00	0.6	1.5	1	0.42	0.21054	0.70
06/12/2026 10:00	0.6	1.5	1	0.42	0.21024	0.70
06/12/2026 11:00	0.6	1.5	1	0.43	0.21474	0.72
06/12/2026 12:00	0.6	1.5	1	0.51	0.25404	0.85
06/12/2026 13:00	0.6	1.5	1	0.52	0.25938	0.86
06/12/2026 14:00	0.6	1.5	1	0.52	0.26148	0.87
06/12/2026 15:00	0.5	1.5	2	0.61	0.30438	1.01
06/12/2026 16:00	0.7	1.5	1	0.58	0.28806	0.96
06/12/2026 17:00	0.6	1.5	0	0.46	0.23166	0.77
06/12/2026 18:00	0.6	1.5	1	0.49	0.24714	0.82
06/12/2026 19:00	0.6	1.5	1	0.53	0.26256	0.88
06/12/2026 20:00	0.9	1.5	1	0.60	0.30108	1.00
06/12/2026 21:00	1.0	1.5	1	0.60	0.29928	1.00
06/12/2026 22:00	1.1	1.5	1	0.60	0.29778	0.99
06/12/2026 23:00	1.2	1.5	1	0.57	0.28488	0.95
Average/Sum#:	0.7	1.5	1	0.49	0.24492	0.82
Minimum:	0.5	1.5	0	0.42	0.21024	0.70
Maximum:	1.2	1.5	2	0.61	0.30438	1.01
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/13/2026 00:00	0.7	1.5	0	0.43	0.21336	0.71
06/13/2026 01:00	0.7	1.5	1	0.42	0.21204	0.71
06/13/2026 02:00	0.7	1.5	1	0.42	0.21138	0.70
06/13/2026 03:00	0.8	1.5	1	0.46	0.23112	0.77
06/13/2026 04:00	0.7	1.5	1	0.48	0.24132	0.80
06/13/2026 05:00	0.7	1.5	1	0.45	0.22434	0.75
06/13/2026 06:00	0.7	1.5	1	0.42	0.21174	0.71
06/13/2026 07:00	0.7	1.5	1	0.42	0.21180	0.71
06/13/2026 08:00	0.7	1.5	1	0.42	0.21144	0.70
06/13/2026 09:00	0.7	1.5	1	0.42	0.21102	0.70
06/13/2026 10:00	0.6	1.5	1	0.42	0.21072	0.70
06/13/2026 11:00	0.6	1.5	1	0.42	0.21144	0.70
06/13/2026 12:00	0.6	1.5	1	0.42	0.21156	0.71
06/13/2026 13:00	0.6	1.5	1	0.42	0.21144	0.70
06/13/2026 14:00	0.6	1.5	1	0.42	0.21126	0.70
06/13/2026 15:00	0.6	1.5	1	0.42	0.21096	0.70
06/13/2026 16:00	0.6	1.5	1	0.47	0.23538	0.78
06/13/2026 17:00	0.6	1.5	0	0.48	0.23880	0.80
06/13/2026 18:00	0.7	1.5	1	0.53	0.26310	0.88
06/13/2026 19:00	0.3	1.6	3	0.76	0.37758	1.26
06/13/2026 20:00	0.3	1.5	2	0.70	0.35202	1.17
06/13/2026 21:00	0.3	1.5	2	0.71	0.35442	1.18
06/13/2026 22:00	0.3	1.5	3	0.77	0.38292	1.28
06/13/2026 23:00	0.3	1.5	3	0.76	0.38178	1.27
Average/Sum#:	0.6	1.5	1	0.50	0.25137	0.84
Minimum:	0.3	1.5	0	0.42	0.21072	0.70
Maximum:	0.8	1.6	3	0.77	0.38292	1.28
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/14/2026 00:00	1.2	1.5	1	0.60	0.29874	1.00
06/14/2026 01:00	1.4	1.5	1	0.57	0.28518	0.95
06/14/2026 02:00	0.7	1.4	0	0.48	0.24108	0.80
06/14/2026 03:00	0.8	1.5	1	0.42	0.21222	0.71
06/14/2026 04:00	0.7	1.5	1	0.42	0.21234	0.71
06/14/2026 05:00	0.7	1.5	1	0.42	0.21246	0.71
06/14/2026 06:00	0.7	1.5	1	0.42	0.21234	0.71
06/14/2026 07:00	0.7	1.5	1	0.42	0.21246	0.71
06/14/2026 08:00	0.7	1.5	1	0.42	0.21216	0.71
06/14/2026 09:00	0.7	1.5	1	0.42	0.21174	0.71
06/14/2026 10:00	0.7	1.5	1	0.42	0.21138	0.70
06/14/2026 11:00	0.6	1.5	1	0.42	0.21174	0.71
06/14/2026 12:00	0.6	1.5	1	0.42	0.21162	0.71
06/14/2026 13:00	0.6	1.5	1	0.42	0.21150	0.71
06/14/2026 14:00	0.6	1.5	1	0.42	0.21126	0.70
06/14/2026 15:00	0.6	1.5	1	0.42	0.21072	0.70
06/14/2026 16:00	0.6	1.5	1	0.51	0.25278	0.84
06/14/2026 17:00	0.6	1.5	0	0.48	0.24162	0.81
06/14/2026 18:00	0.6	1.5	1	0.51	0.25578	0.85
06/14/2026 19:00	0.6	1.5	1	0.51	0.25536	0.85
06/14/2026 20:00	0.6	1.5	1	0.49	0.24714	0.82
06/14/2026 21:00	0.6	1.5	1	0.49	0.24300	0.81
06/14/2026 22:00	0.7	1.5	1	0.44	0.21840	0.73
06/14/2026 23:00	0.7	1.5	1	0.44	0.21960	0.73
Average/Sum#:	0.7	1.5	1	0.46	0.22969	0.77
Minimum:	0.6	1.4	0	0.42	0.21072	0.70
Maximum:	1.4	1.5	1	0.60	0.29874	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/15/2026 00:00	0.7	1.5	1	0.44	0.22074	0.74
06/15/2026 01:00	0.7	1.5	1	0.43	0.21288	0.71
06/15/2026 02:00	0.7	1.5	1	0.42	0.21120	0.70
06/15/2026 03:00	0.8	1.5	1	0.42	0.21150	0.71
06/15/2026 04:00	0.7	1.5	1	0.42	0.21174	0.71
06/15/2026 05:00	0.7	1.5	1	0.42	0.21180	0.71
06/15/2026 06:00	0.7	1.5	1	0.42	0.21168	0.71
06/15/2026 07:00	0.7	1.5	1	0.42	0.21186	0.71
06/15/2026 08:00	0.7	1.5	1	0.42	0.21150	0.71
06/15/2026 09:00	0.7	1.5	1	0.42	0.21144	0.70
06/15/2026 10:00	0.7	1.5	1	0.42	0.21132	0.70
06/15/2026 11:00	0.6	1.5	1	0.42	0.21162	0.71
06/15/2026 12:00	0.6	1.5	1	0.42	0.21168	0.71
06/15/2026 13:00	0.6	1.5	1	0.42	0.21162	0.71
06/15/2026 14:00	0.6	1.5	1	0.47	0.23364	0.78
06/15/2026 15:00	0.6	1.5	1	0.49	0.24570	0.82
06/15/2026 16:00	0.6	1.5	0	0.47	0.23442	0.78
06/15/2026 17:00	0.7	1.5	1	0.49	0.24324	0.81
06/15/2026 18:00	0.7	1.5	1	0.62	0.31230	1.04
06/15/2026 19:00	1.0	1.5	1	0.52	0.25848	0.86
06/15/2026 20:00	0.7	1.5	0	0.42	0.21228	0.71
06/15/2026 21:00	0.7	1.5	1	0.43	0.21348	0.71
06/15/2026 22:00	0.7	1.5	1	0.46	0.23028	0.77
06/15/2026 23:00	1.3	1.5	1	0.57	0.28650	0.96
Average/Sum#:	0.7	1.5	1	0.45	0.22679	0.76
Minimum:	0.6	1.5	0	0.42	0.21120	0.70
Maximum:	1.3	1.5	1	0.62	0.31230	1.04
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/16/2026 00:00	1.4	1.5	1	0.58	0.28866	0.96
06/16/2026 01:00	1.6	1.5	1	0.58	0.28800	0.96
06/16/2026 02:00	1.5	1.5	1	0.58	0.29082	0.97
06/16/2026 03:00	1.4	1.5	1	0.59	0.29364	0.98
06/16/2026 04:00	0.8	1.5	0	0.44	0.22158	0.74
06/16/2026 05:00	0.7	1.5	1	0.43	0.21264	0.71
06/16/2026 06:00	0.7	1.5	1	0.45	0.22698	0.76
06/16/2026 07:00	0.7	1.5	2	0.66	0.33198	1.11
06/16/2026 08:00	0.5	1.5	2	0.68	0.34020	1.13
06/16/2026 09:00	0.4	1.5	2	0.68	0.34062	1.14
06/16/2026 10:00	0.4	1.5	2	0.68	0.34110	1.14
06/16/2026 11:00	0.4	1.5	2	0.69	0.34266	1.14
06/16/2026 12:00	0.4	1.5	2	0.69	0.34374	1.15
06/16/2026 13:00	0.3	1.5	2	0.69	0.34512	1.15
06/16/2026 14:00	0.2	1.5	3	0.72	0.36246	1.21
06/16/2026 15:00	0.2	1.5	3	0.74	0.37068	1.24
06/16/2026 16:00	0.1	1.5	3	0.74	0.36942	1.23
06/16/2026 17:00	0.6	1.5	1	0.62	0.30996	1.03
06/16/2026 18:00	1.0	1.5	1	0.59	0.29658	0.99
06/16/2026 19:00	1.1	1.5	1	0.59	0.29454	0.98
06/16/2026 20:00	1.2	1.5	1	0.59	0.29274	0.98
06/16/2026 21:00	1.3	1.5	1	0.58	0.29100	0.97
06/16/2026 22:00	1.3	1.5	1	0.58	0.29154	0.97
06/16/2026 23:00	1.7	1.5	1	0.58	0.29088	0.97
Average/Sum#:	0.8	1.5	2	0.61	0.30740	1.03
Minimum:	0.1	1.5	0	0.43	0.21264	0.71
Maximum:	1.7	1.5	3	0.74	0.37068	1.24
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/17/2026 00:00	2.0	1.5	1	0.58	0.29022	0.97
06/17/2026 01:00	2.1	1.5	1	0.58	0.28950	0.97
06/17/2026 02:00	2.0	1.5	1	0.58	0.28926	0.96
06/17/2026 03:00	2.1	1.5	1	0.58	0.28950	0.97
06/17/2026 04:00	2.0	1.5	1	0.58	0.28950	0.97
06/17/2026 05:00	1.5	1.5	1	0.52	0.26076	0.87
06/17/2026 06:00	0.7	1.5	1	0.45	0.22584	0.75
06/17/2026 07:00	0.6	1.6	2	0.69	0.34710	1.16
06/17/2026 08:00	0.3	1.5	3	0.72	0.35874	1.20
06/17/2026 09:00	0.3	1.5	3	0.72	0.35994	1.20
06/17/2026 10:00	0.2	1.5	3	0.72	0.36186	1.21
06/17/2026 11:00	0.2	1.5	3	0.73	0.36444	1.21
06/17/2026 12:00	0.2	1.5	3	0.73	0.36588	1.22
06/17/2026 13:00	0.1	1.5	3	0.73	0.36672	1.22
06/17/2026 14:00	0.1	1.5	3	0.73	0.36714	1.22
06/17/2026 15:00	0.1	1.5	3	0.73	0.36708	1.22
06/17/2026 16:00	0.1	1.5	3	0.73	0.36696	1.22
06/17/2026 17:00	0.6	1.5	1	0.62	0.30984	1.03
06/17/2026 18:00	1.0	1.5	1	0.59	0.29556	0.99
06/17/2026 19:00	1.1	1.5	1	0.59	0.29352	0.98
06/17/2026 20:00	1.3	1.5	1	0.58	0.29148	0.97
06/17/2026 21:00	1.4	1.5	1	0.58	0.29058	0.97
06/17/2026 22:00	1.5	1.5	1	0.58	0.29004	0.97
06/17/2026 23:00	1.7	1.5	1	0.58	0.28896	0.96
Average/Sum#:	1.0	1.5	2	0.63	0.31752	1.06
Minimum:	0.1	1.5	1	0.45	0.22584	0.75
Maximum:	2.1	1.6	3	0.73	0.36714	1.22
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/18/2026 00:00	1.6	1.5	1	0.58	0.28896	0.96
06/18/2026 01:00	1.6	1.5	1	0.58	0.28920	0.96
06/18/2026 02:00	1.6	1.5	1	0.58	0.28944	0.96
06/18/2026 03:00	1.7	1.5	2	0.58	0.28980	0.97
06/18/2026 04:00	1.6	1.5	1	0.59	0.29514	0.98
06/18/2026 05:00	1.1	1.5	2	0.59	0.29334	0.98
06/18/2026 06:00	0.8	1.5	0	0.43	0.21282	0.71
06/18/2026 07:00	0.7	1.5	1	0.42	0.21204	0.71
06/18/2026 08:00	0.7	1.5	1	0.42	0.21174	0.71
06/18/2026 09:00	0.7	1.5	1	0.42	0.21156	0.71
06/18/2026 10:00	0.7	1.5	1	0.42	0.21138	0.70
06/18/2026 11:00	0.7	1.5	1	0.42	0.21204	0.71
06/18/2026 12:00	0.7	1.5	1	0.42	0.21216	0.71
06/18/2026 13:00	0.7	1.5	1	0.42	0.21204	0.71
06/18/2026 14:00	0.7	1.5	1	0.42	0.21192	0.71
06/18/2026 15:00	0.7	1.5	1	0.42	0.21186	0.71
06/18/2026 16:00	0.7	1.5	1	0.42	0.21198	0.71
06/18/2026 17:00	0.8	1.5	1	0.49	0.24510	0.82
06/18/2026 18:00	0.7	1.5	2	0.65	0.32292	1.08
06/18/2026 19:00	0.3	1.5	3	0.69	0.34674	1.16
06/18/2026 20:00	0.4	1.5	2	0.69	0.34272	1.14
06/18/2026 21:00	1.3	1.5	1	0.59	0.29250	0.98
06/18/2026 22:00	1.3	1.5	2	0.59	0.29568	0.99
06/18/2026 23:00	1.2	1.5	2	0.60	0.30240	1.01
Average/Sum#:	1.0	1.5	1	0.52	0.25940	0.87
Minimum:	0.3	1.5	0	0.42	0.21138	0.70
Maximum:	1.7	1.5	3	0.69	0.34674	1.16
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/19/2026 00:00	1.3	1.5	2	0.61	0.30408	1.01
06/19/2026 01:00	2.0	1.5	1	0.58	0.28992	0.97
06/19/2026 02:00	1.9	1.5	1	0.58	0.28944	0.96
06/19/2026 03:00	2.0	1.5	1	0.58	0.28896	0.96
06/19/2026 04:00	2.0	1.5	1	0.58	0.28884	0.96
06/19/2026 05:00	0.9	1.4	1	0.43	0.21504	0.72
06/19/2026 06:00	0.0	0.0	0	0.16	0.07986	0.27
06/19/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/19/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
06/19/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
06/19/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
06/19/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
06/19/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
06/19/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
06/19/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
06/19/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
06/19/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
06/19/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
06/19/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
06/19/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
06/19/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
06/19/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
06/19/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
06/19/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	1.4	1.3	1	0.50	0.25088	0.84
Minimum:	0.0	0.0	1	0.16	0.07986	0.27
Maximum:	2.0	1.5	2	0.61	0.30408	1.01
%SI	70.83	70.83	75.00	70.83	70.83	70.83

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/20/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
06/20/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
06/20/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
06/20/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
06/20/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
06/20/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
06/20/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
06/20/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/20/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
06/20/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
06/20/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
06/20/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
06/20/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
06/20/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
06/20/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
06/20/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
06/20/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
06/20/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
06/20/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
06/20/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
06/20/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
06/20/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
06/20/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
06/20/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/21/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
06/21/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
06/21/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
06/21/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
06/21/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
06/21/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
06/21/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
06/21/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/21/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
06/21/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
06/21/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
06/21/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
06/21/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
06/21/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
06/21/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
06/21/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
06/21/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
06/21/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
06/21/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
06/21/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
06/21/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
06/21/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
06/21/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
06/21/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/22/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
06/22/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
06/22/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
06/22/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
06/22/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
06/22/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
06/22/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
06/22/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/22/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
06/22/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
06/22/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
06/22/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
06/22/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
06/22/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
06/22/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
06/22/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
06/22/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
06/22/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
06/22/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
06/22/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
06/22/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
06/22/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
06/22/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
06/22/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/23/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
06/23/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
06/23/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
06/23/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
06/23/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
06/23/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
06/23/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
06/23/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/23/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
06/23/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
06/23/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
06/23/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
06/23/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
06/23/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
06/23/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
06/23/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
06/23/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
06/23/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
06/23/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
06/23/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
06/23/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
06/23/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
06/23/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
06/23/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/24/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
06/24/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
06/24/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
06/24/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
06/24/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
06/24/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
06/24/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
06/24/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/24/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
06/24/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
06/24/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
06/24/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
06/24/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
06/24/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
06/24/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
06/24/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
06/24/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
06/24/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
06/24/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
06/24/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
06/24/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
06/24/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
06/24/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
06/24/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/25/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
06/25/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
06/25/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
06/25/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
06/25/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
06/25/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
06/25/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
06/25/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/25/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
06/25/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
06/25/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
06/25/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
06/25/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
06/25/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
06/25/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
06/25/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
06/25/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
06/25/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
06/25/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
06/25/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
06/25/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
06/25/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
06/25/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
06/25/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/26/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
06/26/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
06/26/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
06/26/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
06/26/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
06/26/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
06/26/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
06/26/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/26/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
06/26/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
06/26/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
06/26/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
06/26/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
06/26/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
06/26/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
06/26/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
06/26/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
06/26/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
06/26/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
06/26/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
06/26/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
06/26/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
06/26/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
06/26/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/27/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
06/27/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
06/27/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
06/27/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
06/27/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
06/27/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
06/27/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
06/27/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/27/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
06/27/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
06/27/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
06/27/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
06/27/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
06/27/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
06/27/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
06/27/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
06/27/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
06/27/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
06/27/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
06/27/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
06/27/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
06/27/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
06/27/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
06/27/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/28/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
06/28/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
06/28/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
06/28/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
06/28/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
06/28/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
06/28/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
06/28/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/28/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
06/28/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
06/28/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
06/28/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
06/28/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
06/28/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
06/28/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
06/28/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
06/28/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
06/28/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
06/28/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
06/28/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
06/28/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
06/28/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
06/28/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
06/28/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/29/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
06/29/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
06/29/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
06/29/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
06/29/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
06/29/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
06/29/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
06/29/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/29/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
06/29/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
06/29/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
06/29/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
06/29/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
06/29/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
06/29/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
06/29/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
06/29/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
06/29/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
06/29/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
06/29/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
06/29/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
06/29/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
06/29/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
06/29/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
06/30/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
06/30/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
06/30/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
06/30/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
06/30/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
06/30/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
06/30/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
06/30/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/30/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
06/30/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
06/30/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
06/30/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
06/30/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
06/30/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
06/30/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
06/30/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
06/30/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
06/30/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
06/30/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
06/30/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
06/30/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
06/30/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
06/30/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
06/30/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/01/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2026 08:00	0.0	0.0	0	0.19	0.09342	0.31
04/01/2026 09:00	0.8	1.5	-3	0.47	0.23718	0.79
04/01/2026 10:00	0.8	1.5	-3	0.48	0.23868	0.80
04/01/2026 11:00	0.8	1.5	-2	0.48	0.23946	0.80
04/01/2026 12:00	0.8	1.5	-3	0.47	0.23676	0.79
04/01/2026 13:00	0.8	1.5	-3	0.44	0.21846	0.73
04/01/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/01/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.7	1.3	-3	0.42	0.21066	0.70
Minimum:	0.0	0.0	-3	0.19	0.09342	0.31
Maximum:	0.8	1.5	-2	0.48	0.23946	0.80
%SI	75.00	75.00	79.17	75.00	75.00	75.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/02/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/02/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/03/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/03/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/04/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/04/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/05/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/05/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/06/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/06/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/07/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/07/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/08/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/08/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/08/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/08/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/08/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/08/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/08/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/08/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/08/2026 08:00	0.0	0.0	0	0.22	0.10812	0.36
04/08/2026 09:00	0.0	0.0	0	0.48	0.23808	0.79
04/08/2026 10:00	0.8	1.5	-2	0.48	0.23970	0.80
04/08/2026 11:00	0.7	1.6	-2	0.59	0.29376	0.98
04/08/2026 12:00	0.6	1.5	-2	0.59	0.29436	0.98
04/08/2026 13:00	0.6	1.5	-2	0.59	0.29310	0.98
04/08/2026 14:00	0.6	1.5	-2	0.58	0.29202	0.97
04/08/2026 15:00	0.6	1.5	-1	0.57	0.28254	0.94
04/08/2026 16:00	0.0	0.0	0	0.22	0.10854	0.36
04/08/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/08/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/08/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/08/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/08/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/08/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/08/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.4	1.0	-2	0.48	0.23891	0.80
Minimum:	0.0	0.0	-2	0.22	0.10812	0.36
Maximum:	0.8	1.6	-1	0.59	0.29436	0.98
%SI	62.50	62.50	75.00	62.50	62.50	62.50

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/09/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/09/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/09/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/09/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/09/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/09/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/09/2026 06:00	0.0	0.0	0	0.23	0.11268	0.38
04/09/2026 07:00	0.8	1.7	-1	0.48	0.23922	0.80
04/09/2026 08:00	0.8	1.5	-3	0.47	0.23742	0.79
04/09/2026 09:00	0.7	1.5	-1	0.52	0.26058	0.87
04/09/2026 10:00	0.7	1.5	-3	0.49	0.24486	0.82
04/09/2026 11:00	0.7	1.5	-3	0.49	0.24372	0.81
04/09/2026 12:00	0.8	1.3	-2	0.32	0.16044	0.53
04/09/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/09/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/09/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/09/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/09/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/09/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/09/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/09/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/09/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/09/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/09/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.6	1.3	-2	0.43	0.21413	0.71
Minimum:	0.0	0.0	-3	0.23	0.11268	0.38
Maximum:	0.8	1.7	-1	0.52	0.26058	0.87
%SI	70.83	70.83	75.00	70.83	70.83	70.83

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/10/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/10/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/11/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/11/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/12/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/12/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/13/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/13/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/14/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/14/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/14/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/14/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/14/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/14/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/14/2026 06:00	0.0	0.0	0	0.23	0.11592	0.39
04/14/2026 07:00	0.8	1.6	-2	0.49	0.24342	0.81
04/14/2026 08:00	0.8	1.5	-2	0.49	0.24276	0.81
04/14/2026 09:00	0.7	1.5	-1	0.58	0.29232	0.97
04/14/2026 10:00	0.7	1.5	-2	0.49	0.24402	0.81
04/14/2026 11:00	0.7	1.5	-2	0.56	0.28008	0.93
04/14/2026 12:00	0.4	1.5	3	0.75	0.37512	1.25
04/14/2026 13:00	0.7	1.4	-2	0.54	0.26814	0.89
04/14/2026 14:00	0.7	1.4	-3	0.35	0.17376	0.58
04/14/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/14/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/14/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/14/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/14/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/14/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/14/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/14/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/14/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.6	1.3	-1	0.50	0.24839	0.83
Minimum:	0.0	0.0	-3	0.23	0.11592	0.39
Maximum:	0.8	1.6	3	0.75	0.37512	1.25
%SI	62.50	62.50	66.67	62.50	62.50	62.50

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/15/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/15/2026 22:00	0.0	0.0	0	0.30	0.15006	0.50
04/15/2026 23:00	0.7	1.5	-1	0.54	0.27024	0.90
Average/Sum#:	0.4	0.8	-1	0.42	0.21015	0.70
Minimum:	0.0	0.0	-1	0.30	0.15006	0.50
Maximum:	0.7	1.5	-1	0.54	0.27024	0.90
%SI	91.67	91.67	95.83	91.67	91.67	91.67

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/16/2026 00:00	0.7	1.6	0	0.61	0.30270	1.01
04/16/2026 01:00	0.7	1.5	-1	0.60	0.30192	1.01
04/16/2026 02:00	0.7	1.5	-1	0.59	0.29736	0.99
04/16/2026 03:00	0.7	1.5	-1	0.61	0.30414	1.01
04/16/2026 04:00	0.7	1.5	-1	0.61	0.30684	1.02
04/16/2026 05:00	0.7	1.5	-1	0.62	0.30858	1.03
04/16/2026 06:00	0.7	1.5	-2	0.59	0.29364	0.98
04/16/2026 07:00	0.7	1.5	-1	0.56	0.28140	0.94
04/16/2026 08:00	0.7	1.5	-1	0.58	0.28968	0.97
04/16/2026 09:00	0.7	1.5	-2	0.58	0.29112	0.97
04/16/2026 10:00	0.7	1.5	-2	0.58	0.29190	0.97
04/16/2026 11:00	0.7	1.5	-2	0.59	0.29268	0.98
04/16/2026 12:00	0.7	1.5	-2	0.59	0.29316	0.98
04/16/2026 13:00	0.7	1.5	-2	0.59	0.29400	0.98
04/16/2026 14:00	0.7	1.4	-2	0.54	0.27234	0.91
04/16/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/16/2026 16:00	0.0	0.0	0	0.22	0.11034	0.37
04/16/2026 17:00	0.8	1.5	-3	0.48	0.23988	0.80
04/16/2026 18:00	0.8	1.5	-2	0.47	0.23610	0.79
04/16/2026 19:00	0.8	1.5	-2	0.47	0.23604	0.79
04/16/2026 20:00	0.8	1.5	-2	0.47	0.23586	0.79
04/16/2026 21:00	0.8	1.5	-2	0.47	0.23622	0.79
04/16/2026 22:00	0.8	1.5	-2	0.47	0.23496	0.78
04/16/2026 23:00	0.8	1.5	-2	0.45	0.22710	0.76
Average/Sum#:	0.7	1.4	-2	0.54	0.26861	0.90
Minimum:	0.0	0.0	-3	0.22	0.11034	0.37
Maximum:	0.8	1.6	0	0.62	0.30858	1.03
%SI	4.17	4.17	8.33	4.17	4.17	4.17

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/17/2026 00:00	0.7	1.5	-1	0.55	0.27420	0.91
04/17/2026 01:00	0.7	1.5	-1	0.58	0.29022	0.97
04/17/2026 02:00	0.7	1.5	-1	0.58	0.29064	0.97
04/17/2026 03:00	0.7	1.5	-1	0.58	0.29184	0.97
04/17/2026 04:00	0.7	1.5	-2	0.58	0.29184	0.97
04/17/2026 05:00	0.7	1.5	-2	0.59	0.29256	0.98
04/17/2026 06:00	0.7	1.5	-1	0.59	0.29262	0.98
04/17/2026 07:00	0.7	1.5	-1	0.59	0.29280	0.98
04/17/2026 08:00	0.7	1.5	-1	0.59	0.29274	0.98
04/17/2026 09:00	0.7	1.5	-1	0.59	0.29292	0.98
04/17/2026 10:00	0.7	1.5	-1	0.59	0.29394	0.98
04/17/2026 11:00	0.7	1.5	-2	0.59	0.29364	0.98
04/17/2026 12:00	0.7	1.5	-2	0.58	0.29214	0.97
04/17/2026 13:00	0.7	1.5	-2	0.58	0.29076	0.97
04/17/2026 14:00	0.7	1.5	-2	0.58	0.28968	0.97
04/17/2026 15:00	0.6	1.5	-2	0.58	0.29076	0.97
04/17/2026 16:00	0.6	1.5	-2	0.58	0.29238	0.97
04/17/2026 17:00	0.6	1.5	-2	0.58	0.29208	0.97
04/17/2026 18:00	0.6	1.5	-2	0.58	0.29226	0.97
04/17/2026 19:00	0.7	1.5	-1	0.58	0.29244	0.97
04/17/2026 20:00	0.7	1.5	-1	0.58	0.29238	0.97
04/17/2026 21:00	0.7	1.5	-1	0.59	0.29256	0.98
04/17/2026 22:00	0.8	1.5	-1	0.59	0.29322	0.98
04/17/2026 23:00	0.8	1.5	-1	0.59	0.29364	0.98
Average/Sum#:	0.7	1.5	-1	0.58	0.29143	0.97
Minimum:	0.6	1.5	-2	0.55	0.27420	0.91
Maximum:	0.8	1.5	-1	0.59	0.29394	0.98
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/18/2026 00:00	0.8	1.5	-1	0.59	0.29352	0.98
04/18/2026 01:00	0.8	1.5	-1	0.59	0.29358	0.98
04/18/2026 02:00	0.8	1.5	-1	0.59	0.29334	0.98
04/18/2026 03:00	0.8	1.5	-1	0.58	0.29238	0.97
04/18/2026 04:00	0.8	1.5	-1	0.58	0.29208	0.97
04/18/2026 05:00	0.8	1.5	-1	0.58	0.29202	0.97
04/18/2026 06:00	0.8	1.5	-1	0.58	0.29226	0.97
04/18/2026 07:00	0.9	1.5	-2	0.52	0.26160	0.87
04/18/2026 08:00	0.9	1.5	-3	0.45	0.22656	0.76
04/18/2026 09:00	0.7	1.5	-2	0.53	0.26550	0.89
04/18/2026 10:00	0.7	1.5	-2	0.59	0.29316	0.98
04/18/2026 11:00	0.7	1.5	-2	0.58	0.29220	0.97
04/18/2026 12:00	0.6	1.5	-2	0.59	0.29346	0.98
04/18/2026 13:00	0.6	1.5	-2	0.59	0.29370	0.98
04/18/2026 14:00	0.6	1.5	-2	0.59	0.29388	0.98
04/18/2026 15:00	0.6	1.5	-2	0.59	0.29412	0.98
04/18/2026 16:00	0.6	1.5	-2	0.59	0.29376	0.98
04/18/2026 17:00	0.6	1.5	-2	0.59	0.29370	0.98
04/18/2026 18:00	0.6	1.5	-2	0.59	0.29346	0.98
04/18/2026 19:00	0.7	1.5	-1	0.59	0.29316	0.98
04/18/2026 20:00	0.7	1.5	-2	0.59	0.29322	0.98
04/18/2026 21:00	0.7	1.5	-2	0.59	0.29358	0.98
04/18/2026 22:00	0.7	1.5	-2	0.59	0.29406	0.98
04/18/2026 23:00	0.7	1.5	-2	0.59	0.29370	0.98
Average/Sum#:	0.7	1.5	-2	0.58	0.28800	0.96
Minimum:	0.6	1.5	-3	0.45	0.22656	0.76
Maximum:	0.9	1.5	-1	0.59	0.29412	0.98
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/19/2026 00:00	0.7	1.5	-1	0.59	0.29340	0.98
04/19/2026 01:00	0.7	1.5	-1	0.59	0.29400	0.98
04/19/2026 02:00	0.7	1.5	-2	0.59	0.29352	0.98
04/19/2026 03:00	0.7	1.5	-2	0.59	0.29352	0.98
04/19/2026 04:00	0.7	1.5	-1	0.59	0.29418	0.98
04/19/2026 05:00	0.7	1.5	-1	0.59	0.29328	0.98
04/19/2026 06:00	0.7	1.5	-1	0.59	0.29394	0.98
04/19/2026 07:00	0.7	1.5	-2	0.59	0.29448	0.98
04/19/2026 08:00	0.7	1.5	-2	0.59	0.29358	0.98
04/19/2026 09:00	0.7	1.5	-2	0.59	0.29394	0.98
04/19/2026 10:00	0.7	1.5	-2	0.59	0.29430	0.98
04/19/2026 11:00	0.6	1.5	-2	0.59	0.29460	0.98
04/19/2026 12:00	0.6	1.5	-2	0.59	0.29442	0.98
04/19/2026 13:00	0.6	1.5	-2	0.59	0.29460	0.98
04/19/2026 14:00	0.6	1.5	-2	0.59	0.29436	0.98
04/19/2026 15:00	0.6	1.5	-2	0.59	0.29466	0.98
04/19/2026 16:00	0.6	1.5	-2	0.59	0.29484	0.98
04/19/2026 17:00	0.6	1.5	-2	0.59	0.29394	0.98
04/19/2026 18:00	0.7	1.5	-2	0.59	0.29340	0.98
04/19/2026 19:00	0.7	1.5	-2	0.59	0.29322	0.98
04/19/2026 20:00	0.7	1.5	-2	0.59	0.29364	0.98
04/19/2026 21:00	0.7	1.5	-2	0.59	0.29358	0.98
04/19/2026 22:00	0.7	1.5	-1	0.59	0.29340	0.98
04/19/2026 23:00	0.7	1.5	-1	0.59	0.29346	0.98
Average/Sum#:	0.7	1.5	-2	0.59	0.29393	0.98
Minimum:	0.6	1.5	-2	0.59	0.29322	0.98
Maximum:	0.7	1.5	-1	0.59	0.29484	0.98
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/20/2026 00:00	0.7	1.5	-1	0.59	0.29352	0.98
04/20/2026 01:00	0.7	1.5	-1	0.59	0.29286	0.98
04/20/2026 02:00	0.7	1.5	-1	0.59	0.29256	0.98
04/20/2026 03:00	0.7	1.5	-2	0.58	0.29238	0.97
04/20/2026 04:00	0.7	1.5	-1	0.59	0.29250	0.98
04/20/2026 05:00	0.7	1.5	-1	0.59	0.29328	0.98
04/20/2026 06:00	0.8	1.5	-2	0.59	0.29328	0.98
04/20/2026 07:00	0.7	1.5	-2	0.59	0.29298	0.98
04/20/2026 08:00	0.7	1.5	-2	0.59	0.29412	0.98
04/20/2026 09:00	0.7	1.5	-2	0.59	0.29460	0.98
04/20/2026 10:00	0.8	1.5	-2	0.59	0.29340	0.98
04/20/2026 11:00	0.7	1.5	-2	0.58	0.29184	0.97
04/20/2026 12:00	0.7	1.5	-2	0.58	0.29142	0.97
04/20/2026 13:00	0.7	1.5	-2	0.59	0.29310	0.98
04/20/2026 14:00	0.7	1.5	-2	0.59	0.29424	0.98
04/20/2026 15:00	0.7	1.5	-2	0.59	0.29286	0.98
04/20/2026 16:00	0.7	1.5	-2	0.59	0.29256	0.98
04/20/2026 17:00	0.7	1.5	-1	0.59	0.29256	0.98
04/20/2026 18:00	0.7	1.5	-1	0.59	0.29256	0.98
04/20/2026 19:00	0.8	1.5	-2	0.59	0.29304	0.98
04/20/2026 20:00	0.9	1.5	-2	0.58	0.29232	0.97
04/20/2026 21:00	0.7	1.5	-2	0.59	0.29274	0.98
04/20/2026 22:00	0.7	1.5	-2	0.54	0.26898	0.90
04/20/2026 23:00	0.0	0.0	0	0.09	0.04362	0.15
Average/Sum#:	0.7	1.4	-2	0.57	0.28156	0.94
Minimum:	0.0	0.0	-2	0.09	0.04362	0.15
Maximum:	0.9	1.5	-1	0.59	0.29460	0.98
%SI	0.00	0.00	4.17	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/21/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/21/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/22/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/22/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/23/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/23/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/24/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/24/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/25/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/25/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/26/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/26/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/27/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/27/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/28/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/28/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/29/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/29/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
04/30/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
04/30/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/01/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/01/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/02/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/02/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/03/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/03/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/04/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/04/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/05/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/05/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/06/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/06/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/07/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/07/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/08/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/08/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/08/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/08/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/08/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/08/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/08/2026 06:00	0.0	0.0	0	0.28	0.13866	0.46
05/08/2026 07:00	0.9	1.6	-2	0.48	0.23850	0.80
05/08/2026 08:00	0.9	1.5	-2	0.47	0.23748	0.79
05/08/2026 09:00	0.7	1.5	-2	0.58	0.28764	0.96
05/08/2026 10:00	0.8	1.5	-1	0.57	0.28698	0.96
05/08/2026 11:00	0.8	1.5	-2	0.53	0.26694	0.89
05/08/2026 12:00	0.7	1.5	-1	0.56	0.27846	0.93
05/08/2026 13:00	0.8	1.5	-2	0.52	0.26196	0.87
05/08/2026 14:00	0.4	1.5	3	0.77	0.38430	1.28
05/08/2026 15:00	0.8	1.4	-1	0.43	0.21702	0.72
05/08/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/08/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/08/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/08/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/08/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/08/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/08/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/08/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.7	1.4	-1	0.52	0.25979	0.87
Minimum:	0.0	0.0	-2	0.28	0.13866	0.46
Maximum:	0.9	1.6	3	0.77	0.38430	1.28
%SI	58.33	58.33	62.50	58.33	58.33	58.33

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/09/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/09/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/09/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/09/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/09/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/09/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/09/2026 06:00	0.0	0.0	0	0.25	0.12480	0.42
05/09/2026 07:00	0.9	1.5	-2	0.46	0.23112	0.77
05/09/2026 08:00	0.9	1.5	-2	0.46	0.22944	0.76
05/09/2026 09:00	0.9	1.5	-2	0.46	0.22944	0.76
05/09/2026 10:00	0.8	1.5	-2	0.46	0.22920	0.76
05/09/2026 11:00	0.8	1.5	-2	0.46	0.22890	0.76
05/09/2026 12:00	0.8	1.5	-2	0.45	0.22428	0.75
05/09/2026 13:00	0.0	0.0	0	0.20	0.09876	0.33
05/09/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/09/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/09/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/09/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/09/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/09/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/09/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/09/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/09/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/09/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.6	1.1	-2	0.40	0.19949	0.66
Minimum:	0.0	0.0	-2	0.20	0.09876	0.33
Maximum:	0.9	1.5	-2	0.46	0.23112	0.77
%SI	66.67	66.67	75.00	66.67	66.67	66.67

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/10/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/10/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/10/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/10/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/10/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/10/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/10/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/10/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/10/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/10/2026 09:00	0.0	0.0	0	0.20	0.10116	0.34
05/10/2026 10:00	0.7	1.7	-1	0.49	0.24294	0.81
05/10/2026 11:00	0.7	1.5	-1	0.52	0.25848	0.86
05/10/2026 12:00	0.7	1.5	-1	0.56	0.27840	0.93
05/10/2026 13:00	0.7	1.5	-1	0.56	0.28068	0.94
05/10/2026 14:00	0.5	1.5	6	0.80	0.39912	1.33
05/10/2026 15:00	0.8	1.4	-2	0.49	0.24318	0.81
05/10/2026 16:00	0.0	0.0	0	0.21	0.10434	0.35
05/10/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/10/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/10/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/10/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/10/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/10/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/10/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.5	1.1	0	0.48	0.23854	0.80
Minimum:	0.0	0.0	-2	0.20	0.10116	0.34
Maximum:	0.8	1.7	6	0.80	0.39912	1.33
%SI	66.67	66.67	75.00	66.67	66.67	66.67

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/11/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/11/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/11/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/11/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/11/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/11/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/11/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/11/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/11/2026 08:00	0.0	0.0	0	0.17	0.08556	0.29
05/11/2026 09:00	0.8	1.6	1	0.47	0.23274	0.78
05/11/2026 10:00	0.8	1.5	-1	0.52	0.25968	0.87
05/11/2026 11:00	0.7	1.6	-1	0.57	0.28608	0.95
05/11/2026 12:00	0.7	1.5	-1	0.56	0.28248	0.94
05/11/2026 13:00	0.4	1.6	5	0.77	0.38448	1.28
05/11/2026 14:00	0.7	1.5	-1	0.56	0.28116	0.94
05/11/2026 15:00	0.7	1.5	-1	0.52	0.25926	0.86
05/11/2026 16:00	0.0	0.0	0	0.08	0.04098	0.14
05/11/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/11/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/11/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/11/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/11/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/11/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/11/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.5	1.2	0	0.47	0.23471	0.78
Minimum:	0.0	0.0	-1	0.08	0.04098	0.14
Maximum:	0.8	1.6	5	0.77	0.38448	1.28
%SI	62.50	62.50	70.83	62.50	62.50	62.50

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/12/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/12/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/12/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/12/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/12/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/12/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/12/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/12/2026 07:00	0.0	0.0	0	0.38	0.19044	0.63
05/12/2026 08:00	0.9	1.5	-1	0.46	0.22806	0.76
05/12/2026 09:00	0.9	1.5	-1	0.45	0.22734	0.76
05/12/2026 10:00	0.7	1.5	-1	0.51	0.25728	0.86
05/12/2026 11:00	0.7	1.5	-1	0.52	0.26130	0.87
05/12/2026 12:00	0.8	1.5	-1	0.48	0.23976	0.80
05/12/2026 13:00	0.7	1.5	-1	0.49	0.24666	0.82
05/12/2026 14:00	0.7	1.5	2	0.66	0.32802	1.09
05/12/2026 15:00	0.4	1.5	2	0.72	0.35892	1.20
05/12/2026 16:00	0.9	1.5	0	0.58	0.29106	0.97
05/12/2026 17:00	0.8	1.5	0	0.46	0.23088	0.77
05/12/2026 18:00	0.7	1.5	-1	0.52	0.25992	0.87
05/12/2026 19:00	0.7	1.5	0	0.53	0.26718	0.89
05/12/2026 20:00	0.0	0.0	0	0.11	0.05532	0.18
05/12/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/12/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/12/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.6	1.3	0	0.49	0.24587	0.82
Minimum:	0.0	0.0	-1	0.11	0.05532	0.18
Maximum:	0.9	1.5	2	0.72	0.35892	1.20
%SI	41.67	41.67	50.00	41.67	41.67	41.67

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/13/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/13/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/14/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/14/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/15/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/15/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/15/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/15/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/15/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/15/2026 05:00	0.0	0.0	0	0.22	0.10782	0.36
05/15/2026 06:00	0.8	1.3	-1	0.47	0.23382	0.78
05/15/2026 07:00	0.8	1.5	-2	0.46	0.23238	0.77
05/15/2026 08:00	0.7	1.5	-1	0.49	0.24672	0.82
05/15/2026 09:00	0.7	1.5	0	0.56	0.28164	0.94
05/15/2026 10:00	0.7	1.5	-1	0.55	0.27390	0.91
05/15/2026 11:00	0.6	1.5	-1	0.55	0.27708	0.92
05/15/2026 12:00	0.8	1.5	1	0.64	0.32196	1.07
05/15/2026 13:00	0.2	1.5	3	0.75	0.37650	1.26
05/15/2026 14:00	0.6	1.5	1	0.66	0.33234	1.11
05/15/2026 15:00	0.7	1.5	-1	0.51	0.25290	0.84
05/15/2026 16:00	0.7	1.5	0	0.57	0.28320	0.94
05/15/2026 17:00	0.7	1.5	0	0.54	0.27150	0.91
05/15/2026 18:00	0.0	0.0	0	0.24	0.12180	0.41
05/15/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/15/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/15/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/15/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/15/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.6	1.3	0	0.52	0.25811	0.86
Minimum:	0.0	0.0	-2	0.22	0.10782	0.36
Maximum:	0.8	1.5	3	0.75	0.37650	1.26
%SI	41.67	41.67	50.00	41.67	41.67	41.67

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/16/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/16/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/17/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/17/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/18/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/18/2026 22:00	0.0	0.0	0	0.09	0.04446	0.15
05/18/2026 23:00	0.0	0.0	0	0.52	0.26208	0.87
Average/Sum#:	0.0	0.0	0	0.31	0.15327	0.51
Minimum:	0.0	0.0	0	0.09	0.04446	0.15
Maximum:	0.0	0.0	0	0.52	0.26208	0.87
%SI	91.67	91.67	100.00	91.67	91.67	91.67

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/19/2026 00:00	0.7	1.5	-2	0.56	0.27996	0.93
05/19/2026 01:00	0.7	1.5	-2	0.59	0.29496	0.98
05/19/2026 02:00	0.7	1.4	-2	0.59	0.29286	0.98
05/19/2026 03:00	0.7	1.6	-1	0.59	0.29370	0.98
05/19/2026 04:00	0.7	1.5	-2	0.56	0.27888	0.93
05/19/2026 05:00	0.8	1.4	-2	0.48	0.23826	0.79
05/19/2026 06:00	0.8	1.5	-2	0.45	0.22470	0.75
05/19/2026 07:00	0.8	1.5	-2	0.39	0.19374	0.65
05/19/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/19/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/19/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/19/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/19/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/19/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/19/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/19/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/19/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/19/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/19/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/19/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/19/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/19/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/19/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/19/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.7	1.5	-2	0.53	0.26213	0.87
Minimum:	0.7	1.4	-2	0.39	0.19374	0.65
Maximum:	0.8	1.6	-1	0.59	0.29496	0.98
%SI	66.67	66.67	66.67	66.67	66.67	66.67

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/20/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/20/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/20/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/20/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/20/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/20/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/20/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/20/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/20/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/20/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/20/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/20/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/20/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/20/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/20/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/20/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/20/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/20/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/20/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/20/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/20/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/20/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/20/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/20/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/21/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/21/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/21/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/21/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/21/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/21/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/21/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/21/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/21/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/21/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/21/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/21/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/21/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/21/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/21/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/21/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/21/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/21/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/21/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/21/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/21/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/21/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/21/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/21/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/22/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
05/22/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
05/22/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
05/22/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
05/22/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
05/22/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
05/22/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
05/22/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
05/22/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
05/22/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
05/22/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
05/22/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
05/22/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
05/22/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
05/22/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
05/22/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
05/22/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
05/22/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
05/22/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
05/22/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
05/22/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
05/22/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
05/22/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
05/22/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/23/2026 00:00	0.0	0.0	0	0.17	0.08592	0.29
05/23/2026 01:00	0.9	1.6	-2	0.46	0.23190	0.77
05/23/2026 02:00	0.8	1.5	-3	0.45	0.22584	0.75
05/23/2026 03:00	0.8	1.5	-2	0.47	0.23562	0.79
05/23/2026 04:00	0.7	1.5	-2	0.55	0.27744	0.92
05/23/2026 05:00	0.8	1.3	-2	0.48	0.24000	0.80
05/23/2026 06:00	0.8	1.5	-3	0.46	0.22872	0.76
05/23/2026 07:00	0.8	1.5	-2	0.46	0.22848	0.76
05/23/2026 08:00	0.8	1.5	-1	0.46	0.22860	0.76
05/23/2026 09:00	0.8	1.5	-1	0.46	0.22920	0.76
05/23/2026 10:00	0.8	1.5	-1	0.46	0.22974	0.77
05/23/2026 11:00	0.8	1.5	-1	0.46	0.22920	0.76
05/23/2026 12:00	0.8	1.5	-1	0.46	0.22800	0.76
05/23/2026 13:00	0.8	1.5	-1	0.46	0.22782	0.76
05/23/2026 14:00	0.8	1.5	-1	0.46	0.22752	0.76
05/23/2026 15:00	0.7	1.5	-1	0.45	0.22722	0.76
05/23/2026 16:00	0.7	1.5	-1	0.45	0.22746	0.76
05/23/2026 17:00	0.8	1.5	-1	0.46	0.22770	0.76
05/23/2026 18:00	0.8	1.5	-1	0.46	0.22758	0.76
05/23/2026 19:00	0.8	1.5	-1	0.46	0.22764	0.76
05/23/2026 20:00	0.8	1.5	-2	0.46	0.22758	0.76
05/23/2026 21:00	0.8	1.5	-2	0.45	0.22740	0.76
05/23/2026 22:00	0.9	1.5	-2	0.45	0.22746	0.76
05/23/2026 23:00	0.9	1.5	-3	0.46	0.22812	0.76
Average/Sum#:	0.8	1.4	-2	0.45	0.22509	0.75
Minimum:	0.0	0.0	-3	0.17	0.08592	0.29
Maximum:	0.9	1.6	-1	0.55	0.27744	0.92
%SI	0.00	0.00	4.17	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/24/2026 00:00	0.9	1.5	-3	0.46	0.22836	0.76
05/24/2026 01:00	0.9	1.5	-3	0.46	0.22842	0.76
05/24/2026 02:00	0.9	1.4	-3	0.46	0.22878	0.76
05/24/2026 03:00	0.9	1.5	-2	0.46	0.23040	0.77
05/24/2026 04:00	0.9	1.5	-3	0.46	0.23070	0.77
05/24/2026 05:00	0.9	1.5	-3	0.46	0.23088	0.77
05/24/2026 06:00	0.9	1.5	-3	0.46	0.23118	0.77
05/24/2026 07:00	0.9	1.5	-3	0.46	0.22956	0.77
05/24/2026 08:00	0.8	1.5	-1	0.46	0.22920	0.76
05/24/2026 09:00	0.8	1.5	-1	0.46	0.22962	0.77
05/24/2026 10:00	0.8	1.5	-1	0.46	0.22980	0.77
05/24/2026 11:00	0.8	1.5	-1	0.46	0.22782	0.76
05/24/2026 12:00	0.8	1.5	-1	0.45	0.22716	0.76
05/24/2026 13:00	0.8	1.5	-1	0.45	0.22704	0.76
05/24/2026 14:00	0.8	1.5	-1	0.45	0.22716	0.76
05/24/2026 15:00	0.8	1.5	-1	0.46	0.22758	0.76
05/24/2026 16:00	0.8	1.5	-1	0.46	0.22752	0.76
05/24/2026 17:00	0.8	1.5	-1	0.46	0.22764	0.76
05/24/2026 18:00	0.8	1.5	-1	0.46	0.22770	0.76
05/24/2026 19:00	0.8	1.5	-1	0.46	0.22764	0.76
05/24/2026 20:00	0.9	1.5	-2	0.46	0.22764	0.76
05/24/2026 21:00	0.9	1.5	-2	0.46	0.22860	0.76
05/24/2026 22:00	0.9	1.5	-3	0.46	0.22866	0.76
05/24/2026 23:00	0.9	1.5	-3	0.46	0.22890	0.76
Average/Sum#:	0.9	1.5	-2	0.46	0.22867	0.76
Minimum:	0.8	1.4	-3	0.45	0.22704	0.76
Maximum:	0.9	1.5	-1	0.46	0.23118	0.77
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/25/2026 00:00	0.9	1.5	-3	0.46	0.22884	0.76
05/25/2026 01:00	0.9	1.5	-4	0.46	0.22878	0.76
05/25/2026 02:00	0.9	1.5	-3	0.46	0.22842	0.76
05/25/2026 03:00	0.9	1.5	-3	0.46	0.22944	0.76
05/25/2026 04:00	0.9	1.5	-3	0.46	0.22938	0.76
05/25/2026 05:00	0.9	1.5	-3	0.46	0.22998	0.77
05/25/2026 06:00	0.9	1.5	-3	0.46	0.22848	0.76
05/25/2026 07:00	0.9	1.5	-3	0.45	0.22698	0.76
05/25/2026 08:00	0.9	1.5	-2	0.46	0.22776	0.76
05/25/2026 09:00	0.9	1.5	-2	0.46	0.22788	0.76
05/25/2026 10:00	0.9	1.5	-2	0.45	0.22668	0.76
05/25/2026 11:00	0.8	1.5	-2	0.45	0.22656	0.76
05/25/2026 12:00	0.8	1.5	-2	0.45	0.22674	0.76
05/25/2026 13:00	0.8	1.5	-1	0.45	0.22728	0.76
05/25/2026 14:00	0.8	1.5	-1	0.45	0.22734	0.76
05/25/2026 15:00	0.8	1.5	-1	0.45	0.22716	0.76
05/25/2026 16:00	0.8	1.5	-1	0.45	0.22722	0.76
05/25/2026 17:00	0.8	1.5	-2	0.45	0.22716	0.76
05/25/2026 18:00	0.9	1.5	-2	0.45	0.22734	0.76
05/25/2026 19:00	0.9	1.5	-3	0.45	0.22722	0.76
05/25/2026 20:00	0.9	1.5	-3	0.46	0.22758	0.76
05/25/2026 21:00	0.9	1.5	-3	0.46	0.22764	0.76
05/25/2026 22:00	0.9	1.5	-3	0.46	0.22776	0.76
05/25/2026 23:00	0.9	1.5	-3	0.46	0.22920	0.76
Average/Sum#:	0.9	1.5	-2	0.46	0.22787	0.76
Minimum:	0.8	1.5	-4	0.45	0.22656	0.76
Maximum:	0.9	1.5	-1	0.46	0.22998	0.77
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/26/2026 00:00	0.9	1.5	-3	0.46	0.22956	0.77
05/26/2026 01:00	0.9	1.5	-3	0.46	0.22962	0.77
05/26/2026 02:00	0.9	1.5	-3	0.46	0.23070	0.77
05/26/2026 03:00	0.9	1.5	-2	0.46	0.23100	0.77
05/26/2026 04:00	0.9	1.5	-3	0.46	0.23094	0.77
05/26/2026 05:00	0.9	1.5	-3	0.46	0.22872	0.76
05/26/2026 06:00	0.8	1.7	-1	0.50	0.24774	0.83
05/26/2026 07:00	0.8	1.6	-2	0.53	0.26724	0.89
05/26/2026 08:00	0.9	1.5	-3	0.46	0.22800	0.76
05/26/2026 09:00	0.9	1.5	-2	0.46	0.22776	0.76
05/26/2026 10:00	0.8	1.5	-1	0.49	0.24324	0.81
05/26/2026 11:00	0.8	1.4	-1	0.46	0.23112	0.77
05/26/2026 12:00	0.9	1.7	3	0.46	0.22764	0.76
05/26/2026 13:00	0.8	0.3	0	0.46	0.22782	0.76
05/26/2026 14:00	0.9	1.4	-2	0.46	0.22764	0.76
05/26/2026 15:00	0.8	1.5	-1	0.45	0.22746	0.76
05/26/2026 16:00	0.8	1.5	-2	0.46	0.22782	0.76
05/26/2026 17:00	0.8	1.5	-3	0.47	0.23520	0.78
05/26/2026 18:00	0.8	1.5	-2	0.47	0.23526	0.78
05/26/2026 19:00	0.9	1.5	-2	0.45	0.22746	0.76
05/26/2026 20:00	0.9	1.5	-3	0.45	0.22728	0.76
05/26/2026 21:00	0.9	1.5	-3	0.45	0.22716	0.76
05/26/2026 22:00	0.9	1.5	-3	0.46	0.22818	0.76
05/26/2026 23:00	0.8	1.5	-2	0.55	0.27504	0.92
Average/Sum#:	0.9	1.5	-2	0.47	0.23415	0.78
Minimum:	0.8	0.3	-3	0.45	0.22716	0.76
Maximum:	0.9	1.7	3	0.55	0.27504	0.92
%SI	4.17	4.17	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/27/2026 00:00	0.7	1.5	-3	0.55	0.27528	0.92
05/27/2026 01:00	0.8	1.5	-2	0.54	0.27204	0.91
05/27/2026 02:00	0.9	1.7	-2	0.49	0.24576	0.82
05/27/2026 03:00	0.8	1.4	-1	0.54	0.27156	0.91
05/27/2026 04:00	1.0	1.5	-2	0.54	0.26814	0.89
05/27/2026 05:00	1.0	1.4	-2	0.51	0.25398	0.85
05/27/2026 06:00	0.9	1.5	-3	0.45	0.22638	0.75
05/27/2026 07:00	0.8	1.4	-2	0.49	0.24552	0.82
05/27/2026 08:00	0.9	1.5	-2	0.45	0.22650	0.76
05/27/2026 09:00	0.9	1.5	-2	0.45	0.22608	0.75
05/27/2026 10:00	0.9	1.5	-2	0.45	0.22602	0.75
05/27/2026 11:00	0.9	1.5	-2	0.45	0.22638	0.75
05/27/2026 12:00	0.9	1.5	-1	0.45	0.22644	0.75
05/27/2026 13:00	0.9	1.5	-2	0.45	0.22614	0.75
05/27/2026 14:00	0.8	1.5	-2	0.45	0.22632	0.75
05/27/2026 15:00	0.8	1.5	-1	0.49	0.24744	0.82
05/27/2026 16:00	0.8	1.5	-1	0.45	0.22734	0.76
05/27/2026 17:00	0.8	1.5	-1	0.50	0.24762	0.83
05/27/2026 18:00	0.7	1.5	-1	0.55	0.27360	0.91
05/27/2026 19:00	0.7	1.5	-1	0.53	0.26592	0.89
05/27/2026 20:00	0.7	1.5	-1	0.55	0.27624	0.92
05/27/2026 21:00	0.7	1.5	-1	0.55	0.27744	0.92
05/27/2026 22:00	0.9	1.5	-2	0.47	0.23532	0.78
05/27/2026 23:00	0.7	1.5	-2	0.55	0.27570	0.92
Average/Sum#:	0.8	1.5	-2	0.50	0.24872	0.83
Minimum:	0.7	1.4	-3	0.45	0.22602	0.75
Maximum:	1.0	1.7	-1	0.55	0.27744	0.92
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/28/2026 00:00	0.8	1.5	-2	0.55	0.27354	0.91
05/28/2026 01:00	0.9	1.5	-2	0.47	0.23370	0.78
05/28/2026 02:00	0.8	1.6	-2	0.49	0.24402	0.81
05/28/2026 03:00	0.9	1.5	-2	0.46	0.22812	0.76
05/28/2026 04:00	0.9	1.5	-3	0.46	0.22776	0.76
05/28/2026 05:00	0.9	1.5	-3	0.46	0.22764	0.76
05/28/2026 06:00	0.9	1.5	-3	0.46	0.23202	0.77
05/28/2026 07:00	0.8	1.5	-2	0.52	0.26076	0.87
05/28/2026 08:00	0.8	1.5	-2	0.49	0.24630	0.82
05/28/2026 09:00	0.8	1.5	-2	0.51	0.25626	0.85
05/28/2026 10:00	0.7	1.5	-1	0.53	0.26376	0.88
05/28/2026 11:00	0.9	1.5	-2	0.46	0.22806	0.76
05/28/2026 12:00	0.8	1.5	-2	0.46	0.22842	0.76
05/28/2026 13:00	0.8	1.5	-1	0.46	0.23226	0.77
05/28/2026 14:00	0.9	1.5	-1	0.46	0.22776	0.76
05/28/2026 15:00	0.8	1.5	-1	0.46	0.22770	0.76
05/28/2026 16:00	0.8	1.5	-1	0.46	0.22770	0.76
05/28/2026 17:00	0.8	1.5	-2	0.46	0.22794	0.76
05/28/2026 18:00	0.7	1.5	-1	0.53	0.26274	0.88
05/28/2026 19:00	0.8	1.5	-2	0.46	0.22812	0.76
05/28/2026 20:00	0.7	1.5	-1	0.55	0.27510	0.92
05/28/2026 21:00	0.7	1.5	-2	0.56	0.27768	0.93
05/28/2026 22:00	0.7	1.5	-2	0.55	0.27366	0.91
05/28/2026 23:00	0.7	1.5	-2	0.49	0.24378	0.81
Average/Sum#:	0.8	1.5	-2	0.49	0.24395	0.81
Minimum:	0.7	1.5	-3	0.46	0.22764	0.76
Maximum:	0.9	1.6	-1	0.56	0.27768	0.93
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/29/2026 00:00	0.8	1.5	-3	0.46	0.22794	0.76
05/29/2026 01:00	0.8	1.5	-3	0.46	0.22896	0.76
05/29/2026 02:00	0.8	1.5	-3	0.46	0.22902	0.76
05/29/2026 03:00	0.8	1.5	-3	0.46	0.22914	0.76
05/29/2026 04:00	0.8	1.5	-3	0.46	0.22908	0.76
05/29/2026 05:00	0.8	1.5	-3	0.46	0.22866	0.76
05/29/2026 06:00	0.8	1.5	-3	0.46	0.22818	0.76
05/29/2026 07:00	0.8	1.5	-3	0.46	0.22836	0.76
05/29/2026 08:00	0.8	1.5	-3	0.46	0.22806	0.76
05/29/2026 09:00	0.8	1.5	-2	0.46	0.22818	0.76
05/29/2026 10:00	0.8	1.5	-2	0.46	0.22848	0.76
05/29/2026 11:00	0.7	1.5	-2	0.46	0.22914	0.76
05/29/2026 12:00	0.7	1.5	-2	0.46	0.22908	0.76
05/29/2026 13:00	0.7	1.5	-2	0.46	0.22842	0.76
05/29/2026 14:00	0.7	1.5	-2	0.46	0.22848	0.76
05/29/2026 15:00	0.7	1.5	-1	0.46	0.22830	0.76
05/29/2026 16:00	0.7	1.5	-1	0.46	0.22908	0.76
05/29/2026 17:00	0.7	1.5	-1	0.46	0.22866	0.76
05/29/2026 18:00	0.7	1.5	-1	0.46	0.22920	0.76
05/29/2026 19:00	0.7	1.5	-2	0.46	0.22896	0.76
05/29/2026 20:00	0.8	1.5	-3	0.46	0.22818	0.76
05/29/2026 21:00	0.7	1.5	-2	0.46	0.22890	0.76
05/29/2026 22:00	0.7	1.5	-2	0.46	0.22968	0.77
05/29/2026 23:00	0.7	1.5	-2	0.46	0.22986	0.77
Average/Sum#:	0.8	1.5	-2	0.46	0.22875	0.76
Minimum:	0.7	1.5	-3	0.46	0.22794	0.76
Maximum:	0.8	1.5	-1	0.46	0.22986	0.77
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/30/2026 00:00	0.8	1.5	-3	0.46	0.22938	0.76
05/30/2026 01:00	0.8	1.5	-3	0.46	0.22950	0.77
05/30/2026 02:00	0.8	1.5	-3	0.46	0.22902	0.76
05/30/2026 03:00	0.8	1.5	-3	0.46	0.22878	0.76
05/30/2026 04:00	0.8	1.5	-3	0.46	0.22920	0.76
05/30/2026 05:00	0.8	1.5	-3	0.46	0.22896	0.76
05/30/2026 06:00	0.8	1.5	-3	0.46	0.22836	0.76
05/30/2026 07:00	0.8	1.5	-2	0.46	0.22824	0.76
05/30/2026 08:00	0.7	1.5	-1	0.46	0.22872	0.76
05/30/2026 09:00	0.7	1.5	-1	0.46	0.22920	0.76
05/30/2026 10:00	0.7	1.5	-1	0.46	0.22920	0.76
05/30/2026 11:00	0.7	1.5	-1	0.46	0.22800	0.76
05/30/2026 12:00	0.7	1.5	-1	0.46	0.22788	0.76
05/30/2026 13:00	0.7	1.5	-2	0.46	0.22770	0.76
05/30/2026 14:00	0.7	1.5	-1	0.45	0.22740	0.76
05/30/2026 15:00	0.7	1.5	-1	0.45	0.22716	0.76
05/30/2026 16:00	0.7	1.5	-1	0.45	0.22698	0.76
05/30/2026 17:00	0.7	1.5	-1	0.45	0.22626	0.75
05/30/2026 18:00	0.7	1.5	-1	0.45	0.22560	0.75
05/30/2026 19:00	0.7	1.5	-1	0.46	0.22848	0.76
05/30/2026 20:00	0.8	1.5	-1	0.46	0.22962	0.77
05/30/2026 21:00	0.7	1.5	-1	0.46	0.22938	0.76
05/30/2026 22:00	0.8	1.5	-1	0.46	0.22956	0.77
05/30/2026 23:00	0.8	1.5	-2	0.46	0.22944	0.76
Average/Sum#:	0.7	1.5	-2	0.46	0.22842	0.76
Minimum:	0.7	1.5	-3	0.45	0.22560	0.75
Maximum:	0.8	1.5	-1	0.46	0.22962	0.77
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
05/31/2026 00:00	0.8	1.5	-2	0.46	0.22872	0.76
05/31/2026 01:00	0.8	1.5	-2	0.46	0.22890	0.76
05/31/2026 02:00	0.8	1.5	-2	0.46	0.22854	0.76
05/31/2026 03:00	0.8	1.5	-2	0.46	0.22842	0.76
05/31/2026 04:00	0.8	1.5	-3	0.46	0.22890	0.76
05/31/2026 05:00	0.8	1.5	-2	0.46	0.22872	0.76
05/31/2026 06:00	0.8	1.5	-1	0.46	0.22842	0.76
05/31/2026 07:00	0.8	1.5	-1	0.46	0.22830	0.76
05/31/2026 08:00	0.7	1.5	-1	0.46	0.22866	0.76
05/31/2026 09:00	0.7	1.5	-1	0.46	0.22788	0.76
05/31/2026 10:00	0.7	1.5	-1	0.45	0.22698	0.76
05/31/2026 11:00	0.7	1.5	-1	0.45	0.22728	0.76
05/31/2026 12:00	0.7	1.5	-1	0.45	0.22704	0.76
05/31/2026 13:00	0.7	1.5	-1	0.45	0.22692	0.76
05/31/2026 14:00	0.7	1.5	-1	0.45	0.22686	0.76
05/31/2026 15:00	0.6	1.5	-1	0.45	0.22662	0.76
05/31/2026 16:00	0.7	1.5	-1	0.45	0.22638	0.75
05/31/2026 17:00	0.7	1.5	-1	0.46	0.23142	0.77
05/31/2026 18:00	0.7	1.5	-1	0.45	0.22572	0.75
05/31/2026 19:00	0.7	1.5	-1	0.45	0.22554	0.75
05/31/2026 20:00	0.7	1.5	-1	0.45	0.22572	0.75
05/31/2026 21:00	0.8	1.5	-1	0.45	0.22584	0.75
05/31/2026 22:00	0.8	1.5	-1	0.45	0.22560	0.75
05/31/2026 23:00	0.8	1.5	-2	0.45	0.22590	0.75
Average/Sum#:	0.7	1.5	-1	0.45	0.22747	0.76
Minimum:	0.6	1.5	-3	0.45	0.22554	0.75
Maximum:	0.8	1.5	-1	0.46	0.23142	0.77
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/01/2026 00:00	0.8	1.5	-2	0.45	0.22572	0.75
06/01/2026 01:00	0.8	1.5	-2	0.45	0.22680	0.76
06/01/2026 02:00	0.8	1.5	-2	0.45	0.22698	0.76
06/01/2026 03:00	0.8	1.5	-2	0.46	0.22752	0.76
06/01/2026 04:00	0.8	1.5	-3	0.46	0.22884	0.76
06/01/2026 05:00	0.8	1.5	-2	0.46	0.22896	0.76
06/01/2026 06:00	0.8	1.5	-1	0.46	0.22890	0.76
06/01/2026 07:00	0.8	1.5	-1	0.46	0.22800	0.76
06/01/2026 08:00	0.8	1.5	-1	0.45	0.22668	0.76
06/01/2026 09:00	0.8	1.5	-1	0.45	0.22644	0.75
06/01/2026 10:00	0.7	1.5	-1	0.45	0.22698	0.76
06/01/2026 11:00	0.7	1.5	-1	0.45	0.22722	0.76
06/01/2026 12:00	0.7	1.5	-1	0.45	0.22692	0.76
06/01/2026 13:00	0.7	1.5	-1	0.45	0.22650	0.76
06/01/2026 14:00	0.7	1.5	0	0.45	0.22614	0.75
06/01/2026 15:00	0.7	1.5	-1	0.45	0.22614	0.75
06/01/2026 16:00	0.7	1.5	-1	0.46	0.22902	0.76
06/01/2026 17:00	0.7	1.5	-1	0.48	0.24204	0.81
06/01/2026 18:00	0.7	1.5	-1	0.52	0.26154	0.87
06/01/2026 19:00	0.7	1.5	0	0.48	0.24102	0.80
06/01/2026 20:00	0.7	1.5	0	0.47	0.23706	0.79
06/01/2026 21:00	0.7	1.5	-1	0.47	0.23670	0.79
06/01/2026 22:00	0.7	1.5	0	0.52	0.25770	0.86
06/01/2026 23:00	0.8	1.5	-1	0.46	0.23040	0.77
Average/Sum#:	0.7	1.5	-1	0.46	0.23209	0.77
Minimum:	0.7	1.5	-3	0.45	0.22572	0.75
Maximum:	0.8	1.5	0	0.52	0.26154	0.87
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/02/2026 00:00	0.8	1.5	-1	0.46	0.23202	0.77
06/02/2026 01:00	0.8	1.5	-2	0.45	0.22620	0.75
06/02/2026 02:00	0.8	1.5	-2	0.45	0.22596	0.75
06/02/2026 03:00	0.8	1.5	-2	0.45	0.22608	0.75
06/02/2026 04:00	0.8	1.5	-2	0.45	0.22728	0.76
06/02/2026 05:00	0.8	1.5	-2	0.46	0.23160	0.77
06/02/2026 06:00	0.8	1.5	-1	0.46	0.22830	0.76
06/02/2026 07:00	0.8	1.5	-1	0.46	0.22830	0.76
06/02/2026 08:00	0.8	1.5	0	0.46	0.22830	0.76
06/02/2026 09:00	0.7	1.5	-1	0.45	0.22662	0.76
06/02/2026 10:00	0.7	1.5	-1	0.45	0.22662	0.76
06/02/2026 11:00	0.8	1.5	-1	0.45	0.22710	0.76
06/02/2026 12:00	0.7	1.5	-1	0.45	0.22650	0.76
06/02/2026 13:00	0.7	1.5	-1	0.45	0.22656	0.76
06/02/2026 14:00	0.7	1.5	0	0.45	0.22596	0.75
06/02/2026 15:00	0.7	1.5	-1	0.45	0.22620	0.75
06/02/2026 16:00	0.7	1.5	-1	0.49	0.24564	0.82
06/02/2026 17:00	0.7	1.5	0	0.51	0.25278	0.84
06/02/2026 18:00	0.7	1.5	0	0.55	0.27468	0.92
06/02/2026 19:00	0.8	1.5	0	0.49	0.24726	0.82
06/02/2026 20:00	0.7	1.5	0	0.50	0.25050	0.84
06/02/2026 21:00	0.6	1.5	0	0.53	0.26580	0.89
06/02/2026 22:00	0.7	1.5	-1	0.49	0.24342	0.81
06/02/2026 23:00	0.8	1.5	-1	0.45	0.22728	0.76
Average/Sum#:	0.7	1.5	-1	0.47	0.23529	0.78
Minimum:	0.6	1.5	-2	0.45	0.22596	0.75
Maximum:	0.8	1.5	0	0.55	0.27468	0.92
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/03/2026 00:00	0.8	1.5	-1	0.46	0.22794	0.76
06/03/2026 01:00	0.8	1.5	-2	0.46	0.22782	0.76
06/03/2026 02:00	0.8	1.5	-2	0.46	0.22806	0.76
06/03/2026 03:00	0.8	1.5	-2	0.46	0.22836	0.76
06/03/2026 04:00	0.8	1.5	-2	0.46	0.22806	0.76
06/03/2026 05:00	0.8	1.5	-2	0.46	0.22794	0.76
06/03/2026 06:00	0.8	1.5	-2	0.46	0.22788	0.76
06/03/2026 07:00	0.8	1.5	-1	0.46	0.22806	0.76
06/03/2026 08:00	0.8	1.5	0	0.46	0.22800	0.76
06/03/2026 09:00	0.8	1.5	-1	0.46	0.22872	0.76
06/03/2026 10:00	0.8	1.5	0	0.46	0.22878	0.76
06/03/2026 11:00	0.8	1.5	-1	0.46	0.22836	0.76
06/03/2026 12:00	0.7	1.5	-1	0.45	0.22560	0.75
06/03/2026 13:00	0.7	1.5	-1	0.45	0.22488	0.75
06/03/2026 14:00	0.7	1.5	-1	0.45	0.22482	0.75
06/03/2026 15:00	0.7	1.5	-1	0.45	0.22470	0.75
06/03/2026 16:00	0.6	1.5	-1	0.52	0.25926	0.86
06/03/2026 17:00	0.7	1.5	-1	0.50	0.25164	0.84
06/03/2026 18:00	0.6	1.5	0	0.56	0.27756	0.93
06/03/2026 19:00	0.6	1.5	0	0.51	0.25272	0.84
06/03/2026 20:00	0.7	1.5	0	0.49	0.24510	0.82
06/03/2026 21:00	0.7	1.5	0	0.50	0.24930	0.83
06/03/2026 22:00	0.0	0.0	0	0.14	0.07020	0.23
06/03/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.7	1.4	-1	0.46	0.22799	0.76
Minimum:	0.0	0.0	-2	0.14	0.07020	0.23
Maximum:	0.8	1.5	0	0.56	0.27756	0.93
%SI	4.17	4.17	8.33	4.17	4.17	4.17

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/04/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
06/04/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/05/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
06/05/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
06/05/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
06/05/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
06/05/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
06/05/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
06/05/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
06/05/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/05/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
06/05/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
06/05/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
06/05/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
06/05/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
06/05/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
06/05/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
06/05/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
06/05/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
06/05/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
06/05/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
06/05/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
06/05/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
06/05/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
06/05/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
06/05/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/06/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
06/06/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/07/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
06/07/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/08/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
06/08/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/09/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
06/09/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/10/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
06/10/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
06/10/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
06/10/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
06/10/2026 04:00	0.0	0.0	0	0.25	0.12498	0.42
06/10/2026 05:00	0.8	1.4	-3	0.48	0.23886	0.80
06/10/2026 06:00	0.8	1.5	-2	0.51	0.25626	0.85
06/10/2026 07:00	0.2	1.5	2	0.75	0.37344	1.24
06/10/2026 08:00	0.1	1.5	3	0.75	0.37632	1.25
06/10/2026 09:00	0.1	1.5	4	0.75	0.37740	1.26
06/10/2026 10:00	0.1	1.5	3	0.75	0.37662	1.26
06/10/2026 11:00	0.1	1.5	3	0.75	0.37650	1.26
06/10/2026 12:00	0.1	1.5	3	0.75	0.37728	1.26
06/10/2026 13:00	0.1	1.5	3	0.76	0.37776	1.26
06/10/2026 14:00	0.1	1.5	4	0.76	0.37794	1.26
06/10/2026 15:00	0.1	1.5	4	0.76	0.37848	1.26
06/10/2026 16:00	0.1	1.5	3	0.76	0.37968	1.27
06/10/2026 17:00	0.1	1.5	3	0.76	0.38010	1.27
06/10/2026 18:00	0.1	1.5	3	0.76	0.37914	1.26
06/10/2026 19:00	0.7	1.5	0	0.62	0.30762	1.03
06/10/2026 20:00	0.7	1.5	-1	0.45	0.22548	0.75
06/10/2026 21:00	0.7	1.5	-1	0.45	0.22386	0.75
06/10/2026 22:00	0.7	1.5	-1	0.45	0.22404	0.75
06/10/2026 23:00	0.7	1.5	-1	0.45	0.22416	0.75
Average/Sum#:	0.3	1.4	2	0.64	0.31780	1.06
Minimum:	0.0	0.0	-3	0.25	0.12498	0.42
Maximum:	0.8	1.5	4	0.76	0.38010	1.27
%SI	16.67	16.67	20.83	16.67	16.67	16.67

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/11/2026 00:00	0.7	1.5	-1	0.45	0.22422	0.75
06/11/2026 01:00	0.7	1.5	-1	0.45	0.22422	0.75
06/11/2026 02:00	0.7	1.5	-1	0.45	0.22422	0.75
06/11/2026 03:00	0.8	1.5	-1	0.45	0.22446	0.75
06/11/2026 04:00	0.8	1.5	-2	0.45	0.22458	0.75
06/11/2026 05:00	0.8	1.5	-1	0.53	0.26448	0.88
06/11/2026 06:00	0.7	1.5	1	0.66	0.32964	1.10
06/11/2026 07:00	0.1	1.5	4	0.75	0.37644	1.25
06/11/2026 08:00	0.2	1.5	3	0.75	0.37536	1.25
06/11/2026 09:00	0.1	1.5	3	0.75	0.37608	1.25
06/11/2026 10:00	0.1	1.5	3	0.75	0.37746	1.26
06/11/2026 11:00	0.1	1.5	3	0.76	0.37938	1.26
06/11/2026 12:00	0.1	1.5	4	0.76	0.38028	1.27
06/11/2026 13:00	0.1	1.5	4	0.76	0.38088	1.27
06/11/2026 14:00	0.1	1.5	4	0.76	0.38094	1.27
06/11/2026 15:00	0.1	1.5	4	0.76	0.38118	1.27
06/11/2026 16:00	0.1	1.5	4	0.76	0.38160	1.27
06/11/2026 17:00	0.1	1.5	4	0.76	0.38184	1.27
06/11/2026 18:00	0.2	1.5	4	0.76	0.38052	1.27
06/11/2026 19:00	0.6	1.5	0	0.61	0.30690	1.02
06/11/2026 20:00	0.7	1.5	-1	0.45	0.22548	0.75
06/11/2026 21:00	0.7	1.5	-1	0.48	0.24096	0.80
06/11/2026 22:00	0.7	1.5	0	0.49	0.24546	0.82
06/11/2026 23:00	0.7	1.5	-1	0.45	0.22374	0.75
Average/Sum#:	0.4	1.5	1	0.63	0.31293	1.04
Minimum:	0.1	1.5	-2	0.45	0.22374	0.75
Maximum:	0.8	1.5	4	0.76	0.38184	1.27
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/12/2026 00:00	0.7	1.5	-1	0.45	0.22404	0.75
06/12/2026 01:00	0.7	1.5	-1	0.46	0.22938	0.76
06/12/2026 02:00	0.7	1.5	-1	0.45	0.22662	0.76
06/12/2026 03:00	0.7	1.5	-1	0.50	0.24888	0.83
06/12/2026 04:00	0.7	1.5	-1	0.46	0.23154	0.77
06/12/2026 05:00	0.7	1.5	-1	0.48	0.23832	0.79
06/12/2026 06:00	0.7	1.5	-1	0.45	0.22422	0.75
06/12/2026 07:00	0.7	1.5	-1	0.45	0.22392	0.75
06/12/2026 08:00	0.7	1.5	-1	0.45	0.22374	0.75
06/12/2026 09:00	0.7	1.5	-1	0.45	0.22332	0.74
06/12/2026 10:00	0.7	1.5	-1	0.45	0.22314	0.74
06/12/2026 11:00	0.6	1.5	-1	0.45	0.22638	0.75
06/12/2026 12:00	0.6	1.5	-1	0.54	0.26988	0.90
06/12/2026 13:00	0.6	1.5	0	0.55	0.27612	0.92
06/12/2026 14:00	0.6	1.5	0	0.55	0.27732	0.92
06/12/2026 15:00	0.5	1.5	2	0.64	0.32040	1.07
06/12/2026 16:00	0.7	1.5	1	0.61	0.30390	1.01
06/12/2026 17:00	0.6	1.5	-1	0.49	0.24540	0.82
06/12/2026 18:00	0.6	1.5	0	0.53	0.26358	0.88
06/12/2026 19:00	0.6	1.5	0	0.56	0.27996	0.93
06/12/2026 20:00	0.9	1.5	1	0.64	0.31890	1.06
06/12/2026 21:00	0.9	1.5	1	0.63	0.31698	1.06
06/12/2026 22:00	1.0	1.5	1	0.63	0.31536	1.05
06/12/2026 23:00	1.0	1.5	0	0.61	0.30360	1.01
Average/Sum#:	0.7	1.5	0	0.52	0.25979	0.87
Minimum:	0.5	1.5	-1	0.45	0.22314	0.74
Maximum:	1.0	1.5	2	0.64	0.32040	1.07
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/13/2026 00:00	0.7	1.5	-1	0.45	0.22656	0.76
06/13/2026 01:00	0.7	1.5	-1	0.45	0.22494	0.75
06/13/2026 02:00	0.7	1.5	-1	0.45	0.22464	0.75
06/13/2026 03:00	0.7	1.5	-1	0.49	0.24618	0.82
06/13/2026 04:00	0.7	1.5	-1	0.52	0.25770	0.86
06/13/2026 05:00	0.7	1.5	-1	0.48	0.23856	0.80
06/13/2026 06:00	0.7	1.5	-1	0.45	0.22464	0.75
06/13/2026 07:00	0.7	1.5	-1	0.45	0.22434	0.75
06/13/2026 08:00	0.7	1.5	-1	0.45	0.22416	0.75
06/13/2026 09:00	0.7	1.5	-1	0.45	0.22386	0.75
06/13/2026 10:00	0.7	1.5	-1	0.45	0.22368	0.75
06/13/2026 11:00	0.7	1.5	-1	0.45	0.22332	0.74
06/13/2026 12:00	0.6	1.5	-1	0.45	0.22290	0.74
06/13/2026 13:00	0.6	1.5	0	0.45	0.22266	0.74
06/13/2026 14:00	0.6	1.5	0	0.44	0.22248	0.74
06/13/2026 15:00	0.6	1.5	0	0.44	0.22236	0.74
06/13/2026 16:00	0.6	1.5	0	0.50	0.24960	0.83
06/13/2026 17:00	0.6	1.5	-1	0.51	0.25380	0.85
06/13/2026 18:00	0.7	1.5	0	0.56	0.28164	0.94
06/13/2026 19:00	0.2	1.6	5	0.79	0.39444	1.31
06/13/2026 20:00	0.1	1.5	3	0.74	0.36936	1.23
06/13/2026 21:00	0.2	1.5	3	0.74	0.37218	1.24
06/13/2026 22:00	0.1	1.5	5	0.80	0.40092	1.34
06/13/2026 23:00	0.2	1.5	5	0.80	0.40104	1.34
Average/Sum#:	0.6	1.5	0	0.53	0.26567	0.89
Minimum:	0.1	1.5	-1	0.44	0.22236	0.74
Maximum:	0.7	1.6	5	0.80	0.40104	1.34
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/14/2026 00:00	0.9	1.5	0	0.64	0.31758	1.06
06/14/2026 01:00	1.0	1.5	0	0.61	0.30516	1.02
06/14/2026 02:00	0.6	1.5	-1	0.52	0.25758	0.86
06/14/2026 03:00	0.7	1.5	-2	0.45	0.22524	0.75
06/14/2026 04:00	0.7	1.5	-2	0.45	0.22536	0.75
06/14/2026 05:00	0.7	1.5	-2	0.45	0.22560	0.75
06/14/2026 06:00	0.7	1.5	-1	0.45	0.22560	0.75
06/14/2026 07:00	0.7	1.5	-1	0.45	0.22536	0.75
06/14/2026 08:00	0.7	1.5	0	0.45	0.22518	0.75
06/14/2026 09:00	0.7	1.5	-1	0.45	0.22476	0.75
06/14/2026 10:00	0.7	1.5	-1	0.45	0.22446	0.75
06/14/2026 11:00	0.6	1.5	-1	0.45	0.22410	0.75
06/14/2026 12:00	0.6	1.5	-1	0.45	0.22386	0.75
06/14/2026 13:00	0.6	1.5	-1	0.45	0.22302	0.74
06/14/2026 14:00	0.6	1.5	0	0.45	0.22266	0.74
06/14/2026 15:00	0.6	1.5	0	0.44	0.22230	0.74
06/14/2026 16:00	0.6	1.5	0	0.54	0.26922	0.90
06/14/2026 17:00	0.6	1.5	-1	0.51	0.25704	0.86
06/14/2026 18:00	0.6	1.5	0	0.55	0.27342	0.91
06/14/2026 19:00	0.6	1.5	0	0.55	0.27288	0.91
06/14/2026 20:00	0.6	1.5	0	0.53	0.26412	0.88
06/14/2026 21:00	0.6	1.5	0	0.52	0.26052	0.87
06/14/2026 22:00	0.7	1.5	0	0.47	0.23286	0.78
06/14/2026 23:00	0.7	1.5	-1	0.47	0.23406	0.78
Average/Sum#:	0.7	1.5	-1	0.49	0.24425	0.81
Minimum:	0.6	1.5	-2	0.44	0.22230	0.74
Maximum:	1.0	1.5	0	0.64	0.31758	1.06
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/15/2026 00:00	0.7	1.5	-1	0.47	0.23502	0.78
06/15/2026 01:00	0.7	1.5	-1	0.45	0.22632	0.75
06/15/2026 02:00	0.7	1.5	-2	0.45	0.22446	0.75
06/15/2026 03:00	0.7	1.5	-2	0.45	0.22464	0.75
06/15/2026 04:00	0.7	1.5	-2	0.45	0.22476	0.75
06/15/2026 05:00	0.7	1.5	-2	0.45	0.22494	0.75
06/15/2026 06:00	0.7	1.5	-1	0.45	0.22494	0.75
06/15/2026 07:00	0.7	1.5	-1	0.45	0.22482	0.75
06/15/2026 08:00	0.7	1.5	0	0.45	0.22458	0.75
06/15/2026 09:00	0.7	1.5	-1	0.45	0.22458	0.75
06/15/2026 10:00	0.7	1.5	-1	0.45	0.22422	0.75
06/15/2026 11:00	0.7	1.5	-1	0.45	0.22398	0.75
06/15/2026 12:00	0.7	1.5	-1	0.45	0.22392	0.75
06/15/2026 13:00	0.7	1.5	0	0.45	0.22344	0.74
06/15/2026 14:00	0.6	1.5	0	0.50	0.24786	0.83
06/15/2026 15:00	0.6	1.5	0	0.52	0.26118	0.87
06/15/2026 16:00	0.6	1.5	-1	0.50	0.24852	0.83
06/15/2026 17:00	0.7	1.5	0	0.52	0.25776	0.86
06/15/2026 18:00	0.3	1.5	3	0.66	0.32862	1.10
06/15/2026 19:00	0.7	1.5	0	0.55	0.27582	0.92
06/15/2026 20:00	0.6	1.5	0	0.45	0.22614	0.75
06/15/2026 21:00	0.7	1.5	-1	0.45	0.22740	0.76
06/15/2026 22:00	0.7	1.5	-1	0.49	0.24570	0.82
06/15/2026 23:00	0.9	1.5	1	0.61	0.30456	1.02
Average/Sum#:	0.7	1.5	-1	0.48	0.24076	0.80
Minimum:	0.3	1.5	-2	0.45	0.22344	0.74
Maximum:	0.9	1.5	3	0.66	0.32862	1.10
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/16/2026 00:00	0.9	1.5	0	0.61	0.30702	1.02
06/16/2026 01:00	0.9	1.5	0	0.61	0.30618	1.02
06/16/2026 02:00	1.0	1.5	-1	0.61	0.30516	1.02
06/16/2026 03:00	1.3	1.5	-1	0.60	0.29886	1.00
06/16/2026 04:00	0.8	1.5	-2	0.47	0.23442	0.78
06/16/2026 05:00	0.7	1.5	-2	0.45	0.22590	0.75
06/16/2026 06:00	0.7	1.5	-1	0.48	0.24156	0.81
06/16/2026 07:00	0.3	1.5	4	0.70	0.35094	1.17
06/16/2026 08:00	0.1	1.5	5	0.71	0.35718	1.19
06/16/2026 09:00	0.1	1.5	5	0.71	0.35736	1.19
06/16/2026 10:00	0.1	1.5	6	0.72	0.35760	1.19
06/16/2026 11:00	0.1	1.5	7	0.72	0.35814	1.19
06/16/2026 12:00	0.1	1.5	7	0.72	0.35892	1.20
06/16/2026 13:00	0.1	1.5	8	0.72	0.35910	1.20
06/16/2026 14:00	0.1	1.5	5	0.75	0.37608	1.25
06/16/2026 15:00	0.1	1.5	5	0.77	0.38550	1.29
06/16/2026 16:00	0.1	1.5	5	0.77	0.38400	1.28
06/16/2026 17:00	0.6	1.5	1	0.65	0.32532	1.08
06/16/2026 18:00	0.8	1.5	1	0.63	0.31344	1.04
06/16/2026 19:00	0.8	1.5	1	0.63	0.31254	1.04
06/16/2026 20:00	0.9	1.5	1	0.62	0.31080	1.04
06/16/2026 21:00	0.9	1.5	0	0.62	0.30942	1.03
06/16/2026 22:00	1.0	1.5	0	0.62	0.30954	1.03
06/16/2026 23:00	1.2	1.5	0	0.62	0.30900	1.03
Average/Sum#:	0.6	1.5	2	0.65	0.32308	1.08
Minimum:	0.1	1.5	-2	0.45	0.22590	0.75
Maximum:	1.3	1.5	8	0.77	0.38550	1.29
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/17/2026 00:00	1.3	1.5	-1	0.62	0.30834	1.03
06/17/2026 01:00	1.4	1.5	-1	0.62	0.30774	1.03
06/17/2026 02:00	1.3	1.5	-1	0.61	0.30666	1.02
06/17/2026 03:00	1.3	1.5	-1	0.61	0.30636	1.02
06/17/2026 04:00	1.2	1.5	-1	0.61	0.30624	1.02
06/17/2026 05:00	1.0	1.5	-1	0.55	0.27696	0.92
06/17/2026 06:00	0.7	1.5	-1	0.48	0.24060	0.80
06/17/2026 07:00	0.4	1.6	2	0.73	0.36630	1.22
06/17/2026 08:00	0.1	1.5	3	0.75	0.37572	1.25
06/17/2026 09:00	0.1	1.5	3	0.75	0.37668	1.26
06/17/2026 10:00	0.1	1.5	3	0.76	0.37806	1.26
06/17/2026 11:00	0.1	1.5	3	0.76	0.37950	1.27
06/17/2026 12:00	0.1	1.5	3	0.76	0.38070	1.27
06/17/2026 13:00	0.1	1.5	4	0.76	0.38148	1.27
06/17/2026 14:00	0.1	1.5	4	0.76	0.38166	1.27
06/17/2026 15:00	0.1	1.5	4	0.76	0.38172	1.27
06/17/2026 16:00	0.1	1.5	4	0.76	0.38160	1.27
06/17/2026 17:00	0.6	1.5	1	0.65	0.32514	1.08
06/17/2026 18:00	0.8	1.5	1	0.62	0.31212	1.04
06/17/2026 19:00	0.9	1.5	1	0.62	0.31128	1.04
06/17/2026 20:00	0.9	1.5	1	0.62	0.30948	1.03
06/17/2026 21:00	1.1	1.5	0	0.62	0.30846	1.03
06/17/2026 22:00	1.2	1.5	0	0.62	0.30786	1.03
06/17/2026 23:00	1.4	1.5	0	0.61	0.30690	1.02
Average/Sum#:	0.7	1.5	1	0.67	0.33407	1.11
Minimum:	0.1	1.5	-1	0.48	0.24060	0.80
Maximum:	1.4	1.6	4	0.76	0.38172	1.27
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/18/2026 00:00	1.2	1.5	-1	0.61	0.30636	1.02
06/18/2026 01:00	1.2	1.5	-1	0.61	0.30618	1.02
06/18/2026 02:00	1.3	1.5	-1	0.61	0.30612	1.02
06/18/2026 03:00	1.3	1.5	-1	0.61	0.30660	1.02
06/18/2026 04:00	1.2	1.5	-1	0.62	0.31158	1.04
06/18/2026 05:00	0.8	1.5	-1	0.62	0.31044	1.03
06/18/2026 06:00	0.7	1.5	-2	0.45	0.22626	0.75
06/18/2026 07:00	0.7	1.5	-1	0.45	0.22500	0.75
06/18/2026 08:00	0.7	1.5	-1	0.45	0.22482	0.75
06/18/2026 09:00	0.7	1.5	0	0.45	0.22464	0.75
06/18/2026 10:00	0.7	1.5	0	0.45	0.22452	0.75
06/18/2026 11:00	0.6	1.5	-1	0.45	0.22434	0.75
06/18/2026 12:00	0.6	1.5	-1	0.45	0.22416	0.75
06/18/2026 13:00	0.6	1.5	-1	0.45	0.22404	0.75
06/18/2026 14:00	0.6	1.5	-1	0.45	0.22398	0.75
06/18/2026 15:00	0.6	1.5	-1	0.45	0.22410	0.75
06/18/2026 16:00	0.6	1.5	0	0.45	0.22410	0.75
06/18/2026 17:00	0.7	1.5	0	0.52	0.25806	0.86
06/18/2026 18:00	0.6	1.5	1	0.68	0.34068	1.14
06/18/2026 19:00	0.1	1.5	3	0.73	0.36354	1.21
06/18/2026 20:00	0.2	1.5	2	0.72	0.35994	1.20
06/18/2026 21:00	0.9	1.5	0	0.62	0.30978	1.03
06/18/2026 22:00	1.0	1.5	0	0.63	0.31320	1.04
06/18/2026 23:00	0.9	1.5	0	0.64	0.32046	1.07
Average/Sum#:	0.8	1.5	0	0.55	0.27429	0.91
Minimum:	0.1	1.5	-2	0.45	0.22398	0.75
Maximum:	1.3	1.5	3	0.73	0.36354	1.21
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/19/2026 00:00	0.8	1.5	0	0.64	0.32226	1.07
06/19/2026 01:00	1.0	1.5	-1	0.62	0.30768	1.03
06/19/2026 02:00	1.1	1.5	-1	0.61	0.30744	1.02
06/19/2026 03:00	1.1	1.5	-1	0.61	0.30738	1.02
06/19/2026 04:00	1.1	1.5	-1	0.61	0.30672	1.02
06/19/2026 05:00	0.7	1.5	-2	0.49	0.24492	0.82
06/19/2026 06:00	0.8	1.5	-2	0.46	0.23244	0.77
06/19/2026 07:00	0.7	1.5	-1	0.46	0.22752	0.76
06/19/2026 08:00	0.7	1.5	0	0.46	0.22812	0.76
06/19/2026 09:00	0.7	1.5	0	0.46	0.22788	0.76
06/19/2026 10:00	0.7	1.5	-1	0.45	0.22614	0.75
06/19/2026 11:00	0.7	1.5	0	0.45	0.22560	0.75
06/19/2026 12:00	0.6	1.5	0	0.45	0.22512	0.75
06/19/2026 13:00	0.6	1.5	-1	0.45	0.22542	0.75
06/19/2026 14:00	0.6	1.5	-1	0.46	0.22920	0.76
06/19/2026 15:00	0.6	1.5	0	0.50	0.24954	0.83
06/19/2026 16:00	0.6	1.5	0	0.48	0.24132	0.80
06/19/2026 17:00	0.6	1.5	0	0.48	0.23778	0.79
06/19/2026 18:00	0.6	1.5	0	0.51	0.25572	0.85
06/19/2026 19:00	0.6	1.5	0	0.51	0.25290	0.84
06/19/2026 20:00	0.7	1.5	-1	0.46	0.22986	0.77
06/19/2026 21:00	0.7	1.5	-1	0.46	0.22824	0.76
06/19/2026 22:00	0.7	1.5	-1	0.46	0.22806	0.76
06/19/2026 23:00	0.7	1.5	-2	0.45	0.22698	0.76
Average/Sum#:	0.7	1.5	-1	0.50	0.24976	0.83
Minimum:	0.6	1.5	-2	0.45	0.22512	0.75
Maximum:	1.1	1.5	0	0.64	0.32226	1.07
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/20/2026 00:00	0.7	1.5	-2	0.45	0.22632	0.75
06/20/2026 01:00	0.7	1.5	-2	0.45	0.22620	0.75
06/20/2026 02:00	0.7	1.5	-2	0.45	0.22686	0.76
06/20/2026 03:00	0.7	1.5	-2	0.45	0.22680	0.76
06/20/2026 04:00	0.7	1.5	-2	0.45	0.22722	0.76
06/20/2026 05:00	0.7	1.5	-2	0.48	0.24240	0.81
06/20/2026 06:00	0.7	1.5	-1	0.45	0.22638	0.75
06/20/2026 07:00	0.7	1.5	-1	0.45	0.22668	0.76
06/20/2026 08:00	0.7	1.5	0	0.45	0.22734	0.76
06/20/2026 09:00	0.7	1.5	0	0.46	0.22764	0.76
06/20/2026 10:00	0.6	1.5	0	0.45	0.22656	0.76
06/20/2026 11:00	0.6	1.5	-1	0.45	0.22644	0.75
06/20/2026 12:00	0.6	1.5	-1	0.45	0.22668	0.76
06/20/2026 13:00	0.6	1.5	-1	0.45	0.22662	0.76
06/20/2026 14:00	0.6	1.5	0	0.45	0.22644	0.75
06/20/2026 15:00	0.6	1.5	-1	0.45	0.22626	0.75
06/20/2026 16:00	0.6	1.5	-1	0.45	0.22500	0.75
06/20/2026 17:00	0.6	1.5	-1	0.46	0.22902	0.76
06/20/2026 18:00	0.6	1.5	0	0.45	0.22602	0.75
06/20/2026 19:00	0.6	1.5	0	0.45	0.22566	0.75
06/20/2026 20:00	0.7	1.5	0	0.45	0.22548	0.75
06/20/2026 21:00	0.7	1.5	-1	0.45	0.22632	0.75
06/20/2026 22:00	0.7	1.5	-1	0.45	0.22716	0.76
06/20/2026 23:00	0.7	1.5	-2	0.45	0.22722	0.76
Average/Sum#:	0.7	1.5	-1	0.45	0.22728	0.76
Minimum:	0.6	1.5	-2	0.45	0.22500	0.75
Maximum:	0.7	1.5	0	0.48	0.24240	0.81
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/21/2026 00:00	0.7	1.5	-2	0.45	0.22686	0.76
06/21/2026 01:00	0.7	1.5	-2	0.45	0.22710	0.76
06/21/2026 02:00	0.7	1.5	-2	0.45	0.22692	0.76
06/21/2026 03:00	0.7	1.5	-2	0.45	0.22728	0.76
06/21/2026 04:00	0.7	1.5	-2	0.45	0.22734	0.76
06/21/2026 05:00	0.7	1.5	-2	0.45	0.22746	0.76
06/21/2026 06:00	0.7	1.5	-1	0.46	0.22764	0.76
06/21/2026 07:00	0.7	1.5	-1	0.46	0.22764	0.76
06/21/2026 08:00	0.7	1.5	0	0.46	0.22800	0.76
06/21/2026 09:00	0.7	1.5	-1	0.45	0.22644	0.75
06/21/2026 10:00	0.7	1.5	0	0.45	0.22584	0.75
06/21/2026 11:00	0.7	1.5	-1	0.45	0.22590	0.75
06/21/2026 12:00	0.6	1.5	-1	0.45	0.22626	0.75
06/21/2026 13:00	0.6	1.5	-1	0.45	0.22602	0.75
06/21/2026 14:00	0.6	1.5	0	0.45	0.22578	0.75
06/21/2026 15:00	0.6	1.5	0	0.45	0.22512	0.75
06/21/2026 16:00	0.6	1.5	-1	0.45	0.22446	0.75
06/21/2026 17:00	0.6	1.5	0	0.48	0.24108	0.80
06/21/2026 18:00	0.6	1.5	-1	0.52	0.25986	0.87
06/21/2026 19:00	0.6	1.5	0	0.55	0.27456	0.92
06/21/2026 20:00	0.6	1.5	0	0.52	0.25986	0.87
06/21/2026 21:00	0.6	1.5	0	0.53	0.26298	0.88
06/21/2026 22:00	0.6	1.5	0	0.55	0.27378	0.91
06/21/2026 23:00	0.6	1.5	-1	0.55	0.27324	0.91
Average/Sum#:	0.7	1.5	-1	0.47	0.23739	0.79
Minimum:	0.6	1.5	-2	0.45	0.22446	0.75
Maximum:	0.7	1.5	0	0.55	0.27456	0.92
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/22/2026 00:00	0.7	1.5	-1	0.48	0.24150	0.81
06/22/2026 01:00	0.7	1.5	-1	0.45	0.22692	0.76
06/22/2026 02:00	0.7	1.5	-2	0.46	0.22758	0.76
06/22/2026 03:00	0.7	1.5	-2	0.46	0.22788	0.76
06/22/2026 04:00	0.7	1.5	-2	0.46	0.22824	0.76
06/22/2026 05:00	0.7	1.5	-2	0.47	0.23484	0.78
06/22/2026 06:00	0.7	1.5	-2	0.45	0.22668	0.76
06/22/2026 07:00	0.7	1.5	-1	0.45	0.22734	0.76
06/22/2026 08:00	0.7	1.5	-1	0.45	0.22614	0.75
06/22/2026 09:00	0.6	1.5	-1	0.50	0.24840	0.83
06/22/2026 10:00	0.6	1.5	-1	0.49	0.24678	0.82
06/22/2026 11:00	0.6	1.5	-1	0.47	0.23658	0.79
06/22/2026 12:00	0.6	1.5	-1	0.46	0.22824	0.76
06/22/2026 13:00	0.6	1.5	-1	0.45	0.22674	0.76
06/22/2026 14:00	0.6	1.5	0	0.45	0.22542	0.75
06/22/2026 15:00	0.6	1.5	0	0.45	0.22434	0.75
06/22/2026 16:00	0.7	1.5	-1	0.46	0.23106	0.77
06/22/2026 17:00	0.6	1.5	-1	0.49	0.24420	0.81
06/22/2026 18:00	0.6	1.5	0	0.55	0.27558	0.92
06/22/2026 19:00	0.6	1.5	0	0.48	0.23874	0.80
06/22/2026 20:00	0.7	1.5	0	0.45	0.22608	0.75
06/22/2026 21:00	0.7	1.5	-1	0.45	0.22566	0.75
06/22/2026 22:00	0.7	1.5	-1	0.45	0.22698	0.76
06/22/2026 23:00	0.7	1.5	-1	0.45	0.22680	0.76
Average/Sum#:	0.7	1.5	-1	0.47	0.23328	0.78
Minimum:	0.6	1.5	-2	0.45	0.22434	0.75
Maximum:	0.7	1.5	0	0.55	0.27558	0.92
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/23/2026 00:00	0.7	1.5	-2	0.45	0.22716	0.76
06/23/2026 01:00	0.7	1.5	-2	0.45	0.22722	0.76
06/23/2026 02:00	0.7	1.5	-2	0.45	0.22740	0.76
06/23/2026 03:00	0.7	1.5	-2	0.45	0.22728	0.76
06/23/2026 04:00	0.7	1.5	-2	0.45	0.22710	0.76
06/23/2026 05:00	0.7	1.5	-2	0.45	0.22692	0.76
06/23/2026 06:00	0.7	1.5	-2	0.46	0.23094	0.77
06/23/2026 07:00	0.7	1.5	-1	0.45	0.22686	0.76
06/23/2026 08:00	0.7	1.5	-1	0.45	0.22680	0.76
06/23/2026 09:00	0.7	1.5	-1	0.45	0.22650	0.76
06/23/2026 10:00	0.6	1.5	-1	0.45	0.22536	0.75
06/23/2026 11:00	0.6	1.5	-1	0.45	0.22488	0.75
06/23/2026 12:00	0.6	1.5	-1	0.45	0.22488	0.75
06/23/2026 13:00	0.6	1.5	-1	0.45	0.22380	0.75
06/23/2026 14:00	0.6	1.5	0	0.47	0.23424	0.78
06/23/2026 15:00	0.6	1.4	0	0.48	0.24168	0.81
06/23/2026 16:00	0.6	1.5	-1	0.50	0.24780	0.83
06/23/2026 17:00	0.6	1.5	0	0.51	0.25734	0.86
06/23/2026 18:00	0.6	1.5	0	0.54	0.26826	0.89
06/23/2026 19:00	0.6	1.5	0	0.55	0.27342	0.91
06/23/2026 20:00	0.6	1.5	0	0.55	0.27348	0.91
06/23/2026 21:00	0.6	1.5	0	0.52	0.26142	0.87
06/23/2026 22:00	0.6	1.5	-1	0.51	0.25530	0.85
06/23/2026 23:00	0.6	1.5	0	0.53	0.26376	0.88
Average/Sum#:	0.6	1.5	-1	0.48	0.23958	0.80
Minimum:	0.6	1.4	-2	0.45	0.22380	0.75
Maximum:	0.7	1.5	0	0.55	0.27348	0.91
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/24/2026 00:00	0.7	1.5	-1	0.49	0.24660	0.82
06/24/2026 01:00	0.7	1.5	-1	0.47	0.23460	0.78
06/24/2026 02:00	0.7	1.6	-2	0.45	0.22662	0.76
06/24/2026 03:00	0.7	1.5	-2	0.45	0.22686	0.76
06/24/2026 04:00	0.7	1.5	-2	0.46	0.23082	0.77
06/24/2026 05:00	0.6	1.5	-1	0.54	0.26754	0.89
06/24/2026 06:00	0.7	1.5	-1	0.46	0.23034	0.77
06/24/2026 07:00	0.7	1.5	-1	0.45	0.22668	0.76
06/24/2026 08:00	0.7	1.5	-1	0.45	0.22602	0.75
06/24/2026 09:00	0.7	1.5	0	0.45	0.22632	0.75
06/24/2026 10:00	0.7	1.5	0	0.45	0.22512	0.75
06/24/2026 11:00	0.7	1.5	-1	0.45	0.22398	0.75
06/24/2026 12:00	0.6	1.5	-1	0.49	0.24396	0.81
06/24/2026 13:00	0.6	1.5	-1	0.52	0.25782	0.86
06/24/2026 14:00	0.6	1.5	0	0.53	0.26514	0.88
06/24/2026 15:00	0.6	1.5	0	0.51	0.25716	0.86
06/24/2026 16:00	0.6	1.5	0	0.50	0.24936	0.83
06/24/2026 17:00	0.6	1.5	0	0.48	0.23790	0.79
06/24/2026 18:00	0.6	1.5	0	0.46	0.23172	0.77
06/24/2026 19:00	0.7	1.5	0	0.45	0.22512	0.75
06/24/2026 20:00	0.7	1.5	0	0.45	0.22554	0.75
06/24/2026 21:00	0.7	1.5	-1	0.45	0.22578	0.75
06/24/2026 22:00	0.7	1.5	-1	0.45	0.22548	0.75
06/24/2026 23:00	0.7	1.5	-2	0.45	0.22494	0.75
Average/Sum#:	0.7	1.5	-1	0.47	0.23589	0.79
Minimum:	0.6	1.5	-2	0.45	0.22398	0.75
Maximum:	0.7	1.6	0	0.54	0.26754	0.89
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/25/2026 00:00	0.7	1.5	-2	0.45	0.22494	0.75
06/25/2026 01:00	0.7	1.5	-3	0.45	0.22506	0.75
06/25/2026 02:00	0.7	1.5	-3	0.45	0.22524	0.75
06/25/2026 03:00	0.7	1.5	-3	0.45	0.22542	0.75
06/25/2026 04:00	0.7	1.5	-3	0.48	0.24138	0.80
06/25/2026 05:00	0.7	1.5	-2	0.50	0.24906	0.83
06/25/2026 06:00	0.7	1.5	-2	0.45	0.22476	0.75
06/25/2026 07:00	0.7	1.5	-2	0.45	0.22392	0.75
06/25/2026 08:00	0.7	1.5	-1	0.45	0.22464	0.75
06/25/2026 09:00	0.7	1.5	-1	0.45	0.22554	0.75
06/25/2026 10:00	0.7	1.5	-1	0.45	0.22506	0.75
06/25/2026 11:00	0.7	1.5	-1	0.45	0.22440	0.75
06/25/2026 12:00	0.7	1.5	-1	0.45	0.22464	0.75
06/25/2026 13:00	0.6	1.5	-1	0.45	0.22506	0.75
06/25/2026 14:00	0.6	1.5	-1	0.45	0.22524	0.75
06/25/2026 15:00	0.6	1.5	-1	0.45	0.22518	0.75
06/25/2026 16:00	0.6	1.5	-1	0.45	0.22560	0.75
06/25/2026 17:00	0.6	1.5	-1	0.47	0.23340	0.78
06/25/2026 18:00	0.6	1.5	0	0.49	0.24660	0.82
06/25/2026 19:00	0.7	1.5	0	0.46	0.22770	0.76
06/25/2026 20:00	0.7	1.5	-1	0.45	0.22626	0.75
06/25/2026 21:00	0.7	1.5	-1	0.45	0.22614	0.75
06/25/2026 22:00	0.7	1.5	-2	0.45	0.22608	0.75
06/25/2026 23:00	0.7	1.5	-2	0.45	0.22596	0.75
Average/Sum#:	0.7	1.5	-2	0.46	0.22822	0.76
Minimum:	0.6	1.5	-3	0.45	0.22392	0.75
Maximum:	0.7	1.5	0	0.50	0.24906	0.83
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/26/2026 00:00	0.7	1.5	-2	0.45	0.22608	0.75
06/26/2026 01:00	0.7	1.5	-2	0.45	0.22608	0.75
06/26/2026 02:00	0.7	1.5	-2	0.45	0.22728	0.76
06/26/2026 03:00	0.7	1.5	-2	0.46	0.22782	0.76
06/26/2026 04:00	0.7	1.5	-2	0.46	0.22782	0.76
06/26/2026 05:00	0.7	1.5	-2	0.45	0.22716	0.76
06/26/2026 06:00	0.7	1.5	-2	0.45	0.22644	0.75
06/26/2026 07:00	0.7	1.5	-2	0.45	0.22554	0.75
06/26/2026 08:00	0.7	1.5	-2	0.45	0.22530	0.75
06/26/2026 09:00	0.8	1.5	-1	0.45	0.22518	0.75
06/26/2026 10:00	0.7	1.5	-1	0.45	0.22554	0.75
06/26/2026 11:00	0.7	1.5	-1	0.45	0.22572	0.75
06/26/2026 12:00	0.7	1.5	0	0.45	0.22530	0.75
06/26/2026 13:00	0.7	1.5	-1	0.45	0.22566	0.75
06/26/2026 14:00	0.7	1.5	-1	0.45	0.22488	0.75
06/26/2026 15:00	0.7	1.5	0	0.45	0.22422	0.75
06/26/2026 16:00	0.7	1.5	0	0.45	0.22464	0.75
06/26/2026 17:00	0.7	1.5	0	0.45	0.22446	0.75
06/26/2026 18:00	0.7	1.5	0	0.49	0.24444	0.81
06/26/2026 19:00	0.7	1.5	-1	0.46	0.22866	0.76
06/26/2026 20:00	0.7	1.5	-1	0.45	0.22614	0.75
06/26/2026 21:00	0.7	1.5	-1	0.45	0.22596	0.75
06/26/2026 22:00	0.8	1.5	-2	0.45	0.22542	0.75
06/26/2026 23:00	0.8	1.5	-2	0.45	0.22530	0.75
Average/Sum#:	0.7	1.5	-1	0.45	0.22671	0.75
Minimum:	0.7	1.5	-2	0.45	0.22422	0.75
Maximum:	0.8	1.5	0	0.49	0.24444	0.81
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/27/2026 00:00	0.8	1.5	-2	0.45	0.22530	0.75
06/27/2026 01:00	0.8	1.5	-2	0.45	0.22584	0.75
06/27/2026 02:00	0.8	1.5	-2	0.45	0.22584	0.75
06/27/2026 03:00	0.8	1.5	-2	0.45	0.22590	0.75
06/27/2026 04:00	0.8	1.5	-2	0.45	0.22632	0.75
06/27/2026 05:00	0.8	1.5	-2	0.45	0.22638	0.75
06/27/2026 06:00	0.8	1.5	-1	0.45	0.22596	0.75
06/27/2026 07:00	0.8	1.5	-2	0.45	0.22590	0.75
06/27/2026 08:00	0.7	1.5	-1	0.45	0.22560	0.75
06/27/2026 09:00	0.7	1.5	-1	0.45	0.22620	0.75
06/27/2026 10:00	0.7	1.5	-1	0.45	0.22626	0.75
06/27/2026 11:00	0.7	1.5	-1	0.45	0.22650	0.76
06/27/2026 12:00	0.7	1.5	-1	0.45	0.22692	0.76
06/27/2026 13:00	0.7	1.5	-1	0.45	0.22674	0.76
06/27/2026 14:00	0.7	1.5	-1	0.45	0.22566	0.75
06/27/2026 15:00	0.7	1.5	-1	0.45	0.22506	0.75
06/27/2026 16:00	0.7	1.5	-1	0.45	0.22548	0.75
06/27/2026 17:00	0.7	1.5	-1	0.45	0.22740	0.76
06/27/2026 18:00	0.7	1.5	-1	0.47	0.23406	0.78
06/27/2026 19:00	0.7	1.5	-1	0.45	0.22734	0.76
06/27/2026 20:00	0.7	1.5	0	0.46	0.22788	0.76
06/27/2026 21:00	0.8	1.5	-1	0.46	0.22770	0.76
06/27/2026 22:00	0.8	1.5	-1	0.45	0.22746	0.76
06/27/2026 23:00	0.8	1.5	-2	0.45	0.22698	0.76
Average/Sum#:	0.7	1.5	-1	0.45	0.22670	0.76
Minimum:	0.7	1.5	-2	0.45	0.22506	0.75
Maximum:	0.8	1.5	0	0.47	0.23406	0.78
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/28/2026 00:00	0.8	1.5	-2	0.45	0.22710	0.76
06/28/2026 01:00	0.8	1.5	-2	0.45	0.22704	0.76
06/28/2026 02:00	0.8	1.6	-2	0.45	0.22698	0.76
06/28/2026 03:00	0.8	1.5	-2	0.45	0.22722	0.76
06/28/2026 04:00	0.8	1.5	-2	0.46	0.22776	0.76
06/28/2026 05:00	0.8	1.5	-2	0.45	0.22746	0.76
06/28/2026 06:00	0.9	1.5	-1	0.45	0.22704	0.76
06/28/2026 07:00	0.8	1.5	-1	0.45	0.22656	0.76
06/28/2026 08:00	0.8	1.5	0	0.45	0.22620	0.75
06/28/2026 09:00	0.8	1.5	0	0.45	0.22554	0.75
06/28/2026 10:00	0.7	1.5	0	0.45	0.22530	0.75
06/28/2026 11:00	0.7	1.5	0	0.45	0.22638	0.75
06/28/2026 12:00	0.7	1.5	0	0.45	0.22656	0.76
06/28/2026 13:00	0.7	1.5	-1	0.45	0.22680	0.76
06/28/2026 14:00	0.7	1.5	0	0.45	0.22482	0.75
06/28/2026 15:00	0.7	1.5	0	0.45	0.22464	0.75
06/28/2026 16:00	0.7	1.5	0	0.45	0.22470	0.75
06/28/2026 17:00	0.7	1.5	0	0.45	0.22440	0.75
06/28/2026 18:00	0.7	1.5	-1	0.45	0.22482	0.75
06/28/2026 19:00	0.8	1.5	0	0.45	0.22554	0.75
06/28/2026 20:00	0.8	1.5	0	0.45	0.22590	0.75
06/28/2026 21:00	0.8	1.5	0	0.45	0.22590	0.75
06/28/2026 22:00	0.9	1.5	0	0.45	0.22572	0.75
06/28/2026 23:00	0.9	1.5	-1	0.45	0.22662	0.76
Average/Sum#:	0.8	1.5	-1	0.45	0.22613	0.75
Minimum:	0.7	1.5	-2	0.45	0.22440	0.75
Maximum:	0.9	1.6	0	0.46	0.22776	0.76
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/29/2026 00:00	0.9	1.5	-1	0.45	0.22686	0.76
06/29/2026 01:00	0.8	1.5	-1	0.45	0.22722	0.76
06/29/2026 02:00	0.8	1.5	-1	0.45	0.22716	0.76
06/29/2026 03:00	0.8	1.5	-2	0.45	0.22668	0.76
06/29/2026 04:00	0.8	1.5	-2	0.45	0.22698	0.76
06/29/2026 05:00	0.8	1.5	-1	0.45	0.22674	0.76
06/29/2026 06:00	0.8	1.5	-1	0.45	0.22686	0.76
06/29/2026 07:00	0.8	1.5	-1	0.45	0.22668	0.76
06/29/2026 08:00	0.8	1.5	0	0.45	0.22656	0.76
06/29/2026 09:00	0.8	1.5	0	0.45	0.22728	0.76
06/29/2026 10:00	0.8	1.5	0	0.45	0.22530	0.75
06/29/2026 11:00	0.8	1.5	-1	0.45	0.22458	0.75
06/29/2026 12:00	0.7	1.5	-1	0.45	0.22458	0.75
06/29/2026 13:00	0.7	1.5	-1	0.45	0.22446	0.75
06/29/2026 14:00	0.7	1.5	-1	0.45	0.22398	0.75
06/29/2026 15:00	0.7	1.5	-1	0.45	0.22476	0.75
06/29/2026 16:00	0.7	1.5	-1	0.45	0.22488	0.75
06/29/2026 17:00	0.7	1.5	0	0.46	0.22956	0.77
06/29/2026 18:00	0.8	1.5	0	0.45	0.22446	0.75
06/29/2026 19:00	0.7	1.5	-1	0.45	0.22422	0.75
06/29/2026 20:00	0.8	1.5	0	0.45	0.22482	0.75
06/29/2026 21:00	0.9	1.5	0	0.45	0.22506	0.75
06/29/2026 22:00	0.9	1.5	-1	0.45	0.22452	0.75
06/29/2026 23:00	0.8	1.5	-1	0.54	0.27246	0.91
Average/Sum#:	0.8	1.5	-1	0.45	0.22778	0.76
Minimum:	0.7	1.5	-2	0.45	0.22398	0.75
Maximum:	0.9	1.5	0	0.54	0.27246	0.91
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:35 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
06/30/2026 00:00	0.8	1.5	-1	0.54	0.27234	0.91
06/30/2026 01:00	0.7	1.5	-1	0.54	0.27216	0.91
06/30/2026 02:00	0.7	1.5	-1	0.54	0.27234	0.91
06/30/2026 03:00	0.7	1.5	-1	0.54	0.27222	0.91
06/30/2026 04:00	0.7	1.5	-1	0.54	0.27090	0.90
06/30/2026 05:00	0.8	1.5	-1	0.51	0.25572	0.85
06/30/2026 06:00	0.8	1.5	0	0.55	0.27444	0.91
06/30/2026 07:00	0.7	1.5	0	0.53	0.26598	0.89
06/30/2026 08:00	0.7	1.5	0	0.53	0.26622	0.89
06/30/2026 09:00	0.7	1.5	0	0.55	0.27276	0.91
06/30/2026 10:00	0.7	1.5	0	0.55	0.27264	0.91
06/30/2026 11:00	0.7	1.5	-1	0.45	0.22524	0.75
06/30/2026 12:00	0.7	1.5	-1	0.45	0.22548	0.75
06/30/2026 13:00	0.7	1.5	-1	0.47	0.23322	0.78
06/30/2026 14:00	0.7	1.5	0	0.47	0.23286	0.78
06/30/2026 15:00	0.7	1.5	0	0.46	0.23232	0.77
06/30/2026 16:00	0.7	1.5	-1	0.46	0.23232	0.77
06/30/2026 17:00	0.7	1.5	0	0.47	0.23550	0.79
06/30/2026 18:00	0.6	1.5	0	0.53	0.26538	0.88
06/30/2026 19:00	0.8	1.5	0	0.48	0.24036	0.80
06/30/2026 20:00	0.7	1.5	0	0.49	0.24462	0.82
06/30/2026 21:00	0.7	1.5	-1	0.47	0.23304	0.78
06/30/2026 22:00	0.7	1.5	-1	0.47	0.23370	0.78
06/30/2026 23:00	0.7	1.5	-1	0.47	0.23400	0.78
Average/Sum#:	0.7	1.5	-1	0.50	0.25149	0.84
Minimum:	0.6	1.5	-1	0.45	0.22524	0.75
Maximum:	0.8	1.5	0	0.55	0.27444	0.91
%SI	0.00	0.00	0.00	0.00	0.00	0.00

Startup / Shutdown Events

CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:46 **Location:** Roseville, CA

Unit Offline

Tag Name: CT6_UnitOn_TF_1H

Offline Periods		
Start Time	**End Time**	**Duration in Hour(s)**
04/01/2026 00:00	05/13/2026 07:00	1016
05/13/2026 14:00	05/20/2026 09:00	164
05/20/2026 11:00	05/21/2026 06:00	20
05/21/2026 09:00	05/21/2026 09:00	1
05/21/2026 17:00	06/03/2026 09:00	305
06/03/2026 16:00	06/12/2026 10:00	211
06/12/2026 22:00	06/17/2026 04:00	103
06/17/2026 20:00	06/30/2026 08:00	301
06/30/2026 10:00	06/30/2026 10:00	1
06/30/2026 12:00	06/30/2026 23:00	12

Startup / Shutdown Events

CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:46 **Location:** Roseville, CA

Operating Time Summary	
Available Data for Report (excludes missing data):	2,184.00 Hour(s)
Total Offline:	2,134.00 Hour(s)
Offline Percentage:	97.71 %
Total Online:	50.00 Hour(s)
Online Percentage:	2.29 %

Startup / Shutdown Events

CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:46 **Location:** Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	05/13/2026 08:46	05/13/2026 08:56	Startup	11
2	05/13/2026 12:58	05/13/2026 13:05	Shutdown	8
3	05/20/2026 10:40	05/20/2026 10:40	Startup	1
4	05/21/2026 07:51	05/21/2026 08:01	Startup	11
5	05/21/2026 08:39	05/21/2026 08:46	Shutdown	8
6	05/21/2026 10:51	05/21/2026 11:01	Startup	11
7	05/21/2026 15:58	05/21/2026 16:05	Shutdown	8
8	06/03/2026 10:54	06/03/2026 11:02	Startup	9
9	06/03/2026 11:02	06/03/2026 11:09	Shutdown	8
10	06/03/2026 11:55	06/03/2026 12:05	Startup	11
11	06/03/2026 14:58	06/03/2026 15:05	Shutdown	8
12	06/12/2026 11:02	06/12/2026 11:13	Startup	12
13	06/12/2026 20:58	06/12/2026 21:05	Shutdown	8
14	06/17/2026 05:51	06/17/2026 06:01	Startup	11
15	06/17/2026 18:58	06/17/2026 19:05	Shutdown	8
16	06/30/2026 09:41	06/30/2026 09:41	Startup	1
17	06/30/2026 11:43	06/30/2026 11:43	Startup	1

Startup / Shutdown Events

CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/24/2026 10:46 **Location:** Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Startup	10	79	3.53
Shutdown	7	56	2.50
Total Process Events:	17	135	6.03

Total Report Time:	2,183.98 Hour(s)
Total Operating Time:	37.33 Hour(s)
Total Startup Time:	79 Minute(s)
Total Shutdown Time:	56 Minute(s)
Total Startup/Shutdown Time:	135 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	6.03 %