DOCKETED	
Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	271661
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q2 2026 - Part 12s
Description:	N/A
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public Agency
Submission Date:	7/27/2026 2:19:01 PM
Docketed Date:	7/27/2026

RegPerfect CEMS Logs

Log Time	Operator	Initials	Description	Tags	Files
06/27/2026 12:55	cro-operator	DWN	CT2-CHANGED HIGH NOX/CO BOTTLE. CYL #EB0102637. CO 178.7 / NOX 179.0. EXP 9/30/33. CT2-CHANGED O2 BOTTLE. CYL #ALM-016181. O2 18.03. EXP 7/15/33. CT2-CHANGED INLET NOX BOTTLE. CYL #CC362946. NOX 20.58. EXP 8/19/28.		
06/26/2026 09:48	cro-operator	DWN	CT2 - CHANGED LOW NOX/CO BOTTLE. EB0096521. NOX 9.324 / CO 9.134. EXP 9/22/28.		
06/22/2026 16:10	cro-operator	PJ	CT2- CHANGED LO NOX/CO CYL #225701152 NOX CON 9.573 CO CON 8.966 EXP09/15/2032		
06/21/2026 10:40	cro-operator	PJ	CT1- CHANGED 02 CEMS BOTTLE CYL ID 225104095 SPAN 02 18.01% EXP DATE 07/15/2033		
06/19/2026 08:31	cro-operator	DWN	MONTHLY GCV FOR JUNE UPDATED TO 104,600		
06/08/2026 08:36	cro-operator	KS	CT1- PLACED CEMS OOS TO FIX 1X ALERT FOR CEMS SCR NOX LOW AND HIGH. PREFORMED A MANUAL FOLLOWED BY AN AUTO CAL. PASSED WITH NO ISSUES.		
06/04/2026 15:45	cro-operator	SM	CT6 - PERFORMED NOX ANALYZER MAINTENENCE. REBUILT REACTION CELL AND REPLACED DFU FILTER. DID MANUAL CAL AND STARTED AUTO CAL.		
06/04/2026 11:00	cro-operator	SM	CT5 - PERFORMED ANNUAL ANALYZER MAINTENANCE. REBUILD REACTION CELL, DFU FILTER AND SIGHT GLASS FOR BOTH NOX ANALYZER. REPLACED CO PUMP. SPANNED GAS, MANUAL CAL AND INITIATED HANDS FREE CAL WHEN COMPLETED.		
06/04/2026 10:19	cro-operator	KS	CT1- PREFORMED LINEARITY TEST FOR NOX HIGH AND O2. PASSED WITH NO ISSUES.		
06/03/2026 15:12	cro-operator	SM	CT2 - PERFORMED MONTHLY CEMS PM. SPANNED GAS. RECORDED TST DATA		
06/03/2026 14:13	cro-operator	SM	CT1 - CEMS MONTHLY MAINT PM. RECORDED TST DATA. SPAN GAS.		

Log Time	Operator	Initials	Description	Tags	Files
06/03/2026 13:29	cro-operator	KS	CT5- CEMS OOS TO REPLACE SCR SAMPLE PROBE HEATER BREAKER. WAS PLACED BACK IN SERVICE.		
05/27/2026 23:11	cro-operator	DC	CT2- CHANGED LOW INLET NOX BOTTLE TO ID:225702027, CON: 20.46 TOTAL NITROGEN OXIDES, EXP: 10/13/28		
05/26/2026 15:11	cro-operator	KS	CT2-PREFORMED LINEARITY TEST FOR NOX AND O2. ALSO PREFORMED CGA FOR CO HIGH AND CO LOW.		
05/26/2026 10:21	cro-operator	KS	CT2- REPLACED 18.00% O2 DAILY BOTTLE, CYL #225701002, EXP DATE-03/03/2033		
05/26/2026 10:20	cro-operator	KS	CT1- PREFORMED CGA TESTING FOR CO HIGH AND CO LOW. PASSED BOTH WITH NO ISSUES.		
05/26/2026 24:41	cro-operator	RC	CT2 : CHANGE HI NOX/CO, CYL # CC734528, NO 179.6/CO 175.1, EXP DATE 07/30/33		
05/22/2026 23:21	cro-operator	DC	CT1- CHANGED HIGH NOX/CO BOTTLE TO ID: CC253431, CON: 177 TOTAL NITROGEN OXIDES, EXP: 07/24/33		
05/14/2026 13:06	cro-operator	SM	CT6 - PERFORMED CGA FOR HI CO AND LO CO.		
05/14/2026 09:45	cro-operator	SM	CT6 - PERFORMED MANUAL CAL AND AUTO CAL TWICE TO TRUE UP NOX ANALYZER LOW NOX.		
05/13/2026 15:00	cro-operator	SM	CT 1 & 2 - PERFORMED MONTHLY CEMS MAINT. REPLACED PARTICULATE FILTER FOR EACH ANALYZER. SPANNED GAS. RECORDED TST DATA.		
05/13/2026 10:24	cro-operator	SM	CT5 - COMPLETED CGA'S FOR CO HI AND LOW		
05/13/2026 07:28	cro-operator	SM	CT2 - INITIATED HANDS FREE CAL		
05/13/2026 07:27	cro-operator	SM	CT - 6 5/12/26 PERFORMED MANUAL CAL NOX AND CO ANALYZER		
05/12/2026 07:29	cro-	DC	CT5- CHANGED INLET NOX BOTTLE TO CYLINDER ID: EB0149574, CON: 44.65		

Log Time	Operator	Initials	Description	Tags	Files
	operator		TOTAL NITRIC OXIDES, EXP: 09/22/28		
05/08/2026 15:58	cro-operator	SM	CT5 - REPLACED HICON NO2 CONVERTER. SPANNED GAS. INITIATED HANDS FREE CAL.		
05/04/2026 11:19	cro-operator	SL	UPDATED GCV VALUE TO 104200 TO CT 1/2/5/6 AND GCV_GAS		
04/19/2026 15:45	cro-operator	JB	RPEAK CT-5 SWITCHED OUT NOX 450 PPM BOTTLE ON CEMS. CYLINDER # EB0149704 EXP DATE: 11/19/33 TOTAL NITROS OXIDES 444.4		
04/18/2026 13:15	cro-operator	DC	CT2: CHANGED LOW INLET NOX BOTTLE TO ID- CC53521, CON- 20.58 TOTAL NITROGEN OXIDES, EXP- 06/10/28		
04/17/2026 06:50	cro-operator	KS	CT1- PREFORMED A MANUAL CAL THEN AUTO CAL CHECK TO FIX 1X ALARM FOR SCR HIGH AND LOW NOX		
04/16/2026 13:16	cro-operator	DC	CT1- CHANGED O2 BOTTLE TO ID: 225104093, EXP: 09/16/32, CON: 17.97 O2		
04/16/2026 11:33	cro-operator	SM	CT1 - HAD 1X ALERT FOR LOW NOX. PERFORMED MANUAL CAL AND STARTED HANDS FREE CAL.		
04/16/2026 07:01	cro-operator	DC	CT1- CHANGED LOW NOX LOW CO BOTTLE WITH BOTTLE ID: EB0004641. CONC: CO- 9.183, TOTAL NITROGEN OXIDES- 9.438 EXP- 08/12/28		
04/14/2026 15:45	cro-operator	KS	CT1- CEMS OOS TO PREFORM MANUAL CAL AND AUTO CAL CHECK TO FIX NOX CAL DRIFT.		
04/12/2026 02:22	cro-operator	DWN	UNIT 2 CEMS SCHACK O2 SENSOR CHANGED		
04/05/2026 09:12	cro-operator	SL	UNDATED GCV FOR APRIL. NEW VALUE: 104500		
04/03/2026 10:49	cro-operator	KS	CT5- CEMS OOS TO PREFORM MONTHLY CHECKS AND PREFORM AUTO CAL CHECK		
04/03/2026 10:48	cro-operator	KS	CT6- CEMS OOS TO PREFORM MONTHLY CHECKS AND PREFORM AUTO CAL CHECK		

Log Time	Operator	Initials	Description	Tags	Files
04/03/2026 10:48	cro-operator	KS	CT1- CEMS OOS TO PREFORM MONTHLY CHECKS AND PREFORM AUTO CAL CHECK		
04/03/2026 10:45	cro-operator	KS	CT2- CEMS OOS TO PREFORM MONTHLY CHECKS AND PREFORM AUTO CAL CHECK		

Linearity Report

ORIS Code: 56298
Facility Name: ROSEVILLE ENERGY
EDR Site ID: CT001
Component ID: A16
ReasonForTest: QA
Component Type: O2D
Grace Period: 0
Instrument Name: CT1_O2D_P_Instrument
Test End Date/Time: 06/04/2026
Scale: High
Performance Spec: 5 %
Test No.: 142
Highest Error: 4.0
Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
06/04/2026	0621	L	18.0	5.0	4.8		27.8 %
06/04/2026	0626	M	18.0	11.0	10.9		61.1 %
06/04/2026	0631	H	18.0	18.0	18.0		100.0 %
06/04/2026	0638	L	18.0	5.0	4.8		27.8 %
06/04/2026	0643	M	18.0	11.0	10.9		61.1 %
06/04/2026	0648	H	18.0	18.0	18.0		100.0 %
06/04/2026	0655	L	18.0	5.0	4.8		27.8 %
06/04/2026	0700	M	18.0	11.0	10.9		61.1 %
06/04/2026	0705	H	18.0	18.0	18.0		100.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.000	4.800	No	**4.0**
M	11.000	10.900	No	**0.9**
H	18.000	18.000	No	**0.0**

Linearity Report

ORIS Code: 56298
Facility Name: ROSEVILLE ENERGY
EDR Site ID: CT001
Component ID: A15
ReasonForTest: QA
Component Type: NOXA
Grace Period: 0
Instrument Name: CT1_NOXDualRg_P_Instrum
Test End Date/Time: 06/04/2026
Scale: High
Performance Spec: 5 %
Test No.: 143
Highest Error: 2.8
Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
06/04/2026	0737	L	200.0	51.7	50.0		25.9 %
06/04/2026	0742	M	200.0	111.5	110.2		55.8 %
06/04/2026	0747	H	200.0	177.0	176.7		88.5 %
06/04/2026	0754	L	200.0	51.7	50.3		25.9 %
06/04/2026	0759	M	200.0	111.5	110.5		55.8 %
06/04/2026	0804	H	200.0	177.0	176.9		88.5 %
06/04/2026	0811	L	200.0	51.7	50.4		25.9 %
06/04/2026	0816	M	200.0	111.5	110.7		55.8 %
06/04/2026	0821	H	200.0	177.0	176.9		88.5 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	51.700	50.233	No	**2.8**
M	111.500	110.467	No	**0.9**
H	177.000	176.833	No	**0.1**

Linearity Report

ORIS Code: 56298
Facility Name: ROSEVILLE ENERGY
EDR Site ID: CT002
Component ID: A22
ReasonForTest: QA
Component Type: O2D
Grace Period: 0
Instrument Name: CT2_O2D_P_Instrument
Test End Date/Time: 05/26/2026
Scale: High
Performance Spec: 5 %
Test No.: 143
Highest Error: 0.7
Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
05/26/2026	0931	L	21.0	5.0	5.0		23.8 %
05/26/2026	0936	M	21.0	11.0	11.0		52.4 %
05/26/2026	0941	H	21.0	18.0	18.0		85.7 %
05/26/2026	0948	L	21.0	5.0	5.1		23.8 %
05/26/2026	0953	M	21.0	11.0	11.0		52.4 %
05/26/2026	0958	H	21.0	18.0	18.1		85.7 %
05/26/2026	1005	L	21.0	5.0	5.0		23.8 %
05/26/2026	1010	M	21.0	11.0	11.0		52.4 %
05/26/2026	1015	H	21.0	18.0	18.0		85.7 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.000	5.033	No	**0.7**
M	11.000	11.000	No	**0.0**
H	18.000	18.033	No	**0.2**

Linearity Report

ORIS Code:	56298	Facility Name:	ROSEVILLE ENERGY		
EDR Site ID:	CT002	Component ID:	A21	ReasonForTest:	QA
		Component Type:	NOXA	Grace Period:	0
Instrument Name:	CT2_NOXDualRg_P_Instrum	Test End Date/Time:	05/26/2026	Scale:	High
Performance Spec:	5 %	Test No.:	144	Highest Error:	0.7
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
05/26/2026	1123	L	200.0	51.1	51.5		25.6 %
05/26/2026	1128	M	200.0	111.3	112.0		55.7 %
05/26/2026	1133	H	200.0	179.6	181.0		89.8 %
05/26/2026	1140	L	200.0	51.1	50.7		25.6 %
05/26/2026	1145	M	200.0	111.3	112.0		55.7 %
05/26/2026	1150	H	200.0	179.6	180.7		89.8 %
05/26/2026	1157	L	200.0	51.1	50.7		25.6 %
05/26/2026	1202	M	200.0	111.3	112.2		55.7 %
05/26/2026	1207	H	200.0	179.6	180.6		89.8 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	51.100	50.967	No	**0.3**
M	111.300	112.067	No	**0.7**
H	179.600	180.767	No	**0.6**

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
04/01/2026 00:00	0	0	0	0	0
04/01/2026 01:00	0	0	0	0	0
04/01/2026 02:00	0	0	0	0	0
04/01/2026 03:00	0	0	0	0	0
04/01/2026 04:00	0	0	0	0	0
04/01/2026 05:00	0	0	0	0	0
04/01/2026 06:00	0	0	0	0	0
04/01/2026 07:00	0	0	0	0	0
04/01/2026 08:00	1	0	2	0	0
04/01/2026 09:00	1	0	13	0	0
04/01/2026 10:00	1	0	24	0	0
04/01/2026 11:00	1	0	33	0	0
04/01/2026 12:00	1	0	33	0	0
04/01/2026 13:00	1	0	32	0	0
04/01/2026 14:00	0	0	21	0	0
04/01/2026 15:00	0	0	10	0	0
04/01/2026 16:00	0	0	0	0	0
04/01/2026 17:00	0	0	0	0	0
04/01/2026 18:00	0	0	0	0	0
04/01/2026 19:00	0	0	0	0	0
04/01/2026 20:00	0	0	0	0	0
04/01/2026 21:00	0	0	0	0	0
04/01/2026 22:00	0	0	0	0	0
04/01/2026 23:00	0	0	0	0	0
Average/Sum#:	6 #	0	7	0	0
Minimum:	0	0	0	0	0
Maximum:	1	0	33	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
04/02/2026 00:00	0	0	0	0	0
04/02/2026 01:00	0	0	0	0	0
04/02/2026 02:00	0	0	0	0	0
04/02/2026 03:00	0	0	0	0	0
04/02/2026 04:00	0	0	0	0	0
04/02/2026 05:00	0	0	0	0	0
04/02/2026 06:00	0	0	0	0	0
04/02/2026 07:00	0	0	0	0	0
04/02/2026 08:00	0	0	0	0	0
04/02/2026 09:00	0	0	0	0	0
04/02/2026 10:00	0	0	0	0	0
04/02/2026 11:00	0	0	0	0	0
04/02/2026 12:00	0	0	0	0	0
04/02/2026 13:00	0	0	0	0	0
04/02/2026 14:00	0	0	0	0	0
04/02/2026 15:00	0	0	0	0	0
04/02/2026 16:00	0	0	0	0	0
04/02/2026 17:00	0	0	0	0	0
04/02/2026 18:00	0	0	0	0	0
04/02/2026 19:00	0	0	0	0	0
04/02/2026 20:00	0	0	0	0	0
04/02/2026 21:00	0	0	0	0	0
04/02/2026 22:00	0	0	0	0	0
04/02/2026 23:00	0	0	0	0	0
Average/Sum#:	0 #	0	0	0	0
Minimum:	0	0	0	0	0
Maximum:	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
04/03/2026 00:00	0	0	0	0	0
04/03/2026 01:00	0	0	0	0	0
04/03/2026 02:00	0	0	0	0	0
04/03/2026 03:00	0	0	0	0	0
04/03/2026 04:00	0	0	0	0	0
04/03/2026 05:00	0	0	0	0	0
04/03/2026 06:00	0	0	0	0	0
04/03/2026 07:00	0	0	0	0	0
04/03/2026 08:00	0	0	0	0	0
04/03/2026 09:00	0	0	0	0	0
04/03/2026 10:00	0	0	0	0	0
04/03/2026 11:00	0	0	0	0	0
04/03/2026 12:00	0	0	0	0	0
04/03/2026 13:00	0	0	0	0	0
04/03/2026 14:00	0	0	0	0	0
04/03/2026 15:00	0	0	0	0	0
04/03/2026 16:00	0	0	0	0	0
04/03/2026 17:00	0	0	0	0	0
04/03/2026 18:00	0	0	0	0	0
04/03/2026 19:00	0	0	0	0	0
04/03/2026 20:00	0	0	0	0	0
04/03/2026 21:00	0	0	0	0	0
04/03/2026 22:00	0	0	0	0	0
04/03/2026 23:00	0	0	0	0	0
Average/Sum#:	0 #	0	0	0	0
Minimum:	0	0	0	0	0
Maximum:	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
04/04/2026 00:00	0	0	0	0	0
04/04/2026 01:00	0	0	0	0	0
04/04/2026 02:00	0	0	0	0	0
04/04/2026 03:00	0	0	0	0	0
04/04/2026 04:00	0	0	0	0	0
04/04/2026 05:00	0	0	0	0	0
04/04/2026 06:00	0	0	0	0	0
04/04/2026 07:00	0	0	0	0	0
04/04/2026 08:00	0	0	0	0	0
04/04/2026 09:00	0	0	0	0	0
04/04/2026 10:00	0	0	0	0	0
04/04/2026 11:00	0	0	0	0	0
04/04/2026 12:00	0	0	0	0	0
04/04/2026 13:00	0	0	0	0	0
04/04/2026 14:00	0	0	0	0	0
04/04/2026 15:00	0	0	0	0	0
04/04/2026 16:00	0	0	0	0	0
04/04/2026 17:00	0	0	0	0	0
04/04/2026 18:00	0	0	0	0	0
04/04/2026 19:00	0	0	0	0	0
04/04/2026 20:00	0	0	0	0	0
04/04/2026 21:00	0	0	0	0	0
04/04/2026 22:00	0	0	0	0	0
04/04/2026 23:00	0	0	0	0	0
Average/Sum#:	0 #	0	0	0	0
Minimum:	0	0	0	0	0
Maximum:	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
04/05/2026 00:00	0	0	0	0	0
04/05/2026 01:00	0	0	0	0	0
04/05/2026 02:00	0	0	0	0	0
04/05/2026 03:00	0	0	0	0	0
04/05/2026 04:00	0	0	0	0	0
04/05/2026 05:00	0	0	0	0	0
04/05/2026 06:00	0	0	0	0	0
04/05/2026 07:00	0	0	0	0	0
04/05/2026 08:00	0	0	0	0	0
04/05/2026 09:00	0	0	0	0	0
04/05/2026 10:00	0	0	0	0	0
04/05/2026 11:00	0	0	0	0	0
04/05/2026 12:00	0	0	0	0	0
04/05/2026 13:00	0	0	0	0	0
04/05/2026 14:00	0	0	0	0	0
04/05/2026 15:00	0	0	0	0	0
04/05/2026 16:00	0	0	0	0	0
04/05/2026 17:00	0	0	0	0	0
04/05/2026 18:00	0	0	0	0	0
04/05/2026 19:00	0	0	0	0	0
04/05/2026 20:00	0	0	0	0	0
04/05/2026 21:00	0	0	0	0	0
04/05/2026 22:00	0	0	0	0	0
04/05/2026 23:00	0	0	0	0	0
Average/Sum#:	0 #	0	0	0	0
Minimum:	0	0	0	0	0
Maximum:	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
04/06/2026 00:00	0	0	0	0	0
04/06/2026 01:00	0	0	0	0	0
04/06/2026 02:00	0	0	0	0	0
04/06/2026 03:00	0	0	0	0	0
04/06/2026 04:00	0	0	0	0	0
04/06/2026 05:00	0	0	0	0	0
04/06/2026 06:00	0	0	0	0	0
04/06/2026 07:00	0	0	0	0	0
04/06/2026 08:00	0	0	0	0	0
04/06/2026 09:00	0	0	0	0	0
04/06/2026 10:00	0	0	0	0	0
04/06/2026 11:00	0	0	0	0	0
04/06/2026 12:00	0	0	0	0	0
04/06/2026 13:00	0	0	0	0	0
04/06/2026 14:00	0	0	0	0	0
04/06/2026 15:00	0	0	0	0	0
04/06/2026 16:00	0	0	0	0	0
04/06/2026 17:00	0	0	0	0	0
04/06/2026 18:00	0	0	0	0	0
04/06/2026 19:00	0	0	0	0	0
04/06/2026 20:00	0	0	0	0	0
04/06/2026 21:00	0	0	0	0	0
04/06/2026 22:00	0	0	0	0	0
04/06/2026 23:00	0	0	0	0	0
Average/Sum#:	0 #	0	0	0	0
Minimum:	0	0	0	0	0
Maximum:	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
04/07/2026 00:00	0	0	0	0	0
04/07/2026 01:00	0	0	0	0	0
04/07/2026 02:00	0	0	0	0	0
04/07/2026 03:00	0	0	0	0	0
04/07/2026 04:00	0	0	0	0	0
04/07/2026 05:00	0	0	0	0	0
04/07/2026 06:00	0	0	0	0	0
04/07/2026 07:00	0	0	0	0	0
04/07/2026 08:00	0	0	0	0	0
04/07/2026 09:00	0	0	0	0	0
04/07/2026 10:00	0	0	0	0	0
04/07/2026 11:00	0	0	0	0	0
04/07/2026 12:00	0	0	0	0	0
04/07/2026 13:00	0	0	0	0	0
04/07/2026 14:00	0	0	0	0	0
04/07/2026 15:00	0	0	0	0	0
04/07/2026 16:00	0	0	0	0	0
04/07/2026 17:00	0	0	0	0	0
04/07/2026 18:00	0	0	0	0	0
04/07/2026 19:00	0	0	0	0	0
04/07/2026 20:00	0	0	0	0	0
04/07/2026 21:00	0	0	0	0	0
04/07/2026 22:00	0	0	0	0	0
04/07/2026 23:00	0	0	0	0	0
Average/Sum#:	0 #	0	0	0	0
Minimum:	0	0	0	0	0
Maximum:	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
04/08/2026 00:00	0	0	0	0	0
04/08/2026 01:00	0	0	0	0	0
04/08/2026 02:00	0	0	0	0	0
04/08/2026 03:00	0	0	0	0	0
04/08/2026 04:00	0	0	0	0	0
04/08/2026 05:00	0	0	0	0	0
04/08/2026 06:00	0	0	0	0	0
04/08/2026 07:00	0	0	0	0	0
04/08/2026 08:00	1	0	3	0	0
04/08/2026 09:00	1	0	14	0	0
04/08/2026 10:00	1	0	25	0	0
04/08/2026 11:00	1	0	36	0	0
04/08/2026 12:00	1	0	40	0	0
04/08/2026 13:00	1	0	44	0	0
04/08/2026 14:00	1	0	44	0	0
04/08/2026 15:00	1	0	43	0	0
04/08/2026 16:00	1	0	31	0	0
04/08/2026 17:00	0	0	16	0	0
04/08/2026 18:00	0	0	2	0	0
04/08/2026 19:00	0	0	0	0	0
04/08/2026 20:00	0	0	0	0	0
04/08/2026 21:00	0	0	0	0	0
04/08/2026 22:00	0	0	0	0	0
04/08/2026 23:00	0	0	0	0	0
Average/Sum#:	9 #	0	12	0	0
Minimum:	0	0	0	0	0
Maximum:	1	0	44	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
04/09/2026 00:00	0	0	0	0	0
04/09/2026 01:00	0	0	0	0	0
04/09/2026 02:00	0	0	0	0	0
04/09/2026 03:00	0	0	0	0	0
04/09/2026 04:00	0	0	0	0	0
04/09/2026 05:00	0	0	0	0	0
04/09/2026 06:00	1	0	3	0	0
04/09/2026 07:00	1	0	14	0	0
04/09/2026 08:00	1	0	25	0	0
04/09/2026 09:00	1	0	37	0	0
04/09/2026 10:00	1	0	43	0	0
04/09/2026 11:00	1	0	47	0	0
04/09/2026 12:00	1	0	37	0	0
04/09/2026 13:00	0	0	21	0	0
04/09/2026 14:00	0	0	6	0	0
04/09/2026 15:00	0	0	0	0	0
04/09/2026 16:00	0	0	0	0	0
04/09/2026 17:00	0	0	0	0	0
04/09/2026 18:00	0	0	0	0	0
04/09/2026 19:00	0	0	0	0	0
04/09/2026 20:00	0	0	0	0	0
04/09/2026 21:00	0	0	0	0	0
04/09/2026 22:00	0	0	0	0	0
04/09/2026 23:00	0	0	0	0	0
Average/Sum#:	7 #	0	10	0	0
Minimum:	0	0	0	0	0
Maximum:	1	0	47	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
04/10/2026 00:00	0	0	0	0	0
04/10/2026 01:00	0	0	0	0	0
04/10/2026 02:00	0	0	0	0	0
04/10/2026 03:00	0	0	0	0	0
04/10/2026 04:00	0	0	0	0	0
04/10/2026 05:00	0	0	0	0	0
04/10/2026 06:00	0	0	0	0	0
04/10/2026 07:00	0	0	0	0	0
04/10/2026 08:00	0	0	0	0	0
04/10/2026 09:00	0	0	0	0	0
04/10/2026 10:00	0	0	0	0	0
04/10/2026 11:00	0	0	0	0	0
04/10/2026 12:00	0	0	0	0	0
04/10/2026 13:00	0	0	0	0	0
04/10/2026 14:00	0	0	0	0	0
04/10/2026 15:00	0	0	0	0	0
04/10/2026 16:00	0	0	0	0	0
04/10/2026 17:00	0	0	0	0	0
04/10/2026 18:00	0	0	0	0	0
04/10/2026 19:00	0	0	0	0	0
04/10/2026 20:00	0	0	0	0	0
04/10/2026 21:00	0	0	0	0	0
04/10/2026 22:00	0	0	0	0	0
04/10/2026 23:00	0	0	0	0	0
Average/Sum#:	0 #	0	0	0	0
Minimum:	0	0	0	0	0
Maximum:	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
04/11/2026 00:00	0	0	0	0	0
04/11/2026 01:00	0	0	0	0	0
04/11/2026 02:00	0	0	0	0	0
04/11/2026 03:00	0	0	0	0	0
04/11/2026 04:00	0	0	0	0	0
04/11/2026 05:00	0	0	0	0	0
04/11/2026 06:00	0	0	0	0	0
04/11/2026 07:00	0	0	0	0	0
04/11/2026 08:00	0	0	0	0	0
04/11/2026 09:00	0	0	0	0	0
04/11/2026 10:00	0	0	0	0	0
04/11/2026 11:00	0	0	0	0	0
04/11/2026 12:00	0	0	0	0	0
04/11/2026 13:00	0	0	0	0	0
04/11/2026 14:00	0	0	0	0	0
04/11/2026 15:00	0	0	0	0	0
04/11/2026 16:00	0	0	0	0	0
04/11/2026 17:00	0	0	0	0	0
04/11/2026 18:00	0	0	0	0	0
04/11/2026 19:00	0	0	0	0	0
04/11/2026 20:00	0	0	0	0	0
04/11/2026 21:00	0	0	0	0	0
04/11/2026 22:00	0	0	0	0	0
04/11/2026 23:00	0	0	0	0	0
Average/Sum#:	0 #	0	0	0	0
Minimum:	0	0	0	0	0
Maximum:	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
04/12/2026 00:00	0	0	0	0	0
04/12/2026 01:00	0	0	0	0	0
04/12/2026 02:00	0	0	0	0	0
04/12/2026 03:00	0	0	0	0	0
04/12/2026 04:00	0	0	0	0	0
04/12/2026 05:00	0	0	0	0	0
04/12/2026 06:00	0	0	0	0	0
04/12/2026 07:00	0	0	0	0	0
04/12/2026 08:00	0	0	0	0	0
04/12/2026 09:00	0	0	0	0	0
04/12/2026 10:00	0	0	0	0	0
04/12/2026 11:00	0	0	0	0	0
04/12/2026 12:00	0	0	0	0	0
04/12/2026 13:00	0	0	0	0	0
04/12/2026 14:00	0	0	0	0	0
04/12/2026 15:00	0	0	0	0	0
04/12/2026 16:00	0	0	0	0	0
04/12/2026 17:00	0	0	0	0	0
04/12/2026 18:00	0	0	0	0	0
04/12/2026 19:00	0	0	0	0	0
04/12/2026 20:00	0	0	0	0	0
04/12/2026 21:00	0	0	0	0	0
04/12/2026 22:00	0	0	0	0	0
04/12/2026 23:00	0	0	0	0	0
Average/Sum#:	0 #	0	0	0	0
Minimum:	0	0	0	0	0
Maximum:	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
04/13/2026 00:00	0	0	0	0	0
04/13/2026 01:00	0	0	0	0	0
04/13/2026 02:00	0	0	0	0	0
04/13/2026 03:00	0	0	0	0	0
04/13/2026 04:00	0	0	0	0	0
04/13/2026 05:00	0	0	0	0	0
04/13/2026 06:00	0	0	0	0	0
04/13/2026 07:00	0	0	0	0	0
04/13/2026 08:00	0	0	0	0	0
04/13/2026 09:00	0	0	0	0	0
04/13/2026 10:00	0	0	0	0	0
04/13/2026 11:00	0	0	0	0	0
04/13/2026 12:00	0	0	0	0	0
04/13/2026 13:00	0	0	0	0	0
04/13/2026 14:00	0	0	0	0	0
04/13/2026 15:00	0	0	0	0	0
04/13/2026 16:00	0	0	0	0	0
04/13/2026 17:00	0	0	0	0	0
04/13/2026 18:00	0	0	0	0	0
04/13/2026 19:00	0	0	0	0	0
04/13/2026 20:00	0	0	0	0	0
04/13/2026 21:00	0	0	0	0	0
04/13/2026 22:00	0	0	0	0	0
04/13/2026 23:00	0	0	0	0	0
Average/Sum#:	0 #	0	0	0	0
Minimum:	0	0	0	0	0
Maximum:	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
04/14/2026 00:00	0	0	0	0	0
04/14/2026 01:00	0	0	0	0	0
04/14/2026 02:00	0	0	0	0	0
04/14/2026 03:00	0	0	0	0	0
04/14/2026 04:00	0	0	0	0	0
04/14/2026 05:00	0	0	0	0	0
04/14/2026 06:00	1	0	3	0	0
04/14/2026 07:00	1	0	14	0	0
04/14/2026 08:00	1	0	26	0	0
04/14/2026 09:00	1	4	39	0	0
04/14/2026 10:00	1	18	43	0	0
04/14/2026 11:00	1	38	51	0	0
04/14/2026 12:00	1	60	60	0	0
04/14/2026 13:00	1	63	64	0	0
04/14/2026 14:00	1	43	51	0	0
04/14/2026 15:00	0	17	25	0	0
04/14/2026 16:00	0	0	7	0	0
04/14/2026 17:00	0	0	0	0	0
04/14/2026 18:00	0	0	0	0	0
04/14/2026 19:00	0	0	0	0	0
04/14/2026 20:00	0	0	0	0	0
04/14/2026 21:00	0	0	0	0	0
04/14/2026 22:00	0	0	0	0	0
04/14/2026 23:00	0	0	0	0	0
Average/Sum#:	9 #	10	16	0	0
Minimum:	0	0	0	0	0
Maximum:	1	63	64	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
04/15/2026 00:00	0	0	0	0	0
04/15/2026 01:00	0	0	0	0	0
04/15/2026 02:00	0	0	0	0	0
04/15/2026 03:00	0	0	0	0	0
04/15/2026 04:00	0	0	0	0	0
04/15/2026 05:00	0	0	0	0	0
04/15/2026 06:00	0	0	0	0	0
04/15/2026 07:00	0	0	0	0	0
04/15/2026 08:00	0	0	0	0	0
04/15/2026 09:00	0	0	0	0	0
04/15/2026 10:00	0	0	0	0	0
04/15/2026 11:00	0	0	0	0	0
04/15/2026 12:00	0	0	0	0	0
04/15/2026 13:00	0	0	0	0	0
04/15/2026 14:00	0	0	0	0	0
04/15/2026 15:00	0	0	0	0	0
04/15/2026 16:00	0	0	0	0	0
04/15/2026 17:00	0	0	0	0	0
04/15/2026 18:00	0	0	0	0	0
04/15/2026 19:00	0	0	0	0	0
04/15/2026 20:00	0	0	0	0	0
04/15/2026 21:00	0	0	0	0	0
04/15/2026 22:00	1	0	5	0	0
04/15/2026 23:00	1	0	18	0	0
Average/Sum#:	2 #	0	1	0	0
Minimum:	0	0	0	0	0
Maximum:	1	0	18	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
04/16/2026 00:00	1	0	33	0	0
04/16/2026 01:00	1	0	43	0	0
04/16/2026 02:00	1	0	45	0	0
04/16/2026 03:00	1	0	45	0	0
04/16/2026 04:00	1	0	46	0	0
04/16/2026 05:00	1	0	46	0	0
04/16/2026 06:00	1	0	46	0	0
04/16/2026 07:00	1	3	44	0	0
04/16/2026 08:00	1	17	43	0	0
04/16/2026 09:00	1	32	43	0	0
04/16/2026 10:00	1	44	43	0	0
04/16/2026 11:00	1	44	44	0	0
04/16/2026 12:00	1	44	44	0	0
04/16/2026 13:00	1	44	44	0	0
04/16/2026 14:00	1	42	43	0	0
04/16/2026 15:00	0	28	28	0	0
04/16/2026 16:00	1	13	17	0	0
04/16/2026 17:00	1	0	14	0	0
04/16/2026 18:00	1	0	25	0	0
04/16/2026 19:00	1	0	32	0	0
04/16/2026 20:00	1	0	32	0	0
04/16/2026 21:00	1	0	32	0	0
04/16/2026 22:00	1	5	32	0	0
04/16/2026 23:00	1	15	31	0	0
Average/Sum#:	23 #	14	37	0	0
Minimum:	0	0	14	0	0
Maximum:	1	44	46	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
04/17/2026 00:00	1	28	34	0	0
04/17/2026 01:00	1	38	38	0	0
04/17/2026 02:00	1	42	42	0	0
04/17/2026 03:00	1	43	43	0	0
04/17/2026 04:00	1	44	44	0	0
04/17/2026 05:00	1	44	44	0	0
04/17/2026 06:00	1	44	44	0	0
04/17/2026 07:00	1	44	44	0	0
04/17/2026 08:00	1	44	44	0	0
04/17/2026 09:00	1	44	44	0	0
04/17/2026 10:00	1	44	44	0	0
04/17/2026 11:00	1	44	44	0	0
04/17/2026 12:00	1	44	44	0	0
04/17/2026 13:00	1	44	43	0	0
04/17/2026 14:00	1	44	43	0	0
04/17/2026 15:00	1	44	43	0	0
04/17/2026 16:00	1	44	43	0	0
04/17/2026 17:00	1	44	44	0	0
04/17/2026 18:00	1	44	44	0	0
04/17/2026 19:00	1	44	44	0	0
04/17/2026 20:00	1	44	44	0	0
04/17/2026 21:00	1	44	44	0	0
04/17/2026 22:00	1	44	44	0	0
04/17/2026 23:00	1	44	44	0	0
Average/Sum#:	24 #	43	43	0	0
Minimum:	1	28	34	0	0
Maximum:	1	44	44	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
04/18/2026 00:00	1	44	44	0	0
04/18/2026 01:00	1	44	44	0	0
04/18/2026 02:00	1	44	44	0	0
04/18/2026 03:00	1	44	44	0	0
04/18/2026 04:00	1	44	44	0	0
04/18/2026 05:00	1	44	44	0	0
04/18/2026 06:00	1	44	44	0	0
04/18/2026 07:00	1	44	44	0	0
04/18/2026 08:00	1	44	44	0	0
04/18/2026 09:00	1	44	44	0	0
04/18/2026 10:00	1	44	44	0	0
04/18/2026 11:00	1	44	43	0	0
04/18/2026 12:00	1	44	44	0	0
04/18/2026 13:00	1	44	44	0	0
04/18/2026 14:00	1	44	44	0	0
04/18/2026 15:00	1	44	44	0	0
04/18/2026 16:00	1	44	44	0	0
04/18/2026 17:00	1	44	44	0	0
04/18/2026 18:00	1	44	44	0	0
04/18/2026 19:00	1	44	44	0	0
04/18/2026 20:00	1	44	44	0	0
04/18/2026 21:00	1	44	44	0	0
04/18/2026 22:00	1	44	44	0	0
04/18/2026 23:00	1	44	44	0	0
Average/Sum#:	24 #	44	44	0	0
Minimum:	1	44	43	0	0
Maximum:	1	44	44	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
04/19/2026 00:00	1	44	44	0	0
04/19/2026 01:00	1	44	44	0	0
04/19/2026 02:00	1	44	44	0	0
04/19/2026 03:00	1	44	44	0	0
04/19/2026 04:00	1	44	44	0	0
04/19/2026 05:00	1	44	44	0	0
04/19/2026 06:00	1	44	44	0	0
04/19/2026 07:00	1	44	44	0	0
04/19/2026 08:00	1	44	44	0	0
04/19/2026 09:00	1	44	44	0	0
04/19/2026 10:00	1	44	44	0	0
04/19/2026 11:00	1	44	44	0	0
04/19/2026 12:00	1	44	44	0	0
04/19/2026 13:00	1	44	44	0	0
04/19/2026 14:00	1	44	44	0	0
04/19/2026 15:00	1	44	44	0	0
04/19/2026 16:00	1	44	44	0	0
04/19/2026 17:00	1	44	44	0	0
04/19/2026 18:00	1	44	44	0	0
04/19/2026 19:00	1	44	44	0	0
04/19/2026 20:00	1	44	44	0	0
04/19/2026 21:00	1	44	44	0	0
04/19/2026 22:00	1	44	44	0	0
04/19/2026 23:00	1	44	44	0	0
Average/Sum#:	24 #	44	44	0	0
Minimum:	1	44	44	0	0
Maximum:	1	44	44	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
04/20/2026 00:00	1	44	44	0	0
04/20/2026 01:00	1	44	44	0	0
04/20/2026 02:00	1	44	44	0	0
04/20/2026 03:00	1	44	44	0	0
04/20/2026 04:00	1	44	44	0	0
04/20/2026 05:00	1	44	44	0	0
04/20/2026 06:00	1	44	44	0	0
04/20/2026 07:00	1	44	44	0	0
04/20/2026 08:00	1	44	44	0	0
04/20/2026 09:00	1	44	44	0	0
04/20/2026 10:00	1	44	44	0	0
04/20/2026 11:00	1	44	44	0	0
04/20/2026 12:00	1	44	43	0	0
04/20/2026 13:00	1	44	43	0	0
04/20/2026 14:00	1	44	44	0	0
04/20/2026 15:00	1	44	44	0	0
04/20/2026 16:00	1	44	44	0	0
04/20/2026 17:00	1	44	44	0	0
04/20/2026 18:00	1	44	44	0	0
04/20/2026 19:00	1	44	44	0	0
04/20/2026 20:00	1	44	44	0	0
04/20/2026 21:00	1	44	44	0	0
04/20/2026 22:00	1	42	42	0	0
04/20/2026 23:00	1	28	28	0	0
Average/Sum#:	24 #	43	43	0	0
Minimum:	1	28	28	0	0
Maximum:	1	44	44	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
04/21/2026 00:00	0	13	13	0	0
04/21/2026 01:00	0	0	0	0	0
04/21/2026 02:00	0	0	0	0	0
04/21/2026 03:00	0	0	0	0	0
04/21/2026 04:00	0	0	0	0	0
04/21/2026 05:00	0	0	0	0	0
04/21/2026 06:00	0	0	0	0	0
04/21/2026 07:00	0	0	0	0	0
04/21/2026 08:00	0	0	0	0	0
04/21/2026 09:00	0	0	0	0	0
04/21/2026 10:00	0	0	0	0	0
04/21/2026 11:00	0	0	0	0	0
04/21/2026 12:00	0	0	0	0	0
04/21/2026 13:00	0	0	0	0	0
04/21/2026 14:00	0	0	0	0	0
04/21/2026 15:00	0	0	0	0	0
04/21/2026 16:00	0	0	0	0	0
04/21/2026 17:00	0	0	0	0	0
04/21/2026 18:00	0	0	0	0	0
04/21/2026 19:00	0	0	0	0	0
04/21/2026 20:00	0	0	0	0	0
04/21/2026 21:00	0	0	0	0	0
04/21/2026 22:00	0	0	0	0	0
04/21/2026 23:00	0	0	0	0	0
Average/Sum#:	0 #	1	1	0	0
Minimum:	0	0	0	0	0
Maximum:	0	13	13	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
04/22/2026 00:00	0	0	0	0	0
04/22/2026 01:00	0	0	0	0	0
04/22/2026 02:00	0	0	0	0	0
04/22/2026 03:00	0	0	0	0	0
04/22/2026 04:00	0	0	0	0	0
04/22/2026 05:00	0	0	0	0	0
04/22/2026 06:00	0	0	0	0	0
04/22/2026 07:00	0	0	0	0	0
04/22/2026 08:00	0	0	0	0	0
04/22/2026 09:00	0	0	0	0	0
04/22/2026 10:00	0	0	0	0	0
04/22/2026 11:00	0	0	0	0	0
04/22/2026 12:00	0	0	0	0	0
04/22/2026 13:00	0	0	0	0	0
04/22/2026 14:00	0	0	0	0	0
04/22/2026 15:00	0	0	0	0	0
04/22/2026 16:00	0	0	0	0	0
04/22/2026 17:00	0	0	0	0	0
04/22/2026 18:00	0	0	0	0	0
04/22/2026 19:00	0	0	0	0	0
04/22/2026 20:00	0	0	0	0	0
04/22/2026 21:00	0	0	0	0	0
04/22/2026 22:00	0	0	0	0	0
04/22/2026 23:00	0	0	0	0	0
Average/Sum#:	0 #	0	0	0	0
Minimum:	0	0	0	0	0
Maximum:	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
04/23/2026 00:00	0	0	0	0	0
04/23/2026 01:00	0	0	0	0	0
04/23/2026 02:00	0	0	0	0	0
04/23/2026 03:00	0	0	0	0	0
04/23/2026 04:00	0	0	0	0	0
04/23/2026 05:00	0	0	0	0	0
04/23/2026 06:00	0	0	0	0	0
04/23/2026 07:00	0	0	0	0	0
04/23/2026 08:00	0	0	0	0	0
04/23/2026 09:00	0	0	0	0	0
04/23/2026 10:00	0	0	0	0	0
04/23/2026 11:00	0	0	0	0	0
04/23/2026 12:00	0	0	0	0	0
04/23/2026 13:00	0	0	0	0	0
04/23/2026 14:00	0	0	0	0	0
04/23/2026 15:00	0	0	0	0	0
04/23/2026 16:00	0	0	0	0	0
04/23/2026 17:00	0	0	0	0	0
04/23/2026 18:00	0	0	0	0	0
04/23/2026 19:00	0	0	0	0	0
04/23/2026 20:00	0	0	0	0	0
04/23/2026 21:00	0	0	0	0	0
04/23/2026 22:00	0	0	0	0	0
04/23/2026 23:00	0	0	0	0	0
Average/Sum#:	0 #	0	0	0	0
Minimum:	0	0	0	0	0
Maximum:	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
04/24/2026 00:00	0	0	0	0	0
04/24/2026 01:00	0	0	0	0	0
04/24/2026 02:00	0	0	0	0	0
04/24/2026 03:00	0	0	0	0	0
04/24/2026 04:00	0	0	0	0	0
04/24/2026 05:00	0	0	0	0	0
04/24/2026 06:00	0	0	0	0	0
04/24/2026 07:00	0	0	0	0	0
04/24/2026 08:00	0	0	0	0	0
04/24/2026 09:00	0	0	0	0	0
04/24/2026 10:00	0	0	0	0	0
04/24/2026 11:00	0	0	0	0	0
04/24/2026 12:00	0	0	0	0	0
04/24/2026 13:00	0	0	0	0	0
04/24/2026 14:00	0	0	0	0	0
04/24/2026 15:00	0	0	0	0	0
04/24/2026 16:00	0	0	0	0	0
04/24/2026 17:00	0	0	0	0	0
04/24/2026 18:00	0	0	0	0	0
04/24/2026 19:00	0	0	0	0	0
04/24/2026 20:00	0	0	0	0	0
04/24/2026 21:00	0	0	0	0	0
04/24/2026 22:00	0	0	0	0	0
04/24/2026 23:00	0	0	0	0	0
Average/Sum#:	0 #	0	0	0	0
Minimum:	0	0	0	0	0
Maximum:	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
04/25/2026 00:00	0	0	0	0	0
04/25/2026 01:00	0	0	0	0	0
04/25/2026 02:00	0	0	0	0	0
04/25/2026 03:00	0	0	0	0	0
04/25/2026 04:00	0	0	0	0	0
04/25/2026 05:00	0	0	0	0	0
04/25/2026 06:00	0	0	0	0	0
04/25/2026 07:00	0	0	0	0	0
04/25/2026 08:00	0	0	0	0	0
04/25/2026 09:00	0	0	0	0	0
04/25/2026 10:00	0	0	0	0	0
04/25/2026 11:00	0	0	0	0	0
04/25/2026 12:00	0	0	0	0	0
04/25/2026 13:00	0	0	0	0	0
04/25/2026 14:00	0	0	0	0	0
04/25/2026 15:00	0	0	0	0	0
04/25/2026 16:00	0	0	0	0	0
04/25/2026 17:00	0	0	0	0	0
04/25/2026 18:00	0	0	0	0	0
04/25/2026 19:00	0	0	0	0	0
04/25/2026 20:00	0	0	0	0	0
04/25/2026 21:00	0	0	0	0	0
04/25/2026 22:00	0	0	0	0	0
04/25/2026 23:00	0	0	0	0	0
Average/Sum#:	0 #	0	0	0	0
Minimum:	0	0	0	0	0
Maximum:	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
04/26/2026 00:00	0	0	0	0	0
04/26/2026 01:00	0	0	0	0	0
04/26/2026 02:00	0	0	0	0	0
04/26/2026 03:00	0	0	0	0	0
04/26/2026 04:00	0	0	0	0	0
04/26/2026 05:00	0	0	0	0	0
04/26/2026 06:00	0	0	0	0	0
04/26/2026 07:00	0	0	0	0	0
04/26/2026 08:00	0	0	0	0	0
04/26/2026 09:00	0	0	0	0	0
04/26/2026 10:00	0	0	0	0	0
04/26/2026 11:00	0	0	0	0	0
04/26/2026 12:00	0	0	0	0	0
04/26/2026 13:00	0	0	0	0	0
04/26/2026 14:00	0	0	0	0	0
04/26/2026 15:00	0	0	0	0	0
04/26/2026 16:00	0	0	0	0	0
04/26/2026 17:00	0	0	0	0	0
04/26/2026 18:00	0	0	0	0	0
04/26/2026 19:00	0	0	0	0	0
04/26/2026 20:00	0	0	0	0	0
04/26/2026 21:00	0	0	0	0	0
04/26/2026 22:00	0	0	0	0	0
04/26/2026 23:00	0	0	0	0	0
Average/Sum#:	0 #	0	0	0	0
Minimum:	0	0	0	0	0
Maximum:	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
04/27/2026 00:00	0	0	0	0	0
04/27/2026 01:00	0	0	0	0	0
04/27/2026 02:00	0	0	0	0	0
04/27/2026 03:00	0	0	0	0	0
04/27/2026 04:00	0	0	0	0	0
04/27/2026 05:00	0	0	0	0	0
04/27/2026 06:00	0	0	0	0	0
04/27/2026 07:00	0	0	0	0	0
04/27/2026 08:00	0	0	0	0	0
04/27/2026 09:00	0	0	0	0	0
04/27/2026 10:00	0	0	0	0	0
04/27/2026 11:00	0	0	0	0	0
04/27/2026 12:00	0	0	0	0	0
04/27/2026 13:00	0	0	0	0	0
04/27/2026 14:00	0	0	0	0	0
04/27/2026 15:00	0	0	0	0	0
04/27/2026 16:00	0	0	0	0	0
04/27/2026 17:00	0	0	0	0	0
04/27/2026 18:00	0	0	0	0	0
04/27/2026 19:00	0	0	0	0	0
04/27/2026 20:00	0	0	0	0	0
04/27/2026 21:00	0	0	0	0	0
04/27/2026 22:00	0	0	0	0	0
04/27/2026 23:00	0	0	0	0	0
Average/Sum#:	0 #	0	0	0	0
Minimum:	0	0	0	0	0
Maximum:	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
04/28/2026 00:00	0	0	0	0	0
04/28/2026 01:00	0	0	0	0	0
04/28/2026 02:00	0	0	0	0	0
04/28/2026 03:00	0	0	0	0	0
04/28/2026 04:00	0	0	0	0	0
04/28/2026 05:00	0	0	0	0	0
04/28/2026 06:00	0	0	0	0	0
04/28/2026 07:00	0	0	0	0	0
04/28/2026 08:00	0	0	0	0	0
04/28/2026 09:00	0	0	0	0	0
04/28/2026 10:00	0	0	0	0	0
04/28/2026 11:00	0	0	0	0	0
04/28/2026 12:00	0	0	0	0	0
04/28/2026 13:00	0	0	0	0	0
04/28/2026 14:00	0	0	0	0	0
04/28/2026 15:00	0	0	0	0	0
04/28/2026 16:00	0	0	0	0	0
04/28/2026 17:00	0	0	0	0	0
04/28/2026 18:00	0	0	0	0	0
04/28/2026 19:00	0	0	0	0	0
04/28/2026 20:00	0	0	0	0	0
04/28/2026 21:00	0	0	0	0	0
04/28/2026 22:00	0	0	0	0	0
04/28/2026 23:00	0	0	0	0	0
Average/Sum#:	0 #	0	0	0	0
Minimum:	0	0	0	0	0
Maximum:	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
04/29/2026 00:00	0	0	0	0	0
04/29/2026 01:00	0	0	0	0	0
04/29/2026 02:00	0	0	0	0	0
04/29/2026 03:00	0	0	0	0	0
04/29/2026 04:00	0	0	0	0	0
04/29/2026 05:00	0	0	0	0	0
04/29/2026 06:00	0	0	0	0	0
04/29/2026 07:00	0	0	0	0	0
04/29/2026 08:00	0	0	0	0	0
04/29/2026 09:00	0	0	0	0	0
04/29/2026 10:00	0	0	0	0	0
04/29/2026 11:00	0	0	0	0	0
04/29/2026 12:00	0	0	0	0	0
04/29/2026 13:00	0	0	0	0	0
04/29/2026 14:00	0	0	0	0	0
04/29/2026 15:00	0	0	0	0	0
04/29/2026 16:00	0	0	0	0	0
04/29/2026 17:00	0	0	0	0	0
04/29/2026 18:00	0	0	0	0	0
04/29/2026 19:00	0	0	0	0	0
04/29/2026 20:00	0	0	0	0	0
04/29/2026 21:00	0	0	0	0	0
04/29/2026 22:00	0	0	0	0	0
04/29/2026 23:00	0	0	0	0	0
Average/Sum#:	0 #	0	0	0	0
Minimum:	0	0	0	0	0
Maximum:	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
04/30/2026 00:00	0	0	0	0	0
04/30/2026 01:00	0	0	0	0	0
04/30/2026 02:00	0	0	0	0	0
04/30/2026 03:00	0	0	0	0	0
04/30/2026 04:00	0	0	0	0	0
04/30/2026 05:00	0	0	0	0	0
04/30/2026 06:00	0	0	0	0	0
04/30/2026 07:00	0	0	0	0	0
04/30/2026 08:00	0	0	0	0	0
04/30/2026 09:00	0	0	0	0	0
04/30/2026 10:00	0	0	0	0	0
04/30/2026 11:00	0	0	0	0	0
04/30/2026 12:00	0	0	0	0	0
04/30/2026 13:00	0	0	0	0	0
04/30/2026 14:00	0	0	0	0	0
04/30/2026 15:00	0	0	0	0	0
04/30/2026 16:00	0	0	0	0	0
04/30/2026 17:00	0	0	0	0	0
04/30/2026 18:00	0	0	0	0	0
04/30/2026 19:00	0	0	0	0	0
04/30/2026 20:00	0	0	0	0	0
04/30/2026 21:00	0	0	0	0	0
04/30/2026 22:00	0	0	0	0	0
04/30/2026 23:00	0	0	0	0	0
Average/Sum#:	0 #	0	0	0	0
Minimum:	0	0	0	0	0
Maximum:	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
05/01/2026 00:00	0	0	0	0	0
05/01/2026 01:00	0	0	0	0	0
05/01/2026 02:00	0	0	0	0	0
05/01/2026 03:00	0	0	0	0	0
05/01/2026 04:00	0	0	0	0	0
05/01/2026 05:00	0	0	0	0	0
05/01/2026 06:00	0	0	0	0	0
05/01/2026 07:00	0	0	0	0	0
05/01/2026 08:00	0	0	0	0	0
05/01/2026 09:00	0	0	0	0	0
05/01/2026 10:00	0	0	0	0	0
05/01/2026 11:00	0	0	0	0	0
05/01/2026 12:00	0	0	0	0	0
05/01/2026 13:00	0	0	0	0	0
05/01/2026 14:00	0	0	0	0	0
05/01/2026 15:00	0	0	0	0	0
05/01/2026 16:00	0	0	0	0	0
05/01/2026 17:00	0	0	0	0	0
05/01/2026 18:00	0	0	0	0	0
05/01/2026 19:00	0	0	0	0	0
05/01/2026 20:00	0	0	0	0	0
05/01/2026 21:00	0	0	0	0	0
05/01/2026 22:00	0	0	0	0	0
05/01/2026 23:00	0	0	0	0	0
Average/Sum#:	0 #	0	0	0	0
Minimum:	0	0	0	0	0
Maximum:	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
05/02/2026 00:00	0	0	0	0	0
05/02/2026 01:00	0	0	0	0	0
05/02/2026 02:00	0	0	0	0	0
05/02/2026 03:00	0	0	0	0	0
05/02/2026 04:00	0	0	0	0	0
05/02/2026 05:00	0	0	0	0	0
05/02/2026 06:00	0	0	0	0	0
05/02/2026 07:00	0	0	0	0	0
05/02/2026 08:00	0	0	0	0	0
05/02/2026 09:00	0	0	0	0	0
05/02/2026 10:00	0	0	0	0	0
05/02/2026 11:00	0	0	0	0	0
05/02/2026 12:00	0	0	0	0	0
05/02/2026 13:00	0	0	0	0	0
05/02/2026 14:00	0	0	0	0	0
05/02/2026 15:00	0	0	0	0	0
05/02/2026 16:00	0	0	0	0	0
05/02/2026 17:00	0	0	0	0	0
05/02/2026 18:00	0	0	0	0	0
05/02/2026 19:00	0	0	0	0	0
05/02/2026 20:00	0	0	0	0	0
05/02/2026 21:00	0	0	0	0	0
05/02/2026 22:00	0	0	0	0	0
05/02/2026 23:00	0	0	0	0	0
Average/Sum#:	0 #	0	0	0	0
Minimum:	0	0	0	0	0
Maximum:	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
05/03/2026 00:00	0	0	0	0	0
05/03/2026 01:00	0	0	0	0	0
05/03/2026 02:00	0	0	0	0	0
05/03/2026 03:00	0	0	0	0	0
05/03/2026 04:00	0	0	0	0	0
05/03/2026 05:00	0	0	0	0	0
05/03/2026 06:00	0	0	0	0	0
05/03/2026 07:00	0	0	0	0	0
05/03/2026 08:00	0	0	0	0	0
05/03/2026 09:00	0	0	0	0	0
05/03/2026 10:00	0	0	0	0	0
05/03/2026 11:00	0	0	0	0	0
05/03/2026 12:00	0	0	0	0	0
05/03/2026 13:00	0	0	0	0	0
05/03/2026 14:00	0	0	0	0	0
05/03/2026 15:00	0	0	0	0	0
05/03/2026 16:00	0	0	0	0	0
05/03/2026 17:00	0	0	0	0	0
05/03/2026 18:00	0	0	0	0	0
05/03/2026 19:00	0	0	0	0	0
05/03/2026 20:00	0	0	0	0	0
05/03/2026 21:00	0	0	0	0	0
05/03/2026 22:00	0	0	0	0	0
05/03/2026 23:00	0	0	0	0	0
Average/Sum#:	0 #	0	0	0	0
Minimum:	0	0	0	0	0
Maximum:	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
05/04/2026 00:00	0	0	0	0	0
05/04/2026 01:00	0	0	0	0	0
05/04/2026 02:00	0	0	0	0	0
05/04/2026 03:00	0	0	0	0	0
05/04/2026 04:00	0	0	0	0	0
05/04/2026 05:00	0	0	0	0	0
05/04/2026 06:00	0	0	0	0	0
05/04/2026 07:00	0	0	0	0	0
05/04/2026 08:00	0	0	0	0	0
05/04/2026 09:00	0	0	0	0	0
05/04/2026 10:00	0	0	0	0	0
05/04/2026 11:00	0	0	0	0	0
05/04/2026 12:00	0	0	0	0	0
05/04/2026 13:00	0	0	0	0	0
05/04/2026 14:00	0	0	0	0	0
05/04/2026 15:00	0	0	0	0	0
05/04/2026 16:00	0	0	0	0	0
05/04/2026 17:00	0	0	0	0	0
05/04/2026 18:00	0	0	0	0	0
05/04/2026 19:00	0	0	0	0	0
05/04/2026 20:00	0	0	0	0	0
05/04/2026 21:00	0	0	0	0	0
05/04/2026 22:00	0	0	0	0	0
05/04/2026 23:00	0	0	0	0	0
Average/Sum#:	0 #	0	0	0	0
Minimum:	0	0	0	0	0
Maximum:	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
05/05/2026 00:00	0	0	0	0	0
05/05/2026 01:00	0	0	0	0	0
05/05/2026 02:00	0	0	0	0	0
05/05/2026 03:00	0	0	0	0	0
05/05/2026 04:00	0	0	0	0	0
05/05/2026 05:00	0	0	0	0	0
05/05/2026 06:00	0	0	0	0	0
05/05/2026 07:00	0	0	0	0	0
05/05/2026 08:00	0	0	0	0	0
05/05/2026 09:00	0	0	0	0	0
05/05/2026 10:00	0	0	0	0	0
05/05/2026 11:00	0	0	0	0	0
05/05/2026 12:00	0	0	0	0	0
05/05/2026 13:00	0	0	0	0	0
05/05/2026 14:00	0	0	0	0	0
05/05/2026 15:00	0	0	0	0	0
05/05/2026 16:00	0	0	0	0	0
05/05/2026 17:00	0	0	0	0	0
05/05/2026 18:00	0	0	0	0	0
05/05/2026 19:00	0	0	0	0	0
05/05/2026 20:00	0	0	0	0	0
05/05/2026 21:00	0	0	0	0	0
05/05/2026 22:00	0	0	0	0	0
05/05/2026 23:00	0	0	0	0	0
Average/Sum#:	0 #	0	0	0	0
Minimum:	0	0	0	0	0
Maximum:	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
05/06/2026 00:00	0	0	0	0	0
05/06/2026 01:00	0	0	0	0	0
05/06/2026 02:00	0	0	0	0	0
05/06/2026 03:00	0	0	0	0	0
05/06/2026 04:00	0	0	0	0	0
05/06/2026 05:00	0	0	0	0	0
05/06/2026 06:00	0	0	0	0	0
05/06/2026 07:00	0	0	0	0	0
05/06/2026 08:00	0	0	0	0	0
05/06/2026 09:00	0	0	0	0	0
05/06/2026 10:00	0	0	0	0	0
05/06/2026 11:00	0	0	0	0	0
05/06/2026 12:00	0	0	0	0	0
05/06/2026 13:00	0	0	0	0	0
05/06/2026 14:00	0	0	0	0	0
05/06/2026 15:00	0	0	0	0	0
05/06/2026 16:00	0	0	0	0	0
05/06/2026 17:00	0	0	0	0	0
05/06/2026 18:00	0	0	0	0	0
05/06/2026 19:00	0	0	0	0	0
05/06/2026 20:00	0	0	0	0	0
05/06/2026 21:00	0	0	0	0	0
05/06/2026 22:00	0	0	0	0	0
05/06/2026 23:00	0	0	0	0	0
Average/Sum#:	0 #	0	0	0	0
Minimum:	0	0	0	0	0
Maximum:	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
05/07/2026 00:00	0	0	0	0	0
05/07/2026 01:00	0	0	0	0	0
05/07/2026 02:00	0	0	0	0	0
05/07/2026 03:00	0	0	0	0	0
05/07/2026 04:00	0	0	0	0	0
05/07/2026 05:00	0	0	0	0	0
05/07/2026 06:00	0	0	0	0	0
05/07/2026 07:00	0	0	0	0	0
05/07/2026 08:00	0	0	0	0	0
05/07/2026 09:00	0	0	0	0	0
05/07/2026 10:00	0	0	0	0	0
05/07/2026 11:00	0	0	0	0	0
05/07/2026 12:00	0	0	0	0	0
05/07/2026 13:00	0	0	0	0	0
05/07/2026 14:00	0	0	0	0	0
05/07/2026 15:00	0	0	0	0	0
05/07/2026 16:00	0	0	0	0	0
05/07/2026 17:00	0	0	0	0	0
05/07/2026 18:00	0	0	0	0	0
05/07/2026 19:00	0	0	0	0	0
05/07/2026 20:00	0	0	0	0	0
05/07/2026 21:00	0	0	0	0	0
05/07/2026 22:00	0	0	0	0	0
05/07/2026 23:00	0	0	0	0	0
Average/Sum#:	0 #	0	0	0	0
Minimum:	0	0	0	0	0
Maximum:	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
05/08/2026 00:00	0	0	0	0	0
05/08/2026 01:00	0	0	0	0	0
05/08/2026 02:00	0	0	0	0	0
05/08/2026 03:00	0	0	0	0	0
05/08/2026 04:00	0	0	0	0	0
05/08/2026 05:00	0	0	0	0	0
05/08/2026 06:00	1	0	5	0	0
05/08/2026 07:00	1	0	16	0	0
05/08/2026 08:00	1	0	27	0	0
05/08/2026 09:00	1	0	36	0	0
05/08/2026 10:00	1	0	42	0	0
05/08/2026 11:00	1	0	48	0	0
05/08/2026 12:00	1	11	51	0	0
05/08/2026 13:00	1	29	53	0	0
05/08/2026 14:00	1	54	61	0	0
05/08/2026 15:00	1	55	58	0	0
05/08/2026 16:00	0	37	39	0	0
05/08/2026 17:00	0	12	14	0	0
05/08/2026 18:00	0	0	0	0	0
05/08/2026 19:00	0	0	0	0	0
05/08/2026 20:00	0	0	0	0	0
05/08/2026 21:00	0	0	0	0	0
05/08/2026 22:00	0	0	0	0	0
05/08/2026 23:00	0	0	0	0	0
Average/Sum#:	10 #	8	19	0	0
Minimum:	0	0	0	0	0
Maximum:	1	55	61	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
05/09/2026 00:00	0	0	0	0	0
05/09/2026 01:00	0	0	0	0	0
05/09/2026 02:00	0	0	0	0	0
05/09/2026 03:00	0	0	0	0	0
05/09/2026 04:00	0	0	0	0	0
05/09/2026 05:00	0	0	0	0	0
05/09/2026 06:00	1	0	4	0	0
05/09/2026 07:00	1	0	14	0	0
05/09/2026 08:00	1	0	25	0	0
05/09/2026 09:00	1	0	31	0	0
05/09/2026 10:00	1	0	31	0	0
05/09/2026 11:00	1	0	31	0	0
05/09/2026 12:00	1	0	31	0	0
05/09/2026 13:00	1	0	22	0	0
05/09/2026 14:00	0	0	12	0	0
05/09/2026 15:00	0	0	2	0	0
05/09/2026 16:00	0	0	0	0	0
05/09/2026 17:00	0	0	0	0	0
05/09/2026 18:00	0	0	0	0	0
05/09/2026 19:00	0	0	0	0	0
05/09/2026 20:00	0	0	0	0	0
05/09/2026 21:00	0	0	0	0	0
05/09/2026 22:00	0	0	0	0	0
05/09/2026 23:00	0	0	0	0	0
Average/Sum#:	8 #	0	8	0	0
Minimum:	0	0	0	0	0
Maximum:	1	0	31	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
05/10/2026 00:00	0	0	0	0	0
05/10/2026 01:00	0	0	0	0	0
05/10/2026 02:00	0	0	0	0	0
05/10/2026 03:00	0	0	0	0	0
05/10/2026 04:00	0	0	0	0	0
05/10/2026 05:00	0	0	0	0	0
05/10/2026 06:00	0	0	0	0	0
05/10/2026 07:00	0	0	0	0	0
05/10/2026 08:00	0	0	0	0	0
05/10/2026 09:00	1	0	3	0	0
05/10/2026 10:00	1	0	14	0	0
05/10/2026 11:00	1	0	28	0	0
05/10/2026 12:00	1	0	45	0	0
05/10/2026 13:00	1	0	53	0	0
05/10/2026 14:00	1	0	64	0	0
05/10/2026 15:00	1	0	60	0	0
05/10/2026 16:00	1	0	43	0	0
05/10/2026 17:00	0	0	17	0	0
05/10/2026 18:00	0	0	2	0	0
05/10/2026 19:00	0	0	0	0	0
05/10/2026 20:00	0	0	0	0	0
05/10/2026 21:00	0	0	0	0	0
05/10/2026 22:00	0	0	0	0	0
05/10/2026 23:00	0	0	0	0	0
Average/Sum#:	8 #	0	14	0	0
Minimum:	0	0	0	0	0
Maximum:	1	0	64	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
05/11/2026 00:00	0	0	0	0	0
05/11/2026 01:00	0	0	0	0	0
05/11/2026 02:00	0	0	0	0	0
05/11/2026 03:00	0	0	0	0	0
05/11/2026 04:00	0	0	0	0	0
05/11/2026 05:00	0	0	0	0	0
05/11/2026 06:00	0	0	0	0	0
05/11/2026 07:00	0	0	0	0	0
05/11/2026 08:00	1	0	2	0	0
05/11/2026 09:00	1	0	12	0	0
05/11/2026 10:00	1	0	26	0	0
05/11/2026 11:00	1	0	43	0	0
05/11/2026 12:00	1	0	52	0	0
05/11/2026 13:00	1	0	62	0	0
05/11/2026 14:00	1	0	60	0	0
05/11/2026 15:00	1	0	53	0	0
05/11/2026 16:00	1	0	28	0	0
05/11/2026 17:00	0	0	12	0	0
05/11/2026 18:00	0	0	0	0	0
05/11/2026 19:00	0	0	0	0	0
05/11/2026 20:00	0	0	0	0	0
05/11/2026 21:00	0	0	0	0	0
05/11/2026 22:00	0	0	0	0	0
05/11/2026 23:00	0	0	0	0	0
Average/Sum#:	9 #	0	15	0	0
Minimum:	0	0	0	0	0
Maximum:	1	0	62	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
05/12/2026 00:00	0	0	0	0	0
05/12/2026 01:00	0	0	0	0	0
05/12/2026 02:00	0	0	0	0	0
05/12/2026 03:00	0	0	0	0	0
05/12/2026 04:00	0	0	0	0	0
05/12/2026 05:00	0	0	0	0	0
05/12/2026 06:00	1	0	0	0	0
05/12/2026 07:00	1	0	8	0	0
05/12/2026 08:00	1	0	18	0	0
05/12/2026 09:00	1	0	32	11	0
05/12/2026 10:00	1	0	41	26	0
05/12/2026 11:00	1	3	48	25	0
05/12/2026 12:00	1	17	49	22	0
05/12/2026 13:00	1	34	50	0	0
05/12/2026 14:00	1	54	56	0	0
05/12/2026 15:00	1	65	66	0	0
05/12/2026 16:00	1	68	69	0	0
05/12/2026 17:00	1	60	63	0	0
05/12/2026 18:00	1	35	55	0	0
05/12/2026 19:00	1	14	47	0	0
05/12/2026 20:00	1	0	31	0	0
05/12/2026 21:00	0	0	13	0	0
05/12/2026 22:00	0	0	0	0	0
05/12/2026 23:00	0	0	0	0	0
Average/Sum#:	15 #	15	27	4	0
Minimum:	0	0	0	0	0
Maximum:	1	68	69	26	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
05/13/2026 00:00	0	0	0	0	0
05/13/2026 01:00	0	0	0	0	0
05/13/2026 02:00	0	0	0	0	0
05/13/2026 03:00	0	0	0	0	0
05/13/2026 04:00	0	0	0	0	0
05/13/2026 05:00	0	0	0	0	0
05/13/2026 06:00	0	0	0	0	0
05/13/2026 07:00	0	0	0	0	0
05/13/2026 08:00	1	0	0	0	14
05/13/2026 09:00	1	0	0	0	25
05/13/2026 10:00	1	0	0	0	25
05/13/2026 11:00	1	0	0	0	25
05/13/2026 12:00	1	0	0	0	25
05/13/2026 13:00	1	0	0	0	0
05/13/2026 14:00	0	0	0	0	0
05/13/2026 15:00	0	0	0	0	0
05/13/2026 16:00	0	0	0	0	0
05/13/2026 17:00	0	0	0	0	0
05/13/2026 18:00	0	0	0	0	0
05/13/2026 19:00	0	0	0	0	0
05/13/2026 20:00	0	0	0	0	0
05/13/2026 21:00	0	0	0	0	0
05/13/2026 22:00	0	0	0	0	0
05/13/2026 23:00	0	0	0	0	0
Average/Sum#:	6 #	0	0	0	5
Minimum:	0	0	0	0	0
Maximum:	1	0	0	0	25
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
05/14/2026 00:00	0	0	0	0	0
05/14/2026 01:00	0	0	0	0	0
05/14/2026 02:00	0	0	0	0	0
05/14/2026 03:00	0	0	0	0	0
05/14/2026 04:00	0	0	0	0	0
05/14/2026 05:00	0	0	0	0	0
05/14/2026 06:00	0	0	0	0	0
05/14/2026 07:00	0	0	0	0	0
05/14/2026 08:00	0	0	0	0	0
05/14/2026 09:00	0	0	0	0	0
05/14/2026 10:00	0	0	0	0	0
05/14/2026 11:00	0	0	0	0	0
05/14/2026 12:00	0	0	0	0	0
05/14/2026 13:00	0	0	0	0	0
05/14/2026 14:00	0	0	0	0	0
05/14/2026 15:00	0	0	0	0	0
05/14/2026 16:00	0	0	0	0	0
05/14/2026 17:00	0	0	0	0	0
05/14/2026 18:00	0	0	0	0	0
05/14/2026 19:00	0	0	0	0	0
05/14/2026 20:00	0	0	0	0	0
05/14/2026 21:00	0	0	0	0	0
05/14/2026 22:00	0	0	0	0	0
05/14/2026 23:00	0	0	0	0	0
Average/Sum#:	0 #	0	0	0	0
Minimum:	0	0	0	0	0
Maximum:	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
05/15/2026 00:00	0	0	0	0	0
05/15/2026 01:00	0	0	0	0	0
05/15/2026 02:00	0	0	0	0	0
05/15/2026 03:00	0	0	0	0	0
05/15/2026 04:00	0	0	0	0	0
05/15/2026 05:00	1	0	3	0	0
05/15/2026 06:00	1	0	14	0	0
05/15/2026 07:00	1	0	24	0	0
05/15/2026 08:00	1	0	36	0	0
05/15/2026 09:00	1	0	43	0	0
05/15/2026 10:00	1	9	50	0	0
05/15/2026 11:00	1	28	55	0	0
05/15/2026 12:00	1	51	60	0	0
05/15/2026 13:00	1	68	68	0	0
05/15/2026 14:00	1	72	72	0	0
05/15/2026 15:00	1	66	67	0	0
05/15/2026 16:00	1	43	61	0	0
05/15/2026 17:00	1	20	51	0	0
05/15/2026 18:00	1	3	37	0	0
05/15/2026 19:00	0	0	17	0	0
05/15/2026 20:00	0	0	3	0	0
05/15/2026 21:00	0	0	0	0	0
05/15/2026 22:00	0	0	0	0	0
05/15/2026 23:00	0	0	0	0	0
Average/Sum#:	14 #	15	28	0	0
Minimum:	0	0	0	0	0
Maximum:	1	72	72	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
05/16/2026 00:00	0	0	0	0	0
05/16/2026 01:00	0	0	0	0	0
05/16/2026 02:00	0	0	0	0	0
05/16/2026 03:00	0	0	0	0	0
05/16/2026 04:00	0	0	0	0	0
05/16/2026 05:00	0	0	0	0	0
05/16/2026 06:00	0	0	0	0	0
05/16/2026 07:00	0	0	0	0	0
05/16/2026 08:00	0	0	0	0	0
05/16/2026 09:00	0	0	0	0	0
05/16/2026 10:00	0	0	0	0	0
05/16/2026 11:00	0	0	0	0	0
05/16/2026 12:00	0	0	0	0	0
05/16/2026 13:00	0	0	0	0	0
05/16/2026 14:00	0	0	0	0	0
05/16/2026 15:00	0	0	0	0	0
05/16/2026 16:00	0	0	0	0	0
05/16/2026 17:00	0	0	0	0	0
05/16/2026 18:00	0	0	0	0	0
05/16/2026 19:00	0	0	0	0	0
05/16/2026 20:00	0	0	0	0	0
05/16/2026 21:00	0	0	0	0	0
05/16/2026 22:00	0	0	0	0	0
05/16/2026 23:00	0	0	0	0	0
Average/Sum#:	0 #	0	0	0	0
Minimum:	0	0	0	0	0
Maximum:	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
05/17/2026 00:00	0	0	0	0	0
05/17/2026 01:00	0	0	0	0	0
05/17/2026 02:00	0	0	0	0	0
05/17/2026 03:00	0	0	0	0	0
05/17/2026 04:00	0	0	0	0	0
05/17/2026 05:00	0	0	0	0	0
05/17/2026 06:00	0	0	0	0	0
05/17/2026 07:00	0	0	0	0	0
05/17/2026 08:00	0	0	0	0	0
05/17/2026 09:00	0	0	0	0	0
05/17/2026 10:00	0	0	0	0	0
05/17/2026 11:00	0	0	0	0	0
05/17/2026 12:00	0	0	0	0	0
05/17/2026 13:00	0	0	0	0	0
05/17/2026 14:00	0	0	0	0	0
05/17/2026 15:00	0	0	0	0	0
05/17/2026 16:00	0	0	0	0	0
05/17/2026 17:00	0	0	0	0	0
05/17/2026 18:00	0	0	0	0	0
05/17/2026 19:00	0	0	0	0	0
05/17/2026 20:00	0	0	0	0	0
05/17/2026 21:00	0	0	0	0	0
05/17/2026 22:00	0	0	0	0	0
05/17/2026 23:00	0	0	0	0	0
Average/Sum#:	0 #	0	0	0	0
Minimum:	0	0	0	0	0
Maximum:	0	0	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
05/18/2026 00:00	0	0	0	0	0
05/18/2026 01:00	0	0	0	0	0
05/18/2026 02:00	0	0	0	0	0
05/18/2026 03:00	0	0	0	0	0
05/18/2026 04:00	0	0	0	0	0
05/18/2026 05:00	0	0	0	0	0
05/18/2026 06:00	0	0	0	0	0
05/18/2026 07:00	0	0	0	0	0
05/18/2026 08:00	0	0	0	0	0
05/18/2026 09:00	0	0	0	0	0
05/18/2026 10:00	0	0	0	0	0
05/18/2026 11:00	0	0	0	0	0
05/18/2026 12:00	0	0	0	0	0
05/18/2026 13:00	0	0	0	0	0
05/18/2026 14:00	0	0	0	0	0
05/18/2026 15:00	0	0	0	0	0
05/18/2026 16:00	0	0	0	0	0
05/18/2026 17:00	0	0	0	0	0
05/18/2026 18:00	0	0	0	0	0
05/18/2026 19:00	0	0	0	0	0
05/18/2026 20:00	0	0	0	0	0
05/18/2026 21:00	0	0	0	0	0
05/18/2026 22:00	1	0	0	0	0
05/18/2026 23:00	1	0	12	0	0
Average/Sum#:	2 #	0	1	0	0
Minimum:	0	0	0	0	0
Maximum:	1	0	12	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
05/19/2026 00:00	1	0	26	0	0
05/19/2026 01:00	1	0	44	0	0
05/19/2026 02:00	1	0	52	0	0
05/19/2026 03:00	1	0	58	0	0
05/19/2026 04:00	1	13	57	0	0
05/19/2026 05:00	1	29	53	0	0
05/19/2026 06:00	1	44	49	0	0
05/19/2026 07:00	1	48	43	0	0
05/19/2026 08:00	1	47	27	0	0
05/19/2026 09:00	1	46	11	0	0
05/19/2026 10:00	1	44	0	0	0
05/19/2026 11:00	1	45	0	0	0
05/19/2026 12:00	1	45	0	0	0
05/19/2026 13:00	1	47	0	0	0
05/19/2026 14:00	1	47	0	0	0
05/19/2026 15:00	1	48	0	0	0
05/19/2026 16:00	1	48	0	0	0
05/19/2026 17:00	1	49	0	0	0
05/19/2026 18:00	1	48	0	0	0
05/19/2026 19:00	1	46	0	0	0
05/19/2026 20:00	1	45	0	0	0
05/19/2026 21:00	1	45	0	0	0
05/19/2026 22:00	1	45	0	0	0
05/19/2026 23:00	1	45	0	0	0
Average/Sum#:	24 #	36	18	0	0
Minimum:	1	0	0	0	0
Maximum:	1	49	58	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
05/20/2026 00:00	1	45	0	0	0
05/20/2026 01:00	1	45	0	0	0
05/20/2026 02:00	1	45	0	0	0
05/20/2026 03:00	1	45	0	0	0
05/20/2026 04:00	1	45	0	0	0
05/20/2026 05:00	1	45	0	0	0
05/20/2026 06:00	1	45	0	0	0
05/20/2026 07:00	1	45	0	0	0
05/20/2026 08:00	1	45	0	23	0
05/20/2026 09:00	1	45	0	0	0
05/20/2026 10:00	1	45	0	0	0
05/20/2026 11:00	1	45	0	7	0
05/20/2026 12:00	1	45	0	28	0
05/20/2026 13:00	1	45	0	28	0
05/20/2026 14:00	1	45	0	28	0
05/20/2026 15:00	1	45	0	28	0
05/20/2026 16:00	1	47	0	0	0
05/20/2026 17:00	1	50	0	0	0
05/20/2026 18:00	1	52	0	0	0
05/20/2026 19:00	1	54	0	0	0
05/20/2026 20:00	1	55	0	0	0
05/20/2026 21:00	1	57	0	0	0
05/20/2026 22:00	1	57	0	0	0
05/20/2026 23:00	1	57	0	0	0
Average/Sum#:	24 #	48	0	6	0
Minimum:	1	45	0	0	0
Maximum:	1	57	0	28	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
05/21/2026 00:00	1	55	0	0	0
05/21/2026 01:00	1	54	0	0	0
05/21/2026 02:00	1	50	0	0	0
05/21/2026 03:00	1	51	0	0	0
05/21/2026 04:00	1	52	0	0	0
05/21/2026 05:00	1	53	0	0	0
05/21/2026 06:00	1	51	0	0	0
05/21/2026 07:00	1	47	0	0	9
05/21/2026 08:00	1	45	0	0	24
05/21/2026 09:00	1	45	0	0	0
05/21/2026 10:00	1	45	0	0	4
05/21/2026 11:00	1	45	0	0	28
05/21/2026 12:00	1	45	0	0	28
05/21/2026 13:00	1	45	0	0	28
05/21/2026 14:00	1	45	0	0	27
05/21/2026 15:00	1	47	0	0	27
05/21/2026 16:00	1	48	0	0	0
05/21/2026 17:00	1	50	0	0	0
05/21/2026 18:00	1	50	0	0	0
05/21/2026 19:00	1	50	0	0	0
05/21/2026 20:00	1	47	0	0	0
05/21/2026 21:00	1	45	0	0	0
05/21/2026 22:00	1	45	0	0	0
05/21/2026 23:00	1	45	0	0	0
Average/Sum#:	24 #	48	0	0	7
Minimum:	1	45	0	0	0
Maximum:	1	55	0	0	28
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
05/22/2026 00:00	1	45	0	0	0
05/22/2026 01:00	1	45	0	0	0
05/22/2026 02:00	1	45	0	0	0
05/22/2026 03:00	1	45	0	0	0
05/22/2026 04:00	1	45	0	0	0
05/22/2026 05:00	1	45	0	0	0
05/22/2026 06:00	1	45	0	0	0
05/22/2026 07:00	1	45	0	0	0
05/22/2026 08:00	1	45	0	0	0
05/22/2026 09:00	1	45	0	0	0
05/22/2026 10:00	1	45	0	0	0
05/22/2026 11:00	1	45	0	0	0
05/22/2026 12:00	1	45	0	0	0
05/22/2026 13:00	1	45	0	0	0
05/22/2026 14:00	1	45	0	0	0
05/22/2026 15:00	1	45	0	0	0
05/22/2026 16:00	1	45	0	0	0
05/22/2026 17:00	1	46	0	0	0
05/22/2026 18:00	1	48	0	0	0
05/22/2026 19:00	1	48	0	0	0
05/22/2026 20:00	1	47	0	0	0
05/22/2026 21:00	1	45	0	0	0
05/22/2026 22:00	1	45	0	0	0
05/22/2026 23:00	1	45	0	0	0
Average/Sum#:	24 #	45	0	0	0
Minimum:	1	45	0	0	0
Maximum:	1	48	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
05/23/2026 00:00	1	48	2	0	0
05/23/2026 01:00	1	47	16	0	0
05/23/2026 02:00	1	47	32	0	0
05/23/2026 03:00	1	45	46	0	0
05/23/2026 04:00	1	50	51	0	0
05/23/2026 05:00	1	48	52	0	0
05/23/2026 06:00	1	32	51	0	0
05/23/2026 07:00	1	12	46	0	0
05/23/2026 08:00	1	0	45	0	0
05/23/2026 09:00	1	0	45	0	0
05/23/2026 10:00	1	0	45	0	0
05/23/2026 11:00	1	0	45	0	0
05/23/2026 12:00	1	0	45	0	0
05/23/2026 13:00	1	0	45	0	0
05/23/2026 14:00	1	0	45	0	0
05/23/2026 15:00	1	0	45	0	0
05/23/2026 16:00	1	0	45	0	0
05/23/2026 17:00	1	0	45	0	0
05/23/2026 18:00	1	0	45	0	0
05/23/2026 19:00	1	0	45	0	0
05/23/2026 20:00	1	0	45	0	0
05/23/2026 21:00	1	0	45	0	0
05/23/2026 22:00	1	0	45	0	0
05/23/2026 23:00	1	0	45	0	0
Average/Sum#:	24 #	14	42	0	0
Minimum:	1	0	2	0	0
Maximum:	1	50	52	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
05/24/2026 00:00	1	0	45	0	0
05/24/2026 01:00	1	0	45	0	0
05/24/2026 02:00	1	0	45	0	0
05/24/2026 03:00	1	0	45	0	0
05/24/2026 04:00	1	0	45	0	0
05/24/2026 05:00	1	0	45	0	0
05/24/2026 06:00	1	0	45	0	0
05/24/2026 07:00	1	0	45	0	0
05/24/2026 08:00	1	0	45	0	0
05/24/2026 09:00	1	0	45	0	0
05/24/2026 10:00	1	0	45	0	0
05/24/2026 11:00	1	0	45	0	0
05/24/2026 12:00	1	0	45	0	0
05/24/2026 13:00	1	0	45	0	0
05/24/2026 14:00	1	0	45	0	0
05/24/2026 15:00	1	0	45	0	0
05/24/2026 16:00	1	0	45	0	0
05/24/2026 17:00	1	0	45	0	0
05/24/2026 18:00	1	0	45	0	0
05/24/2026 19:00	1	0	45	0	0
05/24/2026 20:00	1	0	45	0	0
05/24/2026 21:00	1	0	45	0	0
05/24/2026 22:00	1	0	45	0	0
05/24/2026 23:00	1	0	45	0	0
Average/Sum#:	24 #	0	45	0	0
Minimum:	1	0	45	0	0
Maximum:	1	0	45	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
05/25/2026 00:00	1	0	45	0	0
05/25/2026 01:00	1	0	45	0	0
05/25/2026 02:00	1	0	45	0	0
05/25/2026 03:00	1	0	45	0	0
05/25/2026 04:00	1	0	45	0	0
05/25/2026 05:00	1	0	45	0	0
05/25/2026 06:00	1	0	45	0	0
05/25/2026 07:00	1	0	45	0	0
05/25/2026 08:00	1	0	44	0	0
05/25/2026 09:00	1	0	44	0	0
05/25/2026 10:00	1	0	45	0	0
05/25/2026 11:00	1	0	45	0	0
05/25/2026 12:00	1	0	45	0	0
05/25/2026 13:00	1	0	45	0	0
05/25/2026 14:00	1	0	45	0	0
05/25/2026 15:00	1	0	45	0	0
05/25/2026 16:00	1	0	45	0	0
05/25/2026 17:00	1	0	45	0	0
05/25/2026 18:00	1	0	45	0	0
05/25/2026 19:00	1	0	45	0	0
05/25/2026 20:00	1	0	45	0	0
05/25/2026 21:00	1	0	45	0	0
05/25/2026 22:00	1	0	45	0	0
05/25/2026 23:00	1	0	45	0	0
Average/Sum#:	24 #	0	45	0	0
Minimum:	1	0	44	0	0
Maximum:	1	0	45	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
05/26/2026 00:00	1	0	45	0	0
05/26/2026 01:00	1	0	45	0	0
05/26/2026 02:00	1	0	45	0	0
05/26/2026 03:00	1	0	45	0	0
05/26/2026 04:00	1	0	45	0	0
05/26/2026 05:00	1	0	45	0	0
05/26/2026 06:00	1	0	47	0	0
05/26/2026 07:00	1	0	50	0	0
05/26/2026 08:00	1	0	50	0	0
05/26/2026 09:00	1	0	48	0	0
05/26/2026 10:00	1	0	46	0	0
05/26/2026 11:00	1	0	47	0	0
05/26/2026 12:00	1	0	47	0	0
05/26/2026 13:00	1	0	45	0	0
05/26/2026 14:00	1	0	45	0	0
05/26/2026 15:00	1	0	45	0	0
05/26/2026 16:00	1	0	45	0	0
05/26/2026 17:00	1	0	46	0	0
05/26/2026 18:00	1	0	46	0	0
05/26/2026 19:00	1	0	46	0	0
05/26/2026 20:00	1	0	45	0	0
05/26/2026 21:00	1	0	44	0	0
05/26/2026 22:00	1	0	44	0	0
05/26/2026 23:00	1	0	49	0	0
Average/Sum#:	24 #	0	46	0	0
Minimum:	1	0	44	0	0
Maximum:	1	0	50	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
05/27/2026 00:00	1	0	53	0	0
05/27/2026 01:00	1	0	57	0	0
05/27/2026 02:00	1	0	54	0	0
05/27/2026 03:00	1	0	54	0	0
05/27/2026 04:00	1	0	53	0	0
05/27/2026 05:00	1	0	54	0	0
05/27/2026 06:00	1	0	50	0	0
05/27/2026 07:00	1	0	48	0	0
05/27/2026 08:00	1	0	46	0	0
05/27/2026 09:00	1	0	46	0	0
05/27/2026 10:00	1	0	44	0	0
05/27/2026 11:00	1	0	44	0	0
05/27/2026 12:00	1	0	44	0	0
05/27/2026 13:00	1	0	44	0	0
05/27/2026 14:00	1	0	44	0	0
05/27/2026 15:00	1	0	46	0	0
05/27/2026 16:00	1	0	46	0	0
05/27/2026 17:00	1	0	48	0	0
05/27/2026 18:00	1	0	50	0	0
05/27/2026 19:00	1	0	53	0	0
05/27/2026 20:00	1	0	56	0	0
05/27/2026 21:00	1	1	56	0	0
05/27/2026 22:00	1	15	53	0	0
05/27/2026 23:00	1	35	54	0	0
Average/Sum#:	24 #	2	50	0	0
Minimum:	1	0	44	0	0
Maximum:	1	35	57	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
05/28/2026 00:00	1	53	55	0	0
05/28/2026 01:00	1	55	56	0	0
05/28/2026 02:00	1	47	53	0	0
05/28/2026 03:00	1	27	48	0	0
05/28/2026 04:00	1	11	47	0	0
05/28/2026 05:00	1	0	45	0	0
05/28/2026 06:00	1	0	45	0	0
05/28/2026 07:00	1	0	48	0	0
05/28/2026 08:00	1	0	49	0	0
05/28/2026 09:00	1	0	51	0	0
05/28/2026 10:00	1	0	52	0	0
05/28/2026 11:00	1	0	50	0	0
05/28/2026 12:00	1	0	48	0	0
05/28/2026 13:00	1	0	45	0	0
05/28/2026 14:00	1	0	45	0	0
05/28/2026 15:00	1	0	45	0	0
05/28/2026 16:00	1	0	45	0	0
05/28/2026 17:00	1	0	45	0	0
05/28/2026 18:00	1	3	47	0	0
05/28/2026 19:00	1	18	47	0	0
05/28/2026 20:00	1	37	51	0	0
05/28/2026 21:00	1	53	54	0	0
05/28/2026 22:00	1	58	59	0	0
05/28/2026 23:00	1	50	57	0	0
Average/Sum#:	24 #	17	49	0	0
Minimum:	1	0	45	0	0
Maximum:	1	58	59	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
05/29/2026 00:00	1	30	52	0	0
05/29/2026 01:00	1	11	47	0	0
05/29/2026 02:00	1	0	45	0	0
05/29/2026 03:00	1	0	45	0	0
05/29/2026 04:00	1	0	45	0	0
05/29/2026 05:00	1	0	45	0	0
05/29/2026 06:00	1	0	45	0	0
05/29/2026 07:00	1	0	45	0	0
05/29/2026 08:00	1	0	45	0	0
05/29/2026 09:00	1	0	45	0	0
05/29/2026 10:00	1	0	45	0	0
05/29/2026 11:00	1	0	45	0	0
05/29/2026 12:00	1	0	45	0	0
05/29/2026 13:00	1	0	45	0	0
05/29/2026 14:00	1	0	45	0	0
05/29/2026 15:00	1	0	45	0	0
05/29/2026 16:00	1	0	45	0	0
05/29/2026 17:00	1	0	45	0	0
05/29/2026 18:00	1	0	45	0	0
05/29/2026 19:00	1	0	45	0	0
05/29/2026 20:00	1	0	45	0	0
05/29/2026 21:00	1	0	45	0	0
05/29/2026 22:00	1	0	45	0	0
05/29/2026 23:00	1	0	45	0	0
Average/Sum#:	24 #	2	45	0	0
Minimum:	1	0	45	0	0
Maximum:	1	30	52	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
05/30/2026 00:00	1	0	45	0	0
05/30/2026 01:00	1	0	45	0	0
05/30/2026 02:00	1	0	45	0	0
05/30/2026 03:00	1	0	45	0	0
05/30/2026 04:00	1	0	45	0	0
05/30/2026 05:00	1	0	45	0	0
05/30/2026 06:00	1	0	45	0	0
05/30/2026 07:00	1	0	45	0	0
05/30/2026 08:00	1	0	45	0	0
05/30/2026 09:00	1	0	45	0	0
05/30/2026 10:00	1	0	45	0	0
05/30/2026 11:00	1	0	45	0	0
05/30/2026 12:00	1	0	45	0	0
05/30/2026 13:00	1	0	45	0	0
05/30/2026 14:00	1	0	45	0	0
05/30/2026 15:00	1	0	45	0	0
05/30/2026 16:00	1	0	45	0	0
05/30/2026 17:00	1	0	45	0	0
05/30/2026 18:00	1	0	45	0	0
05/30/2026 19:00	1	0	45	0	0
05/30/2026 20:00	1	0	45	0	0
05/30/2026 21:00	1	0	45	0	0
05/30/2026 22:00	1	0	45	0	0
05/30/2026 23:00	1	0	45	0	0
Average/Sum#:	24 #	0	45	0	0
Minimum:	1	0	45	0	0
Maximum:	1	0	45	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
05/31/2026 00:00	1	0	45	0	0
05/31/2026 01:00	1	0	45	0	0
05/31/2026 02:00	1	0	45	0	0
05/31/2026 03:00	1	0	45	0	0
05/31/2026 04:00	1	0	45	0	0
05/31/2026 05:00	1	0	45	0	0
05/31/2026 06:00	1	0	45	0	0
05/31/2026 07:00	1	0	45	0	0
05/31/2026 08:00	1	0	45	0	0
05/31/2026 09:00	1	0	45	0	0
05/31/2026 10:00	1	0	45	0	0
05/31/2026 11:00	1	0	45	0	0
05/31/2026 12:00	1	0	45	0	0
05/31/2026 13:00	1	0	45	0	0
05/31/2026 14:00	1	0	45	0	0
05/31/2026 15:00	1	0	45	0	0
05/31/2026 16:00	1	0	45	0	0
05/31/2026 17:00	1	0	45	0	0
05/31/2026 18:00	1	0	45	0	0
05/31/2026 19:00	1	0	45	0	0
05/31/2026 20:00	1	0	45	0	0
05/31/2026 21:00	1	0	45	0	0
05/31/2026 22:00	1	0	45	0	0
05/31/2026 23:00	1	0	45	0	0
Average/Sum#:	24 #	0	45	0	0
Minimum:	1	0	45	0	0
Maximum:	1	0	45	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
06/01/2026 00:00	1	0	45	0	0
06/01/2026 01:00	1	0	45	0	0
06/01/2026 02:00	1	0	45	0	0
06/01/2026 03:00	1	0	45	0	0
06/01/2026 04:00	1	0	45	0	0
06/01/2026 05:00	1	0	45	0	0
06/01/2026 06:00	1	0	45	0	0
06/01/2026 07:00	1	0	45	0	0
06/01/2026 08:00	1	0	45	0	0
06/01/2026 09:00	1	0	45	0	0
06/01/2026 10:00	1	0	45	0	0
06/01/2026 11:00	1	0	45	0	0
06/01/2026 12:00	1	0	45	0	0
06/01/2026 13:00	1	0	45	0	0
06/01/2026 14:00	1	0	45	0	0
06/01/2026 15:00	1	0	45	0	0
06/01/2026 16:00	1	0	45	0	0
06/01/2026 17:00	1	0	46	0	0
06/01/2026 18:00	1	0	49	0	0
06/01/2026 19:00	1	0	50	0	0
06/01/2026 20:00	1	0	49	0	0
06/01/2026 21:00	1	0	47	0	0
06/01/2026 22:00	1	0	49	0	0
06/01/2026 23:00	1	0	48	0	0
Average/Sum#:	24 #	0	46	0	0
Minimum:	1	0	45	0	0
Maximum:	1	0	50	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
06/02/2026 00:00	1	0	48	0	0
06/02/2026 01:00	1	0	46	0	0
06/02/2026 02:00	1	0	45	0	0
06/02/2026 03:00	1	0	45	0	0
06/02/2026 04:00	1	0	45	0	0
06/02/2026 05:00	1	0	45	0	0
06/02/2026 06:00	1	0	45	0	0
06/02/2026 07:00	1	0	45	0	0
06/02/2026 08:00	1	0	45	0	0
06/02/2026 09:00	1	0	45	0	0
06/02/2026 10:00	1	0	45	0	0
06/02/2026 11:00	1	0	45	0	0
06/02/2026 12:00	1	0	45	0	0
06/02/2026 13:00	1	0	45	0	0
06/02/2026 14:00	1	0	44	0	0
06/02/2026 15:00	1	0	45	0	0
06/02/2026 16:00	1	0	46	0	0
06/02/2026 17:00	1	0	48	0	0
06/02/2026 18:00	1	0	52	0	0
06/02/2026 19:00	1	0	53	0	0
06/02/2026 20:00	1	0	52	0	0
06/02/2026 21:00	1	0	51	0	0
06/02/2026 22:00	1	0	51	0	0
06/02/2026 23:00	1	0	49	0	0
Average/Sum#:	24 #	0	47	0	0
Minimum:	1	0	44	0	0
Maximum:	1	0	53	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
06/03/2026 00:00	1	0	46	0	0
06/03/2026 01:00	1	0	45	0	0
06/03/2026 02:00	1	0	45	0	0
06/03/2026 03:00	1	0	45	0	0
06/03/2026 04:00	1	0	45	0	0
06/03/2026 05:00	1	0	45	0	0
06/03/2026 06:00	1	0	45	0	0
06/03/2026 07:00	1	0	45	1	0
06/03/2026 08:00	1	0	45	25	0
06/03/2026 09:00	1	0	45	25	0
06/03/2026 10:00	1	0	45	25	1
06/03/2026 11:00	1	0	45	1	4
06/03/2026 12:00	1	0	45	0	24
06/03/2026 13:00	1	0	45	0	25
06/03/2026 14:00	1	0	45	0	25
06/03/2026 15:00	1	0	45	0	0
06/03/2026 16:00	1	2	47	0	0
06/03/2026 17:00	1	19	49	0	0
06/03/2026 18:00	1	38	54	0	0
06/03/2026 19:00	1	54	55	0	0
06/03/2026 20:00	1	54	55	0	0
06/03/2026 21:00	1	54	53	0	0
06/03/2026 22:00	1	55	35	0	0
06/03/2026 23:00	1	53	18	0	0
Average/Sum#:	24 #	14	45	3	3
Minimum:	1	0	18	0	0
Maximum:	1	55	55	25	25
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
06/04/2026 00:00	1	49	0	0	0
06/04/2026 01:00	1	46	0	0	0
06/04/2026 02:00	1	47	0	0	0
06/04/2026 03:00	1	47	0	0	0
06/04/2026 04:00	1	45	0	0	0
06/04/2026 05:00	1	45	0	0	0
06/04/2026 06:00	1	45	0	0	0
06/04/2026 07:00	1	45	0	0	0
06/04/2026 08:00	1	45	0	0	0
06/04/2026 09:00	1	45	0	0	0
06/04/2026 10:00	1	45	0	0	0
06/04/2026 11:00	1	45	0	0	0
06/04/2026 12:00	1	45	0	0	0
06/04/2026 13:00	1	45	0	0	0
06/04/2026 14:00	1	45	0	0	0
06/04/2026 15:00	1	45	0	0	0
06/04/2026 16:00	1	45	0	0	0
06/04/2026 17:00	1	45	0	0	0
06/04/2026 18:00	1	45	0	0	0
06/04/2026 19:00	1	45	0	0	0
06/04/2026 20:00	1	45	0	0	0
06/04/2026 21:00	1	45	0	0	0
06/04/2026 22:00	1	45	0	0	0
06/04/2026 23:00	1	45	0	0	0
Average/Sum#:	24 #	45	0	0	0
Minimum:	1	45	0	0	0
Maximum:	1	49	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
06/05/2026 00:00	1	45	0	0	0
06/05/2026 01:00	1	45	0	0	0
06/05/2026 02:00	1	45	0	0	0
06/05/2026 03:00	1	45	0	0	0
06/05/2026 04:00	1	48	0	0	0
06/05/2026 05:00	1	50	0	0	0
06/05/2026 06:00	1	50	0	0	0
06/05/2026 07:00	1	47	0	0	0
06/05/2026 08:00	1	45	0	0	0
06/05/2026 09:00	1	45	0	0	0
06/05/2026 10:00	1	45	0	0	0
06/05/2026 11:00	1	45	0	0	0
06/05/2026 12:00	1	45	0	0	0
06/05/2026 13:00	1	45	0	0	0
06/05/2026 14:00	1	45	0	0	0
06/05/2026 15:00	1	45	0	0	0
06/05/2026 16:00	1	45	0	0	0
06/05/2026 17:00	1	46	0	0	0
06/05/2026 18:00	1	48	0	0	0
06/05/2026 19:00	1	49	0	0	0
06/05/2026 20:00	1	48	0	0	0
06/05/2026 21:00	1	46	0	0	0
06/05/2026 22:00	1	45	0	0	0
06/05/2026 23:00	1	46	0	0	0
Average/Sum#:	24 #	46	0	0	0
Minimum:	1	45	0	0	0
Maximum:	1	50	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
06/06/2026 00:00	1	46	0	0	0
06/06/2026 01:00	1	45	0	0	0
06/06/2026 02:00	1	45	0	0	0
06/06/2026 03:00	1	45	0	0	0
06/06/2026 04:00	1	45	0	0	0
06/06/2026 05:00	1	45	0	0	0
06/06/2026 06:00	1	45	0	0	0
06/06/2026 07:00	1	45	0	0	0
06/06/2026 08:00	1	45	0	0	0
06/06/2026 09:00	1	45	0	0	0
06/06/2026 10:00	1	45	0	0	0
06/06/2026 11:00	1	45	0	0	0
06/06/2026 12:00	1	45	0	0	0
06/06/2026 13:00	1	45	0	0	0
06/06/2026 14:00	1	45	0	0	0
06/06/2026 15:00	1	45	0	0	0
06/06/2026 16:00	1	45	0	0	0
06/06/2026 17:00	1	45	0	0	0
06/06/2026 18:00	1	45	0	0	0
06/06/2026 19:00	1	45	0	0	0
06/06/2026 20:00	1	45	0	0	0
06/06/2026 21:00	1	45	0	0	0
06/06/2026 22:00	1	45	0	0	0
06/06/2026 23:00	1	45	0	0	0
Average/Sum#:	24 #	45	0	0	0
Minimum:	1	45	0	0	0
Maximum:	1	46	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
06/07/2026 00:00	1	45	0	0	0
06/07/2026 01:00	1	45	0	0	0
06/07/2026 02:00	1	45	0	0	0
06/07/2026 03:00	1	45	0	0	0
06/07/2026 04:00	1	45	0	0	0
06/07/2026 05:00	1	45	0	0	0
06/07/2026 06:00	1	45	0	0	0
06/07/2026 07:00	1	45	0	0	0
06/07/2026 08:00	1	45	0	0	0
06/07/2026 09:00	1	45	0	0	0
06/07/2026 10:00	1	45	0	0	0
06/07/2026 11:00	1	45	0	0	0
06/07/2026 12:00	1	45	0	0	0
06/07/2026 13:00	1	45	0	0	0
06/07/2026 14:00	1	45	0	0	0
06/07/2026 15:00	1	45	0	0	0
06/07/2026 16:00	1	45	0	0	0
06/07/2026 17:00	1	45	0	0	0
06/07/2026 18:00	1	44	0	0	0
06/07/2026 19:00	1	44	0	0	0
06/07/2026 20:00	1	44	0	0	0
06/07/2026 21:00	1	45	0	0	0
06/07/2026 22:00	1	45	0	0	0
06/07/2026 23:00	1	45	0	0	0
Average/Sum#:	24 #	45	0	0	0
Minimum:	1	44	0	0	0
Maximum:	1	45	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
06/08/2026 00:00	1	45	0	0	0
06/08/2026 01:00	1	45	0	0	0
06/08/2026 02:00	1	45	0	0	0
06/08/2026 03:00	1	45	0	0	0
06/08/2026 04:00	1	45	0	0	0
06/08/2026 05:00	1	45	0	0	0
06/08/2026 06:00	1	45	0	0	0
06/08/2026 07:00	1	45	0	0	0
06/08/2026 08:00	1	44	0	0	0
06/08/2026 09:00	1	44	0	0	0
06/08/2026 10:00	1	44	0	0	0
06/08/2026 11:00	1	44	0	0	0
06/08/2026 12:00	1	45	0	0	0
06/08/2026 13:00	1	45	0	0	0
06/08/2026 14:00	1	45	0	0	0
06/08/2026 15:00	1	45	0	0	0
06/08/2026 16:00	1	44	0	0	0
06/08/2026 17:00	1	45	0	0	0
06/08/2026 18:00	1	47	0	0	0
06/08/2026 19:00	1	48	0	0	0
06/08/2026 20:00	1	47	0	0	0
06/08/2026 21:00	1	46	0	0	0
06/08/2026 22:00	1	50	0	0	0
06/08/2026 23:00	1	53	0	0	0
Average/Sum#:	24 #	46	0	0	0
Minimum:	1	44	0	0	0
Maximum:	1	53	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
06/09/2026 00:00	1	52	0	0	0
06/09/2026 01:00	1	49	0	0	0
06/09/2026 02:00	1	46	0	0	0
06/09/2026 03:00	1	45	0	0	0
06/09/2026 04:00	1	45	0	0	0
06/09/2026 05:00	1	47	0	0	0
06/09/2026 06:00	1	47	0	0	0
06/09/2026 07:00	1	46	0	0	0
06/09/2026 08:00	1	45	0	0	0
06/09/2026 09:00	1	45	0	0	0
06/09/2026 10:00	1	45	0	0	0
06/09/2026 11:00	1	45	0	0	0
06/09/2026 12:00	1	45	0	0	0
06/09/2026 13:00	1	45	0	0	0
06/09/2026 14:00	1	45	0	0	0
06/09/2026 15:00	1	45	0	0	0
06/09/2026 16:00	1	45	0	0	0
06/09/2026 17:00	1	46	0	0	0
06/09/2026 18:00	1	48	0	0	0
06/09/2026 19:00	1	52	0	0	0
06/09/2026 20:00	1	54	0	0	0
06/09/2026 21:00	1	52	0	0	0
06/09/2026 22:00	1	50	0	0	0
06/09/2026 23:00	1	48	0	0	0
Average/Sum#:	24 #	47	0	0	0
Minimum:	1	45	0	0	0
Maximum:	1	54	0	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
06/10/2026 00:00	1	48	0	0	0
06/10/2026 01:00	1	46	0	0	0
06/10/2026 02:00	1	45	0	0	0
06/10/2026 03:00	1	45	0	0	0
06/10/2026 04:00	1	48	5	0	0
06/10/2026 05:00	1	48	20	0	0
06/10/2026 06:00	1	51	38	0	0
06/10/2026 07:00	1	59	59	0	0
06/10/2026 08:00	1	69	70	0	0
06/10/2026 09:00	1	77	77	0	0
06/10/2026 10:00	1	77	77	0	0
06/10/2026 11:00	1	77	78	0	0
06/10/2026 12:00	1	77	78	0	0
06/10/2026 13:00	1	77	78	0	0
06/10/2026 14:00	1	77	78	0	0
06/10/2026 15:00	1	77	78	0	0
06/10/2026 16:00	1	77	78	0	0
06/10/2026 17:00	1	77	78	0	0
06/10/2026 18:00	1	77	78	0	0
06/10/2026 19:00	1	73	74	0	0
06/10/2026 20:00	1	63	64	0	0
06/10/2026 21:00	1	53	54	0	0
06/10/2026 22:00	1	46	47	0	0
06/10/2026 23:00	1	46	47	0	0
Average/Sum#:	24 #	63	52	0	0
Minimum:	1	45	0	0	0
Maximum:	1	77	78	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
06/11/2026 00:00	1	46	47	0	0
06/11/2026 01:00	1	46	47	0	0
06/11/2026 02:00	1	46	47	0	0
06/11/2026 03:00	1	46	47	0	0
06/11/2026 04:00	1	46	47	0	0
06/11/2026 05:00	1	49	50	0	0
06/11/2026 06:00	1	57	58	0	0
06/11/2026 07:00	1	67	68	0	0
06/11/2026 08:00	1	74	75	0	0
06/11/2026 09:00	1	77	78	0	0
06/11/2026 10:00	1	77	78	0	0
06/11/2026 11:00	1	77	78	0	0
06/11/2026 12:00	1	77	78	0	0
06/11/2026 13:00	1	77	78	0	0
06/11/2026 14:00	1	77	78	0	0
06/11/2026 15:00	1	77	78	0	0
06/11/2026 16:00	1	77	78	0	0
06/11/2026 17:00	1	77	78	0	0
06/11/2026 18:00	1	77	78	0	0
06/11/2026 19:00	1	73	74	0	0
06/11/2026 20:00	1	63	64	0	0
06/11/2026 21:00	1	55	56	0	0
06/11/2026 22:00	1	50	51	0	0
06/11/2026 23:00	1	50	50	0	0
Average/Sum#:	24 #	64	65	0	0
Minimum:	1	46	47	0	0
Maximum:	1	77	78	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
06/12/2026 00:00	1	48	49	0	0
06/12/2026 01:00	1	46	47	0	0
06/12/2026 02:00	1	47	48	0	0
06/12/2026 03:00	1	49	50	0	0
06/12/2026 04:00	1	49	50	0	0
06/12/2026 05:00	1	50	51	0	0
06/12/2026 06:00	1	48	49	16	0
06/12/2026 07:00	1	47	48	28	0
06/12/2026 08:00	1	46	47	28	0
06/12/2026 09:00	1	46	47	28	0
06/12/2026 10:00	1	46	47	27	0
06/12/2026 11:00	1	46	47	13	23
06/12/2026 12:00	1	50	51	0	27
06/12/2026 13:00	1	54	55	0	26
06/12/2026 14:00	1	59	59	0	26
06/12/2026 15:00	1	62	63	0	26
06/12/2026 16:00	1	64	65	0	26
06/12/2026 17:00	1	62	62	0	26
06/12/2026 18:00	1	58	58	0	26
06/12/2026 19:00	1	56	57	0	27
06/12/2026 20:00	1	61	62	0	28
06/12/2026 21:00	1	64	65	0	0
06/12/2026 22:00	1	67	67	0	0
06/12/2026 23:00	1	66	67	0	0
Average/Sum#:	24 #	54	55	6	11
Minimum:	1	46	47	0	0
Maximum:	1	67	67	28	28
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
06/13/2026 00:00	1	59	60	0	0
06/13/2026 01:00	1	52	53	0	0
06/13/2026 02:00	1	46	47	0	0
06/13/2026 03:00	1	48	49	0	0
06/13/2026 04:00	1	51	52	0	0
06/13/2026 05:00	1	52	53	0	0
06/13/2026 06:00	1	50	51	0	0
06/13/2026 07:00	1	47	48	0	0
06/13/2026 08:00	1	46	47	0	0
06/13/2026 09:00	1	46	47	0	0
06/13/2026 10:00	1	46	47	0	0
06/13/2026 11:00	1	46	47	0	0
06/13/2026 12:00	1	46	47	0	0
06/13/2026 13:00	1	46	47	0	0
06/13/2026 14:00	1	46	47	0	0
06/13/2026 15:00	1	46	47	0	0
06/13/2026 16:00	1	48	49	0	0
06/13/2026 17:00	1	51	51	0	0
06/13/2026 18:00	1	55	56	0	0
06/13/2026 19:00	1	64	65	0	0
06/13/2026 20:00	1	71	72	0	0
06/13/2026 21:00	1	76	77	0	0
06/13/2026 22:00	1	77	78	0	0
06/13/2026 23:00	1	79	80	0	0
Average/Sum#:	24 #	54	55	0	0
Minimum:	1	46	47	0	0
Maximum:	1	79	80	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
06/14/2026 00:00	1	76	77	0	0
06/14/2026 01:00	1	71	73	0	0
06/14/2026 02:00	1	62	64	0	0
06/14/2026 03:00	1	55	57	0	0
06/14/2026 04:00	1	49	50	0	0
06/14/2026 05:00	1	46	47	0	0
06/14/2026 06:00	1	46	47	0	0
06/14/2026 07:00	1	46	47	0	0
06/14/2026 08:00	1	46	47	0	0
06/14/2026 09:00	1	46	47	0	0
06/14/2026 10:00	1	46	47	0	0
06/14/2026 11:00	1	46	47	0	0
06/14/2026 12:00	1	46	47	0	0
06/14/2026 13:00	1	46	47	0	0
06/14/2026 14:00	1	46	47	0	0
06/14/2026 15:00	1	46	47	0	0
06/14/2026 16:00	1	50	51	0	0
06/14/2026 17:00	1	52	54	0	0
06/14/2026 18:00	1	57	58	0	0
06/14/2026 19:00	1	57	59	0	0
06/14/2026 20:00	1	58	59	0	0
06/14/2026 21:00	1	57	58	0	0
06/14/2026 22:00	1	53	54	0	0
06/14/2026 23:00	1	51	52	0	0
Average/Sum#:	24 #	52	53	0	0
Minimum:	1	46	47	0	0
Maximum:	1	76	77	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
06/15/2026 00:00	1	49	50	0	0
06/15/2026 01:00	1	48	49	0	0
06/15/2026 02:00	1	47	48	0	0
06/15/2026 03:00	1	46	47	0	0
06/15/2026 04:00	1	46	47	0	0
06/15/2026 05:00	1	46	47	0	0
06/15/2026 06:00	1	46	47	0	0
06/15/2026 07:00	1	46	47	0	0
06/15/2026 08:00	1	46	47	0	0
06/15/2026 09:00	1	46	47	0	0
06/15/2026 10:00	1	46	47	0	0
06/15/2026 11:00	1	46	47	0	0
06/15/2026 12:00	1	46	47	0	0
06/15/2026 13:00	1	46	47	0	0
06/15/2026 14:00	1	48	49	0	0
06/15/2026 15:00	1	51	52	0	0
06/15/2026 16:00	1	53	54	0	0
06/15/2026 17:00	1	54	55	0	0
06/15/2026 18:00	1	59	60	0	0
06/15/2026 19:00	1	62	63	0	0
06/15/2026 20:00	1	59	60	0	0
06/15/2026 21:00	1	51	52	0	0
06/15/2026 22:00	1	48	49	0	0
06/15/2026 23:00	1	55	56	0	0
Average/Sum#:	24 #	50	51	0	0
Minimum:	1	46	47	0	0
Maximum:	1	62	63	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
06/16/2026 00:00	1	61	62	0	0
06/16/2026 01:00	1	66	67	0	0
06/16/2026 02:00	1	66	67	0	0
06/16/2026 03:00	1	67	67	0	0
06/16/2026 04:00	1	61	61	0	0
06/16/2026 05:00	1	54	54	6	0
06/16/2026 06:00	1	48	49	26	0
06/16/2026 07:00	1	57	58	26	0
06/16/2026 08:00	1	67	68	26	0
06/16/2026 09:00	1	76	77	26	0
06/16/2026 10:00	1	77	78	26	0
06/16/2026 11:00	1	77	78	26	0
06/16/2026 12:00	1	77	78	26	0
06/16/2026 13:00	1	77	78	26	0
06/16/2026 14:00	1	77	77	26	0
06/16/2026 15:00	1	77	77	26	0
06/16/2026 16:00	1	77	77	26	0
06/16/2026 17:00	1	74	74	26	0
06/16/2026 18:00	1	71	71	26	0
06/16/2026 19:00	1	67	67	0	0
06/16/2026 20:00	1	67	67	0	0
06/16/2026 21:00	1	66	67	0	0
06/16/2026 22:00	1	66	67	0	0
06/16/2026 23:00	1	66	67	0	0
Average/Sum#:	24 #	68	69	14	0
Minimum:	1	48	49	0	0
Maximum:	1	77	78	26	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
06/17/2026 00:00	1	66	67	0	0
06/17/2026 01:00	1	66	67	0	0
06/17/2026 02:00	1	66	67	0	0
06/17/2026 03:00	1	66	67	0	0
06/17/2026 04:00	1	67	67	0	0
06/17/2026 05:00	1	65	65	0	8
06/17/2026 06:00	1	59	60	0	28
06/17/2026 07:00	1	62	63	0	28
06/17/2026 08:00	1	67	68	0	28
06/17/2026 09:00	1	76	77	0	28
06/17/2026 10:00	1	77	78	0	28
06/17/2026 11:00	1	77	78	0	28
06/17/2026 12:00	1	77	78	0	28
06/17/2026 13:00	1	77	78	0	28
06/17/2026 14:00	1	77	77	0	28
06/17/2026 15:00	1	77	77	0	28
06/17/2026 16:00	1	77	77	0	28
06/17/2026 17:00	1	74	74	0	28
06/17/2026 18:00	1	71	71	0	28
06/17/2026 19:00	1	67	68	0	0
06/17/2026 20:00	1	66	67	0	0
06/17/2026 21:00	1	66	67	0	0
06/17/2026 22:00	1	66	67	0	0
06/17/2026 23:00	1	66	67	0	0
Average/Sum#:	24 #	70	71	0	16
Minimum:	1	59	60	0	0
Maximum:	1	77	78	0	28
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
06/18/2026 00:00	1	66	67	0	0
06/18/2026 01:00	1	67	67	0	0
06/18/2026 02:00	1	67	67	0	0
06/18/2026 03:00	1	67	67	0	0
06/18/2026 04:00	1	67	67	0	0
06/18/2026 05:00	1	67	68	0	0
06/18/2026 06:00	1	60	61	0	0
06/18/2026 07:00	1	53	54	0	0
06/18/2026 08:00	1	46	47	0	0
06/18/2026 09:00	1	46	47	0	0
06/18/2026 10:00	1	46	47	0	0
06/18/2026 11:00	1	46	47	0	0
06/18/2026 12:00	1	46	47	0	0
06/18/2026 13:00	1	46	47	0	0
06/18/2026 14:00	1	46	47	0	0
06/18/2026 15:00	1	46	47	0	0
06/18/2026 16:00	1	46	47	0	0
06/18/2026 17:00	1	49	50	0	0
06/18/2026 18:00	1	58	58	0	0
06/18/2026 19:00	1	67	68	0	0
06/18/2026 20:00	1	74	75	0	0
06/18/2026 21:00	1	72	73	0	0
06/18/2026 22:00	1	70	70	0	0
06/18/2026 23:00	1	67	68	0	0
Average/Sum#:	24 #	58	58	0	0
Minimum:	1	46	47	0	0
Maximum:	1	74	75	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
06/19/2026 00:00	1	68	68	0	0
06/19/2026 01:00	1	68	68	0	0
06/19/2026 02:00	1	67	68	0	0
06/19/2026 03:00	1	66	67	0	0
06/19/2026 04:00	1	66	67	0	0
06/19/2026 05:00	1	60	62	0	0
06/19/2026 06:00	1	38	55	0	0
06/19/2026 07:00	1	16	48	0	0
06/19/2026 08:00	1	0	45	0	0
06/19/2026 09:00	1	0	45	0	0
06/19/2026 10:00	1	0	45	0	0
06/19/2026 11:00	1	0	45	0	0
06/19/2026 12:00	1	0	45	0	0
06/19/2026 13:00	1	0	45	0	0
06/19/2026 14:00	1	0	45	0	0
06/19/2026 15:00	1	0	46	0	0
06/19/2026 16:00	1	0	48	0	0
06/19/2026 17:00	1	0	49	0	0
06/19/2026 18:00	1	0	49	0	0
06/19/2026 19:00	1	0	50	0	0
06/19/2026 20:00	1	0	49	0	0
06/19/2026 21:00	1	0	47	0	0
06/19/2026 22:00	1	0	45	0	0
06/19/2026 23:00	1	0	45	0	0
Average/Sum#:	24 #	19	52	0	0
Minimum:	1	0	45	0	0
Maximum:	1	68	68	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
06/20/2026 00:00	1	0	44	0	0
06/20/2026 01:00	1	0	44	0	0
06/20/2026 02:00	1	0	44	0	0
06/20/2026 03:00	1	0	44	0	0
06/20/2026 04:00	1	0	44	0	0
06/20/2026 05:00	1	0	45	0	0
06/20/2026 06:00	1	0	45	0	0
06/20/2026 07:00	1	0	45	0	0
06/20/2026 08:00	1	0	44	0	0
06/20/2026 09:00	1	0	45	0	0
06/20/2026 10:00	1	0	45	0	0
06/20/2026 11:00	1	0	45	0	0
06/20/2026 12:00	1	0	45	0	0
06/20/2026 13:00	1	0	45	0	0
06/20/2026 14:00	1	0	45	0	0
06/20/2026 15:00	1	0	45	0	0
06/20/2026 16:00	1	0	45	0	0
06/20/2026 17:00	1	0	45	0	0
06/20/2026 18:00	1	0	45	0	0
06/20/2026 19:00	1	0	45	0	0
06/20/2026 20:00	1	0	45	0	0
06/20/2026 21:00	1	0	45	0	0
06/20/2026 22:00	1	0	45	0	0
06/20/2026 23:00	1	0	45	0	0
Average/Sum#:	24 #	0	45	0	0
Minimum:	1	0	44	0	0
Maximum:	1	0	45	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
06/21/2026 00:00	1	0	44	0	0
06/21/2026 01:00	1	0	44	0	0
06/21/2026 02:00	1	0	44	0	0
06/21/2026 03:00	1	0	44	0	0
06/21/2026 04:00	1	0	44	0	0
06/21/2026 05:00	1	0	44	0	0
06/21/2026 06:00	1	0	44	0	0
06/21/2026 07:00	1	0	45	0	0
06/21/2026 08:00	1	0	45	0	0
06/21/2026 09:00	1	0	45	0	0
06/21/2026 10:00	1	0	45	0	0
06/21/2026 11:00	1	0	45	0	0
06/21/2026 12:00	1	0	45	0	0
06/21/2026 13:00	1	0	45	0	0
06/21/2026 14:00	1	0	45	0	0
06/21/2026 15:00	1	0	45	0	0
06/21/2026 16:00	1	0	45	0	0
06/21/2026 17:00	1	0	46	0	0
06/21/2026 18:00	1	0	49	0	0
06/21/2026 19:00	1	0	52	0	0
06/21/2026 20:00	1	0	54	0	0
06/21/2026 21:00	1	0	54	0	0
06/21/2026 22:00	1	0	54	0	0
06/21/2026 23:00	1	0	55	0	0
Average/Sum#:	24 #	0	47	0	0
Minimum:	1	0	44	0	0
Maximum:	1	0	55	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
06/22/2026 00:00	1	0	53	0	0
06/22/2026 01:00	1	0	49	0	0
06/22/2026 02:00	1	0	45	0	0
06/22/2026 03:00	1	0	44	0	0
06/22/2026 04:00	1	0	44	0	0
06/22/2026 05:00	1	0	45	0	0
06/22/2026 06:00	1	0	45	0	0
06/22/2026 07:00	1	0	45	0	0
06/22/2026 08:00	1	0	44	0	0
06/22/2026 09:00	1	0	46	0	0
06/22/2026 10:00	1	0	48	0	0
06/22/2026 11:00	1	0	49	0	0
06/22/2026 12:00	1	0	47	0	0
06/22/2026 13:00	1	0	46	0	0
06/22/2026 14:00	1	0	45	0	0
06/22/2026 15:00	1	0	45	0	0
06/22/2026 16:00	1	0	45	0	0
06/22/2026 17:00	1	0	47	0	0
06/22/2026 18:00	1	0	50	0	0
06/22/2026 19:00	1	0	51	0	0
06/22/2026 20:00	1	0	49	0	0
06/22/2026 21:00	1	0	45	0	0
06/22/2026 22:00	1	0	44	0	0
06/22/2026 23:00	1	0	44	0	0
Average/Sum#:	24 #	0	46	0	0
Minimum:	1	0	44	0	0
Maximum:	1	0	53	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
06/23/2026 00:00	1	0	44	0	0
06/23/2026 01:00	1	0	44	0	0
06/23/2026 02:00	1	0	44	0	0
06/23/2026 03:00	1	0	44	0	0
06/23/2026 04:00	1	0	44	0	0
06/23/2026 05:00	1	0	44	0	0
06/23/2026 06:00	1	0	44	0	0
06/23/2026 07:00	1	0	44	0	0
06/23/2026 08:00	1	0	44	0	0
06/23/2026 09:00	1	0	44	0	0
06/23/2026 10:00	1	0	44	0	0
06/23/2026 11:00	1	0	44	0	0
06/23/2026 12:00	1	0	44	0	0
06/23/2026 13:00	1	0	44	0	0
06/23/2026 14:00	1	0	45	0	0
06/23/2026 15:00	1	0	47	0	0
06/23/2026 16:00	1	0	49	0	0
06/23/2026 17:00	1	0	50	0	0
06/23/2026 18:00	1	0	52	0	0
06/23/2026 19:00	1	0	54	0	0
06/23/2026 20:00	1	0	56	0	0
06/23/2026 21:00	1	0	55	0	0
06/23/2026 22:00	1	0	54	0	0
06/23/2026 23:00	1	0	53	0	0
Average/Sum#:	24 #	0	47	0	0
Minimum:	1	0	44	0	0
Maximum:	1	0	56	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
06/24/2026 00:00	1	0	52	0	0
06/24/2026 01:00	1	0	50	0	0
06/24/2026 02:00	1	0	46	0	0
06/24/2026 03:00	1	0	45	0	0
06/24/2026 04:00	1	0	44	0	0
06/24/2026 05:00	1	0	48	0	0
06/24/2026 06:00	1	0	48	0	0
06/24/2026 07:00	1	0	48	0	0
06/24/2026 08:00	1	0	44	0	0
06/24/2026 09:00	1	0	44	0	0
06/24/2026 10:00	1	0	44	0	0
06/24/2026 11:00	1	0	44	0	0
06/24/2026 12:00	1	0	46	0	0
06/24/2026 13:00	1	0	48	0	0
06/24/2026 14:00	1	0	52	0	0
06/24/2026 15:00	1	0	53	0	0
06/24/2026 16:00	1	0	52	0	0
06/24/2026 17:00	1	0	50	0	0
06/24/2026 18:00	1	0	48	0	0
06/24/2026 19:00	1	0	46	0	0
06/24/2026 20:00	1	0	45	0	0
06/24/2026 21:00	1	0	44	0	0
06/24/2026 22:00	1	0	44	0	0
06/24/2026 23:00	1	0	44	0	0
Average/Sum#:	24 #	0	47	0	0
Minimum:	1	0	44	0	0
Maximum:	1	0	53	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
06/25/2026 00:00	1	0	44	0	0
06/25/2026 01:00	1	0	44	0	0
06/25/2026 02:00	1	0	44	0	0
06/25/2026 03:00	1	0	44	0	0
06/25/2026 04:00	1	0	45	0	0
06/25/2026 05:00	1	0	47	0	0
06/25/2026 06:00	1	0	47	0	0
06/25/2026 07:00	1	0	46	0	0
06/25/2026 08:00	1	0	44	0	0
06/25/2026 09:00	1	0	44	0	0
06/25/2026 10:00	1	0	44	0	0
06/25/2026 11:00	1	0	44	0	0
06/25/2026 12:00	1	0	44	0	0
06/25/2026 13:00	1	0	44	0	0
06/25/2026 14:00	1	0	44	0	0
06/25/2026 15:00	1	0	44	0	0
06/25/2026 16:00	1	0	44	0	0
06/25/2026 17:00	1	0	45	0	0
06/25/2026 18:00	1	0	46	0	0
06/25/2026 19:00	1	0	47	0	0
06/25/2026 20:00	1	0	46	0	0
06/25/2026 21:00	1	0	44	0	0
06/25/2026 22:00	1	0	44	0	0
06/25/2026 23:00	1	0	44	0	0
Average/Sum#:	24 #	0	45	0	0
Minimum:	1	0	44	0	0
Maximum:	1	0	47	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
06/26/2026 00:00	1	0	44	0	0
06/26/2026 01:00	1	0	44	0	0
06/26/2026 02:00	1	0	44	0	0
06/26/2026 03:00	1	0	44	0	0
06/26/2026 04:00	1	0	44	0	0
06/26/2026 05:00	1	0	44	0	0
06/26/2026 06:00	1	0	44	0	0
06/26/2026 07:00	1	0	44	0	0
06/26/2026 08:00	1	0	44	0	0
06/26/2026 09:00	1	0	44	0	0
06/26/2026 10:00	1	0	44	0	0
06/26/2026 11:00	1	0	44	0	0
06/26/2026 12:00	1	0	44	0	0
06/26/2026 13:00	1	0	44	0	0
06/26/2026 14:00	1	0	44	0	0
06/26/2026 15:00	1	0	44	0	0
06/26/2026 16:00	1	0	44	0	0
06/26/2026 17:00	1	0	44	0	0
06/26/2026 18:00	1	0	46	0	0
06/26/2026 19:00	1	0	46	0	0
06/26/2026 20:00	1	0	46	0	0
06/26/2026 21:00	1	0	44	0	0
06/26/2026 22:00	1	0	44	0	0
06/26/2026 23:00	1	0	44	0	0
Average/Sum#:	24 #	0	44	0	0
Minimum:	1	0	44	0	0
Maximum:	1	0	46	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
06/27/2026 00:00	1	0	44	0	0
06/27/2026 01:00	1	0	44	0	0
06/27/2026 02:00	1	0	44	0	0
06/27/2026 03:00	1	0	44	0	0
06/27/2026 04:00	1	0	44	0	0
06/27/2026 05:00	1	0	44	0	0
06/27/2026 06:00	1	0	44	0	0
06/27/2026 07:00	1	0	44	0	0
06/27/2026 08:00	1	0	44	0	0
06/27/2026 09:00	1	0	44	0	0
06/27/2026 10:00	1	0	44	0	0
06/27/2026 11:00	1	0	44	0	0
06/27/2026 12:00	1	0	44	0	0
06/27/2026 13:00	1	0	44	0	0
06/27/2026 14:00	1	0	45	0	0
06/27/2026 15:00	1	0	45	0	0
06/27/2026 16:00	1	0	44	0	0
06/27/2026 17:00	1	0	44	0	0
06/27/2026 18:00	1	0	45	0	0
06/27/2026 19:00	1	0	45	0	0
06/27/2026 20:00	1	0	45	0	0
06/27/2026 21:00	1	0	44	0	0
06/27/2026 22:00	1	0	44	0	0
06/27/2026 23:00	1	0	44	0	0
Average/Sum#:	24 #	0	44	0	0
Minimum:	1	0	44	0	0
Maximum:	1	0	45	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
06/28/2026 00:00	1	0	44	0	0
06/28/2026 01:00	1	0	44	0	0
06/28/2026 02:00	1	0	44	0	0
06/28/2026 03:00	1	0	44	0	0
06/28/2026 04:00	1	0	44	0	0
06/28/2026 05:00	1	0	44	0	0
06/28/2026 06:00	1	0	44	0	0
06/28/2026 07:00	1	0	44	0	0
06/28/2026 08:00	1	0	44	0	0
06/28/2026 09:00	1	0	44	0	0
06/28/2026 10:00	1	0	44	0	0
06/28/2026 11:00	1	0	44	0	0
06/28/2026 12:00	1	0	44	0	0
06/28/2026 13:00	1	0	44	0	0
06/28/2026 14:00	1	0	44	0	0
06/28/2026 15:00	1	0	44	0	0
06/28/2026 16:00	1	0	44	0	0
06/28/2026 17:00	1	0	44	0	0
06/28/2026 18:00	1	0	44	0	0
06/28/2026 19:00	1	0	44	0	0
06/28/2026 20:00	1	0	45	0	0
06/28/2026 21:00	1	0	45	0	0
06/28/2026 22:00	1	0	45	0	0
06/28/2026 23:00	1	0	45	0	0
Average/Sum#:	24 #	0	44	0	0
Minimum:	1	0	44	0	0
Maximum:	1	0	45	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
06/29/2026 00:00	1	0	45	0	0
06/29/2026 01:00	1	0	44	0	0
06/29/2026 02:00	1	0	44	0	0
06/29/2026 03:00	1	0	44	0	0
06/29/2026 04:00	1	0	44	0	0
06/29/2026 05:00	1	0	44	0	0
06/29/2026 06:00	1	0	44	0	0
06/29/2026 07:00	1	0	44	0	0
06/29/2026 08:00	1	0	44	0	0
06/29/2026 09:00	1	0	44	0	0
06/29/2026 10:00	1	0	44	0	0
06/29/2026 11:00	1	0	44	0	0
06/29/2026 12:00	1	0	44	0	0
06/29/2026 13:00	1	0	44	0	0
06/29/2026 14:00	1	0	44	0	0
06/29/2026 15:00	1	0	44	0	0
06/29/2026 16:00	1	0	44	0	0
06/29/2026 17:00	1	0	45	0	0
06/29/2026 18:00	1	0	45	0	0
06/29/2026 19:00	1	0	45	0	0
06/29/2026 20:00	1	0	44	0	0
06/29/2026 21:00	1	0	44	0	0
06/29/2026 22:00	1	0	44	0	0
06/29/2026 23:00	1	0	48	0	0
Average/Sum#:	24 #	0	44	0	0
Minimum:	1	0	44	0	0
Maximum:	1	0	48	0	0
%SI	0.00	0.00	0.00	0.00	0.00

AQ34 3HR AVG LOAD

CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:56 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Units CT1 & CT2 UnitOn, TF 1 Hour(s)	Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
06/30/2026 00:00	1	0	52	0	0
06/30/2026 01:00	1	0	56	0	0
06/30/2026 02:00	1	0	56	0	0
06/30/2026 03:00	1	0	56	0	0
06/30/2026 04:00	1	0	56	0	0
06/30/2026 05:00	1	0	55	0	0
06/30/2026 06:00	1	0	55	0	0
06/30/2026 07:00	1	0	54	0	0
06/30/2026 08:00	1	0	55	0	0
06/30/2026 09:00	1	0	55	0	0
06/30/2026 10:00	1	0	56	0	0
06/30/2026 11:00	1	0	52	0	0
06/30/2026 12:00	1	0	49	0	0
06/30/2026 13:00	1	0	46	0	0
06/30/2026 14:00	1	0	46	0	0
06/30/2026 15:00	1	0	47	0	0
06/30/2026 16:00	1	0	47	0	0
06/30/2026 17:00	1	0	47	0	0
06/30/2026 18:00	1	0	50	0	0
06/30/2026 19:00	1	0	50	0	0
06/30/2026 20:00	1	0	51	0	0
06/30/2026 21:00	1	0	48	0	0
06/30/2026 22:00	1	0	47	0	0
06/30/2026 23:00	1	0	46	0	0
Average/Sum#:	24 #	0	51	0	0
Minimum:	1	0	46	0	0
Maximum:	1	0	56	0	0
%SI	0.00	0.00	0.00	0.00	0.00

Monthly Summary Report

Units CT1 / CT2 / CT5 / CT6

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/01/2026 08:10 **Location:** Roseville, CA

	Unit CT1 OperatingTime, Hr		Unit CT1 DBOn, Hr		Unit CT2 OperatingTime, Hr		Unit CT2 DBOn, Hr		Unit CT5 OperatingTime, Hr		Unit CT6 OperatingTime, Hr	
	1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)		1 Hour(s)	
Date	Sum	Running Sum	Sum	Running Sum	Sum	Running Sum	Sum	Running Sum	Sum	Running Sum	Sum	Running Sum
Apr 26	107.78	107.78	1.08	1.08	144.18	144.18	0.97	0.97	0.00	0.00	0.00	0.00
May 26	122.16	229.94	6.50	7.58	278.61	422.79	8.91	9.88	8.50	8.50	10.53	10.53
Jun 26	373.27	603.21	102.70	110.28	569.34	992.13	102.85	112.73	20.96	29.46	26.81	37.34
Sum/Avg	603.21		110.28		992.13		112.73		29.46		37.34	
Limit												

Tons 12 Month Rolling Summary

CT1 and CT2 Combined

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/01/2026 08:10 **Location:** Roseville, CA

* = Excess Emission

	Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2	
	CO, Ton		NOx, Ton		PM10, Ton		SO2, Ton		VOC, Ton	
	1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)	
Date	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Apr 2026	0.3728	3.6946	0.3738	7.9810	0.0698	1.7251	0.0350	0.8657	0.1163	2.8859
May 2026	0.5937	3.7674	0.5422	7.4867	0.0976	1.6073	0.0492	0.8073	0.1630	2.6892
Jun 2026	0.3743	3.7226	1.1646	7.7370	0.2439	1.6487	0.1229	0.8290	0.4076	2.7589
Sum/Avg	3.7226		7.7370		1.6487		0.8290		2.7589	
Limit										

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/01/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/01/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/01/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/01/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/01/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/01/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/01/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/01/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/01/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/01/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/01/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/01/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/01/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/01/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/01/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/01/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/01/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/01/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/01/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/01/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/01/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/01/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/01/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/01/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/02/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/02/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/02/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/02/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/02/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/02/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/02/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/02/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/02/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/02/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/02/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/02/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/02/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/02/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/02/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/02/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/02/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/02/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/02/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/02/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/02/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/02/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/02/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/02/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/03/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/03/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/03/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/03/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/03/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/03/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/03/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/03/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/03/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/03/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/03/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/03/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/03/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/03/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/03/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/03/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/03/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/03/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/03/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/03/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/03/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/03/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/03/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/03/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/04/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/04/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/04/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/04/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/04/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/04/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/04/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/04/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/04/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/04/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/04/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/04/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/04/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/04/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/04/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/04/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/04/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/04/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/04/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/04/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/04/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/04/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/04/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/04/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/05/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/05/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/05/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/05/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/05/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/05/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/05/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/05/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/05/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/05/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/05/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/05/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/05/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/05/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/05/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/05/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/05/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/05/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/05/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/05/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/05/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/05/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/05/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/05/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/06/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/06/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/06/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/06/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/06/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/06/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/06/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/06/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/06/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/06/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/06/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/06/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/06/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/06/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/06/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/06/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/06/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/06/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/06/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/06/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/06/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/06/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/06/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/06/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/07/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/07/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/07/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/07/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/07/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/07/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/07/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/07/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/07/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/07/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/07/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/07/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/07/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/07/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/07/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/07/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/07/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/07/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/07/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/07/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/07/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/07/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/07/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/07/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/08/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/08/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/08/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/08/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/08/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/08/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/08/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/08/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/08/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/08/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/08/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/08/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/08/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/08/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/08/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/08/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/08/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/08/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/08/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/08/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/08/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/08/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/08/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/08/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/09/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/09/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/09/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/09/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/09/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/09/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/09/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/09/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/09/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/09/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/09/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/09/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/09/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/09/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/09/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/09/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/09/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/09/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/09/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/09/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/09/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/09/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/09/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/09/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/10/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/10/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/10/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/10/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/10/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/10/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/10/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/10/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/10/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/10/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/10/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/10/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/10/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/10/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/10/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/10/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/10/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/10/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/10/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/10/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/10/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/10/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/10/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/10/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/11/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/11/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/11/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/11/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/11/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/11/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/11/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/11/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/11/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/11/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/11/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/11/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/11/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/11/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/11/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/11/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/11/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/11/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/11/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/11/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/11/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/11/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/11/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/11/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/12/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/12/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/12/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/12/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/12/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/12/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/12/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/12/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/12/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/12/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/12/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/12/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/12/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/12/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/12/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/12/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/12/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/12/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/12/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/12/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/12/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/12/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/12/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/12/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/13/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/13/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/13/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/13/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/13/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/13/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/13/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/13/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/13/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/13/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/13/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/13/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/13/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/13/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/13/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/13/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/13/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/13/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/13/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/13/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/13/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/13/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/13/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/13/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/14/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/14/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/14/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/14/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/14/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/14/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/14/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/14/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/14/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/14/2026 09:00	1,812.4	0.0	1,812.4	104,500.0	189.4	0.00	0.0	0.0
04/14/2026 10:00	3,690.2	0.0	3,690.2	104,500.0	385.6	0.43	0.2	0.7
04/14/2026 11:00	4,203.1	0.0	4,203.1	104,500.0	439.2	0.53	0.3	0.9
04/14/2026 12:00	4,498.8	1,595.5	6,062.4	104,500.0	633.5	0.76	0.4	1.3
04/14/2026 13:00	3,845.2	116.4	3,856.8	104,500.0	403.0	0.53	0.3	0.9
04/14/2026 14:00	976.8	64.0	976.8	104,500.0	102.1	0.00	0.0	0.0
04/14/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/14/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/14/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/14/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/14/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/14/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/14/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/14/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/14/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Average/Sum#:	3,171.1	296.0	3,433.6	104,500.0	358.8	0.56	0.3	1.0
Minimum:	976.8	0.0	976.8	104,500.0	102.1	0.43	0.2	0.7
Maximum:	4,498.8	1,595.5	6,062.4	104,500.0	633.5	0.76	0.4	1.3
%SI	75.00	75.00	75.00	0.00	75.00	83.33	83.33	83.33

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/15/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/15/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/15/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/15/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/15/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/15/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/15/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/15/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/15/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/15/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/15/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/15/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/15/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/15/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/15/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/15/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/15/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/15/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/15/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/15/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/15/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/15/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/15/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/15/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/16/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/16/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/16/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/16/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/16/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/16/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/16/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/16/2026 07:00	1,718.5	0.0	1,718.5	104,500.0	179.6	0.00	0.0	0.0
04/16/2026 08:00	4,332.5	0.0	4,332.5	104,500.0	452.7	0.55	0.3	0.9
04/16/2026 09:00	4,348.0	0.0	4,348.0	104,500.0	454.4	0.55	0.3	0.9
04/16/2026 10:00	4,352.9	0.0	4,352.9	104,500.0	454.9	0.55	0.3	0.9
04/16/2026 11:00	4,376.9	0.0	4,376.9	104,500.0	457.4	0.55	0.3	0.9
04/16/2026 12:00	4,388.3	14.9	4,388.3	104,500.0	458.6	0.55	0.3	0.9
04/16/2026 13:00	4,383.5	30.6	4,383.5	104,500.0	458.1	0.56	0.3	0.9
04/16/2026 14:00	3,986.5	0.8	3,986.5	104,500.0	416.6	0.51	0.3	0.9
04/16/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/16/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/16/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/16/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/16/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/16/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/16/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/16/2026 22:00	2,261.6	0.0	2,261.6	104,500.0	236.3	0.00	0.0	0.0
04/16/2026 23:00	3,410.5	0.0	3,410.5	104,500.0	356.4	0.43	0.2	0.7
Average/Sum#:	3,755.9	4.6	3,755.9	104,500.0	392.5	0.53	0.3	0.9
Minimum:	1,718.5	0.0	1,718.5	104,500.0	179.6	0.43	0.2	0.7
Maximum:	4,388.3	30.6	4,388.3	104,500.0	458.6	0.56	0.3	0.9
%SI	58.33	58.33	58.33	0.00	58.33	66.67	66.67	66.67

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/17/2026 00:00	4,084.7	0.0	4,084.7	104,500.0	426.9	0.51	0.3	0.9
04/17/2026 01:00	4,328.9	0.0	4,328.9	104,500.0	452.4	0.54	0.3	0.9
04/17/2026 02:00	4,336.2	0.0	4,336.2	104,500.0	453.1	0.54	0.3	0.9
04/17/2026 03:00	4,354.3	0.0	4,354.3	104,500.0	455.0	0.55	0.3	0.9
04/17/2026 04:00	4,349.3	0.0	4,349.3	104,500.0	454.5	0.55	0.3	0.9
04/17/2026 05:00	4,362.4	0.0	4,362.4	104,500.0	455.9	0.55	0.3	0.9
04/17/2026 06:00	4,366.7	0.0	4,366.7	104,500.0	456.3	0.55	0.3	0.9
04/17/2026 07:00	4,372.1	0.0	4,372.1	104,500.0	456.9	0.55	0.3	0.9
04/17/2026 08:00	4,369.6	0.1	4,369.6	104,500.0	456.6	0.55	0.3	0.9
04/17/2026 09:00	4,369.1	0.0	4,369.1	104,500.0	456.6	0.55	0.3	0.9
04/17/2026 10:00	4,377.3	0.0	4,377.3	104,500.0	457.4	0.55	0.3	0.9
04/17/2026 11:00	4,400.7	0.0	4,400.7	104,500.0	459.9	0.55	0.3	0.9
04/17/2026 12:00	4,405.2	23.1	4,405.2	104,500.0	460.3	0.55	0.3	0.9
04/17/2026 13:00	4,396.6	56.5	4,396.6	104,500.0	459.4	0.56	0.3	0.9
04/17/2026 14:00	4,384.9	10.7	4,384.9	104,500.0	458.2	0.55	0.3	0.9
04/17/2026 15:00	4,375.7	0.0	4,375.7	104,500.0	457.3	0.55	0.3	0.9
04/17/2026 16:00	4,379.8	0.0	4,379.8	104,500.0	457.7	0.55	0.3	0.9
04/17/2026 17:00	4,373.8	0.0	4,373.8	104,500.0	457.1	0.55	0.3	0.9
04/17/2026 18:00	4,370.6	0.0	4,370.6	104,500.0	456.7	0.55	0.3	0.9
04/17/2026 19:00	4,366.5	0.0	4,366.5	104,500.0	456.3	0.55	0.3	0.9
04/17/2026 20:00	4,366.0	0.0	4,366.0	104,500.0	456.2	0.55	0.3	0.9
04/17/2026 21:00	4,367.1	0.0	4,367.1	104,500.0	456.4	0.55	0.3	0.9
04/17/2026 22:00	4,367.6	0.0	4,367.6	104,500.0	456.4	0.55	0.3	0.9
04/17/2026 23:00	4,370.2	0.0	4,370.2	104,500.0	456.7	0.55	0.3	0.9
Average/Sum#:	4,358.1	3.8	4,358.1	104,500.0	455.4	0.55	0.3	0.9
Minimum:	4,084.7	0.0	4,084.7	104,500.0	426.9	0.51	0.3	0.9
Maximum:	4,405.2	56.5	4,405.2	104,500.0	460.3	0.56	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/18/2026 00:00	4,377.0	0.0	4,377.0	104,500.0	457.4	0.55	0.3	0.9
04/18/2026 01:00	4,373.3	0.0	4,373.3	104,500.0	457.0	0.55	0.3	0.9
04/18/2026 02:00	4,373.0	0.0	4,373.0	104,500.0	457.0	0.55	0.3	0.9
04/18/2026 03:00	4,369.3	0.0	4,369.3	104,500.0	456.6	0.55	0.3	0.9
04/18/2026 04:00	4,364.8	0.0	4,364.8	104,500.0	456.1	0.55	0.3	0.9
04/18/2026 05:00	4,367.9	0.0	4,367.9	104,500.0	456.4	0.55	0.3	0.9
04/18/2026 06:00	4,367.3	0.0	4,367.3	104,500.0	456.4	0.55	0.3	0.9
04/18/2026 07:00	3,921.6	1.7	3,921.6	104,500.0	409.8	0.49	0.2	0.8
04/18/2026 08:00	3,401.7	21.3	3,401.7	104,500.0	355.5	0.43	0.2	0.7
04/18/2026 09:00	3,967.6	0.0	3,967.6	104,500.0	414.6	0.50	0.2	0.8
04/18/2026 10:00	4,384.9	0.9	4,384.9	104,500.0	458.2	0.55	0.3	0.9
04/18/2026 11:00	4,410.4	0.1	4,410.4	104,500.0	460.9	0.55	0.3	0.9
04/18/2026 12:00	4,407.6	28.2	4,407.6	104,500.0	460.6	0.55	0.3	0.9
04/18/2026 13:00	4,405.8	33.8	4,405.8	104,500.0	460.4	0.56	0.3	0.9
04/18/2026 14:00	4,405.3	12.2	4,405.3	104,500.0	460.4	0.55	0.3	0.9
04/18/2026 15:00	4,403.6	0.0	4,403.6	104,500.0	460.2	0.55	0.3	0.9
04/18/2026 16:00	4,396.5	0.0	4,396.5	104,500.0	459.4	0.55	0.3	0.9
04/18/2026 17:00	4,395.2	0.0	4,395.2	104,500.0	459.3	0.55	0.3	0.9
04/18/2026 18:00	4,385.5	0.0	4,385.5	104,500.0	458.3	0.55	0.3	0.9
04/18/2026 19:00	4,386.8	0.0	4,386.8	104,500.0	458.4	0.55	0.3	0.9
04/18/2026 20:00	4,373.6	0.0	4,373.6	104,500.0	457.0	0.55	0.3	0.9
04/18/2026 21:00	4,377.7	0.0	4,377.7	104,500.0	457.5	0.55	0.3	0.9
04/18/2026 22:00	4,382.6	0.0	4,382.6	104,500.0	458.0	0.55	0.3	0.9
04/18/2026 23:00	4,383.5	0.0	4,383.5	104,500.0	458.1	0.55	0.3	0.9
Average/Sum#:	4,307.6	4.1	4,307.6	104,500.0	450.1	0.54	0.3	0.9
Minimum:	3,401.7	0.0	3,401.7	104,500.0	355.5	0.43	0.2	0.7
Maximum:	4,410.4	33.8	4,410.4	104,500.0	460.9	0.56	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/19/2026 00:00	4,375.4	0.0	4,375.4	104,500.0	457.2	0.55	0.3	0.9
04/19/2026 01:00	4,373.2	0.0	4,373.2	104,500.0	457.0	0.55	0.3	0.9
04/19/2026 02:00	4,372.1	0.0	4,372.1	104,500.0	456.9	0.55	0.3	0.9
04/19/2026 03:00	4,368.8	0.0	4,368.8	104,500.0	456.5	0.55	0.3	0.9
04/19/2026 04:00	4,370.1	0.0	4,370.1	104,500.0	456.7	0.55	0.3	0.9
04/19/2026 05:00	4,372.3	0.0	4,372.3	104,500.0	456.9	0.55	0.3	0.9
04/19/2026 06:00	4,382.7	0.0	4,382.7	104,500.0	458.0	0.55	0.3	0.9
04/19/2026 07:00	4,397.5	4.3	4,397.5	104,500.0	459.5	0.55	0.3	0.9
04/19/2026 08:00	4,391.6	12.3	4,391.6	104,500.0	458.9	0.55	0.3	0.9
04/19/2026 09:00	4,397.6	0.0	4,397.6	104,500.0	459.5	0.55	0.3	0.9
04/19/2026 10:00	4,401.3	4.7	4,401.3	104,500.0	459.9	0.55	0.3	0.9
04/19/2026 11:00	4,414.8	0.0	4,414.8	104,500.0	461.3	0.55	0.3	0.9
04/19/2026 12:00	4,414.3	16.6	4,414.3	104,500.0	461.3	0.55	0.3	0.9
04/19/2026 13:00	4,419.1	22.2	4,419.1	104,500.0	461.8	0.56	0.3	0.9
04/19/2026 14:00	4,409.2	1.4	4,409.2	104,500.0	460.8	0.55	0.3	0.9
04/19/2026 15:00	4,408.0	0.0	4,408.0	104,500.0	460.6	0.55	0.3	0.9
04/19/2026 16:00	4,403.0	0.0	4,403.0	104,500.0	460.1	0.55	0.3	0.9
04/19/2026 17:00	4,392.1	0.0	4,392.1	104,500.0	459.0	0.55	0.3	0.9
04/19/2026 18:00	4,386.2	0.0	4,386.2	104,500.0	458.4	0.55	0.3	0.9
04/19/2026 19:00	4,385.1	0.0	4,385.1	104,500.0	458.2	0.55	0.3	0.9
04/19/2026 20:00	4,387.7	0.0	4,387.7	104,500.0	458.5	0.55	0.3	0.9
04/19/2026 21:00	4,384.6	0.0	4,384.6	104,500.0	458.2	0.55	0.3	0.9
04/19/2026 22:00	4,383.0	0.0	4,383.0	104,500.0	458.0	0.55	0.3	0.9
04/19/2026 23:00	4,382.6	0.0	4,382.6	104,500.0	458.0	0.55	0.3	0.9
Average/Sum#:	4,390.5	2.6	4,390.5	104,500.0	458.8	0.55	0.3	0.9
Minimum:	4,368.8	0.0	4,368.8	104,500.0	456.5	0.55	0.3	0.9
Maximum:	4,419.1	22.2	4,419.1	104,500.0	461.8	0.56	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/20/2026 00:00	4,385.1	0.0	4,385.1	104,500.0	458.2	0.55	0.3	0.9
04/20/2026 01:00	4,372.6	0.0	4,372.6	104,500.0	456.9	0.55	0.3	0.9
04/20/2026 02:00	4,367.9	0.0	4,367.9	104,500.0	456.4	0.55	0.3	0.9
04/20/2026 03:00	4,360.1	0.0	4,360.1	104,500.0	455.6	0.55	0.3	0.9
04/20/2026 04:00	4,363.4	0.0	4,363.4	104,500.0	456.0	0.55	0.3	0.9
04/20/2026 05:00	4,364.8	0.0	4,364.8	104,500.0	456.1	0.55	0.3	0.9
04/20/2026 06:00	4,380.6	0.0	4,380.6	104,500.0	457.8	0.55	0.3	0.9
04/20/2026 07:00	4,384.4	0.0	4,384.4	104,500.0	458.2	0.55	0.3	0.9
04/20/2026 08:00	4,388.1	0.0	4,388.1	104,500.0	458.6	0.55	0.3	0.9
04/20/2026 09:00	4,394.6	0.0	4,394.6	104,500.0	459.2	0.55	0.3	0.9
04/20/2026 10:00	4,411.2	0.0	4,411.2	104,500.0	461.0	0.55	0.3	0.9
04/20/2026 11:00	4,410.7	0.0	4,410.7	104,500.0	460.9	0.55	0.3	0.9
04/20/2026 12:00	4,408.0	0.0	4,408.0	104,500.0	460.6	0.55	0.3	0.9
04/20/2026 13:00	4,409.1	0.0	4,409.1	104,500.0	460.8	0.55	0.3	0.9
04/20/2026 14:00	4,403.1	0.0	4,403.1	104,500.0	460.1	0.55	0.3	0.9
04/20/2026 15:00	4,368.9	0.0	4,368.9	104,500.0	456.6	0.55	0.3	0.9
04/20/2026 16:00	4,363.7	0.0	4,363.7	104,500.0	456.0	0.55	0.3	0.9
04/20/2026 17:00	4,362.6	0.0	4,362.6	104,500.0	455.9	0.55	0.3	0.9
04/20/2026 18:00	4,358.8	0.0	4,358.8	104,500.0	455.5	0.55	0.3	0.9
04/20/2026 19:00	4,362.0	0.0	4,362.0	104,500.0	455.8	0.55	0.3	0.9
04/20/2026 20:00	4,355.0	0.0	4,355.0	104,500.0	455.1	0.55	0.3	0.9
04/20/2026 21:00	4,361.6	0.0	4,361.6	104,500.0	455.8	0.55	0.3	0.9
04/20/2026 22:00	4,013.7	0.0	4,013.7	104,500.0	419.4	0.55	0.3	0.9
04/20/2026 23:00	919.1	0.0	919.1	104,500.0	96.0	0.00	0.0	0.0
Average/Sum#:	4,219.5	0.0	4,219.5	104,500.0	440.9	0.55	0.3	0.9
Minimum:	919.1	0.0	919.1	104,500.0	96.0	0.55	0.3	0.9
Maximum:	4,411.2	0.0	4,411.2	104,500.0	461.0	0.55	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	4.17	4.17	4.17

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/21/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/21/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/21/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/21/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/21/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/21/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/21/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/21/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/21/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/21/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/21/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/21/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/21/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/21/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/21/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/21/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/21/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/21/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/21/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/21/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/21/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/21/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/21/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/21/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/22/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/22/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/22/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/22/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/22/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/22/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/22/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/22/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/22/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/22/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/22/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/22/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/22/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/22/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/22/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/22/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/22/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/22/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/22/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/22/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/22/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/22/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/22/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/22/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/23/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/23/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/23/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/23/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/23/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/23/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/23/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/23/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/23/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/23/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/23/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/23/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/23/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/23/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/23/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/23/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/23/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/23/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/23/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/23/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/23/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/23/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/23/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/23/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/24/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/24/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/24/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/24/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/24/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/24/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/24/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/24/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/24/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/24/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/24/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/24/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/24/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/24/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/24/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/24/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/24/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/24/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/24/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/24/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/24/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/24/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/24/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/24/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/25/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/25/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/25/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/25/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/25/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/25/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/25/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/25/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/25/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/25/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/25/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/25/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/25/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/25/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/25/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/25/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/25/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/25/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/25/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/25/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/25/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/25/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/25/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/25/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/26/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/26/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/26/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/26/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/26/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/26/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/26/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/26/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/26/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/26/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/26/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/26/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/26/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/26/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/26/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/26/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/26/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/26/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/26/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/26/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/26/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/26/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/26/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/26/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/27/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/27/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/27/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/27/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/27/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/27/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/27/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/27/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/27/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/27/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/27/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/27/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/27/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/27/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/27/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/27/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/27/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/27/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/27/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/27/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/27/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/27/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/27/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/27/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/28/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/28/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/28/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/28/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/28/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/28/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/28/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/28/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/28/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/28/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/28/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/28/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/28/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/28/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/28/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/28/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/28/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/28/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/28/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/28/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/28/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/28/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/28/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/28/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/29/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/29/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/29/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/29/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/29/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/29/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/29/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/29/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/29/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/29/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/29/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/29/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/29/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/29/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/29/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/29/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/29/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/29/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/29/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/29/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/29/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/29/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/29/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/29/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/30/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/30/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/30/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/30/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/30/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/30/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/30/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/30/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/30/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/30/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/30/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/30/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/30/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/30/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/30/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/30/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/30/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/30/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/30/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/30/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/30/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/30/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/30/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
04/30/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/01/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/01/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/01/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/01/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/01/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/01/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/01/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/01/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/01/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/01/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/01/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/01/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/01/2026 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/01/2026 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/01/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/01/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/01/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/01/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/01/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/01/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/01/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/01/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/01/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/01/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/02/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/02/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/02/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/02/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/02/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/02/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/02/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/02/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/02/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/02/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/02/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/02/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/02/2026 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/02/2026 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/02/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/02/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/02/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/02/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/02/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/02/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/02/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/02/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/02/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/02/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/03/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/03/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/03/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/03/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/03/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/03/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/03/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/03/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/03/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/03/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/03/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/03/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/03/2026 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/03/2026 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/03/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/03/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/03/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/03/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/03/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/03/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/03/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/03/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/03/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/03/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/04/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/04/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/04/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/04/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/04/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/04/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/04/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/04/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/04/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/04/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/04/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/04/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/04/2026 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/04/2026 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/04/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/04/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/04/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/04/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/04/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/04/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/04/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/04/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/04/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/04/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/05/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/05/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/05/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/05/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/05/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/05/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/05/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/05/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/05/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/05/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/05/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/05/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/05/2026 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/05/2026 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/05/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/05/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/05/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/05/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/05/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/05/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/05/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/05/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/05/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/05/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/06/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/06/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/06/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/06/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/06/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/06/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/06/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/06/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/06/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/06/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/06/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/06/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/06/2026 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/06/2026 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/06/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/06/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/06/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/06/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/06/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/06/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/06/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/06/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/06/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/06/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/07/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/07/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/07/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/07/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/07/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/07/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/07/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/07/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/07/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/07/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/07/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/07/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/07/2026 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/07/2026 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/07/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/07/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/07/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/07/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/07/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/07/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/07/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/07/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/07/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/07/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/08/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/08/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/08/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/08/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/08/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/08/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/08/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/08/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/08/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/08/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/08/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/08/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/08/2026 12:00	3,281.6	82.7	3,281.6	104,200.0	341.9	0.00	0.0	0.0
05/08/2026 13:00	3,967.5	68.8	3,967.5	104,200.0	413.4	0.50	0.3	0.8
05/08/2026 14:00	4,405.1	1,357.7	5,667.8	104,200.0	590.6	0.72	0.4	1.2
05/08/2026 15:00	3,188.1	172.7	3,220.8	104,200.0	335.6	0.57	0.3	0.9
05/08/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/08/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/08/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/08/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/08/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/08/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/08/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/08/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	3,710.6	420.5	4,034.4	104,200.0	420.4	0.60	0.3	1.0
Minimum:	3,188.1	68.8	3,220.8	104,200.0	335.6	0.50	0.3	0.8
Maximum:	4,405.1	1,357.7	5,667.8	104,200.0	590.6	0.72	0.4	1.2
%SI	83.33	83.33	83.33	0.00	83.33	87.50	87.50	87.50

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/09/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/09/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/09/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/09/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/09/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/09/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/09/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/09/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/09/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/09/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/09/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/09/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/09/2026 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/09/2026 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/09/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/09/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/09/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/09/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/09/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/09/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/09/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/09/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/09/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/09/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/10/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/10/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/10/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/10/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/10/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/10/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/10/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/10/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/10/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/10/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/10/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/10/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/10/2026 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/10/2026 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/10/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/10/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/10/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/10/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/10/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/10/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/10/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/10/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/10/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/10/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/11/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/11/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/11/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/11/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/11/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/11/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/11/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/11/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/11/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/11/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/11/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/11/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/11/2026 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/11/2026 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/11/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/11/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/11/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/11/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/11/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/11/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/11/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/11/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/11/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/11/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/12/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/12/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/12/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/12/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/12/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/12/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/12/2026 06:00	547.7	91.5	547.7	104,200.0	57.1	0.00	0.0	0.0
05/12/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/12/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/12/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/12/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/12/2026 11:00	1,656.7	81.2	1,656.7	104,200.0	172.6	0.00	0.0	0.0
05/12/2026 12:00	3,427.0	78.2	3,427.0	104,200.0	357.1	0.43	0.2	0.7
05/12/2026 13:00	3,733.8	69.1	3,733.8	104,200.0	389.1	0.48	0.2	0.8
05/12/2026 14:00	4,358.3	675.2	4,999.7	104,200.0	521.0	0.63	0.3	1.0
05/12/2026 15:00	4,348.6	1,138.1	5,486.7	104,200.0	571.7	0.69	0.3	1.1
05/12/2026 16:00	4,242.3	226.7	4,371.5	104,200.0	455.5	0.56	0.3	0.9
05/12/2026 17:00	3,206.0	69.8	3,206.0	104,200.0	334.1	0.44	0.2	0.7
05/12/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/12/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/12/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/12/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/12/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/12/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	3,190.1	303.7	3,428.6	104,200.0	357.3	0.54	0.3	0.9
Minimum:	547.7	69.1	547.7	104,200.0	57.1	0.43	0.2	0.7
Maximum:	4,358.3	1,138.1	5,486.7	104,200.0	571.7	0.69	0.3	1.1
%SI	66.67	66.67	66.67	0.00	66.67	75.00	75.00	75.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/13/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/13/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/13/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/13/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/13/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/13/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/13/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/13/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/13/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/13/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/13/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/13/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/13/2026 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/13/2026 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/13/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/13/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/13/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/13/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/13/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/13/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/13/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/13/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/13/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/13/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/14/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/14/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/14/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/14/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/14/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/14/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/14/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/14/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/14/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/14/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/14/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/14/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/14/2026 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/14/2026 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/14/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/14/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/14/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/14/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/14/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/14/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/14/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/14/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/14/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/14/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/15/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/15/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/15/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/15/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/15/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/15/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/15/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/15/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/15/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/15/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/15/2026 10:00	2,759.1	86.3	2,759.1	104,200.0	287.5	0.00	0.0	0.0
05/15/2026 11:00	4,189.9	111.3	4,189.9	104,200.0	436.6	0.54	0.3	0.9
05/15/2026 12:00	4,378.5	577.1	4,897.9	104,200.0	510.4	0.62	0.3	1.0
05/15/2026 13:00	4,375.4	1,428.7	5,804.1	104,200.0	604.8	0.73	0.4	1.2
05/15/2026 14:00	4,365.1	723.4	5,088.5	104,200.0	530.2	0.64	0.3	1.1
05/15/2026 15:00	3,755.8	110.9	3,764.7	104,200.0	392.3	0.49	0.2	0.8
05/15/2026 16:00	1,722.2	92.9	1,722.2	104,200.0	179.5	0.00	0.0	0.0
05/15/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/15/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/15/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/15/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/15/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/15/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/15/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	3,649.4	447.2	4,032.3	104,200.0	420.2	0.60	0.3	1.0
Minimum:	1,722.2	86.3	1,722.2	104,200.0	179.5	0.49	0.2	0.8
Maximum:	4,378.5	1,428.7	5,804.1	104,200.0	604.8	0.73	0.4	1.2
%SI	70.83	70.83	70.83	0.00	70.83	79.17	79.17	79.17

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/16/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/16/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/16/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/16/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/16/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/16/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/16/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/16/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/16/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/16/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/16/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/16/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/16/2026 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/16/2026 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/16/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/16/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/16/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/16/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/16/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/16/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/16/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/16/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/16/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/16/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/17/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/17/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/17/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/17/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/17/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/17/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/17/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/17/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/17/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/17/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/17/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/17/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/17/2026 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/17/2026 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/17/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/17/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/17/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/17/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/17/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/17/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/17/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/17/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/17/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/17/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/18/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/18/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/18/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/18/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/18/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/18/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/18/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/18/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/18/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/18/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/18/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/18/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/18/2026 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/18/2026 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/18/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/18/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/18/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/18/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/18/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/18/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/18/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/18/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/18/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/18/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/19/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/19/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/19/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/19/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/19/2026 04:00	3,429.6	0.0	3,429.6	104,200.0	357.4	0.00	0.0	0.0
05/19/2026 05:00	3,580.3	41.6	3,580.3	104,200.0	373.1	0.44	0.2	0.7
05/19/2026 06:00	3,383.4	97.2	3,383.4	104,200.0	352.6	0.44	0.2	0.7
05/19/2026 07:00	3,636.5	109.9	3,636.5	104,200.0	378.9	0.47	0.2	0.8
05/19/2026 08:00	3,398.0	123.1	3,398.0	104,200.0	354.1	0.44	0.2	0.7
05/19/2026 09:00	3,409.1	106.0	3,409.1	104,200.0	355.2	0.44	0.2	0.7
05/19/2026 10:00	3,402.9	104.9	3,402.9	104,200.0	354.6	0.44	0.2	0.7
05/19/2026 11:00	3,443.0	118.2	3,443.0	104,200.0	358.8	0.45	0.2	0.7
05/19/2026 12:00	3,442.6	113.0	3,442.6	104,200.0	358.7	0.44	0.2	0.7
05/19/2026 13:00	3,799.2	108.9	3,799.2	104,200.0	395.9	0.49	0.2	0.8
05/19/2026 14:00	3,451.3	106.2	3,451.3	104,200.0	359.6	0.44	0.2	0.7
05/19/2026 15:00	3,517.0	103.2	3,517.0	104,200.0	366.5	0.45	0.2	0.8
05/19/2026 16:00	3,851.6	106.2	3,851.6	104,200.0	401.3	0.50	0.2	0.8
05/19/2026 17:00	3,646.0	109.0	3,646.0	104,200.0	379.9	0.47	0.2	0.8
05/19/2026 18:00	3,445.0	94.6	3,445.0	104,200.0	359.0	0.44	0.2	0.7
05/19/2026 19:00	3,433.7	90.8	3,433.7	104,200.0	357.8	0.44	0.2	0.7
05/19/2026 20:00	3,411.1	89.4	3,411.1	104,200.0	355.4	0.44	0.2	0.7
05/19/2026 21:00	3,415.6	87.9	3,415.6	104,200.0	355.9	0.44	0.2	0.7
05/19/2026 22:00	3,429.4	84.0	3,429.4	104,200.0	357.3	0.44	0.2	0.7
05/19/2026 23:00	3,425.9	86.4	3,425.9	104,200.0	357.0	0.44	0.2	0.7
Average/Sum#:	3,497.6	94.0	3,497.6	104,200.0	364.5	0.45	0.2	0.7
Minimum:	3,383.4	0.0	3,383.4	104,200.0	352.6	0.44	0.2	0.7
Maximum:	3,851.6	123.1	3,851.6	104,200.0	401.3	0.50	0.2	0.8
%SI	16.67	16.67	16.67	0.00	16.67	20.83	20.83	20.83

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/20/2026 00:00	3,447.2	83.0	3,447.2	104,200.0	359.2	0.44	0.2	0.7
05/20/2026 01:00	3,460.0	80.1	3,460.0	104,200.0	360.5	0.44	0.2	0.7
05/20/2026 02:00	3,423.7	81.0	3,423.7	104,200.0	356.7	0.44	0.2	0.7
05/20/2026 03:00	3,412.7	77.2	3,412.7	104,200.0	355.6	0.44	0.2	0.7
05/20/2026 04:00	3,430.9	72.9	3,430.9	104,200.0	357.5	0.44	0.2	0.7
05/20/2026 05:00	3,438.4	77.9	3,438.4	104,200.0	358.3	0.44	0.2	0.7
05/20/2026 06:00	3,434.1	105.9	3,434.1	104,200.0	357.8	0.44	0.2	0.7
05/20/2026 07:00	3,437.1	107.7	3,437.1	104,200.0	358.1	0.44	0.2	0.7
05/20/2026 08:00	3,433.0	112.9	3,433.0	104,200.0	357.7	0.44	0.2	0.7
05/20/2026 09:00	3,428.1	98.8	3,428.1	104,200.0	357.2	0.44	0.2	0.7
05/20/2026 10:00	3,396.7	103.0	3,396.7	104,200.0	353.9	0.44	0.2	0.7
05/20/2026 11:00	3,417.5	108.5	3,417.5	104,200.0	356.1	0.44	0.2	0.7
05/20/2026 12:00	3,425.9	112.7	3,425.9	104,200.0	357.0	0.44	0.2	0.7
05/20/2026 13:00	3,516.8	109.0	3,516.8	104,200.0	366.5	0.45	0.2	0.8
05/20/2026 14:00	3,421.4	104.2	3,421.4	104,200.0	356.5	0.44	0.2	0.7
05/20/2026 15:00	3,419.8	104.8	3,419.8	104,200.0	356.3	0.44	0.2	0.7
05/20/2026 16:00	3,716.5	105.2	3,716.5	104,200.0	387.3	0.48	0.2	0.8
05/20/2026 17:00	4,040.2	105.9	4,040.2	104,200.0	421.0	0.52	0.3	0.9
05/20/2026 18:00	3,868.0	94.5	3,868.0	104,200.0	403.0	0.50	0.2	0.8
05/20/2026 19:00	4,089.9	96.4	4,089.9	104,200.0	426.2	0.52	0.3	0.9
05/20/2026 20:00	4,142.1	95.7	4,142.1	104,200.0	431.6	0.53	0.3	0.9
05/20/2026 21:00	4,147.5	97.5	4,147.5	104,200.0	432.2	0.53	0.3	0.9
05/20/2026 22:00	4,142.1	94.0	4,142.1	104,200.0	431.6	0.53	0.3	0.9
05/20/2026 23:00	4,151.6	95.2	4,151.6	104,200.0	432.6	0.53	0.3	0.9
Average/Sum#:	3,635.1	96.8	3,635.1	104,200.0	378.8	0.47	0.2	0.8
Minimum:	3,396.7	72.9	3,396.7	104,200.0	353.9	0.44	0.2	0.7
Maximum:	4,151.6	112.9	4,151.6	104,200.0	432.6	0.53	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/21/2026 00:00	3,783.9	94.8	3,783.9	104,200.0	394.3	0.48	0.2	0.8
05/21/2026 01:00	3,984.1	93.0	3,984.1	104,200.0	415.1	0.51	0.3	0.8
05/21/2026 02:00	3,512.0	92.7	3,512.0	104,200.0	366.0	0.45	0.2	0.8
05/21/2026 03:00	3,928.3	91.8	3,928.3	104,200.0	409.3	0.50	0.3	0.8
05/21/2026 04:00	4,161.4	89.5	4,161.4	104,200.0	433.6	0.53	0.3	0.9
05/21/2026 05:00	3,744.3	94.5	3,744.3	104,200.0	390.2	0.48	0.2	0.8
05/21/2026 06:00	3,461.3	110.8	3,461.3	104,200.0	360.7	0.45	0.2	0.7
05/21/2026 07:00	3,461.8	113.3	3,461.8	104,200.0	360.7	0.45	0.2	0.7
05/21/2026 08:00	3,436.8	117.1	3,436.8	104,200.0	358.1	0.44	0.2	0.7
05/21/2026 09:00	3,444.6	112.3	3,444.6	104,200.0	358.9	0.44	0.2	0.7
05/21/2026 10:00	3,450.0	117.1	3,450.0	104,200.0	359.5	0.45	0.2	0.7
05/21/2026 11:00	3,442.0	117.5	3,442.0	104,200.0	358.7	0.45	0.2	0.7
05/21/2026 12:00	3,463.5	114.4	3,463.5	104,200.0	360.9	0.45	0.2	0.7
05/21/2026 13:00	3,452.9	112.9	3,452.9	104,200.0	359.8	0.45	0.2	0.7
05/21/2026 14:00	3,454.0	104.9	3,454.0	104,200.0	359.9	0.44	0.2	0.7
05/21/2026 15:00	3,790.5	104.2	3,790.5	104,200.0	395.0	0.49	0.2	0.8
05/21/2026 16:00	3,638.3	106.9	3,638.3	104,200.0	379.1	0.47	0.2	0.8
05/21/2026 17:00	3,908.5	109.4	3,908.5	104,200.0	407.3	0.50	0.3	0.8
05/21/2026 18:00	3,827.8	98.8	3,827.8	104,200.0	398.9	0.49	0.2	0.8
05/21/2026 19:00	3,510.4	97.0	3,510.4	104,200.0	365.8	0.45	0.2	0.8
05/21/2026 20:00	3,461.9	98.5	3,461.9	104,200.0	360.7	0.45	0.2	0.7
05/21/2026 21:00	3,459.5	94.2	3,459.5	104,200.0	360.5	0.44	0.2	0.7
05/21/2026 22:00	3,454.7	93.4	3,454.7	104,200.0	360.0	0.44	0.2	0.7
05/21/2026 23:00	3,451.1	90.5	3,451.1	104,200.0	359.6	0.44	0.2	0.7
Average/Sum#:	3,611.8	102.9	3,611.8	104,200.0	376.4	0.46	0.2	0.8
Minimum:	3,436.8	89.5	3,436.8	104,200.0	358.1	0.44	0.2	0.7
Maximum:	4,161.4	117.5	4,161.4	104,200.0	433.6	0.53	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/22/2026 00:00	3,444.3	87.3	3,444.3	104,200.0	358.9	0.44	0.2	0.7
05/22/2026 01:00	3,455.6	83.9	3,455.6	104,200.0	360.1	0.44	0.2	0.7
05/22/2026 02:00	3,455.3	85.2	3,455.3	104,200.0	360.0	0.44	0.2	0.7
05/22/2026 03:00	3,462.3	81.6	3,462.3	104,200.0	360.8	0.44	0.2	0.7
05/22/2026 04:00	3,457.3	80.2	3,457.3	104,200.0	360.3	0.44	0.2	0.7
05/22/2026 05:00	3,454.0	83.4	3,454.0	104,200.0	359.9	0.44	0.2	0.7
05/22/2026 06:00	3,452.7	95.1	3,452.7	104,200.0	359.8	0.44	0.2	0.7
05/22/2026 07:00	3,459.0	102.2	3,459.0	104,200.0	360.4	0.45	0.2	0.7
05/22/2026 08:00	3,449.2	106.1	3,449.2	104,200.0	359.4	0.44	0.2	0.7
05/22/2026 09:00	3,436.2	102.4	3,436.2	104,200.0	358.1	0.44	0.2	0.7
05/22/2026 10:00	3,428.9	110.3	3,428.9	104,200.0	357.3	0.44	0.2	0.7
05/22/2026 11:00	3,439.9	113.4	3,439.9	104,200.0	358.4	0.44	0.2	0.7
05/22/2026 12:00	3,449.6	112.5	3,449.6	104,200.0	359.4	0.45	0.2	0.7
05/22/2026 13:00	3,455.5	110.9	3,455.5	104,200.0	360.1	0.45	0.2	0.7
05/22/2026 14:00	3,457.1	101.0	3,457.1	104,200.0	360.2	0.44	0.2	0.7
05/22/2026 15:00	3,449.6	98.0	3,449.6	104,200.0	359.4	0.44	0.2	0.7
05/22/2026 16:00	3,453.6	99.5	3,453.6	104,200.0	359.9	0.44	0.2	0.7
05/22/2026 17:00	3,622.2	102.1	3,622.2	104,200.0	377.4	0.47	0.2	0.8
05/22/2026 18:00	3,770.5	92.8	3,770.5	104,200.0	392.9	0.48	0.2	0.8
05/22/2026 19:00	3,425.1	89.5	3,425.1	104,200.0	356.9	0.44	0.2	0.7
05/22/2026 20:00	3,422.8	86.5	3,422.8	104,200.0	356.7	0.44	0.2	0.7
05/22/2026 21:00	3,423.3	81.4	3,423.3	104,200.0	356.7	0.44	0.2	0.7
05/22/2026 22:00	3,430.9	76.9	3,430.9	104,200.0	357.5	0.44	0.2	0.7
05/22/2026 23:00	3,448.3	74.1	3,448.3	104,200.0	359.3	0.44	0.2	0.7
Average/Sum#:	3,466.8	94.0	3,466.8	104,200.0	361.2	0.44	0.2	0.7
Minimum:	3,422.8	74.1	3,422.8	104,200.0	356.7	0.44	0.2	0.7
Maximum:	3,770.5	113.4	3,770.5	104,200.0	392.9	0.48	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/23/2026 00:00	3,987.1	71.4	3,987.1	104,200.0	415.5	0.51	0.3	0.8
05/23/2026 01:00	3,468.4	65.9	3,468.4	104,200.0	361.4	0.44	0.2	0.7
05/23/2026 02:00	3,399.4	63.2	3,399.4	104,200.0	354.2	0.43	0.2	0.7
05/23/2026 03:00	3,543.7	61.4	3,543.7	104,200.0	369.3	0.45	0.2	0.8
05/23/2026 04:00	4,155.7	59.6	4,155.7	104,200.0	433.0	0.53	0.3	0.9
05/23/2026 05:00	3,172.4	28.7	3,172.4	104,200.0	330.6	0.46	0.2	0.8
05/23/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/23/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/23/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/23/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/23/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/23/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/23/2026 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/23/2026 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/23/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/23/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/23/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/23/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/23/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/23/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/23/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/23/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/23/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/23/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	3,621.1	58.4	3,621.1	104,200.0	377.3	0.47	0.2	0.8
Minimum:	3,172.4	28.7	3,172.4	104,200.0	330.6	0.43	0.2	0.7
Maximum:	4,155.7	71.4	4,155.7	104,200.0	433.0	0.53	0.3	0.9
%SI	75.00	75.00	75.00	0.00	75.00	75.00	75.00	75.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/24/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/24/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/24/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/24/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/24/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/24/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/24/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/24/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/24/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/24/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/24/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/24/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/24/2026 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/24/2026 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/24/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/24/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/24/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/24/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/24/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/24/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/24/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/24/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/24/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/24/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/25/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/25/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/25/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/25/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/25/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/25/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/25/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/25/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/25/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/25/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/25/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/25/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/25/2026 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/25/2026 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/25/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/25/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/25/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/25/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/25/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/25/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/25/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/25/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/25/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/25/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/26/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/26/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/26/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/26/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/26/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/26/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/26/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/26/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/26/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/26/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/26/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/26/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/26/2026 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/26/2026 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/26/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/26/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/26/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/26/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/26/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/26/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/26/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/26/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/26/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/26/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/27/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/27/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/27/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/27/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/27/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/27/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/27/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/27/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/27/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/27/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/27/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/27/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/27/2026 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/27/2026 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/27/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/27/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/27/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/27/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/27/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/27/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/27/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/27/2026 21:00	1,209.6	39.2	1,209.6	104,200.0	126.0	0.00	0.0	0.0
05/27/2026 22:00	3,514.1	52.7	3,514.1	104,200.0	366.2	0.45	0.2	0.8
05/27/2026 23:00	4,128.6	34.5	4,128.6	104,200.0	430.2	0.52	0.3	0.9
Average/Sum#:	2,950.8	42.1	2,950.8	104,200.0	307.5	0.49	0.3	0.9
Minimum:	1,209.6	34.5	1,209.6	104,200.0	126.0	0.45	0.2	0.8
Maximum:	4,128.6	52.7	4,128.6	104,200.0	430.2	0.52	0.3	0.9
%SI	87.50	87.50	87.50	0.00	87.50	91.67	91.67	91.67

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/28/2026 00:00	4,108.0	20.5	4,108.0	104,200.0	428.1	0.51	0.3	0.9
05/28/2026 01:00	3,521.5	16.8	3,521.5	104,200.0	366.9	0.44	0.2	0.7
05/28/2026 02:00	2,967.0	56.4	2,967.0	104,200.0	309.2	0.43	0.2	0.7
05/28/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/28/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/28/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/28/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/28/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/28/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/28/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/28/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/28/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/28/2026 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/28/2026 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/28/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/28/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/28/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/28/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/28/2026 18:00	1,711.3	74.5	1,711.3	104,200.0	178.3	0.00	0.0	0.0
05/28/2026 19:00	3,448.9	71.4	3,448.9	104,200.0	359.4	0.44	0.2	0.7
05/28/2026 20:00	4,120.1	69.0	4,120.1	104,200.0	429.3	0.52	0.3	0.9
05/28/2026 21:00	4,151.2	65.6	4,151.2	104,200.0	432.6	0.53	0.3	0.9
05/28/2026 22:00	4,101.8	64.3	4,101.8	104,200.0	427.4	0.52	0.3	0.9
05/28/2026 23:00	2,953.6	64.0	2,953.6	104,200.0	307.8	0.43	0.2	0.7
Average/Sum#:	3,453.7	55.8	3,453.7	104,200.0	359.9	0.48	0.3	0.8
Minimum:	1,711.3	16.8	1,711.3	104,200.0	178.3	0.43	0.2	0.7
Maximum:	4,151.2	74.5	4,151.2	104,200.0	432.6	0.53	0.3	0.9
%SI	62.50	62.50	62.50	0.00	62.50	66.67	66.67	66.67

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/29/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/29/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/29/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/29/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/29/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/29/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/29/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/29/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/29/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/29/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/29/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/29/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/29/2026 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/29/2026 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/29/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/29/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/29/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/29/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/29/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/29/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/29/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/29/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/29/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/29/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/30/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/30/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/30/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/30/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/30/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/30/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/30/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/30/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/30/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/30/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/30/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/30/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/30/2026 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/30/2026 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/30/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/30/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/30/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/30/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/30/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/30/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/30/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/30/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/30/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/30/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/31/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/31/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/31/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/31/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/31/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/31/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/31/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/31/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/31/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/31/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/31/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/31/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/31/2026 12:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/31/2026 13:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/31/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/31/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/31/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/31/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/31/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/31/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/31/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/31/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/31/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
05/31/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/01/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
06/01/2026 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/01/2026 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/01/2026 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/01/2026 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/01/2026 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/01/2026 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/01/2026 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/01/2026 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/01/2026 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/01/2026 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/01/2026 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/01/2026 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/01/2026 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/01/2026 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/01/2026 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/01/2026 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/01/2026 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/01/2026 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/01/2026 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/01/2026 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/01/2026 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/01/2026 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/01/2026 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,583.3	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/02/2026 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/02/2026 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/02/2026 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/02/2026 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/02/2026 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/02/2026 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/02/2026 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/02/2026 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/02/2026 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/02/2026 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/02/2026 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/02/2026 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/02/2026 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/02/2026 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/02/2026 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/02/2026 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/02/2026 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/02/2026 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/02/2026 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/02/2026 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/02/2026 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/02/2026 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/02/2026 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/02/2026 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/03/2026 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/03/2026 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/03/2026 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/03/2026 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/03/2026 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/03/2026 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/03/2026 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/03/2026 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/03/2026 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/03/2026 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/03/2026 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/03/2026 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/03/2026 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/03/2026 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/03/2026 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/03/2026 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/03/2026 16:00	1,525.9	107.6	1,525.9	104,600.0	159.6	0.00	0.0	0.0
06/03/2026 17:00	3,811.5	112.7	3,811.5	104,600.0	398.7	0.54	0.3	0.9
06/03/2026 18:00	4,153.8	102.3	4,153.8	104,600.0	434.5	0.53	0.3	0.9
06/03/2026 19:00	3,800.0	96.7	3,800.0	104,600.0	397.5	0.49	0.2	0.8
06/03/2026 20:00	3,681.1	96.2	3,681.1	104,600.0	385.0	0.48	0.2	0.8
06/03/2026 21:00	3,989.4	93.4	3,989.4	104,600.0	417.3	0.51	0.3	0.9
06/03/2026 22:00	4,038.7	90.9	4,038.7	104,600.0	422.4	0.52	0.3	0.9
06/03/2026 23:00	3,456.2	88.2	3,456.2	104,600.0	361.5	0.45	0.2	0.7
Average/Sum#:	3,557.1	98.5	3,557.1	104,600.0	372.1	0.50	0.3	0.8
Minimum:	1,525.9	88.2	1,525.9	104,600.0	159.6	0.45	0.2	0.7
Maximum:	4,153.8	112.7	4,153.8	104,600.0	434.5	0.54	0.3	0.9
%SI	66.67	66.67	66.67	0.00	66.67	70.83	70.83	70.83

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/04/2026 00:00	3,442.4	84.8	3,442.4	104,600.0	360.1	0.44	0.2	0.7
06/04/2026 01:00	3,685.6	81.3	3,685.6	104,600.0	385.5	0.47	0.2	0.8
06/04/2026 02:00	3,525.7	79.0	3,525.7	104,600.0	368.8	0.45	0.2	0.8
06/04/2026 03:00	3,480.9	76.2	3,480.9	104,600.0	364.1	0.45	0.2	0.7
06/04/2026 04:00	3,470.1	75.2	3,470.1	104,600.0	363.0	0.45	0.2	0.7
06/04/2026 05:00	3,466.4	78.0	3,466.4	104,600.0	362.6	0.44	0.2	0.7
06/04/2026 06:00	3,459.2	98.8	3,459.2	104,600.0	361.8	0.45	0.2	0.7
06/04/2026 07:00	3,461.9	106.8	3,461.9	104,600.0	362.1	0.45	0.2	0.7
06/04/2026 08:00	3,464.7	112.9	3,464.7	104,600.0	362.4	0.45	0.2	0.7
06/04/2026 09:00	3,444.7	114.1	3,444.7	104,600.0	360.3	0.45	0.2	0.7
06/04/2026 10:00	3,441.9	113.2	3,441.9	104,600.0	360.0	0.45	0.2	0.7
06/04/2026 11:00	3,447.8	109.9	3,447.8	104,600.0	360.6	0.45	0.2	0.7
06/04/2026 12:00	3,454.9	109.5	3,454.9	104,600.0	361.4	0.45	0.2	0.7
06/04/2026 13:00	3,449.1	116.4	3,449.1	104,600.0	360.8	0.45	0.2	0.7
06/04/2026 14:00	3,452.0	110.5	3,452.0	104,600.0	361.1	0.45	0.2	0.7
06/04/2026 15:00	3,449.3	104.4	3,449.3	104,600.0	360.8	0.45	0.2	0.7
06/04/2026 16:00	3,435.0	104.8	3,435.0	104,600.0	359.3	0.44	0.2	0.7
06/04/2026 17:00	3,489.1	113.9	3,489.1	104,600.0	365.0	0.45	0.2	0.8
06/04/2026 18:00	3,419.8	104.1	3,419.8	104,600.0	357.7	0.44	0.2	0.7
06/04/2026 19:00	3,420.2	99.8	3,420.2	104,600.0	357.8	0.44	0.2	0.7
06/04/2026 20:00	3,428.2	96.9	3,428.2	104,600.0	358.6	0.44	0.2	0.7
06/04/2026 21:00	3,477.7	93.6	3,477.7	104,600.0	363.8	0.45	0.2	0.7
06/04/2026 22:00	3,428.0	89.1	3,428.0	104,600.0	358.6	0.44	0.2	0.7
06/04/2026 23:00	3,453.9	88.9	3,453.9	104,600.0	361.3	0.44	0.2	0.7
Average/Sum#:	3,464.5	98.4	3,464.5	104,600.0	362.4	0.45	0.2	0.7
Minimum:	3,419.8	75.2	3,419.8	104,600.0	357.7	0.44	0.2	0.7
Maximum:	3,685.6	116.4	3,685.6	104,600.0	385.5	0.47	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/05/2026 00:00	3,442.9	87.2	3,442.9	104,600.0	360.1	0.44	0.2	0.7
06/05/2026 01:00	3,438.4	85.3	3,438.4	104,600.0	359.7	0.44	0.2	0.7
06/05/2026 02:00	3,434.9	85.3	3,434.9	104,600.0	359.3	0.44	0.2	0.7
06/05/2026 03:00	3,442.8	84.8	3,442.8	104,600.0	360.1	0.44	0.2	0.7
06/05/2026 04:00	3,968.6	82.4	3,968.6	104,600.0	415.1	0.51	0.3	0.8
06/05/2026 05:00	3,854.5	87.8	3,854.5	104,600.0	403.2	0.49	0.2	0.8
06/05/2026 06:00	3,446.8	97.5	3,446.8	104,600.0	360.5	0.45	0.2	0.7
06/05/2026 07:00	3,452.7	102.8	3,452.7	104,600.0	361.2	0.45	0.2	0.7
06/05/2026 08:00	3,450.6	107.2	3,450.6	104,600.0	360.9	0.45	0.2	0.7
06/05/2026 09:00	3,445.1	114.5	3,445.1	104,600.0	360.4	0.45	0.2	0.7
06/05/2026 10:00	3,445.2	117.1	3,445.2	104,600.0	360.4	0.45	0.2	0.7
06/05/2026 11:00	3,459.0	111.3	3,459.0	104,600.0	361.8	0.45	0.2	0.7
06/05/2026 12:00	3,471.4	108.1	3,471.4	104,600.0	363.1	0.45	0.2	0.7
06/05/2026 13:00	3,467.4	110.3	3,467.4	104,600.0	362.7	0.45	0.2	0.7
06/05/2026 14:00	3,461.2	108.3	3,461.2	104,600.0	362.0	0.45	0.2	0.7
06/05/2026 15:00	3,432.8	99.9	3,432.8	104,600.0	359.1	0.44	0.2	0.7
06/05/2026 16:00	3,416.6	100.2	3,416.6	104,600.0	357.4	0.44	0.2	0.7
06/05/2026 17:00	3,638.8	101.5	3,638.8	104,600.0	380.6	0.47	0.2	0.8
06/05/2026 18:00	3,857.7	93.5	3,857.7	104,600.0	403.5	0.50	0.2	0.8
06/05/2026 19:00	3,549.4	95.5	3,549.4	104,600.0	371.3	0.46	0.2	0.8
06/05/2026 20:00	3,412.9	94.5	3,412.9	104,600.0	357.0	0.44	0.2	0.7
06/05/2026 21:00	3,437.9	90.4	3,437.9	104,600.0	359.6	0.44	0.2	0.7
06/05/2026 22:00	3,489.9	87.5	3,489.9	104,600.0	365.0	0.45	0.2	0.7
06/05/2026 23:00	3,497.8	86.2	3,497.8	104,600.0	365.9	0.45	0.2	0.7
Average/Sum#:	3,517.3	97.5	3,517.3	104,600.0	367.9	0.45	0.2	0.7
Minimum:	3,412.9	82.4	3,412.9	104,600.0	357.0	0.44	0.2	0.7
Maximum:	3,968.6	117.1	3,968.6	104,600.0	415.1	0.51	0.3	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/06/2026 00:00	3,433.6	83.1	3,433.6	104,600.0	359.2	0.44	0.2	0.7
06/06/2026 01:00	3,434.0	78.6	3,434.0	104,600.0	359.2	0.44	0.2	0.7
06/06/2026 02:00	3,439.4	76.4	3,439.4	104,600.0	359.8	0.44	0.2	0.7
06/06/2026 03:00	3,459.8	72.9	3,459.8	104,600.0	361.9	0.44	0.2	0.7
06/06/2026 04:00	3,458.9	71.0	3,458.9	104,600.0	361.8	0.44	0.2	0.7
06/06/2026 05:00	3,439.8	71.9	3,439.8	104,600.0	359.8	0.44	0.2	0.7
06/06/2026 06:00	3,438.3	85.6	3,438.3	104,600.0	359.6	0.44	0.2	0.7
06/06/2026 07:00	3,467.5	96.4	3,467.5	104,600.0	362.7	0.45	0.2	0.7
06/06/2026 08:00	3,460.7	85.8	3,460.7	104,600.0	362.0	0.45	0.2	0.7
06/06/2026 09:00	3,460.2	84.4	3,460.2	104,600.0	361.9	0.45	0.2	0.7
06/06/2026 10:00	3,466.9	95.2	3,466.9	104,600.0	362.6	0.45	0.2	0.7
06/06/2026 11:00	3,465.7	89.5	3,465.7	104,600.0	362.5	0.45	0.2	0.7
06/06/2026 12:00	3,460.4	96.8	3,460.4	104,600.0	362.0	0.45	0.2	0.7
06/06/2026 13:00	3,438.3	105.9	3,438.3	104,600.0	359.6	0.45	0.2	0.7
06/06/2026 14:00	3,431.4	109.5	3,431.4	104,600.0	358.9	0.44	0.2	0.7
06/06/2026 15:00	3,424.7	103.8	3,424.7	104,600.0	358.2	0.44	0.2	0.7
06/06/2026 16:00	3,421.7	106.8	3,421.7	104,600.0	357.9	0.44	0.2	0.7
06/06/2026 17:00	3,421.0	110.4	3,421.0	104,600.0	357.8	0.44	0.2	0.7
06/06/2026 18:00	3,418.0	98.0	3,418.0	104,600.0	357.5	0.44	0.2	0.7
06/06/2026 19:00	3,415.2	91.4	3,415.2	104,600.0	357.2	0.44	0.2	0.7
06/06/2026 20:00	3,434.6	87.9	3,434.6	104,600.0	359.3	0.44	0.2	0.7
06/06/2026 21:00	3,444.2	81.3	3,444.2	104,600.0	360.3	0.44	0.2	0.7
06/06/2026 22:00	3,448.3	78.0	3,448.3	104,600.0	360.7	0.44	0.2	0.7
06/06/2026 23:00	3,457.2	74.8	3,457.2	104,600.0	361.6	0.44	0.2	0.7
Average/Sum#:	3,443.3	89.0	3,443.3	104,600.0	360.2	0.44	0.2	0.7
Minimum:	3,415.2	71.0	3,415.2	104,600.0	357.2	0.44	0.2	0.7
Maximum:	3,467.5	110.4	3,467.5	104,600.0	362.7	0.45	0.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/07/2026 00:00	3,449.0	69.7	3,449.0	104,600.0	360.8	0.44	0.2	0.7
06/07/2026 01:00	3,452.8	66.5	3,452.8	104,600.0	361.2	0.44	0.2	0.7
06/07/2026 02:00	3,460.6	65.1	3,460.6	104,600.0	362.0	0.44	0.2	0.7
06/07/2026 03:00	3,472.3	51.6	3,472.3	104,600.0	363.2	0.44	0.2	0.7
06/07/2026 04:00	3,463.2	28.7	3,463.2	104,600.0	362.3	0.44	0.2	0.7
06/07/2026 05:00	3,467.1	23.9	3,467.1	104,600.0	362.7	0.44	0.2	0.7
06/07/2026 06:00	3,461.2	82.9	3,461.2	104,600.0	362.0	0.44	0.2	0.7
06/07/2026 07:00	3,471.5	98.2	3,471.5	104,600.0	363.1	0.45	0.2	0.7
06/07/2026 08:00	3,472.4	107.3	3,472.4	104,600.0	363.2	0.45	0.2	0.7
06/07/2026 09:00	3,472.0	109.9	3,472.0	104,600.0	363.2	0.45	0.2	0.7
06/07/2026 10:00	3,463.8	111.6	3,463.8	104,600.0	362.3	0.45	0.2	0.7
06/07/2026 11:00	3,461.3	110.2	3,461.3	104,600.0	362.1	0.45	0.2	0.7
06/07/2026 12:00	3,443.8	108.5	3,443.8	104,600.0	360.2	0.45	0.2	0.7
06/07/2026 13:00	3,445.9	113.0	3,445.9	104,600.0	360.4	0.45	0.2	0.7
06/07/2026 14:00	3,435.7	113.3	3,435.7	104,600.0	359.4	0.45	0.2	0.7
06/07/2026 15:00	3,428.8	107.6	3,428.8	104,600.0	358.7	0.44	0.2	0.7
06/07/2026 16:00	3,426.1	111.7	3,426.1	104,600.0	358.4	0.44	0.2	0.7
06/07/2026 17:00	3,419.4	113.5	3,419.4	104,600.0	357.7	0.44	0.2	0.7
06/07/2026 18:00	3,418.5	104.3	3,418.5	104,600.0	357.6	0.44	0.2	0.7
06/07/2026 19:00	3,417.1	98.7	3,417.1	104,600.0	357.4	0.44	0.2	0.7
06/07/2026 20:00	3,421.7	93.3	3,421.7	104,600.0	357.9	0.44	0.2	0.7
06/07/2026 21:00	3,417.8	89.9	3,417.8	104,600.0	357.5	0.44	0.2	0.7
06/07/2026 22:00	3,426.8	88.9	3,426.8	104,600.0	358.4	0.44	0.2	0.7
06/07/2026 23:00	3,446.3	84.1	3,446.3	104,600.0	360.5	0.44	0.2	0.7
Average/Sum#:	3,446.5	89.7	3,446.5	104,600.0	360.5	0.44	0.2	0.7
Minimum:	3,417.1	23.9	3,417.1	104,600.0	357.4	0.44	0.2	0.7
Maximum:	3,472.4	113.5	3,472.4	104,600.0	363.2	0.45	0.2	0.7
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/08/2026 00:00	3,454.8	81.2	3,454.8	104,600.0	361.4	0.44	0.2	0.7
06/08/2026 01:00	3,457.7	78.5	3,457.7	104,600.0	361.7	0.44	0.2	0.7
06/08/2026 02:00	3,458.7	75.3	3,458.7	104,600.0	361.8	0.44	0.2	0.7
06/08/2026 03:00	3,460.4	72.3	3,460.4	104,600.0	362.0	0.44	0.2	0.7
06/08/2026 04:00	3,463.7	70.2	3,463.7	104,600.0	362.3	0.44	0.2	0.7
06/08/2026 05:00	3,505.9	76.9	3,505.9	104,600.0	366.7	0.45	0.2	0.7
06/08/2026 06:00	3,441.3	105.7	3,441.3	104,600.0	360.0	0.45	0.2	0.7
06/08/2026 07:00	3,444.6	110.6	3,444.6	104,600.0	360.3	0.45	0.2	0.7
06/08/2026 08:00	3,436.5	109.9	3,436.5	104,600.0	359.5	0.45	0.2	0.7
06/08/2026 09:00	3,444.4	102.0	3,444.4	104,600.0	360.3	0.45	0.2	0.7
06/08/2026 10:00	3,451.7	108.0	3,451.7	104,600.0	361.0	0.45	0.2	0.7
06/08/2026 11:00	3,456.1	112.3	3,456.1	104,600.0	361.5	0.45	0.2	0.7
06/08/2026 12:00	3,443.7	113.4	3,443.7	104,600.0	360.2	0.45	0.2	0.7
06/08/2026 13:00	3,427.5	111.9	3,427.5	104,600.0	358.5	0.44	0.2	0.7
06/08/2026 14:00	3,426.4	110.2	3,426.4	104,600.0	358.4	0.44	0.2	0.7
06/08/2026 15:00	3,425.0	107.0	3,425.0	104,600.0	358.3	0.44	0.2	0.7
06/08/2026 16:00	3,434.0	101.7	3,434.0	104,600.0	359.2	0.44	0.2	0.7
06/08/2026 17:00	3,556.2	104.9	3,556.2	104,600.0	372.0	0.46	0.2	0.8
06/08/2026 18:00	3,839.6	100.3	3,839.6	104,600.0	401.6	0.49	0.2	0.8
06/08/2026 19:00	3,446.3	98.1	3,446.3	104,600.0	360.5	0.44	0.2	0.7
06/08/2026 20:00	3,475.7	96.5	3,475.7	104,600.0	363.6	0.45	0.2	0.7
06/08/2026 21:00	3,669.5	93.8	3,669.5	104,600.0	383.8	0.47	0.2	0.8
06/08/2026 22:00	4,139.9	90.3	4,139.9	104,600.0	433.0	0.53	0.3	0.9
06/08/2026 23:00	3,986.6	88.7	3,986.6	104,600.0	417.0	0.51	0.3	0.9
Average/Sum#:	3,531.1	96.7	3,531.1	104,600.0	369.4	0.45	0.2	0.7
Minimum:	3,425.0	70.2	3,425.0	104,600.0	358.3	0.44	0.2	0.7
Maximum:	4,139.9	113.4	4,139.9	104,600.0	433.0	0.53	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/09/2026 00:00	3,582.2	86.0	3,582.2	104,600.0	374.7	0.46	0.2	0.8
06/09/2026 01:00	3,472.9	82.5	3,472.9	104,600.0	363.3	0.45	0.2	0.7
06/09/2026 02:00	3,471.1	80.6	3,471.1	104,600.0	363.1	0.45	0.2	0.7
06/09/2026 03:00	3,472.3	78.8	3,472.3	104,600.0	363.2	0.45	0.2	0.7
06/09/2026 04:00	3,562.6	78.6	3,562.6	104,600.0	372.6	0.46	0.2	0.8
06/09/2026 05:00	3,709.6	79.4	3,709.6	104,600.0	388.0	0.48	0.2	0.8
06/09/2026 06:00	3,472.5	86.2	3,472.5	104,600.0	363.2	0.45	0.2	0.7
06/09/2026 07:00	3,469.8	113.9	3,469.8	104,600.0	362.9	0.45	0.2	0.8
06/09/2026 08:00	3,472.5	114.6	3,472.5	104,600.0	363.2	0.45	0.2	0.8
06/09/2026 09:00	3,476.0	115.0	3,476.0	104,600.0	363.6	0.45	0.2	0.8
06/09/2026 10:00	3,473.2	116.3	3,473.2	104,600.0	363.3	0.45	0.2	0.8
06/09/2026 11:00	3,461.8	115.1	3,461.8	104,600.0	362.1	0.45	0.2	0.7
06/09/2026 12:00	3,461.2	114.4	3,461.2	104,600.0	362.0	0.45	0.2	0.7
06/09/2026 13:00	3,462.3	117.5	3,462.3	104,600.0	362.2	0.45	0.2	0.7
06/09/2026 14:00	3,456.2	112.9	3,456.2	104,600.0	361.5	0.45	0.2	0.7
06/09/2026 15:00	3,449.3	108.7	3,449.3	104,600.0	360.8	0.45	0.2	0.7
06/09/2026 16:00	3,444.7	112.7	3,444.7	104,600.0	360.3	0.45	0.2	0.7
06/09/2026 17:00	3,560.3	118.9	3,560.3	104,600.0	372.4	0.46	0.2	0.8
06/09/2026 18:00	3,860.4	101.4	3,860.4	104,600.0	403.8	0.50	0.2	0.8
06/09/2026 19:00	4,151.8	98.9	4,151.8	104,600.0	434.3	0.53	0.3	0.9
06/09/2026 20:00	3,903.4	97.2	3,903.4	104,600.0	408.3	0.50	0.3	0.8
06/09/2026 21:00	3,427.2	94.5	3,427.2	104,600.0	358.5	0.44	0.2	0.7
06/09/2026 22:00	3,849.9	90.7	3,849.9	104,600.0	402.7	0.49	0.2	0.8
06/09/2026 23:00	3,591.2	87.3	3,591.2	104,600.0	375.6	0.46	0.2	0.8
Average/Sum#:	3,571.4	100.1	3,571.4	104,600.0	373.6	0.46	0.2	0.8
Minimum:	3,427.2	78.6	3,427.2	104,600.0	358.5	0.44	0.2	0.7
Maximum:	4,151.8	118.9	4,151.8	104,600.0	434.3	0.53	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/10/2026 00:00	3,462.1	85.0	3,462.1	104,600.0	362.1	0.45	0.2	0.7
06/10/2026 01:00	3,475.9	80.8	3,475.9	104,600.0	363.6	0.45	0.2	0.7
06/10/2026 02:00	3,479.0	78.4	3,479.0	104,600.0	363.9	0.45	0.2	0.7
06/10/2026 03:00	3,509.2	77.4	3,509.2	104,600.0	367.1	0.45	0.2	0.8
06/10/2026 04:00	4,073.5	89.3	4,073.5	104,600.0	426.1	0.52	0.3	0.9
06/10/2026 05:00	3,624.8	94.0	3,624.8	104,600.0	379.2	0.47	0.2	0.8
06/10/2026 06:00	3,808.5	205.8	3,849.7	104,600.0	402.7	0.50	0.3	0.8
06/10/2026 07:00	4,392.4	1,355.8	5,748.2	104,600.0	601.3	0.72	0.4	1.2
06/10/2026 08:00	4,323.7	1,470.5	5,794.2	104,600.0	606.1	0.73	0.4	1.2
06/10/2026 09:00	4,279.1	1,543.9	5,823.0	104,600.0	609.1	0.73	0.4	1.2
06/10/2026 10:00	4,315.0	1,471.8	5,786.8	104,600.0	605.3	0.73	0.4	1.2
06/10/2026 11:00	4,362.7	1,423.9	5,786.6	104,600.0	605.3	0.73	0.4	1.2
06/10/2026 12:00	4,337.2	1,463.3	5,800.5	104,600.0	606.7	0.73	0.4	1.2
06/10/2026 13:00	4,314.3	1,491.7	5,806.0	104,600.0	607.3	0.73	0.4	1.2
06/10/2026 14:00	4,300.4	1,508.9	5,809.3	104,600.0	607.7	0.73	0.4	1.2
06/10/2026 15:00	4,289.7	1,526.7	5,816.4	104,600.0	608.4	0.73	0.4	1.2
06/10/2026 16:00	4,284.2	1,548.4	5,832.6	104,600.0	610.1	0.73	0.4	1.2
06/10/2026 17:00	4,284.5	1,553.7	5,838.2	104,600.0	610.7	0.73	0.4	1.2
06/10/2026 18:00	4,275.6	1,531.1	5,806.7	104,600.0	607.4	0.73	0.4	1.2
06/10/2026 19:00	4,239.7	493.1	4,634.2	104,600.0	484.7	0.59	0.3	1.0
06/10/2026 20:00	3,400.7	108.5	3,400.7	104,600.0	355.7	0.44	0.2	0.7
06/10/2026 21:00	3,375.1	107.0	3,375.1	104,600.0	353.0	0.44	0.2	0.7
06/10/2026 22:00	3,376.1	102.2	3,376.1	104,600.0	353.1	0.44	0.2	0.7
06/10/2026 23:00	3,382.5	97.9	3,382.5	104,600.0	353.8	0.44	0.2	0.7
Average/Sum#:	3,956.9	812.9	4,720.5	104,600.0	493.8	0.60	0.3	1.0
Minimum:	3,375.1	77.4	3,375.1	104,600.0	353.0	0.44	0.2	0.7
Maximum:	4,392.4	1,553.7	5,838.2	104,600.0	610.7	0.73	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/11/2026 00:00	3,380.8	95.8	3,380.8	104,600.0	353.6	0.44	0.2	0.7
06/11/2026 01:00	3,383.8	92.4	3,383.8	104,600.0	353.9	0.44	0.2	0.7
06/11/2026 02:00	3,388.9	92.2	3,388.9	104,600.0	354.5	0.44	0.2	0.7
06/11/2026 03:00	3,391.4	98.1	3,391.4	104,600.0	354.7	0.44	0.2	0.7
06/11/2026 04:00	3,396.4	102.4	3,396.4	104,600.0	355.3	0.44	0.2	0.7
06/11/2026 05:00	3,916.3	223.5	3,990.1	104,600.0	417.4	0.52	0.3	0.9
06/11/2026 06:00	4,334.7	707.9	5,042.6	104,600.0	527.5	0.63	0.3	1.1
06/11/2026 07:00	4,287.2	1,522.9	5,810.1	104,600.0	607.7	0.73	0.4	1.2
06/11/2026 08:00	4,338.1	1,421.8	5,759.9	104,600.0	602.5	0.72	0.4	1.2
06/11/2026 09:00	4,349.1	1,410.2	5,759.3	104,600.0	602.4	0.72	0.4	1.2
06/11/2026 10:00	4,315.2	1,469.3	5,784.5	104,600.0	605.1	0.73	0.4	1.2
06/11/2026 11:00	4,311.0	1,524.7	5,835.7	104,600.0	610.4	0.73	0.4	1.2
06/11/2026 12:00	4,297.5	1,547.9	5,845.4	104,600.0	611.4	0.73	0.4	1.2
06/11/2026 13:00	4,274.7	1,585.9	5,860.6	104,600.0	613.0	0.74	0.4	1.2
06/11/2026 14:00	4,253.8	1,609.9	5,863.7	104,600.0	613.3	0.74	0.4	1.2
06/11/2026 15:00	4,238.8	1,623.4	5,862.2	104,600.0	613.2	0.74	0.4	1.2
06/11/2026 16:00	4,236.3	1,634.0	5,870.3	104,600.0	614.0	0.74	0.4	1.2
06/11/2026 17:00	4,227.2	1,644.9	5,872.1	104,600.0	614.2	0.74	0.4	1.2
06/11/2026 18:00	4,222.1	1,617.3	5,839.4	104,600.0	610.8	0.73	0.4	1.2
06/11/2026 19:00	4,197.2	537.7	4,627.4	104,600.0	484.0	0.59	0.3	1.0
06/11/2026 20:00	3,398.7	97.1	3,398.7	104,600.0	355.5	0.44	0.2	0.7
06/11/2026 21:00	3,630.1	91.7	3,630.1	104,600.0	379.7	0.47	0.2	0.8
06/11/2026 22:00	3,714.6	87.1	3,714.6	104,600.0	388.5	0.48	0.2	0.8
06/11/2026 23:00	3,374.3	86.3	3,374.3	104,600.0	353.0	0.43	0.2	0.7
Average/Sum#:	3,952.4	871.9	4,778.4	104,600.0	499.8	0.61	0.3	1.0
Minimum:	3,374.3	86.3	3,374.3	104,600.0	353.0	0.43	0.2	0.7
Maximum:	4,349.1	1,644.9	5,872.1	104,600.0	614.2	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/12/2026 00:00	3,373.3	85.6	3,373.3	104,600.0	352.8	0.43	0.2	0.7
06/12/2026 01:00	3,455.3	86.9	3,455.3	104,600.0	361.4	0.44	0.2	0.7
06/12/2026 02:00	3,414.3	86.1	3,414.3	104,600.0	357.1	0.44	0.2	0.7
06/12/2026 03:00	3,735.8	85.2	3,735.8	104,600.0	390.8	0.48	0.2	0.8
06/12/2026 04:00	3,486.0	83.3	3,486.0	104,600.0	364.6	0.45	0.2	0.7
06/12/2026 05:00	3,591.9	90.8	3,591.9	104,600.0	375.7	0.46	0.2	0.8
06/12/2026 06:00	3,385.5	94.6	3,385.5	104,600.0	354.1	0.44	0.2	0.7
06/12/2026 07:00	3,385.0	102.8	3,385.0	104,600.0	354.1	0.44	0.2	0.7
06/12/2026 08:00	3,376.8	109.7	3,376.8	104,600.0	353.2	0.44	0.2	0.7
06/12/2026 09:00	3,367.6	116.5	3,367.6	104,600.0	352.3	0.44	0.2	0.7
06/12/2026 10:00	3,362.4	114.6	3,362.4	104,600.0	351.7	0.44	0.2	0.7
06/12/2026 11:00	3,434.8	107.0	3,434.8	104,600.0	359.3	0.45	0.2	0.7
06/12/2026 12:00	4,062.9	102.8	4,062.9	104,600.0	425.0	0.52	0.3	0.9
06/12/2026 13:00	4,149.2	103.3	4,149.2	104,600.0	434.0	0.53	0.3	0.9
06/12/2026 14:00	4,182.0	97.8	4,182.0	104,600.0	437.4	0.53	0.3	0.9
06/12/2026 15:00	4,210.1	844.4	4,868.7	104,600.0	509.3	0.63	0.3	1.1
06/12/2026 16:00	4,197.0	500.5	4,607.4	104,600.0	481.9	0.59	0.3	1.0
06/12/2026 17:00	3,705.1	91.1	3,705.1	104,600.0	387.6	0.48	0.2	0.8
06/12/2026 18:00	3,952.9	87.9	3,952.9	104,600.0	413.5	0.51	0.3	0.8
06/12/2026 19:00	4,196.9	91.0	4,199.6	104,600.0	439.3	0.54	0.3	0.9
06/12/2026 20:00	4,258.5	557.7	4,816.2	104,600.0	503.8	0.60	0.3	1.0
06/12/2026 21:00	4,280.3	506.5	4,786.8	104,600.0	500.7	0.60	0.3	1.0
06/12/2026 22:00	4,322.0	441.4	4,763.4	104,600.0	498.3	0.60	0.3	1.0
06/12/2026 23:00	4,300.3	319.9	4,556.2	104,600.0	476.6	0.58	0.3	1.0
Average/Sum#:	3,799.4	204.5	3,917.5	104,600.0	409.8	0.50	0.2	0.8
Minimum:	3,362.4	83.3	3,362.4	104,600.0	351.7	0.43	0.2	0.7
Maximum:	4,322.0	844.4	4,868.7	104,600.0	509.3	0.63	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/13/2026 00:00	3,412.5	59.4	3,412.5	104,600.0	356.9	0.43	0.2	0.7
06/13/2026 01:00	3,391.7	67.2	3,391.7	104,600.0	354.8	0.43	0.2	0.7
06/13/2026 02:00	3,380.6	74.0	3,380.6	104,600.0	353.6	0.43	0.2	0.7
06/13/2026 03:00	3,696.5	73.7	3,696.5	104,600.0	386.7	0.47	0.2	0.8
06/13/2026 04:00	3,860.1	73.9	3,860.1	104,600.0	403.8	0.49	0.2	0.8
06/13/2026 05:00	3,588.7	74.7	3,588.7	104,600.0	375.4	0.46	0.2	0.8
06/13/2026 06:00	3,386.7	85.5	3,386.7	104,600.0	354.2	0.44	0.2	0.7
06/13/2026 07:00	3,387.7	89.6	3,387.7	104,600.0	354.4	0.44	0.2	0.7
06/13/2026 08:00	3,381.7	102.8	3,381.7	104,600.0	353.7	0.44	0.2	0.7
06/13/2026 09:00	3,374.8	103.4	3,374.8	104,600.0	353.0	0.44	0.2	0.7
06/13/2026 10:00	3,370.6	111.3	3,370.6	104,600.0	352.6	0.44	0.2	0.7
06/13/2026 11:00	3,382.2	104.8	3,382.2	104,600.0	353.8	0.44	0.2	0.7
06/13/2026 12:00	3,383.8	102.0	3,383.8	104,600.0	353.9	0.44	0.2	0.7
06/13/2026 13:00	3,382.2	99.0	3,382.2	104,600.0	353.8	0.44	0.2	0.7
06/13/2026 14:00	3,378.9	91.0	3,378.9	104,600.0	353.4	0.44	0.2	0.7
06/13/2026 15:00	3,374.6	83.2	3,374.6	104,600.0	353.0	0.43	0.2	0.7
06/13/2026 16:00	3,765.3	83.4	3,765.3	104,600.0	393.9	0.48	0.2	0.8
06/13/2026 17:00	3,819.6	84.6	3,819.6	104,600.0	399.5	0.49	0.2	0.8
06/13/2026 18:00	4,167.9	173.7	4,207.9	104,600.0	440.1	0.55	0.3	0.9
06/13/2026 19:00	4,289.0	1,750.1	6,039.1	104,600.0	631.7	0.76	0.4	1.3
06/13/2026 20:00	4,296.0	1,334.9	5,630.9	104,600.0	589.0	0.71	0.4	1.2
06/13/2026 21:00	4,310.8	1,358.1	5,668.9	104,600.0	593.0	0.71	0.4	1.2
06/13/2026 22:00	4,349.2	1,775.7	6,124.9	104,600.0	640.7	0.77	0.4	1.3
06/13/2026 23:00	4,374.2	1,732.6	6,106.8	104,600.0	638.8	0.77	0.4	1.3
Average/Sum#:	3,687.7	403.7	4,020.7	104,600.0	420.6	0.51	0.2	0.8
Minimum:	3,370.6	59.4	3,370.6	104,600.0	352.6	0.43	0.2	0.7
Maximum:	4,374.2	1,775.7	6,124.9	104,600.0	640.7	0.77	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/14/2026 00:00	4,394.1	384.2	4,778.3	104,600.0	499.8	0.60	0.3	1.0
06/14/2026 01:00	4,385.5	234.5	4,561.4	104,600.0	477.1	0.58	0.3	1.0
06/14/2026 02:00	3,856.5	69.6	3,856.5	104,600.0	403.4	0.49	0.2	0.8
06/14/2026 03:00	3,394.5	65.4	3,394.5	104,600.0	355.1	0.43	0.2	0.7
06/14/2026 04:00	3,396.0	62.0	3,396.0	104,600.0	355.2	0.43	0.2	0.7
06/14/2026 05:00	3,398.4	61.2	3,398.4	104,600.0	355.5	0.43	0.2	0.7
06/14/2026 06:00	3,396.0	70.0	3,396.0	104,600.0	355.2	0.43	0.2	0.7
06/14/2026 07:00	3,398.3	82.3	3,398.3	104,600.0	355.5	0.44	0.2	0.7
06/14/2026 08:00	3,393.3	87.3	3,393.3	104,600.0	354.9	0.44	0.2	0.7
06/14/2026 09:00	3,387.2	94.5	3,387.2	104,600.0	354.3	0.44	0.2	0.7
06/14/2026 10:00	3,381.0	93.8	3,381.0	104,600.0	353.7	0.44	0.2	0.7
06/14/2026 11:00	3,386.5	89.1	3,386.5	104,600.0	354.2	0.44	0.2	0.7
06/14/2026 12:00	3,384.6	90.0	3,384.6	104,600.0	354.0	0.44	0.2	0.7
06/14/2026 13:00	3,382.6	99.4	3,382.6	104,600.0	353.8	0.44	0.2	0.7
06/14/2026 14:00	3,379.0	91.6	3,379.0	104,600.0	353.4	0.44	0.2	0.7
06/14/2026 15:00	3,370.3	81.8	3,370.3	104,600.0	352.5	0.43	0.2	0.7
06/14/2026 16:00	4,043.6	80.9	4,043.6	104,600.0	423.0	0.52	0.3	0.9
06/14/2026 17:00	3,864.5	83.2	3,864.5	104,600.0	404.2	0.50	0.2	0.8
06/14/2026 18:00	4,090.8	77.9	4,090.8	104,600.0	427.9	0.52	0.3	0.9
06/14/2026 19:00	4,084.9	68.6	4,084.9	104,600.0	427.3	0.52	0.3	0.9
06/14/2026 20:00	3,953.3	57.6	3,953.3	104,600.0	413.5	0.50	0.3	0.8
06/14/2026 21:00	3,886.6	38.7	3,886.6	104,600.0	406.5	0.49	0.2	0.8
06/14/2026 22:00	3,493.4	11.8	3,493.4	104,600.0	365.4	0.44	0.2	0.7
06/14/2026 23:00	3,512.2	24.5	3,512.2	104,600.0	367.4	0.44	0.2	0.7
Average/Sum#:	3,650.5	91.7	3,673.9	104,600.0	384.3	0.47	0.2	0.8
Minimum:	3,370.3	11.8	3,370.3	104,600.0	352.5	0.43	0.2	0.7
Maximum:	4,394.1	384.2	4,778.3	104,600.0	499.8	0.60	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/15/2026 00:00	3,530.6	35.0	3,530.6	104,600.0	369.3	0.45	0.2	0.7
06/15/2026 01:00	3,405.0	30.9	3,405.0	104,600.0	356.2	0.43	0.2	0.7
06/15/2026 02:00	3,377.9	16.3	3,377.9	104,600.0	353.3	0.43	0.2	0.7
06/15/2026 03:00	3,382.8	5.8	3,382.8	104,600.0	353.8	0.43	0.2	0.7
06/15/2026 04:00	3,386.4	4.4	3,386.4	104,600.0	354.2	0.43	0.2	0.7
06/15/2026 05:00	3,387.8	12.7	3,387.8	104,600.0	354.4	0.43	0.2	0.7
06/15/2026 06:00	3,386.0	27.0	3,386.0	104,600.0	354.2	0.43	0.2	0.7
06/15/2026 07:00	3,388.7	0.0	3,388.7	104,600.0	354.5	0.43	0.2	0.7
06/15/2026 08:00	3,382.9	0.2	3,382.9	104,600.0	353.9	0.42	0.2	0.7
06/15/2026 09:00	3,381.9	10.9	3,381.9	104,600.0	353.7	0.43	0.2	0.7
06/15/2026 10:00	3,379.8	15.7	3,379.8	104,600.0	353.5	0.43	0.2	0.7
06/15/2026 11:00	3,385.2	3.2	3,385.2	104,600.0	354.1	0.42	0.2	0.7
06/15/2026 12:00	3,386.0	34.9	3,386.0	104,600.0	354.2	0.43	0.2	0.7
06/15/2026 13:00	3,385.3	50.1	3,385.3	104,600.0	354.1	0.43	0.2	0.7
06/15/2026 14:00	3,736.9	35.3	3,736.9	104,600.0	390.9	0.47	0.2	0.8
06/15/2026 15:00	3,929.8	0.1	3,929.8	104,600.0	411.1	0.49	0.2	0.8
06/15/2026 16:00	3,749.7	0.1	3,749.7	104,600.0	392.2	0.47	0.2	0.8
06/15/2026 17:00	3,875.8	83.1	3,890.8	104,600.0	407.0	0.50	0.2	0.8
06/15/2026 18:00	4,276.3	719.2	4,995.5	104,600.0	522.5	0.63	0.3	1.0
06/15/2026 19:00	4,043.4	175.0	4,134.4	104,600.0	432.5	0.53	0.3	0.9
06/15/2026 20:00	3,395.1	0.0	3,395.1	104,600.0	355.1	0.42	0.2	0.7
06/15/2026 21:00	3,414.5	0.0	3,414.5	104,600.0	357.2	0.43	0.2	0.7
06/15/2026 22:00	3,683.0	0.0	3,683.0	104,600.0	385.2	0.46	0.2	0.8
06/15/2026 23:00	4,329.8	266.3	4,582.8	104,600.0	479.4	0.58	0.3	1.0
Average/Sum#:	3,582.5	63.6	3,627.5	104,600.0	379.4	0.46	0.2	0.8
Minimum:	3,377.9	0.0	3,377.9	104,600.0	353.3	0.42	0.2	0.7
Maximum:	4,329.8	719.2	4,995.5	104,600.0	522.5	0.63	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/16/2026 00:00	4,380.6	236.5	4,617.1	104,600.0	482.9	0.58	0.3	1.0
06/16/2026 01:00	4,406.4	199.7	4,606.1	104,600.0	481.8	0.58	0.3	1.0
06/16/2026 02:00	4,415.6	236.5	4,652.1	104,600.0	486.6	0.59	0.3	1.0
06/16/2026 03:00	4,430.7	265.6	4,696.3	104,600.0	491.2	0.59	0.3	1.0
06/16/2026 04:00	3,544.3	2.0	3,544.3	104,600.0	370.7	0.45	0.2	0.7
06/16/2026 05:00	3,401.2	0.0	3,401.2	104,600.0	355.8	0.43	0.2	0.7
06/16/2026 06:00	3,630.1	0.0	3,630.1	104,600.0	379.7	0.46	0.2	0.8
06/16/2026 07:00	4,459.5	895.0	5,309.8	104,600.0	555.4	0.67	0.3	1.1
06/16/2026 08:00	4,447.3	994.4	5,441.7	104,600.0	569.2	0.68	0.3	1.1
06/16/2026 09:00	4,418.8	1,029.4	5,448.2	104,600.0	569.9	0.68	0.3	1.1
06/16/2026 10:00	4,387.9	1,067.8	5,455.7	104,600.0	570.7	0.68	0.3	1.1
06/16/2026 11:00	4,358.5	1,122.4	5,480.9	104,600.0	573.3	0.69	0.3	1.1
06/16/2026 12:00	4,324.2	1,173.6	5,497.8	104,600.0	575.1	0.69	0.3	1.2
06/16/2026 13:00	4,292.6	1,227.1	5,519.7	104,600.0	577.4	0.69	0.3	1.2
06/16/2026 14:00	4,282.9	1,515.0	5,797.9	104,600.0	606.5	0.73	0.4	1.2
06/16/2026 15:00	4,258.1	1,671.2	5,929.3	104,600.0	620.2	0.74	0.4	1.2
06/16/2026 16:00	4,265.1	1,643.7	5,908.8	104,600.0	618.1	0.74	0.4	1.2
06/16/2026 17:00	4,266.0	692.0	4,958.0	104,600.0	518.6	0.62	0.3	1.0
06/16/2026 18:00	4,288.8	455.0	4,743.8	104,600.0	496.2	0.60	0.3	1.0
06/16/2026 19:00	4,300.2	410.7	4,710.9	104,600.0	492.8	0.59	0.3	1.0
06/16/2026 20:00	4,339.5	342.4	4,681.9	104,600.0	489.7	0.59	0.3	1.0
06/16/2026 21:00	4,369.2	285.1	4,654.3	104,600.0	486.8	0.58	0.3	1.0
06/16/2026 22:00	4,400.8	262.4	4,663.2	104,600.0	487.8	0.59	0.3	1.0
06/16/2026 23:00	4,415.2	237.8	4,653.0	104,600.0	486.7	0.58	0.3	1.0
Average/Sum#:	4,253.5	665.2	4,916.8	104,600.0	514.3	0.62	0.3	1.0
Minimum:	3,401.2	0.0	3,401.2	104,600.0	355.8	0.43	0.2	0.7
Maximum:	4,459.5	1,671.2	5,929.3	104,600.0	620.2	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/17/2026 00:00	4,433.2	208.9	4,642.1	104,600.0	485.6	0.58	0.3	1.0
06/17/2026 01:00	4,439.7	191.2	4,630.9	104,600.0	484.4	0.58	0.3	1.0
06/17/2026 02:00	4,443.7	183.2	4,626.9	104,600.0	484.0	0.58	0.3	1.0
06/17/2026 03:00	4,447.4	183.0	4,630.4	104,600.0	484.3	0.58	0.3	1.0
06/17/2026 04:00	4,447.8	182.8	4,630.6	104,600.0	484.4	0.58	0.3	1.0
06/17/2026 05:00	4,122.5	92.4	4,170.5	104,600.0	436.2	0.53	0.3	0.9
06/17/2026 06:00	3,612.0	0.0	3,612.0	104,600.0	377.8	0.45	0.2	0.8
06/17/2026 07:00	4,425.7	1,185.4	5,551.8	104,600.0	580.7	0.70	0.4	1.2
06/17/2026 08:00	4,408.4	1,329.4	5,737.8	104,600.0	600.2	0.72	0.4	1.2
06/17/2026 09:00	4,383.2	1,373.7	5,756.9	104,600.0	602.2	0.72	0.4	1.2
06/17/2026 10:00	4,353.9	1,434.4	5,788.3	104,600.0	605.5	0.73	0.4	1.2
06/17/2026 11:00	4,339.8	1,489.1	5,828.9	104,600.0	609.7	0.73	0.4	1.2
06/17/2026 12:00	4,315.4	1,536.8	5,852.2	104,600.0	612.1	0.73	0.4	1.2
06/17/2026 13:00	4,286.2	1,579.0	5,865.2	104,600.0	613.5	0.74	0.4	1.2
06/17/2026 14:00	4,264.5	1,607.7	5,872.2	104,600.0	614.2	0.74	0.4	1.2
06/17/2026 15:00	4,257.1	1,614.0	5,871.1	104,600.0	614.1	0.74	0.4	1.2
06/17/2026 16:00	4,255.3	1,614.0	5,869.3	104,600.0	613.9	0.74	0.4	1.2
06/17/2026 17:00	4,274.3	681.4	4,955.7	104,600.0	518.4	0.62	0.3	1.0
06/17/2026 18:00	4,289.5	438.0	4,727.5	104,600.0	494.5	0.59	0.3	1.0
06/17/2026 19:00	4,305.4	389.0	4,694.4	104,600.0	491.0	0.59	0.3	1.0
06/17/2026 20:00	4,347.9	314.6	4,662.5	104,600.0	487.7	0.59	0.3	1.0
06/17/2026 21:00	4,380.1	267.5	4,647.6	104,600.0	486.1	0.58	0.3	1.0
06/17/2026 22:00	4,405.7	233.5	4,639.2	104,600.0	485.3	0.58	0.3	1.0
06/17/2026 23:00	4,421.2	200.3	4,621.5	104,600.0	483.4	0.58	0.3	1.0
Average/Sum#:	4,319.2	763.7	5,078.6	104,600.0	531.2	0.64	0.3	1.1
Minimum:	3,612.0	0.0	3,612.0	104,600.0	377.8	0.45	0.2	0.8
Maximum:	4,447.8	1,614.0	5,872.2	104,600.0	614.2	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/18/2026 00:00	4,437.7	184.1	4,621.8	104,600.0	483.4	0.58	0.3	1.0
06/18/2026 01:00	4,442.5	183.3	4,625.8	104,600.0	483.9	0.58	0.3	1.0
06/18/2026 02:00	4,447.4	182.6	4,630.0	104,600.0	484.3	0.58	0.3	1.0
06/18/2026 03:00	4,452.3	182.9	4,635.2	104,600.0	484.8	0.58	0.3	1.0
06/18/2026 04:00	4,454.9	265.8	4,720.7	104,600.0	493.8	0.59	0.3	1.0
06/18/2026 05:00	4,377.5	407.9	4,691.6	104,600.0	490.7	0.60	0.3	1.0
06/18/2026 06:00	3,404.4	0.0	3,404.4	104,600.0	356.1	0.43	0.2	0.7
06/18/2026 07:00	3,391.6	0.0	3,391.6	104,600.0	354.8	0.43	0.2	0.7
06/18/2026 08:00	3,387.0	0.0	3,387.0	104,600.0	354.3	0.43	0.2	0.7
06/18/2026 09:00	3,384.1	0.0	3,384.1	104,600.0	354.0	0.42	0.2	0.7
06/18/2026 10:00	3,380.8	0.0	3,380.8	104,600.0	353.6	0.42	0.2	0.7
06/18/2026 11:00	3,392.0	0.0	3,392.0	104,600.0	354.8	0.43	0.2	0.7
06/18/2026 12:00	3,393.0	0.1	3,393.0	104,600.0	354.9	0.43	0.2	0.7
06/18/2026 13:00	3,391.8	50.3	3,391.8	104,600.0	354.8	0.43	0.2	0.7
06/18/2026 14:00	3,389.4	19.9	3,389.4	104,600.0	354.5	0.43	0.2	0.7
06/18/2026 15:00	3,389.0	0.1	3,389.0	104,600.0	354.5	0.43	0.2	0.7
06/18/2026 16:00	3,390.2	0.2	3,390.2	104,600.0	354.6	0.43	0.2	0.7
06/18/2026 17:00	3,884.8	126.2	3,920.1	104,600.0	410.0	0.50	0.3	0.8
06/18/2026 18:00	4,357.0	808.1	5,165.1	104,600.0	540.3	0.65	0.3	1.1
06/18/2026 19:00	4,303.3	1,242.9	5,546.2	104,600.0	580.1	0.70	0.3	1.2
06/18/2026 20:00	4,315.2	1,166.9	5,482.1	104,600.0	573.4	0.69	0.3	1.1
06/18/2026 21:00	4,363.3	315.1	4,678.4	104,600.0	489.4	0.59	0.3	1.0
06/18/2026 22:00	4,390.9	338.0	4,728.9	104,600.0	494.6	0.59	0.3	1.0
06/18/2026 23:00	4,405.8	431.2	4,837.0	104,600.0	506.0	0.61	0.3	1.0
Average/Sum#:	3,913.6	246.1	4,149.0	104,600.0	434.0	0.52	0.3	0.9
Minimum:	3,380.8	0.0	3,380.8	104,600.0	353.6	0.42	0.2	0.7
Maximum:	4,454.9	1,242.9	5,546.2	104,600.0	580.1	0.70	0.3	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/19/2026 00:00	4,411.1	453.0	4,864.1	104,600.0	508.8	0.61	0.3	1.0
06/19/2026 01:00	4,422.9	214.4	4,637.3	104,600.0	485.1	0.58	0.3	1.0
06/19/2026 02:00	4,426.7	202.5	4,629.2	104,600.0	484.2	0.58	0.3	1.0
06/19/2026 03:00	4,427.2	194.3	4,621.5	104,600.0	483.4	0.58	0.3	1.0
06/19/2026 04:00	4,434.3	185.6	4,619.9	104,600.0	483.2	0.58	0.3	1.0
06/19/2026 05:00	3,439.6	2.6	3,439.7	104,600.0	359.8	0.46	0.2	0.8
06/19/2026 06:00	1,277.5	0.0	1,277.5	104,600.0	133.6	0.00	0.0	0.0
06/19/2026 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/19/2026 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/19/2026 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/19/2026 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/19/2026 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/19/2026 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/19/2026 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/19/2026 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/19/2026 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/19/2026 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/19/2026 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/19/2026 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/19/2026 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/19/2026 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/19/2026 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/19/2026 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/19/2026 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	3,834.2	178.9	4,012.7	104,600.0	419.7	0.57	0.3	1.0
Minimum:	1,277.5	0.0	1,277.5	104,600.0	133.6	0.46	0.2	0.8
Maximum:	4,434.3	453.0	4,864.1	104,600.0	508.8	0.61	0.3	1.0
%SI	70.83	70.83	70.83	0.00	70.83	75.00	75.00	75.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/20/2026 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/20/2026 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/20/2026 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/20/2026 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/20/2026 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/20/2026 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/20/2026 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/20/2026 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/20/2026 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/20/2026 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/20/2026 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/20/2026 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/20/2026 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/20/2026 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/20/2026 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/20/2026 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/20/2026 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/20/2026 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/20/2026 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/20/2026 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/20/2026 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/20/2026 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/20/2026 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/20/2026 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/21/2026 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/21/2026 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/21/2026 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/21/2026 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/21/2026 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/21/2026 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/21/2026 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/21/2026 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/21/2026 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/21/2026 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/21/2026 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/21/2026 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/21/2026 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/21/2026 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/21/2026 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/21/2026 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/21/2026 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/21/2026 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/21/2026 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/21/2026 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/21/2026 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/21/2026 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/21/2026 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/21/2026 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/22/2026 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/22/2026 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/22/2026 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/22/2026 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/22/2026 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/22/2026 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/22/2026 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/22/2026 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/22/2026 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/22/2026 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/22/2026 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/22/2026 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/22/2026 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/22/2026 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/22/2026 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/22/2026 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/22/2026 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/22/2026 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/22/2026 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/22/2026 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/22/2026 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/22/2026 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/22/2026 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/22/2026 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/23/2026 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/23/2026 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/23/2026 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/23/2026 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/23/2026 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/23/2026 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/23/2026 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/23/2026 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/23/2026 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/23/2026 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/23/2026 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/23/2026 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/23/2026 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/23/2026 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/23/2026 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/23/2026 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/23/2026 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/23/2026 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/23/2026 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/23/2026 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/23/2026 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/23/2026 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/23/2026 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/23/2026 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/24/2026 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/24/2026 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/24/2026 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/24/2026 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/24/2026 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/24/2026 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/24/2026 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/24/2026 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/24/2026 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/24/2026 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/24/2026 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/24/2026 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/24/2026 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/24/2026 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/24/2026 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/24/2026 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/24/2026 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/24/2026 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/24/2026 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/24/2026 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/24/2026 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/24/2026 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/24/2026 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/24/2026 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/25/2026 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/25/2026 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/25/2026 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/25/2026 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/25/2026 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/25/2026 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/25/2026 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/25/2026 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/25/2026 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/25/2026 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/25/2026 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/25/2026 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/25/2026 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/25/2026 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/25/2026 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/25/2026 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/25/2026 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/25/2026 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/25/2026 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/25/2026 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/25/2026 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/25/2026 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/25/2026 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/25/2026 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/26/2026 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/26/2026 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/26/2026 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/26/2026 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/26/2026 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/26/2026 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/26/2026 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/26/2026 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/26/2026 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/26/2026 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/26/2026 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/26/2026 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/26/2026 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/26/2026 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/26/2026 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/26/2026 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/26/2026 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/26/2026 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/26/2026 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/26/2026 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/26/2026 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/26/2026 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/26/2026 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/26/2026 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/27/2026 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/27/2026 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/27/2026 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/27/2026 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/27/2026 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/27/2026 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/27/2026 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/27/2026 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/27/2026 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/27/2026 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/27/2026 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/27/2026 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/27/2026 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/27/2026 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/27/2026 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/27/2026 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/27/2026 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/27/2026 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/27/2026 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/27/2026 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/27/2026 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/27/2026 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/27/2026 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/27/2026 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/28/2026 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/28/2026 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/28/2026 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/28/2026 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/28/2026 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/28/2026 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/28/2026 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/28/2026 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/28/2026 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/28/2026 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/28/2026 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/28/2026 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/28/2026 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/28/2026 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/28/2026 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/28/2026 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/28/2026 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/28/2026 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/28/2026 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/28/2026 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/28/2026 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/28/2026 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/28/2026 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/28/2026 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/29/2026 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/29/2026 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/29/2026 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/29/2026 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/29/2026 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/29/2026 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/29/2026 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/29/2026 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/29/2026 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/29/2026 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/29/2026 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/29/2026 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/29/2026 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/29/2026 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/29/2026 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/29/2026 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/29/2026 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/29/2026 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/29/2026 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/29/2026 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/29/2026 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/29/2026 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/29/2026 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/29/2026 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/30/2026 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/30/2026 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/30/2026 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/30/2026 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/30/2026 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/30/2026 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/30/2026 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/30/2026 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/30/2026 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/30/2026 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/30/2026 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/30/2026 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/30/2026 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/30/2026 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/30/2026 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/30/2026 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/30/2026 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/30/2026 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/30/2026 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/30/2026 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/30/2026 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/30/2026 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/30/2026 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
06/30/2026 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/01/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/01/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/01/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/01/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/01/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/01/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/01/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/01/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/01/2026 08:00	1,489.5	46.3	1,489.5	104,500.0	155.7	0.0	0.0	0.0
04/01/2026 09:00	3,783.1	50.0	3,783.1	104,500.0	395.3	0.5	0.2	0.8
04/01/2026 10:00	3,806.5	51.2	3,806.5	104,500.0	397.8	0.5	0.2	0.8
04/01/2026 11:00	3,818.7	58.3	3,818.7	104,500.0	399.1	0.5	0.2	0.8
04/01/2026 12:00	3,775.8	63.9	3,775.8	104,500.0	394.6	0.5	0.2	0.8
04/01/2026 13:00	3,484.3	69.2	3,484.3	104,500.0	364.1	0.5	0.2	0.8
04/01/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/01/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/01/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/01/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/01/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/01/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/01/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/01/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/01/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/01/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,359.7	56.5	3,359.7	104,500.0	351.1	0.5	0.2	0.8
Minimum:	1,489.5	46.3	1,489.5	104,500.0	155.7	0.5	0.2	0.8
Maximum:	3,818.7	69.2	3,818.7	104,500.0	399.1	0.5	0.2	0.8
%SI	75.00	75.00	75.00	0.00	75.00	79.17	79.17	79.17

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/02/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/02/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/02/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/02/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/02/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/02/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/02/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/02/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/02/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/02/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/02/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/02/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/02/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/02/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/02/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/02/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/02/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/02/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/02/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/02/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/02/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/02/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/02/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/02/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/03/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/03/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/03/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/03/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/03/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/03/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/03/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/03/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/03/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/03/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/03/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/03/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/03/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/03/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/03/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/03/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/03/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/03/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/03/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/03/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/03/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/03/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/03/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/03/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/04/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/04/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/04/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/04/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/04/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/04/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/04/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/04/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/04/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/04/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/04/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/04/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/04/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/04/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/04/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/04/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/04/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/04/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/04/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/04/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/04/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/04/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/04/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/04/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/05/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/05/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/05/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/05/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/05/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/05/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/05/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/05/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/05/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/05/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/05/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/05/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/05/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/05/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/05/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/05/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/05/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/05/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/05/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/05/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/05/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/05/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/05/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/05/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/06/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/06/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/06/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/06/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/06/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/06/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/06/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/06/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/06/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/06/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/06/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/06/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/06/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/06/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/06/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/06/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/06/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/06/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/06/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/06/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/06/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/06/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/06/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/06/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/07/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/07/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/07/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/07/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/07/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/07/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/07/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/07/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/07/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/07/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/07/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/07/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/07/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/07/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/07/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/07/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/07/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/07/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/07/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/07/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/07/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/07/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/07/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/07/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/08/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/08/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/08/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/08/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/08/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/08/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/08/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/08/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/08/2026 08:00	1,724.0	76.3	1,724.0	104,500.0	180.2	0.0	0.0	0.0
04/08/2026 09:00	3,797.6	82.1	3,797.6	104,500.0	396.8	0.0	0.0	0.0
04/08/2026 10:00	3,822.8	84.3	3,822.8	104,500.0	399.5	0.5	0.2	0.8
04/08/2026 11:00	4,685.5	99.2	4,685.5	104,500.0	489.6	0.6	0.3	1.0
04/08/2026 12:00	4,694.6	116.9	4,694.6	104,500.0	490.6	0.6	0.3	1.0
04/08/2026 13:00	4,674.2	137.8	4,674.2	104,500.0	488.5	0.6	0.3	1.0
04/08/2026 14:00	4,657.1	99.4	4,657.1	104,500.0	486.7	0.6	0.3	1.0
04/08/2026 15:00	4,506.3	118.6	4,506.3	104,500.0	470.9	0.6	0.3	1.0
04/08/2026 16:00	1,731.0	119.9	1,731.0	104,500.0	180.9	0.0	0.0	0.0
04/08/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/08/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/08/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/08/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/08/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/08/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/08/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,810.3	103.8	3,810.3	104,500.0	398.2	0.6	0.3	1.0
Minimum:	1,724.0	76.3	1,724.0	104,500.0	180.2	0.5	0.2	0.8
Maximum:	4,694.6	137.8	4,694.6	104,500.0	490.6	0.6	0.3	1.0
%SI	62.50	62.50	62.50	0.00	62.50	75.00	75.00	75.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/09/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/09/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/09/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/09/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/09/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/09/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/09/2026 06:00	1,797.1	85.3	1,797.1	104,500.0	187.8	0.0	0.0	0.0
04/09/2026 07:00	3,815.5	91.8	3,815.5	104,500.0	398.7	0.5	0.2	0.8
04/09/2026 08:00	3,786.7	100.2	3,786.7	104,500.0	395.7	0.5	0.2	0.8
04/09/2026 09:00	4,156.3	101.6	4,156.3	104,500.0	434.3	0.5	0.3	0.9
04/09/2026 10:00	3,905.2	103.0	3,905.2	104,500.0	408.1	0.5	0.3	0.8
04/09/2026 11:00	3,886.7	112.6	3,886.7	104,500.0	406.2	0.5	0.3	0.8
04/09/2026 12:00	2,558.8	118.6	2,558.8	104,500.0	267.4	0.5	0.2	0.8
04/09/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/09/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/09/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/09/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/09/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/09/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/09/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/09/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/09/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/09/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/09/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,415.2	101.9	3,415.2	104,500.0	356.9	0.5	0.3	0.8
Minimum:	1,797.1	85.3	1,797.1	104,500.0	187.8	0.5	0.2	0.8
Maximum:	4,156.3	118.6	4,156.3	104,500.0	434.3	0.5	0.3	0.9
%SI	70.83	70.83	70.83	0.00	70.83	75.00	75.00	75.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/10/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/10/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/10/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/10/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/10/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/10/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/10/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/10/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/10/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/10/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/10/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/10/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/10/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/10/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/10/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/10/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/10/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/10/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/10/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/10/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/10/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/10/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/10/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/10/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/11/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/11/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/11/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/11/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/11/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/11/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/11/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/11/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/11/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/11/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/11/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/11/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/11/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/11/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/11/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/11/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/11/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/11/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/11/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/11/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/11/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/11/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/11/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/11/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/12/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/12/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/12/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/12/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/12/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/12/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/12/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/12/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/12/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/12/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/12/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/12/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/12/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/12/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/12/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/12/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/12/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/12/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/12/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/12/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/12/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/12/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/12/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/12/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/13/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/13/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/13/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/13/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/13/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/13/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/13/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/13/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/13/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/13/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/13/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/13/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/13/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/13/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/13/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/13/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/13/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/13/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/13/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/13/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/13/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/13/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/13/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/13/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/14/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/14/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/14/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/14/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/14/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/14/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/14/2026 06:00	1,848.9	90.3	1,848.9	104,500.0	193.2	0.0	0.0	0.0
04/14/2026 07:00	3,882.5	101.7	3,882.5	104,500.0	405.7	0.5	0.2	0.8
04/14/2026 08:00	3,871.8	98.6	3,871.8	104,500.0	404.6	0.5	0.2	0.8
04/14/2026 09:00	4,662.2	77.1	4,662.2	104,500.0	487.2	0.6	0.3	1.0
04/14/2026 10:00	3,892.3	88.1	3,892.3	104,500.0	406.7	0.5	0.2	0.8
04/14/2026 11:00	4,466.6	87.0	4,466.6	104,500.0	466.8	0.6	0.3	1.0
04/14/2026 12:00	4,735.2	1,433.5	5,982.3	104,500.0	625.2	0.8	0.4	1.3
04/14/2026 13:00	4,260.7	162.8	4,277.0	104,500.0	446.9	0.6	0.3	0.9
04/14/2026 14:00	2,771.4	113.0	2,771.4	104,500.0	289.6	0.5	0.2	0.8
04/14/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/14/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/14/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/14/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/14/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/14/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/14/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/14/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/14/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,821.3	250.2	3,961.7	104,500.0	414.0	0.6	0.3	0.9
Minimum:	1,848.9	77.1	1,848.9	104,500.0	193.2	0.5	0.2	0.8
Maximum:	4,735.2	1,433.5	5,982.3	104,500.0	625.2	0.8	0.4	1.3
%SI	62.50	62.50	62.50	0.00	62.50	66.67	66.67	66.67

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/15/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/15/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/15/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/15/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/15/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/15/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/15/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/15/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/15/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/15/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/15/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/15/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/15/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/15/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/15/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/15/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/15/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/15/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/15/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/15/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/15/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/15/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/15/2026 22:00	2,392.9	72.3	2,392.9	104,500.0	250.1	0.0	0.0	0.0
04/15/2026 23:00	4,310.3	72.8	4,310.3	104,500.0	450.4	0.6	0.3	0.9
Average/Sum#:	3,351.6	72.6	3,351.6	104,500.0	350.3	0.6	0.3	0.9
Minimum:	2,392.9	72.3	2,392.9	104,500.0	250.1	0.6	0.3	0.9
Maximum:	4,310.3	72.8	4,310.3	104,500.0	450.4	0.6	0.3	0.9
%SI	91.67	91.67	91.67	0.00	91.67	95.83	95.83	95.83

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/16/2026 00:00	4,827.8	73.0	4,827.8	104,500.0	504.5	0.6	0.3	1.0
04/16/2026 01:00	4,814.9	73.0	4,814.9	104,500.0	503.2	0.6	0.3	1.0
04/16/2026 02:00	4,742.6	75.4	4,742.6	104,500.0	495.6	0.6	0.3	1.0
04/16/2026 03:00	4,850.4	73.3	4,850.4	104,500.0	506.9	0.6	0.3	1.0
04/16/2026 04:00	4,893.4	70.4	4,893.4	104,500.0	511.4	0.6	0.3	1.0
04/16/2026 05:00	4,922.0	66.4	4,922.0	104,500.0	514.3	0.6	0.3	1.0
04/16/2026 06:00	4,682.8	69.8	4,682.8	104,500.0	489.4	0.6	0.3	1.0
04/16/2026 07:00	4,488.1	75.5	4,488.1	104,500.0	469.0	0.6	0.3	1.0
04/16/2026 08:00	4,620.5	68.2	4,620.5	104,500.0	482.8	0.6	0.3	1.0
04/16/2026 09:00	4,643.5	71.1	4,643.5	104,500.0	485.2	0.6	0.3	1.0
04/16/2026 10:00	4,655.6	85.7	4,655.6	104,500.0	486.5	0.6	0.3	1.0
04/16/2026 11:00	4,667.5	80.5	4,667.5	104,500.0	487.8	0.6	0.3	1.0
04/16/2026 12:00	4,676.0	103.5	4,676.0	104,500.0	488.6	0.6	0.3	1.0
04/16/2026 13:00	4,688.7	99.6	4,688.7	104,500.0	490.0	0.6	0.3	1.0
04/16/2026 14:00	4,343.4	96.7	4,343.4	104,500.0	453.9	0.6	0.3	0.9
04/16/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/16/2026 16:00	1,759.8	89.6	1,759.8	104,500.0	183.9	0.0	0.0	0.0
04/16/2026 17:00	3,825.9	92.1	3,825.9	104,500.0	399.8	0.5	0.2	0.8
04/16/2026 18:00	3,765.6	86.8	3,765.6	104,500.0	393.5	0.5	0.2	0.8
04/16/2026 19:00	3,764.5	84.0	3,764.5	104,500.0	393.4	0.5	0.2	0.8
04/16/2026 20:00	3,761.5	79.2	3,761.5	104,500.0	393.1	0.5	0.2	0.8
04/16/2026 21:00	3,767.8	74.7	3,767.8	104,500.0	393.7	0.5	0.2	0.8
04/16/2026 22:00	3,747.7	72.9	3,747.7	104,500.0	391.6	0.5	0.2	0.8
04/16/2026 23:00	3,621.7	73.3	3,621.7	104,500.0	378.5	0.5	0.2	0.8
Average/Sum#:	4,284.0	79.8	4,284.0	104,500.0	447.7	0.6	0.3	0.9
Minimum:	1,759.8	66.4	1,759.8	104,500.0	183.9	0.5	0.2	0.8
Maximum:	4,922.0	103.5	4,922.0	104,500.0	514.3	0.6	0.3	1.0
%SI	4.17	4.17	4.17	0.00	4.17	8.33	8.33	8.33

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/17/2026 00:00	4,373.2	71.9	4,373.2	104,500.0	457.0	0.6	0.3	0.9
04/17/2026 01:00	4,629.1	64.2	4,629.1	104,500.0	483.7	0.6	0.3	1.0
04/17/2026 02:00	4,635.7	61.8	4,635.7	104,500.0	484.4	0.6	0.3	1.0
04/17/2026 03:00	4,654.6	56.7	4,654.6	104,500.0	486.4	0.6	0.3	1.0
04/17/2026 04:00	4,655.0	49.7	4,655.0	104,500.0	486.4	0.6	0.3	1.0
04/17/2026 05:00	4,665.7	50.6	4,665.7	104,500.0	487.6	0.6	0.3	1.0
04/17/2026 06:00	4,666.7	82.6	4,666.7	104,500.0	487.7	0.6	0.3	1.0
04/17/2026 07:00	4,669.8	102.2	4,669.8	104,500.0	488.0	0.6	0.3	1.0
04/17/2026 08:00	4,668.5	87.9	4,668.5	104,500.0	487.9	0.6	0.3	1.0
04/17/2026 09:00	4,672.0	81.1	4,672.0	104,500.0	488.2	0.6	0.3	1.0
04/17/2026 10:00	4,688.1	97.5	4,688.1	104,500.0	489.9	0.6	0.3	1.0
04/17/2026 11:00	4,683.7	89.8	4,683.7	104,500.0	489.4	0.6	0.3	1.0
04/17/2026 12:00	4,659.7	124.5	4,659.7	104,500.0	486.9	0.6	0.3	1.0
04/17/2026 13:00	4,637.4	129.3	4,637.4	104,500.0	484.6	0.6	0.3	1.0
04/17/2026 14:00	4,620.4	111.7	4,620.4	104,500.0	482.8	0.6	0.3	1.0
04/17/2026 15:00	4,637.4	110.0	4,637.4	104,500.0	484.6	0.6	0.3	1.0
04/17/2026 16:00	4,663.5	111.4	4,663.5	104,500.0	487.3	0.6	0.3	1.0
04/17/2026 17:00	4,657.9	111.5	4,657.9	104,500.0	486.8	0.6	0.3	1.0
04/17/2026 18:00	4,661.3	99.5	4,661.3	104,500.0	487.1	0.6	0.3	1.0
04/17/2026 19:00	4,664.5	97.8	4,664.5	104,500.0	487.4	0.6	0.3	1.0
04/17/2026 20:00	4,663.6	98.2	4,663.6	104,500.0	487.3	0.6	0.3	1.0
04/17/2026 21:00	4,665.8	95.3	4,665.8	104,500.0	487.6	0.6	0.3	1.0
04/17/2026 22:00	4,676.8	93.7	4,676.8	104,500.0	488.7	0.6	0.3	1.0
04/17/2026 23:00	4,683.2	89.2	4,683.2	104,500.0	489.4	0.6	0.3	1.0
Average/Sum#:	4,648.1	90.3	4,648.1	104,500.0	485.7	0.6	0.3	1.0
Minimum:	4,373.2	49.7	4,373.2	104,500.0	457.0	0.6	0.3	0.9
Maximum:	4,688.1	129.3	4,688.1	104,500.0	489.9	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/18/2026 00:00	4,681.8	83.9	4,681.8	104,500.0	489.2	0.6	0.3	1.0
04/18/2026 01:00	4,681.9	84.1	4,681.9	104,500.0	489.3	0.6	0.3	1.0
04/18/2026 02:00	4,678.0	82.2	4,678.0	104,500.0	488.9	0.6	0.3	1.0
04/18/2026 03:00	4,663.4	80.9	4,663.4	104,500.0	487.3	0.6	0.3	1.0
04/18/2026 04:00	4,658.0	77.1	4,658.0	104,500.0	486.8	0.6	0.3	1.0
04/18/2026 05:00	4,657.0	75.3	4,657.0	104,500.0	486.7	0.6	0.3	1.0
04/18/2026 06:00	4,661.4	101.3	4,661.4	104,500.0	487.1	0.6	0.3	1.0
04/18/2026 07:00	4,172.4	103.3	4,172.4	104,500.0	436.0	0.5	0.3	0.9
04/18/2026 08:00	3,613.0	102.5	3,613.0	104,500.0	377.6	0.5	0.2	0.8
04/18/2026 09:00	4,234.0	87.8	4,234.0	104,500.0	442.5	0.5	0.3	0.9
04/18/2026 10:00	4,675.7	106.9	4,675.7	104,500.0	488.6	0.6	0.3	1.0
04/18/2026 11:00	4,660.3	107.3	4,660.3	104,500.0	487.0	0.6	0.3	1.0
04/18/2026 12:00	4,680.2	135.1	4,680.2	104,500.0	489.1	0.6	0.3	1.0
04/18/2026 13:00	4,683.8	139.0	4,683.8	104,500.0	489.5	0.6	0.3	1.0
04/18/2026 14:00	4,687.1	123.6	4,687.1	104,500.0	489.8	0.6	0.3	1.0
04/18/2026 15:00	4,691.2	118.1	4,691.2	104,500.0	490.2	0.6	0.3	1.0
04/18/2026 16:00	4,685.1	119.8	4,685.1	104,500.0	489.6	0.6	0.3	1.0
04/18/2026 17:00	4,683.8	120.2	4,683.8	104,500.0	489.5	0.6	0.3	1.0
04/18/2026 18:00	4,680.6	111.9	4,680.6	104,500.0	489.1	0.6	0.3	1.0
04/18/2026 19:00	4,675.7	108.1	4,675.7	104,500.0	488.6	0.6	0.3	1.0
04/18/2026 20:00	4,676.5	98.4	4,676.5	104,500.0	488.7	0.6	0.3	1.0
04/18/2026 21:00	4,682.5	100.1	4,682.5	104,500.0	489.3	0.6	0.3	1.0
04/18/2026 22:00	4,689.7	96.3	4,689.7	104,500.0	490.1	0.6	0.3	1.0
04/18/2026 23:00	4,684.1	95.3	4,684.1	104,500.0	489.5	0.6	0.3	1.0
Average/Sum#:	4,593.2	102.4	4,593.2	104,500.0	480.0	0.6	0.3	1.0
Minimum:	3,613.0	75.3	3,613.0	104,500.0	377.6	0.5	0.2	0.8
Maximum:	4,691.2	139.0	4,691.2	104,500.0	490.2	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/19/2026 00:00	4,679.0	93.0	4,679.0	104,500.0	489.0	0.6	0.3	1.0
04/19/2026 01:00	4,688.8	90.6	4,688.8	104,500.0	490.0	0.6	0.3	1.0
04/19/2026 02:00	4,681.5	92.0	4,681.5	104,500.0	489.2	0.6	0.3	1.0
04/19/2026 03:00	4,681.5	89.0	4,681.5	104,500.0	489.2	0.6	0.3	1.0
04/19/2026 04:00	4,691.5	84.8	4,691.5	104,500.0	490.3	0.6	0.3	1.0
04/19/2026 05:00	4,677.7	91.4	4,677.7	104,500.0	488.8	0.6	0.3	1.0
04/19/2026 06:00	4,687.7	96.5	4,687.7	104,500.0	489.9	0.6	0.3	1.0
04/19/2026 07:00	4,696.7	128.5	4,696.7	104,500.0	490.8	0.6	0.3	1.0
04/19/2026 08:00	4,681.9	115.0	4,681.9	104,500.0	489.3	0.6	0.3	1.0
04/19/2026 09:00	4,688.4	105.3	4,688.4	104,500.0	489.9	0.6	0.3	1.0
04/19/2026 10:00	4,693.4	113.8	4,693.4	104,500.0	490.5	0.6	0.3	1.0
04/19/2026 11:00	4,698.1	115.9	4,698.1	104,500.0	491.0	0.6	0.3	1.0
04/19/2026 12:00	4,696.1	133.2	4,696.1	104,500.0	490.7	0.6	0.3	1.0
04/19/2026 13:00	4,699.0	132.5	4,699.0	104,500.0	491.0	0.6	0.3	1.0
04/19/2026 14:00	4,694.8	125.1	4,694.8	104,500.0	490.6	0.6	0.3	1.0
04/19/2026 15:00	4,699.7	121.2	4,699.7	104,500.0	491.1	0.6	0.3	1.0
04/19/2026 16:00	4,702.8	121.0	4,702.8	104,500.0	491.4	0.6	0.3	1.0
04/19/2026 17:00	4,688.4	117.1	4,688.4	104,500.0	489.9	0.6	0.3	1.0
04/19/2026 18:00	4,679.0	114.4	4,679.0	104,500.0	489.0	0.6	0.3	1.0
04/19/2026 19:00	4,676.9	109.8	4,676.9	104,500.0	488.7	0.6	0.3	1.0
04/19/2026 20:00	4,683.0	100.8	4,683.0	104,500.0	489.4	0.6	0.3	1.0
04/19/2026 21:00	4,682.6	103.3	4,682.6	104,500.0	489.3	0.6	0.3	1.0
04/19/2026 22:00	4,679.9	103.4	4,679.9	104,500.0	489.0	0.6	0.3	1.0
04/19/2026 23:00	4,680.8	97.3	4,680.8	104,500.0	489.1	0.6	0.3	1.0
Average/Sum#:	4,687.9	108.1	4,687.9	104,500.0	489.9	0.6	0.3	1.0
Minimum:	4,676.9	84.8	4,676.9	104,500.0	488.7	0.6	0.3	1.0
Maximum:	4,702.8	133.2	4,702.8	104,500.0	491.4	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/20/2026 00:00	4,681.7	94.4	4,681.7	104,500.0	489.2	0.6	0.3	1.0
04/20/2026 01:00	4,671.1	95.3	4,671.1	104,500.0	488.1	0.6	0.3	1.0
04/20/2026 02:00	4,666.5	89.7	4,666.5	104,500.0	487.6	0.6	0.3	1.0
04/20/2026 03:00	4,662.8	81.0	4,662.8	104,500.0	487.3	0.6	0.3	1.0
04/20/2026 04:00	4,665.3	79.1	4,665.3	104,500.0	487.5	0.6	0.3	1.0
04/20/2026 05:00	4,677.5	71.7	4,677.5	104,500.0	488.8	0.6	0.3	1.0
04/20/2026 06:00	4,677.1	112.8	4,677.1	104,500.0	488.8	0.6	0.3	1.0
04/20/2026 07:00	4,672.3	120.9	4,672.3	104,500.0	488.3	0.6	0.3	1.0
04/20/2026 08:00	4,690.9	113.5	4,690.9	104,500.0	490.2	0.6	0.3	1.0
04/20/2026 09:00	4,698.7	93.3	4,698.7	104,500.0	491.0	0.6	0.3	1.0
04/20/2026 10:00	4,679.5	93.5	4,679.5	104,500.0	489.0	0.6	0.3	1.0
04/20/2026 11:00	4,654.4	109.7	4,654.4	104,500.0	486.4	0.6	0.3	1.0
04/20/2026 12:00	4,648.1	111.1	4,648.1	104,500.0	485.7	0.6	0.3	1.0
04/20/2026 13:00	4,674.7	98.9	4,674.7	104,500.0	488.5	0.6	0.3	1.0
04/20/2026 14:00	4,692.5	95.5	4,692.5	104,500.0	490.4	0.6	0.3	1.0
04/20/2026 15:00	4,670.4	87.1	4,670.4	104,500.0	488.1	0.6	0.3	1.0
04/20/2026 16:00	4,665.7	86.2	4,665.7	104,500.0	487.6	0.6	0.3	1.0
04/20/2026 17:00	4,665.8	86.0	4,665.8	104,500.0	487.6	0.6	0.3	1.0
04/20/2026 18:00	4,665.8	83.3	4,665.8	104,500.0	487.6	0.6	0.3	1.0
04/20/2026 19:00	4,673.6	75.5	4,673.6	104,500.0	488.4	0.6	0.3	1.0
04/20/2026 20:00	4,662.1	72.7	4,662.1	104,500.0	487.2	0.6	0.3	1.0
04/20/2026 21:00	4,668.7	68.9	4,668.7	104,500.0	487.9	0.6	0.3	1.0
04/20/2026 22:00	4,290.1	70.3	4,290.1	104,500.0	448.3	0.6	0.3	1.0
04/20/2026 23:00	695.8	71.8	695.8	104,500.0	72.7	0.0	0.0	0.0
Average/Sum#:	4,490.5	90.1	4,490.5	104,500.0	469.3	0.6	0.3	1.0
Minimum:	695.8	68.9	695.8	104,500.0	72.7	0.6	0.3	1.0
Maximum:	4,698.7	120.9	4,698.7	104,500.0	491.0	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	4.17	4.17	4.17

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/21/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/21/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/21/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/21/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/21/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/21/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/21/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/21/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/21/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/21/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/21/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/21/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/21/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/21/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/21/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/21/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/21/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/21/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/21/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/21/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/21/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/21/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/21/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/21/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/22/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/22/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/22/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/22/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/22/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/22/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/22/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/22/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/22/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/22/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/22/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/22/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/22/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/22/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/22/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/22/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/22/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/22/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/22/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/22/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/22/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/22/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/22/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/22/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/23/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/23/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/23/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/23/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/23/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/23/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/23/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/23/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/23/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/23/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/23/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/23/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/23/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/23/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/23/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/23/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/23/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/23/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/23/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/23/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/23/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/23/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/23/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/23/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/24/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/24/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/24/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/24/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/24/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/24/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/24/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/24/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/24/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/24/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/24/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/24/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/24/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/24/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/24/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/24/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/24/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/24/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/24/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/24/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/24/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/24/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/24/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/24/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/25/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/25/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/25/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/25/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/25/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/25/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/25/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/25/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/25/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/25/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/25/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/25/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/25/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/25/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/25/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/25/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/25/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/25/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/25/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/25/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/25/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/25/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/25/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/25/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/26/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/26/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/26/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/26/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/26/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/26/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/26/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/26/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/26/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/26/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/26/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/26/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/26/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/26/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/26/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/26/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/26/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/26/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/26/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/26/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/26/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/26/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/26/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/26/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/27/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/27/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/27/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/27/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/27/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/27/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/27/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/27/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/27/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/27/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/27/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/27/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/27/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/27/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/27/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/27/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/27/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/27/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/27/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/27/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/27/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/27/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/27/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/27/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/28/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/28/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/28/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/28/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/28/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/28/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/28/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/28/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/28/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/28/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/28/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/28/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/28/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/28/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/28/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/28/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/28/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/28/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/28/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/28/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/28/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/28/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/28/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/28/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/29/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/29/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/29/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/29/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/29/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/29/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/29/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/29/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/29/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/29/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/29/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/29/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/29/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/29/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/29/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/29/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/29/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/29/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/29/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/29/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/29/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/29/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/29/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/29/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
04/30/2026 00:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/30/2026 01:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/30/2026 02:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/30/2026 03:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/30/2026 04:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/30/2026 05:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/30/2026 06:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/30/2026 07:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/30/2026 08:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/30/2026 09:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/30/2026 10:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/30/2026 11:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/30/2026 12:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/30/2026 13:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/30/2026 14:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/30/2026 15:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/30/2026 16:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/30/2026 17:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/30/2026 18:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/30/2026 19:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/30/2026 20:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/30/2026 21:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/30/2026 22:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
04/30/2026 23:00	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,500.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/01/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/01/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/01/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/01/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/01/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/01/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/01/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/01/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/01/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/01/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/01/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/01/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/01/2026 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/01/2026 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/01/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/01/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/01/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/01/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/01/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/01/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/01/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/01/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/01/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/01/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/02/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/02/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/02/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/02/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/02/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/02/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/02/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/02/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/02/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/02/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/02/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/02/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/02/2026 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/02/2026 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/02/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/02/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/02/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/02/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/02/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/02/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/02/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/02/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/02/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/02/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/03/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/03/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/03/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/03/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/03/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/03/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/03/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/03/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/03/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/03/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/03/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/03/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/03/2026 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/03/2026 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/03/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/03/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/03/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/03/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/03/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/03/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/03/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/03/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/03/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/03/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/04/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/04/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/04/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/04/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/04/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/04/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/04/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/04/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/04/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/04/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/04/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/04/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/04/2026 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/04/2026 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/04/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/04/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/04/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/04/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/04/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/04/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/04/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/04/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/04/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/04/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/05/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/05/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/05/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/05/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/05/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/05/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/05/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/05/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/05/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/05/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/05/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/05/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/05/2026 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/05/2026 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/05/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/05/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/05/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/05/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/05/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/05/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/05/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/05/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/05/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/05/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/06/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/06/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/06/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/06/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/06/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/06/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/06/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/06/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/06/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/06/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/06/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/06/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/06/2026 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/06/2026 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/06/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/06/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/06/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/06/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/06/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/06/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/06/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/06/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/06/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/06/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/07/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/07/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/07/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/07/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/07/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/07/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/07/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/07/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/07/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/07/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/07/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/07/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/07/2026 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/07/2026 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/07/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/07/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/07/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/07/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/07/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/07/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/07/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/07/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/07/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/07/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/08/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/08/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/08/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/08/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/08/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/08/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/08/2026 06:00	2,217.9	115.1	2,217.9	104,200.0	231.1	0.0	0.0	0.0
05/08/2026 07:00	3,815.1	109.0	3,815.1	104,200.0	397.5	0.5	0.2	0.8
05/08/2026 08:00	3,798.9	115.4	3,798.9	104,200.0	395.8	0.5	0.2	0.8
05/08/2026 09:00	4,600.5	107.5	4,600.5	104,200.0	479.4	0.6	0.3	1.0
05/08/2026 10:00	4,589.9	117.5	4,589.9	104,200.0	478.3	0.6	0.3	1.0
05/08/2026 11:00	4,269.9	165.3	4,269.9	104,200.0	444.9	0.6	0.3	0.9
05/08/2026 12:00	4,454.3	158.6	4,454.3	104,200.0	464.1	0.6	0.3	1.0
05/08/2026 13:00	4,185.5	146.6	4,189.9	104,200.0	436.6	0.5	0.3	0.9
05/08/2026 14:00	4,608.2	1,538.3	6,146.5	104,200.0	640.5	0.8	0.4	1.3
05/08/2026 15:00	3,454.5	167.7	3,471.3	104,200.0	361.7	0.5	0.2	0.8
05/08/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/08/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/08/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/08/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/08/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/08/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/08/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/08/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,999.5	274.1	4,155.4	104,200.0	433.0	0.6	0.3	0.9
Minimum:	2,217.9	107.5	2,217.9	104,200.0	231.1	0.5	0.2	0.8
Maximum:	4,608.2	1,538.3	6,146.5	104,200.0	640.5	0.8	0.4	1.3
%SI	58.33	58.33	58.33	0.00	58.33	62.50	62.50	62.50

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/09/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/09/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/09/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/09/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/09/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/09/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/09/2026 06:00	1,996.6	123.5	1,996.6	104,200.0	208.0	0.0	0.0	0.0
05/09/2026 07:00	3,696.8	115.9	3,696.8	104,200.0	385.2	0.5	0.2	0.8
05/09/2026 08:00	3,669.8	135.6	3,669.8	104,200.0	382.4	0.5	0.2	0.8
05/09/2026 09:00	3,669.6	123.7	3,669.6	104,200.0	382.4	0.5	0.2	0.8
05/09/2026 10:00	3,666.4	122.2	3,666.4	104,200.0	382.0	0.5	0.2	0.8
05/09/2026 11:00	3,661.2	158.0	3,661.2	104,200.0	381.5	0.5	0.2	0.8
05/09/2026 12:00	3,587.4	162.0	3,587.4	104,200.0	373.8	0.5	0.2	0.8
05/09/2026 13:00	1,579.6	159.2	1,579.6	104,200.0	164.6	0.0	0.0	0.0
05/09/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/09/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/09/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/09/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/09/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/09/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/09/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/09/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/09/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/09/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,190.9	137.5	3,190.9	104,200.0	332.5	0.5	0.2	0.8
Minimum:	1,579.6	115.9	1,579.6	104,200.0	164.6	0.5	0.2	0.8
Maximum:	3,696.8	162.0	3,696.8	104,200.0	385.2	0.5	0.2	0.8
%SI	66.67	66.67	66.67	0.00	66.67	75.00	75.00	75.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/10/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/10/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/10/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/10/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/10/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/10/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/10/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/10/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/10/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/10/2026 09:00	1,618.5	106.3	1,618.5	104,200.0	168.6	0.0	0.0	0.0
05/10/2026 10:00	3,885.8	109.7	3,885.8	104,200.0	404.9	0.5	0.3	0.9
05/10/2026 11:00	4,134.7	164.5	4,134.7	104,200.0	430.8	0.5	0.3	0.9
05/10/2026 12:00	4,453.1	163.2	4,453.1	104,200.0	464.0	0.6	0.3	1.0
05/10/2026 13:00	4,485.1	158.6	4,489.9	104,200.0	467.8	0.6	0.3	1.0
05/10/2026 14:00	4,559.7	1,824.1	6,383.8	104,200.0	665.2	0.8	0.4	1.3
05/10/2026 15:00	3,866.4	178.7	3,889.6	104,200.0	405.3	0.5	0.3	0.9
05/10/2026 16:00	1,668.6	145.9	1,668.6	104,200.0	173.9	0.0	0.0	0.0
05/10/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/10/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/10/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/10/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/10/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/10/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/10/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,584.0	356.4	3,815.5	104,200.0	397.6	0.6	0.3	1.0
Minimum:	1,618.5	106.3	1,618.5	104,200.0	168.6	0.5	0.3	0.9
Maximum:	4,559.7	1,824.1	6,383.8	104,200.0	665.2	0.8	0.4	1.3
%SI	66.67	66.67	66.67	0.00	66.67	75.00	75.00	75.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/11/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/11/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/11/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/11/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/11/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/11/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/11/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/11/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/11/2026 08:00	1,368.9	143.2	1,368.9	104,200.0	142.6	0.0	0.0	0.0
05/11/2026 09:00	3,722.2	133.0	3,722.2	104,200.0	387.9	0.5	0.2	0.8
05/11/2026 10:00	4,153.5	129.0	4,153.5	104,200.0	432.8	0.5	0.3	0.9
05/11/2026 11:00	4,575.8	169.3	4,575.8	104,200.0	476.8	0.6	0.3	1.0
05/11/2026 12:00	4,518.4	165.1	4,518.4	104,200.0	470.8	0.6	0.3	1.0
05/11/2026 13:00	4,541.9	1,640.7	6,149.8	104,200.0	640.8	0.8	0.4	1.3
05/11/2026 14:00	4,471.5	200.1	4,497.5	104,200.0	468.6	0.6	0.3	1.0
05/11/2026 15:00	4,147.1	147.1	4,147.1	104,200.0	432.1	0.6	0.3	1.0
05/11/2026 16:00	655.6	153.6	655.6	104,200.0	68.3	0.0	0.0	0.0
05/11/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/11/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/11/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/11/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/11/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/11/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/11/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,572.8	320.1	3,754.3	104,200.0	391.2	0.6	0.3	1.0
Minimum:	655.6	129.0	655.6	104,200.0	68.3	0.5	0.2	0.8
Maximum:	4,575.8	1,640.7	6,149.8	104,200.0	640.8	0.8	0.4	1.3
%SI	62.50	62.50	62.50	0.00	62.50	70.83	70.83	70.83

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/12/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/12/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/12/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/12/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/12/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/12/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/12/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/12/2026 07:00	3,045.8	126.2	3,045.8	104,200.0	317.4	0.0	0.0	0.0
05/12/2026 08:00	3,648.2	145.5	3,648.2	104,200.0	380.1	0.5	0.2	0.8
05/12/2026 09:00	3,636.2	135.1	3,636.2	104,200.0	378.9	0.5	0.2	0.8
05/12/2026 10:00	4,115.1	137.2	4,115.1	104,200.0	428.8	0.5	0.3	0.9
05/12/2026 11:00	4,179.4	177.4	4,179.4	104,200.0	435.5	0.5	0.3	0.9
05/12/2026 12:00	3,834.5	172.6	3,834.5	104,200.0	399.6	0.5	0.3	0.8
05/12/2026 13:00	3,945.3	152.9	3,945.3	104,200.0	411.1	0.5	0.3	0.9
05/12/2026 14:00	4,598.4	682.4	5,246.7	104,200.0	546.7	0.7	0.3	1.1
05/12/2026 15:00	4,611.5	1,129.2	5,740.7	104,200.0	598.2	0.7	0.4	1.2
05/12/2026 16:00	4,504.8	259.5	4,655.3	104,200.0	485.1	0.6	0.3	1.0
05/12/2026 17:00	3,693.3	139.7	3,693.3	104,200.0	384.8	0.5	0.2	0.8
05/12/2026 18:00	4,157.5	132.9	4,157.5	104,200.0	433.2	0.5	0.3	0.9
05/12/2026 19:00	4,273.2	98.5	4,273.2	104,200.0	445.3	0.6	0.3	1.0
05/12/2026 20:00	885.0	84.8	885.0	104,200.0	92.2	0.0	0.0	0.0
05/12/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/12/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/12/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,794.9	255.3	3,932.6	104,200.0	409.8	0.6	0.3	0.9
Minimum:	885.0	84.8	885.0	104,200.0	92.2	0.5	0.2	0.8
Maximum:	4,611.5	1,129.2	5,740.7	104,200.0	598.2	0.7	0.4	1.2
%SI	41.67	41.67	41.67	0.00	41.67	50.00	50.00	50.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/13/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/13/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/13/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/13/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/13/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/13/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/13/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/13/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/13/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/13/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/13/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/13/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/13/2026 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/13/2026 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/13/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/13/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/13/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/13/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/13/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/13/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/13/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/13/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/13/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/13/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/14/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/14/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/14/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/14/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/14/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/14/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/14/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/14/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/14/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/14/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/14/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/14/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/14/2026 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/14/2026 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/14/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/14/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/14/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/14/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/14/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/14/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/14/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/14/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/14/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/14/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/15/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/15/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/15/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/15/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/15/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/15/2026 05:00	1,724.8	119.7	1,724.8	104,200.0	179.7	0.0	0.0	0.0
05/15/2026 06:00	3,740.2	152.6	3,740.2	104,200.0	389.7	0.5	0.2	0.8
05/15/2026 07:00	3,716.7	171.4	3,716.7	104,200.0	387.3	0.5	0.2	0.8
05/15/2026 08:00	3,946.4	169.3	3,946.4	104,200.0	411.2	0.5	0.3	0.9
05/15/2026 09:00	4,505.2	124.8	4,505.2	104,200.0	469.4	0.6	0.3	1.0
05/15/2026 10:00	4,381.4	158.8	4,381.4	104,200.0	456.5	0.6	0.3	0.9
05/15/2026 11:00	4,431.6	197.3	4,431.6	104,200.0	461.8	0.6	0.3	1.0
05/15/2026 12:00	4,603.1	594.3	5,149.9	104,200.0	536.6	0.7	0.3	1.1
05/15/2026 13:00	4,604.5	1,417.2	6,021.7	104,200.0	627.5	0.8	0.4	1.3
05/15/2026 14:00	4,599.7	716.4	5,316.1	104,200.0	553.9	0.7	0.3	1.1
05/15/2026 15:00	4,033.6	149.0	4,045.5	104,200.0	421.5	0.5	0.3	0.9
05/15/2026 16:00	4,529.4	135.3	4,529.4	104,200.0	472.0	0.6	0.3	1.0
05/15/2026 17:00	4,342.2	142.2	4,342.2	104,200.0	452.5	0.6	0.3	1.0
05/15/2026 18:00	1,948.6	142.1	1,948.6	104,200.0	203.0	0.0	0.0	0.0
05/15/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/15/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/15/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/15/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/15/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,936.2	313.6	4,128.6	104,200.0	430.2	0.6	0.3	1.0
Minimum:	1,724.8	119.7	1,724.8	104,200.0	179.7	0.5	0.2	0.8
Maximum:	4,604.5	1,417.2	6,021.7	104,200.0	627.5	0.8	0.4	1.3
%SI	41.67	41.67	41.67	0.00	41.67	50.00	50.00	50.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/16/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/16/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/16/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/16/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/16/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/16/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/16/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/16/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/16/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/16/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/16/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/16/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/16/2026 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/16/2026 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/16/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/16/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/16/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/16/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/16/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/16/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/16/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/16/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/16/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/16/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/17/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/17/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/17/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/17/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/17/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/17/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/17/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/17/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/17/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/17/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/17/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/17/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/17/2026 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/17/2026 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/17/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/17/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/17/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/17/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/17/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/17/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/17/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/17/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/17/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/17/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/18/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/18/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/18/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/18/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/18/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/18/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/18/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/18/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/18/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/18/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/18/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/18/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/18/2026 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/18/2026 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/18/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/18/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/18/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/18/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/18/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/18/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/18/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/18/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/18/2026 22:00	711.4	125.4	711.4	104,200.0	74.1	0.0	0.0	0.0
05/18/2026 23:00	4,192.0	122.9	4,192.0	104,200.0	436.8	0.0	0.0	0.0
Average/Sum#:	2,451.7	124.2	2,451.7	104,200.0	255.5	0.0	0.0	0.0
Minimum:	711.4	122.9	711.4	104,200.0	74.1	0.0	0.0	0.0
Maximum:	4,192.0	125.4	4,192.0	104,200.0	436.8	0.0	0.0	0.0
%SI	91.67	91.67	91.67	0.00	91.67	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/19/2026 00:00	4,478.1	121.6	4,478.1	104,200.0	466.6	0.6	0.3	1.0
05/19/2026 01:00	4,718.0	123.5	4,718.0	104,200.0	491.6	0.6	0.3	1.0
05/19/2026 02:00	4,684.6	119.8	4,684.6	104,200.0	488.1	0.6	0.3	1.0
05/19/2026 03:00	4,697.4	116.2	4,697.4	104,200.0	489.5	0.6	0.3	1.0
05/19/2026 04:00	4,460.7	117.5	4,460.7	104,200.0	464.8	0.6	0.3	1.0
05/19/2026 05:00	3,811.1	133.9	3,811.1	104,200.0	397.1	0.5	0.2	0.8
05/19/2026 06:00	3,594.4	160.8	3,594.4	104,200.0	374.5	0.5	0.2	0.8
05/19/2026 07:00	3,098.9	170.7	3,098.9	104,200.0	322.9	0.5	0.2	0.8
05/19/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/19/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/19/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/19/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/19/2026 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/19/2026 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/19/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/19/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/19/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/19/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/19/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/19/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/19/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/19/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/19/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/19/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	4,192.9	133.0	4,192.9	104,200.0	436.9	0.6	0.3	0.9
Minimum:	3,098.9	116.2	3,098.9	104,200.0	322.9	0.5	0.2	0.8
Maximum:	4,718.0	170.7	4,718.0	104,200.0	491.6	0.6	0.3	1.0
%SI	66.67	66.67	66.67	0.00	66.67	66.67	66.67	66.67

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/20/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/20/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/20/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/20/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/20/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/20/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/20/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/20/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/20/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/20/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/20/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/20/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/20/2026 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/20/2026 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/20/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/20/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/20/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/20/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/20/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/20/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/20/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/20/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/20/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/20/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/21/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/21/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/21/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/21/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/21/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/21/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/21/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/21/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/21/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/21/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/21/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/21/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/21/2026 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/21/2026 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/21/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/21/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/21/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/21/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/21/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/21/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/21/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/21/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/21/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/21/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/22/2026 00:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/22/2026 01:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/22/2026 02:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/22/2026 03:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/22/2026 04:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/22/2026 05:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/22/2026 06:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/22/2026 07:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/22/2026 08:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/22/2026 09:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/22/2026 10:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/22/2026 11:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/22/2026 12:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/22/2026 13:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/22/2026 14:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/22/2026 15:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/22/2026 16:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/22/2026 17:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/22/2026 18:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/22/2026 19:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/22/2026 20:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/22/2026 21:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/22/2026 22:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
05/22/2026 23:00	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,200.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/23/2026 00:00	1,374.3	124.9	1,374.3	104,200.0	143.2	0.0	0.0	0.0
05/23/2026 01:00	3,709.5	124.8	3,709.5	104,200.0	386.5	0.5	0.2	0.8
05/23/2026 02:00	3,612.5	124.1	3,612.5	104,200.0	376.4	0.5	0.2	0.8
05/23/2026 03:00	3,768.6	121.9	3,768.6	104,200.0	392.7	0.5	0.2	0.8
05/23/2026 04:00	4,437.9	120.9	4,437.9	104,200.0	462.4	0.6	0.3	0.9
05/23/2026 05:00	3,838.9	122.7	3,838.9	104,200.0	400.0	0.5	0.2	0.8
05/23/2026 06:00	3,658.4	135.7	3,658.4	104,200.0	381.2	0.5	0.2	0.8
05/23/2026 07:00	3,654.6	149.6	3,654.6	104,200.0	380.8	0.5	0.2	0.8
05/23/2026 08:00	3,656.1	160.7	3,656.1	104,200.0	381.0	0.5	0.2	0.8
05/23/2026 09:00	3,665.7	158.0	3,665.7	104,200.0	382.0	0.5	0.2	0.8
05/23/2026 10:00	3,674.3	169.5	3,674.3	104,200.0	382.9	0.5	0.2	0.8
05/23/2026 11:00	3,666.4	202.9	3,666.4	104,200.0	382.0	0.5	0.2	0.8
05/23/2026 12:00	3,646.4	198.9	3,646.4	104,200.0	380.0	0.5	0.2	0.8
05/23/2026 13:00	3,644.4	171.2	3,644.4	104,200.0	379.7	0.5	0.2	0.8
05/23/2026 14:00	3,639.1	160.4	3,639.1	104,200.0	379.2	0.5	0.2	0.8
05/23/2026 15:00	3,634.0	148.3	3,634.0	104,200.0	378.7	0.5	0.2	0.8
05/23/2026 16:00	3,637.9	170.0	3,637.9	104,200.0	379.1	0.5	0.2	0.8
05/23/2026 17:00	3,641.6	164.4	3,641.6	104,200.0	379.5	0.5	0.2	0.8
05/23/2026 18:00	3,639.9	165.5	3,639.9	104,200.0	379.3	0.5	0.2	0.8
05/23/2026 19:00	3,641.4	144.7	3,641.4	104,200.0	379.4	0.5	0.2	0.8
05/23/2026 20:00	3,640.4	146.6	3,640.4	104,200.0	379.3	0.5	0.2	0.8
05/23/2026 21:00	3,636.9	137.4	3,636.9	104,200.0	379.0	0.5	0.2	0.8
05/23/2026 22:00	3,637.8	130.8	3,637.8	104,200.0	379.1	0.5	0.2	0.8
05/23/2026 23:00	3,649.0	131.6	3,649.0	104,200.0	380.2	0.5	0.2	0.8
Average/Sum#:	3,600.3	149.4	3,600.3	104,200.0	375.2	0.5	0.2	0.8
Minimum:	1,374.3	120.9	1,374.3	104,200.0	143.2	0.5	0.2	0.8
Maximum:	4,437.9	202.9	4,437.9	104,200.0	462.4	0.6	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	4.17	4.17	4.17

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/24/2026 00:00	3,652.4	126.5	3,652.4	104,200.0	380.6	0.5	0.2	0.8
05/24/2026 01:00	3,653.1	124.5	3,653.1	104,200.0	380.7	0.5	0.2	0.8
05/24/2026 02:00	3,659.5	122.6	3,659.5	104,200.0	381.3	0.5	0.2	0.8
05/24/2026 03:00	3,685.0	121.0	3,685.0	104,200.0	384.0	0.5	0.2	0.8
05/24/2026 04:00	3,690.4	119.4	3,690.4	104,200.0	384.5	0.5	0.2	0.8
05/24/2026 05:00	3,692.7	124.8	3,692.7	104,200.0	384.8	0.5	0.2	0.8
05/24/2026 06:00	3,697.3	130.5	3,697.3	104,200.0	385.3	0.5	0.2	0.8
05/24/2026 07:00	3,671.9	162.6	3,671.9	104,200.0	382.6	0.5	0.2	0.8
05/24/2026 08:00	3,666.1	176.9	3,666.1	104,200.0	382.0	0.5	0.2	0.8
05/24/2026 09:00	3,672.4	153.9	3,672.4	104,200.0	382.7	0.5	0.2	0.8
05/24/2026 10:00	3,676.1	177.7	3,676.1	104,200.0	383.0	0.5	0.2	0.8
05/24/2026 11:00	3,644.3	205.8	3,644.3	104,200.0	379.7	0.5	0.2	0.8
05/24/2026 12:00	3,633.7	194.3	3,633.7	104,200.0	378.6	0.5	0.2	0.8
05/24/2026 13:00	3,631.7	171.4	3,631.7	104,200.0	378.4	0.5	0.2	0.8
05/24/2026 14:00	3,633.0	165.6	3,633.0	104,200.0	378.6	0.5	0.2	0.8
05/24/2026 15:00	3,640.0	146.0	3,640.0	104,200.0	379.3	0.5	0.2	0.8
05/24/2026 16:00	3,638.7	157.6	3,638.7	104,200.0	379.2	0.5	0.2	0.8
05/24/2026 17:00	3,640.9	149.6	3,640.9	104,200.0	379.4	0.5	0.2	0.8
05/24/2026 18:00	3,642.2	163.5	3,642.2	104,200.0	379.5	0.5	0.2	0.8
05/24/2026 19:00	3,641.2	147.3	3,641.2	104,200.0	379.4	0.5	0.2	0.8
05/24/2026 20:00	3,641.4	137.9	3,641.4	104,200.0	379.4	0.5	0.2	0.8
05/24/2026 21:00	3,656.7	132.8	3,656.7	104,200.0	381.0	0.5	0.2	0.8
05/24/2026 22:00	3,657.0	131.6	3,657.0	104,200.0	381.1	0.5	0.2	0.8
05/24/2026 23:00	3,660.9	128.3	3,660.9	104,200.0	381.5	0.5	0.2	0.8
Average/Sum#:	3,657.4	148.8	3,657.4	104,200.0	381.1	0.5	0.2	0.8
Minimum:	3,631.7	119.4	3,631.7	104,200.0	378.4	0.5	0.2	0.8
Maximum:	3,697.3	205.8	3,697.3	104,200.0	385.3	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/25/2026 00:00	3,660.3	127.4	3,660.3	104,200.0	381.4	0.5	0.2	0.8
05/25/2026 01:00	3,659.1	124.2	3,659.1	104,200.0	381.3	0.5	0.2	0.8
05/25/2026 02:00	3,653.5	119.6	3,653.5	104,200.0	380.7	0.5	0.2	0.8
05/25/2026 03:00	3,669.7	118.4	3,669.7	104,200.0	382.4	0.5	0.2	0.8
05/25/2026 04:00	3,669.1	116.9	3,669.1	104,200.0	382.3	0.5	0.2	0.8
05/25/2026 05:00	3,678.9	123.3	3,678.9	104,200.0	383.3	0.5	0.2	0.8
05/25/2026 06:00	3,654.5	134.7	3,654.5	104,200.0	380.8	0.5	0.2	0.8
05/25/2026 07:00	3,630.2	151.4	3,630.2	104,200.0	378.3	0.5	0.2	0.8
05/25/2026 08:00	3,643.4	154.0	3,643.4	104,200.0	379.6	0.5	0.2	0.8
05/25/2026 09:00	3,644.6	144.4	3,644.6	104,200.0	379.8	0.5	0.2	0.8
05/25/2026 10:00	3,626.0	163.2	3,626.0	104,200.0	377.8	0.5	0.2	0.8
05/25/2026 11:00	3,624.2	190.0	3,624.2	104,200.0	377.6	0.5	0.2	0.8
05/25/2026 12:00	3,627.0	188.5	3,627.0	104,200.0	377.9	0.5	0.2	0.8
05/25/2026 13:00	3,635.7	168.7	3,635.7	104,200.0	378.8	0.5	0.2	0.8
05/25/2026 14:00	3,636.2	152.0	3,636.2	104,200.0	378.9	0.5	0.2	0.8
05/25/2026 15:00	3,633.5	136.7	3,633.5	104,200.0	378.6	0.5	0.2	0.8
05/25/2026 16:00	3,634.3	151.0	3,634.3	104,200.0	378.7	0.5	0.2	0.8
05/25/2026 17:00	3,633.0	142.7	3,633.0	104,200.0	378.6	0.5	0.2	0.8
05/25/2026 18:00	3,636.0	142.0	3,636.0	104,200.0	378.9	0.5	0.2	0.8
05/25/2026 19:00	3,633.9	131.2	3,633.9	104,200.0	378.7	0.5	0.2	0.8
05/25/2026 20:00	3,639.9	128.7	3,639.9	104,200.0	379.3	0.5	0.2	0.8
05/25/2026 21:00	3,641.1	125.2	3,641.1	104,200.0	379.4	0.5	0.2	0.8
05/25/2026 22:00	3,643.3	122.5	3,643.3	104,200.0	379.6	0.5	0.2	0.8
05/25/2026 23:00	3,666.5	127.9	3,666.5	104,200.0	382.0	0.5	0.2	0.8
Average/Sum#:	3,644.7	141.0	3,644.7	104,200.0	379.8	0.5	0.2	0.8
Minimum:	3,624.2	116.9	3,624.2	104,200.0	377.6	0.5	0.2	0.8
Maximum:	3,678.9	190.0	3,678.9	104,200.0	383.3	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/26/2026 00:00	3,672.1	125.5	3,672.1	104,200.0	382.6	0.5	0.2	0.8
05/26/2026 01:00	3,672.3	125.6	3,672.3	104,200.0	382.7	0.5	0.2	0.8
05/26/2026 02:00	3,689.8	122.1	3,689.8	104,200.0	384.5	0.5	0.2	0.8
05/26/2026 03:00	3,694.8	117.4	3,694.8	104,200.0	385.0	0.5	0.2	0.8
05/26/2026 04:00	3,693.7	118.9	3,693.7	104,200.0	384.9	0.5	0.2	0.8
05/26/2026 05:00	3,658.8	119.5	3,658.8	104,200.0	381.2	0.5	0.2	0.8
05/26/2026 06:00	3,962.6	127.9	3,962.6	104,200.0	412.9	0.5	0.3	0.9
05/26/2026 07:00	4,274.6	130.1	4,274.6	104,200.0	445.4	0.6	0.3	0.9
05/26/2026 08:00	3,647.1	138.7	3,647.1	104,200.0	380.0	0.5	0.2	0.8
05/26/2026 09:00	3,643.4	166.5	3,643.4	104,200.0	379.6	0.5	0.2	0.8
05/26/2026 10:00	3,890.5	156.5	3,890.5	104,200.0	405.4	0.5	0.3	0.8
05/26/2026 11:00	3,696.6	176.5	3,696.6	104,200.0	385.2	0.5	0.2	0.8
05/26/2026 12:00	3,641.1	171.7	3,641.1	104,200.0	379.4	0.5	0.2	0.8
05/26/2026 13:00	3,644.1	159.6	3,644.1	104,200.0	379.7	0.5	0.2	0.8
05/26/2026 14:00	3,641.1	138.8	3,641.1	104,200.0	379.4	0.5	0.2	0.8
05/26/2026 15:00	3,638.0	152.9	3,638.0	104,200.0	379.1	0.5	0.2	0.8
05/26/2026 16:00	3,643.6	118.6	3,643.6	104,200.0	379.7	0.5	0.2	0.8
05/26/2026 17:00	3,761.7	120.1	3,761.7	104,200.0	392.0	0.5	0.2	0.8
05/26/2026 18:00	3,763.3	149.7	3,763.3	104,200.0	392.1	0.5	0.2	0.8
05/26/2026 19:00	3,638.6	134.6	3,638.6	104,200.0	379.1	0.5	0.2	0.8
05/26/2026 20:00	3,635.2	121.6	3,635.2	104,200.0	378.8	0.5	0.2	0.8
05/26/2026 21:00	3,633.3	122.8	3,633.3	104,200.0	378.6	0.5	0.2	0.8
05/26/2026 22:00	3,649.4	114.2	3,649.4	104,200.0	380.3	0.5	0.2	0.8
05/26/2026 23:00	4,398.9	109.5	4,398.9	104,200.0	458.4	0.6	0.3	0.9
Average/Sum#:	3,745.2	135.0	3,745.2	104,200.0	390.3	0.5	0.2	0.8
Minimum:	3,633.3	109.5	3,633.3	104,200.0	378.6	0.5	0.2	0.8
Maximum:	4,398.9	176.5	4,398.9	104,200.0	458.4	0.6	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/27/2026 00:00	4,403.5	119.3	4,403.5	104,200.0	458.8	0.6	0.3	0.9
05/27/2026 01:00	4,351.7	117.7	4,351.7	104,200.0	453.4	0.6	0.3	0.9
05/27/2026 02:00	3,931.1	112.8	3,931.1	104,200.0	409.6	0.5	0.3	0.8
05/27/2026 03:00	4,343.3	113.8	4,343.3	104,200.0	452.6	0.6	0.3	0.9
05/27/2026 04:00	4,288.8	111.1	4,288.8	104,200.0	446.9	0.6	0.3	0.9
05/27/2026 05:00	4,062.4	113.4	4,062.4	104,200.0	423.3	0.5	0.3	0.9
05/27/2026 06:00	3,620.7	144.8	3,620.7	104,200.0	377.3	0.5	0.2	0.8
05/27/2026 07:00	3,926.7	154.3	3,926.7	104,200.0	409.2	0.5	0.3	0.9
05/27/2026 08:00	3,623.1	169.7	3,623.1	104,200.0	377.5	0.5	0.2	0.8
05/27/2026 09:00	3,616.4	143.8	3,616.4	104,200.0	376.8	0.5	0.2	0.8
05/27/2026 10:00	3,614.7	157.7	3,614.7	104,200.0	376.7	0.5	0.2	0.8
05/27/2026 11:00	3,621.0	179.3	3,621.0	104,200.0	377.3	0.5	0.2	0.8
05/27/2026 12:00	3,621.8	170.8	3,621.8	104,200.0	377.4	0.5	0.2	0.8
05/27/2026 13:00	3,616.8	159.0	3,616.8	104,200.0	376.9	0.5	0.2	0.8
05/27/2026 14:00	3,620.2	150.4	3,620.2	104,200.0	377.2	0.5	0.2	0.8
05/27/2026 15:00	3,958.2	135.9	3,958.2	104,200.0	412.4	0.5	0.3	0.9
05/27/2026 16:00	3,636.1	122.0	3,636.1	104,200.0	378.9	0.5	0.2	0.8
05/27/2026 17:00	3,960.5	135.0	3,960.5	104,200.0	412.7	0.5	0.3	0.9
05/27/2026 18:00	4,376.0	139.1	4,376.0	104,200.0	456.0	0.6	0.3	0.9
05/27/2026 19:00	4,253.4	135.8	4,253.4	104,200.0	443.2	0.5	0.3	0.9
05/27/2026 20:00	4,418.7	135.8	4,418.7	104,200.0	460.4	0.6	0.3	0.9
05/27/2026 21:00	4,437.5	138.6	4,437.5	104,200.0	462.4	0.6	0.3	1.0
05/27/2026 22:00	3,763.7	140.6	3,763.7	104,200.0	392.2	0.5	0.2	0.8
05/27/2026 23:00	4,409.4	135.5	4,409.4	104,200.0	459.5	0.6	0.3	0.9
Average/Sum#:	3,978.2	139.0	3,978.2	104,200.0	414.5	0.5	0.3	0.9
Minimum:	3,614.7	111.1	3,614.7	104,200.0	376.7	0.5	0.2	0.8
Maximum:	4,437.5	179.3	4,437.5	104,200.0	462.4	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/28/2026 00:00	4,375.0	127.7	4,375.0	104,200.0	455.9	0.6	0.3	0.9
05/28/2026 01:00	3,737.8	133.9	3,737.8	104,200.0	389.5	0.5	0.2	0.8
05/28/2026 02:00	3,903.2	132.4	3,903.2	104,200.0	406.7	0.5	0.3	0.8
05/28/2026 03:00	3,648.9	118.2	3,648.9	104,200.0	380.2	0.5	0.2	0.8
05/28/2026 04:00	3,642.8	112.1	3,642.8	104,200.0	379.6	0.5	0.2	0.8
05/28/2026 05:00	3,641.5	111.1	3,641.5	104,200.0	379.4	0.5	0.2	0.8
05/28/2026 06:00	3,711.4	119.9	3,711.4	104,200.0	386.7	0.5	0.2	0.8
05/28/2026 07:00	4,170.4	131.6	4,170.4	104,200.0	434.6	0.5	0.3	0.9
05/28/2026 08:00	3,939.8	135.0	3,939.8	104,200.0	410.5	0.5	0.3	0.8
05/28/2026 09:00	4,098.4	147.5	4,098.4	104,200.0	427.1	0.5	0.3	0.9
05/28/2026 10:00	4,218.5	161.7	4,218.5	104,200.0	439.6	0.5	0.3	0.9
05/28/2026 11:00	3,648.0	169.0	3,648.0	104,200.0	380.1	0.5	0.2	0.8
05/28/2026 12:00	3,653.9	157.3	3,653.9	104,200.0	380.7	0.5	0.2	0.8
05/28/2026 13:00	3,715.3	163.3	3,715.3	104,200.0	387.1	0.5	0.2	0.8
05/28/2026 14:00	3,642.7	139.0	3,642.7	104,200.0	379.6	0.5	0.2	0.8
05/28/2026 15:00	3,641.7	145.4	3,641.7	104,200.0	379.5	0.5	0.2	0.8
05/28/2026 16:00	3,641.7	150.7	3,641.7	104,200.0	379.5	0.5	0.2	0.8
05/28/2026 17:00	3,646.3	143.1	3,646.3	104,200.0	379.9	0.5	0.2	0.8
05/28/2026 18:00	4,202.4	152.4	4,202.4	104,200.0	437.9	0.5	0.3	0.9
05/28/2026 19:00	3,648.4	138.3	3,648.4	104,200.0	380.2	0.5	0.2	0.8
05/28/2026 20:00	4,400.1	134.9	4,400.1	104,200.0	458.5	0.6	0.3	0.9
05/28/2026 21:00	4,441.6	134.9	4,441.6	104,200.0	462.8	0.6	0.3	1.0
05/28/2026 22:00	4,377.0	135.1	4,377.0	104,200.0	456.1	0.6	0.3	0.9
05/28/2026 23:00	3,899.2	126.2	3,899.2	104,200.0	406.3	0.5	0.3	0.8
Average/Sum#:	3,901.9	138.4	3,901.9	104,200.0	406.6	0.5	0.2	0.8
Minimum:	3,641.5	111.1	3,641.5	104,200.0	379.4	0.5	0.2	0.8
Maximum:	4,441.6	169.0	4,441.6	104,200.0	462.8	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/29/2026 00:00	3,645.9	114.1	3,645.9	104,200.0	379.9	0.5	0.2	0.8
05/29/2026 01:00	3,662.5	111.5	3,662.5	104,200.0	381.6	0.5	0.2	0.8
05/29/2026 02:00	3,663.6	114.9	3,663.6	104,200.0	381.7	0.5	0.2	0.8
05/29/2026 03:00	3,664.8	114.7	3,664.8	104,200.0	381.9	0.5	0.2	0.8
05/29/2026 04:00	3,664.1	117.1	3,664.1	104,200.0	381.8	0.5	0.2	0.8
05/29/2026 05:00	3,657.0	118.5	3,657.0	104,200.0	381.1	0.5	0.2	0.8
05/29/2026 06:00	3,649.6	121.8	3,649.6	104,200.0	380.3	0.5	0.2	0.8
05/29/2026 07:00	3,652.2	124.0	3,652.2	104,200.0	380.6	0.5	0.2	0.8
05/29/2026 08:00	3,647.8	126.8	3,647.8	104,200.0	380.1	0.5	0.2	0.8
05/29/2026 09:00	3,649.4	135.1	3,649.4	104,200.0	380.3	0.5	0.2	0.8
05/29/2026 10:00	3,654.4	146.0	3,654.4	104,200.0	380.8	0.5	0.2	0.8
05/29/2026 11:00	3,664.8	145.2	3,664.8	104,200.0	381.9	0.5	0.2	0.8
05/29/2026 12:00	3,664.4	153.3	3,664.4	104,200.0	381.8	0.5	0.2	0.8
05/29/2026 13:00	3,653.2	134.9	3,653.2	104,200.0	380.7	0.5	0.2	0.8
05/29/2026 14:00	3,654.1	149.9	3,654.1	104,200.0	380.8	0.5	0.2	0.8
05/29/2026 15:00	3,651.4	143.4	3,651.4	104,200.0	380.5	0.5	0.2	0.8
05/29/2026 16:00	3,663.8	146.6	3,663.8	104,200.0	381.8	0.5	0.2	0.8
05/29/2026 17:00	3,657.5	142.8	3,657.5	104,200.0	381.1	0.5	0.2	0.8
05/29/2026 18:00	3,665.6	144.5	3,665.6	104,200.0	382.0	0.5	0.2	0.8
05/29/2026 19:00	3,661.9	131.0	3,661.9	104,200.0	381.6	0.5	0.2	0.8
05/29/2026 20:00	3,649.4	120.7	3,649.4	104,200.0	380.3	0.5	0.2	0.8
05/29/2026 21:00	3,661.2	133.5	3,661.2	104,200.0	381.5	0.5	0.2	0.8
05/29/2026 22:00	3,673.5	131.6	3,673.5	104,200.0	382.8	0.5	0.2	0.8
05/29/2026 23:00	3,676.2	128.5	3,676.2	104,200.0	383.1	0.5	0.2	0.8
Average/Sum#:	3,658.7	131.3	3,658.7	104,200.0	381.3	0.5	0.2	0.8
Minimum:	3,645.9	111.5	3,645.9	104,200.0	379.9	0.5	0.2	0.8
Maximum:	3,676.2	153.3	3,676.2	104,200.0	383.1	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/30/2026 00:00	3,669.0	123.4	3,669.0	104,200.0	382.3	0.5	0.2	0.8
05/30/2026 01:00	3,671.0	122.3	3,671.0	104,200.0	382.5	0.5	0.2	0.8
05/30/2026 02:00	3,663.0	119.4	3,663.0	104,200.0	381.7	0.5	0.2	0.8
05/30/2026 03:00	3,659.7	120.4	3,659.7	104,200.0	381.3	0.5	0.2	0.8
05/30/2026 04:00	3,666.0	116.8	3,666.0	104,200.0	382.0	0.5	0.2	0.8
05/30/2026 05:00	3,662.5	123.2	3,662.5	104,200.0	381.6	0.5	0.2	0.8
05/30/2026 06:00	3,652.5	134.6	3,652.5	104,200.0	380.6	0.5	0.2	0.8
05/30/2026 07:00	3,650.6	153.6	3,650.6	104,200.0	380.4	0.5	0.2	0.8
05/30/2026 08:00	3,658.5	175.0	3,658.5	104,200.0	381.2	0.5	0.2	0.8
05/30/2026 09:00	3,666.2	163.9	3,666.2	104,200.0	382.0	0.5	0.2	0.8
05/30/2026 10:00	3,665.8	190.3	3,665.8	104,200.0	382.0	0.5	0.2	0.8
05/30/2026 11:00	3,647.2	198.6	3,647.2	104,200.0	380.0	0.5	0.2	0.8
05/30/2026 12:00	3,644.8	180.2	3,644.8	104,200.0	379.8	0.5	0.2	0.8
05/30/2026 13:00	3,642.2	168.7	3,642.2	104,200.0	379.5	0.5	0.2	0.8
05/30/2026 14:00	3,637.2	158.0	3,637.2	104,200.0	379.0	0.5	0.2	0.8
05/30/2026 15:00	3,633.4	140.6	3,633.4	104,200.0	378.6	0.5	0.2	0.8
05/30/2026 16:00	3,630.4	148.8	3,630.4	104,200.0	378.3	0.5	0.2	0.8
05/30/2026 17:00	3,618.8	144.9	3,618.8	104,200.0	377.1	0.5	0.2	0.8
05/30/2026 18:00	3,608.2	157.6	3,608.2	104,200.0	376.0	0.5	0.2	0.8
05/30/2026 19:00	3,654.7	132.2	3,654.7	104,200.0	380.8	0.5	0.2	0.8
05/30/2026 20:00	3,673.2	129.4	3,673.2	104,200.0	382.7	0.5	0.2	0.8
05/30/2026 21:00	3,669.1	143.8	3,669.1	104,200.0	382.3	0.5	0.2	0.8
05/30/2026 22:00	3,672.2	139.7	3,672.2	104,200.0	382.6	0.5	0.2	0.8
05/30/2026 23:00	3,669.8	136.5	3,669.8	104,200.0	382.4	0.5	0.2	0.8
Average/Sum#:	3,653.6	146.7	3,653.6	104,200.0	380.7	0.5	0.2	0.8
Minimum:	3,608.2	116.8	3,608.2	104,200.0	376.0	0.5	0.2	0.8
Maximum:	3,673.2	198.6	3,673.2	104,200.0	382.7	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
05/31/2026 00:00	3,658.2	136.6	3,658.2	104,200.0	381.2	0.5	0.2	0.8
05/31/2026 01:00	3,661.1	132.8	3,661.1	104,200.0	381.5	0.5	0.2	0.8
05/31/2026 02:00	3,655.8	134.6	3,655.8	104,200.0	380.9	0.5	0.2	0.8
05/31/2026 03:00	3,653.2	132.2	3,653.2	104,200.0	380.7	0.5	0.2	0.8
05/31/2026 04:00	3,660.8	127.4	3,660.8	104,200.0	381.5	0.5	0.2	0.8
05/31/2026 05:00	3,658.7	136.3	3,658.7	104,200.0	381.2	0.5	0.2	0.8
05/31/2026 06:00	3,653.2	161.8	3,653.2	104,200.0	380.7	0.5	0.2	0.8
05/31/2026 07:00	3,651.6	172.3	3,651.6	104,200.0	380.5	0.5	0.2	0.8
05/31/2026 08:00	3,657.7	184.7	3,657.7	104,200.0	381.1	0.5	0.2	0.8
05/31/2026 09:00	3,644.8	172.3	3,644.8	104,200.0	379.8	0.5	0.2	0.8
05/31/2026 10:00	3,630.8	180.0	3,630.8	104,200.0	378.3	0.5	0.2	0.8
05/31/2026 11:00	3,635.1	199.9	3,635.1	104,200.0	378.8	0.5	0.2	0.8
05/31/2026 12:00	3,631.1	192.1	3,631.1	104,200.0	378.4	0.5	0.2	0.8
05/31/2026 13:00	3,629.5	175.2	3,629.5	104,200.0	378.2	0.5	0.2	0.8
05/31/2026 14:00	3,628.6	155.2	3,628.6	104,200.0	378.1	0.5	0.2	0.8
05/31/2026 15:00	3,625.2	150.3	3,625.2	104,200.0	377.7	0.5	0.2	0.8
05/31/2026 16:00	3,621.4	157.9	3,621.4	104,200.0	377.3	0.5	0.2	0.8
05/31/2026 17:00	3,701.5	150.4	3,701.5	104,200.0	385.7	0.5	0.2	0.8
05/31/2026 18:00	3,610.5	164.9	3,610.5	104,200.0	376.2	0.5	0.2	0.8
05/31/2026 19:00	3,607.8	146.1	3,607.8	104,200.0	375.9	0.5	0.2	0.8
05/31/2026 20:00	3,610.8	151.7	3,610.8	104,200.0	376.2	0.5	0.2	0.8
05/31/2026 21:00	3,612.3	150.5	3,612.3	104,200.0	376.4	0.5	0.2	0.8
05/31/2026 22:00	3,608.5	150.0	3,608.5	104,200.0	376.0	0.5	0.2	0.8
05/31/2026 23:00	3,612.9	143.8	3,612.9	104,200.0	376.5	0.5	0.2	0.8
Average/Sum#:	3,638.4	156.6	3,638.4	104,200.0	379.1	0.5	0.2	0.8
Minimum:	3,607.8	127.4	3,607.8	104,200.0	375.9	0.5	0.2	0.8
Maximum:	3,701.5	199.9	3,701.5	104,200.0	385.7	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/01/2026 00:00	3,610.4	142.6	3,610.4	104,200.0	376.2	0.5	0.2	0.8
06/01/2026 01:00	3,613.8	143.7	3,613.8	104,600.0	378.0	0.5	0.2	0.8
06/01/2026 02:00	3,616.3	140.9	3,616.3	104,600.0	378.3	0.5	0.2	0.8
06/01/2026 03:00	3,625.7	139.8	3,625.7	104,600.0	379.2	0.5	0.2	0.8
06/01/2026 04:00	3,646.2	138.1	3,646.2	104,600.0	381.4	0.5	0.2	0.8
06/01/2026 05:00	3,648.4	147.5	3,648.4	104,600.0	381.6	0.5	0.2	0.8
06/01/2026 06:00	3,647.0	180.5	3,647.0	104,600.0	381.5	0.5	0.2	0.8
06/01/2026 07:00	3,633.2	176.1	3,633.2	104,600.0	380.0	0.5	0.2	0.8
06/01/2026 08:00	3,611.5	182.0	3,611.5	104,600.0	377.8	0.5	0.2	0.8
06/01/2026 09:00	3,607.9	180.7	3,607.9	104,600.0	377.4	0.5	0.2	0.8
06/01/2026 10:00	3,616.8	189.7	3,616.8	104,600.0	378.3	0.5	0.2	0.8
06/01/2026 11:00	3,620.5	198.8	3,620.5	104,600.0	378.7	0.5	0.2	0.8
06/01/2026 12:00	3,615.6	195.0	3,615.6	104,600.0	378.2	0.5	0.2	0.8
06/01/2026 13:00	3,608.7	180.0	3,608.7	104,600.0	377.5	0.5	0.2	0.8
06/01/2026 14:00	3,603.3	169.4	3,603.3	104,600.0	376.9	0.5	0.2	0.8
06/01/2026 15:00	3,603.2	159.2	3,603.2	104,600.0	376.9	0.5	0.2	0.8
06/01/2026 16:00	3,648.8	165.9	3,648.8	104,600.0	381.7	0.5	0.2	0.8
06/01/2026 17:00	3,857.0	160.6	3,857.0	104,600.0	403.4	0.5	0.3	0.8
06/01/2026 18:00	4,167.5	165.8	4,167.5	104,600.0	435.9	0.5	0.3	0.9
06/01/2026 19:00	3,840.2	152.2	3,840.2	104,600.0	401.7	0.5	0.3	0.8
06/01/2026 20:00	3,777.2	152.1	3,777.2	104,600.0	395.1	0.5	0.2	0.8
06/01/2026 21:00	3,771.6	148.9	3,771.6	104,600.0	394.5	0.5	0.2	0.8
06/01/2026 22:00	4,106.2	138.2	4,106.2	104,600.0	429.5	0.5	0.3	0.9
06/01/2026 23:00	3,671.0	148.0	3,671.0	104,600.0	384.0	0.5	0.2	0.8
Average/Sum#:	3,698.7	162.3	3,698.7	104,583.3	386.8	0.5	0.2	0.8
Minimum:	3,603.2	138.1	3,603.2	104,200.0	376.2	0.5	0.2	0.8
Maximum:	4,167.5	198.8	4,167.5	104,600.0	435.9	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/02/2026 00:00	3,696.7	148.8	3,696.7	104,600.0	386.7	0.5	0.2	0.8
06/02/2026 01:00	3,604.3	146.3	3,604.3	104,600.0	377.0	0.5	0.2	0.8
06/02/2026 02:00	3,600.4	142.0	3,600.4	104,600.0	376.6	0.5	0.2	0.8
06/02/2026 03:00	3,602.7	138.4	3,602.7	104,600.0	376.8	0.5	0.2	0.8
06/02/2026 04:00	3,621.8	138.4	3,621.8	104,600.0	378.8	0.5	0.2	0.8
06/02/2026 05:00	3,690.5	147.8	3,690.5	104,600.0	386.0	0.5	0.2	0.8
06/02/2026 06:00	3,638.1	166.7	3,638.1	104,600.0	380.5	0.5	0.2	0.8
06/02/2026 07:00	3,637.3	176.0	3,637.3	104,600.0	380.5	0.5	0.2	0.8
06/02/2026 08:00	3,638.1	192.9	3,638.1	104,600.0	380.5	0.5	0.2	0.8
06/02/2026 09:00	3,610.5	196.1	3,610.5	104,600.0	377.7	0.5	0.2	0.8
06/02/2026 10:00	3,610.7	192.2	3,610.7	104,600.0	377.7	0.5	0.2	0.8
06/02/2026 11:00	3,618.9	199.5	3,618.9	104,600.0	378.5	0.5	0.2	0.8
06/02/2026 12:00	3,609.2	196.1	3,609.2	104,600.0	377.5	0.5	0.2	0.8
06/02/2026 13:00	3,609.7	182.1	3,609.7	104,600.0	377.6	0.5	0.2	0.8
06/02/2026 14:00	3,600.8	172.8	3,600.8	104,600.0	376.6	0.5	0.2	0.8
06/02/2026 15:00	3,604.4	164.2	3,604.4	104,600.0	377.0	0.5	0.2	0.8
06/02/2026 16:00	3,914.2	168.7	3,914.2	104,600.0	409.4	0.5	0.3	0.9
06/02/2026 17:00	4,027.8	163.3	4,027.8	104,600.0	421.3	0.5	0.3	0.9
06/02/2026 18:00	4,376.9	157.9	4,376.9	104,600.0	457.8	0.6	0.3	0.9
06/02/2026 19:00	3,940.1	152.3	3,940.1	104,600.0	412.1	0.5	0.3	0.9
06/02/2026 20:00	3,991.6	147.9	3,991.6	104,600.0	417.5	0.5	0.3	0.9
06/02/2026 21:00	4,235.3	144.9	4,235.3	104,600.0	443.0	0.5	0.3	0.9
06/02/2026 22:00	3,878.5	155.4	3,878.5	104,600.0	405.7	0.5	0.3	0.8
06/02/2026 23:00	3,621.6	150.5	3,621.6	104,600.0	378.8	0.5	0.2	0.8
Average/Sum#:	3,749.2	164.2	3,749.2	104,600.0	392.2	0.5	0.2	0.8
Minimum:	3,600.4	138.4	3,600.4	104,600.0	376.6	0.5	0.2	0.8
Maximum:	4,376.9	199.5	4,376.9	104,600.0	457.8	0.6	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/03/2026 00:00	3,632.1	150.9	3,632.1	104,600.0	379.9	0.5	0.2	0.8
06/03/2026 01:00	3,630.0	144.9	3,630.0	104,600.0	379.7	0.5	0.2	0.8
06/03/2026 02:00	3,633.8	141.7	3,633.8	104,600.0	380.1	0.5	0.2	0.8
06/03/2026 03:00	3,638.6	139.2	3,638.6	104,600.0	380.6	0.5	0.2	0.8
06/03/2026 04:00	3,633.6	137.8	3,633.6	104,600.0	380.1	0.5	0.2	0.8
06/03/2026 05:00	3,632.1	144.5	3,632.1	104,600.0	379.9	0.5	0.2	0.8
06/03/2026 06:00	3,630.6	153.5	3,630.6	104,600.0	379.8	0.5	0.2	0.8
06/03/2026 07:00	3,633.9	172.0	3,633.9	104,600.0	380.1	0.5	0.2	0.8
06/03/2026 08:00	3,633.3	191.8	3,633.3	104,600.0	380.0	0.5	0.2	0.8
06/03/2026 09:00	3,644.2	188.3	3,644.2	104,600.0	381.2	0.5	0.2	0.8
06/03/2026 10:00	3,645.7	187.9	3,645.7	104,600.0	381.3	0.5	0.2	0.8
06/03/2026 11:00	3,638.2	221.4	3,638.2	104,600.0	380.6	0.5	0.2	0.8
06/03/2026 12:00	3,594.4	199.2	3,594.4	104,600.0	376.0	0.5	0.2	0.8
06/03/2026 13:00	3,583.4	180.0	3,583.4	104,600.0	374.8	0.5	0.2	0.8
06/03/2026 14:00	3,582.5	166.0	3,582.5	104,600.0	374.7	0.5	0.2	0.8
06/03/2026 15:00	3,580.0	164.5	3,580.0	104,600.0	374.5	0.5	0.2	0.8
06/03/2026 16:00	4,131.0	170.3	4,131.0	104,600.0	432.1	0.5	0.3	0.9
06/03/2026 17:00	4,009.9	165.9	4,009.9	104,600.0	419.4	0.5	0.3	0.9
06/03/2026 18:00	4,422.2	169.1	4,422.2	104,600.0	462.6	0.6	0.3	1.0
06/03/2026 19:00	4,026.7	156.7	4,026.7	104,600.0	421.2	0.5	0.3	0.9
06/03/2026 20:00	3,905.4	152.7	3,905.4	104,600.0	408.5	0.5	0.3	0.8
06/03/2026 21:00	3,972.0	152.3	3,972.0	104,600.0	415.5	0.6	0.3	0.9
06/03/2026 22:00	1,118.4	164.6	1,118.4	104,600.0	117.0	0.0	0.0	0.0
06/03/2026 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	3,632.7	165.9	3,632.7	104,600.0	380.0	0.5	0.2	0.8
Minimum:	1,118.4	137.8	1,118.4	104,600.0	117.0	0.5	0.2	0.8
Maximum:	4,422.2	221.4	4,422.2	104,600.0	462.6	0.6	0.3	1.0
%SI	4.17	4.17	4.17	0.00	4.17	8.33	8.33	8.33

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/04/2026 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/04/2026 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/04/2026 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/04/2026 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/04/2026 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/04/2026 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/04/2026 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/04/2026 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/04/2026 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/04/2026 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/04/2026 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/04/2026 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/04/2026 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/04/2026 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/04/2026 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/04/2026 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/04/2026 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/04/2026 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/04/2026 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/04/2026 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/04/2026 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/04/2026 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/04/2026 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/04/2026 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/05/2026 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/05/2026 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/05/2026 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/05/2026 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/05/2026 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/05/2026 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/05/2026 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/05/2026 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/05/2026 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/05/2026 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/05/2026 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/05/2026 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/05/2026 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/05/2026 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/05/2026 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/05/2026 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/05/2026 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/05/2026 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/05/2026 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/05/2026 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/05/2026 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/05/2026 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/05/2026 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/05/2026 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/06/2026 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/06/2026 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/06/2026 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/06/2026 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/06/2026 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/06/2026 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/06/2026 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/06/2026 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/06/2026 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/06/2026 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/06/2026 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/06/2026 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/06/2026 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/06/2026 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/06/2026 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/06/2026 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/06/2026 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/06/2026 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/06/2026 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/06/2026 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/06/2026 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/06/2026 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/06/2026 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/06/2026 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/07/2026 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/07/2026 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/07/2026 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/07/2026 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/07/2026 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/07/2026 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/07/2026 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/07/2026 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/07/2026 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/07/2026 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/07/2026 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/07/2026 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/07/2026 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/07/2026 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/07/2026 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/07/2026 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/07/2026 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/07/2026 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/07/2026 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/07/2026 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/07/2026 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/07/2026 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/07/2026 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/07/2026 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/08/2026 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/08/2026 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/08/2026 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/08/2026 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/08/2026 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/08/2026 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/08/2026 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/08/2026 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/08/2026 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/08/2026 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/08/2026 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/08/2026 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/08/2026 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/08/2026 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/08/2026 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/08/2026 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/08/2026 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/08/2026 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/08/2026 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/08/2026 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/08/2026 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/08/2026 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/08/2026 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/08/2026 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/09/2026 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/09/2026 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/09/2026 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/09/2026 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/09/2026 04:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/09/2026 05:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/09/2026 06:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/09/2026 07:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/09/2026 08:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/09/2026 09:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/09/2026 10:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/09/2026 11:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/09/2026 12:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/09/2026 13:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/09/2026 14:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/09/2026 15:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/09/2026 16:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/09/2026 17:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/09/2026 18:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/09/2026 19:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/09/2026 20:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/09/2026 21:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/09/2026 22:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/09/2026 23:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/10/2026 00:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/10/2026 01:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/10/2026 02:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/10/2026 03:00	0.0	0.0	0.0	104,600.0	0.0	0.0	0.0	0.0
06/10/2026 04:00	1,991.0	129.8	1,991.0	104,600.0	208.3	0.0	0.0	0.0
06/10/2026 05:00	3,806.1	144.4	3,806.1	104,600.0	398.1	0.5	0.2	0.8
06/10/2026 06:00	4,022.7	273.2	4,082.8	104,600.0	427.1	0.5	0.3	0.9
06/10/2026 07:00	4,605.3	1,344.6	5,949.9	104,600.0	622.4	0.7	0.4	1.2
06/10/2026 08:00	4,538.3	1,457.4	5,995.7	104,600.0	627.2	0.8	0.4	1.3
06/10/2026 09:00	4,483.6	1,529.9	6,013.5	104,600.0	629.0	0.8	0.4	1.3
06/10/2026 10:00	4,541.4	1,459.2	6,000.6	104,600.0	627.7	0.8	0.4	1.3
06/10/2026 11:00	4,587.7	1,411.2	5,998.9	104,600.0	627.5	0.8	0.4	1.3
06/10/2026 12:00	4,561.5	1,450.4	6,011.9	104,600.0	628.8	0.8	0.4	1.3
06/10/2026 13:00	4,540.9	1,478.1	6,019.0	104,600.0	629.6	0.8	0.4	1.3
06/10/2026 14:00	4,526.5	1,495.3	6,021.8	104,600.0	629.9	0.8	0.4	1.3
06/10/2026 15:00	4,517.6	1,513.0	6,030.6	104,600.0	630.8	0.8	0.4	1.3
06/10/2026 16:00	4,515.1	1,534.3	6,049.4	104,600.0	632.8	0.8	0.4	1.3
06/10/2026 17:00	4,517.0	1,539.7	6,056.7	104,600.0	633.5	0.8	0.4	1.3
06/10/2026 18:00	4,523.9	1,517.4	6,041.3	104,600.0	631.9	0.8	0.4	1.3
06/10/2026 19:00	4,501.6	500.3	4,901.8	104,600.0	512.7	0.6	0.3	1.0
06/10/2026 20:00	3,592.8	158.3	3,592.8	104,600.0	375.8	0.5	0.2	0.8
06/10/2026 21:00	3,567.1	151.9	3,567.1	104,600.0	373.1	0.5	0.2	0.8
06/10/2026 22:00	3,569.9	148.4	3,569.9	104,600.0	373.4	0.5	0.2	0.8
06/10/2026 23:00	3,571.6	165.2	3,571.6	104,600.0	373.6	0.5	0.2	0.8
Average/Sum#:	4,154.1	970.1	5,063.6	104,600.0	529.7	0.7	0.3	1.1
Minimum:	1,991.0	129.8	1,991.0	104,600.0	208.3	0.5	0.2	0.8
Maximum:	4,605.3	1,539.7	6,056.7	104,600.0	633.5	0.8	0.4	1.3
%SI	16.67	16.67	16.67	0.00	16.67	20.83	20.83	20.83

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/11/2026 00:00	3,572.6	160.6	3,572.6	104,600.0	373.7	0.5	0.2	0.8
06/11/2026 01:00	3,572.4	160.1	3,572.4	104,600.0	373.7	0.5	0.2	0.8
06/11/2026 02:00	3,573.1	153.4	3,573.1	104,600.0	373.7	0.5	0.2	0.8
06/11/2026 03:00	3,576.4	146.8	3,576.4	104,600.0	374.1	0.5	0.2	0.8
06/11/2026 04:00	3,578.3	146.8	3,578.3	104,600.0	374.3	0.5	0.2	0.8
06/11/2026 05:00	4,124.2	256.8	4,214.1	104,600.0	440.8	0.6	0.3	0.9
06/11/2026 06:00	4,550.9	701.7	5,252.6	104,600.0	549.4	0.7	0.3	1.1
06/11/2026 07:00	4,488.4	1,509.6	5,998.0	104,600.0	627.4	0.8	0.4	1.3
06/11/2026 08:00	4,571.9	1,409.2	5,981.1	104,600.0	625.6	0.8	0.4	1.3
06/11/2026 09:00	4,595.2	1,397.3	5,992.5	104,600.0	626.8	0.8	0.4	1.3
06/11/2026 10:00	4,558.7	1,455.9	6,014.6	104,600.0	629.1	0.8	0.4	1.3
06/11/2026 11:00	4,533.8	1,511.0	6,044.8	104,600.0	632.3	0.8	0.4	1.3
06/11/2026 12:00	4,525.3	1,534.0	6,059.3	104,600.0	633.8	0.8	0.4	1.3
06/11/2026 13:00	4,497.7	1,571.2	6,068.9	104,600.0	634.8	0.8	0.4	1.3
06/11/2026 14:00	4,474.8	1,595.4	6,070.2	104,600.0	634.9	0.8	0.4	1.3
06/11/2026 15:00	4,465.1	1,608.8	6,073.9	104,600.0	635.3	0.8	0.4	1.3
06/11/2026 16:00	4,461.0	1,619.1	6,080.1	104,600.0	636.0	0.8	0.4	1.3
06/11/2026 17:00	4,453.7	1,630.0	6,083.7	104,600.0	636.4	0.8	0.4	1.3
06/11/2026 18:00	4,460.1	1,602.9	6,063.0	104,600.0	634.2	0.8	0.4	1.3
06/11/2026 19:00	4,450.0	550.6	4,890.5	104,600.0	511.5	0.6	0.3	1.0
06/11/2026 20:00	3,593.2	166.6	3,593.2	104,600.0	375.8	0.5	0.2	0.8
06/11/2026 21:00	3,839.4	162.2	3,839.4	104,600.0	401.6	0.5	0.3	0.8
06/11/2026 22:00	3,911.5	158.5	3,911.5	104,600.0	409.1	0.5	0.3	0.9
06/11/2026 23:00	3,565.1	162.4	3,565.1	104,600.0	372.9	0.5	0.2	0.8
Average/Sum#:	4,166.4	890.5	4,986.2	104,600.0	521.6	0.7	0.3	1.1
Minimum:	3,565.1	146.8	3,565.1	104,600.0	372.9	0.5	0.2	0.8
Maximum:	4,595.2	1,630.0	6,083.7	104,600.0	636.4	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/12/2026 00:00	3,569.8	159.2	3,569.8	104,600.0	373.4	0.5	0.2	0.8
06/12/2026 01:00	3,655.1	166.1	3,655.1	104,600.0	382.3	0.5	0.2	0.8
06/12/2026 02:00	3,610.9	167.6	3,610.9	104,600.0	377.7	0.5	0.2	0.8
06/12/2026 03:00	3,965.4	165.7	3,965.4	104,600.0	414.8	0.5	0.3	0.9
06/12/2026 04:00	3,689.0	162.4	3,689.0	104,600.0	385.9	0.5	0.2	0.8
06/12/2026 05:00	3,797.0	165.4	3,797.0	104,600.0	397.2	0.5	0.2	0.8
06/12/2026 06:00	3,572.8	192.4	3,572.8	104,600.0	373.7	0.5	0.2	0.8
06/12/2026 07:00	3,568.0	202.7	3,568.0	104,600.0	373.2	0.5	0.2	0.8
06/12/2026 08:00	3,565.4	188.6	3,565.4	104,600.0	372.9	0.5	0.2	0.8
06/12/2026 09:00	3,558.0	194.8	3,558.0	104,600.0	372.2	0.5	0.2	0.8
06/12/2026 10:00	3,555.2	207.5	3,555.2	104,600.0	371.9	0.5	0.2	0.8
06/12/2026 11:00	3,606.7	204.0	3,606.7	104,600.0	377.3	0.5	0.2	0.8
06/12/2026 12:00	4,300.4	201.7	4,300.4	104,600.0	449.8	0.6	0.3	0.9
06/12/2026 13:00	4,399.9	190.6	4,399.9	104,600.0	460.2	0.6	0.3	1.0
06/12/2026 14:00	4,418.3	179.0	4,418.3	104,600.0	462.2	0.6	0.3	1.0
06/12/2026 15:00	4,424.5	873.0	5,105.4	104,600.0	534.0	0.7	0.3	1.1
06/12/2026 16:00	4,418.8	515.9	4,841.8	104,600.0	506.5	0.6	0.3	1.0
06/12/2026 17:00	3,909.7	181.2	3,909.7	104,600.0	409.0	0.5	0.3	0.9
06/12/2026 18:00	4,200.2	179.3	4,200.2	104,600.0	439.3	0.6	0.3	0.9
06/12/2026 19:00	4,455.5	176.7	4,460.8	104,600.0	466.6	0.6	0.3	1.0
06/12/2026 20:00	4,516.3	565.2	5,081.5	104,600.0	531.5	0.6	0.3	1.1
06/12/2026 21:00	4,548.3	502.0	5,050.3	104,600.0	528.3	0.6	0.3	1.1
06/12/2026 22:00	4,586.5	438.3	5,024.8	104,600.0	525.6	0.6	0.3	1.1
06/12/2026 23:00	4,564.2	341.5	4,837.4	104,600.0	506.0	0.6	0.3	1.0
Average/Sum#:	4,019.0	271.7	4,139.3	104,600.0	433.0	0.6	0.3	0.9
Minimum:	3,555.2	159.2	3,555.2	104,600.0	371.9	0.5	0.2	0.8
Maximum:	4,586.5	873.0	5,105.4	104,600.0	534.0	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/13/2026 00:00	3,609.9	166.3	3,609.9	104,600.0	377.6	0.5	0.2	0.8
06/13/2026 01:00	3,584.5	164.3	3,584.5	104,600.0	374.9	0.5	0.2	0.8
06/13/2026 02:00	3,579.1	164.0	3,579.1	104,600.0	374.4	0.5	0.2	0.8
06/13/2026 03:00	3,922.5	160.1	3,922.5	104,600.0	410.3	0.5	0.3	0.9
06/13/2026 04:00	4,106.4	157.0	4,106.4	104,600.0	429.5	0.5	0.3	0.9
06/13/2026 05:00	3,801.4	166.2	3,801.4	104,600.0	397.6	0.5	0.2	0.8
06/13/2026 06:00	3,579.1	191.0	3,579.1	104,600.0	374.4	0.5	0.2	0.8
06/13/2026 07:00	3,574.4	202.4	3,574.4	104,600.0	373.9	0.5	0.2	0.8
06/13/2026 08:00	3,571.8	191.8	3,571.8	104,600.0	373.6	0.5	0.2	0.8
06/13/2026 09:00	3,567.3	200.2	3,567.3	104,600.0	373.1	0.5	0.2	0.8
06/13/2026 10:00	3,564.1	201.4	3,564.1	104,600.0	372.8	0.5	0.2	0.8
06/13/2026 11:00	3,558.5	206.3	3,558.5	104,600.0	372.2	0.5	0.2	0.8
06/13/2026 12:00	3,551.2	208.1	3,551.2	104,600.0	371.5	0.5	0.2	0.8
06/13/2026 13:00	3,548.2	194.5	3,548.2	104,600.0	371.1	0.5	0.2	0.8
06/13/2026 14:00	3,544.6	180.5	3,544.6	104,600.0	370.8	0.5	0.2	0.8
06/13/2026 15:00	3,543.3	178.1	3,543.3	104,600.0	370.6	0.5	0.2	0.8
06/13/2026 16:00	3,976.9	183.4	3,976.9	104,600.0	416.0	0.5	0.3	0.9
06/13/2026 17:00	4,043.5	178.6	4,043.5	104,600.0	423.0	0.5	0.3	0.9
06/13/2026 18:00	4,426.6	266.9	4,488.0	104,600.0	469.4	0.6	0.3	1.0
06/13/2026 19:00	4,542.7	1,742.0	6,284.7	104,600.0	657.4	0.8	0.4	1.3
06/13/2026 20:00	4,562.3	1,322.9	5,885.2	104,600.0	615.6	0.7	0.4	1.2
06/13/2026 21:00	4,584.3	1,346.3	5,930.6	104,600.0	620.3	0.7	0.4	1.2
06/13/2026 22:00	4,622.1	1,766.1	6,388.2	104,600.0	668.2	0.8	0.4	1.3
06/13/2026 23:00	4,650.9	1,739.4	6,390.3	104,600.0	668.4	0.8	0.4	1.3
Average/Sum#:	3,900.7	478.2	4,233.1	104,600.0	442.8	0.6	0.3	0.9
Minimum:	3,543.3	157.0	3,543.3	104,600.0	370.6	0.5	0.2	0.8
Maximum:	4,650.9	1,766.1	6,390.3	104,600.0	668.4	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/14/2026 00:00	4,676.8	383.3	5,060.1	104,600.0	529.3	0.6	0.3	1.1
06/14/2026 01:00	4,668.9	257.7	4,862.2	104,600.0	508.6	0.6	0.3	1.0
06/14/2026 02:00	4,103.9	161.2	4,103.9	104,600.0	429.3	0.5	0.3	0.9
06/14/2026 03:00	3,588.7	156.2	3,588.7	104,600.0	375.4	0.5	0.2	0.8
06/14/2026 04:00	3,591.2	151.7	3,591.2	104,600.0	375.6	0.5	0.2	0.8
06/14/2026 05:00	3,595.1	153.1	3,595.1	104,600.0	376.0	0.5	0.2	0.8
06/14/2026 06:00	3,594.7	175.6	3,594.7	104,600.0	376.0	0.5	0.2	0.8
06/14/2026 07:00	3,590.6	191.0	3,590.6	104,600.0	375.6	0.5	0.2	0.8
06/14/2026 08:00	3,588.3	192.0	3,588.3	104,600.0	375.3	0.5	0.2	0.8
06/14/2026 09:00	3,580.9	189.4	3,580.9	104,600.0	374.6	0.5	0.2	0.8
06/14/2026 10:00	3,576.9	200.1	3,576.9	104,600.0	374.1	0.5	0.2	0.8
06/14/2026 11:00	3,570.5	211.4	3,570.5	104,600.0	373.5	0.5	0.2	0.8
06/14/2026 12:00	3,566.7	211.2	3,566.7	104,600.0	373.1	0.5	0.2	0.8
06/14/2026 13:00	3,554.0	198.0	3,554.0	104,600.0	371.7	0.5	0.2	0.8
06/14/2026 14:00	3,547.4	176.1	3,547.4	104,600.0	371.1	0.5	0.2	0.8
06/14/2026 15:00	3,541.8	175.9	3,541.8	104,600.0	370.5	0.5	0.2	0.8
06/14/2026 16:00	4,289.3	180.4	4,289.3	104,600.0	448.7	0.6	0.3	0.9
06/14/2026 17:00	4,095.7	175.1	4,095.7	104,600.0	428.4	0.5	0.3	0.9
06/14/2026 18:00	4,356.5	171.2	4,356.5	104,600.0	455.7	0.6	0.3	0.9
06/14/2026 19:00	4,348.3	163.1	4,348.3	104,600.0	454.8	0.6	0.3	0.9
06/14/2026 20:00	4,208.4	159.3	4,208.4	104,600.0	440.2	0.5	0.3	0.9
06/14/2026 21:00	4,151.3	167.0	4,151.3	104,600.0	434.2	0.5	0.3	0.9
06/14/2026 22:00	3,710.1	169.5	3,710.1	104,600.0	388.1	0.5	0.2	0.8
06/14/2026 23:00	3,729.1	162.5	3,729.1	104,600.0	390.1	0.5	0.2	0.8
Average/Sum#:	3,867.7	188.8	3,891.7	104,600.0	407.1	0.5	0.2	0.9
Minimum:	3,541.8	151.7	3,541.8	104,600.0	370.5	0.5	0.2	0.8
Maximum:	4,676.8	383.3	5,060.1	104,600.0	529.3	0.6	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/15/2026 00:00	3,745.0	156.5	3,745.0	104,600.0	391.7	0.5	0.2	0.8
06/15/2026 01:00	3,606.0	152.5	3,606.0	104,600.0	377.2	0.5	0.2	0.8
06/15/2026 02:00	3,576.7	150.7	3,576.7	104,600.0	374.1	0.5	0.2	0.8
06/15/2026 03:00	3,579.2	148.1	3,579.2	104,600.0	374.4	0.5	0.2	0.8
06/15/2026 04:00	3,581.2	145.6	3,581.2	104,600.0	374.6	0.5	0.2	0.8
06/15/2026 05:00	3,584.3	152.1	3,584.3	104,600.0	374.9	0.5	0.2	0.8
06/15/2026 06:00	3,584.0	102.4	3,584.0	104,600.0	374.9	0.5	0.2	0.8
06/15/2026 07:00	3,582.2	44.3	3,582.2	104,600.0	374.7	0.5	0.2	0.8
06/15/2026 08:00	3,578.8	37.2	3,578.8	104,600.0	374.3	0.5	0.2	0.8
06/15/2026 09:00	3,578.5	84.3	3,578.5	104,600.0	374.3	0.5	0.2	0.8
06/15/2026 10:00	3,572.8	97.2	3,572.8	104,600.0	373.7	0.5	0.2	0.8
06/15/2026 11:00	3,569.3	119.4	3,569.3	104,600.0	373.3	0.5	0.2	0.8
06/15/2026 12:00	3,567.7	113.0	3,567.7	104,600.0	373.2	0.5	0.2	0.8
06/15/2026 13:00	3,560.1	93.6	3,560.1	104,600.0	372.4	0.5	0.2	0.8
06/15/2026 14:00	3,948.9	17.3	3,948.9	104,600.0	413.1	0.5	0.2	0.8
06/15/2026 15:00	4,162.0	0.0	4,162.0	104,600.0	435.3	0.5	0.3	0.9
06/15/2026 16:00	3,960.1	18.3	3,960.1	104,600.0	414.2	0.5	0.2	0.8
06/15/2026 17:00	4,095.5	64.8	4,107.2	104,600.0	429.6	0.5	0.3	0.9
06/15/2026 18:00	4,529.4	706.6	5,236.0	104,600.0	547.7	0.7	0.3	1.1
06/15/2026 19:00	4,298.9	185.4	4,395.3	104,600.0	459.7	0.6	0.3	0.9
06/15/2026 20:00	3,603.5	0.0	3,603.5	104,600.0	376.9	0.5	0.2	0.8
06/15/2026 21:00	3,623.8	0.0	3,623.8	104,600.0	379.0	0.5	0.2	0.8
06/15/2026 22:00	3,915.1	0.0	3,915.1	104,600.0	409.5	0.5	0.2	0.8
06/15/2026 23:00	4,606.2	259.6	4,852.8	104,600.0	507.6	0.6	0.3	1.0
Average/Sum#:	3,792.1	118.7	3,836.3	104,600.0	401.3	0.5	0.2	0.8
Minimum:	3,560.1	0.0	3,560.1	104,600.0	372.4	0.5	0.2	0.8
Maximum:	4,606.2	706.6	5,236.0	104,600.0	547.7	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/16/2026 00:00	4,657.0	235.1	4,892.1	104,600.0	511.7	0.6	0.3	1.0
06/16/2026 01:00	4,680.0	198.6	4,878.6	104,600.0	510.3	0.6	0.3	1.0
06/16/2026 02:00	4,698.9	163.2	4,862.1	104,600.0	508.6	0.6	0.3	1.0
06/16/2026 03:00	4,709.4	52.6	4,762.0	104,600.0	498.1	0.6	0.3	1.0
06/16/2026 04:00	3,735.6	0.0	3,735.6	104,600.0	390.7	0.5	0.2	0.8
06/16/2026 05:00	3,599.9	0.0	3,599.9	104,600.0	376.5	0.5	0.2	0.8
06/16/2026 06:00	3,849.2	0.3	3,849.2	104,600.0	402.6	0.5	0.2	0.8
06/16/2026 07:00	4,724.5	893.8	5,591.5	104,600.0	584.9	0.7	0.4	1.2
06/16/2026 08:00	4,704.8	986.0	5,690.8	104,600.0	595.3	0.7	0.4	1.2
06/16/2026 09:00	4,673.9	1,020.4	5,694.3	104,600.0	595.6	0.7	0.4	1.2
06/16/2026 10:00	4,639.8	1,058.4	5,698.2	104,600.0	596.0	0.7	0.4	1.2
06/16/2026 11:00	4,594.2	1,112.3	5,706.5	104,600.0	596.9	0.7	0.4	1.2
06/16/2026 12:00	4,558.1	1,161.3	5,719.4	104,600.0	598.2	0.7	0.4	1.2
06/16/2026 13:00	4,520.3	1,201.9	5,722.2	104,600.0	598.5	0.7	0.4	1.2
06/16/2026 14:00	4,505.9	1,486.6	5,992.5	104,600.0	626.8	0.8	0.4	1.3
06/16/2026 15:00	4,486.2	1,655.8	6,142.0	104,600.0	642.5	0.8	0.4	1.3
06/16/2026 16:00	4,490.1	1,628.6	6,118.7	104,600.0	640.0	0.8	0.4	1.3
06/16/2026 17:00	4,498.2	684.9	5,183.1	104,600.0	542.2	0.6	0.3	1.1
06/16/2026 18:00	4,543.5	451.1	4,994.6	104,600.0	522.4	0.6	0.3	1.0
06/16/2026 19:00	4,572.9	407.2	4,980.1	104,600.0	520.9	0.6	0.3	1.0
06/16/2026 20:00	4,613.1	339.4	4,952.5	104,600.0	518.0	0.6	0.3	1.0
06/16/2026 21:00	4,647.4	282.9	4,930.3	104,600.0	515.7	0.6	0.3	1.0
06/16/2026 22:00	4,671.8	260.8	4,932.6	104,600.0	515.9	0.6	0.3	1.0
06/16/2026 23:00	4,687.3	236.3	4,923.6	104,600.0	515.0	0.6	0.3	1.0
Average/Sum#:	4,502.6	646.6	5,148.0	104,600.0	538.5	0.6	0.3	1.1
Minimum:	3,599.9	0.0	3,599.9	104,600.0	376.5	0.5	0.2	0.8
Maximum:	4,724.5	1,655.8	6,142.0	104,600.0	642.5	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/17/2026 00:00	4,705.6	207.4	4,913.0	104,600.0	513.9	0.6	0.3	1.0
06/17/2026 01:00	4,713.8	190.1	4,903.9	104,600.0	512.9	0.6	0.3	1.0
06/17/2026 02:00	4,712.0	174.5	4,886.5	104,600.0	511.1	0.6	0.3	1.0
06/17/2026 03:00	4,714.5	167.4	4,881.9	104,600.0	510.6	0.6	0.3	1.0
06/17/2026 04:00	4,718.2	160.9	4,879.1	104,600.0	510.4	0.6	0.3	1.0
06/17/2026 05:00	4,371.0	80.6	4,412.9	104,600.0	461.6	0.6	0.3	0.9
06/17/2026 06:00	3,833.9	0.1	3,833.9	104,600.0	401.0	0.5	0.2	0.8
06/17/2026 07:00	4,684.6	1,187.1	5,836.1	104,600.0	610.5	0.7	0.4	1.2
06/17/2026 08:00	4,669.4	1,317.5	5,986.9	104,600.0	626.2	0.8	0.4	1.3
06/17/2026 09:00	4,640.4	1,361.4	6,001.8	104,600.0	627.8	0.8	0.4	1.3
06/17/2026 10:00	4,602.8	1,421.3	6,024.1	104,600.0	630.1	0.8	0.4	1.3
06/17/2026 11:00	4,571.5	1,475.5	6,047.0	104,600.0	632.5	0.8	0.4	1.3
06/17/2026 12:00	4,542.6	1,523.0	6,065.6	104,600.0	634.5	0.8	0.4	1.3
06/17/2026 13:00	4,513.7	1,564.6	6,078.3	104,600.0	635.8	0.8	0.4	1.3
06/17/2026 14:00	4,488.1	1,593.1	6,081.2	104,600.0	636.1	0.8	0.4	1.3
06/17/2026 15:00	4,482.6	1,599.6	6,082.2	104,600.0	636.2	0.8	0.4	1.3
06/17/2026 16:00	4,480.7	1,599.5	6,080.2	104,600.0	636.0	0.8	0.4	1.3
06/17/2026 17:00	4,505.4	675.0	5,180.4	104,600.0	541.9	0.7	0.3	1.1
06/17/2026 18:00	4,538.6	434.2	4,972.8	104,600.0	520.2	0.6	0.3	1.0
06/17/2026 19:00	4,574.6	385.5	4,960.1	104,600.0	518.8	0.6	0.3	1.0
06/17/2026 20:00	4,619.5	312.0	4,931.5	104,600.0	515.8	0.6	0.3	1.0
06/17/2026 21:00	4,649.1	266.2	4,915.3	104,600.0	514.1	0.6	0.3	1.0
06/17/2026 22:00	4,673.2	232.3	4,905.5	104,600.0	513.1	0.6	0.3	1.0
06/17/2026 23:00	4,691.3	198.9	4,890.2	104,600.0	511.5	0.6	0.3	1.0
Average/Sum#:	4,570.7	755.3	5,322.9	104,600.0	556.8	0.7	0.3	1.1
Minimum:	3,833.9	0.1	3,833.9	104,600.0	401.0	0.5	0.2	0.8
Maximum:	4,718.2	1,599.6	6,082.2	104,600.0	636.2	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/18/2026 00:00	4,706.2	175.1	4,881.3	104,600.0	510.6	0.6	0.3	1.0
06/18/2026 01:00	4,708.0	170.7	4,878.7	104,600.0	510.3	0.6	0.3	1.0
06/18/2026 02:00	4,718.7	159.4	4,878.1	104,600.0	510.2	0.6	0.3	1.0
06/18/2026 03:00	4,723.6	161.8	4,885.4	104,600.0	511.0	0.6	0.3	1.0
06/18/2026 04:00	4,726.8	237.5	4,964.3	104,600.0	519.3	0.6	0.3	1.0
06/18/2026 05:00	4,642.9	393.8	4,946.1	104,600.0	517.4	0.6	0.3	1.1
06/18/2026 06:00	3,605.1	0.0	3,605.1	104,600.0	377.1	0.5	0.2	0.8
06/18/2026 07:00	3,585.1	1.1	3,585.1	104,600.0	375.0	0.5	0.2	0.7
06/18/2026 08:00	3,582.6	23.8	3,582.6	104,600.0	374.7	0.5	0.2	0.8
06/18/2026 09:00	3,579.3	95.5	3,579.3	104,600.0	374.4	0.5	0.2	0.8
06/18/2026 10:00	3,577.4	75.7	3,577.4	104,600.0	374.2	0.5	0.2	0.8
06/18/2026 11:00	3,574.4	142.7	3,574.4	104,600.0	373.9	0.5	0.2	0.8
06/18/2026 12:00	3,571.4	118.1	3,571.4	104,600.0	373.6	0.5	0.2	0.8
06/18/2026 13:00	3,569.6	87.4	3,569.6	104,600.0	373.4	0.5	0.2	0.8
06/18/2026 14:00	3,568.7	0.0	3,568.7	104,600.0	373.3	0.5	0.2	0.7
06/18/2026 15:00	3,570.6	0.0	3,570.6	104,600.0	373.5	0.4	0.2	0.7
06/18/2026 16:00	3,571.1	0.1	3,571.1	104,600.0	373.5	0.5	0.2	0.7
06/18/2026 17:00	4,082.8	106.7	4,111.6	104,600.0	430.1	0.5	0.3	0.9
06/18/2026 18:00	4,626.9	801.6	5,428.5	104,600.0	567.8	0.7	0.3	1.1
06/18/2026 19:00	4,560.7	1,231.9	5,792.6	104,600.0	605.9	0.7	0.4	1.2
06/18/2026 20:00	4,579.1	1,156.4	5,735.5	104,600.0	599.9	0.7	0.4	1.2
06/18/2026 21:00	4,624.8	311.6	4,936.4	104,600.0	516.3	0.6	0.3	1.0
06/18/2026 22:00	4,655.0	335.7	4,990.7	104,600.0	522.0	0.6	0.3	1.0
06/18/2026 23:00	4,678.0	427.7	5,105.7	104,600.0	534.1	0.6	0.3	1.1
Average/Sum#:	4,141.2	258.9	4,370.4	104,600.0	457.1	0.6	0.3	0.9
Minimum:	3,568.7	0.0	3,568.7	104,600.0	373.3	0.4	0.2	0.7
Maximum:	4,726.8	1,231.9	5,792.6	104,600.0	605.9	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/19/2026 00:00	4,686.2	449.0	5,135.2	104,600.0	537.1	0.6	0.3	1.1
06/19/2026 01:00	4,690.1	212.8	4,902.9	104,600.0	512.8	0.6	0.3	1.0
06/19/2026 02:00	4,697.5	201.1	4,898.6	104,600.0	512.4	0.6	0.3	1.0
06/19/2026 03:00	4,705.1	193.0	4,898.1	104,600.0	512.3	0.6	0.3	1.0
06/19/2026 04:00	4,708.9	178.5	4,887.4	104,600.0	511.2	0.6	0.3	1.0
06/19/2026 05:00	3,902.8	1.2	3,902.8	104,600.0	408.2	0.5	0.2	0.8
06/19/2026 06:00	3,703.8	5.0	3,704.1	104,600.0	387.4	0.5	0.2	0.8
06/19/2026 07:00	3,625.5	0.0	3,625.5	104,600.0	379.2	0.5	0.2	0.8
06/19/2026 08:00	3,634.4	28.5	3,634.4	104,600.0	380.2	0.5	0.2	0.8
06/19/2026 09:00	3,630.8	19.1	3,630.8	104,600.0	379.8	0.5	0.2	0.8
06/19/2026 10:00	3,602.8	104.5	3,602.8	104,600.0	376.9	0.5	0.2	0.8
06/19/2026 11:00	3,594.8	119.6	3,594.8	104,600.0	376.0	0.5	0.2	0.8
06/19/2026 12:00	3,586.9	106.7	3,586.9	104,600.0	375.2	0.5	0.2	0.8
06/19/2026 13:00	3,591.9	95.9	3,591.9	104,600.0	375.7	0.5	0.2	0.8
06/19/2026 14:00	3,651.6	0.0	3,651.6	104,600.0	382.0	0.5	0.2	0.8
06/19/2026 15:00	3,976.0	0.0	3,976.0	104,600.0	415.9	0.5	0.2	0.8
06/19/2026 16:00	3,845.1	7.5	3,845.1	104,600.0	402.2	0.5	0.2	0.8
06/19/2026 17:00	3,788.5	0.0	3,788.5	104,600.0	396.3	0.5	0.2	0.8
06/19/2026 18:00	4,074.4	0.0	4,074.4	104,600.0	426.2	0.5	0.3	0.9
06/19/2026 19:00	4,029.6	0.0	4,029.6	104,600.0	421.5	0.5	0.3	0.8
06/19/2026 20:00	3,662.6	0.0	3,662.6	104,600.0	383.1	0.5	0.2	0.8
06/19/2026 21:00	3,636.7	0.0	3,636.7	104,600.0	380.4	0.5	0.2	0.8
06/19/2026 22:00	3,633.7	0.0	3,633.7	104,600.0	380.1	0.5	0.2	0.8
06/19/2026 23:00	3,616.5	0.0	3,616.5	104,600.0	378.3	0.5	0.2	0.8
Average/Sum#:	3,928.2	71.8	3,979.6	104,600.0	416.3	0.5	0.2	0.9
Minimum:	3,586.9	0.0	3,586.9	104,600.0	375.2	0.5	0.2	0.8
Maximum:	4,708.9	449.0	5,135.2	104,600.0	537.1	0.6	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/20/2026 00:00	3,606.4	0.0	3,606.4	104,600.0	377.2	0.5	0.2	0.8
06/20/2026 01:00	3,603.9	0.0	3,603.9	104,600.0	377.0	0.5	0.2	0.8
06/20/2026 02:00	3,614.5	0.0	3,614.5	104,600.0	378.1	0.5	0.2	0.8
06/20/2026 03:00	3,614.1	0.0	3,614.1	104,600.0	378.0	0.5	0.2	0.8
06/20/2026 04:00	3,620.2	0.0	3,620.2	104,600.0	378.7	0.5	0.2	0.8
06/20/2026 05:00	3,861.9	0.0	3,861.9	104,600.0	404.0	0.5	0.2	0.8
06/20/2026 06:00	3,607.0	0.0	3,607.0	104,600.0	377.3	0.5	0.2	0.8
06/20/2026 07:00	3,612.3	26.2	3,612.3	104,600.0	377.8	0.5	0.2	0.8
06/20/2026 08:00	3,622.6	20.5	3,622.6	104,600.0	378.9	0.5	0.2	0.8
06/20/2026 09:00	3,626.7	74.1	3,626.7	104,600.0	379.4	0.5	0.2	0.8
06/20/2026 10:00	3,610.2	87.8	3,610.2	104,600.0	377.6	0.5	0.2	0.8
06/20/2026 11:00	3,608.2	116.2	3,608.2	104,600.0	377.4	0.5	0.2	0.8
06/20/2026 12:00	3,611.4	111.8	3,611.4	104,600.0	377.8	0.5	0.2	0.8
06/20/2026 13:00	3,610.8	89.9	3,610.8	104,600.0	377.7	0.5	0.2	0.8
06/20/2026 14:00	3,607.7	0.0	3,607.7	104,600.0	377.4	0.5	0.2	0.8
06/20/2026 15:00	3,604.8	0.0	3,604.8	104,600.0	377.1	0.5	0.2	0.8
06/20/2026 16:00	3,584.7	5.3	3,584.7	104,600.0	375.0	0.5	0.2	0.8
06/20/2026 17:00	3,648.7	0.0	3,648.7	104,600.0	381.7	0.5	0.2	0.8
06/20/2026 18:00	3,601.6	0.0	3,601.6	104,600.0	376.7	0.5	0.2	0.8
06/20/2026 19:00	3,595.6	0.0	3,595.6	104,600.0	376.1	0.5	0.2	0.8
06/20/2026 20:00	3,592.8	0.0	3,592.8	104,600.0	375.8	0.5	0.2	0.8
06/20/2026 21:00	3,606.3	0.0	3,606.3	104,600.0	377.2	0.5	0.2	0.8
06/20/2026 22:00	3,619.4	0.0	3,619.4	104,600.0	378.6	0.5	0.2	0.8
06/20/2026 23:00	3,620.2	0.0	3,620.2	104,600.0	378.7	0.5	0.2	0.8
Average/Sum#:	3,621.3	22.2	3,621.3	104,600.0	378.8	0.5	0.2	0.8
Minimum:	3,584.7	0.0	3,584.7	104,600.0	375.0	0.5	0.2	0.8
Maximum:	3,861.9	116.2	3,861.9	104,600.0	404.0	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/21/2026 00:00	3,614.5	0.0	3,614.5	104,600.0	378.1	0.5	0.2	0.8
06/21/2026 01:00	3,618.1	0.0	3,618.1	104,600.0	378.5	0.5	0.2	0.8
06/21/2026 02:00	3,615.9	0.0	3,615.9	104,600.0	378.2	0.5	0.2	0.8
06/21/2026 03:00	3,621.4	0.0	3,621.4	104,600.0	378.8	0.5	0.2	0.8
06/21/2026 04:00	3,622.8	0.0	3,622.8	104,600.0	378.9	0.5	0.2	0.8
06/21/2026 05:00	3,624.0	0.0	3,624.0	104,600.0	379.1	0.5	0.2	0.8
06/21/2026 06:00	3,627.1	0.0	3,627.1	104,600.0	379.4	0.5	0.2	0.8
06/21/2026 07:00	3,627.1	0.0	3,627.1	104,600.0	379.4	0.5	0.2	0.8
06/21/2026 08:00	3,632.7	21.5	3,632.7	104,600.0	380.0	0.5	0.2	0.8
06/21/2026 09:00	3,608.0	93.4	3,608.0	104,600.0	377.4	0.5	0.2	0.8
06/21/2026 10:00	3,598.2	128.8	3,598.2	104,600.0	376.4	0.5	0.2	0.8
06/21/2026 11:00	3,599.9	121.4	3,599.9	104,600.0	376.5	0.5	0.2	0.8
06/21/2026 12:00	3,605.1	116.6	3,605.1	104,600.0	377.1	0.5	0.2	0.8
06/21/2026 13:00	3,601.4	71.9	3,601.4	104,600.0	376.7	0.5	0.2	0.8
06/21/2026 14:00	3,597.7	3.8	3,597.7	104,600.0	376.3	0.5	0.2	0.8
06/21/2026 15:00	3,587.2	0.0	3,587.2	104,600.0	375.2	0.5	0.2	0.8
06/21/2026 16:00	3,576.2	5.8	3,576.2	104,600.0	374.1	0.5	0.2	0.7
06/21/2026 17:00	3,841.4	0.0	3,841.4	104,600.0	401.8	0.5	0.2	0.8
06/21/2026 18:00	4,140.5	0.0	4,140.5	104,600.0	433.1	0.5	0.3	0.9
06/21/2026 19:00	4,374.3	0.0	4,374.3	104,600.0	457.6	0.5	0.3	0.9
06/21/2026 20:00	4,140.5	0.0	4,140.5	104,600.0	433.1	0.5	0.3	0.9
06/21/2026 21:00	4,189.8	0.0	4,189.8	104,600.0	438.3	0.5	0.3	0.9
06/21/2026 22:00	4,362.0	0.0	4,362.0	104,600.0	456.3	0.5	0.3	0.9
06/21/2026 23:00	4,354.1	0.0	4,354.1	104,600.0	455.4	0.5	0.3	0.9
Average/Sum#:	3,782.5	23.5	3,782.5	104,600.0	395.7	0.5	0.2	0.8
Minimum:	3,576.2	0.0	3,576.2	104,600.0	374.1	0.5	0.2	0.7
Maximum:	4,374.3	128.8	4,374.3	104,600.0	457.6	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/22/2026 00:00	3,847.7	0.0	3,847.7	104,600.0	402.5	0.5	0.2	0.8
06/22/2026 01:00	3,616.0	0.0	3,616.0	104,600.0	378.2	0.5	0.2	0.8
06/22/2026 02:00	3,626.0	0.0	3,626.0	104,600.0	379.3	0.5	0.2	0.8
06/22/2026 03:00	3,630.9	0.0	3,630.9	104,600.0	379.8	0.5	0.2	0.8
06/22/2026 04:00	3,636.9	0.0	3,636.9	104,600.0	380.4	0.5	0.2	0.8
06/22/2026 05:00	3,742.1	0.0	3,742.1	104,600.0	391.4	0.5	0.2	0.8
06/22/2026 06:00	3,611.6	0.3	3,611.6	104,600.0	377.8	0.5	0.2	0.8
06/22/2026 07:00	3,622.5	0.5	3,622.5	104,600.0	378.9	0.5	0.2	0.8
06/22/2026 08:00	3,603.1	35.5	3,603.1	104,600.0	376.9	0.5	0.2	0.8
06/22/2026 09:00	3,957.5	81.6	3,957.5	104,600.0	414.0	0.5	0.3	0.8
06/22/2026 10:00	3,932.2	135.1	3,932.2	104,600.0	411.3	0.5	0.3	0.9
06/22/2026 11:00	3,769.6	121.5	3,769.6	104,600.0	394.3	0.5	0.2	0.8
06/22/2026 12:00	3,636.3	118.0	3,636.3	104,600.0	380.4	0.5	0.2	0.8
06/22/2026 13:00	3,613.0	85.6	3,613.0	104,600.0	377.9	0.5	0.2	0.8
06/22/2026 14:00	3,591.7	13.0	3,591.7	104,600.0	375.7	0.5	0.2	0.8
06/22/2026 15:00	3,574.4	0.0	3,574.4	104,600.0	373.9	0.4	0.2	0.7
06/22/2026 16:00	3,681.3	11.1	3,681.6	104,600.0	385.1	0.5	0.2	0.8
06/22/2026 17:00	3,891.0	0.0	3,891.0	104,600.0	407.0	0.5	0.2	0.8
06/22/2026 18:00	4,390.6	0.0	4,390.6	104,600.0	459.3	0.6	0.3	0.9
06/22/2026 19:00	3,804.2	0.0	3,804.2	104,600.0	397.9	0.5	0.2	0.8
06/22/2026 20:00	3,602.7	0.0	3,602.7	104,600.0	376.8	0.5	0.2	0.8
06/22/2026 21:00	3,595.8	0.0	3,595.8	104,600.0	376.1	0.5	0.2	0.8
06/22/2026 22:00	3,617.1	0.0	3,617.1	104,600.0	378.3	0.5	0.2	0.8
06/22/2026 23:00	3,614.2	0.0	3,614.2	104,600.0	378.0	0.5	0.2	0.8
Average/Sum#:	3,717.0	25.1	3,717.0	104,600.0	388.8	0.5	0.2	0.8
Minimum:	3,574.4	0.0	3,574.4	104,600.0	373.9	0.4	0.2	0.7
Maximum:	4,390.6	135.1	4,390.6	104,600.0	459.3	0.6	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/23/2026 00:00	3,619.8	0.0	3,619.8	104,600.0	378.6	0.5	0.2	0.8
06/23/2026 01:00	3,620.8	0.0	3,620.8	104,600.0	378.7	0.5	0.2	0.8
06/23/2026 02:00	3,623.7	0.0	3,623.7	104,600.0	379.0	0.5	0.2	0.8
06/23/2026 03:00	3,621.7	0.0	3,621.7	104,600.0	378.8	0.5	0.2	0.8
06/23/2026 04:00	3,618.5	0.0	3,618.5	104,600.0	378.5	0.5	0.2	0.8
06/23/2026 05:00	3,615.9	0.0	3,615.9	104,600.0	378.2	0.5	0.2	0.8
06/23/2026 06:00	3,680.0	0.0	3,680.0	104,600.0	384.9	0.5	0.2	0.8
06/23/2026 07:00	3,614.9	3.3	3,614.9	104,600.0	378.1	0.5	0.2	0.8
06/23/2026 08:00	3,613.5	29.4	3,613.5	104,600.0	378.0	0.5	0.2	0.8
06/23/2026 09:00	3,609.1	51.3	3,609.1	104,600.0	377.5	0.5	0.2	0.8
06/23/2026 10:00	3,591.1	116.2	3,591.1	104,600.0	375.6	0.5	0.2	0.8
06/23/2026 11:00	3,583.5	109.7	3,583.5	104,600.0	374.8	0.5	0.2	0.8
06/23/2026 12:00	3,582.7	129.8	3,582.7	104,600.0	374.8	0.5	0.2	0.8
06/23/2026 13:00	3,566.3	100.7	3,566.3	104,600.0	373.0	0.5	0.2	0.8
06/23/2026 14:00	3,732.2	15.8	3,732.2	104,600.0	390.4	0.5	0.2	0.8
06/23/2026 15:00	3,850.6	0.0	3,850.6	104,600.0	402.8	0.5	0.2	0.8
06/23/2026 16:00	3,948.7	17.4	3,948.7	104,600.0	413.0	0.5	0.2	0.8
06/23/2026 17:00	4,100.8	0.0	4,100.8	104,600.0	428.9	0.5	0.3	0.9
06/23/2026 18:00	4,274.8	0.0	4,274.8	104,600.0	447.1	0.5	0.3	0.9
06/23/2026 19:00	4,356.3	0.0	4,356.3	104,600.0	455.7	0.5	0.3	0.9
06/23/2026 20:00	4,357.3	0.0	4,357.3	104,600.0	455.8	0.5	0.3	0.9
06/23/2026 21:00	4,165.3	0.0	4,165.3	104,600.0	435.7	0.5	0.3	0.9
06/23/2026 22:00	4,068.1	0.0	4,068.1	104,600.0	425.5	0.5	0.3	0.9
06/23/2026 23:00	4,202.4	0.0	4,202.4	104,600.0	439.6	0.5	0.3	0.9
Average/Sum#:	3,817.4	23.9	3,817.4	104,600.0	399.3	0.5	0.2	0.8
Minimum:	3,566.3	0.0	3,566.3	104,600.0	373.0	0.5	0.2	0.8
Maximum:	4,357.3	129.8	4,357.3	104,600.0	455.8	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/24/2026 00:00	3,928.8	0.0	3,928.8	104,600.0	411.0	0.5	0.2	0.8
06/24/2026 01:00	3,738.1	0.0	3,738.1	104,600.0	391.0	0.5	0.2	0.8
06/24/2026 02:00	3,611.0	0.0	3,611.0	104,600.0	377.7	0.5	0.2	0.8
06/24/2026 03:00	3,614.3	0.0	3,614.3	104,600.0	378.1	0.5	0.2	0.8
06/24/2026 04:00	3,677.4	0.0	3,677.4	104,600.0	384.7	0.5	0.2	0.8
06/24/2026 05:00	4,263.2	0.0	4,263.2	104,600.0	445.9	0.5	0.3	0.9
06/24/2026 06:00	3,669.8	0.9	3,669.8	104,600.0	383.9	0.5	0.2	0.8
06/24/2026 07:00	3,611.9	0.0	3,611.9	104,600.0	377.8	0.5	0.2	0.8
06/24/2026 08:00	3,601.7	52.0	3,601.7	104,600.0	376.7	0.5	0.2	0.8
06/24/2026 09:00	3,606.0	84.9	3,606.0	104,600.0	377.2	0.5	0.2	0.8
06/24/2026 10:00	3,586.7	97.2	3,586.7	104,600.0	375.2	0.5	0.2	0.8
06/24/2026 11:00	3,568.5	119.7	3,568.5	104,600.0	373.3	0.5	0.2	0.8
06/24/2026 12:00	3,887.3	135.2	3,887.3	104,600.0	406.6	0.5	0.3	0.8
06/24/2026 13:00	4,108.0	101.4	4,108.0	104,600.0	429.7	0.5	0.3	0.9
06/24/2026 14:00	4,224.7	9.4	4,224.7	104,600.0	441.9	0.5	0.3	0.9
06/24/2026 15:00	4,097.5	0.0	4,097.5	104,600.0	428.6	0.5	0.3	0.9
06/24/2026 16:00	3,973.2	13.9	3,973.2	104,600.0	415.6	0.5	0.3	0.8
06/24/2026 17:00	3,790.3	0.0	3,790.3	104,600.0	396.5	0.5	0.2	0.8
06/24/2026 18:00	3,692.1	0.0	3,692.1	104,600.0	386.2	0.5	0.2	0.8
06/24/2026 19:00	3,586.8	0.0	3,586.8	104,600.0	375.2	0.5	0.2	0.8
06/24/2026 20:00	3,593.6	0.0	3,593.6	104,600.0	375.9	0.5	0.2	0.8
06/24/2026 21:00	3,597.6	0.0	3,597.6	104,600.0	376.3	0.5	0.2	0.8
06/24/2026 22:00	3,592.9	0.0	3,592.9	104,600.0	375.8	0.5	0.2	0.8
06/24/2026 23:00	3,584.1	0.0	3,584.1	104,600.0	374.9	0.5	0.2	0.7
Average/Sum#:	3,758.6	25.6	3,758.6	104,600.0	393.2	0.5	0.2	0.8
Minimum:	3,568.5	0.0	3,568.5	104,600.0	373.3	0.5	0.2	0.7
Maximum:	4,263.2	135.2	4,263.2	104,600.0	445.9	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/25/2026 00:00	3,583.8	0.0	3,583.8	104,600.0	374.9	0.5	0.2	0.8
06/25/2026 01:00	3,586.5	0.0	3,586.5	104,600.0	375.1	0.5	0.2	0.8
06/25/2026 02:00	3,588.7	0.0	3,588.7	104,600.0	375.4	0.5	0.2	0.8
06/25/2026 03:00	3,591.4	0.0	3,591.4	104,600.0	375.7	0.5	0.2	0.8
06/25/2026 04:00	3,846.4	0.0	3,846.4	104,600.0	402.3	0.5	0.2	0.8
06/25/2026 05:00	3,968.3	0.0	3,968.3	104,600.0	415.1	0.5	0.2	0.8
06/25/2026 06:00	3,580.8	0.0	3,580.8	104,600.0	374.6	0.5	0.2	0.8
06/25/2026 07:00	3,567.4	0.0	3,567.4	104,600.0	373.2	0.4	0.2	0.7
06/25/2026 08:00	3,579.3	12.9	3,579.3	104,600.0	374.4	0.5	0.2	0.8
06/25/2026 09:00	3,593.5	29.4	3,593.5	104,600.0	375.9	0.5	0.2	0.8
06/25/2026 10:00	3,586.1	90.2	3,586.1	104,600.0	375.1	0.5	0.2	0.8
06/25/2026 11:00	3,575.8	132.1	3,575.8	104,600.0	374.0	0.5	0.2	0.8
06/25/2026 12:00	3,579.6	109.7	3,579.6	104,600.0	374.4	0.5	0.2	0.8
06/25/2026 13:00	3,586.0	93.0	3,586.0	104,600.0	375.1	0.5	0.2	0.8
06/25/2026 14:00	3,589.3	0.1	3,589.3	104,600.0	375.4	0.5	0.2	0.8
06/25/2026 15:00	3,587.9	0.0	3,587.9	104,600.0	375.3	0.5	0.2	0.8
06/25/2026 16:00	3,594.6	8.3	3,594.6	104,600.0	376.0	0.5	0.2	0.8
06/25/2026 17:00	3,719.1	0.0	3,719.1	104,600.0	389.0	0.5	0.2	0.8
06/25/2026 18:00	3,928.8	0.0	3,928.8	104,600.0	411.0	0.5	0.2	0.8
06/25/2026 19:00	3,628.4	0.0	3,628.4	104,600.0	379.5	0.5	0.2	0.8
06/25/2026 20:00	3,605.0	0.0	3,605.0	104,600.0	377.1	0.5	0.2	0.8
06/25/2026 21:00	3,603.6	0.0	3,603.6	104,600.0	376.9	0.5	0.2	0.8
06/25/2026 22:00	3,602.7	0.0	3,602.7	104,600.0	376.8	0.5	0.2	0.8
06/25/2026 23:00	3,600.3	0.0	3,600.3	104,600.0	376.6	0.5	0.2	0.8
Average/Sum#:	3,636.4	19.8	3,636.4	104,600.0	380.4	0.5	0.2	0.8
Minimum:	3,567.4	0.0	3,567.4	104,600.0	373.2	0.4	0.2	0.7
Maximum:	3,968.3	132.1	3,968.3	104,600.0	415.1	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/26/2026 00:00	3,602.2	0.0	3,602.2	104,600.0	376.8	0.5	0.2	0.8
06/26/2026 01:00	3,602.7	0.0	3,602.7	104,600.0	376.8	0.5	0.2	0.8
06/26/2026 02:00	3,621.2	0.0	3,621.2	104,600.0	378.8	0.5	0.2	0.8
06/26/2026 03:00	3,630.3	0.0	3,630.3	104,600.0	379.7	0.5	0.2	0.8
06/26/2026 04:00	3,629.7	0.0	3,629.7	104,600.0	379.7	0.5	0.2	0.8
06/26/2026 05:00	3,619.9	0.0	3,619.9	104,600.0	378.6	0.5	0.2	0.8
06/26/2026 06:00	3,607.7	0.0	3,607.7	104,600.0	377.4	0.5	0.2	0.8
06/26/2026 07:00	3,593.4	0.0	3,593.4	104,600.0	375.9	0.5	0.2	0.8
06/26/2026 08:00	3,590.0	0.0	3,590.0	104,600.0	375.5	0.5	0.2	0.8
06/26/2026 09:00	3,588.4	31.0	3,588.4	104,600.0	375.3	0.5	0.2	0.8
06/26/2026 10:00	3,593.3	74.1	3,593.3	104,600.0	375.9	0.5	0.2	0.8
06/26/2026 11:00	3,596.6	105.2	3,596.6	104,600.0	376.2	0.5	0.2	0.8
06/26/2026 12:00	3,589.6	103.0	3,589.6	104,600.0	375.5	0.5	0.2	0.8
06/26/2026 13:00	3,595.2	54.3	3,595.2	104,600.0	376.1	0.5	0.2	0.8
06/26/2026 14:00	3,583.1	0.0	3,583.1	104,600.0	374.8	0.5	0.2	0.7
06/26/2026 15:00	3,572.4	0.0	3,572.4	104,600.0	373.7	0.4	0.2	0.7
06/26/2026 16:00	3,578.9	0.0	3,578.9	104,600.0	374.4	0.4	0.2	0.7
06/26/2026 17:00	3,576.4	0.0	3,576.4	104,600.0	374.1	0.4	0.2	0.7
06/26/2026 18:00	3,894.9	0.0	3,894.9	104,600.0	407.4	0.5	0.2	0.8
06/26/2026 19:00	3,643.5	0.0	3,643.5	104,600.0	381.1	0.5	0.2	0.8
06/26/2026 20:00	3,602.8	0.0	3,602.8	104,600.0	376.9	0.5	0.2	0.8
06/26/2026 21:00	3,600.7	0.0	3,600.7	104,600.0	376.6	0.5	0.2	0.8
06/26/2026 22:00	3,591.5	0.0	3,591.5	104,600.0	375.7	0.5	0.2	0.8
06/26/2026 23:00	3,589.8	0.0	3,589.8	104,600.0	375.5	0.5	0.2	0.8
Average/Sum#:	3,612.3	15.3	3,612.3	104,600.0	377.9	0.5	0.2	0.8
Minimum:	3,572.4	0.0	3,572.4	104,600.0	373.7	0.4	0.2	0.7
Maximum:	3,894.9	105.2	3,894.9	104,600.0	407.4	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/27/2026 00:00	3,589.9	0.0	3,589.9	104,600.0	375.5	0.5	0.2	0.8
06/27/2026 01:00	3,598.1	0.0	3,598.1	104,600.0	376.4	0.5	0.2	0.8
06/27/2026 02:00	3,598.7	0.0	3,598.7	104,600.0	376.4	0.5	0.2	0.8
06/27/2026 03:00	3,599.6	0.0	3,599.6	104,600.0	376.5	0.5	0.2	0.8
06/27/2026 04:00	3,605.7	0.0	3,605.7	104,600.0	377.2	0.5	0.2	0.8
06/27/2026 05:00	3,607.3	0.0	3,607.3	104,600.0	377.3	0.5	0.2	0.8
06/27/2026 06:00	3,600.0	0.0	3,600.0	104,600.0	376.6	0.5	0.2	0.8
06/27/2026 07:00	3,599.1	0.0	3,599.1	104,600.0	376.5	0.5	0.2	0.8
06/27/2026 08:00	3,594.6	0.0	3,594.6	104,600.0	376.0	0.5	0.2	0.8
06/27/2026 09:00	3,604.6	1.1	3,604.6	104,600.0	377.0	0.5	0.2	0.8
06/27/2026 10:00	3,604.7	26.0	3,604.7	104,600.0	377.1	0.5	0.2	0.8
06/27/2026 11:00	3,609.3	35.1	3,609.3	104,600.0	377.5	0.5	0.2	0.8
06/27/2026 12:00	3,615.4	116.1	3,615.4	104,600.0	378.2	0.5	0.2	0.8
06/27/2026 13:00	3,613.2	73.4	3,613.2	104,600.0	377.9	0.5	0.2	0.8
06/27/2026 14:00	3,595.5	0.0	3,595.5	104,600.0	376.1	0.5	0.2	0.8
06/27/2026 15:00	3,586.3	0.0	3,586.3	104,600.0	375.1	0.5	0.2	0.8
06/27/2026 16:00	3,592.4	0.0	3,592.4	104,600.0	375.8	0.5	0.2	0.8
06/27/2026 17:00	3,623.7	0.0	3,623.7	104,600.0	379.0	0.5	0.2	0.8
06/27/2026 18:00	3,729.2	0.0	3,729.2	104,600.0	390.1	0.5	0.2	0.8
06/27/2026 19:00	3,622.3	0.0	3,622.3	104,600.0	378.9	0.5	0.2	0.8
06/27/2026 20:00	3,631.2	0.0	3,631.2	104,600.0	379.8	0.5	0.2	0.8
06/27/2026 21:00	3,628.2	0.0	3,628.2	104,600.0	379.5	0.5	0.2	0.8
06/27/2026 22:00	3,623.9	0.0	3,623.9	104,600.0	379.1	0.5	0.2	0.8
06/27/2026 23:00	3,617.1	0.0	3,617.1	104,600.0	378.3	0.5	0.2	0.8
Average/Sum#:	3,612.1	10.5	3,612.1	104,600.0	377.8	0.5	0.2	0.8
Minimum:	3,586.3	0.0	3,586.3	104,600.0	375.1	0.5	0.2	0.8
Maximum:	3,729.2	116.1	3,729.2	104,600.0	390.1	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/28/2026 00:00	3,618.8	0.0	3,618.8	104,600.0	378.5	0.5	0.2	0.8
06/28/2026 01:00	3,617.9	0.0	3,617.9	104,600.0	378.4	0.5	0.2	0.8
06/28/2026 02:00	3,617.0	0.0	3,617.0	104,600.0	378.3	0.5	0.2	0.8
06/28/2026 03:00	3,620.8	0.0	3,620.8	104,600.0	378.7	0.5	0.2	0.8
06/28/2026 04:00	3,629.3	0.0	3,629.3	104,600.0	379.6	0.5	0.2	0.8
06/28/2026 05:00	3,624.7	0.0	3,624.7	104,600.0	379.1	0.5	0.2	0.8
06/28/2026 06:00	3,617.8	0.1	3,617.8	104,600.0	378.4	0.5	0.2	0.8
06/28/2026 07:00	3,610.2	4.5	3,610.2	104,600.0	377.6	0.5	0.2	0.8
06/28/2026 08:00	3,604.1	0.0	3,604.1	104,600.0	377.0	0.5	0.2	0.8
06/28/2026 09:00	3,593.7	0.0	3,593.7	104,600.0	375.9	0.5	0.2	0.8
06/28/2026 10:00	3,590.1	53.6	3,590.1	104,600.0	375.5	0.5	0.2	0.8
06/28/2026 11:00	3,606.6	13.7	3,606.6	104,600.0	377.3	0.5	0.2	0.8
06/28/2026 12:00	3,610.2	60.7	3,610.2	104,600.0	377.6	0.5	0.2	0.8
06/28/2026 13:00	3,613.6	23.8	3,613.6	104,600.0	378.0	0.5	0.2	0.8
06/28/2026 14:00	3,582.4	0.0	3,582.4	104,600.0	374.7	0.5	0.2	0.7
06/28/2026 15:00	3,579.5	0.0	3,579.5	104,600.0	374.4	0.4	0.2	0.7
06/28/2026 16:00	3,580.5	0.0	3,580.5	104,600.0	374.5	0.5	0.2	0.7
06/28/2026 17:00	3,575.5	0.0	3,575.5	104,600.0	374.0	0.4	0.2	0.7
06/28/2026 18:00	3,581.9	0.0	3,581.9	104,600.0	374.7	0.4	0.2	0.7
06/28/2026 19:00	3,593.6	0.0	3,593.6	104,600.0	375.9	0.5	0.2	0.8
06/28/2026 20:00	3,599.9	0.0	3,599.9	104,600.0	376.5	0.5	0.2	0.8
06/28/2026 21:00	3,599.5	0.0	3,599.5	104,600.0	376.5	0.5	0.2	0.8
06/28/2026 22:00	3,596.8	0.0	3,596.8	104,600.0	376.2	0.5	0.2	0.8
06/28/2026 23:00	3,611.2	0.0	3,611.2	104,600.0	377.7	0.5	0.2	0.8
Average/Sum#:	3,603.2	6.5	3,603.2	104,600.0	376.9	0.5	0.2	0.8
Minimum:	3,575.5	0.0	3,575.5	104,600.0	374.0	0.4	0.2	0.7
Maximum:	3,629.3	60.7	3,629.3	104,600.0	379.6	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/29/2026 00:00	3,614.5	0.0	3,614.5	104,600.0	378.1	0.5	0.2	0.8
06/29/2026 01:00	3,620.2	0.0	3,620.2	104,600.0	378.7	0.5	0.2	0.8
06/29/2026 02:00	3,619.5	0.0	3,619.5	104,600.0	378.6	0.5	0.2	0.8
06/29/2026 03:00	3,611.9	0.0	3,611.9	104,600.0	377.8	0.5	0.2	0.8
06/29/2026 04:00	3,616.7	0.0	3,616.7	104,600.0	378.3	0.5	0.2	0.8
06/29/2026 05:00	3,612.6	0.0	3,612.6	104,600.0	377.9	0.5	0.2	0.8
06/29/2026 06:00	3,614.3	0.1	3,614.3	104,600.0	378.1	0.5	0.2	0.8
06/29/2026 07:00	3,612.3	0.0	3,612.3	104,600.0	377.8	0.5	0.2	0.8
06/29/2026 08:00	3,610.0	4.2	3,610.0	104,600.0	377.6	0.5	0.2	0.8
06/29/2026 09:00	3,621.8	19.3	3,621.8	104,600.0	378.8	0.5	0.2	0.8
06/29/2026 10:00	3,589.5	90.0	3,589.5	104,600.0	375.5	0.5	0.2	0.8
06/29/2026 11:00	3,578.5	111.3	3,578.5	104,600.0	374.3	0.5	0.2	0.8
06/29/2026 12:00	3,578.8	99.6	3,578.8	104,600.0	374.3	0.5	0.2	0.8
06/29/2026 13:00	3,576.2	33.2	3,576.2	104,600.0	374.1	0.5	0.2	0.8
06/29/2026 14:00	3,569.0	2.2	3,569.0	104,600.0	373.3	0.4	0.2	0.7
06/29/2026 15:00	3,581.1	0.0	3,581.1	104,600.0	374.6	0.4	0.2	0.7
06/29/2026 16:00	3,583.3	0.0	3,583.3	104,600.0	374.8	0.5	0.2	0.7
06/29/2026 17:00	3,657.6	0.0	3,657.6	104,600.0	382.6	0.5	0.2	0.8
06/29/2026 18:00	3,576.9	0.0	3,576.9	104,600.0	374.1	0.4	0.2	0.7
06/29/2026 19:00	3,572.8	0.0	3,572.8	104,600.0	373.7	0.4	0.2	0.7
06/29/2026 20:00	3,582.0	0.0	3,582.0	104,600.0	374.7	0.4	0.2	0.7
06/29/2026 21:00	3,586.1	0.0	3,586.1	104,600.0	375.1	0.5	0.2	0.8
06/29/2026 22:00	3,577.6	0.0	3,577.6	104,600.0	374.2	0.5	0.2	0.7
06/29/2026 23:00	4,341.1	0.0	4,341.1	104,600.0	454.1	0.5	0.3	0.9
Average/Sum#:	3,629.3	15.0	3,629.3	104,600.0	379.6	0.5	0.2	0.8
Minimum:	3,569.0	0.0	3,569.0	104,600.0	373.3	0.4	0.2	0.7
Maximum:	4,341.1	111.3	4,341.1	104,600.0	454.1	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 04/01/2026 00:00 **To:** 06/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 07/08/2026 06:48 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
06/30/2026 00:00	4,339.4	0.0	4,339.4	104,600.0	453.9	0.5	0.3	0.9
06/30/2026 01:00	4,336.8	0.0	4,336.8	104,600.0	453.6	0.5	0.3	0.9
06/30/2026 02:00	4,339.0	0.0	4,339.0	104,600.0	453.9	0.5	0.3	0.9
06/30/2026 03:00	4,337.8	0.0	4,337.8	104,600.0	453.7	0.5	0.3	0.9
06/30/2026 04:00	4,316.9	0.0	4,316.9	104,600.0	451.5	0.5	0.3	0.9
06/30/2026 05:00	4,074.4	0.0	4,074.4	104,600.0	426.2	0.5	0.3	0.9
06/30/2026 06:00	4,372.8	3.0	4,372.8	104,600.0	457.4	0.5	0.3	0.9
06/30/2026 07:00	4,237.7	1.2	4,237.7	104,600.0	443.3	0.5	0.3	0.9
06/30/2026 08:00	4,241.4	0.0	4,241.4	104,600.0	443.7	0.5	0.3	0.9
06/30/2026 09:00	4,346.2	31.4	4,346.2	104,600.0	454.6	0.5	0.3	0.9
06/30/2026 10:00	4,344.0	109.1	4,344.0	104,600.0	454.4	0.6	0.3	0.9
06/30/2026 11:00	3,589.3	114.6	3,589.3	104,600.0	375.4	0.5	0.2	0.8
06/30/2026 12:00	3,593.0	114.7	3,593.0	104,600.0	375.8	0.5	0.2	0.8
06/30/2026 13:00	3,716.4	87.6	3,716.4	104,600.0	388.7	0.5	0.2	0.8
06/30/2026 14:00	3,710.4	14.5	3,710.4	104,600.0	388.1	0.5	0.2	0.8
06/30/2026 15:00	3,701.7	0.0	3,701.7	104,600.0	387.2	0.5	0.2	0.8
06/30/2026 16:00	3,701.7	13.7	3,701.7	104,600.0	387.2	0.5	0.2	0.8
06/30/2026 17:00	3,752.8	0.0	3,752.8	104,600.0	392.5	0.5	0.2	0.8
06/30/2026 18:00	4,228.9	0.0	4,228.9	104,600.0	442.3	0.5	0.3	0.9
06/30/2026 19:00	3,829.4	0.0	3,829.4	104,600.0	400.6	0.5	0.2	0.8
06/30/2026 20:00	3,897.3	0.0	3,897.3	104,600.0	407.7	0.5	0.2	0.8
06/30/2026 21:00	3,713.0	0.0	3,713.0	104,600.0	388.4	0.5	0.2	0.8
06/30/2026 22:00	3,723.4	0.0	3,723.4	104,600.0	389.5	0.5	0.2	0.8
06/30/2026 23:00	3,728.3	0.0	3,728.3	104,600.0	390.0	0.5	0.2	0.8
Average/Sum#:	4,007.2	20.4	4,007.2	104,600.0	419.2	0.5	0.3	0.9
Minimum:	3,589.3	0.0	3,589.3	104,600.0	375.4	0.5	0.2	0.8
Maximum:	4,372.8	114.7	4,372.8	104,600.0	457.4	0.6	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00