

Energy - Docket Optical System

From: Erika Walther [ewalther@energy-solution.com]
Sent: Wednesday, February 13, 2013 9:47 AM
To: Energy - Docket Optical System
Cc: Michael McGaraghan; Heidi Hauenstein
Subject: 12-BSTD-05

California Energy Commission

DOCKETED
12-BSTD-5

TN # 69515

FEB 13 2013

Dear Energy Commission,

I am submitting an edit to the following section of the Non-residential Compliance Manual as indicated below:

4.2.7 Open and Closed Circuit Cooling Towers

§110.2 (e)

All open and closed circuit cooling towers ~~over~~ **with a rated capacity of** 150 tons ~~of capacity~~ **or greater** must have a control system that maximizes the cycles of concentration based on the water quality conditions based on either conductivity or flow.

This edit is necessary because the adopted code provides an exception for cooling towers with a rated capacity of less than 150 tons; towers with a rated capacity equal to 150 tons (or greater) are covered by the code.

Thank you,

Erika Walther
Energy Solutions
510-482-4420 x224