

DOCKETED	
Docket Number:	24-OPT-05
Project Title:	Corby Battery Energy Storage System Project
TN #:	272615
Document Title:	Judith Gronroos Comments - Proposed site for Corby BESS
Description:	N/A
Filer:	System
Organization:	Judith Gronroos
Submitter Role:	Public
Submission Date:	9/13/2026 10:12:41 AM
Docketed Date:	9/14/2026

*Comment Received From: Judith Gronroos
Submitted On: 9/13/2026
Docket Number: 24-OPT-05*

Proposed site for Corby BESS

Additional submitted attachment is included below.

NOT LISTENING TO FIRST RESPONDERS IS DANGEROUS. THEY HAVE TO PROTECT THE COMMUNITY!

CEC PLEASE direct the applicant to resubmit its proposal based on the use of Lambie Industrial Park.

Vacaville Firefighters Association letter. “On Sept. 2, the day after the hearing, the Vacaville Firefighters Association resubmitted a letter to the CEC in which they opposed the current proposed site and strongly recommended the alternate Lambie Park location for the following reasons:

- Locating the facility at Lambie removes the immediate, direct threat to Interstate 80 and other critical transportation corridors. A thermal runaway event at Lambie would not necessitate closing major traffic corridors.
- Lambie Industrial Park offers significant separation from dense residential subdivision and schools. This is a crucial safety enhancement that allows our firefighters more options for containment without the imminent, complex challenges of large-scale public evacuations.
- While a BESS fire will always be complex, responding to one in a properly designated and isolated industrial zone dramatically reduces the multi-agency strain and resource-sharing conflicts that are a core concern.

The “presumption of benefit” to the community from the Corby project in its proposed location has clearly not been met and does not outweigh the risks. The Lampie Industrial Park site could provide benefits to all with minimal risks.