DOCKETED	
Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	273261
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q3 2026 - Part 5s
Description:	N/A
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public Agency
Submission Date:	10/28/2026 7:52:54 AM
Docketed Date:	10/28/2026

II. Emissions Overview

AQ-15

AQ-15 The Project owner shall install a selective catalytic reduction (SCR) system and an oxidation catalyst on the gas turbine. The SCR and oxidation catalyst equipment shall be operated whenever the gas turbine is operated.

Verification: The Project owner shall submit to the CPM a written statement by a California registered Professional Engineer stating that said engineer has reviewed the as built deigns or inspected the identified equipment and certifies that it is operational and air tight. The Project owner shall include the operational status of the SCR and oxidation catalyst during all hours of operation as part of the Quarterly Air Quality Report required by the Condition of Certification AQ-SC6

This document is on file from the 2007 4Q QAQR.

AQ-21, AQ-54-63, AQ-71, AQ-131-135, AQ-137-138, & AQ-145-149

AQ-21, AQ-54-63, AQ-71, AQ-131-135, AQ-137-138, & AQ145-149:
Fuel use emission and operational data -Hourly/Daily/Quarterly

Verification: The Project owner shall include all necessary emissions data to demonstrate compliance with the emissions limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

Sample Spreadsheet Listing

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/02/26 23:34	39480.3			0			0			0			0			0		
07/02/26 23:35	39451.4			0			0			0			0			0		
07/02/26 23:36	39393.7			0			0			0			0			0		
07/02/26 23:37	39283.9			0			0			0			0			0		
07/02/26 23:38	44008.8			0			0			0			0			0		
07/02/26 23:39	44245.7			0			0			0			0			1		
07/02/26 23:40	48127.3			0			0			0			0			1		
07/02/26 23:41	54712.1			34.5			0.7			0			0			1		
07/02/26 23:42	63422.7			1445.5			16.23			214.53			3.96			1		
07/02/26 23:43	73259.5			998.5			18.05			171.21			5.09			1		
07/02/26 23:44	89912.3			567.6			22.13			119.43			7.66			1		
07/02/26 23:45	129184.7			441.7			25.85			133.56			12.86			1		
07/02/26 23:46	146126.3			323.3			32.33			110.66			18.21			1		
07/02/26 23:47	157961.7			729.5			33.31			269.77			20.27			1		
07/02/26 23:48	174810.8			1899.6			25.75			777.73			17.35			1		
07/02/26 23:49	195206.6			1443.6			31.57			659.85			23.75			1		
07/02/26 23:50	216959.8			205.4			39.65			104.33			33.15			1		
07/02/26 23:51	237627			13.2			42.65			7.32			39.06			1		
07/02/26 23:52	260558.5			2.3			63.92			1.4			64.16			1		
07/02/26 23:53	285511.7			1.9			56.15			1.25			61.77			1		
07/02/26 23:54	306294.5			1.7			27.35			1.22			32.29			1		
07/02/26 23:55	323958.1			1.8			13.25			1.36			16.55			1		
07/02/26 23:56	339969.7			1.8			11.89			1.43			15.57			1		
07/02/26 23:57	343741.5			1.8			11.13			1.42			14.74			1		
07/02/26 23:58	344717.7			1.7			9.95			1.36			13.21			1		
07/02/26 23:59	344613.8			1.5			8.68			1.22			11.53			1		
07/03/26 0:00	348108.3			1.5			8.21			1.18			11.01			1		
07/03/26 0:01	362340.9			1.4			7.1			1.16			9.91			1		
07/03/26 0:02	382176.4			1.2			5.64			1.1			8.3			1		
07/03/26 0:03	393630.5			1.1			4.74			0.99			7.19			1		
07/03/26 0:04	395611.8			0.9			4.65			0.83			7.09			1		
07/03/26 0:05	396530.2			0.9			4.74			0.83			7.24			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/03/26 0:06	396541.8			0.9			4.67			0.82			7.13			1		
07/03/26 0:07	396120.1			0.9			4.74			0.83			7.23			1		
07/03/26 0:08	395652.2			0.8			4.74			0.75			7.22			1		
07/03/26 0:09	394566.3			0.8			4.74			0.74			7.2			1		
07/03/26 0:10	394485.4			0.8			4.65			0.74			7.07			1		
07/03/26 0:11	395542.5			0.8			4.47			0.75			6.81			1		
07/03/26 0:12	396316.5			0.8			4.38			0.75			6.69			1		
07/03/26 0:13	396177.9			0.7			4.38			0.66			6.69			1		
07/03/26 0:14	387519.4			0.7			4.47			0.65			6.67			1		
07/03/26 0:15	368434.8			0.7			4.93			0.61			7			1		
07/03/26 0:16	355756.1			0.8			5.29			0.65			7.26			1		
07/03/26 0:17	351135.1			0.8			5.21			0.64			7.04			1		
07/03/26 0:18	348749.5			0.8			4.69			0.64			6.3			1		
07/03/26 0:19	347213			0.8			4.69			0.63			6.27			1		
07/03/26 0:20	344943			0.8			5.02			0.64			6.67			1		
07/03/26 0:21	344573.3			0.8			5.21			0.63			6.91			1		
07/03/26 0:22	344307.6			0.8			2.82			0.64			3.74			1		
07/03/26 0:23	344244.1			0.8			1.85			0.64			2.45			1		
07/03/26 0:24	344342.3			0.8			1.85			0.64			2.45			1		
07/03/26 0:25	343955.3			0.8			2.03			0.64			2.68			1		
07/03/26 0:26	343984.1			0.8			2.47			0.64			3.27			1		
07/03/26 0:27	344163.2			0.7			2.91			0.57			3.85			1		
07/03/26 0:28	342257.1			0.7			3.08			0.56			4.06			1		
07/03/26 0:29	341569.7			0.7			3.08			0.56			4.06			1		
07/03/26 0:30	341581.2			0.7			2.47			0.56			3.25			1		
07/03/26 0:31	341875.8			0.7			2.11			0.56			2.78			1		
07/03/26 0:32	341644.8			0.7			2.03			0.56			2.67			1		
07/03/26 0:33	341460			0.7			1.94			0.56			2.55			1		
07/03/26 0:34	341563.9			0.7			1.94			0.56			2.55			1		
07/03/26 0:35	341985.6			0.7			1.85			0.56			2.44			1		
07/03/26 0:36	341465.7			0.7			1.85			0.56			2.43			1		
07/03/26 0:37	341535			0.8			1.85			0.63			2.43			1		
07/03/26 0:38	341795			0.8			1.76			0.63			2.32			1		
07/03/26 0:39	339704			0.7			1.67			0.56			2.19			1		
07/03/26 0:40	338491			0.7			1.67			0.56			2.18			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/03/26 0:41	340645.5			0.7			1.59			0.56			2.08			1		
07/03/26 0:42	342083.8			0.8			1.5			0.63			1.97			1		
07/03/26 0:43	343279.4			0.8			1.41			0.64			1.86			0		
07/03/26 0:44	343475.8			0.7			1.32			0.57			1.75			0		
07/03/26 0:45	343579.8			0.7			1.41			0.57			1.87			0		
07/03/26 0:46	343308.3			0.7			1.32			0.57			1.75			0		
07/03/26 0:47	343296.8			0.7			1.32			0.57			1.75			0		

Sample Spreadsheet Listing

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/03/26 4:05	337867.1			0.8			1.5			0.63			1.95			0		
07/03/26 4:06	338358.1			0.8			1.5			0.63			1.95			0		
07/03/26 4:07	338231			0.8			1.5			0.63			1.95			0		
07/03/26 4:08	338300.3			0.7			1.5			0.56			1.95			0		
07/03/26 4:09	337930.7			0.7			1.5			0.56			1.95			0		
07/03/26 4:10	335152.3			0.7			1.5			0.55			1.93			1		
07/03/26 4:11	317147.9			0.7			1.5			0.52			1.83			1		
07/03/26 4:12	294435.9			0.7			1.65			0.48			1.87			1		
07/03/26 4:13	271937.6			0.7			1.79			0.46			1.87			1		
07/03/26 4:14	251772.9			0.6			2.95			0.33			2.86			1		
07/03/26 4:15	228038.5			0.5			4.19			0.25			3.68			1		
07/03/26 4:16	207255.8			0.3			12.11			0.15			9.67			1		
07/03/26 4:17	183954.6			3.5			15.73			1.49			11.15			1		
07/03/26 4:18	165049.1			137.8			17.96			53.24			11.42			1		
07/03/26 4:19	148742.9			925.3			19.62			322.28			11.25			1		
07/03/26 4:20	101690			1786.7			19.89			425.54			7.8			1		
07/03/26 4:21	47295.5			0			23.01			274.34			4.2			0		
07/03/26 4:22	46775.7			0			0.3			0			0			0		
07/03/26 4:23	47359			0			0.3			0			0			0		
07/03/26 4:24	46758.3			0			0.2			0			0			0		
07/03/26 4:25	44834.8			0			0.2			0			0			0		

Sample Spreadsheet Listing

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/04/26 0:34	36453.6			0			0			0			0			0		
07/04/26 0:35	36494			0			0			0			0			0		
07/04/26 0:36	36517.1			0			0			0			0			0		
07/04/26 0:37	36638.4			0			0			0			0			0		
07/04/26 0:38	36517.1			0			0			0			0			0		
07/04/26 0:39	39197.3			0			0			0			0			1		
07/04/26 0:40	44309.2			0			0			0			0			1		
07/04/26 0:41	52205.3			1949			27.53			238.2			5.54			1		
07/04/26 0:42	61591.6			1349.5			12.19			194.54			2.89			1		
07/04/26 0:43	71711.5			858.1			19.01			144.07			5.25			1		
07/04/26 0:44	92251.7			523.3			25.67			113.05			9.12			1		
07/04/26 0:45	132679.3			378.1			30.57			117.49			15.63			1		
07/04/26 0:46	143446.1			265.7			42.83			89.22			23.67			1		
07/04/26 0:47	152589.8			1088.1			46.06			388.72			27.08			1		
07/04/26 0:48	169184.8			1959			44.8			776.17			29.21			1		
07/04/26 0:49	189892.5			1664.3			46.05			739.88			33.69			1		
07/04/26 0:50	212130.9			277.2			43.27			137.67			35.37			1		
07/04/26 0:51	232515.1			18.8			41.67			10.24			37.33			1		
07/04/26 0:52	255255.9			2.7			57.33			1.6			56.39			1		
07/04/26 0:53	280781			2			52.1			1.31			56.37			1		
07/04/26 0:54	301852.6			1.9			23.06			1.35			26.81			1		
07/04/26 0:55	320122.6			1.8			10			1.35			12.34			1		
07/04/26 0:56	337457			1.8			8.29			1.42			10.79			1		
07/04/26 0:57	343828.2			1.7			8.21			1.38			10.87			1		
07/04/26 0:58	345156.7			1.6			7.61			1.31			10.12			1		
07/04/26 0:59	344839			1.5			7.27			1.17			9.66			1		
07/04/26 1:00	348091			1.3			6.58			1.05			8.83			1		
07/04/26 1:01	362081			1.2			5.9			1.03			8.23			1		
07/04/26 1:02	381812.5			1.1			4.76			0.94			7			1		
07/04/26 1:03	393318.7			1			4.11			0.91			6.23			1		
07/04/26 1:04	396125.9			0.8			4.11			0.75			6.28			1		
07/04/26 1:05	396813.3			0.8			4.2			0.75			6.43			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/04/26 1:06	396472.4			0.8			4.38			0.75			6.69			1		
07/04/26 1:07	396247.2			0.8			4.38			0.75			6.69			1		
07/04/26 1:08	395276.8			0.8			4.38			0.74			6.67			1		
07/04/26 1:09	394225.5			0.7			4.29			0.66			6.52			1		
07/04/26 1:10	393821.2			0.7			4.29			0.66			6.51			1		
07/04/26 1:11	379305.6			0.7			4.47			0.64			6.53			1		
07/04/26 1:12	361208.8			0.7			5.02			0.6			6.99			1		
07/04/26 1:13	356108.4			0.8			5.03			0.65			6.91			1		
07/04/26 1:14	354860.8			0.8			4.51			0.65			6.17			1		
07/04/26 1:15	353451.3			0.8			4.49			0.66			6.12			1		
07/04/26 1:16	352371.2			0.8			4.49			0.65			6.1			1		
07/04/26 1:17	352752.4			0.8			4.49			0.65			6.11			1		
07/04/26 1:18	350782.8			0.7			3.26			0.58			4.4			1		
07/04/26 1:19	346392.8			0.7			2.99			0.57			4			1		
07/04/26 1:20	346641.2			0.7			2.03			0.57			2.71			1		
07/04/26 1:21	345410.8			0.7			1.85			0.57			2.46			1		
07/04/26 1:22	344844.8			0.7			1.85			0.57			2.46			1		
07/04/26 1:23	345127.8			0.7			1.94			0.57			2.58			1		
07/04/26 1:24	344284.5			0.7			2.11			0.57			2.8			1		
07/04/26 1:25	344619.5			0.7			2.29			0.57			3.04			1		
07/04/26 1:26	344290.3			0.7			2.47			0.57			3.27			1		
07/04/26 1:27	344111.2			0.7			2.64			0.57			3.5			1		
07/04/26 1:28	344602.2			0.7			2.64			0.57			3.51			1		
07/04/26 1:29	344169			0.7			1.94			0.57			2.57			1		
07/04/26 1:30	343533.6			0.7			1.76			0.57			2.33			1		
07/04/26 1:31	343487.4			0.7			1.67			0.57			2.21			1		
07/04/26 1:32	343279.4			0.7			1.76			0.57			2.33			1		
07/04/26 1:33	343377.6			0.7			1.94			0.57			2.56			1		
07/04/26 1:34	343181.3			0.7			1.94			0.57			2.56			1		
07/04/26 1:35	343337.2			0.7			1.76			0.57			2.33			1		
07/04/26 1:36	343787.7			0.7			1.59			0.57			2.1			1		
07/04/26 1:37	343389.2			0.7			1.5			0.57			1.98			1		
07/04/26 1:38	341956.7			0.7			1.41			0.56			1.86			1		
07/04/26 1:39	340899.7			0.7			1.41			0.56			1.85			1		
07/04/26 1:40	340928.6			0.7			1.41			0.56			1.85			0		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/04/26 1:41	340789.9			0.7			1.32			0.56			1.73			0		
07/04/26 1:42	341252			0.7			1.32			0.56			1.74			0		
07/04/26 1:43	341332.9			0.7			1.32			0.56			1.74			0		
07/04/26 1:44	341159.6			0.7			1.32			0.56			1.74			0		

Sample Spreadsheet Listing

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/04/26 5:04	337295.3			0.7			1.5			0.56			1.95			0		
07/04/26 5:05	337497.5			0.7			1.5			0.56			1.95			0		
07/04/26 5:06	337254.8			0.7			1.5			0.56			1.95			0		
07/04/26 5:07	337624.5			0.7			1.5			0.56			1.95			0		
07/04/26 5:08	337734.3			0.7			1.5			0.56			1.95			0		
07/04/26 5:09	333933.6			0.7			1.5			0.55			1.93			1		
07/04/26 5:10	315340			0.7			1.5			0.52			1.82			1		
07/04/26 5:11	292431.6			0.7			1.67			0.48			1.89			1		
07/04/26 5:12	269846.6			0.6			1.82			0.4			1.89			1		
07/04/26 5:13	249387.4			0.6			2.67			0.32			2.57			1		
07/04/26 5:14	226097.7			0.5			4.93			0.26			4.3			1		
07/04/26 5:15	204858.6			0.3			12.85			0.15			10.15			1		
07/04/26 5:16	181280.2			4.3			16.2			1.82			11.31			1		
07/04/26 5:17	161681.5			151.4			18.75			57.32			11.68			1		
07/04/26 5:18	144907.5			994.1			21.33			337.34			11.91			1		
07/04/26 5:19	76569.3			1842.2			21.34			330.31			6.3			1		
07/04/26 5:20	37551.1			0			24.78			237.27			3.59			0		
07/04/26 5:21	37712.8			0			0.2			0			0			0		
07/04/26 5:22	37678.1			0			0.2			0			0			0		
07/04/26 5:23	37863			0			0.2			0			0			0		
07/04/26 5:24	38157.6			0			0.1			0			0			0		

Sample Spreadsheet Listing

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/04/26 18:19	45626.2			0			0			0			0			0		
07/04/26 18:20	45464.4			0			0			0			0			0		
07/04/26 18:21	45314.3			0			0			0			0			0		
07/04/26 18:22	45198.8			0			0			0			0			0		
07/04/26 18:23	45031.2			0			0			0			0			0		
07/04/26 18:24	50097			-0.1			0			0			0			1		
07/04/26 18:25	53250.8			3.3			0			0			0			1		
07/04/26 18:26	60661.6			1229.8			11.8			174.81			2.76			1		
07/04/26 18:27	69712.9			1014.4			11.43			165.54			3.07			1		
07/04/26 18:28	80393.1			527			17.08			99.2			5.29			1		
07/04/26 18:29	109031.5			286.4			21.45			73.09			9.01			1		
07/04/26 18:30	142302.4			178.7			31.22			59.53			17.11			1		
07/04/26 18:31	148176.8			142.6			42.87			49.47			24.48			1		
07/04/26 18:32	149961.6			1636.7			39.46			574.83			22.81			1		
07/04/26 18:33	153306.1			1843.8			38			662			22.46			1		
07/04/26 18:34	168503.2			1843.8			38			727.62			24.68			1		
07/04/26 18:35	189673			1157			39.55			513.85			28.9			1		
07/04/26 18:36	212431.2			121.9			40.32			60.65			33			1		
07/04/26 18:37	233445			7.4			42.04			4.03			37.82			1		
07/04/26 18:38	257445.1			2.4			61.95			1.45			61.46			1		
07/04/26 18:39	280827.2			2.1			43.46			1.36			47.03			1		
07/04/26 18:40	301563.7			1.8			17.88			1.26			20.77			1		
07/04/26 18:41	320319.1			1.8			8.81			1.32			10.87			1		
07/04/26 18:42	337584.1			1.6			8.72			1.25			11.34			1		
07/04/26 18:43	342274.3			1.4			7.84			1.13			10.34			1		
07/04/26 18:44	343764.6			1.3			7.75			1.06			10.27			1		
07/04/26 18:45	344636.9			1.1			7.04			0.92			9.36			1		
07/04/26 18:46	344365.3			1.1			6.08			0.85			8.06			1		
07/04/26 18:47	343077.3			1.1			5.99			0.85			7.92			1		
07/04/26 18:48	349685.3			1			5.55			0.79			7.48			1		
07/04/26 18:49	368157.5			0.9			4.81			0.78			6.83			1		
07/04/26 18:50	377584.3			0.8			4.79			0.73			6.97			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/04/26 18:51	381598.8			0.7			4.79			0.66			7.05			1		
07/04/26 18:52	382788.6			0.7			4.79			0.66			7.07			1		
07/04/26 18:53	382938.8			0.7			4.89			0.66			7.21			1		
07/04/26 18:54	383031.3			0.6			4.89			0.58			7.21			1		
07/04/26 18:55	374811.7			0.6			4.79			0.57			6.92			1		
07/04/26 18:56	355392.1			0.6			5.26			0.53			7.21			1		
07/04/26 18:57	344244.1			0.7			5.81			0.58			7.71			1		
07/04/26 18:58	341529.3			0.7			5.64			0.56			7.42			1		
07/04/26 18:59	353382			0.7			5.1			0.59			6.94			1		
07/04/26 19:00	374066.6			0.6			4.52			0.57			6.51			1		
07/04/26 19:01	397171.4			0.6			4.5			0.52			6.88			1		
07/04/26 19:02	400706.4			0.6			4.78			0.53			7.37			1		
07/04/26 19:03	398563.5			0.5			4.18			0.51			6.41			1		
07/04/26 19:04	398661.6			0.6			2.03			0.6			3.12			1		
07/04/26 19:05	398286.2			0.6			1.84			0.6			2.83			1		
07/04/26 19:06	397968.5			0.6			2.4			0.6			3.68			1		
07/04/26 19:07	397483.3			0.6			2.77			0.6			4.24			1		
07/04/26 19:08	396645.8			0.6			2.86			0.6			4.37			1		
07/04/26 19:09	396085.4			0.6			2.95			0.6			4.5			1		
07/04/26 19:10	395894.8			0.6			2.58			0.6			3.94			1		
07/04/26 19:11	396819			0.6			2.03			0.6			3.1			1		
07/04/26 19:12	398372.8			0.6			2.03			0.6			3.11			1		
07/04/26 19:13	398811.8			0.6			2.03			0.6			3.12			1		
07/04/26 19:14	399273.9			0.6			2.12			0.6			3.26			1		
07/04/26 19:15	399181.5			0.6			2.21			0.6			3.4			1		
07/04/26 19:16	397876			0.6			2.21			0.6			3.4			1		
07/04/26 19:17	396050.8			0.6			2.12			0.63			3.41			1		
07/04/26 19:18	397697			1.1			1.88			1.07			3.08			1		
07/04/26 19:19	398557.7			1.8			1.59			1.83			2.71			1		
07/04/26 19:20	399753.3			1.8			1.43			1.94			2.58			1		
07/04/26 19:21	400562			1.2			1.37			1.33			2.49			1		
07/04/26 19:22	400804.6			0.7			1.42			0.79			2.59			1		
07/04/26 19:23	400891.2			0.6			1.49			0.63			2.79			1		
07/04/26 19:24	400891.3			0.5			1.4			0.59			2.51			1		
07/04/26 19:25	401047.3			0.5			1.42			0.52			2.55			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/04/26 19:26	401532.4			0.6			1.36			0.62			2.5			1		
07/04/26 19:27	400977.9			0.6			1.26			0.61			2.29			1		
07/04/26 19:28	401284			0.6			1.26			0.61			2.29			0		
07/04/26 19:29	399626.2			0.6			1.34			0.61			2.42			0		
07/04/26 19:30	398488.4			0.6			1.34			0.6			2.39			0		
07/04/26 19:31	398124.5			0.6			1.36			0.61			2.43			0		
07/04/26 19:32	398875.4			0.6			1.28			0.62			2.33			0		

Sample Spreadsheet Listing

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/05/26 0:30	337330			0.7			1.52			0.56			1.98			0		
07/05/26 0:31	337110.5			0.7			1.52			0.56			1.97			0		
07/05/26 0:32	336723.5			0.7			1.52			0.56			1.97			0		
07/05/26 0:33	337584.1			0.7			1.52			0.57			1.98			0		
07/05/26 0:34	337254.9			0.7			1.52			0.56			1.98			0		
07/05/26 0:35	335071.5			0.7			1.52			0.56			1.96			1		
07/05/26 0:36	317979.7			0.7			1.52			0.53			1.86			1		
07/05/26 0:37	295562.3			0.7			1.59			0.49			1.81			1		
07/05/26 0:38	272757.9			0.7			1.72			0.46			1.81			1		
07/05/26 0:39	251842.3			0.6			2.4			0.38			2.33			1		
07/05/26 0:40	228743.2			0.5			3.43			0.25			3.02			1		
07/05/26 0:41	207943.1			0.4			9.77			0.2			7.82			1		
07/05/26 0:42	183469.4			0.7			16.11			0.29			11.39			1		
07/05/26 0:43	162894.6			69.1			18.6			26.37			11.67			1		
07/05/26 0:44	145981.9			695			21.24			237.57			11.95			1		
07/05/26 0:45	99443			1740			21.41			405.07			8.2			1		
07/05/26 0:46	35708.5			0			24.67			204.4			3.4			0		
07/05/26 0:47	35621.8			0			0.3			0			0			0		
07/05/26 0:48	35772			0			0.2			0			0			0		
07/05/26 0:49	35662.2			0			0.2			0			0			0		
07/05/26 0:50	35962.6			0			0.1			0			0			0		

Sample Spreadsheet Listing

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/10/26 16:04	47520.8			0			0			0			0			0		
07/10/26 16:05	47636.3			0			0			0			0			0		
07/10/26 16:06	47676.7			0			0			0			0			0		
07/10/26 16:07	47809.6			0			0			0			0			0		
07/10/26 16:08	53886.2			0			0			0			0			0		
07/10/26 16:09	60528.8			0.1			0			0			0			1		
07/10/26 16:10	63803.9			0.2			0			0			0			1		
07/10/26 16:11	69753.4			1394.4			21.63			227.85			5.82			1		
07/10/26 16:12	77262.4			1120.6			14.55			202.68			4.33			1		
07/10/26 16:13	85822.8			666.1			18.63			133.89			6.16			1		
07/10/26 16:14	105542.7			337.4			24.14			83.37			9.82			1		
07/10/26 16:15	141459.1			200.4			29.99			66.38			16.35			1		
07/10/26 16:16	150845.4			137.5			43.74			48.58			25.43			1		
07/10/26 16:17	158903.2			1009.8			38.62			375.68			23.65			1		
07/10/26 16:18	174585.6			1830.9			36.79			748.37			24.75			1		
07/10/26 16:19	195408.8			903.5			47.51			413.38			35.78			1		
07/10/26 16:20	217289			101.9			57.08			51.87			47.8			1		
07/10/26 16:21	238816.9			5.7			60.93			3.16			56.07			1		
07/10/26 16:22	262077.7			1.9			81.96			1.18			82.76			1		
07/10/26 16:23	285280.7			1.7			51.39			1.14			56.49			1		
07/10/26 16:24	305329.8			1.7			22.19			1.2			26.11			1		
07/10/26 16:25	324714.7			1.8			11.8			1.34			14.76			1		
07/10/26 16:26	340322			1.7			11.71			1.38			15.36			1		
07/10/26 16:27	345740.1			1.6			9.54			1.33			12.71			1		
07/10/26 16:28	346196.4			1.6			8.63			1.28			11.51			1		
07/10/26 16:29	346768.3			1.5			7.46			1.2			9.97			1		
07/10/26 16:30	346086.7			1.3			6.96			1.07			9.28			1		
07/10/26 16:31	345468.7			1.2			6.16			1			8.21			1		
07/10/26 16:32	345653.4			1.2			5.81			1			7.74			1		
07/10/26 16:33	344307.6			1.1			5.37			0.85			7.13			1		
07/10/26 16:34	343828.2			1.1			5.36			0.86			7.11			1		
07/10/26 16:35	343429.6			1			5.27			0.79			6.98			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/10/26 16:36	343302.5			1			5.01			0.79			6.62			1		
07/10/26 16:37	343042.6			1			4.83			0.79			6.38			1		
07/10/26 16:38	342389.9			0.9			4.74			0.72			6.25			1		
07/10/26 16:39	341795			0.9			4.65			0.72			6.12			1		
07/10/26 16:40	342291.7			0.9			4.47			0.72			5.89			1		
07/10/26 16:41	341494.6			0.8			4.38			0.64			5.76			1		
07/10/26 16:42	341696.8			0.8			4.29			0.64			5.65			1		
07/10/26 16:43	341286.7			0.8			4.2			0.64			5.53			1		
07/10/26 16:44	340945.8			0.8			4.2			0.64			5.52			1		
07/10/26 16:45	345093.2			0.8			4.27			0.66			5.67			1		
07/10/26 16:46	362710.6			0.8			4.18			0.69			5.84			1		
07/10/26 16:47	373026.9			0.7			4.06			0.64			5.83			1		
07/10/26 16:48	373373.5			0.7			3.93			0.65			5.66			1		
07/10/26 16:49	366349.6			0.6			4.52			0.55			6.38			1		
07/10/26 16:50	360613.8			0.7			4.27			0.61			5.93			1		
07/10/26 16:51	355109.1			0.7			3.54			0.6			4.84			1		
07/10/26 16:52	350690.3			0.8			3.36			0.67			4.54			1		
07/10/26 16:53	350257.1			0.8			3.18			0.67			4.29			1		
07/10/26 16:54	364033.3			0.8			2.9			0.7			4.07			1		
07/10/26 16:55	370878.1			0.7			2.4			0.64			3.43			1		
07/10/26 16:56	371900.5			0.7			2.3			0.64			3.3			1		
07/10/26 16:57	372276			0.7			1.94			0.64			2.78			1		
07/10/26 16:58	373333			0.7			1.38			0.64			1.99			1		
07/10/26 16:59	389951.1			0.7			1.29			0.67			1.94			1		
07/10/26 17:00	388847.9			0.7			1.2			0.67			1.8			1		
07/10/26 17:01	386837.8			0.7			1.09			0.66			1.62			1		
07/10/26 17:02	386751.1			0.7			1.01			0.67			1.51			1		
07/10/26 17:03	389558.3			0.7			0.92			0.67			1.38			1		
07/10/26 17:04	399118			0.7			0.74			0.69			1.13			1		
07/10/26 17:05	414118.8			0.7			0.66			0.64			1.05			1		
07/10/26 17:06	422575.1			0.7			0.66			0.65			1.07			1		
07/10/26 17:07	422806.1			0.6			0.65			0.64			1.05			1		
07/10/26 17:08	422032.1			0.6			0.73			0.63			1.18			0		
07/10/26 17:09	422292.1			0.7			0.82			0.72			1.33			0		
07/10/26 17:10	422095.7			0.7			0.82			0.72			1.33			0		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/10/26 17:11	421483.4			0.7			0.83			0.73			1.35			0		
07/10/26 17:12	422436.5			0.6			0.92			0.64			1.5			0		

Sample Spreadsheet Listing

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/11/26 5:15	340836.1			0.9			1.5			0.7			1.97			0		
07/11/26 5:16	340749.5			0.9			1.5			0.7			1.97			0		
07/11/26 5:17	340547.3			0.9			1.5			0.7			1.96			0		
07/11/26 5:18	340483.8			0.9			1.5			0.7			1.96			0		
07/11/26 5:19	340789.9			0.9			1.5			0.7			1.97			0		
07/11/26 5:20	337711.2			0.9			1.5			0.7			1.95			1		
07/11/26 5:21	319337.1			0.9			1.59			0.66			1.95			1		
07/11/26 5:22	297168			0.9			1.65			0.6			1.89			1		
07/11/26 5:23	275276.3			0.9			1.97			0.58			2.09			1		
07/11/26 5:24	255683.4			0.7			3.87			0.44			3.81			1		
07/11/26 5:25	232318.7			0.7			5.8			0.36			5.2			1		
07/11/26 5:26	212102			0.5			14.39			0.26			11.76			1		
07/11/26 5:27	189234			3.5			17.7			1.54			12.9			1		
07/11/26 5:28	170345.9			136.6			20.06			54.5			13.17			1		
07/11/26 5:29	154802.1			934			20.21			338.48			12.05			1		
07/11/26 5:30	106443.8			1840.3			21.86			458.49			8.97			1		
07/11/26 5:31	65219			0			22.98			376.78			5.77			0		
07/11/26 5:32	64647.2			0			0.2			0			0			0		
07/11/26 5:33	64826.3			0			0.2			0			0			0		
07/11/26 5:34	64000.3			0			0.2			0			0			0		
07/11/26 5:35	63723			0			0.1			0			0			0		

Sample Spreadsheet Listing

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/11/26 15:54	57184.4			0			0			0			0			0		
07/11/26 15:55	57149.7			0			0			0			0			0		
07/11/26 15:56	57063.1			0			0			0			0			0		
07/11/26 15:57	57005.3			0			0			0			0			0		
07/11/26 15:58	56855.1			0			0			0			0			0		
07/11/26 15:59	58819			0.1			0			0			0			1		
07/11/26 16:00	62261.6			0.5			0			0			0			1		
07/11/26 16:01	68424.8			1148.8			12.64			184.12			3.33			1		
07/11/26 16:02	76037.9			1030.4			10.76			183.37			3.15			1		
07/11/26 16:03	84921.7			595.9			17.7			118.45			5.79			1		
07/11/26 16:04	106663.3			313.8			23.06			78.38			9.48			1		
07/11/26 16:05	142747.2			189.5			29.99			63.34			16.5			1		
07/11/26 16:06	147605			131.8			43.46			45.54			24.72			1		
07/11/26 16:07	156852.7			1310			40.01			481.2			24.19			1		
07/11/26 16:08	172916.3			1843.8			39.56			746.6			26.37			1		
07/11/26 16:09	193623.9			1038.4			40.68			470.69			30.35			1		
07/11/26 16:10	216180			102.4			41.85			51.81			34.86			1		
07/11/26 16:11	236864.6			5.8			44.67			3.21			40.78			1		
07/11/26 16:12	260327.5			2.1			62.11			1.31			62.31			1		
07/11/26 16:13	283397.6			1.8			37.59			1.2			41.04			1		
07/11/26 16:14	303585.4			1.7			15.94			1.19			18.65			1		
07/11/26 16:15	322311.8			1.7			8.63			1.26			10.72			1		
07/11/26 16:16	338491			1.6			8.5			1.24			11.09			1		
07/11/26 16:17	344446.2			1.5			7.81			1.19			10.36			1		
07/11/26 16:18	345249.1			1.3			6.34			1.07			8.43			1		
07/11/26 16:19	345116.3			1.2			6.07			0.98			8.08			1		
07/11/26 16:20	344902.6			1.1			5.55			0.92			7.37			1		
07/11/26 16:21	344261.4			1.1			5.37			0.85			7.13			1		
07/11/26 16:22	343903.3			1.1			5.28			0.85			7			1		
07/11/26 16:23	343163.9			1			5.11			0.78			6.75			1		
07/11/26 16:24	342153.1			1			4.84			0.78			6.39			1		
07/11/26 16:25	342014.5			0.9			4.74			0.72			6.24			1		

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/11/26 16:26	341442.6			0.9			4.65			0.71			6.12			1		
07/11/26 16:27	341142.3			0.8			4.56			0.64			5.99			1		
07/11/26 16:28	340709			0.8			4.47			0.64			5.87			1		
07/11/26 16:29	340818.8			0.8			4.38			0.64			5.75			1		
07/11/26 16:30	340582			0.8			4.29			0.64			5.63			1		
07/11/26 16:31	340079.4			0.8			4.29			0.64			5.62			1		
07/11/26 16:32	339917.7			0.8			4.29			0.64			5.62			1		
07/11/26 16:33	339750.2			0.8			4.29			0.64			5.62			1		
07/11/26 16:34	339536.5			0.8			4.38			0.64			5.73			1		
07/11/26 16:35	339542.3			0.7			3.93			0.57			5.15			1		
07/11/26 16:36	339022.4			0.7			3.58			0.57			4.67			1		
07/11/26 16:37	338912.6			0.7			2.68			0.57			3.5			1		
07/11/26 16:38	338860.7			0.7			2.32			0.57			3.03			1		
07/11/26 16:39	338531.4			0.7			1.91			0.58			2.49			1		
07/11/26 16:40	338895.3			0.7			1.82			0.58			2.37			1		
07/11/26 16:41	338525.6			0.7			1.63			0.58			2.13			1		
07/11/26 16:42	338554.5			0.7			1.54			0.58			2.01			1		
07/11/26 16:43	338629.6			0.7			1.45			0.58			1.9			1		
07/11/26 16:44	338491			0.7			1.43			0.57			1.87			1		
07/11/26 16:45	338127			0.7			1.45			0.57			1.89			1		
07/11/26 16:46	338410.1			0.7			1.45			0.58			1.89			1		
07/11/26 16:47	337982.7			0.7			1.45			0.57			1.89			1		
07/11/26 16:48	337699.6			0.7			1.45			0.57			1.89			1		
07/11/26 16:49	338236.8			0.7			1.54			0.58			2.01			0		
07/11/26 16:50	337566.8			0.7			1.54			0.57			2.01			0		
07/11/26 16:51	337098.9			0.7			1.54			0.57			2			0		
07/11/26 16:52	337526.3			0.7			1.54			0.57			2.01			0		
07/11/26 16:53	337555.3			0.7			1.45			0.57			1.89			0		

Sample Spreadsheet Listing

	CT1_GasFlow_CT_scfh_1M			CT1_CO_Ppmvdc_1M			CT1_NOx_Ppmvdc_1M			CT1_CO_LbPerHr_1M			CT1_NOx_LbPerHr_1M			CT1_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/05/26 6:57	340275.8			0.9			1.48			0.69			1.94			0		
09/05/26 6:58	339992.8			0.9			1.48			0.69			1.94			0		
09/05/26 6:59	339686.7			0.9			1.48			0.69			1.94			0		
09/05/26 7:00	339507.6			0.8			1.48			0.62			1.94			0		
09/05/26 7:01	339692.4			0.8			1.48			0.62			1.94			0		
09/05/26 7:02	333858.5			0.8			1.48			0.61			1.91			1		
09/05/26 7:03	336977.6			0.9			2			0.72			2.61			0		
09/05/26 7:04	338889.5			1			2.29			0.77			3			0		
09/05/26 7:05	339114.8			1			0.88			0.77			1.16			0		
09/05/26 7:06	338889.5			0.9			0.78			0.69			1.02			0		
09/05/26 7:07	338953.1			0.9			0.78			0.69			1.02			0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/16/26 7:12	361006.6			0.7	X		1.79	X		0.61	X		2.49	X		0		
09/16/26 7:13	361272.3			1	X		1.8	X		0.87	X		2.5	X		0		
09/16/26 7:14	360602.3			0.7	X		1.76	X		0.61	X		2.45	X		0		
09/16/26 7:15	360070.8			0.6	X		1.79	X		0.53	X		2.49	X		0		
09/16/26 7:16	360313.5			0.7	X		1.76	X		0.6	X		2.45	X		0		
09/16/26 7:17	270470.5			1			1.5			0.61			1.56			1		
09/16/26 7:18	0			0			1.77			0			0			0		
09/16/26 7:19	0			0			0			0			0			0		
09/16/26 7:20	0			0			0			0			0			0		
09/16/26 7:21	0			0			0			0			0			0		
09/16/26 7:22	0			0			0			0			0			0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/16/26 14:20	0			0			0			0			0			0		
09/16/26 14:21	0			0			0			0			0			0		
09/16/26 14:22	0			0			0			0			0			0		
09/16/26 14:23	0			0			0			0			0			0		
09/16/26 14:24	0			0			0			0			0			0		
09/16/26 14:25	1345.9			-0.2			0			0			0			1		
09/16/26 14:26	7202.9			607.7			11.8			10.2			0.33			1		
09/16/26 14:27	31953.9			1129.6			10.19			84.71			1.26			1		
09/16/26 14:28	42368.4			838.5			11.8			83.34			1.93			1		
09/16/26 14:29	0			0			15.05			0			0			0		
09/16/26 14:30	0			0			7.59			0			0			0		
09/16/26 14:31	0			0			5.9			0			0			0		
09/16/26 14:32	0			0			0			0			0			0		
09/16/26 14:33	0			0			0			0			0			0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/16/26 14:20	0			0			0			0			0			0		
09/16/26 14:21	0			0			0			0			0			0		
09/16/26 14:22	0			0			0			0			0			0		
09/16/26 14:23	0			0			0			0			0			0		
09/16/26 14:24	0			0			0			0			0			0		
09/16/26 14:25	1345.9			-0.2			0			0			0			1		
09/16/26 14:26	7202.9			607.7			11.8			10.2			0.33			1		
09/16/26 14:27	31953.9			1129.6			10.19			84.71			1.26			1		
09/16/26 14:28	42368.4			838.5			11.8			83.34			1.93			1		
09/16/26 14:29	0			0			15.05			0			0			0		
09/16/26 14:30	0			0			7.59			0			0			0		
09/16/26 14:31	0			0			5.9			0			0			0		
09/16/26 14:32	0			0			0			0			0			0		
09/16/26 14:33	0			0			0			0			0			0		

Sample Spreadsheet Listing

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/16/26 14:57	0			0			0			0			0			0		
09/16/26 14:58	0			0			0			0			0			0		
09/16/26 14:59	0			0			0			0			0			0		
09/16/26 15:00	0			0			0			0			0			0		
09/16/26 15:01	0			0			0			0			0			0		
09/16/26 15:02	0			-0.2			0			0			0			1		
09/16/26 15:03	0			-0.2			0			0			0			1		
09/16/26 15:04	16086.7			1448.5			23.6			54.79			1.47			1		
09/16/26 15:05	37441.3			1062.8			11.8			93.26			1.7			1		
09/16/26 15:06	51269.5			699.5			15.41			84.08			3.05			1		
09/16/26 15:07	65779.3			436.9			19.47			67.38			4.94			1		
09/16/26 15:08	99136.9			289.4			22.8			67.3			8.73			1		
09/16/26 15:09	144029.5			195.2			31.22			65.93			17.36			1		
09/16/26 15:10	147922.7			162.6			43.74			56.4			24.98			1		
09/16/26 15:11	162241.9			1421.3			41.69			540.86			26.11			1		
09/16/26 15:12	183203.7			1770.4			44.8			760.88			31.69			1		
09/16/26 15:13	207319.3			1011.5			42.94			492.02			34.37			1		
09/16/26 15:14	228286.9			228.8			42.6			122.51			37.54			1		
09/16/26 15:15	250011.2			18.7			40.8			10.97			39.38			1		
09/16/26 15:16	276073.3			2.2			40.37			1.42			43.03			1		
09/16/26 15:17	302285.8			1.4			22.98			1.03			26.82			1		
09/16/26 15:18	326129.9			1.2			14.46			0.95			18.21			1		
09/16/26 15:19	345538			1.2			10.39			1			13.86			1		
09/16/26 15:20	365748.8			1.2			8.16			1.04			11.52			1		
09/16/26 15:21	384278.9			1.2			6.68			1.09			9.91			1		
09/16/26 15:22	406228.4			1.2			5.9			1.11			9.25			1		
09/16/26 15:23	423354.9			1			5.81			0.99			9.5			1		
09/16/26 15:24	429056			0.8			5.72			0.84			9.47			1		
09/16/26 15:25	431476.2			0.7			5.63			0.74			9.38			1		
09/16/26 15:26	429362.1			0.7			5.81			0.74			9.63			1		
09/16/26 15:27	426583.8			0.6			5.9			0.65			9.72			1		
09/16/26 15:28	412328.1			0.6			5.99			0.62			9.54			1		

	CT2_GasFlow_CT_scfh_1M			CT2_CO_Ppmvdc_1M			CT2_NOx_Ppmvdc_1M			CT2_CO_LbPerHr_1M			CT2_NOx_LbPerHr_1M			CT2_SUSD_TF_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
09/16/26 15:29	404287.7			0.6			6.54			0.6			10.2			1		
09/16/26 15:30	395923.7			0.6			6.63			0.59			10.13			1		
09/16/26 15:31	388466.7			0.6			6.53			0.57			9.79			1		
09/16/26 15:32	383285.4			0.6			6.53			0.56			9.66			1		
09/16/26 15:33	376088.3			0.6			5.72			0.55			8.31			1		
09/16/26 15:34	369636.3			0.6			3.75			0.54			5.36			1		
09/16/26 15:35	365454.3			0.6			2.95			0.54			4.16			1		
09/16/26 15:36	364483.8			0.6			2.95			0.54			4.15			1		
09/16/26 15:37	364547.4			0.6			3.04			0.54			4.28			1		
09/16/26 15:38	364408.8			0.6			3.27			0.54			4.6			1		
09/16/26 15:39	363247.8			0.6			3.31			0.53			4.64			1		
09/16/26 15:40	363842.7			0.6			3.4			0.53			4.77			1		
09/16/26 15:41	362866.5			0.6			3.49			0.53			4.88			1		
09/16/26 15:42	362791.4			0.6			3.63			0.54			5.09			1		
09/16/26 15:43	363409.5			0.6			3.4			0.53			4.77			1		
09/16/26 15:44	362387.1			0.6			2.68			0.53			3.75			1		
09/16/26 15:45	363588.5			0.6			2.54			0.54			3.57			1		
09/16/26 15:46	361387.8			0.6			2.32			0.53			3.24			1		
09/16/26 15:47	359949.6			0.6			2.09			0.54			2.9			1		
09/16/26 15:48	360140.2			0.6			1.91			0.54			2.65			1		
09/16/26 15:49	359995.8			0.6			1.72			0.54			2.4			1		
09/16/26 15:50	360400.1			0.6			1.61			0.53			2.24			1		
09/16/26 15:51	360429			0.6			1.63			0.54			2.27			1		
09/16/26 15:52	360249.9			0.6			1.63			0.54			2.27			1		
09/16/26 15:53	359475.9			0.6			1.7			0.53			2.36			1		
09/16/26 15:54	359452.8			0.6			1.79			0.53			2.48			1		
09/16/26 15:55	361151			0.6			1.82			0.54			2.53			1		
09/16/26 15:56	361757.5			0.6			1.91			0.54			2.66			1		
09/16/26 15:57	361890.4			0.6			1.82			0.54			2.54			1		
09/16/26 15:58	361676.6			0.6			1.63			0.54			2.28			0		
09/16/26 15:59	360919.9			0.6			1.54			0.54			2.15			0		
09/16/26 16:00	361590			0.6			1.45			0.54			2.03			0		
09/16/26 16:01	361520.7			0.6			1.36			0.54			1.9			0		
09/16/26 16:02	362352.5			0.6			1.36			0.54			1.9			0		

CO LbPerHr 1-Hour Block Excess Emissions

CT5

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:15 **Location:** Roseville, CA

Tag Name: CT5_CO_Norm_LbPerHr_1H
Total Operating Time: 81.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,079.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**81.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

CO Ppmvdc 1-Hour Block Excess Emissions

CT5

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:15 **Location:** Roseville, CA

Tag Name: CT5_CO_Norm_Ppmvdc_1H
Total Operating Time: 81.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,079.00 Hour(s) Report Time: 2,160.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Tag Value	Limit	Reason Code	Action Code
1	07/14/26 20:00	07/14/26 20:59	1	12.0	4.0		

Total Operating Time:	**81.00 Hour(s)**
Total Duration (Online only):	**1.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**1.23 %**
Time in compliance as a percentage of operating time:	**98.77 %**

CO Lbs SUSD 1-Hour Block Excess Emissions

CT5

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:15 **Location:** Roseville, CA

Tag Name: CT5_CO_SUSD_Lbs_1H
Total Operating Time: 81.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,079.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**81.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Startup/Shutdown Event Report

CT5 - CO Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:15 **Location:** Roseville, CA

Tag Name: CT5_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 55.82 Hours

Non-Operating Time: 2,104.18 Hours Report Time: 2,160.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
07/14/2026 15:51 07/14/2026 16:01 Startup	11	0.58	19.40		
07/14/2026 20:23 07/14/2026 20:25 Startup	3	0.03	19.40		
07/14/2026 20:25 07/14/2026 20:34 Shutdown	10	0.01	21.60		
07/14/2026 20:29 07/14/2026 20:34 Shutdown	6	0.07	21.60		
07/15/2026 08:53 07/15/2026 09:02 Startup	10	0.49	19.40		
07/15/2026 13:57 07/15/2026 14:04 Shutdown	8	0.08	21.60		
07/20/2026 15:07 07/20/2026 15:19 Startup	13	0.55	19.40		
07/20/2026 19:03 07/20/2026 19:10 Shutdown	8	0.07	21.60		
07/21/2026 15:51 07/21/2026 16:01 Startup	11	0.40	19.40		
07/21/2026 20:58 07/21/2026 21:05 Shutdown	8	0.08	21.60		
08/05/2026 13:52 08/05/2026 13:58 Startup	7	0.50	19.40		
08/05/2026 13:58 08/05/2026 14:03 Shutdown	6	0.08	21.60		
08/06/2026 14:53 08/06/2026 15:07 Startup	15	0.00 SI	19.40		

Startup/Shutdown Event Report

CT5 - CO Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:15 **Location:** Roseville, CA

Tag Name: CT5_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 55.82 Hours

Non-Operating Time: 2,104.18 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
08/06/2026 15:24 08/06/2026 15:31 Shutdown	8	0.00 SI	21.60		
08/07/2026 11:51 08/07/2026 12:01 Startup	11	0.00 SI	19.40		
08/07/2026 13:58 08/07/2026 14:04 Shutdown	7	0.05	21.60		
08/19/2026 14:57 08/19/2026 15:06 Startup	10	0.39	19.40		
08/19/2026 15:18 08/19/2026 15:26 Shutdown	9	0.05	21.60		
08/20/2026 11:56 08/20/2026 12:04 Startup	9	0.00 SI	19.40		
08/20/2026 13:58 08/20/2026 14:04 Shutdown	7	0.07	21.60		
08/20/2026 15:55 08/20/2026 16:05 Startup	11	0.27	19.40		
08/20/2026 20:59 08/20/2026 21:05 Shutdown	7	0.10	21.60		
08/25/2026 14:51 08/25/2026 15:00 Startup	10	0.54	19.40		
08/25/2026 19:58 08/25/2026 20:04 Shutdown	7	0.08	21.60		
08/27/2026 13:52 08/27/2026 14:01 Startup	10	0.39	19.40		
08/27/2026 15:07 08/27/2026 15:12 Shutdown	6	0.00 SI	21.60		
08/28/2026 08:54 08/28/2026 09:04 Startup	11	0.00 SI	19.40		

Startup/Shutdown Event Report

CT5 - CO Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:15 **Location:** Roseville, CA

Tag Name: CT5_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 55.82 Hours

Non-Operating Time: 2,104.18 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
08/28/2026 11:55 08/28/2026 12:01 Shutdown	7	0.08	21.60		
09/09/2026 11:51 09/09/2026 12:00 Startup	10	0.57	19.40		
09/09/2026 20:58 09/09/2026 21:04 Shutdown	7	0.06	21.60		
09/10/2026 15:51 09/10/2026 16:00 Startup	10	0.65	19.40		
09/10/2026 22:59 09/10/2026 23:05 Shutdown	7	0.07	21.60		

No excess emissions were found in the reporting period.

Startup/Shutdown Event Report

CT5 - CO Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:15 **Location:** Roseville, CA

Tag Name: CT5_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 55.82 Hours

Non-Operating Time: 2,104.18 Hours Report Time: 2,160.00 Hours

Event Invalid Information

Invalid Event Period		Reason	Action
Begin/End	Duration in Minute(s)	Code - Description	Code - Description
08/06/2026 14:53 08/06/2026 15:07	15		
08/06/2026 15:24 08/06/2026 15:31	8		
08/07/2026 11:51 08/07/2026 12:01	11		
08/20/2026 11:56 08/20/2026 12:04	9		
08/27/2026 15:07 08/27/2026 15:12	6		
08/28/2026 08:54 08/28/2026 09:04	11		

Total CMS Downtime	**60**	**Minute(s)**
Total Downtime as a percentage of operating time	**1.79**	**%**
Total Availability as a percentage of operating time	**98.21**	**%**

Startup/Shutdown Event Report

CT5 - CO Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:15 **Location:** Roseville, CA

Tag Name: CT5_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 55.82 Hours

Non-Operating Time: 2,104.18 Hours Report Time: 2,160.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	60
2. Total CMS Downtime in Minute(s)	60
3. Total Downtime as a percentage of operating time	1.79
4. Total Availability as a percentage of operating time	98.21

NOx LbPerHr 1-Hour Block Excess Emissions

CT5

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:15 **Location:** Roseville, CA

Tag Name: CT5_NOx_Norm_LbPerHr_1H
Total Operating Time: 81.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: -71.00 Hour(s) Report Time: 10.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**81.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

NOx Ppmvdc 1-Hour Block Excess Emissions

CT5

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:15 **Location:** Roseville, CA

Tag Name: CT5_NOx_Norm_Ppmvdc_1H
Total Operating Time: 81.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: -71.00 Hour(s) Report Time: 10.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Tag Value	Limit	Reason Code	Action Code
1	07/14/26 16:00	07/14/26 16:59	1	2.6	2.5		
2	07/14/26 20:00	07/14/26 20:59	1	17.1	2.5		
3	08/19/26 15:00	08/19/26 15:59	1	2.7	2.5	4 - Other known causes	24 - Unit Shutdown To Facilitate Repairs

Total Operating Time:	**81.00 Hour(s)**
Total Duration (Online only):	**3.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**3.70 %**
Time in compliance as a percentage of operating time:	**96.30 %**

Report Code	Type	Text	Duration	Duration Percent
4	Reason	Other known causes	1	33.33
24	Action	Unit Shutdown To Facilitate Repairs	1	33.33

NOx Lbs SUSD 1-Hour Block Excess Emissions

CT5

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:18 **Location:** Roseville, CA

Tag Name: CT5_NOx_SUSD_Lbs_1H
Total Operating Time: 81.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: -57.00 Hour(s) Report Time: 24.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**81.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Startup/Shutdown Event Report

CT5 - NOx Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:18 **Location:** Roseville, CA

Tag Name: CT5_NOx_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 55.82 Hours

Non-Operating Time: -31.82 Hours Report Time: 24.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
07/14/2026 15:51 07/14/2026 16:01 Startup	11	1.21	3.10		
07/14/2026 20:23 07/14/2026 20:25 Startup	3	0.04	3.10		
07/14/2026 20:25 07/14/2026 20:34 Shutdown	10	0.04	3.40		
07/14/2026 20:29 07/14/2026 20:34 Shutdown	6	0.19	3.40		
07/15/2026 08:53 07/15/2026 09:02 Startup	10	1.06	3.10		
07/15/2026 13:57 07/15/2026 14:04 Shutdown	8	0.12	3.40		
07/20/2026 15:07 07/20/2026 15:19 Startup	13	1.39	3.10		
07/20/2026 19:03 07/20/2026 19:10 Shutdown	8	0.13	3.40		
07/21/2026 15:51 07/21/2026 16:01 Startup	11	1.22	3.10		
07/21/2026 20:58 07/21/2026 21:05 Shutdown	8	0.12	3.40		
08/05/2026 13:52 08/05/2026 13:58 Startup	7	0.37	3.10		
08/05/2026 13:58 08/05/2026 14:03 Shutdown	6	0.45	3.40		
08/06/2026 14:53 08/06/2026 15:07 Startup	15	0.00 SI	3.10		

Startup/Shutdown Event Report

CT5 - NOx Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:18 **Location:** Roseville, CA

Tag Name: CT5_NOx_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 55.82 Hours

Non-Operating Time: -31.82 Hours Report Time: 24.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
08/06/2026 15:24 08/06/2026 15:31 Shutdown	8	0.00 SI	3.40		
08/07/2026 11:51 08/07/2026 12:01 Startup	11	0.00 SI	3.10		
08/07/2026 13:58 08/07/2026 14:04 Shutdown	7	0.07	3.40		
08/19/2026 14:57 08/19/2026 15:06 Startup	10	1.17	3.10		
08/19/2026 15:18 08/19/2026 15:26 Shutdown	9	0.47	3.40		
08/20/2026 11:56 08/20/2026 12:04 Startup	9	0.00 SI	3.10		
08/20/2026 13:58 08/20/2026 14:04 Shutdown	7	0.08	3.40		
08/20/2026 15:55 08/20/2026 16:05 Startup	11	0.97	3.10		
08/20/2026 20:59 08/20/2026 21:05 Shutdown	7	0.10	3.40		
08/25/2026 14:51 08/25/2026 15:00 Startup	10	1.14	3.10		
08/25/2026 19:58 08/25/2026 20:04 Shutdown	7	0.09	3.40		
08/27/2026 13:52 08/27/2026 14:01 Startup	10	1.07	3.10		
08/27/2026 15:07 08/27/2026 15:12 Shutdown	6	0.00 SI	3.40		
08/28/2026 08:54 08/28/2026 09:04 Startup	11	0.00 SI	3.10		

Startup/Shutdown Event Report

CT5 - NOx Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:18 **Location:** Roseville, CA

Tag Name: CT5_NOx_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 55.82 Hours

Non-Operating Time: -31.82 Hours Report Time: 24.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
08/28/2026 11:55 08/28/2026 12:01 Shutdown	7	0.11	3.40		
09/09/2026 11:51 09/09/2026 12:00 Startup	10	1.15	3.10		
09/09/2026 20:58 09/09/2026 21:04 Shutdown	7	0.10	3.40		
09/10/2026 15:51 09/10/2026 16:00 Startup	10	1.08	3.10		
09/10/2026 22:59 09/10/2026 23:05 Shutdown	7	0.10	3.40		

No excess emissions were found in the reporting period.

Startup/Shutdown Event Report

CT5 - NOx Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:18 **Location:** Roseville, CA

Tag Name: CT5_NOx_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 55.82 Hours

Non-Operating Time: -31.82 Hours Report Time: 24.00 Hours

Event Invalid Information

Invalid Event Period		Reason	Action
Begin/End	Duration in Minute(s)	Code - Description	Code - Description
08/06/2026 14:53 08/06/2026 15:07	15		
08/06/2026 15:24 08/06/2026 15:31	8		
08/07/2026 11:51 08/07/2026 12:01	11		
08/20/2026 11:56 08/20/2026 12:04	9		
08/27/2026 15:07 08/27/2026 15:12	6		
08/28/2026 08:54 08/28/2026 09:04	11		

Total CMS Downtime	**60**	**Minute(s)**
Total Downtime as a percentage of operating time	**1.79**	**%**
Total Availability as a percentage of operating time	**98.21**	**%**

Startup/Shutdown Event Report

CT5 - NOx Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:18 **Location:** Roseville, CA

Tag Name: CT5_NOx_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 55.82 Hours

Non-Operating Time: -31.82 Hours Report Time: 24.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	60
2. Total CMS Downtime in Minute(s)	60
3. Total Downtime as a percentage of operating time	1.79
4. Total Availability as a percentage of operating time	98.21

PM10 LbPerHr 1-Hour Block Excess Emissions

CT5

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:18 **Location:** Roseville, CA

Tag Name: CT5_PM10_LbPerHr_1H
Total Operating Time: 81.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,079.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**81.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

SO2 LbPerHr 1-Hour Block Excess Emissions

CT5

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:20 **Location:** Roseville, CA

Tag Name: CT5_SO2_P60_LbPerHr_1H
Total Operating Time: 81.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,079.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**81.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

VOC LbPerHr 1-Hour Block Excess Emissions

CT5

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:20 **Location:** Roseville, CA

Tag Name: CT5_VOC_Norm_LbPerHr_1H
Total Operating Time: 81.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,079.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**81.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

VOC SUSD Lb 1-Hour Block Excess Emissions

CT5

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:20 **Location:** Roseville, CA

Tag Name: CT5_VOC_SUSD_Lbs_1H
Total Operating Time: 81.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,079.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**81.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Startup/Shutdown Event Report

CT5 - VOC Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:20 **Location:** Roseville, CA

Tag Name: CT5_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 55.82 Hours

Non-Operating Time: 2,104.18 Hours Report Time: 2,160.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
07/14/2026 15:51 07/14/2026 16:01 Startup	11	0.04	0.80		
07/14/2026 20:23 07/14/2026 20:25 Startup	3	0.00	0.80		
07/14/2026 20:25 07/14/2026 20:34 Shutdown	10	0.00	0.90		
07/14/2026 20:29 07/14/2026 20:34 Shutdown	6	0.01	0.90		
07/15/2026 08:53 07/15/2026 09:02 Startup	10	0.05	0.80		
07/15/2026 13:57 07/15/2026 14:04 Shutdown	8	0.02	0.90		
07/20/2026 15:07 07/20/2026 15:19 Startup	13	0.05	0.80		
07/20/2026 19:03 07/20/2026 19:10 Shutdown	8	0.02	0.90		
07/21/2026 15:51 07/21/2026 16:01 Startup	11	0.04	0.80		
07/21/2026 20:58 07/21/2026 21:05 Shutdown	8	0.02	0.90		
08/05/2026 13:52 08/05/2026 13:58 Startup	7	0.01	0.80		
08/05/2026 13:58 08/05/2026 14:03 Shutdown	6	0.01	0.90		
08/06/2026 14:53 08/06/2026 15:07 Startup	15	0.04	0.80		

Startup/Shutdown Event Report

CT5 - VOC Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:20 **Location:** Roseville, CA

Tag Name: CT5_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 55.82 Hours

Non-Operating Time: 2,104.18 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
08/06/2026 15:24 08/06/2026 15:31 Shutdown	8	0.02	0.90		
08/07/2026 11:51 08/07/2026 12:01 Startup	11	0.05	0.80		
08/07/2026 13:58 08/07/2026 14:04 Shutdown	7	0.01	0.90		
08/19/2026 14:57 08/19/2026 15:06 Startup	10	0.04	0.80		
08/19/2026 15:18 08/19/2026 15:26 Shutdown	9	0.02	0.90		
08/20/2026 11:56 08/20/2026 12:04 Startup	9	0.04	0.80		
08/20/2026 13:58 08/20/2026 14:04 Shutdown	7	0.02	0.90		
08/20/2026 15:55 08/20/2026 16:05 Startup	11	0.04	0.80		
08/20/2026 20:59 08/20/2026 21:05 Shutdown	7	0.02	0.90		
08/25/2026 14:51 08/25/2026 15:00 Startup	10	0.04	0.80		
08/25/2026 19:58 08/25/2026 20:04 Shutdown	7	0.02	0.90		
08/27/2026 13:52 08/27/2026 14:01 Startup	10	0.04	0.80		
08/27/2026 15:07 08/27/2026 15:12 Shutdown	6	0.02	0.90		
08/28/2026 08:54 08/28/2026 09:04 Startup	11	0.04	0.80		

Startup/Shutdown Event Report

CT5 - VOC Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:20 **Location:** Roseville, CA

Tag Name: CT5_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 55.82 Hours

Non-Operating Time: 2,104.18 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
08/28/2026 11:55 08/28/2026 12:01 Shutdown	7	0.02	0.90		
09/09/2026 11:51 09/09/2026 12:00 Startup	10	0.05	0.80		
09/09/2026 20:58 09/09/2026 21:04 Shutdown	7	0.01	0.90		
09/10/2026 15:51 09/10/2026 16:00 Startup	10	0.03	0.80		
09/10/2026 22:59 09/10/2026 23:05 Shutdown	7	0.01	0.90		

No excess emissions were found in the reporting period.

Startup/Shutdown Event Report

CT5 - VOC Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:20 **Location:** Roseville, CA

Tag Name: CT5_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 55.82 Hours

Non-Operating Time: 2,104.18 Hours Report Time: 2,160.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Startup/Shutdown Event Report

CT5 - VOC Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:20 **Location:** Roseville, CA

Tag Name: CT5_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 55.82 Hours

Non-Operating Time: 2,104.18 Hours Report Time: 2,160.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

CO LbPerHr 1-Hour Block Excess Emissions

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:30 **Location:** Roseville, CA

Tag Name: CT6_CO_Norm_LbPerHr_1H
Total Operating Time: 97.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,063.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**97.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

CO Ppmvdc 1-Hour Block Excess Emissions

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:30 **Location:** Roseville, CA

Tag Name: CT6_CO_Norm_Ppmvdc_1H
Total Operating Time: 97.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,063.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**97.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

CO Lbs SUSD 1-Hour Block Excess Emissions

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:30 **Location:** Roseville, CA

Tag Name: CT6_CO_SUSD_Lbs_1H
Total Operating Time: 97.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,063.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**97.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Startup/Shutdown Event Report

CT6 - CO Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:30 **Location:** Roseville, CA

Tag Name: CT6_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 75.25 Hours

Non-Operating Time: 2,084.75 Hours Report Time: 2,160.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
07/14/2026 15:51 07/14/2026 15:53 Startup	3	0.00 SI	19.40		
07/14/2026 16:02 07/14/2026 16:04 Startup	3	0.00 SI	19.40		
07/14/2026 16:16 07/14/2026 16:18 Startup	3	0.00 SI	19.40		
07/14/2026 19:42 07/14/2026 19:42 Startup	1	0.00 SI	19.40		
07/14/2026 19:44 07/14/2026 19:44 Startup	1	0.00 SI	19.40		
07/15/2026 07:20 07/15/2026 07:20 Startup	1	0.00 SI	19.40		
07/15/2026 07:27 07/15/2026 07:27 Startup	1	0.00 SI	19.40		
07/15/2026 11:51 07/15/2026 12:00 Startup	10	0.00 SI	19.40		
07/15/2026 20:58 07/15/2026 21:05 Shutdown	8	0.09	21.60		
07/20/2026 15:06 07/20/2026 15:16 Startup	11	0.49	19.40		
07/20/2026 21:28 07/20/2026 21:35 Shutdown	8	0.12	21.60		
07/21/2026 13:51 07/21/2026 14:00 Startup	10	0.44	19.40		
07/21/2026 20:58 07/21/2026 21:05 Shutdown	8	0.10	21.60		

Startup/Shutdown Event Report

CT6 - CO Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:30 **Location:** Roseville, CA

Tag Name: CT6_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 75.25 Hours

Non-Operating Time: 2,084.75 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
08/03/2026 14:51 08/03/2026 14:59 Startup	9	0.51	19.40		
08/03/2026 20:58 08/03/2026 21:04 Shutdown	7	0.09	21.60		
08/04/2026 14:52 08/04/2026 15:01 Startup	10	0.48	19.40		
08/04/2026 19:58 08/04/2026 20:04 Shutdown	7	0.10	21.60		
08/05/2026 14:05 08/05/2026 14:14 Startup	10	0.47	19.40		
08/05/2026 19:58 08/05/2026 20:04 Shutdown	7	0.11	21.60		
08/06/2026 15:31 08/06/2026 15:42 Startup	12	0.52	19.40		
08/06/2026 19:58 08/06/2026 20:04 Shutdown	7	0.10	21.60		
08/19/2026 15:31 08/19/2026 15:42 Startup	12	0.62	19.40		
08/19/2026 21:58 08/19/2026 22:04 Shutdown	7	0.10	21.60		
08/27/2026 15:20 08/27/2026 15:30 Startup	11	0.44	19.40		
08/27/2026 19:58 08/27/2026 20:04 Shutdown	7	0.09	21.60		
09/08/2026 16:53 09/08/2026 17:02 Startup	10	0.50	19.40		
09/08/2026 21:58 09/08/2026 22:05 Shutdown	8	0.12	21.60		

Startup/Shutdown Event Report

CT6 - CO Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:30 **Location:** Roseville, CA

Tag Name: CT6_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 75.25 Hours

Non-Operating Time: 2,084.75 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
09/09/2026 11:51 09/09/2026 12:03 Startup	13	0.46	19.40		
09/09/2026 20:58 09/09/2026 21:04 Shutdown	7	0.10	21.60		
09/10/2026 15:51 09/10/2026 16:00 Startup	10	0.36	19.40		
09/10/2026 19:59 09/10/2026 20:05 Shutdown	7	0.06	21.60		

No excess emissions were found in the reporting period.

Startup/Shutdown Event Report

CT6 - CO Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:30 **Location:** Roseville, CA

Tag Name: CT6_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 75.25 Hours

Non-Operating Time: 2,084.75 Hours Report Time: 2,160.00 Hours

Event Invalid Information

Invalid Event Period		Reason	Action
Begin/End	Duration in Minute(s)	Code - Description	Code - Description
07/14/2026 15:51 07/14/2026 15:53	3		
07/14/2026 16:02 07/14/2026 16:04	3		
07/14/2026 16:16 07/14/2026 16:18	3		
07/14/2026 19:42 07/14/2026 19:42	1		
07/14/2026 19:44 07/14/2026 19:44	1		
07/15/2026 07:20 07/15/2026 07:20	1		
07/15/2026 07:27 07/15/2026 07:27	1		
07/15/2026 11:51 07/15/2026 12:00	10		

Total CMS Downtime	23	Minute(s)
Total Downtime as a percentage of operating time	0.51	%
Total Availability as a percentage of operating time	99.49	%

Startup/Shutdown Event Report

CT6 - CO Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:30 **Location:** Roseville, CA

Tag Name: CT6_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 75.25 Hours

Non-Operating Time: 2,084.75 Hours Report Time: 2,160.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	23
2. Total CMS Downtime in Minute(s)	23
3. Total Downtime as a percentage of operating time	0.51
4. Total Availability as a percentage of operating time	99.49

NOx LbPerHr 1-Hour Block Excess Emissions

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:32 **Location:** Roseville, CA

Tag Name: CT6_NOx_Norm_LbPerHr_1H
Total Operating Time: 97.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: -84.00 Hour(s) Report Time: 13.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**97.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

NOx Ppmvdc 1-Hour Block Excess Emissions

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:32 **Location:** Roseville, CA

Tag Name: CT6_NOx_Norm_Ppmvdc_1H
Total Operating Time: 97.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: -84.00 Hour(s) Report Time: 13.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Tag Value	Limit	Reason Code	Action Code
1	07/20/26 15:00	07/20/26 15:59	1	2.7	2.5	1 - Startup/shutdown	

Total Operating Time:	**97.00 Hour(s)**
Total Duration (Online only):	**1.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**1.03 %**
Time in compliance as a percentage of operating time:	**98.97 %**

Report Code	Type	Text	Duration	Duration Percent
1	Reason	Startup/shutdown	1	100.00

NOx Lbs SUSD 1-Hour Block Excess Emissions

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:32 **Location:** Roseville, CA

Tag Name: CT6_NOx_SUSD_Lbs_1H
Total Operating Time: 97.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,063.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**97.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Startup/Shutdown Event Report

CT6 - NOx Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:32 **Location:** Roseville, CA

Tag Name: CT6_NOx_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 75.25 Hours

Non-Operating Time: 2,084.75 Hours Report Time: 2,160.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
07/14/2026 15:51 07/14/2026 15:53 Startup	3	0.00 SI	3.10		
07/14/2026 16:02 07/14/2026 16:04 Startup	3	0.00 SI	3.10		
07/14/2026 16:16 07/14/2026 16:18 Startup	3	0.00 SI	3.10		
07/14/2026 19:42 07/14/2026 19:42 Startup	1	0.00 SI	3.10		
07/14/2026 19:44 07/14/2026 19:44 Startup	1	0.00 SI	3.10		
07/15/2026 07:20 07/15/2026 07:20 Startup	1	0.00 SI	3.10		
07/15/2026 07:27 07/15/2026 07:27 Startup	1	0.00 SI	3.10		
07/15/2026 11:51 07/15/2026 12:00 Startup	10	0.00 SI	3.10		
07/15/2026 20:58 07/15/2026 21:05 Shutdown	8	0.12	3.40		
07/20/2026 15:06 07/20/2026 15:16 Startup	11	1.15	3.10		
07/20/2026 21:28 07/20/2026 21:35 Shutdown	8	0.12	3.40		
07/21/2026 13:51 07/21/2026 14:00 Startup	10	0.98	3.10		
07/21/2026 20:58 07/21/2026 21:05 Shutdown	8	0.12	3.40		

Startup/Shutdown Event Report

CT6 - NOx Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:32 **Location:** Roseville, CA

Tag Name: CT6_NOx_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 75.25 Hours

Non-Operating Time: 2,084.75 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
08/03/2026 14:51 08/03/2026 14:59 Startup	9	0.89	3.10		
08/03/2026 20:58 08/03/2026 21:04 Shutdown	7	0.10	3.40		
08/04/2026 14:52 08/04/2026 15:01 Startup	10	0.99	3.10		
08/04/2026 19:58 08/04/2026 20:04 Shutdown	7	0.09	3.40		
08/05/2026 14:05 08/05/2026 14:14 Startup	10	1.06	3.10		
08/05/2026 19:58 08/05/2026 20:04 Shutdown	7	0.10	3.40		
08/06/2026 15:31 08/06/2026 15:42 Startup	12	1.25	3.10		
08/06/2026 19:58 08/06/2026 20:04 Shutdown	7	0.09	3.40		
08/19/2026 15:31 08/19/2026 15:42 Startup	12	1.16	3.10		
08/19/2026 21:58 08/19/2026 22:04 Shutdown	7	0.09	3.40		
08/27/2026 15:20 08/27/2026 15:30 Startup	11	0.62	3.10		
08/27/2026 19:58 08/27/2026 20:04 Shutdown	7	0.11	3.40		
09/08/2026 16:53 09/08/2026 17:02 Startup	10	0.80	3.10		
09/08/2026 21:58 09/08/2026 22:05 Shutdown	8	0.11	3.40		

Startup/Shutdown Event Report

CT6 - NOx Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:32 **Location:** Roseville, CA

Tag Name: CT6_NOx_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 75.25 Hours

Non-Operating Time: 2,084.75 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
09/09/2026 11:51 09/09/2026 12:03 Startup	13	1.35	3.10		
09/09/2026 20:58 09/09/2026 21:04 Shutdown	7	0.10	3.40		
09/10/2026 15:51 09/10/2026 16:00 Startup	10	0.75	3.10		
09/10/2026 19:59 09/10/2026 20:05 Shutdown	7	0.09	3.40		

No excess emissions were found in the reporting period.

Startup/Shutdown Event Report

CT6 - NOx Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:32 **Location:** Roseville, CA

Tag Name: CT6_NOx_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 75.25 Hours

Non-Operating Time: 2,084.75 Hours Report Time: 2,160.00 Hours

Event Invalid Information

Invalid Event Period		Reason	Action
Begin/End	Duration in Minute(s)	Code - Description	Code - Description
07/14/2026 15:51 07/14/2026 15:53	3		
07/14/2026 16:02 07/14/2026 16:04	3		
07/14/2026 16:16 07/14/2026 16:18	3		
07/14/2026 19:42 07/14/2026 19:42	1		
07/14/2026 19:44 07/14/2026 19:44	1		
07/15/2026 07:20 07/15/2026 07:20	1		
07/15/2026 07:27 07/15/2026 07:27	1		
07/15/2026 11:51 07/15/2026 12:00	10		

Total CMS Downtime	23	Minute(s)
Total Downtime as a percentage of operating time	0.51	%
Total Availability as a percentage of operating time	99.49	%

Startup/Shutdown Event Report

CT6 - NOx Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:32 **Location:** Roseville, CA

Tag Name: CT6_NOx_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 75.25 Hours

Non-Operating Time: 2,084.75 Hours Report Time: 2,160.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	23
2. Total CMS Downtime in Minute(s)	23
3. Total Downtime as a percentage of operating time	0.51
4. Total Availability as a percentage of operating time	99.49

PM10 LbPerHr 1-Hour Block Excess Emissions

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:32 **Location:** Roseville, CA

Tag Name: CT6_PM10_LbPerHr_1H
Total Operating Time: 97.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,063.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**97.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

SO2 LbPerHr 1-Hour Block Excess Emissions

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:35 **Location:** Roseville, CA

Tag Name: CT6_SO2_P60_LbPerHr_1H
Total Operating Time: 97.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,063.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**97.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

VOC LbPerHr 1-Hour Block Excess Emissions

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:35 **Location:** Roseville, CA

Tag Name: CT6_VOC_Norm_LbPerHr_1H
Total Operating Time: 97.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,063.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**97.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

VOC SUSD Lb 1-Hour Block Excess Emissions

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:35 **Location:** Roseville, CA

Tag Name: CT6_VOC_SUSD_Lbs_1H
Total Operating Time: 97.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,063.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**97.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Startup/Shutdown Event Report

CT6 - VOC Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:35 **Location:** Roseville, CA

Tag Name: CT6_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 75.25 Hours

Non-Operating Time: 2,084.75 Hours Report Time: 2,160.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
07/14/2026 15:51 07/14/2026 15:53 Startup	3	0.00	0.80		
07/14/2026 16:02 07/14/2026 16:04 Startup	3	0.00	0.80		
07/14/2026 16:16 07/14/2026 16:18 Startup	3	0.00	0.80		
07/14/2026 19:42 07/14/2026 19:42 Startup	1	0.00	0.80		
07/14/2026 19:44 07/14/2026 19:44 Startup	1	0.00	0.80		
07/15/2026 07:20 07/15/2026 07:20 Startup	1	0.00	0.80		
07/15/2026 07:27 07/15/2026 07:27 Startup	1	0.00	0.80		
07/15/2026 11:51 07/15/2026 12:00 Startup	10	0.05	0.80		
07/15/2026 20:58 07/15/2026 21:05 Shutdown	8	0.02	0.90		
07/20/2026 15:06 07/20/2026 15:16 Startup	11	0.05	0.80		
07/20/2026 21:28 07/20/2026 21:35 Shutdown	8	0.02	0.90		
07/21/2026 13:51 07/21/2026 14:00 Startup	10	0.05	0.80		
07/21/2026 20:58 07/21/2026 21:05 Shutdown	8	0.02	0.90		

Startup/Shutdown Event Report

CT6 - VOC Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:35 **Location:** Roseville, CA

Tag Name: CT6_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 75.25 Hours

Non-Operating Time: 2,084.75 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
08/03/2026 14:51 08/03/2026 14:59 Startup	9	0.04	0.80		
08/03/2026 20:58 08/03/2026 21:04 Shutdown	7	0.02	0.90		
08/04/2026 14:52 08/04/2026 15:01 Startup	10	0.04	0.80		
08/04/2026 19:58 08/04/2026 20:04 Shutdown	7	0.02	0.90		
08/05/2026 14:05 08/05/2026 14:14 Startup	10	0.04	0.80		
08/05/2026 19:58 08/05/2026 20:04 Shutdown	7	0.02	0.90		
08/06/2026 15:31 08/06/2026 15:42 Startup	12	0.04	0.80		
08/06/2026 19:58 08/06/2026 20:04 Shutdown	7	0.02	0.90		
08/19/2026 15:31 08/19/2026 15:42 Startup	12	0.05	0.80		
08/19/2026 21:58 08/19/2026 22:04 Shutdown	7	0.02	0.90		
08/27/2026 15:20 08/27/2026 15:30 Startup	11	0.04	0.80		
08/27/2026 19:58 08/27/2026 20:04 Shutdown	7	0.02	0.90		
09/08/2026 16:53 09/08/2026 17:02 Startup	10	0.04	0.80		
09/08/2026 21:58 09/08/2026 22:05 Shutdown	8	0.02	0.90		

Startup/Shutdown Event Report

CT6 - VOC Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:35 **Location:** Roseville, CA

Tag Name: CT6_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 75.25 Hours

Non-Operating Time: 2,084.75 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
09/09/2026 11:51 09/09/2026 12:03 Startup	13	0.04	0.80		
09/09/2026 20:58 09/09/2026 21:04 Shutdown	7	0.02	0.90		
09/10/2026 15:51 09/10/2026 16:00 Startup	10	0.04	0.80		
09/10/2026 19:59 09/10/2026 20:05 Shutdown	7	0.01	0.90		

No excess emissions were found in the reporting period.

Startup/Shutdown Event Report

CT6 - VOC Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:35 **Location:** Roseville, CA

Tag Name: CT6_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 75.25 Hours

Non-Operating Time: 2,084.75 Hours Report Time: 2,160.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Startup/Shutdown Event Report

CT6 - VOC Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:35 **Location:** Roseville, CA

Tag Name: CT6_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 75.25 Hours

Non-Operating Time: 2,084.75 Hours Report Time: 2,160.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Replace the dates with the ones you need

7/1/2026 0:00
9/30/2026 0:00

1D

TOWER AVG.

5233

	519-AIT-9504-1
7/1/26 0:00	4082.0
7/2/26 0:00	4357.4
7/3/26 0:00	4365.0
7/4/26 0:00	3989.4
7/5/26 0:00	4290.0
7/6/26 0:00	4360.1
7/7/26 0:00	4123.1
7/8/26 0:00	4548.0
7/9/26 0:00	4311.8
7/10/26 0:00	4925.6
7/11/26 0:00	4626.7
7/12/26 0:00	4483.0
7/13/26 0:00	4828.6
7/14/26 0:00	5061.3
7/15/26 0:00	5479.3
7/16/26 0:00	5390.8
7/17/26 0:00	5506.5
7/18/26 0:00	5869.8
7/19/26 0:00	5454.5
7/20/26 0:00	6159.2
7/21/26 0:00	5783.3
7/22/26 0:00	5783.2
7/23/26 0:00	5307.0
7/24/26 0:00	5522.4
7/25/26 0:00	5666.6
7/26/26 0:00	5892.1
7/27/26 0:00	5564.4
7/28/26 0:00	6444.0
7/29/26 0:00	5712.0
7/30/26 0:00	6155.2
7/31/26 0:00	6302.8
8/1/26 0:00	5758.8
8/2/26 0:00	5518.1
8/3/26 0:00	5714.7
8/4/26 0:00	4471.0
8/5/26 0:00	4833.0
8/6/26 0:00	3929.4
8/7/26 0:00	4327.8
8/8/26 0:00	4780.0
8/9/26 0:00	4868.0
8/10/26 0:00	4634.3
8/11/26 0:00	5466.1
8/12/26 0:00	4819.0
8/13/26 0:00	5047.8
8/14/26 0:00	5089.1
8/15/26 0:00	5006.4
8/16/26 0:00	5222.3
8/17/26 0:00	4692.0
8/18/26 0:00	5162.6

8/19/26 0:00	5382.6
8/20/26 0:00	4733.6
8/21/26 0:00	4962.3
8/22/26 0:00	5183.5
8/23/26 0:00	5208.2
8/24/26 0:00	5759.6
8/25/26 0:00	6021.5
8/26/26 0:00	4991.6
8/27/26 0:00	5748.5
8/28/26 0:00	5662.2
8/29/26 0:00	5543.9
8/30/26 0:00	5658.0
8/31/26 0:00	6301.0
9/1/26 0:00	6122.1
9/2/26 0:00	6095.8
9/3/26 0:00	6157.2
9/4/26 0:00	5022.6
9/5/26 0:00	5792.4
9/6/26 0:00	5348.5
9/7/26 0:00	4934.5
9/8/26 0:00	5464.5
9/9/26 0:00	5662.6
9/10/26 0:00	5191.8
9/11/26 0:00	5561.5
9/12/26 0:00	5503.5
9/13/26 0:00	5439.4
9/14/26 0:00	6138.5
9/15/26 0:00	5273.5
9/16/26 0:00	5618.0
9/17/26 0:00	5482.8
9/18/26 0:00	4902.9
9/19/26 0:00	5644.2
9/20/26 0:00	4670.6
9/21/26 0:00	5270.5
9/22/26 0:00	4654.1
9/23/26 0:00	4664.1
9/24/26 0:00	5398.3
9/25/26 0:00	4921.0
9/26/26 0:00	4699.9
9/27/26 0:00	5274.2
9/28/26 0:00	5248.9

Resize to show al size to show all values

ROSEVILLE ENERGY PARK COOLING TOWER EMISSIONS

POLLUTANT	LBS PER DAY	QUARTER 1	QUARTER 2	QUARTER 3	QUARTER 4
PM-10	16.3	1471	1487	1504	1504

Whereas compliance with the PM-10 emission limit shall be demonstrated as;
Cooling tower recirculation rate * total dissolved solids of blowdown * design drift rate

	53814	Gallons per minute
	* 8.33	Pounds per gallon
	* 1440	Minutes per day
Circ pump flow rate	**64,550,969**	Pounds per day

	5233	Average daily conductivity umhos
	0.00000064	Conversion to TDS ppm
Total dissolved solids	**0.00334912**	

Design drift rate	**0.005%**
PM-10 pounds per day	**10.81**

	92	Days in quarter
PM-10 pounds this quarter	**994**	3Q26

fill only these

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
07/01/2026	16.14	53.37	5.69	11.53	19.16
07/02/2026	58.63	59.10	5.62	11.33	18.90
07/03/2026	37.30	63.80	6.53	13.10	21.84
07/04/2026	145.98	93.93	8.22	16.43	27.47
07/05/2026	34.99	56.98	6.03	11.97	19.97
07/06/2026	16.61	55.09	5.93	11.76	19.60
07/07/2026	16.74	57.44	6.15	12.32	20.52
07/08/2026	16.07	51.44	5.60	11.04	18.49
07/09/2026	16.14	53.00	5.74	11.41	19.04
07/10/2026	63.64	88.18	8.50	16.96	28.25
07/11/2026	96.21	105.63	10.45	20.89	34.79
07/12/2026	34.97	148.39	15.81	31.62	52.76
07/13/2026	25.91	148.45	16.09	32.23	53.69
07/14/2026	34.57	158.08	16.64	33.23	55.53
07/15/2026	40.12	181.30	18.51	36.97	61.78
07/16/2026	40.27	139.39	15.00	29.96	49.97
07/17/2026	48.61	137.62	14.92	29.76	49.62
07/18/2026	58.81	133.65	14.40	28.82	48.04
07/19/2026	42.57	146.52	15.77	31.57	52.59
07/20/2026	32.89	185.62	18.95	38.04	63.23
07/21/2026	36.03	183.40	18.80	37.52	62.63
07/22/2026	47.94	137.58	14.89	29.79	49.65
07/23/2026	52.85	134.01	14.46	28.88	48.15
07/24/2026	53.96	141.20	15.28	30.56	50.91
07/25/2026	49.84	138.77	14.98	29.95	49.92
07/26/2026	45.40	137.86	14.89	29.74	49.53
07/27/2026	48.36	139.16	15.04	30.09	50.19
07/28/2026	41.36	123.61	13.31	26.64	44.36
07/29/2026	18.58	117.81	12.67	25.27	42.16
07/30/2026	24.74	100.51	10.82	21.57	35.98
07/31/2026	26.20	118.12	12.72	25.38	42.33
Monthly Avg/Sum:	1,322.43 sum	3,589.01 sum	378.41 sum	756.33 sum	1,261.05 sum
Daily Min:	16.07	51.44	5.60	11.04	18.49
Daily Max:	145.98	185.62	18.95	38.04	63.23
Jul 2026 - Jul 2026	1,322.43 sum	3,589.01 sum	378.41 sum	756.33 sum	1,261.05 sum
QTD:	1,322.43 sum	3,589.01 sum	378.41 sum	756.33 sum	1,261.05 sum
YTD 2026:	4,847.69 sum	8,176.27 sum	820.98 sum	1,633.90 sum	2,732.02 sum

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
08/01/2026	24.60	115.05	12.44	24.90	41.46
08/02/2026	28.99	114.74	12.32	24.52	40.94
08/03/2026	29.83	131.88	13.81	27.72	45.98
08/04/2026	29.89	127.41	13.43	26.91	44.74
08/05/2026	34.17	127.37	13.25	26.59	44.16
08/06/2026	25.80	126.90	13.30	26.71	44.35
08/07/2026	25.46	123.68	13.47	26.90	44.85
08/08/2026	24.46	117.11	12.63	25.31	42.18
08/09/2026	22.02	117.28	12.71	25.42	42.38
08/10/2026	25.48	117.04	12.63	25.23	42.08
08/11/2026	24.49	121.87	13.11	26.28	43.78
08/12/2026	33.19	112.42	12.10	24.21	40.36
08/13/2026	33.85	108.34	11.66	23.36	38.88
08/14/2026	30.85	98.62	10.60	21.29	35.44
08/15/2026	31.04	101.70	10.93	21.92	36.46
08/16/2026	38.48	113.67	12.29	24.60	41.02
08/17/2026	33.05	115.71	12.46	24.85	41.47
08/18/2026	29.32	115.96	12.56	25.04	41.83
08/19/2026	33.09	135.31	13.90	27.85	46.25
08/20/2026	33.65	131.55	13.96	28.07	46.52
08/21/2026	32.25	117.01	12.63	25.24	42.08
08/22/2026	35.11	113.31	12.19	24.42	40.67
08/23/2026	31.58	120.52	12.94	25.91	43.14
08/24/2026	29.22	126.87	13.67	27.42	45.64
08/25/2026	36.04	129.72	13.69	27.56	45.67
08/26/2026	30.18	118.96	12.88	25.77	42.97
08/27/2026	39.00	137.46	14.33	28.70	47.73
08/28/2026	45.85	148.07	15.85	31.80	52.85
08/29/2026	59.28	136.67	14.74	29.51	49.13
08/30/2026	57.49	137.25	14.81	29.65	49.46
08/31/2026	56.02	120.29	12.99	25.96	43.31
Monthly Avg/Sum:	1,043.73 sum	3,779.74 sum	404.28 sum	809.62 sum	1,347.78 sum
Daily Min:	22.02	98.62	10.60	21.29	35.44
Daily Max:	59.28	148.07	15.85	31.80	52.85
Jul 2026 - Aug 2026	2,366.16 sum	7,368.75 sum	782.69 sum	1,565.95 sum	2,608.83 sum
QTD:	2,366.16 sum	7,368.75 sum	782.69 sum	1,565.95 sum	2,608.83 sum
YTD 2026:	5,891.42 sum	11,956.01 sum	1,225.26 sum	2,443.52 sum	4,079.80 sum

Monthly Summary By Day Report

Units CT1 and CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:03 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT1 & CT2 CO, Lb 1 Hour(s)	Units CT1 & CT2 NOx, Lb 1 Hour(s)	Units CT1 & CT2 SO2, Lb 1 Hour(s)	Units CT1 & CT2 PM10, Lb 1 Hour(s)	Units CT1 & CT2 VOC, Lb 1 Hour(s)
09/01/2026	33.62	98.51	10.61	21.20	35.32
09/02/2026	33.33	98.31	10.59	21.21	35.37
09/03/2026	35.46	107.00	11.50	23.01	38.30
09/04/2026	34.59	104.88	11.29	22.60	37.66
09/05/2026	34.56	102.01	10.94	21.86	36.43
09/06/2026	34.68	99.38	10.71	21.36	35.62
09/07/2026	36.73	102.50	11.11	22.14	36.95
09/08/2026	36.82	136.51	14.41	28.99	48.04
09/09/2026	37.23	178.25	17.99	35.86	60.04
09/10/2026	45.47	136.99	14.11	28.14	47.07
09/11/2026	34.73	98.49	10.51	21.17	35.22
09/12/2026	34.50	97.20	10.38	20.88	34.80
09/13/2026	36.50	99.06	10.68	21.26	35.45
09/14/2026	38.10	98.74	10.61	21.22	35.39
09/15/2026	37.01	106.09	11.52	22.94	38.21
09/16/2026	73.22	90.32	9.00	17.95	29.95
09/17/2026	28.28	99.04	10.67	21.28	35.49
09/18/2026	29.15	99.78	10.75	21.43	35.80
09/19/2026	28.95	98.21	10.60	21.13	35.18
09/20/2026	29.31	100.20	10.85	21.59	36.08
09/21/2026	28.82	100.42	10.83	21.59	36.02
09/22/2026	30.81	100.50	10.85	21.58	36.07
09/23/2026	30.76	100.34	10.86	21.62	36.11
09/24/2026	31.83	103.12	11.16	22.27	37.10
09/25/2026	26.19	97.78	10.53	21.00	35.00
09/26/2026	25.71	105.67	11.41	22.64	37.87
09/27/2026	30.07	117.18	12.67	25.32	42.22
09/28/2026	34.56	104.00	11.22	22.31	37.25
09/29/2026	26.77	97.75	10.55	21.12	35.20
09/30/2026	31.78	123.51	13.28	26.57	44.28
Monthly Avg/Sum:	1,029.54 sum	3,201.74 sum	342.19 sum	683.24 sum	1,139.49 sum
Daily Min:	25.71	90.32	9.00	17.95	29.95
Daily Max:	73.22	178.25	17.99	35.86	60.04
Jul 2026 - Sep 2026	3,395.70 sum	10,570.49 sum	1,124.88 sum	2,249.19 sum	3,748.32 sum
QTD:	3,395.70 sum	10,570.49 sum	1,124.88 sum	2,249.19 sum	3,748.32 sum
YTD 2026:	6,920.96 sum	15,157.75 sum	1,567.45 sum	3,126.76 sum	5,219.29 sum

Monthly Summary By Day Report

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)
07/01/2026	0.0	0.0	0.0	0.0
07/02/2026	43.0	6.9	0.0	0.0
07/03/2026	18.5	4.7	0.0	0.0
07/04/2026	119.2	21.4	0.0	0.0
07/05/2026	14.6	1.1	0.0	0.0
07/06/2026	0.0	0.0	0.0	0.0
07/07/2026	0.0	0.0	0.0	0.0
07/08/2026	0.0	0.0	0.0	0.0
07/09/2026	0.0	0.0	0.0	0.0
07/10/2026	39.9	11.1	0.0	0.0
07/11/2026	61.4	9.9	0.0	0.0
07/12/2026	0.0	0.0	0.0	0.0
07/13/2026	0.0	0.0	0.0	0.0
07/14/2026	0.0	0.0	0.0	0.0
07/15/2026	0.0	0.0	0.0	0.0
07/16/2026	0.0	0.0	0.0	0.0
07/17/2026	0.0	0.0	0.0	0.0
07/18/2026	0.0	0.0	0.0	0.0
07/19/2026	0.0	0.0	0.0	0.0
07/20/2026	0.0	0.0	0.0	0.0
07/21/2026	0.0	0.0	0.0	0.0
07/22/2026	0.0	0.0	0.0	0.0
07/23/2026	0.0	0.0	0.0	0.0
07/24/2026	0.0	0.0	0.0	0.0
07/25/2026	0.0	0.0	0.0	0.0
07/26/2026	0.0	0.0	0.0	0.0
07/27/2026	0.0	0.0	0.0	0.0
07/28/2026	0.0	0.0	0.0	0.0
07/29/2026	0.0	0.0	0.0	0.0
07/30/2026	0.0	0.0	0.0	0.0
07/31/2026	0.0	0.0	0.0	0.0
Monthly Avg/Sum:	296.6 sum	55.1 sum	0.0 sum	0.0 sum
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	119.2	21.4	0.0	0.0
Jul 2026 - Jul 2026	296.6 sum	55.1 sum	0.0 sum	0.0 sum
QTD:	296.6 sum	55.1 sum	0.0 sum	0.0 sum
YTD 2026:	1,418.6 sum	214.3 sum	1,145.0 sum	289.7 sum

Monthly Summary By Day Report

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)
08/01/2026	0.0	0.0	0.0	0.0
08/02/2026	0.0	0.0	0.0	0.0
08/03/2026	0.0	0.0	0.0	0.0
08/04/2026	0.0	0.0	0.0	0.0
08/05/2026	0.0	0.0	0.0	0.0
08/06/2026	0.0	0.0	0.0	0.0
08/07/2026	0.0	0.0	0.0	0.0
08/08/2026	0.0	0.0	0.0	0.0
08/09/2026	0.0	0.0	0.0	0.0
08/10/2026	0.0	0.0	0.0	0.0
08/11/2026	0.0	0.0	0.0	0.0
08/12/2026	0.0	0.0	0.0	0.0
08/13/2026	0.0	0.0	0.0	0.0
08/14/2026	0.0	0.0	0.0	0.0
08/15/2026	0.0	0.0	0.0	0.0
08/16/2026	0.0	0.0	0.0	0.0
08/17/2026	0.0	0.0	0.0	0.0
08/18/2026	0.0	0.0	0.0	0.0
08/19/2026	0.0	0.0	0.0	0.0
08/20/2026	0.0	0.0	0.0	0.0
08/21/2026	0.0	0.0	0.0	0.0
08/22/2026	0.0	0.0	0.0	0.0
08/23/2026	0.0	0.0	0.0	0.0
08/24/2026	0.0	0.0	0.0	0.0
08/25/2026	0.0	0.0	0.0	0.0
08/26/2026	0.0	0.0	0.0	0.0
08/27/2026	0.0	0.0	0.0	0.0
08/28/2026	0.0	0.0	0.0	0.0
08/29/2026	0.0	0.0	0.0	0.0
08/30/2026	0.0	0.0	0.0	0.0
08/31/2026	0.0	0.0	0.0	0.0
Monthly Avg/Sum:	0.0 sum	0.0 sum	0.0 sum	0.0 sum
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	0.0	0.0	0.0	0.0
Jul 2026 - Aug 2026	296.6 sum	55.1 sum	0.0 sum	0.0 sum
QTD:	296.6 sum	55.1 sum	0.0 sum	0.0 sum
YTD 2026:	1,418.6 sum	214.3 sum	1,145.0 sum	289.7 sum

Monthly Summary By Day Report

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)
09/01/2026	0.0	0.0	0.0	0.0
09/02/2026	0.0	0.0	0.0	0.0
09/03/2026	0.0	0.0	0.0	0.0
09/04/2026	0.0	0.0	0.0	0.0
09/05/2026	0.0	0.0	0.0	0.0
09/06/2026	0.0	0.0	0.0	0.0
09/07/2026	0.0	0.0	0.0	0.0
09/08/2026	0.0	0.0	0.0	0.0
09/09/2026	0.0	0.0	0.0	0.0
09/10/2026	0.0	0.0	0.0	0.0
09/11/2026	0.0	0.0	0.0	0.0
09/12/2026	0.0	0.0	0.0	0.0
09/13/2026	0.0	0.0	0.0	0.0
09/14/2026	0.0	0.0	0.0	0.0
09/15/2026	0.0	0.0	0.0	0.0
09/16/2026	0.0	0.0	43.7	9.3
09/17/2026	0.0	0.0	0.0	0.0
09/18/2026	0.0	0.0	0.0	0.0
09/19/2026	0.0	0.0	0.0	0.0
09/20/2026	0.0	0.0	0.0	0.0
09/21/2026	0.0	0.0	0.0	0.0
09/22/2026	0.0	0.0	0.0	0.0
09/23/2026	0.0	0.0	0.0	0.0
09/24/2026	0.0	0.0	0.0	0.0
09/25/2026	0.0	0.0	0.0	0.0
09/26/2026	0.0	0.0	0.0	0.0
09/27/2026	0.0	0.0	0.0	0.0
09/28/2026	0.0	0.0	0.0	0.0
09/29/2026	0.0	0.0	0.0	0.0
09/30/2026	0.0	0.0	0.0	0.0
Monthly Avg/Sum:	0.0 sum	0.0 sum	43.7 sum	9.3 sum
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	0.0	0.0	43.7	9.3
Jul 2026 - Sep 2026	296.6 sum	55.1 sum	43.7 sum	9.3 sum
QTD:	296.6 sum	55.1 sum	43.7 sum	9.3 sum
YTD 2026:	1,418.6 sum	214.3 sum	1,188.7 sum	299.0 sum

Tons 12 Month Rolling Summary

CT1 and CT2 Combined

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

* = Excess Emission

	Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2		Units CT1 & CT2	
	CO, Ton		NOx, Ton		PM10, Ton		SO2, Ton		VOC, Ton	
	1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)		1 Day(s)	
Date	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum	Sum	Rolling Sum
Jul 2026	0.6614	3.8910	1.7946	8.1068	0.3783	1.6940	0.1892	0.8514	0.6307	2.8348
Aug 2026	0.5214	3.7438	1.8899	8.1015	0.4051	1.6896	0.2022	0.8469	0.6738	2.8210
Sep 2026	0.5150	3.4875	1.6011	7.6356	0.3417	1.5692	0.1712	0.7868	0.5696	2.6190
Sum/Avg	3.4875		7.6356		1.5692		0.7868		2.6190	
Limit										

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/01/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
07/01/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
07/01/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
07/01/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
07/01/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
07/01/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
07/01/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
07/01/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
07/01/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
07/01/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
07/01/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
07/01/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
07/01/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
07/01/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
07/01/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
07/01/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
07/01/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
07/01/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
07/01/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
07/01/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
07/01/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
07/01/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
07/01/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
07/01/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/02/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
07/02/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
07/02/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
07/02/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
07/02/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
07/02/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
07/02/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
07/02/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
07/02/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
07/02/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
07/02/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
07/02/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
07/02/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
07/02/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
07/02/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
07/02/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
07/02/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
07/02/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
07/02/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
07/02/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
07/02/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
07/02/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
07/02/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
07/02/2026 23:00	0.0	0.0	0	0.25	0.12492	0.42
Average/Sum#:	0.0	0.0	0	0.25	0.12492	0.42
Minimum:	0.0	0.0	0	0.25	0.12492	0.42
Maximum:	0.0	0.0	0	0.25	0.12492	0.42
%SI	95.83	95.83	100.00	95.83	95.83	95.83

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/03/2026 00:00	0.7	1.5	1	0.45	0.22266	0.74
07/03/2026 01:00	0.7	1.5	1	0.43	0.21318	0.71
07/03/2026 02:00	0.8	1.5	1	0.42	0.21210	0.71
07/03/2026 03:00	0.8	1.5	1	0.42	0.21198	0.71
07/03/2026 04:00	0.7	1.5	1	0.35	0.17592	0.59
07/03/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
07/03/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
07/03/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
07/03/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
07/03/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
07/03/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
07/03/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
07/03/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
07/03/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
07/03/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
07/03/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
07/03/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
07/03/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
07/03/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
07/03/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
07/03/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
07/03/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
07/03/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
07/03/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.7	1.5	1	0.41	0.20717	0.69
Minimum:	0.7	1.5	1	0.35	0.17592	0.59
Maximum:	0.8	1.5	1	0.45	0.22266	0.74
%SI	79.17	79.17	79.17	79.17	79.17	79.17

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/04/2026 00:00	0.0	0.0	0	0.25	0.12324	0.41
07/04/2026 01:00	0.7	1.4	1	0.44	0.22134	0.74
07/04/2026 02:00	0.7	1.5	1	0.43	0.21372	0.71
07/04/2026 03:00	0.8	1.5	1	0.42	0.21174	0.71
07/04/2026 04:00	0.7	1.5	1	0.42	0.21204	0.71
07/04/2026 05:00	0.7	1.5	1	0.34	0.17238	0.57
07/04/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
07/04/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
07/04/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
07/04/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
07/04/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
07/04/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
07/04/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
07/04/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
07/04/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
07/04/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
07/04/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
07/04/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
07/04/2026 18:00	0.0	0.0	0	0.33	0.16446	0.55
07/04/2026 19:00	0.6	1.4	2	0.54	0.27222	0.91
07/04/2026 20:00	0.7	1.5	1	0.51	0.25458	0.85
07/04/2026 21:00	0.6	1.5	1	0.42	0.21162	0.71
07/04/2026 22:00	0.7	1.5	1	0.44	0.22074	0.74
07/04/2026 23:00	0.6	1.5	1	0.49	0.24594	0.82
Average/Sum#:	0.6	1.2	1	0.42	0.21034	0.70
Minimum:	0.0	0.0	1	0.25	0.12324	0.41
Maximum:	0.8	1.5	2	0.54	0.27222	0.91
%SI	50.00	50.00	58.33	50.00	50.00	50.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/05/2026 00:00	0.7	1.5	1	0.41	0.20382	0.68
07/05/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
07/05/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
07/05/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
07/05/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
07/05/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
07/05/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
07/05/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
07/05/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
07/05/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
07/05/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
07/05/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
07/05/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
07/05/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
07/05/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
07/05/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
07/05/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
07/05/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
07/05/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
07/05/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
07/05/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
07/05/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
07/05/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
07/05/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.7	1.5	1	0.41	0.20382	0.68
Minimum:	0.7	1.5	1	0.41	0.20382	0.68
Maximum:	0.7	1.5	1	0.41	0.20382	0.68
%SI	95.83	95.83	95.83	95.83	95.83	95.83

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/06/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
07/06/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
07/06/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
07/06/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
07/06/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
07/06/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
07/06/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
07/06/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
07/06/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
07/06/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
07/06/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
07/06/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
07/06/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
07/06/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
07/06/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
07/06/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
07/06/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
07/06/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
07/06/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
07/06/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
07/06/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
07/06/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
07/06/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
07/06/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/07/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
07/07/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
07/07/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
07/07/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
07/07/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
07/07/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
07/07/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
07/07/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
07/07/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
07/07/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
07/07/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
07/07/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
07/07/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
07/07/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
07/07/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
07/07/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
07/07/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
07/07/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
07/07/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
07/07/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
07/07/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
07/07/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
07/07/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
07/07/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/08/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
07/08/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
07/08/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
07/08/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
07/08/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
07/08/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
07/08/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
07/08/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
07/08/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
07/08/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
07/08/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
07/08/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
07/08/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
07/08/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
07/08/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
07/08/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
07/08/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
07/08/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
07/08/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
07/08/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
07/08/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
07/08/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
07/08/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
07/08/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/09/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
07/09/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
07/09/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
07/09/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
07/09/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
07/09/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
07/09/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
07/09/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
07/09/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
07/09/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
07/09/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
07/09/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
07/09/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
07/09/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
07/09/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
07/09/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
07/09/2026 16:00	0.0	0.0	0	0.00	0.00000	0.00
07/09/2026 17:00	0.0	0.0	0	0.00	0.00000	0.00
07/09/2026 18:00	0.0	0.0	0	0.00	0.00000	0.00
07/09/2026 19:00	0.0	0.0	0	0.00	0.00000	0.00
07/09/2026 20:00	0.0	0.0	0	0.00	0.00000	0.00
07/09/2026 21:00	0.0	0.0	0	0.00	0.00000	0.00
07/09/2026 22:00	0.0	0.0	0	0.00	0.00000	0.00
07/09/2026 23:00	0.0	0.0	0	0.00	0.00000	0.00
Average/Sum#:	0.0	0.0	0	0.00	0.00000	0.00
Minimum:	0.0	0.0	0	0.00	0.00000	0.00
Maximum:	0.0	0.0	0	0.00	0.00000	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/10/2026 00:00	0.0	0.0	0	0.00	0.00000	0.00
07/10/2026 01:00	0.0	0.0	0	0.00	0.00000	0.00
07/10/2026 02:00	0.0	0.0	0	0.00	0.00000	0.00
07/10/2026 03:00	0.0	0.0	0	0.00	0.00000	0.00
07/10/2026 04:00	0.0	0.0	0	0.00	0.00000	0.00
07/10/2026 05:00	0.0	0.0	0	0.00	0.00000	0.00
07/10/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
07/10/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
07/10/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
07/10/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
07/10/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
07/10/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
07/10/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
07/10/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
07/10/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
07/10/2026 15:00	0.0	0.0	0	0.00	0.00000	0.00
07/10/2026 16:00	0.0	0.0	0	0.37	0.18366	0.61
07/10/2026 17:00	0.8	1.4	1	0.58	0.29010	0.97
07/10/2026 18:00	0.6	1.5	2	0.64	0.31836	1.06
07/10/2026 19:00	0.5	1.5	2	0.62	0.31248	1.04
07/10/2026 20:00	0.9	1.5	2	0.60	0.29916	1.00
07/10/2026 21:00	1.1	1.5	2	0.59	0.29694	0.99
07/10/2026 22:00	1.2	1.5	2	0.59	0.29640	0.99
07/10/2026 23:00	1.2	1.5	2	0.59	0.29538	0.98
Average/Sum#:	0.8	1.3	2	0.57	0.28656	0.96
Minimum:	0.0	0.0	1	0.37	0.18366	0.61
Maximum:	1.2	1.5	2	0.64	0.31836	1.06
%SI	66.67	66.67	70.83	66.67	66.67	66.67

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/11/2026 00:00	1.3	1.5	2	0.59	0.29412	0.98
07/11/2026 01:00	1.3	1.5	2	0.59	0.29298	0.98
07/11/2026 02:00	1.7	1.5	1	0.58	0.29160	0.97
07/11/2026 03:00	1.9	1.5	2	0.58	0.29112	0.97
07/11/2026 04:00	1.5	1.5	1	0.54	0.26838	0.89
07/11/2026 05:00	0.9	1.5	0	0.38	0.18954	0.63
07/11/2026 06:00	0.0	0.0	0	0.00	0.00000	0.00
07/11/2026 07:00	0.0	0.0	0	0.00	0.00000	0.00
07/11/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
07/11/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
07/11/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
07/11/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
07/11/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
07/11/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
07/11/2026 14:00	0.0	0.0	0	0.00	0.00000	0.00
07/11/2026 15:00	0.0	0.0	0	0.07	0.03690	0.12
07/11/2026 16:00	0.7	1.5	0	0.38	0.18930	0.63
07/11/2026 17:00	0.7	1.6	2	0.60	0.29802	0.99
07/11/2026 18:00	0.9	1.5	1	0.61	0.30252	1.01
07/11/2026 19:00	1.0	1.5	2	0.60	0.29904	1.00
07/11/2026 20:00	0.8	1.5	2	0.61	0.30318	1.01
07/11/2026 21:00	0.7	1.5	2	0.63	0.31590	1.05
07/11/2026 22:00	1.0	1.5	2	0.60	0.30186	1.01
07/11/2026 23:00	0.6	1.5	3	0.68	0.33774	1.13
Average/Sum#:	1.0	1.4	2	0.54	0.26748	0.89
Minimum:	0.0	0.0	0	0.07	0.03690	0.12
Maximum:	1.9	1.6	3	0.68	0.33774	1.13
%SI	37.50	37.50	41.67	37.50	37.50	37.50