DOCKETED	
Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	273256
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q3 2026 - Part 3s
Description:	N/A
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public Agency
Submission Date:	10/28/2026 7:52:54 AM
Docketed Date:	10/28/2026

NH3 Slip Ppmvdc 1-Hour Block Excess Emissions

CT5

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:15 **Location:** Roseville, CA

Tag Name: CT5_NH3Slip_Ppmvdc_1H
Total Operating Time: 81.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: -57.00 Hour(s) Report Time: 24.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Tag Value	Limit	Reason Code	Action Code
1	07/14/26 16:00	07/14/26 16:59	1	11.0	10.0		
2	07/14/26 17:00	07/14/26 17:59	1	13.7	10.0		
3	07/14/26 18:00	07/14/26 18:59	1	14.7	10.0		
4	07/14/26 19:00	07/14/26 19:59	1	13.9	10.0		
5	09/09/26 13:00	09/09/26 13:59	1	10.2	10.0		

Total Operating Time:	**81.00 Hour(s)**
Total Duration (Online only):	**5.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**6.17 %**
Time in compliance as a percentage of operating time:	**93.83 %**

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
07/01/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
07/02/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
07/03/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
07/04/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
07/05/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
07/06/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
07/07/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
07/08/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
07/09/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
07/10/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
07/11/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
07/12/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/12/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
07/13/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/13/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
07/14/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2026 15:00	0.0	0.0	2.9	0.0	0.0	655.2	0.05	0.05
07/14/2026 16:00	0.0	0.0	2.9	0.0	-0.1	1,310.5	0.10	0.10
07/14/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2026 19:00	0.0	0.0	0.0	0.0	-0.1	655.2	0.03	0.03
07/14/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/14/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	1.9	0.0	-0.1	0.0	0.18 #	0.18 #
Minimum:	0.0	0.0	0.0	0.0	-0.1	0.0	0.00	0.00
Maximum:	0.0	0.0	2.9	0.0	0.0	0.0	0.10	0.10
%SI	100.00	100.00	87.50	100.00	87.50	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
07/15/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2026 07:00	0.0	0.0	0.0	0.0	-0.1	655.2	0.03	0.03
07/15/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2026 11:00	0.0	0.0	16.7	0.0	28.9	81,444.7	0.15	0.15
07/15/2026 12:00	8.1	2.1	21.8	15.6	86.9	659,132.4	0.02	1.00
07/15/2026 13:00	8.3	2.0	21.4	15.6	90.2	659,649.1	0.00	1.00
07/15/2026 14:00	8.5	2.0	22.2	15.7	91.6	650,476.6	0.00	1.00
07/15/2026 15:00	8.6	1.9	22.1	15.7	91.8	651,003.3	0.00	1.00
07/15/2026 16:00	8.9	1.9	22.7	15.7	94.7	650,739.9	0.00	1.00
07/15/2026 17:00	8.8	1.9	23.1	15.7	95.0	649,423.2	0.00	1.00
07/15/2026 18:00	8.6	1.9	23.4	15.7	93.6	647,316.4	0.00	1.00
07/15/2026 19:00	8.4	2.0	23.7	15.6	89.7	633,035.8	0.00	1.00
07/15/2026 20:00	8.1	2.0	23.9	15.6	87.6	628,126.5	0.03	1.00
07/15/2026 21:00	2.4	1.8	16.9	18.4	19.2	209,248.0	0.10	0.10
07/15/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/15/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	7.9	2.0	19.8	15.9	72.4	603,815.1	0.33 #	9.28 #
Minimum:	2.4	1.8	0.0	15.6	-0.1	209,248.0	0.00	0.00
Maximum:	8.9	2.1	23.9	18.4	95.0	659,649.1	0.15	1.00
%SI	58.33	58.33	50.00	58.33	50.00	58.33	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
07/16/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/16/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
07/17/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/17/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
07/18/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/18/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
07/19/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/19/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
07/20/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2026 15:00	5.7	3.5	21.3	16.0	62.5	598,913.6	0.18	0.90
07/20/2026 16:00	7.5	2.0	21.8	15.6	82.2	657,065.3	0.00	1.00
07/20/2026 17:00	7.8	2.0	22.7	15.6	87.3	657,323.7	0.00	1.00
07/20/2026 18:00	7.7	2.0	23.2	15.6	84.7	639,495.3	0.00	1.00
07/20/2026 19:00	8.0	2.0	24.5	15.6	87.9	634,069.3	0.00	1.00
07/20/2026 20:00	7.5	2.0	23.8	15.6	83.5	634,327.7	0.00	1.00
07/20/2026 21:00	6.5	1.9	22.3	16.1	71.3	594,843.7	0.13	0.60
07/20/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/20/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	7.2	2.2	22.8	15.7	79.9	630,862.7	0.31 #	6.50 #
Minimum:	5.7	1.9	21.3	15.6	62.5	594,843.7	0.00	0.00
Maximum:	8.0	3.5	24.5	16.1	87.9	657,323.7	0.18	1.00
%SI	70.83	70.83	70.83	70.83	70.83	70.83	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
07/21/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2026 13:00	3.6	8.4	17.2	17.5	31.0	517,964.6	0.15	0.15
07/21/2026 14:00	8.3	1.9	22.7	15.5	87.0	629,681.6	0.02	1.00
07/21/2026 15:00	8.4	2.0	22.5	15.7	90.0	648,896.5	0.00	1.00
07/21/2026 16:00	8.3	2.0	22.5	15.7	91.1	664,960.9	0.00	1.00
07/21/2026 17:00	8.2	1.9	22.6	15.6	91.7	668,434.1	0.00	1.00
07/21/2026 18:00	7.7	2.0	21.9	15.6	86.4	668,175.7	0.00	1.00
07/21/2026 19:00	7.1	2.0	21.4	15.6	80.9	665,333.5	0.00	1.00
07/21/2026 20:00	6.9	2.0	21.8	15.5	78.9	650,223.0	0.03	1.00
07/21/2026 21:00	1.6	1.8	17.2	18.4	19.1	213,630.2	0.10	0.10
07/21/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/21/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	6.7	2.7	21.1	16.1	72.9	591,922.2	0.30 #	7.25 #
Minimum:	1.6	1.8	17.2	15.5	19.1	213,630.2	0.00	0.00
Maximum:	8.4	8.4	22.7	18.4	91.7	668,434.1	0.15	1.00
%SI	62.50	62.50	62.50	62.50	62.50	62.50	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
07/22/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/22/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
07/23/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/23/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
07/24/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/24/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
07/25/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/25/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:25 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
07/26/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/26/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
07/27/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/27/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
07/28/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/28/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/28/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/28/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/28/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/28/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/28/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/28/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/28/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/28/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/28/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/28/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/28/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/28/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/28/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/28/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/28/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/28/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/28/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/28/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/28/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/28/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/28/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/28/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
07/29/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/29/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/29/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/29/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/29/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/29/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/29/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/29/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/29/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/29/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/29/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/29/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/29/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/29/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/29/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/29/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/29/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/29/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/29/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/29/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/29/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/29/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/29/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/29/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
07/30/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/30/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/30/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/30/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/30/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/30/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/30/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/30/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/30/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/30/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/30/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/30/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/30/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/30/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/30/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/30/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/30/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/30/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/30/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/30/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/30/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/30/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/30/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/30/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
07/31/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/31/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/31/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/31/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/31/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/31/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/31/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/31/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/31/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/31/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/31/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/31/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/31/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/31/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/31/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/31/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/31/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/31/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/31/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/31/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/31/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/31/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/31/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/31/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
08/01/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/01/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/01/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/01/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/01/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/01/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/01/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/01/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/01/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/01/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/01/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/01/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/01/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/01/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/01/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/01/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/01/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/01/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/01/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/01/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/01/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/01/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/01/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/01/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
08/02/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/02/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/02/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/02/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/02/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/02/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/02/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/02/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/02/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/02/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/02/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/02/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/02/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/02/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/02/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/02/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/02/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/02/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/02/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/02/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/02/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/02/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/02/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/02/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
08/03/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/03/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/03/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/03/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/03/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/03/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/03/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/03/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/03/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/03/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/03/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/03/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/03/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/03/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/03/2026 14:00	3.8	7.8	16.5	17.6	31.1	507,932.0	0.15	0.15
08/03/2026 15:00	8.5	1.9	24.0	15.6	85.8	595,570.4	0.00	1.00
08/03/2026 16:00	9.2	1.9	23.9	15.8	93.0	617,583.5	0.00	1.00
08/03/2026 17:00	9.4	1.8	24.7	15.8	96.4	616,241.0	0.00	1.00
08/03/2026 18:00	9.0	1.8	24.3	15.8	93.2	615,166.9	0.00	1.00
08/03/2026 19:00	8.5	1.8	23.7	15.7	86.8	602,283.4	0.00	1.00
08/03/2026 20:00	7.7	1.8	23.3	15.7	80.1	597,279.7	0.03	1.00
08/03/2026 21:00	0.7	1.7	17.7	18.5	20.1	235,084.5	0.08	0.08
08/03/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/03/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	7.1	2.6	22.3	16.3	73.3	548,392.7	0.26 #	6.23 #
Minimum:	0.7	1.7	16.5	15.6	20.1	235,084.5	0.00	0.00
Maximum:	9.4	7.8	24.7	18.5	96.4	617,583.5	0.15	1.00
%SI	66.67	66.67	66.67	66.67	66.67	66.67	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
08/04/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/04/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/04/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/04/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/04/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/04/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/04/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/04/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/04/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/04/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/04/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/04/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/04/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/04/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/04/2026 14:00	2.2	9.7	15.6	18.1	19.5	479,787.6	0.13	0.13
08/04/2026 15:00	7.4	1.8	23.1	15.6	76.4	594,536.9	0.03	1.00
08/04/2026 16:00	8.1	1.9	23.4	15.7	83.7	603,863.5	0.00	1.00
08/04/2026 17:00	7.7	1.8	23.4	15.7	82.2	603,600.1	0.00	1.00
08/04/2026 18:00	6.8	1.8	22.7	15.7	74.2	603,336.8	0.00	1.00
08/04/2026 19:00	6.6	1.8	23.2	15.7	72.0	594,382.9	0.03	1.00
08/04/2026 20:00	0.5	1.7	16.2	18.6	18.0	232,802.1	0.08	0.08
08/04/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/04/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/04/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	5.6	2.9	21.1	16.4	60.9	530,330.0	0.27 #	5.21 #
Minimum:	0.5	1.7	15.6	15.6	18.0	232,802.1	0.00	0.00
Maximum:	8.1	9.7	23.4	18.6	83.7	603,863.5	0.13	1.00
%SI	70.83	70.83	70.83	70.83	70.83	70.83	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
08/05/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/05/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/05/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/05/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/05/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/05/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/05/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/05/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/05/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/05/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/05/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/05/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/05/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/05/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/05/2026 14:00	5.8	3.0	21.0	15.9	60.6	581,731.5	0.17	0.92
08/05/2026 15:00	6.8	1.9	21.5	15.7	72.4	612,290.7	0.00	1.00
08/05/2026 16:00	6.9	1.9	21.9	15.7	75.1	612,290.7	0.00	1.00
08/05/2026 17:00	7.1	1.9	22.4	15.7	76.8	611,500.7	0.00	1.00
08/05/2026 18:00	7.4	1.9	23.2	15.7	80.0	609,920.6	0.00	1.00
08/05/2026 19:00	7.2	1.8	23.3	15.7	76.7	602,283.4	0.03	1.00
08/05/2026 20:00	1.0	1.8	16.2	18.5	19.5	230,519.8	0.08	0.08
08/05/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/05/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/05/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	6.0	2.0	21.4	16.1	65.9	551,505.3	0.28 #	6.00 #
Minimum:	1.0	1.8	16.2	15.7	19.5	230,519.8	0.00	0.00
Maximum:	7.4	3.0	23.3	18.5	80.0	612,290.7	0.17	1.00
%SI	70.83	70.83	70.83	70.83	70.83	70.83	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
08/06/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2026 15:00	5.5	5.1	22.9	16.5	52.2	506,375.8	0.20	0.48
08/06/2026 16:00	8.0	2.0	24.4	15.7	80.0	571,471.3	0.00	1.00
08/06/2026 17:00	8.7	1.9	23.8	15.7	88.5	605,443.6	0.00	1.00
08/06/2026 18:00	8.5	1.9	24.5	15.7	88.3	605,180.2	0.00	1.00
08/06/2026 19:00	7.9	1.8	23.9	15.7	82.0	596,489.7	0.03	1.00
08/06/2026 20:00	0.9	1.6	16.4	18.5	19.7	229,949.2	0.08	0.08
08/06/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/06/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	6.6	2.4	22.7	16.3	68.5	519,151.6	0.31 #	4.56 #
Minimum:	0.9	1.6	16.4	15.7	19.7	229,949.2	0.00	0.00
Maximum:	8.7	5.1	24.5	18.5	88.5	605,443.6	0.20	1.00
%SI	75.00	75.00	75.00	75.00	75.00	75.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
08/07/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/07/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
08/08/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/08/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
08/09/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/09/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
08/10/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/10/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
08/11/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/11/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
08/12/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/12/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
08/13/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/13/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
08/14/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/14/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/14/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/14/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/14/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/14/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/14/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/14/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/14/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/14/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/14/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/14/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/14/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/14/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/14/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/14/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/14/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/14/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/14/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/14/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/14/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/14/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/14/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/14/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
08/15/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/15/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/15/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/15/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/15/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/15/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/15/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/15/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/15/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/15/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/15/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/15/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/15/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/15/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/15/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/15/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/15/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/15/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/15/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/15/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/15/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/15/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/15/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/15/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
08/16/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/16/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/16/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/16/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/16/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/16/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/16/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/16/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/16/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/16/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/16/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/16/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/16/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/16/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/16/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/16/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/16/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/16/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/16/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/16/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/16/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/16/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/16/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/16/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
08/17/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/17/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
08/18/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/18/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
08/19/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/19/2026 15:00	5.8	4.5	21.7	16.3	54.6	529,014.6	0.20	0.48
08/19/2026 16:00	8.2	2.0	23.4	15.7	85.6	610,710.6	0.00	1.00
08/19/2026 17:00	8.8	1.9	23.5	15.7	89.8	610,183.9	0.00	1.00
08/19/2026 18:00	7.8	1.8	22.4	15.7	80.7	610,183.9	0.00	1.00
08/19/2026 19:00	7.0	1.9	21.6	15.6	73.1	598,929.4	0.00	1.00
08/19/2026 20:00	6.6	1.9	21.0	15.5	68.6	585,809.3	0.00	1.00
08/19/2026 21:00	6.7	1.9	21.2	15.5	67.4	575,919.0	0.03	1.00
08/19/2026 22:00	1.3	1.7	15.3	18.6	18.7	232,206.7	0.08	0.08
08/19/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	6.5	2.2	21.3	16.1	67.3	544,119.7	0.31 #	6.56 #
Minimum:	1.3	1.7	15.3	15.5	18.7	232,206.7	0.00	0.00
Maximum:	8.8	4.5	23.5	18.6	89.8	610,710.6	0.20	1.00
%SI	66.67	66.67	66.67	66.67	66.67	66.67	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
08/20/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/20/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
08/21/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/21/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
08/22/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/22/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
08/23/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/23/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
08/24/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/24/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
08/25/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/25/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
08/26/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/26/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
08/27/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/27/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/27/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/27/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/27/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/27/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/27/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/27/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/27/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/27/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/27/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/27/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/27/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/27/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/27/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/27/2026 15:00	6.3	2.7	21.1	16.1	62.3	566,599.3	0.18	0.67
08/27/2026 16:00	7.9	1.9	22.1	15.6	79.2	599,187.8	0.00	1.00
08/27/2026 17:00	7.6	1.9	22.0	15.6	77.6	598,671.0	0.00	1.00
08/27/2026 18:00	7.1	1.9	21.4	15.6	73.5	598,154.2	0.00	1.00
08/27/2026 19:00	7.1	1.9	21.9	15.6	73.5	593,245.0	0.03	1.00
08/27/2026 20:00	1.2	1.9	16.5	18.5	20.1	239,078.7	0.08	0.08
08/27/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/27/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/27/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	6.2	2.0	20.8	16.2	64.4	532,489.3	0.29 #	4.75 #
Minimum:	1.2	1.9	16.5	15.6	20.1	239,078.7	0.00	0.00
Maximum:	7.9	2.7	22.1	18.5	79.2	599,187.8	0.18	1.00
%SI	75.00	75.00	75.00	75.00	75.00	75.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
08/28/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/28/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/28/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/28/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/28/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/28/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/28/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/28/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/28/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/28/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/28/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/28/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/28/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/28/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/28/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/28/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/28/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/28/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/28/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/28/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/28/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/28/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/28/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/28/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
08/29/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/29/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/29/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/29/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/29/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/29/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/29/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/29/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/29/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/29/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/29/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/29/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/29/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/29/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/29/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/29/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/29/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/29/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/29/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/29/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/29/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/29/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/29/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/29/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
08/30/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/30/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
08/31/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
08/31/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
09/01/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/01/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
09/02/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/02/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
09/03/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/03/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
09/04/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/04/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/04/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/04/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/04/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/04/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/04/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/04/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/04/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/04/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/04/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/04/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/04/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/04/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/04/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/04/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/04/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/04/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/04/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/04/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/04/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/04/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/04/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/04/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
09/05/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/05/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/05/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/05/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/05/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/05/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/05/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/05/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/05/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/05/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/05/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/05/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/05/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/05/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/05/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/05/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/05/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/05/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/05/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/05/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/05/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/05/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/05/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/05/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
09/06/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/06/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
09/07/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/07/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
09/08/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/08/2026 16:00	1.1	7.9	13.9	18.6	14.1	470,367.5	0.12	0.12
09/08/2026 17:00	8.8	2.0	24.0	15.5	83.8	581,751.8	0.05	1.00
09/08/2026 18:00	8.8	1.9	23.5	15.6	84.5	580,325.9	0.00	1.00
09/08/2026 19:00	8.1	1.8	23.2	15.6	79.6	579,034.0	0.00	1.00
09/08/2026 20:00	7.9	1.9	22.8	15.5	76.0	567,803.9	0.00	1.00
09/08/2026 21:00	7.6	1.9	22.4	15.5	72.9	563,746.4	0.03	1.00
09/08/2026 22:00	3.7	1.9	15.6	18.5	17.8	202,560.7	0.10	0.10
09/08/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	6.6	2.8	20.8	16.4	61.2	506,512.9	0.30 #	5.22 #
Minimum:	1.1	1.8	13.9	15.5	14.1	202,560.7	0.00	0.00
Maximum:	8.8	7.9	24.0	18.6	84.5	581,751.8	0.12	1.00
%SI	70.83	70.83	70.83	70.83	70.83	70.83	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
09/09/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2026 11:00	0.1	8.0	13.1	19.0	2.4	287,579.1	0.15	0.15
09/09/2026 12:00	9.3	2.6	23.1	15.6	71.9	571,282.5	0.07	1.00
09/09/2026 13:00	9.5	1.9	22.9	15.7	74.7	569,627.9	0.00	1.00
09/09/2026 14:00	9.1	1.9	23.7	15.8	71.3	545,621.6	0.00	1.00
09/09/2026 15:00	9.0	1.9	25.2	15.9	71.0	530,241.1	0.00	1.00
09/09/2026 16:00	9.3	1.9	25.3	15.9	72.1	527,502.3	0.00	1.00
09/09/2026 17:00	9.7	1.8	25.7	15.9	72.0	504,769.8	0.00	1.00
09/09/2026 18:00	9.6	1.8	25.2	15.9	70.1	503,674.3	0.00	1.00
09/09/2026 19:00	9.4	1.8	24.8	15.9	68.4	502,578.7	0.00	1.00
09/09/2026 20:00	9.0	1.9	23.8	15.8	63.3	488,696.5	0.03	1.00
09/09/2026 21:00	1.2	2.0	16.5	18.5	18.2	220,819.7	0.08	0.08
09/09/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/09/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	7.7	2.5	22.7	16.4	59.6	477,490.3	0.33 #	9.23 #
Minimum:	0.1	1.8	13.1	15.6	2.4	220,819.7	0.00	0.00
Maximum:	9.7	8.0	25.7	19.0	74.7	571,282.5	0.15	1.00
%SI	54.17	54.17	54.17	54.17	54.17	54.17	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
09/10/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/10/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/10/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/10/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/10/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/10/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/10/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/10/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/10/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/10/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/10/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/10/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/10/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/10/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/10/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/10/2026 15:00	3.6	7.4	17.0	17.8	22.8	439,982.8	0.15	0.15
09/10/2026 16:00	9.3	1.8	25.9	16.0	65.6	472,311.7	0.02	1.00
09/10/2026 17:00	10.0	1.8	25.9	16.1	70.5	480,725.0	0.00	1.00
09/10/2026 18:00	9.9	1.9	26.5	16.1	69.6	479,298.5	0.00	1.00
09/10/2026 19:00	9.8	1.9	26.6	16.0	68.8	467,001.7	0.02	1.00
09/10/2026 20:00	3.9	2.1	17.8	18.4	18.1	194,458.3	0.10	0.10
09/10/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/10/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/10/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	7.8	2.8	23.3	16.7	52.6	422,296.3	0.29 #	4.25 #
Minimum:	3.6	1.8	17.0	16.0	18.1	194,458.3	0.00	0.00
Maximum:	10.0	7.4	26.6	18.4	70.5	480,725.0	0.15	1.00
%SI	75.00	75.00	75.00	75.00	75.00	75.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
09/11/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/11/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
09/12/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/12/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
09/13/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/13/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
09/14/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/14/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
09/15/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/15/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
09/16/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
09/17/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/17/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
09/18/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/18/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
09/19/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/19/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
09/20/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/20/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
09/21/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/21/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
09/22/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/22/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
09/23/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/23/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
09/24/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/24/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
09/25/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/25/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
09/26/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/26/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
09/27/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/27/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
09/28/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/28/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
09/29/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/29/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Daily Summary

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:26 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT6 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT6 NOx, Ppm 1 Hour(s)	Unit CT6 NOx, _SCR, Ppm 1 Hour(s)	Unit CT6 O2, Dry, Pct 1 Hour(s)	Unit CT6 NH3Inj, LbPerHr 1 Hour(s)	Unit CT6 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT6 SUSD, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
09/30/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/30/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	100.00	100.00	100.00	100.00	0.00	0.00

NH3 Slip Ppmvdc 1-Hour Block Excess Emissions

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:32 **Location:** Roseville, CA

Tag Name: CT6_NH3Slip_Ppmvdc_1H
Total Operating Time: 97.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,063.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**97.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

AQ-139

AQ-139: The Project Owner shall ensure compliance with the continuous emission monitoring requirements of 40 CFR Part 60 and 40 CFR Part 75.

Verification: The Project owner shall include all necessary operational data to demonstrate compliance with the limits provided in this Condition as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6.

Cylinder Gas Audit

Facility: ROSEVILLE ENERGY
Unit/Stack: CT1
Parameter/Scale: CO / High

Test Date: 07/27/2026
Test Result: **Pass**

Instrument Name: CT1_CODualRg_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
07/27/2026	12:41	L	200	50.2	50.0	25.1 %
07/27/2026	12:46	M	200	109.0	111.6	54.5 %
07/27/2026	12:58	L	200	50.2	50.0	25.1 %
07/27/2026	13:03	M	200	109.0	111.4	54.5 %
07/27/2026	13:15	L	200	50.2	50.1	25.1 %
07/27/2026	13:20	M	200	109.0	111.3	54.5 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	50.200	50.033	Std	**0.3**
M	109.000	111.433	Std	**2.2**

Cylinder Gas Audit

Facility: ROSEVILLE ENERGY
Unit/Stack: CT1
Parameter/Scale: CO / Low

Test Date: 07/28/2026
Test Result: **Pass**

Instrument Name: CT1_CODualRg_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
07/28/2026	08:35	L	10	2.6	2.1	26.0 %
07/28/2026	08:40	M	10	5.7	5.5	57.0 %
07/28/2026	08:47	L	10	2.6	2.1	26.0 %
07/28/2026	08:52	M	10	5.7	5.5	57.0 %
07/28/2026	08:59	L	10	2.6	2.1	26.0 %
07/28/2026	09:04	M	10	5.7	5.5	57.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	2.600	2.100	Alt	**0.5**
M	5.700	5.500	Std	**3.5**

Cylinder Gas Audit

Facility: ROSEVILLE ENERGY
Unit/Stack: CT2
Parameter/Scale: CO / High
Test Date: 07/27/2026
Test Result: **Pass**
Instrument Name: CT2_CODualRg_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
07/27/2026	09:27	L	200	49.9	49.9	25.0 %
07/27/2026	09:32	M	200	109.6	111.9	54.8 %
07/27/2026	09:44	L	200	49.9	50.0	25.0 %
07/27/2026	09:49	M	200	109.6	111.8	54.8 %
07/27/2026	10:01	L	200	49.9	49.9	25.0 %
07/27/2026	10:06	M	200	109.6	111.6	54.8 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	49.900	49.933	Std	**0.1**
M	109.600	111.767	Std	**2.0**

Cylinder Gas Audit

Facility: ROSEVILLE ENERGY
Unit/Stack: CT2
Parameter/Scale: CO / Low

Test Date: 07/27/2026
Test Result: **Pass**

Instrument Name: CT2_CODualRg_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
07/27/2026	11:39	L	10	2.5	2.3	25.0 %
07/27/2026	11:44	M	10	5.7	5.6	57.0 %
07/27/2026	11:51	L	10	2.5	2.3	25.0 %
07/27/2026	11:56	M	10	5.7	5.6	57.0 %
07/27/2026	12:03	L	10	2.5	2.2	25.0 %
07/27/2026	12:08	M	10	5.7	5.6	57.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	2.500	2.267	Std	**9.3**
M	5.700	5.600	Std	**1.8**

Cylinder Gas Audit

Facility: ROSEVILLE ENERGY
Unit/Stack: CT5
Parameter/Scale: CO / Low

Test Date: 07/22/2026
Test Result: **Pass**

Instrument Name: CT5_CODualRg_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
07/22/2026	06:05	L	20	5.1	5.0	25.5 %
07/22/2026	06:10	M	20	11.1	11.0	55.5 %
07/22/2026	06:22	L	20	5.1	5.0	25.5 %
07/22/2026	06:27	M	20	11.1	11.1	55.5 %
07/22/2026	06:39	L	20	5.1	5.0	25.5 %
07/22/2026	06:44	M	20	11.1	11.0	55.5 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	5.100	5.000	Std	**2.0**
M	11.100	11.033	Std	**0.6**

Cylinder Gas Audit

Facility: ROSEVILLE ENERGY
Unit/Stack: CT5
Parameter/Scale: CO / High
Test Date: 07/22/2026
Test Result: **Pass**
Instrument Name: CT5_CODualRg_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
07/22/2026	07:07	L	1000	245.4	257.0	24.5 %
07/22/2026	07:12	M	1000	559.5	554.6	56.0 %
07/22/2026	07:19	L	1000	245.4	257.8	24.5 %
07/22/2026	07:24	M	1000	559.5	554.0	56.0 %
07/22/2026	07:31	L	1000	245.4	258.7	24.5 %
07/22/2026	07:36	M	1000	559.5	555.2	56.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	245.400	257.833	Std	**5.1**
M	559.500	554.600	Std	**0.9**

Cylinder Gas Audit

Facility: ROSEVILLE ENERGY
Unit/Stack: CT6
Parameter/Scale: CO / Low
Test Date: 07/22/2026
Test Result: **Pass**
Instrument Name: CT6_CODualRg_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
07/22/2026	06:46	L	20	5.0	5.1	25.0 %
07/22/2026	06:51	M	20	11.2	11.0	56.0 %
07/22/2026	07:03	L	20	5.0	5.1	25.0 %
07/22/2026	07:08	M	20	11.2	11.0	56.0 %
07/22/2026	07:20	L	20	5.0	5.1	25.0 %
07/22/2026	07:25	M	20	11.2	11.0	56.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	5.000	5.100	Std	**2.0**
M	11.200	11.000	Std	**1.8**

Cylinder Gas Audit

Facility: ROSEVILLE ENERGY
Unit/Stack: CT6
Parameter/Scale: CO / High
Test Date: 07/22/2026
Test Result: **Pass**
Instrument Name: CT6_CODualRg_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
07/22/2026	07:44	L	1000	253.0	255.8	25.3 %
07/22/2026	07:49	M	1000	571.0	571.8	57.1 %
07/22/2026	07:56	L	1000	253.0	255.6	25.3 %
07/22/2026	08:01	M	1000	571.0	570.5	57.1 %
07/22/2026	08:08	L	1000	253.0	256.6	25.3 %
07/22/2026	08:13	M	1000	571.0	570.3	57.1 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	253.000	256.000	Std	**1.2**
M	571.000	570.867	Std	**0.0**

CO Ppmvdc EDS/CMS Summary Report

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59
Generated: 10/01/2026 08:12

Facility Name: ROSEVILLE ENERGY
Location: Roseville, CA
Description: Electric Utility

CMS Data from: CT1_CO_Ppmvdc_1H, CT1_UnitOn_TF_1H
EDS Data from: CT1_CO_Ppmvdc_3H, CT1_UnitOn_TF_1H
Emission Limitation: 4
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 04/09/2006 14:00
Process Unit(s) Description:
Operating time for EDS: 1,986.00 Hour(s)
Operating time for CMS: 1,986.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

CO Lb/Hr EDS/CMS Summary Report

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59
Generated: 10/01/2026 08:12

Facility Name: ROSEVILLE ENERGY
Location: Roseville, CA
Description: Electric Utility

CMS Data from: CT1_CO_3Hr_LbPerHr_1H, CT1_UnitOn_TF_1H
EDS Data from: CT1_CO_3Hr_LbPerHr_1H, CT1_UnitOn_TF_1H
Emission Limitation: 6.2
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 04/09/2006 14:00
Process Unit(s) Description:
Operating time for EDS: 1,986.00 Hour(s)
Operating time for CMS: 1,986.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	15
2. Total CMS Downtime	15
3. Total Downtime as a percentage of operating time	0.76
4. Total Availability as a percentage of operating time	99.24

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

CO SUSD Lb/Hr EDS/CMS Summary Report

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59
Generated: 10/01/2026 08:15

Facility Name: ROSEVILLE ENERGY
Location: Roseville, CA
Description: Electric Utility

CMS Data from: CT1_CO_SUSD_LbPerHr_1H, CT1_UnitOn_TF_1H
EDS Data from: CT1_CO_SUSD_LbPerHr_1H, CT1_UnitOn_TF_1H
Emission Limitation: 89.5
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 04/09/2006 14:00
Process Unit(s) Description:
Operating time for EDS: 1,986.00 Hour(s)
Operating time for CMS: 1,986.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	97
2. Total CMS Downtime	97
3. Total Downtime as a percentage of operating time	4.88
4. Total Availability as a percentage of operating time	95.12

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

NOx Ppmvdc EDS/CMS Summary Report

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59
Generated: 10/01/2026 08:12

Facility Name: ROSEVILLE ENERGY
Location: Roseville, CA
Description: Electric Utility

CMS Data from: CT1_NOx_Ppmvdc_1H, CT1_UnitOn_TF_1H
EDS Data from: CT1_NOx_Ppmvdc_1H, CT1_UnitOn_TF_1H
Emission Limitation: 2.0
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 04/09/2006 14:00
Process Unit(s) Description:
Operating time for EDS: 1,986.00 Hour(s)
Operating time for CMS: 1,986.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

NOx Lb/Hr EDS/CMS Summary Report

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59
Generated: 10/01/2026 08:12

Facility Name: ROSEVILLE ENERGY
Location: Roseville, CA
Description: Electric Utility

CMS Data from: CT1_NOx_Norm_LbPerHr_1H, CT1_UnitOn_TF_1H
EDS Data from: CT1_NOx_Norm_LbPerHr_1H, CT1_UnitOn_TF_1H
Emission Limitation: 5.1
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 04/09/2006 14:00
Process Unit(s) Description:
Operating time for EDS: 1,986.00 Hour(s)
Operating time for CMS: 1,986.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	5
2. Total CMS Downtime	5
3. Total Downtime as a percentage of operating time	0.25
4. Total Availability as a percentage of operating time	99.75

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

NOx SUSD Lb/Hr EDS/CMS Summary Report

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59
Generated: 10/01/2026 08:12

Facility Name: ROSEVILLE ENERGY
Location: Roseville, CA
Description: Electric Utility

CMS Data from: CT1_NOx_SUSD_LbPerHr_1H, CT1_UnitOn_TF_1H
EDS Data from: CT1_NOx_SUSD_LbPerHr_1H, CT1_UnitOn_TF_1H
Emission Limitation: 37.1
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 04/09/2006 14:00
Process Unit(s) Description:
Operating time for EDS: 1,986.00 Hour(s)
Operating time for CMS: 1,986.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	97
2. Total CMS Downtime	97
3. Total Downtime as a percentage of operating time	4.88
4. Total Availability as a percentage of operating time	95.12

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

CO Ppmvdc EDS/CMS Summary Report

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59
Generated: 10/01/2026 08:14

Facility Name: ROSEVILLE ENERGY
Location: Roseville, CA
Description: Electric Utility

CMS Data from: CT2_CO_Ppmvdc_1H, CT2_UnitOn_TF_1H
EDS Data from: CT2_CO_Ppmvdc_3H, CT2_UnitOn_TF_1H
Emission Limitation: 4
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 04/10/2006 07:00
Process Unit(s) Description:
Operating time for EDS: 2,202.00 Hour(s)
Operating time for CMS: 2,202.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	1
2. Total CMS Downtime	1
3. Total Downtime as a percentage of operating time	0.05
4. Total Availability as a percentage of operating time	99.95

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

CO Lb/Hr EDS/CMS Summary Report

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59
Generated: 10/01/2026 08:14

Facility Name: ROSEVILLE ENERGY
Location: Roseville, CA
Description: Electric Utility

CMS Data from: CT2_CO_3Hr_LbPerHr_1H, CT2_UnitOn_TF_1H
EDS Data from: CT2_CO_3Hr_LbPerHr_1H, CT2_UnitOn_TF_1H
Emission Limitation: 6.2
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 04/10/2006 07:00
Process Unit(s) Description:
Operating time for EDS: 2,202.00 Hour(s)
Operating time for CMS: 2,202.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	4
2. Total CMS Downtime	4
3. Total Downtime as a percentage of operating time	0.18
4. Total Availability as a percentage of operating time	99.82

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

CO SUSD Lb/Hr EDS/CMS Summary Report

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59
Generated: 10/01/2026 08:14

Facility Name: ROSEVILLE ENERGY
Location: Roseville, CA
Description: Electric Utility

CMS Data from: CT2_CO_SUSD_LbPerHr_1H, CT2_UnitOn_TF_1H
EDS Data from: CT2_CO_SUSD_LbPerHr_1H, CT2_UnitOn_TF_1H
Emission Limitation: 89.5
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 04/10/2006 07:00
Process Unit(s) Description:
Operating time for EDS: 2,202.00 Hour(s)
Operating time for CMS: 2,202.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	106
2. Total CMS Downtime	106
3. Total Downtime as a percentage of operating time	4.81
4. Total Availability as a percentage of operating time	95.19

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.