DOCKETED	
Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	273254
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q3 2026 - Part 22s
Description:	N/A
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public Agency
Submission Date:	10/28/2026 7:52:54 AM
Docketed Date:	10/28/2026

Startup/Shutdown Event Report

CT6 - CO Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:30 **Location:** Roseville, CA

Tag Name: CT6_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 75.25 Hours

Non-Operating Time: 2,084.75 Hours Report Time: 2,160.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
07/14/2026 15:51 07/14/2026 15:53 Startup	3	0.00 SI	19.40		
07/14/2026 16:02 07/14/2026 16:04 Startup	3	0.00 SI	19.40		
07/14/2026 16:16 07/14/2026 16:18 Startup	3	0.00 SI	19.40		
07/14/2026 19:42 07/14/2026 19:42 Startup	1	0.00 SI	19.40		
07/14/2026 19:44 07/14/2026 19:44 Startup	1	0.00 SI	19.40		
07/15/2026 07:20 07/15/2026 07:20 Startup	1	0.00 SI	19.40		
07/15/2026 07:27 07/15/2026 07:27 Startup	1	0.00 SI	19.40		
07/15/2026 11:51 07/15/2026 12:00 Startup	10	0.00 SI	19.40		
07/15/2026 20:58 07/15/2026 21:05 Shutdown	8	0.09	21.60		
07/20/2026 15:06 07/20/2026 15:16 Startup	11	0.49	19.40		
07/20/2026 21:28 07/20/2026 21:35 Shutdown	8	0.12	21.60		
07/21/2026 13:51 07/21/2026 14:00 Startup	10	0.44	19.40		
07/21/2026 20:58 07/21/2026 21:05 Shutdown	8	0.10	21.60		

Startup/Shutdown Event Report

CT6 - CO Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:30 **Location:** Roseville, CA

Tag Name: CT6_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 75.25 Hours

Non-Operating Time: 2,084.75 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
08/03/2026 14:51 08/03/2026 14:59 Startup	9	0.51	19.40		
08/03/2026 20:58 08/03/2026 21:04 Shutdown	7	0.09	21.60		
08/04/2026 14:52 08/04/2026 15:01 Startup	10	0.48	19.40		
08/04/2026 19:58 08/04/2026 20:04 Shutdown	7	0.10	21.60		
08/05/2026 14:05 08/05/2026 14:14 Startup	10	0.47	19.40		
08/05/2026 19:58 08/05/2026 20:04 Shutdown	7	0.11	21.60		
08/06/2026 15:31 08/06/2026 15:42 Startup	12	0.52	19.40		
08/06/2026 19:58 08/06/2026 20:04 Shutdown	7	0.10	21.60		
08/19/2026 15:31 08/19/2026 15:42 Startup	12	0.62	19.40		
08/19/2026 21:58 08/19/2026 22:04 Shutdown	7	0.10	21.60		
08/27/2026 15:20 08/27/2026 15:30 Startup	11	0.44	19.40		
08/27/2026 19:58 08/27/2026 20:04 Shutdown	7	0.09	21.60		
09/08/2026 16:53 09/08/2026 17:02 Startup	10	0.50	19.40		
09/08/2026 21:58 09/08/2026 22:05 Shutdown	8	0.12	21.60		

Startup/Shutdown Event Report

CT6 - CO Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:30 **Location:** Roseville, CA

Tag Name: CT6_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 75.25 Hours

Non-Operating Time: 2,084.75 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
09/09/2026 11:51 09/09/2026 12:03 Startup	13	0.46	19.40		
09/09/2026 20:58 09/09/2026 21:04 Shutdown	7	0.10	21.60		
09/10/2026 15:51 09/10/2026 16:00 Startup	10	0.36	19.40		
09/10/2026 19:59 09/10/2026 20:05 Shutdown	7	0.06	21.60		

No excess emissions were found in the reporting period.

Startup/Shutdown Event Report

CT6 - CO Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:30 **Location:** Roseville, CA

Tag Name: CT6_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 75.25 Hours

Non-Operating Time: 2,084.75 Hours Report Time: 2,160.00 Hours

Event Invalid Information

Invalid Event Period		Reason	Action
Begin/End	Duration in Minute(s)	Code - Description	Code - Description
07/14/2026 15:51 07/14/2026 15:53	3		
07/14/2026 16:02 07/14/2026 16:04	3		
07/14/2026 16:16 07/14/2026 16:18	3		
07/14/2026 19:42 07/14/2026 19:42	1		
07/14/2026 19:44 07/14/2026 19:44	1		
07/15/2026 07:20 07/15/2026 07:20	1		
07/15/2026 07:27 07/15/2026 07:27	1		
07/15/2026 11:51 07/15/2026 12:00	10		

Total CMS Downtime	23	Minute(s)
Total Downtime as a percentage of operating time	0.51	%
Total Availability as a percentage of operating time	99.49	%

Startup/Shutdown Event Report

CT6 - CO Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:30 **Location:** Roseville, CA

Tag Name: CT6_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 75.25 Hours

Non-Operating Time: 2,084.75 Hours Report Time: 2,160.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	23
2. Total CMS Downtime in Minute(s)	23
3. Total Downtime as a percentage of operating time	0.51
4. Total Availability as a percentage of operating time	99.49

Heat Input MBtuPerHr 1-Hour Block Excess Emissions

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:30 **Location:** Roseville, CA

Tag Name: CT6_HI_MBtuPerHr_1H
Total Operating Time: 97.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 465.00 Hour(s) Report Time: 562.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**97.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

NH3 Slip Ppmvdc 1-Hour Block Excess Emissions

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 09:08 **Location:** Roseville, CA

Tag Name: CT6_NH3Slip_Ppmvdc_1H
Total Operating Time: 97.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,111.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**97.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

NOx Ppmvdc EDS/CMS Summary Report

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59
Generated: 10/01/2026 09:50

Facility Name: ROSEVILLE ENERGY
Location: Roseville, CA
Description: Electric Utility

CMS Data from: CT6_NOx_Norm_Ppmvdc_1H, CT6_UnitOn_TF_1H
EDS Data from: CT6_NOx_Norm_Ppmvdc_1H, CT6_UnitOn_TF_1H
Emission Limitation: 2.5
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, T200H
Date of Latest CMS Certification or Audit: 04/01/2024 00:00
Process Unit(s) Description:
Operating time for EDS: 97.00 Hour(s)
Operating time for CMS: 97.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	1
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	1
4. Time of Excess Emission as a percentage of operating time	1.03
5. Time in compliance as percentage of operating time	98.97

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	22
2. Total CMS Downtime	22
3. Total Downtime as a percentage of operating time	22.68
4. Total Availability as a percentage of operating time	77.32

NOx Lb/Hr EDS/CMS Summary Report

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59
Generated: 10/01/2026 09:50

Facility Name: ROSEVILLE ENERGY
Location: Roseville, CA
Description: Electric Utility

CMS Data from: CT6_NOx_Norm_LbPerHr_1H, CT6_UnitOn_TF_1H
EDS Data from: CT6_NOx_Norm_LbPerHr_1H, CT6_UnitOn_TF_1H
Emission Limitation: 2.71
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, T200H
Date of Latest CMS Certification or Audit: 04/01/2024 00:00
Process Unit(s) Description:
Operating time for EDS: 97.00 Hour(s)
Operating time for CMS: 97.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	22
2. Total CMS Downtime	22
3. Total Downtime as a percentage of operating time	22.68
4. Total Availability as a percentage of operating time	77.32

NOx SUSD Lb/Hr EDS/CMS Summary Report

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59
Generated: 10/01/2026 09:50

Facility Name: ROSEVILLE ENERGY
Location: Roseville, CA
Description: Electric Utility

CMS Data from: CT6_NOx_SUSD_Lbs_1H, CT6_UnitOn_TF_1H
EDS Data from: CT6_NOx_SUSD_Lbs_1H, CT6_UnitOn_TF_1H
Emission Limitation: 6.50
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, T200H
Date of Latest CMS Certification or Audit: 04/01/2024 00:00
Process Unit(s) Description:
Operating time for EDS: 97.00 Hour(s)
Operating time for CMS: 97.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	18
2. Total CMS Downtime	18
3. Total Downtime as a percentage of operating time	18.56
4. Total Availability as a percentage of operating time	81.44

PM10 LbPerHr 1-Hour Block Excess Emissions

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:06 **Location:** Roseville, CA

Tag Name: CT6_PM10_LbPerHr_1H
Total Operating Time: 97.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,111.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**97.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

SO2 LbPerHr 1-Hour Block Excess Emissions

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:06 **Location:** Roseville, CA

Tag Name: CT6_SO2_P60_LbPerHr_1H
Total Operating Time: 97.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,111.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**97.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

VOC LbPerHr 1-Hour Block Excess Emissions

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:06 **Location:** Roseville, CA

Tag Name: CT6_VOC_Norm_LbPerHr_1H
Total Operating Time: 97.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,111.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**97.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

VOC SUSD Lb 1-Hour Block Excess Emissions

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:35 **Location:** Roseville, CA

Tag Name: CT6_VOC_SUSD_Lbs_1H
Total Operating Time: 97.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,063.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**97.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Startup/Shutdown Event Report

CT6 - VOC Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:35 **Location:** Roseville, CA

Tag Name: CT6_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 75.25 Hours

Non-Operating Time: 2,084.75 Hours Report Time: 2,160.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
07/14/2026 15:51 07/14/2026 15:53 Startup	3	0.00	0.80		
07/14/2026 16:02 07/14/2026 16:04 Startup	3	0.00	0.80		
07/14/2026 16:16 07/14/2026 16:18 Startup	3	0.00	0.80		
07/14/2026 19:42 07/14/2026 19:42 Startup	1	0.00	0.80		
07/14/2026 19:44 07/14/2026 19:44 Startup	1	0.00	0.80		
07/15/2026 07:20 07/15/2026 07:20 Startup	1	0.00	0.80		
07/15/2026 07:27 07/15/2026 07:27 Startup	1	0.00	0.80		
07/15/2026 11:51 07/15/2026 12:00 Startup	10	0.05	0.80		
07/15/2026 20:58 07/15/2026 21:05 Shutdown	8	0.02	0.90		
07/20/2026 15:06 07/20/2026 15:16 Startup	11	0.05	0.80		
07/20/2026 21:28 07/20/2026 21:35 Shutdown	8	0.02	0.90		
07/21/2026 13:51 07/21/2026 14:00 Startup	10	0.05	0.80		
07/21/2026 20:58 07/21/2026 21:05 Shutdown	8	0.02	0.90		

Startup/Shutdown Event Report

CT6 - VOC Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:35 **Location:** Roseville, CA

Tag Name: CT6_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 75.25 Hours

Non-Operating Time: 2,084.75 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
08/03/2026 14:51 08/03/2026 14:59 Startup	9	0.04	0.80		
08/03/2026 20:58 08/03/2026 21:04 Shutdown	7	0.02	0.90		
08/04/2026 14:52 08/04/2026 15:01 Startup	10	0.04	0.80		
08/04/2026 19:58 08/04/2026 20:04 Shutdown	7	0.02	0.90		
08/05/2026 14:05 08/05/2026 14:14 Startup	10	0.04	0.80		
08/05/2026 19:58 08/05/2026 20:04 Shutdown	7	0.02	0.90		
08/06/2026 15:31 08/06/2026 15:42 Startup	12	0.04	0.80		
08/06/2026 19:58 08/06/2026 20:04 Shutdown	7	0.02	0.90		
08/19/2026 15:31 08/19/2026 15:42 Startup	12	0.05	0.80		
08/19/2026 21:58 08/19/2026 22:04 Shutdown	7	0.02	0.90		
08/27/2026 15:20 08/27/2026 15:30 Startup	11	0.04	0.80		
08/27/2026 19:58 08/27/2026 20:04 Shutdown	7	0.02	0.90		
09/08/2026 16:53 09/08/2026 17:02 Startup	10	0.04	0.80		
09/08/2026 21:58 09/08/2026 22:05 Shutdown	8	0.02	0.90		

Startup/Shutdown Event Report

CT6 - VOC Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:35 **Location:** Roseville, CA

Tag Name: CT6_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 75.25 Hours

Non-Operating Time: 2,084.75 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
09/09/2026 11:51 09/09/2026 12:03 Startup	13	0.04	0.80		
09/09/2026 20:58 09/09/2026 21:04 Shutdown	7	0.02	0.90		
09/10/2026 15:51 09/10/2026 16:00 Startup	10	0.04	0.80		
09/10/2026 19:59 09/10/2026 20:05 Shutdown	7	0.01	0.90		

No excess emissions were found in the reporting period.

Startup/Shutdown Event Report

CT6 - VOC Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:35 **Location:** Roseville, CA

Tag Name: CT6_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 75.25 Hours

Non-Operating Time: 2,084.75 Hours Report Time: 2,160.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Startup/Shutdown Event Report

CT6 - VOC Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:35 **Location:** Roseville, CA

Tag Name: CT6_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 75.25 Hours

Non-Operating Time: 2,084.75 Hours Report Time: 2,160.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

CO Invalid Data

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Tag Name: CT1_CO_Ppm_1H
Total Operating Time: 1,986.00 Hour(s)
Non-Operating Time: 222.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	**1,986.00 Hour(s)**
Total Monitor Downtime (Online only):	**0.00 Hour(s)**
Percent Monitor Availability:	**100.00 %**
Percent Monitor Downtime:	**0.00 %**

NOx Invalid Data

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Tag Name: CT1_NOx_Ppm_1H
Total Operating Time: 1,986.00 Hour(s)
Non-Operating Time: 222.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	**1,986.00 Hour(s)**
Total Monitor Downtime (Online only):	**0.00 Hour(s)**
Percent Monitor Availability:	**100.00 %**
Percent Monitor Downtime:	**0.00 %**

NOx SCR Invalid Data

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Tag Name: CT1_NOx_SCR_Ppm_1H
Total Operating Time: 1,986.00 Hour(s)
Non-Operating Time: 222.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	**1,986.00 Hour(s)**
Total Monitor Downtime (Online only):	**0.00 Hour(s)**
Percent Monitor Availability:	**100.00 %**
Percent Monitor Downtime:	**0.00 %**

O2 Invalid Data

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Tag Name: CT1_O2Dry_Pct_1H
Total Operating Time: 1,986.00 Hour(s)
Non-Operating Time: 222.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	**1,986.00 Hour(s)**
Total Monitor Downtime (Online only):	**0.00 Hour(s)**
Percent Monitor Availability:	**100.00 %**
Percent Monitor Downtime:	**0.00 %**

CO Invalid Data

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Tag Name: CT2_CO_Ppm_1H
Total Operating Time: 2,202.00 Hour(s)
Non-Operating Time: 6.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	09/16/2026 07:00	09/16/2026 07:59	1	54 - UNIT TRIP. NOT ENOUGH MINUTES AFTER MAINTENANCE	27 - PERFORM CALIBRATION WHEN UNIT COMES ON LINE.

Total Operating Time:	**2,202.00 Hour(s)**
Total Monitor Downtime (Online only):	**1.00 Hour(s)**
Percent Monitor Availability:	**99.95 %**
Percent Monitor Downtime:	**0.05 %**

Report Code	Type	Text	Duration	Duration Percent
54	Reason	UNIT TRIP. NOT ENOUGH MINUTES AFTER MAINTENANCE	1	100.00
27	Action	PERFORM CALIBRATION WHEN UNIT COMES ON LINE.	1	100.00

NOx Invalid Data

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:15 **Location:** Roseville, CA

Tag Name: CT2_NOx_Ppm_1H
Total Operating Time: 2,202.00 Hour(s)
Non-Operating Time: 6.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	09/16/2026 07:00	09/16/2026 07:59	1	54 - UNIT TRIP. NOT ENOUGH MINUTES AFTER MAINTENANCE	27 - PERFORM CALIBRATION WHEN UNIT COMES ON LINE.

Total Operating Time:	**2,202.00 Hour(s)**
Total Monitor Downtime (Online only):	**1.00 Hour(s)**
Percent Monitor Availability:	**99.95 %**
Percent Monitor Downtime:	**0.05 %**

Report Code	Type	Text	Duration	Duration Percent
54	Reason	UNIT TRIP. NOT ENOUGH MINUTES AFTER MAINTENANCE	1	100.00
27	Action	PERFORM CALIBRATION WHEN UNIT COMES ON LINE.	1	100.00

NOx SCR Invalid Data

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Tag Name: CT2_NOx_SCR_Ppm_1H
Total Operating Time: 2,202.00 Hour(s)
Non-Operating Time: 6.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	09/16/2026 07:00	09/16/2026 07:59	1	54 - UNIT TRIP. NOT ENOUGH MINUTES AFTER MAINTENANCE	27 - PERFORM CALIBRATION WHEN UNIT COMES ON LINE.

Total Operating Time:	**2,202.00 Hour(s)**
Total Monitor Downtime (Online only):	**1.00 Hour(s)**
Percent Monitor Availability:	**99.95 %**
Percent Monitor Downtime:	**0.05 %**

Report Code	Type	Text	Duration	Duration Percent
54	Reason	UNIT TRIP. NOT ENOUGH MINUTES AFTER MAINTENANCE	1	100.00
27	Action	PERFORM CALIBRATION WHEN UNIT COMES ON LINE.	1	100.00

O2 Invalid Data

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Tag Name: CT2_O2Dry_Pct_1H
Total Operating Time: 2,202.00 Hour(s)
Non-Operating Time: 6.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	09/16/2026 07:00	09/16/2026 07:59	1	54 - UNIT TRIP. NOT ENOUGH MINUTES AFTER MAINTENANCE	27 - PERFORM CALIBRATION WHEN UNIT COMES ON LINE.

Total Operating Time:	**2,202.00 Hour(s)**
Total Monitor Downtime (Online only):	**1.00 Hour(s)**
Percent Monitor Availability:	**99.95 %**
Percent Monitor Downtime:	**0.05 %**

Report Code	Type	Text	Duration	Duration Percent
54	Reason	UNIT TRIP. NOT ENOUGH MINUTES AFTER MAINTENANCE	1	100.00
27	Action	PERFORM CALIBRATION WHEN UNIT COMES ON LINE.	1	100.00

CO Invalid Data

CT5

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:40 **Location:** Roseville, CA

Tag Name: CT5_CO_Ppm_1H
Total Operating Time: 81.00 Hour(s)
Non-Operating Time: 2,079.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	**81.00 Hour(s)**
Total Monitor Downtime (Online only):	**0.00 Hour(s)**
Percent Monitor Availability:	**100.00 %**
Percent Monitor Downtime:	**0.00 %**

NOx Invalid Data

CT5

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:40 **Location:** Roseville, CA

Tag Name: CT5_NOx_Ppm_1H
Total Operating Time: 81.00 Hour(s)
Non-Operating Time: 2,079.00 Hour(s) Report Time: 2,160.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	08/06/2026 14:00	08/06/2026 14:59	1		
2	08/06/2026 15:00	08/06/2026 15:59	1		
3	08/07/2026 11:00	08/07/2026 11:59	1		
4	08/07/2026 12:00	08/07/2026 12:59	1		
5	08/20/2026 11:00	08/20/2026 11:59	1		
6	08/20/2026 12:00	08/20/2026 12:59	1	3 - Quality assurance calibration	
7	08/28/2026 08:00	08/28/2026 08:59	1		

Total Operating Time:	**81.00 Hour(s)**
Total Monitor Downtime (Online only):	**7.00 Hour(s)**
Percent Monitor Availability:	**91.36 %**
Percent Monitor Downtime:	**8.64 %**

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	1	14.29

NOx SCR Invalid Data

CT5

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:40 **Location:** Roseville, CA

Tag Name: CT5_NOx_SCR_Ppm_1H
Total Operating Time: 81.00 Hour(s)
Non-Operating Time: 2,079.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	**81.00 Hour(s)**
Total Monitor Downtime (Online only):	**0.00 Hour(s)**
Percent Monitor Availability:	**100.00 %**
Percent Monitor Downtime:	**0.00 %**

O2 Invalid Data

CT5

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:40 **Location:** Roseville, CA

Tag Name: CT5_O2Dry_Pct_1H
Total Operating Time: 81.00 Hour(s)
Non-Operating Time: 2,079.00 Hour(s) Report Time: 2,160.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	08/06/2026 14:00	08/06/2026 14:59	1		
2	08/06/2026 15:00	08/06/2026 15:59	1		
3	08/07/2026 11:00	08/07/2026 11:59	1		
4	08/07/2026 12:00	08/07/2026 12:59	1		
5	08/20/2026 11:00	08/20/2026 11:59	1		
6	08/20/2026 12:00	08/20/2026 12:59	1	3 - Quality assurance calibration	
7	08/28/2026 08:00	08/28/2026 08:59	1		

Total Operating Time:	**81.00 Hour(s)**
Total Monitor Downtime (Online only):	**7.00 Hour(s)**
Percent Monitor Availability:	**91.36 %**
Percent Monitor Downtime:	**8.64 %**

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	1	14.29

CO Invalid Data

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:45 **Location:** Roseville, CA

Tag Name: CT6_CO_Ppm_1H
Total Operating Time: 97.00 Hour(s)
Non-Operating Time: 2,063.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	**97.00 Hour(s)**
Total Monitor Downtime (Online only):	**0.00 Hour(s)**
Percent Monitor Availability:	**100.00 %**
Percent Monitor Downtime:	**0.00 %**

NOx Invalid Data

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:45 **Location:** Roseville, CA

Tag Name: CT6_NOx_Ppm_1H
Total Operating Time: 97.00 Hour(s)
Non-Operating Time: 2,063.00 Hour(s) Report Time: 2,160.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	07/14/2026 15:00	07/14/2026 15:59	1	8 - No prior online calibration within 26 hours	
2	07/14/2026 16:00	07/14/2026 16:59	1	8 - No prior online calibration within 26 hours	
3	07/14/2026 19:00	07/14/2026 19:59	1	8 - No prior online calibration within 26 hours	
4	07/15/2026 07:00	07/15/2026 07:59	1	8 - No prior online calibration within 26 hours	
5	07/15/2026 11:00	07/15/2026 11:59	1	8 - No prior online calibration within 26 hours	

Total Operating Time:	**97.00 Hour(s)**
Total Monitor Downtime (Online only):	**5.00 Hour(s)**
Percent Monitor Availability:	**94.85 %**
Percent Monitor Downtime:	**5.15 %**

Report Code	Type	Text	Duration	Duration Percent
8	Reason	No prior online calibration within 26 hours	5	100.00

NOx SCR Invalid Data

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:45 **Location:** Roseville, CA

Tag Name: CT6_NOx_SCR_Ppm_1H
Total Operating Time: 97.00 Hour(s)
Non-Operating Time: 2,063.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	**97.00 Hour(s)**
Total Monitor Downtime (Online only):	**0.00 Hour(s)**
Percent Monitor Availability:	**100.00 %**
Percent Monitor Downtime:	**0.00 %**

O2 Invalid Data

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:45 **Location:** Roseville, CA

Tag Name: CT6_O2Dry_Pct_1H
Total Operating Time: 97.00 Hour(s)
Non-Operating Time: 2,063.00 Hour(s) Report Time: 2,160.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	07/14/2026 15:00	07/14/2026 15:59	1	8 - No prior online calibration within 26 hours	
2	07/14/2026 16:00	07/14/2026 16:59	1	8 - No prior online calibration within 26 hours	
3	07/14/2026 19:00	07/14/2026 19:59	1	8 - No prior online calibration within 26 hours	
4	07/15/2026 07:00	07/15/2026 07:59	1	8 - No prior online calibration within 26 hours	
5	07/15/2026 11:00	07/15/2026 11:59	1	8 - No prior online calibration within 26 hours	

Total Operating Time:	**97.00 Hour(s)**
Total Monitor Downtime (Online only):	**5.00 Hour(s)**
Percent Monitor Availability:	**94.85 %**
Percent Monitor Downtime:	**5.15 %**

Report Code	Type	Text	Duration	Duration Percent
8	Reason	No prior online calibration within 26 hours	5	100.00

Linearity Report

ORIS Code: 56298
Facility Name: ROSEVILLE ENERGY
EDR Site ID: CT001
Component ID: A15
ReasonForTest: QA
Component Type: NOXA
Grace Period: 0
Instrument Name: CT1_NOXDualRg_P_Instrum
Test End Date/Time: 07/27/2026
Scale: High
Performance Spec: 5 %
Test No.: 144
Highest Error: 1.7
Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
07/27/2026	1241	L	200.0	51.7	50.5		25.9 %
07/27/2026	1246	M	200.0	111.5	111.1		55.8 %
07/27/2026	1251	H	200.0	177.9	179.1		89.0 %
07/27/2026	1258	L	200.0	51.7	50.9		25.9 %
07/27/2026	1303	M	200.0	111.5	111.6		55.8 %
07/27/2026	1308	H	200.0	177.9	179.6		89.0 %
07/27/2026	1315	L	200.0	51.7	51.0		25.9 %
07/27/2026	1320	M	200.0	111.5	111.8		55.8 %
07/27/2026	1325	H	200.0	177.9	179.6		89.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	51.700	50.800	No	**1.7**
M	111.500	111.500	No	**0.0**
H	177.900	179.433	No	**0.9**

Linearity Report

ORIS Code: 56298
Facility Name: ROSEVILLE ENERGY
EDR Site ID: CT001
Component ID: A16
ReasonForTest: QA
Component Type: O2D
Grace Period: 0
Instrument Name: CT1_O2D_P_Instrument
Test End Date/Time: 07/27/2026
Scale: High
Performance Spec: 5 %
Test No.: 145
Highest Error: 4.0
Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
07/27/2026	1425	L	18.0	5.0	4.8		27.8 %
07/27/2026	1430	M	18.0	11.0	10.9		61.1 %
07/27/2026	1435	H	18.0	18.0	18.0		100.0 %
07/27/2026	1442	L	18.0	5.0	4.8		27.8 %
07/27/2026	1447	M	18.0	11.0	10.9		61.1 %
07/27/2026	1452	H	18.0	18.0	18.0		100.0 %
07/27/2026	1459	L	18.0	5.0	4.8		27.8 %
07/27/2026	1504	M	18.0	11.0	10.9		61.1 %
07/27/2026	1509	H	18.0	18.0	18.0		100.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.000	4.800	No	**4.0**
M	11.000	10.900	No	**0.9**
H	18.000	18.000	No	**0.0**

Linearity Report

ORIS Code: 56298
Facility Name: ROSEVILLE ENERGY
EDR Site ID: CT002
Component ID: A22
ReasonForTest: QA
Component Type: O2D
Grace Period: 0
Instrument Name: CT2_O2D_P_Instrument
Test End Date/Time: 07/27/2026
Scale: High
Performance Spec: 5 %
Test No.: 145
Highest Error: 0.7
Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
07/27/2026	0747	L	21.0	5.0	5.1		23.8 %
07/27/2026	0752	M	21.0	11.0	11.0		52.4 %
07/27/2026	0757	H	21.0	18.0	18.0		85.7 %
07/27/2026	0804	L	21.0	5.0	5.0		23.8 %
07/27/2026	0809	M	21.0	11.0	11.0		52.4 %
07/27/2026	0814	H	21.0	18.0	18.0		85.7 %
07/27/2026	0821	L	21.0	5.0	5.0		23.8 %
07/27/2026	0826	M	21.0	11.0	11.0		52.4 %
07/27/2026	0831	H	21.0	18.0	18.0		85.7 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.000	5.033	No	**0.7**
M	11.000	11.000	No	**0.0**
H	18.000	18.000	No	**0.0**

Linearity Report

ORIS Code: 56298
Facility Name: ROSEVILLE ENERGY
EDR Site ID: CT002
Component ID: A21
ReasonForTest: QA
Component Type: NOXA
Grace Period: 0
Instrument Name: CT2_NOXDualRg_P_Instrum
Test End Date/Time: 07/27/2026
Scale: High
Performance Spec: 5 %
Test No.: 146
Highest Error: 0.3
Status (Pass/Fail): **Passed**

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
07/27/2026	0927	L	200.0	51.1	51.2		25.6 %
07/27/2026	0932	M	200.0	108.5	106.6		54.3 %
07/27/2026	0937	H	200.0	179.0	179.7		89.5 %
07/27/2026	0944	L	200.0	51.1	50.9		25.6 %
07/27/2026	0949	M	200.0	108.5	109.2		54.3 %
07/27/2026	0954	H	200.0	179.0	179.3		89.5 %
07/27/2026	1001	L	200.0	51.1	50.9		25.6 %
07/27/2026	1006	M	200.0	108.5	108.9		54.3 %
07/27/2026	1011	H	200.0	179.0	179.8		89.5 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	51.100	51.000	No	**0.2**
M	108.500	108.233	No	**0.2**
H	179.000	179.600	No	**0.3**

No linearity tests were performed on CT5 and CT6 during Q3 2026 due to the units running under 168 hours during the reporting quarter. Last completed linearity Q1 2026.

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/01/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	07/01/26 02:24	200.0	179.0	178.0		|R-A|/Span * 100		0.5
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/01/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	07/01/26 02:19	30.0	20.6	20.4		|R-A|/Span * 100		0.7
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/01/26 03:14	200.0	0.0	0.3		|R-A|/Span * 100		0.2
	High	07/01/26 03:24	200.0	178.7	176.4		|R-A|/Span * 100		1.2
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/01/26 03:14	10.0	0.0	-0.1		|R-A|/Span * 100		1.0
	High	07/01/26 03:19	10.0	9.1	9.1		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/01/26 03:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	07/01/26 03:24	200.0	179.0	179.5		|R-A|/Span * 100		0.3
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/01/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/01/26 03:19	10.0	9.3	9.3		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/01/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	07/01/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT5_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Offline**			**Pass**
	Zero	07/01/26 07:53	1,000.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/01/26 08:03	1,000.0	907.4	910.4		|R-A|/Span * 100		0.3
Part 60	**CT5_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Offline**			**Pass**
	High	07/01/26 07:48	20.0	18.3	18.5		|R-A|/Span * 100		1.0
	Zero	07/01/26 07:53	20.0	0.0	0.1		|R-A|/Span * 100		0.5
Part 75	**CT5_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Offline**			**Offline**
	Zero	07/01/26 07:48	500.0	0.0	0.2	off	|R-A|/Span * 100		0.0
	High	07/01/26 07:58	500.0	444.4	444.2	off	|R-A|/Span * 100		0.0
Part 75	**CT5_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Offline**			**Offline**
	Zero	07/01/26 07:48	10.0	0.0	0.2	off	|R-A|/Span * 100		2.0
	High	07/01/26 07:53	10.0	9.6	9.8	off	|R-A|/Span * 100		2.0
Part 75	**CT5_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Offline**			**Offline**
	High	07/01/26 07:48	25.0	22.5	22.5	off	|R-A|		0.0
	Zero	07/01/26 07:53	25.0	0.0	0.0	off	|R-A|		0.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT6_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Offline**			**Pass**
	Zero	07/01/26 08:40	1,000.0	0.0	-0.1		|R-A|/Span * 100		0.0
	High	07/01/26 08:50	1,000.0	905.1	897.6		|R-A|/Span * 100		0.8
Part 60	**CT6_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Offline**			**Pass**
	High	07/01/26 08:35	20.0	18.3	18.3		|R-A|/Span * 100		0.0
	Zero	07/01/26 08:40	20.0	0.0	-0.1		|R-A|/Span * 100		0.5
Part 75	**CT6_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Offline**			**Offline**
	Zero	07/01/26 08:35	500.0	0.0	-0.1	Off	|R-A|/Span * 100		0.0
	High	07/01/26 08:45	500.0	439.3	439.8	Off	|R-A|/Span * 100		0.1
Part 75	**CT6_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Offline**			**Offline**
	Zero	07/01/26 08:35	10.0	0.0	0.1	Off	|R-A|/Span * 100		1.0
	High	07/01/26 08:40	10.0	9.7	10.0	Off	|R-A|/Span * 100		3.0
Part 75	**CT6_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Offline**			**Offline**
	High	07/01/26 08:35	25.0	22.5	22.5	Off	|R-A|		0.0
	Zero	07/01/26 08:40	25.0	0.0	0.0	Off	|R-A|		0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/02/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	07/02/26 02:24	200.0	179.0	178.6		|R-A|/Span * 100		0.2
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/02/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	07/02/26 02:19	30.0	20.6	20.5		|R-A|/Span * 100		0.3
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/02/26 03:14	200.0	0.0	0.4		|R-A|/Span * 100		0.2
	High	07/02/26 03:24	200.0	178.7	176.4		|R-A|/Span * 100		1.2
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/02/26 03:14	10.0	0.0	-0.1		|R-A|/Span * 100		1.0
	High	07/02/26 03:19	10.0	9.1	9.1		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/02/26 03:14	200.0	0.0	0.4		|R-A|/Span * 100		0.2
	High	07/02/26 03:24	200.0	179.0	179.1		|R-A|/Span * 100		0.1
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/02/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/02/26 03:19	10.0	9.3	9.3		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/02/26 03:14	21.0	18.0	18.1		|R-A|		0.1
	Zero	07/02/26 03:19	21.0	0.0	0.0		|R-A|		0.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/03/26 01:44	200.0	0.0	1.2		|R-A|/Span * 100		0.6
	High	07/03/26 01:54	200.0	178.6	179.9		|R-A|/Span * 100		0.7
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/03/26 01:44	10.0	0.0	-0.1		|R-A|/Span * 100		1.0
	High	07/03/26 01:49	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/03/26 01:44	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/03/26 01:54	200.0	177.0	175.4		|R-A|/Span * 100		0.8
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/03/26 01:44	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/03/26 01:49	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/03/26 01:44	18.0	18.0	18.0		|R-A|		0.0
	Zero	07/03/26 01:49	18.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/03/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	07/03/26 02:24	200.0	177.0	177.5		|R-A|/Span * 100		0.3
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/03/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/03/26 02:19	30.0	20.3	20.5		|R-A|/Span * 100		0.7
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/03/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	07/03/26 02:24	200.0	179.0	178.6		|R-A|/Span * 100		0.2
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/03/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	07/03/26 02:19	30.0	20.6	20.4		|R-A|/Span * 100		0.7
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/03/26 03:14	200.0	0.0	1.3		|R-A|/Span * 100		0.7
	High	07/03/26 03:24	200.0	178.6	180.0		|R-A|/Span * 100		0.7
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/03/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/03/26 03:19	10.0	9.2	9.3		|R-A|/Span * 100		1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/03/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/03/26 03:24	200.0	177.0	175.6		|R-A|/Span * 100		0.7

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/03/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/03/26 03:19	10.0	9.4	9.3		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/03/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	07/03/26 03:19	18.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/03/26 03:14	200.0	0.0	0.4		|R-A|/Span * 100		0.2
	High	07/03/26 03:24	200.0	178.7	176.4		|R-A|/Span * 100		1.2
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/03/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/03/26 03:19	10.0	9.1	9.2		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/03/26 03:14	200.0	0.0	0.3		|R-A|/Span * 100		0.2
	High	07/03/26 03:24	200.0	179.0	179.0		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/03/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/03/26 03:19	10.0	9.3	9.3		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/03/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	07/03/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/04/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	07/04/26 02:24	200.0	177.0	177.1		|R-A|/Span * 100		0.1
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/04/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	07/04/26 02:19	30.0	20.3	20.5		|R-A|/Span * 100		0.7
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/04/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	07/04/26 02:24	200.0	179.0	178.3		|R-A|/Span * 100		0.4
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/04/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	07/04/26 02:19	30.0	20.6	20.4		|R-A|/Span * 100		0.7
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/04/26 03:14	200.0	0.0	1.3		|R-A|/Span * 100		0.7
	High	07/04/26 03:24	200.0	178.6	179.6		|R-A|/Span * 100		0.5

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	07/04/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/04/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	07/04/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/04/26 03:24	200.0	177.0	174.5		|R-A|/Span * 100		1.3
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	07/04/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/04/26 03:19	10.0	9.4	9.2		|R-A|/Span * 100		2.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	High	07/04/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	07/04/26 03:19	18.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	07/04/26 03:14	200.0	0.0	0.3		|R-A|/Span * 100		0.2
	High	07/04/26 03:24	200.0	178.7	175.9		|R-A|/Span * 100		1.4
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	07/04/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/04/26 03:19	10.0	9.1	9.1		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	07/04/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/04/26 03:24	200.0	179.0	178.6		|R-A|/Span * 100		0.2
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	07/04/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/04/26 03:19	10.0	9.3	9.3		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	High	07/04/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	07/04/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	07/05/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	07/05/26 02:24	200.0	179.0	178.1		|R-A|/Span * 100		0.5
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	07/05/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	07/05/26 02:19	30.0	20.6	20.4		|R-A|/Span * 100		0.7
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	07/05/26 03:14	200.0	0.0	0.4		|R-A|/Span * 100		0.2
	High	07/05/26 03:24	200.0	178.7	176.5		|R-A|/Span * 100		1.1

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	07/05/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/05/26 03:19	10.0	9.1	9.2		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	07/05/26 03:14	200.0	0.0	0.1		|R-A|/Span * 100		0.1
	High	07/05/26 03:24	200.0	179.0	178.4		|R-A|/Span * 100		0.3
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	07/05/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/05/26 03:19	10.0	9.3	9.3		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	High	07/05/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	07/05/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	07/06/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	07/06/26 02:24	200.0	179.0	178.1		|R-A|/Span * 100		0.5
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	07/06/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	07/06/26 02:19	30.0	20.6	20.4		|R-A|/Span * 100		0.7
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	07/06/26 03:14	200.0	0.0	0.4		|R-A|/Span * 100		0.2
	High	07/06/26 03:24	200.0	178.7	176.5		|R-A|/Span * 100		1.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	07/06/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/06/26 03:19	10.0	9.1	9.2		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	07/06/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/06/26 03:24	200.0	179.0	178.9		|R-A|/Span * 100		0.1
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	07/06/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/06/26 03:19	10.0	9.3	9.3		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	High	07/06/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	07/06/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Offline**		**Pass**	
	Zero	07/06/26 07:40	200.0	0.0	1.6		|R-A|/Span * 100		0.8
	High	07/06/26 07:50	200.0	178.6	179.6		|R-A|/Span * 100		0.5

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Offline**			**Pass**
	Zero	07/06/26 07:40	10.0	0.0	0.1		|R-A|/Span * 100		1.0
	High	07/06/26 07:45	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Offline**			**Offline**
	Zero	07/06/26 07:40	200.0	0.0	0.0	Off	|R-A|/Span * 100		0.0
	High	07/06/26 07:50	200.0	177.0	178.3	Off	|R-A|/Span * 100		0.7
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Offline**			**Offline**
	Zero	07/06/26 07:40	10.0	0.0	0.0	Off	|R-A|/Span * 100		0.0
	High	07/06/26 07:45	10.0	9.4	9.6	Off	|R-A|/Span * 100		2.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Offline**			**Offline**
	High	07/06/26 07:40	18.0	18.0	18.0	Off	|R-A|		0.0
	Zero	07/06/26 07:45	18.0	0.0	0.0	Off	|R-A|		0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/07/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	07/07/26 02:24	200.0	179.0	177.9		|R-A|/Span * 100		0.6
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/07/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	07/07/26 02:19	30.0	20.6	20.3		|R-A|/Span * 100		1.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/07/26 03:14	200.0	0.0	0.4		|R-A|/Span * 100		0.2
	High	07/07/26 03:24	200.0	178.7	176.9		|R-A|/Span * 100		0.9
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/07/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/07/26 03:19	10.0	9.1	9.2		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/07/26 03:14	200.0	0.0	0.3		|R-A|/Span * 100		0.2
	High	07/07/26 03:24	200.0	179.0	179.0		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/07/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/07/26 03:19	10.0	9.3	9.3		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/07/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	07/07/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/08/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	07/08/26 02:24	200.0	179.0	177.9		|R-A|/Span * 100		0.6

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/08/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	07/08/26 02:19	30.0	20.6	20.3		|R-A|/Span * 100		1.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/08/26 03:14	200.0	0.0	0.4		|R-A|/Span * 100		0.2
	High	07/08/26 03:24	200.0	178.7	176.2		|R-A|/Span * 100		1.3
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/08/26 03:14	10.0	0.0	-0.1		|R-A|/Span * 100		1.0
	High	07/08/26 03:19	10.0	9.1	9.2		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/08/26 03:14	200.0	0.0	0.3		|R-A|/Span * 100		0.2
	High	07/08/26 03:24	200.0	179.0	178.6		|R-A|/Span * 100		0.2
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/08/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/08/26 03:19	10.0	9.3	9.3		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/08/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	07/08/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/09/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	07/09/26 02:24	200.0	179.0	178.7		|R-A|/Span * 100		0.2
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/09/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	07/09/26 02:19	30.0	20.6	20.5		|R-A|/Span * 100		0.3
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/09/26 03:14	200.0	0.0	0.4		|R-A|/Span * 100		0.2
	High	07/09/26 03:24	200.0	178.7	176.5		|R-A|/Span * 100		1.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/09/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/09/26 03:19	10.0	9.1	9.2		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/09/26 03:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	07/09/26 03:24	200.0	179.0	178.4		|R-A|/Span * 100		0.3
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/09/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/09/26 03:19	10.0	9.3	9.3		|R-A|/Span * 100		0.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/09/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	07/09/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/10/26 02:14	200.0	0.0	-0.5		|R-A|/Span * 100		0.3
	High	07/10/26 02:24	200.0	179.0	178.0		|R-A|/Span * 100		0.5
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/10/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	07/10/26 02:19	30.0	20.6	20.4		|R-A|/Span * 100		0.7
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/10/26 03:14	200.0	0.0	0.3		|R-A|/Span * 100		0.2
	High	07/10/26 03:24	200.0	178.7	176.4		|R-A|/Span * 100		1.2
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/10/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/10/26 03:19	10.0	9.1	9.2		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/10/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/10/26 03:24	200.0	179.0	179.7		|R-A|/Span * 100		0.4
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/10/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/10/26 03:19	10.0	9.3	9.3		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/10/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	07/10/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/10/26 18:14	200.0	0.0	1.5		|R-A|/Span * 100		0.8
	High	07/10/26 18:24	200.0	178.6	180.5		|R-A|/Span * 100		1.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/10/26 18:14	10.0	0.0	0.1		|R-A|/Span * 100		1.0
	High	07/10/26 18:19	10.0	9.2	9.3		|R-A|/Span * 100		1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/10/26 18:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/10/26 18:24	200.0	177.0	177.6		|R-A|/Span * 100		0.3
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/10/26 18:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/10/26 18:19	10.0	9.4	9.5		|R-A|/Span * 100		1.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/10/26 18:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	07/10/26 18:19	18.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/11/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	07/11/26 02:24	200.0	177.0	175.0		|R-A|/Span * 100		1.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/11/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/11/26 02:19	30.0	20.3	19.9		|R-A|/Span * 100		1.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/11/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	07/11/26 02:24	200.0	179.0	176.2		|R-A|/Span * 100		1.4
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/11/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	07/11/26 02:19	30.0	20.6	19.9		|R-A|/Span * 100		2.3
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/11/26 03:14	200.0	0.0	1.7		|R-A|/Span * 100		0.9
	High	07/11/26 03:24	200.0	178.6	181.2		|R-A|/Span * 100		1.3
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/11/26 03:14	10.0	0.0	0.1		|R-A|/Span * 100		1.0
	High	07/11/26 03:19	10.0	9.2	9.3		|R-A|/Span * 100		1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/11/26 03:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	07/11/26 03:24	200.0	177.0	177.9		|R-A|/Span * 100		0.5
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/11/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/11/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/11/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	07/11/26 03:19	18.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/11/26 03:14	200.0	0.0	0.2		|R-A|/Span * 100		0.1
	High	07/11/26 03:24	200.0	178.7	176.3		|R-A|/Span * 100		1.2
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/11/26 03:14	10.0	0.0	-0.1		|R-A|/Span * 100		1.0
	High	07/11/26 03:19	10.0	9.1	9.2		|R-A|/Span * 100		1.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	07/11/26 03:14	200.0	0.0	0.2		|R-A|/Span * 100		0.1
	High	07/11/26 03:24	200.0	179.0	179.6		|R-A|/Span * 100		0.3
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	07/11/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/11/26 03:19	10.0	9.3	9.3		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	High	07/11/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	07/11/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	07/12/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	07/12/26 02:24	200.0	177.0	174.9		|R-A|/Span * 100		1.1
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	07/12/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/12/26 02:19	30.0	20.3	20.0		|R-A|/Span * 100		1.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	07/12/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	07/12/26 02:24	200.0	179.0	176.5		|R-A|/Span * 100		1.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	07/12/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/12/26 02:19	30.0	20.6	20.0		|R-A|/Span * 100		2.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	07/12/26 03:14	200.0	0.0	1.5		|R-A|/Span * 100		0.8
	High	07/12/26 03:24	200.0	178.6	180.6		|R-A|/Span * 100		1.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	07/12/26 03:14	10.0	0.0	0.1		|R-A|/Span * 100		1.0
	High	07/12/26 03:19	10.0	9.2	9.3		|R-A|/Span * 100		1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	07/12/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/12/26 03:24	200.0	177.0	177.8		|R-A|/Span * 100		0.4
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	07/12/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/12/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	High	07/12/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	07/12/26 03:19	18.0	0.0	0.0		|R-A|		0.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	07/12/26 03:14	200.0	0.0	0.3		|R-A|/Span * 100		0.2
	High	07/12/26 03:24	200.0	178.7	176.6		|R-A|/Span * 100		1.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	07/12/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/12/26 03:19	10.0	9.1	9.2		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	07/12/26 03:14	200.0	0.0	0.4		|R-A|/Span * 100		0.2
	High	07/12/26 03:24	200.0	179.0	179.8		|R-A|/Span * 100		0.4
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	07/12/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/12/26 03:19	10.0	9.3	9.3		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	High	07/12/26 03:14	21.0	18.0	18.1		|R-A|		0.1
	Zero	07/12/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	07/13/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	07/13/26 02:24	200.0	177.0	174.0		|R-A|/Span * 100		1.5
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	07/13/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	07/13/26 02:19	30.0	20.3	19.9		|R-A|/Span * 100		1.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	07/13/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	07/13/26 02:24	200.0	179.0	177.0		|R-A|/Span * 100		1.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	07/13/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	07/13/26 02:19	30.0	20.6	20.2		|R-A|/Span * 100		1.3
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	07/13/26 03:14	200.0	0.0	1.5		|R-A|/Span * 100		0.8
	High	07/13/26 03:24	200.0	178.6	180.2		|R-A|/Span * 100		0.8
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	07/13/26 03:14	10.0	0.0	0.1		|R-A|/Span * 100		1.0
	High	07/13/26 03:19	10.0	9.2	9.3		|R-A|/Span * 100		1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	07/13/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/13/26 03:24	200.0	177.0	176.4		|R-A|/Span * 100		0.3

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/13/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/13/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/13/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	07/13/26 03:19	18.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/13/26 03:14	200.0	0.0	0.3		|R-A|/Span * 100		0.2
	High	07/13/26 03:24	200.0	178.7	176.5		|R-A|/Span * 100		1.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/13/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/13/26 03:19	10.0	9.1	9.2		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/13/26 03:14	200.0	0.0	0.2		|R-A|/Span * 100		0.1
	High	07/13/26 03:24	200.0	179.0	179.2		|R-A|/Span * 100		0.1
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/13/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/13/26 03:19	10.0	9.3	9.3		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/13/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	07/13/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/14/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	07/14/26 02:24	200.0	177.0	173.8		|R-A|/Span * 100		1.6
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/14/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/14/26 02:19	30.0	20.3	19.9		|R-A|/Span * 100		1.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/14/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	07/14/26 02:24	200.0	179.0	177.1		|R-A|/Span * 100		1.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/14/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	07/14/26 02:19	30.0	20.6	20.3		|R-A|/Span * 100		1.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/14/26 03:14	200.0	0.0	1.6		|R-A|/Span * 100		0.8
	High	07/14/26 03:24	200.0	178.6	180.3		|R-A|/Span * 100		0.9

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/14/26 03:14	10.0	0.0	0.1		|R-A|/Span * 100		1.0
	High	07/14/26 03:19	10.0	9.2	9.3		|R-A|/Span * 100		1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/14/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/14/26 03:24	200.0	177.0	177.4		|R-A|/Span * 100		0.2
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/14/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/14/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/14/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	07/14/26 03:19	18.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/14/26 03:14	200.0	0.0	0.3		|R-A|/Span * 100		0.2
	High	07/14/26 03:24	200.0	178.7	176.2		|R-A|/Span * 100		1.3
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/14/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/14/26 03:19	10.0	9.1	9.2		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/14/26 03:14	200.0	0.0	0.1		|R-A|/Span * 100		0.1
	High	07/14/26 03:24	200.0	179.0	179.6		|R-A|/Span * 100		0.3
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/14/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/14/26 03:19	10.0	9.3	9.3		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/14/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	07/14/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT5_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Offline**			**Pass**
	Zero	07/14/26 08:48	1,000.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/14/26 08:58	1,000.0	907.4	905.4		|R-A|/Span * 100		0.2
Part 60	**CT5_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Offline**			**Pass**
	High	07/14/26 08:43	20.0	18.3	18.3		|R-A|/Span * 100		0.0
	Zero	07/14/26 08:48	20.0	0.0	0.0		|R-A|/Span * 100		0.0
Part 75	**CT5_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Offline**			**Offline**
	Zero	07/14/26 08:43	500.0	0.0	0.2	Off	|R-A|/Span * 100		0.0
	High	07/14/26 08:53	500.0	444.4	444.9	Off	|R-A|/Span * 100		0.1

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT5_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Offline**			**Offline**
	Zero	07/14/26 08:43	10.0	0.0	0.2	Off	|R-A|/Span * 100		2.0
	High	07/14/26 08:48	10.0	9.6	9.9	Off	|R-A|/Span * 100		3.0
Part 75	**CT5_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Offline**			**Offline**
	High	07/14/26 08:43	25.0	22.5	22.5	Off	|R-A|		0.0
	Zero	07/14/26 08:48	25.0	0.0	0.0	Off	|R-A|		0.0
Part 60	**CT6_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Offline**			**Pass**
	Zero	07/14/26 09:14	1,000.0	0.0	0.4		|R-A|/Span * 100		0.0
	High	07/14/26 09:24	1,000.0	905.1	905.1		|R-A|/Span * 100		0.0
Part 60	**CT6_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Offline**			**Pass**
	High	07/14/26 09:09	20.0	18.3	18.3		|R-A|/Span * 100		0.0
	Zero	07/14/26 09:14	20.0	0.0	0.4		|R-A|/Span * 100		2.0
Part 75	**CT6_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Offline**			**Offline**
	Zero	07/14/26 09:09	500.0	0.0	-0.1	Off	|R-A|/Span * 100		0.0
	High	07/14/26 09:19	500.0	439.3	439.0	Off	|R-A|/Span * 100		0.1
Part 75	**CT6_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Offline**			**Offline**
	Zero	07/14/26 09:09	10.0	0.0	0.2	Off	|R-A|/Span * 100		2.0
	High	07/14/26 09:14	10.0	9.7	10.0	Off	|R-A|/Span * 100		3.0
Part 75	**CT6_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Offline**			**Offline**
	High	07/14/26 09:09	25.0	22.5	22.5	Off	|R-A|		0.0
	Zero	07/14/26 09:14	25.0	0.0	0.0	Off	|R-A|		0.0
Part 60	**CT5_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/14/26 17:23	1,000.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/14/26 17:33	1,000.0	907.4	909.3		|R-A|/Span * 100		0.2
Part 60	**CT5_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	High	07/14/26 17:18	20.0	18.3	18.4		|R-A|/Span * 100		0.5
	Zero	07/14/26 17:23	20.0	0.0	0.0		|R-A|/Span * 100		0.0
Part 75	**CT5_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/14/26 17:18	500.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/14/26 17:28	500.0	444.4	447.3		|R-A|/Span * 100		0.6
Part 75	**CT5_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/14/26 17:18	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/14/26 17:23	10.0	9.6	9.6		|R-A|/Span * 100		0.0
Part 75	**CT5_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/14/26 17:18	25.0	22.5	22.5		|R-A|		0.0
	Zero	07/14/26 17:23	25.0	0.0	0.0		|R-A|		0.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/15/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	07/15/26 02:24	200.0	177.0	174.2		|R-A|/Span * 100		1.4
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/15/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/15/26 02:19	30.0	20.3	20.0		|R-A|/Span * 100		1.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/15/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	07/15/26 02:24	200.0	179.0	177.0		|R-A|/Span * 100		1.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/15/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/15/26 02:19	30.0	20.6	20.2		|R-A|/Span * 100		1.3
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/15/26 03:14	200.0	0.0	1.6		|R-A|/Span * 100		0.8
	High	07/15/26 03:24	200.0	178.6	180.3		|R-A|/Span * 100		0.9
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/15/26 03:14	10.0	0.0	0.1		|R-A|/Span * 100		1.0
	High	07/15/26 03:19	10.0	9.2	9.3		|R-A|/Span * 100		1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/15/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/15/26 03:24	200.0	177.0	177.5		|R-A|/Span * 100		0.3
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/15/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/15/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/15/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	07/15/26 03:19	18.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/15/26 03:14	200.0	0.0	0.3		|R-A|/Span * 100		0.2
	High	07/15/26 03:24	200.0	178.7	176.4		|R-A|/Span * 100		1.2
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/15/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/15/26 03:19	10.0	9.1	9.2		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/15/26 03:14	200.0	0.0	0.1		|R-A|/Span * 100		0.1
	High	07/15/26 03:24	200.0	179.0	179.4		|R-A|/Span * 100		0.2

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/15/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/15/26 03:19	10.0	9.3	9.3		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/15/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	07/15/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT5_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/15/26 10:09	1,000.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/15/26 10:19	1,000.0	907.4	907.6		|R-A|/Span * 100		0.0
Part 60	**CT5_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	High	07/15/26 10:04	20.0	18.3	18.3		|R-A|/Span * 100		0.0
	Zero	07/15/26 10:09	20.0	0.0	0.0		|R-A|/Span * 100		0.0
Part 75	**CT5_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/15/26 10:04	500.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/15/26 10:14	500.0	444.4	445.8		|R-A|/Span * 100		0.3
Part 75	**CT5_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/15/26 10:04	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/15/26 10:09	10.0	9.6	9.7		|R-A|/Span * 100		1.0
Part 75	**CT5_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/15/26 10:04	25.0	22.5	22.5		|R-A|		0.0
	Zero	07/15/26 10:09	25.0	0.0	0.0		|R-A|		0.0
Part 60	**CT6_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/15/26 12:27	1,000.0	0.0	0.4		|R-A|/Span * 100		0.0
	High	07/15/26 12:37	1,000.0	905.1	902.5		|R-A|/Span * 100		0.3
Part 60	**CT6_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	High	07/15/26 12:22	20.0	18.3	18.3		|R-A|/Span * 100		0.0
	Zero	07/15/26 12:27	20.0	0.0	0.5		|R-A|/Span * 100		2.5
Part 75	**CT6_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/15/26 12:22	500.0	0.0	-0.2		|R-A|/Span * 100		0.0
	High	07/15/26 12:32	500.0	439.3	439.9		|R-A|/Span * 100		0.1
Part 75	**CT6_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/15/26 12:22	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/15/26 12:27	10.0	9.7	9.9		|R-A|/Span * 100		2.0
Part 75	**CT6_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/15/26 12:22	25.0	22.5	22.4		|R-A|		0.1
	Zero	07/15/26 12:27	25.0	0.0	0.0		|R-A|		0.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/16/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	07/16/26 02:24	200.0	177.9	173.9		|R-A|/Span * 100		2.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/16/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/16/26 02:19	30.0	20.3	20.0		|R-A|/Span * 100		1.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/16/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	07/16/26 02:24	200.0	179.0	176.3		|R-A|/Span * 100		1.4
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/16/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/16/26 02:19	30.0	20.6	20.0		|R-A|/Span * 100		2.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/16/26 03:14	200.0	0.0	1.6		|R-A|/Span * 100		0.8
	High	07/16/26 03:24	200.0	179.0	180.0		|R-A|/Span * 100		0.5
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/16/26 03:14	10.0	0.0	0.1		|R-A|/Span * 100		1.0
	High	07/16/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/16/26 03:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	07/16/26 03:24	200.0	177.9	178.4		|R-A|/Span * 100		0.3
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/16/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/16/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/16/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	07/16/26 03:19	18.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/16/26 03:14	200.0	0.0	0.3		|R-A|/Span * 100		0.2
	High	07/16/26 03:24	200.0	178.7	176.8		|R-A|/Span * 100		1.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/16/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/16/26 03:19	10.0	9.1	9.2		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/16/26 03:14	200.0	0.0	0.2		|R-A|/Span * 100		0.1
	High	07/16/26 03:24	200.0	179.0	181.1		|R-A|/Span * 100		1.1

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/16/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/16/26 03:19	10.0	9.3	9.3		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/16/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	07/16/26 03:19	21.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/17/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	07/17/26 02:24	200.0	177.9	174.6		|R-A|/Span * 100		1.7
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/17/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/17/26 02:19	30.0	20.3	19.8		|R-A|/Span * 100		1.7
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/17/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	07/17/26 02:24	200.0	179.0	177.4		|R-A|/Span * 100		0.8
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/17/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/17/26 02:19	30.0	20.6	20.1		|R-A|/Span * 100		1.7
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/17/26 03:14	200.0	0.0	0.4		|R-A|/Span * 100		0.2
	High	07/17/26 03:24	200.0	178.7	176.8		|R-A|/Span * 100		1.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/17/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/17/26 03:19	10.0	9.1	9.2		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/17/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/17/26 03:24	200.0	179.0	179.3		|R-A|/Span * 100		0.2
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/17/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/17/26 03:19	10.0	9.3	9.3		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/17/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	07/17/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/17/26 03:14	200.0	0.0	1.5		|R-A|/Span * 100		0.8
	High	07/17/26 03:25	200.0	179.0	180.0		|R-A|/Span * 100		0.5

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/17/26 03:14	10.0	0.0	0.1		|R-A|/Span * 100		1.0
	High	07/17/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/17/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/17/26 03:25	200.0	177.9	178.8		|R-A|/Span * 100		0.5
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/17/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/17/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/17/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	07/17/26 03:19	18.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/18/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	07/18/26 02:24	200.0	177.9	174.1		|R-A|/Span * 100		1.9
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/18/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/18/26 02:19	30.0	20.3	19.8		|R-A|/Span * 100		1.7
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/18/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	07/18/26 02:24	200.0	179.0	176.1		|R-A|/Span * 100		1.5
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/18/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/18/26 02:19	30.0	20.6	19.9		|R-A|/Span * 100		2.3
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/18/26 03:14	200.0	0.0	1.6		|R-A|/Span * 100		0.8
	High	07/18/26 03:24	200.0	179.0	179.6		|R-A|/Span * 100		0.3
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/18/26 03:14	10.0	0.0	0.1		|R-A|/Span * 100		1.0
	High	07/18/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/18/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/18/26 03:24	200.0	177.9	177.8		|R-A|/Span * 100		0.1
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/18/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/18/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/18/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	07/18/26 03:19	18.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/18/26 03:14	200.0	0.0	0.4		|R-A|/Span * 100		0.2
	High	07/18/26 03:24	200.0	178.7	176.6		|R-A|/Span * 100		1.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/18/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/18/26 03:19	10.0	9.1	9.2		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/18/26 03:14	200.0	0.0	0.2		|R-A|/Span * 100		0.1
	High	07/18/26 03:24	200.0	179.0	178.3		|R-A|/Span * 100		0.4
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/18/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/18/26 03:19	10.0	9.3	9.2		|R-A|/Span * 100		1.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/18/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	07/18/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/19/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	07/19/26 02:24	200.0	177.9	174.2		|R-A|/Span * 100		1.9
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/19/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/19/26 02:19	30.0	20.3	19.8		|R-A|/Span * 100		1.7
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/19/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	07/19/26 02:24	200.0	179.0	176.4		|R-A|/Span * 100		1.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/19/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/19/26 02:19	30.0	20.6	20.0		|R-A|/Span * 100		2.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/19/26 03:14	200.0	0.0	1.6		|R-A|/Span * 100		0.8
	High	07/19/26 03:24	200.0	179.0	179.7		|R-A|/Span * 100		0.4
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/19/26 03:14	10.0	0.0	0.1		|R-A|/Span * 100		1.0
	High	07/19/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/19/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/19/26 03:24	200.0	177.9	177.6		|R-A|/Span * 100		0.2
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/19/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/19/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/19/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	07/19/26 03:19	18.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/19/26 03:14	200.0	0.0	0.4		|R-A|/Span * 100		0.2
	High	07/19/26 03:24	200.0	178.7	176.9		|R-A|/Span * 100		0.9
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/19/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/19/26 03:19	10.0	9.1	9.2		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/19/26 03:14	200.0	0.0	0.1		|R-A|/Span * 100		0.1
	High	07/19/26 03:24	200.0	179.0	178.6		|R-A|/Span * 100		0.2
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/19/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/19/26 03:19	10.0	9.3	9.3		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/19/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	07/19/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/20/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	07/20/26 02:24	200.0	177.9	174.9		|R-A|/Span * 100		1.5
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/20/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/20/26 02:19	30.0	20.3	20.1		|R-A|/Span * 100		0.7
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/20/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	07/20/26 02:24	200.0	179.0	177.7		|R-A|/Span * 100		0.7
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/20/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/20/26 02:19	30.0	20.6	20.3		|R-A|/Span * 100		1.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	07/20/26 03:14	200.0	0.0	1.5		|R-A|/Span * 100		0.8
	High	07/20/26 03:24	200.0	179.0	180.0		|R-A|/Span * 100		0.5
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	07/20/26 03:14	10.0	0.0	0.1		|R-A|/Span * 100		1.0
	High	07/20/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	07/20/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/20/26 03:24	200.0	177.9	178.0		|R-A|/Span * 100		0.1
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	07/20/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/20/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	High	07/20/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	07/20/26 03:19	18.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	07/20/26 03:14	200.0	0.0	0.3		|R-A|/Span * 100		0.2
	High	07/20/26 03:24	200.0	178.7	177.2		|R-A|/Span * 100		0.8
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	07/20/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/20/26 03:19	10.0	9.1	9.2		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	07/20/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/20/26 03:24	200.0	179.0	178.7		|R-A|/Span * 100		0.2
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	07/20/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/20/26 03:19	10.0	9.3	9.3		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	High	07/20/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	07/20/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT5_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	07/20/26 16:10	1,000.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/20/26 16:20	1,000.0	907.4	909.7		|R-A|/Span * 100		0.2
Part 60	**CT5_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	High	07/20/26 16:05	20.0	18.3	18.4		|R-A|/Span * 100		0.5
	Zero	07/20/26 16:10	20.0	0.0	0.0		|R-A|/Span * 100		0.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT5_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/20/26 16:05	500.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/20/26 16:15	500.0	444.4	443.7		|R-A|/Span * 100		0.1
Part 75	**CT5_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/20/26 16:05	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/20/26 16:10	10.0	9.6	9.6		|R-A|/Span * 100		0.0
Part 75	**CT5_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/20/26 16:05	25.0	22.5	22.5		|R-A|		0.0
	Zero	07/20/26 16:10	25.0	0.0	0.0		|R-A|		0.0
Part 60	**CT6_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/20/26 16:11	1,000.0	0.0	0.6		|R-A|/Span * 100		0.1
	High	07/20/26 16:21	1,000.0	905.1	907.7		|R-A|/Span * 100		0.3
Part 60	**CT6_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	High	07/20/26 16:06	20.0	18.3	18.6		|R-A|/Span * 100		1.5
	Zero	07/20/26 16:11	20.0	0.0	0.7		|R-A|/Span * 100		3.5
Part 75	**CT6_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/20/26 16:06	500.0	0.0	-0.2		|R-A|/Span * 100		0.0
	High	07/20/26 16:16	500.0	439.3	438.9		|R-A|/Span * 100		0.1
Part 75	**CT6_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/20/26 16:06	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/20/26 16:11	10.0	9.7	9.9		|R-A|/Span * 100		2.0
Part 75	**CT6_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/20/26 16:06	25.0	22.5	22.4		|R-A|		0.1
	Zero	07/20/26 16:11	25.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/21/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	07/21/26 02:24	200.0	177.9	174.5		|R-A|/Span * 100		1.7
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/21/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/21/26 02:19	30.0	20.3	20.0		|R-A|/Span * 100		1.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/21/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	07/21/26 02:24	200.0	179.0	177.0		|R-A|/Span * 100		1.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/21/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/21/26 02:19	30.0	20.6	20.2		|R-A|/Span * 100		1.3

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	07/21/26 03:14	200.0	0.0	1.6		|R-A|/Span * 100		0.8
	High	07/21/26 03:24	200.0	179.0	180.1		|R-A|/Span * 100		0.6
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	07/21/26 03:14	10.0	0.0	0.1		|R-A|/Span * 100		1.0
	High	07/21/26 03:19	10.0	9.2	9.3		|R-A|/Span * 100		1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	07/21/26 03:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	07/21/26 03:24	200.0	177.9	177.7		|R-A|/Span * 100		0.1
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	07/21/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/21/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	High	07/21/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	07/21/26 03:19	18.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	07/21/26 03:14	200.0	0.0	0.4		|R-A|/Span * 100		0.2
	High	07/21/26 03:24	200.0	178.7	177.2		|R-A|/Span * 100		0.8
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	07/21/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/21/26 03:19	10.0	9.1	9.2		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	07/21/26 03:14	200.0	0.0	0.2		|R-A|/Span * 100		0.1
	High	07/21/26 03:24	200.0	179.0	178.6		|R-A|/Span * 100		0.2
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	07/21/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/21/26 03:19	10.0	9.3	9.2		|R-A|/Span * 100		1.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	High	07/21/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	07/21/26 03:19	21.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT6_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	07/21/26 15:00	1,000.0	0.0	0.6		|R-A|/Span * 100		0.1
	High	07/21/26 15:10	1,000.0	905.1	908.8		|R-A|/Span * 100		0.4
Part 60	**CT6_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	High	07/21/26 14:55	20.0	18.3	18.7		|R-A|/Span * 100		2.0
	Zero	07/21/26 15:00	20.0	0.0	0.7		|R-A|/Span * 100		3.5

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT6_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/21/26 14:55	500.0	0.0	-0.2		|R-A|/Span * 100		0.0
	High	07/21/26 15:05	500.0	439.3	437.8		|R-A|/Span * 100		0.3
Part 75	**CT6_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/21/26 14:55	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/21/26 15:00	10.0	9.7	9.9		|R-A|/Span * 100		2.0
Part 75	**CT6_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/21/26 14:55	25.0	22.5	22.4		|R-A|		0.1
	Zero	07/21/26 15:00	25.0	0.0	0.0		|R-A|		0.0
Part 60	**CT5_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/21/26 17:00	1,000.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/21/26 17:10	1,000.0	907.4	907.2		|R-A|/Span * 100		0.0
Part 60	**CT5_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	High	07/21/26 16:55	20.0	18.3	18.4		|R-A|/Span * 100		0.5
	Zero	07/21/26 17:00	20.0	0.0	0.0		|R-A|/Span * 100		0.0
Part 75	**CT5_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/21/26 16:55	500.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/21/26 17:05	500.0	444.4	445.0		|R-A|/Span * 100		0.1
Part 75	**CT5_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/21/26 16:55	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/21/26 17:00	10.0	9.6	9.6		|R-A|/Span * 100		0.0
Part 75	**CT5_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/21/26 16:55	25.0	22.5	22.5		|R-A|		0.0
	Zero	07/21/26 17:00	25.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/22/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	07/22/26 02:24	200.0	177.9	173.8		|R-A|/Span * 100		2.1
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/22/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/22/26 02:19	30.0	20.3	19.9		|R-A|/Span * 100		1.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/22/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	07/22/26 02:24	200.0	179.0	175.8		|R-A|/Span * 100		1.6
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/22/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/22/26 02:19	30.0	20.6	19.9		|R-A|/Span * 100		2.3

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	07/22/26 03:14	200.0	0.0	1.6		|R-A|/Span * 100		0.8
	High	07/22/26 03:24	200.0	179.0	180.0		|R-A|/Span * 100		0.5
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	07/22/26 03:14	10.0	0.0	0.1		|R-A|/Span * 100		1.0
	High	07/22/26 03:19	10.0	9.2	9.3		|R-A|/Span * 100		1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	07/22/26 03:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	07/22/26 03:24	200.0	177.9	177.4		|R-A|/Span * 100		0.3
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	07/22/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/22/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	High	07/22/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	07/22/26 03:19	18.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	07/22/26 03:14	200.0	0.0	0.4		|R-A|/Span * 100		0.2
	High	07/22/26 03:24	200.0	178.7	176.5		|R-A|/Span * 100		1.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	07/22/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/22/26 03:19	10.0	9.1	9.2		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	07/22/26 03:14	200.0	0.0	-0.2		|R-A|/Span * 100		0.1
	High	07/22/26 03:24	200.0	179.0	178.2		|R-A|/Span * 100		0.4
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	07/22/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/22/26 03:19	10.0	9.3	9.2		|R-A|/Span * 100		1.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	High	07/22/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	07/22/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	07/23/26 02:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/23/26 02:24	200.0	177.9	173.3		|R-A|/Span * 100		2.3
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	07/23/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/23/26 02:19	30.0	20.3	19.7		|R-A|/Span * 100		2.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/23/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	07/23/26 02:24	200.0	179.0	175.3		|R-A|/Span * 100		1.9
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/23/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/23/26 02:19	30.0	20.6	19.8	>1x Alert	|R-A|/Span * 100		2.7
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/23/26 03:14	200.0	0.0	1.7		|R-A|/Span * 100		0.9
	High	07/23/26 03:24	200.0	179.0	180.5		|R-A|/Span * 100		0.8
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/23/26 03:14	10.0	0.0	0.1		|R-A|/Span * 100		1.0
	High	07/23/26 03:19	10.0	9.2	9.3		|R-A|/Span * 100		1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/23/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/23/26 03:24	200.0	177.9	177.3		|R-A|/Span * 100		0.3
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/23/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/23/26 03:19	10.0	9.4	9.3		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/23/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	07/23/26 03:19	18.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/23/26 03:14	200.0	0.0	0.3		|R-A|/Span * 100		0.2
	High	07/23/26 03:24	200.0	178.7	176.8		|R-A|/Span * 100		1.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/23/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/23/26 03:19	10.0	9.1	9.2		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/23/26 03:14	200.0	0.0	0.2		|R-A|/Span * 100		0.1
	High	07/23/26 03:24	200.0	179.0	178.3		|R-A|/Span * 100		0.4
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/23/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/23/26 03:19	10.0	9.3	9.2		|R-A|/Span * 100		1.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/23/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	07/23/26 03:19	21.0	0.0	0.0		|R-A|		0.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/24/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	07/24/26 02:24	200.0	177.9	173.6		|R-A|/Span * 100		2.2
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/24/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/24/26 02:19	30.0	20.7	19.6	>1x Alert	|R-A|/Span * 100		3.7
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/24/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	07/24/26 02:24	200.0	179.0	175.5		|R-A|/Span * 100		1.8
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/24/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/24/26 02:19	30.0	20.6	19.9		|R-A|/Span * 100		2.3
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/24/26 03:14	200.0	0.0	1.7		|R-A|/Span * 100		0.9
	High	07/24/26 03:24	200.0	179.0	180.7		|R-A|/Span * 100		0.9
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/24/26 03:14	10.0	0.0	0.1		|R-A|/Span * 100		1.0
	High	07/24/26 03:19	10.0	9.2	9.3		|R-A|/Span * 100		1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/24/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/24/26 03:24	200.0	177.9	177.9		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/24/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/24/26 03:19	10.0	9.4	9.3		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/24/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	07/24/26 03:19	18.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/24/26 03:14	200.0	0.0	0.4		|R-A|/Span * 100		0.2
	High	07/24/26 03:24	200.0	178.7	178.4		|R-A|/Span * 100		0.2
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/24/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/24/26 03:19	10.0	9.1	9.1		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/24/26 03:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	07/24/26 03:24	200.0	179.0	179.2		|R-A|/Span * 100		0.1

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/24/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/24/26 03:19	10.0	9.3	9.4		|R-A|/Span * 100		1.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/24/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	07/24/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/25/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	07/25/26 02:24	200.0	177.9	173.3		|R-A|/Span * 100		2.3
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/25/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/25/26 02:19	30.0	20.7	19.4	>1x Alert	|R-A|/Span * 100		4.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/25/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	07/25/26 02:24	200.0	179.0	175.0		|R-A|/Span * 100		2.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/25/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/25/26 02:19	30.0	20.6	19.7	>1x Alert	|R-A|/Span * 100		3.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/25/26 03:14	200.0	0.0	1.6		|R-A|/Span * 100		0.8
	High	07/25/26 03:24	200.0	179.0	180.4		|R-A|/Span * 100		0.7
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/25/26 03:14	10.0	0.0	0.1		|R-A|/Span * 100		1.0
	High	07/25/26 03:19	10.0	9.2	9.3		|R-A|/Span * 100		1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/25/26 03:14	200.0	0.0	0.1		|R-A|/Span * 100		0.1
	High	07/25/26 03:24	200.0	177.9	177.7		|R-A|/Span * 100		0.1
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/25/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/25/26 03:19	10.0	9.4	9.3		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/25/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	07/25/26 03:19	18.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/25/26 03:14	200.0	0.0	0.3		|R-A|/Span * 100		0.2
	High	07/25/26 03:24	200.0	178.7	178.8		|R-A|/Span * 100		0.1

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/25/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/25/26 03:19	10.0	9.1	9.1		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/25/26 03:14	200.0	0.0	0.4		|R-A|/Span * 100		0.2
	High	07/25/26 03:24	200.0	179.0	179.7		|R-A|/Span * 100		0.4
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/25/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/25/26 03:19	10.0	9.3	9.3		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/25/26 03:14	21.0	18.0	18.1		|R-A|		0.1
	Zero	07/25/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/26/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	07/26/26 02:24	200.0	177.9	173.4		|R-A|/Span * 100		2.3
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/26/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/26/26 02:19	30.0	20.7	19.7	>1x Alert	|R-A|/Span * 100		3.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/26/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	07/26/26 02:24	200.0	179.0	175.3		|R-A|/Span * 100		1.9
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/26/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/26/26 02:19	30.0	20.6	19.8	>1x Alert	|R-A|/Span * 100		2.7
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/26/26 03:14	200.0	0.0	1.7		|R-A|/Span * 100		0.9
	High	07/26/26 03:24	200.0	179.0	180.3		|R-A|/Span * 100		0.7
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/26/26 03:14	10.0	0.0	0.1		|R-A|/Span * 100		1.0
	High	07/26/26 03:19	10.0	9.2	9.3		|R-A|/Span * 100		1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/26/26 03:14	200.0	0.0	0.1		|R-A|/Span * 100		0.1
	High	07/26/26 03:24	200.0	177.9	177.9		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/26/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/26/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/26/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	07/26/26 03:19	18.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/26/26 03:14	200.0	0.0	0.2		|R-A|/Span * 100		0.1
	High	07/26/26 03:24	200.0	178.7	178.4		|R-A|/Span * 100		0.2
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/26/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/26/26 03:19	10.0	9.1	9.1		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/26/26 03:14	200.0	0.0	-0.2		|R-A|/Span * 100		0.1
	High	07/26/26 03:24	200.0	179.0	179.9		|R-A|/Span * 100		0.5
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/26/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/26/26 03:19	10.0	9.3	9.3		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/26/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	07/26/26 03:19	21.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/27/26 02:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/27/26 02:24	200.0	177.9	173.5		|R-A|/Span * 100		2.2
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/27/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/27/26 02:19	30.0	20.7	19.7	>1x Alert	|R-A|/Span * 100		3.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/27/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	07/27/26 02:24	200.0	179.0	175.5		|R-A|/Span * 100		1.8
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/27/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/27/26 02:19	30.0	20.6	19.9		|R-A|/Span * 100		2.3
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/27/26 03:14	200.0	0.0	1.6		|R-A|/Span * 100		0.8
	High	07/27/26 03:24	200.0	179.0	180.4		|R-A|/Span * 100		0.7
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/27/26 03:14	10.0	0.0	0.1		|R-A|/Span * 100		1.0
	High	07/27/26 03:19	10.0	9.2	9.3		|R-A|/Span * 100		1.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/27/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/27/26 03:24	200.0	177.9	177.8		|R-A|/Span * 100		0.1
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/27/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/27/26 03:19	10.0	9.4	9.3		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/27/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	07/27/26 03:19	18.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/27/26 03:14	200.0	0.0	0.3		|R-A|/Span * 100		0.2
	High	07/27/26 03:24	200.0	178.7	178.3		|R-A|/Span * 100		0.2
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/27/26 03:14	10.0	0.0	-0.1		|R-A|/Span * 100		1.0
	High	07/27/26 03:19	10.0	9.1	9.1		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/27/26 03:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	07/27/26 03:24	200.0	179.0	179.8		|R-A|/Span * 100		0.4
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/27/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/27/26 03:19	10.0	9.3	9.3		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/27/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	07/27/26 03:19	21.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/27/26 08:53	200.0	0.0	-0.3		|R-A|/Span * 100		0.2
	High	07/27/26 09:03	200.0	177.9	179.3		|R-A|/Span * 100		0.7
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/27/26 08:53	30.0	0.0	-0.2		|R-A|/Span * 100		0.7
	High	07/27/26 08:58	30.0	20.7	21.5	>1x Alert	|R-A|/Span * 100		2.7
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/28/26 02:14	200.0	0.0	-0.3		|R-A|/Span * 100		0.2
	High	07/28/26 02:24	200.0	177.9	178.5		|R-A|/Span * 100		0.3
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/28/26 02:14	30.0	0.0	-0.3		|R-A|/Span * 100		1.0
	High	07/28/26 02:19	30.0	20.7	20.6		|R-A|/Span * 100		0.3

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/28/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	07/28/26 02:24	200.0	179.0	174.9		|R-A|/Span * 100		2.1
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/28/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/28/26 02:19	30.0	20.6	19.7	>1x Alert	|R-A|/Span * 100		3.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/28/26 03:14	200.0	0.0	0.9		|R-A|/Span * 100		0.5
	High	07/28/26 03:24	200.0	179.0	180.5		|R-A|/Span * 100		0.8
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/28/26 03:14	10.0	0.0	-0.4		|R-A|/Span * 100		4.0
	High	07/28/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/28/26 03:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	07/28/26 03:24	200.0	177.9	178.6		|R-A|/Span * 100		0.4
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/28/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/28/26 03:19	10.0	9.4	9.5		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/28/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	07/28/26 03:19	18.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/28/26 03:14	200.0	0.0	0.3		|R-A|/Span * 100		0.2
	High	07/28/26 03:24	200.0	178.7	178.5		|R-A|/Span * 100		0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/28/26 03:14	10.0	0.0	-0.1		|R-A|/Span * 100		1.0
	High	07/28/26 03:19	10.0	9.1	9.1		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/28/26 03:14	200.0	0.0	0.2		|R-A|/Span * 100		0.1
	High	07/28/26 03:24	200.0	179.0	179.6		|R-A|/Span * 100		0.3
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/28/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/28/26 03:19	10.0	9.3	9.4		|R-A|/Span * 100		1.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/28/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	07/28/26 03:19	21.0	0.0	0.0		|R-A|		0.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/29/26 02:14	200.0	0.0	-0.3		|R-A|/Span * 100		0.2
	High	07/29/26 02:24	200.0	177.9	179.0		|R-A|/Span * 100		0.6
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/29/26 02:14	30.0	0.0	-0.3		|R-A|/Span * 100		1.0
	High	07/29/26 02:19	30.0	20.7	20.9		|R-A|/Span * 100		0.7
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/29/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	07/29/26 02:24	200.0	179.8	179.0		|R-A|/Span * 100		0.4
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/29/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	07/29/26 02:19	30.0	20.6	20.8		|R-A|/Span * 100		0.7
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/29/26 03:14	200.0	0.0	0.9		|R-A|/Span * 100		0.5
	High	07/29/26 03:24	200.0	179.0	180.6		|R-A|/Span * 100		0.8
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/29/26 03:14	10.0	0.0	-0.4		|R-A|/Span * 100		4.0
	High	07/29/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/29/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/29/26 03:24	200.0	177.9	177.9		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/29/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/29/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/29/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	07/29/26 03:19	18.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/29/26 03:14	200.0	0.0	0.3		|R-A|/Span * 100		0.2
	High	07/29/26 03:24	200.0	180.9	177.5		|R-A|/Span * 100		1.7
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/29/26 03:14	10.0	0.0	-0.1		|R-A|/Span * 100		1.0
	High	07/29/26 03:19	10.0	9.1	9.1		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/29/26 03:14	200.0	0.0	0.5		|R-A|/Span * 100		0.3
	High	07/29/26 03:24	200.0	179.8	179.7		|R-A|/Span * 100		0.1

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/29/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/29/26 03:19	10.0	9.3	9.3		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/29/26 03:14	21.0	18.0	18.1		|R-A|		0.1
	Zero	07/29/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/30/26 02:14	200.0	0.0	-0.3		|R-A|/Span * 100		0.2
	High	07/30/26 02:24	200.0	177.9	179.6		|R-A|/Span * 100		0.9
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/30/26 02:14	30.0	0.0	-0.3		|R-A|/Span * 100		1.0
	High	07/30/26 02:19	30.0	20.7	21.1		|R-A|/Span * 100		1.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/30/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	07/30/26 02:24	200.0	179.8	180.3		|R-A|/Span * 100		0.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/30/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	07/30/26 02:19	30.0	20.6	20.9		|R-A|/Span * 100		1.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/30/26 03:14	200.0	0.0	1.0		|R-A|/Span * 100		0.5
	High	07/30/26 03:24	200.0	179.0	180.3		|R-A|/Span * 100		0.7
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/30/26 03:14	10.0	0.0	-0.4		|R-A|/Span * 100		4.0
	High	07/30/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/30/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/30/26 03:24	200.0	177.9	178.0		|R-A|/Span * 100		0.1
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/30/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/30/26 03:19	10.0	9.4	9.5		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/30/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	07/30/26 03:19	18.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/30/26 03:14	200.0	0.0	0.4		|R-A|/Span * 100		0.2
	High	07/30/26 03:24	200.0	180.9	177.5		|R-A|/Span * 100		1.7

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/30/26 03:14	10.0	0.0	-0.1		|R-A|/Span * 100		1.0
	High	07/30/26 03:19	10.0	9.1	9.1		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/30/26 03:14	200.0	0.0	0.3		|R-A|/Span * 100		0.2
	High	07/30/26 03:24	200.0	179.8	180.5		|R-A|/Span * 100		0.4
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/30/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/30/26 03:19	10.0	9.3	9.3		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/30/26 03:14	21.0	18.0	18.1		|R-A|		0.1
	Zero	07/30/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/31/26 02:14	200.0	0.0	-0.3		|R-A|/Span * 100		0.2
	High	07/31/26 02:24	200.0	177.9	179.9		|R-A|/Span * 100		1.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/31/26 02:14	30.0	0.0	-0.3		|R-A|/Span * 100		1.0
	High	07/31/26 02:19	30.0	20.7	21.1		|R-A|/Span * 100		1.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/31/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	07/31/26 02:24	200.0	179.8	181.4		|R-A|/Span * 100		0.8
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/31/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	07/31/26 02:19	30.0	20.6	21.0		|R-A|/Span * 100		1.3
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/31/26 03:14	200.0	0.0	0.9		|R-A|/Span * 100		0.5
	High	07/31/26 03:24	200.0	179.0	180.0		|R-A|/Span * 100		0.5
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/31/26 03:14	10.0	0.0	-0.4		|R-A|/Span * 100		4.0
	High	07/31/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/31/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/31/26 03:24	200.0	177.9	177.8		|R-A|/Span * 100		0.1
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/31/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/31/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/31/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	07/31/26 03:19	18.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/31/26 03:14	200.0	0.0	0.4		|R-A|/Span * 100		0.2
	High	07/31/26 03:24	200.0	180.9	177.8		|R-A|/Span * 100		1.6
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/31/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/31/26 03:19	10.0	9.1	9.1		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	07/31/26 03:14	200.0	0.0	-0.3		|R-A|/Span * 100		0.2
	High	07/31/26 03:24	200.0	179.8	179.9		|R-A|/Span * 100		0.1
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	07/31/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	07/31/26 03:19	10.0	9.3	9.4		|R-A|/Span * 100		1.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	07/31/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	07/31/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/01/26 02:14	200.0	0.0	-0.3		|R-A|/Span * 100		0.2
	High	08/01/26 02:24	200.0	177.9	179.2		|R-A|/Span * 100		0.7
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/01/26 02:14	30.0	0.0	-0.3		|R-A|/Span * 100		1.0
	High	08/01/26 02:19	30.0	20.7	21.0		|R-A|/Span * 100		1.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/01/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	08/01/26 02:24	200.0	179.8	180.4		|R-A|/Span * 100		0.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/01/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	08/01/26 02:19	30.0	20.6	20.9		|R-A|/Span * 100		1.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/01/26 03:14	200.0	0.0	0.5		|R-A|/Span * 100		0.3
	High	08/01/26 03:24	200.0	180.9	177.9		|R-A|/Span * 100		1.5
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/01/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/01/26 03:19	10.0	9.1	9.1		|R-A|/Span * 100		0.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/01/26 03:14	200.0	0.0	0.1		|R-A|/Span * 100		0.1
	High	08/01/26 03:24	200.0	179.8	179.4		|R-A|/Span * 100		0.2
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/01/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/01/26 03:19	10.0	9.3	9.3		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/01/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	08/01/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/01/26 03:14	200.0	0.0	1.0		|R-A|/Span * 100		0.5
	High	08/01/26 03:25	200.0	179.0	179.4		|R-A|/Span * 100		0.2
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/01/26 03:14	10.0	0.0	-0.4		|R-A|/Span * 100		4.0
	High	08/01/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/01/26 03:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	08/01/26 03:25	200.0	177.9	178.6		|R-A|/Span * 100		0.4
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/01/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/01/26 03:19	10.0	9.2	9.4		|R-A|/Span * 100		2.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/01/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	08/01/26 03:19	18.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/02/26 02:14	200.0	0.0	-0.3		|R-A|/Span * 100		0.2
	High	08/02/26 02:24	200.0	177.9	179.6		|R-A|/Span * 100		0.9
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/02/26 02:14	30.0	0.0	-0.3		|R-A|/Span * 100		1.0
	High	08/02/26 02:19	30.0	20.7	21.0		|R-A|/Span * 100		1.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/02/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	08/02/26 02:24	200.0	179.8	180.7		|R-A|/Span * 100		0.5
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/02/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	08/02/26 02:19	30.0	20.6	20.9		|R-A|/Span * 100		1.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/02/26 03:14	200.0	0.0	0.9		|R-A|/Span * 100		0.5
	High	08/02/26 03:24	200.0	179.0	179.9		|R-A|/Span * 100		0.5
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/02/26 03:14	10.0	0.0	-0.4		|R-A|/Span * 100		4.0
	High	08/02/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/02/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/02/26 03:24	200.0	177.9	177.9		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/02/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/02/26 03:19	10.0	9.2	9.6	>1x Alert	|R-A|/Span * 100		4.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/02/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	08/02/26 03:19	18.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/02/26 03:14	200.0	0.0	0.4		|R-A|/Span * 100		0.2
	High	08/02/26 03:24	200.0	180.9	178.3		|R-A|/Span * 100		1.3
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/02/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/02/26 03:19	10.0	9.1	9.1		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/02/26 03:14	200.0	0.0	0.2		|R-A|/Span * 100		0.1
	High	08/02/26 03:24	200.0	179.8	179.7		|R-A|/Span * 100		0.1
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/02/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/02/26 03:19	10.0	9.3	9.3		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/02/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	08/02/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/03/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	08/03/26 02:24	200.0	177.9	179.9		|R-A|/Span * 100		1.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/03/26 02:14	30.0	0.0	-0.3		|R-A|/Span * 100		1.0
	High	08/03/26 02:19	30.0	20.7	21.0		|R-A|/Span * 100		1.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/03/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	08/03/26 02:24	200.0	179.8	180.8		|R-A|/Span * 100		0.5
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/03/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	08/03/26 02:19	30.0	20.6	20.9		|R-A|/Span * 100		1.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/03/26 03:14	200.0	0.0	1.0		|R-A|/Span * 100		0.5
	High	08/03/26 03:24	200.0	179.0	180.3		|R-A|/Span * 100		0.7
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/03/26 03:14	10.0	0.0	-0.4		|R-A|/Span * 100		4.0
	High	08/03/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/03/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/03/26 03:24	200.0	177.9	178.1		|R-A|/Span * 100		0.1
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/03/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/03/26 03:19	10.0	9.2	9.6	>1x Alert	|R-A|/Span * 100		4.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/03/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	08/03/26 03:19	18.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/03/26 03:14	200.0	0.0	0.3		|R-A|/Span * 100		0.2
	High	08/03/26 03:24	200.0	180.9	178.2		|R-A|/Span * 100		1.4
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/03/26 03:14	10.0	0.0	-0.1		|R-A|/Span * 100		1.0
	High	08/03/26 03:19	10.0	9.1	9.1		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/03/26 03:14	200.0	0.0	0.3		|R-A|/Span * 100		0.2
	High	08/03/26 03:24	200.0	179.8	179.6		|R-A|/Span * 100		0.1
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/03/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/03/26 03:19	10.0	9.3	9.3		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/03/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	08/03/26 03:19	21.0	0.0	0.0		|R-A|		0.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT6_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	08/03/26 16:12	1,000.0	0.0	0.5		|R-A|/Span * 100		0.1
	High	08/03/26 16:22	1,000.0	905.1	923.7		|R-A|/Span * 100		1.9
Part 60	**CT6_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	High	08/03/26 16:07	20.0	18.6	19.3		|R-A|/Span * 100		3.5
	Zero	08/03/26 16:12	20.0	0.0	0.6		|R-A|/Span * 100		3.0
Part 75	**CT6_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	08/03/26 16:07	500.0	0.0	-0.2		|R-A|/Span * 100		0.0
	High	08/03/26 16:17	500.0	439.3	438.2		|R-A|/Span * 100		0.2
Part 75	**CT6_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	08/03/26 16:07	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/03/26 16:12	10.0	9.5	9.7		|R-A|/Span * 100		2.0
Part 75	**CT6_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	High	08/03/26 16:07	25.0	22.5	22.5		|R-A|		0.0
	Zero	08/03/26 16:12	25.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	08/04/26 02:14	200.0	0.0	-0.3		|R-A|/Span * 100		0.2
	High	08/04/26 02:24	200.0	177.9	179.5		|R-A|/Span * 100		0.8
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	08/04/26 02:14	30.0	0.0	-0.3		|R-A|/Span * 100		1.0
	High	08/04/26 02:19	30.0	20.7	21.1		|R-A|/Span * 100		1.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	08/04/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	08/04/26 02:24	200.0	179.8	180.8		|R-A|/Span * 100		0.5
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	08/04/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	08/04/26 02:19	30.0	20.6	20.9		|R-A|/Span * 100		1.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	08/04/26 03:14	200.0	0.0	0.9		|R-A|/Span * 100		0.5
	High	08/04/26 03:24	200.0	179.0	180.3		|R-A|/Span * 100		0.7
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	08/04/26 03:14	10.0	0.0	-0.4		|R-A|/Span * 100		4.0
	High	08/04/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	08/04/26 03:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	08/04/26 03:24	200.0	177.9	177.9		|R-A|/Span * 100		0.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/04/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/04/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/04/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	08/04/26 03:19	18.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/04/26 03:14	200.0	0.0	0.5		|R-A|/Span * 100		0.3
	High	08/04/26 03:24	200.0	180.9	178.6		|R-A|/Span * 100		1.2
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/04/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/04/26 03:19	10.0	9.1	9.1		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/04/26 03:14	200.0	0.0	0.1		|R-A|/Span * 100		0.1
	High	08/04/26 03:24	200.0	179.8	179.9		|R-A|/Span * 100		0.1
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/04/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/04/26 03:19	10.0	9.3	9.3		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/04/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	08/04/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT6_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/04/26 16:22	1,000.0	0.0	0.6		|R-A|/Span * 100		0.1
	High	08/04/26 16:32	1,000.0	905.1	921.7		|R-A|/Span * 100		1.7
Part 60	**CT6_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	High	08/04/26 16:17	20.0	18.6	19.2		|R-A|/Span * 100		3.0
	Zero	08/04/26 16:22	20.0	0.0	0.6		|R-A|/Span * 100		3.0
Part 75	**CT6_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/04/26 16:17	500.0	0.0	-0.2		|R-A|/Span * 100		0.0
	High	08/04/26 16:27	500.0	439.3	436.9		|R-A|/Span * 100		0.5
Part 75	**CT6_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/04/26 16:17	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/04/26 16:22	10.0	9.5	9.7		|R-A|/Span * 100		2.0
Part 75	**CT6_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/04/26 16:17	25.0	22.5	22.5		|R-A|		0.0
	Zero	08/04/26 16:22	25.0	0.0	0.0		|R-A|		0.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/05/26 02:14	200.0	0.0	-0.3		|R-A|/Span * 100		0.2
	High	08/05/26 02:24	200.0	177.9	179.8		|R-A|/Span * 100		1.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/05/26 02:14	30.0	0.0	-0.3		|R-A|/Span * 100		1.0
	High	08/05/26 02:19	30.0	20.7	21.0		|R-A|/Span * 100		1.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/05/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	08/05/26 02:24	200.0	179.8	180.4		|R-A|/Span * 100		0.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/05/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	08/05/26 02:19	30.0	20.6	20.9		|R-A|/Span * 100		1.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/05/26 03:14	200.0	0.0	1.0		|R-A|/Span * 100		0.5
	High	08/05/26 03:24	200.0	179.0	180.3		|R-A|/Span * 100		0.7
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/05/26 03:14	10.0	0.0	-0.4		|R-A|/Span * 100		4.0
	High	08/05/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/05/26 03:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	08/05/26 03:24	200.0	177.9	177.8		|R-A|/Span * 100		0.1
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/05/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/05/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/05/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	08/05/26 03:19	18.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/05/26 03:14	200.0	0.0	0.5		|R-A|/Span * 100		0.3
	High	08/05/26 03:24	200.0	180.9	178.3		|R-A|/Span * 100		1.3
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/05/26 03:14	10.0	0.0	-0.1		|R-A|/Span * 100		1.0
	High	08/05/26 03:19	10.0	9.1	9.1		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/05/26 03:14	200.0	0.0	0.4		|R-A|/Span * 100		0.2
	High	08/05/26 03:24	200.0	179.8	179.7		|R-A|/Span * 100		0.1

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/05/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/05/26 03:19	10.0	9.3	9.3		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/05/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	08/05/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT6_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/05/26 15:12	1,000.0	0.0	0.6		|R-A|/Span * 100		0.1
	High	08/05/26 15:22	1,000.0	905.1	922.7		|R-A|/Span * 100		1.8
Part 60	**CT6_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	High	08/05/26 15:07	20.0	18.6	19.5		|R-A|/Span * 100		4.5
	Zero	08/05/26 15:12	20.0	0.0	0.7		|R-A|/Span * 100		3.5
Part 75	**CT6_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/05/26 15:07	500.0	0.0	-0.2		|R-A|/Span * 100		0.0
	High	08/05/26 15:17	500.0	439.3	436.0		|R-A|/Span * 100		0.7
Part 75	**CT6_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/05/26 15:07	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/05/26 15:12	10.0	9.5	9.7		|R-A|/Span * 100		2.0
Part 75	**CT6_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/05/26 15:07	25.0	22.5	22.5		|R-A|		0.0
	Zero	08/05/26 15:12	25.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/06/26 02:14	200.0	0.0	-0.3		|R-A|/Span * 100		0.2
	High	08/06/26 02:24	200.0	177.9	179.7		|R-A|/Span * 100		0.9
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/06/26 02:14	30.0	0.0	-0.3		|R-A|/Span * 100		1.0
	High	08/06/26 02:19	30.0	20.7	21.1		|R-A|/Span * 100		1.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/06/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	08/06/26 02:24	200.0	179.8	180.6		|R-A|/Span * 100		0.4
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/06/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/06/26 02:19	30.0	20.6	20.9		|R-A|/Span * 100		1.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/06/26 03:14	200.0	0.0	1.2		|R-A|/Span * 100		0.6
	High	08/06/26 03:24	200.0	179.0	180.4		|R-A|/Span * 100		0.7

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/06/26 03:14	10.0	0.0	-0.3		|R-A|/Span * 100		3.0
	High	08/06/26 03:19	10.0	9.2	9.3		|R-A|/Span * 100		1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/06/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/06/26 03:24	200.0	177.9	178.0		|R-A|/Span * 100		0.1
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/06/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/06/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/06/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	08/06/26 03:19	18.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/06/26 03:14	200.0	0.0	0.4		|R-A|/Span * 100		0.2
	High	08/06/26 03:24	200.0	180.9	178.2		|R-A|/Span * 100		1.4
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/06/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/06/26 03:19	10.0	9.1	9.1		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/06/26 03:14	200.0	0.0	0.5		|R-A|/Span * 100		0.3
	High	08/06/26 03:24	200.0	179.8	179.4		|R-A|/Span * 100		0.2
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/06/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/06/26 03:19	10.0	9.3	9.3		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/06/26 03:14	21.0	18.0	18.1		|R-A|		0.1
	Zero	08/06/26 03:19	21.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT6_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/06/26 16:12	1,000.0	0.0	0.6		|R-A|/Span * 100		0.1
	High	08/06/26 16:22	1,000.0	905.1	925.3		|R-A|/Span * 100		2.0
Part 60	**CT6_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	High	08/06/26 16:07	20.0	18.6	19.7	>1x Alert	|R-A|/Span * 100		5.5
	Zero	08/06/26 16:12	20.0	0.0	0.7		|R-A|/Span * 100		3.5
Part 75	**CT6_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/06/26 16:07	500.0	0.0	-0.2		|R-A|/Span * 100		0.0
	High	08/06/26 16:17	500.0	439.3	437.8		|R-A|/Span * 100		0.3

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT6_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/06/26 16:07	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/06/26 16:12	10.0	9.5	9.8	>1x Alert	|R-A|/Span * 100		3.0
Part 75	**CT6_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/06/26 16:07	25.0	22.5	22.5		|R-A|		0.0
	Zero	08/06/26 16:12	25.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/07/26 02:14	200.0	0.0	-0.3		|R-A|/Span * 100		0.2
	High	08/07/26 02:24	200.0	177.9	179.3		|R-A|/Span * 100		0.7
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/07/26 02:14	30.0	0.0	-0.3		|R-A|/Span * 100		1.0
	High	08/07/26 02:19	30.0	20.7	20.9		|R-A|/Span * 100		0.7
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/07/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	08/07/26 02:24	200.0	179.8	179.0		|R-A|/Span * 100		0.4
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/07/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	08/07/26 02:19	30.0	20.6	20.7		|R-A|/Span * 100		0.3
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/07/26 03:14	200.0	0.0	1.3		|R-A|/Span * 100		0.7
	High	08/07/26 03:24	200.0	179.0	180.7		|R-A|/Span * 100		0.9
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/07/26 03:14	10.0	0.0	-0.3		|R-A|/Span * 100		3.0
	High	08/07/26 03:19	10.0	9.2	9.3		|R-A|/Span * 100		1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/07/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/07/26 03:24	200.0	177.9	177.9		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/07/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/07/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/07/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	08/07/26 03:19	18.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/07/26 03:14	200.0	0.0	0.3		|R-A|/Span * 100		0.2
	High	08/07/26 03:24	200.0	180.9	177.8		|R-A|/Span * 100		1.6

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/07/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/07/26 03:19	10.0	9.1	9.1		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/07/26 03:14	200.0	0.0	0.3		|R-A|/Span * 100		0.2
	High	08/07/26 03:24	200.0	179.8	180.0		|R-A|/Span * 100		0.1
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/07/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/07/26 03:19	10.0	9.3	9.4		|R-A|/Span * 100		1.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/07/26 03:14	21.0	18.0	18.1		|R-A|		0.1
	Zero	08/07/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT5_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/07/26 13:10	1,000.0	0.0	-0.1		|R-A|/Span * 100		0.0
	High	08/07/26 13:20	1,000.0	907.4	907.9		|R-A|/Span * 100		0.1
Part 60	**CT5_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	High	08/07/26 13:05	20.0	18.3	18.3		|R-A|/Span * 100		0.0
	Zero	08/07/26 13:10	20.0	0.0	-0.1		|R-A|/Span * 100		0.5
Part 75	**CT5_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/07/26 13:05	500.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/07/26 13:15	500.0	444.4	441.5		|R-A|/Span * 100		0.6
Part 75	**CT5_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/07/26 13:05	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/07/26 13:10	10.0	9.6	9.6		|R-A|/Span * 100		0.0
Part 75	**CT5_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/07/26 13:05	25.0	22.5	22.5		|R-A|		0.0
	Zero	08/07/26 13:10	25.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/08/26 02:14	200.0	0.0	-0.3		|R-A|/Span * 100		0.2
	High	08/08/26 02:24	200.0	177.9	179.2		|R-A|/Span * 100		0.7
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/08/26 02:14	30.0	0.0	-0.3		|R-A|/Span * 100		1.0
	High	08/08/26 02:19	30.0	20.7	20.9		|R-A|/Span * 100		0.7
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/08/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	08/08/26 02:24	200.0	179.8	179.3		|R-A|/Span * 100		0.3

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/08/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	08/08/26 02:19	30.0	20.6	20.7		|R-A|/Span * 100		0.3
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/08/26 03:14	200.0	0.0	1.3		|R-A|/Span * 100		0.7
	High	08/08/26 03:24	200.0	179.0	180.7		|R-A|/Span * 100		0.9
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/08/26 03:14	10.0	0.0	-0.3		|R-A|/Span * 100		3.0
	High	08/08/26 03:19	10.0	9.2	9.3		|R-A|/Span * 100		1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/08/26 03:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	08/08/26 03:24	200.0	177.9	177.8		|R-A|/Span * 100		0.1
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/08/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/08/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/08/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	08/08/26 03:19	18.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/08/26 03:14	200.0	0.0	0.3		|R-A|/Span * 100		0.2
	High	08/08/26 03:24	200.0	180.9	177.4		|R-A|/Span * 100		1.8
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/08/26 03:14	10.0	0.0	-0.1		|R-A|/Span * 100		1.0
	High	08/08/26 03:19	10.0	9.1	9.1		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/08/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/08/26 03:24	200.0	179.8	180.0		|R-A|/Span * 100		0.1
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/08/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/08/26 03:19	10.0	9.3	9.4		|R-A|/Span * 100		1.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/08/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	08/08/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/09/26 02:14	200.0	0.0	-0.3		|R-A|/Span * 100		0.2
	High	08/09/26 02:24	200.0	177.9	179.4		|R-A|/Span * 100		0.8

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/09/26 02:14	30.0	0.0	-0.3		|R-A|/Span * 100		1.0
	High	08/09/26 02:19	30.0	20.7	21.0		|R-A|/Span * 100		1.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/09/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	08/09/26 02:24	200.0	179.8	179.9		|R-A|/Span * 100		0.1
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/09/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	08/09/26 02:19	30.0	20.6	20.8		|R-A|/Span * 100		0.7
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/09/26 03:14	200.0	0.0	1.3		|R-A|/Span * 100		0.7
	High	08/09/26 03:24	200.0	179.0	181.0		|R-A|/Span * 100		1.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/09/26 03:14	10.0	0.0	-0.3		|R-A|/Span * 100		3.0
	High	08/09/26 03:19	10.0	9.2	9.3		|R-A|/Span * 100		1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/09/26 03:14	200.0	0.0	0.1		|R-A|/Span * 100		0.1
	High	08/09/26 03:24	200.0	177.9	177.6		|R-A|/Span * 100		0.2
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/09/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/09/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/09/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	08/09/26 03:19	18.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/09/26 03:14	200.0	0.0	0.3		|R-A|/Span * 100		0.2
	High	08/09/26 03:24	200.0	180.9	177.7		|R-A|/Span * 100		1.6
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/09/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/09/26 03:19	10.0	9.1	9.1		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/09/26 03:14	200.0	0.0	0.3		|R-A|/Span * 100		0.2
	High	08/09/26 03:24	200.0	179.8	180.3		|R-A|/Span * 100		0.3
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/09/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/09/26 03:19	10.0	9.3	9.4		|R-A|/Span * 100		1.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/09/26 03:14	21.0	18.0	18.1		|R-A|		0.1
	Zero	08/09/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/10/26 02:14	200.0	0.0	-0.3		|R-A|/Span * 100		0.2
	High	08/10/26 02:24	200.0	177.9	179.9		|R-A|/Span * 100		1.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/10/26 02:14	30.0	0.0	-0.3		|R-A|/Span * 100		1.0
	High	08/10/26 02:19	30.0	20.7	21.0		|R-A|/Span * 100		1.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/10/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	08/10/26 02:24	200.0	179.8	180.3		|R-A|/Span * 100		0.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/10/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	08/10/26 02:19	30.0	20.6	20.8		|R-A|/Span * 100		0.7
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/10/26 03:14	200.0	0.0	1.2		|R-A|/Span * 100		0.6
	High	08/10/26 03:24	200.0	179.0	181.1		|R-A|/Span * 100		1.1
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/10/26 03:14	10.0	0.0	-0.3		|R-A|/Span * 100		3.0
	High	08/10/26 03:19	10.0	9.2	9.3		|R-A|/Span * 100		1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/10/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/10/26 03:24	200.0	177.9	178.0		|R-A|/Span * 100		0.1
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/10/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/10/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/10/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	08/10/26 03:19	18.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/10/26 03:14	200.0	0.0	0.3		|R-A|/Span * 100		0.2
	High	08/10/26 03:24	200.0	180.9	178.1		|R-A|/Span * 100		1.4
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/10/26 03:14	10.0	0.0	-0.1		|R-A|/Span * 100		1.0
	High	08/10/26 03:19	10.0	9.1	9.1		|R-A|/Span * 100		0.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/10/26 03:14	200.0	0.0	0.2		|R-A|/Span * 100		0.1
	High	08/10/26 03:24	200.0	179.8	180.7		|R-A|/Span * 100		0.5
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/10/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/10/26 03:19	10.0	9.3	9.3		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/10/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	08/10/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/11/26 02:14	200.0	0.0	-0.3		|R-A|/Span * 100		0.2
	High	08/11/26 02:24	200.0	177.9	179.5		|R-A|/Span * 100		0.8
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/11/26 02:14	30.0	0.0	-0.3		|R-A|/Span * 100		1.0
	High	08/11/26 02:19	30.0	20.7	20.9		|R-A|/Span * 100		0.7
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/11/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	08/11/26 02:24	200.0	179.8	179.3		|R-A|/Span * 100		0.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/11/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	08/11/26 02:19	30.0	20.6	20.7		|R-A|/Span * 100		0.3
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/11/26 03:14	200.0	0.0	1.3		|R-A|/Span * 100		0.7
	High	08/11/26 03:24	200.0	179.0	180.6		|R-A|/Span * 100		0.8
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/11/26 03:14	10.0	0.0	-0.3		|R-A|/Span * 100		3.0
	High	08/11/26 03:19	10.0	9.2	9.3		|R-A|/Span * 100		1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/11/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/11/26 03:24	200.0	177.9	177.8		|R-A|/Span * 100		0.1
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/11/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/11/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/11/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	08/11/26 03:19	18.0	0.0	0.0		|R-A|		0.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	08/11/26 03:14	200.0	0.0	0.4		|R-A|/Span * 100		0.2
	High	08/11/26 03:24	200.0	180.9	177.5		|R-A|/Span * 100		1.7
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	08/11/26 03:14	10.0	0.0	-0.1		|R-A|/Span * 100		1.0
	High	08/11/26 03:19	10.0	9.1	9.1		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	08/11/26 03:14	200.0	0.0	0.3		|R-A|/Span * 100		0.2
	High	08/11/26 03:24	200.0	179.8	180.6		|R-A|/Span * 100		0.4
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	08/11/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/11/26 03:19	10.0	9.3	9.3		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	High	08/11/26 03:14	21.0	18.0	18.1		|R-A|		0.1
	Zero	08/11/26 03:19	21.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	08/12/26 02:14	200.0	0.0	-0.3		|R-A|/Span * 100		0.2
	High	08/12/26 02:24	200.0	177.9	179.5		|R-A|/Span * 100		0.8
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	08/12/26 02:14	30.0	0.0	-0.3		|R-A|/Span * 100		1.0
	High	08/12/26 02:19	30.0	20.7	20.9		|R-A|/Span * 100		0.7
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	08/12/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	08/12/26 02:24	200.0	179.8	179.5		|R-A|/Span * 100		0.2
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	08/12/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	08/12/26 02:19	30.0	20.6	20.7		|R-A|/Span * 100		0.3
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	08/12/26 03:14	200.0	0.0	1.3		|R-A|/Span * 100		0.7
	High	08/12/26 03:24	200.0	179.0	180.8		|R-A|/Span * 100		0.9
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	08/12/26 03:14	10.0	0.0	-0.3		|R-A|/Span * 100		3.0
	High	08/12/26 03:19	10.0	9.2	9.3		|R-A|/Span * 100		1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	08/12/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/12/26 03:24	200.0	177.9	177.8		|R-A|/Span * 100		0.1

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/12/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/12/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/12/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	08/12/26 03:19	18.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/12/26 03:14	200.0	0.0	0.4		|R-A|/Span * 100		0.2
	High	08/12/26 03:24	200.0	180.9	177.9		|R-A|/Span * 100		1.5
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/12/26 03:14	10.0	0.0	-0.1		|R-A|/Span * 100		1.0
	High	08/12/26 03:19	10.0	9.1	9.1		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/12/26 03:14	200.0	0.0	0.1		|R-A|/Span * 100		0.1
	High	08/12/26 03:24	200.0	179.8	180.5		|R-A|/Span * 100		0.4
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/12/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/12/26 03:19	10.0	9.3	9.3		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/12/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	08/12/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/13/26 02:14	200.0	0.0	-0.3		|R-A|/Span * 100		0.2
	High	08/13/26 02:24	200.0	177.9	179.8		|R-A|/Span * 100		1.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/13/26 02:14	30.0	0.0	-0.3		|R-A|/Span * 100		1.0
	High	08/13/26 02:19	30.0	20.7	21.0		|R-A|/Span * 100		1.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/13/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	08/13/26 02:24	200.0	179.8	179.1		|R-A|/Span * 100		0.4
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/13/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	08/13/26 02:19	30.0	20.6	20.7		|R-A|/Span * 100		0.3
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/13/26 03:14	200.0	0.0	1.2		|R-A|/Span * 100		0.6
	High	08/13/26 03:24	200.0	179.0	180.7		|R-A|/Span * 100		0.9

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/13/26 03:14	10.0	0.0	-0.3		|R-A|/Span * 100		3.0
	High	08/13/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/13/26 03:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	08/13/26 03:24	200.0	177.9	177.5		|R-A|/Span * 100		0.2
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/13/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/13/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/13/26 03:14	18.0	18.0	18.1		|R-A|		0.1
	Zero	08/13/26 03:19	18.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/13/26 03:14	200.0	0.0	0.3		|R-A|/Span * 100		0.2
	High	08/13/26 03:24	200.0	180.9	177.8		|R-A|/Span * 100		1.6
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/13/26 03:14	10.0	0.0	-0.1		|R-A|/Span * 100		1.0
	High	08/13/26 03:19	10.0	9.1	9.1		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/13/26 03:14	200.0	0.0	0.5		|R-A|/Span * 100		0.3
	High	08/13/26 03:24	200.0	179.8	180.6		|R-A|/Span * 100		0.4
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/13/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/13/26 03:19	10.0	9.3	9.4		|R-A|/Span * 100		1.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/13/26 03:14	21.0	18.0	18.1		|R-A|		0.1
	Zero	08/13/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/14/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	08/14/26 02:24	200.0	177.9	177.1		|R-A|/Span * 100		0.4
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/14/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/14/26 02:19	30.0	20.7	20.6		|R-A|/Span * 100		0.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/14/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	08/14/26 02:24	200.0	179.8	179.9		|R-A|/Span * 100		0.1

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/14/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	08/14/26 02:19	30.0	20.6	20.4		|R-A|/Span * 100		0.7
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/14/26 03:14	200.0	0.0	1.3		|R-A|/Span * 100		0.7
	High	08/14/26 03:24	200.0	179.0	179.5		|R-A|/Span * 100		0.3
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/14/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/14/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/14/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/14/26 03:24	200.0	177.9	177.7		|R-A|/Span * 100		0.1
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/14/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/14/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/14/26 03:14	18.0	18.0	18.1		|R-A|		0.1
	Zero	08/14/26 03:19	18.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/14/26 03:14	200.0	0.0	0.4		|R-A|/Span * 100		0.2
	High	08/14/26 03:24	200.0	180.9	181.3		|R-A|/Span * 100		0.2
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/14/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/14/26 03:19	10.0	9.1	9.2		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/14/26 03:14	200.0	0.0	0.3		|R-A|/Span * 100		0.2
	High	08/14/26 03:24	200.0	179.8	179.7		|R-A|/Span * 100		0.1
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/14/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/14/26 03:19	10.0	9.3	9.3		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/14/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	08/14/26 03:19	21.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/15/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	08/15/26 02:24	200.0	177.9	177.7		|R-A|/Span * 100		0.1

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/15/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/15/26 02:19	30.0	20.7	20.8		|R-A|/Span * 100		0.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/15/26 02:14	200.0	0.0	-0.5		|R-A|/Span * 100		0.3
	High	08/15/26 02:24	200.0	179.8	179.8		|R-A|/Span * 100		0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/15/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	08/15/26 02:19	30.0	20.6	20.4		|R-A|/Span * 100		0.7
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/15/26 03:14	200.0	0.0	1.5		|R-A|/Span * 100		0.8
	High	08/15/26 03:24	200.0	179.0	179.9		|R-A|/Span * 100		0.5
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/15/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/15/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/15/26 03:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	08/15/26 03:24	200.0	177.9	177.9		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/15/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/15/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/15/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	08/15/26 03:19	18.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/15/26 03:14	200.0	0.0	0.4		|R-A|/Span * 100		0.2
	High	08/15/26 03:24	200.0	180.9	180.9		|R-A|/Span * 100		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/15/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/15/26 03:19	10.0	9.1	9.1		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/15/26 03:14	200.0	0.0	0.2		|R-A|/Span * 100		0.1
	High	08/15/26 03:24	200.0	179.8	179.7		|R-A|/Span * 100		0.1
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/15/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/15/26 03:19	10.0	9.3	9.3		|R-A|/Span * 100		0.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/15/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	08/15/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/16/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	08/16/26 02:24	200.0	177.9	177.5		|R-A|/Span * 100		0.2
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/16/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/16/26 02:19	30.0	20.7	20.6		|R-A|/Span * 100		0.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/16/26 02:14	200.0	0.0	-0.5		|R-A|/Span * 100		0.3
	High	08/16/26 02:24	200.0	179.8	179.4		|R-A|/Span * 100		0.2
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/16/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	08/16/26 02:19	30.0	20.6	20.3		|R-A|/Span * 100		1.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/16/26 03:14	200.0	0.0	1.4		|R-A|/Span * 100		0.7
	High	08/16/26 03:24	200.0	179.0	179.8		|R-A|/Span * 100		0.4
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/16/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/16/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/16/26 03:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	08/16/26 03:24	200.0	177.9	177.7		|R-A|/Span * 100		0.1
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/16/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/16/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/16/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	08/16/26 03:19	18.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/16/26 03:14	200.0	0.0	0.4		|R-A|/Span * 100		0.2
	High	08/16/26 03:24	200.0	180.9	180.9		|R-A|/Span * 100		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/16/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/16/26 03:19	10.0	9.1	9.1		|R-A|/Span * 100		0.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/16/26 03:14	200.0	0.0	0.2		|R-A|/Span * 100		0.1
	High	08/16/26 03:24	200.0	179.8	179.7		|R-A|/Span * 100		0.1
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/16/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/16/26 03:19	10.0	9.3	9.3		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/16/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	08/16/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/17/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	08/17/26 02:24	200.0	177.9	177.3		|R-A|/Span * 100		0.3
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/17/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/17/26 02:19	30.0	20.7	20.7		|R-A|/Span * 100		0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/17/26 02:14	200.0	0.0	-0.5		|R-A|/Span * 100		0.3
	High	08/17/26 02:24	200.0	179.8	179.7		|R-A|/Span * 100		0.1
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/17/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	08/17/26 02:19	30.0	20.6	20.3		|R-A|/Span * 100		1.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/17/26 03:14	200.0	0.0	1.4		|R-A|/Span * 100		0.7
	High	08/17/26 03:24	200.0	179.0	180.2		|R-A|/Span * 100		0.6
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/17/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/17/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/17/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/17/26 03:24	200.0	177.9	178.4		|R-A|/Span * 100		0.3
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/17/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/17/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/17/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	08/17/26 03:19	18.0	0.0	0.0		|R-A|		0.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/17/26 03:14	200.0	0.0	0.5		|R-A|/Span * 100		0.3
	High	08/17/26 03:24	200.0	180.9	181.3		|R-A|/Span * 100		0.2
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/17/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/17/26 03:19	10.0	9.1	9.2		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/17/26 03:14	200.0	0.0	0.4		|R-A|/Span * 100		0.2
	High	08/17/26 03:24	200.0	179.8	180.2		|R-A|/Span * 100		0.2
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/17/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/17/26 03:19	10.0	9.3	9.3		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/17/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	08/17/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/18/26 02:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/18/26 02:24	200.0	180.4	174.8	>1x Alert	|R-A|/Span * 100		2.8
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/18/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/18/26 02:19	30.0	20.7	20.7		|R-A|/Span * 100		0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/18/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	08/18/26 02:24	200.0	179.8	179.6		|R-A|/Span * 100		0.1
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/18/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	08/18/26 02:19	30.0	20.6	20.3		|R-A|/Span * 100		1.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/18/26 03:14	200.0	0.0	1.3		|R-A|/Span * 100		0.7
	High	08/18/26 03:24	200.0	181.3	180.6		|R-A|/Span * 100		0.4
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/18/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/18/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/18/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/18/26 03:24	200.0	180.4	177.2		|R-A|/Span * 100		1.6

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/18/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/18/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/18/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	08/18/26 03:19	18.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/18/26 03:14	200.0	0.0	0.4		|R-A|/Span * 100		0.2
	High	08/18/26 03:24	200.0	180.9	180.9		|R-A|/Span * 100		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/18/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/18/26 03:19	10.0	9.0	9.0		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/18/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/18/26 03:24	200.0	179.8	179.3		|R-A|/Span * 100		0.3
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/18/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/18/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/18/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	08/18/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/19/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	08/19/26 02:24	200.0	180.4	177.6		|R-A|/Span * 100		1.4
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/19/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/19/26 02:19	30.0	20.7	20.8		|R-A|/Span * 100		0.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/19/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	08/19/26 02:24	200.0	179.8	179.9		|R-A|/Span * 100		0.1
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/19/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	08/19/26 02:19	30.0	20.6	20.4		|R-A|/Span * 100		0.7
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/19/26 03:14	200.0	0.0	1.4		|R-A|/Span * 100		0.7
	High	08/19/26 03:24	200.0	181.3	181.0		|R-A|/Span * 100		0.2

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/19/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/19/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/19/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/19/26 03:24	200.0	180.4	177.2		|R-A|/Span * 100		1.6
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/19/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/19/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/19/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	08/19/26 03:19	18.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/19/26 03:14	200.0	0.0	0.4		|R-A|/Span * 100		0.2
	High	08/19/26 03:24	200.0	180.9	181.5		|R-A|/Span * 100		0.3
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/19/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/19/26 03:19	10.0	9.0	9.0		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/19/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/19/26 03:24	200.0	179.8	179.8		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/19/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/19/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/19/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	08/19/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT6_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/19/26 16:47	1,000.0	0.0	1.1		|R-A|/Span * 100		0.1
	High	08/19/26 16:57	1,000.0	905.1	934.7		|R-A|/Span * 100		3.0
Part 60	**CT6_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	High	08/19/26 16:42	20.0	18.6	20.3	>1x Alert	|R-A|/Span * 100		8.5
	Zero	08/19/26 16:47	20.0	0.0	1.2	>1x Alert	|R-A|/Span * 100		6.0
Part 75	**CT6_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/19/26 16:42	500.0	0.0	-0.2		|R-A|/Span * 100		0.0
	High	08/19/26 16:52	500.0	439.3	435.0		|R-A|/Span * 100		0.9

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT6_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/19/26 16:42	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/19/26 16:47	10.0	9.5	9.7		|R-A|/Span * 100		2.0
Part 75	**CT6_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/19/26 16:42	25.0	22.5	22.5		|R-A|		0.0
	Zero	08/19/26 16:47	25.0	0.0	0.0		|R-A|		0.0
Part 60	**CT6_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	High	08/19/26 17:41	20.0	18.6	18.8		|R-A|/Span * 100		1.0
	Zero	08/19/26 17:46	20.0	0.0	0.0		|R-A|/Span * 100		0.0
Part 75	**CT6_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/19/26 17:41	25.0	22.5	22.5		|R-A|		0.0
	Zero	08/19/26 17:46	25.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/20/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	08/20/26 02:24	200.0	180.4	177.2		|R-A|/Span * 100		1.6
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/20/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/20/26 02:19	30.0	20.7	20.6		|R-A|/Span * 100		0.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/20/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	08/20/26 02:24	200.0	179.8	180.1		|R-A|/Span * 100		0.2
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/20/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	08/20/26 02:19	30.0	20.6	20.3		|R-A|/Span * 100		1.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/20/26 03:14	200.0	0.0	1.4		|R-A|/Span * 100		0.7
	High	08/20/26 03:24	200.0	181.3	181.0		|R-A|/Span * 100		0.2
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/20/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/20/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/20/26 03:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	08/20/26 03:24	200.0	180.4	177.2		|R-A|/Span * 100		1.6
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/20/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/20/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/20/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	08/20/26 03:19	18.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/20/26 03:14	200.0	0.0	0.5		|R-A|/Span * 100		0.3
	High	08/20/26 03:24	200.0	180.9	181.3		|R-A|/Span * 100		0.2
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/20/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/20/26 03:19	10.0	9.0	9.0		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/20/26 03:14	200.0	0.0	0.5		|R-A|/Span * 100		0.3
	High	08/20/26 03:24	200.0	179.8	180.0		|R-A|/Span * 100		0.1
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/20/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/20/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/20/26 03:14	21.0	18.0	18.1		|R-A|		0.1
	Zero	08/20/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT5_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/20/26 12:32	1,000.0	0.0	-0.1		|R-A|/Span * 100		0.0
	High	08/20/26 12:42	1,000.0	907.4	907.8		|R-A|/Span * 100		0.0
Part 60	**CT5_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	High	08/20/26 12:27	20.0	18.3	18.2		|R-A|/Span * 100		0.5
	Zero	08/20/26 12:32	20.0	0.0	-0.1		|R-A|/Span * 100		0.5
Part 75	**CT5_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/20/26 12:27	500.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/20/26 12:37	500.0	444.4	442.0		|R-A|/Span * 100		0.5
Part 75	**CT5_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/20/26 12:27	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/20/26 12:32	10.0	9.6	9.6		|R-A|/Span * 100		0.0
Part 75	**CT5_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/20/26 12:27	25.0	22.5	22.5		|R-A|		0.0
	Zero	08/20/26 12:32	25.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/21/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	08/21/26 02:24	200.0	180.4	176.9		|R-A|/Span * 100		1.8

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/21/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/21/26 02:19	30.0	20.7	20.6		|R-A|/Span * 100		0.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/21/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	08/21/26 02:24	200.0	179.8	178.2		|R-A|/Span * 100		0.8
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/21/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	08/21/26 02:19	30.0	20.6	20.2		|R-A|/Span * 100		1.3
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/21/26 03:14	200.0	0.0	1.5		|R-A|/Span * 100		0.8
	High	08/21/26 03:24	200.0	181.3	180.9		|R-A|/Span * 100		0.2
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/21/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/21/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/21/26 03:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	08/21/26 03:24	200.0	180.4	176.7		|R-A|/Span * 100		1.9
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/21/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/21/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/21/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	08/21/26 03:19	18.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/21/26 03:14	200.0	0.0	0.3		|R-A|/Span * 100		0.2
	High	08/21/26 03:24	200.0	180.9	180.9		|R-A|/Span * 100		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/21/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/21/26 03:19	10.0	9.0	9.0		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/21/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/21/26 03:24	200.0	179.8	180.1		|R-A|/Span * 100		0.2
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/21/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/21/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/21/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	08/21/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/22/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	08/22/26 02:24	200.0	180.4	176.9		|R-A|/Span * 100		1.8
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/22/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/22/26 02:19	30.0	20.7	20.5		|R-A|/Span * 100		0.7
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/22/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	08/22/26 02:24	200.0	179.8	179.0		|R-A|/Span * 100		0.4
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/22/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	08/22/26 02:19	30.0	20.6	20.2		|R-A|/Span * 100		1.3
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/22/26 03:14	200.0	0.0	1.3		|R-A|/Span * 100		0.7
	High	08/22/26 03:24	200.0	181.3	181.0		|R-A|/Span * 100		0.2
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/22/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/22/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/22/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/22/26 03:24	200.0	180.4	176.8		|R-A|/Span * 100		1.8
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/22/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/22/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/22/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	08/22/26 03:19	18.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/22/26 03:14	200.0	0.0	0.4		|R-A|/Span * 100		0.2
	High	08/22/26 03:24	200.0	180.9	180.9		|R-A|/Span * 100		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/22/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/22/26 03:19	10.0	9.0	9.0		|R-A|/Span * 100		0.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/22/26 03:14	200.0	0.0	0.2		|R-A|/Span * 100		0.1
	High	08/22/26 03:24	200.0	179.8	179.8		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/22/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/22/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/22/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	08/22/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/23/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	08/23/26 02:24	200.0	180.4	177.2		|R-A|/Span * 100		1.6
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/23/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/23/26 02:19	30.0	20.7	20.7		|R-A|/Span * 100		0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/23/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	08/23/26 02:24	200.0	179.8	179.7		|R-A|/Span * 100		0.1
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/23/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	08/23/26 02:19	30.0	20.6	20.4		|R-A|/Span * 100		0.7
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/23/26 03:14	200.0	0.0	1.4		|R-A|/Span * 100		0.7
	High	08/23/26 03:24	200.0	181.3	180.7		|R-A|/Span * 100		0.3
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/23/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/23/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/23/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/23/26 03:24	200.0	180.4	176.7		|R-A|/Span * 100		1.9
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/23/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/23/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/23/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	08/23/26 03:19	18.0	0.0	-0.1		|R-A|		0.1

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/23/26 03:14	200.0	0.0	0.6		|R-A|/Span * 100		0.3
	High	08/23/26 03:24	200.0	180.9	180.9		|R-A|/Span * 100		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/23/26 03:14	10.0	0.0	0.2		|R-A|/Span * 100		2.0
	High	08/23/26 03:19	10.0	9.0	9.1		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/23/26 03:14	200.0	0.0	0.3		|R-A|/Span * 100		0.2
	High	08/23/26 03:24	200.0	179.8	180.3		|R-A|/Span * 100		0.3
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/23/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/23/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/23/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	08/23/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/24/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	08/24/26 02:24	200.0	180.4	176.8		|R-A|/Span * 100		1.8
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/24/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/24/26 02:19	30.0	20.7	20.5		|R-A|/Span * 100		0.7
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/24/26 02:14	200.0	0.0	-0.5		|R-A|/Span * 100		0.3
	High	08/24/26 02:24	200.0	179.8	179.4		|R-A|/Span * 100		0.2
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/24/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	08/24/26 02:19	30.0	20.6	20.3		|R-A|/Span * 100		1.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/24/26 03:14	200.0	0.0	1.4		|R-A|/Span * 100		0.7
	High	08/24/26 03:24	200.0	181.3	181.2		|R-A|/Span * 100		0.1
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/24/26 03:14	10.0	0.0	0.1		|R-A|/Span * 100		1.0
	High	08/24/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/24/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/24/26 03:24	200.0	180.4	176.7		|R-A|/Span * 100		1.9

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/24/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/24/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/24/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	08/24/26 03:19	18.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/24/26 03:14	200.0	0.0	0.7		|R-A|/Span * 100		0.4
	High	08/24/26 03:24	200.0	180.9	181.3		|R-A|/Span * 100		0.2
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/24/26 03:14	10.0	0.0	0.3		|R-A|/Span * 100		3.0
	High	08/24/26 03:19	10.0	9.0	9.0		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/24/26 03:14	200.0	0.0	0.3		|R-A|/Span * 100		0.2
	High	08/24/26 03:24	200.0	179.8	180.1		|R-A|/Span * 100		0.2
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/24/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/24/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/24/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	08/24/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/25/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	08/25/26 02:24	200.0	180.4	176.7		|R-A|/Span * 100		1.9
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/25/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/25/26 02:19	30.0	20.7	20.6		|R-A|/Span * 100		0.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/25/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	08/25/26 02:24	200.0	179.8	178.8		|R-A|/Span * 100		0.5
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/25/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	08/25/26 02:19	30.0	20.6	20.2		|R-A|/Span * 100		1.3
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/25/26 03:14	200.0	0.0	1.5		|R-A|/Span * 100		0.8
	High	08/25/26 03:24	200.0	181.3	181.1		|R-A|/Span * 100		0.1

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/25/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/25/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/25/26 03:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	08/25/26 03:24	200.0	180.4	176.6		|R-A|/Span * 100		1.9
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/25/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/25/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/25/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	08/25/26 03:19	18.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/25/26 03:14	200.0	0.0	0.8		|R-A|/Span * 100		0.4
	High	08/25/26 03:24	200.0	180.9	181.2		|R-A|/Span * 100		0.2
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/25/26 03:14	10.0	0.0	0.3		|R-A|/Span * 100		3.0
	High	08/25/26 03:19	10.0	9.0	9.0		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/25/26 03:14	200.0	0.0	0.3		|R-A|/Span * 100		0.2
	High	08/25/26 03:24	200.0	179.8	180.1		|R-A|/Span * 100		0.2
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/25/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/25/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/25/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	08/25/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT5_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/25/26 16:11	1,000.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/25/26 16:21	1,000.0	907.4	909.1		|R-A|/Span * 100		0.2
Part 60	**CT5_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	High	08/25/26 16:06	20.0	18.3	18.3		|R-A|/Span * 100		0.0
	Zero	08/25/26 16:11	20.0	0.0	0.0		|R-A|/Span * 100		0.0
Part 75	**CT5_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/25/26 16:06	500.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/25/26 16:16	500.0	444.4	443.7		|R-A|/Span * 100		0.1

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT5_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/25/26 16:06	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/25/26 16:11	10.0	9.6	9.5		|R-A|/Span * 100		1.0
Part 75	**CT5_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/25/26 16:06	25.0	22.5	22.5		|R-A|		0.0
	Zero	08/25/26 16:11	25.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/26/26 02:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/26/26 02:24	200.0	180.4	177.1		|R-A|/Span * 100		1.7
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/26/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/26/26 02:19	30.0	20.7	20.6		|R-A|/Span * 100		0.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/26/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	08/26/26 02:24	200.0	179.8	179.0		|R-A|/Span * 100		0.4
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/26/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	08/26/26 02:19	30.0	20.6	20.2		|R-A|/Span * 100		1.3
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/26/26 03:14	200.0	0.0	1.6		|R-A|/Span * 100		0.8
	High	08/26/26 03:24	200.0	181.3	180.7		|R-A|/Span * 100		0.3
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/26/26 03:14	10.0	0.0	0.1		|R-A|/Span * 100		1.0
	High	08/26/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/26/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/26/26 03:24	200.0	180.4	176.8		|R-A|/Span * 100		1.8
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/26/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/26/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/26/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	08/26/26 03:19	18.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/26/26 03:14	200.0	0.0	0.6		|R-A|/Span * 100		0.3
	High	08/26/26 03:24	200.0	180.9	181.2		|R-A|/Span * 100		0.2

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	08/26/26 03:14	10.0	0.0	0.3		|R-A|/Span * 100		3.0
	High	08/26/26 03:19	10.0	9.0	9.1		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	08/26/26 03:14	200.0	0.0	0.3		|R-A|/Span * 100		0.2
	High	08/26/26 03:24	200.0	179.8	179.8		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	08/26/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/26/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	High	08/26/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	08/26/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	08/27/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	08/27/26 02:24	200.0	180.4	177.9		|R-A|/Span * 100		1.3
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	08/27/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/27/26 02:19	30.0	20.7	20.7		|R-A|/Span * 100		0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	08/27/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	08/27/26 02:24	200.0	179.8	179.5		|R-A|/Span * 100		0.2
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	08/27/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	08/27/26 02:19	30.0	20.6	20.3		|R-A|/Span * 100		1.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	08/27/26 03:14	200.0	0.0	1.3		|R-A|/Span * 100		0.7
	High	08/27/26 03:24	200.0	181.3	180.6		|R-A|/Span * 100		0.4
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	08/27/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/27/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	08/27/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/27/26 03:24	200.0	180.4	176.8		|R-A|/Span * 100		1.8
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	08/27/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/27/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/27/26 03:14	18.0	18.0	18.1		|R-A|		0.1
	Zero	08/27/26 03:19	18.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/27/26 03:14	200.0	0.0	0.8		|R-A|/Span * 100		0.4
	High	08/27/26 03:24	200.0	180.9	181.5		|R-A|/Span * 100		0.3
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/27/26 03:14	10.0	0.0	0.3		|R-A|/Span * 100		3.0
	High	08/27/26 03:19	10.0	9.0	9.1		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/27/26 03:14	200.0	0.0	0.5		|R-A|/Span * 100		0.3
	High	08/27/26 03:24	200.0	179.8	179.8		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/27/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/27/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/27/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	08/27/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT5_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Offline**			**Pass**
	Zero	08/27/26 15:16	1,000.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/27/26 15:26	1,000.0	907.4	910.2		|R-A|/Span * 100		0.3
Part 60	**CT5_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	High	08/27/26 15:11	20.0	18.3	18.3		|R-A|/Span * 100		0.0
	Zero	08/27/26 15:16	20.0	0.0	0.0		|R-A|/Span * 100		0.0
Part 75	**CT5_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Incomplete**
	Zero	08/27/26 15:11	500.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/27/26 15:21	500.0	444.4	442.3	Off	|R-A|/Span * 100		0.4
Part 75	**CT5_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Incomplete**
	Zero	08/27/26 15:11	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/27/26 15:16	10.0	9.6	9.5	Off	|R-A|/Span * 100		1.0
Part 75	**CT5_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Incomplete**
	High	08/27/26 15:11	25.0	22.5	22.5		|R-A|		0.0
	Zero	08/27/26 15:16	25.0	0.0	0.0	Off	|R-A|		0.0
Part 60	**CT6_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/27/26 16:16	1,000.0	0.0	0.2		|R-A|/Span * 100		0.0
	High	08/27/26 16:26	1,000.0	905.1	940.3		|R-A|/Span * 100		3.5

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT6_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	High	08/27/26 16:11	20.0	18.6	19.3		|R-A|/Span * 100		3.5
	Zero	08/27/26 16:16	20.0	0.0	0.3		|R-A|/Span * 100		1.5
Part 75	**CT6_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/27/26 16:11	500.0	0.0	-0.2		|R-A|/Span * 100		0.0
	High	08/27/26 16:21	500.0	439.3	430.4		|R-A|/Span * 100		1.8
Part 75	**CT6_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/27/26 16:11	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/27/26 16:16	10.0	9.5	9.6		|R-A|/Span * 100		1.0
Part 75	**CT6_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/27/26 16:11	25.0	22.5	22.5		|R-A|		0.0
	Zero	08/27/26 16:16	25.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/28/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	08/28/26 02:24	200.0	180.4	177.8		|R-A|/Span * 100		1.3
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/28/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/28/26 02:19	30.0	20.7	20.6		|R-A|/Span * 100		0.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/28/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	08/28/26 02:24	200.0	179.8	179.6		|R-A|/Span * 100		0.1
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/28/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	08/28/26 02:19	30.0	21.4	20.7		|R-A|/Span * 100		2.3
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/28/26 03:14	200.0	0.0	1.3		|R-A|/Span * 100		0.7
	High	08/28/26 03:24	200.0	181.3	180.3		|R-A|/Span * 100		0.5
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/28/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/28/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/28/26 03:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	08/28/26 03:24	200.0	180.4	176.9		|R-A|/Span * 100		1.8
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/28/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/28/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/28/26 03:14	18.0	18.0	18.1		|R-A|		0.1
	Zero	08/28/26 03:19	18.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/28/26 03:14	200.0	0.0	0.7		|R-A|/Span * 100		0.4
	High	08/28/26 03:24	200.0	180.9	181.6		|R-A|/Span * 100		0.4
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/28/26 03:14	10.0	0.0	0.3		|R-A|/Span * 100		3.0
	High	08/28/26 03:19	10.0	9.0	9.1		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/28/26 03:14	200.0	0.0	0.4		|R-A|/Span * 100		0.2
	High	08/28/26 03:24	200.0	179.8	180.3		|R-A|/Span * 100		0.3
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/28/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/28/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/28/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	08/28/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT5_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/28/26 09:19	1,000.0	0.0	-0.1		|R-A|/Span * 100		0.0
	High	08/28/26 09:29	1,000.0	907.4	906.7		|R-A|/Span * 100		0.1
Part 60	**CT5_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	High	08/28/26 09:14	20.0	18.3	18.3		|R-A|/Span * 100		0.0
	Zero	08/28/26 09:19	20.0	0.0	0.0		|R-A|/Span * 100		0.0
Part 75	**CT5_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/28/26 09:14	500.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/28/26 09:24	500.0	444.4	443.0		|R-A|/Span * 100		0.3
Part 75	**CT5_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/28/26 09:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/28/26 09:19	10.0	9.6	9.5		|R-A|/Span * 100		1.0
Part 75	**CT5_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/28/26 09:14	25.0	22.5	22.5		|R-A|		0.0
	Zero	08/28/26 09:19	25.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/29/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	08/29/26 02:24	200.0	180.4	176.7		|R-A|/Span * 100		1.9

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/29/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/29/26 02:19	30.0	20.7	20.4		|R-A|/Span * 100		1.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/29/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	08/29/26 02:24	200.0	179.8	177.6		|R-A|/Span * 100		1.1
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/29/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	08/29/26 02:19	30.0	21.4	20.3	>1x Alert	|R-A|/Span * 100		3.7
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/29/26 03:14	200.0	0.0	1.3		|R-A|/Span * 100		0.7
	High	08/29/26 03:24	200.0	181.3	180.4		|R-A|/Span * 100		0.5
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/29/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/29/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/29/26 03:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	08/29/26 03:24	200.0	180.4	176.7		|R-A|/Span * 100		1.9
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/29/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/29/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/29/26 03:14	18.0	18.0	18.1		|R-A|		0.1
	Zero	08/29/26 03:19	18.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/29/26 03:14	200.0	0.0	0.7		|R-A|/Span * 100		0.4
	High	08/29/26 03:24	200.0	180.9	181.7		|R-A|/Span * 100		0.4
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/29/26 03:14	10.0	0.0	0.3		|R-A|/Span * 100		3.0
	High	08/29/26 03:19	10.0	9.0	9.1		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/29/26 03:14	200.0	0.0	0.2		|R-A|/Span * 100		0.1
	High	08/29/26 03:24	200.0	179.8	179.7		|R-A|/Span * 100		0.1
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/29/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/29/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/29/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	08/29/26 03:19	21.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/30/26 02:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/30/26 02:24	200.0	180.4	176.7		|R-A|/Span * 100		1.9
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/30/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/30/26 02:19	30.0	20.7	20.3		|R-A|/Span * 100		1.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/30/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	08/30/26 02:24	200.0	177.6	175.9		|R-A|/Span * 100		0.9
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/30/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	08/30/26 02:19	30.0	21.4	20.3	>1x Alert	|R-A|/Span * 100		3.7
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/30/26 03:14	200.0	0.0	1.5		|R-A|/Span * 100		0.8
	High	08/30/26 03:24	200.0	181.3	180.7		|R-A|/Span * 100		0.3
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/30/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/30/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/30/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/30/26 03:24	200.0	180.4	176.5		|R-A|/Span * 100		2.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/30/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/30/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	08/30/26 03:14	18.0	18.0	18.1		|R-A|		0.1
	Zero	08/30/26 03:19	18.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	08/30/26 03:14	200.0	0.0	0.8		|R-A|/Span * 100		0.4
	High	08/30/26 03:24	200.0	178.2	181.7		|R-A|/Span * 100		1.8
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	08/30/26 03:14	10.0	0.0	0.3		|R-A|/Span * 100		3.0
	High	08/30/26 03:19	10.0	9.0	9.1		|R-A|/Span * 100		1.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	08/30/26 03:14	200.0	0.0	0.5		|R-A|/Span * 100		0.3
	High	08/30/26 03:24	200.0	177.6	179.0		|R-A|/Span * 100		0.7
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	08/30/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/30/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	High	08/30/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	08/30/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	08/31/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	08/31/26 02:24	200.0	180.4	176.6		|R-A|/Span * 100		1.9
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	08/31/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/31/26 02:19	30.0	20.7	20.3		|R-A|/Span * 100		1.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	08/31/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	08/31/26 02:24	200.0	177.6	177.5		|R-A|/Span * 100		0.1
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	08/31/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	08/31/26 02:19	30.0	21.4	20.3	>1x Alert	|R-A|/Span * 100		3.7
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	08/31/26 03:14	200.0	0.0	1.4		|R-A|/Span * 100		0.7
	High	08/31/26 03:24	200.0	181.3	180.5		|R-A|/Span * 100		0.4
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	08/31/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/31/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	08/31/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/31/26 03:24	200.0	180.4	176.8		|R-A|/Span * 100		1.8
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	08/31/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/31/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	High	08/31/26 03:14	18.0	18.0	18.1		|R-A|		0.1
	Zero	08/31/26 03:19	18.0	0.0	-0.1		|R-A|		0.1

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	08/31/26 03:14	200.0	0.0	0.8		|R-A|/Span * 100		0.4
	High	08/31/26 03:24	200.0	178.2	182.0		|R-A|/Span * 100		1.9
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	08/31/26 03:14	10.0	0.0	0.3		|R-A|/Span * 100		3.0
	High	08/31/26 03:19	10.0	9.0	9.1		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	08/31/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/31/26 03:24	200.0	177.6	179.5		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	08/31/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	08/31/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	High	08/31/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	08/31/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	08/31/26 07:54	200.0	0.0	-0.2		|R-A|/Span * 100		0.1
	High	08/31/26 08:04	200.0	177.6	178.2		|R-A|/Span * 100		0.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	08/31/26 07:54	30.0	0.0	0.2		|R-A|/Span * 100		0.7
	High	08/31/26 07:59	30.0	21.4	21.9		|R-A|/Span * 100		1.7
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	09/01/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/01/26 02:24	200.0	180.4	177.5		|R-A|/Span * 100		1.5
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	09/01/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/01/26 02:19	30.0	20.7	20.6		|R-A|/Span * 100		0.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	09/01/26 02:14	200.0	0.0	-0.5		|R-A|/Span * 100		0.3
	High	09/01/26 02:24	200.0	177.6	177.2		|R-A|/Span * 100		0.2
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	09/01/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	09/01/26 02:19	30.0	21.4	21.4		|R-A|/Span * 100		0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	09/01/26 03:14	200.0	0.0	1.5		|R-A|/Span * 100		0.8
	High	09/01/26 03:24	200.0	181.3	180.3		|R-A|/Span * 100		0.5

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/01/26 03:14	10.0	0.0	0.1		|R-A|/Span * 100		1.0
	High	09/01/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/01/26 03:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/01/26 03:24	200.0	180.4	176.6		|R-A|/Span * 100		1.9
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/01/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/01/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/01/26 03:14	18.0	18.0	18.1		|R-A|		0.1
	Zero	09/01/26 03:19	18.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/01/26 03:14	200.0	0.0	0.8		|R-A|/Span * 100		0.4
	High	09/01/26 03:24	200.0	178.2	181.7		|R-A|/Span * 100		1.8
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/01/26 03:14	10.0	0.0	0.3		|R-A|/Span * 100		3.0
	High	09/01/26 03:19	10.0	9.0	9.1		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/01/26 03:14	200.0	0.0	0.3		|R-A|/Span * 100		0.2
	High	09/01/26 03:24	200.0	177.6	179.1		|R-A|/Span * 100		0.8
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/01/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/01/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/01/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	09/01/26 03:19	21.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT6_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Offline**			**Pass**
	Zero	09/01/26 13:19	1,000.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/01/26 13:29	1,000.0	905.1	906.9		|R-A|/Span * 100		0.2
Part 60	**CT6_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Offline**			**Pass**
	High	09/01/26 13:14	20.0	18.6	18.5		|R-A|/Span * 100		0.5
	Zero	09/01/26 13:19	20.0	0.0	0.0		|R-A|/Span * 100		0.0
Part 75	**CT6_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Offline**			**Offline**
	Zero	09/01/26 13:14	500.0	0.0	-0.1	Off	|R-A|/Span * 100		0.0
	High	09/01/26 13:24	500.0	439.3	439.4	Off	|R-A|/Span * 100		0.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT6_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Offline**			**Offline**
	Zero	09/01/26 13:14	10.0	0.0	0.2	Off	|R-A|/Span * 100		2.0
	High	09/01/26 13:19	10.0	9.5	9.9	Off	|R-A|/Span * 100		4.0
Part 75	**CT6_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Offline**			**Offline**
	High	09/01/26 13:14	25.0	22.5	22.5	Off	|R-A|		0.0
	Zero	09/01/26 13:19	25.0	0.0	0.0	Off	|R-A|		0.0
Part 60	**CT5_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Offline**			**Pass**
	Zero	09/01/26 13:57	1,000.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/01/26 14:07	1,000.0	907.4	905.7		|R-A|/Span * 100		0.2
Part 60	**CT5_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Offline**			**Pass**
	High	09/01/26 13:52	20.0	18.3	18.3		|R-A|/Span * 100		0.0
	Zero	09/01/26 13:57	20.0	0.0	0.0		|R-A|/Span * 100		0.0
Part 75	**CT5_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Offline**			**Offline**
	Zero	09/01/26 13:52	500.0	0.0	0.1	Off	|R-A|/Span * 100		0.0
	High	09/01/26 14:02	500.0	444.4	444.9	Off	|R-A|/Span * 100		0.1
Part 75	**CT5_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Offline**			**Offline**
	Zero	09/01/26 13:52	10.0	0.0	0.1	Off	|R-A|/Span * 100		1.0
	High	09/01/26 13:57	10.0	9.6	9.9	Off	|R-A|/Span * 100		3.0
Part 75	**CT5_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Offline**			**Offline**
	High	09/01/26 13:52	25.0	22.5	22.5	Off	|R-A|		0.0
	Zero	09/01/26 13:57	25.0	0.0	0.0	Off	|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/02/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/02/26 02:24	200.0	180.4	177.0		|R-A|/Span * 100		1.7
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/02/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/02/26 02:19	30.0	20.7	20.6		|R-A|/Span * 100		0.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/02/26 02:14	200.0	0.0	-0.5		|R-A|/Span * 100		0.3
	High	09/02/26 02:24	200.0	177.6	177.7		|R-A|/Span * 100		0.1
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/02/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	09/02/26 02:19	30.0	21.4	21.5		|R-A|/Span * 100		0.3
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/02/26 03:14	200.0	0.0	1.2		|R-A|/Span * 100		0.6
	High	09/02/26 03:24	200.0	181.3	179.9		|R-A|/Span * 100		0.7

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/02/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/02/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/02/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/02/26 03:24	200.0	180.4	176.1		|R-A|/Span * 100		2.2
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/02/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/02/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/02/26 03:14	18.0	18.0	18.1		|R-A|		0.1
	Zero	09/02/26 03:19	18.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/02/26 03:14	200.0	0.0	0.8		|R-A|/Span * 100		0.4
	High	09/02/26 03:24	200.0	178.2	181.3		|R-A|/Span * 100		1.6
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/02/26 03:14	10.0	0.0	0.3		|R-A|/Span * 100		3.0
	High	09/02/26 03:19	10.0	9.0	9.1		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/02/26 03:14	200.0	0.0	0.2		|R-A|/Span * 100		0.1
	High	09/02/26 03:24	200.0	177.6	179.4		|R-A|/Span * 100		0.9
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/02/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/02/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/02/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	09/02/26 03:19	21.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/03/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/03/26 02:24	200.0	180.4	176.9		|R-A|/Span * 100		1.8
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/03/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/03/26 02:19	30.0	20.7	20.6		|R-A|/Span * 100		0.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/03/26 02:14	200.0	0.0	-0.5		|R-A|/Span * 100		0.3
	High	09/03/26 02:24	200.0	177.6	177.9		|R-A|/Span * 100		0.2

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/03/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	09/03/26 02:19	30.0	21.4	21.6		|R-A|/Span * 100		0.7
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/03/26 03:14	200.0	0.0	1.4		|R-A|/Span * 100		0.7
	High	09/03/26 03:24	200.0	181.3	180.9		|R-A|/Span * 100		0.2
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/03/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/03/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/03/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/03/26 03:24	200.0	180.4	176.2		|R-A|/Span * 100		2.1
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/03/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/03/26 03:19	10.0	9.2	9.0		|R-A|/Span * 100		2.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/03/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	09/03/26 03:19	18.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/03/26 03:14	200.0	0.0	0.7		|R-A|/Span * 100		0.4
	High	09/03/26 03:24	200.0	178.2	181.3		|R-A|/Span * 100		1.6
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/03/26 03:14	10.0	0.0	0.3		|R-A|/Span * 100		3.0
	High	09/03/26 03:19	10.0	9.0	9.1		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/03/26 03:14	200.0	0.0	0.1		|R-A|/Span * 100		0.1
	High	09/03/26 03:24	200.0	177.6	179.7		|R-A|/Span * 100		1.1
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/03/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/03/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/03/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	09/03/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/04/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/04/26 02:24	200.0	180.4	176.6		|R-A|/Span * 100		1.9

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/04/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/04/26 02:19	30.0	20.7	20.6		|R-A|/Span * 100		0.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/04/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	09/04/26 02:24	200.0	177.6	176.2		|R-A|/Span * 100		0.7
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/04/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	09/04/26 02:19	30.0	21.4	21.4		|R-A|/Span * 100		0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/04/26 03:14	200.0	0.0	1.7		|R-A|/Span * 100		0.9
	High	09/04/26 03:24	200.0	181.3	181.3		|R-A|/Span * 100		0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/04/26 03:14	10.0	0.0	0.1		|R-A|/Span * 100		1.0
	High	09/04/26 03:19	10.0	9.2	9.3		|R-A|/Span * 100		1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/04/26 03:14	200.0	0.0	0.1		|R-A|/Span * 100		0.1
	High	09/04/26 03:24	200.0	180.4	176.1		|R-A|/Span * 100		2.2
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/04/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/04/26 03:19	10.0	9.2	9.0		|R-A|/Span * 100		2.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/04/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	09/04/26 03:19	18.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/04/26 03:14	200.0	0.0	0.7		|R-A|/Span * 100		0.4
	High	09/04/26 03:24	200.0	178.2	181.6		|R-A|/Span * 100		1.7
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/04/26 03:14	10.0	0.0	0.3		|R-A|/Span * 100		3.0
	High	09/04/26 03:19	10.0	9.0	9.1		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/04/26 03:14	200.0	0.0	0.5		|R-A|/Span * 100		0.3
	High	09/04/26 03:24	200.0	177.6	179.9		|R-A|/Span * 100		1.2
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/04/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/04/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	High	09/04/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	09/04/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	09/05/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/05/26 02:24	200.0	180.4	177.2		|R-A|/Span * 100		1.6
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	09/05/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/05/26 02:19	30.0	20.7	20.6		|R-A|/Span * 100		0.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	09/05/26 02:14	200.0	0.0	-0.5		|R-A|/Span * 100		0.3
	High	09/05/26 02:24	200.0	177.6	176.9		|R-A|/Span * 100		0.4
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	09/05/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	09/05/26 02:19	30.0	21.4	21.5		|R-A|/Span * 100		0.3
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	09/05/26 03:14	200.0	0.0	1.5		|R-A|/Span * 100		0.8
	High	09/05/26 03:24	200.0	181.3	180.9		|R-A|/Span * 100		0.2
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	09/05/26 03:14	10.0	0.0	0.1		|R-A|/Span * 100		1.0
	High	09/05/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	09/05/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/05/26 03:24	200.0	180.4	176.9		|R-A|/Span * 100		1.8
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	09/05/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/05/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	High	09/05/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	09/05/26 03:19	18.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	09/05/26 03:14	200.0	0.0	0.6		|R-A|/Span * 100		0.3
	High	09/05/26 03:24	200.0	178.2	180.8		|R-A|/Span * 100		1.3
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	09/05/26 03:14	10.0	0.0	0.3		|R-A|/Span * 100		3.0
	High	09/05/26 03:19	10.0	9.0	9.1		|R-A|/Span * 100		1.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/05/26 03:14	200.0	0.0	-0.2		|R-A|/Span * 100		0.1
	High	09/05/26 03:24	200.0	177.6	180.0		|R-A|/Span * 100		1.2
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/05/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/05/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/05/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	09/05/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/06/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/06/26 02:24	200.0	180.4	177.4		|R-A|/Span * 100		1.5
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/06/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/06/26 02:19	30.0	20.7	20.7		|R-A|/Span * 100		0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/06/26 02:14	200.0	0.0	-0.5		|R-A|/Span * 100		0.3
	High	09/06/26 02:24	200.0	177.6	177.2		|R-A|/Span * 100		0.2
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/06/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	09/06/26 02:19	30.0	21.4	21.5		|R-A|/Span * 100		0.3
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/06/26 03:14	200.0	0.0	1.6		|R-A|/Span * 100		0.8
	High	09/06/26 03:24	200.0	181.3	180.8		|R-A|/Span * 100		0.3
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/06/26 03:14	10.0	0.0	0.1		|R-A|/Span * 100		1.0
	High	09/06/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/06/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/06/26 03:24	200.0	180.4	176.8		|R-A|/Span * 100		1.8
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/06/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/06/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/06/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	09/06/26 03:19	18.0	0.0	0.0		|R-A|		0.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	09/06/26 03:14	200.0	0.0	0.6		|R-A|/Span * 100		0.3
	High	09/06/26 03:24	200.0	178.2	180.8		|R-A|/Span * 100		1.3
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	09/06/26 03:14	10.0	0.0	0.3		|R-A|/Span * 100		3.0
	High	09/06/26 03:19	10.0	9.0	9.1		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	09/06/26 03:14	200.0	0.0	0.2		|R-A|/Span * 100		0.1
	High	09/06/26 03:24	200.0	177.6	180.3		|R-A|/Span * 100		1.4
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	09/06/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/06/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	High	09/06/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	09/06/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	09/07/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/07/26 02:24	200.0	180.4	177.2		|R-A|/Span * 100		1.6
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	09/07/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/07/26 02:19	30.0	20.7	20.6		|R-A|/Span * 100		0.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	09/07/26 02:14	200.0	0.0	-0.5		|R-A|/Span * 100		0.3
	High	09/07/26 02:24	200.0	177.6	177.2		|R-A|/Span * 100		0.2
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	09/07/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	09/07/26 02:19	30.0	21.4	21.5		|R-A|/Span * 100		0.3
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	09/07/26 03:14	200.0	0.0	1.6		|R-A|/Span * 100		0.8
	High	09/07/26 03:24	200.0	181.3	180.6		|R-A|/Span * 100		0.4
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	09/07/26 03:14	10.0	0.0	0.1		|R-A|/Span * 100		1.0
	High	09/07/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	09/07/26 03:14	200.0	0.0	0.1		|R-A|/Span * 100		0.1
	High	09/07/26 03:24	200.0	180.4	176.6		|R-A|/Span * 100		1.9

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/07/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/07/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/07/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	09/07/26 03:19	18.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/07/26 03:14	200.0	0.0	0.6		|R-A|/Span * 100		0.3
	High	09/07/26 03:24	200.0	178.2	181.1		|R-A|/Span * 100		1.5
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/07/26 03:14	10.0	0.0	0.3		|R-A|/Span * 100		3.0
	High	09/07/26 03:19	10.0	9.0	9.1		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/07/26 03:14	200.0	0.0	-0.3		|R-A|/Span * 100		0.2
	High	09/07/26 03:24	200.0	177.6	179.9		|R-A|/Span * 100		1.2
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/07/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/07/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/07/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	09/07/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/08/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/08/26 02:24	200.0	180.4	176.8		|R-A|/Span * 100		1.8
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/08/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/08/26 02:19	30.0	20.7	20.6		|R-A|/Span * 100		0.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/08/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	09/08/26 02:24	200.0	177.6	176.8		|R-A|/Span * 100		0.4
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/08/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	09/08/26 02:19	30.0	21.4	21.4		|R-A|/Span * 100		0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/08/26 03:14	200.0	0.0	1.6		|R-A|/Span * 100		0.8
	High	09/08/26 03:24	200.0	181.3	181.2		|R-A|/Span * 100		0.1

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	09/08/26 03:14	10.0	0.0	0.1		|R-A|/Span * 100		1.0
	High	09/08/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	09/08/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/08/26 03:24	200.0	180.4	176.6		|R-A|/Span * 100		1.9
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	09/08/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/08/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	High	09/08/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	09/08/26 03:19	18.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	09/08/26 03:14	200.0	0.0	0.7		|R-A|/Span * 100		0.4
	High	09/08/26 03:24	200.0	178.2	181.2		|R-A|/Span * 100		1.5
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	09/08/26 03:14	10.0	0.0	0.3		|R-A|/Span * 100		3.0
	High	09/08/26 03:19	10.0	9.0	9.1		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	09/08/26 03:14	200.0	0.0	0.2		|R-A|/Span * 100		0.1
	High	09/08/26 03:24	200.0	177.6	180.2		|R-A|/Span * 100		1.3
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	09/08/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/08/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	High	09/08/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	09/08/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT6_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	09/08/26 18:12	1,000.0	0.0	0.2		|R-A|/Span * 100		0.0
	High	09/08/26 18:22	1,000.0	923.1	920.5		|R-A|/Span * 100		0.3
Part 60	**CT6_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	High	09/08/26 18:07	20.0	18.6	19.1		|R-A|/Span * 100		2.5
	Zero	09/08/26 18:12	20.0	0.0	0.2		|R-A|/Span * 100		1.0
Part 75	**CT6_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	09/08/26 18:07	500.0	0.0	-0.2		|R-A|/Span * 100		0.0
	High	09/08/26 18:17	500.0	439.3	436.2		|R-A|/Span * 100		0.6

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT6_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/08/26 18:07	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/08/26 18:12	10.0	9.5	9.7		|R-A|/Span * 100		2.0
Part 75	**CT6_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/08/26 18:07	25.0	22.5	22.5		|R-A|		0.0
	Zero	09/08/26 18:12	25.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/09/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/09/26 02:24	200.0	180.4	176.5		|R-A|/Span * 100		2.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/09/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/09/26 02:19	30.0	20.7	20.5		|R-A|/Span * 100		0.7
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/09/26 02:14	200.0	0.0	-0.5		|R-A|/Span * 100		0.3
	High	09/09/26 02:24	200.0	177.6	176.2		|R-A|/Span * 100		0.7
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/09/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	09/09/26 02:19	30.0	21.4	21.4		|R-A|/Span * 100		0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/09/26 03:14	200.0	0.0	1.6		|R-A|/Span * 100		0.8
	High	09/09/26 03:24	200.0	181.3	180.7		|R-A|/Span * 100		0.3
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/09/26 03:14	10.0	0.0	0.1		|R-A|/Span * 100		1.0
	High	09/09/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/09/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/09/26 03:24	200.0	180.4	176.5		|R-A|/Span * 100		2.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/09/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/09/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/09/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	09/09/26 03:19	18.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/09/26 03:14	200.0	0.0	0.7		|R-A|/Span * 100		0.4
	High	09/09/26 03:24	200.0	178.2	180.9		|R-A|/Span * 100		1.4

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/09/26 03:14	10.0	0.0	0.3		|R-A|/Span * 100		3.0
	High	09/09/26 03:19	10.0	9.0	9.1		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/09/26 03:14	200.0	0.0	0.1		|R-A|/Span * 100		0.1
	High	09/09/26 03:24	200.0	177.6	180.1		|R-A|/Span * 100		1.3
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/09/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/09/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/09/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	09/09/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT5_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/09/26 13:10	1,000.0	0.0	-0.1		|R-A|/Span * 100		0.0
	High	09/09/26 13:20	1,000.0	918.1	910.9		|R-A|/Span * 100		0.7
Part 60	**CT5_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	High	09/09/26 13:05	20.0	18.3	18.2		|R-A|/Span * 100		0.5
	Zero	09/09/26 13:10	20.0	0.0	-0.1		|R-A|/Span * 100		0.5
Part 75	**CT5_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/09/26 13:05	500.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/09/26 13:15	500.0	444.4	442.5		|R-A|/Span * 100		0.4
Part 75	**CT5_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/09/26 13:05	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/09/26 13:10	10.0	9.6	9.6		|R-A|/Span * 100		0.0
Part 75	**CT5_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/09/26 13:05	25.0	22.5	22.5		|R-A|		0.0
	Zero	09/09/26 13:10	25.0	0.0	0.0		|R-A|		0.0
Part 60	**CT6_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/09/26 13:11	1,000.0	0.0	0.3		|R-A|/Span * 100		0.0
	High	09/09/26 13:21	1,000.0	923.1	923.2		|R-A|/Span * 100		0.0
Part 60	**CT6_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	High	09/09/26 13:06	20.0	18.6	19.1		|R-A|/Span * 100		2.5
	Zero	09/09/26 13:11	20.0	0.0	0.3		|R-A|/Span * 100		1.5
Part 75	**CT6_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/09/26 13:06	500.0	0.0	-0.2		|R-A|/Span * 100		0.0
	High	09/09/26 13:16	500.0	435.6	449.6	>1x Alert	|R-A|/Span * 100		2.8

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT6_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/09/26 13:06	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/09/26 13:11	10.0	9.5	9.8	>1x Alert	|R-A|/Span * 100		3.0
Part 75	**CT6_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/09/26 13:06	25.0	22.5	22.5		|R-A|		0.0
	Zero	09/09/26 13:11	25.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/10/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/10/26 02:24	200.0	180.4	176.9		|R-A|/Span * 100		1.8
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/10/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/10/26 02:19	30.0	20.7	20.6		|R-A|/Span * 100		0.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/10/26 02:14	200.0	0.0	-0.5		|R-A|/Span * 100		0.3
	High	09/10/26 02:24	200.0	177.6	176.6		|R-A|/Span * 100		0.5
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/10/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	09/10/26 02:19	30.0	21.4	21.4		|R-A|/Span * 100		0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/10/26 03:14	200.0	0.0	1.5		|R-A|/Span * 100		0.8
	High	09/10/26 03:24	200.0	181.3	180.2		|R-A|/Span * 100		0.6
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/10/26 03:14	10.0	0.0	0.1		|R-A|/Span * 100		1.0
	High	09/10/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/10/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/10/26 03:24	200.0	180.4	176.8		|R-A|/Span * 100		1.8
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/10/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/10/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/10/26 03:14	18.0	18.0	18.1		|R-A|		0.1
	Zero	09/10/26 03:19	18.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/10/26 03:14	200.0	0.0	0.6		|R-A|/Span * 100		0.3
	High	09/10/26 03:24	200.0	178.2	181.6		|R-A|/Span * 100		1.7

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/10/26 03:14	10.0	0.0	0.3		|R-A|/Span * 100		3.0
	High	09/10/26 03:19	10.0	9.0	9.1		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/10/26 03:14	200.0	0.0	0.1		|R-A|/Span * 100		0.1
	High	09/10/26 03:24	200.0	177.6	179.8		|R-A|/Span * 100		1.1
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/10/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/10/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/10/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	09/10/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT6_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Offline**			**Pass**
	Zero	09/10/26 06:56	1,000.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/10/26 07:06	1,000.0	923.1	925.3		|R-A|/Span * 100		0.2
Part 60	**CT6_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Offline**			**Pass**
	High	09/10/26 06:51	20.0	18.6	18.8		|R-A|/Span * 100		1.0
	Zero	09/10/26 06:56	20.0	0.0	0.0		|R-A|/Span * 100		0.0
Part 75	**CT6_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Offline**			**Offline**
	Zero	09/10/26 06:51	500.0	0.0	0.1	Off	|R-A|/Span * 100		0.0
	High	09/10/26 07:01	500.0	435.6	435.0	Off	|R-A|/Span * 100		0.1
Part 75	**CT6_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Offline**			**Offline**
	Zero	09/10/26 06:51	10.0	0.0	0.1	Off	|R-A|/Span * 100		1.0
	High	09/10/26 06:56	10.0	9.5	9.7	Off	|R-A|/Span * 100		2.0
Part 75	**CT6_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Offline**			**Offline**
	High	09/10/26 06:51	25.0	22.5	22.5	Off	|R-A|		0.0
	Zero	09/10/26 06:56	25.0	0.0	0.0	Off	|R-A|		0.0
Part 60	**CT6_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/10/26 17:04	1,000.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/10/26 17:14	1,000.0	923.1	926.9		|R-A|/Span * 100		0.4
Part 60	**CT6_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	High	09/10/26 16:59	20.0	18.6	18.9		|R-A|/Span * 100		1.5
	Zero	09/10/26 17:04	20.0	0.0	0.1		|R-A|/Span * 100		0.5
Part 75	**CT6_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/10/26 16:59	500.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/10/26 17:09	500.0	435.6	437.3		|R-A|/Span * 100		0.3

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT6_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/10/26 16:59	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/10/26 17:04	10.0	9.5	9.5		|R-A|/Span * 100		0.0
Part 75	**CT6_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/10/26 16:59	25.0	22.5	22.5		|R-A|		0.0
	Zero	09/10/26 17:04	25.0	0.0	0.0		|R-A|		0.0
Part 60	**CT5_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/10/26 17:05	1,000.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/10/26 17:15	1,000.0	918.1	918.2		|R-A|/Span * 100		0.0
Part 60	**CT5_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	High	09/10/26 17:00	20.0	18.3	18.3		|R-A|/Span * 100		0.0
	Zero	09/10/26 17:05	20.0	0.0	0.0		|R-A|/Span * 100		0.0
Part 75	**CT5_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/10/26 17:00	500.0	0.0	-0.1		|R-A|/Span * 100		0.0
	High	09/10/26 17:10	500.0	444.4	444.2		|R-A|/Span * 100		0.0
Part 75	**CT5_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/10/26 17:00	10.0	0.0	-0.2		|R-A|/Span * 100		2.0
	High	09/10/26 17:05	10.0	9.6	9.8		|R-A|/Span * 100		2.0
Part 75	**CT5_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/10/26 17:00	25.0	22.5	22.5		|R-A|		0.0
	Zero	09/10/26 17:05	25.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/11/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/11/26 02:24	200.0	180.4	177.7		|R-A|/Span * 100		1.4
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/11/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/11/26 02:19	30.0	20.7	20.7		|R-A|/Span * 100		0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/11/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	09/11/26 02:24	200.0	177.6	177.9		|R-A|/Span * 100		0.2
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/11/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	09/11/26 02:19	30.0	21.4	21.6		|R-A|/Span * 100		0.7
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/11/26 03:14	200.0	0.0	1.5		|R-A|/Span * 100		0.8
	High	09/11/26 03:24	200.0	181.3	180.7		|R-A|/Span * 100		0.3

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/11/26 03:14	10.0	0.0	0.1		|R-A|/Span * 100		1.0
	High	09/11/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/11/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/11/26 03:24	200.0	180.4	177.1		|R-A|/Span * 100		1.7
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/11/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/11/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/11/26 03:14	18.0	18.0	18.1		|R-A|		0.1
	Zero	09/11/26 03:19	18.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/11/26 03:14	200.0	0.0	0.7		|R-A|/Span * 100		0.4
	High	09/11/26 03:24	200.0	178.2	182.0		|R-A|/Span * 100		1.9
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/11/26 03:14	10.0	0.0	0.4		|R-A|/Span * 100		4.0
	High	09/11/26 03:19	10.0	9.0	9.1		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/11/26 03:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/11/26 03:24	200.0	177.6	179.8		|R-A|/Span * 100		1.1
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/11/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/11/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/11/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	09/11/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/12/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/12/26 02:24	200.0	180.4	177.4		|R-A|/Span * 100		1.5
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/12/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/12/26 02:19	30.0	20.7	20.7		|R-A|/Span * 100		0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/12/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	09/12/26 02:24	200.0	177.6	178.2		|R-A|/Span * 100		0.3

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/12/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	09/12/26 02:19	30.0	21.4	21.6		|R-A|/Span * 100		0.7
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/12/26 03:14	200.0	0.0	1.5		|R-A|/Span * 100		0.8
	High	09/12/26 03:24	200.0	181.3	180.9		|R-A|/Span * 100		0.2
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/12/26 03:14	10.0	0.0	0.3		|R-A|/Span * 100		3.0
	High	09/12/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/12/26 03:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/12/26 03:24	200.0	180.4	176.4		|R-A|/Span * 100		2.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/12/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/12/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/12/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	09/12/26 03:19	18.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/12/26 03:14	200.0	0.0	0.8		|R-A|/Span * 100		0.4
	High	09/12/26 03:24	200.0	178.2	182.4		|R-A|/Span * 100		2.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/12/26 03:14	10.0	0.0	0.3		|R-A|/Span * 100		3.0
	High	09/12/26 03:19	10.0	9.0	9.2		|R-A|/Span * 100		2.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/12/26 03:14	200.0	0.0	0.6		|R-A|/Span * 100		0.3
	High	09/12/26 03:24	200.0	177.6	179.3		|R-A|/Span * 100		0.9
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/12/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/12/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/12/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	09/12/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/13/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/13/26 02:24	200.0	180.4	177.3		|R-A|/Span * 100		1.6

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/13/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/13/26 02:19	30.0	20.7	20.7		|R-A|/Span * 100		0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/13/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	09/13/26 02:24	200.0	177.6	178.0		|R-A|/Span * 100		0.2
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/13/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	09/13/26 02:19	30.0	21.4	21.6		|R-A|/Span * 100		0.7
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/13/26 03:14	200.0	0.0	1.5		|R-A|/Span * 100		0.8
	High	09/13/26 03:24	200.0	181.3	180.5		|R-A|/Span * 100		0.4
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/13/26 03:14	10.0	0.0	0.3		|R-A|/Span * 100		3.0
	High	09/13/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/13/26 03:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/13/26 03:24	200.0	180.4	176.6		|R-A|/Span * 100		1.9
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/13/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/13/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/13/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	09/13/26 03:19	18.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/13/26 03:14	200.0	0.0	0.8		|R-A|/Span * 100		0.4
	High	09/13/26 03:24	200.0	178.2	181.7		|R-A|/Span * 100		1.8
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/13/26 03:14	10.0	0.0	0.4		|R-A|/Span * 100		4.0
	High	09/13/26 03:19	10.0	9.0	9.2		|R-A|/Span * 100		2.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/13/26 03:14	200.0	0.0	0.2		|R-A|/Span * 100		0.1
	High	09/13/26 03:24	200.0	177.6	179.4		|R-A|/Span * 100		0.9
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/13/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/13/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/13/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	09/13/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/14/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/14/26 02:24	200.0	180.4	177.6		|R-A|/Span * 100		1.4
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/14/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/14/26 02:19	30.0	20.7	20.7		|R-A|/Span * 100		0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/14/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	09/14/26 02:24	200.0	177.6	178.2		|R-A|/Span * 100		0.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/14/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	09/14/26 02:19	30.0	21.4	21.7		|R-A|/Span * 100		1.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/14/26 03:14	200.0	0.0	1.7		|R-A|/Span * 100		0.9
	High	09/14/26 03:24	200.0	181.3	180.7		|R-A|/Span * 100		0.3
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/14/26 03:14	10.0	0.0	0.3		|R-A|/Span * 100		3.0
	High	09/14/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/14/26 03:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/14/26 03:24	200.0	180.4	176.4		|R-A|/Span * 100		2.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/14/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/14/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/14/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	09/14/26 03:19	18.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/14/26 03:14	200.0	0.0	0.7		|R-A|/Span * 100		0.4
	High	09/14/26 03:24	200.0	178.2	182.0		|R-A|/Span * 100		1.9
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/14/26 03:14	10.0	0.0	0.3		|R-A|/Span * 100		3.0
	High	09/14/26 03:19	10.0	9.0	9.2		|R-A|/Span * 100		2.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/14/26 03:14	200.0	0.0	0.2		|R-A|/Span * 100		0.1
	High	09/14/26 03:24	200.0	177.6	179.0		|R-A|/Span * 100		0.7
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/14/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/14/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/14/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	09/14/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/15/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/15/26 02:24	200.0	180.4	177.9		|R-A|/Span * 100		1.3
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/15/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/15/26 02:19	30.0	20.7	20.7		|R-A|/Span * 100		0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/15/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	09/15/26 02:24	200.0	177.6	178.2		|R-A|/Span * 100		0.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/15/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	09/15/26 02:19	30.0	21.4	21.6		|R-A|/Span * 100		0.7
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/15/26 03:14	200.0	0.0	1.6		|R-A|/Span * 100		0.8
	High	09/15/26 03:24	200.0	181.3	181.8		|R-A|/Span * 100		0.3
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/15/26 03:14	10.0	0.0	0.3		|R-A|/Span * 100		3.0
	High	09/15/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/15/26 03:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/15/26 03:24	200.0	180.4	177.0		|R-A|/Span * 100		1.7
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/15/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/15/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/15/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	09/15/26 03:19	18.0	0.0	-0.1		|R-A|		0.1

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/15/26 03:14	200.0	0.0	0.7		|R-A|/Span * 100		0.4
	High	09/15/26 03:24	200.0	178.2	182.3		|R-A|/Span * 100		2.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/15/26 03:14	10.0	0.0	0.4		|R-A|/Span * 100		4.0
	High	09/15/26 03:19	10.0	9.0	9.2		|R-A|/Span * 100		2.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/15/26 03:14	200.0	0.0	0.4		|R-A|/Span * 100		0.2
	High	09/15/26 03:24	200.0	177.6	179.9		|R-A|/Span * 100		1.2
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/15/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/15/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/15/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	09/15/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/16/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/16/26 02:24	200.0	180.4	177.8		|R-A|/Span * 100		1.3
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/16/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/16/26 02:19	30.0	20.7	20.7		|R-A|/Span * 100		0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/16/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	09/16/26 02:24	200.0	177.6	177.8		|R-A|/Span * 100		0.1
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/16/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	09/16/26 02:19	30.0	21.4	21.6		|R-A|/Span * 100		0.7
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/16/26 03:14	200.0	0.0	1.7		|R-A|/Span * 100		0.9
	High	09/16/26 03:24	200.0	181.3	181.4		|R-A|/Span * 100		0.1
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/16/26 03:14	10.0	0.0	0.3		|R-A|/Span * 100		3.0
	High	09/16/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/16/26 03:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/16/26 03:24	200.0	180.4	176.8		|R-A|/Span * 100		1.8

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/16/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/16/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/16/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	09/16/26 03:19	18.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/16/26 03:14	200.0	0.0	0.7		|R-A|/Span * 100		0.4
	High	09/16/26 03:24	200.0	178.2	182.0		|R-A|/Span * 100		1.9
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/16/26 03:14	10.0	0.0	0.4		|R-A|/Span * 100		4.0
	High	09/16/26 03:19	10.0	9.0	9.2		|R-A|/Span * 100		2.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/16/26 03:14	200.0	0.0	0.2		|R-A|/Span * 100		0.1
	High	09/16/26 03:24	200.0	177.6	179.1		|R-A|/Span * 100		0.8
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/16/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/16/26 03:19	10.0	9.4	9.3		|R-A|/Span * 100		1.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/16/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	09/16/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/17/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/17/26 02:24	200.0	180.4	176.6		|R-A|/Span * 100		1.9
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/17/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/17/26 02:19	30.0	20.7	20.6		|R-A|/Span * 100		0.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/17/26 02:14	200.0	0.0	-0.5		|R-A|/Span * 100		0.3
	High	09/17/26 02:24	200.0	177.6	177.2		|R-A|/Span * 100		0.2
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/17/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	09/17/26 02:19	30.0	21.4	21.4		|R-A|/Span * 100		0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/17/26 03:14	200.0	0.0	1.5		|R-A|/Span * 100		0.8
	High	09/17/26 03:24	200.0	181.3	180.6		|R-A|/Span * 100		0.4

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	09/17/26 03:14	10.0	0.0	0.3		|R-A|/Span * 100		3.0
	High	09/17/26 03:19	10.0	9.2	9.3		|R-A|/Span * 100		1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	09/17/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/17/26 03:24	200.0	180.4	176.7		|R-A|/Span * 100		1.9
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	09/17/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/17/26 03:19	10.0	9.2	9.0		|R-A|/Span * 100		2.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	High	09/17/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	09/17/26 03:19	18.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	09/17/26 03:14	200.0	0.0	0.4		|R-A|/Span * 100		0.2
	High	09/17/26 03:24	200.0	178.2	177.9		|R-A|/Span * 100		0.2
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	09/17/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/17/26 03:19	10.0	9.0	9.0		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	09/17/26 03:14	200.0	0.0	-0.2		|R-A|/Span * 100		0.1
	High	09/17/26 03:24	200.0	177.6	178.0		|R-A|/Span * 100		0.2
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	09/17/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/17/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	High	09/17/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	09/17/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	09/18/26 02:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/18/26 02:24	200.0	180.4	176.6		|R-A|/Span * 100		1.9
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	09/18/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/18/26 02:19	30.0	20.7	20.6		|R-A|/Span * 100		0.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	09/18/26 02:14	200.0	0.0	-0.5		|R-A|/Span * 100		0.3
	High	09/18/26 02:24	200.0	177.6	175.3		|R-A|/Span * 100		1.2

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/18/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	09/18/26 02:19	30.0	21.4	21.1		|R-A|/Span * 100		1.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/18/26 03:14	200.0	0.0	1.5		|R-A|/Span * 100		0.8
	High	09/18/26 03:24	200.0	181.3	180.3		|R-A|/Span * 100		0.5
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/18/26 03:14	10.0	0.0	0.3		|R-A|/Span * 100		3.0
	High	09/18/26 03:19	10.0	9.2	9.3		|R-A|/Span * 100		1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/18/26 03:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/18/26 03:24	200.0	180.4	176.5		|R-A|/Span * 100		2.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/18/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/18/26 03:19	10.0	9.2	9.0		|R-A|/Span * 100		2.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/18/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	09/18/26 03:19	18.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/18/26 03:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/18/26 03:24	200.0	178.2	177.0		|R-A|/Span * 100		0.6
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/18/26 03:14	10.0	0.0	-0.3		|R-A|/Span * 100		3.0
	High	09/18/26 03:19	10.0	9.0	8.9		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/18/26 03:14	200.0	0.0	0.3		|R-A|/Span * 100		0.2
	High	09/18/26 03:24	200.0	177.6	178.4		|R-A|/Span * 100		0.4
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/18/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/18/26 03:19	10.0	9.4	9.5		|R-A|/Span * 100		1.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/18/26 03:14	21.0	18.0	18.1		|R-A|		0.1
	Zero	09/18/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/19/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/19/26 02:24	200.0	180.4	176.6		|R-A|/Span * 100		1.9

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/19/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/19/26 02:19	30.0	20.7	20.7		|R-A|/Span * 100		0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/19/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	09/19/26 02:24	200.0	177.6	175.3		|R-A|/Span * 100		1.2
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/19/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	09/19/26 02:19	30.0	21.4	21.2		|R-A|/Span * 100		0.7
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/19/26 03:14	200.0	0.0	1.7		|R-A|/Span * 100		0.9
	High	09/19/26 03:24	200.0	181.3	181.2		|R-A|/Span * 100		0.1
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/19/26 03:14	10.0	0.0	0.3		|R-A|/Span * 100		3.0
	High	09/19/26 03:19	10.0	9.2	9.3		|R-A|/Span * 100		1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/19/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/19/26 03:24	200.0	180.4	176.5		|R-A|/Span * 100		2.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/19/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/19/26 03:19	10.0	9.2	9.0		|R-A|/Span * 100		2.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/19/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	09/19/26 03:19	18.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/19/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/19/26 03:24	200.0	178.2	177.5		|R-A|/Span * 100		0.4
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/19/26 03:14	10.0	0.0	-0.3		|R-A|/Span * 100		3.0
	High	09/19/26 03:19	10.0	9.0	8.9		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/19/26 03:14	200.0	0.0	0.1		|R-A|/Span * 100		0.1
	High	09/19/26 03:24	200.0	177.6	178.6		|R-A|/Span * 100		0.5
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/19/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/19/26 03:19	10.0	9.4	9.5		|R-A|/Span * 100		1.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/19/26 03:14	21.0	18.0	18.1		|R-A|		0.1
	Zero	09/19/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/20/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/20/26 02:24	200.0	180.4	176.6		|R-A|/Span * 100		1.9
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/20/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/20/26 02:19	30.0	20.7	20.6		|R-A|/Span * 100		0.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/20/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	09/20/26 02:24	200.0	177.6	175.7		|R-A|/Span * 100		1.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/20/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	09/20/26 02:19	30.0	21.4	21.2		|R-A|/Span * 100		0.7
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/20/26 03:14	200.0	0.0	1.6		|R-A|/Span * 100		0.8
	High	09/20/26 03:24	200.0	181.3	181.2		|R-A|/Span * 100		0.1
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/20/26 03:14	10.0	0.0	0.3		|R-A|/Span * 100		3.0
	High	09/20/26 03:19	10.0	9.2	9.3		|R-A|/Span * 100		1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/20/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/20/26 03:24	200.0	180.4	176.6		|R-A|/Span * 100		1.9
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/20/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/20/26 03:19	10.0	9.2	9.0		|R-A|/Span * 100		2.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/20/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	09/20/26 03:19	18.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/20/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/20/26 03:24	200.0	178.2	177.5		|R-A|/Span * 100		0.4
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/20/26 03:14	10.0	0.0	-0.3		|R-A|/Span * 100		3.0
	High	09/20/26 03:19	10.0	9.0	8.9		|R-A|/Span * 100		1.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/20/26 03:14	200.0	0.0	0.2		|R-A|/Span * 100		0.1
	High	09/20/26 03:24	200.0	177.6	178.8		|R-A|/Span * 100		0.6
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/20/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/20/26 03:19	10.0	9.4	9.5		|R-A|/Span * 100		1.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/20/26 03:14	21.0	18.0	18.1		|R-A|		0.1
	Zero	09/20/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/21/26 02:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/21/26 02:24	200.0	180.4	176.8		|R-A|/Span * 100		1.8
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/21/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/21/26 02:19	30.0	20.7	20.6		|R-A|/Span * 100		0.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/21/26 02:14	200.0	0.0	-0.5		|R-A|/Span * 100		0.3
	High	09/21/26 02:24	200.0	177.6	175.9		|R-A|/Span * 100		0.9
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/21/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	09/21/26 02:19	30.0	21.4	21.2		|R-A|/Span * 100		0.7
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/21/26 03:14	200.0	0.0	1.7		|R-A|/Span * 100		0.9
	High	09/21/26 03:24	200.0	181.3	181.4		|R-A|/Span * 100		0.1
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/21/26 03:14	10.0	0.0	0.3		|R-A|/Span * 100		3.0
	High	09/21/26 03:19	10.0	9.2	9.3		|R-A|/Span * 100		1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/21/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/21/26 03:24	200.0	180.4	176.8		|R-A|/Span * 100		1.8
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/21/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/21/26 03:19	10.0	9.2	9.0		|R-A|/Span * 100		2.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/21/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	09/21/26 03:19	18.0	0.0	0.0		|R-A|		0.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/21/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/21/26 03:24	200.0	178.2	178.0		|R-A|/Span * 100		0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/21/26 03:14	10.0	0.0	-0.3		|R-A|/Span * 100		3.0
	High	09/21/26 03:19	10.0	9.0	9.0		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/21/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/21/26 03:24	200.0	177.6	178.9		|R-A|/Span * 100		0.7
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/21/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/21/26 03:19	10.0	9.4	9.5		|R-A|/Span * 100		1.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/21/26 03:14	21.0	18.0	18.1		|R-A|		0.1
	Zero	09/21/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/22/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/22/26 02:24	200.0	180.4	176.8		|R-A|/Span * 100		1.8
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/22/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/22/26 02:19	30.0	20.7	20.6		|R-A|/Span * 100		0.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/22/26 02:14	200.0	0.0	-0.5		|R-A|/Span * 100		0.3
	High	09/22/26 02:24	200.0	177.6	175.7		|R-A|/Span * 100		1.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/22/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	09/22/26 02:19	30.0	21.4	21.2		|R-A|/Span * 100		0.7
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/22/26 03:14	200.0	0.0	1.6		|R-A|/Span * 100		0.8
	High	09/22/26 03:24	200.0	181.3	181.2		|R-A|/Span * 100		0.1
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/22/26 03:14	10.0	0.0	0.3		|R-A|/Span * 100		3.0
	High	09/22/26 03:19	10.0	9.2	9.3		|R-A|/Span * 100		1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/22/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/22/26 03:24	200.0	180.4	176.5		|R-A|/Span * 100		2.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/22/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/22/26 03:19	10.0	9.2	9.0		|R-A|/Span * 100		2.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/22/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	09/22/26 03:19	18.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/22/26 03:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/22/26 03:24	200.0	178.2	177.8		|R-A|/Span * 100		0.2
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/22/26 03:14	10.0	0.0	-0.3		|R-A|/Span * 100		3.0
	High	09/22/26 03:19	10.0	9.0	8.9		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/22/26 03:14	200.0	0.0	0.3		|R-A|/Span * 100		0.2
	High	09/22/26 03:24	200.0	177.6	178.8		|R-A|/Span * 100		0.6
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/22/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/22/26 03:19	10.0	9.4	9.5		|R-A|/Span * 100		1.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/22/26 03:14	21.0	18.0	18.1		|R-A|		0.1
	Zero	09/22/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/23/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/23/26 02:24	200.0	180.4	176.4		|R-A|/Span * 100		2.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/23/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/23/26 02:19	30.0	20.7	20.5		|R-A|/Span * 100		0.7
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/23/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	09/23/26 02:24	200.0	177.6	175.5		|R-A|/Span * 100		1.1
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/23/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	09/23/26 02:19	30.0	21.4	21.1		|R-A|/Span * 100		1.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/23/26 03:14	200.0	0.0	1.6		|R-A|/Span * 100		0.8
	High	09/23/26 03:24	200.0	181.3	181.0		|R-A|/Span * 100		0.2

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/23/26 03:14	10.0	0.0	0.3		|R-A|/Span * 100		3.0
	High	09/23/26 03:19	10.0	9.2	9.3		|R-A|/Span * 100		1.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/23/26 03:14	200.0	0.0	0.1		|R-A|/Span * 100		0.1
	High	09/23/26 03:24	200.0	180.4	176.8		|R-A|/Span * 100		1.8
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/23/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/23/26 03:19	10.0	9.2	9.0		|R-A|/Span * 100		2.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/23/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	09/23/26 03:19	18.0	0.0	0.0		|R-A|		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/23/26 03:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/23/26 03:24	200.0	178.2	177.7		|R-A|/Span * 100		0.3
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/23/26 03:14	10.0	0.0	-0.3		|R-A|/Span * 100		3.0
	High	09/23/26 03:19	10.0	9.0	8.9		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/23/26 03:14	200.0	0.0	0.3		|R-A|/Span * 100		0.2
	High	09/23/26 03:24	200.0	177.6	178.3		|R-A|/Span * 100		0.4
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/23/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/23/26 03:19	10.0	9.4	9.5		|R-A|/Span * 100		1.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/23/26 03:14	21.0	18.0	18.1		|R-A|		0.1
	Zero	09/23/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/24/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/24/26 02:24	200.0	180.4	177.1		|R-A|/Span * 100		1.7
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/24/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/24/26 02:19	30.0	20.7	20.7		|R-A|/Span * 100		0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/24/26 02:14	200.0	0.0	-0.5		|R-A|/Span * 100		0.3
	High	09/24/26 02:24	200.0	177.6	175.8		|R-A|/Span * 100		0.9

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/24/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	09/24/26 02:19	30.0	21.4	21.2		|R-A|/Span * 100		0.7
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/24/26 03:14	200.0	0.0	1.6		|R-A|/Span * 100		0.8
	High	09/24/26 03:24	200.0	181.3	181.1		|R-A|/Span * 100		0.1
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/24/26 03:14	10.0	0.0	0.3		|R-A|/Span * 100		3.0
	High	09/24/26 03:19	10.0	9.2	9.2		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/24/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/24/26 03:24	200.0	180.4	177.0		|R-A|/Span * 100		1.7
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/24/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/24/26 03:19	10.0	9.2	9.1		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/24/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	09/24/26 03:19	18.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/24/26 03:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/24/26 03:24	200.0	178.2	177.7		|R-A|/Span * 100		0.3
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/24/26 03:14	10.0	0.0	-0.3		|R-A|/Span * 100		3.0
	High	09/24/26 03:19	10.0	9.0	8.9		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/24/26 03:14	200.0	0.0	0.5		|R-A|/Span * 100		0.3
	High	09/24/26 03:24	200.0	177.6	179.0		|R-A|/Span * 100		0.7
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/24/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/24/26 03:19	10.0	9.4	9.5		|R-A|/Span * 100		1.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/24/26 03:14	21.0	18.0	18.1		|R-A|		0.1
	Zero	09/24/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/25/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/25/26 02:24	200.0	177.2	173.2		|R-A|/Span * 100		2.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/25/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/25/26 02:19	30.0	20.7	20.7		|R-A|/Span * 100		0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/25/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	09/25/26 02:24	200.0	177.6	177.1		|R-A|/Span * 100		0.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/25/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	09/25/26 02:19	30.0	21.2	21.1		|R-A|/Span * 100		0.3
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/25/26 03:14	200.0	0.0	1.6		|R-A|/Span * 100		0.8
	High	09/25/26 03:24	200.0	178.6	179.3		|R-A|/Span * 100		0.4
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/25/26 03:14	10.0	0.0	0.3		|R-A|/Span * 100		3.0
	High	09/25/26 03:19	10.0	8.9	9.1		|R-A|/Span * 100		2.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/25/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/25/26 03:24	200.0	177.2	176.4		|R-A|/Span * 100		0.4
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/25/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/25/26 03:19	10.0	9.3	9.0	>1x Alert	|R-A|/Span * 100		3.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/25/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	09/25/26 03:19	18.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/25/26 03:14	200.0	0.0	0.1		|R-A|/Span * 100		0.1
	High	09/25/26 03:24	200.0	178.2	177.9		|R-A|/Span * 100		0.2
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/25/26 03:14	10.0	0.0	-0.3		|R-A|/Span * 100		3.0
	High	09/25/26 03:19	10.0	9.0	9.0		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/25/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/25/26 03:24	200.0	177.6	178.4		|R-A|/Span * 100		0.4
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/25/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/25/26 03:19	10.0	9.4	9.5		|R-A|/Span * 100		1.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/25/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	09/25/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/26/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/26/26 02:24	200.0	177.2	176.6		|R-A|/Span * 100		0.3
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/26/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/26/26 02:19	30.0	20.7	20.7		|R-A|/Span * 100		0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/26/26 02:14	200.0	0.0	-0.5		|R-A|/Span * 100		0.3
	High	09/26/26 02:24	200.0	177.6	177.1		|R-A|/Span * 100		0.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/26/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	09/26/26 02:19	30.0	21.2	21.2		|R-A|/Span * 100		0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/26/26 03:14	200.0	0.0	1.3		|R-A|/Span * 100		0.7
	High	09/26/26 03:24	200.0	178.6	179.3		|R-A|/Span * 100		0.4
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/26/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/26/26 03:19	10.0	8.9	8.9		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/26/26 03:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/26/26 03:24	200.0	177.2	176.1		|R-A|/Span * 100		0.6
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/26/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/26/26 03:19	10.0	9.3	9.3		|R-A|/Span * 100		0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/26/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	09/26/26 03:19	18.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/26/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/26/26 03:24	200.0	178.2	178.2		|R-A|/Span * 100		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/26/26 03:14	10.0	0.0	-0.3		|R-A|/Span * 100		3.0
	High	09/26/26 03:19	10.0	9.0	9.0		|R-A|/Span * 100		0.0

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	09/26/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/26/26 03:24	200.0	177.6	178.1		|R-A|/Span * 100		0.3
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	09/26/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/26/26 03:19	10.0	9.4	9.5		|R-A|/Span * 100		1.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	High	09/26/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	09/26/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	09/27/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/27/26 02:24	200.0	177.2	175.7		|R-A|/Span * 100		0.8
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	09/27/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/27/26 02:19	30.0	20.7	20.4		|R-A|/Span * 100		1.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	09/27/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	09/27/26 02:24	200.0	177.6	175.5		|R-A|/Span * 100		1.1
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	09/27/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	09/27/26 02:19	30.0	21.2	20.8		|R-A|/Span * 100		1.3
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	09/27/26 03:14	200.0	0.0	1.4		|R-A|/Span * 100		0.7
	High	09/27/26 03:24	200.0	178.6	179.7		|R-A|/Span * 100		0.6
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	09/27/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/27/26 03:19	10.0	8.9	8.9		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	09/27/26 03:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/27/26 03:24	200.0	177.2	175.9		|R-A|/Span * 100		0.7
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	09/27/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/27/26 03:19	10.0	9.3	9.3		|R-A|/Span * 100		0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	High	09/27/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	09/27/26 03:19	18.0	0.0	-0.1		|R-A|		0.1

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	09/27/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/27/26 03:24	200.0	178.2	178.5		|R-A|/Span * 100		0.2
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	09/27/26 03:14	10.0	0.0	-0.3		|R-A|/Span * 100		3.0
	High	09/27/26 03:19	10.0	9.0	8.9		|R-A|/Span * 100		1.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	09/27/26 03:14	200.0	0.0	0.3		|R-A|/Span * 100		0.2
	High	09/27/26 03:24	200.0	177.6	178.0		|R-A|/Span * 100		0.2
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	09/27/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/27/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	High	09/27/26 03:14	21.0	18.0	18.1		|R-A|		0.1
	Zero	09/27/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	09/28/26 02:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/28/26 02:24	200.0	177.2	176.1		|R-A|/Span * 100		0.6
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	09/28/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/28/26 02:19	30.0	20.7	20.5		|R-A|/Span * 100		0.7
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	09/28/26 02:14	200.0	0.0	-0.5		|R-A|/Span * 100		0.3
	High	09/28/26 02:24	200.0	177.6	176.0		|R-A|/Span * 100		0.8
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	09/28/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	09/28/26 02:19	30.0	21.2	21.0		|R-A|/Span * 100		0.7
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	09/28/26 03:14	200.0	0.0	1.3		|R-A|/Span * 100		0.7
	High	09/28/26 03:24	200.0	178.6	179.7		|R-A|/Span * 100		0.6
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	09/28/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/28/26 03:19	10.0	8.9	8.9		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	09/28/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/28/26 03:24	200.0	177.2	175.9		|R-A|/Span * 100		0.7

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/28/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/28/26 03:19	10.0	9.3	9.3		|R-A|/Span * 100		0.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/28/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	09/28/26 03:19	18.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/28/26 03:14	200.0	0.0	0.1		|R-A|/Span * 100		0.1
	High	09/28/26 03:24	200.0	178.2	178.2		|R-A|/Span * 100		0.0
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/28/26 03:14	10.0	0.0	-0.3		|R-A|/Span * 100		3.0
	High	09/28/26 03:19	10.0	9.0	9.0		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/28/26 03:14	200.0	0.0	0.3		|R-A|/Span * 100		0.2
	High	09/28/26 03:24	200.0	177.6	177.7		|R-A|/Span * 100		0.1
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/28/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/28/26 03:19	10.0	9.4	9.4		|R-A|/Span * 100		0.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/28/26 03:14	21.0	18.0	18.1		|R-A|		0.1
	Zero	09/28/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/29/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/29/26 02:24	200.0	177.2	176.5		|R-A|/Span * 100		0.4
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/29/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/29/26 02:19	30.0	20.7	20.6		|R-A|/Span * 100		0.3
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/29/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	09/29/26 02:24	200.0	177.3	175.2		|R-A|/Span * 100		1.1
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/29/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	09/29/26 02:19	30.0	21.2	21.2		|R-A|/Span * 100		0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/29/26 03:14	200.0	0.0	1.3		|R-A|/Span * 100		0.7
	High	09/29/26 03:24	200.0	178.6	179.6		|R-A|/Span * 100		0.5

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	09/29/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/29/26 03:19	10.0	8.9	8.9		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	09/29/26 03:14	200.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/29/26 03:24	200.0	177.2	175.9		|R-A|/Span * 100		0.7
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	09/29/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/29/26 03:19	10.0	9.3	9.4		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	High	09/29/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	09/29/26 03:19	18.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	09/29/26 03:14	200.0	0.0	0.2		|R-A|/Span * 100		0.1
	High	09/29/26 03:24	200.0	178.1	178.4		|R-A|/Span * 100		0.2
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	09/29/26 03:14	10.0	0.0	-0.3		|R-A|/Span * 100		3.0
	High	09/29/26 03:19	10.0	9.0	9.0		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	09/29/26 03:14	200.0	0.0	0.1		|R-A|/Span * 100		0.1
	High	09/29/26 03:24	200.0	177.3	177.9		|R-A|/Span * 100		0.3
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	09/29/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/29/26 03:19	10.0	9.4	9.5		|R-A|/Span * 100		1.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	High	09/29/26 03:14	21.0	18.0	18.0		|R-A|		0.0
	Zero	09/29/26 03:19	21.0	0.0	0.0		|R-A|		0.0
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	09/30/26 02:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/30/26 02:24	200.0	177.2	176.9		|R-A|/Span * 100		0.2
Part 60	**CT1_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**		**Pass**	
	Zero	09/30/26 02:14	30.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/30/26 02:19	30.0	20.7	20.7		|R-A|/Span * 100		0.0
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**		**Pass**	
	Zero	09/30/26 02:14	200.0	0.0	-0.4		|R-A|/Span * 100		0.2
	High	09/30/26 02:24	200.0	177.3	177.1		|R-A|/Span * 100		0.1

Daily Calibration Results

All Units

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/08/2026 10:30 **Location:** Roseville, CA

All Monitoring Sites, All Instruments, Daily, Integrity, Intensity, Interference, PEMSCAL, Sample Volume Checks

		Calibration Time	Span	Reference	Actual	Status	Performance Specification	Alt Spec	Deviation
Part 60	**CT2_NOXInlet_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/30/26 02:14	30.0	0.0	-0.1		|R-A|/Span * 100		0.3
	High	09/30/26 02:19	30.0	21.2	21.2		|R-A|/Span * 100		0.0
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/30/26 03:14	200.0	0.0	1.5		|R-A|/Span * 100		0.8
	High	09/30/26 03:24	200.0	178.6	179.6		|R-A|/Span * 100		0.5
Part 60	**CT1_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/30/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/30/26 03:19	10.0	8.9	8.9		|R-A|/Span * 100		0.0
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/30/26 03:14	200.0	0.0	-0.1		|R-A|/Span * 100		0.1
	High	09/30/26 03:24	200.0	177.2	176.3		|R-A|/Span * 100		0.5
Part 75	**CT1_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/30/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/30/26 03:19	10.0	9.3	9.4		|R-A|/Span * 100		1.0
Part 75	**CT1_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/30/26 03:14	18.0	18.0	18.0		|R-A|		0.0
	Zero	09/30/26 03:19	18.0	0.0	-0.1		|R-A|		0.1
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/30/26 03:14	200.0	0.0	0.1		|R-A|/Span * 100		0.1
	High	09/30/26 03:24	200.0	178.1	178.8		|R-A|/Span * 100		0.4
Part 60	**CT2_CODualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/30/26 03:14	10.0	0.0	-0.3		|R-A|/Span * 100		3.0
	High	09/30/26 03:19	10.0	9.0	9.0		|R-A|/Span * 100		0.0
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	Zero	09/30/26 03:14	200.0	0.0	0.5		|R-A|/Span * 100		0.3
	High	09/30/26 03:24	200.0	177.3	178.4		|R-A|/Span * 100		0.6
Part 75	**CT2_NOXDualRg_P_Instrument**	**Used For QA**	**Range: Low**			**Calibration Result: Online**			**Pass**
	Zero	09/30/26 03:14	10.0	0.0	0.0		|R-A|/Span * 100		0.0
	High	09/30/26 03:19	10.0	9.4	9.5		|R-A|/Span * 100		1.0
Part 75	**CT2_O2D_P_Instrument**	**Used For QA**	**Range: High**			**Calibration Result: Online**			**Pass**
	High	09/30/26 03:14	21.0	18.0	18.1		|R-A|		0.1
	Zero	09/30/26 03:19	21.0	0.0	0.0		|R-A|		0.0