| DOCKETED | |
|---|---|
| **Docket Number:** | 03-AFC-01C |
| **Project Title:** | Roseville Energy Park Compliance |
| **TN #:** | 273255 |
| **Document Title:** | Roseville Energy Park Quarterly Air Quality Report - Q3 2026 - Part 23s |
| **Description:** | N/A |
| **Filer:** | Roseville Electric Compliance |
| **Organization:** | Roseville Electric |
| **Submitter Role:** | Public Agency |
| **Submission Date:** | 10/28/2026 7:52:54 AM |
| **Docketed Date:** | 10/28/2026 |

## RegPerfect CEMS Logs

| Log Time | Operator | Initials | Description | Tags | Files |
|---|---|---|---|---|---|
| 09/28/2026 09:11 | cro-operator | DCC | CT2- CHANGED OUT HIGH NOX/CO CAL GAS BOTTLE. 177.3PPM/178.1PPM CYLINDER ID 225702032 EXPIRES 8/17/2034 | | |
| 09/25/2026 07:37 | cro-operator | SM | CT1 - LO NOX HAD 1X ALERT. TRUED UP STACK NOX ANALYZER. | | |
| 09/24/2026 13:26 | cro-operator | DCC | CT2- CHANGED OUT SCR LOW NOX/CO CAL GAS BOTTLE. NOX 21.15 PPM/CO 19.94 PPM. CYLINDER ID CC362946 EXPIRES 09/02/2029 | | |
| 09/24/2026 13:24 | cro-operator | DCC | CT1- CHANGED OUT LOW NOX/CO CAL GAS BOTTLE. NOX 9.265 PPM/CO 8.949 PPM. CYLINDER ID CC205497 EXPIRES 09/02/2029 | | |
| 09/24/2026 13:22 | cro-operator | DCC | CT1- CHANGED OUT HIGH NOX/CO CAL GAS BOTTLE. NOX 177.2 PPM/CO 178.6 PPM. CYLINDER ID EB0032615 EXPIRES 08/17/2034 | | |
| 09/17/2026 16:50 | cro-operator | JBF | CHANGED O2 ON CT 2 / ACT CONC 18.02 / CYLINDER # 225701002 / CERT DATE 8-3-26 / EXP DATE 8-2-34 | | |
| 09/15/2026 10:20 | cro-operator | SM | CT6 - SEMI ANUAL MAINT PM. REPLACED DFU FILTER FOR STACK AND INLET NOX ANALYZER. SPANNED GAS. | | |
| 09/11/2026 09:17 | cro-operator | DCC | CT1- CHANGED OUT O2 CAL GAS BOTTLE. 17.99% CYLINDER ID 252108155 EXPIRES 08/10/2034 | | |
| 09/11/2026 07:26 | cro-operator | SM | CT5 - ON 9-10-26 PERFOMED SEMI ANNUAL MAINTENANCE PM. REPLACED DFU FILTER FOR INLET AND STACK NOX ANALYZER. SPANNED GAS. | | |
| 09/09/2026 10:34 | cro-operator | DCC | CT6- CHANGED DAILY 450 PPM NOX BOTTLE. CONCENTRATION 435.6 PPM, CYLINDER ID EB0149604, EXPIRES 9/18/2033 | | |
| 09/09/2026 06:52 | cro-operator | DWN | NH3 CORRECTION FACTOR UPDATED<br>CT1 - 0.295<br>CT2 - 0.311<br>CT5 - 0.231<br>CT6 - 0.233 | | |
| 09/08/2026 11:38 | cro- | DCC | CT6- CHANGED OUT 900 PPM CO CAL GAS BOTTLE. CONCENTRATION 923.1 | | |

| Log Time | Operator | Initials | Description | Tags | Files |
|---|---|---|---|---|---|
| | operator | | PPM, CYLINDER ID CC181405, EXPIRES 03/25/2034 | | |
| 09/08/2026 11:36 | cro-operator | DCC | CT5- CHANGED OUT 900 PPM CO CAL GAS BOTTLE. CONCENTRATION 918.1 PPM, CYLINDER ID CC749717, EXPIRES 06/13/2033. | | |
| 09/07/2026 06:43 | cro-operator | DWN | UPDATED MONTHLY GCV FOR SEPTEMBER TO 104,800 FOR ALL UNITS | | |
| 09/01/2026 15:23 | cro-operator | KS | CT5-PREFORMED MONTHLY CEMS CHECKS AND PREFORMED MANUAL THEN AUTO CALIBRATION CHECKS | | |
| 09/01/2026 15:23 | cro-operator | KS | CT6-PREFORMED MONTHLY CEMS CHECKS AND PREFORMED MANUAL THEN AUTO CALIBRATION CHECKS | | |
| 08/29/2026 11:10 | cro-operator | GAB | CT2 CHANGED OUT HIGH NOX/CO BOTTLE 178.2/177.6 CYLINDER CC742395 EXP. 08/18/2034 | | |
| 08/27/2026 14:08 | cro-operator | DC | CT2- CHANGED SCR INLET LOW NOX/LOW CO BOTTLE. NOX 21.4 PPM, CO 20.21 PPM. BOTTLE ID 225702027, EXPIRES 08/05/2029 | | |
| 08/23/2026 24:26 | cro-operator | DC | CT2- CHANGED 02 BOTTLE TO ID: 252108165, CON: 18%, EXP: 08/10/34 | | |
| 08/17/2026 08:43 | cro-operator | DCC | CT2 - CHANGED OUT LOW NOX/CO DAILY CAL GAS BOTTLE 9.419 PPM/8.986 PPM. CYLINDER #EB0102296 EXPIRES 10/13/2028 | | |
| 08/17/2026 08:40 | cro-operator | DCC | CT1 CHANGED OUT HIGH NOX/CO DAILY CAL GAS BOTTLE. 180.4PPM/181.3PPM. CYLINDER #EB0037675 EXPIRES 11/04/2033 | | |
| 08/13/2026 09:11 | cro-operator | DWN | UPDATED GCV FOR AUGUST TO 105,100 FOR ALL UNITS | | |
| 08/05/2026 11:46 | cro-operator | JB | CHANGED OUT CT1 OXYGEN-18% 08/05/2026<br>CYLINDER # 225104089<br>DATE CERT 10/06/2025<br>DATE EXP 10/05/2033 | | |
| 08/03/2026 15:08 | cro-operator | JBF | CT6 - CHANGED DAILY/QUARTLY BOTTLE CO 18.64 PPM & O2 22.52 PPM | | |

| Log Time | Operator | Initials | Description | Tags | Files |
|---|---|---|---|---|---|
| 08/03/2026 15:07 | cro-operator | JBF | CT6 - CHANGED DAILY NOX BOTTLE 9.509 PPM | | |
| 08/01/2026 20:21 | cro-operator | PJ | CT1-CHANGED LO NOX/CO CYL #EB0144535 NOX9.168/ CO 9.184 EXP 07/29/2028 | | |
| 07/28/2026 12:04 | cro-operator | JF | CT2 - REPLACED DAILY CEMS NOX. NOX 20.38 | | |
| 07/28/2026 11:58 | cro-operator | JF | REPLACED UNIT 2 CEMS DAILY HIGH SPAN NOX/CO. NOX - 179.8, CO - 180.9 | | |
| 07/28/2026 10:16 | cro-operator | SM | CT2 - PERFORMED MANUAL CAL FOR INLET NOX | | |
| 07/28/2026 10:14 | cro-operator | KS | CT1- PREFORMED CGA TEST FOR CO/LOW | | |
| 07/27/2026 11:16 | cro-operator | KS | CT2- PREFORMED LINEARITY TEST FOR O2. PASSED WITH NO ISSUES. | | |
| 07/27/2026 11:13 | cro-operator | KS | CT2- CHANGED NOX AND CO HIGH LINEARITY MID BOTTLE. CYLINDER #EB0153112. EXPIRATION DATE 6/10/2033. | | |
| 07/27/2026 24:42 | cro-operator | DC | CT2- CHANGED O2 BOTTLE TO ID:225104102, CON: 18.02 O2, EXP: 08/07/2033 | | |
| 07/24/2026 24:12 | cro-operator | DC | CT1- CHANGED SCR LOW INLET NOW/CO BOTTLE, CON: 20.66 TOTAL NITROGEN OXIDES, ID: CC118014, EXP: 05/19/29 | | |
| 07/22/2026 09:12 | cro-operator | KS | CT6-PREFORMED CGA TESTING FOR CO/HIGH AND CO/LOW | | |
| 07/22/2026 09:11 | cro-operator | KS | CT5- PREFORMED CGA TESTING FOR CO/HIGH AND CO/LOW | | |
| 07/16/2026 12:45 | cro-operator | DWN | UPDATED GCV FOR JULY TO 105,300 FOR ALL UNITS | | |
| 07/15/2026 21:39 | cro- | RC | CT1 - REPLACED HIGH NO/CO BOTTLE 177.9/179 PPM, CYLINDER# CC7336, EXP | | |

| Log Time | Operator | Initials | Description | Tags | Files |
|---|---|---|---|---|---|
| | operator | | DATE 09/16/33 | | |
| 07/14/2026 10:10 | cro-operator | KS | CT6-CEMS OOS TO PREFORM MANUAL CALIBRATIONS AND AUTO CAL CHECK. | | |
| 07/14/2026 10:09 | cro-operator | KS | CT5-CEMS OOS TO PREFORM MANUAL CALIBRATIONS AND AUTO CAL CHECK. | | |
| 07/01/2026 10:18 | cro-operator | KS | CT6- PREFORMED MONTHLY CEMS CHECKS AND MANUAL/AUTO CALIBRATION. | | |
| 07/01/2026 10:17 | cro-operator | KS | CT5- PREFORMED MONTHLY CEMS CHECKS AND MANUAL/AUTO CALIBRATION. | | |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 07/01/2026 00:00 | 1 | 0 | 46 | 0 | 0 |
| 07/01/2026 01:00 | 1 | 0 | 46 | 0 | 0 |
| 07/01/2026 02:00 | 1 | 0 | 46 | 0 | 0 |
| 07/01/2026 03:00 | 1 | 0 | 46 | 0 | 0 |
| 07/01/2026 04:00 | 1 | 0 | 46 | 0 | 0 |
| 07/01/2026 05:00 | 1 | 0 | 46 | 0 | 0 |
| 07/01/2026 06:00 | 1 | 0 | 46 | 0 | 0 |
| 07/01/2026 07:00 | 1 | 0 | 46 | 0 | 0 |
| 07/01/2026 08:00 | 1 | 0 | 46 | 0 | 0 |
| 07/01/2026 09:00 | 1 | 0 | 46 | 0 | 0 |
| 07/01/2026 10:00 | 1 | 0 | 46 | 0 | 0 |
| 07/01/2026 11:00 | 1 | 0 | 46 | 0 | 0 |
| 07/01/2026 12:00 | 1 | 0 | 46 | 0 | 0 |
| 07/01/2026 13:00 | 1 | 0 | 46 | 0 | 0 |
| 07/01/2026 14:00 | 1 | 0 | 46 | 0 | 0 |
| 07/01/2026 15:00 | 1 | 0 | 46 | 0 | 0 |
| 07/01/2026 16:00 | 1 | 0 | 46 | 0 | 0 |
| 07/01/2026 17:00 | 1 | 0 | 47 | 0 | 0 |
| 07/01/2026 18:00 | 1 | 0 | 50 | 0 | 0 |
| 07/01/2026 19:00 | 1 | 0 | 53 | 0 | 0 |
| 07/01/2026 20:00 | 1 | 0 | 54 | 0 | 0 |
| 07/01/2026 21:00 | 1 | 0 | 52 | 0 | 0 |
| 07/01/2026 22:00 | 1 | 0 | 50 | 0 | 0 |
| 07/01/2026 23:00 | 1 | 0 | 49 | 0 | 0 |
| Average/Sum#: | 24 # | 0 | 47 | 0 | 0 |
| Minimum: | 1 | 0 | 46 | 0 | 0 |
| Maximum: | 1 | 0 | 54 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 07/02/2026 00:00 | 1 | 0 | 48 | 0 | 0 |
| 07/02/2026 01:00 | 1 | 0 | 47 | 0 | 0 |
| 07/02/2026 02:00 | 1 | 0 | 46 | 0 | 0 |
| 07/02/2026 03:00 | 1 | 0 | 46 | 0 | 0 |
| 07/02/2026 04:00 | 1 | 0 | 47 | 0 | 0 |
| 07/02/2026 05:00 | 1 | 0 | 46 | 0 | 0 |
| 07/02/2026 06:00 | 1 | 0 | 46 | 0 | 0 |
| 07/02/2026 07:00 | 1 | 0 | 46 | 0 | 0 |
| 07/02/2026 08:00 | 1 | 0 | 46 | 0 | 0 |
| 07/02/2026 09:00 | 1 | 0 | 46 | 0 | 0 |
| 07/02/2026 10:00 | 1 | 0 | 46 | 0 | 0 |
| 07/02/2026 11:00 | 1 | 0 | 46 | 0 | 0 |
| 07/02/2026 12:00 | 1 | 0 | 46 | 0 | 0 |
| 07/02/2026 13:00 | 1 | 0 | 46 | 0 | 0 |
| 07/02/2026 14:00 | 1 | 0 | 46 | 0 | 0 |
| 07/02/2026 15:00 | 1 | 0 | 46 | 0 | 0 |
| 07/02/2026 16:00 | 1 | 0 | 46 | 0 | 0 |
| 07/02/2026 17:00 | 1 | 0 | 47 | 0 | 0 |
| 07/02/2026 18:00 | 1 | 0 | 47 | 0 | 0 |
| 07/02/2026 19:00 | 1 | 0 | 47 | 0 | 0 |
| 07/02/2026 20:00 | 1 | 0 | 46 | 0 | 0 |
| 07/02/2026 21:00 | 1 | 0 | 46 | 0 | 0 |
| 07/02/2026 22:00 | 1 | 0 | 46 | 0 | 0 |
| 07/02/2026 23:00 | 1 | 5 | 48 | 0 | 0 |
| Average/Sum#: | 24 # | 0 | 46 | 0 | 0 |
| Minimum: | 1 | 0 | 46 | 0 | 0 |
| Maximum: | 1 | 5 | 48 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 07/03/2026 00:00 | 1 | 20 | 48 | 0 | 0 |
| 07/03/2026 01:00 | 1 | 35 | 48 | 0 | 0 |
| 07/03/2026 02:00 | 1 | 45 | 46 | 0 | 0 |
| 07/03/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 07/03/2026 04:00 | 1 | 40 | 47 | 0 | 0 |
| 07/03/2026 05:00 | 1 | 25 | 47 | 0 | 0 |
| 07/03/2026 06:00 | 1 | 9 | 47 | 0 | 0 |
| 07/03/2026 07:00 | 1 | 0 | 46 | 0 | 0 |
| 07/03/2026 08:00 | 1 | 0 | 46 | 0 | 0 |
| 07/03/2026 09:00 | 1 | 0 | 47 | 0 | 0 |
| 07/03/2026 10:00 | 1 | 0 | 47 | 0 | 0 |
| 07/03/2026 11:00 | 1 | 0 | 47 | 0 | 0 |
| 07/03/2026 12:00 | 1 | 0 | 47 | 0 | 0 |
| 07/03/2026 13:00 | 1 | 0 | 47 | 0 | 0 |
| 07/03/2026 14:00 | 1 | 0 | 47 | 0 | 0 |
| 07/03/2026 15:00 | 1 | 0 | 47 | 0 | 0 |
| 07/03/2026 16:00 | 1 | 0 | 48 | 0 | 0 |
| 07/03/2026 17:00 | 1 | 0 | 48 | 0 | 0 |
| 07/03/2026 18:00 | 1 | 0 | 48 | 0 | 0 |
| 07/03/2026 19:00 | 1 | 0 | 48 | 0 | 0 |
| 07/03/2026 20:00 | 1 | 0 | 47 | 0 | 0 |
| 07/03/2026 21:00 | 1 | 0 | 47 | 0 | 0 |
| 07/03/2026 22:00 | 1 | 0 | 47 | 0 | 0 |
| 07/03/2026 23:00 | 1 | 0 | 47 | 0 | 0 |
| Average/Sum#: | 24 # | 9 | 47 | 0 | 0 |
| Minimum: | 1 | 0 | 46 | 0 | 0 |
| Maximum: | 1 | 46 | 48 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 07/04/2026 00:00 | 1 | 5 | 49 | 0 | 0 |
| 07/04/2026 01:00 | 1 | 20 | 49 | 0 | 0 |
| 07/04/2026 02:00 | 1 | 35 | 48 | 0 | 0 |
| 07/04/2026 03:00 | 1 | 46 | 46 | 0 | 0 |
| 07/04/2026 04:00 | 1 | 46 | 47 | 0 | 0 |
| 07/04/2026 05:00 | 1 | 40 | 50 | 0 | 0 |
| 07/04/2026 06:00 | 1 | 24 | 52 | 0 | 0 |
| 07/04/2026 07:00 | 1 | 9 | 52 | 0 | 0 |
| 07/04/2026 08:00 | 1 | 0 | 49 | 0 | 0 |
| 07/04/2026 09:00 | 1 | 0 | 47 | 0 | 0 |
| 07/04/2026 10:00 | 1 | 0 | 46 | 0 | 0 |
| 07/04/2026 11:00 | 1 | 0 | 46 | 0 | 0 |
| 07/04/2026 12:00 | 1 | 0 | 47 | 0 | 0 |
| 07/04/2026 13:00 | 1 | 0 | 47 | 0 | 0 |
| 07/04/2026 14:00 | 1 | 0 | 47 | 0 | 0 |
| 07/04/2026 15:00 | 1 | 0 | 50 | 0 | 0 |
| 07/04/2026 16:00 | 1 | 0 | 53 | 0 | 0 |
| 07/04/2026 17:00 | 1 | 0 | 56 | 0 | 0 |
| 07/04/2026 18:00 | 1 | 8 | 54 | 0 | 0 |
| 07/04/2026 19:00 | 1 | 28 | 58 | 0 | 0 |
| 07/04/2026 20:00 | 1 | 47 | 60 | 0 | 0 |
| 07/04/2026 21:00 | 1 | 55 | 59 | 0 | 0 |
| 07/04/2026 22:00 | 1 | 51 | 53 | 0 | 0 |
| 07/04/2026 23:00 | 1 | 50 | 51 | 0 | 0 |
| Average/Sum#: | 24 # | 19 | 51 | 0 | 0 |
| Minimum: | 1 | 0 | 46 | 0 | 0 |
| Maximum: | 1 | 55 | 60 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 07/05/2026 00:00 | 1 | 48 | 53 | 0 | 0 |
| 07/05/2026 01:00 | 1 | 32 | 52 | 0 | 0 |
| 07/05/2026 02:00 | 1 | 14 | 49 | 0 | 0 |
| 07/05/2026 03:00 | 1 | 0 | 47 | 0 | 0 |
| 07/05/2026 04:00 | 1 | 0 | 47 | 0 | 0 |
| 07/05/2026 05:00 | 1 | 0 | 48 | 0 | 0 |
| 07/05/2026 06:00 | 1 | 0 | 49 | 0 | 0 |
| 07/05/2026 07:00 | 1 | 0 | 49 | 0 | 0 |
| 07/05/2026 08:00 | 1 | 0 | 47 | 0 | 0 |
| 07/05/2026 09:00 | 1 | 0 | 46 | 0 | 0 |
| 07/05/2026 10:00 | 1 | 0 | 45 | 0 | 0 |
| 07/05/2026 11:00 | 1 | 0 | 45 | 0 | 0 |
| 07/05/2026 12:00 | 1 | 0 | 44 | 0 | 0 |
| 07/05/2026 13:00 | 1 | 0 | 44 | 0 | 0 |
| 07/05/2026 14:00 | 1 | 0 | 44 | 0 | 0 |
| 07/05/2026 15:00 | 1 | 0 | 44 | 0 | 0 |
| 07/05/2026 16:00 | 1 | 0 | 45 | 0 | 0 |
| 07/05/2026 17:00 | 1 | 0 | 49 | 0 | 0 |
| 07/05/2026 18:00 | 1 | 0 | 53 | 0 | 0 |
| 07/05/2026 19:00 | 1 | 0 | 56 | 0 | 0 |
| 07/05/2026 20:00 | 1 | 0 | 56 | 0 | 0 |
| 07/05/2026 21:00 | 1 | 0 | 56 | 0 | 0 |
| 07/05/2026 22:00 | 1 | 0 | 53 | 0 | 0 |
| 07/05/2026 23:00 | 1 | 0 | 50 | 0 | 0 |
| Average/Sum#: | 24 # | 4 | 49 | 0 | 0 |
| Minimum: | 1 | 0 | 44 | 0 | 0 |
| Maximum: | 1 | 48 | 56 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 07/06/2026 00:00 | 1 | 0 | 46 | 0 | 0 |
| 07/06/2026 01:00 | 1 | 0 | 45 | 0 | 0 |
| 07/06/2026 02:00 | 1 | 0 | 45 | 0 | 0 |
| 07/06/2026 03:00 | 1 | 0 | 44 | 0 | 0 |
| 07/06/2026 04:00 | 1 | 0 | 46 | 0 | 0 |
| 07/06/2026 05:00 | 1 | 0 | 47 | 0 | 0 |
| 07/06/2026 06:00 | 1 | 0 | 47 | 0 | 0 |
| 07/06/2026 07:00 | 1 | 0 | 45 | 0 | 0 |
| 07/06/2026 08:00 | 1 | 0 | 44 | 0 | 0 |
| 07/06/2026 09:00 | 1 | 0 | 44 | 0 | 0 |
| 07/06/2026 10:00 | 1 | 0 | 44 | 0 | 0 |
| 07/06/2026 11:00 | 1 | 0 | 44 | 0 | 0 |
| 07/06/2026 12:00 | 1 | 0 | 44 | 0 | 0 |
| 07/06/2026 13:00 | 1 | 0 | 45 | 0 | 0 |
| 07/06/2026 14:00 | 1 | 0 | 46 | 0 | 0 |
| 07/06/2026 15:00 | 1 | 0 | 48 | 0 | 0 |
| 07/06/2026 16:00 | 1 | 0 | 50 | 0 | 0 |
| 07/06/2026 17:00 | 1 | 0 | 51 | 0 | 0 |
| 07/06/2026 18:00 | 1 | 0 | 53 | 0 | 0 |
| 07/06/2026 19:00 | 1 | 0 | 55 | 0 | 0 |
| 07/06/2026 20:00 | 1 | 0 | 57 | 0 | 0 |
| 07/06/2026 21:00 | 1 | 0 | 57 | 0 | 0 |
| 07/06/2026 22:00 | 1 | 0 | 57 | 0 | 0 |
| 07/06/2026 23:00 | 1 | 0 | 57 | 0 | 0 |
| Average/Sum#: | 24 # | 0 | 48 | 0 | 0 |
| Minimum: | 1 | 0 | 44 | 0 | 0 |
| Maximum: | 1 | 0 | 57 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 07/07/2026 00:00 | 1 | 0 | 57 | 0 | 0 |
| 07/07/2026 01:00 | 1 | 0 | 56 | 0 | 0 |
| 07/07/2026 02:00 | 1 | 0 | 56 | 0 | 0 |
| 07/07/2026 03:00 | 1 | 0 | 56 | 0 | 0 |
| 07/07/2026 04:00 | 1 | 0 | 56 | 0 | 0 |
| 07/07/2026 05:00 | 1 | 0 | 54 | 0 | 0 |
| 07/07/2026 06:00 | 1 | 0 | 50 | 0 | 0 |
| 07/07/2026 07:00 | 1 | 0 | 46 | 0 | 0 |
| 07/07/2026 08:00 | 1 | 0 | 44 | 0 | 0 |
| 07/07/2026 09:00 | 1 | 0 | 44 | 0 | 0 |
| 07/07/2026 10:00 | 1 | 0 | 44 | 0 | 0 |
| 07/07/2026 11:00 | 1 | 0 | 46 | 0 | 0 |
| 07/07/2026 12:00 | 1 | 0 | 48 | 0 | 0 |
| 07/07/2026 13:00 | 1 | 0 | 49 | 0 | 0 |
| 07/07/2026 14:00 | 1 | 0 | 50 | 0 | 0 |
| 07/07/2026 15:00 | 1 | 0 | 51 | 0 | 0 |
| 07/07/2026 16:00 | 1 | 0 | 51 | 0 | 0 |
| 07/07/2026 17:00 | 1 | 0 | 51 | 0 | 0 |
| 07/07/2026 18:00 | 1 | 0 | 53 | 0 | 0 |
| 07/07/2026 19:00 | 1 | 0 | 55 | 0 | 0 |
| 07/07/2026 20:00 | 1 | 0 | 56 | 0 | 0 |
| 07/07/2026 21:00 | 1 | 0 | 56 | 0 | 0 |
| 07/07/2026 22:00 | 1 | 0 | 56 | 0 | 0 |
| 07/07/2026 23:00 | 1 | 0 | 55 | 0 | 0 |
| Average/Sum#: | 24 # | 0 | 52 | 0 | 0 |
| Minimum: | 1 | 0 | 44 | 0 | 0 |
| Maximum: | 1 | 0 | 57 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 07/08/2026 00:00 | 1 | 0 | 55 | 0 | 0 |
| 07/08/2026 01:00 | 1 | 0 | 52 | 0 | 0 |
| 07/08/2026 02:00 | 1 | 0 | 49 | 0 | 0 |
| 07/08/2026 03:00 | 1 | 0 | 45 | 0 | 0 |
| 07/08/2026 04:00 | 1 | 0 | 44 | 0 | 0 |
| 07/08/2026 05:00 | 1 | 0 | 44 | 0 | 0 |
| 07/08/2026 06:00 | 1 | 0 | 44 | 0 | 0 |
| 07/08/2026 07:00 | 1 | 0 | 44 | 0 | 0 |
| 07/08/2026 08:00 | 1 | 0 | 44 | 0 | 0 |
| 07/08/2026 09:00 | 1 | 0 | 44 | 0 | 0 |
| 07/08/2026 10:00 | 1 | 0 | 44 | 0 | 0 |
| 07/08/2026 11:00 | 1 | 0 | 44 | 0 | 0 |
| 07/08/2026 12:00 | 1 | 0 | 44 | 0 | 0 |
| 07/08/2026 13:00 | 1 | 0 | 44 | 0 | 0 |
| 07/08/2026 14:00 | 1 | 0 | 44 | 0 | 0 |
| 07/08/2026 15:00 | 1 | 0 | 44 | 0 | 0 |
| 07/08/2026 16:00 | 1 | 0 | 45 | 0 | 0 |
| 07/08/2026 17:00 | 1 | 0 | 46 | 0 | 0 |
| 07/08/2026 18:00 | 1 | 0 | 48 | 0 | 0 |
| 07/08/2026 19:00 | 1 | 0 | 48 | 0 | 0 |
| 07/08/2026 20:00 | 1 | 0 | 46 | 0 | 0 |
| 07/08/2026 21:00 | 1 | 0 | 44 | 0 | 0 |
| 07/08/2026 22:00 | 1 | 0 | 44 | 0 | 0 |
| 07/08/2026 23:00 | 1 | 0 | 44 | 0 | 0 |
| Average/Sum#: | 24 # | 0 | 46 | 0 | 0 |
| Minimum: | 1 | 0 | 44 | 0 | 0 |
| Maximum: | 1 | 0 | 55 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 07/09/2026 00:00 | 1 | 0 | 44 | 0 | 0 |
| 07/09/2026 01:00 | 1 | 0 | 44 | 0 | 0 |
| 07/09/2026 02:00 | 1 | 0 | 44 | 0 | 0 |
| 07/09/2026 03:00 | 1 | 0 | 44 | 0 | 0 |
| 07/09/2026 04:00 | 1 | 0 | 45 | 0 | 0 |
| 07/09/2026 05:00 | 1 | 0 | 46 | 0 | 0 |
| 07/09/2026 06:00 | 1 | 0 | 46 | 0 | 0 |
| 07/09/2026 07:00 | 1 | 0 | 45 | 0 | 0 |
| 07/09/2026 08:00 | 1 | 0 | 44 | 0 | 0 |
| 07/09/2026 09:00 | 1 | 0 | 44 | 0 | 0 |
| 07/09/2026 10:00 | 1 | 0 | 44 | 0 | 0 |
| 07/09/2026 11:00 | 1 | 0 | 44 | 0 | 0 |
| 07/09/2026 12:00 | 1 | 0 | 44 | 0 | 0 |
| 07/09/2026 13:00 | 1 | 0 | 45 | 0 | 0 |
| 07/09/2026 14:00 | 1 | 0 | 45 | 0 | 0 |
| 07/09/2026 15:00 | 1 | 0 | 45 | 0 | 0 |
| 07/09/2026 16:00 | 1 | 0 | 46 | 0 | 0 |
| 07/09/2026 17:00 | 1 | 0 | 48 | 0 | 0 |
| 07/09/2026 18:00 | 1 | 0 | 52 | 0 | 0 |
| 07/09/2026 19:00 | 1 | 0 | 54 | 0 | 0 |
| 07/09/2026 20:00 | 1 | 0 | 55 | 0 | 0 |
| 07/09/2026 21:00 | 1 | 0 | 53 | 0 | 0 |
| 07/09/2026 22:00 | 1 | 0 | 51 | 0 | 0 |
| 07/09/2026 23:00 | 1 | 0 | 51 | 0 | 0 |
| Average/Sum#: | 24 # | 0 | 47 | 0 | 0 |
| Minimum: | 1 | 0 | 44 | 0 | 0 |
| Maximum: | 1 | 0 | 55 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 07/10/2026 00:00 | 1 | 0 | 50 | 0 | 0 |
| 07/10/2026 01:00 | 1 | 0 | 48 | 0 | 0 |
| 07/10/2026 02:00 | 1 | 0 | 45 | 0 | 0 |
| 07/10/2026 03:00 | 1 | 0 | 48 | 0 | 0 |
| 07/10/2026 04:00 | 1 | 0 | 49 | 0 | 0 |
| 07/10/2026 05:00 | 1 | 0 | 51 | 0 | 0 |
| 07/10/2026 06:00 | 1 | 0 | 48 | 0 | 0 |
| 07/10/2026 07:00 | 1 | 0 | 46 | 0 | 0 |
| 07/10/2026 08:00 | 1 | 0 | 44 | 0 | 0 |
| 07/10/2026 09:00 | 1 | 0 | 44 | 0 | 0 |
| 07/10/2026 10:00 | 1 | 0 | 44 | 0 | 0 |
| 07/10/2026 11:00 | 1 | 0 | 44 | 0 | 0 |
| 07/10/2026 12:00 | 1 | 0 | 44 | 0 | 0 |
| 07/10/2026 13:00 | 1 | 0 | 44 | 0 | 0 |
| 07/10/2026 14:00 | 1 | 0 | 44 | 0 | 0 |
| 07/10/2026 15:00 | 1 | 0 | 45 | 0 | 0 |
| 07/10/2026 16:00 | 1 | 10 | 45 | 0 | 0 |
| 07/10/2026 17:00 | 1 | 32 | 52 | 0 | 0 |
| 07/10/2026 18:00 | 1 | 54 | 60 | 0 | 0 |
| 07/10/2026 19:00 | 1 | 67 | 68 | 0 | 0 |
| 07/10/2026 20:00 | 1 | 68 | 68 | 0 | 0 |
| 07/10/2026 21:00 | 1 | 67 | 68 | 0 | 0 |
| 07/10/2026 22:00 | 1 | 66 | 67 | 0 | 0 |
| 07/10/2026 23:00 | 1 | 66 | 67 | 0 | 0 |
| Average/Sum#: | 24 # | 18 | 51 | 0 | 0 |
| Minimum: | 1 | 0 | 44 | 0 | 0 |
| Maximum: | 1 | 68 | 68 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 07/11/2026 00:00 | 1 | 66 | 67 | 0 | 0 |
| 07/11/2026 01:00 | 1 | 66 | 67 | 0 | 0 |
| 07/11/2026 02:00 | 1 | 66 | 67 | 0 | 0 |
| 07/11/2026 03:00 | 1 | 66 | 67 | 0 | 0 |
| 07/11/2026 04:00 | 1 | 65 | 66 | 0 | 0 |
| 07/11/2026 05:00 | 1 | 54 | 60 | 0 | 0 |
| 07/11/2026 06:00 | 1 | 32 | 53 | 0 | 0 |
| 07/11/2026 07:00 | 1 | 11 | 47 | 0 | 0 |
| 07/11/2026 08:00 | 1 | 0 | 45 | 0 | 0 |
| 07/11/2026 09:00 | 1 | 0 | 45 | 0 | 0 |
| 07/11/2026 10:00 | 1 | 0 | 45 | 0 | 0 |
| 07/11/2026 11:00 | 1 | 0 | 45 | 0 | 0 |
| 07/11/2026 12:00 | 1 | 0 | 45 | 0 | 0 |
| 07/11/2026 13:00 | 1 | 0 | 45 | 0 | 0 |
| 07/11/2026 14:00 | 1 | 0 | 45 | 0 | 0 |
| 07/11/2026 15:00 | 1 | 0 | 46 | 0 | 0 |
| 07/11/2026 16:00 | 1 | 12 | 46 | 0 | 0 |
| 07/11/2026 17:00 | 1 | 34 | 54 | 0 | 0 |
| 07/11/2026 18:00 | 1 | 56 | 61 | 0 | 0 |
| 07/11/2026 19:00 | 1 | 67 | 68 | 0 | 0 |
| 07/11/2026 20:00 | 1 | 67 | 67 | 0 | 0 |
| 07/11/2026 21:00 | 1 | 67 | 68 | 0 | 0 |
| 07/11/2026 22:00 | 1 | 68 | 68 | 0 | 0 |
| 07/11/2026 23:00 | 1 | 70 | 70 | 0 | 0 |
| Average/Sum#: | 24 # | 36 | 57 | 0 | 0 |
| Minimum: | 1 | 0 | 45 | 0 | 0 |
| Maximum: | 1 | 70 | 70 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 07/12/2026 00:00 | 1 | 69 | 70 | 0 | 0 |
| 07/12/2026 01:00 | 1 | 69 | 70 | 0 | 0 |
| 07/12/2026 02:00 | 1 | 66 | 67 | 0 | 0 |
| 07/12/2026 03:00 | 1 | 66 | 67 | 0 | 0 |
| 07/12/2026 04:00 | 1 | 66 | 67 | 0 | 0 |
| 07/12/2026 05:00 | 1 | 66 | 67 | 0 | 0 |
| 07/12/2026 06:00 | 1 | 66 | 67 | 0 | 0 |
| 07/12/2026 07:00 | 1 | 68 | 69 | 0 | 0 |
| 07/12/2026 08:00 | 1 | 71 | 72 | 0 | 0 |
| 07/12/2026 09:00 | 1 | 72 | 73 | 0 | 0 |
| 07/12/2026 10:00 | 1 | 70 | 71 | 0 | 0 |
| 07/12/2026 11:00 | 1 | 68 | 68 | 0 | 0 |
| 07/12/2026 12:00 | 1 | 67 | 67 | 0 | 0 |
| 07/12/2026 13:00 | 1 | 68 | 69 | 0 | 0 |
| 07/12/2026 14:00 | 1 | 70 | 71 | 0 | 0 |
| 07/12/2026 15:00 | 1 | 74 | 75 | 0 | 0 |
| 07/12/2026 16:00 | 1 | 76 | 78 | 0 | 0 |
| 07/12/2026 17:00 | 1 | 75 | 77 | 0 | 0 |
| 07/12/2026 18:00 | 1 | 72 | 74 | 0 | 0 |
| 07/12/2026 19:00 | 1 | 72 | 74 | 0 | 0 |
| 07/12/2026 20:00 | 1 | 75 | 76 | 0 | 0 |
| 07/12/2026 21:00 | 1 | 78 | 80 | 0 | 0 |
| 07/12/2026 22:00 | 1 | 77 | 78 | 0 | 0 |
| 07/12/2026 23:00 | 1 | 67 | 68 | 0 | 0 |
| Average/Sum#: | 24 # | 70 | 71 | 0 | 0 |
| Minimum: | 1 | 66 | 67 | 0 | 0 |
| Maximum: | 1 | 78 | 80 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 07/13/2026 00:00 | 1 | 58 | 59 | 0 | 0 |
| 07/13/2026 01:00 | 1 | 53 | 54 | 0 | 0 |
| 07/13/2026 02:00 | 1 | 56 | 57 | 0 | 0 |
| 07/13/2026 03:00 | 1 | 58 | 59 | 0 | 0 |
| 07/13/2026 04:00 | 1 | 58 | 59 | 0 | 0 |
| 07/13/2026 05:00 | 1 | 56 | 57 | 0 | 0 |
| 07/13/2026 06:00 | 1 | 57 | 58 | 0 | 0 |
| 07/13/2026 07:00 | 1 | 56 | 57 | 0 | 0 |
| 07/13/2026 08:00 | 1 | 62 | 63 | 0 | 0 |
| 07/13/2026 09:00 | 1 | 68 | 69 | 0 | 0 |
| 07/13/2026 10:00 | 1 | 76 | 77 | 0 | 0 |
| 07/13/2026 11:00 | 1 | 79 | 80 | 0 | 0 |
| 07/13/2026 12:00 | 1 | 79 | 80 | 0 | 0 |
| 07/13/2026 13:00 | 1 | 79 | 80 | 0 | 0 |
| 07/13/2026 14:00 | 1 | 79 | 80 | 0 | 0 |
| 07/13/2026 15:00 | 1 | 79 | 80 | 0 | 0 |
| 07/13/2026 16:00 | 1 | 79 | 80 | 0 | 0 |
| 07/13/2026 17:00 | 1 | 79 | 80 | 0 | 0 |
| 07/13/2026 18:00 | 1 | 78 | 80 | 0 | 0 |
| 07/13/2026 19:00 | 1 | 78 | 80 | 0 | 0 |
| 07/13/2026 20:00 | 1 | 79 | 80 | 0 | 0 |
| 07/13/2026 21:00 | 1 | 79 | 80 | 0 | 0 |
| 07/13/2026 22:00 | 1 | 76 | 77 | 0 | 0 |
| 07/13/2026 23:00 | 1 | 72 | 73 | 0 | 0 |
| Average/Sum#: | 24 # | 70 | 71 | 0 | 0 |
| Minimum: | 1 | 53 | 54 | 0 | 0 |
| Maximum: | 1 | 79 | 80 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 07/14/2026 00:00 | 1 | 70 | 71 | 0 | 0 |
| 07/14/2026 01:00 | 1 | 69 | 69 | 0 | 0 |
| 07/14/2026 02:00 | 1 | 68 | 69 | 0 | 0 |
| 07/14/2026 03:00 | 1 | 66 | 67 | 0 | 0 |
| 07/14/2026 04:00 | 1 | 66 | 67 | 0 | 0 |
| 07/14/2026 05:00 | 1 | 67 | 68 | 0 | 0 |
| 07/14/2026 06:00 | 1 | 67 | 68 | 0 | 0 |
| 07/14/2026 07:00 | 1 | 68 | 68 | 0 | 0 |
| 07/14/2026 08:00 | 1 | 66 | 67 | 0 | 0 |
| 07/14/2026 09:00 | 1 | 66 | 67 | 0 | 0 |
| 07/14/2026 10:00 | 1 | 66 | 67 | 0 | 0 |
| 07/14/2026 11:00 | 1 | 67 | 67 | 0 | 0 |
| 07/14/2026 12:00 | 1 | 68 | 68 | 0 | 0 |
| 07/14/2026 13:00 | 1 | 69 | 70 | 0 | 0 |
| 07/14/2026 14:00 | 1 | 72 | 73 | 0 | 0 |
| 07/14/2026 15:00 | 1 | 75 | 76 | 4 | 0 |
| 07/14/2026 16:00 | 1 | 77 | 78 | 26 | 0 |
| 07/14/2026 17:00 | 1 | 77 | 79 | 27 | 0 |
| 07/14/2026 18:00 | 1 | 77 | 79 | 27 | 0 |
| 07/14/2026 19:00 | 1 | 77 | 78 | 27 | 0 |
| 07/14/2026 20:00 | 1 | 76 | 77 | 0 | 0 |
| 07/14/2026 21:00 | 1 | 75 | 76 | 0 | 0 |
| 07/14/2026 22:00 | 1 | 73 | 74 | 0 | 0 |
| 07/14/2026 23:00 | 1 | 70 | 72 | 0 | 0 |
| Average/Sum#: | 24 # | 71 | 71 | 5 | 0 |
| Minimum: | 1 | 66 | 67 | 0 | 0 |
| Maximum: | 1 | 77 | 79 | 27 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 07/15/2026 00:00 | 1 | 67 | 69 | 0 | 0 |
| 07/15/2026 01:00 | 1 | 66 | 68 | 0 | 0 |
| 07/15/2026 02:00 | 1 | 66 | 68 | 0 | 0 |
| 07/15/2026 03:00 | 1 | 66 | 68 | 0 | 0 |
| 07/15/2026 04:00 | 1 | 66 | 68 | 0 | 0 |
| 07/15/2026 05:00 | 1 | 66 | 67 | 0 | 0 |
| 07/15/2026 06:00 | 1 | 66 | 67 | 0 | 0 |
| 07/15/2026 07:00 | 1 | 67 | 67 | 0 | 0 |
| 07/15/2026 08:00 | 1 | 67 | 67 | 6 | 0 |
| 07/15/2026 09:00 | 1 | 67 | 67 | 28 | 0 |
| 07/15/2026 10:00 | 1 | 70 | 71 | 26 | 0 |
| 07/15/2026 11:00 | 1 | 74 | 74 | 25 | 10 |
| 07/15/2026 12:00 | 1 | 75 | 76 | 25 | 25 |
| 07/15/2026 13:00 | 1 | 74 | 75 | 25 | 25 |
| 07/15/2026 14:00 | 1 | 74 | 76 | 0 | 24 |
| 07/15/2026 15:00 | 1 | 75 | 77 | 0 | 24 |
| 07/15/2026 16:00 | 1 | 77 | 79 | 0 | 24 |
| 07/15/2026 17:00 | 1 | 77 | 78 | 0 | 24 |
| 07/15/2026 18:00 | 1 | 77 | 79 | 0 | 24 |
| 07/15/2026 19:00 | 1 | 77 | 78 | 0 | 24 |
| 07/15/2026 20:00 | 1 | 76 | 78 | 0 | 24 |
| 07/15/2026 21:00 | 1 | 75 | 77 | 0 | 0 |
| 07/15/2026 22:00 | 1 | 72 | 73 | 0 | 0 |
| 07/15/2026 23:00 | 1 | 69 | 70 | 0 | 0 |
| Average/Sum#: | 24 # | 71 | 72 | 6 | 10 |
| Minimum: | 1 | 66 | 67 | 0 | 0 |
| Maximum: | 1 | 77 | 79 | 28 | 25 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 07/16/2026 00:00 | 1 | 67 | 67 | 0 | 0 |
| 07/16/2026 01:00 | 1 | 66 | 67 | 0 | 0 |
| 07/16/2026 02:00 | 1 | 66 | 67 | 0 | 0 |
| 07/16/2026 03:00 | 1 | 66 | 67 | 0 | 0 |
| 07/16/2026 04:00 | 1 | 66 | 67 | 0 | 0 |
| 07/16/2026 05:00 | 1 | 66 | 67 | 0 | 0 |
| 07/16/2026 06:00 | 1 | 66 | 67 | 0 | 0 |
| 07/16/2026 07:00 | 1 | 66 | 67 | 0 | 0 |
| 07/16/2026 08:00 | 1 | 66 | 67 | 0 | 0 |
| 07/16/2026 09:00 | 1 | 66 | 67 | 0 | 0 |
| 07/16/2026 10:00 | 1 | 67 | 67 | 0 | 0 |
| 07/16/2026 11:00 | 1 | 67 | 67 | 0 | 0 |
| 07/16/2026 12:00 | 1 | 67 | 67 | 0 | 0 |
| 07/16/2026 13:00 | 1 | 67 | 67 | 0 | 0 |
| 07/16/2026 14:00 | 1 | 67 | 67 | 0 | 0 |
| 07/16/2026 15:00 | 1 | 67 | 67 | 0 | 0 |
| 07/16/2026 16:00 | 1 | 67 | 67 | 0 | 0 |
| 07/16/2026 17:00 | 1 | 67 | 68 | 0 | 0 |
| 07/16/2026 18:00 | 1 | 67 | 68 | 0 | 0 |
| 07/16/2026 19:00 | 1 | 66 | 68 | 0 | 0 |
| 07/16/2026 20:00 | 1 | 66 | 68 | 0 | 0 |
| 07/16/2026 21:00 | 1 | 66 | 67 | 0 | 0 |
| 07/16/2026 22:00 | 1 | 66 | 67 | 0 | 0 |
| 07/16/2026 23:00 | 1 | 67 | 67 | 0 | 0 |
| Average/Sum#: | 24 # | 66 | 67 | 0 | 0 |
| Minimum: | 1 | 66 | 67 | 0 | 0 |
| Maximum: | 1 | 67 | 68 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 07/17/2026 00:00 | 1 | 67 | 67 | 0 | 0 |
| 07/17/2026 01:00 | 1 | 66 | 67 | 0 | 0 |
| 07/17/2026 02:00 | 1 | 66 | 67 | 0 | 0 |
| 07/17/2026 03:00 | 1 | 66 | 67 | 0 | 0 |
| 07/17/2026 04:00 | 1 | 66 | 67 | 0 | 0 |
| 07/17/2026 05:00 | 1 | 66 | 67 | 0 | 0 |
| 07/17/2026 06:00 | 1 | 66 | 67 | 0 | 0 |
| 07/17/2026 07:00 | 1 | 66 | 67 | 0 | 0 |
| 07/17/2026 08:00 | 1 | 66 | 67 | 0 | 0 |
| 07/17/2026 09:00 | 1 | 66 | 67 | 0 | 0 |
| 07/17/2026 10:00 | 1 | 66 | 67 | 0 | 0 |
| 07/17/2026 11:00 | 1 | 67 | 67 | 0 | 0 |
| 07/17/2026 12:00 | 1 | 67 | 67 | 0 | 0 |
| 07/17/2026 13:00 | 1 | 67 | 67 | 0 | 0 |
| 07/17/2026 14:00 | 1 | 67 | 67 | 0 | 0 |
| 07/17/2026 15:00 | 1 | 67 | 67 | 0 | 0 |
| 07/17/2026 16:00 | 1 | 67 | 67 | 0 | 0 |
| 07/17/2026 17:00 | 1 | 67 | 67 | 0 | 0 |
| 07/17/2026 18:00 | 1 | 67 | 67 | 0 | 0 |
| 07/17/2026 19:00 | 1 | 67 | 67 | 0 | 0 |
| 07/17/2026 20:00 | 1 | 67 | 67 | 0 | 0 |
| 07/17/2026 21:00 | 1 | 66 | 67 | 0 | 0 |
| 07/17/2026 22:00 | 1 | 66 | 67 | 0 | 0 |
| 07/17/2026 23:00 | 1 | 66 | 67 | 0 | 0 |
| Average/Sum#: | 24 # | 66 | 67 | 0 | 0 |
| Minimum: | 1 | 66 | 67 | 0 | 0 |
| Maximum: | 1 | 67 | 67 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 07/18/2026 00:00 | 1 | 66 | 67 | 0 | 0 |
| 07/18/2026 01:00 | 1 | 66 | 67 | 0 | 0 |
| 07/18/2026 02:00 | 1 | 66 | 67 | 0 | 0 |
| 07/18/2026 03:00 | 1 | 66 | 67 | 0 | 0 |
| 07/18/2026 04:00 | 1 | 66 | 67 | 0 | 0 |
| 07/18/2026 05:00 | 1 | 67 | 68 | 0 | 0 |
| 07/18/2026 06:00 | 1 | 67 | 68 | 0 | 0 |
| 07/18/2026 07:00 | 1 | 67 | 68 | 0 | 0 |
| 07/18/2026 08:00 | 1 | 66 | 67 | 0 | 0 |
| 07/18/2026 09:00 | 1 | 66 | 67 | 0 | 0 |
| 07/18/2026 10:00 | 1 | 66 | 67 | 0 | 0 |
| 07/18/2026 11:00 | 1 | 64 | 65 | 0 | 0 |
| 07/18/2026 12:00 | 1 | 57 | 58 | 0 | 0 |
| 07/18/2026 13:00 | 1 | 52 | 52 | 0 | 0 |
| 07/18/2026 14:00 | 1 | 54 | 55 | 0 | 0 |
| 07/18/2026 15:00 | 1 | 61 | 61 | 0 | 0 |
| 07/18/2026 16:00 | 1 | 67 | 67 | 0 | 0 |
| 07/18/2026 17:00 | 1 | 67 | 67 | 0 | 0 |
| 07/18/2026 18:00 | 1 | 67 | 67 | 0 | 0 |
| 07/18/2026 19:00 | 1 | 67 | 67 | 0 | 0 |
| 07/18/2026 20:00 | 1 | 67 | 67 | 0 | 0 |
| 07/18/2026 21:00 | 1 | 67 | 67 | 0 | 0 |
| 07/18/2026 22:00 | 1 | 66 | 67 | 0 | 0 |
| 07/18/2026 23:00 | 1 | 66 | 67 | 0 | 0 |
| Average/Sum#: | 24 # | 65 | 65 | 0 | 0 |
| Minimum: | 1 | 52 | 52 | 0 | 0 |
| Maximum: | 1 | 67 | 68 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 07/19/2026 00:00 | 1 | 66 | 67 | 0 | 0 |
| 07/19/2026 01:00 | 1 | 66 | 67 | 0 | 0 |
| 07/19/2026 02:00 | 1 | 66 | 67 | 0 | 0 |
| 07/19/2026 03:00 | 1 | 66 | 67 | 0 | 0 |
| 07/19/2026 04:00 | 1 | 66 | 67 | 0 | 0 |
| 07/19/2026 05:00 | 1 | 66 | 67 | 0 | 0 |
| 07/19/2026 06:00 | 1 | 66 | 67 | 0 | 0 |
| 07/19/2026 07:00 | 1 | 66 | 67 | 0 | 0 |
| 07/19/2026 08:00 | 1 | 66 | 67 | 0 | 0 |
| 07/19/2026 09:00 | 1 | 66 | 67 | 0 | 0 |
| 07/19/2026 10:00 | 1 | 66 | 67 | 0 | 0 |
| 07/19/2026 11:00 | 1 | 66 | 67 | 0 | 0 |
| 07/19/2026 12:00 | 1 | 67 | 67 | 0 | 0 |
| 07/19/2026 13:00 | 1 | 67 | 67 | 0 | 0 |
| 07/19/2026 14:00 | 1 | 67 | 67 | 0 | 0 |
| 07/19/2026 15:00 | 1 | 67 | 67 | 0 | 0 |
| 07/19/2026 16:00 | 1 | 67 | 67 | 0 | 0 |
| 07/19/2026 17:00 | 1 | 69 | 69 | 0 | 0 |
| 07/19/2026 18:00 | 1 | 72 | 72 | 0 | 0 |
| 07/19/2026 19:00 | 1 | 74 | 75 | 0 | 0 |
| 07/19/2026 20:00 | 1 | 76 | 77 | 0 | 0 |
| 07/19/2026 21:00 | 1 | 77 | 79 | 0 | 0 |
| 07/19/2026 22:00 | 1 | 78 | 80 | 0 | 0 |
| 07/19/2026 23:00 | 1 | 78 | 80 | 0 | 0 |
| Average/Sum#: | 24 # | 69 | 70 | 0 | 0 |
| Minimum: | 1 | 66 | 67 | 0 | 0 |
| Maximum: | 1 | 78 | 80 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 07/20/2026 00:00 | 1 | 76 | 78 | 0 | 0 |
| 07/20/2026 01:00 | 1 | 72 | 73 | 0 | 0 |
| 07/20/2026 02:00 | 1 | 68 | 70 | 0 | 0 |
| 07/20/2026 03:00 | 1 | 71 | 72 | 0 | 0 |
| 07/20/2026 04:00 | 1 | 75 | 76 | 0 | 0 |
| 07/20/2026 05:00 | 1 | 79 | 80 | 0 | 0 |
| 07/20/2026 06:00 | 1 | 79 | 80 | 0 | 0 |
| 07/20/2026 07:00 | 1 | 78 | 79 | 0 | 0 |
| 07/20/2026 08:00 | 1 | 77 | 78 | 0 | 0 |
| 07/20/2026 09:00 | 1 | 76 | 77 | 0 | 0 |
| 07/20/2026 10:00 | 1 | 76 | 77 | 0 | 0 |
| 07/20/2026 11:00 | 1 | 76 | 77 | 0 | 0 |
| 07/20/2026 12:00 | 1 | 76 | 78 | 0 | 0 |
| 07/20/2026 13:00 | 1 | 76 | 78 | 0 | 0 |
| 07/20/2026 14:00 | 1 | 76 | 77 | 0 | 0 |
| 07/20/2026 15:00 | 1 | 76 | 77 | 20 | 20 |
| 07/20/2026 16:00 | 1 | 75 | 76 | 24 | 25 |
| 07/20/2026 17:00 | 1 | 76 | 77 | 24 | 25 |
| 07/20/2026 18:00 | 1 | 77 | 78 | 23 | 24 |
| 07/20/2026 19:00 | 1 | 77 | 78 | 10 | 24 |
| 07/20/2026 20:00 | 1 | 77 | 79 | 0 | 24 |
| 07/20/2026 21:00 | 1 | 77 | 78 | 0 | 20 |
| 07/20/2026 22:00 | 1 | 74 | 76 | 0 | 0 |
| 07/20/2026 23:00 | 1 | 72 | 74 | 0 | 0 |
| Average/Sum#: | 24 # | 76 | 77 | 4 | 7 |
| Minimum: | 1 | 68 | 70 | 0 | 0 |
| Maximum: | 1 | 79 | 80 | 24 | 25 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 07/21/2026 00:00 | 1 | 69 | 70 | 0 | 0 |
| 07/21/2026 01:00 | 1 | 68 | 69 | 0 | 0 |
| 07/21/2026 02:00 | 1 | 66 | 67 | 0 | 0 |
| 07/21/2026 03:00 | 1 | 66 | 67 | 0 | 0 |
| 07/21/2026 04:00 | 1 | 67 | 68 | 0 | 0 |
| 07/21/2026 05:00 | 1 | 70 | 71 | 0 | 0 |
| 07/21/2026 06:00 | 1 | 71 | 72 | 0 | 0 |
| 07/21/2026 07:00 | 1 | 71 | 72 | 0 | 0 |
| 07/21/2026 08:00 | 1 | 69 | 70 | 0 | 0 |
| 07/21/2026 09:00 | 1 | 68 | 69 | 0 | 0 |
| 07/21/2026 10:00 | 1 | 68 | 68 | 0 | 0 |
| 07/21/2026 11:00 | 1 | 68 | 69 | 0 | 0 |
| 07/21/2026 12:00 | 1 | 72 | 73 | 0 | 0 |
| 07/21/2026 13:00 | 1 | 75 | 76 | 0 | 10 |
| 07/21/2026 14:00 | 1 | 77 | 78 | 0 | 24 |
| 07/21/2026 15:00 | 1 | 77 | 78 | 5 | 24 |
| 07/21/2026 16:00 | 1 | 77 | 78 | 24 | 25 |
| 07/21/2026 17:00 | 1 | 78 | 79 | 24 | 26 |
| 07/21/2026 18:00 | 1 | 78 | 79 | 24 | 26 |
| 07/21/2026 19:00 | 1 | 79 | 80 | 24 | 25 |
| 07/21/2026 20:00 | 1 | 79 | 80 | 24 | 25 |
| 07/21/2026 21:00 | 1 | 79 | 80 | 0 | 0 |
| 07/21/2026 22:00 | 1 | 78 | 79 | 0 | 0 |
| 07/21/2026 23:00 | 1 | 77 | 78 | 0 | 0 |
| Average/Sum#: | 24 # | 73 | 74 | 5 | 8 |
| Minimum: | 1 | 66 | 67 | 0 | 0 |
| Maximum: | 1 | 79 | 80 | 24 | 26 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 07/22/2026 00:00 | 1 | 73 | 74 | 0 | 0 |
| 07/22/2026 01:00 | 1 | 70 | 70 | 0 | 0 |
| 07/22/2026 02:00 | 1 | 66 | 67 | 0 | 0 |
| 07/22/2026 03:00 | 1 | 66 | 67 | 0 | 0 |
| 07/22/2026 04:00 | 1 | 66 | 68 | 0 | 0 |
| 07/22/2026 05:00 | 1 | 68 | 69 | 0 | 0 |
| 07/22/2026 06:00 | 1 | 68 | 69 | 0 | 0 |
| 07/22/2026 07:00 | 1 | 68 | 69 | 0 | 0 |
| 07/22/2026 08:00 | 1 | 69 | 69 | 0 | 0 |
| 07/22/2026 09:00 | 1 | 69 | 69 | 0 | 0 |
| 07/22/2026 10:00 | 1 | 69 | 69 | 0 | 0 |
| 07/22/2026 11:00 | 1 | 67 | 67 | 0 | 0 |
| 07/22/2026 12:00 | 1 | 67 | 67 | 0 | 0 |
| 07/22/2026 13:00 | 1 | 67 | 67 | 0 | 0 |
| 07/22/2026 14:00 | 1 | 67 | 67 | 0 | 0 |
| 07/22/2026 15:00 | 1 | 67 | 67 | 0 | 0 |
| 07/22/2026 16:00 | 1 | 67 | 67 | 0 | 0 |
| 07/22/2026 17:00 | 1 | 67 | 67 | 0 | 0 |
| 07/22/2026 18:00 | 1 | 67 | 67 | 0 | 0 |
| 07/22/2026 19:00 | 1 | 67 | 67 | 0 | 0 |
| 07/22/2026 20:00 | 1 | 67 | 67 | 0 | 0 |
| 07/22/2026 21:00 | 1 | 67 | 67 | 0 | 0 |
| 07/22/2026 22:00 | 1 | 66 | 67 | 0 | 0 |
| 07/22/2026 23:00 | 1 | 66 | 67 | 0 | 0 |
| Average/Sum#: | 24 # | 68 | 68 | 0 | 0 |
| Minimum: | 1 | 66 | 67 | 0 | 0 |
| Maximum: | 1 | 73 | 74 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 07/23/2026 00:00 | 1 | 66 | 67 | 0 | 0 |
| 07/23/2026 01:00 | 1 | 66 | 67 | 0 | 0 |
| 07/23/2026 02:00 | 1 | 66 | 67 | 0 | 0 |
| 07/23/2026 03:00 | 1 | 66 | 67 | 0 | 0 |
| 07/23/2026 04:00 | 1 | 66 | 67 | 0 | 0 |
| 07/23/2026 05:00 | 1 | 66 | 67 | 0 | 0 |
| 07/23/2026 06:00 | 1 | 66 | 67 | 0 | 0 |
| 07/23/2026 07:00 | 1 | 66 | 67 | 0 | 0 |
| 07/23/2026 08:00 | 1 | 66 | 66 | 0 | 0 |
| 07/23/2026 09:00 | 1 | 59 | 60 | 0 | 0 |
| 07/23/2026 10:00 | 1 | 53 | 53 | 0 | 0 |
| 07/23/2026 11:00 | 1 | 51 | 51 | 0 | 0 |
| 07/23/2026 12:00 | 1 | 58 | 58 | 0 | 0 |
| 07/23/2026 13:00 | 1 | 65 | 65 | 0 | 0 |
| 07/23/2026 14:00 | 1 | 67 | 67 | 0 | 0 |
| 07/23/2026 15:00 | 1 | 67 | 67 | 0 | 0 |
| 07/23/2026 16:00 | 1 | 67 | 67 | 0 | 0 |
| 07/23/2026 17:00 | 1 | 67 | 67 | 0 | 0 |
| 07/23/2026 18:00 | 1 | 68 | 68 | 0 | 0 |
| 07/23/2026 19:00 | 1 | 68 | 68 | 0 | 0 |
| 07/23/2026 20:00 | 1 | 68 | 69 | 0 | 0 |
| 07/23/2026 21:00 | 1 | 67 | 69 | 0 | 0 |
| 07/23/2026 22:00 | 1 | 67 | 69 | 0 | 0 |
| 07/23/2026 23:00 | 1 | 67 | 68 | 0 | 0 |
| Average/Sum#: | 24 # | 65 | 65 | 0 | 0 |
| Minimum: | 1 | 51 | 51 | 0 | 0 |
| Maximum: | 1 | 68 | 69 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 07/24/2026 00:00 | 1 | 67 | 68 | 0 | 0 |
| 07/24/2026 01:00 | 1 | 66 | 68 | 0 | 0 |
| 07/24/2026 02:00 | 1 | 66 | 68 | 0 | 0 |
| 07/24/2026 03:00 | 1 | 66 | 68 | 0 | 0 |
| 07/24/2026 04:00 | 1 | 66 | 68 | 0 | 0 |
| 07/24/2026 05:00 | 1 | 66 | 68 | 0 | 0 |
| 07/24/2026 06:00 | 1 | 66 | 67 | 0 | 0 |
| 07/24/2026 07:00 | 1 | 66 | 67 | 0 | 0 |
| 07/24/2026 08:00 | 1 | 66 | 67 | 0 | 0 |
| 07/24/2026 09:00 | 1 | 66 | 67 | 0 | 0 |
| 07/24/2026 10:00 | 1 | 66 | 67 | 0 | 0 |
| 07/24/2026 11:00 | 1 | 60 | 61 | 0 | 0 |
| 07/24/2026 12:00 | 1 | 58 | 59 | 0 | 0 |
| 07/24/2026 13:00 | 1 | 60 | 61 | 0 | 0 |
| 07/24/2026 14:00 | 1 | 71 | 72 | 0 | 0 |
| 07/24/2026 15:00 | 1 | 76 | 77 | 0 | 0 |
| 07/24/2026 16:00 | 1 | 76 | 77 | 0 | 0 |
| 07/24/2026 17:00 | 1 | 74 | 76 | 0 | 0 |
| 07/24/2026 18:00 | 1 | 73 | 75 | 0 | 0 |
| 07/24/2026 19:00 | 1 | 72 | 74 | 0 | 0 |
| 07/24/2026 20:00 | 1 | 71 | 73 | 0 | 0 |
| 07/24/2026 21:00 | 1 | 69 | 70 | 0 | 0 |
| 07/24/2026 22:00 | 1 | 68 | 69 | 0 | 0 |
| 07/24/2026 23:00 | 1 | 67 | 68 | 0 | 0 |
| Average/Sum#: | 24 # | 68 | 69 | 0 | 0 |
| Minimum: | 1 | 58 | 59 | 0 | 0 |
| Maximum: | 1 | 76 | 77 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 07/25/2026 00:00 | 1 | 66 | 67 | 0 | 0 |
| 07/25/2026 01:00 | 1 | 66 | 67 | 0 | 0 |
| 07/25/2026 02:00 | 1 | 66 | 67 | 0 | 0 |
| 07/25/2026 03:00 | 1 | 66 | 67 | 0 | 0 |
| 07/25/2026 04:00 | 1 | 66 | 68 | 0 | 0 |
| 07/25/2026 05:00 | 1 | 66 | 68 | 0 | 0 |
| 07/25/2026 06:00 | 1 | 66 | 67 | 0 | 0 |
| 07/25/2026 07:00 | 1 | 66 | 67 | 0 | 0 |
| 07/25/2026 08:00 | 1 | 66 | 67 | 0 | 0 |
| 07/25/2026 09:00 | 1 | 66 | 67 | 0 | 0 |
| 07/25/2026 10:00 | 1 | 66 | 67 | 0 | 0 |
| 07/25/2026 11:00 | 1 | 67 | 67 | 0 | 0 |
| 07/25/2026 12:00 | 1 | 67 | 67 | 0 | 0 |
| 07/25/2026 13:00 | 1 | 67 | 67 | 0 | 0 |
| 07/25/2026 14:00 | 1 | 67 | 67 | 0 | 0 |
| 07/25/2026 15:00 | 1 | 67 | 67 | 0 | 0 |
| 07/25/2026 16:00 | 1 | 67 | 67 | 0 | 0 |
| 07/25/2026 17:00 | 1 | 67 | 67 | 0 | 0 |
| 07/25/2026 18:00 | 1 | 67 | 67 | 0 | 0 |
| 07/25/2026 19:00 | 1 | 67 | 67 | 0 | 0 |
| 07/25/2026 20:00 | 1 | 67 | 67 | 0 | 0 |
| 07/25/2026 21:00 | 1 | 66 | 67 | 0 | 0 |
| 07/25/2026 22:00 | 1 | 66 | 67 | 0 | 0 |
| 07/25/2026 23:00 | 1 | 66 | 67 | 0 | 0 |
| Average/Sum#: | 24 # | 66 | 67 | 0 | 0 |
| Minimum: | 1 | 66 | 67 | 0 | 0 |
| Maximum: | 1 | 67 | 68 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 07/26/2026 00:00 | 1 | 66 | 67 | 0 | 0 |
| 07/26/2026 01:00 | 1 | 66 | 67 | 0 | 0 |
| 07/26/2026 02:00 | 1 | 66 | 67 | 0 | 0 |
| 07/26/2026 03:00 | 1 | 66 | 67 | 0 | 0 |
| 07/26/2026 04:00 | 1 | 66 | 67 | 0 | 0 |
| 07/26/2026 05:00 | 1 | 66 | 67 | 0 | 0 |
| 07/26/2026 06:00 | 1 | 66 | 67 | 0 | 0 |
| 07/26/2026 07:00 | 1 | 60 | 61 | 0 | 0 |
| 07/26/2026 08:00 | 1 | 58 | 59 | 0 | 0 |
| 07/26/2026 09:00 | 1 | 58 | 59 | 0 | 0 |
| 07/26/2026 10:00 | 1 | 65 | 65 | 0 | 0 |
| 07/26/2026 11:00 | 1 | 67 | 67 | 0 | 0 |
| 07/26/2026 12:00 | 1 | 67 | 67 | 0 | 0 |
| 07/26/2026 13:00 | 1 | 67 | 67 | 0 | 0 |
| 07/26/2026 14:00 | 1 | 67 | 67 | 0 | 0 |
| 07/26/2026 15:00 | 1 | 67 | 67 | 0 | 0 |
| 07/26/2026 16:00 | 1 | 67 | 67 | 0 | 0 |
| 07/26/2026 17:00 | 1 | 67 | 67 | 0 | 0 |
| 07/26/2026 18:00 | 1 | 67 | 67 | 0 | 0 |
| 07/26/2026 19:00 | 1 | 67 | 67 | 0 | 0 |
| 07/26/2026 20:00 | 1 | 67 | 68 | 0 | 0 |
| 07/26/2026 21:00 | 1 | 68 | 69 | 0 | 0 |
| 07/26/2026 22:00 | 1 | 70 | 71 | 0 | 0 |
| 07/26/2026 23:00 | 1 | 70 | 71 | 0 | 0 |
| Average/Sum#: | 24 # | 66 | 66 | 0 | 0 |
| Minimum: | 1 | 58 | 59 | 0 | 0 |
| Maximum: | 1 | 70 | 71 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 07/27/2026 00:00 | 1 | 69 | 70 | 0 | 0 |
| 07/27/2026 01:00 | 1 | 67 | 68 | 0 | 0 |
| 07/27/2026 02:00 | 1 | 67 | 68 | 0 | 0 |
| 07/27/2026 03:00 | 1 | 66 | 67 | 0 | 0 |
| 07/27/2026 04:00 | 1 | 66 | 67 | 0 | 0 |
| 07/27/2026 05:00 | 1 | 66 | 67 | 0 | 0 |
| 07/27/2026 06:00 | 1 | 66 | 67 | 0 | 0 |
| 07/27/2026 07:00 | 1 | 66 | 67 | 0 | 0 |
| 07/27/2026 08:00 | 1 | 66 | 67 | 0 | 0 |
| 07/27/2026 09:00 | 1 | 66 | 67 | 0 | 0 |
| 07/27/2026 10:00 | 1 | 66 | 67 | 0 | 0 |
| 07/27/2026 11:00 | 1 | 67 | 67 | 0 | 0 |
| 07/27/2026 12:00 | 1 | 67 | 67 | 0 | 0 |
| 07/27/2026 13:00 | 1 | 67 | 67 | 0 | 0 |
| 07/27/2026 14:00 | 1 | 67 | 67 | 0 | 0 |
| 07/27/2026 15:00 | 1 | 67 | 67 | 0 | 0 |
| 07/27/2026 16:00 | 1 | 67 | 67 | 0 | 0 |
| 07/27/2026 17:00 | 1 | 67 | 67 | 0 | 0 |
| 07/27/2026 18:00 | 1 | 69 | 69 | 0 | 0 |
| 07/27/2026 19:00 | 1 | 71 | 72 | 0 | 0 |
| 07/27/2026 20:00 | 1 | 72 | 73 | 0 | 0 |
| 07/27/2026 21:00 | 1 | 70 | 71 | 0 | 0 |
| 07/27/2026 22:00 | 1 | 68 | 69 | 0 | 0 |
| 07/27/2026 23:00 | 1 | 66 | 67 | 0 | 0 |
| Average/Sum#: | 24 # | 67 | 68 | 0 | 0 |
| Minimum: | 1 | 66 | 67 | 0 | 0 |
| Maximum: | 1 | 72 | 73 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 07/28/2026 00:00 | 1 | 66 | 67 | 0 | 0 |
| 07/28/2026 01:00 | 1 | 66 | 67 | 0 | 0 |
| 07/28/2026 02:00 | 1 | 66 | 67 | 0 | 0 |
| 07/28/2026 03:00 | 1 | 66 | 67 | 0 | 0 |
| 07/28/2026 04:00 | 1 | 66 | 67 | 0 | 0 |
| 07/28/2026 05:00 | 1 | 66 | 67 | 0 | 0 |
| 07/28/2026 06:00 | 1 | 66 | 67 | 0 | 0 |
| 07/28/2026 07:00 | 1 | 62 | 63 | 0 | 0 |
| 07/28/2026 08:00 | 1 | 55 | 56 | 0 | 0 |
| 07/28/2026 09:00 | 1 | 49 | 50 | 0 | 0 |
| 07/28/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 07/28/2026 11:00 | 1 | 47 | 48 | 0 | 0 |
| 07/28/2026 12:00 | 1 | 54 | 54 | 0 | 0 |
| 07/28/2026 13:00 | 1 | 54 | 54 | 0 | 0 |
| 07/28/2026 14:00 | 1 | 53 | 53 | 0 | 0 |
| 07/28/2026 15:00 | 1 | 48 | 49 | 0 | 0 |
| 07/28/2026 16:00 | 1 | 54 | 55 | 0 | 0 |
| 07/28/2026 17:00 | 1 | 61 | 62 | 0 | 0 |
| 07/28/2026 18:00 | 1 | 67 | 67 | 0 | 0 |
| 07/28/2026 19:00 | 1 | 67 | 67 | 0 | 0 |
| 07/28/2026 20:00 | 1 | 67 | 67 | 0 | 0 |
| 07/28/2026 21:00 | 1 | 67 | 67 | 0 | 0 |
| 07/28/2026 22:00 | 1 | 66 | 67 | 0 | 0 |
| 07/28/2026 23:00 | 1 | 60 | 61 | 0 | 0 |
| Average/Sum#: | 24 # | 60 | 61 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 67 | 67 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 07/29/2026 00:00 | 1 | 53 | 54 | 0 | 0 |
| 07/29/2026 01:00 | 1 | 47 | 48 | 0 | 0 |
| 07/29/2026 02:00 | 1 | 46 | 47 | 0 | 0 |
| 07/29/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 07/29/2026 04:00 | 1 | 46 | 47 | 0 | 0 |
| 07/29/2026 05:00 | 1 | 46 | 47 | 0 | 0 |
| 07/29/2026 06:00 | 1 | 46 | 47 | 0 | 0 |
| 07/29/2026 07:00 | 1 | 46 | 47 | 0 | 0 |
| 07/29/2026 08:00 | 1 | 46 | 47 | 0 | 0 |
| 07/29/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 07/29/2026 10:00 | 1 | 47 | 48 | 0 | 0 |
| 07/29/2026 11:00 | 1 | 54 | 54 | 0 | 0 |
| 07/29/2026 12:00 | 1 | 61 | 61 | 0 | 0 |
| 07/29/2026 13:00 | 1 | 67 | 67 | 0 | 0 |
| 07/29/2026 14:00 | 1 | 67 | 67 | 0 | 0 |
| 07/29/2026 15:00 | 1 | 67 | 67 | 0 | 0 |
| 07/29/2026 16:00 | 1 | 67 | 67 | 0 | 0 |
| 07/29/2026 17:00 | 1 | 67 | 67 | 0 | 0 |
| 07/29/2026 18:00 | 1 | 67 | 68 | 0 | 0 |
| 07/29/2026 19:00 | 1 | 67 | 68 | 0 | 0 |
| 07/29/2026 20:00 | 1 | 67 | 68 | 0 | 0 |
| 07/29/2026 21:00 | 1 | 60 | 62 | 0 | 0 |
| 07/29/2026 22:00 | 1 | 53 | 55 | 0 | 0 |
| 07/29/2026 23:00 | 1 | 47 | 48 | 0 | 0 |
| Average/Sum#: | 24 # | 55 | 56 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 67 | 68 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 07/30/2026 00:00 | 1 | 46 | 47 | 0 | 0 |
| 07/30/2026 01:00 | 1 | 46 | 47 | 0 | 0 |
| 07/30/2026 02:00 | 1 | 46 | 47 | 0 | 0 |
| 07/30/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 07/30/2026 04:00 | 1 | 46 | 47 | 0 | 0 |
| 07/30/2026 05:00 | 1 | 46 | 47 | 0 | 0 |
| 07/30/2026 06:00 | 1 | 46 | 47 | 0 | 0 |
| 07/30/2026 07:00 | 1 | 46 | 47 | 0 | 0 |
| 07/30/2026 08:00 | 1 | 46 | 47 | 0 | 0 |
| 07/30/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 07/30/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 07/30/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 07/30/2026 12:00 | 1 | 46 | 47 | 0 | 0 |
| 07/30/2026 13:00 | 1 | 46 | 47 | 0 | 0 |
| 07/30/2026 14:00 | 1 | 48 | 49 | 0 | 0 |
| 07/30/2026 15:00 | 1 | 48 | 50 | 0 | 0 |
| 07/30/2026 16:00 | 1 | 49 | 51 | 0 | 0 |
| 07/30/2026 17:00 | 1 | 49 | 51 | 0 | 0 |
| 07/30/2026 18:00 | 1 | 54 | 55 | 0 | 0 |
| 07/30/2026 19:00 | 1 | 54 | 55 | 0 | 0 |
| 07/30/2026 20:00 | 1 | 51 | 52 | 0 | 0 |
| 07/30/2026 21:00 | 1 | 47 | 48 | 0 | 0 |
| 07/30/2026 22:00 | 1 | 47 | 48 | 0 | 0 |
| 07/30/2026 23:00 | 1 | 47 | 48 | 0 | 0 |
| Average/Sum#: | 24 # | 47 | 49 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 54 | 55 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 07/31/2026 00:00 | 1 | 47 | 48 | 0 | 0 |
| 07/31/2026 01:00 | 1 | 46 | 47 | 0 | 0 |
| 07/31/2026 02:00 | 1 | 46 | 47 | 0 | 0 |
| 07/31/2026 03:00 | 1 | 46 | 46 | 0 | 0 |
| 07/31/2026 04:00 | 1 | 47 | 47 | 0 | 0 |
| 07/31/2026 05:00 | 1 | 47 | 48 | 0 | 0 |
| 07/31/2026 06:00 | 1 | 47 | 48 | 0 | 0 |
| 07/31/2026 07:00 | 1 | 46 | 47 | 0 | 0 |
| 07/31/2026 08:00 | 1 | 46 | 47 | 0 | 0 |
| 07/31/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 07/31/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 07/31/2026 11:00 | 1 | 47 | 48 | 0 | 0 |
| 07/31/2026 12:00 | 1 | 51 | 52 | 0 | 0 |
| 07/31/2026 13:00 | 1 | 55 | 56 | 0 | 0 |
| 07/31/2026 14:00 | 1 | 59 | 60 | 0 | 0 |
| 07/31/2026 15:00 | 1 | 62 | 63 | 0 | 0 |
| 07/31/2026 16:00 | 1 | 66 | 67 | 0 | 0 |
| 07/31/2026 17:00 | 1 | 71 | 73 | 0 | 0 |
| 07/31/2026 18:00 | 1 | 75 | 76 | 0 | 0 |
| 07/31/2026 19:00 | 1 | 74 | 75 | 0 | 0 |
| 07/31/2026 20:00 | 1 | 71 | 72 | 0 | 0 |
| 07/31/2026 21:00 | 1 | 67 | 68 | 0 | 0 |
| 07/31/2026 22:00 | 1 | 66 | 67 | 0 | 0 |
| 07/31/2026 23:00 | 1 | 60 | 61 | 0 | 0 |
| Average/Sum#: | 24 # | 56 | 57 | 0 | 0 |
| Minimum: | 1 | 46 | 46 | 0 | 0 |
| Maximum: | 1 | 75 | 76 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 08/01/2026 00:00 | 1 | 53 | 54 | 0 | 0 |
| 08/01/2026 01:00 | 1 | 47 | 48 | 0 | 0 |
| 08/01/2026 02:00 | 1 | 46 | 47 | 0 | 0 |
| 08/01/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 08/01/2026 04:00 | 1 | 46 | 47 | 0 | 0 |
| 08/01/2026 05:00 | 1 | 46 | 47 | 0 | 0 |
| 08/01/2026 06:00 | 1 | 46 | 47 | 0 | 0 |
| 08/01/2026 07:00 | 1 | 46 | 47 | 0 | 0 |
| 08/01/2026 08:00 | 1 | 46 | 47 | 0 | 0 |
| 08/01/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 08/01/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 08/01/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 08/01/2026 12:00 | 1 | 46 | 47 | 0 | 0 |
| 08/01/2026 13:00 | 1 | 46 | 47 | 0 | 0 |
| 08/01/2026 14:00 | 1 | 47 | 48 | 0 | 0 |
| 08/01/2026 15:00 | 1 | 54 | 55 | 0 | 0 |
| 08/01/2026 16:00 | 1 | 61 | 62 | 0 | 0 |
| 08/01/2026 17:00 | 1 | 68 | 69 | 0 | 0 |
| 08/01/2026 18:00 | 1 | 72 | 73 | 0 | 0 |
| 08/01/2026 19:00 | 1 | 75 | 76 | 0 | 0 |
| 08/01/2026 20:00 | 1 | 73 | 74 | 0 | 0 |
| 08/01/2026 21:00 | 1 | 69 | 70 | 0 | 0 |
| 08/01/2026 22:00 | 1 | 66 | 68 | 0 | 0 |
| 08/01/2026 23:00 | 1 | 62 | 64 | 0 | 0 |
| Average/Sum#: | 24 # | 54 | 55 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 75 | 76 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 08/02/2026 00:00 | 1 | 56 | 57 | 0 | 0 |
| 08/02/2026 01:00 | 1 | 49 | 50 | 0 | 0 |
| 08/02/2026 02:00 | 1 | 46 | 47 | 0 | 0 |
| 08/02/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 08/02/2026 04:00 | 1 | 46 | 47 | 0 | 0 |
| 08/02/2026 05:00 | 1 | 46 | 47 | 0 | 0 |
| 08/02/2026 06:00 | 1 | 46 | 47 | 0 | 0 |
| 08/02/2026 07:00 | 1 | 46 | 47 | 0 | 0 |
| 08/02/2026 08:00 | 1 | 46 | 47 | 0 | 0 |
| 08/02/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 08/02/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 08/02/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 08/02/2026 12:00 | 1 | 46 | 47 | 0 | 0 |
| 08/02/2026 13:00 | 1 | 47 | 48 | 0 | 0 |
| 08/02/2026 14:00 | 1 | 54 | 55 | 0 | 0 |
| 08/02/2026 15:00 | 1 | 61 | 62 | 0 | 0 |
| 08/02/2026 16:00 | 1 | 67 | 68 | 0 | 0 |
| 08/02/2026 17:00 | 1 | 67 | 68 | 0 | 0 |
| 08/02/2026 18:00 | 1 | 67 | 68 | 0 | 0 |
| 08/02/2026 19:00 | 1 | 67 | 67 | 0 | 0 |
| 08/02/2026 20:00 | 1 | 67 | 67 | 0 | 0 |
| 08/02/2026 21:00 | 1 | 67 | 67 | 0 | 0 |
| 08/02/2026 22:00 | 1 | 64 | 65 | 0 | 0 |
| 08/02/2026 23:00 | 1 | 60 | 62 | 0 | 0 |
| Average/Sum#: | 24 # | 54 | 55 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 67 | 68 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 08/03/2026 00:00 | 1 | 54 | 55 | 0 | 0 |
| 08/03/2026 01:00 | 1 | 51 | 52 | 0 | 0 |
| 08/03/2026 02:00 | 1 | 47 | 48 | 0 | 0 |
| 08/03/2026 03:00 | 1 | 47 | 48 | 0 | 0 |
| 08/03/2026 04:00 | 1 | 49 | 50 | 0 | 0 |
| 08/03/2026 05:00 | 1 | 51 | 52 | 0 | 0 |
| 08/03/2026 06:00 | 1 | 51 | 52 | 0 | 0 |
| 08/03/2026 07:00 | 1 | 48 | 49 | 0 | 0 |
| 08/03/2026 08:00 | 1 | 46 | 47 | 0 | 0 |
| 08/03/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 08/03/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 08/03/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 08/03/2026 12:00 | 1 | 48 | 49 | 0 | 0 |
| 08/03/2026 13:00 | 1 | 50 | 51 | 0 | 0 |
| 08/03/2026 14:00 | 1 | 57 | 58 | 0 | 10 |
| 08/03/2026 15:00 | 1 | 62 | 63 | 0 | 22 |
| 08/03/2026 16:00 | 1 | 68 | 69 | 0 | 22 |
| 08/03/2026 17:00 | 1 | 70 | 71 | 0 | 22 |
| 08/03/2026 18:00 | 1 | 74 | 75 | 0 | 22 |
| 08/03/2026 19:00 | 1 | 76 | 77 | 0 | 22 |
| 08/03/2026 20:00 | 1 | 77 | 78 | 0 | 22 |
| 08/03/2026 21:00 | 1 | 74 | 75 | 0 | 0 |
| 08/03/2026 22:00 | 1 | 66 | 68 | 0 | 0 |
| 08/03/2026 23:00 | 1 | 60 | 62 | 0 | 0 |
| Average/Sum#: | 24 # | 57 | 58 | 0 | 6 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 77 | 78 | 0 | 22 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 08/04/2026 00:00 | 1 | 54 | 55 | 0 | 0 |
| 08/04/2026 01:00 | 1 | 51 | 52 | 0 | 0 |
| 08/04/2026 02:00 | 1 | 47 | 48 | 0 | 0 |
| 08/04/2026 03:00 | 1 | 47 | 48 | 0 | 0 |
| 08/04/2026 04:00 | 1 | 50 | 51 | 0 | 0 |
| 08/04/2026 05:00 | 1 | 52 | 53 | 0 | 0 |
| 08/04/2026 06:00 | 1 | 53 | 54 | 0 | 0 |
| 08/04/2026 07:00 | 1 | 50 | 51 | 0 | 0 |
| 08/04/2026 08:00 | 1 | 47 | 48 | 0 | 0 |
| 08/04/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 08/04/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 08/04/2026 11:00 | 1 | 47 | 48 | 0 | 0 |
| 08/04/2026 12:00 | 1 | 50 | 51 | 0 | 0 |
| 08/04/2026 13:00 | 1 | 53 | 55 | 0 | 0 |
| 08/04/2026 14:00 | 1 | 60 | 61 | 0 | 7 |
| 08/04/2026 15:00 | 1 | 66 | 67 | 0 | 22 |
| 08/04/2026 16:00 | 1 | 70 | 71 | 0 | 22 |
| 08/04/2026 17:00 | 1 | 70 | 71 | 0 | 22 |
| 08/04/2026 18:00 | 1 | 72 | 72 | 0 | 22 |
| 08/04/2026 19:00 | 1 | 71 | 72 | 0 | 22 |
| 08/04/2026 20:00 | 1 | 69 | 71 | 0 | 0 |
| 08/04/2026 21:00 | 1 | 66 | 68 | 0 | 0 |
| 08/04/2026 22:00 | 1 | 60 | 61 | 0 | 0 |
| 08/04/2026 23:00 | 1 | 57 | 58 | 0 | 0 |
| Average/Sum#: | 24 # | 56 | 58 | 0 | 5 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 72 | 72 | 0 | 22 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 08/05/2026 00:00 | 1 | 53 | 54 | 0 | 0 |
| 08/05/2026 01:00 | 1 | 52 | 53 | 0 | 0 |
| 08/05/2026 02:00 | 1 | 48 | 49 | 0 | 0 |
| 08/05/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 08/05/2026 04:00 | 1 | 46 | 47 | 0 | 0 |
| 08/05/2026 05:00 | 1 | 46 | 47 | 0 | 0 |
| 08/05/2026 06:00 | 1 | 47 | 48 | 0 | 0 |
| 08/05/2026 07:00 | 1 | 47 | 48 | 0 | 0 |
| 08/05/2026 08:00 | 1 | 47 | 48 | 0 | 0 |
| 08/05/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 08/05/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 08/05/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 08/05/2026 12:00 | 1 | 47 | 48 | 0 | 0 |
| 08/05/2026 13:00 | 1 | 48 | 49 | 0 | 0 |
| 08/05/2026 14:00 | 1 | 55 | 55 | 0 | 20 |
| 08/05/2026 15:00 | 1 | 61 | 61 | 0 | 22 |
| 08/05/2026 16:00 | 1 | 67 | 68 | 0 | 22 |
| 08/05/2026 17:00 | 1 | 68 | 70 | 0 | 22 |
| 08/05/2026 18:00 | 1 | 69 | 70 | 0 | 22 |
| 08/05/2026 19:00 | 1 | 67 | 68 | 0 | 22 |
| 08/05/2026 20:00 | 1 | 67 | 68 | 0 | 0 |
| 08/05/2026 21:00 | 1 | 66 | 68 | 0 | 0 |
| 08/05/2026 22:00 | 1 | 64 | 65 | 0 | 0 |
| 08/05/2026 23:00 | 1 | 60 | 62 | 0 | 0 |
| Average/Sum#: | 24 # | 55 | 56 | 0 | 5 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 69 | 70 | 0 | 22 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 08/06/2026 00:00 | 1 | 54 | 55 | 0 | 0 |
| 08/06/2026 01:00 | 1 | 50 | 51 | 0 | 0 |
| 08/06/2026 02:00 | 1 | 47 | 48 | 0 | 0 |
| 08/06/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 08/06/2026 04:00 | 1 | 46 | 47 | 0 | 0 |
| 08/06/2026 05:00 | 1 | 47 | 48 | 0 | 0 |
| 08/06/2026 06:00 | 1 | 47 | 48 | 0 | 0 |
| 08/06/2026 07:00 | 1 | 47 | 48 | 0 | 0 |
| 08/06/2026 08:00 | 1 | 46 | 47 | 0 | 0 |
| 08/06/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 08/06/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 08/06/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 08/06/2026 12:00 | 1 | 46 | 47 | 0 | 0 |
| 08/06/2026 13:00 | 1 | 47 | 48 | 0 | 0 |
| 08/06/2026 14:00 | 1 | 53 | 54 | 0 | 0 |
| 08/06/2026 15:00 | 1 | 60 | 61 | 13 | 14 |
| 08/06/2026 16:00 | 1 | 67 | 67 | 0 | 20 |
| 08/06/2026 17:00 | 1 | 71 | 71 | 0 | 22 |
| 08/06/2026 18:00 | 1 | 74 | 74 | 0 | 22 |
| 08/06/2026 19:00 | 1 | 73 | 74 | 0 | 22 |
| 08/06/2026 20:00 | 1 | 69 | 70 | 0 | 0 |
| 08/06/2026 21:00 | 1 | 68 | 69 | 0 | 0 |
| 08/06/2026 22:00 | 1 | 65 | 66 | 0 | 0 |
| 08/06/2026 23:00 | 1 | 63 | 64 | 0 | 0 |
| Average/Sum#: | 24 # | 55 | 56 | 1 | 4 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 74 | 74 | 13 | 22 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 08/07/2026 00:00 | 1 | 59 | 60 | 0 | 0 |
| 08/07/2026 01:00 | 1 | 58 | 60 | 0 | 0 |
| 08/07/2026 02:00 | 1 | 58 | 60 | 0 | 0 |
| 08/07/2026 03:00 | 1 | 55 | 57 | 0 | 0 |
| 08/07/2026 04:00 | 1 | 55 | 57 | 0 | 0 |
| 08/07/2026 05:00 | 1 | 55 | 57 | 0 | 0 |
| 08/07/2026 06:00 | 1 | 55 | 56 | 0 | 0 |
| 08/07/2026 07:00 | 1 | 51 | 52 | 0 | 0 |
| 08/07/2026 08:00 | 1 | 47 | 48 | 0 | 0 |
| 08/07/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 08/07/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 08/07/2026 11:00 | 1 | 48 | 48 | 6 | 0 |
| 08/07/2026 12:00 | 1 | 48 | 49 | 19 | 0 |
| 08/07/2026 13:00 | 1 | 51 | 52 | 18 | 0 |
| 08/07/2026 14:00 | 1 | 56 | 57 | 0 | 0 |
| 08/07/2026 15:00 | 1 | 63 | 63 | 0 | 0 |
| 08/07/2026 16:00 | 1 | 67 | 67 | 0 | 0 |
| 08/07/2026 17:00 | 1 | 68 | 69 | 0 | 0 |
| 08/07/2026 18:00 | 1 | 71 | 72 | 0 | 0 |
| 08/07/2026 19:00 | 1 | 71 | 73 | 0 | 0 |
| 08/07/2026 20:00 | 1 | 70 | 72 | 0 | 0 |
| 08/07/2026 21:00 | 1 | 67 | 69 | 0 | 0 |
| 08/07/2026 22:00 | 1 | 64 | 65 | 0 | 0 |
| 08/07/2026 23:00 | 1 | 61 | 62 | 0 | 0 |
| Average/Sum#: | 24 # | 58 | 59 | 2 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 71 | 73 | 19 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 08/08/2026 00:00 | 1 | 58 | 59 | 0 | 0 |
| 08/08/2026 01:00 | 1 | 55 | 57 | 0 | 0 |
| 08/08/2026 02:00 | 1 | 51 | 52 | 0 | 0 |
| 08/08/2026 03:00 | 1 | 47 | 48 | 0 | 0 |
| 08/08/2026 04:00 | 1 | 49 | 50 | 0 | 0 |
| 08/08/2026 05:00 | 1 | 51 | 52 | 0 | 0 |
| 08/08/2026 06:00 | 1 | 51 | 52 | 0 | 0 |
| 08/08/2026 07:00 | 1 | 47 | 48 | 0 | 0 |
| 08/08/2026 08:00 | 1 | 45 | 46 | 0 | 0 |
| 08/08/2026 09:00 | 1 | 45 | 46 | 0 | 0 |
| 08/08/2026 10:00 | 1 | 45 | 46 | 0 | 0 |
| 08/08/2026 11:00 | 1 | 45 | 46 | 0 | 0 |
| 08/08/2026 12:00 | 1 | 45 | 46 | 0 | 0 |
| 08/08/2026 13:00 | 1 | 46 | 47 | 0 | 0 |
| 08/08/2026 14:00 | 1 | 54 | 54 | 0 | 0 |
| 08/08/2026 15:00 | 1 | 61 | 62 | 0 | 0 |
| 08/08/2026 16:00 | 1 | 67 | 68 | 0 | 0 |
| 08/08/2026 17:00 | 1 | 67 | 68 | 0 | 0 |
| 08/08/2026 18:00 | 1 | 67 | 68 | 0 | 0 |
| 08/08/2026 19:00 | 1 | 67 | 68 | 0 | 0 |
| 08/08/2026 20:00 | 1 | 67 | 67 | 0 | 0 |
| 08/08/2026 21:00 | 1 | 67 | 67 | 0 | 0 |
| 08/08/2026 22:00 | 1 | 64 | 65 | 0 | 0 |
| 08/08/2026 23:00 | 1 | 59 | 61 | 0 | 0 |
| Average/Sum#: | 24 # | 55 | 56 | 0 | 0 |
| Minimum: | 1 | 45 | 46 | 0 | 0 |
| Maximum: | 1 | 67 | 68 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 08/09/2026 00:00 | 1 | 53 | 54 | 0 | 0 |
| 08/09/2026 01:00 | 1 | 49 | 50 | 0 | 0 |
| 08/09/2026 02:00 | 1 | 46 | 47 | 0 | 0 |
| 08/09/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 08/09/2026 04:00 | 1 | 46 | 47 | 0 | 0 |
| 08/09/2026 05:00 | 1 | 48 | 49 | 0 | 0 |
| 08/09/2026 06:00 | 1 | 48 | 49 | 0 | 0 |
| 08/09/2026 07:00 | 1 | 48 | 49 | 0 | 0 |
| 08/09/2026 08:00 | 1 | 46 | 47 | 0 | 0 |
| 08/09/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 08/09/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 08/09/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 08/09/2026 12:00 | 1 | 46 | 47 | 0 | 0 |
| 08/09/2026 13:00 | 1 | 50 | 51 | 0 | 0 |
| 08/09/2026 14:00 | 1 | 57 | 58 | 0 | 0 |
| 08/09/2026 15:00 | 1 | 66 | 68 | 0 | 0 |
| 08/09/2026 16:00 | 1 | 73 | 75 | 0 | 0 |
| 08/09/2026 17:00 | 1 | 75 | 77 | 0 | 0 |
| 08/09/2026 18:00 | 1 | 75 | 77 | 0 | 0 |
| 08/09/2026 19:00 | 1 | 72 | 74 | 0 | 0 |
| 08/09/2026 20:00 | 1 | 69 | 71 | 0 | 0 |
| 08/09/2026 21:00 | 1 | 66 | 68 | 0 | 0 |
| 08/09/2026 22:00 | 1 | 60 | 61 | 0 | 0 |
| 08/09/2026 23:00 | 1 | 53 | 54 | 0 | 0 |
| Average/Sum#: | 24 # | 55 | 57 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 75 | 77 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 08/10/2026 00:00 | 1 | 47 | 48 | 0 | 0 |
| 08/10/2026 01:00 | 1 | 46 | 47 | 0 | 0 |
| 08/10/2026 02:00 | 1 | 46 | 47 | 0 | 0 |
| 08/10/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 08/10/2026 04:00 | 1 | 48 | 49 | 0 | 0 |
| 08/10/2026 05:00 | 1 | 48 | 49 | 0 | 0 |
| 08/10/2026 06:00 | 1 | 50 | 51 | 0 | 0 |
| 08/10/2026 07:00 | 1 | 48 | 49 | 0 | 0 |
| 08/10/2026 08:00 | 1 | 48 | 49 | 0 | 0 |
| 08/10/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 08/10/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 08/10/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 08/10/2026 12:00 | 1 | 47 | 47 | 0 | 0 |
| 08/10/2026 13:00 | 1 | 50 | 50 | 0 | 0 |
| 08/10/2026 14:00 | 1 | 52 | 52 | 0 | 0 |
| 08/10/2026 15:00 | 1 | 58 | 59 | 0 | 0 |
| 08/10/2026 16:00 | 1 | 64 | 65 | 0 | 0 |
| 08/10/2026 17:00 | 1 | 72 | 74 | 0 | 0 |
| 08/10/2026 18:00 | 1 | 75 | 76 | 0 | 0 |
| 08/10/2026 19:00 | 1 | 74 | 75 | 0 | 0 |
| 08/10/2026 20:00 | 1 | 71 | 72 | 0 | 0 |
| 08/10/2026 21:00 | 1 | 70 | 71 | 0 | 0 |
| 08/10/2026 22:00 | 1 | 66 | 67 | 0 | 0 |
| 08/10/2026 23:00 | 1 | 60 | 61 | 0 | 0 |
| Average/Sum#: | 24 # | 55 | 56 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 75 | 76 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 08/11/2026 00:00 | 1 | 53 | 54 | 0 | 0 |
| 08/11/2026 01:00 | 1 | 49 | 50 | 0 | 0 |
| 08/11/2026 02:00 | 1 | 47 | 49 | 0 | 0 |
| 08/11/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 08/11/2026 04:00 | 1 | 46 | 47 | 0 | 0 |
| 08/11/2026 05:00 | 1 | 48 | 49 | 0 | 0 |
| 08/11/2026 06:00 | 1 | 50 | 51 | 0 | 0 |
| 08/11/2026 07:00 | 1 | 50 | 51 | 0 | 0 |
| 08/11/2026 08:00 | 1 | 48 | 49 | 0 | 0 |
| 08/11/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 08/11/2026 10:00 | 1 | 47 | 48 | 0 | 0 |
| 08/11/2026 11:00 | 1 | 51 | 51 | 0 | 0 |
| 08/11/2026 12:00 | 1 | 55 | 56 | 0 | 0 |
| 08/11/2026 13:00 | 1 | 62 | 63 | 0 | 0 |
| 08/11/2026 14:00 | 1 | 66 | 67 | 0 | 0 |
| 08/11/2026 15:00 | 1 | 69 | 70 | 0 | 0 |
| 08/11/2026 16:00 | 1 | 71 | 72 | 0 | 0 |
| 08/11/2026 17:00 | 1 | 74 | 75 | 0 | 0 |
| 08/11/2026 18:00 | 1 | 76 | 77 | 0 | 0 |
| 08/11/2026 19:00 | 1 | 76 | 77 | 0 | 0 |
| 08/11/2026 20:00 | 1 | 74 | 75 | 0 | 0 |
| 08/11/2026 21:00 | 1 | 68 | 70 | 0 | 0 |
| 08/11/2026 22:00 | 1 | 61 | 63 | 0 | 0 |
| 08/11/2026 23:00 | 1 | 53 | 54 | 0 | 0 |
| Average/Sum#: | 24 # | 58 | 59 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 76 | 77 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 08/12/2026 00:00 | 1 | 49 | 50 | 0 | 0 |
| 08/12/2026 01:00 | 1 | 46 | 47 | 0 | 0 |
| 08/12/2026 02:00 | 1 | 46 | 47 | 0 | 0 |
| 08/12/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 08/12/2026 04:00 | 1 | 48 | 49 | 0 | 0 |
| 08/12/2026 05:00 | 1 | 51 | 53 | 0 | 0 |
| 08/12/2026 06:00 | 1 | 51 | 53 | 0 | 0 |
| 08/12/2026 07:00 | 1 | 50 | 51 | 0 | 0 |
| 08/12/2026 08:00 | 1 | 46 | 47 | 0 | 0 |
| 08/12/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 08/12/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 08/12/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 08/12/2026 12:00 | 1 | 46 | 47 | 0 | 0 |
| 08/12/2026 13:00 | 1 | 53 | 54 | 0 | 0 |
| 08/12/2026 14:00 | 1 | 60 | 60 | 0 | 0 |
| 08/12/2026 15:00 | 1 | 66 | 67 | 0 | 0 |
| 08/12/2026 16:00 | 1 | 66 | 67 | 0 | 0 |
| 08/12/2026 17:00 | 1 | 66 | 67 | 0 | 0 |
| 08/12/2026 18:00 | 1 | 66 | 67 | 0 | 0 |
| 08/12/2026 19:00 | 1 | 66 | 68 | 0 | 0 |
| 08/12/2026 20:00 | 1 | 66 | 68 | 0 | 0 |
| 08/12/2026 21:00 | 1 | 60 | 62 | 0 | 0 |
| 08/12/2026 22:00 | 1 | 54 | 55 | 0 | 0 |
| 08/12/2026 23:00 | 1 | 47 | 48 | 0 | 0 |
| Average/Sum#: | 24 # | 54 | 55 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 66 | 68 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 08/13/2026 00:00 | 1 | 46 | 47 | 0 | 0 |
| 08/13/2026 01:00 | 1 | 46 | 47 | 0 | 0 |
| 08/13/2026 02:00 | 1 | 46 | 47 | 0 | 0 |
| 08/13/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 08/13/2026 04:00 | 1 | 46 | 47 | 0 | 0 |
| 08/13/2026 05:00 | 1 | 46 | 47 | 0 | 0 |
| 08/13/2026 06:00 | 1 | 46 | 47 | 0 | 0 |
| 08/13/2026 07:00 | 1 | 46 | 47 | 0 | 0 |
| 08/13/2026 08:00 | 1 | 46 | 47 | 0 | 0 |
| 08/13/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 08/13/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 08/13/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 08/13/2026 12:00 | 1 | 47 | 48 | 0 | 0 |
| 08/13/2026 13:00 | 1 | 54 | 55 | 0 | 0 |
| 08/13/2026 14:00 | 1 | 61 | 62 | 0 | 0 |
| 08/13/2026 15:00 | 1 | 66 | 67 | 0 | 0 |
| 08/13/2026 16:00 | 1 | 66 | 67 | 0 | 0 |
| 08/13/2026 17:00 | 1 | 66 | 67 | 0 | 0 |
| 08/13/2026 18:00 | 1 | 66 | 67 | 0 | 0 |
| 08/13/2026 19:00 | 1 | 60 | 61 | 0 | 0 |
| 08/13/2026 20:00 | 1 | 53 | 54 | 0 | 0 |
| 08/13/2026 21:00 | 1 | 46 | 47 | 0 | 0 |
| 08/13/2026 22:00 | 1 | 46 | 47 | 0 | 0 |
| 08/13/2026 23:00 | 1 | 46 | 47 | 0 | 0 |
| Average/Sum#: | 24 # | 51 | 52 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 66 | 67 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 08/14/2026 00:00 | 1 | 46 | 47 | 0 | 0 |
| 08/14/2026 01:00 | 1 | 46 | 47 | 0 | 0 |
| 08/14/2026 02:00 | 1 | 46 | 47 | 0 | 0 |
| 08/14/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 08/14/2026 04:00 | 1 | 46 | 47 | 0 | 0 |
| 08/14/2026 05:00 | 1 | 46 | 47 | 0 | 0 |
| 08/14/2026 06:00 | 1 | 47 | 48 | 0 | 0 |
| 08/14/2026 07:00 | 1 | 47 | 48 | 0 | 0 |
| 08/14/2026 08:00 | 1 | 47 | 48 | 0 | 0 |
| 08/14/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 08/14/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 08/14/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 08/14/2026 12:00 | 1 | 46 | 47 | 0 | 0 |
| 08/14/2026 13:00 | 1 | 46 | 47 | 0 | 0 |
| 08/14/2026 14:00 | 1 | 46 | 47 | 0 | 0 |
| 08/14/2026 15:00 | 1 | 46 | 47 | 0 | 0 |
| 08/14/2026 16:00 | 1 | 46 | 47 | 0 | 0 |
| 08/14/2026 17:00 | 1 | 47 | 48 | 0 | 0 |
| 08/14/2026 18:00 | 1 | 47 | 48 | 0 | 0 |
| 08/14/2026 19:00 | 1 | 47 | 48 | 0 | 0 |
| 08/14/2026 20:00 | 1 | 46 | 47 | 0 | 0 |
| 08/14/2026 21:00 | 1 | 46 | 47 | 0 | 0 |
| 08/14/2026 22:00 | 1 | 46 | 47 | 0 | 0 |
| 08/14/2026 23:00 | 1 | 46 | 47 | 0 | 0 |
| Average/Sum#: | 24 # | 46 | 47 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 47 | 48 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 08/15/2026 00:00 | 1 | 46 | 47 | 0 | 0 |
| 08/15/2026 01:00 | 1 | 46 | 47 | 0 | 0 |
| 08/15/2026 02:00 | 1 | 46 | 47 | 0 | 0 |
| 08/15/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 08/15/2026 04:00 | 1 | 46 | 47 | 0 | 0 |
| 08/15/2026 05:00 | 1 | 46 | 47 | 0 | 0 |
| 08/15/2026 06:00 | 1 | 46 | 47 | 0 | 0 |
| 08/15/2026 07:00 | 1 | 46 | 47 | 0 | 0 |
| 08/15/2026 08:00 | 1 | 46 | 47 | 0 | 0 |
| 08/15/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 08/15/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 08/15/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 08/15/2026 12:00 | 1 | 46 | 47 | 0 | 0 |
| 08/15/2026 13:00 | 1 | 46 | 47 | 0 | 0 |
| 08/15/2026 14:00 | 1 | 46 | 47 | 0 | 0 |
| 08/15/2026 15:00 | 1 | 46 | 47 | 0 | 0 |
| 08/15/2026 16:00 | 1 | 47 | 48 | 0 | 0 |
| 08/15/2026 17:00 | 1 | 49 | 50 | 0 | 0 |
| 08/15/2026 18:00 | 1 | 50 | 50 | 0 | 0 |
| 08/15/2026 19:00 | 1 | 50 | 51 | 0 | 0 |
| 08/15/2026 20:00 | 1 | 48 | 49 | 0 | 0 |
| 08/15/2026 21:00 | 1 | 51 | 52 | 0 | 0 |
| 08/15/2026 22:00 | 1 | 54 | 55 | 0 | 0 |
| 08/15/2026 23:00 | 1 | 58 | 59 | 0 | 0 |
| Average/Sum#: | 24 # | 48 | 49 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 58 | 59 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 08/16/2026 00:00 | 1 | 58 | 59 | 0 | 0 |
| 08/16/2026 01:00 | 1 | 54 | 55 | 0 | 0 |
| 08/16/2026 02:00 | 1 | 50 | 51 | 0 | 0 |
| 08/16/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 08/16/2026 04:00 | 1 | 46 | 47 | 0 | 0 |
| 08/16/2026 05:00 | 1 | 46 | 47 | 0 | 0 |
| 08/16/2026 06:00 | 1 | 46 | 47 | 0 | 0 |
| 08/16/2026 07:00 | 1 | 46 | 47 | 0 | 0 |
| 08/16/2026 08:00 | 1 | 46 | 47 | 0 | 0 |
| 08/16/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 08/16/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 08/16/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 08/16/2026 12:00 | 1 | 47 | 48 | 0 | 0 |
| 08/16/2026 13:00 | 1 | 54 | 55 | 0 | 0 |
| 08/16/2026 14:00 | 1 | 61 | 62 | 0 | 0 |
| 08/16/2026 15:00 | 1 | 66 | 67 | 0 | 0 |
| 08/16/2026 16:00 | 1 | 66 | 67 | 0 | 0 |
| 08/16/2026 17:00 | 1 | 67 | 68 | 0 | 0 |
| 08/16/2026 18:00 | 1 | 68 | 69 | 0 | 0 |
| 08/16/2026 19:00 | 1 | 67 | 68 | 0 | 0 |
| 08/16/2026 20:00 | 1 | 66 | 67 | 0 | 0 |
| 08/16/2026 21:00 | 1 | 64 | 65 | 0 | 0 |
| 08/16/2026 22:00 | 1 | 61 | 62 | 0 | 0 |
| 08/16/2026 23:00 | 1 | 54 | 55 | 0 | 0 |
| Average/Sum#: | 24 # | 55 | 56 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 68 | 69 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 08/17/2026 00:00 | 1 | 50 | 51 | 0 | 0 |
| 08/17/2026 01:00 | 1 | 46 | 47 | 0 | 0 |
| 08/17/2026 02:00 | 1 | 46 | 47 | 0 | 0 |
| 08/17/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 08/17/2026 04:00 | 1 | 46 | 47 | 0 | 0 |
| 08/17/2026 05:00 | 1 | 46 | 47 | 0 | 0 |
| 08/17/2026 06:00 | 1 | 46 | 47 | 0 | 0 |
| 08/17/2026 07:00 | 1 | 46 | 47 | 0 | 0 |
| 08/17/2026 08:00 | 1 | 46 | 47 | 0 | 0 |
| 08/17/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 08/17/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 08/17/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 08/17/2026 12:00 | 1 | 47 | 48 | 0 | 0 |
| 08/17/2026 13:00 | 1 | 54 | 55 | 0 | 0 |
| 08/17/2026 14:00 | 1 | 63 | 64 | 0 | 0 |
| 08/17/2026 15:00 | 1 | 70 | 71 | 0 | 0 |
| 08/17/2026 16:00 | 1 | 72 | 73 | 0 | 0 |
| 08/17/2026 17:00 | 1 | 73 | 74 | 0 | 0 |
| 08/17/2026 18:00 | 1 | 73 | 74 | 0 | 0 |
| 08/17/2026 19:00 | 1 | 73 | 74 | 0 | 0 |
| 08/17/2026 20:00 | 1 | 70 | 71 | 0 | 0 |
| 08/17/2026 21:00 | 1 | 63 | 64 | 0 | 0 |
| 08/17/2026 22:00 | 1 | 56 | 57 | 0 | 0 |
| 08/17/2026 23:00 | 1 | 49 | 50 | 0 | 0 |
| Average/Sum#: | 24 # | 55 | 56 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 73 | 74 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 08/18/2026 00:00 | 1 | 47 | 48 | 0 | 0 |
| 08/18/2026 01:00 | 1 | 46 | 47 | 0 | 0 |
| 08/18/2026 02:00 | 1 | 46 | 47 | 0 | 0 |
| 08/18/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 08/18/2026 04:00 | 1 | 46 | 47 | 0 | 0 |
| 08/18/2026 05:00 | 1 | 46 | 47 | 0 | 0 |
| 08/18/2026 06:00 | 1 | 46 | 47 | 0 | 0 |
| 08/18/2026 07:00 | 1 | 46 | 47 | 0 | 0 |
| 08/18/2026 08:00 | 1 | 46 | 46 | 0 | 0 |
| 08/18/2026 09:00 | 1 | 46 | 46 | 0 | 0 |
| 08/18/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 08/18/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 08/18/2026 12:00 | 1 | 47 | 48 | 0 | 0 |
| 08/18/2026 13:00 | 1 | 54 | 55 | 0 | 0 |
| 08/18/2026 14:00 | 1 | 62 | 62 | 0 | 0 |
| 08/18/2026 15:00 | 1 | 68 | 68 | 0 | 0 |
| 08/18/2026 16:00 | 1 | 69 | 69 | 0 | 0 |
| 08/18/2026 17:00 | 1 | 72 | 72 | 0 | 0 |
| 08/18/2026 18:00 | 1 | 75 | 75 | 0 | 0 |
| 08/18/2026 19:00 | 1 | 74 | 75 | 0 | 0 |
| 08/18/2026 20:00 | 1 | 70 | 71 | 0 | 0 |
| 08/18/2026 21:00 | 1 | 63 | 64 | 0 | 0 |
| 08/18/2026 22:00 | 1 | 56 | 57 | 0 | 0 |
| 08/18/2026 23:00 | 1 | 50 | 51 | 0 | 0 |
| Average/Sum#: | 24 # | 55 | 55 | 0 | 0 |
| Minimum: | 1 | 46 | 46 | 0 | 0 |
| Maximum: | 1 | 75 | 75 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 08/19/2026 00:00 | 1 | 47 | 48 | 0 | 0 |
| 08/19/2026 01:00 | 1 | 46 | 47 | 0 | 0 |
| 08/19/2026 02:00 | 1 | 46 | 47 | 0 | 0 |
| 08/19/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 08/19/2026 04:00 | 1 | 46 | 47 | 0 | 0 |
| 08/19/2026 05:00 | 1 | 46 | 47 | 0 | 0 |
| 08/19/2026 06:00 | 1 | 46 | 47 | 0 | 0 |
| 08/19/2026 07:00 | 1 | 46 | 47 | 0 | 0 |
| 08/19/2026 08:00 | 1 | 45 | 46 | 0 | 0 |
| 08/19/2026 09:00 | 1 | 45 | 46 | 0 | 0 |
| 08/19/2026 10:00 | 1 | 45 | 46 | 0 | 0 |
| 08/19/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 08/19/2026 12:00 | 1 | 47 | 48 | 0 | 0 |
| 08/19/2026 13:00 | 1 | 54 | 55 | 0 | 0 |
| 08/19/2026 14:00 | 1 | 61 | 62 | 0 | 0 |
| 08/19/2026 15:00 | 1 | 67 | 69 | 13 | 16 |
| 08/19/2026 16:00 | 1 | 68 | 70 | 0 | 22 |
| 08/19/2026 17:00 | 1 | 71 | 72 | 0 | 22 |
| 08/19/2026 18:00 | 1 | 74 | 75 | 0 | 22 |
| 08/19/2026 19:00 | 1 | 77 | 78 | 0 | 22 |
| 08/19/2026 20:00 | 1 | 75 | 76 | 0 | 22 |
| 08/19/2026 21:00 | 1 | 69 | 70 | 0 | 22 |
| 08/19/2026 22:00 | 1 | 63 | 64 | 0 | 0 |
| 08/19/2026 23:00 | 1 | 58 | 60 | 0 | 0 |
| Average/Sum#: | 24 # | 56 | 57 | 1 | 6 |
| Minimum: | 1 | 45 | 46 | 0 | 0 |
| Maximum: | 1 | 77 | 78 | 13 | 22 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 08/20/2026 00:00 | 1 | 56 | 58 | 0 | 0 |
| 08/20/2026 01:00 | 1 | 52 | 54 | 0 | 0 |
| 08/20/2026 02:00 | 1 | 48 | 49 | 0 | 0 |
| 08/20/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 08/20/2026 04:00 | 1 | 46 | 47 | 0 | 0 |
| 08/20/2026 05:00 | 1 | 46 | 47 | 0 | 0 |
| 08/20/2026 06:00 | 1 | 46 | 47 | 0 | 0 |
| 08/20/2026 07:00 | 1 | 46 | 47 | 0 | 0 |
| 08/20/2026 08:00 | 1 | 46 | 46 | 0 | 0 |
| 08/20/2026 09:00 | 1 | 46 | 46 | 0 | 0 |
| 08/20/2026 10:00 | 1 | 45 | 46 | 0 | 0 |
| 08/20/2026 11:00 | 1 | 45 | 46 | 0 | 0 |
| 08/20/2026 12:00 | 1 | 47 | 48 | 20 | 0 |
| 08/20/2026 13:00 | 1 | 54 | 55 | 20 | 0 |
| 08/20/2026 14:00 | 1 | 61 | 62 | 0 | 0 |
| 08/20/2026 15:00 | 1 | 67 | 68 | 0 | 0 |
| 08/20/2026 16:00 | 1 | 68 | 68 | 21 | 0 |
| 08/20/2026 17:00 | 1 | 71 | 72 | 22 | 0 |
| 08/20/2026 18:00 | 1 | 75 | 76 | 22 | 0 |
| 08/20/2026 19:00 | 1 | 77 | 79 | 22 | 0 |
| 08/20/2026 20:00 | 1 | 76 | 77 | 22 | 0 |
| 08/20/2026 21:00 | 1 | 70 | 71 | 2 | 0 |
| 08/20/2026 22:00 | 1 | 63 | 65 | 0 | 0 |
| 08/20/2026 23:00 | 1 | 58 | 60 | 0 | 0 |
| Average/Sum#: | 24 # | 56 | 58 | 6 | 0 |
| Minimum: | 1 | 45 | 46 | 0 | 0 |
| Maximum: | 1 | 77 | 79 | 22 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 08/21/2026 00:00 | 1 | 58 | 60 | 0 | 0 |
| 08/21/2026 01:00 | 1 | 55 | 56 | 0 | 0 |
| 08/21/2026 02:00 | 1 | 53 | 54 | 0 | 0 |
| 08/21/2026 03:00 | 1 | 49 | 50 | 0 | 0 |
| 08/21/2026 04:00 | 1 | 48 | 50 | 0 | 0 |
| 08/21/2026 05:00 | 1 | 51 | 52 | 0 | 0 |
| 08/21/2026 06:00 | 1 | 52 | 53 | 0 | 0 |
| 08/21/2026 07:00 | 1 | 51 | 52 | 0 | 0 |
| 08/21/2026 08:00 | 1 | 47 | 48 | 0 | 0 |
| 08/21/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 08/21/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 08/21/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 08/21/2026 12:00 | 1 | 47 | 48 | 0 | 0 |
| 08/21/2026 13:00 | 1 | 54 | 55 | 0 | 0 |
| 08/21/2026 14:00 | 1 | 61 | 62 | 0 | 0 |
| 08/21/2026 15:00 | 1 | 67 | 67 | 0 | 0 |
| 08/21/2026 16:00 | 1 | 67 | 68 | 0 | 0 |
| 08/21/2026 17:00 | 1 | 69 | 72 | 0 | 0 |
| 08/21/2026 18:00 | 1 | 68 | 73 | 0 | 0 |
| 08/21/2026 19:00 | 1 | 68 | 72 | 0 | 0 |
| 08/21/2026 20:00 | 1 | 66 | 69 | 0 | 0 |
| 08/21/2026 21:00 | 1 | 60 | 61 | 0 | 0 |
| 08/21/2026 22:00 | 1 | 53 | 54 | 0 | 0 |
| 08/21/2026 23:00 | 1 | 49 | 50 | 0 | 0 |
| Average/Sum#: | 24 # | 55 | 57 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 69 | 73 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 08/22/2026 00:00 | 1 | 51 | 52 | 0 | 0 |
| 08/22/2026 01:00 | 1 | 53 | 54 | 0 | 0 |
| 08/22/2026 02:00 | 1 | 50 | 51 | 0 | 0 |
| 08/22/2026 03:00 | 1 | 48 | 49 | 0 | 0 |
| 08/22/2026 04:00 | 1 | 48 | 49 | 0 | 0 |
| 08/22/2026 05:00 | 1 | 48 | 49 | 0 | 0 |
| 08/22/2026 06:00 | 1 | 48 | 49 | 0 | 0 |
| 08/22/2026 07:00 | 1 | 46 | 47 | 0 | 0 |
| 08/22/2026 08:00 | 1 | 46 | 47 | 0 | 0 |
| 08/22/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 08/22/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 08/22/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 08/22/2026 12:00 | 1 | 47 | 48 | 0 | 0 |
| 08/22/2026 13:00 | 1 | 54 | 55 | 0 | 0 |
| 08/22/2026 14:00 | 1 | 61 | 62 | 0 | 0 |
| 08/22/2026 15:00 | 1 | 66 | 67 | 0 | 0 |
| 08/22/2026 16:00 | 1 | 66 | 67 | 0 | 0 |
| 08/22/2026 17:00 | 1 | 66 | 67 | 0 | 0 |
| 08/22/2026 18:00 | 1 | 67 | 67 | 0 | 0 |
| 08/22/2026 19:00 | 1 | 67 | 67 | 0 | 0 |
| 08/22/2026 20:00 | 1 | 67 | 67 | 0 | 0 |
| 08/22/2026 21:00 | 1 | 61 | 61 | 0 | 0 |
| 08/22/2026 22:00 | 1 | 54 | 54 | 0 | 0 |
| 08/22/2026 23:00 | 1 | 47 | 48 | 0 | 0 |
| Average/Sum#: | 24 # | 54 | 55 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 67 | 67 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 08/23/2026 00:00 | 1 | 47 | 48 | 0 | 0 |
| 08/23/2026 01:00 | 1 | 47 | 48 | 0 | 0 |
| 08/23/2026 02:00 | 1 | 47 | 48 | 0 | 0 |
| 08/23/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 08/23/2026 04:00 | 1 | 46 | 47 | 0 | 0 |
| 08/23/2026 05:00 | 1 | 46 | 47 | 0 | 0 |
| 08/23/2026 06:00 | 1 | 46 | 47 | 0 | 0 |
| 08/23/2026 07:00 | 1 | 46 | 47 | 0 | 0 |
| 08/23/2026 08:00 | 1 | 46 | 47 | 0 | 0 |
| 08/23/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 08/23/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 08/23/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 08/23/2026 12:00 | 1 | 47 | 48 | 0 | 0 |
| 08/23/2026 13:00 | 1 | 54 | 55 | 0 | 0 |
| 08/23/2026 14:00 | 1 | 61 | 62 | 0 | 0 |
| 08/23/2026 15:00 | 1 | 67 | 68 | 0 | 0 |
| 08/23/2026 16:00 | 1 | 70 | 71 | 0 | 0 |
| 08/23/2026 17:00 | 1 | 73 | 75 | 0 | 0 |
| 08/23/2026 18:00 | 1 | 76 | 77 | 0 | 0 |
| 08/23/2026 19:00 | 1 | 76 | 77 | 0 | 0 |
| 08/23/2026 20:00 | 1 | 74 | 76 | 0 | 0 |
| 08/23/2026 21:00 | 1 | 68 | 70 | 0 | 0 |
| 08/23/2026 22:00 | 1 | 63 | 65 | 0 | 0 |
| 08/23/2026 23:00 | 1 | 58 | 60 | 0 | 0 |
| Average/Sum#: | 24 # | 56 | 57 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 76 | 77 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 08/24/2026 00:00 | 1 | 58 | 59 | 0 | 0 |
| 08/24/2026 01:00 | 1 | 58 | 59 | 0 | 0 |
| 08/24/2026 02:00 | 1 | 58 | 59 | 0 | 0 |
| 08/24/2026 03:00 | 1 | 58 | 59 | 0 | 0 |
| 08/24/2026 04:00 | 1 | 58 | 59 | 0 | 0 |
| 08/24/2026 05:00 | 1 | 54 | 55 | 0 | 0 |
| 08/24/2026 06:00 | 1 | 52 | 53 | 0 | 0 |
| 08/24/2026 07:00 | 1 | 49 | 50 | 0 | 0 |
| 08/24/2026 08:00 | 1 | 48 | 49 | 0 | 0 |
| 08/24/2026 09:00 | 1 | 47 | 48 | 0 | 0 |
| 08/24/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 08/24/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 08/24/2026 12:00 | 1 | 47 | 48 | 0 | 0 |
| 08/24/2026 13:00 | 1 | 54 | 55 | 0 | 0 |
| 08/24/2026 14:00 | 1 | 64 | 65 | 0 | 0 |
| 08/24/2026 15:00 | 1 | 73 | 74 | 0 | 0 |
| 08/24/2026 16:00 | 1 | 76 | 77 | 0 | 0 |
| 08/24/2026 17:00 | 1 | 77 | 78 | 0 | 0 |
| 08/24/2026 18:00 | 1 | 77 | 79 | 0 | 0 |
| 08/24/2026 19:00 | 1 | 78 | 80 | 0 | 0 |
| 08/24/2026 20:00 | 1 | 76 | 78 | 0 | 0 |
| 08/24/2026 21:00 | 1 | 70 | 71 | 0 | 0 |
| 08/24/2026 22:00 | 1 | 63 | 64 | 0 | 0 |
| 08/24/2026 23:00 | 1 | 58 | 59 | 0 | 0 |
| Average/Sum#: | 24 # | 60 | 61 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 78 | 80 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 08/25/2026 00:00 | 1 | 56 | 57 | 0 | 0 |
| 08/25/2026 01:00 | 1 | 52 | 53 | 0 | 0 |
| 08/25/2026 02:00 | 1 | 49 | 50 | 0 | 0 |
| 08/25/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 08/25/2026 04:00 | 1 | 48 | 49 | 0 | 0 |
| 08/25/2026 05:00 | 1 | 49 | 50 | 0 | 0 |
| 08/25/2026 06:00 | 1 | 50 | 51 | 0 | 0 |
| 08/25/2026 07:00 | 1 | 48 | 49 | 0 | 0 |
| 08/25/2026 08:00 | 1 | 47 | 48 | 0 | 0 |
| 08/25/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 08/25/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 08/25/2026 11:00 | 1 | 48 | 49 | 0 | 0 |
| 08/25/2026 12:00 | 1 | 51 | 52 | 0 | 0 |
| 08/25/2026 13:00 | 1 | 56 | 57 | 0 | 0 |
| 08/25/2026 14:00 | 1 | 61 | 63 | 9 | 0 |
| 08/25/2026 15:00 | 1 | 65 | 66 | 21 | 0 |
| 08/25/2026 16:00 | 1 | 69 | 71 | 20 | 0 |
| 08/25/2026 17:00 | 1 | 73 | 74 | 20 | 0 |
| 08/25/2026 18:00 | 1 | 77 | 78 | 20 | 0 |
| 08/25/2026 19:00 | 1 | 78 | 79 | 20 | 0 |
| 08/25/2026 20:00 | 1 | 75 | 76 | 0 | 0 |
| 08/25/2026 21:00 | 1 | 71 | 72 | 0 | 0 |
| 08/25/2026 22:00 | 1 | 63 | 64 | 0 | 0 |
| 08/25/2026 23:00 | 1 | 55 | 56 | 0 | 0 |
| Average/Sum#: | 24 # | 57 | 59 | 5 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 78 | 79 | 21 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 08/26/2026 00:00 | 1 | 48 | 49 | 0 | 0 |
| 08/26/2026 01:00 | 1 | 46 | 47 | 0 | 0 |
| 08/26/2026 02:00 | 1 | 48 | 49 | 0 | 0 |
| 08/26/2026 03:00 | 1 | 47 | 48 | 0 | 0 |
| 08/26/2026 04:00 | 1 | 50 | 51 | 0 | 0 |
| 08/26/2026 05:00 | 1 | 52 | 54 | 0 | 0 |
| 08/26/2026 06:00 | 1 | 54 | 56 | 0 | 0 |
| 08/26/2026 07:00 | 1 | 52 | 53 | 0 | 0 |
| 08/26/2026 08:00 | 1 | 48 | 49 | 0 | 0 |
| 08/26/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 08/26/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 08/26/2026 11:00 | 1 | 50 | 51 | 0 | 0 |
| 08/26/2026 12:00 | 1 | 54 | 55 | 0 | 0 |
| 08/26/2026 13:00 | 1 | 61 | 62 | 0 | 0 |
| 08/26/2026 14:00 | 1 | 64 | 65 | 0 | 0 |
| 08/26/2026 15:00 | 1 | 67 | 67 | 0 | 0 |
| 08/26/2026 16:00 | 1 | 67 | 67 | 0 | 0 |
| 08/26/2026 17:00 | 1 | 69 | 69 | 0 | 0 |
| 08/26/2026 18:00 | 1 | 69 | 71 | 0 | 0 |
| 08/26/2026 19:00 | 1 | 70 | 72 | 0 | 0 |
| 08/26/2026 20:00 | 1 | 70 | 71 | 0 | 0 |
| 08/26/2026 21:00 | 1 | 66 | 67 | 0 | 0 |
| 08/26/2026 22:00 | 1 | 59 | 60 | 0 | 0 |
| 08/26/2026 23:00 | 1 | 54 | 55 | 0 | 0 |
| Average/Sum#: | 24 # | 57 | 58 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 70 | 72 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 08/27/2026 00:00 | 1 | 51 | 52 | 0 | 0 |
| 08/27/2026 01:00 | 1 | 50 | 51 | 0 | 0 |
| 08/27/2026 02:00 | 1 | 47 | 48 | 0 | 0 |
| 08/27/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 08/27/2026 04:00 | 1 | 46 | 47 | 0 | 0 |
| 08/27/2026 05:00 | 1 | 48 | 49 | 0 | 0 |
| 08/27/2026 06:00 | 1 | 50 | 51 | 0 | 0 |
| 08/27/2026 07:00 | 1 | 54 | 55 | 0 | 0 |
| 08/27/2026 08:00 | 1 | 56 | 58 | 0 | 0 |
| 08/27/2026 09:00 | 1 | 58 | 60 | 0 | 0 |
| 08/27/2026 10:00 | 1 | 58 | 60 | 0 | 0 |
| 08/27/2026 11:00 | 1 | 58 | 60 | 0 | 0 |
| 08/27/2026 12:00 | 1 | 58 | 60 | 0 | 0 |
| 08/27/2026 13:00 | 1 | 63 | 65 | 7 | 0 |
| 08/27/2026 14:00 | 1 | 70 | 71 | 22 | 0 |
| 08/27/2026 15:00 | 1 | 73 | 74 | 15 | 18 |
| 08/27/2026 16:00 | 1 | 71 | 72 | 0 | 22 |
| 08/27/2026 17:00 | 1 | 68 | 69 | 0 | 22 |
| 08/27/2026 18:00 | 1 | 67 | 68 | 0 | 22 |
| 08/27/2026 19:00 | 1 | 66 | 67 | 0 | 22 |
| 08/27/2026 20:00 | 1 | 67 | 69 | 0 | 0 |
| 08/27/2026 21:00 | 1 | 64 | 66 | 0 | 0 |
| 08/27/2026 22:00 | 1 | 62 | 64 | 0 | 0 |
| 08/27/2026 23:00 | 1 | 63 | 64 | 0 | 0 |
| Average/Sum#: | 24 # | 59 | 60 | 2 | 4 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 73 | 74 | 22 | 22 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 08/28/2026 00:00 | 1 | 66 | 68 | 0 | 0 |
| 08/28/2026 01:00 | 1 | 69 | 70 | 0 | 0 |
| 08/28/2026 02:00 | 1 | 67 | 68 | 0 | 0 |
| 08/28/2026 03:00 | 1 | 67 | 68 | 0 | 0 |
| 08/28/2026 04:00 | 1 | 68 | 69 | 0 | 0 |
| 08/28/2026 05:00 | 1 | 72 | 73 | 0 | 0 |
| 08/28/2026 06:00 | 1 | 75 | 76 | 0 | 0 |
| 08/28/2026 07:00 | 1 | 77 | 79 | 0 | 0 |
| 08/28/2026 08:00 | 1 | 75 | 76 | 1 | 0 |
| 08/28/2026 09:00 | 1 | 71 | 73 | 20 | 0 |
| 08/28/2026 10:00 | 1 | 68 | 69 | 20 | 0 |
| 08/28/2026 11:00 | 1 | 67 | 68 | 19 | 0 |
| 08/28/2026 12:00 | 1 | 67 | 68 | 0 | 0 |
| 08/28/2026 13:00 | 1 | 67 | 68 | 0 | 0 |
| 08/28/2026 14:00 | 1 | 66 | 68 | 0 | 0 |
| 08/28/2026 15:00 | 1 | 66 | 68 | 0 | 0 |
| 08/28/2026 16:00 | 1 | 67 | 67 | 0 | 0 |
| 08/28/2026 17:00 | 1 | 67 | 67 | 0 | 0 |
| 08/28/2026 18:00 | 1 | 67 | 67 | 0 | 0 |
| 08/28/2026 19:00 | 1 | 67 | 67 | 0 | 0 |
| 08/28/2026 20:00 | 1 | 66 | 67 | 0 | 0 |
| 08/28/2026 21:00 | 1 | 66 | 67 | 0 | 0 |
| 08/28/2026 22:00 | 1 | 66 | 67 | 0 | 0 |
| 08/28/2026 23:00 | 1 | 66 | 67 | 0 | 0 |
| Average/Sum#: | 24 # | 68 | 69 | 3 | 0 |
| Minimum: | 1 | 66 | 67 | 0 | 0 |
| Maximum: | 1 | 77 | 79 | 20 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 08/29/2026 00:00 | 1 | 66 | 67 | 0 | 0 |
| 08/29/2026 01:00 | 1 | 66 | 67 | 0 | 0 |
| 08/29/2026 02:00 | 1 | 66 | 67 | 0 | 0 |
| 08/29/2026 03:00 | 1 | 66 | 67 | 0 | 0 |
| 08/29/2026 04:00 | 1 | 66 | 67 | 0 | 0 |
| 08/29/2026 05:00 | 1 | 66 | 67 | 0 | 0 |
| 08/29/2026 06:00 | 1 | 66 | 67 | 0 | 0 |
| 08/29/2026 07:00 | 1 | 66 | 67 | 0 | 0 |
| 08/29/2026 08:00 | 1 | 66 | 67 | 0 | 0 |
| 08/29/2026 09:00 | 1 | 66 | 67 | 0 | 0 |
| 08/29/2026 10:00 | 1 | 66 | 67 | 0 | 0 |
| 08/29/2026 11:00 | 1 | 66 | 67 | 0 | 0 |
| 08/29/2026 12:00 | 1 | 67 | 67 | 0 | 0 |
| 08/29/2026 13:00 | 1 | 67 | 67 | 0 | 0 |
| 08/29/2026 14:00 | 1 | 67 | 67 | 0 | 0 |
| 08/29/2026 15:00 | 1 | 67 | 67 | 0 | 0 |
| 08/29/2026 16:00 | 1 | 66 | 67 | 0 | 0 |
| 08/29/2026 17:00 | 1 | 67 | 68 | 0 | 0 |
| 08/29/2026 18:00 | 1 | 67 | 68 | 0 | 0 |
| 08/29/2026 19:00 | 1 | 67 | 68 | 0 | 0 |
| 08/29/2026 20:00 | 1 | 66 | 67 | 0 | 0 |
| 08/29/2026 21:00 | 1 | 66 | 67 | 0 | 0 |
| 08/29/2026 22:00 | 1 | 66 | 67 | 0 | 0 |
| 08/29/2026 23:00 | 1 | 66 | 67 | 0 | 0 |
| Average/Sum#: | 24 # | 66 | 67 | 0 | 0 |
| Minimum: | 1 | 66 | 67 | 0 | 0 |
| Maximum: | 1 | 67 | 68 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 08/30/2026 00:00 | 1 | 66 | 68 | 0 | 0 |
| 08/30/2026 01:00 | 1 | 66 | 67 | 0 | 0 |
| 08/30/2026 02:00 | 1 | 66 | 67 | 0 | 0 |
| 08/30/2026 03:00 | 1 | 66 | 67 | 0 | 0 |
| 08/30/2026 04:00 | 1 | 66 | 67 | 0 | 0 |
| 08/30/2026 05:00 | 1 | 66 | 67 | 0 | 0 |
| 08/30/2026 06:00 | 1 | 66 | 67 | 0 | 0 |
| 08/30/2026 07:00 | 1 | 66 | 67 | 0 | 0 |
| 08/30/2026 08:00 | 1 | 66 | 67 | 0 | 0 |
| 08/30/2026 09:00 | 1 | 66 | 67 | 0 | 0 |
| 08/30/2026 10:00 | 1 | 66 | 67 | 0 | 0 |
| 08/30/2026 11:00 | 1 | 66 | 67 | 0 | 0 |
| 08/30/2026 12:00 | 1 | 66 | 67 | 0 | 0 |
| 08/30/2026 13:00 | 1 | 67 | 67 | 0 | 0 |
| 08/30/2026 14:00 | 1 | 67 | 67 | 0 | 0 |
| 08/30/2026 15:00 | 1 | 67 | 67 | 0 | 0 |
| 08/30/2026 16:00 | 1 | 67 | 67 | 0 | 0 |
| 08/30/2026 17:00 | 1 | 68 | 68 | 0 | 0 |
| 08/30/2026 18:00 | 1 | 68 | 68 | 0 | 0 |
| 08/30/2026 19:00 | 1 | 68 | 68 | 0 | 0 |
| 08/30/2026 20:00 | 1 | 67 | 67 | 0 | 0 |
| 08/30/2026 21:00 | 1 | 66 | 67 | 0 | 0 |
| 08/30/2026 22:00 | 1 | 66 | 68 | 0 | 0 |
| 08/30/2026 23:00 | 1 | 66 | 68 | 0 | 0 |
| Average/Sum#: | 24 # | 66 | 67 | 0 | 0 |
| Minimum: | 1 | 66 | 67 | 0 | 0 |
| Maximum: | 1 | 68 | 68 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 08/31/2026 00:00 | 1 | 66 | 67 | 0 | 0 |
| 08/31/2026 01:00 | 1 | 66 | 67 | 0 | 0 |
| 08/31/2026 02:00 | 1 | 66 | 67 | 0 | 0 |
| 08/31/2026 03:00 | 1 | 66 | 67 | 0 | 0 |
| 08/31/2026 04:00 | 1 | 66 | 67 | 0 | 0 |
| 08/31/2026 05:00 | 1 | 64 | 65 | 0 | 0 |
| 08/31/2026 06:00 | 1 | 57 | 58 | 0 | 0 |
| 08/31/2026 07:00 | 1 | 50 | 51 | 0 | 0 |
| 08/31/2026 08:00 | 1 | 46 | 47 | 0 | 0 |
| 08/31/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 08/31/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 08/31/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 08/31/2026 12:00 | 1 | 47 | 48 | 0 | 0 |
| 08/31/2026 13:00 | 1 | 54 | 55 | 0 | 0 |
| 08/31/2026 14:00 | 1 | 61 | 62 | 0 | 0 |
| 08/31/2026 15:00 | 1 | 67 | 67 | 0 | 0 |
| 08/31/2026 16:00 | 1 | 67 | 67 | 0 | 0 |
| 08/31/2026 17:00 | 1 | 67 | 67 | 0 | 0 |
| 08/31/2026 18:00 | 1 | 66 | 67 | 0 | 0 |
| 08/31/2026 19:00 | 1 | 66 | 67 | 0 | 0 |
| 08/31/2026 20:00 | 1 | 66 | 67 | 0 | 0 |
| 08/31/2026 21:00 | 1 | 62 | 63 | 0 | 0 |
| 08/31/2026 22:00 | 1 | 55 | 56 | 0 | 0 |
| 08/31/2026 23:00 | 1 | 50 | 51 | 0 | 0 |
| Average/Sum#: | 24 # | 59 | 60 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 67 | 67 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 09/01/2026 00:00 | 1 | 49 | 50 | 0 | 0 |
| 09/01/2026 01:00 | 1 | 49 | 50 | 0 | 0 |
| 09/01/2026 02:00 | 1 | 47 | 48 | 0 | 0 |
| 09/01/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 09/01/2026 04:00 | 1 | 46 | 47 | 0 | 0 |
| 09/01/2026 05:00 | 1 | 46 | 47 | 0 | 0 |
| 09/01/2026 06:00 | 1 | 46 | 47 | 0 | 0 |
| 09/01/2026 07:00 | 1 | 46 | 47 | 0 | 0 |
| 09/01/2026 08:00 | 1 | 46 | 47 | 0 | 0 |
| 09/01/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 09/01/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 09/01/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 09/01/2026 12:00 | 1 | 46 | 47 | 0 | 0 |
| 09/01/2026 13:00 | 1 | 46 | 47 | 0 | 0 |
| 09/01/2026 14:00 | 1 | 46 | 47 | 0 | 0 |
| 09/01/2026 15:00 | 1 | 46 | 47 | 0 | 0 |
| 09/01/2026 16:00 | 1 | 46 | 47 | 0 | 0 |
| 09/01/2026 17:00 | 1 | 47 | 48 | 0 | 0 |
| 09/01/2026 18:00 | 1 | 47 | 48 | 0 | 0 |
| 09/01/2026 19:00 | 1 | 47 | 48 | 0 | 0 |
| 09/01/2026 20:00 | 1 | 46 | 47 | 0 | 0 |
| 09/01/2026 21:00 | 1 | 46 | 47 | 0 | 0 |
| 09/01/2026 22:00 | 1 | 46 | 47 | 0 | 0 |
| 09/01/2026 23:00 | 1 | 46 | 47 | 0 | 0 |
| Average/Sum#: | 24 # | 46 | 47 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 49 | 50 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 09/02/2026 00:00 | 1 | 46 | 47 | 0 | 0 |
| 09/02/2026 01:00 | 1 | 46 | 47 | 0 | 0 |
| 09/02/2026 02:00 | 1 | 46 | 47 | 0 | 0 |
| 09/02/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 09/02/2026 04:00 | 1 | 46 | 47 | 0 | 0 |
| 09/02/2026 05:00 | 1 | 46 | 47 | 0 | 0 |
| 09/02/2026 06:00 | 1 | 46 | 47 | 0 | 0 |
| 09/02/2026 07:00 | 1 | 46 | 47 | 0 | 0 |
| 09/02/2026 08:00 | 1 | 46 | 47 | 0 | 0 |
| 09/02/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 09/02/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 09/02/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 09/02/2026 12:00 | 1 | 46 | 47 | 0 | 0 |
| 09/02/2026 13:00 | 1 | 46 | 47 | 0 | 0 |
| 09/02/2026 14:00 | 1 | 46 | 47 | 0 | 0 |
| 09/02/2026 15:00 | 1 | 46 | 47 | 0 | 0 |
| 09/02/2026 16:00 | 1 | 46 | 47 | 0 | 0 |
| 09/02/2026 17:00 | 1 | 47 | 48 | 0 | 0 |
| 09/02/2026 18:00 | 1 | 47 | 48 | 0 | 0 |
| 09/02/2026 19:00 | 1 | 47 | 48 | 0 | 0 |
| 09/02/2026 20:00 | 1 | 46 | 47 | 0 | 0 |
| 09/02/2026 21:00 | 1 | 46 | 47 | 0 | 0 |
| 09/02/2026 22:00 | 1 | 46 | 47 | 0 | 0 |
| 09/02/2026 23:00 | 1 | 46 | 47 | 0 | 0 |
| Average/Sum#: | 24 # | 46 | 47 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 47 | 48 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 09/03/2026 00:00 | 1 | 46 | 47 | 0 | 0 |
| 09/03/2026 01:00 | 1 | 46 | 47 | 0 | 0 |
| 09/03/2026 02:00 | 1 | 46 | 47 | 0 | 0 |
| 09/03/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 09/03/2026 04:00 | 1 | 46 | 47 | 0 | 0 |
| 09/03/2026 05:00 | 1 | 46 | 47 | 0 | 0 |
| 09/03/2026 06:00 | 1 | 46 | 47 | 0 | 0 |
| 09/03/2026 07:00 | 1 | 47 | 48 | 0 | 0 |
| 09/03/2026 08:00 | 1 | 48 | 49 | 0 | 0 |
| 09/03/2026 09:00 | 1 | 51 | 52 | 0 | 0 |
| 09/03/2026 10:00 | 1 | 51 | 52 | 0 | 0 |
| 09/03/2026 11:00 | 1 | 50 | 51 | 0 | 0 |
| 09/03/2026 12:00 | 1 | 49 | 50 | 0 | 0 |
| 09/03/2026 13:00 | 1 | 51 | 52 | 0 | 0 |
| 09/03/2026 14:00 | 1 | 55 | 56 | 0 | 0 |
| 09/03/2026 15:00 | 1 | 58 | 59 | 0 | 0 |
| 09/03/2026 16:00 | 1 | 55 | 56 | 0 | 0 |
| 09/03/2026 17:00 | 1 | 53 | 54 | 0 | 0 |
| 09/03/2026 18:00 | 1 | 49 | 50 | 0 | 0 |
| 09/03/2026 19:00 | 1 | 50 | 51 | 0 | 0 |
| 09/03/2026 20:00 | 1 | 52 | 53 | 0 | 0 |
| 09/03/2026 21:00 | 1 | 56 | 57 | 0 | 0 |
| 09/03/2026 22:00 | 1 | 58 | 59 | 0 | 0 |
| 09/03/2026 23:00 | 1 | 58 | 59 | 0 | 0 |
| Average/Sum#: | 24 # | 51 | 52 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 58 | 59 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 09/04/2026 00:00 | 1 | 55 | 56 | 0 | 0 |
| 09/04/2026 01:00 | 1 | 51 | 52 | 0 | 0 |
| 09/04/2026 02:00 | 1 | 47 | 48 | 0 | 0 |
| 09/04/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 09/04/2026 04:00 | 1 | 47 | 48 | 0 | 0 |
| 09/04/2026 05:00 | 1 | 50 | 51 | 0 | 0 |
| 09/04/2026 06:00 | 1 | 51 | 52 | 0 | 0 |
| 09/04/2026 07:00 | 1 | 52 | 53 | 0 | 0 |
| 09/04/2026 08:00 | 1 | 48 | 49 | 0 | 0 |
| 09/04/2026 09:00 | 1 | 47 | 48 | 0 | 0 |
| 09/04/2026 10:00 | 1 | 48 | 49 | 0 | 0 |
| 09/04/2026 11:00 | 1 | 48 | 49 | 0 | 0 |
| 09/04/2026 12:00 | 1 | 48 | 49 | 0 | 0 |
| 09/04/2026 13:00 | 1 | 46 | 47 | 0 | 0 |
| 09/04/2026 14:00 | 1 | 46 | 47 | 0 | 0 |
| 09/04/2026 15:00 | 1 | 46 | 47 | 0 | 0 |
| 09/04/2026 16:00 | 1 | 47 | 48 | 0 | 0 |
| 09/04/2026 17:00 | 1 | 48 | 49 | 0 | 0 |
| 09/04/2026 18:00 | 1 | 52 | 53 | 0 | 0 |
| 09/04/2026 19:00 | 1 | 56 | 57 | 0 | 0 |
| 09/04/2026 20:00 | 1 | 58 | 59 | 0 | 0 |
| 09/04/2026 21:00 | 1 | 58 | 59 | 0 | 0 |
| 09/04/2026 22:00 | 1 | 58 | 59 | 0 | 0 |
| 09/04/2026 23:00 | 1 | 55 | 56 | 0 | 0 |
| Average/Sum#: | 24 # | 50 | 51 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 58 | 59 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 09/05/2026 00:00 | 1 | 51 | 52 | 0 | 0 |
| 09/05/2026 01:00 | 1 | 48 | 49 | 0 | 0 |
| 09/05/2026 02:00 | 1 | 49 | 50 | 0 | 0 |
| 09/05/2026 03:00 | 1 | 48 | 49 | 0 | 0 |
| 09/05/2026 04:00 | 1 | 50 | 51 | 0 | 0 |
| 09/05/2026 05:00 | 1 | 53 | 54 | 0 | 0 |
| 09/05/2026 06:00 | 1 | 53 | 54 | 0 | 0 |
| 09/05/2026 07:00 | 1 | 50 | 51 | 0 | 0 |
| 09/05/2026 08:00 | 1 | 46 | 47 | 0 | 0 |
| 09/05/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 09/05/2026 10:00 | 1 | 46 | 46 | 0 | 0 |
| 09/05/2026 11:00 | 1 | 46 | 46 | 0 | 0 |
| 09/05/2026 12:00 | 1 | 46 | 47 | 0 | 0 |
| 09/05/2026 13:00 | 1 | 46 | 47 | 0 | 0 |
| 09/05/2026 14:00 | 1 | 46 | 47 | 0 | 0 |
| 09/05/2026 15:00 | 1 | 46 | 47 | 0 | 0 |
| 09/05/2026 16:00 | 1 | 48 | 47 | 0 | 0 |
| 09/05/2026 17:00 | 1 | 50 | 48 | 0 | 0 |
| 09/05/2026 18:00 | 1 | 51 | 49 | 0 | 0 |
| 09/05/2026 19:00 | 1 | 50 | 50 | 0 | 0 |
| 09/05/2026 20:00 | 1 | 48 | 48 | 0 | 0 |
| 09/05/2026 21:00 | 1 | 48 | 48 | 0 | 0 |
| 09/05/2026 22:00 | 1 | 48 | 49 | 0 | 0 |
| 09/05/2026 23:00 | 1 | 48 | 49 | 0 | 0 |
| Average/Sum#: | 24 # | 48 | 49 | 0 | 0 |
| Minimum: | 1 | 46 | 46 | 0 | 0 |
| Maximum: | 1 | 53 | 54 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 09/06/2026 00:00 | 1 | 48 | 49 | 0 | 0 |
| 09/06/2026 01:00 | 1 | 47 | 48 | 0 | 0 |
| 09/06/2026 02:00 | 1 | 47 | 48 | 0 | 0 |
| 09/06/2026 03:00 | 1 | 47 | 48 | 0 | 0 |
| 09/06/2026 04:00 | 1 | 47 | 48 | 0 | 0 |
| 09/06/2026 05:00 | 1 | 46 | 47 | 0 | 0 |
| 09/06/2026 06:00 | 1 | 48 | 49 | 0 | 0 |
| 09/06/2026 07:00 | 1 | 48 | 49 | 0 | 0 |
| 09/06/2026 08:00 | 1 | 48 | 49 | 0 | 0 |
| 09/06/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 09/06/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 09/06/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 09/06/2026 12:00 | 1 | 46 | 47 | 0 | 0 |
| 09/06/2026 13:00 | 1 | 46 | 47 | 0 | 0 |
| 09/06/2026 14:00 | 1 | 46 | 47 | 0 | 0 |
| 09/06/2026 15:00 | 1 | 48 | 49 | 0 | 0 |
| 09/06/2026 16:00 | 1 | 49 | 50 | 0 | 0 |
| 09/06/2026 17:00 | 1 | 49 | 50 | 0 | 0 |
| 09/06/2026 18:00 | 1 | 47 | 48 | 0 | 0 |
| 09/06/2026 19:00 | 1 | 46 | 47 | 0 | 0 |
| 09/06/2026 20:00 | 1 | 46 | 47 | 0 | 0 |
| 09/06/2026 21:00 | 1 | 46 | 47 | 0 | 0 |
| 09/06/2026 22:00 | 1 | 46 | 47 | 0 | 0 |
| 09/06/2026 23:00 | 1 | 47 | 48 | 0 | 0 |
| Average/Sum#: | 24 # | 47 | 48 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 49 | 50 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 09/07/2026 00:00 | 1 | 47 | 48 | 0 | 0 |
| 09/07/2026 01:00 | 1 | 47 | 48 | 0 | 0 |
| 09/07/2026 02:00 | 1 | 46 | 47 | 0 | 0 |
| 09/07/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 09/07/2026 04:00 | 1 | 46 | 47 | 0 | 0 |
| 09/07/2026 05:00 | 1 | 46 | 47 | 0 | 0 |
| 09/07/2026 06:00 | 1 | 47 | 48 | 0 | 0 |
| 09/07/2026 07:00 | 1 | 47 | 48 | 0 | 0 |
| 09/07/2026 08:00 | 1 | 47 | 48 | 0 | 0 |
| 09/07/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 09/07/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 09/07/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 09/07/2026 12:00 | 1 | 46 | 47 | 0 | 0 |
| 09/07/2026 13:00 | 1 | 46 | 47 | 0 | 0 |
| 09/07/2026 14:00 | 1 | 46 | 47 | 0 | 0 |
| 09/07/2026 15:00 | 1 | 46 | 47 | 0 | 0 |
| 09/07/2026 16:00 | 1 | 48 | 49 | 0 | 0 |
| 09/07/2026 17:00 | 1 | 49 | 50 | 0 | 0 |
| 09/07/2026 18:00 | 1 | 50 | 51 | 0 | 0 |
| 09/07/2026 19:00 | 1 | 53 | 54 | 0 | 0 |
| 09/07/2026 20:00 | 1 | 55 | 57 | 0 | 0 |
| 09/07/2026 21:00 | 1 | 58 | 60 | 0 | 0 |
| 09/07/2026 22:00 | 1 | 58 | 60 | 0 | 0 |
| 09/07/2026 23:00 | 1 | 58 | 60 | 0 | 0 |
| Average/Sum#: | 24 # | 49 | 50 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 58 | 60 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 09/08/2026 00:00 | 1 | 58 | 60 | 0 | 0 |
| 09/08/2026 01:00 | 1 | 56 | 58 | 0 | 0 |
| 09/08/2026 02:00 | 1 | 52 | 53 | 0 | 0 |
| 09/08/2026 03:00 | 1 | 49 | 50 | 0 | 0 |
| 09/08/2026 04:00 | 1 | 50 | 51 | 0 | 0 |
| 09/08/2026 05:00 | 1 | 54 | 55 | 0 | 0 |
| 09/08/2026 06:00 | 1 | 55 | 56 | 0 | 0 |
| 09/08/2026 07:00 | 1 | 52 | 52 | 0 | 0 |
| 09/08/2026 08:00 | 1 | 48 | 48 | 0 | 0 |
| 09/08/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 09/08/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 09/08/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 09/08/2026 12:00 | 1 | 47 | 48 | 0 | 0 |
| 09/08/2026 13:00 | 1 | 51 | 52 | 0 | 0 |
| 09/08/2026 14:00 | 1 | 60 | 61 | 0 | 0 |
| 09/08/2026 15:00 | 1 | 70 | 71 | 0 | 0 |
| 09/08/2026 16:00 | 1 | 76 | 77 | 0 | 5 |
| 09/08/2026 17:00 | 1 | 78 | 79 | 0 | 22 |
| 09/08/2026 18:00 | 1 | 79 | 80 | 0 | 22 |
| 09/08/2026 19:00 | 1 | 79 | 80 | 0 | 22 |
| 09/08/2026 20:00 | 1 | 79 | 80 | 0 | 22 |
| 09/08/2026 21:00 | 1 | 78 | 79 | 0 | 22 |
| 09/08/2026 22:00 | 1 | 76 | 77 | 0 | 0 |
| 09/08/2026 23:00 | 1 | 69 | 70 | 0 | 0 |
| Average/Sum#: | 24 # | 61 | 62 | 0 | 5 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 79 | 80 | 0 | 22 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 09/09/2026 00:00 | 1 | 62 | 63 | 0 | 0 |
| 09/09/2026 01:00 | 1 | 54 | 55 | 0 | 0 |
| 09/09/2026 02:00 | 1 | 50 | 51 | 0 | 0 |
| 09/09/2026 03:00 | 1 | 47 | 48 | 0 | 0 |
| 09/09/2026 04:00 | 1 | 47 | 48 | 0 | 0 |
| 09/09/2026 05:00 | 1 | 53 | 54 | 0 | 0 |
| 09/09/2026 06:00 | 1 | 61 | 62 | 0 | 0 |
| 09/09/2026 07:00 | 1 | 69 | 70 | 0 | 0 |
| 09/09/2026 08:00 | 1 | 73 | 74 | 0 | 0 |
| 09/09/2026 09:00 | 1 | 76 | 77 | 0 | 0 |
| 09/09/2026 10:00 | 1 | 78 | 78 | 0 | 0 |
| 09/09/2026 11:00 | 1 | 77 | 78 | 10 | 1 |
| 09/09/2026 12:00 | 1 | 77 | 77 | 20 | 21 |
| 09/09/2026 13:00 | 1 | 77 | 78 | 17 | 21 |
| 09/09/2026 14:00 | 1 | 77 | 78 | 15 | 19 |
| 09/09/2026 15:00 | 1 | 78 | 79 | 15 | 18 |
| 09/09/2026 16:00 | 1 | 79 | 80 | 15 | 18 |
| 09/09/2026 17:00 | 1 | 78 | 79 | 15 | 17 |
| 09/09/2026 18:00 | 1 | 78 | 79 | 15 | 17 |
| 09/09/2026 19:00 | 1 | 77 | 78 | 15 | 17 |
| 09/09/2026 20:00 | 1 | 78 | 79 | 15 | 17 |
| 09/09/2026 21:00 | 1 | 78 | 79 | 0 | 0 |
| 09/09/2026 22:00 | 1 | 78 | 79 | 0 | 0 |
| 09/09/2026 23:00 | 1 | 72 | 73 | 0 | 0 |
| Average/Sum#: | 24 # | 70 | 71 | 6 | 7 |
| Minimum: | 1 | 47 | 48 | 0 | 0 |
| Maximum: | 1 | 79 | 80 | 20 | 21 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 09/10/2026 00:00 | 1 | 65 | 66 | 0 | 0 |
| 09/10/2026 01:00 | 1 | 58 | 60 | 0 | 0 |
| 09/10/2026 02:00 | 1 | 58 | 59 | 0 | 0 |
| 09/10/2026 03:00 | 1 | 54 | 55 | 0 | 0 |
| 09/10/2026 04:00 | 1 | 51 | 52 | 0 | 0 |
| 09/10/2026 05:00 | 1 | 51 | 52 | 0 | 0 |
| 09/10/2026 06:00 | 1 | 52 | 53 | 0 | 0 |
| 09/10/2026 07:00 | 1 | 52 | 53 | 0 | 0 |
| 09/10/2026 08:00 | 1 | 48 | 49 | 0 | 0 |
| 09/10/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 09/10/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 09/10/2026 11:00 | 1 | 47 | 48 | 0 | 0 |
| 09/10/2026 12:00 | 1 | 54 | 55 | 0 | 0 |
| 09/10/2026 13:00 | 1 | 61 | 62 | 0 | 0 |
| 09/10/2026 14:00 | 1 | 66 | 67 | 0 | 0 |
| 09/10/2026 15:00 | 1 | 66 | 68 | 5 | 7 |
| 09/10/2026 16:00 | 1 | 67 | 69 | 15 | 15 |
| 09/10/2026 17:00 | 1 | 69 | 71 | 15 | 15 |
| 09/10/2026 18:00 | 1 | 69 | 71 | 15 | 15 |
| 09/10/2026 19:00 | 1 | 68 | 70 | 15 | 15 |
| 09/10/2026 20:00 | 1 | 66 | 68 | 15 | 0 |
| 09/10/2026 21:00 | 1 | 66 | 67 | 15 | 0 |
| 09/10/2026 22:00 | 1 | 66 | 67 | 15 | 0 |
| 09/10/2026 23:00 | 1 | 60 | 61 | 1 | 0 |
| Average/Sum#: | 24 # | 59 | 60 | 5 | 3 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 69 | 71 | 15 | 15 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 09/11/2026 00:00 | 1 | 53 | 54 | 0 | 0 |
| 09/11/2026 01:00 | 1 | 46 | 47 | 0 | 0 |
| 09/11/2026 02:00 | 1 | 46 | 47 | 0 | 0 |
| 09/11/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 09/11/2026 04:00 | 1 | 46 | 47 | 0 | 0 |
| 09/11/2026 05:00 | 1 | 46 | 47 | 0 | 0 |
| 09/11/2026 06:00 | 1 | 46 | 47 | 0 | 0 |
| 09/11/2026 07:00 | 1 | 46 | 47 | 0 | 0 |
| 09/11/2026 08:00 | 1 | 46 | 47 | 0 | 0 |
| 09/11/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 09/11/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 09/11/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 09/11/2026 12:00 | 1 | 46 | 47 | 0 | 0 |
| 09/11/2026 13:00 | 1 | 46 | 47 | 0 | 0 |
| 09/11/2026 14:00 | 1 | 46 | 47 | 0 | 0 |
| 09/11/2026 15:00 | 1 | 49 | 50 | 0 | 0 |
| 09/11/2026 16:00 | 1 | 51 | 52 | 0 | 0 |
| 09/11/2026 17:00 | 1 | 53 | 54 | 0 | 0 |
| 09/11/2026 18:00 | 1 | 49 | 50 | 0 | 0 |
| 09/11/2026 19:00 | 1 | 48 | 49 | 0 | 0 |
| 09/11/2026 20:00 | 1 | 46 | 47 | 0 | 0 |
| 09/11/2026 21:00 | 1 | 46 | 47 | 0 | 0 |
| 09/11/2026 22:00 | 1 | 46 | 47 | 0 | 0 |
| 09/11/2026 23:00 | 1 | 46 | 47 | 0 | 0 |
| Average/Sum#: | 24 # | 47 | 48 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 53 | 54 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 09/12/2026 00:00 | 1 | 46 | 47 | 0 | 0 |
| 09/12/2026 01:00 | 1 | 46 | 47 | 0 | 0 |
| 09/12/2026 02:00 | 1 | 46 | 47 | 0 | 0 |
| 09/12/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 09/12/2026 04:00 | 1 | 46 | 47 | 0 | 0 |
| 09/12/2026 05:00 | 1 | 46 | 47 | 0 | 0 |
| 09/12/2026 06:00 | 1 | 46 | 47 | 0 | 0 |
| 09/12/2026 07:00 | 1 | 46 | 47 | 0 | 0 |
| 09/12/2026 08:00 | 1 | 46 | 47 | 0 | 0 |
| 09/12/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 09/12/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 09/12/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 09/12/2026 12:00 | 1 | 46 | 47 | 0 | 0 |
| 09/12/2026 13:00 | 1 | 46 | 47 | 0 | 0 |
| 09/12/2026 14:00 | 1 | 46 | 47 | 0 | 0 |
| 09/12/2026 15:00 | 1 | 46 | 47 | 0 | 0 |
| 09/12/2026 16:00 | 1 | 47 | 48 | 0 | 0 |
| 09/12/2026 17:00 | 1 | 47 | 48 | 0 | 0 |
| 09/12/2026 18:00 | 1 | 47 | 48 | 0 | 0 |
| 09/12/2026 19:00 | 1 | 46 | 47 | 0 | 0 |
| 09/12/2026 20:00 | 1 | 46 | 47 | 0 | 0 |
| 09/12/2026 21:00 | 1 | 46 | 47 | 0 | 0 |
| 09/12/2026 22:00 | 1 | 46 | 47 | 0 | 0 |
| 09/12/2026 23:00 | 1 | 46 | 47 | 0 | 0 |
| Average/Sum#: | 24 # | 46 | 47 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 47 | 48 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 09/13/2026 00:00 | 1 | 46 | 47 | 0 | 0 |
| 09/13/2026 01:00 | 1 | 46 | 47 | 0 | 0 |
| 09/13/2026 02:00 | 1 | 46 | 47 | 0 | 0 |
| 09/13/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 09/13/2026 04:00 | 1 | 46 | 47 | 0 | 0 |
| 09/13/2026 05:00 | 1 | 49 | 50 | 0 | 0 |
| 09/13/2026 06:00 | 1 | 50 | 51 | 0 | 0 |
| 09/13/2026 07:00 | 1 | 50 | 51 | 0 | 0 |
| 09/13/2026 08:00 | 1 | 47 | 48 | 0 | 0 |
| 09/13/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 09/13/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 09/13/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 09/13/2026 12:00 | 1 | 46 | 47 | 0 | 0 |
| 09/13/2026 13:00 | 1 | 46 | 47 | 0 | 0 |
| 09/13/2026 14:00 | 1 | 46 | 47 | 0 | 0 |
| 09/13/2026 15:00 | 1 | 46 | 47 | 0 | 0 |
| 09/13/2026 16:00 | 1 | 47 | 48 | 0 | 0 |
| 09/13/2026 17:00 | 1 | 50 | 51 | 0 | 0 |
| 09/13/2026 18:00 | 1 | 51 | 52 | 0 | 0 |
| 09/13/2026 19:00 | 1 | 49 | 50 | 0 | 0 |
| 09/13/2026 20:00 | 1 | 46 | 47 | 0 | 0 |
| 09/13/2026 21:00 | 1 | 46 | 47 | 0 | 0 |
| 09/13/2026 22:00 | 1 | 46 | 47 | 0 | 0 |
| 09/13/2026 23:00 | 1 | 46 | 47 | 0 | 0 |
| Average/Sum#: | 24 # | 47 | 48 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 51 | 52 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 09/14/2026 00:00 | 1 | 46 | 47 | 0 | 0 |
| 09/14/2026 01:00 | 1 | 46 | 47 | 0 | 0 |
| 09/14/2026 02:00 | 1 | 46 | 47 | 0 | 0 |
| 09/14/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 09/14/2026 04:00 | 1 | 46 | 47 | 0 | 0 |
| 09/14/2026 05:00 | 1 | 46 | 47 | 0 | 0 |
| 09/14/2026 06:00 | 1 | 47 | 48 | 0 | 0 |
| 09/14/2026 07:00 | 1 | 47 | 48 | 0 | 0 |
| 09/14/2026 08:00 | 1 | 47 | 48 | 0 | 0 |
| 09/14/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 09/14/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 09/14/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 09/14/2026 12:00 | 1 | 46 | 47 | 0 | 0 |
| 09/14/2026 13:00 | 1 | 46 | 47 | 0 | 0 |
| 09/14/2026 14:00 | 1 | 46 | 47 | 0 | 0 |
| 09/14/2026 15:00 | 1 | 46 | 47 | 0 | 0 |
| 09/14/2026 16:00 | 1 | 47 | 48 | 0 | 0 |
| 09/14/2026 17:00 | 1 | 49 | 50 | 0 | 0 |
| 09/14/2026 18:00 | 1 | 49 | 50 | 0 | 0 |
| 09/14/2026 19:00 | 1 | 48 | 49 | 0 | 0 |
| 09/14/2026 20:00 | 1 | 46 | 48 | 0 | 0 |
| 09/14/2026 21:00 | 1 | 46 | 48 | 0 | 0 |
| 09/14/2026 22:00 | 1 | 46 | 47 | 0 | 0 |
| 09/14/2026 23:00 | 1 | 49 | 50 | 0 | 0 |
| Average/Sum#: | 24 # | 47 | 48 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 49 | 50 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 09/15/2026 00:00 | 1 | 50 | 51 | 0 | 0 |
| 09/15/2026 01:00 | 1 | 51 | 52 | 0 | 0 |
| 09/15/2026 02:00 | 1 | 48 | 49 | 0 | 0 |
| 09/15/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 09/15/2026 04:00 | 1 | 47 | 48 | 0 | 0 |
| 09/15/2026 05:00 | 1 | 51 | 52 | 0 | 0 |
| 09/15/2026 06:00 | 1 | 55 | 56 | 0 | 0 |
| 09/15/2026 07:00 | 1 | 58 | 59 | 0 | 0 |
| 09/15/2026 08:00 | 1 | 58 | 59 | 0 | 0 |
| 09/15/2026 09:00 | 1 | 58 | 59 | 0 | 0 |
| 09/15/2026 10:00 | 1 | 57 | 58 | 0 | 0 |
| 09/15/2026 11:00 | 1 | 57 | 58 | 0 | 0 |
| 09/15/2026 12:00 | 1 | 56 | 58 | 0 | 0 |
| 09/15/2026 13:00 | 1 | 57 | 58 | 0 | 0 |
| 09/15/2026 14:00 | 1 | 56 | 58 | 0 | 0 |
| 09/15/2026 15:00 | 1 | 56 | 58 | 0 | 0 |
| 09/15/2026 16:00 | 1 | 54 | 55 | 0 | 0 |
| 09/15/2026 17:00 | 1 | 51 | 51 | 0 | 0 |
| 09/15/2026 18:00 | 1 | 47 | 48 | 0 | 0 |
| 09/15/2026 19:00 | 1 | 46 | 47 | 0 | 0 |
| 09/15/2026 20:00 | 1 | 46 | 47 | 0 | 0 |
| 09/15/2026 21:00 | 1 | 46 | 47 | 0 | 0 |
| 09/15/2026 22:00 | 1 | 46 | 47 | 0 | 0 |
| 09/15/2026 23:00 | 1 | 46 | 47 | 0 | 0 |
| Average/Sum#: | 24 # | 52 | 53 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 58 | 59 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 09/16/2026 00:00 | 1 | 46 | 47 | 0 | 0 |
| 09/16/2026 01:00 | 1 | 46 | 47 | 0 | 0 |
| 09/16/2026 02:00 | 1 | 46 | 47 | 0 | 0 |
| 09/16/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 09/16/2026 04:00 | 1 | 46 | 47 | 0 | 0 |
| 09/16/2026 05:00 | 1 | 46 | 47 | 0 | 0 |
| 09/16/2026 06:00 | 1 | 46 | 47 | 0 | 0 |
| 09/16/2026 07:00 | 1 | 48 | 43 | 0 | 0 |
| 09/16/2026 08:00 | 1 | 51 | 28 | 0 | 0 |
| 09/16/2026 09:00 | 1 | 54 | 12 | 0 | 0 |
| 09/16/2026 10:00 | 1 | 52 | 0 | 0 | 0 |
| 09/16/2026 11:00 | 1 | 48 | 0 | 0 | 0 |
| 09/16/2026 12:00 | 1 | 45 | 0 | 0 | 0 |
| 09/16/2026 13:00 | 1 | 48 | 0 | 0 | 0 |
| 09/16/2026 14:00 | 1 | 52 | 0 | 0 | 0 |
| 09/16/2026 15:00 | 1 | 53 | 12 | 0 | 0 |
| 09/16/2026 16:00 | 1 | 50 | 27 | 0 | 0 |
| 09/16/2026 17:00 | 1 | 47 | 43 | 0 | 0 |
| 09/16/2026 18:00 | 1 | 46 | 47 | 0 | 0 |
| 09/16/2026 19:00 | 1 | 46 | 47 | 0 | 0 |
| 09/16/2026 20:00 | 1 | 46 | 47 | 0 | 0 |
| 09/16/2026 21:00 | 1 | 46 | 47 | 0 | 0 |
| 09/16/2026 22:00 | 1 | 46 | 47 | 0 | 0 |
| 09/16/2026 23:00 | 1 | 46 | 47 | 0 | 0 |
| Average/Sum#: | 24 # | 48 | 32 | 0 | 0 |
| Minimum: | 1 | 45 | 0 | 0 | 0 |
| Maximum: | 1 | 54 | 47 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 09/17/2026 00:00 | 1 | 46 | 47 | 0 | 0 |
| 09/17/2026 01:00 | 1 | 46 | 47 | 0 | 0 |
| 09/17/2026 02:00 | 1 | 46 | 47 | 0 | 0 |
| 09/17/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 09/17/2026 04:00 | 1 | 46 | 47 | 0 | 0 |
| 09/17/2026 05:00 | 1 | 48 | 49 | 0 | 0 |
| 09/17/2026 06:00 | 1 | 50 | 51 | 0 | 0 |
| 09/17/2026 07:00 | 1 | 50 | 51 | 0 | 0 |
| 09/17/2026 08:00 | 1 | 48 | 49 | 0 | 0 |
| 09/17/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 09/17/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 09/17/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 09/17/2026 12:00 | 1 | 46 | 47 | 0 | 0 |
| 09/17/2026 13:00 | 1 | 46 | 47 | 0 | 0 |
| 09/17/2026 14:00 | 1 | 46 | 47 | 0 | 0 |
| 09/17/2026 15:00 | 1 | 46 | 47 | 0 | 0 |
| 09/17/2026 16:00 | 1 | 47 | 48 | 0 | 0 |
| 09/17/2026 17:00 | 1 | 47 | 48 | 0 | 0 |
| 09/17/2026 18:00 | 1 | 47 | 48 | 0 | 0 |
| 09/17/2026 19:00 | 1 | 46 | 47 | 0 | 0 |
| 09/17/2026 20:00 | 1 | 46 | 47 | 0 | 0 |
| 09/17/2026 21:00 | 1 | 46 | 47 | 0 | 0 |
| 09/17/2026 22:00 | 1 | 46 | 47 | 0 | 0 |
| 09/17/2026 23:00 | 1 | 46 | 47 | 0 | 0 |
| Average/Sum#: | 24 # | 47 | 48 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 50 | 51 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 09/18/2026 00:00 | 1 | 46 | 47 | 0 | 0 |
| 09/18/2026 01:00 | 1 | 46 | 47 | 0 | 0 |
| 09/18/2026 02:00 | 1 | 46 | 47 | 0 | 0 |
| 09/18/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 09/18/2026 04:00 | 1 | 46 | 47 | 0 | 0 |
| 09/18/2026 05:00 | 1 | 46 | 47 | 0 | 0 |
| 09/18/2026 06:00 | 1 | 48 | 49 | 0 | 0 |
| 09/18/2026 07:00 | 1 | 48 | 49 | 0 | 0 |
| 09/18/2026 08:00 | 1 | 48 | 49 | 0 | 0 |
| 09/18/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 09/18/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 09/18/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 09/18/2026 12:00 | 1 | 46 | 47 | 0 | 0 |
| 09/18/2026 13:00 | 1 | 46 | 47 | 0 | 0 |
| 09/18/2026 14:00 | 1 | 46 | 47 | 0 | 0 |
| 09/18/2026 15:00 | 1 | 46 | 47 | 0 | 0 |
| 09/18/2026 16:00 | 1 | 49 | 49 | 0 | 0 |
| 09/18/2026 17:00 | 1 | 53 | 53 | 0 | 0 |
| 09/18/2026 18:00 | 1 | 53 | 53 | 0 | 0 |
| 09/18/2026 19:00 | 1 | 50 | 51 | 0 | 0 |
| 09/18/2026 20:00 | 1 | 46 | 47 | 0 | 0 |
| 09/18/2026 21:00 | 1 | 46 | 47 | 0 | 0 |
| 09/18/2026 22:00 | 1 | 46 | 47 | 0 | 0 |
| 09/18/2026 23:00 | 1 | 46 | 47 | 0 | 0 |
| Average/Sum#: | 24 # | 47 | 48 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 53 | 53 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 09/19/2026 00:00 | 1 | 46 | 47 | 0 | 0 |
| 09/19/2026 01:00 | 1 | 46 | 47 | 0 | 0 |
| 09/19/2026 02:00 | 1 | 46 | 47 | 0 | 0 |
| 09/19/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 09/19/2026 04:00 | 1 | 46 | 47 | 0 | 0 |
| 09/19/2026 05:00 | 1 | 46 | 47 | 0 | 0 |
| 09/19/2026 06:00 | 1 | 46 | 47 | 0 | 0 |
| 09/19/2026 07:00 | 1 | 46 | 47 | 0 | 0 |
| 09/19/2026 08:00 | 1 | 46 | 47 | 0 | 0 |
| 09/19/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 09/19/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 09/19/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 09/19/2026 12:00 | 1 | 46 | 47 | 0 | 0 |
| 09/19/2026 13:00 | 1 | 46 | 47 | 0 | 0 |
| 09/19/2026 14:00 | 1 | 46 | 47 | 0 | 0 |
| 09/19/2026 15:00 | 1 | 46 | 47 | 0 | 0 |
| 09/19/2026 16:00 | 1 | 47 | 48 | 0 | 0 |
| 09/19/2026 17:00 | 1 | 47 | 48 | 0 | 0 |
| 09/19/2026 18:00 | 1 | 47 | 48 | 0 | 0 |
| 09/19/2026 19:00 | 1 | 46 | 47 | 0 | 0 |
| 09/19/2026 20:00 | 1 | 46 | 47 | 0 | 0 |
| 09/19/2026 21:00 | 1 | 46 | 47 | 0 | 0 |
| 09/19/2026 22:00 | 1 | 47 | 48 | 0 | 0 |
| 09/19/2026 23:00 | 1 | 48 | 49 | 0 | 0 |
| Average/Sum#: | 24 # | 46 | 47 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 48 | 49 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 09/20/2026 00:00 | 1 | 48 | 49 | 0 | 0 |
| 09/20/2026 01:00 | 1 | 47 | 48 | 0 | 0 |
| 09/20/2026 02:00 | 1 | 47 | 48 | 0 | 0 |
| 09/20/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 09/20/2026 04:00 | 1 | 46 | 47 | 0 | 0 |
| 09/20/2026 05:00 | 1 | 46 | 47 | 0 | 0 |
| 09/20/2026 06:00 | 1 | 46 | 47 | 0 | 0 |
| 09/20/2026 07:00 | 1 | 46 | 47 | 0 | 0 |
| 09/20/2026 08:00 | 1 | 46 | 47 | 0 | 0 |
| 09/20/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 09/20/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 09/20/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 09/20/2026 12:00 | 1 | 46 | 47 | 0 | 0 |
| 09/20/2026 13:00 | 1 | 48 | 49 | 0 | 0 |
| 09/20/2026 14:00 | 1 | 52 | 53 | 0 | 0 |
| 09/20/2026 15:00 | 1 | 56 | 56 | 0 | 0 |
| 09/20/2026 16:00 | 1 | 56 | 57 | 0 | 0 |
| 09/20/2026 17:00 | 1 | 52 | 53 | 0 | 0 |
| 09/20/2026 18:00 | 1 | 49 | 50 | 0 | 0 |
| 09/20/2026 19:00 | 1 | 46 | 47 | 0 | 0 |
| 09/20/2026 20:00 | 1 | 46 | 47 | 0 | 0 |
| 09/20/2026 21:00 | 1 | 46 | 47 | 0 | 0 |
| 09/20/2026 22:00 | 1 | 46 | 47 | 0 | 0 |
| 09/20/2026 23:00 | 1 | 46 | 47 | 0 | 0 |
| Average/Sum#: | 24 # | 48 | 49 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 56 | 57 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 09/21/2026 00:00 | 1 | 46 | 47 | 0 | 0 |
| 09/21/2026 01:00 | 1 | 46 | 47 | 0 | 0 |
| 09/21/2026 02:00 | 1 | 46 | 47 | 0 | 0 |
| 09/21/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 09/21/2026 04:00 | 1 | 47 | 48 | 0 | 0 |
| 09/21/2026 05:00 | 1 | 50 | 51 | 0 | 0 |
| 09/21/2026 06:00 | 1 | 53 | 54 | 0 | 0 |
| 09/21/2026 07:00 | 1 | 55 | 56 | 0 | 0 |
| 09/21/2026 08:00 | 1 | 53 | 54 | 0 | 0 |
| 09/21/2026 09:00 | 1 | 50 | 51 | 0 | 0 |
| 09/21/2026 10:00 | 1 | 47 | 48 | 0 | 0 |
| 09/21/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 09/21/2026 12:00 | 1 | 46 | 47 | 0 | 0 |
| 09/21/2026 13:00 | 1 | 46 | 47 | 0 | 0 |
| 09/21/2026 14:00 | 1 | 47 | 48 | 0 | 0 |
| 09/21/2026 15:00 | 1 | 47 | 48 | 0 | 0 |
| 09/21/2026 16:00 | 1 | 47 | 48 | 0 | 0 |
| 09/21/2026 17:00 | 1 | 47 | 48 | 0 | 0 |
| 09/21/2026 18:00 | 1 | 47 | 48 | 0 | 0 |
| 09/21/2026 19:00 | 1 | 46 | 47 | 0 | 0 |
| 09/21/2026 20:00 | 1 | 46 | 47 | 0 | 0 |
| 09/21/2026 21:00 | 1 | 46 | 47 | 0 | 0 |
| 09/21/2026 22:00 | 1 | 46 | 47 | 0 | 0 |
| 09/21/2026 23:00 | 1 | 46 | 47 | 0 | 0 |
| Average/Sum#: | 24 # | 48 | 49 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 55 | 56 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 09/22/2026 00:00 | 1 | 46 | 47 | 0 | 0 |
| 09/22/2026 01:00 | 1 | 46 | 47 | 0 | 0 |
| 09/22/2026 02:00 | 1 | 46 | 47 | 0 | 0 |
| 09/22/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 09/22/2026 04:00 | 1 | 46 | 47 | 0 | 0 |
| 09/22/2026 05:00 | 1 | 46 | 47 | 0 | 0 |
| 09/22/2026 06:00 | 1 | 47 | 48 | 0 | 0 |
| 09/22/2026 07:00 | 1 | 47 | 48 | 0 | 0 |
| 09/22/2026 08:00 | 1 | 47 | 48 | 0 | 0 |
| 09/22/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 09/22/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 09/22/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 09/22/2026 12:00 | 1 | 46 | 47 | 0 | 0 |
| 09/22/2026 13:00 | 1 | 46 | 47 | 0 | 0 |
| 09/22/2026 14:00 | 1 | 46 | 47 | 0 | 0 |
| 09/22/2026 15:00 | 1 | 46 | 47 | 0 | 0 |
| 09/22/2026 16:00 | 1 | 46 | 47 | 0 | 0 |
| 09/22/2026 17:00 | 1 | 46 | 47 | 0 | 0 |
| 09/22/2026 18:00 | 1 | 46 | 47 | 0 | 0 |
| 09/22/2026 19:00 | 1 | 46 | 47 | 0 | 0 |
| 09/22/2026 20:00 | 1 | 46 | 47 | 0 | 0 |
| 09/22/2026 21:00 | 1 | 49 | 50 | 0 | 0 |
| 09/22/2026 22:00 | 1 | 56 | 57 | 0 | 0 |
| 09/22/2026 23:00 | 1 | 57 | 58 | 0 | 0 |
| Average/Sum#: | 24 # | 47 | 48 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 57 | 58 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 09/23/2026 00:00 | 1 | 54 | 55 | 0 | 0 |
| 09/23/2026 01:00 | 1 | 47 | 48 | 0 | 0 |
| 09/23/2026 02:00 | 1 | 46 | 47 | 0 | 0 |
| 09/23/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 09/23/2026 04:00 | 1 | 46 | 47 | 0 | 0 |
| 09/23/2026 05:00 | 1 | 48 | 49 | 0 | 0 |
| 09/23/2026 06:00 | 1 | 50 | 51 | 0 | 0 |
| 09/23/2026 07:00 | 1 | 49 | 50 | 0 | 0 |
| 09/23/2026 08:00 | 1 | 47 | 48 | 0 | 0 |
| 09/23/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 09/23/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 09/23/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 09/23/2026 12:00 | 1 | 46 | 47 | 0 | 0 |
| 09/23/2026 13:00 | 1 | 46 | 47 | 0 | 0 |
| 09/23/2026 14:00 | 1 | 46 | 47 | 0 | 0 |
| 09/23/2026 15:00 | 1 | 47 | 48 | 0 | 0 |
| 09/23/2026 16:00 | 1 | 49 | 50 | 0 | 0 |
| 09/23/2026 17:00 | 1 | 49 | 50 | 0 | 0 |
| 09/23/2026 18:00 | 1 | 48 | 49 | 0 | 0 |
| 09/23/2026 19:00 | 1 | 50 | 51 | 0 | 0 |
| 09/23/2026 20:00 | 1 | 52 | 53 | 0 | 0 |
| 09/23/2026 21:00 | 1 | 52 | 53 | 0 | 0 |
| 09/23/2026 22:00 | 1 | 48 | 49 | 0 | 0 |
| 09/23/2026 23:00 | 1 | 46 | 47 | 0 | 0 |
| Average/Sum#: | 24 # | 48 | 49 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 54 | 55 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 09/24/2026 00:00 | 1 | 46 | 47 | 0 | 0 |
| 09/24/2026 01:00 | 1 | 46 | 47 | 0 | 0 |
| 09/24/2026 02:00 | 1 | 46 | 47 | 0 | 0 |
| 09/24/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 09/24/2026 04:00 | 1 | 46 | 47 | 0 | 0 |
| 09/24/2026 05:00 | 1 | 48 | 50 | 0 | 0 |
| 09/24/2026 06:00 | 1 | 50 | 52 | 0 | 0 |
| 09/24/2026 07:00 | 1 | 50 | 51 | 0 | 0 |
| 09/24/2026 08:00 | 1 | 48 | 49 | 0 | 0 |
| 09/24/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 09/24/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 09/24/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 09/24/2026 12:00 | 1 | 46 | 47 | 0 | 0 |
| 09/24/2026 13:00 | 1 | 47 | 48 | 0 | 0 |
| 09/24/2026 14:00 | 1 | 49 | 50 | 0 | 0 |
| 09/24/2026 15:00 | 1 | 52 | 53 | 0 | 0 |
| 09/24/2026 16:00 | 1 | 52 | 53 | 0 | 0 |
| 09/24/2026 17:00 | 1 | 55 | 56 | 0 | 0 |
| 09/24/2026 18:00 | 1 | 61 | 62 | 0 | 0 |
| 09/24/2026 19:00 | 1 | 60 | 61 | 0 | 0 |
| 09/24/2026 20:00 | 1 | 55 | 56 | 0 | 0 |
| 09/24/2026 21:00 | 1 | 47 | 48 | 0 | 0 |
| 09/24/2026 22:00 | 1 | 46 | 47 | 0 | 0 |
| 09/24/2026 23:00 | 1 | 46 | 47 | 0 | 0 |
| Average/Sum#: | 24 # | 49 | 50 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 61 | 62 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 09/25/2026 00:00 | 1 | 46 | 47 | 0 | 0 |
| 09/25/2026 01:00 | 1 | 46 | 47 | 0 | 0 |
| 09/25/2026 02:00 | 1 | 46 | 47 | 0 | 0 |
| 09/25/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 09/25/2026 04:00 | 1 | 46 | 47 | 0 | 0 |
| 09/25/2026 05:00 | 1 | 46 | 47 | 0 | 0 |
| 09/25/2026 06:00 | 1 | 47 | 48 | 0 | 0 |
| 09/25/2026 07:00 | 1 | 48 | 49 | 0 | 0 |
| 09/25/2026 08:00 | 1 | 48 | 49 | 0 | 0 |
| 09/25/2026 09:00 | 1 | 47 | 48 | 0 | 0 |
| 09/25/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 09/25/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 09/25/2026 12:00 | 1 | 46 | 47 | 0 | 0 |
| 09/25/2026 13:00 | 1 | 46 | 47 | 0 | 0 |
| 09/25/2026 14:00 | 1 | 46 | 47 | 0 | 0 |
| 09/25/2026 15:00 | 1 | 46 | 47 | 0 | 0 |
| 09/25/2026 16:00 | 1 | 46 | 47 | 0 | 0 |
| 09/25/2026 17:00 | 1 | 46 | 47 | 0 | 0 |
| 09/25/2026 18:00 | 1 | 46 | 47 | 0 | 0 |
| 09/25/2026 19:00 | 1 | 46 | 47 | 0 | 0 |
| 09/25/2026 20:00 | 1 | 46 | 47 | 0 | 0 |
| 09/25/2026 21:00 | 1 | 46 | 47 | 0 | 0 |
| 09/25/2026 22:00 | 1 | 46 | 47 | 0 | 0 |
| 09/25/2026 23:00 | 1 | 46 | 47 | 0 | 0 |
| Average/Sum#: | 24 # | 46 | 47 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 48 | 49 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 09/26/2026 00:00 | 1 | 46 | 47 | 0 | 0 |
| 09/26/2026 01:00 | 1 | 46 | 47 | 0 | 0 |
| 09/26/2026 02:00 | 1 | 46 | 47 | 0 | 0 |
| 09/26/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 09/26/2026 04:00 | 1 | 46 | 47 | 0 | 0 |
| 09/26/2026 05:00 | 1 | 46 | 47 | 0 | 0 |
| 09/26/2026 06:00 | 1 | 46 | 47 | 0 | 0 |
| 09/26/2026 07:00 | 1 | 46 | 47 | 0 | 0 |
| 09/26/2026 08:00 | 1 | 46 | 47 | 0 | 0 |
| 09/26/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 09/26/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 09/26/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 09/26/2026 12:00 | 1 | 46 | 47 | 0 | 0 |
| 09/26/2026 13:00 | 1 | 46 | 47 | 0 | 0 |
| 09/26/2026 14:00 | 1 | 46 | 47 | 0 | 0 |
| 09/26/2026 15:00 | 1 | 46 | 47 | 0 | 0 |
| 09/26/2026 16:00 | 1 | 48 | 49 | 0 | 0 |
| 09/26/2026 17:00 | 1 | 52 | 53 | 0 | 0 |
| 09/26/2026 18:00 | 1 | 54 | 55 | 0 | 0 |
| 09/26/2026 19:00 | 1 | 56 | 57 | 0 | 0 |
| 09/26/2026 20:00 | 1 | 56 | 58 | 0 | 0 |
| 09/26/2026 21:00 | 1 | 58 | 60 | 0 | 0 |
| 09/26/2026 22:00 | 1 | 59 | 61 | 0 | 0 |
| 09/26/2026 23:00 | 1 | 65 | 67 | 0 | 0 |
| Average/Sum#: | 24 # | 49 | 51 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 65 | 67 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 09/27/2026 00:00 | 1 | 68 | 69 | 0 | 0 |
| 09/27/2026 01:00 | 1 | 68 | 69 | 0 | 0 |
| 09/27/2026 02:00 | 1 | 60 | 61 | 0 | 0 |
| 09/27/2026 03:00 | 1 | 55 | 56 | 0 | 0 |
| 09/27/2026 04:00 | 1 | 50 | 51 | 0 | 0 |
| 09/27/2026 05:00 | 1 | 49 | 50 | 0 | 0 |
| 09/27/2026 06:00 | 1 | 52 | 53 | 0 | 0 |
| 09/27/2026 07:00 | 1 | 55 | 56 | 0 | 0 |
| 09/27/2026 08:00 | 1 | 54 | 55 | 0 | 0 |
| 09/27/2026 09:00 | 1 | 51 | 52 | 0 | 0 |
| 09/27/2026 10:00 | 1 | 47 | 48 | 0 | 0 |
| 09/27/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 09/27/2026 12:00 | 1 | 46 | 47 | 0 | 0 |
| 09/27/2026 13:00 | 1 | 46 | 47 | 0 | 0 |
| 09/27/2026 14:00 | 1 | 46 | 47 | 0 | 0 |
| 09/27/2026 15:00 | 1 | 47 | 48 | 0 | 0 |
| 09/27/2026 16:00 | 1 | 50 | 51 | 0 | 0 |
| 09/27/2026 17:00 | 1 | 60 | 61 | 0 | 0 |
| 09/27/2026 18:00 | 1 | 68 | 69 | 0 | 0 |
| 09/27/2026 19:00 | 1 | 75 | 76 | 0 | 0 |
| 09/27/2026 20:00 | 1 | 75 | 76 | 0 | 0 |
| 09/27/2026 21:00 | 1 | 72 | 74 | 0 | 0 |
| 09/27/2026 22:00 | 1 | 69 | 70 | 0 | 0 |
| 09/27/2026 23:00 | 1 | 62 | 63 | 0 | 0 |
| Average/Sum#: | 24 # | 57 | 58 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 75 | 76 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 09/28/2026 00:00 | 1 | 57 | 58 | 0 | 0 |
| 09/28/2026 01:00 | 1 | 50 | 52 | 0 | 0 |
| 09/28/2026 02:00 | 1 | 49 | 51 | 0 | 0 |
| 09/28/2026 03:00 | 1 | 50 | 51 | 0 | 0 |
| 09/28/2026 04:00 | 1 | 57 | 58 | 0 | 0 |
| 09/28/2026 05:00 | 1 | 63 | 64 | 0 | 0 |
| 09/28/2026 06:00 | 1 | 68 | 68 | 0 | 0 |
| 09/28/2026 07:00 | 1 | 62 | 63 | 0 | 0 |
| 09/28/2026 08:00 | 1 | 55 | 56 | 0 | 0 |
| 09/28/2026 09:00 | 1 | 48 | 49 | 0 | 0 |
| 09/28/2026 10:00 | 1 | 46 | 47 | 0 | 0 |
| 09/28/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 09/28/2026 12:00 | 1 | 46 | 47 | 0 | 0 |
| 09/28/2026 13:00 | 1 | 46 | 47 | 0 | 0 |
| 09/28/2026 14:00 | 1 | 46 | 47 | 0 | 0 |
| 09/28/2026 15:00 | 1 | 46 | 47 | 0 | 0 |
| 09/28/2026 16:00 | 1 | 46 | 47 | 0 | 0 |
| 09/28/2026 17:00 | 1 | 46 | 47 | 0 | 0 |
| 09/28/2026 18:00 | 1 | 46 | 47 | 0 | 0 |
| 09/28/2026 19:00 | 1 | 46 | 47 | 0 | 0 |
| 09/28/2026 20:00 | 1 | 46 | 47 | 0 | 0 |
| 09/28/2026 21:00 | 1 | 46 | 47 | 0 | 0 |
| 09/28/2026 22:00 | 1 | 46 | 47 | 0 | 0 |
| 09/28/2026 23:00 | 1 | 46 | 47 | 0 | 0 |
| Average/Sum#: | 24 # | 50 | 51 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 68 | 68 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 09/29/2026 00:00 | 1 | 46 | 47 | 0 | 0 |
| 09/29/2026 01:00 | 1 | 46 | 47 | 0 | 0 |
| 09/29/2026 02:00 | 1 | 46 | 47 | 0 | 0 |
| 09/29/2026 03:00 | 1 | 46 | 47 | 0 | 0 |
| 09/29/2026 04:00 | 1 | 46 | 47 | 0 | 0 |
| 09/29/2026 05:00 | 1 | 46 | 47 | 0 | 0 |
| 09/29/2026 06:00 | 1 | 46 | 47 | 0 | 0 |
| 09/29/2026 07:00 | 1 | 46 | 47 | 0 | 0 |
| 09/29/2026 08:00 | 1 | 46 | 47 | 0 | 0 |
| 09/29/2026 09:00 | 1 | 46 | 46 | 0 | 0 |
| 09/29/2026 10:00 | 1 | 46 | 46 | 0 | 0 |
| 09/29/2026 11:00 | 1 | 46 | 47 | 0 | 0 |
| 09/29/2026 12:00 | 1 | 46 | 47 | 0 | 0 |
| 09/29/2026 13:00 | 1 | 46 | 47 | 0 | 0 |
| 09/29/2026 14:00 | 1 | 46 | 46 | 0 | 0 |
| 09/29/2026 15:00 | 1 | 45 | 46 | 0 | 0 |
| 09/29/2026 16:00 | 1 | 46 | 47 | 0 | 0 |
| 09/29/2026 17:00 | 1 | 46 | 47 | 0 | 0 |
| 09/29/2026 18:00 | 1 | 46 | 47 | 0 | 0 |
| 09/29/2026 19:00 | 1 | 46 | 47 | 0 | 0 |
| 09/29/2026 20:00 | 1 | 46 | 47 | 0 | 0 |
| 09/29/2026 21:00 | 1 | 46 | 47 | 0 | 0 |
| 09/29/2026 22:00 | 1 | 46 | 47 | 0 | 0 |
| 09/29/2026 23:00 | 1 | 50 | 51 | 0 | 0 |
| Average/Sum#: | 24 # | 46 | 47 | 0 | 0 |
| Minimum: | 1 | 45 | 46 | 0 | 0 |
| Maximum: | 1 | 50 | 51 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# AQ34 3HR AVG LOAD

## CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/13/2026 12:15 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| | Units CT1 & CT2 UnitOn, TF 1 Hour(s) | Unit CT1 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT2 Load_Total_, 3Hr, MWe 1 Hour(s) | Unit CT5 Load, MWe 1 Hour(s) | Unit CT6 Load, MWe 1 Hour(s) |
|---|---|---|---|---|---|
| 09/30/2026 00:00 | 1 | 50 | 51 | 0 | 0 |
| 09/30/2026 01:00 | 1 | 50 | 51 | 0 | 0 |
| 09/30/2026 02:00 | 1 | 47 | 48 | 0 | 0 |
| 09/30/2026 03:00 | 1 | 53 | 54 | 0 | 0 |
| 09/30/2026 04:00 | 1 | 60 | 61 | 0 | 0 |
| 09/30/2026 05:00 | 1 | 67 | 68 | 0 | 0 |
| 09/30/2026 06:00 | 1 | 67 | 68 | 0 | 0 |
| 09/30/2026 07:00 | 1 | 60 | 61 | 0 | 0 |
| 09/30/2026 08:00 | 1 | 52 | 53 | 0 | 0 |
| 09/30/2026 09:00 | 1 | 46 | 47 | 0 | 0 |
| 09/30/2026 10:00 | 1 | 47 | 48 | 0 | 0 |
| 09/30/2026 11:00 | 1 | 49 | 50 | 0 | 0 |
| 09/30/2026 12:00 | 1 | 52 | 54 | 0 | 0 |
| 09/30/2026 13:00 | 1 | 58 | 60 | 0 | 0 |
| 09/30/2026 14:00 | 1 | 66 | 67 | 0 | 0 |
| 09/30/2026 15:00 | 1 | 72 | 73 | 0 | 0 |
| 09/30/2026 16:00 | 1 | 75 | 76 | 0 | 0 |
| 09/30/2026 17:00 | 1 | 75 | 76 | 0 | 0 |
| 09/30/2026 18:00 | 1 | 72 | 73 | 0 | 0 |
| 09/30/2026 19:00 | 1 | 69 | 69 | 0 | 0 |
| 09/30/2026 20:00 | 1 | 64 | 64 | 0 | 0 |
| 09/30/2026 21:00 | 1 | 64 | 64 | 0 | 0 |
| 09/30/2026 22:00 | 1 | 59 | 60 | 0 | 0 |
| 09/30/2026 23:00 | 1 | 56 | 57 | 0 | 0 |
| Average/Sum#: | 24 # | 60 | 61 | 0 | 0 |
| Minimum: | 1 | 46 | 47 | 0 | 0 |
| Maximum: | 1 | 75 | 76 | 0 | 0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# Monthly Summary Report

## Units CT1 / CT2 / CT5 / CT6

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

| | Unit CT1 OperatingTime, Hr | | Unit CT1 DBOn, Hr | | Unit CT2 OperatingTime, Hr | | Unit CT2 DBOn, Hr | | Unit CT5 OperatingTime, Hr | | Unit CT6 OperatingTime, Hr | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| | 1 Hour(s) | | 1 Hour(s) | | 1 Hour(s) | | 1 Hour(s) | | 1 Hour(s) | | 1 Hour(s) | |
| Date | Sum | Running Sum | Sum | Running Sum | Sum | Running Sum | Sum | Running Sum | Sum | Running Sum | Sum | Running Sum |
| Jul 26 | 517.14 | 517.14 | 419.42 | 419.42 | 744.00 | 744.00 | 419.81 | 419.81 | 18.69 | 18.69 | 23.21 | 23.21 |
| Aug 26 | 744.00 | 1,261.14 | 286.71 | 706.13 | 744.00 | 1,488.00 | 286.90 | 706.71 | 20.62 | 39.31 | 33.31 | 56.52 |
| Sep 26 | 720.00 | 1,981.14 | 63.94 | 770.07 | 712.34 | 2,200.34 | 63.91 | 770.62 | 16.48 | 55.79 | 18.70 | 75.22 |
| Sum/Avg | 1,981.14 | | 770.07 | | 2,200.34 | | 770.62 | | 55.79 | | 75.22 | |
| Limit | | | | | | | | | | | | |

# Tons 12 Month Rolling Summary

## CT1 and CT2 Combined

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

* = Excess Emission

| | Units CT1 & CT2 | | Units CT1 & CT2 | | Units CT1 & CT2 | | Units CT1 & CT2 | | Units CT1 & CT2 | |
|---|---|---|---|---|---|---|---|---|---|---|
| | CO, Ton | | NOx, Ton | | PM10, Ton | | SO2, Ton | | VOC, Ton | |
| | 1 Day(s) | | 1 Day(s) | | 1 Day(s) | | 1 Day(s) | | 1 Day(s) | |
| Date | Sum | Rolling Sum | Sum | Rolling Sum | Sum | Rolling Sum | Sum | Rolling Sum | Sum | Rolling Sum |
| Jul 2026 | 0.6614 | 3.8910 | 1.7946 | 8.1068 | 0.3783 | 1.6940 | 0.1892 | 0.8514 | 0.6307 | 2.8348 |
| Aug 2026 | 0.5214 | 3.7438 | 1.8899 | 8.1015 | 0.4051 | 1.6896 | 0.2022 | 0.8469 | 0.6738 | 2.8210 |
| Sep 2026 | 0.5150 | 3.4875 | 1.6011 | 7.6356 | 0.3417 | 1.5692 | 0.1712 | 0.7868 | 0.5696 | 2.6190 |
| **Sum/Avg** | 3.4875 | | 7.6356 | | 1.5692 | | 0.7868 | | 2.6190 | |
| **Limit** | | | | | | | | | | |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 07/01/2026 00:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/01/2026 01:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/01/2026 02:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/01/2026 03:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/01/2026 04:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/01/2026 05:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/01/2026 06:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/01/2026 07:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/01/2026 08:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/01/2026 09:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/01/2026 10:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/01/2026 11:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/01/2026 12:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/01/2026 13:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/01/2026 14:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/01/2026 15:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/01/2026 16:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/01/2026 17:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/01/2026 18:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/01/2026 19:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/01/2026 20:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/01/2026 21:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/01/2026 22:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/01/2026 23:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| Average/Sum#: | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| Minimum: | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| Maximum: | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| %SI | 100.00 | 100.00 | 100.00 | 0.00 | 100.00 | 100.00 | 100.00 | 100.00 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 07/02/2026 00:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/02/2026 01:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/02/2026 02:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/02/2026 03:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/02/2026 04:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/02/2026 05:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/02/2026 06:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/02/2026 07:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/02/2026 08:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/02/2026 09:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/02/2026 10:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/02/2026 11:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/02/2026 12:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/02/2026 13:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/02/2026 14:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/02/2026 15:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/02/2026 16:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/02/2026 17:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/02/2026 18:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/02/2026 19:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/02/2026 20:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/02/2026 21:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/02/2026 22:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/02/2026 23:00 | 1,990.9 | 0.0 | 1,990.9 | 104,600.0 | 208.2 | 0.00 | 0.0 | 0.0 |
| Average/Sum#: | 1,990.9 | 0.0 | 1,990.9 | 104,600.0 | 208.2 | 0.00 | 0.0 | 0.0 |
| Minimum: | 1,990.9 | 0.0 | 1,990.9 | 104,600.0 | 208.2 | 0.00 | 0.0 | 0.0 |
| Maximum: | 1,990.9 | 0.0 | 1,990.9 | 104,600.0 | 208.2 | 0.00 | 0.0 | 0.0 |
| %SI | 95.83 | 95.83 | 95.83 | 0.00 | 95.83 | 100.00 | 100.00 | 100.00 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 07/03/2026 00:00 | 3,547.7 | 0.0 | 3,547.7 | 104,600.0 | 371.1 | 0.43 | 0.2 | 0.7 |
| 07/03/2026 01:00 | 3,396.4 | 0.0 | 3,396.4 | 104,600.0 | 355.3 | 0.43 | 0.2 | 0.7 |
| 07/03/2026 02:00 | 3,379.5 | 0.0 | 3,379.5 | 104,600.0 | 353.5 | 0.42 | 0.2 | 0.7 |
| 07/03/2026 03:00 | 3,377.7 | 0.0 | 3,377.7 | 104,600.0 | 353.3 | 0.42 | 0.2 | 0.7 |
| 07/03/2026 04:00 | 2,803.1 | 0.0 | 2,803.1 | 104,600.0 | 293.2 | 0.42 | 0.2 | 0.7 |
| 07/03/2026 05:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/03/2026 06:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/03/2026 07:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/03/2026 08:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/03/2026 09:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/03/2026 10:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/03/2026 11:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/03/2026 12:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/03/2026 13:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/03/2026 14:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/03/2026 15:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/03/2026 16:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/03/2026 17:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/03/2026 18:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/03/2026 19:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/03/2026 20:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/03/2026 21:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/03/2026 22:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/03/2026 23:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| Average/Sum#: | 3,300.9 | 0.0 | 3,300.9 | 104,600.0 | 345.3 | 0.42 | 0.2 | 0.7 |
| Minimum: | 2,803.1 | 0.0 | 2,803.1 | 104,600.0 | 293.2 | 0.42 | 0.2 | 0.7 |
| Maximum: | 3,547.7 | 0.0 | 3,547.7 | 104,600.0 | 371.1 | 0.43 | 0.2 | 0.7 |
| %SI | 79.17 | 79.17 | 79.17 | 0.00 | 79.17 | 79.17 | 79.17 | 79.17 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 07/04/2026 00:00 | 1,963.3 | 0.0 | 1,963.3 | 104,600.0 | 205.4 | 0.00 | 0.0 | 0.0 |
| 07/04/2026 01:00 | 3,526.4 | 0.0 | 3,526.4 | 104,600.0 | 368.9 | 0.43 | 0.2 | 0.7 |
| 07/04/2026 02:00 | 3,405.0 | 0.0 | 3,405.0 | 104,600.0 | 356.2 | 0.43 | 0.2 | 0.7 |
| 07/04/2026 03:00 | 3,373.6 | 0.0 | 3,373.6 | 104,600.0 | 352.9 | 0.42 | 0.2 | 0.7 |
| 07/04/2026 04:00 | 3,378.3 | 0.0 | 3,378.3 | 104,600.0 | 353.4 | 0.42 | 0.2 | 0.7 |
| 07/04/2026 05:00 | 2,746.7 | 0.0 | 2,746.7 | 104,600.0 | 287.3 | 0.42 | 0.2 | 0.7 |
| 07/04/2026 06:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/04/2026 07:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/04/2026 08:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/04/2026 09:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/04/2026 10:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/04/2026 11:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/04/2026 12:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/04/2026 13:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/04/2026 14:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/04/2026 15:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/04/2026 16:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/04/2026 17:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/04/2026 18:00 | 2,620.0 | 0.0 | 2,620.0 | 104,600.0 | 274.1 | 0.00 | 0.0 | 0.0 |
| 07/04/2026 19:00 | 4,002.5 | 458.3 | 4,337.1 | 104,600.0 | 453.7 | 0.59 | 0.3 | 1.0 |
| 07/04/2026 20:00 | 3,911.9 | 277.5 | 4,056.2 | 104,600.0 | 424.3 | 0.52 | 0.3 | 0.9 |
| 07/04/2026 21:00 | 3,372.2 | 0.0 | 3,372.2 | 104,600.0 | 352.7 | 0.42 | 0.2 | 0.7 |
| 07/04/2026 22:00 | 3,516.8 | 0.0 | 3,516.8 | 104,600.0 | 367.9 | 0.44 | 0.2 | 0.7 |
| 07/04/2026 23:00 | 3,918.9 | 0.0 | 3,918.9 | 104,600.0 | 409.9 | 0.49 | 0.2 | 0.8 |
| Average/Sum#: | 3,311.3 | 61.3 | 3,351.2 | 104,600.0 | 350.6 | 0.46 | 0.2 | 0.8 |
| Minimum: | 1,963.3 | 0.0 | 1,963.3 | 104,600.0 | 205.4 | 0.42 | 0.2 | 0.7 |
| Maximum: | 4,002.5 | 458.3 | 4,337.1 | 104,600.0 | 453.7 | 0.59 | 0.3 | 1.0 |
| %SI | 50.00 | 50.00 | 50.00 | 0.00 | 50.00 | 58.33 | 58.33 | 58.33 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 07/05/2026 00:00 | 3,247.3 | 0.0 | 3,247.3 | 104,600.0 | 339.7 | 0.44 | 0.2 | 0.7 |
| 07/05/2026 01:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/05/2026 02:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/05/2026 03:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/05/2026 04:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/05/2026 05:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/05/2026 06:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/05/2026 07:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/05/2026 08:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/05/2026 09:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/05/2026 10:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/05/2026 11:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/05/2026 12:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/05/2026 13:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/05/2026 14:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/05/2026 15:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/05/2026 16:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/05/2026 17:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/05/2026 18:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/05/2026 19:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/05/2026 20:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/05/2026 21:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/05/2026 22:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/05/2026 23:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| Average/Sum#: | 3,247.3 | 0.0 | 3,247.3 | 104,600.0 | 339.7 | 0.44 | 0.2 | 0.7 |
| Minimum: | 3,247.3 | 0.0 | 3,247.3 | 104,600.0 | 339.7 | 0.44 | 0.2 | 0.7 |
| Maximum: | 3,247.3 | 0.0 | 3,247.3 | 104,600.0 | 339.7 | 0.44 | 0.2 | 0.7 |
| %SI | 95.83 | 95.83 | 95.83 | 0.00 | 95.83 | 95.83 | 95.83 | 95.83 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 07/06/2026 00:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/06/2026 01:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/06/2026 02:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/06/2026 03:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/06/2026 04:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/06/2026 05:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/06/2026 06:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/06/2026 07:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/06/2026 08:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/06/2026 09:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/06/2026 10:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/06/2026 11:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/06/2026 12:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/06/2026 13:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/06/2026 14:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/06/2026 15:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/06/2026 16:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/06/2026 17:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/06/2026 18:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/06/2026 19:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/06/2026 20:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/06/2026 21:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/06/2026 22:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/06/2026 23:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| Average/Sum#: | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| Minimum: | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| Maximum: | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| %SI | 100.00 | 100.00 | 100.00 | 0.00 | 100.00 | 100.00 | 100.00 | 100.00 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 07/07/2026 00:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/07/2026 01:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/07/2026 02:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/07/2026 03:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/07/2026 04:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/07/2026 05:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/07/2026 06:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/07/2026 07:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/07/2026 08:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/07/2026 09:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/07/2026 10:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/07/2026 11:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/07/2026 12:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/07/2026 13:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/07/2026 14:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/07/2026 15:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/07/2026 16:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/07/2026 17:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/07/2026 18:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/07/2026 19:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/07/2026 20:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/07/2026 21:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/07/2026 22:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/07/2026 23:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| Average/Sum#: | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| Minimum: | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| Maximum: | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| %SI | 100.00 | 100.00 | 100.00 | 0.00 | 100.00 | 100.00 | 100.00 | 100.00 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 07/08/2026 00:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/08/2026 01:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/08/2026 02:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/08/2026 03:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/08/2026 04:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/08/2026 05:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/08/2026 06:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/08/2026 07:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/08/2026 08:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/08/2026 09:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/08/2026 10:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/08/2026 11:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/08/2026 12:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/08/2026 13:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/08/2026 14:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/08/2026 15:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/08/2026 16:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/08/2026 17:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/08/2026 18:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/08/2026 19:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/08/2026 20:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/08/2026 21:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/08/2026 22:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/08/2026 23:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| Average/Sum#: | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| Minimum: | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| Maximum: | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| %SI | 100.00 | 100.00 | 100.00 | 0.00 | 100.00 | 100.00 | 100.00 | 100.00 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 07/09/2026 00:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/09/2026 01:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/09/2026 02:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/09/2026 03:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/09/2026 04:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/09/2026 05:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/09/2026 06:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/09/2026 07:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/09/2026 08:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/09/2026 09:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/09/2026 10:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/09/2026 11:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/09/2026 12:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/09/2026 13:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/09/2026 14:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/09/2026 15:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/09/2026 16:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/09/2026 17:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/09/2026 18:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/09/2026 19:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/09/2026 20:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/09/2026 21:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/09/2026 22:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/09/2026 23:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| Average/Sum#: | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| Minimum: | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| Maximum: | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| %SI | 100.00 | 100.00 | 100.00 | 0.00 | 100.00 | 100.00 | 100.00 | 100.00 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 07/10/2026 00:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/10/2026 01:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/10/2026 02:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/10/2026 03:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/10/2026 04:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/10/2026 05:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/10/2026 06:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/10/2026 07:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/10/2026 08:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/10/2026 09:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/10/2026 10:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/10/2026 11:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/10/2026 12:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/10/2026 13:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/10/2026 14:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/10/2026 15:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/10/2026 16:00 | 2,926.1 | 0.0 | 2,926.1 | 104,600.0 | 306.1 | 0.00 | 0.0 | 0.0 |
| 07/10/2026 17:00 | 4,238.9 | 532.5 | 4,622.3 | 104,600.0 | 483.5 | 0.61 | 0.3 | 1.0 |
| 07/10/2026 18:00 | 4,087.1 | 986.0 | 5,073.1 | 104,600.0 | 530.6 | 0.64 | 0.3 | 1.1 |
| 07/10/2026 19:00 | 4,105.9 | 872.6 | 4,978.5 | 104,600.0 | 520.8 | 0.63 | 0.3 | 1.0 |
| 07/10/2026 20:00 | 4,236.6 | 530.1 | 4,766.7 | 104,600.0 | 498.6 | 0.60 | 0.3 | 1.0 |
| 07/10/2026 21:00 | 4,282.1 | 449.7 | 4,731.8 | 104,600.0 | 494.9 | 0.59 | 0.3 | 1.0 |
| 07/10/2026 22:00 | 4,317.2 | 405.9 | 4,723.1 | 104,600.0 | 494.0 | 0.59 | 0.3 | 1.0 |
| 07/10/2026 23:00 | 4,347.8 | 358.4 | 4,706.2 | 104,600.0 | 492.3 | 0.59 | 0.3 | 1.0 |
| Average/Sum#: | 4,067.7 | 516.9 | 4,566.0 | 104,600.0 | 477.6 | 0.61 | 0.3 | 1.0 |
| Minimum: | 2,926.1 | 0.0 | 2,926.1 | 104,600.0 | 306.1 | 0.59 | 0.3 | 1.0 |
| Maximum: | 4,347.8 | 986.0 | 5,073.1 | 104,600.0 | 530.6 | 0.64 | 0.3 | 1.1 |
| %SI | 66.67 | 66.67 | 66.67 | 0.00 | 66.67 | 70.83 | 70.83 | 70.83 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 07/11/2026 00:00 | 4,366.7 | 320.2 | 4,686.9 | 104,600.0 | 490.2 | 0.59 | 0.3 | 1.0 |
| 07/11/2026 01:00 | 4,383.3 | 285.0 | 4,668.3 | 104,600.0 | 488.3 | 0.59 | 0.3 | 1.0 |
| 07/11/2026 02:00 | 4,397.9 | 248.1 | 4,646.0 | 104,600.0 | 486.0 | 0.58 | 0.3 | 1.0 |
| 07/11/2026 03:00 | 4,415.3 | 223.8 | 4,639.1 | 104,600.0 | 485.2 | 0.58 | 0.3 | 1.0 |
| 07/11/2026 04:00 | 4,198.3 | 129.3 | 4,275.9 | 104,600.0 | 447.3 | 0.54 | 0.3 | 0.9 |
| 07/11/2026 05:00 | 3,020.3 | 0.0 | 3,020.3 | 104,600.0 | 315.9 | 0.43 | 0.2 | 0.7 |
| 07/11/2026 06:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/11/2026 07:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/11/2026 08:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/11/2026 09:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/11/2026 10:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/11/2026 11:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/11/2026 12:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/11/2026 13:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/11/2026 14:00 | 0.0 | 0.0 | 0.0 | 104,600.0 | 0.0 | 0.00 | 0.0 | 0.0 |
| 07/11/2026 15:00 | 588.2 | 0.0 | 588.2 | 104,600.0 | 61.5 | 0.00 | 0.0 | 0.0 |
| 07/11/2026 16:00 | 3,016.5 | 0.0 | 3,016.5 | 104,600.0 | 315.5 | 0.46 | 0.2 | 0.8 |
| 07/11/2026 17:00 | 4,245.2 | 718.8 | 4,748.4 | 104,600.0 | 496.7 | 0.62 | 0.3 | 1.0 |
| 07/11/2026 18:00 | 4,291.4 | 529.0 | 4,820.4 | 104,600.0 | 504.2 | 0.61 | 0.3 | 1.0 |
| 07/11/2026 19:00 | 4,271.3 | 493.2 | 4,764.5 | 104,600.0 | 498.4 | 0.60 | 0.3 | 1.0 |
| 07/11/2026 20:00 | 4,175.6 | 654.8 | 4,830.4 | 104,600.0 | 505.3 | 0.61 | 0.3 | 1.0 |
| 07/11/2026 21:00 | 4,208.5 | 824.8 | 5,033.3 | 104,600.0 | 526.5 | 0.63 | 0.3 | 1.1 |
| 07/11/2026 22:00 | 4,237.4 | 572.5 | 4,809.9 | 104,600.0 | 503.1 | 0.60 | 0.3 | 1.0 |
| 07/11/2026 23:00 | 4,244.5 | 1,136.9 | 5,381.4 | 104,600.0 | 562.9 | 0.68 | 0.3 | 1.1 |
| Average/Sum#: | 3,870.7 | 409.1 | 4,262.0 | 104,600.0 | 445.8 | 0.58 | 0.3 | 1.0 |
| Minimum: | 588.2 | 0.0 | 588.2 | 104,600.0 | 61.5 | 0.43 | 0.2 | 0.7 |
| Maximum: | 4,415.3 | 1,136.9 | 5,381.4 | 104,600.0 | 562.9 | 0.68 | 0.3 | 1.1 |
| %SI | 37.50 | 37.50 | 37.50 | 0.00 | 37.50 | 41.67 | 41.67 | 41.67 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 07/12/2026 00:00 | 4,247.4 | 505.4 | 4,752.8 | 104,600.0 | 497.1 | 0.60 | 0.3 | 1.0 |
| 07/12/2026 01:00 | 4,259.8 | 471.7 | 4,731.5 | 104,600.0 | 494.9 | 0.59 | 0.3 | 1.0 |
| 07/12/2026 02:00 | 4,280.7 | 448.7 | 4,729.4 | 104,600.0 | 494.7 | 0.59 | 0.3 | 1.0 |
| 07/12/2026 03:00 | 4,286.8 | 446.8 | 4,733.6 | 104,600.0 | 495.1 | 0.59 | 0.3 | 1.0 |
| 07/12/2026 04:00 | 4,307.9 | 420.8 | 4,728.7 | 104,600.0 | 494.6 | 0.59 | 0.3 | 1.0 |
| 07/12/2026 05:00 | 4,297.6 | 423.5 | 4,721.1 | 104,600.0 | 493.8 | 0.59 | 0.3 | 1.0 |
| 07/12/2026 06:00 | 4,340.0 | 438.8 | 4,778.8 | 104,600.0 | 499.9 | 0.60 | 0.3 | 1.0 |
| 07/12/2026 07:00 | 4,291.8 | 1,047.4 | 5,339.2 | 104,600.0 | 558.5 | 0.67 | 0.3 | 1.1 |
| 07/12/2026 08:00 | 4,281.1 | 1,301.2 | 5,582.3 | 104,600.0 | 583.9 | 0.70 | 0.4 | 1.2 |
| 07/12/2026 09:00 | 4,268.7 | 648.3 | 4,917.0 | 104,600.0 | 514.3 | 0.62 | 0.3 | 1.0 |
| 07/12/2026 10:00 | 4,270.1 | 490.7 | 4,760.8 | 104,600.0 | 498.0 | 0.60 | 0.3 | 1.0 |
| 07/12/2026 11:00 | 4,206.8 | 611.8 | 4,818.6 | 104,600.0 | 504.0 | 0.61 | 0.3 | 1.0 |
| 07/12/2026 12:00 | 4,106.7 | 758.4 | 4,865.1 | 104,600.0 | 508.9 | 0.61 | 0.3 | 1.0 |
| 07/12/2026 13:00 | 4,095.0 | 1,240.1 | 5,335.1 | 104,600.0 | 558.1 | 0.67 | 0.3 | 1.1 |
| 07/12/2026 14:00 | 4,273.1 | 1,354.7 | 5,627.8 | 104,600.0 | 588.7 | 0.71 | 0.4 | 1.2 |
| 07/12/2026 15:00 | 4,260.2 | 1,674.3 | 5,934.5 | 104,600.0 | 620.7 | 0.74 | 0.4 | 1.2 |
| 07/12/2026 16:00 | 4,257.7 | 1,666.6 | 5,924.3 | 104,600.0 | 619.7 | 0.74 | 0.4 | 1.2 |
| 07/12/2026 17:00 | 4,251.7 | 997.1 | 5,248.8 | 104,600.0 | 549.0 | 0.66 | 0.3 | 1.1 |
| 07/12/2026 18:00 | 4,271.1 | 645.0 | 4,916.1 | 104,600.0 | 514.2 | 0.62 | 0.3 | 1.0 |
| 07/12/2026 19:00 | 4,289.3 | 1,550.3 | 5,839.6 | 104,600.0 | 610.8 | 0.73 | 0.4 | 1.2 |
| 07/12/2026 20:00 | 4,308.1 | 1,686.3 | 5,994.4 | 104,600.0 | 627.0 | 0.75 | 0.4 | 1.3 |
| 07/12/2026 21:00 | 4,310.1 | 1,658.6 | 5,968.7 | 104,600.0 | 624.3 | 0.75 | 0.4 | 1.2 |
| 07/12/2026 22:00 | 4,307.8 | 1,037.1 | 5,344.9 | 104,600.0 | 559.1 | 0.67 | 0.3 | 1.1 |
| 07/12/2026 23:00 | 3,580.6 | 0.0 | 3,580.6 | 104,600.0 | 374.5 | 0.45 | 0.2 | 0.7 |
| Average/Sum#: | 4,235.4 | 896.8 | 5,132.2 | 104,600.0 | 536.8 | 0.64 | 0.3 | 1.1 |
| Minimum: | 3,580.6 | 0.0 | 3,580.6 | 104,600.0 | 374.5 | 0.45 | 0.2 | 0.7 |
| Maximum: | 4,340.0 | 1,686.3 | 5,994.4 | 104,600.0 | 627.0 | 0.75 | 0.4 | 1.3 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 07/13/2026 00:00 | 3,693.8 | 0.0 | 3,693.8 | 104,600.0 | 386.4 | 0.46 | 0.2 | 0.8 |
| 07/13/2026 01:00 | 4,113.7 | 0.0 | 4,113.7 | 104,600.0 | 430.3 | 0.52 | 0.3 | 0.9 |
| 07/13/2026 02:00 | 4,115.7 | 0.0 | 4,115.7 | 104,600.0 | 430.5 | 0.52 | 0.3 | 0.9 |
| 07/13/2026 03:00 | 4,042.3 | 0.0 | 4,042.3 | 104,600.0 | 422.8 | 0.51 | 0.3 | 0.8 |
| 07/13/2026 04:00 | 4,102.2 | 0.0 | 4,102.2 | 104,600.0 | 429.1 | 0.52 | 0.3 | 0.9 |
| 07/13/2026 05:00 | 3,843.5 | 0.0 | 3,843.5 | 104,600.0 | 402.0 | 0.48 | 0.2 | 0.8 |
| 07/13/2026 06:00 | 4,102.5 | 0.0 | 4,102.5 | 104,600.0 | 429.1 | 0.52 | 0.3 | 0.9 |
| 07/13/2026 07:00 | 4,061.8 | 0.0 | 4,061.8 | 104,600.0 | 424.9 | 0.51 | 0.3 | 0.8 |
| 07/13/2026 08:00 | 4,196.2 | 1,144.3 | 5,306.2 | 104,600.0 | 555.0 | 0.67 | 0.3 | 1.1 |
| 07/13/2026 09:00 | 4,274.2 | 1,816.3 | 6,090.5 | 104,600.0 | 637.1 | 0.77 | 0.4 | 1.3 |
| 07/13/2026 10:00 | 4,303.8 | 1,748.1 | 6,051.9 | 104,600.0 | 633.0 | 0.76 | 0.4 | 1.3 |
| 07/13/2026 11:00 | 4,296.9 | 1,744.1 | 6,041.0 | 104,600.0 | 631.9 | 0.76 | 0.4 | 1.3 |
| 07/13/2026 12:00 | 4,284.7 | 1,747.2 | 6,031.9 | 104,600.0 | 630.9 | 0.76 | 0.4 | 1.3 |
| 07/13/2026 13:00 | 4,271.3 | 1,788.8 | 6,060.1 | 104,600.0 | 633.9 | 0.76 | 0.4 | 1.3 |
| 07/13/2026 14:00 | 4,270.7 | 1,774.0 | 6,044.7 | 104,600.0 | 632.3 | 0.76 | 0.4 | 1.3 |
| 07/13/2026 15:00 | 4,261.3 | 1,787.9 | 6,049.2 | 104,600.0 | 632.7 | 0.76 | 0.4 | 1.3 |
| 07/13/2026 16:00 | 4,253.0 | 1,789.4 | 6,042.4 | 104,600.0 | 632.0 | 0.76 | 0.4 | 1.3 |
| 07/13/2026 17:00 | 4,236.0 | 1,743.5 | 5,979.5 | 104,600.0 | 625.5 | 0.75 | 0.4 | 1.3 |
| 07/13/2026 18:00 | 4,235.2 | 1,734.1 | 5,969.3 | 104,600.0 | 624.4 | 0.75 | 0.4 | 1.2 |
| 07/13/2026 19:00 | 4,252.7 | 1,757.9 | 6,010.6 | 104,600.0 | 628.7 | 0.75 | 0.4 | 1.3 |
| 07/13/2026 20:00 | 4,303.1 | 1,675.8 | 5,978.9 | 104,600.0 | 625.4 | 0.75 | 0.4 | 1.3 |
| 07/13/2026 21:00 | 4,321.5 | 1,507.9 | 5,829.4 | 104,600.0 | 609.8 | 0.73 | 0.4 | 1.2 |
| 07/13/2026 22:00 | 4,338.7 | 751.5 | 5,090.2 | 104,600.0 | 532.4 | 0.64 | 0.3 | 1.1 |
| 07/13/2026 23:00 | 4,332.0 | 508.1 | 4,840.1 | 104,600.0 | 506.3 | 0.61 | 0.3 | 1.0 |
| Average/Sum#: | 4,187.8 | 1,042.5 | 5,228.8 | 104,600.0 | 546.9 | 0.66 | 0.3 | 1.1 |
| Minimum: | 3,693.8 | 0.0 | 3,693.8 | 104,600.0 | 386.4 | 0.46 | 0.2 | 0.8 |
| Maximum: | 4,338.7 | 1,816.3 | 6,090.5 | 104,600.0 | 637.1 | 0.77 | 0.4 | 1.3 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 07/14/2026 00:00 | 4,346.5 | 777.0 | 5,123.5 | 104,600.0 | 535.9 | 0.64 | 0.3 | 1.1 |
| 07/14/2026 01:00 | 4,297.4 | 464.7 | 4,762.1 | 104,600.0 | 498.1 | 0.60 | 0.3 | 1.0 |
| 07/14/2026 02:00 | 4,228.0 | 552.5 | 4,780.5 | 104,600.0 | 500.0 | 0.60 | 0.3 | 1.0 |
| 07/14/2026 03:00 | 4,252.5 | 501.0 | 4,753.5 | 104,600.0 | 497.2 | 0.60 | 0.3 | 1.0 |
| 07/14/2026 04:00 | 4,256.3 | 491.1 | 4,747.4 | 104,600.0 | 496.6 | 0.60 | 0.3 | 1.0 |
| 07/14/2026 05:00 | 4,273.7 | 765.1 | 5,038.8 | 104,600.0 | 527.1 | 0.63 | 0.3 | 1.1 |
| 07/14/2026 06:00 | 4,266.4 | 451.8 | 4,718.2 | 104,600.0 | 493.5 | 0.59 | 0.3 | 1.0 |
| 07/14/2026 07:00 | 4,223.5 | 542.8 | 4,766.3 | 104,600.0 | 498.6 | 0.60 | 0.3 | 1.0 |
| 07/14/2026 08:00 | 4,144.7 | 668.1 | 4,812.8 | 104,600.0 | 503.4 | 0.60 | 0.3 | 1.0 |
| 07/14/2026 09:00 | 4,010.4 | 878.3 | 4,888.7 | 104,600.0 | 511.4 | 0.61 | 0.3 | 1.0 |
| 07/14/2026 10:00 | 3,929.2 | 1,036.4 | 4,965.6 | 104,600.0 | 519.4 | 0.62 | 0.3 | 1.0 |
| 07/14/2026 11:00 | 3,846.8 | 1,217.5 | 5,064.3 | 104,600.0 | 529.7 | 0.64 | 0.3 | 1.1 |
| 07/14/2026 12:00 | 4,200.8 | 875.1 | 5,075.9 | 104,600.0 | 530.9 | 0.64 | 0.3 | 1.1 |
| 07/14/2026 13:00 | 4,223.0 | 1,146.0 | 5,369.0 | 104,600.0 | 561.6 | 0.67 | 0.3 | 1.1 |
| 07/14/2026 14:00 | 4,216.1 | 1,532.1 | 5,748.2 | 104,600.0 | 601.3 | 0.72 | 0.4 | 1.2 |
| 07/14/2026 15:00 | 4,210.1 | 1,694.8 | 5,904.9 | 104,600.0 | 617.7 | 0.74 | 0.4 | 1.2 |
| 07/14/2026 16:00 | 4,194.7 | 1,664.2 | 5,858.9 | 104,600.0 | 612.8 | 0.73 | 0.4 | 1.2 |
| 07/14/2026 17:00 | 4,194.9 | 1,759.4 | 5,954.3 | 104,600.0 | 622.8 | 0.75 | 0.4 | 1.2 |
| 07/14/2026 18:00 | 4,192.0 | 1,726.0 | 5,918.0 | 104,600.0 | 619.0 | 0.74 | 0.4 | 1.2 |
| 07/14/2026 19:00 | 4,192.4 | 1,554.3 | 5,746.7 | 104,600.0 | 601.1 | 0.72 | 0.4 | 1.2 |
| 07/14/2026 20:00 | 4,248.0 | 1,256.7 | 5,504.7 | 104,600.0 | 575.8 | 0.69 | 0.3 | 1.2 |
| 07/14/2026 21:00 | 4,266.3 | 1,340.3 | 5,606.6 | 104,600.0 | 586.5 | 0.70 | 0.4 | 1.2 |
| 07/14/2026 22:00 | 4,280.4 | 743.7 | 5,024.1 | 104,600.0 | 525.5 | 0.63 | 0.3 | 1.1 |
| 07/14/2026 23:00 | 4,295.6 | 395.5 | 4,691.1 | 104,600.0 | 490.7 | 0.59 | 0.3 | 1.0 |
| Average/Sum#: | 4,199.6 | 1,001.4 | 5,201.0 | 104,600.0 | 544.0 | 0.65 | 0.3 | 1.1 |
| Minimum: | 3,846.8 | 395.5 | 4,691.1 | 104,600.0 | 490.7 | 0.59 | 0.3 | 1.0 |
| Maximum: | 4,346.5 | 1,759.4 | 5,954.3 | 104,600.0 | 622.8 | 0.75 | 0.4 | 1.2 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 07/15/2026 00:00 | 4,201.8 | 526.8 | 4,728.6 | 104,600.0 | 494.6 | 0.60 | 0.3 | 1.0 |
| 07/15/2026 01:00 | 4,141.5 | 609.0 | 4,750.5 | 104,600.0 | 496.9 | 0.60 | 0.3 | 1.0 |
| 07/15/2026 02:00 | 4,155.2 | 566.2 | 4,721.4 | 104,600.0 | 493.9 | 0.59 | 0.3 | 1.0 |
| 07/15/2026 03:00 | 4,178.2 | 530.7 | 4,708.9 | 104,600.0 | 492.6 | 0.59 | 0.3 | 1.0 |
| 07/15/2026 04:00 | 4,203.1 | 504.5 | 4,707.6 | 104,600.0 | 492.4 | 0.59 | 0.3 | 1.0 |
| 07/15/2026 05:00 | 4,228.7 | 483.5 | 4,712.2 | 104,600.0 | 492.9 | 0.59 | 0.3 | 1.0 |
| 07/15/2026 06:00 | 4,230.1 | 520.1 | 4,750.2 | 104,600.0 | 496.9 | 0.60 | 0.3 | 1.0 |
| 07/15/2026 07:00 | 4,179.9 | 623.7 | 4,803.6 | 104,600.0 | 502.5 | 0.60 | 0.3 | 1.0 |
| 07/15/2026 08:00 | 4,079.1 | 775.0 | 4,854.1 | 104,600.0 | 507.7 | 0.61 | 0.3 | 1.0 |
| 07/15/2026 09:00 | 3,977.0 | 991.4 | 4,968.4 | 104,600.0 | 519.7 | 0.62 | 0.3 | 1.0 |
| 07/15/2026 10:00 | 4,140.5 | 1,754.7 | 5,895.2 | 104,600.0 | 616.6 | 0.74 | 0.4 | 1.2 |
| 07/15/2026 11:00 | 4,222.0 | 1,731.0 | 5,953.0 | 104,600.0 | 622.7 | 0.75 | 0.4 | 1.2 |
| 07/15/2026 12:00 | 4,210.7 | 1,249.7 | 5,460.4 | 104,600.0 | 571.2 | 0.69 | 0.3 | 1.1 |
| 07/15/2026 13:00 | 4,200.7 | 1,471.4 | 5,672.1 | 104,600.0 | 593.3 | 0.71 | 0.4 | 1.2 |
| 07/15/2026 14:00 | 4,183.0 | 1,866.5 | 6,049.5 | 104,600.0 | 632.8 | 0.76 | 0.4 | 1.3 |
| 07/15/2026 15:00 | 4,159.8 | 1,706.6 | 5,866.4 | 104,600.0 | 613.6 | 0.74 | 0.4 | 1.2 |
| 07/15/2026 16:00 | 4,175.2 | 1,889.8 | 6,065.0 | 104,600.0 | 634.4 | 0.76 | 0.4 | 1.3 |
| 07/15/2026 17:00 | 4,183.9 | 1,798.2 | 5,982.1 | 104,600.0 | 625.7 | 0.75 | 0.4 | 1.3 |
| 07/15/2026 18:00 | 4,214.4 | 1,800.3 | 6,014.7 | 104,600.0 | 629.1 | 0.75 | 0.4 | 1.3 |
| 07/15/2026 19:00 | 4,259.8 | 1,601.2 | 5,861.0 | 104,600.0 | 613.1 | 0.74 | 0.4 | 1.2 |
| 07/15/2026 20:00 | 4,276.0 | 1,390.5 | 5,666.5 | 104,600.0 | 592.7 | 0.71 | 0.4 | 1.2 |
| 07/15/2026 21:00 | 4,299.4 | 1,155.7 | 5,455.1 | 104,600.0 | 570.6 | 0.69 | 0.3 | 1.1 |
| 07/15/2026 22:00 | 4,180.3 | 782.3 | 4,962.6 | 104,600.0 | 519.1 | 0.62 | 0.3 | 1.0 |
| 07/15/2026 23:00 | 4,218.4 | 633.3 | 4,851.7 | 104,600.0 | 507.5 | 0.61 | 0.3 | 1.0 |
| Average/Sum#: | 4,187.4 | 1,123.4 | 5,310.9 | 104,600.0 | 555.5 | 0.67 | 0.3 | 1.1 |
| Minimum: | 3,977.0 | 483.5 | 4,707.6 | 104,600.0 | 492.4 | 0.59 | 0.3 | 1.0 |
| Maximum: | 4,299.4 | 1,889.8 | 6,065.0 | 104,600.0 | 634.4 | 0.76 | 0.4 | 1.3 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 07/16/2026 00:00 | 4,254.6 | 583.1 | 4,837.7 | 104,600.0 | 506.0 | 0.61 | 0.3 | 1.0 |
| 07/16/2026 01:00 | 4,263.4 | 521.1 | 4,784.5 | 104,600.0 | 500.5 | 0.60 | 0.3 | 1.0 |
| 07/16/2026 02:00 | 4,287.8 | 426.5 | 4,714.3 | 104,600.0 | 493.1 | 0.59 | 0.3 | 1.0 |
| 07/16/2026 03:00 | 4,315.1 | 378.5 | 4,693.6 | 104,600.0 | 491.0 | 0.59 | 0.3 | 1.0 |
| 07/16/2026 04:00 | 4,331.9 | 364.9 | 4,696.8 | 104,600.0 | 491.3 | 0.59 | 0.3 | 1.0 |
| 07/16/2026 05:00 | 4,342.1 | 354.7 | 4,696.8 | 104,600.0 | 491.3 | 0.59 | 0.3 | 1.0 |
| 07/16/2026 06:00 | 4,329.3 | 368.7 | 4,698.0 | 104,600.0 | 491.4 | 0.59 | 0.3 | 1.0 |
| 07/16/2026 07:00 | 4,297.1 | 438.2 | 4,735.3 | 104,600.0 | 495.3 | 0.59 | 0.3 | 1.0 |
| 07/16/2026 08:00 | 4,247.8 | 517.8 | 4,765.6 | 104,600.0 | 498.5 | 0.60 | 0.3 | 1.0 |
| 07/16/2026 09:00 | 4,197.5 | 596.6 | 4,794.1 | 104,600.0 | 501.5 | 0.60 | 0.3 | 1.0 |
| 07/16/2026 10:00 | 4,127.0 | 717.9 | 4,844.9 | 104,600.0 | 506.8 | 0.61 | 0.3 | 1.0 |
| 07/16/2026 11:00 | 4,051.5 | 875.1 | 4,926.6 | 105,300.0 | 518.8 | 0.62 | 0.3 | 1.0 |
| 07/16/2026 12:00 | 3,896.0 | 1,113.6 | 5,009.6 | 105,300.0 | 527.5 | 0.63 | 0.3 | 1.1 |
| 07/16/2026 13:00 | 3,867.4 | 1,185.1 | 5,052.5 | 105,300.0 | 532.0 | 0.64 | 0.3 | 1.1 |
| 07/16/2026 14:00 | 3,814.2 | 1,257.1 | 5,071.3 | 105,300.0 | 534.0 | 0.64 | 0.3 | 1.1 |
| 07/16/2026 15:00 | 3,750.8 | 1,330.6 | 5,081.4 | 105,300.0 | 535.1 | 0.64 | 0.3 | 1.1 |
| 07/16/2026 16:00 | 3,784.5 | 1,275.5 | 5,060.0 | 105,300.0 | 532.8 | 0.64 | 0.3 | 1.1 |
| 07/16/2026 17:00 | 3,873.2 | 1,183.2 | 5,056.4 | 105,300.0 | 532.4 | 0.64 | 0.3 | 1.1 |
| 07/16/2026 18:00 | 3,947.3 | 986.2 | 4,933.5 | 105,300.0 | 519.5 | 0.62 | 0.3 | 1.0 |
| 07/16/2026 19:00 | 4,081.5 | 738.1 | 4,819.6 | 105,300.0 | 507.5 | 0.61 | 0.3 | 1.0 |
| 07/16/2026 20:00 | 4,184.8 | 579.2 | 4,764.0 | 105,300.0 | 501.6 | 0.60 | 0.3 | 1.0 |
| 07/16/2026 21:00 | 4,235.4 | 505.1 | 4,740.5 | 105,300.0 | 499.2 | 0.60 | 0.3 | 1.0 |
| 07/16/2026 22:00 | 4,275.5 | 451.0 | 4,726.5 | 105,300.0 | 497.7 | 0.60 | 0.3 | 1.0 |
| 07/16/2026 23:00 | 4,308.4 | 397.3 | 4,705.7 | 105,300.0 | 495.5 | 0.59 | 0.3 | 1.0 |
| Average/Sum#: | 4,127.7 | 714.4 | 4,842.1 | 104,979.2 | 508.3 | 0.61 | 0.3 | 1.0 |
| Minimum: | 3,750.8 | 354.7 | 4,693.6 | 104,600.0 | 491.0 | 0.59 | 0.3 | 1.0 |
| Maximum: | 4,342.1 | 1,330.6 | 5,081.4 | 105,300.0 | 535.1 | 0.64 | 0.3 | 1.1 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 07/17/2026 00:00 | 4,330.9 | 366.8 | 4,697.7 | 105,300.0 | 494.7 | 0.59 | 0.3 | 1.0 |
| 07/17/2026 01:00 | 4,358.0 | 325.9 | 4,683.9 | 105,300.0 | 493.2 | 0.59 | 0.3 | 1.0 |
| 07/17/2026 02:00 | 4,360.0 | 324.1 | 4,684.1 | 105,300.0 | 493.2 | 0.59 | 0.3 | 1.0 |
| 07/17/2026 03:00 | 4,374.3 | 306.3 | 4,680.6 | 105,300.0 | 492.9 | 0.59 | 0.3 | 1.0 |
| 07/17/2026 04:00 | 4,399.0 | 265.9 | 4,664.9 | 105,300.0 | 491.2 | 0.59 | 0.3 | 1.0 |
| 07/17/2026 05:00 | 4,410.7 | 248.4 | 4,659.1 | 105,300.0 | 490.6 | 0.59 | 0.3 | 1.0 |
| 07/17/2026 06:00 | 4,398.1 | 284.0 | 4,682.1 | 105,300.0 | 493.0 | 0.59 | 0.3 | 1.0 |
| 07/17/2026 07:00 | 4,378.4 | 339.4 | 4,717.8 | 105,300.0 | 496.8 | 0.60 | 0.3 | 1.0 |
| 07/17/2026 08:00 | 4,332.5 | 416.3 | 4,748.8 | 105,300.0 | 500.0 | 0.60 | 0.3 | 1.0 |
| 07/17/2026 09:00 | 4,299.5 | 462.3 | 4,761.8 | 105,300.0 | 501.4 | 0.60 | 0.3 | 1.0 |
| 07/17/2026 10:00 | 4,257.4 | 536.6 | 4,794.0 | 105,300.0 | 504.8 | 0.61 | 0.3 | 1.0 |
| 07/17/2026 11:00 | 4,188.5 | 670.1 | 4,858.6 | 105,300.0 | 511.6 | 0.61 | 0.3 | 1.0 |
| 07/17/2026 12:00 | 4,069.9 | 860.8 | 4,930.7 | 105,300.0 | 519.2 | 0.62 | 0.3 | 1.0 |
| 07/17/2026 13:00 | 3,951.2 | 1,038.8 | 4,990.0 | 105,300.0 | 525.4 | 0.63 | 0.3 | 1.1 |
| 07/17/2026 14:00 | 3,834.2 | 1,188.7 | 5,022.9 | 105,300.0 | 528.9 | 0.63 | 0.3 | 1.1 |
| 07/17/2026 15:00 | 3,840.9 | 1,199.4 | 5,040.3 | 105,300.0 | 530.7 | 0.64 | 0.3 | 1.1 |
| 07/17/2026 16:00 | 3,818.7 | 1,215.3 | 5,034.0 | 105,300.0 | 530.1 | 0.64 | 0.3 | 1.1 |
| 07/17/2026 17:00 | 3,912.2 | 1,077.7 | 4,989.9 | 105,300.0 | 525.4 | 0.63 | 0.3 | 1.1 |
| 07/17/2026 18:00 | 4,070.3 | 815.9 | 4,886.2 | 105,300.0 | 514.5 | 0.62 | 0.3 | 1.0 |
| 07/17/2026 19:00 | 4,191.5 | 582.1 | 4,773.6 | 105,300.0 | 502.7 | 0.60 | 0.3 | 1.0 |
| 07/17/2026 20:00 | 4,245.0 | 473.7 | 4,718.7 | 105,300.0 | 496.9 | 0.60 | 0.3 | 1.0 |
| 07/17/2026 21:00 | 4,281.1 | 419.3 | 4,700.4 | 105,300.0 | 495.0 | 0.59 | 0.3 | 1.0 |
| 07/17/2026 22:00 | 4,323.3 | 359.8 | 4,683.1 | 105,300.0 | 493.1 | 0.59 | 0.3 | 1.0 |
| 07/17/2026 23:00 | 4,357.0 | 317.4 | 4,674.4 | 105,300.0 | 492.2 | 0.59 | 0.3 | 1.0 |
| Average/Sum#: | 4,207.6 | 587.3 | 4,794.9 | 105,300.0 | 504.9 | 0.61 | 0.3 | 1.0 |
| Minimum: | 3,818.7 | 248.4 | 4,659.1 | 105,300.0 | 490.6 | 0.59 | 0.3 | 1.0 |
| Maximum: | 4,410.7 | 1,215.3 | 5,040.3 | 105,300.0 | 530.7 | 0.64 | 0.3 | 1.1 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 07/18/2026 00:00 | 4,388.9 | 270.0 | 4,658.9 | 105,300.0 | 490.6 | 0.59 | 0.3 | 1.0 |
| 07/18/2026 01:00 | 4,398.9 | 242.0 | 4,640.9 | 105,300.0 | 488.7 | 0.59 | 0.3 | 1.0 |
| 07/18/2026 02:00 | 4,421.3 | 203.2 | 4,624.5 | 105,300.0 | 487.0 | 0.58 | 0.3 | 1.0 |
| 07/18/2026 03:00 | 4,446.1 | 181.7 | 4,627.8 | 105,300.0 | 487.3 | 0.58 | 0.3 | 1.0 |
| 07/18/2026 04:00 | 4,465.0 | 176.6 | 4,641.6 | 105,300.0 | 488.8 | 0.59 | 0.3 | 1.0 |
| 07/18/2026 05:00 | 4,475.9 | 332.2 | 4,784.8 | 105,300.0 | 503.8 | 0.61 | 0.3 | 1.0 |
| 07/18/2026 06:00 | 4,474.4 | 175.1 | 4,649.5 | 105,300.0 | 489.6 | 0.59 | 0.3 | 1.0 |
| 07/18/2026 07:00 | 4,459.0 | 198.8 | 4,657.8 | 105,300.0 | 490.5 | 0.59 | 0.3 | 1.0 |
| 07/18/2026 08:00 | 4,408.2 | 291.1 | 4,699.3 | 105,300.0 | 494.8 | 0.59 | 0.3 | 1.0 |
| 07/18/2026 09:00 | 4,354.6 | 378.5 | 4,733.1 | 105,300.0 | 498.4 | 0.60 | 0.3 | 1.0 |
| 07/18/2026 10:00 | 4,309.3 | 445.5 | 4,754.8 | 105,300.0 | 500.7 | 0.60 | 0.3 | 1.0 |
| 07/18/2026 11:00 | 3,955.7 | 265.0 | 4,093.5 | 105,300.0 | 431.0 | 0.53 | 0.3 | 0.9 |
| 07/18/2026 12:00 | 3,380.8 | 0.0 | 3,380.8 | 105,300.0 | 356.0 | 0.43 | 0.2 | 0.7 |
| 07/18/2026 13:00 | 3,591.1 | 20.3 | 3,593.5 | 105,300.0 | 378.4 | 0.46 | 0.2 | 0.8 |
| 07/18/2026 14:00 | 3,997.9 | 965.0 | 4,962.9 | 105,300.0 | 522.6 | 0.63 | 0.3 | 1.0 |
| 07/18/2026 15:00 | 3,942.1 | 1,045.4 | 4,987.5 | 105,300.0 | 525.2 | 0.63 | 0.3 | 1.1 |
| 07/18/2026 16:00 | 3,919.4 | 1,085.5 | 5,004.9 | 105,300.0 | 527.0 | 0.63 | 0.3 | 1.1 |
| 07/18/2026 17:00 | 3,909.7 | 1,086.7 | 4,996.4 | 105,300.0 | 526.1 | 0.63 | 0.3 | 1.1 |
| 07/18/2026 18:00 | 3,972.9 | 971.2 | 4,944.1 | 105,300.0 | 520.6 | 0.63 | 0.3 | 1.0 |
| 07/18/2026 19:00 | 4,114.4 | 721.1 | 4,835.5 | 105,300.0 | 509.2 | 0.61 | 0.3 | 1.0 |
| 07/18/2026 20:00 | 4,184.0 | 599.2 | 4,783.2 | 105,300.0 | 503.7 | 0.60 | 0.3 | 1.0 |
| 07/18/2026 21:00 | 4,206.6 | 562.0 | 4,768.6 | 105,300.0 | 502.1 | 0.60 | 0.3 | 1.0 |
| 07/18/2026 22:00 | 4,247.3 | 505.4 | 4,752.7 | 105,300.0 | 500.5 | 0.60 | 0.3 | 1.0 |
| 07/18/2026 23:00 | 4,288.8 | 448.1 | 4,736.9 | 105,300.0 | 498.8 | 0.60 | 0.3 | 1.0 |
| Average/Sum#: | 4,179.7 | 465.4 | 4,638.1 | 105,300.0 | 488.4 | 0.59 | 0.3 | 1.0 |
| Minimum: | 3,380.8 | 0.0 | 3,380.8 | 105,300.0 | 356.0 | 0.43 | 0.2 | 0.7 |
| Maximum: | 4,475.9 | 1,086.7 | 5,004.9 | 105,300.0 | 527.0 | 0.63 | 0.3 | 1.1 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 07/19/2026 00:00 | 4,319.4 | 396.1 | 4,715.5 | 105,300.0 | 496.5 | 0.60 | 0.3 | 1.0 |
| 07/19/2026 01:00 | 4,342.5 | 348.6 | 4,691.1 | 105,300.0 | 494.0 | 0.59 | 0.3 | 1.0 |
| 07/19/2026 02:00 | 4,366.9 | 308.0 | 4,674.9 | 105,300.0 | 492.3 | 0.59 | 0.3 | 1.0 |
| 07/19/2026 03:00 | 4,376.6 | 278.9 | 4,655.5 | 105,300.0 | 490.2 | 0.59 | 0.3 | 1.0 |
| 07/19/2026 04:00 | 4,384.8 | 250.8 | 4,635.6 | 105,300.0 | 488.1 | 0.59 | 0.3 | 1.0 |
| 07/19/2026 05:00 | 4,393.7 | 240.2 | 4,633.9 | 105,300.0 | 487.9 | 0.59 | 0.3 | 1.0 |
| 07/19/2026 06:00 | 4,391.7 | 263.8 | 4,655.5 | 105,300.0 | 490.2 | 0.59 | 0.3 | 1.0 |
| 07/19/2026 07:00 | 4,378.6 | 310.6 | 4,689.2 | 105,300.0 | 493.8 | 0.59 | 0.3 | 1.0 |
| 07/19/2026 08:00 | 4,333.4 | 386.0 | 4,719.4 | 105,300.0 | 497.0 | 0.60 | 0.3 | 1.0 |
| 07/19/2026 09:00 | 4,281.4 | 464.1 | 4,745.5 | 105,300.0 | 499.7 | 0.60 | 0.3 | 1.0 |
| 07/19/2026 10:00 | 4,237.2 | 563.0 | 4,800.2 | 105,300.0 | 505.5 | 0.61 | 0.3 | 1.0 |
| 07/19/2026 11:00 | 4,154.6 | 751.3 | 4,905.9 | 105,300.0 | 516.6 | 0.62 | 0.3 | 1.0 |
| 07/19/2026 12:00 | 4,018.5 | 959.6 | 4,978.1 | 105,300.0 | 524.2 | 0.63 | 0.3 | 1.0 |
| 07/19/2026 13:00 | 3,963.6 | 1,057.5 | 5,021.1 | 105,300.0 | 528.7 | 0.63 | 0.3 | 1.1 |
| 07/19/2026 14:00 | 3,913.0 | 1,140.5 | 5,053.5 | 105,300.0 | 532.1 | 0.64 | 0.3 | 1.1 |
| 07/19/2026 15:00 | 3,862.6 | 1,231.5 | 5,094.1 | 105,300.0 | 536.4 | 0.64 | 0.3 | 1.1 |
| 07/19/2026 16:00 | 3,841.8 | 1,283.5 | 5,125.3 | 105,300.0 | 539.7 | 0.65 | 0.3 | 1.1 |
| 07/19/2026 17:00 | 4,013.4 | 1,545.5 | 5,558.9 | 105,300.0 | 585.4 | 0.70 | 0.4 | 1.2 |
| 07/19/2026 18:00 | 4,261.9 | 1,360.0 | 5,621.9 | 105,300.0 | 592.0 | 0.71 | 0.4 | 1.2 |
| 07/19/2026 19:00 | 4,322.3 | 1,134.0 | 5,456.3 | 105,300.0 | 574.5 | 0.69 | 0.3 | 1.1 |
| 07/19/2026 20:00 | 4,335.8 | 1,566.5 | 5,902.3 | 105,300.0 | 621.5 | 0.75 | 0.4 | 1.2 |
| 07/19/2026 21:00 | 4,312.4 | 1,611.8 | 5,924.2 | 105,300.0 | 623.8 | 0.75 | 0.4 | 1.3 |
| 07/19/2026 22:00 | 4,324.7 | 1,546.6 | 5,871.3 | 105,300.0 | 618.2 | 0.74 | 0.4 | 1.2 |
| 07/19/2026 23:00 | 4,354.6 | 1,495.7 | 5,850.3 | 105,300.0 | 616.0 | 0.74 | 0.4 | 1.2 |
| Average/Sum#: | 4,228.6 | 853.9 | 5,082.5 | 105,300.0 | 535.2 | 0.64 | 0.3 | 1.1 |
| Minimum: | 3,841.8 | 240.2 | 4,633.9 | 105,300.0 | 487.9 | 0.59 | 0.3 | 1.0 |
| Maximum: | 4,393.7 | 1,611.8 | 5,924.2 | 105,300.0 | 623.8 | 0.75 | 0.4 | 1.3 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 07/20/2026 00:00 | 4,375.5 | 736.1 | 5,111.6 | 105,300.0 | 538.3 | 0.65 | 0.3 | 1.1 |
| 07/20/2026 01:00 | 4,297.3 | 426.5 | 4,723.8 | 105,300.0 | 497.4 | 0.60 | 0.3 | 1.0 |
| 07/20/2026 02:00 | 4,299.6 | 656.7 | 4,956.3 | 105,300.0 | 521.9 | 0.63 | 0.3 | 1.0 |
| 07/20/2026 03:00 | 4,303.0 | 1,611.6 | 5,914.6 | 105,300.0 | 622.8 | 0.75 | 0.4 | 1.2 |
| 07/20/2026 04:00 | 4,302.2 | 1,707.9 | 6,010.1 | 105,300.0 | 632.9 | 0.76 | 0.4 | 1.3 |
| 07/20/2026 05:00 | 4,316.8 | 1,666.2 | 5,983.0 | 105,300.0 | 630.0 | 0.76 | 0.4 | 1.3 |
| 07/20/2026 06:00 | 4,317.0 | 1,543.6 | 5,860.6 | 105,300.0 | 617.1 | 0.74 | 0.4 | 1.2 |
| 07/20/2026 07:00 | 4,298.9 | 1,436.1 | 5,735.0 | 105,300.0 | 603.9 | 0.73 | 0.4 | 1.2 |
| 07/20/2026 08:00 | 4,277.5 | 1,492.6 | 5,770.1 | 105,300.0 | 607.6 | 0.73 | 0.4 | 1.2 |
| 07/20/2026 09:00 | 4,238.7 | 1,333.5 | 5,572.2 | 105,300.0 | 586.8 | 0.70 | 0.4 | 1.2 |
| 07/20/2026 10:00 | 4,308.4 | 1,531.3 | 5,839.7 | 105,300.0 | 614.9 | 0.74 | 0.4 | 1.2 |
| 07/20/2026 11:00 | 4,332.0 | 1,452.5 | 5,784.5 | 105,300.0 | 609.1 | 0.73 | 0.4 | 1.2 |
| 07/20/2026 12:00 | 4,301.0 | 1,371.9 | 5,672.9 | 105,300.0 | 597.4 | 0.72 | 0.4 | 1.2 |
| 07/20/2026 13:00 | 4,288.1 | 1,579.4 | 5,867.5 | 105,300.0 | 617.8 | 0.74 | 0.4 | 1.2 |
| 07/20/2026 14:00 | 4,271.5 | 1,352.6 | 5,624.1 | 105,300.0 | 592.2 | 0.71 | 0.4 | 1.2 |
| 07/20/2026 15:00 | 4,273.0 | 1,360.3 | 5,633.3 | 105,300.0 | 593.2 | 0.71 | 0.4 | 1.2 |
| 07/20/2026 16:00 | 4,286.4 | 1,435.8 | 5,722.2 | 105,300.0 | 602.5 | 0.72 | 0.4 | 1.2 |
| 07/20/2026 17:00 | 4,293.8 | 1,418.3 | 5,712.1 | 105,300.0 | 601.5 | 0.72 | 0.4 | 1.2 |
| 07/20/2026 18:00 | 4,316.8 | 1,550.2 | 5,867.0 | 105,300.0 | 617.8 | 0.74 | 0.4 | 1.2 |
| 07/20/2026 19:00 | 4,332.2 | 1,425.6 | 5,757.8 | 105,300.0 | 606.3 | 0.73 | 0.4 | 1.2 |
| 07/20/2026 20:00 | 4,316.0 | 1,513.9 | 5,829.9 | 105,300.0 | 613.9 | 0.74 | 0.4 | 1.2 |
| 07/20/2026 21:00 | 4,328.5 | 1,351.8 | 5,680.3 | 105,300.0 | 598.1 | 0.72 | 0.4 | 1.2 |
| 07/20/2026 22:00 | 4,330.0 | 757.2 | 5,087.2 | 105,300.0 | 535.7 | 0.64 | 0.3 | 1.1 |
| 07/20/2026 23:00 | 4,201.1 | 1,023.8 | 5,224.9 | 105,300.0 | 550.2 | 0.66 | 0.3 | 1.1 |
| Average/Sum#: | 4,300.2 | 1,322.3 | 5,622.5 | 105,300.0 | 592.1 | 0.71 | 0.4 | 1.2 |
| Minimum: | 4,201.1 | 426.5 | 4,723.8 | 105,300.0 | 497.4 | 0.60 | 0.3 | 1.0 |
| Maximum: | 4,375.5 | 1,707.9 | 6,010.1 | 105,300.0 | 632.9 | 0.76 | 0.4 | 1.3 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 07/21/2026 00:00 | 4,210.5 | 565.4 | 4,775.9 | 105,300.0 | 502.9 | 0.60 | 0.3 | 1.0 |
| 07/21/2026 01:00 | 4,207.2 | 572.8 | 4,780.0 | 105,300.0 | 503.3 | 0.60 | 0.3 | 1.0 |
| 07/21/2026 02:00 | 4,218.8 | 559.9 | 4,778.7 | 105,300.0 | 503.2 | 0.60 | 0.3 | 1.0 |
| 07/21/2026 03:00 | 4,252.2 | 512.7 | 4,764.9 | 105,300.0 | 501.7 | 0.60 | 0.3 | 1.0 |
| 07/21/2026 04:00 | 4,254.2 | 744.9 | 4,999.1 | 105,300.0 | 526.4 | 0.63 | 0.3 | 1.1 |
| 07/21/2026 05:00 | 4,262.3 | 1,397.3 | 5,659.6 | 105,300.0 | 596.0 | 0.71 | 0.4 | 1.2 |
| 07/21/2026 06:00 | 4,260.5 | 893.1 | 5,153.6 | 105,300.0 | 542.7 | 0.65 | 0.3 | 1.1 |
| 07/21/2026 07:00 | 4,242.5 | 729.3 | 4,971.8 | 105,300.0 | 523.5 | 0.63 | 0.3 | 1.0 |
| 07/21/2026 08:00 | 4,203.8 | 903.8 | 5,107.6 | 105,300.0 | 537.8 | 0.65 | 0.3 | 1.1 |
| 07/21/2026 09:00 | 4,067.8 | 863.7 | 4,931.5 | 105,300.0 | 519.3 | 0.62 | 0.3 | 1.0 |
| 07/21/2026 10:00 | 3,912.1 | 1,127.8 | 5,039.9 | 105,300.0 | 530.7 | 0.64 | 0.3 | 1.1 |
| 07/21/2026 11:00 | 3,983.3 | 1,429.3 | 5,412.6 | 105,300.0 | 569.9 | 0.68 | 0.3 | 1.1 |
| 07/21/2026 12:00 | 4,255.4 | 1,682.0 | 5,937.4 | 105,300.0 | 625.2 | 0.75 | 0.4 | 1.3 |
| 07/21/2026 13:00 | 4,226.6 | 1,613.0 | 5,839.6 | 105,300.0 | 614.9 | 0.74 | 0.4 | 1.2 |
| 07/21/2026 14:00 | 4,228.0 | 1,666.5 | 5,894.5 | 105,300.0 | 620.7 | 0.74 | 0.4 | 1.2 |
| 07/21/2026 15:00 | 4,200.3 | 1,779.7 | 5,980.0 | 105,300.0 | 629.7 | 0.76 | 0.4 | 1.3 |
| 07/21/2026 16:00 | 4,200.9 | 1,661.0 | 5,861.9 | 105,300.0 | 617.3 | 0.74 | 0.4 | 1.2 |
| 07/21/2026 17:00 | 4,198.7 | 1,749.9 | 5,948.6 | 105,300.0 | 626.4 | 0.75 | 0.4 | 1.3 |
| 07/21/2026 18:00 | 4,191.3 | 1,876.6 | 6,067.9 | 105,300.0 | 638.9 | 0.77 | 0.4 | 1.3 |
| 07/21/2026 19:00 | 4,204.2 | 1,842.2 | 6,046.4 | 105,300.0 | 636.7 | 0.76 | 0.4 | 1.3 |
| 07/21/2026 20:00 | 4,253.2 | 1,734.7 | 5,987.9 | 105,300.0 | 630.5 | 0.76 | 0.4 | 1.3 |
| 07/21/2026 21:00 | 4,284.2 | 1,583.3 | 5,867.5 | 105,300.0 | 617.8 | 0.74 | 0.4 | 1.2 |
| 07/21/2026 22:00 | 4,271.3 | 1,452.5 | 5,723.8 | 105,300.0 | 602.7 | 0.72 | 0.4 | 1.2 |
| 07/21/2026 23:00 | 4,296.0 | 1,302.0 | 5,598.0 | 105,300.0 | 589.5 | 0.71 | 0.4 | 1.2 |
| Average/Sum#: | 4,203.6 | 1,260.1 | 5,463.7 | 105,300.0 | 575.3 | 0.69 | 0.4 | 1.2 |
| Minimum: | 3,912.1 | 512.7 | 4,764.9 | 105,300.0 | 501.7 | 0.60 | 0.3 | 1.0 |
| Maximum: | 4,296.0 | 1,876.6 | 6,067.9 | 105,300.0 | 638.9 | 0.77 | 0.4 | 1.3 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 07/22/2026 00:00 | 4,223.1 | 494.1 | 4,717.2 | 105,300.0 | 496.7 | 0.60 | 0.3 | 1.0 |
| 07/22/2026 01:00 | 4,228.9 | 493.4 | 4,722.3 | 105,300.0 | 497.3 | 0.60 | 0.3 | 1.0 |
| 07/22/2026 02:00 | 4,246.1 | 459.9 | 4,706.0 | 105,300.0 | 495.5 | 0.59 | 0.3 | 1.0 |
| 07/22/2026 03:00 | 4,275.6 | 416.0 | 4,691.6 | 105,300.0 | 494.0 | 0.59 | 0.3 | 1.0 |
| 07/22/2026 04:00 | 4,294.0 | 448.9 | 4,742.9 | 105,300.0 | 499.4 | 0.60 | 0.3 | 1.0 |
| 07/22/2026 05:00 | 4,303.7 | 712.1 | 5,015.8 | 105,300.0 | 528.2 | 0.63 | 0.3 | 1.1 |
| 07/22/2026 06:00 | 4,289.1 | 412.5 | 4,701.6 | 105,300.0 | 495.1 | 0.59 | 0.3 | 1.0 |
| 07/22/2026 07:00 | 4,292.2 | 540.1 | 4,832.3 | 105,300.0 | 508.8 | 0.61 | 0.3 | 1.0 |
| 07/22/2026 08:00 | 4,278.9 | 906.3 | 5,185.2 | 105,300.0 | 546.0 | 0.66 | 0.3 | 1.1 |
| 07/22/2026 09:00 | 4,261.5 | 470.8 | 4,732.3 | 105,300.0 | 498.3 | 0.60 | 0.3 | 1.0 |
| 07/22/2026 10:00 | 4,230.8 | 531.2 | 4,762.0 | 105,300.0 | 501.4 | 0.60 | 0.3 | 1.0 |
| 07/22/2026 11:00 | 4,220.5 | 582.3 | 4,802.8 | 105,300.0 | 505.7 | 0.61 | 0.3 | 1.0 |
| 07/22/2026 12:00 | 4,191.3 | 636.9 | 4,828.2 | 105,300.0 | 508.4 | 0.61 | 0.3 | 1.0 |
| 07/22/2026 13:00 | 4,126.2 | 730.5 | 4,856.7 | 105,300.0 | 511.4 | 0.61 | 0.3 | 1.0 |
| 07/22/2026 14:00 | 4,059.4 | 824.2 | 4,883.6 | 105,300.0 | 514.2 | 0.62 | 0.3 | 1.0 |
| 07/22/2026 15:00 | 4,052.1 | 840.1 | 4,892.2 | 105,300.0 | 515.1 | 0.62 | 0.3 | 1.0 |
| 07/22/2026 16:00 | 3,997.4 | 886.4 | 4,883.8 | 105,300.0 | 514.3 | 0.62 | 0.3 | 1.0 |
| 07/22/2026 17:00 | 4,027.8 | 841.1 | 4,868.9 | 105,300.0 | 512.7 | 0.62 | 0.3 | 1.0 |
| 07/22/2026 18:00 | 4,112.8 | 702.8 | 4,815.6 | 105,300.0 | 507.1 | 0.61 | 0.3 | 1.0 |
| 07/22/2026 19:00 | 4,192.5 | 549.7 | 4,742.2 | 105,300.0 | 499.4 | 0.60 | 0.3 | 1.0 |
| 07/22/2026 20:00 | 4,245.1 | 438.9 | 4,684.0 | 105,300.0 | 493.2 | 0.59 | 0.3 | 1.0 |
| 07/22/2026 21:00 | 4,279.3 | 371.1 | 4,650.4 | 105,300.0 | 489.7 | 0.59 | 0.3 | 1.0 |
| 07/22/2026 22:00 | 4,324.4 | 314.9 | 4,639.3 | 105,300.0 | 488.5 | 0.59 | 0.3 | 1.0 |
| 07/22/2026 23:00 | 4,348.4 | 275.8 | 4,624.2 | 105,300.0 | 486.9 | 0.58 | 0.3 | 1.0 |
| Average/Sum#: | 4,212.5 | 578.3 | 4,790.9 | 105,300.0 | 504.5 | 0.61 | 0.3 | 1.0 |
| Minimum: | 3,997.4 | 275.8 | 4,624.2 | 105,300.0 | 486.9 | 0.58 | 0.3 | 1.0 |
| Maximum: | 4,348.4 | 906.3 | 5,185.2 | 105,300.0 | 546.0 | 0.66 | 0.3 | 1.1 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 07/23/2026 00:00 | 4,361.0 | 253.7 | 4,614.7 | 105,300.0 | 485.9 | 0.58 | 0.3 | 1.0 |
| 07/23/2026 01:00 | 4,375.3 | 240.5 | 4,615.8 | 105,300.0 | 486.0 | 0.58 | 0.3 | 1.0 |
| 07/23/2026 02:00 | 4,384.8 | 213.3 | 4,598.1 | 105,300.0 | 484.2 | 0.58 | 0.3 | 1.0 |
| 07/23/2026 03:00 | 4,396.2 | 205.8 | 4,602.0 | 105,300.0 | 484.6 | 0.58 | 0.3 | 1.0 |
| 07/23/2026 04:00 | 4,415.9 | 200.7 | 4,616.6 | 105,300.0 | 486.1 | 0.58 | 0.3 | 1.0 |
| 07/23/2026 05:00 | 4,427.8 | 196.2 | 4,624.0 | 105,300.0 | 486.9 | 0.58 | 0.3 | 1.0 |
| 07/23/2026 06:00 | 4,408.3 | 240.2 | 4,648.5 | 105,300.0 | 489.5 | 0.59 | 0.3 | 1.0 |
| 07/23/2026 07:00 | 4,399.3 | 283.8 | 4,683.1 | 105,300.0 | 493.1 | 0.59 | 0.3 | 1.0 |
| 07/23/2026 08:00 | 4,300.8 | 250.8 | 4,493.9 | 105,300.0 | 473.2 | 0.57 | 0.3 | 1.0 |
| 07/23/2026 09:00 | 3,393.7 | 0.0 | 3,393.7 | 105,300.0 | 357.4 | 0.43 | 0.2 | 0.7 |
| 07/23/2026 10:00 | 3,369.4 | 0.0 | 3,369.4 | 105,300.0 | 354.8 | 0.43 | 0.2 | 0.7 |
| 07/23/2026 11:00 | 4,017.6 | 316.9 | 4,166.5 | 105,300.0 | 438.7 | 0.55 | 0.3 | 0.9 |
| 07/23/2026 12:00 | 4,142.7 | 762.6 | 4,905.3 | 105,300.0 | 516.5 | 0.62 | 0.3 | 1.0 |
| 07/23/2026 13:00 | 4,059.1 | 890.7 | 4,949.8 | 105,300.0 | 521.2 | 0.63 | 0.3 | 1.0 |
| 07/23/2026 14:00 | 3,992.5 | 976.2 | 4,968.7 | 105,300.0 | 523.2 | 0.63 | 0.3 | 1.0 |
| 07/23/2026 15:00 | 3,943.4 | 1,044.0 | 4,987.4 | 105,300.0 | 525.2 | 0.63 | 0.3 | 1.1 |
| 07/23/2026 16:00 | 3,926.6 | 1,070.7 | 4,997.3 | 105,300.0 | 526.2 | 0.63 | 0.3 | 1.1 |
| 07/23/2026 17:00 | 3,925.2 | 1,090.2 | 5,015.4 | 105,300.0 | 528.1 | 0.63 | 0.3 | 1.1 |
| 07/23/2026 18:00 | 3,970.5 | 1,192.4 | 5,162.9 | 105,300.0 | 543.7 | 0.65 | 0.3 | 1.1 |
| 07/23/2026 19:00 | 4,132.3 | 765.2 | 4,897.5 | 105,300.0 | 515.7 | 0.62 | 0.3 | 1.0 |
| 07/23/2026 20:00 | 4,198.7 | 806.3 | 5,005.0 | 105,300.0 | 527.0 | 0.63 | 0.3 | 1.1 |
| 07/23/2026 21:00 | 4,223.5 | 526.3 | 4,749.8 | 105,300.0 | 500.2 | 0.60 | 0.3 | 1.0 |
| 07/23/2026 22:00 | 4,277.1 | 484.0 | 4,761.1 | 105,300.0 | 501.3 | 0.60 | 0.3 | 1.0 |
| 07/23/2026 23:00 | 4,315.7 | 463.0 | 4,778.7 | 105,300.0 | 503.2 | 0.60 | 0.3 | 1.0 |
| Average/Sum#: | 4,139.9 | 519.7 | 4,650.2 | 105,300.0 | 489.7 | 0.59 | 0.3 | 1.0 |
| Minimum: | 3,369.4 | 0.0 | 3,369.4 | 105,300.0 | 354.8 | 0.43 | 0.2 | 0.7 |
| Maximum: | 4,427.8 | 1,192.4 | 5,162.9 | 105,300.0 | 543.7 | 0.65 | 0.3 | 1.1 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 07/24/2026 00:00 | 4,340.4 | 332.4 | 4,672.8 | 105,300.0 | 492.0 | 0.59 | 0.3 | 1.0 |
| 07/24/2026 01:00 | 4,357.6 | 309.5 | 4,667.1 | 105,300.0 | 491.4 | 0.59 | 0.3 | 1.0 |
| 07/24/2026 02:00 | 4,362.6 | 296.0 | 4,658.6 | 105,300.0 | 490.6 | 0.59 | 0.3 | 1.0 |
| 07/24/2026 03:00 | 4,379.4 | 271.2 | 4,650.6 | 105,300.0 | 489.7 | 0.59 | 0.3 | 1.0 |
| 07/24/2026 04:00 | 4,397.5 | 235.5 | 4,633.0 | 105,300.0 | 487.9 | 0.59 | 0.3 | 1.0 |
| 07/24/2026 05:00 | 4,414.8 | 229.2 | 4,644.0 | 105,300.0 | 489.0 | 0.59 | 0.3 | 1.0 |
| 07/24/2026 06:00 | 4,394.7 | 276.9 | 4,671.6 | 105,300.0 | 491.9 | 0.59 | 0.3 | 1.0 |
| 07/24/2026 07:00 | 4,368.3 | 344.8 | 4,713.1 | 105,300.0 | 496.3 | 0.60 | 0.3 | 1.0 |
| 07/24/2026 08:00 | 4,313.1 | 432.8 | 4,745.9 | 105,300.0 | 499.7 | 0.60 | 0.3 | 1.0 |
| 07/24/2026 09:00 | 4,259.8 | 524.8 | 4,784.6 | 105,300.0 | 503.8 | 0.60 | 0.3 | 1.0 |
| 07/24/2026 10:00 | 4,210.6 | 617.4 | 4,828.0 | 105,300.0 | 508.4 | 0.61 | 0.3 | 1.0 |
| 07/24/2026 11:00 | 3,442.6 | 9.1 | 3,442.9 | 105,300.0 | 362.5 | 0.44 | 0.2 | 0.7 |
| 07/24/2026 12:00 | 4,006.0 | 529.3 | 4,350.0 | 105,300.0 | 458.1 | 0.57 | 0.3 | 1.0 |
| 07/24/2026 13:00 | 4,056.4 | 1,481.8 | 5,538.2 | 105,300.0 | 583.2 | 0.70 | 0.3 | 1.2 |
| 07/24/2026 14:00 | 4,264.8 | 1,730.9 | 5,995.7 | 105,300.0 | 631.3 | 0.76 | 0.4 | 1.3 |
| 07/24/2026 15:00 | 4,259.6 | 1,708.1 | 5,967.7 | 105,300.0 | 628.4 | 0.75 | 0.4 | 1.3 |
| 07/24/2026 16:00 | 4,209.2 | 1,164.8 | 5,374.0 | 105,300.0 | 565.9 | 0.68 | 0.3 | 1.1 |
| 07/24/2026 17:00 | 4,269.4 | 1,252.0 | 5,521.4 | 105,300.0 | 581.4 | 0.70 | 0.3 | 1.2 |
| 07/24/2026 18:00 | 4,293.9 | 1,344.0 | 5,637.9 | 105,300.0 | 593.7 | 0.71 | 0.4 | 1.2 |
| 07/24/2026 19:00 | 4,309.0 | 658.7 | 4,967.7 | 105,300.0 | 523.1 | 0.63 | 0.3 | 1.0 |
| 07/24/2026 20:00 | 4,342.7 | 641.0 | 4,983.7 | 105,300.0 | 524.8 | 0.63 | 0.3 | 1.0 |
| 07/24/2026 21:00 | 4,367.4 | 427.8 | 4,795.2 | 105,300.0 | 504.9 | 0.61 | 0.3 | 1.0 |
| 07/24/2026 22:00 | 4,361.3 | 293.3 | 4,654.6 | 105,300.0 | 490.1 | 0.59 | 0.3 | 1.0 |
| 07/24/2026 23:00 | 4,331.0 | 357.3 | 4,688.3 | 105,300.0 | 493.7 | 0.59 | 0.3 | 1.0 |
| Average/Sum#: | 4,263.0 | 644.5 | 4,899.4 | 105,300.0 | 515.9 | 0.62 | 0.3 | 1.0 |
| Minimum: | 3,442.6 | 9.1 | 3,442.9 | 105,300.0 | 362.5 | 0.44 | 0.2 | 0.7 |
| Maximum: | 4,414.8 | 1,730.9 | 5,995.7 | 105,300.0 | 631.3 | 0.76 | 0.4 | 1.3 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 07/25/2026 00:00 | 4,351.2 | 324.5 | 4,675.7 | 105,300.0 | 492.4 | 0.59 | 0.3 | 1.0 |
| 07/25/2026 01:00 | 4,368.3 | 296.2 | 4,664.5 | 105,300.0 | 491.2 | 0.59 | 0.3 | 1.0 |
| 07/25/2026 02:00 | 4,379.2 | 279.3 | 4,658.5 | 105,300.0 | 490.5 | 0.59 | 0.3 | 1.0 |
| 07/25/2026 03:00 | 4,379.3 | 271.6 | 4,650.9 | 105,300.0 | 489.7 | 0.59 | 0.3 | 1.0 |
| 07/25/2026 04:00 | 4,393.2 | 246.5 | 4,639.7 | 105,300.0 | 488.6 | 0.59 | 0.3 | 1.0 |
| 07/25/2026 05:00 | 4,416.4 | 222.4 | 4,638.8 | 105,300.0 | 488.5 | 0.59 | 0.3 | 1.0 |
| 07/25/2026 06:00 | 4,403.7 | 270.9 | 4,674.6 | 105,300.0 | 492.2 | 0.59 | 0.3 | 1.0 |
| 07/25/2026 07:00 | 4,366.0 | 347.8 | 4,713.8 | 105,300.0 | 496.4 | 0.60 | 0.3 | 1.0 |
| 07/25/2026 08:00 | 4,316.0 | 421.3 | 4,737.3 | 105,300.0 | 498.8 | 0.60 | 0.3 | 1.0 |
| 07/25/2026 09:00 | 4,257.1 | 526.5 | 4,783.6 | 105,300.0 | 503.7 | 0.61 | 0.3 | 1.0 |
| 07/25/2026 10:00 | 4,201.9 | 631.8 | 4,833.7 | 105,300.0 | 509.0 | 0.61 | 0.3 | 1.0 |
| 07/25/2026 11:00 | 4,118.5 | 791.8 | 4,910.3 | 105,300.0 | 517.1 | 0.62 | 0.3 | 1.0 |
| 07/25/2026 12:00 | 4,005.5 | 981.7 | 4,987.2 | 105,300.0 | 525.2 | 0.63 | 0.3 | 1.1 |
| 07/25/2026 13:00 | 3,942.1 | 1,091.7 | 5,033.8 | 105,300.0 | 530.1 | 0.64 | 0.3 | 1.1 |
| 07/25/2026 14:00 | 3,880.0 | 1,181.6 | 5,061.6 | 105,300.0 | 533.0 | 0.64 | 0.3 | 1.1 |
| 07/25/2026 15:00 | 3,822.2 | 1,247.0 | 5,069.2 | 105,300.0 | 533.8 | 0.64 | 0.3 | 1.1 |
| 07/25/2026 16:00 | 3,787.1 | 1,307.7 | 5,094.8 | 105,300.0 | 536.5 | 0.64 | 0.3 | 1.1 |
| 07/25/2026 17:00 | 3,812.8 | 1,269.4 | 5,082.2 | 105,300.0 | 535.2 | 0.64 | 0.3 | 1.1 |
| 07/25/2026 18:00 | 3,932.2 | 1,060.2 | 4,992.4 | 105,300.0 | 525.7 | 0.63 | 0.3 | 1.1 |
| 07/25/2026 19:00 | 4,062.0 | 809.9 | 4,871.9 | 105,300.0 | 513.0 | 0.62 | 0.3 | 1.0 |
| 07/25/2026 20:00 | 4,154.3 | 634.5 | 4,788.8 | 105,300.0 | 504.3 | 0.61 | 0.3 | 1.0 |
| 07/25/2026 21:00 | 4,188.6 | 554.2 | 4,742.8 | 105,300.0 | 499.4 | 0.60 | 0.3 | 1.0 |
| 07/25/2026 22:00 | 4,229.3 | 493.0 | 4,722.3 | 105,300.0 | 497.3 | 0.60 | 0.3 | 1.0 |
| 07/25/2026 23:00 | 4,265.1 | 438.2 | 4,703.3 | 105,300.0 | 495.3 | 0.59 | 0.3 | 1.0 |
| Average/Sum#: | 4,168.0 | 654.2 | 4,822.2 | 105,300.0 | 507.8 | 0.61 | 0.3 | 1.0 |
| Minimum: | 3,787.1 | 222.4 | 4,638.8 | 105,300.0 | 488.5 | 0.59 | 0.3 | 1.0 |
| Maximum: | 4,416.4 | 1,307.7 | 5,094.8 | 105,300.0 | 536.5 | 0.64 | 0.3 | 1.1 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 07/26/2026 00:00 | 4,302.5 | 396.5 | 4,699.0 | 105,300.0 | 494.8 | 0.59 | 0.3 | 1.0 |
| 07/26/2026 01:00 | 4,326.5 | 352.7 | 4,679.2 | 105,300.0 | 492.7 | 0.59 | 0.3 | 1.0 |
| 07/26/2026 02:00 | 4,346.9 | 306.9 | 4,653.8 | 105,300.0 | 490.0 | 0.59 | 0.3 | 1.0 |
| 07/26/2026 03:00 | 4,371.9 | 273.1 | 4,645.0 | 105,300.0 | 489.1 | 0.59 | 0.3 | 1.0 |
| 07/26/2026 04:00 | 4,387.7 | 255.3 | 4,643.0 | 105,300.0 | 488.9 | 0.59 | 0.3 | 1.0 |
| 07/26/2026 05:00 | 4,395.6 | 245.8 | 4,641.4 | 105,300.0 | 488.7 | 0.59 | 0.3 | 1.0 |
| 07/26/2026 06:00 | 4,386.9 | 273.8 | 4,655.2 | 105,300.0 | 490.2 | 0.59 | 0.3 | 1.0 |
| 07/26/2026 07:00 | 3,435.3 | 0.0 | 3,435.3 | 105,300.0 | 361.7 | 0.44 | 0.2 | 0.7 |
| 07/26/2026 08:00 | 4,075.6 | 205.9 | 4,174.4 | 105,300.0 | 439.6 | 0.54 | 0.3 | 0.9 |
| 07/26/2026 09:00 | 4,258.8 | 515.1 | 4,773.9 | 105,300.0 | 502.7 | 0.60 | 0.3 | 1.0 |
| 07/26/2026 10:00 | 4,206.8 | 613.3 | 4,820.1 | 105,300.0 | 507.6 | 0.61 | 0.3 | 1.0 |
| 07/26/2026 11:00 | 4,155.5 | 718.7 | 4,874.2 | 105,300.0 | 513.3 | 0.62 | 0.3 | 1.0 |
| 07/26/2026 12:00 | 4,031.4 | 927.2 | 4,958.6 | 105,300.0 | 522.1 | 0.63 | 0.3 | 1.0 |
| 07/26/2026 13:00 | 3,946.9 | 1,071.8 | 5,018.7 | 105,300.0 | 528.5 | 0.63 | 0.3 | 1.1 |
| 07/26/2026 14:00 | 3,890.0 | 1,164.9 | 5,054.9 | 105,300.0 | 532.3 | 0.64 | 0.3 | 1.1 |
| 07/26/2026 15:00 | 3,845.6 | 1,211.2 | 5,056.8 | 105,300.0 | 532.5 | 0.64 | 0.3 | 1.1 |
| 07/26/2026 16:00 | 3,831.8 | 1,228.6 | 5,060.4 | 105,300.0 | 532.9 | 0.64 | 0.3 | 1.1 |
| 07/26/2026 17:00 | 3,835.9 | 1,209.8 | 5,045.7 | 105,300.0 | 531.3 | 0.64 | 0.3 | 1.1 |
| 07/26/2026 18:00 | 3,994.7 | 954.6 | 4,949.3 | 105,300.0 | 521.2 | 0.63 | 0.3 | 1.0 |
| 07/26/2026 19:00 | 4,097.9 | 739.6 | 4,837.5 | 105,300.0 | 509.4 | 0.61 | 0.3 | 1.0 |
| 07/26/2026 20:00 | 4,188.3 | 654.8 | 4,843.1 | 105,300.0 | 510.0 | 0.61 | 0.3 | 1.0 |
| 07/26/2026 21:00 | 4,244.2 | 1,026.6 | 5,270.8 | 105,300.0 | 555.0 | 0.67 | 0.3 | 1.1 |
| 07/26/2026 22:00 | 4,283.4 | 946.9 | 5,230.3 | 105,300.0 | 550.8 | 0.66 | 0.3 | 1.1 |
| 07/26/2026 23:00 | 4,321.7 | 351.7 | 4,673.4 | 105,300.0 | 492.1 | 0.59 | 0.3 | 1.0 |
| Average/Sum#: | 4,131.7 | 651.9 | 4,778.9 | 105,300.0 | 503.2 | 0.61 | 0.3 | 1.0 |
| Minimum: | 3,435.3 | 0.0 | 3,435.3 | 105,300.0 | 361.7 | 0.44 | 0.2 | 0.7 |
| Maximum: | 4,395.6 | 1,228.6 | 5,270.8 | 105,300.0 | 555.0 | 0.67 | 0.3 | 1.1 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 07/27/2026 00:00 | 4,340.7 | 469.7 | 4,810.4 | 105,300.0 | 506.5 | 0.61 | 0.3 | 1.0 |
| 07/27/2026 01:00 | 4,364.6 | 273.1 | 4,637.7 | 105,300.0 | 488.3 | 0.59 | 0.3 | 1.0 |
| 07/27/2026 02:00 | 4,382.1 | 243.2 | 4,625.3 | 105,300.0 | 487.0 | 0.58 | 0.3 | 1.0 |
| 07/27/2026 03:00 | 4,391.4 | 231.5 | 4,622.9 | 105,300.0 | 486.8 | 0.58 | 0.3 | 1.0 |
| 07/27/2026 04:00 | 4,407.0 | 204.4 | 4,611.4 | 105,300.0 | 485.6 | 0.58 | 0.3 | 1.0 |
| 07/27/2026 05:00 | 4,411.7 | 189.3 | 4,601.0 | 105,300.0 | 484.5 | 0.58 | 0.3 | 1.0 |
| 07/27/2026 06:00 | 4,406.5 | 229.1 | 4,635.6 | 105,300.0 | 488.1 | 0.59 | 0.3 | 1.0 |
| 07/27/2026 07:00 | 4,380.1 | 296.5 | 4,676.6 | 105,300.0 | 492.4 | 0.59 | 0.3 | 1.0 |
| 07/27/2026 08:00 | 4,325.7 | 379.5 | 4,705.2 | 105,300.0 | 495.5 | 0.59 | 0.3 | 1.0 |
| 07/27/2026 09:00 | 4,278.5 | 473.5 | 4,752.0 | 105,300.0 | 500.4 | 0.60 | 0.3 | 1.0 |
| 07/27/2026 10:00 | 4,227.0 | 560.7 | 4,787.7 | 105,300.0 | 504.1 | 0.60 | 0.3 | 1.0 |
| 07/27/2026 11:00 | 4,172.7 | 697.1 | 4,869.8 | 105,300.0 | 512.8 | 0.62 | 0.3 | 1.0 |
| 07/27/2026 12:00 | 4,078.3 | 868.7 | 4,947.0 | 105,300.0 | 520.9 | 0.63 | 0.3 | 1.0 |
| 07/27/2026 13:00 | 4,000.7 | 998.4 | 4,999.1 | 105,300.0 | 526.4 | 0.63 | 0.3 | 1.1 |
| 07/27/2026 14:00 | 3,947.9 | 1,081.3 | 5,029.2 | 105,300.0 | 529.6 | 0.64 | 0.3 | 1.1 |
| 07/27/2026 15:00 | 3,900.7 | 1,132.9 | 5,033.6 | 105,300.0 | 530.0 | 0.64 | 0.3 | 1.1 |
| 07/27/2026 16:00 | 3,868.7 | 1,181.6 | 5,050.3 | 105,300.0 | 531.8 | 0.64 | 0.3 | 1.1 |
| 07/27/2026 17:00 | 3,987.5 | 1,071.4 | 5,058.9 | 105,300.0 | 532.7 | 0.64 | 0.3 | 1.1 |
| 07/27/2026 18:00 | 4,286.8 | 1,013.4 | 5,300.2 | 105,300.0 | 558.1 | 0.67 | 0.3 | 1.1 |
| 07/27/2026 19:00 | 4,313.2 | 1,045.2 | 5,358.4 | 105,300.0 | 564.2 | 0.68 | 0.3 | 1.1 |
| 07/27/2026 20:00 | 4,344.3 | 696.1 | 5,040.4 | 105,300.0 | 530.8 | 0.64 | 0.3 | 1.1 |
| 07/27/2026 21:00 | 4,305.5 | 411.3 | 4,716.8 | 105,300.0 | 496.7 | 0.60 | 0.3 | 1.0 |
| 07/27/2026 22:00 | 4,276.4 | 420.5 | 4,696.9 | 105,300.0 | 494.6 | 0.59 | 0.3 | 1.0 |
| 07/27/2026 23:00 | 4,305.4 | 376.4 | 4,681.8 | 105,300.0 | 493.0 | 0.59 | 0.3 | 1.0 |
| Average/Sum#: | 4,237.6 | 606.0 | 4,843.7 | 105,300.0 | 510.0 | 0.61 | 0.3 | 1.0 |
| Minimum: | 3,868.7 | 189.3 | 4,601.0 | 105,300.0 | 484.5 | 0.58 | 0.3 | 1.0 |
| Maximum: | 4,411.7 | 1,181.6 | 5,358.4 | 105,300.0 | 564.2 | 0.68 | 0.3 | 1.1 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 07/28/2026 00:00 | 4,336.3 | 338.6 | 4,674.9 | 105,300.0 | 492.3 | 0.59 | 0.3 | 1.0 |
| 07/28/2026 01:00 | 4,352.0 | 298.8 | 4,650.8 | 105,300.0 | 489.7 | 0.59 | 0.3 | 1.0 |
| 07/28/2026 02:00 | 4,375.8 | 278.9 | 4,654.7 | 105,300.0 | 490.1 | 0.59 | 0.3 | 1.0 |
| 07/28/2026 03:00 | 4,384.0 | 257.1 | 4,641.1 | 105,300.0 | 488.7 | 0.59 | 0.3 | 1.0 |
| 07/28/2026 04:00 | 4,391.5 | 250.1 | 4,641.6 | 105,300.0 | 488.8 | 0.59 | 0.3 | 1.0 |
| 07/28/2026 05:00 | 4,409.9 | 224.3 | 4,634.2 | 105,300.0 | 488.0 | 0.59 | 0.3 | 1.0 |
| 07/28/2026 06:00 | 4,402.1 | 258.1 | 4,660.2 | 105,300.0 | 490.7 | 0.59 | 0.3 | 1.0 |
| 07/28/2026 07:00 | 3,818.1 | 46.3 | 3,826.4 | 105,300.0 | 402.9 | 0.49 | 0.2 | 0.8 |
| 07/28/2026 08:00 | 3,377.5 | 0.0 | 3,377.5 | 105,300.0 | 355.7 | 0.43 | 0.2 | 0.7 |
| 07/28/2026 09:00 | 3,375.1 | 0.0 | 3,375.1 | 105,300.0 | 355.4 | 0.43 | 0.2 | 0.7 |
| 07/28/2026 10:00 | 3,371.0 | 0.0 | 3,371.0 | 105,300.0 | 355.0 | 0.43 | 0.2 | 0.7 |
| 07/28/2026 11:00 | 3,620.7 | 3.1 | 3,620.8 | 105,300.0 | 381.3 | 0.46 | 0.2 | 0.8 |
| 07/28/2026 12:00 | 4,116.0 | 578.5 | 4,578.8 | 105,300.0 | 482.1 | 0.59 | 0.3 | 1.0 |
| 07/28/2026 13:00 | 3,400.3 | 0.0 | 3,400.3 | 105,300.0 | 358.1 | 0.43 | 0.2 | 0.7 |
| 07/28/2026 14:00 | 3,382.9 | 0.0 | 3,382.9 | 105,300.0 | 356.2 | 0.43 | 0.2 | 0.7 |
| 07/28/2026 15:00 | 3,610.7 | 3.1 | 3,610.8 | 105,300.0 | 380.2 | 0.46 | 0.2 | 0.8 |
| 07/28/2026 16:00 | 4,227.4 | 574.9 | 4,802.3 | 105,300.0 | 505.7 | 0.61 | 0.3 | 1.0 |
| 07/28/2026 17:00 | 4,257.3 | 562.9 | 4,820.2 | 105,300.0 | 507.6 | 0.61 | 0.3 | 1.0 |
| 07/28/2026 18:00 | 4,012.0 | 941.3 | 4,953.3 | 105,300.0 | 521.6 | 0.63 | 0.3 | 1.0 |
| 07/28/2026 19:00 | 4,051.6 | 846.3 | 4,897.9 | 105,300.0 | 515.7 | 0.62 | 0.3 | 1.0 |
| 07/28/2026 20:00 | 4,160.9 | 659.5 | 4,820.4 | 105,300.0 | 507.6 | 0.61 | 0.3 | 1.0 |
| 07/28/2026 21:00 | 4,149.0 | 629.9 | 4,778.9 | 105,300.0 | 503.2 | 0.60 | 0.3 | 1.0 |
| 07/28/2026 22:00 | 4,189.0 | 557.0 | 4,746.0 | 105,300.0 | 499.8 | 0.60 | 0.3 | 1.0 |
| 07/28/2026 23:00 | 3,443.3 | 6.2 | 3,443.5 | 105,300.0 | 362.6 | 0.43 | 0.2 | 0.7 |
| Average/Sum#: | 3,967.3 | 304.8 | 4,265.2 | 105,300.0 | 449.1 | 0.54 | 0.3 | 0.9 |
| Minimum: | 3,371.0 | 0.0 | 3,371.0 | 105,300.0 | 355.0 | 0.43 | 0.2 | 0.7 |
| Maximum: | 4,409.9 | 941.3 | 4,953.3 | 105,300.0 | 521.6 | 0.63 | 0.3 | 1.0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 07/29/2026 00:00 | 3,359.7 | 0.0 | 3,359.7 | 105,300.0 | 353.8 | 0.42 | 0.2 | 0.7 |
| 07/29/2026 01:00 | 3,361.3 | 0.0 | 3,361.3 | 105,300.0 | 353.9 | 0.42 | 0.2 | 0.7 |
| 07/29/2026 02:00 | 3,365.3 | 0.0 | 3,365.3 | 105,300.0 | 354.4 | 0.43 | 0.2 | 0.7 |
| 07/29/2026 03:00 | 3,369.4 | 0.0 | 3,369.4 | 105,300.0 | 354.8 | 0.43 | 0.2 | 0.7 |
| 07/29/2026 04:00 | 3,368.3 | 0.0 | 3,368.3 | 105,300.0 | 354.7 | 0.43 | 0.2 | 0.7 |
| 07/29/2026 05:00 | 3,368.7 | 0.0 | 3,368.7 | 105,300.0 | 354.7 | 0.43 | 0.2 | 0.7 |
| 07/29/2026 06:00 | 3,369.3 | 0.0 | 3,369.3 | 105,300.0 | 354.8 | 0.43 | 0.2 | 0.7 |
| 07/29/2026 07:00 | 3,373.1 | 0.0 | 3,373.1 | 105,300.0 | 355.2 | 0.43 | 0.2 | 0.7 |
| 07/29/2026 08:00 | 3,364.6 | 0.0 | 3,364.6 | 105,300.0 | 354.3 | 0.43 | 0.2 | 0.7 |
| 07/29/2026 09:00 | 3,366.3 | 0.0 | 3,366.3 | 105,300.0 | 354.5 | 0.43 | 0.2 | 0.7 |
| 07/29/2026 10:00 | 3,599.3 | 3.1 | 3,599.4 | 105,300.0 | 379.0 | 0.46 | 0.2 | 0.8 |
| 07/29/2026 11:00 | 4,102.9 | 835.7 | 4,938.6 | 105,300.0 | 520.0 | 0.62 | 0.3 | 1.0 |
| 07/29/2026 12:00 | 3,961.2 | 1,022.8 | 4,984.0 | 105,300.0 | 524.8 | 0.63 | 0.3 | 1.0 |
| 07/29/2026 13:00 | 3,838.5 | 1,210.1 | 5,048.6 | 105,300.0 | 531.6 | 0.64 | 0.3 | 1.1 |
| 07/29/2026 14:00 | 3,797.5 | 1,275.8 | 5,073.3 | 105,300.0 | 534.2 | 0.64 | 0.3 | 1.1 |
| 07/29/2026 15:00 | 3,759.1 | 1,341.7 | 5,100.8 | 105,300.0 | 537.1 | 0.64 | 0.3 | 1.1 |
| 07/29/2026 16:00 | 3,754.8 | 1,353.3 | 5,108.1 | 105,300.0 | 537.9 | 0.65 | 0.3 | 1.1 |
| 07/29/2026 17:00 | 3,764.6 | 1,373.5 | 5,138.1 | 105,300.0 | 541.0 | 0.65 | 0.3 | 1.1 |
| 07/29/2026 18:00 | 3,850.8 | 1,294.7 | 5,145.5 | 105,300.0 | 541.8 | 0.65 | 0.3 | 1.1 |
| 07/29/2026 19:00 | 3,891.6 | 1,048.8 | 4,940.4 | 105,300.0 | 520.2 | 0.62 | 0.3 | 1.0 |
| 07/29/2026 20:00 | 4,058.9 | 770.3 | 4,829.2 | 105,300.0 | 508.5 | 0.61 | 0.3 | 1.0 |
| 07/29/2026 21:00 | 3,437.1 | 15.2 | 3,438.2 | 105,300.0 | 362.0 | 0.43 | 0.2 | 0.7 |
| 07/29/2026 22:00 | 3,354.0 | 0.0 | 3,354.0 | 105,300.0 | 353.2 | 0.42 | 0.2 | 0.7 |
| 07/29/2026 23:00 | 3,358.6 | 0.0 | 3,358.6 | 105,300.0 | 353.7 | 0.42 | 0.2 | 0.7 |
| Average/Sum#: | 3,591.5 | 481.0 | 4,071.8 | 105,300.0 | 428.8 | 0.52 | 0.2 | 0.9 |
| Minimum: | 3,354.0 | 0.0 | 3,354.0 | 105,300.0 | 353.2 | 0.42 | 0.2 | 0.7 |
| Maximum: | 4,102.9 | 1,373.5 | 5,145.5 | 105,300.0 | 541.8 | 0.65 | 0.3 | 1.1 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 07/30/2026 00:00 | 3,362.1 | 0.0 | 3,362.1 | 105,300.0 | 354.0 | 0.42 | 0.2 | 0.7 |
| 07/30/2026 01:00 | 3,361.8 | 0.0 | 3,361.8 | 105,300.0 | 354.0 | 0.42 | 0.2 | 0.7 |
| 07/30/2026 02:00 | 3,362.1 | 0.0 | 3,362.1 | 105,300.0 | 354.0 | 0.42 | 0.2 | 0.7 |
| 07/30/2026 03:00 | 3,365.3 | 0.0 | 3,365.3 | 105,300.0 | 354.4 | 0.43 | 0.2 | 0.7 |
| 07/30/2026 04:00 | 3,366.2 | 0.0 | 3,366.2 | 105,300.0 | 354.5 | 0.43 | 0.2 | 0.7 |
| 07/30/2026 05:00 | 3,365.1 | 0.0 | 3,365.1 | 105,300.0 | 354.3 | 0.43 | 0.2 | 0.7 |
| 07/30/2026 06:00 | 3,366.4 | 0.0 | 3,366.4 | 105,300.0 | 354.5 | 0.43 | 0.2 | 0.7 |
| 07/30/2026 07:00 | 3,372.3 | 0.0 | 3,372.3 | 105,300.0 | 355.1 | 0.43 | 0.2 | 0.7 |
| 07/30/2026 08:00 | 3,360.3 | 0.0 | 3,360.3 | 105,300.0 | 353.8 | 0.42 | 0.2 | 0.7 |
| 07/30/2026 09:00 | 3,358.5 | 0.0 | 3,358.5 | 105,300.0 | 353.7 | 0.42 | 0.2 | 0.7 |
| 07/30/2026 10:00 | 3,357.4 | 0.0 | 3,357.4 | 105,300.0 | 353.5 | 0.42 | 0.2 | 0.7 |
| 07/30/2026 11:00 | 3,364.2 | 0.0 | 3,364.2 | 105,300.0 | 354.3 | 0.43 | 0.2 | 0.7 |
| 07/30/2026 12:00 | 3,365.9 | 0.0 | 3,365.9 | 105,300.0 | 354.4 | 0.43 | 0.2 | 0.7 |
| 07/30/2026 13:00 | 3,369.0 | 0.0 | 3,369.0 | 105,300.0 | 354.8 | 0.43 | 0.2 | 0.7 |
| 07/30/2026 14:00 | 3,734.1 | 0.0 | 3,734.1 | 105,300.0 | 393.2 | 0.47 | 0.2 | 0.8 |
| 07/30/2026 15:00 | 3,379.7 | 0.0 | 3,379.7 | 105,300.0 | 355.9 | 0.43 | 0.2 | 0.7 |
| 07/30/2026 16:00 | 3,501.3 | 0.0 | 3,501.3 | 105,300.0 | 368.7 | 0.44 | 0.2 | 0.7 |
| 07/30/2026 17:00 | 3,802.5 | 0.0 | 3,802.5 | 105,300.0 | 400.4 | 0.48 | 0.2 | 0.8 |
| 07/30/2026 18:00 | 4,097.9 | 0.0 | 4,097.9 | 105,300.0 | 431.5 | 0.52 | 0.3 | 0.9 |
| 07/30/2026 19:00 | 3,517.9 | 0.0 | 3,517.9 | 105,300.0 | 370.4 | 0.44 | 0.2 | 0.7 |
| 07/30/2026 20:00 | 3,338.2 | 0.0 | 3,338.2 | 105,300.0 | 351.5 | 0.42 | 0.2 | 0.7 |
| 07/30/2026 21:00 | 3,414.5 | 0.0 | 3,414.5 | 105,300.0 | 359.5 | 0.43 | 0.2 | 0.7 |
| 07/30/2026 22:00 | 3,514.4 | 0.0 | 3,514.4 | 105,300.0 | 370.1 | 0.44 | 0.2 | 0.7 |
| 07/30/2026 23:00 | 3,366.2 | 0.0 | 3,366.2 | 105,300.0 | 354.5 | 0.42 | 0.2 | 0.7 |
| Average/Sum#: | 3,448.5 | 0.0 | 3,448.5 | 105,300.0 | 363.1 | 0.44 | 0.2 | 0.7 |
| Minimum: | 3,338.2 | 0.0 | 3,338.2 | 105,300.0 | 351.5 | 0.42 | 0.2 | 0.7 |
| Maximum: | 4,097.9 | 0.0 | 4,097.9 | 105,300.0 | 431.5 | 0.52 | 0.3 | 0.9 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 07/31/2026 00:00 | 3,348.1 | 0.0 | 3,348.1 | 105,300.0 | 352.6 | 0.42 | 0.2 | 0.7 |
| 07/31/2026 01:00 | 3,356.9 | 0.0 | 3,356.9 | 105,300.0 | 353.5 | 0.42 | 0.2 | 0.7 |
| 07/31/2026 02:00 | 3,363.2 | 0.0 | 3,363.2 | 105,300.0 | 354.1 | 0.43 | 0.2 | 0.7 |
| 07/31/2026 03:00 | 3,367.7 | 0.0 | 3,367.7 | 105,300.0 | 354.6 | 0.43 | 0.2 | 0.7 |
| 07/31/2026 04:00 | 3,544.8 | 0.0 | 3,544.8 | 105,300.0 | 373.3 | 0.45 | 0.2 | 0.7 |
| 07/31/2026 05:00 | 3,373.8 | 0.0 | 3,373.8 | 105,300.0 | 355.3 | 0.43 | 0.2 | 0.7 |
| 07/31/2026 06:00 | 3,371.7 | 0.0 | 3,371.7 | 105,300.0 | 355.0 | 0.43 | 0.2 | 0.7 |
| 07/31/2026 07:00 | 3,378.1 | 0.0 | 3,378.1 | 105,300.0 | 355.7 | 0.43 | 0.2 | 0.7 |
| 07/31/2026 08:00 | 3,368.7 | 0.0 | 3,368.7 | 105,300.0 | 354.7 | 0.43 | 0.2 | 0.7 |
| 07/31/2026 09:00 | 3,365.2 | 0.0 | 3,365.2 | 105,300.0 | 354.4 | 0.43 | 0.2 | 0.7 |
| 07/31/2026 10:00 | 3,363.3 | 0.0 | 3,363.3 | 105,300.0 | 354.2 | 0.43 | 0.2 | 0.7 |
| 07/31/2026 11:00 | 3,499.9 | 0.0 | 3,499.9 | 105,300.0 | 368.5 | 0.45 | 0.2 | 0.7 |
| 07/31/2026 12:00 | 4,145.1 | 0.0 | 4,145.1 | 105,300.0 | 436.5 | 0.52 | 0.3 | 0.9 |
| 07/31/2026 13:00 | 4,134.8 | 0.0 | 4,134.8 | 105,300.0 | 435.4 | 0.52 | 0.3 | 0.9 |
| 07/31/2026 14:00 | 4,136.6 | 3.7 | 4,136.7 | 105,300.0 | 435.6 | 0.52 | 0.3 | 0.9 |
| 07/31/2026 15:00 | 4,255.5 | 757.1 | 5,012.6 | 105,300.0 | 527.8 | 0.63 | 0.3 | 1.1 |
| 07/31/2026 16:00 | 4,250.8 | 1,011.5 | 5,262.3 | 105,300.0 | 554.1 | 0.66 | 0.3 | 1.1 |
| 07/31/2026 17:00 | 4,257.6 | 1,325.2 | 5,582.8 | 105,300.0 | 587.9 | 0.70 | 0.4 | 1.2 |
| 07/31/2026 18:00 | 4,259.3 | 1,756.3 | 6,015.6 | 105,300.0 | 633.4 | 0.76 | 0.4 | 1.3 |
| 07/31/2026 19:00 | 4,280.6 | 616.6 | 4,897.2 | 105,300.0 | 515.7 | 0.62 | 0.3 | 1.0 |
| 07/31/2026 20:00 | 4,056.9 | 767.9 | 4,824.8 | 105,300.0 | 508.1 | 0.61 | 0.3 | 1.0 |
| 07/31/2026 21:00 | 4,079.3 | 705.1 | 4,784.4 | 105,300.0 | 503.8 | 0.61 | 0.3 | 1.0 |
| 07/31/2026 22:00 | 4,165.3 | 572.9 | 4,738.2 | 105,300.0 | 498.9 | 0.60 | 0.3 | 1.0 |
| 07/31/2026 23:00 | 3,438.0 | 5.4 | 3,438.2 | 105,300.0 | 362.0 | 0.43 | 0.2 | 0.7 |
| Average/Sum#: | 3,756.7 | 313.4 | 4,069.8 | 105,300.0 | 428.5 | 0.52 | 0.3 | 0.9 |
| Minimum: | 3,348.1 | 0.0 | 3,348.1 | 105,300.0 | 352.6 | 0.42 | 0.2 | 0.7 |
| Maximum: | 4,280.6 | 1,756.3 | 6,015.6 | 105,300.0 | 633.4 | 0.76 | 0.4 | 1.3 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 08/01/2026 00:00 | 3,363.3 | 0.0 | 3,363.3 | 105,300.0 | 354.2 | 0.43 | 0.2 | 0.7 |
| 08/01/2026 01:00 | 3,362.8 | 0.0 | 3,362.8 | 105,300.0 | 354.1 | 0.42 | 0.2 | 0.7 |
| 08/01/2026 02:00 | 3,367.2 | 0.0 | 3,367.2 | 105,300.0 | 354.6 | 0.43 | 0.2 | 0.7 |
| 08/01/2026 03:00 | 3,373.0 | 0.0 | 3,373.0 | 105,300.0 | 355.2 | 0.43 | 0.2 | 0.7 |
| 08/01/2026 04:00 | 3,375.6 | 0.0 | 3,375.6 | 105,300.0 | 355.5 | 0.43 | 0.2 | 0.7 |
| 08/01/2026 05:00 | 3,377.5 | 0.0 | 3,377.5 | 105,300.0 | 355.7 | 0.43 | 0.2 | 0.7 |
| 08/01/2026 06:00 | 3,377.9 | 0.0 | 3,377.9 | 105,300.0 | 355.7 | 0.43 | 0.2 | 0.7 |
| 08/01/2026 07:00 | 3,381.8 | 0.0 | 3,381.8 | 105,300.0 | 356.1 | 0.43 | 0.2 | 0.7 |
| 08/01/2026 08:00 | 3,372.3 | 0.0 | 3,372.3 | 105,300.0 | 355.1 | 0.43 | 0.2 | 0.7 |
| 08/01/2026 09:00 | 3,370.2 | 0.0 | 3,370.2 | 105,300.0 | 354.9 | 0.43 | 0.2 | 0.7 |
| 08/01/2026 10:00 | 3,367.1 | 0.0 | 3,367.1 | 105,300.0 | 354.6 | 0.43 | 0.2 | 0.7 |
| 08/01/2026 11:00 | 3,380.7 | 0.0 | 3,380.7 | 105,300.0 | 356.0 | 0.43 | 0.2 | 0.7 |
| 08/01/2026 12:00 | 3,380.3 | 0.0 | 3,380.3 | 105,300.0 | 355.9 | 0.43 | 0.2 | 0.7 |
| 08/01/2026 13:00 | 3,376.4 | 0.0 | 3,376.4 | 105,300.0 | 355.5 | 0.43 | 0.2 | 0.7 |
| 08/01/2026 14:00 | 3,599.7 | 3.8 | 3,599.8 | 105,300.0 | 379.1 | 0.46 | 0.2 | 0.8 |
| 08/01/2026 15:00 | 4,168.4 | 639.1 | 4,807.5 | 105,300.0 | 506.2 | 0.61 | 0.3 | 1.0 |
| 08/01/2026 16:00 | 4,057.3 | 838.7 | 4,896.0 | 105,300.0 | 515.5 | 0.62 | 0.3 | 1.0 |
| 08/01/2026 17:00 | 4,198.5 | 1,194.0 | 5,392.5 | 105,300.0 | 567.8 | 0.68 | 0.3 | 1.1 |
| 08/01/2026 18:00 | 4,198.2 | 1,786.1 | 5,984.3 | 105,300.0 | 630.1 | 0.76 | 0.4 | 1.3 |
| 08/01/2026 19:00 | 4,237.8 | 1,320.6 | 5,558.4 | 105,300.0 | 585.3 | 0.70 | 0.4 | 1.2 |
| 08/01/2026 20:00 | 4,236.5 | 491.7 | 4,728.2 | 105,300.0 | 497.9 | 0.60 | 0.3 | 1.0 |
| 08/01/2026 21:00 | 3,962.0 | 907.1 | 4,869.1 | 105,300.0 | 512.7 | 0.62 | 0.3 | 1.0 |
| 08/01/2026 22:00 | 4,004.5 | 797.8 | 4,802.3 | 105,300.0 | 505.7 | 0.61 | 0.3 | 1.0 |
| 08/01/2026 23:00 | 3,832.8 | 7.3 | 3,833.0 | 105,300.0 | 403.6 | 0.49 | 0.2 | 0.8 |
| Average/Sum#: | 3,655.1 | 332.8 | 3,987.4 | 105,300.0 | 419.9 | 0.51 | 0.2 | 0.8 |
| Minimum: | 3,362.8 | 0.0 | 3,362.8 | 105,300.0 | 354.1 | 0.42 | 0.2 | 0.7 |
| Maximum: | 4,237.8 | 1,786.1 | 5,984.3 | 105,300.0 | 630.1 | 0.76 | 0.4 | 1.3 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 08/02/2026 00:00 | 3,382.8 | 0.0 | 3,382.8 | 105,300.0 | 356.2 | 0.43 | 0.2 | 0.7 |
| 08/02/2026 01:00 | 3,348.4 | 0.0 | 3,348.4 | 105,300.0 | 352.6 | 0.42 | 0.2 | 0.7 |
| 08/02/2026 02:00 | 3,350.5 | 0.0 | 3,350.5 | 105,300.0 | 352.8 | 0.42 | 0.2 | 0.7 |
| 08/02/2026 03:00 | 3,362.5 | 0.0 | 3,362.5 | 105,300.0 | 354.1 | 0.42 | 0.2 | 0.7 |
| 08/02/2026 04:00 | 3,361.9 | 0.0 | 3,361.9 | 105,300.0 | 354.0 | 0.42 | 0.2 | 0.7 |
| 08/02/2026 05:00 | 3,366.1 | 0.0 | 3,366.1 | 105,300.0 | 354.5 | 0.43 | 0.2 | 0.7 |
| 08/02/2026 06:00 | 3,363.2 | 0.0 | 3,363.2 | 105,300.0 | 354.1 | 0.42 | 0.2 | 0.7 |
| 08/02/2026 07:00 | 3,365.8 | 0.0 | 3,365.8 | 105,300.0 | 354.4 | 0.43 | 0.2 | 0.7 |
| 08/02/2026 08:00 | 3,355.9 | 0.0 | 3,355.9 | 105,300.0 | 353.4 | 0.42 | 0.2 | 0.7 |
| 08/02/2026 09:00 | 3,348.1 | 0.0 | 3,348.1 | 105,300.0 | 352.6 | 0.42 | 0.2 | 0.7 |
| 08/02/2026 10:00 | 3,349.9 | 0.0 | 3,349.9 | 105,300.0 | 352.7 | 0.42 | 0.2 | 0.7 |
| 08/02/2026 11:00 | 3,359.5 | 0.0 | 3,359.5 | 105,300.0 | 353.8 | 0.42 | 0.2 | 0.7 |
| 08/02/2026 12:00 | 3,356.7 | 0.0 | 3,356.7 | 105,300.0 | 353.5 | 0.42 | 0.2 | 0.7 |
| 08/02/2026 13:00 | 3,600.5 | 3.8 | 3,600.6 | 105,300.0 | 379.1 | 0.45 | 0.2 | 0.8 |
| 08/02/2026 14:00 | 4,206.7 | 592.6 | 4,799.3 | 105,300.0 | 505.4 | 0.61 | 0.3 | 1.0 |
| 08/02/2026 15:00 | 4,192.2 | 593.3 | 4,785.5 | 105,300.0 | 503.9 | 0.60 | 0.3 | 1.0 |
| 08/02/2026 16:00 | 4,190.3 | 830.8 | 5,021.1 | 105,300.0 | 528.7 | 0.63 | 0.3 | 1.1 |
| 08/02/2026 17:00 | 4,192.7 | 668.9 | 4,861.6 | 105,300.0 | 511.9 | 0.61 | 0.3 | 1.0 |
| 08/02/2026 18:00 | 4,154.6 | 671.8 | 4,826.4 | 105,300.0 | 508.2 | 0.61 | 0.3 | 1.0 |
| 08/02/2026 19:00 | 3,776.4 | 1,264.2 | 5,040.6 | 105,300.0 | 530.8 | 0.64 | 0.3 | 1.1 |
| 08/02/2026 20:00 | 3,849.3 | 1,135.5 | 4,984.8 | 105,300.0 | 524.9 | 0.63 | 0.3 | 1.0 |
| 08/02/2026 21:00 | 3,891.5 | 1,013.7 | 4,905.2 | 105,300.0 | 516.5 | 0.62 | 0.3 | 1.0 |
| 08/02/2026 22:00 | 3,980.3 | 141.0 | 4,095.9 | 105,300.0 | 431.3 | 0.52 | 0.3 | 0.9 |
| 08/02/2026 23:00 | 3,859.8 | 95.0 | 3,914.0 | 105,300.0 | 412.1 | 0.50 | 0.2 | 0.8 |
| Average/Sum#: | 3,648.6 | 292.1 | 3,937.8 | 105,300.0 | 414.6 | 0.50 | 0.2 | 0.8 |
| Minimum: | 3,348.1 | 0.0 | 3,348.1 | 105,300.0 | 352.6 | 0.42 | 0.2 | 0.7 |
| Maximum: | 4,206.7 | 1,264.2 | 5,040.6 | 105,300.0 | 530.8 | 0.64 | 0.3 | 1.1 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 08/03/2026 00:00 | 3,353.7 | 0.0 | 3,353.7 | 105,300.0 | 353.1 | 0.42 | 0.2 | 0.7 |
| 08/03/2026 01:00 | 3,617.3 | 0.0 | 3,617.3 | 105,300.0 | 380.9 | 0.46 | 0.2 | 0.8 |
| 08/03/2026 02:00 | 3,342.4 | 0.0 | 3,342.4 | 105,300.0 | 352.0 | 0.42 | 0.2 | 0.7 |
| 08/03/2026 03:00 | 3,342.8 | 0.0 | 3,342.8 | 105,300.0 | 352.0 | 0.42 | 0.2 | 0.7 |
| 08/03/2026 04:00 | 3,830.7 | 0.0 | 3,830.7 | 105,300.0 | 403.4 | 0.48 | 0.2 | 0.8 |
| 08/03/2026 05:00 | 3,735.7 | 0.0 | 3,735.7 | 105,300.0 | 393.4 | 0.47 | 0.2 | 0.8 |
| 08/03/2026 06:00 | 3,363.7 | 0.0 | 3,363.7 | 105,300.0 | 354.2 | 0.42 | 0.2 | 0.7 |
| 08/03/2026 07:00 | 3,366.4 | 0.0 | 3,366.4 | 105,300.0 | 354.5 | 0.43 | 0.2 | 0.7 |
| 08/03/2026 08:00 | 3,349.6 | 0.0 | 3,349.6 | 105,300.0 | 352.7 | 0.42 | 0.2 | 0.7 |
| 08/03/2026 09:00 | 3,347.2 | 0.0 | 3,347.2 | 105,300.0 | 352.5 | 0.42 | 0.2 | 0.7 |
| 08/03/2026 10:00 | 3,348.6 | 0.0 | 3,348.6 | 105,300.0 | 352.6 | 0.42 | 0.2 | 0.7 |
| 08/03/2026 11:00 | 3,358.7 | 0.0 | 3,358.7 | 105,300.0 | 353.7 | 0.42 | 0.2 | 0.7 |
| 08/03/2026 12:00 | 3,650.0 | 0.0 | 3,650.0 | 105,300.0 | 384.3 | 0.46 | 0.2 | 0.8 |
| 08/03/2026 13:00 | 3,807.0 | 3.8 | 3,807.1 | 105,300.0 | 400.9 | 0.48 | 0.2 | 0.8 |
| 08/03/2026 14:00 | 4,176.6 | 748.4 | 4,925.0 | 105,300.0 | 518.6 | 0.62 | 0.3 | 1.0 |
| 08/03/2026 15:00 | 4,184.3 | 669.1 | 4,853.4 | 105,300.0 | 511.1 | 0.61 | 0.3 | 1.0 |
| 08/03/2026 16:00 | 4,187.7 | 1,106.1 | 5,293.8 | 105,300.0 | 557.4 | 0.67 | 0.3 | 1.1 |
| 08/03/2026 17:00 | 4,187.1 | 1,232.2 | 5,419.3 | 105,300.0 | 570.7 | 0.69 | 0.3 | 1.1 |
| 08/03/2026 18:00 | 4,171.4 | 1,904.2 | 6,075.6 | 105,300.0 | 639.8 | 0.77 | 0.4 | 1.3 |
| 08/03/2026 19:00 | 4,184.1 | 1,632.6 | 5,816.7 | 105,300.0 | 612.5 | 0.74 | 0.4 | 1.2 |
| 08/03/2026 20:00 | 4,227.4 | 1,351.6 | 5,579.0 | 105,300.0 | 587.5 | 0.70 | 0.4 | 1.2 |
| 08/03/2026 21:00 | 4,109.3 | 918.3 | 5,027.6 | 105,300.0 | 529.4 | 0.64 | 0.3 | 1.1 |
| 08/03/2026 22:00 | 3,805.0 | 83.7 | 3,842.7 | 105,300.0 | 404.6 | 0.49 | 0.2 | 0.8 |
| 08/03/2026 23:00 | 4,007.5 | 0.0 | 4,007.5 | 105,300.0 | 422.0 | 0.51 | 0.3 | 0.8 |
| Average/Sum#: | 3,752.3 | 402.1 | 4,152.3 | 105,300.0 | 437.2 | 0.52 | 0.3 | 0.9 |
| Minimum: | 3,342.4 | 0.0 | 3,342.4 | 105,300.0 | 352.0 | 0.42 | 0.2 | 0.7 |
| Maximum: | 4,227.4 | 1,904.2 | 6,075.6 | 105,300.0 | 639.8 | 0.77 | 0.4 | 1.3 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 08/04/2026 00:00 | 3,493.5 | 0.0 | 3,493.5 | 105,300.0 | 367.9 | 0.44 | 0.2 | 0.7 |
| 08/04/2026 01:00 | 3,348.2 | 0.0 | 3,348.2 | 105,300.0 | 352.6 | 0.42 | 0.2 | 0.7 |
| 08/04/2026 02:00 | 3,346.7 | 0.0 | 3,346.7 | 105,300.0 | 352.4 | 0.42 | 0.2 | 0.7 |
| 08/04/2026 03:00 | 3,519.5 | 0.0 | 3,519.5 | 105,300.0 | 370.6 | 0.44 | 0.2 | 0.7 |
| 08/04/2026 04:00 | 3,865.0 | 0.0 | 3,865.0 | 105,300.0 | 407.0 | 0.49 | 0.2 | 0.8 |
| 08/04/2026 05:00 | 3,730.5 | 0.0 | 3,730.5 | 105,300.0 | 392.8 | 0.47 | 0.2 | 0.8 |
| 08/04/2026 06:00 | 3,607.6 | 0.0 | 3,607.6 | 105,300.0 | 379.9 | 0.45 | 0.2 | 0.8 |
| 08/04/2026 07:00 | 3,355.2 | 0.0 | 3,355.2 | 105,300.0 | 353.3 | 0.42 | 0.2 | 0.7 |
| 08/04/2026 08:00 | 3,349.2 | 0.0 | 3,349.2 | 105,300.0 | 352.7 | 0.42 | 0.2 | 0.7 |
| 08/04/2026 09:00 | 3,351.7 | 0.0 | 3,351.7 | 105,300.0 | 352.9 | 0.42 | 0.2 | 0.7 |
| 08/04/2026 10:00 | 3,377.3 | 0.0 | 3,377.3 | 105,300.0 | 355.6 | 0.42 | 0.2 | 0.7 |
| 08/04/2026 11:00 | 3,558.5 | 0.0 | 3,558.5 | 105,300.0 | 374.7 | 0.45 | 0.2 | 0.7 |
| 08/04/2026 12:00 | 3,847.8 | 0.0 | 3,847.8 | 105,300.0 | 405.2 | 0.49 | 0.2 | 0.8 |
| 08/04/2026 13:00 | 4,027.0 | 3.7 | 4,027.1 | 105,300.0 | 424.1 | 0.51 | 0.3 | 0.8 |
| 08/04/2026 14:00 | 4,194.4 | 938.7 | 5,133.1 | 105,300.0 | 540.5 | 0.65 | 0.3 | 1.1 |
| 08/04/2026 15:00 | 4,178.6 | 1,072.0 | 5,250.6 | 105,300.0 | 552.9 | 0.66 | 0.3 | 1.1 |
| 08/04/2026 16:00 | 4,170.4 | 901.0 | 5,071.4 | 105,300.0 | 534.0 | 0.64 | 0.3 | 1.1 |
| 08/04/2026 17:00 | 4,089.5 | 1,180.4 | 5,187.3 | 105,300.0 | 546.2 | 0.67 | 0.3 | 1.1 |
| 08/04/2026 18:00 | 4,209.0 | 1,492.0 | 5,701.0 | 105,300.0 | 600.3 | 0.72 | 0.4 | 1.2 |
| 08/04/2026 19:00 | 4,243.5 | 489.1 | 4,732.6 | 105,300.0 | 498.3 | 0.60 | 0.3 | 1.0 |
| 08/04/2026 20:00 | 4,146.1 | 633.1 | 4,779.2 | 105,300.0 | 503.2 | 0.61 | 0.3 | 1.0 |
| 08/04/2026 21:00 | 4,100.6 | 724.9 | 4,825.5 | 105,300.0 | 508.1 | 0.61 | 0.3 | 1.0 |
| 08/04/2026 22:00 | 3,453.9 | 1.3 | 3,453.9 | 105,300.0 | 363.7 | 0.43 | 0.2 | 0.7 |
| 08/04/2026 23:00 | 3,985.0 | 0.0 | 3,985.0 | 105,300.0 | 419.6 | 0.50 | 0.3 | 0.8 |
| Average/Sum#: | 3,772.9 | 309.8 | 4,079.1 | 105,300.0 | 429.5 | 0.51 | 0.2 | 0.9 |
| Minimum: | 3,346.7 | 0.0 | 3,346.7 | 105,300.0 | 352.4 | 0.42 | 0.2 | 0.7 |
| Maximum: | 4,243.5 | 1,492.0 | 5,701.0 | 105,300.0 | 600.3 | 0.72 | 0.4 | 1.2 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 08/05/2026 00:00 | 3,765.5 | 0.0 | 3,765.5 | 105,300.0 | 396.5 | 0.48 | 0.2 | 0.8 |
| 08/05/2026 01:00 | 3,373.1 | 0.0 | 3,373.1 | 105,300.0 | 355.2 | 0.43 | 0.2 | 0.7 |
| 08/05/2026 02:00 | 3,372.2 | 0.0 | 3,372.2 | 105,300.0 | 355.1 | 0.43 | 0.2 | 0.7 |
| 08/05/2026 03:00 | 3,372.3 | 0.0 | 3,372.3 | 105,300.0 | 355.1 | 0.43 | 0.2 | 0.7 |
| 08/05/2026 04:00 | 3,424.1 | 0.0 | 3,424.1 | 105,300.0 | 360.6 | 0.44 | 0.2 | 0.7 |
| 08/05/2026 05:00 | 3,376.0 | 0.0 | 3,376.0 | 105,300.0 | 355.5 | 0.43 | 0.2 | 0.7 |
| 08/05/2026 06:00 | 3,512.6 | 0.0 | 3,512.6 | 105,300.0 | 369.9 | 0.45 | 0.2 | 0.7 |
| 08/05/2026 07:00 | 3,383.8 | 0.0 | 3,383.8 | 105,300.0 | 356.3 | 0.43 | 0.2 | 0.7 |
| 08/05/2026 08:00 | 3,374.6 | 0.0 | 3,374.6 | 105,300.0 | 355.3 | 0.43 | 0.2 | 0.7 |
| 08/05/2026 09:00 | 3,373.8 | 0.0 | 3,373.8 | 105,300.0 | 355.3 | 0.43 | 0.2 | 0.7 |
| 08/05/2026 10:00 | 3,372.7 | 0.0 | 3,372.7 | 105,300.0 | 355.1 | 0.43 | 0.2 | 0.7 |
| 08/05/2026 11:00 | 3,381.7 | 0.0 | 3,381.7 | 105,300.0 | 356.1 | 0.43 | 0.2 | 0.7 |
| 08/05/2026 12:00 | 3,532.9 | 0.0 | 3,532.9 | 105,300.0 | 372.0 | 0.45 | 0.2 | 0.7 |
| 08/05/2026 13:00 | 3,666.2 | 0.0 | 3,666.2 | 105,300.0 | 386.1 | 0.46 | 0.2 | 0.8 |
| 08/05/2026 14:00 | 4,263.8 | 538.8 | 4,791.8 | 105,300.0 | 504.6 | 0.61 | 0.3 | 1.0 |
| 08/05/2026 15:00 | 4,241.5 | 589.9 | 4,831.4 | 105,300.0 | 508.7 | 0.61 | 0.3 | 1.0 |
| 08/05/2026 16:00 | 4,239.8 | 1,014.5 | 5,254.3 | 105,300.0 | 553.3 | 0.66 | 0.3 | 1.1 |
| 08/05/2026 17:00 | 4,245.8 | 828.6 | 5,074.4 | 105,300.0 | 534.3 | 0.64 | 0.3 | 1.1 |
| 08/05/2026 18:00 | 4,280.2 | 497.2 | 4,777.4 | 105,300.0 | 503.1 | 0.60 | 0.3 | 1.0 |
| 08/05/2026 19:00 | 4,129.5 | 709.1 | 4,838.6 | 105,300.0 | 509.5 | 0.61 | 0.3 | 1.0 |
| 08/05/2026 20:00 | 4,070.2 | 793.8 | 4,864.0 | 105,300.0 | 512.2 | 0.62 | 0.3 | 1.0 |
| 08/05/2026 21:00 | 4,161.8 | 620.2 | 4,782.0 | 105,300.0 | 503.5 | 0.60 | 0.3 | 1.0 |
| 08/05/2026 22:00 | 4,072.4 | 4.3 | 4,072.5 | 105,300.0 | 428.8 | 0.52 | 0.3 | 0.9 |
| 08/05/2026 23:00 | 3,927.4 | 0.0 | 3,927.4 | 105,300.0 | 413.6 | 0.49 | 0.2 | 0.8 |
| Average/Sum#: | 3,746.4 | 233.2 | 3,979.0 | 105,300.0 | 419.0 | 0.50 | 0.2 | 0.8 |
| Minimum: | 3,372.2 | 0.0 | 3,372.2 | 105,300.0 | 355.1 | 0.43 | 0.2 | 0.7 |
| Maximum: | 4,280.2 | 1,014.5 | 5,254.3 | 105,300.0 | 553.3 | 0.66 | 0.3 | 1.1 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 08/06/2026 00:00 | 3,487.2 | 0.0 | 3,487.2 | 105,300.0 | 367.2 | 0.44 | 0.2 | 0.7 |
| 08/06/2026 01:00 | 3,353.8 | 0.0 | 3,353.8 | 105,300.0 | 353.2 | 0.42 | 0.2 | 0.7 |
| 08/06/2026 02:00 | 3,354.8 | 0.0 | 3,354.8 | 105,300.0 | 353.3 | 0.42 | 0.2 | 0.7 |
| 08/06/2026 03:00 | 3,360.7 | 0.0 | 3,360.7 | 105,300.0 | 353.9 | 0.42 | 0.2 | 0.7 |
| 08/06/2026 04:00 | 3,399.0 | 0.0 | 3,399.0 | 105,300.0 | 357.9 | 0.43 | 0.2 | 0.7 |
| 08/06/2026 05:00 | 3,556.3 | 0.0 | 3,556.3 | 105,300.0 | 374.5 | 0.45 | 0.2 | 0.8 |
| 08/06/2026 06:00 | 3,370.4 | 0.0 | 3,370.4 | 105,300.0 | 354.9 | 0.43 | 0.2 | 0.7 |
| 08/06/2026 07:00 | 3,375.4 | 0.0 | 3,375.4 | 105,300.0 | 355.4 | 0.43 | 0.2 | 0.7 |
| 08/06/2026 08:00 | 3,365.6 | 0.0 | 3,365.6 | 105,300.0 | 354.4 | 0.43 | 0.2 | 0.7 |
| 08/06/2026 09:00 | 3,363.6 | 0.0 | 3,363.6 | 105,300.0 | 354.2 | 0.42 | 0.2 | 0.7 |
| 08/06/2026 10:00 | 3,365.8 | 0.0 | 3,365.8 | 105,300.0 | 354.4 | 0.43 | 0.2 | 0.7 |
| 08/06/2026 11:00 | 3,369.4 | 0.0 | 3,369.4 | 105,300.0 | 354.8 | 0.43 | 0.2 | 0.7 |
| 08/06/2026 12:00 | 3,369.6 | 0.0 | 3,369.6 | 105,300.0 | 354.8 | 0.43 | 0.2 | 0.7 |
| 08/06/2026 13:00 | 3,564.1 | 0.0 | 3,564.1 | 105,300.0 | 375.3 | 0.45 | 0.2 | 0.8 |
| 08/06/2026 14:00 | 3,803.1 | 1,213.8 | 4,980.5 | 105,300.0 | 524.4 | 0.63 | 0.3 | 1.1 |
| 08/06/2026 15:00 | 3,701.8 | 1,405.2 | 5,107.0 | 105,300.0 | 537.8 | 0.65 | 0.3 | 1.1 |
| 08/06/2026 16:00 | 3,795.9 | 1,457.8 | 5,253.7 | 105,300.0 | 553.2 | 0.67 | 0.3 | 1.1 |
| 08/06/2026 17:00 | 4,237.9 | 1,650.2 | 5,888.1 | 105,300.0 | 620.0 | 0.74 | 0.4 | 1.2 |
| 08/06/2026 18:00 | 4,279.3 | 1,369.3 | 5,648.6 | 105,300.0 | 594.8 | 0.71 | 0.4 | 1.2 |
| 08/06/2026 19:00 | 4,264.0 | 546.5 | 4,810.5 | 105,300.0 | 506.5 | 0.61 | 0.3 | 1.0 |
| 08/06/2026 20:00 | 4,053.3 | 867.2 | 4,920.5 | 105,300.0 | 518.1 | 0.62 | 0.3 | 1.0 |
| 08/06/2026 21:00 | 4,125.9 | 991.6 | 5,117.5 | 105,300.0 | 538.9 | 0.65 | 0.3 | 1.1 |
| 08/06/2026 22:00 | 4,067.9 | 4.4 | 4,068.0 | 105,300.0 | 428.4 | 0.51 | 0.3 | 0.9 |
| 08/06/2026 23:00 | 4,067.3 | 0.0 | 4,067.3 | 105,300.0 | 428.3 | 0.51 | 0.3 | 0.9 |
| Average/Sum#: | 3,668.8 | 396.1 | 4,063.2 | 105,300.0 | 427.9 | 0.51 | 0.3 | 0.9 |
| Minimum: | 3,353.8 | 0.0 | 3,353.8 | 105,300.0 | 353.2 | 0.42 | 0.2 | 0.7 |
| Maximum: | 4,279.3 | 1,650.2 | 5,888.1 | 105,300.0 | 620.0 | 0.74 | 0.4 | 1.2 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 08/07/2026 00:00 | 4,065.1 | 0.0 | 4,065.1 | 105,300.0 | 428.1 | 0.51 | 0.3 | 0.9 |
| 08/07/2026 01:00 | 4,065.2 | 0.0 | 4,065.2 | 105,300.0 | 428.1 | 0.51 | 0.3 | 0.9 |
| 08/07/2026 02:00 | 4,063.8 | 0.0 | 4,063.8 | 105,300.0 | 427.9 | 0.51 | 0.3 | 0.9 |
| 08/07/2026 03:00 | 3,579.1 | 0.0 | 3,579.1 | 105,300.0 | 376.9 | 0.45 | 0.2 | 0.8 |
| 08/07/2026 04:00 | 4,035.4 | 0.0 | 4,035.4 | 105,300.0 | 424.9 | 0.51 | 0.3 | 0.9 |
| 08/07/2026 05:00 | 4,059.8 | 0.0 | 4,059.8 | 105,300.0 | 427.5 | 0.51 | 0.3 | 0.9 |
| 08/07/2026 06:00 | 3,561.6 | 0.0 | 3,561.6 | 105,300.0 | 375.0 | 0.45 | 0.2 | 0.8 |
| 08/07/2026 07:00 | 3,379.5 | 0.0 | 3,379.5 | 105,300.0 | 355.9 | 0.43 | 0.2 | 0.7 |
| 08/07/2026 08:00 | 3,372.7 | 0.0 | 3,372.7 | 105,300.0 | 355.1 | 0.43 | 0.2 | 0.7 |
| 08/07/2026 09:00 | 3,369.6 | 0.0 | 3,369.6 | 105,300.0 | 354.8 | 0.43 | 0.2 | 0.7 |
| 08/07/2026 10:00 | 3,368.4 | 0.0 | 3,368.4 | 105,300.0 | 354.7 | 0.43 | 0.2 | 0.7 |
| 08/07/2026 11:00 | 3,650.5 | 0.0 | 3,650.5 | 105,300.0 | 384.4 | 0.46 | 0.2 | 0.8 |
| 08/07/2026 12:00 | 3,500.2 | 0.0 | 3,500.2 | 105,300.0 | 368.6 | 0.44 | 0.2 | 0.7 |
| 08/07/2026 13:00 | 3,932.8 | 1.3 | 3,932.8 | 105,300.0 | 414.1 | 0.50 | 0.2 | 0.8 |
| 08/07/2026 14:00 | 4,026.8 | 967.0 | 4,993.8 | 105,300.0 | 525.8 | 0.63 | 0.3 | 1.1 |
| 08/07/2026 15:00 | 3,696.8 | 1,489.2 | 5,186.0 | 105,300.0 | 546.1 | 0.65 | 0.3 | 1.1 |
| 08/07/2026 16:00 | 3,746.9 | 1,433.7 | 5,180.6 | 105,300.0 | 545.5 | 0.66 | 0.3 | 1.1 |
| 08/07/2026 17:00 | 4,219.0 | 1,001.1 | 5,220.1 | 105,300.0 | 549.7 | 0.66 | 0.3 | 1.1 |
| 08/07/2026 18:00 | 4,250.2 | 1,521.6 | 5,771.8 | 105,300.0 | 607.8 | 0.73 | 0.4 | 1.2 |
| 08/07/2026 19:00 | 4,276.2 | 795.1 | 5,071.3 | 105,300.0 | 534.0 | 0.64 | 0.3 | 1.1 |
| 08/07/2026 20:00 | 4,271.0 | 617.4 | 4,888.4 | 105,300.0 | 514.7 | 0.62 | 0.3 | 1.0 |
| 08/07/2026 21:00 | 4,170.3 | 767.8 | 4,938.1 | 105,300.0 | 520.0 | 0.62 | 0.3 | 1.0 |
| 08/07/2026 22:00 | 4,101.7 | 6.8 | 4,101.9 | 105,300.0 | 431.9 | 0.52 | 0.3 | 0.9 |
| 08/07/2026 23:00 | 4,181.9 | 0.0 | 4,181.9 | 105,300.0 | 440.4 | 0.53 | 0.3 | 0.9 |
| Average/Sum#: | 3,872.7 | 358.4 | 4,230.7 | 105,300.0 | 445.5 | 0.53 | 0.3 | 0.9 |
| Minimum: | 3,368.4 | 0.0 | 3,368.4 | 105,300.0 | 354.7 | 0.43 | 0.2 | 0.7 |
| Maximum: | 4,276.2 | 1,521.6 | 5,771.8 | 105,300.0 | 607.8 | 0.73 | 0.4 | 1.2 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 08/08/2026 00:00 | 4,179.5 | 0.0 | 4,179.5 | 105,300.0 | 440.1 | 0.53 | 0.3 | 0.9 |
| 08/08/2026 01:00 | 3,665.7 | 0.0 | 3,665.7 | 105,300.0 | 386.0 | 0.46 | 0.2 | 0.8 |
| 08/08/2026 02:00 | 3,376.2 | 0.0 | 3,376.2 | 105,300.0 | 355.5 | 0.43 | 0.2 | 0.7 |
| 08/08/2026 03:00 | 3,401.4 | 0.0 | 3,401.4 | 105,300.0 | 358.2 | 0.43 | 0.2 | 0.7 |
| 08/08/2026 04:00 | 4,030.6 | 0.0 | 4,030.6 | 105,300.0 | 424.4 | 0.51 | 0.3 | 0.8 |
| 08/08/2026 05:00 | 3,814.8 | 0.0 | 3,814.8 | 105,300.0 | 401.7 | 0.48 | 0.2 | 0.8 |
| 08/08/2026 06:00 | 3,390.2 | 0.0 | 3,390.2 | 105,300.0 | 357.0 | 0.43 | 0.2 | 0.7 |
| 08/08/2026 07:00 | 3,391.1 | 0.0 | 3,391.1 | 105,300.0 | 357.1 | 0.43 | 0.2 | 0.7 |
| 08/08/2026 08:00 | 3,406.1 | 0.0 | 3,406.1 | 105,300.0 | 358.7 | 0.43 | 0.2 | 0.7 |
| 08/08/2026 09:00 | 3,406.7 | 0.0 | 3,406.7 | 105,300.0 | 358.7 | 0.43 | 0.2 | 0.7 |
| 08/08/2026 10:00 | 3,400.0 | 0.0 | 3,400.0 | 105,300.0 | 358.0 | 0.43 | 0.2 | 0.7 |
| 08/08/2026 11:00 | 3,399.6 | 0.0 | 3,399.6 | 105,300.0 | 358.0 | 0.43 | 0.2 | 0.7 |
| 08/08/2026 12:00 | 3,398.7 | 0.0 | 3,398.7 | 105,300.0 | 357.9 | 0.43 | 0.2 | 0.7 |
| 08/08/2026 13:00 | 3,552.6 | 143.4 | 3,588.5 | 105,300.0 | 377.9 | 0.47 | 0.2 | 0.8 |
| 08/08/2026 14:00 | 3,767.9 | 1,440.6 | 5,208.5 | 105,300.0 | 548.5 | 0.66 | 0.3 | 1.1 |
| 08/08/2026 15:00 | 3,826.2 | 1,219.7 | 5,045.9 | 105,300.0 | 531.3 | 0.64 | 0.3 | 1.1 |
| 08/08/2026 16:00 | 4,178.5 | 694.4 | 4,872.9 | 105,300.0 | 513.1 | 0.62 | 0.3 | 1.0 |
| 08/08/2026 17:00 | 4,201.3 | 776.2 | 4,977.5 | 105,300.0 | 524.1 | 0.63 | 0.3 | 1.0 |
| 08/08/2026 18:00 | 4,228.0 | 672.5 | 4,900.5 | 105,300.0 | 516.0 | 0.62 | 0.3 | 1.0 |
| 08/08/2026 19:00 | 4,071.6 | 823.5 | 4,895.1 | 105,300.0 | 515.5 | 0.62 | 0.3 | 1.0 |
| 08/08/2026 20:00 | 4,087.7 | 778.3 | 4,866.0 | 105,300.0 | 512.4 | 0.61 | 0.3 | 1.0 |
| 08/08/2026 21:00 | 4,099.1 | 717.6 | 4,816.7 | 105,300.0 | 507.2 | 0.61 | 0.3 | 1.0 |
| 08/08/2026 22:00 | 4,085.5 | 6.5 | 4,085.7 | 105,300.0 | 430.2 | 0.52 | 0.3 | 0.9 |
| 08/08/2026 23:00 | 3,831.5 | 0.0 | 3,831.5 | 105,300.0 | 403.5 | 0.48 | 0.2 | 0.8 |
| Average/Sum#: | 3,757.9 | 303.0 | 4,056.2 | 105,300.0 | 427.1 | 0.51 | 0.2 | 0.8 |
| Minimum: | 3,376.2 | 0.0 | 3,376.2 | 105,300.0 | 355.5 | 0.43 | 0.2 | 0.7 |
| Maximum: | 4,228.0 | 1,440.6 | 5,208.5 | 105,300.0 | 548.5 | 0.66 | 0.3 | 1.1 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 08/09/2026 00:00 | 3,367.7 | 0.0 | 3,367.7 | 105,300.0 | 354.6 | 0.43 | 0.2 | 0.7 |
| 08/09/2026 01:00 | 3,367.6 | 0.0 | 3,367.6 | 105,300.0 | 354.6 | 0.43 | 0.2 | 0.7 |
| 08/09/2026 02:00 | 3,371.3 | 0.0 | 3,371.3 | 105,300.0 | 355.0 | 0.43 | 0.2 | 0.7 |
| 08/09/2026 03:00 | 3,371.3 | 0.0 | 3,371.3 | 105,300.0 | 355.0 | 0.43 | 0.2 | 0.7 |
| 08/09/2026 04:00 | 3,408.7 | 0.0 | 3,408.7 | 105,300.0 | 358.9 | 0.43 | 0.2 | 0.7 |
| 08/09/2026 05:00 | 3,789.3 | 0.0 | 3,789.3 | 105,300.0 | 399.0 | 0.48 | 0.2 | 0.8 |
| 08/09/2026 06:00 | 3,385.2 | 0.0 | 3,385.2 | 105,300.0 | 356.5 | 0.43 | 0.2 | 0.7 |
| 08/09/2026 07:00 | 3,389.0 | 0.0 | 3,389.0 | 105,300.0 | 356.9 | 0.43 | 0.2 | 0.7 |
| 08/09/2026 08:00 | 3,381.3 | 0.0 | 3,381.3 | 105,300.0 | 356.1 | 0.43 | 0.2 | 0.7 |
| 08/09/2026 09:00 | 3,376.0 | 0.0 | 3,376.0 | 105,300.0 | 355.5 | 0.43 | 0.2 | 0.7 |
| 08/09/2026 10:00 | 3,374.9 | 0.0 | 3,374.9 | 105,300.0 | 355.4 | 0.43 | 0.2 | 0.7 |
| 08/09/2026 11:00 | 3,379.6 | 0.0 | 3,379.6 | 105,300.0 | 355.9 | 0.43 | 0.2 | 0.7 |
| 08/09/2026 12:00 | 3,471.8 | 0.0 | 3,471.8 | 105,300.0 | 365.6 | 0.44 | 0.2 | 0.7 |
| 08/09/2026 13:00 | 3,998.5 | 0.0 | 3,998.5 | 105,300.0 | 421.0 | 0.51 | 0.3 | 0.8 |
| 08/09/2026 14:00 | 4,197.4 | 890.7 | 4,892.1 | 105,300.0 | 515.1 | 0.64 | 0.3 | 1.1 |
| 08/09/2026 15:00 | 4,138.0 | 1,593.9 | 5,731.9 | 105,300.0 | 603.6 | 0.72 | 0.4 | 1.2 |
| 08/09/2026 16:00 | 4,130.2 | 1,678.2 | 5,808.4 | 105,300.0 | 611.6 | 0.73 | 0.4 | 1.2 |
| 08/09/2026 17:00 | 4,157.8 | 1,484.8 | 5,642.6 | 105,300.0 | 594.2 | 0.71 | 0.4 | 1.2 |
| 08/09/2026 18:00 | 4,214.7 | 1,618.9 | 5,833.6 | 105,300.0 | 614.3 | 0.74 | 0.4 | 1.2 |
| 08/09/2026 19:00 | 4,187.7 | 647.3 | 4,835.0 | 105,300.0 | 509.1 | 0.61 | 0.3 | 1.0 |
| 08/09/2026 20:00 | 3,967.8 | 958.6 | 4,926.4 | 105,300.0 | 518.7 | 0.62 | 0.3 | 1.0 |
| 08/09/2026 21:00 | 4,097.5 | 747.4 | 4,830.0 | 105,300.0 | 508.6 | 0.61 | 0.3 | 1.0 |
| 08/09/2026 22:00 | 3,489.5 | 0.0 | 3,489.5 | 105,300.0 | 367.4 | 0.44 | 0.2 | 0.7 |
| 08/09/2026 23:00 | 3,357.9 | 0.0 | 3,357.9 | 105,300.0 | 353.6 | 0.42 | 0.2 | 0.7 |
| Average/Sum#: | 3,682.1 | 400.8 | 4,074.2 | 105,300.0 | 429.0 | 0.52 | 0.3 | 0.8 |
| Minimum: | 3,357.9 | 0.0 | 3,357.9 | 105,300.0 | 353.6 | 0.42 | 0.2 | 0.7 |
| Maximum: | 4,214.7 | 1,678.2 | 5,833.6 | 105,300.0 | 614.3 | 0.74 | 0.4 | 1.2 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 08/10/2026 00:00 | 3,362.0 | 0.0 | 3,362.0 | 105,300.0 | 354.0 | 0.42 | 0.2 | 0.7 |
| 08/10/2026 01:00 | 3,363.4 | 0.0 | 3,363.4 | 105,300.0 | 354.2 | 0.43 | 0.2 | 0.7 |
| 08/10/2026 02:00 | 3,363.1 | 0.0 | 3,363.1 | 105,300.0 | 354.1 | 0.42 | 0.2 | 0.7 |
| 08/10/2026 03:00 | 3,367.4 | 0.0 | 3,367.4 | 105,300.0 | 354.6 | 0.43 | 0.2 | 0.7 |
| 08/10/2026 04:00 | 3,733.0 | 0.0 | 3,733.0 | 105,300.0 | 393.1 | 0.47 | 0.2 | 0.8 |
| 08/10/2026 05:00 | 3,372.8 | 0.0 | 3,372.8 | 105,300.0 | 355.2 | 0.43 | 0.2 | 0.7 |
| 08/10/2026 06:00 | 3,695.9 | 0.0 | 3,695.9 | 105,300.0 | 389.2 | 0.47 | 0.2 | 0.8 |
| 08/10/2026 07:00 | 3,387.7 | 0.0 | 3,387.7 | 105,300.0 | 356.7 | 0.43 | 0.2 | 0.7 |
| 08/10/2026 08:00 | 3,377.7 | 0.0 | 3,377.7 | 105,300.0 | 355.7 | 0.43 | 0.2 | 0.7 |
| 08/10/2026 09:00 | 3,375.9 | 0.0 | 3,375.9 | 105,300.0 | 355.5 | 0.43 | 0.2 | 0.7 |
| 08/10/2026 10:00 | 3,375.6 | 0.0 | 3,375.6 | 105,300.0 | 355.5 | 0.43 | 0.2 | 0.7 |
| 08/10/2026 11:00 | 3,382.6 | 0.0 | 3,382.6 | 105,300.0 | 356.2 | 0.43 | 0.2 | 0.7 |
| 08/10/2026 12:00 | 3,561.3 | 0.0 | 3,561.3 | 105,300.0 | 375.0 | 0.45 | 0.2 | 0.7 |
| 08/10/2026 13:00 | 3,877.2 | 0.0 | 3,877.2 | 105,300.0 | 408.3 | 0.49 | 0.2 | 0.8 |
| 08/10/2026 14:00 | 3,776.3 | 5.1 | 3,776.5 | 105,300.0 | 397.7 | 0.48 | 0.2 | 0.8 |
| 08/10/2026 15:00 | 4,274.6 | 633.2 | 4,907.8 | 105,300.0 | 516.8 | 0.62 | 0.3 | 1.0 |
| 08/10/2026 16:00 | 4,262.6 | 1,272.7 | 5,535.3 | 105,300.0 | 582.9 | 0.70 | 0.3 | 1.2 |
| 08/10/2026 17:00 | 4,270.6 | 1,544.2 | 5,814.8 | 105,300.0 | 612.3 | 0.74 | 0.4 | 1.2 |
| 08/10/2026 18:00 | 4,290.7 | 1,338.3 | 5,629.0 | 105,300.0 | 592.7 | 0.71 | 0.4 | 1.2 |
| 08/10/2026 19:00 | 4,312.4 | 843.6 | 5,156.0 | 105,300.0 | 542.9 | 0.65 | 0.3 | 1.1 |
| 08/10/2026 20:00 | 4,339.2 | 513.4 | 4,852.6 | 105,300.0 | 511.0 | 0.61 | 0.3 | 1.0 |
| 08/10/2026 21:00 | 4,364.5 | 741.7 | 5,106.2 | 105,300.0 | 537.7 | 0.64 | 0.3 | 1.1 |
| 08/10/2026 22:00 | 4,094.6 | 2.4 | 4,094.6 | 105,300.0 | 431.2 | 0.52 | 0.3 | 0.9 |
| 08/10/2026 23:00 | 3,572.0 | 0.0 | 3,572.0 | 105,300.0 | 376.1 | 0.45 | 0.2 | 0.8 |
| Average/Sum#: | 3,756.4 | 287.3 | 4,043.4 | 105,300.0 | 425.8 | 0.51 | 0.2 | 0.9 |
| Minimum: | 3,362.0 | 0.0 | 3,362.0 | 105,300.0 | 354.0 | 0.42 | 0.2 | 0.7 |
| Maximum: | 4,364.5 | 1,544.2 | 5,814.8 | 105,300.0 | 612.3 | 0.74 | 0.4 | 1.2 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 08/11/2026 00:00 | 3,629.3 | 0.0 | 3,629.3 | 105,300.0 | 382.2 | 0.46 | 0.2 | 0.8 |
| 08/11/2026 01:00 | 3,381.9 | 0.0 | 3,381.9 | 105,300.0 | 356.1 | 0.43 | 0.2 | 0.7 |
| 08/11/2026 02:00 | 3,380.2 | 0.0 | 3,380.2 | 105,300.0 | 355.9 | 0.43 | 0.2 | 0.7 |
| 08/11/2026 03:00 | 3,381.7 | 0.0 | 3,381.7 | 105,300.0 | 356.1 | 0.43 | 0.2 | 0.7 |
| 08/11/2026 04:00 | 3,416.6 | 0.0 | 3,416.6 | 105,300.0 | 359.8 | 0.43 | 0.2 | 0.7 |
| 08/11/2026 05:00 | 3,626.9 | 0.0 | 3,626.9 | 105,300.0 | 381.9 | 0.46 | 0.2 | 0.8 |
| 08/11/2026 06:00 | 3,775.6 | 0.0 | 3,775.6 | 105,300.0 | 397.6 | 0.48 | 0.2 | 0.8 |
| 08/11/2026 07:00 | 3,397.2 | 0.0 | 3,397.2 | 105,300.0 | 357.7 | 0.43 | 0.2 | 0.7 |
| 08/11/2026 08:00 | 3,388.6 | 0.0 | 3,388.6 | 105,300.0 | 356.8 | 0.43 | 0.2 | 0.7 |
| 08/11/2026 09:00 | 3,388.0 | 0.0 | 3,388.0 | 105,300.0 | 356.8 | 0.43 | 0.2 | 0.7 |
| 08/11/2026 10:00 | 3,482.1 | 0.0 | 3,482.1 | 105,300.0 | 366.7 | 0.44 | 0.2 | 0.7 |
| 08/11/2026 11:00 | 4,083.8 | 0.0 | 4,083.8 | 105,300.0 | 430.0 | 0.52 | 0.3 | 0.9 |
| 08/11/2026 12:00 | 4,116.9 | 3.2 | 4,117.0 | 105,300.0 | 433.5 | 0.52 | 0.3 | 0.9 |
| 08/11/2026 13:00 | 4,341.2 | 773.1 | 5,114.3 | 105,300.0 | 538.5 | 0.65 | 0.3 | 1.1 |
| 08/11/2026 14:00 | 4,326.0 | 656.1 | 4,982.1 | 105,300.0 | 524.6 | 0.63 | 0.3 | 1.0 |
| 08/11/2026 15:00 | 4,307.4 | 628.4 | 4,935.8 | 105,300.0 | 519.7 | 0.62 | 0.3 | 1.0 |
| 08/11/2026 16:00 | 4,293.2 | 1,316.6 | 5,609.8 | 105,300.0 | 590.7 | 0.71 | 0.4 | 1.2 |
| 08/11/2026 17:00 | 4,309.8 | 1,683.0 | 5,992.8 | 105,300.0 | 631.0 | 0.76 | 0.4 | 1.3 |
| 08/11/2026 18:00 | 4,312.7 | 1,309.1 | 5,621.8 | 105,300.0 | 592.0 | 0.71 | 0.4 | 1.2 |
| 08/11/2026 19:00 | 4,334.0 | 1,256.6 | 5,590.6 | 105,300.0 | 588.7 | 0.71 | 0.4 | 1.2 |
| 08/11/2026 20:00 | 4,360.1 | 902.1 | 5,262.2 | 105,300.0 | 554.1 | 0.67 | 0.3 | 1.1 |
| 08/11/2026 21:00 | 4,093.0 | 2.4 | 4,093.0 | 105,300.0 | 431.0 | 0.52 | 0.3 | 0.9 |
| 08/11/2026 22:00 | 3,833.9 | 0.0 | 3,833.9 | 105,300.0 | 403.7 | 0.49 | 0.2 | 0.8 |
| 08/11/2026 23:00 | 3,447.6 | 0.0 | 3,447.6 | 105,300.0 | 363.0 | 0.44 | 0.2 | 0.7 |
| Average/Sum#: | 3,850.3 | 355.4 | 4,205.5 | 105,300.0 | 442.8 | 0.53 | 0.3 | 0.9 |
| Minimum: | 3,380.2 | 0.0 | 3,380.2 | 105,300.0 | 355.9 | 0.43 | 0.2 | 0.7 |
| Maximum: | 4,360.1 | 1,683.0 | 5,992.8 | 105,300.0 | 631.0 | 0.76 | 0.4 | 1.3 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |

# Fuel Gas and Emissions Daily Summary

## CT1

**From:** 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

**Generated:** 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

| Const. Value/Limit Tag: | | | | | | > 4.73 | > 1 | > 1.8 |
|---|---|---|---|---|---|---|---|---|
| | Unit CT1 GasFlow, _CT, 100scfh | Unit CT1 GasFlow, _DB, 100scfh | Unit CT1 GasFlowTotal, 100scfh | Unit CT1 GCVGas, BtuPer100scf | Unit CT1 HI, MBtuPerHr | Unit CT1 PM10_Norm, LbPerHr | Unit CT1 SO2_Norm, LbPerHr | Unit CT1 VOC_Norm, LbPerHr |
| | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) | 1 Hour(s) |
| 08/12/2026 00:00 | 3,372.3 | 0.0 | 3,372.3 | 105,300.0 | 355.1 | 0.43 | 0.2 | 0.7 |
| 08/12/2026 01:00 | 3,373.6 | 0.0 | 3,373.6 | 105,300.0 | 355.2 | 0.43 | 0.2 | 0.7 |
| 08/12/2026 02:00 | 3,375.6 | 0.0 | 3,375.6 | 105,300.0 | 355.5 | 0.43 | 0.2 | 0.7 |
| 08/12/2026 03:00 | 3,376.4 | 0.0 | 3,376.4 | 105,300.0 | 355.5 | 0.43 | 0.2 | 0.7 |
| 08/12/2026 04:00 | 3,697.2 | 0.0 | 3,697.2 | 105,300.0 | 389.3 | 0.47 | 0.2 | 0.8 |
| 08/12/2026 05:00 | 3,997.7 | 0.0 | 3,997.7 | 105,300.0 | 421.0 | 0.51 | 0.3 | 0.8 |
| 08/12/2026 06:00 | 3,372.5 | 0.0 | 3,372.5 | 105,300.0 | 355.1 | 0.43 | 0.2 | 0.7 |
| 08/12/2026 07:00 | 3,380.3 | 0.0 | 3,380.3 | 105,300.0 | 355.9 | 0.43 | 0.2 | 0.7 |
| 08/12/2026 08:00 | 3,382.9 | 0.0 | 3,382.9 | 105,300.0 | 356.2 | 0.43 | 0.2 | 0.7 |
| 08/12/2026 09:00 | 3,379.6 | 0.0 | 3,379.6 | 105,300.0 | 355.9 | 0.43 | 0.2 | 0.7 |
| 08/12/2026 10:00 | 3,378.6 | 0.0 | 3,378.6 | 105,300.0 | 355.8 | 0.43 | 0.2 | 0.7 |
| 08/12/2026 11:00 | 3,387.3 | 0.0 | 3,387.3 | 105,300.0 | 356.7 | 0.43 | 0.2 | 0.7 |
| 08/12/2026 12:00 | 3,416.6 | 0.0 | 3,416.6 | 105,300.0 | 359.8 | 0.43 | 0.2 | 0.7 |
| 08/12/2026 13:00 | 4,303.7 | 457.5 | 4,747.5 | 105,300.0 | 499.9 | 0.60 | 0.3 | 1.0 |
| 08/12/2026 14:00 | 4,311.2 | 453.2 | 4,764.4 | 105,300.0 | 501.7 | 0.60 | 0.3 | 1.0 |
| 08/12/2026 15:00 | 4,304.5 | 439.2 | 4,743.7 | 105,300.0 | 499.5 | 0.60 | 0.3 | 1.0 |
| 08/12/2026 16:00 | 4,291.8 | 450.3 | 4,742.1 | 105,300.0 | 499.3 | 0.60 | 0.3 | 1.0 |
| 08/12/2026 17:00 | 4,314.9 | 411.4 | 4,726.3 | 105,300.0 | 497.7 | 0.60 | 0.3 | 1.0 |
| 08/12/2026 18:00 | 4,329.7 | 382.0 | 4,711.7 | 105,300.0 | 496.1 | 0.60 | 0.3 | 1.0 |
| 08/12/2026 19:00 | 4,357.3 | 320.4 | 4,677.7 | 105,300.0 | 492.6 | 0.59 | 0.3 | 1.0 |
| 08/12/2026 20:00 | 4,317.7 | 368.1 | 4,685.8 | 105,300.0 | 493.4 | 0.59 | 0.3 | 1.0 |
| 08/12/2026 21:00 | 3,524.1 | 8.5 | 3,524.5 | 105,300.0 | 371.1 | 0.44 | 0.2 | 0.7 |
| 08/12/2026 22:00 | 3,365.3 | 0.0 | 3,365.3 | 105,300.0 | 354.4 | 0.43 | 0.2 | 0.7 |
| 08/12/2026 23:00 | 3,365.4 | 0.0 | 3,365.4 | 105,300.0 | 354.4 | 0.43 | 0.2 | 0.7 |
| Average/Sum#: | 3,736.5 | 137.1 | 3,872.7 | 105,300.0 | 407.8 | 0.49 | 0.2 | 0.8 |
| Minimum: | 3,365.3 | 0.0 | 3,365.3 | 105,300.0 | 354.4 | 0.43 | 0.2 | 0.7 |
| Maximum: | 4,357.3 | 457.5 | 4,764.4 | 105,300.0 | 501.7 | 0.60 | 0.3 | 1.0 |
| %SI | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |