DOCKETED	
Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	273248
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q3 2026 - Part 26s
Description:	N/A
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public Agency
Submission Date:	10/28/2026 7:52:54 AM
Docketed Date:	10/28/2026

CT5_CT6_Fuel_DailySummary

CT5_CT6_Fuel_DailySummary

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/13/2026 12:18 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT5 GasFlow, 100scfh 1 Hour(s)	Unit CT6 GasFlow, 100scfh 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
09/08/2026 00:00	0.0	0.0	0	0
09/08/2026 01:00	0.0	0.0	0	0
09/08/2026 02:00	0.0	0.0	0	0
09/08/2026 03:00	0.0	0.0	0	0
09/08/2026 04:00	0.0	0.0	0	0
09/08/2026 05:00	0.0	0.0	0	0
09/08/2026 06:00	0.0	0.0	0	0
09/08/2026 07:00	0.0	0.0	0	0
09/08/2026 08:00	0.0	0.0	0	0
09/08/2026 09:00	0.0	0.0	0	0
09/08/2026 10:00	0.0	0.0	0	0
09/08/2026 11:00	0.0	0.0	0	0
09/08/2026 12:00	0.0	0.0	0	0
09/08/2026 13:00	0.0	0.0	0	0
09/08/2026 14:00	0.0	0.0	0	0
09/08/2026 15:00	0.0	0.0	0	0
09/08/2026 16:00	0.0	754.1	0	5
09/08/2026 17:00	0.0	2,189.3	0	22
09/08/2026 18:00	0.0	2,143.1	0	22
09/08/2026 19:00	0.0	2,138.2	0	22
09/08/2026 20:00	0.0	2,136.9	0	22
09/08/2026 21:00	0.0	2,121.3	0	22
09/08/2026 22:00	0.0	338.3	0	0
09/08/2026 23:00	0.0	0.0	0	0
Average/Sum#:	0.0 #	11,821.2 #	0 #	115 #
Minimum:	0.0	338.3	0	0
Maximum:	0.0	2,189.3	0	22
%SI	100.00	70.83	0.00	0.00

CT5_CT6_Fuel_DailySummary

CT5_CT6_Fuel_DailySummary

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/13/2026 12:18 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT5 GasFlow, 100scfh 1 Hour(s)	Unit CT6 GasFlow, 100scfh 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
09/09/2026 00:00	0.0	0.0	0	0
09/09/2026 01:00	0.0	0.0	0	0
09/09/2026 02:00	0.0	0.0	0	0
09/09/2026 03:00	0.0	0.0	0	0
09/09/2026 04:00	0.0	0.0	0	0
09/09/2026 05:00	0.0	0.0	0	0
09/09/2026 06:00	0.0	0.0	0	0
09/09/2026 07:00	0.0	0.0	0	0
09/09/2026 08:00	0.0	0.0	0	0
09/09/2026 09:00	0.0	0.0	0	0
09/09/2026 10:00	0.0	0.0	0	0
09/09/2026 11:00	1,211.1	381.2	10	1
09/09/2026 12:00	2,021.7	2,109.5	20	21
09/09/2026 13:00	1,793.0	2,064.4	17	21
09/09/2026 14:00	1,672.2	1,938.9	15	19
09/09/2026 15:00	1,663.1	1,847.0	15	18
09/09/2026 16:00	1,657.4	1,837.9	15	18
09/09/2026 17:00	1,654.0	1,758.8	15	17
09/09/2026 18:00	1,649.4	1,754.4	15	17
09/09/2026 19:00	1,647.8	1,751.4	15	17
09/09/2026 20:00	1,631.1	1,736.5	15	17
09/09/2026 21:00	358.4	369.6	0	0
09/09/2026 22:00	0.0	0.0	0	0
09/09/2026 23:00	0.0	0.0	0	0
Average/Sum#:	16,959.2 #	17,549.6 #	152 #	166 #
Minimum:	358.4	369.6	0	0
Maximum:	2,021.7	2,109.5	20	21
%SI	54.17	54.17	0.00	0.00

CT5_CT6_Fuel_DailySummary

CT5_CT6_Fuel_DailySummary

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/13/2026 12:18 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT5 GasFlow, 100scfh 1 Hour(s)	Unit CT6 GasFlow, 100scfh 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
09/10/2026 00:00	0.0	0.0	0	0
09/10/2026 01:00	0.0	0.0	0	0
09/10/2026 02:00	0.0	0.0	0	0
09/10/2026 03:00	0.0	0.0	0	0
09/10/2026 04:00	0.0	0.0	0	0
09/10/2026 05:00	0.0	0.0	0	0
09/10/2026 06:00	0.0	0.0	0	0
09/10/2026 07:00	0.0	0.0	0	0
09/10/2026 08:00	0.0	0.0	0	0
09/10/2026 09:00	0.0	0.0	0	0
09/10/2026 10:00	0.0	0.0	0	0
09/10/2026 11:00	0.0	0.0	0	0
09/10/2026 12:00	0.0	0.0	0	0
09/10/2026 13:00	0.0	0.0	0	0
09/10/2026 14:00	0.0	0.0	0	0
09/10/2026 15:00	791.1	950.0	5	7
09/10/2026 16:00	1,666.7	1,612.8	15	15
09/10/2026 17:00	1,655.2	1,607.8	15	15
09/10/2026 18:00	1,651.1	1,603.0	15	15
09/10/2026 19:00	1,648.7	1,594.3	15	15
09/10/2026 20:00	1,647.2	338.3	15	0
09/10/2026 21:00	1,645.5	0.0	15	0
09/10/2026 22:00	1,643.7	0.0	15	0
09/10/2026 23:00	431.5	0.0	1	0
Average/Sum#:	12,780.7 #	7,706.2 #	111 #	67 #
Minimum:	431.5	338.3	0	0
Maximum:	1,666.7	1,612.8	15	15
%SI	62.50	75.00	0.00	0.00

CT5_CT6_Fuel_DailySummary

CT5_CT6_Fuel_DailySummary

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/13/2026 12:18 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT5 GasFlow, 100scfh 1 Hour(s)	Unit CT6 GasFlow, 100scfh 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
09/11/2026 00:00	0.0	0.0	0	0
09/11/2026 01:00	0.0	0.0	0	0
09/11/2026 02:00	0.0	0.0	0	0
09/11/2026 03:00	0.0	0.0	0	0
09/11/2026 04:00	0.0	0.0	0	0
09/11/2026 05:00	0.0	0.0	0	0
09/11/2026 06:00	0.0	0.0	0	0
09/11/2026 07:00	0.0	0.0	0	0
09/11/2026 08:00	0.0	0.0	0	0
09/11/2026 09:00	0.0	0.0	0	0
09/11/2026 10:00	0.0	0.0	0	0
09/11/2026 11:00	0.0	0.0	0	0
09/11/2026 12:00	0.0	0.0	0	0
09/11/2026 13:00	0.0	0.0	0	0
09/11/2026 14:00	0.0	0.0	0	0
09/11/2026 15:00	0.0	0.0	0	0
09/11/2026 16:00	0.0	0.0	0	0
09/11/2026 17:00	0.0	0.0	0	0
09/11/2026 18:00	0.0	0.0	0	0
09/11/2026 19:00	0.0	0.0	0	0
09/11/2026 20:00	0.0	0.0	0	0
09/11/2026 21:00	0.0	0.0	0	0
09/11/2026 22:00	0.0	0.0	0	0
09/11/2026 23:00	0.0	0.0	0	0
Average/Sum#:	0.0 #	0.0 #	0 #	0 #
Minimum:	0.0	0.0	0	0
Maximum:	0.0	0.0	0	0
%SI	100.00	100.00	0.00	0.00

CT5_CT6_Fuel_DailySummary

CT5_CT6_Fuel_DailySummary

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/13/2026 12:18 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT5 GasFlow, 100scfh 1 Hour(s)	Unit CT6 GasFlow, 100scfh 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
09/12/2026 00:00	0.0	0.0	0	0
09/12/2026 01:00	0.0	0.0	0	0
09/12/2026 02:00	0.0	0.0	0	0
09/12/2026 03:00	0.0	0.0	0	0
09/12/2026 04:00	0.0	0.0	0	0
09/12/2026 05:00	0.0	0.0	0	0
09/12/2026 06:00	0.0	0.0	0	0
09/12/2026 07:00	0.0	0.0	0	0
09/12/2026 08:00	0.0	0.0	0	0
09/12/2026 09:00	0.0	0.0	0	0
09/12/2026 10:00	0.0	0.0	0	0
09/12/2026 11:00	0.0	0.0	0	0
09/12/2026 12:00	0.0	0.0	0	0
09/12/2026 13:00	0.0	0.0	0	0
09/12/2026 14:00	0.0	0.0	0	0
09/12/2026 15:00	0.0	0.0	0	0
09/12/2026 16:00	0.0	0.0	0	0
09/12/2026 17:00	0.0	0.0	0	0
09/12/2026 18:00	0.0	0.0	0	0
09/12/2026 19:00	0.0	0.0	0	0
09/12/2026 20:00	0.0	0.0	0	0
09/12/2026 21:00	0.0	0.0	0	0
09/12/2026 22:00	0.0	0.0	0	0
09/12/2026 23:00	0.0	0.0	0	0
Average/Sum#:	0.0 #	0.0 #	0 #	0 #
Minimum:	0.0	0.0	0	0
Maximum:	0.0	0.0	0	0
%SI	100.00	100.00	0.00	0.00

CT5_CT6_Fuel_DailySummary

CT5_CT6_Fuel_DailySummary

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/13/2026 12:18 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT5 GasFlow, 100scfh 1 Hour(s)	Unit CT6 GasFlow, 100scfh 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
09/13/2026 00:00	0.0	0.0	0	0
09/13/2026 01:00	0.0	0.0	0	0
09/13/2026 02:00	0.0	0.0	0	0
09/13/2026 03:00	0.0	0.0	0	0
09/13/2026 04:00	0.0	0.0	0	0
09/13/2026 05:00	0.0	0.0	0	0
09/13/2026 06:00	0.0	0.0	0	0
09/13/2026 07:00	0.0	0.0	0	0
09/13/2026 08:00	0.0	0.0	0	0
09/13/2026 09:00	0.0	0.0	0	0
09/13/2026 10:00	0.0	0.0	0	0
09/13/2026 11:00	0.0	0.0	0	0
09/13/2026 12:00	0.0	0.0	0	0
09/13/2026 13:00	0.0	0.0	0	0
09/13/2026 14:00	0.0	0.0	0	0
09/13/2026 15:00	0.0	0.0	0	0
09/13/2026 16:00	0.0	0.0	0	0
09/13/2026 17:00	0.0	0.0	0	0
09/13/2026 18:00	0.0	0.0	0	0
09/13/2026 19:00	0.0	0.0	0	0
09/13/2026 20:00	0.0	0.0	0	0
09/13/2026 21:00	0.0	0.0	0	0
09/13/2026 22:00	0.0	0.0	0	0
09/13/2026 23:00	0.0	0.0	0	0
Average/Sum#:	0.0 #	0.0 #	0 #	0 #
Minimum:	0.0	0.0	0	0
Maximum:	0.0	0.0	0	0
%SI	100.00	100.00	0.00	0.00

CT5_CT6_Fuel_DailySummary

CT5_CT6_Fuel_DailySummary

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/13/2026 12:18 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT5 GasFlow, 100scfh 1 Hour(s)	Unit CT6 GasFlow, 100scfh 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
09/14/2026 00:00	0.0	0.0	0	0
09/14/2026 01:00	0.0	0.0	0	0
09/14/2026 02:00	0.0	0.0	0	0
09/14/2026 03:00	0.0	0.0	0	0
09/14/2026 04:00	0.0	0.0	0	0
09/14/2026 05:00	0.0	0.0	0	0
09/14/2026 06:00	0.0	0.0	0	0
09/14/2026 07:00	0.0	0.0	0	0
09/14/2026 08:00	0.0	0.0	0	0
09/14/2026 09:00	0.0	0.0	0	0
09/14/2026 10:00	0.0	0.0	0	0
09/14/2026 11:00	0.0	0.0	0	0
09/14/2026 12:00	0.0	0.0	0	0
09/14/2026 13:00	0.0	0.0	0	0
09/14/2026 14:00	0.0	0.0	0	0
09/14/2026 15:00	0.0	0.0	0	0
09/14/2026 16:00	0.0	0.0	0	0
09/14/2026 17:00	0.0	0.0	0	0
09/14/2026 18:00	0.0	0.0	0	0
09/14/2026 19:00	0.0	0.0	0	0
09/14/2026 20:00	0.0	0.0	0	0
09/14/2026 21:00	0.0	0.0	0	0
09/14/2026 22:00	0.0	0.0	0	0
09/14/2026 23:00	0.0	0.0	0	0
Average/Sum#:	0.0 #	0.0 #	0 #	0 #
Minimum:	0.0	0.0	0	0
Maximum:	0.0	0.0	0	0
%SI	100.00	100.00	0.00	0.00

CT5_CT6_Fuel_DailySummary

CT5_CT6_Fuel_DailySummary

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/13/2026 12:18 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT5 GasFlow, 100scfh 1 Hour(s)	Unit CT6 GasFlow, 100scfh 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
09/15/2026 00:00	0.0	0.0	0	0
09/15/2026 01:00	0.0	0.0	0	0
09/15/2026 02:00	0.0	0.0	0	0
09/15/2026 03:00	0.0	0.0	0	0
09/15/2026 04:00	0.0	0.0	0	0
09/15/2026 05:00	0.0	0.0	0	0
09/15/2026 06:00	0.0	0.0	0	0
09/15/2026 07:00	0.0	0.0	0	0
09/15/2026 08:00	0.0	0.0	0	0
09/15/2026 09:00	0.0	0.0	0	0
09/15/2026 10:00	0.0	0.0	0	0
09/15/2026 11:00	0.0	0.0	0	0
09/15/2026 12:00	0.0	0.0	0	0
09/15/2026 13:00	0.0	0.0	0	0
09/15/2026 14:00	0.0	0.0	0	0
09/15/2026 15:00	0.0	0.0	0	0
09/15/2026 16:00	0.0	0.0	0	0
09/15/2026 17:00	0.0	0.0	0	0
09/15/2026 18:00	0.0	0.0	0	0
09/15/2026 19:00	0.0	0.0	0	0
09/15/2026 20:00	0.0	0.0	0	0
09/15/2026 21:00	0.0	0.0	0	0
09/15/2026 22:00	0.0	0.0	0	0
09/15/2026 23:00	0.0	0.0	0	0
Average/Sum#:	0.0 #	0.0 #	0 #	0 #
Minimum:	0.0	0.0	0	0
Maximum:	0.0	0.0	0	0
%SI	100.00	100.00	0.00	0.00

CT5_CT6_Fuel_DailySummary

CT5_CT6_Fuel_DailySummary

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/13/2026 12:18 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT5 GasFlow, 100scfh 1 Hour(s)	Unit CT6 GasFlow, 100scfh 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
09/16/2026 00:00	0.0	0.0	0	0
09/16/2026 01:00	0.0	0.0	0	0
09/16/2026 02:00	0.0	0.0	0	0
09/16/2026 03:00	0.0	0.0	0	0
09/16/2026 04:00	0.0	0.0	0	0
09/16/2026 05:00	0.0	0.0	0	0
09/16/2026 06:00	0.0	0.0	0	0
09/16/2026 07:00	0.0	0.0	0	0
09/16/2026 08:00	0.0	0.0	0	0
09/16/2026 09:00	0.0	0.0	0	0
09/16/2026 10:00	0.0	0.0	0	0
09/16/2026 11:00	0.0	0.0	0	0
09/16/2026 12:00	0.0	0.0	0	0
09/16/2026 13:00	0.0	0.0	0	0
09/16/2026 14:00	0.0	0.0	0	0
09/16/2026 15:00	0.0	0.0	0	0
09/16/2026 16:00	0.0	0.0	0	0
09/16/2026 17:00	0.0	0.0	0	0
09/16/2026 18:00	0.0	0.0	0	0
09/16/2026 19:00	0.0	0.0	0	0
09/16/2026 20:00	0.0	0.0	0	0
09/16/2026 21:00	0.0	0.0	0	0
09/16/2026 22:00	0.0	0.0	0	0
09/16/2026 23:00	0.0	0.0	0	0
Average/Sum#:	0.0 #	0.0 #	0 #	0 #
Minimum:	0.0	0.0	0	0
Maximum:	0.0	0.0	0	0
%SI	100.00	100.00	0.00	0.00

CT5_CT6_Fuel_DailySummary

CT5_CT6_Fuel_DailySummary

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/13/2026 12:18 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT5 GasFlow, 100scfh 1 Hour(s)	Unit CT6 GasFlow, 100scfh 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
09/17/2026 00:00	0.0	0.0	0	0
09/17/2026 01:00	0.0	0.0	0	0
09/17/2026 02:00	0.0	0.0	0	0
09/17/2026 03:00	0.0	0.0	0	0
09/17/2026 04:00	0.0	0.0	0	0
09/17/2026 05:00	0.0	0.0	0	0
09/17/2026 06:00	0.0	0.0	0	0
09/17/2026 07:00	0.0	0.0	0	0
09/17/2026 08:00	0.0	0.0	0	0
09/17/2026 09:00	0.0	0.0	0	0
09/17/2026 10:00	0.0	0.0	0	0
09/17/2026 11:00	0.0	0.0	0	0
09/17/2026 12:00	0.0	0.0	0	0
09/17/2026 13:00	0.0	0.0	0	0
09/17/2026 14:00	0.0	0.0	0	0
09/17/2026 15:00	0.0	0.0	0	0
09/17/2026 16:00	0.0	0.0	0	0
09/17/2026 17:00	0.0	0.0	0	0
09/17/2026 18:00	0.0	0.0	0	0
09/17/2026 19:00	0.0	0.0	0	0
09/17/2026 20:00	0.0	0.0	0	0
09/17/2026 21:00	0.0	0.0	0	0
09/17/2026 22:00	0.0	0.0	0	0
09/17/2026 23:00	0.0	0.0	0	0
Average/Sum#:	0.0 #	0.0 #	0 #	0 #
Minimum:	0.0	0.0	0	0
Maximum:	0.0	0.0	0	0
%SI	100.00	100.00	0.00	0.00

CT5_CT6_Fuel_DailySummary

CT5_CT6_Fuel_DailySummary

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/13/2026 12:18 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT5 GasFlow, 100scfh 1 Hour(s)	Unit CT6 GasFlow, 100scfh 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
09/18/2026 00:00	0.0	0.0	0	0
09/18/2026 01:00	0.0	0.0	0	0
09/18/2026 02:00	0.0	0.0	0	0
09/18/2026 03:00	0.0	0.0	0	0
09/18/2026 04:00	0.0	0.0	0	0
09/18/2026 05:00	0.0	0.0	0	0
09/18/2026 06:00	0.0	0.0	0	0
09/18/2026 07:00	0.0	0.0	0	0
09/18/2026 08:00	0.0	0.0	0	0
09/18/2026 09:00	0.0	0.0	0	0
09/18/2026 10:00	0.0	0.0	0	0
09/18/2026 11:00	0.0	0.0	0	0
09/18/2026 12:00	0.0	0.0	0	0
09/18/2026 13:00	0.0	0.0	0	0
09/18/2026 14:00	0.0	0.0	0	0
09/18/2026 15:00	0.0	0.0	0	0
09/18/2026 16:00	0.0	0.0	0	0
09/18/2026 17:00	0.0	0.0	0	0
09/18/2026 18:00	0.0	0.0	0	0
09/18/2026 19:00	0.0	0.0	0	0
09/18/2026 20:00	0.0	0.0	0	0
09/18/2026 21:00	0.0	0.0	0	0
09/18/2026 22:00	0.0	0.0	0	0
09/18/2026 23:00	0.0	0.0	0	0
Average/Sum#:	0.0 #	0.0 #	0 #	0 #
Minimum:	0.0	0.0	0	0
Maximum:	0.0	0.0	0	0
%SI	100.00	100.00	0.00	0.00

CT5_CT6_Fuel_DailySummary

CT5_CT6_Fuel_DailySummary

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/13/2026 12:18 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT5 GasFlow, 100scfh 1 Hour(s)	Unit CT6 GasFlow, 100scfh 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
09/19/2026 00:00	0.0	0.0	0	0
09/19/2026 01:00	0.0	0.0	0	0
09/19/2026 02:00	0.0	0.0	0	0
09/19/2026 03:00	0.0	0.0	0	0
09/19/2026 04:00	0.0	0.0	0	0
09/19/2026 05:00	0.0	0.0	0	0
09/19/2026 06:00	0.0	0.0	0	0
09/19/2026 07:00	0.0	0.0	0	0
09/19/2026 08:00	0.0	0.0	0	0
09/19/2026 09:00	0.0	0.0	0	0
09/19/2026 10:00	0.0	0.0	0	0
09/19/2026 11:00	0.0	0.0	0	0
09/19/2026 12:00	0.0	0.0	0	0
09/19/2026 13:00	0.0	0.0	0	0
09/19/2026 14:00	0.0	0.0	0	0
09/19/2026 15:00	0.0	0.0	0	0
09/19/2026 16:00	0.0	0.0	0	0
09/19/2026 17:00	0.0	0.0	0	0
09/19/2026 18:00	0.0	0.0	0	0
09/19/2026 19:00	0.0	0.0	0	0
09/19/2026 20:00	0.0	0.0	0	0
09/19/2026 21:00	0.0	0.0	0	0
09/19/2026 22:00	0.0	0.0	0	0
09/19/2026 23:00	0.0	0.0	0	0
Average/Sum#:	0.0 #	0.0 #	0 #	0 #
Minimum:	0.0	0.0	0	0
Maximum:	0.0	0.0	0	0
%SI	100.00	100.00	0.00	0.00

CT5_CT6_Fuel_DailySummary

CT5_CT6_Fuel_DailySummary

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/13/2026 12:18 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT5 GasFlow, 100scfh 1 Hour(s)	Unit CT6 GasFlow, 100scfh 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
09/20/2026 00:00	0.0	0.0	0	0
09/20/2026 01:00	0.0	0.0	0	0
09/20/2026 02:00	0.0	0.0	0	0
09/20/2026 03:00	0.0	0.0	0	0
09/20/2026 04:00	0.0	0.0	0	0
09/20/2026 05:00	0.0	0.0	0	0
09/20/2026 06:00	0.0	0.0	0	0
09/20/2026 07:00	0.0	0.0	0	0
09/20/2026 08:00	0.0	0.0	0	0
09/20/2026 09:00	0.0	0.0	0	0
09/20/2026 10:00	0.0	0.0	0	0
09/20/2026 11:00	0.0	0.0	0	0
09/20/2026 12:00	0.0	0.0	0	0
09/20/2026 13:00	0.0	0.0	0	0
09/20/2026 14:00	0.0	0.0	0	0
09/20/2026 15:00	0.0	0.0	0	0
09/20/2026 16:00	0.0	0.0	0	0
09/20/2026 17:00	0.0	0.0	0	0
09/20/2026 18:00	0.0	0.0	0	0
09/20/2026 19:00	0.0	0.0	0	0
09/20/2026 20:00	0.0	0.0	0	0
09/20/2026 21:00	0.0	0.0	0	0
09/20/2026 22:00	0.0	0.0	0	0
09/20/2026 23:00	0.0	0.0	0	0
Average/Sum#:	0.0 #	0.0 #	0 #	0 #
Minimum:	0.0	0.0	0	0
Maximum:	0.0	0.0	0	0
%SI	100.00	100.00	0.00	0.00

CT5_CT6_Fuel_DailySummary

CT5_CT6_Fuel_DailySummary

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/13/2026 12:18 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT5 GasFlow, 100scfh 1 Hour(s)	Unit CT6 GasFlow, 100scfh 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
09/21/2026 00:00	0.0	0.0	0	0
09/21/2026 01:00	0.0	0.0	0	0
09/21/2026 02:00	0.0	0.0	0	0
09/21/2026 03:00	0.0	0.0	0	0
09/21/2026 04:00	0.0	0.0	0	0
09/21/2026 05:00	0.0	0.0	0	0
09/21/2026 06:00	0.0	0.0	0	0
09/21/2026 07:00	0.0	0.0	0	0
09/21/2026 08:00	0.0	0.0	0	0
09/21/2026 09:00	0.0	0.0	0	0
09/21/2026 10:00	0.0	0.0	0	0
09/21/2026 11:00	0.0	0.0	0	0
09/21/2026 12:00	0.0	0.0	0	0
09/21/2026 13:00	0.0	0.0	0	0
09/21/2026 14:00	0.0	0.0	0	0
09/21/2026 15:00	0.0	0.0	0	0
09/21/2026 16:00	0.0	0.0	0	0
09/21/2026 17:00	0.0	0.0	0	0
09/21/2026 18:00	0.0	0.0	0	0
09/21/2026 19:00	0.0	0.0	0	0
09/21/2026 20:00	0.0	0.0	0	0
09/21/2026 21:00	0.0	0.0	0	0
09/21/2026 22:00	0.0	0.0	0	0
09/21/2026 23:00	0.0	0.0	0	0
Average/Sum#:	0.0 #	0.0 #	0 #	0 #
Minimum:	0.0	0.0	0	0
Maximum:	0.0	0.0	0	0
%SI	100.00	100.00	0.00	0.00

CT5_CT6_Fuel_DailySummary

CT5_CT6_Fuel_DailySummary

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/13/2026 12:18 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT5 GasFlow, 100scfh 1 Hour(s)	Unit CT6 GasFlow, 100scfh 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
09/22/2026 00:00	0.0	0.0	0	0
09/22/2026 01:00	0.0	0.0	0	0
09/22/2026 02:00	0.0	0.0	0	0
09/22/2026 03:00	0.0	0.0	0	0
09/22/2026 04:00	0.0	0.0	0	0
09/22/2026 05:00	0.0	0.0	0	0
09/22/2026 06:00	0.0	0.0	0	0
09/22/2026 07:00	0.0	0.0	0	0
09/22/2026 08:00	0.0	0.0	0	0
09/22/2026 09:00	0.0	0.0	0	0
09/22/2026 10:00	0.0	0.0	0	0
09/22/2026 11:00	0.0	0.0	0	0
09/22/2026 12:00	0.0	0.0	0	0
09/22/2026 13:00	0.0	0.0	0	0
09/22/2026 14:00	0.0	0.0	0	0
09/22/2026 15:00	0.0	0.0	0	0
09/22/2026 16:00	0.0	0.0	0	0
09/22/2026 17:00	0.0	0.0	0	0
09/22/2026 18:00	0.0	0.0	0	0
09/22/2026 19:00	0.0	0.0	0	0
09/22/2026 20:00	0.0	0.0	0	0
09/22/2026 21:00	0.0	0.0	0	0
09/22/2026 22:00	0.0	0.0	0	0
09/22/2026 23:00	0.0	0.0	0	0
Average/Sum#:	0.0 #	0.0 #	0 #	0 #
Minimum:	0.0	0.0	0	0
Maximum:	0.0	0.0	0	0
%SI	100.00	100.00	0.00	0.00

CT5_CT6_Fuel_DailySummary

CT5_CT6_Fuel_DailySummary

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/13/2026 12:18 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT5 GasFlow, 100scfh 1 Hour(s)	Unit CT6 GasFlow, 100scfh 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
09/23/2026 00:00	0.0	0.0	0	0
09/23/2026 01:00	0.0	0.0	0	0
09/23/2026 02:00	0.0	0.0	0	0
09/23/2026 03:00	0.0	0.0	0	0
09/23/2026 04:00	0.0	0.0	0	0
09/23/2026 05:00	0.0	0.0	0	0
09/23/2026 06:00	0.0	0.0	0	0
09/23/2026 07:00	0.0	0.0	0	0
09/23/2026 08:00	0.0	0.0	0	0
09/23/2026 09:00	0.0	0.0	0	0
09/23/2026 10:00	0.0	0.0	0	0
09/23/2026 11:00	0.0	0.0	0	0
09/23/2026 12:00	0.0	0.0	0	0
09/23/2026 13:00	0.0	0.0	0	0
09/23/2026 14:00	0.0	0.0	0	0
09/23/2026 15:00	0.0	0.0	0	0
09/23/2026 16:00	0.0	0.0	0	0
09/23/2026 17:00	0.0	0.0	0	0
09/23/2026 18:00	0.0	0.0	0	0
09/23/2026 19:00	0.0	0.0	0	0
09/23/2026 20:00	0.0	0.0	0	0
09/23/2026 21:00	0.0	0.0	0	0
09/23/2026 22:00	0.0	0.0	0	0
09/23/2026 23:00	0.0	0.0	0	0
Average/Sum#:	0.0 #	0.0 #	0 #	0 #
Minimum:	0.0	0.0	0	0
Maximum:	0.0	0.0	0	0
%SI	100.00	100.00	0.00	0.00

CT5_CT6_Fuel_DailySummary

CT5_CT6_Fuel_DailySummary

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/13/2026 12:18 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT5 GasFlow, 100scfh 1 Hour(s)	Unit CT6 GasFlow, 100scfh 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
09/24/2026 00:00	0.0	0.0	0	0
09/24/2026 01:00	0.0	0.0	0	0
09/24/2026 02:00	0.0	0.0	0	0
09/24/2026 03:00	0.0	0.0	0	0
09/24/2026 04:00	0.0	0.0	0	0
09/24/2026 05:00	0.0	0.0	0	0
09/24/2026 06:00	0.0	0.0	0	0
09/24/2026 07:00	0.0	0.0	0	0
09/24/2026 08:00	0.0	0.0	0	0
09/24/2026 09:00	0.0	0.0	0	0
09/24/2026 10:00	0.0	0.0	0	0
09/24/2026 11:00	0.0	0.0	0	0
09/24/2026 12:00	0.0	0.0	0	0
09/24/2026 13:00	0.0	0.0	0	0
09/24/2026 14:00	0.0	0.0	0	0
09/24/2026 15:00	0.0	0.0	0	0
09/24/2026 16:00	0.0	0.0	0	0
09/24/2026 17:00	0.0	0.0	0	0
09/24/2026 18:00	0.0	0.0	0	0
09/24/2026 19:00	0.0	0.0	0	0
09/24/2026 20:00	0.0	0.0	0	0
09/24/2026 21:00	0.0	0.0	0	0
09/24/2026 22:00	0.0	0.0	0	0
09/24/2026 23:00	0.0	0.0	0	0
Average/Sum#:	0.0 #	0.0 #	0 #	0 #
Minimum:	0.0	0.0	0	0
Maximum:	0.0	0.0	0	0
%SI	100.00	100.00	0.00	0.00

CT5_CT6_Fuel_DailySummary

CT5_CT6_Fuel_DailySummary

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/13/2026 12:18 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT5 GasFlow, 100scfh 1 Hour(s)	Unit CT6 GasFlow, 100scfh 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
09/25/2026 00:00	0.0	0.0	0	0
09/25/2026 01:00	0.0	0.0	0	0
09/25/2026 02:00	0.0	0.0	0	0
09/25/2026 03:00	0.0	0.0	0	0
09/25/2026 04:00	0.0	0.0	0	0
09/25/2026 05:00	0.0	0.0	0	0
09/25/2026 06:00	0.0	0.0	0	0
09/25/2026 07:00	0.0	0.0	0	0
09/25/2026 08:00	0.0	0.0	0	0
09/25/2026 09:00	0.0	0.0	0	0
09/25/2026 10:00	0.0	0.0	0	0
09/25/2026 11:00	0.0	0.0	0	0
09/25/2026 12:00	0.0	0.0	0	0
09/25/2026 13:00	0.0	0.0	0	0
09/25/2026 14:00	0.0	0.0	0	0
09/25/2026 15:00	0.0	0.0	0	0
09/25/2026 16:00	0.0	0.0	0	0
09/25/2026 17:00	0.0	0.0	0	0
09/25/2026 18:00	0.0	0.0	0	0
09/25/2026 19:00	0.0	0.0	0	0
09/25/2026 20:00	0.0	0.0	0	0
09/25/2026 21:00	0.0	0.0	0	0
09/25/2026 22:00	0.0	0.0	0	0
09/25/2026 23:00	0.0	0.0	0	0
Average/Sum#:	0.0 #	0.0 #	0 #	0 #
Minimum:	0.0	0.0	0	0
Maximum:	0.0	0.0	0	0
%SI	100.00	100.00	0.00	0.00

CT5_CT6_Fuel_DailySummary

CT5_CT6_Fuel_DailySummary

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/13/2026 12:18 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT5 GasFlow, 100scfh 1 Hour(s)	Unit CT6 GasFlow, 100scfh 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
09/26/2026 00:00	0.0	0.0	0	0
09/26/2026 01:00	0.0	0.0	0	0
09/26/2026 02:00	0.0	0.0	0	0
09/26/2026 03:00	0.0	0.0	0	0
09/26/2026 04:00	0.0	0.0	0	0
09/26/2026 05:00	0.0	0.0	0	0
09/26/2026 06:00	0.0	0.0	0	0
09/26/2026 07:00	0.0	0.0	0	0
09/26/2026 08:00	0.0	0.0	0	0
09/26/2026 09:00	0.0	0.0	0	0
09/26/2026 10:00	0.0	0.0	0	0
09/26/2026 11:00	0.0	0.0	0	0
09/26/2026 12:00	0.0	0.0	0	0
09/26/2026 13:00	0.0	0.0	0	0
09/26/2026 14:00	0.0	0.0	0	0
09/26/2026 15:00	0.0	0.0	0	0
09/26/2026 16:00	0.0	0.0	0	0
09/26/2026 17:00	0.0	0.0	0	0
09/26/2026 18:00	0.0	0.0	0	0
09/26/2026 19:00	0.0	0.0	0	0
09/26/2026 20:00	0.0	0.0	0	0
09/26/2026 21:00	0.0	0.0	0	0
09/26/2026 22:00	0.0	0.0	0	0
09/26/2026 23:00	0.0	0.0	0	0
Average/Sum#:	0.0 #	0.0 #	0 #	0 #
Minimum:	0.0	0.0	0	0
Maximum:	0.0	0.0	0	0
%SI	100.00	100.00	0.00	0.00

CT5_CT6_Fuel_DailySummary

CT5_CT6_Fuel_DailySummary

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/13/2026 12:18 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT5 GasFlow, 100scfh 1 Hour(s)	Unit CT6 GasFlow, 100scfh 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
09/27/2026 00:00	0.0	0.0	0	0
09/27/2026 01:00	0.0	0.0	0	0
09/27/2026 02:00	0.0	0.0	0	0
09/27/2026 03:00	0.0	0.0	0	0
09/27/2026 04:00	0.0	0.0	0	0
09/27/2026 05:00	0.0	0.0	0	0
09/27/2026 06:00	0.0	0.0	0	0
09/27/2026 07:00	0.0	0.0	0	0
09/27/2026 08:00	0.0	0.0	0	0
09/27/2026 09:00	0.0	0.0	0	0
09/27/2026 10:00	0.0	0.0	0	0
09/27/2026 11:00	0.0	0.0	0	0
09/27/2026 12:00	0.0	0.0	0	0
09/27/2026 13:00	0.0	0.0	0	0
09/27/2026 14:00	0.0	0.0	0	0
09/27/2026 15:00	0.0	0.0	0	0
09/27/2026 16:00	0.0	0.0	0	0
09/27/2026 17:00	0.0	0.0	0	0
09/27/2026 18:00	0.0	0.0	0	0
09/27/2026 19:00	0.0	0.0	0	0
09/27/2026 20:00	0.0	0.0	0	0
09/27/2026 21:00	0.0	0.0	0	0
09/27/2026 22:00	0.0	0.0	0	0
09/27/2026 23:00	0.0	0.0	0	0
Average/Sum#:	0.0 #	0.0 #	0 #	0 #
Minimum:	0.0	0.0	0	0
Maximum:	0.0	0.0	0	0
%SI	100.00	100.00	0.00	0.00

CT5_CT6_Fuel_DailySummary

CT5_CT6_Fuel_DailySummary

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/13/2026 12:18 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT5 GasFlow, 100scfh 1 Hour(s)	Unit CT6 GasFlow, 100scfh 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
09/28/2026 00:00	0.0	0.0	0	0
09/28/2026 01:00	0.0	0.0	0	0
09/28/2026 02:00	0.0	0.0	0	0
09/28/2026 03:00	0.0	0.0	0	0
09/28/2026 04:00	0.0	0.0	0	0
09/28/2026 05:00	0.0	0.0	0	0
09/28/2026 06:00	0.0	0.0	0	0
09/28/2026 07:00	0.0	0.0	0	0
09/28/2026 08:00	0.0	0.0	0	0
09/28/2026 09:00	0.0	0.0	0	0
09/28/2026 10:00	0.0	0.0	0	0
09/28/2026 11:00	0.0	0.0	0	0
09/28/2026 12:00	0.0	0.0	0	0
09/28/2026 13:00	0.0	0.0	0	0
09/28/2026 14:00	0.0	0.0	0	0
09/28/2026 15:00	0.0	0.0	0	0
09/28/2026 16:00	0.0	0.0	0	0
09/28/2026 17:00	0.0	0.0	0	0
09/28/2026 18:00	0.0	0.0	0	0
09/28/2026 19:00	0.0	0.0	0	0
09/28/2026 20:00	0.0	0.0	0	0
09/28/2026 21:00	0.0	0.0	0	0
09/28/2026 22:00	0.0	0.0	0	0
09/28/2026 23:00	0.0	0.0	0	0
Average/Sum#:	0.0 #	0.0 #	0 #	0 #
Minimum:	0.0	0.0	0	0
Maximum:	0.0	0.0	0	0
%SI	100.00	100.00	0.00	0.00

CT5_CT6_Fuel_DailySummary

CT5_CT6_Fuel_DailySummary

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/13/2026 12:18 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT5 GasFlow, 100scfh 1 Hour(s)	Unit CT6 GasFlow, 100scfh 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
09/29/2026 00:00	0.0	0.0	0	0
09/29/2026 01:00	0.0	0.0	0	0
09/29/2026 02:00	0.0	0.0	0	0
09/29/2026 03:00	0.0	0.0	0	0
09/29/2026 04:00	0.0	0.0	0	0
09/29/2026 05:00	0.0	0.0	0	0
09/29/2026 06:00	0.0	0.0	0	0
09/29/2026 07:00	0.0	0.0	0	0
09/29/2026 08:00	0.0	0.0	0	0
09/29/2026 09:00	0.0	0.0	0	0
09/29/2026 10:00	0.0	0.0	0	0
09/29/2026 11:00	0.0	0.0	0	0
09/29/2026 12:00	0.0	0.0	0	0
09/29/2026 13:00	0.0	0.0	0	0
09/29/2026 14:00	0.0	0.0	0	0
09/29/2026 15:00	0.0	0.0	0	0
09/29/2026 16:00	0.0	0.0	0	0
09/29/2026 17:00	0.0	0.0	0	0
09/29/2026 18:00	0.0	0.0	0	0
09/29/2026 19:00	0.0	0.0	0	0
09/29/2026 20:00	0.0	0.0	0	0
09/29/2026 21:00	0.0	0.0	0	0
09/29/2026 22:00	0.0	0.0	0	0
09/29/2026 23:00	0.0	0.0	0	0
Average/Sum#:	0.0 #	0.0 #	0 #	0 #
Minimum:	0.0	0.0	0	0
Maximum:	0.0	0.0	0	0
%SI	100.00	100.00	0.00	0.00

CT5_CT6_Fuel_DailySummary

CT5_CT6_Fuel_DailySummary

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/13/2026 12:18 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT5 GasFlow, 100scfh 1 Hour(s)	Unit CT6 GasFlow, 100scfh 1 Hour(s)	Unit CT5 Load, MWe 1 Hour(s)	Unit CT6 Load, MWe 1 Hour(s)
09/30/2026 00:00	0.0	0.0	0	0
09/30/2026 01:00	0.0	0.0	0	0
09/30/2026 02:00	0.0	0.0	0	0
09/30/2026 03:00	0.0	0.0	0	0
09/30/2026 04:00	0.0	0.0	0	0
09/30/2026 05:00	0.0	0.0	0	0
09/30/2026 06:00	0.0	0.0	0	0
09/30/2026 07:00	0.0	0.0	0	0
09/30/2026 08:00	0.0	0.0	0	0
09/30/2026 09:00	0.0	0.0	0	0
09/30/2026 10:00	0.0	0.0	0	0
09/30/2026 11:00	0.0	0.0	0	0
09/30/2026 12:00	0.0	0.0	0	0
09/30/2026 13:00	0.0	0.0	0	0
09/30/2026 14:00	0.0	0.0	0	0
09/30/2026 15:00	0.0	0.0	0	0
09/30/2026 16:00	0.0	0.0	0	0
09/30/2026 17:00	0.0	0.0	0	0
09/30/2026 18:00	0.0	0.0	0	0
09/30/2026 19:00	0.0	0.0	0	0
09/30/2026 20:00	0.0	0.0	0	0
09/30/2026 21:00	0.0	0.0	0	0
09/30/2026 22:00	0.0	0.0	0	0
09/30/2026 23:00	0.0	0.0	0	0
Average/Sum#:	0.0 #	0.0 #	0 #	0 #
Minimum:	0.0	0.0	0	0
Maximum:	0.0	0.0	0	0
%SI	100.00	100.00	0.00	0.00

CT5_Lbs_MonthlySummaryByDay

CT5_Lbs_MonthlySummaryByDay

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:03 **Location:** Roseville, CA

* = Excess Emission

	Unit CT5 CO, Lb 1 Hour(s)		Unit CT5 NOx, Lb 1 Hour(s)		Unit CT5 SO2, Lb 1 Hour(s)		Unit CT5 PM10, Lb 1 Hour(s)		Unit CT5 VOC, Lb 1 Hour(s)		Unit CT5 OperatingTime, Hr 1 Hour(s)	
Date	**Sum**	**Rolling Sum**	**Sum**	**Rolling Sum**	**Sum**	**Rolling Sum**	**Sum**	**Rolling Sum**	**Sum**	**Rolling Sum**	**Sum**	**Rolling Sum**
Jul 2026	15.07	311.83	43.70	785.81	2.76	49.59	5.40	92.91	9.23	165.09	18.69	319.26
Aug 2026	15.04	238.57	33.83	495.30	2.53	31.68	5.61	59.78	8.57	105.57	20.62	206.19
Sep 2026	7.70	170.66	25.82	388.81	1.67	23.89	3.36	45.37	5.76	79.79	16.48	162.44
Sum/Avg	170.66		388.81		23.89		45.37		79.79		162.44	
Limit												

CT6_Lbs_MonthlySummaryByDay

CT6_Lbs_MonthlySummaryByDay

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:10 **Location:** Roseville, CA

* = Excess Emission

	Unit CT6 CO, Lb 1 Hour(s)		Unit CT6 NOx, Lb 1 Hour(s)		Unit CT6 SO2, Lb 1 Hour(s)		Unit CT6 PM10, Lb 1 Hour(s)		Unit CT6 VOC, Lb 1 Hour(s)		Unit CT6 OperatingTime, Hr 1 Hour(s)	
Date	**Sum**	**Rolling Sum**	**Sum**	**Rolling Sum**	**Sum**	**Rolling Sum**	**Sum**	**Rolling Sum**	**Sum**	**Rolling Sum**	**Sum**	**Rolling Sum**
Jul 2026	17.95	266.30	47.92	713.00	3.38	50.20	6.80	93.75	11.25	167.75	23.21	321.30
Aug 2026	25.51	191.44	63.85	461.12	4.51	31.94	9.65	61.58	14.89	107.04	33.31	211.92
Sep 2026	8.49	165.96	31.18	410.39	2.14	28.68	4.33	55.67	7.22	96.25	18.70	195.39
Sum/Avg	165.96		410.39		28.68		55.67		96.25		195.39	
Limit												

Monthly Summary By Day Report

Units CT5 and CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/13/2026 12:17 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT5 & CT6 CO, Lb 1 Hour(s)	Units CT5 & CT6 NOx, Lb 1 Hour(s)	Units CT5 & CT6 SO2, Lb 1 Hour(s)	Units CT5 & CT6 PM10, Lb 1 Hour(s)	Units CT5 & CT6 VOC, Lb 1 Hour(s)	Unit CT5 OperatingTime, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
07/01/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
07/02/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
07/03/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
07/04/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
07/05/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
07/06/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
07/07/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
07/08/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
07/09/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
07/10/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
07/11/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
07/12/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
07/13/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
07/14/2026	3.19	10.67	0.63	1.17	2.12	4.18	0.18
07/15/2026	10.27	30.09	2.18	4.23	7.19	5.20	9.28
07/16/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
07/17/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
07/18/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
07/19/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
07/20/2026	9.78	24.19	1.52	3.15	5.07	4.06	6.50
07/21/2026	9.98	26.89	1.83	3.65	6.14	5.25	7.25
07/22/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
07/23/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
07/24/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
07/25/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
07/26/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
07/27/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
07/28/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
07/29/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
07/30/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
07/31/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum:	33.22 sum	91.84 sum	6.16 sum	12.20 sum	20.52 sum	18.69 sum	23.21 sum
Daily Min:	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Daily Max:	10.27	30.09	2.18	4.23	7.19	5.25	9.28
Jul 2026 - Jul 2026	33.22 sum	91.84 sum	6.16 sum	12.20 sum	20.52 sum	18.69 sum	23.21 sum
QTD:	33.22 sum	91.84 sum	6.16 sum	12.20 sum	20.52 sum	18.69 sum	23.21 sum
YTD 2026:	227.15 sum	532.31 sum	36.27 sum	67.93 sum	121.43 sum	109.80 sum	123.15 sum

Monthly Summary By Day Report

Units CT5 and CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/13/2026 12:17 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT5 & CT6 CO, Lb 1 Hour(s)	Units CT5 & CT6 NOx, Lb 1 Hour(s)	Units CT5 & CT6 SO2, Lb 1 Hour(s)	Units CT5 & CT6 PM10, Lb 1 Hour(s)	Units CT5 & CT6 VOC, Lb 1 Hour(s)	Unit CT5 OperatingTime, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
08/01/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
08/02/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
08/03/2026	4.48	11.60	0.85	1.82	2.80	0.00	6.23
08/04/2026	3.89	9.67	0.71	1.51	2.33	0.00	5.21
08/05/2026	5.55	12.46	0.82	1.78	2.73	0.20	6.00
08/06/2026	3.63	9.19	0.65	1.41	2.14	0.65	4.56
08/07/2026	0.74	1.41	0.26	0.52	0.87	2.23	0.00
08/08/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
08/09/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
08/10/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
08/11/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
08/12/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
08/13/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
08/14/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
08/15/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
08/16/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
08/17/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
08/18/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
08/19/2026	5.70	15.13	0.93	1.99	3.07	0.50	6.56
08/20/2026	5.31	11.58	0.96	2.11	3.24	7.33	0.00
08/21/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
08/22/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
08/23/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
08/24/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
08/25/2026	4.03	9.45	0.66	1.52	2.25	5.23	0.00
08/26/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
08/27/2026	4.94	12.13	0.81	1.69	2.70	1.35	4.75
08/28/2026	2.84	4.96	0.39	0.91	1.31	3.13	0.00
08/29/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
08/30/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
08/31/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum:	41.11 sum	97.58 sum	7.04 sum	15.26 sum	23.44 sum	20.62 sum	33.31 sum
Daily Min:	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Daily Max:	5.70	15.13	0.96	2.11	3.24	7.33	6.56
Jul 2026 - Aug 2026	74.33 sum	189.42 sum	13.20 sum	27.46 sum	43.96 sum	39.31 sum	56.52 sum
QTD:	74.33 sum	189.42 sum	13.20 sum	27.46 sum	43.96 sum	39.31 sum	56.52 sum
YTD 2026:	268.26 sum	629.89 sum	43.31 sum	83.19 sum	144.87 sum	130.42 sum	156.46 sum

Monthly Summary By Day Report

Units CT5 and CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/13/2026 12:17 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Units CT5 & CT6 CO, Lb 1 Hour(s)	Units CT5 & CT6 NOx, Lb 1 Hour(s)	Units CT5 & CT6 SO2, Lb 1 Hour(s)	Units CT5 & CT6 PM10, Lb 1 Hour(s)	Units CT5 & CT6 VOC, Lb 1 Hour(s)	Unit CT5 OperatingTime, Hr 1 Hour(s)	Unit CT6 OperatingTime, Hr 1 Hour(s)
09/01/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
09/02/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
09/03/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
09/04/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
09/05/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
09/06/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
09/07/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
09/08/2026	3.23	9.43	0.67	1.51	2.28	0.00	5.22
09/09/2026	8.36	30.11	2.03	3.93	6.84	9.23	9.23
09/10/2026	4.60	17.46	1.15	2.25	3.86	7.25	4.25
09/11/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
09/12/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
09/13/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
09/14/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
09/15/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
09/16/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
09/17/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
09/18/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
09/19/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
09/20/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
09/21/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
09/22/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
09/23/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
09/24/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
09/25/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
09/26/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
09/27/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
09/28/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
09/29/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
09/30/2026	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Monthly Avg/Sum:	16.19 sum	57.00 sum	3.85 sum	7.69 sum	12.98 sum	16.48 sum	18.70 sum
Daily Min:	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Daily Max:	8.36	30.11	2.03	3.93	6.84	9.23	9.23
Jul 2026 - Sep 2026	90.52 sum	246.42 sum	17.05 sum	35.15 sum	56.94 sum	55.79 sum	75.22 sum
QTD:	90.52 sum	246.42 sum	17.05 sum	35.15 sum	56.94 sum	55.79 sum	75.22 sum
YTD 2026:	284.45 sum	686.89 sum	47.16 sum	90.88 sum	157.85 sum	146.90 sum	175.16 sum

AQ-36 thru AQ-38, AQ-41, AQ-117, AQ-119, & AQ-140

AQ-36 thru AQ-38, AQ-41, AQ-117, AQ-119, & AQ-140:
PCAPCD notifications/corrective action: breakdowns,excess emissions, CEMS inoperable, or a negative declaration when no excess emissions occurred.

Verification: The Pro ject owner shall include the identification of all breakdowns, PCAPCD notification, resulting excess emission (if any) and corrective actions taken (if any) as part of the Quarterly Air Quality Report required in Condition of Certification AQ-SC6

Excess Emission Report

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/12/2026 13:17 **Location:** Roseville, CA

Tag Name: ALL_CO_Lb_1D
Total Operating Time: 92.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 0.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**92.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/12/2026 13:18 **Location:** Roseville, CA

Tag Name: ALL_NOx_Lb_1D
Total Operating Time: 92.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 0.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**92.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/12/2026 13:19 **Location:** Roseville, CA

Tag Name: ALL_PM10_Lb_1D
Total Operating Time: 92.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 0.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**92.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/12/2026 13:19 **Location:** Roseville, CA

Tag Name: ALL_SO2_Ton_1D
Total Operating Time: 92.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 0.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**92.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Excess Emission Report

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/12/2026 13:20 **Location:** Roseville, CA

Tag Name: ALL_VOC_Lb_1D
Total Operating Time: 92.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 0.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**92.00 Day(s)**
Total Duration (Online only):	**0.00 Day(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

| | | |

Year

2	0			-			

Non-Compliance Event Number

UPSET / BREAKDOWN AND EMERGENCY CHECKLIST

Company Name		Address	
Detection of Non-Compliance Event	Date	Time	☐ AM ☐ PM

Complete the following questions associated with determining whether an event is an "Upset/Breakdown" Event pursuant to Rule 404, and/or an "Emergency" Event pursuant to Rule 507. To be considered as a legitimate Upset / Breakdown or Emergency event, all of the checklist questions must be answered with a "Yes" checkmark.

Yes	No		
☐	☐	1.	Equipment associated with the breakdown event have been designed, maintained, and operated in a manner consistent with minimizing emissions.
☐	☐	2.	The amount and duration of emissions as a result of the event have been minimized.
☐	☐	3.	The event is not part of a recurring pattern of previous breakdowns of the same equipment for same/similar reasons that are indicative of inadequate equipment design, operation, or maintenance.
☐	☐	4.	The event is not the result of operator error, negligence, carelessness, or willful misconduct (i.e., the facility is being properly operated).
☐	☐	5.	The event is not the result of improper equipment design.
☐	☐	6.	The event is not the result of improper preventative maintenance of equipment.
☐	☐	7.	The event is the result of a sudden, unavoidable breakdown of equipment, beyond the control of the operator.
☐	☐	8.	The event could not have been foreseen or avoided or planned for, and could not have been avoided or prevented by better operating and maintenance practices.
☐	☐	9.	The event has not resulted in a nuisance.
☐	☐	10.	The event is not the result of the disregard of air pollution rules or regulations.
☐	☐	11.	This Upset / Breakdown form has been completed and submitted to the District in a timely manner -- within 7 calendar days from the end of the Non-Compliance Event.
☐	☐	12.	Immediate corrective actions have been taken to minimize emissions, as described in Item 11 on the Part I Non-Compliance Event Notification Form.

I certify under penalty of law that I am the responsible official for this facility, or his/her duly designated representative, and based on information and belief formed after reasonable inquiry, the statements and information in this document are true, accurate, and complete.

Signature _____

You are requesting that the District not take enforcement action because the Non-Compliance Event is the result of an "Upset / Breakdown" Event under District Rule 404. A breakdown condition means an unforeseeable failure or malfunction of 1) any air pollution control equipment or related operating equipment which causes a violation of any emission limitations or restriction prescribed by the District Rules and Regulations, or by State law, or 2) any in-stack continuous monitoring equipment, where such failure or malfunction: (1) is not the result of neglect or disregard of any air pollution control law or rule or regulation; (2) is not intentional or the result of negligence; (3) is not the result of improper maintenance; (4) does not constitute a nuisance; (5) is not a recurrent breakdown of the same equipment. You have the burden of providing sufficient information to demonstrate that the Upset / Breakdown was an unforeseeable equipment failure or malfunction that meets the above listed criteria. This checklist must be completed and returned to the District with either the Part 1 or Part II Non-Compliance Event Notification form to attest to your having made this determination. Submission of a request for shielding from enforcement action does not by itself confer such a shield. If breakdown or emission exceeding operations continue after the breakdown or emission exceedance is identified, the possibility exists that the District after consideration of the information provided, the timeliness and completeness of the submittals, and a comparison to other like breakdowns, may ultimately determine that the Non-Compliance Event was not the result of a legitimate Upset / Breakdown event and may elect to take enforcement action. Action to return to compliance should be accomplished as expeditiously as possible. Thus, you are advised to: (1) assure that the breakdown meets the criteria for an unforeseeable failure or malfunction; (2) minimize emissions resulting from the event to the maximum degree possible; and (3) assure that the required failure and malfunction information and information on the corrective actions taken is provided to the District in a complete and timely manner.

CITY OF ROSEVILLE CALIFORNIA

Memorandum

Roseville Electric - Generation

To: Bruce Springsteen, *Manager, Compliance and Enforcement, PCAPCD*
Heather Selvester, *Air Quality Specialist, PCAPCD*

From: Drew Yarbrough, *Power Plant Operations Supervisor*

Date: June 22nd, 2026

Subject: Non-Compliance Event Notification #2026-008 PART II

Bruce,

This memo provides supplemental details to the Non-Compliance Event Notification #2026-008.

The event occurred during a two-unit run on RPEAK CT5 and CT6.

Incident Summary:

- **Hour of Exceedance:** 16:00-19:59 (CEMS Time)
- **Shutdown of CT:** 19:50 (CEMS Time)
- **Event:** During startup of CT5 and CT6, CT6 failed to start, leading to distraction.
- **Response:** Exceedance went unnoticed, unit stayed online.

Emissions Impact:

On 7/14/26, CT5 and CT6 were dispatched for operation. Upon starting both Combustion Turbines, CT5 started successfully, and CT6 failed to start. The operator ramped CT5 to 28 MW and then began troubleshooting CT6's failure to run. Multiple attempts were made to restart CT6, requiring the Control Room Operator to divert their attention from the running unit to the restart efforts. Ultimately the On-Call Instrument and Controls Technician was called in to aid in the troubleshooting efforts. This event also took place during a high ambient temperature condition, which usually requires the CT's load to be reduced to maintain compliance. Due to the distraction of CT6, the Operator did not reduce CT5's load, resulting in excess NOx production and subsequent NH3 Slip. To further complicate matters, the CTs were dispatched just prior to shift turnover. Since the on-shift Control Room Operator did not notice the excess emissions, it was not turned over to the oncoming shift, who also began to troubleshoot CT6's failure to start, resulting in the continuation of excess emissions.

Follow-Up Actions:

1) CT6 failure to run was attributed to a corrupt control system file which has since been reloaded, and a successful test run has been completed.
2) Startup procedures have been revised to instruct the Control Room Operator to ramp the CT to 24MW instead of 28MW. This new load of 24MW is a more conservative operating profile for high ambient conditions that should allow us to maintain compliance.
3) During next training opportunity, the new startup procedure will be reviewed with the Operations staff, as well as the expectation that we will continually monitor emissions.

4) All future control logic changes or updates will be accompanied by a test run to ensure they have not introduced any failure modes.

5) We have instructed our power schedulers that, when possible, we would prefer to dispatch RPEAK earlier in the day around 1500, if they are scheduled to run later in the evening. This will allow more time for the Operators and Technicians to troubleshoot issues with more staff on site, and prior to shift turnover.

Drew Yarbrough



(916) 746-1656
dyarbrough@roseville.ca.us

	CT5_NOx_Ppmvdc_1M			CT5_NH3Inj_LbPerHr_1M			CT5_NH3Slip_Ppmvdc_1M			CT5_NH3Slip_Ppmvdc_1H			CT5_ExhaustFlow_LbPerHr_1M			CT5_GasFlow_kscfh_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/14/26 17:27	137.73	X		132.1			101.9	X					175994	X		256.8		
07/14/26 17:28	137.76	X		132.1			101.8	X					176190.5	X		257.1		
07/14/26 17:29	137.82	X		132.1			102.1	X					175535.3	X		256.1		
07/14/26 17:30	29.42	X		132.1			80.4	X					174880.1	X		255.2		
07/14/26 17:31	0.34	X		132.1			74.6	X					174618	X		254.8		
07/14/26 17:32	0.28	X		132.1			74.2	X					175338.7	X		255.8		
07/14/26 17:33	0.2	X		132.1			74	X					175731.9	X		256.4		
07/14/26 17:34	0.24	X		132.1			42.7	X					294042.8	X		256.6		
07/14/26 17:35	1.08	X		132.1			11.6	X					750109.2	X		256.6		
07/14/26 17:36	2.04	X		132.1			13.3	X					706570.3	X		256.5		
07/14/26 17:37	2.61	X		132.1			13.4	X					706833.7	X		256.6		
07/14/26 17:38	2.61	X		132.1			13.4	X					704463.5	X		255.7		
07/14/26 17:39	2.61			135.2			13.8						704726.9			255.8		
07/14/26 17:40	2.61			136.1			13.9						706833.7			256.6		
07/14/26 17:41	2.5			136.1			13.9						706833.7			256.6		
07/14/26 17:42	2.5			136.1			13.9						706570.3			256.5		
07/14/26 17:43	2.5			136.1			13.8						706833.7			256.6		
07/14/26 17:44	2.5			136.4			13.9						706570.3			256.5		
07/14/26 17:45	2.5			137.1			14.1						706043.6			256.3		
07/14/26 17:46	2.38			138.3			14.2						705253.6			256		
07/14/26 17:47	2.38			139.1			14.2						707887.1			257		
07/14/26 17:48	2.38			139.1			14.2						708413.8			257.2		
07/14/26 17:49	2.38			139.1			14.3						706570.3			256.5		
07/14/26 17:50	2.38			139.1			14.3						706307			256.4		
07/14/26 17:51	2.27			139.1			14.3						707360.4			256.8		
07/14/26 17:52	2.27			139.1			14.3						706570.3			256.5		
07/14/26 17:53	2.27			139.1			14.3						706307			256.4		
07/14/26 17:54	2.27			139.1			14.3						707623.7			256.9		
07/14/26 17:55	2.27			139.1			14.3						706833.7			256.6		
07/14/26 17:56	2.16			139.1			14.3						708940.5			257.4		
07/14/26 17:57	2.16			138			14.2						710520.6			257.9		
07/14/26 17:58	2.04			138.1			14.2						707623.7			256.9		
07/14/26 17:59	2.16			138.1			14.1						708677.1			257.3		
07/14/26 18:00	2.27			138			14			14.7			709203.8			257.5		
07/14/26 18:01	2.27			139			14.2						706043.6			256.3		

	CT5_NOx_Ppmvdc_1M			CT5_NH3Inj_LbPerHr_1M			CT5_NH3Slip_Ppmvdc_1M			CT5_NH3Slip_Ppmvdc_1H			CT5_ExhaustFlow_LbPerHr_1M			CT5_GasFlow_kscfh_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/14/26 18:02	2.27			139.1			14.2						705780.3			256.2		
07/14/26 18:03	2.27			139.1			14.1						707623.7			256.9		
07/14/26 18:04	2.27			139.1			14.1						707623.7			256.9		
07/14/26 18:05	2.38			139.1			14.1						709203.8			257.5		
07/14/26 18:06	2.38			139.1			14.2						707097			256.7		
07/14/26 18:07	2.38			141			14.4						707623.7			256.9		
07/14/26 18:08	2.38			141.1			14.4						708413.8			257.2		
07/14/26 18:09	2.38			141.1			14.3						708940.5			257.4		
07/14/26 18:10	2.38			141.1			14.4						707623.7			256.9		
07/14/26 18:11	2.38			141.1			14.3						707887.1			257		
07/14/26 18:12	2.38			141.9			14.5						707887.1			257		
07/14/26 18:13	2.38			142.1			14.5						709993.9			257.7		
07/14/26 18:14	2.38			142.5			14.6						709467.2			257.6		
07/14/26 18:15	2.38			144.1			14.8						709203.8			257.5		
07/14/26 18:16	2.38			144.1			14.9						708150.4			257.1		
07/14/26 18:17	2.27			144.1			14.9						708940.5			257.4		
07/14/26 18:18	2.27			144.1			14.9						708413.8			257.2		
07/14/26 18:19	2.27			144.1			14.9						710520.6			257.9		
07/14/26 18:20	2.27			144.1			14.9						709993.9			257.7		
07/14/26 18:21	2.27			144.1			14.9						709467.2			257.6		
07/14/26 18:22	2.27			144.1			14.9						708940.5			257.4		
07/14/26 18:23	2.16			144.1			14.8						711047.3			258.1		
07/14/26 18:24	2.27			144.1			14.8						711837.3			258.4		
07/14/26 18:25	2.27			144.1			14.8						712364			258.6		
07/14/26 18:26	2.27			144.7			14.9						711837.3			258.4		
07/14/26 18:27	2.27			146.1			15						712100.7			258.5		
07/14/26 18:28	2.27			145			14.9						710783.9			258		
07/14/26 18:29	2.27			145.7			15						712100.7			258.5		
07/14/26 18:30	2.27			146.1			15.1						712627.4			258.7		
07/14/26 18:31	2.27			146.1			15						713680.8			259.1		
07/14/26 18:32	2.16			146.1			15						713944.1			259.2		
07/14/26 18:33	2.27			146.1			15.1						713944.1			259.2		
07/14/26 18:34	2.27			145.9			15.1						712627.4			258.7		
07/14/26 18:35	2.27			144.1			14.8						713417.4			259		
07/14/26 18:36	2.27			144.1			14.8						714207.5			259.3		

	CT5_NOx_Ppmvdc_1M			CT5_NH3Inj_LbPerHr_1M			CT5_NH3Slip_Ppmvdc_1M			CT5_NH3Slip_Ppmvdc_1H			CT5_ExhaustFlow_LbPerHr_1M			CT5_GasFlow_kscfh_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/14/26 18:37	2.27			144.4			14.8						714207.5			259.3		
07/14/26 18:38	2.27			146.1			15						714997.5			259.6		
07/14/26 18:39	2.27			146.1			15						715260.9			259.7		
07/14/26 18:40	2.16			146.1			15						716050.9			259.9		
07/14/26 18:41	2.16			145.3			15						715787.6			259.8		
07/14/26 18:42	2.16			144.1			14.9						713944.1			259.2		
07/14/26 18:43	2.04			144.1			14.8						716841			260.2		
07/14/26 18:44	2.04			144.1			14.9						718684.5			260.9		
07/14/26 18:45	2.04			144.6			14.9						720527.9			261.6		
07/14/26 18:46	2.04			144.1			14.9						719737.9			261.3		
07/14/26 18:47	2.04			143.8			14.8						719474.5			261.2		
07/14/26 18:48	2.04			143.1			14.7						719211.2			261.1		
07/14/26 18:49	2.16			143.7			14.7						720791.3			261.7		
07/14/26 18:50	2.12			145.9			15.5						709775.2			262.6		
07/14/26 18:51	2.12			146.1			15.6						709775.2			262.6		
07/14/26 18:52	2.04			145.6			15						723161.4			262.5		
07/14/26 18:53	2.04			144.1			14.9						720001.2			261.4		
07/14/26 18:54	2.16			144.1			14.8						721844.7			262		
07/14/26 18:55	2.16			144.1			14.7						721318			261.9		
07/14/26 18:56	2.16			144.1			14.6						722634.7			262.3		
07/14/26 18:57	2.16			144.1			14.6						723688.1			262.7		
07/14/26 18:58	2.16			144.1			14.5						723951.5			262.8		
07/14/26 18:59	2.16			145.2			14.7						722898.1			262.4		
07/14/26 19:00	2.16			144.1			14.6			13.9			721844.7			262		
07/14/26 19:01	2.16			144.6			14.6						721844.7			262		
07/14/26 19:02	2.16			146.1			14.7						724214.8			262.9		
07/14/26 19:03	2.16			146.1			14.7						725531.6			263.4		
07/14/26 19:04	2.16			146.6			14.7						727111.7			264		
07/14/26 19:05	2.16			146.8			14.8						726058.3			263.6		
07/14/26 19:06	2.16			146.1			14.7						726321.6			263.7		
07/14/26 19:07	2.16			146.1			14.7						728428.4			264.4		
07/14/26 19:08	2.12			146.1			15.1						716493.2			265.1		
07/14/26 19:09	2.12			146.1			15.1						715459.6			264.7		
07/14/26 19:10	2.12			146.1			15.2						713392.6			264		
07/14/26 19:11	2.16			145.1			14.7						725004.9			263.2		

	CT5_NOx_Ppmvdc_1M			CT5_NH3Inj_LbPerHr_1M			CT5_NH3Slip_Ppmvdc_1M			CT5_NH3Slip_Ppmvdc_1H			CT5_ExhaustFlow_LbPerHr_1M			CT5_GasFlow_kscfh_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/14/26 19:12	2.16			144.1			14.5						724478.2			263		
07/14/26 19:13	2.16			143.2			14.4						723424.8			262.6		
07/14/26 19:14	2.16			143.9			14.4						729745.2			264.9		
07/14/26 19:15	2.12			144.1			14.9						716493.2			265.1		
07/14/26 19:16	2.12			145.9			15						722694.3			267.4		
07/14/26 19:17	2.12			146.1			15						722436			267.3		
07/14/26 19:18	2.12			144.4			14.8						722177.6			267.2		
07/14/26 19:19	2.12			145.7			14.9						726053.3			268.6		
07/14/26 19:20	2.12			146.1			15.1						719593.8			266.3		
07/14/26 19:21	2.23			146.1			15.2						716751.6			265.2		
07/14/26 19:22	2.12			146.1			15.2						717526.7			265.5		
07/14/26 19:23	2.12			146.1			15.2						716751.6			265.2		
07/14/26 19:24	2.12			144.8			15						715976.4			264.9		
07/14/26 19:25	2.12			145.2			14.9						720110.5			266.4		
07/14/26 19:26	2.23			146.1			15						721919.2			267.1		
07/14/26 19:27	2.23			146.1			15						724244.6			268		
07/14/26 19:28	2.23			146.1			14.9						727603.6			269.2		
07/14/26 19:29	2.23			146.1			15						725019.8			268.3		
07/14/26 19:30	2.23			146.1			15						724244.6			268		
07/14/26 19:31	2.23			146.1			14.9						728378.7			269.5		
07/14/26 19:32	2.12			146.1			15						727086.8			269		
07/14/26 19:33	2.12			146.1			15						725794.9			268.5		
07/14/26 19:34	2.23			146.1			15.1						723727.9			267.8		
07/14/26 19:35	2.12			146.1			15.2						719335.4			266.2		
07/14/26 19:36	2.12			145.4			15.1						718301.8			265.8		
07/14/26 19:37	2.16			145.1			14.6						731588.6			265.6		
07/14/26 19:38	2.12			144.9			15						717268.3			265.4		
07/14/26 19:39	2.16			144.3			14.4						731325.3			265.5		
07/14/26 19:40	2.04			143.1			14.3						732115.3			265.8		
07/14/26 19:41	2.04			143.1			14.2						733958.8			266.4		
07/14/26 19:42	2			143.1			14.7						720627.3			266.6		
07/14/26 19:43	2			142.8			14.6						721144			266.8		
07/14/26 19:44	2			142			14.5						720885.7			266.7		
07/14/26 19:45	2.04			142.1			14.1						735275.6			266.9		
07/14/26 19:46	2.04			120.8			11.2						736065.6			267.2		

	CT5_NOx_Ppmvdc_1M			CT5_NH3Inj_LbPerHr_1M			CT5_NH3Slip_Ppmvdc_1M			CT5_NH3Slip_Ppmvdc_1H			CT5_ExhaustFlow_LbPerHr_1M			CT5_GasFlow_kscfh_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/14/26 19:47	7.59			0			0						2732979.8			267.1		
07/14/26 19:48	1.4			0			0						0			267.2		
07/14/26 19:49	0.8			0			0						0			44.6		
07/14/26 19:50	0.3			0			0						0			0.1		
07/14/26 19:51	0.2			0			0						0			0.1		
07/14/26 19:52	0.2			0			0						0			0.1		
07/14/26 19:53	0.1			0			0						0			0.1		
07/14/26 19:54	0.1			0			0						0			0.1		
07/14/26 19:55	0.1			0			0						0			0.1		
07/14/26 19:56	0.1			0			0						0			0.1		
07/14/26 19:57	0.1			0			0						0			0.1		
07/14/26 19:58	0.1			0			0						0			0.1		
07/14/26 19:59	0.1			0			0						0			0.1		
07/14/26 20:00	0.1			0			0			0.2			0			0.1		

Year: | | | | Non-Compliance Event Number: 2026 009

Placer County
110 Maple Street, Auburn, CA 95603 • (530) 745-2330 • Fax (530) 745-2373 • www.placer.ca.gov/apcd
Erik C. White, Air Pollution Control Officer

NON-COMPLIANCE EVENT NOTIFICATION FORM – PART I

submit within 2 business hours after detection of the Non-Compliance Event

1.	**Company Name**	ROSEVILLE ENERGY PARK - RPEAK			**Address**	5120 PHILLIP ROAD, ROSEVILLE, CA.			
2.	**Title V Source Status**	**Major** Yes ☒ No ☐			**Synthetic Minor** Yes ☐ No ☒				
3.	**For Title V Sources, is the Non-Compliance Event the Result of an Emergency under District Rule 507, Section 402.2(I)**							Yes ☐ No ☒	
4.	**Emission Exceedances**	NOx ☒	SOx ☐	PM ☐	VOC ☐	CO ☐	Opacity ☐	None ☐	check all that apply
5.	**CEMS / COMS / CMS Breakdown**	Yes ☐ No ☒							
6.	**Detection of Non-Compliance Event**	**Date** 7/14/26		**Time** 17:00		☐ AM ☒ PM			
7.	**Start of Non-Compliance Event**	**Date** 7/14/26		**Time** 16:00		☐ AM ☒ PM ☐ Not known			
8.	**Violation**	**Permit No.** REPR-20-03	**Condition No.** 34 b iii	**Rule**	**Section**				
9.	**Unit / Equipment Involved**	CT5							
10.	**Description / Cause of Non-Compliance Event**	**NOx PPMVDC Exceedance**				☒ additional information attached			
11.	**Immediate Corrective Actions**	**Troubleshooting in progress**				☐ additional information attached			
12.	**Was the Non-Compliance Event an Emission Violation or Monitoring Equipment Failure or Malfunction** Yes ☐ No ☐ **If yes, do you Request that the Violation, Failure or Malfunction be Shielded from Enforcement Action as an Upset / Breakdown Pursuant to District Rule 404**								
	Yes ☐	No ☐	Not Able to Determine at this Time ☒			If "Yes", complete and submit the Upset / Breakdown Checklist Form with Part I			
13.	**Submitted By**	Drew Yarbrough				**Telephone** (916) 746 - 1656			
	Signature			**Date** 7/15/26	**Time** 08:00	☒ AM ☐ PM			

NON-COMPLIANCE EVENT NOTIFICATION FORM – PART II

submit within 7 calendar days after end of the Non-Compliance Event

14.	**End of Non-Compliance Event**	**Date** 7/14/26	**Time** 16:59 & ~~20:50~~ 20:35 PM	☐ AM ☒ PM		
15.	**Duration of Non-Compliance Event**	**Hours** 3	5 ~~50~~ **Minutes**			
16.	**Excess Emissions Estimates**	NOx 0.1, 14.6 PPMVDC	SOx	PM		
	VOC	CO	Opacity	%, for	minutes	Other
17.	**Variance in Effect**	Yes ☐ Variance #		No ☒		
18.	**Corrective and Preventative Actions Taken**	**(a) Minimize Emissions**	**(b) Correct Event**	**(c) Prevent Future Events**	☒ additional information attached	
19.	**If Not Able to Determine in Item 12 of Part I, Was the Non-Compliance Event an Emission Violation or Monitoring Equipment Failure or Malfunction** **If yes, do you Request that the Violation, Failure or Malfunction be Shielded from Enforcement Action as an Upset / Breakdown Under District Rule 404**					
	Yes ☐	No ☒	If "Yes", complete and submit the Upset / Breakdown Checklist Form if not previously submitted with Part I			
20.	**Submitted By**	DREW YARBROUGH	**Telephone**	(916) 746-1656		

I certify under penalty of law that I am the responsible official for this facility, or his/her duly designated representative, and based on information and belief formed after reasonable inquiry, the statements and information in this document are true, accurate, and complete.

Signature **Date** 7/22/26 **Time** 13:00 ☐ AM ☒ PM

Year

2	0			-			

Non-Compliance Event Number

UPSET / BREAKDOWN AND EMERGENCY CHECKLIST

Company Name		Address	
Detection of Non-Compliance Event	Date	Time	☐ AM ☐ PM

Complete the following questions associated with determining whether an event is an "Upset/Breakdown" Event pursuant to Rule 404, and/or an "Emergency" Event pursuant to Rule 507. To be considered as a legitimate Upset / Breakdown or Emergency event, all of the checklist questions must be answered with a "Yes" checkmark.

Yes	No		
☐	☐	1.	Equipment associated with the breakdown event have been designed, maintained, and operated in a manner consistent with minimizing emissions.
☐	☐	2.	The amount and duration of emissions as a result of the event have been minimized.
☐	☐	3.	The event is not part of a recurring pattern of previous breakdowns of the same equipment for same/similar reasons that are indicative of inadequate equipment design, operation, or maintenance.
☐	☐	4.	The event is not the result of operator error, negligence, carelessness, or willful misconduct (i.e., the facility is being properly operated).
☐	☐	5.	The event is not the result of improper equipment design.
☐	☐	6.	The event is not the result of improper preventative maintenance of equipment.
☐	☐	7.	The event is the result of a sudden, unavoidable breakdown of equipment, beyond the control of the operator.
☐	☐	8.	The event could not have been foreseen or avoided or planned for, and could not have been avoided or prevented by better operating and maintenance practices.
☐	☐	9.	The event has not resulted in a nuisance.
☐	☐	10.	The event is not the result of the disregard of air pollution rules or regulations.
☐	☐	11.	This Upset / Breakdown form has been completed and submitted to the District in a timely manner -- within 7 calendar days from the end of the Non-Compliance Event.
☐	☐	12.	Immediate corrective actions have been taken to minimize emissions, as described in Item 11 on the Part I Non-Compliance Event Notification Form.

I certify under penalty of law that I am the responsible official for this facility, or his/her duly designated representative, and based on information and belief formed after reasonable inquiry, the statements and information in this document are true, accurate, and complete.

Signature _____

You are requesting that the District not take enforcement action because the Non-Compliance Event is the result of an "Upset / Breakdown" Event under District Rule 404. A breakdown condition means an unforeseeable failure or malfunction of 1) any air pollution control equipment or related operating equipment which causes a violation of any emission limitations or restriction prescribed by the District Rules and Regulations, or by State law, or 2) any in-stack continuous monitoring equipment, where such failure or malfunction: (1) is not the result of neglect or disregard of any air pollution control law or rule or regulation; (2) is not intentional or the result of negligence; (3) is not the result of improper maintenance; (4) does not constitute a nuisance; (5) is not a recurrent breakdown of the same equipment. You have the burden of providing sufficient information to demonstrate that the Upset / Breakdown was an unforeseeable equipment failure or malfunction that meets the above listed criteria. This checklist must be completed and returned to the District with either the Part 1 or Part II Non-Compliance Event Notification form to attest to your having made this determination. Submission of a request for shielding from enforcement action does not by itself confer such a shield. If breakdown or emission exceeding operations continue after the breakdown or emission exceedance is identified, the possibility exists that the District after consideration of the information provided, the timeliness and completeness of the submittals, and a comparison to other like breakdowns, may ultimately determine that the Non-Compliance Event was not the result of a legitimate Upset / Breakdown event and may elect to take enforcement action. Action to return to compliance should be accomplished as expeditiously as possible. Thus, you are advised to: (1) assure that the breakdown meets the criteria for an unforeseeable failure or malfunction; (2) minimize emissions resulting from the event to the maximum degree possible; and (3) assure that the required failure and malfunction information and information on the corrective actions taken is provided to the District in a complete and timely manner.

CITY OF ROSEVILLE CALIFORNIA

Memorandum

Roseville Electric - Generation

To: Bruce Springsteen, *Manager, Compliance and Enforcement, PCAPCD*
Heather Selvester, *Air Quality Specialist, PCAPCD*

From: Drew Yarbrough, *Power Plant Operations Supervisor*

Date: June 22nd, 2026

Subject: Non-Compliance Event Notification #2026-009 PART II

Bruce,

This memo provides supplemental details to the Non-Compliance Event Notification #2026-009.

The event occurred during a two-unit run on RPEAK CT5 and CT6.

Incident Summary:

- **Hour of Exceedance:** 16:00-16:59 and 20:00-20:59 (CEMS Time)
- **Shutdown of CT:** 19:50 and 20:35 (CEMS Time)
- **Event:** During startup of CT5 and CT6, CT6 failed to start, leading to distraction.
- **Response:** Exceedance went unnoticed, unit stayed online. Unit shutdown during second run due to startup bit clearance.

Emissions Impact:

On 7/14/26, CT5 and CT6 were dispatched for operation. Upon starting both Combustion Turbines, CT5 started successfully, and CT6 failed to start. The operator ramped CT5 to 28 MW and then began troubleshooting CT6's failure to run. Multiple attempts were made to restart CT6, requiring the Control Room Operator to divert their attention from the running unit to the restart efforts. Ultimately the On-Call Instrument and Controls Technician was called in to aid in the troubleshooting efforts. This event also took place during a high ambient temperature condition, which usually requires the CT's load to be reduced to maintain compliance. Due to the distraction of CT6, the Operator did not reduce CT5's load, resulting in excess NOx production and subsequent NH3 Slip. To further complicate matters, the CTs were dispatched just prior to shift turnover. Since the on-shift Control Room Operator did not notice the excess emissions, it was not turned over to the oncoming shift, who also began to troubleshoot CT6's failure to start, resulting in the continuation of excess emissions.

At 19:50 CT5 tripped as a result of the troubleshooting effort on CT6. While attempting to clear the corrupted control system file from CT6, the control system files on CT5 were inadvertently reloaded, causing a turbine trip. After the turbine trip, the Control Room Operator attempted to restart CT5 at 20:24, but for an unknown reason at this time, the "startup" signal to the CEMS cleared after only 3 minutes of operation and prior to the unit coming into compliance. The operator shutdown the unit to prevent further excess emissions.

Follow-Up Actions:

1) CT6 failure to run was attributed to a corrupt control system file which has since been reloaded, and a successful test run has been completed.

2) Startup procedures have been revised to instruct the Control Room Operator to ramp the CT to 24MW instead of 28MW. This new load of 24MW is a more conservative operating profile for high ambient conditions that should allow us to maintain compliance.

3) During next training opportunity, the new startup procedure will be reviewed with the Operations staff, as well as the expectation that we will continually monitor emissions.

4) All future control logic changes or updates will be accompanied by a test run to ensure they have not introduced any failure modes.

5) We have instructed our power schedulers that, when possible, we would prefer to dispatch RPEAK earlier in the day around 1500, if they are scheduled to run later in the evening. This will allow more time for the Operators and Technicians to troubleshoot issues with more staff on site, and prior to shift turnover.

6) We will need to further troubleshoot the reason for the startup signal loss to the CEMS which happened during the restart attempt.

Drew Yarbrough



(916) 746-1656
dyarbrough@roseville.ca.us

NOx Ppmvdc 1-Hour Block Excess Emissions

CT5

From: 07/14/2026 00:00 **To:** 07/14/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 07/15/2026 05:10 **Location:** Roseville, CA

Tag Name: CT5_NOx_Norm_Ppmvdc_1H
Total Operating Time: 6.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 18.00 Hour(s) Report Time: 24.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Tag Value	Limit	Reason Code	Action Code
1	07/14/26 16:00	07/14/26 16:59	1	2.6	2.5		
2	07/14/26 20:00	07/14/26 20:59	1	17.1	2.5		

Total Operating Time:	**6.00 Hour(s)**
Total Duration (Online only):	**2.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**33.33 %**
Time in compliance as a percentage of operating time:	**66.67 %**

Sample Spreadsheet Listing

NOx PPM 1600 & 2000

	CT5_NOx_Ppmvdc_1M			CT5_NOx_Ppmvdc_1H			CT5_WaterInj_GPM_1M			CT5_NH3Inj_LbPerHr_1M			CT5_NH3Slip_Ppmvdc_1M			CT5_Load_MWe_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/14/26 15:45	0						0			0			0			0		
07/14/26 15:46	0						0			0			0			0		
07/14/26 15:47	0						0			0			0			0		
07/14/26 15:48	0						0			0			0			0		
07/14/26 15:49	0						0			0			0			0		
07/14/26 15:50	0						0			0			0			0		
07/14/26 15:51	0						1			0			0			0		
07/14/26 15:52	3.75						1.8			0			0			0		
07/14/26 15:53	25.4						2.2			0			0			0		
07/14/26 15:54	28.82						0			0			0			0		
07/14/26 15:55	29.5						0			0			0			0		
07/14/26 15:56	29.75						0			0			0			0.1		
07/14/26 15:57	35.63						0.8			1.3			-1.6			5		
07/14/26 15:58	46.79						8.2			43.8			10.1			12		
07/14/26 15:59	16.45						21.7			71.5			9.3			20.9		
07/14/26 16:00	1.75			2.6			29.8			101.4			12.7			26.2		
07/14/26 16:01	1.52						29.3			101.1			13.3			26.2		
07/14/26 16:02	1.7						28.7			100.4			13.2			26.1		
07/14/26 16:03	2.27						28.4			100.1			12.8			26.2		
07/14/26 16:04	3.37						28			100.1			12.3			26.2		
07/14/26 16:05	4.37						27.5			100.1			10.9			26.1		
07/14/26 16:06	4.18						27.4			100.2			10.1			26.2		
07/14/26 16:07	3.17						27.3			93.6			8.9			26.3		
07/14/26 16:08	2.67						26.9			88.1			7.9			26.1		
07/14/26 16:09	2.95						26.6			90.6			8			26.1		
07/14/26 16:10	3.52						26.5			98.9			9.2			26.2		
07/14/26 16:11	3.4						26.7			103.1			9.6			26.4		
07/14/26 16:12	2.95						26.9			100.7			9.2			26.5		
07/14/26 16:13	2.61						26.6			97.5			8.8			26.4		
07/14/26 16:14	2.61						26.6			97.7			8.8			26.4		
07/14/26 16:15	2.84						26.6			100.3			9.3			26.2		
07/14/26 16:16	2.95						26.4			104.1			9.8			26.2		

	CT5_NOx_Ppmvdc_1M			CT5_NOx_Ppmvdc_1H			CT5_WaterInj_GPM_1M			CT5_NH3Inj_LbPerHr_1M			CT5_NH3Slip_Ppmvdc_1M			CT5_Load_MWe_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/14/26 16:17	2.89						26.4			105.8			9.6			26.2		
07/14/26 16:18	2.89						26.5			106.1			9.6			26.3		
07/14/26 16:19	2.61						26.6			106.1			9.9			26.4		
07/14/26 16:20	2.5						26.7			106.1			10			26.4		
07/14/26 16:21	2.55						26.5			106.1			9.7			26.3		
07/14/26 16:22	2.61						26.8			106.1			10			26.4		
07/14/26 16:23	2.72						26.8			108.5			10.3			26.5		
07/14/26 16:24	2.72						26.8			110.5			10.6			26.5		
07/14/26 16:25	2.5						27			109.3			10.5			26.6		
07/14/26 16:26	2.27						27			108.2			10.4			26.7		
07/14/26 16:27	2.27						27			109.1			10.5			26.6		
07/14/26 16:28	2.38						26.8			109.1			10.6			26.5		
07/14/26 16:29	2.38						27.3			109.8			10.5			26.7		
07/14/26 16:30	2.5						27.9			112.1			10.7			27		
07/14/26 16:31	2.38						27.6			110.3			10.7			26.8		
07/14/26 16:32	2.27						27.4			109.3			10.6			26.7		
07/14/26 16:33	2.38						27.2			111.2			10.8			26.6		
07/14/26 16:34	2.61						26.7			112.1			10.8			26.4		
07/14/26 16:35	2.61						26.6			114.5			11.1			26.5		
07/14/26 16:36	2.61						26.7			115			11.2			26.5		
07/14/26 16:37	2.5						26.5			115			11.2			26.5		
07/14/26 16:38	2.61						26.7			116.6			11.3			26.6		
07/14/26 16:39	2.61						26.6			117.7			11.4			26.5		
07/14/26 16:40	2.61						26.4			119.1			11.6			26.4		
07/14/26 16:41	2.61						26.4			118.8			11.7			26.4		
07/14/26 16:42	2.5						26.5			118.1			11.5			26.5		
07/14/26 16:43	2.5						26.5			120			11.8			26.4		
07/14/26 16:44	2.5						26.5			120.1			11.7			26.5		
07/14/26 16:45	2.5						26.8			120.1			11.7			26.7		
07/14/26 16:46	2.5						26.8			121.1			11.8			26.6		
07/14/26 16:47	2.5						26.6			122.1			12.1			26.5		
07/14/26 16:48	2.5						26.9			122.1			12			26.6		
07/14/26 16:49	2.38						26.8			122.1			12.1			26.5		
07/14/26 16:50	2.38						26.5			122.1			12.2			26.4		
07/14/26 16:51	2.38						26.5			122.1			12.1			26.4		

	CT5_NOx_Ppmvdc_1M			CT5_NOx_Ppmvdc_1H			CT5_WaterInj_GPM_1M			CT5_NH3Inj_LbPerHr_1M			CT5_NH3Slip_Ppmvdc_1M			CT5_Load_MWe_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/14/26 16:52	2.5						26.4			123.8			12.4			26.4		
07/14/26 16:53	2.38						26.5			124.4			12.5			26.4		
07/14/26 16:54	2.38						26.8			124.3			12.4			26.5		
07/14/26 16:55	2.38						27			124.1			12.3			26.5		
07/14/26 16:56	2.38						26.8			125.3			12.5			26.5		
07/14/26 16:57	2.5						26.6			127.1			12.8			26.5		
07/14/26 16:58	2.38						26.6			127.1			12.8			26.4		
07/14/26 16:59	2.38						26.4			127.1			12.8			26.5		
07/14/26 17:00	2.38			2.4			26.3			127.1			12.8			26.5		
07/14/26 17:01	2.38						26.3			127.1			12.7			26.5		
07/14/26 17:02	2.38						26.6			127.3			12.6			26.7		
07/14/26 17:03	2.5						26.7			129.1			12.9			26.7		
07/14/26 17:04	2.5						26.9			129.1			12.9			26.7		
07/14/26 17:05	2.38						26.7			129.1			13			26.5		
07/14/26 17:06	2.38						26.7			129.1			13			26.5		
07/14/26 17:07	2.5						26.9			130.6			13.2			26.6		
07/14/26 17:08	2.5						26.9			131.1			13.2			26.5		
07/14/26 17:09	2.38						26.5			131.1			13.3			26.4		
07/14/26 17:10	2.38						26.7			131.1			13.2			26.5		
07/14/26 17:11	2.38						26.6			131.8			13.4			26.4		
07/14/26 17:12	2.38						26.7			133.1			13.5			26.5		
07/14/26 17:13	2.27						26.6			133.1			13.5			26.5		
07/14/26 17:14	2.95	X					26.8			133.1			7.5	X		26.6		
07/14/26 17:15	1.5	X					26.6			133.1			0	X		26.5		
07/14/26 17:16	0.7	X					26.7			133.1			0	X		26.6		
07/14/26 17:17	0	X					26.6			133.1			0	X		26.5		
07/14/26 17:18	0	X					26.6			133.1			0	X		26.5		
07/14/26 17:19	0.73	X					26.6			133.1			19.2	X		26.4		
07/14/26 17:20	2.57	X					26.7			133.1			75.1	X		26.6		
07/14/26 17:21	2.71	X					26.8			132.9			74.8	X		26.6		
07/14/26 17:22	2.71	X					26.6			132.1			74.5	X		26.6		
07/14/26 17:23	2.71	X					26.8			132.1			74.3	X		26.7		
07/14/26 17:24	2.74	X					26.7			132.1			74.3	X		26.6		
07/14/26 17:25	85.45	X					27.1			132.1			90.7	X		26.8		
07/14/26 17:26	137.79	X					27			132.1			101.5	X		26.8		

	CT5_NOx_Ppmvdc_1M			CT5_NOx_Ppmvdc_1H			CT5_WaterInj_GPM_1M			CT5_NH3Inj_LbPerHr_1M			CT5_NH3Slip_Ppmvdc_1M			CT5_Load_MWe_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/14/26 17:27	137.73	X					26.6			132.1			101.9	X		26.6		
07/14/26 17:28	137.76	X					26.7			132.1			101.8	X		26.7		
07/14/26 17:29	137.82	X					26.4			132.1			102.1	X		26.5		
07/14/26 17:30	29.42	X					26.4			132.1			80.4	X		26.4		
07/14/26 17:31	0.34	X					26.2			132.1			74.6	X		26.4		
07/14/26 17:32	0.28	X					26.4			132.1			74.2	X		26.5		
07/14/26 17:33	0.2	X					26.6			132.1			74	X		26.6		
07/14/26 17:34	0.24	X					26.6			132.1			42.7	X		26.6		
07/14/26 17:35	1.08	X					26.5			132.1			11.6	X		26.6		
07/14/26 17:36	2.04	X					26.6			132.1			13.3	X		26.6		
07/14/26 17:37	2.61	X					26.5			132.1			13.4	X		26.6		
07/14/26 17:38	2.61	X					26.4			132.1			13.4	X		26.5		
07/14/26 17:39	2.61						26.4			135.2			13.8			26.5		
07/14/26 17:40	2.61						26.5			136.1			13.9			26.6		
07/14/26 17:41	2.5						26.5			136.1			13.9			26.6		
07/14/26 17:42	2.5						26.5			136.1			13.9			26.6		
07/14/26 17:43	2.5						26.5			136.1			13.8			26.6		
07/14/26 17:44	2.5						26.6			136.4			13.9			26.6		
07/14/26 17:45	2.5						26.4			137.1			14.1			26.5		
07/14/26 17:46	2.38						26.4			138.3			14.2			26.5		
07/14/26 17:47	2.38						26.5			139.1			14.2			26.7		
07/14/26 17:48	2.38						26.5			139.1			14.2			26.7		
07/14/26 17:49	2.38						26.4			139.1			14.3			26.6		
07/14/26 17:50	2.38						26.4			139.1			14.3			26.6		
07/14/26 17:51	2.27						26.5			139.1			14.3			26.6		
07/14/26 17:52	2.27						26.5			139.1			14.3			26.6		
07/14/26 17:53	2.27						26.5			139.1			14.3			26.6		
07/14/26 17:54	2.27						26.7			139.1			14.3			26.7		
07/14/26 17:55	2.27						26.5			139.1			14.3			26.6		
07/14/26 17:56	2.16						26.6			139.1			14.3			26.7		
07/14/26 17:57	2.16						26.7			138			14.2			26.8		
07/14/26 17:58	2.04						26.4			138.1			14.2			26.6		
07/14/26 17:59	2.16						26.5			138.1			14.1			26.7		
07/14/26 18:00	2.27			2.2			26.3			138			14			26.8		
07/14/26 18:01	2.27						26.2			139			14.2			26.6		

	CT5_NOx_Ppmvdc_1M			CT5_NOx_Ppmvdc_1H			CT5_WaterInj_GPM_1M			CT5_NH3Inj_LbPerHr_1M			CT5_NH3Slip_Ppmvdc_1M			CT5_Load_MWe_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/14/26 18:02	2.27						26.1			139.1			14.2			26.6		
07/14/26 18:03	2.27						26.4			139.1			14.1			26.7		
07/14/26 18:04	2.27						26.5			139.1			14.1			26.7		
07/14/26 18:05	2.38						26.5			139.1			14.1			26.8		
07/14/26 18:06	2.38						26.4			139.1			14.2			26.7		
07/14/26 18:07	2.38						26.3			141			14.4			26.7		
07/14/26 18:08	2.38						26.3			141.1			14.4			26.7		
07/14/26 18:09	2.38						26.5			141.1			14.3			26.7		
07/14/26 18:10	2.38						26.4			141.1			14.4			26.7		
07/14/26 18:11	2.38						26.3			141.1			14.3			26.7		
07/14/26 18:12	2.38						26.4			141.9			14.5			26.7		
07/14/26 18:13	2.38						26.6			142.1			14.5			26.8		
07/14/26 18:14	2.38						26.5			142.5			14.6			26.8		
07/14/26 18:15	2.38						26.8			144.1			14.8			26.8		
07/14/26 18:16	2.38						26.6			144.1			14.9			26.7		
07/14/26 18:17	2.27						26.7			144.1			14.9			26.7		
07/14/26 18:18	2.27						26.8			144.1			14.9			26.7		
07/14/26 18:19	2.27						26.9			144.1			14.9			26.8		
07/14/26 18:20	2.27						26.8			144.1			14.9			26.8		
07/14/26 18:21	2.27						26.9			144.1			14.9			26.8		
07/14/26 18:22	2.27						26.8			144.1			14.9			26.7		
07/14/26 18:23	2.16						26.9			144.1			14.8			26.8		
07/14/26 18:24	2.27						26.9			144.1			14.8			26.9		
07/14/26 18:25	2.27						27			144.1			14.8			26.9		
07/14/26 18:26	2.27						26.8			144.7			14.9			26.9		
07/14/26 18:27	2.27						26.9			146.1			15			26.9		
07/14/26 18:28	2.27						26.8			145			14.9			26.8		
07/14/26 18:29	2.27						26.9			145.7			15			26.9		
07/14/26 18:30	2.27						26.9			146.1			15.1			26.9		
07/14/26 18:31	2.27						27.1			146.1			15			27		
07/14/26 18:32	2.16						27.1			146.1			15			27		
07/14/26 18:33	2.27						27.1			146.1			15.1			27		
07/14/26 18:34	2.27						27			145.9			15.1			26.9		
07/14/26 18:35	2.27						27			144.1			14.8			27		
07/14/26 18:36	2.27						27.1			144.1			14.8			27		

	CT5_NOx_Ppmvdc_1M			CT5_NOx_Ppmvdc_1H			CT5_WaterInj_GPM_1M			CT5_NH3Inj_LbPerHr_1M			CT5_NH3Slip_Ppmvdc_1M			CT5_Load_MWe_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/14/26 18:37	2.27						27.1			144.4			14.8			27		
07/14/26 18:38	2.27						27.1			146.1			15			27.1		
07/14/26 18:39	2.27						27.2			146.1			15			27.1		
07/14/26 18:40	2.16						27.2			146.1			15			27.1		
07/14/26 18:41	2.16						27.3			145.3			15			27.1		
07/14/26 18:42	2.16						27.1			144.1			14.9			27		
07/14/26 18:43	2.04						27.3			144.1			14.8			27.1		
07/14/26 18:44	2.04						27.4			144.1			14.9			27.2		
07/14/26 18:45	2.04						27.5			144.6			14.9			27.3		
07/14/26 18:46	2.04						27.5			144.1			14.9			27.3		
07/14/26 18:47	2.04						27.4			143.8			14.8			27.2		
07/14/26 18:48	2.04						27.4			143.1			14.7			27.2		
07/14/26 18:49	2.16						27.4			143.7			14.7			27.3		
07/14/26 18:50	2.12						27.6			145.9			15.5			27.4		
07/14/26 18:51	2.12						27.6			146.1			15.6			27.4		
07/14/26 18:52	2.04						27.5			145.6			15			27.4		
07/14/26 18:53	2.04						27.3			144.1			14.9			27.3		
07/14/26 18:54	2.16						27.4			144.1			14.8			27.4		
07/14/26 18:55	2.16						27.3			144.1			14.7			27.4		
07/14/26 18:56	2.16						27.4			144.1			14.6			27.5		
07/14/26 18:57	2.16						27.5			144.1			14.6			27.5		
07/14/26 18:58	2.16						27.5			144.1			14.5			27.5		
07/14/26 18:59	2.16						27.3			145.2			14.7			27.5		
07/14/26 19:00	2.16			2.2			27.3			144.1			14.6			27.4		
07/14/26 19:01	2.16						27.3			144.6			14.6			27.4		
07/14/26 19:02	2.16						27.4			146.1			14.7			27.6		
07/14/26 19:03	2.16						27.4			146.1			14.7			27.6		
07/14/26 19:04	2.16						27.5			146.6			14.7			27.7		
07/14/26 19:05	2.16						27.5			146.8			14.8			27.6		
07/14/26 19:06	2.16						27.6			146.1			14.7			27.6		
07/14/26 19:07	2.16						27.7			146.1			14.7			27.7		
07/14/26 19:08	2.12						27.8			146.1			15.1			27.8		
07/14/26 19:09	2.12						27.8			146.1			15.1			27.7		
07/14/26 19:10	2.12						27.7			146.1			15.2			27.7		
07/14/26 19:11	2.16						27.5			145.1			14.7			27.5		

	CT5_NOx_Ppmvdc_1M			CT5_NOx_Ppmvdc_1H			CT5_WaterInj_GPM_1M			CT5_NH3Inj_LbPerHr_1M			CT5_NH3Slip_Ppmvdc_1M			CT5_Load_MWe_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/14/26 19:12	2.16						27.6			144.1			14.5			27.5		
07/14/26 19:13	2.16						27.4			143.2			14.4			27.5		
07/14/26 19:14	2.16						27.8			143.9			14.4			27.8		
07/14/26 19:15	2.12						27.8			144.1			14.9			27.8		
07/14/26 19:16	2.12						28.4			145.9			15			28		
07/14/26 19:17	2.12						28.4			146.1			15			28		
07/14/26 19:18	2.12						28.4			144.4			14.8			28		
07/14/26 19:19	2.12						28.6			145.7			14.9			28.2		
07/14/26 19:20	2.12						28.1			146.1			15.1			27.9		
07/14/26 19:21	2.23						27.9			146.1			15.2			27.8		
07/14/26 19:22	2.12						27.9			146.1			15.2			27.8		
07/14/26 19:23	2.12						27.8			146.1			15.2			27.8		
07/14/26 19:24	2.12						27.7			144.8			15			27.7		
07/14/26 19:25	2.12						27.9			145.2			14.9			27.9		
07/14/26 19:26	2.23						28.1			146.1			15			28		
07/14/26 19:27	2.23						28.1			146.1			15			28.1		
07/14/26 19:28	2.23						28.3			146.1			14.9			28.3		
07/14/26 19:29	2.23						28.2			146.1			15			28.1		
07/14/26 19:30	2.23						28.1			146.1			15			28.1		
07/14/26 19:31	2.23						28.5			146.1			14.9			28.3		
07/14/26 19:32	2.12						28.5			146.1			15			28.2		
07/14/26 19:33	2.12						28.2			146.1			15			28.2		
07/14/26 19:34	2.23						28.1			146.1			15.1			28.1		
07/14/26 19:35	2.12						27.9			146.1			15.2			27.9		
07/14/26 19:36	2.12						27.9			145.4			15.1			27.8		
07/14/26 19:37	2.16						27.7			145.1			14.6			27.8		
07/14/26 19:38	2.12						27.7			144.9			15			27.8		
07/14/26 19:39	2.16						27.8			144.3			14.4			27.8		
07/14/26 19:40	2.04						27.8			143.1			14.3			27.8		
07/14/26 19:41	2.04						27.9			143.1			14.2			27.9		
07/14/26 19:42	2						27.9			143.1			14.7			27.9		
07/14/26 19:43	2						27.9			142.8			14.6			27.9		
07/14/26 19:44	2						27.9			142			14.5			27.9		
07/14/26 19:45	2.04						28.2			142.1			14.1			28		
07/14/26 19:46	2.04						28.1			120.8			11.2			28		

	CT5_NOx_Ppmvdc_1M			CT5_NOx_Ppmvdc_1H			CT5_WaterInj_GPM_1M			CT5_NH3Inj_LbPerHr_1M			CT5_NH3Slip_Ppmvdc_1M			CT5_Load_MWe_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/14/26 19:47	7.59						28.2			0			0			28		
07/14/26 19:48	1.4						28.2			0			0			28		
07/14/26 19:49	0.8						4.7			0			0			4.7		
07/14/26 19:50	0.3						0			0			0			0		
07/14/26 19:51	0.2						0			0			0			0		
07/14/26 19:52	0.2						0			0			0			0		
07/14/26 19:53	0.1						0			0			0			0		
07/14/26 19:54	0.1						0			0			0			0		
07/14/26 19:55	0.1						0			0			0			0		
07/14/26 19:56	0.1						0			0			0			0		
07/14/26 19:57	0.1						0			0			0			0		
07/14/26 19:58	0.1						0			0			0			0		
07/14/26 19:59	0.1						0			0			0			0		
07/14/26 20:00	0.1			17.1			0			0			0			0		
07/14/26 20:01	0.1						0			0			0			0		
07/14/26 20:02	0.1						0			0			0			0		
07/14/26 20:03	0.1						0			0			0			0		
07/14/26 20:04	0						0			0			0			0		
07/14/26 20:05	0						0			0			0			0		
07/14/26 20:06	0.1						0			0			0			0		
07/14/26 20:07	0						0			0			0			0		
07/14/26 20:08	0						0			0			0			0		
07/14/26 20:09	0						0			0			0			0		
07/14/26 20:10	0						0			0			0			0		
07/14/26 20:11	0						0			0			0			0		
07/14/26 20:12	0						0			0			0			0		
07/14/26 20:13	0						0			0			0			0		
07/14/26 20:14	0						0			0			0			0		
07/14/26 20:15	0						0			0			0			0		
07/14/26 20:16	0						0			0			0			0		
07/14/26 20:17	0						0			0			0			0		
07/14/26 20:18	0						1.6			0			0			0		
07/14/26 20:19	0						0.1			0			0			0		
07/14/26 20:20	0						0			0			0			0		
07/14/26 20:21	0						0			0			0			0		

	CT5_NOx_Ppmvdc_1M			CT5_NOx_Ppmvdc_1H			CT5_WaterInj_GPM_1M			CT5_NH3Inj_LbPerHr_1M			CT5_NH3Slip_Ppmvdc_1M			CT5_Load_MWe_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/14/26 20:22	0						0			0			0			0		
07/14/26 20:23	0						0			0			0			0		
07/14/26 20:24	1.48						2.4			3.2			-5.9			0		
07/14/26 20:25	19.95						0			9			3			0		
07/14/26 20:26	20.79						0			9			2.5			0		
07/14/26 20:27	17.16						0			10.7			1.5			0		
07/14/26 20:28	13.22						0			12			-0.3			0		
07/14/26 20:29	12.78						0			12			-0.7			0		
07/14/26 20:30	12.05						0			12			-0.9			0		
07/14/26 20:31	11.8						0			12			-1.1			0		
07/14/26 20:32	13.28						0			12			-1			0		
07/14/26 20:33	14.5						0			13			-0.3			0		
07/14/26 20:34	15.49						0.2			16.8			5.5			0		
07/14/26 20:35	2.7						0			4.4			318.8			0		
07/14/26 20:36	0.2						0			0			0			0		
07/14/26 20:37	0.1						0			0			0			0		
07/14/26 20:38	0.1						0			0			0			0		
07/14/26 20:39	0						0			0			0			0		
07/14/26 20:40	0						0			0			0			0		

Sample Spreadsheet Listing

	CT5_GasFlow_100scfh_1M			CT5_NOx_Ppmvdc_1M			CT5_NOx_Ppmvdc_1H			CT5_Startup_Minutes_1M			CT5_WaterInj_GPM_1M			CT5_Load_MWe_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/14/26 20:00	1			0.1			17.1			0			0			0		
07/14/26 20:01	1			0.1						0			0			0		
07/14/26 20:02	1			0.1						0			0			0		
07/14/26 20:03	2			0.1						0			0			0		
07/14/26 20:04	2			0						0			0			0		
07/14/26 20:05	1			0						0			0			0		
07/14/26 20:06	2			0.1						0			0			0		
07/14/26 20:07	1			0						0			0			0		
07/14/26 20:08	2			0						0			0			0		
07/14/26 20:09	2			0						0			0			0		
07/14/26 20:10	2			0						0			0			0		
07/14/26 20:11	2			0						0			0			0		
07/14/26 20:12	2			0						0			0			0		
07/14/26 20:13	2			0						0			0			0		
07/14/26 20:14	1			0						0			0			0		
07/14/26 20:15	2			0						0			0			0		
07/14/26 20:16	2			0						0			0			0		
07/14/26 20:17	2			0						0			0			0		
07/14/26 20:18	2			0						0			1.6			0		
07/14/26 20:19	2			0						0			0.1			0		
07/14/26 20:20	2			0						0			0			0		
07/14/26 20:21	2			0						0			0			0		
07/14/26 20:22	2			0						0			0			0		
07/14/26 20:23	2			0						1			0			0		
07/14/26 20:24	216			1.48						2			2.4			0		
07/14/26 20:25	274			19.95						3			0			0		
07/14/26 20:26	292			20.79						0			0			0		
07/14/26 20:27	392			17.16						0			0			0		
07/14/26 20:28	395			13.22						0			0			0		
07/14/26 20:29	400			12.78						0			0			0		
07/14/26 20:30	401			12.05						0			0			0		
07/14/26 20:31	401			11.8						0			0			0		

LOST START UP SIGNAL

	CT5_GasFlow_100scfh_1M			CT5_NOx_Ppmvdc_1M			CT5_NOx_Ppmvdc_1H			CT5_Startup_Minutes_1M			CT5_WaterInj_GPM_1M			CT5_Load_MWe_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/14/26 20:32	401			13.28						0			0			0		
07/14/26 20:33	401			14.5						0			0			0		
07/14/26 20:34	254			15.49						0			0.2			0		
07/14/26 20:35	1			2.7						0			0			0		
07/14/26 20:36	2			0.2						0			0			0		
07/14/26 20:37	2			0.1						0			0			0		
07/14/26 20:38	2			0.1						0			0			0		
07/14/26 20:39	2			0						0			0			0		
07/14/26 20:40	2			0						0			0			0		
07/14/26 20:41	2			0						0			0			0		
07/14/26 20:42	2			0						0			0			0		
07/14/26 20:43	1			0						0			0			0		
07/14/26 20:44	2			0						0			0			0		
07/14/26 20:45	1			0						0			0			0		
07/14/26 20:46	2			0						0			0			0		
07/14/26 20:47	1			0						0			0			0		
07/14/26 20:48	2			0						0			0			0		
07/14/26 20:49	2			0						0			0			0		
07/14/26 20:50	2			0						0			0			0		
07/14/26 20:51	1			0						0			0			0		
07/14/26 20:52	2			0						0			0			0		
07/14/26 20:53	2			0						0			0			0		
07/14/26 20:54	2			0						0			0			0		
07/14/26 20:55	2			0						0			0			0		
07/14/26 20:56	2			0						0			0			0		
07/14/26 20:57	2			0						0			0			0		
07/14/26 20:58	2			0						0			0			0		
07/14/26 20:59	2			0						0			0			0		

Sample Spreadsheet Listing

	CT5_NOx_1Hr_Ppmvdc_1M			CT5_NOx_Norm_Ppmvdc_1H			CT5_ExhaustFlow_LbPerHr_1M			CT5_GasFlow_kscfh_1M			CT5_Load_MWe_1M			CT5_Startup_Minutes_1M		
Date/Time	**Value**	**Sl**	**Modc**	**Value**	**Sl**	**Modc**	**Value**	**Sl**	**Modc**	**Value**	**Sl**	**Modc**	**Value**	**Sl**	**Modc**	**Value**	**Sl**	**Modc**
07/14/26 15:45	0	X					0			0.1			0			0		
07/14/26 15:46	0	X					0			0.1			0			0		
07/14/26 15:47	0	X					0			0.1			0			0		
07/14/26 15:48	0	X					0			0.1			0			0		
07/14/26 15:49	0	X					0			0.1			0			0		
07/14/26 15:50	0	X					0			0.1			0			0		
07/14/26 15:51	0	X					0			6.5			0			1		
07/14/26 15:52	0	X					407092.5			31.3			0			2		
07/14/26 15:53	0	X					233397.5			37.5			0			3		
07/14/26 15:54	0	X					237542.5			43.1			0			4		
07/14/26 15:55	0	X					234993.2			41			0			5		
07/14/26 15:56	0	X					217396.1			36.4			0.1			6		
07/14/26 15:57	0	X					473504.8			85.9			5			7		
07/14/26 15:58	0	X					490445			147.2			12			8		
07/14/26 15:59	0	X					594646.2			215.9			20.9			9		
07/14/26 16:00	0	X		2.6			584787			261.3			26.2			10		
07/14/26 16:01	0	X					563538.9			259.7			26.2			11		
07/14/26 16:02	1.7						558974.1			257.6			26.1			0		
07/14/26 16:03	2						567573.7			257.6			26.2			0		
07/14/26 16:04	2.4						584722.5			257.2			26.2			0		
07/14/26 16:05	2.9						632768.5			256.2			26.1			0		
07/14/26 16:06	3.1						668279.1			256.6			26.2			0		
07/14/26 16:07	3.1						680654.6			256.6			26.3			0		
07/14/26 16:08	3.1						690138.2			255.4			26.1			0		
07/14/26 16:09	3.1						702093.3			254.9			26.1			0		
07/14/26 16:10	3.1						702356.7			255			26.2			0		
07/14/26 16:11	3.1						707097			256.7			26.4			0		
07/14/26 16:12	3.1						708940.5			257.4			26.5			0		
07/14/26 16:13	3.1						705780.3			256.2			26.4			0		
07/14/26 16:14	3						704726.9			255.8			26.4			0		
07/14/26 16:15	3						702620			255.1			26.2			0		
07/14/26 16:16	3						701830			254.8			26.2			0		

	CT5_NOx_1Hr_Ppmvdc_1M			CT5_NOx_Norm_Ppmvdc_1H			CT5_ExhaustFlow_LbPerHr_1M			CT5_GasFlow_kscfh_1M			CT5_Load_MWe_1M			CT5_Startup_Minutes_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/14/26 16:17	3						714785.8			254.5			26.2			0		
07/14/26 16:18	3						717739.5			255.5			26.3			0		
07/14/26 16:19	3						704200.2			255.6			26.4			0		
07/14/26 16:20	3						705780.3			256.2			26.4			0		
07/14/26 16:21	2.9						716933.9			255.3			26.3			0		
07/14/26 16:22	2.9						705516.9			256.1			26.4			0		
07/14/26 16:23	2.9						706307			256.4			26.5			0		
07/14/26 16:24	2.9						706307			256.4			26.5			0		
07/14/26 16:25	2.9						708677.1			257.3			26.6			0		
07/14/26 16:26	2.9						709203.8			257.5			26.7			0		
07/14/26 16:27	2.8						708413.8			257.2			26.6			0		
07/14/26 16:28	2.8						706307			256.4			26.5			0		
07/14/26 16:29	2.8						710783.9			258			26.7			0		
07/14/26 16:30	2.8						717104.3			260.3			27			0		
07/14/26 16:31	2.8						712364			258.6			26.8			0		
07/14/26 16:32	2.8						709203.8			257.5			26.7			0		
07/14/26 16:33	2.8						707623.7			256.9			26.6			0		
07/14/26 16:34	2.8						704463.5			255.7			26.4			0		
07/14/26 16:35	2.8						705516.9			256.1			26.5			0		
07/14/26 16:36	2.7						706833.7			256.6			26.5			0		
07/14/26 16:37	2.7						704990.2			255.9			26.5			0		
07/14/26 16:38	2.7						707887.1			257			26.6			0		
07/14/26 16:39	2.7						706570.3			256.5			26.5			0		
07/14/26 16:40	2.7						703936.8			255.5			26.4			0		
07/14/26 16:41	2.7						703410.1			255.4			26.4			0		
07/14/26 16:42	2.7						704200.2			255.6			26.5			0		
07/14/26 16:43	2.7						704463.5			255.7			26.4			0		
07/14/26 16:44	2.7						705253.6			256			26.5			0		
07/14/26 16:45	2.7						708413.8			257.2			26.7			0		
07/14/26 16:46	2.7						707623.7			256.9			26.6			0		
07/14/26 16:47	2.7						705516.9			256.1			26.5			0		
07/14/26 16:48	2.7						707623.7			256.9			26.6			0		
07/14/26 16:49	2.7						706570.3			256.5			26.5			0		
07/14/26 16:50	2.7						703936.8			255.5			26.4			0		
07/14/26 16:51	2.7						704463.5			255.7			26.4			0		

	CT5_NOx_1Hr_Ppmvdc_1M			CT5_NOx_Norm_Ppmvdc_1H			CT5_ExhaustFlow_LbPerHr_1M			CT5_GasFlow_kscfh_1M			CT5_Load_MWe_1M			CT5_Startup_Minutes_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/14/26 16:52	2.7						702883.4			255.2			26.4			0		
07/14/26 16:53	2.7						702883.4			255.2			26.4			0		
07/14/26 16:54	2.7						705253.6			256			26.5			0		
07/14/26 16:55	2.7						705780.3			256.2			26.5			0		
07/14/26 16:56	2.7						704726.9			255.8			26.5			0		
07/14/26 16:57	2.6						704726.9			255.8			26.5			0		
07/14/26 16:58	2.6						704990.2			255.9			26.4			0		
07/14/26 16:59	2.6						704726.9			255.8			26.5			0		
07/14/26 17:00	2.4			2.4			704200.2			255.6			26.5			0		
07/14/26 17:01	2.4						704726.9			255.8			26.5			0		
07/14/26 17:02	2.4						708150.4			257.1			26.7			0		
07/14/26 17:03	2.4						708677.1			257.3			26.7			0		
07/14/26 17:04	2.4						708150.4			257.1			26.7			0		
07/14/26 17:05	2.4						705780.3			256.2			26.5			0		
07/14/26 17:06	2.4						705516.9			256.1			26.5			0		
07/14/26 17:07	2.4						707097			256.7			26.6			0		
07/14/26 17:08	2.4						706570.3			256.5			26.5			0		
07/14/26 17:09	2.4						702620			255.1			26.4			0		
07/14/26 17:10	2.4						706043.6			256.3			26.5			0		
07/14/26 17:11	2.4						703410.1			255.4			26.4			0		
07/14/26 17:12	2.4						705780.3			256.2			26.5			0		
07/14/26 17:13	2.4						705516.9			256.1			26.5			0		
07/14/26 17:14	2.4						919568.5	X		256.8			26.6			0		
07/14/26 17:15	2.4						0	X		256.1			26.5			0		
07/14/26 17:16	2.4						0	X		256.5			26.6			0		
07/14/26 17:17	2.4						0	X		256.1			26.5			0		
07/14/26 17:18	2.4						0	X		255.9			26.5			0		
07/14/26 17:19	2.4						563360.1	X		255.6			26.4			0		
07/14/26 17:20	2.4						175797.4	X		256.5			26.6			0		
07/14/26 17:21	2.4						176059.5	X		256.9			26.6			0		
07/14/26 17:22	2.4						175862.9	X		256.6			26.6			0		
07/14/26 17:23	2.4						176256.1	X		257.2			26.7			0		
07/14/26 17:24	2.4						176256.1	X		257.2			26.6			0		
07/14/26 17:25	2.4						177238.9	X		258.6			26.8			0		
07/14/26 17:26	2.4						176976.8	X		258.2			26.8			0		

	CT5_NOx_1Hr_Ppmvdc_1M			CT5_NOx_Norm_Ppmvdc_1H			T5_ExhaustFlow_LbPerHr_1M			CT5_GasFlow_kscfh_1M			CT5_Load_MWe_1M			CT5_Startup_Minutes_1M		
Date/Time	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**	**Value**	**SI**	**Modc**
07/14/26 17:27	2.4						175994	X		256.8			26.6			0		
07/14/26 17:28	2.4						176190.5	X		257.1			26.7			0		
07/14/26 17:29	2.4						175535.3	X		256.1			26.5			0		
07/14/26 17:30	2.4						174880.1	X		255.2			26.4			0		
07/14/26 17:31	2.4						174618	X		254.8			26.4			0		
07/14/26 17:32	2.4						175338.7	X		255.8			26.5			0		
07/14/26 17:33	2.4						175731.9	X		256.4			26.6			0		
07/14/26 17:34	2.4						294042.8	X		256.6			26.6			0		
07/14/26 17:35	2.4						750109.2	X		256.6			26.6			0		
07/14/26 17:36	2.4						706570.3	X		256.5			26.6			0		
07/14/26 17:37	2.4						706833.7	X		256.6			26.6			0		
07/14/26 17:38	2.4						704463.5	X		255.7			26.5			0		
07/14/26 17:39	2.4						704726.9			255.8			26.5			0		
07/14/26 17:40	2.4						706833.7			256.6			26.6			0		
07/14/26 17:41	2.4						706833.7			256.6			26.6			0		
07/14/26 17:42	2.4						706570.3			256.5			26.6			0		
07/14/26 17:43	2.4						706833.7			256.6			26.6			0		
07/14/26 17:44	2.4						706570.3			256.5			26.6			0		
07/14/26 17:45	2.4						706043.6			256.3			26.5			0		
07/14/26 17:46	2.4						705253.6			256			26.5			0		
07/14/26 17:47	2.4						707887.1			257			26.7			0		
07/14/26 17:48	2.4						708413.8			257.2			26.7			0		
07/14/26 17:49	2.4						706570.3			256.5			26.6			0		
07/14/26 17:50	2.4						706307			256.4			26.6			0		
07/14/26 17:51	2.4						707360.4			256.8			26.6			0		
07/14/26 17:52	2.4						706570.3			256.5			26.6			0		
07/14/26 17:53	2.4						706307			256.4			26.6			0		
07/14/26 17:54	2.4						707623.7			256.9			26.7			0		
07/14/26 17:55	2.4						706833.7			256.6			26.6			0		
07/14/26 17:56	2.4						708940.5			257.4			26.7			0		
07/14/26 17:57	2.4						710520.6			257.9			26.8			0		
07/14/26 17:58	2.4						707623.7			256.9			26.6			0		
07/14/26 17:59	2.4						708677.1			257.3			26.7			0		
07/14/26 18:00	2.3			2.2			709203.8			257.5			26.8			0		
07/14/26 18:01	2.3						706043.6			256.3			26.6			0		