DOCKETED	
Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	273244
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q3 2026 - Part 29s
Description:	N/A
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public Agency
Submission Date:	10/28/2026 7:52:54 AM
Docketed Date:	10/28/2026

CO LbPerHr 3-Hour Rolling Excess Emissions

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:17 **Location:** Roseville, CA

Tag Name: CT1_CO_3Hr_LbPerHr_1H
Total Operating Time: 1,986.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 222.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,986.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

CO Ppmvdc 3-Hour Block Excess Emissions

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:17 **Location:** Roseville, CA

Tag Name: CT1_CO_Ppmvdc_3H
Total Operating Time: 1,986.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 222.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,986.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

CO LbPerHr SUSD 1-Hour Block Excess Emissions

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:17 **Location:** Roseville, CA

Tag Name: CT1_CO_SUSD_LbPerHr_1H
Total Operating Time: 1,986.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 222.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,986.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

NH3 Slip Ppmvdc 1-Hour Block Excess Emissions

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:17 **Location:** Roseville, CA

Tag Name: CT1_NH3Slip_Ppmvdc_1H
Total Operating Time: 1,986.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 222.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,986.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

NOx LbPerHr 1-Hour Block Excess Emissions

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:17 **Location:** Roseville, CA

Tag Name: CT1_NOx_Norm_LbPerHr_1H

Total Operating Time: 1,986.00 Hour(s) **No Exclusions Allowed**

Non-Operating Time: 222.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,986.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

NOx Ppmvdc 1-Hour Block Excess Emissions

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:17 **Location:** Roseville, CA

Tag Name: CT1_NOx_Ppmvdc_1H
Total Operating Time: 1,986.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 222.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,986.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

NOx LbPerHr SUSD 1-Hour Block Excess Emissions

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:17 **Location:** Roseville, CA

Tag Name: CT1_NOx_SUSD_LbPerHr_1H
Total Operating Time: 1,986.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 222.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,986.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

PM10 LbPerHr 1-Hour Block Excess Emissions

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:17 **Location:** Roseville, CA

Tag Name: CT1_PM10_Norm_LbPerHr_1H
Total Operating Time: 1,986.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 222.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,986.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

SO2 LbPerHr 1-Hour Block Excess Emissions

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:17 **Location:** Roseville, CA

Tag Name: CT1_SO2_Norm_LbPerHr_1H
Total Operating Time: 1,986.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 222.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,986.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

VOC LbPerHr 1-Hour Block Excess Emissions

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:17 **Location:** Roseville, CA

Tag Name: CT1_VOC_Norm_LbPerHr_1H
Total Operating Time: 1,986.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 222.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**1,986.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

CO LbPerHr 3-Hour Rolling Excess Emissions

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:19 **Location:** Roseville, CA

Tag Name: CT2_CO_3Hr_LbPerHr_1H
Total Operating Time: 2,202.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 6.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,202.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

CO Ppmvdc 3-Hour Block Excess Emissions

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:19 **Location:** Roseville, CA

Tag Name: CT2_CO_Ppmvdc_3H
Total Operating Time: 2,202.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 6.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,202.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

CO LbPerHr SUSD 1-Hour Block Excess Emissions

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:19 **Location:** Roseville, CA

Tag Name: CT2_CO_SUSD_LbPerHr_1H
Total Operating Time: 2,202.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 6.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,202.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

NH3 Slip Ppmvdc 1-Hour Block Excess Emissions

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:19 **Location:** Roseville, CA

Tag Name: CT2_NH3Slip_Ppmvdc_1H
Total Operating Time: 2,202.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 6.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,202.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

NOx LbPerHr 1-Hour Block Excess Emissions

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:19 **Location:** Roseville, CA

Tag Name: CT2_NOx_Norm_LbPerHr_1H
Total Operating Time: 2,202.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 6.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,202.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

NOx Ppmvdc 1-Hour Block Excess Emissions

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:19 **Location:** Roseville, CA

Tag Name: CT2_NOx_Ppmvdc_1H
Total Operating Time: 2,202.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 6.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,202.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

NOx LbPerHr SUSD 1-Hour Block Excess Emissions

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:19 **Location:** Roseville, CA

Tag Name: CT2_NOx_SUSD_LbPerHr_1H
Total Operating Time: 2,202.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 6.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,202.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

PM10 LbPerHr 1-Hour Block Excess Emissions

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:19 **Location:** Roseville, CA

Tag Name: CT2_PM10_Norm_LbPerHr_1H
Total Operating Time: 2,202.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 6.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,202.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

SO2 LbPerHr 1-Hour Block Excess Emissions

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:19 **Location:** Roseville, CA

Tag Name: CT2_SO2_Norm_LbPerHr_1H
Total Operating Time: 2,202.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 6.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,202.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

VOC LbPerHr 1-Hour Block Excess Emissions

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:19 **Location:** Roseville, CA

Tag Name: CT2_VOC_Norm_LbPerHr_1H
Total Operating Time: 2,202.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 6.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**2,202.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

CO LbPerHr 1-Hour Block Excess Emissions

CT5

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:15 **Location:** Roseville, CA

Tag Name: CT5_CO_Norm_LbPerHr_1H
Total Operating Time: 81.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,079.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**81.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

CO Ppmvdc 1-Hour Block Excess Emissions

CT5

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:15 **Location:** Roseville, CA

Tag Name: CT5_CO_Norm_Ppmvdc_1H
Total Operating Time: 81.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,079.00 Hour(s) Report Time: 2,160.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Tag Value	Limit	Reason Code	Action Code
1	07/14/26 20:00	07/14/26 20:59	1	12.0	4.0		

Total Operating Time:	**81.00 Hour(s)**
Total Duration (Online only):	**1.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**1.23 %**
Time in compliance as a percentage of operating time:	**98.77 %**

CO Lbs SUSD 1-Hour Block Excess Emissions

CT5

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:15 **Location:** Roseville, CA

Tag Name: CT5_CO_SUSD_Lbs_1H
Total Operating Time: 81.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,079.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**81.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Startup/Shutdown Event Report

CT5 - CO Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:15 **Location:** Roseville, CA

Tag Name: CT5_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 55.82 Hours

Non-Operating Time: 2,104.18 Hours Report Time: 2,160.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
07/14/2026 15:51 07/14/2026 16:01 Startup	11	0.58	19.40		
07/14/2026 20:23 07/14/2026 20:25 Startup	3	0.03	19.40		
07/14/2026 20:25 07/14/2026 20:34 Shutdown	10	0.01	21.60		
07/14/2026 20:29 07/14/2026 20:34 Shutdown	6	0.07	21.60		
07/15/2026 08:53 07/15/2026 09:02 Startup	10	0.49	19.40		
07/15/2026 13:57 07/15/2026 14:04 Shutdown	8	0.08	21.60		
07/20/2026 15:07 07/20/2026 15:19 Startup	13	0.55	19.40		
07/20/2026 19:03 07/20/2026 19:10 Shutdown	8	0.07	21.60		
07/21/2026 15:51 07/21/2026 16:01 Startup	11	0.40	19.40		
07/21/2026 20:58 07/21/2026 21:05 Shutdown	8	0.08	21.60		
08/05/2026 13:52 08/05/2026 13:58 Startup	7	0.50	19.40		
08/05/2026 13:58 08/05/2026 14:03 Shutdown	6	0.08	21.60		
08/06/2026 14:53 08/06/2026 15:07 Startup	15	0.00 SI	19.40		

Startup/Shutdown Event Report

CT5 - CO Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:15 **Location:** Roseville, CA

Tag Name: CT5_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 55.82 Hours

Non-Operating Time: 2,104.18 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
08/06/2026 15:24 08/06/2026 15:31 Shutdown	8	0.00 SI	21.60		
08/07/2026 11:51 08/07/2026 12:01 Startup	11	0.00 SI	19.40		
08/07/2026 13:58 08/07/2026 14:04 Shutdown	7	0.05	21.60		
08/19/2026 14:57 08/19/2026 15:06 Startup	10	0.39	19.40		
08/19/2026 15:18 08/19/2026 15:26 Shutdown	9	0.05	21.60		
08/20/2026 11:56 08/20/2026 12:04 Startup	9	0.00 SI	19.40		
08/20/2026 13:58 08/20/2026 14:04 Shutdown	7	0.07	21.60		
08/20/2026 15:55 08/20/2026 16:05 Startup	11	0.27	19.40		
08/20/2026 20:59 08/20/2026 21:05 Shutdown	7	0.10	21.60		
08/25/2026 14:51 08/25/2026 15:00 Startup	10	0.54	19.40		
08/25/2026 19:58 08/25/2026 20:04 Shutdown	7	0.08	21.60		
08/27/2026 13:52 08/27/2026 14:01 Startup	10	0.39	19.40		
08/27/2026 15:07 08/27/2026 15:12 Shutdown	6	0.00 SI	21.60		
08/28/2026 08:54 08/28/2026 09:04 Startup	11	0.00 SI	19.40		

Startup/Shutdown Event Report

CT5 - CO Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:15 **Location:** Roseville, CA

Tag Name: CT5_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 55.82 Hours

Non-Operating Time: 2,104.18 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
08/28/2026 11:55 08/28/2026 12:01 Shutdown	7	0.08	21.60		
09/09/2026 11:51 09/09/2026 12:00 Startup	10	0.57	19.40		
09/09/2026 20:58 09/09/2026 21:04 Shutdown	7	0.06	21.60		
09/10/2026 15:51 09/10/2026 16:00 Startup	10	0.65	19.40		
09/10/2026 22:59 09/10/2026 23:05 Shutdown	7	0.07	21.60		

No excess emissions were found in the reporting period.

Startup/Shutdown Event Report

CT5 - CO Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:15 **Location:** Roseville, CA

Tag Name: CT5_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 55.82 Hours

Non-Operating Time: 2,104.18 Hours Report Time: 2,160.00 Hours

Event Invalid Information

Invalid Event Period		Reason	Action
Begin/End	Duration in Minute(s)	Code - Description	Code - Description
08/06/2026 14:53 08/06/2026 15:07	15		
08/06/2026 15:24 08/06/2026 15:31	8		
08/07/2026 11:51 08/07/2026 12:01	11		
08/20/2026 11:56 08/20/2026 12:04	9		
08/27/2026 15:07 08/27/2026 15:12	6		
08/28/2026 08:54 08/28/2026 09:04	11		

Total CMS Downtime	**60**	**Minute(s)**
Total Downtime as a percentage of operating time	**1.79**	**%**
Total Availability as a percentage of operating time	**98.21**	**%**

Startup/Shutdown Event Report

CT5 - CO Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:15 **Location:** Roseville, CA

Tag Name: CT5_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 55.82 Hours

Non-Operating Time: 2,104.18 Hours Report Time: 2,160.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	60
2. Total CMS Downtime in Minute(s)	60
3. Total Downtime as a percentage of operating time	1.79
4. Total Availability as a percentage of operating time	98.21

Heat Input MBtuPerHr 1-Hour Block Excess Emissions

CT5

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:15 **Location:** Roseville, CA

Tag Name: CT5_HI_MBtuPerHr_1H
Total Operating Time: 81.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: -72.00 Hour(s) Report Time: 9.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**81.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

NH3 Slip Ppmvdc 1-Hour Block Excess Emissions

CT5

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:15 **Location:** Roseville, CA

Tag Name: CT5_NH3Slip_Ppmvdc_1H
Total Operating Time: 81.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: -57.00 Hour(s) Report Time: 24.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Tag Value	Limit	Reason Code	Action Code
1	07/14/26 16:00	07/14/26 16:59	1	11.0	10.0		
2	07/14/26 17:00	07/14/26 17:59	1	13.7	10.0		
3	07/14/26 18:00	07/14/26 18:59	1	14.7	10.0		
4	07/14/26 19:00	07/14/26 19:59	1	13.9	10.0		
5	09/09/26 13:00	09/09/26 13:59	1	10.2	10.0		

Total Operating Time:	**81.00 Hour(s)**
Total Duration (Online only):	**5.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**6.17 %**
Time in compliance as a percentage of operating time:	**93.83 %**

NOx LbPerHr 1-Hour Block Excess Emissions

CT5

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:15 **Location:** Roseville, CA

Tag Name: CT5_NOx_Norm_LbPerHr_1H
Total Operating Time: 81.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: -71.00 Hour(s) Report Time: 10.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**81.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

NOx Ppmvdc 1-Hour Block Excess Emissions

CT5

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:15 **Location:** Roseville, CA

Tag Name: CT5_NOx_Norm_Ppmvdc_1H
Total Operating Time: 81.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: -71.00 Hour(s) Report Time: 10.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Tag Value	Limit	Reason Code	Action Code
1	07/14/26 16:00	07/14/26 16:59	1	2.6	2.5		
2	07/14/26 20:00	07/14/26 20:59	1	17.1	2.5		
3	08/19/26 15:00	08/19/26 15:59	1	2.7	2.5	4 - Other known causes	24 - Unit Shutdown To Facilitate Repairs

Total Operating Time:	**81.00 Hour(s)**
Total Duration (Online only):	**3.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**3.70 %**
Time in compliance as a percentage of operating time:	**96.30 %**

Report Code	Type	Text	Duration	Duration Percent
4	Reason	Other known causes	1	33.33
24	Action	Unit Shutdown To Facilitate Repairs	1	33.33

NOx Lbs SUSD 1-Hour Block Excess Emissions

CT5

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:18 **Location:** Roseville, CA

Tag Name: CT5_NOx_SUSD_Lbs_1H
Total Operating Time: 81.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: -57.00 Hour(s) Report Time: 24.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**81.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Startup/Shutdown Event Report

CT5 - NOx Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:18 **Location:** Roseville, CA

Tag Name: CT5_NOx_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 55.82 Hours

Non-Operating Time: -31.82 Hours Report Time: 24.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
07/14/2026 15:51 07/14/2026 16:01 Startup	11	1.21	3.10		
07/14/2026 20:23 07/14/2026 20:25 Startup	3	0.04	3.10		
07/14/2026 20:25 07/14/2026 20:34 Shutdown	10	0.04	3.40		
07/14/2026 20:29 07/14/2026 20:34 Shutdown	6	0.19	3.40		
07/15/2026 08:53 07/15/2026 09:02 Startup	10	1.06	3.10		
07/15/2026 13:57 07/15/2026 14:04 Shutdown	8	0.12	3.40		
07/20/2026 15:07 07/20/2026 15:19 Startup	13	1.39	3.10		
07/20/2026 19:03 07/20/2026 19:10 Shutdown	8	0.13	3.40		
07/21/2026 15:51 07/21/2026 16:01 Startup	11	1.22	3.10		
07/21/2026 20:58 07/21/2026 21:05 Shutdown	8	0.12	3.40		
08/05/2026 13:52 08/05/2026 13:58 Startup	7	0.37	3.10		
08/05/2026 13:58 08/05/2026 14:03 Shutdown	6	0.45	3.40		
08/06/2026 14:53 08/06/2026 15:07 Startup	15	0.00 SI	3.10		

Startup/Shutdown Event Report

CT5 - NOx Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:18 **Location:** Roseville, CA

Tag Name: CT5_NOx_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 55.82 Hours

Non-Operating Time: -31.82 Hours Report Time: 24.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
08/06/2026 15:24 08/06/2026 15:31 Shutdown	8	0.00 SI	3.40		
08/07/2026 11:51 08/07/2026 12:01 Startup	11	0.00 SI	3.10		
08/07/2026 13:58 08/07/2026 14:04 Shutdown	7	0.07	3.40		
08/19/2026 14:57 08/19/2026 15:06 Startup	10	1.17	3.10		
08/19/2026 15:18 08/19/2026 15:26 Shutdown	9	0.47	3.40		
08/20/2026 11:56 08/20/2026 12:04 Startup	9	0.00 SI	3.10		
08/20/2026 13:58 08/20/2026 14:04 Shutdown	7	0.08	3.40		
08/20/2026 15:55 08/20/2026 16:05 Startup	11	0.97	3.10		
08/20/2026 20:59 08/20/2026 21:05 Shutdown	7	0.10	3.40		
08/25/2026 14:51 08/25/2026 15:00 Startup	10	1.14	3.10		
08/25/2026 19:58 08/25/2026 20:04 Shutdown	7	0.09	3.40		
08/27/2026 13:52 08/27/2026 14:01 Startup	10	1.07	3.10		
08/27/2026 15:07 08/27/2026 15:12 Shutdown	6	0.00 SI	3.40		
08/28/2026 08:54 08/28/2026 09:04 Startup	11	0.00 SI	3.10		

Startup/Shutdown Event Report

CT5 - NOx Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:18 **Location:** Roseville, CA

Tag Name: CT5_NOx_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 55.82 Hours

Non-Operating Time: -31.82 Hours Report Time: 24.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
08/28/2026 11:55 08/28/2026 12:01 Shutdown	7	0.11	3.40		
09/09/2026 11:51 09/09/2026 12:00 Startup	10	1.15	3.10		
09/09/2026 20:58 09/09/2026 21:04 Shutdown	7	0.10	3.40		
09/10/2026 15:51 09/10/2026 16:00 Startup	10	1.08	3.10		
09/10/2026 22:59 09/10/2026 23:05 Shutdown	7	0.10	3.40		

No excess emissions were found in the reporting period.

Startup/Shutdown Event Report

CT5 - NOx Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:18 **Location:** Roseville, CA

Tag Name: CT5_NOx_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 55.82 Hours

Non-Operating Time: -31.82 Hours Report Time: 24.00 Hours

Event Invalid Information

Invalid Event Period		Reason	Action
Begin/End	Duration in Minute(s)	Code - Description	Code - Description
08/06/2026 14:53 08/06/2026 15:07	15		
08/06/2026 15:24 08/06/2026 15:31	8		
08/07/2026 11:51 08/07/2026 12:01	11		
08/20/2026 11:56 08/20/2026 12:04	9		
08/27/2026 15:07 08/27/2026 15:12	6		
08/28/2026 08:54 08/28/2026 09:04	11		

Total CMS Downtime	**60**	**Minute(s)**
Total Downtime as a percentage of operating time	**1.79**	**%**
Total Availability as a percentage of operating time	**98.21**	**%**

Startup/Shutdown Event Report

CT5 - NOx Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:18 **Location:** Roseville, CA

Tag Name: CT5_NOx_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 55.82 Hours

Non-Operating Time: -31.82 Hours Report Time: 24.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	60
2. Total CMS Downtime in Minute(s)	60
3. Total Downtime as a percentage of operating time	1.79
4. Total Availability as a percentage of operating time	98.21

PM10 LbPerHr 1-Hour Block Excess Emissions

CT5

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:18 **Location:** Roseville, CA

Tag Name: CT5_PM10_LbPerHr_1H
Total Operating Time: 81.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,079.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**81.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

SO2 LbPerHr 1-Hour Block Excess Emissions

CT5

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:20 **Location:** Roseville, CA

Tag Name: CT5_SO2_P60_LbPerHr_1H
Total Operating Time: 81.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,079.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**81.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

VOC LbPerHr 1-Hour Block Excess Emissions

CT5

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:20 **Location:** Roseville, CA

Tag Name: CT5_VOC_Norm_LbPerHr_1H
Total Operating Time: 81.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,079.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**81.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

VOC SUSD Lb 1-Hour Block Excess Emissions

CT5

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:20 **Location:** Roseville, CA

Tag Name: CT5_VOC_SUSD_Lbs_1H
Total Operating Time: 81.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,079.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**81.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Startup/Shutdown Event Report

CT5 - VOC Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:20 **Location:** Roseville, CA

Tag Name: CT5_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 55.82 Hours

Non-Operating Time: 2,104.18 Hours Report Time: 2,160.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
07/14/2026 15:51 07/14/2026 16:01 Startup	11	0.04	0.80		
07/14/2026 20:23 07/14/2026 20:25 Startup	3	0.00	0.80		
07/14/2026 20:25 07/14/2026 20:34 Shutdown	10	0.00	0.90		
07/14/2026 20:29 07/14/2026 20:34 Shutdown	6	0.01	0.90		
07/15/2026 08:53 07/15/2026 09:02 Startup	10	0.05	0.80		
07/15/2026 13:57 07/15/2026 14:04 Shutdown	8	0.02	0.90		
07/20/2026 15:07 07/20/2026 15:19 Startup	13	0.05	0.80		
07/20/2026 19:03 07/20/2026 19:10 Shutdown	8	0.02	0.90		
07/21/2026 15:51 07/21/2026 16:01 Startup	11	0.04	0.80		
07/21/2026 20:58 07/21/2026 21:05 Shutdown	8	0.02	0.90		
08/05/2026 13:52 08/05/2026 13:58 Startup	7	0.01	0.80		
08/05/2026 13:58 08/05/2026 14:03 Shutdown	6	0.01	0.90		
08/06/2026 14:53 08/06/2026 15:07 Startup	15	0.04	0.80		

Startup/Shutdown Event Report

CT5 - VOC Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:20 **Location:** Roseville, CA

Tag Name: CT5_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 55.82 Hours

Non-Operating Time: 2,104.18 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
08/06/2026 15:24 08/06/2026 15:31 Shutdown	8	0.02	0.90		
08/07/2026 11:51 08/07/2026 12:01 Startup	11	0.05	0.80		
08/07/2026 13:58 08/07/2026 14:04 Shutdown	7	0.01	0.90		
08/19/2026 14:57 08/19/2026 15:06 Startup	10	0.04	0.80		
08/19/2026 15:18 08/19/2026 15:26 Shutdown	9	0.02	0.90		
08/20/2026 11:56 08/20/2026 12:04 Startup	9	0.04	0.80		
08/20/2026 13:58 08/20/2026 14:04 Shutdown	7	0.02	0.90		
08/20/2026 15:55 08/20/2026 16:05 Startup	11	0.04	0.80		
08/20/2026 20:59 08/20/2026 21:05 Shutdown	7	0.02	0.90		
08/25/2026 14:51 08/25/2026 15:00 Startup	10	0.04	0.80		
08/25/2026 19:58 08/25/2026 20:04 Shutdown	7	0.02	0.90		
08/27/2026 13:52 08/27/2026 14:01 Startup	10	0.04	0.80		
08/27/2026 15:07 08/27/2026 15:12 Shutdown	6	0.02	0.90		
08/28/2026 08:54 08/28/2026 09:04 Startup	11	0.04	0.80		

Startup/Shutdown Event Report

CT5 - VOC Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:20 **Location:** Roseville, CA

Tag Name: CT5_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 55.82 Hours

Non-Operating Time: 2,104.18 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
08/28/2026 11:55 08/28/2026 12:01 Shutdown	7	0.02	0.90		
09/09/2026 11:51 09/09/2026 12:00 Startup	10	0.05	0.80		
09/09/2026 20:58 09/09/2026 21:04 Shutdown	7	0.01	0.90		
09/10/2026 15:51 09/10/2026 16:00 Startup	10	0.03	0.80		
09/10/2026 22:59 09/10/2026 23:05 Shutdown	7	0.01	0.90		

No excess emissions were found in the reporting period.

Startup/Shutdown Event Report

CT5 - VOC Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:20 **Location:** Roseville, CA

Tag Name: CT5_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 55.82 Hours

Non-Operating Time: 2,104.18 Hours Report Time: 2,160.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Startup/Shutdown Event Report

CT5 - VOC Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:20 **Location:** Roseville, CA

Tag Name: CT5_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 55.82 Hours

Non-Operating Time: 2,104.18 Hours Report Time: 2,160.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

CO LbPerHr 1-Hour Block Excess Emissions

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:30 **Location:** Roseville, CA

Tag Name: CT6_CO_Norm_LbPerHr_1H
Total Operating Time: 97.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,063.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**97.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

CO Ppmvdc 1-Hour Block Excess Emissions

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:30 **Location:** Roseville, CA

Tag Name: CT6_CO_Norm_Ppmvdc_1H
Total Operating Time: 97.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,063.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**97.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

CO Lbs SUSD 1-Hour Block Excess Emissions

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:30 **Location:** Roseville, CA

Tag Name: CT6_CO_SUSD_Lbs_1H
Total Operating Time: 97.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,063.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**97.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Startup/Shutdown Event Report

CT6 - CO Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:30 **Location:** Roseville, CA

Tag Name: CT6_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 75.25 Hours

Non-Operating Time: 2,084.75 Hours Report Time: 2,160.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
07/14/2026 15:51 07/14/2026 15:53 Startup	3	0.00 SI	19.40		
07/14/2026 16:02 07/14/2026 16:04 Startup	3	0.00 SI	19.40		
07/14/2026 16:16 07/14/2026 16:18 Startup	3	0.00 SI	19.40		
07/14/2026 19:42 07/14/2026 19:42 Startup	1	0.00 SI	19.40		
07/14/2026 19:44 07/14/2026 19:44 Startup	1	0.00 SI	19.40		
07/15/2026 07:20 07/15/2026 07:20 Startup	1	0.00 SI	19.40		
07/15/2026 07:27 07/15/2026 07:27 Startup	1	0.00 SI	19.40		
07/15/2026 11:51 07/15/2026 12:00 Startup	10	0.00 SI	19.40		
07/15/2026 20:58 07/15/2026 21:05 Shutdown	8	0.09	21.60		
07/20/2026 15:06 07/20/2026 15:16 Startup	11	0.49	19.40		
07/20/2026 21:28 07/20/2026 21:35 Shutdown	8	0.12	21.60		
07/21/2026 13:51 07/21/2026 14:00 Startup	10	0.44	19.40		
07/21/2026 20:58 07/21/2026 21:05 Shutdown	8	0.10	21.60		

Startup/Shutdown Event Report

CT6 - CO Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:30 **Location:** Roseville, CA

Tag Name: CT6_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 75.25 Hours

Non-Operating Time: 2,084.75 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
08/03/2026 14:51 08/03/2026 14:59 Startup	9	0.51	19.40		
08/03/2026 20:58 08/03/2026 21:04 Shutdown	7	0.09	21.60		
08/04/2026 14:52 08/04/2026 15:01 Startup	10	0.48	19.40		
08/04/2026 19:58 08/04/2026 20:04 Shutdown	7	0.10	21.60		
08/05/2026 14:05 08/05/2026 14:14 Startup	10	0.47	19.40		
08/05/2026 19:58 08/05/2026 20:04 Shutdown	7	0.11	21.60		
08/06/2026 15:31 08/06/2026 15:42 Startup	12	0.52	19.40		
08/06/2026 19:58 08/06/2026 20:04 Shutdown	7	0.10	21.60		
08/19/2026 15:31 08/19/2026 15:42 Startup	12	0.62	19.40		
08/19/2026 21:58 08/19/2026 22:04 Shutdown	7	0.10	21.60		
08/27/2026 15:20 08/27/2026 15:30 Startup	11	0.44	19.40		
08/27/2026 19:58 08/27/2026 20:04 Shutdown	7	0.09	21.60		
09/08/2026 16:53 09/08/2026 17:02 Startup	10	0.50	19.40		
09/08/2026 21:58 09/08/2026 22:05 Shutdown	8	0.12	21.60		

Startup/Shutdown Event Report

CT6 - CO Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:30 **Location:** Roseville, CA

Tag Name: CT6_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 75.25 Hours

Non-Operating Time: 2,084.75 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
09/09/2026 11:51 09/09/2026 12:03 Startup	13	0.46	19.40		
09/09/2026 20:58 09/09/2026 21:04 Shutdown	7	0.10	21.60		
09/10/2026 15:51 09/10/2026 16:00 Startup	10	0.36	19.40		
09/10/2026 19:59 09/10/2026 20:05 Shutdown	7	0.06	21.60		

No excess emissions were found in the reporting period.

Startup/Shutdown Event Report

CT6 - CO Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:30 **Location:** Roseville, CA

Tag Name: CT6_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 75.25 Hours

Non-Operating Time: 2,084.75 Hours Report Time: 2,160.00 Hours

Event Invalid Information

Invalid Event Period		Reason	Action
Begin/End	Duration in Minute(s)	Code - Description	Code - Description
07/14/2026 15:51 07/14/2026 15:53	3		
07/14/2026 16:02 07/14/2026 16:04	3		
07/14/2026 16:16 07/14/2026 16:18	3		
07/14/2026 19:42 07/14/2026 19:42	1		
07/14/2026 19:44 07/14/2026 19:44	1		
07/15/2026 07:20 07/15/2026 07:20	1		
07/15/2026 07:27 07/15/2026 07:27	1		
07/15/2026 11:51 07/15/2026 12:00	10		

Total CMS Downtime	23	Minute(s)
Total Downtime as a percentage of operating time	0.51	%
Total Availability as a percentage of operating time	99.49	%

Startup/Shutdown Event Report

CT6 - CO Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:30 **Location:** Roseville, CA

Tag Name: CT6_CO_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 75.25 Hours

Non-Operating Time: 2,084.75 Hours Report Time: 2,160.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	23
2. Total CMS Downtime in Minute(s)	23
3. Total Downtime as a percentage of operating time	0.51
4. Total Availability as a percentage of operating time	99.49

Heat Input MBtuPerHr 1-Hour Block Excess Emissions

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:30 **Location:** Roseville, CA

Tag Name: CT6_HI_MBtuPerHr_1H
Total Operating Time: 97.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 465.00 Hour(s) Report Time: 562.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**97.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

NH3 Slip Ppmvdc 1-Hour Block Excess Emissions

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:32 **Location:** Roseville, CA

Tag Name: CT6_NH3Slip_Ppmvdc_1H
Total Operating Time: 97.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,063.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**97.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

NOx LbPerHr 1-Hour Block Excess Emissions

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:32 **Location:** Roseville, CA

Tag Name: CT6_NOx_Norm_LbPerHr_1H
Total Operating Time: 97.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: -84.00 Hour(s) Report Time: 13.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**97.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

NOx Ppmvdc 1-Hour Block Excess Emissions

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:32 **Location:** Roseville, CA

Tag Name: CT6_NOx_Norm_Ppmvdc_1H
Total Operating Time: 97.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: -84.00 Hour(s) Report Time: 13.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Tag Value	Limit	Reason Code	Action Code
1	07/20/26 15:00	07/20/26 15:59	1	2.7	2.5	1 - Startup/shutdown	

Total Operating Time:	**97.00 Hour(s)**
Total Duration (Online only):	**1.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**1.03 %**
Time in compliance as a percentage of operating time:	**98.97 %**

Report Code	Type	Text	Duration	Duration Percent
1	Reason	Startup/shutdown	1	100.00

NOx Lbs SUSD 1-Hour Block Excess Emissions

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:32 **Location:** Roseville, CA

Tag Name: CT6_NOx_SUSD_Lbs_1H
Total Operating Time: 97.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,063.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**97.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Startup/Shutdown Event Report

CT6 - NOx Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:32 **Location:** Roseville, CA

Tag Name: CT6_NOx_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 75.25 Hours

Non-Operating Time: 2,084.75 Hours Report Time: 2,160.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
07/14/2026 15:51 07/14/2026 15:53 Startup	3	0.00 SI	3.10		
07/14/2026 16:02 07/14/2026 16:04 Startup	3	0.00 SI	3.10		
07/14/2026 16:16 07/14/2026 16:18 Startup	3	0.00 SI	3.10		
07/14/2026 19:42 07/14/2026 19:42 Startup	1	0.00 SI	3.10		
07/14/2026 19:44 07/14/2026 19:44 Startup	1	0.00 SI	3.10		
07/15/2026 07:20 07/15/2026 07:20 Startup	1	0.00 SI	3.10		
07/15/2026 07:27 07/15/2026 07:27 Startup	1	0.00 SI	3.10		
07/15/2026 11:51 07/15/2026 12:00 Startup	10	0.00 SI	3.10		
07/15/2026 20:58 07/15/2026 21:05 Shutdown	8	0.12	3.40		
07/20/2026 15:06 07/20/2026 15:16 Startup	11	1.15	3.10		
07/20/2026 21:28 07/20/2026 21:35 Shutdown	8	0.12	3.40		
07/21/2026 13:51 07/21/2026 14:00 Startup	10	0.98	3.10		
07/21/2026 20:58 07/21/2026 21:05 Shutdown	8	0.12	3.40		

Startup/Shutdown Event Report

CT6 - NOx Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:32 **Location:** Roseville, CA

Tag Name: CT6_NOx_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 75.25 Hours

Non-Operating Time: 2,084.75 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
08/03/2026 14:51 08/03/2026 14:59 Startup	9	0.89	3.10		
08/03/2026 20:58 08/03/2026 21:04 Shutdown	7	0.10	3.40		
08/04/2026 14:52 08/04/2026 15:01 Startup	10	0.99	3.10		
08/04/2026 19:58 08/04/2026 20:04 Shutdown	7	0.09	3.40		
08/05/2026 14:05 08/05/2026 14:14 Startup	10	1.06	3.10		
08/05/2026 19:58 08/05/2026 20:04 Shutdown	7	0.10	3.40		
08/06/2026 15:31 08/06/2026 15:42 Startup	12	1.25	3.10		
08/06/2026 19:58 08/06/2026 20:04 Shutdown	7	0.09	3.40		
08/19/2026 15:31 08/19/2026 15:42 Startup	12	1.16	3.10		
08/19/2026 21:58 08/19/2026 22:04 Shutdown	7	0.09	3.40		
08/27/2026 15:20 08/27/2026 15:30 Startup	11	0.62	3.10		
08/27/2026 19:58 08/27/2026 20:04 Shutdown	7	0.11	3.40		
09/08/2026 16:53 09/08/2026 17:02 Startup	10	0.80	3.10		
09/08/2026 21:58 09/08/2026 22:05 Shutdown	8	0.11	3.40		

Startup/Shutdown Event Report

CT6 - NOx Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:32 **Location:** Roseville, CA

Tag Name: CT6_NOx_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 75.25 Hours

Non-Operating Time: 2,084.75 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
09/09/2026 11:51 09/09/2026 12:03 Startup	13	1.35	3.10		
09/09/2026 20:58 09/09/2026 21:04 Shutdown	7	0.10	3.40		
09/10/2026 15:51 09/10/2026 16:00 Startup	10	0.75	3.10		
09/10/2026 19:59 09/10/2026 20:05 Shutdown	7	0.09	3.40		

No excess emissions were found in the reporting period.

Startup/Shutdown Event Report

CT6 - NOx Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:32 **Location:** Roseville, CA

Tag Name: CT6_NOx_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 75.25 Hours

Non-Operating Time: 2,084.75 Hours Report Time: 2,160.00 Hours

Event Invalid Information

Invalid Event Period		Reason	Action
Begin/End	Duration in Minute(s)	Code - Description	Code - Description
07/14/2026 15:51 07/14/2026 15:53	3		
07/14/2026 16:02 07/14/2026 16:04	3		
07/14/2026 16:16 07/14/2026 16:18	3		
07/14/2026 19:42 07/14/2026 19:42	1		
07/14/2026 19:44 07/14/2026 19:44	1		
07/15/2026 07:20 07/15/2026 07:20	1		
07/15/2026 07:27 07/15/2026 07:27	1		
07/15/2026 11:51 07/15/2026 12:00	10		

Total CMS Downtime	23	Minute(s)
Total Downtime as a percentage of operating time	0.51	%
Total Availability as a percentage of operating time	99.49	%

Startup/Shutdown Event Report

CT6 - NOx Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:32 **Location:** Roseville, CA

Tag Name: CT6_NOx_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 75.25 Hours

Non-Operating Time: 2,084.75 Hours Report Time: 2,160.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	23
2. Total CMS Downtime in Minute(s)	23
3. Total Downtime as a percentage of operating time	0.51
4. Total Availability as a percentage of operating time	99.49

PM10 LbPerHr 1-Hour Block Excess Emissions

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:32 **Location:** Roseville, CA

Tag Name: CT6_PM10_LbPerHr_1H
Total Operating Time: 97.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,063.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**97.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

SO2 LbPerHr 1-Hour Block Excess Emissions

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:35 **Location:** Roseville, CA

Tag Name: CT6_SO2_P60_LbPerHr_1H
Total Operating Time: 97.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,063.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**97.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

VOC LbPerHr 1-Hour Block Excess Emissions

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:35 **Location:** Roseville, CA

Tag Name: CT6_VOC_Norm_LbPerHr_1H
Total Operating Time: 97.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,063.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**97.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

VOC SUSD Lb 1-Hour Block Excess Emissions

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:35 **Location:** Roseville, CA

Tag Name: CT6_VOC_SUSD_Lbs_1H
Total Operating Time: 97.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 2,063.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	**97.00 Hour(s)**
Total Duration (Online only):	**0.00 Hour(s)**
Time in exceedance as a percentage of operating time:	**0.00 %**
Time in compliance as a percentage of operating time:	**100.00 %**

Startup/Shutdown Event Report

CT6 - VOC Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:35 **Location:** Roseville, CA

Tag Name: CT6_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 75.25 Hours

Non-Operating Time: 2,084.75 Hours Report Time: 2,160.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
07/14/2026 15:51 07/14/2026 15:53 Startup	3	0.00	0.80		
07/14/2026 16:02 07/14/2026 16:04 Startup	3	0.00	0.80		
07/14/2026 16:16 07/14/2026 16:18 Startup	3	0.00	0.80		
07/14/2026 19:42 07/14/2026 19:42 Startup	1	0.00	0.80		
07/14/2026 19:44 07/14/2026 19:44 Startup	1	0.00	0.80		
07/15/2026 07:20 07/15/2026 07:20 Startup	1	0.00	0.80		
07/15/2026 07:27 07/15/2026 07:27 Startup	1	0.00	0.80		
07/15/2026 11:51 07/15/2026 12:00 Startup	10	0.05	0.80		
07/15/2026 20:58 07/15/2026 21:05 Shutdown	8	0.02	0.90		
07/20/2026 15:06 07/20/2026 15:16 Startup	11	0.05	0.80		
07/20/2026 21:28 07/20/2026 21:35 Shutdown	8	0.02	0.90		
07/21/2026 13:51 07/21/2026 14:00 Startup	10	0.05	0.80		
07/21/2026 20:58 07/21/2026 21:05 Shutdown	8	0.02	0.90		

Startup/Shutdown Event Report

CT6 - VOC Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:35 **Location:** Roseville, CA

Tag Name: CT6_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 75.25 Hours

Non-Operating Time: 2,084.75 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
08/03/2026 14:51 08/03/2026 14:59 Startup	9	0.04	0.80		
08/03/2026 20:58 08/03/2026 21:04 Shutdown	7	0.02	0.90		
08/04/2026 14:52 08/04/2026 15:01 Startup	10	0.04	0.80		
08/04/2026 19:58 08/04/2026 20:04 Shutdown	7	0.02	0.90		
08/05/2026 14:05 08/05/2026 14:14 Startup	10	0.04	0.80		
08/05/2026 19:58 08/05/2026 20:04 Shutdown	7	0.02	0.90		
08/06/2026 15:31 08/06/2026 15:42 Startup	12	0.04	0.80		
08/06/2026 19:58 08/06/2026 20:04 Shutdown	7	0.02	0.90		
08/19/2026 15:31 08/19/2026 15:42 Startup	12	0.05	0.80		
08/19/2026 21:58 08/19/2026 22:04 Shutdown	7	0.02	0.90		
08/27/2026 15:20 08/27/2026 15:30 Startup	11	0.04	0.80		
08/27/2026 19:58 08/27/2026 20:04 Shutdown	7	0.02	0.90		
09/08/2026 16:53 09/08/2026 17:02 Startup	10	0.04	0.80		
09/08/2026 21:58 09/08/2026 22:05 Shutdown	8	0.02	0.90		

Startup/Shutdown Event Report

CT6 - VOC Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:35 **Location:** Roseville, CA

Tag Name: CT6_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 75.25 Hours

Non-Operating Time: 2,084.75 Hours Report Time: 2,160.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Limit	Code - Description	Code - Description
09/09/2026 11:51 09/09/2026 12:03 Startup	13	0.04	0.80		
09/09/2026 20:58 09/09/2026 21:04 Shutdown	7	0.02	0.90		
09/10/2026 15:51 09/10/2026 16:00 Startup	10	0.04	0.80		
09/10/2026 19:59 09/10/2026 20:05 Shutdown	7	0.01	0.90		

No excess emissions were found in the reporting period.

Startup/Shutdown Event Report

CT6 - VOC Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:35 **Location:** Roseville, CA

Tag Name: CT6_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 75.25 Hours

Non-Operating Time: 2,084.75 Hours Report Time: 2,160.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Startup/Shutdown Event Report

CT6 - VOC Lbs Per Startup/Shutdown

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 09:35 **Location:** Roseville, CA

Tag Name: CT6_VOC_LbPerHr_1M SI = SampleInvalid, * = Excess Emission

Total Operating Time: 75.25 Hours

Non-Operating Time: 2,084.75 Hours Report Time: 2,160.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary	
1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

CO Invalid Data

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Tag Name: CT1_CO_Ppm_1H
Total Operating Time: 1,986.00 Hour(s)
Non-Operating Time: 222.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	**1,986.00 Hour(s)**
Total Monitor Downtime (Online only):	**0.00 Hour(s)**
Percent Monitor Availability:	**100.00 %**
Percent Monitor Downtime:	**0.00 %**

NOx Invalid Data

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Tag Name: CT1_NOx_Ppm_1H
Total Operating Time: 1,986.00 Hour(s)
Non-Operating Time: 222.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	**1,986.00 Hour(s)**
Total Monitor Downtime (Online only):	**0.00 Hour(s)**
Percent Monitor Availability:	**100.00 %**
Percent Monitor Downtime:	**0.00 %**

NOx SCR Invalid Data

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Tag Name: CT1_NOx_SCR_Ppm_1H
Total Operating Time: 1,986.00 Hour(s)
Non-Operating Time: 222.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	**1,986.00 Hour(s)**
Total Monitor Downtime (Online only):	**0.00 Hour(s)**
Percent Monitor Availability:	**100.00 %**
Percent Monitor Downtime:	**0.00 %**

O2 Invalid Data

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Tag Name: CT1_O2Dry_Pct_1H
Total Operating Time: 1,986.00 Hour(s)
Non-Operating Time: 222.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	**1,986.00 Hour(s)**
Total Monitor Downtime (Online only):	**0.00 Hour(s)**
Percent Monitor Availability:	**100.00 %**
Percent Monitor Downtime:	**0.00 %**

CO Invalid Data

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Tag Name: CT2_CO_Ppm_1H
Total Operating Time: 2,202.00 Hour(s)
Non-Operating Time: 6.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	09/16/2026 07:00	09/16/2026 07:59	1	54 - UNIT TRIP. NOT ENOUGH MINUTES AFTER MAINTENANCE	27 - PERFORM CALIBRATION WHEN UNIT COMES ON LINE.

Total Operating Time:	**2,202.00 Hour(s)**
Total Monitor Downtime (Online only):	**1.00 Hour(s)**
Percent Monitor Availability:	**99.95 %**
Percent Monitor Downtime:	**0.05 %**

Report Code	Type	Text	Duration	Duration Percent
54	Reason	UNIT TRIP. NOT ENOUGH MINUTES AFTER MAINTENANCE	1	100.00
27	Action	PERFORM CALIBRATION WHEN UNIT COMES ON LINE.	1	100.00

NOx Invalid Data

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:15 **Location:** Roseville, CA

Tag Name: CT2_NOx_Ppm_1H
Total Operating Time: 2,202.00 Hour(s)
Non-Operating Time: 6.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	09/16/2026 07:00	09/16/2026 07:59	1	54 - UNIT TRIP. NOT ENOUGH MINUTES AFTER MAINTENANCE	27 - PERFORM CALIBRATION WHEN UNIT COMES ON LINE.

Total Operating Time:	**2,202.00 Hour(s)**
Total Monitor Downtime (Online only):	**1.00 Hour(s)**
Percent Monitor Availability:	**99.95 %**
Percent Monitor Downtime:	**0.05 %**

Report Code	Type	Text	Duration	Duration Percent
54	Reason	UNIT TRIP. NOT ENOUGH MINUTES AFTER MAINTENANCE	1	100.00
27	Action	PERFORM CALIBRATION WHEN UNIT COMES ON LINE.	1	100.00

NOx SCR Invalid Data

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Tag Name: CT2_NOx_SCR_Ppm_1H
Total Operating Time: 2,202.00 Hour(s)
Non-Operating Time: 6.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	09/16/2026 07:00	09/16/2026 07:59	1	54 - UNIT TRIP. NOT ENOUGH MINUTES AFTER MAINTENANCE	27 - PERFORM CALIBRATION WHEN UNIT COMES ON LINE.

Total Operating Time:	**2,202.00 Hour(s)**
Total Monitor Downtime (Online only):	**1.00 Hour(s)**
Percent Monitor Availability:	**99.95 %**
Percent Monitor Downtime:	**0.05 %**

Report Code	Type	Text	Duration	Duration Percent
54	Reason	UNIT TRIP. NOT ENOUGH MINUTES AFTER MAINTENANCE	1	100.00
27	Action	PERFORM CALIBRATION WHEN UNIT COMES ON LINE.	1	100.00

O2 Invalid Data

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Tag Name: CT2_O2Dry_Pct_1H
Total Operating Time: 2,202.00 Hour(s)
Non-Operating Time: 6.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	09/16/2026 07:00	09/16/2026 07:59	1	54 - UNIT TRIP. NOT ENOUGH MINUTES AFTER MAINTENANCE	27 - PERFORM CALIBRATION WHEN UNIT COMES ON LINE.

Total Operating Time:	**2,202.00 Hour(s)**
Total Monitor Downtime (Online only):	**1.00 Hour(s)**
Percent Monitor Availability:	**99.95 %**
Percent Monitor Downtime:	**0.05 %**

Report Code	Type	Text	Duration	Duration Percent
54	Reason	UNIT TRIP. NOT ENOUGH MINUTES AFTER MAINTENANCE	1	100.00
27	Action	PERFORM CALIBRATION WHEN UNIT COMES ON LINE.	1	100.00

CO Invalid Data

CT5

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:40 **Location:** Roseville, CA

Tag Name: CT5_CO_Ppm_1H
Total Operating Time: 81.00 Hour(s)
Non-Operating Time: 2,079.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	**81.00 Hour(s)**
Total Monitor Downtime (Online only):	**0.00 Hour(s)**
Percent Monitor Availability:	**100.00 %**
Percent Monitor Downtime:	**0.00 %**

NOx Invalid Data

CT5

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:40 **Location:** Roseville, CA

Tag Name: CT5_NOx_Ppm_1H
Total Operating Time: 81.00 Hour(s)
Non-Operating Time: 2,079.00 Hour(s) Report Time: 2,160.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	08/06/2026 14:00	08/06/2026 14:59	1		
2	08/06/2026 15:00	08/06/2026 15:59	1		
3	08/07/2026 11:00	08/07/2026 11:59	1		
4	08/07/2026 12:00	08/07/2026 12:59	1		
5	08/20/2026 11:00	08/20/2026 11:59	1		
6	08/20/2026 12:00	08/20/2026 12:59	1	3 - Quality assurance calibration	
7	08/28/2026 08:00	08/28/2026 08:59	1		

Total Operating Time:	**81.00 Hour(s)**
Total Monitor Downtime (Online only):	**7.00 Hour(s)**
Percent Monitor Availability:	**91.36 %**
Percent Monitor Downtime:	**8.64 %**

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	1	14.29

NOx SCR Invalid Data

CT5

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:40 **Location:** Roseville, CA

Tag Name: CT5_NOx_SCR_Ppm_1H
Total Operating Time: 81.00 Hour(s)
Non-Operating Time: 2,079.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	**81.00 Hour(s)**
Total Monitor Downtime (Online only):	**0.00 Hour(s)**
Percent Monitor Availability:	**100.00 %**
Percent Monitor Downtime:	**0.00 %**

O2 Invalid Data

CT5

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:40 **Location:** Roseville, CA

Tag Name: CT5_O2Dry_Pct_1H
Total Operating Time: 81.00 Hour(s)
Non-Operating Time: 2,079.00 Hour(s) Report Time: 2,160.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	08/06/2026 14:00	08/06/2026 14:59	1		
2	08/06/2026 15:00	08/06/2026 15:59	1		
3	08/07/2026 11:00	08/07/2026 11:59	1		
4	08/07/2026 12:00	08/07/2026 12:59	1		
5	08/20/2026 11:00	08/20/2026 11:59	1		
6	08/20/2026 12:00	08/20/2026 12:59	1	3 - Quality assurance calibration	
7	08/28/2026 08:00	08/28/2026 08:59	1		

Total Operating Time:	**81.00 Hour(s)**
Total Monitor Downtime (Online only):	**7.00 Hour(s)**
Percent Monitor Availability:	**91.36 %**
Percent Monitor Downtime:	**8.64 %**

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	1	14.29

CO Invalid Data

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:45 **Location:** Roseville, CA

Tag Name: CT6_CO_Ppm_1H
Total Operating Time: 97.00 Hour(s)
Non-Operating Time: 2,063.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	**97.00 Hour(s)**
Total Monitor Downtime (Online only):	**0.00 Hour(s)**
Percent Monitor Availability:	**100.00 %**
Percent Monitor Downtime:	**0.00 %**

NOx Invalid Data

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:45 **Location:** Roseville, CA

Tag Name: CT6_NOx_Ppm_1H
Total Operating Time: 97.00 Hour(s)
Non-Operating Time: 2,063.00 Hour(s) Report Time: 2,160.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	07/14/2026 15:00	07/14/2026 15:59	1	8 - No prior online calibration within 26 hours	
2	07/14/2026 16:00	07/14/2026 16:59	1	8 - No prior online calibration within 26 hours	
3	07/14/2026 19:00	07/14/2026 19:59	1	8 - No prior online calibration within 26 hours	
4	07/15/2026 07:00	07/15/2026 07:59	1	8 - No prior online calibration within 26 hours	
5	07/15/2026 11:00	07/15/2026 11:59	1	8 - No prior online calibration within 26 hours	

Total Operating Time:	**97.00 Hour(s)**
Total Monitor Downtime (Online only):	**5.00 Hour(s)**
Percent Monitor Availability:	**94.85 %**
Percent Monitor Downtime:	**5.15 %**

Report Code	Type	Text	Duration	Duration Percent
8	Reason	No prior online calibration within 26 hours	5	100.00

NOx SCR Invalid Data

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:45 **Location:** Roseville, CA

Tag Name: CT6_NOx_SCR_Ppm_1H
Total Operating Time: 97.00 Hour(s)
Non-Operating Time: 2,063.00 Hour(s) Report Time: 2,160.00 Hour(s)

No incidents have been reported for this reporting period. Monitor has 100% availability.

Total Operating Time:	**97.00 Hour(s)**
Total Monitor Downtime (Online only):	**0.00 Hour(s)**
Percent Monitor Availability:	**100.00 %**
Percent Monitor Downtime:	**0.00 %**

O2 Invalid Data

CT6

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 09:45 **Location:** Roseville, CA

Tag Name: CT6_O2Dry_Pct_1H
Total Operating Time: 97.00 Hour(s)
Non-Operating Time: 2,063.00 Hour(s) Report Time: 2,160.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	07/14/2026 15:00	07/14/2026 15:59	1	8 - No prior online calibration within 26 hours	
2	07/14/2026 16:00	07/14/2026 16:59	1	8 - No prior online calibration within 26 hours	
3	07/14/2026 19:00	07/14/2026 19:59	1	8 - No prior online calibration within 26 hours	
4	07/15/2026 07:00	07/15/2026 07:59	1	8 - No prior online calibration within 26 hours	
5	07/15/2026 11:00	07/15/2026 11:59	1	8 - No prior online calibration within 26 hours	

Total Operating Time:	**97.00 Hour(s)**
Total Monitor Downtime (Online only):	**5.00 Hour(s)**
Percent Monitor Availability:	**94.85 %**
Percent Monitor Downtime:	**5.15 %**

Report Code	Type	Text	Duration	Duration Percent
8	Reason	No prior online calibration within 26 hours	5	100.00