DOCKETED	
Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	273236
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q3 2026 - Part 6s
Description:	N/A
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public Agency
Submission Date:	10/28/2026 7:52:54 AM
Docketed Date:	10/28/2026

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/12/2026 00:00	1.0	1.5	2	0.60	0.29826	0.99
07/12/2026 01:00	1.1	1.5	2	0.59	0.29694	0.99
07/12/2026 02:00	1.1	1.5	1	0.59	0.29682	0.99
07/12/2026 03:00	1.1	1.5	2	0.59	0.29706	0.99
07/12/2026 04:00	1.0	1.5	2	0.59	0.29676	0.99
07/12/2026 05:00	1.1	1.5	2	0.59	0.29628	0.99
07/12/2026 06:00	1.0	1.5	2	0.60	0.29994	1.00
07/12/2026 07:00	0.6	1.5	2	0.67	0.33510	1.12
07/12/2026 08:00	0.4	1.5	3	0.70	0.35034	1.17
07/12/2026 09:00	0.7	1.5	2	0.62	0.30858	1.03
07/12/2026 10:00	0.9	1.6	1	0.60	0.29880	1.00
07/12/2026 11:00	0.8	1.7	1	0.60	0.30240	1.01
07/12/2026 12:00	0.6	1.7	2	0.61	0.30534	1.02
07/12/2026 13:00	0.4	1.8	2	0.67	0.33486	1.12
07/12/2026 14:00	0.3	1.8	2	0.71	0.35322	1.18
07/12/2026 15:00	0.3	1.6	3	0.74	0.37242	1.24
07/12/2026 16:00	0.3	1.5	3	0.74	0.37182	1.24
07/12/2026 17:00	0.6	1.5	2	0.66	0.32940	1.10
07/12/2026 18:00	0.8	1.5	2	0.62	0.30852	1.03
07/12/2026 19:00	0.3	1.5	3	0.73	0.36648	1.22
07/12/2026 20:00	0.3	1.5	3	0.75	0.37620	1.25
07/12/2026 21:00	0.3	1.5	3	0.75	0.37458	1.25
07/12/2026 22:00	0.6	1.5	2	0.67	0.33546	1.12
07/12/2026 23:00	0.9	1.5	1	0.45	0.22470	0.75
Average/Sum#:	0.7	1.6	2	0.64	0.32210	1.07
Minimum:	0.3	1.5	1	0.45	0.22470	0.75
Maximum:	1.1	1.8	3	0.75	0.37620	1.25
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/13/2026 00:00	0.8	1.5	1	0.46	0.23184	0.77
07/13/2026 01:00	0.8	1.5	1	0.52	0.25818	0.86
07/13/2026 02:00	0.8	1.5	1	0.52	0.25830	0.86
07/13/2026 03:00	0.9	1.5	1	0.51	0.25368	0.85
07/13/2026 04:00	0.8	1.5	1	0.51	0.25746	0.86
07/13/2026 05:00	0.9	1.5	1	0.48	0.24120	0.80
07/13/2026 06:00	0.9	1.5	1	0.51	0.25746	0.86
07/13/2026 07:00	0.9	1.5	1	0.51	0.25494	0.85
07/13/2026 08:00	0.6	1.5	2	0.67	0.33300	1.11
07/13/2026 09:00	0.3	1.5	3	0.76	0.38226	1.27
07/13/2026 10:00	0.3	1.5	3	0.76	0.37980	1.27
07/13/2026 11:00	0.3	1.5	3	0.76	0.37914	1.26
07/13/2026 12:00	0.3	1.5	3	0.76	0.37854	1.26
07/13/2026 13:00	0.3	1.5	3	0.76	0.38034	1.27
07/13/2026 14:00	0.3	1.5	3	0.76	0.37938	1.26
07/13/2026 15:00	0.3	1.5	3	0.76	0.37962	1.27
07/13/2026 16:00	0.3	1.5	3	0.76	0.37920	1.26
07/13/2026 17:00	0.3	1.5	3	0.75	0.37530	1.25
07/13/2026 18:00	0.3	1.5	3	0.75	0.37464	1.25
07/13/2026 19:00	0.3	1.5	3	0.75	0.37722	1.26
07/13/2026 20:00	0.3	1.5	3	0.75	0.37524	1.25
07/13/2026 21:00	0.3	1.5	3	0.73	0.36588	1.22
07/13/2026 22:00	0.8	1.5	2	0.64	0.31944	1.06
07/13/2026 23:00	1.0	1.5	2	0.61	0.30378	1.01
Average/Sum#:	0.5	1.5	2	0.66	0.32816	1.09
Minimum:	0.3	1.5	1	0.46	0.23184	0.77
Maximum:	1.0	1.5	3	0.76	0.38226	1.27
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/14/2026 00:00	0.7	1.5	2	0.64	0.32154	1.07
07/14/2026 01:00	1.0	1.5	2	0.60	0.29886	1.00
07/14/2026 02:00	1.0	1.5	2	0.60	0.30000	1.00
07/14/2026 03:00	1.0	1.5	2	0.60	0.29832	0.99
07/14/2026 04:00	1.1	1.5	2	0.60	0.29796	0.99
07/14/2026 05:00	0.9	1.5	2	0.63	0.31626	1.05
07/14/2026 06:00	1.1	1.5	2	0.59	0.29610	0.99
07/14/2026 07:00	0.9	1.5	2	0.60	0.29916	1.00
07/14/2026 08:00	0.7	1.5	2	0.60	0.30204	1.01
07/14/2026 09:00	0.5	1.5	2	0.61	0.30684	1.02
07/14/2026 10:00	0.4	1.5	2	0.62	0.31164	1.04
07/14/2026 11:00	0.3	1.5	3	0.64	0.31782	1.06
07/14/2026 12:00	0.5	1.5	2	0.64	0.31854	1.06
07/14/2026 13:00	0.5	1.5	2	0.67	0.33696	1.12
07/14/2026 14:00	0.3	1.5	3	0.72	0.36078	1.20
07/14/2026 15:00	0.2	1.5	3	0.74	0.37062	1.24
07/14/2026 16:00	0.3	1.5	3	0.74	0.36768	1.23
07/14/2026 17:00	0.2	1.5	4	0.75	0.37368	1.25
07/14/2026 18:00	0.3	1.5	3	0.74	0.37140	1.24
07/14/2026 19:00	0.2	1.5	3	0.72	0.36066	1.20
07/14/2026 20:00	0.4	1.5	3	0.69	0.34548	1.15
07/14/2026 21:00	0.3	1.5	3	0.70	0.35190	1.17
07/14/2026 22:00	0.8	1.5	2	0.63	0.31530	1.05
07/14/2026 23:00	1.2	1.5	1	0.59	0.29442	0.98
Average/Sum#:	0.6	1.5	2	0.65	0.32642	1.09
Minimum:	0.2	1.5	1	0.59	0.29442	0.98
Maximum:	1.2	1.5	4	0.75	0.37368	1.25
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/15/2026 00:00	1.0	1.5	2	0.59	0.29676	0.99
07/15/2026 01:00	0.9	1.5	2	0.60	0.29814	0.99
07/15/2026 02:00	0.9	1.5	2	0.59	0.29634	0.99
07/15/2026 03:00	1.1	1.5	2	0.59	0.29556	0.99
07/15/2026 04:00	1.1	1.5	2	0.59	0.29544	0.98
07/15/2026 05:00	1.1	1.5	2	0.59	0.29574	0.99
07/15/2026 06:00	1.0	1.5	2	0.60	0.29814	0.99
07/15/2026 07:00	0.8	1.5	2	0.60	0.30150	1.01
07/15/2026 08:00	0.6	1.5	2	0.61	0.30462	1.02
07/15/2026 09:00	0.4	1.5	2	0.62	0.31182	1.04
07/15/2026 10:00	0.3	1.6	4	0.74	0.36996	1.23
07/15/2026 11:00	0.3	1.5	3	0.75	0.37362	1.25
07/15/2026 12:00	0.4	1.5	2	0.69	0.34272	1.14
07/15/2026 13:00	0.2	1.5	3	0.71	0.35598	1.19
07/15/2026 14:00	0.3	1.5	4	0.76	0.37968	1.27
07/15/2026 15:00	0.2	1.5	3	0.74	0.36816	1.23
07/15/2026 16:00	0.3	1.5	4	0.76	0.38064	1.27
07/15/2026 17:00	0.2	1.5	4	0.75	0.37542	1.25
07/15/2026 18:00	0.2	1.5	4	0.75	0.37746	1.26
07/15/2026 19:00	0.3	1.5	3	0.74	0.36786	1.23
07/15/2026 20:00	0.3	1.5	3	0.71	0.35562	1.19
07/15/2026 21:00	0.5	1.5	2	0.68	0.34236	1.14
07/15/2026 22:00	0.8	1.5	2	0.62	0.31146	1.04
07/15/2026 23:00	0.9	1.5	2	0.61	0.30450	1.02
Average/Sum#:	0.6	1.5	3	0.67	0.33331	1.11
Minimum:	0.2	1.5	2	0.59	0.29544	0.98
Maximum:	1.1	1.6	4	0.76	0.38064	1.27
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/16/2026 00:00	1.0	1.5	2	0.61	0.30360	1.01
07/16/2026 01:00	1.0	1.5	2	0.60	0.30030	1.00
07/16/2026 02:00	1.2	1.5	1	0.59	0.29586	0.99
07/16/2026 03:00	1.3	1.5	2	0.59	0.29460	0.98
07/16/2026 04:00	1.3	1.5	2	0.59	0.29478	0.98
07/16/2026 05:00	1.3	1.5	2	0.59	0.29478	0.98
07/16/2026 06:00	1.3	1.5	2	0.59	0.29484	0.98
07/16/2026 07:00	1.2	1.5	2	0.59	0.29718	0.99
07/16/2026 08:00	1.0	1.5	2	0.60	0.29910	1.00
07/16/2026 09:00	0.8	1.5	2	0.60	0.30090	1.00
07/16/2026 10:00	0.7	1.5	2	0.61	0.30408	1.01
07/16/2026 11:00	0.5	1.5	2	0.62	0.31128	1.04
07/16/2026 12:00	0.3	1.5	2	0.63	0.31650	1.06
07/16/2026 13:00	0.3	1.5	3	0.64	0.31920	1.06
07/16/2026 14:00	0.2	1.5	3	0.64	0.32040	1.07
07/16/2026 15:00	0.2	1.5	3	0.64	0.32106	1.07
07/16/2026 16:00	0.2	1.5	3	0.64	0.31968	1.07
07/16/2026 17:00	0.3	1.5	3	0.64	0.31944	1.06
07/16/2026 18:00	0.4	1.5	2	0.62	0.31170	1.04
07/16/2026 19:00	0.6	1.5	2	0.61	0.30450	1.02
07/16/2026 20:00	0.9	1.5	2	0.60	0.30096	1.00
07/16/2026 21:00	1.0	1.5	2	0.60	0.29952	1.00
07/16/2026 22:00	1.1	1.5	2	0.60	0.29862	1.00
07/16/2026 23:00	1.2	1.5	2	0.59	0.29730	0.99
Average/Sum#:	0.8	1.5	2	0.61	0.30501	1.02
Minimum:	0.2	1.5	1	0.59	0.29460	0.98
Maximum:	1.3	1.5	3	0.64	0.32106	1.07
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/17/2026 00:00	1.3	1.5	2	0.59	0.29682	0.99
07/17/2026 01:00	1.3	1.5	2	0.59	0.29592	0.99
07/17/2026 02:00	1.3	1.5	1	0.59	0.29592	0.99
07/17/2026 03:00	1.4	1.5	2	0.59	0.29574	0.99
07/17/2026 04:00	1.5	1.5	1	0.59	0.29472	0.98
07/17/2026 05:00	1.7	1.5	1	0.59	0.29436	0.98
07/17/2026 06:00	1.6	1.5	1	0.59	0.29580	0.99
07/17/2026 07:00	1.4	1.5	1	0.60	0.29808	0.99
07/17/2026 08:00	1.2	1.5	2	0.60	0.30000	1.00
07/17/2026 09:00	1.0	1.5	2	0.60	0.30084	1.00
07/17/2026 10:00	0.9	1.5	2	0.61	0.30288	1.01
07/17/2026 11:00	0.7	1.5	2	0.61	0.30696	1.02
07/17/2026 12:00	0.5	1.5	2	0.62	0.31152	1.04
07/17/2026 13:00	0.4	1.5	2	0.63	0.31524	1.05
07/17/2026 14:00	0.3	1.5	3	0.63	0.31734	1.06
07/17/2026 15:00	0.2	1.5	3	0.64	0.31842	1.06
07/17/2026 16:00	0.2	1.5	3	0.64	0.31806	1.06
07/17/2026 17:00	0.3	1.5	2	0.63	0.31524	1.05
07/17/2026 18:00	0.5	1.5	2	0.62	0.30870	1.03
07/17/2026 19:00	0.7	1.5	2	0.60	0.30162	1.01
07/17/2026 20:00	1.0	1.5	2	0.60	0.29814	0.99
07/17/2026 21:00	1.2	1.5	2	0.59	0.29700	0.99
07/17/2026 22:00	1.3	1.5	2	0.59	0.29586	0.99
07/17/2026 23:00	1.3	1.5	1	0.59	0.29532	0.98
Average/Sum#:	1.0	1.5	2	0.61	0.30294	1.01
Minimum:	0.2	1.5	1	0.59	0.29436	0.98
Maximum:	1.7	1.5	3	0.64	0.31842	1.06
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/18/2026 00:00	1.6	1.5	1	0.59	0.29436	0.98
07/18/2026 01:00	1.7	1.5	1	0.59	0.29322	0.98
07/18/2026 02:00	1.9	1.5	1	0.58	0.29220	0.97
07/18/2026 03:00	2.0	1.5	1	0.58	0.29238	0.97
07/18/2026 04:00	1.9	1.5	1	0.59	0.29328	0.98
07/18/2026 05:00	1.9	1.5	1	0.60	0.30228	1.01
07/18/2026 06:00	2.1	1.5	1	0.59	0.29376	0.98
07/18/2026 07:00	1.8	1.5	1	0.59	0.29430	0.98
07/18/2026 08:00	1.6	1.5	1	0.59	0.29688	0.99
07/18/2026 09:00	1.3	1.5	1	0.60	0.29904	1.00
07/18/2026 10:00	1.1	1.5	1	0.60	0.30042	1.00
07/18/2026 11:00	0.9	1.5	1	0.52	0.25860	0.86
07/18/2026 12:00	0.7	1.5	0	0.43	0.21360	0.71
07/18/2026 13:00	0.8	1.5	1	0.45	0.22704	0.76
07/18/2026 14:00	0.5	1.5	2	0.63	0.31356	1.05
07/18/2026 15:00	0.4	1.5	2	0.63	0.31512	1.05
07/18/2026 16:00	0.3	1.5	2	0.63	0.31620	1.05
07/18/2026 17:00	0.3	1.5	2	0.63	0.31566	1.05
07/18/2026 18:00	0.4	1.5	2	0.62	0.31236	1.04
07/18/2026 19:00	0.6	1.5	2	0.61	0.30552	1.02
07/18/2026 20:00	0.8	1.5	2	0.60	0.30222	1.01
07/18/2026 21:00	0.9	1.5	2	0.60	0.30126	1.00
07/18/2026 22:00	1.1	1.5	2	0.60	0.30030	1.00
07/18/2026 23:00	1.2	1.5	1	0.60	0.29928	1.00
Average/Sum#:	1.2	1.5	1	0.59	0.29304	0.98
Minimum:	0.3	1.5	0	0.43	0.21360	0.71
Maximum:	2.1	1.5	2	0.63	0.31620	1.05
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/19/2026 00:00	1.2	1.5	1	0.60	0.29790	0.99
07/19/2026 01:00	1.3	1.5	1	0.59	0.29640	0.99
07/19/2026 02:00	1.3	1.5	1	0.59	0.29538	0.98
07/19/2026 03:00	1.7	1.5	1	0.59	0.29412	0.98
07/19/2026 04:00	1.8	1.5	1	0.59	0.29286	0.98
07/19/2026 05:00	1.8	1.5	1	0.59	0.29274	0.98
07/19/2026 06:00	1.6	1.5	1	0.59	0.29412	0.98
07/19/2026 07:00	1.5	1.5	1	0.59	0.29628	0.99
07/19/2026 08:00	1.2	1.5	1	0.60	0.29820	0.99
07/19/2026 09:00	1.0	1.5	2	0.60	0.29982	1.00
07/19/2026 10:00	0.8	1.5	2	0.61	0.30330	1.01
07/19/2026 11:00	0.7	1.5	2	0.62	0.30996	1.03
07/19/2026 12:00	0.5	1.5	2	0.63	0.31452	1.05
07/19/2026 13:00	0.4	1.5	2	0.63	0.31722	1.06
07/19/2026 14:00	0.4	1.5	2	0.64	0.31926	1.06
07/19/2026 15:00	0.3	1.5	3	0.64	0.32184	1.07
07/19/2026 16:00	0.2	1.5	3	0.65	0.32382	1.08
07/19/2026 17:00	0.2	1.5	3	0.70	0.35124	1.17
07/19/2026 18:00	0.3	1.5	3	0.71	0.35520	1.18
07/19/2026 19:00	0.4	1.5	2	0.69	0.34470	1.15
07/19/2026 20:00	0.3	1.5	3	0.75	0.37290	1.24
07/19/2026 21:00	0.3	1.5	3	0.75	0.37428	1.25
07/19/2026 22:00	0.3	1.5	3	0.74	0.37092	1.24
07/19/2026 23:00	0.4	1.5	3	0.74	0.36960	1.23
Average/Sum#:	0.8	1.5	2	0.64	0.32111	1.07
Minimum:	0.2	1.5	1	0.59	0.29274	0.98
Maximum:	1.8	1.5	3	0.75	0.37428	1.25
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/20/2026 00:00	0.9	1.5	2	0.65	0.32298	1.08
07/20/2026 01:00	1.3	1.5	1	0.60	0.29844	0.99
07/20/2026 02:00	1.0	1.4	2	0.63	0.31314	1.04
07/20/2026 03:00	0.4	1.6	3	0.75	0.37368	1.25
07/20/2026 04:00	0.3	1.5	4	0.76	0.37974	1.27
07/20/2026 05:00	0.3	1.5	3	0.76	0.37800	1.26
07/20/2026 06:00	0.3	1.5	3	0.74	0.37026	1.23
07/20/2026 07:00	0.4	1.5	3	0.72	0.36234	1.21
07/20/2026 08:00	0.4	1.5	3	0.73	0.36456	1.22
07/20/2026 09:00	0.4	1.5	3	0.70	0.35208	1.17
07/20/2026 10:00	0.3	1.5	3	0.74	0.36894	1.23
07/20/2026 11:00	0.3	1.5	3	0.73	0.36546	1.22
07/20/2026 12:00	0.3	1.5	3	0.72	0.35844	1.19
07/20/2026 13:00	0.2	1.5	3	0.74	0.37068	1.24
07/20/2026 14:00	0.3	1.5	3	0.71	0.35532	1.18
07/20/2026 15:00	0.3	1.5	3	0.71	0.35592	1.19
07/20/2026 16:00	0.3	1.5	3	0.72	0.36150	1.21
07/20/2026 17:00	0.3	1.5	3	0.72	0.36090	1.20
07/20/2026 18:00	0.2	1.5	3	0.74	0.37068	1.24
07/20/2026 19:00	0.3	1.5	3	0.73	0.36378	1.21
07/20/2026 20:00	0.3	1.5	3	0.74	0.36834	1.23
07/20/2026 21:00	0.4	1.5	3	0.72	0.35886	1.20
07/20/2026 22:00	0.8	1.5	2	0.64	0.32142	1.07
07/20/2026 23:00	0.5	1.5	2	0.66	0.33012	1.10
Average/Sum#:	0.4	1.5	3	0.71	0.35523	1.18
Minimum:	0.2	1.4	1	0.60	0.29844	0.99
Maximum:	1.3	1.6	4	0.76	0.37974	1.27
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/21/2026 00:00	0.9	1.5	2	0.60	0.30174	1.01
07/21/2026 01:00	0.9	1.5	2	0.60	0.30198	1.01
07/21/2026 02:00	1.0	1.5	2	0.60	0.30192	1.01
07/21/2026 03:00	1.0	1.5	2	0.60	0.30102	1.00
07/21/2026 04:00	0.9	1.5	2	0.63	0.31584	1.05
07/21/2026 05:00	0.4	1.5	3	0.72	0.35760	1.19
07/21/2026 06:00	0.7	1.5	2	0.65	0.32562	1.09
07/21/2026 07:00	0.7	1.5	2	0.63	0.31410	1.05
07/21/2026 08:00	0.6	1.5	2	0.65	0.32268	1.08
07/21/2026 09:00	0.6	1.5	2	0.62	0.31158	1.04
07/21/2026 10:00	0.4	1.5	2	0.64	0.31842	1.06
07/21/2026 11:00	0.3	1.5	3	0.68	0.34194	1.14
07/21/2026 12:00	0.3	1.5	3	0.75	0.37512	1.25
07/21/2026 13:00	0.3	1.5	3	0.74	0.36894	1.23
07/21/2026 14:00	0.3	1.5	3	0.74	0.37242	1.24
07/21/2026 15:00	0.3	1.5	3	0.76	0.37782	1.26
07/21/2026 16:00	0.2	1.5	3	0.74	0.37038	1.23
07/21/2026 17:00	0.2	1.5	3	0.75	0.37584	1.25
07/21/2026 18:00	0.3	1.5	4	0.77	0.38334	1.28
07/21/2026 19:00	0.3	1.5	4	0.76	0.38202	1.27
07/21/2026 20:00	0.2	1.5	3	0.76	0.37830	1.26
07/21/2026 21:00	0.3	1.5	3	0.74	0.37068	1.24
07/21/2026 22:00	0.4	1.5	3	0.72	0.36162	1.21
07/21/2026 23:00	0.5	1.5	3	0.71	0.35370	1.18
Average/Sum#:	0.5	1.5	3	0.69	0.34519	1.15
Minimum:	0.2	1.5	2	0.60	0.30102	1.00
Maximum:	1.0	1.5	4	0.77	0.38334	1.28
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/22/2026 00:00	1.1	1.5	1	0.60	0.29802	0.99
07/22/2026 01:00	1.0	1.5	1	0.60	0.29838	0.99
07/22/2026 02:00	1.1	1.5	1	0.59	0.29730	0.99
07/22/2026 03:00	1.3	1.5	1	0.59	0.29640	0.99
07/22/2026 04:00	1.2	1.5	1	0.60	0.29964	1.00
07/22/2026 05:00	0.8	1.5	2	0.63	0.31692	1.06
07/22/2026 06:00	1.2	1.5	1	0.59	0.29706	0.99
07/22/2026 07:00	1.0	1.5	2	0.61	0.30528	1.02
07/22/2026 08:00	0.6	1.5	2	0.66	0.32760	1.09
07/22/2026 09:00	1.0	1.5	1	0.60	0.29898	1.00
07/22/2026 10:00	0.8	1.5	2	0.60	0.30084	1.00
07/22/2026 11:00	0.7	1.5	2	0.61	0.30342	1.01
07/22/2026 12:00	0.7	1.5	2	0.61	0.30504	1.02
07/22/2026 13:00	0.6	1.5	2	0.61	0.30684	1.02
07/22/2026 14:00	0.5	1.5	2	0.62	0.30852	1.03
07/22/2026 15:00	0.5	1.5	2	0.62	0.30906	1.03
07/22/2026 16:00	0.5	1.5	2	0.62	0.30858	1.03
07/22/2026 17:00	0.5	1.5	2	0.62	0.30762	1.03
07/22/2026 18:00	0.6	1.5	2	0.61	0.30426	1.01
07/22/2026 19:00	0.8	1.5	2	0.60	0.29964	1.00
07/22/2026 20:00	1.1	1.5	2	0.59	0.29592	0.99
07/22/2026 21:00	1.2	1.5	1	0.59	0.29382	0.98
07/22/2026 22:00	1.3	1.5	1	0.59	0.29310	0.98
07/22/2026 23:00	1.5	1.5	1	0.58	0.29214	0.97
Average/Sum#:	0.9	1.5	2	0.61	0.30268	1.01
Minimum:	0.5	1.5	1	0.58	0.29214	0.97
Maximum:	1.5	1.5	2	0.66	0.32760	1.09
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/23/2026 00:00	1.7	1.5	1	0.58	0.29154	0.97
07/23/2026 01:00	1.7	1.5	1	0.58	0.29160	0.97
07/23/2026 02:00	1.8	1.5	1	0.58	0.29052	0.97
07/23/2026 03:00	1.9	1.5	1	0.58	0.29076	0.97
07/23/2026 04:00	1.9	1.5	1	0.58	0.29166	0.97
07/23/2026 05:00	1.8	1.5	1	0.58	0.29214	0.97
07/23/2026 06:00	1.7	1.5	1	0.59	0.29370	0.98
07/23/2026 07:00	1.6	1.5	1	0.59	0.29586	0.99
07/23/2026 08:00	1.3	1.5	1	0.57	0.28392	0.95
07/23/2026 09:00	0.9	1.5	1	0.43	0.21444	0.71
07/23/2026 10:00	0.8	1.5	1	0.43	0.21288	0.71
07/23/2026 11:00	0.8	1.6	1	0.53	0.26322	0.88
07/23/2026 12:00	0.6	1.5	2	0.62	0.30990	1.03
07/23/2026 13:00	0.5	1.5	2	0.63	0.31272	1.04
07/23/2026 14:00	0.4	1.5	2	0.63	0.31392	1.05
07/23/2026 15:00	0.4	1.5	2	0.63	0.31512	1.05
07/23/2026 16:00	0.4	1.5	2	0.63	0.31572	1.05
07/23/2026 17:00	0.4	1.5	2	0.63	0.31686	1.06
07/23/2026 18:00	0.3	1.5	2	0.65	0.32622	1.09
07/23/2026 19:00	0.6	1.5	2	0.62	0.30942	1.03
07/23/2026 20:00	0.6	1.5	2	0.63	0.31620	1.05
07/23/2026 21:00	1.0	1.5	1	0.60	0.30012	1.00
07/23/2026 22:00	1.1	1.5	1	0.60	0.30078	1.00
07/23/2026 23:00	1.2	1.5	2	0.60	0.30192	1.01
Average/Sum#:	1.1	1.5	1	0.59	0.29380	0.98
Minimum:	0.3	1.5	1	0.43	0.21288	0.71
Maximum:	1.9	1.6	2	0.65	0.32622	1.09
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/24/2026 00:00	1.3	1.5	1	0.59	0.29520	0.98
07/24/2026 01:00	1.3	1.5	1	0.59	0.29484	0.98
07/24/2026 02:00	1.3	1.5	1	0.59	0.29436	0.98
07/24/2026 03:00	1.6	1.5	2	0.59	0.29382	0.98
07/24/2026 04:00	1.8	1.5	1	0.59	0.29274	0.98
07/24/2026 05:00	1.9	1.5	1	0.59	0.29340	0.98
07/24/2026 06:00	1.6	1.5	1	0.59	0.29514	0.98
07/24/2026 07:00	1.4	1.5	1	0.60	0.29778	0.99
07/24/2026 08:00	1.2	1.5	2	0.60	0.29982	1.00
07/24/2026 09:00	0.9	1.5	2	0.60	0.30228	1.01
07/24/2026 10:00	0.8	1.5	2	0.61	0.30504	1.02
07/24/2026 11:00	0.9	1.5	0	0.44	0.21750	0.73
07/24/2026 12:00	1.0	1.6	2	0.55	0.27486	0.92
07/24/2026 13:00	0.3	1.5	3	0.70	0.34992	1.17
07/24/2026 14:00	0.3	1.5	3	0.76	0.37878	1.26
07/24/2026 15:00	0.3	1.5	3	0.75	0.37704	1.26
07/24/2026 16:00	0.4	1.5	2	0.68	0.33954	1.13
07/24/2026 17:00	0.4	1.5	2	0.70	0.34884	1.16
07/24/2026 18:00	0.3	1.5	3	0.71	0.35622	1.19
07/24/2026 19:00	0.8	1.5	2	0.63	0.31386	1.05
07/24/2026 20:00	0.9	1.5	2	0.63	0.31488	1.05
07/24/2026 21:00	1.2	1.5	1	0.61	0.30294	1.01
07/24/2026 22:00	1.7	1.5	1	0.59	0.29406	0.98
07/24/2026 23:00	1.3	1.5	1	0.59	0.29622	0.99
Average/Sum#:	1.0	1.5	2	0.62	0.30955	1.03
Minimum:	0.3	1.5	0	0.44	0.21750	0.73
Maximum:	1.9	1.6	3	0.76	0.37878	1.26
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/25/2026 00:00	1.3	1.5	1	0.59	0.29544	0.98
07/25/2026 01:00	1.4	1.5	1	0.59	0.29472	0.98
07/25/2026 02:00	1.7	1.5	1	0.59	0.29430	0.98
07/25/2026 03:00	1.8	1.5	1	0.59	0.29382	0.98
07/25/2026 04:00	1.8	1.5	1	0.59	0.29316	0.98
07/25/2026 05:00	1.9	1.5	1	0.59	0.29310	0.98
07/25/2026 06:00	1.7	1.5	1	0.59	0.29532	0.98
07/25/2026 07:00	1.4	1.5	1	0.60	0.29784	0.99
07/25/2026 08:00	1.2	1.5	2	0.60	0.29928	1.00
07/25/2026 09:00	1.0	1.5	2	0.60	0.30222	1.01
07/25/2026 10:00	0.7	1.5	2	0.61	0.30540	1.02
07/25/2026 11:00	0.6	1.5	2	0.62	0.31026	1.03
07/25/2026 12:00	0.4	1.5	2	0.63	0.31512	1.05
07/25/2026 13:00	0.4	1.5	2	0.64	0.31806	1.06
07/25/2026 14:00	0.3	1.5	3	0.64	0.31980	1.07
07/25/2026 15:00	0.3	1.5	3	0.64	0.32028	1.07
07/25/2026 16:00	0.2	1.5	3	0.64	0.32190	1.07
07/25/2026 17:00	0.2	1.5	3	0.64	0.32112	1.07
07/25/2026 18:00	0.4	1.5	2	0.63	0.31542	1.05
07/25/2026 19:00	0.5	1.5	2	0.62	0.30780	1.03
07/25/2026 20:00	0.7	1.5	2	0.61	0.30258	1.01
07/25/2026 21:00	1.0	1.5	2	0.60	0.29964	1.00
07/25/2026 22:00	1.1	1.5	1	0.60	0.29838	0.99
07/25/2026 23:00	1.2	1.5	1	0.59	0.29718	0.99
Average/Sum#:	1.0	1.5	2	0.61	0.30467	1.02
Minimum:	0.2	1.5	1	0.59	0.29310	0.98
Maximum:	1.9	1.5	3	0.64	0.32190	1.07
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/26/2026 00:00	1.2	1.5	1	0.59	0.29688	0.99
07/26/2026 01:00	1.3	1.5	1	0.59	0.29562	0.99
07/26/2026 02:00	1.3	1.5	1	0.59	0.29400	0.98
07/26/2026 03:00	1.7	1.5	2	0.59	0.29346	0.98
07/26/2026 04:00	1.7	1.5	1	0.59	0.29334	0.98
07/26/2026 05:00	1.8	1.5	1	0.59	0.29322	0.98
07/26/2026 06:00	1.6	1.5	1	0.59	0.29412	0.98
07/26/2026 07:00	1.0	1.5	1	0.43	0.21702	0.72
07/26/2026 08:00	1.0	1.5	1	0.53	0.26376	0.88
07/26/2026 09:00	1.0	1.5	2	0.60	0.30162	1.01
07/26/2026 10:00	0.8	1.5	2	0.61	0.30456	1.02
07/26/2026 11:00	0.6	1.5	2	0.62	0.30798	1.03
07/26/2026 12:00	0.5	1.5	2	0.63	0.31326	1.04
07/26/2026 13:00	0.4	1.5	2	0.63	0.31710	1.06
07/26/2026 14:00	0.3	1.5	3	0.64	0.31938	1.06
07/26/2026 15:00	0.3	1.5	3	0.64	0.31950	1.07
07/26/2026 16:00	0.3	1.5	3	0.64	0.31974	1.07
07/26/2026 17:00	0.3	1.5	3	0.64	0.31878	1.06
07/26/2026 18:00	0.4	1.5	2	0.63	0.31272	1.04
07/26/2026 19:00	0.6	1.5	2	0.61	0.30564	1.02
07/26/2026 20:00	0.8	1.5	2	0.61	0.30600	1.02
07/26/2026 21:00	0.7	1.5	2	0.67	0.33300	1.11
07/26/2026 22:00	0.8	1.5	2	0.66	0.33048	1.10
07/26/2026 23:00	1.3	1.5	1	0.59	0.29526	0.98
Average/Sum#:	0.9	1.5	2	0.60	0.30194	1.01
Minimum:	0.3	1.5	1	0.43	0.21702	0.72
Maximum:	1.8	1.5	3	0.67	0.33300	1.11
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/27/2026 00:00	1.1	1.5	2	0.61	0.30390	1.01
07/27/2026 01:00	1.5	1.5	1	0.59	0.29298	0.98
07/27/2026 02:00	1.7	1.5	1	0.58	0.29220	0.97
07/27/2026 03:00	1.8	1.5	1	0.58	0.29208	0.97
07/27/2026 04:00	1.8	1.5	1	0.58	0.29136	0.97
07/27/2026 05:00	1.9	1.5	1	0.58	0.29070	0.97
07/27/2026 06:00	1.7	1.5	1	0.59	0.29286	0.98
07/27/2026 07:00	1.5	1.5	1	0.59	0.29544	0.98
07/27/2026 08:00	1.4	1.5	1	0.59	0.29730	0.99
07/27/2026 09:00	1.0	1.5	1	0.60	0.30024	1.00
07/27/2026 10:00	0.9	1.5	1	0.60	0.30246	1.01
07/27/2026 11:00	0.7	1.5	2	0.62	0.30768	1.03
07/27/2026 12:00	0.5	1.5	2	0.63	0.31254	1.04
07/27/2026 13:00	0.1	1.5	2	0.63	0.31584	1.05
07/27/2026 14:00	0.1	1.5	2	0.64	0.31776	1.06
07/27/2026 15:00	0.0	1.5	3	0.64	0.31800	1.06
07/27/2026 16:00	0.0	1.5	3	0.64	0.31908	1.06
07/27/2026 17:00	0.0	1.5	2	0.64	0.31962	1.07
07/27/2026 18:00	0.3	1.5	2	0.67	0.33486	1.12
07/27/2026 19:00	0.1	1.5	2	0.68	0.33852	1.13
07/27/2026 20:00	0.4	1.5	2	0.64	0.31848	1.06
07/27/2026 21:00	0.8	1.5	1	0.60	0.29802	0.99
07/27/2026 22:00	0.8	1.5	1	0.59	0.29676	0.99
07/27/2026 23:00	0.9	1.5	1	0.59	0.29580	0.99
Average/Sum#:	0.9	1.5	2	0.61	0.30602	1.02
Minimum:	0.0	1.5	1	0.58	0.29070	0.97
Maximum:	1.9	1.5	3	0.68	0.33852	1.13
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/28/2026 00:00	0.9	1.5	1	0.59	0.29538	0.98
07/28/2026 01:00	0.9	1.5	1	0.59	0.29382	0.98
07/28/2026 02:00	1.1	1.5	1	0.59	0.29406	0.98
07/28/2026 03:00	1.5	1.5	2	0.59	0.29322	0.98
07/28/2026 04:00	1.5	1.5	1	0.59	0.29328	0.98
07/28/2026 05:00	1.5	1.5	1	0.59	0.29280	0.98
07/28/2026 06:00	1.4	1.5	1	0.59	0.29442	0.98
07/28/2026 07:00	0.7	1.5	1	0.48	0.24174	0.81
07/28/2026 08:00	0.4	1.5	1	0.43	0.21342	0.71
07/28/2026 09:00	0.4	1.6	1	0.43	0.21324	0.71
07/28/2026 10:00	0.4	1.5	1	0.43	0.21300	0.71
07/28/2026 11:00	0.4	1.5	1	0.46	0.22878	0.76
07/28/2026 12:00	0.5	1.5	1	0.58	0.28926	0.96
07/28/2026 13:00	0.4	1.5	0	0.43	0.21486	0.72
07/28/2026 14:00	0.4	1.5	1	0.43	0.21372	0.71
07/28/2026 15:00	0.4	1.5	1	0.46	0.22812	0.76
07/28/2026 16:00	0.6	1.5	2	0.61	0.30342	1.01
07/28/2026 17:00	0.6	1.5	1	0.61	0.30456	1.02
07/28/2026 18:00	0.2	1.5	2	0.63	0.31296	1.04
07/28/2026 19:00	0.2	1.5	2	0.62	0.30942	1.03
07/28/2026 20:00	0.4	1.5	2	0.61	0.30456	1.02
07/28/2026 21:00	0.5	1.5	2	0.60	0.30192	1.01
07/28/2026 22:00	0.6	1.5	1	0.60	0.29988	1.00
07/28/2026 23:00	0.5	1.5	0	0.44	0.21756	0.73
Average/Sum#:	0.7	1.5	1	0.54	0.26948	0.90
Minimum:	0.2	1.5	0	0.43	0.21300	0.71
Maximum:	1.5	1.6	2	0.63	0.31296	1.04
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/29/2026 00:00	0.4	1.5	1	0.42	0.21228	0.71
07/29/2026 01:00	0.4	1.5	1	0.42	0.21234	0.71
07/29/2026 02:00	0.4	1.5	1	0.43	0.21264	0.71
07/29/2026 03:00	0.5	1.5	1	0.43	0.21288	0.71
07/29/2026 04:00	0.4	1.5	1	0.43	0.21282	0.71
07/29/2026 05:00	0.5	1.5	1	0.43	0.21282	0.71
07/29/2026 06:00	0.5	1.5	1	0.43	0.21288	0.71
07/29/2026 07:00	0.4	1.5	1	0.43	0.21312	0.71
07/29/2026 08:00	0.4	1.5	1	0.43	0.21258	0.71
07/29/2026 09:00	0.4	1.5	1	0.43	0.21270	0.71
07/29/2026 10:00	0.4	1.5	1	0.45	0.22740	0.76
07/29/2026 11:00	0.3	1.5	2	0.62	0.31200	1.04
07/29/2026 12:00	0.1	1.5	2	0.63	0.31488	1.05
07/29/2026 13:00	0.0	1.5	3	0.64	0.31896	1.06
07/29/2026 14:00	0.0	1.5	3	0.64	0.32052	1.07
07/29/2026 15:00	0.0	1.5	3	0.64	0.32226	1.07
07/29/2026 16:00	0.0	1.5	3	0.65	0.32274	1.08
07/29/2026 17:00	0.0	1.5	3	0.65	0.32460	1.08
07/29/2026 18:00	0.0	1.5	3	0.65	0.32508	1.08
07/29/2026 19:00	0.0	1.5	2	0.62	0.31212	1.04
07/29/2026 20:00	0.2	1.5	2	0.61	0.30510	1.02
07/29/2026 21:00	0.5	1.5	0	0.43	0.21720	0.72
07/29/2026 22:00	0.4	1.5	1	0.42	0.21192	0.71
07/29/2026 23:00	0.4	1.5	1	0.42	0.21222	0.71
Average/Sum#:	0.3	1.5	2	0.51	0.25725	0.86
Minimum:	0.0	1.5	0	0.42	0.21192	0.71
Maximum:	0.5	1.5	3	0.65	0.32508	1.08
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/30/2026 00:00	0.4	1.5	1	0.42	0.21240	0.71
07/30/2026 01:00	0.4	1.5	1	0.42	0.21240	0.71
07/30/2026 02:00	0.4	1.5	1	0.42	0.21240	0.71
07/30/2026 03:00	0.5	1.5	1	0.43	0.21264	0.71
07/30/2026 04:00	0.4	1.5	1	0.43	0.21270	0.71
07/30/2026 05:00	0.4	1.5	1	0.43	0.21258	0.71
07/30/2026 06:00	0.4	1.5	1	0.43	0.21270	0.71
07/30/2026 07:00	0.4	1.5	1	0.43	0.21306	0.71
07/30/2026 08:00	0.4	1.5	1	0.42	0.21228	0.71
07/30/2026 09:00	0.4	1.5	1	0.42	0.21222	0.71
07/30/2026 10:00	0.4	1.5	1	0.42	0.21210	0.71
07/30/2026 11:00	0.4	1.5	1	0.43	0.21258	0.71
07/30/2026 12:00	0.4	1.5	1	0.43	0.21264	0.71
07/30/2026 13:00	0.4	1.5	1	0.43	0.21288	0.71
07/30/2026 14:00	0.4	1.5	1	0.47	0.23592	0.79
07/30/2026 15:00	0.4	1.5	1	0.43	0.21354	0.71
07/30/2026 16:00	0.4	1.5	1	0.44	0.22122	0.74
07/30/2026 17:00	0.4	1.5	1	0.48	0.24024	0.80
07/30/2026 18:00	0.4	1.5	1	0.52	0.25890	0.86
07/30/2026 19:00	0.4	1.5	1	0.44	0.22224	0.74
07/30/2026 20:00	0.4	1.5	1	0.42	0.21090	0.70
07/30/2026 21:00	0.4	1.5	1	0.43	0.21570	0.72
07/30/2026 22:00	0.4	1.5	1	0.44	0.22206	0.74
07/30/2026 23:00	0.4	1.5	1	0.43	0.21270	0.71
Average/Sum#:	0.4	1.5	1	0.44	0.21788	0.73
Minimum:	0.4	1.5	1	0.42	0.21090	0.70
Maximum:	0.5	1.5	1	0.52	0.25890	0.86
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
07/31/2026 00:00	0.4	1.5	1	0.42	0.21156	0.71
07/31/2026 01:00	0.4	1.5	1	0.42	0.21210	0.71
07/31/2026 02:00	0.4	1.5	1	0.42	0.21246	0.71
07/31/2026 03:00	0.5	1.5	1	0.43	0.21276	0.71
07/31/2026 04:00	0.5	1.5	1	0.45	0.22398	0.75
07/31/2026 05:00	0.5	1.5	1	0.43	0.21318	0.71
07/31/2026 06:00	0.4	1.5	1	0.43	0.21300	0.71
07/31/2026 07:00	0.4	1.5	1	0.43	0.21342	0.71
07/31/2026 08:00	0.4	1.5	1	0.43	0.21282	0.71
07/31/2026 09:00	0.4	1.5	1	0.43	0.21264	0.71
07/31/2026 10:00	0.5	1.5	1	0.43	0.21252	0.71
07/31/2026 11:00	0.5	1.5	1	0.44	0.22110	0.74
07/31/2026 12:00	0.4	1.5	1	0.52	0.26190	0.87
07/31/2026 13:00	0.4	1.5	1	0.52	0.26124	0.87
07/31/2026 14:00	0.4	1.5	1	0.52	0.26136	0.87
07/31/2026 15:00	0.5	1.5	2	0.63	0.31668	1.06
07/31/2026 16:00	0.2	1.5	2	0.66	0.33246	1.11
07/31/2026 17:00	0.0	1.5	3	0.71	0.35274	1.18
07/31/2026 18:00	0.0	1.5	4	0.76	0.38004	1.27
07/31/2026 19:00	0.5	1.5	2	0.62	0.30942	1.03
07/31/2026 20:00	0.3	1.5	2	0.61	0.30486	1.02
07/31/2026 21:00	0.4	1.5	2	0.60	0.30228	1.01
07/31/2026 22:00	0.6	1.5	2	0.60	0.29934	1.00
07/31/2026 23:00	0.5	1.5	0	0.43	0.21720	0.72
Average/Sum#:	0.4	1.5	1	0.51	0.25713	0.86
Minimum:	0.0	1.5	0	0.42	0.21156	0.71
Maximum:	0.6	1.5	4	0.76	0.38004	1.27
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/01/2026 00:00	0.4	1.5	1	0.43	0.21252	0.71
08/01/2026 01:00	0.4	1.5	1	0.42	0.21246	0.71
08/01/2026 02:00	0.4	1.5	1	0.43	0.21276	0.71
08/01/2026 03:00	0.5	1.5	1	0.43	0.21312	0.71
08/01/2026 04:00	0.4	1.5	1	0.43	0.21330	0.71
08/01/2026 05:00	0.4	1.5	1	0.43	0.21342	0.71
08/01/2026 06:00	0.4	1.5	1	0.43	0.21342	0.71
08/01/2026 07:00	0.4	1.5	1	0.43	0.21366	0.71
08/01/2026 08:00	0.4	1.5	1	0.43	0.21306	0.71
08/01/2026 09:00	0.4	1.5	1	0.43	0.21294	0.71
08/01/2026 10:00	0.4	1.5	1	0.43	0.21276	0.71
08/01/2026 11:00	0.4	1.5	1	0.43	0.21360	0.71
08/01/2026 12:00	0.4	1.5	1	0.43	0.21354	0.71
08/01/2026 13:00	0.4	1.5	1	0.43	0.21330	0.71
08/01/2026 14:00	0.4	1.5	1	0.45	0.22746	0.76
08/01/2026 15:00	0.6	1.5	2	0.61	0.30372	1.01
08/01/2026 16:00	0.2	1.5	2	0.62	0.30930	1.03
08/01/2026 17:00	0.1	1.5	2	0.68	0.34068	1.14
08/01/2026 18:00	0.0	1.5	3	0.76	0.37806	1.26
08/01/2026 19:00	0.0	1.5	3	0.70	0.35118	1.17
08/01/2026 20:00	0.7	1.5	1	0.60	0.29874	1.00
08/01/2026 21:00	0.2	1.5	2	0.62	0.30762	1.03
08/01/2026 22:00	0.3	1.5	2	0.61	0.30342	1.01
08/01/2026 23:00	0.5	1.5	1	0.48	0.24216	0.81
Average/Sum#:	0.4	1.5	1	0.51	0.25193	0.84
Minimum:	0.0	1.5	1	0.42	0.21246	0.71
Maximum:	0.7	1.5	3	0.76	0.37806	1.26
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/02/2026 00:00	0.4	1.5	0	0.43	0.21372	0.71
08/02/2026 01:00	0.4	1.5	1	0.42	0.21156	0.71
08/02/2026 02:00	0.4	1.5	1	0.42	0.21168	0.71
08/02/2026 03:00	0.5	1.5	1	0.42	0.21246	0.71
08/02/2026 04:00	0.4	1.5	1	0.42	0.21240	0.71
08/02/2026 05:00	0.6	1.5	1	0.43	0.21270	0.71
08/02/2026 06:00	0.6	1.5	1	0.42	0.21246	0.71
08/02/2026 07:00	0.4	1.5	1	0.43	0.21264	0.71
08/02/2026 08:00	0.4	1.5	1	0.42	0.21204	0.71
08/02/2026 09:00	0.4	1.5	1	0.42	0.21156	0.71
08/02/2026 10:00	0.4	1.5	1	0.42	0.21162	0.71
08/02/2026 11:00	0.4	1.5	1	0.42	0.21228	0.71
08/02/2026 12:00	0.4	1.5	1	0.42	0.21210	0.71
08/02/2026 13:00	0.4	1.5	0	0.45	0.22746	0.76
08/02/2026 14:00	0.6	1.5	1	0.61	0.30324	1.01
08/02/2026 15:00	0.5	1.5	1	0.60	0.30234	1.01
08/02/2026 16:00	0.3	1.5	2	0.63	0.31722	1.06
08/02/2026 17:00	0.4	1.5	1	0.61	0.30714	1.02
08/02/2026 18:00	0.4	1.5	2	0.61	0.30492	1.02
08/02/2026 19:00	0.0	1.5	3	0.64	0.31848	1.06
08/02/2026 20:00	0.0	1.5	2	0.63	0.31494	1.05
08/02/2026 21:00	0.1	1.5	2	0.62	0.30990	1.03
08/02/2026 22:00	1.6	1.5	1	0.52	0.25878	0.86
08/02/2026 23:00	1.1	1.5	1	0.49	0.24726	0.82
Average/Sum#:	0.5	1.5	1	0.50	0.24879	0.83
Minimum:	0.0	1.5	0	0.42	0.21156	0.71
Maximum:	1.6	1.5	3	0.64	0.31848	1.06
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/03/2026 00:00	0.4	1.5	0	0.42	0.21186	0.71
08/03/2026 01:00	0.4	1.5	1	0.46	0.22854	0.76
08/03/2026 02:00	0.4	1.5	1	0.42	0.21120	0.70
08/03/2026 03:00	0.5	1.5	1	0.42	0.21120	0.70
08/03/2026 04:00	0.4	1.5	1	0.48	0.24204	0.81
08/03/2026 05:00	0.6	1.5	1	0.47	0.23604	0.79
08/03/2026 06:00	0.6	1.5	0	0.43	0.21252	0.71
08/03/2026 07:00	0.5	1.5	1	0.43	0.21270	0.71
08/03/2026 08:00	0.5	1.5	1	0.42	0.21162	0.71
08/03/2026 09:00	0.5	1.5	1	0.42	0.21150	0.71
08/03/2026 10:00	0.4	1.5	1	0.42	0.21156	0.71
08/03/2026 11:00	0.4	1.5	1	0.42	0.21222	0.71
08/03/2026 12:00	0.4	1.5	0	0.46	0.23058	0.77
08/03/2026 13:00	0.4	1.5	0	0.48	0.24054	0.80
08/03/2026 14:00	0.4	1.5	1	0.62	0.31116	1.04
08/03/2026 15:00	0.4	1.5	1	0.61	0.30666	1.02
08/03/2026 16:00	0.1	1.5	2	0.67	0.33444	1.11
08/03/2026 17:00	0.1	1.5	2	0.68	0.34242	1.14
08/03/2026 18:00	0.0	1.5	4	0.77	0.38388	1.28
08/03/2026 19:00	0.0	1.5	3	0.74	0.36750	1.23
08/03/2026 20:00	0.0	1.5	3	0.71	0.35250	1.18
08/03/2026 21:00	0.2	1.5	2	0.64	0.31764	1.06
08/03/2026 22:00	1.2	1.5	1	0.49	0.24276	0.81
08/03/2026 23:00	0.5	1.5	1	0.51	0.25320	0.84
Average/Sum#:	0.4	1.5	1	0.52	0.26235	0.88
Minimum:	0.0	1.5	0	0.42	0.21120	0.70
Maximum:	1.2	1.5	4	0.77	0.38388	1.28
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/04/2026 00:00	0.4	1.5	0	0.44	0.22074	0.74
08/04/2026 01:00	0.4	1.5	0	0.42	0.21156	0.71
08/04/2026 02:00	0.4	1.5	0	0.42	0.21144	0.70
08/04/2026 03:00	0.5	1.6	1	0.44	0.22236	0.74
08/04/2026 04:00	0.5	1.5	1	0.49	0.24420	0.81
08/04/2026 05:00	0.5	1.5	1	0.47	0.23568	0.79
08/04/2026 06:00	0.5	1.5	0	0.46	0.22794	0.76
08/04/2026 07:00	0.4	1.5	1	0.42	0.21198	0.71
08/04/2026 08:00	0.4	1.5	1	0.42	0.21162	0.71
08/04/2026 09:00	0.4	1.5	0	0.42	0.21174	0.71
08/04/2026 10:00	0.4	1.5	0	0.43	0.21336	0.71
08/04/2026 11:00	0.4	1.5	0	0.45	0.22482	0.75
08/04/2026 12:00	0.4	1.5	0	0.49	0.24312	0.81
08/04/2026 13:00	0.3	1.5	0	0.51	0.25446	0.85
08/04/2026 14:00	0.3	1.5	2	0.65	0.32430	1.08
08/04/2026 15:00	0.2	1.5	2	0.66	0.33174	1.11
08/04/2026 16:00	0.2	1.5	2	0.64	0.32040	1.07
08/04/2026 17:00	0.2	1.5	2	0.66	0.32772	1.09
08/04/2026 18:00	0.0	1.5	2	0.72	0.36018	1.20
08/04/2026 19:00	0.6	1.5	1	0.60	0.29898	1.00
08/04/2026 20:00	0.5	1.5	1	0.60	0.30192	1.01
08/04/2026 21:00	0.4	1.5	1	0.61	0.30486	1.02
08/04/2026 22:00	0.4	1.5	0	0.44	0.21822	0.73
08/04/2026 23:00	0.4	1.5	1	0.50	0.25176	0.84
Average/Sum#:	0.4	1.5	1	0.52	0.25771	0.86
Minimum:	0.0	1.5	0	0.42	0.21144	0.70
Maximum:	0.6	1.6	2	0.72	0.36018	1.20
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/05/2026 00:00	0.4	1.5	1	0.48	0.23790	0.79
08/05/2026 01:00	0.4	1.5	0	0.43	0.21312	0.71
08/05/2026 02:00	0.5	1.5	0	0.43	0.21306	0.71
08/05/2026 03:00	0.5	1.5	1	0.43	0.21306	0.71
08/05/2026 04:00	0.4	1.5	1	0.43	0.21636	0.72
08/05/2026 05:00	0.4	1.5	0	0.43	0.21330	0.71
08/05/2026 06:00	0.4	1.5	1	0.44	0.22194	0.74
08/05/2026 07:00	0.4	1.5	1	0.43	0.21378	0.71
08/05/2026 08:00	0.4	1.5	1	0.43	0.21318	0.71
08/05/2026 09:00	0.4	1.5	1	0.43	0.21318	0.71
08/05/2026 10:00	0.4	1.5	0	0.43	0.21306	0.71
08/05/2026 11:00	0.4	1.5	0	0.43	0.21366	0.71
08/05/2026 12:00	0.4	1.5	0	0.45	0.22320	0.74
08/05/2026 13:00	0.4	1.5	0	0.46	0.23166	0.77
08/05/2026 14:00	0.6	1.5	1	0.61	0.30276	1.01
08/05/2026 15:00	0.5	1.5	1	0.61	0.30522	1.02
08/05/2026 16:00	0.3	1.5	2	0.66	0.33198	1.11
08/05/2026 17:00	0.3	1.5	1	0.64	0.32058	1.07
08/05/2026 18:00	0.6	1.5	1	0.60	0.30186	1.01
08/05/2026 19:00	0.4	1.5	2	0.61	0.30570	1.02
08/05/2026 20:00	0.3	1.5	2	0.61	0.30732	1.02
08/05/2026 21:00	0.5	1.5	1	0.60	0.30210	1.01
08/05/2026 22:00	0.5	1.5	1	0.51	0.25728	0.86
08/05/2026 23:00	0.5	1.5	1	0.50	0.24816	0.83
Average/Sum#:	0.4	1.5	1	0.50	0.25139	0.84
Minimum:	0.3	1.5	0	0.43	0.21306	0.71
Maximum:	0.6	1.5	2	0.66	0.33198	1.11
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/06/2026 00:00	0.4	1.5	0	0.44	0.22032	0.73
08/06/2026 01:00	0.4	1.5	0	0.42	0.21192	0.71
08/06/2026 02:00	0.4	1.5	0	0.42	0.21198	0.71
08/06/2026 03:00	0.5	1.5	1	0.42	0.21234	0.71
08/06/2026 04:00	0.5	1.5	1	0.43	0.21474	0.72
08/06/2026 05:00	0.5	1.5	0	0.45	0.22470	0.75
08/06/2026 06:00	0.5	1.5	1	0.43	0.21294	0.71
08/06/2026 07:00	0.4	1.5	1	0.43	0.21324	0.71
08/06/2026 08:00	0.4	1.5	1	0.43	0.21264	0.71
08/06/2026 09:00	0.4	1.5	1	0.43	0.21252	0.71
08/06/2026 10:00	0.4	1.5	1	0.43	0.21264	0.71
08/06/2026 11:00	0.4	1.5	0	0.43	0.21288	0.71
08/06/2026 12:00	0.4	1.5	0	0.43	0.21288	0.71
08/06/2026 13:00	0.4	1.5	1	0.45	0.22518	0.75
08/06/2026 14:00	0.1	1.5	2	0.63	0.31464	1.05
08/06/2026 15:00	0.0	1.5	3	0.65	0.32268	1.08
08/06/2026 16:00	0.0	1.5	3	0.66	0.33192	1.11
08/06/2026 17:00	0.0	1.6	3	0.74	0.37200	1.24
08/06/2026 18:00	0.0	1.5	2	0.71	0.35688	1.19
08/06/2026 19:00	0.6	1.5	1	0.61	0.30390	1.01
08/06/2026 20:00	0.3	1.5	2	0.62	0.31086	1.04
08/06/2026 21:00	0.3	1.5	2	0.65	0.32334	1.08
08/06/2026 22:00	0.6	1.5	1	0.51	0.25704	0.86
08/06/2026 23:00	0.5	1.5	1	0.51	0.25698	0.86
Average/Sum#:	0.4	1.5	1	0.51	0.25672	0.86
Minimum:	0.0	1.5	0	0.42	0.21192	0.71
Maximum:	0.6	1.6	3	0.74	0.37200	1.24
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/07/2026 00:00	0.5	1.5	1	0.51	0.25686	0.86
08/07/2026 01:00	0.5	1.5	1	0.51	0.25686	0.86
08/07/2026 02:00	0.5	1.6	1	0.51	0.25674	0.86
08/07/2026 03:00	0.6	1.5	1	0.45	0.22614	0.75
08/07/2026 04:00	0.5	1.5	1	0.51	0.25494	0.85
08/07/2026 05:00	0.4	1.5	1	0.51	0.25650	0.86
08/07/2026 06:00	0.5	1.5	0	0.45	0.22500	0.75
08/07/2026 07:00	0.4	1.5	1	0.43	0.21354	0.71
08/07/2026 08:00	0.4	1.5	1	0.43	0.21306	0.71
08/07/2026 09:00	0.4	1.5	1	0.43	0.21288	0.71
08/07/2026 10:00	0.4	1.5	0	0.43	0.21282	0.71
08/07/2026 11:00	0.4	1.5	0	0.46	0.23064	0.77
08/07/2026 12:00	0.4	1.5	0	0.44	0.22116	0.74
08/07/2026 13:00	0.4	1.5	0	0.50	0.24846	0.83
08/07/2026 14:00	0.4	1.5	2	0.63	0.31548	1.05
08/07/2026 15:00	0.0	1.5	3	0.66	0.32766	1.09
08/07/2026 16:00	0.0	1.5	3	0.65	0.32730	1.09
08/07/2026 17:00	0.2	1.5	2	0.66	0.32982	1.10
08/07/2026 18:00	0.0	1.5	2	0.73	0.36468	1.22
08/07/2026 19:00	0.3	1.5	1	0.64	0.32040	1.07
08/07/2026 20:00	0.6	1.5	1	0.62	0.30882	1.03
08/07/2026 21:00	0.4	1.5	1	0.62	0.31200	1.04
08/07/2026 22:00	0.5	1.5	1	0.52	0.25914	0.86
08/07/2026 23:00	0.4	1.5	1	0.53	0.26424	0.88
Average/Sum#:	0.4	1.5	1	0.53	0.26730	0.89
Minimum:	0.0	1.5	0	0.43	0.21282	0.71
Maximum:	0.6	1.6	3	0.73	0.36468	1.22
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/08/2026 00:00	0.4	1.5	1	0.53	0.26406	0.88
08/08/2026 01:00	0.4	1.5	0	0.46	0.23160	0.77
08/08/2026 02:00	0.4	1.5	0	0.43	0.21330	0.71
08/08/2026 03:00	0.5	1.5	1	0.43	0.21492	0.72
08/08/2026 04:00	0.4	1.5	1	0.51	0.25464	0.85
08/08/2026 05:00	0.4	1.5	0	0.48	0.24102	0.80
08/08/2026 06:00	0.4	1.5	1	0.43	0.21420	0.71
08/08/2026 07:00	0.4	1.5	1	0.43	0.21426	0.71
08/08/2026 08:00	0.4	1.5	1	0.43	0.21522	0.72
08/08/2026 09:00	0.4	1.5	1	0.43	0.21522	0.72
08/08/2026 10:00	0.4	1.5	1	0.43	0.21480	0.72
08/08/2026 11:00	0.4	1.5	0	0.43	0.21480	0.72
08/08/2026 12:00	0.4	1.5	0	0.43	0.21474	0.72
08/08/2026 13:00	0.5	1.5	1	0.45	0.22674	0.76
08/08/2026 14:00	0.0	1.5	3	0.66	0.32910	1.10
08/08/2026 15:00	0.0	1.5	2	0.64	0.31878	1.06
08/08/2026 16:00	0.4	1.5	1	0.62	0.30786	1.03
08/08/2026 17:00	0.3	1.5	1	0.63	0.31446	1.05
08/08/2026 18:00	0.4	1.5	1	0.62	0.30960	1.03
08/08/2026 19:00	0.3	1.5	2	0.62	0.30930	1.03
08/08/2026 20:00	0.3	1.5	1	0.61	0.30744	1.02
08/08/2026 21:00	0.4	1.5	1	0.61	0.30432	1.01
08/08/2026 22:00	0.5	1.5	1	0.52	0.25812	0.86
08/08/2026 23:00	0.5	1.5	0	0.48	0.24210	0.81
Average/Sum#:	0.4	1.5	1	0.51	0.25628	0.85
Minimum:	0.0	1.5	0	0.43	0.21330	0.71
Maximum:	0.5	1.5	3	0.66	0.32910	1.10
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/09/2026 00:00	0.4	1.5	0	0.43	0.21276	0.71
08/09/2026 01:00	0.4	1.5	0	0.43	0.21276	0.71
08/09/2026 02:00	0.4	1.5	0	0.43	0.21300	0.71
08/09/2026 03:00	0.5	1.5	0	0.43	0.21300	0.71
08/09/2026 04:00	0.4	1.5	0	0.43	0.21534	0.72
08/09/2026 05:00	0.5	1.5	1	0.48	0.23940	0.80
08/09/2026 06:00	0.4	1.5	1	0.43	0.21390	0.71
08/09/2026 07:00	0.5	1.5	1	0.43	0.21414	0.71
08/09/2026 08:00	0.4	1.5	1	0.43	0.21366	0.71
08/09/2026 09:00	0.4	1.5	1	0.43	0.21330	0.71
08/09/2026 10:00	0.4	1.5	0	0.43	0.21324	0.71
08/09/2026 11:00	0.4	1.5	0	0.43	0.21354	0.71
08/09/2026 12:00	0.4	1.5	0	0.44	0.21936	0.73
08/09/2026 13:00	0.4	1.5	0	0.51	0.25260	0.84
08/09/2026 14:00	0.3	1.5	2	0.62	0.30906	1.03
08/09/2026 15:00	0.0	1.5	3	0.72	0.36216	1.21
08/09/2026 16:00	0.0	1.5	3	0.73	0.36696	1.22
08/09/2026 17:00	0.0	1.5	2	0.71	0.35652	1.19
08/09/2026 18:00	0.0	1.5	3	0.74	0.36858	1.23
08/09/2026 19:00	0.5	1.5	1	0.61	0.30546	1.02
08/09/2026 20:00	0.1	1.5	2	0.62	0.31122	1.04
08/09/2026 21:00	0.4	1.5	1	0.61	0.30516	1.02
08/09/2026 22:00	0.4	1.5	0	0.44	0.22044	0.73
08/09/2026 23:00	0.4	1.5	0	0.42	0.21216	0.71
Average/Sum#:	0.3	1.5	1	0.52	0.25741	0.86
Minimum:	0.0	1.5	0	0.42	0.21216	0.71
Maximum:	0.5	1.5	3	0.74	0.36858	1.23
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/10/2026 00:00	0.4	1.5	0	0.42	0.21240	0.71
08/10/2026 01:00	0.4	1.5	0	0.43	0.21252	0.71
08/10/2026 02:00	0.4	1.5	0	0.42	0.21246	0.71
08/10/2026 03:00	0.5	1.5	1	0.43	0.21276	0.71
08/10/2026 04:00	0.4	1.5	1	0.47	0.23586	0.79
08/10/2026 05:00	0.4	1.5	0	0.43	0.21312	0.71
08/10/2026 06:00	0.4	1.5	1	0.47	0.23352	0.78
08/10/2026 07:00	0.4	1.5	1	0.43	0.21402	0.71
08/10/2026 08:00	0.4	1.5	1	0.43	0.21342	0.71
08/10/2026 09:00	0.4	1.5	1	0.43	0.21330	0.71
08/10/2026 10:00	0.4	1.5	0	0.43	0.21330	0.71
08/10/2026 11:00	0.4	1.5	0	0.43	0.21372	0.71
08/10/2026 12:00	0.4	1.5	1	0.45	0.22500	0.75
08/10/2026 13:00	0.4	1.5	0	0.49	0.24498	0.82
08/10/2026 14:00	0.4	1.5	0	0.48	0.23862	0.80
08/10/2026 15:00	0.5	1.5	1	0.62	0.31008	1.03
08/10/2026 16:00	0.2	1.6	2	0.70	0.34974	1.17
08/10/2026 17:00	0.0	1.5	3	0.73	0.36738	1.22
08/10/2026 18:00	0.0	1.5	2	0.71	0.35562	1.19
08/10/2026 19:00	0.3	1.5	1	0.65	0.32574	1.09
08/10/2026 20:00	0.7	1.5	1	0.61	0.30660	1.02
08/10/2026 21:00	0.6	1.5	1	0.65	0.32262	1.08
08/10/2026 22:00	0.5	1.5	1	0.52	0.25872	0.86
08/10/2026 23:00	0.4	1.5	0	0.45	0.22566	0.75
Average/Sum#:	0.4	1.5	1	0.51	0.25547	0.85
Minimum:	0.0	1.5	0	0.42	0.21240	0.71
Maximum:	0.7	1.6	3	0.73	0.36738	1.22
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/11/2026 00:00	0.4	1.5	0	0.46	0.22932	0.76
08/11/2026 01:00	0.4	1.5	0	0.43	0.21366	0.71
08/11/2026 02:00	0.4	1.5	0	0.43	0.21354	0.71
08/11/2026 03:00	0.5	1.5	1	0.43	0.21366	0.71
08/11/2026 04:00	0.4	1.5	0	0.43	0.21588	0.72
08/11/2026 05:00	0.4	1.5	1	0.46	0.22914	0.76
08/11/2026 06:00	0.4	1.5	1	0.48	0.23856	0.80
08/11/2026 07:00	0.4	1.5	1	0.43	0.21462	0.72
08/11/2026 08:00	0.4	1.5	1	0.43	0.21408	0.71
08/11/2026 09:00	0.4	1.5	1	0.43	0.21408	0.71
08/11/2026 10:00	0.4	1.5	1	0.44	0.22002	0.73
08/11/2026 11:00	0.4	1.5	1	0.52	0.25800	0.86
08/11/2026 12:00	0.4	1.5	1	0.52	0.26010	0.87
08/11/2026 13:00	0.5	1.5	2	0.65	0.32310	1.08
08/11/2026 14:00	0.5	1.5	1	0.63	0.31476	1.05
08/11/2026 15:00	0.6	1.5	1	0.62	0.31182	1.04
08/11/2026 16:00	0.1	1.5	2	0.71	0.35442	1.18
08/11/2026 17:00	0.0	1.5	3	0.76	0.37860	1.26
08/11/2026 18:00	0.1	1.5	2	0.71	0.35520	1.18
08/11/2026 19:00	0.1	1.5	2	0.71	0.35322	1.18
08/11/2026 20:00	0.3	1.5	2	0.66	0.33246	1.11
08/11/2026 21:00	0.5	1.5	1	0.52	0.25860	0.86
08/11/2026 22:00	0.4	1.5	0	0.48	0.24222	0.81
08/11/2026 23:00	0.4	1.5	0	0.44	0.21780	0.73
Average/Sum#:	0.4	1.5	1	0.53	0.26570	0.89
Minimum:	0.0	1.5	0	0.43	0.21354	0.71
Maximum:	0.6	1.5	3	0.76	0.37860	1.26
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/12/2026 00:00	0.4	1.5	1	0.43	0.21306	0.71
08/12/2026 01:00	0.4	1.5	1	0.43	0.21312	0.71
08/12/2026 02:00	0.4	1.5	1	0.43	0.21330	0.71
08/12/2026 03:00	0.5	1.5	1	0.43	0.21330	0.71
08/12/2026 04:00	0.4	1.5	1	0.47	0.23358	0.78
08/12/2026 05:00	0.4	1.5	1	0.51	0.25260	0.84
08/12/2026 06:00	0.5	1.5	0	0.43	0.21306	0.71
08/12/2026 07:00	0.5	1.5	1	0.43	0.21354	0.71
08/12/2026 08:00	0.4	1.5	1	0.43	0.21372	0.71
08/12/2026 09:00	0.4	1.5	1	0.43	0.21354	0.71
08/12/2026 10:00	0.4	1.5	1	0.43	0.21348	0.71
08/12/2026 11:00	0.4	1.5	1	0.43	0.21402	0.71
08/12/2026 12:00	0.4	1.5	0	0.43	0.21588	0.72
08/12/2026 13:00	0.7	1.5	1	0.60	0.29994	1.00
08/12/2026 14:00	0.7	1.5	1	0.60	0.30102	1.00
08/12/2026 15:00	0.7	1.5	1	0.60	0.29970	1.00
08/12/2026 16:00	0.7	1.5	1	0.60	0.29958	1.00
08/12/2026 17:00	0.7	1.5	1	0.60	0.29862	1.00
08/12/2026 18:00	0.7	1.5	1	0.60	0.29766	0.99
08/12/2026 19:00	0.8	1.5	1	0.59	0.29556	0.99
08/12/2026 20:00	0.8	1.5	1	0.59	0.29604	0.99
08/12/2026 21:00	0.5	1.5	0	0.45	0.22266	0.74
08/12/2026 22:00	0.4	1.5	0	0.43	0.21264	0.71
08/12/2026 23:00	0.4	1.5	0	0.43	0.21264	0.71
Average/Sum#:	0.5	1.5	1	0.49	0.24468	0.82
Minimum:	0.4	1.5	0	0.43	0.21264	0.71
Maximum:	0.8	1.5	1	0.60	0.30102	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/13/2026 00:00	0.4	1.5	1	0.43	0.21282	0.71
08/13/2026 01:00	0.4	1.5	1	0.43	0.21294	0.71
08/13/2026 02:00	0.4	1.5	0	0.43	0.21336	0.71
08/13/2026 03:00	0.5	1.5	1	0.43	0.21354	0.71
08/13/2026 04:00	0.4	1.5	0	0.43	0.21360	0.71
08/13/2026 05:00	0.4	1.5	1	0.43	0.21372	0.71
08/13/2026 06:00	0.4	1.5	1	0.43	0.21402	0.71
08/13/2026 07:00	0.7	1.5	0	0.43	0.21426	0.71
08/13/2026 08:00	0.7	1.5	1	0.43	0.21360	0.71
08/13/2026 09:00	0.7	1.5	1	0.43	0.21336	0.71
08/13/2026 10:00	0.7	1.5	1	0.43	0.21336	0.71
08/13/2026 11:00	0.7	1.5	1	0.43	0.21396	0.71
08/13/2026 12:00	0.7	1.5	0	0.46	0.22818	0.76
08/13/2026 13:00	0.9	1.5	1	0.60	0.30228	1.01
08/13/2026 14:00	0.7	1.5	1	0.61	0.30324	1.01
08/13/2026 15:00	0.7	1.5	1	0.61	0.30312	1.01
08/13/2026 16:00	0.8	1.5	1	0.60	0.30102	1.00
08/13/2026 17:00	0.9	1.5	1	0.60	0.29958	1.00
08/13/2026 18:00	1.0	1.5	1	0.59	0.29736	0.99
08/13/2026 19:00	0.8	1.5	0	0.43	0.21576	0.72
08/13/2026 20:00	0.7	1.5	1	0.43	0.21306	0.71
08/13/2026 21:00	0.7	1.5	1	0.43	0.21306	0.71
08/13/2026 22:00	0.7	1.5	1	0.43	0.21318	0.71
08/13/2026 23:00	0.7	1.5	1	0.43	0.21318	0.71
Average/Sum#:	0.7	1.5	1	0.47	0.23607	0.79
Minimum:	0.4	1.5	0	0.43	0.21282	0.71
Maximum:	1.0	1.5	1	0.61	0.30324	1.01
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/14/2026 00:00	0.7	1.5	1	0.43	0.21318	0.71
08/14/2026 01:00	0.7	1.5	1	0.43	0.21324	0.71
08/14/2026 02:00	0.7	1.5	0	0.43	0.21330	0.71
08/14/2026 03:00	0.8	1.5	1	0.43	0.21336	0.71
08/14/2026 04:00	0.7	1.5	1	0.43	0.21342	0.71
08/14/2026 05:00	0.7	1.5	0	0.43	0.21528	0.72
08/14/2026 06:00	0.7	1.5	1	0.44	0.22224	0.74
08/14/2026 07:00	0.7	1.5	1	0.43	0.21366	0.71
08/14/2026 08:00	0.7	1.5	1	0.43	0.21384	0.71
08/14/2026 09:00	0.7	1.5	1	0.43	0.21354	0.71
08/14/2026 10:00	0.7	1.5	1	0.43	0.21360	0.71
08/14/2026 11:00	0.7	1.5	1	0.43	0.21432	0.71
08/14/2026 12:00	0.7	1.5	0	0.43	0.21450	0.72
08/14/2026 13:00	0.6	1.5	1	0.43	0.21462	0.72
08/14/2026 14:00	0.7	1.5	1	0.43	0.21468	0.72
08/14/2026 15:00	0.6	1.5	1	0.43	0.21426	0.71
08/14/2026 16:00	0.7	1.5	1	0.43	0.21372	0.71
08/14/2026 17:00	0.6	1.5	1	0.45	0.22404	0.75
08/14/2026 18:00	0.6	1.5	0	0.43	0.21492	0.72
08/14/2026 19:00	0.6	1.5	1	0.43	0.21342	0.71
08/14/2026 20:00	0.7	1.5	1	0.43	0.21378	0.71
08/14/2026 21:00	0.7	1.5	1	0.43	0.21372	0.71
08/14/2026 22:00	0.7	1.5	1	0.43	0.21396	0.71
08/14/2026 23:00	0.7	1.5	1	0.43	0.21402	0.71
Average/Sum#:	0.7	1.5	1	0.43	0.21469	0.72
Minimum:	0.6	1.5	0	0.43	0.21318	0.71
Maximum:	0.8	1.5	1	0.45	0.22404	0.75
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/15/2026 00:00	0.7	1.5	0	0.43	0.21426	0.71
08/15/2026 01:00	0.7	1.5	0	0.43	0.21426	0.71
08/15/2026 02:00	0.7	1.5	0	0.43	0.21426	0.71
08/15/2026 03:00	0.8	1.5	1	0.43	0.21366	0.71
08/15/2026 04:00	0.7	1.5	1	0.43	0.21324	0.71
08/15/2026 05:00	0.7	1.5	1	0.43	0.21300	0.71
08/15/2026 06:00	0.7	1.5	1	0.43	0.21300	0.71
08/15/2026 07:00	0.7	1.5	1	0.43	0.21306	0.71
08/15/2026 08:00	0.7	1.5	1	0.43	0.21294	0.71
08/15/2026 09:00	0.7	1.5	1	0.43	0.21318	0.71
08/15/2026 10:00	0.7	1.5	1	0.43	0.21342	0.71
08/15/2026 11:00	0.6	1.5	0	0.43	0.21408	0.71
08/15/2026 12:00	0.6	1.5	0	0.43	0.21426	0.71
08/15/2026 13:00	0.7	1.5	1	0.43	0.21450	0.72
08/15/2026 14:00	0.7	1.5	0	0.43	0.21468	0.72
08/15/2026 15:00	0.7	1.5	1	0.43	0.21426	0.71
08/15/2026 16:00	0.6	1.5	1	0.45	0.22542	0.75
08/15/2026 17:00	0.6	1.5	0	0.47	0.23442	0.78
08/15/2026 18:00	0.6	1.5	0	0.44	0.21876	0.73
08/15/2026 19:00	0.6	1.5	1	0.45	0.22566	0.75
08/15/2026 20:00	0.6	1.5	0	0.43	0.21348	0.71
08/15/2026 21:00	0.6	1.5	1	0.52	0.25824	0.86
08/15/2026 22:00	0.6	1.5	1	0.51	0.25332	0.84
08/15/2026 23:00	0.6	1.5	1	0.52	0.25890	0.86
Average/Sum#:	0.7	1.5	1	0.44	0.22118	0.74
Minimum:	0.6	1.5	0	0.43	0.21294	0.71
Maximum:	0.8	1.5	1	0.52	0.25890	0.86
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/16/2026 00:00	0.6	1.5	1	0.51	0.25692	0.86
08/16/2026 01:00	0.7	1.5	0	0.43	0.21270	0.71
08/16/2026 02:00	0.7	1.5	0	0.43	0.21300	0.71
08/16/2026 03:00	0.8	1.5	1	0.43	0.21306	0.71
08/16/2026 04:00	0.7	1.5	1	0.43	0.21324	0.71
08/16/2026 05:00	0.7	1.5	1	0.43	0.21360	0.71
08/16/2026 06:00	0.7	1.5	1	0.43	0.21378	0.71
08/16/2026 07:00	0.7	1.5	1	0.43	0.21408	0.71
08/16/2026 08:00	0.7	1.5	1	0.43	0.21354	0.71
08/16/2026 09:00	0.7	1.5	1	0.43	0.21330	0.71
08/16/2026 10:00	0.7	1.5	1	0.43	0.21330	0.71
08/16/2026 11:00	0.7	1.5	1	0.43	0.21378	0.71
08/16/2026 12:00	0.7	1.5	0	0.46	0.22872	0.76
08/16/2026 13:00	0.9	1.5	1	0.60	0.29994	1.00
08/16/2026 14:00	0.9	1.5	1	0.60	0.30012	1.00
08/16/2026 15:00	0.9	1.5	1	0.60	0.29946	1.00
08/16/2026 16:00	0.8	1.5	1	0.61	0.30432	1.01
08/16/2026 17:00	0.7	1.5	1	0.63	0.31590	1.05
08/16/2026 18:00	0.8	1.5	1	0.60	0.30246	1.01
08/16/2026 19:00	1.0	1.5	1	0.59	0.29688	0.99
08/16/2026 20:00	0.7	1.5	1	0.60	0.30084	1.00
08/16/2026 21:00	0.7	1.5	1	0.52	0.25794	0.86
08/16/2026 22:00	0.6	1.5	1	0.50	0.25134	0.84
08/16/2026 23:00	0.7	1.5	0	0.42	0.21132	0.70
Average/Sum#:	0.7	1.5	1	0.50	0.24890	0.83
Minimum:	0.6	1.5	0	0.42	0.21132	0.70
Maximum:	1.0	1.5	1	0.63	0.31590	1.05
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/17/2026 00:00	0.7	1.5	0	0.42	0.21156	0.71
08/17/2026 01:00	0.7	1.5	0	0.42	0.21186	0.71
08/17/2026 02:00	0.7	1.5	0	0.42	0.21174	0.71
08/17/2026 03:00	0.8	1.5	0	0.42	0.21162	0.71
08/17/2026 04:00	0.7	1.5	1	0.43	0.21390	0.71
08/17/2026 05:00	0.8	1.5	1	0.42	0.21228	0.71
08/17/2026 06:00	0.7	1.5	1	0.42	0.21228	0.71
08/17/2026 07:00	0.7	1.5	1	0.42	0.21234	0.71
08/17/2026 08:00	0.7	1.5	1	0.42	0.21246	0.71
08/17/2026 09:00	0.7	1.5	1	0.42	0.21246	0.71
08/17/2026 10:00	0.7	1.5	1	0.42	0.21246	0.71
08/17/2026 11:00	0.7	1.5	1	0.43	0.21252	0.71
08/17/2026 12:00	0.6	1.5	0	0.45	0.22704	0.76
08/17/2026 13:00	1.0	1.5	1	0.60	0.29814	0.99
08/17/2026 14:00	0.5	1.5	2	0.67	0.33342	1.11
08/17/2026 15:00	0.4	1.5	2	0.68	0.33786	1.13
08/17/2026 16:00	0.6	1.5	2	0.64	0.32142	1.07
08/17/2026 17:00	0.3	1.5	2	0.72	0.35838	1.19
08/17/2026 18:00	0.4	1.5	2	0.67	0.33708	1.12
08/17/2026 19:00	0.7	1.5	2	0.63	0.31674	1.06
08/17/2026 20:00	0.7	1.5	2	0.60	0.30246	1.01
08/17/2026 21:00	0.7	1.5	1	0.47	0.23256	0.78
08/17/2026 22:00	0.7	1.5	0	0.45	0.22278	0.74
08/17/2026 23:00	0.7	1.5	0	0.42	0.21144	0.70
Average/Sum#:	0.7	1.5	1	0.50	0.25195	0.84
Minimum:	0.3	1.5	0	0.42	0.21144	0.70
Maximum:	1.0	1.5	2	0.72	0.35838	1.19
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/18/2026 00:00	0.7	1.5	0	0.42	0.21174	0.71
08/18/2026 01:00	0.7	1.5	1	0.42	0.21180	0.71
08/18/2026 02:00	0.7	1.5	1	0.42	0.21198	0.71
08/18/2026 03:00	0.8	1.5	1	0.42	0.21210	0.71
08/18/2026 04:00	0.7	1.5	1	0.42	0.21246	0.71
08/18/2026 05:00	0.7	1.5	1	0.42	0.21240	0.71
08/18/2026 06:00	0.7	1.5	1	0.43	0.21300	0.71
08/18/2026 07:00	0.7	1.5	1	0.43	0.21306	0.71
08/18/2026 08:00	0.7	1.5	1	0.42	0.21240	0.71
08/18/2026 09:00	0.7	1.5	1	0.42	0.21234	0.71
08/18/2026 10:00	0.7	1.5	1	0.42	0.21240	0.71
08/18/2026 11:00	0.7	1.5	0	0.43	0.21258	0.71
08/18/2026 12:00	0.8	1.5	1	0.45	0.22542	0.75
08/18/2026 13:00	0.4	1.5	2	0.63	0.31674	1.06
08/18/2026 14:00	0.2	1.5	2	0.65	0.32730	1.09
08/18/2026 15:00	0.2	1.5	2	0.64	0.32232	1.07
08/18/2026 16:00	0.2	1.5	3	0.68	0.33786	1.13
08/18/2026 17:00	0.2	1.5	3	0.75	0.37668	1.26
08/18/2026 18:00	0.2	1.5	2	0.72	0.36036	1.20
08/18/2026 19:00	0.6	1.5	2	0.64	0.32100	1.07
08/18/2026 20:00	1.1	1.5	1	0.59	0.29442	0.98
08/18/2026 21:00	0.8	1.5	0	0.48	0.23850	0.80
08/18/2026 22:00	0.7	1.5	0	0.45	0.22284	0.74
08/18/2026 23:00	0.7	1.5	0	0.43	0.21516	0.72
Average/Sum#:	0.6	1.5	1	0.51	0.25445	0.85
Minimum:	0.2	1.5	0	0.42	0.21174	0.71
Maximum:	1.1	1.5	3	0.75	0.37668	1.26
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/19/2026 00:00	0.7	1.5	0	0.42	0.21150	0.71
08/19/2026 01:00	0.7	1.5	0	0.42	0.21168	0.71
08/19/2026 02:00	0.7	1.5	1	0.42	0.21192	0.71
08/19/2026 03:00	0.8	1.5	1	0.42	0.21222	0.71
08/19/2026 04:00	0.7	1.5	1	0.42	0.21216	0.71
08/19/2026 05:00	0.7	1.5	1	0.42	0.21216	0.71
08/19/2026 06:00	0.8	1.5	1	0.43	0.21258	0.71
08/19/2026 07:00	0.7	1.5	1	0.43	0.21294	0.71
08/19/2026 08:00	0.7	1.5	1	0.43	0.21252	0.71
08/19/2026 09:00	0.7	1.5	1	0.42	0.21234	0.71
08/19/2026 10:00	0.7	1.5	1	0.43	0.21252	0.71
08/19/2026 11:00	0.6	1.5	0	0.43	0.21276	0.71
08/19/2026 12:00	0.8	1.5	1	0.45	0.22374	0.75
08/19/2026 13:00	0.2	1.5	3	0.65	0.32550	1.09
08/19/2026 14:00	0.1	1.5	3	0.68	0.33858	1.13
08/19/2026 15:00	0.3	1.5	3	0.65	0.32454	1.08
08/19/2026 16:00	0.1	1.5	3	0.67	0.33330	1.11
08/19/2026 17:00	0.2	1.5	3	0.74	0.37086	1.24
08/19/2026 18:00	0.2	1.5	3	0.74	0.37158	1.24
08/19/2026 19:00	0.3	1.5	2	0.72	0.36006	1.20
08/19/2026 20:00	0.5	1.5	2	0.67	0.33354	1.11
08/19/2026 21:00	0.8	1.5	1	0.51	0.25392	0.85
08/19/2026 22:00	0.7	1.5	1	0.52	0.25776	0.86
08/19/2026 23:00	0.7	1.5	1	0.52	0.25758	0.86
Average/Sum#:	0.6	1.5	1	0.53	0.26243	0.88
Minimum:	0.1	1.5	0	0.42	0.21150	0.71
Maximum:	0.8	1.5	3	0.74	0.37158	1.24
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/20/2026 00:00	0.7	1.5	1	0.47	0.23640	0.79
08/20/2026 01:00	0.7	1.5	0	0.43	0.21324	0.71
08/20/2026 02:00	0.7	1.5	0	0.43	0.21300	0.71
08/20/2026 03:00	0.8	1.5	1	0.43	0.21252	0.71
08/20/2026 04:00	0.8	1.5	1	0.43	0.21258	0.71
08/20/2026 05:00	0.8	1.5	1	0.43	0.21300	0.71
08/20/2026 06:00	0.8	1.5	1	0.43	0.21486	0.72
08/20/2026 07:00	0.7	1.5	1	0.43	0.21372	0.71
08/20/2026 08:00	0.7	1.5	1	0.43	0.21336	0.71
08/20/2026 09:00	0.7	1.5	1	0.43	0.21312	0.71
08/20/2026 10:00	0.7	1.5	1	0.43	0.21324	0.71
08/20/2026 11:00	0.7	1.5	1	0.43	0.21522	0.72
08/20/2026 12:00	0.8	1.5	0	0.46	0.22920	0.76
08/20/2026 13:00	0.4	1.5	2	0.63	0.31548	1.05
08/20/2026 14:00	0.3	1.5	2	0.64	0.32034	1.07
08/20/2026 15:00	0.2	1.5	2	0.64	0.32088	1.07
08/20/2026 16:00	0.2	1.5	3	0.66	0.32988	1.10
08/20/2026 17:00	0.2	1.5	3	0.75	0.37692	1.26
08/20/2026 18:00	0.2	1.5	3	0.73	0.36408	1.21
08/20/2026 19:00	0.2	1.5	2	0.73	0.36420	1.21
08/20/2026 20:00	0.5	1.5	2	0.67	0.33642	1.12
08/20/2026 21:00	0.7	1.5	1	0.51	0.25734	0.86
08/20/2026 22:00	0.7	1.5	1	0.52	0.25770	0.86
08/20/2026 23:00	0.7	1.5	1	0.52	0.25770	0.86
Average/Sum#:	0.6	1.5	1	0.53	0.26310	0.88
Minimum:	0.2	1.5	0	0.43	0.21252	0.71
Maximum:	0.8	1.5	3	0.75	0.37692	1.26
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/21/2026 00:00	0.7	1.5	1	0.52	0.25770	0.86
08/21/2026 01:00	0.7	1.5	0	0.44	0.22200	0.74
08/21/2026 02:00	0.7	1.5	0	0.47	0.23358	0.78
08/21/2026 03:00	0.8	1.5	1	0.43	0.21732	0.72
08/21/2026 04:00	0.8	1.5	0	0.43	0.21636	0.72
08/21/2026 05:00	0.7	1.5	1	0.52	0.25890	0.86
08/21/2026 06:00	0.8	1.5	1	0.46	0.22986	0.77
08/21/2026 07:00	0.7	1.5	1	0.43	0.21384	0.71
08/21/2026 08:00	0.7	1.5	1	0.43	0.21378	0.71
08/21/2026 09:00	0.7	1.5	1	0.43	0.21378	0.71
08/21/2026 10:00	0.7	1.5	1	0.43	0.21366	0.71
08/21/2026 11:00	0.7	1.5	1	0.43	0.21390	0.71
08/21/2026 12:00	0.7	1.5	0	0.46	0.22902	0.76
08/21/2026 13:00	0.6	1.5	2	0.62	0.31086	1.04
08/21/2026 14:00	0.2	1.5	2	0.64	0.31806	1.06
08/21/2026 15:00	0.2	1.5	2	0.64	0.31776	1.06
08/21/2026 16:00	0.2	1.5	3	0.65	0.32562	1.09
08/21/2026 17:00	0.1	1.5	3	0.70	0.34806	1.16
08/21/2026 18:00	0.7	1.5	1	0.60	0.29868	1.00
08/21/2026 19:00	1.0	1.5	1	0.59	0.29496	0.98
08/21/2026 20:00	1.1	1.5	1	0.59	0.29610	0.99
08/21/2026 21:00	0.8	1.5	0	0.43	0.21594	0.72
08/21/2026 22:00	0.8	1.5	1	0.43	0.21294	0.71
08/21/2026 23:00	0.7	1.5	1	0.48	0.24222	0.81
Average/Sum#:	0.7	1.5	1	0.51	0.25479	0.85
Minimum:	0.1	1.5	0	0.43	0.21294	0.71
Maximum:	1.1	1.5	3	0.70	0.34806	1.16
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/22/2026 00:00	0.7	1.5	1	0.48	0.23832	0.79
08/22/2026 01:00	0.7	1.5	1	0.47	0.23292	0.78
08/22/2026 02:00	0.8	1.5	0	0.43	0.21276	0.71
08/22/2026 03:00	0.8	1.5	1	0.43	0.21294	0.71
08/22/2026 04:00	0.7	1.5	1	0.46	0.23058	0.77
08/22/2026 05:00	0.8	1.5	0	0.43	0.21408	0.71
08/22/2026 06:00	0.8	1.5	1	0.43	0.21372	0.71
08/22/2026 07:00	0.8	1.5	1	0.43	0.21402	0.71
08/22/2026 08:00	0.7	1.5	1	0.43	0.21348	0.71
08/22/2026 09:00	0.7	1.5	1	0.43	0.21342	0.71
08/22/2026 10:00	0.7	1.5	1	0.43	0.21342	0.71
08/22/2026 11:00	0.7	1.5	1	0.43	0.21360	0.71
08/22/2026 12:00	0.6	1.5	1	0.46	0.22824	0.76
08/22/2026 13:00	1.0	1.5	1	0.60	0.29796	0.99
08/22/2026 14:00	1.0	1.5	1	0.60	0.29898	1.00
08/22/2026 15:00	1.0	1.5	1	0.60	0.29850	1.00
08/22/2026 16:00	0.9	1.5	1	0.60	0.29952	1.00
08/22/2026 17:00	0.3	1.5	2	0.63	0.31482	1.05
08/22/2026 18:00	0.3	1.5	2	0.63	0.31338	1.04
08/22/2026 19:00	0.5	1.5	2	0.62	0.30780	1.03
08/22/2026 20:00	0.7	1.5	1	0.61	0.30312	1.01
08/22/2026 21:00	0.8	1.5	0	0.44	0.21918	0.73
08/22/2026 22:00	0.7	1.5	0	0.42	0.21234	0.71
08/22/2026 23:00	0.7	1.5	0	0.43	0.21264	0.71
Average/Sum#:	0.7	1.5	1	0.50	0.24707	0.82
Minimum:	0.3	1.5	0	0.42	0.21234	0.71
Maximum:	1.0	1.5	2	0.63	0.31482	1.05
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/23/2026 00:00	0.7	1.5	0	0.46	0.22938	0.76
08/23/2026 01:00	0.7	1.5	0	0.43	0.21336	0.71
08/23/2026 02:00	0.8	1.5	0	0.43	0.21264	0.71
08/23/2026 03:00	0.8	1.5	1	0.43	0.21282	0.71
08/23/2026 04:00	0.8	1.5	1	0.43	0.21318	0.71
08/23/2026 05:00	0.9	1.5	1	0.43	0.21330	0.71
08/23/2026 06:00	1.0	1.5	1	0.43	0.21324	0.71
08/23/2026 07:00	1.0	1.5	1	0.43	0.21342	0.71
08/23/2026 08:00	0.8	1.5	1	0.43	0.21318	0.71
08/23/2026 09:00	0.7	1.5	1	0.43	0.21300	0.71
08/23/2026 10:00	0.7	1.5	1	0.43	0.21288	0.71
08/23/2026 11:00	0.7	1.5	1	0.43	0.21324	0.71
08/23/2026 12:00	0.7	1.5	0	0.46	0.22836	0.76
08/23/2026 13:00	0.9	1.5	1	0.60	0.29958	1.00
08/23/2026 14:00	0.2	1.5	3	0.64	0.31896	1.06
08/23/2026 15:00	0.2	1.5	2	0.67	0.33366	1.11
08/23/2026 16:00	0.5	1.5	2	0.69	0.34284	1.14
08/23/2026 17:00	0.2	1.5	3	0.74	0.37176	1.24
08/23/2026 18:00	0.2	1.5	3	0.73	0.36720	1.22
08/23/2026 19:00	0.4	1.5	2	0.69	0.34710	1.16
08/23/2026 20:00	0.6	1.5	2	0.67	0.33360	1.11
08/23/2026 21:00	0.7	1.5	1	0.52	0.25926	0.86
08/23/2026 22:00	0.7	1.5	1	0.52	0.25896	0.86
08/23/2026 23:00	0.7	1.5	1	0.52	0.25920	0.86
Average/Sum#:	0.7	1.5	1	0.53	0.26226	0.87
Minimum:	0.2	1.5	0	0.43	0.21264	0.71
Maximum:	1.0	1.5	3	0.74	0.37176	1.24
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/24/2026 00:00	0.7	1.5	1	0.52	0.25884	0.86
08/24/2026 01:00	0.7	1.5	1	0.52	0.25800	0.86
08/24/2026 02:00	0.7	1.5	1	0.52	0.25848	0.86
08/24/2026 03:00	0.8	1.5	1	0.51	0.25320	0.84
08/24/2026 04:00	0.7	1.5	1	0.51	0.25608	0.85
08/24/2026 05:00	0.7	1.5	0	0.43	0.21528	0.72
08/24/2026 06:00	0.7	1.5	1	0.47	0.23346	0.78
08/24/2026 07:00	0.8	1.5	1	0.44	0.22230	0.74
08/24/2026 08:00	0.7	1.5	1	0.43	0.21312	0.71
08/24/2026 09:00	0.7	1.5	1	0.43	0.21300	0.71
08/24/2026 10:00	0.7	1.5	1	0.43	0.21282	0.71
08/24/2026 11:00	0.6	1.5	1	0.43	0.21330	0.71
08/24/2026 12:00	0.6	1.5	1	0.46	0.22956	0.77
08/24/2026 13:00	0.4	1.5	2	0.64	0.31974	1.07
08/24/2026 14:00	0.2	1.5	3	0.71	0.35610	1.19
08/24/2026 15:00	0.2	1.5	3	0.75	0.37296	1.24
08/24/2026 16:00	0.3	1.5	2	0.71	0.35682	1.19
08/24/2026 17:00	0.2	1.5	3	0.75	0.37278	1.24
08/24/2026 18:00	0.2	1.5	3	0.75	0.37470	1.25
08/24/2026 19:00	0.2	1.5	3	0.75	0.37284	1.24
08/24/2026 20:00	0.6	1.5	2	0.66	0.32898	1.10
08/24/2026 21:00	0.7	1.5	1	0.52	0.25836	0.86
08/24/2026 22:00	0.7	1.5	1	0.52	0.25836	0.86
08/24/2026 23:00	0.7	1.5	1	0.50	0.25032	0.83
Average/Sum#:	0.6	1.5	2	0.56	0.27748	0.92
Minimum:	0.2	1.5	0	0.43	0.21282	0.71
Maximum:	0.8	1.5	3	0.75	0.37470	1.25
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/25/2026 00:00	0.7	1.5	1	0.48	0.23802	0.79
08/25/2026 01:00	0.7	1.5	0	0.43	0.21618	0.72
08/25/2026 02:00	0.7	1.5	0	0.43	0.21396	0.71
08/25/2026 03:00	0.8	1.5	1	0.43	0.21420	0.71
08/25/2026 04:00	0.7	1.5	1	0.47	0.23622	0.79
08/25/2026 05:00	0.7	1.5	1	0.45	0.22500	0.75
08/25/2026 06:00	0.8	1.5	0	0.46	0.22776	0.76
08/25/2026 07:00	0.8	1.5	1	0.43	0.21438	0.71
08/25/2026 08:00	0.7	1.5	1	0.43	0.21408	0.71
08/25/2026 09:00	0.7	1.5	1	0.43	0.21372	0.71
08/25/2026 10:00	0.7	1.5	1	0.43	0.21360	0.71
08/25/2026 11:00	0.6	1.5	1	0.47	0.23604	0.79
08/25/2026 12:00	0.6	1.5	1	0.50	0.25218	0.84
08/25/2026 13:00	0.6	1.5	1	0.52	0.25962	0.87
08/25/2026 14:00	0.8	1.5	1	0.63	0.31710	1.06
08/25/2026 15:00	0.8	1.5	1	0.61	0.30510	1.02
08/25/2026 16:00	0.4	1.5	2	0.68	0.34104	1.14
08/25/2026 17:00	0.2	1.5	3	0.76	0.37890	1.26
08/25/2026 18:00	0.2	1.5	3	0.76	0.37818	1.26
08/25/2026 19:00	0.3	1.5	2	0.72	0.35772	1.19
08/25/2026 20:00	0.6	1.5	2	0.64	0.32136	1.07
08/25/2026 21:00	0.6	1.5	2	0.63	0.31344	1.04
08/25/2026 22:00	0.8	1.5	0	0.46	0.23088	0.77
08/25/2026 23:00	0.7	1.5	0	0.43	0.21318	0.71
Average/Sum#:	0.6	1.5	1	0.53	0.26383	0.88
Minimum:	0.2	1.5	0	0.43	0.21318	0.71
Maximum:	0.8	1.5	3	0.76	0.37890	1.26
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/26/2026 00:00	0.7	1.5	0	0.43	0.21690	0.72
08/26/2026 01:00	0.7	1.5	0	0.43	0.21312	0.71
08/26/2026 02:00	0.7	1.5	1	0.46	0.22794	0.76
08/26/2026 03:00	0.8	1.5	1	0.43	0.21354	0.71
08/26/2026 04:00	0.7	1.5	1	0.48	0.23910	0.80
08/26/2026 05:00	0.7	1.5	1	0.52	0.25848	0.86
08/26/2026 06:00	0.7	1.5	1	0.47	0.23352	0.78
08/26/2026 07:00	0.7	1.5	1	0.43	0.21414	0.71
08/26/2026 08:00	0.7	1.5	1	0.43	0.21366	0.71
08/26/2026 09:00	0.7	1.5	1	0.43	0.21342	0.71
08/26/2026 10:00	0.7	1.5	1	0.43	0.21336	0.71
08/26/2026 11:00	0.6	1.5	1	0.52	0.25830	0.86
08/26/2026 12:00	0.6	1.5	1	0.51	0.25650	0.86
08/26/2026 13:00	0.8	1.5	2	0.62	0.31104	1.04
08/26/2026 14:00	0.2	1.5	2	0.63	0.31722	1.06
08/26/2026 15:00	0.1	1.5	3	0.64	0.31938	1.06
08/26/2026 16:00	0.1	1.5	3	0.64	0.32010	1.07
08/26/2026 17:00	0.3	1.5	2	0.69	0.34386	1.15
08/26/2026 18:00	0.5	1.5	2	0.64	0.31956	1.07
08/26/2026 19:00	0.3	1.5	2	0.66	0.32790	1.09
08/26/2026 20:00	0.5	1.5	2	0.65	0.32262	1.08
08/26/2026 21:00	0.7	1.5	1	0.51	0.25734	0.86
08/26/2026 22:00	0.8	1.5	0	0.43	0.21732	0.72
08/26/2026 23:00	0.7	1.5	0	0.48	0.24012	0.80
Average/Sum#:	0.6	1.5	1	0.52	0.26119	0.87
Minimum:	0.1	1.5	0	0.43	0.21312	0.71
Maximum:	0.8	1.5	3	0.69	0.34386	1.15
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/27/2026 00:00	0.8	1.5	0	0.45	0.22632	0.75
08/27/2026 01:00	0.8	1.5	0	0.43	0.21306	0.71
08/27/2026 02:00	0.7	1.5	0	0.43	0.21300	0.71
08/27/2026 03:00	0.8	1.5	1	0.43	0.21306	0.71
08/27/2026 04:00	0.8	1.5	0	0.43	0.21354	0.71
08/27/2026 05:00	0.8	1.5	1	0.47	0.23376	0.78
08/27/2026 06:00	0.7	1.5	1	0.48	0.24024	0.80
08/27/2026 07:00	0.7	1.5	1	0.52	0.26010	0.87
08/27/2026 08:00	0.6	1.5	1	0.52	0.25944	0.86
08/27/2026 09:00	0.6	1.5	1	0.52	0.25902	0.86
08/27/2026 10:00	0.6	1.5	1	0.52	0.25980	0.87
08/27/2026 11:00	0.6	1.5	1	0.52	0.26022	0.87
08/27/2026 12:00	0.6	1.5	1	0.52	0.25950	0.87
08/27/2026 13:00	0.5	1.6	2	0.71	0.35358	1.18
08/27/2026 14:00	0.2	1.5	3	0.74	0.36828	1.23
08/27/2026 15:00	0.7	1.5	1	0.62	0.31146	1.04
08/27/2026 16:00	0.6	1.5	1	0.64	0.31764	1.06
08/27/2026 17:00	0.9	1.5	1	0.60	0.29982	1.00
08/27/2026 18:00	0.5	1.5	2	0.62	0.30918	1.03
08/27/2026 19:00	0.5	1.5	2	0.62	0.30942	1.03
08/27/2026 20:00	0.4	1.5	2	0.65	0.32604	1.09
08/27/2026 21:00	0.7	1.5	1	0.51	0.25728	0.86
08/27/2026 22:00	0.7	1.5	1	0.52	0.25932	0.86
08/27/2026 23:00	0.5	1.5	2	0.67	0.33498	1.12
Average/Sum#:	0.6	1.5	1	0.55	0.27325	0.91
Minimum:	0.2	1.5	0	0.43	0.21300	0.71
Maximum:	0.9	1.6	3	0.74	0.36828	1.23
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/28/2026 00:00	0.7	1.5	2	0.62	0.31212	1.04
08/28/2026 01:00	0.8	1.5	1	0.61	0.30672	1.02
08/28/2026 02:00	1.0	1.5	1	0.60	0.29892	1.00
08/28/2026 03:00	1.0	1.5	2	0.61	0.30558	1.02
08/28/2026 04:00	0.6	1.5	2	0.66	0.32976	1.10
08/28/2026 05:00	0.3	1.5	3	0.74	0.37056	1.24
08/28/2026 06:00	0.3	1.5	3	0.72	0.35994	1.20
08/28/2026 07:00	0.3	1.5	3	0.74	0.37068	1.24
08/28/2026 08:00	0.8	1.5	1	0.63	0.31674	1.06
08/28/2026 09:00	1.0	1.5	1	0.60	0.30078	1.00
08/28/2026 10:00	0.8	1.5	1	0.62	0.30852	1.03
08/28/2026 11:00	0.6	1.5	2	0.63	0.31350	1.05
08/28/2026 12:00	0.6	1.5	2	0.62	0.31098	1.04
08/28/2026 13:00	0.6	1.5	2	0.61	0.30606	1.02
08/28/2026 14:00	0.5	1.5	2	0.62	0.30786	1.03
08/28/2026 15:00	0.5	1.5	2	0.62	0.30810	1.03
08/28/2026 16:00	0.6	1.5	2	0.61	0.30624	1.02
08/28/2026 17:00	0.7	1.5	1	0.61	0.30384	1.01
08/28/2026 18:00	0.7	1.5	1	0.61	0.30450	1.02
08/28/2026 19:00	0.9	1.5	1	0.60	0.29988	1.00
08/28/2026 20:00	0.9	1.5	1	0.60	0.29850	1.00
08/28/2026 21:00	1.0	1.5	1	0.59	0.29646	0.99
08/28/2026 22:00	1.1	1.5	1	0.59	0.29550	0.99
08/28/2026 23:00	1.2	1.5	1	0.59	0.29508	0.98
Average/Sum#:	0.7	1.5	2	0.63	0.31362	1.05
Minimum:	0.3	1.5	1	0.59	0.29508	0.98
Maximum:	1.2	1.5	3	0.74	0.37068	1.24
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/29/2026 00:00	1.2	1.5	1	0.59	0.29430	0.98
08/29/2026 01:00	1.1	1.5	1	0.59	0.29448	0.98
08/29/2026 02:00	1.1	1.5	1	0.59	0.29382	0.98
08/29/2026 03:00	1.3	1.5	1	0.59	0.29328	0.98
08/29/2026 04:00	1.3	1.5	1	0.59	0.29256	0.98
08/29/2026 05:00	1.4	1.5	1	0.58	0.29166	0.97
08/29/2026 06:00	1.4	1.5	1	0.59	0.29274	0.98
08/29/2026 07:00	1.2	1.5	1	0.59	0.29466	0.98
08/29/2026 08:00	1.1	1.5	1	0.59	0.29544	0.98
08/29/2026 09:00	1.0	1.5	1	0.59	0.29742	0.99
08/29/2026 10:00	0.9	1.5	1	0.60	0.30042	1.00
08/29/2026 11:00	0.7	1.5	1	0.61	0.30360	1.01
08/29/2026 12:00	0.6	1.5	2	0.61	0.30726	1.02
08/29/2026 13:00	0.5	1.5	2	0.62	0.30996	1.03
08/29/2026 14:00	0.4	1.5	2	0.62	0.31182	1.04
08/29/2026 15:00	0.7	1.5	1	0.61	0.30252	1.01
08/29/2026 16:00	1.0	1.5	1	0.59	0.29688	0.99
08/29/2026 17:00	0.8	1.5	1	0.62	0.31170	1.04
08/29/2026 18:00	0.8	1.5	1	0.60	0.29916	1.00
08/29/2026 19:00	0.8	1.5	1	0.60	0.29928	1.00
08/29/2026 20:00	0.9	1.5	1	0.60	0.29850	1.00
08/29/2026 21:00	1.1	1.5	1	0.59	0.29706	0.99
08/29/2026 22:00	1.2	1.5	1	0.59	0.29604	0.99
08/29/2026 23:00	1.2	1.5	1	0.59	0.29502	0.98
Average/Sum#:	1.0	1.5	1	0.60	0.29873	1.00
Minimum:	0.4	1.5	1	0.58	0.29166	0.97
Maximum:	1.4	1.5	2	0.62	0.31182	1.04
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/30/2026 00:00	1.1	1.5	1	0.59	0.29388	0.98
08/30/2026 01:00	1.2	1.5	1	0.59	0.29286	0.98
08/30/2026 02:00	1.3	1.5	1	0.59	0.29382	0.98
08/30/2026 03:00	1.5	1.5	1	0.59	0.29298	0.98
08/30/2026 04:00	1.5	1.5	1	0.59	0.29250	0.98
08/30/2026 05:00	1.5	1.5	1	0.58	0.29202	0.97
08/30/2026 06:00	1.4	1.5	1	0.59	0.29328	0.98
08/30/2026 07:00	1.3	1.5	1	0.59	0.29520	0.98
08/30/2026 08:00	1.1	1.5	1	0.59	0.29676	0.99
08/30/2026 09:00	1.1	1.5	1	0.60	0.29886	1.00
08/30/2026 10:00	0.9	1.5	1	0.60	0.30186	1.01
08/30/2026 11:00	0.8	1.5	1	0.61	0.30486	1.02
08/30/2026 12:00	0.6	1.5	1	0.62	0.30810	1.03
08/30/2026 13:00	0.5	1.5	2	0.62	0.30966	1.03
08/30/2026 14:00	0.5	1.5	2	0.62	0.31002	1.03
08/30/2026 15:00	0.5	1.5	2	0.62	0.31146	1.04
08/30/2026 16:00	0.4	1.5	2	0.63	0.31668	1.06
08/30/2026 17:00	0.3	1.5	2	0.66	0.33078	1.10
08/30/2026 18:00	0.5	1.5	2	0.61	0.30714	1.02
08/30/2026 19:00	0.8	1.5	1	0.60	0.30084	1.00
08/30/2026 20:00	0.9	1.5	1	0.60	0.29898	1.00
08/30/2026 21:00	1.1	1.5	1	0.60	0.29772	0.99
08/30/2026 22:00	1.1	1.5	1	0.59	0.29622	0.99
08/30/2026 23:00	1.3	1.5	1	0.59	0.29580	0.99
Average/Sum#:	1.0	1.5	1	0.60	0.30135	1.01
Minimum:	0.3	1.5	1	0.58	0.29202	0.97
Maximum:	1.5	1.5	2	0.66	0.33078	1.10
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
08/31/2026 00:00	1.3	1.5	1	0.59	0.29466	0.98
08/31/2026 01:00	1.3	1.5	1	0.59	0.29352	0.98
08/31/2026 02:00	1.6	1.5	1	0.59	0.29316	0.98
08/31/2026 03:00	1.9	1.5	1	0.59	0.29316	0.98
08/31/2026 04:00	1.8	1.5	1	0.58	0.29238	0.97
08/31/2026 05:00	1.3	1.5	1	0.52	0.26076	0.87
08/31/2026 06:00	0.8	1.5	0	0.43	0.21468	0.72
08/31/2026 07:00	0.8	1.5	1	0.43	0.21468	0.72
08/31/2026 08:00	0.8	1.5	1	0.43	0.21426	0.71
08/31/2026 09:00	0.7	1.5	1	0.43	0.21414	0.71
08/31/2026 10:00	0.7	1.5	1	0.43	0.21408	0.71
08/31/2026 11:00	0.7	1.5	1	0.43	0.21432	0.71
08/31/2026 12:00	0.7	1.5	1	0.46	0.22920	0.76
08/31/2026 13:00	1.0	1.5	1	0.60	0.30228	1.01
08/31/2026 14:00	0.9	1.5	1	0.60	0.30048	1.00
08/31/2026 15:00	0.9	1.5	1	0.60	0.30000	1.00
08/31/2026 16:00	0.9	1.5	1	0.60	0.29946	1.00
08/31/2026 17:00	1.0	1.5	1	0.60	0.29784	0.99
08/31/2026 18:00	1.1	1.5	1	0.59	0.29580	0.99
08/31/2026 19:00	1.1	1.5	1	0.59	0.29520	0.98
08/31/2026 20:00	1.3	1.5	1	0.59	0.29388	0.98
08/31/2026 21:00	1.0	1.5	1	0.48	0.24036	0.80
08/31/2026 22:00	0.8	1.5	0	0.43	0.21444	0.71
08/31/2026 23:00	0.8	1.5	0	0.46	0.22902	0.76
Average/Sum#:	1.1	1.5	1	0.53	0.26299	0.88
Minimum:	0.7	1.5	0	0.43	0.21408	0.71
Maximum:	1.9	1.5	1	0.60	0.30228	1.01
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/01/2026 00:00	0.8	1.5	1	0.46	0.22866	0.76
09/01/2026 01:00	0.8	1.5	1	0.43	0.21444	0.71
09/01/2026 02:00	0.8	1.5	0	0.43	0.21438	0.71
09/01/2026 03:00	0.9	1.5	1	0.43	0.21432	0.71
09/01/2026 04:00	0.8	1.5	1	0.43	0.21420	0.71
09/01/2026 05:00	0.8	1.5	1	0.43	0.21426	0.71
09/01/2026 06:00	0.8	1.5	1	0.43	0.21426	0.71
09/01/2026 07:00	0.8	1.5	1	0.43	0.21414	0.71
09/01/2026 08:00	0.8	1.5	1	0.43	0.21408	0.71
09/01/2026 09:00	0.8	1.5	1	0.43	0.21384	0.71
09/01/2026 10:00	0.7	1.5	1	0.43	0.21372	0.71
09/01/2026 11:00	0.7	1.5	1	0.43	0.21360	0.71
09/01/2026 12:00	0.7	1.5	1	0.43	0.21330	0.71
09/01/2026 13:00	0.7	1.5	1	0.43	0.21270	0.71
09/01/2026 14:00	0.7	1.5	1	0.43	0.21252	0.71
09/01/2026 15:00	0.7	1.5	1	0.42	0.21246	0.71
09/01/2026 16:00	0.7	1.5	1	0.42	0.21240	0.71
09/01/2026 17:00	0.7	1.5	1	0.44	0.22122	0.74
09/01/2026 18:00	0.7	1.5	0	0.43	0.21288	0.71
09/01/2026 19:00	0.7	1.5	1	0.43	0.21300	0.71
09/01/2026 20:00	0.7	1.5	1	0.43	0.21348	0.71
09/01/2026 21:00	0.8	1.5	1	0.43	0.21384	0.71
09/01/2026 22:00	0.8	1.5	1	0.43	0.21396	0.71
09/01/2026 23:00	0.8	1.5	1	0.43	0.21432	0.71
Average/Sum#:	0.8	1.5	1	0.43	0.21458	0.71
Minimum:	0.7	1.5	0	0.42	0.21240	0.71
Maximum:	0.9	1.5	1	0.46	0.22866	0.76
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/02/2026 00:00	0.8	1.5	1	0.43	0.21450	0.72
09/02/2026 01:00	0.8	1.5	1	0.43	0.21456	0.72
09/02/2026 02:00	0.8	1.5	1	0.43	0.21462	0.72
09/02/2026 03:00	0.9	1.5	1	0.43	0.21474	0.72
09/02/2026 04:00	0.8	1.5	1	0.43	0.21486	0.72
09/02/2026 05:00	0.8	1.5	1	0.43	0.21474	0.72
09/02/2026 06:00	0.8	1.5	1	0.43	0.21468	0.72
09/02/2026 07:00	0.8	1.5	1	0.43	0.21456	0.72
09/02/2026 08:00	0.7	1.5	1	0.43	0.21450	0.72
09/02/2026 09:00	0.7	1.5	1	0.43	0.21432	0.71
09/02/2026 10:00	0.7	1.5	1	0.43	0.21408	0.71
09/02/2026 11:00	0.7	1.5	1	0.43	0.21354	0.71
09/02/2026 12:00	0.7	1.5	1	0.43	0.21294	0.71
09/02/2026 13:00	0.7	1.5	1	0.43	0.21264	0.71
09/02/2026 14:00	0.7	1.5	1	0.42	0.21246	0.71
09/02/2026 15:00	0.7	1.5	1	0.42	0.21240	0.71
09/02/2026 16:00	0.7	1.5	1	0.43	0.21450	0.72
09/02/2026 17:00	0.7	1.5	1	0.46	0.22824	0.76
09/02/2026 18:00	0.7	1.5	1	0.43	0.21252	0.71
09/02/2026 19:00	0.7	1.5	1	0.42	0.21216	0.71
09/02/2026 20:00	0.7	1.5	1	0.42	0.21228	0.71
09/02/2026 21:00	0.7	1.5	1	0.43	0.21264	0.71
09/02/2026 22:00	0.8	1.5	1	0.43	0.21276	0.71
09/02/2026 23:00	0.8	1.5	1	0.43	0.21288	0.71
Average/Sum#:	0.7	1.5	1	0.43	0.21426	0.72
Minimum:	0.7	1.5	1	0.42	0.21216	0.71
Maximum:	0.9	1.5	1	0.46	0.22824	0.76
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/03/2026 00:00	0.8	1.5	1	0.43	0.21312	0.71
09/03/2026 01:00	0.8	1.5	1	0.43	0.21330	0.71
09/03/2026 02:00	0.8	1.5	1	0.43	0.21336	0.71
09/03/2026 03:00	0.9	1.5	1	0.43	0.21348	0.71
09/03/2026 04:00	0.8	1.5	1	0.43	0.21348	0.71
09/03/2026 05:00	0.8	1.5	1	0.43	0.21366	0.71
09/03/2026 06:00	0.8	1.5	1	0.43	0.21618	0.72
09/03/2026 07:00	0.8	1.5	1	0.46	0.22794	0.76
09/03/2026 08:00	0.8	1.5	1	0.45	0.22578	0.75
09/03/2026 09:00	0.7	1.5	1	0.48	0.23784	0.79
09/03/2026 10:00	0.7	1.5	1	0.46	0.23034	0.77
09/03/2026 11:00	0.7	1.5	1	0.43	0.21300	0.71
09/03/2026 12:00	0.7	1.5	1	0.46	0.22986	0.77
09/03/2026 13:00	0.6	1.5	1	0.51	0.25614	0.85
09/03/2026 14:00	0.7	1.5	1	0.51	0.25704	0.86
09/03/2026 15:00	0.6	1.5	1	0.51	0.25692	0.86
09/03/2026 16:00	0.7	1.5	0	0.45	0.22326	0.74
09/03/2026 17:00	0.7	1.5	1	0.48	0.23922	0.80
09/03/2026 18:00	0.8	1.5	0	0.43	0.21498	0.72
09/03/2026 19:00	0.7	1.5	1	0.46	0.23226	0.77
09/03/2026 20:00	0.7	1.5	1	0.52	0.25764	0.86
09/03/2026 21:00	0.8	1.5	1	0.52	0.26010	0.87
09/03/2026 22:00	0.8	1.5	1	0.52	0.26010	0.87
09/03/2026 23:00	0.7	1.5	1	0.51	0.25704	0.86
Average/Sum#:	0.7	1.5	1	0.47	0.23234	0.77
Minimum:	0.6	1.5	0	0.43	0.21300	0.71
Maximum:	0.9	1.5	1	0.52	0.26010	0.87
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/04/2026 00:00	0.8	1.5	0	0.45	0.22380	0.75
09/04/2026 01:00	0.8	1.5	0	0.43	0.21378	0.71
09/04/2026 02:00	0.8	1.5	0	0.43	0.21384	0.71
09/04/2026 03:00	0.8	1.5	1	0.43	0.21360	0.71
09/04/2026 04:00	0.8	1.5	0	0.44	0.22056	0.74
09/04/2026 05:00	0.7	1.5	1	0.51	0.25440	0.85
09/04/2026 06:00	0.8	1.5	0	0.45	0.22548	0.75
09/04/2026 07:00	0.8	1.5	1	0.46	0.22872	0.76
09/04/2026 08:00	0.8	1.5	0	0.43	0.21354	0.71
09/04/2026 09:00	0.8	1.5	1	0.43	0.21336	0.71
09/04/2026 10:00	0.7	1.5	1	0.46	0.23172	0.77
09/04/2026 11:00	0.8	1.5	1	0.43	0.21330	0.71
09/04/2026 12:00	0.7	1.5	1	0.43	0.21318	0.71
09/04/2026 13:00	0.7	1.5	1	0.43	0.21276	0.71
09/04/2026 14:00	0.7	1.5	1	0.43	0.21258	0.71
09/04/2026 15:00	0.7	1.5	1	0.42	0.21246	0.71
09/04/2026 16:00	0.7	1.5	1	0.44	0.22140	0.74
09/04/2026 17:00	0.7	1.5	0	0.46	0.23028	0.77
09/04/2026 18:00	0.7	1.5	1	0.52	0.25812	0.86
09/04/2026 19:00	0.7	1.5	1	0.51	0.25734	0.86
09/04/2026 20:00	0.7	1.5	1	0.52	0.25758	0.86
09/04/2026 21:00	0.7	1.5	1	0.52	0.25830	0.86
09/04/2026 22:00	0.7	1.5	1	0.52	0.25782	0.86
09/04/2026 23:00	0.8	1.5	0	0.44	0.21822	0.73
Average/Sum#:	0.7	1.5	1	0.46	0.22817	0.76
Minimum:	0.7	1.5	0	0.42	0.21246	0.71
Maximum:	0.8	1.5	1	0.52	0.25830	0.86
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/05/2026 00:00	0.8	1.5	1	0.45	0.22470	0.75
09/05/2026 01:00	0.8	1.5	1	0.45	0.22362	0.75
09/05/2026 02:00	0.8	1.7	1	0.46	0.22980	0.77
09/05/2026 03:00	0.9	1.5	1	0.43	0.21468	0.72
09/05/2026 04:00	0.7	1.5	1	0.49	0.24486	0.82
09/05/2026 05:00	0.7	1.5	1	0.52	0.25776	0.86
09/05/2026 06:00	0.8	1.5	0	0.43	0.21438	0.71
09/05/2026 07:00	0.8	1.4	0	0.43	0.21378	0.71
09/05/2026 08:00	0.8	1.5	1	0.43	0.21336	0.71
09/05/2026 09:00	0.8	1.5	1	0.43	0.21318	0.71
09/05/2026 10:00	0.7	1.5	1	0.43	0.21276	0.71
09/05/2026 11:00	0.8	1.5	1	0.43	0.21270	0.71
09/05/2026 12:00	0.8	1.5	1	0.43	0.21264	0.71
09/05/2026 13:00	0.7	1.5	1	0.42	0.21240	0.71
09/05/2026 14:00	0.7	1.5	1	0.43	0.21252	0.71
09/05/2026 15:00	0.7	1.5	1	0.43	0.21276	0.71
09/05/2026 16:00	0.9	1.5	1	0.46	0.23022	0.77
09/05/2026 17:00	0.8	1.5	0	0.48	0.24222	0.81
09/05/2026 18:00	0.7	1.5	0	0.44	0.21774	0.73
09/05/2026 19:00	0.7	1.5	1	0.44	0.22104	0.74
09/05/2026 20:00	0.7	1.5	1	0.43	0.21342	0.71
09/05/2026 21:00	0.8	1.5	1	0.44	0.22134	0.74
09/05/2026 22:00	0.8	1.5	1	0.45	0.22308	0.74
09/05/2026 23:00	0.8	1.5	1	0.44	0.21972	0.73
Average/Sum#:	0.8	1.5	1	0.44	0.22145	0.74
Minimum:	0.7	1.4	0	0.42	0.21240	0.71
Maximum:	0.9	1.7	1	0.52	0.25776	0.86
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/06/2026 00:00	0.8	1.5	1	0.43	0.21348	0.71
09/06/2026 01:00	0.8	1.5	1	0.43	0.21540	0.72
09/06/2026 02:00	0.8	1.4	0	0.44	0.22230	0.74
09/06/2026 03:00	0.9	1.5	1	0.43	0.21342	0.71
09/06/2026 04:00	0.8	1.5	1	0.43	0.21570	0.72
09/06/2026 05:00	0.8	1.5	1	0.43	0.21402	0.71
09/06/2026 06:00	0.8	1.5	1	0.47	0.23280	0.78
09/06/2026 07:00	0.8	1.5	1	0.43	0.21342	0.71
09/06/2026 08:00	0.8	1.5	1	0.43	0.21300	0.71
09/06/2026 09:00	0.8	1.5	1	0.43	0.21276	0.71
09/06/2026 10:00	0.8	1.5	1	0.42	0.21246	0.71
09/06/2026 11:00	0.8	1.5	1	0.42	0.21240	0.71
09/06/2026 12:00	0.8	1.5	1	0.42	0.21216	0.71
09/06/2026 13:00	0.8	1.5	1	0.42	0.21174	0.71
09/06/2026 14:00	0.8	1.5	1	0.42	0.21234	0.71
09/06/2026 15:00	0.7	1.5	1	0.46	0.23196	0.77
09/06/2026 16:00	0.7	1.5	0	0.45	0.22410	0.75
09/06/2026 17:00	0.7	1.5	0	0.42	0.21168	0.71
09/06/2026 18:00	0.7	1.5	1	0.42	0.21186	0.71
09/06/2026 19:00	0.7	1.5	1	0.42	0.21204	0.71
09/06/2026 20:00	0.8	1.5	1	0.43	0.21252	0.71
09/06/2026 21:00	0.8	1.5	1	0.43	0.21258	0.71
09/06/2026 22:00	0.8	1.5	1	0.43	0.21306	0.71
09/06/2026 23:00	0.8	1.5	1	0.46	0.22866	0.76
Average/Sum#:	0.8	1.5	1	0.43	0.21608	0.72
Minimum:	0.7	1.4	0	0.42	0.21168	0.71
Maximum:	0.9	1.5	1	0.47	0.23280	0.78
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/07/2026 00:00	0.8	1.5	1	0.43	0.21354	0.71
09/07/2026 01:00	0.8	1.5	1	0.43	0.21384	0.71
09/07/2026 02:00	0.8	1.5	1	0.43	0.21408	0.71
09/07/2026 03:00	1.0	1.5	1	0.43	0.21438	0.71
09/07/2026 04:00	0.9	1.5	1	0.43	0.21438	0.71
09/07/2026 05:00	0.9	1.5	1	0.43	0.21402	0.71
09/07/2026 06:00	0.9	1.5	1	0.45	0.22530	0.75
09/07/2026 07:00	0.9	1.5	1	0.43	0.21360	0.71
09/07/2026 08:00	0.8	1.5	1	0.43	0.21294	0.71
09/07/2026 09:00	0.8	1.5	1	0.42	0.21246	0.71
09/07/2026 10:00	0.8	1.5	1	0.42	0.21210	0.71
09/07/2026 11:00	0.8	1.5	1	0.43	0.21252	0.71
09/07/2026 12:00	0.8	1.5	1	0.42	0.21222	0.71
09/07/2026 13:00	0.7	1.5	1	0.42	0.21120	0.70
09/07/2026 14:00	0.7	1.5	1	0.42	0.21210	0.71
09/07/2026 15:00	0.7	1.5	1	0.42	0.21096	0.70
09/07/2026 16:00	0.7	1.5	1	0.46	0.23118	0.77
09/07/2026 17:00	0.7	1.5	1	0.46	0.22764	0.76
09/07/2026 18:00	0.7	1.5	1	0.45	0.22536	0.75
09/07/2026 19:00	0.7	1.5	1	0.51	0.25284	0.84
09/07/2026 20:00	0.8	1.5	1	0.51	0.25422	0.85
09/07/2026 21:00	0.9	1.5	1	0.51	0.25428	0.85
09/07/2026 22:00	0.8	1.5	1	0.51	0.25446	0.85
09/07/2026 23:00	0.8	1.5	1	0.51	0.25512	0.85
Average/Sum#:	0.8	1.5	1	0.45	0.22395	0.75
Minimum:	0.7	1.5	1	0.42	0.21096	0.70
Maximum:	1.0	1.5	1	0.51	0.25512	0.85
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/08/2026 00:00	0.9	1.5	1	0.51	0.25524	0.85
09/08/2026 01:00	1.0	1.5	1	0.47	0.23556	0.79
09/08/2026 02:00	0.9	1.5	1	0.42	0.21114	0.70
09/08/2026 03:00	1.0	1.5	1	0.44	0.21840	0.73
09/08/2026 04:00	1.1	1.5	1	0.50	0.24930	0.83
09/08/2026 05:00	0.9	1.5	1	0.51	0.25620	0.85
09/08/2026 06:00	1.0	1.5	1	0.46	0.22788	0.76
09/08/2026 07:00	1.0	1.5	1	0.42	0.21126	0.70
09/08/2026 08:00	0.9	1.5	1	0.42	0.21072	0.70
09/08/2026 09:00	0.8	1.5	1	0.42	0.21060	0.70
09/08/2026 10:00	0.8	1.5	1	0.42	0.20982	0.70
09/08/2026 11:00	0.8	1.5	1	0.42	0.21036	0.70
09/08/2026 12:00	0.8	1.5	0	0.43	0.21648	0.72
09/08/2026 13:00	0.7	1.5	1	0.51	0.25656	0.86
09/08/2026 14:00	0.5	1.6	2	0.69	0.34638	1.15
09/08/2026 15:00	0.2	1.5	3	0.73	0.36444	1.21
09/08/2026 16:00	0.2	1.5	3	0.74	0.36888	1.23
09/08/2026 17:00	0.2	1.5	3	0.75	0.37500	1.25
09/08/2026 18:00	0.2	1.5	3	0.75	0.37368	1.25
09/08/2026 19:00	0.3	1.5	3	0.75	0.37320	1.24
09/08/2026 20:00	0.3	1.5	3	0.73	0.36588	1.22
09/08/2026 21:00	0.3	1.5	3	0.73	0.36426	1.21
09/08/2026 22:00	0.6	1.5	2	0.67	0.33366	1.11
09/08/2026 23:00	0.9	1.5	1	0.50	0.25080	0.84
Average/Sum#:	0.7	1.5	2	0.56	0.27899	0.93
Minimum:	0.2	1.5	0	0.42	0.20982	0.70
Maximum:	1.1	1.6	3	0.75	0.37500	1.25
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/09/2026 00:00	0.9	1.5	1	0.48	0.24132	0.80
09/09/2026 01:00	0.9	1.5	1	0.45	0.22254	0.74
09/09/2026 02:00	1.0	1.6	1	0.42	0.21162	0.71
09/09/2026 03:00	1.0	1.5	1	0.42	0.21198	0.71
09/09/2026 04:00	1.0	1.5	1	0.44	0.22032	0.73
09/09/2026 05:00	1.4	1.5	1	0.58	0.28782	0.96
09/09/2026 06:00	1.2	1.5	1	0.61	0.30372	1.01
09/09/2026 07:00	0.6	1.5	2	0.67	0.33456	1.12
09/09/2026 08:00	0.3	1.5	4	0.73	0.36354	1.21
09/09/2026 09:00	0.3	1.5	4	0.74	0.36798	1.23
09/09/2026 10:00	0.2	1.5	5	0.73	0.36486	1.22
09/09/2026 11:00	0.2	1.5	4	0.72	0.36216	1.21
09/09/2026 12:00	0.2	1.5	3	0.71	0.35646	1.19
09/09/2026 13:00	0.2	1.5	4	0.74	0.36774	1.23
09/09/2026 14:00	0.2	1.5	4	0.74	0.36888	1.23
09/09/2026 15:00	0.2	1.5	4	0.76	0.37782	1.26
09/09/2026 16:00	0.2	1.5	5	0.75	0.37710	1.26
09/09/2026 17:00	0.2	1.5	4	0.73	0.36654	1.22
09/09/2026 18:00	0.2	1.5	4	0.75	0.37590	1.25
09/09/2026 19:00	0.2	1.5	3	0.71	0.35580	1.19
09/09/2026 20:00	0.2	1.5	4	0.75	0.37488	1.25
09/09/2026 21:00	0.3	1.5	4	0.75	0.37500	1.25
09/09/2026 22:00	0.4	1.5	3	0.72	0.35880	1.20
09/09/2026 23:00	0.9	1.5	1	0.51	0.25602	0.85
Average/Sum#:	0.5	1.5	3	0.65	0.32514	1.08
Minimum:	0.2	1.5	1	0.42	0.21162	0.71
Maximum:	1.4	1.6	5	0.76	0.37782	1.26
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/10/2026 00:00	0.8	1.5	1	0.51	0.25590	0.85
09/10/2026 01:00	0.8	1.5	1	0.51	0.25482	0.85
09/10/2026 02:00	0.8	1.5	1	0.50	0.25056	0.84
09/10/2026 03:00	0.9	1.5	0	0.42	0.21114	0.70
09/10/2026 04:00	0.8	1.5	1	0.43	0.21516	0.72
09/10/2026 05:00	0.7	1.5	1	0.50	0.25230	0.84
09/10/2026 06:00	0.8	1.5	1	0.45	0.22722	0.76
09/10/2026 07:00	0.8	1.5	1	0.42	0.20940	0.70
09/10/2026 08:00	0.8	1.5	1	0.42	0.20916	0.70
09/10/2026 09:00	0.8	1.5	1	0.42	0.20898	0.70
09/10/2026 10:00	0.8	1.5	1	0.42	0.20916	0.70
09/10/2026 11:00	0.7	1.5	1	0.45	0.22500	0.75
09/10/2026 12:00	0.9	1.5	2	0.59	0.29550	0.99
09/10/2026 13:00	0.7	1.5	2	0.60	0.29880	1.00
09/10/2026 14:00	0.7	1.5	2	0.60	0.30120	1.00
09/10/2026 15:00	0.6	1.5	2	0.60	0.30204	1.01
09/10/2026 16:00	0.5	1.5	2	0.64	0.32046	1.07
09/10/2026 17:00	0.3	1.5	3	0.68	0.33858	1.13
09/10/2026 18:00	0.8	1.5	2	0.60	0.29934	1.00
09/10/2026 19:00	1.1	1.5	2	0.59	0.29472	0.98
09/10/2026 20:00	1.2	1.5	2	0.59	0.29466	0.98
09/10/2026 21:00	0.8	1.5	2	0.60	0.30156	1.01
09/10/2026 22:00	0.9	1.5	2	0.60	0.29904	1.00
09/10/2026 23:00	0.9	1.5	1	0.43	0.21444	0.71
Average/Sum#:	0.8	1.5	1	0.52	0.26205	0.87
Minimum:	0.3	1.5	0	0.42	0.20898	0.70
Maximum:	1.2	1.5	3	0.68	0.33858	1.13
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/11/2026 00:00	0.8	1.5	1	0.42	0.20976	0.70
09/11/2026 01:00	0.8	1.5	1	0.42	0.20988	0.70
09/11/2026 02:00	0.8	1.5	1	0.42	0.20988	0.70
09/11/2026 03:00	0.9	1.5	1	0.42	0.21006	0.70
09/11/2026 04:00	0.8	1.5	1	0.42	0.21048	0.70
09/11/2026 05:00	0.8	1.5	1	0.42	0.21072	0.70
09/11/2026 06:00	0.8	1.5	1	0.42	0.21090	0.70
09/11/2026 07:00	0.8	1.5	1	0.42	0.21084	0.70
09/11/2026 08:00	0.8	1.5	1	0.42	0.21048	0.70
09/11/2026 09:00	0.8	1.5	1	0.42	0.21018	0.70
09/11/2026 10:00	0.8	1.5	1	0.42	0.21024	0.70
09/11/2026 11:00	0.8	1.5	1	0.42	0.21060	0.70
09/11/2026 12:00	0.7	1.5	1	0.42	0.21018	0.70
09/11/2026 13:00	0.7	1.5	1	0.42	0.20958	0.70
09/11/2026 14:00	0.7	1.5	1	0.42	0.20982	0.70
09/11/2026 15:00	0.7	1.5	1	0.49	0.24594	0.82
09/11/2026 16:00	0.7	1.5	0	0.46	0.22944	0.76
09/11/2026 17:00	0.7	1.5	0	0.46	0.22776	0.76
09/11/2026 18:00	0.8	1.5	0	0.42	0.21096	0.70
09/11/2026 19:00	0.8	1.5	1	0.42	0.21096	0.70
09/11/2026 20:00	0.8	1.5	1	0.42	0.21066	0.70
09/11/2026 21:00	0.8	1.5	1	0.42	0.21030	0.70
09/11/2026 22:00	0.8	1.5	1	0.42	0.21024	0.70
09/11/2026 23:00	0.8	1.5	1	0.42	0.21018	0.70
Average/Sum#:	0.8	1.5	1	0.43	0.21334	0.71
Minimum:	0.7	1.5	0	0.42	0.20958	0.70
Maximum:	0.9	1.5	1	0.49	0.24594	0.82
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/12/2026 00:00	0.8	1.5	1	0.42	0.21018	0.70
09/12/2026 01:00	0.9	1.5	1	0.42	0.21024	0.70
09/12/2026 02:00	0.8	1.5	1	0.42	0.21024	0.70
09/12/2026 03:00	0.9	1.5	1	0.42	0.21036	0.70
09/12/2026 04:00	0.9	1.5	1	0.42	0.21042	0.70
09/12/2026 05:00	0.8	1.5	1	0.42	0.21048	0.70
09/12/2026 06:00	0.9	1.5	1	0.42	0.21060	0.70
09/12/2026 07:00	0.8	1.5	1	0.42	0.21048	0.70
09/12/2026 08:00	0.8	1.5	1	0.42	0.21024	0.70
09/12/2026 09:00	0.8	1.5	1	0.42	0.21000	0.70
09/12/2026 10:00	0.8	1.5	1	0.42	0.20994	0.70
09/12/2026 11:00	0.8	1.5	1	0.42	0.21012	0.70
09/12/2026 12:00	0.7	1.5	1	0.42	0.20988	0.70
09/12/2026 13:00	0.7	1.5	1	0.42	0.20922	0.70
09/12/2026 14:00	0.7	1.5	1	0.42	0.20916	0.70
09/12/2026 15:00	0.7	1.5	1	0.42	0.20922	0.70
09/12/2026 16:00	0.7	1.5	1	0.44	0.22200	0.74
09/12/2026 17:00	0.7	1.5	1	0.42	0.21132	0.70
09/12/2026 18:00	0.7	1.5	1	0.42	0.20946	0.70
09/12/2026 19:00	0.7	1.5	1	0.42	0.20976	0.70
09/12/2026 20:00	0.8	1.5	1	0.42	0.20982	0.70
09/12/2026 21:00	0.8	1.5	1	0.42	0.21048	0.70
09/12/2026 22:00	0.8	1.5	1	0.43	0.21270	0.71
09/12/2026 23:00	0.8	1.5	1	0.42	0.21090	0.70
Average/Sum#:	0.8	1.5	1	0.42	0.21072	0.70
Minimum:	0.7	1.5	1	0.42	0.20916	0.70
Maximum:	0.9	1.5	1	0.44	0.22200	0.74
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/13/2026 00:00	0.8	1.5	1	0.42	0.21108	0.70
09/13/2026 01:00	0.8	1.5	1	0.42	0.21120	0.70
09/13/2026 02:00	0.9	1.5	1	0.42	0.21132	0.70
09/13/2026 03:00	0.9	1.5	1	0.42	0.21144	0.70
09/13/2026 04:00	0.9	1.5	1	0.42	0.21150	0.71
09/13/2026 05:00	0.8	1.5	1	0.48	0.24054	0.80
09/13/2026 06:00	0.9	1.5	1	0.45	0.22380	0.75
09/13/2026 07:00	0.9	1.5	1	0.42	0.21144	0.70
09/13/2026 08:00	0.8	1.5	1	0.42	0.21108	0.70
09/13/2026 09:00	0.8	1.5	1	0.42	0.21114	0.70
09/13/2026 10:00	0.8	1.5	1	0.42	0.21114	0.70
09/13/2026 11:00	0.9	1.5	1	0.42	0.21138	0.70
09/13/2026 12:00	0.8	1.5	1	0.42	0.21120	0.70
09/13/2026 13:00	0.8	1.5	1	0.42	0.21078	0.70
09/13/2026 14:00	0.8	1.5	1	0.42	0.21066	0.70
09/13/2026 15:00	0.8	1.5	1	0.42	0.21054	0.70
09/13/2026 16:00	0.8	1.5	1	0.45	0.22422	0.75
09/13/2026 17:00	0.8	1.5	1	0.49	0.24330	0.81
09/13/2026 18:00	0.8	1.5	1	0.42	0.21198	0.71
09/13/2026 19:00	0.8	1.5	1	0.42	0.21060	0.70
09/13/2026 20:00	0.8	1.5	1	0.42	0.21132	0.70
09/13/2026 21:00	0.9	1.5	1	0.42	0.21120	0.70
09/13/2026 22:00	0.8	1.5	1	0.42	0.21126	0.70
09/13/2026 23:00	0.9	1.5	1	0.42	0.21174	0.71
Average/Sum#:	0.8	1.5	1	0.43	0.21483	0.71
Minimum:	0.8	1.5	1	0.42	0.21054	0.70
Maximum:	0.9	1.5	1	0.49	0.24330	0.81
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/14/2026 00:00	1.0	1.5	1	0.42	0.21168	0.71
09/14/2026 01:00	0.9	1.5	1	0.42	0.21168	0.71
09/14/2026 02:00	0.9	1.5	1	0.42	0.21186	0.71
09/14/2026 03:00	1.0	1.5	1	0.42	0.21204	0.71
09/14/2026 04:00	1.0	1.5	1	0.42	0.21216	0.71
09/14/2026 05:00	1.0	1.5	1	0.43	0.21480	0.72
09/14/2026 06:00	1.0	1.5	1	0.44	0.22206	0.74
09/14/2026 07:00	0.9	1.5	1	0.42	0.21156	0.71
09/14/2026 08:00	0.9	1.5	1	0.42	0.21120	0.70
09/14/2026 09:00	0.9	1.5	1	0.42	0.21072	0.70
09/14/2026 10:00	0.8	1.5	1	0.42	0.21060	0.70
09/14/2026 11:00	0.8	1.5	1	0.42	0.21096	0.70
09/14/2026 12:00	0.8	1.5	1	0.42	0.21084	0.70
09/14/2026 13:00	0.8	1.5	1	0.42	0.21036	0.70
09/14/2026 14:00	0.8	1.5	1	0.42	0.21030	0.70
09/14/2026 15:00	0.8	1.5	1	0.42	0.21006	0.70
09/14/2026 16:00	0.8	1.5	1	0.44	0.22152	0.74
09/14/2026 17:00	0.8	1.5	1	0.46	0.22842	0.76
09/14/2026 18:00	0.8	1.5	1	0.42	0.21012	0.70
09/14/2026 19:00	0.8	1.5	1	0.43	0.21600	0.72
09/14/2026 20:00	0.8	1.5	1	0.42	0.21150	0.71
09/14/2026 21:00	0.9	1.5	1	0.42	0.21036	0.70
09/14/2026 22:00	0.9	1.5	1	0.42	0.21120	0.70
09/14/2026 23:00	0.8	1.5	1	0.49	0.24402	0.81
Average/Sum#:	0.9	1.5	1	0.43	0.21442	0.72
Minimum:	0.8	1.5	1	0.42	0.21006	0.70
Maximum:	1.0	1.5	1	0.49	0.24402	0.81
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/15/2026 00:00	0.8	1.5	1	0.45	0.22626	0.75
09/15/2026 01:00	0.8	1.5	1	0.43	0.21420	0.71
09/15/2026 02:00	0.9	1.3	0	0.42	0.21132	0.70
09/15/2026 03:00	0.9	1.5	1	0.42	0.21144	0.70
09/15/2026 04:00	0.8	1.5	1	0.44	0.21840	0.73
09/15/2026 05:00	0.7	1.5	1	0.51	0.25614	0.85
09/15/2026 06:00	0.8	1.5	1	0.51	0.25632	0.85
09/15/2026 07:00	0.8	1.5	1	0.50	0.25116	0.84
09/15/2026 08:00	0.7	1.5	1	0.51	0.25626	0.85
09/15/2026 09:00	0.7	1.5	1	0.51	0.25572	0.85
09/15/2026 10:00	0.7	1.5	1	0.49	0.24408	0.81
09/15/2026 11:00	0.7	1.5	1	0.51	0.25602	0.85
09/15/2026 12:00	0.7	1.5	1	0.50	0.24972	0.83
09/15/2026 13:00	0.7	1.5	1	0.50	0.24936	0.83
09/15/2026 14:00	0.7	1.5	1	0.50	0.24924	0.83
09/15/2026 15:00	0.7	1.5	1	0.50	0.24792	0.83
09/15/2026 16:00	0.7	1.5	1	0.44	0.22158	0.74
09/15/2026 17:00	0.7	1.5	1	0.43	0.21312	0.71
09/15/2026 18:00	0.7	1.5	1	0.42	0.21102	0.70
09/15/2026 19:00	0.7	1.5	1	0.42	0.21084	0.70
09/15/2026 20:00	0.7	1.5	1	0.42	0.21132	0.70
09/15/2026 21:00	0.7	1.5	1	0.42	0.21168	0.71
09/15/2026 22:00	0.8	1.5	1	0.42	0.21192	0.71
09/15/2026 23:00	0.8	1.5	1	0.42	0.21216	0.71
Average/Sum#:	0.7	1.5	1	0.46	0.23155	0.77
Minimum:	0.7	1.3	0	0.42	0.21084	0.70
Maximum:	0.9	1.5	1	0.51	0.25632	0.85
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/16/2026 00:00	0.8	1.5	1	0.42	0.21228	0.71
09/16/2026 01:00	0.8	1.5	1	0.42	0.21240	0.71
09/16/2026 02:00	0.8	1.5	1	0.43	0.21276	0.71
09/16/2026 03:00	0.8	1.5	1	0.43	0.21288	0.71
09/16/2026 04:00	0.8	1.5	1	0.43	0.21294	0.71
09/16/2026 05:00	0.8	1.5	1	0.43	0.21330	0.71
09/16/2026 06:00	0.8	1.5	1	0.43	0.21720	0.72
09/16/2026 07:00	0.7	1.5	1	0.48	0.24108	0.80
09/16/2026 08:00	0.7	1.5	1	0.52	0.25824	0.86
09/16/2026 09:00	0.7	1.5	1	0.50	0.24942	0.83
09/16/2026 10:00	0.7	1.5	0	0.43	0.21546	0.72
09/16/2026 11:00	0.7	1.5	1	0.43	0.21444	0.71
09/16/2026 12:00	0.8	1.5	1	0.43	0.21438	0.71
09/16/2026 13:00	0.6	1.5	1	0.50	0.24954	0.83
09/16/2026 14:00	0.7	1.5	1	0.52	0.26070	0.87
09/16/2026 15:00	0.7	1.5	1	0.47	0.23286	0.78
09/16/2026 16:00	0.7	1.5	1	0.42	0.21186	0.71
09/16/2026 17:00	0.7	1.5	1	0.42	0.21174	0.71
09/16/2026 18:00	0.7	1.5	1	0.42	0.21228	0.71
09/16/2026 19:00	0.8	1.5	1	0.42	0.21246	0.71
09/16/2026 20:00	0.8	1.5	1	0.43	0.21258	0.71
09/16/2026 21:00	0.8	1.5	1	0.43	0.21270	0.71
09/16/2026 22:00	0.8	1.5	1	0.43	0.21288	0.71
09/16/2026 23:00	0.8	1.5	1	0.43	0.21300	0.71
Average/Sum#:	0.8	1.5	1	0.44	0.22206	0.74
Minimum:	0.6	1.5	0	0.42	0.21174	0.71
Maximum:	0.8	1.5	1	0.52	0.26070	0.87
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/17/2026 00:00	0.8	1.5	1	0.43	0.21300	0.71
09/17/2026 01:00	0.8	1.5	1	0.43	0.21306	0.71
09/17/2026 02:00	0.8	1.5	1	0.43	0.21312	0.71
09/17/2026 03:00	0.9	1.5	1	0.43	0.21336	0.71
09/17/2026 04:00	0.8	1.5	1	0.43	0.21318	0.71
09/17/2026 05:00	0.8	1.5	1	0.47	0.23508	0.78
09/17/2026 06:00	0.8	1.5	1	0.47	0.23340	0.78
09/17/2026 07:00	0.8	1.5	1	0.43	0.21306	0.71
09/17/2026 08:00	0.8	1.5	1	0.43	0.21306	0.71
09/17/2026 09:00	0.8	1.5	1	0.43	0.21324	0.71
09/17/2026 10:00	0.7	1.5	1	0.43	0.21300	0.71
09/17/2026 11:00	0.8	1.5	1	0.43	0.21288	0.71
09/17/2026 12:00	0.7	1.5	1	0.43	0.21276	0.71
09/17/2026 13:00	0.7	1.5	1	0.43	0.21252	0.71
09/17/2026 14:00	0.8	1.5	1	0.42	0.21234	0.71
09/17/2026 15:00	0.7	1.5	1	0.42	0.21234	0.71
09/17/2026 16:00	0.7	1.5	1	0.44	0.22104	0.74
09/17/2026 17:00	0.7	1.5	1	0.42	0.21234	0.71
09/17/2026 18:00	0.7	1.5	1	0.42	0.21228	0.71
09/17/2026 19:00	0.8	1.5	1	0.42	0.21234	0.71
09/17/2026 20:00	0.8	1.5	1	0.43	0.21252	0.71
09/17/2026 21:00	0.8	1.5	1	0.43	0.21282	0.71
09/17/2026 22:00	0.8	1.5	1	0.43	0.21288	0.71
09/17/2026 23:00	0.8	1.5	1	0.43	0.21312	0.71
Average/Sum#:	0.8	1.5	1	0.43	0.21495	0.72
Minimum:	0.7	1.5	1	0.42	0.21228	0.71
Maximum:	0.9	1.5	1	0.47	0.23508	0.78
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/18/2026 00:00	0.8	1.5	1	0.43	0.21312	0.71
09/18/2026 01:00	0.8	1.5	1	0.43	0.21324	0.71
09/18/2026 02:00	0.8	1.5	1	0.43	0.21330	0.71
09/18/2026 03:00	0.9	1.5	1	0.43	0.21372	0.71
09/18/2026 04:00	0.9	1.5	1	0.43	0.21372	0.71
09/18/2026 05:00	0.9	1.5	1	0.43	0.21396	0.71
09/18/2026 06:00	0.9	1.5	1	0.47	0.23484	0.78
09/18/2026 07:00	0.9	1.5	1	0.43	0.21468	0.72
09/18/2026 08:00	0.9	1.5	1	0.43	0.21312	0.71
09/18/2026 09:00	0.8	1.5	1	0.43	0.21270	0.71
09/18/2026 10:00	0.8	1.5	1	0.42	0.21246	0.71
09/18/2026 11:00	0.8	1.5	1	0.43	0.21306	0.71
09/18/2026 12:00	0.8	1.5	1	0.43	0.21288	0.71
09/18/2026 13:00	0.8	1.5	1	0.43	0.21330	0.71
09/18/2026 14:00	0.7	1.5	1	0.42	0.21156	0.71
09/18/2026 15:00	0.7	1.5	1	0.42	0.21156	0.71
09/18/2026 16:00	0.7	1.5	1	0.48	0.24234	0.81
09/18/2026 17:00	0.7	1.5	1	0.51	0.25614	0.85
09/18/2026 18:00	0.7	1.5	1	0.43	0.21252	0.71
09/18/2026 19:00	0.7	1.5	1	0.42	0.21150	0.71
09/18/2026 20:00	0.7	1.5	1	0.42	0.21174	0.71
09/18/2026 21:00	0.8	1.5	1	0.42	0.21162	0.71
09/18/2026 22:00	0.8	1.5	1	0.42	0.21180	0.71
09/18/2026 23:00	0.8	1.5	1	0.42	0.21240	0.71
Average/Sum#:	0.8	1.5	1	0.43	0.21672	0.72
Minimum:	0.7	1.5	1	0.42	0.21150	0.71
Maximum:	0.9	1.5	1	0.51	0.25614	0.85
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/19/2026 00:00	0.8	1.5	1	0.43	0.21258	0.71
09/19/2026 01:00	0.8	1.5	1	0.43	0.21258	0.71
09/19/2026 02:00	0.8	1.5	1	0.43	0.21276	0.71
09/19/2026 03:00	0.9	1.5	1	0.43	0.21294	0.71
09/19/2026 04:00	0.9	1.5	1	0.43	0.21294	0.71
09/19/2026 05:00	0.9	1.5	1	0.43	0.21312	0.71
09/19/2026 06:00	0.9	1.5	1	0.43	0.21312	0.71
09/19/2026 07:00	0.8	1.5	1	0.43	0.21270	0.71
09/19/2026 08:00	0.8	1.5	1	0.42	0.21228	0.71
09/19/2026 09:00	0.8	1.5	1	0.42	0.21216	0.71
09/19/2026 10:00	0.8	1.5	1	0.42	0.21204	0.71
09/19/2026 11:00	0.8	1.5	1	0.43	0.21318	0.71
09/19/2026 12:00	0.7	1.5	1	0.43	0.21252	0.71
09/19/2026 13:00	0.8	1.5	1	0.42	0.21180	0.71
09/19/2026 14:00	0.7	1.5	1	0.42	0.21126	0.70
09/19/2026 15:00	0.7	1.5	1	0.42	0.21132	0.70
09/19/2026 16:00	0.7	1.5	1	0.44	0.21846	0.73
09/19/2026 17:00	0.8	1.5	1	0.42	0.21120	0.70
09/19/2026 18:00	0.7	1.5	1	0.42	0.21138	0.70
09/19/2026 19:00	0.7	1.5	1	0.42	0.21162	0.71
09/19/2026 20:00	0.8	1.5	1	0.42	0.21138	0.70
09/19/2026 21:00	0.8	1.5	1	0.43	0.21468	0.72
09/19/2026 22:00	0.8	1.5	0	0.45	0.22314	0.74
09/19/2026 23:00	0.8	1.5	1	0.44	0.21984	0.73
Average/Sum#:	0.8	1.5	1	0.43	0.21338	0.71
Minimum:	0.7	1.5	0	0.42	0.21120	0.70
Maximum:	0.9	1.5	1	0.45	0.22314	0.74
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/20/2026 00:00	0.8	1.5	1	0.44	0.21798	0.73
09/20/2026 01:00	0.9	1.5	1	0.42	0.21216	0.71
09/20/2026 02:00	0.8	1.5	1	0.42	0.21234	0.71
09/20/2026 03:00	0.9	1.5	1	0.42	0.21240	0.71
09/20/2026 04:00	0.8	1.5	1	0.43	0.21252	0.71
09/20/2026 05:00	0.8	1.5	1	0.43	0.21288	0.71
09/20/2026 06:00	0.8	1.5	1	0.43	0.21336	0.71
09/20/2026 07:00	0.8	1.5	1	0.43	0.21276	0.71
09/20/2026 08:00	0.8	1.5	1	0.43	0.21264	0.71
09/20/2026 09:00	0.8	1.5	1	0.42	0.21228	0.71
09/20/2026 10:00	0.8	1.5	1	0.42	0.21198	0.71
09/20/2026 11:00	0.8	1.5	1	0.42	0.21234	0.71
09/20/2026 12:00	0.8	1.5	1	0.42	0.21234	0.71
09/20/2026 13:00	0.7	1.5	1	0.47	0.23382	0.78
09/20/2026 14:00	0.7	1.5	1	0.51	0.25674	0.86
09/20/2026 15:00	0.7	1.5	1	0.50	0.25224	0.84
09/20/2026 16:00	0.7	1.5	1	0.49	0.24270	0.81
09/20/2026 17:00	0.7	1.5	0	0.43	0.21294	0.71
09/20/2026 18:00	0.7	1.5	1	0.42	0.21156	0.71
09/20/2026 19:00	0.8	1.5	1	0.42	0.21192	0.71
09/20/2026 20:00	0.8	1.5	1	0.42	0.21216	0.71
09/20/2026 21:00	0.8	1.5	1	0.42	0.21198	0.71
09/20/2026 22:00	0.9	1.5	1	0.42	0.21210	0.71
09/20/2026 23:00	0.8	1.5	1	0.43	0.21558	0.72
Average/Sum#:	0.8	1.5	1	0.44	0.21841	0.73
Minimum:	0.7	1.5	0	0.42	0.21156	0.71
Maximum:	0.9	1.5	1	0.51	0.25674	0.86
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/21/2026 00:00	0.8	1.5	1	0.42	0.21216	0.71
09/21/2026 01:00	0.8	1.5	1	0.42	0.21228	0.71
09/21/2026 02:00	0.8	1.5	1	0.42	0.21240	0.71
09/21/2026 03:00	0.9	1.5	1	0.43	0.21252	0.71
09/21/2026 04:00	0.8	1.5	1	0.45	0.22368	0.75
09/21/2026 05:00	0.7	1.5	1	0.50	0.24990	0.83
09/21/2026 06:00	0.8	1.5	1	0.49	0.24378	0.81
09/21/2026 07:00	0.8	1.5	1	0.48	0.24120	0.80
09/21/2026 08:00	0.8	1.5	1	0.46	0.22896	0.76
09/21/2026 09:00	0.8	1.5	1	0.43	0.21276	0.71
09/21/2026 10:00	0.8	1.5	1	0.43	0.21258	0.71
09/21/2026 11:00	0.8	1.5	1	0.43	0.21252	0.71
09/21/2026 12:00	0.8	1.5	1	0.43	0.21264	0.71
09/21/2026 13:00	0.8	1.5	1	0.42	0.21234	0.71
09/21/2026 14:00	0.8	1.5	1	0.44	0.21900	0.73
09/21/2026 15:00	0.7	1.5	1	0.42	0.21168	0.71
09/21/2026 16:00	0.7	1.5	1	0.44	0.22032	0.73
09/21/2026 17:00	0.7	1.5	1	0.42	0.21162	0.71
09/21/2026 18:00	0.8	1.5	1	0.42	0.21192	0.71
09/21/2026 19:00	0.8	1.5	1	0.42	0.21234	0.71
09/21/2026 20:00	0.8	1.5	1	0.42	0.21228	0.71
09/21/2026 21:00	0.8	1.5	1	0.42	0.21246	0.71
09/21/2026 22:00	0.8	1.5	1	0.43	0.21252	0.71
09/21/2026 23:00	0.8	1.5	1	0.43	0.21264	0.71
Average/Sum#:	0.8	1.5	1	0.44	0.21819	0.73
Minimum:	0.7	1.5	1	0.42	0.21162	0.71
Maximum:	0.9	1.5	1	0.50	0.24990	0.83
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/22/2026 00:00	0.8	1.5	1	0.43	0.21282	0.71
09/22/2026 01:00	0.8	1.5	1	0.43	0.21288	0.71
09/22/2026 02:00	0.8	1.5	1	0.43	0.21312	0.71
09/22/2026 03:00	0.9	1.5	1	0.43	0.21318	0.71
09/22/2026 04:00	0.8	1.5	1	0.43	0.21342	0.71
09/22/2026 05:00	0.8	1.5	1	0.43	0.21354	0.71
09/22/2026 06:00	0.8	1.5	1	0.44	0.22206	0.74
09/22/2026 07:00	0.8	1.5	1	0.43	0.21354	0.71
09/22/2026 08:00	0.8	1.5	1	0.43	0.21318	0.71
09/22/2026 09:00	0.8	1.5	1	0.43	0.21282	0.71
09/22/2026 10:00	0.8	1.5	1	0.42	0.21240	0.71
09/22/2026 11:00	0.8	1.5	1	0.42	0.21234	0.71
09/22/2026 12:00	0.8	1.5	1	0.42	0.21222	0.71
09/22/2026 13:00	0.8	1.5	1	0.42	0.21192	0.71
09/22/2026 14:00	0.8	1.5	1	0.42	0.21186	0.71
09/22/2026 15:00	0.8	1.5	1	0.42	0.21192	0.71
09/22/2026 16:00	0.8	1.5	1	0.43	0.21672	0.72
09/22/2026 17:00	0.8	1.5	1	0.42	0.21132	0.70
09/22/2026 18:00	0.7	1.5	1	0.42	0.21108	0.70
09/22/2026 19:00	0.7	1.5	1	0.42	0.21174	0.71
09/22/2026 20:00	0.8	1.5	1	0.42	0.21204	0.71
09/22/2026 21:00	1.0	1.5	1	0.49	0.24390	0.81
09/22/2026 22:00	1.3	1.5	1	0.59	0.29352	0.98
09/22/2026 23:00	0.9	1.5	1	0.45	0.22512	0.75
Average/Sum#:	0.8	1.5	1	0.44	0.21828	0.73
Minimum:	0.7	1.5	1	0.42	0.21108	0.70
Maximum:	1.3	1.5	1	0.59	0.29352	0.98
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/23/2026 00:00	0.8	1.5	1	0.43	0.21318	0.71
09/23/2026 01:00	0.9	1.5	1	0.43	0.21354	0.71
09/23/2026 02:00	0.8	1.5	1	0.43	0.21330	0.71
09/23/2026 03:00	0.9	1.5	1	0.43	0.21348	0.71
09/23/2026 04:00	0.9	1.5	1	0.43	0.21576	0.72
09/23/2026 05:00	0.9	1.5	1	0.47	0.23520	0.78
09/23/2026 06:00	0.9	1.5	1	0.46	0.22986	0.77
09/23/2026 07:00	0.9	1.5	1	0.43	0.21348	0.71
09/23/2026 08:00	0.9	1.5	1	0.43	0.21282	0.71
09/23/2026 09:00	0.8	1.5	1	0.43	0.21258	0.71
09/23/2026 10:00	0.8	1.5	1	0.42	0.21240	0.71
09/23/2026 11:00	0.8	1.5	1	0.42	0.21210	0.71
09/23/2026 12:00	0.8	1.5	1	0.42	0.21186	0.71
09/23/2026 13:00	0.8	1.5	1	0.43	0.21708	0.72
09/23/2026 14:00	0.8	1.5	1	0.43	0.21396	0.71
09/23/2026 15:00	0.8	1.5	1	0.44	0.22170	0.74
09/23/2026 16:00	0.8	1.5	1	0.47	0.23430	0.78
09/23/2026 17:00	0.8	1.5	1	0.43	0.21396	0.71
09/23/2026 18:00	0.8	1.5	1	0.42	0.21162	0.71
09/23/2026 19:00	0.8	1.5	1	0.51	0.25386	0.85
09/23/2026 20:00	0.9	1.5	1	0.46	0.23148	0.77
09/23/2026 21:00	0.9	1.5	1	0.43	0.21600	0.72
09/23/2026 22:00	0.9	1.5	1	0.42	0.21198	0.71
09/23/2026 23:00	0.9	1.5	0	0.43	0.21282	0.71
Average/Sum#:	0.8	1.5	1	0.44	0.21868	0.73
Minimum:	0.8	1.5	0	0.42	0.21162	0.71
Maximum:	0.9	1.5	1	0.51	0.25386	0.85
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/24/2026 00:00	1.1	1.5	1	0.43	0.21282	0.71
09/24/2026 01:00	1.0	1.5	1	0.43	0.21270	0.71
09/24/2026 02:00	0.9	1.5	1	0.43	0.21252	0.71
09/24/2026 03:00	1.0	1.5	1	0.43	0.21276	0.71
09/24/2026 04:00	0.9	1.5	1	0.43	0.21438	0.71
09/24/2026 05:00	1.0	1.5	1	0.48	0.23874	0.80
09/24/2026 06:00	1.0	1.5	1	0.47	0.23406	0.78
09/24/2026 07:00	1.0	1.5	1	0.43	0.21282	0.71
09/24/2026 08:00	0.9	1.5	1	0.42	0.21234	0.71
09/24/2026 09:00	0.9	1.5	1	0.42	0.21192	0.71
09/24/2026 10:00	0.8	1.5	1	0.42	0.21192	0.71
09/24/2026 11:00	0.8	1.5	1	0.42	0.21156	0.71
09/24/2026 12:00	0.8	1.5	1	0.42	0.21156	0.71
09/24/2026 13:00	0.7	1.5	1	0.46	0.22932	0.76
09/24/2026 14:00	0.7	1.5	1	0.47	0.23592	0.79
09/24/2026 15:00	0.7	1.5	0	0.48	0.23898	0.80
09/24/2026 16:00	0.7	1.5	1	0.47	0.23610	0.79
09/24/2026 17:00	0.9	1.5	1	0.53	0.26448	0.88
09/24/2026 18:00	0.8	1.5	2	0.63	0.31260	1.04
09/24/2026 19:00	0.9	1.5	1	0.45	0.22308	0.74
09/24/2026 20:00	0.8	1.5	1	0.42	0.21072	0.70
09/24/2026 21:00	0.8	1.5	1	0.42	0.21096	0.70
09/24/2026 22:00	0.8	1.5	1	0.42	0.21126	0.70
09/24/2026 23:00	0.9	1.5	1	0.42	0.21144	0.70
Average/Sum#:	0.9	1.5	1	0.45	0.22479	0.75
Minimum:	0.7	1.5	0	0.42	0.21072	0.70
Maximum:	1.1	1.5	2	0.63	0.31260	1.04
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/25/2026 00:00	0.8	1.5	1	0.42	0.21162	0.71
09/25/2026 01:00	0.9	1.5	1	0.42	0.21162	0.71
09/25/2026 02:00	0.9	1.5	1	0.42	0.21162	0.71
09/25/2026 03:00	1.0	1.5	1	0.42	0.21168	0.71
09/25/2026 04:00	0.9	1.5	1	0.42	0.21174	0.71
09/25/2026 05:00	0.9	1.5	1	0.43	0.21378	0.71
09/25/2026 06:00	0.7	1.5	0	0.44	0.22038	0.73
09/25/2026 07:00	0.6	1.5	1	0.44	0.22188	0.74
09/25/2026 08:00	0.6	1.5	1	0.42	0.21144	0.70
09/25/2026 09:00	0.6	1.5	1	0.42	0.21114	0.70
09/25/2026 10:00	0.5	1.5	1	0.42	0.21120	0.70
09/25/2026 11:00	0.5	1.5	1	0.42	0.21036	0.70
09/25/2026 12:00	0.5	1.5	1	0.42	0.21024	0.70
09/25/2026 13:00	0.5	1.5	1	0.42	0.21048	0.70
09/25/2026 14:00	0.5	1.5	1	0.42	0.21012	0.70
09/25/2026 15:00	0.5	1.5	1	0.42	0.21000	0.70
09/25/2026 16:00	0.5	1.5	1	0.43	0.21438	0.71
09/25/2026 17:00	0.5	1.5	1	0.42	0.21030	0.70
09/25/2026 18:00	0.5	1.5	1	0.42	0.21048	0.70
09/25/2026 19:00	0.5	1.5	1	0.42	0.21066	0.70
09/25/2026 20:00	0.6	1.5	1	0.42	0.21054	0.70
09/25/2026 21:00	0.6	1.5	1	0.42	0.21096	0.70
09/25/2026 22:00	0.6	1.5	1	0.42	0.21120	0.70
09/25/2026 23:00	0.6	1.5	1	0.42	0.21120	0.70
Average/Sum#:	0.6	1.5	1	0.42	0.21204	0.71
Minimum:	0.5	1.5	0	0.42	0.21000	0.70
Maximum:	1.0	1.5	1	0.44	0.22188	0.74
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/26/2026 00:00	0.6	1.5	1	0.42	0.21156	0.71
09/26/2026 01:00	0.6	1.5	1	0.42	0.21156	0.71
09/26/2026 02:00	0.7	1.5	1	0.42	0.21180	0.71
09/26/2026 03:00	0.7	1.5	1	0.42	0.21186	0.71
09/26/2026 04:00	0.6	1.5	1	0.42	0.21192	0.71
09/26/2026 05:00	0.6	1.5	1	0.42	0.21198	0.71
09/26/2026 06:00	0.6	1.5	1	0.42	0.21204	0.71
09/26/2026 07:00	0.6	1.5	1	0.42	0.21216	0.71
09/26/2026 08:00	0.6	1.5	1	0.42	0.21216	0.71
09/26/2026 09:00	0.6	1.5	1	0.42	0.21204	0.71
09/26/2026 10:00	0.6	1.5	1	0.42	0.21168	0.71
09/26/2026 11:00	0.6	1.5	1	0.42	0.21132	0.70
09/26/2026 12:00	0.6	1.5	1	0.42	0.21150	0.71
09/26/2026 13:00	0.6	1.5	1	0.42	0.21132	0.70
09/26/2026 14:00	0.5	1.5	1	0.42	0.21126	0.70
09/26/2026 15:00	0.5	1.5	1	0.42	0.21120	0.70
09/26/2026 16:00	0.5	1.5	1	0.47	0.23664	0.79
09/26/2026 17:00	0.5	1.5	1	0.51	0.25710	0.86
09/26/2026 18:00	0.5	1.5	1	0.46	0.23142	0.77
09/26/2026 19:00	0.6	1.5	1	0.51	0.25650	0.86
09/26/2026 20:00	0.6	1.5	1	0.51	0.25536	0.85
09/26/2026 21:00	0.6	1.5	1	0.51	0.25536	0.85
09/26/2026 22:00	0.8	1.5	1	0.52	0.26190	0.87
09/26/2026 23:00	0.2	1.5	4	0.72	0.35940	1.20
Average/Sum#:	0.6	1.5	1	0.46	0.22921	0.77
Minimum:	0.2	1.5	1	0.42	0.21120	0.70
Maximum:	0.8	1.5	4	0.72	0.35940	1.20
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/27/2026 00:00	0.9	1.5	2	0.59	0.29490	0.98
09/27/2026 01:00	0.9	1.5	1	0.52	0.26016	0.87
09/27/2026 02:00	0.6	1.4	0	0.48	0.24024	0.80
09/27/2026 03:00	0.7	1.5	1	0.45	0.22626	0.75
09/27/2026 04:00	0.7	1.5	1	0.43	0.21540	0.72
09/27/2026 05:00	0.6	1.5	1	0.46	0.23130	0.77
09/27/2026 06:00	0.5	1.5	1	0.51	0.25278	0.84
09/27/2026 07:00	0.5	1.5	1	0.51	0.25278	0.84
09/27/2026 08:00	0.6	1.5	1	0.45	0.22434	0.75
09/27/2026 09:00	0.6	1.5	1	0.42	0.21234	0.71
09/27/2026 10:00	0.6	1.5	1	0.42	0.21228	0.71
09/27/2026 11:00	0.6	1.5	1	0.42	0.21216	0.71
09/27/2026 12:00	0.6	1.5	1	0.42	0.21186	0.71
09/27/2026 13:00	0.6	1.5	1	0.42	0.21162	0.71
09/27/2026 14:00	0.6	1.5	1	0.43	0.21402	0.71
09/27/2026 15:00	0.5	1.5	1	0.45	0.22326	0.74
09/27/2026 16:00	0.7	1.5	1	0.49	0.24516	0.82
09/27/2026 17:00	0.2	1.5	3	0.70	0.35016	1.17
09/27/2026 18:00	0.2	1.5	3	0.69	0.34626	1.15
09/27/2026 19:00	0.3	1.5	3	0.69	0.34530	1.15
09/27/2026 20:00	0.4	1.5	2	0.68	0.33750	1.13
09/27/2026 21:00	1.1	1.5	2	0.60	0.30162	1.01
09/27/2026 22:00	1.1	1.5	1	0.56	0.27954	0.93
09/27/2026 23:00	0.6	1.5	1	0.48	0.23862	0.80
Average/Sum#:	0.6	1.5	1	0.51	0.25583	0.85
Minimum:	0.2	1.4	0	0.42	0.21162	0.71
Maximum:	1.1	1.5	3	0.70	0.35016	1.17
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/28/2026 00:00	0.6	1.5	1	0.47	0.23490	0.78
09/28/2026 01:00	0.6	1.5	1	0.43	0.21306	0.71
09/28/2026 02:00	0.6	1.5	1	0.45	0.22572	0.75
09/28/2026 03:00	1.2	1.6	1	0.49	0.24474	0.82
09/28/2026 04:00	1.9	1.5	1	0.59	0.29334	0.98
09/28/2026 05:00	1.6	1.5	2	0.60	0.30216	1.01
09/28/2026 06:00	0.9	1.5	2	0.60	0.29796	0.99
09/28/2026 07:00	0.7	1.5	1	0.46	0.23094	0.77
09/28/2026 08:00	0.6	1.5	1	0.43	0.21252	0.71
09/28/2026 09:00	0.6	1.5	1	0.42	0.21210	0.71
09/28/2026 10:00	0.6	1.5	1	0.42	0.21162	0.71
09/28/2026 11:00	0.6	1.5	1	0.42	0.21168	0.71
09/28/2026 12:00	0.6	1.5	1	0.42	0.21126	0.70
09/28/2026 13:00	0.6	1.5	1	0.42	0.21102	0.70
09/28/2026 14:00	0.6	1.5	1	0.42	0.21084	0.70
09/28/2026 15:00	0.6	1.5	1	0.42	0.21066	0.70
09/28/2026 16:00	0.6	1.5	1	0.42	0.21138	0.70
09/28/2026 17:00	0.6	1.5	1	0.42	0.21048	0.70
09/28/2026 18:00	0.6	1.5	1	0.42	0.21042	0.70
09/28/2026 19:00	0.6	1.5	1	0.42	0.21078	0.70
09/28/2026 20:00	0.6	1.5	1	0.42	0.21096	0.70
09/28/2026 21:00	0.7	1.5	1	0.42	0.21144	0.70
09/28/2026 22:00	0.7	1.5	1	0.42	0.21162	0.71
09/28/2026 23:00	0.7	1.5	1	0.42	0.21186	0.71
Average/Sum#:	0.8	1.5	1	0.45	0.22598	0.75
Minimum:	0.6	1.5	1	0.42	0.21042	0.70
Maximum:	1.9	1.6	2	0.60	0.30216	1.01
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/29/2026 00:00	0.7	1.5	1	0.42	0.21198	0.71
09/29/2026 01:00	0.7	1.5	1	0.42	0.21216	0.71
09/29/2026 02:00	0.7	1.5	1	0.42	0.21222	0.71
09/29/2026 03:00	0.8	1.5	1	0.42	0.21246	0.71
09/29/2026 04:00	0.8	1.5	1	0.43	0.21270	0.71
09/29/2026 05:00	0.7	1.5	1	0.43	0.21264	0.71
09/29/2026 06:00	0.7	1.5	1	0.43	0.21258	0.71
09/29/2026 07:00	0.7	1.5	1	0.42	0.21216	0.71
09/29/2026 08:00	0.7	1.5	1	0.42	0.21162	0.71
09/29/2026 09:00	0.6	1.5	1	0.42	0.21096	0.70
09/29/2026 10:00	0.6	1.5	1	0.42	0.21072	0.70
09/29/2026 11:00	0.5	1.5	1	0.42	0.21102	0.70
09/29/2026 12:00	0.5	1.5	1	0.42	0.21030	0.70
09/29/2026 13:00	0.6	1.5	1	0.42	0.21000	0.70
09/29/2026 14:00	0.6	1.5	1	0.42	0.20994	0.70
09/29/2026 15:00	0.6	1.5	1	0.42	0.21006	0.70
09/29/2026 16:00	0.5	1.5	1	0.43	0.21744	0.72
09/29/2026 17:00	0.5	1.5	1	0.42	0.21054	0.70
09/29/2026 18:00	0.5	1.5	1	0.42	0.21048	0.70
09/29/2026 19:00	0.5	1.5	1	0.42	0.21030	0.70
09/29/2026 20:00	0.5	1.5	1	0.42	0.21060	0.70
09/29/2026 21:00	0.6	1.5	1	0.42	0.21060	0.70
09/29/2026 22:00	0.6	1.5	1	0.42	0.21102	0.70
09/29/2026 23:00	0.6	1.5	1	0.51	0.25626	0.85
Average/Sum#:	0.6	1.5	1	0.43	0.21337	0.71
Minimum:	0.5	1.5	1	0.42	0.20994	0.70
Maximum:	0.8	1.5	1	0.51	0.25626	0.85
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT1 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT1 PM10, LbPerHr 1 Hour(s)	Unit CT1 SO2, LbPerHr 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)
09/30/2026 00:00	0.6	1.5	1	0.42	0.21096	0.70
09/30/2026 01:00	0.7	1.5	1	0.43	0.21258	0.71
09/30/2026 02:00	0.6	1.5	1	0.45	0.22434	0.75
09/30/2026 03:00	1.5	1.6	2	0.56	0.27798	0.93
09/30/2026 04:00	1.0	1.5	2	0.59	0.29268	0.98
09/30/2026 05:00	0.5	1.5	3	0.67	0.33534	1.12
09/30/2026 06:00	0.6	1.4	2	0.54	0.27030	0.90
09/30/2026 07:00	0.7	1.5	1	0.42	0.21180	0.71
09/30/2026 08:00	0.6	1.5	1	0.43	0.21318	0.71
09/30/2026 09:00	0.6	1.5	1	0.42	0.21030	0.70
09/30/2026 10:00	0.6	1.5	1	0.44	0.21852	0.73
09/30/2026 11:00	0.6	1.5	1	0.47	0.23394	0.78
09/30/2026 12:00	0.7	1.5	1	0.50	0.25200	0.84
09/30/2026 13:00	0.8	1.5	2	0.59	0.29694	0.99
09/30/2026 14:00	0.3	1.6	3	0.70	0.35136	1.17
09/30/2026 15:00	0.1	1.5	3	0.71	0.35532	1.18
09/30/2026 16:00	0.2	1.5	3	0.70	0.35106	1.17
09/30/2026 17:00	0.2	1.5	3	0.68	0.34098	1.14
09/30/2026 18:00	0.5	1.5	2	0.61	0.30414	1.01
09/30/2026 19:00	0.7	1.5	2	0.57	0.28374	0.95
09/30/2026 20:00	0.7	1.5	1	0.52	0.25956	0.87
09/30/2026 21:00	0.8	1.5	2	0.60	0.29814	0.99
09/30/2026 22:00	0.7	1.5	0	0.45	0.22428	0.75
09/30/2026 23:00	0.6	1.5	1	0.46	0.22788	0.76
Average/Sum#:	0.6	1.5	2	0.54	0.26906	0.90
Minimum:	0.1	1.4	0	0.42	0.21030	0.70
Maximum:	1.5	1.6	3	0.71	0.35532	1.18
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/01/2026 00:00	0.8	1.5	-1	0.47	0.23424	0.78
07/01/2026 01:00	0.8	1.5	-2	0.47	0.23604	0.79
07/01/2026 02:00	0.8	1.5	-2	0.47	0.23574	0.79
07/01/2026 03:00	0.8	1.5	-2	0.47	0.23574	0.79
07/01/2026 04:00	0.8	1.5	-2	0.47	0.23526	0.78
07/01/2026 05:00	0.8	1.5	-1	0.47	0.23532	0.78
07/01/2026 06:00	0.8	1.5	-1	0.47	0.23496	0.78
07/01/2026 07:00	0.8	1.5	-1	0.47	0.23562	0.79
07/01/2026 08:00	0.8	1.5	0	0.47	0.23538	0.78
07/01/2026 09:00	0.7	1.5	0	0.47	0.23532	0.78
07/01/2026 10:00	0.7	1.5	-1	0.47	0.23400	0.78
07/01/2026 11:00	0.7	1.5	-1	0.47	0.23406	0.78
07/01/2026 12:00	0.7	1.5	-1	0.47	0.23478	0.78
07/01/2026 13:00	0.7	1.5	-1	0.47	0.23454	0.78
07/01/2026 14:00	0.7	1.5	0	0.47	0.23454	0.78
07/01/2026 15:00	0.7	1.5	-1	0.47	0.23460	0.78
07/01/2026 16:00	0.7	1.5	-1	0.48	0.23952	0.80
07/01/2026 17:00	0.7	1.5	-1	0.50	0.24768	0.83
07/01/2026 18:00	0.6	1.5	0	0.53	0.26418	0.88
07/01/2026 19:00	0.6	1.5	0	0.55	0.27612	0.92
07/01/2026 20:00	0.7	1.5	0	0.53	0.26322	0.88
07/01/2026 21:00	0.8	1.5	-1	0.48	0.24054	0.80
07/01/2026 22:00	0.8	1.5	-1	0.48	0.24162	0.81
07/01/2026 23:00	0.7	1.5	-1	0.50	0.24984	0.83
Average/Sum#:	0.7	1.5	-1	0.48	0.24095	0.80
Minimum:	0.6	1.5	-2	0.47	0.23400	0.78
Maximum:	0.8	1.5	0	0.55	0.27612	0.92
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/02/2026 00:00	0.8	1.5	-2	0.47	0.23466	0.78
07/02/2026 01:00	0.8	1.5	-2	0.47	0.23424	0.78
07/02/2026 02:00	0.8	1.5	-2	0.47	0.23418	0.78
07/02/2026 03:00	0.8	1.5	-2	0.47	0.23406	0.78
07/02/2026 04:00	0.8	1.5	-2	0.47	0.23718	0.79
07/02/2026 05:00	0.8	1.5	-2	0.47	0.23460	0.78
07/02/2026 06:00	0.8	1.5	-2	0.47	0.23448	0.78
07/02/2026 07:00	0.8	1.5	-2	0.47	0.23442	0.78
07/02/2026 08:00	0.8	1.5	0	0.47	0.23460	0.78
07/02/2026 09:00	0.8	1.5	0	0.47	0.23490	0.78
07/02/2026 10:00	0.7	1.5	-1	0.47	0.23400	0.78
07/02/2026 11:00	0.7	1.5	-1	0.47	0.23298	0.78
07/02/2026 12:00	0.7	1.5	-1	0.47	0.23262	0.78
07/02/2026 13:00	0.7	1.5	-1	0.47	0.23304	0.78
07/02/2026 14:00	0.7	1.5	-1	0.47	0.23328	0.78
07/02/2026 15:00	0.7	1.5	-1	0.47	0.23346	0.78
07/02/2026 16:00	0.7	1.5	-1	0.47	0.23352	0.78
07/02/2026 17:00	0.7	1.5	-1	0.48	0.24210	0.81
07/02/2026 18:00	0.7	1.5	-1	0.47	0.23286	0.78
07/02/2026 19:00	0.7	1.5	0	0.46	0.23202	0.77
07/02/2026 20:00	0.7	1.5	-1	0.47	0.23310	0.78
07/02/2026 21:00	0.7	1.5	-1	0.47	0.23322	0.78
07/02/2026 22:00	0.7	1.5	-1	0.47	0.23610	0.79
07/02/2026 23:00	0.7	1.5	-1	0.54	0.26832	0.89
Average/Sum#:	0.7	1.5	-1	0.47	0.23575	0.79
Minimum:	0.7	1.5	-2	0.46	0.23202	0.77
Maximum:	0.8	1.5	0	0.54	0.26832	0.89
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/03/2026 00:00	0.8	1.5	-2	0.47	0.23718	0.79
07/03/2026 01:00	0.8	1.5	-2	0.46	0.22806	0.76
07/03/2026 02:00	0.8	1.5	-2	0.45	0.22692	0.76
07/03/2026 03:00	0.8	1.5	-2	0.45	0.22686	0.76
07/03/2026 04:00	0.8	1.5	-2	0.47	0.23502	0.78
07/03/2026 05:00	0.8	1.5	-2	0.47	0.23616	0.79
07/03/2026 06:00	0.8	1.5	-1	0.47	0.23682	0.79
07/03/2026 07:00	0.8	1.5	-1	0.47	0.23706	0.79
07/03/2026 08:00	0.8	1.5	-1	0.48	0.23754	0.79
07/03/2026 09:00	0.7	1.5	-1	0.47	0.23574	0.79
07/03/2026 10:00	0.7	1.5	-1	0.47	0.23538	0.78
07/03/2026 11:00	0.7	1.5	-1	0.47	0.23568	0.79
07/03/2026 12:00	0.7	1.5	-1	0.47	0.23598	0.79
07/03/2026 13:00	0.7	1.5	-1	0.47	0.23616	0.79
07/03/2026 14:00	0.7	1.5	0	0.47	0.23598	0.79
07/03/2026 15:00	0.7	1.5	-1	0.47	0.23586	0.79
07/03/2026 16:00	0.8	1.5	-1	0.49	0.24408	0.81
07/03/2026 17:00	0.7	1.5	-1	0.49	0.24648	0.82
07/03/2026 18:00	0.7	1.5	-1	0.47	0.23562	0.79
07/03/2026 19:00	0.7	1.5	0	0.47	0.23706	0.79
07/03/2026 20:00	0.7	1.5	0	0.47	0.23652	0.79
07/03/2026 21:00	0.7	1.5	0	0.47	0.23664	0.79
07/03/2026 22:00	0.8	1.5	-1	0.47	0.23598	0.79
07/03/2026 23:00	0.7	1.5	-1	0.49	0.24264	0.81
Average/Sum#:	0.7	1.5	-1	0.47	0.23614	0.79
Minimum:	0.7	1.5	-2	0.45	0.22686	0.76
Maximum:	0.8	1.5	0	0.49	0.24648	0.82
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/04/2026 00:00	0.7	1.5	-1	0.54	0.26898	0.90
07/04/2026 01:00	0.8	1.5	-1	0.47	0.23568	0.79
07/04/2026 02:00	0.8	1.5	-2	0.46	0.22872	0.76
07/04/2026 03:00	0.8	1.5	-2	0.45	0.22668	0.76
07/04/2026 04:00	0.8	1.5	-2	0.45	0.22710	0.76
07/04/2026 05:00	0.8	1.5	-2	0.53	0.26574	0.89
07/04/2026 06:00	0.7	1.5	-1	0.53	0.26304	0.88
07/04/2026 07:00	0.8	1.5	-1	0.49	0.24318	0.81
07/04/2026 08:00	0.7	1.5	-1	0.47	0.23532	0.78
07/04/2026 09:00	0.7	1.5	-1	0.47	0.23526	0.78
07/04/2026 10:00	0.7	1.5	-1	0.47	0.23580	0.79
07/04/2026 11:00	0.7	1.5	-1	0.47	0.23460	0.78
07/04/2026 12:00	0.7	1.5	-1	0.47	0.23382	0.78
07/04/2026 13:00	0.7	1.5	-1	0.47	0.23382	0.78
07/04/2026 14:00	0.7	1.5	0	0.47	0.23568	0.79
07/04/2026 15:00	0.6	1.5	0	0.55	0.27378	0.91
07/04/2026 16:00	0.6	1.5	0	0.55	0.27708	0.92
07/04/2026 17:00	0.6	1.5	0	0.55	0.27342	0.91
07/04/2026 18:00	0.6	1.5	0	0.52	0.26244	0.87
07/04/2026 19:00	0.8	1.5	1	0.62	0.30894	1.03
07/04/2026 20:00	0.9	1.5	0	0.56	0.28206	0.94
07/04/2026 21:00	0.8	1.5	0	0.46	0.22788	0.76
07/04/2026 22:00	0.7	1.5	-1	0.48	0.23772	0.79
07/04/2026 23:00	0.7	1.5	-1	0.53	0.26472	0.88
Average/Sum#:	0.7	1.5	-1	0.50	0.25048	0.84
Minimum:	0.6	1.5	-2	0.45	0.22668	0.76
Maximum:	0.9	1.5	1	0.62	0.30894	1.03
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/05/2026 00:00	0.7	1.5	-1	0.50	0.24786	0.83
07/05/2026 01:00	0.8	1.5	-1	0.47	0.23730	0.79
07/05/2026 02:00	0.8	1.6	-1	0.48	0.23796	0.79
07/05/2026 03:00	0.8	1.5	-2	0.47	0.23724	0.79
07/05/2026 04:00	0.8	1.5	-2	0.48	0.23778	0.79
07/05/2026 05:00	0.7	1.5	-2	0.52	0.26094	0.87
07/05/2026 06:00	0.8	1.5	-1	0.49	0.24720	0.82
07/05/2026 07:00	0.8	1.5	-2	0.47	0.23742	0.79
07/05/2026 08:00	0.8	1.5	-1	0.47	0.23658	0.79
07/05/2026 09:00	0.8	1.5	-1	0.46	0.22992	0.77
07/05/2026 10:00	0.8	1.5	-1	0.46	0.23016	0.77
07/05/2026 11:00	0.7	1.5	-1	0.46	0.22938	0.76
07/05/2026 12:00	0.7	1.5	-1	0.46	0.22770	0.76
07/05/2026 13:00	0.7	1.5	-1	0.45	0.22704	0.76
07/05/2026 14:00	0.7	1.5	-1	0.45	0.22668	0.76
07/05/2026 15:00	0.7	1.5	-1	0.45	0.22728	0.76
07/05/2026 16:00	0.7	1.5	-1	0.46	0.22932	0.76
07/05/2026 17:00	0.6	1.5	0	0.56	0.27762	0.93
07/05/2026 18:00	0.6	1.5	0	0.55	0.27708	0.92
07/05/2026 19:00	0.6	1.5	0	0.55	0.27648	0.92
07/05/2026 20:00	0.7	1.5	0	0.55	0.27642	0.92
07/05/2026 21:00	0.7	1.5	0	0.55	0.27642	0.92
07/05/2026 22:00	0.8	1.5	-1	0.49	0.24408	0.81
07/05/2026 23:00	0.8	1.5	-1	0.46	0.23202	0.77
Average/Sum#:	0.7	1.5	-1	0.49	0.24450	0.81
Minimum:	0.6	1.5	-2	0.45	0.22668	0.76
Maximum:	0.8	1.6	0	0.56	0.27762	0.93
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/06/2026 00:00	0.8	1.5	-2	0.47	0.23334	0.78
07/06/2026 01:00	0.8	1.5	-2	0.46	0.22950	0.77
07/06/2026 02:00	0.8	1.5	-2	0.46	0.22944	0.76
07/06/2026 03:00	0.8	1.5	-2	0.46	0.22950	0.77
07/06/2026 04:00	0.8	1.5	-2	0.50	0.25050	0.84
07/06/2026 05:00	0.8	1.5	-2	0.48	0.24066	0.80
07/06/2026 06:00	0.8	1.5	-1	0.46	0.22884	0.76
07/06/2026 07:00	0.8	1.5	-1	0.46	0.22884	0.76
07/06/2026 08:00	0.8	1.5	0	0.46	0.22908	0.76
07/06/2026 09:00	0.8	1.5	0	0.46	0.22980	0.77
07/06/2026 10:00	0.8	1.5	-1	0.46	0.22986	0.77
07/06/2026 11:00	0.8	1.5	-1	0.46	0.22932	0.76
07/06/2026 12:00	0.8	1.5	-1	0.46	0.22770	0.76
07/06/2026 13:00	0.7	1.5	-1	0.47	0.23742	0.79
07/06/2026 14:00	0.7	1.5	0	0.47	0.23664	0.79
07/06/2026 15:00	0.7	1.5	0	0.50	0.25050	0.84
07/06/2026 16:00	0.7	1.5	-1	0.51	0.25644	0.85
07/06/2026 17:00	0.7	1.5	-1	0.51	0.25344	0.84
07/06/2026 18:00	0.6	1.5	0	0.56	0.27852	0.93
07/06/2026 19:00	0.6	1.5	0	0.56	0.27888	0.93
07/06/2026 20:00	0.6	1.5	0	0.56	0.27852	0.93
07/06/2026 21:00	0.7	1.5	-1	0.56	0.27864	0.93
07/06/2026 22:00	0.7	1.5	-1	0.56	0.27816	0.93
07/06/2026 23:00	0.7	1.5	-1	0.56	0.27750	0.93
Average/Sum#:	0.7	1.5	-1	0.49	0.24671	0.82
Minimum:	0.6	1.5	-2	0.46	0.22770	0.76
Maximum:	0.8	1.5	0	0.56	0.27888	0.93
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/07/2026 00:00	0.7	1.5	-2	0.55	0.27708	0.92
07/07/2026 01:00	0.7	1.5	-2	0.54	0.26928	0.90
07/07/2026 02:00	0.7	1.6	-2	0.55	0.27642	0.92
07/07/2026 03:00	0.7	1.5	-2	0.55	0.27654	0.92
07/07/2026 04:00	0.7	1.5	-2	0.55	0.27738	0.92
07/07/2026 05:00	0.7	1.5	-2	0.52	0.25806	0.86
07/07/2026 06:00	0.8	1.5	-2	0.46	0.23004	0.77
07/07/2026 07:00	0.8	1.5	-2	0.46	0.22998	0.77
07/07/2026 08:00	0.8	1.5	-1	0.46	0.23010	0.77
07/07/2026 09:00	0.8	1.5	-1	0.46	0.23034	0.77
07/07/2026 10:00	0.8	1.5	-1	0.46	0.23028	0.77
07/07/2026 11:00	0.7	1.5	-1	0.51	0.25368	0.85
07/07/2026 12:00	0.7	1.5	-1	0.49	0.24552	0.82
07/07/2026 13:00	0.7	1.5	-1	0.50	0.24792	0.83
07/07/2026 14:00	0.7	1.5	-1	0.53	0.26496	0.88
07/07/2026 15:00	0.7	1.5	-1	0.50	0.24978	0.83
07/07/2026 16:00	0.7	1.5	0	0.50	0.25194	0.84
07/07/2026 17:00	0.7	1.5	-1	0.52	0.26088	0.87
07/07/2026 18:00	0.7	1.5	0	0.55	0.27414	0.91
07/07/2026 19:00	0.6	1.5	0	0.55	0.27534	0.92
07/07/2026 20:00	0.7	1.5	-1	0.55	0.27468	0.92
07/07/2026 21:00	0.7	1.5	-1	0.55	0.27366	0.91
07/07/2026 22:00	0.7	1.5	-1	0.55	0.27354	0.91
07/07/2026 23:00	0.7	1.5	-1	0.53	0.26592	0.89
Average/Sum#:	0.7	1.5	-1	0.52	0.25823	0.86
Minimum:	0.6	1.5	-2	0.46	0.22998	0.77
Maximum:	0.8	1.6	0	0.55	0.27738	0.92
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/08/2026 00:00	0.7	1.5	-1	0.55	0.27534	0.92
07/08/2026 01:00	0.8	1.5	-2	0.47	0.23718	0.79
07/08/2026 02:00	0.8	1.5	-2	0.46	0.22782	0.76
07/08/2026 03:00	0.8	1.5	-2	0.46	0.22788	0.76
07/08/2026 04:00	0.8	1.5	-2	0.46	0.22800	0.76
07/08/2026 05:00	0.8	1.5	-2	0.46	0.22866	0.76
07/08/2026 06:00	0.8	1.5	-1	0.46	0.23142	0.77
07/08/2026 07:00	0.8	1.5	-1	0.46	0.22836	0.76
07/08/2026 08:00	0.8	1.5	0	0.46	0.22896	0.76
07/08/2026 09:00	0.8	1.5	-1	0.46	0.22962	0.77
07/08/2026 10:00	0.8	1.5	-1	0.46	0.22908	0.76
07/08/2026 11:00	0.8	1.5	-1	0.46	0.22848	0.76
07/08/2026 12:00	0.8	1.5	-1	0.46	0.22866	0.76
07/08/2026 13:00	0.7	1.5	-1	0.46	0.22908	0.76
07/08/2026 14:00	0.7	1.5	-1	0.46	0.22890	0.76
07/08/2026 15:00	0.7	1.5	-1	0.45	0.22746	0.76
07/08/2026 16:00	0.7	1.5	-1	0.45	0.22698	0.76
07/08/2026 17:00	0.7	1.5	-1	0.49	0.24372	0.81
07/08/2026 18:00	0.7	1.5	-1	0.50	0.25020	0.83
07/08/2026 19:00	0.7	1.5	-1	0.46	0.22872	0.76
07/08/2026 20:00	0.8	1.5	-1	0.46	0.22860	0.76
07/08/2026 21:00	0.8	1.5	-1	0.46	0.22848	0.76
07/08/2026 22:00	0.8	1.5	-1	0.46	0.22788	0.76
07/08/2026 23:00	0.8	1.5	-1	0.45	0.22734	0.76
Average/Sum#:	0.8	1.5	-1	0.47	0.23237	0.77
Minimum:	0.7	1.5	-2	0.45	0.22698	0.76
Maximum:	0.8	1.5	0	0.55	0.27534	0.92
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/09/2026 00:00	0.8	1.5	-2	0.45	0.22728	0.76
07/09/2026 01:00	0.8	1.5	-2	0.45	0.22722	0.76
07/09/2026 02:00	0.8	1.5	-2	0.45	0.22710	0.76
07/09/2026 03:00	0.8	1.5	-2	0.46	0.22872	0.76
07/09/2026 04:00	0.8	1.5	-2	0.48	0.24018	0.80
07/09/2026 05:00	0.8	1.5	-2	0.49	0.24276	0.81
07/09/2026 06:00	0.8	1.5	-1	0.46	0.22920	0.76
07/09/2026 07:00	0.8	1.5	-1	0.46	0.22944	0.76
07/09/2026 08:00	0.8	1.5	-1	0.46	0.22878	0.76
07/09/2026 09:00	0.8	1.5	-1	0.46	0.22788	0.76
07/09/2026 10:00	0.8	1.5	-1	0.46	0.22782	0.76
07/09/2026 11:00	0.7	1.5	-1	0.46	0.22836	0.76
07/09/2026 12:00	0.7	1.5	-1	0.46	0.22776	0.76
07/09/2026 13:00	0.7	1.5	-1	0.47	0.23628	0.79
07/09/2026 14:00	0.7	1.5	0	0.45	0.22716	0.76
07/09/2026 15:00	0.7	1.5	-1	0.45	0.22404	0.75
07/09/2026 16:00	0.7	1.5	-1	0.49	0.24312	0.81
07/09/2026 17:00	0.7	1.5	-1	0.51	0.25284	0.84
07/09/2026 18:00	0.6	1.5	0	0.55	0.27708	0.92
07/09/2026 19:00	0.6	1.5	0	0.55	0.27618	0.92
07/09/2026 20:00	0.7	1.5	0	0.51	0.25638	0.85
07/09/2026 21:00	0.7	1.5	0	0.51	0.25596	0.85
07/09/2026 22:00	0.7	1.5	0	0.52	0.25758	0.86
07/09/2026 23:00	0.7	1.5	-1	0.51	0.25422	0.85
Average/Sum#:	0.7	1.5	-1	0.48	0.23972	0.80
Minimum:	0.6	1.5	-2	0.45	0.22404	0.75
Maximum:	0.8	1.5	0	0.55	0.27708	0.92
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/10/2026 00:00	0.8	1.5	-1	0.48	0.24018	0.80
07/10/2026 01:00	0.8	1.5	-1	0.46	0.23196	0.77
07/10/2026 02:00	0.8	1.5	-2	0.46	0.23016	0.77
07/10/2026 03:00	0.7	1.5	-1	0.54	0.26976	0.90
07/10/2026 04:00	0.7	1.5	-2	0.51	0.25440	0.85
07/10/2026 05:00	0.8	1.5	-2	0.51	0.25512	0.85
07/10/2026 06:00	0.8	1.5	-1	0.46	0.23064	0.77
07/10/2026 07:00	0.8	1.5	-1	0.46	0.23046	0.77
07/10/2026 08:00	0.8	1.5	-1	0.46	0.23040	0.77
07/10/2026 09:00	0.8	1.5	-1	0.46	0.22986	0.77
07/10/2026 10:00	0.8	1.5	-1	0.46	0.22866	0.76
07/10/2026 11:00	0.7	1.5	-1	0.46	0.22854	0.76
07/10/2026 12:00	0.7	1.5	-1	0.46	0.22836	0.76
07/10/2026 13:00	0.7	1.5	-1	0.46	0.22764	0.76
07/10/2026 14:00	0.7	1.5	-1	0.45	0.22710	0.76
07/10/2026 15:00	0.7	1.5	-1	0.47	0.23472	0.78
07/10/2026 16:00	0.7	1.5	-1	0.49	0.24354	0.81
07/10/2026 17:00	0.8	1.5	1	0.62	0.30822	1.03
07/10/2026 18:00	0.4	1.5	2	0.67	0.33576	1.12
07/10/2026 19:00	0.5	1.5	2	0.66	0.33006	1.10
07/10/2026 20:00	0.8	1.5	1	0.63	0.31686	1.06
07/10/2026 21:00	0.9	1.5	1	0.63	0.31506	1.05
07/10/2026 22:00	0.9	1.5	1	0.63	0.31428	1.05
07/10/2026 23:00	1.0	1.5	0	0.63	0.31356	1.05
Average/Sum#:	0.8	1.5	-1	0.52	0.26064	0.87
Minimum:	0.4	1.5	-2	0.45	0.22710	0.76
Maximum:	1.0	1.5	2	0.67	0.33576	1.12
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/11/2026 00:00	1.0	1.5	0	0.63	0.31278	1.04
07/11/2026 01:00	1.0	1.5	0	0.62	0.31176	1.04
07/11/2026 02:00	1.1	1.5	-1	0.62	0.31068	1.04
07/11/2026 03:00	1.2	1.5	-1	0.62	0.31020	1.03
07/11/2026 04:00	1.1	1.5	-1	0.57	0.28590	0.95
07/11/2026 05:00	0.8	1.5	-2	0.48	0.24234	0.81
07/11/2026 06:00	0.8	1.5	-1	0.47	0.23352	0.78
07/11/2026 07:00	0.8	1.5	-1	0.46	0.22920	0.76
07/11/2026 08:00	0.8	1.5	0	0.46	0.22974	0.77
07/11/2026 09:00	0.8	1.5	-1	0.46	0.23010	0.77
07/11/2026 10:00	0.8	1.5	-1	0.46	0.22896	0.76
07/11/2026 11:00	0.7	1.5	-1	0.46	0.22860	0.76
07/11/2026 12:00	0.7	1.5	-1	0.46	0.22854	0.76
07/11/2026 13:00	0.7	1.5	-1	0.45	0.22716	0.76
07/11/2026 14:00	0.7	1.5	0	0.45	0.22686	0.76
07/11/2026 15:00	0.7	1.5	0	0.48	0.24246	0.81
07/11/2026 16:00	0.8	1.5	-1	0.48	0.23778	0.79
07/11/2026 17:00	0.7	1.5	1	0.63	0.31638	1.05
07/11/2026 18:00	0.8	1.5	1	0.64	0.32082	1.07
07/11/2026 19:00	0.9	1.5	1	0.63	0.31698	1.06
07/11/2026 20:00	0.7	1.5	1	0.64	0.32040	1.07
07/11/2026 21:00	0.5	1.5	2	0.67	0.33258	1.11
07/11/2026 22:00	0.8	1.5	1	0.64	0.31818	1.06
07/11/2026 23:00	0.4	1.5	3	0.71	0.35478	1.18
Average/Sum#:	0.8	1.5	0	0.55	0.27486	0.92
Minimum:	0.4	1.5	-2	0.45	0.22686	0.76
Maximum:	1.2	1.5	3	0.71	0.35478	1.18
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/12/2026 00:00	0.8	1.5	1	0.63	0.31614	1.05
07/12/2026 01:00	0.9	1.5	1	0.63	0.31518	1.05
07/12/2026 02:00	0.9	1.5	0	0.63	0.31470	1.05
07/12/2026 03:00	0.9	1.5	1	0.63	0.31458	1.05
07/12/2026 04:00	0.9	1.5	0	0.63	0.31410	1.05
07/12/2026 05:00	0.9	1.5	0	0.63	0.31374	1.05
07/12/2026 06:00	0.9	1.5	1	0.63	0.31722	1.06
07/12/2026 07:00	0.5	1.5	2	0.70	0.35220	1.17
07/12/2026 08:00	0.2	1.5	3	0.73	0.36630	1.22
07/12/2026 09:00	0.7	1.5	1	0.65	0.32442	1.08
07/12/2026 10:00	0.8	1.5	1	0.63	0.31398	1.05
07/12/2026 11:00	0.7	1.5	1	0.63	0.31704	1.06
07/12/2026 12:00	0.6	1.5	1	0.64	0.32094	1.07
07/12/2026 13:00	0.3	1.5	3	0.70	0.35010	1.17
07/12/2026 14:00	0.2	1.5	3	0.74	0.37098	1.24
07/12/2026 15:00	0.1	1.5	5	0.78	0.39060	1.30
07/12/2026 16:00	0.1	1.5	5	0.78	0.39078	1.30
07/12/2026 17:00	0.5	1.5	2	0.70	0.34914	1.16
07/12/2026 18:00	0.7	1.5	1	0.66	0.32790	1.09
07/12/2026 19:00	0.1	1.5	4	0.77	0.38532	1.28
07/12/2026 20:00	0.1	1.5	5	0.79	0.39450	1.32
07/12/2026 21:00	0.1	1.5	4	0.79	0.39276	1.31
07/12/2026 22:00	0.5	1.5	3	0.71	0.35418	1.18
07/12/2026 23:00	0.8	1.5	-1	0.48	0.23898	0.80
Average/Sum#:	0.6	1.5	2	0.68	0.33941	1.13
Minimum:	0.1	1.5	-1	0.48	0.23898	0.80
Maximum:	0.9	1.5	5	0.79	0.39450	1.32
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/13/2026 00:00	0.8	1.5	-1	0.49	0.24666	0.82
07/13/2026 01:00	0.7	1.5	0	0.55	0.27672	0.92
07/13/2026 02:00	0.7	1.5	-1	0.55	0.27696	0.92
07/13/2026 03:00	0.7	1.5	0	0.54	0.27078	0.90
07/13/2026 04:00	0.7	1.5	0	0.55	0.27516	0.92
07/13/2026 05:00	0.9	1.5	-1	0.51	0.25650	0.86
07/13/2026 06:00	0.9	1.5	-1	0.55	0.27534	0.92
07/13/2026 07:00	0.9	1.5	0	0.54	0.27186	0.91
07/13/2026 08:00	0.5	1.5	2	0.70	0.34926	1.16
07/13/2026 09:00	0.2	1.5	5	0.79	0.39720	1.32
07/13/2026 10:00	0.1	1.5	5	0.79	0.39612	1.32
07/13/2026 11:00	0.1	1.5	5	0.79	0.39552	1.32
07/13/2026 12:00	0.1	1.5	5	0.79	0.39492	1.32
07/13/2026 13:00	0.1	1.5	5	0.79	0.39690	1.32
07/13/2026 14:00	0.1	1.5	5	0.79	0.39654	1.32
07/13/2026 15:00	0.1	1.5	5	0.79	0.39654	1.32
07/13/2026 16:00	0.1	1.5	5	0.79	0.39660	1.32
07/13/2026 17:00	0.1	1.5	5	0.79	0.39342	1.31
07/13/2026 18:00	0.1	1.5	5	0.79	0.39282	1.31
07/13/2026 19:00	0.1	1.5	5	0.79	0.39582	1.32
07/13/2026 20:00	0.1	1.5	5	0.79	0.39342	1.31
07/13/2026 21:00	0.1	1.5	4	0.77	0.38466	1.28
07/13/2026 22:00	0.8	1.5	1	0.67	0.33714	1.12
07/13/2026 23:00	0.9	1.5	1	0.65	0.32286	1.08
Average/Sum#:	0.4	1.5	3	0.69	0.34541	1.15
Minimum:	0.1	1.5	-1	0.49	0.24666	0.82
Maximum:	0.9	1.5	5	0.79	0.39720	1.32
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/14/2026 00:00	0.6	1.5	1	0.68	0.34026	1.13
07/14/2026 01:00	0.9	1.5	1	0.63	0.31542	1.05
07/14/2026 02:00	0.8	1.4	1	0.63	0.31608	1.05
07/14/2026 03:00	0.9	1.5	0	0.63	0.31512	1.05
07/14/2026 04:00	0.9	1.5	0	0.63	0.31542	1.05
07/14/2026 05:00	0.6	1.5	1	0.67	0.33384	1.11
07/14/2026 06:00	0.9	1.5	1	0.63	0.31314	1.04
07/14/2026 07:00	0.8	1.5	1	0.63	0.31476	1.05
07/14/2026 08:00	0.7	1.5	1	0.63	0.31728	1.06
07/14/2026 09:00	0.4	1.5	2	0.64	0.32208	1.07
07/14/2026 10:00	0.3	1.5	2	0.65	0.32502	1.08
07/14/2026 11:00	0.1	1.5	3	0.66	0.32934	1.10
07/14/2026 12:00	0.5	1.4	1	0.67	0.33516	1.12
07/14/2026 13:00	0.4	1.5	3	0.71	0.35352	1.18
07/14/2026 14:00	0.1	1.5	4	0.75	0.37746	1.26
07/14/2026 15:00	0.1	1.5	6	0.78	0.38796	1.29
07/14/2026 16:00	0.1	1.5	5	0.77	0.38532	1.28
07/14/2026 17:00	0.1	1.5	6	0.78	0.39108	1.30
07/14/2026 18:00	0.1	1.5	5	0.78	0.38958	1.30
07/14/2026 19:00	0.1	1.5	4	0.76	0.37920	1.26
07/14/2026 20:00	0.3	1.5	3	0.73	0.36438	1.21
07/14/2026 21:00	0.2	1.5	3	0.74	0.37128	1.24
07/14/2026 22:00	0.6	1.5	1	0.67	0.33504	1.12
07/14/2026 23:00	1.0	1.5	1	0.63	0.31542	1.05
Average/Sum#:	0.5	1.5	2	0.69	0.34347	1.14
Minimum:	0.1	1.4	0	0.63	0.31314	1.04
Maximum:	1.0	1.5	6	0.78	0.39108	1.30
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/15/2026 00:00	0.8	1.5	1	0.63	0.31722	1.06
07/15/2026 01:00	0.7	1.5	1	0.63	0.31644	1.05
07/15/2026 02:00	0.7	1.5	1	0.63	0.31440	1.05
07/15/2026 03:00	0.8	1.5	1	0.63	0.31338	1.04
07/15/2026 04:00	0.8	1.5	1	0.63	0.31314	1.04
07/15/2026 05:00	0.8	1.5	1	0.63	0.31380	1.05
07/15/2026 06:00	0.8	1.5	1	0.63	0.31536	1.05
07/15/2026 07:00	0.7	1.5	1	0.64	0.31788	1.06
07/15/2026 08:00	0.6	1.5	2	0.64	0.32112	1.07
07/15/2026 09:00	0.3	1.5	3	0.65	0.32580	1.09
07/15/2026 10:00	0.1	1.5	6	0.77	0.38652	1.29
07/15/2026 11:00	0.1	1.5	5	0.78	0.39138	1.30
07/15/2026 12:00	0.3	1.5	3	0.72	0.35958	1.20
07/15/2026 13:00	0.2	1.5	4	0.75	0.37302	1.24
07/15/2026 14:00	0.2	1.5	7	0.80	0.39816	1.33
07/15/2026 15:00	0.1	1.5	5	0.78	0.38784	1.29
07/15/2026 16:00	0.2	1.5	7	0.81	0.40266	1.34
07/15/2026 17:00	0.1	1.5	6	0.79	0.39372	1.31
07/15/2026 18:00	0.1	1.5	6	0.79	0.39624	1.32
07/15/2026 19:00	0.1	1.5	5	0.77	0.38724	1.29
07/15/2026 20:00	0.2	1.5	3	0.75	0.37596	1.25
07/15/2026 21:00	0.3	1.5	3	0.73	0.36264	1.21
07/15/2026 22:00	0.6	1.5	2	0.66	0.32880	1.10
07/15/2026 23:00	0.7	1.5	1	0.64	0.32178	1.07
Average/Sum#:	0.4	1.5	3	0.70	0.35142	1.17
Minimum:	0.1	1.5	1	0.63	0.31314	1.04
Maximum:	0.8	1.5	7	0.81	0.40266	1.34
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/16/2026 00:00	0.8	1.5	1	0.64	0.32076	1.07
07/16/2026 01:00	0.8	1.5	1	0.64	0.31866	1.06
07/16/2026 02:00	0.9	1.5	0	0.63	0.31464	1.05
07/16/2026 03:00	1.0	1.5	0	0.63	0.31362	1.05
07/16/2026 04:00	1.0	1.5	0	0.63	0.31410	1.05
07/16/2026 05:00	1.0	1.5	0	0.63	0.31386	1.05
07/16/2026 06:00	1.0	1.5	0	0.63	0.31374	1.05
07/16/2026 07:00	0.9	1.5	1	0.63	0.31500	1.05
07/16/2026 08:00	0.8	1.5	1	0.63	0.31644	1.05
07/16/2026 09:00	0.7	1.5	1	0.64	0.31764	1.06
07/16/2026 10:00	0.7	1.5	1	0.64	0.32034	1.07
07/16/2026 11:00	0.5	1.5	2	0.65	0.32250	1.08
07/16/2026 12:00	0.2	1.5	2	0.66	0.32868	1.10
07/16/2026 13:00	0.2	1.5	3	0.66	0.32904	1.10
07/16/2026 14:00	0.1	1.5	4	0.66	0.33030	1.10
07/16/2026 15:00	0.1	1.5	4	0.66	0.33240	1.11
07/16/2026 16:00	0.1	1.5	3	0.66	0.33126	1.10
07/16/2026 17:00	0.2	1.5	3	0.66	0.33084	1.10
07/16/2026 18:00	0.3	1.5	2	0.65	0.32556	1.09
07/16/2026 19:00	0.6	1.5	2	0.64	0.32070	1.07
07/16/2026 20:00	0.7	1.5	1	0.63	0.31680	1.06
07/16/2026 21:00	0.8	1.5	1	0.63	0.31518	1.05
07/16/2026 22:00	0.9	1.5	1	0.63	0.31410	1.05
07/16/2026 23:00	0.9	1.5	0	0.63	0.31296	1.04
Average/Sum#:	0.6	1.5	1	0.64	0.32038	1.07
Minimum:	0.1	1.5	0	0.63	0.31296	1.04
Maximum:	1.0	1.5	4	0.66	0.33240	1.11
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/17/2026 00:00	0.9	1.5	0	0.63	0.31284	1.04
07/17/2026 01:00	1.0	1.5	0	0.62	0.31200	1.04
07/17/2026 02:00	1.0	1.4	-1	0.63	0.31284	1.04
07/17/2026 03:00	1.1	1.5	-1	0.63	0.31284	1.04
07/17/2026 04:00	1.2	1.5	-1	0.62	0.31206	1.04
07/17/2026 05:00	1.2	1.5	0	0.62	0.31194	1.04
07/17/2026 06:00	1.2	1.5	0	0.63	0.31290	1.04
07/17/2026 07:00	1.0	1.5	0	0.63	0.31422	1.05
07/17/2026 08:00	1.0	1.5	1	0.63	0.31572	1.05
07/17/2026 09:00	0.9	1.5	1	0.63	0.31548	1.05
07/17/2026 10:00	0.9	1.5	1	0.63	0.31632	1.05
07/17/2026 11:00	0.7	1.5	1	0.64	0.31938	1.06
07/17/2026 12:00	0.5	1.5	2	0.64	0.32220	1.07
07/17/2026 13:00	0.3	1.5	2	0.65	0.32628	1.09
07/17/2026 14:00	0.2	1.5	3	0.66	0.32964	1.10
07/17/2026 15:00	0.2	1.5	3	0.66	0.32868	1.10
07/17/2026 16:00	0.2	1.5	3	0.66	0.32898	1.10
07/17/2026 17:00	0.2	1.5	2	0.65	0.32562	1.09
07/17/2026 18:00	0.5	1.5	1	0.64	0.31980	1.07
07/17/2026 19:00	0.7	1.5	1	0.63	0.31566	1.05
07/17/2026 20:00	0.8	1.5	1	0.63	0.31404	1.05
07/17/2026 21:00	0.9	1.5	1	0.63	0.31338	1.04
07/17/2026 22:00	1.0	1.5	0	0.62	0.31242	1.04
07/17/2026 23:00	1.0	1.5	0	0.62	0.31152	1.04
Average/Sum#:	0.8	1.5	1	0.63	0.31737	1.06
Minimum:	0.2	1.4	-1	0.62	0.31152	1.04
Maximum:	1.2	1.5	3	0.66	0.32964	1.10
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/18/2026 00:00	1.3	1.5	0	0.62	0.31056	1.04
07/18/2026 01:00	1.4	1.5	-1	0.62	0.30990	1.03
07/18/2026 02:00	1.5	1.6	-1	0.62	0.30948	1.03
07/18/2026 03:00	1.6	1.5	-1	0.62	0.30954	1.03
07/18/2026 04:00	1.6	1.5	-1	0.62	0.30852	1.03
07/18/2026 05:00	1.6	1.5	-1	0.64	0.31782	1.06
07/18/2026 06:00	2.2	1.5	-1	0.62	0.30960	1.03
07/18/2026 07:00	2.1	1.5	0	0.62	0.31116	1.04
07/18/2026 08:00	1.6	1.5	1	0.63	0.31326	1.04
07/18/2026 09:00	1.1	1.5	1	0.63	0.31440	1.05
07/18/2026 10:00	1.0	1.5	0	0.63	0.31512	1.05
07/18/2026 11:00	0.9	1.5	-1	0.55	0.27462	0.92
07/18/2026 12:00	0.8	1.5	-1	0.45	0.22500	0.75
07/18/2026 13:00	0.9	1.5	-1	0.48	0.23946	0.80
07/18/2026 14:00	0.4	1.5	2	0.65	0.32454	1.08
07/18/2026 15:00	0.3	1.5	2	0.65	0.32502	1.08
07/18/2026 16:00	0.3	1.5	2	0.65	0.32550	1.09
07/18/2026 17:00	0.2	1.5	2	0.65	0.32556	1.09
07/18/2026 18:00	0.3	1.5	2	0.65	0.32340	1.08
07/18/2026 19:00	0.6	1.5	1	0.64	0.31848	1.06
07/18/2026 20:00	0.7	1.5	1	0.63	0.31740	1.06
07/18/2026 21:00	0.8	1.5	1	0.64	0.31788	1.06
07/18/2026 22:00	0.9	1.5	1	0.63	0.31644	1.05
07/18/2026 23:00	0.9	1.5	0	0.63	0.31542	1.05
Average/Sum#:	1.0	1.5	0	0.62	0.30742	1.03
Minimum:	0.2	1.5	-1	0.45	0.22500	0.75
Maximum:	2.2	1.6	2	0.65	0.32556	1.09
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/19/2026 00:00	1.0	1.5	0	0.63	0.31494	1.05
07/19/2026 01:00	1.1	1.5	0	0.63	0.31398	1.05
07/19/2026 02:00	1.2	1.5	0	0.63	0.31296	1.04
07/19/2026 03:00	1.2	1.5	0	0.62	0.31194	1.04
07/19/2026 04:00	1.2	1.5	0	0.62	0.31092	1.04
07/19/2026 05:00	1.4	1.5	0	0.62	0.31092	1.04
07/19/2026 06:00	1.4	1.5	0	0.62	0.31188	1.04
07/19/2026 07:00	1.4	1.5	0	0.63	0.31260	1.04
07/19/2026 08:00	1.1	1.5	1	0.63	0.31362	1.05
07/19/2026 09:00	1.0	1.5	1	0.63	0.31446	1.05
07/19/2026 10:00	0.9	1.5	1	0.63	0.31692	1.06
07/19/2026 11:00	0.6	1.5	1	0.64	0.31980	1.07
07/19/2026 12:00	0.4	1.5	2	0.65	0.32502	1.08
07/19/2026 13:00	0.3	1.5	2	0.65	0.32736	1.09
07/19/2026 14:00	0.2	1.5	3	0.66	0.32874	1.10
07/19/2026 15:00	0.2	1.5	3	0.66	0.33042	1.10
07/19/2026 16:00	0.2	1.5	3	0.67	0.33360	1.11
07/19/2026 17:00	0.1	1.5	5	0.73	0.36300	1.21
07/19/2026 18:00	0.2	1.5	3	0.74	0.37164	1.24
07/19/2026 19:00	0.4	1.5	2	0.73	0.36294	1.21
07/19/2026 20:00	0.2	1.5	4	0.78	0.39120	1.30
07/19/2026 21:00	0.2	1.5	4	0.79	0.39360	1.31
07/19/2026 22:00	0.2	1.5	4	0.78	0.38970	1.30
07/19/2026 23:00	0.2	1.5	3	0.77	0.38748	1.29
Average/Sum#:	0.7	1.5	2	0.67	0.33624	1.12
Minimum:	0.1	1.5	0	0.62	0.31092	1.04
Maximum:	1.4	1.5	5	0.79	0.39360	1.31
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/20/2026 00:00	0.7	1.5	1	0.68	0.34164	1.14
07/20/2026 01:00	1.0	1.5	0	0.63	0.31494	1.05
07/20/2026 02:00	0.8	1.4	1	0.66	0.32904	1.10
07/20/2026 03:00	0.2	1.6	4	0.78	0.38928	1.30
07/20/2026 04:00	0.2	1.5	5	0.79	0.39564	1.32
07/20/2026 05:00	0.2	1.5	4	0.79	0.39438	1.31
07/20/2026 06:00	0.2	1.5	4	0.77	0.38634	1.29
07/20/2026 07:00	0.2	1.5	3	0.76	0.37854	1.26
07/20/2026 08:00	0.2	1.5	4	0.76	0.38016	1.27
07/20/2026 09:00	0.2	1.5	3	0.73	0.36720	1.22
07/20/2026 10:00	0.2	1.5	4	0.77	0.38430	1.28
07/20/2026 11:00	0.2	1.5	3	0.76	0.38130	1.27
07/20/2026 12:00	0.2	1.5	3	0.75	0.37428	1.25
07/20/2026 13:00	0.1	1.5	4	0.77	0.38658	1.29
07/20/2026 14:00	0.2	1.5	3	0.74	0.37086	1.24
07/20/2026 15:00	0.2	1.5	3	0.74	0.37158	1.24
07/20/2026 16:00	0.2	1.5	3	0.76	0.37764	1.26
07/20/2026 17:00	0.2	1.5	3	0.76	0.37752	1.26
07/20/2026 18:00	0.2	1.5	4	0.78	0.38802	1.29
07/20/2026 19:00	0.2	1.5	3	0.76	0.38148	1.27
07/20/2026 20:00	0.2	1.5	4	0.77	0.38664	1.29
07/20/2026 21:00	0.3	1.5	3	0.75	0.37638	1.25
07/20/2026 22:00	0.7	1.5	1	0.68	0.33852	1.13
07/20/2026 23:00	0.5	1.5	2	0.69	0.34554	1.15
Average/Sum#:	0.3	1.5	3	0.74	0.37158	1.24
Minimum:	0.1	1.4	0	0.63	0.31494	1.05
Maximum:	1.0	1.6	5	0.79	0.39564	1.32
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/21/2026 00:00	0.8	1.5	1	0.63	0.31704	1.06
07/21/2026 01:00	0.8	1.5	1	0.64	0.31818	1.06
07/21/2026 02:00	0.8	1.5	1	0.64	0.31830	1.06
07/21/2026 03:00	0.9	1.5	1	0.63	0.31686	1.06
07/21/2026 04:00	0.7	1.5	1	0.66	0.33186	1.11
07/21/2026 05:00	0.2	1.5	3	0.75	0.37308	1.24
07/21/2026 06:00	0.6	1.5	2	0.68	0.34092	1.14
07/21/2026 07:00	0.7	1.5	1	0.66	0.32898	1.10
07/21/2026 08:00	0.5	1.5	2	0.67	0.33666	1.12
07/21/2026 09:00	0.5	1.5	2	0.65	0.32502	1.08
07/21/2026 10:00	0.3	1.5	3	0.66	0.33114	1.10
07/21/2026 11:00	0.2	1.5	4	0.71	0.35466	1.18
07/21/2026 12:00	0.2	1.5	5	0.78	0.39096	1.30
07/21/2026 13:00	0.2	1.5	4	0.77	0.38502	1.28
07/21/2026 14:00	0.2	1.5	5	0.77	0.38748	1.29
07/21/2026 15:00	0.2	1.5	6	0.79	0.39306	1.31
07/21/2026 16:00	0.1	1.5	5	0.77	0.38550	1.29
07/21/2026 17:00	0.2	1.5	6	0.78	0.39102	1.30
07/21/2026 18:00	0.2	1.5	6	0.80	0.39852	1.33
07/21/2026 19:00	0.1	1.5	6	0.80	0.39774	1.33
07/21/2026 20:00	0.1	1.5	6	0.79	0.39456	1.32
07/21/2026 21:00	0.1	1.5	5	0.78	0.38790	1.29
07/21/2026 22:00	0.2	1.5	4	0.76	0.38022	1.27
07/21/2026 23:00	0.3	1.5	3	0.74	0.37188	1.24
Average/Sum#:	0.4	1.5	3	0.72	0.36069	1.20
Minimum:	0.1	1.5	1	0.63	0.31686	1.06
Maximum:	0.9	1.5	6	0.80	0.39852	1.33
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/22/2026 00:00	0.9	1.5	1	0.63	0.31512	1.05
07/22/2026 01:00	0.9	1.5	1	0.63	0.31494	1.05
07/22/2026 02:00	0.9	1.5	0	0.63	0.31464	1.05
07/22/2026 03:00	1.0	1.5	0	0.63	0.31392	1.05
07/22/2026 04:00	1.0	1.5	0	0.63	0.31698	1.06
07/22/2026 05:00	0.7	1.5	1	0.67	0.33372	1.11
07/22/2026 06:00	1.0	1.5	1	0.63	0.31350	1.05
07/22/2026 07:00	0.9	1.5	1	0.64	0.32052	1.07
07/22/2026 08:00	0.5	1.5	2	0.69	0.34290	1.14
07/22/2026 09:00	0.9	1.5	1	0.63	0.31392	1.05
07/22/2026 10:00	0.8	1.5	1	0.63	0.31488	1.05
07/22/2026 11:00	0.8	1.5	1	0.63	0.31632	1.05
07/22/2026 12:00	0.7	1.5	1	0.64	0.31770	1.06
07/22/2026 13:00	0.6	1.5	1	0.64	0.31920	1.06
07/22/2026 14:00	0.5	1.5	2	0.64	0.32040	1.07
07/22/2026 15:00	0.5	1.5	2	0.64	0.32010	1.07
07/22/2026 16:00	0.4	1.5	2	0.64	0.32070	1.07
07/22/2026 17:00	0.5	1.5	1	0.64	0.31944	1.06
07/22/2026 18:00	0.6	1.5	1	0.63	0.31692	1.06
07/22/2026 19:00	0.8	1.5	1	0.63	0.31446	1.05
07/22/2026 20:00	1.0	1.5	1	0.62	0.31236	1.04
07/22/2026 21:00	1.1	1.5	0	0.62	0.31122	1.04
07/22/2026 22:00	1.4	1.5	0	0.62	0.31080	1.04
07/22/2026 23:00	1.4	1.5	0	0.62	0.31002	1.03
Average/Sum#:	0.8	1.5	1	0.64	0.31770	1.06
Minimum:	0.4	1.5	0	0.62	0.31002	1.03
Maximum:	1.4	1.5	2	0.69	0.34290	1.14
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/23/2026 00:00	1.4	1.5	0	0.62	0.31008	1.03
07/23/2026 01:00	1.4	1.5	0	0.62	0.30990	1.03
07/23/2026 02:00	1.5	1.5	-1	0.62	0.30912	1.03
07/23/2026 03:00	1.5	1.5	-1	0.62	0.30918	1.03
07/23/2026 04:00	1.5	1.5	-1	0.62	0.30954	1.03
07/23/2026 05:00	1.5	1.5	0	0.62	0.30966	1.03
07/23/2026 06:00	1.5	1.5	0	0.62	0.31140	1.04
07/23/2026 07:00	1.4	1.5	0	0.62	0.31224	1.04
07/23/2026 08:00	1.4	1.5	0	0.60	0.30108	1.00
07/23/2026 09:00	0.9	1.5	-1	0.45	0.22704	0.76
07/23/2026 10:00	0.9	1.5	-1	0.45	0.22536	0.75
07/23/2026 11:00	0.8	1.6	0	0.56	0.27840	0.93
07/23/2026 12:00	0.6	1.5	1	0.64	0.32016	1.07
07/23/2026 13:00	0.5	1.5	2	0.64	0.32238	1.07
07/23/2026 14:00	0.4	1.5	2	0.65	0.32358	1.08
07/23/2026 15:00	0.3	1.5	2	0.65	0.32496	1.08
07/23/2026 16:00	0.3	1.5	2	0.65	0.32544	1.08
07/23/2026 17:00	0.2	1.5	2	0.65	0.32628	1.09
07/23/2026 18:00	0.2	1.5	3	0.67	0.33660	1.12
07/23/2026 19:00	0.5	1.5	1	0.64	0.32232	1.07
07/23/2026 20:00	0.6	1.5	2	0.66	0.33198	1.11
07/23/2026 21:00	0.9	1.5	1	0.64	0.31758	1.06
07/23/2026 22:00	0.9	1.5	1	0.64	0.31806	1.06
07/23/2026 23:00	1.2	1.5	0	0.64	0.31932	1.06
Average/Sum#:	0.9	1.5	1	0.62	0.30840	1.03
Minimum:	0.2	1.5	-1	0.45	0.22536	0.75
Maximum:	1.5	1.6	3	0.67	0.33660	1.12
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/24/2026 00:00	1.4	1.5	0	0.63	0.31326	1.04
07/24/2026 01:00	1.4	1.5	0	0.63	0.31314	1.04
07/24/2026 02:00	1.4	1.5	0	0.63	0.31314	1.04
07/24/2026 03:00	1.4	1.5	0	0.62	0.31248	1.04
07/24/2026 04:00	1.5	1.5	0	0.62	0.31140	1.04
07/24/2026 05:00	1.5	1.5	0	0.62	0.31128	1.04
07/24/2026 06:00	1.4	1.5	0	0.63	0.31290	1.04
07/24/2026 07:00	1.4	1.5	1	0.63	0.31410	1.05
07/24/2026 08:00	1.1	1.5	1	0.63	0.31572	1.05
07/24/2026 09:00	0.9	1.5	1	0.63	0.31722	1.06
07/24/2026 10:00	0.7	1.5	1	0.64	0.31878	1.06
07/24/2026 11:00	0.9	1.5	-1	0.46	0.22980	0.77
07/24/2026 12:00	0.7	1.5	1	0.61	0.30354	1.01
07/24/2026 13:00	0.2	1.5	4	0.72	0.36174	1.21
07/24/2026 14:00	0.1	1.5	6	0.79	0.39354	1.31
07/24/2026 15:00	0.1	1.5	6	0.78	0.39186	1.31
07/24/2026 16:00	0.3	1.5	2	0.71	0.35562	1.19
07/24/2026 17:00	0.3	1.6	3	0.73	0.36450	1.22
07/24/2026 18:00	0.2	1.5	3	0.74	0.37242	1.24
07/24/2026 19:00	0.8	1.5	1	0.66	0.33168	1.11
07/24/2026 20:00	0.8	1.5	1	0.67	0.33348	1.11
07/24/2026 21:00	1.2	1.5	1	0.64	0.32202	1.07
07/24/2026 22:00	1.5	1.5	0	0.63	0.31254	1.04
07/24/2026 23:00	1.4	1.5	0	0.63	0.31332	1.04
Average/Sum#:	0.9	1.5	1	0.65	0.32665	1.09
Minimum:	0.1	1.5	-1	0.46	0.22980	0.77
Maximum:	1.5	1.6	6	0.79	0.39354	1.31
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/25/2026 00:00	1.4	1.5	0	0.63	0.31302	1.04
07/25/2026 01:00	1.4	1.5	0	0.62	0.31248	1.04
07/25/2026 02:00	1.4	1.5	-1	0.62	0.31230	1.04
07/25/2026 03:00	1.4	1.5	-1	0.62	0.31224	1.04
07/25/2026 04:00	1.5	1.5	-1	0.62	0.31170	1.04
07/25/2026 05:00	1.7	1.5	0	0.62	0.31092	1.04
07/25/2026 06:00	1.5	1.5	0	0.62	0.31200	1.04
07/25/2026 07:00	1.4	1.5	0	0.63	0.31416	1.05
07/25/2026 08:00	1.2	1.5	1	0.63	0.31572	1.05
07/25/2026 09:00	0.9	1.5	1	0.64	0.31782	1.06
07/25/2026 10:00	0.7	1.5	1	0.64	0.31968	1.07
07/25/2026 11:00	0.6	1.5	1	0.65	0.32280	1.08
07/25/2026 12:00	0.4	1.5	2	0.65	0.32622	1.09
07/25/2026 13:00	0.2	1.5	2	0.66	0.32778	1.09
07/25/2026 14:00	0.2	1.5	3	0.66	0.32892	1.10
07/25/2026 15:00	0.1	1.5	4	0.66	0.32958	1.10
07/25/2026 16:00	0.1	1.5	4	0.66	0.33090	1.10
07/25/2026 17:00	0.1	1.5	3	0.66	0.33084	1.10
07/25/2026 18:00	0.2	1.5	2	0.65	0.32622	1.09
07/25/2026 19:00	0.5	1.5	1	0.64	0.32118	1.07
07/25/2026 20:00	0.7	1.5	1	0.64	0.31830	1.06
07/25/2026 21:00	0.8	1.5	1	0.63	0.31680	1.06
07/25/2026 22:00	0.9	1.5	1	0.63	0.31590	1.05
07/25/2026 23:00	0.9	1.5	1	0.63	0.31494	1.05
Average/Sum#:	0.8	1.5	1	0.64	0.31927	1.06
Minimum:	0.1	1.5	-1	0.62	0.31092	1.04
Maximum:	1.7	1.5	4	0.66	0.33090	1.10
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/26/2026 00:00	1.0	1.5	0	0.63	0.31458	1.05
07/26/2026 01:00	1.1	1.5	0	0.63	0.31380	1.05
07/26/2026 02:00	1.2	1.5	0	0.63	0.31260	1.04
07/26/2026 03:00	1.3	1.5	0	0.62	0.31164	1.04
07/26/2026 04:00	1.4	1.5	0	0.62	0.31194	1.04
07/26/2026 05:00	1.6	1.5	0	0.62	0.31230	1.04
07/26/2026 06:00	1.5	1.5	0	0.63	0.31308	1.04
07/26/2026 07:00	0.9	1.5	-1	0.46	0.22992	0.77
07/26/2026 08:00	0.9	1.5	0	0.56	0.28194	0.94
07/26/2026 09:00	0.9	1.5	1	0.64	0.31776	1.06
07/26/2026 10:00	0.7	1.5	1	0.64	0.31932	1.06
07/26/2026 11:00	0.6	1.5	1	0.64	0.32010	1.07
07/26/2026 12:00	0.4	1.5	2	0.65	0.32442	1.08
07/26/2026 13:00	0.3	1.5	2	0.65	0.32682	1.09
07/26/2026 14:00	0.2	1.5	3	0.66	0.32826	1.09
07/26/2026 15:00	0.1	1.5	3	0.66	0.32934	1.10
07/26/2026 16:00	0.1	1.5	3	0.66	0.32946	1.10
07/26/2026 17:00	0.1	1.5	3	0.66	0.33024	1.10
07/26/2026 18:00	0.3	1.5	2	0.65	0.32526	1.08
07/26/2026 19:00	0.6	1.5	1	0.64	0.32202	1.07
07/26/2026 20:00	0.7	1.5	1	0.65	0.32280	1.08
07/26/2026 21:00	0.5	1.5	2	0.70	0.34950	1.17
07/26/2026 22:00	0.5	1.5	2	0.70	0.34764	1.16
07/26/2026 23:00	1.1	1.5	0	0.63	0.31272	1.04
Average/Sum#:	0.8	1.5	1	0.63	0.31698	1.06
Minimum:	0.1	1.5	-1	0.46	0.22992	0.77
Maximum:	1.6	1.5	3	0.70	0.34950	1.17
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/27/2026 00:00	1.1	1.5	0	0.64	0.32208	1.07
07/27/2026 01:00	1.4	1.5	0	0.62	0.31104	1.04
07/27/2026 02:00	1.4	1.5	-1	0.62	0.31056	1.04
07/27/2026 03:00	1.4	1.5	-1	0.62	0.31062	1.04
07/27/2026 04:00	1.4	1.5	0	0.62	0.30990	1.03
07/27/2026 05:00	1.5	1.5	0	0.62	0.30978	1.03
07/27/2026 06:00	1.4	1.5	0	0.62	0.31110	1.04
07/27/2026 07:00	1.4	1.5	0	0.62	0.31242	1.04
07/27/2026 08:00	1.1	1.5	-1	0.63	0.31398	1.05
07/27/2026 09:00	1.0	1.5	1	0.63	0.31518	1.05
07/27/2026 10:00	0.8	1.4	0	0.63	0.31662	1.06
07/27/2026 11:00	0.7	1.5	1	0.64	0.31896	1.06
07/27/2026 12:00	0.5	1.5	2	0.64	0.32226	1.07
07/27/2026 13:00	0.3	1.5	2	0.65	0.32520	1.08
07/27/2026 14:00	0.2	1.5	3	0.65	0.32640	1.09
07/27/2026 15:00	0.2	1.5	3	0.65	0.32694	1.09
07/27/2026 16:00	0.2	1.5	3	0.66	0.32868	1.10
07/27/2026 17:00	0.2	1.4	2	0.66	0.33138	1.10
07/27/2026 18:00	0.5	1.5	2	0.70	0.35076	1.17
07/27/2026 19:00	0.4	1.5	2	0.71	0.35550	1.19
07/27/2026 20:00	0.7	1.5	1	0.67	0.33654	1.12
07/27/2026 21:00	1.0	1.5	1	0.63	0.31632	1.05
07/27/2026 22:00	1.0	1.5	1	0.63	0.31464	1.05
07/27/2026 23:00	1.1	1.5	0	0.63	0.31386	1.05
Average/Sum#:	0.9	1.5	1	0.64	0.32128	1.07
Minimum:	0.2	1.4	-1	0.62	0.30978	1.03
Maximum:	1.5	1.5	3	0.71	0.35550	1.19
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/28/2026 00:00	1.2	1.5	0	0.63	0.31362	1.05
07/28/2026 01:00	1.2	1.5	0	0.63	0.31278	1.04
07/28/2026 02:00	1.3	1.5	0	0.63	0.31254	1.04
07/28/2026 03:00	1.5	1.5	0	0.62	0.31182	1.04
07/28/2026 04:00	1.5	1.5	0	0.62	0.31200	1.04
07/28/2026 05:00	1.5	1.5	0	0.62	0.31140	1.04
07/28/2026 06:00	1.5	1.5	0	0.62	0.31218	1.04
07/28/2026 07:00	1.0	1.5	-1	0.51	0.25716	0.86
07/28/2026 08:00	0.9	1.5	-1	0.45	0.22626	0.75
07/28/2026 09:00	0.8	1.5	-1	0.45	0.22608	0.75
07/28/2026 10:00	0.8	1.5	-1	0.45	0.22560	0.75
07/28/2026 11:00	0.8	1.5	-1	0.49	0.24420	0.81
07/28/2026 12:00	0.7	1.5	0	0.61	0.30528	1.02
07/28/2026 13:00	0.8	1.5	-1	0.45	0.22614	0.75
07/28/2026 14:00	0.8	1.5	-1	0.45	0.22494	0.75
07/28/2026 15:00	0.8	1.5	-1	0.49	0.24342	0.81
07/28/2026 16:00	0.8	1.5	1	0.64	0.31938	1.06
07/28/2026 17:00	0.8	1.5	1	0.64	0.32028	1.07
07/28/2026 18:00	0.4	1.5	2	0.65	0.32574	1.09
07/28/2026 19:00	0.5	1.5	1	0.64	0.32226	1.07
07/28/2026 20:00	0.7	1.5	1	0.64	0.31932	1.06
07/28/2026 21:00	0.7	1.5	1	0.64	0.31956	1.07
07/28/2026 22:00	0.8	1.5	1	0.63	0.31710	1.06
07/28/2026 23:00	0.9	1.5	-1	0.46	0.23154	0.77
Average/Sum#:	0.9	1.5	0	0.57	0.28503	0.95
Minimum:	0.4	1.5	-1	0.45	0.22494	0.75
Maximum:	1.5	1.5	2	0.65	0.32574	1.09
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/29/2026 00:00	0.8	1.5	-1	0.45	0.22572	0.75
07/29/2026 01:00	0.8	1.5	-1	0.45	0.22572	0.75
07/29/2026 02:00	0.8	1.6	-1	0.45	0.22596	0.75
07/29/2026 03:00	0.8	1.5	-1	0.45	0.22602	0.75
07/29/2026 04:00	0.8	1.5	-1	0.45	0.22608	0.75
07/29/2026 05:00	0.9	1.5	-1	0.45	0.22596	0.75
07/29/2026 06:00	0.9	1.5	-1	0.45	0.22596	0.75
07/29/2026 07:00	0.8	1.5	-1	0.45	0.22590	0.75
07/29/2026 08:00	0.8	1.5	-1	0.45	0.22560	0.75
07/29/2026 09:00	0.8	1.5	-1	0.45	0.22548	0.75
07/29/2026 10:00	0.8	1.5	-1	0.48	0.24120	0.80
07/29/2026 11:00	0.6	1.6	1	0.65	0.32376	1.08
07/29/2026 12:00	0.3	1.5	2	0.65	0.32634	1.09
07/29/2026 13:00	0.2	1.5	3	0.66	0.33018	1.10
07/29/2026 14:00	0.1	1.5	3	0.66	0.33060	1.10
07/29/2026 15:00	0.1	1.5	4	0.66	0.33180	1.11
07/29/2026 16:00	0.1	1.5	4	0.66	0.33192	1.11
07/29/2026 17:00	0.1	1.5	4	0.67	0.33516	1.12
07/29/2026 18:00	0.1	1.5	3	0.67	0.33672	1.12
07/29/2026 19:00	0.3	1.5	2	0.66	0.32856	1.10
07/29/2026 20:00	0.5	1.5	1	0.64	0.32154	1.07
07/29/2026 21:00	0.8	1.5	-1	0.46	0.23136	0.77
07/29/2026 22:00	0.8	1.5	-1	0.45	0.22542	0.75
07/29/2026 23:00	0.8	1.5	-1	0.45	0.22554	0.75
Average/Sum#:	0.6	1.5	1	0.54	0.26994	0.90
Minimum:	0.1	1.5	-1	0.45	0.22542	0.75
Maximum:	0.9	1.6	4	0.67	0.33672	1.12
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/30/2026 00:00	0.8	1.5	-1	0.45	0.22590	0.75
07/30/2026 01:00	0.8	1.5	-1	0.45	0.22602	0.75
07/30/2026 02:00	0.8	1.6	-1	0.45	0.22608	0.75
07/30/2026 03:00	0.9	1.5	-1	0.45	0.22602	0.75
07/30/2026 04:00	0.9	1.5	-2	0.45	0.22608	0.75
07/30/2026 05:00	0.8	1.5	-1	0.45	0.22608	0.75
07/30/2026 06:00	0.8	1.5	-1	0.45	0.22590	0.75
07/30/2026 07:00	0.8	1.5	-1	0.45	0.22566	0.75
07/30/2026 08:00	0.8	1.5	-1	0.45	0.22530	0.75
07/30/2026 09:00	0.8	1.5	-1	0.45	0.22512	0.75
07/30/2026 10:00	0.8	1.5	-1	0.45	0.22476	0.75
07/30/2026 11:00	0.8	1.5	-1	0.45	0.22452	0.75
07/30/2026 12:00	0.8	1.5	-1	0.45	0.22440	0.75
07/30/2026 13:00	0.8	1.5	-1	0.45	0.22422	0.75
07/30/2026 14:00	0.7	1.5	0	0.51	0.25290	0.84
07/30/2026 15:00	0.7	1.5	-1	0.47	0.23688	0.79
07/30/2026 16:00	0.7	1.5	-1	0.47	0.23358	0.78
07/30/2026 17:00	0.7	1.5	-1	0.51	0.25434	0.85
07/30/2026 18:00	0.7	1.5	-1	0.55	0.27492	0.92
07/30/2026 19:00	0.8	1.5	-1	0.47	0.23628	0.79
07/30/2026 20:00	0.8	1.5	-1	0.45	0.22464	0.75
07/30/2026 21:00	0.8	1.5	-1	0.46	0.22968	0.77
07/30/2026 22:00	0.8	1.5	-1	0.47	0.23658	0.79
07/30/2026 23:00	0.8	1.5	-1	0.45	0.22638	0.75
Average/Sum#:	0.8	1.5	-1	0.46	0.23176	0.77
Minimum:	0.7	1.5	-2	0.45	0.22422	0.75
Maximum:	0.9	1.6	0	0.55	0.27492	0.92
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
07/31/2026 00:00	0.8	1.5	-1	0.45	0.22536	0.75
07/31/2026 01:00	0.9	1.5	-1	0.45	0.22560	0.75
07/31/2026 02:00	0.8	1.5	-2	0.45	0.22578	0.75
07/31/2026 03:00	0.9	1.5	-2	0.45	0.22602	0.75
07/31/2026 04:00	0.9	1.5	-2	0.48	0.23826	0.79
07/31/2026 05:00	0.9	1.5	-2	0.45	0.22644	0.75
07/31/2026 06:00	0.9	1.5	-1	0.45	0.22626	0.75
07/31/2026 07:00	0.9	1.5	-1	0.45	0.22626	0.75
07/31/2026 08:00	0.8	1.5	-1	0.45	0.22602	0.75
07/31/2026 09:00	0.8	1.5	-1	0.45	0.22566	0.75
07/31/2026 10:00	0.8	1.5	-1	0.45	0.22524	0.75
07/31/2026 11:00	0.8	1.5	-1	0.47	0.23382	0.78
07/31/2026 12:00	0.7	1.5	-1	0.56	0.27762	0.93
07/31/2026 13:00	0.7	1.5	-1	0.55	0.27690	0.92
07/31/2026 14:00	0.7	1.5	0	0.56	0.27936	0.93
07/31/2026 15:00	0.7	1.5	1	0.67	0.33270	1.11
07/31/2026 16:00	0.5	1.5	2	0.70	0.34824	1.16
07/31/2026 17:00	0.3	1.5	3	0.74	0.36864	1.23
07/31/2026 18:00	0.1	1.5	5	0.79	0.39564	1.32
07/31/2026 19:00	0.8	1.5	1	0.65	0.32682	1.09
07/31/2026 20:00	0.6	1.5	1	0.64	0.32076	1.07
07/31/2026 21:00	0.6	1.5	1	0.64	0.32016	1.07
07/31/2026 22:00	0.8	1.5	1	0.63	0.31716	1.06
07/31/2026 23:00	0.9	1.5	-1	0.46	0.23154	0.77
Average/Sum#:	0.7	1.5	0	0.54	0.27193	0.91
Minimum:	0.1	1.5	-2	0.45	0.22524	0.75
Maximum:	0.9	1.5	5	0.79	0.39564	1.32
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/01/2026 00:00	0.8	1.5	-1	0.45	0.22614	0.75
08/01/2026 01:00	0.8	1.5	-1	0.45	0.22578	0.75
08/01/2026 02:00	0.8	1.5	-2	0.45	0.22596	0.75
08/01/2026 03:00	0.9	1.5	-2	0.45	0.22608	0.75
08/01/2026 04:00	0.9	1.5	-2	0.45	0.22632	0.75
08/01/2026 05:00	0.9	1.5	-2	0.45	0.22626	0.75
08/01/2026 06:00	0.9	1.5	-1	0.45	0.22644	0.75
08/01/2026 07:00	0.8	1.5	-1	0.45	0.22602	0.75
08/01/2026 08:00	0.8	1.5	-1	0.45	0.22572	0.75
08/01/2026 09:00	0.8	1.5	-1	0.45	0.22518	0.75
08/01/2026 10:00	0.8	1.5	-1	0.45	0.22512	0.75
08/01/2026 11:00	0.8	1.5	-1	0.45	0.22512	0.75
08/01/2026 12:00	0.8	1.5	-1	0.45	0.22458	0.75
08/01/2026 13:00	0.8	1.5	-1	0.45	0.22374	0.75
08/01/2026 14:00	0.8	1.5	0	0.48	0.24006	0.80
08/01/2026 15:00	0.9	1.5	2	0.64	0.31926	1.06
08/01/2026 16:00	0.6	1.5	2	0.65	0.32340	1.08
08/01/2026 17:00	0.4	1.5	2	0.71	0.35532	1.18
08/01/2026 18:00	0.2	1.5	6	0.79	0.39258	1.31
08/01/2026 19:00	0.3	1.5	3	0.73	0.36696	1.22
08/01/2026 20:00	1.0	1.5	1	0.63	0.31554	1.05
08/01/2026 21:00	0.5	1.5	2	0.65	0.32496	1.08
08/01/2026 22:00	0.6	1.5	1	0.65	0.32322	1.08
08/01/2026 23:00	0.8	1.5	-1	0.52	0.25812	0.86
Average/Sum#:	0.7	1.5	0	0.53	0.26575	0.88
Minimum:	0.2	1.5	-2	0.45	0.22374	0.75
Maximum:	1.0	1.5	6	0.79	0.39258	1.31
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/02/2026 00:00	0.8	1.5	-1	0.45	0.22710	0.76
08/02/2026 01:00	0.9	1.5	-1	0.45	0.22488	0.75
08/02/2026 02:00	0.8	1.5	-1	0.45	0.22512	0.75
08/02/2026 03:00	0.9	1.5	-1	0.45	0.22536	0.75
08/02/2026 04:00	0.9	1.5	-1	0.45	0.22524	0.75
08/02/2026 05:00	1.0	1.5	-1	0.45	0.22548	0.75
08/02/2026 06:00	1.0	1.5	-1	0.45	0.22536	0.75
08/02/2026 07:00	0.9	1.5	-1	0.45	0.22482	0.75
08/02/2026 08:00	0.8	1.5	-1	0.45	0.22422	0.75
08/02/2026 09:00	0.8	1.5	-1	0.45	0.22386	0.75
08/02/2026 10:00	0.8	1.5	-1	0.45	0.22392	0.75
08/02/2026 11:00	0.8	1.5	-1	0.45	0.22338	0.74
08/02/2026 12:00	0.8	1.5	-1	0.45	0.22284	0.74
08/02/2026 13:00	0.7	1.5	-1	0.48	0.24000	0.80
08/02/2026 14:00	0.9	1.5	1	0.63	0.31716	1.06
08/02/2026 15:00	0.9	1.5	1	0.63	0.31686	1.06
08/02/2026 16:00	0.6	1.5	1	0.66	0.33216	1.11
08/02/2026 17:00	0.7	1.5	1	0.64	0.32196	1.07
08/02/2026 18:00	0.8	1.5	1	0.64	0.32004	1.07
08/02/2026 19:00	0.1	1.5	3	0.66	0.33036	1.10
08/02/2026 20:00	0.2	1.5	2	0.65	0.32748	1.09
08/02/2026 21:00	0.3	1.5	2	0.65	0.32598	1.09
08/02/2026 22:00	1.7	1.5	0	0.55	0.27642	0.92
08/02/2026 23:00	1.4	1.5	0	0.53	0.26436	0.88
Average/Sum#:	0.8	1.5	0	0.52	0.26227	0.87
Minimum:	0.1	1.5	-1	0.45	0.22284	0.74
Maximum:	1.7	1.5	3	0.66	0.33216	1.11
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/03/2026 00:00	0.9	1.5	-1	0.45	0.22470	0.75
08/03/2026 01:00	0.8	1.5	-1	0.49	0.24318	0.81
08/03/2026 02:00	0.9	1.5	-1	0.45	0.22434	0.75
08/03/2026 03:00	0.9	1.5	-1	0.45	0.22446	0.75
08/03/2026 04:00	0.8	1.5	-1	0.52	0.25842	0.86
08/03/2026 05:00	0.9	1.5	-1	0.50	0.25128	0.84
08/03/2026 06:00	1.0	1.5	-1	0.45	0.22500	0.75
08/03/2026 07:00	0.9	1.5	-1	0.45	0.22434	0.75
08/03/2026 08:00	0.9	1.5	-1	0.45	0.22392	0.75
08/03/2026 09:00	0.8	1.5	-1	0.45	0.22374	0.75
08/03/2026 10:00	0.8	1.5	-1	0.45	0.22368	0.75
08/03/2026 11:00	0.8	1.5	-1	0.45	0.22302	0.74
08/03/2026 12:00	0.8	1.5	-1	0.49	0.24318	0.81
08/03/2026 13:00	0.7	1.5	-1	0.51	0.25416	0.85
08/03/2026 14:00	0.7	1.5	1	0.65	0.32592	1.09
08/03/2026 15:00	0.7	1.5	1	0.64	0.32172	1.07
08/03/2026 16:00	0.4	1.5	3	0.70	0.34920	1.16
08/03/2026 17:00	0.4	1.5	3	0.71	0.35730	1.19
08/03/2026 18:00	0.2	1.5	7	0.80	0.39948	1.33
08/03/2026 19:00	0.2	1.5	5	0.77	0.38322	1.28
08/03/2026 20:00	0.3	1.5	3	0.74	0.36852	1.23
08/03/2026 21:00	0.5	1.5	2	0.67	0.33456	1.12
08/03/2026 22:00	1.1	1.5	-1	0.52	0.25902	0.86
08/03/2026 23:00	0.7	1.5	0	0.54	0.26964	0.90
Average/Sum#:	0.7	1.5	0	0.55	0.27650	0.92
Minimum:	0.2	1.5	-1	0.45	0.22302	0.74
Maximum:	1.1	1.5	7	0.80	0.39948	1.33
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/04/2026 00:00	0.9	1.5	-1	0.47	0.23478	0.78
08/04/2026 01:00	0.9	1.5	-1	0.45	0.22470	0.75
08/04/2026 02:00	0.9	1.5	-1	0.45	0.22488	0.75
08/04/2026 03:00	0.8	1.5	-1	0.47	0.23676	0.79
08/04/2026 04:00	0.8	1.5	-1	0.52	0.26046	0.87
08/04/2026 05:00	0.8	1.5	-1	0.50	0.25110	0.84
08/04/2026 06:00	0.8	1.5	-1	0.48	0.24228	0.81
08/04/2026 07:00	0.9	1.5	-1	0.45	0.22476	0.75
08/04/2026 08:00	0.8	1.5	-1	0.45	0.22458	0.75
08/04/2026 09:00	0.8	1.5	-1	0.45	0.22452	0.75
08/04/2026 10:00	0.8	1.5	-1	0.45	0.22584	0.75
08/04/2026 11:00	0.8	1.5	-1	0.47	0.23718	0.79
08/04/2026 12:00	0.7	1.5	-1	0.51	0.25722	0.86
08/04/2026 13:00	0.7	1.5	-1	0.54	0.27198	0.91
08/04/2026 14:00	0.6	1.5	2	0.68	0.33858	1.13
08/04/2026 15:00	0.4	1.5	3	0.69	0.34614	1.15
08/04/2026 16:00	0.5	1.5	1	0.67	0.33564	1.12
08/04/2026 17:00	0.5	1.4	2	0.65	0.32520	1.08
08/04/2026 18:00	0.2	1.5	4	0.75	0.37512	1.25
08/04/2026 19:00	0.9	1.5	0	0.63	0.31542	1.05
08/04/2026 20:00	0.8	1.5	1	0.64	0.31980	1.07
08/04/2026 21:00	0.6	1.5	1	0.64	0.32112	1.07
08/04/2026 22:00	0.8	1.5	-1	0.46	0.23178	0.77
08/04/2026 23:00	0.7	1.5	-1	0.54	0.26868	0.90
Average/Sum#:	0.7	1.5	0	0.54	0.27161	0.91
Minimum:	0.2	1.4	-1	0.45	0.22452	0.75
Maximum:	0.9	1.5	4	0.75	0.37512	1.25
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/05/2026 00:00	0.8	1.5	-1	0.51	0.25332	0.84
08/05/2026 01:00	0.9	1.5	-1	0.45	0.22620	0.75
08/05/2026 02:00	0.9	1.5	-2	0.45	0.22638	0.75
08/05/2026 03:00	0.9	1.5	-1	0.45	0.22644	0.75
08/05/2026 04:00	0.8	1.5	-2	0.46	0.23004	0.77
08/05/2026 05:00	0.8	1.5	-2	0.45	0.22668	0.76
08/05/2026 06:00	0.8	1.5	-1	0.47	0.23574	0.79
08/05/2026 07:00	0.9	1.5	-1	0.45	0.22638	0.75
08/05/2026 08:00	0.8	1.5	-1	0.45	0.22626	0.75
08/05/2026 09:00	0.8	1.5	-1	0.45	0.22602	0.75
08/05/2026 10:00	0.8	1.5	-1	0.45	0.22566	0.75
08/05/2026 11:00	0.8	1.5	-1	0.45	0.22530	0.75
08/05/2026 12:00	0.8	1.5	-1	0.47	0.23514	0.78
08/05/2026 13:00	0.7	1.5	-1	0.49	0.24444	0.81
08/05/2026 14:00	1.1	1.5	1	0.63	0.31404	1.05
08/05/2026 15:00	0.9	1.5	1	0.64	0.31986	1.07
08/05/2026 16:00	0.6	1.5	2	0.69	0.34680	1.16
08/05/2026 17:00	0.6	1.5	1	0.67	0.33576	1.12
08/05/2026 18:00	0.9	1.5	1	0.64	0.31812	1.06
08/05/2026 19:00	0.7	1.5	1	0.64	0.32130	1.07
08/05/2026 20:00	0.6	1.5	1	0.65	0.32316	1.08
08/05/2026 21:00	0.7	1.5	1	0.64	0.31860	1.06
08/05/2026 22:00	0.8	1.5	0	0.55	0.27468	0.92
08/05/2026 23:00	0.7	1.5	-1	0.53	0.26484	0.88
Average/Sum#:	0.8	1.5	0	0.53	0.26547	0.88
Minimum:	0.6	1.5	-2	0.45	0.22530	0.75
Maximum:	1.1	1.5	2	0.69	0.34680	1.16
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/06/2026 00:00	0.8	1.5	-1	0.47	0.23406	0.78
08/06/2026 01:00	0.8	1.5	-1	0.45	0.22536	0.75
08/06/2026 02:00	0.8	1.5	-1	0.45	0.22542	0.75
08/06/2026 03:00	0.9	1.5	-1	0.45	0.22554	0.75
08/06/2026 04:00	0.8	1.5	-2	0.46	0.22824	0.76
08/06/2026 05:00	0.8	1.5	-1	0.48	0.23910	0.80
08/06/2026 06:00	0.9	1.5	-1	0.45	0.22602	0.75
08/06/2026 07:00	0.9	1.5	-1	0.45	0.22572	0.75
08/06/2026 08:00	0.8	1.5	-1	0.45	0.22554	0.75
08/06/2026 09:00	0.8	1.5	-1	0.45	0.22524	0.75
08/06/2026 10:00	0.8	1.5	-1	0.45	0.22488	0.75
08/06/2026 11:00	0.8	1.5	-1	0.45	0.22440	0.75
08/06/2026 12:00	0.8	1.5	-1	0.45	0.22416	0.75
08/06/2026 13:00	0.8	1.5	-1	0.47	0.23586	0.79
08/06/2026 14:00	0.3	1.5	3	0.65	0.32394	1.08
08/06/2026 15:00	0.1	1.5	5	0.66	0.33168	1.11
08/06/2026 16:00	0.1	1.5	5	0.69	0.34338	1.14
08/06/2026 17:00	0.1	1.5	5	0.77	0.38670	1.29
08/06/2026 18:00	0.3	1.5	3	0.75	0.37284	1.24
08/06/2026 19:00	0.9	1.5	1	0.64	0.32052	1.07
08/06/2026 20:00	0.5	1.5	2	0.65	0.32658	1.09
08/06/2026 21:00	0.4	1.5	2	0.68	0.33978	1.13
08/06/2026 22:00	0.7	1.5	-1	0.55	0.27480	0.92
08/06/2026 23:00	0.7	1.5	0	0.55	0.27402	0.91
Average/Sum#:	0.7	1.5	0	0.54	0.27016	0.90
Minimum:	0.1	1.5	-2	0.45	0.22416	0.75
Maximum:	0.9	1.5	5	0.77	0.38670	1.29
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/07/2026 00:00	0.7	1.5	-1	0.55	0.27366	0.91
08/07/2026 01:00	0.7	1.5	-1	0.55	0.27414	0.91
08/07/2026 02:00	0.7	1.5	-1	0.55	0.27420	0.91
08/07/2026 03:00	0.8	1.5	-1	0.48	0.24060	0.80
08/07/2026 04:00	0.7	1.5	-1	0.54	0.27216	0.91
08/07/2026 05:00	0.7	1.5	-1	0.55	0.27396	0.91
08/07/2026 06:00	0.8	1.5	-1	0.48	0.23892	0.80
08/07/2026 07:00	0.9	1.5	-1	0.45	0.22608	0.75
08/07/2026 08:00	0.8	1.5	-1	0.45	0.22566	0.75
08/07/2026 09:00	0.8	1.5	-1	0.45	0.22536	0.75
08/07/2026 10:00	0.8	1.5	-1	0.45	0.22494	0.75
08/07/2026 11:00	0.7	1.5	-1	0.49	0.24300	0.81
08/07/2026 12:00	0.8	1.5	-1	0.46	0.23226	0.77
08/07/2026 13:00	0.7	1.5	-1	0.53	0.26256	0.88
08/07/2026 14:00	0.6	1.5	3	0.66	0.32784	1.09
08/07/2026 15:00	0.1	1.5	6	0.67	0.33582	1.12
08/07/2026 16:00	0.1	1.5	5	0.68	0.33774	1.13
08/07/2026 17:00	0.5	1.5	1	0.69	0.34494	1.15
08/07/2026 18:00	0.2	1.5	3	0.76	0.37980	1.27
08/07/2026 19:00	0.6	1.5	1	0.67	0.33636	1.12
08/07/2026 20:00	0.9	1.5	1	0.65	0.32622	1.09
08/07/2026 21:00	0.6	1.5	1	0.65	0.32712	1.09
08/07/2026 22:00	0.8	1.5	0	0.55	0.27648	0.92
08/07/2026 23:00	0.7	1.5	0	0.56	0.28194	0.94
Average/Sum#:	0.7	1.5	0	0.56	0.28174	0.94
Minimum:	0.1	1.5	-1	0.45	0.22494	0.75
Maximum:	0.9	1.5	6	0.76	0.37980	1.27
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/08/2026 00:00	0.7	1.5	-1	0.56	0.28194	0.94
08/08/2026 01:00	0.8	1.5	-1	0.49	0.24660	0.82
08/08/2026 02:00	0.8	1.5	-1	0.45	0.22704	0.76
08/08/2026 03:00	0.8	1.5	-1	0.46	0.22776	0.76
08/08/2026 04:00	0.7	1.5	-1	0.54	0.27192	0.91
08/08/2026 05:00	0.8	1.5	-1	0.51	0.25644	0.85
08/08/2026 06:00	0.8	1.5	-1	0.45	0.22746	0.76
08/08/2026 07:00	0.8	1.5	-1	0.45	0.22716	0.76
08/08/2026 08:00	0.8	1.5	-1	0.46	0.22770	0.76
08/08/2026 09:00	0.8	1.5	-1	0.46	0.22794	0.76
08/08/2026 10:00	0.8	1.5	-1	0.45	0.22740	0.76
08/08/2026 11:00	0.8	1.5	-1	0.45	0.22674	0.76
08/08/2026 12:00	0.8	1.5	-1	0.45	0.22608	0.75
08/08/2026 13:00	0.8	1.5	-1	0.48	0.23916	0.80
08/08/2026 14:00	0.1	1.5	4	0.68	0.33786	1.13
08/08/2026 15:00	0.3	1.5	4	0.66	0.33192	1.11
08/08/2026 16:00	0.6	1.5	0	0.65	0.32412	1.08
08/08/2026 17:00	0.6	1.5	1	0.66	0.32916	1.10
08/08/2026 18:00	0.7	1.5	1	0.65	0.32430	1.08
08/08/2026 19:00	0.5	1.5	1	0.65	0.32286	1.08
08/08/2026 20:00	0.6	1.5	1	0.64	0.32166	1.07
08/08/2026 21:00	0.6	1.5	1	0.64	0.32118	1.07
08/08/2026 22:00	0.8	1.5	-1	0.55	0.27606	0.92
08/08/2026 23:00	0.7	1.5	-1	0.52	0.25818	0.86
Average/Sum#:	0.7	1.5	0	0.54	0.27036	0.90
Minimum:	0.1	1.5	-1	0.45	0.22608	0.75
Maximum:	0.8	1.5	4	0.68	0.33786	1.13
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/09/2026 00:00	0.8	1.5	-1	0.45	0.22614	0.75
08/09/2026 01:00	0.8	1.5	-1	0.45	0.22638	0.75
08/09/2026 02:00	0.8	1.5	-1	0.45	0.22656	0.76
08/09/2026 03:00	0.9	1.5	-1	0.45	0.22674	0.76
08/09/2026 04:00	0.8	1.5	-1	0.46	0.22896	0.76
08/09/2026 05:00	0.8	1.5	-1	0.51	0.25524	0.85
08/09/2026 06:00	0.8	1.5	-1	0.45	0.22674	0.76
08/09/2026 07:00	0.8	1.5	-1	0.45	0.22656	0.76
08/09/2026 08:00	0.8	1.5	-1	0.45	0.22608	0.75
08/09/2026 09:00	0.8	1.5	-1	0.45	0.22566	0.75
08/09/2026 10:00	0.8	1.5	-1	0.45	0.22548	0.75
08/09/2026 11:00	0.8	1.5	-1	0.45	0.22500	0.75
08/09/2026 12:00	0.7	1.5	-1	0.46	0.23046	0.77
08/09/2026 13:00	0.7	1.5	-1	0.54	0.26754	0.89
08/09/2026 14:00	0.6	1.5	2	0.65	0.32598	1.09
08/09/2026 15:00	0.1	1.5	4	0.76	0.37980	1.27
08/09/2026 16:00	0.1	1.5	5	0.77	0.38544	1.28
08/09/2026 17:00	0.2	1.5	4	0.75	0.37332	1.24
08/09/2026 18:00	0.2	1.5	4	0.77	0.38334	1.28
08/09/2026 19:00	0.7	1.5	1	0.64	0.32232	1.07
08/09/2026 20:00	0.4	1.5	2	0.65	0.32718	1.09
08/09/2026 21:00	0.6	1.5	1	0.64	0.32160	1.07
08/09/2026 22:00	0.8	1.5	-1	0.47	0.23388	0.78
08/09/2026 23:00	0.8	1.5	-1	0.45	0.22548	0.75
Average/Sum#:	0.7	1.5	0	0.54	0.27175	0.91
Minimum:	0.1	1.5	-1	0.45	0.22500	0.75
Maximum:	0.9	1.5	5	0.77	0.38544	1.28
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/10/2026 00:00	0.8	1.5	-1	0.45	0.22596	0.75
08/10/2026 01:00	0.8	1.5	-1	0.45	0.22614	0.75
08/10/2026 02:00	0.8	1.5	-1	0.45	0.22620	0.75
08/10/2026 03:00	0.8	1.5	-1	0.45	0.22632	0.75
08/10/2026 04:00	0.7	1.5	-1	0.50	0.25122	0.84
08/10/2026 05:00	0.8	1.5	-1	0.45	0.22674	0.76
08/10/2026 06:00	0.8	1.5	-1	0.50	0.24810	0.83
08/10/2026 07:00	0.8	1.5	-1	0.45	0.22644	0.75
08/10/2026 08:00	0.8	1.5	-1	0.45	0.22602	0.75
08/10/2026 09:00	0.8	1.5	-1	0.45	0.22578	0.75
08/10/2026 10:00	0.8	1.5	-1	0.45	0.22572	0.75
08/10/2026 11:00	0.8	1.5	-1	0.45	0.22536	0.75
08/10/2026 12:00	0.8	1.5	-1	0.47	0.23700	0.79
08/10/2026 13:00	0.7	1.5	-1	0.52	0.25848	0.86
08/10/2026 14:00	0.7	1.5	-1	0.50	0.25206	0.84
08/10/2026 15:00	0.8	1.5	1	0.65	0.32436	1.08
08/10/2026 16:00	0.4	1.5	3	0.73	0.36564	1.22
08/10/2026 17:00	0.2	1.5	4	0.77	0.38322	1.28
08/10/2026 18:00	0.2	1.5	3	0.74	0.37200	1.24
08/10/2026 19:00	0.5	1.5	1	0.69	0.34356	1.15
08/10/2026 20:00	0.9	1.5	1	0.65	0.32502	1.08
08/10/2026 21:00	0.7	1.5	1	0.68	0.34074	1.14
08/10/2026 22:00	0.8	1.5	0	0.55	0.27606	0.92
08/10/2026 23:00	0.8	1.5	-1	0.48	0.23988	0.80
Average/Sum#:	0.7	1.5	0	0.54	0.26992	0.90
Minimum:	0.2	1.5	-1	0.45	0.22536	0.75
Maximum:	0.9	1.5	4	0.77	0.38322	1.28
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/11/2026 00:00	0.8	1.5	-1	0.49	0.24396	0.81
08/11/2026 01:00	0.8	1.5	-1	0.45	0.22692	0.76
08/11/2026 02:00	0.8	1.5	-1	0.45	0.22692	0.76
08/11/2026 03:00	0.8	1.5	-1	0.45	0.22722	0.76
08/11/2026 04:00	0.8	1.5	-2	0.46	0.22968	0.77
08/11/2026 05:00	0.8	1.5	-1	0.49	0.24414	0.81
08/11/2026 06:00	0.8	1.5	-1	0.51	0.25362	0.85
08/11/2026 07:00	0.8	1.5	-1	0.45	0.22716	0.76
08/11/2026 08:00	0.8	1.5	-1	0.45	0.22686	0.76
08/11/2026 09:00	0.8	1.5	-1	0.45	0.22674	0.76
08/11/2026 10:00	0.8	1.5	-1	0.47	0.23292	0.78
08/11/2026 11:00	0.7	1.5	-1	0.54	0.27174	0.91
08/11/2026 12:00	0.6	1.5	-1	0.57	0.28380	0.95
08/11/2026 13:00	0.7	1.5	1	0.68	0.33894	1.13
08/11/2026 14:00	0.7	1.5	1	0.66	0.33024	1.10
08/11/2026 15:00	0.8	1.5	1	0.66	0.32766	1.09
08/11/2026 16:00	0.3	1.5	3	0.74	0.37044	1.23
08/11/2026 17:00	0.1	1.5	5	0.79	0.39450	1.32
08/11/2026 18:00	0.2	1.5	3	0.74	0.37200	1.24
08/11/2026 19:00	0.3	1.5	3	0.74	0.37038	1.23
08/11/2026 20:00	0.6	1.5	2	0.70	0.35010	1.17
08/11/2026 21:00	0.7	1.5	-1	0.55	0.27618	0.92
08/11/2026 22:00	0.7	1.5	-1	0.52	0.25812	0.86
08/11/2026 23:00	0.8	1.5	-1	0.46	0.23160	0.77
Average/Sum#:	0.7	1.5	0	0.56	0.28091	0.94
Minimum:	0.1	1.5	-2	0.45	0.22674	0.76
Maximum:	0.8	1.5	5	0.79	0.39450	1.32
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/12/2026 00:00	0.8	1.5	-1	0.45	0.22650	0.76
08/12/2026 01:00	0.8	1.5	-1	0.45	0.22668	0.76
08/12/2026 02:00	0.8	1.5	-1	0.45	0.22674	0.76
08/12/2026 03:00	0.8	1.5	-1	0.45	0.22692	0.76
08/12/2026 04:00	0.8	1.5	-1	0.50	0.24918	0.83
08/12/2026 05:00	0.7	1.5	-1	0.54	0.26958	0.90
08/12/2026 06:00	0.8	1.5	-2	0.45	0.22662	0.76
08/12/2026 07:00	0.8	1.5	-2	0.45	0.22686	0.76
08/12/2026 08:00	0.8	1.5	-1	0.45	0.22656	0.76
08/12/2026 09:00	0.8	1.5	-1	0.45	0.22626	0.75
08/12/2026 10:00	0.8	1.5	-1	0.45	0.22590	0.75
08/12/2026 11:00	0.8	1.5	-2	0.45	0.22566	0.75
08/12/2026 12:00	0.8	1.5	-2	0.46	0.22764	0.76
08/12/2026 13:00	1.0	1.5	0	0.63	0.31632	1.05
08/12/2026 14:00	0.9	1.5	0	0.63	0.31614	1.05
08/12/2026 15:00	1.0	1.5	0	0.63	0.31572	1.05
08/12/2026 16:00	0.9	1.5	0	0.63	0.31572	1.05
08/12/2026 17:00	1.0	1.5	0	0.63	0.31500	1.05
08/12/2026 18:00	1.0	1.5	0	0.63	0.31440	1.05
08/12/2026 19:00	1.1	1.5	1	0.63	0.31302	1.04
08/12/2026 20:00	1.1	1.5	1	0.63	0.31362	1.05
08/12/2026 21:00	0.9	1.5	-1	0.47	0.23664	0.79
08/12/2026 22:00	0.8	1.5	-1	0.45	0.22602	0.75
08/12/2026 23:00	0.8	1.5	-1	0.45	0.22614	0.75
Average/Sum#:	0.9	1.5	-1	0.52	0.25916	0.86
Minimum:	0.7	1.5	-2	0.45	0.22566	0.75
Maximum:	1.1	1.5	1	0.63	0.31632	1.05
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/13/2026 00:00	0.8	1.5	-2	0.45	0.22626	0.75
08/13/2026 01:00	0.8	1.5	-2	0.45	0.22650	0.76
08/13/2026 02:00	0.8	1.5	-2	0.45	0.22686	0.76
08/13/2026 03:00	0.8	1.5	-2	0.45	0.22716	0.76
08/13/2026 04:00	0.8	1.5	-2	0.45	0.22728	0.76
08/13/2026 05:00	0.8	1.5	-2	0.46	0.22758	0.76
08/13/2026 06:00	0.8	1.5	-2	0.46	0.22752	0.76
08/13/2026 07:00	0.8	1.5	-2	0.45	0.22728	0.76
08/13/2026 08:00	0.9	1.5	-1	0.45	0.22722	0.76
08/13/2026 09:00	0.8	1.5	-1	0.45	0.22698	0.76
08/13/2026 10:00	0.8	1.5	-1	0.45	0.22656	0.76
08/13/2026 11:00	0.8	1.5	-1	0.45	0.22620	0.75
08/13/2026 12:00	0.8	1.5	-1	0.49	0.24276	0.81
08/13/2026 13:00	0.9	1.5	0	0.63	0.31596	1.05
08/13/2026 14:00	0.8	1.5	0	0.63	0.31686	1.06
08/13/2026 15:00	0.8	1.5	0	0.63	0.31638	1.05
08/13/2026 16:00	0.9	1.5	0	0.63	0.31518	1.05
08/13/2026 17:00	1.0	1.5	0	0.63	0.31422	1.05
08/13/2026 18:00	1.0	1.5	0	0.63	0.31290	1.04
08/13/2026 19:00	0.9	1.5	-1	0.46	0.22932	0.76
08/13/2026 20:00	0.9	1.5	-1	0.45	0.22686	0.76
08/13/2026 21:00	0.9	1.5	-2	0.45	0.22698	0.76
08/13/2026 22:00	0.9	1.5	-2	0.45	0.22710	0.76
08/13/2026 23:00	0.9	1.5	-2	0.45	0.22710	0.76
Average/Sum#:	0.9	1.5	-1	0.50	0.24979	0.83
Minimum:	0.8	1.5	-2	0.45	0.22620	0.75
Maximum:	1.0	1.5	0	0.63	0.31686	1.06
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/14/2026 00:00	0.9	1.5	-2	0.45	0.22734	0.76
08/14/2026 01:00	0.9	1.5	-2	0.46	0.22752	0.76
08/14/2026 02:00	0.9	1.5	-2	0.46	0.22752	0.76
08/14/2026 03:00	0.9	1.5	-2	0.45	0.22746	0.76
08/14/2026 04:00	0.9	1.5	-2	0.46	0.22752	0.76
08/14/2026 05:00	0.9	1.5	-2	0.46	0.22956	0.77
08/14/2026 06:00	0.9	1.5	-2	0.47	0.23676	0.79
08/14/2026 07:00	0.9	1.5	-2	0.45	0.22740	0.76
08/14/2026 08:00	0.9	1.5	-2	0.45	0.22746	0.76
08/14/2026 09:00	0.9	1.5	-1	0.45	0.22722	0.76
08/14/2026 10:00	0.9	1.5	-1	0.45	0.22704	0.76
08/14/2026 11:00	0.8	1.5	-1	0.45	0.22698	0.76
08/14/2026 12:00	0.8	1.5	-1	0.45	0.22674	0.76
08/14/2026 13:00	0.8	1.5	-2	0.45	0.22656	0.76
08/14/2026 14:00	0.8	1.5	-2	0.45	0.22638	0.75
08/14/2026 15:00	0.8	1.5	-1	0.45	0.22638	0.75
08/14/2026 16:00	0.8	1.5	-1	0.45	0.22632	0.75
08/14/2026 17:00	0.8	1.5	-1	0.48	0.23760	0.79
08/14/2026 18:00	0.8	1.5	-1	0.46	0.22788	0.76
08/14/2026 19:00	0.8	1.5	-1	0.45	0.22704	0.76
08/14/2026 20:00	0.9	1.5	-1	0.46	0.22758	0.76
08/14/2026 21:00	0.9	1.5	-1	0.46	0.22782	0.76
08/14/2026 22:00	0.9	1.5	-2	0.46	0.22812	0.76
08/14/2026 23:00	0.9	1.5	-2	0.46	0.22824	0.76
Average/Sum#:	0.9	1.5	-2	0.46	0.22819	0.76
Minimum:	0.8	1.5	-2	0.45	0.22632	0.75
Maximum:	0.9	1.5	-1	0.48	0.23760	0.79
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/15/2026 00:00	0.9	1.5	-2	0.46	0.22836	0.76
08/15/2026 01:00	0.9	1.5	-2	0.46	0.22848	0.76
08/15/2026 02:00	0.9	1.5	-2	0.46	0.22854	0.76
08/15/2026 03:00	0.9	1.5	-2	0.46	0.22788	0.76
08/15/2026 04:00	0.9	1.5	-2	0.45	0.22734	0.76
08/15/2026 05:00	0.9	1.5	-2	0.45	0.22704	0.76
08/15/2026 06:00	0.9	1.5	-2	0.45	0.22692	0.76
08/15/2026 07:00	0.9	1.5	-2	0.45	0.22674	0.76
08/15/2026 08:00	0.9	1.5	-1	0.45	0.22656	0.76
08/15/2026 09:00	0.8	1.5	-1	0.45	0.22674	0.76
08/15/2026 10:00	0.8	1.5	-1	0.45	0.22674	0.76
08/15/2026 11:00	0.8	1.5	-2	0.45	0.22644	0.75
08/15/2026 12:00	0.8	1.5	-2	0.45	0.22644	0.75
08/15/2026 13:00	0.8	1.5	-2	0.45	0.22620	0.75
08/15/2026 14:00	0.8	1.5	-2	0.45	0.22620	0.75
08/15/2026 15:00	0.8	1.5	-1	0.45	0.22614	0.75
08/15/2026 16:00	0.8	1.5	-1	0.48	0.23838	0.79
08/15/2026 17:00	0.8	1.5	-1	0.50	0.24882	0.83
08/15/2026 18:00	0.8	1.5	-2	0.46	0.23208	0.77
08/15/2026 19:00	0.8	1.5	-1	0.48	0.24048	0.80
08/15/2026 20:00	0.8	1.5	-1	0.45	0.22740	0.76
08/15/2026 21:00	0.7	1.5	-1	0.55	0.27642	0.92
08/15/2026 22:00	0.8	1.5	-1	0.54	0.27072	0.90
08/15/2026 23:00	0.8	1.5	-1	0.55	0.27702	0.92
Average/Sum#:	0.8	1.5	-2	0.47	0.23517	0.78
Minimum:	0.7	1.5	-2	0.45	0.22614	0.75
Maximum:	0.9	1.5	-1	0.55	0.27702	0.92
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/16/2026 00:00	0.8	1.5	-1	0.55	0.27504	0.92
08/16/2026 01:00	0.9	1.5	-2	0.45	0.22674	0.76
08/16/2026 02:00	0.9	1.5	-2	0.45	0.22686	0.76
08/16/2026 03:00	0.9	1.5	-2	0.45	0.22710	0.76
08/16/2026 04:00	0.9	1.5	-2	0.45	0.22734	0.76
08/16/2026 05:00	0.9	1.5	-2	0.46	0.22752	0.76
08/16/2026 06:00	0.9	1.5	-1	0.46	0.22758	0.76
08/16/2026 07:00	0.9	1.5	-1	0.45	0.22746	0.76
08/16/2026 08:00	0.9	1.5	-1	0.45	0.22698	0.76
08/16/2026 09:00	0.9	1.5	-1	0.45	0.22680	0.76
08/16/2026 10:00	0.9	1.5	-1	0.45	0.22632	0.75
08/16/2026 11:00	0.9	1.5	-1	0.45	0.22584	0.75
08/16/2026 12:00	0.8	1.5	-1	0.48	0.24180	0.81
08/16/2026 13:00	1.1	1.5	0	0.63	0.31488	1.05
08/16/2026 14:00	1.0	1.5	0	0.63	0.31512	1.05
08/16/2026 15:00	1.0	1.5	1	0.63	0.31506	1.05
08/16/2026 16:00	0.9	1.5	0	0.64	0.31980	1.07
08/16/2026 17:00	0.8	1.5	1	0.66	0.33174	1.11
08/16/2026 18:00	0.9	1.5	0	0.64	0.31878	1.06
08/16/2026 19:00	1.1	1.5	0	0.63	0.31392	1.05
08/16/2026 20:00	0.9	1.5	1	0.63	0.31650	1.06
08/16/2026 21:00	0.8	1.5	-1	0.55	0.27582	0.92
08/16/2026 22:00	0.7	1.5	0	0.54	0.26826	0.89
08/16/2026 23:00	0.9	1.5	-1	0.45	0.22506	0.75
Average/Sum#:	0.9	1.5	-1	0.53	0.26368	0.88
Minimum:	0.7	1.5	-2	0.45	0.22506	0.75
Maximum:	1.1	1.5	1	0.66	0.33174	1.11
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/17/2026 00:00	0.9	1.5	-1	0.45	0.22536	0.75
08/17/2026 01:00	0.9	1.5	-1	0.45	0.22542	0.75
08/17/2026 02:00	0.9	1.5	-1	0.45	0.22548	0.75
08/17/2026 03:00	0.9	1.5	-1	0.45	0.22566	0.75
08/17/2026 04:00	0.9	1.5	-1	0.46	0.22812	0.76
08/17/2026 05:00	0.9	1.5	-1	0.45	0.22602	0.75
08/17/2026 06:00	0.9	1.5	-1	0.45	0.22584	0.75
08/17/2026 07:00	0.9	1.5	-1	0.45	0.22584	0.75
08/17/2026 08:00	0.9	1.5	-1	0.45	0.22572	0.75
08/17/2026 09:00	0.9	1.5	-1	0.45	0.22542	0.75
08/17/2026 10:00	0.9	1.5	-1	0.45	0.22506	0.75
08/17/2026 11:00	0.8	1.5	-1	0.45	0.22476	0.75
08/17/2026 12:00	0.8	1.5	-1	0.48	0.24114	0.80
08/17/2026 13:00	1.1	1.5	0	0.63	0.31464	1.05
08/17/2026 14:00	0.6	1.5	2	0.70	0.34896	1.16
08/17/2026 15:00	0.4	1.5	2	0.71	0.35328	1.18
08/17/2026 16:00	0.6	1.5	1	0.67	0.33744	1.12
08/17/2026 17:00	0.3	1.5	4	0.75	0.37428	1.25
08/17/2026 18:00	0.5	1.5	2	0.71	0.35364	1.18
08/17/2026 19:00	0.8	1.5	1	0.67	0.33420	1.11
08/17/2026 20:00	0.7	1.5	1	0.63	0.31746	1.06
08/17/2026 21:00	0.9	1.5	-1	0.50	0.24798	0.83
08/17/2026 22:00	0.9	1.5	-1	0.48	0.23760	0.79
08/17/2026 23:00	0.9	1.5	-1	0.45	0.22548	0.75
Average/Sum#:	0.8	1.5	0	0.53	0.26645	0.89
Minimum:	0.3	1.5	-1	0.45	0.22476	0.75
Maximum:	1.1	1.5	4	0.75	0.37428	1.25
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/18/2026 00:00	0.9	1.5	-1	0.45	0.22572	0.75
08/18/2026 01:00	0.9	1.5	-1	0.45	0.22578	0.75
08/18/2026 02:00	0.9	1.5	-1	0.45	0.22602	0.75
08/18/2026 03:00	0.9	1.5	-1	0.45	0.22620	0.75
08/18/2026 04:00	0.9	1.5	-2	0.45	0.22644	0.75
08/18/2026 05:00	0.9	1.5	-2	0.45	0.22650	0.76
08/18/2026 06:00	0.9	1.5	-2	0.45	0.22656	0.76
08/18/2026 07:00	0.9	1.5	-1	0.45	0.22614	0.75
08/18/2026 08:00	0.9	1.5	-1	0.45	0.22590	0.75
08/18/2026 09:00	0.9	1.5	-1	0.45	0.22548	0.75
08/18/2026 10:00	0.9	1.5	-1	0.45	0.22506	0.75
08/18/2026 11:00	0.8	1.5	-1	0.45	0.22470	0.75
08/18/2026 12:00	0.9	1.5	-1	0.48	0.23832	0.79
08/18/2026 13:00	0.4	1.5	2	0.65	0.32694	1.09
08/18/2026 14:00	0.3	1.5	3	0.68	0.33774	1.13
08/18/2026 15:00	0.2	1.5	3	0.66	0.33192	1.11
08/18/2026 16:00	0.2	1.5	4	0.70	0.35040	1.17
08/18/2026 17:00	0.2	1.5	5	0.79	0.39270	1.31
08/18/2026 18:00	0.2	1.5	3	0.75	0.37614	1.25
08/18/2026 19:00	0.7	1.5	1	0.68	0.33798	1.13
08/18/2026 20:00	1.1	1.5	0	0.63	0.31266	1.04
08/18/2026 21:00	0.9	1.5	-1	0.51	0.25440	0.85
08/18/2026 22:00	0.9	1.5	-1	0.47	0.23736	0.79
08/18/2026 23:00	0.9	1.5	-1	0.46	0.22938	0.76
Average/Sum#:	0.7	1.5	0	0.54	0.26819	0.89
Minimum:	0.2	1.5	-2	0.45	0.22470	0.75
Maximum:	1.1	1.5	5	0.79	0.39270	1.31
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/19/2026 00:00	0.9	1.5	-1	0.45	0.22560	0.75
08/19/2026 01:00	0.9	1.5	-1	0.45	0.22584	0.75
08/19/2026 02:00	0.9	1.5	-1	0.45	0.22596	0.75
08/19/2026 03:00	0.9	1.5	-1	0.45	0.22608	0.75
08/19/2026 04:00	0.9	1.5	-1	0.45	0.22620	0.75
08/19/2026 05:00	0.9	1.5	-1	0.45	0.22644	0.75
08/19/2026 06:00	0.9	1.5	-1	0.45	0.22632	0.75
08/19/2026 07:00	0.9	1.5	-1	0.45	0.22608	0.75
08/19/2026 08:00	0.9	1.5	-1	0.45	0.22584	0.75
08/19/2026 09:00	0.9	1.5	-1	0.45	0.22536	0.75
08/19/2026 10:00	0.9	1.5	-1	0.45	0.22524	0.75
08/19/2026 11:00	0.8	1.5	-1	0.45	0.22506	0.75
08/19/2026 12:00	0.9	1.5	-1	0.47	0.23724	0.79
08/19/2026 13:00	0.2	1.5	3	0.67	0.33714	1.12
08/19/2026 14:00	0.2	1.5	4	0.70	0.34998	1.17
08/19/2026 15:00	0.4	1.5	4	0.68	0.34062	1.14
08/19/2026 16:00	0.1	1.5	5	0.69	0.34650	1.16
08/19/2026 17:00	0.2	1.5	4	0.77	0.38718	1.29
08/19/2026 18:00	0.2	1.5	4	0.78	0.38778	1.29
08/19/2026 19:00	0.3	1.5	3	0.75	0.37728	1.26
08/19/2026 20:00	0.6	1.5	2	0.70	0.35088	1.17
08/19/2026 21:00	0.8	1.5	-1	0.54	0.27168	0.91
08/19/2026 22:00	0.7	1.5	0	0.55	0.27600	0.92
08/19/2026 23:00	0.8	1.5	0	0.55	0.27504	0.92
Average/Sum#:	0.7	1.5	1	0.55	0.27697	0.92
Minimum:	0.1	1.5	-1	0.45	0.22506	0.75
Maximum:	0.9	1.5	5	0.78	0.38778	1.29
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/20/2026 00:00	0.8	1.5	-1	0.50	0.25218	0.84
08/20/2026 01:00	0.9	1.5	-1	0.45	0.22722	0.76
08/20/2026 02:00	0.9	1.5	-1	0.45	0.22698	0.76
08/20/2026 03:00	0.9	1.5	-1	0.45	0.22644	0.75
08/20/2026 04:00	0.9	1.5	-1	0.45	0.22656	0.76
08/20/2026 05:00	0.9	1.5	-2	0.45	0.22710	0.76
08/20/2026 06:00	0.9	1.5	-1	0.46	0.22866	0.76
08/20/2026 07:00	0.9	1.5	-1	0.45	0.22692	0.76
08/20/2026 08:00	0.9	1.5	-1	0.45	0.22674	0.76
08/20/2026 09:00	0.9	1.5	-1	0.45	0.22626	0.75
08/20/2026 10:00	0.9	1.5	-1	0.45	0.22608	0.75
08/20/2026 11:00	0.9	1.5	-1	0.45	0.22740	0.76
08/20/2026 12:00	0.9	1.5	-1	0.49	0.24354	0.81
08/20/2026 13:00	0.3	1.5	2	0.66	0.33096	1.10
08/20/2026 14:00	0.4	1.5	2	0.67	0.33294	1.11
08/20/2026 15:00	0.2	1.5	3	0.67	0.33300	1.11
08/20/2026 16:00	0.2	1.5	3	0.68	0.34158	1.14
08/20/2026 17:00	0.2	1.5	5	0.79	0.39306	1.31
08/20/2026 18:00	0.3	1.5	4	0.76	0.38118	1.27
08/20/2026 19:00	0.3	1.5	3	0.76	0.38154	1.27
08/20/2026 20:00	0.5	1.5	2	0.71	0.35412	1.18
08/20/2026 21:00	0.8	1.5	-1	0.55	0.27504	0.92
08/20/2026 22:00	0.7	1.5	-1	0.55	0.27480	0.92
08/20/2026 23:00	0.7	1.5	-1	0.55	0.27486	0.92
Average/Sum#:	0.7	1.5	0	0.55	0.27772	0.93
Minimum:	0.2	1.5	-2	0.45	0.22608	0.75
Maximum:	0.9	1.5	5	0.79	0.39306	1.31
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/21/2026 00:00	0.8	1.5	-1	0.55	0.27486	0.92
08/21/2026 01:00	0.9	1.5	-1	0.47	0.23682	0.79
08/21/2026 02:00	0.8	1.4	-2	0.50	0.24954	0.83
08/21/2026 03:00	0.9	1.5	-2	0.46	0.23172	0.77
08/21/2026 04:00	0.9	1.5	-2	0.46	0.23076	0.77
08/21/2026 05:00	0.8	1.5	-1	0.55	0.27654	0.92
08/21/2026 06:00	0.9	1.5	-1	0.49	0.24456	0.82
08/21/2026 07:00	0.9	1.5	-1	0.45	0.22722	0.76
08/21/2026 08:00	0.9	1.5	-1	0.45	0.22728	0.76
08/21/2026 09:00	0.9	1.5	-1	0.45	0.22692	0.76
08/21/2026 10:00	0.8	1.5	-1	0.45	0.22662	0.76
08/21/2026 11:00	0.8	1.5	-1	0.45	0.22620	0.75
08/21/2026 12:00	0.8	1.5	-1	0.49	0.24264	0.81
08/21/2026 13:00	0.6	1.5	2	0.65	0.32472	1.08
08/21/2026 14:00	0.2	1.5	2	0.66	0.33066	1.10
08/21/2026 15:00	0.2	1.5	3	0.66	0.32862	1.10
08/21/2026 16:00	0.2	1.5	3	0.68	0.33810	1.13
08/21/2026 17:00	0.2	1.5	4	0.78	0.38916	1.30
08/21/2026 18:00	0.8	1.5	1	0.65	0.32682	1.09
08/21/2026 19:00	1.1	1.5	0	0.63	0.31530	1.05
08/21/2026 20:00	1.2	1.5	1	0.63	0.31548	1.05
08/21/2026 21:00	0.9	1.5	-1	0.46	0.22968	0.77
08/21/2026 22:00	0.9	1.5	-1	0.45	0.22626	0.75
08/21/2026 23:00	0.8	1.5	-1	0.52	0.25854	0.86
Average/Sum#:	0.8	1.5	0	0.54	0.27104	0.90
Minimum:	0.2	1.4	-2	0.45	0.22620	0.75
Maximum:	1.2	1.5	4	0.78	0.38916	1.30
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/22/2026 00:00	0.8	1.5	-1	0.51	0.25428	0.85
08/22/2026 01:00	0.8	1.5	-1	0.50	0.24822	0.83
08/22/2026 02:00	0.9	1.5	-1	0.45	0.22668	0.76
08/22/2026 03:00	0.9	1.5	-2	0.45	0.22686	0.76
08/22/2026 04:00	0.8	1.5	-1	0.49	0.24612	0.82
08/22/2026 05:00	0.9	1.5	-2	0.46	0.22818	0.76
08/22/2026 06:00	0.9	1.5	-1	0.45	0.22722	0.76
08/22/2026 07:00	0.9	1.5	-1	0.45	0.22704	0.76
08/22/2026 08:00	0.9	1.5	-1	0.45	0.22674	0.76
08/22/2026 09:00	0.8	1.5	-1	0.45	0.22656	0.76
08/22/2026 10:00	0.8	1.5	-1	0.45	0.22626	0.75
08/22/2026 11:00	0.8	1.5	-1	0.45	0.22560	0.75
08/22/2026 12:00	0.8	1.5	-1	0.48	0.24126	0.80
08/22/2026 13:00	1.1	1.5	0	0.63	0.31512	1.05
08/22/2026 14:00	1.0	1.5	0	0.63	0.31500	1.05
08/22/2026 15:00	1.0	1.5	1	0.63	0.31494	1.05
08/22/2026 16:00	1.0	1.5	1	0.63	0.31638	1.05
08/22/2026 17:00	0.3	1.5	2	0.65	0.32562	1.09
08/22/2026 18:00	0.3	1.5	2	0.65	0.32466	1.08
08/22/2026 19:00	0.5	1.5	1	0.64	0.32058	1.07
08/22/2026 20:00	0.7	1.5	1	0.63	0.31746	1.06
08/22/2026 21:00	0.9	1.5	-1	0.47	0.23328	0.78
08/22/2026 22:00	0.9	1.5	-1	0.45	0.22614	0.75
08/22/2026 23:00	0.9	1.5	-1	0.45	0.22662	0.76
Average/Sum#:	0.8	1.5	0	0.52	0.26112	0.87
Minimum:	0.3	1.5	-2	0.45	0.22560	0.75
Maximum:	1.1	1.5	2	0.65	0.32562	1.09
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/23/2026 00:00	0.8	1.5	-1	0.49	0.24480	0.82
08/23/2026 01:00	0.9	1.5	-1	0.46	0.22758	0.76
08/23/2026 02:00	0.9	1.5	-1	0.45	0.22668	0.76
08/23/2026 03:00	1.0	1.5	-1	0.45	0.22686	0.76
08/23/2026 04:00	1.0	1.5	-1	0.45	0.22710	0.76
08/23/2026 05:00	1.0	1.5	-2	0.45	0.22734	0.76
08/23/2026 06:00	1.1	1.5	-1	0.45	0.22722	0.76
08/23/2026 07:00	1.1	1.5	-1	0.45	0.22680	0.76
08/23/2026 08:00	0.9	1.5	-1	0.45	0.22632	0.75
08/23/2026 09:00	0.9	1.5	-1	0.45	0.22590	0.75
08/23/2026 10:00	0.9	1.5	-1	0.45	0.22554	0.75
08/23/2026 11:00	0.9	1.5	-1	0.45	0.22524	0.75
08/23/2026 12:00	0.9	1.5	-1	0.49	0.24306	0.81
08/23/2026 13:00	1.0	1.5	1	0.63	0.31674	1.06
08/23/2026 14:00	0.3	1.5	3	0.66	0.32970	1.10
08/23/2026 15:00	0.3	1.5	3	0.69	0.34716	1.16
08/23/2026 16:00	0.5	1.5	3	0.72	0.35934	1.20
08/23/2026 17:00	0.2	1.5	4	0.78	0.38808	1.29
08/23/2026 18:00	0.2	1.5	4	0.77	0.38364	1.28
08/23/2026 19:00	0.4	1.5	2	0.73	0.36462	1.22
08/23/2026 20:00	0.6	1.5	2	0.70	0.35124	1.17
08/23/2026 21:00	0.8	1.5	-1	0.55	0.27630	0.92
08/23/2026 22:00	0.8	1.5	0	0.55	0.27654	0.92
08/23/2026 23:00	0.8	1.5	0	0.55	0.27576	0.92
Average/Sum#:	0.8	1.5	0	0.55	0.27707	0.92
Minimum:	0.2	1.5	-2	0.45	0.22524	0.75
Maximum:	1.1	1.5	4	0.78	0.38808	1.29
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/24/2026 00:00	0.8	1.5	0	0.55	0.27588	0.92
08/24/2026 01:00	0.8	1.5	0	0.55	0.27582	0.92
08/24/2026 02:00	0.8	1.5	0	0.55	0.27534	0.92
08/24/2026 03:00	0.8	1.5	-1	0.54	0.27066	0.90
08/24/2026 04:00	0.8	1.5	0	0.55	0.27360	0.91
08/24/2026 05:00	0.9	1.5	-1	0.46	0.22944	0.76
08/24/2026 06:00	0.8	1.5	-1	0.50	0.24870	0.83
08/24/2026 07:00	0.9	1.5	-1	0.47	0.23634	0.79
08/24/2026 08:00	0.9	1.5	-1	0.45	0.22626	0.75
08/24/2026 09:00	0.9	1.5	-1	0.45	0.22602	0.75
08/24/2026 10:00	0.9	1.5	-1	0.45	0.22572	0.75
08/24/2026 11:00	0.8	1.5	-1	0.45	0.22560	0.75
08/24/2026 12:00	0.8	1.5	-1	0.49	0.24414	0.81
08/24/2026 13:00	0.4	1.5	2	0.67	0.33366	1.11
08/24/2026 14:00	0.2	1.5	4	0.74	0.36978	1.23
08/24/2026 15:00	0.2	1.5	5	0.78	0.38904	1.30
08/24/2026 16:00	0.3	1.5	3	0.75	0.37362	1.25
08/24/2026 17:00	0.2	1.5	5	0.78	0.38982	1.30
08/24/2026 18:00	0.2	1.5	5	0.78	0.39210	1.31
08/24/2026 19:00	0.2	1.5	4	0.78	0.39126	1.30
08/24/2026 20:00	0.6	1.5	2	0.69	0.34716	1.16
08/24/2026 21:00	0.8	1.5	-1	0.55	0.27606	0.92
08/24/2026 22:00	0.7	1.5	0	0.55	0.27600	0.92
08/24/2026 23:00	0.8	1.5	0	0.53	0.26664	0.89
Average/Sum#:	0.6	1.5	1	0.59	0.29328	0.98
Minimum:	0.2	1.5	-1	0.45	0.22560	0.75
Maximum:	0.9	1.5	5	0.78	0.39210	1.31
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/25/2026 00:00	0.8	1.5	-1	0.51	0.25326	0.84
08/25/2026 01:00	0.9	1.5	-1	0.46	0.22902	0.76
08/25/2026 02:00	0.9	1.5	-1	0.45	0.22680	0.76
08/25/2026 03:00	0.9	1.5	-2	0.45	0.22710	0.76
08/25/2026 04:00	0.8	1.5	-1	0.50	0.25116	0.84
08/25/2026 05:00	0.9	1.5	-2	0.48	0.23916	0.80
08/25/2026 06:00	0.9	1.5	-1	0.48	0.24192	0.81
08/25/2026 07:00	0.9	1.5	-1	0.45	0.22698	0.76
08/25/2026 08:00	0.9	1.5	-1	0.45	0.22680	0.76
08/25/2026 09:00	0.9	1.5	-1	0.45	0.22662	0.76
08/25/2026 10:00	0.9	1.5	-1	0.45	0.22620	0.75
08/25/2026 11:00	0.8	1.5	-1	0.50	0.25020	0.83
08/25/2026 12:00	0.7	1.5	-1	0.54	0.26754	0.89
08/25/2026 13:00	0.7	1.5	-1	0.56	0.28098	0.94
08/25/2026 14:00	0.8	1.5	1	0.67	0.33348	1.11
08/25/2026 15:00	0.9	1.5	1	0.64	0.32178	1.07
08/25/2026 16:00	0.5	1.5	2	0.71	0.35748	1.19
08/25/2026 17:00	0.2	1.5	5	0.79	0.39480	1.32
08/25/2026 18:00	0.2	1.5	5	0.79	0.39468	1.32
08/25/2026 19:00	0.3	1.5	3	0.75	0.37482	1.25
08/25/2026 20:00	0.7	1.5	2	0.68	0.33864	1.13
08/25/2026 21:00	0.6	1.5	2	0.66	0.32982	1.10
08/25/2026 22:00	0.9	1.5	-1	0.49	0.24588	0.82
08/25/2026 23:00	0.9	1.5	-1	0.45	0.22662	0.76
Average/Sum#:	0.7	1.5	0	0.56	0.27882	0.93
Minimum:	0.2	1.5	-2	0.45	0.22620	0.75
Maximum:	0.9	1.5	5	0.79	0.39480	1.32
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/26/2026 00:00	0.9	1.5	-1	0.46	0.23052	0.77
08/26/2026 01:00	0.9	1.5	-1	0.45	0.22650	0.76
08/26/2026 02:00	0.9	1.5	-1	0.48	0.24240	0.81
08/26/2026 03:00	0.9	1.4	-1	0.45	0.22662	0.76
08/26/2026 04:00	0.8	1.5	-1	0.51	0.25440	0.85
08/26/2026 05:00	0.8	1.5	-1	0.55	0.27558	0.92
08/26/2026 06:00	0.9	1.5	-1	0.50	0.24798	0.83
08/26/2026 07:00	0.9	1.5	-1	0.45	0.22680	0.76
08/26/2026 08:00	0.9	1.5	-1	0.45	0.22656	0.76
08/26/2026 09:00	0.9	1.5	-1	0.45	0.22608	0.75
08/26/2026 10:00	0.9	1.5	-1	0.45	0.22596	0.75
08/26/2026 11:00	0.7	1.5	-1	0.55	0.27420	0.91
08/26/2026 12:00	0.7	1.5	-1	0.56	0.27750	0.93
08/26/2026 13:00	0.8	1.5	1	0.65	0.32724	1.09
08/26/2026 14:00	0.3	1.5	3	0.66	0.32802	1.09
08/26/2026 15:00	0.2	1.5	3	0.66	0.32946	1.10
08/26/2026 16:00	0.2	1.5	4	0.66	0.32994	1.10
08/26/2026 17:00	0.3	1.5	3	0.72	0.35892	1.20
08/26/2026 18:00	0.6	1.5	1	0.67	0.33624	1.12
08/26/2026 19:00	0.4	1.5	2	0.68	0.34242	1.14
08/26/2026 20:00	0.6	1.5	2	0.68	0.33918	1.13
08/26/2026 21:00	0.9	1.5	-1	0.55	0.27450	0.92
08/26/2026 22:00	0.9	1.5	-1	0.46	0.23088	0.77
08/26/2026 23:00	0.9	1.5	0	0.51	0.25602	0.85
Average/Sum#:	0.7	1.5	0	0.55	0.27558	0.92
Minimum:	0.2	1.4	-1	0.45	0.22596	0.75
Maximum:	0.9	1.5	4	0.72	0.35892	1.20
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/27/2026 00:00	0.9	1.5	-1	0.48	0.24066	0.80
08/27/2026 01:00	0.9	1.5	-1	0.45	0.22632	0.75
08/27/2026 02:00	0.9	1.5	-1	0.45	0.22650	0.76
08/27/2026 03:00	1.0	1.5	-1	0.45	0.22662	0.76
08/27/2026 04:00	0.9	1.5	-1	0.45	0.22668	0.76
08/27/2026 05:00	0.9	1.5	-1	0.50	0.24822	0.83
08/27/2026 06:00	0.9	1.5	-1	0.51	0.25536	0.85
08/27/2026 07:00	0.8	1.5	-1	0.55	0.27744	0.92
08/27/2026 08:00	0.8	1.5	0	0.55	0.27732	0.92
08/27/2026 09:00	0.7	1.5	-1	0.55	0.27738	0.92
08/27/2026 10:00	0.8	1.5	-1	0.55	0.27666	0.92
08/27/2026 11:00	0.8	1.5	-1	0.55	0.27678	0.92
08/27/2026 12:00	0.8	1.5	0	0.57	0.28368	0.95
08/27/2026 13:00	0.5	1.5	3	0.74	0.36954	1.23
08/27/2026 14:00	0.3	1.5	4	0.77	0.38376	1.28
08/27/2026 15:00	0.7	1.5	1	0.66	0.32778	1.09
08/27/2026 16:00	0.7	1.5	1	0.67	0.33462	1.12
08/27/2026 17:00	0.9	1.5	1	0.63	0.31710	1.06
08/27/2026 18:00	0.6	1.5	2	0.65	0.32382	1.08
08/27/2026 19:00	0.5	1.5	2	0.65	0.32550	1.09
08/27/2026 20:00	0.4	1.5	3	0.69	0.34272	1.14
08/27/2026 21:00	0.8	1.5	-1	0.55	0.27552	0.92
08/27/2026 22:00	0.8	1.5	0	0.55	0.27708	0.92
08/27/2026 23:00	0.6	1.5	3	0.70	0.35172	1.17
Average/Sum#:	0.7	1.5	0	0.58	0.28953	0.97
Minimum:	0.3	1.5	-1	0.45	0.22632	0.75
Maximum:	1.0	1.5	4	0.77	0.38376	1.28
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/28/2026 00:00	0.7	1.5	1	0.66	0.32898	1.10
08/28/2026 01:00	0.8	1.5	1	0.65	0.32376	1.08
08/28/2026 02:00	1.0	1.5	0	0.63	0.31620	1.05
08/28/2026 03:00	0.9	1.5	1	0.64	0.32202	1.07
08/28/2026 04:00	0.6	1.5	2	0.69	0.34674	1.16
08/28/2026 05:00	0.3	1.5	4	0.78	0.38766	1.29
08/28/2026 06:00	0.4	1.5	4	0.75	0.37662	1.26
08/28/2026 07:00	0.3	1.5	3	0.78	0.38778	1.29
08/28/2026 08:00	1.0	1.5	1	0.67	0.33474	1.12
08/28/2026 09:00	1.0	1.5	1	0.63	0.31722	1.06
08/28/2026 10:00	0.9	1.5	1	0.65	0.32418	1.08
08/28/2026 11:00	0.6	1.5	1	0.66	0.32844	1.09
08/28/2026 12:00	0.7	1.5	1	0.65	0.32652	1.09
08/28/2026 13:00	0.7	1.5	1	0.64	0.32214	1.07
08/28/2026 14:00	0.6	1.5	1	0.65	0.32424	1.08
08/28/2026 15:00	0.6	1.5	1	0.64	0.32154	1.07
08/28/2026 16:00	0.7	1.5	1	0.64	0.31998	1.07
08/28/2026 17:00	0.8	1.5	1	0.64	0.31878	1.06
08/28/2026 18:00	0.8	1.5	1	0.64	0.32016	1.07
08/28/2026 19:00	0.9	1.5	1	0.63	0.31680	1.06
08/28/2026 20:00	0.9	1.5	1	0.63	0.31524	1.05
08/28/2026 21:00	1.0	1.5	1	0.63	0.31386	1.05
08/28/2026 22:00	1.1	1.5	0	0.63	0.31350	1.05
08/28/2026 23:00	1.2	1.5	0	0.63	0.31344	1.04
Average/Sum#:	0.8	1.5	1	0.66	0.33002	1.10
Minimum:	0.3	1.5	0	0.63	0.31344	1.04
Maximum:	1.2	1.5	4	0.78	0.38778	1.29
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/29/2026 00:00	1.3	1.5	0	0.63	0.31308	1.04
08/29/2026 01:00	1.3	1.5	0	0.63	0.31332	1.04
08/29/2026 02:00	1.5	1.5	0	0.63	0.31284	1.04
08/29/2026 03:00	1.6	1.5	0	0.62	0.31218	1.04
08/29/2026 04:00	1.6	1.5	0	0.62	0.31134	1.04
08/29/2026 05:00	1.7	1.5	0	0.62	0.31008	1.03
08/29/2026 06:00	1.7	1.5	0	0.62	0.31038	1.03
08/29/2026 07:00	1.6	1.5	0	0.62	0.31224	1.04
08/29/2026 08:00	1.5	1.5	1	0.63	0.31260	1.04
08/29/2026 09:00	1.1	1.5	1	0.63	0.31434	1.05
08/29/2026 10:00	1.0	1.5	1	0.63	0.31548	1.05
08/29/2026 11:00	0.9	1.5	0	0.64	0.31764	1.06
08/29/2026 12:00	0.7	1.5	1	0.64	0.32064	1.07
08/29/2026 13:00	0.6	1.5	1	0.65	0.32280	1.08
08/29/2026 14:00	0.5	1.5	2	0.65	0.32544	1.08
08/29/2026 15:00	0.9	1.5	1	0.64	0.31848	1.06
08/29/2026 16:00	1.2	1.5	0	0.63	0.31422	1.05
08/29/2026 17:00	1.0	1.5	1	0.66	0.32922	1.10
08/29/2026 18:00	1.0	1.5	1	0.63	0.31572	1.05
08/29/2026 19:00	0.9	1.5	1	0.63	0.31536	1.05
08/29/2026 20:00	1.0	1.5	1	0.63	0.31578	1.05
08/29/2026 21:00	1.1	1.5	0	0.63	0.31512	1.05
08/29/2026 22:00	1.2	1.5	0	0.63	0.31410	1.05
08/29/2026 23:00	1.4	1.5	0	0.63	0.31326	1.04
Average/Sum#:	1.2	1.5	1	0.63	0.31565	1.05
Minimum:	0.5	1.5	0	0.62	0.31008	1.03
Maximum:	1.7	1.5	2	0.66	0.32922	1.10
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/30/2026 00:00	1.6	1.5	0	0.62	0.31212	1.04
08/30/2026 01:00	1.6	1.5	0	0.62	0.31128	1.04
08/30/2026 02:00	1.6	1.5	0	0.62	0.31128	1.04
08/30/2026 03:00	1.6	1.5	0	0.62	0.31110	1.04
08/30/2026 04:00	1.7	1.5	0	0.62	0.31086	1.04
08/30/2026 05:00	1.7	1.5	0	0.62	0.31020	1.03
08/30/2026 06:00	1.8	1.5	0	0.62	0.30978	1.03
08/30/2026 07:00	1.6	1.5	0	0.62	0.31218	1.04
08/30/2026 08:00	1.6	1.5	1	0.63	0.31344	1.04
08/30/2026 09:00	1.2	1.5	1	0.63	0.31470	1.05
08/30/2026 10:00	1.0	1.5	1	0.63	0.31704	1.06
08/30/2026 11:00	0.9	1.5	1	0.64	0.31848	1.06
08/30/2026 12:00	0.7	1.5	0	0.64	0.32034	1.07
08/30/2026 13:00	0.6	1.5	1	0.64	0.32124	1.07
08/30/2026 14:00	0.6	1.5	1	0.64	0.32100	1.07
08/30/2026 15:00	0.5	1.5	1	0.64	0.32226	1.07
08/30/2026 16:00	0.5	1.5	2	0.66	0.32766	1.09
08/30/2026 17:00	0.4	1.5	3	0.68	0.34182	1.14
08/30/2026 18:00	0.6	1.5	1	0.64	0.31974	1.07
08/30/2026 19:00	0.9	1.5	1	0.63	0.31590	1.05
08/30/2026 20:00	1.0	1.5	1	0.63	0.31542	1.05
08/30/2026 21:00	1.0	1.5	1	0.63	0.31590	1.05
08/30/2026 22:00	1.1	1.5	0	0.63	0.31482	1.05
08/30/2026 23:00	1.3	1.5	0	0.63	0.31302	1.04
Average/Sum#:	1.1	1.5	1	0.63	0.31673	1.06
Minimum:	0.4	1.5	0	0.62	0.30978	1.03
Maximum:	1.8	1.5	3	0.68	0.34182	1.14
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
08/31/2026 00:00	1.4	1.5	0	0.62	0.31212	1.04
08/31/2026 01:00	1.6	1.5	0	0.62	0.31128	1.04
08/31/2026 02:00	1.6	1.5	0	0.62	0.31122	1.04
08/31/2026 03:00	1.6	1.5	0	0.62	0.31098	1.04
08/31/2026 04:00	1.7	1.5	0	0.62	0.31080	1.04
08/31/2026 05:00	1.4	1.5	-1	0.55	0.27732	0.92
08/31/2026 06:00	1.0	1.5	-2	0.45	0.22740	0.76
08/31/2026 07:00	1.0	1.5	-2	0.45	0.22740	0.76
08/31/2026 08:00	1.0	1.5	-2	0.45	0.22704	0.76
08/31/2026 09:00	1.0	1.5	-1	0.45	0.22704	0.76
08/31/2026 10:00	1.0	1.5	-1	0.45	0.22692	0.76
08/31/2026 11:00	0.9	1.5	-1	0.45	0.22686	0.76
08/31/2026 12:00	0.9	1.5	-1	0.49	0.24426	0.81
08/31/2026 13:00	1.1	1.5	0	0.64	0.31794	1.06
08/31/2026 14:00	1.0	1.5	0	0.63	0.31602	1.05
08/31/2026 15:00	1.0	1.5	0	0.63	0.31584	1.05
08/31/2026 16:00	1.0	1.5	0	0.63	0.31572	1.05
08/31/2026 17:00	1.2	1.5	0	0.63	0.31410	1.05
08/31/2026 18:00	1.5	1.5	0	0.62	0.31236	1.04
08/31/2026 19:00	1.6	1.5	0	0.63	0.31296	1.04
08/31/2026 20:00	1.6	1.5	0	0.62	0.31212	1.04
08/31/2026 21:00	1.2	1.5	-1	0.51	0.25560	0.85
08/31/2026 22:00	1.0	1.5	-2	0.45	0.22722	0.76
08/31/2026 23:00	0.9	1.5	-2	0.49	0.24330	0.81
Average/Sum#:	1.2	1.5	-1	0.56	0.27849	0.93
Minimum:	0.9	1.5	-2	0.45	0.22686	0.76
Maximum:	1.7	1.5	0	0.64	0.31794	1.06
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/01/2026 00:00	0.9	1.5	-2	0.49	0.24276	0.81
09/01/2026 01:00	1.0	1.5	-2	0.45	0.22656	0.76
09/01/2026 02:00	1.0	1.5	-2	0.45	0.22650	0.76
09/01/2026 03:00	1.0	1.5	-2	0.45	0.22632	0.75
09/01/2026 04:00	1.0	1.5	-2	0.45	0.22644	0.75
09/01/2026 05:00	1.0	1.5	-2	0.45	0.22656	0.76
09/01/2026 06:00	1.0	1.5	-2	0.45	0.22632	0.75
09/01/2026 07:00	1.0	1.5	-2	0.45	0.22626	0.75
09/01/2026 08:00	1.0	1.5	-1	0.45	0.22620	0.75
09/01/2026 09:00	1.0	1.5	-1	0.45	0.22584	0.75
09/01/2026 10:00	0.9	1.5	-1	0.45	0.22572	0.75
09/01/2026 11:00	0.9	1.5	-1	0.45	0.22530	0.75
09/01/2026 12:00	0.9	1.5	-1	0.45	0.22512	0.75
09/01/2026 13:00	0.9	1.5	-1	0.45	0.22488	0.75
09/01/2026 14:00	0.9	1.5	-1	0.45	0.22470	0.75
09/01/2026 15:00	0.9	1.5	-1	0.45	0.22446	0.75
09/01/2026 16:00	0.9	1.5	-2	0.45	0.22452	0.75
09/01/2026 17:00	0.9	1.5	-1	0.47	0.23424	0.78
09/01/2026 18:00	0.9	1.5	-1	0.45	0.22506	0.75
09/01/2026 19:00	0.9	1.5	-1	0.45	0.22524	0.75
09/01/2026 20:00	0.9	1.5	-1	0.45	0.22572	0.75
09/01/2026 21:00	1.0	1.5	-1	0.45	0.22596	0.75
09/01/2026 22:00	1.0	1.5	-1	0.45	0.22632	0.75
09/01/2026 23:00	1.0	1.5	-2	0.45	0.22662	0.76
Average/Sum#:	1.0	1.5	-1	0.45	0.22682	0.76
Minimum:	0.9	1.5	-2	0.45	0.22446	0.75
Maximum:	1.0	1.5	-1	0.49	0.24276	0.81
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/02/2026 00:00	1.0	1.5	-2	0.45	0.22692	0.76
09/02/2026 01:00	1.0	1.5	-2	0.45	0.22686	0.76
09/02/2026 02:00	1.0	1.5	-2	0.45	0.22692	0.76
09/02/2026 03:00	1.0	1.5	-2	0.45	0.22686	0.76
09/02/2026 04:00	1.0	1.5	-2	0.45	0.22698	0.76
09/02/2026 05:00	1.0	1.5	-2	0.45	0.22692	0.76
09/02/2026 06:00	1.0	1.5	-1	0.45	0.22686	0.76
09/02/2026 07:00	1.0	1.5	-1	0.45	0.22674	0.76
09/02/2026 08:00	0.9	1.5	-1	0.45	0.22662	0.76
09/02/2026 09:00	0.9	1.5	-1	0.45	0.22644	0.75
09/02/2026 10:00	0.9	1.5	-2	0.45	0.22602	0.75
09/02/2026 11:00	0.9	1.5	-2	0.45	0.22542	0.75
09/02/2026 12:00	0.9	1.5	-1	0.45	0.22482	0.75
09/02/2026 13:00	0.9	1.5	-2	0.45	0.22458	0.75
09/02/2026 14:00	0.9	1.5	-2	0.45	0.22452	0.75
09/02/2026 15:00	0.9	1.5	-2	0.45	0.22440	0.75
09/02/2026 16:00	0.9	1.5	-2	0.45	0.22680	0.76
09/02/2026 17:00	0.9	1.5	-1	0.48	0.24198	0.81
09/02/2026 18:00	0.9	1.5	-1	0.45	0.22470	0.75
09/02/2026 19:00	0.9	1.5	-1	0.45	0.22434	0.75
09/02/2026 20:00	0.9	1.5	-1	0.45	0.22458	0.75
09/02/2026 21:00	1.0	1.5	-1	0.45	0.22482	0.75
09/02/2026 22:00	1.0	1.5	-1	0.45	0.22488	0.75
09/02/2026 23:00	1.0	1.5	-1	0.45	0.22512	0.75
Average/Sum#:	0.9	1.5	-2	0.45	0.22646	0.76
Minimum:	0.9	1.5	-2	0.45	0.22434	0.75
Maximum:	1.0	1.5	-1	0.48	0.24198	0.81
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/03/2026 00:00	1.0	1.5	-1	0.45	0.22536	0.75
09/03/2026 01:00	1.0	1.5	-1	0.45	0.22548	0.75
09/03/2026 02:00	1.0	1.5	-2	0.45	0.22560	0.75
09/03/2026 03:00	1.0	1.5	-2	0.45	0.22566	0.75
09/03/2026 04:00	1.0	1.5	-2	0.45	0.22554	0.75
09/03/2026 05:00	1.0	1.5	-2	0.45	0.22602	0.75
09/03/2026 06:00	1.0	1.5	-2	0.46	0.22860	0.76
09/03/2026 07:00	0.9	1.5	-1	0.48	0.24144	0.80
09/03/2026 08:00	0.9	1.5	-1	0.48	0.23886	0.80
09/03/2026 09:00	0.9	1.5	-1	0.50	0.25212	0.84
09/03/2026 10:00	0.9	1.5	-1	0.49	0.24378	0.81
09/03/2026 11:00	0.9	1.5	-2	0.45	0.22494	0.75
09/03/2026 12:00	0.9	1.5	-2	0.49	0.24342	0.81
09/03/2026 13:00	0.8	1.5	-1	0.54	0.27222	0.91
09/03/2026 14:00	0.8	1.5	-1	0.55	0.27276	0.91
09/03/2026 15:00	0.8	1.5	-1	0.54	0.27240	0.91
09/03/2026 16:00	0.9	1.5	-2	0.47	0.23640	0.79
09/03/2026 17:00	0.8	1.5	-1	0.51	0.25380	0.85
09/03/2026 18:00	0.9	1.5	-1	0.45	0.22716	0.76
09/03/2026 19:00	0.9	1.5	-1	0.49	0.24648	0.82
09/03/2026 20:00	0.8	1.5	-1	0.55	0.27354	0.91
09/03/2026 21:00	0.9	1.5	-1	0.55	0.27552	0.92
09/03/2026 22:00	0.9	1.5	-1	0.55	0.27594	0.92
09/03/2026 23:00	0.8	1.5	-1	0.55	0.27312	0.91
Average/Sum#:	0.9	1.5	-1	0.49	0.24609	0.82
Minimum:	0.8	1.5	-2	0.45	0.22494	0.75
Maximum:	1.0	1.5	-1	0.55	0.27594	0.92
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/04/2026 00:00	0.9	1.5	-1	0.47	0.23676	0.79
09/04/2026 01:00	0.9	1.5	-1	0.45	0.22590	0.75
09/04/2026 02:00	0.9	1.5	-1	0.45	0.22590	0.75
09/04/2026 03:00	1.0	1.5	-1	0.45	0.22584	0.75
09/04/2026 04:00	0.9	1.5	-1	0.47	0.23328	0.78
09/04/2026 05:00	0.8	1.5	-1	0.54	0.27030	0.90
09/04/2026 06:00	0.9	1.5	-1	0.48	0.23850	0.80
09/04/2026 07:00	0.9	1.5	-1	0.48	0.24222	0.81
09/04/2026 08:00	0.9	1.5	-1	0.45	0.22572	0.75
09/04/2026 09:00	0.9	1.5	0	0.45	0.22554	0.75
09/04/2026 10:00	0.9	1.5	-1	0.49	0.24558	0.82
09/04/2026 11:00	0.9	1.5	-1	0.45	0.22500	0.75
09/04/2026 12:00	0.9	1.5	-1	0.45	0.22494	0.75
09/04/2026 13:00	0.9	1.5	-1	0.45	0.22500	0.75
09/04/2026 14:00	0.9	1.5	-2	0.45	0.22470	0.75
09/04/2026 15:00	0.9	1.5	-1	0.45	0.22458	0.75
09/04/2026 16:00	0.9	1.5	-2	0.47	0.23430	0.78
09/04/2026 17:00	0.9	1.5	-1	0.49	0.24438	0.81
09/04/2026 18:00	0.8	1.5	-1	0.55	0.27450	0.92
09/04/2026 19:00	0.8	1.5	-1	0.55	0.27378	0.91
09/04/2026 20:00	0.8	1.5	0	0.55	0.27396	0.91
09/04/2026 21:00	0.8	1.5	0	0.55	0.27474	0.92
09/04/2026 22:00	0.8	1.5	0	0.55	0.27384	0.91
09/04/2026 23:00	1.0	1.5	-1	0.46	0.23064	0.77
Average/Sum#:	0.9	1.5	-1	0.48	0.24166	0.81
Minimum:	0.8	1.5	-2	0.45	0.22458	0.75
Maximum:	1.0	1.5	0	0.55	0.27474	0.92
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/05/2026 00:00	1.0	1.5	-1	0.48	0.23778	0.79
09/05/2026 01:00	1.0	1.5	-1	0.47	0.23634	0.79
09/05/2026 02:00	0.9	1.7	-1	0.49	0.24306	0.81
09/05/2026 03:00	1.0	1.5	-1	0.45	0.22656	0.76
09/05/2026 04:00	0.9	1.5	-1	0.52	0.25950	0.87
09/05/2026 05:00	0.8	1.5	-1	0.55	0.27378	0.91
09/05/2026 06:00	1.0	1.5	-2	0.45	0.22590	0.75
09/05/2026 07:00	1.0	1.5	-1	0.45	0.22584	0.75
09/05/2026 08:00	0.9	1.5	-1	0.45	0.22548	0.75
09/05/2026 09:00	0.9	1.5	-1	0.45	0.22542	0.75
09/05/2026 10:00	0.9	1.5	-1	0.45	0.22506	0.75
09/05/2026 11:00	0.9	1.5	-1	0.45	0.22464	0.75
09/05/2026 12:00	0.9	1.5	-1	0.45	0.22452	0.75
09/05/2026 13:00	0.9	1.5	-1	0.45	0.22452	0.75
09/05/2026 14:00	0.9	1.5	-1	0.45	0.22476	0.75
09/05/2026 15:00	0.9	1.5	-2	0.45	0.22470	0.75
09/05/2026 16:00	0.9	1.5	-2	0.45	0.22452	0.75
09/05/2026 17:00	0.9	1.5	-1	0.49	0.24384	0.81
09/05/2026 18:00	0.9	1.5	-1	0.46	0.23094	0.77
09/05/2026 19:00	0.9	1.5	-1	0.47	0.23460	0.78
09/05/2026 20:00	0.9	1.5	-1	0.45	0.22602	0.75
09/05/2026 21:00	0.9	1.5	-1	0.47	0.23478	0.78
09/05/2026 22:00	0.9	1.5	0	0.47	0.23646	0.79
09/05/2026 23:00	1.0	1.5	-1	0.47	0.23280	0.78
Average/Sum#:	0.9	1.5	-1	0.47	0.23299	0.78
Minimum:	0.8	1.5	-2	0.45	0.22452	0.75
Maximum:	1.0	1.7	0	0.55	0.27378	0.91
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/06/2026 00:00	1.0	1.5	-1	0.45	0.22572	0.75
09/06/2026 01:00	1.0	1.5	-1	0.46	0.22788	0.76
09/06/2026 02:00	1.0	1.5	-1	0.47	0.23520	0.78
09/06/2026 03:00	1.0	1.5	-1	0.45	0.22554	0.75
09/06/2026 04:00	1.0	1.5	-1	0.46	0.22812	0.76
09/06/2026 05:00	1.0	1.5	-1	0.45	0.22620	0.75
09/06/2026 06:00	0.9	1.5	-1	0.49	0.24654	0.82
09/06/2026 07:00	1.0	1.5	-1	0.45	0.22560	0.75
09/06/2026 08:00	1.0	1.5	-1	0.45	0.22536	0.75
09/06/2026 09:00	1.0	1.5	-1	0.45	0.22512	0.75
09/06/2026 10:00	0.9	1.5	-1	0.45	0.22500	0.75
09/06/2026 11:00	0.9	1.5	-1	0.45	0.22446	0.75
09/06/2026 12:00	0.9	1.5	-1	0.45	0.22398	0.75
09/06/2026 13:00	0.9	1.5	-1	0.45	0.22410	0.75
09/06/2026 14:00	0.9	1.5	-1	0.45	0.22470	0.75
09/06/2026 15:00	0.9	1.5	-1	0.49	0.24618	0.82
09/06/2026 16:00	0.9	1.5	-2	0.48	0.23772	0.79
09/06/2026 17:00	0.9	1.5	-2	0.45	0.22404	0.75
09/06/2026 18:00	0.9	1.5	-1	0.45	0.22446	0.75
09/06/2026 19:00	0.9	1.5	-1	0.45	0.22470	0.75
09/06/2026 20:00	1.0	1.5	0	0.45	0.22494	0.75
09/06/2026 21:00	1.0	1.5	0	0.45	0.22524	0.75
09/06/2026 22:00	1.0	1.5	-1	0.45	0.22560	0.75
09/06/2026 23:00	0.9	1.5	-1	0.48	0.24234	0.81
Average/Sum#:	1.0	1.5	-1	0.46	0.22870	0.76
Minimum:	0.9	1.5	-2	0.45	0.22398	0.75
Maximum:	1.0	1.5	0	0.49	0.24654	0.82
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/07/2026 00:00	1.0	1.5	-1	0.45	0.22542	0.75
09/07/2026 01:00	1.0	1.5	-1	0.45	0.22584	0.75
09/07/2026 02:00	1.0	1.5	-1	0.45	0.22590	0.75
09/07/2026 03:00	1.1	1.5	-1	0.45	0.22590	0.75
09/07/2026 04:00	1.1	1.5	-1	0.45	0.22596	0.75
09/07/2026 05:00	1.1	1.5	-1	0.45	0.22650	0.76
09/07/2026 06:00	1.1	1.5	-1	0.48	0.23862	0.80
09/07/2026 07:00	1.1	1.5	-1	0.45	0.22608	0.75
09/07/2026 08:00	1.0	1.5	-1	0.45	0.22578	0.75
09/07/2026 09:00	1.0	1.5	-1	0.45	0.22524	0.75
09/07/2026 10:00	0.9	1.5	-1	0.45	0.22494	0.75
09/07/2026 11:00	0.9	1.5	-1	0.45	0.22458	0.75
09/07/2026 12:00	0.9	1.5	-2	0.45	0.22428	0.75
09/07/2026 13:00	0.9	1.5	-2	0.45	0.22416	0.75
09/07/2026 14:00	0.9	1.5	-2	0.45	0.22512	0.75
09/07/2026 15:00	0.9	1.5	-2	0.45	0.22344	0.74
09/07/2026 16:00	0.8	1.5	-2	0.49	0.24570	0.82
09/07/2026 17:00	0.9	1.5	-2	0.48	0.24090	0.80
09/07/2026 18:00	0.9	1.5	-2	0.48	0.24024	0.80
09/07/2026 19:00	0.9	1.5	-1	0.54	0.27084	0.90
09/07/2026 20:00	0.9	1.5	0	0.54	0.27216	0.91
09/07/2026 21:00	0.9	1.5	0	0.54	0.27186	0.91
09/07/2026 22:00	1.0	1.5	0	0.54	0.27150	0.91
09/07/2026 23:00	1.0	1.5	0	0.54	0.27210	0.91
Average/Sum#:	1.0	1.5	-1	0.47	0.23763	0.79
Minimum:	0.8	1.5	-2	0.45	0.22344	0.74
Maximum:	1.1	1.5	0	0.54	0.27216	0.91
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/08/2026 00:00	1.0	1.5	0	0.54	0.27192	0.91
09/08/2026 01:00	1.2	1.5	-1	0.50	0.25032	0.83
09/08/2026 02:00	1.1	1.5	-1	0.45	0.22344	0.74
09/08/2026 03:00	1.1	1.5	-1	0.46	0.23160	0.77
09/08/2026 04:00	1.2	1.5	-1	0.53	0.26544	0.88
09/08/2026 05:00	1.1	1.5	0	0.54	0.27210	0.91
09/08/2026 06:00	1.1	1.5	-1	0.48	0.24120	0.80
09/08/2026 07:00	1.2	1.5	-1	0.45	0.22368	0.75
09/08/2026 08:00	1.0	1.5	-1	0.45	0.22350	0.75
09/08/2026 09:00	1.0	1.5	-1	0.45	0.22344	0.74
09/08/2026 10:00	1.0	1.5	-2	0.45	0.22284	0.74
09/08/2026 11:00	1.0	1.5	-2	0.44	0.22242	0.74
09/08/2026 12:00	1.0	1.5	-2	0.46	0.22902	0.76
09/08/2026 13:00	0.8	1.5	-1	0.55	0.27276	0.91
09/08/2026 14:00	0.5	1.5	3	0.72	0.36240	1.21
09/08/2026 15:00	0.3	1.5	4	0.76	0.38010	1.27
09/08/2026 16:00	0.3	1.5	4	0.77	0.38424	1.28
09/08/2026 17:00	0.2	1.5	5	0.78	0.39060	1.30
09/08/2026 18:00	0.3	1.5	4	0.78	0.38958	1.30
09/08/2026 19:00	0.3	1.5	4	0.78	0.38844	1.29
09/08/2026 20:00	0.5	1.5	4	0.76	0.38028	1.27
09/08/2026 21:00	0.3	1.5	5	0.76	0.37824	1.26
09/08/2026 22:00	0.6	1.5	3	0.70	0.34848	1.16
09/08/2026 23:00	1.0	1.5	-1	0.53	0.26712	0.89
Average/Sum#:	0.8	1.5	1	0.59	0.29347	0.98
Minimum:	0.2	1.5	-2	0.44	0.22242	0.74
Maximum:	1.2	1.5	5	0.78	0.39060	1.30
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/09/2026 00:00	1.0	1.5	0	0.51	0.25638	0.85
09/09/2026 01:00	1.1	1.5	-1	0.47	0.23646	0.79
09/09/2026 02:00	1.1	1.5	-1	0.45	0.22422	0.75
09/09/2026 03:00	1.1	1.5	0	0.45	0.22452	0.75
09/09/2026 04:00	1.2	1.5	0	0.47	0.23388	0.78
09/09/2026 05:00	1.6	1.5	0	0.61	0.30270	1.01
09/09/2026 06:00	1.3	1.5	1	0.64	0.31884	1.06
09/09/2026 07:00	0.7	1.5	1	0.70	0.34914	1.16
09/09/2026 08:00	0.4	1.5	2	0.76	0.37806	1.26
09/09/2026 09:00	0.3	1.5	2	0.76	0.38190	1.27
09/09/2026 10:00	0.2	1.5	2	0.75	0.37590	1.25
09/09/2026 11:00	0.3	1.5	1	0.75	0.37620	1.25
09/09/2026 12:00	0.3	1.5	1	0.74	0.37140	1.24
09/09/2026 13:00	0.2	1.5	2	0.77	0.38316	1.28
09/09/2026 14:00	0.2	1.5	2	0.77	0.38436	1.28
09/09/2026 15:00	0.2	1.5	3	0.79	0.39354	1.31
09/09/2026 16:00	0.3	1.5	3	0.79	0.39264	1.31
09/09/2026 17:00	0.2	1.5	2	0.76	0.38208	1.27
09/09/2026 18:00	0.3	1.5	2	0.78	0.39132	1.30
09/09/2026 19:00	0.3	1.5	1	0.74	0.37188	1.24
09/09/2026 20:00	0.3	1.5	2	0.78	0.39108	1.30
09/09/2026 21:00	0.3	1.5	2	0.78	0.39102	1.30
09/09/2026 22:00	0.4	1.5	2	0.75	0.37464	1.25
09/09/2026 23:00	1.0	1.5	0	0.55	0.27408	0.91
Average/Sum#:	0.6	1.5	1	0.68	0.33998	1.13
Minimum:	0.2	1.5	-1	0.45	0.22422	0.75
Maximum:	1.6	1.5	3	0.79	0.39354	1.31
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/10/2026 00:00	0.9	1.5	0	0.55	0.27390	0.91
09/10/2026 01:00	0.9	1.5	0	0.54	0.27246	0.91
09/10/2026 02:00	0.9	1.5	0	0.53	0.26700	0.89
09/10/2026 03:00	1.0	1.5	0	0.45	0.22446	0.75
09/10/2026 04:00	1.0	1.5	0	0.46	0.22902	0.76
09/10/2026 05:00	0.8	1.5	0	0.54	0.26964	0.90
09/10/2026 06:00	0.9	1.5	0	0.48	0.24210	0.81
09/10/2026 07:00	1.0	1.5	-1	0.44	0.22248	0.74
09/10/2026 08:00	1.0	1.5	0	0.44	0.22218	0.74
09/10/2026 09:00	0.9	1.5	-1	0.44	0.22212	0.74
09/10/2026 10:00	0.9	1.5	-1	0.44	0.22152	0.74
09/10/2026 11:00	0.9	1.5	-1	0.48	0.23820	0.79
09/10/2026 12:00	1.1	1.5	0	0.62	0.31200	1.04
09/10/2026 13:00	0.9	1.5	0	0.63	0.31512	1.05
09/10/2026 14:00	0.8	1.5	0	0.64	0.31818	1.06
09/10/2026 15:00	0.8	1.5	0	0.64	0.31986	1.07
09/10/2026 16:00	0.6	1.5	1	0.68	0.33846	1.13
09/10/2026 17:00	0.4	1.5	1	0.71	0.35592	1.19
09/10/2026 18:00	0.9	1.5	0	0.63	0.31680	1.06
09/10/2026 19:00	1.1	1.5	0	0.63	0.31332	1.04
09/10/2026 20:00	1.2	1.5	0	0.63	0.31326	1.04
09/10/2026 21:00	0.8	1.5	1	0.63	0.31620	1.05
09/10/2026 22:00	0.9	1.5	0	0.63	0.31410	1.05
09/10/2026 23:00	1.0	1.5	0	0.46	0.22830	0.76
Average/Sum#:	0.9	1.5	0	0.56	0.27778	0.93
Minimum:	0.4	1.5	-1	0.44	0.22152	0.74
Maximum:	1.2	1.5	1	0.71	0.35592	1.19
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/11/2026 00:00	1.0	1.5	0	0.45	0.22332	0.74
09/11/2026 01:00	1.0	1.5	0	0.45	0.22368	0.75
09/11/2026 02:00	1.0	1.5	0	0.45	0.22362	0.75
09/11/2026 03:00	1.0	1.5	0	0.45	0.22368	0.75
09/11/2026 04:00	1.0	1.5	0	0.45	0.22392	0.75
09/11/2026 05:00	1.0	1.5	0	0.45	0.22416	0.75
09/11/2026 06:00	1.0	1.5	0	0.45	0.22428	0.75
09/11/2026 07:00	1.0	1.5	0	0.45	0.22404	0.75
09/11/2026 08:00	1.0	1.5	0	0.45	0.22380	0.75
09/11/2026 09:00	1.0	1.5	0	0.45	0.22356	0.75
09/11/2026 10:00	1.0	1.5	0	0.45	0.22332	0.74
09/11/2026 11:00	1.0	1.5	-1	0.45	0.22302	0.74
09/11/2026 12:00	1.0	1.5	-1	0.45	0.22284	0.74
09/11/2026 13:00	1.0	1.5	-1	0.45	0.22266	0.74
09/11/2026 14:00	1.0	1.5	-1	0.45	0.22278	0.74
09/11/2026 15:00	0.8	1.5	-1	0.52	0.26190	0.87
09/11/2026 16:00	0.9	1.5	-1	0.49	0.24372	0.81
09/11/2026 17:00	0.9	1.5	0	0.48	0.24216	0.81
09/11/2026 18:00	1.0	1.5	-1	0.45	0.22404	0.75
09/11/2026 19:00	1.0	1.5	0	0.45	0.22422	0.75
09/11/2026 20:00	1.0	1.5	0	0.45	0.22404	0.75
09/11/2026 21:00	1.0	1.5	0	0.45	0.22362	0.75
09/11/2026 22:00	1.0	1.5	0	0.45	0.22374	0.75
09/11/2026 23:00	1.0	1.5	0	0.45	0.22356	0.75
Average/Sum#:	1.0	1.5	0	0.46	0.22682	0.76
Minimum:	0.8	1.5	-1	0.45	0.22266	0.74
Maximum:	1.0	1.5	0	0.52	0.26190	0.87
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/12/2026 00:00	1.0	1.5	0	0.45	0.22368	0.75
09/12/2026 01:00	1.0	1.5	0	0.45	0.22362	0.75
09/12/2026 02:00	1.0	1.5	0	0.45	0.22374	0.75
09/12/2026 03:00	1.1	1.5	0	0.45	0.22386	0.75
09/12/2026 04:00	1.1	1.5	0	0.45	0.22374	0.75
09/12/2026 05:00	1.0	1.5	0	0.45	0.22392	0.75
09/12/2026 06:00	1.0	1.5	0	0.45	0.22398	0.75
09/12/2026 07:00	1.0	1.5	0	0.45	0.22398	0.75
09/12/2026 08:00	1.0	1.5	0	0.45	0.22362	0.75
09/12/2026 09:00	1.0	1.5	-1	0.45	0.22338	0.74
09/12/2026 10:00	1.0	1.5	0	0.45	0.22296	0.74
09/12/2026 11:00	1.0	1.5	-1	0.44	0.22248	0.74
09/12/2026 12:00	1.0	1.5	-1	0.44	0.22236	0.74
09/12/2026 13:00	0.9	1.5	-1	0.44	0.22212	0.74
09/12/2026 14:00	0.9	1.5	-1	0.44	0.22194	0.74
09/12/2026 15:00	0.9	1.5	-1	0.44	0.22206	0.74
09/12/2026 16:00	0.9	1.5	-1	0.47	0.23556	0.79
09/12/2026 17:00	0.9	1.5	0	0.45	0.22446	0.75
09/12/2026 18:00	1.0	1.5	0	0.45	0.22302	0.74
09/12/2026 19:00	1.0	1.5	0	0.45	0.22344	0.74
09/12/2026 20:00	1.0	1.5	0	0.45	0.22356	0.75
09/12/2026 21:00	1.0	1.5	-1	0.45	0.22392	0.75
09/12/2026 22:00	1.0	1.5	-1	0.45	0.22626	0.75
09/12/2026 23:00	1.0	1.5	-1	0.45	0.22428	0.75
Average/Sum#:	1.0	1.5	0	0.45	0.22400	0.75
Minimum:	0.9	1.5	-1	0.44	0.22194	0.74
Maximum:	1.1	1.5	0	0.47	0.23556	0.79
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/13/2026 00:00	1.0	1.5	-1	0.45	0.22452	0.75
09/13/2026 01:00	1.0	1.5	-1	0.45	0.22470	0.75
09/13/2026 02:00	1.0	1.5	-1	0.45	0.22488	0.75
09/13/2026 03:00	1.1	1.5	-1	0.45	0.22494	0.75
09/13/2026 04:00	1.1	1.5	-1	0.45	0.22506	0.75
09/13/2026 05:00	1.0	1.5	-1	0.51	0.25650	0.86
09/13/2026 06:00	1.0	1.5	-1	0.48	0.23826	0.79
09/13/2026 07:00	1.1	1.5	-1	0.45	0.22470	0.75
09/13/2026 08:00	1.0	1.5	0	0.45	0.22464	0.75
09/13/2026 09:00	1.0	1.5	0	0.45	0.22452	0.75
09/13/2026 10:00	1.0	1.5	0	0.45	0.22434	0.75
09/13/2026 11:00	1.0	1.5	0	0.45	0.22410	0.75
09/13/2026 12:00	1.0	1.5	-1	0.45	0.22380	0.75
09/13/2026 13:00	1.0	1.5	-1	0.45	0.22380	0.75
09/13/2026 14:00	1.0	1.5	-1	0.45	0.22356	0.75
09/13/2026 15:00	1.0	1.5	-1	0.45	0.22344	0.74
09/13/2026 16:00	1.0	1.5	-1	0.48	0.23868	0.80
09/13/2026 17:00	0.9	1.5	-1	0.52	0.25974	0.87
09/13/2026 18:00	1.0	1.5	-1	0.45	0.22536	0.75
09/13/2026 19:00	1.0	1.5	-1	0.45	0.22380	0.75
09/13/2026 20:00	1.0	1.5	-1	0.45	0.22422	0.75
09/13/2026 21:00	1.1	1.5	-1	0.45	0.22416	0.75
09/13/2026 22:00	1.0	1.5	-1	0.45	0.22446	0.75
09/13/2026 23:00	1.1	1.5	-1	0.45	0.22464	0.75
Average/Sum#:	1.0	1.5	-1	0.46	0.22837	0.76
Minimum:	0.9	1.5	-1	0.45	0.22344	0.74
Maximum:	1.1	1.5	0	0.52	0.25974	0.87
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/14/2026 00:00	1.1	1.5	-1	0.45	0.22476	0.75
09/14/2026 01:00	1.1	1.5	-1	0.45	0.22476	0.75
09/14/2026 02:00	1.1	1.5	-1	0.45	0.22470	0.75
09/14/2026 03:00	1.1	1.5	-1	0.45	0.22494	0.75
09/14/2026 04:00	1.1	1.5	-1	0.45	0.22500	0.75
09/14/2026 05:00	1.1	1.5	-1	0.46	0.22794	0.76
09/14/2026 06:00	1.1	1.5	-1	0.47	0.23562	0.79
09/14/2026 07:00	1.1	1.5	-1	0.45	0.22482	0.75
09/14/2026 08:00	1.1	1.5	-1	0.45	0.22428	0.75
09/14/2026 09:00	1.1	1.5	-1	0.45	0.22404	0.75
09/14/2026 10:00	1.0	1.5	-1	0.45	0.22374	0.75
09/14/2026 11:00	1.0	1.5	-1	0.45	0.22338	0.74
09/14/2026 12:00	1.0	1.5	-1	0.45	0.22338	0.74
09/14/2026 13:00	1.0	1.5	-1	0.45	0.22314	0.74
09/14/2026 14:00	1.0	1.5	-1	0.45	0.22296	0.74
09/14/2026 15:00	1.0	1.5	-1	0.45	0.22296	0.74
09/14/2026 16:00	1.0	1.5	-1	0.47	0.23460	0.78
09/14/2026 17:00	1.0	1.5	-1	0.49	0.24312	0.81
09/14/2026 18:00	1.0	1.5	-1	0.45	0.22350	0.75
09/14/2026 19:00	1.0	1.5	-1	0.46	0.22974	0.77
09/14/2026 20:00	1.1	1.5	-1	0.45	0.22500	0.75
09/14/2026 21:00	1.1	1.5	-1	0.45	0.22374	0.75
09/14/2026 22:00	1.1	1.5	-1	0.45	0.22482	0.75
09/14/2026 23:00	1.0	1.5	-1	0.52	0.26016	0.87
Average/Sum#:	1.1	1.5	-1	0.46	0.22771	0.76
Minimum:	1.0	1.5	-1	0.45	0.22296	0.74
Maximum:	1.1	1.5	-1	0.52	0.26016	0.87
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/15/2026 00:00	1.0	1.5	-1	0.48	0.24066	0.80
09/15/2026 01:00	1.1	1.5	-1	0.46	0.22818	0.76
09/15/2026 02:00	1.1	1.5	-1	0.45	0.22488	0.75
09/15/2026 03:00	1.1	1.5	-1	0.45	0.22482	0.75
09/15/2026 04:00	1.1	1.5	-1	0.46	0.23220	0.77
09/15/2026 05:00	0.9	1.5	0	0.55	0.27348	0.91
09/15/2026 06:00	1.0	1.5	0	0.55	0.27342	0.91
09/15/2026 07:00	1.0	1.5	-1	0.54	0.26802	0.89
09/15/2026 08:00	0.9	1.5	-1	0.55	0.27378	0.91
09/15/2026 09:00	0.9	1.5	-1	0.55	0.27318	0.91
09/15/2026 10:00	0.9	1.5	-1	0.52	0.26022	0.87
09/15/2026 11:00	0.9	1.5	-1	0.55	0.27360	0.91
09/15/2026 12:00	0.8	1.5	-1	0.53	0.26616	0.89
09/15/2026 13:00	0.9	1.5	-1	0.53	0.26634	0.89
09/15/2026 14:00	0.9	1.5	-1	0.53	0.26604	0.89
09/15/2026 15:00	0.9	1.5	-1	0.53	0.26418	0.88
09/15/2026 16:00	0.9	1.5	-1	0.47	0.23526	0.78
09/15/2026 17:00	0.9	1.5	-1	0.45	0.22560	0.75
09/15/2026 18:00	1.0	1.5	-1	0.45	0.22434	0.75
09/15/2026 19:00	1.0	1.5	-1	0.45	0.22458	0.75
09/15/2026 20:00	1.0	1.5	-1	0.45	0.22512	0.75
09/15/2026 21:00	1.0	1.5	-1	0.45	0.22542	0.75
09/15/2026 22:00	1.0	1.5	-1	0.45	0.22548	0.75
09/15/2026 23:00	1.0	1.5	-1	0.45	0.22566	0.75
Average/Sum#:	1.0	1.5	-1	0.49	0.24669	0.82
Minimum:	0.8	1.5	-1	0.45	0.22434	0.75
Maximum:	1.1	1.5	0	0.55	0.27378	0.91
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/16/2026 00:00	1.0	1.5	-1	0.45	0.22578	0.75
09/16/2026 01:00	1.0	1.5	-1	0.45	0.22596	0.75
09/16/2026 02:00	1.0	1.5	-1	0.45	0.22614	0.75
09/16/2026 03:00	1.1	1.5	-1	0.45	0.22638	0.75
09/16/2026 04:00	1.0	1.5	-1	0.45	0.22662	0.76
09/16/2026 05:00	1.1	1.5	-1	0.45	0.22698	0.76
09/16/2026 06:00	1.0	1.5	-1	0.46	0.23112	0.77
09/16/2026 07:00	0.0	0.0	0	0.45	0.22362	0.75
09/16/2026 08:00	0.0	0.0	0	0.00	0.00000	0.00
09/16/2026 09:00	0.0	0.0	0	0.00	0.00000	0.00
09/16/2026 10:00	0.0	0.0	0	0.00	0.00000	0.00
09/16/2026 11:00	0.0	0.0	0	0.00	0.00000	0.00
09/16/2026 12:00	0.0	0.0	0	0.00	0.00000	0.00
09/16/2026 13:00	0.0	0.0	0	0.00	0.00000	0.00
09/16/2026 14:00	0.0	0.0	0	0.03	0.01302	0.04
09/16/2026 15:00	0.6	1.6	0	0.39	0.19428	0.65
09/16/2026 16:00	0.6	1.5	-1	0.45	0.22566	0.75
09/16/2026 17:00	0.6	1.5	-1	0.45	0.22548	0.75
09/16/2026 18:00	0.6	1.5	-1	0.45	0.22584	0.75
09/16/2026 19:00	0.6	1.5	-1	0.45	0.22608	0.75
09/16/2026 20:00	0.6	1.5	-1	0.45	0.22632	0.75
09/16/2026 21:00	0.6	1.5	-1	0.45	0.22650	0.76
09/16/2026 22:00	0.6	1.5	-1	0.45	0.22668	0.76
09/16/2026 23:00	0.6	1.5	-1	0.45	0.22662	0.76
Average/Sum#:	0.7	1.4	-1	0.42	0.21273	0.71
Minimum:	0.0	0.0	-1	0.03	0.01302	0.04
Maximum:	1.1	1.6	0	0.46	0.23112	0.77
%SI	29.17	29.17	33.33	25.00	25.00	25.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/17/2026 00:00	0.6	1.5	-1	0.45	0.22668	0.76
09/17/2026 01:00	0.6	1.5	-1	0.45	0.22674	0.76
09/17/2026 02:00	0.7	1.5	-1	0.45	0.22698	0.76
09/17/2026 03:00	0.7	1.5	-1	0.45	0.22698	0.76
09/17/2026 04:00	0.7	1.5	-1	0.45	0.22686	0.76
09/17/2026 05:00	0.6	1.5	-1	0.50	0.25074	0.84
09/17/2026 06:00	0.6	1.5	-1	0.50	0.24882	0.83
09/17/2026 07:00	0.6	1.5	-1	0.45	0.22662	0.76
09/17/2026 08:00	0.6	1.5	-1	0.45	0.22656	0.76
09/17/2026 09:00	0.6	1.5	-1	0.45	0.22662	0.76
09/17/2026 10:00	0.6	1.5	-1	0.45	0.22638	0.75
09/17/2026 11:00	0.6	1.5	-1	0.45	0.22608	0.75
09/17/2026 12:00	0.6	1.5	-1	0.45	0.22590	0.75
09/17/2026 13:00	0.6	1.5	-1	0.45	0.22590	0.75
09/17/2026 14:00	0.6	1.5	-1	0.45	0.22572	0.75
09/17/2026 15:00	0.6	1.5	-1	0.45	0.22572	0.75
09/17/2026 16:00	0.6	1.5	-1	0.47	0.23520	0.78
09/17/2026 17:00	0.6	1.5	-1	0.45	0.22572	0.75
09/17/2026 18:00	0.6	1.5	-1	0.45	0.22584	0.75
09/17/2026 19:00	0.6	1.5	-1	0.45	0.22596	0.75
09/17/2026 20:00	0.6	1.5	-1	0.45	0.22620	0.75
09/17/2026 21:00	0.7	1.5	-1	0.45	0.22632	0.75
09/17/2026 22:00	0.7	1.5	-1	0.45	0.22626	0.75
09/17/2026 23:00	0.7	1.5	-1	0.45	0.22638	0.75
Average/Sum#:	0.6	1.5	-1	0.46	0.22863	0.76
Minimum:	0.6	1.5	-1	0.45	0.22572	0.75
Maximum:	0.7	1.5	-1	0.50	0.25074	0.84
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/18/2026 00:00	0.7	1.5	-1	0.45	0.22650	0.76
09/18/2026 01:00	0.7	1.5	-1	0.45	0.22662	0.76
09/18/2026 02:00	0.7	1.5	-1	0.45	0.22662	0.76
09/18/2026 03:00	0.7	1.5	-1	0.45	0.22674	0.76
09/18/2026 04:00	0.7	1.5	-1	0.45	0.22692	0.76
09/18/2026 05:00	0.7	1.5	-1	0.45	0.22692	0.76
09/18/2026 06:00	0.7	1.5	0	0.50	0.24996	0.83
09/18/2026 07:00	0.7	1.5	-1	0.46	0.22800	0.76
09/18/2026 08:00	0.7	1.5	-1	0.45	0.22650	0.76
09/18/2026 09:00	0.6	1.5	-1	0.45	0.22614	0.75
09/18/2026 10:00	0.6	1.5	-1	0.45	0.22602	0.75
09/18/2026 11:00	0.6	1.5	-1	0.45	0.22560	0.75
09/18/2026 12:00	0.6	1.5	-1	0.45	0.22542	0.75
09/18/2026 13:00	0.6	1.5	-1	0.45	0.22656	0.76
09/18/2026 14:00	0.6	1.5	-1	0.45	0.22494	0.75
09/18/2026 15:00	0.6	1.5	-1	0.45	0.22494	0.75
09/18/2026 16:00	0.6	1.5	-1	0.51	0.25698	0.86
09/18/2026 17:00	0.6	1.5	-1	0.55	0.27360	0.91
09/18/2026 18:00	0.6	1.5	-1	0.45	0.22620	0.75
09/18/2026 19:00	0.6	1.5	-1	0.45	0.22506	0.75
09/18/2026 20:00	0.6	1.5	-1	0.45	0.22542	0.75
09/18/2026 21:00	0.7	1.5	-1	0.45	0.22572	0.75
09/18/2026 22:00	0.7	1.5	-1	0.45	0.22602	0.75
09/18/2026 23:00	0.7	1.5	-1	0.45	0.22608	0.75
Average/Sum#:	0.7	1.5	-1	0.46	0.23040	0.77
Minimum:	0.6	1.5	-1	0.45	0.22494	0.75
Maximum:	0.7	1.5	0	0.55	0.27360	0.91
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/19/2026 00:00	0.7	1.5	-1	0.45	0.22626	0.75
09/19/2026 01:00	0.7	1.5	-1	0.45	0.22638	0.75
09/19/2026 02:00	0.7	1.5	-1	0.45	0.22650	0.76
09/19/2026 03:00	0.7	1.5	-1	0.45	0.22632	0.75
09/19/2026 04:00	0.7	1.5	-1	0.45	0.22644	0.75
09/19/2026 05:00	0.7	1.5	-1	0.45	0.22644	0.75
09/19/2026 06:00	0.7	1.5	-1	0.45	0.22638	0.75
09/19/2026 07:00	0.7	1.5	-1	0.45	0.22638	0.75
09/19/2026 08:00	0.7	1.5	-1	0.45	0.22602	0.75
09/19/2026 09:00	0.6	1.5	-1	0.45	0.22584	0.75
09/19/2026 10:00	0.6	1.5	-1	0.45	0.22560	0.75
09/19/2026 11:00	0.6	1.5	-1	0.45	0.22518	0.75
09/19/2026 12:00	0.6	1.5	-1	0.45	0.22506	0.75
09/19/2026 13:00	0.6	1.5	-1	0.45	0.22494	0.75
09/19/2026 14:00	0.6	1.5	-1	0.45	0.22458	0.75
09/19/2026 15:00	0.6	1.5	-1	0.45	0.22446	0.75
09/19/2026 16:00	0.6	1.5	-1	0.46	0.23226	0.77
09/19/2026 17:00	0.6	1.5	-1	0.45	0.22410	0.75
09/19/2026 18:00	0.6	1.5	-1	0.45	0.22476	0.75
09/19/2026 19:00	0.6	1.5	-1	0.45	0.22524	0.75
09/19/2026 20:00	0.7	1.5	-1	0.45	0.22536	0.75
09/19/2026 21:00	0.7	1.5	-1	0.46	0.22896	0.76
09/19/2026 22:00	0.7	1.5	-1	0.48	0.23808	0.79
09/19/2026 23:00	0.7	1.5	-1	0.47	0.23418	0.78
Average/Sum#:	0.7	1.5	-1	0.45	0.22691	0.75
Minimum:	0.6	1.5	-1	0.45	0.22410	0.75
Maximum:	0.7	1.5	-1	0.48	0.23808	0.79
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/20/2026 00:00	0.7	1.5	-1	0.46	0.23238	0.77
09/20/2026 01:00	0.7	1.5	-1	0.45	0.22584	0.75
09/20/2026 02:00	0.7	1.5	-1	0.45	0.22596	0.75
09/20/2026 03:00	0.7	1.5	-1	0.45	0.22608	0.75
09/20/2026 04:00	0.7	1.5	-1	0.45	0.22620	0.75
09/20/2026 05:00	0.7	1.5	-1	0.45	0.22650	0.76
09/20/2026 06:00	0.7	1.5	-1	0.45	0.22710	0.76
09/20/2026 07:00	0.7	1.5	-1	0.45	0.22650	0.76
09/20/2026 08:00	0.7	1.5	-1	0.45	0.22626	0.75
09/20/2026 09:00	0.7	1.5	-1	0.45	0.22590	0.75
09/20/2026 10:00	0.6	1.5	-1	0.45	0.22554	0.75
09/20/2026 11:00	0.6	1.5	-1	0.45	0.22548	0.75
09/20/2026 12:00	0.6	1.5	-1	0.45	0.22530	0.75
09/20/2026 13:00	0.6	1.5	-1	0.50	0.24930	0.83
09/20/2026 14:00	0.6	1.5	-1	0.55	0.27438	0.91
09/20/2026 15:00	0.6	1.5	-1	0.54	0.26838	0.89
09/20/2026 16:00	0.6	1.5	-1	0.52	0.25932	0.86
09/20/2026 17:00	0.6	1.5	-1	0.45	0.22644	0.75
09/20/2026 18:00	0.6	1.5	-1	0.45	0.22530	0.75
09/20/2026 19:00	0.7	1.5	-1	0.45	0.22572	0.75
09/20/2026 20:00	0.7	1.5	-1	0.45	0.22578	0.75
09/20/2026 21:00	0.7	1.5	-1	0.45	0.22578	0.75
09/20/2026 22:00	0.7	1.5	-1	0.45	0.22590	0.75
09/20/2026 23:00	0.7	1.5	-1	0.46	0.22974	0.77
Average/Sum#:	0.7	1.5	-1	0.46	0.23255	0.77
Minimum:	0.6	1.5	-1	0.45	0.22530	0.75
Maximum:	0.7	1.5	-1	0.55	0.27438	0.91
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/21/2026 00:00	0.7	1.5	-1	0.45	0.22578	0.75
09/21/2026 01:00	0.7	1.5	-1	0.45	0.22596	0.75
09/21/2026 02:00	0.7	1.5	-1	0.45	0.22614	0.75
09/21/2026 03:00	0.7	1.5	-1	0.45	0.22614	0.75
09/21/2026 04:00	0.7	1.5	-1	0.48	0.23838	0.79
09/21/2026 05:00	0.6	1.5	0	0.53	0.26712	0.89
09/21/2026 06:00	0.6	1.5	0	0.52	0.26040	0.87
09/21/2026 07:00	0.6	1.5	-1	0.51	0.25740	0.86
09/21/2026 08:00	0.6	1.5	-1	0.49	0.24402	0.81
09/21/2026 09:00	0.7	1.5	-1	0.45	0.22650	0.76
09/21/2026 10:00	0.6	1.5	-1	0.45	0.22626	0.75
09/21/2026 11:00	0.6	1.5	-1	0.45	0.22590	0.75
09/21/2026 12:00	0.6	1.5	-1	0.45	0.22572	0.75
09/21/2026 13:00	0.6	1.5	-1	0.45	0.22548	0.75
09/21/2026 14:00	0.6	1.5	-1	0.47	0.23298	0.78
09/21/2026 15:00	0.6	1.5	-1	0.45	0.22512	0.75
09/21/2026 16:00	0.6	1.5	-1	0.47	0.23442	0.78
09/21/2026 17:00	0.6	1.5	-1	0.45	0.22530	0.75
09/21/2026 18:00	0.6	1.5	-1	0.45	0.22566	0.75
09/21/2026 19:00	0.6	1.5	-1	0.45	0.22590	0.75
09/21/2026 20:00	0.6	1.5	-1	0.45	0.22608	0.75
09/21/2026 21:00	0.6	1.5	-1	0.45	0.22626	0.75
09/21/2026 22:00	0.6	1.5	-1	0.45	0.22632	0.75
09/21/2026 23:00	0.6	1.5	-1	0.45	0.22644	0.75
Average/Sum#:	0.6	1.5	-1	0.46	0.23232	0.77
Minimum:	0.6	1.5	-1	0.45	0.22512	0.75
Maximum:	0.7	1.5	0	0.53	0.26712	0.89
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/22/2026 00:00	0.7	1.5	-1	0.45	0.22644	0.75
09/22/2026 01:00	0.6	1.5	-1	0.45	0.22662	0.76
09/22/2026 02:00	0.6	1.5	-1	0.45	0.22680	0.76
09/22/2026 03:00	0.7	1.5	-1	0.45	0.22692	0.76
09/22/2026 04:00	0.7	1.5	-1	0.45	0.22698	0.76
09/22/2026 05:00	0.7	1.5	-1	0.46	0.22752	0.76
09/22/2026 06:00	0.7	1.5	-1	0.47	0.23658	0.79
09/22/2026 07:00	0.7	1.5	-1	0.45	0.22722	0.76
09/22/2026 08:00	0.6	1.5	-1	0.45	0.22698	0.76
09/22/2026 09:00	0.7	1.5	-1	0.45	0.22656	0.76
09/22/2026 10:00	0.6	1.5	-1	0.45	0.22608	0.75
09/22/2026 11:00	0.6	1.5	-1	0.45	0.22578	0.75
09/22/2026 12:00	0.6	1.5	-1	0.45	0.22560	0.75
09/22/2026 13:00	0.6	1.5	-1	0.45	0.22512	0.75
09/22/2026 14:00	0.6	1.5	-1	0.45	0.22500	0.75
09/22/2026 15:00	0.6	1.5	-1	0.45	0.22494	0.75
09/22/2026 16:00	0.6	1.5	-1	0.46	0.23010	0.77
09/22/2026 17:00	0.6	1.5	-1	0.45	0.22470	0.75
09/22/2026 18:00	0.6	1.5	-1	0.45	0.22494	0.75
09/22/2026 19:00	0.6	1.5	-1	0.45	0.22554	0.75
09/22/2026 20:00	0.6	1.5	-1	0.45	0.22578	0.75
09/22/2026 21:00	0.8	1.5	0	0.52	0.26004	0.87
09/22/2026 22:00	1.2	1.5	0	0.62	0.31194	1.04
09/22/2026 23:00	0.7	1.5	-1	0.48	0.23994	0.80
Average/Sum#:	0.7	1.5	-1	0.46	0.23226	0.78
Minimum:	0.6	1.5	-1	0.45	0.22470	0.75
Maximum:	1.2	1.5	0	0.62	0.31194	1.04
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/23/2026 00:00	0.7	1.5	-1	0.45	0.22650	0.76
09/23/2026 01:00	0.7	1.5	-1	0.45	0.22680	0.76
09/23/2026 02:00	0.7	1.5	-1	0.45	0.22668	0.76
09/23/2026 03:00	0.7	1.5	-1	0.45	0.22692	0.76
09/23/2026 04:00	0.7	1.5	-1	0.46	0.22932	0.76
09/23/2026 05:00	0.7	1.5	-1	0.50	0.25062	0.84
09/23/2026 06:00	0.7	1.5	-1	0.49	0.24420	0.81
09/23/2026 07:00	0.7	1.5	-1	0.45	0.22680	0.76
09/23/2026 08:00	0.7	1.5	-1	0.45	0.22644	0.75
09/23/2026 09:00	0.7	1.5	-1	0.45	0.22596	0.75
09/23/2026 10:00	0.6	1.5	-1	0.45	0.22578	0.75
09/23/2026 11:00	0.6	1.5	-1	0.45	0.22536	0.75
09/23/2026 12:00	0.6	1.5	-1	0.45	0.22500	0.75
09/23/2026 13:00	0.6	1.5	-1	0.46	0.23046	0.77
09/23/2026 14:00	0.6	1.5	-1	0.45	0.22704	0.76
09/23/2026 15:00	0.7	1.5	-1	0.47	0.23454	0.78
09/23/2026 16:00	0.6	1.5	-1	0.50	0.24822	0.83
09/23/2026 17:00	0.6	1.5	-1	0.45	0.22716	0.76
09/23/2026 18:00	0.6	1.5	-1	0.45	0.22488	0.75
09/23/2026 19:00	0.6	1.5	-1	0.54	0.27240	0.91
09/23/2026 20:00	0.7	1.5	-1	0.49	0.24708	0.82
09/23/2026 21:00	0.7	1.5	-1	0.46	0.22998	0.77
09/23/2026 22:00	0.7	1.5	-1	0.45	0.22590	0.75
09/23/2026 23:00	0.8	1.5	-1	0.45	0.22614	0.75
Average/Sum#:	0.7	1.5	-1	0.46	0.23251	0.78
Minimum:	0.6	1.5	-1	0.45	0.22488	0.75
Maximum:	0.8	1.5	-1	0.54	0.27240	0.91
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/24/2026 00:00	0.9	1.5	-1	0.45	0.22638	0.75
09/24/2026 01:00	0.8	1.5	-1	0.45	0.22602	0.75
09/24/2026 02:00	0.7	1.5	-1	0.45	0.22620	0.75
09/24/2026 03:00	0.7	1.5	-1	0.45	0.22602	0.75
09/24/2026 04:00	0.7	1.5	-1	0.46	0.22824	0.76
09/24/2026 05:00	0.8	1.5	-1	0.51	0.25476	0.85
09/24/2026 06:00	0.8	1.5	-1	0.50	0.24936	0.83
09/24/2026 07:00	0.8	1.5	-1	0.45	0.22626	0.75
09/24/2026 08:00	0.7	1.5	-1	0.45	0.22584	0.75
09/24/2026 09:00	0.7	1.5	-1	0.45	0.22542	0.75
09/24/2026 10:00	0.6	1.5	-1	0.45	0.22500	0.75
09/24/2026 11:00	0.6	1.5	-1	0.45	0.22476	0.75
09/24/2026 12:00	0.6	1.5	-1	0.45	0.22470	0.75
09/24/2026 13:00	0.6	1.5	-1	0.49	0.24342	0.81
09/24/2026 14:00	0.6	1.5	-1	0.50	0.25080	0.84
09/24/2026 15:00	0.5	1.5	-1	0.51	0.25398	0.85
09/24/2026 16:00	0.6	1.5	-1	0.50	0.25104	0.84
09/24/2026 17:00	0.7	1.5	0	0.56	0.28188	0.94
09/24/2026 18:00	0.6	1.5	0	0.66	0.33090	1.10
09/24/2026 19:00	0.6	1.5	-1	0.48	0.23796	0.79
09/24/2026 20:00	0.6	1.5	-1	0.45	0.22476	0.75
09/24/2026 21:00	0.6	1.5	-1	0.45	0.22500	0.75
09/24/2026 22:00	0.6	1.5	-1	0.45	0.22530	0.75
09/24/2026 23:00	0.7	1.5	-1	0.45	0.22536	0.75
Average/Sum#:	0.7	1.5	-1	0.48	0.23914	0.80
Minimum:	0.5	1.5	-1	0.45	0.22470	0.75
Maximum:	0.9	1.5	0	0.66	0.33090	1.10
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/25/2026 00:00	0.7	1.5	-1	0.45	0.22536	0.75
09/25/2026 01:00	0.7	1.5	-1	0.45	0.22548	0.75
09/25/2026 02:00	0.7	1.5	-1	0.45	0.22554	0.75
09/25/2026 03:00	0.7	1.5	-1	0.45	0.22572	0.75
09/25/2026 04:00	0.7	1.5	-1	0.45	0.22578	0.75
09/25/2026 05:00	0.7	1.5	-1	0.46	0.22776	0.76
09/25/2026 06:00	0.7	1.5	-1	0.47	0.23478	0.78
09/25/2026 07:00	0.7	1.5	-1	0.47	0.23646	0.79
09/25/2026 08:00	0.7	1.5	-1	0.45	0.22512	0.75
09/25/2026 09:00	0.6	1.5	-1	0.45	0.22488	0.75
09/25/2026 10:00	0.6	1.5	-1	0.45	0.22470	0.75
09/25/2026 11:00	0.6	1.5	-1	0.45	0.22410	0.75
09/25/2026 12:00	0.6	1.5	-1	0.45	0.22362	0.75
09/25/2026 13:00	0.6	1.5	-1	0.45	0.22344	0.74
09/25/2026 14:00	0.6	1.5	-1	0.45	0.22326	0.74
09/25/2026 15:00	0.6	1.5	-1	0.45	0.22308	0.74
09/25/2026 16:00	0.6	1.5	-1	0.46	0.22800	0.76
09/25/2026 17:00	0.6	1.5	-1	0.45	0.22356	0.75
09/25/2026 18:00	0.6	1.5	-1	0.45	0.22404	0.75
09/25/2026 19:00	0.6	1.5	-1	0.45	0.22434	0.75
09/25/2026 20:00	0.7	1.5	-1	0.45	0.22470	0.75
09/25/2026 21:00	0.7	1.5	-1	0.45	0.22488	0.75
09/25/2026 22:00	0.7	1.5	-1	0.45	0.22500	0.75
09/25/2026 23:00	0.7	1.5	-1	0.45	0.22500	0.75
Average/Sum#:	0.7	1.5	-1	0.45	0.22578	0.75
Minimum:	0.6	1.5	-1	0.45	0.22308	0.74
Maximum:	0.7	1.5	-1	0.47	0.23646	0.79
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/26/2026 00:00	0.7	1.5	-1	0.45	0.22518	0.75
09/26/2026 01:00	0.7	1.5	-1	0.45	0.22548	0.75
09/26/2026 02:00	0.7	1.5	-1	0.45	0.22560	0.75
09/26/2026 03:00	0.7	1.5	-1	0.45	0.22554	0.75
09/26/2026 04:00	0.7	1.5	-1	0.45	0.22542	0.75
09/26/2026 05:00	0.7	1.5	-1	0.45	0.22560	0.75
09/26/2026 06:00	0.7	1.5	-1	0.45	0.22560	0.75
09/26/2026 07:00	0.7	1.5	-1	0.45	0.22578	0.75
09/26/2026 08:00	0.7	1.5	-1	0.45	0.22590	0.75
09/26/2026 09:00	0.7	1.5	-1	0.45	0.22560	0.75
09/26/2026 10:00	0.6	1.5	-1	0.45	0.22548	0.75
09/26/2026 11:00	0.6	1.5	-1	0.45	0.22512	0.75
09/26/2026 12:00	0.6	1.5	-1	0.45	0.22488	0.75
09/26/2026 13:00	0.6	1.5	-1	0.45	0.22452	0.75
09/26/2026 14:00	0.6	1.5	-1	0.45	0.22434	0.75
09/26/2026 15:00	0.6	1.5	-1	0.45	0.22416	0.75
09/26/2026 16:00	0.6	1.5	-1	0.50	0.25194	0.84
09/26/2026 17:00	0.5	1.5	-1	0.55	0.27462	0.92
09/26/2026 18:00	0.6	1.5	-1	0.49	0.24702	0.82
09/26/2026 19:00	0.6	1.5	0	0.55	0.27444	0.91
09/26/2026 20:00	0.6	1.5	-1	0.55	0.27288	0.91
09/26/2026 21:00	0.7	1.5	0	0.55	0.27294	0.91
09/26/2026 22:00	0.8	1.5	0	0.56	0.27966	0.93
09/26/2026 23:00	0.2	1.5	1	0.76	0.37752	1.26
Average/Sum#:	0.6	1.5	-1	0.49	0.24397	0.81
Minimum:	0.2	1.5	-1	0.45	0.22416	0.75
Maximum:	0.8	1.5	1	0.76	0.37752	1.26
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/27/2026 00:00	1.0	1.5	0	0.63	0.31398	1.05
09/27/2026 01:00	0.9	1.5	0	0.56	0.27804	0.93
09/27/2026 02:00	0.6	1.4	-1	0.51	0.25656	0.86
09/27/2026 03:00	0.7	1.4	0	0.48	0.24126	0.80
09/27/2026 04:00	0.7	1.5	-1	0.46	0.22950	0.77
09/27/2026 05:00	0.7	1.5	0	0.49	0.24690	0.82
09/27/2026 06:00	0.6	1.5	0	0.54	0.27006	0.90
09/27/2026 07:00	0.6	1.5	0	0.54	0.27012	0.90
09/27/2026 08:00	0.7	1.5	-1	0.48	0.23880	0.80
09/27/2026 09:00	0.7	1.5	-1	0.45	0.22590	0.75
09/27/2026 10:00	0.7	1.5	-1	0.45	0.22578	0.75
09/27/2026 11:00	0.7	1.5	-1	0.45	0.22566	0.75
09/27/2026 12:00	0.7	1.5	-1	0.45	0.22512	0.75
09/27/2026 13:00	0.7	1.5	-1	0.45	0.22470	0.75
09/27/2026 14:00	0.6	1.5	-1	0.45	0.22746	0.76
09/27/2026 15:00	0.6	1.5	-1	0.48	0.23766	0.79
09/27/2026 16:00	0.8	1.5	-1	0.52	0.26130	0.87
09/27/2026 17:00	0.2	1.5	0	0.74	0.36750	1.23
09/27/2026 18:00	0.2	1.5	0	0.73	0.36354	1.21
09/27/2026 19:00	0.3	1.5	1	0.73	0.36294	1.21
09/27/2026 20:00	0.4	1.5	0	0.71	0.35544	1.18
09/27/2026 21:00	1.0	1.5	0	0.64	0.31986	1.07
09/27/2026 22:00	1.2	1.5	0	0.60	0.29796	0.99
09/27/2026 23:00	0.6	1.5	-1	0.51	0.25446	0.85
Average/Sum#:	0.7	1.5	0	0.54	0.27169	0.91
Minimum:	0.2	1.4	-1	0.45	0.22470	0.75
Maximum:	1.2	1.5	1	0.74	0.36750	1.23
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/28/2026 00:00	0.6	1.5	-1	0.50	0.25056	0.84
09/28/2026 01:00	0.7	1.5	-1	0.45	0.22674	0.76
09/28/2026 02:00	0.7	1.6	-1	0.48	0.24030	0.80
09/28/2026 03:00	1.2	1.6	0	0.52	0.26064	0.87
09/28/2026 04:00	1.9	1.5	0	0.61	0.30336	1.01
09/28/2026 05:00	1.7	1.5	0	0.62	0.31206	1.04
09/28/2026 06:00	1.1	1.5	0	0.62	0.31212	1.04
09/28/2026 07:00	0.7	1.5	-1	0.49	0.24570	0.82
09/28/2026 08:00	0.7	1.5	-1	0.45	0.22590	0.75
09/28/2026 09:00	0.7	1.5	-1	0.45	0.22560	0.75
09/28/2026 10:00	0.7	1.5	-1	0.45	0.22524	0.75
09/28/2026 11:00	0.7	1.5	-1	0.45	0.22494	0.75
09/28/2026 12:00	0.6	1.5	-1	0.45	0.22476	0.75
09/28/2026 13:00	0.6	1.5	-1	0.45	0.22452	0.75
09/28/2026 14:00	0.6	1.5	-1	0.45	0.22422	0.75
09/28/2026 15:00	0.6	1.5	-1	0.45	0.22392	0.75
09/28/2026 16:00	0.6	1.5	-1	0.45	0.22476	0.75
09/28/2026 17:00	0.6	1.5	-1	0.45	0.22356	0.75
09/28/2026 18:00	0.6	1.5	-1	0.45	0.22380	0.75
09/28/2026 19:00	0.7	1.5	-1	0.45	0.22440	0.75
09/28/2026 20:00	0.7	1.5	-1	0.45	0.22464	0.75
09/28/2026 21:00	0.8	1.5	-1	0.45	0.22482	0.75
09/28/2026 22:00	0.7	1.5	-1	0.45	0.22500	0.75
09/28/2026 23:00	0.7	1.5	-1	0.45	0.22524	0.75
Average/Sum#:	0.8	1.5	-1	0.48	0.23945	0.80
Minimum:	0.6	1.5	-1	0.45	0.22356	0.75
Maximum:	1.9	1.6	0	0.62	0.31212	1.04
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/29/2026 00:00	0.8	1.5	-1	0.45	0.22542	0.75
09/29/2026 01:00	0.8	1.5	0	0.45	0.22542	0.75
09/29/2026 02:00	0.8	1.5	0	0.45	0.22554	0.75
09/29/2026 03:00	0.8	1.5	0	0.45	0.22554	0.75
09/29/2026 04:00	0.8	1.5	0	0.45	0.22566	0.75
09/29/2026 05:00	0.8	1.5	0	0.45	0.22584	0.75
09/29/2026 06:00	0.8	1.5	-1	0.45	0.22584	0.75
09/29/2026 07:00	0.8	1.5	-1	0.45	0.22554	0.75
09/29/2026 08:00	0.7	1.5	-1	0.45	0.22506	0.75
09/29/2026 09:00	0.7	1.5	-1	0.45	0.22446	0.75
09/29/2026 10:00	0.7	1.5	-1	0.45	0.22392	0.75
09/29/2026 11:00	0.6	1.5	-1	0.45	0.22368	0.75
09/29/2026 12:00	0.6	1.5	-1	0.45	0.22332	0.74
09/29/2026 13:00	0.6	1.5	-1	0.45	0.22284	0.74
09/29/2026 14:00	0.7	1.5	-1	0.45	0.22272	0.74
09/29/2026 15:00	0.6	1.5	-1	0.45	0.22278	0.74
09/29/2026 16:00	0.6	1.5	-1	0.46	0.23064	0.77
09/29/2026 17:00	0.6	1.4	-1	0.45	0.22422	0.75
09/29/2026 18:00	0.6	1.5	-1	0.45	0.22362	0.75
09/29/2026 19:00	0.7	1.5	-1	0.45	0.22380	0.75
09/29/2026 20:00	0.7	1.5	-1	0.45	0.22422	0.75
09/29/2026 21:00	0.7	1.5	-1	0.45	0.22434	0.75
09/29/2026 22:00	0.7	1.5	-1	0.45	0.22458	0.75
09/29/2026 23:00	0.7	1.5	0	0.55	0.27378	0.91
Average/Sum#:	0.7	1.5	-1	0.45	0.22678	0.76
Minimum:	0.6	1.4	-1	0.45	0.22272	0.74
Maximum:	0.8	1.5	0	0.55	0.27378	0.91
%SI	0.00	0.00	0.00	0.00	0.00	0.00

AQ57 CT2 HOURLY EMISSIONS

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 12:57 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 PM10, LbPerHr 1 Hour(s)	Unit CT2 SO2, LbPerHr 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)
09/30/2026 00:00	0.7	1.5	-1	0.45	0.22446	0.75
09/30/2026 01:00	0.7	1.5	-1	0.45	0.22590	0.75
09/30/2026 02:00	0.7	1.5	-1	0.48	0.23928	0.80
09/30/2026 03:00	1.4	1.6	0	0.59	0.29400	0.98
09/30/2026 04:00	1.3	1.5	0	0.62	0.30906	1.03
09/30/2026 05:00	0.8	1.5	1	0.70	0.35142	1.17
09/30/2026 06:00	0.7	1.5	0	0.57	0.28566	0.95
09/30/2026 07:00	0.8	1.5	-1	0.45	0.22536	0.75
09/30/2026 08:00	0.7	1.5	-1	0.45	0.22692	0.76
09/30/2026 09:00	0.7	1.5	-1	0.45	0.22392	0.75
09/30/2026 10:00	0.7	1.5	-1	0.46	0.23244	0.77
09/30/2026 11:00	0.7	1.5	-1	0.49	0.24714	0.82
09/30/2026 12:00	0.8	1.5	0	0.54	0.27006	0.90
09/30/2026 13:00	0.8	1.5	0	0.63	0.31404	1.05
09/30/2026 14:00	0.3	1.5	1	0.74	0.36828	1.23
09/30/2026 15:00	0.1	1.5	1	0.74	0.37206	1.24
09/30/2026 16:00	0.2	1.5	1	0.74	0.36762	1.23
09/30/2026 17:00	0.2	1.5	1	0.71	0.35742	1.19
09/30/2026 18:00	0.4	1.5	0	0.63	0.31608	1.05
09/30/2026 19:00	0.7	1.5	0	0.59	0.29520	0.98
09/30/2026 20:00	0.8	1.5	0	0.56	0.27750	0.93
09/30/2026 21:00	0.8	1.5	0	0.63	0.31386	1.05
09/30/2026 22:00	0.8	1.5	-1	0.48	0.23892	0.80
09/30/2026 23:00	0.7	1.5	-1	0.49	0.24282	0.81
Average/Sum#:	0.7	1.5	0	0.57	0.28414	0.95
Minimum:	0.1	1.5	-1	0.45	0.22392	0.75
Maximum:	1.4	1.6	1	0.74	0.37206	1.24
%SI	0.00	0.00	0.00	0.00	0.00	0.00