DOCKETED	
Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	273237
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q3 2026 - Part 7s
Description:	N/A
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public Agency
Submission Date:	10/28/2026 7:52:54 AM
Docketed Date:	10/28/2026

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/01/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	0.00	100.00	100.00	100.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/02/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 23:00	0.0	0.0	43.3	172.9	17.0	209.6	0.35	0.35
Average/Sum#:	0.0	0.0	1.8	172.9	17.0	209.6	0.35 #	0.35 #
Minimum:	0.0	0.0	0.0	172.9	17.0	209.6	0.00	0.00
Maximum:	0.0	0.0	43.3	172.9	17.0	209.6	0.35	0.35
%SI	95.83	100.00	0.00	95.83	95.83	95.83	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/03/2026 00:00	0.7	0.0	0.5	0.9	14.2	373.6	0.72	1.00
07/03/2026 01:00	0.7	0.0	0.0	0.8	14.2	357.6	0.00	1.00
07/03/2026 02:00	0.8	0.6	0.0	0.9	14.2	355.9	0.00	1.00
07/03/2026 03:00	0.8	0.6	0.0	0.9	14.2	355.7	0.00	1.00
07/03/2026 04:00	0.7	0.6	18.1	86.1	14.7	295.2	0.18	0.35
07/03/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.7	0.6	0.8	17.9	14.3	347.6	0.90 #	4.35 #
Minimum:	0.7	0.6	0.0	0.8	14.2	295.2	0.00	0.00
Maximum:	0.8	0.6	18.1	86.1	14.7	373.6	0.72	1.00
%SI	79.17	87.50	8.33	79.17	79.17	79.17	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/04/2026 00:00	0.0	0.0	49.7	191.6	17.0	206.7	0.35	0.35
07/04/2026 01:00	0.7	0.0	0.4	0.8	14.2	371.3	0.67	1.00
07/04/2026 02:00	0.7	0.0	0.0	0.8	14.2	358.5	0.00	1.00
07/04/2026 03:00	0.8	0.6	0.0	0.9	14.2	355.2	0.00	1.00
07/04/2026 04:00	0.7	0.6	0.0	0.8	14.2	355.7	0.00	1.00
07/04/2026 05:00	0.7	0.6	16.2	92.5	14.8	289.2	0.18	0.33
07/04/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 18:00	0.0	0.0	53.4	131.8	16.0	275.9	0.60	0.60
07/04/2026 19:00	0.6	0.0	0.3	0.8	13.8	456.7	0.47	1.00
07/04/2026 20:00	0.7	0.0	0.0	0.8	14.0	427.1	0.00	1.00
07/04/2026 21:00	0.6	0.6	0.0	0.7	14.3	355.1	0.00	1.00
07/04/2026 22:00	0.7	0.6	0.0	0.8	14.3	370.3	0.00	1.00
07/04/2026 23:00	0.6	0.6	0.0	0.7	14.4	412.7	0.00	1.00
Average/Sum#:	0.6	0.6	5.2	35.3	14.6	352.9	2.27 #	10.28 #
Minimum:	0.0	0.6	0.0	0.7	13.8	206.7	0.00	0.00
Maximum:	0.8	0.6	53.4	191.6	17.0	456.7	0.67	1.00
%SI	50.00	75.00	4.17	50.00	50.00	50.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/05/2026 00:00	0.7	0.6	14.7	34.6	14.5	341.9	0.18	0.77
07/05/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.7	0.6	0.6	34.6	14.5	341.9	0.18 #	0.77 #
Minimum:	0.7	0.6	0.0	34.6	14.5	341.9	0.00	0.00
Maximum:	0.7	0.6	14.7	34.6	14.5	341.9	0.18	0.77
%SI	95.83	95.83	0.00	95.83	95.83	95.83	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/06/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	0.00	100.00	100.00	100.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/07/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	0.00	100.00	100.00	100.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/08/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	0.00	100.00	100.00	100.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/09/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	0.00	100.00	100.00	100.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/10/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 16:00	0.0	0.0	40.0	62.2	15.4	308.1	0.85	0.85
07/10/2026 17:00	0.8	0.0	0.1	1.0	13.7	486.7	0.13	1.00
07/10/2026 18:00	0.6	0.0	0.0	0.7	13.0	534.2	0.00	1.00
07/10/2026 19:00	0.5	0.7	0.0	0.7	13.2	524.2	0.00	1.00
07/10/2026 20:00	0.9	0.8	0.0	1.1	13.7	501.9	0.00	1.00
07/10/2026 21:00	1.1	0.9	0.0	1.3	13.8	498.3	0.00	1.00
07/10/2026 22:00	1.2	1.2	0.0	1.4	13.8	497.3	0.00	1.00
07/10/2026 23:00	1.2	1.3	0.0	1.4	13.9	495.6	0.00	1.00
Average/Sum#:	0.8	1.0	1.7	8.7	13.8	480.8	0.98 #	7.85 #
Minimum:	0.0	0.7	0.0	0.7	13.0	308.1	0.00	0.00
Maximum:	1.2	1.3	40.0	62.2	15.4	534.2	0.85	1.00
%SI	66.67	79.17	4.17	66.67	66.67	66.67	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/11/2026 00:00	1.3	1.4	0.0	1.5	13.9	493.5	0.00	1.00
07/11/2026 01:00	1.3	1.4	0.0	1.5	14.0	491.6	0.00	1.00
07/11/2026 02:00	1.7	1.6	0.0	2.0	14.0	489.2	0.00	1.00
07/11/2026 03:00	1.9	1.8	0.0	2.2	14.0	488.5	0.00	1.00
07/11/2026 04:00	1.5	1.8	0.0	1.7	14.1	450.3	0.00	1.00
07/11/2026 05:00	0.9	1.4	20.7	58.9	14.6	318.0	0.18	0.52
07/11/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 15:00	0.0	0.0	0.0	0.1	21.0	61.9	0.02	0.02
07/11/2026 16:00	0.7	0.0	41.2	57.6	15.1	317.6	0.82	1.00
07/11/2026 17:00	0.7	0.0	0.0	0.9	13.4	500.0	0.00	1.00
07/11/2026 18:00	0.9	0.8	0.0	1.1	13.6	507.6	0.00	1.00
07/11/2026 19:00	1.0	1.0	0.0	1.2	13.7	501.7	0.00	1.00
07/11/2026 20:00	0.8	1.0	0.0	1.0	13.5	508.6	0.00	1.00
07/11/2026 21:00	0.7	0.9	0.0	0.9	13.2	530.0	0.00	1.00
07/11/2026 22:00	1.0	0.9	0.0	1.2	13.6	506.5	0.00	1.00
07/11/2026 23:00	0.6	0.9	0.0	0.7	12.8	566.7	0.00	1.00
Average/Sum#:	1.0	1.2	2.7	8.8	14.3	448.8	1.02 #	13.54 #
Minimum:	0.0	0.8	0.0	0.1	12.8	61.9	0.00	0.00
Maximum:	1.9	1.8	41.2	58.9	21.0	566.7	0.82	1.00
%SI	37.50	50.00	4.17	37.50	37.50	37.50	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/12/2026 00:00	1.0	1.0	0.0	1.2	13.7	500.5	0.00	1.00
07/12/2026 01:00	1.1	1.0	0.0	1.3	13.7	498.2	0.00	1.00
07/12/2026 02:00	1.1	1.2	0.0	1.3	13.8	498.0	0.00	1.00
07/12/2026 03:00	1.1	1.2	0.0	1.3	13.8	498.4	0.00	1.00
07/12/2026 04:00	1.0	1.2	0.0	1.2	13.8	497.9	0.00	1.00
07/12/2026 05:00	1.1	1.2	0.0	1.3	13.8	497.1	0.00	1.00
07/12/2026 06:00	1.0	1.2	0.0	1.3	13.8	503.2	0.00	1.00
07/12/2026 07:00	0.6	1.0	0.0	0.8	12.9	562.2	0.00	1.00
07/12/2026 08:00	0.4	0.8	0.0	0.5	12.5	587.8	0.00	1.00
07/12/2026 09:00	0.7	0.7	0.0	0.9	13.5	517.8	0.00	1.00
07/12/2026 10:00	0.9	0.8	0.0	1.1	13.7	501.3	0.00	1.00
07/12/2026 11:00	0.8	0.9	0.0	1.0	13.6	507.4	0.00	1.00
07/12/2026 12:00	0.6	0.9	0.0	0.8	13.3	512.3	0.00	1.00
07/12/2026 13:00	0.4	0.7	0.0	0.5	12.6	561.8	0.00	1.00
07/12/2026 14:00	0.3	0.5	0.0	0.5	12.5	592.6	0.00	1.00
07/12/2026 15:00	0.3	0.4	0.0	0.4	12.0	624.9	0.00	1.00
07/12/2026 16:00	0.3	0.4	0.0	0.4	12.0	623.8	0.00	1.00
07/12/2026 17:00	0.6	0.5	0.0	0.8	13.0	552.7	0.00	1.00
07/12/2026 18:00	0.8	0.7	0.0	1.0	13.5	517.7	0.00	1.00
07/12/2026 19:00	0.3	0.7	0.0	0.4	12.2	614.9	0.00	1.00
07/12/2026 20:00	0.3	0.6	0.0	0.4	12.0	631.2	0.00	1.00
07/12/2026 21:00	0.3	0.4	0.0	0.4	12.0	628.5	0.00	1.00
07/12/2026 22:00	0.6	0.5	0.0	0.8	12.8	562.8	0.00	1.00
07/12/2026 23:00	0.9	0.7	0.0	1.0	14.3	377.0	0.00	1.00
Average/Sum#:	0.7	0.8	0.0	0.9	13.1	540.4	0.00 #	24.00 #
Minimum:	0.3	0.4	0.0	0.4	12.0	377.0	0.00	1.00
Maximum:	1.1	1.2	0.0	1.3	14.3	631.2	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/13/2026 00:00	0.8	0.8	0.0	0.9	14.3	389.0	0.00	1.00
07/13/2026 01:00	0.8	0.8	0.0	0.9	14.4	433.2	0.00	1.00
07/13/2026 02:00	0.8	0.8	0.0	0.9	14.4	433.4	0.00	1.00
07/13/2026 03:00	0.9	0.8	0.0	1.0	14.4	425.7	0.00	1.00
07/13/2026 04:00	0.8	0.8	0.0	0.9	14.4	432.0	0.00	1.00
07/13/2026 05:00	0.9	0.8	0.0	1.0	14.2	404.7	0.00	1.00
07/13/2026 06:00	0.9	0.8	0.0	1.0	14.3	432.0	0.00	1.00
07/13/2026 07:00	0.9	0.9	0.0	1.0	14.4	427.7	0.00	1.00
07/13/2026 08:00	0.6	0.8	0.0	0.8	12.8	558.7	0.00	1.00
07/13/2026 09:00	0.3	0.7	0.0	0.4	11.8	641.3	0.00	1.00
07/13/2026 10:00	0.3	0.5	0.0	0.4	11.8	637.3	0.00	1.00
07/13/2026 11:00	0.3	0.4	0.0	0.4	11.8	636.1	0.00	1.00
07/13/2026 12:00	0.3	0.4	0.0	0.4	11.8	635.2	0.00	1.00
07/13/2026 13:00	0.3	0.4	0.0	0.4	11.8	638.1	0.00	1.00
07/13/2026 14:00	0.3	0.4	0.0	0.4	11.8	636.5	0.00	1.00
07/13/2026 15:00	0.3	0.4	0.0	0.4	11.8	637.0	0.00	1.00
07/13/2026 16:00	0.3	0.4	0.0	0.4	11.8	636.3	0.00	1.00
07/13/2026 17:00	0.3	0.4	0.0	0.4	11.8	629.6	0.00	1.00
07/13/2026 18:00	0.3	0.4	0.0	0.4	11.9	628.6	0.00	1.00
07/13/2026 19:00	0.3	0.4	0.0	0.4	11.8	632.9	0.00	1.00
07/13/2026 20:00	0.3	0.4	0.0	0.4	11.9	629.6	0.00	1.00
07/13/2026 21:00	0.3	0.4	0.0	0.5	12.2	613.8	0.00	1.00
07/13/2026 22:00	0.8	0.6	0.0	1.0	13.3	536.0	0.00	1.00
07/13/2026 23:00	1.0	0.8	0.0	1.3	13.6	509.7	0.00	1.00
Average/Sum#:	0.5	0.6	0.0	0.7	12.9	550.6	0.00 #	24.00 #
Minimum:	0.3	0.4	0.0	0.4	11.8	389.0	0.00	1.00
Maximum:	1.0	0.9	0.0	1.3	14.4	641.3	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/14/2026 00:00	0.7	1.0	0.0	0.9	13.2	539.5	0.00	1.00
07/14/2026 01:00	1.0	1.1	0.0	1.2	13.7	501.4	0.00	1.00
07/14/2026 02:00	1.0	1.0	0.0	1.2	13.6	503.4	0.00	1.00
07/14/2026 03:00	1.0	1.1	0.0	1.2	13.7	500.5	0.00	1.00
07/14/2026 04:00	1.1	1.1	0.0	1.3	13.7	499.9	0.00	1.00
07/14/2026 05:00	0.9	1.1	0.0	1.1	13.3	530.6	0.00	1.00
07/14/2026 06:00	1.1	1.1	0.0	1.3	13.8	496.8	0.00	1.00
07/14/2026 07:00	0.9	1.1	0.0	1.1	13.7	501.9	0.00	1.00
07/14/2026 08:00	0.7	1.0	0.0	0.9	13.5	506.8	0.00	1.00
07/14/2026 09:00	0.5	0.8	0.0	0.7	13.1	514.8	0.00	1.00
07/14/2026 10:00	0.4	0.6	0.0	0.5	12.8	522.9	0.00	1.00
07/14/2026 11:00	0.3	0.4	0.0	0.4	12.5	533.3	0.00	1.00
07/14/2026 12:00	0.5	0.4	0.0	0.7	13.1	534.5	0.00	1.00
07/14/2026 13:00	0.5	0.5	0.0	0.7	12.8	565.4	0.00	1.00
07/14/2026 14:00	0.3	0.5	0.0	0.4	12.2	605.3	0.00	1.00
07/14/2026 15:00	0.2	0.4	0.0	0.3	11.9	621.8	0.00	1.00
07/14/2026 16:00	0.3	0.4	0.0	0.4	12.0	616.9	0.00	1.00
07/14/2026 17:00	0.2	0.3	0.0	0.3	11.9	627.0	0.00	1.00
07/14/2026 18:00	0.3	0.3	0.0	0.4	11.9	623.2	0.00	1.00
07/14/2026 19:00	0.2	0.3	0.0	0.3	12.1	605.1	0.00	1.00
07/14/2026 20:00	0.4	0.3	0.0	0.5	12.6	579.6	0.00	1.00
07/14/2026 21:00	0.3	0.4	0.0	0.5	12.4	590.4	0.00	1.00
07/14/2026 22:00	0.8	0.6	0.0	1.0	13.3	529.0	0.00	1.00
07/14/2026 23:00	1.2	0.9	0.0	1.5	13.8	494.0	0.00	1.00
Average/Sum#:	0.6	0.7	0.0	0.8	12.9	547.7	0.00 #	24.00 #
Minimum:	0.2	0.3	0.0	0.3	11.9	494.0	0.00	1.00
Maximum:	1.2	1.1	0.0	1.5	13.8	627.0	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/15/2026 00:00	1.0	1.1	0.0	1.2	13.6	497.9	0.00	1.00
07/15/2026 01:00	0.9	1.1	0.0	1.1	13.6	500.2	0.00	1.00
07/15/2026 02:00	0.9	1.0	0.0	1.1	13.6	497.2	0.00	1.00
07/15/2026 03:00	1.1	1.0	0.0	1.3	13.7	495.8	0.00	1.00
07/15/2026 04:00	1.1	1.1	0.0	1.3	13.7	495.7	0.00	1.00
07/15/2026 05:00	1.1	1.2	0.0	1.3	13.7	496.2	0.00	1.00
07/15/2026 06:00	1.0	1.1	0.0	1.2	13.7	500.2	0.00	1.00
07/15/2026 07:00	0.8	1.1	0.0	1.0	13.6	505.8	0.00	1.00
07/15/2026 08:00	0.6	0.9	0.0	0.8	13.3	511.1	0.00	1.00
07/15/2026 09:00	0.4	0.7	0.0	0.6	13.0	523.2	0.00	1.00
07/15/2026 10:00	0.3	0.5	0.0	0.4	11.9	620.8	0.00	1.00
07/15/2026 11:00	0.3	0.4	0.0	0.4	11.9	626.9	0.00	1.00
07/15/2026 12:00	0.4	0.4	0.0	0.6	12.6	575.0	0.00	1.00
07/15/2026 13:00	0.2	0.4	0.0	0.4	12.3	597.3	0.00	1.00
07/15/2026 14:00	0.3	0.4	0.0	0.4	11.7	637.0	0.00	1.00
07/15/2026 15:00	0.2	0.3	0.0	0.3	11.9	617.7	0.00	1.00
07/15/2026 16:00	0.3	0.3	0.0	0.4	11.7	638.6	0.00	1.00
07/15/2026 17:00	0.2	0.3	0.0	0.3	11.8	629.9	0.00	1.00
07/15/2026 18:00	0.2	0.3	0.0	0.3	11.8	633.3	0.00	1.00
07/15/2026 19:00	0.3	0.3	0.0	0.4	12.1	617.2	0.00	1.00
07/15/2026 20:00	0.3	0.3	0.0	0.5	12.4	596.7	0.00	1.00
07/15/2026 21:00	0.5	0.5	0.0	0.7	12.7	574.4	0.00	1.00
07/15/2026 22:00	0.8	0.7	0.0	1.0	13.3	522.6	0.00	1.00
07/15/2026 23:00	0.9	0.9	0.0	1.1	13.5	510.9	0.00	1.00
Average/Sum#:	0.6	0.7	0.0	0.8	12.8	559.2	0.00 #	24.00 #
Minimum:	0.2	0.3	0.0	0.3	11.7	495.7	0.00	1.00
Maximum:	1.1	1.2	0.0	1.3	13.7	638.6	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/16/2026 00:00	1.0	1.0	0.0	1.2	13.6	509.4	0.00	1.00
07/16/2026 01:00	1.0	1.1	0.0	1.2	13.7	503.8	0.00	1.00
07/16/2026 02:00	1.2	1.2	0.0	1.4	13.8	496.4	0.00	1.00
07/16/2026 03:00	1.3	1.3	0.0	1.6	13.9	494.2	0.00	1.00
07/16/2026 04:00	1.3	1.4	0.0	1.6	13.9	494.6	0.00	1.00
07/16/2026 05:00	1.3	1.5	0.0	1.6	13.9	494.6	0.00	1.00
07/16/2026 06:00	1.3	1.5	0.0	1.5	13.9	494.7	0.00	1.00
07/16/2026 07:00	1.2	1.4	0.0	1.4	13.8	498.6	0.00	1.00
07/16/2026 08:00	1.0	1.3	0.0	1.2	13.7	501.8	0.00	1.00
07/16/2026 09:00	0.8	1.1	0.0	1.0	13.6	504.8	0.00	1.00
07/16/2026 10:00	0.7	0.9	0.0	0.9	13.4	510.2	0.00	1.00
07/16/2026 11:00	0.5	0.8	0.0	0.7	13.2	518.8	0.00	1.00
07/16/2026 12:00	0.3	0.6	0.0	0.4	12.8	527.5	0.00	1.00
07/16/2026 13:00	0.3	0.4	0.0	0.4	12.6	532.0	0.00	1.00
07/16/2026 14:00	0.2	0.3	0.0	0.3	12.5	534.0	0.00	1.00
07/16/2026 15:00	0.2	0.2	0.0	0.3	12.3	535.1	0.00	1.00
07/16/2026 16:00	0.2	0.2	0.0	0.3	12.4	532.8	0.00	1.00
07/16/2026 17:00	0.3	0.2	0.0	0.4	12.6	532.4	0.00	1.00
07/16/2026 18:00	0.4	0.3	0.0	0.5	13.0	519.5	0.00	1.00
07/16/2026 19:00	0.6	0.5	0.0	0.8	13.4	507.5	0.00	1.00
07/16/2026 20:00	0.9	0.7	0.0	1.1	13.6	501.6	0.00	1.00
07/16/2026 21:00	1.0	0.9	0.0	1.2	13.7	499.2	0.00	1.00
07/16/2026 22:00	1.1	1.1	0.0	1.3	13.8	497.7	0.00	1.00
07/16/2026 23:00	1.2	1.2	0.0	1.5	13.9	495.5	0.00	1.00
Average/Sum#:	0.8	0.9	0.0	1.0	13.4	509.9	0.00 #	24.00 #
Minimum:	0.2	0.2	0.0	0.3	12.3	494.2	0.00	1.00
Maximum:	1.3	1.5	0.0	1.6	13.9	535.1	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/17/2026 00:00	1.3	1.4	0.0	1.6	13.9	494.7	0.00	1.00
07/17/2026 01:00	1.3	1.5	0.0	1.6	13.9	493.2	0.00	1.00
07/17/2026 02:00	1.3	1.5	0.0	1.6	13.9	493.2	0.00	1.00
07/17/2026 03:00	1.4	1.5	0.0	1.6	14.0	492.9	0.00	1.00
07/17/2026 04:00	1.5	1.6	0.0	1.8	14.0	491.2	0.00	1.00
07/17/2026 05:00	1.7	1.7	0.0	2.0	14.0	490.6	0.00	1.00
07/17/2026 06:00	1.6	1.8	0.0	1.9	14.0	493.0	0.00	1.00
07/17/2026 07:00	1.4	1.7	0.0	1.6	13.9	496.8	0.00	1.00
07/17/2026 08:00	1.2	1.5	0.0	1.4	13.8	500.0	0.00	1.00
07/17/2026 09:00	1.0	1.3	0.0	1.2	13.8	501.4	0.00	1.00
07/17/2026 10:00	0.9	1.1	0.0	1.1	13.7	504.8	0.00	1.00
07/17/2026 11:00	0.7	1.0	0.0	0.9	13.5	511.6	0.00	1.00
07/17/2026 12:00	0.5	0.8	0.0	0.7	13.2	519.2	0.00	1.00
07/17/2026 13:00	0.4	0.6	0.0	0.5	12.9	525.4	0.00	1.00
07/17/2026 14:00	0.3	0.4	0.0	0.4	12.6	528.9	0.00	1.00
07/17/2026 15:00	0.2	0.3	0.0	0.3	12.6	530.7	0.00	1.00
07/17/2026 16:00	0.2	0.3	0.0	0.3	12.6	530.1	0.00	1.00
07/17/2026 17:00	0.3	0.3	0.0	0.4	12.8	525.4	0.00	1.00
07/17/2026 18:00	0.5	0.4	0.0	0.7	13.3	514.5	0.00	1.00
07/17/2026 19:00	0.7	0.6	0.0	0.9	13.6	502.7	0.00	1.00
07/17/2026 20:00	1.0	0.9	0.0	1.2	13.8	496.9	0.00	1.00
07/17/2026 21:00	1.2	1.1	0.0	1.4	13.8	495.0	0.00	1.00
07/17/2026 22:00	1.3	1.3	0.0	1.5	13.9	493.1	0.00	1.00
07/17/2026 23:00	1.3	1.4	0.0	1.6	13.9	492.2	0.00	1.00
Average/Sum#:	1.0	1.1	0.0	1.2	13.6	504.9	0.00 #	24.00 #
Minimum:	0.2	0.3	0.0	0.3	12.6	490.6	0.00	1.00
Maximum:	1.7	1.8	0.0	2.0	14.0	530.7	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/18/2026 00:00	1.6	1.5	0.0	1.8	14.0	490.6	0.00	1.00
07/18/2026 01:00	1.7	1.7	0.0	2.0	14.0	488.7	0.00	1.00
07/18/2026 02:00	1.9	1.9	0.0	2.2	14.1	487.0	0.00	1.00
07/18/2026 03:00	2.0	2.0	0.0	2.3	14.1	487.3	0.00	1.00
07/18/2026 04:00	1.9	2.1	0.0	2.2	14.1	488.8	0.00	1.00
07/18/2026 05:00	1.9	2.1	0.0	2.2	13.9	503.8	0.00	1.00
07/18/2026 06:00	2.1	2.2	0.0	2.4	14.1	489.6	0.00	1.00
07/18/2026 07:00	1.8	2.1	0.0	2.1	14.1	490.5	0.00	1.00
07/18/2026 08:00	1.6	2.0	0.0	1.9	14.0	494.8	0.00	1.00
07/18/2026 09:00	1.3	1.7	0.0	1.5	13.9	498.4	0.00	1.00
07/18/2026 10:00	1.1	1.5	0.0	1.3	13.8	500.7	0.00	1.00
07/18/2026 11:00	0.9	1.2	0.0	1.1	14.0	431.0	0.00	1.00
07/18/2026 12:00	0.7	0.9	0.0	0.8	14.4	356.0	0.00	1.00
07/18/2026 13:00	0.8	0.7	0.0	0.9	14.4	378.4	0.00	1.00
07/18/2026 14:00	0.5	0.6	0.0	0.6	13.1	522.6	0.00	1.00
07/18/2026 15:00	0.4	0.6	0.0	0.5	12.9	525.2	0.00	1.00
07/18/2026 16:00	0.3	0.5	0.0	0.4	12.8	527.0	0.00	1.00
07/18/2026 17:00	0.3	0.4	0.0	0.4	12.8	526.1	0.00	1.00
07/18/2026 18:00	0.4	0.4	0.0	0.5	13.0	520.6	0.00	1.00
07/18/2026 19:00	0.6	0.5	0.0	0.8	13.5	509.2	0.00	1.00
07/18/2026 20:00	0.8	0.7	0.0	1.0	13.6	503.7	0.00	1.00
07/18/2026 21:00	0.9	0.9	0.0	1.1	13.7	502.1	0.00	1.00
07/18/2026 22:00	1.1	1.0	0.0	1.3	13.7	500.5	0.00	1.00
07/18/2026 23:00	1.2	1.2	0.0	1.4	13.8	498.8	0.00	1.00
Average/Sum#:	1.2	1.3	0.0	1.4	13.7	488.4	0.00 #	24.00 #
Minimum:	0.3	0.4	0.0	0.4	12.8	356.0	0.00	1.00
Maximum:	2.1	2.2	0.0	2.4	14.4	527.0	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/19/2026 00:00	1.2	1.3	0.0	1.5	13.8	496.5	0.00	1.00
07/19/2026 01:00	1.3	1.4	0.0	1.6	13.9	494.0	0.00	1.00
07/19/2026 02:00	1.3	1.5	0.0	1.6	13.9	492.3	0.00	1.00
07/19/2026 03:00	1.7	1.6	0.0	2.0	14.0	490.2	0.00	1.00
07/19/2026 04:00	1.8	1.7	0.0	2.1	14.0	488.1	0.00	1.00
07/19/2026 05:00	1.8	1.9	0.0	2.1	14.0	487.9	0.00	1.00
07/19/2026 06:00	1.6	1.9	0.0	1.9	14.0	490.2	0.00	1.00
07/19/2026 07:00	1.5	1.8	0.0	1.7	14.0	493.8	0.00	1.00
07/19/2026 08:00	1.2	1.6	0.0	1.4	13.9	497.0	0.00	1.00
07/19/2026 09:00	1.0	1.3	0.0	1.2	13.8	499.7	0.00	1.00
07/19/2026 10:00	0.8	1.1	0.0	1.0	13.7	505.5	0.00	1.00
07/19/2026 11:00	0.7	1.0	0.0	0.9	13.4	516.6	0.00	1.00
07/19/2026 12:00	0.5	0.8	0.0	0.6	13.0	524.2	0.00	1.00
07/19/2026 13:00	0.4	0.6	0.0	0.5	12.8	528.7	0.00	1.00
07/19/2026 14:00	0.4	0.5	0.0	0.5	12.7	532.1	0.00	1.00
07/19/2026 15:00	0.3	0.4	0.0	0.4	12.5	536.4	0.00	1.00
07/19/2026 16:00	0.2	0.3	0.0	0.3	12.5	539.7	0.00	1.00
07/19/2026 17:00	0.2	0.3	0.0	0.3	12.1	585.4	0.00	1.00
07/19/2026 18:00	0.3	0.3	0.0	0.4	12.5	592.0	0.00	1.00
07/19/2026 19:00	0.4	0.4	0.0	0.6	12.8	574.5	0.00	1.00
07/19/2026 20:00	0.3	0.4	0.0	0.4	12.2	621.5	0.00	1.00
07/19/2026 21:00	0.3	0.5	0.0	0.5	12.1	623.8	0.00	1.00
07/19/2026 22:00	0.3	0.5	0.0	0.5	12.2	618.2	0.00	1.00
07/19/2026 23:00	0.4	0.5	0.0	0.6	12.2	616.0	0.00	1.00
Average/Sum#:	0.8	1.0	0.0	1.0	13.2	535.2	0.00 #	24.00 #
Minimum:	0.2	0.3	0.0	0.3	12.1	487.9	0.00	1.00
Maximum:	1.8	1.9	0.0	2.1	14.0	623.8	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/20/2026 00:00	0.9	0.7	0.0	1.1	13.3	538.3	0.00	1.00
07/20/2026 01:00	1.3	1.0	0.0	1.5	13.8	497.4	0.00	1.00
07/20/2026 02:00	1.0	1.2	0.0	1.2	13.5	521.9	0.00	1.00
07/20/2026 03:00	0.4	1.0	0.0	0.6	12.1	622.8	0.00	1.00
07/20/2026 04:00	0.3	0.7	0.0	0.5	12.0	632.9	0.00	1.00
07/20/2026 05:00	0.3	0.5	0.0	0.5	12.0	630.0	0.00	1.00
07/20/2026 06:00	0.3	0.5	0.0	0.5	12.2	617.1	0.00	1.00
07/20/2026 07:00	0.4	0.5	0.0	0.5	12.4	603.9	0.00	1.00
07/20/2026 08:00	0.4	0.5	0.0	0.5	12.3	607.6	0.00	1.00
07/20/2026 09:00	0.4	0.5	0.0	0.5	12.6	586.8	0.00	1.00
07/20/2026 10:00	0.3	0.5	0.0	0.4	12.2	614.9	0.00	1.00
07/20/2026 11:00	0.3	0.4	0.0	0.4	12.3	609.1	0.00	1.00
07/20/2026 12:00	0.3	0.4	0.0	0.4	12.5	597.4	0.00	1.00
07/20/2026 13:00	0.2	0.4	0.0	0.3	12.2	617.8	0.00	1.00
07/20/2026 14:00	0.3	0.4	0.0	0.4	12.5	592.2	0.00	1.00
07/20/2026 15:00	0.3	0.4	0.0	0.4	12.5	593.2	0.00	1.00
07/20/2026 16:00	0.3	0.4	0.0	0.4	12.3	602.5	0.00	1.00
07/20/2026 17:00	0.3	0.4	0.0	0.4	12.4	601.5	0.00	1.00
07/20/2026 18:00	0.2	0.4	0.0	0.3	12.2	617.8	0.00	1.00
07/20/2026 19:00	0.3	0.4	0.0	0.4	12.4	606.3	0.00	1.00
07/20/2026 20:00	0.3	0.4	0.0	0.4	12.2	613.9	0.00	1.00
07/20/2026 21:00	0.4	0.4	0.0	0.5	12.5	598.1	0.00	1.00
07/20/2026 22:00	0.8	0.6	0.0	0.9	13.3	535.7	0.00	1.00
07/20/2026 23:00	0.5	0.6	0.0	0.7	12.9	550.2	0.00	1.00
Average/Sum#:	0.4	0.6	0.0	0.6	12.5	592.1	0.00 #	24.00 #
Minimum:	0.2	0.4	0.0	0.3	12.0	497.4	0.00	1.00
Maximum:	1.3	1.2	0.0	1.5	13.8	632.9	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/21/2026 00:00	0.9	0.8	0.0	1.1	13.6	502.9	0.00	1.00
07/21/2026 01:00	0.9	0.9	0.0	1.1	13.6	503.3	0.00	1.00
07/21/2026 02:00	1.0	1.0	0.0	1.2	13.6	503.2	0.00	1.00
07/21/2026 03:00	1.0	1.1	0.0	1.2	13.7	501.7	0.00	1.00
07/21/2026 04:00	0.9	1.1	0.0	1.0	13.4	526.4	0.00	1.00
07/21/2026 05:00	0.4	0.9	0.0	0.5	12.5	596.0	0.00	1.00
07/21/2026 06:00	0.7	0.8	0.0	0.8	13.1	542.7	0.00	1.00
07/21/2026 07:00	0.7	0.7	0.0	0.9	13.4	523.5	0.00	1.00
07/21/2026 08:00	0.6	0.8	0.0	0.8	13.2	537.8	0.00	1.00
07/21/2026 09:00	0.6	0.8	0.0	0.8	13.2	519.3	0.00	1.00
07/21/2026 10:00	0.4	0.6	0.0	0.5	12.7	530.7	0.00	1.00
07/21/2026 11:00	0.3	0.5	0.0	0.4	12.3	569.9	0.00	1.00
07/21/2026 12:00	0.3	0.4	0.0	0.4	12.0	625.2	0.00	1.00
07/21/2026 13:00	0.3	0.4	0.0	0.4	12.1	614.9	0.00	1.00
07/21/2026 14:00	0.3	0.4	0.0	0.4	12.0	620.7	0.00	1.00
07/21/2026 15:00	0.3	0.4	0.0	0.4	11.8	629.7	0.00	1.00
07/21/2026 16:00	0.2	0.3	0.0	0.3	12.0	617.3	0.00	1.00
07/21/2026 17:00	0.2	0.3	0.0	0.3	11.9	626.4	0.00	1.00
07/21/2026 18:00	0.3	0.3	0.0	0.4	11.7	638.9	0.00	1.00
07/21/2026 19:00	0.3	0.4	0.0	0.4	11.7	636.7	0.00	1.00
07/21/2026 20:00	0.2	0.4	0.0	0.3	11.9	630.5	0.00	1.00
07/21/2026 21:00	0.3	0.3	0.0	0.4	12.1	617.8	0.00	1.00
07/21/2026 22:00	0.4	0.4	0.0	0.5	12.3	602.7	0.00	1.00
07/21/2026 23:00	0.5	0.5	0.0	0.7	12.5	589.5	0.00	1.00
Average/Sum#:	0.5	0.6	0.0	0.6	12.6	575.3	0.00 #	24.00 #
Minimum:	0.2	0.3	0.0	0.3	11.7	501.7	0.00	1.00
Maximum:	1.0	1.1	0.0	1.2	13.7	638.9	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/22/2026 00:00	1.1	0.8	0.0	1.3	13.7	496.7	0.00	1.00
07/22/2026 01:00	1.0	1.0	0.0	1.2	13.7	497.3	0.00	1.00
07/22/2026 02:00	1.1	1.2	0.0	1.4	13.7	495.5	0.00	1.00
07/22/2026 03:00	1.3	1.3	0.0	1.6	13.8	494.0	0.00	1.00
07/22/2026 04:00	1.2	1.3	0.0	1.4	13.7	499.4	0.00	1.00
07/22/2026 05:00	0.8	1.2	0.0	1.1	13.3	528.2	0.00	1.00
07/22/2026 06:00	1.2	1.2	0.0	1.4	13.8	495.1	0.00	1.00
07/22/2026 07:00	1.0	1.1	0.0	1.2	13.7	508.8	0.00	1.00
07/22/2026 08:00	0.6	1.0	0.0	0.7	13.1	546.0	0.00	1.00
07/22/2026 09:00	1.0	1.0	0.0	1.2	13.7	498.3	0.00	1.00
07/22/2026 10:00	0.8	0.9	0.0	1.0	13.7	501.4	0.00	1.00
07/22/2026 11:00	0.7	1.0	0.0	0.9	13.6	505.7	0.00	1.00
07/22/2026 12:00	0.7	0.9	0.0	0.9	13.5	508.4	0.00	1.00
07/22/2026 13:00	0.6	0.8	0.0	0.8	13.4	511.4	0.00	1.00
07/22/2026 14:00	0.5	0.7	0.0	0.7	13.2	514.2	0.00	1.00
07/22/2026 15:00	0.5	0.6	0.0	0.7	13.2	515.1	0.00	1.00
07/22/2026 16:00	0.5	0.6	0.0	0.6	13.1	514.3	0.00	1.00
07/22/2026 17:00	0.5	0.6	0.0	0.7	13.2	512.7	0.00	1.00
07/22/2026 18:00	0.6	0.6	0.0	0.8	13.4	507.1	0.00	1.00
07/22/2026 19:00	0.8	0.7	0.0	1.0	13.6	499.4	0.00	1.00
07/22/2026 20:00	1.1	0.9	0.0	1.3	13.8	493.2	0.00	1.00
07/22/2026 21:00	1.2	1.1	0.0	1.5	13.8	489.7	0.00	1.00
07/22/2026 22:00	1.3	1.3	0.0	1.5	13.9	488.5	0.00	1.00
07/22/2026 23:00	1.5	1.4	0.0	1.8	13.9	486.9	0.00	1.00
Average/Sum#:	0.9	1.0	0.0	1.1	13.6	504.5	0.00 #	24.00 #
Minimum:	0.5	0.6	0.0	0.6	13.1	486.9	0.00	1.00
Maximum:	1.5	1.4	0.0	1.8	13.9	546.0	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/23/2026 00:00	1.7	1.6	0.0	2.0	14.0	485.9	0.00	1.00
07/23/2026 01:00	1.7	1.8	0.0	2.0	14.0	486.0	0.00	1.00
07/23/2026 02:00	1.8	1.9	0.0	2.1	14.0	484.2	0.00	1.00
07/23/2026 03:00	1.9	2.0	0.0	2.2	14.0	484.6	0.00	1.00
07/23/2026 04:00	1.9	2.0	0.0	2.2	14.0	486.1	0.00	1.00
07/23/2026 05:00	1.8	2.0	0.0	2.1	14.0	486.9	0.00	1.00
07/23/2026 06:00	1.7	2.0	0.0	2.0	14.0	489.5	0.00	1.00
07/23/2026 07:00	1.6	1.9	0.0	1.9	13.9	493.1	0.00	1.00
07/23/2026 08:00	1.3	1.7	0.0	1.6	14.0	473.2	0.00	1.00
07/23/2026 09:00	0.9	1.3	0.0	1.0	14.2	357.4	0.00	1.00
07/23/2026 10:00	0.8	1.0	0.0	0.9	14.3	354.8	0.00	1.00
07/23/2026 11:00	0.8	0.8	0.0	1.0	14.0	438.7	0.00	1.00
07/23/2026 12:00	0.6	0.8	0.0	0.8	13.3	516.5	0.00	1.00
07/23/2026 13:00	0.5	0.7	0.0	0.7	13.1	521.2	0.00	1.00
07/23/2026 14:00	0.4	0.6	0.0	0.6	13.0	523.2	0.00	1.00
07/23/2026 15:00	0.4	0.5	0.0	0.5	12.8	525.2	0.00	1.00
07/23/2026 16:00	0.4	0.4	0.0	0.5	12.8	526.2	0.00	1.00
07/23/2026 17:00	0.4	0.4	0.0	0.5	12.8	528.1	0.00	1.00
07/23/2026 18:00	0.3	0.4	0.0	0.4	12.6	543.7	0.00	1.00
07/23/2026 19:00	0.6	0.5	0.0	0.8	13.3	515.7	0.00	1.00
07/23/2026 20:00	0.6	0.6	0.0	0.8	13.3	527.0	0.00	1.00
07/23/2026 21:00	1.0	0.8	0.0	1.2	13.7	500.2	0.00	1.00
07/23/2026 22:00	1.1	1.0	0.0	1.4	13.7	501.3	0.00	1.00
07/23/2026 23:00	1.2	1.2	0.0	1.4	13.7	503.2	0.00	1.00
Average/Sum#:	1.1	1.2	0.0	1.3	13.6	489.7	0.00 #	24.00 #
Minimum:	0.3	0.4	0.0	0.4	12.6	354.8	0.00	1.00
Maximum:	1.9	2.0	0.0	2.2	14.3	543.7	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/24/2026 00:00	1.3	1.3	0.0	1.6	13.9	492.0	0.00	1.00
07/24/2026 01:00	1.3	1.4	0.0	1.5	13.9	491.4	0.00	1.00
07/24/2026 02:00	1.3	1.4	0.0	1.5	13.9	490.6	0.00	1.00
07/24/2026 03:00	1.6	1.5	0.0	1.9	14.0	489.7	0.00	1.00
07/24/2026 04:00	1.8	1.7	0.0	2.1	14.0	487.9	0.00	1.00
07/24/2026 05:00	1.9	1.9	0.0	2.2	14.0	489.0	0.00	1.00
07/24/2026 06:00	1.6	1.9	0.0	1.9	13.9	491.9	0.00	1.00
07/24/2026 07:00	1.4	1.8	0.0	1.7	13.9	496.3	0.00	1.00
07/24/2026 08:00	1.2	1.6	0.0	1.4	13.8	499.7	0.00	1.00
07/24/2026 09:00	0.9	1.3	0.0	1.1	13.7	503.8	0.00	1.00
07/24/2026 10:00	0.8	1.1	0.0	1.0	13.5	508.4	0.00	1.00
07/24/2026 11:00	0.9	0.9	0.0	1.0	14.3	362.5	0.00	1.00
07/24/2026 12:00	1.0	0.9	0.0	1.2	13.7	458.1	0.00	1.00
07/24/2026 13:00	0.3	0.7	0.0	0.4	12.2	583.2	0.00	1.00
07/24/2026 14:00	0.3	0.6	0.0	0.4	11.9	631.3	0.00	1.00
07/24/2026 15:00	0.3	0.4	0.0	0.4	11.9	628.4	0.00	1.00
07/24/2026 16:00	0.4	0.4	0.0	0.5	12.7	565.9	0.00	1.00
07/24/2026 17:00	0.4	0.5	0.0	0.6	12.6	581.4	0.00	1.00
07/24/2026 18:00	0.3	0.5	0.0	0.5	12.5	593.7	0.00	1.00
07/24/2026 19:00	0.8	0.6	0.0	1.0	13.4	523.1	0.00	1.00
07/24/2026 20:00	0.9	0.8	0.0	1.2	13.4	524.8	0.00	1.00
07/24/2026 21:00	1.2	1.1	0.0	1.5	13.7	504.9	0.00	1.00
07/24/2026 22:00	1.7	1.4	0.0	2.0	14.0	490.1	0.00	1.00
07/24/2026 23:00	1.3	1.5	0.0	1.5	13.9	493.7	0.00	1.00
Average/Sum#:	1.0	1.1	0.0	1.3	13.4	515.9	0.00 #	24.00 #
Minimum:	0.3	0.4	0.0	0.4	11.9	362.5	0.00	1.00
Maximum:	1.9	1.9	0.0	2.2	14.3	631.3	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/25/2026 00:00	1.3	1.6	0.0	1.6	13.9	492.4	0.00	1.00
07/25/2026 01:00	1.4	1.5	0.0	1.7	13.9	491.2	0.00	1.00
07/25/2026 02:00	1.7	1.6	0.0	2.0	13.9	490.5	0.00	1.00
07/25/2026 03:00	1.8	1.8	0.0	2.1	14.0	489.7	0.00	1.00
07/25/2026 04:00	1.8	1.9	0.0	2.1	14.0	488.6	0.00	1.00
07/25/2026 05:00	1.9	2.0	0.0	2.2	14.0	488.5	0.00	1.00
07/25/2026 06:00	1.7	1.9	0.0	2.0	13.9	492.2	0.00	1.00
07/25/2026 07:00	1.4	1.8	0.0	1.7	13.9	496.4	0.00	1.00
07/25/2026 08:00	1.2	1.6	0.0	1.4	13.8	498.8	0.00	1.00
07/25/2026 09:00	1.0	1.3	0.0	1.2	13.7	503.7	0.00	1.00
07/25/2026 10:00	0.7	1.1	0.0	0.9	13.6	509.0	0.00	1.00
07/25/2026 11:00	0.6	0.9	0.0	0.8	13.3	517.1	0.00	1.00
07/25/2026 12:00	0.4	0.7	0.0	0.6	13.0	525.2	0.00	1.00
07/25/2026 13:00	0.4	0.5	0.0	0.5	12.8	530.1	0.00	1.00
07/25/2026 14:00	0.3	0.4	0.0	0.4	12.6	533.0	0.00	1.00
07/25/2026 15:00	0.3	0.3	0.0	0.4	12.5	533.8	0.00	1.00
07/25/2026 16:00	0.2	0.3	0.0	0.3	12.4	536.5	0.00	1.00
07/25/2026 17:00	0.2	0.3	0.0	0.3	12.4	535.2	0.00	1.00
07/25/2026 18:00	0.4	0.3	0.0	0.5	12.8	525.7	0.00	1.00
07/25/2026 19:00	0.5	0.4	0.0	0.7	13.2	513.0	0.00	1.00
07/25/2026 20:00	0.7	0.6	0.0	0.9	13.5	504.3	0.00	1.00
07/25/2026 21:00	1.0	0.8	0.0	1.2	13.6	499.4	0.00	1.00
07/25/2026 22:00	1.1	1.0	0.0	1.3	13.7	497.3	0.00	1.00
07/25/2026 23:00	1.2	1.2	0.0	1.4	13.8	495.3	0.00	1.00
Average/Sum#:	1.0	1.1	0.0	1.2	13.4	507.8	0.00 #	24.00 #
Minimum:	0.2	0.3	0.0	0.3	12.4	488.5	0.00	1.00
Maximum:	1.9	2.0	0.0	2.2	14.0	536.5	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/26/2026 00:00	1.2	1.3	0.0	1.5	13.8	494.8	0.00	1.00
07/26/2026 01:00	1.3	1.3	0.0	1.5	13.9	492.7	0.00	1.00
07/26/2026 02:00	1.3	1.4	0.0	1.6	13.9	490.0	0.00	1.00
07/26/2026 03:00	1.7	1.5	0.0	2.0	14.0	489.1	0.00	1.00
07/26/2026 04:00	1.7	1.7	0.0	2.0	14.0	488.9	0.00	1.00
07/26/2026 05:00	1.8	1.9	0.0	2.1	14.0	488.7	0.00	1.00
07/26/2026 06:00	1.6	1.9	0.0	1.9	14.0	490.2	0.00	1.00
07/26/2026 07:00	1.0	1.5	0.0	1.1	14.2	361.7	0.00	1.00
07/26/2026 08:00	1.0	1.2	0.0	1.2	14.1	439.6	0.00	1.00
07/26/2026 09:00	1.0	1.0	0.0	1.2	13.7	502.7	0.00	1.00
07/26/2026 10:00	0.8	1.0	0.0	1.0	13.6	507.6	0.00	1.00
07/26/2026 11:00	0.6	0.9	0.0	0.8	13.4	513.3	0.00	1.00
07/26/2026 12:00	0.5	0.8	0.0	0.6	13.1	522.1	0.00	1.00
07/26/2026 13:00	0.4	0.6	0.0	0.5	12.8	528.5	0.00	1.00
07/26/2026 14:00	0.3	0.4	0.0	0.4	12.6	532.3	0.00	1.00
07/26/2026 15:00	0.3	0.3	0.0	0.4	12.5	532.5	0.00	1.00
07/26/2026 16:00	0.3	0.3	0.0	0.4	12.5	532.9	0.00	1.00
07/26/2026 17:00	0.3	0.3	0.0	0.4	12.5	531.3	0.00	1.00
07/26/2026 18:00	0.4	0.4	0.0	0.6	13.0	521.2	0.00	1.00
07/26/2026 19:00	0.6	0.5	0.0	0.8	13.4	509.4	0.00	1.00
07/26/2026 20:00	0.8	0.7	0.0	1.0	13.5	510.0	0.00	1.00
07/26/2026 21:00	0.7	0.8	0.0	0.9	13.0	555.0	0.00	1.00
07/26/2026 22:00	0.8	0.9	0.0	1.0	13.0	550.8	0.00	1.00
07/26/2026 23:00	1.3	1.0	0.0	1.5	13.9	492.1	0.00	1.00
Average/Sum#:	0.9	1.0	0.0	1.1	13.4	503.2	0.00 #	24.00 #
Minimum:	0.3	0.3	0.0	0.4	12.5	361.7	0.00	1.00
Maximum:	1.8	1.9	0.0	2.1	14.2	555.0	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/27/2026 00:00	1.1	1.2	0.0	1.3	13.7	506.5	0.00	1.00
07/27/2026 01:00	1.5	1.4	0.0	1.7	14.0	488.3	0.00	1.00
07/27/2026 02:00	1.7	1.6	0.0	2.0	14.0	487.0	0.00	1.00
07/27/2026 03:00	1.8	1.8	0.0	2.1	14.0	486.8	0.00	1.00
07/27/2026 04:00	1.8	2.0	0.0	2.1	14.0	485.6	0.00	1.00
07/27/2026 05:00	1.9	2.0	0.0	2.2	14.1	484.5	0.00	1.00
07/27/2026 06:00	1.7	2.0	0.0	2.0	14.0	488.1	0.00	1.00
07/27/2026 07:00	1.5	1.9	0.0	1.8	13.9	492.4	0.00	1.00
07/27/2026 08:00	1.4	1.7	0.0	1.7	13.9	495.5	0.00	1.00
07/27/2026 09:00	1.0	1.4	0.0	1.2	13.7	500.4	0.00	1.00
07/27/2026 10:00	0.9	1.2	0.0	1.1	13.6	504.1	0.00	1.00
07/27/2026 11:00	0.7	1.0	0.0	0.9	13.5	512.8	0.00	1.00
07/27/2026 12:00	0.5	0.8	0.0	0.7	13.3	520.9	0.00	1.00
07/27/2026 13:00	0.1	0.5	0.0	0.2	12.9	526.4	0.00	1.00
07/27/2026 14:00	0.1	0.3	0.0	0.1	12.9	529.6	0.00	1.00
07/27/2026 15:00	0.0	0.1	0.0	0.0	12.7	530.0	0.00	1.00
07/27/2026 16:00	0.0	0.0	0.0	0.0	12.6	531.8	0.00	1.00
07/27/2026 17:00	0.0	0.0	0.0	0.0	12.8	532.7	0.00	1.00
07/27/2026 18:00	0.3	0.1	0.0	0.3	12.9	558.1	0.00	1.00
07/27/2026 19:00	0.1	0.2	0.0	0.2	12.8	564.2	0.00	1.00
07/27/2026 20:00	0.4	0.3	0.0	0.5	13.3	530.8	0.00	1.00
07/27/2026 21:00	0.8	0.5	0.0	1.0	13.8	496.7	0.00	1.00
07/27/2026 22:00	0.8	0.8	0.0	1.0	13.8	494.6	0.00	1.00
07/27/2026 23:00	0.9	0.9	0.0	1.1	13.9	493.0	0.00	1.00
Average/Sum#:	0.9	1.0	0.0	1.1	13.5	510.0	0.00 #	24.00 #
Minimum:	0.0	0.0	0.0	0.0	12.6	484.5	0.00	1.00
Maximum:	1.9	2.0	0.0	2.2	14.1	564.2	0.00	1.00
%SI	0.00	0.00	25.00	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/28/2026 00:00	0.9	1.0	0.0	1.1	13.9	492.3	0.00	1.00
07/28/2026 01:00	0.9	1.0	0.0	1.1	13.9	489.7	0.00	1.00
07/28/2026 02:00	1.1	1.1	0.0	1.3	14.0	490.1	0.00	1.00
07/28/2026 03:00	1.5	1.3	0.0	1.7	14.0	488.7	0.00	1.00
07/28/2026 04:00	1.5	1.5	0.0	1.7	14.0	488.8	0.00	1.00
07/28/2026 05:00	1.5	1.6	0.0	1.8	14.0	488.0	0.00	1.00
07/28/2026 06:00	1.4	1.6	0.0	1.6	14.0	490.7	0.00	1.00
07/28/2026 07:00	0.7	1.3	0.0	0.8	14.2	402.9	0.00	1.00
07/28/2026 08:00	0.4	0.9	0.0	0.5	14.2	355.7	0.00	1.00
07/28/2026 09:00	0.4	0.5	0.0	0.5	14.3	355.4	0.00	1.00
07/28/2026 10:00	0.4	0.4	0.0	0.5	14.3	355.0	0.00	1.00
07/28/2026 11:00	0.4	0.3	0.0	0.4	14.4	381.3	0.00	1.00
07/28/2026 12:00	0.5	0.4	0.0	0.6	13.6	482.1	0.00	1.00
07/28/2026 13:00	0.4	0.4	0.0	0.4	14.4	358.1	0.00	1.00
07/28/2026 14:00	0.4	0.4	0.0	0.4	14.4	356.2	0.00	1.00
07/28/2026 15:00	0.4	0.3	0.0	0.4	14.4	380.2	0.00	1.00
07/28/2026 16:00	0.6	0.4	0.0	0.7	13.6	505.7	0.00	1.00
07/28/2026 17:00	0.6	0.5	0.0	0.7	13.6	507.6	0.00	1.00
07/28/2026 18:00	0.2	0.5	0.0	0.2	13.0	521.6	0.00	1.00
07/28/2026 19:00	0.2	0.3	0.0	0.2	13.2	515.7	0.00	1.00
07/28/2026 20:00	0.4	0.3	0.0	0.5	13.5	507.6	0.00	1.00
07/28/2026 21:00	0.5	0.4	0.0	0.6	13.5	503.2	0.00	1.00
07/28/2026 22:00	0.6	0.6	0.0	0.8	13.6	499.8	0.00	1.00
07/28/2026 23:00	0.5	0.6	0.0	0.6	14.2	362.6	0.00	1.00
Average/Sum#:	0.7	0.7	0.0	0.8	13.9	449.1	0.00 #	24.00 #
Minimum:	0.2	0.3	0.0	0.2	13.0	355.0	0.00	1.00
Maximum:	1.5	1.6	0.0	1.8	14.4	521.6	0.00	1.00
%SI	0.00	0.00	12.50	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/29/2026 00:00	0.4	0.5	0.0	0.5	14.2	353.8	0.00	1.00
07/29/2026 01:00	0.4	0.4	0.0	0.5	14.2	353.9	0.00	1.00
07/29/2026 02:00	0.4	0.4	0.0	0.5	14.2	354.4	0.00	1.00
07/29/2026 03:00	0.5	0.4	0.0	0.6	14.2	354.8	0.00	1.00
07/29/2026 04:00	0.4	0.4	0.0	0.5	14.2	354.7	0.00	1.00
07/29/2026 05:00	0.5	0.4	0.0	0.6	14.2	354.7	0.00	1.00
07/29/2026 06:00	0.5	0.4	0.0	0.6	14.2	354.8	0.00	1.00
07/29/2026 07:00	0.4	0.4	0.0	0.5	14.2	355.2	0.00	1.00
07/29/2026 08:00	0.4	0.4	0.0	0.5	14.3	354.3	0.00	1.00
07/29/2026 09:00	0.4	0.3	0.0	0.5	14.3	354.5	0.00	1.00
07/29/2026 10:00	0.4	0.3	0.0	0.4	14.4	379.0	0.00	1.00
07/29/2026 11:00	0.3	0.3	0.0	0.4	13.3	520.0	0.00	1.00
07/29/2026 12:00	0.1	0.3	0.0	0.1	12.9	524.8	0.00	1.00
07/29/2026 13:00	0.0	0.1	0.0	0.0	12.5	531.6	0.00	1.00
07/29/2026 14:00	0.0	-0.1	0.0	0.0	12.4	534.2	0.00	1.00
07/29/2026 15:00	0.0	-0.2	0.0	0.0	12.3	537.1	0.00	1.00
07/29/2026 16:00	0.0	-0.2	0.0	0.0	12.2	537.9	0.00	1.00
07/29/2026 17:00	0.0	-0.2	0.0	0.0	12.2	541.0	0.00	1.00
07/29/2026 18:00	0.0	-0.2	0.0	0.0	12.4	541.8	0.00	1.00
07/29/2026 19:00	0.0	-0.1	0.0	0.0	12.8	520.2	0.00	1.00
07/29/2026 20:00	0.2	0.1	0.0	0.3	13.3	508.5	0.00	1.00
07/29/2026 21:00	0.5	0.2	0.0	0.5	14.3	362.0	0.00	1.00
07/29/2026 22:00	0.4	0.3	0.0	0.4	14.3	353.2	0.00	1.00
07/29/2026 23:00	0.4	0.3	0.0	0.4	14.3	353.7	0.00	1.00
Average/Sum#:	0.3	0.2	0.0	0.3	13.6	428.8	0.00 #	24.00 #
Minimum:	0.0	-0.2	0.0	0.0	12.2	353.2	0.00	1.00
Maximum:	0.5	0.5	0.0	0.6	14.4	541.8	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/30/2026 00:00	0.4	0.3	0.0	0.4	14.3	354.0	0.00	1.00
07/30/2026 01:00	0.4	0.3	0.0	0.5	14.3	354.0	0.00	1.00
07/30/2026 02:00	0.4	0.3	0.0	0.5	14.3	354.0	0.00	1.00
07/30/2026 03:00	0.5	0.3	0.0	0.6	14.2	354.4	0.00	1.00
07/30/2026 04:00	0.4	0.4	0.0	0.5	14.2	354.5	0.00	1.00
07/30/2026 05:00	0.4	0.4	0.0	0.5	14.2	354.3	0.00	1.00
07/30/2026 06:00	0.4	0.4	0.0	0.5	14.2	354.5	0.00	1.00
07/30/2026 07:00	0.4	0.4	0.0	0.5	14.3	355.1	0.00	1.00
07/30/2026 08:00	0.4	0.4	0.0	0.5	14.3	353.8	0.00	1.00
07/30/2026 09:00	0.4	0.3	0.0	0.5	14.3	353.7	0.00	1.00
07/30/2026 10:00	0.4	0.3	0.0	0.5	14.3	353.5	0.00	1.00
07/30/2026 11:00	0.4	0.3	0.0	0.4	14.4	354.3	0.00	1.00
07/30/2026 12:00	0.4	0.3	0.0	0.4	14.4	354.4	0.00	1.00
07/30/2026 13:00	0.4	0.3	0.0	0.4	14.4	354.8	0.00	1.00
07/30/2026 14:00	0.4	0.3	0.0	0.4	14.4	393.2	0.00	1.00
07/30/2026 15:00	0.4	0.3	0.0	0.4	14.3	355.9	0.00	1.00
07/30/2026 16:00	0.4	0.3	0.0	0.4	14.5	368.7	0.00	1.00
07/30/2026 17:00	0.4	0.3	0.0	0.4	14.4	400.4	0.00	1.00
07/30/2026 18:00	0.4	0.3	0.0	0.4	14.4	431.5	0.00	1.00
07/30/2026 19:00	0.4	0.3	0.0	0.5	14.4	370.4	0.00	1.00
07/30/2026 20:00	0.4	0.3	0.0	0.4	14.4	351.5	0.00	1.00
07/30/2026 21:00	0.4	0.3	0.0	0.5	14.3	359.5	0.00	1.00
07/30/2026 22:00	0.4	0.3	0.0	0.5	14.4	370.1	0.00	1.00
07/30/2026 23:00	0.4	0.4	0.0	0.5	14.3	354.5	0.00	1.00
Average/Sum#:	0.4	0.3	0.0	0.5	14.3	363.1	0.00 #	24.00 #
Minimum:	0.4	0.3	0.0	0.4	14.2	351.5	0.00	1.00
Maximum:	0.5	0.4	0.0	0.6	14.5	431.5	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/31/2026 00:00	0.4	0.4	0.0	0.5	14.3	352.6	0.00	1.00
07/31/2026 01:00	0.4	0.4	0.0	0.5	14.3	353.5	0.00	1.00
07/31/2026 02:00	0.4	0.4	0.0	0.5	14.3	354.1	0.00	1.00
07/31/2026 03:00	0.5	0.4	0.0	0.6	14.2	354.6	0.00	1.00
07/31/2026 04:00	0.5	0.4	0.0	0.6	14.2	373.3	0.00	1.00
07/31/2026 05:00	0.5	0.4	0.0	0.6	14.2	355.3	0.00	1.00
07/31/2026 06:00	0.4	0.4	0.0	0.5	14.2	355.0	0.00	1.00
07/31/2026 07:00	0.4	0.4	0.0	0.5	14.3	355.7	0.00	1.00
07/31/2026 08:00	0.4	0.4	0.0	0.5	14.3	354.7	0.00	1.00
07/31/2026 09:00	0.4	0.4	0.0	0.5	14.3	354.4	0.00	1.00
07/31/2026 10:00	0.5	0.4	0.0	0.5	14.4	354.2	0.00	1.00
07/31/2026 11:00	0.5	0.4	0.0	0.5	14.4	368.5	0.00	1.00
07/31/2026 12:00	0.4	0.4	0.0	0.4	14.4	436.5	0.00	1.00
07/31/2026 13:00	0.4	0.3	0.0	0.4	14.4	435.4	0.00	1.00
07/31/2026 14:00	0.4	0.3	0.0	0.4	14.4	435.6	0.00	1.00
07/31/2026 15:00	0.5	0.4	0.0	0.6	13.3	527.8	0.00	1.00
07/31/2026 16:00	0.2	0.4	0.0	0.3	13.0	554.1	0.00	1.00
07/31/2026 17:00	0.0	0.3	0.0	0.1	12.6	587.9	0.00	1.00
07/31/2026 18:00	0.0	0.1	0.0	0.0	11.9	633.4	0.00	1.00
07/31/2026 19:00	0.5	0.2	0.0	0.6	13.5	515.7	0.00	1.00
07/31/2026 20:00	0.3	0.3	0.0	0.4	13.3	508.1	0.00	1.00
07/31/2026 21:00	0.4	0.4	0.0	0.5	13.4	503.8	0.00	1.00
07/31/2026 22:00	0.6	0.4	0.0	0.7	13.6	498.9	0.00	1.00
07/31/2026 23:00	0.5	0.5	0.0	0.6	14.3	362.0	0.00	1.00
Average/Sum#:	0.4	0.4	0.0	0.5	13.9	428.5	0.00 #	24.00 #
Minimum:	0.0	0.1	0.0	0.0	11.9	352.6	0.00	1.00
Maximum:	0.6	0.5	0.0	0.7	14.4	633.4	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/01/2026 00:00	0.4	0.4	0.0	0.5	14.3	354.2	0.00	1.00
08/01/2026 01:00	0.4	0.3	0.0	0.5	14.3	353.4	0.00	1.00
08/01/2026 02:00	0.4	0.3	0.0	0.5	14.3	353.9	0.00	1.00
08/01/2026 03:00	0.5	0.3	0.0	0.6	14.2	354.5	0.00	1.00
08/01/2026 04:00	0.4	0.4	0.0	0.5	14.2	354.8	0.00	1.00
08/01/2026 05:00	0.4	0.4	0.0	0.5	14.2	355.0	0.00	1.00
08/01/2026 06:00	0.4	0.4	0.0	0.5	14.2	355.0	0.00	1.00
08/01/2026 07:00	0.4	0.4	0.0	0.5	14.2	355.4	0.00	1.00
08/01/2026 08:00	0.4	0.4	0.0	0.5	14.3	354.4	0.00	1.00
08/01/2026 09:00	0.4	0.3	0.0	0.5	14.3	354.2	0.00	1.00
08/01/2026 10:00	0.4	0.3	0.0	0.4	14.4	353.9	0.00	1.00
08/01/2026 11:00	0.4	0.3	0.0	0.4	14.4	355.3	0.00	1.00
08/01/2026 12:00	0.4	0.3	0.0	0.4	14.4	355.3	0.00	1.00
08/01/2026 13:00	0.4	0.3	0.0	0.4	14.4	354.9	0.00	1.00
08/01/2026 14:00	0.4	0.3	0.0	0.4	14.5	378.3	0.00	1.00
08/01/2026 15:00	0.6	0.4	0.0	0.7	13.5	505.3	0.00	1.00
08/01/2026 16:00	0.2	0.4	0.0	0.3	13.2	514.6	0.00	1.00
08/01/2026 17:00	0.1	0.3	0.0	0.1	12.7	566.8	0.00	1.00
08/01/2026 18:00	0.0	0.1	0.0	0.0	11.8	628.9	0.00	1.00
08/01/2026 19:00	0.0	0.0	0.0	0.0	12.5	584.2	0.00	1.00
08/01/2026 20:00	0.7	0.2	0.0	0.8	13.7	496.9	0.00	1.00
08/01/2026 21:00	0.2	0.3	0.0	0.3	13.0	511.7	0.00	1.00
08/01/2026 22:00	0.3	0.4	0.0	0.4	13.2	504.7	0.00	1.00
08/01/2026 23:00	0.5	0.3	0.0	0.5	14.4	402.8	0.00	1.00
Average/Sum#:	0.4	0.3	0.0	0.4	13.9	419.1	0.00 #	24.00 #
Minimum:	0.0	0.0	0.0	0.0	11.8	353.4	0.00	1.00
Maximum:	0.7	0.4	0.0	0.8	14.5	628.9	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/02/2026 00:00	0.4	0.4	0.0	0.5	14.3	355.5	0.00	1.00
08/02/2026 01:00	0.4	0.4	0.0	0.5	14.3	351.9	0.00	1.00
08/02/2026 02:00	0.4	0.3	0.0	0.4	14.3	352.1	0.00	1.00
08/02/2026 03:00	0.5	0.3	0.0	0.6	14.3	353.4	0.00	1.00
08/02/2026 04:00	0.4	0.4	0.0	0.5	14.3	353.3	0.00	1.00
08/02/2026 05:00	0.6	0.4	0.0	0.7	14.2	353.8	0.00	1.00
08/02/2026 06:00	0.6	0.5	0.0	0.7	14.2	353.5	0.00	1.00
08/02/2026 07:00	0.4	0.5	0.0	0.5	14.3	353.7	0.00	1.00
08/02/2026 08:00	0.4	0.4	0.0	0.5	14.3	352.7	0.00	1.00
08/02/2026 09:00	0.4	0.4	0.0	0.4	14.4	351.9	0.00	1.00
08/02/2026 10:00	0.4	0.3	0.0	0.4	14.4	352.1	0.00	1.00
08/02/2026 11:00	0.4	0.3	0.0	0.4	14.4	353.1	0.00	1.00
08/02/2026 12:00	0.4	0.3	0.0	0.4	14.4	352.8	0.00	1.00
08/02/2026 13:00	0.4	0.3	0.0	0.4	14.5	378.4	0.00	1.00
08/02/2026 14:00	0.6	0.4	0.0	0.7	13.5	504.4	0.00	1.00
08/02/2026 15:00	0.5	0.5	0.0	0.6	13.5	503.0	0.00	1.00
08/02/2026 16:00	0.3	0.5	0.0	0.4	13.2	527.7	0.00	1.00
08/02/2026 17:00	0.4	0.4	0.0	0.5	13.5	511.0	0.00	1.00
08/02/2026 18:00	0.4	0.4	0.0	0.5	13.4	507.3	0.00	1.00
08/02/2026 19:00	0.0	0.2	0.0	0.0	12.4	529.8	0.00	1.00
08/02/2026 20:00	0.0	0.1	0.0	0.0	12.6	523.9	0.00	1.00
08/02/2026 21:00	0.1	0.0	0.0	0.1	12.8	515.5	0.00	1.00
08/02/2026 22:00	1.6	0.5	0.0	1.8	14.2	430.5	0.00	1.00
08/02/2026 23:00	1.1	0.9	0.0	1.3	14.3	411.4	0.00	1.00
Average/Sum#:	0.5	0.4	0.0	0.5	13.9	413.9	0.00 #	24.00 #
Minimum:	0.0	0.0	0.0	0.0	12.4	351.9	0.00	1.00
Maximum:	1.6	0.9	0.0	1.8	14.5	529.8	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/03/2026 00:00	0.4	1.0	0.0	0.5	14.3	352.5	0.00	1.00
08/03/2026 01:00	0.4	0.6	0.0	0.5	14.4	380.2	0.00	1.00
08/03/2026 02:00	0.4	0.4	0.0	0.5	14.3	351.3	0.00	1.00
08/03/2026 03:00	0.5	0.4	0.0	0.6	14.3	351.3	0.00	1.00
08/03/2026 04:00	0.4	0.4	0.0	0.5	14.4	402.6	0.00	1.00
08/03/2026 05:00	0.6	0.4	0.0	0.7	14.3	392.6	0.00	1.00
08/03/2026 06:00	0.6	0.5	0.0	0.7	14.3	353.5	0.00	1.00
08/03/2026 07:00	0.5	0.5	0.0	0.6	14.3	353.8	0.00	1.00
08/03/2026 08:00	0.5	0.4	0.0	0.5	14.4	352.0	0.00	1.00
08/03/2026 09:00	0.5	0.4	0.0	0.5	14.4	351.8	0.00	1.00
08/03/2026 10:00	0.4	0.3	0.0	0.4	14.4	351.9	0.00	1.00
08/03/2026 11:00	0.4	0.3	0.0	0.4	14.4	353.0	0.00	1.00
08/03/2026 12:00	0.4	0.3	0.0	0.4	14.5	383.6	0.00	1.00
08/03/2026 13:00	0.4	0.3	0.0	0.4	14.4	400.1	0.00	1.00
08/03/2026 14:00	0.4	0.4	0.0	0.6	13.3	517.6	0.00	1.00
08/03/2026 15:00	0.4	0.4	0.0	0.5	13.4	510.1	0.00	1.00
08/03/2026 16:00	0.1	0.4	0.0	0.2	12.8	556.4	0.00	1.00
08/03/2026 17:00	0.1	0.2	0.0	0.1	12.7	569.6	0.00	1.00
08/03/2026 18:00	0.0	0.1	0.0	0.0	11.6	638.5	0.00	1.00
08/03/2026 19:00	0.0	0.0	0.0	0.0	12.0	611.3	0.00	1.00
08/03/2026 20:00	0.0	0.0	0.0	0.1	12.4	586.4	0.00	1.00
08/03/2026 21:00	0.2	0.1	0.0	0.3	13.0	528.4	0.00	1.00
08/03/2026 22:00	1.2	0.5	0.0	1.3	14.2	403.9	0.00	1.00
08/03/2026 23:00	0.5	0.6	0.0	0.5	14.5	421.2	0.00	1.00
Average/Sum#:	0.4	0.4	0.0	0.5	13.8	436.4	0.00 #	24.00 #
Minimum:	0.0	0.0	0.0	0.0	11.6	351.3	0.00	1.00
Maximum:	1.2	1.0	0.0	1.3	14.5	638.5	0.00	1.00
%SI	0.00	0.00	8.33	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/04/2026 00:00	0.4	0.6	0.0	0.5	14.3	367.2	0.00	1.00
08/04/2026 01:00	0.4	0.4	0.0	0.5	14.3	351.9	0.00	1.00
08/04/2026 02:00	0.4	0.4	0.0	0.5	14.3	351.7	0.00	1.00
08/04/2026 03:00	0.5	0.4	0.0	0.6	14.3	369.9	0.00	1.00
08/04/2026 04:00	0.5	0.4	0.0	0.5	14.4	406.2	0.00	1.00
08/04/2026 05:00	0.5	0.4	0.0	0.5	14.3	392.1	0.00	1.00
08/04/2026 06:00	0.5	0.4	0.0	0.5	14.3	379.2	0.00	1.00
08/04/2026 07:00	0.4	0.4	0.0	0.5	14.3	352.6	0.00	1.00
08/04/2026 08:00	0.4	0.3	0.0	0.5	14.3	352.0	0.00	1.00
08/04/2026 09:00	0.4	0.3	0.0	0.5	14.3	352.3	0.00	1.00
08/04/2026 10:00	0.4	0.3	0.0	0.5	14.3	355.0	0.00	1.00
08/04/2026 11:00	0.4	0.3	0.0	0.4	14.4	374.0	0.00	1.00
08/04/2026 12:00	0.4	0.3	0.0	0.4	14.4	404.4	0.00	1.00
08/04/2026 13:00	0.3	0.3	0.0	0.3	14.4	423.2	0.00	1.00
08/04/2026 14:00	0.3	0.3	0.0	0.4	13.1	539.5	0.00	1.00
08/04/2026 15:00	0.2	0.3	0.0	0.2	12.8	551.8	0.00	1.00
08/04/2026 16:00	0.2	0.3	0.0	0.3	13.1	533.0	0.00	1.00
08/04/2026 17:00	0.2	0.2	0.0	0.3	12.7	545.2	0.00	1.00
08/04/2026 18:00	0.0	0.2	0.0	0.0	12.2	599.2	0.00	1.00
08/04/2026 19:00	0.6	0.3	0.0	0.7	13.7	497.4	0.00	1.00
08/04/2026 20:00	0.5	0.4	0.0	0.7	13.5	502.3	0.00	1.00
08/04/2026 21:00	0.4	0.6	0.0	0.5	13.4	507.2	0.00	1.00
08/04/2026 22:00	0.4	0.5	0.0	0.5	14.3	363.0	0.00	1.00
08/04/2026 23:00	0.4	0.4	0.0	0.4	14.4	418.8	0.00	1.00
Average/Sum#:	0.4	0.4	0.0	0.4	13.9	428.7	0.00 #	24.00 #
Minimum:	0.0	0.2	0.0	0.0	12.2	351.7	0.00	1.00
Maximum:	0.6	0.6	0.0	0.7	14.4	599.2	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/05/2026 00:00	0.4	0.4	0.0	0.5	14.3	395.8	0.00	1.00
08/05/2026 01:00	0.4	0.4	0.0	0.5	14.2	354.5	0.00	1.00
08/05/2026 02:00	0.5	0.4	0.0	0.6	14.2	354.4	0.00	1.00
08/05/2026 03:00	0.5	0.4	0.0	0.6	14.2	354.4	0.00	1.00
08/05/2026 04:00	0.4	0.4	0.0	0.5	14.2	359.9	0.00	1.00
08/05/2026 05:00	0.4	0.4	0.0	0.5	14.2	354.8	0.00	1.00
08/05/2026 06:00	0.4	0.4	0.0	0.5	14.2	369.2	0.00	1.00
08/05/2026 07:00	0.4	0.4	0.0	0.5	14.2	355.6	0.00	1.00
08/05/2026 08:00	0.4	0.4	0.0	0.5	14.2	354.7	0.00	1.00
08/05/2026 09:00	0.4	0.4	0.0	0.5	14.3	354.6	0.00	1.00
08/05/2026 10:00	0.4	0.3	0.0	0.5	14.3	354.5	0.00	1.00
08/05/2026 11:00	0.4	0.3	0.0	0.4	14.3	355.4	0.00	1.00
08/05/2026 12:00	0.4	0.3	0.0	0.4	14.4	371.3	0.00	1.00
08/05/2026 13:00	0.4	0.3	0.0	0.4	14.3	385.3	0.00	1.00
08/05/2026 14:00	0.6	0.4	0.0	0.7	13.6	503.6	0.00	1.00
08/05/2026 15:00	0.5	0.5	0.0	0.6	13.5	507.8	0.00	1.00
08/05/2026 16:00	0.3	0.5	0.0	0.3	12.9	552.2	0.00	1.00
08/05/2026 17:00	0.3	0.4	0.0	0.4	13.2	533.3	0.00	1.00
08/05/2026 18:00	0.6	0.4	0.0	0.7	13.7	502.1	0.00	1.00
08/05/2026 19:00	0.4	0.4	0.0	0.5	13.4	508.5	0.00	1.00
08/05/2026 20:00	0.3	0.4	0.0	0.4	13.3	511.2	0.00	1.00
08/05/2026 21:00	0.5	0.4	0.0	0.6	13.5	502.6	0.00	1.00
08/05/2026 22:00	0.5	0.5	0.0	0.6	14.4	428.0	0.00	1.00
08/05/2026 23:00	0.5	0.5	0.0	0.5	14.4	412.8	0.00	1.00
Average/Sum#:	0.4	0.4	0.0	0.5	14.0	418.2	0.00 #	24.00 #
Minimum:	0.3	0.3	0.0	0.3	12.9	354.4	0.00	1.00
Maximum:	0.6	0.5	0.0	0.7	14.4	552.2	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/06/2026 00:00	0.4	0.4	0.0	0.5	14.3	366.5	0.00	1.00
08/06/2026 01:00	0.4	0.4	0.0	0.5	14.3	352.5	0.00	1.00
08/06/2026 02:00	0.4	0.4	0.0	0.5	14.3	352.6	0.00	1.00
08/06/2026 03:00	0.5	0.4	0.0	0.6	14.2	353.2	0.00	1.00
08/06/2026 04:00	0.5	0.4	0.0	0.5	14.2	357.2	0.00	1.00
08/06/2026 05:00	0.5	0.4	0.0	0.5	14.2	373.8	0.00	1.00
08/06/2026 06:00	0.5	0.4	0.0	0.6	14.2	354.2	0.00	1.00
08/06/2026 07:00	0.4	0.4	0.0	0.5	14.2	354.8	0.00	1.00
08/06/2026 08:00	0.4	0.4	0.0	0.5	14.2	353.7	0.00	1.00
08/06/2026 09:00	0.4	0.4	0.0	0.5	14.3	353.5	0.00	1.00
08/06/2026 10:00	0.4	0.4	0.0	0.5	14.3	353.7	0.00	1.00
08/06/2026 11:00	0.4	0.4	0.0	0.4	14.4	354.1	0.00	1.00
08/06/2026 12:00	0.4	0.3	0.0	0.4	14.4	354.1	0.00	1.00
08/06/2026 13:00	0.4	0.3	0.0	0.4	14.4	374.6	0.00	1.00
08/06/2026 14:00	0.1	0.2	0.0	0.1	12.6	523.5	0.00	1.00
08/06/2026 15:00	0.0	0.1	0.0	0.0	12.2	536.7	0.00	1.00
08/06/2026 16:00	0.0	0.0	0.0	0.0	12.1	552.2	0.00	1.00
08/06/2026 17:00	0.0	-0.1	0.0	0.0	12.0	618.8	0.00	1.00
08/06/2026 18:00	0.0	0.0	0.0	0.0	12.4	593.7	0.00	1.00
08/06/2026 19:00	0.6	0.2	0.0	0.7	13.6	505.6	0.00	1.00
08/06/2026 20:00	0.3	0.3	0.0	0.3	13.2	517.1	0.00	1.00
08/06/2026 21:00	0.3	0.4	0.0	0.3	13.0	537.8	0.00	1.00
08/06/2026 22:00	0.6	0.4	0.0	0.6	14.5	427.5	0.00	1.00
08/06/2026 23:00	0.5	0.4	0.0	0.5	14.4	427.5	0.00	1.00
Average/Sum#:	0.4	0.3	0.0	0.4	13.7	427.0	0.00 #	24.00 #
Minimum:	0.0	-0.1	0.0	0.0	12.0	352.5	0.00	1.00
Maximum:	0.6	0.4	0.0	0.7	14.5	618.8	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/07/2026 00:00	0.5	0.4	0.0	0.5	14.4	427.2	0.00	1.00
08/07/2026 01:00	0.5	0.4	0.0	0.5	14.4	427.3	0.00	1.00
08/07/2026 02:00	0.5	0.4	0.0	0.5	14.4	427.1	0.00	1.00
08/07/2026 03:00	0.6	0.4	0.0	0.7	14.2	376.2	0.00	1.00
08/07/2026 04:00	0.5	0.4	0.0	0.5	14.3	424.1	0.00	1.00
08/07/2026 05:00	0.4	0.4	0.0	0.5	14.3	426.7	0.00	1.00
08/07/2026 06:00	0.5	0.4	0.0	0.6	14.2	374.3	0.00	1.00
08/07/2026 07:00	0.4	0.4	0.0	0.5	14.2	355.2	0.00	1.00
08/07/2026 08:00	0.4	0.4	0.0	0.5	14.3	354.5	0.00	1.00
08/07/2026 09:00	0.4	0.4	0.0	0.5	14.3	354.1	0.00	1.00
08/07/2026 10:00	0.4	0.4	0.0	0.5	14.3	354.0	0.00	1.00
08/07/2026 11:00	0.4	0.4	0.0	0.4	14.4	383.7	0.00	1.00
08/07/2026 12:00	0.4	0.3	0.0	0.4	14.4	367.9	0.00	1.00
08/07/2026 13:00	0.4	0.3	0.0	0.4	14.4	413.3	0.00	1.00
08/07/2026 14:00	0.4	0.4	0.0	0.4	12.9	524.8	0.00	1.00
08/07/2026 15:00	0.0	0.2	0.0	0.0	12.0	545.0	0.00	1.00
08/07/2026 16:00	0.0	0.0	0.0	0.0	12.1	544.5	0.00	1.00
08/07/2026 17:00	0.2	0.0	0.0	0.3	13.0	548.6	0.00	1.00
08/07/2026 18:00	0.0	0.1	0.0	0.0	12.2	606.6	0.00	1.00
08/07/2026 19:00	0.3	0.2	0.0	0.4	13.2	533.0	0.00	1.00
08/07/2026 20:00	0.6	0.4	0.0	0.8	13.5	513.8	0.00	1.00
08/07/2026 21:00	0.4	0.5	0.0	0.5	13.3	519.0	0.00	1.00
08/07/2026 22:00	0.5	0.6	0.0	0.5	14.4	431.1	0.00	1.00
08/07/2026 23:00	0.4	0.5	0.0	0.4	14.5	439.5	0.00	1.00
Average/Sum#:	0.4	0.3	0.0	0.4	13.8	444.6	0.00 #	24.00 #
Minimum:	0.0	0.0	0.0	0.0	12.0	354.0	0.00	1.00
Maximum:	0.6	0.6	0.0	0.8	14.5	606.6	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/08/2026 00:00	0.4	0.4	0.0	0.4	14.4	439.3	0.00	1.00
08/08/2026 01:00	0.4	0.4	0.0	0.5	14.3	385.3	0.00	1.00
08/08/2026 02:00	0.4	0.4	0.0	0.5	14.2	354.8	0.00	1.00
08/08/2026 03:00	0.5	0.4	0.0	0.6	14.2	357.5	0.00	1.00
08/08/2026 04:00	0.4	0.4	0.0	0.4	14.4	423.6	0.00	1.00
08/08/2026 05:00	0.4	0.4	0.0	0.5	14.3	400.9	0.00	1.00
08/08/2026 06:00	0.4	0.4	0.0	0.5	14.2	356.3	0.00	1.00
08/08/2026 07:00	0.4	0.4	0.0	0.5	14.2	356.4	0.00	1.00
08/08/2026 08:00	0.4	0.4	0.0	0.5	14.3	358.0	0.00	1.00
08/08/2026 09:00	0.4	0.4	0.0	0.5	14.3	358.0	0.00	1.00
08/08/2026 10:00	0.4	0.4	0.0	0.4	14.3	357.3	0.00	1.00
08/08/2026 11:00	0.4	0.3	0.0	0.4	14.4	357.3	0.00	1.00
08/08/2026 12:00	0.4	0.3	0.0	0.4	14.4	357.2	0.00	1.00
08/08/2026 13:00	0.5	0.3	0.0	0.5	14.2	377.2	0.00	1.00
08/08/2026 14:00	0.0	0.2	0.0	0.0	12.1	547.4	0.00	1.00
08/08/2026 15:00	0.0	0.1	0.0	0.0	12.4	530.3	0.00	1.00
08/08/2026 16:00	0.4	0.1	0.0	0.5	13.4	512.1	0.00	1.00
08/08/2026 17:00	0.3	0.3	0.0	0.4	13.3	523.1	0.00	1.00
08/08/2026 18:00	0.4	0.4	0.0	0.5	13.4	515.0	0.00	1.00
08/08/2026 19:00	0.3	0.4	0.0	0.3	13.2	514.5	0.00	1.00
08/08/2026 20:00	0.3	0.3	0.0	0.4	13.3	511.4	0.00	1.00
08/08/2026 21:00	0.4	0.4	0.0	0.5	13.3	506.2	0.00	1.00
08/08/2026 22:00	0.5	0.4	0.0	0.5	14.5	429.4	0.00	1.00
08/08/2026 23:00	0.5	0.5	0.0	0.5	14.4	402.7	0.00	1.00
Average/Sum#:	0.4	0.4	0.0	0.4	13.9	426.3	0.00 #	24.00 #
Minimum:	0.0	0.1	0.0	0.0	12.1	354.8	0.00	1.00
Maximum:	0.5	0.5	0.0	0.6	14.5	547.4	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/09/2026 00:00	0.4	0.4	0.0	0.5	14.3	353.9	0.00	1.00
08/09/2026 01:00	0.4	0.4	0.0	0.5	14.3	353.9	0.00	1.00
08/09/2026 02:00	0.4	0.4	0.0	0.5	14.2	354.3	0.00	1.00
08/09/2026 03:00	0.5	0.4	0.0	0.6	14.2	354.3	0.00	1.00
08/09/2026 04:00	0.4	0.4	0.0	0.5	14.2	358.3	0.00	1.00
08/09/2026 05:00	0.5	0.4	0.0	0.5	14.3	398.3	0.00	1.00
08/09/2026 06:00	0.4	0.4	0.0	0.5	14.2	355.8	0.00	1.00
08/09/2026 07:00	0.5	0.4	0.0	0.6	14.3	356.2	0.00	1.00
08/09/2026 08:00	0.4	0.4	0.0	0.5	14.3	355.4	0.00	1.00
08/09/2026 09:00	0.4	0.4	0.0	0.5	14.3	354.8	0.00	1.00
08/09/2026 10:00	0.4	0.3	0.0	0.4	14.4	354.7	0.00	1.00
08/09/2026 11:00	0.4	0.3	0.0	0.4	14.4	355.2	0.00	1.00
08/09/2026 12:00	0.4	0.3	0.0	0.4	14.4	364.9	0.00	1.00
08/09/2026 13:00	0.4	0.3	0.0	0.4	14.4	420.2	0.00	1.00
08/09/2026 14:00	0.3	0.3	0.0	0.4	13.1	514.2	0.00	1.00
08/09/2026 15:00	0.0	0.2	0.0	0.0	12.0	602.4	0.00	1.00
08/09/2026 16:00	0.0	0.1	0.0	0.0	11.9	610.5	0.00	1.00
08/09/2026 17:00	0.0	0.0	0.0	0.0	12.2	593.0	0.00	1.00
08/09/2026 18:00	0.0	0.0	0.0	0.0	12.0	613.1	0.00	1.00
08/09/2026 19:00	0.5	0.2	0.0	0.5	13.4	508.2	0.00	1.00
08/09/2026 20:00	0.1	0.2	0.0	0.2	12.9	517.8	0.00	1.00
08/09/2026 21:00	0.4	0.4	0.0	0.5	13.3	507.6	0.00	1.00
08/09/2026 22:00	0.4	0.3	0.0	0.5	14.3	366.7	0.00	1.00
08/09/2026 23:00	0.4	0.4	0.0	0.5	14.3	352.9	0.00	1.00
Average/Sum#:	0.3	0.3	0.0	0.4	13.7	428.2	0.00 #	24.00 #
Minimum:	0.0	0.0	0.0	0.0	11.9	352.9	0.00	1.00
Maximum:	0.5	0.4	0.0	0.6	14.4	613.1	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/10/2026 00:00	0.4	0.3	0.0	0.5	14.3	353.3	0.00	1.00
08/10/2026 01:00	0.4	0.3	0.0	0.5	14.2	353.5	0.00	1.00
08/10/2026 02:00	0.4	0.3	0.0	0.5	14.2	353.5	0.00	1.00
08/10/2026 03:00	0.5	0.4	0.0	0.6	14.2	353.9	0.00	1.00
08/10/2026 04:00	0.4	0.4	0.0	0.5	14.3	392.3	0.00	1.00
08/10/2026 05:00	0.4	0.4	0.0	0.5	14.2	354.5	0.00	1.00
08/10/2026 06:00	0.4	0.4	0.0	0.5	14.3	388.4	0.00	1.00
08/10/2026 07:00	0.4	0.4	0.0	0.5	14.2	356.0	0.00	1.00
08/10/2026 08:00	0.4	0.4	0.0	0.5	14.3	355.0	0.00	1.00
08/10/2026 09:00	0.4	0.4	0.0	0.5	14.3	354.8	0.00	1.00
08/10/2026 10:00	0.4	0.4	0.0	0.5	14.3	354.8	0.00	1.00
08/10/2026 11:00	0.4	0.3	0.0	0.4	14.4	355.5	0.00	1.00
08/10/2026 12:00	0.4	0.3	0.0	0.4	14.4	374.3	0.00	1.00
08/10/2026 13:00	0.4	0.3	0.0	0.4	14.3	407.5	0.00	1.00
08/10/2026 14:00	0.4	0.3	0.0	0.4	14.3	396.9	0.00	1.00
08/10/2026 15:00	0.5	0.4	0.0	0.6	13.5	515.8	0.00	1.00
08/10/2026 16:00	0.2	0.4	0.0	0.2	12.6	581.8	0.00	1.00
08/10/2026 17:00	0.0	0.3	0.0	0.0	12.2	611.1	0.00	1.00
08/10/2026 18:00	0.0	0.1	0.0	0.0	12.5	591.6	0.00	1.00
08/10/2026 19:00	0.3	0.1	0.0	0.4	13.1	541.9	0.00	1.00
08/10/2026 20:00	0.7	0.4	0.0	0.9	13.6	510.0	0.00	1.00
08/10/2026 21:00	0.6	0.6	0.0	0.7	13.3	536.7	0.00	1.00
08/10/2026 22:00	0.5	0.6	0.0	0.5	14.4	430.3	0.00	1.00
08/10/2026 23:00	0.4	0.5	0.0	0.5	14.3	375.4	0.00	1.00
Average/Sum#:	0.4	0.4	0.0	0.5	13.9	425.0	0.00 #	24.00 #
Minimum:	0.0	0.1	0.0	0.0	12.2	353.3	0.00	1.00
Maximum:	0.7	0.6	0.0	0.9	14.4	611.1	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/11/2026 00:00	0.4	0.4	0.0	0.5	14.3	381.4	0.00	1.00
08/11/2026 01:00	0.4	0.4	0.0	0.5	14.2	355.4	0.00	1.00
08/11/2026 02:00	0.4	0.4	0.0	0.5	14.2	355.3	0.00	1.00
08/11/2026 03:00	0.5	0.4	0.0	0.6	14.2	355.4	0.00	1.00
08/11/2026 04:00	0.4	0.4	0.0	0.5	14.2	359.1	0.00	1.00
08/11/2026 05:00	0.4	0.4	0.0	0.5	14.2	381.2	0.00	1.00
08/11/2026 06:00	0.4	0.4	0.0	0.5	14.3	396.8	0.00	1.00
08/11/2026 07:00	0.4	0.4	0.0	0.5	14.3	357.0	0.00	1.00
08/11/2026 08:00	0.4	0.4	0.0	0.5	14.3	356.1	0.00	1.00
08/11/2026 09:00	0.4	0.4	0.0	0.5	14.3	356.1	0.00	1.00
08/11/2026 10:00	0.4	0.4	0.0	0.5	14.3	366.0	0.00	1.00
08/11/2026 11:00	0.4	0.3	0.0	0.4	14.5	429.2	0.00	1.00
08/11/2026 12:00	0.4	0.3	0.0	0.4	14.4	432.7	0.00	1.00
08/11/2026 13:00	0.5	0.4	0.0	0.6	13.3	537.5	0.00	1.00
08/11/2026 14:00	0.5	0.5	0.0	0.6	13.5	523.6	0.00	1.00
08/11/2026 15:00	0.6	0.6	0.0	0.6	13.5	518.8	0.00	1.00
08/11/2026 16:00	0.1	0.4	0.0	0.1	12.5	589.6	0.00	1.00
08/11/2026 17:00	0.0	0.2	0.0	0.0	12.0	629.8	0.00	1.00
08/11/2026 18:00	0.1	0.1	0.0	0.1	12.5	590.9	0.00	1.00
08/11/2026 19:00	0.1	0.1	0.0	0.1	12.6	587.6	0.00	1.00
08/11/2026 20:00	0.3	0.2	0.0	0.4	13.0	553.1	0.00	1.00
08/11/2026 21:00	0.5	0.3	0.0	0.5	14.4	430.2	0.00	1.00
08/11/2026 22:00	0.4	0.4	0.0	0.5	14.3	402.9	0.00	1.00
08/11/2026 23:00	0.4	0.4	0.0	0.5	14.3	362.3	0.00	1.00
Average/Sum#:	0.4	0.4	0.0	0.4	13.8	442.0	0.00 #	24.00 #
Minimum:	0.0	0.1	0.0	0.0	12.0	355.3	0.00	1.00
Maximum:	0.6	0.6	0.0	0.6	14.5	629.8	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/12/2026 00:00	0.4	0.4	0.0	0.5	14.3	354.4	0.00	1.00
08/12/2026 01:00	0.4	0.4	0.0	0.5	14.2	354.6	0.00	1.00
08/12/2026 02:00	0.4	0.4	0.0	0.5	14.2	354.8	0.00	1.00
08/12/2026 03:00	0.5	0.4	0.0	0.6	14.2	354.9	0.00	1.00
08/12/2026 04:00	0.4	0.4	0.0	0.5	14.3	388.6	0.00	1.00
08/12/2026 05:00	0.4	0.4	0.0	0.5	14.3	420.2	0.00	1.00
08/12/2026 06:00	0.5	0.4	0.0	0.6	14.2	354.4	0.00	1.00
08/12/2026 07:00	0.5	0.4	0.0	0.6	14.2	355.3	0.00	1.00
08/12/2026 08:00	0.4	0.4	0.0	0.5	14.2	355.5	0.00	1.00
08/12/2026 09:00	0.4	0.4	0.0	0.5	14.3	355.2	0.00	1.00
08/12/2026 10:00	0.4	0.4	0.0	0.5	14.3	355.1	0.00	1.00
08/12/2026 11:00	0.4	0.4	0.0	0.5	14.3	356.0	0.00	1.00
08/12/2026 12:00	0.4	0.4	0.0	0.4	14.4	359.1	0.00	1.00
08/12/2026 13:00	0.7	0.5	0.0	0.9	13.8	499.0	0.00	1.00
08/12/2026 14:00	0.7	0.6	0.0	0.8	13.8	500.7	0.00	1.00
08/12/2026 15:00	0.7	0.7	0.0	0.8	13.8	498.6	0.00	1.00
08/12/2026 16:00	0.7	0.7	0.0	0.8	13.8	498.4	0.00	1.00
08/12/2026 17:00	0.7	0.7	0.0	0.8	13.8	496.7	0.00	1.00
08/12/2026 18:00	0.7	0.7	0.0	0.9	13.8	495.2	0.00	1.00
08/12/2026 19:00	0.8	0.8	0.0	0.9	13.9	491.6	0.00	1.00
08/12/2026 20:00	0.8	0.9	0.0	1.0	13.8	492.5	0.00	1.00
08/12/2026 21:00	0.5	0.8	0.0	0.6	14.3	370.4	0.00	1.00
08/12/2026 22:00	0.4	0.6	0.0	0.5	14.3	353.7	0.00	1.00
08/12/2026 23:00	0.4	0.4	0.0	0.5	14.3	353.7	0.00	1.00
Average/Sum#:	0.5	0.5	0.0	0.6	14.1	407.0	0.00 #	24.00 #
Minimum:	0.4	0.4	0.0	0.4	13.8	353.7	0.00	1.00
Maximum:	0.8	0.9	0.0	1.0	14.4	500.7	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/13/2026 00:00	0.4	0.3	0.0	0.5	14.2	354.0	0.00	1.00
08/13/2026 01:00	0.4	0.4	0.0	0.5	14.2	354.2	0.00	1.00
08/13/2026 02:00	0.4	0.4	0.0	0.5	14.2	354.9	0.00	1.00
08/13/2026 03:00	0.5	0.4	0.0	0.6	14.2	355.2	0.00	1.00
08/13/2026 04:00	0.4	0.4	0.0	0.5	14.2	355.4	0.00	1.00
08/13/2026 05:00	0.4	0.4	0.0	0.5	14.2	355.5	0.00	1.00
08/13/2026 06:00	0.4	0.4	0.0	0.5	14.2	356.0	0.00	1.00
08/13/2026 07:00	0.7	0.5	0.0	0.8	14.2	356.4	0.00	1.00
08/13/2026 08:00	0.7	0.5	0.0	0.8	14.2	356.0	0.00	1.00
08/13/2026 09:00	0.7	0.6	0.0	0.8	14.2	355.6	0.00	1.00
08/13/2026 10:00	0.7	0.6	0.0	0.8	14.3	355.6	0.00	1.00
08/13/2026 11:00	0.7	0.6	0.0	0.8	14.3	356.6	0.00	1.00
08/13/2026 12:00	0.7	0.6	0.0	0.8	14.4	380.3	0.00	1.00
08/13/2026 13:00	0.9	0.7	0.0	1.1	13.7	503.8	0.00	1.00
08/13/2026 14:00	0.7	0.8	0.0	0.9	13.6	505.4	0.00	1.00
08/13/2026 15:00	0.7	0.9	0.0	0.9	13.6	505.2	0.00	1.00
08/13/2026 16:00	0.8	0.9	0.0	1.0	13.7	501.7	0.00	1.00
08/13/2026 17:00	0.9	0.9	0.0	1.1	13.8	499.3	0.00	1.00
08/13/2026 18:00	1.0	1.0	0.0	1.2	13.8	495.6	0.00	1.00
08/13/2026 19:00	0.8	0.9	0.0	0.9	14.2	359.6	0.00	1.00
08/13/2026 20:00	0.7	0.8	0.0	0.8	14.2	355.1	0.00	1.00
08/13/2026 21:00	0.7	0.6	0.0	0.8	14.2	355.1	0.00	1.00
08/13/2026 22:00	0.7	0.6	0.0	0.8	14.2	355.3	0.00	1.00
08/13/2026 23:00	0.7	0.6	0.0	0.8	14.2	355.3	0.00	1.00
Average/Sum#:	0.7	0.6	0.0	0.8	14.1	393.2	0.00 #	24.00 #
Minimum:	0.4	0.3	0.0	0.5	13.6	354.0	0.00	1.00
Maximum:	1.0	1.0	0.0	1.2	14.4	505.4	0.00	1.00
%SI	0.00	0.00	12.50	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/14/2026 00:00	0.7	0.6	0.0	0.8	14.2	355.3	0.00	1.00
08/14/2026 01:00	0.7	0.6	0.0	0.8	14.2	355.4	0.00	1.00
08/14/2026 02:00	0.7	0.6	0.0	0.8	14.2	355.5	0.00	1.00
08/14/2026 03:00	0.8	0.6	0.0	0.9	14.2	355.6	0.00	1.00
08/14/2026 04:00	0.7	0.6	0.0	0.8	14.2	355.7	0.00	1.00
08/14/2026 05:00	0.7	0.6	0.0	0.8	14.2	358.8	0.00	1.00
08/14/2026 06:00	0.7	0.6	0.0	0.8	14.2	370.4	0.00	1.00
08/14/2026 07:00	0.7	0.6	0.0	0.8	14.2	356.1	0.00	1.00
08/14/2026 08:00	0.7	0.6	0.0	0.8	14.2	356.4	0.00	1.00
08/14/2026 09:00	0.7	0.6	0.0	0.8	14.2	355.9	0.00	1.00
08/14/2026 10:00	0.7	0.6	0.0	0.8	14.2	356.0	0.00	1.00
08/14/2026 11:00	0.7	0.6	0.0	0.8	14.2	357.2	0.00	1.00
08/14/2026 12:00	0.7	0.5	0.0	0.8	14.3	357.5	0.00	1.00
08/14/2026 13:00	0.6	0.5	0.0	0.7	14.3	357.7	0.00	1.00
08/14/2026 14:00	0.7	0.5	0.0	0.8	14.3	357.8	0.00	1.00
08/14/2026 15:00	0.6	0.5	0.0	0.7	14.3	357.1	0.00	1.00
08/14/2026 16:00	0.7	0.5	0.0	0.8	14.3	356.2	0.00	1.00
08/14/2026 17:00	0.6	0.5	0.0	0.7	14.3	373.4	0.00	1.00
08/14/2026 18:00	0.6	0.5	0.0	0.7	14.3	358.2	0.00	1.00
08/14/2026 19:00	0.6	0.5	0.0	0.7	14.2	355.7	0.00	1.00
08/14/2026 20:00	0.7	0.5	0.0	0.8	14.2	356.3	0.00	1.00
08/14/2026 21:00	0.7	0.5	0.0	0.8	14.2	356.2	0.00	1.00
08/14/2026 22:00	0.7	0.6	0.0	0.8	14.2	356.6	0.00	1.00
08/14/2026 23:00	0.7	0.6	0.0	0.8	14.2	356.7	0.00	1.00
Average/Sum#:	0.7	0.6	0.0	0.8	14.2	357.8	0.00 #	24.00 #
Minimum:	0.6	0.5	0.0	0.7	14.2	355.3	0.00	1.00
Maximum:	0.8	0.6	0.0	0.9	14.3	373.4	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/15/2026 00:00	0.7	0.6	0.0	0.8	14.2	357.1	0.00	1.00
08/15/2026 01:00	0.7	0.6	0.0	0.8	14.2	357.1	0.00	1.00
08/15/2026 02:00	0.7	0.6	0.0	0.8	14.2	357.1	0.00	1.00
08/15/2026 03:00	0.8	0.6	0.0	0.9	14.2	356.1	0.00	1.00
08/15/2026 04:00	0.7	0.6	0.0	0.8	14.2	355.4	0.00	1.00
08/15/2026 05:00	0.7	0.6	0.0	0.8	14.2	355.0	0.00	1.00
08/15/2026 06:00	0.7	0.6	0.0	0.8	14.2	355.0	0.00	1.00
08/15/2026 07:00	0.7	0.6	0.0	0.8	14.2	355.1	0.00	1.00
08/15/2026 08:00	0.7	0.6	0.0	0.8	14.2	354.9	0.00	1.00
08/15/2026 09:00	0.7	0.6	0.0	0.8	14.2	355.3	0.00	1.00
08/15/2026 10:00	0.7	0.6	0.0	0.8	14.2	355.7	0.00	1.00
08/15/2026 11:00	0.6	0.6	0.0	0.7	14.3	356.8	0.00	1.00
08/15/2026 12:00	0.6	0.5	0.0	0.7	14.3	357.1	0.00	1.00
08/15/2026 13:00	0.7	0.5	0.0	0.8	14.3	357.5	0.00	1.00
08/15/2026 14:00	0.7	0.5	0.0	0.8	14.3	357.8	0.00	1.00
08/15/2026 15:00	0.7	0.5	0.0	0.8	14.3	357.1	0.00	1.00
08/15/2026 16:00	0.6	0.6	0.0	0.7	14.4	375.7	0.00	1.00
08/15/2026 17:00	0.6	0.6	0.0	0.7	14.4	390.7	0.00	1.00
08/15/2026 18:00	0.6	0.6	0.0	0.7	14.3	364.6	0.00	1.00
08/15/2026 19:00	0.6	0.5	0.0	0.7	14.3	376.1	0.00	1.00
08/15/2026 20:00	0.6	0.5	0.0	0.7	14.3	355.8	0.00	1.00
08/15/2026 21:00	0.6	0.5	0.0	0.7	14.4	430.4	0.00	1.00
08/15/2026 22:00	0.6	0.6	0.0	0.7	14.4	422.2	0.00	1.00
08/15/2026 23:00	0.6	0.6	0.0	0.7	14.4	431.5	0.00	1.00
Average/Sum#:	0.7	0.6	0.0	0.8	14.3	368.6	0.00 #	24.00 #
Minimum:	0.6	0.5	0.0	0.7	14.2	354.9	0.00	1.00
Maximum:	0.8	0.6	0.0	0.9	14.4	431.5	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/16/2026 00:00	0.6	0.6	0.0	0.7	14.3	428.2	0.00	1.00
08/16/2026 01:00	0.7	0.6	0.0	0.8	14.2	354.5	0.00	1.00
08/16/2026 02:00	0.7	0.6	0.0	0.8	14.2	355.0	0.00	1.00
08/16/2026 03:00	0.8	0.6	0.0	0.9	14.2	355.1	0.00	1.00
08/16/2026 04:00	0.7	0.6	0.0	0.8	14.2	355.4	0.00	1.00
08/16/2026 05:00	0.7	0.6	0.0	0.8	14.2	356.0	0.00	1.00
08/16/2026 06:00	0.7	0.6	0.0	0.8	14.2	356.3	0.00	1.00
08/16/2026 07:00	0.7	0.6	0.0	0.8	14.2	356.8	0.00	1.00
08/16/2026 08:00	0.7	0.6	0.0	0.8	14.2	355.9	0.00	1.00
08/16/2026 09:00	0.7	0.6	0.0	0.8	14.2	355.5	0.00	1.00
08/16/2026 10:00	0.7	0.6	0.0	0.8	14.3	355.5	0.00	1.00
08/16/2026 11:00	0.7	0.6	0.0	0.8	14.3	356.3	0.00	1.00
08/16/2026 12:00	0.7	0.6	0.0	0.8	14.3	381.2	0.00	1.00
08/16/2026 13:00	0.9	0.8	0.0	1.1	13.7	499.9	0.00	1.00
08/16/2026 14:00	0.9	0.9	0.0	1.1	13.8	500.2	0.00	1.00
08/16/2026 15:00	0.9	1.0	0.0	1.1	13.8	499.1	0.00	1.00
08/16/2026 16:00	0.8	1.0	0.0	1.0	13.6	507.2	0.00	1.00
08/16/2026 17:00	0.7	0.9	0.0	0.9	13.4	526.5	0.00	1.00
08/16/2026 18:00	0.8	0.9	0.0	1.0	13.6	504.1	0.00	1.00
08/16/2026 19:00	1.0	0.9	0.0	1.2	13.8	494.8	0.00	1.00
08/16/2026 20:00	0.7	1.0	0.0	0.9	13.6	501.4	0.00	1.00
08/16/2026 21:00	0.7	0.9	0.0	0.8	14.5	429.9	0.00	1.00
08/16/2026 22:00	0.6	0.7	0.0	0.7	14.5	418.9	0.00	1.00
08/16/2026 23:00	0.7	0.6	0.0	0.8	14.3	352.2	0.00	1.00
Average/Sum#:	0.7	0.7	0.0	0.9	14.1	414.8	0.00 #	24.00 #
Minimum:	0.6	0.6	0.0	0.7	13.4	352.2	0.00	1.00
Maximum:	1.0	1.0	0.0	1.2	14.5	526.5	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/17/2026 00:00	0.7	0.6	0.0	0.8	14.3	352.6	0.00	1.00
08/17/2026 01:00	0.7	0.6	0.0	0.8	14.3	353.1	0.00	1.00
08/17/2026 02:00	0.7	0.6	0.0	0.8	14.3	352.9	0.00	1.00
08/17/2026 03:00	0.8	0.6	0.0	0.9	14.2	352.7	0.00	1.00
08/17/2026 04:00	0.7	0.6	0.0	0.8	14.2	356.5	0.00	1.00
08/17/2026 05:00	0.8	0.6	0.0	0.9	14.2	353.8	0.00	1.00
08/17/2026 06:00	0.7	0.6	0.0	0.8	14.2	353.8	0.00	1.00
08/17/2026 07:00	0.7	0.6	0.0	0.8	14.2	353.9	0.00	1.00
08/17/2026 08:00	0.7	0.6	0.0	0.8	14.3	354.1	0.00	1.00
08/17/2026 09:00	0.7	0.6	0.0	0.8	14.3	354.1	0.00	1.00
08/17/2026 10:00	0.7	0.6	0.0	0.8	14.3	354.1	0.00	1.00
08/17/2026 11:00	0.7	0.6	0.0	0.8	14.3	354.2	0.00	1.00
08/17/2026 12:00	0.6	0.6	0.0	0.7	14.4	378.4	0.00	1.00
08/17/2026 13:00	1.0	0.8	0.0	1.2	13.8	496.9	0.00	1.00
08/17/2026 14:00	0.5	0.8	0.0	0.7	13.0	555.7	0.00	1.00
08/17/2026 15:00	0.4	0.7	0.0	0.5	12.8	563.1	0.00	1.00
08/17/2026 16:00	0.6	0.6	0.0	0.7	13.2	535.7	0.00	1.00
08/17/2026 17:00	0.3	0.5	0.0	0.5	12.4	597.3	0.00	1.00
08/17/2026 18:00	0.4	0.5	0.0	0.6	12.9	561.8	0.00	1.00
08/17/2026 19:00	0.7	0.6	0.0	0.8	13.4	527.9	0.00	1.00
08/17/2026 20:00	0.7	0.7	0.0	0.9	13.6	504.1	0.00	1.00
08/17/2026 21:00	0.7	0.7	0.0	0.8	14.4	387.6	0.00	1.00
08/17/2026 22:00	0.7	0.7	0.0	0.8	14.4	371.3	0.00	1.00
08/17/2026 23:00	0.7	0.6	0.0	0.8	14.3	352.4	0.00	1.00
Average/Sum#:	0.7	0.6	0.0	0.8	13.9	419.9	0.00 #	24.00 #
Minimum:	0.3	0.5	0.0	0.5	12.4	352.4	0.00	1.00
Maximum:	1.0	0.8	0.0	1.2	14.4	597.3	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/18/2026 00:00	0.7	0.6	0.0	0.8	14.3	352.9	0.00	1.00
08/18/2026 01:00	0.7	0.6	0.0	0.8	14.2	353.0	0.00	1.00
08/18/2026 02:00	0.7	0.6	0.0	0.8	14.2	353.3	0.00	1.00
08/18/2026 03:00	0.8	0.6	0.0	0.9	14.2	353.5	0.00	1.00
08/18/2026 04:00	0.7	0.6	0.0	0.8	14.2	354.1	0.00	1.00
08/18/2026 05:00	0.7	0.6	0.0	0.8	14.2	354.0	0.00	1.00
08/18/2026 06:00	0.7	0.6	0.0	0.8	14.2	355.0	0.00	1.00
08/18/2026 07:00	0.7	0.6	0.0	0.8	14.2	355.1	0.00	1.00
08/18/2026 08:00	0.7	0.6	0.0	0.8	14.2	354.0	0.00	1.00
08/18/2026 09:00	0.7	0.6	0.0	0.8	14.3	353.9	0.00	1.00
08/18/2026 10:00	0.7	0.6	0.0	0.8	14.3	354.0	0.00	1.00
08/18/2026 11:00	0.7	0.6	0.0	0.8	14.3	354.3	0.00	1.00
08/18/2026 12:00	0.8	0.7	0.0	1.0	14.4	375.7	0.00	1.00
08/18/2026 13:00	0.4	0.6	0.0	0.5	12.9	527.9	0.00	1.00
08/18/2026 14:00	0.2	0.5	0.0	0.3	12.5	545.5	0.00	1.00
08/18/2026 15:00	0.2	0.3	0.0	0.3	12.4	537.2	0.00	1.00
08/18/2026 16:00	0.2	0.2	0.0	0.2	12.3	563.1	0.00	1.00
08/18/2026 17:00	0.2	0.2	0.0	0.3	12.0	627.8	0.00	1.00
08/18/2026 18:00	0.2	0.3	0.0	0.3	12.3	600.6	0.00	1.00
08/18/2026 19:00	0.6	0.4	0.0	0.8	13.2	535.0	0.00	1.00
08/18/2026 20:00	1.1	0.7	0.0	1.3	13.8	490.7	0.00	1.00
08/18/2026 21:00	0.8	0.9	0.0	0.9	14.2	397.5	0.00	1.00
08/18/2026 22:00	0.7	0.8	0.0	0.8	14.3	371.4	0.00	1.00
08/18/2026 23:00	0.7	0.6	0.0	0.8	14.3	358.6	0.00	1.00
Average/Sum#:	0.6	0.6	0.0	0.7	13.7	424.1	0.00 #	24.00 #
Minimum:	0.2	0.2	0.0	0.2	12.0	352.9	0.00	1.00
Maximum:	1.1	0.9	0.0	1.3	14.4	627.8	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/19/2026 00:00	0.7	0.6	0.0	0.8	14.3	352.5	0.00	1.00
08/19/2026 01:00	0.7	0.6	0.0	0.8	14.2	352.8	0.00	1.00
08/19/2026 02:00	0.7	0.6	0.0	0.8	14.2	353.2	0.00	1.00
08/19/2026 03:00	0.8	0.6	0.0	0.9	14.2	353.7	0.00	1.00
08/19/2026 04:00	0.7	0.6	0.0	0.8	14.2	353.6	0.00	1.00
08/19/2026 05:00	0.7	0.6	0.0	0.8	14.2	353.6	0.00	1.00
08/19/2026 06:00	0.8	0.6	0.0	0.9	14.2	354.3	0.00	1.00
08/19/2026 07:00	0.7	0.6	0.0	0.8	14.2	354.9	0.00	1.00
08/19/2026 08:00	0.7	0.6	0.0	0.8	14.3	354.2	0.00	1.00
08/19/2026 09:00	0.7	0.6	0.0	0.8	14.3	353.9	0.00	1.00
08/19/2026 10:00	0.7	0.6	0.0	0.8	14.3	354.2	0.00	1.00
08/19/2026 11:00	0.6	0.6	0.0	0.7	14.4	354.6	0.00	1.00
08/19/2026 12:00	0.8	0.6	0.0	0.9	14.4	372.9	0.00	1.00
08/19/2026 13:00	0.2	0.5	0.0	0.3	12.3	542.5	0.00	1.00
08/19/2026 14:00	0.1	0.4	0.0	0.2	12.2	564.3	0.00	1.00
08/19/2026 15:00	0.3	0.3	0.0	0.5	12.5	540.9	0.00	1.00
08/19/2026 16:00	0.1	0.3	0.0	0.2	12.1	555.5	0.00	1.00
08/19/2026 17:00	0.2	0.3	0.0	0.3	12.1	618.1	0.00	1.00
08/19/2026 18:00	0.2	0.3	0.0	0.3	12.1	619.3	0.00	1.00
08/19/2026 19:00	0.3	0.3	0.0	0.4	12.3	600.1	0.00	1.00
08/19/2026 20:00	0.5	0.4	0.0	0.7	12.9	555.9	0.00	1.00
08/19/2026 21:00	0.8	0.6	0.0	0.9	14.4	423.2	0.00	1.00
08/19/2026 22:00	0.7	0.7	0.0	0.8	14.5	429.6	0.00	1.00
08/19/2026 23:00	0.7	0.7	0.0	0.8	14.4	429.3	0.00	1.00
Average/Sum#:	0.6	0.5	0.0	0.7	13.6	437.4	0.00 #	24.00 #
Minimum:	0.1	0.3	0.0	0.2	12.1	352.5	0.00	1.00
Maximum:	0.8	0.7	0.0	0.9	14.5	619.3	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/20/2026 00:00	0.7	0.7	0.0	0.8	14.3	394.0	0.00	1.00
08/20/2026 01:00	0.7	0.7	0.0	0.8	14.3	355.4	0.00	1.00
08/20/2026 02:00	0.7	0.6	0.0	0.8	14.3	355.0	0.00	1.00
08/20/2026 03:00	0.8	0.6	0.0	0.9	14.2	354.2	0.00	1.00
08/20/2026 04:00	0.8	0.6	0.0	0.9	14.2	354.3	0.00	1.00
08/20/2026 05:00	0.8	0.6	0.0	0.9	14.2	355.0	0.00	1.00
08/20/2026 06:00	0.8	0.6	0.0	0.9	14.2	358.1	0.00	1.00
08/20/2026 07:00	0.7	0.6	0.0	0.8	14.2	356.2	0.00	1.00
08/20/2026 08:00	0.7	0.6	0.0	0.8	14.2	355.6	0.00	1.00
08/20/2026 09:00	0.7	0.6	0.0	0.8	14.3	355.2	0.00	1.00
08/20/2026 10:00	0.7	0.6	0.0	0.8	14.3	355.4	0.00	1.00
08/20/2026 11:00	0.7	0.6	0.0	0.8	14.3	358.7	0.00	1.00
08/20/2026 12:00	0.8	0.6	0.0	0.9	14.4	382.0	0.00	1.00
08/20/2026 13:00	0.4	0.6	0.0	0.5	12.9	525.8	0.00	1.00
08/20/2026 14:00	0.3	0.5	0.0	0.5	12.8	533.9	0.00	1.00
08/20/2026 15:00	0.2	0.4	0.0	0.3	12.5	534.8	0.00	1.00
08/20/2026 16:00	0.2	0.3	0.0	0.3	12.4	549.8	0.00	1.00
08/20/2026 17:00	0.2	0.2	0.0	0.3	12.0	628.2	0.00	1.00
08/20/2026 18:00	0.2	0.3	0.0	0.3	12.3	606.8	0.00	1.00
08/20/2026 19:00	0.2	0.3	0.0	0.3	12.3	607.0	0.00	1.00
08/20/2026 20:00	0.5	0.4	0.0	0.7	12.9	560.7	0.00	1.00
08/20/2026 21:00	0.7	0.5	0.0	0.8	14.4	428.9	0.00	1.00
08/20/2026 22:00	0.7	0.7	0.0	0.8	14.4	429.5	0.00	1.00
08/20/2026 23:00	0.7	0.7	0.0	0.8	14.4	429.5	0.00	1.00
Average/Sum#:	0.6	0.5	0.0	0.7	13.7	438.5	0.00 #	24.00 #
Minimum:	0.2	0.2	0.0	0.3	12.0	354.2	0.00	1.00
Maximum:	0.8	0.7	0.0	0.9	14.4	628.2	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/21/2026 00:00	0.7	0.7	0.0	0.8	14.3	429.5	0.00	1.00
08/21/2026 01:00	0.7	0.7	0.0	0.8	14.2	370.0	0.00	1.00
08/21/2026 02:00	0.7	0.6	0.0	0.8	14.2	389.3	0.00	1.00
08/21/2026 03:00	0.8	0.6	0.0	0.9	14.2	362.2	0.00	1.00
08/21/2026 04:00	0.8	0.6	0.0	0.9	14.2	360.6	0.00	1.00
08/21/2026 05:00	0.7	0.7	0.0	0.8	14.3	431.5	0.00	1.00
08/21/2026 06:00	0.8	0.7	0.0	0.9	14.2	383.1	0.00	1.00
08/21/2026 07:00	0.7	0.7	0.0	0.8	14.2	356.4	0.00	1.00
08/21/2026 08:00	0.7	0.6	0.0	0.8	14.2	356.3	0.00	1.00
08/21/2026 09:00	0.7	0.6	0.0	0.8	14.2	356.3	0.00	1.00
08/21/2026 10:00	0.7	0.6	0.0	0.8	14.3	356.1	0.00	1.00
08/21/2026 11:00	0.7	0.6	0.0	0.8	14.3	356.5	0.00	1.00
08/21/2026 12:00	0.7	0.6	0.0	0.8	14.4	381.7	0.00	1.00
08/21/2026 13:00	0.6	0.6	0.0	0.7	13.1	518.1	0.00	1.00
08/21/2026 14:00	0.2	0.5	0.0	0.3	12.6	530.1	0.00	1.00
08/21/2026 15:00	0.2	0.4	0.0	0.3	12.6	529.6	0.00	1.00
08/21/2026 16:00	0.2	0.3	0.0	0.3	12.4	542.7	0.00	1.00
08/21/2026 17:00	0.1	0.2	0.0	0.2	12.1	580.1	0.00	1.00
08/21/2026 18:00	0.7	0.4	0.0	0.8	13.6	497.8	0.00	1.00
08/21/2026 19:00	1.0	0.7	0.0	1.2	13.9	491.6	0.00	1.00
08/21/2026 20:00	1.1	1.0	0.0	1.3	13.8	493.5	0.00	1.00
08/21/2026 21:00	0.8	1.0	0.0	0.9	14.3	359.9	0.00	1.00
08/21/2026 22:00	0.8	0.8	0.0	0.9	14.3	354.9	0.00	1.00
08/21/2026 23:00	0.7	0.6	0.0	0.8	14.3	403.7	0.00	1.00
Average/Sum#:	0.7	0.6	0.0	0.8	13.8	424.6	0.00 #	24.00 #
Minimum:	0.1	0.2	0.0	0.2	12.1	354.9	0.00	1.00
Maximum:	1.1	1.0	0.0	1.3	14.4	580.1	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/22/2026 00:00	0.7	0.6	0.0	0.8	14.3	397.2	0.00	1.00
08/22/2026 01:00	0.7	0.6	0.0	0.8	14.3	388.2	0.00	1.00
08/22/2026 02:00	0.8	0.6	0.0	0.9	14.2	354.6	0.00	1.00
08/22/2026 03:00	0.8	0.6	0.0	0.9	14.2	354.9	0.00	1.00
08/22/2026 04:00	0.7	0.6	0.0	0.8	14.2	384.3	0.00	1.00
08/22/2026 05:00	0.8	0.6	0.0	0.9	14.2	356.8	0.00	1.00
08/22/2026 06:00	0.8	0.6	0.0	0.9	14.2	356.2	0.00	1.00
08/22/2026 07:00	0.8	0.6	0.0	0.9	14.2	356.7	0.00	1.00
08/22/2026 08:00	0.7	0.6	0.0	0.8	14.2	355.8	0.00	1.00
08/22/2026 09:00	0.7	0.6	0.0	0.8	14.3	355.7	0.00	1.00
08/22/2026 10:00	0.7	0.6	0.0	0.8	14.3	355.7	0.00	1.00
08/22/2026 11:00	0.7	0.6	0.0	0.8	14.4	356.0	0.00	1.00
08/22/2026 12:00	0.6	0.6	0.0	0.7	14.4	380.4	0.00	1.00
08/22/2026 13:00	1.0	0.7	0.0	1.2	13.8	496.6	0.00	1.00
08/22/2026 14:00	1.0	0.9	0.0	1.2	13.8	498.3	0.00	1.00
08/22/2026 15:00	1.0	1.1	0.0	1.2	13.8	497.5	0.00	1.00
08/22/2026 16:00	0.9	1.1	0.0	1.1	13.7	499.2	0.00	1.00
08/22/2026 17:00	0.3	0.8	0.0	0.4	12.9	524.7	0.00	1.00
08/22/2026 18:00	0.3	0.6	0.0	0.4	12.9	522.3	0.00	1.00
08/22/2026 19:00	0.5	0.5	0.0	0.6	13.3	513.0	0.00	1.00
08/22/2026 20:00	0.7	0.6	0.0	0.9	13.6	505.2	0.00	1.00
08/22/2026 21:00	0.8	0.7	0.0	0.9	14.3	365.3	0.00	1.00
08/22/2026 22:00	0.7	0.7	0.0	0.8	14.3	353.9	0.00	1.00
08/22/2026 23:00	0.7	0.6	0.0	0.8	14.3	354.4	0.00	1.00
Average/Sum#:	0.7	0.7	0.0	0.8	14.0	411.8	0.00 #	24.00 #
Minimum:	0.3	0.5	0.0	0.4	12.9	353.9	0.00	1.00
Maximum:	1.0	1.1	0.0	1.2	14.4	524.7	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/23/2026 00:00	0.7	0.6	0.0	0.8	14.3	382.3	0.00	1.00
08/23/2026 01:00	0.7	0.6	0.0	0.8	14.3	355.6	0.00	1.00
08/23/2026 02:00	0.8	0.6	0.0	0.9	14.2	354.4	0.00	1.00
08/23/2026 03:00	0.8	0.6	0.0	1.0	14.2	354.7	0.00	1.00
08/23/2026 04:00	0.8	0.6	0.0	0.9	14.2	355.3	0.00	1.00
08/23/2026 05:00	0.9	0.7	0.0	1.0	14.2	355.5	0.00	1.00
08/23/2026 06:00	1.0	0.7	0.0	1.1	14.2	355.4	0.00	1.00
08/23/2026 07:00	1.0	0.7	0.0	1.1	14.2	355.7	0.00	1.00
08/23/2026 08:00	0.8	0.7	0.0	0.9	14.3	355.3	0.00	1.00
08/23/2026 09:00	0.7	0.6	0.0	0.8	14.3	355.0	0.00	1.00
08/23/2026 10:00	0.7	0.6	0.0	0.8	14.3	354.8	0.00	1.00
08/23/2026 11:00	0.7	0.6	0.0	0.8	14.4	355.4	0.00	1.00
08/23/2026 12:00	0.7	0.6	0.0	0.8	14.4	380.6	0.00	1.00
08/23/2026 13:00	0.9	0.7	0.0	1.1	13.6	499.3	0.00	1.00
08/23/2026 14:00	0.2	0.6	0.0	0.3	12.5	531.6	0.00	1.00
08/23/2026 15:00	0.2	0.5	0.0	0.4	12.6	556.1	0.00	1.00
08/23/2026 16:00	0.5	0.4	0.0	0.6	12.8	571.4	0.00	1.00
08/23/2026 17:00	0.2	0.4	0.0	0.3	12.1	619.6	0.00	1.00
08/23/2026 18:00	0.2	0.4	0.0	0.3	12.2	612.0	0.00	1.00
08/23/2026 19:00	0.4	0.4	0.0	0.5	12.7	578.5	0.00	1.00
08/23/2026 20:00	0.6	0.5	0.0	0.7	12.9	556.0	0.00	1.00
08/23/2026 21:00	0.7	0.6	0.0	0.8	14.4	432.1	0.00	1.00
08/23/2026 22:00	0.7	0.7	0.0	0.8	14.3	431.6	0.00	1.00
08/23/2026 23:00	0.7	0.7	0.0	0.8	14.3	432.0	0.00	1.00
Average/Sum#:	0.7	0.6	0.0	0.8	13.7	437.1	0.00 #	24.00 #
Minimum:	0.2	0.4	0.0	0.3	12.1	354.4	0.00	1.00
Maximum:	1.0	0.7	0.0	1.1	14.4	619.6	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/24/2026 00:00	0.7	0.7	0.0	0.8	14.3	431.4	0.00	1.00
08/24/2026 01:00	0.7	0.7	0.0	0.8	14.4	430.0	0.00	1.00
08/24/2026 02:00	0.7	0.7	0.0	0.8	14.4	430.8	0.00	1.00
08/24/2026 03:00	0.8	0.7	0.0	0.9	14.4	422.0	0.00	1.00
08/24/2026 04:00	0.7	0.7	0.0	0.8	14.4	426.8	0.00	1.00
08/24/2026 05:00	0.7	0.7	0.0	0.8	14.2	358.8	0.00	1.00
08/24/2026 06:00	0.7	0.6	0.0	0.8	14.3	389.1	0.00	1.00
08/24/2026 07:00	0.8	0.6	0.0	0.9	14.3	370.5	0.00	1.00
08/24/2026 08:00	0.7	0.6	0.0	0.8	14.3	355.2	0.00	1.00
08/24/2026 09:00	0.7	0.6	0.0	0.8	14.3	355.0	0.00	1.00
08/24/2026 10:00	0.7	0.6	0.0	0.8	14.4	354.7	0.00	1.00
08/24/2026 11:00	0.6	0.6	0.0	0.7	14.4	355.5	0.00	1.00
08/24/2026 12:00	0.6	0.6	0.0	0.7	14.4	382.6	0.00	1.00
08/24/2026 13:00	0.4	0.5	0.0	0.6	12.8	532.9	0.00	1.00
08/24/2026 14:00	0.2	0.4	0.0	0.3	12.2	593.5	0.00	1.00
08/24/2026 15:00	0.2	0.3	0.0	0.3	12.1	621.6	0.00	1.00
08/24/2026 16:00	0.3	0.3	0.0	0.4	12.5	594.7	0.00	1.00
08/24/2026 17:00	0.2	0.3	0.0	0.3	12.1	621.3	0.00	1.00
08/24/2026 18:00	0.2	0.3	0.0	0.3	12.1	624.5	0.00	1.00
08/24/2026 19:00	0.2	0.3	0.0	0.3	12.1	621.4	0.00	1.00
08/24/2026 20:00	0.6	0.4	0.0	0.7	13.1	548.3	0.00	1.00
08/24/2026 21:00	0.7	0.6	0.0	0.8	14.5	430.6	0.00	1.00
08/24/2026 22:00	0.7	0.7	0.0	0.8	14.4	430.6	0.00	1.00
08/24/2026 23:00	0.7	0.7	0.0	0.8	14.4	417.2	0.00	1.00
Average/Sum#:	0.6	0.6	0.0	0.7	13.7	462.5	0.00 #	24.00 #
Minimum:	0.2	0.3	0.0	0.3	12.1	354.7	0.00	1.00
Maximum:	0.8	0.7	0.0	0.9	14.5	624.5	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/25/2026 00:00	0.7	0.7	0.0	0.8	14.3	396.7	0.00	1.00
08/25/2026 01:00	0.7	0.6	0.0	0.8	14.2	360.3	0.00	1.00
08/25/2026 02:00	0.7	0.6	0.0	0.8	14.2	356.6	0.00	1.00
08/25/2026 03:00	0.8	0.6	0.0	0.9	14.2	357.0	0.00	1.00
08/25/2026 04:00	0.7	0.6	0.0	0.8	14.3	393.7	0.00	1.00
08/25/2026 05:00	0.7	0.6	0.0	0.8	14.2	375.0	0.00	1.00
08/25/2026 06:00	0.8	0.6	0.0	0.9	14.2	379.6	0.00	1.00
08/25/2026 07:00	0.8	0.6	0.0	0.9	14.2	357.3	0.00	1.00
08/25/2026 08:00	0.7	0.6	0.0	0.8	14.2	356.8	0.00	1.00
08/25/2026 09:00	0.7	0.6	0.0	0.8	14.3	356.2	0.00	1.00
08/25/2026 10:00	0.7	0.6	0.0	0.8	14.3	356.0	0.00	1.00
08/25/2026 11:00	0.6	0.6	0.0	0.7	14.4	393.4	0.00	1.00
08/25/2026 12:00	0.6	0.6	0.0	0.7	14.4	420.3	0.00	1.00
08/25/2026 13:00	0.6	0.6	0.0	0.7	14.4	432.7	0.00	1.00
08/25/2026 14:00	0.8	0.7	0.0	0.9	13.4	528.5	0.00	1.00
08/25/2026 15:00	0.8	0.8	0.0	1.0	13.7	508.5	0.00	1.00
08/25/2026 16:00	0.4	0.8	0.0	0.6	12.8	568.4	0.00	1.00
08/25/2026 17:00	0.2	0.6	0.0	0.3	12.0	631.5	0.00	1.00
08/25/2026 18:00	0.2	0.4	0.0	0.3	12.0	630.3	0.00	1.00
08/25/2026 19:00	0.3	0.3	0.0	0.4	12.5	596.2	0.00	1.00
08/25/2026 20:00	0.6	0.5	0.0	0.8	13.3	535.6	0.00	1.00
08/25/2026 21:00	0.6	0.6	0.0	0.8	13.3	522.4	0.00	1.00
08/25/2026 22:00	0.8	0.7	0.0	0.9	14.4	384.8	0.00	1.00
08/25/2026 23:00	0.7	0.7	0.0	0.8	14.3	355.3	0.00	1.00
Average/Sum#:	0.6	0.6	0.0	0.8	13.8	439.7	0.00 #	24.00 #
Minimum:	0.2	0.3	0.0	0.3	12.0	355.3	0.00	1.00
Maximum:	0.8	0.8	0.0	1.0	14.4	631.5	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/26/2026 00:00	0.7	0.6	0.0	0.8	14.3	361.5	0.00	1.00
08/26/2026 01:00	0.7	0.6	0.0	0.8	14.3	355.2	0.00	1.00
08/26/2026 02:00	0.7	0.6	0.0	0.8	14.3	379.9	0.00	1.00
08/26/2026 03:00	0.8	0.6	0.0	1.0	14.2	355.9	0.00	1.00
08/26/2026 04:00	0.7	0.7	0.0	0.8	14.3	398.5	0.00	1.00
08/26/2026 05:00	0.7	0.7	0.0	0.8	14.4	430.8	0.00	1.00
08/26/2026 06:00	0.7	0.7	0.0	0.8	14.3	389.2	0.00	1.00
08/26/2026 07:00	0.7	0.7	0.0	0.8	14.2	356.9	0.00	1.00
08/26/2026 08:00	0.7	0.6	0.0	0.8	14.3	356.1	0.00	1.00
08/26/2026 09:00	0.7	0.6	0.0	0.8	14.3	355.7	0.00	1.00
08/26/2026 10:00	0.7	0.6	0.0	0.8	14.4	355.6	0.00	1.00
08/26/2026 11:00	0.6	0.6	0.0	0.7	14.4	430.5	0.00	1.00
08/26/2026 12:00	0.6	0.6	0.0	0.7	14.4	427.5	0.00	1.00
08/26/2026 13:00	0.8	0.7	0.0	1.0	13.4	518.4	0.00	1.00
08/26/2026 14:00	0.2	0.6	0.0	0.3	12.7	528.7	0.00	1.00
08/26/2026 15:00	0.1	0.5	0.0	0.2	12.5	532.3	0.00	1.00
08/26/2026 16:00	0.1	0.2	0.0	0.2	12.5	533.5	0.00	1.00
08/26/2026 17:00	0.3	0.2	0.0	0.4	12.6	573.1	0.00	1.00
08/26/2026 18:00	0.5	0.4	0.0	0.7	13.2	532.6	0.00	1.00
08/26/2026 19:00	0.3	0.4	0.0	0.4	12.9	546.5	0.00	1.00
08/26/2026 20:00	0.5	0.5	0.0	0.7	13.1	537.7	0.00	1.00
08/26/2026 21:00	0.7	0.6	0.0	0.8	14.5	428.9	0.00	1.00
08/26/2026 22:00	0.8	0.6	0.0	0.9	14.3	362.2	0.00	1.00
08/26/2026 23:00	0.7	0.7	0.0	0.8	14.4	400.2	0.00	1.00
Average/Sum#:	0.6	0.6	0.0	0.7	13.8	435.3	0.00 #	24.00 #
Minimum:	0.1	0.2	0.0	0.2	12.5	355.2	0.00	1.00
Maximum:	0.8	0.7	0.0	1.0	14.5	573.1	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/27/2026 00:00	0.8	0.7	0.0	0.9	14.3	377.2	0.00	1.00
08/27/2026 01:00	0.8	0.7	0.0	0.9	14.3	355.1	0.00	1.00
08/27/2026 02:00	0.7	0.6	0.0	0.8	14.3	355.0	0.00	1.00
08/27/2026 03:00	0.8	0.6	0.0	0.9	14.3	355.1	0.00	1.00
08/27/2026 04:00	0.8	0.6	0.0	0.9	14.3	355.9	0.00	1.00
08/27/2026 05:00	0.8	0.7	0.0	0.9	14.3	389.6	0.00	1.00
08/27/2026 06:00	0.7	0.7	0.0	0.8	14.3	400.4	0.00	1.00
08/27/2026 07:00	0.7	0.7	0.0	0.8	14.4	433.5	0.00	1.00
08/27/2026 08:00	0.6	0.7	0.0	0.7	14.5	432.4	0.00	1.00
08/27/2026 09:00	0.6	0.7	0.0	0.7	14.5	431.7	0.00	1.00
08/27/2026 10:00	0.6	0.6	0.0	0.7	14.5	433.0	0.00	1.00
08/27/2026 11:00	0.6	0.6	0.0	0.7	14.4	433.7	0.00	1.00
08/27/2026 12:00	0.6	0.6	0.0	0.7	14.4	432.5	0.00	1.00
08/27/2026 13:00	0.5	0.6	0.0	0.6	12.6	589.3	0.00	1.00
08/27/2026 14:00	0.2	0.5	0.0	0.3	12.2	613.8	0.00	1.00
08/27/2026 15:00	0.7	0.6	0.0	0.9	13.4	519.1	0.00	1.00
08/27/2026 16:00	0.6	0.6	0.0	0.8	13.3	529.4	0.00	1.00
08/27/2026 17:00	0.9	0.9	0.0	1.1	13.7	499.7	0.00	1.00
08/27/2026 18:00	0.5	0.8	0.0	0.6	13.2	515.3	0.00	1.00
08/27/2026 19:00	0.5	0.7	0.0	0.6	13.2	515.7	0.00	1.00
08/27/2026 20:00	0.4	0.5	0.0	0.5	12.7	543.4	0.00	1.00
08/27/2026 21:00	0.7	0.5	0.0	0.8	14.5	428.8	0.00	1.00
08/27/2026 22:00	0.7	0.6	0.0	0.8	14.5	432.2	0.00	1.00
08/27/2026 23:00	0.5	0.7	0.0	0.7	12.9	558.3	0.00	1.00
Average/Sum#:	0.6	0.6	0.0	0.8	13.9	455.4	0.00 #	24.00 #
Minimum:	0.2	0.5	0.0	0.3	12.2	355.0	0.00	1.00
Maximum:	0.9	0.9	0.0	1.1	14.5	613.8	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/28/2026 00:00	0.7	0.7	0.0	0.9	13.5	520.2	0.00	1.00
08/28/2026 01:00	0.8	0.8	0.0	1.0	13.6	511.2	0.00	1.00
08/28/2026 02:00	1.0	0.9	0.0	1.2	13.8	498.2	0.00	1.00
08/28/2026 03:00	1.0	1.0	0.0	1.2	13.6	509.3	0.00	1.00
08/28/2026 04:00	0.6	1.0	0.0	0.8	13.2	549.6	0.00	1.00
08/28/2026 05:00	0.3	0.8	0.0	0.4	12.3	617.6	0.00	1.00
08/28/2026 06:00	0.3	0.5	0.0	0.5	12.5	599.9	0.00	1.00
08/28/2026 07:00	0.3	0.4	0.0	0.4	12.3	617.8	0.00	1.00
08/28/2026 08:00	0.8	0.6	0.0	1.0	13.5	527.9	0.00	1.00
08/28/2026 09:00	1.0	0.8	0.0	1.2	13.8	501.3	0.00	1.00
08/28/2026 10:00	0.8	1.0	0.0	1.0	13.6	514.2	0.00	1.00
08/28/2026 11:00	0.6	1.0	0.0	0.8	13.4	522.5	0.00	1.00
08/28/2026 12:00	0.6	0.8	0.0	0.8	13.4	518.3	0.00	1.00
08/28/2026 13:00	0.6	0.7	0.0	0.8	13.5	510.1	0.00	1.00
08/28/2026 14:00	0.5	0.7	0.0	0.7	13.3	513.1	0.00	1.00
08/28/2026 15:00	0.5	0.6	0.0	0.7	13.4	513.5	0.00	1.00
08/28/2026 16:00	0.6	0.6	0.0	0.8	13.5	510.4	0.00	1.00
08/28/2026 17:00	0.7	0.7	0.0	0.9	13.6	506.4	0.00	1.00
08/28/2026 18:00	0.7	0.8	0.0	0.9	13.6	507.5	0.00	1.00
08/28/2026 19:00	0.9	0.9	0.0	1.1	13.7	499.8	0.00	1.00
08/28/2026 20:00	0.9	0.9	0.0	1.1	13.8	497.5	0.00	1.00
08/28/2026 21:00	1.0	1.0	0.0	1.2	13.8	494.1	0.00	1.00
08/28/2026 22:00	1.1	1.1	0.0	1.3	13.9	492.5	0.00	1.00
08/28/2026 23:00	1.2	1.2	0.0	1.4	13.9	491.8	0.00	1.00
Average/Sum#:	0.7	0.8	0.0	0.9	13.4	522.7	0.00 #	24.00 #
Minimum:	0.3	0.4	0.0	0.4	12.3	491.8	0.00	1.00
Maximum:	1.2	1.2	0.0	1.4	13.9	617.8	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/29/2026 00:00	1.2	1.3	0.0	1.4	13.9	490.5	0.00	1.00
08/29/2026 01:00	1.1	1.3	0.0	1.3	13.9	490.8	0.00	1.00
08/29/2026 02:00	1.1	1.3	0.0	1.3	14.0	489.7	0.00	1.00
08/29/2026 03:00	1.3	1.3	0.0	1.5	14.0	488.8	0.00	1.00
08/29/2026 04:00	1.3	1.3	0.0	1.5	14.0	487.6	0.00	1.00
08/29/2026 05:00	1.4	1.4	0.0	1.6	14.1	486.1	0.00	1.00
08/29/2026 06:00	1.4	1.5	0.0	1.6	14.1	487.9	0.00	1.00
08/29/2026 07:00	1.2	1.4	0.0	1.4	14.0	491.1	0.00	1.00
08/29/2026 08:00	1.1	1.3	0.0	1.3	14.0	492.4	0.00	1.00
08/29/2026 09:00	1.0	1.2	0.0	1.2	13.9	495.7	0.00	1.00
08/29/2026 10:00	0.9	1.1	0.0	1.1	13.8	500.7	0.00	1.00
08/29/2026 11:00	0.7	1.0	0.0	0.9	13.7	506.0	0.00	1.00
08/29/2026 12:00	0.6	0.9	0.0	0.8	13.5	512.1	0.00	1.00
08/29/2026 13:00	0.5	0.7	0.0	0.7	13.3	516.6	0.00	1.00
08/29/2026 14:00	0.4	0.6	0.0	0.5	13.1	519.7	0.00	1.00
08/29/2026 15:00	0.7	0.6	0.0	0.9	13.5	504.2	0.00	1.00
08/29/2026 16:00	1.0	0.8	0.0	1.2	13.9	494.8	0.00	1.00
08/29/2026 17:00	0.8	0.9	0.0	1.0	13.6	519.5	0.00	1.00
08/29/2026 18:00	0.8	1.0	0.0	1.0	13.7	498.6	0.00	1.00
08/29/2026 19:00	0.8	0.9	0.0	1.0	13.7	498.8	0.00	1.00
08/29/2026 20:00	0.9	1.0	0.0	1.1	13.8	497.5	0.00	1.00
08/29/2026 21:00	1.1	1.1	0.0	1.3	13.8	495.1	0.00	1.00
08/29/2026 22:00	1.2	1.2	0.0	1.4	13.9	493.4	0.00	1.00
08/29/2026 23:00	1.2	1.3	0.0	1.4	13.9	491.7	0.00	1.00
Average/Sum#:	1.0	1.1	0.0	1.2	13.8	497.9	0.00 #	24.00 #
Minimum:	0.4	0.6	0.0	0.5	13.1	486.1	0.00	1.00
Maximum:	1.4	1.5	0.0	1.6	14.1	519.7	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/30/2026 00:00	1.1	1.3	0.0	1.3	14.0	489.8	0.00	1.00
08/30/2026 01:00	1.2	1.3	0.0	1.4	14.0	488.1	0.00	1.00
08/30/2026 02:00	1.3	1.3	0.0	1.5	14.0	489.7	0.00	1.00
08/30/2026 03:00	1.5	1.4	0.0	1.7	14.1	488.3	0.00	1.00
08/30/2026 04:00	1.5	1.5	0.0	1.7	14.1	487.5	0.00	1.00
08/30/2026 05:00	1.5	1.6	0.0	1.7	14.1	486.7	0.00	1.00
08/30/2026 06:00	1.4	1.6	0.0	1.6	14.1	488.8	0.00	1.00
08/30/2026 07:00	1.3	1.5	0.0	1.5	14.0	492.0	0.00	1.00
08/30/2026 08:00	1.1	1.4	0.0	1.3	14.0	494.6	0.00	1.00
08/30/2026 09:00	1.1	1.3	0.0	1.3	13.9	498.1	0.00	1.00
08/30/2026 10:00	0.9	1.1	0.0	1.1	13.7	503.1	0.00	1.00
08/30/2026 11:00	0.8	1.0	0.0	1.0	13.6	508.1	0.00	1.00
08/30/2026 12:00	0.6	0.9	0.0	0.8	13.5	513.5	0.00	1.00
08/30/2026 13:00	0.5	0.7	0.0	0.7	13.3	516.1	0.00	1.00
08/30/2026 14:00	0.5	0.6	0.0	0.6	13.3	516.7	0.00	1.00
08/30/2026 15:00	0.5	0.6	0.0	0.6	13.2	519.1	0.00	1.00
08/30/2026 16:00	0.4	0.5	0.0	0.5	13.0	527.8	0.00	1.00
08/30/2026 17:00	0.3	0.4	0.0	0.4	12.7	551.3	0.00	1.00
08/30/2026 18:00	0.5	0.5	0.0	0.7	13.4	511.9	0.00	1.00
08/30/2026 19:00	0.8	0.6	0.0	1.0	13.7	501.4	0.00	1.00
08/30/2026 20:00	0.9	0.8	0.0	1.1	13.8	498.3	0.00	1.00
08/30/2026 21:00	1.1	1.0	0.0	1.3	13.8	496.2	0.00	1.00
08/30/2026 22:00	1.1	1.1	0.0	1.3	13.8	493.7	0.00	1.00
08/30/2026 23:00	1.3	1.3	0.0	1.5	13.9	493.0	0.00	1.00
Average/Sum#:	1.0	1.1	0.0	1.2	13.7	502.2	0.00 #	24.00 #
Minimum:	0.3	0.4	0.0	0.4	12.7	486.7	0.00	1.00
Maximum:	1.5	1.6	0.0	1.7	14.1	551.3	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/31/2026 00:00	1.3	1.3	0.0	1.5	14.0	491.1	0.00	1.00
08/31/2026 01:00	1.3	1.4	0.0	1.5	14.0	489.2	0.00	1.00
08/31/2026 02:00	1.6	1.5	0.0	1.9	14.0	488.6	0.00	1.00
08/31/2026 03:00	1.9	1.7	0.0	2.2	14.0	488.6	0.00	1.00
08/31/2026 04:00	1.8	1.9	0.0	2.1	14.1	487.3	0.00	1.00
08/31/2026 05:00	1.3	1.8	0.0	1.5	14.2	434.6	0.00	1.00
08/31/2026 06:00	0.8	1.3	0.0	0.9	14.2	357.8	0.00	1.00
08/31/2026 07:00	0.8	0.8	0.0	0.9	14.2	357.8	0.00	1.00
08/31/2026 08:00	0.8	0.6	0.0	0.9	14.2	357.1	0.00	1.00
08/31/2026 09:00	0.7	0.6	0.0	0.8	14.2	356.9	0.00	1.00
08/31/2026 10:00	0.7	0.6	0.0	0.8	14.3	356.8	0.00	1.00
08/31/2026 11:00	0.7	0.6	0.0	0.8	14.3	357.2	0.00	1.00
08/31/2026 12:00	0.7	0.6	0.0	0.8	14.4	382.0	0.00	1.00
08/31/2026 13:00	1.0	0.8	0.0	1.2	13.7	503.8	0.00	1.00
08/31/2026 14:00	0.9	0.9	0.0	1.1	13.7	500.8	0.00	1.00
08/31/2026 15:00	0.9	1.0	0.0	1.1	13.7	500.0	0.00	1.00
08/31/2026 16:00	0.9	1.0	0.0	1.1	13.8	499.1	0.00	1.00
08/31/2026 17:00	1.0	1.0	0.0	1.2	13.8	496.4	0.00	1.00
08/31/2026 18:00	1.1	1.1	0.0	1.3	13.9	493.0	0.00	1.00
08/31/2026 19:00	1.1	1.2	0.0	1.3	14.0	492.0	0.00	1.00
08/31/2026 20:00	1.3	1.3	0.0	1.5	14.0	489.8	0.00	1.00
08/31/2026 21:00	1.0	1.2	0.0	1.2	14.1	400.6	0.00	1.00
08/31/2026 22:00	0.8	1.0	0.0	0.9	14.2	357.4	0.00	1.00
08/31/2026 23:00	0.8	0.7	0.0	0.9	14.2	381.7	0.00	1.00
Average/Sum#:	1.1	1.1	0.0	1.2	14.1	438.3	0.00 #	24.00 #
Minimum:	0.7	0.6	0.0	0.8	13.7	356.8	0.00	1.00
Maximum:	1.9	1.9	0.0	2.2	14.4	503.8	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/01/2026 00:00	0.8	0.6	0.0	0.9	14.2	381.1	0.00	1.00
09/01/2026 01:00	0.8	0.6	0.0	0.9	14.2	356.4	0.00	1.00
09/01/2026 02:00	0.8	0.6	0.0	0.9	14.2	356.2	0.00	1.00
09/01/2026 03:00	0.9	0.6	0.0	1.0	14.2	356.1	0.00	1.00
09/01/2026 04:00	0.8	0.6	0.0	0.9	14.2	356.0	0.00	1.00
09/01/2026 05:00	0.8	0.6	0.0	0.9	14.2	356.1	0.00	1.00
09/01/2026 06:00	0.8	0.6	0.0	0.9	14.2	356.1	0.00	1.00
09/01/2026 07:00	0.8	0.6	0.0	0.9	14.2	355.8	0.00	1.00
09/01/2026 08:00	0.8	0.6	0.0	0.9	14.2	355.8	0.00	1.00
09/01/2026 09:00	0.8	0.6	0.0	0.9	14.2	355.3	0.00	1.00
09/01/2026 10:00	0.7	0.6	0.0	0.8	14.3	355.2	0.00	1.00
09/01/2026 11:00	0.7	0.6	0.0	0.8	14.3	355.0	0.00	1.00
09/01/2026 12:00	0.7	0.6	0.0	0.8	14.3	354.5	0.00	1.00
09/01/2026 13:00	0.7	0.6	0.0	0.8	14.3	353.5	0.00	1.00
09/01/2026 14:00	0.7	0.6	0.0	0.8	14.3	353.2	0.00	1.00
09/01/2026 15:00	0.7	0.6	0.0	0.8	14.3	353.1	0.00	1.00
09/01/2026 16:00	0.7	0.6	0.0	0.8	14.3	353.0	0.00	1.00
09/01/2026 17:00	0.7	0.6	0.0	0.8	14.3	367.7	0.00	1.00
09/01/2026 18:00	0.7	0.6	0.0	0.8	14.3	353.7	0.00	1.00
09/01/2026 19:00	0.7	0.6	0.0	0.8	14.2	354.0	0.00	1.00
09/01/2026 20:00	0.7	0.6	0.0	0.8	14.2	354.8	0.00	1.00
09/01/2026 21:00	0.8	0.6	0.0	0.9	14.2	355.4	0.00	1.00
09/01/2026 22:00	0.8	0.6	0.0	0.9	14.2	355.6	0.00	1.00
09/01/2026 23:00	0.8	0.6	0.0	0.9	14.2	356.1	0.00	1.00
Average/Sum#:	0.8	0.6	0.0	0.9	14.2	356.7	0.00 #	24.00 #
Minimum:	0.7	0.6	0.0	0.8	14.2	353.0	0.00	1.00
Maximum:	0.9	0.6	0.0	1.0	14.3	381.1	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/02/2026 00:00	0.8	0.6	0.0	0.9	14.2	356.5	0.00	1.00
09/02/2026 01:00	0.8	0.6	0.0	0.9	14.2	356.6	0.00	1.00
09/02/2026 02:00	0.8	0.6	0.0	0.9	14.2	356.7	0.00	1.00
09/02/2026 03:00	0.9	0.6	0.0	1.0	14.2	356.9	0.00	1.00
09/02/2026 04:00	0.8	0.6	0.0	0.9	14.2	357.1	0.00	1.00
09/02/2026 05:00	0.8	0.6	0.0	0.9	14.2	356.9	0.00	1.00
09/02/2026 06:00	0.8	0.6	0.0	0.9	14.2	356.8	0.00	1.00
09/02/2026 07:00	0.8	0.6	0.0	0.9	14.2	356.6	0.00	1.00
09/02/2026 08:00	0.7	0.6	0.0	0.8	14.2	356.5	0.00	1.00
09/02/2026 09:00	0.7	0.6	0.0	0.8	14.2	356.1	0.00	1.00
09/02/2026 10:00	0.7	0.6	0.0	0.8	14.3	355.8	0.00	1.00
09/02/2026 11:00	0.7	0.6	0.0	0.8	14.3	354.9	0.00	1.00
09/02/2026 12:00	0.7	0.6	0.0	0.8	14.3	353.9	0.00	1.00
09/02/2026 13:00	0.7	0.6	0.0	0.8	14.3	353.4	0.00	1.00
09/02/2026 14:00	0.7	0.6	0.0	0.8	14.3	353.1	0.00	1.00
09/02/2026 15:00	0.7	0.6	0.0	0.8	14.3	352.9	0.00	1.00
09/02/2026 16:00	0.7	0.6	0.0	0.8	14.3	356.5	0.00	1.00
09/02/2026 17:00	0.7	0.6	0.0	0.8	14.3	379.3	0.00	1.00
09/02/2026 18:00	0.7	0.6	0.0	0.8	14.3	353.2	0.00	1.00
09/02/2026 19:00	0.7	0.6	0.0	0.8	14.3	352.6	0.00	1.00
09/02/2026 20:00	0.7	0.6	0.0	0.8	14.2	352.7	0.00	1.00
09/02/2026 21:00	0.7	0.6	0.0	0.8	14.2	353.4	0.00	1.00
09/02/2026 22:00	0.8	0.6	0.0	0.9	14.2	353.6	0.00	1.00
09/02/2026 23:00	0.8	0.6	0.0	0.9	14.2	353.8	0.00	1.00
Average/Sum#:	0.7	0.6	0.0	0.8	14.2	356.1	0.00 #	24.00 #
Minimum:	0.7	0.6	0.0	0.8	14.2	352.6	0.00	1.00
Maximum:	0.9	0.6	0.0	1.0	14.3	379.3	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/03/2026 00:00	0.8	0.6	0.0	0.9	14.2	354.2	0.00	1.00
09/03/2026 01:00	0.8	0.6	0.0	0.9	14.2	354.5	0.00	1.00
09/03/2026 02:00	0.8	0.6	0.0	0.9	14.2	354.6	0.00	1.00
09/03/2026 03:00	0.9	0.6	0.0	1.0	14.2	354.7	0.00	1.00
09/03/2026 04:00	0.8	0.6	0.0	0.9	14.2	354.7	0.00	1.00
09/03/2026 05:00	0.8	0.6	0.0	0.9	14.2	355.1	0.00	1.00
09/03/2026 06:00	0.8	0.6	0.0	0.9	14.2	359.3	0.00	1.00
09/03/2026 07:00	0.8	0.6	0.0	0.9	14.2	378.8	0.00	1.00
09/03/2026 08:00	0.8	0.6	0.0	0.9	14.2	375.2	0.00	1.00
09/03/2026 09:00	0.7	0.6	0.0	0.8	14.3	395.3	0.00	1.00
09/03/2026 10:00	0.7	0.6	0.0	0.8	14.2	382.8	0.00	1.00
09/03/2026 11:00	0.7	0.6	0.0	0.8	14.2	354.0	0.00	1.00
09/03/2026 12:00	0.7	0.6	0.0	0.8	14.3	382.0	0.00	1.00
09/03/2026 13:00	0.6	0.6	0.0	0.7	14.4	425.6	0.00	1.00
09/03/2026 14:00	0.7	0.6	0.0	0.8	14.4	427.1	0.00	1.00
09/03/2026 15:00	0.6	0.6	0.0	0.7	14.4	427.0	0.00	1.00
09/03/2026 16:00	0.7	0.6	0.0	0.8	14.2	371.1	0.00	1.00
09/03/2026 17:00	0.7	0.6	0.0	0.8	14.3	397.5	0.00	1.00
09/03/2026 18:00	0.8	0.6	0.0	0.9	14.2	357.2	0.00	1.00
09/03/2026 19:00	0.7	0.6	0.0	0.8	14.2	386.0	0.00	1.00
09/03/2026 20:00	0.7	0.6	0.0	0.8	14.3	428.2	0.00	1.00
09/03/2026 21:00	0.8	0.7	0.0	0.9	14.3	432.2	0.00	1.00
09/03/2026 22:00	0.8	0.8	0.0	0.9	14.3	432.3	0.00	1.00
09/03/2026 23:00	0.7	0.8	0.0	0.8	14.3	427.1	0.00	1.00
Average/Sum#:	0.7	0.6	0.0	0.8	14.3	386.1	0.00 #	24.00 #
Minimum:	0.6	0.6	0.0	0.7	14.2	354.0	0.00	1.00
Maximum:	0.9	0.8	0.0	1.0	14.4	432.3	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/04/2026 00:00	0.8	0.7	0.0	0.9	14.2	372.0	0.00	1.00
09/04/2026 01:00	0.8	0.6	0.0	0.9	14.1	355.3	0.00	1.00
09/04/2026 02:00	0.8	0.6	0.0	0.9	14.2	355.4	0.00	1.00
09/04/2026 03:00	0.8	0.6	0.0	1.0	14.2	355.0	0.00	1.00
09/04/2026 04:00	0.8	0.6	0.0	0.9	14.2	366.5	0.00	1.00
09/04/2026 05:00	0.7	0.7	0.0	0.8	14.3	422.8	0.00	1.00
09/04/2026 06:00	0.8	0.6	0.0	0.9	14.2	374.8	0.00	1.00
09/04/2026 07:00	0.8	0.6	0.0	0.9	14.2	380.1	0.00	1.00
09/04/2026 08:00	0.8	0.6	0.0	0.9	14.2	354.9	0.00	1.00
09/04/2026 09:00	0.8	0.6	0.0	0.9	14.2	354.6	0.00	1.00
09/04/2026 10:00	0.7	0.6	0.0	0.8	14.3	385.1	0.00	1.00
09/04/2026 11:00	0.8	0.6	0.0	0.9	14.2	354.5	0.00	1.00
09/04/2026 12:00	0.7	0.6	0.0	0.8	14.3	354.3	0.00	1.00
09/04/2026 13:00	0.7	0.6	0.0	0.8	14.3	353.6	0.00	1.00
09/04/2026 14:00	0.7	0.6	0.0	0.8	14.3	353.3	0.00	1.00
09/04/2026 15:00	0.7	0.6	0.0	0.8	14.3	353.1	0.00	1.00
09/04/2026 16:00	0.7	0.6	0.0	0.8	14.3	367.9	0.00	1.00
09/04/2026 17:00	0.7	0.6	0.0	0.8	14.4	382.7	0.00	1.00
09/04/2026 18:00	0.7	0.6	0.0	0.8	14.4	428.9	0.00	1.00
09/04/2026 19:00	0.7	0.7	0.0	0.8	14.4	427.7	0.00	1.00
09/04/2026 20:00	0.7	0.7	0.0	0.8	14.4	428.1	0.00	1.00
09/04/2026 21:00	0.7	0.7	0.0	0.8	14.4	429.3	0.00	1.00
09/04/2026 22:00	0.7	0.7	0.0	0.8	14.4	428.5	0.00	1.00
09/04/2026 23:00	0.8	0.7	0.0	0.9	14.2	362.6	0.00	1.00
Average/Sum#:	0.7	0.6	0.0	0.9	14.3	379.2	0.00 #	24.00 #
Minimum:	0.7	0.6	0.0	0.8	14.1	353.1	0.00	1.00
Maximum:	0.8	0.7	0.0	1.0	14.4	429.3	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/05/2026 00:00	0.8	0.7	0.0	0.9	14.2	373.4	0.00	1.00
09/05/2026 01:00	0.8	0.7	0.0	0.9	14.2	371.6	0.00	1.00
09/05/2026 02:00	0.8	0.7	0.0	0.9	14.2	381.9	0.00	1.00
09/05/2026 03:00	0.9	0.7	0.0	1.0	14.2	356.7	0.00	1.00
09/05/2026 04:00	0.7	0.7	0.0	0.8	14.3	406.9	0.00	1.00
09/05/2026 05:00	0.7	0.7	0.0	0.8	14.3	428.4	0.00	1.00
09/05/2026 06:00	0.8	0.7	0.0	0.9	14.1	356.3	0.00	1.00
09/05/2026 07:00	0.8	0.7	0.0	0.9	14.2	355.3	0.02	1.00
09/05/2026 08:00	0.8	0.6	0.0	0.9	14.2	354.6	0.00	1.00
09/05/2026 09:00	0.8	0.6	0.0	0.9	14.2	354.2	0.00	1.00
09/05/2026 10:00	0.7	0.6	0.0	0.8	14.3	353.6	0.00	1.00
09/05/2026 11:00	0.8	0.6	0.0	0.9	14.3	353.5	0.00	1.00
09/05/2026 12:00	0.8	0.6	0.0	0.9	14.3	353.4	0.00	1.00
09/05/2026 13:00	0.7	0.6	0.0	0.8	14.3	353.0	0.00	1.00
09/05/2026 14:00	0.7	0.6	0.0	0.8	14.4	353.2	0.00	1.00
09/05/2026 15:00	0.7	0.6	0.0	0.8	14.3	353.6	0.00	1.00
09/05/2026 16:00	0.9	0.7	0.0	1.0	14.4	382.6	0.00	1.00
09/05/2026 17:00	0.8	0.7	0.0	0.9	14.3	402.6	0.00	1.00
09/05/2026 18:00	0.7	0.7	0.0	0.8	14.3	361.9	0.00	1.00
09/05/2026 19:00	0.7	0.6	0.0	0.8	14.3	367.4	0.00	1.00
09/05/2026 20:00	0.7	0.6	0.0	0.8	14.3	354.7	0.00	1.00
09/05/2026 21:00	0.8	0.6	0.0	0.9	14.3	367.8	0.00	1.00
09/05/2026 22:00	0.8	0.6	0.0	0.9	14.3	370.8	0.00	1.00
09/05/2026 23:00	0.8	0.7	0.0	0.9	14.3	365.1	0.00	1.00
Average/Sum#:	0.8	0.7	0.0	0.9	14.3	368.0	0.02 #	24.00 #
Minimum:	0.7	0.6	0.0	0.8	14.1	353.0	0.00	1.00
Maximum:	0.9	0.7	0.0	1.0	14.4	428.4	0.02	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/06/2026 00:00	0.8	0.7	0.0	0.9	14.2	354.8	0.00	1.00
09/06/2026 01:00	0.8	0.6	0.0	0.9	14.2	358.0	0.00	1.00
09/06/2026 02:00	0.8	0.6	0.0	0.9	14.2	369.4	0.00	1.00
09/06/2026 03:00	0.9	0.7	0.0	1.0	14.2	354.7	0.00	1.00
09/06/2026 04:00	0.8	0.7	0.0	0.9	14.2	358.5	0.00	1.00
09/06/2026 05:00	0.8	0.6	0.0	0.9	14.2	355.7	0.00	1.00
09/06/2026 06:00	0.8	0.6	0.0	0.9	14.2	386.9	0.00	1.00
09/06/2026 07:00	0.8	0.6	0.0	0.9	14.2	354.7	0.00	1.00
09/06/2026 08:00	0.8	0.6	0.0	0.9	14.2	354.0	0.00	1.00
09/06/2026 09:00	0.8	0.6	0.0	0.9	14.2	353.6	0.00	1.00
09/06/2026 10:00	0.8	0.6	0.0	0.9	14.3	353.1	0.00	1.00
09/06/2026 11:00	0.8	0.6	0.0	0.9	14.3	353.0	0.00	1.00
09/06/2026 12:00	0.8	0.6	0.0	0.9	14.3	352.6	0.00	1.00
09/06/2026 13:00	0.8	0.6	0.0	0.9	14.4	351.9	0.00	1.00
09/06/2026 14:00	0.8	0.6	0.0	0.9	14.4	352.9	0.00	1.00
09/06/2026 15:00	0.7	0.6	0.0	0.8	14.5	385.5	0.00	1.00
09/06/2026 16:00	0.7	0.6	0.0	0.8	14.4	372.4	0.00	1.00
09/06/2026 17:00	0.7	0.6	0.0	0.8	14.3	351.8	0.00	1.00
09/06/2026 18:00	0.7	0.6	0.0	0.8	14.3	352.1	0.00	1.00
09/06/2026 19:00	0.7	0.6	0.0	0.8	14.3	352.4	0.00	1.00
09/06/2026 20:00	0.8	0.6	0.0	0.9	14.3	353.2	0.00	1.00
09/06/2026 21:00	0.8	0.6	0.0	0.9	14.3	353.3	0.00	1.00
09/06/2026 22:00	0.8	0.6	0.0	0.9	14.2	354.1	0.00	1.00
09/06/2026 23:00	0.8	0.6	0.0	0.9	14.3	380.1	0.00	1.00
Average/Sum#:	0.8	0.6	0.0	0.9	14.3	359.1	0.00 #	24.00 #
Minimum:	0.7	0.6	0.0	0.8	14.2	351.8	0.00	1.00
Maximum:	0.9	0.7	0.0	1.0	14.5	386.9	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/07/2026 00:00	0.8	0.6	0.0	0.9	14.2	354.9	0.00	1.00
09/07/2026 01:00	0.8	0.6	0.0	0.9	14.2	355.4	0.00	1.00
09/07/2026 02:00	0.8	0.6	0.0	0.9	14.2	355.8	0.00	1.00
09/07/2026 03:00	1.0	0.7	0.0	1.1	14.2	356.2	0.00	1.00
09/07/2026 04:00	0.9	0.7	0.0	1.0	14.2	356.2	0.00	1.00
09/07/2026 05:00	0.9	0.7	0.0	1.0	14.2	356.7	0.00	1.00
09/07/2026 06:00	0.9	0.7	0.0	1.0	14.2	375.5	0.00	1.00
09/07/2026 07:00	0.9	0.7	0.0	1.0	14.2	356.0	0.00	1.00
09/07/2026 08:00	0.8	0.7	0.0	0.9	14.2	354.9	0.00	1.00
09/07/2026 09:00	0.8	0.6	0.0	0.9	14.3	354.1	0.00	1.00
09/07/2026 10:00	0.8	0.6	0.0	0.9	14.3	353.5	0.00	1.00
09/07/2026 11:00	0.8	0.6	0.0	0.9	14.3	354.2	0.00	1.00
09/07/2026 12:00	0.8	0.6	0.0	0.9	14.4	353.7	0.00	1.00
09/07/2026 13:00	0.7	0.6	0.0	0.8	14.4	352.0	0.00	1.00
09/07/2026 14:00	0.7	0.6	0.0	0.8	14.4	353.5	0.00	1.00
09/07/2026 15:00	0.7	0.6	0.0	0.8	14.4	351.6	0.00	1.00
09/07/2026 16:00	0.7	0.6	0.0	0.8	14.4	385.3	0.00	1.00
09/07/2026 17:00	0.7	0.6	0.0	0.8	14.4	379.4	0.00	1.00
09/07/2026 18:00	0.7	0.6	0.0	0.8	14.4	375.6	0.00	1.00
09/07/2026 19:00	0.7	0.6	0.0	0.8	14.5	421.4	0.00	1.00
09/07/2026 20:00	0.8	0.7	0.0	0.9	14.5	423.7	0.00	1.00
09/07/2026 21:00	0.9	0.7	0.0	1.0	14.4	423.8	0.00	1.00
09/07/2026 22:00	0.8	0.8	0.0	0.9	14.4	424.1	0.00	1.00
09/07/2026 23:00	0.8	0.8	0.0	0.9	14.4	425.2	0.00	1.00
Average/Sum#:	0.8	0.7	0.0	0.9	14.3	373.0	0.00 #	24.00 #
Minimum:	0.7	0.6	0.0	0.8	14.2	351.6	0.00	1.00
Maximum:	1.0	0.8	0.0	1.1	14.5	425.2	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/08/2026 00:00	0.9	0.8	0.0	1.0	14.4	425.4	0.00	1.00
09/08/2026 01:00	1.0	0.8	0.0	1.1	14.3	392.6	0.00	1.00
09/08/2026 02:00	0.9	0.8	0.0	1.0	14.2	351.9	0.00	1.00
09/08/2026 03:00	1.0	0.8	0.0	1.1	14.2	364.0	0.00	1.00
09/08/2026 04:00	1.1	0.8	0.0	1.2	14.3	415.5	0.00	1.00
09/08/2026 05:00	0.9	0.9	0.0	1.0	14.3	427.0	0.00	1.00
09/08/2026 06:00	1.0	0.9	0.0	1.1	14.2	379.8	0.00	1.00
09/08/2026 07:00	1.0	0.8	0.0	1.1	14.2	352.1	0.00	1.00
09/08/2026 08:00	0.9	0.8	0.0	1.0	14.3	351.2	0.00	1.00
09/08/2026 09:00	0.8	0.7	0.0	0.9	14.3	351.0	0.00	1.00
09/08/2026 10:00	0.8	0.6	0.0	0.9	14.3	349.7	0.00	1.00
09/08/2026 11:00	0.8	0.6	0.0	0.9	14.4	350.6	0.00	1.00
09/08/2026 12:00	0.8	0.6	0.0	0.8	14.4	360.8	0.00	1.00
09/08/2026 13:00	0.7	0.6	0.0	0.8	14.4	427.6	0.00	1.00
09/08/2026 14:00	0.5	0.6	0.0	0.6	12.6	577.3	0.00	1.00
09/08/2026 15:00	0.2	0.5	0.0	0.3	12.1	607.4	0.00	1.00
09/08/2026 16:00	0.2	0.4	0.0	0.3	12.1	614.8	0.00	1.00
09/08/2026 17:00	0.2	0.3	0.0	0.3	11.9	625.0	0.00	1.00
09/08/2026 18:00	0.2	0.3	0.0	0.3	12.0	622.8	0.00	1.00
09/08/2026 19:00	0.3	0.3	0.0	0.4	12.0	622.0	0.00	1.00
09/08/2026 20:00	0.3	0.3	0.0	0.4	12.2	609.8	0.00	1.00
09/08/2026 21:00	0.3	0.4	0.0	0.4	12.1	607.1	0.00	1.00
09/08/2026 22:00	0.6	0.5	0.0	0.7	12.8	556.1	0.00	1.00
09/08/2026 23:00	0.9	0.6	0.0	1.0	14.4	418.0	0.00	1.00
Average/Sum#:	0.7	0.6	0.0	0.8	13.5	465.0	0.00 #	24.00 #
Minimum:	0.2	0.3	0.0	0.3	11.9	349.7	0.00	1.00
Maximum:	1.1	0.9	0.0	1.2	14.4	625.0	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/09/2026 00:00	0.9	0.7	0.0	1.0	14.3	402.2	0.00	1.00
09/09/2026 01:00	0.9	0.8	0.0	1.0	14.2	370.9	0.00	1.00
09/09/2026 02:00	1.0	0.8	0.0	1.1	14.2	352.7	0.00	1.00
09/09/2026 03:00	1.0	0.8	0.0	1.1	14.2	353.3	0.00	1.00
09/09/2026 04:00	1.0	0.8	0.0	1.1	14.2	367.2	0.00	1.00
09/09/2026 05:00	1.4	1.0	0.0	1.6	14.1	479.7	0.00	1.00
09/09/2026 06:00	1.2	1.2	0.0	1.4	13.8	506.2	0.00	1.00
09/09/2026 07:00	0.6	1.2	0.0	0.8	13.1	557.6	0.00	1.00
09/09/2026 08:00	0.3	0.8	0.0	0.4	12.3	605.9	0.00	1.00
09/09/2026 09:00	0.3	0.5	0.0	0.4	12.1	613.3	0.00	1.00
09/09/2026 10:00	0.2	0.3	0.0	0.3	11.9	608.1	0.00	1.00
09/09/2026 11:00	0.2	0.3	0.0	0.3	12.2	603.6	0.00	1.00
09/09/2026 12:00	0.2	0.3	0.0	0.3	12.4	594.1	0.00	1.00
09/09/2026 13:00	0.2	0.3	0.0	0.3	12.1	612.9	0.00	1.00
09/09/2026 14:00	0.2	0.3	0.0	0.3	12.0	614.8	0.00	1.00
09/09/2026 15:00	0.2	0.3	0.0	0.3	11.8	629.7	0.00	1.00
09/09/2026 16:00	0.2	0.3	0.0	0.3	11.8	628.5	0.00	1.00
09/09/2026 17:00	0.2	0.3	0.0	0.3	12.1	610.9	0.00	1.00
09/09/2026 18:00	0.2	0.3	0.0	0.3	11.8	626.5	0.00	1.00
09/09/2026 19:00	0.2	0.3	0.0	0.3	12.4	593.0	0.00	1.00
09/09/2026 20:00	0.2	0.3	0.0	0.3	11.9	624.8	0.00	1.00
09/09/2026 21:00	0.3	0.3	0.0	0.4	11.9	625.0	0.00	1.00
09/09/2026 22:00	0.4	0.4	0.0	0.5	12.3	598.0	0.00	1.00
09/09/2026 23:00	0.9	0.6	0.0	1.0	14.5	426.7	0.00	1.00
Average/Sum#:	0.5	0.6	0.0	0.6	12.8	541.9	0.00 #	24.00 #
Minimum:	0.2	0.3	0.0	0.3	11.8	352.7	0.00	1.00
Maximum:	1.4	1.2	0.0	1.6	14.5	629.7	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/10/2026 00:00	0.8	0.7	0.0	0.9	14.5	426.5	0.00	1.00
09/10/2026 01:00	0.8	0.8	0.0	0.9	14.5	424.7	0.00	1.00
09/10/2026 02:00	0.8	0.8	0.0	0.9	14.5	417.6	0.00	1.00
09/10/2026 03:00	0.9	0.8	0.0	1.0	14.3	351.9	0.00	1.00
09/10/2026 04:00	0.8	0.7	0.0	0.9	14.3	358.6	0.00	1.00
09/10/2026 05:00	0.7	0.7	0.0	0.8	14.5	420.5	0.00	1.00
09/10/2026 06:00	0.8	0.7	0.0	0.9	14.4	378.7	0.00	1.00
09/10/2026 07:00	0.8	0.7	0.0	0.9	14.3	349.0	0.00	1.00
09/10/2026 08:00	0.8	0.6	0.0	0.9	14.4	348.6	0.00	1.00
09/10/2026 09:00	0.8	0.6	0.0	0.9	14.4	348.3	0.00	1.00
09/10/2026 10:00	0.8	0.6	0.0	0.9	14.4	348.6	0.00	1.00
09/10/2026 11:00	0.7	0.6	0.0	0.8	14.4	375.0	0.00	1.00
09/10/2026 12:00	0.9	0.7	0.0	1.1	13.7	492.5	0.00	1.00
09/10/2026 13:00	0.7	0.8	0.0	0.9	13.6	498.0	0.00	1.00
09/10/2026 14:00	0.7	0.9	0.0	0.9	13.5	502.0	0.00	1.00
09/10/2026 15:00	0.6	0.8	0.0	0.8	13.4	503.4	0.00	1.00
09/10/2026 16:00	0.5	0.7	0.0	0.6	13.0	534.1	0.00	1.00
09/10/2026 17:00	0.3	0.6	0.0	0.5	12.6	564.3	0.00	1.00
09/10/2026 18:00	0.8	0.6	0.0	1.0	13.6	498.9	0.00	1.00
09/10/2026 19:00	1.1	0.8	0.0	1.3	13.8	491.2	0.00	1.00
09/10/2026 20:00	1.2	1.1	0.0	1.4	13.8	491.1	0.00	1.00
09/10/2026 21:00	0.8	1.1	0.0	1.0	13.5	502.6	0.00	1.00
09/10/2026 22:00	0.9	1.1	0.0	1.1	13.6	498.4	0.00	1.00
09/10/2026 23:00	0.9	0.9	0.0	1.0	14.3	357.4	0.00	1.00
Average/Sum#:	0.8	0.8	0.0	0.9	14.0	436.7	0.00 #	24.00 #
Minimum:	0.3	0.6	0.0	0.5	12.6	348.3	0.00	1.00
Maximum:	1.2	1.1	0.0	1.4	14.5	564.3	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/11/2026 00:00	0.8	0.8	0.0	0.9	14.3	349.6	0.00	1.00
09/11/2026 01:00	0.8	0.6	0.0	0.9	14.3	349.8	0.00	1.00
09/11/2026 02:00	0.8	0.6	0.0	0.9	14.3	349.8	0.00	1.00
09/11/2026 03:00	0.9	0.6	0.0	1.0	14.3	350.1	0.00	1.00
09/11/2026 04:00	0.8	0.6	0.0	0.9	14.3	350.8	0.00	1.00
09/11/2026 05:00	0.8	0.6	0.0	0.9	14.3	351.2	0.00	1.00
09/11/2026 06:00	0.8	0.6	0.0	0.9	14.2	351.5	0.00	1.00
09/11/2026 07:00	0.8	0.6	0.0	0.9	14.2	351.4	0.00	1.00
09/11/2026 08:00	0.8	0.6	0.0	0.9	14.3	350.8	0.00	1.00
09/11/2026 09:00	0.8	0.6	0.0	0.9	14.3	350.3	0.00	1.00
09/11/2026 10:00	0.8	0.6	0.0	0.9	14.3	350.4	0.00	1.00
09/11/2026 11:00	0.8	0.6	0.0	0.9	14.4	351.0	0.00	1.00
09/11/2026 12:00	0.7	0.6	0.0	0.8	14.4	350.3	0.00	1.00
09/11/2026 13:00	0.7	0.6	0.0	0.8	14.4	349.3	0.00	1.00
09/11/2026 14:00	0.7	0.6	0.0	0.8	14.4	349.7	0.00	1.00
09/11/2026 15:00	0.7	0.6	0.0	0.8	14.5	409.9	0.00	1.00
09/11/2026 16:00	0.7	0.6	0.0	0.8	14.3	382.4	0.00	1.00
09/11/2026 17:00	0.7	0.6	0.0	0.8	14.3	379.6	0.00	1.00
09/11/2026 18:00	0.8	0.6	0.0	0.9	14.2	351.6	0.00	1.00
09/11/2026 19:00	0.8	0.6	0.0	0.9	14.2	351.6	0.00	1.00
09/11/2026 20:00	0.8	0.6	0.0	0.9	14.2	351.1	0.00	1.00
09/11/2026 21:00	0.8	0.6	0.0	0.9	14.3	350.5	0.00	1.00
09/11/2026 22:00	0.8	0.6	0.0	0.9	14.3	350.4	0.00	1.00
09/11/2026 23:00	0.8	0.6	0.0	0.9	14.2	350.3	0.00	1.00
Average/Sum#:	0.8	0.6	0.0	0.9	14.3	355.6	0.00 #	24.00 #
Minimum:	0.7	0.6	0.0	0.8	14.2	349.3	0.00	1.00
Maximum:	0.9	0.8	0.0	1.0	14.5	409.9	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/12/2026 00:00	0.8	0.6	0.0	0.9	14.2	350.3	0.00	1.00
09/12/2026 01:00	0.9	0.6	0.0	1.0	14.2	350.4	0.00	1.00
09/12/2026 02:00	0.8	0.6	0.0	0.9	14.2	350.4	0.00	1.00
09/12/2026 03:00	0.9	0.7	0.0	1.0	14.2	350.6	0.00	1.00
09/12/2026 04:00	0.9	0.7	0.0	1.0	14.2	350.7	0.00	1.00
09/12/2026 05:00	0.8	0.7	0.0	0.9	14.2	350.8	0.00	1.00
09/12/2026 06:00	0.9	0.7	0.0	1.0	14.2	351.0	0.00	1.00
09/12/2026 07:00	0.8	0.7	0.0	0.9	14.3	350.8	0.00	1.00
09/12/2026 08:00	0.8	0.7	0.0	0.9	14.3	350.4	0.00	1.00
09/12/2026 09:00	0.8	0.6	0.0	0.9	14.3	350.0	0.00	1.00
09/12/2026 10:00	0.8	0.6	0.0	0.9	14.3	349.9	0.00	1.00
09/12/2026 11:00	0.8	0.6	0.0	0.9	14.4	350.2	0.00	1.00
09/12/2026 12:00	0.7	0.6	0.0	0.8	14.4	349.8	0.00	1.00
09/12/2026 13:00	0.7	0.6	0.0	0.8	14.4	348.7	0.00	1.00
09/12/2026 14:00	0.7	0.6	0.0	0.8	14.4	348.6	0.00	1.00
09/12/2026 15:00	0.7	0.6	0.0	0.8	14.4	348.7	0.00	1.00
09/12/2026 16:00	0.7	0.6	0.0	0.8	14.4	370.0	0.00	1.00
09/12/2026 17:00	0.7	0.6	0.0	0.8	14.3	352.2	0.00	1.00
09/12/2026 18:00	0.7	0.6	0.0	0.8	14.3	349.1	0.00	1.00
09/12/2026 19:00	0.7	0.6	0.0	0.8	14.3	349.6	0.00	1.00
09/12/2026 20:00	0.8	0.6	0.0	0.9	14.3	349.7	0.00	1.00
09/12/2026 21:00	0.8	0.6	0.0	0.9	14.3	350.8	0.00	1.00
09/12/2026 22:00	0.8	0.6	0.0	0.9	14.2	354.5	0.00	1.00
09/12/2026 23:00	0.8	0.6	0.0	0.9	14.2	351.5	0.00	1.00
Average/Sum#:	0.8	0.6	0.0	0.9	14.3	351.2	0.00 #	24.00 #
Minimum:	0.7	0.6	0.0	0.8	14.2	348.6	0.00	1.00
Maximum:	0.9	0.7	0.0	1.0	14.4	370.0	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/13/2026 00:00	0.8	0.6	0.0	0.9	14.2	351.8	0.00	1.00
09/13/2026 01:00	0.8	0.6	0.0	0.9	14.2	352.0	0.00	1.00
09/13/2026 02:00	0.9	0.6	0.0	1.0	14.2	352.2	0.00	1.00
09/13/2026 03:00	0.9	0.7	0.0	1.1	14.2	352.4	0.00	1.00
09/13/2026 04:00	0.9	0.7	0.0	1.0	14.2	352.5	0.00	1.00
09/13/2026 05:00	0.8	0.7	0.0	0.9	14.3	400.9	0.00	1.00
09/13/2026 06:00	0.9	0.7	0.0	1.0	14.2	373.0	0.00	1.00
09/13/2026 07:00	0.9	0.7	0.0	1.0	14.2	352.4	0.00	1.00
09/13/2026 08:00	0.8	0.7	0.0	0.9	14.2	351.8	0.00	1.00
09/13/2026 09:00	0.8	0.7	0.0	0.9	14.2	351.9	0.00	1.00
09/13/2026 10:00	0.8	0.6	0.0	0.9	14.3	351.9	0.00	1.00
09/13/2026 11:00	0.9	0.6	0.0	1.0	14.3	352.3	0.00	1.00
09/13/2026 12:00	0.8	0.7	0.0	0.9	14.3	352.0	0.00	1.00
09/13/2026 13:00	0.8	0.7	0.0	0.9	14.3	351.3	0.00	1.00
09/13/2026 14:00	0.8	0.6	0.0	0.9	14.3	351.1	0.00	1.00
09/13/2026 15:00	0.8	0.6	0.0	0.9	14.3	350.9	0.00	1.00
09/13/2026 16:00	0.8	0.6	0.0	0.9	14.4	373.7	0.00	1.00
09/13/2026 17:00	0.8	0.7	0.0	0.9	14.5	405.5	0.00	1.00
09/13/2026 18:00	0.8	0.7	0.0	0.9	14.3	353.3	0.00	1.00
09/13/2026 19:00	0.8	0.6	0.0	0.9	14.3	351.0	0.00	1.00
09/13/2026 20:00	0.8	0.6	0.0	0.9	14.3	352.2	0.00	1.00
09/13/2026 21:00	0.9	0.6	0.0	1.0	14.3	352.0	0.00	1.00
09/13/2026 22:00	0.8	0.6	0.0	0.9	14.3	352.1	0.00	1.00
09/13/2026 23:00	0.9	0.7	0.0	1.0	14.3	352.9	0.00	1.00
Average/Sum#:	0.8	0.7	0.0	0.9	14.3	358.0	0.00 #	24.00 #
Minimum:	0.8	0.6	0.0	0.9	14.2	350.9	0.00	1.00
Maximum:	0.9	0.7	0.0	1.1	14.5	405.5	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/14/2026 00:00	1.0	0.7	0.0	1.1	14.2	352.8	0.00	1.00
09/14/2026 01:00	0.9	0.7	0.0	1.0	14.2	352.8	0.00	1.00
09/14/2026 02:00	0.9	0.7	0.0	1.0	14.2	353.1	0.00	1.00
09/14/2026 03:00	1.0	0.7	0.0	1.1	14.2	353.4	0.00	1.00
09/14/2026 04:00	1.0	0.7	0.0	1.1	14.2	353.6	0.00	1.00
09/14/2026 05:00	1.0	0.7	0.0	1.1	14.2	358.0	0.00	1.00
09/14/2026 06:00	1.0	0.7	0.0	1.1	14.2	370.1	0.00	1.00
09/14/2026 07:00	0.9	0.7	0.0	1.0	14.2	352.6	0.00	1.00
09/14/2026 08:00	0.9	0.7	0.0	1.0	14.2	352.0	0.00	1.00
09/14/2026 09:00	0.9	0.7	0.0	1.0	14.3	351.2	0.00	1.00
09/14/2026 10:00	0.8	0.7	0.0	0.9	14.3	351.0	0.00	1.00
09/14/2026 11:00	0.8	0.6	0.0	0.9	14.3	351.6	0.00	1.00
09/14/2026 12:00	0.8	0.6	0.0	0.9	14.4	351.4	0.00	1.00
09/14/2026 13:00	0.8	0.6	0.0	0.9	14.4	350.6	0.00	1.00
09/14/2026 14:00	0.8	0.6	0.0	0.9	14.4	350.5	0.00	1.00
09/14/2026 15:00	0.8	0.6	0.0	0.9	14.4	350.1	0.00	1.00
09/14/2026 16:00	0.8	0.6	0.0	0.9	14.4	369.2	0.00	1.00
09/14/2026 17:00	0.8	0.6	0.0	0.9	14.4	380.7	0.00	1.00
09/14/2026 18:00	0.8	0.6	0.0	0.9	14.4	350.2	0.00	1.00
09/14/2026 19:00	0.8	0.6	0.0	0.9	14.3	360.0	0.00	1.00
09/14/2026 20:00	0.8	0.6	0.0	0.9	14.3	352.5	0.00	1.00
09/14/2026 21:00	0.9	0.7	0.0	1.0	14.3	350.6	0.00	1.00
09/14/2026 22:00	0.9	0.7	0.0	1.0	14.3	352.0	0.00	1.00
09/14/2026 23:00	0.8	0.7	0.0	0.9	14.4	406.7	0.00	1.00
Average/Sum#:	0.9	0.7	0.0	1.0	14.3	357.4	0.00 #	24.00 #
Minimum:	0.8	0.6	0.0	0.9	14.2	350.1	0.00	1.00
Maximum:	1.0	0.7	0.0	1.1	14.4	406.7	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/15/2026 00:00	0.8	0.7	0.0	0.9	14.3	377.1	0.00	1.00
09/15/2026 01:00	0.8	0.7	0.0	0.9	14.2	357.0	0.00	1.00
09/15/2026 02:00	0.9	0.7	0.0	1.0	14.2	352.2	0.00	1.00
09/15/2026 03:00	0.9	0.7	0.0	1.1	14.2	352.4	0.00	1.00
09/15/2026 04:00	0.8	0.7	0.0	0.9	14.2	364.0	0.00	1.00
09/15/2026 05:00	0.7	0.7	0.0	0.8	14.4	426.9	0.00	1.00
09/15/2026 06:00	0.8	0.7	0.0	0.9	14.3	427.2	0.00	1.00
09/15/2026 07:00	0.8	0.7	0.0	0.9	14.3	418.6	0.00	1.00
09/15/2026 08:00	0.7	0.7	0.0	0.8	14.4	427.1	0.00	1.00
09/15/2026 09:00	0.7	0.7	0.0	0.8	14.4	426.2	0.00	1.00
09/15/2026 10:00	0.7	0.7	0.0	0.8	14.4	406.8	0.00	1.00
09/15/2026 11:00	0.7	0.7	0.0	0.8	14.5	426.7	0.00	1.00
09/15/2026 12:00	0.7	0.7	0.0	0.8	14.5	416.2	0.00	1.00
09/15/2026 13:00	0.7	0.7	0.0	0.8	14.5	415.6	0.00	1.00
09/15/2026 14:00	0.7	0.7	0.0	0.8	14.5	415.4	0.00	1.00
09/15/2026 15:00	0.7	0.7	0.0	0.8	14.5	413.2	0.00	1.00
09/15/2026 16:00	0.7	0.7	0.0	0.8	14.4	369.3	0.00	1.00
09/15/2026 17:00	0.7	0.6	0.0	0.8	14.4	355.2	0.00	1.00
09/15/2026 18:00	0.7	0.6	0.0	0.8	14.3	351.7	0.00	1.00
09/15/2026 19:00	0.7	0.6	0.0	0.8	14.3	351.4	0.00	1.00
09/15/2026 20:00	0.7	0.6	0.0	0.8	14.3	352.2	0.00	1.00
09/15/2026 21:00	0.7	0.6	0.0	0.8	14.2	352.8	0.00	1.00
09/15/2026 22:00	0.8	0.6	0.0	0.9	14.2	353.2	0.00	1.00
09/15/2026 23:00	0.8	0.6	0.0	0.9	14.2	353.6	0.00	1.00
Average/Sum#:	0.7	0.7	0.0	0.9	14.3	385.9	0.00 #	24.00 #
Minimum:	0.7	0.6	0.0	0.8	14.2	351.4	0.00	1.00
Maximum:	0.9	0.7	0.0	1.1	14.5	427.2	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/16/2026 00:00	0.8	0.6	0.0	0.9	14.2	353.8	0.00	1.00
09/16/2026 01:00	0.8	0.6	0.0	0.9	14.2	354.0	0.00	1.00
09/16/2026 02:00	0.8	0.6	0.0	0.9	14.2	354.6	0.00	1.00
09/16/2026 03:00	0.8	0.6	0.0	1.0	14.2	354.8	0.00	1.00
09/16/2026 04:00	0.8	0.6	0.0	0.9	14.2	354.9	0.00	1.00
09/16/2026 05:00	0.8	0.6	0.0	0.9	14.2	355.5	0.00	1.00
09/16/2026 06:00	0.8	0.6	0.0	0.9	14.2	362.0	0.00	1.00
09/16/2026 07:00	0.7	0.6	0.0	0.8	14.3	401.8	0.00	1.00
09/16/2026 08:00	0.7	0.7	0.0	0.8	14.3	430.4	0.00	1.00
09/16/2026 09:00	0.7	0.7	0.0	0.8	14.3	415.7	0.00	1.00
09/16/2026 10:00	0.7	0.7	0.0	0.8	14.2	359.1	0.00	1.00
09/16/2026 11:00	0.7	0.6	0.0	0.8	14.3	357.4	0.00	1.00
09/16/2026 12:00	0.8	0.6	0.0	0.9	14.3	357.3	0.00	1.00
09/16/2026 13:00	0.6	0.6	0.0	0.7	14.4	415.9	0.00	1.00
09/16/2026 14:00	0.7	0.6	0.0	0.8	14.5	434.5	0.00	1.00
09/16/2026 15:00	0.7	0.6	0.0	0.8	14.3	388.1	0.00	1.00
09/16/2026 16:00	0.7	0.6	0.0	0.8	14.3	353.1	0.00	1.00
09/16/2026 17:00	0.7	0.6	0.0	0.8	14.3	352.9	0.00	1.00
09/16/2026 18:00	0.7	0.6	0.0	0.8	14.2	353.8	0.00	1.00
09/16/2026 19:00	0.8	0.6	0.0	0.9	14.2	354.1	0.00	1.00
09/16/2026 20:00	0.8	0.6	0.0	0.9	14.2	354.3	0.00	1.00
09/16/2026 21:00	0.8	0.6	0.0	0.9	14.2	354.5	0.00	1.00
09/16/2026 22:00	0.8	0.6	0.0	0.9	14.2	354.8	0.00	1.00
09/16/2026 23:00	0.8	0.6	0.0	0.9	14.2	355.0	0.00	1.00
Average/Sum#:	0.8	0.6	0.0	0.9	14.3	370.1	0.00 #	24.00 #
Minimum:	0.6	0.6	0.0	0.7	14.2	352.9	0.00	1.00
Maximum:	0.8	0.7	0.0	1.0	14.5	434.5	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/17/2026 00:00	0.8	0.6	0.0	0.9	14.2	355.0	0.00	1.00
09/17/2026 01:00	0.8	0.6	0.0	0.9	14.2	355.1	0.00	1.00
09/17/2026 02:00	0.8	0.6	0.0	0.9	14.2	355.2	0.00	1.00
09/17/2026 03:00	0.9	0.6	0.0	1.0	14.2	355.6	0.00	1.00
09/17/2026 04:00	0.8	0.6	0.0	0.9	14.2	355.3	0.00	1.00
09/17/2026 05:00	0.8	0.7	0.0	0.9	14.3	391.8	0.00	1.00
09/17/2026 06:00	0.8	0.7	0.0	0.9	14.2	389.0	0.00	1.00
09/17/2026 07:00	0.8	0.7	0.0	0.9	14.2	355.1	0.00	1.00
09/17/2026 08:00	0.8	0.6	0.0	0.9	14.2	355.1	0.00	1.00
09/17/2026 09:00	0.8	0.6	0.0	0.9	14.2	355.4	0.00	1.00
09/17/2026 10:00	0.7	0.6	0.0	0.8	14.2	355.0	0.00	1.00
09/17/2026 11:00	0.8	0.6	0.0	0.9	14.2	354.8	0.00	1.00
09/17/2026 12:00	0.7	0.6	0.0	0.8	14.3	354.6	0.00	1.00
09/17/2026 13:00	0.7	0.6	0.0	0.8	14.3	354.2	0.00	1.00
09/17/2026 14:00	0.8	0.6	0.0	0.9	14.3	353.9	0.00	1.00
09/17/2026 15:00	0.7	0.6	0.0	0.8	14.3	353.9	0.00	1.00
09/17/2026 16:00	0.7	0.6	0.0	0.8	14.3	368.4	0.00	1.00
09/17/2026 17:00	0.7	0.6	0.0	0.8	14.3	353.9	0.00	1.00
09/17/2026 18:00	0.7	0.6	0.0	0.8	14.2	353.8	0.00	1.00
09/17/2026 19:00	0.8	0.6	0.0	0.9	14.2	353.9	0.00	1.00
09/17/2026 20:00	0.8	0.6	0.0	0.9	14.2	354.2	0.00	1.00
09/17/2026 21:00	0.8	0.6	0.0	0.9	14.2	354.7	0.00	1.00
09/17/2026 22:00	0.8	0.6	0.0	0.9	14.2	354.8	0.00	1.00
09/17/2026 23:00	0.8	0.6	0.0	0.9	14.2	355.2	0.00	1.00
Average/Sum#:	0.8	0.6	0.0	0.9	14.2	358.2	0.00 #	24.00 #
Minimum:	0.7	0.6	0.0	0.8	14.2	353.8	0.00	1.00
Maximum:	0.9	0.7	0.0	1.0	14.3	391.8	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/18/2026 00:00	0.8	0.7	0.0	0.9	14.2	355.2	0.00	1.00
09/18/2026 01:00	0.8	0.6	0.0	0.9	14.2	355.4	0.00	1.00
09/18/2026 02:00	0.8	0.6	0.0	0.9	14.2	355.5	0.00	1.00
09/18/2026 03:00	0.9	0.6	0.0	1.0	14.1	356.2	0.00	1.00
09/18/2026 04:00	0.9	0.7	0.0	1.0	14.2	356.2	0.00	1.00
09/18/2026 05:00	0.9	0.7	0.0	1.0	14.2	356.6	0.00	1.00
09/18/2026 06:00	0.9	0.7	0.0	1.0	14.2	391.4	0.00	1.00
09/18/2026 07:00	0.9	0.7	0.0	1.0	14.2	357.8	0.00	1.00
09/18/2026 08:00	0.9	0.7	0.0	1.0	14.2	355.2	0.00	1.00
09/18/2026 09:00	0.8	0.7	0.0	0.9	14.2	354.5	0.00	1.00
09/18/2026 10:00	0.8	0.6	0.0	0.9	14.3	354.1	0.00	1.00
09/18/2026 11:00	0.8	0.6	0.0	0.9	14.3	355.1	0.00	1.00
09/18/2026 12:00	0.8	0.6	0.0	0.9	14.3	354.8	0.00	1.00
09/18/2026 13:00	0.8	0.6	0.0	0.9	14.3	355.5	0.00	1.00
09/18/2026 14:00	0.7	0.6	0.0	0.8	14.3	352.6	0.00	1.00
09/18/2026 15:00	0.7	0.6	0.0	0.8	14.3	352.6	0.00	1.00
09/18/2026 16:00	0.7	0.6	0.0	0.8	14.4	403.9	0.00	1.00
09/18/2026 17:00	0.7	0.6	0.0	0.8	14.5	426.9	0.00	1.00
09/18/2026 18:00	0.7	0.6	0.0	0.8	14.3	354.2	0.00	1.00
09/18/2026 19:00	0.7	0.6	0.0	0.8	14.3	352.5	0.00	1.00
09/18/2026 20:00	0.7	0.6	0.0	0.8	14.3	352.9	0.00	1.00
09/18/2026 21:00	0.8	0.6	0.0	0.9	14.3	352.7	0.00	1.00
09/18/2026 22:00	0.8	0.6	0.0	0.9	14.2	353.0	0.00	1.00
09/18/2026 23:00	0.8	0.6	0.0	0.9	14.2	354.0	0.00	1.00
Average/Sum#:	0.8	0.6	0.0	0.9	14.3	361.2	0.00 #	24.00 #
Minimum:	0.7	0.6	0.0	0.8	14.1	352.5	0.00	1.00
Maximum:	0.9	0.7	0.0	1.0	14.5	426.9	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/19/2026 00:00	0.8	0.6	0.0	0.9	14.2	354.3	0.00	1.00
09/19/2026 01:00	0.8	0.6	0.0	0.9	14.2	354.3	0.00	1.00
09/19/2026 02:00	0.8	0.6	0.0	0.9	14.2	354.6	0.00	1.00
09/19/2026 03:00	0.9	0.6	0.0	1.0	14.2	354.9	0.00	1.00
09/19/2026 04:00	0.9	0.7	0.0	1.0	14.2	354.9	0.00	1.00
09/19/2026 05:00	0.9	0.7	0.0	1.0	14.2	355.2	0.00	1.00
09/19/2026 06:00	0.9	0.7	0.0	1.0	14.2	355.2	0.00	1.00
09/19/2026 07:00	0.8	0.7	0.0	0.9	14.2	354.5	0.00	1.00
09/19/2026 08:00	0.8	0.6	0.0	0.9	14.2	353.8	0.00	1.00
09/19/2026 09:00	0.8	0.6	0.0	0.9	14.2	353.6	0.00	1.00
09/19/2026 10:00	0.8	0.6	0.0	0.9	14.3	353.4	0.00	1.00
09/19/2026 11:00	0.8	0.6	0.0	0.9	14.3	355.3	0.00	1.00
09/19/2026 12:00	0.7	0.6	0.0	0.8	14.3	354.2	0.00	1.00
09/19/2026 13:00	0.8	0.6	0.0	0.9	14.3	353.0	0.00	1.00
09/19/2026 14:00	0.7	0.6	0.0	0.8	14.4	352.1	0.00	1.00
09/19/2026 15:00	0.7	0.6	0.0	0.8	14.4	352.2	0.00	1.00
09/19/2026 16:00	0.7	0.6	0.0	0.8	14.4	364.1	0.00	1.00
09/19/2026 17:00	0.8	0.6	0.0	0.9	14.4	352.0	0.00	1.00
09/19/2026 18:00	0.7	0.6	0.0	0.8	14.3	352.3	0.00	1.00
09/19/2026 19:00	0.7	0.6	0.0	0.8	14.3	352.7	0.00	1.00
09/19/2026 20:00	0.8	0.6	0.0	0.9	14.3	352.3	0.00	1.00
09/19/2026 21:00	0.8	0.6	0.0	0.9	14.3	357.8	0.00	1.00
09/19/2026 22:00	0.8	0.6	0.0	0.9	14.3	371.9	0.00	1.00
09/19/2026 23:00	0.8	0.7	0.0	0.9	14.2	366.4	0.00	1.00
Average/Sum#:	0.8	0.6	0.0	0.9	14.3	355.6	0.00 #	24.00 #
Minimum:	0.7	0.6	0.0	0.8	14.2	352.0	0.00	1.00
Maximum:	0.9	0.7	0.0	1.0	14.4	371.9	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/20/2026 00:00	0.8	0.7	0.0	0.9	14.2	363.3	0.00	1.00
09/20/2026 01:00	0.9	0.7	0.0	1.0	14.2	353.6	0.00	1.00
09/20/2026 02:00	0.8	0.7	0.0	0.9	14.2	353.9	0.00	1.00
09/20/2026 03:00	0.9	0.7	0.0	1.0	14.2	354.0	0.00	1.00
09/20/2026 04:00	0.8	0.6	0.0	0.9	14.2	354.2	0.00	1.00
09/20/2026 05:00	0.8	0.6	0.0	0.9	14.2	354.8	0.00	1.00
09/20/2026 06:00	0.8	0.6	0.0	0.9	14.2	355.6	0.00	1.00
09/20/2026 07:00	0.8	0.6	0.0	0.9	14.2	354.6	0.00	1.00
09/20/2026 08:00	0.8	0.6	0.0	0.9	14.2	354.4	0.00	1.00
09/20/2026 09:00	0.8	0.6	0.0	0.9	14.2	353.8	0.00	1.00
09/20/2026 10:00	0.8	0.6	0.0	0.9	14.3	353.3	0.00	1.00
09/20/2026 11:00	0.8	0.6	0.0	0.9	14.3	353.9	0.00	1.00
09/20/2026 12:00	0.8	0.6	0.0	0.9	14.3	353.9	0.00	1.00
09/20/2026 13:00	0.7	0.6	0.0	0.8	14.4	389.7	0.00	1.00
09/20/2026 14:00	0.7	0.6	0.0	0.8	14.5	427.9	0.00	1.00
09/20/2026 15:00	0.7	0.7	0.0	0.8	14.5	420.4	0.00	1.00
09/20/2026 16:00	0.7	0.7	0.0	0.8	14.4	404.5	0.00	1.00
09/20/2026 17:00	0.7	0.7	0.0	0.8	14.3	354.9	0.00	1.00
09/20/2026 18:00	0.7	0.6	0.0	0.8	14.3	352.6	0.00	1.00
09/20/2026 19:00	0.8	0.6	0.0	0.9	14.2	353.2	0.00	1.00
09/20/2026 20:00	0.8	0.6	0.0	0.9	14.2	353.6	0.00	1.00
09/20/2026 21:00	0.8	0.6	0.0	0.9	14.2	353.3	0.00	1.00
09/20/2026 22:00	0.9	0.6	0.0	1.0	14.2	353.5	0.00	1.00
09/20/2026 23:00	0.8	0.7	0.0	0.9	14.2	359.3	0.00	1.00
Average/Sum#:	0.8	0.6	0.0	0.9	14.3	364.0	0.00 #	24.00 #
Minimum:	0.7	0.6	0.0	0.8	14.2	352.6	0.00	1.00
Maximum:	0.9	0.7	0.0	1.0	14.5	427.9	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/21/2026 00:00	0.8	0.7	0.0	0.9	14.2	353.6	0.00	1.00
09/21/2026 01:00	0.8	0.6	0.0	0.9	14.2	353.8	0.00	1.00
09/21/2026 02:00	0.8	0.6	0.0	0.9	14.2	354.0	0.00	1.00
09/21/2026 03:00	0.9	0.6	0.0	1.0	14.2	354.2	0.00	1.00
09/21/2026 04:00	0.8	0.7	0.0	0.9	14.2	372.8	0.00	1.00
09/21/2026 05:00	0.7	0.7	0.0	0.8	14.3	416.5	0.00	1.00
09/21/2026 06:00	0.8	0.7	0.0	0.9	14.2	406.3	0.00	1.00
09/21/2026 07:00	0.8	0.7	0.0	0.9	14.2	402.0	0.00	1.00
09/21/2026 08:00	0.8	0.7	0.0	0.9	14.2	381.6	0.00	1.00
09/21/2026 09:00	0.8	0.7	0.0	0.9	14.2	354.6	0.00	1.00
09/21/2026 10:00	0.8	0.6	0.0	0.9	14.2	354.3	0.00	1.00
09/21/2026 11:00	0.8	0.6	0.0	0.9	14.3	354.2	0.00	1.00
09/21/2026 12:00	0.8	0.6	0.0	0.9	14.3	354.4	0.00	1.00
09/21/2026 13:00	0.8	0.6	0.0	0.9	14.3	353.9	0.00	1.00
09/21/2026 14:00	0.8	0.6	0.0	0.9	14.3	365.0	0.00	1.00
09/21/2026 15:00	0.7	0.6	0.0	0.8	14.3	352.8	0.00	1.00
09/21/2026 16:00	0.7	0.6	0.0	0.8	14.3	367.2	0.00	1.00
09/21/2026 17:00	0.7	0.6	0.0	0.8	14.3	352.7	0.00	1.00
09/21/2026 18:00	0.8	0.6	0.0	0.9	14.2	353.2	0.00	1.00
09/21/2026 19:00	0.8	0.6	0.0	0.9	14.2	353.9	0.00	1.00
09/21/2026 20:00	0.8	0.6	0.0	0.9	14.2	353.8	0.00	1.00
09/21/2026 21:00	0.8	0.6	0.0	0.9	14.2	354.1	0.00	1.00
09/21/2026 22:00	0.8	0.6	0.0	0.9	14.2	354.2	0.00	1.00
09/21/2026 23:00	0.8	0.6	0.0	0.9	14.2	354.4	0.00	1.00
Average/Sum#:	0.8	0.6	0.0	0.9	14.2	363.6	0.00 #	24.00 #
Minimum:	0.7	0.6	0.0	0.8	14.2	352.7	0.00	1.00
Maximum:	0.9	0.7	0.0	1.0	14.3	416.5	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/22/2026 00:00	0.8	0.6	0.0	0.9	14.2	354.7	0.00	1.00
09/22/2026 01:00	0.8	0.6	0.0	0.9	14.2	354.8	0.00	1.00
09/22/2026 02:00	0.8	0.6	0.0	0.9	14.1	355.2	0.00	1.00
09/22/2026 03:00	0.9	0.6	0.0	1.0	14.1	355.3	0.00	1.00
09/22/2026 04:00	0.8	0.6	0.0	0.9	14.1	355.7	0.00	1.00
09/22/2026 05:00	0.8	0.6	0.0	0.9	14.1	355.9	0.00	1.00
09/22/2026 06:00	0.8	0.6	0.0	0.9	14.1	370.1	0.00	1.00
09/22/2026 07:00	0.8	0.6	0.0	0.9	14.1	355.9	0.00	1.00
09/22/2026 08:00	0.8	0.6	0.0	0.9	14.2	355.3	0.00	1.00
09/22/2026 09:00	0.8	0.6	0.0	0.9	14.2	354.7	0.00	1.00
09/22/2026 10:00	0.8	0.6	0.0	0.9	14.2	354.0	0.00	1.00
09/22/2026 11:00	0.8	0.6	0.0	0.9	14.2	353.9	0.00	1.00
09/22/2026 12:00	0.8	0.6	0.0	0.9	14.3	353.7	0.00	1.00
09/22/2026 13:00	0.8	0.6	0.0	0.9	14.3	353.2	0.00	1.00
09/22/2026 14:00	0.8	0.6	0.0	0.9	14.3	353.1	0.00	1.00
09/22/2026 15:00	0.8	0.6	0.0	0.9	14.3	353.2	0.00	1.00
09/22/2026 16:00	0.8	0.6	0.0	0.9	14.3	361.2	0.00	1.00
09/22/2026 17:00	0.8	0.6	0.0	0.9	14.3	352.2	0.00	1.00
09/22/2026 18:00	0.7	0.6	0.0	0.8	14.3	351.8	0.00	1.00
09/22/2026 19:00	0.7	0.6	0.0	0.8	14.3	352.9	0.00	1.00
09/22/2026 20:00	0.8	0.6	0.0	0.9	14.2	353.4	0.00	1.00
09/22/2026 21:00	1.0	0.7	0.0	1.1	14.2	406.5	0.00	1.00
09/22/2026 22:00	1.3	1.0	0.0	1.5	13.9	489.2	0.00	1.00
09/22/2026 23:00	0.9	1.1	0.0	1.0	14.2	375.2	0.00	1.00
Average/Sum#:	0.8	0.6	0.0	0.9	14.2	363.8	0.00 #	24.00 #
Minimum:	0.7	0.6	0.0	0.8	13.9	351.8	0.00	1.00
Maximum:	1.3	1.1	0.0	1.5	14.3	489.2	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/23/2026 00:00	0.8	0.9	0.0	0.9	14.2	355.3	0.00	1.00
09/23/2026 01:00	0.9	0.7	0.0	1.0	14.2	355.9	0.00	1.00
09/23/2026 02:00	0.8	0.6	0.0	0.9	14.2	355.5	0.00	1.00
09/23/2026 03:00	0.9	0.7	0.0	1.0	14.2	355.8	0.00	1.00
09/23/2026 04:00	0.9	0.7	0.0	1.0	14.2	359.6	0.00	1.00
09/23/2026 05:00	0.9	0.7	0.0	1.0	14.2	392.0	0.00	1.00
09/23/2026 06:00	0.9	0.7	0.0	1.0	14.1	383.1	0.00	1.00
09/23/2026 07:00	0.9	0.7	0.0	1.0	14.2	355.8	0.00	1.00
09/23/2026 08:00	0.9	0.7	0.0	1.0	14.2	354.7	0.00	1.00
09/23/2026 09:00	0.8	0.7	0.0	0.9	14.2	354.3	0.00	1.00
09/23/2026 10:00	0.8	0.7	0.0	0.9	14.3	354.0	0.00	1.00
09/23/2026 11:00	0.8	0.6	0.0	0.9	14.3	353.5	0.00	1.00
09/23/2026 12:00	0.8	0.6	0.0	0.9	14.3	353.1	0.00	1.00
09/23/2026 13:00	0.8	0.6	0.0	0.9	14.4	361.8	0.00	1.00
09/23/2026 14:00	0.8	0.6	0.0	0.9	14.4	356.6	0.00	1.00
09/23/2026 15:00	0.8	0.6	0.0	0.9	14.4	369.5	0.00	1.00
09/23/2026 16:00	0.8	0.7	0.0	0.9	14.4	390.5	0.00	1.00
09/23/2026 17:00	0.8	0.7	0.0	0.9	14.3	356.6	0.00	1.00
09/23/2026 18:00	0.8	0.6	0.0	0.9	14.4	352.7	0.00	1.00
09/23/2026 19:00	0.8	0.6	0.0	0.9	14.5	423.1	0.00	1.00
09/23/2026 20:00	0.9	0.7	0.0	1.0	14.4	385.8	0.00	1.00
09/23/2026 21:00	0.9	0.7	0.0	1.0	14.3	360.0	0.00	1.00
09/23/2026 22:00	0.9	0.7	0.0	1.0	14.3	353.3	0.00	1.00
09/23/2026 23:00	0.9	0.7	0.0	1.0	14.2	354.7	0.00	1.00
Average/Sum#:	0.8	0.7	0.0	0.9	14.3	364.5	0.00 #	24.00 #
Minimum:	0.8	0.6	0.0	0.9	14.1	352.7	0.00	1.00
Maximum:	0.9	0.9	0.0	1.0	14.5	423.1	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/24/2026 00:00	1.1	0.7	0.0	1.2	14.2	354.7	0.00	1.00
09/24/2026 01:00	1.0	0.8	0.0	1.1	14.2	354.5	0.00	1.00
09/24/2026 02:00	0.9	0.8	0.0	1.0	14.2	354.2	0.00	1.00
09/24/2026 03:00	1.0	0.8	0.0	1.1	14.2	354.6	0.00	1.00
09/24/2026 04:00	0.9	0.7	0.0	1.0	14.2	357.3	0.00	1.00
09/24/2026 05:00	1.0	0.8	0.0	1.1	14.3	397.9	0.00	1.00
09/24/2026 06:00	1.0	0.8	0.0	1.1	14.2	390.1	0.00	1.00
09/24/2026 07:00	1.0	0.9	0.0	1.1	14.2	354.7	0.00	1.00
09/24/2026 08:00	0.9	0.8	0.0	1.0	14.3	353.9	0.00	1.00
09/24/2026 09:00	0.9	0.7	0.0	1.0	14.3	353.2	0.00	1.00
09/24/2026 10:00	0.8	0.7	0.0	0.9	14.4	353.2	0.00	1.00
09/24/2026 11:00	0.8	0.7	0.0	0.9	14.4	352.6	0.00	1.00
09/24/2026 12:00	0.8	0.6	0.0	0.9	14.4	352.6	0.00	1.00
09/24/2026 13:00	0.7	0.6	0.0	0.8	14.4	382.2	0.00	1.00
09/24/2026 14:00	0.7	0.6	0.0	0.8	14.3	393.2	0.00	1.00
09/24/2026 15:00	0.7	0.7	0.0	0.8	14.3	398.3	0.00	1.00
09/24/2026 16:00	0.7	0.7	0.0	0.8	14.3	393.5	0.00	1.00
09/24/2026 17:00	0.9	0.8	0.0	1.0	14.2	440.8	0.00	1.00
09/24/2026 18:00	0.8	0.8	0.0	1.0	13.4	521.0	0.00	1.00
09/24/2026 19:00	0.9	0.8	0.0	1.0	14.3	371.8	0.00	1.00
09/24/2026 20:00	0.8	0.7	0.0	0.9	14.3	351.2	0.00	1.00
09/24/2026 21:00	0.8	0.6	0.0	0.9	14.3	351.6	0.00	1.00
09/24/2026 22:00	0.8	0.6	0.0	0.9	14.3	352.1	0.00	1.00
09/24/2026 23:00	0.9	0.6	0.0	1.0	14.3	352.4	0.00	1.00
Average/Sum#:	0.9	0.7	0.0	1.0	14.2	374.7	0.00 #	24.00 #
Minimum:	0.7	0.6	0.0	0.8	13.4	351.2	0.00	1.00
Maximum:	1.1	0.9	0.0	1.2	14.4	521.0	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/25/2026 00:00	0.8	0.7	0.0	0.9	14.3	352.7	0.00	1.00
09/25/2026 01:00	0.9	0.7	0.0	1.0	14.3	352.7	0.00	1.00
09/25/2026 02:00	0.9	0.7	0.0	1.0	14.2	352.7	0.00	1.00
09/25/2026 03:00	1.0	0.7	0.0	1.1	14.2	352.8	0.00	1.00
09/25/2026 04:00	0.9	0.7	0.0	1.0	14.2	352.9	0.00	1.00
09/25/2026 05:00	0.9	0.7	0.0	1.0	14.2	356.3	0.00	1.00
09/25/2026 06:00	0.7	0.7	0.0	0.8	14.2	367.3	0.00	1.00
09/25/2026 07:00	0.6	0.6	0.0	0.7	14.3	369.8	0.00	1.00
09/25/2026 08:00	0.6	0.5	0.0	0.7	14.3	352.4	0.00	1.00
09/25/2026 09:00	0.6	0.5	0.0	0.7	14.3	351.9	0.00	1.00
09/25/2026 10:00	0.5	0.5	0.0	0.6	14.3	352.0	0.00	1.00
09/25/2026 11:00	0.5	0.4	0.0	0.6	14.3	350.6	0.00	1.00
09/25/2026 12:00	0.5	0.4	0.0	0.6	14.3	350.4	0.00	1.00
09/25/2026 13:00	0.5	0.4	0.0	0.6	14.4	350.8	0.00	1.00
09/25/2026 14:00	0.5	0.4	0.0	0.6	14.4	350.2	0.00	1.00
09/25/2026 15:00	0.5	0.4	0.0	0.6	14.4	350.0	0.00	1.00
09/25/2026 16:00	0.5	0.4	0.0	0.6	14.4	357.3	0.00	1.00
09/25/2026 17:00	0.5	0.4	0.0	0.6	14.3	350.5	0.00	1.00
09/25/2026 18:00	0.5	0.4	0.0	0.6	14.3	350.8	0.00	1.00
09/25/2026 19:00	0.5	0.4	0.0	0.6	14.3	351.1	0.00	1.00
09/25/2026 20:00	0.6	0.4	0.0	0.7	14.3	350.9	0.00	1.00
09/25/2026 21:00	0.6	0.5	0.0	0.7	14.3	351.6	0.00	1.00
09/25/2026 22:00	0.6	0.5	0.0	0.7	14.3	352.0	0.00	1.00
09/25/2026 23:00	0.6	0.5	0.0	0.7	14.2	352.0	0.00	1.00
Average/Sum#:	0.6	0.5	0.0	0.7	14.3	353.4	0.00 #	24.00 #
Minimum:	0.5	0.4	0.0	0.6	14.2	350.0	0.00	1.00
Maximum:	1.0	0.7	0.0	1.1	14.4	369.8	0.00	1.00
%SI	0.00	0.00	8.33	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/26/2026 00:00	0.6	0.5	0.0	0.7	14.2	352.6	0.00	1.00
09/26/2026 01:00	0.6	0.5	0.0	0.7	14.2	352.6	0.00	1.00
09/26/2026 02:00	0.7	0.5	0.0	0.8	14.2	353.0	0.00	1.00
09/26/2026 03:00	0.7	0.6	0.0	0.8	14.2	353.1	0.00	1.00
09/26/2026 04:00	0.6	0.6	0.0	0.7	14.2	353.2	0.00	1.00
09/26/2026 05:00	0.6	0.5	0.0	0.7	14.2	353.3	0.00	1.00
09/26/2026 06:00	0.6	0.5	0.0	0.7	14.2	353.4	0.00	1.00
09/26/2026 07:00	0.6	0.5	0.0	0.7	14.2	353.6	0.00	1.00
09/26/2026 08:00	0.6	0.5	0.0	0.7	14.2	353.6	0.00	1.00
09/26/2026 09:00	0.6	0.5	0.0	0.7	14.2	353.4	0.00	1.00
09/26/2026 10:00	0.6	0.5	0.0	0.7	14.3	352.8	0.00	1.00
09/26/2026 11:00	0.6	0.5	0.0	0.7	14.3	352.2	0.00	1.00
09/26/2026 12:00	0.6	0.5	0.0	0.7	14.3	352.5	0.00	1.00
09/26/2026 13:00	0.6	0.5	0.0	0.7	14.3	352.2	0.00	1.00
09/26/2026 14:00	0.5	0.5	0.0	0.6	14.4	352.1	0.00	1.00
09/26/2026 15:00	0.5	0.4	0.0	0.6	14.4	352.0	0.00	1.00
09/26/2026 16:00	0.5	0.4	0.0	0.6	14.4	394.4	0.00	1.00
09/26/2026 17:00	0.5	0.4	0.0	0.6	14.3	428.5	0.00	1.00
09/26/2026 18:00	0.5	0.5	0.0	0.6	14.4	385.7	0.00	1.00
09/26/2026 19:00	0.6	0.5	0.0	0.6	14.5	427.5	0.00	1.00
09/26/2026 20:00	0.6	0.5	0.0	0.6	14.5	425.6	0.00	1.00
09/26/2026 21:00	0.6	0.5	0.0	0.6	14.5	425.6	0.00	1.00
09/26/2026 22:00	0.8	0.6	0.0	0.9	14.3	436.5	0.00	1.00
09/26/2026 23:00	0.2	0.5	0.0	0.3	12.4	599.0	0.00	1.00
Average/Sum#:	0.6	0.5	0.0	0.7	14.2	382.0	0.00 #	24.00 #
Minimum:	0.2	0.4	0.0	0.3	12.4	352.0	0.00	1.00
Maximum:	0.8	0.6	0.0	0.9	14.5	599.0	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/27/2026 00:00	0.9	0.7	0.0	1.1	13.9	491.5	0.00	1.00
09/27/2026 01:00	0.9	0.8	0.0	1.1	14.1	433.6	0.00	1.00
09/27/2026 02:00	0.6	0.8	0.0	0.7	14.3	400.4	0.00	1.00
09/27/2026 03:00	0.7	0.7	0.0	0.8	14.2	377.1	0.00	1.00
09/27/2026 04:00	0.7	0.6	0.0	0.8	14.2	359.0	0.00	1.00
09/27/2026 05:00	0.6	0.6	0.0	0.7	14.3	385.5	0.00	1.00
09/27/2026 06:00	0.5	0.5	0.0	0.6	14.3	421.3	0.00	1.00
09/27/2026 07:00	0.5	0.5	0.0	0.6	14.3	421.3	0.00	1.00
09/27/2026 08:00	0.6	0.5	0.0	0.7	14.2	373.9	0.00	1.00
09/27/2026 09:00	0.6	0.5	0.0	0.7	14.2	353.9	0.00	1.00
09/27/2026 10:00	0.6	0.5	0.0	0.7	14.2	353.8	0.00	1.00
09/27/2026 11:00	0.6	0.5	0.0	0.7	14.2	353.6	0.00	1.00
09/27/2026 12:00	0.6	0.5	0.0	0.7	14.3	353.1	0.00	1.00
09/27/2026 13:00	0.6	0.5	0.0	0.7	14.3	352.7	0.00	1.00
09/27/2026 14:00	0.6	0.5	0.0	0.6	14.3	356.7	0.00	1.00
09/27/2026 15:00	0.5	0.5	0.0	0.6	14.4	372.1	0.00	1.00
09/27/2026 16:00	0.7	0.5	0.0	0.8	14.3	408.6	0.00	1.00
09/27/2026 17:00	0.2	0.5	0.0	0.3	12.7	583.6	0.00	1.00
09/27/2026 18:00	0.2	0.4	0.0	0.3	12.8	577.1	0.00	1.00
09/27/2026 19:00	0.3	0.3	0.0	0.4	12.8	575.5	0.00	1.00
09/27/2026 20:00	0.4	0.4	0.0	0.5	13.0	562.5	0.00	1.00
09/27/2026 21:00	1.1	0.7	0.0	1.3	13.8	502.7	0.00	1.00
09/27/2026 22:00	1.1	1.0	0.0	1.3	14.1	465.9	0.00	1.00
09/27/2026 23:00	0.6	1.0	0.0	0.7	14.2	397.7	0.00	1.00
Average/Sum#:	0.6	0.6	0.0	0.7	14.0	426.4	0.00 #	24.00 #
Minimum:	0.2	0.3	0.0	0.3	12.7	352.7	0.00	1.00
Maximum:	1.1	1.0	0.0	1.3	14.4	583.6	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/28/2026 00:00	0.6	0.7	0.0	0.7	14.2	391.5	0.00	1.00
09/28/2026 01:00	0.6	0.5	0.0	0.7	14.2	355.1	0.00	1.00
09/28/2026 02:00	0.6	0.5	0.0	0.7	14.2	376.2	0.00	1.00
09/28/2026 03:00	1.2	0.7	0.0	1.3	14.2	407.9	0.00	1.00
09/28/2026 04:00	1.9	1.2	0.0	2.2	14.1	488.9	0.00	1.00
09/28/2026 05:00	1.6	1.7	0.0	1.9	13.9	503.6	0.00	1.00
09/28/2026 06:00	0.9	1.6	0.0	1.0	13.7	496.6	0.00	1.00
09/28/2026 07:00	0.7	1.1	0.0	0.8	14.2	384.9	0.00	1.00
09/28/2026 08:00	0.6	0.7	0.0	0.7	14.2	354.2	0.00	1.00
09/28/2026 09:00	0.6	0.5	0.0	0.7	14.2	353.5	0.00	1.00
09/28/2026 10:00	0.6	0.5	0.0	0.7	14.3	352.7	0.00	1.00
09/28/2026 11:00	0.6	0.5	0.0	0.7	14.3	352.8	0.00	1.00
09/28/2026 12:00	0.6	0.5	0.0	0.7	14.3	352.1	0.00	1.00
09/28/2026 13:00	0.6	0.5	0.0	0.7	14.3	351.7	0.00	1.00
09/28/2026 14:00	0.6	0.5	0.0	0.7	14.4	351.4	0.00	1.00
09/28/2026 15:00	0.6	0.5	0.0	0.7	14.4	351.1	0.00	1.00
09/28/2026 16:00	0.6	0.5	0.0	0.7	14.4	352.3	0.00	1.00
09/28/2026 17:00	0.6	0.5	0.0	0.7	14.4	350.8	0.00	1.00
09/28/2026 18:00	0.6	0.5	0.0	0.7	14.4	350.7	0.00	1.00
09/28/2026 19:00	0.6	0.5	0.0	0.7	14.3	351.3	0.00	1.00
09/28/2026 20:00	0.6	0.5	0.0	0.7	14.3	351.6	0.00	1.00
09/28/2026 21:00	0.7	0.5	0.0	0.8	14.3	352.4	0.00	1.00
09/28/2026 22:00	0.7	0.5	0.0	0.8	14.2	352.7	0.00	1.00
09/28/2026 23:00	0.7	0.5	0.0	0.8	14.2	353.1	0.00	1.00
Average/Sum#:	0.8	0.7	0.0	0.9	14.2	376.6	0.00 #	24.00 #
Minimum:	0.6	0.5	0.0	0.7	13.7	350.7	0.00	1.00
Maximum:	1.9	1.7	0.0	2.2	14.4	503.6	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/29/2026 00:00	0.7	0.6	0.0	0.8	14.2	353.3	0.00	1.00
09/29/2026 01:00	0.7	0.6	0.0	0.8	14.2	353.6	0.00	1.00
09/29/2026 02:00	0.7	0.6	0.0	0.8	14.2	353.7	0.00	1.00
09/29/2026 03:00	0.8	0.6	0.0	0.9	14.2	354.1	0.00	1.00
09/29/2026 04:00	0.8	0.6	0.0	0.9	14.2	354.5	0.00	1.00
09/29/2026 05:00	0.7	0.6	0.0	0.8	14.2	354.4	0.00	1.00
09/29/2026 06:00	0.7	0.6	0.0	0.8	14.2	354.3	0.00	1.00
09/29/2026 07:00	0.7	0.6	0.0	0.8	14.2	353.6	0.00	1.00
09/29/2026 08:00	0.7	0.6	0.0	0.8	14.2	352.7	0.00	1.00
09/29/2026 09:00	0.6	0.5	0.0	0.7	14.3	351.6	0.00	1.00
09/29/2026 10:00	0.6	0.5	0.0	0.7	14.4	351.2	0.00	1.00
09/29/2026 11:00	0.5	0.5	0.0	0.6	14.4	351.7	0.00	1.00
09/29/2026 12:00	0.5	0.5	0.0	0.6	14.4	350.5	0.00	1.00
09/29/2026 13:00	0.6	0.4	0.0	0.6	14.5	350.0	0.00	1.00
09/29/2026 14:00	0.6	0.4	0.0	0.6	14.5	349.9	0.00	1.00
09/29/2026 15:00	0.6	0.4	0.0	0.6	14.5	350.1	0.00	1.00
09/29/2026 16:00	0.5	0.4	0.0	0.6	14.4	362.4	0.00	1.00
09/29/2026 17:00	0.5	0.4	0.0	0.6	14.4	350.9	0.00	1.00
09/29/2026 18:00	0.5	0.4	0.0	0.6	14.4	350.8	0.00	1.00
09/29/2026 19:00	0.5	0.4	0.0	0.6	14.4	350.5	0.00	1.00
09/29/2026 20:00	0.5	0.4	0.0	0.6	14.3	351.0	0.00	1.00
09/29/2026 21:00	0.6	0.5	0.0	0.7	14.3	351.0	0.00	1.00
09/29/2026 22:00	0.6	0.5	0.0	0.7	14.3	351.7	0.00	1.00
09/29/2026 23:00	0.6	0.5	0.0	0.7	14.4	427.1	0.00	1.00
Average/Sum#:	0.6	0.5	0.0	0.7	14.3	355.6	0.00 #	24.00 #
Minimum:	0.5	0.4	0.0	0.6	14.2	349.9	0.00	1.00
Maximum:	0.8	0.6	0.0	0.9	14.5	427.1	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:45 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT1 CO, Ppmvdc 1 Hour(s)	Unit CT1 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT1 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT1 CO, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/30/2026 00:00	0.6	0.5	0.0	0.7	14.3	351.6	0.00	1.00
09/30/2026 01:00	0.7	0.6	0.0	0.8	14.3	354.3	0.00	1.00
09/30/2026 02:00	0.6	0.5	0.0	0.7	14.3	373.9	0.00	1.00
09/30/2026 03:00	1.5	0.9	0.0	1.7	14.2	463.3	0.00	1.00
09/30/2026 04:00	1.0	1.1	0.0	1.2	14.0	487.8	0.00	1.00
09/30/2026 05:00	0.5	1.1	0.0	0.7	13.1	558.9	0.00	1.00
09/30/2026 06:00	0.6	0.8	0.0	0.7	13.7	450.5	0.00	1.00
09/30/2026 07:00	0.7	0.6	0.0	0.8	14.2	353.0	0.00	1.00
09/30/2026 08:00	0.6	0.5	0.0	0.7	14.3	355.3	0.00	1.00
09/30/2026 09:00	0.6	0.5	0.0	0.7	14.3	350.5	0.00	1.00
09/30/2026 10:00	0.6	0.5	0.0	0.7	14.4	364.2	0.00	1.00
09/30/2026 11:00	0.6	0.5	0.0	0.6	14.5	389.9	0.00	1.00
09/30/2026 12:00	0.7	0.6	0.0	0.8	14.3	420.0	0.00	1.00
09/30/2026 13:00	0.8	0.7	0.0	1.0	13.7	494.9	0.00	1.00
09/30/2026 14:00	0.3	0.6	0.0	0.4	12.5	585.6	0.00	1.00
09/30/2026 15:00	0.1	0.5	0.0	0.2	12.3	592.2	0.00	1.00
09/30/2026 16:00	0.2	0.2	0.0	0.2	12.4	585.1	0.00	1.00
09/30/2026 17:00	0.2	0.2	0.0	0.3	12.7	568.3	0.00	1.00
09/30/2026 18:00	0.5	0.3	0.0	0.6	13.4	506.9	0.00	1.00
09/30/2026 19:00	0.7	0.5	0.0	0.8	13.7	472.9	0.00	1.00
09/30/2026 20:00	0.7	0.6	0.0	0.8	14.3	432.6	0.00	1.00
09/30/2026 21:00	0.8	0.8	0.0	1.0	13.6	496.9	0.00	1.00
09/30/2026 22:00	0.7	0.7	0.0	0.9	14.3	373.8	0.00	1.00
09/30/2026 23:00	0.6	0.7	0.0	0.7	14.3	379.8	0.00	1.00
Average/Sum#:	0.6	0.6	0.0	0.7	13.8	448.4	0.00 #	24.00 #
Minimum:	0.1	0.2	0.0	0.2	12.3	350.5	0.00	1.00
Maximum:	1.5	1.1	0.0	1.7	14.5	592.2	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/01/2026 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/01/2026 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/01/2026 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/01/2026 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/01/2026 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/01/2026 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/01/2026 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/01/2026 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/01/2026 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/01/2026 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/01/2026 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/01/2026 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/01/2026 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/01/2026 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/01/2026 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/01/2026 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/01/2026 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/01/2026 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/01/2026 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/01/2026 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/01/2026 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/01/2026 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/01/2026 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/01/2026 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/02/2026 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/02/2026 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/02/2026 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/02/2026 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/02/2026 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/02/2026 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/02/2026 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/02/2026 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/02/2026 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/02/2026 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/02/2026 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/02/2026 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/02/2026 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/02/2026 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/02/2026 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/02/2026 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/02/2026 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/02/2026 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/02/2026 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/02/2026 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/02/2026 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/02/2026 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/02/2026 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/02/2026 23:00	1,990.9	0.0	1,990.9	104,600.0	208.2	0.00	0.0	0.0
Average/Sum#:	1,990.9	0.0	1,990.9	104,600.0	208.2	0.00	0.0	0.0
Minimum:	1,990.9	0.0	1,990.9	104,600.0	208.2	0.00	0.0	0.0
Maximum:	1,990.9	0.0	1,990.9	104,600.0	208.2	0.00	0.0	0.0
%SI	95.83	95.83	95.83	0.00	95.83	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/03/2026 00:00	3,547.7	0.0	3,547.7	104,600.0	371.1	0.43	0.2	0.7
07/03/2026 01:00	3,396.4	0.0	3,396.4	104,600.0	355.3	0.43	0.2	0.7
07/03/2026 02:00	3,379.5	0.0	3,379.5	104,600.0	353.5	0.42	0.2	0.7
07/03/2026 03:00	3,377.7	0.0	3,377.7	104,600.0	353.3	0.42	0.2	0.7
07/03/2026 04:00	2,803.1	0.0	2,803.1	104,600.0	293.2	0.42	0.2	0.7
07/03/2026 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/03/2026 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/03/2026 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/03/2026 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/03/2026 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/03/2026 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/03/2026 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/03/2026 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/03/2026 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/03/2026 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/03/2026 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/03/2026 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/03/2026 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/03/2026 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/03/2026 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/03/2026 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/03/2026 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/03/2026 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/03/2026 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	3,300.9	0.0	3,300.9	104,600.0	345.3	0.42	0.2	0.7
Minimum:	2,803.1	0.0	2,803.1	104,600.0	293.2	0.42	0.2	0.7
Maximum:	3,547.7	0.0	3,547.7	104,600.0	371.1	0.43	0.2	0.7
%SI	79.17	79.17	79.17	0.00	79.17	79.17	79.17	79.17

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/04/2026 00:00	1,963.3	0.0	1,963.3	104,600.0	205.4	0.00	0.0	0.0
07/04/2026 01:00	3,526.4	0.0	3,526.4	104,600.0	368.9	0.43	0.2	0.7
07/04/2026 02:00	3,405.0	0.0	3,405.0	104,600.0	356.2	0.43	0.2	0.7
07/04/2026 03:00	3,373.6	0.0	3,373.6	104,600.0	352.9	0.42	0.2	0.7
07/04/2026 04:00	3,378.3	0.0	3,378.3	104,600.0	353.4	0.42	0.2	0.7
07/04/2026 05:00	2,746.7	0.0	2,746.7	104,600.0	287.3	0.42	0.2	0.7
07/04/2026 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/04/2026 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/04/2026 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/04/2026 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/04/2026 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/04/2026 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/04/2026 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/04/2026 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/04/2026 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/04/2026 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/04/2026 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/04/2026 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/04/2026 18:00	2,620.0	0.0	2,620.0	104,600.0	274.1	0.00	0.0	0.0
07/04/2026 19:00	4,002.5	458.3	4,337.1	104,600.0	453.7	0.59	0.3	1.0
07/04/2026 20:00	3,911.9	277.5	4,056.2	104,600.0	424.3	0.52	0.3	0.9
07/04/2026 21:00	3,372.2	0.0	3,372.2	104,600.0	352.7	0.42	0.2	0.7
07/04/2026 22:00	3,516.8	0.0	3,516.8	104,600.0	367.9	0.44	0.2	0.7
07/04/2026 23:00	3,918.9	0.0	3,918.9	104,600.0	409.9	0.49	0.2	0.8
Average/Sum#:	3,311.3	61.3	3,351.2	104,600.0	350.6	0.46	0.2	0.8
Minimum:	1,963.3	0.0	1,963.3	104,600.0	205.4	0.42	0.2	0.7
Maximum:	4,002.5	458.3	4,337.1	104,600.0	453.7	0.59	0.3	1.0
%SI	50.00	50.00	50.00	0.00	50.00	58.33	58.33	58.33

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/05/2026 00:00	3,247.3	0.0	3,247.3	104,600.0	339.7	0.44	0.2	0.7
07/05/2026 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/05/2026 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/05/2026 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/05/2026 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/05/2026 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/05/2026 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/05/2026 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/05/2026 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/05/2026 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/05/2026 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/05/2026 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/05/2026 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/05/2026 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/05/2026 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/05/2026 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/05/2026 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/05/2026 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/05/2026 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/05/2026 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/05/2026 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/05/2026 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/05/2026 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/05/2026 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	3,247.3	0.0	3,247.3	104,600.0	339.7	0.44	0.2	0.7
Minimum:	3,247.3	0.0	3,247.3	104,600.0	339.7	0.44	0.2	0.7
Maximum:	3,247.3	0.0	3,247.3	104,600.0	339.7	0.44	0.2	0.7
%SI	95.83	95.83	95.83	0.00	95.83	95.83	95.83	95.83

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/06/2026 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/06/2026 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/06/2026 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/06/2026 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/06/2026 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/06/2026 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/06/2026 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/06/2026 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/06/2026 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/06/2026 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/06/2026 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/06/2026 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/06/2026 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/06/2026 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/06/2026 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/06/2026 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/06/2026 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/06/2026 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/06/2026 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/06/2026 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/06/2026 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/06/2026 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/06/2026 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/06/2026 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/07/2026 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/07/2026 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/07/2026 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/07/2026 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/07/2026 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/07/2026 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/07/2026 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/07/2026 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/07/2026 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/07/2026 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/07/2026 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/07/2026 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/07/2026 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/07/2026 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/07/2026 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/07/2026 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/07/2026 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/07/2026 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/07/2026 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/07/2026 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/07/2026 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/07/2026 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/07/2026 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/07/2026 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/08/2026 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/08/2026 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/08/2026 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/08/2026 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/08/2026 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/08/2026 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/08/2026 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/08/2026 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/08/2026 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/08/2026 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/08/2026 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/08/2026 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/08/2026 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/08/2026 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/08/2026 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/08/2026 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/08/2026 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/08/2026 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/08/2026 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/08/2026 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/08/2026 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/08/2026 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/08/2026 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/08/2026 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/09/2026 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/09/2026 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/09/2026 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/09/2026 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/09/2026 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/09/2026 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/09/2026 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/09/2026 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/09/2026 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/09/2026 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/09/2026 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/09/2026 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/09/2026 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/09/2026 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/09/2026 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/09/2026 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/09/2026 16:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/09/2026 17:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/09/2026 18:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/09/2026 19:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/09/2026 20:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/09/2026 21:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/09/2026 22:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/09/2026 23:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Minimum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
Maximum:	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
%SI	100.00	100.00	100.00	0.00	100.00	100.00	100.00	100.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/10/2026 00:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/10/2026 01:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/10/2026 02:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/10/2026 03:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/10/2026 04:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/10/2026 05:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/10/2026 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/10/2026 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/10/2026 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/10/2026 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/10/2026 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/10/2026 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/10/2026 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/10/2026 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/10/2026 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/10/2026 15:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/10/2026 16:00	2,926.1	0.0	2,926.1	104,600.0	306.1	0.00	0.0	0.0
07/10/2026 17:00	4,238.9	532.5	4,622.3	104,600.0	483.5	0.61	0.3	1.0
07/10/2026 18:00	4,087.1	986.0	5,073.1	104,600.0	530.6	0.64	0.3	1.1
07/10/2026 19:00	4,105.9	872.6	4,978.5	104,600.0	520.8	0.63	0.3	1.0
07/10/2026 20:00	4,236.6	530.1	4,766.7	104,600.0	498.6	0.60	0.3	1.0
07/10/2026 21:00	4,282.1	449.7	4,731.8	104,600.0	494.9	0.59	0.3	1.0
07/10/2026 22:00	4,317.2	405.9	4,723.1	104,600.0	494.0	0.59	0.3	1.0
07/10/2026 23:00	4,347.8	358.4	4,706.2	104,600.0	492.3	0.59	0.3	1.0
Average/Sum#:	4,067.7	516.9	4,566.0	104,600.0	477.6	0.61	0.3	1.0
Minimum:	2,926.1	0.0	2,926.1	104,600.0	306.1	0.59	0.3	1.0
Maximum:	4,347.8	986.0	5,073.1	104,600.0	530.6	0.64	0.3	1.1
%SI	66.67	66.67	66.67	0.00	66.67	70.83	70.83	70.83

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/11/2026 00:00	4,366.7	320.2	4,686.9	104,600.0	490.2	0.59	0.3	1.0
07/11/2026 01:00	4,383.3	285.0	4,668.3	104,600.0	488.3	0.59	0.3	1.0
07/11/2026 02:00	4,397.9	248.1	4,646.0	104,600.0	486.0	0.58	0.3	1.0
07/11/2026 03:00	4,415.3	223.8	4,639.1	104,600.0	485.2	0.58	0.3	1.0
07/11/2026 04:00	4,198.3	129.3	4,275.9	104,600.0	447.3	0.54	0.3	0.9
07/11/2026 05:00	3,020.3	0.0	3,020.3	104,600.0	315.9	0.43	0.2	0.7
07/11/2026 06:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/11/2026 07:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/11/2026 08:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/11/2026 09:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/11/2026 10:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/11/2026 11:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/11/2026 12:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/11/2026 13:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/11/2026 14:00	0.0	0.0	0.0	104,600.0	0.0	0.00	0.0	0.0
07/11/2026 15:00	588.2	0.0	588.2	104,600.0	61.5	0.00	0.0	0.0
07/11/2026 16:00	3,016.5	0.0	3,016.5	104,600.0	315.5	0.46	0.2	0.8
07/11/2026 17:00	4,245.2	718.8	4,748.4	104,600.0	496.7	0.62	0.3	1.0
07/11/2026 18:00	4,291.4	529.0	4,820.4	104,600.0	504.2	0.61	0.3	1.0
07/11/2026 19:00	4,271.3	493.2	4,764.5	104,600.0	498.4	0.60	0.3	1.0
07/11/2026 20:00	4,175.6	654.8	4,830.4	104,600.0	505.3	0.61	0.3	1.0
07/11/2026 21:00	4,208.5	824.8	5,033.3	104,600.0	526.5	0.63	0.3	1.1
07/11/2026 22:00	4,237.4	572.5	4,809.9	104,600.0	503.1	0.60	0.3	1.0
07/11/2026 23:00	4,244.5	1,136.9	5,381.4	104,600.0	562.9	0.68	0.3	1.1
Average/Sum#:	3,870.7	409.1	4,262.0	104,600.0	445.8	0.58	0.3	1.0
Minimum:	588.2	0.0	588.2	104,600.0	61.5	0.43	0.2	0.7
Maximum:	4,415.3	1,136.9	5,381.4	104,600.0	562.9	0.68	0.3	1.1
%SI	37.50	37.50	37.50	0.00	37.50	41.67	41.67	41.67

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/12/2026 00:00	4,247.4	505.4	4,752.8	104,600.0	497.1	0.60	0.3	1.0
07/12/2026 01:00	4,259.8	471.7	4,731.5	104,600.0	494.9	0.59	0.3	1.0
07/12/2026 02:00	4,280.7	448.7	4,729.4	104,600.0	494.7	0.59	0.3	1.0
07/12/2026 03:00	4,286.8	446.8	4,733.6	104,600.0	495.1	0.59	0.3	1.0
07/12/2026 04:00	4,307.9	420.8	4,728.7	104,600.0	494.6	0.59	0.3	1.0
07/12/2026 05:00	4,297.6	423.5	4,721.1	104,600.0	493.8	0.59	0.3	1.0
07/12/2026 06:00	4,340.0	438.8	4,778.8	104,600.0	499.9	0.60	0.3	1.0
07/12/2026 07:00	4,291.8	1,047.4	5,339.2	104,600.0	558.5	0.67	0.3	1.1
07/12/2026 08:00	4,281.1	1,301.2	5,582.3	104,600.0	583.9	0.70	0.4	1.2
07/12/2026 09:00	4,268.7	648.3	4,917.0	104,600.0	514.3	0.62	0.3	1.0
07/12/2026 10:00	4,270.1	490.7	4,760.8	104,600.0	498.0	0.60	0.3	1.0
07/12/2026 11:00	4,206.8	611.8	4,818.6	104,600.0	504.0	0.61	0.3	1.0
07/12/2026 12:00	4,106.7	758.4	4,865.1	104,600.0	508.9	0.61	0.3	1.0
07/12/2026 13:00	4,095.0	1,240.1	5,335.1	104,600.0	558.1	0.67	0.3	1.1
07/12/2026 14:00	4,273.1	1,354.7	5,627.8	104,600.0	588.7	0.71	0.4	1.2
07/12/2026 15:00	4,260.2	1,674.3	5,934.5	104,600.0	620.7	0.74	0.4	1.2
07/12/2026 16:00	4,257.7	1,666.6	5,924.3	104,600.0	619.7	0.74	0.4	1.2
07/12/2026 17:00	4,251.7	997.1	5,248.8	104,600.0	549.0	0.66	0.3	1.1
07/12/2026 18:00	4,271.1	645.0	4,916.1	104,600.0	514.2	0.62	0.3	1.0
07/12/2026 19:00	4,289.3	1,550.3	5,839.6	104,600.0	610.8	0.73	0.4	1.2
07/12/2026 20:00	4,308.1	1,686.3	5,994.4	104,600.0	627.0	0.75	0.4	1.3
07/12/2026 21:00	4,310.1	1,658.6	5,968.7	104,600.0	624.3	0.75	0.4	1.2
07/12/2026 22:00	4,307.8	1,037.1	5,344.9	104,600.0	559.1	0.67	0.3	1.1
07/12/2026 23:00	3,580.6	0.0	3,580.6	104,600.0	374.5	0.45	0.2	0.7
Average/Sum#:	4,235.4	896.8	5,132.2	104,600.0	536.8	0.64	0.3	1.1
Minimum:	3,580.6	0.0	3,580.6	104,600.0	374.5	0.45	0.2	0.7
Maximum:	4,340.0	1,686.3	5,994.4	104,600.0	627.0	0.75	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/13/2026 00:00	3,693.8	0.0	3,693.8	104,600.0	386.4	0.46	0.2	0.8
07/13/2026 01:00	4,113.7	0.0	4,113.7	104,600.0	430.3	0.52	0.3	0.9
07/13/2026 02:00	4,115.7	0.0	4,115.7	104,600.0	430.5	0.52	0.3	0.9
07/13/2026 03:00	4,042.3	0.0	4,042.3	104,600.0	422.8	0.51	0.3	0.8
07/13/2026 04:00	4,102.2	0.0	4,102.2	104,600.0	429.1	0.52	0.3	0.9
07/13/2026 05:00	3,843.5	0.0	3,843.5	104,600.0	402.0	0.48	0.2	0.8
07/13/2026 06:00	4,102.5	0.0	4,102.5	104,600.0	429.1	0.52	0.3	0.9
07/13/2026 07:00	4,061.8	0.0	4,061.8	104,600.0	424.9	0.51	0.3	0.8
07/13/2026 08:00	4,196.2	1,144.3	5,306.2	104,600.0	555.0	0.67	0.3	1.1
07/13/2026 09:00	4,274.2	1,816.3	6,090.5	104,600.0	637.1	0.77	0.4	1.3
07/13/2026 10:00	4,303.8	1,748.1	6,051.9	104,600.0	633.0	0.76	0.4	1.3
07/13/2026 11:00	4,296.9	1,744.1	6,041.0	104,600.0	631.9	0.76	0.4	1.3
07/13/2026 12:00	4,284.7	1,747.2	6,031.9	104,600.0	630.9	0.76	0.4	1.3
07/13/2026 13:00	4,271.3	1,788.8	6,060.1	104,600.0	633.9	0.76	0.4	1.3
07/13/2026 14:00	4,270.7	1,774.0	6,044.7	104,600.0	632.3	0.76	0.4	1.3
07/13/2026 15:00	4,261.3	1,787.9	6,049.2	104,600.0	632.7	0.76	0.4	1.3
07/13/2026 16:00	4,253.0	1,789.4	6,042.4	104,600.0	632.0	0.76	0.4	1.3
07/13/2026 17:00	4,236.0	1,743.5	5,979.5	104,600.0	625.5	0.75	0.4	1.3
07/13/2026 18:00	4,235.2	1,734.1	5,969.3	104,600.0	624.4	0.75	0.4	1.2
07/13/2026 19:00	4,252.7	1,757.9	6,010.6	104,600.0	628.7	0.75	0.4	1.3
07/13/2026 20:00	4,303.1	1,675.8	5,978.9	104,600.0	625.4	0.75	0.4	1.3
07/13/2026 21:00	4,321.5	1,507.9	5,829.4	104,600.0	609.8	0.73	0.4	1.2
07/13/2026 22:00	4,338.7	751.5	5,090.2	104,600.0	532.4	0.64	0.3	1.1
07/13/2026 23:00	4,332.0	508.1	4,840.1	104,600.0	506.3	0.61	0.3	1.0
Average/Sum#:	4,187.8	1,042.5	5,228.8	104,600.0	546.9	0.66	0.3	1.1
Minimum:	3,693.8	0.0	3,693.8	104,600.0	386.4	0.46	0.2	0.8
Maximum:	4,338.7	1,816.3	6,090.5	104,600.0	637.1	0.77	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/14/2026 00:00	4,346.5	777.0	5,123.5	104,600.0	535.9	0.64	0.3	1.1
07/14/2026 01:00	4,297.4	464.7	4,762.1	104,600.0	498.1	0.60	0.3	1.0
07/14/2026 02:00	4,228.0	552.5	4,780.5	104,600.0	500.0	0.60	0.3	1.0
07/14/2026 03:00	4,252.5	501.0	4,753.5	104,600.0	497.2	0.60	0.3	1.0
07/14/2026 04:00	4,256.3	491.1	4,747.4	104,600.0	496.6	0.60	0.3	1.0
07/14/2026 05:00	4,273.7	765.1	5,038.8	104,600.0	527.1	0.63	0.3	1.1
07/14/2026 06:00	4,266.4	451.8	4,718.2	104,600.0	493.5	0.59	0.3	1.0
07/14/2026 07:00	4,223.5	542.8	4,766.3	104,600.0	498.6	0.60	0.3	1.0
07/14/2026 08:00	4,144.7	668.1	4,812.8	104,600.0	503.4	0.60	0.3	1.0
07/14/2026 09:00	4,010.4	878.3	4,888.7	104,600.0	511.4	0.61	0.3	1.0
07/14/2026 10:00	3,929.2	1,036.4	4,965.6	104,600.0	519.4	0.62	0.3	1.0
07/14/2026 11:00	3,846.8	1,217.5	5,064.3	104,600.0	529.7	0.64	0.3	1.1
07/14/2026 12:00	4,200.8	875.1	5,075.9	104,600.0	530.9	0.64	0.3	1.1
07/14/2026 13:00	4,223.0	1,146.0	5,369.0	104,600.0	561.6	0.67	0.3	1.1
07/14/2026 14:00	4,216.1	1,532.1	5,748.2	104,600.0	601.3	0.72	0.4	1.2
07/14/2026 15:00	4,210.1	1,694.8	5,904.9	104,600.0	617.7	0.74	0.4	1.2
07/14/2026 16:00	4,194.7	1,664.2	5,858.9	104,600.0	612.8	0.73	0.4	1.2
07/14/2026 17:00	4,194.9	1,759.4	5,954.3	104,600.0	622.8	0.75	0.4	1.2
07/14/2026 18:00	4,192.0	1,726.0	5,918.0	104,600.0	619.0	0.74	0.4	1.2
07/14/2026 19:00	4,192.4	1,554.3	5,746.7	104,600.0	601.1	0.72	0.4	1.2
07/14/2026 20:00	4,248.0	1,256.7	5,504.7	104,600.0	575.8	0.69	0.3	1.2
07/14/2026 21:00	4,266.3	1,340.3	5,606.6	104,600.0	586.5	0.70	0.4	1.2
07/14/2026 22:00	4,280.4	743.7	5,024.1	104,600.0	525.5	0.63	0.3	1.1
07/14/2026 23:00	4,295.6	395.5	4,691.1	104,600.0	490.7	0.59	0.3	1.0
Average/Sum#:	4,199.6	1,001.4	5,201.0	104,600.0	544.0	0.65	0.3	1.1
Minimum:	3,846.8	395.5	4,691.1	104,600.0	490.7	0.59	0.3	1.0
Maximum:	4,346.5	1,759.4	5,954.3	104,600.0	622.8	0.75	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/15/2026 00:00	4,201.8	526.8	4,728.6	104,600.0	494.6	0.60	0.3	1.0
07/15/2026 01:00	4,141.5	609.0	4,750.5	104,600.0	496.9	0.60	0.3	1.0
07/15/2026 02:00	4,155.2	566.2	4,721.4	104,600.0	493.9	0.59	0.3	1.0
07/15/2026 03:00	4,178.2	530.7	4,708.9	104,600.0	492.6	0.59	0.3	1.0
07/15/2026 04:00	4,203.1	504.5	4,707.6	104,600.0	492.4	0.59	0.3	1.0
07/15/2026 05:00	4,228.7	483.5	4,712.2	104,600.0	492.9	0.59	0.3	1.0
07/15/2026 06:00	4,230.1	520.1	4,750.2	104,600.0	496.9	0.60	0.3	1.0
07/15/2026 07:00	4,179.9	623.7	4,803.6	104,600.0	502.5	0.60	0.3	1.0
07/15/2026 08:00	4,079.1	775.0	4,854.1	104,600.0	507.7	0.61	0.3	1.0
07/15/2026 09:00	3,977.0	991.4	4,968.4	104,600.0	519.7	0.62	0.3	1.0
07/15/2026 10:00	4,140.5	1,754.7	5,895.2	104,600.0	616.6	0.74	0.4	1.2
07/15/2026 11:00	4,222.0	1,731.0	5,953.0	104,600.0	622.7	0.75	0.4	1.2
07/15/2026 12:00	4,210.7	1,249.7	5,460.4	104,600.0	571.2	0.69	0.3	1.1
07/15/2026 13:00	4,200.7	1,471.4	5,672.1	104,600.0	593.3	0.71	0.4	1.2
07/15/2026 14:00	4,183.0	1,866.5	6,049.5	104,600.0	632.8	0.76	0.4	1.3
07/15/2026 15:00	4,159.8	1,706.6	5,866.4	104,600.0	613.6	0.74	0.4	1.2
07/15/2026 16:00	4,175.2	1,889.8	6,065.0	104,600.0	634.4	0.76	0.4	1.3
07/15/2026 17:00	4,183.9	1,798.2	5,982.1	104,600.0	625.7	0.75	0.4	1.3
07/15/2026 18:00	4,214.4	1,800.3	6,014.7	104,600.0	629.1	0.75	0.4	1.3
07/15/2026 19:00	4,259.8	1,601.2	5,861.0	104,600.0	613.1	0.74	0.4	1.2
07/15/2026 20:00	4,276.0	1,390.5	5,666.5	104,600.0	592.7	0.71	0.4	1.2
07/15/2026 21:00	4,299.4	1,155.7	5,455.1	104,600.0	570.6	0.69	0.3	1.1
07/15/2026 22:00	4,180.3	782.3	4,962.6	104,600.0	519.1	0.62	0.3	1.0
07/15/2026 23:00	4,218.4	633.3	4,851.7	104,600.0	507.5	0.61	0.3	1.0
Average/Sum#:	4,187.4	1,123.4	5,310.9	104,600.0	555.5	0.67	0.3	1.1
Minimum:	3,977.0	483.5	4,707.6	104,600.0	492.4	0.59	0.3	1.0
Maximum:	4,299.4	1,889.8	6,065.0	104,600.0	634.4	0.76	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/16/2026 00:00	4,254.6	583.1	4,837.7	104,600.0	506.0	0.61	0.3	1.0
07/16/2026 01:00	4,263.4	521.1	4,784.5	104,600.0	500.5	0.60	0.3	1.0
07/16/2026 02:00	4,287.8	426.5	4,714.3	104,600.0	493.1	0.59	0.3	1.0
07/16/2026 03:00	4,315.1	378.5	4,693.6	104,600.0	491.0	0.59	0.3	1.0
07/16/2026 04:00	4,331.9	364.9	4,696.8	104,600.0	491.3	0.59	0.3	1.0
07/16/2026 05:00	4,342.1	354.7	4,696.8	104,600.0	491.3	0.59	0.3	1.0
07/16/2026 06:00	4,329.3	368.7	4,698.0	104,600.0	491.4	0.59	0.3	1.0
07/16/2026 07:00	4,297.1	438.2	4,735.3	104,600.0	495.3	0.59	0.3	1.0
07/16/2026 08:00	4,247.8	517.8	4,765.6	104,600.0	498.5	0.60	0.3	1.0
07/16/2026 09:00	4,197.5	596.6	4,794.1	104,600.0	501.5	0.60	0.3	1.0
07/16/2026 10:00	4,127.0	717.9	4,844.9	104,600.0	506.8	0.61	0.3	1.0
07/16/2026 11:00	4,051.5	875.1	4,926.6	105,300.0	518.8	0.62	0.3	1.0
07/16/2026 12:00	3,896.0	1,113.6	5,009.6	105,300.0	527.5	0.63	0.3	1.1
07/16/2026 13:00	3,867.4	1,185.1	5,052.5	105,300.0	532.0	0.64	0.3	1.1
07/16/2026 14:00	3,814.2	1,257.1	5,071.3	105,300.0	534.0	0.64	0.3	1.1
07/16/2026 15:00	3,750.8	1,330.6	5,081.4	105,300.0	535.1	0.64	0.3	1.1
07/16/2026 16:00	3,784.5	1,275.5	5,060.0	105,300.0	532.8	0.64	0.3	1.1
07/16/2026 17:00	3,873.2	1,183.2	5,056.4	105,300.0	532.4	0.64	0.3	1.1
07/16/2026 18:00	3,947.3	986.2	4,933.5	105,300.0	519.5	0.62	0.3	1.0
07/16/2026 19:00	4,081.5	738.1	4,819.6	105,300.0	507.5	0.61	0.3	1.0
07/16/2026 20:00	4,184.8	579.2	4,764.0	105,300.0	501.6	0.60	0.3	1.0
07/16/2026 21:00	4,235.4	505.1	4,740.5	105,300.0	499.2	0.60	0.3	1.0
07/16/2026 22:00	4,275.5	451.0	4,726.5	105,300.0	497.7	0.60	0.3	1.0
07/16/2026 23:00	4,308.4	397.3	4,705.7	105,300.0	495.5	0.59	0.3	1.0
Average/Sum#:	4,127.7	714.4	4,842.1	104,979.2	508.3	0.61	0.3	1.0
Minimum:	3,750.8	354.7	4,693.6	104,600.0	491.0	0.59	0.3	1.0
Maximum:	4,342.1	1,330.6	5,081.4	105,300.0	535.1	0.64	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/17/2026 00:00	4,330.9	366.8	4,697.7	105,300.0	494.7	0.59	0.3	1.0
07/17/2026 01:00	4,358.0	325.9	4,683.9	105,300.0	493.2	0.59	0.3	1.0
07/17/2026 02:00	4,360.0	324.1	4,684.1	105,300.0	493.2	0.59	0.3	1.0
07/17/2026 03:00	4,374.3	306.3	4,680.6	105,300.0	492.9	0.59	0.3	1.0
07/17/2026 04:00	4,399.0	265.9	4,664.9	105,300.0	491.2	0.59	0.3	1.0
07/17/2026 05:00	4,410.7	248.4	4,659.1	105,300.0	490.6	0.59	0.3	1.0
07/17/2026 06:00	4,398.1	284.0	4,682.1	105,300.0	493.0	0.59	0.3	1.0
07/17/2026 07:00	4,378.4	339.4	4,717.8	105,300.0	496.8	0.60	0.3	1.0
07/17/2026 08:00	4,332.5	416.3	4,748.8	105,300.0	500.0	0.60	0.3	1.0
07/17/2026 09:00	4,299.5	462.3	4,761.8	105,300.0	501.4	0.60	0.3	1.0
07/17/2026 10:00	4,257.4	536.6	4,794.0	105,300.0	504.8	0.61	0.3	1.0
07/17/2026 11:00	4,188.5	670.1	4,858.6	105,300.0	511.6	0.61	0.3	1.0
07/17/2026 12:00	4,069.9	860.8	4,930.7	105,300.0	519.2	0.62	0.3	1.0
07/17/2026 13:00	3,951.2	1,038.8	4,990.0	105,300.0	525.4	0.63	0.3	1.1
07/17/2026 14:00	3,834.2	1,188.7	5,022.9	105,300.0	528.9	0.63	0.3	1.1
07/17/2026 15:00	3,840.9	1,199.4	5,040.3	105,300.0	530.7	0.64	0.3	1.1
07/17/2026 16:00	3,818.7	1,215.3	5,034.0	105,300.0	530.1	0.64	0.3	1.1
07/17/2026 17:00	3,912.2	1,077.7	4,989.9	105,300.0	525.4	0.63	0.3	1.1
07/17/2026 18:00	4,070.3	815.9	4,886.2	105,300.0	514.5	0.62	0.3	1.0
07/17/2026 19:00	4,191.5	582.1	4,773.6	105,300.0	502.7	0.60	0.3	1.0
07/17/2026 20:00	4,245.0	473.7	4,718.7	105,300.0	496.9	0.60	0.3	1.0
07/17/2026 21:00	4,281.1	419.3	4,700.4	105,300.0	495.0	0.59	0.3	1.0
07/17/2026 22:00	4,323.3	359.8	4,683.1	105,300.0	493.1	0.59	0.3	1.0
07/17/2026 23:00	4,357.0	317.4	4,674.4	105,300.0	492.2	0.59	0.3	1.0
Average/Sum#:	4,207.6	587.3	4,794.9	105,300.0	504.9	0.61	0.3	1.0
Minimum:	3,818.7	248.4	4,659.1	105,300.0	490.6	0.59	0.3	1.0
Maximum:	4,410.7	1,215.3	5,040.3	105,300.0	530.7	0.64	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/18/2026 00:00	4,388.9	270.0	4,658.9	105,300.0	490.6	0.59	0.3	1.0
07/18/2026 01:00	4,398.9	242.0	4,640.9	105,300.0	488.7	0.59	0.3	1.0
07/18/2026 02:00	4,421.3	203.2	4,624.5	105,300.0	487.0	0.58	0.3	1.0
07/18/2026 03:00	4,446.1	181.7	4,627.8	105,300.0	487.3	0.58	0.3	1.0
07/18/2026 04:00	4,465.0	176.6	4,641.6	105,300.0	488.8	0.59	0.3	1.0
07/18/2026 05:00	4,475.9	332.2	4,784.8	105,300.0	503.8	0.61	0.3	1.0
07/18/2026 06:00	4,474.4	175.1	4,649.5	105,300.0	489.6	0.59	0.3	1.0
07/18/2026 07:00	4,459.0	198.8	4,657.8	105,300.0	490.5	0.59	0.3	1.0
07/18/2026 08:00	4,408.2	291.1	4,699.3	105,300.0	494.8	0.59	0.3	1.0
07/18/2026 09:00	4,354.6	378.5	4,733.1	105,300.0	498.4	0.60	0.3	1.0
07/18/2026 10:00	4,309.3	445.5	4,754.8	105,300.0	500.7	0.60	0.3	1.0
07/18/2026 11:00	3,955.7	265.0	4,093.5	105,300.0	431.0	0.53	0.3	0.9
07/18/2026 12:00	3,380.8	0.0	3,380.8	105,300.0	356.0	0.43	0.2	0.7
07/18/2026 13:00	3,591.1	20.3	3,593.5	105,300.0	378.4	0.46	0.2	0.8
07/18/2026 14:00	3,997.9	965.0	4,962.9	105,300.0	522.6	0.63	0.3	1.0
07/18/2026 15:00	3,942.1	1,045.4	4,987.5	105,300.0	525.2	0.63	0.3	1.1
07/18/2026 16:00	3,919.4	1,085.5	5,004.9	105,300.0	527.0	0.63	0.3	1.1
07/18/2026 17:00	3,909.7	1,086.7	4,996.4	105,300.0	526.1	0.63	0.3	1.1
07/18/2026 18:00	3,972.9	971.2	4,944.1	105,300.0	520.6	0.63	0.3	1.0
07/18/2026 19:00	4,114.4	721.1	4,835.5	105,300.0	509.2	0.61	0.3	1.0
07/18/2026 20:00	4,184.0	599.2	4,783.2	105,300.0	503.7	0.60	0.3	1.0
07/18/2026 21:00	4,206.6	562.0	4,768.6	105,300.0	502.1	0.60	0.3	1.0
07/18/2026 22:00	4,247.3	505.4	4,752.7	105,300.0	500.5	0.60	0.3	1.0
07/18/2026 23:00	4,288.8	448.1	4,736.9	105,300.0	498.8	0.60	0.3	1.0
Average/Sum#:	4,179.7	465.4	4,638.1	105,300.0	488.4	0.59	0.3	1.0
Minimum:	3,380.8	0.0	3,380.8	105,300.0	356.0	0.43	0.2	0.7
Maximum:	4,475.9	1,086.7	5,004.9	105,300.0	527.0	0.63	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/19/2026 00:00	4,319.4	396.1	4,715.5	105,300.0	496.5	0.60	0.3	1.0
07/19/2026 01:00	4,342.5	348.6	4,691.1	105,300.0	494.0	0.59	0.3	1.0
07/19/2026 02:00	4,366.9	308.0	4,674.9	105,300.0	492.3	0.59	0.3	1.0
07/19/2026 03:00	4,376.6	278.9	4,655.5	105,300.0	490.2	0.59	0.3	1.0
07/19/2026 04:00	4,384.8	250.8	4,635.6	105,300.0	488.1	0.59	0.3	1.0
07/19/2026 05:00	4,393.7	240.2	4,633.9	105,300.0	487.9	0.59	0.3	1.0
07/19/2026 06:00	4,391.7	263.8	4,655.5	105,300.0	490.2	0.59	0.3	1.0
07/19/2026 07:00	4,378.6	310.6	4,689.2	105,300.0	493.8	0.59	0.3	1.0
07/19/2026 08:00	4,333.4	386.0	4,719.4	105,300.0	497.0	0.60	0.3	1.0
07/19/2026 09:00	4,281.4	464.1	4,745.5	105,300.0	499.7	0.60	0.3	1.0
07/19/2026 10:00	4,237.2	563.0	4,800.2	105,300.0	505.5	0.61	0.3	1.0
07/19/2026 11:00	4,154.6	751.3	4,905.9	105,300.0	516.6	0.62	0.3	1.0
07/19/2026 12:00	4,018.5	959.6	4,978.1	105,300.0	524.2	0.63	0.3	1.0
07/19/2026 13:00	3,963.6	1,057.5	5,021.1	105,300.0	528.7	0.63	0.3	1.1
07/19/2026 14:00	3,913.0	1,140.5	5,053.5	105,300.0	532.1	0.64	0.3	1.1
07/19/2026 15:00	3,862.6	1,231.5	5,094.1	105,300.0	536.4	0.64	0.3	1.1
07/19/2026 16:00	3,841.8	1,283.5	5,125.3	105,300.0	539.7	0.65	0.3	1.1
07/19/2026 17:00	4,013.4	1,545.5	5,558.9	105,300.0	585.4	0.70	0.4	1.2
07/19/2026 18:00	4,261.9	1,360.0	5,621.9	105,300.0	592.0	0.71	0.4	1.2
07/19/2026 19:00	4,322.3	1,134.0	5,456.3	105,300.0	574.5	0.69	0.3	1.1
07/19/2026 20:00	4,335.8	1,566.5	5,902.3	105,300.0	621.5	0.75	0.4	1.2
07/19/2026 21:00	4,312.4	1,611.8	5,924.2	105,300.0	623.8	0.75	0.4	1.3
07/19/2026 22:00	4,324.7	1,546.6	5,871.3	105,300.0	618.2	0.74	0.4	1.2
07/19/2026 23:00	4,354.6	1,495.7	5,850.3	105,300.0	616.0	0.74	0.4	1.2
Average/Sum#:	4,228.6	853.9	5,082.5	105,300.0	535.2	0.64	0.3	1.1
Minimum:	3,841.8	240.2	4,633.9	105,300.0	487.9	0.59	0.3	1.0
Maximum:	4,393.7	1,611.8	5,924.2	105,300.0	623.8	0.75	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/20/2026 00:00	4,375.5	736.1	5,111.6	105,300.0	538.3	0.65	0.3	1.1
07/20/2026 01:00	4,297.3	426.5	4,723.8	105,300.0	497.4	0.60	0.3	1.0
07/20/2026 02:00	4,299.6	656.7	4,956.3	105,300.0	521.9	0.63	0.3	1.0
07/20/2026 03:00	4,303.0	1,611.6	5,914.6	105,300.0	622.8	0.75	0.4	1.2
07/20/2026 04:00	4,302.2	1,707.9	6,010.1	105,300.0	632.9	0.76	0.4	1.3
07/20/2026 05:00	4,316.8	1,666.2	5,983.0	105,300.0	630.0	0.76	0.4	1.3
07/20/2026 06:00	4,317.0	1,543.6	5,860.6	105,300.0	617.1	0.74	0.4	1.2
07/20/2026 07:00	4,298.9	1,436.1	5,735.0	105,300.0	603.9	0.73	0.4	1.2
07/20/2026 08:00	4,277.5	1,492.6	5,770.1	105,300.0	607.6	0.73	0.4	1.2
07/20/2026 09:00	4,238.7	1,333.5	5,572.2	105,300.0	586.8	0.70	0.4	1.2
07/20/2026 10:00	4,308.4	1,531.3	5,839.7	105,300.0	614.9	0.74	0.4	1.2
07/20/2026 11:00	4,332.0	1,452.5	5,784.5	105,300.0	609.1	0.73	0.4	1.2
07/20/2026 12:00	4,301.0	1,371.9	5,672.9	105,300.0	597.4	0.72	0.4	1.2
07/20/2026 13:00	4,288.1	1,579.4	5,867.5	105,300.0	617.8	0.74	0.4	1.2
07/20/2026 14:00	4,271.5	1,352.6	5,624.1	105,300.0	592.2	0.71	0.4	1.2
07/20/2026 15:00	4,273.0	1,360.3	5,633.3	105,300.0	593.2	0.71	0.4	1.2
07/20/2026 16:00	4,286.4	1,435.8	5,722.2	105,300.0	602.5	0.72	0.4	1.2
07/20/2026 17:00	4,293.8	1,418.3	5,712.1	105,300.0	601.5	0.72	0.4	1.2
07/20/2026 18:00	4,316.8	1,550.2	5,867.0	105,300.0	617.8	0.74	0.4	1.2
07/20/2026 19:00	4,332.2	1,425.6	5,757.8	105,300.0	606.3	0.73	0.4	1.2
07/20/2026 20:00	4,316.0	1,513.9	5,829.9	105,300.0	613.9	0.74	0.4	1.2
07/20/2026 21:00	4,328.5	1,351.8	5,680.3	105,300.0	598.1	0.72	0.4	1.2
07/20/2026 22:00	4,330.0	757.2	5,087.2	105,300.0	535.7	0.64	0.3	1.1
07/20/2026 23:00	4,201.1	1,023.8	5,224.9	105,300.0	550.2	0.66	0.3	1.1
Average/Sum#:	4,300.2	1,322.3	5,622.5	105,300.0	592.1	0.71	0.4	1.2
Minimum:	4,201.1	426.5	4,723.8	105,300.0	497.4	0.60	0.3	1.0
Maximum:	4,375.5	1,707.9	6,010.1	105,300.0	632.9	0.76	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/21/2026 00:00	4,210.5	565.4	4,775.9	105,300.0	502.9	0.60	0.3	1.0
07/21/2026 01:00	4,207.2	572.8	4,780.0	105,300.0	503.3	0.60	0.3	1.0
07/21/2026 02:00	4,218.8	559.9	4,778.7	105,300.0	503.2	0.60	0.3	1.0
07/21/2026 03:00	4,252.2	512.7	4,764.9	105,300.0	501.7	0.60	0.3	1.0
07/21/2026 04:00	4,254.2	744.9	4,999.1	105,300.0	526.4	0.63	0.3	1.1
07/21/2026 05:00	4,262.3	1,397.3	5,659.6	105,300.0	596.0	0.71	0.4	1.2
07/21/2026 06:00	4,260.5	893.1	5,153.6	105,300.0	542.7	0.65	0.3	1.1
07/21/2026 07:00	4,242.5	729.3	4,971.8	105,300.0	523.5	0.63	0.3	1.0
07/21/2026 08:00	4,203.8	903.8	5,107.6	105,300.0	537.8	0.65	0.3	1.1
07/21/2026 09:00	4,067.8	863.7	4,931.5	105,300.0	519.3	0.62	0.3	1.0
07/21/2026 10:00	3,912.1	1,127.8	5,039.9	105,300.0	530.7	0.64	0.3	1.1
07/21/2026 11:00	3,983.3	1,429.3	5,412.6	105,300.0	569.9	0.68	0.3	1.1
07/21/2026 12:00	4,255.4	1,682.0	5,937.4	105,300.0	625.2	0.75	0.4	1.3
07/21/2026 13:00	4,226.6	1,613.0	5,839.6	105,300.0	614.9	0.74	0.4	1.2
07/21/2026 14:00	4,228.0	1,666.5	5,894.5	105,300.0	620.7	0.74	0.4	1.2
07/21/2026 15:00	4,200.3	1,779.7	5,980.0	105,300.0	629.7	0.76	0.4	1.3
07/21/2026 16:00	4,200.9	1,661.0	5,861.9	105,300.0	617.3	0.74	0.4	1.2
07/21/2026 17:00	4,198.7	1,749.9	5,948.6	105,300.0	626.4	0.75	0.4	1.3
07/21/2026 18:00	4,191.3	1,876.6	6,067.9	105,300.0	638.9	0.77	0.4	1.3
07/21/2026 19:00	4,204.2	1,842.2	6,046.4	105,300.0	636.7	0.76	0.4	1.3
07/21/2026 20:00	4,253.2	1,734.7	5,987.9	105,300.0	630.5	0.76	0.4	1.3
07/21/2026 21:00	4,284.2	1,583.3	5,867.5	105,300.0	617.8	0.74	0.4	1.2
07/21/2026 22:00	4,271.3	1,452.5	5,723.8	105,300.0	602.7	0.72	0.4	1.2
07/21/2026 23:00	4,296.0	1,302.0	5,598.0	105,300.0	589.5	0.71	0.4	1.2
Average/Sum#:	4,203.6	1,260.1	5,463.7	105,300.0	575.3	0.69	0.4	1.2
Minimum:	3,912.1	512.7	4,764.9	105,300.0	501.7	0.60	0.3	1.0
Maximum:	4,296.0	1,876.6	6,067.9	105,300.0	638.9	0.77	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/22/2026 00:00	4,223.1	494.1	4,717.2	105,300.0	496.7	0.60	0.3	1.0
07/22/2026 01:00	4,228.9	493.4	4,722.3	105,300.0	497.3	0.60	0.3	1.0
07/22/2026 02:00	4,246.1	459.9	4,706.0	105,300.0	495.5	0.59	0.3	1.0
07/22/2026 03:00	4,275.6	416.0	4,691.6	105,300.0	494.0	0.59	0.3	1.0
07/22/2026 04:00	4,294.0	448.9	4,742.9	105,300.0	499.4	0.60	0.3	1.0
07/22/2026 05:00	4,303.7	712.1	5,015.8	105,300.0	528.2	0.63	0.3	1.1
07/22/2026 06:00	4,289.1	412.5	4,701.6	105,300.0	495.1	0.59	0.3	1.0
07/22/2026 07:00	4,292.2	540.1	4,832.3	105,300.0	508.8	0.61	0.3	1.0
07/22/2026 08:00	4,278.9	906.3	5,185.2	105,300.0	546.0	0.66	0.3	1.1
07/22/2026 09:00	4,261.5	470.8	4,732.3	105,300.0	498.3	0.60	0.3	1.0
07/22/2026 10:00	4,230.8	531.2	4,762.0	105,300.0	501.4	0.60	0.3	1.0
07/22/2026 11:00	4,220.5	582.3	4,802.8	105,300.0	505.7	0.61	0.3	1.0
07/22/2026 12:00	4,191.3	636.9	4,828.2	105,300.0	508.4	0.61	0.3	1.0
07/22/2026 13:00	4,126.2	730.5	4,856.7	105,300.0	511.4	0.61	0.3	1.0
07/22/2026 14:00	4,059.4	824.2	4,883.6	105,300.0	514.2	0.62	0.3	1.0
07/22/2026 15:00	4,052.1	840.1	4,892.2	105,300.0	515.1	0.62	0.3	1.0
07/22/2026 16:00	3,997.4	886.4	4,883.8	105,300.0	514.3	0.62	0.3	1.0
07/22/2026 17:00	4,027.8	841.1	4,868.9	105,300.0	512.7	0.62	0.3	1.0
07/22/2026 18:00	4,112.8	702.8	4,815.6	105,300.0	507.1	0.61	0.3	1.0
07/22/2026 19:00	4,192.5	549.7	4,742.2	105,300.0	499.4	0.60	0.3	1.0
07/22/2026 20:00	4,245.1	438.9	4,684.0	105,300.0	493.2	0.59	0.3	1.0
07/22/2026 21:00	4,279.3	371.1	4,650.4	105,300.0	489.7	0.59	0.3	1.0
07/22/2026 22:00	4,324.4	314.9	4,639.3	105,300.0	488.5	0.59	0.3	1.0
07/22/2026 23:00	4,348.4	275.8	4,624.2	105,300.0	486.9	0.58	0.3	1.0
Average/Sum#:	4,212.5	578.3	4,790.9	105,300.0	504.5	0.61	0.3	1.0
Minimum:	3,997.4	275.8	4,624.2	105,300.0	486.9	0.58	0.3	1.0
Maximum:	4,348.4	906.3	5,185.2	105,300.0	546.0	0.66	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/23/2026 00:00	4,361.0	253.7	4,614.7	105,300.0	485.9	0.58	0.3	1.0
07/23/2026 01:00	4,375.3	240.5	4,615.8	105,300.0	486.0	0.58	0.3	1.0
07/23/2026 02:00	4,384.8	213.3	4,598.1	105,300.0	484.2	0.58	0.3	1.0
07/23/2026 03:00	4,396.2	205.8	4,602.0	105,300.0	484.6	0.58	0.3	1.0
07/23/2026 04:00	4,415.9	200.7	4,616.6	105,300.0	486.1	0.58	0.3	1.0
07/23/2026 05:00	4,427.8	196.2	4,624.0	105,300.0	486.9	0.58	0.3	1.0
07/23/2026 06:00	4,408.3	240.2	4,648.5	105,300.0	489.5	0.59	0.3	1.0
07/23/2026 07:00	4,399.3	283.8	4,683.1	105,300.0	493.1	0.59	0.3	1.0
07/23/2026 08:00	4,300.8	250.8	4,493.9	105,300.0	473.2	0.57	0.3	1.0
07/23/2026 09:00	3,393.7	0.0	3,393.7	105,300.0	357.4	0.43	0.2	0.7
07/23/2026 10:00	3,369.4	0.0	3,369.4	105,300.0	354.8	0.43	0.2	0.7
07/23/2026 11:00	4,017.6	316.9	4,166.5	105,300.0	438.7	0.55	0.3	0.9
07/23/2026 12:00	4,142.7	762.6	4,905.3	105,300.0	516.5	0.62	0.3	1.0
07/23/2026 13:00	4,059.1	890.7	4,949.8	105,300.0	521.2	0.63	0.3	1.0
07/23/2026 14:00	3,992.5	976.2	4,968.7	105,300.0	523.2	0.63	0.3	1.0
07/23/2026 15:00	3,943.4	1,044.0	4,987.4	105,300.0	525.2	0.63	0.3	1.1
07/23/2026 16:00	3,926.6	1,070.7	4,997.3	105,300.0	526.2	0.63	0.3	1.1
07/23/2026 17:00	3,925.2	1,090.2	5,015.4	105,300.0	528.1	0.63	0.3	1.1
07/23/2026 18:00	3,970.5	1,192.4	5,162.9	105,300.0	543.7	0.65	0.3	1.1
07/23/2026 19:00	4,132.3	765.2	4,897.5	105,300.0	515.7	0.62	0.3	1.0
07/23/2026 20:00	4,198.7	806.3	5,005.0	105,300.0	527.0	0.63	0.3	1.1
07/23/2026 21:00	4,223.5	526.3	4,749.8	105,300.0	500.2	0.60	0.3	1.0
07/23/2026 22:00	4,277.1	484.0	4,761.1	105,300.0	501.3	0.60	0.3	1.0
07/23/2026 23:00	4,315.7	463.0	4,778.7	105,300.0	503.2	0.60	0.3	1.0
Average/Sum#:	4,139.9	519.7	4,650.2	105,300.0	489.7	0.59	0.3	1.0
Minimum:	3,369.4	0.0	3,369.4	105,300.0	354.8	0.43	0.2	0.7
Maximum:	4,427.8	1,192.4	5,162.9	105,300.0	543.7	0.65	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/24/2026 00:00	4,340.4	332.4	4,672.8	105,300.0	492.0	0.59	0.3	1.0
07/24/2026 01:00	4,357.6	309.5	4,667.1	105,300.0	491.4	0.59	0.3	1.0
07/24/2026 02:00	4,362.6	296.0	4,658.6	105,300.0	490.6	0.59	0.3	1.0
07/24/2026 03:00	4,379.4	271.2	4,650.6	105,300.0	489.7	0.59	0.3	1.0
07/24/2026 04:00	4,397.5	235.5	4,633.0	105,300.0	487.9	0.59	0.3	1.0
07/24/2026 05:00	4,414.8	229.2	4,644.0	105,300.0	489.0	0.59	0.3	1.0
07/24/2026 06:00	4,394.7	276.9	4,671.6	105,300.0	491.9	0.59	0.3	1.0
07/24/2026 07:00	4,368.3	344.8	4,713.1	105,300.0	496.3	0.60	0.3	1.0
07/24/2026 08:00	4,313.1	432.8	4,745.9	105,300.0	499.7	0.60	0.3	1.0
07/24/2026 09:00	4,259.8	524.8	4,784.6	105,300.0	503.8	0.60	0.3	1.0
07/24/2026 10:00	4,210.6	617.4	4,828.0	105,300.0	508.4	0.61	0.3	1.0
07/24/2026 11:00	3,442.6	9.1	3,442.9	105,300.0	362.5	0.44	0.2	0.7
07/24/2026 12:00	4,006.0	529.3	4,350.0	105,300.0	458.1	0.57	0.3	1.0
07/24/2026 13:00	4,056.4	1,481.8	5,538.2	105,300.0	583.2	0.70	0.3	1.2
07/24/2026 14:00	4,264.8	1,730.9	5,995.7	105,300.0	631.3	0.76	0.4	1.3
07/24/2026 15:00	4,259.6	1,708.1	5,967.7	105,300.0	628.4	0.75	0.4	1.3
07/24/2026 16:00	4,209.2	1,164.8	5,374.0	105,300.0	565.9	0.68	0.3	1.1
07/24/2026 17:00	4,269.4	1,252.0	5,521.4	105,300.0	581.4	0.70	0.3	1.2
07/24/2026 18:00	4,293.9	1,344.0	5,637.9	105,300.0	593.7	0.71	0.4	1.2
07/24/2026 19:00	4,309.0	658.7	4,967.7	105,300.0	523.1	0.63	0.3	1.0
07/24/2026 20:00	4,342.7	641.0	4,983.7	105,300.0	524.8	0.63	0.3	1.0
07/24/2026 21:00	4,367.4	427.8	4,795.2	105,300.0	504.9	0.61	0.3	1.0
07/24/2026 22:00	4,361.3	293.3	4,654.6	105,300.0	490.1	0.59	0.3	1.0
07/24/2026 23:00	4,331.0	357.3	4,688.3	105,300.0	493.7	0.59	0.3	1.0
Average/Sum#:	4,263.0	644.5	4,899.4	105,300.0	515.9	0.62	0.3	1.0
Minimum:	3,442.6	9.1	3,442.9	105,300.0	362.5	0.44	0.2	0.7
Maximum:	4,414.8	1,730.9	5,995.7	105,300.0	631.3	0.76	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/25/2026 00:00	4,351.2	324.5	4,675.7	105,300.0	492.4	0.59	0.3	1.0
07/25/2026 01:00	4,368.3	296.2	4,664.5	105,300.0	491.2	0.59	0.3	1.0
07/25/2026 02:00	4,379.2	279.3	4,658.5	105,300.0	490.5	0.59	0.3	1.0
07/25/2026 03:00	4,379.3	271.6	4,650.9	105,300.0	489.7	0.59	0.3	1.0
07/25/2026 04:00	4,393.2	246.5	4,639.7	105,300.0	488.6	0.59	0.3	1.0
07/25/2026 05:00	4,416.4	222.4	4,638.8	105,300.0	488.5	0.59	0.3	1.0
07/25/2026 06:00	4,403.7	270.9	4,674.6	105,300.0	492.2	0.59	0.3	1.0
07/25/2026 07:00	4,366.0	347.8	4,713.8	105,300.0	496.4	0.60	0.3	1.0
07/25/2026 08:00	4,316.0	421.3	4,737.3	105,300.0	498.8	0.60	0.3	1.0
07/25/2026 09:00	4,257.1	526.5	4,783.6	105,300.0	503.7	0.61	0.3	1.0
07/25/2026 10:00	4,201.9	631.8	4,833.7	105,300.0	509.0	0.61	0.3	1.0
07/25/2026 11:00	4,118.5	791.8	4,910.3	105,300.0	517.1	0.62	0.3	1.0
07/25/2026 12:00	4,005.5	981.7	4,987.2	105,300.0	525.2	0.63	0.3	1.1
07/25/2026 13:00	3,942.1	1,091.7	5,033.8	105,300.0	530.1	0.64	0.3	1.1
07/25/2026 14:00	3,880.0	1,181.6	5,061.6	105,300.0	533.0	0.64	0.3	1.1
07/25/2026 15:00	3,822.2	1,247.0	5,069.2	105,300.0	533.8	0.64	0.3	1.1
07/25/2026 16:00	3,787.1	1,307.7	5,094.8	105,300.0	536.5	0.64	0.3	1.1
07/25/2026 17:00	3,812.8	1,269.4	5,082.2	105,300.0	535.2	0.64	0.3	1.1
07/25/2026 18:00	3,932.2	1,060.2	4,992.4	105,300.0	525.7	0.63	0.3	1.1
07/25/2026 19:00	4,062.0	809.9	4,871.9	105,300.0	513.0	0.62	0.3	1.0
07/25/2026 20:00	4,154.3	634.5	4,788.8	105,300.0	504.3	0.61	0.3	1.0
07/25/2026 21:00	4,188.6	554.2	4,742.8	105,300.0	499.4	0.60	0.3	1.0
07/25/2026 22:00	4,229.3	493.0	4,722.3	105,300.0	497.3	0.60	0.3	1.0
07/25/2026 23:00	4,265.1	438.2	4,703.3	105,300.0	495.3	0.59	0.3	1.0
Average/Sum#:	4,168.0	654.2	4,822.2	105,300.0	507.8	0.61	0.3	1.0
Minimum:	3,787.1	222.4	4,638.8	105,300.0	488.5	0.59	0.3	1.0
Maximum:	4,416.4	1,307.7	5,094.8	105,300.0	536.5	0.64	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/26/2026 00:00	4,302.5	396.5	4,699.0	105,300.0	494.8	0.59	0.3	1.0
07/26/2026 01:00	4,326.5	352.7	4,679.2	105,300.0	492.7	0.59	0.3	1.0
07/26/2026 02:00	4,346.9	306.9	4,653.8	105,300.0	490.0	0.59	0.3	1.0
07/26/2026 03:00	4,371.9	273.1	4,645.0	105,300.0	489.1	0.59	0.3	1.0
07/26/2026 04:00	4,387.7	255.3	4,643.0	105,300.0	488.9	0.59	0.3	1.0
07/26/2026 05:00	4,395.6	245.8	4,641.4	105,300.0	488.7	0.59	0.3	1.0
07/26/2026 06:00	4,386.9	273.8	4,655.2	105,300.0	490.2	0.59	0.3	1.0
07/26/2026 07:00	3,435.3	0.0	3,435.3	105,300.0	361.7	0.44	0.2	0.7
07/26/2026 08:00	4,075.6	205.9	4,174.4	105,300.0	439.6	0.54	0.3	0.9
07/26/2026 09:00	4,258.8	515.1	4,773.9	105,300.0	502.7	0.60	0.3	1.0
07/26/2026 10:00	4,206.8	613.3	4,820.1	105,300.0	507.6	0.61	0.3	1.0
07/26/2026 11:00	4,155.5	718.7	4,874.2	105,300.0	513.3	0.62	0.3	1.0
07/26/2026 12:00	4,031.4	927.2	4,958.6	105,300.0	522.1	0.63	0.3	1.0
07/26/2026 13:00	3,946.9	1,071.8	5,018.7	105,300.0	528.5	0.63	0.3	1.1
07/26/2026 14:00	3,890.0	1,164.9	5,054.9	105,300.0	532.3	0.64	0.3	1.1
07/26/2026 15:00	3,845.6	1,211.2	5,056.8	105,300.0	532.5	0.64	0.3	1.1
07/26/2026 16:00	3,831.8	1,228.6	5,060.4	105,300.0	532.9	0.64	0.3	1.1
07/26/2026 17:00	3,835.9	1,209.8	5,045.7	105,300.0	531.3	0.64	0.3	1.1
07/26/2026 18:00	3,994.7	954.6	4,949.3	105,300.0	521.2	0.63	0.3	1.0
07/26/2026 19:00	4,097.9	739.6	4,837.5	105,300.0	509.4	0.61	0.3	1.0
07/26/2026 20:00	4,188.3	654.8	4,843.1	105,300.0	510.0	0.61	0.3	1.0
07/26/2026 21:00	4,244.2	1,026.6	5,270.8	105,300.0	555.0	0.67	0.3	1.1
07/26/2026 22:00	4,283.4	946.9	5,230.3	105,300.0	550.8	0.66	0.3	1.1
07/26/2026 23:00	4,321.7	351.7	4,673.4	105,300.0	492.1	0.59	0.3	1.0
Average/Sum#:	4,131.7	651.9	4,778.9	105,300.0	503.2	0.61	0.3	1.0
Minimum:	3,435.3	0.0	3,435.3	105,300.0	361.7	0.44	0.2	0.7
Maximum:	4,395.6	1,228.6	5,270.8	105,300.0	555.0	0.67	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/27/2026 00:00	4,340.7	469.7	4,810.4	105,300.0	506.5	0.61	0.3	1.0
07/27/2026 01:00	4,364.6	273.1	4,637.7	105,300.0	488.3	0.59	0.3	1.0
07/27/2026 02:00	4,382.1	243.2	4,625.3	105,300.0	487.0	0.58	0.3	1.0
07/27/2026 03:00	4,391.4	231.5	4,622.9	105,300.0	486.8	0.58	0.3	1.0
07/27/2026 04:00	4,407.0	204.4	4,611.4	105,300.0	485.6	0.58	0.3	1.0
07/27/2026 05:00	4,411.7	189.3	4,601.0	105,300.0	484.5	0.58	0.3	1.0
07/27/2026 06:00	4,406.5	229.1	4,635.6	105,300.0	488.1	0.59	0.3	1.0
07/27/2026 07:00	4,380.1	296.5	4,676.6	105,300.0	492.4	0.59	0.3	1.0
07/27/2026 08:00	4,325.7	379.5	4,705.2	105,300.0	495.5	0.59	0.3	1.0
07/27/2026 09:00	4,278.5	473.5	4,752.0	105,300.0	500.4	0.60	0.3	1.0
07/27/2026 10:00	4,227.0	560.7	4,787.7	105,300.0	504.1	0.60	0.3	1.0
07/27/2026 11:00	4,172.7	697.1	4,869.8	105,300.0	512.8	0.62	0.3	1.0
07/27/2026 12:00	4,078.3	868.7	4,947.0	105,300.0	520.9	0.63	0.3	1.0
07/27/2026 13:00	4,000.7	998.4	4,999.1	105,300.0	526.4	0.63	0.3	1.1
07/27/2026 14:00	3,947.9	1,081.3	5,029.2	105,300.0	529.6	0.64	0.3	1.1
07/27/2026 15:00	3,900.7	1,132.9	5,033.6	105,300.0	530.0	0.64	0.3	1.1
07/27/2026 16:00	3,868.7	1,181.6	5,050.3	105,300.0	531.8	0.64	0.3	1.1
07/27/2026 17:00	3,987.5	1,071.4	5,058.9	105,300.0	532.7	0.64	0.3	1.1
07/27/2026 18:00	4,286.8	1,013.4	5,300.2	105,300.0	558.1	0.67	0.3	1.1
07/27/2026 19:00	4,313.2	1,045.2	5,358.4	105,300.0	564.2	0.68	0.3	1.1
07/27/2026 20:00	4,344.3	696.1	5,040.4	105,300.0	530.8	0.64	0.3	1.1
07/27/2026 21:00	4,305.5	411.3	4,716.8	105,300.0	496.7	0.60	0.3	1.0
07/27/2026 22:00	4,276.4	420.5	4,696.9	105,300.0	494.6	0.59	0.3	1.0
07/27/2026 23:00	4,305.4	376.4	4,681.8	105,300.0	493.0	0.59	0.3	1.0
Average/Sum#:	4,237.6	606.0	4,843.7	105,300.0	510.0	0.61	0.3	1.0
Minimum:	3,868.7	189.3	4,601.0	105,300.0	484.5	0.58	0.3	1.0
Maximum:	4,411.7	1,181.6	5,358.4	105,300.0	564.2	0.68	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/28/2026 00:00	4,336.3	338.6	4,674.9	105,300.0	492.3	0.59	0.3	1.0
07/28/2026 01:00	4,352.0	298.8	4,650.8	105,300.0	489.7	0.59	0.3	1.0
07/28/2026 02:00	4,375.8	278.9	4,654.7	105,300.0	490.1	0.59	0.3	1.0
07/28/2026 03:00	4,384.0	257.1	4,641.1	105,300.0	488.7	0.59	0.3	1.0
07/28/2026 04:00	4,391.5	250.1	4,641.6	105,300.0	488.8	0.59	0.3	1.0
07/28/2026 05:00	4,409.9	224.3	4,634.2	105,300.0	488.0	0.59	0.3	1.0
07/28/2026 06:00	4,402.1	258.1	4,660.2	105,300.0	490.7	0.59	0.3	1.0
07/28/2026 07:00	3,818.1	46.3	3,826.4	105,300.0	402.9	0.49	0.2	0.8
07/28/2026 08:00	3,377.5	0.0	3,377.5	105,300.0	355.7	0.43	0.2	0.7
07/28/2026 09:00	3,375.1	0.0	3,375.1	105,300.0	355.4	0.43	0.2	0.7
07/28/2026 10:00	3,371.0	0.0	3,371.0	105,300.0	355.0	0.43	0.2	0.7
07/28/2026 11:00	3,620.7	3.1	3,620.8	105,300.0	381.3	0.46	0.2	0.8
07/28/2026 12:00	4,116.0	578.5	4,578.8	105,300.0	482.1	0.59	0.3	1.0
07/28/2026 13:00	3,400.3	0.0	3,400.3	105,300.0	358.1	0.43	0.2	0.7
07/28/2026 14:00	3,382.9	0.0	3,382.9	105,300.0	356.2	0.43	0.2	0.7
07/28/2026 15:00	3,610.7	3.1	3,610.8	105,300.0	380.2	0.46	0.2	0.8
07/28/2026 16:00	4,227.4	574.9	4,802.3	105,300.0	505.7	0.61	0.3	1.0
07/28/2026 17:00	4,257.3	562.9	4,820.2	105,300.0	507.6	0.61	0.3	1.0
07/28/2026 18:00	4,012.0	941.3	4,953.3	105,300.0	521.6	0.63	0.3	1.0
07/28/2026 19:00	4,051.6	846.3	4,897.9	105,300.0	515.7	0.62	0.3	1.0
07/28/2026 20:00	4,160.9	659.5	4,820.4	105,300.0	507.6	0.61	0.3	1.0
07/28/2026 21:00	4,149.0	629.9	4,778.9	105,300.0	503.2	0.60	0.3	1.0
07/28/2026 22:00	4,189.0	557.0	4,746.0	105,300.0	499.8	0.60	0.3	1.0
07/28/2026 23:00	3,443.3	6.2	3,443.5	105,300.0	362.6	0.43	0.2	0.7
Average/Sum#:	3,967.3	304.8	4,265.2	105,300.0	449.1	0.54	0.3	0.9
Minimum:	3,371.0	0.0	3,371.0	105,300.0	355.0	0.43	0.2	0.7
Maximum:	4,409.9	941.3	4,953.3	105,300.0	521.6	0.63	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/29/2026 00:00	3,359.7	0.0	3,359.7	105,300.0	353.8	0.42	0.2	0.7
07/29/2026 01:00	3,361.3	0.0	3,361.3	105,300.0	353.9	0.42	0.2	0.7
07/29/2026 02:00	3,365.3	0.0	3,365.3	105,300.0	354.4	0.43	0.2	0.7
07/29/2026 03:00	3,369.4	0.0	3,369.4	105,300.0	354.8	0.43	0.2	0.7
07/29/2026 04:00	3,368.3	0.0	3,368.3	105,300.0	354.7	0.43	0.2	0.7
07/29/2026 05:00	3,368.7	0.0	3,368.7	105,300.0	354.7	0.43	0.2	0.7
07/29/2026 06:00	3,369.3	0.0	3,369.3	105,300.0	354.8	0.43	0.2	0.7
07/29/2026 07:00	3,373.1	0.0	3,373.1	105,300.0	355.2	0.43	0.2	0.7
07/29/2026 08:00	3,364.6	0.0	3,364.6	105,300.0	354.3	0.43	0.2	0.7
07/29/2026 09:00	3,366.3	0.0	3,366.3	105,300.0	354.5	0.43	0.2	0.7
07/29/2026 10:00	3,599.3	3.1	3,599.4	105,300.0	379.0	0.46	0.2	0.8
07/29/2026 11:00	4,102.9	835.7	4,938.6	105,300.0	520.0	0.62	0.3	1.0
07/29/2026 12:00	3,961.2	1,022.8	4,984.0	105,300.0	524.8	0.63	0.3	1.0
07/29/2026 13:00	3,838.5	1,210.1	5,048.6	105,300.0	531.6	0.64	0.3	1.1
07/29/2026 14:00	3,797.5	1,275.8	5,073.3	105,300.0	534.2	0.64	0.3	1.1
07/29/2026 15:00	3,759.1	1,341.7	5,100.8	105,300.0	537.1	0.64	0.3	1.1
07/29/2026 16:00	3,754.8	1,353.3	5,108.1	105,300.0	537.9	0.65	0.3	1.1
07/29/2026 17:00	3,764.6	1,373.5	5,138.1	105,300.0	541.0	0.65	0.3	1.1
07/29/2026 18:00	3,850.8	1,294.7	5,145.5	105,300.0	541.8	0.65	0.3	1.1
07/29/2026 19:00	3,891.6	1,048.8	4,940.4	105,300.0	520.2	0.62	0.3	1.0
07/29/2026 20:00	4,058.9	770.3	4,829.2	105,300.0	508.5	0.61	0.3	1.0
07/29/2026 21:00	3,437.1	15.2	3,438.2	105,300.0	362.0	0.43	0.2	0.7
07/29/2026 22:00	3,354.0	0.0	3,354.0	105,300.0	353.2	0.42	0.2	0.7
07/29/2026 23:00	3,358.6	0.0	3,358.6	105,300.0	353.7	0.42	0.2	0.7
Average/Sum#:	3,591.5	481.0	4,071.8	105,300.0	428.8	0.52	0.2	0.9
Minimum:	3,354.0	0.0	3,354.0	105,300.0	353.2	0.42	0.2	0.7
Maximum:	4,102.9	1,373.5	5,145.5	105,300.0	541.8	0.65	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/30/2026 00:00	3,362.1	0.0	3,362.1	105,300.0	354.0	0.42	0.2	0.7
07/30/2026 01:00	3,361.8	0.0	3,361.8	105,300.0	354.0	0.42	0.2	0.7
07/30/2026 02:00	3,362.1	0.0	3,362.1	105,300.0	354.0	0.42	0.2	0.7
07/30/2026 03:00	3,365.3	0.0	3,365.3	105,300.0	354.4	0.43	0.2	0.7
07/30/2026 04:00	3,366.2	0.0	3,366.2	105,300.0	354.5	0.43	0.2	0.7
07/30/2026 05:00	3,365.1	0.0	3,365.1	105,300.0	354.3	0.43	0.2	0.7
07/30/2026 06:00	3,366.4	0.0	3,366.4	105,300.0	354.5	0.43	0.2	0.7
07/30/2026 07:00	3,372.3	0.0	3,372.3	105,300.0	355.1	0.43	0.2	0.7
07/30/2026 08:00	3,360.3	0.0	3,360.3	105,300.0	353.8	0.42	0.2	0.7
07/30/2026 09:00	3,358.5	0.0	3,358.5	105,300.0	353.7	0.42	0.2	0.7
07/30/2026 10:00	3,357.4	0.0	3,357.4	105,300.0	353.5	0.42	0.2	0.7
07/30/2026 11:00	3,364.2	0.0	3,364.2	105,300.0	354.3	0.43	0.2	0.7
07/30/2026 12:00	3,365.9	0.0	3,365.9	105,300.0	354.4	0.43	0.2	0.7
07/30/2026 13:00	3,369.0	0.0	3,369.0	105,300.0	354.8	0.43	0.2	0.7
07/30/2026 14:00	3,734.1	0.0	3,734.1	105,300.0	393.2	0.47	0.2	0.8
07/30/2026 15:00	3,379.7	0.0	3,379.7	105,300.0	355.9	0.43	0.2	0.7
07/30/2026 16:00	3,501.3	0.0	3,501.3	105,300.0	368.7	0.44	0.2	0.7
07/30/2026 17:00	3,802.5	0.0	3,802.5	105,300.0	400.4	0.48	0.2	0.8
07/30/2026 18:00	4,097.9	0.0	4,097.9	105,300.0	431.5	0.52	0.3	0.9
07/30/2026 19:00	3,517.9	0.0	3,517.9	105,300.0	370.4	0.44	0.2	0.7
07/30/2026 20:00	3,338.2	0.0	3,338.2	105,300.0	351.5	0.42	0.2	0.7
07/30/2026 21:00	3,414.5	0.0	3,414.5	105,300.0	359.5	0.43	0.2	0.7
07/30/2026 22:00	3,514.4	0.0	3,514.4	105,300.0	370.1	0.44	0.2	0.7
07/30/2026 23:00	3,366.2	0.0	3,366.2	105,300.0	354.5	0.42	0.2	0.7
Average/Sum#:	3,448.5	0.0	3,448.5	105,300.0	363.1	0.44	0.2	0.7
Minimum:	3,338.2	0.0	3,338.2	105,300.0	351.5	0.42	0.2	0.7
Maximum:	4,097.9	0.0	4,097.9	105,300.0	431.5	0.52	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/31/2026 00:00	3,348.1	0.0	3,348.1	105,300.0	352.6	0.42	0.2	0.7
07/31/2026 01:00	3,356.9	0.0	3,356.9	105,300.0	353.5	0.42	0.2	0.7
07/31/2026 02:00	3,363.2	0.0	3,363.2	105,300.0	354.1	0.43	0.2	0.7
07/31/2026 03:00	3,367.7	0.0	3,367.7	105,300.0	354.6	0.43	0.2	0.7
07/31/2026 04:00	3,544.8	0.0	3,544.8	105,300.0	373.3	0.45	0.2	0.7
07/31/2026 05:00	3,373.8	0.0	3,373.8	105,300.0	355.3	0.43	0.2	0.7
07/31/2026 06:00	3,371.7	0.0	3,371.7	105,300.0	355.0	0.43	0.2	0.7
07/31/2026 07:00	3,378.1	0.0	3,378.1	105,300.0	355.7	0.43	0.2	0.7
07/31/2026 08:00	3,368.7	0.0	3,368.7	105,300.0	354.7	0.43	0.2	0.7
07/31/2026 09:00	3,365.2	0.0	3,365.2	105,300.0	354.4	0.43	0.2	0.7
07/31/2026 10:00	3,363.3	0.0	3,363.3	105,300.0	354.2	0.43	0.2	0.7
07/31/2026 11:00	3,499.9	0.0	3,499.9	105,300.0	368.5	0.45	0.2	0.7
07/31/2026 12:00	4,145.1	0.0	4,145.1	105,300.0	436.5	0.52	0.3	0.9
07/31/2026 13:00	4,134.8	0.0	4,134.8	105,300.0	435.4	0.52	0.3	0.9
07/31/2026 14:00	4,136.6	3.7	4,136.7	105,300.0	435.6	0.52	0.3	0.9
07/31/2026 15:00	4,255.5	757.1	5,012.6	105,300.0	527.8	0.63	0.3	1.1
07/31/2026 16:00	4,250.8	1,011.5	5,262.3	105,300.0	554.1	0.66	0.3	1.1
07/31/2026 17:00	4,257.6	1,325.2	5,582.8	105,300.0	587.9	0.70	0.4	1.2
07/31/2026 18:00	4,259.3	1,756.3	6,015.6	105,300.0	633.4	0.76	0.4	1.3
07/31/2026 19:00	4,280.6	616.6	4,897.2	105,300.0	515.7	0.62	0.3	1.0
07/31/2026 20:00	4,056.9	767.9	4,824.8	105,300.0	508.1	0.61	0.3	1.0
07/31/2026 21:00	4,079.3	705.1	4,784.4	105,300.0	503.8	0.61	0.3	1.0
07/31/2026 22:00	4,165.3	572.9	4,738.2	105,300.0	498.9	0.60	0.3	1.0
07/31/2026 23:00	3,438.0	5.4	3,438.2	105,300.0	362.0	0.43	0.2	0.7
Average/Sum#:	3,756.7	313.4	4,069.8	105,300.0	428.5	0.52	0.3	0.9
Minimum:	3,348.1	0.0	3,348.1	105,300.0	352.6	0.42	0.2	0.7
Maximum:	4,280.6	1,756.3	6,015.6	105,300.0	633.4	0.76	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/01/2026 00:00	3,363.3	0.0	3,363.3	105,300.0	354.2	0.43	0.2	0.7
08/01/2026 01:00	3,362.8	0.0	3,362.8	105,300.0	354.1	0.42	0.2	0.7
08/01/2026 02:00	3,367.2	0.0	3,367.2	105,300.0	354.6	0.43	0.2	0.7
08/01/2026 03:00	3,373.0	0.0	3,373.0	105,300.0	355.2	0.43	0.2	0.7
08/01/2026 04:00	3,375.6	0.0	3,375.6	105,300.0	355.5	0.43	0.2	0.7
08/01/2026 05:00	3,377.5	0.0	3,377.5	105,300.0	355.7	0.43	0.2	0.7
08/01/2026 06:00	3,377.9	0.0	3,377.9	105,300.0	355.7	0.43	0.2	0.7
08/01/2026 07:00	3,381.8	0.0	3,381.8	105,300.0	356.1	0.43	0.2	0.7
08/01/2026 08:00	3,372.3	0.0	3,372.3	105,300.0	355.1	0.43	0.2	0.7
08/01/2026 09:00	3,370.2	0.0	3,370.2	105,300.0	354.9	0.43	0.2	0.7
08/01/2026 10:00	3,367.1	0.0	3,367.1	105,300.0	354.6	0.43	0.2	0.7
08/01/2026 11:00	3,380.7	0.0	3,380.7	105,300.0	356.0	0.43	0.2	0.7
08/01/2026 12:00	3,380.3	0.0	3,380.3	105,300.0	355.9	0.43	0.2	0.7
08/01/2026 13:00	3,376.4	0.0	3,376.4	105,300.0	355.5	0.43	0.2	0.7
08/01/2026 14:00	3,599.7	3.8	3,599.8	105,300.0	379.1	0.46	0.2	0.8
08/01/2026 15:00	4,168.4	639.1	4,807.5	105,300.0	506.2	0.61	0.3	1.0
08/01/2026 16:00	4,057.3	838.7	4,896.0	105,300.0	515.5	0.62	0.3	1.0
08/01/2026 17:00	4,198.5	1,194.0	5,392.5	105,300.0	567.8	0.68	0.3	1.1
08/01/2026 18:00	4,198.2	1,786.1	5,984.3	105,300.0	630.1	0.76	0.4	1.3
08/01/2026 19:00	4,237.8	1,320.6	5,558.4	105,300.0	585.3	0.70	0.4	1.2
08/01/2026 20:00	4,236.5	491.7	4,728.2	105,300.0	497.9	0.60	0.3	1.0
08/01/2026 21:00	3,962.0	907.1	4,869.1	105,300.0	512.7	0.62	0.3	1.0
08/01/2026 22:00	4,004.5	797.8	4,802.3	105,300.0	505.7	0.61	0.3	1.0
08/01/2026 23:00	3,832.8	7.3	3,833.0	105,300.0	403.6	0.49	0.2	0.8
Average/Sum#:	3,655.1	332.8	3,987.4	105,300.0	419.9	0.51	0.2	0.8
Minimum:	3,362.8	0.0	3,362.8	105,300.0	354.1	0.42	0.2	0.7
Maximum:	4,237.8	1,786.1	5,984.3	105,300.0	630.1	0.76	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/02/2026 00:00	3,382.8	0.0	3,382.8	105,300.0	356.2	0.43	0.2	0.7
08/02/2026 01:00	3,348.4	0.0	3,348.4	105,300.0	352.6	0.42	0.2	0.7
08/02/2026 02:00	3,350.5	0.0	3,350.5	105,300.0	352.8	0.42	0.2	0.7
08/02/2026 03:00	3,362.5	0.0	3,362.5	105,300.0	354.1	0.42	0.2	0.7
08/02/2026 04:00	3,361.9	0.0	3,361.9	105,300.0	354.0	0.42	0.2	0.7
08/02/2026 05:00	3,366.1	0.0	3,366.1	105,300.0	354.5	0.43	0.2	0.7
08/02/2026 06:00	3,363.2	0.0	3,363.2	105,300.0	354.1	0.42	0.2	0.7
08/02/2026 07:00	3,365.8	0.0	3,365.8	105,300.0	354.4	0.43	0.2	0.7
08/02/2026 08:00	3,355.9	0.0	3,355.9	105,300.0	353.4	0.42	0.2	0.7
08/02/2026 09:00	3,348.1	0.0	3,348.1	105,300.0	352.6	0.42	0.2	0.7
08/02/2026 10:00	3,349.9	0.0	3,349.9	105,300.0	352.7	0.42	0.2	0.7
08/02/2026 11:00	3,359.5	0.0	3,359.5	105,300.0	353.8	0.42	0.2	0.7
08/02/2026 12:00	3,356.7	0.0	3,356.7	105,300.0	353.5	0.42	0.2	0.7
08/02/2026 13:00	3,600.5	3.8	3,600.6	105,300.0	379.1	0.45	0.2	0.8
08/02/2026 14:00	4,206.7	592.6	4,799.3	105,300.0	505.4	0.61	0.3	1.0
08/02/2026 15:00	4,192.2	593.3	4,785.5	105,300.0	503.9	0.60	0.3	1.0
08/02/2026 16:00	4,190.3	830.8	5,021.1	105,300.0	528.7	0.63	0.3	1.1
08/02/2026 17:00	4,192.7	668.9	4,861.6	105,300.0	511.9	0.61	0.3	1.0
08/02/2026 18:00	4,154.6	671.8	4,826.4	105,300.0	508.2	0.61	0.3	1.0
08/02/2026 19:00	3,776.4	1,264.2	5,040.6	105,300.0	530.8	0.64	0.3	1.1
08/02/2026 20:00	3,849.3	1,135.5	4,984.8	105,300.0	524.9	0.63	0.3	1.0
08/02/2026 21:00	3,891.5	1,013.7	4,905.2	105,300.0	516.5	0.62	0.3	1.0
08/02/2026 22:00	3,980.3	141.0	4,095.9	105,300.0	431.3	0.52	0.3	0.9
08/02/2026 23:00	3,859.8	95.0	3,914.0	105,300.0	412.1	0.50	0.2	0.8
Average/Sum#:	3,648.6	292.1	3,937.8	105,300.0	414.6	0.50	0.2	0.8
Minimum:	3,348.1	0.0	3,348.1	105,300.0	352.6	0.42	0.2	0.7
Maximum:	4,206.7	1,264.2	5,040.6	105,300.0	530.8	0.64	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/03/2026 00:00	3,353.7	0.0	3,353.7	105,300.0	353.1	0.42	0.2	0.7
08/03/2026 01:00	3,617.3	0.0	3,617.3	105,300.0	380.9	0.46	0.2	0.8
08/03/2026 02:00	3,342.4	0.0	3,342.4	105,300.0	352.0	0.42	0.2	0.7
08/03/2026 03:00	3,342.8	0.0	3,342.8	105,300.0	352.0	0.42	0.2	0.7
08/03/2026 04:00	3,830.7	0.0	3,830.7	105,300.0	403.4	0.48	0.2	0.8
08/03/2026 05:00	3,735.7	0.0	3,735.7	105,300.0	393.4	0.47	0.2	0.8
08/03/2026 06:00	3,363.7	0.0	3,363.7	105,300.0	354.2	0.42	0.2	0.7
08/03/2026 07:00	3,366.4	0.0	3,366.4	105,300.0	354.5	0.43	0.2	0.7
08/03/2026 08:00	3,349.6	0.0	3,349.6	105,300.0	352.7	0.42	0.2	0.7
08/03/2026 09:00	3,347.2	0.0	3,347.2	105,300.0	352.5	0.42	0.2	0.7
08/03/2026 10:00	3,348.6	0.0	3,348.6	105,300.0	352.6	0.42	0.2	0.7
08/03/2026 11:00	3,358.7	0.0	3,358.7	105,300.0	353.7	0.42	0.2	0.7
08/03/2026 12:00	3,650.0	0.0	3,650.0	105,300.0	384.3	0.46	0.2	0.8
08/03/2026 13:00	3,807.0	3.8	3,807.1	105,300.0	400.9	0.48	0.2	0.8
08/03/2026 14:00	4,176.6	748.4	4,925.0	105,300.0	518.6	0.62	0.3	1.0
08/03/2026 15:00	4,184.3	669.1	4,853.4	105,300.0	511.1	0.61	0.3	1.0
08/03/2026 16:00	4,187.7	1,106.1	5,293.8	105,300.0	557.4	0.67	0.3	1.1
08/03/2026 17:00	4,187.1	1,232.2	5,419.3	105,300.0	570.7	0.69	0.3	1.1
08/03/2026 18:00	4,171.4	1,904.2	6,075.6	105,300.0	639.8	0.77	0.4	1.3
08/03/2026 19:00	4,184.1	1,632.6	5,816.7	105,300.0	612.5	0.74	0.4	1.2
08/03/2026 20:00	4,227.4	1,351.6	5,579.0	105,300.0	587.5	0.70	0.4	1.2
08/03/2026 21:00	4,109.3	918.3	5,027.6	105,300.0	529.4	0.64	0.3	1.1
08/03/2026 22:00	3,805.0	83.7	3,842.7	105,300.0	404.6	0.49	0.2	0.8
08/03/2026 23:00	4,007.5	0.0	4,007.5	105,300.0	422.0	0.51	0.3	0.8
Average/Sum#:	3,752.3	402.1	4,152.3	105,300.0	437.2	0.52	0.3	0.9
Minimum:	3,342.4	0.0	3,342.4	105,300.0	352.0	0.42	0.2	0.7
Maximum:	4,227.4	1,904.2	6,075.6	105,300.0	639.8	0.77	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/04/2026 00:00	3,493.5	0.0	3,493.5	105,300.0	367.9	0.44	0.2	0.7
08/04/2026 01:00	3,348.2	0.0	3,348.2	105,300.0	352.6	0.42	0.2	0.7
08/04/2026 02:00	3,346.7	0.0	3,346.7	105,300.0	352.4	0.42	0.2	0.7
08/04/2026 03:00	3,519.5	0.0	3,519.5	105,300.0	370.6	0.44	0.2	0.7
08/04/2026 04:00	3,865.0	0.0	3,865.0	105,300.0	407.0	0.49	0.2	0.8
08/04/2026 05:00	3,730.5	0.0	3,730.5	105,300.0	392.8	0.47	0.2	0.8
08/04/2026 06:00	3,607.6	0.0	3,607.6	105,300.0	379.9	0.45	0.2	0.8
08/04/2026 07:00	3,355.2	0.0	3,355.2	105,300.0	353.3	0.42	0.2	0.7
08/04/2026 08:00	3,349.2	0.0	3,349.2	105,300.0	352.7	0.42	0.2	0.7
08/04/2026 09:00	3,351.7	0.0	3,351.7	105,300.0	352.9	0.42	0.2	0.7
08/04/2026 10:00	3,377.3	0.0	3,377.3	105,300.0	355.6	0.42	0.2	0.7
08/04/2026 11:00	3,558.5	0.0	3,558.5	105,300.0	374.7	0.45	0.2	0.7
08/04/2026 12:00	3,847.8	0.0	3,847.8	105,300.0	405.2	0.49	0.2	0.8
08/04/2026 13:00	4,027.0	3.7	4,027.1	105,300.0	424.1	0.51	0.3	0.8
08/04/2026 14:00	4,194.4	938.7	5,133.1	105,300.0	540.5	0.65	0.3	1.1
08/04/2026 15:00	4,178.6	1,072.0	5,250.6	105,300.0	552.9	0.66	0.3	1.1
08/04/2026 16:00	4,170.4	901.0	5,071.4	105,300.0	534.0	0.64	0.3	1.1
08/04/2026 17:00	4,089.5	1,180.4	5,187.3	105,300.0	546.2	0.67	0.3	1.1
08/04/2026 18:00	4,209.0	1,492.0	5,701.0	105,300.0	600.3	0.72	0.4	1.2
08/04/2026 19:00	4,243.5	489.1	4,732.6	105,300.0	498.3	0.60	0.3	1.0
08/04/2026 20:00	4,146.1	633.1	4,779.2	105,300.0	503.2	0.61	0.3	1.0
08/04/2026 21:00	4,100.6	724.9	4,825.5	105,300.0	508.1	0.61	0.3	1.0
08/04/2026 22:00	3,453.9	1.3	3,453.9	105,300.0	363.7	0.43	0.2	0.7
08/04/2026 23:00	3,985.0	0.0	3,985.0	105,300.0	419.6	0.50	0.3	0.8
Average/Sum#:	3,772.9	309.8	4,079.1	105,300.0	429.5	0.51	0.2	0.9
Minimum:	3,346.7	0.0	3,346.7	105,300.0	352.4	0.42	0.2	0.7
Maximum:	4,243.5	1,492.0	5,701.0	105,300.0	600.3	0.72	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/05/2026 00:00	3,765.5	0.0	3,765.5	105,300.0	396.5	0.48	0.2	0.8
08/05/2026 01:00	3,373.1	0.0	3,373.1	105,300.0	355.2	0.43	0.2	0.7
08/05/2026 02:00	3,372.2	0.0	3,372.2	105,300.0	355.1	0.43	0.2	0.7
08/05/2026 03:00	3,372.3	0.0	3,372.3	105,300.0	355.1	0.43	0.2	0.7
08/05/2026 04:00	3,424.1	0.0	3,424.1	105,300.0	360.6	0.44	0.2	0.7
08/05/2026 05:00	3,376.0	0.0	3,376.0	105,300.0	355.5	0.43	0.2	0.7
08/05/2026 06:00	3,512.6	0.0	3,512.6	105,300.0	369.9	0.45	0.2	0.7
08/05/2026 07:00	3,383.8	0.0	3,383.8	105,300.0	356.3	0.43	0.2	0.7
08/05/2026 08:00	3,374.6	0.0	3,374.6	105,300.0	355.3	0.43	0.2	0.7
08/05/2026 09:00	3,373.8	0.0	3,373.8	105,300.0	355.3	0.43	0.2	0.7
08/05/2026 10:00	3,372.7	0.0	3,372.7	105,300.0	355.1	0.43	0.2	0.7
08/05/2026 11:00	3,381.7	0.0	3,381.7	105,300.0	356.1	0.43	0.2	0.7
08/05/2026 12:00	3,532.9	0.0	3,532.9	105,300.0	372.0	0.45	0.2	0.7
08/05/2026 13:00	3,666.2	0.0	3,666.2	105,300.0	386.1	0.46	0.2	0.8
08/05/2026 14:00	4,263.8	538.8	4,791.8	105,300.0	504.6	0.61	0.3	1.0
08/05/2026 15:00	4,241.5	589.9	4,831.4	105,300.0	508.7	0.61	0.3	1.0
08/05/2026 16:00	4,239.8	1,014.5	5,254.3	105,300.0	553.3	0.66	0.3	1.1
08/05/2026 17:00	4,245.8	828.6	5,074.4	105,300.0	534.3	0.64	0.3	1.1
08/05/2026 18:00	4,280.2	497.2	4,777.4	105,300.0	503.1	0.60	0.3	1.0
08/05/2026 19:00	4,129.5	709.1	4,838.6	105,300.0	509.5	0.61	0.3	1.0
08/05/2026 20:00	4,070.2	793.8	4,864.0	105,300.0	512.2	0.62	0.3	1.0
08/05/2026 21:00	4,161.8	620.2	4,782.0	105,300.0	503.5	0.60	0.3	1.0
08/05/2026 22:00	4,072.4	4.3	4,072.5	105,300.0	428.8	0.52	0.3	0.9
08/05/2026 23:00	3,927.4	0.0	3,927.4	105,300.0	413.6	0.49	0.2	0.8
Average/Sum#:	3,746.4	233.2	3,979.0	105,300.0	419.0	0.50	0.2	0.8
Minimum:	3,372.2	0.0	3,372.2	105,300.0	355.1	0.43	0.2	0.7
Maximum:	4,280.2	1,014.5	5,254.3	105,300.0	553.3	0.66	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/06/2026 00:00	3,487.2	0.0	3,487.2	105,300.0	367.2	0.44	0.2	0.7
08/06/2026 01:00	3,353.8	0.0	3,353.8	105,300.0	353.2	0.42	0.2	0.7
08/06/2026 02:00	3,354.8	0.0	3,354.8	105,300.0	353.3	0.42	0.2	0.7
08/06/2026 03:00	3,360.7	0.0	3,360.7	105,300.0	353.9	0.42	0.2	0.7
08/06/2026 04:00	3,399.0	0.0	3,399.0	105,300.0	357.9	0.43	0.2	0.7
08/06/2026 05:00	3,556.3	0.0	3,556.3	105,300.0	374.5	0.45	0.2	0.8
08/06/2026 06:00	3,370.4	0.0	3,370.4	105,300.0	354.9	0.43	0.2	0.7
08/06/2026 07:00	3,375.4	0.0	3,375.4	105,300.0	355.4	0.43	0.2	0.7
08/06/2026 08:00	3,365.6	0.0	3,365.6	105,300.0	354.4	0.43	0.2	0.7
08/06/2026 09:00	3,363.6	0.0	3,363.6	105,300.0	354.2	0.42	0.2	0.7
08/06/2026 10:00	3,365.8	0.0	3,365.8	105,300.0	354.4	0.43	0.2	0.7
08/06/2026 11:00	3,369.4	0.0	3,369.4	105,300.0	354.8	0.43	0.2	0.7
08/06/2026 12:00	3,369.6	0.0	3,369.6	105,300.0	354.8	0.43	0.2	0.7
08/06/2026 13:00	3,564.1	0.0	3,564.1	105,300.0	375.3	0.45	0.2	0.8
08/06/2026 14:00	3,803.1	1,213.8	4,980.5	105,300.0	524.4	0.63	0.3	1.1
08/06/2026 15:00	3,701.8	1,405.2	5,107.0	105,300.0	537.8	0.65	0.3	1.1
08/06/2026 16:00	3,795.9	1,457.8	5,253.7	105,300.0	553.2	0.67	0.3	1.1
08/06/2026 17:00	4,237.9	1,650.2	5,888.1	105,300.0	620.0	0.74	0.4	1.2
08/06/2026 18:00	4,279.3	1,369.3	5,648.6	105,300.0	594.8	0.71	0.4	1.2
08/06/2026 19:00	4,264.0	546.5	4,810.5	105,300.0	506.5	0.61	0.3	1.0
08/06/2026 20:00	4,053.3	867.2	4,920.5	105,300.0	518.1	0.62	0.3	1.0
08/06/2026 21:00	4,125.9	991.6	5,117.5	105,300.0	538.9	0.65	0.3	1.1
08/06/2026 22:00	4,067.9	4.4	4,068.0	105,300.0	428.4	0.51	0.3	0.9
08/06/2026 23:00	4,067.3	0.0	4,067.3	105,300.0	428.3	0.51	0.3	0.9
Average/Sum#:	3,668.8	396.1	4,063.2	105,300.0	427.9	0.51	0.3	0.9
Minimum:	3,353.8	0.0	3,353.8	105,300.0	353.2	0.42	0.2	0.7
Maximum:	4,279.3	1,650.2	5,888.1	105,300.0	620.0	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/07/2026 00:00	4,065.1	0.0	4,065.1	105,300.0	428.1	0.51	0.3	0.9
08/07/2026 01:00	4,065.2	0.0	4,065.2	105,300.0	428.1	0.51	0.3	0.9
08/07/2026 02:00	4,063.8	0.0	4,063.8	105,300.0	427.9	0.51	0.3	0.9
08/07/2026 03:00	3,579.1	0.0	3,579.1	105,300.0	376.9	0.45	0.2	0.8
08/07/2026 04:00	4,035.4	0.0	4,035.4	105,300.0	424.9	0.51	0.3	0.9
08/07/2026 05:00	4,059.8	0.0	4,059.8	105,300.0	427.5	0.51	0.3	0.9
08/07/2026 06:00	3,561.6	0.0	3,561.6	105,300.0	375.0	0.45	0.2	0.8
08/07/2026 07:00	3,379.5	0.0	3,379.5	105,300.0	355.9	0.43	0.2	0.7
08/07/2026 08:00	3,372.7	0.0	3,372.7	105,300.0	355.1	0.43	0.2	0.7
08/07/2026 09:00	3,369.6	0.0	3,369.6	105,300.0	354.8	0.43	0.2	0.7
08/07/2026 10:00	3,368.4	0.0	3,368.4	105,300.0	354.7	0.43	0.2	0.7
08/07/2026 11:00	3,650.5	0.0	3,650.5	105,300.0	384.4	0.46	0.2	0.8
08/07/2026 12:00	3,500.2	0.0	3,500.2	105,300.0	368.6	0.44	0.2	0.7
08/07/2026 13:00	3,932.8	1.3	3,932.8	105,300.0	414.1	0.50	0.2	0.8
08/07/2026 14:00	4,026.8	967.0	4,993.8	105,300.0	525.8	0.63	0.3	1.1
08/07/2026 15:00	3,696.8	1,489.2	5,186.0	105,300.0	546.1	0.65	0.3	1.1
08/07/2026 16:00	3,746.9	1,433.7	5,180.6	105,300.0	545.5	0.66	0.3	1.1
08/07/2026 17:00	4,219.0	1,001.1	5,220.1	105,300.0	549.7	0.66	0.3	1.1
08/07/2026 18:00	4,250.2	1,521.6	5,771.8	105,300.0	607.8	0.73	0.4	1.2
08/07/2026 19:00	4,276.2	795.1	5,071.3	105,300.0	534.0	0.64	0.3	1.1
08/07/2026 20:00	4,271.0	617.4	4,888.4	105,300.0	514.7	0.62	0.3	1.0
08/07/2026 21:00	4,170.3	767.8	4,938.1	105,300.0	520.0	0.62	0.3	1.0
08/07/2026 22:00	4,101.7	6.8	4,101.9	105,300.0	431.9	0.52	0.3	0.9
08/07/2026 23:00	4,181.9	0.0	4,181.9	105,300.0	440.4	0.53	0.3	0.9
Average/Sum#:	3,872.7	358.4	4,230.7	105,300.0	445.5	0.53	0.3	0.9
Minimum:	3,368.4	0.0	3,368.4	105,300.0	354.7	0.43	0.2	0.7
Maximum:	4,276.2	1,521.6	5,771.8	105,300.0	607.8	0.73	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/08/2026 00:00	4,179.5	0.0	4,179.5	105,300.0	440.1	0.53	0.3	0.9
08/08/2026 01:00	3,665.7	0.0	3,665.7	105,300.0	386.0	0.46	0.2	0.8
08/08/2026 02:00	3,376.2	0.0	3,376.2	105,300.0	355.5	0.43	0.2	0.7
08/08/2026 03:00	3,401.4	0.0	3,401.4	105,300.0	358.2	0.43	0.2	0.7
08/08/2026 04:00	4,030.6	0.0	4,030.6	105,300.0	424.4	0.51	0.3	0.8
08/08/2026 05:00	3,814.8	0.0	3,814.8	105,300.0	401.7	0.48	0.2	0.8
08/08/2026 06:00	3,390.2	0.0	3,390.2	105,300.0	357.0	0.43	0.2	0.7
08/08/2026 07:00	3,391.1	0.0	3,391.1	105,300.0	357.1	0.43	0.2	0.7
08/08/2026 08:00	3,406.1	0.0	3,406.1	105,300.0	358.7	0.43	0.2	0.7
08/08/2026 09:00	3,406.7	0.0	3,406.7	105,300.0	358.7	0.43	0.2	0.7
08/08/2026 10:00	3,400.0	0.0	3,400.0	105,300.0	358.0	0.43	0.2	0.7
08/08/2026 11:00	3,399.6	0.0	3,399.6	105,300.0	358.0	0.43	0.2	0.7
08/08/2026 12:00	3,398.7	0.0	3,398.7	105,300.0	357.9	0.43	0.2	0.7
08/08/2026 13:00	3,552.6	143.4	3,588.5	105,300.0	377.9	0.47	0.2	0.8
08/08/2026 14:00	3,767.9	1,440.6	5,208.5	105,300.0	548.5	0.66	0.3	1.1
08/08/2026 15:00	3,826.2	1,219.7	5,045.9	105,300.0	531.3	0.64	0.3	1.1
08/08/2026 16:00	4,178.5	694.4	4,872.9	105,300.0	513.1	0.62	0.3	1.0
08/08/2026 17:00	4,201.3	776.2	4,977.5	105,300.0	524.1	0.63	0.3	1.0
08/08/2026 18:00	4,228.0	672.5	4,900.5	105,300.0	516.0	0.62	0.3	1.0
08/08/2026 19:00	4,071.6	823.5	4,895.1	105,300.0	515.5	0.62	0.3	1.0
08/08/2026 20:00	4,087.7	778.3	4,866.0	105,300.0	512.4	0.61	0.3	1.0
08/08/2026 21:00	4,099.1	717.6	4,816.7	105,300.0	507.2	0.61	0.3	1.0
08/08/2026 22:00	4,085.5	6.5	4,085.7	105,300.0	430.2	0.52	0.3	0.9
08/08/2026 23:00	3,831.5	0.0	3,831.5	105,300.0	403.5	0.48	0.2	0.8
Average/Sum#:	3,757.9	303.0	4,056.2	105,300.0	427.1	0.51	0.2	0.8
Minimum:	3,376.2	0.0	3,376.2	105,300.0	355.5	0.43	0.2	0.7
Maximum:	4,228.0	1,440.6	5,208.5	105,300.0	548.5	0.66	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/09/2026 00:00	3,367.7	0.0	3,367.7	105,300.0	354.6	0.43	0.2	0.7
08/09/2026 01:00	3,367.6	0.0	3,367.6	105,300.0	354.6	0.43	0.2	0.7
08/09/2026 02:00	3,371.3	0.0	3,371.3	105,300.0	355.0	0.43	0.2	0.7
08/09/2026 03:00	3,371.3	0.0	3,371.3	105,300.0	355.0	0.43	0.2	0.7
08/09/2026 04:00	3,408.7	0.0	3,408.7	105,300.0	358.9	0.43	0.2	0.7
08/09/2026 05:00	3,789.3	0.0	3,789.3	105,300.0	399.0	0.48	0.2	0.8
08/09/2026 06:00	3,385.2	0.0	3,385.2	105,300.0	356.5	0.43	0.2	0.7
08/09/2026 07:00	3,389.0	0.0	3,389.0	105,300.0	356.9	0.43	0.2	0.7
08/09/2026 08:00	3,381.3	0.0	3,381.3	105,300.0	356.1	0.43	0.2	0.7
08/09/2026 09:00	3,376.0	0.0	3,376.0	105,300.0	355.5	0.43	0.2	0.7
08/09/2026 10:00	3,374.9	0.0	3,374.9	105,300.0	355.4	0.43	0.2	0.7
08/09/2026 11:00	3,379.6	0.0	3,379.6	105,300.0	355.9	0.43	0.2	0.7
08/09/2026 12:00	3,471.8	0.0	3,471.8	105,300.0	365.6	0.44	0.2	0.7
08/09/2026 13:00	3,998.5	0.0	3,998.5	105,300.0	421.0	0.51	0.3	0.8
08/09/2026 14:00	4,197.4	890.7	4,892.1	105,300.0	515.1	0.64	0.3	1.1
08/09/2026 15:00	4,138.0	1,593.9	5,731.9	105,300.0	603.6	0.72	0.4	1.2
08/09/2026 16:00	4,130.2	1,678.2	5,808.4	105,300.0	611.6	0.73	0.4	1.2
08/09/2026 17:00	4,157.8	1,484.8	5,642.6	105,300.0	594.2	0.71	0.4	1.2
08/09/2026 18:00	4,214.7	1,618.9	5,833.6	105,300.0	614.3	0.74	0.4	1.2
08/09/2026 19:00	4,187.7	647.3	4,835.0	105,300.0	509.1	0.61	0.3	1.0
08/09/2026 20:00	3,967.8	958.6	4,926.4	105,300.0	518.7	0.62	0.3	1.0
08/09/2026 21:00	4,097.5	747.4	4,830.0	105,300.0	508.6	0.61	0.3	1.0
08/09/2026 22:00	3,489.5	0.0	3,489.5	105,300.0	367.4	0.44	0.2	0.7
08/09/2026 23:00	3,357.9	0.0	3,357.9	105,300.0	353.6	0.42	0.2	0.7
Average/Sum#:	3,682.1	400.8	4,074.2	105,300.0	429.0	0.52	0.3	0.8
Minimum:	3,357.9	0.0	3,357.9	105,300.0	353.6	0.42	0.2	0.7
Maximum:	4,214.7	1,678.2	5,833.6	105,300.0	614.3	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/10/2026 00:00	3,362.0	0.0	3,362.0	105,300.0	354.0	0.42	0.2	0.7
08/10/2026 01:00	3,363.4	0.0	3,363.4	105,300.0	354.2	0.43	0.2	0.7
08/10/2026 02:00	3,363.1	0.0	3,363.1	105,300.0	354.1	0.42	0.2	0.7
08/10/2026 03:00	3,367.4	0.0	3,367.4	105,300.0	354.6	0.43	0.2	0.7
08/10/2026 04:00	3,733.0	0.0	3,733.0	105,300.0	393.1	0.47	0.2	0.8
08/10/2026 05:00	3,372.8	0.0	3,372.8	105,300.0	355.2	0.43	0.2	0.7
08/10/2026 06:00	3,695.9	0.0	3,695.9	105,300.0	389.2	0.47	0.2	0.8
08/10/2026 07:00	3,387.7	0.0	3,387.7	105,300.0	356.7	0.43	0.2	0.7
08/10/2026 08:00	3,377.7	0.0	3,377.7	105,300.0	355.7	0.43	0.2	0.7
08/10/2026 09:00	3,375.9	0.0	3,375.9	105,300.0	355.5	0.43	0.2	0.7
08/10/2026 10:00	3,375.6	0.0	3,375.6	105,300.0	355.5	0.43	0.2	0.7
08/10/2026 11:00	3,382.6	0.0	3,382.6	105,300.0	356.2	0.43	0.2	0.7
08/10/2026 12:00	3,561.3	0.0	3,561.3	105,300.0	375.0	0.45	0.2	0.7
08/10/2026 13:00	3,877.2	0.0	3,877.2	105,300.0	408.3	0.49	0.2	0.8
08/10/2026 14:00	3,776.3	5.1	3,776.5	105,300.0	397.7	0.48	0.2	0.8
08/10/2026 15:00	4,274.6	633.2	4,907.8	105,300.0	516.8	0.62	0.3	1.0
08/10/2026 16:00	4,262.6	1,272.7	5,535.3	105,300.0	582.9	0.70	0.3	1.2
08/10/2026 17:00	4,270.6	1,544.2	5,814.8	105,300.0	612.3	0.74	0.4	1.2
08/10/2026 18:00	4,290.7	1,338.3	5,629.0	105,300.0	592.7	0.71	0.4	1.2
08/10/2026 19:00	4,312.4	843.6	5,156.0	105,300.0	542.9	0.65	0.3	1.1
08/10/2026 20:00	4,339.2	513.4	4,852.6	105,300.0	511.0	0.61	0.3	1.0
08/10/2026 21:00	4,364.5	741.7	5,106.2	105,300.0	537.7	0.64	0.3	1.1
08/10/2026 22:00	4,094.6	2.4	4,094.6	105,300.0	431.2	0.52	0.3	0.9
08/10/2026 23:00	3,572.0	0.0	3,572.0	105,300.0	376.1	0.45	0.2	0.8
Average/Sum#:	3,756.4	287.3	4,043.4	105,300.0	425.8	0.51	0.2	0.9
Minimum:	3,362.0	0.0	3,362.0	105,300.0	354.0	0.42	0.2	0.7
Maximum:	4,364.5	1,544.2	5,814.8	105,300.0	612.3	0.74	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/11/2026 00:00	3,629.3	0.0	3,629.3	105,300.0	382.2	0.46	0.2	0.8
08/11/2026 01:00	3,381.9	0.0	3,381.9	105,300.0	356.1	0.43	0.2	0.7
08/11/2026 02:00	3,380.2	0.0	3,380.2	105,300.0	355.9	0.43	0.2	0.7
08/11/2026 03:00	3,381.7	0.0	3,381.7	105,300.0	356.1	0.43	0.2	0.7
08/11/2026 04:00	3,416.6	0.0	3,416.6	105,300.0	359.8	0.43	0.2	0.7
08/11/2026 05:00	3,626.9	0.0	3,626.9	105,300.0	381.9	0.46	0.2	0.8
08/11/2026 06:00	3,775.6	0.0	3,775.6	105,300.0	397.6	0.48	0.2	0.8
08/11/2026 07:00	3,397.2	0.0	3,397.2	105,300.0	357.7	0.43	0.2	0.7
08/11/2026 08:00	3,388.6	0.0	3,388.6	105,300.0	356.8	0.43	0.2	0.7
08/11/2026 09:00	3,388.0	0.0	3,388.0	105,300.0	356.8	0.43	0.2	0.7
08/11/2026 10:00	3,482.1	0.0	3,482.1	105,300.0	366.7	0.44	0.2	0.7
08/11/2026 11:00	4,083.8	0.0	4,083.8	105,300.0	430.0	0.52	0.3	0.9
08/11/2026 12:00	4,116.9	3.2	4,117.0	105,300.0	433.5	0.52	0.3	0.9
08/11/2026 13:00	4,341.2	773.1	5,114.3	105,300.0	538.5	0.65	0.3	1.1
08/11/2026 14:00	4,326.0	656.1	4,982.1	105,300.0	524.6	0.63	0.3	1.0
08/11/2026 15:00	4,307.4	628.4	4,935.8	105,300.0	519.7	0.62	0.3	1.0
08/11/2026 16:00	4,293.2	1,316.6	5,609.8	105,300.0	590.7	0.71	0.4	1.2
08/11/2026 17:00	4,309.8	1,683.0	5,992.8	105,300.0	631.0	0.76	0.4	1.3
08/11/2026 18:00	4,312.7	1,309.1	5,621.8	105,300.0	592.0	0.71	0.4	1.2
08/11/2026 19:00	4,334.0	1,256.6	5,590.6	105,300.0	588.7	0.71	0.4	1.2
08/11/2026 20:00	4,360.1	902.1	5,262.2	105,300.0	554.1	0.67	0.3	1.1
08/11/2026 21:00	4,093.0	2.4	4,093.0	105,300.0	431.0	0.52	0.3	0.9
08/11/2026 22:00	3,833.9	0.0	3,833.9	105,300.0	403.7	0.49	0.2	0.8
08/11/2026 23:00	3,447.6	0.0	3,447.6	105,300.0	363.0	0.44	0.2	0.7
Average/Sum#:	3,850.3	355.4	4,205.5	105,300.0	442.8	0.53	0.3	0.9
Minimum:	3,380.2	0.0	3,380.2	105,300.0	355.9	0.43	0.2	0.7
Maximum:	4,360.1	1,683.0	5,992.8	105,300.0	631.0	0.76	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT1 GasFlow, _CT, 100scfh	Unit CT1 GasFlow, _DB, 100scfh	Unit CT1 GasFlowTotal, 100scfh	Unit CT1 GCVGas, BtuPer100scf	Unit CT1 HI, MBtuPerHr	Unit CT1 PM10_Norm, LbPerHr	Unit CT1 SO2_Norm, LbPerHr	Unit CT1 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/12/2026 00:00	3,372.3	0.0	3,372.3	105,300.0	355.1	0.43	0.2	0.7
08/12/2026 01:00	3,373.6	0.0	3,373.6	105,300.0	355.2	0.43	0.2	0.7
08/12/2026 02:00	3,375.6	0.0	3,375.6	105,300.0	355.5	0.43	0.2	0.7
08/12/2026 03:00	3,376.4	0.0	3,376.4	105,300.0	355.5	0.43	0.2	0.7
08/12/2026 04:00	3,697.2	0.0	3,697.2	105,300.0	389.3	0.47	0.2	0.8
08/12/2026 05:00	3,997.7	0.0	3,997.7	105,300.0	421.0	0.51	0.3	0.8
08/12/2026 06:00	3,372.5	0.0	3,372.5	105,300.0	355.1	0.43	0.2	0.7
08/12/2026 07:00	3,380.3	0.0	3,380.3	105,300.0	355.9	0.43	0.2	0.7
08/12/2026 08:00	3,382.9	0.0	3,382.9	105,300.0	356.2	0.43	0.2	0.7
08/12/2026 09:00	3,379.6	0.0	3,379.6	105,300.0	355.9	0.43	0.2	0.7
08/12/2026 10:00	3,378.6	0.0	3,378.6	105,300.0	355.8	0.43	0.2	0.7
08/12/2026 11:00	3,387.3	0.0	3,387.3	105,300.0	356.7	0.43	0.2	0.7
08/12/2026 12:00	3,416.6	0.0	3,416.6	105,300.0	359.8	0.43	0.2	0.7
08/12/2026 13:00	4,303.7	457.5	4,747.5	105,300.0	499.9	0.60	0.3	1.0
08/12/2026 14:00	4,311.2	453.2	4,764.4	105,300.0	501.7	0.60	0.3	1.0
08/12/2026 15:00	4,304.5	439.2	4,743.7	105,300.0	499.5	0.60	0.3	1.0
08/12/2026 16:00	4,291.8	450.3	4,742.1	105,300.0	499.3	0.60	0.3	1.0
08/12/2026 17:00	4,314.9	411.4	4,726.3	105,300.0	497.7	0.60	0.3	1.0
08/12/2026 18:00	4,329.7	382.0	4,711.7	105,300.0	496.1	0.60	0.3	1.0
08/12/2026 19:00	4,357.3	320.4	4,677.7	105,300.0	492.6	0.59	0.3	1.0
08/12/2026 20:00	4,317.7	368.1	4,685.8	105,300.0	493.4	0.59	0.3	1.0
08/12/2026 21:00	3,524.1	8.5	3,524.5	105,300.0	371.1	0.44	0.2	0.7
08/12/2026 22:00	3,365.3	0.0	3,365.3	105,300.0	354.4	0.43	0.2	0.7
08/12/2026 23:00	3,365.4	0.0	3,365.4	105,300.0	354.4	0.43	0.2	0.7
Average/Sum#:	3,736.5	137.1	3,872.7	105,300.0	407.8	0.49	0.2	0.8
Minimum:	3,365.3	0.0	3,365.3	105,300.0	354.4	0.43	0.2	0.7
Maximum:	4,357.3	457.5	4,764.4	105,300.0	501.7	0.60	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00