DOCKETED	
Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	273239
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q3 2026 - Part 9s
Description:	N/A
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public Agency
Submission Date:	10/28/2026 7:52:54 AM
Docketed Date:	10/28/2026

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	NOx, Ppmvdc	NOx_Norm, LbPerHr	NOx_SUSD, LbPerHr	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/01/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/01/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	0.00	100.00	100.00	100.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/02/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/02/2026 23:00	0.0	0.0	6.9	17.4	17.0	209.6	0.35	0.35
Average/Sum#:	0.0	0.0	0.3	17.4	17.0	209.6	0.35 #	0.35 #
Minimum:	0.0	0.0	0.0	17.4	17.0	209.6	0.00	0.00
Maximum:	0.0	0.0	6.9	17.4	17.0	209.6	0.35	0.35
%SI	95.83	100.00	0.00	95.83	95.83	95.83	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/03/2026 00:00	1.5	1.9	3.6	3.4	14.2	373.6	0.72	1.00
07/03/2026 01:00	1.5	2.0	0.0	1.7	14.2	357.6	0.00	1.00
07/03/2026 02:00	1.5	2.0	0.0	1.7	14.2	355.9	0.00	1.00
07/03/2026 03:00	1.5	2.0	0.0	1.7	14.2	355.7	0.00	1.00
07/03/2026 04:00	1.5	2.0	1.1	4.6	14.7	295.2	0.18	0.35
07/03/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/03/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	1.5	2.0	0.2	2.6	14.3	347.6	0.90 #	4.35 #
Minimum:	1.5	1.9	0.0	1.7	14.2	295.2	0.00	0.00
Maximum:	1.5	2.0	3.6	4.6	14.7	373.6	0.72	1.00
%SI	79.17	79.17	8.33	79.17	79.17	79.17	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/04/2026 00:00	0.0	0.0	7.0	17.6	17.0	206.7	0.35	0.35
07/04/2026 01:00	1.4	1.9	3.0	3.0	14.2	371.3	0.67	1.00
07/04/2026 02:00	1.5	2.0	0.0	1.7	14.2	358.5	0.00	1.00
07/04/2026 03:00	1.5	1.9	0.0	1.7	14.2	355.2	0.00	1.00
07/04/2026 04:00	1.5	2.0	0.0	1.7	14.2	355.7	0.00	1.00
07/04/2026 05:00	1.5	2.0	1.1	4.9	14.8	289.2	0.18	0.33
07/04/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/04/2026 18:00	0.0	0.0	8.6	12.6	16.0	275.9	0.60	0.60
07/04/2026 19:00	1.4	2.6	1.7	2.2	13.8	456.7	0.47	1.00
07/04/2026 20:00	1.5	2.4	0.0	1.7	14.0	427.1	0.00	1.00
07/04/2026 21:00	1.5	2.0	0.0	1.7	14.3	355.1	0.00	1.00
07/04/2026 22:00	1.5	2.1	0.0	1.7	14.3	370.3	0.00	1.00
07/04/2026 23:00	1.5	2.2	0.0	1.6	14.4	412.7	0.00	1.00
Average/Sum#:	1.2	2.1	0.9	4.3	14.6	352.9	2.27 #	10.28 #
Minimum:	0.0	1.9	0.0	1.6	13.8	206.7	0.00	0.00
Maximum:	1.5	2.6	8.6	17.6	17.0	456.7	0.67	1.00
%SI	50.00	58.33	4.17	50.00	50.00	50.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/05/2026 00:00	1.5	2.1	1.1	3.0	14.5	341.9	0.18	0.77
07/05/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/05/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	1.5	2.1	0.0	3.0	14.5	341.9	0.18 #	0.77 #
Minimum:	1.5	2.1	0.0	3.0	14.5	341.9	0.00	0.00
Maximum:	1.5	2.1	1.1	3.0	14.5	341.9	0.18	0.77
%SI	95.83	95.83	0.00	95.83	95.83	95.83	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/06/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/06/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	0.00	100.00	100.00	100.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/07/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/07/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	0.00	100.00	100.00	100.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/08/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/08/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	0.00	100.00	100.00	100.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/09/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/09/2026 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.00 #	0.00 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
%SI	100.00	100.00	0.00	100.00	100.00	100.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/10/2026 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/10/2026 16:00	0.0	0.0	10.9	11.1	15.4	308.1	0.85	0.85
07/10/2026 17:00	1.4	2.7	0.2	1.7	13.7	486.7	0.13	1.00
07/10/2026 18:00	1.5	2.9	0.0	2.0	13.0	534.2	0.00	1.00
07/10/2026 19:00	1.5	2.9	0.0	2.0	13.2	524.2	0.00	1.00
07/10/2026 20:00	1.5	2.8	0.0	1.8	13.7	501.9	0.00	1.00
07/10/2026 21:00	1.5	2.8	0.0	1.8	13.8	498.3	0.00	1.00
07/10/2026 22:00	1.5	2.7	0.0	1.8	13.8	497.3	0.00	1.00
07/10/2026 23:00	1.5	2.8	0.0	1.8	13.9	495.6	0.00	1.00
Average/Sum#:	1.3	2.8	0.5	3.0	13.8	480.8	0.98 #	7.85 #
Minimum:	0.0	2.7	0.0	1.7	13.0	308.1	0.00	0.00
Maximum:	1.5	2.9	10.9	11.1	15.4	534.2	0.85	1.00
%SI	66.67	70.83	4.17	66.67	66.67	66.67	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/11/2026 00:00	1.5	2.7	0.0	1.8	13.9	493.5	0.00	1.00
07/11/2026 01:00	1.5	2.8	0.0	1.8	14.0	491.6	0.00	1.00
07/11/2026 02:00	1.5	2.7	0.0	1.8	14.0	489.2	0.00	1.00
07/11/2026 03:00	1.5	2.7	0.0	1.8	14.0	488.5	0.00	1.00
07/11/2026 04:00	1.5	2.5	0.0	1.7	14.1	450.3	0.00	1.00
07/11/2026 05:00	1.5	2.0	1.3	3.9	14.6	318.0	0.18	0.52
07/11/2026 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
07/11/2026 15:00	0.0	0.0	0.0	0.0	21.0	61.9	0.02	0.02
07/11/2026 16:00	1.5	2.1	8.7	8.0	15.1	317.6	0.82	1.00
07/11/2026 17:00	1.6	3.0	0.0	2.0	13.4	500.0	0.00	1.00
07/11/2026 18:00	1.5	2.8	0.0	1.9	13.6	507.6	0.00	1.00
07/11/2026 19:00	1.5	2.8	0.0	1.8	13.7	501.7	0.00	1.00
07/11/2026 20:00	1.5	2.8	0.0	1.9	13.5	508.6	0.00	1.00
07/11/2026 21:00	1.5	2.9	0.0	2.0	13.2	530.0	0.00	1.00
07/11/2026 22:00	1.5	2.8	0.0	1.9	13.6	506.5	0.00	1.00
07/11/2026 23:00	1.5	3.2	0.0	2.1	12.8	566.7	0.00	1.00
Average/Sum#:	1.4	2.7	0.4	2.3	14.3	448.8	1.02 #	13.54 #
Minimum:	0.0	2.0	0.0	0.0	12.8	61.9	0.00	0.00
Maximum:	1.6	3.2	8.7	8.0	21.0	566.7	0.82	1.00
%SI	37.50	41.67	4.17	37.50	37.50	37.50	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/12/2026 00:00	1.5	2.8	0.0	1.8	13.7	500.5	0.00	1.00
07/12/2026 01:00	1.5	2.7	0.0	1.8	13.7	498.2	0.00	1.00
07/12/2026 02:00	1.5	2.8	0.0	1.8	13.8	498.0	0.00	1.00
07/12/2026 03:00	1.5	2.8	0.0	1.8	13.8	498.4	0.00	1.00
07/12/2026 04:00	1.5	2.8	0.0	1.8	13.8	497.9	0.00	1.00
07/12/2026 05:00	1.5	2.8	0.0	1.8	13.8	497.1	0.00	1.00
07/12/2026 06:00	1.5	2.8	0.0	1.8	13.8	503.2	0.00	1.00
07/12/2026 07:00	1.5	3.2	0.0	2.0	12.9	562.2	0.00	1.00
07/12/2026 08:00	1.5	3.3	0.0	2.1	12.5	587.8	0.00	1.00
07/12/2026 09:00	1.5	2.8	0.0	1.9	13.5	517.8	0.00	1.00
07/12/2026 10:00	1.6	2.9	0.0	1.9	13.7	501.3	0.00	1.00
07/12/2026 11:00	1.7	3.1	0.0	2.1	13.6	507.4	0.00	1.00
07/12/2026 12:00	1.7	3.1	0.0	2.1	13.3	512.3	0.00	1.00
07/12/2026 13:00	1.8	3.7	0.0	2.5	12.6	561.8	0.00	1.00
07/12/2026 14:00	1.8	3.9	0.0	2.5	12.5	592.6	0.00	1.00
07/12/2026 15:00	1.6	3.6	0.0	2.3	12.0	624.9	0.00	1.00
07/12/2026 16:00	1.5	3.4	0.0	2.3	12.0	623.8	0.00	1.00
07/12/2026 17:00	1.5	3.1	0.0	2.0	13.0	552.7	0.00	1.00
07/12/2026 18:00	1.5	2.8	0.0	1.9	13.5	517.7	0.00	1.00
07/12/2026 19:00	1.5	3.5	0.0	2.3	12.2	614.9	0.00	1.00
07/12/2026 20:00	1.5	3.5	0.0	2.3	12.0	631.2	0.00	1.00
07/12/2026 21:00	1.5	3.5	0.0	2.3	12.0	628.5	0.00	1.00
07/12/2026 22:00	1.5	3.1	0.0	2.0	12.8	562.8	0.00	1.00
07/12/2026 23:00	1.5	2.0	0.0	1.7	14.3	377.0	0.00	1.00
Average/Sum#:	1.6	3.1	0.0	2.0	13.1	540.4	0.00 #	24.00 #
Minimum:	1.5	2.0	0.0	1.7	12.0	377.0	0.00	1.00
Maximum:	1.8	3.9	0.0	2.5	14.3	631.2	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/13/2026 00:00	1.5	2.2	0.0	1.7	14.3	389.0	0.00	1.00
07/13/2026 01:00	1.5	2.4	0.0	1.7	14.4	433.2	0.00	1.00
07/13/2026 02:00	1.5	2.5	0.0	1.7	14.4	433.4	0.00	1.00
07/13/2026 03:00	1.5	2.4	0.0	1.7	14.4	425.7	0.00	1.00
07/13/2026 04:00	1.5	2.4	0.0	1.7	14.4	432.0	0.00	1.00
07/13/2026 05:00	1.5	2.2	0.0	1.7	14.2	404.7	0.00	1.00
07/13/2026 06:00	1.5	2.4	0.0	1.7	14.3	432.0	0.00	1.00
07/13/2026 07:00	1.5	2.4	0.0	1.7	14.4	427.7	0.00	1.00
07/13/2026 08:00	1.5	3.2	0.0	2.1	12.8	558.7	0.00	1.00
07/13/2026 09:00	1.5	3.6	0.0	2.4	11.8	641.3	0.00	1.00
07/13/2026 10:00	1.5	3.5	0.0	2.3	11.8	637.3	0.00	1.00
07/13/2026 11:00	1.5	3.5	0.0	2.3	11.8	636.1	0.00	1.00
07/13/2026 12:00	1.5	3.5	0.0	2.3	11.8	635.2	0.00	1.00
07/13/2026 13:00	1.5	3.5	0.0	2.3	11.8	638.1	0.00	1.00
07/13/2026 14:00	1.5	3.5	0.0	2.3	11.8	636.5	0.00	1.00
07/13/2026 15:00	1.5	3.5	0.0	2.3	11.8	637.0	0.00	1.00
07/13/2026 16:00	1.5	3.6	0.0	2.3	11.8	636.3	0.00	1.00
07/13/2026 17:00	1.5	3.5	0.0	2.3	11.8	629.6	0.00	1.00
07/13/2026 18:00	1.5	3.5	0.0	2.3	11.9	628.6	0.00	1.00
07/13/2026 19:00	1.5	3.5	0.0	2.3	11.8	632.9	0.00	1.00
07/13/2026 20:00	1.5	3.5	0.0	2.3	11.9	629.6	0.00	1.00
07/13/2026 21:00	1.5	3.4	0.0	2.2	12.2	613.8	0.00	1.00
07/13/2026 22:00	1.5	2.9	0.0	1.9	13.3	536.0	0.00	1.00
07/13/2026 23:00	1.5	2.9	0.0	1.9	13.6	509.7	0.00	1.00
Average/Sum#:	1.5	3.1	0.0	2.1	12.9	550.6	0.00 #	24.00 #
Minimum:	1.5	2.2	0.0	1.7	11.8	389.0	0.00	1.00
Maximum:	1.5	3.6	0.0	2.4	14.4	641.3	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/14/2026 00:00	1.5	3.0	0.0	2.0	13.2	539.5	0.00	1.00
07/14/2026 01:00	1.5	2.8	0.0	1.8	13.7	501.4	0.00	1.00
07/14/2026 02:00	1.5	2.8	0.0	1.9	13.6	503.4	0.00	1.00
07/14/2026 03:00	1.5	2.8	0.0	1.8	13.7	500.5	0.00	1.00
07/14/2026 04:00	1.5	2.8	0.0	1.8	13.7	499.9	0.00	1.00
07/14/2026 05:00	1.5	3.0	0.0	1.9	13.3	530.6	0.00	1.00
07/14/2026 06:00	1.5	2.8	0.0	1.8	13.8	496.8	0.00	1.00
07/14/2026 07:00	1.5	2.8	0.0	1.8	13.7	501.9	0.00	1.00
07/14/2026 08:00	1.5	2.8	0.0	1.9	13.5	506.8	0.00	1.00
07/14/2026 09:00	1.5	2.9	0.0	2.0	13.1	514.8	0.00	1.00
07/14/2026 10:00	1.5	2.9	0.0	2.1	12.8	522.9	0.00	1.00
07/14/2026 11:00	1.5	3.0	0.0	2.1	12.5	533.3	0.00	1.00
07/14/2026 12:00	1.5	3.0	0.0	2.0	13.1	534.5	0.00	1.00
07/14/2026 13:00	1.5	3.2	0.0	2.1	12.8	565.4	0.00	1.00
07/14/2026 14:00	1.5	3.4	0.0	2.2	12.2	605.3	0.00	1.00
07/14/2026 15:00	1.5	3.5	0.0	2.3	11.9	621.8	0.00	1.00
07/14/2026 16:00	1.5	3.4	0.0	2.3	12.0	616.9	0.00	1.00
07/14/2026 17:00	1.5	3.5	0.0	2.3	11.9	627.0	0.00	1.00
07/14/2026 18:00	1.5	3.5	0.0	2.3	11.9	623.2	0.00	1.00
07/14/2026 19:00	1.5	3.3	0.0	2.2	12.1	605.1	0.00	1.00
07/14/2026 20:00	1.5	3.2	0.0	2.1	12.6	579.6	0.00	1.00
07/14/2026 21:00	1.5	3.3	0.0	2.2	12.4	590.4	0.00	1.00
07/14/2026 22:00	1.5	2.9	0.0	1.9	13.3	529.0	0.00	1.00
07/14/2026 23:00	1.5	2.7	0.0	1.8	13.8	494.0	0.00	1.00
Average/Sum#:	1.5	3.1	0.0	2.0	12.9	547.7	0.00 #	24.00 #
Minimum:	1.5	2.7	0.0	1.8	11.9	494.0	0.00	1.00
Maximum:	1.5	3.5	0.0	2.3	13.8	627.0	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/15/2026 00:00	1.5	2.8	0.0	1.9	13.6	497.9	0.00	1.00
07/15/2026 01:00	1.5	2.8	0.0	1.9	13.6	500.2	0.00	1.00
07/15/2026 02:00	1.5	2.7	0.0	1.8	13.6	497.2	0.00	1.00
07/15/2026 03:00	1.5	2.8	0.0	1.9	13.7	495.8	0.00	1.00
07/15/2026 04:00	1.5	2.7	0.0	1.8	13.7	495.7	0.00	1.00
07/15/2026 05:00	1.5	2.7	0.0	1.8	13.7	496.2	0.00	1.00
07/15/2026 06:00	1.5	2.8	0.0	1.8	13.7	500.2	0.00	1.00
07/15/2026 07:00	1.5	2.8	0.0	1.9	13.6	505.8	0.00	1.00
07/15/2026 08:00	1.5	2.8	0.0	1.9	13.3	511.1	0.00	1.00
07/15/2026 09:00	1.5	2.9	0.0	2.0	13.0	523.2	0.00	1.00
07/15/2026 10:00	1.6	3.5	0.0	2.4	11.9	620.8	0.00	1.00
07/15/2026 11:00	1.5	3.4	0.0	2.3	11.9	626.9	0.00	1.00
07/15/2026 12:00	1.5	3.2	0.0	2.1	12.6	575.0	0.00	1.00
07/15/2026 13:00	1.5	3.3	0.0	2.2	12.3	597.3	0.00	1.00
07/15/2026 14:00	1.5	3.6	0.0	2.4	11.7	637.0	0.00	1.00
07/15/2026 15:00	1.5	3.4	0.0	2.3	11.9	617.7	0.00	1.00
07/15/2026 16:00	1.5	3.6	0.0	2.4	11.7	638.6	0.00	1.00
07/15/2026 17:00	1.5	3.5	0.0	2.3	11.8	629.9	0.00	1.00
07/15/2026 18:00	1.5	3.5	0.0	2.3	11.8	633.3	0.00	1.00
07/15/2026 19:00	1.5	3.4	0.0	2.2	12.1	617.2	0.00	1.00
07/15/2026 20:00	1.5	3.3	0.0	2.2	12.4	596.7	0.00	1.00
07/15/2026 21:00	1.5	3.2	0.0	2.1	12.7	574.4	0.00	1.00
07/15/2026 22:00	1.5	2.9	0.0	1.9	13.3	522.6	0.00	1.00
07/15/2026 23:00	1.5	2.9	0.0	1.9	13.5	510.9	0.00	1.00
Average/Sum#:	1.5	3.1	0.0	2.1	12.8	559.2	0.00 #	24.00 #
Minimum:	1.5	2.7	0.0	1.8	11.7	495.7	0.00	1.00
Maximum:	1.6	3.6	0.0	2.4	13.7	638.6	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/16/2026 00:00	1.5	2.9	0.0	1.9	13.6	509.4	0.00	1.00
07/16/2026 01:00	1.5	2.8	0.0	1.8	13.7	503.8	0.00	1.00
07/16/2026 02:00	1.5	2.7	0.0	1.8	13.8	496.4	0.00	1.00
07/16/2026 03:00	1.5	2.8	0.0	1.8	13.9	494.2	0.00	1.00
07/16/2026 04:00	1.5	2.8	0.0	1.8	13.9	494.6	0.00	1.00
07/16/2026 05:00	1.5	2.8	0.0	1.8	13.9	494.6	0.00	1.00
07/16/2026 06:00	1.5	2.8	0.0	1.8	13.9	494.7	0.00	1.00
07/16/2026 07:00	1.5	2.8	0.0	1.8	13.8	498.6	0.00	1.00
07/16/2026 08:00	1.5	2.8	0.0	1.8	13.7	501.8	0.00	1.00
07/16/2026 09:00	1.5	2.8	0.0	1.9	13.6	504.8	0.00	1.00
07/16/2026 10:00	1.5	2.8	0.0	1.9	13.4	510.2	0.00	1.00
07/16/2026 11:00	1.5	2.9	0.0	2.0	13.2	518.8	0.00	1.00
07/16/2026 12:00	1.5	2.9	0.0	2.1	12.8	527.5	0.00	1.00
07/16/2026 13:00	1.5	3.0	0.0	2.1	12.6	532.0	0.00	1.00
07/16/2026 14:00	1.5	3.0	0.0	2.2	12.5	534.0	0.00	1.00
07/16/2026 15:00	1.5	3.0	0.0	2.2	12.3	535.1	0.00	1.00
07/16/2026 16:00	1.5	3.0	0.0	2.2	12.4	532.8	0.00	1.00
07/16/2026 17:00	1.5	3.0	0.0	2.1	12.6	532.4	0.00	1.00
07/16/2026 18:00	1.5	2.9	0.0	2.0	13.0	519.5	0.00	1.00
07/16/2026 19:00	1.5	2.8	0.0	1.9	13.4	507.5	0.00	1.00
07/16/2026 20:00	1.5	2.8	0.0	1.9	13.6	501.6	0.00	1.00
07/16/2026 21:00	1.5	2.8	0.0	1.8	13.7	499.2	0.00	1.00
07/16/2026 22:00	1.5	2.8	0.0	1.8	13.8	497.7	0.00	1.00
07/16/2026 23:00	1.5	2.8	0.0	1.8	13.9	495.5	0.00	1.00
Average/Sum#:	1.5	2.9	0.0	1.9	13.4	509.9	0.00 #	24.00 #
Minimum:	1.5	2.7	0.0	1.8	12.3	494.2	0.00	1.00
Maximum:	1.5	3.0	0.0	2.2	13.9	535.1	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/17/2026 00:00	1.5	2.8	0.0	1.8	13.9	494.7	0.00	1.00
07/17/2026 01:00	1.5	2.7	0.0	1.8	13.9	493.2	0.00	1.00
07/17/2026 02:00	1.5	2.7	0.0	1.7	13.9	493.2	0.00	1.00
07/17/2026 03:00	1.5	2.8	0.0	1.8	14.0	492.9	0.00	1.00
07/17/2026 04:00	1.5	2.7	0.0	1.8	14.0	491.2	0.00	1.00
07/17/2026 05:00	1.5	2.8	0.0	1.8	14.0	490.6	0.00	1.00
07/17/2026 06:00	1.5	2.8	0.0	1.8	14.0	493.0	0.00	1.00
07/17/2026 07:00	1.5	2.8	0.0	1.8	13.9	496.8	0.00	1.00
07/17/2026 08:00	1.5	2.8	0.0	1.8	13.8	500.0	0.00	1.00
07/17/2026 09:00	1.5	2.8	0.0	1.8	13.8	501.4	0.00	1.00
07/17/2026 10:00	1.5	2.8	0.0	1.8	13.7	504.8	0.00	1.00
07/17/2026 11:00	1.5	2.9	0.0	1.9	13.5	511.6	0.00	1.00
07/17/2026 12:00	1.5	2.9	0.0	2.0	13.2	519.2	0.00	1.00
07/17/2026 13:00	1.5	2.9	0.0	2.0	12.9	525.4	0.00	1.00
07/17/2026 14:00	1.5	2.9	0.0	2.1	12.6	528.9	0.00	1.00
07/17/2026 15:00	1.5	3.0	0.0	2.1	12.6	530.7	0.00	1.00
07/17/2026 16:00	1.5	2.9	0.0	2.1	12.6	530.1	0.00	1.00
07/17/2026 17:00	1.5	2.9	0.0	2.1	12.8	525.4	0.00	1.00
07/17/2026 18:00	1.5	2.9	0.0	2.0	13.3	514.5	0.00	1.00
07/17/2026 19:00	1.5	2.8	0.0	1.9	13.6	502.7	0.00	1.00
07/17/2026 20:00	1.5	2.8	0.0	1.8	13.8	496.9	0.00	1.00
07/17/2026 21:00	1.5	2.7	0.0	1.8	13.8	495.0	0.00	1.00
07/17/2026 22:00	1.5	2.7	0.0	1.8	13.9	493.1	0.00	1.00
07/17/2026 23:00	1.5	2.7	0.0	1.8	13.9	492.2	0.00	1.00
Average/Sum#:	1.5	2.8	0.0	1.9	13.6	504.9	0.00 #	24.00 #
Minimum:	1.5	2.7	0.0	1.7	12.6	490.6	0.00	1.00
Maximum:	1.5	3.0	0.0	2.1	14.0	530.7	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/18/2026 00:00	1.5	2.7	0.0	1.8	14.0	490.6	0.00	1.00
07/18/2026 01:00	1.5	2.7	0.0	1.8	14.0	488.7	0.00	1.00
07/18/2026 02:00	1.5	2.7	0.0	1.7	14.1	487.0	0.00	1.00
07/18/2026 03:00	1.5	2.7	0.0	1.8	14.1	487.3	0.00	1.00
07/18/2026 04:00	1.5	2.7	0.0	1.7	14.1	488.8	0.00	1.00
07/18/2026 05:00	1.5	2.8	0.0	1.8	13.9	503.8	0.00	1.00
07/18/2026 06:00	1.5	2.7	0.0	1.7	14.1	489.6	0.00	1.00
07/18/2026 07:00	1.5	2.7	0.0	1.7	14.1	490.5	0.00	1.00
07/18/2026 08:00	1.5	2.8	0.0	1.8	14.0	494.8	0.00	1.00
07/18/2026 09:00	1.5	2.8	0.0	1.8	13.9	498.4	0.00	1.00
07/18/2026 10:00	1.5	2.8	0.0	1.8	13.8	500.7	0.00	1.00
07/18/2026 11:00	1.5	2.4	0.0	1.7	14.0	431.0	0.00	1.00
07/18/2026 12:00	1.5	2.0	0.0	1.7	14.4	356.0	0.00	1.00
07/18/2026 13:00	1.5	2.2	0.0	1.7	14.4	378.4	0.00	1.00
07/18/2026 14:00	1.5	3.0	0.0	2.0	13.1	522.6	0.00	1.00
07/18/2026 15:00	1.5	2.9	0.0	2.0	12.9	525.2	0.00	1.00
07/18/2026 16:00	1.5	2.9	0.0	2.1	12.8	527.0	0.00	1.00
07/18/2026 17:00	1.5	2.9	0.0	2.1	12.8	526.1	0.00	1.00
07/18/2026 18:00	1.5	2.9	0.0	2.0	13.0	520.6	0.00	1.00
07/18/2026 19:00	1.5	2.8	0.0	1.9	13.5	509.2	0.00	1.00
07/18/2026 20:00	1.5	2.8	0.0	1.9	13.6	503.7	0.00	1.00
07/18/2026 21:00	1.5	2.8	0.0	1.9	13.7	502.1	0.00	1.00
07/18/2026 22:00	1.5	2.8	0.0	1.8	13.7	500.5	0.00	1.00
07/18/2026 23:00	1.5	2.8	0.0	1.8	13.8	498.8	0.00	1.00
Average/Sum#:	1.5	2.7	0.0	1.8	13.7	488.4	0.00 #	24.00 #
Minimum:	1.5	2.0	0.0	1.7	12.8	356.0	0.00	1.00
Maximum:	1.5	3.0	0.0	2.1	14.4	527.0	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/19/2026 00:00	1.5	2.8	0.0	1.8	13.8	496.5	0.00	1.00
07/19/2026 01:00	1.5	2.8	0.0	1.8	13.9	494.0	0.00	1.00
07/19/2026 02:00	1.5	2.8	0.0	1.8	13.9	492.3	0.00	1.00
07/19/2026 03:00	1.5	2.7	0.0	1.8	14.0	490.2	0.00	1.00
07/19/2026 04:00	1.5	2.7	0.0	1.8	14.0	488.1	0.00	1.00
07/19/2026 05:00	1.5	2.7	0.0	1.8	14.0	487.9	0.00	1.00
07/19/2026 06:00	1.5	2.7	0.0	1.8	14.0	490.2	0.00	1.00
07/19/2026 07:00	1.5	2.8	0.0	1.8	14.0	493.8	0.00	1.00
07/19/2026 08:00	1.5	2.8	0.0	1.8	13.9	497.0	0.00	1.00
07/19/2026 09:00	1.5	2.8	0.0	1.8	13.8	499.7	0.00	1.00
07/19/2026 10:00	1.5	2.8	0.0	1.8	13.7	505.5	0.00	1.00
07/19/2026 11:00	1.5	2.9	0.0	1.9	13.4	516.6	0.00	1.00
07/19/2026 12:00	1.5	2.9	0.0	2.0	13.0	524.2	0.00	1.00
07/19/2026 13:00	1.5	2.9	0.0	2.1	12.8	528.7	0.00	1.00
07/19/2026 14:00	1.5	3.0	0.0	2.1	12.7	532.1	0.00	1.00
07/19/2026 15:00	1.5	3.0	0.0	2.2	12.5	536.4	0.00	1.00
07/19/2026 16:00	1.5	3.0	0.0	2.2	12.5	539.7	0.00	1.00
07/19/2026 17:00	1.5	3.3	0.0	2.3	12.1	585.4	0.00	1.00
07/19/2026 18:00	1.5	3.2	0.0	2.1	12.5	592.0	0.00	1.00
07/19/2026 19:00	1.5	3.2	0.0	2.1	12.8	574.5	0.00	1.00
07/19/2026 20:00	1.5	3.5	0.0	2.3	12.2	621.5	0.00	1.00
07/19/2026 21:00	1.5	3.5	0.0	2.2	12.1	623.8	0.00	1.00
07/19/2026 22:00	1.5	3.4	0.0	2.2	12.2	618.2	0.00	1.00
07/19/2026 23:00	1.5	3.4	0.0	2.2	12.2	616.0	0.00	1.00
Average/Sum#:	1.5	3.0	0.0	2.0	13.2	535.2	0.00 #	24.00 #
Minimum:	1.5	2.7	0.0	1.8	12.1	487.9	0.00	1.00
Maximum:	1.5	3.5	0.0	2.3	14.0	623.8	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/20/2026 00:00	1.5	3.0	0.0	1.9	13.3	538.3	0.00	1.00
07/20/2026 01:00	1.5	2.8	0.0	1.8	13.8	497.4	0.00	1.00
07/20/2026 02:00	1.4	2.7	0.0	1.8	13.5	521.9	0.00	1.00
07/20/2026 03:00	1.6	3.6	0.0	2.3	12.1	622.8	0.00	1.00
07/20/2026 04:00	1.5	3.5	0.0	2.3	12.0	632.9	0.00	1.00
07/20/2026 05:00	1.5	3.5	0.0	2.3	12.0	630.0	0.00	1.00
07/20/2026 06:00	1.5	3.4	0.0	2.2	12.2	617.1	0.00	1.00
07/20/2026 07:00	1.5	3.3	0.0	2.2	12.4	603.9	0.00	1.00
07/20/2026 08:00	1.5	3.4	0.0	2.2	12.3	607.6	0.00	1.00
07/20/2026 09:00	1.5	3.2	0.0	2.1	12.6	586.8	0.00	1.00
07/20/2026 10:00	1.5	3.4	0.0	2.2	12.2	614.9	0.00	1.00
07/20/2026 11:00	1.5	3.4	0.0	2.2	12.3	609.1	0.00	1.00
07/20/2026 12:00	1.5	3.3	0.0	2.1	12.5	597.4	0.00	1.00
07/20/2026 13:00	1.5	3.5	0.0	2.3	12.2	617.8	0.00	1.00
07/20/2026 14:00	1.5	3.3	0.0	2.1	12.5	592.2	0.00	1.00
07/20/2026 15:00	1.5	3.3	0.0	2.2	12.5	593.2	0.00	1.00
07/20/2026 16:00	1.5	3.4	0.0	2.2	12.3	602.5	0.00	1.00
07/20/2026 17:00	1.5	3.4	0.0	2.2	12.4	601.5	0.00	1.00
07/20/2026 18:00	1.5	3.5	0.0	2.2	12.2	617.8	0.00	1.00
07/20/2026 19:00	1.5	3.4	0.0	2.2	12.4	606.3	0.00	1.00
07/20/2026 20:00	1.5	3.4	0.0	2.2	12.2	613.9	0.00	1.00
07/20/2026 21:00	1.5	3.3	0.0	2.2	12.5	598.1	0.00	1.00
07/20/2026 22:00	1.5	2.9	0.0	1.9	13.3	535.7	0.00	1.00
07/20/2026 23:00	1.5	3.1	0.0	2.0	12.9	550.2	0.00	1.00
Average/Sum#:	1.5	3.3	0.0	2.1	12.5	592.1	0.00 #	24.00 #
Minimum:	1.4	2.7	0.0	1.8	12.0	497.4	0.00	1.00
Maximum:	1.6	3.6	0.0	2.3	13.8	632.9	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/21/2026 00:00	1.5	2.8	0.0	1.9	13.6	502.9	0.00	1.00
07/21/2026 01:00	1.5	2.8	0.0	1.9	13.6	503.3	0.00	1.00
07/21/2026 02:00	1.5	2.9	0.0	1.9	13.6	503.2	0.00	1.00
07/21/2026 03:00	1.5	2.8	0.0	1.9	13.7	501.7	0.00	1.00
07/21/2026 04:00	1.5	2.9	0.0	1.9	13.4	526.4	0.00	1.00
07/21/2026 05:00	1.5	3.3	0.0	2.2	12.5	596.0	0.00	1.00
07/21/2026 06:00	1.5	3.0	0.0	2.0	13.1	542.7	0.00	1.00
07/21/2026 07:00	1.5	2.9	0.0	1.9	13.4	523.5	0.00	1.00
07/21/2026 08:00	1.5	3.0	0.0	2.0	13.2	537.8	0.00	1.00
07/21/2026 09:00	1.5	2.9	0.0	1.9	13.2	519.3	0.00	1.00
07/21/2026 10:00	1.5	3.0	0.0	2.1	12.7	530.7	0.00	1.00
07/21/2026 11:00	1.5	3.2	0.0	2.2	12.3	569.9	0.00	1.00
07/21/2026 12:00	1.5	3.5	0.0	2.3	12.0	625.2	0.00	1.00
07/21/2026 13:00	1.5	3.4	0.0	2.2	12.1	614.9	0.00	1.00
07/21/2026 14:00	1.5	3.5	0.0	2.3	12.0	620.7	0.00	1.00
07/21/2026 15:00	1.5	3.5	0.0	2.3	11.8	629.7	0.00	1.00
07/21/2026 16:00	1.5	3.4	0.0	2.3	12.0	617.3	0.00	1.00
07/21/2026 17:00	1.5	3.5	0.0	2.3	11.9	626.4	0.00	1.00
07/21/2026 18:00	1.5	3.6	0.0	2.4	11.7	638.9	0.00	1.00
07/21/2026 19:00	1.5	3.5	0.0	2.3	11.7	636.7	0.00	1.00
07/21/2026 20:00	1.5	3.5	0.0	2.3	11.9	630.5	0.00	1.00
07/21/2026 21:00	1.5	3.4	0.0	2.2	12.1	617.8	0.00	1.00
07/21/2026 22:00	1.5	3.3	0.0	2.2	12.3	602.7	0.00	1.00
07/21/2026 23:00	1.5	3.3	0.0	2.1	12.5	589.5	0.00	1.00
Average/Sum#:	1.5	3.2	0.0	2.1	12.6	575.3	0.00 #	24.00 #
Minimum:	1.5	2.8	0.0	1.9	11.7	501.7	0.00	1.00
Maximum:	1.5	3.6	0.0	2.4	13.7	638.9	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/22/2026 00:00	1.5	2.8	0.0	1.8	13.7	496.7	0.00	1.00
07/22/2026 01:00	1.5	2.8	0.0	1.8	13.7	497.3	0.00	1.00
07/22/2026 02:00	1.5	2.8	0.0	1.8	13.7	495.5	0.00	1.00
07/22/2026 03:00	1.5	2.8	0.0	1.8	13.8	494.0	0.00	1.00
07/22/2026 04:00	1.5	2.8	0.0	1.8	13.7	499.4	0.00	1.00
07/22/2026 05:00	1.5	2.9	0.0	1.9	13.3	528.2	0.00	1.00
07/22/2026 06:00	1.5	2.7	0.0	1.8	13.8	495.1	0.00	1.00
07/22/2026 07:00	1.5	2.8	0.0	1.9	13.7	508.8	0.00	1.00
07/22/2026 08:00	1.5	3.0	0.0	2.0	13.1	546.0	0.00	1.00
07/22/2026 09:00	1.5	2.8	0.0	1.8	13.7	498.3	0.00	1.00
07/22/2026 10:00	1.5	2.8	0.0	1.9	13.7	501.4	0.00	1.00
07/22/2026 11:00	1.5	2.8	0.0	1.9	13.6	505.7	0.00	1.00
07/22/2026 12:00	1.5	2.8	0.0	1.9	13.5	508.4	0.00	1.00
07/22/2026 13:00	1.5	2.8	0.0	1.9	13.4	511.4	0.00	1.00
07/22/2026 14:00	1.5	2.9	0.0	2.0	13.2	514.2	0.00	1.00
07/22/2026 15:00	1.5	2.9	0.0	2.0	13.2	515.1	0.00	1.00
07/22/2026 16:00	1.5	2.9	0.0	2.0	13.1	514.3	0.00	1.00
07/22/2026 17:00	1.5	2.8	0.0	2.0	13.2	512.7	0.00	1.00
07/22/2026 18:00	1.5	2.8	0.0	1.9	13.4	507.1	0.00	1.00
07/22/2026 19:00	1.5	2.8	0.0	1.9	13.6	499.4	0.00	1.00
07/22/2026 20:00	1.5	2.7	0.0	1.8	13.8	493.2	0.00	1.00
07/22/2026 21:00	1.5	2.7	0.0	1.8	13.8	489.7	0.00	1.00
07/22/2026 22:00	1.5	2.7	0.0	1.8	13.9	488.5	0.00	1.00
07/22/2026 23:00	1.5	2.7	0.0	1.8	13.9	486.9	0.00	1.00
Average/Sum#:	1.5	2.8	0.0	1.9	13.6	504.5	0.00 #	24.00 #
Minimum:	1.5	2.7	0.0	1.8	13.1	486.9	0.00	1.00
Maximum:	1.5	3.0	0.0	2.0	13.9	546.0	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/23/2026 00:00	1.5	2.7	0.0	1.8	14.0	485.9	0.00	1.00
07/23/2026 01:00	1.5	2.7	0.0	1.8	14.0	486.0	0.00	1.00
07/23/2026 02:00	1.5	2.7	0.0	1.8	14.0	484.2	0.00	1.00
07/23/2026 03:00	1.5	2.7	0.0	1.8	14.0	484.6	0.00	1.00
07/23/2026 04:00	1.5	2.7	0.0	1.8	14.0	486.1	0.00	1.00
07/23/2026 05:00	1.5	2.7	0.0	1.8	14.0	486.9	0.00	1.00
07/23/2026 06:00	1.5	2.8	0.0	1.8	14.0	489.5	0.00	1.00
07/23/2026 07:00	1.5	2.8	0.0	1.8	13.9	493.1	0.00	1.00
07/23/2026 08:00	1.5	2.6	0.0	1.7	14.0	473.2	0.00	1.00
07/23/2026 09:00	1.5	1.9	0.0	1.7	14.2	357.4	0.00	1.00
07/23/2026 10:00	1.5	2.0	0.0	1.7	14.3	354.8	0.00	1.00
07/23/2026 11:00	1.6	2.7	0.0	1.9	14.0	438.7	0.00	1.00
07/23/2026 12:00	1.5	2.9	0.0	1.9	13.3	516.5	0.00	1.00
07/23/2026 13:00	1.5	2.9	0.0	2.0	13.1	521.2	0.00	1.00
07/23/2026 14:00	1.5	2.9	0.0	2.0	13.0	523.2	0.00	1.00
07/23/2026 15:00	1.5	2.9	0.0	2.1	12.8	525.2	0.00	1.00
07/23/2026 16:00	1.5	2.9	0.0	2.1	12.8	526.2	0.00	1.00
07/23/2026 17:00	1.5	2.9	0.0	2.1	12.8	528.1	0.00	1.00
07/23/2026 18:00	1.5	3.0	0.0	2.1	12.6	543.7	0.00	1.00
07/23/2026 19:00	1.5	2.8	0.0	1.9	13.3	515.7	0.00	1.00
07/23/2026 20:00	1.5	2.9	0.0	2.0	13.3	527.0	0.00	1.00
07/23/2026 21:00	1.5	2.8	0.0	1.8	13.7	500.2	0.00	1.00
07/23/2026 22:00	1.5	2.8	0.0	1.8	13.7	501.3	0.00	1.00
07/23/2026 23:00	1.5	2.8	0.0	1.8	13.7	503.2	0.00	1.00
Average/Sum#:	1.5	2.7	0.0	1.9	13.6	489.7	0.00 #	24.00 #
Minimum:	1.5	1.9	0.0	1.7	12.6	354.8	0.00	1.00
Maximum:	1.6	3.0	0.0	2.1	14.3	543.7	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/24/2026 00:00	1.5	2.7	0.0	1.8	13.9	492.0	0.00	1.00
07/24/2026 01:00	1.5	2.7	0.0	1.8	13.9	491.4	0.00	1.00
07/24/2026 02:00	1.5	2.7	0.0	1.8	13.9	490.6	0.00	1.00
07/24/2026 03:00	1.5	2.7	0.0	1.8	14.0	489.7	0.00	1.00
07/24/2026 04:00	1.5	2.7	0.0	1.8	14.0	487.9	0.00	1.00
07/24/2026 05:00	1.5	2.8	0.0	1.8	14.0	489.0	0.00	1.00
07/24/2026 06:00	1.5	2.8	0.0	1.8	13.9	491.9	0.00	1.00
07/24/2026 07:00	1.5	2.8	0.0	1.8	13.9	496.3	0.00	1.00
07/24/2026 08:00	1.5	2.8	0.0	1.8	13.8	499.7	0.00	1.00
07/24/2026 09:00	1.5	2.8	0.0	1.8	13.7	503.8	0.00	1.00
07/24/2026 10:00	1.5	2.8	0.0	1.9	13.5	508.4	0.00	1.00
07/24/2026 11:00	1.5	2.0	0.0	1.6	14.3	362.5	0.00	1.00
07/24/2026 12:00	1.6	2.8	0.0	1.9	13.7	458.1	0.00	1.00
07/24/2026 13:00	1.5	3.3	0.0	2.2	12.2	583.2	0.00	1.00
07/24/2026 14:00	1.5	3.6	0.0	2.3	11.9	631.3	0.00	1.00
07/24/2026 15:00	1.5	3.5	0.0	2.3	11.9	628.4	0.00	1.00
07/24/2026 16:00	1.5	3.1	0.0	2.1	12.7	565.9	0.00	1.00
07/24/2026 17:00	1.5	3.3	0.0	2.2	12.6	581.4	0.00	1.00
07/24/2026 18:00	1.5	3.2	0.0	2.1	12.5	593.7	0.00	1.00
07/24/2026 19:00	1.5	2.9	0.0	1.9	13.4	523.1	0.00	1.00
07/24/2026 20:00	1.5	2.9	0.0	1.9	13.4	524.8	0.00	1.00
07/24/2026 21:00	1.5	2.8	0.0	1.8	13.7	504.9	0.00	1.00
07/24/2026 22:00	1.5	2.7	0.0	1.8	14.0	490.1	0.00	1.00
07/24/2026 23:00	1.5	2.8	0.0	1.8	13.9	493.7	0.00	1.00
Average/Sum#:	1.5	2.9	0.0	1.9	13.4	515.9	0.00 #	24.00 #
Minimum:	1.5	2.0	0.0	1.6	11.9	362.5	0.00	1.00
Maximum:	1.6	3.6	0.0	2.3	14.3	631.3	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/25/2026 00:00	1.5	2.7	0.0	1.8	13.9	492.4	0.00	1.00
07/25/2026 01:00	1.5	2.7	0.0	1.8	13.9	491.2	0.00	1.00
07/25/2026 02:00	1.5	2.7	0.0	1.8	13.9	490.5	0.00	1.00
07/25/2026 03:00	1.5	2.7	0.0	1.8	14.0	489.7	0.00	1.00
07/25/2026 04:00	1.5	2.7	0.0	1.8	14.0	488.6	0.00	1.00
07/25/2026 05:00	1.5	2.7	0.0	1.8	14.0	488.5	0.00	1.00
07/25/2026 06:00	1.5	2.7	0.0	1.8	13.9	492.2	0.00	1.00
07/25/2026 07:00	1.5	2.8	0.0	1.8	13.9	496.4	0.00	1.00
07/25/2026 08:00	1.5	2.8	0.0	1.8	13.8	498.8	0.00	1.00
07/25/2026 09:00	1.5	2.8	0.0	1.8	13.7	503.7	0.00	1.00
07/25/2026 10:00	1.5	2.8	0.0	1.9	13.6	509.0	0.00	1.00
07/25/2026 11:00	1.5	2.9	0.0	1.9	13.3	517.1	0.00	1.00
07/25/2026 12:00	1.5	2.9	0.0	2.0	13.0	525.2	0.00	1.00
07/25/2026 13:00	1.5	2.9	0.0	2.1	12.8	530.1	0.00	1.00
07/25/2026 14:00	1.5	3.0	0.0	2.1	12.6	533.0	0.00	1.00
07/25/2026 15:00	1.5	3.0	0.0	2.2	12.5	533.8	0.00	1.00
07/25/2026 16:00	1.5	3.0	0.0	2.2	12.4	536.5	0.00	1.00
07/25/2026 17:00	1.5	3.0	0.0	2.2	12.4	535.2	0.00	1.00
07/25/2026 18:00	1.5	2.9	0.0	2.1	12.8	525.7	0.00	1.00
07/25/2026 19:00	1.5	2.9	0.0	2.0	13.2	513.0	0.00	1.00
07/25/2026 20:00	1.5	2.8	0.0	1.9	13.5	504.3	0.00	1.00
07/25/2026 21:00	1.5	2.8	0.0	1.9	13.6	499.4	0.00	1.00
07/25/2026 22:00	1.5	2.8	0.0	1.8	13.7	497.3	0.00	1.00
07/25/2026 23:00	1.5	2.8	0.0	1.8	13.8	495.3	0.00	1.00
Average/Sum#:	1.5	2.8	0.0	1.9	13.4	507.8	0.00 #	24.00 #
Minimum:	1.5	2.7	0.0	1.8	12.4	488.5	0.00	1.00
Maximum:	1.5	3.0	0.0	2.2	14.0	536.5	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/26/2026 00:00	1.5	2.7	0.0	1.8	13.8	494.8	0.00	1.00
07/26/2026 01:00	1.5	2.8	0.0	1.8	13.9	492.7	0.00	1.00
07/26/2026 02:00	1.5	2.7	0.0	1.8	13.9	490.0	0.00	1.00
07/26/2026 03:00	1.5	2.7	0.0	1.8	14.0	489.1	0.00	1.00
07/26/2026 04:00	1.5	2.7	0.0	1.8	14.0	488.9	0.00	1.00
07/26/2026 05:00	1.5	2.7	0.0	1.8	14.0	488.7	0.00	1.00
07/26/2026 06:00	1.5	2.8	0.0	1.8	14.0	490.2	0.00	1.00
07/26/2026 07:00	1.5	1.9	0.0	1.7	14.2	361.7	0.00	1.00
07/26/2026 08:00	1.5	2.6	0.0	1.8	14.1	439.6	0.00	1.00
07/26/2026 09:00	1.5	2.8	0.0	1.8	13.7	502.7	0.00	1.00
07/26/2026 10:00	1.5	2.8	0.0	1.9	13.6	507.6	0.00	1.00
07/26/2026 11:00	1.5	2.8	0.0	1.9	13.4	513.3	0.00	1.00
07/26/2026 12:00	1.5	2.9	0.0	2.0	13.1	522.1	0.00	1.00
07/26/2026 13:00	1.5	3.0	0.0	2.1	12.8	528.5	0.00	1.00
07/26/2026 14:00	1.5	3.0	0.0	2.1	12.6	532.3	0.00	1.00
07/26/2026 15:00	1.5	3.0	0.0	2.1	12.5	532.5	0.00	1.00
07/26/2026 16:00	1.5	3.0	0.0	2.1	12.5	532.9	0.00	1.00
07/26/2026 17:00	1.5	2.9	0.0	2.1	12.5	531.3	0.00	1.00
07/26/2026 18:00	1.5	2.9	0.0	2.0	13.0	521.2	0.00	1.00
07/26/2026 19:00	1.5	2.8	0.0	1.9	13.4	509.4	0.00	1.00
07/26/2026 20:00	1.5	2.8	0.0	1.9	13.5	510.0	0.00	1.00
07/26/2026 21:00	1.5	3.1	0.0	2.0	13.0	555.0	0.00	1.00
07/26/2026 22:00	1.5	3.1	0.0	2.0	13.0	550.8	0.00	1.00
07/26/2026 23:00	1.5	2.7	0.0	1.8	13.9	492.1	0.00	1.00
Average/Sum#:	1.5	2.8	0.0	1.9	13.4	503.2	0.00 #	24.00 #
Minimum:	1.5	1.9	0.0	1.7	12.5	361.7	0.00	1.00
Maximum:	1.5	3.1	0.0	2.1	14.2	555.0	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/27/2026 00:00	1.5	2.8	0.0	1.8	13.7	506.5	0.00	1.00
07/27/2026 01:00	1.5	2.7	0.0	1.8	14.0	488.3	0.00	1.00
07/27/2026 02:00	1.5	2.7	0.0	1.8	14.0	487.0	0.00	1.00
07/27/2026 03:00	1.5	2.7	0.0	1.8	14.0	486.8	0.00	1.00
07/27/2026 04:00	1.5	2.7	0.0	1.7	14.0	485.6	0.00	1.00
07/27/2026 05:00	1.5	2.7	0.0	1.7	14.1	484.5	0.00	1.00
07/27/2026 06:00	1.5	2.7	0.0	1.8	14.0	488.1	0.00	1.00
07/27/2026 07:00	1.5	2.8	0.0	1.8	13.9	492.4	0.00	1.00
07/27/2026 08:00	1.5	2.8	0.0	1.8	13.9	495.5	0.00	1.00
07/27/2026 09:00	1.5	2.8	0.0	1.9	13.7	500.4	0.00	1.00
07/27/2026 10:00	1.5	2.8	0.0	1.9	13.6	504.1	0.00	1.00
07/27/2026 11:00	1.5	2.9	0.0	1.9	13.5	512.8	0.00	1.00
07/27/2026 12:00	1.5	2.9	0.0	1.9	13.3	520.9	0.00	1.00
07/27/2026 13:00	1.5	3.0	0.0	2.1	12.9	526.4	0.00	1.00
07/27/2026 14:00	1.5	2.9	0.0	2.1	12.9	529.6	0.00	1.00
07/27/2026 15:00	1.5	3.0	0.0	2.1	12.7	530.0	0.00	1.00
07/27/2026 16:00	1.5	3.0	0.0	2.1	12.6	531.8	0.00	1.00
07/27/2026 17:00	1.5	2.9	0.0	2.0	12.8	532.7	0.00	1.00
07/27/2026 18:00	1.5	3.2	0.0	2.1	12.9	558.1	0.00	1.00
07/27/2026 19:00	1.5	3.1	0.0	2.0	12.8	564.2	0.00	1.00
07/27/2026 20:00	1.5	2.9	0.0	1.9	13.3	530.8	0.00	1.00
07/27/2026 21:00	1.5	2.8	0.0	1.8	13.8	496.7	0.00	1.00
07/27/2026 22:00	1.5	2.7	0.0	1.8	13.8	494.6	0.00	1.00
07/27/2026 23:00	1.5	2.7	0.0	1.8	13.9	493.0	0.00	1.00
Average/Sum#:	1.5	2.8	0.0	1.9	13.5	510.0	0.00 #	24.00 #
Minimum:	1.5	2.7	0.0	1.7	12.6	484.5	0.00	1.00
Maximum:	1.5	3.2	0.0	2.1	14.1	564.2	0.00	1.00
%SI	0.00	0.00	25.00	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/28/2026 00:00	1.5	2.7	0.0	1.8	13.9	492.3	0.00	1.00
07/28/2026 01:00	1.5	2.7	0.0	1.8	13.9	489.7	0.00	1.00
07/28/2026 02:00	1.5	2.7	0.0	1.8	14.0	490.1	0.00	1.00
07/28/2026 03:00	1.5	2.7	0.0	1.8	14.0	488.7	0.00	1.00
07/28/2026 04:00	1.5	2.7	0.0	1.8	14.0	488.8	0.00	1.00
07/28/2026 05:00	1.5	2.7	0.0	1.8	14.0	488.0	0.00	1.00
07/28/2026 06:00	1.5	2.8	0.0	1.8	14.0	490.7	0.00	1.00
07/28/2026 07:00	1.5	2.2	0.0	1.7	14.2	402.9	0.00	1.00
07/28/2026 08:00	1.5	2.0	0.0	1.7	14.2	355.7	0.00	1.00
07/28/2026 09:00	1.6	2.0	0.0	1.7	14.3	355.4	0.00	1.00
07/28/2026 10:00	1.5	2.0	0.0	1.7	14.3	355.0	0.00	1.00
07/28/2026 11:00	1.5	2.1	0.0	1.7	14.4	381.3	0.00	1.00
07/28/2026 12:00	1.5	2.8	0.0	1.9	13.6	482.1	0.00	1.00
07/28/2026 13:00	1.5	2.0	0.0	1.7	14.4	358.1	0.00	1.00
07/28/2026 14:00	1.5	2.0	0.0	1.7	14.4	356.2	0.00	1.00
07/28/2026 15:00	1.5	2.2	0.0	1.7	14.4	380.2	0.00	1.00
07/28/2026 16:00	1.5	2.8	0.0	1.9	13.6	505.7	0.00	1.00
07/28/2026 17:00	1.5	2.8	0.0	1.9	13.6	507.6	0.00	1.00
07/28/2026 18:00	1.5	2.9	0.0	2.0	13.0	521.6	0.00	1.00
07/28/2026 19:00	1.5	2.9	0.0	2.0	13.2	515.7	0.00	1.00
07/28/2026 20:00	1.5	2.8	0.0	1.9	13.5	507.6	0.00	1.00
07/28/2026 21:00	1.5	2.8	0.0	1.9	13.5	503.2	0.00	1.00
07/28/2026 22:00	1.5	2.8	0.0	1.9	13.6	499.8	0.00	1.00
07/28/2026 23:00	1.5	1.9	0.0	1.7	14.2	362.6	0.00	1.00
Average/Sum#:	1.5	2.5	0.0	1.8	13.9	449.1	0.00 #	24.00 #
Minimum:	1.5	1.9	0.0	1.7	13.0	355.0	0.00	1.00
Maximum:	1.6	2.9	0.0	2.0	14.4	521.6	0.00	1.00
%SI	0.00	0.00	12.50	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/29/2026 00:00	1.5	2.0	0.0	1.7	14.2	353.8	0.00	1.00
07/29/2026 01:00	1.5	2.0	0.0	1.7	14.2	353.9	0.00	1.00
07/29/2026 02:00	1.5	2.0	0.0	1.7	14.2	354.4	0.00	1.00
07/29/2026 03:00	1.5	2.0	0.0	1.7	14.2	354.8	0.00	1.00
07/29/2026 04:00	1.5	2.0	0.0	1.7	14.2	354.7	0.00	1.00
07/29/2026 05:00	1.5	2.0	0.0	1.7	14.2	354.7	0.00	1.00
07/29/2026 06:00	1.5	2.0	0.0	1.7	14.2	354.8	0.00	1.00
07/29/2026 07:00	1.5	2.0	0.0	1.7	14.2	355.2	0.00	1.00
07/29/2026 08:00	1.5	2.0	0.0	1.7	14.3	354.3	0.00	1.00
07/29/2026 09:00	1.5	2.0	0.0	1.7	14.3	354.5	0.00	1.00
07/29/2026 10:00	1.5	2.2	0.0	1.7	14.4	379.0	0.00	1.00
07/29/2026 11:00	1.5	2.9	0.0	2.0	13.3	520.0	0.00	1.00
07/29/2026 12:00	1.5	2.9	0.0	2.0	12.9	524.8	0.00	1.00
07/29/2026 13:00	1.5	3.0	0.0	2.1	12.5	531.6	0.00	1.00
07/29/2026 14:00	1.5	3.0	0.0	2.2	12.4	534.2	0.00	1.00
07/29/2026 15:00	1.5	3.0	0.0	2.2	12.3	537.1	0.00	1.00
07/29/2026 16:00	1.5	3.0	0.0	2.2	12.2	537.9	0.00	1.00
07/29/2026 17:00	1.5	3.0	0.0	2.2	12.2	541.0	0.00	1.00
07/29/2026 18:00	1.5	3.0	0.0	2.2	12.4	541.8	0.00	1.00
07/29/2026 19:00	1.5	2.9	0.0	2.1	12.8	520.2	0.00	1.00
07/29/2026 20:00	1.5	2.8	0.0	2.0	13.3	508.5	0.00	1.00
07/29/2026 21:00	1.5	2.0	0.0	1.6	14.3	362.0	0.00	1.00
07/29/2026 22:00	1.5	2.0	0.0	1.7	14.3	353.2	0.00	1.00
07/29/2026 23:00	1.5	2.0	0.0	1.7	14.3	353.7	0.00	1.00
Average/Sum#:	1.5	2.4	0.0	1.9	13.6	428.8	0.00 #	24.00 #
Minimum:	1.5	2.0	0.0	1.6	12.2	353.2	0.00	1.00
Maximum:	1.5	3.0	0.0	2.2	14.4	541.8	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/30/2026 00:00	1.5	2.0	0.0	1.7	14.3	354.0	0.00	1.00
07/30/2026 01:00	1.5	2.0	0.0	1.7	14.3	354.0	0.00	1.00
07/30/2026 02:00	1.5	2.0	0.0	1.7	14.3	354.0	0.00	1.00
07/30/2026 03:00	1.5	2.0	0.0	1.7	14.2	354.4	0.00	1.00
07/30/2026 04:00	1.5	2.0	0.0	1.7	14.2	354.5	0.00	1.00
07/30/2026 05:00	1.5	2.0	0.0	1.7	14.2	354.3	0.00	1.00
07/30/2026 06:00	1.5	2.0	0.0	1.7	14.2	354.5	0.00	1.00
07/30/2026 07:00	1.5	2.0	0.0	1.7	14.3	355.1	0.00	1.00
07/30/2026 08:00	1.5	2.0	0.0	1.7	14.3	353.8	0.00	1.00
07/30/2026 09:00	1.5	2.0	0.0	1.7	14.3	353.7	0.00	1.00
07/30/2026 10:00	1.5	2.0	0.0	1.7	14.3	353.5	0.00	1.00
07/30/2026 11:00	1.5	2.0	0.0	1.7	14.4	354.3	0.00	1.00
07/30/2026 12:00	1.5	2.0	0.0	1.7	14.4	354.4	0.00	1.00
07/30/2026 13:00	1.5	2.0	0.0	1.7	14.4	354.8	0.00	1.00
07/30/2026 14:00	1.5	2.2	0.0	1.7	14.4	393.2	0.00	1.00
07/30/2026 15:00	1.5	2.0	0.0	1.7	14.3	355.9	0.00	1.00
07/30/2026 16:00	1.5	2.0	0.0	1.6	14.5	368.7	0.00	1.00
07/30/2026 17:00	1.5	2.2	0.0	1.7	14.4	400.4	0.00	1.00
07/30/2026 18:00	1.5	2.4	0.0	1.7	14.4	431.5	0.00	1.00
07/30/2026 19:00	1.5	2.0	0.0	1.6	14.4	370.4	0.00	1.00
07/30/2026 20:00	1.5	2.0	0.0	1.7	14.4	351.5	0.00	1.00
07/30/2026 21:00	1.5	2.0	0.0	1.7	14.3	359.5	0.00	1.00
07/30/2026 22:00	1.5	2.1	0.0	1.7	14.4	370.1	0.00	1.00
07/30/2026 23:00	1.5	2.0	0.0	1.7	14.3	354.5	0.00	1.00
Average/Sum#:	1.5	2.0	0.0	1.7	14.3	363.1	0.00 #	24.00 #
Minimum:	1.5	2.0	0.0	1.6	14.2	351.5	0.00	1.00
Maximum:	1.5	2.4	0.0	1.7	14.5	431.5	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
07/31/2026 00:00	1.5	2.0	0.0	1.7	14.3	352.6	0.00	1.00
07/31/2026 01:00	1.5	2.0	0.0	1.7	14.3	353.5	0.00	1.00
07/31/2026 02:00	1.5	2.0	0.0	1.7	14.3	354.1	0.00	1.00
07/31/2026 03:00	1.5	2.0	0.0	1.7	14.2	354.6	0.00	1.00
07/31/2026 04:00	1.5	2.1	0.0	1.7	14.2	373.3	0.00	1.00
07/31/2026 05:00	1.5	1.9	0.0	1.7	14.2	355.3	0.00	1.00
07/31/2026 06:00	1.5	2.0	0.0	1.7	14.2	355.0	0.00	1.00
07/31/2026 07:00	1.5	2.0	0.0	1.7	14.3	355.7	0.00	1.00
07/31/2026 08:00	1.5	2.0	0.0	1.7	14.3	354.7	0.00	1.00
07/31/2026 09:00	1.5	2.0	0.0	1.7	14.3	354.4	0.00	1.00
07/31/2026 10:00	1.5	2.0	0.0	1.7	14.4	354.2	0.00	1.00
07/31/2026 11:00	1.5	2.1	0.0	1.7	14.4	368.5	0.00	1.00
07/31/2026 12:00	1.5	2.4	0.0	1.7	14.4	436.5	0.00	1.00
07/31/2026 13:00	1.5	2.4	0.0	1.7	14.4	435.4	0.00	1.00
07/31/2026 14:00	1.5	2.5	0.0	1.7	14.4	435.6	0.00	1.00
07/31/2026 15:00	1.5	3.0	0.0	2.0	13.3	527.8	0.00	1.00
07/31/2026 16:00	1.5	3.1	0.0	2.1	13.0	554.1	0.00	1.00
07/31/2026 17:00	1.5	3.3	0.0	2.2	12.6	587.9	0.00	1.00
07/31/2026 18:00	1.5	3.5	0.0	2.3	11.9	633.4	0.00	1.00
07/31/2026 19:00	1.5	2.8	0.0	1.8	13.5	515.7	0.00	1.00
07/31/2026 20:00	1.5	2.8	0.0	1.9	13.3	508.1	0.00	1.00
07/31/2026 21:00	1.5	2.8	0.0	1.9	13.4	503.8	0.00	1.00
07/31/2026 22:00	1.5	2.8	0.0	1.9	13.6	498.9	0.00	1.00
07/31/2026 23:00	1.5	2.0	0.0	1.6	14.3	362.0	0.00	1.00
Average/Sum#:	1.5	2.4	0.0	1.8	13.9	428.5	0.00 #	24.00 #
Minimum:	1.5	1.9	0.0	1.6	11.9	352.6	0.00	1.00
Maximum:	1.5	3.5	0.0	2.3	14.4	633.4	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/01/2026 00:00	1.5	2.0	0.0	1.7	14.3	354.2	0.00	1.00
08/01/2026 01:00	1.5	2.0	0.0	1.7	14.3	353.4	0.00	1.00
08/01/2026 02:00	1.5	2.0	0.0	1.7	14.3	353.9	0.00	1.00
08/01/2026 03:00	1.5	2.0	0.0	1.7	14.2	354.5	0.00	1.00
08/01/2026 04:00	1.5	2.0	0.0	1.7	14.2	354.8	0.00	1.00
08/01/2026 05:00	1.5	2.0	0.0	1.7	14.2	355.0	0.00	1.00
08/01/2026 06:00	1.5	2.0	0.0	1.7	14.2	355.0	0.00	1.00
08/01/2026 07:00	1.5	2.0	0.0	1.7	14.2	355.4	0.00	1.00
08/01/2026 08:00	1.5	2.0	0.0	1.7	14.3	354.4	0.00	1.00
08/01/2026 09:00	1.5	2.0	0.0	1.7	14.3	354.2	0.00	1.00
08/01/2026 10:00	1.5	2.0	0.0	1.7	14.4	353.9	0.00	1.00
08/01/2026 11:00	1.5	2.0	0.0	1.7	14.4	355.3	0.00	1.00
08/01/2026 12:00	1.5	2.0	0.0	1.7	14.4	355.3	0.00	1.00
08/01/2026 13:00	1.5	2.0	0.0	1.7	14.4	354.9	0.00	1.00
08/01/2026 14:00	1.5	2.0	0.0	1.6	14.5	378.3	0.00	1.00
08/01/2026 15:00	1.5	2.9	0.0	1.9	13.5	505.3	0.00	1.00
08/01/2026 16:00	1.5	2.8	0.0	2.0	13.2	514.6	0.00	1.00
08/01/2026 17:00	1.5	3.2	0.0	2.1	12.7	566.8	0.00	1.00
08/01/2026 18:00	1.5	3.5	0.0	2.3	11.8	628.9	0.00	1.00
08/01/2026 19:00	1.5	3.2	0.0	2.1	12.5	584.2	0.00	1.00
08/01/2026 20:00	1.5	2.8	0.0	1.8	13.7	496.9	0.00	1.00
08/01/2026 21:00	1.5	2.8	0.0	2.0	13.0	511.7	0.00	1.00
08/01/2026 22:00	1.5	2.8	0.0	2.0	13.2	504.7	0.00	1.00
08/01/2026 23:00	1.5	2.2	0.0	1.6	14.4	402.8	0.00	1.00
Average/Sum#:	1.5	2.3	0.0	1.8	13.9	419.1	0.00 #	24.00 #
Minimum:	1.5	2.0	0.0	1.6	11.8	353.4	0.00	1.00
Maximum:	1.5	3.5	0.0	2.3	14.5	628.9	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/02/2026 00:00	1.5	2.0	0.0	1.7	14.3	355.5	0.00	1.00
08/02/2026 01:00	1.5	2.0	0.0	1.7	14.3	351.9	0.00	1.00
08/02/2026 02:00	1.5	1.9	0.0	1.7	14.3	352.1	0.00	1.00
08/02/2026 03:00	1.5	1.9	0.0	1.7	14.3	353.4	0.00	1.00
08/02/2026 04:00	1.5	2.0	0.0	1.7	14.3	353.3	0.00	1.00
08/02/2026 05:00	1.5	2.0	0.0	1.7	14.2	353.8	0.00	1.00
08/02/2026 06:00	1.5	2.0	0.0	1.7	14.2	353.5	0.00	1.00
08/02/2026 07:00	1.5	2.0	0.0	1.7	14.3	353.7	0.00	1.00
08/02/2026 08:00	1.5	2.0	0.0	1.7	14.3	352.7	0.00	1.00
08/02/2026 09:00	1.5	2.0	0.0	1.7	14.4	351.9	0.00	1.00
08/02/2026 10:00	1.5	2.0	0.0	1.7	14.4	352.1	0.00	1.00
08/02/2026 11:00	1.5	2.0	0.0	1.7	14.4	353.1	0.00	1.00
08/02/2026 12:00	1.5	2.0	0.0	1.7	14.4	352.8	0.00	1.00
08/02/2026 13:00	1.5	2.1	0.0	1.7	14.5	378.4	0.00	1.00
08/02/2026 14:00	1.5	2.9	0.0	1.9	13.5	504.4	0.00	1.00
08/02/2026 15:00	1.5	2.8	0.0	1.9	13.5	503.0	0.00	1.00
08/02/2026 16:00	1.5	3.0	0.0	2.0	13.2	527.7	0.00	1.00
08/02/2026 17:00	1.5	2.8	0.0	1.9	13.5	511.0	0.00	1.00
08/02/2026 18:00	1.5	2.8	0.0	1.9	13.4	507.3	0.00	1.00
08/02/2026 19:00	1.5	3.0	0.0	2.2	12.4	529.8	0.00	1.00
08/02/2026 20:00	1.5	2.9	0.0	2.1	12.6	523.9	0.00	1.00
08/02/2026 21:00	1.5	2.9	0.0	2.1	12.8	515.5	0.00	1.00
08/02/2026 22:00	1.5	2.4	0.0	1.7	14.2	430.5	0.00	1.00
08/02/2026 23:00	1.5	2.3	0.0	1.7	14.3	411.4	0.00	1.00
Average/Sum#:	1.5	2.3	0.0	1.8	13.9	413.9	0.00 #	24.00 #
Minimum:	1.5	1.9	0.0	1.7	12.4	351.9	0.00	1.00
Maximum:	1.5	3.0	0.0	2.2	14.5	529.8	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/03/2026 00:00	1.5	2.0	0.0	1.7	14.3	352.5	0.00	1.00
08/03/2026 01:00	1.5	2.1	0.0	1.7	14.4	380.2	0.00	1.00
08/03/2026 02:00	1.5	2.0	0.0	1.7	14.3	351.3	0.00	1.00
08/03/2026 03:00	1.5	2.0	0.0	1.7	14.3	351.3	0.00	1.00
08/03/2026 04:00	1.5	2.3	0.0	1.7	14.4	402.6	0.00	1.00
08/03/2026 05:00	1.5	2.2	0.0	1.7	14.3	392.6	0.00	1.00
08/03/2026 06:00	1.5	1.9	0.0	1.7	14.3	353.5	0.00	1.00
08/03/2026 07:00	1.5	2.0	0.0	1.7	14.3	353.8	0.00	1.00
08/03/2026 08:00	1.5	2.0	0.0	1.7	14.4	352.0	0.00	1.00
08/03/2026 09:00	1.5	2.0	0.0	1.7	14.4	351.8	0.00	1.00
08/03/2026 10:00	1.5	2.0	0.0	1.7	14.4	351.9	0.00	1.00
08/03/2026 11:00	1.5	2.0	0.0	1.7	14.4	353.0	0.00	1.00
08/03/2026 12:00	1.5	2.1	0.0	1.6	14.5	383.6	0.00	1.00
08/03/2026 13:00	1.5	2.2	0.0	1.7	14.4	400.1	0.00	1.00
08/03/2026 14:00	1.5	2.9	0.0	2.0	13.3	517.6	0.00	1.00
08/03/2026 15:00	1.5	2.8	0.0	1.9	13.4	510.1	0.00	1.00
08/03/2026 16:00	1.5	3.2	0.0	2.1	12.8	556.4	0.00	1.00
08/03/2026 17:00	1.5	3.2	0.0	2.1	12.7	569.6	0.00	1.00
08/03/2026 18:00	1.5	3.6	0.0	2.4	11.6	638.5	0.00	1.00
08/03/2026 19:00	1.5	3.3	0.0	2.2	12.0	611.3	0.00	1.00
08/03/2026 20:00	1.5	3.2	0.0	2.1	12.4	586.4	0.00	1.00
08/03/2026 21:00	1.5	2.9	0.0	2.0	13.0	528.4	0.00	1.00
08/03/2026 22:00	1.5	2.2	0.0	1.7	14.2	403.9	0.00	1.00
08/03/2026 23:00	1.5	2.4	0.0	1.7	14.5	421.2	0.00	1.00
Average/Sum#:	1.5	2.4	0.0	1.8	13.8	436.4	0.00 #	24.00 #
Minimum:	1.5	1.9	0.0	1.6	11.6	351.3	0.00	1.00
Maximum:	1.5	3.6	0.0	2.4	14.5	638.5	0.00	1.00
%SI	0.00	0.00	8.33	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/04/2026 00:00	1.5	2.0	0.0	1.7	14.3	367.2	0.00	1.00
08/04/2026 01:00	1.5	2.0	0.0	1.7	14.3	351.9	0.00	1.00
08/04/2026 02:00	1.5	2.0	0.0	1.7	14.3	351.7	0.00	1.00
08/04/2026 03:00	1.6	2.2	0.0	1.7	14.3	369.9	0.00	1.00
08/04/2026 04:00	1.5	2.3	0.0	1.7	14.4	406.2	0.00	1.00
08/04/2026 05:00	1.5	2.2	0.0	1.7	14.3	392.1	0.00	1.00
08/04/2026 06:00	1.5	2.1	0.0	1.7	14.3	379.2	0.00	1.00
08/04/2026 07:00	1.5	2.0	0.0	1.7	14.3	352.6	0.00	1.00
08/04/2026 08:00	1.5	2.0	0.0	1.7	14.3	352.0	0.00	1.00
08/04/2026 09:00	1.5	2.0	0.0	1.7	14.3	352.3	0.00	1.00
08/04/2026 10:00	1.5	2.0	0.0	1.7	14.3	355.0	0.00	1.00
08/04/2026 11:00	1.5	2.1	0.0	1.6	14.4	374.0	0.00	1.00
08/04/2026 12:00	1.5	2.2	0.0	1.6	14.4	404.4	0.00	1.00
08/04/2026 13:00	1.5	2.4	0.0	1.7	14.4	423.2	0.00	1.00
08/04/2026 14:00	1.5	3.1	0.0	2.0	13.1	539.5	0.00	1.00
08/04/2026 15:00	1.5	3.1	0.0	2.1	12.8	551.8	0.00	1.00
08/04/2026 16:00	1.5	2.9	0.0	2.0	13.1	533.0	0.00	1.00
08/04/2026 17:00	1.5	3.0	0.0	2.1	12.7	545.2	0.00	1.00
08/04/2026 18:00	1.5	3.4	0.0	2.2	12.2	599.2	0.00	1.00
08/04/2026 19:00	1.5	2.7	0.0	1.8	13.7	497.4	0.00	1.00
08/04/2026 20:00	1.5	2.8	0.0	1.9	13.5	502.3	0.00	1.00
08/04/2026 21:00	1.5	2.8	0.0	1.9	13.4	507.2	0.00	1.00
08/04/2026 22:00	1.5	2.0	0.0	1.6	14.3	363.0	0.00	1.00
08/04/2026 23:00	1.5	2.4	0.0	1.7	14.4	418.8	0.00	1.00
Average/Sum#:	1.5	2.4	0.0	1.8	13.9	428.7	0.00 #	24.00 #
Minimum:	1.5	2.0	0.0	1.6	12.2	351.7	0.00	1.00
Maximum:	1.6	3.4	0.0	2.2	14.4	599.2	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/05/2026 00:00	1.5	2.2	0.0	1.7	14.3	395.8	0.00	1.00
08/05/2026 01:00	1.5	2.0	0.0	1.7	14.2	354.5	0.00	1.00
08/05/2026 02:00	1.5	2.0	0.0	1.7	14.2	354.4	0.00	1.00
08/05/2026 03:00	1.5	2.0	0.0	1.7	14.2	354.4	0.00	1.00
08/05/2026 04:00	1.5	2.0	0.0	1.7	14.2	359.9	0.00	1.00
08/05/2026 05:00	1.5	2.0	0.0	1.7	14.2	354.8	0.00	1.00
08/05/2026 06:00	1.5	2.0	0.0	1.7	14.2	369.2	0.00	1.00
08/05/2026 07:00	1.5	2.0	0.0	1.7	14.2	355.6	0.00	1.00
08/05/2026 08:00	1.5	2.0	0.0	1.7	14.2	354.7	0.00	1.00
08/05/2026 09:00	1.5	2.0	0.0	1.7	14.3	354.6	0.00	1.00
08/05/2026 10:00	1.5	2.0	0.0	1.7	14.3	354.5	0.00	1.00
08/05/2026 11:00	1.5	2.0	0.0	1.7	14.3	355.4	0.00	1.00
08/05/2026 12:00	1.5	2.1	0.0	1.7	14.4	371.3	0.00	1.00
08/05/2026 13:00	1.5	2.1	0.0	1.7	14.3	385.3	0.00	1.00
08/05/2026 14:00	1.5	2.9	0.0	1.9	13.6	503.6	0.00	1.00
08/05/2026 15:00	1.5	2.8	0.0	1.9	13.5	507.8	0.00	1.00
08/05/2026 16:00	1.5	3.1	0.0	2.1	12.9	552.2	0.00	1.00
08/05/2026 17:00	1.5	2.9	0.0	1.9	13.2	533.3	0.00	1.00
08/05/2026 18:00	1.5	2.8	0.0	1.9	13.7	502.1	0.00	1.00
08/05/2026 19:00	1.5	2.8	0.0	1.9	13.4	508.5	0.00	1.00
08/05/2026 20:00	1.5	2.9	0.0	1.9	13.3	511.2	0.00	1.00
08/05/2026 21:00	1.5	2.8	0.0	1.9	13.5	502.6	0.00	1.00
08/05/2026 22:00	1.5	2.4	0.0	1.6	14.4	428.0	0.00	1.00
08/05/2026 23:00	1.5	2.3	0.0	1.6	14.4	412.8	0.00	1.00
Average/Sum#:	1.5	2.3	0.0	1.8	14.0	418.2	0.00 #	24.00 #
Minimum:	1.5	2.0	0.0	1.6	12.9	354.4	0.00	1.00
Maximum:	1.5	3.1	0.0	2.1	14.4	552.2	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/06/2026 00:00	1.5	2.0	0.0	1.7	14.3	366.5	0.00	1.00
08/06/2026 01:00	1.5	2.0	0.0	1.7	14.3	352.5	0.00	1.00
08/06/2026 02:00	1.5	2.0	0.0	1.7	14.3	352.6	0.00	1.00
08/06/2026 03:00	1.5	1.9	0.0	1.7	14.2	353.2	0.00	1.00
08/06/2026 04:00	1.5	2.0	0.0	1.7	14.2	357.2	0.00	1.00
08/06/2026 05:00	1.5	2.0	0.0	1.7	14.2	373.8	0.00	1.00
08/06/2026 06:00	1.5	2.0	0.0	1.7	14.2	354.2	0.00	1.00
08/06/2026 07:00	1.5	2.0	0.0	1.7	14.2	354.8	0.00	1.00
08/06/2026 08:00	1.5	2.0	0.0	1.7	14.2	353.7	0.00	1.00
08/06/2026 09:00	1.5	2.0	0.0	1.7	14.3	353.5	0.00	1.00
08/06/2026 10:00	1.5	2.0	0.0	1.7	14.3	353.7	0.00	1.00
08/06/2026 11:00	1.5	2.0	0.0	1.7	14.4	354.1	0.00	1.00
08/06/2026 12:00	1.5	2.0	0.0	1.7	14.4	354.1	0.00	1.00
08/06/2026 13:00	1.5	2.1	0.0	1.7	14.4	374.6	0.00	1.00
08/06/2026 14:00	1.5	3.0	0.0	2.2	12.6	523.5	0.00	1.00
08/06/2026 15:00	1.5	3.0	0.0	2.2	12.2	536.7	0.00	1.00
08/06/2026 16:00	1.5	3.1	0.0	2.2	12.1	552.2	0.00	1.00
08/06/2026 17:00	1.6	3.5	0.0	2.3	12.0	618.8	0.00	1.00
08/06/2026 18:00	1.5	3.2	0.0	2.1	12.4	593.7	0.00	1.00
08/06/2026 19:00	1.5	2.8	0.0	1.9	13.6	505.6	0.00	1.00
08/06/2026 20:00	1.5	2.9	0.0	2.0	13.2	517.1	0.00	1.00
08/06/2026 21:00	1.5	3.0	0.0	2.0	13.0	537.8	0.00	1.00
08/06/2026 22:00	1.5	2.4	0.0	1.6	14.5	427.5	0.00	1.00
08/06/2026 23:00	1.5	2.4	0.0	1.7	14.4	427.5	0.00	1.00
Average/Sum#:	1.5	2.4	0.0	1.8	13.7	427.0	0.00 #	24.00 #
Minimum:	1.5	1.9	0.0	1.6	12.0	352.5	0.00	1.00
Maximum:	1.6	3.5	0.0	2.3	14.5	618.8	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/07/2026 00:00	1.5	2.4	0.0	1.7	14.4	427.2	0.00	1.00
08/07/2026 01:00	1.5	2.4	0.0	1.7	14.4	427.3	0.00	1.00
08/07/2026 02:00	1.6	2.5	0.0	1.7	14.4	427.1	0.00	1.00
08/07/2026 03:00	1.5	2.0	0.0	1.6	14.2	376.2	0.00	1.00
08/07/2026 04:00	1.5	2.4	0.0	1.7	14.3	424.1	0.00	1.00
08/07/2026 05:00	1.5	2.4	0.0	1.7	14.3	426.7	0.00	1.00
08/07/2026 06:00	1.5	2.0	0.0	1.7	14.2	374.3	0.00	1.00
08/07/2026 07:00	1.5	2.0	0.0	1.7	14.2	355.2	0.00	1.00
08/07/2026 08:00	1.5	2.0	0.0	1.7	14.3	354.5	0.00	1.00
08/07/2026 09:00	1.5	2.0	0.0	1.7	14.3	354.1	0.00	1.00
08/07/2026 10:00	1.5	2.0	0.0	1.7	14.3	354.0	0.00	1.00
08/07/2026 11:00	1.5	2.1	0.0	1.7	14.4	383.7	0.00	1.00
08/07/2026 12:00	1.5	2.0	0.0	1.6	14.4	367.9	0.00	1.00
08/07/2026 13:00	1.5	2.3	0.0	1.6	14.4	413.3	0.00	1.00
08/07/2026 14:00	1.5	3.0	0.0	2.1	12.9	524.8	0.00	1.00
08/07/2026 15:00	1.5	3.1	0.0	2.3	12.0	545.0	0.00	1.00
08/07/2026 16:00	1.5	3.0	0.0	2.2	12.1	544.5	0.00	1.00
08/07/2026 17:00	1.5	3.1	0.0	2.1	13.0	548.6	0.00	1.00
08/07/2026 18:00	1.5	3.3	0.0	2.2	12.2	606.6	0.00	1.00
08/07/2026 19:00	1.5	2.9	0.0	2.0	13.2	533.0	0.00	1.00
08/07/2026 20:00	1.5	2.9	0.0	1.9	13.5	513.8	0.00	1.00
08/07/2026 21:00	1.5	2.9	0.0	1.9	13.3	519.0	0.00	1.00
08/07/2026 22:00	1.5	2.4	0.0	1.6	14.4	431.1	0.00	1.00
08/07/2026 23:00	1.5	2.5	0.0	1.6	14.5	439.5	0.00	1.00
Average/Sum#:	1.5	2.5	0.0	1.8	13.8	444.6	0.00 #	24.00 #
Minimum:	1.5	2.0	0.0	1.6	12.0	354.0	0.00	1.00
Maximum:	1.6	3.3	0.0	2.3	14.5	606.6	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/08/2026 00:00	1.5	2.5	0.0	1.7	14.4	439.3	0.00	1.00
08/08/2026 01:00	1.5	2.1	0.0	1.7	14.3	385.3	0.00	1.00
08/08/2026 02:00	1.5	1.9	0.0	1.7	14.2	354.8	0.00	1.00
08/08/2026 03:00	1.5	2.0	0.0	1.7	14.2	357.5	0.00	1.00
08/08/2026 04:00	1.5	2.4	0.0	1.7	14.4	423.6	0.00	1.00
08/08/2026 05:00	1.5	2.2	0.0	1.7	14.3	400.9	0.00	1.00
08/08/2026 06:00	1.5	2.0	0.0	1.7	14.2	356.3	0.00	1.00
08/08/2026 07:00	1.5	2.0	0.0	1.7	14.2	356.4	0.00	1.00
08/08/2026 08:00	1.5	2.0	0.0	1.7	14.3	358.0	0.00	1.00
08/08/2026 09:00	1.5	2.0	0.0	1.7	14.3	358.0	0.00	1.00
08/08/2026 10:00	1.5	2.0	0.0	1.7	14.3	357.3	0.00	1.00
08/08/2026 11:00	1.5	2.0	0.0	1.7	14.4	357.3	0.00	1.00
08/08/2026 12:00	1.5	2.0	0.0	1.7	14.4	357.2	0.00	1.00
08/08/2026 13:00	1.5	2.2	0.0	1.7	14.2	377.2	0.00	1.00
08/08/2026 14:00	1.5	3.1	0.0	2.3	12.1	547.4	0.00	1.00
08/08/2026 15:00	1.5	2.9	0.0	2.1	12.4	530.3	0.00	1.00
08/08/2026 16:00	1.5	2.8	0.0	1.9	13.4	512.1	0.00	1.00
08/08/2026 17:00	1.5	2.9	0.0	2.0	13.3	523.1	0.00	1.00
08/08/2026 18:00	1.5	2.9	0.0	1.9	13.4	515.0	0.00	1.00
08/08/2026 19:00	1.5	2.9	0.0	2.0	13.2	514.5	0.00	1.00
08/08/2026 20:00	1.5	2.8	0.0	1.9	13.3	511.4	0.00	1.00
08/08/2026 21:00	1.5	2.8	0.0	1.9	13.3	506.2	0.00	1.00
08/08/2026 22:00	1.5	2.4	0.0	1.6	14.5	429.4	0.00	1.00
08/08/2026 23:00	1.5	2.2	0.0	1.6	14.4	402.7	0.00	1.00
Average/Sum#:	1.5	2.4	0.0	1.8	13.9	426.3	0.00 #	24.00 #
Minimum:	1.5	1.9	0.0	1.6	12.1	354.8	0.00	1.00
Maximum:	1.5	3.1	0.0	2.3	14.5	547.4	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/09/2026 00:00	1.5	2.0	0.0	1.7	14.3	353.9	0.00	1.00
08/09/2026 01:00	1.5	2.0	0.0	1.7	14.3	353.9	0.00	1.00
08/09/2026 02:00	1.5	2.0	0.0	1.7	14.2	354.3	0.00	1.00
08/09/2026 03:00	1.5	2.0	0.0	1.7	14.2	354.3	0.00	1.00
08/09/2026 04:00	1.5	2.0	0.0	1.7	14.2	358.3	0.00	1.00
08/09/2026 05:00	1.5	2.2	0.0	1.7	14.3	398.3	0.00	1.00
08/09/2026 06:00	1.5	2.0	0.0	1.7	14.2	355.8	0.00	1.00
08/09/2026 07:00	1.5	2.0	0.0	1.7	14.3	356.2	0.00	1.00
08/09/2026 08:00	1.5	2.0	0.0	1.7	14.3	355.4	0.00	1.00
08/09/2026 09:00	1.5	2.0	0.0	1.7	14.3	354.8	0.00	1.00
08/09/2026 10:00	1.5	2.0	0.0	1.7	14.4	354.7	0.00	1.00
08/09/2026 11:00	1.5	2.0	0.0	1.7	14.4	355.2	0.00	1.00
08/09/2026 12:00	1.5	2.0	0.0	1.6	14.4	364.9	0.00	1.00
08/09/2026 13:00	1.5	2.3	0.0	1.6	14.4	420.2	0.00	1.00
08/09/2026 14:00	1.5	3.0	0.0	2.0	13.1	514.2	0.00	1.00
08/09/2026 15:00	1.5	3.4	0.0	2.3	12.0	602.4	0.00	1.00
08/09/2026 16:00	1.5	3.4	0.0	2.3	11.9	610.5	0.00	1.00
08/09/2026 17:00	1.5	3.3	0.0	2.2	12.2	593.0	0.00	1.00
08/09/2026 18:00	1.5	3.3	0.0	2.2	12.0	613.1	0.00	1.00
08/09/2026 19:00	1.5	2.8	0.0	1.9	13.4	508.2	0.00	1.00
08/09/2026 20:00	1.5	2.9	0.0	2.0	12.9	517.8	0.00	1.00
08/09/2026 21:00	1.5	2.8	0.0	1.9	13.3	507.6	0.00	1.00
08/09/2026 22:00	1.5	2.0	0.0	1.6	14.3	366.7	0.00	1.00
08/09/2026 23:00	1.5	2.0	0.0	1.7	14.3	352.9	0.00	1.00
Average/Sum#:	1.5	2.4	0.0	1.8	13.7	428.2	0.00 #	24.00 #
Minimum:	1.5	2.0	0.0	1.6	11.9	352.9	0.00	1.00
Maximum:	1.5	3.4	0.0	2.3	14.4	613.1	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/10/2026 00:00	1.5	2.0	0.0	1.7	14.3	353.3	0.00	1.00
08/10/2026 01:00	1.5	2.0	0.0	1.7	14.2	353.5	0.00	1.00
08/10/2026 02:00	1.5	1.9	0.0	1.7	14.2	353.5	0.00	1.00
08/10/2026 03:00	1.5	2.0	0.0	1.7	14.2	353.9	0.00	1.00
08/10/2026 04:00	1.5	2.2	0.0	1.7	14.3	392.3	0.00	1.00
08/10/2026 05:00	1.5	1.9	0.0	1.7	14.2	354.5	0.00	1.00
08/10/2026 06:00	1.5	2.2	0.0	1.7	14.3	388.4	0.00	1.00
08/10/2026 07:00	1.5	2.0	0.0	1.7	14.2	356.0	0.00	1.00
08/10/2026 08:00	1.5	2.0	0.0	1.7	14.3	355.0	0.00	1.00
08/10/2026 09:00	1.5	2.0	0.0	1.7	14.3	354.8	0.00	1.00
08/10/2026 10:00	1.5	2.0	0.0	1.7	14.3	354.8	0.00	1.00
08/10/2026 11:00	1.5	2.0	0.0	1.7	14.4	355.5	0.00	1.00
08/10/2026 12:00	1.5	2.1	0.0	1.7	14.4	374.3	0.00	1.00
08/10/2026 13:00	1.5	2.3	0.0	1.7	14.3	407.5	0.00	1.00
08/10/2026 14:00	1.5	2.2	0.0	1.7	14.3	396.9	0.00	1.00
08/10/2026 15:00	1.5	2.9	0.0	1.9	13.5	515.8	0.00	1.00
08/10/2026 16:00	1.6	3.3	0.0	2.2	12.6	581.8	0.00	1.00
08/10/2026 17:00	1.5	3.4	0.0	2.2	12.2	611.1	0.00	1.00
08/10/2026 18:00	1.5	3.2	0.0	2.1	12.5	591.6	0.00	1.00
08/10/2026 19:00	1.5	3.0	0.0	2.0	13.1	541.9	0.00	1.00
08/10/2026 20:00	1.5	2.8	0.0	1.9	13.6	510.0	0.00	1.00
08/10/2026 21:00	1.5	3.0	0.0	2.0	13.3	536.7	0.00	1.00
08/10/2026 22:00	1.5	2.4	0.0	1.6	14.4	430.3	0.00	1.00
08/10/2026 23:00	1.5	2.1	0.0	1.7	14.3	375.4	0.00	1.00
Average/Sum#:	1.5	2.4	0.0	1.8	13.9	425.0	0.00 #	24.00 #
Minimum:	1.5	1.9	0.0	1.6	12.2	353.3	0.00	1.00
Maximum:	1.6	3.4	0.0	2.2	14.4	611.1	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/11/2026 00:00	1.5	2.1	0.0	1.7	14.3	381.4	0.00	1.00
08/11/2026 01:00	1.5	2.0	0.0	1.7	14.2	355.4	0.00	1.00
08/11/2026 02:00	1.5	2.0	0.0	1.7	14.2	355.3	0.00	1.00
08/11/2026 03:00	1.5	2.0	0.0	1.7	14.2	355.4	0.00	1.00
08/11/2026 04:00	1.5	2.0	0.0	1.7	14.2	359.1	0.00	1.00
08/11/2026 05:00	1.5	2.1	0.0	1.7	14.2	381.2	0.00	1.00
08/11/2026 06:00	1.5	2.2	0.0	1.7	14.3	396.8	0.00	1.00
08/11/2026 07:00	1.5	2.0	0.0	1.7	14.3	357.0	0.00	1.00
08/11/2026 08:00	1.5	2.0	0.0	1.7	14.3	356.1	0.00	1.00
08/11/2026 09:00	1.5	2.0	0.0	1.7	14.3	356.1	0.00	1.00
08/11/2026 10:00	1.5	2.0	0.0	1.7	14.3	366.0	0.00	1.00
08/11/2026 11:00	1.5	2.4	0.0	1.7	14.5	429.2	0.00	1.00
08/11/2026 12:00	1.5	2.4	0.0	1.6	14.4	432.7	0.00	1.00
08/11/2026 13:00	1.5	3.0	0.0	2.0	13.3	537.5	0.00	1.00
08/11/2026 14:00	1.5	2.9	0.0	1.9	13.5	523.6	0.00	1.00
08/11/2026 15:00	1.5	2.9	0.0	1.9	13.5	518.8	0.00	1.00
08/11/2026 16:00	1.5	3.3	0.0	2.2	12.5	589.6	0.00	1.00
08/11/2026 17:00	1.5	3.6	0.0	2.3	12.0	629.8	0.00	1.00
08/11/2026 18:00	1.5	3.2	0.0	2.1	12.5	590.9	0.00	1.00
08/11/2026 19:00	1.5	3.2	0.0	2.1	12.6	587.6	0.00	1.00
08/11/2026 20:00	1.5	3.1	0.0	2.0	13.0	553.1	0.00	1.00
08/11/2026 21:00	1.5	2.4	0.0	1.6	14.4	430.2	0.00	1.00
08/11/2026 22:00	1.5	2.2	0.0	1.6	14.3	402.9	0.00	1.00
08/11/2026 23:00	1.5	2.0	0.0	1.7	14.3	362.3	0.00	1.00
Average/Sum#:	1.5	2.5	0.0	1.8	13.8	442.0	0.00 #	24.00 #
Minimum:	1.5	2.0	0.0	1.6	12.0	355.3	0.00	1.00
Maximum:	1.5	3.6	0.0	2.3	14.5	629.8	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/12/2026 00:00	1.5	2.0	0.0	1.7	14.3	354.4	0.00	1.00
08/12/2026 01:00	1.5	2.0	0.0	1.7	14.2	354.6	0.00	1.00
08/12/2026 02:00	1.5	2.0	0.0	1.7	14.2	354.8	0.00	1.00
08/12/2026 03:00	1.5	2.0	0.0	1.7	14.2	354.9	0.00	1.00
08/12/2026 04:00	1.5	2.2	0.0	1.7	14.3	388.6	0.00	1.00
08/12/2026 05:00	1.5	2.3	0.0	1.7	14.3	420.2	0.00	1.00
08/12/2026 06:00	1.5	2.0	0.0	1.7	14.2	354.4	0.00	1.00
08/12/2026 07:00	1.5	2.0	0.0	1.7	14.2	355.3	0.00	1.00
08/12/2026 08:00	1.5	2.0	0.0	1.7	14.2	355.5	0.00	1.00
08/12/2026 09:00	1.5	2.0	0.0	1.7	14.3	355.2	0.00	1.00
08/12/2026 10:00	1.5	2.0	0.0	1.7	14.3	355.1	0.00	1.00
08/12/2026 11:00	1.5	2.0	0.0	1.7	14.3	356.0	0.00	1.00
08/12/2026 12:00	1.5	2.0	0.0	1.7	14.4	359.1	0.00	1.00
08/12/2026 13:00	1.5	2.8	0.0	1.9	13.8	499.0	0.00	1.00
08/12/2026 14:00	1.5	2.8	0.0	1.8	13.8	500.7	0.00	1.00
08/12/2026 15:00	1.5	2.8	0.0	1.8	13.8	498.6	0.00	1.00
08/12/2026 16:00	1.5	2.8	0.0	1.8	13.8	498.4	0.00	1.00
08/12/2026 17:00	1.5	2.7	0.0	1.8	13.8	496.7	0.00	1.00
08/12/2026 18:00	1.5	2.8	0.0	1.8	13.8	495.2	0.00	1.00
08/12/2026 19:00	1.5	2.7	0.0	1.8	13.9	491.6	0.00	1.00
08/12/2026 20:00	1.5	2.7	0.0	1.8	13.8	492.5	0.00	1.00
08/12/2026 21:00	1.5	2.0	0.0	1.6	14.3	370.4	0.00	1.00
08/12/2026 22:00	1.5	2.0	0.0	1.7	14.3	353.7	0.00	1.00
08/12/2026 23:00	1.5	2.0	0.0	1.7	14.3	353.7	0.00	1.00
Average/Sum#:	1.5	2.3	0.0	1.7	14.1	407.0	0.00 #	24.00 #
Minimum:	1.5	2.0	0.0	1.6	13.8	353.7	0.00	1.00
Maximum:	1.5	2.8	0.0	1.9	14.4	500.7	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/13/2026 00:00	1.5	2.0	0.0	1.7	14.2	354.0	0.00	1.00
08/13/2026 01:00	1.5	2.0	0.0	1.7	14.2	354.2	0.00	1.00
08/13/2026 02:00	1.5	1.9	0.0	1.7	14.2	354.9	0.00	1.00
08/13/2026 03:00	1.5	2.0	0.0	1.7	14.2	355.2	0.00	1.00
08/13/2026 04:00	1.5	2.0	0.0	1.7	14.2	355.4	0.00	1.00
08/13/2026 05:00	1.5	2.0	0.0	1.7	14.2	355.5	0.00	1.00
08/13/2026 06:00	1.5	2.0	0.0	1.7	14.2	356.0	0.00	1.00
08/13/2026 07:00	1.5	1.9	0.0	1.7	14.2	356.4	0.00	1.00
08/13/2026 08:00	1.5	2.0	0.0	1.7	14.2	356.0	0.00	1.00
08/13/2026 09:00	1.5	2.0	0.0	1.7	14.2	355.6	0.00	1.00
08/13/2026 10:00	1.5	2.0	0.0	1.7	14.3	355.6	0.00	1.00
08/13/2026 11:00	1.5	2.0	0.0	1.7	14.3	356.6	0.00	1.00
08/13/2026 12:00	1.5	2.2	0.0	1.7	14.4	380.3	0.00	1.00
08/13/2026 13:00	1.5	2.9	0.0	1.9	13.7	503.8	0.00	1.00
08/13/2026 14:00	1.5	2.8	0.0	1.9	13.6	505.4	0.00	1.00
08/13/2026 15:00	1.5	2.8	0.0	1.9	13.6	505.2	0.00	1.00
08/13/2026 16:00	1.5	2.8	0.0	1.8	13.7	501.7	0.00	1.00
08/13/2026 17:00	1.5	2.8	0.0	1.8	13.8	499.3	0.00	1.00
08/13/2026 18:00	1.5	2.7	0.0	1.8	13.8	495.6	0.00	1.00
08/13/2026 19:00	1.5	1.9	0.0	1.7	14.2	359.6	0.00	1.00
08/13/2026 20:00	1.5	2.0	0.0	1.7	14.2	355.1	0.00	1.00
08/13/2026 21:00	1.5	2.0	0.0	1.7	14.2	355.1	0.00	1.00
08/13/2026 22:00	1.5	2.0	0.0	1.7	14.2	355.3	0.00	1.00
08/13/2026 23:00	1.5	2.0	0.0	1.7	14.2	355.3	0.00	1.00
Average/Sum#:	1.5	2.2	0.0	1.7	14.1	393.2	0.00 #	24.00 #
Minimum:	1.5	1.9	0.0	1.7	13.6	354.0	0.00	1.00
Maximum:	1.5	2.9	0.0	1.9	14.4	505.4	0.00	1.00
%SI	0.00	0.00	12.50	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/14/2026 00:00	1.5	2.0	0.0	1.7	14.2	355.3	0.00	1.00
08/14/2026 01:00	1.5	2.0	0.0	1.7	14.2	355.4	0.00	1.00
08/14/2026 02:00	1.5	2.0	0.0	1.7	14.2	355.5	0.00	1.00
08/14/2026 03:00	1.5	2.0	0.0	1.7	14.2	355.6	0.00	1.00
08/14/2026 04:00	1.5	2.0	0.0	1.7	14.2	355.7	0.00	1.00
08/14/2026 05:00	1.5	2.0	0.0	1.7	14.2	358.8	0.00	1.00
08/14/2026 06:00	1.5	2.1	0.0	1.7	14.2	370.4	0.00	1.00
08/14/2026 07:00	1.5	2.0	0.0	1.7	14.2	356.1	0.00	1.00
08/14/2026 08:00	1.5	2.0	0.0	1.7	14.2	356.4	0.00	1.00
08/14/2026 09:00	1.5	2.0	0.0	1.7	14.2	355.9	0.00	1.00
08/14/2026 10:00	1.5	2.0	0.0	1.7	14.2	356.0	0.00	1.00
08/14/2026 11:00	1.5	2.0	0.0	1.7	14.2	357.2	0.00	1.00
08/14/2026 12:00	1.5	2.0	0.0	1.7	14.3	357.5	0.00	1.00
08/14/2026 13:00	1.5	2.0	0.0	1.7	14.3	357.7	0.00	1.00
08/14/2026 14:00	1.5	2.0	0.0	1.7	14.3	357.8	0.00	1.00
08/14/2026 15:00	1.5	2.0	0.0	1.7	14.3	357.1	0.00	1.00
08/14/2026 16:00	1.5	2.0	0.0	1.7	14.3	356.2	0.00	1.00
08/14/2026 17:00	1.5	2.1	0.0	1.7	14.3	373.4	0.00	1.00
08/14/2026 18:00	1.5	2.0	0.0	1.7	14.3	358.2	0.00	1.00
08/14/2026 19:00	1.5	2.0	0.0	1.7	14.2	355.7	0.00	1.00
08/14/2026 20:00	1.5	2.0	0.0	1.7	14.2	356.3	0.00	1.00
08/14/2026 21:00	1.5	2.0	0.0	1.7	14.2	356.2	0.00	1.00
08/14/2026 22:00	1.5	2.0	0.0	1.7	14.2	356.6	0.00	1.00
08/14/2026 23:00	1.5	2.0	0.0	1.7	14.2	356.7	0.00	1.00
Average/Sum#:	1.5	2.0	0.0	1.7	14.2	357.8	0.00 #	24.00 #
Minimum:	1.5	2.0	0.0	1.7	14.2	355.3	0.00	1.00
Maximum:	1.5	2.1	0.0	1.7	14.3	373.4	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/15/2026 00:00	1.5	2.0	0.0	1.7	14.2	357.1	0.00	1.00
08/15/2026 01:00	1.5	2.0	0.0	1.7	14.2	357.1	0.00	1.00
08/15/2026 02:00	1.5	2.0	0.0	1.7	14.2	357.1	0.00	1.00
08/15/2026 03:00	1.5	2.0	0.0	1.7	14.2	356.1	0.00	1.00
08/15/2026 04:00	1.5	2.0	0.0	1.7	14.2	355.4	0.00	1.00
08/15/2026 05:00	1.5	2.0	0.0	1.7	14.2	355.0	0.00	1.00
08/15/2026 06:00	1.5	2.0	0.0	1.7	14.2	355.0	0.00	1.00
08/15/2026 07:00	1.5	2.0	0.0	1.7	14.2	355.1	0.00	1.00
08/15/2026 08:00	1.5	2.0	0.0	1.7	14.2	354.9	0.00	1.00
08/15/2026 09:00	1.5	2.0	0.0	1.7	14.2	355.3	0.00	1.00
08/15/2026 10:00	1.5	2.0	0.0	1.7	14.2	355.7	0.00	1.00
08/15/2026 11:00	1.5	2.0	0.0	1.7	14.3	356.8	0.00	1.00
08/15/2026 12:00	1.5	2.0	0.0	1.7	14.3	357.1	0.00	1.00
08/15/2026 13:00	1.5	2.0	0.0	1.7	14.3	357.5	0.00	1.00
08/15/2026 14:00	1.5	2.0	0.0	1.7	14.3	357.8	0.00	1.00
08/15/2026 15:00	1.5	2.0	0.0	1.7	14.3	357.1	0.00	1.00
08/15/2026 16:00	1.5	2.1	0.0	1.7	14.4	375.7	0.00	1.00
08/15/2026 17:00	1.5	2.2	0.0	1.7	14.4	390.7	0.00	1.00
08/15/2026 18:00	1.5	2.0	0.0	1.7	14.3	364.6	0.00	1.00
08/15/2026 19:00	1.5	2.1	0.0	1.7	14.3	376.1	0.00	1.00
08/15/2026 20:00	1.5	2.0	0.0	1.7	14.3	355.8	0.00	1.00
08/15/2026 21:00	1.5	2.5	0.0	1.7	14.4	430.4	0.00	1.00
08/15/2026 22:00	1.5	2.4	0.0	1.7	14.4	422.2	0.00	1.00
08/15/2026 23:00	1.5	2.4	0.0	1.7	14.4	431.5	0.00	1.00
Average/Sum#:	1.5	2.1	0.0	1.7	14.3	368.6	0.00 #	24.00 #
Minimum:	1.5	2.0	0.0	1.7	14.2	354.9	0.00	1.00
Maximum:	1.5	2.5	0.0	1.7	14.4	431.5	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/16/2026 00:00	1.5	2.4	0.0	1.7	14.3	428.2	0.00	1.00
08/16/2026 01:00	1.5	1.9	0.0	1.7	14.2	354.5	0.00	1.00
08/16/2026 02:00	1.5	2.0	0.0	1.7	14.2	355.0	0.00	1.00
08/16/2026 03:00	1.5	2.0	0.0	1.7	14.2	355.1	0.00	1.00
08/16/2026 04:00	1.5	2.0	0.0	1.7	14.2	355.4	0.00	1.00
08/16/2026 05:00	1.5	2.0	0.0	1.7	14.2	356.0	0.00	1.00
08/16/2026 06:00	1.5	2.0	0.0	1.7	14.2	356.3	0.00	1.00
08/16/2026 07:00	1.5	2.0	0.0	1.7	14.2	356.8	0.00	1.00
08/16/2026 08:00	1.5	2.0	0.0	1.7	14.2	355.9	0.00	1.00
08/16/2026 09:00	1.5	2.0	0.0	1.7	14.2	355.5	0.00	1.00
08/16/2026 10:00	1.5	2.0	0.0	1.7	14.3	355.5	0.00	1.00
08/16/2026 11:00	1.5	2.0	0.0	1.7	14.3	356.3	0.00	1.00
08/16/2026 12:00	1.5	2.1	0.0	1.7	14.3	381.2	0.00	1.00
08/16/2026 13:00	1.5	2.8	0.0	1.8	13.7	499.9	0.00	1.00
08/16/2026 14:00	1.5	2.8	0.0	1.8	13.8	500.2	0.00	1.00
08/16/2026 15:00	1.5	2.8	0.0	1.8	13.8	499.1	0.00	1.00
08/16/2026 16:00	1.5	2.8	0.0	1.9	13.6	507.2	0.00	1.00
08/16/2026 17:00	1.5	2.9	0.0	1.9	13.4	526.5	0.00	1.00
08/16/2026 18:00	1.5	2.8	0.0	1.8	13.6	504.1	0.00	1.00
08/16/2026 19:00	1.5	2.7	0.0	1.8	13.8	494.8	0.00	1.00
08/16/2026 20:00	1.5	2.8	0.0	1.9	13.6	501.4	0.00	1.00
08/16/2026 21:00	1.5	2.4	0.0	1.6	14.5	429.9	0.00	1.00
08/16/2026 22:00	1.5	2.3	0.0	1.6	14.5	418.9	0.00	1.00
08/16/2026 23:00	1.5	2.0	0.0	1.7	14.3	352.2	0.00	1.00
Average/Sum#:	1.5	2.3	0.0	1.7	14.1	414.8	0.00 #	24.00 #
Minimum:	1.5	1.9	0.0	1.6	13.4	352.2	0.00	1.00
Maximum:	1.5	2.9	0.0	1.9	14.5	526.5	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/17/2026 00:00	1.5	2.0	0.0	1.7	14.3	352.6	0.00	1.00
08/17/2026 01:00	1.5	2.0	0.0	1.7	14.3	353.1	0.00	1.00
08/17/2026 02:00	1.5	1.9	0.0	1.7	14.3	352.9	0.00	1.00
08/17/2026 03:00	1.5	2.0	0.0	1.7	14.2	352.7	0.00	1.00
08/17/2026 04:00	1.5	2.0	0.0	1.7	14.2	356.5	0.00	1.00
08/17/2026 05:00	1.5	1.9	0.0	1.7	14.2	353.8	0.00	1.00
08/17/2026 06:00	1.5	2.0	0.0	1.7	14.2	353.8	0.00	1.00
08/17/2026 07:00	1.5	2.0	0.0	1.7	14.2	353.9	0.00	1.00
08/17/2026 08:00	1.5	2.0	0.0	1.7	14.3	354.1	0.00	1.00
08/17/2026 09:00	1.5	2.0	0.0	1.7	14.3	354.1	0.00	1.00
08/17/2026 10:00	1.5	2.0	0.0	1.7	14.3	354.1	0.00	1.00
08/17/2026 11:00	1.5	2.0	0.0	1.7	14.3	354.2	0.00	1.00
08/17/2026 12:00	1.5	2.1	0.0	1.7	14.4	378.4	0.00	1.00
08/17/2026 13:00	1.5	2.8	0.0	1.8	13.8	496.9	0.00	1.00
08/17/2026 14:00	1.5	3.1	0.0	2.1	13.0	555.7	0.00	1.00
08/17/2026 15:00	1.5	3.1	0.0	2.0	12.8	563.1	0.00	1.00
08/17/2026 16:00	1.5	3.0	0.0	2.0	13.2	535.7	0.00	1.00
08/17/2026 17:00	1.5	3.4	0.0	2.2	12.4	597.3	0.00	1.00
08/17/2026 18:00	1.5	3.0	0.0	2.0	12.9	561.8	0.00	1.00
08/17/2026 19:00	1.5	2.9	0.0	1.9	13.4	527.9	0.00	1.00
08/17/2026 20:00	1.5	2.8	0.0	1.9	13.6	504.1	0.00	1.00
08/17/2026 21:00	1.5	2.1	0.0	1.6	14.4	387.6	0.00	1.00
08/17/2026 22:00	1.5	2.1	0.0	1.7	14.4	371.3	0.00	1.00
08/17/2026 23:00	1.5	2.0	0.0	1.7	14.3	352.4	0.00	1.00
Average/Sum#:	1.5	2.3	0.0	1.8	13.9	419.9	0.00 #	24.00 #
Minimum:	1.5	1.9	0.0	1.6	12.4	352.4	0.00	1.00
Maximum:	1.5	3.4	0.0	2.2	14.4	597.3	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/18/2026 00:00	1.5	2.0	0.0	1.7	14.3	352.9	0.00	1.00
08/18/2026 01:00	1.5	2.0	0.0	1.7	14.2	353.0	0.00	1.00
08/18/2026 02:00	1.5	1.9	0.0	1.7	14.2	353.3	0.00	1.00
08/18/2026 03:00	1.5	2.0	0.0	1.7	14.2	353.5	0.00	1.00
08/18/2026 04:00	1.5	2.0	0.0	1.7	14.2	354.1	0.00	1.00
08/18/2026 05:00	1.5	2.0	0.0	1.7	14.2	354.0	0.00	1.00
08/18/2026 06:00	1.5	2.0	0.0	1.7	14.2	355.0	0.00	1.00
08/18/2026 07:00	1.5	2.0	0.0	1.7	14.2	355.1	0.00	1.00
08/18/2026 08:00	1.5	2.0	0.0	1.7	14.2	354.0	0.00	1.00
08/18/2026 09:00	1.5	2.0	0.0	1.7	14.3	353.9	0.00	1.00
08/18/2026 10:00	1.5	2.0	0.0	1.7	14.3	354.0	0.00	1.00
08/18/2026 11:00	1.5	2.0	0.0	1.7	14.3	354.3	0.00	1.00
08/18/2026 12:00	1.5	2.2	0.0	1.7	14.4	375.7	0.00	1.00
08/18/2026 13:00	1.5	3.0	0.0	2.1	12.9	527.9	0.00	1.00
08/18/2026 14:00	1.5	3.1	0.0	2.2	12.5	545.5	0.00	1.00
08/18/2026 15:00	1.5	3.0	0.0	2.1	12.4	537.2	0.00	1.00
08/18/2026 16:00	1.5	3.2	0.0	2.2	12.3	563.1	0.00	1.00
08/18/2026 17:00	1.5	3.6	0.0	2.3	12.0	627.8	0.00	1.00
08/18/2026 18:00	1.5	3.3	0.0	2.1	12.3	600.6	0.00	1.00
08/18/2026 19:00	1.5	3.0	0.0	1.9	13.2	535.0	0.00	1.00
08/18/2026 20:00	1.5	2.7	0.0	1.8	13.8	490.7	0.00	1.00
08/18/2026 21:00	1.5	2.1	0.0	1.6	14.2	397.5	0.00	1.00
08/18/2026 22:00	1.5	2.1	0.0	1.7	14.3	371.4	0.00	1.00
08/18/2026 23:00	1.5	2.0	0.0	1.7	14.3	358.6	0.00	1.00
Average/Sum#:	1.5	2.4	0.0	1.8	13.7	424.1	0.00 #	24.00 #
Minimum:	1.5	1.9	0.0	1.6	12.0	352.9	0.00	1.00
Maximum:	1.5	3.6	0.0	2.3	14.4	627.8	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/19/2026 00:00	1.5	2.0	0.0	1.7	14.3	352.5	0.00	1.00
08/19/2026 01:00	1.5	1.9	0.0	1.7	14.2	352.8	0.00	1.00
08/19/2026 02:00	1.5	2.0	0.0	1.7	14.2	353.2	0.00	1.00
08/19/2026 03:00	1.5	2.0	0.0	1.7	14.2	353.7	0.00	1.00
08/19/2026 04:00	1.5	2.0	0.0	1.7	14.2	353.6	0.00	1.00
08/19/2026 05:00	1.5	2.0	0.0	1.7	14.2	353.6	0.00	1.00
08/19/2026 06:00	1.5	2.0	0.0	1.7	14.2	354.3	0.00	1.00
08/19/2026 07:00	1.5	2.0	0.0	1.7	14.2	354.9	0.00	1.00
08/19/2026 08:00	1.5	2.0	0.0	1.7	14.3	354.2	0.00	1.00
08/19/2026 09:00	1.5	2.0	0.0	1.7	14.3	353.9	0.00	1.00
08/19/2026 10:00	1.5	2.0	0.0	1.7	14.3	354.2	0.00	1.00
08/19/2026 11:00	1.5	2.0	0.0	1.7	14.4	354.6	0.00	1.00
08/19/2026 12:00	1.5	2.1	0.0	1.7	14.4	372.9	0.00	1.00
08/19/2026 13:00	1.5	3.1	0.0	2.2	12.3	542.5	0.00	1.00
08/19/2026 14:00	1.5	3.1	0.0	2.2	12.2	564.3	0.00	1.00
08/19/2026 15:00	1.5	3.0	0.0	2.2	12.5	540.9	0.00	1.00
08/19/2026 16:00	1.5	3.1	0.0	2.2	12.1	555.5	0.00	1.00
08/19/2026 17:00	1.5	3.5	0.0	2.3	12.1	618.1	0.00	1.00
08/19/2026 18:00	1.5	3.4	0.0	2.2	12.1	619.3	0.00	1.00
08/19/2026 19:00	1.5	3.3	0.0	2.2	12.3	600.1	0.00	1.00
08/19/2026 20:00	1.5	3.1	0.0	2.0	12.9	555.9	0.00	1.00
08/19/2026 21:00	1.5	2.3	0.0	1.6	14.4	423.2	0.00	1.00
08/19/2026 22:00	1.5	2.4	0.0	1.7	14.5	429.6	0.00	1.00
08/19/2026 23:00	1.5	2.4	0.0	1.7	14.4	429.3	0.00	1.00
Average/Sum#:	1.5	2.4	0.0	1.9	13.6	437.4	0.00 #	24.00 #
Minimum:	1.5	1.9	0.0	1.6	12.1	352.5	0.00	1.00
Maximum:	1.5	3.5	0.0	2.3	14.5	619.3	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/20/2026 00:00	1.5	2.1	0.0	1.6	14.3	394.0	0.00	1.00
08/20/2026 01:00	1.5	2.0	0.0	1.7	14.3	355.4	0.00	1.00
08/20/2026 02:00	1.5	2.0	0.0	1.7	14.3	355.0	0.00	1.00
08/20/2026 03:00	1.5	2.0	0.0	1.7	14.2	354.2	0.00	1.00
08/20/2026 04:00	1.5	2.0	0.0	1.7	14.2	354.3	0.00	1.00
08/20/2026 05:00	1.5	2.0	0.0	1.7	14.2	355.0	0.00	1.00
08/20/2026 06:00	1.5	2.0	0.0	1.7	14.2	358.1	0.00	1.00
08/20/2026 07:00	1.5	2.0	0.0	1.7	14.2	356.2	0.00	1.00
08/20/2026 08:00	1.5	2.0	0.0	1.7	14.2	355.6	0.00	1.00
08/20/2026 09:00	1.5	2.0	0.0	1.7	14.3	355.2	0.00	1.00
08/20/2026 10:00	1.5	2.0	0.0	1.7	14.3	355.4	0.00	1.00
08/20/2026 11:00	1.5	2.0	0.0	1.7	14.3	358.7	0.00	1.00
08/20/2026 12:00	1.5	2.2	0.0	1.7	14.4	382.0	0.00	1.00
08/20/2026 13:00	1.5	3.0	0.0	2.1	12.9	525.8	0.00	1.00
08/20/2026 14:00	1.5	3.0	0.0	2.1	12.8	533.9	0.00	1.00
08/20/2026 15:00	1.5	3.0	0.0	2.1	12.5	534.8	0.00	1.00
08/20/2026 16:00	1.5	3.1	0.0	2.2	12.4	549.8	0.00	1.00
08/20/2026 17:00	1.5	3.5	0.0	2.3	12.0	628.2	0.00	1.00
08/20/2026 18:00	1.5	3.3	0.0	2.2	12.3	606.8	0.00	1.00
08/20/2026 19:00	1.5	3.4	0.0	2.2	12.3	607.0	0.00	1.00
08/20/2026 20:00	1.5	3.1	0.0	2.0	12.9	560.7	0.00	1.00
08/20/2026 21:00	1.5	2.4	0.0	1.6	14.4	428.9	0.00	1.00
08/20/2026 22:00	1.5	2.4	0.0	1.7	14.4	429.5	0.00	1.00
08/20/2026 23:00	1.5	2.4	0.0	1.7	14.4	429.5	0.00	1.00
Average/Sum#:	1.5	2.5	0.0	1.8	13.7	438.5	0.00 #	24.00 #
Minimum:	1.5	2.0	0.0	1.6	12.0	354.2	0.00	1.00
Maximum:	1.5	3.5	0.0	2.3	14.4	628.2	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/21/2026 00:00	1.5	2.4	0.0	1.7	14.3	429.5	0.00	1.00
08/21/2026 01:00	1.5	2.0	0.0	1.7	14.2	370.0	0.00	1.00
08/21/2026 02:00	1.5	2.2	0.0	1.7	14.2	389.3	0.00	1.00
08/21/2026 03:00	1.5	2.1	0.0	1.7	14.2	362.2	0.00	1.00
08/21/2026 04:00	1.5	2.0	0.0	1.7	14.2	360.6	0.00	1.00
08/21/2026 05:00	1.5	2.4	0.0	1.7	14.3	431.5	0.00	1.00
08/21/2026 06:00	1.5	2.1	0.0	1.7	14.2	383.1	0.00	1.00
08/21/2026 07:00	1.5	2.0	0.0	1.7	14.2	356.4	0.00	1.00
08/21/2026 08:00	1.5	2.0	0.0	1.7	14.2	356.3	0.00	1.00
08/21/2026 09:00	1.5	2.0	0.0	1.7	14.2	356.3	0.00	1.00
08/21/2026 10:00	1.5	2.0	0.0	1.7	14.3	356.1	0.00	1.00
08/21/2026 11:00	1.5	2.0	0.0	1.7	14.3	356.5	0.00	1.00
08/21/2026 12:00	1.5	2.1	0.0	1.7	14.4	381.7	0.00	1.00
08/21/2026 13:00	1.5	2.9	0.0	2.0	13.1	518.1	0.00	1.00
08/21/2026 14:00	1.5	2.9	0.0	2.1	12.6	530.1	0.00	1.00
08/21/2026 15:00	1.5	3.0	0.0	2.1	12.6	529.6	0.00	1.00
08/21/2026 16:00	1.5	3.1	0.0	2.2	12.4	542.7	0.00	1.00
08/21/2026 17:00	1.5	3.2	0.0	2.3	12.1	580.1	0.00	1.00
08/21/2026 18:00	1.5	2.7	0.0	1.8	13.6	497.8	0.00	1.00
08/21/2026 19:00	1.5	2.7	0.0	1.8	13.9	491.6	0.00	1.00
08/21/2026 20:00	1.5	2.8	0.0	1.8	13.8	493.5	0.00	1.00
08/21/2026 21:00	1.5	2.0	0.0	1.7	14.3	359.9	0.00	1.00
08/21/2026 22:00	1.5	2.0	0.0	1.7	14.3	354.9	0.00	1.00
08/21/2026 23:00	1.5	2.3	0.0	1.7	14.3	403.7	0.00	1.00
Average/Sum#:	1.5	2.4	0.0	1.8	13.8	424.6	0.00 #	24.00 #
Minimum:	1.5	2.0	0.0	1.7	12.1	354.9	0.00	1.00
Maximum:	1.5	3.2	0.0	2.3	14.4	580.1	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/22/2026 00:00	1.5	2.2	0.0	1.7	14.3	397.2	0.00	1.00
08/22/2026 01:00	1.5	2.1	0.0	1.7	14.3	388.2	0.00	1.00
08/22/2026 02:00	1.5	2.0	0.0	1.7	14.2	354.6	0.00	1.00
08/22/2026 03:00	1.5	2.0	0.0	1.7	14.2	354.9	0.00	1.00
08/22/2026 04:00	1.5	2.2	0.0	1.7	14.2	384.3	0.00	1.00
08/22/2026 05:00	1.5	1.9	0.0	1.7	14.2	356.8	0.00	1.00
08/22/2026 06:00	1.5	2.0	0.0	1.7	14.2	356.2	0.00	1.00
08/22/2026 07:00	1.5	2.0	0.0	1.7	14.2	356.7	0.00	1.00
08/22/2026 08:00	1.5	2.0	0.0	1.7	14.2	355.8	0.00	1.00
08/22/2026 09:00	1.5	2.0	0.0	1.7	14.3	355.7	0.00	1.00
08/22/2026 10:00	1.5	2.0	0.0	1.7	14.3	355.7	0.00	1.00
08/22/2026 11:00	1.5	2.0	0.0	1.7	14.4	356.0	0.00	1.00
08/22/2026 12:00	1.5	2.1	0.0	1.7	14.4	380.4	0.00	1.00
08/22/2026 13:00	1.5	2.8	0.0	1.8	13.8	496.6	0.00	1.00
08/22/2026 14:00	1.5	2.8	0.0	1.8	13.8	498.3	0.00	1.00
08/22/2026 15:00	1.5	2.8	0.0	1.8	13.8	497.5	0.00	1.00
08/22/2026 16:00	1.5	2.8	0.0	1.8	13.7	499.2	0.00	1.00
08/22/2026 17:00	1.5	2.9	0.0	2.0	12.9	524.7	0.00	1.00
08/22/2026 18:00	1.5	2.9	0.0	2.0	12.9	522.3	0.00	1.00
08/22/2026 19:00	1.5	2.8	0.0	2.0	13.3	513.0	0.00	1.00
08/22/2026 20:00	1.5	2.8	0.0	1.9	13.6	505.2	0.00	1.00
08/22/2026 21:00	1.5	2.0	0.0	1.6	14.3	365.3	0.00	1.00
08/22/2026 22:00	1.5	2.0	0.0	1.7	14.3	353.9	0.00	1.00
08/22/2026 23:00	1.5	2.0	0.0	1.7	14.3	354.4	0.00	1.00
Average/Sum#:	1.5	2.3	0.0	1.8	14.0	411.8	0.00 #	24.00 #
Minimum:	1.5	1.9	0.0	1.6	12.9	353.9	0.00	1.00
Maximum:	1.5	2.9	0.0	2.0	14.4	524.7	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/23/2026 00:00	1.5	2.1	0.0	1.7	14.3	382.3	0.00	1.00
08/23/2026 01:00	1.5	2.0	0.0	1.7	14.3	355.6	0.00	1.00
08/23/2026 02:00	1.5	2.0	0.0	1.7	14.2	354.4	0.00	1.00
08/23/2026 03:00	1.5	2.0	0.0	1.7	14.2	354.7	0.00	1.00
08/23/2026 04:00	1.5	2.0	0.0	1.7	14.2	355.3	0.00	1.00
08/23/2026 05:00	1.5	2.0	0.0	1.7	14.2	355.5	0.00	1.00
08/23/2026 06:00	1.5	2.0	0.0	1.7	14.2	355.4	0.00	1.00
08/23/2026 07:00	1.5	2.0	0.0	1.7	14.2	355.7	0.00	1.00
08/23/2026 08:00	1.5	2.0	0.0	1.7	14.3	355.3	0.00	1.00
08/23/2026 09:00	1.5	2.0	0.0	1.7	14.3	355.0	0.00	1.00
08/23/2026 10:00	1.5	2.0	0.0	1.7	14.3	354.8	0.00	1.00
08/23/2026 11:00	1.5	2.0	0.0	1.7	14.4	355.4	0.00	1.00
08/23/2026 12:00	1.5	2.1	0.0	1.7	14.4	380.6	0.00	1.00
08/23/2026 13:00	1.5	2.8	0.0	1.9	13.6	499.3	0.00	1.00
08/23/2026 14:00	1.5	3.0	0.0	2.2	12.5	531.6	0.00	1.00
08/23/2026 15:00	1.5	3.1	0.0	2.1	12.6	556.1	0.00	1.00
08/23/2026 16:00	1.5	3.2	0.0	2.1	12.8	571.4	0.00	1.00
08/23/2026 17:00	1.5	3.5	0.0	2.3	12.1	619.6	0.00	1.00
08/23/2026 18:00	1.5	3.3	0.0	2.2	12.2	612.0	0.00	1.00
08/23/2026 19:00	1.5	3.2	0.0	2.1	12.7	578.5	0.00	1.00
08/23/2026 20:00	1.5	3.1	0.0	2.0	12.9	556.0	0.00	1.00
08/23/2026 21:00	1.5	2.4	0.0	1.7	14.4	432.1	0.00	1.00
08/23/2026 22:00	1.5	2.4	0.0	1.7	14.3	431.6	0.00	1.00
08/23/2026 23:00	1.5	2.4	0.0	1.7	14.3	432.0	0.00	1.00
Average/Sum#:	1.5	2.4	0.0	1.8	13.7	437.1	0.00 #	24.00 #
Minimum:	1.5	2.0	0.0	1.7	12.1	354.4	0.00	1.00
Maximum:	1.5	3.5	0.0	2.3	14.4	619.6	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/24/2026 00:00	1.5	2.4	0.0	1.7	14.3	431.4	0.00	1.00
08/24/2026 01:00	1.5	2.4	0.0	1.6	14.4	430.0	0.00	1.00
08/24/2026 02:00	1.5	2.4	0.0	1.6	14.4	430.8	0.00	1.00
08/24/2026 03:00	1.5	2.3	0.0	1.6	14.4	422.0	0.00	1.00
08/24/2026 04:00	1.5	2.4	0.0	1.7	14.4	426.8	0.00	1.00
08/24/2026 05:00	1.5	2.0	0.0	1.7	14.2	358.8	0.00	1.00
08/24/2026 06:00	1.5	2.2	0.0	1.7	14.3	389.1	0.00	1.00
08/24/2026 07:00	1.5	2.1	0.0	1.7	14.3	370.5	0.00	1.00
08/24/2026 08:00	1.5	2.0	0.0	1.7	14.3	355.2	0.00	1.00
08/24/2026 09:00	1.5	2.0	0.0	1.7	14.3	355.0	0.00	1.00
08/24/2026 10:00	1.5	2.0	0.0	1.7	14.4	354.7	0.00	1.00
08/24/2026 11:00	1.5	2.0	0.0	1.7	14.4	355.5	0.00	1.00
08/24/2026 12:00	1.5	2.1	0.0	1.6	14.4	382.6	0.00	1.00
08/24/2026 13:00	1.5	3.0	0.0	2.1	12.8	532.9	0.00	1.00
08/24/2026 14:00	1.5	3.4	0.0	2.3	12.2	593.5	0.00	1.00
08/24/2026 15:00	1.5	3.5	0.0	2.3	12.1	621.6	0.00	1.00
08/24/2026 16:00	1.5	3.3	0.0	2.2	12.5	594.7	0.00	1.00
08/24/2026 17:00	1.5	3.5	0.0	2.2	12.1	621.3	0.00	1.00
08/24/2026 18:00	1.5	3.5	0.0	2.2	12.1	624.5	0.00	1.00
08/24/2026 19:00	1.5	3.4	0.0	2.2	12.1	621.4	0.00	1.00
08/24/2026 20:00	1.5	3.0	0.0	2.0	13.1	548.3	0.00	1.00
08/24/2026 21:00	1.5	2.4	0.0	1.6	14.5	430.6	0.00	1.00
08/24/2026 22:00	1.5	2.4	0.0	1.7	14.4	430.6	0.00	1.00
08/24/2026 23:00	1.5	2.3	0.0	1.7	14.4	417.2	0.00	1.00
Average/Sum#:	1.5	2.6	0.0	1.8	13.7	462.5	0.00 #	24.00 #
Minimum:	1.5	2.0	0.0	1.6	12.1	354.7	0.00	1.00
Maximum:	1.5	3.5	0.0	2.3	14.5	624.5	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/25/2026 00:00	1.5	2.2	0.0	1.7	14.3	396.7	0.00	1.00
08/25/2026 01:00	1.5	2.0	0.0	1.7	14.2	360.3	0.00	1.00
08/25/2026 02:00	1.5	1.9	0.0	1.7	14.2	356.6	0.00	1.00
08/25/2026 03:00	1.5	2.0	0.0	1.7	14.2	357.0	0.00	1.00
08/25/2026 04:00	1.5	2.2	0.0	1.7	14.3	393.7	0.00	1.00
08/25/2026 05:00	1.5	2.0	0.0	1.7	14.2	375.0	0.00	1.00
08/25/2026 06:00	1.5	2.1	0.0	1.7	14.2	379.6	0.00	1.00
08/25/2026 07:00	1.5	2.0	0.0	1.7	14.2	357.3	0.00	1.00
08/25/2026 08:00	1.5	2.0	0.0	1.7	14.2	356.8	0.00	1.00
08/25/2026 09:00	1.5	2.0	0.0	1.7	14.3	356.2	0.00	1.00
08/25/2026 10:00	1.5	2.0	0.0	1.7	14.3	356.0	0.00	1.00
08/25/2026 11:00	1.5	2.2	0.0	1.7	14.4	393.4	0.00	1.00
08/25/2026 12:00	1.5	2.3	0.0	1.6	14.4	420.3	0.00	1.00
08/25/2026 13:00	1.5	2.4	0.0	1.7	14.4	432.7	0.00	1.00
08/25/2026 14:00	1.5	3.0	0.0	1.9	13.4	528.5	0.00	1.00
08/25/2026 15:00	1.5	2.8	0.0	1.8	13.7	508.5	0.00	1.00
08/25/2026 16:00	1.5	3.2	0.0	2.1	12.8	568.4	0.00	1.00
08/25/2026 17:00	1.5	3.5	0.0	2.3	12.0	631.5	0.00	1.00
08/25/2026 18:00	1.5	3.5	0.0	2.2	12.0	630.3	0.00	1.00
08/25/2026 19:00	1.5	3.3	0.0	2.1	12.5	596.2	0.00	1.00
08/25/2026 20:00	1.5	3.0	0.0	1.9	13.3	535.6	0.00	1.00
08/25/2026 21:00	1.5	2.9	0.0	1.9	13.3	522.4	0.00	1.00
08/25/2026 22:00	1.5	2.1	0.0	1.6	14.4	384.8	0.00	1.00
08/25/2026 23:00	1.5	2.0	0.0	1.7	14.3	355.3	0.00	1.00
Average/Sum#:	1.5	2.4	0.0	1.8	13.8	439.7	0.00 #	24.00 #
Minimum:	1.5	1.9	0.0	1.6	12.0	355.3	0.00	1.00
Maximum:	1.5	3.5	0.0	2.3	14.4	631.5	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/26/2026 00:00	1.5	2.0	0.0	1.7	14.3	361.5	0.00	1.00
08/26/2026 01:00	1.5	2.0	0.0	1.7	14.3	355.2	0.00	1.00
08/26/2026 02:00	1.5	2.1	0.0	1.7	14.3	379.9	0.00	1.00
08/26/2026 03:00	1.5	1.9	0.0	1.7	14.2	355.9	0.00	1.00
08/26/2026 04:00	1.5	2.3	0.0	1.7	14.3	398.5	0.00	1.00
08/26/2026 05:00	1.5	2.4	0.0	1.7	14.4	430.8	0.00	1.00
08/26/2026 06:00	1.5	2.1	0.0	1.7	14.3	389.2	0.00	1.00
08/26/2026 07:00	1.5	2.0	0.0	1.7	14.2	356.9	0.00	1.00
08/26/2026 08:00	1.5	2.0	0.0	1.7	14.3	356.1	0.00	1.00
08/26/2026 09:00	1.5	2.0	0.0	1.7	14.3	355.7	0.00	1.00
08/26/2026 10:00	1.5	2.0	0.0	1.7	14.4	355.6	0.00	1.00
08/26/2026 11:00	1.5	2.4	0.0	1.7	14.4	430.5	0.00	1.00
08/26/2026 12:00	1.5	2.4	0.0	1.7	14.4	427.5	0.00	1.00
08/26/2026 13:00	1.5	2.9	0.0	1.9	13.4	518.4	0.00	1.00
08/26/2026 14:00	1.5	3.0	0.0	2.1	12.7	528.7	0.00	1.00
08/26/2026 15:00	1.5	3.0	0.0	2.1	12.5	532.3	0.00	1.00
08/26/2026 16:00	1.5	3.0	0.0	2.2	12.5	533.5	0.00	1.00
08/26/2026 17:00	1.5	3.2	0.0	2.1	12.6	573.1	0.00	1.00
08/26/2026 18:00	1.5	2.9	0.0	1.9	13.2	532.6	0.00	1.00
08/26/2026 19:00	1.5	3.1	0.0	2.1	12.9	546.5	0.00	1.00
08/26/2026 20:00	1.5	3.0	0.0	2.0	13.1	537.7	0.00	1.00
08/26/2026 21:00	1.5	2.3	0.0	1.6	14.5	428.9	0.00	1.00
08/26/2026 22:00	1.5	2.0	0.0	1.6	14.3	362.2	0.00	1.00
08/26/2026 23:00	1.5	2.2	0.0	1.6	14.4	400.2	0.00	1.00
Average/Sum#:	1.5	2.4	0.0	1.8	13.8	435.3	0.00 #	24.00 #
Minimum:	1.5	1.9	0.0	1.6	12.5	355.2	0.00	1.00
Maximum:	1.5	3.2	0.0	2.2	14.5	573.1	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/27/2026 00:00	1.5	2.1	0.0	1.7	14.3	377.2	0.00	1.00
08/27/2026 01:00	1.5	2.0	0.0	1.7	14.3	355.1	0.00	1.00
08/27/2026 02:00	1.5	2.0	0.0	1.7	14.3	355.0	0.00	1.00
08/27/2026 03:00	1.5	2.0	0.0	1.7	14.3	355.1	0.00	1.00
08/27/2026 04:00	1.5	2.0	0.0	1.7	14.3	355.9	0.00	1.00
08/27/2026 05:00	1.5	2.2	0.0	1.7	14.3	389.6	0.00	1.00
08/27/2026 06:00	1.5	2.2	0.0	1.7	14.3	400.4	0.00	1.00
08/27/2026 07:00	1.5	2.4	0.0	1.7	14.4	433.5	0.00	1.00
08/27/2026 08:00	1.5	2.4	0.0	1.7	14.5	432.4	0.00	1.00
08/27/2026 09:00	1.5	2.4	0.0	1.6	14.5	431.7	0.00	1.00
08/27/2026 10:00	1.5	2.4	0.0	1.6	14.5	433.0	0.00	1.00
08/27/2026 11:00	1.5	2.4	0.0	1.7	14.4	433.7	0.00	1.00
08/27/2026 12:00	1.5	2.4	0.0	1.7	14.4	432.5	0.00	1.00
08/27/2026 13:00	1.6	3.4	0.0	2.2	12.6	589.3	0.00	1.00
08/27/2026 14:00	1.5	3.4	0.0	2.2	12.2	613.8	0.00	1.00
08/27/2026 15:00	1.5	2.8	0.0	1.9	13.4	519.1	0.00	1.00
08/27/2026 16:00	1.5	2.9	0.0	1.9	13.3	529.4	0.00	1.00
08/27/2026 17:00	1.5	2.8	0.0	1.8	13.7	499.7	0.00	1.00
08/27/2026 18:00	1.5	2.9	0.0	2.0	13.2	515.3	0.00	1.00
08/27/2026 19:00	1.5	2.9	0.0	2.0	13.2	515.7	0.00	1.00
08/27/2026 20:00	1.5	3.0	0.0	2.1	12.7	543.4	0.00	1.00
08/27/2026 21:00	1.5	2.4	0.0	1.6	14.5	428.8	0.00	1.00
08/27/2026 22:00	1.5	2.4	0.0	1.6	14.5	432.2	0.00	1.00
08/27/2026 23:00	1.5	3.2	0.0	2.1	12.9	558.3	0.00	1.00
Average/Sum#:	1.5	2.5	0.0	1.8	13.9	455.4	0.00 #	24.00 #
Minimum:	1.5	2.0	0.0	1.6	12.2	355.0	0.00	1.00
Maximum:	1.6	3.4	0.0	2.2	14.5	613.8	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/28/2026 00:00	1.5	2.9	0.0	1.9	13.5	520.2	0.00	1.00
08/28/2026 01:00	1.5	2.8	0.0	1.9	13.6	511.2	0.00	1.00
08/28/2026 02:00	1.5	2.7	0.0	1.8	13.8	498.2	0.00	1.00
08/28/2026 03:00	1.5	2.9	0.0	1.9	13.6	509.3	0.00	1.00
08/28/2026 04:00	1.5	3.1	0.0	2.0	13.2	549.6	0.00	1.00
08/28/2026 05:00	1.5	3.5	0.0	2.2	12.3	617.6	0.00	1.00
08/28/2026 06:00	1.5	3.3	0.0	2.1	12.5	599.9	0.00	1.00
08/28/2026 07:00	1.5	3.4	0.0	2.2	12.3	617.8	0.00	1.00
08/28/2026 08:00	1.5	2.9	0.0	1.9	13.5	527.9	0.00	1.00
08/28/2026 09:00	1.5	2.8	0.0	1.8	13.8	501.3	0.00	1.00
08/28/2026 10:00	1.5	2.9	0.0	1.9	13.6	514.2	0.00	1.00
08/28/2026 11:00	1.5	2.9	0.0	1.9	13.4	522.5	0.00	1.00
08/28/2026 12:00	1.5	2.9	0.0	1.9	13.4	518.3	0.00	1.00
08/28/2026 13:00	1.5	2.8	0.0	1.9	13.5	510.1	0.00	1.00
08/28/2026 14:00	1.5	2.8	0.0	1.9	13.3	513.1	0.00	1.00
08/28/2026 15:00	1.5	2.9	0.0	1.9	13.4	513.5	0.00	1.00
08/28/2026 16:00	1.5	2.8	0.0	1.9	13.5	510.4	0.00	1.00
08/28/2026 17:00	1.5	2.8	0.0	1.9	13.6	506.4	0.00	1.00
08/28/2026 18:00	1.5	2.8	0.0	1.9	13.6	507.5	0.00	1.00
08/28/2026 19:00	1.5	2.8	0.0	1.8	13.7	499.8	0.00	1.00
08/28/2026 20:00	1.5	2.8	0.0	1.8	13.8	497.5	0.00	1.00
08/28/2026 21:00	1.5	2.7	0.0	1.8	13.8	494.1	0.00	1.00
08/28/2026 22:00	1.5	2.7	0.0	1.8	13.9	492.5	0.00	1.00
08/28/2026 23:00	1.5	2.7	0.0	1.8	13.9	491.8	0.00	1.00
Average/Sum#:	1.5	2.9	0.0	1.9	13.4	522.7	0.00 #	24.00 #
Minimum:	1.5	2.7	0.0	1.8	12.3	491.8	0.00	1.00
Maximum:	1.5	3.5	0.0	2.2	13.9	617.8	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/29/2026 00:00	1.5	2.7	0.0	1.8	13.9	490.5	0.00	1.00
08/29/2026 01:00	1.5	2.7	0.0	1.8	13.9	490.8	0.00	1.00
08/29/2026 02:00	1.5	2.7	0.0	1.8	14.0	489.7	0.00	1.00
08/29/2026 03:00	1.5	2.7	0.0	1.8	14.0	488.8	0.00	1.00
08/29/2026 04:00	1.5	2.7	0.0	1.8	14.0	487.6	0.00	1.00
08/29/2026 05:00	1.5	2.7	0.0	1.7	14.1	486.1	0.00	1.00
08/29/2026 06:00	1.5	2.7	0.0	1.7	14.1	487.9	0.00	1.00
08/29/2026 07:00	1.5	2.7	0.0	1.8	14.0	491.1	0.00	1.00
08/29/2026 08:00	1.5	2.8	0.0	1.8	14.0	492.4	0.00	1.00
08/29/2026 09:00	1.5	2.8	0.0	1.8	13.9	495.7	0.00	1.00
08/29/2026 10:00	1.5	2.8	0.0	1.8	13.8	500.7	0.00	1.00
08/29/2026 11:00	1.5	2.8	0.0	1.8	13.7	506.0	0.00	1.00
08/29/2026 12:00	1.5	2.8	0.0	1.9	13.5	512.1	0.00	1.00
08/29/2026 13:00	1.5	2.9	0.0	1.9	13.3	516.6	0.00	1.00
08/29/2026 14:00	1.5	2.9	0.0	2.0	13.1	519.7	0.00	1.00
08/29/2026 15:00	1.5	2.8	0.0	1.9	13.5	504.2	0.00	1.00
08/29/2026 16:00	1.5	2.8	0.0	1.8	13.9	494.8	0.00	1.00
08/29/2026 17:00	1.5	2.9	0.0	1.9	13.6	519.5	0.00	1.00
08/29/2026 18:00	1.5	2.8	0.0	1.8	13.7	498.6	0.00	1.00
08/29/2026 19:00	1.5	2.8	0.0	1.8	13.7	498.8	0.00	1.00
08/29/2026 20:00	1.5	2.8	0.0	1.8	13.8	497.5	0.00	1.00
08/29/2026 21:00	1.5	2.7	0.0	1.8	13.8	495.1	0.00	1.00
08/29/2026 22:00	1.5	2.7	0.0	1.8	13.9	493.4	0.00	1.00
08/29/2026 23:00	1.5	2.7	0.0	1.8	13.9	491.7	0.00	1.00
Average/Sum#:	1.5	2.8	0.0	1.8	13.8	497.9	0.00 #	24.00 #
Minimum:	1.5	2.7	0.0	1.7	13.1	486.1	0.00	1.00
Maximum:	1.5	2.9	0.0	2.0	14.1	519.7	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/30/2026 00:00	1.5	2.8	0.0	1.8	14.0	489.8	0.00	1.00
08/30/2026 01:00	1.5	2.7	0.0	1.8	14.0	488.1	0.00	1.00
08/30/2026 02:00	1.5	2.7	0.0	1.8	14.0	489.7	0.00	1.00
08/30/2026 03:00	1.5	2.7	0.0	1.8	14.1	488.3	0.00	1.00
08/30/2026 04:00	1.5	2.7	0.0	1.7	14.1	487.5	0.00	1.00
08/30/2026 05:00	1.5	2.7	0.0	1.7	14.1	486.7	0.00	1.00
08/30/2026 06:00	1.5	2.7	0.0	1.7	14.1	488.8	0.00	1.00
08/30/2026 07:00	1.5	2.7	0.0	1.8	14.0	492.0	0.00	1.00
08/30/2026 08:00	1.5	2.8	0.0	1.8	14.0	494.6	0.00	1.00
08/30/2026 09:00	1.5	2.8	0.0	1.8	13.9	498.1	0.00	1.00
08/30/2026 10:00	1.5	2.8	0.0	1.8	13.7	503.1	0.00	1.00
08/30/2026 11:00	1.5	2.8	0.0	1.9	13.6	508.1	0.00	1.00
08/30/2026 12:00	1.5	2.9	0.0	1.9	13.5	513.5	0.00	1.00
08/30/2026 13:00	1.5	2.9	0.0	1.9	13.3	516.1	0.00	1.00
08/30/2026 14:00	1.5	2.9	0.0	2.0	13.3	516.7	0.00	1.00
08/30/2026 15:00	1.5	2.9	0.0	2.0	13.2	519.1	0.00	1.00
08/30/2026 16:00	1.5	2.9	0.0	2.0	13.0	527.8	0.00	1.00
08/30/2026 17:00	1.5	3.1	0.0	2.1	12.7	551.3	0.00	1.00
08/30/2026 18:00	1.5	2.8	0.0	1.9	13.4	511.9	0.00	1.00
08/30/2026 19:00	1.5	2.8	0.0	1.8	13.7	501.4	0.00	1.00
08/30/2026 20:00	1.5	2.8	0.0	1.8	13.8	498.3	0.00	1.00
08/30/2026 21:00	1.5	2.8	0.0	1.8	13.8	496.2	0.00	1.00
08/30/2026 22:00	1.5	2.7	0.0	1.8	13.8	493.7	0.00	1.00
08/30/2026 23:00	1.5	2.7	0.0	1.8	13.9	493.0	0.00	1.00
Average/Sum#:	1.5	2.8	0.0	1.8	13.7	502.2	0.00 #	24.00 #
Minimum:	1.5	2.7	0.0	1.7	12.7	486.7	0.00	1.00
Maximum:	1.5	3.1	0.0	2.1	14.1	551.3	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
08/31/2026 00:00	1.5	2.7	0.0	1.8	14.0	491.1	0.00	1.00
08/31/2026 01:00	1.5	2.7	0.0	1.8	14.0	489.2	0.00	1.00
08/31/2026 02:00	1.5	2.7	0.0	1.7	14.0	488.6	0.00	1.00
08/31/2026 03:00	1.5	2.7	0.0	1.8	14.0	488.6	0.00	1.00
08/31/2026 04:00	1.5	2.7	0.0	1.7	14.1	487.3	0.00	1.00
08/31/2026 05:00	1.5	2.4	0.0	1.7	14.2	434.6	0.00	1.00
08/31/2026 06:00	1.5	2.0	0.0	1.7	14.2	357.8	0.00	1.00
08/31/2026 07:00	1.5	2.0	0.0	1.7	14.2	357.8	0.00	1.00
08/31/2026 08:00	1.5	2.0	0.0	1.7	14.2	357.1	0.00	1.00
08/31/2026 09:00	1.5	2.0	0.0	1.7	14.2	356.9	0.00	1.00
08/31/2026 10:00	1.5	2.0	0.0	1.7	14.3	356.8	0.00	1.00
08/31/2026 11:00	1.5	2.0	0.0	1.7	14.3	357.2	0.00	1.00
08/31/2026 12:00	1.5	2.2	0.0	1.7	14.4	382.0	0.00	1.00
08/31/2026 13:00	1.5	2.8	0.0	1.9	13.7	503.8	0.00	1.00
08/31/2026 14:00	1.5	2.8	0.0	1.8	13.7	500.8	0.00	1.00
08/31/2026 15:00	1.5	2.8	0.0	1.8	13.7	500.0	0.00	1.00
08/31/2026 16:00	1.5	2.8	0.0	1.8	13.8	499.1	0.00	1.00
08/31/2026 17:00	1.5	2.8	0.0	1.8	13.8	496.4	0.00	1.00
08/31/2026 18:00	1.5	2.8	0.0	1.8	13.9	493.0	0.00	1.00
08/31/2026 19:00	1.5	2.8	0.0	1.8	14.0	492.0	0.00	1.00
08/31/2026 20:00	1.5	2.7	0.0	1.8	14.0	489.8	0.00	1.00
08/31/2026 21:00	1.5	2.2	0.0	1.7	14.1	400.6	0.00	1.00
08/31/2026 22:00	1.5	2.0	0.0	1.7	14.2	357.4	0.00	1.00
08/31/2026 23:00	1.5	2.1	0.0	1.7	14.2	381.7	0.00	1.00
Average/Sum#:	1.5	2.4	0.0	1.8	14.1	438.3	0.00 #	24.00 #
Minimum:	1.5	2.0	0.0	1.7	13.7	356.8	0.00	1.00
Maximum:	1.5	2.8	0.0	1.9	14.4	503.8	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/01/2026 00:00	1.5	2.1	0.0	1.7	14.2	381.1	0.00	1.00
09/01/2026 01:00	1.5	2.0	0.0	1.7	14.2	356.4	0.00	1.00
09/01/2026 02:00	1.5	2.0	0.0	1.7	14.2	356.2	0.00	1.00
09/01/2026 03:00	1.5	2.0	0.0	1.7	14.2	356.1	0.00	1.00
09/01/2026 04:00	1.5	2.0	0.0	1.7	14.2	356.0	0.00	1.00
09/01/2026 05:00	1.5	2.0	0.0	1.7	14.2	356.1	0.00	1.00
09/01/2026 06:00	1.5	2.0	0.0	1.7	14.2	356.1	0.00	1.00
09/01/2026 07:00	1.5	2.0	0.0	1.7	14.2	355.8	0.00	1.00
09/01/2026 08:00	1.5	2.0	0.0	1.7	14.2	355.8	0.00	1.00
09/01/2026 09:00	1.5	2.0	0.0	1.7	14.2	355.3	0.00	1.00
09/01/2026 10:00	1.5	2.0	0.0	1.7	14.3	355.2	0.00	1.00
09/01/2026 11:00	1.5	2.0	0.0	1.7	14.3	355.0	0.00	1.00
09/01/2026 12:00	1.5	2.0	0.0	1.7	14.3	354.5	0.00	1.00
09/01/2026 13:00	1.5	2.0	0.0	1.7	14.3	353.5	0.00	1.00
09/01/2026 14:00	1.5	2.0	0.0	1.7	14.3	353.2	0.00	1.00
09/01/2026 15:00	1.5	2.0	0.0	1.7	14.3	353.1	0.00	1.00
09/01/2026 16:00	1.5	2.0	0.0	1.7	14.3	353.0	0.00	1.00
09/01/2026 17:00	1.5	2.1	0.0	1.7	14.3	367.7	0.00	1.00
09/01/2026 18:00	1.5	2.0	0.0	1.7	14.3	353.7	0.00	1.00
09/01/2026 19:00	1.5	2.0	0.0	1.7	14.2	354.0	0.00	1.00
09/01/2026 20:00	1.5	2.0	0.0	1.7	14.2	354.8	0.00	1.00
09/01/2026 21:00	1.5	2.0	0.0	1.7	14.2	355.4	0.00	1.00
09/01/2026 22:00	1.5	2.0	0.0	1.7	14.2	355.6	0.00	1.00
09/01/2026 23:00	1.5	2.0	0.0	1.7	14.2	356.1	0.00	1.00
Average/Sum#:	1.5	2.0	0.0	1.7	14.2	356.7	0.00 #	24.00 #
Minimum:	1.5	2.0	0.0	1.7	14.2	353.0	0.00	1.00
Maximum:	1.5	2.1	0.0	1.7	14.3	381.1	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/02/2026 00:00	1.5	2.0	0.0	1.7	14.2	356.5	0.00	1.00
09/02/2026 01:00	1.5	2.0	0.0	1.7	14.2	356.6	0.00	1.00
09/02/2026 02:00	1.5	2.0	0.0	1.7	14.2	356.7	0.00	1.00
09/02/2026 03:00	1.5	2.0	0.0	1.7	14.2	356.9	0.00	1.00
09/02/2026 04:00	1.5	2.0	0.0	1.7	14.2	357.1	0.00	1.00
09/02/2026 05:00	1.5	2.0	0.0	1.7	14.2	356.9	0.00	1.00
09/02/2026 06:00	1.5	2.0	0.0	1.7	14.2	356.8	0.00	1.00
09/02/2026 07:00	1.5	2.0	0.0	1.7	14.2	356.6	0.00	1.00
09/02/2026 08:00	1.5	2.0	0.0	1.7	14.2	356.5	0.00	1.00
09/02/2026 09:00	1.5	2.0	0.0	1.7	14.2	356.1	0.00	1.00
09/02/2026 10:00	1.5	2.0	0.0	1.7	14.3	355.8	0.00	1.00
09/02/2026 11:00	1.5	2.0	0.0	1.7	14.3	354.9	0.00	1.00
09/02/2026 12:00	1.5	2.0	0.0	1.7	14.3	353.9	0.00	1.00
09/02/2026 13:00	1.5	2.0	0.0	1.7	14.3	353.4	0.00	1.00
09/02/2026 14:00	1.5	2.0	0.0	1.7	14.3	353.1	0.00	1.00
09/02/2026 15:00	1.5	2.0	0.0	1.7	14.3	352.9	0.00	1.00
09/02/2026 16:00	1.5	2.0	0.0	1.7	14.3	356.5	0.00	1.00
09/02/2026 17:00	1.5	2.1	0.0	1.7	14.3	379.3	0.00	1.00
09/02/2026 18:00	1.5	1.9	0.0	1.7	14.3	353.2	0.00	1.00
09/02/2026 19:00	1.5	2.0	0.0	1.7	14.3	352.6	0.00	1.00
09/02/2026 20:00	1.5	2.0	0.0	1.7	14.2	352.7	0.00	1.00
09/02/2026 21:00	1.5	2.0	0.0	1.7	14.2	353.4	0.00	1.00
09/02/2026 22:00	1.5	2.0	0.0	1.7	14.2	353.6	0.00	1.00
09/02/2026 23:00	1.5	2.0	0.0	1.7	14.2	353.8	0.00	1.00
Average/Sum#:	1.5	2.0	0.0	1.7	14.2	356.1	0.00 #	24.00 #
Minimum:	1.5	1.9	0.0	1.7	14.2	352.6	0.00	1.00
Maximum:	1.5	2.1	0.0	1.7	14.3	379.3	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/03/2026 00:00	1.5	2.0	0.0	1.7	14.2	354.2	0.00	1.00
09/03/2026 01:00	1.5	2.0	0.0	1.7	14.2	354.5	0.00	1.00
09/03/2026 02:00	1.5	2.0	0.0	1.7	14.2	354.6	0.00	1.00
09/03/2026 03:00	1.5	2.0	0.0	1.7	14.2	354.7	0.00	1.00
09/03/2026 04:00	1.5	2.0	0.0	1.7	14.2	354.7	0.00	1.00
09/03/2026 05:00	1.5	2.0	0.0	1.7	14.2	355.1	0.00	1.00
09/03/2026 06:00	1.5	2.0	0.0	1.7	14.2	359.3	0.00	1.00
09/03/2026 07:00	1.5	2.1	0.0	1.7	14.2	378.8	0.00	1.00
09/03/2026 08:00	1.5	2.1	0.0	1.7	14.2	375.2	0.00	1.00
09/03/2026 09:00	1.5	2.2	0.0	1.7	14.3	395.3	0.00	1.00
09/03/2026 10:00	1.5	2.1	0.0	1.7	14.2	382.8	0.00	1.00
09/03/2026 11:00	1.5	2.0	0.0	1.7	14.2	354.0	0.00	1.00
09/03/2026 12:00	1.5	2.1	0.0	1.7	14.3	382.0	0.00	1.00
09/03/2026 13:00	1.5	2.4	0.0	1.7	14.4	425.6	0.00	1.00
09/03/2026 14:00	1.5	2.4	0.0	1.7	14.4	427.1	0.00	1.00
09/03/2026 15:00	1.5	2.4	0.0	1.7	14.4	427.0	0.00	1.00
09/03/2026 16:00	1.5	2.1	0.0	1.7	14.2	371.1	0.00	1.00
09/03/2026 17:00	1.5	2.2	0.0	1.7	14.3	397.5	0.00	1.00
09/03/2026 18:00	1.5	2.0	0.0	1.7	14.2	357.2	0.00	1.00
09/03/2026 19:00	1.5	2.1	0.0	1.7	14.2	386.0	0.00	1.00
09/03/2026 20:00	1.5	2.4	0.0	1.7	14.3	428.2	0.00	1.00
09/03/2026 21:00	1.5	2.4	0.0	1.7	14.3	432.2	0.00	1.00
09/03/2026 22:00	1.5	2.4	0.0	1.7	14.3	432.3	0.00	1.00
09/03/2026 23:00	1.5	2.4	0.0	1.7	14.3	427.1	0.00	1.00
Average/Sum#:	1.5	2.2	0.0	1.7	14.3	386.1	0.00 #	24.00 #
Minimum:	1.5	2.0	0.0	1.7	14.2	354.0	0.00	1.00
Maximum:	1.5	2.4	0.0	1.7	14.4	432.3	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/04/2026 00:00	1.5	2.0	0.0	1.7	14.2	372.0	0.00	1.00
09/04/2026 01:00	1.5	1.9	0.0	1.7	14.1	355.3	0.00	1.00
09/04/2026 02:00	1.5	2.0	0.0	1.7	14.2	355.4	0.00	1.00
09/04/2026 03:00	1.5	2.0	0.0	1.7	14.2	355.0	0.00	1.00
09/04/2026 04:00	1.5	2.0	0.0	1.7	14.2	366.5	0.00	1.00
09/04/2026 05:00	1.5	2.4	0.0	1.7	14.3	422.8	0.00	1.00
09/04/2026 06:00	1.5	2.1	0.0	1.7	14.2	374.8	0.00	1.00
09/04/2026 07:00	1.5	2.1	0.0	1.7	14.2	380.1	0.00	1.00
09/04/2026 08:00	1.5	2.0	0.0	1.7	14.2	354.9	0.00	1.00
09/04/2026 09:00	1.5	2.0	0.0	1.7	14.2	354.6	0.00	1.00
09/04/2026 10:00	1.5	2.1	0.0	1.7	14.3	385.1	0.00	1.00
09/04/2026 11:00	1.5	2.0	0.0	1.7	14.2	354.5	0.00	1.00
09/04/2026 12:00	1.5	2.0	0.0	1.7	14.3	354.3	0.00	1.00
09/04/2026 13:00	1.5	2.0	0.0	1.7	14.3	353.6	0.00	1.00
09/04/2026 14:00	1.5	2.0	0.0	1.7	14.3	353.3	0.00	1.00
09/04/2026 15:00	1.5	2.0	0.0	1.7	14.3	353.1	0.00	1.00
09/04/2026 16:00	1.5	2.1	0.0	1.7	14.3	367.9	0.00	1.00
09/04/2026 17:00	1.5	2.1	0.0	1.7	14.4	382.7	0.00	1.00
09/04/2026 18:00	1.5	2.4	0.0	1.7	14.4	428.9	0.00	1.00
09/04/2026 19:00	1.5	2.4	0.0	1.7	14.4	427.7	0.00	1.00
09/04/2026 20:00	1.5	2.4	0.0	1.7	14.4	428.1	0.00	1.00
09/04/2026 21:00	1.5	2.4	0.0	1.7	14.4	429.3	0.00	1.00
09/04/2026 22:00	1.5	2.4	0.0	1.7	14.4	428.5	0.00	1.00
09/04/2026 23:00	1.5	2.0	0.0	1.7	14.2	362.6	0.00	1.00
Average/Sum#:	1.5	2.1	0.0	1.7	14.3	379.2	0.00 #	24.00 #
Minimum:	1.5	1.9	0.0	1.7	14.1	353.1	0.00	1.00
Maximum:	1.5	2.4	0.0	1.7	14.4	429.3	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/05/2026 00:00	1.5	2.1	0.0	1.7	14.2	373.4	0.00	1.00
09/05/2026 01:00	1.5	2.0	0.0	1.7	14.2	371.6	0.00	1.00
09/05/2026 02:00	1.7	2.4	0.0	1.9	14.2	381.9	0.00	1.00
09/05/2026 03:00	1.5	1.9	0.0	1.7	14.2	356.7	0.00	1.00
09/05/2026 04:00	1.5	2.3	0.0	1.7	14.3	406.9	0.00	1.00
09/05/2026 05:00	1.5	2.4	0.0	1.7	14.3	428.4	0.00	1.00
09/05/2026 06:00	1.5	2.0	0.0	1.7	14.1	356.3	0.00	1.00
09/05/2026 07:00	1.4	1.9	0.0	1.6	14.2	355.3	0.02	1.00
09/05/2026 08:00	1.5	2.0	0.0	1.7	14.2	354.6	0.00	1.00
09/05/2026 09:00	1.5	2.0	0.0	1.7	14.2	354.2	0.00	1.00
09/05/2026 10:00	1.5	2.0	0.0	1.7	14.3	353.6	0.00	1.00
09/05/2026 11:00	1.5	2.0	0.0	1.7	14.3	353.5	0.00	1.00
09/05/2026 12:00	1.5	2.0	0.0	1.7	14.3	353.4	0.00	1.00
09/05/2026 13:00	1.5	2.0	0.0	1.7	14.3	353.0	0.00	1.00
09/05/2026 14:00	1.5	2.0	0.0	1.7	14.4	353.2	0.00	1.00
09/05/2026 15:00	1.5	2.0	0.0	1.7	14.3	353.6	0.00	1.00
09/05/2026 16:00	1.5	2.2	0.0	1.7	14.4	382.6	0.00	1.00
09/05/2026 17:00	1.5	2.3	0.0	1.7	14.3	402.6	0.00	1.00
09/05/2026 18:00	1.5	2.0	0.0	1.6	14.3	361.9	0.00	1.00
09/05/2026 19:00	1.5	2.0	0.0	1.7	14.3	367.4	0.00	1.00
09/05/2026 20:00	1.5	2.0	0.0	1.7	14.3	354.7	0.00	1.00
09/05/2026 21:00	1.5	2.1	0.0	1.7	14.3	367.8	0.00	1.00
09/05/2026 22:00	1.5	2.1	0.0	1.7	14.3	370.8	0.00	1.00
09/05/2026 23:00	1.5	2.0	0.0	1.7	14.3	365.1	0.00	1.00
Average/Sum#:	1.5	2.1	0.0	1.7	14.3	368.0	0.02 #	24.00 #
Minimum:	1.4	1.9	0.0	1.6	14.1	353.0	0.00	1.00
Maximum:	1.7	2.4	0.0	1.9	14.4	428.4	0.02	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/06/2026 00:00	1.5	2.0	0.0	1.7	14.2	354.8	0.00	1.00
09/06/2026 01:00	1.5	2.0	0.0	1.7	14.2	358.0	0.00	1.00
09/06/2026 02:00	1.4	2.0	0.0	1.6	14.2	369.4	0.00	1.00
09/06/2026 03:00	1.5	2.0	0.0	1.7	14.2	354.7	0.00	1.00
09/06/2026 04:00	1.5	2.0	0.0	1.7	14.2	358.5	0.00	1.00
09/06/2026 05:00	1.5	2.0	0.0	1.7	14.2	355.7	0.00	1.00
09/06/2026 06:00	1.5	2.1	0.0	1.7	14.2	386.9	0.00	1.00
09/06/2026 07:00	1.5	2.0	0.0	1.7	14.2	354.7	0.00	1.00
09/06/2026 08:00	1.5	2.0	0.0	1.7	14.2	354.0	0.00	1.00
09/06/2026 09:00	1.5	2.0	0.0	1.7	14.2	353.6	0.00	1.00
09/06/2026 10:00	1.5	2.0	0.0	1.7	14.3	353.1	0.00	1.00
09/06/2026 11:00	1.5	2.0	0.0	1.7	14.3	353.0	0.00	1.00
09/06/2026 12:00	1.5	2.0	0.0	1.7	14.3	352.6	0.00	1.00
09/06/2026 13:00	1.5	2.0	0.0	1.7	14.4	351.9	0.00	1.00
09/06/2026 14:00	1.5	2.0	0.0	1.7	14.4	352.9	0.00	1.00
09/06/2026 15:00	1.5	2.2	0.0	1.7	14.5	385.5	0.00	1.00
09/06/2026 16:00	1.5	2.1	0.0	1.7	14.4	372.4	0.00	1.00
09/06/2026 17:00	1.5	1.9	0.0	1.7	14.3	351.8	0.00	1.00
09/06/2026 18:00	1.5	2.0	0.0	1.7	14.3	352.1	0.00	1.00
09/06/2026 19:00	1.5	2.0	0.0	1.7	14.3	352.4	0.00	1.00
09/06/2026 20:00	1.5	2.0	0.0	1.7	14.3	353.2	0.00	1.00
09/06/2026 21:00	1.5	2.0	0.0	1.7	14.3	353.3	0.00	1.00
09/06/2026 22:00	1.5	2.0	0.0	1.7	14.2	354.1	0.00	1.00
09/06/2026 23:00	1.5	2.1	0.0	1.7	14.3	380.1	0.00	1.00
Average/Sum#:	1.5	2.0	0.0	1.7	14.3	359.1	0.00 #	24.00 #
Minimum:	1.4	1.9	0.0	1.6	14.2	351.8	0.00	1.00
Maximum:	1.5	2.2	0.0	1.7	14.5	386.9	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/07/2026 00:00	1.5	2.0	0.0	1.7	14.2	354.9	0.00	1.00
09/07/2026 01:00	1.5	2.0	0.0	1.7	14.2	355.4	0.00	1.00
09/07/2026 02:00	1.5	2.0	0.0	1.7	14.2	355.8	0.00	1.00
09/07/2026 03:00	1.5	2.0	0.0	1.7	14.2	356.2	0.00	1.00
09/07/2026 04:00	1.5	2.0	0.0	1.7	14.2	356.2	0.00	1.00
09/07/2026 05:00	1.5	2.0	0.0	1.7	14.2	356.7	0.00	1.00
09/07/2026 06:00	1.5	2.1	0.0	1.7	14.2	375.5	0.00	1.00
09/07/2026 07:00	1.5	2.0	0.0	1.7	14.2	356.0	0.00	1.00
09/07/2026 08:00	1.5	2.0	0.0	1.7	14.2	354.9	0.00	1.00
09/07/2026 09:00	1.5	2.0	0.0	1.7	14.3	354.1	0.00	1.00
09/07/2026 10:00	1.5	2.0	0.0	1.7	14.3	353.5	0.00	1.00
09/07/2026 11:00	1.5	2.0	0.0	1.7	14.3	354.2	0.00	1.00
09/07/2026 12:00	1.5	2.0	0.0	1.7	14.4	353.7	0.00	1.00
09/07/2026 13:00	1.5	2.0	0.0	1.7	14.4	352.0	0.00	1.00
09/07/2026 14:00	1.5	2.0	0.0	1.7	14.4	353.5	0.00	1.00
09/07/2026 15:00	1.5	2.0	0.0	1.7	14.4	351.6	0.00	1.00
09/07/2026 16:00	1.5	2.2	0.0	1.7	14.4	385.3	0.00	1.00
09/07/2026 17:00	1.5	2.1	0.0	1.7	14.4	379.4	0.00	1.00
09/07/2026 18:00	1.5	2.1	0.0	1.7	14.4	375.6	0.00	1.00
09/07/2026 19:00	1.5	2.3	0.0	1.6	14.5	421.4	0.00	1.00
09/07/2026 20:00	1.5	2.4	0.0	1.6	14.5	423.7	0.00	1.00
09/07/2026 21:00	1.5	2.4	0.0	1.6	14.4	423.8	0.00	1.00
09/07/2026 22:00	1.5	2.4	0.0	1.7	14.4	424.1	0.00	1.00
09/07/2026 23:00	1.5	2.4	0.0	1.7	14.4	425.2	0.00	1.00
Average/Sum#:	1.5	2.1	0.0	1.7	14.3	373.0	0.00 #	24.00 #
Minimum:	1.5	2.0	0.0	1.6	14.2	351.6	0.00	1.00
Maximum:	1.5	2.4	0.0	1.7	14.5	425.2	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/08/2026 00:00	1.5	2.4	0.0	1.7	14.4	425.4	0.00	1.00
09/08/2026 01:00	1.5	2.1	0.0	1.6	14.3	392.6	0.00	1.00
09/08/2026 02:00	1.5	2.0	0.0	1.7	14.2	351.9	0.00	1.00
09/08/2026 03:00	1.5	2.1	0.0	1.7	14.2	364.0	0.00	1.00
09/08/2026 04:00	1.5	2.3	0.0	1.7	14.3	415.5	0.00	1.00
09/08/2026 05:00	1.5	2.4	0.0	1.7	14.3	427.0	0.00	1.00
09/08/2026 06:00	1.5	2.1	0.0	1.7	14.2	379.8	0.00	1.00
09/08/2026 07:00	1.5	1.9	0.0	1.7	14.2	352.1	0.00	1.00
09/08/2026 08:00	1.5	2.0	0.0	1.7	14.3	351.2	0.00	1.00
09/08/2026 09:00	1.5	2.0	0.0	1.7	14.3	351.0	0.00	1.00
09/08/2026 10:00	1.5	2.0	0.0	1.7	14.3	349.7	0.00	1.00
09/08/2026 11:00	1.5	2.0	0.0	1.7	14.4	350.6	0.00	1.00
09/08/2026 12:00	1.5	2.0	0.0	1.7	14.4	360.8	0.00	1.00
09/08/2026 13:00	1.5	2.4	0.0	1.7	14.4	427.6	0.00	1.00
09/08/2026 14:00	1.6	3.3	0.0	2.2	12.6	577.3	0.00	1.00
09/08/2026 15:00	1.5	3.4	0.0	2.2	12.1	607.4	0.00	1.00
09/08/2026 16:00	1.5	3.5	0.0	2.3	12.1	614.8	0.00	1.00
09/08/2026 17:00	1.5	3.4	0.0	2.3	11.9	625.0	0.00	1.00
09/08/2026 18:00	1.5	3.5	0.0	2.3	12.0	622.8	0.00	1.00
09/08/2026 19:00	1.5	3.5	0.0	2.3	12.0	622.0	0.00	1.00
09/08/2026 20:00	1.5	3.4	0.0	2.2	12.2	609.8	0.00	1.00
09/08/2026 21:00	1.5	3.4	0.0	2.2	12.1	607.1	0.00	1.00
09/08/2026 22:00	1.5	3.1	0.0	2.0	12.8	556.1	0.00	1.00
09/08/2026 23:00	1.5	2.3	0.0	1.6	14.4	418.0	0.00	1.00
Average/Sum#:	1.5	2.6	0.0	1.9	13.5	465.0	0.00 #	24.00 #
Minimum:	1.5	1.9	0.0	1.6	11.9	349.7	0.00	1.00
Maximum:	1.6	3.5	0.0	2.3	14.4	625.0	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/09/2026 00:00	1.5	2.2	0.0	1.7	14.3	402.2	0.00	1.00
09/09/2026 01:00	1.5	2.0	0.0	1.7	14.2	370.9	0.00	1.00
09/09/2026 02:00	1.6	2.0	0.0	1.8	14.2	352.7	0.00	1.00
09/09/2026 03:00	1.5	1.9	0.0	1.7	14.2	353.3	0.00	1.00
09/09/2026 04:00	1.5	2.0	0.0	1.7	14.2	367.2	0.00	1.00
09/09/2026 05:00	1.5	2.8	0.0	1.8	14.1	479.7	0.00	1.00
09/09/2026 06:00	1.5	2.8	0.0	1.8	13.8	506.2	0.00	1.00
09/09/2026 07:00	1.5	3.1	0.0	2.0	13.1	557.6	0.00	1.00
09/09/2026 08:00	1.5	3.4	0.0	2.2	12.3	605.9	0.00	1.00
09/09/2026 09:00	1.5	3.4	0.0	2.3	12.1	613.3	0.00	1.00
09/09/2026 10:00	1.5	3.4	0.0	2.3	11.9	608.1	0.00	1.00
09/09/2026 11:00	1.5	3.3	0.0	2.2	12.2	603.6	0.00	1.00
09/09/2026 12:00	1.5	3.3	0.0	2.2	12.4	594.1	0.00	1.00
09/09/2026 13:00	1.5	3.5	0.0	2.3	12.1	612.9	0.00	1.00
09/09/2026 14:00	1.5	3.4	0.0	2.3	12.0	614.8	0.00	1.00
09/09/2026 15:00	1.5	3.5	0.0	2.3	11.8	629.7	0.00	1.00
09/09/2026 16:00	1.5	3.5	0.0	2.3	11.8	628.5	0.00	1.00
09/09/2026 17:00	1.5	3.4	0.0	2.2	12.1	610.9	0.00	1.00
09/09/2026 18:00	1.5	3.5	0.0	2.3	11.8	626.5	0.00	1.00
09/09/2026 19:00	1.5	3.3	0.0	2.1	12.4	593.0	0.00	1.00
09/09/2026 20:00	1.5	3.5	0.0	2.3	11.9	624.8	0.00	1.00
09/09/2026 21:00	1.5	3.5	0.0	2.3	11.9	625.0	0.00	1.00
09/09/2026 22:00	1.5	3.3	0.0	2.2	12.3	598.0	0.00	1.00
09/09/2026 23:00	1.5	2.3	0.0	1.6	14.5	426.7	0.00	1.00
Average/Sum#:	1.5	3.0	0.0	2.1	12.8	541.9	0.00 #	24.00 #
Minimum:	1.5	1.9	0.0	1.6	11.8	352.7	0.00	1.00
Maximum:	1.6	3.5	0.0	2.3	14.5	629.7	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/10/2026 00:00	1.5	2.4	0.0	1.6	14.5	426.5	0.00	1.00
09/10/2026 01:00	1.5	2.3	0.0	1.6	14.5	424.7	0.00	1.00
09/10/2026 02:00	1.5	2.4	0.0	1.7	14.5	417.6	0.00	1.00
09/10/2026 03:00	1.5	1.9	0.0	1.7	14.3	351.9	0.00	1.00
09/10/2026 04:00	1.5	2.0	0.0	1.7	14.3	358.6	0.00	1.00
09/10/2026 05:00	1.5	2.4	0.0	1.7	14.5	420.5	0.00	1.00
09/10/2026 06:00	1.5	2.1	0.0	1.6	14.4	378.7	0.00	1.00
09/10/2026 07:00	1.5	2.0	0.0	1.7	14.3	349.0	0.00	1.00
09/10/2026 08:00	1.5	2.0	0.0	1.7	14.4	348.6	0.00	1.00
09/10/2026 09:00	1.5	1.9	0.0	1.7	14.4	348.3	0.00	1.00
09/10/2026 10:00	1.5	1.9	0.0	1.7	14.4	348.6	0.00	1.00
09/10/2026 11:00	1.5	2.1	0.0	1.7	14.4	375.0	0.00	1.00
09/10/2026 12:00	1.5	2.8	0.0	1.9	13.7	492.5	0.00	1.00
09/10/2026 13:00	1.5	2.8	0.0	1.9	13.6	498.0	0.00	1.00
09/10/2026 14:00	1.5	2.8	0.0	1.9	13.5	502.0	0.00	1.00
09/10/2026 15:00	1.5	2.8	0.0	1.9	13.4	503.4	0.00	1.00
09/10/2026 16:00	1.5	3.0	0.0	2.0	13.0	534.1	0.00	1.00
09/10/2026 17:00	1.5	3.2	0.0	2.1	12.6	564.3	0.00	1.00
09/10/2026 18:00	1.5	2.7	0.0	1.8	13.6	498.9	0.00	1.00
09/10/2026 19:00	1.5	2.7	0.0	1.8	13.8	491.2	0.00	1.00
09/10/2026 20:00	1.5	2.7	0.0	1.8	13.8	491.1	0.00	1.00
09/10/2026 21:00	1.5	2.8	0.0	1.9	13.5	502.6	0.00	1.00
09/10/2026 22:00	1.5	2.8	0.0	1.9	13.6	498.4	0.00	1.00
09/10/2026 23:00	1.5	1.9	0.0	1.6	14.3	357.4	0.00	1.00
Average/Sum#:	1.5	2.4	0.0	1.8	14.0	436.7	0.00 #	24.00 #
Minimum:	1.5	1.9	0.0	1.6	12.6	348.3	0.00	1.00
Maximum:	1.5	3.2	0.0	2.1	14.5	564.3	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/11/2026 00:00	1.5	2.0	0.0	1.7	14.3	349.6	0.00	1.00
09/11/2026 01:00	1.5	2.0	0.0	1.7	14.3	349.8	0.00	1.00
09/11/2026 02:00	1.5	2.0	0.0	1.7	14.3	349.8	0.00	1.00
09/11/2026 03:00	1.5	2.0	0.0	1.7	14.3	350.1	0.00	1.00
09/11/2026 04:00	1.5	2.0	0.0	1.7	14.3	350.8	0.00	1.00
09/11/2026 05:00	1.5	2.0	0.0	1.7	14.3	351.2	0.00	1.00
09/11/2026 06:00	1.5	1.9	0.0	1.7	14.2	351.5	0.00	1.00
09/11/2026 07:00	1.5	1.9	0.0	1.7	14.2	351.4	0.00	1.00
09/11/2026 08:00	1.5	2.0	0.0	1.7	14.3	350.8	0.00	1.00
09/11/2026 09:00	1.5	2.0	0.0	1.7	14.3	350.3	0.00	1.00
09/11/2026 10:00	1.5	2.0	0.0	1.7	14.3	350.4	0.00	1.00
09/11/2026 11:00	1.5	2.0	0.0	1.7	14.4	351.0	0.00	1.00
09/11/2026 12:00	1.5	2.0	0.0	1.7	14.4	350.3	0.00	1.00
09/11/2026 13:00	1.5	2.0	0.0	1.7	14.4	349.3	0.00	1.00
09/11/2026 14:00	1.5	2.0	0.0	1.7	14.4	349.7	0.00	1.00
09/11/2026 15:00	1.5	2.3	0.0	1.6	14.5	409.9	0.00	1.00
09/11/2026 16:00	1.5	2.1	0.0	1.7	14.3	382.4	0.00	1.00
09/11/2026 17:00	1.5	2.1	0.0	1.7	14.3	379.6	0.00	1.00
09/11/2026 18:00	1.5	1.9	0.0	1.7	14.2	351.6	0.00	1.00
09/11/2026 19:00	1.5	1.9	0.0	1.7	14.2	351.6	0.00	1.00
09/11/2026 20:00	1.5	2.0	0.0	1.7	14.2	351.1	0.00	1.00
09/11/2026 21:00	1.5	2.0	0.0	1.7	14.3	350.5	0.00	1.00
09/11/2026 22:00	1.5	2.0	0.0	1.7	14.3	350.4	0.00	1.00
09/11/2026 23:00	1.5	1.9	0.0	1.7	14.2	350.3	0.00	1.00
Average/Sum#:	1.5	2.0	0.0	1.7	14.3	355.6	0.00 #	24.00 #
Minimum:	1.5	1.9	0.0	1.6	14.2	349.3	0.00	1.00
Maximum:	1.5	2.3	0.0	1.7	14.5	409.9	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/12/2026 00:00	1.5	1.9	0.0	1.7	14.2	350.3	0.00	1.00
09/12/2026 01:00	1.5	1.9	0.0	1.7	14.2	350.4	0.00	1.00
09/12/2026 02:00	1.5	2.0	0.0	1.7	14.2	350.4	0.00	1.00
09/12/2026 03:00	1.5	2.0	0.0	1.7	14.2	350.6	0.00	1.00
09/12/2026 04:00	1.5	1.9	0.0	1.7	14.2	350.7	0.00	1.00
09/12/2026 05:00	1.5	1.9	0.0	1.7	14.2	350.8	0.00	1.00
09/12/2026 06:00	1.5	1.9	0.0	1.7	14.2	351.0	0.00	1.00
09/12/2026 07:00	1.5	2.0	0.0	1.7	14.3	350.8	0.00	1.00
09/12/2026 08:00	1.5	2.0	0.0	1.7	14.3	350.4	0.00	1.00
09/12/2026 09:00	1.5	2.0	0.0	1.7	14.3	350.0	0.00	1.00
09/12/2026 10:00	1.5	2.0	0.0	1.7	14.3	349.9	0.00	1.00
09/12/2026 11:00	1.5	2.0	0.0	1.7	14.4	350.2	0.00	1.00
09/12/2026 12:00	1.5	2.0	0.0	1.7	14.4	349.8	0.00	1.00
09/12/2026 13:00	1.5	2.0	0.0	1.7	14.4	348.7	0.00	1.00
09/12/2026 14:00	1.5	2.0	0.0	1.7	14.4	348.6	0.00	1.00
09/12/2026 15:00	1.5	2.0	0.0	1.7	14.4	348.7	0.00	1.00
09/12/2026 16:00	1.5	2.1	0.0	1.7	14.4	370.0	0.00	1.00
09/12/2026 17:00	1.5	1.9	0.0	1.7	14.3	352.2	0.00	1.00
09/12/2026 18:00	1.5	1.9	0.0	1.7	14.3	349.1	0.00	1.00
09/12/2026 19:00	1.5	2.0	0.0	1.7	14.3	349.6	0.00	1.00
09/12/2026 20:00	1.5	2.0	0.0	1.7	14.3	349.7	0.00	1.00
09/12/2026 21:00	1.5	2.0	0.0	1.7	14.3	350.8	0.00	1.00
09/12/2026 22:00	1.5	2.0	0.0	1.7	14.2	354.5	0.00	1.00
09/12/2026 23:00	1.5	1.9	0.0	1.7	14.2	351.5	0.00	1.00
Average/Sum#:	1.5	2.0	0.0	1.7	14.3	351.2	0.00 #	24.00 #
Minimum:	1.5	1.9	0.0	1.7	14.2	348.6	0.00	1.00
Maximum:	1.5	2.1	0.0	1.7	14.4	370.0	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/13/2026 00:00	1.5	1.9	0.0	1.7	14.2	351.8	0.00	1.00
09/13/2026 01:00	1.5	1.9	0.0	1.7	14.2	352.0	0.00	1.00
09/13/2026 02:00	1.5	1.9	0.0	1.7	14.2	352.2	0.00	1.00
09/13/2026 03:00	1.5	2.0	0.0	1.7	14.2	352.4	0.00	1.00
09/13/2026 04:00	1.5	2.0	0.0	1.7	14.2	352.5	0.00	1.00
09/13/2026 05:00	1.5	2.3	0.0	1.7	14.3	400.9	0.00	1.00
09/13/2026 06:00	1.5	2.0	0.0	1.7	14.2	373.0	0.00	1.00
09/13/2026 07:00	1.5	1.9	0.0	1.7	14.2	352.4	0.00	1.00
09/13/2026 08:00	1.5	1.9	0.0	1.7	14.2	351.8	0.00	1.00
09/13/2026 09:00	1.5	1.9	0.0	1.7	14.2	351.9	0.00	1.00
09/13/2026 10:00	1.5	2.0	0.0	1.7	14.3	351.9	0.00	1.00
09/13/2026 11:00	1.5	2.0	0.0	1.7	14.3	352.3	0.00	1.00
09/13/2026 12:00	1.5	2.0	0.0	1.7	14.3	352.0	0.00	1.00
09/13/2026 13:00	1.5	2.0	0.0	1.7	14.3	351.3	0.00	1.00
09/13/2026 14:00	1.5	2.0	0.0	1.7	14.3	351.1	0.00	1.00
09/13/2026 15:00	1.5	2.0	0.0	1.7	14.3	350.9	0.00	1.00
09/13/2026 16:00	1.5	2.1	0.0	1.7	14.4	373.7	0.00	1.00
09/13/2026 17:00	1.5	2.3	0.0	1.6	14.5	405.5	0.00	1.00
09/13/2026 18:00	1.5	2.0	0.0	1.7	14.3	353.3	0.00	1.00
09/13/2026 19:00	1.5	2.0	0.0	1.7	14.3	351.0	0.00	1.00
09/13/2026 20:00	1.5	2.0	0.0	1.7	14.3	352.2	0.00	1.00
09/13/2026 21:00	1.5	2.0	0.0	1.7	14.3	352.0	0.00	1.00
09/13/2026 22:00	1.5	2.0	0.0	1.7	14.3	352.1	0.00	1.00
09/13/2026 23:00	1.5	2.0	0.0	1.7	14.3	352.9	0.00	1.00
Average/Sum#:	1.5	2.0	0.0	1.7	14.3	358.0	0.00 #	24.00 #
Minimum:	1.5	1.9	0.0	1.6	14.2	350.9	0.00	1.00
Maximum:	1.5	2.3	0.0	1.7	14.5	405.5	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/14/2026 00:00	1.5	1.9	0.0	1.7	14.2	352.8	0.00	1.00
09/14/2026 01:00	1.5	1.9	0.0	1.7	14.2	352.8	0.00	1.00
09/14/2026 02:00	1.5	2.0	0.0	1.7	14.2	353.1	0.00	1.00
09/14/2026 03:00	1.5	2.0	0.0	1.7	14.2	353.4	0.00	1.00
09/14/2026 04:00	1.5	2.0	0.0	1.7	14.2	353.6	0.00	1.00
09/14/2026 05:00	1.5	2.0	0.0	1.7	14.2	358.0	0.00	1.00
09/14/2026 06:00	1.5	2.1	0.0	1.7	14.2	370.1	0.00	1.00
09/14/2026 07:00	1.5	1.9	0.0	1.7	14.2	352.6	0.00	1.00
09/14/2026 08:00	1.5	1.9	0.0	1.7	14.2	352.0	0.00	1.00
09/14/2026 09:00	1.5	2.0	0.0	1.7	14.3	351.2	0.00	1.00
09/14/2026 10:00	1.5	2.0	0.0	1.7	14.3	351.0	0.00	1.00
09/14/2026 11:00	1.5	2.0	0.0	1.7	14.3	351.6	0.00	1.00
09/14/2026 12:00	1.5	2.0	0.0	1.7	14.4	351.4	0.00	1.00
09/14/2026 13:00	1.5	2.0	0.0	1.7	14.4	350.6	0.00	1.00
09/14/2026 14:00	1.5	2.0	0.0	1.7	14.4	350.5	0.00	1.00
09/14/2026 15:00	1.5	2.0	0.0	1.7	14.4	350.1	0.00	1.00
09/14/2026 16:00	1.5	2.1	0.0	1.7	14.4	369.2	0.00	1.00
09/14/2026 17:00	1.5	2.1	0.0	1.7	14.4	380.7	0.00	1.00
09/14/2026 18:00	1.5	1.9	0.0	1.7	14.4	350.2	0.00	1.00
09/14/2026 19:00	1.5	2.0	0.0	1.7	14.3	360.0	0.00	1.00
09/14/2026 20:00	1.5	2.0	0.0	1.7	14.3	352.5	0.00	1.00
09/14/2026 21:00	1.5	2.0	0.0	1.7	14.3	350.6	0.00	1.00
09/14/2026 22:00	1.5	2.0	0.0	1.7	14.3	352.0	0.00	1.00
09/14/2026 23:00	1.5	2.3	0.0	1.7	14.4	406.7	0.00	1.00
Average/Sum#:	1.5	2.0	0.0	1.7	14.3	357.4	0.00 #	24.00 #
Minimum:	1.5	1.9	0.0	1.7	14.2	350.1	0.00	1.00
Maximum:	1.5	2.3	0.0	1.7	14.4	406.7	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/15/2026 00:00	1.5	2.1	0.0	1.7	14.3	377.1	0.00	1.00
09/15/2026 01:00	1.5	2.0	0.0	1.7	14.2	357.0	0.00	1.00
09/15/2026 02:00	1.3	1.7	0.0	1.5	14.2	352.2	0.00	1.00
09/15/2026 03:00	1.5	2.0	0.0	1.7	14.2	352.4	0.00	1.00
09/15/2026 04:00	1.5	2.0	0.0	1.7	14.2	364.0	0.00	1.00
09/15/2026 05:00	1.5	2.4	0.0	1.7	14.4	426.9	0.00	1.00
09/15/2026 06:00	1.5	2.4	0.0	1.7	14.3	427.2	0.00	1.00
09/15/2026 07:00	1.5	2.3	0.0	1.7	14.3	418.6	0.00	1.00
09/15/2026 08:00	1.5	2.4	0.0	1.7	14.4	427.1	0.00	1.00
09/15/2026 09:00	1.5	2.4	0.0	1.7	14.4	426.2	0.00	1.00
09/15/2026 10:00	1.5	2.3	0.0	1.7	14.4	406.8	0.00	1.00
09/15/2026 11:00	1.5	2.4	0.0	1.6	14.5	426.7	0.00	1.00
09/15/2026 12:00	1.5	2.3	0.0	1.6	14.5	416.2	0.00	1.00
09/15/2026 13:00	1.5	2.3	0.0	1.6	14.5	415.6	0.00	1.00
09/15/2026 14:00	1.5	2.3	0.0	1.6	14.5	415.4	0.00	1.00
09/15/2026 15:00	1.5	2.3	0.0	1.6	14.5	413.2	0.00	1.00
09/15/2026 16:00	1.5	2.1	0.0	1.6	14.4	369.3	0.00	1.00
09/15/2026 17:00	1.5	2.0	0.0	1.7	14.4	355.2	0.00	1.00
09/15/2026 18:00	1.5	2.0	0.0	1.7	14.3	351.7	0.00	1.00
09/15/2026 19:00	1.5	2.0	0.0	1.7	14.3	351.4	0.00	1.00
09/15/2026 20:00	1.5	2.0	0.0	1.7	14.3	352.2	0.00	1.00
09/15/2026 21:00	1.5	1.9	0.0	1.7	14.2	352.8	0.00	1.00
09/15/2026 22:00	1.5	2.0	0.0	1.7	14.2	353.2	0.00	1.00
09/15/2026 23:00	1.5	2.0	0.0	1.7	14.2	353.6	0.00	1.00
Average/Sum#:	1.5	2.2	0.0	1.7	14.3	385.9	0.00 #	24.00 #
Minimum:	1.3	1.7	0.0	1.5	14.2	351.4	0.00	1.00
Maximum:	1.5	2.4	0.0	1.7	14.5	427.2	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/16/2026 00:00	1.5	2.0	0.0	1.7	14.2	353.8	0.00	1.00
09/16/2026 01:00	1.5	2.0	0.0	1.7	14.2	354.0	0.00	1.00
09/16/2026 02:00	1.5	2.0	0.0	1.7	14.2	354.6	0.00	1.00
09/16/2026 03:00	1.5	2.0	0.0	1.7	14.2	354.8	0.00	1.00
09/16/2026 04:00	1.5	2.0	0.0	1.7	14.2	354.9	0.00	1.00
09/16/2026 05:00	1.5	2.0	0.0	1.7	14.2	355.5	0.00	1.00
09/16/2026 06:00	1.5	2.0	0.0	1.7	14.2	362.0	0.00	1.00
09/16/2026 07:00	1.5	2.3	0.0	1.7	14.3	401.8	0.00	1.00
09/16/2026 08:00	1.5	2.4	0.0	1.7	14.3	430.4	0.00	1.00
09/16/2026 09:00	1.5	2.3	0.0	1.7	14.3	415.7	0.00	1.00
09/16/2026 10:00	1.5	2.0	0.0	1.7	14.2	359.1	0.00	1.00
09/16/2026 11:00	1.5	2.0	0.0	1.7	14.3	357.4	0.00	1.00
09/16/2026 12:00	1.5	2.0	0.0	1.7	14.3	357.3	0.00	1.00
09/16/2026 13:00	1.5	2.4	0.0	1.7	14.4	415.9	0.00	1.00
09/16/2026 14:00	1.5	2.4	0.0	1.6	14.5	434.5	0.00	1.00
09/16/2026 15:00	1.5	2.1	0.0	1.7	14.3	388.1	0.00	1.00
09/16/2026 16:00	1.5	2.0	0.0	1.7	14.3	353.1	0.00	1.00
09/16/2026 17:00	1.5	2.0	0.0	1.7	14.3	352.9	0.00	1.00
09/16/2026 18:00	1.5	2.0	0.0	1.7	14.2	353.8	0.00	1.00
09/16/2026 19:00	1.5	2.0	0.0	1.7	14.2	354.1	0.00	1.00
09/16/2026 20:00	1.5	2.0	0.0	1.7	14.2	354.3	0.00	1.00
09/16/2026 21:00	1.5	2.0	0.0	1.7	14.2	354.5	0.00	1.00
09/16/2026 22:00	1.5	2.0	0.0	1.7	14.2	354.8	0.00	1.00
09/16/2026 23:00	1.5	2.0	0.0	1.7	14.2	355.0	0.00	1.00
Average/Sum#:	1.5	2.1	0.0	1.7	14.3	370.1	0.00 #	24.00 #
Minimum:	1.5	2.0	0.0	1.6	14.2	352.9	0.00	1.00
Maximum:	1.5	2.4	0.0	1.7	14.5	434.5	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/17/2026 00:00	1.5	2.0	0.0	1.7	14.2	355.0	0.00	1.00
09/17/2026 01:00	1.5	2.0	0.0	1.7	14.2	355.1	0.00	1.00
09/17/2026 02:00	1.5	2.0	0.0	1.7	14.2	355.2	0.00	1.00
09/17/2026 03:00	1.5	2.0	0.0	1.7	14.2	355.6	0.00	1.00
09/17/2026 04:00	1.5	2.0	0.0	1.7	14.2	355.3	0.00	1.00
09/17/2026 05:00	1.5	2.2	0.0	1.7	14.3	391.8	0.00	1.00
09/17/2026 06:00	1.5	2.1	0.0	1.7	14.2	389.0	0.00	1.00
09/17/2026 07:00	1.5	2.0	0.0	1.7	14.2	355.1	0.00	1.00
09/17/2026 08:00	1.5	2.0	0.0	1.7	14.2	355.1	0.00	1.00
09/17/2026 09:00	1.5	2.0	0.0	1.7	14.2	355.4	0.00	1.00
09/17/2026 10:00	1.5	2.0	0.0	1.7	14.2	355.0	0.00	1.00
09/17/2026 11:00	1.5	2.0	0.0	1.7	14.2	354.8	0.00	1.00
09/17/2026 12:00	1.5	2.0	0.0	1.7	14.3	354.6	0.00	1.00
09/17/2026 13:00	1.5	2.0	0.0	1.7	14.3	354.2	0.00	1.00
09/17/2026 14:00	1.5	2.0	0.0	1.7	14.3	353.9	0.00	1.00
09/17/2026 15:00	1.5	2.0	0.0	1.7	14.3	353.9	0.00	1.00
09/17/2026 16:00	1.5	2.1	0.0	1.7	14.3	368.4	0.00	1.00
09/17/2026 17:00	1.5	2.0	0.0	1.7	14.3	353.9	0.00	1.00
09/17/2026 18:00	1.5	2.0	0.0	1.7	14.2	353.8	0.00	1.00
09/17/2026 19:00	1.5	2.0	0.0	1.7	14.2	353.9	0.00	1.00
09/17/2026 20:00	1.5	2.0	0.0	1.7	14.2	354.2	0.00	1.00
09/17/2026 21:00	1.5	2.0	0.0	1.7	14.2	354.7	0.00	1.00
09/17/2026 22:00	1.5	2.0	0.0	1.7	14.2	354.8	0.00	1.00
09/17/2026 23:00	1.5	2.0	0.0	1.7	14.2	355.2	0.00	1.00
Average/Sum#:	1.5	2.0	0.0	1.7	14.2	358.2	0.00 #	24.00 #
Minimum:	1.5	2.0	0.0	1.7	14.2	353.8	0.00	1.00
Maximum:	1.5	2.2	0.0	1.7	14.3	391.8	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/18/2026 00:00	1.5	2.0	0.0	1.7	14.2	355.2	0.00	1.00
09/18/2026 01:00	1.5	2.0	0.0	1.7	14.2	355.4	0.00	1.00
09/18/2026 02:00	1.5	2.0	0.0	1.7	14.2	355.5	0.00	1.00
09/18/2026 03:00	1.5	2.0	0.0	1.7	14.1	356.2	0.00	1.00
09/18/2026 04:00	1.5	2.0	0.0	1.7	14.2	356.2	0.00	1.00
09/18/2026 05:00	1.5	2.0	0.0	1.7	14.2	356.6	0.00	1.00
09/18/2026 06:00	1.5	2.2	0.0	1.7	14.2	391.4	0.00	1.00
09/18/2026 07:00	1.5	2.0	0.0	1.7	14.2	357.8	0.00	1.00
09/18/2026 08:00	1.5	2.0	0.0	1.7	14.2	355.2	0.00	1.00
09/18/2026 09:00	1.5	2.0	0.0	1.7	14.2	354.5	0.00	1.00
09/18/2026 10:00	1.5	2.0	0.0	1.7	14.3	354.1	0.00	1.00
09/18/2026 11:00	1.5	2.0	0.0	1.7	14.3	355.1	0.00	1.00
09/18/2026 12:00	1.5	2.0	0.0	1.7	14.3	354.8	0.00	1.00
09/18/2026 13:00	1.5	2.0	0.0	1.7	14.3	355.5	0.00	1.00
09/18/2026 14:00	1.5	2.0	0.0	1.7	14.3	352.6	0.00	1.00
09/18/2026 15:00	1.5	2.0	0.0	1.7	14.3	352.6	0.00	1.00
09/18/2026 16:00	1.5	2.3	0.0	1.7	14.4	403.9	0.00	1.00
09/18/2026 17:00	1.5	2.4	0.0	1.6	14.5	426.9	0.00	1.00
09/18/2026 18:00	1.5	1.9	0.0	1.7	14.3	354.2	0.00	1.00
09/18/2026 19:00	1.5	2.0	0.0	1.7	14.3	352.5	0.00	1.00
09/18/2026 20:00	1.5	2.0	0.0	1.7	14.3	352.9	0.00	1.00
09/18/2026 21:00	1.5	2.0	0.0	1.7	14.3	352.7	0.00	1.00
09/18/2026 22:00	1.5	1.9	0.0	1.7	14.2	353.0	0.00	1.00
09/18/2026 23:00	1.5	2.0	0.0	1.7	14.2	354.0	0.00	1.00
Average/Sum#:	1.5	2.0	0.0	1.7	14.3	361.2	0.00 #	24.00 #
Minimum:	1.5	1.9	0.0	1.6	14.1	352.5	0.00	1.00
Maximum:	1.5	2.4	0.0	1.7	14.5	426.9	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/19/2026 00:00	1.5	2.0	0.0	1.7	14.2	354.3	0.00	1.00
09/19/2026 01:00	1.5	2.0	0.0	1.7	14.2	354.3	0.00	1.00
09/19/2026 02:00	1.5	1.9	0.0	1.7	14.2	354.6	0.00	1.00
09/19/2026 03:00	1.5	2.0	0.0	1.7	14.2	354.9	0.00	1.00
09/19/2026 04:00	1.5	2.0	0.0	1.7	14.2	354.9	0.00	1.00
09/19/2026 05:00	1.5	2.0	0.0	1.7	14.2	355.2	0.00	1.00
09/19/2026 06:00	1.5	2.0	0.0	1.7	14.2	355.2	0.00	1.00
09/19/2026 07:00	1.5	2.0	0.0	1.7	14.2	354.5	0.00	1.00
09/19/2026 08:00	1.5	2.0	0.0	1.7	14.2	353.8	0.00	1.00
09/19/2026 09:00	1.5	2.0	0.0	1.7	14.2	353.6	0.00	1.00
09/19/2026 10:00	1.5	2.0	0.0	1.7	14.3	353.4	0.00	1.00
09/19/2026 11:00	1.5	2.0	0.0	1.7	14.3	355.3	0.00	1.00
09/19/2026 12:00	1.5	2.0	0.0	1.7	14.3	354.2	0.00	1.00
09/19/2026 13:00	1.5	2.0	0.0	1.7	14.3	353.0	0.00	1.00
09/19/2026 14:00	1.5	2.0	0.0	1.7	14.4	352.1	0.00	1.00
09/19/2026 15:00	1.5	2.0	0.0	1.7	14.4	352.2	0.00	1.00
09/19/2026 16:00	1.5	2.1	0.0	1.7	14.4	364.1	0.00	1.00
09/19/2026 17:00	1.5	2.0	0.0	1.7	14.4	352.0	0.00	1.00
09/19/2026 18:00	1.5	2.0	0.0	1.7	14.3	352.3	0.00	1.00
09/19/2026 19:00	1.5	2.0	0.0	1.7	14.3	352.7	0.00	1.00
09/19/2026 20:00	1.5	2.0	0.0	1.7	14.3	352.3	0.00	1.00
09/19/2026 21:00	1.5	2.0	0.0	1.7	14.3	357.8	0.00	1.00
09/19/2026 22:00	1.5	2.0	0.0	1.6	14.3	371.9	0.00	1.00
09/19/2026 23:00	1.5	2.0	0.0	1.7	14.2	366.4	0.00	1.00
Average/Sum#:	1.5	2.0	0.0	1.7	14.3	355.6	0.00 #	24.00 #
Minimum:	1.5	1.9	0.0	1.6	14.2	352.0	0.00	1.00
Maximum:	1.5	2.1	0.0	1.7	14.4	371.9	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/20/2026 00:00	1.5	2.0	0.0	1.7	14.2	363.3	0.00	1.00
09/20/2026 01:00	1.5	2.0	0.0	1.7	14.2	353.6	0.00	1.00
09/20/2026 02:00	1.5	1.9	0.0	1.7	14.2	353.9	0.00	1.00
09/20/2026 03:00	1.5	2.0	0.0	1.7	14.2	354.0	0.00	1.00
09/20/2026 04:00	1.5	2.0	0.0	1.7	14.2	354.2	0.00	1.00
09/20/2026 05:00	1.5	2.0	0.0	1.7	14.2	354.8	0.00	1.00
09/20/2026 06:00	1.5	2.0	0.0	1.7	14.2	355.6	0.00	1.00
09/20/2026 07:00	1.5	2.0	0.0	1.7	14.2	354.6	0.00	1.00
09/20/2026 08:00	1.5	2.0	0.0	1.7	14.2	354.4	0.00	1.00
09/20/2026 09:00	1.5	2.0	0.0	1.7	14.2	353.8	0.00	1.00
09/20/2026 10:00	1.5	2.0	0.0	1.7	14.3	353.3	0.00	1.00
09/20/2026 11:00	1.5	2.0	0.0	1.7	14.3	353.9	0.00	1.00
09/20/2026 12:00	1.5	2.0	0.0	1.7	14.3	353.9	0.00	1.00
09/20/2026 13:00	1.5	2.2	0.0	1.7	14.4	389.7	0.00	1.00
09/20/2026 14:00	1.5	2.4	0.0	1.6	14.5	427.9	0.00	1.00
09/20/2026 15:00	1.5	2.3	0.0	1.6	14.5	420.4	0.00	1.00
09/20/2026 16:00	1.5	2.3	0.0	1.6	14.4	404.5	0.00	1.00
09/20/2026 17:00	1.5	1.9	0.0	1.7	14.3	354.9	0.00	1.00
09/20/2026 18:00	1.5	2.0	0.0	1.7	14.3	352.6	0.00	1.00
09/20/2026 19:00	1.5	2.0	0.0	1.7	14.2	353.2	0.00	1.00
09/20/2026 20:00	1.5	2.0	0.0	1.7	14.2	353.6	0.00	1.00
09/20/2026 21:00	1.5	2.0	0.0	1.7	14.2	353.3	0.00	1.00
09/20/2026 22:00	1.5	2.0	0.0	1.7	14.2	353.5	0.00	1.00
09/20/2026 23:00	1.5	2.0	0.0	1.7	14.2	359.3	0.00	1.00
Average/Sum#:	1.5	2.0	0.0	1.7	14.3	364.0	0.00 #	24.00 #
Minimum:	1.5	1.9	0.0	1.6	14.2	352.6	0.00	1.00
Maximum:	1.5	2.4	0.0	1.7	14.5	427.9	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/21/2026 00:00	1.5	2.0	0.0	1.7	14.2	353.6	0.00	1.00
09/21/2026 01:00	1.5	2.0	0.0	1.7	14.2	353.8	0.00	1.00
09/21/2026 02:00	1.5	1.9	0.0	1.7	14.2	354.0	0.00	1.00
09/21/2026 03:00	1.5	2.0	0.0	1.7	14.2	354.2	0.00	1.00
09/21/2026 04:00	1.5	2.1	0.0	1.7	14.2	372.8	0.00	1.00
09/21/2026 05:00	1.5	2.3	0.0	1.7	14.3	416.5	0.00	1.00
09/21/2026 06:00	1.5	2.2	0.0	1.7	14.2	406.3	0.00	1.00
09/21/2026 07:00	1.5	2.2	0.0	1.7	14.2	402.0	0.00	1.00
09/21/2026 08:00	1.5	2.1	0.0	1.7	14.2	381.6	0.00	1.00
09/21/2026 09:00	1.5	2.0	0.0	1.7	14.2	354.6	0.00	1.00
09/21/2026 10:00	1.5	2.0	0.0	1.7	14.2	354.3	0.00	1.00
09/21/2026 11:00	1.5	2.0	0.0	1.7	14.3	354.2	0.00	1.00
09/21/2026 12:00	1.5	2.0	0.0	1.7	14.3	354.4	0.00	1.00
09/21/2026 13:00	1.5	2.0	0.0	1.7	14.3	353.9	0.00	1.00
09/21/2026 14:00	1.5	2.0	0.0	1.7	14.3	365.0	0.00	1.00
09/21/2026 15:00	1.5	2.0	0.0	1.7	14.3	352.8	0.00	1.00
09/21/2026 16:00	1.5	2.1	0.0	1.7	14.3	367.2	0.00	1.00
09/21/2026 17:00	1.5	2.0	0.0	1.7	14.3	352.7	0.00	1.00
09/21/2026 18:00	1.5	2.0	0.0	1.7	14.2	353.2	0.00	1.00
09/21/2026 19:00	1.5	2.0	0.0	1.7	14.2	353.9	0.00	1.00
09/21/2026 20:00	1.5	2.0	0.0	1.7	14.2	353.8	0.00	1.00
09/21/2026 21:00	1.5	2.0	0.0	1.7	14.2	354.1	0.00	1.00
09/21/2026 22:00	1.5	2.0	0.0	1.7	14.2	354.2	0.00	1.00
09/21/2026 23:00	1.5	2.0	0.0	1.7	14.2	354.4	0.00	1.00
Average/Sum#:	1.5	2.0	0.0	1.7	14.2	363.6	0.00 #	24.00 #
Minimum:	1.5	1.9	0.0	1.7	14.2	352.7	0.00	1.00
Maximum:	1.5	2.3	0.0	1.7	14.3	416.5	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/22/2026 00:00	1.5	2.0	0.0	1.7	14.2	354.7	0.00	1.00
09/22/2026 01:00	1.5	1.9	0.0	1.7	14.2	354.8	0.00	1.00
09/22/2026 02:00	1.5	1.9	0.0	1.7	14.1	355.2	0.00	1.00
09/22/2026 03:00	1.5	2.0	0.0	1.7	14.1	355.3	0.00	1.00
09/22/2026 04:00	1.5	1.9	0.0	1.7	14.1	355.7	0.00	1.00
09/22/2026 05:00	1.5	1.9	0.0	1.7	14.1	355.9	0.00	1.00
09/22/2026 06:00	1.5	2.0	0.0	1.7	14.1	370.1	0.00	1.00
09/22/2026 07:00	1.5	2.0	0.0	1.7	14.1	355.9	0.00	1.00
09/22/2026 08:00	1.5	2.0	0.0	1.7	14.2	355.3	0.00	1.00
09/22/2026 09:00	1.5	2.0	0.0	1.7	14.2	354.7	0.00	1.00
09/22/2026 10:00	1.5	2.0	0.0	1.7	14.2	354.0	0.00	1.00
09/22/2026 11:00	1.5	2.0	0.0	1.7	14.2	353.9	0.00	1.00
09/22/2026 12:00	1.5	2.0	0.0	1.7	14.3	353.7	0.00	1.00
09/22/2026 13:00	1.5	2.0	0.0	1.7	14.3	353.2	0.00	1.00
09/22/2026 14:00	1.5	2.0	0.0	1.7	14.3	353.1	0.00	1.00
09/22/2026 15:00	1.5	2.0	0.0	1.7	14.3	353.2	0.00	1.00
09/22/2026 16:00	1.5	2.0	0.0	1.7	14.3	361.2	0.00	1.00
09/22/2026 17:00	1.5	1.9	0.0	1.7	14.3	352.2	0.00	1.00
09/22/2026 18:00	1.5	2.0	0.0	1.7	14.3	351.8	0.00	1.00
09/22/2026 19:00	1.5	2.0	0.0	1.7	14.3	352.9	0.00	1.00
09/22/2026 20:00	1.5	2.0	0.0	1.7	14.2	353.4	0.00	1.00
09/22/2026 21:00	1.5	2.3	0.0	1.7	14.2	406.5	0.00	1.00
09/22/2026 22:00	1.5	2.7	0.0	1.8	13.9	489.2	0.00	1.00
09/22/2026 23:00	1.5	2.0	0.0	1.7	14.2	375.2	0.00	1.00
Average/Sum#:	1.5	2.0	0.0	1.7	14.2	363.8	0.00 #	24.00 #
Minimum:	1.5	1.9	0.0	1.7	13.9	351.8	0.00	1.00
Maximum:	1.5	2.7	0.0	1.8	14.3	489.2	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/23/2026 00:00	1.5	2.0	0.0	1.7	14.2	355.3	0.00	1.00
09/23/2026 01:00	1.5	2.0	0.0	1.7	14.2	355.9	0.00	1.00
09/23/2026 02:00	1.5	1.9	0.0	1.7	14.2	355.5	0.00	1.00
09/23/2026 03:00	1.5	2.0	0.0	1.7	14.2	355.8	0.00	1.00
09/23/2026 04:00	1.5	2.0	0.0	1.7	14.2	359.6	0.00	1.00
09/23/2026 05:00	1.5	2.2	0.0	1.7	14.2	392.0	0.00	1.00
09/23/2026 06:00	1.5	2.1	0.0	1.7	14.1	383.1	0.00	1.00
09/23/2026 07:00	1.5	1.9	0.0	1.7	14.2	355.8	0.00	1.00
09/23/2026 08:00	1.5	2.0	0.0	1.7	14.2	354.7	0.00	1.00
09/23/2026 09:00	1.5	2.0	0.0	1.7	14.2	354.3	0.00	1.00
09/23/2026 10:00	1.5	2.0	0.0	1.7	14.3	354.0	0.00	1.00
09/23/2026 11:00	1.5	2.0	0.0	1.7	14.3	353.5	0.00	1.00
09/23/2026 12:00	1.5	2.0	0.0	1.7	14.3	353.1	0.00	1.00
09/23/2026 13:00	1.5	2.1	0.0	1.7	14.4	361.8	0.00	1.00
09/23/2026 14:00	1.5	2.0	0.0	1.6	14.4	356.6	0.00	1.00
09/23/2026 15:00	1.5	2.1	0.0	1.7	14.4	369.5	0.00	1.00
09/23/2026 16:00	1.5	2.2	0.0	1.7	14.4	390.5	0.00	1.00
09/23/2026 17:00	1.5	2.0	0.0	1.7	14.3	356.6	0.00	1.00
09/23/2026 18:00	1.5	2.0	0.0	1.7	14.4	352.7	0.00	1.00
09/23/2026 19:00	1.5	2.4	0.0	1.7	14.5	423.1	0.00	1.00
09/23/2026 20:00	1.5	2.1	0.0	1.6	14.4	385.8	0.00	1.00
09/23/2026 21:00	1.5	2.0	0.0	1.7	14.3	360.0	0.00	1.00
09/23/2026 22:00	1.5	2.0	0.0	1.7	14.3	353.3	0.00	1.00
09/23/2026 23:00	1.5	1.9	0.0	1.7	14.2	354.7	0.00	1.00
Average/Sum#:	1.5	2.0	0.0	1.7	14.3	364.5	0.00 #	24.00 #
Minimum:	1.5	1.9	0.0	1.6	14.1	352.7	0.00	1.00
Maximum:	1.5	2.4	0.0	1.7	14.5	423.1	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/24/2026 00:00	1.5	2.0	0.0	1.7	14.2	354.7	0.00	1.00
09/24/2026 01:00	1.5	2.0	0.0	1.7	14.2	354.5	0.00	1.00
09/24/2026 02:00	1.5	2.0	0.0	1.7	14.2	354.2	0.00	1.00
09/24/2026 03:00	1.5	2.0	0.0	1.7	14.2	354.6	0.00	1.00
09/24/2026 04:00	1.5	2.0	0.0	1.7	14.2	357.3	0.00	1.00
09/24/2026 05:00	1.5	2.2	0.0	1.7	14.3	397.9	0.00	1.00
09/24/2026 06:00	1.5	2.1	0.0	1.7	14.2	390.1	0.00	1.00
09/24/2026 07:00	1.5	2.0	0.0	1.7	14.2	354.7	0.00	1.00
09/24/2026 08:00	1.5	2.0	0.0	1.7	14.3	353.9	0.00	1.00
09/24/2026 09:00	1.5	2.0	0.0	1.7	14.3	353.2	0.00	1.00
09/24/2026 10:00	1.5	2.0	0.0	1.7	14.4	353.2	0.00	1.00
09/24/2026 11:00	1.5	2.0	0.0	1.7	14.4	352.6	0.00	1.00
09/24/2026 12:00	1.5	2.0	0.0	1.7	14.4	352.6	0.00	1.00
09/24/2026 13:00	1.5	2.2	0.0	1.7	14.4	382.2	0.00	1.00
09/24/2026 14:00	1.5	2.2	0.0	1.6	14.3	393.2	0.00	1.00
09/24/2026 15:00	1.5	2.2	0.0	1.6	14.3	398.3	0.00	1.00
09/24/2026 16:00	1.5	2.2	0.0	1.7	14.3	393.5	0.00	1.00
09/24/2026 17:00	1.5	2.6	0.0	1.7	14.2	440.8	0.00	1.00
09/24/2026 18:00	1.5	2.9	0.0	1.9	13.4	521.0	0.00	1.00
09/24/2026 19:00	1.5	2.0	0.0	1.6	14.3	371.8	0.00	1.00
09/24/2026 20:00	1.5	2.0	0.0	1.7	14.3	351.2	0.00	1.00
09/24/2026 21:00	1.5	2.0	0.0	1.7	14.3	351.6	0.00	1.00
09/24/2026 22:00	1.5	2.0	0.0	1.7	14.3	352.1	0.00	1.00
09/24/2026 23:00	1.5	2.0	0.0	1.7	14.3	352.4	0.00	1.00
Average/Sum#:	1.5	2.1	0.0	1.7	14.2	374.7	0.00 #	24.00 #
Minimum:	1.5	2.0	0.0	1.6	13.4	351.2	0.00	1.00
Maximum:	1.5	2.9	0.0	1.9	14.4	521.0	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/25/2026 00:00	1.5	2.0	0.0	1.7	14.3	352.7	0.00	1.00
09/25/2026 01:00	1.5	2.0	0.0	1.7	14.3	352.7	0.00	1.00
09/25/2026 02:00	1.5	2.0	0.0	1.7	14.2	352.7	0.00	1.00
09/25/2026 03:00	1.5	2.0	0.0	1.7	14.2	352.8	0.00	1.00
09/25/2026 04:00	1.5	1.9	0.0	1.7	14.2	352.9	0.00	1.00
09/25/2026 05:00	1.5	2.0	0.0	1.7	14.2	356.3	0.00	1.00
09/25/2026 06:00	1.5	2.0	0.0	1.6	14.2	367.3	0.00	1.00
09/25/2026 07:00	1.5	2.1	0.0	1.7	14.3	369.8	0.00	1.00
09/25/2026 08:00	1.5	2.0	0.0	1.7	14.3	352.4	0.00	1.00
09/25/2026 09:00	1.5	2.0	0.0	1.7	14.3	351.9	0.00	1.00
09/25/2026 10:00	1.5	2.0	0.0	1.7	14.3	352.0	0.00	1.00
09/25/2026 11:00	1.5	2.0	0.0	1.7	14.3	350.6	0.00	1.00
09/25/2026 12:00	1.5	2.0	0.0	1.7	14.3	350.4	0.00	1.00
09/25/2026 13:00	1.5	2.0	0.0	1.7	14.4	350.8	0.00	1.00
09/25/2026 14:00	1.5	2.0	0.0	1.7	14.4	350.2	0.00	1.00
09/25/2026 15:00	1.5	2.0	0.0	1.7	14.4	350.0	0.00	1.00
09/25/2026 16:00	1.5	2.0	0.0	1.7	14.4	357.3	0.00	1.00
09/25/2026 17:00	1.5	1.9	0.0	1.6	14.3	350.5	0.00	1.00
09/25/2026 18:00	1.5	2.0	0.0	1.7	14.3	350.8	0.00	1.00
09/25/2026 19:00	1.5	2.0	0.0	1.7	14.3	351.1	0.00	1.00
09/25/2026 20:00	1.5	2.0	0.0	1.7	14.3	350.9	0.00	1.00
09/25/2026 21:00	1.5	2.0	0.0	1.7	14.3	351.6	0.00	1.00
09/25/2026 22:00	1.5	2.0	0.0	1.7	14.3	352.0	0.00	1.00
09/25/2026 23:00	1.5	1.9	0.0	1.7	14.2	352.0	0.00	1.00
Average/Sum#:	1.5	2.0	0.0	1.7	14.3	353.4	0.00 #	24.00 #
Minimum:	1.5	1.9	0.0	1.6	14.2	350.0	0.00	1.00
Maximum:	1.5	2.1	0.0	1.7	14.4	369.8	0.00	1.00
%SI	0.00	0.00	8.33	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/26/2026 00:00	1.5	1.9	0.0	1.7	14.2	352.6	0.00	1.00
09/26/2026 01:00	1.5	1.9	0.0	1.7	14.2	352.6	0.00	1.00
09/26/2026 02:00	1.5	2.0	0.0	1.7	14.2	353.0	0.00	1.00
09/26/2026 03:00	1.5	2.0	0.0	1.7	14.2	353.1	0.00	1.00
09/26/2026 04:00	1.5	1.9	0.0	1.7	14.2	353.2	0.00	1.00
09/26/2026 05:00	1.5	1.9	0.0	1.7	14.2	353.3	0.00	1.00
09/26/2026 06:00	1.5	1.9	0.0	1.7	14.2	353.4	0.00	1.00
09/26/2026 07:00	1.5	2.0	0.0	1.7	14.2	353.6	0.00	1.00
09/26/2026 08:00	1.5	2.0	0.0	1.7	14.2	353.6	0.00	1.00
09/26/2026 09:00	1.5	2.0	0.0	1.7	14.2	353.4	0.00	1.00
09/26/2026 10:00	1.5	2.0	0.0	1.7	14.3	352.8	0.00	1.00
09/26/2026 11:00	1.5	2.0	0.0	1.7	14.3	352.2	0.00	1.00
09/26/2026 12:00	1.5	2.0	0.0	1.7	14.3	352.5	0.00	1.00
09/26/2026 13:00	1.5	2.0	0.0	1.7	14.3	352.2	0.00	1.00
09/26/2026 14:00	1.5	2.0	0.0	1.7	14.4	352.1	0.00	1.00
09/26/2026 15:00	1.5	2.0	0.0	1.7	14.4	352.0	0.00	1.00
09/26/2026 16:00	1.5	2.2	0.0	1.7	14.4	394.4	0.00	1.00
09/26/2026 17:00	1.5	2.4	0.0	1.7	14.3	428.5	0.00	1.00
09/26/2026 18:00	1.5	2.1	0.0	1.6	14.4	385.7	0.00	1.00
09/26/2026 19:00	1.5	2.4	0.0	1.7	14.5	427.5	0.00	1.00
09/26/2026 20:00	1.5	2.4	0.0	1.6	14.5	425.6	0.00	1.00
09/26/2026 21:00	1.5	2.4	0.0	1.6	14.5	425.6	0.00	1.00
09/26/2026 22:00	1.5	2.5	0.0	1.7	14.3	436.5	0.00	1.00
09/26/2026 23:00	1.5	3.4	0.0	2.2	12.4	599.0	0.00	1.00
Average/Sum#:	1.5	2.1	0.0	1.7	14.2	382.0	0.00 #	24.00 #
Minimum:	1.5	1.9	0.0	1.6	12.4	352.0	0.00	1.00
Maximum:	1.5	3.4	0.0	2.2	14.5	599.0	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/27/2026 00:00	1.5	2.7	0.0	1.8	13.9	491.5	0.00	1.00
09/27/2026 01:00	1.5	2.4	0.0	1.7	14.1	433.6	0.00	1.00
09/27/2026 02:00	1.4	2.1	0.0	1.6	14.3	400.4	0.00	1.00
09/27/2026 03:00	1.5	2.0	0.0	1.7	14.2	377.1	0.00	1.00
09/27/2026 04:00	1.5	2.0	0.0	1.7	14.2	359.0	0.00	1.00
09/27/2026 05:00	1.5	2.1	0.0	1.7	14.3	385.5	0.00	1.00
09/27/2026 06:00	1.5	2.3	0.0	1.7	14.3	421.3	0.00	1.00
09/27/2026 07:00	1.5	2.3	0.0	1.7	14.3	421.3	0.00	1.00
09/27/2026 08:00	1.5	2.0	0.0	1.7	14.2	373.9	0.00	1.00
09/27/2026 09:00	1.5	2.0	0.0	1.7	14.2	353.9	0.00	1.00
09/27/2026 10:00	1.5	2.0	0.0	1.7	14.2	353.8	0.00	1.00
09/27/2026 11:00	1.5	2.0	0.0	1.7	14.2	353.6	0.00	1.00
09/27/2026 12:00	1.5	2.0	0.0	1.7	14.3	353.1	0.00	1.00
09/27/2026 13:00	1.5	2.0	0.0	1.7	14.3	352.7	0.00	1.00
09/27/2026 14:00	1.5	2.0	0.0	1.7	14.3	356.7	0.00	1.00
09/27/2026 15:00	1.5	2.1	0.0	1.7	14.4	372.1	0.00	1.00
09/27/2026 16:00	1.5	2.3	0.0	1.7	14.3	408.6	0.00	1.00
09/27/2026 17:00	1.5	3.3	0.0	2.1	12.7	583.6	0.00	1.00
09/27/2026 18:00	1.5	3.2	0.0	2.1	12.8	577.1	0.00	1.00
09/27/2026 19:00	1.5	3.2	0.0	2.1	12.8	575.5	0.00	1.00
09/27/2026 20:00	1.5	3.1	0.0	2.0	13.0	562.5	0.00	1.00
09/27/2026 21:00	1.5	2.8	0.0	1.8	13.8	502.7	0.00	1.00
09/27/2026 22:00	1.5	2.6	0.0	1.7	14.1	465.9	0.00	1.00
09/27/2026 23:00	1.5	2.2	0.0	1.7	14.2	397.7	0.00	1.00
Average/Sum#:	1.5	2.4	0.0	1.8	14.0	426.4	0.00 #	24.00 #
Minimum:	1.4	2.0	0.0	1.6	12.7	352.7	0.00	1.00
Maximum:	1.5	3.3	0.0	2.1	14.4	583.6	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/28/2026 00:00	1.5	2.2	0.0	1.7	14.2	391.5	0.00	1.00
09/28/2026 01:00	1.5	2.0	0.0	1.7	14.2	355.1	0.00	1.00
09/28/2026 02:00	1.5	2.1	0.0	1.7	14.2	376.2	0.00	1.00
09/28/2026 03:00	1.6	2.5	0.0	1.8	14.2	407.9	0.00	1.00
09/28/2026 04:00	1.5	2.7	0.0	1.8	14.1	488.9	0.00	1.00
09/28/2026 05:00	1.5	2.8	0.0	1.8	13.9	503.6	0.00	1.00
09/28/2026 06:00	1.5	2.8	0.0	1.8	13.7	496.6	0.00	1.00
09/28/2026 07:00	1.5	2.1	0.0	1.7	14.2	384.9	0.00	1.00
09/28/2026 08:00	1.5	2.0	0.0	1.7	14.2	354.2	0.00	1.00
09/28/2026 09:00	1.5	2.0	0.0	1.7	14.2	353.5	0.00	1.00
09/28/2026 10:00	1.5	2.0	0.0	1.7	14.3	352.7	0.00	1.00
09/28/2026 11:00	1.5	2.0	0.0	1.7	14.3	352.8	0.00	1.00
09/28/2026 12:00	1.5	2.0	0.0	1.7	14.3	352.1	0.00	1.00
09/28/2026 13:00	1.5	2.0	0.0	1.7	14.3	351.7	0.00	1.00
09/28/2026 14:00	1.5	2.0	0.0	1.7	14.4	351.4	0.00	1.00
09/28/2026 15:00	1.5	2.0	0.0	1.7	14.4	351.1	0.00	1.00
09/28/2026 16:00	1.5	2.0	0.0	1.7	14.4	352.3	0.00	1.00
09/28/2026 17:00	1.5	2.0	0.0	1.7	14.4	350.8	0.00	1.00
09/28/2026 18:00	1.5	2.0	0.0	1.7	14.4	350.7	0.00	1.00
09/28/2026 19:00	1.5	2.0	0.0	1.7	14.3	351.3	0.00	1.00
09/28/2026 20:00	1.5	2.0	0.0	1.7	14.3	351.6	0.00	1.00
09/28/2026 21:00	1.5	2.0	0.0	1.7	14.3	352.4	0.00	1.00
09/28/2026 22:00	1.5	2.0	0.0	1.7	14.2	352.7	0.00	1.00
09/28/2026 23:00	1.5	2.0	0.0	1.7	14.2	353.1	0.00	1.00
Average/Sum#:	1.5	2.1	0.0	1.7	14.2	376.6	0.00 #	24.00 #
Minimum:	1.5	2.0	0.0	1.7	13.7	350.7	0.00	1.00
Maximum:	1.6	2.8	0.0	1.8	14.4	503.6	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/29/2026 00:00	1.5	1.9	0.0	1.7	14.2	353.3	0.00	1.00
09/29/2026 01:00	1.5	2.0	0.0	1.7	14.2	353.6	0.00	1.00
09/29/2026 02:00	1.5	1.9	0.0	1.7	14.2	353.7	0.00	1.00
09/29/2026 03:00	1.5	2.0	0.0	1.7	14.2	354.1	0.00	1.00
09/29/2026 04:00	1.5	2.0	0.0	1.7	14.2	354.5	0.00	1.00
09/29/2026 05:00	1.5	2.0	0.0	1.7	14.2	354.4	0.00	1.00
09/29/2026 06:00	1.5	2.0	0.0	1.7	14.2	354.3	0.00	1.00
09/29/2026 07:00	1.5	2.0	0.0	1.7	14.2	353.6	0.00	1.00
09/29/2026 08:00	1.5	2.0	0.0	1.7	14.2	352.7	0.00	1.00
09/29/2026 09:00	1.5	2.0	0.0	1.7	14.3	351.6	0.00	1.00
09/29/2026 10:00	1.5	2.0	0.0	1.7	14.4	351.2	0.00	1.00
09/29/2026 11:00	1.5	2.0	0.0	1.7	14.4	351.7	0.00	1.00
09/29/2026 12:00	1.5	2.0	0.0	1.7	14.4	350.5	0.00	1.00
09/29/2026 13:00	1.5	2.0	0.0	1.6	14.5	350.0	0.00	1.00
09/29/2026 14:00	1.5	2.0	0.0	1.6	14.5	349.9	0.00	1.00
09/29/2026 15:00	1.5	2.0	0.0	1.6	14.5	350.1	0.00	1.00
09/29/2026 16:00	1.5	2.0	0.0	1.7	14.4	362.4	0.00	1.00
09/29/2026 17:00	1.5	2.0	0.0	1.6	14.4	350.9	0.00	1.00
09/29/2026 18:00	1.5	2.0	0.0	1.7	14.4	350.8	0.00	1.00
09/29/2026 19:00	1.5	2.0	0.0	1.7	14.4	350.5	0.00	1.00
09/29/2026 20:00	1.5	2.0	0.0	1.7	14.3	351.0	0.00	1.00
09/29/2026 21:00	1.5	2.0	0.0	1.7	14.3	351.0	0.00	1.00
09/29/2026 22:00	1.5	2.0	0.0	1.7	14.3	351.7	0.00	1.00
09/29/2026 23:00	1.5	2.4	0.0	1.7	14.4	427.1	0.00	1.00
Average/Sum#:	1.5	2.0	0.0	1.7	14.3	355.6	0.00 #	24.00 #
Minimum:	1.5	1.9	0.0	1.6	14.2	349.9	0.00	1.00
Maximum:	1.5	2.4	0.0	1.7	14.5	427.1	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:46 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT1 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 SUSD, Hr 1 Hour(s)	Unit CT1 OperatingTime, Hr 1 Hour(s)
09/30/2026 00:00	1.5	1.9	0.0	1.7	14.3	351.6	0.00	1.00
09/30/2026 01:00	1.5	2.0	0.0	1.7	14.3	354.3	0.00	1.00
09/30/2026 02:00	1.5	2.1	0.0	1.7	14.3	373.9	0.00	1.00
09/30/2026 03:00	1.6	2.7	0.0	1.8	14.2	463.3	0.00	1.00
09/30/2026 04:00	1.5	2.7	0.0	1.8	14.0	487.8	0.00	1.00
09/30/2026 05:00	1.5	3.2	0.0	2.0	13.1	558.9	0.00	1.00
09/30/2026 06:00	1.4	2.5	0.0	1.8	13.7	450.5	0.00	1.00
09/30/2026 07:00	1.5	2.0	0.0	1.7	14.2	353.0	0.00	1.00
09/30/2026 08:00	1.5	2.0	0.0	1.7	14.3	355.3	0.00	1.00
09/30/2026 09:00	1.5	2.0	0.0	1.7	14.3	350.5	0.00	1.00
09/30/2026 10:00	1.5	2.1	0.0	1.7	14.4	364.2	0.00	1.00
09/30/2026 11:00	1.5	2.2	0.0	1.6	14.5	389.9	0.00	1.00
09/30/2026 12:00	1.5	2.4	0.0	1.7	14.3	420.0	0.00	1.00
09/30/2026 13:00	1.5	2.8	0.0	1.8	13.7	494.9	0.00	1.00
09/30/2026 14:00	1.6	3.4	0.0	2.2	12.5	585.6	0.00	1.00
09/30/2026 15:00	1.5	3.3	0.0	2.2	12.3	592.2	0.00	1.00
09/30/2026 16:00	1.5	3.3	0.0	2.2	12.4	585.1	0.00	1.00
09/30/2026 17:00	1.5	3.1	0.0	2.1	12.7	568.3	0.00	1.00
09/30/2026 18:00	1.5	2.8	0.0	1.9	13.4	506.9	0.00	1.00
09/30/2026 19:00	1.5	2.7	0.0	1.8	13.7	472.9	0.00	1.00
09/30/2026 20:00	1.5	2.5	0.0	1.7	14.3	432.6	0.00	1.00
09/30/2026 21:00	1.5	2.8	0.0	1.9	13.6	496.9	0.00	1.00
09/30/2026 22:00	1.5	2.0	0.0	1.6	14.3	373.8	0.00	1.00
09/30/2026 23:00	1.5	2.1	0.0	1.7	14.3	379.8	0.00	1.00
Average/Sum#:	1.5	2.5	0.0	1.8	13.8	448.4	0.00 #	24.00 #
Minimum:	1.4	1.9	0.0	1.6	12.3	350.5	0.00	1.00
Maximum:	1.6	3.4	0.0	2.2	14.5	592.2	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

Startup / Shutdown Events

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 08:50 **Location:** Roseville, CA

Unit Offline

Tag Name: CT1_UnitOn_TF_1H

Offline Periods		
Start Time	**End Time**	**Duration in Hour(s)**
07/01/2026 00:00	07/02/2026 22:00	47
07/03/2026 05:00	07/03/2026 23:00	19
07/04/2026 06:00	07/04/2026 17:00	12
07/05/2026 01:00	07/10/2026 15:00	135
07/11/2026 06:00	07/11/2026 14:00	9

Startup / Shutdown Events

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 08:50 **Location:** Roseville, CA

Operating Time Summary	
Available Data for Report (excludes missing data):	2,208.00 Hour(s)
Total Offline:	222.00 Hour(s)
Offline Percentage:	10.05 %
Total Online:	1,986.00 Hour(s)
Online Percentage:	89.95 %

Startup / Shutdown Events

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 08:50 **Location:** Roseville, CA

Startup/Shutdown

Number	Start Time	End Time	Event Type	Duration
1	07/02/2026 23:39	07/03/2026 00:42	Cold Startup	64
2	07/03/2026 04:10	07/03/2026 04:20	Shutdown	11
3	07/04/2026 00:39	07/04/2026 01:39	Cold Startup	61
4	07/04/2026 05:09	07/04/2026 05:19	Shutdown	11
5	07/04/2026 18:24	07/04/2026 19:27	Cold Startup	64
6	07/05/2026 00:35	07/05/2026 00:45	Shutdown	11
7	07/10/2026 16:09	07/10/2026 17:07	Cold Startup	59
8	07/11/2026 05:20	07/11/2026 05:30	Shutdown	11
9	07/11/2026 15:59	07/11/2026 16:48	Cold Startup	50
10	09/05/2026 07:02	09/05/2026 07:02	Shutdown	1

Startup / Shutdown Events

CT1

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY
Generated: 10/13/2026 08:50 **Location:** Roseville, CA

Startup/Shutdown Event Summary

	# Events	Duration	Duration %
Cold Startup	5	298	0.25
Warm Startup	0		0.00
Shutdown	5	45	0.04
Total Process Events:	10	343	0.29

Total Report Time:	2,207.98 Hour(s)
Total Operating Time:	1,981.13 Hour(s)
Total Startup Time:	298 Minute(s)
Total Shutdown Time:	45 Minute(s)
Total Startup/Shutdown Time:	343 Minute(s)
Total Startup/Shutdown Time as a Percentage of Total Operating Time:	0.29 %

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/01/2026 00:00	0.8	0.7	0.0	0.9	14.3	390.4	0.00	1.00
07/01/2026 01:00	0.8	0.7	0.0	0.9	14.3	393.4	0.00	1.00
07/01/2026 02:00	0.8	0.7	0.0	0.9	14.3	392.9	0.00	1.00
07/01/2026 03:00	0.8	0.7	0.0	0.9	14.3	392.9	0.00	1.00
07/01/2026 04:00	0.8	0.7	0.0	0.9	14.3	392.1	0.00	1.00
07/01/2026 05:00	0.8	0.7	0.0	0.9	14.3	392.2	0.00	1.00
07/01/2026 06:00	0.8	0.7	0.0	0.9	14.3	391.6	0.00	1.00
07/01/2026 07:00	0.8	0.7	0.0	0.9	14.3	392.7	0.00	1.00
07/01/2026 08:00	0.8	0.7	0.0	0.9	14.3	392.3	0.00	1.00
07/01/2026 09:00	0.7	0.7	0.0	0.8	14.4	392.2	0.00	1.00
07/01/2026 10:00	0.7	0.6	0.0	0.8	14.4	390.0	0.00	1.00
07/01/2026 11:00	0.7	0.6	0.0	0.8	14.4	390.1	0.00	1.00
07/01/2026 12:00	0.7	0.7	0.0	0.8	14.4	391.3	0.00	1.00
07/01/2026 13:00	0.7	0.7	0.0	0.8	14.5	390.9	0.00	1.00
07/01/2026 14:00	0.7	0.7	0.0	0.8	14.5	390.9	0.00	1.00
07/01/2026 15:00	0.7	0.6	0.0	0.8	14.5	391.0	0.00	1.00
07/01/2026 16:00	0.7	0.6	0.0	0.8	14.5	399.2	0.00	1.00
07/01/2026 17:00	0.7	0.6	0.0	0.8	14.4	412.8	0.00	1.00
07/01/2026 18:00	0.6	0.7	0.0	0.7	14.4	440.3	0.00	1.00
07/01/2026 19:00	0.6	0.7	0.0	0.7	14.4	460.2	0.00	1.00
07/01/2026 20:00	0.7	0.7	0.0	0.8	14.3	438.7	0.00	1.00
07/01/2026 21:00	0.8	0.7	0.0	0.9	14.3	400.9	0.00	1.00
07/01/2026 22:00	0.8	0.7	0.0	0.9	14.3	402.7	0.00	1.00
07/01/2026 23:00	0.7	0.7	0.0	0.8	14.4	416.4	0.00	1.00
Average/Sum#:	0.7	0.7	0.0	0.8	14.4	401.6	0.00 #	24.00 #
Minimum:	0.6	0.6	0.0	0.7	14.3	390.0	0.00	1.00
Maximum:	0.8	0.7	0.0	0.9	14.5	460.2	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/02/2026 00:00	0.8	0.7	0.0	0.9	14.3	391.1	0.00	1.00
07/02/2026 01:00	0.8	0.7	0.0	0.9	14.3	390.4	0.00	1.00
07/02/2026 02:00	0.8	0.7	0.0	0.9	14.3	390.3	0.00	1.00
07/02/2026 03:00	0.8	0.7	0.0	0.9	14.3	390.1	0.00	1.00
07/02/2026 04:00	0.8	0.7	0.0	0.9	14.3	395.3	0.00	1.00
07/02/2026 05:00	0.8	0.7	0.0	0.9	14.2	391.0	0.00	1.00
07/02/2026 06:00	0.8	0.7	0.0	0.9	14.3	390.8	0.00	1.00
07/02/2026 07:00	0.8	0.7	0.0	0.9	14.3	390.7	0.00	1.00
07/02/2026 08:00	0.8	0.7	0.0	0.9	14.3	391.0	0.00	1.00
07/02/2026 09:00	0.8	0.7	0.0	0.9	14.3	391.5	0.00	1.00
07/02/2026 10:00	0.7	0.7	0.0	0.8	14.4	390.0	0.00	1.00
07/02/2026 11:00	0.7	0.7	0.0	0.8	14.4	388.3	0.00	1.00
07/02/2026 12:00	0.7	0.6	0.0	0.8	14.4	387.7	0.00	1.00
07/02/2026 13:00	0.7	0.6	0.0	0.8	14.4	388.4	0.00	1.00
07/02/2026 14:00	0.7	0.6	0.0	0.8	14.5	388.8	0.00	1.00
07/02/2026 15:00	0.7	0.6	0.0	0.8	14.5	389.1	0.00	1.00
07/02/2026 16:00	0.7	0.6	0.0	0.8	14.5	389.2	0.00	1.00
07/02/2026 17:00	0.7	0.6	0.0	0.8	14.5	403.5	0.00	1.00
07/02/2026 18:00	0.7	0.6	0.0	0.8	14.4	388.1	0.00	1.00
07/02/2026 19:00	0.7	0.6	0.0	0.8	14.4	386.7	0.00	1.00
07/02/2026 20:00	0.7	0.6	0.0	0.8	14.4	388.5	0.00	1.00
07/02/2026 21:00	0.7	0.6	0.0	0.8	14.4	388.7	0.00	1.00
07/02/2026 22:00	0.7	0.6	0.0	0.8	14.3	393.5	0.00	1.00
07/02/2026 23:00	0.7	0.6	0.0	0.8	14.4	447.2	0.00	1.00
Average/Sum#:	0.7	0.7	0.0	0.8	14.4	392.9	0.00 #	24.00 #
Minimum:	0.7	0.6	0.0	0.8	14.2	386.7	0.00	1.00
Maximum:	0.8	0.7	0.0	0.9	14.5	447.2	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/03/2026 00:00	0.8	0.7	0.0	0.9	14.3	395.3	0.00	1.00
07/03/2026 01:00	0.8	0.7	0.0	0.9	14.3	380.1	0.00	1.00
07/03/2026 02:00	0.8	0.7	0.0	0.9	14.3	378.2	0.00	1.00
07/03/2026 03:00	0.8	0.7	0.0	0.9	14.3	378.1	0.00	1.00
07/03/2026 04:00	0.8	0.7	0.0	0.9	14.3	391.7	0.00	1.00
07/03/2026 05:00	0.8	0.7	0.0	0.9	14.2	393.6	0.00	1.00
07/03/2026 06:00	0.8	0.7	0.0	0.9	14.3	394.7	0.00	1.00
07/03/2026 07:00	0.8	0.7	0.0	0.9	14.3	395.1	0.00	1.00
07/03/2026 08:00	0.8	0.7	0.0	0.9	14.3	395.9	0.00	1.00
07/03/2026 09:00	0.7	0.7	0.0	0.8	14.4	392.9	0.00	1.00
07/03/2026 10:00	0.7	0.7	0.0	0.8	14.4	392.3	0.00	1.00
07/03/2026 11:00	0.7	0.7	0.0	0.8	14.4	392.8	0.00	1.00
07/03/2026 12:00	0.7	0.7	0.0	0.8	14.5	393.3	0.00	1.00
07/03/2026 13:00	0.7	0.7	0.0	0.8	14.5	393.6	0.00	1.00
07/03/2026 14:00	0.7	0.7	0.0	0.8	14.5	393.3	0.00	1.00
07/03/2026 15:00	0.7	0.7	0.0	0.8	14.5	393.1	0.00	1.00
07/03/2026 16:00	0.8	0.7	0.0	0.9	14.5	406.8	0.00	1.00
07/03/2026 17:00	0.7	0.7	0.0	0.8	14.4	410.8	0.00	1.00
07/03/2026 18:00	0.7	0.7	0.0	0.8	14.3	392.7	0.00	1.00
07/03/2026 19:00	0.7	0.6	0.0	0.8	14.3	395.1	0.00	1.00
07/03/2026 20:00	0.7	0.6	0.0	0.8	14.3	394.2	0.00	1.00
07/03/2026 21:00	0.7	0.6	0.0	0.8	14.3	394.4	0.00	1.00
07/03/2026 22:00	0.8	0.6	0.0	0.9	14.3	393.3	0.00	1.00
07/03/2026 23:00	0.7	0.7	0.0	0.8	14.4	404.4	0.00	1.00
Average/Sum#:	0.7	0.7	0.0	0.8	14.4	393.6	0.00 #	24.00 #
Minimum:	0.7	0.6	0.0	0.8	14.2	378.1	0.00	1.00
Maximum:	0.8	0.7	0.0	0.9	14.5	410.8	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/04/2026 00:00	0.7	0.7	0.0	0.8	14.5	448.3	0.00	1.00
07/04/2026 01:00	0.8	0.7	0.0	0.9	14.3	392.8	0.00	1.00
07/04/2026 02:00	0.8	0.7	0.0	0.9	14.3	381.2	0.00	1.00
07/04/2026 03:00	0.8	0.7	0.0	0.9	14.3	377.8	0.00	1.00
07/04/2026 04:00	0.8	0.7	0.0	0.9	14.3	378.5	0.00	1.00
07/04/2026 05:00	0.8	0.7	0.0	0.9	14.4	442.9	0.00	1.00
07/04/2026 06:00	0.7	0.7	0.0	0.8	14.4	438.4	0.00	1.00
07/04/2026 07:00	0.8	0.7	0.0	0.9	14.3	405.3	0.00	1.00
07/04/2026 08:00	0.7	0.7	0.0	0.8	14.3	392.2	0.00	1.00
07/04/2026 09:00	0.7	0.7	0.0	0.8	14.4	392.1	0.00	1.00
07/04/2026 10:00	0.7	0.7	0.0	0.8	14.4	393.0	0.00	1.00
07/04/2026 11:00	0.7	0.7	0.0	0.8	14.4	391.0	0.00	1.00
07/04/2026 12:00	0.7	0.7	0.0	0.8	14.5	389.7	0.00	1.00
07/04/2026 13:00	0.7	0.7	0.0	0.8	14.5	389.7	0.00	1.00
07/04/2026 14:00	0.7	0.7	0.0	0.8	14.5	392.8	0.00	1.00
07/04/2026 15:00	0.6	0.7	0.0	0.7	14.5	456.3	0.00	1.00
07/04/2026 16:00	0.6	0.7	0.0	0.7	14.5	461.8	0.00	1.00
07/04/2026 17:00	0.6	0.7	0.0	0.7	14.5	455.7	0.00	1.00
07/04/2026 18:00	0.6	0.7	0.0	0.7	14.4	437.4	0.00	1.00
07/04/2026 19:00	0.8	0.8	0.0	1.0	13.9	514.9	0.00	1.00
07/04/2026 20:00	0.9	0.9	0.0	1.0	14.0	470.1	0.00	1.00
07/04/2026 21:00	0.8	0.9	0.0	0.9	14.3	379.8	0.00	1.00
07/04/2026 22:00	0.7	0.8	0.0	0.8	14.3	396.2	0.00	1.00
07/04/2026 23:00	0.7	0.7	0.0	0.8	14.4	441.2	0.00	1.00
Average/Sum#:	0.7	0.7	0.0	0.8	14.4	417.5	0.00 #	24.00 #
Minimum:	0.6	0.7	0.0	0.7	13.9	377.8	0.00	1.00
Maximum:	0.9	0.9	0.0	1.0	14.5	514.9	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/05/2026 00:00	0.7	0.7	0.0	0.8	14.3	413.1	0.00	1.00
07/05/2026 01:00	0.8	0.7	0.0	0.9	14.2	395.5	0.00	1.00
07/05/2026 02:00	0.8	0.7	0.0	0.9	14.3	396.6	0.00	1.00
07/05/2026 03:00	0.8	0.7	0.0	0.9	14.3	395.4	0.00	1.00
07/05/2026 04:00	0.8	0.7	0.0	0.9	14.3	396.3	0.00	1.00
07/05/2026 05:00	0.7	0.7	0.0	0.8	14.4	434.9	0.00	1.00
07/05/2026 06:00	0.8	0.7	0.0	0.9	14.3	412.0	0.00	1.00
07/05/2026 07:00	0.8	0.7	0.0	0.9	14.3	395.7	0.00	1.00
07/05/2026 08:00	0.8	0.7	0.0	0.9	14.3	394.3	0.00	1.00
07/05/2026 09:00	0.8	0.7	0.0	0.9	14.3	383.2	0.00	1.00
07/05/2026 10:00	0.8	0.7	0.0	0.9	14.4	383.6	0.00	1.00
07/05/2026 11:00	0.7	0.7	0.0	0.8	14.4	382.3	0.00	1.00
07/05/2026 12:00	0.7	0.7	0.0	0.8	14.4	379.5	0.00	1.00
07/05/2026 13:00	0.7	0.6	0.0	0.8	14.5	378.4	0.00	1.00
07/05/2026 14:00	0.7	0.6	0.0	0.8	14.5	377.8	0.00	1.00
07/05/2026 15:00	0.7	0.6	0.0	0.8	14.5	378.8	0.00	1.00
07/05/2026 16:00	0.7	0.6	0.0	0.8	14.5	382.2	0.00	1.00
07/05/2026 17:00	0.6	0.6	0.0	0.7	14.5	462.7	0.00	1.00
07/05/2026 18:00	0.6	0.7	0.0	0.7	14.4	461.8	0.00	1.00
07/05/2026 19:00	0.6	0.7	0.0	0.7	14.4	460.8	0.00	1.00
07/05/2026 20:00	0.7	0.7	0.0	0.8	14.4	460.7	0.00	1.00
07/05/2026 21:00	0.7	0.7	0.0	0.8	14.4	460.7	0.00	1.00
07/05/2026 22:00	0.8	0.7	0.0	0.9	14.3	406.8	0.00	1.00
07/05/2026 23:00	0.8	0.7	0.0	0.9	14.3	386.7	0.00	1.00
Average/Sum#:	0.7	0.7	0.0	0.8	14.4	407.5	0.00 #	24.00 #
Minimum:	0.6	0.6	0.0	0.7	14.2	377.8	0.00	1.00
Maximum:	0.8	0.7	0.0	0.9	14.5	462.7	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/06/2026 00:00	0.8	0.7	0.0	0.9	14.3	388.9	0.00	1.00
07/06/2026 01:00	0.8	0.7	0.0	0.9	14.3	382.5	0.00	1.00
07/06/2026 02:00	0.8	0.7	0.0	0.9	14.2	382.4	0.00	1.00
07/06/2026 03:00	0.8	0.7	0.0	0.9	14.2	382.5	0.00	1.00
07/06/2026 04:00	0.8	0.7	0.0	0.9	14.3	417.5	0.00	1.00
07/06/2026 05:00	0.8	0.7	0.0	0.9	14.2	401.1	0.00	1.00
07/06/2026 06:00	0.8	0.7	0.0	0.9	14.2	381.4	0.00	1.00
07/06/2026 07:00	0.8	0.7	0.0	0.9	14.3	381.4	0.00	1.00
07/06/2026 08:00	0.8	0.7	0.0	0.9	14.3	381.8	0.00	1.00
07/06/2026 09:00	0.8	0.7	0.0	0.9	14.3	383.0	0.00	1.00
07/06/2026 10:00	0.8	0.7	0.0	0.9	14.4	383.1	0.00	1.00
07/06/2026 11:00	0.8	0.7	0.0	0.9	14.4	382.2	0.00	1.00
07/06/2026 12:00	0.8	0.7	0.0	0.9	14.4	379.5	0.00	1.00
07/06/2026 13:00	0.7	0.7	0.0	0.8	14.5	395.7	0.00	1.00
07/06/2026 14:00	0.7	0.7	0.0	0.8	14.5	394.4	0.00	1.00
07/06/2026 15:00	0.7	0.7	0.0	0.8	14.6	417.5	0.00	1.00
07/06/2026 16:00	0.7	0.7	0.0	0.8	14.6	427.4	0.00	1.00
07/06/2026 17:00	0.7	0.7	0.0	0.8	14.4	422.4	0.00	1.00
07/06/2026 18:00	0.6	0.7	0.0	0.7	14.5	464.2	0.00	1.00
07/06/2026 19:00	0.6	0.7	0.0	0.7	14.4	464.8	0.00	1.00
07/06/2026 20:00	0.6	0.7	0.0	0.7	14.4	464.2	0.00	1.00
07/06/2026 21:00	0.7	0.7	0.0	0.8	14.4	464.4	0.00	1.00
07/06/2026 22:00	0.7	0.7	0.0	0.8	14.4	463.6	0.00	1.00
07/06/2026 23:00	0.7	0.7	0.0	0.8	14.4	462.5	0.00	1.00
Average/Sum#:	0.7	0.7	0.0	0.8	14.4	411.2	0.00 #	24.00 #
Minimum:	0.6	0.7	0.0	0.7	14.2	379.5	0.00	1.00
Maximum:	0.8	0.7	0.0	0.9	14.6	464.8	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/07/2026 00:00	0.7	0.8	0.0	0.8	14.4	461.8	0.00	1.00
07/07/2026 01:00	0.7	0.8	0.0	0.8	14.4	448.8	0.00	1.00
07/07/2026 02:00	0.7	0.7	0.0	0.8	14.4	460.7	0.00	1.00
07/07/2026 03:00	0.7	0.7	0.0	0.8	14.4	460.9	0.00	1.00
07/07/2026 04:00	0.7	0.7	0.0	0.8	14.4	462.3	0.00	1.00
07/07/2026 05:00	0.7	0.7	0.0	0.8	14.3	430.1	0.00	1.00
07/07/2026 06:00	0.8	0.7	0.0	0.9	14.2	383.4	0.00	1.00
07/07/2026 07:00	0.8	0.7	0.0	0.9	14.2	383.3	0.00	1.00
07/07/2026 08:00	0.8	0.7	0.0	0.9	14.3	383.5	0.00	1.00
07/07/2026 09:00	0.8	0.7	0.0	0.9	14.3	383.9	0.00	1.00
07/07/2026 10:00	0.8	0.7	0.0	0.9	14.3	383.8	0.00	1.00
07/07/2026 11:00	0.7	0.7	0.0	0.8	14.5	422.8	0.00	1.00
07/07/2026 12:00	0.7	0.7	0.0	0.8	14.4	409.2	0.00	1.00
07/07/2026 13:00	0.7	0.7	0.0	0.8	14.5	413.2	0.00	1.00
07/07/2026 14:00	0.7	0.7	0.0	0.7	14.6	441.6	0.00	1.00
07/07/2026 15:00	0.7	0.7	0.0	0.8	14.5	416.3	0.00	1.00
07/07/2026 16:00	0.7	0.7	0.0	0.8	14.5	419.9	0.00	1.00
07/07/2026 17:00	0.7	0.7	0.0	0.7	14.6	434.8	0.00	1.00
07/07/2026 18:00	0.7	0.7	0.0	0.7	14.6	456.9	0.00	1.00
07/07/2026 19:00	0.6	0.7	0.0	0.7	14.5	458.9	0.00	1.00
07/07/2026 20:00	0.7	0.7	0.0	0.8	14.5	457.8	0.00	1.00
07/07/2026 21:00	0.7	0.7	0.0	0.8	14.4	456.1	0.00	1.00
07/07/2026 22:00	0.7	0.7	0.0	0.8	14.4	455.9	0.00	1.00
07/07/2026 23:00	0.7	0.7	0.0	0.8	14.3	443.2	0.00	1.00
Average/Sum#:	0.7	0.7	0.0	0.8	14.4	430.4	0.00 #	24.00 #
Minimum:	0.6	0.7	0.0	0.7	14.2	383.3	0.00	1.00
Maximum:	0.8	0.8	0.0	0.9	14.6	462.3	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/08/2026 00:00	0.7	0.7	0.0	0.8	14.4	458.9	0.00	1.00
07/08/2026 01:00	0.8	0.7	0.0	0.9	14.2	395.3	0.00	1.00
07/08/2026 02:00	0.8	0.7	0.0	0.9	14.2	379.7	0.00	1.00
07/08/2026 03:00	0.8	0.7	0.0	0.9	14.2	379.8	0.00	1.00
07/08/2026 04:00	0.8	0.7	0.0	0.9	14.2	380.0	0.00	1.00
07/08/2026 05:00	0.8	0.7	0.0	0.9	14.2	381.1	0.00	1.00
07/08/2026 06:00	0.8	0.7	0.0	0.9	14.2	385.7	0.00	1.00
07/08/2026 07:00	0.8	0.7	0.0	0.9	14.2	380.6	0.00	1.00
07/08/2026 08:00	0.8	0.7	0.0	0.9	14.3	381.6	0.00	1.00
07/08/2026 09:00	0.8	0.7	0.0	0.9	14.3	382.7	0.00	1.00
07/08/2026 10:00	0.8	0.7	0.0	0.9	14.3	381.8	0.00	1.00
07/08/2026 11:00	0.8	0.7	0.0	0.9	14.4	380.8	0.00	1.00
07/08/2026 12:00	0.8	0.7	0.0	0.9	14.4	381.1	0.00	1.00
07/08/2026 13:00	0.7	0.7	0.0	0.8	14.4	381.8	0.00	1.00
07/08/2026 14:00	0.7	0.6	0.0	0.8	14.4	381.5	0.00	1.00
07/08/2026 15:00	0.7	0.6	0.0	0.8	14.5	379.1	0.00	1.00
07/08/2026 16:00	0.7	0.6	0.0	0.8	14.5	378.3	0.00	1.00
07/08/2026 17:00	0.7	0.6	0.0	0.8	14.5	406.2	0.00	1.00
07/08/2026 18:00	0.7	0.7	0.0	0.8	14.5	417.0	0.00	1.00
07/08/2026 19:00	0.7	0.7	0.0	0.8	14.4	381.2	0.00	1.00
07/08/2026 20:00	0.8	0.7	0.0	0.9	14.4	381.0	0.00	1.00
07/08/2026 21:00	0.8	0.7	0.0	0.9	14.3	380.8	0.00	1.00
07/08/2026 22:00	0.8	0.7	0.0	0.9	14.3	379.8	0.00	1.00
07/08/2026 23:00	0.8	0.7	0.0	0.9	14.3	378.9	0.00	1.00
Average/Sum#:	0.8	0.7	0.0	0.9	14.3	387.3	0.00 #	24.00 #
Minimum:	0.7	0.6	0.0	0.8	14.2	378.3	0.00	1.00
Maximum:	0.8	0.7	0.0	0.9	14.5	458.9	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/09/2026 00:00	0.8	0.7	0.0	0.9	14.3	378.8	0.00	1.00
07/09/2026 01:00	0.8	0.7	0.0	0.9	14.3	378.7	0.00	1.00
07/09/2026 02:00	0.8	0.7	0.0	0.9	14.3	378.5	0.00	1.00
07/09/2026 03:00	0.8	0.7	0.0	0.9	14.3	381.2	0.00	1.00
07/09/2026 04:00	0.8	0.7	0.0	0.9	14.3	400.3	0.00	1.00
07/09/2026 05:00	0.8	0.7	0.0	0.9	14.3	404.6	0.00	1.00
07/09/2026 06:00	0.8	0.7	0.0	0.9	14.3	382.0	0.00	1.00
07/09/2026 07:00	0.8	0.7	0.0	0.9	14.3	382.4	0.00	1.00
07/09/2026 08:00	0.8	0.7	0.0	0.9	14.3	381.3	0.00	1.00
07/09/2026 09:00	0.8	0.7	0.0	0.9	14.4	379.8	0.00	1.00
07/09/2026 10:00	0.8	0.7	0.0	0.9	14.4	379.7	0.00	1.00
07/09/2026 11:00	0.7	0.7	0.0	0.8	14.4	380.6	0.00	1.00
07/09/2026 12:00	0.7	0.7	0.0	0.8	14.5	379.6	0.00	1.00
07/09/2026 13:00	0.7	0.7	0.0	0.8	14.5	393.8	0.00	1.00
07/09/2026 14:00	0.7	0.6	0.0	0.8	14.5	378.6	0.00	1.00
07/09/2026 15:00	0.7	0.6	0.0	0.8	14.5	373.4	0.00	1.00
07/09/2026 16:00	0.7	0.6	0.0	0.8	14.5	405.2	0.00	1.00
07/09/2026 17:00	0.7	0.7	0.0	0.8	14.4	421.4	0.00	1.00
07/09/2026 18:00	0.6	0.7	0.0	0.7	14.5	461.8	0.00	1.00
07/09/2026 19:00	0.6	0.7	0.0	0.7	14.5	460.3	0.00	1.00
07/09/2026 20:00	0.7	0.7	0.0	0.8	14.5	427.3	0.00	1.00
07/09/2026 21:00	0.7	0.7	0.0	0.8	14.5	426.6	0.00	1.00
07/09/2026 22:00	0.7	0.7	0.0	0.8	14.5	429.3	0.00	1.00
07/09/2026 23:00	0.7	0.7	0.0	0.8	14.5	423.7	0.00	1.00
Average/Sum#:	0.7	0.7	0.0	0.8	14.4	399.5	0.00 #	24.00 #
Minimum:	0.6	0.6	0.0	0.7	14.3	373.4	0.00	1.00
Maximum:	0.8	0.7	0.0	0.9	14.5	461.8	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/10/2026 00:00	0.8	0.7	0.0	0.9	14.4	400.3	0.00	1.00
07/10/2026 01:00	0.8	0.7	0.0	0.9	14.3	386.6	0.00	1.00
07/10/2026 02:00	0.8	0.7	0.0	0.9	14.3	383.6	0.00	1.00
07/10/2026 03:00	0.7	0.7	0.0	0.8	14.4	449.6	0.00	1.00
07/10/2026 04:00	0.7	0.7	0.0	0.8	14.4	424.0	0.00	1.00
07/10/2026 05:00	0.8	0.7	0.0	0.9	14.4	425.2	0.00	1.00
07/10/2026 06:00	0.8	0.7	0.0	0.9	14.3	384.4	0.00	1.00
07/10/2026 07:00	0.8	0.7	0.0	0.9	14.3	384.1	0.00	1.00
07/10/2026 08:00	0.8	0.7	0.0	0.9	14.4	384.0	0.00	1.00
07/10/2026 09:00	0.8	0.7	0.0	0.9	14.4	383.1	0.00	1.00
07/10/2026 10:00	0.8	0.7	0.0	0.9	14.4	381.1	0.00	1.00
07/10/2026 11:00	0.7	0.7	0.0	0.8	14.4	380.9	0.00	1.00
07/10/2026 12:00	0.7	0.6	0.0	0.8	14.5	380.6	0.00	1.00
07/10/2026 13:00	0.7	0.6	0.0	0.8	14.5	379.4	0.00	1.00
07/10/2026 14:00	0.7	0.6	0.0	0.8	14.5	378.5	0.00	1.00
07/10/2026 15:00	0.7	0.6	0.0	0.8	14.5	391.2	0.00	1.00
07/10/2026 16:00	0.7	0.6	0.0	0.8	14.5	405.9	0.00	1.00
07/10/2026 17:00	0.8	0.7	0.0	0.9	13.8	513.7	0.00	1.00
07/10/2026 18:00	0.4	0.7	0.0	0.5	13.2	559.6	0.00	1.00
07/10/2026 19:00	0.5	0.7	0.0	0.6	13.4	550.1	0.00	1.00
07/10/2026 20:00	0.8	0.7	0.0	1.0	13.9	528.1	0.00	1.00
07/10/2026 21:00	0.9	0.9	0.0	1.1	13.9	525.1	0.00	1.00
07/10/2026 22:00	0.9	1.1	0.0	1.1	14.0	523.8	0.00	1.00
07/10/2026 23:00	1.0	1.1	0.0	1.2	14.1	522.6	0.00	1.00
Average/Sum#:	0.8	0.7	0.0	0.9	14.2	434.4	0.00 #	24.00 #
Minimum:	0.4	0.6	0.0	0.5	13.2	378.5	0.00	1.00
Maximum:	1.0	1.1	0.0	1.2	14.5	559.6	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/11/2026 00:00	1.0	1.2	0.0	1.2	14.1	521.3	0.00	1.00
07/11/2026 01:00	1.0	1.2	0.0	1.2	14.1	519.6	0.00	1.00
07/11/2026 02:00	1.1	1.2	0.0	1.3	14.1	517.8	0.00	1.00
07/11/2026 03:00	1.2	1.3	0.0	1.4	14.2	517.0	0.00	1.00
07/11/2026 04:00	1.1	1.3	0.0	1.3	14.2	476.5	0.00	1.00
07/11/2026 05:00	0.8	1.1	0.0	0.9	14.3	403.9	0.00	1.00
07/11/2026 06:00	0.8	0.9	0.0	0.9	14.3	389.2	0.00	1.00
07/11/2026 07:00	0.8	0.7	0.0	0.9	14.3	382.0	0.00	1.00
07/11/2026 08:00	0.8	0.7	0.0	0.9	14.3	382.9	0.00	1.00
07/11/2026 09:00	0.8	0.7	0.0	0.9	14.4	383.5	0.00	1.00
07/11/2026 10:00	0.8	0.7	0.0	0.9	14.4	381.6	0.00	1.00
07/11/2026 11:00	0.7	0.7	0.0	0.8	14.4	381.0	0.00	1.00
07/11/2026 12:00	0.7	0.6	0.0	0.8	14.4	380.9	0.00	1.00
07/11/2026 13:00	0.7	0.6	0.0	0.8	14.5	378.6	0.00	1.00
07/11/2026 14:00	0.7	0.6	0.0	0.8	14.5	378.1	0.00	1.00
07/11/2026 15:00	0.7	0.6	0.0	0.8	14.5	404.1	0.00	1.00
07/11/2026 16:00	0.8	0.6	0.0	0.9	14.5	396.3	0.00	1.00
07/11/2026 17:00	0.7	0.7	0.0	0.8	13.6	527.3	0.00	1.00
07/11/2026 18:00	0.8	0.8	0.0	1.0	13.8	534.7	0.00	1.00
07/11/2026 19:00	0.9	1.0	0.0	1.1	13.9	528.3	0.00	1.00
07/11/2026 20:00	0.7	1.0	0.0	0.8	13.7	534.0	0.00	1.00
07/11/2026 21:00	0.5	0.8	0.0	0.7	13.4	554.3	0.00	1.00
07/11/2026 22:00	0.8	0.8	0.0	0.9	13.8	530.3	0.00	1.00
07/11/2026 23:00	0.4	0.7	0.0	0.5	13.0	591.3	0.00	1.00
Average/Sum#:	0.8	0.9	0.0	0.9	14.1	458.1	0.00 #	24.00 #
Minimum:	0.4	0.6	0.0	0.5	13.0	378.1	0.00	1.00
Maximum:	1.2	1.3	0.0	1.4	14.5	591.3	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/12/2026 00:00	0.8	0.8	0.0	1.0	13.9	526.9	0.00	1.00
07/12/2026 01:00	0.9	0.9	0.0	1.1	13.9	525.3	0.00	1.00
07/12/2026 02:00	0.9	1.1	0.0	1.1	13.9	524.5	0.00	1.00
07/12/2026 03:00	0.9	1.1	0.0	1.1	13.9	524.3	0.00	1.00
07/12/2026 04:00	0.9	1.1	0.0	1.1	14.0	523.5	0.00	1.00
07/12/2026 05:00	0.9	1.1	0.0	1.1	14.0	522.9	0.00	1.00
07/12/2026 06:00	0.9	1.1	0.0	1.1	13.9	528.7	0.00	1.00
07/12/2026 07:00	0.5	0.9	0.0	0.6	13.2	587.0	0.00	1.00
07/12/2026 08:00	0.2	0.7	0.0	0.3	12.8	610.5	0.00	1.00
07/12/2026 09:00	0.7	0.6	0.0	0.8	13.7	540.7	0.00	1.00
07/12/2026 10:00	0.8	0.7	0.0	1.0	13.9	523.3	0.00	1.00
07/12/2026 11:00	0.7	0.9	0.0	0.9	13.8	528.4	0.00	1.00
07/12/2026 12:00	0.6	0.9	0.0	0.7	13.6	534.9	0.00	1.00
07/12/2026 13:00	0.3	0.7	0.0	0.4	12.9	583.5	0.00	1.00
07/12/2026 14:00	0.2	0.5	0.0	0.3	12.7	618.3	0.00	1.00
07/12/2026 15:00	0.1	0.3	0.0	0.2	12.3	651.0	0.00	1.00
07/12/2026 16:00	0.1	0.2	0.0	0.2	12.3	651.3	0.00	1.00
07/12/2026 17:00	0.5	0.3	0.0	0.6	13.2	581.9	0.00	1.00
07/12/2026 18:00	0.7	0.6	0.0	0.9	13.7	546.5	0.00	1.00
07/12/2026 19:00	0.1	0.6	0.0	0.2	12.4	642.2	0.00	1.00
07/12/2026 20:00	0.1	0.4	0.0	0.2	12.3	657.5	0.00	1.00
07/12/2026 21:00	0.1	0.2	0.0	0.2	12.3	654.6	0.00	1.00
07/12/2026 22:00	0.5	0.3	0.0	0.6	13.0	590.3	0.00	1.00
07/12/2026 23:00	0.8	0.5	0.0	1.0	14.3	398.3	0.00	1.00
Average/Sum#:	0.6	0.7	0.0	0.7	13.3	565.7	0.00 #	24.00 #
Minimum:	0.1	0.2	0.0	0.2	12.3	398.3	0.00	1.00
Maximum:	0.9	1.1	0.0	1.1	14.3	657.5	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/13/2026 00:00	0.8	0.7	0.0	0.9	14.4	411.1	0.00	1.00
07/13/2026 01:00	0.7	0.8	0.0	0.8	14.6	461.2	0.00	1.00
07/13/2026 02:00	0.7	0.8	0.0	0.8	14.6	461.6	0.00	1.00
07/13/2026 03:00	0.7	0.8	0.0	0.8	14.5	451.3	0.00	1.00
07/13/2026 04:00	0.7	0.8	0.0	0.8	14.5	458.6	0.00	1.00
07/13/2026 05:00	0.9	0.8	0.0	1.0	14.4	427.5	0.00	1.00
07/13/2026 06:00	0.9	0.9	0.0	1.0	14.5	458.9	0.00	1.00
07/13/2026 07:00	0.9	0.9	0.0	1.0	14.5	453.1	0.00	1.00
07/13/2026 08:00	0.5	0.8	0.0	0.7	13.0	582.1	0.00	1.00
07/13/2026 09:00	0.2	0.6	0.0	0.3	12.1	662.0	0.00	1.00
07/13/2026 10:00	0.1	0.4	0.0	0.2	12.1	660.2	0.00	1.00
07/13/2026 11:00	0.1	0.2	0.0	0.2	12.2	659.2	0.00	1.00
07/13/2026 12:00	0.1	0.2	0.0	0.2	12.2	658.2	0.00	1.00
07/13/2026 13:00	0.1	0.2	0.0	0.2	12.1	661.5	0.00	1.00
07/13/2026 14:00	0.1	0.2	0.0	0.2	12.1	660.9	0.00	1.00
07/13/2026 15:00	0.1	0.2	0.0	0.2	12.1	660.9	0.00	1.00
07/13/2026 16:00	0.1	0.2	0.0	0.2	12.1	661.0	0.00	1.00
07/13/2026 17:00	0.1	0.2	0.0	0.2	12.1	655.7	0.00	1.00
07/13/2026 18:00	0.1	0.2	0.0	0.2	12.2	654.7	0.00	1.00
07/13/2026 19:00	0.1	0.2	0.0	0.2	12.1	659.7	0.00	1.00
07/13/2026 20:00	0.1	0.2	0.0	0.2	12.2	655.7	0.00	1.00
07/13/2026 21:00	0.1	0.2	0.0	0.2	12.5	641.1	0.00	1.00
07/13/2026 22:00	0.8	0.4	0.0	0.9	13.4	561.9	0.00	1.00
07/13/2026 23:00	0.9	0.7	0.0	1.0	13.8	538.1	0.00	1.00
Average/Sum#:	0.4	0.5	0.0	0.5	13.1	575.7	0.00 #	24.00 #
Minimum:	0.1	0.2	0.0	0.2	12.1	411.1	0.00	1.00
Maximum:	0.9	0.9	0.0	1.0	14.6	662.0	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/14/2026 00:00	0.6	0.9	0.0	0.7	13.4	567.1	0.00	1.00
07/14/2026 01:00	0.9	0.9	0.0	1.1	13.9	525.7	0.00	1.00
07/14/2026 02:00	0.8	0.9	0.0	1.0	13.8	526.8	0.00	1.00
07/14/2026 03:00	0.9	1.1	0.0	1.1	13.9	525.2	0.00	1.00
07/14/2026 04:00	0.9	1.1	0.0	1.1	13.9	525.7	0.00	1.00
07/14/2026 05:00	0.6	1.0	0.0	0.8	13.5	556.4	0.00	1.00
07/14/2026 06:00	0.9	1.0	0.0	1.1	14.0	521.9	0.00	1.00
07/14/2026 07:00	0.8	0.9	0.0	0.9	13.9	524.6	0.00	1.00
07/14/2026 08:00	0.7	0.9	0.0	0.8	13.7	528.8	0.00	1.00
07/14/2026 09:00	0.4	0.7	0.0	0.5	13.4	536.8	0.00	1.00
07/14/2026 10:00	0.3	0.5	0.0	0.4	13.1	541.7	0.00	1.00
07/14/2026 11:00	0.1	0.3	0.0	0.2	12.8	548.9	0.00	1.00
07/14/2026 12:00	0.5	0.4	0.0	0.6	13.3	558.6	0.00	1.00
07/14/2026 13:00	0.4	0.4	0.0	0.5	13.0	589.2	0.00	1.00
07/14/2026 14:00	0.1	0.4	0.0	0.2	12.5	629.1	0.00	1.00
07/14/2026 15:00	0.1	0.3	0.0	0.2	12.2	646.6	0.00	1.00
07/14/2026 16:00	0.1	0.2	0.0	0.2	12.3	642.2	0.00	1.00
07/14/2026 17:00	0.1	0.2	0.0	0.2	12.2	651.8	0.00	1.00
07/14/2026 18:00	0.1	0.2	0.0	0.2	12.2	649.3	0.00	1.00
07/14/2026 19:00	0.1	0.2	0.0	0.2	12.4	632.0	0.00	1.00
07/14/2026 20:00	0.3	0.3	0.0	0.4	12.8	607.3	0.00	1.00
07/14/2026 21:00	0.2	0.3	0.0	0.3	12.7	618.8	0.00	1.00
07/14/2026 22:00	0.6	0.5	0.0	0.8	13.5	558.4	0.00	1.00
07/14/2026 23:00	1.0	0.8	0.0	1.2	13.9	525.7	0.00	1.00
Average/Sum#:	0.5	0.6	0.0	0.6	13.2	572.4	0.00 #	24.00 #
Minimum:	0.1	0.2	0.0	0.2	12.2	521.9	0.00	1.00
Maximum:	1.0	1.1	0.0	1.2	14.0	651.8	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/15/2026 00:00	0.8	1.0	0.0	1.0	13.8	528.7	0.00	1.00
07/15/2026 01:00	0.7	1.0	0.0	0.9	13.8	527.4	0.00	1.00
07/15/2026 02:00	0.7	0.9	0.0	0.9	13.8	524.0	0.00	1.00
07/15/2026 03:00	0.8	0.9	0.0	1.0	13.9	522.3	0.00	1.00
07/15/2026 04:00	0.8	1.0	0.0	1.0	13.9	521.9	0.00	1.00
07/15/2026 05:00	0.8	1.0	0.0	1.0	13.9	523.0	0.00	1.00
07/15/2026 06:00	0.8	1.0	0.0	1.0	13.9	525.6	0.00	1.00
07/15/2026 07:00	0.7	1.0	0.0	0.9	13.8	529.8	0.00	1.00
07/15/2026 08:00	0.6	0.9	0.0	0.7	13.6	535.2	0.00	1.00
07/15/2026 09:00	0.3	0.7	0.0	0.4	13.2	543.0	0.00	1.00
07/15/2026 10:00	0.1	0.4	0.0	0.2	12.1	644.2	0.00	1.00
07/15/2026 11:00	0.1	0.3	0.0	0.2	12.2	652.3	0.00	1.00
07/15/2026 12:00	0.3	0.3	0.0	0.5	12.9	599.3	0.00	1.00
07/15/2026 13:00	0.2	0.3	0.0	0.3	12.5	621.7	0.00	1.00
07/15/2026 14:00	0.2	0.3	0.0	0.3	12.0	663.6	0.00	1.00
07/15/2026 15:00	0.1	0.2	0.0	0.2	12.2	646.4	0.00	1.00
07/15/2026 16:00	0.2	0.3	0.0	0.3	11.9	671.1	0.00	1.00
07/15/2026 17:00	0.1	0.2	0.0	0.2	12.1	656.2	0.00	1.00
07/15/2026 18:00	0.1	0.2	0.0	0.2	12.1	660.4	0.00	1.00
07/15/2026 19:00	0.1	0.2	0.0	0.2	12.4	645.4	0.00	1.00
07/15/2026 20:00	0.2	0.2	0.0	0.3	12.7	626.6	0.00	1.00
07/15/2026 21:00	0.3	0.3	0.0	0.5	12.9	604.4	0.00	1.00
07/15/2026 22:00	0.6	0.5	0.0	0.8	13.5	548.0	0.00	1.00
07/15/2026 23:00	0.7	0.7	0.0	0.9	13.7	536.3	0.00	1.00
Average/Sum#:	0.4	0.6	0.0	0.6	13.0	585.7	0.00 #	24.00 #
Minimum:	0.1	0.2	0.0	0.2	11.9	521.9	0.00	1.00
Maximum:	0.8	1.0	0.0	1.0	13.9	671.1	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/16/2026 00:00	0.8	0.9	0.0	1.0	13.8	534.6	0.00	1.00
07/16/2026 01:00	0.8	0.9	0.0	1.0	13.9	531.1	0.00	1.00
07/16/2026 02:00	0.9	1.0	0.0	1.1	14.0	524.4	0.00	1.00
07/16/2026 03:00	1.0	1.1	0.0	1.2	14.0	522.7	0.00	1.00
07/16/2026 04:00	1.0	1.2	0.0	1.2	14.0	523.5	0.00	1.00
07/16/2026 05:00	1.0	1.2	0.0	1.2	14.0	523.1	0.00	1.00
07/16/2026 06:00	1.0	1.2	0.0	1.2	14.0	522.9	0.00	1.00
07/16/2026 07:00	0.9	1.2	0.0	1.1	14.0	525.0	0.00	1.00
07/16/2026 08:00	0.8	1.1	0.0	1.0	13.9	527.4	0.00	1.00
07/16/2026 09:00	0.7	1.0	0.0	0.9	13.8	529.4	0.00	1.00
07/16/2026 10:00	0.7	0.9	0.0	0.8	13.7	533.9	0.00	1.00
07/16/2026 11:00	0.5	0.8	0.0	0.6	13.4	537.5	0.00	1.00
07/16/2026 12:00	0.2	0.6	0.0	0.3	13.0	547.8	0.00	1.00
07/16/2026 13:00	0.2	0.4	0.0	0.3	12.9	548.4	0.00	1.00
07/16/2026 14:00	0.1	0.2	0.0	0.2	12.7	550.5	0.00	1.00
07/16/2026 15:00	0.1	0.2	0.0	0.2	12.6	554.0	0.00	1.00
07/16/2026 16:00	0.1	0.2	0.0	0.2	12.7	552.1	0.00	1.00
07/16/2026 17:00	0.2	0.2	0.0	0.3	12.9	551.4	0.00	1.00
07/16/2026 18:00	0.3	0.3	0.0	0.4	13.2	542.6	0.00	1.00
07/16/2026 19:00	0.6	0.4	0.0	0.7	13.6	534.5	0.00	1.00
07/16/2026 20:00	0.7	0.7	0.0	0.9	13.8	528.0	0.00	1.00
07/16/2026 21:00	0.8	0.9	0.0	1.0	13.9	525.3	0.00	1.00
07/16/2026 22:00	0.9	1.0	0.0	1.1	13.9	523.5	0.00	1.00
07/16/2026 23:00	0.9	1.1	0.0	1.1	14.0	521.6	0.00	1.00
Average/Sum#:	0.6	0.8	0.0	0.8	13.6	534.0	0.00 #	24.00 #
Minimum:	0.1	0.2	0.0	0.2	12.6	521.6	0.00	1.00
Maximum:	1.0	1.2	0.0	1.2	14.0	554.0	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/17/2026 00:00	0.9	1.1	0.0	1.1	14.0	521.4	0.00	1.00
07/17/2026 01:00	1.0	1.1	0.0	1.2	14.1	520.0	0.00	1.00
07/17/2026 02:00	1.0	1.2	0.0	1.2	14.1	521.4	0.00	1.00
07/17/2026 03:00	1.1	1.2	0.0	1.3	14.1	521.4	0.00	1.00
07/17/2026 04:00	1.2	1.3	0.0	1.4	14.1	520.1	0.00	1.00
07/17/2026 05:00	1.2	1.4	0.0	1.4	14.1	519.9	0.00	1.00
07/17/2026 06:00	1.2	1.4	0.0	1.4	14.1	521.5	0.00	1.00
07/17/2026 07:00	1.0	1.4	0.0	1.2	14.1	523.7	0.00	1.00
07/17/2026 08:00	1.0	1.3	0.0	1.2	14.0	526.2	0.00	1.00
07/17/2026 09:00	0.9	1.2	0.0	1.1	13.9	525.8	0.00	1.00
07/17/2026 10:00	0.9	1.1	0.0	1.1	13.9	527.2	0.00	1.00
07/17/2026 11:00	0.7	1.0	0.0	0.9	13.7	532.3	0.00	1.00
07/17/2026 12:00	0.5	0.8	0.0	0.6	13.4	537.0	0.00	1.00
07/17/2026 13:00	0.3	0.6	0.0	0.4	13.1	543.8	0.00	1.00
07/17/2026 14:00	0.2	0.4	0.0	0.3	12.9	549.4	0.00	1.00
07/17/2026 15:00	0.2	0.3	0.0	0.3	12.8	547.8	0.00	1.00
07/17/2026 16:00	0.2	0.2	0.0	0.3	12.8	548.3	0.00	1.00
07/17/2026 17:00	0.2	0.2	0.0	0.3	13.0	542.7	0.00	1.00
07/17/2026 18:00	0.5	0.4	0.0	0.6	13.4	533.0	0.00	1.00
07/17/2026 19:00	0.7	0.6	0.0	0.9	13.8	526.1	0.00	1.00
07/17/2026 20:00	0.8	0.8	0.0	1.0	13.9	523.4	0.00	1.00
07/17/2026 21:00	0.9	1.0	0.0	1.1	14.0	522.3	0.00	1.00
07/17/2026 22:00	1.0	1.1	0.0	1.2	14.0	520.7	0.00	1.00
07/17/2026 23:00	1.0	1.2	0.0	1.2	14.1	519.2	0.00	1.00
Average/Sum#:	0.8	0.9	0.0	0.9	13.7	528.9	0.00 #	24.00 #
Minimum:	0.2	0.2	0.0	0.3	12.8	519.2	0.00	1.00
Maximum:	1.2	1.4	0.0	1.4	14.1	549.4	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/18/2026 00:00	1.3	1.3	0.0	1.5	14.1	517.6	0.00	1.00
07/18/2026 01:00	1.4	1.4	0.0	1.6	14.1	516.5	0.00	1.00
07/18/2026 02:00	1.5	1.6	0.0	1.7	14.2	515.8	0.00	1.00
07/18/2026 03:00	1.6	1.7	0.0	1.8	14.2	515.9	0.00	1.00
07/18/2026 04:00	1.6	1.8	0.0	1.8	14.2	514.2	0.00	1.00
07/18/2026 05:00	1.6	1.8	0.0	1.8	14.0	529.7	0.00	1.00
07/18/2026 06:00	2.2	2.1	0.0	2.5	14.2	516.0	0.00	1.00
07/18/2026 07:00	2.1	2.3	0.0	2.4	14.2	518.6	0.00	1.00
07/18/2026 08:00	1.6	2.3	0.0	1.8	14.1	522.1	0.00	1.00
07/18/2026 09:00	1.1	1.9	0.0	1.3	14.0	524.0	0.00	1.00
07/18/2026 10:00	1.0	1.4	0.0	1.2	14.0	525.2	0.00	1.00
07/18/2026 11:00	0.9	1.2	0.0	1.0	14.1	457.7	0.00	1.00
07/18/2026 12:00	0.8	1.0	0.0	0.9	14.4	375.0	0.00	1.00
07/18/2026 13:00	0.9	0.9	0.0	1.0	14.5	399.1	0.00	1.00
07/18/2026 14:00	0.4	0.7	0.0	0.6	13.2	540.9	0.00	1.00
07/18/2026 15:00	0.3	0.6	0.0	0.4	13.1	541.7	0.00	1.00
07/18/2026 16:00	0.3	0.4	0.0	0.4	13.0	542.5	0.00	1.00
07/18/2026 17:00	0.2	0.3	0.0	0.3	13.0	542.6	0.00	1.00
07/18/2026 18:00	0.3	0.3	0.0	0.4	13.2	539.0	0.00	1.00
07/18/2026 19:00	0.6	0.5	0.0	0.7	13.6	530.8	0.00	1.00
07/18/2026 20:00	0.7	0.7	0.0	0.9	13.8	529.0	0.00	1.00
07/18/2026 21:00	0.8	0.9	0.0	1.0	13.8	529.8	0.00	1.00
07/18/2026 22:00	0.9	1.0	0.0	1.1	13.9	527.4	0.00	1.00
07/18/2026 23:00	0.9	1.1	0.0	1.1	13.9	525.7	0.00	1.00
Average/Sum#:	1.0	1.2	0.0	1.2	13.9	512.4	0.00 #	24.00 #
Minimum:	0.2	0.3	0.0	0.3	13.0	375.0	0.00	1.00
Maximum:	2.2	2.3	0.0	2.5	14.5	542.6	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/19/2026 00:00	1.0	1.1	0.0	1.2	14.0	524.9	0.00	1.00
07/19/2026 01:00	1.1	1.2	0.0	1.3	14.0	523.3	0.00	1.00
07/19/2026 02:00	1.2	1.3	0.0	1.4	14.1	521.6	0.00	1.00
07/19/2026 03:00	1.2	1.4	0.0	1.4	14.1	519.9	0.00	1.00
07/19/2026 04:00	1.2	1.4	0.0	1.4	14.1	518.2	0.00	1.00
07/19/2026 05:00	1.4	1.5	0.0	1.6	14.1	518.2	0.00	1.00
07/19/2026 06:00	1.4	1.5	0.0	1.6	14.1	519.8	0.00	1.00
07/19/2026 07:00	1.4	1.6	0.0	1.6	14.1	521.0	0.00	1.00
07/19/2026 08:00	1.1	1.5	0.0	1.3	14.0	522.7	0.00	1.00
07/19/2026 09:00	1.0	1.4	0.0	1.2	13.9	524.1	0.00	1.00
07/19/2026 10:00	0.9	1.2	0.0	1.1	13.8	528.2	0.00	1.00
07/19/2026 11:00	0.6	1.0	0.0	0.8	13.6	533.0	0.00	1.00
07/19/2026 12:00	0.4	0.8	0.0	0.5	13.2	541.7	0.00	1.00
07/19/2026 13:00	0.3	0.6	0.0	0.4	13.0	545.6	0.00	1.00
07/19/2026 14:00	0.2	0.4	0.0	0.3	12.9	547.9	0.00	1.00
07/19/2026 15:00	0.2	0.3	0.0	0.3	12.7	550.7	0.00	1.00
07/19/2026 16:00	0.2	0.3	0.0	0.3	12.7	556.0	0.00	1.00
07/19/2026 17:00	0.1	0.2	0.0	0.2	12.4	605.0	0.00	1.00
07/19/2026 18:00	0.2	0.2	0.0	0.3	12.7	619.4	0.00	1.00
07/19/2026 19:00	0.4	0.3	0.0	0.5	13.0	604.9	0.00	1.00
07/19/2026 20:00	0.2	0.4	0.0	0.3	12.4	652.0	0.00	1.00
07/19/2026 21:00	0.2	0.4	0.0	0.3	12.4	656.0	0.00	1.00
07/19/2026 22:00	0.2	0.3	0.0	0.3	12.4	649.5	0.00	1.00
07/19/2026 23:00	0.2	0.3	0.0	0.3	12.5	645.8	0.00	1.00
Average/Sum#:	0.7	0.9	0.0	0.8	13.3	560.4	0.00 #	24.00 #
Minimum:	0.1	0.2	0.0	0.2	12.4	518.2	0.00	1.00
Maximum:	1.4	1.6	0.0	1.6	14.1	656.0	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/20/2026 00:00	0.7	0.5	0.0	0.9	13.5	569.4	0.00	1.00
07/20/2026 01:00	1.0	0.8	0.0	1.2	14.0	524.9	0.00	1.00
07/20/2026 02:00	0.8	1.0	0.0	0.9	13.7	548.4	0.00	1.00
07/20/2026 03:00	0.2	0.8	0.0	0.3	12.4	648.8	0.00	1.00
07/20/2026 04:00	0.2	0.5	0.0	0.3	12.3	659.4	0.00	1.00
07/20/2026 05:00	0.2	0.3	0.0	0.3	12.3	657.3	0.00	1.00
07/20/2026 06:00	0.2	0.3	0.0	0.3	12.5	643.9	0.00	1.00
07/20/2026 07:00	0.2	0.3	0.0	0.3	12.6	630.9	0.00	1.00
07/20/2026 08:00	0.2	0.3	0.0	0.3	12.6	633.6	0.00	1.00
07/20/2026 09:00	0.2	0.3	0.0	0.4	12.8	612.0	0.00	1.00
07/20/2026 10:00	0.2	0.3	0.0	0.3	12.5	640.5	0.00	1.00
07/20/2026 11:00	0.2	0.3	0.0	0.3	12.6	635.5	0.00	1.00
07/20/2026 12:00	0.2	0.3	0.0	0.3	12.7	623.8	0.00	1.00
07/20/2026 13:00	0.1	0.3	0.0	0.2	12.4	644.3	0.00	1.00
07/20/2026 14:00	0.2	0.3	0.0	0.3	12.7	618.1	0.00	1.00
07/20/2026 15:00	0.2	0.3	0.0	0.3	12.7	619.3	0.00	1.00
07/20/2026 16:00	0.2	0.3	0.0	0.3	12.6	629.4	0.00	1.00
07/20/2026 17:00	0.2	0.3	0.0	0.3	12.6	629.2	0.00	1.00
07/20/2026 18:00	0.2	0.3	0.0	0.3	12.4	646.7	0.00	1.00
07/20/2026 19:00	0.2	0.3	0.0	0.3	12.6	635.8	0.00	1.00
07/20/2026 20:00	0.2	0.3	0.0	0.3	12.5	644.4	0.00	1.00
07/20/2026 21:00	0.3	0.3	0.0	0.4	12.7	627.3	0.00	1.00
07/20/2026 22:00	0.7	0.5	0.0	0.9	13.5	564.2	0.00	1.00
07/20/2026 23:00	0.5	0.6	0.0	0.6	13.2	575.9	0.00	1.00
Average/Sum#:	0.3	0.4	0.0	0.4	12.8	619.3	0.00 #	24.00 #
Minimum:	0.1	0.3	0.0	0.2	12.3	524.9	0.00	1.00
Maximum:	1.0	1.0	0.0	1.2	14.0	659.4	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/21/2026 00:00	0.8	0.8	0.0	1.0	13.8	528.4	0.00	1.00
07/21/2026 01:00	0.8	0.9	0.0	1.0	13.8	530.3	0.00	1.00
07/21/2026 02:00	0.8	1.0	0.0	1.0	13.8	530.5	0.00	1.00
07/21/2026 03:00	0.9	1.0	0.0	1.1	13.9	528.1	0.00	1.00
07/21/2026 04:00	0.7	1.0	0.0	0.9	13.6	553.1	0.00	1.00
07/21/2026 05:00	0.2	0.8	0.0	0.3	12.7	621.8	0.00	1.00
07/21/2026 06:00	0.6	0.6	0.0	0.7	13.3	568.2	0.00	1.00
07/21/2026 07:00	0.7	0.6	0.0	0.9	13.6	548.3	0.00	1.00
07/21/2026 08:00	0.5	0.8	0.0	0.7	13.4	561.1	0.00	1.00
07/21/2026 09:00	0.5	0.7	0.0	0.7	13.4	541.7	0.00	1.00
07/21/2026 10:00	0.3	0.6	0.0	0.4	13.0	551.9	0.00	1.00
07/21/2026 11:00	0.2	0.4	0.0	0.3	12.5	591.1	0.00	1.00
07/21/2026 12:00	0.2	0.3	0.0	0.3	12.3	651.6	0.00	1.00
07/21/2026 13:00	0.2	0.3	0.0	0.3	12.4	641.7	0.00	1.00
07/21/2026 14:00	0.2	0.3	0.0	0.3	12.3	645.8	0.00	1.00
07/21/2026 15:00	0.2	0.3	0.0	0.3	12.1	655.1	0.00	1.00
07/21/2026 16:00	0.1	0.3	0.0	0.2	12.3	642.5	0.00	1.00
07/21/2026 17:00	0.2	0.3	0.0	0.3	12.1	651.7	0.00	1.00
07/21/2026 18:00	0.2	0.3	0.0	0.3	12.0	664.2	0.00	1.00
07/21/2026 19:00	0.1	0.3	0.0	0.2	12.0	662.9	0.00	1.00
07/21/2026 20:00	0.1	0.2	0.0	0.2	12.2	657.6	0.00	1.00
07/21/2026 21:00	0.1	0.2	0.0	0.2	12.4	646.5	0.00	1.00
07/21/2026 22:00	0.2	0.2	0.0	0.3	12.5	633.7	0.00	1.00
07/21/2026 23:00	0.3	0.3	0.0	0.4	12.7	619.8	0.00	1.00
Average/Sum#:	0.4	0.5	0.0	0.5	12.8	601.2	0.00 #	24.00 #
Minimum:	0.1	0.2	0.0	0.2	12.0	528.1	0.00	1.00
Maximum:	0.9	1.0	0.0	1.1	13.9	664.2	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/22/2026 00:00	0.9	0.6	0.0	1.1	13.9	525.2	0.00	1.00
07/22/2026 01:00	0.9	0.9	0.0	1.1	13.8	524.9	0.00	1.00
07/22/2026 02:00	0.9	1.1	0.0	1.1	13.9	524.4	0.00	1.00
07/22/2026 03:00	1.0	1.1	0.0	1.2	13.9	523.2	0.00	1.00
07/22/2026 04:00	1.0	1.2	0.0	1.2	13.9	528.3	0.00	1.00
07/22/2026 05:00	0.7	1.1	0.0	0.9	13.5	556.2	0.00	1.00
07/22/2026 06:00	1.0	1.1	0.0	1.2	13.9	522.5	0.00	1.00
07/22/2026 07:00	0.9	1.1	0.0	1.1	13.8	534.2	0.00	1.00
07/22/2026 08:00	0.5	1.0	0.0	0.6	13.3	571.5	0.00	1.00
07/22/2026 09:00	0.9	0.9	0.0	1.1	13.9	523.2	0.00	1.00
07/22/2026 10:00	0.8	0.9	0.0	1.0	13.8	524.8	0.00	1.00
07/22/2026 11:00	0.8	1.0	0.0	1.0	13.8	527.2	0.00	1.00
07/22/2026 12:00	0.7	1.0	0.0	0.9	13.7	529.5	0.00	1.00
07/22/2026 13:00	0.6	0.9	0.0	0.8	13.6	532.0	0.00	1.00
07/22/2026 14:00	0.5	0.8	0.0	0.6	13.4	534.0	0.00	1.00
07/22/2026 15:00	0.5	0.7	0.0	0.6	13.4	533.5	0.00	1.00
07/22/2026 16:00	0.4	0.6	0.0	0.5	13.3	534.5	0.00	1.00
07/22/2026 17:00	0.5	0.5	0.0	0.6	13.4	532.4	0.00	1.00
07/22/2026 18:00	0.6	0.6	0.0	0.8	13.6	528.2	0.00	1.00
07/22/2026 19:00	0.8	0.7	0.0	1.0	13.8	524.1	0.00	1.00
07/22/2026 20:00	1.0	0.9	0.0	1.2	13.9	520.6	0.00	1.00
07/22/2026 21:00	1.1	1.1	0.0	1.3	14.0	518.7	0.00	1.00
07/22/2026 22:00	1.4	1.3	0.0	1.6	14.0	518.0	0.00	1.00
07/22/2026 23:00	1.4	1.5	0.0	1.6	14.1	516.7	0.00	1.00
Average/Sum#:	0.8	0.9	0.0	1.0	13.7	529.5	0.00 #	24.00 #
Minimum:	0.4	0.5	0.0	0.5	13.3	516.7	0.00	1.00
Maximum:	1.4	1.5	0.0	1.6	14.1	571.5	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/23/2026 00:00	1.4	1.6	0.0	1.6	14.1	516.8	0.00	1.00
07/23/2026 01:00	1.4	1.6	0.0	1.6	14.1	516.5	0.00	1.00
07/23/2026 02:00	1.5	1.7	0.0	1.7	14.1	515.2	0.00	1.00
07/23/2026 03:00	1.5	1.7	0.0	1.7	14.1	515.3	0.00	1.00
07/23/2026 04:00	1.5	1.7	0.0	1.7	14.2	515.9	0.00	1.00
07/23/2026 05:00	1.5	1.7	0.0	1.7	14.2	516.1	0.00	1.00
07/23/2026 06:00	1.5	1.7	0.0	1.7	14.1	519.0	0.00	1.00
07/23/2026 07:00	1.4	1.7	0.0	1.6	14.1	520.4	0.00	1.00
07/23/2026 08:00	1.4	1.6	0.0	1.5	14.2	501.8	0.00	1.00
07/23/2026 09:00	0.9	1.3	0.0	1.0	14.3	378.4	0.00	1.00
07/23/2026 10:00	0.9	1.0	0.0	1.0	14.4	375.6	0.00	1.00
07/23/2026 11:00	0.8	0.8	0.0	0.9	14.1	464.0	0.00	1.00
07/23/2026 12:00	0.6	0.8	0.0	0.8	13.6	533.6	0.00	1.00
07/23/2026 13:00	0.5	0.7	0.0	0.6	13.3	537.3	0.00	1.00
07/23/2026 14:00	0.4	0.6	0.0	0.5	13.2	539.3	0.00	1.00
07/23/2026 15:00	0.3	0.5	0.0	0.4	13.1	541.6	0.00	1.00
07/23/2026 16:00	0.3	0.4	0.0	0.4	13.0	542.4	0.00	1.00
07/23/2026 17:00	0.2	0.3	0.0	0.3	13.0	543.8	0.00	1.00
07/23/2026 18:00	0.2	0.3	0.0	0.3	12.8	561.0	0.00	1.00
07/23/2026 19:00	0.5	0.4	0.0	0.7	13.5	537.2	0.00	1.00
07/23/2026 20:00	0.6	0.6	0.0	0.7	13.5	553.3	0.00	1.00
07/23/2026 21:00	0.9	0.8	0.0	1.1	13.8	529.3	0.00	1.00
07/23/2026 22:00	0.9	0.9	0.0	1.1	13.9	530.1	0.00	1.00
07/23/2026 23:00	1.2	1.2	0.0	1.4	13.9	532.2	0.00	1.00
Average/Sum#:	0.9	1.1	0.0	1.1	13.8	514.0	0.00 #	24.00 #
Minimum:	0.2	0.3	0.0	0.3	12.8	375.6	0.00	1.00
Maximum:	1.5	1.7	0.0	1.7	14.4	561.0	0.00	1.00
%SI	0.00	0.00	12.50	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/24/2026 00:00	1.4	1.4	0.0	1.6	14.1	522.1	0.00	1.00
07/24/2026 01:00	1.4	1.5	0.0	1.6	14.1	521.9	0.00	1.00
07/24/2026 02:00	1.4	1.6	0.0	1.6	14.1	521.9	0.00	1.00
07/24/2026 03:00	1.4	1.6	0.0	1.6	14.1	520.8	0.00	1.00
07/24/2026 04:00	1.5	1.6	0.0	1.7	14.1	519.0	0.00	1.00
07/24/2026 05:00	1.5	1.7	0.0	1.7	14.1	518.8	0.00	1.00
07/24/2026 06:00	1.4	1.7	0.0	1.6	14.1	521.5	0.00	1.00
07/24/2026 07:00	1.4	1.7	0.0	1.6	14.1	523.5	0.00	1.00
07/24/2026 08:00	1.1	1.5	0.0	1.3	14.0	526.2	0.00	1.00
07/24/2026 09:00	0.9	1.3	0.0	1.1	13.9	528.7	0.00	1.00
07/24/2026 10:00	0.7	1.1	0.0	0.9	13.7	531.3	0.00	1.00
07/24/2026 11:00	0.9	0.9	0.0	1.0	14.4	383.0	0.00	1.00
07/24/2026 12:00	0.7	0.8	0.0	0.8	13.6	505.9	0.00	1.00
07/24/2026 13:00	0.2	0.6	0.0	0.2	12.5	602.9	0.00	1.00
07/24/2026 14:00	0.1	0.4	0.0	0.2	12.2	655.9	0.00	1.00
07/24/2026 15:00	0.1	0.2	0.0	0.2	12.2	653.1	0.00	1.00
07/24/2026 16:00	0.3	0.3	0.0	0.4	13.0	592.7	0.00	1.00
07/24/2026 17:00	0.3	0.3	0.0	0.4	12.9	607.5	0.00	1.00
07/24/2026 18:00	0.2	0.4	0.0	0.3	12.7	620.7	0.00	1.00
07/24/2026 19:00	0.8	0.5	0.0	0.9	13.6	552.8	0.00	1.00
07/24/2026 20:00	0.8	0.7	0.0	1.0	13.6	555.8	0.00	1.00
07/24/2026 21:00	1.2	1.1	0.0	1.3	13.9	536.7	0.00	1.00
07/24/2026 22:00	1.5	1.4	0.0	1.8	14.1	520.9	0.00	1.00
07/24/2026 23:00	1.4	1.6	0.0	1.6	14.0	522.2	0.00	1.00
Average/Sum#:	0.9	1.1	0.0	1.1	13.6	544.4	0.00 #	24.00 #
Minimum:	0.1	0.2	0.0	0.2	12.2	383.0	0.00	1.00
Maximum:	1.5	1.7	0.0	1.8	14.4	655.9	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/25/2026 00:00	1.4	1.7	0.0	1.6	14.1	521.7	0.00	1.00
07/25/2026 01:00	1.4	1.6	0.0	1.6	14.1	520.8	0.00	1.00
07/25/2026 02:00	1.4	1.6	0.0	1.6	14.1	520.5	0.00	1.00
07/25/2026 03:00	1.4	1.6	0.0	1.6	14.1	520.4	0.00	1.00
07/25/2026 04:00	1.5	1.6	0.0	1.7	14.1	519.5	0.00	1.00
07/25/2026 05:00	1.7	1.7	0.0	1.9	14.2	518.2	0.00	1.00
07/25/2026 06:00	1.5	1.8	0.0	1.7	14.1	520.0	0.00	1.00
07/25/2026 07:00	1.4	1.7	0.0	1.6	14.0	523.6	0.00	1.00
07/25/2026 08:00	1.2	1.6	0.0	1.4	14.0	526.2	0.00	1.00
07/25/2026 09:00	0.9	1.4	0.0	1.1	13.9	529.7	0.00	1.00
07/25/2026 10:00	0.7	1.1	0.0	0.9	13.8	532.8	0.00	1.00
07/25/2026 11:00	0.6	0.9	0.0	0.7	13.5	538.0	0.00	1.00
07/25/2026 12:00	0.4	0.7	0.0	0.5	13.2	543.7	0.00	1.00
07/25/2026 13:00	0.2	0.5	0.0	0.3	13.0	546.3	0.00	1.00
07/25/2026 14:00	0.2	0.3	0.0	0.3	12.9	548.2	0.00	1.00
07/25/2026 15:00	0.1	0.2	0.0	0.2	12.8	549.3	0.00	1.00
07/25/2026 16:00	0.1	0.2	0.0	0.2	12.6	551.5	0.00	1.00
07/25/2026 17:00	0.1	0.2	0.0	0.2	12.7	551.4	0.00	1.00
07/25/2026 18:00	0.2	0.2	0.0	0.3	13.0	543.7	0.00	1.00
07/25/2026 19:00	0.5	0.4	0.0	0.6	13.4	535.3	0.00	1.00
07/25/2026 20:00	0.7	0.6	0.0	0.9	13.7	530.5	0.00	1.00
07/25/2026 21:00	0.8	0.8	0.0	1.0	13.8	528.0	0.00	1.00
07/25/2026 22:00	0.9	0.9	0.0	1.1	13.9	526.5	0.00	1.00
07/25/2026 23:00	0.9	1.0	0.0	1.1	13.9	524.9	0.00	1.00
Average/Sum#:	0.8	1.0	0.0	1.0	13.6	532.1	0.00 #	24.00 #
Minimum:	0.1	0.2	0.0	0.2	12.6	518.2	0.00	1.00
Maximum:	1.7	1.8	0.0	1.9	14.2	551.5	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/26/2026 00:00	1.0	1.1	0.0	1.2	14.0	524.3	0.00	1.00
07/26/2026 01:00	1.1	1.2	0.0	1.3	14.0	523.0	0.00	1.00
07/26/2026 02:00	1.2	1.3	0.0	1.4	14.1	521.0	0.00	1.00
07/26/2026 03:00	1.3	1.4	0.0	1.5	14.1	519.4	0.00	1.00
07/26/2026 04:00	1.4	1.5	0.0	1.6	14.1	519.9	0.00	1.00
07/26/2026 05:00	1.6	1.7	0.0	1.9	14.1	520.5	0.00	1.00
07/26/2026 06:00	1.5	1.8	0.0	1.8	14.1	521.8	0.00	1.00
07/26/2026 07:00	0.9	1.5	0.0	1.1	14.3	383.2	0.00	1.00
07/26/2026 08:00	0.9	1.2	0.0	1.1	14.2	469.9	0.00	1.00
07/26/2026 09:00	0.9	1.0	0.0	1.1	13.9	529.6	0.00	1.00
07/26/2026 10:00	0.7	1.0	0.0	0.9	13.8	532.2	0.00	1.00
07/26/2026 11:00	0.6	0.9	0.0	0.8	13.6	533.5	0.00	1.00
07/26/2026 12:00	0.4	0.7	0.0	0.5	13.3	540.7	0.00	1.00
07/26/2026 13:00	0.3	0.5	0.0	0.4	13.1	544.7	0.00	1.00
07/26/2026 14:00	0.2	0.4	0.0	0.3	12.9	547.1	0.00	1.00
07/26/2026 15:00	0.1	0.3	0.0	0.2	12.8	548.9	0.00	1.00
07/26/2026 16:00	0.1	0.2	0.0	0.2	12.8	549.1	0.00	1.00
07/26/2026 17:00	0.1	0.2	0.0	0.2	12.8	550.4	0.00	1.00
07/26/2026 18:00	0.3	0.3	0.0	0.4	13.2	542.1	0.00	1.00
07/26/2026 19:00	0.6	0.4	0.0	0.7	13.6	536.7	0.00	1.00
07/26/2026 20:00	0.7	0.6	0.0	0.8	13.7	538.0	0.00	1.00
07/26/2026 21:00	0.5	0.7	0.0	0.6	13.2	582.5	0.00	1.00
07/26/2026 22:00	0.5	0.7	0.0	0.7	13.3	579.4	0.00	1.00
07/26/2026 23:00	1.1	0.9	0.0	1.3	14.1	521.2	0.00	1.00
Average/Sum#:	0.8	0.9	0.0	0.9	13.6	528.3	0.00 #	24.00 #
Minimum:	0.1	0.2	0.0	0.2	12.8	383.2	0.00	1.00
Maximum:	1.6	1.8	0.0	1.9	14.3	582.5	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/27/2026 00:00	1.1	1.1	0.0	1.3	13.9	536.8	0.00	1.00
07/27/2026 01:00	1.4	1.4	0.0	1.6	14.1	518.4	0.00	1.00
07/27/2026 02:00	1.4	1.5	0.0	1.6	14.2	517.6	0.00	1.00
07/27/2026 03:00	1.4	1.6	0.0	1.6	14.2	517.7	0.00	1.00
07/27/2026 04:00	1.4	1.6	0.0	1.6	14.2	516.5	0.00	1.00
07/27/2026 05:00	1.5	1.7	0.0	1.7	14.2	516.3	0.00	1.00
07/27/2026 06:00	1.4	1.7	0.0	1.6	14.2	518.5	0.00	1.00
07/27/2026 07:00	1.4	1.6	0.0	1.6	14.1	520.7	0.00	1.00
07/27/2026 08:00	1.1	1.5	0.0	1.3	14.0	523.3	0.00	1.00
07/27/2026 09:00	1.0	1.4	0.0	1.2	14.0	525.3	0.00	1.00
07/27/2026 10:00	0.8	1.2	0.0	1.0	13.8	527.7	0.00	1.00
07/27/2026 11:00	0.7	1.0	0.0	0.9	13.7	531.6	0.00	1.00
07/27/2026 12:00	0.5	0.8	0.0	0.6	13.4	537.1	0.00	1.00
07/27/2026 13:00	0.3	0.6	0.0	0.4	13.2	542.0	0.00	1.00
07/27/2026 14:00	0.2	0.4	0.0	0.3	13.0	544.0	0.00	1.00
07/27/2026 15:00	0.2	0.3	0.0	0.3	12.9	544.9	0.00	1.00
07/27/2026 16:00	0.2	0.3	0.0	0.3	12.9	547.8	0.00	1.00
07/27/2026 17:00	0.2	0.3	0.0	0.3	13.0	552.3	0.00	1.00
07/27/2026 18:00	0.5	0.4	0.0	0.7	13.2	584.6	0.00	1.00
07/27/2026 19:00	0.4	0.5	0.0	0.5	13.1	592.5	0.00	1.00
07/27/2026 20:00	0.7	0.7	0.0	0.9	13.5	560.9	0.00	1.00
07/27/2026 21:00	1.0	0.9	0.0	1.2	13.9	527.2	0.00	1.00
07/27/2026 22:00	1.0	1.1	0.0	1.2	14.0	524.4	0.00	1.00
07/27/2026 23:00	1.1	1.2	0.0	1.3	14.0	523.1	0.00	1.00
Average/Sum#:	0.9	1.0	0.0	1.0	13.7	535.5	0.00 #	24.00 #
Minimum:	0.2	0.3	0.0	0.3	12.9	516.3	0.00	1.00
Maximum:	1.5	1.7	0.0	1.7	14.2	592.5	0.00	1.00
%SI	0.00	0.00	29.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/28/2026 00:00	1.2	1.3	0.0	1.4	14.1	522.7	0.00	1.00
07/28/2026 01:00	1.2	1.4	0.0	1.4	14.1	521.3	0.00	1.00
07/28/2026 02:00	1.3	1.5	0.0	1.5	14.1	520.9	0.00	1.00
07/28/2026 03:00	1.5	1.6	0.0	1.7	14.1	519.7	0.00	1.00
07/28/2026 04:00	1.5	1.7	0.0	1.7	14.1	520.0	0.00	1.00
07/28/2026 05:00	1.5	1.8	0.0	1.7	14.2	519.0	0.00	1.00
07/28/2026 06:00	1.5	1.7	0.0	1.7	14.2	520.3	0.00	1.00
07/28/2026 07:00	1.0	1.5	0.0	1.1	14.3	428.6	0.00	1.00
07/28/2026 08:00	0.9	1.2	0.0	1.0	14.3	377.1	0.00	1.00
07/28/2026 09:00	0.8	0.8	0.0	0.9	14.4	376.8	0.00	1.00
07/28/2026 10:00	0.8	0.7	0.0	0.9	14.4	376.0	0.00	1.00
07/28/2026 11:00	0.8	0.7	0.0	0.9	14.5	407.0	0.00	1.00
07/28/2026 12:00	0.7	0.8	0.0	0.9	13.8	508.8	0.00	1.00
07/28/2026 13:00	0.8	0.8	0.0	0.9	14.4	376.9	0.00	1.00
07/28/2026 14:00	0.8	0.8	0.0	0.9	14.5	374.9	0.00	1.00
07/28/2026 15:00	0.8	0.7	0.0	0.8	14.5	405.7	0.00	1.00
07/28/2026 16:00	0.8	0.8	0.0	1.0	13.8	532.3	0.00	1.00
07/28/2026 17:00	0.8	0.9	0.0	1.0	13.8	533.8	0.00	1.00
07/28/2026 18:00	0.4	0.8	0.0	0.6	13.2	542.9	0.00	1.00
07/28/2026 19:00	0.5	0.7	0.0	0.6	13.4	537.1	0.00	1.00
07/28/2026 20:00	0.7	0.6	0.0	0.8	13.7	532.2	0.00	1.00
07/28/2026 21:00	0.7	0.7	0.0	0.9	13.7	532.6	0.00	1.00
07/28/2026 22:00	0.8	0.9	0.0	1.0	13.8	528.5	0.00	1.00
07/28/2026 23:00	0.9	0.9	0.0	1.0	14.3	385.9	0.00	1.00
Average/Sum#:	0.9	1.1	0.0	1.1	14.1	475.0	0.00 #	24.00 #
Minimum:	0.4	0.6	0.0	0.6	13.2	374.9	0.00	1.00
Maximum:	1.5	1.8	0.0	1.7	14.5	542.9	0.00	1.00
%SI	0.00	0.00	12.50	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/29/2026 00:00	0.8	0.8	0.0	0.9	14.3	376.2	0.00	1.00
07/29/2026 01:00	0.8	0.7	0.0	0.9	14.3	376.2	0.00	1.00
07/29/2026 02:00	0.8	0.7	0.0	0.9	14.3	376.6	0.00	1.00
07/29/2026 03:00	0.8	0.7	0.0	0.9	14.3	376.7	0.00	1.00
07/29/2026 04:00	0.8	0.7	0.0	0.9	14.3	376.8	0.00	1.00
07/29/2026 05:00	0.9	0.7	0.0	1.0	14.3	376.6	0.00	1.00
07/29/2026 06:00	0.9	0.7	0.0	1.0	14.3	376.6	0.00	1.00
07/29/2026 07:00	0.8	0.7	0.0	0.9	14.3	376.5	0.00	1.00
07/29/2026 08:00	0.8	0.7	0.0	0.9	14.3	376.0	0.00	1.00
07/29/2026 09:00	0.8	0.7	0.0	0.9	14.4	375.8	0.00	1.00
07/29/2026 10:00	0.8	0.7	0.0	0.9	14.5	402.0	0.00	1.00
07/29/2026 11:00	0.6	0.7	0.0	0.7	13.4	539.6	0.00	1.00
07/29/2026 12:00	0.3	0.6	0.0	0.4	13.1	543.9	0.00	1.00
07/29/2026 13:00	0.2	0.4	0.0	0.3	12.8	550.3	0.00	1.00
07/29/2026 14:00	0.1	0.3	0.0	0.2	12.7	551.0	0.00	1.00
07/29/2026 15:00	0.1	0.2	0.0	0.2	12.5	553.0	0.00	1.00
07/29/2026 16:00	0.1	0.2	0.0	0.2	12.5	553.2	0.00	1.00
07/29/2026 17:00	0.1	0.2	0.0	0.2	12.5	558.6	0.00	1.00
07/29/2026 18:00	0.1	0.2	0.0	0.2	12.6	561.2	0.00	1.00
07/29/2026 19:00	0.3	0.2	0.0	0.4	13.0	547.6	0.00	1.00
07/29/2026 20:00	0.5	0.4	0.0	0.6	13.5	535.9	0.00	1.00
07/29/2026 21:00	0.8	0.5	0.0	0.9	14.4	385.6	0.00	1.00
07/29/2026 22:00	0.8	0.7	0.0	0.9	14.4	375.7	0.00	1.00
07/29/2026 23:00	0.8	0.7	0.0	0.9	14.4	375.9	0.00	1.00
Average/Sum#:	0.6	0.5	0.0	0.7	13.7	449.9	0.00 #	24.00 #
Minimum:	0.1	0.2	0.0	0.2	12.5	375.7	0.00	1.00
Maximum:	0.9	0.8	0.0	1.0	14.5	561.2	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/30/2026 00:00	0.8	0.7	0.0	0.9	14.3	376.5	0.00	1.00
07/30/2026 01:00	0.8	0.7	0.0	0.9	14.3	376.7	0.00	1.00
07/30/2026 02:00	0.8	0.7	0.0	0.9	14.3	376.8	0.00	1.00
07/30/2026 03:00	0.9	0.7	0.0	1.0	14.3	376.7	0.00	1.00
07/30/2026 04:00	0.9	0.7	0.0	1.0	14.3	376.8	0.00	1.00
07/30/2026 05:00	0.8	0.7	0.0	0.9	14.3	376.8	0.00	1.00
07/30/2026 06:00	0.8	0.7	0.0	0.9	14.3	376.5	0.00	1.00
07/30/2026 07:00	0.8	0.7	0.0	0.9	14.3	376.1	0.00	1.00
07/30/2026 08:00	0.8	0.7	0.0	0.9	14.4	375.5	0.00	1.00
07/30/2026 09:00	0.8	0.7	0.0	0.9	14.4	375.2	0.00	1.00
07/30/2026 10:00	0.8	0.7	0.0	0.9	14.4	374.6	0.00	1.00
07/30/2026 11:00	0.8	0.7	0.0	0.9	14.4	374.2	0.00	1.00
07/30/2026 12:00	0.8	0.7	0.0	0.9	14.5	374.0	0.00	1.00
07/30/2026 13:00	0.8	0.7	0.0	0.9	14.5	373.7	0.00	1.00
07/30/2026 14:00	0.7	0.7	0.0	0.8	14.5	421.5	0.00	1.00
07/30/2026 15:00	0.7	0.7	0.0	0.8	14.5	394.8	0.00	1.00
07/30/2026 16:00	0.7	0.7	0.0	0.8	14.5	389.3	0.00	1.00
07/30/2026 17:00	0.7	0.7	0.0	0.8	14.4	423.9	0.00	1.00
07/30/2026 18:00	0.7	0.7	0.0	0.8	14.5	458.2	0.00	1.00
07/30/2026 19:00	0.8	0.7	0.0	0.9	14.5	393.8	0.00	1.00
07/30/2026 20:00	0.8	0.7	0.0	0.9	14.4	374.4	0.00	1.00
07/30/2026 21:00	0.8	0.7	0.0	0.9	14.4	382.8	0.00	1.00
07/30/2026 22:00	0.8	0.7	0.0	0.9	14.4	394.3	0.00	1.00
07/30/2026 23:00	0.8	0.7	0.0	0.9	14.4	377.3	0.00	1.00
Average/Sum#:	0.8	0.7	0.0	0.9	14.4	386.3	0.00 #	24.00 #
Minimum:	0.7	0.7	0.0	0.8	14.3	373.7	0.00	1.00
Maximum:	0.9	0.7	0.0	1.0	14.5	458.2	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/31/2026 00:00	0.8	0.7	0.0	0.9	14.3	375.6	0.00	1.00
07/31/2026 01:00	0.9	0.7	0.0	1.0	14.3	376.0	0.00	1.00
07/31/2026 02:00	0.8	0.7	0.0	0.9	14.3	376.3	0.00	1.00
07/31/2026 03:00	0.9	0.7	0.0	1.0	14.3	376.7	0.00	1.00
07/31/2026 04:00	0.9	0.7	0.0	1.0	14.3	397.1	0.00	1.00
07/31/2026 05:00	0.9	0.8	0.0	1.0	14.3	377.4	0.00	1.00
07/31/2026 06:00	0.9	0.8	0.0	1.0	14.3	377.1	0.00	1.00
07/31/2026 07:00	0.9	0.8	0.0	1.0	14.3	377.1	0.00	1.00
07/31/2026 08:00	0.8	0.8	0.0	0.9	14.4	376.7	0.00	1.00
07/31/2026 09:00	0.8	0.7	0.0	0.9	14.4	376.1	0.00	1.00
07/31/2026 10:00	0.8	0.7	0.0	0.9	14.4	375.4	0.00	1.00
07/31/2026 11:00	0.8	0.7	0.0	0.9	14.5	389.7	0.00	1.00
07/31/2026 12:00	0.7	0.7	0.0	0.8	14.5	462.7	0.00	1.00
07/31/2026 13:00	0.7	0.8	0.0	0.8	14.5	461.5	0.00	1.00
07/31/2026 14:00	0.7	0.8	0.0	0.8	14.5	465.6	0.00	1.00
07/31/2026 15:00	0.7	0.8	0.0	0.9	13.5	554.5	0.00	1.00
07/31/2026 16:00	0.5	0.8	0.0	0.7	13.2	580.4	0.00	1.00
07/31/2026 17:00	0.3	0.7	0.0	0.4	12.8	614.4	0.00	1.00
07/31/2026 18:00	0.1	0.4	0.0	0.2	12.2	659.4	0.00	1.00
07/31/2026 19:00	0.8	0.5	0.0	1.0	13.6	544.7	0.00	1.00
07/31/2026 20:00	0.6	0.6	0.0	0.7	13.5	534.6	0.00	1.00
07/31/2026 21:00	0.6	0.8	0.0	0.8	13.6	533.6	0.00	1.00
07/31/2026 22:00	0.8	0.8	0.0	1.0	13.8	528.6	0.00	1.00
07/31/2026 23:00	0.9	0.8	0.0	1.0	14.3	385.9	0.00	1.00
Average/Sum#:	0.7	0.7	0.0	0.9	14.0	453.2	0.00 #	24.00 #
Minimum:	0.1	0.4	0.0	0.2	12.2	375.4	0.00	1.00
Maximum:	0.9	0.8	0.0	1.0	14.5	659.4	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/01/2026 00:00	0.8	0.8	0.0	0.9	14.3	376.9	0.00	1.00
08/01/2026 01:00	0.8	0.7	0.0	0.9	14.3	376.3	0.00	1.00
08/01/2026 02:00	0.8	0.7	0.0	0.9	14.3	376.6	0.00	1.00
08/01/2026 03:00	0.9	0.7	0.0	1.0	14.3	376.8	0.00	1.00
08/01/2026 04:00	0.9	0.7	0.0	1.0	14.3	377.2	0.00	1.00
08/01/2026 05:00	0.9	0.7	0.0	1.0	14.3	377.1	0.00	1.00
08/01/2026 06:00	0.9	0.7	0.0	1.0	14.3	377.4	0.00	1.00
08/01/2026 07:00	0.8	0.7	0.0	0.9	14.3	376.7	0.00	1.00
08/01/2026 08:00	0.8	0.7	0.0	0.9	14.3	376.2	0.00	1.00
08/01/2026 09:00	0.8	0.7	0.0	0.9	14.4	375.3	0.00	1.00
08/01/2026 10:00	0.8	0.7	0.0	0.9	14.4	375.2	0.00	1.00
08/01/2026 11:00	0.8	0.7	0.0	0.9	14.5	375.2	0.00	1.00
08/01/2026 12:00	0.8	0.7	0.0	0.9	14.5	374.3	0.00	1.00
08/01/2026 13:00	0.8	0.7	0.0	0.9	14.5	372.9	0.00	1.00
08/01/2026 14:00	0.8	0.7	0.0	0.9	14.5	400.1	0.00	1.00
08/01/2026 15:00	0.9	0.8	0.0	1.1	13.7	532.1	0.00	1.00
08/01/2026 16:00	0.6	0.8	0.0	0.7	13.4	539.0	0.00	1.00
08/01/2026 17:00	0.4	0.8	0.0	0.5	12.9	592.2	0.00	1.00
08/01/2026 18:00	0.2	0.5	0.0	0.3	12.1	654.3	0.00	1.00
08/01/2026 19:00	0.3	0.4	0.0	0.4	12.7	611.6	0.00	1.00
08/01/2026 20:00	1.0	0.6	0.0	1.2	13.8	525.9	0.00	1.00
08/01/2026 21:00	0.5	0.7	0.0	0.6	13.3	541.6	0.00	1.00
08/01/2026 22:00	0.6	0.8	0.0	0.7	13.4	538.7	0.00	1.00
08/01/2026 23:00	0.8	0.6	0.0	0.9	14.5	430.2	0.00	1.00
Average/Sum#:	0.7	0.7	0.0	0.8	14.0	442.9	0.00 #	24.00 #
Minimum:	0.2	0.4	0.0	0.3	12.1	372.9	0.00	1.00
Maximum:	1.0	0.8	0.0	1.2	14.5	654.3	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/02/2026 00:00	0.8	0.7	0.0	0.9	14.4	378.5	0.00	1.00
08/02/2026 01:00	0.9	0.8	0.0	1.0	14.4	374.8	0.00	1.00
08/02/2026 02:00	0.8	0.7	0.0	0.9	14.3	375.2	0.00	1.00
08/02/2026 03:00	0.9	0.8	0.0	1.0	14.3	375.6	0.00	1.00
08/02/2026 04:00	0.9	0.8	0.0	1.0	14.3	375.4	0.00	1.00
08/02/2026 05:00	1.0	0.8	0.0	1.1	14.3	375.8	0.00	1.00
08/02/2026 06:00	1.0	0.9	0.0	1.1	14.3	375.6	0.00	1.00
08/02/2026 07:00	0.9	0.8	0.0	1.0	14.4	374.7	0.00	1.00
08/02/2026 08:00	0.8	0.8	0.0	0.9	14.4	373.7	0.00	1.00
08/02/2026 09:00	0.8	0.7	0.0	0.9	14.5	373.1	0.00	1.00
08/02/2026 10:00	0.8	0.7	0.0	0.9	14.5	373.2	0.00	1.00
08/02/2026 11:00	0.8	0.7	0.0	0.9	14.5	372.3	0.00	1.00
08/02/2026 12:00	0.8	0.7	0.0	0.9	14.5	371.4	0.00	1.00
08/02/2026 13:00	0.7	0.7	0.0	0.8	14.5	400.0	0.00	1.00
08/02/2026 14:00	0.9	0.8	0.0	1.1	13.7	528.6	0.00	1.00
08/02/2026 15:00	0.9	0.9	0.0	1.1	13.7	528.1	0.00	1.00
08/02/2026 16:00	0.6	1.0	0.0	0.8	13.4	553.6	0.00	1.00
08/02/2026 17:00	0.7	0.9	0.0	0.9	13.6	536.6	0.00	1.00
08/02/2026 18:00	0.8	0.9	0.0	1.0	13.6	533.4	0.00	1.00
08/02/2026 19:00	0.1	0.7	0.0	0.2	12.7	550.6	0.00	1.00
08/02/2026 20:00	0.2	0.5	0.0	0.3	12.9	545.8	0.00	1.00
08/02/2026 21:00	0.3	0.3	0.0	0.4	13.1	543.3	0.00	1.00
08/02/2026 22:00	1.7	0.8	0.0	1.9	14.4	460.7	0.00	1.00
08/02/2026 23:00	1.4	1.2	0.0	1.6	14.4	440.6	0.00	1.00
Average/Sum#:	0.8	0.8	0.0	0.9	14.0	437.1	0.00 #	24.00 #
Minimum:	0.1	0.3	0.0	0.2	12.7	371.4	0.00	1.00
Maximum:	1.7	1.2	0.0	1.9	14.5	553.6	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/03/2026 00:00	0.9	1.4	0.0	1.0	14.4	374.5	0.00	1.00
08/03/2026 01:00	0.8	1.0	0.0	0.9	14.4	405.3	0.00	1.00
08/03/2026 02:00	0.9	0.8	0.0	1.0	14.3	373.9	0.00	1.00
08/03/2026 03:00	0.9	0.8	0.0	1.0	14.4	374.1	0.00	1.00
08/03/2026 04:00	0.8	0.8	0.0	0.9	14.5	430.7	0.00	1.00
08/03/2026 05:00	0.9	0.8	0.0	1.0	14.4	418.8	0.00	1.00
08/03/2026 06:00	1.0	0.8	0.0	1.1	14.3	375.0	0.00	1.00
08/03/2026 07:00	0.9	0.8	0.0	1.0	14.4	373.9	0.00	1.00
08/03/2026 08:00	0.9	0.8	0.0	1.0	14.4	373.2	0.00	1.00
08/03/2026 09:00	0.8	0.8	0.0	0.9	14.5	372.9	0.00	1.00
08/03/2026 10:00	0.8	0.7	0.0	0.9	14.5	372.8	0.00	1.00
08/03/2026 11:00	0.8	0.7	0.0	0.9	14.5	371.7	0.00	1.00
08/03/2026 12:00	0.8	0.7	0.0	0.9	14.5	405.3	0.00	1.00
08/03/2026 13:00	0.7	0.7	0.0	0.8	14.4	423.6	0.00	1.00
08/03/2026 14:00	0.7	0.8	0.0	0.9	13.5	543.2	0.00	1.00
08/03/2026 15:00	0.7	0.8	0.0	0.9	13.6	536.2	0.00	1.00
08/03/2026 16:00	0.4	0.8	0.0	0.6	13.0	582.0	0.00	1.00
08/03/2026 17:00	0.4	0.7	0.0	0.5	12.9	595.5	0.00	1.00
08/03/2026 18:00	0.2	0.5	0.0	0.3	11.9	665.8	0.00	1.00
08/03/2026 19:00	0.2	0.4	0.0	0.3	12.3	638.7	0.00	1.00
08/03/2026 20:00	0.3	0.4	0.0	0.5	12.7	614.2	0.00	1.00
08/03/2026 21:00	0.5	0.5	0.0	0.6	13.2	557.6	0.00	1.00
08/03/2026 22:00	1.1	0.7	0.0	1.3	14.4	431.7	0.00	1.00
08/03/2026 23:00	0.7	0.8	0.0	0.8	14.6	449.4	0.00	1.00
Average/Sum#:	0.7	0.8	0.0	0.8	13.9	460.8	0.00 #	24.00 #
Minimum:	0.2	0.4	0.0	0.3	11.9	371.7	0.00	1.00
Maximum:	1.1	1.4	0.0	1.3	14.6	665.8	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/04/2026 00:00	0.9	0.9	0.0	1.0	14.4	391.3	0.00	1.00
08/04/2026 01:00	0.9	0.8	0.0	1.0	14.4	374.5	0.00	1.00
08/04/2026 02:00	0.9	0.7	0.0	1.0	14.3	374.8	0.00	1.00
08/04/2026 03:00	0.8	0.7	0.0	0.9	14.4	394.6	0.00	1.00
08/04/2026 04:00	0.8	0.7	0.0	0.9	14.4	434.1	0.00	1.00
08/04/2026 05:00	0.8	0.8	0.0	0.9	14.4	418.5	0.00	1.00
08/04/2026 06:00	0.8	0.8	0.0	0.9	14.4	403.8	0.00	1.00
08/04/2026 07:00	0.9	0.8	0.0	1.0	14.3	374.6	0.00	1.00
08/04/2026 08:00	0.8	0.7	0.0	0.9	14.3	374.3	0.00	1.00
08/04/2026 09:00	0.8	0.7	0.0	0.9	14.3	374.2	0.00	1.00
08/04/2026 10:00	0.8	0.7	0.0	0.9	14.4	376.4	0.00	1.00
08/04/2026 11:00	0.8	0.7	0.0	0.9	14.5	395.3	0.00	1.00
08/04/2026 12:00	0.7	0.7	0.0	0.8	14.4	428.7	0.00	1.00
08/04/2026 13:00	0.7	0.7	0.0	0.8	14.5	453.3	0.00	1.00
08/04/2026 14:00	0.6	0.7	0.0	0.8	13.2	564.3	0.00	1.00
08/04/2026 15:00	0.4	0.7	0.0	0.6	13.1	576.9	0.00	1.00
08/04/2026 16:00	0.5	0.6	0.0	0.7	13.3	559.4	0.00	1.00
08/04/2026 17:00	0.5	0.6	0.0	0.6	13.2	542.0	0.00	1.00
08/04/2026 18:00	0.2	0.5	0.0	0.3	12.4	625.2	0.00	1.00
08/04/2026 19:00	0.9	0.7	0.0	1.1	13.8	525.7	0.00	1.00
08/04/2026 20:00	0.8	0.8	0.0	1.0	13.7	533.0	0.00	1.00
08/04/2026 21:00	0.6	0.9	0.0	0.8	13.6	535.2	0.00	1.00
08/04/2026 22:00	0.8	0.8	0.0	0.9	14.3	386.3	0.00	1.00
08/04/2026 23:00	0.7	0.7	0.0	0.8	14.5	447.8	0.00	1.00
Average/Sum#:	0.7	0.7	0.0	0.9	14.0	452.7	0.00 #	24.00 #
Minimum:	0.2	0.5	0.0	0.3	12.4	374.2	0.00	1.00
Maximum:	0.9	0.9	0.0	1.1	14.5	625.2	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/05/2026 00:00	0.8	0.7	0.0	0.9	14.4	422.2	0.00	1.00
08/05/2026 01:00	0.9	0.7	0.0	1.0	14.3	377.0	0.00	1.00
08/05/2026 02:00	0.9	0.7	0.0	1.0	14.3	377.3	0.00	1.00
08/05/2026 03:00	0.9	0.7	0.0	1.0	14.3	377.4	0.00	1.00
08/05/2026 04:00	0.8	0.7	0.0	0.9	14.3	383.4	0.00	1.00
08/05/2026 05:00	0.8	0.7	0.0	0.9	14.3	377.8	0.00	1.00
08/05/2026 06:00	0.8	0.7	0.0	0.9	14.3	392.9	0.00	1.00
08/05/2026 07:00	0.9	0.7	0.0	1.0	14.3	377.3	0.00	1.00
08/05/2026 08:00	0.8	0.7	0.0	0.9	14.3	377.1	0.00	1.00
08/05/2026 09:00	0.8	0.7	0.0	0.9	14.3	376.7	0.00	1.00
08/05/2026 10:00	0.8	0.7	0.0	0.9	14.4	376.1	0.00	1.00
08/05/2026 11:00	0.8	0.7	0.0	0.9	14.4	375.5	0.00	1.00
08/05/2026 12:00	0.8	0.7	0.0	0.9	14.5	391.9	0.00	1.00
08/05/2026 13:00	0.7	0.7	0.0	0.8	14.4	407.4	0.00	1.00
08/05/2026 14:00	1.1	0.9	0.0	1.4	13.9	523.4	0.00	1.00
08/05/2026 15:00	0.9	1.0	0.0	1.1	13.7	533.1	0.00	1.00
08/05/2026 16:00	0.6	1.0	0.0	0.7	13.2	578.0	0.00	1.00
08/05/2026 17:00	0.6	0.8	0.0	0.7	13.4	559.6	0.00	1.00
08/05/2026 18:00	0.9	0.8	0.0	1.1	13.8	530.2	0.00	1.00
08/05/2026 19:00	0.7	0.9	0.0	0.8	13.6	535.5	0.00	1.00
08/05/2026 20:00	0.6	0.8	0.0	0.7	13.5	538.6	0.00	1.00
08/05/2026 21:00	0.7	0.8	0.0	0.9	13.7	531.0	0.00	1.00
08/05/2026 22:00	0.8	0.8	0.0	0.9	14.5	457.8	0.00	1.00
08/05/2026 23:00	0.7	0.8	0.0	0.8	14.5	441.4	0.00	1.00
Average/Sum#:	0.8	0.8	0.0	0.9	14.1	442.4	0.00 #	24.00 #
Minimum:	0.6	0.7	0.0	0.7	13.2	375.5	0.00	1.00
Maximum:	1.1	1.0	0.0	1.4	14.5	578.0	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/06/2026 00:00	0.8	0.8	0.0	0.9	14.4	390.1	0.00	1.00
08/06/2026 01:00	0.8	0.7	0.0	0.9	14.4	375.6	0.00	1.00
08/06/2026 02:00	0.8	0.7	0.0	0.9	14.3	375.7	0.00	1.00
08/06/2026 03:00	0.9	0.7	0.0	1.0	14.3	375.9	0.00	1.00
08/06/2026 04:00	0.8	0.7	0.0	0.9	14.3	380.4	0.00	1.00
08/06/2026 05:00	0.8	0.7	0.0	0.9	14.3	398.5	0.00	1.00
08/06/2026 06:00	0.9	0.7	0.0	1.0	14.3	376.7	0.00	1.00
08/06/2026 07:00	0.9	0.7	0.0	1.0	14.3	376.2	0.00	1.00
08/06/2026 08:00	0.8	0.7	0.0	0.9	14.3	375.9	0.00	1.00
08/06/2026 09:00	0.8	0.7	0.0	0.9	14.4	375.4	0.00	1.00
08/06/2026 10:00	0.8	0.7	0.0	0.9	14.4	374.8	0.00	1.00
08/06/2026 11:00	0.8	0.7	0.0	0.9	14.4	374.0	0.00	1.00
08/06/2026 12:00	0.8	0.7	0.0	0.9	14.5	373.6	0.00	1.00
08/06/2026 13:00	0.8	0.7	0.0	0.9	14.5	393.1	0.00	1.00
08/06/2026 14:00	0.3	0.6	0.0	0.4	12.8	539.9	0.00	1.00
08/06/2026 15:00	0.1	0.4	0.0	0.2	12.5	552.8	0.00	1.00
08/06/2026 16:00	0.1	0.2	0.0	0.2	12.4	572.3	0.00	1.00
08/06/2026 17:00	0.1	0.2	0.0	0.2	12.3	644.5	0.00	1.00
08/06/2026 18:00	0.3	0.3	0.0	0.4	12.7	621.4	0.00	1.00
08/06/2026 19:00	0.9	0.6	0.0	1.1	13.8	534.2	0.00	1.00
08/06/2026 20:00	0.5	0.7	0.0	0.6	13.4	544.3	0.00	1.00
08/06/2026 21:00	0.4	0.8	0.0	0.6	13.2	566.3	0.00	1.00
08/06/2026 22:00	0.7	0.7	0.0	0.8	14.6	458.0	0.00	1.00
08/06/2026 23:00	0.7	0.7	0.0	0.8	14.5	456.7	0.00	1.00
Average/Sum#:	0.7	0.6	0.0	0.8	13.9	450.3	0.00 #	24.00 #
Minimum:	0.1	0.2	0.0	0.2	12.3	373.6	0.00	1.00
Maximum:	0.9	0.8	0.0	1.1	14.6	644.5	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/07/2026 00:00	0.7	0.8	0.0	0.8	14.5	456.1	0.00	1.00
08/07/2026 01:00	0.7	0.8	0.0	0.8	14.5	456.9	0.00	1.00
08/07/2026 02:00	0.7	0.8	0.0	0.8	14.5	457.0	0.00	1.00
08/07/2026 03:00	0.8	0.8	0.0	0.9	14.3	401.0	0.00	1.00
08/07/2026 04:00	0.7	0.8	0.0	0.8	14.5	453.6	0.00	1.00
08/07/2026 05:00	0.7	0.8	0.0	0.8	14.5	456.6	0.00	1.00
08/07/2026 06:00	0.8	0.8	0.0	0.9	14.3	398.2	0.00	1.00
08/07/2026 07:00	0.9	0.8	0.0	1.0	14.3	376.8	0.00	1.00
08/07/2026 08:00	0.8	0.7	0.0	0.9	14.4	376.1	0.00	1.00
08/07/2026 09:00	0.8	0.7	0.0	0.9	14.4	375.6	0.00	1.00
08/07/2026 10:00	0.8	0.7	0.0	0.9	14.4	374.9	0.00	1.00
08/07/2026 11:00	0.7	0.7	0.0	0.8	14.5	405.0	0.00	1.00
08/07/2026 12:00	0.8	0.7	0.0	0.9	14.5	387.1	0.00	1.00
08/07/2026 13:00	0.7	0.7	0.0	0.8	14.5	437.6	0.00	1.00
08/07/2026 14:00	0.6	0.7	0.0	0.8	13.2	546.4	0.00	1.00
08/07/2026 15:00	0.1	0.5	0.0	0.2	12.3	559.7	0.00	1.00
08/07/2026 16:00	0.1	0.3	0.0	0.2	12.4	562.9	0.00	1.00
08/07/2026 17:00	0.5	0.3	0.0	0.6	13.2	574.9	0.00	1.00
08/07/2026 18:00	0.2	0.3	0.0	0.3	12.5	633.0	0.00	1.00
08/07/2026 19:00	0.6	0.6	0.0	0.8	13.4	560.6	0.00	1.00
08/07/2026 20:00	0.9	0.7	0.0	1.0	13.7	543.7	0.00	1.00
08/07/2026 21:00	0.6	0.8	0.0	0.7	13.5	545.2	0.00	1.00
08/07/2026 22:00	0.8	0.8	0.0	0.9	14.5	460.8	0.00	1.00
08/07/2026 23:00	0.7	0.8	0.0	0.8	14.6	469.9	0.00	1.00
Average/Sum#:	0.7	0.7	0.0	0.8	14.0	469.6	0.00 #	24.00 #
Minimum:	0.1	0.3	0.0	0.2	12.3	374.9	0.00	1.00
Maximum:	0.9	0.8	0.0	1.0	14.6	633.0	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/08/2026 00:00	0.7	0.8	0.0	0.8	14.6	469.9	0.00	1.00
08/08/2026 01:00	0.8	0.8	0.0	0.9	14.4	411.0	0.00	1.00
08/08/2026 02:00	0.8	0.7	0.0	0.9	14.3	378.4	0.00	1.00
08/08/2026 03:00	0.8	0.7	0.0	0.9	14.3	379.6	0.00	1.00
08/08/2026 04:00	0.7	0.7	0.0	0.8	14.5	453.2	0.00	1.00
08/08/2026 05:00	0.8	0.7	0.0	0.9	14.4	427.4	0.00	1.00
08/08/2026 06:00	0.8	0.7	0.0	0.9	14.3	379.1	0.00	1.00
08/08/2026 07:00	0.8	0.7	0.0	0.9	14.3	378.6	0.00	1.00
08/08/2026 08:00	0.8	0.7	0.0	0.9	14.3	379.5	0.00	1.00
08/08/2026 09:00	0.8	0.7	0.0	0.9	14.4	379.9	0.00	1.00
08/08/2026 10:00	0.8	0.7	0.0	0.9	14.4	379.0	0.00	1.00
08/08/2026 11:00	0.8	0.7	0.0	0.9	14.4	377.9	0.00	1.00
08/08/2026 12:00	0.8	0.7	0.0	0.9	14.5	376.8	0.00	1.00
08/08/2026 13:00	0.8	0.7	0.0	0.9	14.3	398.6	0.00	1.00
08/08/2026 14:00	0.1	0.5	0.0	0.2	12.4	563.1	0.00	1.00
08/08/2026 15:00	0.3	0.4	0.0	0.3	12.7	553.2	0.00	1.00
08/08/2026 16:00	0.6	0.4	0.0	0.8	13.6	540.2	0.00	1.00
08/08/2026 17:00	0.6	0.6	0.0	0.7	13.5	548.6	0.00	1.00
08/08/2026 18:00	0.7	0.8	0.0	0.8	13.6	540.5	0.00	1.00
08/08/2026 19:00	0.5	0.7	0.0	0.7	13.4	538.1	0.00	1.00
08/08/2026 20:00	0.6	0.7	0.0	0.7	13.5	536.1	0.00	1.00
08/08/2026 21:00	0.6	0.6	0.0	0.8	13.6	535.3	0.00	1.00
08/08/2026 22:00	0.8	0.7	0.0	0.9	14.6	460.1	0.00	1.00
08/08/2026 23:00	0.7	0.7	0.0	0.8	14.5	430.3	0.00	1.00
Average/Sum#:	0.7	0.7	0.0	0.8	14.0	450.6	0.00 #	24.00 #
Minimum:	0.1	0.4	0.0	0.2	12.4	376.8	0.00	1.00
Maximum:	0.8	0.8	0.0	0.9	14.6	563.1	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/09/2026 00:00	0.8	0.7	0.0	0.9	14.4	376.9	0.00	1.00
08/09/2026 01:00	0.8	0.7	0.0	0.9	14.3	377.3	0.00	1.00
08/09/2026 02:00	0.8	0.7	0.0	0.9	14.3	377.6	0.00	1.00
08/09/2026 03:00	0.9	0.7	0.0	1.0	14.3	377.9	0.00	1.00
08/09/2026 04:00	0.8	0.7	0.0	0.9	14.3	381.6	0.00	1.00
08/09/2026 05:00	0.8	0.8	0.0	0.9	14.4	425.4	0.00	1.00
08/09/2026 06:00	0.8	0.7	0.0	0.9	14.3	377.9	0.00	1.00
08/09/2026 07:00	0.8	0.7	0.0	0.9	14.3	377.6	0.00	1.00
08/09/2026 08:00	0.8	0.7	0.0	0.9	14.4	376.8	0.00	1.00
08/09/2026 09:00	0.8	0.7	0.0	0.9	14.4	376.1	0.00	1.00
08/09/2026 10:00	0.8	0.7	0.0	0.9	14.5	375.8	0.00	1.00
08/09/2026 11:00	0.8	0.7	0.0	0.9	14.5	375.0	0.00	1.00
08/09/2026 12:00	0.7	0.7	0.0	0.8	14.5	384.1	0.00	1.00
08/09/2026 13:00	0.7	0.7	0.0	0.8	14.5	445.9	0.00	1.00
08/09/2026 14:00	0.6	0.7	0.0	0.7	13.3	543.3	0.00	1.00
08/09/2026 15:00	0.1	0.5	0.0	0.2	12.4	633.0	0.00	1.00
08/09/2026 16:00	0.1	0.4	0.0	0.3	12.2	642.4	0.00	1.00
08/09/2026 17:00	0.2	0.2	0.0	0.3	12.5	622.2	0.00	1.00
08/09/2026 18:00	0.2	0.3	0.0	0.3	12.3	638.9	0.00	1.00
08/09/2026 19:00	0.7	0.5	0.0	0.9	13.6	537.2	0.00	1.00
08/09/2026 20:00	0.4	0.5	0.0	0.5	13.2	545.3	0.00	1.00
08/09/2026 21:00	0.6	0.7	0.0	0.7	13.5	536.0	0.00	1.00
08/09/2026 22:00	0.8	0.6	0.0	0.9	14.4	389.8	0.00	1.00
08/09/2026 23:00	0.8	0.7	0.0	0.9	14.4	375.8	0.00	1.00
Average/Sum#:	0.7	0.6	0.0	0.8	13.9	452.9	0.00 #	24.00 #
Minimum:	0.1	0.2	0.0	0.2	12.2	375.0	0.00	1.00
Maximum:	0.9	0.8	0.0	1.0	14.5	642.4	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/10/2026 00:00	0.8	0.7	0.0	0.9	14.3	376.6	0.00	1.00
08/10/2026 01:00	0.8	0.7	0.0	0.9	14.3	376.9	0.00	1.00
08/10/2026 02:00	0.8	0.7	0.0	0.9	14.3	377.0	0.00	1.00
08/10/2026 03:00	0.8	0.7	0.0	0.9	14.3	377.2	0.00	1.00
08/10/2026 04:00	0.7	0.7	0.0	0.8	14.4	418.7	0.00	1.00
08/10/2026 05:00	0.8	0.7	0.0	0.9	14.3	377.9	0.00	1.00
08/10/2026 06:00	0.8	0.7	0.0	0.9	14.4	413.5	0.00	1.00
08/10/2026 07:00	0.8	0.7	0.0	0.9	14.3	377.4	0.00	1.00
08/10/2026 08:00	0.8	0.7	0.0	0.9	14.4	376.7	0.00	1.00
08/10/2026 09:00	0.8	0.7	0.0	0.9	14.4	376.3	0.00	1.00
08/10/2026 10:00	0.8	0.7	0.0	0.9	14.4	376.2	0.00	1.00
08/10/2026 11:00	0.8	0.7	0.0	0.9	14.5	375.6	0.00	1.00
08/10/2026 12:00	0.8	0.7	0.0	0.9	14.5	395.0	0.00	1.00
08/10/2026 13:00	0.7	0.7	0.0	0.8	14.4	430.8	0.00	1.00
08/10/2026 14:00	0.7	0.7	0.0	0.8	14.4	420.1	0.00	1.00
08/10/2026 15:00	0.8	0.8	0.0	1.0	13.7	540.6	0.00	1.00
08/10/2026 16:00	0.4	0.7	0.0	0.5	12.8	609.4	0.00	1.00
08/10/2026 17:00	0.2	0.6	0.0	0.3	12.5	638.7	0.00	1.00
08/10/2026 18:00	0.2	0.4	0.0	0.3	12.7	620.0	0.00	1.00
08/10/2026 19:00	0.5	0.4	0.0	0.7	13.3	572.6	0.00	1.00
08/10/2026 20:00	0.9	0.7	0.0	1.1	13.8	541.7	0.00	1.00
08/10/2026 21:00	0.7	0.9	0.0	0.9	13.5	567.9	0.00	1.00
08/10/2026 22:00	0.8	0.9	0.0	0.9	14.5	460.1	0.00	1.00
08/10/2026 23:00	0.8	0.8	0.0	0.9	14.4	399.8	0.00	1.00
Average/Sum#:	0.7	0.7	0.0	0.8	14.0	449.9	0.00 #	24.00 #
Minimum:	0.2	0.4	0.0	0.3	12.5	375.6	0.00	1.00
Maximum:	0.9	0.9	0.0	1.1	14.5	638.7	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/11/2026 00:00	0.8	0.7	0.0	0.9	14.4	406.6	0.00	1.00
08/11/2026 01:00	0.8	0.7	0.0	0.9	14.3	378.2	0.00	1.00
08/11/2026 02:00	0.8	0.7	0.0	0.9	14.3	378.2	0.00	1.00
08/11/2026 03:00	0.8	0.7	0.0	0.9	14.3	378.7	0.00	1.00
08/11/2026 04:00	0.8	0.7	0.0	0.9	14.3	382.8	0.00	1.00
08/11/2026 05:00	0.8	0.7	0.0	0.9	14.3	406.9	0.00	1.00
08/11/2026 06:00	0.8	0.7	0.0	0.9	14.4	422.7	0.00	1.00
08/11/2026 07:00	0.8	0.7	0.0	0.9	14.3	378.6	0.00	1.00
08/11/2026 08:00	0.8	0.7	0.0	0.9	14.4	378.1	0.00	1.00
08/11/2026 09:00	0.8	0.7	0.0	0.9	14.4	377.9	0.00	1.00
08/11/2026 10:00	0.8	0.7	0.0	0.9	14.4	388.2	0.00	1.00
08/11/2026 11:00	0.7	0.7	0.0	0.8	14.6	452.9	0.00	1.00
08/11/2026 12:00	0.6	0.7	0.0	0.7	14.5	473.0	0.00	1.00
08/11/2026 13:00	0.7	0.8	0.0	0.9	13.5	564.9	0.00	1.00
08/11/2026 14:00	0.7	0.8	0.0	0.9	13.7	550.4	0.00	1.00
08/11/2026 15:00	0.8	0.9	0.0	1.0	13.7	546.1	0.00	1.00
08/11/2026 16:00	0.3	0.8	0.0	0.4	12.8	617.4	0.00	1.00
08/11/2026 17:00	0.1	0.5	0.0	0.2	12.3	657.5	0.00	1.00
08/11/2026 18:00	0.2	0.3	0.0	0.3	12.8	620.0	0.00	1.00
08/11/2026 19:00	0.3	0.3	0.0	0.4	12.8	617.3	0.00	1.00
08/11/2026 20:00	0.6	0.5	0.0	0.7	13.3	583.5	0.00	1.00
08/11/2026 21:00	0.7	0.6	0.0	0.8	14.5	460.3	0.00	1.00
08/11/2026 22:00	0.7	0.7	0.0	0.8	14.5	430.2	0.00	1.00
08/11/2026 23:00	0.8	0.7	0.0	0.9	14.4	386.0	0.00	1.00
Average/Sum#:	0.7	0.7	0.0	0.8	14.0	468.2	0.00 #	24.00 #
Minimum:	0.1	0.3	0.0	0.2	12.3	377.9	0.00	1.00
Maximum:	0.8	0.9	0.0	1.0	14.6	657.5	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/12/2026 00:00	0.8	0.7	0.0	0.9	14.3	377.5	0.00	1.00
08/12/2026 01:00	0.8	0.7	0.0	0.9	14.3	377.8	0.00	1.00
08/12/2026 02:00	0.8	0.7	0.0	0.9	14.3	377.9	0.00	1.00
08/12/2026 03:00	0.8	0.7	0.0	0.9	14.3	378.2	0.00	1.00
08/12/2026 04:00	0.8	0.7	0.0	0.9	14.4	415.3	0.00	1.00
08/12/2026 05:00	0.7	0.7	0.0	0.8	14.4	449.3	0.00	1.00
08/12/2026 06:00	0.8	0.7	0.0	0.9	14.3	377.7	0.00	1.00
08/12/2026 07:00	0.8	0.7	0.0	0.9	14.3	378.1	0.00	1.00
08/12/2026 08:00	0.8	0.7	0.0	0.9	14.3	377.6	0.00	1.00
08/12/2026 09:00	0.8	0.7	0.0	0.9	14.3	377.1	0.00	1.00
08/12/2026 10:00	0.8	0.7	0.0	0.9	14.4	376.5	0.00	1.00
08/12/2026 11:00	0.8	0.7	0.0	0.9	14.4	376.1	0.00	1.00
08/12/2026 12:00	0.8	0.7	0.0	0.9	14.4	379.4	0.00	1.00
08/12/2026 13:00	1.0	0.9	0.0	1.2	13.9	527.2	0.00	1.00
08/12/2026 14:00	0.9	1.0	0.0	1.1	13.9	526.9	0.00	1.00
08/12/2026 15:00	1.0	1.2	0.0	1.2	13.9	526.2	0.00	1.00
08/12/2026 16:00	0.9	1.1	0.0	1.1	13.9	526.2	0.00	1.00
08/12/2026 17:00	1.0	1.2	0.0	1.2	14.0	525.0	0.00	1.00
08/12/2026 18:00	1.0	1.2	0.0	1.2	14.0	524.0	0.00	1.00
08/12/2026 19:00	1.1	1.2	0.0	1.3	14.1	521.7	0.00	1.00
08/12/2026 20:00	1.1	1.3	0.0	1.3	14.0	522.7	0.00	1.00
08/12/2026 21:00	0.9	1.1	0.0	1.0	14.4	394.4	0.00	1.00
08/12/2026 22:00	0.8	0.9	0.0	0.9	14.3	376.7	0.00	1.00
08/12/2026 23:00	0.8	0.7	0.0	0.9	14.3	376.9	0.00	1.00
Average/Sum#:	0.9	0.9	0.0	1.0	14.2	431.9	0.00 #	24.00 #
Minimum:	0.7	0.7	0.0	0.8	13.9	376.1	0.00	1.00
Maximum:	1.1	1.3	0.0	1.3	14.4	527.2	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/13/2026 00:00	0.8	0.7	0.0	0.9	14.3	377.1	0.00	1.00
08/13/2026 01:00	0.8	0.7	0.0	0.9	14.3	377.5	0.00	1.00
08/13/2026 02:00	0.8	0.7	0.0	0.9	14.3	378.1	0.00	1.00
08/13/2026 03:00	0.8	0.7	0.0	0.9	14.3	378.6	0.00	1.00
08/13/2026 04:00	0.8	0.7	0.0	0.9	14.3	378.8	0.00	1.00
08/13/2026 05:00	0.8	0.7	0.0	0.9	14.2	379.3	0.00	1.00
08/13/2026 06:00	0.8	0.7	0.0	0.9	14.3	379.2	0.00	1.00
08/13/2026 07:00	0.8	0.7	0.0	0.9	14.3	378.8	0.00	1.00
08/13/2026 08:00	0.9	0.7	0.0	1.0	14.3	378.7	0.00	1.00
08/13/2026 09:00	0.8	0.7	0.0	0.9	14.3	378.3	0.00	1.00
08/13/2026 10:00	0.8	0.7	0.0	0.9	14.3	377.6	0.00	1.00
08/13/2026 11:00	0.8	0.7	0.0	0.9	14.3	377.0	0.00	1.00
08/13/2026 12:00	0.8	0.7	0.0	0.9	14.4	404.6	0.00	1.00
08/13/2026 13:00	0.9	0.8	0.0	1.1	13.9	526.6	0.00	1.00
08/13/2026 14:00	0.8	0.9	0.0	1.0	13.8	528.1	0.00	1.00
08/13/2026 15:00	0.8	1.0	0.0	1.0	13.8	527.3	0.00	1.00
08/13/2026 16:00	0.9	1.0	0.0	1.1	13.9	525.3	0.00	1.00
08/13/2026 17:00	1.0	1.1	0.0	1.2	13.9	523.7	0.00	1.00
08/13/2026 18:00	1.0	1.2	0.0	1.2	14.0	521.5	0.00	1.00
08/13/2026 19:00	0.9	1.1	0.0	1.0	14.3	382.2	0.00	1.00
08/13/2026 20:00	0.9	0.9	0.0	1.0	14.3	378.1	0.00	1.00
08/13/2026 21:00	0.9	0.8	0.0	1.0	14.3	378.3	0.00	1.00
08/13/2026 22:00	0.9	0.8	0.0	1.0	14.3	378.5	0.00	1.00
08/13/2026 23:00	0.9	0.8	0.0	1.0	14.3	378.5	0.00	1.00
Average/Sum#:	0.9	0.8	0.0	1.0	14.2	416.3	0.00 #	24.00 #
Minimum:	0.8	0.7	0.0	0.9	13.8	377.0	0.00	1.00
Maximum:	1.0	1.2	0.0	1.2	14.4	528.1	0.00	1.00
%SI	0.00	0.00	12.50	0.00	0.00	0.00	0.00	0.00