DOCKETED	
Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	273240
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q3 2026 - Part 10s
Description:	N/A
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public Agency
Submission Date:	10/28/2026 7:52:54 AM
Docketed Date:	10/28/2026

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/14/2026 00:00	0.9	0.8	0.0	1.0	14.2	378.9	0.00	1.00
08/14/2026 01:00	0.9	0.8	0.0	1.0	14.2	379.2	0.00	1.00
08/14/2026 02:00	0.9	0.8	0.0	1.0	14.2	379.2	0.00	1.00
08/14/2026 03:00	0.9	0.8	0.0	1.0	14.2	379.1	0.00	1.00
08/14/2026 04:00	0.9	0.8	0.0	1.0	14.2	379.2	0.00	1.00
08/14/2026 05:00	0.9	0.8	0.0	1.0	14.2	382.6	0.00	1.00
08/14/2026 06:00	0.9	0.8	0.0	1.0	14.3	394.6	0.00	1.00
08/14/2026 07:00	0.9	0.8	0.0	1.0	14.3	379.0	0.00	1.00
08/14/2026 08:00	0.9	0.7	0.0	1.0	14.3	379.1	0.00	1.00
08/14/2026 09:00	0.9	0.7	0.0	1.0	14.3	378.7	0.00	1.00
08/14/2026 10:00	0.9	0.7	0.0	1.0	14.3	378.4	0.00	1.00
08/14/2026 11:00	0.8	0.7	0.0	0.9	14.3	378.3	0.00	1.00
08/14/2026 12:00	0.8	0.7	0.0	0.9	14.3	377.9	0.00	1.00
08/14/2026 13:00	0.8	0.7	0.0	0.9	14.4	377.6	0.00	1.00
08/14/2026 14:00	0.8	0.7	0.0	0.9	14.4	377.3	0.00	1.00
08/14/2026 15:00	0.8	0.7	0.0	0.9	14.4	377.3	0.00	1.00
08/14/2026 16:00	0.8	0.7	0.0	0.9	14.4	377.2	0.00	1.00
08/14/2026 17:00	0.8	0.7	0.0	0.9	14.4	396.0	0.00	1.00
08/14/2026 18:00	0.8	0.7	0.0	0.9	14.4	379.8	0.00	1.00
08/14/2026 19:00	0.8	0.7	0.0	0.9	14.3	378.4	0.00	1.00
08/14/2026 20:00	0.9	0.7	0.0	1.0	14.3	379.3	0.00	1.00
08/14/2026 21:00	0.9	0.7	0.0	1.0	14.3	379.7	0.00	1.00
08/14/2026 22:00	0.9	0.7	0.0	1.0	14.3	380.2	0.00	1.00
08/14/2026 23:00	0.9	0.8	0.0	1.0	14.2	380.4	0.00	1.00
Average/Sum#:	0.9	0.7	0.0	1.0	14.3	380.3	0.00 #	24.00 #
Minimum:	0.8	0.7	0.0	0.9	14.2	377.2	0.00	1.00
Maximum:	0.9	0.8	0.0	1.0	14.4	396.0	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/15/2026 00:00	0.9	0.8	0.0	1.0	14.2	380.6	0.00	1.00
08/15/2026 01:00	0.9	0.8	0.0	1.0	14.2	380.8	0.00	1.00
08/15/2026 02:00	0.9	0.8	0.0	1.0	14.2	380.9	0.00	1.00
08/15/2026 03:00	0.9	0.8	0.0	1.0	14.2	379.8	0.00	1.00
08/15/2026 04:00	0.9	0.8	0.0	1.0	14.2	378.9	0.00	1.00
08/15/2026 05:00	0.9	0.8	0.0	1.0	14.2	378.4	0.00	1.00
08/15/2026 06:00	0.9	0.7	0.0	1.0	14.2	378.2	0.00	1.00
08/15/2026 07:00	0.9	0.7	0.0	1.0	14.2	377.9	0.00	1.00
08/15/2026 08:00	0.9	0.8	0.0	1.0	14.3	377.6	0.00	1.00
08/15/2026 09:00	0.8	0.8	0.0	0.9	14.3	377.9	0.00	1.00
08/15/2026 10:00	0.8	0.7	0.0	0.9	14.3	377.9	0.00	1.00
08/15/2026 11:00	0.8	0.7	0.0	0.9	14.4	377.4	0.00	1.00
08/15/2026 12:00	0.8	0.7	0.0	0.9	14.4	377.4	0.00	1.00
08/15/2026 13:00	0.8	0.7	0.0	0.9	14.4	377.0	0.00	1.00
08/15/2026 14:00	0.8	0.7	0.0	0.9	14.4	377.0	0.00	1.00
08/15/2026 15:00	0.8	0.7	0.0	0.9	14.4	376.9	0.00	1.00
08/15/2026 16:00	0.8	0.7	0.0	0.9	14.5	397.3	0.00	1.00
08/15/2026 17:00	0.8	0.7	0.0	0.9	14.5	414.7	0.00	1.00
08/15/2026 18:00	0.8	0.7	0.0	0.9	14.4	386.8	0.00	1.00
08/15/2026 19:00	0.8	0.7	0.0	0.9	14.4	400.8	0.00	1.00
08/15/2026 20:00	0.8	0.7	0.0	0.9	14.3	379.0	0.00	1.00
08/15/2026 21:00	0.7	0.7	0.0	0.8	14.5	460.7	0.00	1.00
08/15/2026 22:00	0.8	0.8	0.0	0.9	14.5	451.2	0.00	1.00
08/15/2026 23:00	0.8	0.8	0.0	0.9	14.5	461.7	0.00	1.00
Average/Sum#:	0.8	0.7	0.0	0.9	14.3	392.0	0.00 #	24.00 #
Minimum:	0.7	0.7	0.0	0.8	14.2	376.9	0.00	1.00
Maximum:	0.9	0.8	0.0	1.0	14.5	461.7	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/16/2026 00:00	0.8	0.8	0.0	0.9	14.4	458.4	0.00	1.00
08/16/2026 01:00	0.9	0.8	0.0	1.0	14.3	377.9	0.00	1.00
08/16/2026 02:00	0.9	0.8	0.0	1.0	14.3	378.1	0.00	1.00
08/16/2026 03:00	0.9	0.8	0.0	1.0	14.3	378.5	0.00	1.00
08/16/2026 04:00	0.9	0.8	0.0	1.0	14.2	378.9	0.00	1.00
08/16/2026 05:00	0.9	0.8	0.0	1.0	14.2	379.2	0.00	1.00
08/16/2026 06:00	0.9	0.8	0.0	1.0	14.2	379.3	0.00	1.00
08/16/2026 07:00	0.9	0.8	0.0	1.0	14.3	379.1	0.00	1.00
08/16/2026 08:00	0.9	0.8	0.0	1.0	14.3	378.3	0.00	1.00
08/16/2026 09:00	0.9	0.8	0.0	1.0	14.3	378.0	0.00	1.00
08/16/2026 10:00	0.9	0.8	0.0	1.0	14.4	377.2	0.00	1.00
08/16/2026 11:00	0.9	0.8	0.0	1.0	14.4	376.4	0.00	1.00
08/16/2026 12:00	0.8	0.8	0.0	0.9	14.4	403.0	0.00	1.00
08/16/2026 13:00	1.1	1.0	0.0	1.3	13.9	524.8	0.00	1.00
08/16/2026 14:00	1.0	1.1	0.0	1.2	13.9	525.2	0.00	1.00
08/16/2026 15:00	1.0	1.2	0.0	1.2	13.9	525.1	0.00	1.00
08/16/2026 16:00	0.9	1.2	0.0	1.1	13.8	533.0	0.00	1.00
08/16/2026 17:00	0.8	1.1	0.0	1.0	13.6	552.9	0.00	1.00
08/16/2026 18:00	0.9	1.0	0.0	1.1	13.8	531.3	0.00	1.00
08/16/2026 19:00	1.1	1.1	0.0	1.3	13.9	523.2	0.00	1.00
08/16/2026 20:00	0.9	1.1	0.0	1.1	13.8	527.5	0.00	1.00
08/16/2026 21:00	0.8	1.1	0.0	0.9	14.6	459.7	0.00	1.00
08/16/2026 22:00	0.7	0.9	0.0	0.8	14.6	447.1	0.00	1.00
08/16/2026 23:00	0.9	0.8	0.0	1.0	14.4	375.1	0.00	1.00
Average/Sum#:	0.9	0.9	0.0	1.0	14.2	439.5	0.00 #	24.00 #
Minimum:	0.7	0.8	0.0	0.8	13.6	375.1	0.00	1.00
Maximum:	1.1	1.2	0.0	1.3	14.6	552.9	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/17/2026 00:00	0.9	0.8	0.0	1.0	14.3	375.6	0.00	1.00
08/17/2026 01:00	0.9	0.8	0.0	1.0	14.3	375.7	0.00	1.00
08/17/2026 02:00	0.9	0.8	0.0	1.0	14.3	375.8	0.00	1.00
08/17/2026 03:00	0.9	0.8	0.0	1.0	14.3	376.1	0.00	1.00
08/17/2026 04:00	0.9	0.8	0.0	1.0	14.3	380.2	0.00	1.00
08/17/2026 05:00	0.9	0.8	0.0	1.0	14.3	376.7	0.00	1.00
08/17/2026 06:00	0.9	0.8	0.0	1.0	14.3	376.4	0.00	1.00
08/17/2026 07:00	0.9	0.8	0.0	1.0	14.3	376.4	0.00	1.00
08/17/2026 08:00	0.9	0.8	0.0	1.0	14.3	376.2	0.00	1.00
08/17/2026 09:00	0.9	0.8	0.0	1.0	14.4	375.7	0.00	1.00
08/17/2026 10:00	0.9	0.8	0.0	1.0	14.4	375.1	0.00	1.00
08/17/2026 11:00	0.8	0.7	0.0	0.9	14.4	374.6	0.00	1.00
08/17/2026 12:00	0.8	0.7	0.0	0.9	14.5	401.9	0.00	1.00
08/17/2026 13:00	1.1	0.9	0.0	1.3	13.9	524.4	0.00	1.00
08/17/2026 14:00	0.6	0.9	0.0	0.7	13.2	581.6	0.00	1.00
08/17/2026 15:00	0.4	0.9	0.0	0.6	13.0	588.8	0.00	1.00
08/17/2026 16:00	0.6	0.7	0.0	0.8	13.4	562.4	0.00	1.00
08/17/2026 17:00	0.3	0.6	0.0	0.5	12.7	623.8	0.00	1.00
08/17/2026 18:00	0.5	0.6	0.0	0.6	13.1	589.4	0.00	1.00
08/17/2026 19:00	0.8	0.7	0.0	0.9	13.5	557.0	0.00	1.00
08/17/2026 20:00	0.7	0.8	0.0	0.9	13.8	529.1	0.00	1.00
08/17/2026 21:00	0.9	0.9	0.0	1.0	14.5	413.3	0.00	1.00
08/17/2026 22:00	0.9	0.8	0.0	1.0	14.4	396.0	0.00	1.00
08/17/2026 23:00	0.9	0.8	0.0	1.0	14.3	375.8	0.00	1.00
Average/Sum#:	0.8	0.8	0.0	0.9	14.0	444.1	0.00 #	24.00 #
Minimum:	0.3	0.6	0.0	0.5	12.7	374.6	0.00	1.00
Maximum:	1.1	0.9	0.0	1.3	14.5	623.8	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/18/2026 00:00	0.9	0.8	0.0	1.0	14.3	376.2	0.00	1.00
08/18/2026 01:00	0.9	0.8	0.0	1.0	14.3	376.3	0.00	1.00
08/18/2026 02:00	0.9	0.8	0.0	1.0	14.3	376.7	0.00	1.00
08/18/2026 03:00	0.9	0.8	0.0	1.0	14.3	377.0	0.00	1.00
08/18/2026 04:00	0.9	0.8	0.0	1.0	14.3	377.4	0.00	1.00
08/18/2026 05:00	0.9	0.8	0.0	1.0	14.3	377.5	0.00	1.00
08/18/2026 06:00	0.9	0.8	0.0	1.0	14.3	377.6	0.00	1.00
08/18/2026 07:00	0.9	0.8	0.0	1.0	14.3	376.9	0.00	1.00
08/18/2026 08:00	0.9	0.8	0.0	1.0	14.3	376.5	0.00	1.00
08/18/2026 09:00	0.9	0.8	0.0	1.0	14.4	375.8	0.00	1.00
08/18/2026 10:00	0.9	0.8	0.0	1.0	14.4	375.1	0.00	1.00
08/18/2026 11:00	0.8	0.7	0.0	0.9	14.4	374.5	0.00	1.00
08/18/2026 12:00	0.9	0.7	0.0	1.0	14.4	397.2	0.00	1.00
08/18/2026 13:00	0.4	0.7	0.0	0.5	13.1	544.9	0.00	1.00
08/18/2026 14:00	0.3	0.5	0.0	0.4	12.7	562.9	0.00	1.00
08/18/2026 15:00	0.2	0.4	0.0	0.3	12.7	553.2	0.00	1.00
08/18/2026 16:00	0.2	0.3	0.0	0.3	12.6	584.0	0.00	1.00
08/18/2026 17:00	0.2	0.3	0.0	0.3	12.3	654.5	0.00	1.00
08/18/2026 18:00	0.2	0.3	0.0	0.3	12.6	626.9	0.00	1.00
08/18/2026 19:00	0.7	0.5	0.0	0.8	13.4	563.3	0.00	1.00
08/18/2026 20:00	1.1	0.8	0.0	1.3	14.0	521.1	0.00	1.00
08/18/2026 21:00	0.9	1.0	0.0	1.0	14.3	424.0	0.00	1.00
08/18/2026 22:00	0.9	1.0	0.0	1.0	14.4	395.6	0.00	1.00
08/18/2026 23:00	0.9	0.8	0.0	1.0	14.3	382.3	0.00	1.00
Average/Sum#:	0.7	0.7	0.0	0.8	13.9	447.0	0.00 #	24.00 #
Minimum:	0.2	0.3	0.0	0.3	12.3	374.5	0.00	1.00
Maximum:	1.1	1.0	0.0	1.3	14.4	654.5	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/19/2026 00:00	0.9	0.8	0.0	1.0	14.3	376.0	0.00	1.00
08/19/2026 01:00	0.9	0.8	0.0	1.0	14.3	376.4	0.00	1.00
08/19/2026 02:00	0.9	0.8	0.0	1.0	14.3	376.6	0.00	1.00
08/19/2026 03:00	0.9	0.8	0.0	1.0	14.3	376.8	0.00	1.00
08/19/2026 04:00	0.9	0.8	0.0	1.0	14.3	377.0	0.00	1.00
08/19/2026 05:00	0.9	0.8	0.0	1.0	14.3	377.4	0.00	1.00
08/19/2026 06:00	0.9	0.8	0.0	1.0	14.3	377.2	0.00	1.00
08/19/2026 07:00	0.9	0.8	0.0	1.0	14.3	376.8	0.00	1.00
08/19/2026 08:00	0.9	0.8	0.0	1.0	14.3	376.4	0.00	1.00
08/19/2026 09:00	0.9	0.8	0.0	1.0	14.4	375.6	0.00	1.00
08/19/2026 10:00	0.9	0.8	0.0	1.0	14.4	375.4	0.00	1.00
08/19/2026 11:00	0.8	0.8	0.0	0.9	14.4	375.1	0.00	1.00
08/19/2026 12:00	0.9	0.8	0.0	1.0	14.4	395.4	0.00	1.00
08/19/2026 13:00	0.2	0.6	0.0	0.3	12.6	561.9	0.00	1.00
08/19/2026 14:00	0.2	0.4	0.0	0.3	12.5	583.3	0.00	1.00
08/19/2026 15:00	0.4	0.3	0.0	0.5	12.8	567.7	0.00	1.00
08/19/2026 16:00	0.1	0.3	0.0	0.2	12.4	577.5	0.00	1.00
08/19/2026 17:00	0.2	0.3	0.0	0.3	12.4	645.3	0.00	1.00
08/19/2026 18:00	0.2	0.3	0.0	0.3	12.4	646.3	0.00	1.00
08/19/2026 19:00	0.3	0.3	0.0	0.4	12.6	628.8	0.00	1.00
08/19/2026 20:00	0.6	0.5	0.0	0.7	13.1	584.8	0.00	1.00
08/19/2026 21:00	0.8	0.6	0.0	0.9	14.5	452.8	0.00	1.00
08/19/2026 22:00	0.7	0.8	0.0	0.8	14.6	460.0	0.00	1.00
08/19/2026 23:00	0.8	0.8	0.0	0.9	14.5	458.4	0.00	1.00
Average/Sum#:	0.7	0.7	0.0	0.8	13.8	461.6	0.00 #	24.00 #
Minimum:	0.1	0.3	0.0	0.2	12.4	375.1	0.00	1.00
Maximum:	0.9	0.8	0.0	1.0	14.6	646.3	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/20/2026 00:00	0.8	0.8	0.0	0.9	14.4	420.3	0.00	1.00
08/20/2026 01:00	0.9	0.8	0.0	1.0	14.3	378.7	0.00	1.00
08/20/2026 02:00	0.9	0.8	0.0	1.0	14.3	378.3	0.00	1.00
08/20/2026 03:00	0.9	0.8	0.0	1.0	14.3	377.4	0.00	1.00
08/20/2026 04:00	0.9	0.8	0.0	1.0	14.3	377.6	0.00	1.00
08/20/2026 05:00	0.9	0.8	0.0	1.0	14.3	378.5	0.00	1.00
08/20/2026 06:00	0.9	0.8	0.0	1.0	14.3	381.1	0.00	1.00
08/20/2026 07:00	0.9	0.8	0.0	1.0	14.3	378.2	0.00	1.00
08/20/2026 08:00	0.9	0.8	0.0	1.0	14.3	377.9	0.00	1.00
08/20/2026 09:00	0.9	0.8	0.0	1.0	14.4	377.1	0.00	1.00
08/20/2026 10:00	0.9	0.7	0.0	1.0	14.4	376.8	0.00	1.00
08/20/2026 11:00	0.9	0.7	0.0	1.0	14.4	379.0	0.00	1.00
08/20/2026 12:00	0.9	0.7	0.0	1.0	14.4	405.9	0.00	1.00
08/20/2026 13:00	0.3	0.6	0.0	0.4	13.0	551.6	0.00	1.00
08/20/2026 14:00	0.4	0.6	0.0	0.5	13.1	554.9	0.00	1.00
08/20/2026 15:00	0.2	0.4	0.0	0.3	12.8	555.0	0.00	1.00
08/20/2026 16:00	0.2	0.4	0.0	0.3	12.7	569.3	0.00	1.00
08/20/2026 17:00	0.2	0.3	0.0	0.3	12.3	655.1	0.00	1.00
08/20/2026 18:00	0.3	0.3	0.0	0.4	12.6	635.3	0.00	1.00
08/20/2026 19:00	0.3	0.4	0.0	0.4	12.6	635.9	0.00	1.00
08/20/2026 20:00	0.5	0.5	0.0	0.7	13.1	590.2	0.00	1.00
08/20/2026 21:00	0.8	0.6	0.0	0.9	14.5	458.4	0.00	1.00
08/20/2026 22:00	0.7	0.8	0.0	0.8	14.5	458.0	0.00	1.00
08/20/2026 23:00	0.7	0.8	0.0	0.8	14.5	458.1	0.00	1.00
Average/Sum#:	0.7	0.7	0.0	0.8	13.8	462.9	0.00 #	24.00 #
Minimum:	0.2	0.3	0.0	0.3	12.3	376.8	0.00	1.00
Maximum:	0.9	0.8	0.0	1.0	14.5	655.1	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/21/2026 00:00	0.8	0.8	0.0	0.9	14.4	458.1	0.00	1.00
08/21/2026 01:00	0.9	0.8	0.0	1.0	14.3	394.7	0.00	1.00
08/21/2026 02:00	0.8	0.8	0.0	0.9	14.3	415.9	0.00	1.00
08/21/2026 03:00	0.9	0.8	0.0	1.0	14.3	386.2	0.00	1.00
08/21/2026 04:00	0.9	0.8	0.0	1.0	14.3	384.6	0.00	1.00
08/21/2026 05:00	0.8	0.8	0.0	0.9	14.4	460.9	0.00	1.00
08/21/2026 06:00	0.9	0.8	0.0	1.0	14.3	407.6	0.00	1.00
08/21/2026 07:00	0.9	0.8	0.0	1.0	14.3	378.7	0.00	1.00
08/21/2026 08:00	0.9	0.8	0.0	1.0	14.3	378.8	0.00	1.00
08/21/2026 09:00	0.9	0.8	0.0	1.0	14.3	378.2	0.00	1.00
08/21/2026 10:00	0.8	0.7	0.0	0.9	14.4	377.7	0.00	1.00
08/21/2026 11:00	0.8	0.7	0.0	0.9	14.4	377.0	0.00	1.00
08/21/2026 12:00	0.8	0.7	0.0	0.9	14.5	404.4	0.00	1.00
08/21/2026 13:00	0.6	0.7	0.0	0.7	13.3	541.2	0.00	1.00
08/21/2026 14:00	0.2	0.6	0.0	0.3	12.9	551.1	0.00	1.00
08/21/2026 15:00	0.2	0.4	0.0	0.3	12.9	547.7	0.00	1.00
08/21/2026 16:00	0.2	0.3	0.0	0.3	12.7	563.5	0.00	1.00
08/21/2026 17:00	0.2	0.3	0.0	0.3	12.4	648.6	0.00	1.00
08/21/2026 18:00	0.8	0.5	0.0	1.0	13.7	544.7	0.00	1.00
08/21/2026 19:00	1.1	0.9	0.0	1.3	14.0	525.5	0.00	1.00
08/21/2026 20:00	1.2	1.2	0.0	1.4	14.0	525.8	0.00	1.00
08/21/2026 21:00	0.9	1.2	0.0	1.0	14.3	382.8	0.00	1.00
08/21/2026 22:00	0.9	1.0	0.0	1.0	14.3	377.1	0.00	1.00
08/21/2026 23:00	0.8	0.8	0.0	0.9	14.4	430.9	0.00	1.00
Average/Sum#:	0.8	0.8	0.0	0.9	14.0	451.7	0.00 #	24.00 #
Minimum:	0.2	0.3	0.0	0.3	12.4	377.0	0.00	1.00
Maximum:	1.2	1.2	0.0	1.4	14.5	648.6	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/22/2026 00:00	0.8	0.8	0.0	0.9	14.4	423.8	0.00	1.00
08/22/2026 01:00	0.8	0.8	0.0	0.9	14.4	413.7	0.00	1.00
08/22/2026 02:00	0.9	0.8	0.0	1.0	14.3	377.8	0.00	1.00
08/22/2026 03:00	0.9	0.8	0.0	1.0	14.3	378.1	0.00	1.00
08/22/2026 04:00	0.8	0.8	0.0	0.9	14.3	410.2	0.00	1.00
08/22/2026 05:00	0.9	0.8	0.0	1.0	14.3	380.3	0.00	1.00
08/22/2026 06:00	0.9	0.8	0.0	1.0	14.3	378.7	0.00	1.00
08/22/2026 07:00	0.9	0.8	0.0	1.0	14.3	378.4	0.00	1.00
08/22/2026 08:00	0.9	0.8	0.0	1.0	14.3	377.9	0.00	1.00
08/22/2026 09:00	0.8	0.8	0.0	0.9	14.4	377.6	0.00	1.00
08/22/2026 10:00	0.8	0.7	0.0	0.9	14.4	377.1	0.00	1.00
08/22/2026 11:00	0.8	0.7	0.0	0.9	14.4	376.0	0.00	1.00
08/22/2026 12:00	0.8	0.7	0.0	0.9	14.5	402.1	0.00	1.00
08/22/2026 13:00	1.1	0.9	0.0	1.3	14.0	525.2	0.00	1.00
08/22/2026 14:00	1.0	1.1	0.0	1.2	14.0	525.0	0.00	1.00
08/22/2026 15:00	1.0	1.2	0.0	1.2	14.0	524.9	0.00	1.00
08/22/2026 16:00	1.0	1.2	0.0	1.2	13.9	527.3	0.00	1.00
08/22/2026 17:00	0.3	0.9	0.0	0.4	13.1	542.7	0.00	1.00
08/22/2026 18:00	0.3	0.7	0.0	0.4	13.1	541.1	0.00	1.00
08/22/2026 19:00	0.5	0.5	0.0	0.6	13.5	534.3	0.00	1.00
08/22/2026 20:00	0.7	0.6	0.0	0.9	13.8	529.1	0.00	1.00
08/22/2026 21:00	0.9	0.8	0.0	1.0	14.4	388.8	0.00	1.00
08/22/2026 22:00	0.9	0.8	0.0	1.0	14.4	376.9	0.00	1.00
08/22/2026 23:00	0.9	0.8	0.0	1.0	14.3	377.7	0.00	1.00
Average/Sum#:	0.8	0.8	0.0	0.9	14.1	435.2	0.00 #	24.00 #
Minimum:	0.3	0.5	0.0	0.4	13.1	376.0	0.00	1.00
Maximum:	1.1	1.2	0.0	1.3	14.5	542.7	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/23/2026 00:00	0.8	0.8	0.0	0.9	14.4	408.0	0.00	1.00
08/23/2026 01:00	0.9	0.8	0.0	1.0	14.3	379.3	0.00	1.00
08/23/2026 02:00	0.9	0.8	0.0	1.0	14.3	377.8	0.00	1.00
08/23/2026 03:00	1.0	0.8	0.0	1.1	14.3	378.1	0.00	1.00
08/23/2026 04:00	1.0	0.8	0.0	1.1	14.3	378.5	0.00	1.00
08/23/2026 05:00	1.0	0.8	0.0	1.1	14.3	378.9	0.00	1.00
08/23/2026 06:00	1.1	0.9	0.0	1.2	14.3	378.7	0.00	1.00
08/23/2026 07:00	1.1	0.9	0.0	1.2	14.3	378.0	0.00	1.00
08/23/2026 08:00	0.9	0.9	0.0	1.0	14.4	377.2	0.00	1.00
08/23/2026 09:00	0.9	0.8	0.0	1.0	14.4	376.5	0.00	1.00
08/23/2026 10:00	0.9	0.8	0.0	1.0	14.4	375.9	0.00	1.00
08/23/2026 11:00	0.9	0.8	0.0	1.0	14.5	375.4	0.00	1.00
08/23/2026 12:00	0.9	0.8	0.0	1.0	14.5	405.1	0.00	1.00
08/23/2026 13:00	1.0	0.9	0.0	1.2	13.8	527.9	0.00	1.00
08/23/2026 14:00	0.3	0.8	0.0	0.4	12.8	549.5	0.00	1.00
08/23/2026 15:00	0.3	0.6	0.0	0.4	12.8	578.6	0.00	1.00
08/23/2026 16:00	0.5	0.4	0.0	0.6	13.0	598.9	0.00	1.00
08/23/2026 17:00	0.2	0.4	0.0	0.3	12.4	646.8	0.00	1.00
08/23/2026 18:00	0.2	0.4	0.0	0.3	12.5	639.4	0.00	1.00
08/23/2026 19:00	0.4	0.4	0.0	0.5	12.9	607.7	0.00	1.00
08/23/2026 20:00	0.6	0.5	0.0	0.7	13.2	585.4	0.00	1.00
08/23/2026 21:00	0.8	0.7	0.0	0.9	14.4	460.5	0.00	1.00
08/23/2026 22:00	0.8	0.8	0.0	0.9	14.4	460.9	0.00	1.00
08/23/2026 23:00	0.8	0.8	0.0	0.9	14.4	459.6	0.00	1.00
Average/Sum#:	0.8	0.7	0.0	0.9	13.9	461.8	0.00 #	24.00 #
Minimum:	0.2	0.4	0.0	0.3	12.4	375.4	0.00	1.00
Maximum:	1.1	0.9	0.0	1.2	14.5	646.8	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/24/2026 00:00	0.8	0.8	0.0	0.9	14.4	459.8	0.00	1.00
08/24/2026 01:00	0.8	0.8	0.0	0.9	14.6	459.7	0.00	1.00
08/24/2026 02:00	0.8	0.8	0.0	0.9	14.5	458.9	0.00	1.00
08/24/2026 03:00	0.8	0.8	0.0	0.9	14.5	451.1	0.00	1.00
08/24/2026 04:00	0.8	0.8	0.0	0.9	14.5	456.0	0.00	1.00
08/24/2026 05:00	0.9	0.8	0.0	1.0	14.3	382.4	0.00	1.00
08/24/2026 06:00	0.8	0.8	0.0	0.9	14.4	414.5	0.00	1.00
08/24/2026 07:00	0.9	0.8	0.0	1.0	14.3	393.9	0.00	1.00
08/24/2026 08:00	0.9	0.8	0.0	1.0	14.3	377.1	0.00	1.00
08/24/2026 09:00	0.9	0.8	0.0	1.0	14.4	376.7	0.00	1.00
08/24/2026 10:00	0.9	0.8	0.0	1.0	14.4	376.2	0.00	1.00
08/24/2026 11:00	0.8	0.7	0.0	0.9	14.5	376.0	0.00	1.00
08/24/2026 12:00	0.8	0.7	0.0	0.9	14.5	406.9	0.00	1.00
08/24/2026 13:00	0.4	0.7	0.0	0.6	13.0	556.1	0.00	1.00
08/24/2026 14:00	0.2	0.6	0.0	0.3	12.4	616.3	0.00	1.00
08/24/2026 15:00	0.2	0.4	0.0	0.3	12.4	648.4	0.00	1.00
08/24/2026 16:00	0.3	0.3	0.0	0.4	12.7	622.7	0.00	1.00
08/24/2026 17:00	0.2	0.3	0.0	0.3	12.4	649.7	0.00	1.00
08/24/2026 18:00	0.2	0.3	0.0	0.3	12.4	653.5	0.00	1.00
08/24/2026 19:00	0.2	0.3	0.0	0.3	12.4	652.1	0.00	1.00
08/24/2026 20:00	0.6	0.5	0.0	0.8	13.3	578.6	0.00	1.00
08/24/2026 21:00	0.8	0.6	0.0	0.9	14.6	460.1	0.00	1.00
08/24/2026 22:00	0.7	0.8	0.0	0.8	14.5	460.0	0.00	1.00
08/24/2026 23:00	0.8	0.8	0.0	0.9	14.5	444.4	0.00	1.00
Average/Sum#:	0.6	0.7	0.0	0.8	13.8	488.8	0.00 #	24.00 #
Minimum:	0.2	0.3	0.0	0.3	12.4	376.0	0.00	1.00
Maximum:	0.9	0.8	0.0	1.0	14.6	653.5	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/25/2026 00:00	0.8	0.8	0.0	0.9	14.4	422.1	0.00	1.00
08/25/2026 01:00	0.9	0.8	0.0	1.0	14.3	381.7	0.00	1.00
08/25/2026 02:00	0.9	0.8	0.0	1.0	14.3	378.0	0.00	1.00
08/25/2026 03:00	0.9	0.8	0.0	1.0	14.3	378.5	0.00	1.00
08/25/2026 04:00	0.8	0.8	0.0	0.9	14.3	418.6	0.00	1.00
08/25/2026 05:00	0.9	0.8	0.0	1.0	14.3	398.6	0.00	1.00
08/25/2026 06:00	0.9	0.8	0.0	1.0	14.3	403.2	0.00	1.00
08/25/2026 07:00	0.9	0.8	0.0	1.0	14.3	378.3	0.00	1.00
08/25/2026 08:00	0.9	0.8	0.0	1.0	14.3	378.0	0.00	1.00
08/25/2026 09:00	0.9	0.8	0.0	1.0	14.3	377.7	0.00	1.00
08/25/2026 10:00	0.9	0.8	0.0	1.0	14.4	377.0	0.00	1.00
08/25/2026 11:00	0.8	0.7	0.0	0.9	14.4	417.0	0.00	1.00
08/25/2026 12:00	0.7	0.7	0.0	0.8	14.4	445.9	0.00	1.00
08/25/2026 13:00	0.7	0.8	0.0	0.8	14.5	468.3	0.00	1.00
08/25/2026 14:00	0.8	0.9	0.0	1.0	13.6	555.8	0.00	1.00
08/25/2026 15:00	0.9	1.0	0.0	1.0	13.8	536.3	0.00	1.00
08/25/2026 16:00	0.5	0.9	0.0	0.6	13.1	595.8	0.00	1.00
08/25/2026 17:00	0.2	0.7	0.0	0.3	12.3	658.0	0.00	1.00
08/25/2026 18:00	0.2	0.4	0.0	0.3	12.3	657.8	0.00	1.00
08/25/2026 19:00	0.3	0.3	0.0	0.4	12.8	624.7	0.00	1.00
08/25/2026 20:00	0.7	0.5	0.0	0.9	13.4	564.4	0.00	1.00
08/25/2026 21:00	0.6	0.7	0.0	0.8	13.5	549.7	0.00	1.00
08/25/2026 22:00	0.9	0.8	0.0	1.0	14.4	409.8	0.00	1.00
08/25/2026 23:00	0.9	0.8	0.0	1.0	14.4	377.7	0.00	1.00
Average/Sum#:	0.7	0.8	0.0	0.9	13.9	464.7	0.00 #	24.00 #
Minimum:	0.2	0.3	0.0	0.3	12.3	377.0	0.00	1.00
Maximum:	0.9	1.0	0.0	1.0	14.5	658.0	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/26/2026 00:00	0.9	0.8	0.0	1.0	14.4	384.2	0.00	1.00
08/26/2026 01:00	0.9	0.8	0.0	1.0	14.3	377.5	0.00	1.00
08/26/2026 02:00	0.9	0.8	0.0	1.0	14.4	404.0	0.00	1.00
08/26/2026 03:00	0.9	0.8	0.0	1.0	14.3	377.7	0.00	1.00
08/26/2026 04:00	0.8	0.8	0.0	0.9	14.4	424.0	0.00	1.00
08/26/2026 05:00	0.8	0.8	0.0	0.9	14.5	459.3	0.00	1.00
08/26/2026 06:00	0.9	0.8	0.0	1.0	14.4	413.3	0.00	1.00
08/26/2026 07:00	0.9	0.8	0.0	1.0	14.3	378.0	0.00	1.00
08/26/2026 08:00	0.9	0.8	0.0	1.0	14.4	377.6	0.00	1.00
08/26/2026 09:00	0.9	0.8	0.0	1.0	14.4	376.8	0.00	1.00
08/26/2026 10:00	0.9	0.8	0.0	1.0	14.4	376.6	0.00	1.00
08/26/2026 11:00	0.7	0.8	0.0	0.8	14.5	457.0	0.00	1.00
08/26/2026 12:00	0.7	0.8	0.0	0.8	14.5	462.5	0.00	1.00
08/26/2026 13:00	0.8	0.9	0.0	1.0	13.6	545.4	0.00	1.00
08/26/2026 14:00	0.3	0.7	0.0	0.4	12.9	546.7	0.00	1.00
08/26/2026 15:00	0.2	0.5	0.0	0.3	12.8	549.1	0.00	1.00
08/26/2026 16:00	0.2	0.3	0.0	0.3	12.7	549.9	0.00	1.00
08/26/2026 17:00	0.3	0.3	0.0	0.4	12.8	598.2	0.00	1.00
08/26/2026 18:00	0.6	0.5	0.0	0.7	13.4	560.4	0.00	1.00
08/26/2026 19:00	0.4	0.5	0.0	0.5	13.1	570.7	0.00	1.00
08/26/2026 20:00	0.6	0.6	0.0	0.7	13.3	565.3	0.00	1.00
08/26/2026 21:00	0.9	0.7	0.0	0.9	14.6	457.5	0.00	1.00
08/26/2026 22:00	0.9	0.8	0.0	1.0	14.4	384.8	0.00	1.00
08/26/2026 23:00	0.9	0.8	0.0	0.9	14.5	426.7	0.00	1.00
Average/Sum#:	0.7	0.7	0.0	0.8	14.0	459.3	0.00 #	24.00 #
Minimum:	0.2	0.3	0.0	0.3	12.7	376.6	0.00	1.00
Maximum:	0.9	0.9	0.0	1.0	14.6	598.2	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/27/2026 00:00	0.9	0.8	0.0	1.0	14.4	401.1	0.00	1.00
08/27/2026 01:00	0.9	0.8	0.0	1.0	14.4	377.2	0.00	1.00
08/27/2026 02:00	0.9	0.8	0.0	1.0	14.3	377.5	0.00	1.00
08/27/2026 03:00	1.0	0.8	0.0	1.1	14.3	377.7	0.00	1.00
08/27/2026 04:00	0.9	0.8	0.0	1.0	14.3	377.8	0.00	1.00
08/27/2026 05:00	0.9	0.8	0.0	1.0	14.4	413.7	0.00	1.00
08/27/2026 06:00	0.9	0.8	0.0	1.0	14.4	425.6	0.00	1.00
08/27/2026 07:00	0.8	0.8	0.0	0.9	14.5	462.4	0.00	1.00
08/27/2026 08:00	0.8	0.9	0.0	0.9	14.6	462.2	0.00	1.00
08/27/2026 09:00	0.7	0.9	0.0	0.8	14.6	462.3	0.00	1.00
08/27/2026 10:00	0.8	0.8	0.0	0.9	14.5	461.1	0.00	1.00
08/27/2026 11:00	0.8	0.8	0.0	0.9	14.5	461.3	0.00	1.00
08/27/2026 12:00	0.8	0.8	0.0	0.9	14.5	472.8	0.00	1.00
08/27/2026 13:00	0.5	0.8	0.0	0.7	12.8	615.9	0.00	1.00
08/27/2026 14:00	0.3	0.6	0.0	0.4	12.4	639.6	0.00	1.00
08/27/2026 15:00	0.7	0.7	0.0	0.9	13.6	546.3	0.00	1.00
08/27/2026 16:00	0.7	0.7	0.0	0.8	13.5	557.7	0.00	1.00
08/27/2026 17:00	0.9	0.9	0.0	1.1	13.8	528.5	0.00	1.00
08/27/2026 18:00	0.6	0.8	0.0	0.7	13.4	539.7	0.00	1.00
08/27/2026 19:00	0.5	0.8	0.0	0.6	13.3	542.5	0.00	1.00
08/27/2026 20:00	0.4	0.6	0.0	0.5	13.0	571.2	0.00	1.00
08/27/2026 21:00	0.8	0.7	0.0	0.9	14.6	459.2	0.00	1.00
08/27/2026 22:00	0.8	0.7	0.0	0.9	14.6	461.8	0.00	1.00
08/27/2026 23:00	0.6	0.8	0.0	0.7	13.1	586.2	0.00	1.00
Average/Sum#:	0.7	0.8	0.0	0.9	14.0	482.6	0.00 #	24.00 #
Minimum:	0.3	0.6	0.0	0.4	12.4	377.2	0.00	1.00
Maximum:	1.0	0.9	0.0	1.1	14.6	639.6	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/28/2026 00:00	0.7	0.8	0.0	0.9	13.6	548.3	0.00	1.00
08/28/2026 01:00	0.8	0.9	0.0	1.0	13.8	539.6	0.00	1.00
08/28/2026 02:00	1.0	1.0	0.0	1.2	13.9	527.0	0.00	1.00
08/28/2026 03:00	0.9	1.1	0.0	1.1	13.8	536.7	0.00	1.00
08/28/2026 04:00	0.6	1.0	0.0	0.8	13.3	577.9	0.00	1.00
08/28/2026 05:00	0.3	0.8	0.0	0.4	12.5	646.1	0.00	1.00
08/28/2026 06:00	0.4	0.6	0.0	0.5	12.7	627.7	0.00	1.00
08/28/2026 07:00	0.3	0.4	0.0	0.4	12.5	646.3	0.00	1.00
08/28/2026 08:00	1.0	0.7	0.0	1.2	13.6	557.9	0.00	1.00
08/28/2026 09:00	1.0	0.9	0.0	1.2	13.9	528.7	0.00	1.00
08/28/2026 10:00	0.9	1.1	0.0	1.1	13.7	540.3	0.00	1.00
08/28/2026 11:00	0.6	1.0	0.0	0.8	13.6	547.4	0.00	1.00
08/28/2026 12:00	0.7	0.9	0.0	0.8	13.6	544.2	0.00	1.00
08/28/2026 13:00	0.7	0.8	0.0	0.8	13.7	536.9	0.00	1.00
08/28/2026 14:00	0.6	0.8	0.0	0.7	13.5	540.4	0.00	1.00
08/28/2026 15:00	0.6	0.7	0.0	0.8	13.6	535.9	0.00	1.00
08/28/2026 16:00	0.7	0.7	0.0	0.9	13.7	533.3	0.00	1.00
08/28/2026 17:00	0.8	0.8	0.0	1.0	13.8	531.3	0.00	1.00
08/28/2026 18:00	0.8	0.9	0.0	1.0	13.8	533.6	0.00	1.00
08/28/2026 19:00	0.9	1.0	0.0	1.1	13.9	528.0	0.00	1.00
08/28/2026 20:00	0.9	1.1	0.0	1.1	13.9	525.4	0.00	1.00
08/28/2026 21:00	1.0	1.1	0.0	1.2	14.0	523.1	0.00	1.00
08/28/2026 22:00	1.1	1.2	0.0	1.3	14.0	522.5	0.00	1.00
08/28/2026 23:00	1.2	1.3	0.0	1.4	14.0	522.4	0.00	1.00
Average/Sum#:	0.8	0.9	0.0	0.9	13.6	550.0	0.00 #	24.00 #
Minimum:	0.3	0.4	0.0	0.4	12.5	522.4	0.00	1.00
Maximum:	1.2	1.3	0.0	1.4	14.0	646.3	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/29/2026 00:00	1.3	1.4	0.0	1.5	14.0	521.8	0.00	1.00
08/29/2026 01:00	1.3	1.5	0.0	1.5	14.0	522.2	0.00	1.00
08/29/2026 02:00	1.5	1.6	0.0	1.7	14.1	521.4	0.00	1.00
08/29/2026 03:00	1.6	1.7	0.0	1.8	14.1	520.3	0.00	1.00
08/29/2026 04:00	1.6	1.8	0.0	1.8	14.1	518.9	0.00	1.00
08/29/2026 05:00	1.7	1.8	0.0	1.9	14.2	516.8	0.00	1.00
08/29/2026 06:00	1.7	1.9	0.0	1.9	14.2	517.3	0.00	1.00
08/29/2026 07:00	1.6	1.9	0.0	1.8	14.1	520.4	0.00	1.00
08/29/2026 08:00	1.5	1.8	0.0	1.7	14.1	521.0	0.00	1.00
08/29/2026 09:00	1.1	1.6	0.0	1.3	14.0	523.9	0.00	1.00
08/29/2026 10:00	1.0	1.4	0.0	1.2	13.9	525.8	0.00	1.00
08/29/2026 11:00	0.9	1.2	0.0	1.1	13.8	529.4	0.00	1.00
08/29/2026 12:00	0.7	1.1	0.0	0.9	13.6	534.4	0.00	1.00
08/29/2026 13:00	0.6	0.9	0.0	0.8	13.5	538.0	0.00	1.00
08/29/2026 14:00	0.5	0.7	0.0	0.6	13.3	542.4	0.00	1.00
08/29/2026 15:00	0.9	0.8	0.0	1.0	13.7	530.8	0.00	1.00
08/29/2026 16:00	1.2	1.0	0.0	1.4	14.0	523.7	0.00	1.00
08/29/2026 17:00	1.0	1.2	0.0	1.2	13.7	548.7	0.00	1.00
08/29/2026 18:00	1.0	1.3	0.0	1.2	13.9	526.2	0.00	1.00
08/29/2026 19:00	0.9	1.2	0.0	1.1	13.9	525.6	0.00	1.00
08/29/2026 20:00	1.0	1.2	0.0	1.2	13.9	526.3	0.00	1.00
08/29/2026 21:00	1.1	1.2	0.0	1.3	13.9	525.2	0.00	1.00
08/29/2026 22:00	1.2	1.3	0.0	1.4	14.0	523.5	0.00	1.00
08/29/2026 23:00	1.4	1.4	0.0	1.6	14.0	522.1	0.00	1.00
Average/Sum#:	1.2	1.4	0.0	1.4	13.9	526.1	0.00 #	24.00 #
Minimum:	0.5	0.7	0.0	0.6	13.3	516.8	0.00	1.00
Maximum:	1.7	1.9	0.0	1.9	14.2	548.7	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/30/2026 00:00	1.6	1.6	0.0	1.8	14.1	520.2	0.00	1.00
08/30/2026 01:00	1.6	1.7	0.0	1.8	14.1	518.8	0.00	1.00
08/30/2026 02:00	1.6	1.8	0.0	1.8	14.1	518.8	0.00	1.00
08/30/2026 03:00	1.6	1.8	0.0	1.9	14.1	518.5	0.00	1.00
08/30/2026 04:00	1.7	1.9	0.0	1.9	14.1	518.1	0.00	1.00
08/30/2026 05:00	1.7	1.9	0.0	2.0	14.2	517.0	0.00	1.00
08/30/2026 06:00	1.8	2.0	0.0	2.0	14.2	516.3	0.00	1.00
08/30/2026 07:00	1.6	2.0	0.0	1.9	14.1	520.3	0.00	1.00
08/30/2026 08:00	1.6	1.9	0.0	1.8	14.1	522.4	0.00	1.00
08/30/2026 09:00	1.2	1.7	0.0	1.4	14.0	524.5	0.00	1.00
08/30/2026 10:00	1.0	1.5	0.0	1.2	13.9	528.4	0.00	1.00
08/30/2026 11:00	0.9	1.2	0.0	1.1	13.8	530.8	0.00	1.00
08/30/2026 12:00	0.7	1.1	0.0	0.9	13.7	533.9	0.00	1.00
08/30/2026 13:00	0.6	0.9	0.0	0.8	13.5	535.4	0.00	1.00
08/30/2026 14:00	0.6	0.8	0.0	0.7	13.4	535.0	0.00	1.00
08/30/2026 15:00	0.5	0.7	0.0	0.7	13.3	537.1	0.00	1.00
08/30/2026 16:00	0.5	0.6	0.0	0.6	13.2	546.1	0.00	1.00
08/30/2026 17:00	0.4	0.6	0.0	0.5	12.9	569.7	0.00	1.00
08/30/2026 18:00	0.6	0.6	0.0	0.8	13.6	532.9	0.00	1.00
08/30/2026 19:00	0.9	0.7	0.0	1.1	13.8	526.5	0.00	1.00
08/30/2026 20:00	1.0	1.0	0.0	1.2	13.9	525.7	0.00	1.00
08/30/2026 21:00	1.0	1.1	0.0	1.2	13.9	526.5	0.00	1.00
08/30/2026 22:00	1.1	1.2	0.0	1.3	14.0	524.7	0.00	1.00
08/30/2026 23:00	1.3	1.3	0.0	1.5	14.0	521.7	0.00	1.00
Average/Sum#:	1.1	1.3	0.0	1.3	13.8	527.9	0.00 #	24.00 #
Minimum:	0.4	0.6	0.0	0.5	12.9	516.3	0.00	1.00
Maximum:	1.8	2.0	0.0	2.0	14.2	569.7	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/31/2026 00:00	1.4	1.5	0.0	1.6	14.0	520.2	0.00	1.00
08/31/2026 01:00	1.6	1.7	0.0	1.8	14.1	518.8	0.00	1.00
08/31/2026 02:00	1.6	1.8	0.0	1.8	14.1	518.7	0.00	1.00
08/31/2026 03:00	1.6	1.9	0.0	1.9	14.1	518.3	0.00	1.00
08/31/2026 04:00	1.7	1.9	0.0	1.9	14.1	518.0	0.00	1.00
08/31/2026 05:00	1.4	1.8	0.0	1.5	14.2	462.2	0.00	1.00
08/31/2026 06:00	1.0	1.4	0.0	1.1	14.2	379.0	0.00	1.00
08/31/2026 07:00	1.0	1.0	0.0	1.1	14.2	379.0	0.00	1.00
08/31/2026 08:00	1.0	0.8	0.0	1.1	14.3	378.4	0.00	1.00
08/31/2026 09:00	1.0	0.8	0.0	1.1	14.3	378.4	0.00	1.00
08/31/2026 10:00	1.0	0.8	0.0	1.1	14.3	378.2	0.00	1.00
08/31/2026 11:00	0.9	0.8	0.0	1.0	14.3	378.1	0.00	1.00
08/31/2026 12:00	0.9	0.8	0.0	1.0	14.4	407.1	0.00	1.00
08/31/2026 13:00	1.1	1.0	0.0	1.3	13.9	529.9	0.00	1.00
08/31/2026 14:00	1.0	1.1	0.0	1.2	13.9	526.7	0.00	1.00
08/31/2026 15:00	1.0	1.2	0.0	1.2	13.9	526.4	0.00	1.00
08/31/2026 16:00	1.0	1.2	0.0	1.2	13.9	526.2	0.00	1.00
08/31/2026 17:00	1.2	1.3	0.0	1.4	14.0	523.5	0.00	1.00
08/31/2026 18:00	1.5	1.4	0.0	1.7	14.0	520.6	0.00	1.00
08/31/2026 19:00	1.6	1.6	0.0	1.8	14.1	521.6	0.00	1.00
08/31/2026 20:00	1.6	1.8	0.0	1.8	14.1	520.2	0.00	1.00
08/31/2026 21:00	1.2	1.6	0.0	1.4	14.2	426.0	0.00	1.00
08/31/2026 22:00	1.0	1.3	0.0	1.1	14.3	378.7	0.00	1.00
08/31/2026 23:00	0.9	0.9	0.0	1.0	14.3	405.5	0.00	1.00
Average/Sum#:	1.2	1.3	0.0	1.4	14.1	464.2	0.00 #	24.00 #
Minimum:	0.9	0.8	0.0	1.0	13.9	378.1	0.00	1.00
Maximum:	1.7	1.9	0.0	1.9	14.4	529.9	0.00	1.00
%SI	0.00	0.00	8.33	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/01/2026 00:00	0.9	0.8	0.0	1.0	14.3	404.6	0.00	1.00
09/01/2026 01:00	1.0	0.8	0.0	1.1	14.2	377.6	0.00	1.00
09/01/2026 02:00	1.0	0.8	0.0	1.1	14.2	377.5	0.00	1.00
09/01/2026 03:00	1.0	0.8	0.0	1.1	14.2	377.2	0.00	1.00
09/01/2026 04:00	1.0	0.8	0.0	1.1	14.2	377.4	0.00	1.00
09/01/2026 05:00	1.0	0.8	0.0	1.1	14.2	377.6	0.00	1.00
09/01/2026 06:00	1.0	0.8	0.0	1.1	14.2	377.2	0.00	1.00
09/01/2026 07:00	1.0	0.8	0.0	1.1	14.3	377.1	0.00	1.00
09/01/2026 08:00	1.0	0.8	0.0	1.1	14.3	377.0	0.00	1.00
09/01/2026 09:00	1.0	0.8	0.0	1.1	14.3	376.4	0.00	1.00
09/01/2026 10:00	0.9	0.8	0.0	1.0	14.3	376.2	0.00	1.00
09/01/2026 11:00	0.9	0.8	0.0	1.0	14.3	375.5	0.00	1.00
09/01/2026 12:00	0.9	0.8	0.0	1.0	14.3	375.2	0.00	1.00
09/01/2026 13:00	0.9	0.8	0.0	1.0	14.4	374.8	0.00	1.00
09/01/2026 14:00	0.9	0.8	0.0	1.0	14.4	374.5	0.00	1.00
09/01/2026 15:00	0.9	0.8	0.0	1.0	14.4	374.1	0.00	1.00
09/01/2026 16:00	0.9	0.8	0.0	1.0	14.4	374.2	0.00	1.00
09/01/2026 17:00	0.9	0.8	0.0	1.0	14.4	390.4	0.00	1.00
09/01/2026 18:00	0.9	0.8	0.0	1.0	14.3	375.1	0.00	1.00
09/01/2026 19:00	0.9	0.8	0.0	1.0	14.3	375.4	0.00	1.00
09/01/2026 20:00	0.9	0.8	0.0	1.0	14.3	376.2	0.00	1.00
09/01/2026 21:00	1.0	0.8	0.0	1.1	14.3	376.6	0.00	1.00
09/01/2026 22:00	1.0	0.8	0.0	1.1	14.3	377.2	0.00	1.00
09/01/2026 23:00	1.0	0.8	0.0	1.1	14.2	377.7	0.00	1.00
Average/Sum#:	1.0	0.8	0.0	1.1	14.3	378.0	0.00 #	24.00 #
Minimum:	0.9	0.8	0.0	1.0	14.2	374.1	0.00	1.00
Maximum:	1.0	0.8	0.0	1.1	14.4	404.6	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/02/2026 00:00	1.0	0.8	0.0	1.1	14.2	378.2	0.00	1.00
09/02/2026 01:00	1.0	0.8	0.0	1.1	14.2	378.1	0.00	1.00
09/02/2026 02:00	1.0	0.8	0.0	1.1	14.2	378.2	0.00	1.00
09/02/2026 03:00	1.0	0.8	0.0	1.1	14.2	378.1	0.00	1.00
09/02/2026 04:00	1.0	0.8	0.0	1.1	14.2	378.3	0.00	1.00
09/02/2026 05:00	1.0	0.8	0.0	1.1	14.2	378.2	0.00	1.00
09/02/2026 06:00	1.0	0.8	0.0	1.1	14.2	378.1	0.00	1.00
09/02/2026 07:00	1.0	0.8	0.0	1.1	14.3	377.9	0.00	1.00
09/02/2026 08:00	0.9	0.8	0.0	1.0	14.3	377.7	0.00	1.00
09/02/2026 09:00	0.9	0.8	0.0	1.0	14.3	377.4	0.00	1.00
09/02/2026 10:00	0.9	0.8	0.0	1.0	14.3	376.7	0.00	1.00
09/02/2026 11:00	0.9	0.8	0.0	1.0	14.3	375.7	0.00	1.00
09/02/2026 12:00	0.9	0.8	0.0	1.0	14.3	374.7	0.00	1.00
09/02/2026 13:00	0.9	0.8	0.0	1.0	14.4	374.3	0.00	1.00
09/02/2026 14:00	0.9	0.8	0.0	1.0	14.4	374.2	0.00	1.00
09/02/2026 15:00	0.9	0.8	0.0	1.0	14.4	374.0	0.00	1.00
09/02/2026 16:00	0.9	0.8	0.0	1.0	14.4	378.0	0.00	1.00
09/02/2026 17:00	0.9	0.8	0.0	1.0	14.4	403.3	0.00	1.00
09/02/2026 18:00	0.9	0.8	0.0	1.0	14.3	374.5	0.00	1.00
09/02/2026 19:00	0.9	0.8	0.0	1.0	14.3	373.9	0.00	1.00
09/02/2026 20:00	0.9	0.8	0.0	1.0	14.3	374.3	0.00	1.00
09/02/2026 21:00	1.0	0.8	0.0	1.1	14.3	374.7	0.00	1.00
09/02/2026 22:00	1.0	0.8	0.0	1.1	14.3	374.8	0.00	1.00
09/02/2026 23:00	1.0	0.8	0.0	1.1	14.3	375.2	0.00	1.00
Average/Sum#:	0.9	0.8	0.0	1.0	14.3	377.4	0.00 #	24.00 #
Minimum:	0.9	0.8	0.0	1.0	14.2	373.9	0.00	1.00
Maximum:	1.0	0.8	0.0	1.1	14.4	403.3	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/03/2026 00:00	1.0	0.8	0.0	1.1	14.3	375.6	0.00	1.00
09/03/2026 01:00	1.0	0.8	0.0	1.1	14.3	375.8	0.00	1.00
09/03/2026 02:00	1.0	0.8	0.0	1.1	14.2	376.0	0.00	1.00
09/03/2026 03:00	1.0	0.8	0.0	1.1	14.2	376.1	0.00	1.00
09/03/2026 04:00	1.0	0.8	0.0	1.1	14.2	375.9	0.00	1.00
09/03/2026 05:00	1.0	0.8	0.0	1.1	14.2	376.7	0.00	1.00
09/03/2026 06:00	1.0	0.8	0.0	1.1	14.2	381.0	0.00	1.00
09/03/2026 07:00	0.9	0.8	0.0	1.0	14.3	402.4	0.00	1.00
09/03/2026 08:00	0.9	0.8	0.0	1.0	14.3	398.1	0.00	1.00
09/03/2026 09:00	0.9	0.8	0.0	1.0	14.4	420.2	0.00	1.00
09/03/2026 10:00	0.9	0.8	0.0	1.0	14.3	406.3	0.00	1.00
09/03/2026 11:00	0.9	0.8	0.0	1.0	14.3	374.9	0.00	1.00
09/03/2026 12:00	0.9	0.8	0.0	1.0	14.4	405.7	0.00	1.00
09/03/2026 13:00	0.8	0.8	0.0	0.9	14.5	453.7	0.00	1.00
09/03/2026 14:00	0.8	0.8	0.0	0.9	14.5	454.6	0.00	1.00
09/03/2026 15:00	0.8	0.8	0.0	0.9	14.5	454.0	0.00	1.00
09/03/2026 16:00	0.9	0.8	0.0	1.0	14.3	394.0	0.00	1.00
09/03/2026 17:00	0.8	0.8	0.0	0.9	14.4	423.0	0.00	1.00
09/03/2026 18:00	0.9	0.8	0.0	1.0	14.2	378.6	0.00	1.00
09/03/2026 19:00	0.9	0.8	0.0	1.0	14.3	410.8	0.00	1.00
09/03/2026 20:00	0.8	0.8	0.0	0.9	14.4	455.9	0.00	1.00
09/03/2026 21:00	0.9	0.9	0.0	1.0	14.4	459.2	0.00	1.00
09/03/2026 22:00	0.9	0.9	0.0	1.0	14.4	459.9	0.00	1.00
09/03/2026 23:00	0.8	0.9	0.0	0.9	14.4	455.2	0.00	1.00
Average/Sum#:	0.9	0.8	0.0	1.0	14.3	410.2	0.00 #	24.00 #
Minimum:	0.8	0.8	0.0	0.9	14.2	374.9	0.00	1.00
Maximum:	1.0	0.9	0.0	1.1	14.5	459.9	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/04/2026 00:00	0.9	0.8	0.0	1.0	14.3	394.6	0.00	1.00
09/04/2026 01:00	0.9	0.8	0.0	1.0	14.2	376.5	0.00	1.00
09/04/2026 02:00	0.9	0.7	0.0	1.0	14.2	376.5	0.00	1.00
09/04/2026 03:00	1.0	0.7	0.0	1.1	14.2	376.4	0.00	1.00
09/04/2026 04:00	0.9	0.8	0.0	1.0	14.2	388.8	0.00	1.00
09/04/2026 05:00	0.8	0.8	0.0	0.9	14.4	450.5	0.00	1.00
09/04/2026 06:00	0.9	0.8	0.0	1.0	14.3	397.5	0.00	1.00
09/04/2026 07:00	0.9	0.8	0.0	1.0	14.3	403.7	0.00	1.00
09/04/2026 08:00	0.9	0.8	0.0	1.0	14.3	376.2	0.00	1.00
09/04/2026 09:00	0.9	0.8	0.0	1.0	14.3	375.9	0.00	1.00
09/04/2026 10:00	0.9	0.8	0.0	1.0	14.4	409.3	0.00	1.00
09/04/2026 11:00	0.9	0.8	0.0	1.0	14.3	375.0	0.00	1.00
09/04/2026 12:00	0.9	0.8	0.0	1.0	14.4	374.9	0.00	1.00
09/04/2026 13:00	0.9	0.8	0.0	1.0	14.4	375.0	0.00	1.00
09/04/2026 14:00	0.9	0.8	0.0	1.0	14.4	374.5	0.00	1.00
09/04/2026 15:00	0.9	0.8	0.0	1.0	14.4	374.3	0.00	1.00
09/04/2026 16:00	0.9	0.8	0.0	1.0	14.4	390.5	0.00	1.00
09/04/2026 17:00	0.9	0.8	0.0	1.0	14.5	407.3	0.00	1.00
09/04/2026 18:00	0.8	0.8	0.0	0.9	14.5	457.5	0.00	1.00
09/04/2026 19:00	0.8	0.9	0.0	0.9	14.5	456.3	0.00	1.00
09/04/2026 20:00	0.8	0.9	0.0	0.9	14.5	456.6	0.00	1.00
09/04/2026 21:00	0.8	0.9	0.0	0.9	14.5	457.9	0.00	1.00
09/04/2026 22:00	0.8	0.9	0.0	0.9	14.4	456.4	0.00	1.00
09/04/2026 23:00	1.0	0.9	0.0	1.1	14.3	384.4	0.00	1.00
Average/Sum#:	0.9	0.8	0.0	1.0	14.4	402.8	0.00 #	24.00 #
Minimum:	0.8	0.7	0.0	0.9	14.2	374.3	0.00	1.00
Maximum:	1.0	0.9	0.0	1.1	14.5	457.9	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/05/2026 00:00	1.0	0.8	0.0	1.1	14.3	396.3	0.00	1.00
09/05/2026 01:00	1.0	0.8	0.0	1.1	14.3	393.9	0.00	1.00
09/05/2026 02:00	0.9	0.8	0.0	1.0	14.3	405.1	0.00	1.00
09/05/2026 03:00	1.0	0.8	0.0	1.1	14.2	377.6	0.00	1.00
09/05/2026 04:00	0.9	0.8	0.0	1.0	14.3	432.5	0.00	1.00
09/05/2026 05:00	0.8	0.9	0.0	0.9	14.4	456.3	0.00	1.00
09/05/2026 06:00	1.0	0.9	0.0	1.1	14.2	376.5	0.00	1.00
09/05/2026 07:00	1.0	0.8	0.0	1.1	14.3	376.4	0.00	1.00
09/05/2026 08:00	0.9	0.8	0.0	1.0	14.3	375.8	0.00	1.00
09/05/2026 09:00	0.9	0.8	0.0	1.0	14.3	375.7	0.00	1.00
09/05/2026 10:00	0.9	0.8	0.0	1.0	14.4	375.1	0.00	1.00
09/05/2026 11:00	0.9	0.8	0.0	1.0	14.4	374.4	0.00	1.00
09/05/2026 12:00	0.9	0.8	0.0	1.0	14.4	374.2	0.00	1.00
09/05/2026 13:00	0.9	0.8	0.0	1.0	14.4	374.2	0.00	1.00
09/05/2026 14:00	0.9	0.8	0.0	1.0	14.4	374.6	0.00	1.00
09/05/2026 15:00	0.9	0.8	0.0	1.0	14.4	374.5	0.00	1.00
09/05/2026 16:00	0.9	0.8	0.0	1.0	14.4	374.2	0.00	1.00
09/05/2026 17:00	0.9	0.8	0.0	1.0	14.4	406.4	0.00	1.00
09/05/2026 18:00	0.9	0.8	0.0	1.0	14.4	384.9	0.00	1.00
09/05/2026 19:00	0.9	0.8	0.0	1.0	14.4	391.0	0.00	1.00
09/05/2026 20:00	0.9	0.8	0.0	1.0	14.4	376.7	0.00	1.00
09/05/2026 21:00	0.9	0.8	0.0	1.0	14.4	391.3	0.00	1.00
09/05/2026 22:00	0.9	0.8	0.0	1.0	14.4	394.1	0.00	1.00
09/05/2026 23:00	1.0	0.8	0.0	1.1	14.3	388.0	0.00	1.00
Average/Sum#:	0.9	0.8	0.0	1.0	14.4	388.3	0.00 #	24.00 #
Minimum:	0.8	0.8	0.0	0.9	14.2	374.2	0.00	1.00
Maximum:	1.0	0.9	0.0	1.1	14.4	456.3	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/06/2026 00:00	1.0	0.8	0.0	1.1	14.3	376.2	0.00	1.00
09/06/2026 01:00	1.0	0.8	0.0	1.1	14.3	379.8	0.00	1.00
09/06/2026 02:00	1.0	0.8	0.0	1.1	14.3	392.0	0.00	1.00
09/06/2026 03:00	1.0	0.8	0.0	1.1	14.3	375.9	0.00	1.00
09/06/2026 04:00	1.0	0.8	0.0	1.1	14.3	380.2	0.00	1.00
09/06/2026 05:00	1.0	0.8	0.0	1.1	14.2	377.0	0.00	1.00
09/06/2026 06:00	0.9	0.8	0.0	1.0	14.3	410.9	0.00	1.00
09/06/2026 07:00	1.0	0.8	0.0	1.1	14.3	376.0	0.00	1.00
09/06/2026 08:00	1.0	0.8	0.0	1.1	14.3	375.6	0.00	1.00
09/06/2026 09:00	1.0	0.8	0.0	1.1	14.3	375.2	0.00	1.00
09/06/2026 10:00	0.9	0.8	0.0	1.0	14.4	375.0	0.00	1.00
09/06/2026 11:00	0.9	0.8	0.0	1.0	14.4	374.1	0.00	1.00
09/06/2026 12:00	0.9	0.8	0.0	1.0	14.4	373.3	0.00	1.00
09/06/2026 13:00	0.9	0.8	0.0	1.0	14.4	373.5	0.00	1.00
09/06/2026 14:00	0.9	0.8	0.0	1.0	14.5	374.5	0.00	1.00
09/06/2026 15:00	0.9	0.8	0.0	1.0	14.6	410.3	0.00	1.00
09/06/2026 16:00	0.9	0.8	0.0	1.0	14.5	396.2	0.00	1.00
09/06/2026 17:00	0.9	0.8	0.0	1.0	14.4	373.4	0.00	1.00
09/06/2026 18:00	0.9	0.8	0.0	1.0	14.4	374.1	0.00	1.00
09/06/2026 19:00	0.9	0.8	0.0	1.0	14.4	374.5	0.00	1.00
09/06/2026 20:00	1.0	0.8	0.0	1.1	14.3	374.9	0.00	1.00
09/06/2026 21:00	1.0	0.8	0.0	1.1	14.3	375.4	0.00	1.00
09/06/2026 22:00	1.0	0.8	0.0	1.1	14.3	376.0	0.00	1.00
09/06/2026 23:00	0.9	0.8	0.0	1.0	14.4	403.9	0.00	1.00
Average/Sum#:	1.0	0.8	0.0	1.1	14.4	381.2	0.00 #	24.00 #
Minimum:	0.9	0.8	0.0	1.0	14.2	373.3	0.00	1.00
Maximum:	1.0	0.8	0.0	1.1	14.6	410.9	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/07/2026 00:00	1.0	0.8	0.0	1.1	14.3	375.7	0.00	1.00
09/07/2026 01:00	1.0	0.8	0.0	1.1	14.3	376.4	0.00	1.00
09/07/2026 02:00	1.0	0.8	0.0	1.1	14.3	376.5	0.00	1.00
09/07/2026 03:00	1.1	0.8	0.0	1.2	14.3	376.5	0.00	1.00
09/07/2026 04:00	1.1	0.9	0.0	1.2	14.3	376.6	0.00	1.00
09/07/2026 05:00	1.1	0.9	0.0	1.2	14.3	377.5	0.00	1.00
09/07/2026 06:00	1.1	0.9	0.0	1.2	14.3	397.7	0.00	1.00
09/07/2026 07:00	1.1	0.9	0.0	1.2	14.3	376.8	0.00	1.00
09/07/2026 08:00	1.0	0.9	0.0	1.1	14.3	376.3	0.00	1.00
09/07/2026 09:00	1.0	0.8	0.0	1.1	14.4	375.4	0.00	1.00
09/07/2026 10:00	0.9	0.8	0.0	1.0	14.4	374.9	0.00	1.00
09/07/2026 11:00	0.9	0.8	0.0	1.0	14.4	374.3	0.00	1.00
09/07/2026 12:00	0.9	0.8	0.0	1.0	14.4	373.8	0.00	1.00
09/07/2026 13:00	0.9	0.8	0.0	1.0	14.5	373.6	0.00	1.00
09/07/2026 14:00	0.9	0.8	0.0	1.0	14.5	375.2	0.00	1.00
09/07/2026 15:00	0.9	0.8	0.0	1.0	14.5	372.4	0.00	1.00
09/07/2026 16:00	0.8	0.8	0.0	0.9	14.5	409.5	0.00	1.00
09/07/2026 17:00	0.9	0.8	0.0	1.0	14.4	401.5	0.00	1.00
09/07/2026 18:00	0.9	0.8	0.0	1.0	14.5	400.4	0.00	1.00
09/07/2026 19:00	0.9	0.8	0.0	0.9	14.6	451.4	0.00	1.00
09/07/2026 20:00	0.9	0.9	0.0	1.0	14.6	453.6	0.00	1.00
09/07/2026 21:00	0.9	1.0	0.0	1.0	14.6	453.1	0.00	1.00
09/07/2026 22:00	1.0	1.0	0.0	1.1	14.5	452.5	0.00	1.00
09/07/2026 23:00	1.0	1.0	0.0	1.1	14.5	453.5	0.00	1.00
Average/Sum#:	1.0	0.9	0.0	1.1	14.4	396.0	0.00 #	24.00 #
Minimum:	0.8	0.8	0.0	0.9	14.3	372.4	0.00	1.00
Maximum:	1.1	1.0	0.0	1.2	14.6	453.6	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/08/2026 00:00	1.0	1.0	0.0	1.1	14.5	453.2	0.00	1.00
09/08/2026 01:00	1.2	1.1	0.0	1.3	14.4	417.2	0.00	1.00
09/08/2026 02:00	1.1	1.0	0.0	1.2	14.3	372.4	0.00	1.00
09/08/2026 03:00	1.1	1.0	0.0	1.2	14.3	386.0	0.00	1.00
09/08/2026 04:00	1.2	1.0	0.0	1.4	14.4	442.4	0.00	1.00
09/08/2026 05:00	1.1	1.1	0.0	1.2	14.4	453.5	0.00	1.00
09/08/2026 06:00	1.1	1.1	0.0	1.3	14.3	402.0	0.00	1.00
09/08/2026 07:00	1.2	1.0	0.0	1.3	14.3	372.8	0.00	1.00
09/08/2026 08:00	1.0	0.9	0.0	1.1	14.4	372.5	0.00	1.00
09/08/2026 09:00	1.0	0.9	0.0	1.1	14.4	372.4	0.00	1.00
09/08/2026 10:00	1.0	0.8	0.0	1.1	14.4	371.4	0.00	1.00
09/08/2026 11:00	1.0	0.8	0.0	1.1	14.4	370.7	0.00	1.00
09/08/2026 12:00	1.0	0.8	0.0	1.1	14.5	381.7	0.00	1.00
09/08/2026 13:00	0.8	0.8	0.0	0.9	14.5	454.6	0.00	1.00
09/08/2026 14:00	0.5	0.8	0.0	0.7	12.8	604.0	0.00	1.00
09/08/2026 15:00	0.3	0.7	0.0	0.4	12.4	633.5	0.00	1.00
09/08/2026 16:00	0.3	0.5	0.0	0.4	12.3	640.4	0.00	1.00
09/08/2026 17:00	0.2	0.4	0.0	0.3	12.2	651.0	0.00	1.00
09/08/2026 18:00	0.3	0.4	0.0	0.4	12.3	649.3	0.00	1.00
09/08/2026 19:00	0.3	0.4	0.0	0.4	12.3	647.4	0.00	1.00
09/08/2026 20:00	0.5	0.5	0.0	0.7	12.5	633.8	0.00	1.00
09/08/2026 21:00	0.3	0.5	0.0	0.4	12.4	630.4	0.00	1.00
09/08/2026 22:00	0.6	0.6	0.0	0.8	13.1	580.8	0.00	1.00
09/08/2026 23:00	1.0	0.7	0.0	1.1	14.5	445.2	0.00	1.00
Average/Sum#:	0.8	0.8	0.0	0.9	13.7	489.1	0.00 #	24.00 #
Minimum:	0.2	0.4	0.0	0.3	12.2	370.7	0.00	1.00
Maximum:	1.2	1.1	0.0	1.4	14.5	651.0	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/09/2026 00:00	1.0	0.9	0.0	1.1	14.4	427.3	0.00	1.00
09/09/2026 01:00	1.1	1.0	0.0	1.2	14.3	394.1	0.00	1.00
09/09/2026 02:00	1.1	0.9	0.0	1.3	14.3	373.7	0.00	1.00
09/09/2026 03:00	1.1	0.9	0.0	1.2	14.3	374.2	0.00	1.00
09/09/2026 04:00	1.2	0.9	0.0	1.3	14.3	389.8	0.00	1.00
09/09/2026 05:00	1.6	1.3	0.0	1.9	14.2	504.5	0.00	1.00
09/09/2026 06:00	1.3	1.5	0.0	1.6	13.9	531.4	0.00	1.00
09/09/2026 07:00	0.7	1.5	0.0	0.9	13.3	581.9	0.00	1.00
09/09/2026 08:00	0.4	1.0	0.0	0.5	12.6	630.1	0.00	1.00
09/09/2026 09:00	0.3	0.6	0.0	0.4	12.4	636.5	0.00	1.00
09/09/2026 10:00	0.2	0.4	0.0	0.3	12.2	626.5	0.00	1.00
09/09/2026 11:00	0.3	0.4	0.0	0.4	12.4	627.0	0.00	1.00
09/09/2026 12:00	0.3	0.4	0.0	0.4	12.6	619.0	0.00	1.00
09/09/2026 13:00	0.2	0.4	0.0	0.3	12.4	638.6	0.00	1.00
09/09/2026 14:00	0.2	0.3	0.0	0.3	12.3	640.6	0.00	1.00
09/09/2026 15:00	0.2	0.3	0.0	0.3	12.1	655.9	0.00	1.00
09/09/2026 16:00	0.3	0.3	0.0	0.4	12.1	654.4	0.00	1.00
09/09/2026 17:00	0.2	0.3	0.0	0.3	12.3	636.8	0.00	1.00
09/09/2026 18:00	0.3	0.3	0.0	0.4	12.1	652.2	0.00	1.00
09/09/2026 19:00	0.3	0.4	0.0	0.4	12.6	619.8	0.00	1.00
09/09/2026 20:00	0.3	0.4	0.0	0.4	12.2	651.8	0.00	1.00
09/09/2026 21:00	0.3	0.4	0.0	0.4	12.2	651.7	0.00	1.00
09/09/2026 22:00	0.4	0.4	0.0	0.6	12.6	624.4	0.00	1.00
09/09/2026 23:00	1.0	0.6	0.0	1.1	14.6	456.8	0.00	1.00
Average/Sum#:	0.6	0.7	0.0	0.7	13.0	566.6	0.00 #	24.00 #
Minimum:	0.2	0.3	0.0	0.3	12.1	373.7	0.00	1.00
Maximum:	1.6	1.5	0.0	1.9	14.6	655.9	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/10/2026 00:00	0.9	0.8	0.0	1.0	14.6	456.5	0.00	1.00
09/10/2026 01:00	0.9	0.9	0.0	0.9	14.6	454.1	0.00	1.00
09/10/2026 02:00	0.9	0.9	0.0	1.0	14.6	445.0	0.00	1.00
09/10/2026 03:00	1.0	0.9	0.0	1.1	14.4	374.1	0.00	1.00
09/10/2026 04:00	1.0	0.8	0.0	1.1	14.4	381.7	0.00	1.00
09/10/2026 05:00	0.8	0.8	0.0	0.9	14.6	449.4	0.00	1.00
09/10/2026 06:00	0.9	0.9	0.0	1.0	14.5	403.5	0.00	1.00
09/10/2026 07:00	1.0	0.9	0.0	1.1	14.4	370.8	0.00	1.00
09/10/2026 08:00	1.0	0.8	0.0	1.1	14.4	370.3	0.00	1.00
09/10/2026 09:00	0.9	0.8	0.0	1.0	14.5	370.2	0.00	1.00
09/10/2026 10:00	0.9	0.8	0.0	1.0	14.5	369.2	0.00	1.00
09/10/2026 11:00	0.9	0.8	0.0	1.0	14.5	397.0	0.00	1.00
09/10/2026 12:00	1.1	0.9	0.0	1.3	13.8	520.0	0.00	1.00
09/10/2026 13:00	0.9	1.0	0.0	1.1	13.7	525.2	0.00	1.00
09/10/2026 14:00	0.8	1.1	0.0	1.0	13.6	530.3	0.00	1.00
09/10/2026 15:00	0.8	1.0	0.0	1.0	13.6	533.1	0.00	1.00
09/10/2026 16:00	0.6	0.9	0.0	0.8	13.2	564.1	0.00	1.00
09/10/2026 17:00	0.4	0.7	0.0	0.6	12.8	593.2	0.00	1.00
09/10/2026 18:00	0.9	0.8	0.0	1.1	13.7	528.0	0.00	1.00
09/10/2026 19:00	1.1	1.0	0.0	1.3	13.9	522.2	0.00	1.00
09/10/2026 20:00	1.2	1.3	0.0	1.4	13.9	522.1	0.00	1.00
09/10/2026 21:00	0.8	1.2	0.0	1.0	13.7	527.0	0.00	1.00
09/10/2026 22:00	0.9	1.1	0.0	1.1	13.8	523.5	0.00	1.00
09/10/2026 23:00	1.0	0.9	0.0	1.1	14.4	380.5	0.00	1.00
Average/Sum#:	0.9	0.9	0.0	1.0	14.1	463.0	0.00 #	24.00 #
Minimum:	0.4	0.7	0.0	0.6	12.8	369.2	0.00	1.00
Maximum:	1.2	1.3	0.0	1.4	14.6	593.2	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/11/2026 00:00	1.0	0.9	0.0	1.1	14.4	372.2	0.00	1.00
09/11/2026 01:00	1.0	0.8	0.0	1.1	14.4	372.8	0.00	1.00
09/11/2026 02:00	1.0	0.8	0.0	1.1	14.4	372.7	0.00	1.00
09/11/2026 03:00	1.0	0.8	0.0	1.1	14.3	372.8	0.00	1.00
09/11/2026 04:00	1.0	0.8	0.0	1.1	14.3	373.2	0.00	1.00
09/11/2026 05:00	1.0	0.8	0.0	1.1	14.3	373.6	0.00	1.00
09/11/2026 06:00	1.0	0.8	0.0	1.1	14.3	373.8	0.00	1.00
09/11/2026 07:00	1.0	0.8	0.0	1.1	14.3	373.4	0.00	1.00
09/11/2026 08:00	1.0	0.8	0.0	1.1	14.3	373.0	0.00	1.00
09/11/2026 09:00	1.0	0.8	0.0	1.1	14.3	372.6	0.00	1.00
09/11/2026 10:00	1.0	0.8	0.0	1.1	14.4	372.2	0.00	1.00
09/11/2026 11:00	1.0	0.8	0.0	1.1	14.4	371.7	0.00	1.00
09/11/2026 12:00	1.0	0.8	0.0	1.1	14.4	371.4	0.00	1.00
09/11/2026 13:00	1.0	0.8	0.0	1.1	14.5	371.1	0.00	1.00
09/11/2026 14:00	1.0	0.8	0.0	1.1	14.5	371.3	0.00	1.00
09/11/2026 15:00	0.8	0.8	0.0	0.9	14.5	436.5	0.00	1.00
09/11/2026 16:00	0.9	0.8	0.0	1.0	14.4	406.2	0.00	1.00
09/11/2026 17:00	0.9	0.8	0.0	1.0	14.3	403.6	0.00	1.00
09/11/2026 18:00	1.0	0.8	0.0	1.1	14.3	373.4	0.00	1.00
09/11/2026 19:00	1.0	0.8	0.0	1.1	14.2	373.7	0.00	1.00
09/11/2026 20:00	1.0	0.8	0.0	1.1	14.3	373.4	0.00	1.00
09/11/2026 21:00	1.0	0.8	0.0	1.1	14.3	372.7	0.00	1.00
09/11/2026 22:00	1.0	0.8	0.0	1.1	14.3	372.9	0.00	1.00
09/11/2026 23:00	1.0	0.8	0.0	1.1	14.3	372.6	0.00	1.00
Average/Sum#:	1.0	0.8	0.0	1.1	14.4	378.0	0.00 #	24.00 #
Minimum:	0.8	0.8	0.0	0.9	14.2	371.1	0.00	1.00
Maximum:	1.0	0.9	0.0	1.1	14.5	436.5	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/12/2026 00:00	1.0	0.8	0.0	1.1	14.3	372.8	0.00	1.00
09/12/2026 01:00	1.0	0.8	0.0	1.1	14.3	372.7	0.00	1.00
09/12/2026 02:00	1.0	0.8	0.0	1.1	14.3	372.9	0.00	1.00
09/12/2026 03:00	1.1	0.8	0.0	1.2	14.3	373.1	0.00	1.00
09/12/2026 04:00	1.1	0.9	0.0	1.2	14.3	372.9	0.00	1.00
09/12/2026 05:00	1.0	0.9	0.0	1.1	14.3	373.2	0.00	1.00
09/12/2026 06:00	1.0	0.8	0.0	1.1	14.3	373.3	0.00	1.00
09/12/2026 07:00	1.0	0.8	0.0	1.1	14.3	373.3	0.00	1.00
09/12/2026 08:00	1.0	0.8	0.0	1.1	14.3	372.7	0.00	1.00
09/12/2026 09:00	1.0	0.8	0.0	1.1	14.4	372.3	0.00	1.00
09/12/2026 10:00	1.0	0.8	0.0	1.1	14.4	371.6	0.00	1.00
09/12/2026 11:00	1.0	0.8	0.0	1.1	14.4	370.8	0.00	1.00
09/12/2026 12:00	1.0	0.8	0.0	1.1	14.4	370.6	0.00	1.00
09/12/2026 13:00	0.9	0.8	0.0	1.0	14.5	370.2	0.00	1.00
09/12/2026 14:00	0.9	0.8	0.0	1.0	14.5	369.9	0.00	1.00
09/12/2026 15:00	0.9	0.8	0.0	1.0	14.5	370.1	0.00	1.00
09/12/2026 16:00	0.9	0.8	0.0	1.0	14.5	392.6	0.00	1.00
09/12/2026 17:00	0.9	0.8	0.0	1.0	14.4	374.1	0.00	1.00
09/12/2026 18:00	1.0	0.8	0.0	1.1	14.4	371.7	0.00	1.00
09/12/2026 19:00	1.0	0.8	0.0	1.1	14.3	372.4	0.00	1.00
09/12/2026 20:00	1.0	0.8	0.0	1.1	14.3	372.6	0.00	1.00
09/12/2026 21:00	1.0	0.8	0.0	1.1	14.3	373.2	0.00	1.00
09/12/2026 22:00	1.0	0.8	0.0	1.1	14.3	377.1	0.00	1.00
09/12/2026 23:00	1.0	0.8	0.0	1.1	14.3	373.8	0.00	1.00
Average/Sum#:	1.0	0.8	0.0	1.1	14.4	373.3	0.00 #	24.00 #
Minimum:	0.9	0.8	0.0	1.0	14.3	369.9	0.00	1.00
Maximum:	1.1	0.9	0.0	1.2	14.5	392.6	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/13/2026 00:00	1.0	0.8	0.0	1.1	14.3	374.2	0.00	1.00
09/13/2026 01:00	1.0	0.8	0.0	1.1	14.3	374.5	0.00	1.00
09/13/2026 02:00	1.0	0.8	0.0	1.1	14.3	374.8	0.00	1.00
09/13/2026 03:00	1.1	0.8	0.0	1.2	14.3	374.9	0.00	1.00
09/13/2026 04:00	1.1	0.9	0.0	1.2	14.3	375.1	0.00	1.00
09/13/2026 05:00	1.0	0.9	0.0	1.1	14.3	427.5	0.00	1.00
09/13/2026 06:00	1.0	0.9	0.0	1.1	14.3	397.1	0.00	1.00
09/13/2026 07:00	1.1	0.9	0.0	1.2	14.3	374.5	0.00	1.00
09/13/2026 08:00	1.0	0.9	0.0	1.1	14.3	374.4	0.00	1.00
09/13/2026 09:00	1.0	0.9	0.0	1.1	14.3	374.2	0.00	1.00
09/13/2026 10:00	1.0	0.8	0.0	1.1	14.3	373.9	0.00	1.00
09/13/2026 11:00	1.0	0.8	0.0	1.1	14.3	373.5	0.00	1.00
09/13/2026 12:00	1.0	0.8	0.0	1.1	14.4	373.0	0.00	1.00
09/13/2026 13:00	1.0	0.8	0.0	1.1	14.4	373.0	0.00	1.00
09/13/2026 14:00	1.0	0.8	0.0	1.1	14.4	372.6	0.00	1.00
09/13/2026 15:00	1.0	0.8	0.0	1.1	14.4	372.4	0.00	1.00
09/13/2026 16:00	1.0	0.8	0.0	1.1	14.5	397.8	0.00	1.00
09/13/2026 17:00	0.9	0.9	0.0	1.0	14.6	432.9	0.00	1.00
09/13/2026 18:00	1.0	0.9	0.0	1.1	14.4	375.6	0.00	1.00
09/13/2026 19:00	1.0	0.8	0.0	1.1	14.4	373.0	0.00	1.00
09/13/2026 20:00	1.0	0.8	0.0	1.1	14.4	373.7	0.00	1.00
09/13/2026 21:00	1.1	0.9	0.0	1.2	14.3	373.6	0.00	1.00
09/13/2026 22:00	1.0	0.9	0.0	1.1	14.3	374.1	0.00	1.00
09/13/2026 23:00	1.1	0.9	0.0	1.2	14.3	374.4	0.00	1.00
Average/Sum#:	1.0	0.8	0.0	1.1	14.4	380.6	0.00 #	24.00 #
Minimum:	0.9	0.8	0.0	1.0	14.3	372.4	0.00	1.00
Maximum:	1.1	0.9	0.0	1.2	14.6	432.9	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/14/2026 00:00	1.1	0.9	0.0	1.3	14.3	374.6	0.00	1.00
09/14/2026 01:00	1.1	0.9	0.0	1.2	14.3	374.6	0.00	1.00
09/14/2026 02:00	1.1	0.9	0.0	1.2	14.3	374.5	0.00	1.00
09/14/2026 03:00	1.1	0.9	0.0	1.2	14.2	374.9	0.00	1.00
09/14/2026 04:00	1.1	0.9	0.0	1.3	14.2	375.0	0.00	1.00
09/14/2026 05:00	1.1	1.0	0.0	1.3	14.2	379.9	0.00	1.00
09/14/2026 06:00	1.1	1.0	0.0	1.3	14.2	392.7	0.00	1.00
09/14/2026 07:00	1.1	1.0	0.0	1.2	14.2	374.7	0.00	1.00
09/14/2026 08:00	1.1	0.9	0.0	1.2	14.3	373.8	0.00	1.00
09/14/2026 09:00	1.1	0.9	0.0	1.2	14.3	373.4	0.00	1.00
09/14/2026 10:00	1.0	0.9	0.0	1.1	14.4	372.9	0.00	1.00
09/14/2026 11:00	1.0	0.8	0.0	1.1	14.4	372.3	0.00	1.00
09/14/2026 12:00	1.0	0.8	0.0	1.1	14.4	372.3	0.00	1.00
09/14/2026 13:00	1.0	0.8	0.0	1.1	14.4	371.9	0.00	1.00
09/14/2026 14:00	1.0	0.8	0.0	1.1	14.5	371.6	0.00	1.00
09/14/2026 15:00	1.0	0.8	0.0	1.1	14.4	371.6	0.00	1.00
09/14/2026 16:00	1.0	0.8	0.0	1.1	14.5	391.0	0.00	1.00
09/14/2026 17:00	1.0	0.9	0.0	1.1	14.5	405.2	0.00	1.00
09/14/2026 18:00	1.0	0.9	0.0	1.1	14.4	372.5	0.00	1.00
09/14/2026 19:00	1.0	0.9	0.0	1.1	14.4	382.9	0.00	1.00
09/14/2026 20:00	1.1	0.9	0.0	1.2	14.4	375.0	0.00	1.00
09/14/2026 21:00	1.1	0.9	0.0	1.2	14.4	372.9	0.00	1.00
09/14/2026 22:00	1.1	0.9	0.0	1.2	14.3	374.7	0.00	1.00
09/14/2026 23:00	1.0	0.9	0.0	1.1	14.4	433.6	0.00	1.00
Average/Sum#:	1.1	0.9	0.0	1.2	14.3	379.5	0.00 #	24.00 #
Minimum:	1.0	0.8	0.0	1.1	14.2	371.6	0.00	1.00
Maximum:	1.1	1.0	0.0	1.3	14.5	433.6	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/15/2026 00:00	1.0	0.9	0.0	1.1	14.4	401.1	0.00	1.00
09/15/2026 01:00	1.1	0.9	0.0	1.2	14.3	380.3	0.00	1.00
09/15/2026 02:00	1.1	0.9	0.0	1.2	14.3	374.8	0.00	1.00
09/15/2026 03:00	1.1	0.9	0.0	1.2	14.3	374.7	0.00	1.00
09/15/2026 04:00	1.1	0.9	0.0	1.2	14.3	387.0	0.00	1.00
09/15/2026 05:00	0.9	0.9	0.0	1.0	14.4	455.8	0.00	1.00
09/15/2026 06:00	1.0	1.0	0.0	1.1	14.4	455.7	0.00	1.00
09/15/2026 07:00	1.0	1.0	0.0	1.1	14.4	446.7	0.00	1.00
09/15/2026 08:00	0.9	1.0	0.0	1.0	14.5	456.3	0.00	1.00
09/15/2026 09:00	0.9	0.9	0.0	1.0	14.5	455.3	0.00	1.00
09/15/2026 10:00	0.9	0.9	0.0	1.0	14.5	433.7	0.00	1.00
09/15/2026 11:00	0.9	0.9	0.0	0.9	14.6	456.0	0.00	1.00
09/15/2026 12:00	0.8	0.9	0.0	0.9	14.6	443.6	0.00	1.00
09/15/2026 13:00	0.9	0.9	0.0	0.9	14.6	443.9	0.00	1.00
09/15/2026 14:00	0.9	0.9	0.0	1.0	14.6	443.4	0.00	1.00
09/15/2026 15:00	0.9	0.9	0.0	1.0	14.6	440.3	0.00	1.00
09/15/2026 16:00	0.9	0.9	0.0	1.0	14.5	392.1	0.00	1.00
09/15/2026 17:00	0.9	0.8	0.0	1.0	14.4	376.0	0.00	1.00
09/15/2026 18:00	1.0	0.8	0.0	1.1	14.4	373.9	0.00	1.00
09/15/2026 19:00	1.0	0.8	0.0	1.1	14.4	374.3	0.00	1.00
09/15/2026 20:00	1.0	0.8	0.0	1.1	14.3	375.2	0.00	1.00
09/15/2026 21:00	1.0	0.8	0.0	1.1	14.3	375.7	0.00	1.00
09/15/2026 22:00	1.0	0.8	0.0	1.1	14.3	375.8	0.00	1.00
09/15/2026 23:00	1.0	0.8	0.0	1.1	14.3	376.1	0.00	1.00
Average/Sum#:	1.0	0.9	0.0	1.1	14.4	411.2	0.00 #	24.00 #
Minimum:	0.8	0.8	0.0	0.9	14.3	373.9	0.00	1.00
Maximum:	1.1	1.0	0.0	1.2	14.6	456.3	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/16/2026 00:00	1.0	0.8	0.0	1.1	14.2	376.3	0.00	1.00
09/16/2026 01:00	1.0	0.8	0.0	1.1	14.2	376.6	0.00	1.00
09/16/2026 02:00	1.0	0.8	0.0	1.1	14.2	376.9	0.00	1.00
09/16/2026 03:00	1.1	0.8	0.0	1.2	14.2	377.3	0.00	1.00
09/16/2026 04:00	1.0	0.8	0.0	1.1	14.2	377.7	0.00	1.00
09/16/2026 05:00	1.1	0.9	0.0	1.2	14.2	378.3	0.00	1.00
09/16/2026 06:00	1.0	0.9	0.0	1.1	14.2	385.2	0.00	1.00
09/16/2026 07:00	0.0	0.0	0.0	0.0	0.0	372.7	0.02	0.30
09/16/2026 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2026 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2026 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2026 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2026 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2026 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2026 14:00	0.0	0.0	3.0	115.6	20.2	21.7	0.07	0.07
09/16/2026 15:00	0.6	0.0	40.7	59.3	15.4	323.8	0.93	0.97
09/16/2026 16:00	0.6	0.0	0.0	0.7	14.4	376.1	0.00	1.00
09/16/2026 17:00	0.6	0.5	0.0	0.7	14.3	375.8	0.00	1.00
09/16/2026 18:00	0.6	0.5	0.0	0.7	14.3	376.4	0.00	1.00
09/16/2026 19:00	0.6	0.5	0.0	0.7	14.3	376.8	0.00	1.00
09/16/2026 20:00	0.6	0.5	0.0	0.7	14.3	377.2	0.00	1.00
09/16/2026 21:00	0.6	0.5	0.0	0.7	14.3	377.5	0.00	1.00
09/16/2026 22:00	0.6	0.5	0.0	0.7	14.3	377.8	0.00	1.00
09/16/2026 23:00	0.6	0.5	0.0	0.7	14.3	377.7	0.00	1.00
Average/Sum#:	0.7	0.7	2.0	11.1	14.7	354.5	1.02 #	16.34 #
Minimum:	0.0	0.5	0.0	0.7	14.2	21.7	0.00	0.00
Maximum:	1.1	0.9	40.7	115.6	20.2	385.2	0.93	1.00
%SI	29.17	41.67	8.33	29.17	29.17	25.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/17/2026 00:00	0.6	0.5	0.0	0.7	14.3	377.8	0.00	1.00
09/17/2026 01:00	0.6	0.5	0.0	0.7	14.3	377.9	0.00	1.00
09/17/2026 02:00	0.7	0.5	0.0	0.8	14.3	378.3	0.00	1.00
09/17/2026 03:00	0.7	0.6	0.0	0.8	14.3	378.3	0.00	1.00
09/17/2026 04:00	0.7	0.6	0.0	0.8	14.3	378.1	0.00	1.00
09/17/2026 05:00	0.6	0.6	0.0	0.7	14.3	417.9	0.00	1.00
09/17/2026 06:00	0.6	0.6	0.0	0.7	14.3	414.7	0.00	1.00
09/17/2026 07:00	0.6	0.6	0.0	0.7	14.3	377.7	0.00	1.00
09/17/2026 08:00	0.6	0.5	0.0	0.7	14.3	377.6	0.00	1.00
09/17/2026 09:00	0.6	0.5	0.0	0.7	14.3	377.7	0.00	1.00
09/17/2026 10:00	0.6	0.5	0.0	0.7	14.3	377.3	0.00	1.00
09/17/2026 11:00	0.6	0.5	0.0	0.7	14.3	376.8	0.00	1.00
09/17/2026 12:00	0.6	0.5	0.0	0.7	14.4	376.5	0.00	1.00
09/17/2026 13:00	0.6	0.5	0.0	0.7	14.4	376.5	0.00	1.00
09/17/2026 14:00	0.6	0.5	0.0	0.7	14.4	376.2	0.00	1.00
09/17/2026 15:00	0.6	0.5	0.0	0.7	14.4	376.2	0.00	1.00
09/17/2026 16:00	0.6	0.5	0.0	0.7	14.4	392.0	0.00	1.00
09/17/2026 17:00	0.6	0.5	0.0	0.7	14.4	376.2	0.00	1.00
09/17/2026 18:00	0.6	0.5	0.0	0.7	14.3	376.4	0.00	1.00
09/17/2026 19:00	0.6	0.5	0.0	0.7	14.3	376.6	0.00	1.00
09/17/2026 20:00	0.6	0.5	0.0	0.7	14.3	377.0	0.00	1.00
09/17/2026 21:00	0.7	0.6	0.0	0.8	14.3	377.2	0.00	1.00
09/17/2026 22:00	0.7	0.6	0.0	0.8	14.3	377.1	0.00	1.00
09/17/2026 23:00	0.7	0.6	0.0	0.8	14.3	377.3	0.00	1.00
Average/Sum#:	0.6	0.5	0.0	0.7	14.3	381.1	0.00 #	24.00 #
Minimum:	0.6	0.5	0.0	0.7	14.3	376.2	0.00	1.00
Maximum:	0.7	0.6	0.0	0.8	14.4	417.9	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/18/2026 00:00	0.7	0.6	0.0	0.8	14.3	377.5	0.00	1.00
09/18/2026 01:00	0.7	0.6	0.0	0.8	14.3	377.7	0.00	1.00
09/18/2026 02:00	0.7	0.6	0.0	0.8	14.3	377.7	0.00	1.00
09/18/2026 03:00	0.7	0.6	0.0	0.8	14.3	377.9	0.00	1.00
09/18/2026 04:00	0.7	0.6	0.0	0.8	14.3	378.2	0.00	1.00
09/18/2026 05:00	0.7	0.6	0.0	0.8	14.3	378.2	0.00	1.00
09/18/2026 06:00	0.7	0.6	0.0	0.8	14.3	416.6	0.00	1.00
09/18/2026 07:00	0.7	0.6	0.0	0.8	14.3	380.0	0.00	1.00
09/18/2026 08:00	0.7	0.6	0.0	0.8	14.3	377.5	0.00	1.00
09/18/2026 09:00	0.6	0.6	0.0	0.7	14.3	376.9	0.00	1.00
09/18/2026 10:00	0.6	0.5	0.0	0.7	14.4	376.7	0.00	1.00
09/18/2026 11:00	0.6	0.5	0.0	0.7	14.4	376.0	0.00	1.00
09/18/2026 12:00	0.6	0.5	0.0	0.7	14.4	375.7	0.00	1.00
09/18/2026 13:00	0.6	0.5	0.0	0.7	14.4	377.6	0.00	1.00
09/18/2026 14:00	0.6	0.5	0.0	0.7	14.4	374.9	0.00	1.00
09/18/2026 15:00	0.6	0.5	0.0	0.7	14.4	374.9	0.00	1.00
09/18/2026 16:00	0.6	0.5	0.0	0.6	14.5	428.3	0.00	1.00
09/18/2026 17:00	0.6	0.6	0.0	0.6	14.6	456.0	0.00	1.00
09/18/2026 18:00	0.6	0.6	0.0	0.7	14.4	377.0	0.00	1.00
09/18/2026 19:00	0.6	0.5	0.0	0.7	14.4	375.1	0.00	1.00
09/18/2026 20:00	0.6	0.5	0.0	0.7	14.4	375.7	0.00	1.00
09/18/2026 21:00	0.7	0.5	0.0	0.8	14.3	376.2	0.00	1.00
09/18/2026 22:00	0.7	0.6	0.0	0.8	14.3	376.7	0.00	1.00
09/18/2026 23:00	0.7	0.6	0.0	0.8	14.3	376.8	0.00	1.00
Average/Sum#:	0.7	0.6	0.0	0.7	14.4	384.0	0.00 #	24.00 #
Minimum:	0.6	0.5	0.0	0.6	14.3	374.9	0.00	1.00
Maximum:	0.7	0.6	0.0	0.8	14.6	456.0	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/19/2026 00:00	0.7	0.6	0.0	0.8	14.3	377.1	0.00	1.00
09/19/2026 01:00	0.7	0.6	0.0	0.8	14.3	377.3	0.00	1.00
09/19/2026 02:00	0.7	0.6	0.0	0.8	14.3	377.5	0.00	1.00
09/19/2026 03:00	0.7	0.6	0.0	0.8	14.3	377.2	0.00	1.00
09/19/2026 04:00	0.7	0.6	0.0	0.8	14.3	377.4	0.00	1.00
09/19/2026 05:00	0.7	0.6	0.0	0.8	14.3	377.4	0.00	1.00
09/19/2026 06:00	0.7	0.6	0.0	0.8	14.3	377.3	0.00	1.00
09/19/2026 07:00	0.7	0.6	0.0	0.8	14.3	377.3	0.00	1.00
09/19/2026 08:00	0.7	0.6	0.0	0.8	14.3	376.7	0.00	1.00
09/19/2026 09:00	0.6	0.6	0.0	0.7	14.3	376.4	0.00	1.00
09/19/2026 10:00	0.6	0.5	0.0	0.7	14.4	376.0	0.00	1.00
09/19/2026 11:00	0.6	0.5	0.0	0.7	14.4	375.3	0.00	1.00
09/19/2026 12:00	0.6	0.5	0.0	0.7	14.4	375.1	0.00	1.00
09/19/2026 13:00	0.6	0.5	0.0	0.7	14.5	374.9	0.00	1.00
09/19/2026 14:00	0.6	0.5	0.0	0.7	14.5	374.3	0.00	1.00
09/19/2026 15:00	0.6	0.5	0.0	0.7	14.5	374.1	0.00	1.00
09/19/2026 16:00	0.6	0.5	0.0	0.7	14.5	387.1	0.00	1.00
09/19/2026 17:00	0.6	0.5	0.0	0.7	14.5	373.5	0.00	1.00
09/19/2026 18:00	0.6	0.5	0.0	0.7	14.4	374.6	0.00	1.00
09/19/2026 19:00	0.6	0.5	0.0	0.7	14.4	375.4	0.00	1.00
09/19/2026 20:00	0.7	0.5	0.0	0.8	14.4	375.6	0.00	1.00
09/19/2026 21:00	0.7	0.6	0.0	0.8	14.4	381.6	0.00	1.00
09/19/2026 22:00	0.7	0.6	0.0	0.8	14.4	396.8	0.00	1.00
09/19/2026 23:00	0.7	0.6	0.0	0.8	14.4	390.3	0.00	1.00
Average/Sum#:	0.7	0.6	0.0	0.8	14.4	378.2	0.00 #	24.00 #
Minimum:	0.6	0.5	0.0	0.7	14.3	373.5	0.00	1.00
Maximum:	0.7	0.6	0.0	0.8	14.5	396.8	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/20/2026 00:00	0.7	0.6	0.0	0.8	14.3	387.3	0.00	1.00
09/20/2026 01:00	0.7	0.6	0.0	0.8	14.3	376.4	0.00	1.00
09/20/2026 02:00	0.7	0.6	0.0	0.8	14.3	376.6	0.00	1.00
09/20/2026 03:00	0.7	0.6	0.0	0.8	14.3	376.8	0.00	1.00
09/20/2026 04:00	0.7	0.6	0.0	0.8	14.3	377.0	0.00	1.00
09/20/2026 05:00	0.7	0.6	0.0	0.8	14.3	377.5	0.00	1.00
09/20/2026 06:00	0.7	0.6	0.0	0.8	14.3	378.5	0.00	1.00
09/20/2026 07:00	0.7	0.6	0.0	0.8	14.3	377.5	0.00	1.00
09/20/2026 08:00	0.7	0.6	0.0	0.8	14.3	377.1	0.00	1.00
09/20/2026 09:00	0.7	0.6	0.0	0.8	14.3	376.5	0.00	1.00
09/20/2026 10:00	0.6	0.6	0.0	0.7	14.4	375.9	0.00	1.00
09/20/2026 11:00	0.6	0.5	0.0	0.7	14.4	375.8	0.00	1.00
09/20/2026 12:00	0.6	0.5	0.0	0.7	14.4	375.5	0.00	1.00
09/20/2026 13:00	0.6	0.5	0.0	0.6	14.5	415.5	0.00	1.00
09/20/2026 14:00	0.6	0.5	0.0	0.6	14.6	457.3	0.00	1.00
09/20/2026 15:00	0.6	0.6	0.0	0.6	14.6	447.3	0.00	1.00
09/20/2026 16:00	0.6	0.6	0.0	0.6	14.6	432.2	0.00	1.00
09/20/2026 17:00	0.6	0.6	0.0	0.7	14.4	377.4	0.00	1.00
09/20/2026 18:00	0.6	0.5	0.0	0.7	14.4	375.5	0.00	1.00
09/20/2026 19:00	0.7	0.5	0.0	0.8	14.3	376.2	0.00	1.00
09/20/2026 20:00	0.7	0.6	0.0	0.8	14.3	376.3	0.00	1.00
09/20/2026 21:00	0.7	0.6	0.0	0.8	14.3	376.3	0.00	1.00
09/20/2026 22:00	0.7	0.6	0.0	0.8	14.3	376.5	0.00	1.00
09/20/2026 23:00	0.7	0.6	0.0	0.8	14.3	382.9	0.00	1.00
Average/Sum#:	0.7	0.6	0.0	0.7	14.4	387.6	0.00 #	24.00 #
Minimum:	0.6	0.5	0.0	0.6	14.3	375.5	0.00	1.00
Maximum:	0.7	0.6	0.0	0.8	14.6	457.3	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/21/2026 00:00	0.7	0.6	0.0	0.8	14.3	376.3	0.00	1.00
09/21/2026 01:00	0.7	0.6	0.0	0.8	14.3	376.6	0.00	1.00
09/21/2026 02:00	0.7	0.6	0.0	0.8	14.3	376.9	0.00	1.00
09/21/2026 03:00	0.7	0.6	0.0	0.8	14.3	376.9	0.00	1.00
09/21/2026 04:00	0.7	0.6	0.0	0.8	14.3	397.3	0.00	1.00
09/21/2026 05:00	0.6	0.6	0.0	0.6	14.4	445.2	0.00	1.00
09/21/2026 06:00	0.6	0.6	0.0	0.7	14.3	434.0	0.00	1.00
09/21/2026 07:00	0.6	0.6	0.0	0.7	14.4	429.0	0.00	1.00
09/21/2026 08:00	0.6	0.6	0.0	0.7	14.3	406.7	0.00	1.00
09/21/2026 09:00	0.7	0.6	0.0	0.8	14.3	377.5	0.00	1.00
09/21/2026 10:00	0.6	0.6	0.0	0.7	14.3	377.1	0.00	1.00
09/21/2026 11:00	0.6	0.5	0.0	0.7	14.4	376.5	0.00	1.00
09/21/2026 12:00	0.6	0.5	0.0	0.7	14.4	376.2	0.00	1.00
09/21/2026 13:00	0.6	0.5	0.0	0.7	14.4	375.8	0.00	1.00
09/21/2026 14:00	0.6	0.5	0.0	0.7	14.4	388.3	0.00	1.00
09/21/2026 15:00	0.6	0.5	0.0	0.7	14.4	375.2	0.00	1.00
09/21/2026 16:00	0.6	0.5	0.0	0.7	14.4	390.7	0.00	1.00
09/21/2026 17:00	0.6	0.5	0.0	0.7	14.4	375.5	0.00	1.00
09/21/2026 18:00	0.6	0.5	0.0	0.7	14.4	376.1	0.00	1.00
09/21/2026 19:00	0.6	0.5	0.0	0.7	14.3	376.5	0.00	1.00
09/21/2026 20:00	0.6	0.5	0.0	0.7	14.3	376.8	0.00	1.00
09/21/2026 21:00	0.6	0.5	0.0	0.7	14.3	377.1	0.00	1.00
09/21/2026 22:00	0.6	0.5	0.0	0.7	14.3	377.2	0.00	1.00
09/21/2026 23:00	0.6	0.5	0.0	0.7	14.3	377.4	0.00	1.00
Average/Sum#:	0.6	0.5	0.0	0.7	14.3	387.2	0.00 #	24.00 #
Minimum:	0.6	0.5	0.0	0.6	14.3	375.2	0.00	1.00
Maximum:	0.7	0.6	0.0	0.8	14.4	445.2	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/22/2026 00:00	0.7	0.5	0.0	0.8	14.3	377.4	0.00	1.00
09/22/2026 01:00	0.6	0.5	0.0	0.7	14.3	377.7	0.00	1.00
09/22/2026 02:00	0.6	0.6	0.0	0.7	14.3	378.0	0.00	1.00
09/22/2026 03:00	0.7	0.6	0.0	0.8	14.3	378.2	0.00	1.00
09/22/2026 04:00	0.7	0.6	0.0	0.8	14.3	378.3	0.00	1.00
09/22/2026 05:00	0.7	0.6	0.0	0.8	14.3	379.2	0.00	1.00
09/22/2026 06:00	0.7	0.6	0.0	0.8	14.3	394.3	0.00	1.00
09/22/2026 07:00	0.7	0.6	0.0	0.8	14.3	378.7	0.00	1.00
09/22/2026 08:00	0.6	0.6	0.0	0.7	14.3	378.3	0.00	1.00
09/22/2026 09:00	0.7	0.6	0.0	0.8	14.3	377.6	0.00	1.00
09/22/2026 10:00	0.6	0.6	0.0	0.7	14.3	376.8	0.00	1.00
09/22/2026 11:00	0.6	0.5	0.0	0.7	14.4	376.3	0.00	1.00
09/22/2026 12:00	0.6	0.5	0.0	0.7	14.4	376.0	0.00	1.00
09/22/2026 13:00	0.6	0.5	0.0	0.7	14.4	375.2	0.00	1.00
09/22/2026 14:00	0.6	0.5	0.0	0.7	14.4	375.0	0.00	1.00
09/22/2026 15:00	0.6	0.5	0.0	0.7	14.4	374.9	0.00	1.00
09/22/2026 16:00	0.6	0.5	0.0	0.7	14.4	383.5	0.00	1.00
09/22/2026 17:00	0.6	0.5	0.0	0.7	14.4	374.5	0.00	1.00
09/22/2026 18:00	0.6	0.5	0.0	0.7	14.4	374.9	0.00	1.00
09/22/2026 19:00	0.6	0.5	0.0	0.7	14.4	375.9	0.00	1.00
09/22/2026 20:00	0.6	0.5	0.0	0.7	14.4	376.3	0.00	1.00
09/22/2026 21:00	0.8	0.6	0.0	0.9	14.3	433.4	0.00	1.00
09/22/2026 22:00	1.2	0.9	0.0	1.4	14.0	519.9	0.00	1.00
09/22/2026 23:00	0.7	1.0	0.0	0.9	14.3	399.9	0.00	1.00
Average/Sum#:	0.7	0.6	0.0	0.8	14.3	387.1	0.00 #	24.00 #
Minimum:	0.6	0.5	0.0	0.7	14.0	374.5	0.00	1.00
Maximum:	1.2	1.0	0.0	1.4	14.4	519.9	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/23/2026 00:00	0.7	0.9	0.0	0.8	14.3	377.5	0.00	1.00
09/23/2026 01:00	0.7	0.6	0.0	0.8	14.3	378.0	0.00	1.00
09/23/2026 02:00	0.7	0.6	0.0	0.8	14.3	377.8	0.00	1.00
09/23/2026 03:00	0.7	0.6	0.0	0.8	14.3	378.2	0.00	1.00
09/23/2026 04:00	0.7	0.6	0.0	0.8	14.3	382.2	0.00	1.00
09/23/2026 05:00	0.7	0.6	0.0	0.8	14.3	417.7	0.00	1.00
09/23/2026 06:00	0.7	0.7	0.0	0.8	14.3	407.0	0.00	1.00
09/23/2026 07:00	0.7	0.7	0.0	0.8	14.3	378.0	0.00	1.00
09/23/2026 08:00	0.7	0.6	0.0	0.8	14.3	377.4	0.00	1.00
09/23/2026 09:00	0.7	0.6	0.0	0.8	14.4	376.6	0.00	1.00
09/23/2026 10:00	0.6	0.6	0.0	0.7	14.4	376.3	0.00	1.00
09/23/2026 11:00	0.6	0.5	0.0	0.7	14.4	375.6	0.00	1.00
09/23/2026 12:00	0.6	0.5	0.0	0.7	14.4	375.0	0.00	1.00
09/23/2026 13:00	0.6	0.5	0.0	0.7	14.5	384.1	0.00	1.00
09/23/2026 14:00	0.6	0.5	0.0	0.7	14.5	378.4	0.00	1.00
09/23/2026 15:00	0.7	0.5	0.0	0.7	14.5	390.9	0.00	1.00
09/23/2026 16:00	0.6	0.6	0.0	0.7	14.5	413.7	0.00	1.00
09/23/2026 17:00	0.6	0.6	0.0	0.7	14.4	378.6	0.00	1.00
09/23/2026 18:00	0.6	0.5	0.0	0.7	14.4	374.8	0.00	1.00
09/23/2026 19:00	0.6	0.5	0.0	0.6	14.6	454.0	0.00	1.00
09/23/2026 20:00	0.7	0.6	0.0	0.8	14.5	411.8	0.00	1.00
09/23/2026 21:00	0.7	0.6	0.0	0.8	14.4	383.3	0.00	1.00
09/23/2026 22:00	0.7	0.6	0.0	0.8	14.3	376.5	0.00	1.00
09/23/2026 23:00	0.8	0.6	0.0	0.9	14.3	376.9	0.00	1.00
Average/Sum#:	0.7	0.6	0.0	0.8	14.4	387.5	0.00 #	24.00 #
Minimum:	0.6	0.5	0.0	0.6	14.3	374.8	0.00	1.00
Maximum:	0.8	0.9	0.0	0.9	14.6	454.0	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/24/2026 00:00	0.9	0.7	0.0	1.0	14.3	377.3	0.00	1.00
09/24/2026 01:00	0.8	0.7	0.0	0.9	14.3	376.7	0.00	1.00
09/24/2026 02:00	0.7	0.7	0.0	0.8	14.3	377.0	0.00	1.00
09/24/2026 03:00	0.7	0.6	0.0	0.8	14.3	376.7	0.00	1.00
09/24/2026 04:00	0.7	0.6	0.0	0.8	14.3	380.4	0.00	1.00
09/24/2026 05:00	0.8	0.7	0.0	0.9	14.4	424.6	0.00	1.00
09/24/2026 06:00	0.8	0.7	0.0	0.9	14.3	415.6	0.00	1.00
09/24/2026 07:00	0.8	0.8	0.0	0.9	14.3	377.1	0.00	1.00
09/24/2026 08:00	0.7	0.7	0.0	0.8	14.4	376.4	0.00	1.00
09/24/2026 09:00	0.7	0.6	0.0	0.8	14.4	375.7	0.00	1.00
09/24/2026 10:00	0.6	0.6	0.0	0.7	14.5	375.0	0.00	1.00
09/24/2026 11:00	0.6	0.5	0.0	0.7	14.5	374.6	0.00	1.00
09/24/2026 12:00	0.6	0.5	0.0	0.7	14.5	374.5	0.00	1.00
09/24/2026 13:00	0.6	0.5	0.0	0.6	14.5	405.7	0.00	1.00
09/24/2026 14:00	0.6	0.5	0.0	0.6	14.4	418.0	0.00	1.00
09/24/2026 15:00	0.5	0.5	0.0	0.6	14.4	423.3	0.00	1.00
09/24/2026 16:00	0.6	0.5	0.0	0.6	14.4	418.4	0.00	1.00
09/24/2026 17:00	0.7	0.6	0.0	0.8	14.3	469.8	0.00	1.00
09/24/2026 18:00	0.6	0.7	0.0	0.7	13.6	551.5	0.00	1.00
09/24/2026 19:00	0.6	0.7	0.0	0.7	14.5	396.6	0.00	1.00
09/24/2026 20:00	0.6	0.6	0.0	0.7	14.4	374.6	0.00	1.00
09/24/2026 21:00	0.6	0.5	0.0	0.7	14.4	375.0	0.00	1.00
09/24/2026 22:00	0.6	0.5	0.0	0.7	14.4	375.5	0.00	1.00
09/24/2026 23:00	0.7	0.6	0.0	0.8	14.4	375.6	0.00	1.00
Average/Sum#:	0.7	0.6	0.0	0.8	14.4	398.6	0.00 #	24.00 #
Minimum:	0.5	0.5	0.0	0.6	13.6	374.5	0.00	1.00
Maximum:	0.9	0.8	0.0	1.0	14.5	551.5	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/25/2026 00:00	0.7	0.6	0.0	0.8	14.3	375.6	0.00	1.00
09/25/2026 01:00	0.7	0.6	0.0	0.8	14.3	375.8	0.00	1.00
09/25/2026 02:00	0.7	0.6	0.0	0.8	14.3	375.9	0.00	1.00
09/25/2026 03:00	0.7	0.6	0.0	0.8	14.3	376.2	0.00	1.00
09/25/2026 04:00	0.7	0.6	0.0	0.8	14.3	376.3	0.00	1.00
09/25/2026 05:00	0.7	0.6	0.0	0.8	14.3	379.6	0.00	1.00
09/25/2026 06:00	0.7	0.6	0.0	0.8	14.3	391.3	0.00	1.00
09/25/2026 07:00	0.7	0.6	0.0	0.7	14.4	394.1	0.00	1.00
09/25/2026 08:00	0.7	0.6	0.0	0.8	14.3	375.2	0.00	1.00
09/25/2026 09:00	0.6	0.6	0.0	0.7	14.4	374.8	0.00	1.00
09/25/2026 10:00	0.6	0.5	0.0	0.7	14.4	374.5	0.00	1.00
09/25/2026 11:00	0.6	0.5	0.0	0.7	14.4	373.5	0.00	1.00
09/25/2026 12:00	0.6	0.5	0.0	0.7	14.4	372.7	0.00	1.00
09/25/2026 13:00	0.6	0.5	0.0	0.7	14.4	372.4	0.00	1.00
09/25/2026 14:00	0.6	0.5	0.0	0.7	14.5	372.1	0.00	1.00
09/25/2026 15:00	0.6	0.5	0.0	0.7	14.5	371.8	0.00	1.00
09/25/2026 16:00	0.6	0.5	0.0	0.7	14.5	380.0	0.00	1.00
09/25/2026 17:00	0.6	0.5	0.0	0.7	14.4	372.6	0.00	1.00
09/25/2026 18:00	0.6	0.5	0.0	0.7	14.4	373.4	0.00	1.00
09/25/2026 19:00	0.6	0.5	0.0	0.7	14.4	373.9	0.00	1.00
09/25/2026 20:00	0.7	0.5	0.0	0.8	14.4	374.5	0.00	1.00
09/25/2026 21:00	0.7	0.6	0.0	0.8	14.4	374.8	0.00	1.00
09/25/2026 22:00	0.7	0.6	0.0	0.8	14.3	375.0	0.00	1.00
09/25/2026 23:00	0.7	0.6	0.0	0.8	14.3	375.0	0.00	1.00
Average/Sum#:	0.7	0.6	0.0	0.8	14.4	376.3	0.00 #	24.00 #
Minimum:	0.6	0.5	0.0	0.7	14.3	371.8	0.00	1.00
Maximum:	0.7	0.6	0.0	0.8	14.5	394.1	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/26/2026 00:00	0.7	0.6	0.0	0.8	14.3	375.3	0.00	1.00
09/26/2026 01:00	0.7	0.6	0.0	0.8	14.3	375.8	0.00	1.00
09/26/2026 02:00	0.7	0.6	0.0	0.8	14.3	376.0	0.00	1.00
09/26/2026 03:00	0.7	0.6	0.0	0.8	14.3	375.9	0.00	1.00
09/26/2026 04:00	0.7	0.6	0.0	0.8	14.3	375.7	0.00	1.00
09/26/2026 05:00	0.7	0.6	0.0	0.8	14.3	376.0	0.00	1.00
09/26/2026 06:00	0.7	0.6	0.0	0.8	14.3	376.0	0.00	1.00
09/26/2026 07:00	0.7	0.6	0.0	0.8	14.3	376.3	0.00	1.00
09/26/2026 08:00	0.7	0.6	0.0	0.8	14.3	376.5	0.00	1.00
09/26/2026 09:00	0.7	0.6	0.0	0.8	14.3	376.0	0.00	1.00
09/26/2026 10:00	0.6	0.6	0.0	0.7	14.4	375.8	0.00	1.00
09/26/2026 11:00	0.6	0.6	0.0	0.7	14.4	375.2	0.00	1.00
09/26/2026 12:00	0.6	0.5	0.0	0.7	14.4	374.8	0.00	1.00
09/26/2026 13:00	0.6	0.5	0.0	0.7	14.4	374.2	0.00	1.00
09/26/2026 14:00	0.6	0.5	0.0	0.7	14.5	373.9	0.00	1.00
09/26/2026 15:00	0.6	0.5	0.0	0.7	14.5	373.6	0.00	1.00
09/26/2026 16:00	0.6	0.5	0.0	0.6	14.4	419.9	0.00	1.00
09/26/2026 17:00	0.5	0.5	0.0	0.6	14.4	457.7	0.00	1.00
09/26/2026 18:00	0.6	0.6	0.0	0.7	14.5	411.7	0.00	1.00
09/26/2026 19:00	0.6	0.6	0.0	0.6	14.6	457.4	0.00	1.00
09/26/2026 20:00	0.6	0.6	0.0	0.6	14.6	454.8	0.00	1.00
09/26/2026 21:00	0.7	0.6	0.0	0.7	14.6	454.9	0.00	1.00
09/26/2026 22:00	0.8	0.7	0.0	0.9	14.4	466.1	0.00	1.00
09/26/2026 23:00	0.2	0.6	0.0	0.2	12.7	629.2	0.00	1.00
Average/Sum#:	0.6	0.6	0.0	0.7	14.3	406.6	0.00 #	24.00 #
Minimum:	0.2	0.5	0.0	0.2	12.7	373.6	0.00	1.00
Maximum:	0.8	0.7	0.0	0.9	14.6	629.2	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/27/2026 00:00	1.0	0.7	0.0	1.1	14.0	523.3	0.00	1.00
09/27/2026 01:00	0.9	0.8	0.0	1.1	14.2	463.4	0.00	1.00
09/27/2026 02:00	0.6	0.9	0.0	0.7	14.4	427.6	0.00	1.00
09/27/2026 03:00	0.7	0.7	0.0	0.8	14.3	402.1	0.00	1.00
09/27/2026 04:00	0.7	0.6	0.0	0.8	14.3	382.5	0.00	1.00
09/27/2026 05:00	0.7	0.6	0.0	0.7	14.4	411.5	0.00	1.00
09/27/2026 06:00	0.6	0.6	0.0	0.7	14.4	450.1	0.00	1.00
09/27/2026 07:00	0.6	0.6	0.0	0.7	14.4	450.2	0.00	1.00
09/27/2026 08:00	0.7	0.6	0.0	0.8	14.3	398.0	0.00	1.00
09/27/2026 09:00	0.7	0.6	0.0	0.8	14.3	376.5	0.00	1.00
09/27/2026 10:00	0.7	0.6	0.0	0.8	14.3	376.3	0.00	1.00
09/27/2026 11:00	0.7	0.6	0.0	0.8	14.3	376.1	0.00	1.00
09/27/2026 12:00	0.7	0.6	0.0	0.8	14.4	375.2	0.00	1.00
09/27/2026 13:00	0.7	0.6	0.0	0.8	14.4	374.5	0.00	1.00
09/27/2026 14:00	0.6	0.6	0.0	0.7	14.4	379.1	0.00	1.00
09/27/2026 15:00	0.6	0.5	0.0	0.7	14.5	396.1	0.00	1.00
09/27/2026 16:00	0.8	0.6	0.0	0.9	14.4	435.5	0.00	1.00
09/27/2026 17:00	0.2	0.5	0.0	0.3	12.9	612.5	0.00	1.00
09/27/2026 18:00	0.2	0.5	0.0	0.3	13.0	605.9	0.00	1.00
09/27/2026 19:00	0.3	0.3	0.0	0.4	13.0	604.9	0.00	1.00
09/27/2026 20:00	0.4	0.4	0.0	0.5	13.2	592.4	0.00	1.00
09/27/2026 21:00	1.0	0.7	0.0	1.2	13.9	533.1	0.00	1.00
09/27/2026 22:00	1.2	1.0	0.0	1.3	14.2	496.6	0.00	1.00
09/27/2026 23:00	0.6	1.0	0.0	0.7	14.3	424.1	0.00	1.00
Average/Sum#:	0.7	0.6	0.0	0.8	14.1	452.8	0.00 #	24.00 #
Minimum:	0.2	0.3	0.0	0.3	12.9	374.5	0.00	1.00
Maximum:	1.2	1.0	0.0	1.3	14.5	612.5	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/28/2026 00:00	0.6	0.8	0.0	0.7	14.3	417.6	0.00	1.00
09/28/2026 01:00	0.7	0.6	0.0	0.8	14.2	377.9	0.00	1.00
09/28/2026 02:00	0.7	0.6	0.0	0.8	14.3	400.5	0.00	1.00
09/28/2026 03:00	1.2	0.8	0.0	1.4	14.3	434.4	0.00	1.00
09/28/2026 04:00	1.9	1.4	0.0	2.2	14.2	505.6	0.00	1.00
09/28/2026 05:00	1.7	1.8	0.0	2.0	14.1	520.1	0.00	1.00
09/28/2026 06:00	1.1	1.8	0.0	1.3	13.8	520.2	0.00	1.00
09/28/2026 07:00	0.7	1.3	0.0	0.8	14.3	409.5	0.00	1.00
09/28/2026 08:00	0.7	0.9	0.0	0.8	14.3	376.5	0.00	1.00
09/28/2026 09:00	0.7	0.6	0.0	0.8	14.3	376.0	0.00	1.00
09/28/2026 10:00	0.7	0.6	0.0	0.8	14.3	375.4	0.00	1.00
09/28/2026 11:00	0.7	0.6	0.0	0.8	14.4	374.9	0.00	1.00
09/28/2026 12:00	0.6	0.6	0.0	0.7	14.4	374.6	0.00	1.00
09/28/2026 13:00	0.6	0.6	0.0	0.7	14.4	374.2	0.00	1.00
09/28/2026 14:00	0.6	0.5	0.0	0.7	14.4	373.7	0.00	1.00
09/28/2026 15:00	0.6	0.5	0.0	0.7	14.5	373.2	0.00	1.00
09/28/2026 16:00	0.6	0.5	0.0	0.7	14.5	374.6	0.00	1.00
09/28/2026 17:00	0.6	0.5	0.0	0.7	14.5	372.6	0.00	1.00
09/28/2026 18:00	0.6	0.5	0.0	0.7	14.5	373.0	0.00	1.00
09/28/2026 19:00	0.7	0.6	0.0	0.8	14.4	374.0	0.00	1.00
09/28/2026 20:00	0.7	0.6	0.0	0.8	14.4	374.4	0.00	1.00
09/28/2026 21:00	0.8	0.6	0.0	0.9	14.4	374.7	0.00	1.00
09/28/2026 22:00	0.7	0.6	0.0	0.8	14.3	375.0	0.00	1.00
09/28/2026 23:00	0.7	0.6	0.0	0.8	14.3	375.4	0.00	1.00
Average/Sum#:	0.8	0.8	0.0	0.9	14.3	399.1	0.00 #	24.00 #
Minimum:	0.6	0.5	0.0	0.7	13.8	372.6	0.00	1.00
Maximum:	1.9	1.8	0.0	2.2	14.5	520.2	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/29/2026 00:00	0.8	0.6	0.0	0.9	14.3	375.7	0.00	1.00
09/29/2026 01:00	0.8	0.7	0.0	0.9	14.3	375.7	0.00	1.00
09/29/2026 02:00	0.8	0.7	0.0	0.9	14.3	375.9	0.00	1.00
09/29/2026 03:00	0.8	0.7	0.0	0.9	14.3	375.9	0.00	1.00
09/29/2026 04:00	0.8	0.7	0.0	0.9	14.3	376.1	0.00	1.00
09/29/2026 05:00	0.8	0.7	0.0	0.9	14.3	376.4	0.00	1.00
09/29/2026 06:00	0.8	0.7	0.0	0.9	14.3	376.4	0.00	1.00
09/29/2026 07:00	0.8	0.7	0.0	0.9	14.3	375.9	0.00	1.00
09/29/2026 08:00	0.7	0.7	0.0	0.8	14.3	375.1	0.00	1.00
09/29/2026 09:00	0.7	0.6	0.0	0.8	14.4	374.1	0.00	1.00
09/29/2026 10:00	0.7	0.6	0.0	0.8	14.5	373.2	0.00	1.00
09/29/2026 11:00	0.6	0.6	0.0	0.7	14.5	372.8	0.00	1.00
09/29/2026 12:00	0.6	0.6	0.0	0.7	14.5	372.2	0.00	1.00
09/29/2026 13:00	0.6	0.5	0.0	0.7	14.5	371.4	0.00	1.00
09/29/2026 14:00	0.7	0.5	0.0	0.7	14.6	371.2	0.00	1.00
09/29/2026 15:00	0.6	0.5	0.0	0.7	14.5	371.3	0.00	1.00
09/29/2026 16:00	0.6	0.5	0.0	0.7	14.6	384.4	0.00	1.00
09/29/2026 17:00	0.6	0.5	0.0	0.7	14.4	373.7	0.00	1.00
09/29/2026 18:00	0.6	0.5	0.0	0.7	14.5	372.7	0.00	1.00
09/29/2026 19:00	0.7	0.5	0.0	0.8	14.5	373.0	0.00	1.00
09/29/2026 20:00	0.7	0.6	0.0	0.8	14.4	373.7	0.00	1.00
09/29/2026 21:00	0.7	0.6	0.0	0.8	14.4	373.9	0.00	1.00
09/29/2026 22:00	0.7	0.6	0.0	0.8	14.4	374.3	0.00	1.00
09/29/2026 23:00	0.7	0.6	0.0	0.7	14.5	456.3	0.00	1.00
Average/Sum#:	0.7	0.6	0.0	0.8	14.4	378.0	0.00 #	24.00 #
Minimum:	0.6	0.5	0.0	0.7	14.3	371.2	0.00	1.00
Maximum:	0.8	0.7	0.0	0.9	14.6	456.3	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

CO Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:		> 6.2	> 89.5					
	Unit CT2 CO, Ppmvdc 1 Hour(s)	Unit CT2 CO_3Hr, LbPerHr 1 Hour(s)	Unit CT2 CO_SUSD, LbPerHr 1 Hour(s)	Unit CT2 CO, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/30/2026 00:00	0.7	0.6	0.0	0.8	14.4	374.1	0.00	1.00
09/30/2026 01:00	0.7	0.6	0.0	0.8	14.4	376.5	0.00	1.00
09/30/2026 02:00	0.7	0.6	0.0	0.8	14.4	398.8	0.00	1.00
09/30/2026 03:00	1.4	0.9	0.0	1.6	14.3	490.0	0.00	1.00
09/30/2026 04:00	1.3	1.2	0.0	1.5	14.1	515.1	0.00	1.00
09/30/2026 05:00	0.8	1.3	0.0	0.9	13.3	585.7	0.00	1.00
09/30/2026 06:00	0.7	1.1	0.0	0.9	13.8	476.1	0.00	1.00
09/30/2026 07:00	0.8	0.8	0.0	0.9	14.3	375.6	0.00	1.00
09/30/2026 08:00	0.7	0.7	0.0	0.8	14.4	378.2	0.00	1.00
09/30/2026 09:00	0.7	0.6	0.0	0.8	14.4	373.2	0.00	1.00
09/30/2026 10:00	0.7	0.6	0.0	0.8	14.5	387.4	0.00	1.00
09/30/2026 11:00	0.7	0.6	0.0	0.7	14.5	411.9	0.00	1.00
09/30/2026 12:00	0.8	0.7	0.0	0.8	14.4	450.1	0.00	1.00
09/30/2026 13:00	0.8	0.8	0.0	1.0	13.9	523.4	0.00	1.00
09/30/2026 14:00	0.3	0.7	0.0	0.4	12.7	613.8	0.00	1.00
09/30/2026 15:00	0.1	0.5	0.0	0.2	12.6	620.1	0.00	1.00
09/30/2026 16:00	0.2	0.3	0.0	0.2	12.7	612.7	0.00	1.00
09/30/2026 17:00	0.2	0.2	0.0	0.3	12.9	595.7	0.00	1.00
09/30/2026 18:00	0.4	0.3	0.0	0.5	13.5	526.8	0.00	1.00
09/30/2026 19:00	0.7	0.5	0.0	0.9	13.9	492.0	0.00	1.00
09/30/2026 20:00	0.8	0.7	0.0	0.9	14.5	462.5	0.00	1.00
09/30/2026 21:00	0.8	0.9	0.0	1.0	13.8	523.1	0.00	1.00
09/30/2026 22:00	0.8	0.9	0.0	0.9	14.4	398.2	0.00	1.00
09/30/2026 23:00	0.7	0.8	0.0	0.8	14.4	404.7	0.00	1.00
Average/Sum#:	0.7	0.7	0.0	0.8	13.9	473.6	0.00 #	24.00 #
Minimum:	0.1	0.2	0.0	0.2	12.6	373.2	0.00	1.00
Maximum:	1.4	1.3	0.0	1.6	14.5	620.1	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/01/2026 00:00	3,732.0	0.0	3,732.0	104,600.0	390.4	0.5	0.2	0.8
07/01/2026 01:00	3,735.6	0.0	3,735.6	104,600.0	390.7	0.5	0.2	0.8
07/01/2026 02:00	3,730.9	0.0	3,730.9	104,600.0	390.3	0.5	0.2	0.8
07/01/2026 03:00	3,731.1	0.0	3,731.1	104,600.0	390.3	0.5	0.2	0.8
07/01/2026 04:00	3,723.8	0.0	3,723.8	104,600.0	389.5	0.5	0.2	0.8
07/01/2026 05:00	3,724.2	0.0	3,724.2	104,600.0	389.6	0.5	0.2	0.8
07/01/2026 06:00	3,719.2	0.0	3,719.2	104,600.0	389.0	0.5	0.2	0.8
07/01/2026 07:00	3,729.5	1.9	3,729.5	104,600.0	390.1	0.5	0.2	0.8
07/01/2026 08:00	3,725.9	35.4	3,725.9	104,600.0	389.7	0.5	0.2	0.8
07/01/2026 09:00	3,724.8	25.1	3,724.8	104,600.0	389.6	0.5	0.2	0.8
07/01/2026 10:00	3,703.7	48.6	3,703.7	104,600.0	387.4	0.5	0.2	0.8
07/01/2026 11:00	3,705.1	103.4	3,705.1	104,600.0	387.6	0.5	0.2	0.8
07/01/2026 12:00	3,716.0	105.6	3,716.0	104,600.0	388.7	0.5	0.2	0.8
07/01/2026 13:00	3,712.7	66.8	3,712.7	104,600.0	388.3	0.5	0.2	0.8
07/01/2026 14:00	3,711.9	5.6	3,711.9	104,600.0	388.3	0.5	0.2	0.8
07/01/2026 15:00	3,713.5	0.0	3,713.5	104,600.0	388.4	0.5	0.2	0.8
07/01/2026 16:00	3,790.8	6.7	3,790.8	104,600.0	396.5	0.5	0.2	0.8
07/01/2026 17:00	3,920.2	0.0	3,920.2	104,600.0	410.1	0.5	0.2	0.8
07/01/2026 18:00	4,181.2	0.0	4,181.2	104,600.0	437.4	0.5	0.3	0.9
07/01/2026 19:00	4,369.9	0.0	4,369.9	104,600.0	457.1	0.5	0.3	0.9
07/01/2026 20:00	4,166.1	0.0	4,166.1	104,600.0	435.8	0.5	0.3	0.9
07/01/2026 21:00	3,806.8	0.0	3,806.8	104,600.0	398.2	0.5	0.2	0.8
07/01/2026 22:00	3,824.7	0.0	3,824.7	104,600.0	400.1	0.5	0.2	0.8
07/01/2026 23:00	3,954.1	0.0	3,954.1	104,600.0	413.6	0.5	0.2	0.8
Average/Sum#:	3,814.7	16.6	3,814.7	104,600.0	399.0	0.5	0.2	0.8
Minimum:	3,703.7	0.0	3,703.7	104,600.0	387.4	0.5	0.2	0.8
Maximum:	4,369.9	105.6	4,369.9	104,600.0	457.1	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/02/2026 00:00	3,713.9	0.0	3,713.9	104,600.0	388.5	0.5	0.2	0.8
07/02/2026 01:00	3,707.7	0.0	3,707.7	104,600.0	387.8	0.5	0.2	0.8
07/02/2026 02:00	3,706.5	0.0	3,706.5	104,600.0	387.7	0.5	0.2	0.8
07/02/2026 03:00	3,704.2	0.0	3,704.2	104,600.0	387.5	0.5	0.2	0.8
07/02/2026 04:00	3,754.3	0.0	3,754.3	104,600.0	392.7	0.5	0.2	0.8
07/02/2026 05:00	3,712.8	0.0	3,712.8	104,600.0	388.4	0.5	0.2	0.8
07/02/2026 06:00	3,711.4	0.0	3,711.4	104,600.0	388.2	0.5	0.2	0.8
07/02/2026 07:00	3,710.2	0.0	3,710.2	104,600.0	388.1	0.5	0.2	0.8
07/02/2026 08:00	3,713.1	15.9	3,713.1	104,600.0	388.4	0.5	0.2	0.8
07/02/2026 09:00	3,717.5	25.7	3,717.5	104,600.0	388.9	0.5	0.2	0.8
07/02/2026 10:00	3,703.7	80.3	3,703.7	104,600.0	387.4	0.5	0.2	0.8
07/02/2026 11:00	3,687.5	101.9	3,687.5	104,600.0	385.7	0.5	0.2	0.8
07/02/2026 12:00	3,681.5	96.5	3,681.5	104,600.0	385.1	0.5	0.2	0.8
07/02/2026 13:00	3,688.5	86.9	3,688.5	104,600.0	385.8	0.5	0.2	0.8
07/02/2026 14:00	3,692.2	4.0	3,692.2	104,600.0	386.2	0.5	0.2	0.8
07/02/2026 15:00	3,695.4	0.0	3,695.4	104,600.0	386.5	0.5	0.2	0.8
07/02/2026 16:00	3,695.9	2.9	3,695.9	104,600.0	386.6	0.5	0.2	0.8
07/02/2026 17:00	3,831.5	0.0	3,831.5	104,600.0	400.8	0.5	0.2	0.8
07/02/2026 18:00	3,685.7	0.0	3,685.7	104,600.0	385.5	0.5	0.2	0.8
07/02/2026 19:00	3,672.5	0.0	3,672.5	104,600.0	384.1	0.5	0.2	0.8
07/02/2026 20:00	3,689.0	0.0	3,689.0	104,600.0	385.9	0.5	0.2	0.8
07/02/2026 21:00	3,690.9	0.0	3,690.9	104,600.0	386.1	0.5	0.2	0.8
07/02/2026 22:00	3,737.0	0.0	3,737.0	104,600.0	390.9	0.5	0.2	0.8
07/02/2026 23:00	4,247.1	0.0	4,247.1	104,600.0	444.2	0.5	0.3	0.9
Average/Sum#:	3,731.3	17.3	3,731.3	104,600.0	390.3	0.5	0.2	0.8
Minimum:	3,672.5	0.0	3,672.5	104,600.0	384.1	0.5	0.2	0.8
Maximum:	4,247.1	101.9	4,247.1	104,600.0	444.2	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/03/2026 00:00	3,753.6	0.0	3,753.6	104,600.0	392.6	0.5	0.2	0.8
07/03/2026 01:00	3,609.7	0.0	3,609.7	104,600.0	377.6	0.5	0.2	0.8
07/03/2026 02:00	3,592.0	0.0	3,592.0	104,600.0	375.7	0.5	0.2	0.8
07/03/2026 03:00	3,590.7	0.0	3,590.7	104,600.0	375.6	0.5	0.2	0.8
07/03/2026 04:00	3,720.0	0.0	3,720.0	104,600.0	389.1	0.5	0.2	0.8
07/03/2026 05:00	3,737.7	0.0	3,737.7	104,600.0	391.0	0.5	0.2	0.8
07/03/2026 06:00	3,748.0	0.0	3,748.0	104,600.0	392.0	0.5	0.2	0.8
07/03/2026 07:00	3,751.7	10.8	3,751.7	104,600.0	392.4	0.5	0.2	0.8
07/03/2026 08:00	3,760.0	4.2	3,760.0	104,600.0	393.3	0.5	0.2	0.8
07/03/2026 09:00	3,731.1	51.6	3,731.1	104,600.0	390.3	0.5	0.2	0.8
07/03/2026 10:00	3,725.4	100.0	3,725.4	104,600.0	389.7	0.5	0.2	0.8
07/03/2026 11:00	3,730.0	114.9	3,730.0	104,600.0	390.2	0.5	0.2	0.8
07/03/2026 12:00	3,735.1	107.9	3,735.1	104,600.0	390.7	0.5	0.2	0.8
07/03/2026 13:00	3,737.6	89.2	3,737.6	104,600.0	391.0	0.5	0.2	0.8
07/03/2026 14:00	3,735.5	17.0	3,735.5	104,600.0	390.7	0.5	0.2	0.8
07/03/2026 15:00	3,733.0	0.0	3,733.0	104,600.0	390.5	0.5	0.2	0.8
07/03/2026 16:00	3,863.0	8.0	3,863.0	104,600.0	404.1	0.5	0.2	0.8
07/03/2026 17:00	3,901.1	0.0	3,901.1	104,600.0	408.1	0.5	0.2	0.8
07/03/2026 18:00	3,729.0	0.0	3,729.0	104,600.0	390.1	0.5	0.2	0.8
07/03/2026 19:00	3,752.0	0.0	3,752.0	104,600.0	392.5	0.5	0.2	0.8
07/03/2026 20:00	3,743.2	0.0	3,743.2	104,600.0	391.5	0.5	0.2	0.8
07/03/2026 21:00	3,745.5	0.0	3,745.5	104,600.0	391.8	0.5	0.2	0.8
07/03/2026 22:00	3,735.5	0.0	3,735.5	104,600.0	390.7	0.5	0.2	0.8
07/03/2026 23:00	3,840.0	0.0	3,840.0	104,600.0	401.7	0.5	0.2	0.8
Average/Sum#:	3,737.5	21.0	3,737.5	104,600.0	391.0	0.5	0.2	0.8
Minimum:	3,590.7	0.0	3,590.7	104,600.0	375.6	0.5	0.2	0.8
Maximum:	3,901.1	114.9	3,901.1	104,600.0	408.1	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/04/2026 00:00	4,257.6	0.0	4,257.6	104,600.0	445.3	0.5	0.3	0.9
07/04/2026 01:00	3,730.3	0.0	3,730.3	104,600.0	390.2	0.5	0.2	0.8
07/04/2026 02:00	3,620.3	0.0	3,620.3	104,600.0	378.7	0.5	0.2	0.8
07/04/2026 03:00	3,588.1	0.0	3,588.1	104,600.0	375.3	0.5	0.2	0.8
07/04/2026 04:00	3,594.3	0.0	3,594.3	104,600.0	376.0	0.5	0.2	0.8
07/04/2026 05:00	4,204.9	18.9	4,206.4	104,600.0	440.0	0.5	0.3	0.9
07/04/2026 06:00	4,163.1	0.8	4,163.1	104,600.0	435.5	0.5	0.3	0.9
07/04/2026 07:00	3,848.7	38.0	3,848.7	104,600.0	402.6	0.5	0.2	0.8
07/04/2026 08:00	3,724.5	18.7	3,724.5	104,600.0	389.6	0.5	0.2	0.8
07/04/2026 09:00	3,723.3	39.4	3,723.3	104,600.0	389.5	0.5	0.2	0.8
07/04/2026 10:00	3,732.3	87.8	3,732.3	104,600.0	390.4	0.5	0.2	0.8
07/04/2026 11:00	3,713.3	127.5	3,713.3	104,600.0	388.4	0.5	0.2	0.8
07/04/2026 12:00	3,700.7	101.5	3,700.7	104,600.0	387.1	0.5	0.2	0.8
07/04/2026 13:00	3,700.5	96.3	3,700.5	104,600.0	387.1	0.5	0.2	0.8
07/04/2026 14:00	3,730.5	28.4	3,730.5	104,600.0	390.2	0.5	0.2	0.8
07/04/2026 15:00	4,333.0	0.0	4,333.0	104,600.0	453.2	0.5	0.3	0.9
07/04/2026 16:00	4,385.6	14.8	4,385.6	104,600.0	458.7	0.6	0.3	0.9
07/04/2026 17:00	4,327.9	0.0	4,327.9	104,600.0	452.7	0.5	0.3	0.9
07/04/2026 18:00	4,153.4	0.0	4,153.4	104,600.0	434.4	0.5	0.3	0.9
07/04/2026 19:00	4,562.2	448.7	4,889.8	104,600.0	511.5	0.6	0.3	1.0
07/04/2026 20:00	4,319.6	272.7	4,464.1	104,600.0	466.9	0.6	0.3	1.0
07/04/2026 21:00	3,607.1	0.0	3,607.1	104,600.0	377.3	0.5	0.2	0.8
07/04/2026 22:00	3,763.0	0.0	3,763.0	104,600.0	393.6	0.5	0.2	0.8
07/04/2026 23:00	4,189.8	0.0	4,189.8	104,600.0	438.3	0.5	0.3	0.9
Average/Sum#:	3,944.8	53.9	3,964.5	104,600.0	414.7	0.5	0.2	0.9
Minimum:	3,588.1	0.0	3,588.1	104,600.0	375.3	0.5	0.2	0.8
Maximum:	4,562.2	448.7	4,889.8	104,600.0	511.5	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/05/2026 00:00	3,923.5	0.0	3,923.5	104,600.0	410.4	0.5	0.2	0.8
07/05/2026 01:00	3,756.4	0.0	3,756.4	104,600.0	392.9	0.5	0.2	0.8
07/05/2026 02:00	3,766.5	0.0	3,766.5	104,600.0	394.0	0.5	0.2	0.8
07/05/2026 03:00	3,755.4	0.0	3,755.4	104,600.0	392.8	0.5	0.2	0.8
07/05/2026 04:00	3,763.9	0.0	3,763.9	104,600.0	393.7	0.5	0.2	0.8
07/05/2026 05:00	4,129.7	0.0	4,129.7	104,600.0	432.0	0.5	0.3	0.9
07/05/2026 06:00	3,912.5	0.0	3,912.5	104,600.0	409.2	0.5	0.2	0.8
07/05/2026 07:00	3,758.3	0.0	3,758.3	104,600.0	393.1	0.5	0.2	0.8
07/05/2026 08:00	3,744.6	0.5	3,744.6	104,600.0	391.7	0.5	0.2	0.8
07/05/2026 09:00	3,639.3	23.9	3,639.3	104,600.0	380.7	0.5	0.2	0.8
07/05/2026 10:00	3,642.7	118.8	3,642.7	104,600.0	381.0	0.5	0.2	0.8
07/05/2026 11:00	3,631.0	102.8	3,631.0	104,600.0	379.8	0.5	0.2	0.8
07/05/2026 12:00	3,604.2	112.7	3,604.2	104,600.0	377.0	0.5	0.2	0.8
07/05/2026 13:00	3,593.7	86.0	3,593.7	104,600.0	375.9	0.5	0.2	0.8
07/05/2026 14:00	3,587.4	18.6	3,587.4	104,600.0	375.2	0.5	0.2	0.8
07/05/2026 15:00	3,597.4	0.0	3,597.4	104,600.0	376.3	0.5	0.2	0.8
07/05/2026 16:00	3,630.0	9.1	3,630.0	104,600.0	379.7	0.5	0.2	0.8
07/05/2026 17:00	4,393.9	0.0	4,393.9	104,600.0	459.6	0.6	0.3	0.9
07/05/2026 18:00	4,385.3	0.0	4,385.3	104,600.0	458.7	0.6	0.3	0.9
07/05/2026 19:00	4,375.7	0.0	4,375.7	104,600.0	457.7	0.5	0.3	0.9
07/05/2026 20:00	4,375.2	0.0	4,375.2	104,600.0	457.6	0.5	0.3	0.9
07/05/2026 21:00	4,374.8	0.0	4,374.8	104,600.0	457.6	0.5	0.3	0.9
07/05/2026 22:00	3,863.4	0.0	3,863.4	104,600.0	404.1	0.5	0.2	0.8
07/05/2026 23:00	3,671.9	0.0	3,671.9	104,600.0	384.1	0.5	0.2	0.8
Average/Sum#:	3,869.9	19.7	3,869.9	104,600.0	404.8	0.5	0.2	0.8
Minimum:	3,587.4	0.0	3,587.4	104,600.0	375.2	0.5	0.2	0.8
Maximum:	4,393.9	118.8	4,393.9	104,600.0	459.6	0.6	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/06/2026 00:00	3,693.0	0.0	3,693.0	104,600.0	386.3	0.5	0.2	0.8
07/06/2026 01:00	3,632.1	0.0	3,632.1	104,600.0	379.9	0.5	0.2	0.8
07/06/2026 02:00	3,631.4	0.0	3,631.4	104,600.0	379.8	0.5	0.2	0.8
07/06/2026 03:00	3,632.3	0.0	3,632.3	104,600.0	379.9	0.5	0.2	0.8
07/06/2026 04:00	3,964.4	0.0	3,964.4	104,600.0	414.7	0.5	0.2	0.8
07/06/2026 05:00	3,808.7	0.0	3,808.7	104,600.0	398.4	0.5	0.2	0.8
07/06/2026 06:00	3,622.4	0.0	3,622.4	104,600.0	378.9	0.5	0.2	0.8
07/06/2026 07:00	3,621.9	0.1	3,621.9	104,600.0	378.9	0.5	0.2	0.8
07/06/2026 08:00	3,625.8	0.9	3,625.8	104,600.0	379.3	0.5	0.2	0.8
07/06/2026 09:00	3,637.7	51.3	3,637.7	104,600.0	380.5	0.5	0.2	0.8
07/06/2026 10:00	3,638.5	87.4	3,638.5	104,600.0	380.6	0.5	0.2	0.8
07/06/2026 11:00	3,629.5	111.7	3,629.5	104,600.0	379.6	0.5	0.2	0.8
07/06/2026 12:00	3,604.2	123.3	3,604.2	104,600.0	377.0	0.5	0.2	0.8
07/06/2026 13:00	3,757.5	94.0	3,757.5	104,600.0	393.0	0.5	0.2	0.8
07/06/2026 14:00	3,745.1	27.6	3,745.1	104,600.0	391.7	0.5	0.2	0.8
07/06/2026 15:00	3,964.9	0.0	3,964.9	104,600.0	414.7	0.5	0.2	0.8
07/06/2026 16:00	4,059.1	16.2	4,059.1	104,600.0	424.6	0.5	0.3	0.9
07/06/2026 17:00	4,011.0	0.0	4,011.0	104,600.0	419.6	0.5	0.3	0.8
07/06/2026 18:00	4,408.5	5.2	4,408.5	104,600.0	461.1	0.6	0.3	0.9
07/06/2026 19:00	4,413.8	0.0	4,413.8	104,600.0	461.7	0.6	0.3	0.9
07/06/2026 20:00	4,408.3	0.0	4,408.3	104,600.0	461.1	0.6	0.3	0.9
07/06/2026 21:00	4,409.8	0.0	4,409.8	104,600.0	461.3	0.6	0.3	0.9
07/06/2026 22:00	4,402.4	0.0	4,402.4	104,600.0	460.5	0.6	0.3	0.9
07/06/2026 23:00	4,392.5	0.0	4,392.5	104,600.0	459.5	0.6	0.3	0.9
Average/Sum#:	3,904.8	21.6	3,904.8	104,600.0	408.4	0.5	0.2	0.8
Minimum:	3,604.2	0.0	3,604.2	104,600.0	377.0	0.5	0.2	0.8
Maximum:	4,413.8	123.3	4,413.8	104,600.0	461.7	0.6	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/07/2026 00:00	4,385.1	0.0	4,385.1	104,600.0	458.7	0.6	0.3	0.9
07/07/2026 01:00	4,262.2	0.0	4,262.2	104,600.0	445.8	0.5	0.3	0.9
07/07/2026 02:00	4,374.9	0.0	4,374.9	104,600.0	457.6	0.5	0.3	0.9
07/07/2026 03:00	4,377.1	0.0	4,377.1	104,600.0	457.8	0.5	0.3	0.9
07/07/2026 04:00	4,390.1	0.0	4,390.1	104,600.0	459.2	0.6	0.3	0.9
07/07/2026 05:00	4,084.4	0.0	4,084.4	104,600.0	427.2	0.5	0.3	0.9
07/07/2026 06:00	3,640.8	0.0	3,640.8	104,600.0	380.8	0.5	0.2	0.8
07/07/2026 07:00	3,639.9	4.6	3,639.9	104,600.0	380.7	0.5	0.2	0.8
07/07/2026 08:00	3,642.2	31.4	3,642.2	104,600.0	381.0	0.5	0.2	0.8
07/07/2026 09:00	3,645.8	14.7	3,645.8	104,600.0	381.4	0.5	0.2	0.8
07/07/2026 10:00	3,645.0	131.7	3,645.0	104,600.0	381.3	0.5	0.2	0.8
07/07/2026 11:00	4,014.8	136.9	4,014.8	104,600.0	419.9	0.5	0.3	0.9
07/07/2026 12:00	3,886.2	111.1	3,886.2	104,600.0	406.5	0.5	0.3	0.8
07/07/2026 13:00	3,923.7	98.9	3,923.7	104,600.0	410.4	0.5	0.3	0.8
07/07/2026 14:00	4,194.0	25.3	4,194.0	104,600.0	438.7	0.5	0.3	0.9
07/07/2026 15:00	3,953.9	0.0	3,953.9	104,600.0	413.6	0.5	0.2	0.8
07/07/2026 16:00	3,987.4	4.7	3,987.4	104,600.0	417.1	0.5	0.3	0.8
07/07/2026 17:00	4,129.4	0.0	4,129.4	104,600.0	431.9	0.5	0.3	0.9
07/07/2026 18:00	4,339.0	2.7	4,339.0	104,600.0	453.9	0.5	0.3	0.9
07/07/2026 19:00	4,358.2	0.0	4,358.2	104,600.0	455.9	0.5	0.3	0.9
07/07/2026 20:00	4,347.2	0.0	4,347.2	104,600.0	454.7	0.5	0.3	0.9
07/07/2026 21:00	4,331.0	0.0	4,331.0	104,600.0	453.0	0.5	0.3	0.9
07/07/2026 22:00	4,329.9	0.0	4,329.9	104,600.0	452.9	0.5	0.3	0.9
07/07/2026 23:00	4,208.8	0.0	4,208.8	104,600.0	440.2	0.5	0.3	0.9
Average/Sum#:	4,087.1	23.4	4,087.1	104,600.0	427.5	0.5	0.3	0.9
Minimum:	3,639.9	0.0	3,639.9	104,600.0	380.7	0.5	0.2	0.8
Maximum:	4,390.1	136.9	4,390.1	104,600.0	459.2	0.6	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/08/2026 00:00	4,358.1	0.0	4,358.1	104,600.0	455.9	0.5	0.3	0.9
07/08/2026 01:00	3,754.5	0.0	3,754.5	104,600.0	392.7	0.5	0.2	0.8
07/08/2026 02:00	3,605.8	0.0	3,605.8	104,600.0	377.2	0.5	0.2	0.8
07/08/2026 03:00	3,606.7	0.0	3,606.7	104,600.0	377.3	0.5	0.2	0.8
07/08/2026 04:00	3,608.7	0.0	3,608.7	104,600.0	377.5	0.5	0.2	0.8
07/08/2026 05:00	3,619.6	0.0	3,619.6	104,600.0	378.6	0.5	0.2	0.8
07/08/2026 06:00	3,662.5	0.0	3,662.5	104,600.0	383.1	0.5	0.2	0.8
07/08/2026 07:00	3,614.0	11.6	3,614.0	104,600.0	378.0	0.5	0.2	0.8
07/08/2026 08:00	3,623.5	67.6	3,623.5	104,600.0	379.0	0.5	0.2	0.8
07/08/2026 09:00	3,634.3	78.3	3,634.3	104,600.0	380.1	0.5	0.2	0.8
07/08/2026 10:00	3,626.1	107.1	3,626.1	104,600.0	379.3	0.5	0.2	0.8
07/08/2026 11:00	3,615.9	125.3	3,615.9	104,600.0	378.2	0.5	0.2	0.8
07/08/2026 12:00	3,619.5	129.2	3,619.5	104,600.0	378.6	0.5	0.2	0.8
07/08/2026 13:00	3,625.7	78.2	3,625.7	104,600.0	379.2	0.5	0.2	0.8
07/08/2026 14:00	3,623.4	31.7	3,623.4	104,600.0	379.0	0.5	0.2	0.8
07/08/2026 15:00	3,600.6	0.0	3,600.6	104,600.0	376.6	0.5	0.2	0.8
07/08/2026 16:00	3,592.9	13.8	3,592.9	104,600.0	375.8	0.5	0.2	0.8
07/08/2026 17:00	3,857.2	0.0	3,857.2	104,600.0	403.5	0.5	0.2	0.8
07/08/2026 18:00	3,960.2	9.9	3,960.2	104,600.0	414.2	0.5	0.2	0.8
07/08/2026 19:00	3,620.3	0.0	3,620.3	104,600.0	378.7	0.5	0.2	0.8
07/08/2026 20:00	3,618.6	0.0	3,618.6	104,600.0	378.5	0.5	0.2	0.8
07/08/2026 21:00	3,616.8	0.0	3,616.8	104,600.0	378.3	0.5	0.2	0.8
07/08/2026 22:00	3,607.2	0.0	3,607.2	104,600.0	377.3	0.5	0.2	0.8
07/08/2026 23:00	3,598.2	0.0	3,598.2	104,600.0	376.4	0.5	0.2	0.8
Average/Sum#:	3,677.9	27.2	3,677.9	104,600.0	384.7	0.5	0.2	0.8
Minimum:	3,592.9	0.0	3,592.9	104,600.0	375.8	0.5	0.2	0.8
Maximum:	4,358.1	129.2	4,358.1	104,600.0	455.9	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/09/2026 00:00	3,597.4	0.0	3,597.4	104,600.0	376.3	0.5	0.2	0.8
07/09/2026 01:00	3,596.4	0.0	3,596.4	104,600.0	376.2	0.5	0.2	0.8
07/09/2026 02:00	3,594.1	0.0	3,594.1	104,600.0	375.9	0.5	0.2	0.8
07/09/2026 03:00	3,620.1	0.0	3,620.1	104,600.0	378.7	0.5	0.2	0.8
07/09/2026 04:00	3,801.9	0.0	3,801.9	104,600.0	397.7	0.5	0.2	0.8
07/09/2026 05:00	3,842.7	0.0	3,842.7	104,600.0	401.9	0.5	0.2	0.8
07/09/2026 06:00	3,628.0	38.4	3,628.0	104,600.0	379.5	0.5	0.2	0.8
07/09/2026 07:00	3,631.6	84.0	3,631.6	104,600.0	379.9	0.5	0.2	0.8
07/09/2026 08:00	3,620.9	81.5	3,620.9	104,600.0	378.7	0.5	0.2	0.8
07/09/2026 09:00	3,606.9	91.5	3,606.9	104,600.0	377.3	0.5	0.2	0.8
07/09/2026 10:00	3,606.2	113.8	3,606.2	104,600.0	377.2	0.5	0.2	0.8
07/09/2026 11:00	3,614.9	117.4	3,614.9	104,600.0	378.1	0.5	0.2	0.8
07/09/2026 12:00	3,604.8	126.7	3,604.8	104,600.0	377.1	0.5	0.2	0.8
07/09/2026 13:00	3,740.1	105.7	3,740.1	104,600.0	391.2	0.5	0.2	0.8
07/09/2026 14:00	3,595.3	47.3	3,595.3	104,600.0	376.1	0.5	0.2	0.8
07/09/2026 15:00	3,546.0	9.3	3,546.0	104,600.0	370.9	0.4	0.2	0.7
07/09/2026 16:00	3,848.0	58.5	3,848.0	104,600.0	402.5	0.5	0.2	0.8
07/09/2026 17:00	4,001.8	24.0	4,001.8	104,600.0	418.6	0.5	0.3	0.8
07/09/2026 18:00	4,385.8	27.3	4,385.8	104,600.0	458.8	0.6	0.3	0.9
07/09/2026 19:00	4,371.6	0.0	4,371.6	104,600.0	457.3	0.5	0.3	0.9
07/09/2026 20:00	4,058.0	0.0	4,058.0	104,600.0	424.5	0.5	0.3	0.8
07/09/2026 21:00	4,051.2	0.0	4,051.2	104,600.0	423.8	0.5	0.3	0.8
07/09/2026 22:00	4,077.3	0.0	4,077.3	104,600.0	426.5	0.5	0.3	0.9
07/09/2026 23:00	4,023.3	0.0	4,023.3	104,600.0	420.8	0.5	0.3	0.8
Average/Sum#:	3,794.3	38.6	3,794.3	104,600.0	396.9	0.5	0.2	0.8
Minimum:	3,546.0	0.0	3,546.0	104,600.0	370.9	0.4	0.2	0.7
Maximum:	4,385.8	126.7	4,385.8	104,600.0	458.8	0.6	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/10/2026 00:00	3,801.6	0.0	3,801.6	104,600.0	397.6	0.5	0.2	0.8
07/10/2026 01:00	3,671.0	0.0	3,671.0	104,600.0	384.0	0.5	0.2	0.8
07/10/2026 02:00	3,642.6	0.0	3,642.6	104,600.0	381.0	0.5	0.2	0.8
07/10/2026 03:00	4,269.5	0.0	4,269.5	104,600.0	446.6	0.5	0.3	0.9
07/10/2026 04:00	4,026.8	0.0	4,026.8	104,600.0	421.2	0.5	0.3	0.8
07/10/2026 05:00	4,038.1	0.0	4,038.1	104,600.0	422.4	0.5	0.3	0.8
07/10/2026 06:00	3,650.1	8.8	3,650.1	104,600.0	381.8	0.5	0.2	0.8
07/10/2026 07:00	3,647.5	40.5	3,647.5	104,600.0	381.5	0.5	0.2	0.8
07/10/2026 08:00	3,647.0	55.2	3,647.0	104,600.0	381.5	0.5	0.2	0.8
07/10/2026 09:00	3,638.1	47.1	3,638.1	104,600.0	380.5	0.5	0.2	0.8
07/10/2026 10:00	3,619.2	114.1	3,619.2	104,600.0	378.6	0.5	0.2	0.8
07/10/2026 11:00	3,617.4	137.7	3,617.4	104,600.0	378.4	0.5	0.2	0.8
07/10/2026 12:00	3,614.0	121.6	3,614.0	104,600.0	378.0	0.5	0.2	0.8
07/10/2026 13:00	3,602.6	107.9	3,602.6	104,600.0	376.8	0.5	0.2	0.8
07/10/2026 14:00	3,594.3	47.2	3,594.3	104,600.0	376.0	0.5	0.2	0.8
07/10/2026 15:00	3,714.9	1.2	3,714.9	104,600.0	388.6	0.5	0.2	0.8
07/10/2026 16:00	3,854.7	20.9	3,854.7	104,600.0	403.2	0.5	0.2	0.8
07/10/2026 17:00	4,487.3	535.5	4,878.2	104,600.0	510.3	0.6	0.3	1.1
07/10/2026 18:00	4,336.2	977.7	5,313.9	104,600.0	555.8	0.7	0.3	1.1
07/10/2026 19:00	4,358.7	865.4	5,224.1	104,600.0	546.4	0.7	0.3	1.1
07/10/2026 20:00	4,490.1	525.2	5,015.3	104,600.0	524.6	0.6	0.3	1.1
07/10/2026 21:00	4,540.6	445.7	4,986.3	104,600.0	521.6	0.6	0.3	1.0
07/10/2026 22:00	4,572.0	402.7	4,974.7	104,600.0	520.4	0.6	0.3	1.0
07/10/2026 23:00	4,607.4	355.2	4,962.6	104,600.0	519.1	0.6	0.3	1.0
Average/Sum#:	3,960.1	200.4	4,125.2	104,600.0	431.5	0.5	0.2	0.9
Minimum:	3,594.3	0.0	3,594.3	104,600.0	376.0	0.5	0.2	0.8
Maximum:	4,607.4	977.7	5,313.9	104,600.0	555.8	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/11/2026 00:00	4,632.9	317.6	4,950.5	104,600.0	517.8	0.6	0.3	1.0
07/11/2026 01:00	4,651.8	283.0	4,934.8	104,600.0	516.2	0.6	0.3	1.0
07/11/2026 02:00	4,671.2	246.5	4,917.7	104,600.0	514.4	0.6	0.3	1.0
07/11/2026 03:00	4,687.4	222.0	4,909.4	104,600.0	513.5	0.6	0.3	1.0
07/11/2026 04:00	4,449.4	125.7	4,524.8	104,600.0	473.3	0.6	0.3	1.0
07/11/2026 05:00	3,835.7	0.0	3,835.7	104,600.0	401.2	0.5	0.2	0.8
07/11/2026 06:00	3,696.2	16.3	3,696.2	104,600.0	386.6	0.5	0.2	0.8
07/11/2026 07:00	3,627.8	51.6	3,627.8	104,600.0	379.5	0.5	0.2	0.8
07/11/2026 08:00	3,636.7	38.3	3,636.7	104,600.0	380.4	0.5	0.2	0.8
07/11/2026 09:00	3,642.1	48.8	3,642.1	104,600.0	381.0	0.5	0.2	0.8
07/11/2026 10:00	3,624.2	125.6	3,624.2	104,600.0	379.1	0.5	0.2	0.8
07/11/2026 11:00	3,618.0	128.0	3,618.0	104,600.0	378.4	0.5	0.2	0.8
07/11/2026 12:00	3,617.2	111.4	3,617.2	104,600.0	378.4	0.5	0.2	0.8
07/11/2026 13:00	3,595.6	102.8	3,595.6	104,600.0	376.1	0.5	0.2	0.8
07/11/2026 14:00	3,590.7	46.3	3,590.7	104,600.0	375.6	0.5	0.2	0.8
07/11/2026 15:00	3,837.9	17.5	3,837.9	104,600.0	401.4	0.5	0.2	0.8
07/11/2026 16:00	3,764.0	58.6	3,764.0	104,600.0	393.7	0.5	0.2	0.8
07/11/2026 17:00	4,502.4	722.1	5,007.9	104,600.0	523.8	0.7	0.3	1.1
07/11/2026 18:00	4,553.6	523.9	5,077.5	104,600.0	531.1	0.6	0.3	1.1
07/11/2026 19:00	4,528.3	489.0	5,017.3	104,600.0	524.8	0.6	0.3	1.0
07/11/2026 20:00	4,422.4	649.0	5,071.4	104,600.0	530.5	0.6	0.3	1.1
07/11/2026 21:00	4,446.1	818.2	5,264.3	104,600.0	550.6	0.7	0.3	1.1
07/11/2026 22:00	4,468.4	567.3	5,035.7	104,600.0	526.7	0.6	0.3	1.1
07/11/2026 23:00	4,488.5	1,127.2	5,615.7	104,600.0	587.4	0.7	0.4	1.2
Average/Sum#:	4,107.9	284.9	4,350.5	104,600.0	455.1	0.6	0.3	0.9
Minimum:	3,590.7	0.0	3,590.7	104,600.0	375.6	0.5	0.2	0.8
Maximum:	4,687.4	1,127.2	5,615.7	104,600.0	587.4	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/12/2026 00:00	4,502.5	501.3	5,003.8	104,600.0	523.4	0.6	0.3	1.0
07/12/2026 01:00	4,520.6	467.7	4,988.3	104,600.0	521.8	0.6	0.3	1.0
07/12/2026 02:00	4,535.9	444.7	4,980.6	104,600.0	521.0	0.6	0.3	1.0
07/12/2026 03:00	4,536.5	442.9	4,979.4	104,600.0	520.8	0.6	0.3	1.0
07/12/2026 04:00	4,553.8	417.4	4,971.2	104,600.0	520.0	0.6	0.3	1.0
07/12/2026 05:00	4,546.1	419.9	4,966.0	104,600.0	519.4	0.6	0.3	1.0
07/12/2026 06:00	4,585.5	435.6	5,021.1	104,600.0	525.2	0.6	0.3	1.0
07/12/2026 07:00	4,536.6	1,037.6	5,574.2	104,600.0	583.1	0.7	0.3	1.2
07/12/2026 08:00	4,507.2	1,290.3	5,797.5	104,600.0	606.4	0.7	0.4	1.2
07/12/2026 09:00	4,492.5	642.5	5,135.0	104,600.0	537.1	0.6	0.3	1.1
07/12/2026 10:00	4,482.9	486.6	4,969.5	104,600.0	519.8	0.6	0.3	1.0
07/12/2026 11:00	4,412.1	606.2	5,018.3	104,600.0	524.9	0.6	0.3	1.0
07/12/2026 12:00	4,327.9	751.5	5,079.4	104,600.0	531.3	0.6	0.3	1.1
07/12/2026 13:00	4,310.8	1,230.2	5,541.0	104,600.0	579.6	0.7	0.3	1.2
07/12/2026 14:00	4,529.4	1,342.7	5,872.1	104,600.0	614.2	0.7	0.4	1.2
07/12/2026 15:00	4,522.4	1,660.0	6,182.4	104,600.0	646.7	0.8	0.4	1.3
07/12/2026 16:00	4,532.9	1,652.2	6,185.1	104,600.0	647.0	0.8	0.4	1.3
07/12/2026 17:00	4,536.5	989.4	5,525.9	104,600.0	578.0	0.7	0.3	1.2
07/12/2026 18:00	4,550.9	639.1	5,190.0	104,600.0	542.9	0.7	0.3	1.1
07/12/2026 19:00	4,561.3	1,537.2	6,098.5	104,600.0	637.9	0.8	0.4	1.3
07/12/2026 20:00	4,573.5	1,671.0	6,244.5	104,600.0	653.2	0.8	0.4	1.3
07/12/2026 21:00	4,573.0	1,643.9	6,216.9	104,600.0	650.3	0.8	0.4	1.3
07/12/2026 22:00	4,576.5	1,029.2	5,605.7	104,600.0	586.4	0.7	0.4	1.2
07/12/2026 23:00	3,782.2	1.2	3,782.2	104,600.0	395.6	0.5	0.2	0.8
Average/Sum#:	4,482.9	889.2	5,372.0	104,600.0	561.9	0.7	0.3	1.1
Minimum:	3,782.2	1.2	3,782.2	104,600.0	395.6	0.5	0.2	0.8
Maximum:	4,585.5	1,671.0	6,244.5	104,600.0	653.2	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/13/2026 00:00	3,904.1	0.0	3,904.1	104,600.0	408.4	0.5	0.2	0.8
07/13/2026 01:00	4,379.4	0.0	4,379.4	104,600.0	458.1	0.5	0.3	0.9
07/13/2026 02:00	4,383.3	0.0	4,383.3	104,600.0	458.5	0.5	0.3	0.9
07/13/2026 03:00	4,285.8	0.0	4,285.8	104,600.0	448.3	0.5	0.3	0.9
07/13/2026 04:00	4,355.4	0.0	4,355.4	104,600.0	455.6	0.5	0.3	0.9
07/13/2026 05:00	4,059.4	0.0	4,059.4	104,600.0	424.6	0.5	0.3	0.8
07/13/2026 06:00	4,358.1	41.7	4,358.1	104,600.0	455.9	0.6	0.3	0.9
07/13/2026 07:00	4,301.8	26.4	4,302.6	104,600.0	450.1	0.5	0.3	0.9
07/13/2026 08:00	4,377.2	1,150.4	5,527.6	104,600.0	578.2	0.7	0.3	1.2
07/13/2026 09:00	4,488.1	1,798.9	6,287.0	104,600.0	657.6	0.8	0.4	1.3
07/13/2026 10:00	4,537.7	1,732.0	6,269.7	104,600.0	655.8	0.8	0.4	1.3
07/13/2026 11:00	4,532.1	1,728.1	6,260.2	104,600.0	654.8	0.8	0.4	1.3
07/13/2026 12:00	4,518.7	1,731.9	6,250.6	104,600.0	653.8	0.8	0.4	1.3
07/13/2026 13:00	4,509.4	1,772.5	6,281.9	104,600.0	657.1	0.8	0.4	1.3
07/13/2026 14:00	4,518.2	1,757.8	6,276.0	104,600.0	656.5	0.8	0.4	1.3
07/13/2026 15:00	4,504.8	1,771.7	6,276.5	104,600.0	656.5	0.8	0.4	1.3
07/13/2026 16:00	4,504.4	1,773.1	6,277.5	104,600.0	656.6	0.8	0.4	1.3
07/13/2026 17:00	4,498.1	1,729.0	6,227.1	104,600.0	651.4	0.8	0.4	1.3
07/13/2026 18:00	4,498.4	1,719.4	6,217.8	104,600.0	650.4	0.8	0.4	1.3
07/13/2026 19:00	4,522.8	1,741.8	6,264.6	104,600.0	655.3	0.8	0.4	1.3
07/13/2026 20:00	4,566.0	1,660.5	6,226.5	104,600.0	651.3	0.8	0.4	1.3
07/13/2026 21:00	4,594.5	1,494.0	6,088.5	104,600.0	636.9	0.8	0.4	1.3
07/13/2026 22:00	4,591.7	744.4	5,336.1	104,600.0	558.2	0.7	0.3	1.1
07/13/2026 23:00	4,606.7	503.9	5,110.6	104,600.0	534.6	0.6	0.3	1.1
Average/Sum#:	4,433.2	1,036.6	5,466.9	104,600.0	571.9	0.7	0.4	1.1
Minimum:	3,904.1	0.0	3,904.1	104,600.0	408.4	0.5	0.2	0.8
Maximum:	4,606.7	1,798.9	6,287.0	104,600.0	657.6	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/14/2026 00:00	4,615.2	770.6	5,385.8	104,600.0	563.4	0.7	0.3	1.1
07/14/2026 01:00	4,532.3	460.4	4,992.7	104,600.0	522.2	0.6	0.3	1.0
07/14/2026 02:00	4,455.1	548.0	5,003.1	104,600.0	523.3	0.6	0.3	1.0
07/14/2026 03:00	4,491.0	496.7	4,987.7	104,600.0	521.7	0.6	0.3	1.0
07/14/2026 04:00	4,505.7	486.8	4,992.5	104,600.0	522.2	0.6	0.3	1.0
07/14/2026 05:00	4,525.7	758.7	5,284.4	104,600.0	552.7	0.7	0.3	1.1
07/14/2026 06:00	4,507.9	448.1	4,956.0	104,600.0	518.4	0.6	0.3	1.0
07/14/2026 07:00	4,444.2	537.9	4,982.1	104,600.0	521.1	0.6	0.3	1.0
07/14/2026 08:00	4,360.2	661.9	5,022.1	104,600.0	525.3	0.6	0.3	1.1
07/14/2026 09:00	4,227.3	870.3	5,097.6	104,600.0	533.2	0.6	0.3	1.1
07/14/2026 10:00	4,117.4	1,027.2	5,144.6	104,600.0	538.1	0.6	0.3	1.1
07/14/2026 11:00	4,005.9	1,206.7	5,212.6	104,600.0	545.2	0.7	0.3	1.1
07/14/2026 12:00	4,436.6	868.3	5,304.9	104,600.0	554.9	0.7	0.3	1.1
07/14/2026 13:00	4,457.5	1,137.5	5,595.0	104,600.0	585.2	0.7	0.4	1.2
07/14/2026 14:00	4,454.2	1,520.2	5,974.4	104,600.0	624.9	0.7	0.4	1.2
07/14/2026 15:00	4,458.1	1,682.0	6,140.1	104,600.0	642.3	0.8	0.4	1.3
07/14/2026 16:00	4,443.3	1,655.6	6,098.9	104,600.0	637.9	0.8	0.4	1.3
07/14/2026 17:00	4,441.0	1,749.2	6,190.2	104,600.0	647.5	0.8	0.4	1.3
07/14/2026 18:00	4,448.8	1,717.0	6,165.8	104,600.0	644.9	0.8	0.4	1.3
07/14/2026 19:00	4,460.8	1,541.4	6,002.2	104,600.0	627.8	0.8	0.4	1.3
07/14/2026 20:00	4,521.6	1,246.0	5,767.6	104,600.0	603.3	0.7	0.4	1.2
07/14/2026 21:00	4,547.7	1,328.4	5,876.1	104,600.0	614.6	0.7	0.4	1.2
07/14/2026 22:00	4,566.5	736.4	5,302.9	104,600.0	554.7	0.7	0.3	1.1
07/14/2026 23:00	4,600.5	392.1	4,992.6	104,600.0	522.2	0.6	0.3	1.0
Average/Sum#:	4,442.7	993.6	5,436.3	104,600.0	568.6	0.7	0.3	1.1
Minimum:	4,005.9	392.1	4,956.0	104,600.0	518.4	0.6	0.3	1.0
Maximum:	4,615.2	1,749.2	6,190.2	104,600.0	647.5	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/15/2026 00:00	4,498.6	522.3	5,020.9	104,600.0	525.2	0.6	0.3	1.1
07/15/2026 01:00	4,404.5	603.8	5,008.3	104,600.0	523.9	0.6	0.3	1.0
07/15/2026 02:00	4,414.6	561.5	4,976.1	104,600.0	520.5	0.6	0.3	1.0
07/15/2026 03:00	4,433.9	526.1	4,960.0	104,600.0	518.8	0.6	0.3	1.0
07/15/2026 04:00	4,456.1	500.0	4,956.1	104,600.0	518.4	0.6	0.3	1.0
07/15/2026 05:00	4,487.3	479.6	4,966.9	104,600.0	519.5	0.6	0.3	1.0
07/15/2026 06:00	4,475.6	515.5	4,991.1	104,600.0	522.1	0.6	0.3	1.0
07/15/2026 07:00	4,413.6	618.2	5,031.8	104,600.0	526.3	0.6	0.3	1.1
07/15/2026 08:00	4,314.1	768.2	5,082.3	104,600.0	531.6	0.6	0.3	1.1
07/15/2026 09:00	4,174.0	982.8	5,156.8	104,600.0	539.4	0.6	0.3	1.1
07/15/2026 10:00	4,375.8	1,742.4	6,118.2	104,600.0	640.0	0.8	0.4	1.3
07/15/2026 11:00	4,462.8	1,731.8	6,194.6	104,600.0	648.0	0.8	0.4	1.3
07/15/2026 12:00	4,450.6	1,240.9	5,691.5	104,600.0	595.3	0.7	0.4	1.2
07/15/2026 13:00	4,445.4	1,458.5	5,903.9	104,600.0	617.5	0.7	0.4	1.2
07/15/2026 14:00	4,433.1	1,869.2	6,302.3	104,600.0	659.2	0.8	0.4	1.3
07/15/2026 15:00	4,425.4	1,713.5	6,138.9	104,600.0	642.1	0.8	0.4	1.3
07/15/2026 16:00	4,441.1	1,932.2	6,373.3	104,600.0	666.6	0.8	0.4	1.3
07/15/2026 17:00	4,442.3	1,789.7	6,232.0	104,600.0	651.9	0.8	0.4	1.3
07/15/2026 18:00	4,481.0	1,790.5	6,271.5	104,600.0	656.0	0.8	0.4	1.3
07/15/2026 19:00	4,540.1	1,589.3	6,129.4	104,600.0	641.1	0.8	0.4	1.3
07/15/2026 20:00	4,572.0	1,378.3	5,950.3	104,600.0	622.4	0.7	0.4	1.2
07/15/2026 21:00	4,594.4	1,145.0	5,739.4	104,600.0	600.3	0.7	0.4	1.2
07/15/2026 22:00	4,427.9	776.7	5,204.6	104,600.0	544.4	0.7	0.3	1.1
07/15/2026 23:00	4,465.1	628.0	5,093.1	104,600.0	532.7	0.6	0.3	1.1
Average/Sum#:	4,442.9	1,119.3	5,562.2	104,600.0	581.8	0.7	0.4	1.2
Minimum:	4,174.0	479.6	4,956.1	104,600.0	518.4	0.6	0.3	1.0
Maximum:	4,594.4	1,932.2	6,373.3	104,600.0	666.6	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/16/2026 00:00	4,498.6	578.2	5,076.8	104,600.0	531.0	0.6	0.3	1.1
07/16/2026 01:00	4,526.7	516.7	5,043.4	104,600.0	527.5	0.6	0.3	1.1
07/16/2026 02:00	4,556.9	423.0	4,979.9	104,600.0	520.9	0.6	0.3	1.0
07/16/2026 03:00	4,588.7	375.4	4,964.1	104,600.0	519.2	0.6	0.3	1.0
07/16/2026 04:00	4,609.6	362.0	4,971.6	104,600.0	520.0	0.6	0.3	1.0
07/16/2026 05:00	4,614.9	352.4	4,967.3	104,600.0	519.6	0.6	0.3	1.0
07/16/2026 06:00	4,600.1	366.0	4,966.1	104,600.0	519.5	0.6	0.3	1.0
07/16/2026 07:00	4,551.3	434.4	4,985.7	104,600.0	521.5	0.6	0.3	1.0
07/16/2026 08:00	4,495.5	513.1	5,008.6	104,600.0	523.9	0.6	0.3	1.0
07/16/2026 09:00	4,436.1	591.1	5,027.2	104,600.0	525.8	0.6	0.3	1.1
07/16/2026 10:00	4,358.3	711.9	5,070.2	104,600.0	530.3	0.6	0.3	1.1
07/16/2026 11:00	4,237.3	867.2	5,104.5	105,300.0	537.5	0.6	0.3	1.1
07/16/2026 12:00	4,098.0	1,104.1	5,202.1	105,300.0	547.8	0.7	0.3	1.1
07/16/2026 13:00	4,033.6	1,174.1	5,207.7	105,300.0	548.4	0.7	0.3	1.1
07/16/2026 14:00	3,981.5	1,246.3	5,227.8	105,300.0	550.5	0.7	0.3	1.1
07/16/2026 15:00	3,943.0	1,318.6	5,261.6	105,300.0	554.0	0.7	0.3	1.1
07/16/2026 16:00	3,979.2	1,264.1	5,243.3	105,300.0	552.1	0.7	0.3	1.1
07/16/2026 17:00	4,064.0	1,172.8	5,236.8	105,300.0	551.4	0.7	0.3	1.1
07/16/2026 18:00	4,175.8	977.3	5,153.1	105,300.0	542.6	0.7	0.3	1.1
07/16/2026 19:00	4,344.2	731.9	5,076.1	105,300.0	534.5	0.6	0.3	1.1
07/16/2026 20:00	4,439.8	574.2	5,014.0	105,300.0	528.0	0.6	0.3	1.1
07/16/2026 21:00	4,487.3	500.9	4,988.2	105,300.0	525.3	0.6	0.3	1.1
07/16/2026 22:00	4,524.2	447.2	4,971.4	105,300.0	523.5	0.6	0.3	1.0
07/16/2026 23:00	4,558.9	394.2	4,953.1	105,300.0	521.6	0.6	0.3	1.0
Average/Sum#:	4,362.6	708.2	5,070.9	104,979.2	532.4	0.6	0.3	1.1
Minimum:	3,943.0	352.4	4,953.1	104,600.0	519.2	0.6	0.3	1.0
Maximum:	4,614.9	1,318.6	5,261.6	105,300.0	554.0	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/17/2026 00:00	4,587.6	363.7	4,951.3	105,300.0	521.4	0.6	0.3	1.0
07/17/2026 01:00	4,614.6	323.4	4,938.0	105,300.0	520.0	0.6	0.3	1.0
07/17/2026 02:00	4,629.7	321.6	4,951.3	105,300.0	521.4	0.6	0.3	1.0
07/17/2026 03:00	4,647.6	304.3	4,951.9	105,300.0	521.4	0.6	0.3	1.0
07/17/2026 04:00	4,674.5	264.3	4,938.8	105,300.0	520.1	0.6	0.3	1.0
07/17/2026 05:00	4,689.2	247.8	4,937.0	105,300.0	519.9	0.6	0.3	1.0
07/17/2026 06:00	4,670.6	282.0	4,952.6	105,300.0	521.5	0.6	0.3	1.0
07/17/2026 07:00	4,636.5	336.5	4,973.0	105,300.0	523.7	0.6	0.3	1.0
07/17/2026 08:00	4,584.0	413.3	4,997.3	105,300.0	526.2	0.6	0.3	1.1
07/17/2026 09:00	4,535.4	457.5	4,992.9	105,300.0	525.8	0.6	0.3	1.1
07/17/2026 10:00	4,474.6	532.5	5,007.1	105,300.0	527.2	0.6	0.3	1.1
07/17/2026 11:00	4,390.8	664.7	5,055.5	105,300.0	532.3	0.6	0.3	1.1
07/17/2026 12:00	4,246.4	853.3	5,099.7	105,300.0	537.0	0.6	0.3	1.1
07/17/2026 13:00	4,134.3	1,029.6	5,163.9	105,300.0	543.8	0.7	0.3	1.1
07/17/2026 14:00	4,038.5	1,178.6	5,217.1	105,300.0	549.4	0.7	0.3	1.1
07/17/2026 15:00	4,013.5	1,188.7	5,202.2	105,300.0	547.8	0.7	0.3	1.1
07/17/2026 16:00	4,002.4	1,204.4	5,206.8	105,300.0	548.3	0.7	0.3	1.1
07/17/2026 17:00	4,086.1	1,068.2	5,154.3	105,300.0	542.7	0.7	0.3	1.1
07/17/2026 18:00	4,252.6	808.8	5,061.4	105,300.0	533.0	0.6	0.3	1.1
07/17/2026 19:00	4,419.2	577.0	4,996.2	105,300.0	526.1	0.6	0.3	1.1
07/17/2026 20:00	4,501.2	469.5	4,970.7	105,300.0	523.4	0.6	0.3	1.0
07/17/2026 21:00	4,544.1	416.0	4,960.1	105,300.0	522.3	0.6	0.3	1.0
07/17/2026 22:00	4,587.7	357.1	4,944.8	105,300.0	520.7	0.6	0.3	1.0
07/17/2026 23:00	4,615.4	315.1	4,930.5	105,300.0	519.2	0.6	0.3	1.0
Average/Sum#:	4,440.7	582.4	5,023.1	105,300.0	528.9	0.6	0.3	1.1
Minimum:	4,002.4	247.8	4,930.5	105,300.0	519.2	0.6	0.3	1.0
Maximum:	4,689.2	1,204.4	5,217.1	105,300.0	549.4	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/18/2026 00:00	4,646.9	268.4	4,915.3	105,300.0	517.6	0.6	0.3	1.0
07/18/2026 01:00	4,664.1	240.5	4,904.6	105,300.0	516.5	0.6	0.3	1.0
07/18/2026 02:00	4,696.0	202.1	4,898.1	105,300.0	515.8	0.6	0.3	1.0
07/18/2026 03:00	4,725.5	173.7	4,899.2	105,300.0	515.9	0.6	0.3	1.0
07/18/2026 04:00	4,743.6	139.5	4,883.1	105,300.0	514.2	0.6	0.3	1.0
07/18/2026 05:00	4,749.6	305.7	5,030.8	105,300.0	529.7	0.6	0.3	1.1
07/18/2026 06:00	4,748.8	151.5	4,900.3	105,300.0	516.0	0.6	0.3	1.0
07/18/2026 07:00	4,726.4	198.6	4,925.0	105,300.0	518.6	0.6	0.3	1.0
07/18/2026 08:00	4,671.3	286.7	4,958.0	105,300.0	522.1	0.6	0.3	1.0
07/18/2026 09:00	4,601.8	374.7	4,976.5	105,300.0	524.0	0.6	0.3	1.0
07/18/2026 10:00	4,545.5	442.5	4,988.0	105,300.0	525.2	0.6	0.3	1.1
07/18/2026 11:00	4,166.2	347.1	4,346.7	105,300.0	457.7	0.6	0.3	1.0
07/18/2026 12:00	3,561.4	149.0	3,561.4	105,300.0	375.0	0.5	0.2	0.8
07/18/2026 13:00	3,775.3	123.4	3,790.1	105,300.0	399.1	0.5	0.2	0.8
07/18/2026 14:00	4,178.2	958.1	5,136.3	105,300.0	540.9	0.6	0.3	1.1
07/18/2026 15:00	4,108.0	1,036.2	5,144.2	105,300.0	541.7	0.7	0.3	1.1
07/18/2026 16:00	4,076.1	1,075.8	5,151.9	105,300.0	542.5	0.7	0.3	1.1
07/18/2026 17:00	4,075.5	1,077.1	5,152.6	105,300.0	542.6	0.7	0.3	1.1
07/18/2026 18:00	4,155.7	962.9	5,118.6	105,300.0	539.0	0.6	0.3	1.1
07/18/2026 19:00	4,325.1	715.3	5,040.4	105,300.0	530.8	0.6	0.3	1.1
07/18/2026 20:00	4,430.2	593.9	5,024.1	105,300.0	529.0	0.6	0.3	1.1
07/18/2026 21:00	4,473.7	557.3	5,031.0	105,300.0	529.8	0.6	0.3	1.1
07/18/2026 22:00	4,507.5	501.2	5,008.7	105,300.0	527.4	0.6	0.3	1.1
07/18/2026 23:00	4,548.1	444.6	4,992.7	105,300.0	525.7	0.6	0.3	1.1
Average/Sum#:	4,412.5	471.9	4,865.7	105,300.0	512.4	0.6	0.3	1.0
Minimum:	3,561.4	123.4	3,561.4	105,300.0	375.0	0.5	0.2	0.8
Maximum:	4,749.6	1,077.1	5,152.6	105,300.0	542.6	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/19/2026 00:00	4,591.5	393.0	4,984.5	105,300.0	524.9	0.6	0.3	1.0
07/19/2026 01:00	4,623.2	346.0	4,969.2	105,300.0	523.3	0.6	0.3	1.0
07/19/2026 02:00	4,647.2	305.9	4,953.1	105,300.0	521.6	0.6	0.3	1.0
07/19/2026 03:00	4,659.7	277.3	4,937.0	105,300.0	519.9	0.6	0.3	1.0
07/19/2026 04:00	4,672.1	249.1	4,921.2	105,300.0	518.2	0.6	0.3	1.0
07/19/2026 05:00	4,681.3	239.8	4,921.1	105,300.0	518.2	0.6	0.3	1.0
07/19/2026 06:00	4,674.9	261.8	4,936.7	105,300.0	519.8	0.6	0.3	1.0
07/19/2026 07:00	4,639.7	307.6	4,947.3	105,300.0	521.0	0.6	0.3	1.0
07/19/2026 08:00	4,581.1	382.4	4,963.5	105,300.0	522.7	0.6	0.3	1.0
07/19/2026 09:00	4,517.0	460.0	4,977.0	105,300.0	524.1	0.6	0.3	1.0
07/19/2026 10:00	4,458.4	558.1	5,016.5	105,300.0	528.2	0.6	0.3	1.1
07/19/2026 11:00	4,316.9	744.8	5,061.7	105,300.0	533.0	0.6	0.3	1.1
07/19/2026 12:00	4,193.7	951.0	5,144.7	105,300.0	541.7	0.7	0.3	1.1
07/19/2026 13:00	4,133.6	1,048.2	5,181.8	105,300.0	545.6	0.7	0.3	1.1
07/19/2026 14:00	4,072.9	1,130.4	5,203.3	105,300.0	547.9	0.7	0.3	1.1
07/19/2026 15:00	4,009.5	1,220.3	5,229.8	105,300.0	550.7	0.7	0.3	1.1
07/19/2026 16:00	4,008.7	1,271.6	5,280.3	105,300.0	556.0	0.7	0.3	1.1
07/19/2026 17:00	4,217.7	1,528.2	5,745.9	105,300.0	605.0	0.7	0.4	1.2
07/19/2026 18:00	4,534.2	1,348.0	5,882.2	105,300.0	619.4	0.7	0.4	1.2
07/19/2026 19:00	4,620.1	1,124.1	5,744.2	105,300.0	604.9	0.7	0.4	1.2
07/19/2026 20:00	4,638.8	1,553.3	6,192.1	105,300.0	652.0	0.8	0.4	1.3
07/19/2026 21:00	4,632.2	1,597.4	6,229.6	105,300.0	656.0	0.8	0.4	1.3
07/19/2026 22:00	4,634.9	1,532.8	6,167.7	105,300.0	649.5	0.8	0.4	1.3
07/19/2026 23:00	4,650.4	1,482.7	6,133.1	105,300.0	645.8	0.8	0.4	1.3
Average/Sum#:	4,475.4	846.4	5,321.8	105,300.0	560.4	0.7	0.3	1.1
Minimum:	4,008.7	239.8	4,921.1	105,300.0	518.2	0.6	0.3	1.0
Maximum:	4,681.3	1,597.4	6,229.6	105,300.0	656.0	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/20/2026 00:00	4,677.4	730.3	5,407.7	105,300.0	569.4	0.7	0.3	1.1
07/20/2026 01:00	4,562.4	422.3	4,984.7	105,300.0	524.9	0.6	0.3	1.0
07/20/2026 02:00	4,555.9	651.7	5,207.6	105,300.0	548.4	0.7	0.3	1.1
07/20/2026 03:00	4,563.9	1,597.8	6,161.7	105,300.0	648.8	0.8	0.4	1.3
07/20/2026 04:00	4,569.9	1,692.5	6,262.4	105,300.0	659.4	0.8	0.4	1.3
07/20/2026 05:00	4,590.6	1,651.2	6,241.8	105,300.0	657.3	0.8	0.4	1.3
07/20/2026 06:00	4,585.6	1,529.5	6,115.1	105,300.0	643.9	0.8	0.4	1.3
07/20/2026 07:00	4,567.4	1,423.7	5,991.1	105,300.0	630.9	0.8	0.4	1.3
07/20/2026 08:00	4,537.4	1,480.1	6,017.5	105,300.0	633.6	0.8	0.4	1.3
07/20/2026 09:00	4,490.4	1,321.4	5,811.8	105,300.0	612.0	0.7	0.4	1.2
07/20/2026 10:00	4,563.0	1,519.2	6,082.2	105,300.0	640.5	0.8	0.4	1.3
07/20/2026 11:00	4,594.0	1,440.7	6,034.7	105,300.0	635.5	0.8	0.4	1.3
07/20/2026 12:00	4,564.7	1,359.7	5,924.4	105,300.0	623.8	0.7	0.4	1.2
07/20/2026 13:00	4,550.8	1,567.7	6,118.5	105,300.0	644.3	0.8	0.4	1.3
07/20/2026 14:00	4,528.7	1,341.0	5,869.7	105,300.0	618.1	0.7	0.4	1.2
07/20/2026 15:00	4,532.7	1,348.8	5,881.5	105,300.0	619.3	0.7	0.4	1.2
07/20/2026 16:00	4,552.4	1,424.5	5,976.9	105,300.0	629.4	0.8	0.4	1.3
07/20/2026 17:00	4,569.1	1,406.0	5,975.1	105,300.0	629.2	0.8	0.4	1.3
07/20/2026 18:00	4,603.7	1,537.6	6,141.3	105,300.0	646.7	0.8	0.4	1.3
07/20/2026 19:00	4,624.2	1,413.4	6,037.6	105,300.0	635.8	0.8	0.4	1.3
07/20/2026 20:00	4,618.7	1,500.9	6,119.6	105,300.0	644.4	0.8	0.4	1.3
07/20/2026 21:00	4,617.4	1,340.1	5,957.5	105,300.0	627.3	0.8	0.4	1.3
07/20/2026 22:00	4,607.8	750.1	5,357.9	105,300.0	564.2	0.7	0.3	1.1
07/20/2026 23:00	4,453.5	1,015.3	5,468.8	105,300.0	575.9	0.7	0.3	1.2
Average/Sum#:	4,570.1	1,311.1	5,881.1	105,300.0	619.3	0.8	0.4	1.2
Minimum:	4,453.5	422.3	4,984.7	105,300.0	524.9	0.6	0.3	1.0
Maximum:	4,677.4	1,692.5	6,262.4	105,300.0	659.4	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/21/2026 00:00	4,457.0	560.7	5,017.7	105,300.0	528.4	0.6	0.3	1.1
07/21/2026 01:00	4,468.2	567.9	5,036.1	105,300.0	530.3	0.6	0.3	1.1
07/21/2026 02:00	4,482.8	555.5	5,038.3	105,300.0	530.5	0.6	0.3	1.1
07/21/2026 03:00	4,506.8	508.3	5,015.1	105,300.0	528.1	0.6	0.3	1.1
07/21/2026 04:00	4,513.4	739.2	5,252.6	105,300.0	553.1	0.7	0.3	1.1
07/21/2026 05:00	4,519.4	1,385.2	5,904.6	105,300.0	621.8	0.7	0.4	1.2
07/21/2026 06:00	4,510.3	886.0	5,396.3	105,300.0	568.2	0.7	0.3	1.1
07/21/2026 07:00	4,483.8	723.5	5,207.3	105,300.0	548.3	0.7	0.3	1.1
07/21/2026 08:00	4,431.7	896.5	5,328.2	105,300.0	561.1	0.7	0.3	1.1
07/21/2026 09:00	4,288.7	855.8	5,144.5	105,300.0	541.7	0.7	0.3	1.1
07/21/2026 10:00	4,123.2	1,118.0	5,241.2	105,300.0	551.9	0.7	0.3	1.1
07/21/2026 11:00	4,195.0	1,418.8	5,613.8	105,300.0	591.1	0.7	0.4	1.2
07/21/2026 12:00	4,519.2	1,669.0	6,188.2	105,300.0	651.6	0.8	0.4	1.3
07/21/2026 13:00	4,490.4	1,603.7	6,094.1	105,300.0	641.7	0.8	0.4	1.3
07/21/2026 14:00	4,479.0	1,654.1	6,133.1	105,300.0	645.8	0.8	0.4	1.3
07/21/2026 15:00	4,453.9	1,767.8	6,221.7	105,300.0	655.1	0.8	0.4	1.3
07/21/2026 16:00	4,453.3	1,648.1	6,101.4	105,300.0	642.5	0.8	0.4	1.3
07/21/2026 17:00	4,452.5	1,736.1	6,188.6	105,300.0	651.7	0.8	0.4	1.3
07/21/2026 18:00	4,446.1	1,861.2	6,307.3	105,300.0	664.2	0.8	0.4	1.3
07/21/2026 19:00	4,469.3	1,825.9	6,295.2	105,300.0	662.9	0.8	0.4	1.3
07/21/2026 20:00	4,526.3	1,718.9	6,245.2	105,300.0	657.6	0.8	0.4	1.3
07/21/2026 21:00	4,569.9	1,569.5	6,139.4	105,300.0	646.5	0.8	0.4	1.3
07/21/2026 22:00	4,577.6	1,440.0	6,017.6	105,300.0	633.7	0.8	0.4	1.3
07/21/2026 23:00	4,595.3	1,290.8	5,886.1	105,300.0	619.8	0.7	0.4	1.2
Average/Sum#:	4,458.9	1,250.0	5,708.9	105,300.0	601.2	0.7	0.4	1.2
Minimum:	4,123.2	508.3	5,015.1	105,300.0	528.1	0.6	0.3	1.1
Maximum:	4,595.3	1,861.2	6,307.3	105,300.0	664.2	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/22/2026 00:00	4,497.6	489.9	4,987.5	105,300.0	525.2	0.6	0.3	1.0
07/22/2026 01:00	4,495.4	489.4	4,984.8	105,300.0	524.9	0.6	0.3	1.1
07/22/2026 02:00	4,523.7	456.2	4,979.9	105,300.0	524.4	0.6	0.3	1.0
07/22/2026 03:00	4,556.3	412.8	4,969.1	105,300.0	523.2	0.6	0.3	1.0
07/22/2026 04:00	4,571.5	445.3	5,016.8	105,300.0	528.3	0.6	0.3	1.1
07/22/2026 05:00	4,575.1	706.7	5,281.8	105,300.0	556.2	0.7	0.3	1.1
07/22/2026 06:00	4,552.9	409.3	4,962.2	105,300.0	522.5	0.6	0.3	1.0
07/22/2026 07:00	4,538.5	534.8	5,073.3	105,300.0	534.2	0.6	0.3	1.1
07/22/2026 08:00	4,528.0	899.4	5,427.4	105,300.0	571.5	0.7	0.3	1.1
07/22/2026 09:00	4,501.9	466.4	4,968.3	105,300.0	523.2	0.6	0.3	1.0
07/22/2026 10:00	4,457.1	527.2	4,984.3	105,300.0	524.8	0.6	0.3	1.0
07/22/2026 11:00	4,428.7	577.9	5,006.6	105,300.0	527.2	0.6	0.3	1.1
07/22/2026 12:00	4,397.3	631.4	5,028.7	105,300.0	529.5	0.6	0.3	1.1
07/22/2026 13:00	4,328.3	724.1	5,052.4	105,300.0	532.0	0.6	0.3	1.1
07/22/2026 14:00	4,254.0	817.4	5,071.4	105,300.0	534.0	0.6	0.3	1.1
07/22/2026 15:00	4,234.0	832.6	5,066.6	105,300.0	533.5	0.6	0.3	1.1
07/22/2026 16:00	4,197.3	878.3	5,075.6	105,300.0	534.5	0.6	0.3	1.1
07/22/2026 17:00	4,222.9	833.4	5,056.3	105,300.0	532.4	0.6	0.3	1.1
07/22/2026 18:00	4,319.6	696.9	5,016.5	105,300.0	528.2	0.6	0.3	1.1
07/22/2026 19:00	4,432.4	544.7	4,977.1	105,300.0	524.1	0.6	0.3	1.0
07/22/2026 20:00	4,509.1	435.1	4,944.2	105,300.0	520.6	0.6	0.3	1.0
07/22/2026 21:00	4,558.0	368.0	4,926.0	105,300.0	518.7	0.6	0.3	1.0
07/22/2026 22:00	4,606.6	313.0	4,919.6	105,300.0	518.0	0.6	0.3	1.0
07/22/2026 23:00	4,633.2	273.8	4,907.0	105,300.0	516.7	0.6	0.3	1.0
Average/Sum#:	4,455.0	573.5	5,028.5	105,300.0	529.5	0.6	0.3	1.1
Minimum:	4,197.3	273.8	4,907.0	105,300.0	516.7	0.6	0.3	1.0
Maximum:	4,633.2	899.4	5,427.4	105,300.0	571.5	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/23/2026 00:00	4,655.6	252.0	4,907.6	105,300.0	516.8	0.6	0.3	1.0
07/23/2026 01:00	4,666.4	238.8	4,905.2	105,300.0	516.5	0.6	0.3	1.0
07/23/2026 02:00	4,680.8	212.2	4,893.0	105,300.0	515.2	0.6	0.3	1.0
07/23/2026 03:00	4,689.6	204.4	4,894.0	105,300.0	515.3	0.6	0.3	1.0
07/23/2026 04:00	4,700.5	199.3	4,899.8	105,300.0	515.9	0.6	0.3	1.0
07/23/2026 05:00	4,703.7	197.3	4,901.0	105,300.0	516.1	0.6	0.3	1.0
07/23/2026 06:00	4,691.2	237.4	4,928.6	105,300.0	519.0	0.6	0.3	1.0
07/23/2026 07:00	4,660.3	281.6	4,941.9	105,300.0	520.4	0.6	0.3	1.0
07/23/2026 08:00	4,553.5	274.9	4,765.2	105,300.0	501.8	0.6	0.3	1.0
07/23/2026 09:00	3,593.6	61.9	3,593.6	105,300.0	378.4	0.5	0.2	0.8
07/23/2026 10:00	3,567.2	77.9	3,567.2	105,300.0	375.6	0.5	0.2	0.8
07/23/2026 11:00	4,220.8	385.8	4,406.0	105,300.0	464.0	0.6	0.3	1.0
07/23/2026 12:00	4,311.2	755.8	5,067.0	105,300.0	533.6	0.6	0.3	1.1
07/23/2026 13:00	4,219.7	882.7	5,102.4	105,300.0	537.3	0.6	0.3	1.1
07/23/2026 14:00	4,153.9	967.6	5,121.5	105,300.0	539.3	0.6	0.3	1.1
07/23/2026 15:00	4,108.3	1,034.7	5,143.0	105,300.0	541.6	0.6	0.3	1.1
07/23/2026 16:00	4,089.7	1,061.2	5,150.9	105,300.0	542.4	0.7	0.3	1.1
07/23/2026 17:00	4,084.2	1,080.3	5,164.5	105,300.0	543.8	0.7	0.3	1.1
07/23/2026 18:00	4,145.1	1,182.4	5,327.5	105,300.0	561.0	0.7	0.3	1.1
07/23/2026 19:00	4,343.7	757.8	5,101.5	105,300.0	537.2	0.6	0.3	1.1
07/23/2026 20:00	4,454.6	799.6	5,254.2	105,300.0	553.3	0.7	0.3	1.1
07/23/2026 21:00	4,504.8	521.8	5,026.6	105,300.0	529.3	0.6	0.3	1.1
07/23/2026 22:00	4,554.5	479.5	5,034.0	105,300.0	530.1	0.6	0.3	1.1
07/23/2026 23:00	4,595.2	459.0	5,054.2	105,300.0	532.2	0.6	0.3	1.1
Average/Sum#:	4,372.8	525.2	4,881.3	105,300.0	514.0	0.6	0.3	1.0
Minimum:	3,567.2	61.9	3,567.2	105,300.0	375.6	0.5	0.2	0.8
Maximum:	4,703.7	1,182.4	5,327.5	105,300.0	561.0	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/24/2026 00:00	4,628.3	329.7	4,958.0	105,300.0	522.1	0.6	0.3	1.0
07/24/2026 01:00	4,649.3	307.3	4,956.6	105,300.0	521.9	0.6	0.3	1.0
07/24/2026 02:00	4,662.8	293.9	4,956.7	105,300.0	521.9	0.6	0.3	1.0
07/24/2026 03:00	4,676.0	269.4	4,945.4	105,300.0	520.8	0.6	0.3	1.0
07/24/2026 04:00	4,694.9	233.8	4,928.7	105,300.0	519.0	0.6	0.3	1.0
07/24/2026 05:00	4,698.6	228.6	4,927.2	105,300.0	518.8	0.6	0.3	1.0
07/24/2026 06:00	4,677.9	274.4	4,952.3	105,300.0	521.5	0.6	0.3	1.0
07/24/2026 07:00	4,630.1	341.8	4,971.9	105,300.0	523.5	0.6	0.3	1.0
07/24/2026 08:00	4,568.2	428.7	4,996.9	105,300.0	526.2	0.6	0.3	1.1
07/24/2026 09:00	4,500.6	519.9	5,020.5	105,300.0	528.7	0.6	0.3	1.1
07/24/2026 10:00	4,433.3	612.3	5,045.6	105,300.0	531.3	0.6	0.3	1.1
07/24/2026 11:00	3,633.4	144.5	3,637.7	105,300.0	383.0	0.5	0.2	0.8
07/24/2026 12:00	4,188.8	750.2	4,804.0	105,300.0	505.9	0.6	0.3	1.0
07/24/2026 13:00	4,261.7	1,464.2	5,725.9	105,300.0	602.9	0.7	0.4	1.2
07/24/2026 14:00	4,512.9	1,715.9	6,228.8	105,300.0	655.9	0.8	0.4	1.3
07/24/2026 15:00	4,509.3	1,693.4	6,202.7	105,300.0	653.1	0.8	0.4	1.3
07/24/2026 16:00	4,471.6	1,157.0	5,628.6	105,300.0	592.7	0.7	0.4	1.2
07/24/2026 17:00	4,527.6	1,241.6	5,769.2	105,300.0	607.5	0.7	0.4	1.2
07/24/2026 18:00	4,562.1	1,332.6	5,894.7	105,300.0	620.7	0.7	0.4	1.2
07/24/2026 19:00	4,597.9	651.6	5,249.5	105,300.0	552.8	0.7	0.3	1.1
07/24/2026 20:00	4,642.5	635.7	5,278.2	105,300.0	555.8	0.7	0.3	1.1
07/24/2026 21:00	4,672.1	424.8	5,096.9	105,300.0	536.7	0.6	0.3	1.1
07/24/2026 22:00	4,656.5	290.3	4,946.8	105,300.0	520.9	0.6	0.3	1.0
07/24/2026 23:00	4,605.0	354.3	4,959.3	105,300.0	522.2	0.6	0.3	1.0
Average/Sum#:	4,527.6	654.0	5,170.1	105,300.0	544.4	0.6	0.3	1.1
Minimum:	3,633.4	144.5	3,637.7	105,300.0	383.0	0.5	0.2	0.8
Maximum:	4,698.6	1,715.9	6,228.8	105,300.0	655.9	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/25/2026 00:00	4,632.1	321.9	4,954.0	105,300.0	521.7	0.6	0.3	1.0
07/25/2026 01:00	4,652.3	294.0	4,946.3	105,300.0	520.8	0.6	0.3	1.0
07/25/2026 02:00	4,665.9	277.4	4,943.3	105,300.0	520.5	0.6	0.3	1.0
07/25/2026 03:00	4,672.5	269.5	4,942.0	105,300.0	520.4	0.6	0.3	1.0
07/25/2026 04:00	4,689.0	244.9	4,933.9	105,300.0	519.5	0.6	0.3	1.0
07/25/2026 05:00	4,699.4	221.9	4,921.3	105,300.0	518.2	0.6	0.3	1.0
07/25/2026 06:00	4,670.4	268.3	4,938.7	105,300.0	520.0	0.6	0.3	1.0
07/25/2026 07:00	4,627.1	344.9	4,972.0	105,300.0	523.6	0.6	0.3	1.0
07/25/2026 08:00	4,579.7	417.1	4,996.8	105,300.0	526.2	0.6	0.3	1.1
07/25/2026 09:00	4,509.1	521.3	5,030.4	105,300.0	529.7	0.6	0.3	1.1
07/25/2026 10:00	4,433.1	626.8	5,059.9	105,300.0	532.8	0.6	0.3	1.1
07/25/2026 11:00	4,324.1	784.9	5,109.0	105,300.0	538.0	0.6	0.3	1.1
07/25/2026 12:00	4,190.5	973.0	5,163.5	105,300.0	543.7	0.7	0.3	1.1
07/25/2026 13:00	4,106.5	1,081.9	5,188.4	105,300.0	546.3	0.7	0.3	1.1
07/25/2026 14:00	4,034.7	1,171.1	5,205.8	105,300.0	548.2	0.7	0.3	1.1
07/25/2026 15:00	3,980.9	1,235.7	5,216.6	105,300.0	549.3	0.7	0.3	1.1
07/25/2026 16:00	3,941.3	1,295.8	5,237.1	105,300.0	551.5	0.7	0.3	1.1
07/25/2026 17:00	3,978.8	1,257.9	5,236.7	105,300.0	551.4	0.7	0.3	1.1
07/25/2026 18:00	4,112.4	1,050.9	5,163.3	105,300.0	543.7	0.7	0.3	1.1
07/25/2026 19:00	4,281.0	802.5	5,083.5	105,300.0	535.3	0.6	0.3	1.1
07/25/2026 20:00	4,408.4	629.2	5,037.6	105,300.0	530.5	0.6	0.3	1.1
07/25/2026 21:00	4,465.1	549.3	5,014.4	105,300.0	528.0	0.6	0.3	1.1
07/25/2026 22:00	4,510.9	488.9	4,999.8	105,300.0	526.5	0.6	0.3	1.1
07/25/2026 23:00	4,550.3	434.6	4,984.9	105,300.0	524.9	0.6	0.3	1.0
Average/Sum#:	4,404.8	648.5	5,053.3	105,300.0	532.1	0.6	0.3	1.1
Minimum:	3,941.3	221.9	4,921.3	105,300.0	518.2	0.6	0.3	1.0
Maximum:	4,699.4	1,295.8	5,237.1	105,300.0	551.5	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/26/2026 00:00	4,586.2	393.1	4,979.3	105,300.0	524.3	0.6	0.3	1.0
07/26/2026 01:00	4,617.2	349.8	4,967.0	105,300.0	523.0	0.6	0.3	1.0
07/26/2026 02:00	4,643.4	304.6	4,948.0	105,300.0	521.0	0.6	0.3	1.0
07/26/2026 03:00	4,661.4	271.4	4,932.8	105,300.0	519.4	0.6	0.3	1.0
07/26/2026 04:00	4,684.2	253.3	4,937.5	105,300.0	519.9	0.6	0.3	1.0
07/26/2026 05:00	4,697.8	245.1	4,942.9	105,300.0	520.5	0.6	0.3	1.0
07/26/2026 06:00	4,681.7	273.6	4,955.3	105,300.0	521.8	0.6	0.3	1.0
07/26/2026 07:00	3,638.9	89.4	3,638.9	105,300.0	383.2	0.5	0.2	0.8
07/26/2026 08:00	4,337.6	260.5	4,462.6	105,300.0	469.9	0.6	0.3	1.0
07/26/2026 09:00	4,519.1	509.9	5,029.0	105,300.0	529.6	0.6	0.3	1.1
07/26/2026 10:00	4,446.0	608.4	5,054.4	105,300.0	532.2	0.6	0.3	1.1
07/26/2026 11:00	4,354.3	712.6	5,066.9	105,300.0	533.5	0.6	0.3	1.1
07/26/2026 12:00	4,216.5	918.7	5,135.2	105,300.0	540.7	0.6	0.3	1.1
07/26/2026 13:00	4,111.5	1,061.8	5,173.3	105,300.0	544.7	0.7	0.3	1.1
07/26/2026 14:00	4,041.0	1,154.4	5,195.4	105,300.0	547.1	0.7	0.3	1.1
07/26/2026 15:00	4,012.9	1,200.3	5,213.2	105,300.0	548.9	0.7	0.3	1.1
07/26/2026 16:00	3,997.1	1,217.5	5,214.6	105,300.0	549.1	0.7	0.3	1.1
07/26/2026 17:00	4,027.9	1,198.9	5,226.8	105,300.0	550.4	0.7	0.3	1.1
07/26/2026 18:00	4,201.5	946.2	5,147.7	105,300.0	542.1	0.7	0.3	1.1
07/26/2026 19:00	4,364.0	732.8	5,096.8	105,300.0	536.7	0.6	0.3	1.1
07/26/2026 20:00	4,459.7	649.2	5,108.9	105,300.0	538.0	0.6	0.3	1.1
07/26/2026 21:00	4,512.7	1,018.7	5,531.4	105,300.0	582.5	0.7	0.3	1.2
07/26/2026 22:00	4,563.0	938.9	5,501.9	105,300.0	579.4	0.7	0.3	1.2
07/26/2026 23:00	4,600.8	348.5	4,949.3	105,300.0	521.2	0.6	0.3	1.0
Average/Sum#:	4,374.0	652.4	5,017.0	105,300.0	528.3	0.6	0.3	1.1
Minimum:	3,638.9	89.4	3,638.9	105,300.0	383.2	0.5	0.2	0.8
Maximum:	4,697.8	1,217.5	5,531.4	105,300.0	582.5	0.7	0.3	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/27/2026 00:00	4,631.9	466.1	5,098.0	105,300.0	536.8	0.6	0.3	1.1
07/27/2026 01:00	4,652.2	271.1	4,923.3	105,300.0	518.4	0.6	0.3	1.0
07/27/2026 02:00	4,673.4	241.8	4,915.2	105,300.0	517.6	0.6	0.3	1.0
07/27/2026 03:00	4,686.7	229.9	4,916.6	105,300.0	517.7	0.6	0.3	1.0
07/27/2026 04:00	4,702.2	202.9	4,905.1	105,300.0	516.5	0.6	0.3	1.0
07/27/2026 05:00	4,712.6	190.1	4,902.7	105,300.0	516.3	0.6	0.3	1.0
07/27/2026 06:00	4,696.7	227.2	4,923.9	105,300.0	518.5	0.6	0.3	1.0
07/27/2026 07:00	4,652.0	293.0	4,945.0	105,300.0	520.7	0.6	0.3	1.0
07/27/2026 08:00	4,593.7	376.0	4,969.7	105,300.0	523.3	0.6	0.3	1.0
07/27/2026 09:00	4,520.4	468.6	4,989.0	105,300.0	525.3	0.6	0.3	1.1
07/27/2026 10:00	4,454.8	556.3	5,011.1	105,300.0	527.7	0.6	0.3	1.1
07/27/2026 11:00	4,357.7	691.0	5,048.7	105,300.0	531.6	0.6	0.3	1.1
07/27/2026 12:00	4,239.9	860.8	5,100.7	105,300.0	537.1	0.6	0.3	1.1
07/27/2026 13:00	4,157.6	989.5	5,147.1	105,300.0	542.0	0.7	0.3	1.1
07/27/2026 14:00	4,094.2	1,071.9	5,166.1	105,300.0	544.0	0.7	0.3	1.1
07/27/2026 15:00	4,052.0	1,122.8	5,174.8	105,300.0	544.9	0.7	0.3	1.1
07/27/2026 16:00	4,031.1	1,170.8	5,201.9	105,300.0	547.8	0.7	0.3	1.1
07/27/2026 17:00	4,183.5	1,061.9	5,245.4	105,300.0	552.3	0.7	0.3	1.1
07/27/2026 18:00	4,546.1	1,005.3	5,551.4	105,300.0	584.6	0.7	0.4	1.2
07/27/2026 19:00	4,591.3	1,035.1	5,626.4	105,300.0	592.5	0.7	0.4	1.2
07/27/2026 20:00	4,636.7	689.6	5,326.3	105,300.0	560.9	0.7	0.3	1.1
07/27/2026 21:00	4,598.7	408.1	5,006.8	105,300.0	527.2	0.6	0.3	1.1
07/27/2026 22:00	4,562.6	417.1	4,979.7	105,300.0	524.4	0.6	0.3	1.0
07/27/2026 23:00	4,594.8	373.0	4,967.8	105,300.0	523.1	0.6	0.3	1.0
Average/Sum#:	4,484.3	600.8	5,085.1	105,300.0	535.5	0.6	0.3	1.1
Minimum:	4,031.1	190.1	4,902.7	105,300.0	516.3	0.6	0.3	1.0
Maximum:	4,712.6	1,170.8	5,626.4	105,300.0	592.5	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/28/2026 00:00	4,628.0	335.9	4,963.9	105,300.0	522.7	0.6	0.3	1.0
07/28/2026 01:00	4,654.3	296.7	4,951.0	105,300.0	521.3	0.6	0.3	1.0
07/28/2026 02:00	4,670.4	276.8	4,947.2	105,300.0	520.9	0.6	0.3	1.0
07/28/2026 03:00	4,679.8	255.3	4,935.1	105,300.0	519.7	0.6	0.3	1.0
07/28/2026 04:00	4,689.7	248.2	4,937.9	105,300.0	520.0	0.6	0.3	1.0
07/28/2026 05:00	4,705.0	224.2	4,929.2	105,300.0	519.0	0.6	0.3	1.0
07/28/2026 06:00	4,685.5	255.7	4,941.2	105,300.0	520.3	0.6	0.3	1.0
07/28/2026 07:00	4,051.0	108.3	4,070.5	105,300.0	428.6	0.5	0.3	0.9
07/28/2026 08:00	3,581.5	103.2	3,581.5	105,300.0	377.1	0.5	0.2	0.8
07/28/2026 09:00	3,578.2	63.8	3,578.2	105,300.0	376.8	0.5	0.2	0.8
07/28/2026 10:00	3,570.5	70.0	3,570.5	105,300.0	376.0	0.5	0.2	0.8
07/28/2026 11:00	3,860.8	137.0	3,864.9	105,300.0	407.0	0.5	0.3	0.8
07/28/2026 12:00	4,323.9	619.1	4,831.6	105,300.0	508.8	0.6	0.3	1.0
07/28/2026 13:00	3,579.6	111.6	3,579.6	105,300.0	376.9	0.5	0.2	0.8
07/28/2026 14:00	3,560.3	27.9	3,560.3	105,300.0	374.9	0.5	0.2	0.8
07/28/2026 15:00	3,851.3	58.0	3,853.0	105,300.0	405.7	0.5	0.2	0.8
07/28/2026 16:00	4,481.8	573.3	5,055.1	105,300.0	532.3	0.6	0.3	1.1
07/28/2026 17:00	4,511.7	558.1	5,069.8	105,300.0	533.8	0.6	0.3	1.1
07/28/2026 18:00	4,223.2	932.6	5,155.8	105,300.0	542.9	0.7	0.3	1.1
07/28/2026 19:00	4,261.8	838.7	5,100.5	105,300.0	537.1	0.6	0.3	1.1
07/28/2026 20:00	4,400.1	653.8	5,053.9	105,300.0	532.2	0.6	0.3	1.1
07/28/2026 21:00	4,433.5	624.4	5,057.9	105,300.0	532.6	0.6	0.3	1.1
07/28/2026 22:00	4,466.4	552.2	5,018.6	105,300.0	528.5	0.6	0.3	1.1
07/28/2026 23:00	3,664.5	7.7	3,664.7	105,300.0	385.9	0.5	0.2	0.8
Average/Sum#:	4,213.0	330.5	4,511.3	105,300.0	475.0	0.6	0.3	1.0
Minimum:	3,560.3	7.7	3,560.3	105,300.0	374.9	0.5	0.2	0.8
Maximum:	4,705.0	932.6	5,155.8	105,300.0	542.9	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/29/2026 00:00	3,573.0	0.0	3,573.0	105,300.0	376.2	0.5	0.2	0.8
07/29/2026 01:00	3,572.2	0.0	3,572.2	105,300.0	376.2	0.5	0.2	0.8
07/29/2026 02:00	3,576.6	0.0	3,576.6	105,300.0	376.6	0.5	0.2	0.8
07/29/2026 03:00	3,577.6	0.0	3,577.6	105,300.0	376.7	0.5	0.2	0.8
07/29/2026 04:00	3,578.1	0.0	3,578.1	105,300.0	376.8	0.5	0.2	0.8
07/29/2026 05:00	3,576.1	4.7	3,576.1	105,300.0	376.6	0.5	0.2	0.8
07/29/2026 06:00	3,576.0	76.2	3,576.0	105,300.0	376.6	0.5	0.2	0.8
07/29/2026 07:00	3,575.2	83.5	3,575.2	105,300.0	376.5	0.5	0.2	0.8
07/29/2026 08:00	3,570.5	101.6	3,570.5	105,300.0	376.0	0.5	0.2	0.8
07/29/2026 09:00	3,569.2	63.2	3,569.2	105,300.0	375.8	0.5	0.2	0.8
07/29/2026 10:00	3,815.5	79.4	3,817.9	105,300.0	402.0	0.5	0.2	0.8
07/29/2026 11:00	4,280.5	843.5	5,124.0	105,300.0	539.6	0.6	0.3	1.1
07/29/2026 12:00	4,151.6	1,013.5	5,165.1	105,300.0	543.9	0.7	0.3	1.1
07/29/2026 13:00	4,026.6	1,199.4	5,226.0	105,300.0	550.3	0.7	0.3	1.1
07/29/2026 14:00	3,968.5	1,264.2	5,232.7	105,300.0	551.0	0.7	0.3	1.1
07/29/2026 15:00	3,922.0	1,330.1	5,252.1	105,300.0	553.0	0.7	0.3	1.1
07/29/2026 16:00	3,912.8	1,341.2	5,254.0	105,300.0	553.2	0.7	0.3	1.1
07/29/2026 17:00	3,943.6	1,361.5	5,305.1	105,300.0	558.6	0.7	0.3	1.1
07/29/2026 18:00	4,047.0	1,283.0	5,330.0	105,300.0	561.2	0.7	0.3	1.1
07/29/2026 19:00	4,160.6	1,039.6	5,200.2	105,300.0	547.6	0.7	0.3	1.1
07/29/2026 20:00	4,325.8	763.4	5,089.2	105,300.0	535.9	0.6	0.3	1.1
07/29/2026 21:00	3,660.9	16.5	3,662.1	105,300.0	385.6	0.5	0.2	0.8
07/29/2026 22:00	3,567.9	0.1	3,567.9	105,300.0	375.7	0.5	0.2	0.8
07/29/2026 23:00	3,570.2	2.1	3,570.2	105,300.0	375.9	0.5	0.2	0.8
Average/Sum#:	3,795.8	494.4	4,272.5	105,300.0	449.9	0.6	0.2	0.9
Minimum:	3,567.9	0.0	3,567.9	105,300.0	375.7	0.5	0.2	0.8
Maximum:	4,325.8	1,361.5	5,330.0	105,300.0	561.2	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/30/2026 00:00	3,575.6	0.0	3,575.6	105,300.0	376.5	0.5	0.2	0.8
07/30/2026 01:00	3,577.2	0.0	3,577.2	105,300.0	376.7	0.5	0.2	0.8
07/30/2026 02:00	3,578.4	0.0	3,578.4	105,300.0	376.8	0.5	0.2	0.8
07/30/2026 03:00	3,577.3	0.0	3,577.3	105,300.0	376.7	0.5	0.2	0.8
07/30/2026 04:00	3,577.9	0.0	3,577.9	105,300.0	376.8	0.5	0.2	0.8
07/30/2026 05:00	3,578.4	1.4	3,578.4	105,300.0	376.8	0.5	0.2	0.8
07/30/2026 06:00	3,575.7	51.1	3,575.7	105,300.0	376.5	0.5	0.2	0.8
07/30/2026 07:00	3,571.5	77.3	3,571.5	105,300.0	376.1	0.5	0.2	0.8
07/30/2026 08:00	3,566.2	101.5	3,566.2	105,300.0	375.5	0.5	0.2	0.8
07/30/2026 09:00	3,562.9	72.3	3,562.9	105,300.0	375.2	0.5	0.2	0.8
07/30/2026 10:00	3,557.3	43.0	3,557.3	105,300.0	374.6	0.5	0.2	0.8
07/30/2026 11:00	3,553.8	140.6	3,553.8	105,300.0	374.2	0.5	0.2	0.8
07/30/2026 12:00	3,551.5	143.6	3,551.5	105,300.0	374.0	0.5	0.2	0.8
07/30/2026 13:00	3,548.6	95.0	3,548.6	105,300.0	373.7	0.5	0.2	0.8
07/30/2026 14:00	4,003.0	50.2	4,003.0	105,300.0	421.5	0.5	0.3	0.9
07/30/2026 15:00	3,749.0	71.0	3,749.0	105,300.0	394.8	0.5	0.2	0.8
07/30/2026 16:00	3,697.2	73.9	3,697.2	105,300.0	389.3	0.5	0.2	0.8
07/30/2026 17:00	4,025.4	87.0	4,025.4	105,300.0	423.9	0.5	0.3	0.9
07/30/2026 18:00	4,351.0	47.8	4,351.0	105,300.0	458.2	0.6	0.3	0.9
07/30/2026 19:00	3,739.9	0.0	3,739.9	105,300.0	393.8	0.5	0.2	0.8
07/30/2026 20:00	3,555.2	0.7	3,555.2	105,300.0	374.4	0.5	0.2	0.8
07/30/2026 21:00	3,635.6	0.0	3,635.6	105,300.0	382.8	0.5	0.2	0.8
07/30/2026 22:00	3,745.0	0.2	3,745.0	105,300.0	394.3	0.5	0.2	0.8
07/30/2026 23:00	3,582.9	1.3	3,582.9	105,300.0	377.3	0.5	0.2	0.8
Average/Sum#:	3,668.2	44.1	3,668.2	105,300.0	386.3	0.5	0.2	0.8
Minimum:	3,548.6	0.0	3,548.6	105,300.0	373.7	0.5	0.2	0.8
Maximum:	4,351.0	143.6	4,351.0	105,300.0	458.2	0.6	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/31/2026 00:00	3,566.5	0.0	3,566.5	105,300.0	375.6	0.5	0.2	0.8
07/31/2026 01:00	3,570.5	0.0	3,570.5	105,300.0	376.0	0.5	0.2	0.8
07/31/2026 02:00	3,573.5	0.0	3,573.5	105,300.0	376.3	0.5	0.2	0.8
07/31/2026 03:00	3,577.2	0.0	3,577.2	105,300.0	376.7	0.5	0.2	0.8
07/31/2026 04:00	3,771.4	0.0	3,771.4	105,300.0	397.1	0.5	0.2	0.8
07/31/2026 05:00	3,583.6	0.5	3,583.6	105,300.0	377.4	0.5	0.2	0.8
07/31/2026 06:00	3,581.2	68.3	3,581.2	105,300.0	377.1	0.5	0.2	0.8
07/31/2026 07:00	3,581.2	103.1	3,581.2	105,300.0	377.1	0.5	0.2	0.8
07/31/2026 08:00	3,577.0	112.7	3,577.0	105,300.0	376.7	0.5	0.2	0.8
07/31/2026 09:00	3,571.4	62.9	3,571.4	105,300.0	376.1	0.5	0.2	0.8
07/31/2026 10:00	3,564.7	63.5	3,564.7	105,300.0	375.4	0.5	0.2	0.8
07/31/2026 11:00	3,701.0	123.2	3,701.0	105,300.0	389.7	0.5	0.2	0.8
07/31/2026 12:00	4,394.3	149.5	4,394.3	105,300.0	462.7	0.6	0.3	1.0
07/31/2026 13:00	4,383.0	106.6	4,383.0	105,300.0	461.5	0.6	0.3	0.9
07/31/2026 14:00	4,419.7	58.3	4,421.4	105,300.0	465.6	0.6	0.3	0.9
07/31/2026 15:00	4,511.7	754.0	5,265.7	105,300.0	554.5	0.7	0.3	1.1
07/31/2026 16:00	4,508.5	1,003.5	5,512.0	105,300.0	580.4	0.7	0.3	1.2
07/31/2026 17:00	4,520.4	1,314.4	5,834.8	105,300.0	614.4	0.7	0.4	1.2
07/31/2026 18:00	4,521.2	1,741.1	6,262.3	105,300.0	659.4	0.8	0.4	1.3
07/31/2026 19:00	4,561.7	611.6	5,173.3	105,300.0	544.7	0.7	0.3	1.1
07/31/2026 20:00	4,315.7	761.3	5,077.0	105,300.0	534.6	0.6	0.3	1.1
07/31/2026 21:00	4,367.7	699.4	5,067.1	105,300.0	533.6	0.6	0.3	1.1
07/31/2026 22:00	4,451.6	568.4	5,020.0	105,300.0	528.6	0.6	0.3	1.1
07/31/2026 23:00	3,664.6	7.5	3,664.8	105,300.0	385.9	0.5	0.2	0.8
Average/Sum#:	3,993.3	346.2	4,304.0	105,300.0	453.2	0.6	0.3	0.9
Minimum:	3,564.7	0.0	3,564.7	105,300.0	375.4	0.5	0.2	0.8
Maximum:	4,561.7	1,741.1	6,262.3	105,300.0	659.4	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/01/2026 00:00	3,579.2	3.6	3,579.2	105,300.0	376.9	0.5	0.2	0.8
08/01/2026 01:00	3,580.8	1.8	3,580.8	105,300.0	377.1	0.5	0.2	0.8
08/01/2026 02:00	3,583.4	0.0	3,583.4	105,300.0	377.3	0.5	0.2	0.8
08/01/2026 03:00	3,585.5	0.0	3,585.5	105,300.0	377.6	0.5	0.2	0.8
08/01/2026 04:00	3,588.7	0.0	3,588.7	105,300.0	377.9	0.5	0.2	0.8
08/01/2026 05:00	3,588.0	5.9	3,588.0	105,300.0	377.8	0.5	0.2	0.8
08/01/2026 06:00	3,590.5	88.0	3,590.5	105,300.0	378.1	0.5	0.2	0.8
08/01/2026 07:00	3,584.0	65.9	3,584.0	105,300.0	377.4	0.5	0.2	0.8
08/01/2026 08:00	3,579.0	123.2	3,579.0	105,300.0	376.9	0.5	0.2	0.8
08/01/2026 09:00	3,570.8	71.0	3,570.8	105,300.0	376.0	0.5	0.2	0.8
08/01/2026 10:00	3,570.4	81.3	3,570.4	105,300.0	376.0	0.5	0.2	0.8
08/01/2026 11:00	3,569.6	136.4	3,569.6	105,300.0	375.9	0.5	0.2	0.8
08/01/2026 12:00	3,561.6	136.2	3,561.6	105,300.0	375.0	0.5	0.2	0.8
08/01/2026 13:00	3,547.7	109.2	3,547.7	105,300.0	373.6	0.5	0.2	0.8
08/01/2026 14:00	3,804.4	67.0	3,806.4	105,300.0	400.8	0.5	0.2	0.8
08/01/2026 15:00	4,424.8	638.1	5,062.9	105,300.0	533.1	0.6	0.3	1.1
08/01/2026 16:00	4,297.4	831.2	5,128.6	105,300.0	540.0	0.6	0.3	1.1
08/01/2026 17:00	4,449.0	1,185.5	5,634.5	105,300.0	593.3	0.7	0.4	1.2
08/01/2026 18:00	4,452.3	1,773.4	6,225.7	105,300.0	655.6	0.8	0.4	1.3
08/01/2026 19:00	4,508.6	1,310.8	5,819.4	105,300.0	612.8	0.7	0.4	1.2
08/01/2026 20:00	4,516.9	487.1	5,004.0	105,300.0	526.9	0.6	0.3	1.1
08/01/2026 21:00	4,253.2	899.6	5,152.8	105,300.0	542.6	0.7	0.3	1.1
08/01/2026 22:00	4,334.3	791.2	5,125.5	105,300.0	539.7	0.6	0.3	1.1
08/01/2026 23:00	4,092.3	17.5	4,093.2	105,300.0	431.0	0.5	0.3	0.9
Average/Sum#:	3,883.9	367.7	4,213.8	105,300.0	443.7	0.6	0.3	0.9
Minimum:	3,547.7	0.0	3,547.7	105,300.0	373.6	0.5	0.2	0.8
Maximum:	4,516.9	1,773.4	6,225.7	105,300.0	655.6	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/02/2026 00:00	3,601.1	58.5	3,601.1	105,300.0	379.2	0.5	0.2	0.8
08/02/2026 01:00	3,566.0	46.9	3,566.0	105,300.0	375.5	0.5	0.2	0.8
08/02/2026 02:00	3,570.1	19.9	3,570.1	105,300.0	375.9	0.5	0.2	0.8
08/02/2026 03:00	3,574.2	0.5	3,574.2	105,300.0	376.4	0.5	0.2	0.8
08/02/2026 04:00	3,571.8	3.8	3,571.8	105,300.0	376.1	0.5	0.2	0.8
08/02/2026 05:00	3,575.8	0.0	3,575.8	105,300.0	376.5	0.5	0.2	0.8
08/02/2026 06:00	3,573.8	82.9	3,573.8	105,300.0	376.3	0.5	0.2	0.8
08/02/2026 07:00	3,565.0	109.6	3,565.0	105,300.0	375.4	0.5	0.2	0.8
08/02/2026 08:00	3,555.9	122.8	3,555.9	105,300.0	374.4	0.5	0.2	0.8
08/02/2026 09:00	3,549.8	58.6	3,549.8	105,300.0	373.8	0.5	0.2	0.8
08/02/2026 10:00	3,550.6	89.0	3,550.6	105,300.0	373.9	0.5	0.2	0.8
08/02/2026 11:00	3,542.8	136.2	3,542.8	105,300.0	373.1	0.5	0.2	0.8
08/02/2026 12:00	3,534.2	137.4	3,534.2	105,300.0	372.2	0.5	0.2	0.8
08/02/2026 13:00	3,802.5	111.3	3,805.8	105,300.0	400.8	0.5	0.2	0.8
08/02/2026 14:00	4,439.1	590.4	5,029.5	105,300.0	529.6	0.6	0.3	1.1
08/02/2026 15:00	4,436.3	588.5	5,024.8	105,300.0	529.1	0.6	0.3	1.1
08/02/2026 16:00	4,442.8	824.8	5,267.6	105,300.0	554.7	0.7	0.3	1.1
08/02/2026 17:00	4,442.1	663.7	5,105.8	105,300.0	537.6	0.6	0.3	1.1
08/02/2026 18:00	4,409.5	666.0	5,075.5	105,300.0	534.5	0.6	0.3	1.1
08/02/2026 19:00	3,985.4	1,253.2	5,238.6	105,300.0	551.6	0.7	0.3	1.1
08/02/2026 20:00	4,067.8	1,125.4	5,193.2	105,300.0	546.8	0.7	0.3	1.1
08/02/2026 21:00	4,164.3	1,005.4	5,169.7	105,300.0	544.4	0.7	0.3	1.1
08/02/2026 22:00	4,257.3	148.1	4,383.2	105,300.0	461.6	0.6	0.3	0.9
08/02/2026 23:00	4,126.2	115.7	4,192.1	105,300.0	441.4	0.5	0.3	0.9
Average/Sum#:	3,871.0	331.6	4,159.0	105,300.0	438.0	0.6	0.2	0.9
Minimum:	3,534.2	0.0	3,534.2	105,300.0	372.2	0.5	0.2	0.8
Maximum:	4,442.8	1,253.2	5,267.6	105,300.0	554.7	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/03/2026 00:00	3,563.1	57.8	3,563.1	105,300.0	375.2	0.5	0.2	0.8
08/03/2026 01:00	3,856.4	50.9	3,856.4	105,300.0	406.1	0.5	0.2	0.8
08/03/2026 02:00	3,557.3	25.8	3,557.3	105,300.0	374.6	0.5	0.2	0.8
08/03/2026 03:00	3,559.4	1.2	3,559.4	105,300.0	374.8	0.5	0.2	0.8
08/03/2026 04:00	4,098.3	0.2	4,098.3	105,300.0	431.6	0.5	0.3	0.9
08/03/2026 05:00	3,984.9	9.4	3,984.9	105,300.0	419.6	0.5	0.3	0.8
08/03/2026 06:00	3,568.3	96.2	3,568.3	105,300.0	375.7	0.5	0.2	0.8
08/03/2026 07:00	3,557.8	114.3	3,557.8	105,300.0	374.6	0.5	0.2	0.8
08/03/2026 08:00	3,550.9	122.5	3,550.9	105,300.0	373.9	0.5	0.2	0.8
08/03/2026 09:00	3,548.2	68.4	3,548.2	105,300.0	373.6	0.5	0.2	0.8
08/03/2026 10:00	3,547.1	88.0	3,547.1	105,300.0	373.5	0.5	0.2	0.8
08/03/2026 11:00	3,537.1	134.4	3,537.1	105,300.0	372.5	0.5	0.2	0.8
08/03/2026 12:00	3,856.5	137.5	3,856.5	105,300.0	406.1	0.5	0.3	0.8
08/03/2026 13:00	4,026.9	105.1	4,030.1	105,300.0	424.4	0.5	0.3	0.9
08/03/2026 14:00	4,419.2	749.4	5,168.6	105,300.0	544.3	0.7	0.3	1.1
08/03/2026 15:00	4,438.2	663.9	5,102.1	105,300.0	537.3	0.6	0.3	1.1
08/03/2026 16:00	4,440.2	1,097.5	5,537.7	105,300.0	583.1	0.7	0.3	1.2
08/03/2026 17:00	4,443.1	1,223.4	5,666.5	105,300.0	596.7	0.7	0.4	1.2
08/03/2026 18:00	4,434.5	1,900.2	6,334.7	105,300.0	667.0	0.8	0.4	1.3
08/03/2026 19:00	4,455.9	1,621.0	6,076.9	105,300.0	639.9	0.8	0.4	1.3
08/03/2026 20:00	4,503.3	1,340.9	5,844.2	105,300.0	615.4	0.7	0.4	1.2
08/03/2026 21:00	4,394.5	910.7	5,305.2	105,300.0	558.6	0.7	0.3	1.1
08/03/2026 22:00	4,064.1	91.2	4,107.9	105,300.0	432.6	0.5	0.3	0.9
08/03/2026 23:00	4,275.9	56.4	4,275.9	105,300.0	450.3	0.5	0.3	0.9
Average/Sum#:	3,986.7	444.4	4,384.8	105,300.0	461.7	0.6	0.3	0.9
Minimum:	3,537.1	0.2	3,537.1	105,300.0	372.5	0.5	0.2	0.8
Maximum:	4,503.3	1,900.2	6,334.7	105,300.0	667.0	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/04/2026 00:00	3,723.4	41.4	3,723.4	105,300.0	392.1	0.5	0.2	0.8
08/04/2026 01:00	3,563.6	5.9	3,563.6	105,300.0	375.2	0.5	0.2	0.8
08/04/2026 02:00	3,566.3	0.5	3,566.3	105,300.0	375.5	0.5	0.2	0.8
08/04/2026 03:00	3,754.8	0.0	3,754.8	105,300.0	395.4	0.5	0.2	0.8
08/04/2026 04:00	4,130.2	1.7	4,130.2	105,300.0	434.9	0.5	0.3	0.9
08/04/2026 05:00	3,982.2	1.1	3,982.2	105,300.0	419.3	0.5	0.3	0.8
08/04/2026 06:00	3,842.1	28.3	3,842.1	105,300.0	404.6	0.5	0.2	0.8
08/04/2026 07:00	3,563.9	62.7	3,563.9	105,300.0	375.3	0.5	0.2	0.8
08/04/2026 08:00	3,561.7	89.0	3,561.7	105,300.0	375.0	0.5	0.2	0.8
08/04/2026 09:00	3,560.6	27.3	3,560.6	105,300.0	374.9	0.5	0.2	0.8
08/04/2026 10:00	3,581.5	92.2	3,581.5	105,300.0	377.1	0.5	0.2	0.8
08/04/2026 11:00	3,761.6	136.9	3,761.6	105,300.0	396.1	0.5	0.2	0.8
08/04/2026 12:00	4,079.1	146.3	4,079.1	105,300.0	429.5	0.5	0.3	0.9
08/04/2026 13:00	4,309.2	122.7	4,312.9	105,300.0	454.1	0.6	0.3	0.9
08/04/2026 14:00	4,433.4	936.1	5,369.5	105,300.0	565.4	0.7	0.3	1.1
08/04/2026 15:00	4,425.2	1,063.6	5,488.8	105,300.0	578.0	0.7	0.3	1.2
08/04/2026 16:00	4,428.6	894.0	5,322.6	105,300.0	560.5	0.7	0.3	1.1
08/04/2026 17:00	4,347.6	987.5	5,157.4	105,300.0	543.1	0.7	0.3	1.1
08/04/2026 18:00	4,465.6	1,483.3	5,948.9	105,300.0	626.4	0.8	0.4	1.3
08/04/2026 19:00	4,517.1	484.9	5,002.0	105,300.0	526.7	0.6	0.3	1.1
08/04/2026 20:00	4,443.0	628.0	5,071.0	105,300.0	534.0	0.6	0.3	1.1
08/04/2026 21:00	4,373.6	718.7	5,092.3	105,300.0	536.2	0.6	0.3	1.1
08/04/2026 22:00	3,675.9	2.9	3,676.0	105,300.0	387.1	0.5	0.2	0.8
08/04/2026 23:00	4,260.3	1.2	4,260.3	105,300.0	448.6	0.5	0.3	0.9
Average/Sum#:	4,014.6	331.5	4,307.2	105,300.0	453.5	0.6	0.3	0.9
Minimum:	3,560.6	0.0	3,560.6	105,300.0	374.9	0.5	0.2	0.8
Maximum:	4,517.1	1,483.3	5,948.9	105,300.0	626.4	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/05/2026 00:00	4,017.4	0.0	4,017.4	105,300.0	423.0	0.5	0.3	0.8
08/05/2026 01:00	3,587.4	0.0	3,587.4	105,300.0	377.8	0.5	0.2	0.8
08/05/2026 02:00	3,590.1	0.0	3,590.1	105,300.0	378.0	0.5	0.2	0.8
08/05/2026 03:00	3,591.2	0.0	3,591.2	105,300.0	378.2	0.5	0.2	0.8
08/05/2026 04:00	3,647.7	0.0	3,647.7	105,300.0	384.1	0.5	0.2	0.8
08/05/2026 05:00	3,594.6	0.0	3,594.6	105,300.0	378.5	0.5	0.2	0.8
08/05/2026 06:00	3,738.8	0.0	3,738.8	105,300.0	393.7	0.5	0.2	0.8
08/05/2026 07:00	3,589.7	31.4	3,589.7	105,300.0	378.0	0.5	0.2	0.8
08/05/2026 08:00	3,588.3	100.5	3,588.3	105,300.0	377.8	0.5	0.2	0.8
08/05/2026 09:00	3,584.4	50.2	3,584.4	105,300.0	377.4	0.5	0.2	0.8
08/05/2026 10:00	3,578.3	71.8	3,578.3	105,300.0	376.8	0.5	0.2	0.8
08/05/2026 11:00	3,572.5	135.3	3,572.5	105,300.0	376.2	0.5	0.2	0.8
08/05/2026 12:00	3,728.9	149.3	3,728.9	105,300.0	392.7	0.5	0.2	0.8
08/05/2026 13:00	3,876.0	111.9	3,876.0	105,300.0	408.1	0.5	0.3	0.8
08/05/2026 14:00	4,503.2	491.9	4,980.3	105,300.0	524.4	0.6	0.3	1.1
08/05/2026 15:00	4,487.3	584.7	5,072.0	105,300.0	534.1	0.6	0.3	1.1
08/05/2026 16:00	4,492.3	1,007.4	5,499.7	105,300.0	579.1	0.7	0.3	1.2
08/05/2026 17:00	4,503.1	821.5	5,324.6	105,300.0	560.7	0.7	0.3	1.1
08/05/2026 18:00	4,552.2	492.5	5,044.7	105,300.0	531.2	0.6	0.3	1.1
08/05/2026 19:00	4,391.8	703.0	5,094.8	105,300.0	536.5	0.6	0.3	1.1
08/05/2026 20:00	4,338.1	786.7	5,124.8	105,300.0	539.6	0.6	0.3	1.1
08/05/2026 21:00	4,436.8	615.2	5,052.0	105,300.0	532.0	0.6	0.3	1.1
08/05/2026 22:00	4,356.0	6.3	4,356.2	105,300.0	458.7	0.6	0.3	0.9
08/05/2026 23:00	4,199.9	0.0	4,199.9	105,300.0	442.2	0.5	0.3	0.9
Average/Sum#:	3,981.1	256.7	4,209.8	105,300.0	443.3	0.5	0.3	0.9
Minimum:	3,572.5	0.0	3,572.5	105,300.0	376.2	0.5	0.2	0.8
Maximum:	4,552.2	1,007.4	5,499.7	105,300.0	579.1	0.7	0.3	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/06/2026 00:00	3,711.7	0.9	3,711.7	105,300.0	390.8	0.5	0.2	0.8
08/06/2026 01:00	3,573.6	0.1	3,573.6	105,300.0	376.3	0.5	0.2	0.8
08/06/2026 02:00	3,574.9	0.0	3,574.9	105,300.0	376.4	0.5	0.2	0.8
08/06/2026 03:00	3,576.3	0.0	3,576.3	105,300.0	376.6	0.5	0.2	0.8
08/06/2026 04:00	3,619.3	0.0	3,619.3	105,300.0	381.1	0.5	0.2	0.8
08/06/2026 05:00	3,791.2	0.0	3,791.2	105,300.0	399.2	0.5	0.2	0.8
08/06/2026 06:00	3,584.3	6.1	3,584.3	105,300.0	377.4	0.5	0.2	0.8
08/06/2026 07:00	3,579.8	67.3	3,579.8	105,300.0	377.0	0.5	0.2	0.8
08/06/2026 08:00	3,576.9	102.1	3,576.9	105,300.0	376.6	0.5	0.2	0.8
08/06/2026 09:00	3,572.2	57.1	3,572.2	105,300.0	376.2	0.5	0.2	0.8
08/06/2026 10:00	3,566.4	78.8	3,566.4	105,300.0	375.5	0.5	0.2	0.8
08/06/2026 11:00	3,558.5	132.7	3,558.5	105,300.0	374.7	0.5	0.2	0.8
08/06/2026 12:00	3,554.6	142.7	3,554.6	105,300.0	374.3	0.5	0.2	0.8
08/06/2026 13:00	3,740.7	110.9	3,740.7	105,300.0	393.9	0.5	0.2	0.8
08/06/2026 14:00	3,963.7	1,209.5	5,136.9	105,300.0	540.9	0.7	0.3	1.1
08/06/2026 15:00	3,867.4	1,392.4	5,259.8	105,300.0	553.9	0.7	0.3	1.1
08/06/2026 16:00	3,990.1	1,455.1	5,445.2	105,300.0	573.4	0.7	0.3	1.1
08/06/2026 17:00	4,496.3	1,636.4	6,132.7	105,300.0	645.8	0.8	0.4	1.3
08/06/2026 18:00	4,553.1	1,359.1	5,912.2	105,300.0	622.6	0.7	0.4	1.2
08/06/2026 19:00	4,541.3	541.3	5,082.6	105,300.0	535.2	0.6	0.3	1.1
08/06/2026 20:00	4,318.7	860.1	5,178.8	105,300.0	545.3	0.7	0.3	1.1
08/06/2026 21:00	4,404.5	984.0	5,388.5	105,300.0	567.4	0.7	0.3	1.1
08/06/2026 22:00	4,357.2	7.2	4,357.4	105,300.0	458.8	0.6	0.3	0.9
08/06/2026 23:00	4,345.5	0.0	4,345.5	105,300.0	457.6	0.6	0.3	0.9
Average/Sum#:	3,892.4	422.7	4,284.2	105,300.0	451.1	0.6	0.3	0.9
Minimum:	3,554.6	0.0	3,554.6	105,300.0	374.3	0.5	0.2	0.8
Maximum:	4,553.1	1,636.4	6,132.7	105,300.0	645.8	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/07/2026 00:00	4,339.7	0.5	4,339.7	105,300.0	457.0	0.6	0.3	0.9
08/07/2026 01:00	4,347.6	0.0	4,347.6	105,300.0	457.8	0.6	0.3	0.9
08/07/2026 02:00	4,348.5	0.0	4,348.5	105,300.0	457.9	0.5	0.3	0.9
08/07/2026 03:00	3,815.6	0.0	3,815.6	105,300.0	401.8	0.5	0.2	0.8
08/07/2026 04:00	4,315.5	0.0	4,315.5	105,300.0	454.4	0.5	0.3	0.9
08/07/2026 05:00	4,344.8	0.0	4,344.8	105,300.0	457.5	0.6	0.3	0.9
08/07/2026 06:00	3,788.3	40.1	3,788.3	105,300.0	398.9	0.5	0.2	0.8
08/07/2026 07:00	3,585.0	96.6	3,585.0	105,300.0	377.5	0.5	0.2	0.8
08/07/2026 08:00	3,578.8	107.1	3,578.8	105,300.0	376.8	0.5	0.2	0.8
08/07/2026 09:00	3,573.8	53.0	3,573.8	105,300.0	376.3	0.5	0.2	0.8
08/07/2026 10:00	3,567.5	79.1	3,567.5	105,300.0	375.7	0.5	0.2	0.8
08/07/2026 11:00	3,853.9	137.5	3,853.9	105,300.0	405.8	0.5	0.3	0.8
08/07/2026 12:00	3,682.9	138.5	3,682.9	105,300.0	387.8	0.5	0.2	0.8
08/07/2026 13:00	4,162.1	101.6	4,164.1	105,300.0	438.5	0.5	0.3	0.9
08/07/2026 14:00	4,241.6	957.0	5,198.6	105,300.0	547.4	0.7	0.3	1.1
08/07/2026 15:00	3,849.8	1,475.6	5,325.4	105,300.0	560.8	0.7	0.3	1.1
08/07/2026 16:00	3,931.5	1,424.8	5,356.3	105,300.0	564.0	0.7	0.3	1.1
08/07/2026 17:00	4,477.6	992.4	5,470.0	105,300.0	576.0	0.7	0.3	1.2
08/07/2026 18:00	4,515.3	1,508.0	6,023.3	105,300.0	634.3	0.8	0.4	1.3
08/07/2026 19:00	4,546.0	787.8	5,333.8	105,300.0	561.6	0.7	0.3	1.1
08/07/2026 20:00	4,560.6	612.3	5,172.9	105,300.0	544.7	0.7	0.3	1.1
08/07/2026 21:00	4,425.6	761.7	5,187.3	105,300.0	546.2	0.7	0.3	1.1
08/07/2026 22:00	4,384.0	11.7	4,384.6	105,300.0	461.7	0.6	0.3	0.9
08/07/2026 23:00	4,471.2	0.4	4,471.2	105,300.0	470.8	0.6	0.3	0.9
Average/Sum#:	4,112.8	386.9	4,467.9	105,300.0	470.5	0.6	0.3	0.9
Minimum:	3,567.5	0.0	3,567.5	105,300.0	375.7	0.5	0.2	0.8
Maximum:	4,560.6	1,508.0	6,023.3	105,300.0	634.3	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/08/2026 00:00	4,471.2	1.4	4,471.2	105,300.0	470.8	0.6	0.3	0.9
08/08/2026 01:00	3,910.8	1.1	3,910.8	105,300.0	411.8	0.5	0.2	0.8
08/08/2026 02:00	3,600.5	0.0	3,600.5	105,300.0	379.1	0.5	0.2	0.8
08/08/2026 03:00	3,612.0	0.0	3,612.0	105,300.0	380.3	0.5	0.2	0.8
08/08/2026 04:00	4,311.8	0.0	4,311.8	105,300.0	454.0	0.5	0.3	0.9
08/08/2026 05:00	4,066.2	0.0	4,066.2	105,300.0	428.2	0.5	0.3	0.9
08/08/2026 06:00	3,607.0	0.0	3,607.0	105,300.0	379.8	0.5	0.2	0.8
08/08/2026 07:00	3,602.7	72.4	3,602.7	105,300.0	379.4	0.5	0.2	0.8
08/08/2026 08:00	3,610.9	95.7	3,610.9	105,300.0	380.2	0.5	0.2	0.8
08/08/2026 09:00	3,614.2	57.0	3,614.2	105,300.0	380.6	0.5	0.2	0.8
08/08/2026 10:00	3,606.5	70.1	3,606.5	105,300.0	379.8	0.5	0.2	0.8
08/08/2026 11:00	3,595.8	129.6	3,595.8	105,300.0	378.6	0.5	0.2	0.8
08/08/2026 12:00	3,585.0	147.5	3,585.0	105,300.0	377.5	0.5	0.2	0.8
08/08/2026 13:00	3,731.0	246.2	3,792.6	105,300.0	399.4	0.5	0.3	0.8
08/08/2026 14:00	3,926.8	1,431.0	5,357.8	105,300.0	564.2	0.7	0.3	1.1
08/08/2026 15:00	4,049.4	1,214.3	5,263.7	105,300.0	554.3	0.7	0.3	1.1
08/08/2026 16:00	4,451.6	688.6	5,140.2	105,300.0	541.3	0.7	0.3	1.1
08/08/2026 17:00	4,450.6	769.2	5,219.8	105,300.0	549.6	0.7	0.3	1.1
08/08/2026 18:00	4,476.2	666.6	5,142.8	105,300.0	541.5	0.6	0.3	1.1
08/08/2026 19:00	4,303.9	816.2	5,120.1	105,300.0	539.1	0.6	0.3	1.1
08/08/2026 20:00	4,329.1	771.4	5,100.5	105,300.0	537.1	0.6	0.3	1.1
08/08/2026 21:00	4,382.2	711.4	5,093.6	105,300.0	536.4	0.6	0.3	1.1
08/08/2026 22:00	4,375.2	56.8	4,378.0	105,300.0	461.0	0.6	0.3	0.9
08/08/2026 23:00	4,093.8	11.6	4,093.8	105,300.0	431.1	0.5	0.3	0.9
Average/Sum#:	3,990.2	331.6	4,287.4	105,300.0	451.5	0.6	0.3	0.9
Minimum:	3,585.0	0.0	3,585.0	105,300.0	377.5	0.5	0.2	0.8
Maximum:	4,476.2	1,431.0	5,357.8	105,300.0	564.2	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/09/2026 00:00	3,586.1	0.0	3,586.1	105,300.0	377.6	0.5	0.2	0.8
08/09/2026 01:00	3,589.6	0.4	3,589.6	105,300.0	378.0	0.5	0.2	0.8
08/09/2026 02:00	3,592.6	0.0	3,592.6	105,300.0	378.3	0.5	0.2	0.8
08/09/2026 03:00	3,595.9	0.0	3,595.9	105,300.0	378.6	0.5	0.2	0.8
08/09/2026 04:00	3,630.5	0.0	3,630.5	105,300.0	382.3	0.5	0.2	0.8
08/09/2026 05:00	4,047.4	0.0	4,047.4	105,300.0	426.2	0.5	0.3	0.9
08/09/2026 06:00	3,595.2	47.0	3,595.2	105,300.0	378.6	0.5	0.2	0.8
08/09/2026 07:00	3,593.0	97.7	3,593.0	105,300.0	378.3	0.5	0.2	0.8
08/09/2026 08:00	3,584.7	125.3	3,584.7	105,300.0	377.5	0.5	0.2	0.8
08/09/2026 09:00	3,578.1	44.8	3,578.1	105,300.0	376.8	0.5	0.2	0.8
08/09/2026 10:00	3,575.6	81.4	3,575.6	105,300.0	376.5	0.5	0.2	0.8
08/09/2026 11:00	3,568.4	137.3	3,568.4	105,300.0	375.8	0.5	0.2	0.8
08/09/2026 12:00	3,654.9	149.1	3,654.9	105,300.0	384.9	0.5	0.2	0.8
08/09/2026 13:00	4,242.8	105.3	4,242.8	105,300.0	446.8	0.5	0.3	0.9
08/09/2026 14:00	4,449.8	899.2	5,169.2	105,300.0	544.3	0.7	0.3	1.1
08/09/2026 15:00	4,441.2	1,581.8	6,023.0	105,300.0	634.2	0.8	0.4	1.3
08/09/2026 16:00	4,430.5	1,681.4	6,111.9	105,300.0	643.6	0.8	0.4	1.3
08/09/2026 17:00	4,437.1	1,483.2	5,920.3	105,300.0	623.4	0.7	0.4	1.2
08/09/2026 18:00	4,472.4	1,606.6	6,079.0	105,300.0	640.1	0.8	0.4	1.3
08/09/2026 19:00	4,469.9	641.1	5,111.0	105,300.0	538.2	0.6	0.3	1.1
08/09/2026 20:00	4,238.3	950.1	5,188.4	105,300.0	546.3	0.7	0.3	1.1
08/09/2026 21:00	4,358.2	742.0	5,100.2	105,300.0	537.1	0.6	0.3	1.1
08/09/2026 22:00	3,708.8	8.9	3,708.8	105,300.0	390.5	0.5	0.2	0.8
08/09/2026 23:00	3,575.9	0.1	3,575.9	105,300.0	376.5	0.5	0.2	0.8
Average/Sum#:	3,917.4	432.6	4,309.3	105,300.0	453.8	0.6	0.3	0.9
Minimum:	3,568.4	0.0	3,568.4	105,300.0	375.8	0.5	0.2	0.8
Maximum:	4,472.4	1,681.4	6,111.9	105,300.0	643.6	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/10/2026 00:00	3,583.2	0.8	3,583.2	105,300.0	377.3	0.5	0.2	0.8
08/10/2026 01:00	3,586.2	0.0	3,586.2	105,300.0	377.6	0.5	0.2	0.8
08/10/2026 02:00	3,586.8	0.0	3,586.8	105,300.0	377.7	0.5	0.2	0.8
08/10/2026 03:00	3,589.0	0.0	3,589.0	105,300.0	377.9	0.5	0.2	0.8
08/10/2026 04:00	3,983.5	0.0	3,983.5	105,300.0	419.5	0.5	0.3	0.8
08/10/2026 05:00	3,595.7	0.0	3,595.7	105,300.0	378.6	0.5	0.2	0.8
08/10/2026 06:00	3,934.6	18.7	3,934.6	105,300.0	414.3	0.5	0.2	0.8
08/10/2026 07:00	3,590.5	64.9	3,590.5	105,300.0	378.1	0.5	0.2	0.8
08/10/2026 08:00	3,584.5	100.0	3,584.5	105,300.0	377.4	0.5	0.2	0.8
08/10/2026 09:00	3,580.8	36.0	3,580.8	105,300.0	377.1	0.5	0.2	0.8
08/10/2026 10:00	3,579.5	84.1	3,579.5	105,300.0	376.9	0.5	0.2	0.8
08/10/2026 11:00	3,573.6	138.3	3,573.6	105,300.0	376.3	0.5	0.2	0.8
08/10/2026 12:00	3,758.3	148.4	3,758.3	105,300.0	395.7	0.5	0.2	0.8
08/10/2026 13:00	4,098.7	105.7	4,098.7	105,300.0	431.6	0.5	0.3	0.9
08/10/2026 14:00	3,995.5	76.1	3,997.0	105,300.0	420.9	0.5	0.3	0.9
08/10/2026 15:00	4,535.3	608.8	5,144.1	105,300.0	541.7	0.6	0.3	1.1
08/10/2026 16:00	4,534.3	1,263.6	5,797.9	105,300.0	610.5	0.7	0.4	1.2
08/10/2026 17:00	4,545.6	1,531.1	6,076.7	105,300.0	639.9	0.8	0.4	1.3
08/10/2026 18:00	4,572.4	1,326.3	5,898.7	105,300.0	621.1	0.7	0.4	1.2
08/10/2026 19:00	4,612.4	835.4	5,447.8	105,300.0	573.7	0.7	0.3	1.1
08/10/2026 20:00	4,644.3	509.7	5,154.0	105,300.0	542.7	0.7	0.3	1.1
08/10/2026 21:00	4,667.4	735.9	5,403.3	105,300.0	569.0	0.7	0.3	1.1
08/10/2026 22:00	4,378.1	2.2	4,378.1	105,300.0	461.0	0.6	0.3	0.9
08/10/2026 23:00	3,804.0	0.7	3,804.0	105,300.0	400.6	0.5	0.2	0.8
Average/Sum#:	3,996.4	316.1	4,280.3	105,300.0	450.7	0.6	0.3	0.9
Minimum:	3,573.6	0.0	3,573.6	105,300.0	376.3	0.5	0.2	0.8
Maximum:	4,667.4	1,531.1	6,076.7	105,300.0	639.9	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/11/2026 00:00	3,868.6	0.0	3,868.6	105,300.0	407.4	0.5	0.2	0.8
08/11/2026 01:00	3,598.8	0.0	3,598.8	105,300.0	379.0	0.5	0.2	0.8
08/11/2026 02:00	3,598.7	0.0	3,598.7	105,300.0	378.9	0.5	0.2	0.8
08/11/2026 03:00	3,603.6	0.0	3,603.6	105,300.0	379.5	0.5	0.2	0.8
08/11/2026 04:00	3,641.9	0.0	3,641.9	105,300.0	383.5	0.5	0.2	0.8
08/11/2026 05:00	3,871.1	0.0	3,871.1	105,300.0	407.6	0.5	0.2	0.8
08/11/2026 06:00	4,021.6	5.1	4,021.6	105,300.0	423.5	0.5	0.3	0.8
08/11/2026 07:00	3,602.2	55.3	3,602.2	105,300.0	379.3	0.5	0.2	0.8
08/11/2026 08:00	3,597.6	103.4	3,597.6	105,300.0	378.8	0.5	0.2	0.8
08/11/2026 09:00	3,595.8	31.2	3,595.8	105,300.0	378.6	0.5	0.2	0.8
08/11/2026 10:00	3,693.4	60.3	3,693.4	105,300.0	388.9	0.5	0.2	0.8
08/11/2026 11:00	4,309.2	137.5	4,309.2	105,300.0	453.8	0.6	0.3	0.9
08/11/2026 12:00	4,495.5	152.2	4,500.1	105,300.0	473.9	0.6	0.3	1.0
08/11/2026 13:00	4,598.1	777.2	5,375.3	105,300.0	566.0	0.7	0.3	1.1
08/11/2026 14:00	4,586.4	650.9	5,237.3	105,300.0	551.5	0.7	0.3	1.1
08/11/2026 15:00	4,572.9	623.4	5,196.3	105,300.0	547.2	0.7	0.3	1.1
08/11/2026 16:00	4,568.5	1,305.8	5,874.3	105,300.0	618.6	0.7	0.4	1.2
08/11/2026 17:00	4,587.2	1,668.4	6,255.6	105,300.0	658.7	0.8	0.4	1.3
08/11/2026 18:00	4,602.0	1,297.2	5,899.2	105,300.0	621.2	0.7	0.4	1.2
08/11/2026 19:00	4,628.4	1,245.0	5,873.4	105,300.0	618.5	0.7	0.4	1.2
08/11/2026 20:00	4,657.2	894.9	5,552.1	105,300.0	584.6	0.7	0.4	1.2
08/11/2026 21:00	4,379.5	2.1	4,379.5	105,300.0	461.2	0.6	0.3	0.9
08/11/2026 22:00	4,093.1	0.1	4,093.1	105,300.0	431.0	0.5	0.3	0.9
08/11/2026 23:00	3,672.3	0.6	3,672.3	105,300.0	386.7	0.5	0.2	0.8
Average/Sum#:	4,101.8	375.4	4,454.6	105,300.0	469.1	0.6	0.3	0.9
Minimum:	3,595.8	0.0	3,595.8	105,300.0	378.6	0.5	0.2	0.8
Maximum:	4,657.2	1,668.4	6,255.6	105,300.0	658.7	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/12/2026 00:00	3,591.5	0.0	3,591.5	105,300.0	378.2	0.5	0.2	0.8
08/12/2026 01:00	3,594.5	0.0	3,594.5	105,300.0	378.5	0.5	0.2	0.8
08/12/2026 02:00	3,595.3	0.0	3,595.3	105,300.0	378.6	0.5	0.2	0.8
08/12/2026 03:00	3,598.5	0.0	3,598.5	105,300.0	378.9	0.5	0.2	0.8
08/12/2026 04:00	3,951.0	0.0	3,951.0	105,300.0	416.0	0.5	0.2	0.8
08/12/2026 05:00	4,275.3	0.0	4,275.3	105,300.0	450.2	0.5	0.3	0.9
08/12/2026 06:00	3,594.1	0.0	3,594.1	105,300.0	378.5	0.5	0.2	0.8
08/12/2026 07:00	3,598.0	0.0	3,598.0	105,300.0	378.9	0.5	0.2	0.8
08/12/2026 08:00	3,593.1	16.7	3,593.1	105,300.0	378.4	0.5	0.2	0.8
08/12/2026 09:00	3,588.0	2.0	3,588.0	105,300.0	377.8	0.5	0.2	0.8
08/12/2026 10:00	3,582.1	32.4	3,582.1	105,300.0	377.2	0.5	0.2	0.8
08/12/2026 11:00	3,578.6	108.3	3,578.6	105,300.0	376.8	0.5	0.2	0.8
08/12/2026 12:00	3,610.2	136.5	3,610.2	105,300.0	380.2	0.5	0.2	0.8
08/12/2026 13:00	4,551.1	474.2	5,015.8	105,300.0	528.2	0.6	0.3	1.1
08/12/2026 14:00	4,563.0	449.9	5,012.9	105,300.0	527.9	0.6	0.3	1.1
08/12/2026 15:00	4,571.0	435.5	5,006.5	105,300.0	527.2	0.6	0.3	1.1
08/12/2026 16:00	4,560.0	446.4	5,006.4	105,300.0	527.2	0.6	0.3	1.1
08/12/2026 17:00	4,586.7	408.3	4,995.0	105,300.0	526.0	0.6	0.3	1.1
08/12/2026 18:00	4,607.3	378.7	4,986.0	105,300.0	525.0	0.6	0.3	1.0
08/12/2026 19:00	4,645.3	318.1	4,963.4	105,300.0	522.6	0.6	0.3	1.0
08/12/2026 20:00	4,609.2	363.9	4,973.1	105,300.0	523.7	0.6	0.3	1.0
08/12/2026 21:00	3,752.1	6.9	3,752.4	105,300.0	395.1	0.5	0.2	0.8
08/12/2026 22:00	3,584.1	0.0	3,584.1	105,300.0	377.4	0.5	0.2	0.8
08/12/2026 23:00	3,585.8	0.0	3,585.8	105,300.0	377.6	0.5	0.2	0.8
Average/Sum#:	3,973.6	149.1	4,109.7	105,300.0	432.8	0.5	0.2	0.9
Minimum:	3,578.6	0.0	3,578.6	105,300.0	376.8	0.5	0.2	0.8
Maximum:	4,645.3	474.2	5,015.8	105,300.0	528.2	0.6	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/13/2026 00:00	3,587.9	0.0	3,587.9	105,300.0	377.8	0.5	0.2	0.8
08/13/2026 01:00	3,591.4	0.0	3,591.4	105,300.0	378.2	0.5	0.2	0.8
08/13/2026 02:00	3,597.2	0.0	3,597.2	105,300.0	378.8	0.5	0.2	0.8
08/13/2026 03:00	3,601.9	0.0	3,601.9	105,300.0	379.3	0.5	0.2	0.8
08/13/2026 04:00	3,604.5	0.0	3,604.5	105,300.0	379.6	0.5	0.2	0.8
08/13/2026 05:00	3,608.5	0.0	3,608.5	105,300.0	380.0	0.5	0.2	0.8
08/13/2026 06:00	3,607.7	0.0	3,607.7	105,300.0	379.9	0.5	0.2	0.8
08/13/2026 07:00	3,604.1	0.8	3,604.1	105,300.0	379.5	0.5	0.2	0.8
08/13/2026 08:00	3,602.8	45.0	3,602.8	105,100.0	378.7	0.5	0.2	0.8
08/13/2026 09:00	3,599.1	0.0	3,599.1	105,100.0	378.3	0.5	0.2	0.8
08/13/2026 10:00	3,592.9	0.0	3,592.9	105,100.0	377.6	0.5	0.2	0.8
08/13/2026 11:00	3,586.8	97.4	3,586.8	105,100.0	377.0	0.5	0.2	0.8
08/13/2026 12:00	3,845.8	129.9	3,849.7	105,100.0	404.6	0.5	0.3	0.8
08/13/2026 13:00	4,477.1	533.1	5,010.2	105,100.0	526.6	0.6	0.3	1.1
08/13/2026 14:00	4,443.3	581.2	5,024.5	105,100.0	528.1	0.6	0.3	1.1
08/13/2026 15:00	4,468.5	548.5	5,017.0	105,100.0	527.3	0.6	0.3	1.1
08/13/2026 16:00	4,502.4	495.5	4,997.9	105,100.0	525.3	0.6	0.3	1.1
08/13/2026 17:00	4,533.7	448.7	4,982.4	105,100.0	523.7	0.6	0.3	1.0
08/13/2026 18:00	4,562.0	400.4	4,962.4	105,100.0	521.5	0.6	0.3	1.0
08/13/2026 19:00	3,636.6	0.0	3,636.6	105,100.0	382.2	0.5	0.2	0.8
08/13/2026 20:00	3,597.7	0.0	3,597.7	105,100.0	378.1	0.5	0.2	0.8
08/13/2026 21:00	3,599.1	0.0	3,599.1	105,100.0	378.3	0.5	0.2	0.8
08/13/2026 22:00	3,601.3	0.0	3,601.3	105,100.0	378.5	0.5	0.2	0.8
08/13/2026 23:00	3,601.8	0.0	3,601.8	105,100.0	378.5	0.5	0.2	0.8
Average/Sum#:	3,835.6	136.7	3,961.1	105,166.7	416.6	0.5	0.2	0.9
Minimum:	3,586.8	0.0	3,586.8	105,100.0	377.0	0.5	0.2	0.8
Maximum:	4,562.0	581.2	5,024.5	105,300.0	528.1	0.6	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/14/2026 00:00	3,604.7	0.0	3,604.7	105,100.0	378.9	0.5	0.2	0.8
08/14/2026 01:00	3,607.6	0.0	3,607.6	105,100.0	379.2	0.5	0.2	0.8
08/14/2026 02:00	3,607.6	0.0	3,607.6	105,100.0	379.2	0.5	0.2	0.8
08/14/2026 03:00	3,607.2	0.0	3,607.2	105,100.0	379.1	0.5	0.2	0.8
08/14/2026 04:00	3,608.0	0.0	3,608.0	105,100.0	379.2	0.5	0.2	0.8
08/14/2026 05:00	3,640.5	0.0	3,640.5	105,100.0	382.6	0.5	0.2	0.8
08/14/2026 06:00	3,754.6	0.0	3,754.6	105,100.0	394.6	0.5	0.2	0.8
08/14/2026 07:00	3,606.4	0.0	3,606.4	105,100.0	379.0	0.5	0.2	0.8
08/14/2026 08:00	3,606.6	0.0	3,606.6	105,100.0	379.1	0.5	0.2	0.8
08/14/2026 09:00	3,603.7	0.0	3,603.7	105,100.0	378.7	0.5	0.2	0.8
08/14/2026 10:00	3,600.5	0.0	3,600.5	105,100.0	378.4	0.5	0.2	0.8
08/14/2026 11:00	3,599.6	73.6	3,599.6	105,100.0	378.3	0.5	0.2	0.8
08/14/2026 12:00	3,595.9	96.1	3,595.9	105,100.0	377.9	0.5	0.2	0.8
08/14/2026 13:00	3,593.0	80.5	3,593.0	105,100.0	377.6	0.5	0.2	0.8
08/14/2026 14:00	3,590.0	0.0	3,590.0	105,100.0	377.3	0.5	0.2	0.8
08/14/2026 15:00	3,590.1	0.2	3,590.1	105,100.0	377.3	0.5	0.2	0.8
08/14/2026 16:00	3,588.7	0.0	3,588.7	105,100.0	377.2	0.5	0.2	0.8
08/14/2026 17:00	3,768.0	41.6	3,768.0	105,100.0	396.0	0.5	0.2	0.8
08/14/2026 18:00	3,614.0	0.0	3,614.0	105,100.0	379.8	0.5	0.2	0.8
08/14/2026 19:00	3,600.7	0.0	3,600.7	105,100.0	378.4	0.5	0.2	0.8
08/14/2026 20:00	3,608.6	0.0	3,608.6	105,100.0	379.3	0.5	0.2	0.8
08/14/2026 21:00	3,612.3	0.0	3,612.3	105,100.0	379.7	0.5	0.2	0.8
08/14/2026 22:00	3,617.2	0.0	3,617.2	105,100.0	380.2	0.5	0.2	0.8
08/14/2026 23:00	3,619.3	0.0	3,619.3	105,100.0	380.4	0.5	0.2	0.8
Average/Sum#:	3,618.5	12.2	3,618.5	105,100.0	380.3	0.5	0.2	0.8
Minimum:	3,588.7	0.0	3,588.7	105,100.0	377.2	0.5	0.2	0.8
Maximum:	3,768.0	96.1	3,768.0	105,100.0	396.0	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/15/2026 00:00	3,621.4	0.0	3,621.4	105,100.0	380.6	0.5	0.2	0.8
08/15/2026 01:00	3,623.6	0.0	3,623.6	105,100.0	380.8	0.5	0.2	0.8
08/15/2026 02:00	3,623.7	0.0	3,623.7	105,100.0	380.9	0.5	0.2	0.8
08/15/2026 03:00	3,613.5	0.0	3,613.5	105,100.0	379.8	0.5	0.2	0.8
08/15/2026 04:00	3,604.9	0.0	3,604.9	105,100.0	378.9	0.5	0.2	0.8
08/15/2026 05:00	3,600.0	0.0	3,600.0	105,100.0	378.4	0.5	0.2	0.8
08/15/2026 06:00	3,598.5	0.0	3,598.5	105,100.0	378.2	0.5	0.2	0.8
08/15/2026 07:00	3,595.7	0.0	3,595.7	105,100.0	377.9	0.5	0.2	0.8
08/15/2026 08:00	3,593.1	1.0	3,593.1	105,100.0	377.6	0.5	0.2	0.8
08/15/2026 09:00	3,595.9	0.0	3,595.9	105,100.0	377.9	0.5	0.2	0.8
08/15/2026 10:00	3,595.4	0.0	3,595.4	105,100.0	377.9	0.5	0.2	0.8
08/15/2026 11:00	3,591.1	87.5	3,591.1	105,100.0	377.4	0.5	0.2	0.8
08/15/2026 12:00	3,590.9	90.1	3,590.9	105,100.0	377.4	0.5	0.2	0.8
08/15/2026 13:00	3,586.8	73.6	3,586.8	105,100.0	377.0	0.5	0.2	0.8
08/15/2026 14:00	3,587.4	0.3	3,587.4	105,100.0	377.0	0.5	0.2	0.8
08/15/2026 15:00	3,585.8	10.8	3,585.8	105,100.0	376.9	0.5	0.2	0.8
08/15/2026 16:00	3,780.0	1.7	3,780.0	105,100.0	397.3	0.5	0.2	0.8
08/15/2026 17:00	3,946.1	62.1	3,946.1	105,100.0	414.7	0.5	0.3	0.8
08/15/2026 18:00	3,680.4	5.7	3,680.4	105,100.0	386.8	0.5	0.2	0.8
08/15/2026 19:00	3,813.4	0.0	3,813.4	105,100.0	400.8	0.5	0.2	0.8
08/15/2026 20:00	3,605.8	0.0	3,605.8	105,100.0	379.0	0.5	0.2	0.8
08/15/2026 21:00	4,383.8	0.0	4,383.8	105,100.0	460.7	0.6	0.3	0.9
08/15/2026 22:00	4,292.9	0.0	4,292.9	105,100.0	451.2	0.5	0.3	0.9
08/15/2026 23:00	4,393.4	0.0	4,393.4	105,100.0	461.7	0.6	0.3	0.9
Average/Sum#:	3,729.3	13.9	3,729.3	105,100.0	392.0	0.5	0.2	0.8
Minimum:	3,585.8	0.0	3,585.8	105,100.0	376.9	0.5	0.2	0.8
Maximum:	4,393.4	90.1	4,393.4	105,100.0	461.7	0.6	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/16/2026 00:00	4,361.5	0.0	4,361.5	105,100.0	458.4	0.5	0.3	0.9
08/16/2026 01:00	3,595.6	0.0	3,595.6	105,100.0	377.9	0.5	0.2	0.8
08/16/2026 02:00	3,597.5	0.0	3,597.5	105,100.0	378.1	0.5	0.2	0.8
08/16/2026 03:00	3,601.6	0.0	3,601.6	105,100.0	378.5	0.5	0.2	0.8
08/16/2026 04:00	3,605.3	0.0	3,605.3	105,100.0	378.9	0.5	0.2	0.8
08/16/2026 05:00	3,608.1	0.0	3,608.1	105,100.0	379.2	0.5	0.2	0.8
08/16/2026 06:00	3,609.0	0.0	3,609.0	105,100.0	379.3	0.5	0.2	0.8
08/16/2026 07:00	3,606.8	11.6	3,606.8	105,100.0	379.1	0.5	0.2	0.8
08/16/2026 08:00	3,599.4	62.3	3,599.4	105,100.0	378.3	0.5	0.2	0.8
08/16/2026 09:00	3,596.7	0.0	3,596.7	105,100.0	378.0	0.5	0.2	0.8
08/16/2026 10:00	3,588.9	0.0	3,588.9	105,100.0	377.2	0.5	0.2	0.8
08/16/2026 11:00	3,580.9	86.6	3,580.9	105,100.0	376.4	0.5	0.2	0.8
08/16/2026 12:00	3,834.6	93.8	3,834.6	105,100.0	403.0	0.5	0.2	0.8
08/16/2026 13:00	4,562.5	439.5	4,993.2	105,100.0	524.8	0.6	0.3	1.1
08/16/2026 14:00	4,565.8	431.8	4,997.6	105,100.0	525.2	0.6	0.3	1.1
08/16/2026 15:00	4,565.0	431.4	4,996.4	105,100.0	525.1	0.6	0.3	1.1
08/16/2026 16:00	4,556.6	514.5	5,071.1	105,100.0	533.0	0.6	0.3	1.1
08/16/2026 17:00	4,551.5	709.1	5,260.6	105,100.0	552.9	0.7	0.3	1.1
08/16/2026 18:00	4,555.1	499.7	5,054.8	105,100.0	531.3	0.6	0.3	1.1
08/16/2026 19:00	4,587.8	390.0	4,977.8	105,100.0	523.2	0.6	0.3	1.0
08/16/2026 20:00	4,467.5	551.8	5,019.3	105,100.0	527.5	0.6	0.3	1.1
08/16/2026 21:00	4,373.9	6.5	4,374.1	105,100.0	459.7	0.6	0.3	0.9
08/16/2026 22:00	4,254.2	0.0	4,254.2	105,100.0	447.1	0.5	0.3	0.9
08/16/2026 23:00	3,568.7	0.0	3,568.7	105,100.0	375.1	0.5	0.2	0.8
Average/Sum#:	4,016.4	176.2	4,181.4	105,100.0	439.5	0.5	0.2	0.9
Minimum:	3,568.7	0.0	3,568.7	105,100.0	375.1	0.5	0.2	0.8
Maximum:	4,587.8	709.1	5,260.6	105,100.0	552.9	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/17/2026 00:00	3,573.9	0.0	3,573.9	105,100.0	375.6	0.5	0.2	0.8
08/17/2026 01:00	3,574.8	0.0	3,574.8	105,100.0	375.7	0.5	0.2	0.8
08/17/2026 02:00	3,575.9	0.0	3,575.9	105,100.0	375.8	0.5	0.2	0.8
08/17/2026 03:00	3,578.2	0.1	3,578.2	105,100.0	376.1	0.5	0.2	0.8
08/17/2026 04:00	3,617.3	0.0	3,617.3	105,100.0	380.2	0.5	0.2	0.8
08/17/2026 05:00	3,584.3	0.0	3,584.3	105,100.0	376.7	0.5	0.2	0.8
08/17/2026 06:00	3,581.1	0.0	3,581.1	105,100.0	376.4	0.5	0.2	0.8
08/17/2026 07:00	3,581.7	0.2	3,581.7	105,100.0	376.4	0.5	0.2	0.8
08/17/2026 08:00	3,579.0	73.9	3,579.0	105,100.0	376.2	0.5	0.2	0.8
08/17/2026 09:00	3,574.3	0.0	3,574.3	105,100.0	375.7	0.5	0.2	0.8
08/17/2026 10:00	3,569.3	4.7	3,569.3	105,100.0	375.1	0.5	0.2	0.8
08/17/2026 11:00	3,564.2	86.7	3,564.2	105,100.0	374.6	0.5	0.2	0.8
08/17/2026 12:00	3,821.2	88.3	3,823.8	105,100.0	401.9	0.5	0.2	0.8
08/17/2026 13:00	4,569.5	420.5	4,990.0	105,100.0	524.4	0.6	0.3	1.0
08/17/2026 14:00	4,557.2	976.4	5,533.6	105,100.0	581.6	0.7	0.3	1.2
08/17/2026 15:00	4,539.5	1,062.8	5,602.3	105,100.0	588.8	0.7	0.4	1.2
08/17/2026 16:00	4,546.0	805.4	5,351.4	105,100.0	562.4	0.7	0.3	1.1
08/17/2026 17:00	4,563.1	1,372.5	5,935.6	105,100.0	623.8	0.7	0.4	1.2
08/17/2026 18:00	4,583.3	1,024.6	5,607.9	105,100.0	589.4	0.7	0.4	1.2
08/17/2026 19:00	4,603.7	695.9	5,299.6	105,100.0	557.0	0.7	0.3	1.1
08/17/2026 20:00	4,427.3	607.2	5,034.5	105,100.0	529.1	0.6	0.3	1.1
08/17/2026 21:00	3,932.7	4.2	3,932.8	105,100.0	413.3	0.5	0.2	0.8
08/17/2026 22:00	3,768.2	0.0	3,768.2	105,100.0	396.0	0.5	0.2	0.8
08/17/2026 23:00	3,575.4	0.0	3,575.4	105,100.0	375.8	0.5	0.2	0.8
Average/Sum#:	3,935.0	301.0	4,225.4	105,100.0	444.1	0.6	0.2	0.9
Minimum:	3,564.2	0.0	3,564.2	105,100.0	374.6	0.5	0.2	0.8
Maximum:	4,603.7	1,372.5	5,935.6	105,100.0	623.8	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/18/2026 00:00	3,579.0	0.0	3,579.0	105,100.0	376.2	0.5	0.2	0.8
08/18/2026 01:00	3,580.7	0.0	3,580.7	105,100.0	376.3	0.5	0.2	0.8
08/18/2026 02:00	3,583.9	0.0	3,583.9	105,100.0	376.7	0.5	0.2	0.8
08/18/2026 03:00	3,587.4	0.0	3,587.4	105,100.0	377.0	0.5	0.2	0.8
08/18/2026 04:00	3,591.0	0.0	3,591.0	105,100.0	377.4	0.5	0.2	0.8
08/18/2026 05:00	3,591.9	0.0	3,591.9	105,100.0	377.5	0.5	0.2	0.8
08/18/2026 06:00	3,593.0	0.0	3,593.0	105,100.0	377.6	0.5	0.2	0.8
08/18/2026 07:00	3,586.3	0.1	3,586.3	105,100.0	376.9	0.5	0.2	0.8
08/18/2026 08:00	3,582.1	35.0	3,582.1	105,100.0	376.5	0.5	0.2	0.8
08/18/2026 09:00	3,575.3	0.0	3,575.3	105,100.0	375.8	0.5	0.2	0.8
08/18/2026 10:00	3,568.6	5.3	3,568.6	105,100.0	375.1	0.5	0.2	0.8
08/18/2026 11:00	3,563.3	88.6	3,563.3	105,100.0	374.5	0.5	0.2	0.8
08/18/2026 12:00	3,760.8	119.9	3,778.8	105,100.0	397.2	0.5	0.2	0.8
08/18/2026 13:00	4,154.1	1,030.7	5,184.8	105,100.0	544.9	0.7	0.3	1.1
08/18/2026 14:00	4,095.7	1,260.4	5,356.1	105,100.0	562.9	0.7	0.3	1.1
08/18/2026 15:00	4,011.4	1,252.3	5,263.7	105,100.0	553.2	0.7	0.3	1.1
08/18/2026 16:00	4,161.0	1,395.4	5,556.4	105,100.0	584.0	0.7	0.4	1.2
08/18/2026 17:00	4,535.6	1,691.6	6,227.2	105,100.0	654.5	0.8	0.4	1.3
08/18/2026 18:00	4,533.4	1,431.0	5,964.4	105,100.0	626.9	0.8	0.4	1.3
08/18/2026 19:00	4,580.9	779.0	5,359.9	105,100.0	563.3	0.7	0.3	1.1
08/18/2026 20:00	4,607.9	350.0	4,957.9	105,100.0	521.1	0.6	0.3	1.0
08/18/2026 21:00	4,034.2	2.5	4,034.3	105,100.0	424.0	0.5	0.3	0.8
08/18/2026 22:00	3,764.3	0.0	3,764.3	105,100.0	395.6	0.5	0.2	0.8
08/18/2026 23:00	3,637.8	0.0	3,637.8	105,100.0	382.3	0.5	0.2	0.8
Average/Sum#:	3,869.2	393.4	4,252.8	105,100.0	447.0	0.6	0.3	0.9
Minimum:	3,563.3	0.0	3,563.3	105,100.0	374.5	0.5	0.2	0.8
Maximum:	4,607.9	1,691.6	6,227.2	105,100.0	654.5	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/19/2026 00:00	3,578.0	0.0	3,578.0	105,100.0	376.0	0.5	0.2	0.8
08/19/2026 01:00	3,581.6	0.0	3,581.6	105,100.0	376.4	0.5	0.2	0.8
08/19/2026 02:00	3,582.9	0.0	3,582.9	105,100.0	376.6	0.5	0.2	0.8
08/19/2026 03:00	3,585.4	0.0	3,585.4	105,100.0	376.8	0.5	0.2	0.8
08/19/2026 04:00	3,586.7	0.0	3,586.7	105,100.0	377.0	0.5	0.2	0.8
08/19/2026 05:00	3,590.5	0.0	3,590.5	105,100.0	377.4	0.5	0.2	0.8
08/19/2026 06:00	3,588.5	0.0	3,588.5	105,100.0	377.2	0.5	0.2	0.8
08/19/2026 07:00	3,585.3	29.6	3,585.3	105,100.0	376.8	0.5	0.2	0.8
08/19/2026 08:00	3,581.3	71.2	3,581.3	105,100.0	376.4	0.5	0.2	0.8
08/19/2026 09:00	3,573.4	0.0	3,573.4	105,100.0	375.6	0.5	0.2	0.8
08/19/2026 10:00	3,571.5	57.6	3,571.5	105,100.0	375.4	0.5	0.2	0.8
08/19/2026 11:00	3,569.2	100.3	3,569.2	105,100.0	375.1	0.5	0.2	0.8
08/19/2026 12:00	3,736.3	173.1	3,762.3	105,100.0	395.4	0.5	0.2	0.8
08/19/2026 13:00	4,003.0	1,342.9	5,345.9	105,100.0	561.9	0.7	0.3	1.1
08/19/2026 14:00	4,126.2	1,424.1	5,550.3	105,100.0	583.3	0.7	0.4	1.2
08/19/2026 15:00	4,177.3	1,224.3	5,401.6	105,100.0	567.7	0.7	0.3	1.1
08/19/2026 16:00	4,008.8	1,485.9	5,494.7	105,100.0	577.5	0.7	0.3	1.2
08/19/2026 17:00	4,531.0	1,608.9	6,139.9	105,100.0	645.3	0.8	0.4	1.3
08/19/2026 18:00	4,551.0	1,598.4	6,149.4	105,100.0	646.3	0.8	0.4	1.3
08/19/2026 19:00	4,574.2	1,408.2	5,982.4	105,100.0	628.8	0.8	0.4	1.3
08/19/2026 20:00	4,594.9	969.3	5,564.2	105,100.0	584.8	0.7	0.4	1.2
08/19/2026 21:00	4,308.1	2.5	4,308.2	105,100.0	452.8	0.5	0.3	0.9
08/19/2026 22:00	4,377.2	0.0	4,377.2	105,100.0	460.0	0.6	0.3	0.9
08/19/2026 23:00	4,361.3	0.0	4,361.3	105,100.0	458.4	0.6	0.3	0.9
Average/Sum#:	3,930.2	479.0	4,392.2	105,100.0	461.6	0.6	0.3	1.0
Minimum:	3,569.2	0.0	3,569.2	105,100.0	375.1	0.5	0.2	0.8
Maximum:	4,594.9	1,608.9	6,149.4	105,100.0	646.3	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/20/2026 00:00	3,998.7	0.0	3,998.7	105,100.0	420.3	0.5	0.3	0.8
08/20/2026 01:00	3,602.9	0.0	3,602.9	105,100.0	378.7	0.5	0.2	0.8
08/20/2026 02:00	3,599.0	0.0	3,599.0	105,100.0	378.3	0.5	0.2	0.8
08/20/2026 03:00	3,590.7	0.0	3,590.7	105,100.0	377.4	0.5	0.2	0.8
08/20/2026 04:00	3,592.7	0.0	3,592.7	105,100.0	377.6	0.5	0.2	0.8
08/20/2026 05:00	3,601.8	0.0	3,601.8	105,100.0	378.5	0.5	0.2	0.8
08/20/2026 06:00	3,626.2	0.0	3,626.2	105,100.0	381.1	0.5	0.2	0.8
08/20/2026 07:00	3,598.7	0.3	3,598.7	105,100.0	378.2	0.5	0.2	0.8
08/20/2026 08:00	3,595.3	0.7	3,595.3	105,100.0	377.9	0.5	0.2	0.8
08/20/2026 09:00	3,588.4	0.0	3,588.4	105,100.0	377.1	0.5	0.2	0.8
08/20/2026 10:00	3,585.1	0.1	3,585.1	105,100.0	376.8	0.5	0.2	0.8
08/20/2026 11:00	3,605.8	22.7	3,605.8	105,100.0	379.0	0.5	0.2	0.8
08/20/2026 12:00	3,832.8	160.8	3,861.7	105,100.0	405.9	0.5	0.3	0.8
08/20/2026 13:00	4,158.8	1,090.0	5,248.8	105,100.0	551.6	0.7	0.3	1.1
08/20/2026 14:00	4,239.3	1,040.1	5,279.4	105,100.0	554.9	0.7	0.3	1.1
08/20/2026 15:00	4,061.5	1,219.1	5,280.6	105,100.0	555.0	0.7	0.3	1.1
08/20/2026 16:00	4,121.1	1,295.7	5,416.8	105,100.0	569.3	0.7	0.3	1.1
08/20/2026 17:00	4,551.4	1,681.3	6,232.7	105,100.0	655.1	0.8	0.4	1.3
08/20/2026 18:00	4,595.7	1,448.9	6,044.6	105,100.0	635.3	0.8	0.4	1.3
08/20/2026 19:00	4,627.0	1,423.3	6,050.3	105,100.0	635.9	0.8	0.4	1.3
08/20/2026 20:00	4,625.2	990.0	5,615.2	105,100.0	590.2	0.7	0.4	1.2
08/20/2026 21:00	4,361.2	4.3	4,361.3	105,100.0	458.4	0.6	0.3	0.9
08/20/2026 22:00	4,358.1	0.1	4,358.1	105,100.0	458.0	0.6	0.3	0.9
08/20/2026 23:00	4,358.4	0.0	4,358.4	105,100.0	458.1	0.6	0.3	0.9
Average/Sum#:	3,978.2	432.4	4,403.9	105,100.0	462.9	0.6	0.3	0.9
Minimum:	3,585.1	0.0	3,585.1	105,100.0	376.8	0.5	0.2	0.8
Maximum:	4,627.0	1,681.3	6,232.7	105,100.0	655.1	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/21/2026 00:00	4,358.6	0.0	4,358.6	105,100.0	458.1	0.6	0.3	0.9
08/21/2026 01:00	3,755.0	0.0	3,755.0	105,100.0	394.7	0.5	0.2	0.8
08/21/2026 02:00	3,957.1	0.0	3,957.1	105,100.0	415.9	0.5	0.2	0.8
08/21/2026 03:00	3,674.5	0.0	3,674.5	105,100.0	386.2	0.5	0.2	0.8
08/21/2026 04:00	3,659.8	0.0	3,659.8	105,100.0	384.6	0.5	0.2	0.8
08/21/2026 05:00	4,385.4	0.0	4,385.4	105,100.0	460.9	0.6	0.3	0.9
08/21/2026 06:00	3,877.9	0.0	3,877.9	105,100.0	407.6	0.5	0.2	0.8
08/21/2026 07:00	3,603.7	0.0	3,603.7	105,100.0	378.7	0.5	0.2	0.8
08/21/2026 08:00	3,603.8	0.7	3,603.8	105,100.0	378.8	0.5	0.2	0.8
08/21/2026 09:00	3,598.3	0.0	3,598.3	105,100.0	378.2	0.5	0.2	0.8
08/21/2026 10:00	3,593.6	0.0	3,593.6	105,100.0	377.7	0.5	0.2	0.8
08/21/2026 11:00	3,586.9	2.5	3,586.9	105,100.0	377.0	0.5	0.2	0.8
08/21/2026 12:00	3,847.5	71.9	3,847.5	105,100.0	404.4	0.5	0.2	0.8
08/21/2026 13:00	4,262.4	905.1	5,149.4	105,100.0	541.2	0.7	0.3	1.1
08/21/2026 14:00	4,082.1	1,161.6	5,243.7	105,100.0	551.1	0.7	0.3	1.1
08/21/2026 15:00	4,053.6	1,157.7	5,211.3	105,100.0	547.7	0.7	0.3	1.1
08/21/2026 16:00	4,056.3	1,305.7	5,362.0	105,100.0	563.5	0.7	0.3	1.1
08/21/2026 17:00	4,565.5	1,605.4	6,170.9	105,100.0	648.6	0.8	0.4	1.3
08/21/2026 18:00	4,609.7	572.6	5,182.3	105,100.0	544.7	0.7	0.3	1.1
08/21/2026 19:00	4,633.4	366.3	4,999.7	105,100.0	525.5	0.6	0.3	1.0
08/21/2026 20:00	4,653.7	349.5	5,003.2	105,100.0	525.8	0.6	0.3	1.1
08/21/2026 21:00	3,641.8	0.0	3,641.8	105,100.0	382.8	0.5	0.2	0.8
08/21/2026 22:00	3,588.3	0.0	3,588.3	105,100.0	377.1	0.5	0.2	0.8
08/21/2026 23:00	4,100.3	0.0	4,100.3	105,100.0	430.9	0.5	0.3	0.9
Average/Sum#:	3,989.6	312.5	4,298.1	105,100.0	451.7	0.6	0.3	0.9
Minimum:	3,586.9	0.0	3,586.9	105,100.0	377.0	0.5	0.2	0.8
Maximum:	4,653.7	1,605.4	6,170.9	105,100.0	648.6	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/22/2026 00:00	4,031.9	0.0	4,031.9	105,100.0	423.8	0.5	0.3	0.8
08/22/2026 01:00	3,936.7	0.0	3,936.7	105,100.0	413.7	0.5	0.2	0.8
08/22/2026 02:00	3,594.7	0.0	3,594.7	105,100.0	377.8	0.5	0.2	0.8
08/22/2026 03:00	3,597.9	0.0	3,597.9	105,100.0	378.1	0.5	0.2	0.8
08/22/2026 04:00	3,903.0	0.0	3,903.0	105,100.0	410.2	0.5	0.2	0.8
08/22/2026 05:00	3,618.9	0.0	3,618.9	105,100.0	380.3	0.5	0.2	0.8
08/22/2026 06:00	3,603.4	0.0	3,603.4	105,100.0	378.7	0.5	0.2	0.8
08/22/2026 07:00	3,600.8	0.0	3,600.8	105,100.0	378.4	0.5	0.2	0.8
08/22/2026 08:00	3,596.0	24.8	3,596.0	105,100.0	377.9	0.5	0.2	0.8
08/22/2026 09:00	3,592.7	0.0	3,592.7	105,100.0	377.6	0.5	0.2	0.8
08/22/2026 10:00	3,587.8	5.8	3,587.8	105,100.0	377.1	0.5	0.2	0.8
08/22/2026 11:00	3,577.7	12.8	3,577.7	105,100.0	376.0	0.5	0.2	0.8
08/22/2026 12:00	3,826.2	76.7	3,826.2	105,100.0	402.1	0.5	0.2	0.8
08/22/2026 13:00	4,599.1	405.9	4,996.9	105,100.0	525.2	0.6	0.3	1.1
08/22/2026 14:00	4,582.7	412.9	4,995.6	105,100.0	525.0	0.6	0.3	1.0
08/22/2026 15:00	4,581.9	412.3	4,994.2	105,100.0	524.9	0.6	0.3	1.1
08/22/2026 16:00	4,539.8	477.8	5,017.6	105,100.0	527.3	0.6	0.3	1.1
08/22/2026 17:00	4,108.1	1,055.5	5,163.6	105,100.0	542.7	0.7	0.3	1.1
08/22/2026 18:00	4,131.2	1,016.8	5,148.0	105,100.0	541.1	0.6	0.3	1.1
08/22/2026 19:00	4,272.6	811.3	5,083.9	105,100.0	534.3	0.6	0.3	1.1
08/22/2026 20:00	4,432.5	601.3	5,033.8	105,100.0	529.1	0.6	0.3	1.1
08/22/2026 21:00	3,697.5	19.8	3,698.9	105,100.0	388.8	0.5	0.2	0.8
08/22/2026 22:00	3,586.4	0.0	3,586.4	105,100.0	376.9	0.5	0.2	0.8
08/22/2026 23:00	3,593.3	0.0	3,593.3	105,100.0	377.7	0.5	0.2	0.8
Average/Sum#:	3,924.7	222.2	4,140.8	105,100.0	435.2	0.5	0.2	0.9
Minimum:	3,577.7	0.0	3,577.7	105,100.0	376.0	0.5	0.2	0.8
Maximum:	4,599.1	1,055.5	5,163.6	105,100.0	542.7	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/23/2026 00:00	3,882.1	0.0	3,882.1	105,100.0	408.0	0.5	0.2	0.8
08/23/2026 01:00	3,608.5	0.0	3,608.5	105,100.0	379.3	0.5	0.2	0.8
08/23/2026 02:00	3,594.7	0.0	3,594.7	105,100.0	377.8	0.5	0.2	0.8
08/23/2026 03:00	3,597.8	0.0	3,597.8	105,100.0	378.1	0.5	0.2	0.8
08/23/2026 04:00	3,601.7	0.0	3,601.7	105,100.0	378.5	0.5	0.2	0.8
08/23/2026 05:00	3,605.1	0.0	3,605.1	105,100.0	378.9	0.5	0.2	0.8
08/23/2026 06:00	3,603.5	0.0	3,603.5	105,100.0	378.7	0.5	0.2	0.8
08/23/2026 07:00	3,596.4	0.5	3,596.4	105,100.0	378.0	0.5	0.2	0.8
08/23/2026 08:00	3,588.6	16.8	3,588.6	105,100.0	377.2	0.5	0.2	0.8
08/23/2026 09:00	3,582.2	0.0	3,582.2	105,100.0	376.5	0.5	0.2	0.8
08/23/2026 10:00	3,576.9	23.8	3,576.9	105,100.0	375.9	0.5	0.2	0.8
08/23/2026 11:00	3,572.1	29.7	3,572.1	105,100.0	375.4	0.5	0.2	0.8
08/23/2026 12:00	3,854.4	68.2	3,854.4	105,100.0	405.1	0.5	0.2	0.8
08/23/2026 13:00	4,483.9	567.1	5,022.6	105,100.0	527.9	0.6	0.3	1.1
08/23/2026 14:00	4,012.4	1,216.0	5,228.4	105,100.0	549.5	0.7	0.3	1.1
08/23/2026 15:00	4,285.5	1,219.9	5,505.4	105,100.0	578.6	0.7	0.3	1.2
08/23/2026 16:00	4,554.1	1,144.6	5,698.7	105,100.0	598.9	0.7	0.4	1.2
08/23/2026 17:00	4,556.0	1,598.3	6,154.3	105,100.0	646.8	0.8	0.4	1.3
08/23/2026 18:00	4,560.4	1,523.0	6,083.4	105,100.0	639.4	0.8	0.4	1.3
08/23/2026 19:00	4,575.7	1,206.3	5,782.0	105,100.0	607.7	0.7	0.4	1.2
08/23/2026 20:00	4,604.6	965.4	5,570.0	105,100.0	585.4	0.7	0.4	1.2
08/23/2026 21:00	4,381.1	2.4	4,381.1	105,100.0	460.5	0.6	0.3	0.9
08/23/2026 22:00	4,385.2	0.0	4,385.2	105,100.0	460.9	0.6	0.3	0.9
08/23/2026 23:00	4,373.3	0.0	4,373.3	105,100.0	459.6	0.6	0.3	0.9
Average/Sum#:	4,001.5	399.3	4,393.7	105,100.0	461.8	0.6	0.3	0.9
Minimum:	3,572.1	0.0	3,572.1	105,100.0	375.4	0.5	0.2	0.8
Maximum:	4,604.6	1,598.3	6,154.3	105,100.0	646.8	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/24/2026 00:00	4,374.8	0.0	4,374.8	105,100.0	459.8	0.6	0.3	0.9
08/24/2026 01:00	4,374.1	0.0	4,374.1	105,100.0	459.7	0.6	0.3	0.9
08/24/2026 02:00	4,366.4	0.0	4,366.4	105,100.0	458.9	0.6	0.3	0.9
08/24/2026 03:00	4,291.7	0.0	4,291.7	105,100.0	451.1	0.5	0.3	0.9
08/24/2026 04:00	4,338.7	0.0	4,338.7	105,100.0	456.0	0.5	0.3	0.9
08/24/2026 05:00	3,638.3	0.0	3,638.3	105,100.0	382.4	0.5	0.2	0.8
08/24/2026 06:00	3,943.8	0.0	3,943.8	105,100.0	414.5	0.5	0.2	0.8
08/24/2026 07:00	3,748.0	0.0	3,748.0	105,100.0	393.9	0.5	0.2	0.8
08/24/2026 08:00	3,587.6	20.1	3,587.6	105,100.0	377.1	0.5	0.2	0.8
08/24/2026 09:00	3,584.2	0.0	3,584.2	105,100.0	376.7	0.5	0.2	0.8
08/24/2026 10:00	3,579.9	19.0	3,579.9	105,100.0	376.2	0.5	0.2	0.8
08/24/2026 11:00	3,577.3	24.7	3,577.3	105,100.0	376.0	0.5	0.2	0.8
08/24/2026 12:00	3,869.2	90.6	3,871.9	105,100.0	406.9	0.5	0.2	0.8
08/24/2026 13:00	4,177.8	1,113.0	5,290.8	105,100.0	556.1	0.7	0.3	1.1
08/24/2026 14:00	4,322.5	1,541.9	5,864.4	105,100.0	616.3	0.7	0.4	1.2
08/24/2026 15:00	4,557.0	1,612.8	6,169.8	105,100.0	648.4	0.8	0.4	1.3
08/24/2026 16:00	4,564.9	1,359.8	5,924.7	105,100.0	622.7	0.7	0.4	1.2
08/24/2026 17:00	4,577.8	1,604.3	6,182.1	105,100.0	649.7	0.8	0.4	1.3
08/24/2026 18:00	4,602.6	1,615.2	6,217.8	105,100.0	653.5	0.8	0.4	1.3
08/24/2026 19:00	4,621.3	1,583.4	6,204.7	105,100.0	652.1	0.8	0.4	1.3
08/24/2026 20:00	4,619.8	885.3	5,505.1	105,100.0	578.6	0.7	0.3	1.2
08/24/2026 21:00	4,377.9	5.5	4,378.1	105,100.0	460.1	0.6	0.3	0.9
08/24/2026 22:00	4,376.7	0.0	4,376.7	105,100.0	460.0	0.6	0.3	0.9
08/24/2026 23:00	4,228.0	0.0	4,228.0	105,100.0	444.4	0.5	0.3	0.9
Average/Sum#:	4,179.2	478.2	4,650.8	105,100.0	488.8	0.6	0.3	1.0
Minimum:	3,577.3	0.0	3,577.3	105,100.0	376.0	0.5	0.2	0.8
Maximum:	4,621.3	1,615.2	6,217.8	105,100.0	653.5	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/25/2026 00:00	4,016.6	0.0	4,016.6	105,100.0	422.1	0.5	0.3	0.8
08/25/2026 01:00	3,631.9	0.0	3,631.9	105,100.0	381.7	0.5	0.2	0.8
08/25/2026 02:00	3,596.4	0.0	3,596.4	105,100.0	378.0	0.5	0.2	0.8
08/25/2026 03:00	3,601.4	0.0	3,601.4	105,100.0	378.5	0.5	0.2	0.8
08/25/2026 04:00	3,983.1	0.0	3,983.1	105,100.0	418.6	0.5	0.3	0.8
08/25/2026 05:00	3,792.3	0.0	3,792.3	105,100.0	398.6	0.5	0.2	0.8
08/25/2026 06:00	3,836.2	0.0	3,836.2	105,100.0	403.2	0.5	0.2	0.8
08/25/2026 07:00	3,599.0	0.0	3,599.0	105,100.0	378.3	0.5	0.2	0.8
08/25/2026 08:00	3,597.0	0.0	3,597.0	105,100.0	378.0	0.5	0.2	0.8
08/25/2026 09:00	3,593.4	0.0	3,593.4	105,100.0	377.7	0.5	0.2	0.8
08/25/2026 10:00	3,587.3	23.1	3,587.3	105,100.0	377.0	0.5	0.2	0.8
08/25/2026 11:00	3,967.2	4.3	3,967.2	105,100.0	417.0	0.5	0.3	0.8
08/25/2026 12:00	4,242.9	71.6	4,242.9	105,100.0	445.9	0.5	0.3	0.9
08/25/2026 13:00	4,453.8	77.5	4,456.1	105,100.0	468.3	0.6	0.3	1.0
08/25/2026 14:00	4,580.4	707.6	5,288.0	105,100.0	555.8	0.7	0.3	1.1
08/25/2026 15:00	4,582.4	520.5	5,102.9	105,100.0	536.3	0.6	0.3	1.1
08/25/2026 16:00	4,573.9	1,094.6	5,668.5	105,100.0	595.8	0.7	0.4	1.2
08/25/2026 17:00	4,580.8	1,679.6	6,260.4	105,100.0	658.0	0.8	0.4	1.3
08/25/2026 18:00	4,606.5	1,651.9	6,258.4	105,100.0	657.8	0.8	0.4	1.3
08/25/2026 19:00	4,634.6	1,309.5	5,944.1	105,100.0	624.7	0.8	0.4	1.2
08/25/2026 20:00	4,588.7	781.1	5,369.8	105,100.0	564.4	0.7	0.3	1.1
08/25/2026 21:00	4,457.0	773.1	5,230.1	105,100.0	549.7	0.7	0.3	1.1
08/25/2026 22:00	3,898.9	5.4	3,899.1	105,100.0	409.8	0.5	0.2	0.8
08/25/2026 23:00	3,593.4	0.0	3,593.4	105,100.0	377.7	0.5	0.2	0.8
Average/Sum#:	4,066.5	362.5	4,421.5	105,100.0	464.7	0.6	0.3	0.9
Minimum:	3,587.3	0.0	3,587.3	105,100.0	377.0	0.5	0.2	0.8
Maximum:	4,634.6	1,679.6	6,260.4	105,100.0	658.0	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/26/2026 00:00	3,655.8	0.0	3,655.8	105,100.0	384.2	0.5	0.2	0.8
08/26/2026 01:00	3,591.8	0.0	3,591.8	105,100.0	377.5	0.5	0.2	0.8
08/26/2026 02:00	3,843.9	0.0	3,843.9	105,100.0	404.0	0.5	0.2	0.8
08/26/2026 03:00	3,593.8	0.0	3,593.8	105,100.0	377.7	0.5	0.2	0.8
08/26/2026 04:00	4,034.4	0.0	4,034.4	105,100.0	424.0	0.5	0.3	0.8
08/26/2026 05:00	4,370.2	0.0	4,370.2	105,100.0	459.3	0.6	0.3	0.9
08/26/2026 06:00	3,932.9	0.0	3,932.9	105,100.0	413.3	0.5	0.2	0.8
08/26/2026 07:00	3,596.4	32.2	3,596.4	105,100.0	378.0	0.5	0.2	0.8
08/26/2026 08:00	3,592.5	39.6	3,592.5	105,100.0	377.6	0.5	0.2	0.8
08/26/2026 09:00	3,585.6	0.0	3,585.6	105,100.0	376.8	0.5	0.2	0.8
08/26/2026 10:00	3,583.6	34.0	3,583.6	105,100.0	376.6	0.5	0.2	0.8
08/26/2026 11:00	4,348.0	2.2	4,348.0	105,100.0	457.0	0.5	0.3	0.9
08/26/2026 12:00	4,398.3	87.5	4,400.9	105,100.0	462.5	0.6	0.3	0.9
08/26/2026 13:00	4,470.1	719.7	5,189.8	105,100.0	545.4	0.7	0.3	1.1
08/26/2026 14:00	4,046.8	1,155.3	5,202.1	105,100.0	546.7	0.7	0.3	1.1
08/26/2026 15:00	3,995.5	1,229.2	5,224.7	105,100.0	549.1	0.7	0.3	1.1
08/26/2026 16:00	3,955.0	1,277.1	5,232.1	105,100.0	549.9	0.7	0.3	1.1
08/26/2026 17:00	4,402.1	1,289.6	5,691.7	105,100.0	598.2	0.7	0.4	1.2
08/26/2026 18:00	4,485.0	847.1	5,332.1	105,100.0	560.4	0.7	0.3	1.1
08/26/2026 19:00	4,346.2	1,083.5	5,429.7	105,100.0	570.7	0.7	0.3	1.1
08/26/2026 20:00	4,495.3	883.6	5,378.9	105,100.0	565.3	0.7	0.3	1.1
08/26/2026 21:00	4,352.9	8.4	4,353.3	105,100.0	457.5	0.6	0.3	0.9
08/26/2026 22:00	3,661.0	0.0	3,661.0	105,100.0	384.8	0.5	0.2	0.8
08/26/2026 23:00	4,060.0	0.0	4,060.0	105,100.0	426.7	0.5	0.3	0.9
Average/Sum#:	4,016.5	362.0	4,370.2	105,100.0	459.3	0.6	0.3	0.9
Minimum:	3,583.6	0.0	3,583.6	105,100.0	376.6	0.5	0.2	0.8
Maximum:	4,495.3	1,289.6	5,691.7	105,100.0	598.2	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/27/2026 00:00	3,816.8	0.0	3,816.8	105,100.0	401.1	0.5	0.2	0.8
08/27/2026 01:00	3,588.6	0.0	3,588.6	105,100.0	377.2	0.5	0.2	0.8
08/27/2026 02:00	3,591.8	0.0	3,591.8	105,100.0	377.5	0.5	0.2	0.8
08/27/2026 03:00	3,593.5	0.0	3,593.5	105,100.0	377.7	0.5	0.2	0.8
08/27/2026 04:00	3,595.1	0.0	3,595.1	105,100.0	377.8	0.5	0.2	0.8
08/27/2026 05:00	3,935.9	0.0	3,935.9	105,100.0	413.7	0.5	0.2	0.8
08/27/2026 06:00	4,049.8	0.0	4,049.8	105,100.0	425.6	0.5	0.3	0.9
08/27/2026 07:00	4,399.5	56.5	4,399.5	105,100.0	462.4	0.6	0.3	0.9
08/27/2026 08:00	4,397.4	38.6	4,397.4	105,100.0	462.2	0.6	0.3	0.9
08/27/2026 09:00	4,398.6	0.0	4,398.6	105,100.0	462.3	0.6	0.3	0.9
08/27/2026 10:00	4,386.8	28.6	4,386.8	105,100.0	461.1	0.6	0.3	0.9
08/27/2026 11:00	4,389.1	39.3	4,389.1	105,100.0	461.3	0.6	0.3	0.9
08/27/2026 12:00	4,496.3	75.9	4,498.6	105,100.0	472.8	0.6	0.3	1.0
08/27/2026 13:00	4,555.6	1,304.9	5,860.5	105,100.0	615.9	0.7	0.4	1.2
08/27/2026 14:00	4,540.7	1,545.2	6,085.9	105,100.0	639.6	0.8	0.4	1.3
08/27/2026 15:00	4,527.8	670.2	5,198.0	105,100.0	546.3	0.7	0.3	1.1
08/27/2026 16:00	4,537.5	769.2	5,306.7	105,100.0	557.7	0.7	0.3	1.1
08/27/2026 17:00	4,551.7	476.6	5,028.3	105,100.0	528.5	0.6	0.3	1.1
08/27/2026 18:00	4,288.9	846.1	5,135.0	105,100.0	539.7	0.6	0.3	1.1
08/27/2026 19:00	4,278.6	883.5	5,162.1	105,100.0	542.5	0.7	0.3	1.1
08/27/2026 20:00	4,320.7	1,114.2	5,434.9	105,100.0	571.2	0.7	0.3	1.1
08/27/2026 21:00	4,368.9	11.3	4,369.5	105,100.0	459.2	0.6	0.3	0.9
08/27/2026 22:00	4,394.0	0.0	4,394.0	105,100.0	461.8	0.6	0.3	0.9
08/27/2026 23:00	4,478.0	1,099.1	5,577.1	105,100.0	586.2	0.7	0.4	1.2
Average/Sum#:	4,228.4	373.3	4,591.4	105,100.0	482.6	0.6	0.3	1.0
Minimum:	3,588.6	0.0	3,588.6	105,100.0	377.2	0.5	0.2	0.8
Maximum:	4,555.6	1,545.2	6,085.9	105,100.0	639.6	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/28/2026 00:00	4,513.5	703.7	5,217.2	105,100.0	548.3	0.7	0.3	1.1
08/28/2026 01:00	4,532.6	602.0	5,134.6	105,100.0	539.6	0.6	0.3	1.1
08/28/2026 02:00	4,557.1	457.1	5,014.2	105,100.0	527.0	0.6	0.3	1.1
08/28/2026 03:00	4,568.7	537.5	5,106.2	105,100.0	536.7	0.6	0.3	1.1
08/28/2026 04:00	4,583.4	914.7	5,498.1	105,100.0	577.9	0.7	0.3	1.2
08/28/2026 05:00	4,595.4	1,552.4	6,147.8	105,100.0	646.1	0.8	0.4	1.3
08/28/2026 06:00	4,584.7	1,387.6	5,972.3	105,100.0	627.7	0.8	0.4	1.3
08/28/2026 07:00	4,687.2	1,462.1	6,149.3	105,100.0	646.3	0.8	0.4	1.3
08/28/2026 08:00	4,696.7	611.6	5,308.3	105,100.0	557.9	0.7	0.3	1.1
08/28/2026 09:00	4,539.2	490.8	5,030.0	105,100.0	528.7	0.6	0.3	1.1
08/28/2026 10:00	4,495.4	645.7	5,141.1	105,100.0	540.3	0.6	0.3	1.1
08/28/2026 11:00	4,436.6	771.4	5,208.0	105,100.0	547.4	0.7	0.3	1.1
08/28/2026 12:00	4,426.2	751.5	5,177.7	105,100.0	544.2	0.7	0.3	1.1
08/28/2026 13:00	4,391.1	717.0	5,108.1	105,100.0	536.9	0.6	0.3	1.1
08/28/2026 14:00	4,321.8	819.9	5,141.7	105,100.0	540.4	0.6	0.3	1.1
08/28/2026 15:00	4,327.6	771.2	5,098.8	105,100.0	535.9	0.6	0.3	1.1
08/28/2026 16:00	4,393.9	680.5	5,074.4	105,100.0	533.3	0.6	0.3	1.1
08/28/2026 17:00	4,449.8	605.5	5,055.3	105,100.0	531.3	0.6	0.3	1.1
08/28/2026 18:00	4,473.9	603.5	5,077.4	105,100.0	533.6	0.6	0.3	1.1
08/28/2026 19:00	4,507.4	516.0	5,023.4	105,100.0	528.0	0.6	0.3	1.1
08/28/2026 20:00	4,533.0	466.1	4,999.1	105,100.0	525.4	0.6	0.3	1.1
08/28/2026 21:00	4,563.3	414.3	4,977.6	105,100.0	523.1	0.6	0.3	1.0
08/28/2026 22:00	4,597.9	373.6	4,971.5	105,100.0	522.5	0.6	0.3	1.0
08/28/2026 23:00	4,623.7	347.2	4,970.9	105,100.0	522.4	0.6	0.3	1.0
Average/Sum#:	4,516.7	716.8	5,233.5	105,100.0	550.0	0.6	0.3	1.1
Minimum:	4,321.8	347.2	4,970.9	105,100.0	522.4	0.6	0.3	1.0
Maximum:	4,696.7	1,552.4	6,149.3	105,100.0	646.3	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/29/2026 00:00	4,646.1	318.4	4,964.5	105,100.0	521.8	0.6	0.3	1.0
08/29/2026 01:00	4,643.6	325.2	4,968.8	105,100.0	522.2	0.6	0.3	1.0
08/29/2026 02:00	4,657.7	303.0	4,960.7	105,100.0	521.4	0.6	0.3	1.0
08/29/2026 03:00	4,670.8	279.8	4,950.6	105,100.0	520.3	0.6	0.3	1.0
08/29/2026 04:00	4,690.7	246.2	4,936.9	105,100.0	518.9	0.6	0.3	1.0
08/29/2026 05:00	4,716.1	201.5	4,917.6	105,100.0	516.8	0.6	0.3	1.0
08/29/2026 06:00	4,717.2	205.1	4,922.3	105,100.0	517.3	0.6	0.3	1.0
08/29/2026 07:00	4,688.2	263.2	4,951.4	105,100.0	520.4	0.6	0.3	1.0
08/29/2026 08:00	4,646.1	310.8	4,956.9	105,100.0	521.0	0.6	0.3	1.0
08/29/2026 09:00	4,583.3	401.1	4,984.4	105,100.0	523.9	0.6	0.3	1.0
08/29/2026 10:00	4,528.2	474.4	5,002.6	105,100.0	525.8	0.6	0.3	1.1
08/29/2026 11:00	4,464.4	572.8	5,037.2	105,100.0	529.4	0.6	0.3	1.1
08/29/2026 12:00	4,373.0	711.4	5,084.4	105,100.0	534.4	0.6	0.3	1.1
08/29/2026 13:00	4,291.6	826.9	5,118.5	105,100.0	538.0	0.6	0.3	1.1
08/29/2026 14:00	4,223.1	937.4	5,160.5	105,100.0	542.4	0.7	0.3	1.1
08/29/2026 15:00	4,450.7	600.1	5,050.8	105,100.0	530.8	0.6	0.3	1.1
08/29/2026 16:00	4,601.0	382.1	4,983.1	105,100.0	523.7	0.6	0.3	1.0
08/29/2026 17:00	4,619.3	601.3	5,220.6	105,100.0	548.7	0.7	0.3	1.1
08/29/2026 18:00	4,492.9	513.3	5,006.2	105,100.0	526.2	0.6	0.3	1.1
08/29/2026 19:00	4,477.9	522.7	5,000.6	105,100.0	525.6	0.6	0.3	1.1
08/29/2026 20:00	4,526.5	481.1	5,007.6	105,100.0	526.3	0.6	0.3	1.1
08/29/2026 21:00	4,571.9	424.9	4,996.8	105,100.0	525.2	0.6	0.3	1.1
08/29/2026 22:00	4,600.7	380.5	4,981.2	105,100.0	523.5	0.6	0.3	1.0
08/29/2026 23:00	4,629.3	338.6	4,967.9	105,100.0	522.1	0.6	0.3	1.0
Average/Sum#:	4,562.9	442.6	5,005.5	105,100.0	526.1	0.6	0.3	1.0
Minimum:	4,223.1	201.5	4,917.6	105,100.0	516.8	0.6	0.3	1.0
Maximum:	4,717.2	937.4	5,220.6	105,100.0	548.7	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/30/2026 00:00	4,657.7	291.7	4,949.4	105,100.0	520.2	0.6	0.3	1.0
08/30/2026 01:00	4,678.6	257.8	4,936.4	105,100.0	518.8	0.6	0.3	1.0
08/30/2026 02:00	4,691.0	245.2	4,936.2	105,100.0	518.8	0.6	0.3	1.0
08/30/2026 03:00	4,708.3	225.3	4,933.6	105,100.0	518.5	0.6	0.3	1.0
08/30/2026 04:00	4,723.7	206.0	4,929.7	105,100.0	518.1	0.6	0.3	1.0
08/30/2026 05:00	4,737.3	181.6	4,918.9	105,100.0	517.0	0.6	0.3	1.0
08/30/2026 06:00	4,726.4	185.6	4,912.0	105,100.0	516.3	0.6	0.3	1.0
08/30/2026 07:00	4,695.6	255.2	4,950.8	105,100.0	520.3	0.6	0.3	1.0
08/30/2026 08:00	4,658.3	312.0	4,970.3	105,100.0	522.4	0.6	0.3	1.0
08/30/2026 09:00	4,595.6	394.6	4,990.2	105,100.0	524.5	0.6	0.3	1.0
08/30/2026 10:00	4,527.6	500.4	5,028.0	105,100.0	528.4	0.6	0.3	1.1
08/30/2026 11:00	4,461.2	589.5	5,050.7	105,100.0	530.8	0.6	0.3	1.1
08/30/2026 12:00	4,382.8	696.8	5,079.6	105,100.0	533.9	0.6	0.3	1.1
08/30/2026 13:00	4,295.2	798.6	5,093.8	105,100.0	535.4	0.6	0.3	1.1
08/30/2026 14:00	4,258.8	831.2	5,090.0	105,100.0	535.0	0.6	0.3	1.1
08/30/2026 15:00	4,218.7	891.9	5,110.6	105,100.0	537.1	0.6	0.3	1.1
08/30/2026 16:00	4,209.5	986.5	5,196.0	105,100.0	546.1	0.7	0.3	1.1
08/30/2026 17:00	4,229.4	1,191.0	5,420.4	105,100.0	569.7	0.7	0.3	1.1
08/30/2026 18:00	4,326.6	744.0	5,070.6	105,100.0	532.9	0.6	0.3	1.1
08/30/2026 19:00	4,475.7	534.0	5,009.7	105,100.0	526.5	0.6	0.3	1.1
08/30/2026 20:00	4,525.7	476.4	5,002.1	105,100.0	525.7	0.6	0.3	1.1
08/30/2026 21:00	4,560.2	449.6	5,009.8	105,100.0	526.5	0.6	0.3	1.1
08/30/2026 22:00	4,596.4	396.3	4,992.7	105,100.0	524.7	0.6	0.3	1.1
08/30/2026 23:00	4,617.8	346.2	4,964.0	105,100.0	521.7	0.6	0.3	1.0
Average/Sum#:	4,523.3	499.5	5,022.7	105,100.0	527.9	0.6	0.3	1.1
Minimum:	4,209.5	181.6	4,912.0	105,100.0	516.3	0.6	0.3	1.0
Maximum:	4,737.3	1,191.0	5,420.4	105,100.0	569.7	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/31/2026 00:00	4,647.2	302.6	4,949.8	105,100.0	520.2	0.6	0.3	1.0
08/31/2026 01:00	4,670.1	266.6	4,936.7	105,100.0	518.8	0.6	0.3	1.0
08/31/2026 02:00	4,687.1	248.2	4,935.3	105,100.0	518.7	0.6	0.3	1.0
08/31/2026 03:00	4,703.8	227.7	4,931.5	105,100.0	518.3	0.6	0.3	1.0
08/31/2026 04:00	4,729.3	199.8	4,929.1	105,100.0	518.0	0.6	0.3	1.0
08/31/2026 05:00	4,367.8	70.5	4,398.1	105,100.0	462.2	0.6	0.3	0.9
08/31/2026 06:00	3,605.9	0.0	3,605.9	105,100.0	379.0	0.5	0.2	0.8
08/31/2026 07:00	3,606.5	0.0	3,606.5	105,100.0	379.0	0.5	0.2	0.8
08/31/2026 08:00	3,600.3	0.0	3,600.3	105,100.0	378.4	0.5	0.2	0.8
08/31/2026 09:00	3,600.0	0.0	3,600.0	105,100.0	378.4	0.5	0.2	0.8
08/31/2026 10:00	3,598.2	0.0	3,598.2	105,100.0	378.2	0.5	0.2	0.8
08/31/2026 11:00	3,597.6	0.0	3,597.6	105,100.0	378.1	0.5	0.2	0.8
08/31/2026 12:00	3,873.2	7.1	3,873.4	105,100.0	407.1	0.5	0.2	0.8
08/31/2026 13:00	4,527.8	513.9	5,041.7	105,100.0	529.9	0.6	0.3	1.1
08/31/2026 14:00	4,519.0	492.7	5,011.7	105,100.0	526.7	0.6	0.3	1.1
08/31/2026 15:00	4,515.0	493.9	5,008.9	105,100.0	526.4	0.6	0.3	1.1
08/31/2026 16:00	4,525.6	481.3	5,006.9	105,100.0	526.2	0.6	0.3	1.1
08/31/2026 17:00	4,572.0	409.2	4,981.2	105,100.0	523.5	0.6	0.3	1.0
08/31/2026 18:00	4,642.0	311.0	4,953.0	105,100.0	520.6	0.6	0.3	1.0
08/31/2026 19:00	4,686.6	276.7	4,963.3	105,100.0	521.6	0.6	0.3	1.0
08/31/2026 20:00	4,707.6	241.9	4,949.5	105,100.0	520.2	0.6	0.3	1.0
08/31/2026 21:00	4,031.0	69.6	4,053.3	105,100.0	426.0	0.5	0.3	0.9
08/31/2026 22:00	3,602.9	0.0	3,602.9	105,100.0	378.7	0.5	0.2	0.8
08/31/2026 23:00	3,857.8	0.0	3,857.8	105,100.0	405.5	0.5	0.2	0.8
Average/Sum#:	4,228.1	192.2	4,416.4	105,100.0	464.2	0.6	0.3	0.9
Minimum:	3,597.6	0.0	3,597.6	105,100.0	378.1	0.5	0.2	0.8
Maximum:	4,729.3	513.9	5,041.7	105,100.0	529.9	0.6	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/01/2026 00:00	3,849.9	0.0	3,849.9	105,100.0	404.6	0.5	0.2	0.8
09/01/2026 01:00	3,603.0	0.0	3,603.0	105,100.0	378.7	0.5	0.2	0.8
09/01/2026 02:00	3,601.9	0.0	3,601.9	105,100.0	378.6	0.5	0.2	0.8
09/01/2026 03:00	3,599.7	0.0	3,599.7	105,100.0	378.3	0.5	0.2	0.8
09/01/2026 04:00	3,601.1	0.0	3,601.1	105,100.0	378.5	0.5	0.2	0.8
09/01/2026 05:00	3,603.1	0.0	3,603.1	105,100.0	378.7	0.5	0.2	0.8
09/01/2026 06:00	3,599.4	0.0	3,599.4	105,100.0	378.3	0.5	0.2	0.8
09/01/2026 07:00	3,598.6	0.0	3,598.6	105,100.0	378.2	0.5	0.2	0.8
09/01/2026 08:00	3,597.3	0.0	3,597.3	105,100.0	378.1	0.5	0.2	0.8
09/01/2026 09:00	3,591.3	0.0	3,591.3	105,100.0	377.4	0.5	0.2	0.8
09/01/2026 10:00	3,589.8	0.0	3,589.8	105,100.0	377.3	0.5	0.2	0.8
09/01/2026 11:00	3,583.0	0.0	3,583.0	105,100.0	376.6	0.5	0.2	0.8
09/01/2026 12:00	3,579.9	13.6	3,579.9	105,100.0	376.2	0.5	0.2	0.8
09/01/2026 13:00	3,576.0	37.2	3,576.0	105,100.0	375.8	0.5	0.2	0.8
09/01/2026 14:00	3,573.3	0.0	3,573.3	105,100.0	375.6	0.5	0.2	0.8
09/01/2026 15:00	3,570.0	0.0	3,570.0	105,100.0	375.2	0.5	0.2	0.8
09/01/2026 16:00	3,570.2	0.0	3,570.2	105,100.0	375.2	0.5	0.2	0.8
09/01/2026 17:00	3,724.9	0.0	3,724.9	105,100.0	391.5	0.5	0.2	0.8
09/01/2026 18:00	3,579.1	0.0	3,579.1	105,100.0	376.2	0.5	0.2	0.8
09/01/2026 19:00	3,581.8	0.0	3,581.8	105,100.0	376.4	0.5	0.2	0.8
09/01/2026 20:00	3,589.8	0.0	3,589.8	105,100.0	377.3	0.5	0.2	0.8
09/01/2026 21:00	3,593.7	0.0	3,593.7	105,100.0	377.7	0.5	0.2	0.8
09/01/2026 22:00	3,599.0	0.0	3,599.0	105,100.0	378.3	0.5	0.2	0.8
09/01/2026 23:00	3,604.2	0.0	3,604.2	105,100.0	378.8	0.5	0.2	0.8
Average/Sum#:	3,606.7	2.1	3,606.7	105,100.0	379.1	0.5	0.2	0.8
Minimum:	3,570.0	0.0	3,570.0	105,100.0	375.2	0.5	0.2	0.8
Maximum:	3,849.9	37.2	3,849.9	105,100.0	404.6	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/02/2026 00:00	3,608.4	0.0	3,608.4	105,100.0	379.2	0.5	0.2	0.8
09/02/2026 01:00	3,608.3	0.0	3,608.3	105,100.0	379.2	0.5	0.2	0.8
09/02/2026 02:00	3,608.7	0.0	3,608.7	105,100.0	379.3	0.5	0.2	0.8
09/02/2026 03:00	3,608.1	0.0	3,608.1	105,100.0	379.2	0.5	0.2	0.8
09/02/2026 04:00	3,609.5	0.0	3,609.5	105,100.0	379.4	0.5	0.2	0.8
09/02/2026 05:00	3,608.6	0.0	3,608.6	105,100.0	379.3	0.5	0.2	0.8
09/02/2026 06:00	3,607.5	0.0	3,607.5	105,100.0	379.1	0.5	0.2	0.8
09/02/2026 07:00	3,605.5	0.0	3,605.5	105,100.0	378.9	0.5	0.2	0.8
09/02/2026 08:00	3,603.8	0.0	3,603.8	105,100.0	378.8	0.5	0.2	0.8
09/02/2026 09:00	3,601.5	0.0	3,601.5	105,100.0	378.5	0.5	0.2	0.8
09/02/2026 10:00	3,594.5	0.0	3,594.5	105,100.0	377.8	0.5	0.2	0.8
09/02/2026 11:00	3,585.2	0.0	3,585.2	105,100.0	376.8	0.5	0.2	0.8
09/02/2026 12:00	3,575.1	0.0	3,575.1	105,100.0	375.7	0.5	0.2	0.8
09/02/2026 13:00	3,571.1	0.0	3,571.1	105,100.0	375.3	0.5	0.2	0.8
09/02/2026 14:00	3,570.2	0.0	3,570.2	105,100.0	375.2	0.5	0.2	0.8
09/02/2026 15:00	3,569.0	0.0	3,569.0	105,100.0	375.1	0.5	0.2	0.8
09/02/2026 16:00	3,606.9	0.0	3,606.9	105,100.0	379.1	0.5	0.2	0.8
09/02/2026 17:00	3,848.4	0.0	3,848.4	105,100.0	404.5	0.5	0.2	0.8
09/02/2026 18:00	3,573.9	0.0	3,573.9	105,100.0	375.6	0.5	0.2	0.8
09/02/2026 19:00	3,567.3	0.0	3,567.3	105,100.0	374.9	0.5	0.2	0.8
09/02/2026 20:00	3,571.6	0.0	3,571.6	105,100.0	375.4	0.5	0.2	0.8
09/02/2026 21:00	3,575.2	0.0	3,575.2	105,100.0	375.8	0.5	0.2	0.8
09/02/2026 22:00	3,576.3	0.0	3,576.3	105,100.0	375.9	0.5	0.2	0.8
09/02/2026 23:00	3,580.0	0.0	3,580.0	105,100.0	376.3	0.5	0.2	0.8
Average/Sum#:	3,601.4	0.0	3,601.4	105,100.0	378.5	0.5	0.2	0.8
Minimum:	3,567.3	0.0	3,567.3	105,100.0	374.9	0.5	0.2	0.8
Maximum:	3,848.4	0.0	3,848.4	105,100.0	404.5	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/03/2026 00:00	3,583.6	0.0	3,583.6	105,100.0	376.6	0.5	0.2	0.8
09/03/2026 01:00	3,585.6	0.0	3,585.6	105,100.0	376.8	0.5	0.2	0.8
09/03/2026 02:00	3,588.1	0.0	3,588.1	105,100.0	377.1	0.5	0.2	0.8
09/03/2026 03:00	3,588.4	0.0	3,588.4	105,100.0	377.1	0.5	0.2	0.8
09/03/2026 04:00	3,587.3	0.0	3,587.3	105,100.0	377.0	0.5	0.2	0.8
09/03/2026 05:00	3,594.1	0.0	3,594.1	105,100.0	377.7	0.5	0.2	0.8
09/03/2026 06:00	3,635.3	0.0	3,635.3	105,100.0	382.1	0.5	0.2	0.8
09/03/2026 07:00	3,839.6	0.0	3,839.6	105,100.0	403.5	0.5	0.2	0.8
09/03/2026 08:00	3,798.3	0.0	3,798.3	105,100.0	399.2	0.5	0.2	0.8
09/03/2026 09:00	4,009.6	0.0	4,009.6	105,100.0	421.4	0.5	0.3	0.8
09/03/2026 10:00	3,877.3	0.0	3,877.3	105,100.0	407.5	0.5	0.2	0.8
09/03/2026 11:00	3,577.1	0.0	3,577.1	105,100.0	376.0	0.5	0.2	0.8
09/03/2026 12:00	3,870.9	0.0	3,870.9	105,100.0	406.8	0.5	0.2	0.8
09/03/2026 13:00	4,328.9	0.0	4,328.9	105,100.0	455.0	0.5	0.3	0.9
09/03/2026 14:00	4,337.8	0.0	4,337.8	105,100.0	455.9	0.5	0.3	0.9
09/03/2026 15:00	4,332.3	0.0	4,332.3	105,100.0	455.3	0.5	0.3	0.9
09/03/2026 16:00	3,759.7	0.0	3,759.7	105,100.0	395.1	0.5	0.2	0.8
09/03/2026 17:00	4,035.8	0.0	4,035.8	105,100.0	424.2	0.5	0.3	0.8
09/03/2026 18:00	3,612.5	0.0	3,612.5	105,100.0	379.7	0.5	0.2	0.8
09/03/2026 19:00	3,919.8	0.0	3,919.8	105,100.0	412.0	0.5	0.2	0.8
09/03/2026 20:00	4,350.6	0.0	4,350.6	105,100.0	457.2	0.5	0.3	0.9
09/03/2026 21:00	4,381.7	0.0	4,381.7	105,100.0	460.5	0.6	0.3	0.9
09/03/2026 22:00	4,388.4	0.0	4,388.4	105,100.0	461.2	0.6	0.3	0.9
09/03/2026 23:00	4,343.9	0.0	4,343.9	105,100.0	456.5	0.5	0.3	0.9
Average/Sum#:	3,913.6	0.0	3,913.6	105,100.0	411.3	0.5	0.2	0.8
Minimum:	3,577.1	0.0	3,577.1	105,100.0	376.0	0.5	0.2	0.8
Maximum:	4,388.4	0.0	4,388.4	105,100.0	461.2	0.6	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/04/2026 00:00	3,765.2	0.0	3,765.2	105,100.0	395.7	0.5	0.2	0.8
09/04/2026 01:00	3,592.5	0.0	3,592.5	105,100.0	377.6	0.5	0.2	0.8
09/04/2026 02:00	3,592.2	0.0	3,592.2	105,100.0	377.5	0.5	0.2	0.8
09/04/2026 03:00	3,592.0	0.0	3,592.0	105,100.0	377.5	0.5	0.2	0.8
09/04/2026 04:00	3,709.6	0.0	3,709.6	105,100.0	389.9	0.5	0.2	0.8
09/04/2026 05:00	4,298.2	0.0	4,298.2	105,100.0	451.7	0.5	0.3	0.9
09/04/2026 06:00	3,793.4	0.0	3,793.4	105,100.0	398.7	0.5	0.2	0.8
09/04/2026 07:00	3,852.2	0.0	3,852.2	105,100.0	404.9	0.5	0.2	0.8
09/04/2026 08:00	3,589.8	0.0	3,589.8	105,100.0	377.3	0.5	0.2	0.8
09/04/2026 09:00	3,586.9	0.0	3,586.9	105,100.0	377.0	0.5	0.2	0.8
09/04/2026 10:00	3,905.4	0.0	3,905.4	105,100.0	410.5	0.5	0.2	0.8
09/04/2026 11:00	3,578.4	0.0	3,578.4	105,100.0	376.1	0.5	0.2	0.8
09/04/2026 12:00	3,576.9	5.0	3,576.9	105,100.0	375.9	0.5	0.2	0.8
09/04/2026 13:00	3,578.2	17.5	3,578.2	105,100.0	376.1	0.5	0.2	0.8
09/04/2026 14:00	3,573.7	0.0	3,573.7	105,100.0	375.6	0.5	0.2	0.8
09/04/2026 15:00	3,571.3	0.0	3,571.3	105,100.0	375.3	0.5	0.2	0.8
09/04/2026 16:00	3,725.8	0.0	3,725.8	105,100.0	391.6	0.5	0.2	0.8
09/04/2026 17:00	3,886.1	0.0	3,886.1	105,100.0	408.4	0.5	0.2	0.8
09/04/2026 18:00	4,365.9	0.0	4,365.9	105,100.0	458.9	0.6	0.3	0.9
09/04/2026 19:00	4,354.3	0.0	4,354.3	105,100.0	457.6	0.6	0.3	0.9
09/04/2026 20:00	4,357.1	0.0	4,357.1	105,100.0	457.9	0.6	0.3	0.9
09/04/2026 21:00	4,369.1	0.0	4,369.1	105,100.0	459.2	0.6	0.3	0.9
09/04/2026 22:00	4,354.7	0.0	4,354.7	105,100.0	457.7	0.5	0.3	0.9
09/04/2026 23:00	3,667.6	0.0	3,667.6	105,100.0	385.5	0.5	0.2	0.8
Average/Sum#:	3,843.2	0.9	3,843.2	105,100.0	403.9	0.5	0.2	0.8
Minimum:	3,571.3	0.0	3,571.3	105,100.0	375.3	0.5	0.2	0.8
Maximum:	4,369.1	17.5	4,369.1	105,100.0	459.2	0.6	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/05/2026 00:00	3,781.9	0.0	3,781.9	105,100.0	397.5	0.5	0.2	0.8
09/05/2026 01:00	3,758.4	0.0	3,758.4	105,100.0	395.0	0.5	0.2	0.8
09/05/2026 02:00	3,865.0	0.0	3,865.0	105,100.0	406.2	0.5	0.2	0.8
09/05/2026 03:00	3,603.4	0.0	3,603.4	105,100.0	378.7	0.5	0.2	0.8
09/05/2026 04:00	4,127.2	0.0	4,127.2	105,100.0	433.8	0.5	0.3	0.9
09/05/2026 05:00	4,354.0	0.0	4,354.0	105,100.0	457.6	0.6	0.3	0.9
09/05/2026 06:00	3,592.2	0.0	3,592.2	105,100.0	377.5	0.5	0.2	0.8
09/05/2026 07:00	3,591.3	0.0	3,591.3	105,100.0	377.4	0.5	0.2	0.8
09/05/2026 08:00	3,586.2	0.0	3,586.2	105,100.0	376.9	0.5	0.2	0.8
09/05/2026 09:00	3,584.7	0.0	3,584.7	105,100.0	376.8	0.5	0.2	0.8
09/05/2026 10:00	3,579.6	0.0	3,579.6	105,100.0	376.2	0.5	0.2	0.8
09/05/2026 11:00	3,572.6	0.0	3,572.6	105,100.0	375.5	0.5	0.2	0.8
09/05/2026 12:00	3,570.3	12.0	3,570.3	105,100.0	375.2	0.5	0.2	0.8
09/05/2026 13:00	3,571.0	27.5	3,571.0	105,100.0	375.3	0.5	0.2	0.8
09/05/2026 14:00	3,574.0	0.0	3,574.0	105,100.0	375.6	0.5	0.2	0.8
09/05/2026 15:00	3,573.6	0.0	3,573.6	105,100.0	375.6	0.5	0.2	0.8
09/05/2026 16:00	3,570.6	0.0	3,570.6	105,100.0	375.3	0.5	0.2	0.8
09/05/2026 17:00	3,877.8	0.0	3,877.8	105,100.0	407.6	0.5	0.2	0.8
09/05/2026 18:00	3,673.0	0.0	3,673.0	105,100.0	386.0	0.5	0.2	0.8
09/05/2026 19:00	3,730.6	0.0	3,730.6	105,100.0	392.1	0.5	0.2	0.8
09/05/2026 20:00	3,594.5	0.0	3,594.5	105,100.0	377.8	0.5	0.2	0.8
09/05/2026 21:00	3,733.4	0.0	3,733.4	105,100.0	392.4	0.5	0.2	0.8
09/05/2026 22:00	3,760.6	0.0	3,760.6	105,100.0	395.2	0.5	0.2	0.8
09/05/2026 23:00	3,702.2	0.0	3,702.2	105,100.0	389.1	0.5	0.2	0.8
Average/Sum#:	3,705.3	1.6	3,705.3	105,100.0	389.4	0.5	0.2	0.8
Minimum:	3,570.3	0.0	3,570.3	105,100.0	375.2	0.5	0.2	0.8
Maximum:	4,354.0	27.5	4,354.0	105,100.0	457.6	0.6	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/06/2026 00:00	3,589.7	0.0	3,589.7	105,100.0	377.3	0.5	0.2	0.8
09/06/2026 01:00	3,623.7	0.0	3,623.7	105,100.0	380.9	0.5	0.2	0.8
09/06/2026 02:00	3,740.0	0.0	3,740.0	105,100.0	393.1	0.5	0.2	0.8
09/06/2026 03:00	3,587.0	0.0	3,587.0	105,100.0	377.0	0.5	0.2	0.8
09/06/2026 04:00	3,627.5	0.0	3,627.5	105,100.0	381.3	0.5	0.2	0.8
09/06/2026 05:00	3,597.0	0.0	3,597.0	105,100.0	378.0	0.5	0.2	0.8
09/06/2026 06:00	3,921.0	0.0	3,921.0	105,100.0	412.1	0.5	0.2	0.8
09/06/2026 07:00	3,587.4	0.0	3,587.4	105,100.0	377.0	0.5	0.2	0.8
09/06/2026 08:00	3,583.9	0.0	3,583.9	105,100.0	376.7	0.5	0.2	0.8
09/06/2026 09:00	3,580.4	0.0	3,580.4	105,100.0	376.3	0.5	0.2	0.8
09/06/2026 10:00	3,577.8	0.0	3,577.8	105,100.0	376.0	0.5	0.2	0.8
09/06/2026 11:00	3,569.5	0.0	3,569.5	105,100.0	375.2	0.5	0.2	0.8
09/06/2026 12:00	3,561.6	4.1	3,561.6	105,100.0	374.3	0.5	0.2	0.8
09/06/2026 13:00	3,563.6	20.8	3,563.6	105,100.0	374.5	0.5	0.2	0.8
09/06/2026 14:00	3,573.3	0.0	3,573.3	105,100.0	375.6	0.5	0.2	0.8
09/06/2026 15:00	3,915.1	0.0	3,915.1	105,100.0	411.5	0.5	0.2	0.8
09/06/2026 16:00	3,780.2	0.0	3,780.2	105,100.0	397.3	0.5	0.2	0.8
09/06/2026 17:00	3,563.2	0.0	3,563.2	105,100.0	374.5	0.5	0.2	0.8
09/06/2026 18:00	3,570.0	0.0	3,570.0	105,100.0	375.2	0.5	0.2	0.8
09/06/2026 19:00	3,573.6	0.0	3,573.6	105,100.0	375.6	0.5	0.2	0.8
09/06/2026 20:00	3,576.9	0.0	3,576.9	105,100.0	375.9	0.5	0.2	0.8
09/06/2026 21:00	3,582.0	0.0	3,582.0	105,100.0	376.5	0.5	0.2	0.8
09/06/2026 22:00	3,587.6	0.0	3,587.6	105,100.0	377.1	0.5	0.2	0.8
09/06/2026 23:00	3,853.9	0.0	3,853.9	105,100.0	405.0	0.5	0.2	0.8
Average/Sum#:	3,636.9	1.0	3,636.9	105,100.0	382.2	0.5	0.2	0.8
Minimum:	3,561.6	0.0	3,561.6	105,100.0	374.3	0.5	0.2	0.8
Maximum:	3,921.0	20.8	3,921.0	105,100.0	412.1	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/07/2026 00:00	3,584.7	0.0	3,584.7	105,100.0	376.8	0.5	0.2	0.8
09/07/2026 01:00	3,591.7	0.0	3,591.7	105,100.0	377.5	0.5	0.2	0.8
09/07/2026 02:00	3,592.5	0.0	3,592.5	105,100.0	377.6	0.5	0.2	0.8
09/07/2026 03:00	3,592.8	0.0	3,592.8	105,100.0	377.6	0.5	0.2	0.8
09/07/2026 04:00	3,593.9	0.0	3,593.9	105,100.0	377.7	0.5	0.2	0.8
09/07/2026 05:00	3,601.8	0.0	3,601.8	104,800.0	377.5	0.5	0.2	0.8
09/07/2026 06:00	3,795.1	0.0	3,795.1	104,800.0	397.7	0.5	0.2	0.8
09/07/2026 07:00	3,595.7	0.0	3,595.7	104,800.0	376.8	0.5	0.2	0.8
09/07/2026 08:00	3,590.2	0.0	3,590.2	104,800.0	376.3	0.5	0.2	0.8
09/07/2026 09:00	3,582.1	0.0	3,582.1	104,800.0	375.4	0.5	0.2	0.8
09/07/2026 10:00	3,577.4	0.0	3,577.4	104,800.0	374.9	0.5	0.2	0.8
09/07/2026 11:00	3,571.7	0.0	3,571.7	104,800.0	374.3	0.5	0.2	0.8
09/07/2026 12:00	3,566.9	1.9	3,566.9	104,800.0	373.8	0.5	0.2	0.8
09/07/2026 13:00	3,564.6	9.4	3,564.6	104,800.0	373.6	0.5	0.2	0.8
09/07/2026 14:00	3,580.6	0.0	3,580.6	104,800.0	375.2	0.5	0.2	0.8
09/07/2026 15:00	3,553.6	0.0	3,553.6	104,800.0	372.4	0.4	0.2	0.7
09/07/2026 16:00	3,907.0	0.0	3,907.0	104,800.0	409.5	0.5	0.2	0.8
09/07/2026 17:00	3,830.7	0.0	3,830.7	104,800.0	401.5	0.5	0.2	0.8
09/07/2026 18:00	3,821.0	0.0	3,821.0	104,800.0	400.4	0.5	0.2	0.8
09/07/2026 19:00	4,306.8	0.0	4,306.8	104,800.0	451.4	0.5	0.3	0.9
09/07/2026 20:00	4,327.8	0.0	4,327.8	104,800.0	453.6	0.5	0.3	0.9
09/07/2026 21:00	4,323.5	0.0	4,323.5	104,800.0	453.1	0.5	0.3	0.9
09/07/2026 22:00	4,318.0	0.0	4,318.0	104,800.0	452.5	0.5	0.3	0.9
09/07/2026 23:00	4,327.6	0.0	4,327.6	104,800.0	453.5	0.5	0.3	0.9
Average/Sum#:	3,779.1	0.5	3,779.1	104,862.5	396.3	0.5	0.2	0.8
Minimum:	3,553.6	0.0	3,553.6	104,800.0	372.4	0.4	0.2	0.7
Maximum:	4,327.8	9.4	4,327.8	105,100.0	453.6	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/08/2026 00:00	4,324.5	0.0	4,324.5	104,800.0	453.2	0.5	0.3	0.9
09/08/2026 01:00	3,980.8	0.0	3,980.8	104,800.0	417.2	0.5	0.3	0.8
09/08/2026 02:00	3,553.2	0.0	3,553.2	104,800.0	372.4	0.4	0.2	0.7
09/08/2026 03:00	3,683.4	0.0	3,683.4	104,800.0	386.0	0.5	0.2	0.8
09/08/2026 04:00	4,221.2	0.0	4,221.2	104,800.0	442.4	0.5	0.3	0.9
09/08/2026 05:00	4,327.3	0.0	4,327.3	104,800.0	453.5	0.5	0.3	0.9
09/08/2026 06:00	3,835.9	0.0	3,835.9	104,800.0	402.0	0.5	0.2	0.8
09/08/2026 07:00	3,557.3	0.0	3,557.3	104,800.0	372.8	0.5	0.2	0.7
09/08/2026 08:00	3,554.0	0.0	3,554.0	104,800.0	372.5	0.4	0.2	0.7
09/08/2026 09:00	3,553.1	0.0	3,553.1	104,800.0	372.4	0.4	0.2	0.7
09/08/2026 10:00	3,544.2	0.0	3,544.2	104,800.0	371.4	0.4	0.2	0.7
09/08/2026 11:00	3,537.6	0.0	3,537.6	104,800.0	370.7	0.4	0.2	0.7
09/08/2026 12:00	3,642.6	12.3	3,642.6	104,800.0	381.7	0.5	0.2	0.8
09/08/2026 13:00	4,336.8	31.6	4,337.7	104,800.0	454.6	0.5	0.3	0.9
09/08/2026 14:00	4,498.1	1,264.9	5,763.0	104,800.0	604.0	0.7	0.4	1.2
09/08/2026 15:00	4,495.1	1,550.2	6,045.3	104,800.0	633.5	0.8	0.4	1.3
09/08/2026 16:00	4,495.7	1,615.4	6,111.1	104,800.0	640.4	0.8	0.4	1.3
09/08/2026 17:00	4,511.0	1,701.3	6,212.3	104,800.0	651.0	0.8	0.4	1.3
09/08/2026 18:00	4,536.7	1,659.2	6,195.9	104,800.0	649.3	0.8	0.4	1.3
09/08/2026 19:00	4,539.4	1,638.1	6,177.5	104,800.0	647.4	0.8	0.4	1.3
09/08/2026 20:00	4,559.4	1,488.3	6,047.7	104,800.0	633.8	0.8	0.4	1.3
09/08/2026 21:00	4,436.6	1,578.5	6,015.1	104,800.0	630.4	0.8	0.4	1.3
09/08/2026 22:00	4,471.2	1,070.7	5,541.9	104,800.0	580.8	0.7	0.3	1.2
09/08/2026 23:00	4,248.4	0.1	4,248.4	104,800.0	445.2	0.5	0.3	0.9
Average/Sum#:	4,101.8	567.1	4,667.1	104,800.0	489.1	0.6	0.3	1.0
Minimum:	3,537.6	0.0	3,537.6	104,800.0	370.7	0.4	0.2	0.7
Maximum:	4,559.4	1,701.3	6,212.3	104,800.0	651.0	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/09/2026 00:00	4,077.2	0.0	4,077.2	104,800.0	427.3	0.5	0.3	0.9
09/09/2026 01:00	3,760.8	0.0	3,760.8	104,800.0	394.1	0.5	0.2	0.8
09/09/2026 02:00	3,566.0	0.0	3,566.0	104,800.0	373.7	0.5	0.2	0.7
09/09/2026 03:00	3,570.3	0.0	3,570.3	104,800.0	374.2	0.5	0.2	0.8
09/09/2026 04:00	3,719.8	0.0	3,719.8	104,800.0	389.8	0.5	0.2	0.8
09/09/2026 05:00	4,617.6	213.9	4,814.4	104,800.0	504.5	0.6	0.3	1.0
09/09/2026 06:00	4,650.3	420.0	5,070.3	104,800.0	531.4	0.6	0.3	1.1
09/09/2026 07:00	4,603.1	949.6	5,552.7	104,800.0	581.9	0.7	0.3	1.2
09/09/2026 08:00	4,536.8	1,475.2	6,012.0	104,800.0	630.1	0.8	0.4	1.3
09/09/2026 09:00	4,434.1	1,639.0	6,073.1	104,800.0	636.5	0.8	0.4	1.3
09/09/2026 10:00	4,254.0	1,724.2	5,978.2	104,800.0	626.5	0.8	0.4	1.3
09/09/2026 11:00	4,460.7	1,522.4	5,983.1	104,800.0	627.0	0.8	0.4	1.3
09/09/2026 12:00	4,497.6	1,408.7	5,906.3	104,800.0	619.0	0.7	0.4	1.2
09/09/2026 13:00	4,490.2	1,603.6	6,093.8	104,800.0	638.6	0.8	0.4	1.3
09/09/2026 14:00	4,468.8	1,643.4	6,112.2	104,800.0	640.6	0.8	0.4	1.3
09/09/2026 15:00	4,462.0	1,797.0	6,259.0	104,800.0	655.9	0.8	0.4	1.3
09/09/2026 16:00	4,458.3	1,786.3	6,244.6	104,800.0	654.4	0.8	0.4	1.3
09/09/2026 17:00	4,453.6	1,623.1	6,076.7	104,800.0	636.8	0.8	0.4	1.3
09/09/2026 18:00	4,458.4	1,764.6	6,223.0	104,800.0	652.2	0.8	0.4	1.3
09/09/2026 19:00	4,496.4	1,417.9	5,914.3	104,800.0	619.8	0.7	0.4	1.2
09/09/2026 20:00	4,520.4	1,698.6	6,219.0	104,800.0	651.8	0.8	0.4	1.3
09/09/2026 21:00	4,532.5	1,686.3	6,218.8	104,800.0	651.7	0.8	0.4	1.3
09/09/2026 22:00	4,562.7	1,395.6	5,958.3	104,800.0	624.4	0.7	0.4	1.2
09/09/2026 23:00	4,358.4	1.4	4,358.4	104,800.0	456.8	0.5	0.3	0.9
Average/Sum#:	4,333.8	1,073.8	5,406.8	104,800.0	566.6	0.7	0.3	1.1
Minimum:	3,566.0	0.0	3,566.0	104,800.0	373.7	0.5	0.2	0.7
Maximum:	4,650.3	1,797.0	6,259.0	104,800.0	655.9	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/10/2026 00:00	4,355.8	0.0	4,355.8	104,800.0	456.5	0.5	0.3	0.9
09/10/2026 01:00	4,333.3	0.0	4,333.3	104,800.0	454.1	0.5	0.3	0.9
09/10/2026 02:00	4,246.0	0.0	4,246.0	104,800.0	445.0	0.5	0.3	0.9
09/10/2026 03:00	3,569.2	0.0	3,569.2	104,800.0	374.1	0.4	0.2	0.7
09/10/2026 04:00	3,642.5	0.0	3,642.5	104,800.0	381.7	0.5	0.2	0.8
09/10/2026 05:00	4,287.9	0.0	4,287.9	104,800.0	449.4	0.5	0.3	0.9
09/10/2026 06:00	3,850.3	0.0	3,850.3	104,800.0	403.5	0.5	0.2	0.8
09/10/2026 07:00	3,537.8	0.8	3,537.8	104,800.0	370.8	0.4	0.2	0.7
09/10/2026 08:00	3,533.8	6.9	3,533.8	104,800.0	370.3	0.4	0.2	0.7
09/10/2026 09:00	3,532.4	0.0	3,532.4	104,800.0	370.2	0.4	0.2	0.7
09/10/2026 10:00	3,522.5	0.0	3,522.5	104,800.0	369.2	0.4	0.2	0.7
09/10/2026 11:00	3,787.9	0.0	3,787.9	104,800.0	397.0	0.5	0.2	0.8
09/10/2026 12:00	4,459.6	513.0	4,962.3	104,800.0	520.0	0.6	0.3	1.0
09/10/2026 13:00	4,444.7	566.9	5,011.6	104,800.0	525.2	0.6	0.3	1.1
09/10/2026 14:00	4,425.2	635.1	5,060.3	104,800.0	530.3	0.6	0.3	1.1
09/10/2026 15:00	4,421.1	666.1	5,087.2	104,800.0	533.1	0.6	0.3	1.1
09/10/2026 16:00	4,422.0	960.9	5,382.9	104,800.0	564.1	0.7	0.3	1.1
09/10/2026 17:00	4,447.8	1,212.4	5,660.2	104,800.0	593.2	0.7	0.4	1.2
09/10/2026 18:00	4,497.6	540.7	5,038.3	104,800.0	528.0	0.6	0.3	1.1
09/10/2026 19:00	4,538.7	444.2	4,982.9	104,800.0	522.2	0.6	0.3	1.0
09/10/2026 20:00	4,561.4	420.1	4,981.5	104,800.0	522.1	0.6	0.3	1.0
09/10/2026 21:00	4,358.3	670.0	5,028.3	104,800.0	527.0	0.6	0.3	1.1
09/10/2026 22:00	4,404.1	591.1	4,995.2	104,800.0	523.5	0.6	0.3	1.0
09/10/2026 23:00	3,630.4	0.7	3,630.4	104,800.0	380.5	0.5	0.2	0.8
Average/Sum#:	4,117.1	301.2	4,417.5	104,800.0	463.0	0.5	0.3	0.9
Minimum:	3,522.5	0.0	3,522.5	104,800.0	369.2	0.4	0.2	0.7
Maximum:	4,561.4	1,212.4	5,660.2	104,800.0	593.2	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/11/2026 00:00	3,551.7	0.0	3,551.7	104,800.0	372.2	0.4	0.2	0.7
09/11/2026 01:00	3,556.8	0.0	3,556.8	104,800.0	372.8	0.5	0.2	0.7
09/11/2026 02:00	3,556.1	0.0	3,556.1	104,800.0	372.7	0.4	0.2	0.7
09/11/2026 03:00	3,557.7	0.0	3,557.7	104,800.0	372.8	0.5	0.2	0.7
09/11/2026 04:00	3,561.4	0.0	3,561.4	104,800.0	373.2	0.5	0.2	0.7
09/11/2026 05:00	3,565.2	0.0	3,565.2	104,800.0	373.6	0.5	0.2	0.7
09/11/2026 06:00	3,566.4	0.0	3,566.4	104,800.0	373.8	0.5	0.2	0.7
09/11/2026 07:00	3,562.9	0.0	3,562.9	104,800.0	373.4	0.4	0.2	0.7
09/11/2026 08:00	3,559.0	0.0	3,559.0	104,800.0	373.0	0.5	0.2	0.7
09/11/2026 09:00	3,555.7	0.0	3,555.7	104,800.0	372.6	0.4	0.2	0.7
09/11/2026 10:00	3,551.8	0.0	3,551.8	104,800.0	372.2	0.5	0.2	0.7
09/11/2026 11:00	3,546.8	0.0	3,546.8	104,800.0	371.7	0.4	0.2	0.7
09/11/2026 12:00	3,543.8	10.0	3,543.8	104,800.0	371.4	0.4	0.2	0.7
09/11/2026 13:00	3,541.1	40.4	3,541.1	104,800.0	371.1	0.5	0.2	0.8
09/11/2026 14:00	3,542.5	0.0	3,542.5	104,800.0	371.3	0.4	0.2	0.7
09/11/2026 15:00	4,164.6	0.0	4,164.6	104,800.0	436.5	0.5	0.3	0.9
09/11/2026 16:00	3,875.5	0.0	3,875.5	104,800.0	406.2	0.5	0.2	0.8
09/11/2026 17:00	3,850.9	0.0	3,850.9	104,800.0	403.6	0.5	0.2	0.8
09/11/2026 18:00	3,562.8	0.0	3,562.8	104,800.0	373.4	0.5	0.2	0.7
09/11/2026 19:00	3,566.1	0.0	3,566.1	104,800.0	373.7	0.5	0.2	0.7
09/11/2026 20:00	3,562.6	0.0	3,562.6	104,800.0	373.4	0.5	0.2	0.7
09/11/2026 21:00	3,556.5	0.0	3,556.5	104,800.0	372.7	0.5	0.2	0.7
09/11/2026 22:00	3,557.9	0.0	3,557.9	104,800.0	372.9	0.5	0.2	0.7
09/11/2026 23:00	3,555.0	0.0	3,555.0	104,800.0	372.6	0.5	0.2	0.7
Average/Sum#:	3,607.1	2.1	3,607.1	104,800.0	378.0	0.5	0.2	0.7
Minimum:	3,541.1	0.0	3,541.1	104,800.0	371.1	0.4	0.2	0.7
Maximum:	4,164.6	40.4	4,164.6	104,800.0	436.5	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/12/2026 00:00	3,557.7	0.0	3,557.7	104,800.0	372.8	0.5	0.2	0.7
09/12/2026 01:00	3,556.4	0.0	3,556.4	104,800.0	372.7	0.5	0.2	0.7
09/12/2026 02:00	3,558.5	0.0	3,558.5	104,800.0	372.9	0.5	0.2	0.7
09/12/2026 03:00	3,560.1	0.0	3,560.1	104,800.0	373.1	0.5	0.2	0.7
09/12/2026 04:00	3,558.1	0.0	3,558.1	104,800.0	372.9	0.4	0.2	0.7
09/12/2026 05:00	3,561.5	0.0	3,561.5	104,800.0	373.2	0.5	0.2	0.7
09/12/2026 06:00	3,561.9	0.0	3,561.9	104,800.0	373.3	0.5	0.2	0.7
09/12/2026 07:00	3,561.7	0.0	3,561.7	104,800.0	373.3	0.5	0.2	0.7
09/12/2026 08:00	3,556.2	0.0	3,556.2	104,800.0	372.7	0.5	0.2	0.7
09/12/2026 09:00	3,552.2	0.0	3,552.2	104,800.0	372.3	0.5	0.2	0.7
09/12/2026 10:00	3,545.8	0.0	3,545.8	104,800.0	371.6	0.4	0.2	0.7
09/12/2026 11:00	3,538.2	0.0	3,538.2	104,800.0	370.8	0.4	0.2	0.7
09/12/2026 12:00	3,535.8	3.4	3,535.8	104,800.0	370.6	0.4	0.2	0.7
09/12/2026 13:00	3,532.9	23.5	3,532.9	104,800.0	370.2	0.4	0.2	0.7
09/12/2026 14:00	3,530.0	0.0	3,530.0	104,800.0	369.9	0.4	0.2	0.7
09/12/2026 15:00	3,531.6	0.0	3,531.6	104,800.0	370.1	0.4	0.2	0.7
09/12/2026 16:00	3,746.1	0.0	3,746.1	104,800.0	392.6	0.5	0.2	0.8
09/12/2026 17:00	3,569.9	0.0	3,569.9	104,800.0	374.1	0.4	0.2	0.7
09/12/2026 18:00	3,546.9	0.0	3,546.9	104,800.0	371.7	0.4	0.2	0.7
09/12/2026 19:00	3,553.0	0.0	3,553.0	104,800.0	372.4	0.5	0.2	0.7
09/12/2026 20:00	3,555.8	0.0	3,555.8	104,800.0	372.6	0.5	0.2	0.7
09/12/2026 21:00	3,561.1	0.0	3,561.1	104,800.0	373.2	0.5	0.2	0.7
09/12/2026 22:00	3,598.4	0.0	3,598.4	104,800.0	377.1	0.5	0.2	0.8
09/12/2026 23:00	3,566.7	0.0	3,566.7	104,800.0	373.8	0.5	0.2	0.7
Average/Sum#:	3,562.4	1.1	3,562.4	104,800.0	373.3	0.5	0.2	0.7
Minimum:	3,530.0	0.0	3,530.0	104,800.0	369.9	0.4	0.2	0.7
Maximum:	3,746.1	23.5	3,746.1	104,800.0	392.6	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/13/2026 00:00	3,571.0	0.0	3,571.0	104,800.0	374.2	0.5	0.2	0.8
09/13/2026 01:00	3,573.0	0.0	3,573.0	104,800.0	374.5	0.5	0.2	0.8
09/13/2026 02:00	3,576.3	0.0	3,576.3	104,800.0	374.8	0.5	0.2	0.8
09/13/2026 03:00	3,577.3	0.0	3,577.3	104,800.0	374.9	0.5	0.2	0.8
09/13/2026 04:00	3,579.1	0.0	3,579.1	104,800.0	375.1	0.5	0.2	0.8
09/13/2026 05:00	4,078.9	0.0	4,078.9	104,800.0	427.5	0.5	0.3	0.9
09/13/2026 06:00	3,789.3	0.0	3,789.3	104,800.0	397.1	0.5	0.2	0.8
09/13/2026 07:00	3,573.6	0.0	3,573.6	104,800.0	374.5	0.5	0.2	0.7
09/13/2026 08:00	3,572.6	0.0	3,572.6	104,800.0	374.4	0.5	0.2	0.8
09/13/2026 09:00	3,570.5	0.0	3,570.5	104,800.0	374.2	0.5	0.2	0.7
09/13/2026 10:00	3,567.8	0.0	3,567.8	104,800.0	373.9	0.5	0.2	0.7
09/13/2026 11:00	3,564.1	0.0	3,564.1	104,800.0	373.5	0.5	0.2	0.7
09/13/2026 12:00	3,559.4	0.0	3,559.4	104,800.0	373.0	0.5	0.2	0.7
09/13/2026 13:00	3,559.1	0.0	3,559.1	104,800.0	373.0	0.5	0.2	0.7
09/13/2026 14:00	3,555.1	0.0	3,555.1	104,800.0	372.6	0.5	0.2	0.7
09/13/2026 15:00	3,553.8	0.0	3,553.8	104,800.0	372.4	0.4	0.2	0.7
09/13/2026 16:00	3,796.2	0.0	3,796.2	104,800.0	397.8	0.5	0.2	0.8
09/13/2026 17:00	4,131.0	0.0	4,131.0	104,800.0	432.9	0.5	0.3	0.9
09/13/2026 18:00	3,583.9	0.0	3,583.9	104,800.0	375.6	0.5	0.2	0.8
09/13/2026 19:00	3,558.7	0.0	3,558.7	104,800.0	373.0	0.5	0.2	0.7
09/13/2026 20:00	3,566.3	0.0	3,566.3	104,800.0	373.7	0.5	0.2	0.7
09/13/2026 21:00	3,564.6	0.0	3,564.6	104,800.0	373.6	0.5	0.2	0.7
09/13/2026 22:00	3,569.8	0.0	3,569.8	104,800.0	374.1	0.5	0.2	0.7
09/13/2026 23:00	3,572.5	0.0	3,572.5	104,800.0	374.4	0.5	0.2	0.8
Average/Sum#:	3,631.8	0.0	3,631.8	104,800.0	380.6	0.5	0.2	0.8
Minimum:	3,553.8	0.0	3,553.8	104,800.0	372.4	0.4	0.2	0.7
Maximum:	4,131.0	0.0	4,131.0	104,800.0	432.9	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/14/2026 00:00	3,574.6	0.0	3,574.6	104,800.0	374.6	0.5	0.2	0.8
09/14/2026 01:00	3,574.1	0.0	3,574.1	104,800.0	374.6	0.5	0.2	0.8
09/14/2026 02:00	3,573.4	0.0	3,573.4	104,800.0	374.5	0.5	0.2	0.8
09/14/2026 03:00	3,577.6	0.0	3,577.6	104,800.0	374.9	0.5	0.2	0.8
09/14/2026 04:00	3,578.2	0.0	3,578.2	104,800.0	375.0	0.5	0.2	0.8
09/14/2026 05:00	3,625.2	0.0	3,625.2	104,800.0	379.9	0.5	0.2	0.8
09/14/2026 06:00	3,747.4	0.0	3,747.4	104,800.0	392.7	0.5	0.2	0.8
09/14/2026 07:00	3,575.2	0.0	3,575.2	104,800.0	374.7	0.5	0.2	0.8
09/14/2026 08:00	3,567.0	0.0	3,567.0	104,800.0	373.8	0.5	0.2	0.8
09/14/2026 09:00	3,562.6	0.0	3,562.6	104,800.0	373.4	0.5	0.2	0.7
09/14/2026 10:00	3,558.1	0.0	3,558.1	104,800.0	372.9	0.5	0.2	0.7
09/14/2026 11:00	3,552.4	0.0	3,552.4	104,800.0	372.3	0.5	0.2	0.7
09/14/2026 12:00	3,552.2	0.0	3,552.2	104,800.0	372.3	0.5	0.2	0.7
09/14/2026 13:00	3,548.3	13.4	3,548.3	104,800.0	371.9	0.4	0.2	0.7
09/14/2026 14:00	3,546.2	0.0	3,546.2	104,800.0	371.6	0.4	0.2	0.7
09/14/2026 15:00	3,545.6	0.0	3,545.6	104,800.0	371.6	0.4	0.2	0.7
09/14/2026 16:00	3,730.8	0.0	3,730.8	104,800.0	391.0	0.5	0.2	0.8
09/14/2026 17:00	3,866.2	0.0	3,866.2	104,800.0	405.2	0.5	0.2	0.8
09/14/2026 18:00	3,554.4	0.0	3,554.4	104,800.0	372.5	0.5	0.2	0.7
09/14/2026 19:00	3,653.7	0.0	3,653.7	104,800.0	382.9	0.5	0.2	0.8
09/14/2026 20:00	3,577.9	0.0	3,577.9	104,800.0	375.0	0.5	0.2	0.7
09/14/2026 21:00	3,558.4	0.0	3,558.4	104,800.0	372.9	0.5	0.2	0.7
09/14/2026 22:00	3,575.4	0.0	3,575.4	104,800.0	374.7	0.5	0.2	0.8
09/14/2026 23:00	4,137.5	0.0	4,137.5	104,800.0	433.6	0.5	0.3	0.9
Average/Sum#:	3,621.4	0.6	3,621.4	104,800.0	379.5	0.5	0.2	0.8
Minimum:	3,545.6	0.0	3,545.6	104,800.0	371.6	0.4	0.2	0.7
Maximum:	4,137.5	13.4	4,137.5	104,800.0	433.6	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/15/2026 00:00	3,827.7	0.0	3,827.7	104,800.0	401.1	0.5	0.2	0.8
09/15/2026 01:00	3,628.7	0.0	3,628.7	104,800.0	380.3	0.5	0.2	0.8
09/15/2026 02:00	3,575.9	0.0	3,575.9	104,800.0	374.8	0.5	0.2	0.8
09/15/2026 03:00	3,575.8	0.0	3,575.8	104,800.0	374.7	0.5	0.2	0.8
09/15/2026 04:00	3,692.9	0.0	3,692.9	104,800.0	387.0	0.5	0.2	0.8
09/15/2026 05:00	4,349.7	0.0	4,349.7	104,800.0	455.8	0.5	0.3	0.9
09/15/2026 06:00	4,348.0	0.0	4,348.0	104,800.0	455.7	0.5	0.3	0.9
09/15/2026 07:00	4,262.3	0.0	4,262.3	104,800.0	446.7	0.5	0.3	0.9
09/15/2026 08:00	4,353.9	0.0	4,353.9	104,800.0	456.3	0.5	0.3	0.9
09/15/2026 09:00	4,344.5	0.0	4,344.5	104,800.0	455.3	0.5	0.3	0.9
09/15/2026 10:00	4,138.5	0.0	4,138.5	104,800.0	433.7	0.5	0.3	0.9
09/15/2026 11:00	4,350.9	0.0	4,350.9	104,800.0	456.0	0.5	0.3	0.9
09/15/2026 12:00	4,233.2	5.3	4,233.2	104,800.0	443.6	0.5	0.3	0.9
09/15/2026 13:00	4,236.0	28.2	4,236.0	104,800.0	443.9	0.5	0.3	0.9
09/15/2026 14:00	4,231.1	0.0	4,231.1	104,800.0	443.4	0.5	0.3	0.9
09/15/2026 15:00	4,201.8	0.0	4,201.8	104,800.0	440.3	0.5	0.3	0.9
09/15/2026 16:00	3,741.7	0.0	3,741.7	104,800.0	392.1	0.5	0.2	0.8
09/15/2026 17:00	3,587.9	0.0	3,587.9	104,800.0	376.0	0.5	0.2	0.8
09/15/2026 18:00	3,568.2	0.0	3,568.2	104,800.0	373.9	0.5	0.2	0.8
09/15/2026 19:00	3,571.3	0.0	3,571.3	104,800.0	374.3	0.5	0.2	0.8
09/15/2026 20:00	3,579.9	0.0	3,579.9	104,800.0	375.2	0.5	0.2	0.8
09/15/2026 21:00	3,584.9	0.0	3,584.9	104,800.0	375.7	0.5	0.2	0.8
09/15/2026 22:00	3,586.2	0.0	3,586.2	104,800.0	375.8	0.5	0.2	0.8
09/15/2026 23:00	3,589.0	0.0	3,589.0	104,800.0	376.1	0.5	0.2	0.8
Average/Sum#:	3,923.3	1.4	3,923.3	104,800.0	411.2	0.5	0.2	0.8
Minimum:	3,568.2	0.0	3,568.2	104,800.0	373.9	0.5	0.2	0.8
Maximum:	4,353.9	28.2	4,353.9	104,800.0	456.3	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/16/2026 00:00	3,590.7	0.0	3,590.7	104,800.0	376.3	0.5	0.2	0.8
09/16/2026 01:00	3,593.3	0.0	3,593.3	104,800.0	376.6	0.5	0.2	0.8
09/16/2026 02:00	3,596.1	0.0	3,596.1	104,800.0	376.9	0.5	0.2	0.8
09/16/2026 03:00	3,600.6	0.0	3,600.6	104,800.0	377.3	0.5	0.2	0.8
09/16/2026 04:00	3,603.9	0.0	3,603.9	104,800.0	377.7	0.5	0.2	0.8
09/16/2026 05:00	3,610.0	0.0	3,610.0	104,800.0	378.3	0.5	0.2	0.8
09/16/2026 06:00	3,675.1	0.0	3,675.1	104,800.0	385.2	0.5	0.2	0.8
09/16/2026 07:00	3,556.7	0.0	3,556.7	104,800.0	372.7	0.5	0.2	0.8
09/16/2026 08:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
09/16/2026 09:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
09/16/2026 10:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
09/16/2026 11:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
09/16/2026 12:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
09/16/2026 13:00	0.0	0.0	0.0	104,800.0	0.0	0.0	0.0	0.0
09/16/2026 14:00	207.2	0.0	207.2	104,800.0	21.7	0.0	0.0	0.0
09/16/2026 15:00	3,089.4	0.0	3,089.4	104,800.0	323.8	0.5	0.2	0.8
09/16/2026 16:00	3,589.2	0.0	3,589.2	104,800.0	376.1	0.5	0.2	0.8
09/16/2026 17:00	3,585.6	0.0	3,585.6	104,800.0	375.8	0.5	0.2	0.8
09/16/2026 18:00	3,591.5	0.0	3,591.5	104,800.0	376.4	0.5	0.2	0.8
09/16/2026 19:00	3,595.6	0.0	3,595.6	104,800.0	376.8	0.5	0.2	0.8
09/16/2026 20:00	3,599.1	0.0	3,599.1	104,800.0	377.2	0.5	0.2	0.8
09/16/2026 21:00	3,602.5	0.0	3,602.5	104,800.0	377.5	0.5	0.2	0.8
09/16/2026 22:00	3,604.5	0.0	3,604.5	104,800.0	377.8	0.5	0.2	0.8
09/16/2026 23:00	3,604.1	0.0	3,604.1	104,800.0	377.7	0.5	0.2	0.8
Average/Sum#:	3,383.1	0.0	3,383.1	104,800.0	354.5	0.5	0.2	0.8
Minimum:	207.2	0.0	207.2	104,800.0	21.7	0.5	0.2	0.8
Maximum:	3,675.1	0.0	3,675.1	104,800.0	385.2	0.5	0.2	0.8
%SI	25.00	25.00	25.00	0.00	25.00	29.17	29.17	29.17

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/17/2026 00:00	3,605.3	0.0	3,605.3	104,800.0	377.8	0.5	0.2	0.8
09/17/2026 01:00	3,606.1	0.0	3,606.1	104,800.0	377.9	0.5	0.2	0.8
09/17/2026 02:00	3,609.3	0.0	3,609.3	104,800.0	378.3	0.5	0.2	0.8
09/17/2026 03:00	3,609.7	0.0	3,609.7	104,800.0	378.3	0.5	0.2	0.8
09/17/2026 04:00	3,608.1	0.0	3,608.1	104,800.0	378.1	0.5	0.2	0.8
09/17/2026 05:00	3,987.2	0.0	3,987.2	104,800.0	417.9	0.5	0.3	0.8
09/17/2026 06:00	3,957.4	0.0	3,957.4	104,800.0	414.7	0.5	0.2	0.8
09/17/2026 07:00	3,603.9	0.0	3,603.9	104,800.0	377.7	0.5	0.2	0.8
09/17/2026 08:00	3,603.4	0.0	3,603.4	104,800.0	377.6	0.5	0.2	0.8
09/17/2026 09:00	3,604.2	0.0	3,604.2	104,800.0	377.7	0.5	0.2	0.8
09/17/2026 10:00	3,600.6	0.0	3,600.6	104,800.0	377.3	0.5	0.2	0.8
09/17/2026 11:00	3,595.5	0.0	3,595.5	104,800.0	376.8	0.5	0.2	0.8
09/17/2026 12:00	3,593.0	0.0	3,593.0	104,800.0	376.5	0.5	0.2	0.8
09/17/2026 13:00	3,592.2	0.0	3,592.2	104,800.0	376.5	0.5	0.2	0.8
09/17/2026 14:00	3,590.0	0.0	3,590.0	104,800.0	376.2	0.5	0.2	0.8
09/17/2026 15:00	3,589.9	0.0	3,589.9	104,800.0	376.2	0.5	0.2	0.8
09/17/2026 16:00	3,740.7	0.0	3,740.7	104,800.0	392.0	0.5	0.2	0.8
09/17/2026 17:00	3,589.8	0.0	3,589.8	104,800.0	376.2	0.5	0.2	0.8
09/17/2026 18:00	3,592.0	0.0	3,592.0	104,800.0	376.4	0.5	0.2	0.8
09/17/2026 19:00	3,593.7	0.0	3,593.7	104,800.0	376.6	0.5	0.2	0.8
09/17/2026 20:00	3,597.5	0.0	3,597.5	104,800.0	377.0	0.5	0.2	0.8
09/17/2026 21:00	3,598.8	0.0	3,598.8	104,800.0	377.2	0.5	0.2	0.8
09/17/2026 22:00	3,598.0	0.0	3,598.0	104,800.0	377.1	0.5	0.2	0.8
09/17/2026 23:00	3,600.6	0.0	3,600.6	104,800.0	377.3	0.5	0.2	0.8
Average/Sum#:	3,636.1	0.0	3,636.1	104,800.0	381.1	0.5	0.2	0.8
Minimum:	3,589.8	0.0	3,589.8	104,800.0	376.2	0.5	0.2	0.8
Maximum:	3,987.2	0.0	3,987.2	104,800.0	417.9	0.5	0.3	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/18/2026 00:00	3,602.1	0.0	3,602.1	104,800.0	377.5	0.5	0.2	0.8
09/18/2026 01:00	3,604.2	0.0	3,604.2	104,800.0	377.7	0.5	0.2	0.8
09/18/2026 02:00	3,603.9	0.0	3,603.9	104,800.0	377.7	0.5	0.2	0.8
09/18/2026 03:00	3,605.7	0.0	3,605.7	104,800.0	377.9	0.5	0.2	0.8
09/18/2026 04:00	3,608.5	0.0	3,608.5	104,800.0	378.2	0.5	0.2	0.8
09/18/2026 05:00	3,609.1	0.0	3,609.1	104,800.0	378.2	0.5	0.2	0.8
09/18/2026 06:00	3,975.6	0.0	3,975.6	104,800.0	416.6	0.5	0.2	0.8
09/18/2026 07:00	3,625.9	0.0	3,625.9	104,800.0	380.0	0.5	0.2	0.8
09/18/2026 08:00	3,602.3	0.0	3,602.3	104,800.0	377.5	0.5	0.2	0.8
09/18/2026 09:00	3,596.7	0.0	3,596.7	104,800.0	376.9	0.5	0.2	0.8
09/18/2026 10:00	3,594.5	0.0	3,594.5	104,800.0	376.7	0.5	0.2	0.8
09/18/2026 11:00	3,588.1	0.0	3,588.1	104,800.0	376.0	0.5	0.2	0.8
09/18/2026 12:00	3,585.0	0.0	3,585.0	104,800.0	375.7	0.5	0.2	0.8
09/18/2026 13:00	3,602.9	0.0	3,602.9	104,800.0	377.6	0.5	0.2	0.8
09/18/2026 14:00	3,577.4	0.0	3,577.4	104,800.0	374.9	0.5	0.2	0.8
09/18/2026 15:00	3,577.4	0.0	3,577.4	104,800.0	374.9	0.5	0.2	0.8
09/18/2026 16:00	4,086.8	0.0	4,086.8	104,800.0	428.3	0.5	0.3	0.9
09/18/2026 17:00	4,350.7	0.0	4,350.7	104,800.0	456.0	0.5	0.3	0.9
09/18/2026 18:00	3,596.9	0.0	3,596.9	104,800.0	377.0	0.5	0.2	0.8
09/18/2026 19:00	3,579.4	0.0	3,579.4	104,800.0	375.1	0.5	0.2	0.8
09/18/2026 20:00	3,585.3	0.0	3,585.3	104,800.0	375.7	0.5	0.2	0.8
09/18/2026 21:00	3,589.5	0.0	3,589.5	104,800.0	376.2	0.5	0.2	0.8
09/18/2026 22:00	3,594.0	0.0	3,594.0	104,800.0	376.7	0.5	0.2	0.8
09/18/2026 23:00	3,595.7	0.0	3,595.7	104,800.0	376.8	0.5	0.2	0.8
Average/Sum#:	3,664.1	0.0	3,664.1	104,800.0	384.0	0.5	0.2	0.8
Minimum:	3,577.4	0.0	3,577.4	104,800.0	374.9	0.5	0.2	0.8
Maximum:	4,350.7	0.0	4,350.7	104,800.0	456.0	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/19/2026 00:00	3,598.4	0.0	3,598.4	104,800.0	377.1	0.5	0.2	0.8
09/19/2026 01:00	3,600.2	0.0	3,600.2	104,800.0	377.3	0.5	0.2	0.8
09/19/2026 02:00	3,601.9	0.0	3,601.9	104,800.0	377.5	0.5	0.2	0.8
09/19/2026 03:00	3,599.6	0.0	3,599.6	104,800.0	377.2	0.5	0.2	0.8
09/19/2026 04:00	3,601.3	0.0	3,601.3	104,800.0	377.4	0.5	0.2	0.8
09/19/2026 05:00	3,600.8	0.0	3,600.8	104,800.0	377.4	0.5	0.2	0.8
09/19/2026 06:00	3,600.6	0.0	3,600.6	104,800.0	377.3	0.5	0.2	0.8
09/19/2026 07:00	3,599.9	0.0	3,599.9	104,800.0	377.3	0.5	0.2	0.8
09/19/2026 08:00	3,594.6	0.0	3,594.6	104,800.0	376.7	0.5	0.2	0.8
09/19/2026 09:00	3,591.7	0.0	3,591.7	104,800.0	376.4	0.5	0.2	0.8
09/19/2026 10:00	3,587.7	0.0	3,587.7	104,800.0	376.0	0.5	0.2	0.8
09/19/2026 11:00	3,580.7	0.0	3,580.7	104,800.0	375.3	0.5	0.2	0.8
09/19/2026 12:00	3,578.9	0.1	3,578.9	104,800.0	375.1	0.5	0.2	0.8
09/19/2026 13:00	3,577.1	18.0	3,577.1	104,800.0	374.9	0.5	0.2	0.8
09/19/2026 14:00	3,571.9	0.0	3,571.9	104,800.0	374.3	0.5	0.2	0.7
09/19/2026 15:00	3,569.6	0.0	3,569.6	104,800.0	374.1	0.5	0.2	0.8
09/19/2026 16:00	3,693.3	0.0	3,693.3	104,800.0	387.1	0.5	0.2	0.8
09/19/2026 17:00	3,564.1	0.0	3,564.1	104,800.0	373.5	0.5	0.2	0.7
09/19/2026 18:00	3,574.7	0.0	3,574.7	104,800.0	374.6	0.5	0.2	0.8
09/19/2026 19:00	3,582.2	0.0	3,582.2	104,800.0	375.4	0.5	0.2	0.8
09/19/2026 20:00	3,583.7	0.0	3,583.7	104,800.0	375.6	0.5	0.2	0.8
09/19/2026 21:00	3,641.0	0.0	3,641.0	104,800.0	381.6	0.5	0.2	0.8
09/19/2026 22:00	3,786.6	0.0	3,786.6	104,800.0	396.8	0.5	0.2	0.8
09/19/2026 23:00	3,724.5	0.0	3,724.5	104,800.0	390.3	0.5	0.2	0.8
Average/Sum#:	3,608.5	0.8	3,608.5	104,800.0	378.2	0.5	0.2	0.8
Minimum:	3,564.1	0.0	3,564.1	104,800.0	373.5	0.5	0.2	0.7
Maximum:	3,786.6	18.0	3,786.6	104,800.0	396.8	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/20/2026 00:00	3,695.4	0.0	3,695.4	104,800.0	387.3	0.5	0.2	0.8
09/20/2026 01:00	3,591.8	0.0	3,591.8	104,800.0	376.4	0.5	0.2	0.8
09/20/2026 02:00	3,593.3	0.0	3,593.3	104,800.0	376.6	0.5	0.2	0.8
09/20/2026 03:00	3,595.4	0.0	3,595.4	104,800.0	376.8	0.5	0.2	0.8
09/20/2026 04:00	3,597.0	0.0	3,597.0	104,800.0	377.0	0.5	0.2	0.8
09/20/2026 05:00	3,602.0	0.0	3,602.0	104,800.0	377.5	0.5	0.2	0.8
09/20/2026 06:00	3,611.7	0.0	3,611.7	104,800.0	378.5	0.5	0.2	0.8
09/20/2026 07:00	3,602.0	0.0	3,602.0	104,800.0	377.5	0.5	0.2	0.8
09/20/2026 08:00	3,598.5	0.0	3,598.5	104,800.0	377.1	0.5	0.2	0.8
09/20/2026 09:00	3,592.7	0.0	3,592.7	104,800.0	376.5	0.5	0.2	0.8
09/20/2026 10:00	3,587.3	0.0	3,587.3	104,800.0	375.9	0.5	0.2	0.8
09/20/2026 11:00	3,585.8	0.0	3,585.8	104,800.0	375.8	0.5	0.2	0.8
09/20/2026 12:00	3,583.1	0.0	3,583.1	104,800.0	375.5	0.5	0.2	0.8
09/20/2026 13:00	3,965.1	0.0	3,965.1	104,800.0	415.5	0.5	0.2	0.8
09/20/2026 14:00	4,363.6	0.0	4,363.6	104,800.0	457.3	0.5	0.3	0.9
09/20/2026 15:00	4,268.3	0.0	4,268.3	104,800.0	447.3	0.5	0.3	0.9
09/20/2026 16:00	4,124.4	0.0	4,124.4	104,800.0	432.2	0.5	0.3	0.9
09/20/2026 17:00	3,601.1	0.0	3,601.1	104,800.0	377.4	0.5	0.2	0.8
09/20/2026 18:00	3,583.2	0.0	3,583.2	104,800.0	375.5	0.5	0.2	0.8
09/20/2026 19:00	3,589.6	0.0	3,589.6	104,800.0	376.2	0.5	0.2	0.8
09/20/2026 20:00	3,591.0	0.0	3,591.0	104,800.0	376.3	0.5	0.2	0.8
09/20/2026 21:00	3,590.2	0.0	3,590.2	104,800.0	376.3	0.5	0.2	0.8
09/20/2026 22:00	3,592.1	0.0	3,592.1	104,800.0	376.5	0.5	0.2	0.8
09/20/2026 23:00	3,653.6	0.0	3,653.6	104,800.0	382.9	0.5	0.2	0.8
Average/Sum#:	3,698.3	0.0	3,698.3	104,800.0	387.6	0.5	0.2	0.8
Minimum:	3,583.1	0.0	3,583.1	104,800.0	375.5	0.5	0.2	0.8
Maximum:	4,363.6	0.0	4,363.6	104,800.0	457.3	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/21/2026 00:00	3,590.6	0.0	3,590.6	104,800.0	376.3	0.5	0.2	0.8
09/21/2026 01:00	3,593.3	0.0	3,593.3	104,800.0	376.6	0.5	0.2	0.8
09/21/2026 02:00	3,596.4	0.0	3,596.4	104,800.0	376.9	0.5	0.2	0.8
09/21/2026 03:00	3,596.6	0.0	3,596.6	104,800.0	376.9	0.5	0.2	0.8
09/21/2026 04:00	3,791.2	0.0	3,791.2	104,800.0	397.3	0.5	0.2	0.8
09/21/2026 05:00	4,248.1	0.0	4,248.1	104,800.0	445.2	0.5	0.3	0.9
09/21/2026 06:00	4,141.6	0.0	4,141.6	104,800.0	434.0	0.5	0.3	0.9
09/21/2026 07:00	4,093.5	0.0	4,093.5	104,800.0	429.0	0.5	0.3	0.9
09/21/2026 08:00	3,880.5	0.0	3,880.5	104,800.0	406.7	0.5	0.2	0.8
09/21/2026 09:00	3,602.1	0.0	3,602.1	104,800.0	377.5	0.5	0.2	0.8
09/21/2026 10:00	3,598.3	0.0	3,598.3	104,800.0	377.1	0.5	0.2	0.8
09/21/2026 11:00	3,592.2	0.0	3,592.2	104,800.0	376.5	0.5	0.2	0.8
09/21/2026 12:00	3,589.8	0.0	3,589.8	104,800.0	376.2	0.5	0.2	0.8
09/21/2026 13:00	3,586.3	0.0	3,586.3	104,800.0	375.8	0.5	0.2	0.8
09/21/2026 14:00	3,705.6	0.0	3,705.6	104,800.0	388.3	0.5	0.2	0.8
09/21/2026 15:00	3,580.4	0.0	3,580.4	104,800.0	375.2	0.5	0.2	0.8
09/21/2026 16:00	3,728.4	0.0	3,728.4	104,800.0	390.7	0.5	0.2	0.8
09/21/2026 17:00	3,582.7	0.0	3,582.7	104,800.0	375.5	0.5	0.2	0.8
09/21/2026 18:00	3,588.7	0.0	3,588.7	104,800.0	376.1	0.5	0.2	0.8
09/21/2026 19:00	3,592.3	0.0	3,592.3	104,800.0	376.5	0.5	0.2	0.8
09/21/2026 20:00	3,595.4	0.0	3,595.4	104,800.0	376.8	0.5	0.2	0.8
09/21/2026 21:00	3,598.1	0.0	3,598.1	104,800.0	377.1	0.5	0.2	0.8
09/21/2026 22:00	3,598.8	0.0	3,598.8	104,800.0	377.2	0.5	0.2	0.8
09/21/2026 23:00	3,601.2	0.0	3,601.2	104,800.0	377.4	0.5	0.2	0.8
Average/Sum#:	3,694.7	0.0	3,694.7	104,800.0	387.2	0.5	0.2	0.8
Minimum:	3,580.4	0.0	3,580.4	104,800.0	375.2	0.5	0.2	0.8
Maximum:	4,248.1	0.0	4,248.1	104,800.0	445.2	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/22/2026 00:00	3,601.1	0.0	3,601.1	104,800.0	377.4	0.5	0.2	0.8
09/22/2026 01:00	3,604.1	0.0	3,604.1	104,800.0	377.7	0.5	0.2	0.8
09/22/2026 02:00	3,607.2	0.0	3,607.2	104,800.0	378.0	0.5	0.2	0.8
09/22/2026 03:00	3,608.6	0.0	3,608.6	104,800.0	378.2	0.5	0.2	0.8
09/22/2026 04:00	3,609.5	0.0	3,609.5	104,800.0	378.3	0.5	0.2	0.8
09/22/2026 05:00	3,618.3	0.0	3,618.3	104,800.0	379.2	0.5	0.2	0.8
09/22/2026 06:00	3,762.8	0.0	3,762.8	104,800.0	394.3	0.5	0.2	0.8
09/22/2026 07:00	3,614.0	0.0	3,614.0	104,800.0	378.7	0.5	0.2	0.8
09/22/2026 08:00	3,610.0	0.0	3,610.0	104,800.0	378.3	0.5	0.2	0.8
09/22/2026 09:00	3,603.5	0.0	3,603.5	104,800.0	377.6	0.5	0.2	0.8
09/22/2026 10:00	3,595.8	0.0	3,595.8	104,800.0	376.8	0.5	0.2	0.8
09/22/2026 11:00	3,590.6	0.0	3,590.6	104,800.0	376.3	0.5	0.2	0.8
09/22/2026 12:00	3,587.4	0.0	3,587.4	104,800.0	376.0	0.5	0.2	0.8
09/22/2026 13:00	3,580.6	0.0	3,580.6	104,800.0	375.2	0.5	0.2	0.8
09/22/2026 14:00	3,578.3	0.0	3,578.3	104,800.0	375.0	0.5	0.2	0.8
09/22/2026 15:00	3,577.4	0.0	3,577.4	104,800.0	374.9	0.5	0.2	0.8
09/22/2026 16:00	3,659.6	0.0	3,659.6	104,800.0	383.5	0.5	0.2	0.8
09/22/2026 17:00	3,573.7	0.0	3,573.7	104,800.0	374.5	0.5	0.2	0.8
09/22/2026 18:00	3,577.2	0.0	3,577.2	104,800.0	374.9	0.5	0.2	0.8
09/22/2026 19:00	3,587.3	0.0	3,587.3	104,800.0	375.9	0.5	0.2	0.8
09/22/2026 20:00	3,590.4	0.0	3,590.4	104,800.0	376.3	0.5	0.2	0.8
09/22/2026 21:00	4,109.9	89.9	4,135.1	104,800.0	433.4	0.5	0.3	0.9
09/22/2026 22:00	4,645.3	315.6	4,960.9	104,800.0	519.9	0.6	0.3	1.0
09/22/2026 23:00	3,816.0	1.7	3,816.0	104,800.0	399.9	0.5	0.2	0.8
Average/Sum#:	3,679.5	17.0	3,693.7	104,800.0	387.1	0.5	0.2	0.8
Minimum:	3,573.7	0.0	3,573.7	104,800.0	374.5	0.5	0.2	0.8
Maximum:	4,645.3	315.6	4,960.9	104,800.0	519.9	0.6	0.3	1.0
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/23/2026 00:00	3,601.9	0.0	3,601.9	104,800.0	377.5	0.5	0.2	0.8
09/23/2026 01:00	3,606.9	0.0	3,606.9	104,800.0	378.0	0.5	0.2	0.8
09/23/2026 02:00	3,605.2	0.0	3,605.2	104,800.0	377.8	0.5	0.2	0.8
09/23/2026 03:00	3,608.6	0.0	3,608.6	104,800.0	378.2	0.5	0.2	0.8
09/23/2026 04:00	3,647.0	0.0	3,647.0	104,800.0	382.2	0.5	0.2	0.8
09/23/2026 05:00	3,985.7	0.0	3,985.7	104,800.0	417.7	0.5	0.3	0.8
09/23/2026 06:00	3,883.8	0.0	3,883.8	104,800.0	407.0	0.5	0.2	0.8
09/23/2026 07:00	3,606.5	0.0	3,606.5	104,800.0	378.0	0.5	0.2	0.8
09/23/2026 08:00	3,601.2	0.0	3,601.2	104,800.0	377.4	0.5	0.2	0.8
09/23/2026 09:00	3,593.8	0.0	3,593.8	104,800.0	376.6	0.5	0.2	0.8
09/23/2026 10:00	3,590.9	0.0	3,590.9	104,800.0	376.3	0.5	0.2	0.8
09/23/2026 11:00	3,583.7	0.0	3,583.7	104,800.0	375.6	0.5	0.2	0.8
09/23/2026 12:00	3,578.4	0.0	3,578.4	104,800.0	375.0	0.5	0.2	0.8
09/23/2026 13:00	3,665.5	0.2	3,665.5	104,800.0	384.1	0.5	0.2	0.8
09/23/2026 14:00	3,610.6	0.0	3,610.6	104,800.0	378.4	0.5	0.2	0.8
09/23/2026 15:00	3,730.3	1.1	3,730.3	104,800.0	390.9	0.5	0.2	0.8
09/23/2026 16:00	3,947.7	1.7	3,947.8	104,800.0	413.7	0.5	0.2	0.8
09/23/2026 17:00	3,613.0	0.0	3,613.0	104,800.0	378.6	0.5	0.2	0.8
09/23/2026 18:00	3,575.9	0.0	3,575.9	104,800.0	374.8	0.5	0.2	0.8
09/23/2026 19:00	4,332.2	0.0	4,332.2	104,800.0	454.0	0.5	0.3	0.9
09/23/2026 20:00	3,929.2	0.0	3,929.2	104,800.0	411.8	0.5	0.2	0.8
09/23/2026 21:00	3,657.9	0.0	3,657.9	104,800.0	383.3	0.5	0.2	0.8
09/23/2026 22:00	3,593.0	0.0	3,593.0	104,800.0	376.5	0.5	0.2	0.8
09/23/2026 23:00	3,596.5	0.0	3,596.5	104,800.0	376.9	0.5	0.2	0.8
Average/Sum#:	3,697.7	0.1	3,697.7	104,800.0	387.5	0.5	0.2	0.8
Minimum:	3,575.9	0.0	3,575.9	104,800.0	374.8	0.5	0.2	0.8
Maximum:	4,332.2	1.7	4,332.2	104,800.0	454.0	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/24/2026 00:00	3,600.1	0.0	3,600.1	104,800.0	377.3	0.5	0.2	0.8
09/24/2026 01:00	3,594.9	0.0	3,594.9	104,800.0	376.7	0.5	0.2	0.8
09/24/2026 02:00	3,597.3	0.0	3,597.3	104,800.0	377.0	0.5	0.2	0.8
09/24/2026 03:00	3,594.5	0.0	3,594.5	104,800.0	376.7	0.5	0.2	0.8
09/24/2026 04:00	3,630.1	0.0	3,630.1	104,800.0	380.4	0.5	0.2	0.8
09/24/2026 05:00	4,051.2	0.0	4,051.2	104,800.0	424.6	0.5	0.3	0.8
09/24/2026 06:00	3,965.4	0.0	3,965.4	104,800.0	415.6	0.5	0.2	0.8
09/24/2026 07:00	3,598.1	0.0	3,598.1	104,800.0	377.1	0.5	0.2	0.8
09/24/2026 08:00	3,591.8	0.0	3,591.8	104,800.0	376.4	0.5	0.2	0.8
09/24/2026 09:00	3,584.8	0.0	3,584.8	104,800.0	375.7	0.5	0.2	0.8
09/24/2026 10:00	3,578.1	0.0	3,578.1	104,800.0	375.0	0.5	0.2	0.8
09/24/2026 11:00	3,574.5	0.0	3,574.5	104,800.0	374.6	0.5	0.2	0.8
09/24/2026 12:00	3,573.8	0.0	3,573.8	104,800.0	374.5	0.5	0.2	0.8
09/24/2026 13:00	3,871.3	0.2	3,871.3	104,800.0	405.7	0.5	0.2	0.8
09/24/2026 14:00	3,988.1	0.0	3,988.1	104,800.0	418.0	0.5	0.3	0.8
09/24/2026 15:00	4,039.4	0.0	4,039.4	104,800.0	423.3	0.5	0.3	0.8
09/24/2026 16:00	3,992.7	0.0	3,992.7	104,800.0	418.4	0.5	0.3	0.8
09/24/2026 17:00	4,442.2	146.3	4,483.2	104,800.0	469.8	0.6	0.3	1.0
09/24/2026 18:00	4,574.1	688.5	5,262.6	104,800.0	551.5	0.7	0.3	1.1
09/24/2026 19:00	3,783.7	5.7	3,783.9	104,800.0	396.6	0.5	0.2	0.8
09/24/2026 20:00	3,574.4	0.0	3,574.4	104,800.0	374.6	0.5	0.2	0.8
09/24/2026 21:00	3,578.0	0.0	3,578.0	104,800.0	375.0	0.5	0.2	0.8
09/24/2026 22:00	3,582.7	0.0	3,582.7	104,800.0	375.5	0.5	0.2	0.8
09/24/2026 23:00	3,583.5	0.0	3,583.5	104,800.0	375.6	0.5	0.2	0.8
Average/Sum#:	3,772.7	35.0	3,803.1	104,800.0	398.6	0.5	0.2	0.8
Minimum:	3,573.8	0.0	3,573.8	104,800.0	374.5	0.5	0.2	0.8
Maximum:	4,574.1	688.5	5,262.6	104,800.0	551.5	0.7	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/25/2026 00:00	3,584.4	0.0	3,584.4	104,800.0	375.6	0.5	0.2	0.8
09/25/2026 01:00	3,585.5	0.0	3,585.5	104,800.0	375.8	0.5	0.2	0.8
09/25/2026 02:00	3,586.8	0.0	3,586.8	104,800.0	375.9	0.5	0.2	0.8
09/25/2026 03:00	3,589.5	0.0	3,589.5	104,800.0	376.2	0.5	0.2	0.8
09/25/2026 04:00	3,590.4	0.0	3,590.4	104,800.0	376.3	0.5	0.2	0.8
09/25/2026 05:00	3,621.8	0.0	3,621.8	104,800.0	379.6	0.5	0.2	0.8
09/25/2026 06:00	3,733.8	0.0	3,733.8	104,800.0	391.3	0.5	0.2	0.8
09/25/2026 07:00	3,760.1	0.0	3,760.1	104,800.0	394.1	0.5	0.2	0.8
09/25/2026 08:00	3,580.1	0.0	3,580.1	104,800.0	375.2	0.5	0.2	0.8
09/25/2026 09:00	3,576.3	0.0	3,576.3	104,800.0	374.8	0.5	0.2	0.8
09/25/2026 10:00	3,573.9	0.0	3,573.9	104,800.0	374.5	0.5	0.2	0.8
09/25/2026 11:00	3,564.2	0.0	3,564.2	104,800.0	373.5	0.5	0.2	0.7
09/25/2026 12:00	3,556.4	0.0	3,556.4	104,800.0	372.7	0.5	0.2	0.7
09/25/2026 13:00	3,553.8	0.0	3,553.8	104,800.0	372.4	0.5	0.2	0.7
09/25/2026 14:00	3,550.6	0.0	3,550.6	104,800.0	372.1	0.5	0.2	0.7
09/25/2026 15:00	3,547.6	0.0	3,547.6	104,800.0	371.8	0.4	0.2	0.7
09/25/2026 16:00	3,625.7	0.0	3,625.7	104,800.0	380.0	0.5	0.2	0.8
09/25/2026 17:00	3,555.3	0.0	3,555.3	104,800.0	372.6	0.4	0.2	0.7
09/25/2026 18:00	3,562.7	0.0	3,562.7	104,800.0	373.4	0.5	0.2	0.7
09/25/2026 19:00	3,567.3	0.0	3,567.3	104,800.0	373.9	0.5	0.2	0.8
09/25/2026 20:00	3,573.8	0.0	3,573.8	104,800.0	374.5	0.5	0.2	0.8
09/25/2026 21:00	3,576.0	0.0	3,576.0	104,800.0	374.8	0.5	0.2	0.8
09/25/2026 22:00	3,577.9	0.0	3,577.9	104,800.0	375.0	0.5	0.2	0.8
09/25/2026 23:00	3,578.7	0.0	3,578.7	104,800.0	375.0	0.5	0.2	0.8
Average/Sum#:	3,590.5	0.0	3,590.5	104,800.0	376.3	0.5	0.2	0.8
Minimum:	3,547.6	0.0	3,547.6	104,800.0	371.8	0.4	0.2	0.7
Maximum:	3,760.1	0.0	3,760.1	104,800.0	394.1	0.5	0.2	0.8
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/26/2026 00:00	3,581.2	0.0	3,581.2	104,800.0	375.3	0.5	0.2	0.8
09/26/2026 01:00	3,585.6	0.0	3,585.6	104,800.0	375.8	0.5	0.2	0.8
09/26/2026 02:00	3,588.1	0.0	3,588.1	104,800.0	376.0	0.5	0.2	0.8
09/26/2026 03:00	3,587.3	0.0	3,587.3	104,800.0	375.9	0.5	0.2	0.8
09/26/2026 04:00	3,584.5	0.0	3,584.5	104,800.0	375.7	0.5	0.2	0.8
09/26/2026 05:00	3,588.1	0.0	3,588.1	104,800.0	376.0	0.5	0.2	0.8
09/26/2026 06:00	3,587.9	0.0	3,587.9	104,800.0	376.0	0.5	0.2	0.8
09/26/2026 07:00	3,590.2	0.0	3,590.2	104,800.0	376.3	0.5	0.2	0.8
09/26/2026 08:00	3,592.1	0.0	3,592.1	104,800.0	376.5	0.5	0.2	0.8
09/26/2026 09:00	3,587.4	0.0	3,587.4	104,800.0	376.0	0.5	0.2	0.8
09/26/2026 10:00	3,585.7	0.0	3,585.7	104,800.0	375.8	0.5	0.2	0.8
09/26/2026 11:00	3,580.2	0.0	3,580.2	104,800.0	375.2	0.5	0.2	0.8
09/26/2026 12:00	3,576.8	0.0	3,576.8	104,800.0	374.8	0.5	0.2	0.8
09/26/2026 13:00	3,570.9	0.0	3,570.9	104,800.0	374.2	0.5	0.2	0.8
09/26/2026 14:00	3,567.4	0.0	3,567.4	104,800.0	373.9	0.5	0.2	0.8
09/26/2026 15:00	3,565.1	0.0	3,565.1	104,800.0	373.6	0.5	0.2	0.7
09/26/2026 16:00	4,006.9	0.0	4,006.9	104,800.0	419.9	0.5	0.3	0.8
09/26/2026 17:00	4,367.1	0.0	4,367.1	104,800.0	457.7	0.5	0.3	0.9
09/26/2026 18:00	3,928.6	0.0	3,928.6	104,800.0	411.7	0.5	0.2	0.8
09/26/2026 19:00	4,364.7	0.0	4,364.7	104,800.0	457.4	0.5	0.3	0.9
09/26/2026 20:00	4,339.3	0.0	4,339.3	104,800.0	454.8	0.5	0.3	0.9
09/26/2026 21:00	4,340.7	0.0	4,340.7	104,800.0	454.9	0.5	0.3	0.9
09/26/2026 22:00	4,408.0	140.1	4,447.2	104,800.0	466.1	0.6	0.3	1.0
09/26/2026 23:00	4,605.2	1,398.8	6,004.0	104,800.0	629.2	0.8	0.4	1.3
Average/Sum#:	3,820.0	64.1	3,879.9	104,800.0	406.6	0.5	0.2	0.8
Minimum:	3,565.1	0.0	3,565.1	104,800.0	373.6	0.5	0.2	0.7
Maximum:	4,605.2	1,398.8	6,004.0	104,800.0	629.2	0.8	0.4	1.3
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/27/2026 00:00	4,644.8	348.2	4,993.0	104,800.0	523.3	0.6	0.3	1.0
09/27/2026 01:00	4,352.0	134.9	4,422.1	104,800.0	463.4	0.6	0.3	0.9
09/27/2026 02:00	4,080.6	0.0	4,080.6	104,800.0	427.6	0.5	0.3	0.9
09/27/2026 03:00	3,836.7	0.0	3,836.7	104,800.0	402.1	0.5	0.2	0.8
09/27/2026 04:00	3,650.1	0.0	3,650.1	104,800.0	382.5	0.5	0.2	0.8
09/27/2026 05:00	3,926.3	0.0	3,926.3	104,800.0	411.5	0.5	0.2	0.8
09/27/2026 06:00	4,294.4	0.0	4,294.4	104,800.0	450.1	0.5	0.3	0.9
09/27/2026 07:00	4,295.9	0.0	4,295.9	104,800.0	450.2	0.5	0.3	0.9
09/27/2026 08:00	3,798.1	0.0	3,798.1	104,800.0	398.0	0.5	0.2	0.8
09/27/2026 09:00	3,592.6	0.0	3,592.6	104,800.0	376.5	0.5	0.2	0.8
09/27/2026 10:00	3,590.9	0.0	3,590.9	104,800.0	376.3	0.5	0.2	0.8
09/27/2026 11:00	3,588.6	0.0	3,588.6	104,800.0	376.1	0.5	0.2	0.8
09/27/2026 12:00	3,579.7	0.0	3,579.7	104,800.0	375.2	0.5	0.2	0.8
09/27/2026 13:00	3,573.6	0.0	3,573.6	104,800.0	374.5	0.5	0.2	0.8
09/27/2026 14:00	3,617.2	0.0	3,617.2	104,800.0	379.1	0.5	0.2	0.8
09/27/2026 15:00	3,779.7	0.0	3,779.7	104,800.0	396.1	0.5	0.2	0.8
09/27/2026 16:00	4,136.5	81.9	4,155.3	104,800.0	435.5	0.5	0.3	0.9
09/27/2026 17:00	4,657.2	1,187.5	5,844.7	104,800.0	612.5	0.7	0.4	1.2
09/27/2026 18:00	4,682.9	1,099.0	5,781.9	104,800.0	605.9	0.7	0.4	1.2
09/27/2026 19:00	4,706.5	1,065.9	5,772.4	104,800.0	604.9	0.7	0.4	1.2
09/27/2026 20:00	4,718.9	933.6	5,652.5	104,800.0	592.4	0.7	0.4	1.2
09/27/2026 21:00	4,723.7	363.2	5,086.9	104,800.0	533.1	0.6	0.3	1.1
09/27/2026 22:00	4,626.4	145.0	4,738.1	104,800.0	496.6	0.6	0.3	1.0
09/27/2026 23:00	4,046.5	0.0	4,046.5	104,800.0	424.1	0.5	0.3	0.8
Average/Sum#:	4,104.2	223.3	4,320.7	104,800.0	452.8	0.6	0.3	0.9
Minimum:	3,573.6	0.0	3,573.6	104,800.0	374.5	0.5	0.2	0.8
Maximum:	4,723.7	1,187.5	5,844.7	104,800.0	612.5	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/28/2026 00:00	3,984.6	0.0	3,984.6	104,800.0	417.6	0.5	0.3	0.8
09/28/2026 01:00	3,605.9	0.0	3,605.9	104,800.0	377.9	0.5	0.2	0.8
09/28/2026 02:00	3,821.9	0.0	3,821.9	104,800.0	400.5	0.5	0.2	0.8
09/28/2026 03:00	4,139.7	24.0	4,145.0	104,800.0	434.4	0.5	0.3	0.9
09/28/2026 04:00	4,775.8	48.6	4,824.4	104,800.0	505.6	0.6	0.3	1.0
09/28/2026 05:00	4,776.4	186.5	4,962.9	104,800.0	520.1	0.6	0.3	1.0
09/28/2026 06:00	4,663.0	391.1	4,964.1	104,800.0	520.2	0.6	0.3	1.1
09/28/2026 07:00	3,907.9	0.0	3,907.9	104,800.0	409.5	0.5	0.2	0.8
09/28/2026 08:00	3,592.3	0.0	3,592.3	104,800.0	376.5	0.5	0.2	0.8
09/28/2026 09:00	3,588.1	0.0	3,588.1	104,800.0	376.0	0.5	0.2	0.8
09/28/2026 10:00	3,582.5	0.0	3,582.5	104,800.0	375.4	0.5	0.2	0.8
09/28/2026 11:00	3,577.5	0.0	3,577.5	104,800.0	374.9	0.5	0.2	0.8
09/28/2026 12:00	3,574.9	0.0	3,574.9	104,800.0	374.6	0.5	0.2	0.8
09/28/2026 13:00	3,571.0	0.0	3,571.0	104,800.0	374.2	0.5	0.2	0.8
09/28/2026 14:00	3,565.5	0.0	3,565.5	104,800.0	373.7	0.5	0.2	0.7
09/28/2026 15:00	3,561.0	0.0	3,561.0	104,800.0	373.2	0.5	0.2	0.7
09/28/2026 16:00	3,574.7	0.0	3,574.7	104,800.0	374.6	0.5	0.2	0.8
09/28/2026 17:00	3,555.2	0.0	3,555.2	104,800.0	372.6	0.4	0.2	0.7
09/28/2026 18:00	3,559.2	0.0	3,559.2	104,800.0	373.0	0.4	0.2	0.7
09/28/2026 19:00	3,568.4	0.0	3,568.4	104,800.0	374.0	0.5	0.2	0.8
09/28/2026 20:00	3,572.1	0.0	3,572.1	104,800.0	374.4	0.5	0.2	0.8
09/28/2026 21:00	3,575.6	0.0	3,575.6	104,800.0	374.7	0.5	0.2	0.8
09/28/2026 22:00	3,578.7	0.0	3,578.7	104,800.0	375.0	0.5	0.2	0.8
09/28/2026 23:00	3,581.9	0.0	3,581.9	104,800.0	375.4	0.5	0.2	0.8
Average/Sum#:	3,785.6	27.1	3,808.1	104,800.0	399.1	0.5	0.2	0.8
Minimum:	3,555.2	0.0	3,555.2	104,800.0	372.6	0.4	0.2	0.7
Maximum:	4,776.4	391.1	4,964.1	104,800.0	520.2	0.6	0.3	1.1
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/29/2026 00:00	3,584.9	0.0	3,584.9	104,800.0	375.7	0.5	0.2	0.8
09/29/2026 01:00	3,584.7	0.0	3,584.7	104,800.0	375.7	0.5	0.2	0.8
09/29/2026 02:00	3,586.7	0.0	3,586.7	104,800.0	375.9	0.5	0.2	0.8
09/29/2026 03:00	3,587.0	0.0	3,587.0	104,800.0	375.9	0.5	0.2	0.8
09/29/2026 04:00	3,588.9	0.0	3,588.9	104,800.0	376.1	0.5	0.2	0.8
09/29/2026 05:00	3,591.8	0.0	3,591.8	104,800.0	376.4	0.5	0.2	0.8
09/29/2026 06:00	3,591.8	0.0	3,591.8	104,800.0	376.4	0.5	0.2	0.8
09/29/2026 07:00	3,586.5	0.0	3,586.5	104,800.0	375.9	0.5	0.2	0.8
09/29/2026 08:00	3,579.5	0.0	3,579.5	104,800.0	375.1	0.5	0.2	0.8
09/29/2026 09:00	3,569.4	0.0	3,569.4	104,800.0	374.1	0.5	0.2	0.8
09/29/2026 10:00	3,561.3	0.0	3,561.3	104,800.0	373.2	0.5	0.2	0.7
09/29/2026 11:00	3,557.7	0.0	3,557.7	104,800.0	372.8	0.5	0.2	0.7
09/29/2026 12:00	3,552.0	0.0	3,552.0	104,800.0	372.2	0.4	0.2	0.7
09/29/2026 13:00	3,544.0	0.0	3,544.0	104,800.0	371.4	0.4	0.2	0.7
09/29/2026 14:00	3,541.7	0.0	3,541.7	104,800.0	371.2	0.4	0.2	0.7
09/29/2026 15:00	3,542.7	0.0	3,542.7	104,800.0	371.3	0.4	0.2	0.7
09/29/2026 16:00	3,668.3	0.0	3,668.3	104,800.0	384.4	0.5	0.2	0.8
09/29/2026 17:00	3,566.2	0.0	3,566.2	104,800.0	373.7	0.5	0.2	0.7
09/29/2026 18:00	3,556.3	0.0	3,556.3	104,800.0	372.7	0.5	0.2	0.7
09/29/2026 19:00	3,558.9	0.0	3,558.9	104,800.0	373.0	0.5	0.2	0.7
09/29/2026 20:00	3,565.7	0.0	3,565.7	104,800.0	373.7	0.5	0.2	0.7
09/29/2026 21:00	3,567.5	0.0	3,567.5	104,800.0	373.9	0.5	0.2	0.7
09/29/2026 22:00	3,572.0	0.0	3,572.0	104,800.0	374.3	0.5	0.2	0.8
09/29/2026 23:00	4,353.6	0.0	4,353.6	104,800.0	456.3	0.5	0.3	0.9
Average/Sum#:	3,606.6	0.0	3,606.6	104,800.0	378.0	0.5	0.2	0.8
Minimum:	3,541.7	0.0	3,541.7	104,800.0	371.2	0.4	0.2	0.7
Maximum:	4,353.6	0.0	4,353.6	104,800.0	456.3	0.5	0.3	0.9
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Fuel Gas and Emissions Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:10 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:						> 4.73	> 1	> 1.8
	Unit CT2 GasFlow, _CT, 100scfh	Unit CT2 GasFlow, _DB, 100scfh	Unit CT2 GasFlowTotal, 100scfh	Unit CT2 GCVGas, BtuPer100scf	Unit CT2 HI, MBtuPerHr	Unit CT2 PM10_Norm, LbPerHr	Unit CT2 SO2_Norm, LbPerHr	Unit CT2 VOC_Norm, LbPerHr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/30/2026 00:00	3,569.3	0.0	3,569.3	104,800.0	374.1	0.5	0.2	0.7
09/30/2026 01:00	3,592.5	0.0	3,592.5	104,800.0	376.5	0.5	0.2	0.8
09/30/2026 02:00	3,805.7	0.0	3,805.7	104,800.0	398.8	0.5	0.2	0.8
09/30/2026 03:00	4,586.9	126.6	4,675.5	104,800.0	490.0	0.6	0.3	1.0
09/30/2026 04:00	4,624.1	290.9	4,915.0	104,800.0	515.1	0.6	0.3	1.0
09/30/2026 05:00	4,645.0	943.5	5,588.5	104,800.0	585.7	0.7	0.4	1.2
09/30/2026 06:00	4,326.2	417.3	4,543.2	104,800.0	476.1	0.6	0.3	1.0
09/30/2026 07:00	3,584.0	0.0	3,584.0	104,800.0	375.6	0.5	0.2	0.8
09/30/2026 08:00	3,608.4	0.0	3,608.4	104,800.0	378.2	0.5	0.2	0.8
09/30/2026 09:00	3,561.0	0.0	3,561.0	104,800.0	373.2	0.5	0.2	0.7
09/30/2026 10:00	3,696.4	0.0	3,696.4	104,800.0	387.4	0.5	0.2	0.8
09/30/2026 11:00	3,930.3	0.0	3,930.3	104,800.0	411.9	0.5	0.2	0.8
09/30/2026 12:00	4,273.9	90.6	4,294.7	104,800.0	450.1	0.5	0.3	0.9
09/30/2026 13:00	4,542.9	451.7	4,994.6	104,800.0	523.4	0.6	0.3	1.0
09/30/2026 14:00	4,524.1	1,332.3	5,856.4	104,800.0	613.8	0.7	0.4	1.2
09/30/2026 15:00	4,510.5	1,406.1	5,916.6	104,800.0	620.1	0.7	0.4	1.2
09/30/2026 16:00	4,504.7	1,341.5	5,846.2	104,800.0	612.7	0.7	0.4	1.2
09/30/2026 17:00	4,518.9	1,165.0	5,683.9	104,800.0	595.7	0.7	0.4	1.2
09/30/2026 18:00	4,268.1	758.7	5,026.8	104,800.0	526.8	0.6	0.3	1.1
09/30/2026 19:00	4,311.4	491.7	4,694.9	104,800.0	492.0	0.6	0.3	1.0
09/30/2026 20:00	4,385.1	120.1	4,412.7	104,800.0	462.5	0.6	0.3	0.9
09/30/2026 21:00	4,440.1	551.2	4,991.3	104,800.0	523.1	0.6	0.3	1.0
09/30/2026 22:00	3,799.2	2.7	3,799.3	104,800.0	398.2	0.5	0.2	0.8
09/30/2026 23:00	3,861.6	0.0	3,861.6	104,800.0	404.7	0.5	0.2	0.8
Average/Sum#:	4,144.6	395.4	4,518.7	104,800.0	473.6	0.6	0.3	0.9
Minimum:	3,561.0	0.0	3,561.0	104,800.0	373.2	0.5	0.2	0.7
Maximum:	4,645.0	1,406.1	5,916.6	104,800.0	620.1	0.7	0.4	1.2
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00