DOCKETED	
Docket Number:	03-AFC-01C
Project Title:	Roseville Energy Park Compliance
TN #:	273241
Document Title:	Roseville Energy Park Quarterly Air Quality Report - Q3 2026 - Part 11s
Description:	N/A
Filer:	Roseville Electric Compliance
Organization:	Roseville Electric
Submitter Role:	Public Agency
Submission Date:	10/28/2026 7:52:54 AM
Docketed Date:	10/28/2026

Monthly Summary By Day Report

Unit CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:54 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
07/01/2026	16.31	53.72	5.1	11.57	19.27
07/02/2026	16.00	52.40	4.9	11.35	18.87
07/03/2026	16.13	52.57	4.8	11.30	18.92
07/04/2026	16.74	55.45	5.8	12.03	20.04
07/05/2026	16.41	54.72	5.4	11.71	19.55
07/06/2026	16.70	55.47	5.8	11.87	19.75
07/07/2026	16.85	57.83	6.4	12.39	20.67
07/08/2026	16.19	51.82	5.0	11.18	18.57
07/09/2026	16.28	53.33	5.5	11.52	19.17
07/10/2026	17.95	57.92	5.8	12.52	20.87
07/11/2026	20.18	60.68	6.1	13.19	21.99
07/12/2026	16.38	75.70	8.1	16.29	27.16
07/13/2026	11.83	75.95	8.4	16.55	27.62
07/14/2026	14.49	75.74	8.1	16.48	27.45
07/15/2026	13.67	77.86	8.4	16.88	28.10
07/16/2026	18.70	71.75	7.2	15.39	25.66
07/17/2026	22.54	70.19	7.2	15.23	25.38
07/18/2026	28.71	68.41	7.0	14.77	24.60
07/19/2026	19.78	74.77	7.9	16.14	26.91
07/20/2026	10.33	82.58	9.1	17.83	29.73
07/21/2026	12.13	79.71	8.6	17.31	28.86
07/22/2026	23.62	70.33	7.2	15.25	25.43
07/23/2026	25.23	68.34	7.0	14.79	24.65
07/24/2026	26.29	72.26	7.7	15.68	26.13
07/25/2026	23.96	70.70	7.2	15.31	25.55
07/26/2026	21.52	70.75	7.1	15.23	25.36
07/27/2026	25.00	71.12	7.4	15.39	25.71
07/28/2026	24.54	62.99	6.4	13.66	22.79
07/29/2026	12.92	60.65	5.8	12.92	21.57
07/30/2026	16.67	51.75	5.1	11.11	18.53
07/31/2026	17.36	60.63	6.1	13.04	21.73
Monthly Avg/Sum:	571.41 sum	2,018.09 sum	207.6 sum	435.88 sum	726.59 sum
Daily Min:	10.33	51.75	4.8	11.11	18.53
Daily Max:	28.71	82.58	9.1	17.83	29.73
Jul 2026 - Jul 2026	571.41 sum	2,018.09 sum	207.6 sum	435.88 sum	726.59 sum
QTD:	571.41 sum	2,018.09 sum	207.6 sum	435.88 sum	726.59 sum
YTD 2026:	2,397.73 sum	4,637.84 sum	450.6 sum	950.45 sum	1,584.35 sum

Monthly Summary By Day Report

Unit CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:54 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
08/01/2026	16.71	59.00	6.0	12.75	21.22
08/02/2026	18.94	58.88	5.8	12.57	20.99
08/03/2026	16.86	61.53	6.5	13.30	22.14
08/04/2026	17.45	60.34	6.2	13.01	21.74
08/05/2026	18.82	59.02	5.9	12.73	21.22
08/06/2026	14.97	60.40	6.0	12.97	21.61
08/07/2026	16.22	62.81	6.5	13.52	22.53
08/08/2026	16.33	60.05	6.1	12.96	21.65
08/09/2026	14.93	60.31	6.2	13.02	21.73
08/10/2026	16.79	59.90	6.2	12.93	21.58
08/11/2026	16.19	62.79	6.6	13.47	22.50
08/12/2026	20.75	57.96	5.7	12.41	20.74
08/13/2026	19.30	55.88	5.4	11.95	20.01
08/14/2026	17.57	51.07	4.8	10.94	18.28
08/15/2026	17.65	52.31	5.1	11.25	18.80
08/16/2026	21.51	58.65	5.9	12.63	21.13
08/17/2026	18.37	59.63	5.9	12.79	21.29
08/18/2026	16.27	59.71	6.0	12.86	21.44
08/19/2026	15.11	61.83	6.4	13.25	22.14
08/20/2026	15.54	61.49	6.4	13.30	22.23
08/21/2026	17.79	60.38	6.0	12.99	21.70
08/22/2026	19.09	58.56	5.7	12.50	20.91
08/23/2026	17.32	61.94	6.4	13.27	22.19
08/24/2026	16.02	65.16	7.0	14.06	23.45
08/25/2026	17.61	62.04	6.5	13.36	22.33
08/26/2026	16.74	60.92	6.3	13.21	22.07
08/27/2026	18.76	64.31	6.9	13.87	23.16
08/28/2026	22.59	73.38	7.5	15.84	26.41
08/29/2026	32.89	70.25	7.2	15.17	25.23
08/30/2026	31.81	70.16	7.2	15.18	25.33
08/31/2026	30.54	61.84	6.3	13.32	22.29
Monthly Avg/Sum:	587.44 sum	1,892.50 sum	192.6 sum	407.38 sum	680.04 sum
Daily Min:	14.93	51.07	4.8	10.94	18.28
Daily Max:	32.89	73.38	7.5	15.84	26.41
Jul 2026 - Aug 2026	1,158.85 sum	3,910.59 sum	400.2 sum	843.26 sum	1,406.63 sum
QTD:	1,158.85 sum	3,910.59 sum	400.2 sum	843.26 sum	1,406.63 sum
YTD 2026:	2,985.17 sum	6,530.34 sum	643.2 sum	1,357.83 sum	2,264.39 sum

Monthly Summary By Day Report

Unit CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 14:54 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Limit Value:

	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)	Unit CT2 PM10, Lb 1 Hour(s)	Unit CT2 VOC, Lb 1 Hour(s)
09/01/2026	19.03	50.74	4.8	10.86	18.13
09/02/2026	18.93	50.70	4.8	10.83	18.16
09/03/2026	19.78	55.10	5.7	11.80	19.68
09/04/2026	19.12	53.76	5.4	11.60	19.33
09/05/2026	19.16	52.45	5.0	11.19	18.64
09/06/2026	19.41	51.17	4.8	10.98	18.29
09/07/2026	20.53	52.55	5.3	11.38	19.01
09/08/2026	18.83	65.07	7.1	14.09	23.46
09/09/2026	15.97	75.88	8.3	16.32	27.17
09/10/2026	22.33	61.19	6.4	13.32	22.22
09/11/2026	19.76	50.82	4.9	10.94	18.18
09/12/2026	19.65	50.12	4.8	10.77	17.95
09/13/2026	20.51	51.27	5.0	10.99	18.31
09/14/2026	21.47	50.74	4.9	10.97	18.23
09/15/2026	21.22	54.92	5.9	11.85	19.72
09/16/2026	58.18	41.03	3.3	7.28	12.18
09/17/2026	13.36	51.40	4.9	10.92	18.28
09/18/2026	13.73	51.67	5.1	11.02	18.44
09/19/2026	13.80	50.76	4.8	10.87	18.11
09/20/2026	13.89	51.95	5.1	11.13	18.56
09/21/2026	13.46	52.07	5.1	11.12	18.54
09/22/2026	14.62	52.25	5.0	11.11	18.60
09/23/2026	14.25	51.72	5.0	11.12	18.61
09/24/2026	14.55	53.33	5.4	11.47	19.11
09/25/2026	13.69	50.60	4.8	10.86	18.06
09/26/2026	13.73	54.70	5.6	11.71	19.50
09/27/2026	15.98	60.42	6.5	13.05	21.74
09/28/2026	18.44	53.41	5.3	11.49	19.18
09/29/2026	14.71	50.27	4.9	10.91	18.14
09/30/2026	17.14	63.54	6.7	13.64	22.74
Monthly Avg/Sum:	559.23 sum	1,615.60 sum	160.6 sum	345.59 sum	576.27 sum
Daily Min:	13.36	41.03	3.3	7.28	12.18
Daily Max:	58.18	75.88	8.3	16.32	27.17
Jul 2026 - Sep 2026	1,718.08 sum	5,526.19 sum	560.8 sum	1,188.85 sum	1,982.90 sum
QTD:	1,718.08 sum	5,526.19 sum	560.8 sum	1,188.85 sum	1,982.90 sum
YTD 2026:	3,544.40 sum	8,145.94 sum	803.8 sum	1,703.42 sum	2,840.66 sum

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/01/2026 00:00	-1	1.7	8.5	14.3	7.0	810,035.3	0.00	1.00
07/01/2026 01:00	-2	1.7	8.8	14.3	6.9	810,657.7	0.00	1.00
07/01/2026 02:00	-2	1.7	9.0	14.3	6.7	809,827.8	0.00	1.00
07/01/2026 03:00	-2	1.7	9.0	14.3	6.5	809,827.8	0.00	1.00
07/01/2026 04:00	-2	1.7	8.9	14.3	6.4	808,167.9	0.00	1.00
07/01/2026 05:00	-1	1.7	8.8	14.3	7.0	808,375.4	0.00	1.00
07/01/2026 06:00	-1	1.7	8.7	14.3	8.0	807,130.4	0.00	1.00
07/01/2026 07:00	-1	1.7	8.7	14.3	8.2	809,412.8	0.00	1.00
07/01/2026 08:00	0	1.7	8.6	14.3	9.3	808,582.9	0.00	1.00
07/01/2026 09:00	0	1.7	8.4	14.4	9.0	820,811.9	0.00	1.00
07/01/2026 10:00	-1	1.7	8.3	14.4	8.8	816,176.9	0.00	1.00
07/01/2026 11:00	-1	1.7	8.3	14.4	8.5	816,598.3	0.00	1.00
07/01/2026 12:00	-1	1.6	8.3	14.4	8.2	818,915.8	0.00	1.00
07/01/2026 13:00	-1	1.6	8.3	14.5	8.6	830,855.5	0.00	1.00
07/01/2026 14:00	0	1.6	8.3	14.5	9.3	830,855.5	0.00	1.00
07/01/2026 15:00	-1	1.6	8.4	14.5	9.3	831,069.4	0.00	1.00
07/01/2026 16:00	-1	1.6	8.2	14.5	8.8	848,401.2	0.00	1.00
07/01/2026 17:00	-1	1.6	7.8	14.4	8.1	864,001.4	0.00	1.00
07/01/2026 18:00	0	1.7	7.7	14.4	9.7	921,517.3	0.00	1.00
07/01/2026 19:00	0	1.7	7.7	14.4	11.1	963,021.4	0.00	1.00
07/01/2026 20:00	0	1.7	8.1	14.3	10.5	904,235.1	0.00	1.00
07/01/2026 21:00	-1	1.7	8.4	14.3	8.9	826,219.4	0.00	1.00
07/01/2026 22:00	-1	1.7	8.6	14.3	7.8	830,161.7	0.00	1.00
07/01/2026 23:00	-1	1.7	8.5	14.4	7.8	871,375.3	0.00	1.00
Average/Sum#:	-1	1.7	8.4	14.4	8.4	836,509.8	0.00 #	24.00 #
Minimum:	-2	1.6	7.7	14.3	6.4	807,130.4	0.00	1.00
Maximum:	0	1.7	9.0	14.5	11.1	963,021.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/02/2026 00:00	-2	1.7	8.7	14.3	6.3	806,093.0	0.00	1.00
07/02/2026 01:00	-2	1.7	8.8	14.3	6.2	804,640.6	0.00	1.00
07/02/2026 02:00	-2	1.7	9.0	14.3	6.0	804,433.1	0.00	1.00
07/02/2026 03:00	-2	1.7	8.9	14.3	5.5	804,018.1	0.00	1.00
07/02/2026 04:00	-2	1.7	8.8	14.3	5.4	814,807.5	0.00	1.00
07/02/2026 05:00	-2	1.7	8.9	14.2	5.9	793,857.4	0.00	1.00
07/02/2026 06:00	-2	1.7	8.8	14.3	6.3	805,470.5	0.00	1.00
07/02/2026 07:00	-2	1.7	8.7	14.3	6.6	805,263.0	0.00	1.00
07/02/2026 08:00	0	1.7	8.7	14.3	9.1	805,885.5	0.00	1.00
07/02/2026 09:00	0	1.7	8.7	14.3	9.7	806,922.9	0.00	1.00
07/02/2026 10:00	-1	1.7	8.5	14.4	8.7	816,176.9	0.00	1.00
07/02/2026 11:00	-1	1.7	8.3	14.4	7.9	812,595.4	0.00	1.00
07/02/2026 12:00	-1	1.7	8.3	14.4	7.7	811,331.3	0.00	1.00
07/02/2026 13:00	-1	1.6	8.3	14.4	7.3	812,806.0	0.00	1.00
07/02/2026 14:00	-1	1.6	8.3	14.5	8.2	826,362.0	0.00	1.00
07/02/2026 15:00	-1	1.6	8.3	14.5	8.4	827,003.9	0.00	1.00
07/02/2026 16:00	-1	1.6	8.3	14.5	8.3	827,217.9	0.00	1.00
07/02/2026 17:00	-1	1.6	8.3	14.5	9.2	857,602.0	0.00	1.00
07/02/2026 18:00	-1	1.6	8.3	14.4	8.3	812,174.0	0.00	1.00
07/02/2026 19:00	0	1.7	8.2	14.4	9.0	809,224.5	0.00	1.00
07/02/2026 20:00	-1	1.7	8.2	14.4	8.5	813,016.7	0.00	1.00
07/02/2026 21:00	-1	1.7	8.1	14.4	7.9	813,438.1	0.00	1.00
07/02/2026 22:00	-1	1.7	8.0	14.3	6.8	811,072.7	0.00	1.00
07/02/2026 23:00	-1	1.6	8.1	14.4	8.5	935,843.6	0.00	1.00
Average/Sum#:	-1	1.7	8.5	14.4	7.6	818,219.0	0.00 #	24.00 #
Minimum:	-2	1.6	8.0	14.2	5.4	793,857.4	0.00	1.00
Maximum:	0	1.7	9.0	14.5	9.7	935,843.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/03/2026 00:00	-2	1.7	8.4	14.3	5.9	814,600.0	0.00	1.00
07/03/2026 01:00	-2	1.7	8.4	14.3	5.2	783,476.7	0.00	1.00
07/03/2026 02:00	-2	1.7	8.7	14.3	5.0	779,534.5	0.00	1.00
07/03/2026 03:00	-2	1.7	8.7	14.3	4.9	779,327.0	0.00	1.00
07/03/2026 04:00	-2	1.7	8.7	14.3	5.7	807,337.9	0.00	1.00
07/03/2026 05:00	-2	1.7	8.8	14.2	6.6	799,171.5	0.00	1.00
07/03/2026 06:00	-1	1.7	8.7	14.3	8.3	813,355.1	0.00	1.00
07/03/2026 07:00	-1	1.7	8.7	14.3	8.5	814,185.0	0.00	1.00
07/03/2026 08:00	0	1.7	8.7	14.3	9.3	816,052.4	0.00	1.00
07/03/2026 09:00	-1	1.7	8.4	14.4	8.2	822,286.7	0.00	1.00
07/03/2026 10:00	-1	1.7	8.3	14.4	8.2	821,022.6	0.00	1.00
07/03/2026 11:00	-1	1.7	8.4	14.4	7.9	822,076.0	0.00	1.00
07/03/2026 12:00	-1	1.6	8.4	14.5	7.9	835,990.8	0.00	1.00
07/03/2026 13:00	-1	1.6	8.4	14.5	8.8	836,632.7	0.00	1.00
07/03/2026 14:00	0	1.6	8.4	14.5	9.8	835,990.8	0.00	1.00
07/03/2026 15:00	-1	1.6	8.2	14.5	9.0	835,562.8	0.00	1.00
07/03/2026 16:00	-1	1.6	8.0	14.5	9.2	864,663.1	0.00	1.00
07/03/2026 17:00	-1	1.6	7.8	14.4	7.5	859,787.8	0.00	1.00
07/03/2026 18:00	-1	1.7	7.9	14.3	7.6	809,412.8	0.00	1.00
07/03/2026 19:00	0	1.7	8.0	14.3	8.3	814,392.5	0.00	1.00
07/03/2026 20:00	0	1.7	8.0	14.3	8.6	812,317.6	0.00	1.00
07/03/2026 21:00	0	1.7	7.9	14.3	8.0	812,940.1	0.00	1.00
07/03/2026 22:00	-1	1.7	8.3	14.3	8.4	810,657.7	0.00	1.00
07/03/2026 23:00	-1	1.7	8.2	14.4	7.6	846,304.3	0.00	1.00
Average/Sum#:	-1	1.7	8.4	14.4	7.7	818,628.3	0.00 #	24.00 #
Minimum:	-2	1.6	7.8	14.2	4.9	779,327.0	0.00	1.00
Maximum:	0	1.7	8.8	14.5	9.8	864,663.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/04/2026 00:00	-1	1.6	8.1	14.5	9.0	952,819.8	0.00	1.00
07/04/2026 01:00	-1	1.7	8.4	14.3	6.7	809,620.3	0.00	1.00
07/04/2026 02:00	-2	1.7	8.7	14.3	6.2	785,759.1	0.00	1.00
07/04/2026 03:00	-2	1.7	8.7	14.3	5.2	778,704.5	0.00	1.00
07/04/2026 04:00	-2	1.7	8.7	14.3	5.1	780,156.9	0.00	1.00
07/04/2026 05:00	-1	1.7	9.1	14.4	8.8	926,995.0	0.00	1.00
07/04/2026 06:00	-1	1.7	8.5	14.4	9.4	917,514.3	0.00	1.00
07/04/2026 07:00	-1	1.7	8.6	14.3	9.1	835,348.9	0.00	1.00
07/04/2026 08:00	-1	1.7	8.3	14.3	8.5	808,375.4	0.00	1.00
07/04/2026 09:00	-1	1.7	8.2	14.4	8.3	820,601.2	0.00	1.00
07/04/2026 10:00	-1	1.7	8.3	14.4	8.6	822,497.4	0.00	1.00
07/04/2026 11:00	-1	1.7	8.2	14.4	7.9	818,283.7	0.00	1.00
07/04/2026 12:00	-1	1.6	8.3	14.5	7.9	828,287.8	0.00	1.00
07/04/2026 13:00	-1	1.6	8.2	14.5	8.4	828,287.8	0.00	1.00
07/04/2026 14:00	0	1.6	8.1	14.5	9.3	834,920.9	0.00	1.00
07/04/2026 15:00	0	1.6	7.6	14.5	10.6	969,723.6	0.00	1.00
07/04/2026 16:00	0	1.6	7.6	14.5	10.4	981,492.1	0.00	1.00
07/04/2026 17:00	0	1.6	7.7	14.5	10.3	968,653.8	0.00	1.00
07/04/2026 18:00	0	1.6	8.0	14.4	9.9	915,196.8	0.00	1.00
07/04/2026 19:00	1	1.7	9.8	13.9	16.5	1,000,658.0	0.00	1.00
07/04/2026 20:00	0	1.7	9.3	14.0	13.4	926,643.8	0.00	1.00
07/04/2026 21:00	0	1.7	7.9	14.3	7.9	782,854.3	0.00	1.00
07/04/2026 22:00	0	1.7	8.0	14.3	8.0	816,674.9	0.00	1.00
07/04/2026 23:00	-1	1.7	7.8	14.4	9.0	923,413.4	0.00	1.00
Average/Sum#:	-1	1.7	8.3	14.4	8.9	868,061.8	0.00 #	24.00 #
Minimum:	-2	1.6	7.6	13.9	5.1	778,704.5	0.00	1.00
Maximum:	1	1.7	9.8	14.5	16.5	1,000,658.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/05/2026 00:00	-1	1.7	8.1	14.3	8.2	851,533.0	0.00	1.00
07/05/2026 01:00	-1	1.7	8.5	14.2	7.2	803,055.0	0.00	1.00
07/05/2026 02:00	-1	1.7	9.1	14.3	7.2	817,504.9	0.00	1.00
07/05/2026 03:00	-2	1.7	9.0	14.3	6.7	815,015.0	0.00	1.00
07/05/2026 04:00	-2	1.7	8.9	14.3	6.1	816,882.4	0.00	1.00
07/05/2026 05:00	-2	1.6	8.4	14.4	6.7	910,140.5	0.00	1.00
07/05/2026 06:00	-1	1.7	8.7	14.3	7.6	849,043.1	0.00	1.00
07/05/2026 07:00	-2	1.7	8.7	14.3	6.3	815,637.5	0.00	1.00
07/05/2026 08:00	-1	1.7	8.7	14.3	8.4	812,732.6	0.00	1.00
07/05/2026 09:00	-1	1.7	8.5	14.3	8.2	789,908.9	0.00	1.00
07/05/2026 10:00	-1	1.7	8.4	14.4	8.1	802,693.4	0.00	1.00
07/05/2026 11:00	-1	1.7	8.3	14.4	7.7	800,165.2	0.00	1.00
07/05/2026 12:00	-1	1.7	8.3	14.4	7.7	794,266.1	0.00	1.00
07/05/2026 13:00	-1	1.6	8.1	14.5	7.1	804,322.9	0.00	1.00
07/05/2026 14:00	-1	1.6	8.1	14.5	8.2	802,825.0	0.00	1.00
07/05/2026 15:00	-1	1.6	8.1	14.5	8.0	805,178.7	0.00	1.00
07/05/2026 16:00	-1	1.6	8.0	14.5	7.6	812,453.8	0.00	1.00
07/05/2026 17:00	0	1.7	7.6	14.5	10.1	983,417.9	0.00	1.00
07/05/2026 18:00	0	1.7	7.7	14.4	10.5	966,392.3	0.00	1.00
07/05/2026 19:00	0	1.7	7.9	14.4	11.2	964,285.4	0.00	1.00
07/05/2026 20:00	0	1.7	7.9	14.4	10.9	964,074.8	0.00	1.00
07/05/2026 21:00	0	1.7	7.8	14.4	10.3	964,074.8	0.00	1.00
07/05/2026 22:00	-1	1.7	8.2	14.3	8.2	838,461.2	0.00	1.00
07/05/2026 23:00	-1	1.7	8.3	14.3	6.8	796,963.5	0.00	1.00
Average/Sum#:	-1	1.7	8.3	14.4	8.1	849,209.5	0.00 #	24.00 #
Minimum:	-2	1.6	7.6	14.2	6.1	789,908.9	0.00	1.00
Maximum:	0	1.7	9.1	14.5	11.2	983,417.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/06/2026 00:00	-2	1.7	8.5	14.3	6.2	801,528.2	0.00	1.00
07/06/2026 01:00	-2	1.7	8.5	14.3	5.1	788,249.0	0.00	1.00
07/06/2026 02:00	-2	1.7	8.9	14.2	4.9	776,279.7	0.00	1.00
07/06/2026 03:00	-2	1.7	8.8	14.2	4.7	776,484.1	0.00	1.00
07/06/2026 04:00	-2	1.7	8.5	14.3	5.4	860,455.0	0.00	1.00
07/06/2026 05:00	-2	1.7	8.7	14.2	6.0	814,296.5	0.00	1.00
07/06/2026 06:00	-1	1.7	8.6	14.2	6.6	774,440.1	0.00	1.00
07/06/2026 07:00	-1	1.7	8.5	14.3	6.7	786,174.1	0.00	1.00
07/06/2026 08:00	0	1.7	8.5	14.3	8.9	787,004.0	0.00	1.00
07/06/2026 09:00	0	1.7	8.5	14.3	8.9	789,493.9	0.00	1.00
07/06/2026 10:00	-1	1.7	8.4	14.4	8.4	801,850.6	0.00	1.00
07/06/2026 11:00	-1	1.7	8.4	14.4	8.0	799,743.8	0.00	1.00
07/06/2026 12:00	-1	1.7	8.5	14.4	8.0	794,266.1	0.00	1.00
07/06/2026 13:00	-1	1.7	8.2	14.5	8.3	840,912.2	0.00	1.00
07/06/2026 14:00	0	1.6	8.2	14.5	9.7	838,130.5	0.00	1.00
07/06/2026 15:00	0	1.6	8.4	14.6	10.8	901,429.0	0.00	1.00
07/06/2026 16:00	-1	1.6	8.4	14.6	10.5	922,948.6	0.00	1.00
07/06/2026 17:00	-1	1.7	7.9	14.4	8.7	884,016.1	0.00	1.00
07/06/2026 18:00	0	1.7	7.9	14.5	11.2	986,627.5	0.00	1.00
07/06/2026 19:00	0	1.7	7.8	14.4	11.2	972,712.7	0.00	1.00
07/06/2026 20:00	0	1.7	7.8	14.4	10.3	971,448.6	0.00	1.00
07/06/2026 21:00	-1	1.7	7.8	14.4	9.3	971,870.0	0.00	1.00
07/06/2026 22:00	-1	1.7	7.9	14.4	8.0	970,184.5	0.00	1.00
07/06/2026 23:00	-1	1.7	8.0	14.4	7.7	968,077.7	0.00	1.00
Average/Sum#:	-1	1.7	8.3	14.4	8.1	857,442.6	0.00 #	24.00 #
Minimum:	-2	1.6	7.8	14.2	4.7	774,440.1	0.00	1.00
Maximum:	0	1.7	8.9	14.6	11.2	986,627.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/07/2026 00:00	-2	1.7	8.1	14.4	7.2	966,392.3	0.00	1.00
07/07/2026 01:00	-2	1.6	8.3	14.4	6.7	939,214.4	0.00	1.00
07/07/2026 02:00	-2	1.8	8.4	14.4	6.6	964,074.8	0.00	1.00
07/07/2026 03:00	-2	1.7	8.4	14.4	6.9	964,496.1	0.00	1.00
07/07/2026 04:00	-2	1.7	8.3	14.4	6.8	967,445.7	0.00	1.00
07/07/2026 05:00	-2	1.7	8.5	14.3	6.6	886,391.1	0.00	1.00
07/07/2026 06:00	-2	1.7	8.5	14.2	5.3	778,323.6	0.00	1.00
07/07/2026 07:00	-2	1.7	8.4	14.2	4.9	778,119.2	0.00	1.00
07/07/2026 08:00	-1	1.7	8.4	14.3	7.5	790,531.3	0.00	1.00
07/07/2026 09:00	-1	1.7	8.3	14.3	7.9	791,361.3	0.00	1.00
07/07/2026 10:00	-1	1.7	8.3	14.3	7.8	791,153.8	0.00	1.00
07/07/2026 11:00	-1	1.7	8.0	14.5	8.6	898,470.8	0.00	1.00
07/07/2026 12:00	-1	1.6	8.3	14.4	8.5	856,416.9	0.00	1.00
07/07/2026 13:00	-1	1.7	8.2	14.5	8.9	878,143.4	0.00	1.00
07/07/2026 14:00	-1	1.6	8.1	14.6	9.6	953,597.6	0.00	1.00
07/07/2026 15:00	-1	1.6	8.3	14.5	9.7	884,990.5	0.00	1.00
07/07/2026 16:00	0	1.7	8.2	14.5	10.2	892,479.5	0.00	1.00
07/07/2026 17:00	-1	1.6	8.1	14.6	10.1	938,816.5	0.00	1.00
07/07/2026 18:00	0	1.6	7.9	14.6	10.8	986,637.7	0.00	1.00
07/07/2026 19:00	0	1.6	7.9	14.5	10.7	975,500.9	0.00	1.00
07/07/2026 20:00	-1	1.6	8.0	14.5	9.6	972,933.2	0.00	1.00
07/07/2026 21:00	-1	1.7	8.1	14.4	8.4	954,383.5	0.00	1.00
07/07/2026 22:00	-1	1.7	8.2	14.4	7.9	954,172.8	0.00	1.00
07/07/2026 23:00	-1	1.7	8.5	14.3	7.7	913,364.6	0.00	1.00
Average/Sum#:	-1	1.7	8.2	14.4	8.1	903,225.5	0.00 #	24.00 #
Minimum:	-2	1.6	7.9	14.2	4.9	778,119.2	0.00	1.00
Maximum:	0	1.8	8.5	14.6	10.8	986,637.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/08/2026 00:00	-1	1.7	8.1	14.4	7.6	960,493.2	0.00	1.00
07/08/2026 01:00	-2	1.6	8.7	14.2	5.9	802,646.2	0.00	1.00
07/08/2026 02:00	-2	1.7	9.0	14.2	5.4	770,965.5	0.00	1.00
07/08/2026 03:00	-2	1.7	8.9	14.2	5.2	771,169.9	0.00	1.00
07/08/2026 04:00	-2	1.7	8.9	14.2	5.5	771,578.7	0.00	1.00
07/08/2026 05:00	-2	1.7	8.8	14.2	6.3	773,827.0	0.00	1.00
07/08/2026 06:00	-1	1.7	8.7	14.2	7.5	783,024.6	0.00	1.00
07/08/2026 07:00	-1	1.7	8.6	14.2	7.0	772,600.6	0.00	1.00
07/08/2026 08:00	0	1.7	8.5	14.3	8.9	786,381.6	0.00	1.00
07/08/2026 09:00	-1	1.7	8.4	14.3	8.2	788,664.0	0.00	1.00
07/08/2026 10:00	-1	1.7	8.4	14.3	7.9	787,004.0	0.00	1.00
07/08/2026 11:00	-1	1.7	8.3	14.4	7.4	796,794.3	0.00	1.00
07/08/2026 12:00	-1	1.7	8.2	14.4	6.9	797,637.0	0.00	1.00
07/08/2026 13:00	-1	1.7	8.0	14.4	7.1	798,901.1	0.00	1.00
07/08/2026 14:00	-1	1.7	7.9	14.4	8.0	798,479.8	0.00	1.00
07/08/2026 15:00	-1	1.6	8.0	14.5	8.1	805,820.7	0.00	1.00
07/08/2026 16:00	-1	1.6	8.0	14.5	7.3	804,108.9	0.00	1.00
07/08/2026 17:00	-1	1.7	8.1	14.5	8.6	863,379.3	0.00	1.00
07/08/2026 18:00	-1	1.6	8.2	14.5	9.2	886,274.3	0.00	1.00
07/08/2026 19:00	-1	1.7	8.3	14.4	7.9	797,847.7	0.00	1.00
07/08/2026 20:00	-1	1.7	8.3	14.4	8.4	797,426.4	0.00	1.00
07/08/2026 21:00	-1	1.7	8.3	14.3	7.6	784,929.2	0.00	1.00
07/08/2026 22:00	-1	1.7	8.4	14.3	7.3	782,854.3	0.00	1.00
07/08/2026 23:00	-1	1.7	8.4	14.3	6.8	780,986.9	0.00	1.00
Average/Sum#:	-1	1.7	8.4	14.3	7.3	802,658.1	0.00 #	24.00 #
Minimum:	-2	1.6	7.9	14.2	5.2	770,965.5	0.00	1.00
Maximum:	0	1.7	9.0	14.5	9.2	960,493.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/09/2026 00:00	-1	1.7	8.4	14.3	6.3	780,779.4	0.00	1.00
07/09/2026 01:00	-2	1.7	8.5	14.3	5.6	780,571.9	0.00	1.00
07/09/2026 02:00	-2	1.7	8.8	14.3	4.9	779,949.4	0.00	1.00
07/09/2026 03:00	-2	1.7	8.7	14.3	5.0	785,759.1	0.00	1.00
07/09/2026 04:00	-2	1.7	8.6	14.3	5.2	825,181.9	0.00	1.00
07/09/2026 05:00	-2	1.7	8.7	14.3	6.9	833,896.5	0.00	1.00
07/09/2026 06:00	-1	1.7	8.6	14.3	7.4	787,419.0	0.00	1.00
07/09/2026 07:00	-1	1.7	8.5	14.3	7.8	788,249.0	0.00	1.00
07/09/2026 08:00	-1	1.7	8.5	14.3	6.7	785,759.1	0.00	1.00
07/09/2026 09:00	-1	1.7	8.4	14.4	7.5	794,898.2	0.00	1.00
07/09/2026 10:00	-1	1.7	8.3	14.4	7.7	794,687.5	0.00	1.00
07/09/2026 11:00	-1	1.7	8.0	14.4	6.8	796,583.6	0.00	1.00
07/09/2026 12:00	-1	1.6	7.8	14.5	7.1	806,890.5	0.00	1.00
07/09/2026 13:00	0	1.7	8.1	14.5	9.3	837,060.7	0.00	1.00
07/09/2026 14:00	0	1.6	8.0	14.5	8.8	804,750.8	0.00	1.00
07/09/2026 15:00	0	1.6	7.8	14.5	8.2	793,624.2	0.00	1.00
07/09/2026 16:00	-1	1.6	7.7	14.5	8.3	861,239.6	0.00	1.00
07/09/2026 17:00	-1	1.7	7.5	14.4	7.7	881,909.3	0.00	1.00
07/09/2026 18:00	0	1.6	7.5	14.5	9.7	981,706.1	0.00	1.00
07/09/2026 19:00	0	1.6	7.6	14.5	10.2	978,496.5	0.00	1.00
07/09/2026 20:00	0	1.6	8.2	14.5	10.6	908,313.5	0.00	1.00
07/09/2026 21:00	0	1.7	8.0	14.5	10.3	906,815.7	0.00	1.00
07/09/2026 22:00	0	1.6	8.1	14.5	10.3	912,593.0	0.00	1.00
07/09/2026 23:00	-1	1.6	8.1	14.5	9.4	900,396.5	0.00	1.00
Average/Sum#:	-1	1.7	8.2	14.4	7.8	837,813.8	0.00 #	24.00 #
Minimum:	-2	1.6	7.5	14.3	4.9	779,949.4	0.00	1.00
Maximum:	0	1.7	8.8	14.5	10.6	981,706.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/10/2026 00:00	-1	1.7	8.2	14.4	8.4	837,666.4	0.00	1.00
07/10/2026 01:00	-1	1.7	8.4	14.3	7.4	796,756.0	0.00	1.00
07/10/2026 02:00	-2	1.6	8.8	14.3	6.7	790,531.3	0.00	1.00
07/10/2026 03:00	-1	1.7	8.3	14.4	7.7	940,899.9	0.00	1.00
07/10/2026 04:00	-2	1.6	8.4	14.4	6.5	887,387.0	0.00	1.00
07/10/2026 05:00	-1	1.7	8.5	14.4	7.4	889,915.2	0.00	1.00
07/10/2026 06:00	-1	1.7	8.5	14.3	7.4	792,191.3	0.00	1.00
07/10/2026 07:00	-1	1.7	8.4	14.3	8.3	791,568.8	0.00	1.00
07/10/2026 08:00	-1	1.7	8.4	14.4	8.7	803,746.8	0.00	1.00
07/10/2026 09:00	-1	1.7	8.3	14.4	8.6	801,640.0	0.00	1.00
07/10/2026 10:00	-1	1.7	8.3	14.4	8.6	797,637.0	0.00	1.00
07/10/2026 11:00	-1	1.7	8.1	14.4	7.6	797,215.7	0.00	1.00
07/10/2026 12:00	-1	1.7	7.9	14.5	7.2	808,816.3	0.00	1.00
07/10/2026 13:00	-1	1.6	7.8	14.5	7.2	806,248.6	0.00	1.00
07/10/2026 14:00	-1	1.6	7.8	14.5	7.8	804,536.8	0.00	1.00
07/10/2026 15:00	-1	1.6	7.9	14.5	8.7	831,497.4	0.00	1.00
07/10/2026 16:00	-1	1.6	8.0	14.5	8.3	862,737.4	0.00	1.00
07/10/2026 17:00	1	1.8	9.7	13.8	16.7	984,249.7	0.00	1.00
07/10/2026 18:00	2	1.9	11.5	13.2	20.3	988,475.4	0.00	1.00
07/10/2026 19:00	2	1.9	11.3	13.4	20.1	997,671.3	0.00	1.00
07/10/2026 20:00	1	1.8	10.1	13.9	17.4	1,026,285.8	0.00	1.00
07/10/2026 21:00	1	1.8	10.1	13.9	16.9	1,020,416.8	0.00	1.00
07/10/2026 22:00	1	1.8	10.1	14.0	16.3	1,032,823.8	0.00	1.00
07/10/2026 23:00	0	1.7	9.9	14.1	15.5	1,045,394.4	0.00	1.00
Average/Sum#:	0	1.7	8.9	14.2	10.7	880,679.5	0.00 #	24.00 #
Minimum:	-2	1.6	7.8	13.2	6.5	790,531.3	0.00	1.00
Maximum:	2	1.9	11.5	14.5	20.3	1,045,394.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/11/2026 00:00	0	1.7	9.9	14.1	14.9	1,042,776.4	0.00	1.00
07/11/2026 01:00	0	1.7	9.8	14.1	14.1	1,039,554.2	0.00	1.00
07/11/2026 02:00	-1	1.7	10.2	14.1	13.6	1,035,929.3	0.00	1.00
07/11/2026 03:00	-1	1.7	10.0	14.2	13.3	1,049,551.4	0.00	1.00
07/11/2026 04:00	-1	1.7	9.4	14.2	10.5	967,385.9	0.00	1.00
07/11/2026 05:00	-2	1.6	8.5	14.3	6.8	832,444.0	0.00	1.00
07/11/2026 06:00	-1	1.7	8.4	14.3	7.9	802,150.7	0.00	1.00
07/11/2026 07:00	-1	1.7	8.5	14.3	8.2	787,419.0	0.00	1.00
07/11/2026 08:00	0	1.7	8.4	14.3	9.2	789,286.4	0.00	1.00
07/11/2026 09:00	-1	1.7	8.4	14.4	8.7	802,693.4	0.00	1.00
07/11/2026 10:00	-1	1.7	8.3	14.4	8.4	798,690.4	0.00	1.00
07/11/2026 11:00	-1	1.6	8.0	14.4	6.9	797,215.7	0.00	1.00
07/11/2026 12:00	-1	1.7	7.9	14.4	7.2	797,215.7	0.00	1.00
07/11/2026 13:00	-1	1.7	7.8	14.5	7.7	804,750.8	0.00	1.00
07/11/2026 14:00	0	1.6	7.8	14.5	8.8	803,680.9	0.00	1.00
07/11/2026 15:00	0	1.6	7.6	14.5	8.7	858,885.9	0.00	1.00
07/11/2026 16:00	-1	1.6	8.0	14.5	8.4	842,410.0	0.00	1.00
07/11/2026 17:00	2	1.9	10.3	13.6	18.1	982,608.9	0.00	1.00
07/11/2026 18:00	1	1.8	9.9	13.8	16.0	1,024,368.0	0.00	1.00
07/11/2026 19:00	1	1.8	9.9	13.9	17.4	1,026,677.0	0.00	1.00
07/11/2026 20:00	1	1.8	10.4	13.7	18.6	1,008,999.5	0.00	1.00
07/11/2026 21:00	2	1.9	11.4	13.4	20.4	1,005,340.1	0.00	1.00
07/11/2026 22:00	1	1.8	10.5	13.8	18.0	1,015,881.4	0.00	1.00
07/11/2026 23:00	3	2.0	12.6	13.0	24.0	1,018,227.7	0.00	1.00
Average/Sum#:	0	1.7	9.2	14.1	12.3	913,922.6	0.00 #	24.00 #
Minimum:	-2	1.6	7.6	13.0	6.8	787,419.0	0.00	1.00
Maximum:	3	2.0	12.6	14.5	24.0	1,049,551.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/12/2026 00:00	1	1.8	10.4	13.9	17.1	1,023,938.2	0.00	1.00
07/12/2026 01:00	1	1.8	10.2	13.9	16.7	1,020,808.1	0.00	1.00
07/12/2026 02:00	0	1.8	10.5	13.9	16.2	1,019,243.0	0.00	1.00
07/12/2026 03:00	1	1.8	10.4	13.9	15.9	1,018,851.7	0.00	1.00
07/12/2026 04:00	0	1.8	10.1	14.0	16.2	1,032,030.0	0.00	1.00
07/12/2026 05:00	0	1.8	10.0	14.0	15.9	1,030,839.2	0.00	1.00
07/12/2026 06:00	1	1.8	10.2	13.9	16.6	1,027,459.6	0.00	1.00
07/12/2026 07:00	2	2.0	12.5	13.2	23.7	1,037,027.7	0.00	1.00
07/12/2026 08:00	3	2.1	13.5	12.8	26.0	1,025,208.6	0.00	1.00
07/12/2026 09:00	1	1.8	10.7	13.7	18.1	1,021,552.6	0.00	1.00
07/12/2026 10:00	1	1.8	9.8	13.9	15.9	1,016,895.4	0.00	1.00
07/12/2026 11:00	1	1.8	10.0	13.8	16.7	1,012,409.7	0.00	1.00
07/12/2026 12:00	1	1.9	10.4	13.6	17.3	996,678.3	0.00	1.00
07/12/2026 13:00	3	2.1	12.0	12.9	22.9	992,148.0	0.00	1.00
07/12/2026 14:00	3	2.1	12.8	12.7	24.8	1,025,732.3	0.00	1.00
07/12/2026 15:00	5	2.2	13.2	12.3	29.5	1,029,775.3	0.00	1.00
07/12/2026 16:00	5	2.2	12.9	12.3	30.5	1,030,253.0	0.00	1.00
07/12/2026 17:00	2	2.0	11.5	13.2	21.2	1,027,957.5	0.00	1.00
07/12/2026 18:00	1	1.8	10.2	13.7	17.0	1,032,584.0	0.00	1.00
07/12/2026 19:00	4	2.2	13.2	12.4	28.3	1,027,712.7	0.00	1.00
07/12/2026 20:00	5	2.2	13.6	12.3	30.6	1,040,125.6	0.00	1.00
07/12/2026 21:00	5	2.2	13.4	12.3	29.3	1,035,507.8	0.00	1.00
07/12/2026 22:00	3	2.0	11.6	13.0	22.2	1,016,494.3	0.00	1.00
07/12/2026 23:00	-1	1.6	8.2	14.3	7.8	820,824.7	0.00	1.00
Average/Sum#:	2	1.9	11.3	13.3	20.7	1,015,085.7	0.00 #	24.00 #
Minimum:	-1	1.6	8.2	12.3	7.8	820,824.7	0.00	1.00
Maximum:	5	2.2	13.6	14.3	30.6	1,040,125.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/13/2026 00:00	-1	1.7	8.0	14.4	8.4	860,419.9	0.00	1.00
07/13/2026 01:00	0	1.6	7.5	14.6	10.0	995,767.2	0.00	1.00
07/13/2026 02:00	-1	1.7	7.8	14.6	9.7	996,636.6	0.00	1.00
07/13/2026 03:00	0	1.6	7.7	14.5	9.4	959,239.0	0.00	1.00
07/13/2026 04:00	0	1.6	7.6	14.5	9.8	974,859.0	0.00	1.00
07/13/2026 05:00	-1	1.7	8.1	14.4	8.9	894,550.1	0.00	1.00
07/13/2026 06:00	-1	1.6	7.6	14.5	9.4	975,500.9	0.00	1.00
07/13/2026 07:00	0	1.6	7.6	14.5	10.0	963,090.5	0.00	1.00
07/13/2026 08:00	2	2.0	12.0	13.0	21.7	1,002,280.0	0.00	1.00
07/13/2026 09:00	5	2.3	12.7	12.1	30.1	1,023,333.5	0.00	1.00
07/13/2026 10:00	5	2.2	12.5	12.1	29.1	1,020,532.4	0.00	1.00
07/13/2026 11:00	5	2.2	12.5	12.2	28.8	1,030,688.6	0.00	1.00
07/13/2026 12:00	5	2.2	12.7	12.2	29.1	1,029,114.6	0.00	1.00
07/13/2026 13:00	5	2.2	12.6	12.1	30.1	1,022,555.4	0.00	1.00
07/13/2026 14:00	5	2.2	12.6	12.1	30.2	1,021,621.7	0.00	1.00
07/13/2026 15:00	5	2.2	12.6	12.1	30.0	1,021,621.7	0.00	1.00
07/13/2026 16:00	6	2.2	12.6	12.1	30.3	1,021,777.3	0.00	1.00
07/13/2026 17:00	5	2.2	12.7	12.1	29.7	1,013,685.3	0.00	1.00
07/13/2026 18:00	5	2.2	12.7	12.2	29.1	1,023,762.8	0.00	1.00
07/13/2026 19:00	5	2.2	12.8	12.1	30.5	1,019,754.3	0.00	1.00
07/13/2026 20:00	5	2.2	13.5	12.2	30.3	1,025,179.4	0.00	1.00
07/13/2026 21:00	4	2.1	14.0	12.5	28.1	1,038,317.1	0.00	1.00
07/13/2026 22:00	1	1.9	11.1	13.4	19.1	1,019,216.9	0.00	1.00
07/13/2026 23:00	1	1.8	10.0	13.8	17.2	1,031,118.7	0.00	1.00
Average/Sum#:	3	2.0	10.9	13.1	21.6	999,359.3	0.00 #	24.00 #
Minimum:	-1	1.6	7.5	12.1	8.4	860,419.9	0.00	1.00
Maximum:	6	2.3	14.0	14.6	30.5	1,038,317.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/14/2026 00:00	1	1.9	11.2	13.4	19.4	1,028,711.6	0.00	1.00
07/14/2026 01:00	1	1.8	10.1	13.9	16.8	1,021,590.6	0.00	1.00
07/14/2026 02:00	1	1.7	10.8	13.8	17.5	1,009,323.6	0.00	1.00
07/14/2026 03:00	0	1.8	10.6	13.9	16.8	1,020,612.4	0.00	1.00
07/14/2026 04:00	1	1.8	10.6	13.9	16.8	1,021,590.6	0.00	1.00
07/14/2026 05:00	1	1.9	11.4	13.5	19.5	1,022,812.0	0.00	1.00
07/14/2026 06:00	1	1.8	10.1	14.0	16.4	1,028,854.5	0.00	1.00
07/14/2026 07:00	1	1.8	10.2	13.9	17.2	1,019,438.6	0.00	1.00
07/14/2026 08:00	1	1.8	10.5	13.7	17.6	999,109.2	0.00	1.00
07/14/2026 09:00	2	1.9	11.2	13.4	19.4	973,569.4	0.00	1.00
07/14/2026 10:00	2	2.0	12.1	13.1	20.5	944,727.3	0.00	1.00
07/14/2026 11:00	3	2.1	13.1	12.8	22.6	921,741.0	0.00	1.00
07/14/2026 12:00	1	1.8	10.6	13.3	17.8	999,860.0	0.00	1.00
07/14/2026 13:00	3	2.0	11.2	13.0	22.9	1,014,414.1	0.00	1.00
07/14/2026 14:00	4	2.2	13.1	12.5	28.4	1,018,753.9	0.00	1.00
07/14/2026 15:00	6	2.2	13.1	12.2	31.1	1,011,013.0	0.00	1.00
07/14/2026 16:00	5	2.2	12.8	12.3	30.1	1,015,762.6	0.00	1.00
07/14/2026 17:00	6	2.2	12.9	12.2	31.2	1,019,198.0	0.00	1.00
07/14/2026 18:00	5	2.2	12.8	12.2	30.1	1,015,105.5	0.00	1.00
07/14/2026 19:00	4	2.1	13.3	12.4	27.0	1,011,440.7	0.00	1.00
07/14/2026 20:00	3	2.0	12.4	12.8	23.7	1,019,967.6	0.00	1.00
07/14/2026 21:00	3	2.1	13.0	12.7	25.3	1,026,400.3	0.00	1.00
07/14/2026 22:00	1	1.9	10.9	13.5	18.6	1,026,513.1	0.00	1.00
07/14/2026 23:00	1	1.8	9.7	13.9	16.4	1,021,590.6	0.00	1.00
Average/Sum#:	2	2.0	11.6	13.2	21.8	1,008,837.5	0.00 #	24.00 #
Minimum:	0	1.7	9.7	12.2	16.4	921,741.0	0.00	1.00
Maximum:	6	2.2	13.3	14.0	31.2	1,028,854.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/15/2026 00:00	1	1.8	10.2	13.8	18.4	1,012,988.3	0.00	1.00
07/15/2026 01:00	1	1.8	10.5	13.8	18.7	1,010,480.9	0.00	1.00
07/15/2026 02:00	1	1.8	10.9	13.8	18.3	1,003,923.1	0.00	1.00
07/15/2026 03:00	1	1.8	10.6	13.9	17.5	1,014,939.1	0.00	1.00
07/15/2026 04:00	1	1.8	10.4	13.9	17.3	1,014,156.6	0.00	1.00
07/15/2026 05:00	1	1.8	10.3	13.9	17.0	1,016,308.5	0.00	1.00
07/15/2026 06:00	1	1.8	10.2	13.9	17.1	1,021,395.0	0.00	1.00
07/15/2026 07:00	1	1.8	10.4	13.8	18.2	1,015,109.9	0.00	1.00
07/15/2026 08:00	2	1.9	10.9	13.6	19.0	997,241.1	0.00	1.00
07/15/2026 09:00	3	2.0	12.0	13.2	21.9	959,308.5	0.00	1.00
07/15/2026 10:00	6	2.3	13.1	12.1	30.6	995,945.0	0.00	1.00
07/15/2026 11:00	5	2.2	12.7	12.2	30.1	1,019,985.1	0.00	1.00
07/15/2026 12:00	3	2.1	11.6	12.9	22.3	1,019,022.9	0.00	1.00
07/15/2026 13:00	4	2.1	13.0	12.5	26.6	1,006,689.9	0.00	1.00
07/15/2026 14:00	7	2.3	12.5	12.0	33.3	1,014,297.3	0.00	1.00
07/15/2026 15:00	5	2.2	12.6	12.2	29.9	1,010,698.2	0.00	1.00
07/15/2026 16:00	7	2.3	12.6	11.9	34.5	1,014,287.0	0.00	1.00
07/15/2026 17:00	6	2.2	12.5	12.1	31.8	1,014,463.4	0.00	1.00
07/15/2026 18:00	6	2.2	13.0	12.1	31.7	1,020,843.6	0.00	1.00
07/15/2026 19:00	5	2.1	13.2	12.4	30.4	1,032,868.2	0.00	1.00
07/15/2026 20:00	3	2.1	13.4	12.7	27.1	1,039,426.5	0.00	1.00
07/15/2026 21:00	3	2.0	12.7	12.9	24.9	1,027,581.8	0.00	1.00
07/15/2026 22:00	2	1.9	11.2	13.5	20.2	1,007,452.2	0.00	1.00
07/15/2026 23:00	1	1.8	10.6	13.7	18.5	1,013,183.8	0.00	1.00
Average/Sum#:	3	2.0	11.7	13.0	24.0	1,012,608.2	0.00 #	24.00 #
Minimum:	1	1.8	10.2	11.9	17.0	959,308.5	0.00	1.00
Maximum:	7	2.3	13.4	13.9	34.5	1,039,426.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/16/2026 00:00	1	1.8	10.4	13.8	17.4	1,024,175.1	0.00	1.00
07/16/2026 01:00	1	1.8	10.3	13.9	16.7	1,031,959.1	0.00	1.00
07/16/2026 02:00	0	1.7	10.6	14.0	16.1	1,033,816.2	0.00	1.00
07/16/2026 03:00	0	1.8	10.4	14.0	15.3	1,030,442.2	0.00	1.00
07/16/2026 04:00	0	1.8	10.3	14.0	15.1	1,032,030.0	0.00	1.00
07/16/2026 05:00	0	1.8	10.3	14.0	15.0	1,031,236.1	0.00	1.00
07/16/2026 06:00	0	1.8	10.1	14.0	16.2	1,031,037.6	0.00	1.00
07/16/2026 07:00	1	1.8	10.3	14.0	16.9	1,035,007.0	0.00	1.00
07/16/2026 08:00	1	1.8	10.6	13.9	17.8	1,024,916.3	0.00	1.00
07/16/2026 09:00	1	1.8	10.8	13.8	18.4	1,014,145.6	0.00	1.00
07/16/2026 10:00	1	1.9	11.1	13.7	18.9	1,008,619.1	0.00	1.00
07/16/2026 11:00	2	1.9	11.4	13.4	19.0	981,420.8	0.00	1.00
07/16/2026 12:00	2	2.0	12.6	13.0	21.7	949,583.1	0.00	1.00
07/16/2026 13:00	3	2.1	13.2	12.9	23.1	938,740.4	0.00	1.00
07/16/2026 14:00	4	2.1	13.6	12.7	25.1	919,351.4	0.00	1.00
07/16/2026 15:00	4	2.1	13.9	12.6	25.9	914,049.5	0.00	1.00
07/16/2026 16:00	3	2.1	13.7	12.7	24.3	922,023.4	0.00	1.00
07/16/2026 17:00	3	2.1	13.2	12.9	23.1	943,875.8	0.00	1.00
07/16/2026 18:00	2	2.0	12.0	13.2	20.6	964,999.6	0.00	1.00
07/16/2026 19:00	2	1.9	10.9	13.6	19.1	1,002,681.3	0.00	1.00
07/16/2026 20:00	1	1.8	10.5	13.8	18.2	1,018,388.8	0.00	1.00
07/16/2026 21:00	1	1.8	10.4	13.9	17.5	1,027,655.2	0.00	1.00
07/16/2026 22:00	1	1.8	10.4	13.9	16.8	1,024,133.8	0.00	1.00
07/16/2026 23:00	0	1.8	10.3	14.0	15.9	1,035,205.4	0.00	1.00
Average/Sum#:	1	1.9	11.3	13.6	18.9	997,478.9	0.00 #	24.00 #
Minimum:	0	1.7	10.1	12.6	15.0	914,049.5	0.00	1.00
Maximum:	4	2.1	13.9	14.0	25.9	1,035,205.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/17/2026 00:00	0	1.8	10.2	14.0	15.3	1,034,808.5	0.00	1.00
07/17/2026 01:00	0	1.7	10.2	14.1	14.8	1,047,206.9	0.00	1.00
07/17/2026 02:00	-1	1.7	10.6	14.1	14.9	1,050,026.3	0.00	1.00
07/17/2026 03:00	-1	1.7	10.4	14.1	14.3	1,050,026.3	0.00	1.00
07/17/2026 04:00	-1	1.7	10.0	14.1	13.6	1,047,408.3	0.00	1.00
07/17/2026 05:00	0	1.7	9.8	14.1	13.9	1,047,005.5	0.00	1.00
07/17/2026 06:00	0	1.7	9.8	14.1	15.4	1,050,227.7	0.00	1.00
07/17/2026 07:00	0	1.8	9.8	14.1	15.8	1,054,658.2	0.00	1.00
07/17/2026 08:00	1	1.8	9.9	14.0	16.7	1,044,334.9	0.00	1.00
07/17/2026 09:00	1	1.8	9.9	13.9	16.9	1,028,633.3	0.00	1.00
07/17/2026 10:00	1	1.8	9.9	13.9	16.6	1,031,372.2	0.00	1.00
07/17/2026 11:00	1	1.8	10.3	13.7	17.1	1,012,423.1	0.00	1.00
07/17/2026 12:00	2	1.9	11.1	13.4	18.6	980,507.9	0.00	1.00
07/17/2026 13:00	2	2.0	12.3	13.1	21.6	954,734.6	0.00	1.00
07/17/2026 14:00	3	2.0	13.6	12.9	24.3	940,452.2	0.00	1.00
07/17/2026 15:00	3	2.1	13.7	12.8	24.2	926,136.6	0.00	1.00
07/17/2026 16:00	3	2.1	13.9	12.8	24.0	926,982.0	0.00	1.00
07/17/2026 17:00	2	2.0	13.0	13.0	22.0	940,742.5	0.00	1.00
07/17/2026 18:00	1	1.9	11.3	13.4	18.1	973,204.3	0.00	1.00
07/17/2026 19:00	1	1.8	10.4	13.8	17.7	1,014,724.2	0.00	1.00
07/17/2026 20:00	1	1.8	10.1	13.9	17.0	1,023,938.2	0.00	1.00
07/17/2026 21:00	1	1.8	10.0	14.0	16.2	1,036,594.7	0.00	1.00
07/17/2026 22:00	0	1.7	9.9	14.0	15.2	1,033,419.2	0.00	1.00
07/17/2026 23:00	0	1.7	9.9	14.1	14.3	1,045,595.8	0.00	1.00
Average/Sum#:	1	1.8	10.8	13.7	17.4	1,012,298.5	0.00 #	24.00 #
Minimum:	-1	1.7	9.8	12.8	13.6	926,136.6	0.00	1.00
Maximum:	3	2.1	13.9	14.1	24.3	1,054,658.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/18/2026 00:00	0	1.7	9.7	14.1	13.7	1,042,373.6	0.00	1.00
07/18/2026 01:00	-1	1.7	9.6	14.1	13.1	1,040,158.4	0.00	1.00
07/18/2026 02:00	-1	1.8	10.0	14.2	12.4	1,054,252.4	0.00	1.00
07/18/2026 03:00	-1	1.7	9.8	14.2	12.3	1,054,456.8	0.00	1.00
07/18/2026 04:00	-1	1.7	9.7	14.2	12.2	1,050,982.1	0.00	1.00
07/18/2026 05:00	-1	1.8	10.2	14.0	13.3	1,051,281.3	0.00	1.00
07/18/2026 06:00	-1	1.7	9.6	14.2	12.7	1,054,661.2	0.00	1.00
07/18/2026 07:00	0	1.7	9.5	14.2	13.6	1,059,975.4	0.00	1.00
07/18/2026 08:00	1	1.7	9.5	14.1	16.0	1,051,436.0	0.00	1.00
07/18/2026 09:00	1	1.8	9.8	14.0	16.3	1,039,968.7	0.00	1.00
07/18/2026 10:00	0	1.8	10.0	14.0	16.0	1,042,350.3	0.00	1.00
07/18/2026 11:00	-1	1.7	9.2	14.1	11.7	921,743.4	0.00	1.00
07/18/2026 12:00	-1	1.7	8.0	14.4	6.4	790,052.5	0.00	1.00
07/18/2026 13:00	-1	1.7	8.0	14.5	8.7	853,964.5	0.00	1.00
07/18/2026 14:00	2	1.9	11.6	13.2	21.1	961,976.2	0.00	1.00
07/18/2026 15:00	2	2.0	12.5	13.1	21.7	951,047.7	0.00	1.00
07/18/2026 16:00	2	2.0	12.8	13.0	21.4	940,395.9	0.00	1.00
07/18/2026 17:00	2	2.0	13.1	13.0	21.8	940,569.2	0.00	1.00
07/18/2026 18:00	2	2.0	12.5	13.2	20.4	958,597.1	0.00	1.00
07/18/2026 19:00	1	1.9	11.2	13.6	18.4	995,740.4	0.00	1.00
07/18/2026 20:00	1	1.8	10.7	13.8	18.1	1,020,317.6	0.00	1.00
07/18/2026 21:00	1	1.8	10.4	13.8	17.6	1,021,860.6	0.00	1.00
07/18/2026 22:00	1	1.8	10.2	13.9	16.8	1,031,763.5	0.00	1.00
07/18/2026 23:00	0	1.8	10.0	13.9	15.9	1,028,437.7	0.00	1.00
Average/Sum#:	0	1.8	10.3	13.9	15.5	998,265.1	0.00 #	24.00 #
Minimum:	-1	1.7	8.0	13.0	6.4	790,052.5	0.00	1.00
Maximum:	2	2.0	13.1	14.5	21.8	1,059,975.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/19/2026 00:00	0	1.8	10.0	14.0	15.3	1,041,754.9	0.00	1.00
07/19/2026 01:00	0	1.8	9.9	14.0	14.7	1,038,579.4	0.00	1.00
07/19/2026 02:00	0	1.7	10.1	14.1	14.3	1,050,429.1	0.00	1.00
07/19/2026 03:00	0	1.7	9.9	14.1	13.7	1,047,005.5	0.00	1.00
07/19/2026 04:00	0	1.7	9.7	14.1	13.5	1,043,581.9	0.00	1.00
07/19/2026 05:00	0	1.7	9.6	14.1	13.9	1,043,581.9	0.00	1.00
07/19/2026 06:00	0	1.7	9.6	14.1	15.4	1,046,804.1	0.00	1.00
07/19/2026 07:00	0	1.7	9.6	14.1	15.7	1,049,220.7	0.00	1.00
07/19/2026 08:00	1	1.8	9.9	14.0	16.3	1,037,388.6	0.00	1.00
07/19/2026 09:00	1	1.8	10.3	13.9	16.6	1,025,307.6	0.00	1.00
07/19/2026 10:00	1	1.8	10.4	13.8	16.4	1,018,774.6	0.00	1.00
07/19/2026 11:00	1	1.9	10.8	13.6	16.9	999,867.4	0.00	1.00
07/19/2026 12:00	2	2.0	11.5	13.2	18.9	963,398.9	0.00	1.00
07/19/2026 13:00	2	2.0	12.1	13.0	19.9	945,769.5	0.00	1.00
07/19/2026 14:00	3	2.1	12.7	12.9	22.1	937,884.5	0.00	1.00
07/19/2026 15:00	3	2.1	13.5	12.7	23.5	919,685.4	0.00	1.00
07/19/2026 16:00	3	2.1	13.9	12.7	24.8	928,536.5	0.00	1.00
07/19/2026 17:00	5	2.2	13.7	12.4	28.5	974,707.9	0.00	1.00
07/19/2026 18:00	3	2.0	13.5	12.7	24.9	1,034,416.4	0.00	1.00
07/19/2026 19:00	2	2.0	13.2	13.0	24.1	1,048,563.1	0.00	1.00
07/19/2026 20:00	4	2.2	15.0	12.4	31.2	1,050,429.1	0.00	1.00
07/19/2026 21:00	4	2.2	15.1	12.4	31.4	1,056,873.4	0.00	1.00
07/19/2026 22:00	4	2.2	14.6	12.4	29.5	1,046,401.3	0.00	1.00
07/19/2026 23:00	3	2.2	14.2	12.5	28.3	1,052,826.5	0.00	1.00
Average/Sum#:	2	1.9	11.8	13.3	20.4	1,016,741.2	0.00 #	24.00 #
Minimum:	0	1.7	9.6	12.4	13.5	919,685.4	0.00	1.00
Maximum:	5	2.2	15.1	14.1	31.4	1,056,873.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/20/2026 00:00	1	1.9	11.6	13.5	19.0	1,053,716.5	0.00	1.00
07/20/2026 01:00	0	1.8	10.3	14.0	16.4	1,041,754.9	0.00	1.00
07/20/2026 02:00	1	1.7	11.6	13.7	19.0	1,043,044.9	0.00	1.00
07/20/2026 03:00	4	2.3	14.1	12.4	29.7	1,045,273.6	0.00	1.00
07/20/2026 04:00	5	2.2	14.0	12.3	31.9	1,049,998.2	0.00	1.00
07/20/2026 05:00	4	2.2	14.4	12.3	30.7	1,046,654.2	0.00	1.00
07/20/2026 06:00	4	2.1	14.2	12.5	29.0	1,049,729.0	0.00	1.00
07/20/2026 07:00	3	2.1	13.7	12.6	27.4	1,040,927.5	0.00	1.00
07/20/2026 08:00	4	2.2	13.8	12.6	28.6	1,045,382.3	0.00	1.00
07/20/2026 09:00	3	2.1	13.4	12.8	26.7	1,034,676.2	0.00	1.00
07/20/2026 10:00	4	2.1	13.7	12.5	28.5	1,044,186.1	0.00	1.00
07/20/2026 11:00	3	2.1	13.3	12.6	26.1	1,048,517.1	0.00	1.00
07/20/2026 12:00	3	2.1	13.2	12.7	25.8	1,041,764.5	0.00	1.00
07/20/2026 13:00	4	2.2	13.5	12.4	29.4	1,038,023.7	0.00	1.00
07/20/2026 14:00	3	2.1	13.1	12.7	25.8	1,032,245.4	0.00	1.00
07/20/2026 15:00	3	2.1	13.1	12.7	25.5	1,034,249.4	0.00	1.00
07/20/2026 16:00	3	2.1	13.3	12.6	26.8	1,038,452.7	0.00	1.00
07/20/2026 17:00	3	2.1	13.7	12.6	27.3	1,038,122.7	0.00	1.00
07/20/2026 18:00	4	2.2	14.4	12.4	29.8	1,041,890.3	0.00	1.00
07/20/2026 19:00	3	2.1	14.1	12.6	28.1	1,049,012.1	0.00	1.00
07/20/2026 20:00	4	2.1	14.2	12.5	29.3	1,050,544.1	0.00	1.00
07/20/2026 21:00	3	2.1	13.4	12.7	26.1	1,047,609.7	0.00	1.00
07/20/2026 22:00	1	1.9	11.0	13.5	19.4	1,044,093.6	0.00	1.00
07/20/2026 23:00	2	2.0	11.9	13.2	21.5	1,024,222.7	0.00	1.00
Average/Sum#:	3	2.1	13.2	12.8	26.2	1,042,670.5	0.00 #	24.00 #
Minimum:	0	1.7	10.3	12.3	16.4	1,024,222.7	0.00	1.00
Maximum:	5	2.3	14.4	14.0	31.9	1,053,716.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/21/2026 00:00	1	1.8	10.0	13.8	16.5	1,019,160.3	0.00	1.00
07/21/2026 01:00	1	1.8	10.1	13.8	16.9	1,022,825.0	0.00	1.00
07/21/2026 02:00	1	1.8	10.4	13.8	16.6	1,023,210.8	0.00	1.00
07/21/2026 03:00	1	1.8	10.2	13.9	16.3	1,033,132.9	0.00	1.00
07/21/2026 04:00	1	1.9	11.1	13.6	19.5	1,037,573.5	0.00	1.00
07/21/2026 05:00	3	2.1	13.9	12.7	27.1	1,038,424.5	0.00	1.00
07/21/2026 06:00	2	1.9	11.6	13.3	20.8	1,023,824.9	0.00	1.00
07/21/2026 07:00	1	1.9	10.9	13.6	19.5	1,028,569.0	0.00	1.00
07/21/2026 08:00	2	1.9	11.5	13.4	20.2	1,024,512.0	0.00	1.00
07/21/2026 09:00	2	1.9	11.2	13.4	19.8	989,089.6	0.00	1.00
07/21/2026 10:00	3	2.0	12.6	13.0	22.0	956,690.3	0.00	1.00
07/21/2026 11:00	4	2.1	13.2	12.5	25.8	963,650.9	0.00	1.00
07/21/2026 12:00	5	2.2	13.4	12.3	30.1	1,037,577.8	0.00	1.00
07/21/2026 13:00	4	2.2	13.0	12.4	28.5	1,033,834.9	0.00	1.00
07/21/2026 14:00	5	2.2	12.7	12.3	30.3	1,028,342.2	0.00	1.00
07/21/2026 15:00	6	2.2	12.6	12.1	31.5	1,019,443.1	0.00	1.00
07/21/2026 16:00	5	2.2	13.0	12.3	29.2	1,023,087.4	0.00	1.00
07/21/2026 17:00	6	2.2	12.7	12.1	30.7	1,014,152.1	0.00	1.00
07/21/2026 18:00	6	2.3	12.3	12.0	32.1	1,021,990.6	0.00	1.00
07/21/2026 19:00	6	2.3	12.2	12.0	31.2	1,019,990.4	0.00	1.00
07/21/2026 20:00	6	2.2	12.6	12.2	31.3	1,035,095.9	0.00	1.00
07/21/2026 21:00	5	2.1	13.2	12.4	29.8	1,041,568.1	0.00	1.00
07/21/2026 22:00	4	2.1	13.1	12.5	28.0	1,033,100.3	0.00	1.00
07/21/2026 23:00	3	2.1	12.8	12.7	25.5	1,035,084.4	0.00	1.00
Average/Sum#:	3	2.1	12.1	12.8	25.0	1,020,997.1	0.00 #	24.00 #
Minimum:	1	1.8	10.0	12.0	16.3	956,690.3	0.00	1.00
Maximum:	6	2.3	13.9	13.9	32.1	1,041,568.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/22/2026 00:00	1	1.8	9.8	13.9	16.4	1,027,459.6	0.00	1.00
07/22/2026 01:00	1	1.8	9.6	13.8	15.7	1,012,409.7	0.00	1.00
07/22/2026 02:00	0	1.8	9.9	13.9	14.8	1,025,894.5	0.00	1.00
07/22/2026 03:00	0	1.8	9.6	13.9	13.9	1,023,546.9	0.00	1.00
07/22/2026 04:00	0	1.8	9.5	13.9	14.4	1,033,524.1	0.00	1.00
07/22/2026 05:00	1	1.9	10.5	13.5	16.8	1,029,289.0	0.00	1.00
07/22/2026 06:00	1	1.8	9.3	13.9	14.9	1,022,177.5	0.00	1.00
07/22/2026 07:00	1	1.8	9.7	13.8	17.3	1,030,347.2	0.00	1.00
07/22/2026 08:00	2	1.9	11.3	13.3	19.9	1,029,771.1	0.00	1.00
07/22/2026 09:00	1	1.8	9.5	13.9	16.1	1,023,546.9	0.00	1.00
07/22/2026 10:00	1	1.8	9.5	13.8	15.7	1,012,216.8	0.00	1.00
07/22/2026 11:00	1	1.8	9.5	13.8	15.5	1,016,845.8	0.00	1.00
07/22/2026 12:00	1	1.8	9.7	13.7	16.3	1,007,097.5	0.00	1.00
07/22/2026 13:00	1	1.9	10.1	13.6	16.8	997,991.5	0.00	1.00
07/22/2026 14:00	2	1.9	10.6	13.4	17.8	975,030.2	0.00	1.00
07/22/2026 15:00	2	1.9	10.8	13.4	18.5	974,117.2	0.00	1.00
07/22/2026 16:00	2	1.9	11.4	13.3	20.0	963,101.8	0.00	1.00
07/22/2026 17:00	1	1.9	11.1	13.4	18.2	972,108.7	0.00	1.00
07/22/2026 18:00	1	1.9	10.4	13.6	17.3	990,863.0	0.00	1.00
07/22/2026 19:00	1	1.8	9.8	13.8	16.4	1,010,866.6	0.00	1.00
07/22/2026 20:00	1	1.8	9.6	13.9	15.9	1,018,460.5	0.00	1.00
07/22/2026 21:00	0	1.8	9.5	14.0	14.9	1,029,449.9	0.00	1.00
07/22/2026 22:00	0	1.7	9.4	14.0	14.1	1,028,060.6	0.00	1.00
07/22/2026 23:00	0	1.7	9.4	14.1	13.4	1,040,561.1	0.00	1.00
Average/Sum#:	1	1.8	10.0	13.7	16.3	1,012,280.7	0.00 #	24.00 #
Minimum:	0	1.7	9.3	13.3	13.4	963,101.8	0.00	1.00
Maximum:	2	1.9	11.4	14.1	20.0	1,040,561.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/23/2026 00:00	0	1.7	9.4	14.1	13.2	1,040,762.5	0.00	1.00
07/23/2026 01:00	0	1.7	9.3	14.1	13.0	1,040,158.4	0.00	1.00
07/23/2026 02:00	-1	1.7	9.8	14.1	12.8	1,037,540.4	0.00	1.00
07/23/2026 03:00	-1	1.7	9.6	14.1	12.7	1,037,741.7	0.00	1.00
07/23/2026 04:00	-1	1.7	9.5	14.2	12.9	1,054,456.8	0.00	1.00
07/23/2026 05:00	0	1.7	9.5	14.2	13.7	1,054,865.6	0.00	1.00
07/23/2026 06:00	0	1.7	9.3	14.1	14.8	1,045,193.0	0.00	1.00
07/23/2026 07:00	0	1.7	9.3	14.1	15.1	1,048,012.4	0.00	1.00
07/23/2026 08:00	0	1.7	8.9	14.2	13.7	1,025,637.5	0.00	1.00
07/23/2026 09:00	-1	1.7	8.0	14.3	7.0	785,136.6	0.00	1.00
07/23/2026 10:00	-1	1.7	7.9	14.4	6.6	791,316.6	0.00	1.00
07/23/2026 11:00	0	1.8	9.0	14.1	11.8	934,430.8	0.00	1.00
07/23/2026 12:00	1	1.9	10.6	13.6	17.1	1,000,992.9	0.00	1.00
07/23/2026 13:00	2	1.9	11.3	13.3	18.4	968,147.0	0.00	1.00
07/23/2026 14:00	2	2.0	11.7	13.2	20.6	959,130.6	0.00	1.00
07/23/2026 15:00	2	2.0	12.3	13.1	21.5	950,872.1	0.00	1.00
07/23/2026 16:00	2	2.0	12.7	13.0	21.1	940,222.5	0.00	1.00
07/23/2026 17:00	2	2.0	12.8	13.0	20.9	942,649.3	0.00	1.00
07/23/2026 18:00	3	2.1	12.8	12.8	21.8	948,453.2	0.00	1.00
07/23/2026 19:00	1	1.9	10.7	13.5	17.2	994,128.1	0.00	1.00
07/23/2026 20:00	2	1.9	11.1	13.5	19.5	1,023,922.3	0.00	1.00
07/23/2026 21:00	1	1.8	10.1	13.8	16.4	1,020,896.2	0.00	1.00
07/23/2026 22:00	1	1.8	10.1	13.9	16.2	1,037,045.5	0.00	1.00
07/23/2026 23:00	0	1.8	10.3	13.9	15.7	1,041,153.8	0.00	1.00
Average/Sum#:	1	1.8	10.3	13.8	15.6	988,452.7	0.00 #	24.00 #
Minimum:	-1	1.7	7.9	12.8	6.6	785,136.6	0.00	1.00
Maximum:	3	2.1	12.8	14.4	21.8	1,054,865.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/24/2026 00:00	0	1.7	9.8	14.1	14.4	1,051,436.0	0.00	1.00
07/24/2026 01:00	0	1.7	9.7	14.1	14.1	1,051,033.2	0.00	1.00
07/24/2026 02:00	0	1.8	10.1	14.1	13.8	1,051,033.2	0.00	1.00
07/24/2026 03:00	0	1.7	9.9	14.1	13.5	1,048,818.0	0.00	1.00
07/24/2026 04:00	0	1.7	9.6	14.1	13.3	1,045,193.0	0.00	1.00
07/24/2026 05:00	0	1.7	9.5	14.1	13.5	1,044,790.3	0.00	1.00
07/24/2026 06:00	0	1.7	9.4	14.1	15.3	1,050,227.7	0.00	1.00
07/24/2026 07:00	1	1.7	9.5	14.1	15.7	1,054,255.4	0.00	1.00
07/24/2026 08:00	1	1.8	9.8	14.0	16.7	1,044,334.9	0.00	1.00
07/24/2026 09:00	1	1.8	10.1	13.9	16.6	1,034,306.7	0.00	1.00
07/24/2026 10:00	1	1.8	10.4	13.7	16.5	1,010,521.1	0.00	1.00
07/24/2026 11:00	-1	1.6	8.1	14.4	6.4	806,907.0	0.00	1.00
07/24/2026 12:00	1	1.9	10.3	13.6	16.7	949,029.9	0.00	1.00
07/24/2026 13:00	4	2.2	12.8	12.5	26.5	982,888.0	0.00	1.00
07/24/2026 14:00	6	2.2	12.8	12.2	31.8	1,032,420.1	0.00	1.00
07/24/2026 15:00	6	2.2	12.8	12.2	31.8	1,028,012.7	0.00	1.00
07/24/2026 16:00	2	2.0	12.2	13.0	22.5	1,027,415.0	0.00	1.00
07/24/2026 17:00	3	2.1	12.0	12.9	24.7	1,039,906.6	0.00	1.00
07/24/2026 18:00	3	2.0	13.0	12.7	25.3	1,036,587.5	0.00	1.00
07/24/2026 19:00	1	1.9	10.5	13.6	18.2	1,037,010.7	0.00	1.00
07/24/2026 20:00	1	1.9	10.5	13.6	19.0	1,042,638.5	0.00	1.00
07/24/2026 21:00	1	1.8	9.9	13.9	16.1	1,049,957.2	0.00	1.00
07/24/2026 22:00	0	1.7	9.5	14.1	14.9	1,049,019.4	0.00	1.00
07/24/2026 23:00	0	1.8	9.6	14.0	14.6	1,036,396.3	0.00	1.00
Average/Sum#:	1	1.9	10.5	13.6	18.0	1,025,172.4	0.00 #	24.00 #
Minimum:	-1	1.6	8.1	12.2	6.4	806,907.0	0.00	1.00
Maximum:	6	2.2	13.0	14.4	31.8	1,054,255.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/25/2026 00:00	0	1.7	9.5	14.1	14.1	1,050,630.4	0.00	1.00
07/25/2026 01:00	0	1.7	9.5	14.1	13.5	1,048,818.0	0.00	1.00
07/25/2026 02:00	-1	1.7	10.0	14.1	13.4	1,048,213.8	0.00	1.00
07/25/2026 03:00	-1	1.8	9.8	14.1	13.3	1,048,012.4	0.00	1.00
07/25/2026 04:00	-1	1.7	9.6	14.1	12.9	1,046,200.0	0.00	1.00
07/25/2026 05:00	0	1.7	9.5	14.2	13.5	1,059,157.8	0.00	1.00
07/25/2026 06:00	0	1.7	9.5	14.1	15.1	1,047,206.9	0.00	1.00
07/25/2026 07:00	0	1.8	9.5	14.0	15.6	1,039,174.8	0.00	1.00
07/25/2026 08:00	1	1.8	9.8	14.0	16.9	1,044,334.9	0.00	1.00
07/25/2026 09:00	1	1.8	10.2	13.9	17.3	1,036,263.0	0.00	1.00
07/25/2026 10:00	1	1.8	10.6	13.8	17.6	1,027,646.9	0.00	1.00
07/25/2026 11:00	1	1.9	11.1	13.5	17.7	995,608.5	0.00	1.00
07/25/2026 12:00	2	2.0	11.7	13.2	20.0	966,955.9	0.00	1.00
07/25/2026 13:00	2	2.0	12.5	13.0	21.8	946,983.0	0.00	1.00
07/25/2026 14:00	3	2.0	13.1	12.9	23.9	938,398.1	0.00	1.00
07/25/2026 15:00	4	2.1	13.7	12.8	25.4	928,672.6	0.00	1.00
07/25/2026 16:00	4	2.1	14.0	12.6	25.0	909,924.8	0.00	1.00
07/25/2026 17:00	3	2.1	13.5	12.7	23.2	920,854.4	0.00	1.00
07/25/2026 18:00	2	2.0	12.3	13.0	20.0	942,476.0	0.00	1.00
07/25/2026 19:00	1	1.9	11.0	13.4	18.0	977,403.8	0.00	1.00
07/25/2026 20:00	1	1.8	10.5	13.7	17.9	1,008,999.5	0.00	1.00
07/25/2026 21:00	1	1.8	10.2	13.8	17.5	1,018,388.8	0.00	1.00
07/25/2026 22:00	1	1.8	10.1	13.9	16.7	1,030,002.8	0.00	1.00
07/25/2026 23:00	1	1.8	10.0	13.9	16.2	1,026,872.7	0.00	1.00
Average/Sum#:	1	1.9	10.9	13.6	17.8	1,004,466.7	0.00 #	24.00 #
Minimum:	-1	1.7	9.5	12.6	12.9	909,924.8	0.00	1.00
Maximum:	4	2.1	14.0	14.2	25.4	1,059,157.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/26/2026 00:00	0	1.8	9.9	14.0	15.7	1,040,564.1	0.00	1.00
07/26/2026 01:00	0	1.8	9.7	14.0	15.2	1,037,984.0	0.00	1.00
07/26/2026 02:00	0	1.8	9.9	14.1	14.5	1,049,220.7	0.00	1.00
07/26/2026 03:00	0	1.7	9.6	14.1	13.9	1,045,998.6	0.00	1.00
07/26/2026 04:00	0	1.7	9.5	14.1	13.7	1,047,005.5	0.00	1.00
07/26/2026 05:00	0	1.7	9.5	14.1	14.0	1,048,213.8	0.00	1.00
07/26/2026 06:00	0	1.7	9.5	14.1	15.3	1,050,831.8	0.00	1.00
07/26/2026 07:00	-1	1.7	8.1	14.3	7.2	795,096.1	0.00	1.00
07/26/2026 08:00	0	1.7	8.6	14.2	13.5	960,436.6	0.00	1.00
07/26/2026 09:00	1	1.8	9.9	13.9	17.3	1,036,067.4	0.00	1.00
07/26/2026 10:00	1	1.8	10.5	13.8	17.3	1,026,489.7	0.00	1.00
07/26/2026 11:00	1	1.8	10.8	13.6	17.2	1,000,805.4	0.00	1.00
07/26/2026 12:00	2	1.9	11.4	13.3	19.1	974,273.4	0.00	1.00
07/26/2026 13:00	2	2.0	12.4	13.1	21.6	956,314.7	0.00	1.00
07/26/2026 14:00	3	2.1	13.1	12.9	23.7	936,515.1	0.00	1.00
07/26/2026 15:00	3	2.1	13.4	12.8	24.0	927,996.4	0.00	1.00
07/26/2026 16:00	3	2.1	13.7	12.8	24.1	928,334.5	0.00	1.00
07/26/2026 17:00	3	2.1	13.4	12.8	23.1	930,532.3	0.00	1.00
07/26/2026 18:00	2	2.0	11.6	13.2	19.0	964,110.3	0.00	1.00
07/26/2026 19:00	1	1.9	10.6	13.6	17.9	1,006,808.3	0.00	1.00
07/26/2026 20:00	1	1.8	10.6	13.7	18.4	1,023,264.3	0.00	1.00
07/26/2026 21:00	2	2.0	12.0	13.2	22.6	1,035,960.7	0.00	1.00
07/26/2026 22:00	2	2.0	11.9	13.3	21.5	1,044,005.9	0.00	1.00
07/26/2026 23:00	0	1.8	9.8	14.1	15.0	1,049,623.5	0.00	1.00
Average/Sum#:	1	1.9	10.8	13.6	17.7	996,518.9	0.00 #	24.00 #
Minimum:	-1	1.7	8.1	12.8	7.2	795,096.1	0.00	1.00
Maximum:	3	2.1	13.7	14.3	24.1	1,050,831.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/27/2026 00:00	0	1.8	10.5	13.9	16.1	1,050,152.9	0.00	1.00
07/27/2026 01:00	0	1.7	9.7	14.1	14.2	1,043,984.7	0.00	1.00
07/27/2026 02:00	-1	1.7	10.0	14.2	13.6	1,057,931.4	0.00	1.00
07/27/2026 03:00	-1	1.7	9.8	14.2	13.5	1,058,135.8	0.00	1.00
07/27/2026 04:00	0	1.7	9.7	14.2	13.5	1,055,683.1	0.00	1.00
07/27/2026 05:00	0	1.7	9.6	14.2	13.7	1,055,274.3	0.00	1.00
07/27/2026 06:00	0	1.7	9.5	14.2	15.0	1,059,771.0	0.00	1.00
07/27/2026 07:00	0	1.7	9.5	14.1	16.2	1,048,616.6	0.00	1.00
07/27/2026 08:00	-1	1.8	9.6	14.0	17.5	1,038,579.4	0.00	1.00
07/27/2026 09:00	1	1.8	10.1	14.0	20.0	1,042,548.7	0.00	1.00
07/27/2026 10:00	0	1.7	10.3	13.8	16.2	1,017,810.2	0.00	1.00
07/27/2026 11:00	1	1.8	10.7	13.7	16.5	1,011,091.7	0.00	1.00
07/27/2026 12:00	2	1.9	11.2	13.4	18.3	980,690.4	0.00	1.00
07/27/2026 13:00	2	2.0	11.8	13.2	20.4	963,932.5	0.00	1.00
07/27/2026 14:00	3	2.0	12.5	13.0	22.3	942,996.0	0.00	1.00
07/27/2026 15:00	3	2.0	12.9	12.9	22.5	932,749.2	0.00	1.00
07/27/2026 16:00	3	2.1	13.2	12.9	23.0	937,713.3	0.00	1.00
07/27/2026 17:00	2	1.9	12.5	13.0	20.4	957,383.7	0.00	1.00
07/27/2026 18:00	2	2.0	11.4	13.2	21.4	1,039,695.4	0.00	1.00
07/27/2026 19:00	2	2.0	12.0	13.1	21.5	1,040,235.8	0.00	1.00
07/27/2026 20:00	1	1.9	10.8	13.5	18.6	1,037,986.7	0.00	1.00
07/27/2026 21:00	1	1.8	9.9	13.9	16.4	1,031,372.2	0.00	1.00
07/27/2026 22:00	1	1.8	10.0	14.0	16.1	1,040,762.5	0.00	1.00
07/27/2026 23:00	0	1.8	9.8	14.0	15.5	1,038,182.5	0.00	1.00
Average/Sum#:	1	1.8	10.7	13.7	17.6	1,020,136.7	0.00 #	24.00 #
Minimum:	-1	1.7	9.5	12.9	13.5	932,749.2	0.00	1.00
Maximum:	3	2.1	13.2	14.2	23.0	1,059,771.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/28/2026 00:00	0	1.7	9.6	14.1	15.0	1,052,644.3	0.00	1.00
07/28/2026 01:00	0	1.7	9.5	14.1	14.5	1,049,824.9	0.00	1.00
07/28/2026 02:00	0	1.7	10.0	14.1	14.1	1,049,019.4	0.00	1.00
07/28/2026 03:00	0	1.7	9.8	14.1	14.1	1,046,602.7	0.00	1.00
07/28/2026 04:00	0	1.7	9.8	14.1	14.1	1,047,206.9	0.00	1.00
07/28/2026 05:00	0	1.7	9.6	14.2	14.1	1,060,792.9	0.00	1.00
07/28/2026 06:00	0	1.7	9.5	14.2	15.4	1,063,450.0	0.00	1.00
07/28/2026 07:00	-1	1.7	8.4	14.3	9.9	889,295.9	0.00	1.00
07/28/2026 08:00	-1	1.7	8.1	14.3	7.8	782,439.3	0.00	1.00
07/28/2026 09:00	-1	1.7	8.7	14.4	7.8	793,844.8	0.00	1.00
07/28/2026 10:00	-1	1.7	8.6	14.4	7.4	792,159.3	0.00	1.00
07/28/2026 11:00	-1	1.7	8.3	14.5	7.9	870,868.3	0.00	1.00
07/28/2026 12:00	0	1.8	10.4	13.8	15.5	981,356.5	0.00	1.00
07/28/2026 13:00	-1	1.6	8.5	14.4	8.1	794,055.5	0.00	1.00
07/28/2026 14:00	-1	1.6	8.2	14.5	8.7	802,183.1	0.00	1.00
07/28/2026 15:00	-1	1.7	8.0	14.5	8.7	868,086.7	0.00	1.00
07/28/2026 16:00	1	1.8	10.4	13.8	16.5	1,026,682.5	0.00	1.00
07/28/2026 17:00	1	1.8	10.4	13.8	16.3	1,029,575.7	0.00	1.00
07/28/2026 18:00	2	2.0	12.2	13.2	20.4	965,533.1	0.00	1.00
07/28/2026 19:00	1	1.9	11.4	13.4	18.1	980,690.4	0.00	1.00
07/28/2026 20:00	1	1.9	10.6	13.7	17.3	1,012,232.9	0.00	1.00
07/28/2026 21:00	1	1.8	10.5	13.7	17.3	1,012,993.6	0.00	1.00
07/28/2026 22:00	1	1.8	10.3	13.8	16.7	1,019,353.2	0.00	1.00
07/28/2026 23:00	-1	1.6	8.6	14.3	7.7	800,698.3	0.00	1.00
Average/Sum#:	0	1.7	9.6	14.1	13.1	949,649.6	0.00 #	24.00 #
Minimum:	-1	1.6	8.0	13.2	7.4	782,439.3	0.00	1.00
Maximum:	2	2.0	12.2	14.5	20.4	1,063,450.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/29/2026 00:00	-1	1.7	8.4	14.3	7.0	780,571.9	0.00	1.00
07/29/2026 01:00	-1	1.7	8.5	14.3	6.8	780,571.9	0.00	1.00
07/29/2026 02:00	-1	1.8	8.7	14.3	6.2	781,401.9	0.00	1.00
07/29/2026 03:00	-1	1.7	8.6	14.3	6.4	781,609.3	0.00	1.00
07/29/2026 04:00	-1	1.7	8.6	14.3	6.5	781,816.8	0.00	1.00
07/29/2026 05:00	-1	1.7	8.6	14.3	6.5	781,401.9	0.00	1.00
07/29/2026 06:00	-1	1.7	8.6	14.3	7.7	781,401.9	0.00	1.00
07/29/2026 07:00	-1	1.7	8.6	14.3	8.0	781,194.4	0.00	1.00
07/29/2026 08:00	-1	1.7	8.5	14.3	7.9	780,156.9	0.00	1.00
07/29/2026 09:00	-1	1.7	8.5	14.4	8.0	791,738.0	0.00	1.00
07/29/2026 10:00	-1	1.7	8.4	14.5	8.4	860,169.7	0.00	1.00
07/29/2026 11:00	1	2.0	11.3	13.4	17.2	985,255.2	0.00	1.00
07/29/2026 12:00	2	2.0	12.1	13.1	19.4	954,910.2	0.00	1.00
07/29/2026 13:00	3	2.1	13.5	12.8	22.8	930,363.3	0.00	1.00
07/29/2026 14:00	3	2.1	14.1	12.7	24.8	920,186.4	0.00	1.00
07/29/2026 15:00	4	2.1	14.2	12.5	25.7	901,537.7	0.00	1.00
07/29/2026 16:00	4	2.1	14.2	12.5	24.6	901,863.8	0.00	1.00
07/29/2026 17:00	4	2.2	13.9	12.5	25.0	910,667.2	0.00	1.00
07/29/2026 18:00	3	2.1	13.3	12.6	22.7	925,928.9	0.00	1.00
07/29/2026 19:00	2	2.0	12.3	13.0	20.0	949,236.4	0.00	1.00
07/29/2026 20:00	1	1.9	11.0	13.5	17.6	991,722.3	0.00	1.00
07/29/2026 21:00	-1	1.7	8.6	14.4	7.8	812,384.7	0.00	1.00
07/29/2026 22:00	-1	1.7	8.5	14.4	8.0	791,527.3	0.00	1.00
07/29/2026 23:00	-1	1.7	8.6	14.4	7.8	791,948.7	0.00	1.00
Average/Sum#:	1	1.9	10.4	13.7	13.5	852,065.3	0.00 #	24.00 #
Minimum:	-1	1.7	8.4	12.5	6.2	780,156.9	0.00	1.00
Maximum:	4	2.2	14.2	14.5	25.7	991,722.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/30/2026 00:00	-1	1.7	8.6	14.3	7.3	781,194.4	0.00	1.00
07/30/2026 01:00	-1	1.7	8.7	14.3	7.1	781,609.3	0.00	1.00
07/30/2026 02:00	-1	1.7	8.9	14.3	6.7	781,816.8	0.00	1.00
07/30/2026 03:00	-1	1.7	8.9	14.3	6.6	781,609.3	0.00	1.00
07/30/2026 04:00	-2	1.7	8.8	14.3	6.5	781,816.8	0.00	1.00
07/30/2026 05:00	-1	1.7	8.8	14.3	6.8	781,816.8	0.00	1.00
07/30/2026 06:00	-1	1.7	8.8	14.3	7.8	781,194.4	0.00	1.00
07/30/2026 07:00	-1	1.7	8.7	14.3	8.0	780,364.4	0.00	1.00
07/30/2026 08:00	-1	1.7	8.7	14.4	8.3	791,105.9	0.00	1.00
07/30/2026 09:00	-1	1.7	8.7	14.4	8.3	790,473.9	0.00	1.00
07/30/2026 10:00	-1	1.7	8.7	14.4	8.1	789,209.8	0.00	1.00
07/30/2026 11:00	-1	1.6	8.6	14.4	7.3	788,367.1	0.00	1.00
07/30/2026 12:00	-1	1.6	8.4	14.5	7.2	800,257.4	0.00	1.00
07/30/2026 13:00	-1	1.7	8.3	14.5	7.8	799,615.5	0.00	1.00
07/30/2026 14:00	0	1.6	8.0	14.5	9.9	901,894.3	0.00	1.00
07/30/2026 15:00	-1	1.6	8.2	14.5	8.6	844,763.7	0.00	1.00
07/30/2026 16:00	-1	1.6	7.7	14.5	7.4	832,995.2	0.00	1.00
07/30/2026 17:00	-1	1.7	7.9	14.4	8.2	893,075.4	0.00	1.00
07/30/2026 18:00	-1	1.6	7.8	14.5	9.8	980,422.3	0.00	1.00
07/30/2026 19:00	-1	1.6	8.6	14.5	9.6	842,623.9	0.00	1.00
07/30/2026 20:00	-1	1.7	8.8	14.4	9.0	788,788.4	0.00	1.00
07/30/2026 21:00	-1	1.7	8.9	14.4	9.3	806,485.6	0.00	1.00
07/30/2026 22:00	-1	1.7	8.8	14.4	9.1	830,713.9	0.00	1.00
07/30/2026 23:00	-1	1.7	9.1	14.4	8.5	794,898.2	0.00	1.00
Average/Sum#:	-1	1.7	8.6	14.4	8.1	813,629.7	0.00 #	24.00 #
Minimum:	-2	1.6	7.7	14.3	6.5	780,364.4	0.00	1.00
Maximum:	0	1.7	9.1	14.5	9.9	980,422.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/31/2026 00:00	-1	1.7	9.0	14.3	7.7	779,327.0	0.00	1.00
07/31/2026 01:00	-1	1.7	8.9	14.3	7.0	780,156.9	0.00	1.00
07/31/2026 02:00	-2	1.7	9.1	14.3	6.7	780,779.4	0.00	1.00
07/31/2026 03:00	-2	1.7	9.0	14.3	6.3	781,609.3	0.00	1.00
07/31/2026 04:00	-2	1.7	8.9	14.3	6.9	823,937.0	0.00	1.00
07/31/2026 05:00	-2	1.7	9.0	14.3	6.7	783,061.8	0.00	1.00
07/31/2026 06:00	-1	1.7	8.8	14.3	7.6	782,439.3	0.00	1.00
07/31/2026 07:00	-1	1.7	8.8	14.3	7.9	782,439.3	0.00	1.00
07/31/2026 08:00	-1	1.7	8.7	14.4	7.8	793,634.1	0.00	1.00
07/31/2026 09:00	-1	1.7	8.7	14.4	8.1	792,370.0	0.00	1.00
07/31/2026 10:00	-1	1.7	8.7	14.4	7.8	790,895.3	0.00	1.00
07/31/2026 11:00	-1	1.7	8.3	14.5	7.5	833,851.1	0.00	1.00
07/31/2026 12:00	-1	1.6	7.7	14.5	8.6	990,051.0	0.00	1.00
07/31/2026 13:00	-1	1.6	7.6	14.5	9.5	987,483.4	0.00	1.00
07/31/2026 14:00	0	1.6	7.9	14.5	11.8	996,256.2	0.00	1.00
07/31/2026 15:00	1	1.9	10.8	13.5	18.6	1,026,143.0	0.00	1.00
07/31/2026 16:00	2	2.0	11.6	13.2	21.5	1,032,225.9	0.00	1.00
07/31/2026 17:00	3	2.1	12.7	12.8	25.0	1,038,733.8	0.00	1.00
07/31/2026 18:00	5	2.2	13.3	12.2	31.4	1,037,929.2	0.00	1.00
07/31/2026 19:00	1	1.8	10.6	13.6	16.6	1,021,815.7	0.00	1.00
07/31/2026 20:00	1	1.9	11.1	13.5	18.8	989,316.6	0.00	1.00
07/31/2026 21:00	1	1.9	10.9	13.6	18.1	1,000,992.9	0.00	1.00
07/31/2026 22:00	1	1.8	10.5	13.8	17.2	1,019,546.1	0.00	1.00
07/31/2026 23:00	-1	1.7	8.6	14.3	7.8	800,698.3	0.00	1.00
Average/Sum#:	0	1.8	9.6	14.0	12.2	893,570.5	0.00 #	24.00 #
Minimum:	-2	1.6	7.6	12.2	6.3	779,327.0	0.00	1.00
Maximum:	5	2.2	13.3	14.5	31.4	1,038,733.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/01/2026 00:00	-1	1.7	8.5	14.3	7.2	782,024.3	0.00	1.00
08/01/2026 01:00	-1	1.7	8.5	14.3	7.0	782,439.3	0.00	1.00
08/01/2026 02:00	-2	1.7	8.8	14.3	6.5	782,854.3	0.00	1.00
08/01/2026 03:00	-2	1.7	8.8	14.3	6.0	783,476.7	0.00	1.00
08/01/2026 04:00	-2	1.7	8.7	14.3	5.8	784,099.2	0.00	1.00
08/01/2026 05:00	-2	1.7	8.7	14.3	6.1	783,891.7	0.00	1.00
08/01/2026 06:00	-1	1.7	8.7	14.3	7.0	784,514.2	0.00	1.00
08/01/2026 07:00	-1	1.7	8.6	14.3	7.5	783,061.8	0.00	1.00
08/01/2026 08:00	-1	1.7	8.6	14.3	7.5	782,024.3	0.00	1.00
08/01/2026 09:00	-1	1.7	8.6	14.4	7.8	792,159.3	0.00	1.00
08/01/2026 10:00	-1	1.7	8.5	14.4	7.4	792,159.3	0.00	1.00
08/01/2026 11:00	-1	1.7	8.4	14.5	7.4	804,322.9	0.00	1.00
08/01/2026 12:00	-1	1.6	8.2	14.5	7.5	802,397.1	0.00	1.00
08/01/2026 13:00	-1	1.6	7.9	14.5	7.6	799,401.5	0.00	1.00
08/01/2026 14:00	0	1.6	7.7	14.5	9.7	857,602.0	0.00	1.00
08/01/2026 15:00	2	1.8	10.4	13.7	19.2	1,013,944.6	0.00	1.00
08/01/2026 16:00	2	1.9	11.2	13.4	18.6	985,985.6	0.00	1.00
08/01/2026 17:00	2	2.1	12.0	12.9	21.9	1,015,599.4	0.00	1.00
08/01/2026 18:00	6	2.2	12.9	12.1	30.6	1,020,221.2	0.00	1.00
08/01/2026 19:00	3	2.1	12.7	12.7	24.0	1,023,394.2	0.00	1.00
08/01/2026 20:00	1	1.8	9.7	13.8	15.2	1,016,267.2	0.00	1.00
08/01/2026 21:00	2	1.9	11.3	13.3	19.1	977,696.9	0.00	1.00
08/01/2026 22:00	1	1.9	11.0	13.4	18.5	985,437.8	0.00	1.00
08/01/2026 23:00	-1	1.6	8.2	14.5	9.8	922,221.7	0.00	1.00
Average/Sum#:	0	1.8	9.4	14.0	11.9	869,049.9	0.00 #	24.00 #
Minimum:	-2	1.6	7.7	12.1	5.8	782,024.3	0.00	1.00
Maximum:	6	2.2	12.9	14.5	30.6	1,023,394.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/02/2026 00:00	-1	1.7	8.4	14.4	8.1	798,901.1	0.00	1.00
08/02/2026 01:00	-1	1.7	8.4	14.4	8.2	791,105.9	0.00	1.00
08/02/2026 02:00	-1	1.7	8.8	14.3	8.4	779,949.4	0.00	1.00
08/02/2026 03:00	-1	1.7	8.7	14.3	7.8	780,986.9	0.00	1.00
08/02/2026 04:00	-1	1.7	8.7	14.3	7.9	780,364.4	0.00	1.00
08/02/2026 05:00	-1	1.7	8.7	14.3	7.4	781,194.4	0.00	1.00
08/02/2026 06:00	-1	1.7	8.6	14.3	7.8	780,779.4	0.00	1.00
08/02/2026 07:00	-1	1.7	8.6	14.4	8.2	790,895.3	0.00	1.00
08/02/2026 08:00	-1	1.7	8.6	14.4	8.1	788,788.4	0.00	1.00
08/02/2026 09:00	-1	1.6	8.5	14.5	8.2	799,829.4	0.00	1.00
08/02/2026 10:00	-1	1.7	8.4	14.5	7.3	800,043.4	0.00	1.00
08/02/2026 11:00	-1	1.7	8.1	14.5	7.0	798,331.6	0.00	1.00
08/02/2026 12:00	-1	1.6	7.8	14.5	6.6	796,405.9	0.00	1.00
08/02/2026 13:00	-1	1.6	7.5	14.5	7.9	857,602.0	0.00	1.00
08/02/2026 14:00	1	1.9	10.2	13.7	16.7	1,007,287.7	0.00	1.00
08/02/2026 15:00	1	1.8	10.2	13.7	16.4	1,006,336.7	0.00	1.00
08/02/2026 16:00	1	1.9	11.2	13.4	18.3	1,012,826.3	0.00	1.00
08/02/2026 17:00	1	1.9	10.3	13.6	16.5	1,008,496.6	0.00	1.00
08/02/2026 18:00	1	1.9	10.1	13.6	17.3	1,002,681.3	0.00	1.00
08/02/2026 19:00	3	2.1	13.7	12.7	22.5	921,188.4	0.00	1.00
08/02/2026 20:00	2	2.1	13.0	12.9	21.4	936,001.6	0.00	1.00
08/02/2026 21:00	2	2.0	12.2	13.1	20.0	955,788.0	0.00	1.00
08/02/2026 22:00	0	1.7	8.7	14.4	12.1	972,502.0	0.00	1.00
08/02/2026 23:00	0	1.7	8.7	14.4	11.5	929,944.5	0.00	1.00
Average/Sum#:	0	1.8	9.4	14.0	11.7	869,926.3	0.00 #	24.00 #
Minimum:	-1	1.6	7.5	12.7	6.6	779,949.4	0.00	1.00
Maximum:	3	2.1	13.7	14.5	22.5	1,012,826.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/03/2026 00:00	-1	1.7	8.3	14.4	8.1	790,473.9	0.00	1.00
08/03/2026 01:00	-1	1.7	8.5	14.4	9.6	855,574.2	0.00	1.00
08/03/2026 02:00	-1	1.7	8.8	14.3	8.2	777,252.1	0.00	1.00
08/03/2026 03:00	-1	1.7	8.7	14.4	8.1	789,631.2	0.00	1.00
08/03/2026 04:00	-1	1.7	8.4	14.5	9.7	923,505.6	0.00	1.00
08/03/2026 05:00	-1	1.6	8.7	14.4	9.0	884,016.1	0.00	1.00
08/03/2026 06:00	-1	1.7	8.6	14.3	7.9	779,534.5	0.00	1.00
08/03/2026 07:00	-1	1.7	8.6	14.4	8.0	789,209.8	0.00	1.00
08/03/2026 08:00	-1	1.7	8.6	14.4	8.1	787,735.0	0.00	1.00
08/03/2026 09:00	-1	1.6	8.5	14.5	8.0	799,401.5	0.00	1.00
08/03/2026 10:00	-1	1.6	8.3	14.5	7.2	799,187.5	0.00	1.00
08/03/2026 11:00	-1	1.6	7.8	14.5	6.6	797,047.8	0.00	1.00
08/03/2026 12:00	-1	1.6	7.5	14.5	7.9	868,942.6	0.00	1.00
08/03/2026 13:00	-1	1.7	7.9	14.4	9.2	894,128.8	0.00	1.00
08/03/2026 14:00	1	1.9	10.5	13.5	17.7	1,007,267.2	0.00	1.00
08/03/2026 15:00	1	1.8	10.3	13.6	17.1	1,007,933.9	0.00	1.00
08/03/2026 16:00	3	2.0	12.0	13.0	22.7	1,010,773.9	0.00	1.00
08/03/2026 17:00	3	2.1	12.1	12.9	23.8	1,021,419.4	0.00	1.00
08/03/2026 18:00	7	2.3	13.0	11.9	33.3	1,014,895.6	0.00	1.00
08/03/2026 19:00	5	2.2	13.3	12.3	28.7	1,018,947.3	0.00	1.00
08/03/2026 20:00	3	2.1	12.5	12.7	25.0	1,027,736.3	0.00	1.00
08/03/2026 21:00	2	2.0	11.7	13.2	19.5	993,455.1	0.00	1.00
08/03/2026 22:00	-1	1.6	8.5	14.4	10.3	911,404.6	0.00	1.00
08/03/2026 23:00	0	1.6	8.4	14.6	11.8	978,812.4	0.00	1.00
Average/Sum#:	0	1.8	9.6	13.9	13.6	897,011.9	0.00 #	24.00 #
Minimum:	-1	1.6	7.5	11.9	6.6	777,252.1	0.00	1.00
Maximum:	7	2.3	13.3	14.6	33.3	1,027,736.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/04/2026 00:00	-1	1.7	8.4	14.4	8.8	826,078.9	0.00	1.00
08/04/2026 01:00	-1	1.7	8.5	14.4	8.2	790,473.9	0.00	1.00
08/04/2026 02:00	-1	1.7	8.8	14.3	8.1	779,119.5	0.00	1.00
08/04/2026 03:00	-1	1.7	8.7	14.4	8.5	833,031.4	0.00	1.00
08/04/2026 04:00	-1	1.6	8.5	14.4	9.5	916,250.3	0.00	1.00
08/04/2026 05:00	-1	1.6	8.7	14.4	9.2	883,384.1	0.00	1.00
08/04/2026 06:00	-1	1.7	8.6	14.4	8.9	852,414.0	0.00	1.00
08/04/2026 07:00	-1	1.7	8.7	14.3	8.1	778,704.5	0.00	1.00
08/04/2026 08:00	-1	1.7	8.6	14.3	8.4	778,082.0	0.00	1.00
08/04/2026 09:00	-1	1.7	8.5	14.3	8.3	777,874.5	0.00	1.00
08/04/2026 10:00	-1	1.7	8.4	14.4	7.4	794,476.8	0.00	1.00
08/04/2026 11:00	-1	1.6	7.9	14.5	6.7	847,545.3	0.00	1.00
08/04/2026 12:00	-1	1.6	7.7	14.4	7.4	904,873.5	0.00	1.00
08/04/2026 13:00	-1	1.7	8.0	14.5	10.2	971,649.4	0.00	1.00
08/04/2026 14:00	2	2.0	11.1	13.2	19.6	1,005,548.8	0.00	1.00
08/04/2026 15:00	3	2.0	11.3	13.1	21.5	1,014,778.6	0.00	1.00
08/04/2026 16:00	1	1.9	11.0	13.3	18.3	1,009,950.5	0.00	1.00
08/04/2026 17:00	2	1.9	11.3	13.2	20.6	965,888.8	0.00	1.00
08/04/2026 18:00	4	2.2	12.8	12.4	26.2	1,009,185.2	0.00	1.00
08/04/2026 19:00	0	1.8	9.8	13.8	15.0	1,015,881.4	0.00	1.00
08/04/2026 20:00	1	1.8	10.2	13.7	17.2	1,015,656.4	0.00	1.00
08/04/2026 21:00	1	1.9	10.5	13.6	17.8	1,005,870.3	0.00	1.00
08/04/2026 22:00	-1	1.7	8.3	14.3	8.0	803,188.2	0.00	1.00
08/04/2026 23:00	-1	1.6	8.0	14.5	9.6	959,880.9	0.00	1.00
Average/Sum#:	0	1.8	9.3	14.0	12.1	897,491.1	0.00 #	24.00 #
Minimum:	-1	1.6	7.7	12.4	6.7	777,874.5	0.00	1.00
Maximum:	4	2.2	12.8	14.5	26.2	1,015,881.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/05/2026 00:00	-1	1.6	8.4	14.4	8.9	891,179.3	0.00	1.00
08/05/2026 01:00	-1	1.7	8.5	14.3	6.6	783,891.7	0.00	1.00
08/05/2026 02:00	-2	1.7	8.9	14.3	6.8	784,306.7	0.00	1.00
08/05/2026 03:00	-1	1.7	8.8	14.3	6.5	784,721.7	0.00	1.00
08/05/2026 04:00	-2	1.7	8.8	14.3	6.4	796,963.5	0.00	1.00
08/05/2026 05:00	-2	1.7	8.8	14.3	6.2	785,344.1	0.00	1.00
08/05/2026 06:00	-1	1.7	8.7	14.3	7.3	816,882.4	0.00	1.00
08/05/2026 07:00	-1	1.7	8.7	14.3	7.6	784,306.7	0.00	1.00
08/05/2026 08:00	-1	1.7	8.6	14.3	8.3	783,891.7	0.00	1.00
08/05/2026 09:00	-1	1.7	8.5	14.3	8.1	783,061.8	0.00	1.00
08/05/2026 10:00	-1	1.7	8.5	14.4	7.6	793,844.8	0.00	1.00
08/05/2026 11:00	-1	1.7	8.4	14.4	6.8	792,580.7	0.00	1.00
08/05/2026 12:00	-1	1.6	8.1	14.5	7.1	840,270.2	0.00	1.00
08/05/2026 13:00	-1	1.7	7.8	14.4	6.6	859,787.8	0.00	1.00
08/05/2026 14:00	1	1.8	9.1	13.9	14.6	1,025,894.5	0.00	1.00
08/05/2026 15:00	1	1.8	9.7	13.7	15.6	1,015,846.6	0.00	1.00
08/05/2026 16:00	2	2.0	11.2	13.2	19.7	1,029,913.8	0.00	1.00
08/05/2026 17:00	1	1.9	10.8	13.4	17.9	1,023,781.7	0.00	1.00
08/05/2026 18:00	1	1.8	9.8	13.8	15.3	1,024,560.9	0.00	1.00
08/05/2026 19:00	1	1.9	11.0	13.6	19.0	1,006,433.1	0.00	1.00
08/05/2026 20:00	1	1.9	11.1	13.5	18.8	998,569.5	0.00	1.00
08/05/2026 21:00	1	1.8	10.5	13.7	17.7	1,011,852.5	0.00	1.00
08/05/2026 22:00	0	1.6	8.0	14.5	10.6	981,492.1	0.00	1.00
08/05/2026 23:00	-1	1.6	8.3	14.5	10.2	946,186.7	0.00	1.00
Average/Sum#:	0	1.7	9.1	14.1	10.8	889,398.5	0.00 #	24.00 #
Minimum:	-2	1.6	7.8	13.2	6.2	783,061.8	0.00	1.00
Maximum:	2	2.0	11.2	14.5	19.7	1,029,913.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/06/2026 00:00	-1	1.7	8.6	14.4	8.4	823,340.1	0.00	1.00
08/06/2026 01:00	-1	1.7	8.7	14.4	7.9	792,791.4	0.00	1.00
08/06/2026 02:00	-1	1.7	9.1	14.3	7.5	780,986.9	0.00	1.00
08/06/2026 03:00	-1	1.7	8.9	14.3	6.9	781,401.9	0.00	1.00
08/06/2026 04:00	-2	1.7	8.8	14.3	6.3	790,738.8	0.00	1.00
08/06/2026 05:00	-1	1.7	8.8	14.3	7.3	828,294.3	0.00	1.00
08/06/2026 06:00	-1	1.7	8.8	14.3	7.6	783,061.8	0.00	1.00
08/06/2026 07:00	-1	1.7	8.7	14.3	8.1	782,231.8	0.00	1.00
08/06/2026 08:00	-1	1.7	8.6	14.3	8.7	781,401.9	0.00	1.00
08/06/2026 09:00	-1	1.7	8.6	14.4	8.0	792,580.7	0.00	1.00
08/06/2026 10:00	-1	1.7	8.6	14.4	7.4	791,105.9	0.00	1.00
08/06/2026 11:00	-1	1.7	8.5	14.4	7.2	789,420.5	0.00	1.00
08/06/2026 12:00	-1	1.6	8.4	14.5	7.4	800,899.3	0.00	1.00
08/06/2026 13:00	-1	1.6	8.4	14.5	8.4	842,837.9	0.00	1.00
08/06/2026 14:00	3	2.1	13.6	12.8	24.1	914,471.2	0.00	1.00
08/06/2026 15:00	5	2.2	14.4	12.5	27.7	903,005.0	0.00	1.00
08/06/2026 16:00	5	2.2	13.7	12.4	27.3	923,797.6	0.00	1.00
08/06/2026 17:00	4	2.2	13.7	12.3	29.5	1,028,342.2	0.00	1.00
08/06/2026 18:00	3	2.1	13.3	12.7	26.3	1,039,760.5	0.00	1.00
08/06/2026 19:00	1	1.8	10.3	13.8	16.9	1,032,276.0	0.00	1.00
08/06/2026 20:00	2	1.9	11.4	13.4	19.7	995,662.8	0.00	1.00
08/06/2026 21:00	2	2.0	12.3	13.2	22.1	1,009,105.7	0.00	1.00
08/06/2026 22:00	-1	1.6	8.2	14.6	10.9	997,288.7	0.00	1.00
08/06/2026 23:00	0	1.6	8.1	14.5	10.7	979,138.4	0.00	1.00
Average/Sum#:	0	1.8	10.0	13.9	13.4	874,330.9	0.00 #	24.00 #
Minimum:	-2	1.6	8.1	12.3	6.3	780,986.9	0.00	1.00
Maximum:	5	2.2	14.4	14.6	29.5	1,039,760.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/07/2026 00:00	-1	1.6	8.1	14.5	10.4	977,854.6	0.00	1.00
08/07/2026 01:00	-1	1.6	8.2	14.5	10.1	979,566.4	0.00	1.00
08/07/2026 02:00	-1	1.6	8.5	14.5	9.9	979,780.4	0.00	1.00
08/07/2026 03:00	-1	1.7	8.9	14.3	7.5	833,689.0	0.00	1.00
08/07/2026 04:00	-1	1.7	8.4	14.5	9.3	972,291.3	0.00	1.00
08/07/2026 05:00	-1	1.7	8.4	14.5	9.6	978,924.5	0.00	1.00
08/07/2026 06:00	-1	1.7	8.8	14.3	8.6	827,671.8	0.00	1.00
08/07/2026 07:00	-1	1.7	8.6	14.3	8.2	783,269.2	0.00	1.00
08/07/2026 08:00	-1	1.7	8.5	14.4	8.3	793,844.8	0.00	1.00
08/07/2026 09:00	-1	1.7	8.5	14.4	8.2	792,791.4	0.00	1.00
08/07/2026 10:00	-1	1.6	8.5	14.4	7.5	791,527.3	0.00	1.00
08/07/2026 11:00	-1	1.6	8.2	14.5	7.6	868,300.6	0.00	1.00
08/07/2026 12:00	-1	1.6	7.9	14.5	7.5	829,785.6	0.00	1.00
08/07/2026 13:00	-1	1.6	7.5	14.5	8.0	938,269.7	0.00	1.00
08/07/2026 14:00	3	2.0	11.7	13.2	21.7	973,536.2	0.00	1.00
08/07/2026 15:00	6	2.2	13.5	12.3	27.7	892,992.1	0.00	1.00
08/07/2026 16:00	5	2.2	13.1	12.4	25.9	908,653.4	0.00	1.00
08/07/2026 17:00	1	2.0	11.3	13.2	18.9	1,024,400.6	0.00	1.00
08/07/2026 18:00	3	2.2	13.5	12.5	26.4	1,034,078.4	0.00	1.00
08/07/2026 19:00	1	1.9	10.9	13.4	17.3	1,025,425.0	0.00	1.00
08/07/2026 20:00	1	1.9	10.0	13.7	17.2	1,036,007.6	0.00	1.00
08/07/2026 21:00	1	1.9	11.0	13.5	18.6	1,010,783.2	0.00	1.00
08/07/2026 22:00	0	1.6	8.5	14.5	11.6	987,911.3	0.00	1.00
08/07/2026 23:00	0	1.6	8.1	14.6	11.3	1,023,373.0	0.00	1.00
Average/Sum#:	0	1.8	9.5	14.0	13.2	927,697.0	0.00 #	24.00 #
Minimum:	-1	1.6	7.5	12.3	7.5	783,269.2	0.00	1.00
Maximum:	6	2.2	13.5	14.6	27.7	1,036,007.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/08/2026 00:00	-1	1.6	8.2	14.6	11.1	1,023,373.0	0.00	1.00
08/08/2026 01:00	-1	1.6	8.6	14.4	8.9	867,583.0	0.00	1.00
08/08/2026 02:00	-1	1.7	8.7	14.3	7.1	786,589.1	0.00	1.00
08/08/2026 03:00	-1	1.7	8.7	14.3	6.8	789,078.9	0.00	1.00
08/08/2026 04:00	-1	1.7	8.4	14.5	9.2	971,435.4	0.00	1.00
08/08/2026 05:00	-1	1.6	8.6	14.4	8.5	902,134.6	0.00	1.00
08/08/2026 06:00	-1	1.7	8.6	14.3	6.8	788,041.5	0.00	1.00
08/08/2026 07:00	-1	1.7	8.5	14.3	7.8	787,211.5	0.00	1.00
08/08/2026 08:00	-1	1.7	8.5	14.3	8.3	788,871.4	0.00	1.00
08/08/2026 09:00	-1	1.7	8.5	14.4	7.9	801,850.6	0.00	1.00
08/08/2026 10:00	-1	1.7	8.4	14.4	7.7	800,165.2	0.00	1.00
08/08/2026 11:00	-1	1.6	8.4	14.4	7.2	797,637.0	0.00	1.00
08/08/2026 12:00	-1	1.6	8.0	14.5	6.6	807,746.4	0.00	1.00
08/08/2026 13:00	-1	1.7	8.3	14.3	8.5	828,709.2	0.00	1.00
08/08/2026 14:00	4	2.2	13.4	12.4	24.9	908,975.6	0.00	1.00
08/08/2026 15:00	4	2.1	12.0	12.7	22.5	925,697.5	0.00	1.00
08/08/2026 16:00	0	1.8	10.0	13.6	14.9	1,015,437.6	0.00	1.00
08/08/2026 17:00	1	1.9	10.2	13.5	16.1	1,017,075.2	0.00	1.00
08/08/2026 18:00	1	1.9	9.9	13.6	15.2	1,015,812.7	0.00	1.00
08/08/2026 19:00	1	1.9	10.8	13.4	17.8	984,342.2	0.00	1.00
08/08/2026 20:00	1	1.9	10.7	13.5	17.3	993,943.0	0.00	1.00
08/08/2026 21:00	1	1.9	10.5	13.6	17.2	1,006,245.5	0.00	1.00
08/08/2026 22:00	-1	1.6	7.9	14.6	10.3	1,002,070.9	0.00	1.00
08/08/2026 23:00	-1	1.6	8.2	14.5	9.9	922,435.7	0.00	1.00
Average/Sum#:	0	1.8	9.3	14.0	11.6	897,185.9	0.00 #	24.00 #
Minimum:	-1	1.6	7.9	12.4	6.6	786,589.1	0.00	1.00
Maximum:	4	2.2	13.4	14.6	24.9	1,023,373.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/09/2026 00:00	-1	1.7	8.4	14.4	7.7	795,530.2	0.00	1.00
08/09/2026 01:00	-1	1.7	8.4	14.3	7.4	784,306.7	0.00	1.00
08/09/2026 02:00	-1	1.7	8.7	14.3	7.3	784,929.2	0.00	1.00
08/09/2026 03:00	-1	1.7	8.6	14.3	6.9	785,551.6	0.00	1.00
08/09/2026 04:00	-1	1.7	8.6	14.3	6.9	793,228.7	0.00	1.00
08/09/2026 05:00	-1	1.6	8.5	14.4	8.6	897,921.0	0.00	1.00
08/09/2026 06:00	-1	1.7	8.5	14.3	7.4	785,551.6	0.00	1.00
08/09/2026 07:00	-1	1.7	8.5	14.3	7.4	784,929.2	0.00	1.00
08/09/2026 08:00	-1	1.7	8.4	14.4	7.8	795,319.5	0.00	1.00
08/09/2026 09:00	-1	1.6	8.4	14.4	7.4	793,844.8	0.00	1.00
08/09/2026 10:00	-1	1.7	8.2	14.5	7.1	805,606.7	0.00	1.00
08/09/2026 11:00	-1	1.6	8.0	14.5	6.7	804,108.9	0.00	1.00
08/09/2026 12:00	-1	1.6	7.3	14.5	6.4	823,580.4	0.00	1.00
08/09/2026 13:00	-1	1.6	7.4	14.5	8.4	956,029.4	0.00	1.00
08/09/2026 14:00	2	1.9	10.8	13.3	18.8	980,760.1	0.00	1.00
08/09/2026 15:00	4	2.2	13.3	12.4	27.4	1,021,751.7	0.00	1.00
08/09/2026 16:00	5	2.2	13.1	12.2	28.6	1,013,059.2	0.00	1.00
08/09/2026 17:00	4	2.2	12.3	12.5	24.7	1,016,308.5	0.00	1.00
08/09/2026 18:00	4	2.2	12.7	12.3	27.1	1,019,265.8	0.00	1.00
08/09/2026 19:00	1	1.8	10.1	13.6	15.7	1,009,622.2	0.00	1.00
08/09/2026 20:00	2	2.0	11.5	13.2	19.2	971,579.9	0.00	1.00
08/09/2026 21:00	1	1.9	10.9	13.5	18.0	993,943.0	0.00	1.00
08/09/2026 22:00	-1	1.6	8.6	14.4	8.8	822,708.0	0.00	1.00
08/09/2026 23:00	-1	1.7	8.6	14.4	8.3	793,212.7	0.00	1.00
Average/Sum#:	0	1.8	9.5	13.9	12.5	876,360.4	0.00 #	24.00 #
Minimum:	-1	1.6	7.3	12.2	6.4	784,306.7	0.00	1.00
Maximum:	5	2.2	13.3	14.5	28.6	1,021,751.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/10/2026 00:00	-1	1.7	8.6	14.3	7.9	782,854.3	0.00	1.00
08/10/2026 01:00	-1	1.7	8.6	14.3	7.4	783,476.7	0.00	1.00
08/10/2026 02:00	-1	1.7	8.8	14.3	7.1	783,684.2	0.00	1.00
08/10/2026 03:00	-1	1.7	8.7	14.3	7.0	784,099.2	0.00	1.00
08/10/2026 04:00	-1	1.7	8.5	14.4	8.1	883,805.4	0.00	1.00
08/10/2026 05:00	-1	1.7	8.8	14.3	7.0	785,551.6	0.00	1.00
08/10/2026 06:00	-1	1.7	8.5	14.4	8.8	872,850.0	0.00	1.00
08/10/2026 07:00	-1	1.7	8.6	14.3	8.1	784,514.2	0.00	1.00
08/10/2026 08:00	-1	1.7	8.5	14.4	8.3	795,108.9	0.00	1.00
08/10/2026 09:00	-1	1.7	8.5	14.4	8.0	794,476.8	0.00	1.00
08/10/2026 10:00	-1	1.7	8.4	14.4	7.3	794,055.5	0.00	1.00
08/10/2026 11:00	-1	1.6	8.4	14.5	7.3	805,178.7	0.00	1.00
08/10/2026 12:00	-1	1.6	8.4	14.5	8.2	846,689.4	0.00	1.00
08/10/2026 13:00	-1	1.6	7.9	14.4	8.0	909,297.8	0.00	1.00
08/10/2026 14:00	-1	1.7	7.7	14.4	7.6	886,755.0	0.00	1.00
08/10/2026 15:00	1	1.8	9.8	13.7	15.9	1,030,301.7	0.00	1.00
08/10/2026 16:00	3	2.1	12.0	12.8	23.9	1,032,140.2	0.00	1.00
08/10/2026 17:00	4	2.2	13.1	12.5	27.1	1,043,207.9	0.00	1.00
08/10/2026 18:00	3	2.0	13.0	12.7	24.0	1,037,255.5	0.00	1.00
08/10/2026 19:00	1	1.9	11.3	13.3	18.9	1,033,735.2	0.00	1.00
08/10/2026 20:00	1	1.8	10.2	13.8	16.7	1,046,741.7	0.00	1.00
08/10/2026 21:00	1	1.9	11.1	13.5	19.2	1,052,976.3	0.00	1.00
08/10/2026 22:00	0	1.6	8.0	14.5	10.6	986,413.5	0.00	1.00
08/10/2026 23:00	-1	1.6	8.5	14.4	8.6	843,986.8	0.00	1.00
Average/Sum#:	0	1.8	9.3	14.0	11.7	891,631.5	0.00 #	24.00 #
Minimum:	-1	1.6	7.7	12.5	7.0	782,854.3	0.00	1.00
Maximum:	4	2.2	13.1	14.5	27.1	1,052,976.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/11/2026 00:00	-1	1.7	8.4	14.4	8.4	858,313.1	0.00	1.00
08/11/2026 01:00	-1	1.7	8.5	14.3	7.2	786,381.6	0.00	1.00
08/11/2026 02:00	-1	1.7	8.8	14.3	7.1	786,174.1	0.00	1.00
08/11/2026 03:00	-1	1.7	8.7	14.3	6.7	787,419.0	0.00	1.00
08/11/2026 04:00	-2	1.7	8.6	14.3	6.3	795,718.6	0.00	1.00
08/11/2026 05:00	-1	1.7	8.7	14.3	7.3	845,723.3	0.00	1.00
08/11/2026 06:00	-1	1.7	8.6	14.4	9.3	892,232.7	0.00	1.00
08/11/2026 07:00	-1	1.7	8.6	14.3	8.2	787,004.0	0.00	1.00
08/11/2026 08:00	-1	1.7	8.5	14.4	8.3	798,058.4	0.00	1.00
08/11/2026 09:00	-1	1.7	8.5	14.4	7.8	797,637.0	0.00	1.00
08/11/2026 10:00	-1	1.7	8.3	14.4	7.6	819,337.1	0.00	1.00
08/11/2026 11:00	-1	1.6	8.5	14.6	10.6	986,420.3	0.00	1.00
08/11/2026 12:00	-1	1.6	8.4	14.5	10.7	1,014,016.0	0.00	1.00
08/11/2026 13:00	1	1.9	11.0	13.5	18.2	1,047,424.6	0.00	1.00
08/11/2026 14:00	1	1.9	10.7	13.7	17.3	1,048,941.0	0.00	1.00
08/11/2026 15:00	1	1.8	10.3	13.7	17.2	1,040,762.5	0.00	1.00
08/11/2026 16:00	3	2.1	12.8	12.8	24.6	1,045,834.5	0.00	1.00
08/11/2026 17:00	5	2.2	13.2	12.3	30.6	1,048,883.5	0.00	1.00
08/11/2026 18:00	3	2.0	13.0	12.8	24.4	1,050,230.2	0.00	1.00
08/11/2026 19:00	3	2.1	12.9	12.8	24.5	1,045,665.4	0.00	1.00
08/11/2026 20:00	2	2.0	11.8	13.3	21.0	1,053,375.7	0.00	1.00
08/11/2026 21:00	-1	1.6	8.1	14.5	10.7	986,841.4	0.00	1.00
08/11/2026 22:00	-1	1.6	8.4	14.5	10.0	922,221.7	0.00	1.00
08/11/2026 23:00	-1	1.7	8.5	14.4	8.3	814,702.2	0.00	1.00
Average/Sum#:	0	1.8	9.7	14.0	13.0	919,138.2	0.00 #	24.00 #
Minimum:	-2	1.6	8.1	12.3	6.3	786,174.1	0.00	1.00
Maximum:	5	2.2	13.2	14.6	30.6	1,053,375.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/12/2026 00:00	-1	1.7	8.5	14.3	7.6	784,721.7	0.00	1.00
08/12/2026 01:00	-1	1.7	8.6	14.3	7.4	785,344.1	0.00	1.00
08/12/2026 02:00	-1	1.7	8.9	14.3	7.1	785,551.6	0.00	1.00
08/12/2026 03:00	-1	1.7	8.8	14.3	6.9	786,174.1	0.00	1.00
08/12/2026 04:00	-1	1.7	8.5	14.4	7.3	876,431.6	0.00	1.00
08/12/2026 05:00	-1	1.6	8.5	14.4	8.8	948,484.4	0.00	1.00
08/12/2026 06:00	-2	1.7	8.7	14.3	5.9	785,344.1	0.00	1.00
08/12/2026 07:00	-2	1.7	8.6	14.3	6.5	786,174.1	0.00	1.00
08/12/2026 08:00	-1	1.7	8.5	14.3	7.0	785,136.6	0.00	1.00
08/12/2026 09:00	-1	1.7	8.5	14.3	7.0	783,891.7	0.00	1.00
08/12/2026 10:00	-1	1.7	8.4	14.4	6.8	794,687.5	0.00	1.00
08/12/2026 11:00	-2	1.7	8.4	14.4	6.3	793,844.8	0.00	1.00
08/12/2026 12:00	-2	1.7	8.3	14.4	5.9	801,007.9	0.00	1.00
08/12/2026 13:00	0	1.8	9.4	13.9	13.5	1,033,328.5	0.00	1.00
08/12/2026 14:00	0	1.8	9.6	13.9	14.3	1,032,741.6	0.00	1.00
08/12/2026 15:00	0	1.8	9.7	13.9	15.4	1,031,372.2	0.00	1.00
08/12/2026 16:00	0	1.8	9.6	13.9	15.0	1,031,372.2	0.00	1.00
08/12/2026 17:00	0	1.8	9.7	14.0	15.1	1,043,938.0	0.00	1.00
08/12/2026 18:00	0	1.8	9.6	14.0	15.0	1,041,953.3	0.00	1.00
08/12/2026 19:00	0	1.7	9.5	14.1	15.6	1,052,442.9	0.00	1.00
08/12/2026 20:00	1	1.8	9.5	14.0	16.0	1,039,373.3	0.00	1.00
08/12/2026 21:00	-1	1.6	8.5	14.4	7.8	832,399.3	0.00	1.00
08/12/2026 22:00	-1	1.7	8.4	14.3	6.9	783,061.8	0.00	1.00
08/12/2026 23:00	-1	1.7	8.4	14.3	6.4	783,476.7	0.00	1.00
Average/Sum#:	-1	1.7	8.9	14.2	9.6	883,427.3	0.00 #	24.00 #
Minimum:	-2	1.6	8.3	13.9	5.9	783,061.8	0.00	1.00
Maximum:	1	1.8	9.7	14.4	16.0	1,052,442.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/13/2026 00:00	-2	1.7	8.5	14.3	5.8	783,891.7	0.00	1.00
08/13/2026 01:00	-2	1.7	8.5	14.3	5.6	784,721.7	0.00	1.00
08/13/2026 02:00	-2	1.7	8.8	14.3	5.2	785,966.6	0.00	1.00
08/13/2026 03:00	-2	1.7	8.7	14.3	5.0	787,004.0	0.00	1.00
08/13/2026 04:00	-2	1.7	8.7	14.3	4.5	787,626.5	0.00	1.00
08/13/2026 05:00	-2	1.7	8.6	14.2	4.4	776,688.5	0.00	1.00
08/13/2026 06:00	-2	1.7	8.6	14.3	5.0	788,249.0	0.00	1.00
08/13/2026 07:00	-2	1.7	8.6	14.3	5.4	787,419.0	0.00	1.00
08/13/2026 08:00	-1	1.7	8.5	14.3	7.1	785,759.1	0.00	1.00
08/13/2026 09:00	-1	1.7	8.4	14.3	6.7	784,929.2	0.00	1.00
08/13/2026 10:00	-1	1.7	8.3	14.3	6.7	783,476.7	0.00	1.00
08/13/2026 11:00	-1	1.7	8.3	14.3	6.7	782,231.8	0.00	1.00
08/13/2026 12:00	-1	1.7	8.2	14.4	7.5	852,414.0	0.00	1.00
08/13/2026 13:00	0	1.8	9.7	13.9	14.3	1,030,198.4	0.00	1.00
08/13/2026 14:00	0	1.8	10.2	13.8	15.2	1,018,581.7	0.00	1.00
08/13/2026 15:00	0	1.8	10.3	13.8	14.9	1,017,038.7	0.00	1.00
08/13/2026 16:00	0	1.8	10.1	13.9	15.0	1,027,655.2	0.00	1.00
08/13/2026 17:00	0	1.8	10.0	13.9	15.2	1,024,525.1	0.00	1.00
08/13/2026 18:00	0	1.8	9.9	14.0	15.1	1,035,007.0	0.00	1.00
08/13/2026 19:00	-1	1.7	8.2	14.3	6.4	793,021.2	0.00	1.00
08/13/2026 20:00	-1	1.7	8.2	14.3	6.1	784,514.2	0.00	1.00
08/13/2026 21:00	-2	1.7	8.2	14.3	5.8	784,929.2	0.00	1.00
08/13/2026 22:00	-2	1.7	8.3	14.3	5.5	785,344.1	0.00	1.00
08/13/2026 23:00	-2	1.7	8.3	14.3	5.2	785,344.1	0.00	1.00
Average/Sum#:	-1	1.7	8.8	14.2	8.1	848,189.0	0.00 #	24.00 #
Minimum:	-2	1.7	8.2	13.8	4.4	776,688.5	0.00	1.00
Maximum:	0	1.8	10.3	14.4	15.2	1,035,007.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/14/2026 00:00	-2	1.7	8.4	14.2	4.8	774,440.1	0.00	1.00
08/14/2026 01:00	-2	1.7	8.4	14.2	4.6	775,053.3	0.00	1.00
08/14/2026 02:00	-2	1.7	8.7	14.2	4.5	775,053.3	0.00	1.00
08/14/2026 03:00	-2	1.7	8.5	14.2	4.6	774,848.9	0.00	1.00
08/14/2026 04:00	-2	1.7	8.5	14.2	4.9	775,053.3	0.00	1.00
08/14/2026 05:00	-2	1.7	8.4	14.2	5.0	782,002.6	0.00	1.00
08/14/2026 06:00	-2	1.7	8.4	14.3	5.9	818,749.8	0.00	1.00
08/14/2026 07:00	-2	1.7	8.4	14.3	5.5	786,381.6	0.00	1.00
08/14/2026 08:00	-2	1.7	8.3	14.3	6.0	786,589.1	0.00	1.00
08/14/2026 09:00	-1	1.7	8.3	14.3	6.3	785,759.1	0.00	1.00
08/14/2026 10:00	-1	1.7	8.2	14.3	6.1	785,136.6	0.00	1.00
08/14/2026 11:00	-1	1.7	8.2	14.3	6.2	784,929.2	0.00	1.00
08/14/2026 12:00	-1	1.7	8.2	14.3	6.1	784,099.2	0.00	1.00
08/14/2026 13:00	-2	1.7	8.2	14.4	6.0	795,530.2	0.00	1.00
08/14/2026 14:00	-2	1.7	8.2	14.4	5.8	794,898.2	0.00	1.00
08/14/2026 15:00	-1	1.7	8.2	14.4	6.1	794,898.2	0.00	1.00
08/14/2026 16:00	-1	1.7	8.2	14.4	6.4	794,687.5	0.00	1.00
08/14/2026 17:00	-1	1.7	8.1	14.4	6.7	834,295.5	0.00	1.00
08/14/2026 18:00	-1	1.7	8.3	14.4	7.1	800,165.2	0.00	1.00
08/14/2026 19:00	-1	1.7	8.1	14.3	6.7	785,136.6	0.00	1.00
08/14/2026 20:00	-1	1.7	8.2	14.3	6.5	787,004.0	0.00	1.00
08/14/2026 21:00	-1	1.7	8.2	14.3	6.1	787,834.0	0.00	1.00
08/14/2026 22:00	-2	1.7	8.2	14.3	5.4	788,871.4	0.00	1.00
08/14/2026 23:00	-2	1.7	8.3	14.2	4.9	777,506.0	0.00	1.00
Average/Sum#:	-2	1.7	8.3	14.3	5.8	788,705.1	0.00 #	24.00 #
Minimum:	-2	1.7	8.1	14.2	4.5	774,440.1	0.00	1.00
Maximum:	-1	1.7	8.7	14.4	7.1	834,295.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/15/2026 00:00	-2	1.7	8.4	14.2	4.8	777,914.8	0.00	1.00
08/15/2026 01:00	-2	1.7	8.4	14.2	4.4	778,323.6	0.00	1.00
08/15/2026 02:00	-2	1.7	8.7	14.2	4.4	778,528.0	0.00	1.00
08/15/2026 03:00	-2	1.7	8.6	14.2	4.7	776,279.7	0.00	1.00
08/15/2026 04:00	-2	1.7	8.6	14.2	4.9	774,440.1	0.00	1.00
08/15/2026 05:00	-2	1.7	8.5	14.2	5.0	773,418.2	0.00	1.00
08/15/2026 06:00	-2	1.7	8.4	14.2	5.3	773,009.4	0.00	1.00
08/15/2026 07:00	-2	1.7	8.4	14.2	5.9	772,396.2	0.00	1.00
08/15/2026 08:00	-1	1.7	8.3	14.3	7.0	783,476.7	0.00	1.00
08/15/2026 09:00	-1	1.7	8.2	14.3	6.6	784,099.2	0.00	1.00
08/15/2026 10:00	-1	1.7	8.2	14.3	6.7	784,099.2	0.00	1.00
08/15/2026 11:00	-2	1.7	8.1	14.4	5.8	795,108.9	0.00	1.00
08/15/2026 12:00	-2	1.7	8.1	14.4	5.7	795,108.9	0.00	1.00
08/15/2026 13:00	-2	1.7	8.1	14.4	5.5	794,266.1	0.00	1.00
08/15/2026 14:00	-2	1.7	8.0	14.4	5.9	794,266.1	0.00	1.00
08/15/2026 15:00	-1	1.7	8.1	14.4	6.6	794,055.5	0.00	1.00
08/15/2026 16:00	-1	1.6	8.1	14.5	7.1	850,113.0	0.00	1.00
08/15/2026 17:00	-1	1.6	8.1	14.5	7.8	887,344.2	0.00	1.00
08/15/2026 18:00	-2	1.6	8.4	14.4	6.7	814,912.8	0.00	1.00
08/15/2026 19:00	-1	1.7	8.2	14.4	7.4	844,408.1	0.00	1.00
08/15/2026 20:00	-1	1.7	8.2	14.3	6.6	786,381.6	0.00	1.00
08/15/2026 21:00	-1	1.7	7.8	14.5	9.3	985,771.6	0.00	1.00
08/15/2026 22:00	-1	1.6	8.0	14.5	9.1	965,444.2	0.00	1.00
08/15/2026 23:00	-1	1.6	7.9	14.5	9.2	987,911.3	0.00	1.00
Average/Sum#:	-2	1.7	8.2	14.3	6.4	818,794.9	0.00 #	24.00 #
Minimum:	-2	1.6	7.8	14.2	4.4	772,396.2	0.00	1.00
Maximum:	-1	1.7	8.7	14.5	9.3	987,911.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/16/2026 00:00	-1	1.6	8.0	14.4	8.8	965,760.2	0.00	1.00
08/16/2026 01:00	-2	1.7	8.3	14.3	5.4	784,099.2	0.00	1.00
08/16/2026 02:00	-2	1.7	8.5	14.3	5.2	784,514.2	0.00	1.00
08/16/2026 03:00	-2	1.7	8.4	14.3	5.0	785,344.1	0.00	1.00
08/16/2026 04:00	-2	1.7	8.4	14.2	4.8	774,440.1	0.00	1.00
08/16/2026 05:00	-2	1.7	8.4	14.2	5.0	775,053.3	0.00	1.00
08/16/2026 06:00	-1	1.7	8.3	14.2	6.1	775,257.7	0.00	1.00
08/16/2026 07:00	-1	1.7	8.2	14.3	6.4	786,589.1	0.00	1.00
08/16/2026 08:00	-1	1.7	8.2	14.3	6.8	784,929.2	0.00	1.00
08/16/2026 09:00	-1	1.7	8.1	14.3	6.6	784,306.7	0.00	1.00
08/16/2026 10:00	-1	1.7	8.1	14.4	6.2	794,687.5	0.00	1.00
08/16/2026 11:00	-1	1.7	8.1	14.4	6.5	793,002.1	0.00	1.00
08/16/2026 12:00	-1	1.6	7.7	14.4	6.3	849,043.1	0.00	1.00
08/16/2026 13:00	0	1.8	9.0	13.9	13.4	1,026,677.0	0.00	1.00
08/16/2026 14:00	0	1.8	9.1	13.9	13.7	1,027,459.6	0.00	1.00
08/16/2026 15:00	1	1.8	9.1	13.9	14.3	1,027,263.9	0.00	1.00
08/16/2026 16:00	0	1.8	9.5	13.8	14.6	1,028,032.7	0.00	1.00
08/16/2026 17:00	1	1.9	10.4	13.6	16.8	1,037,198.3	0.00	1.00
08/16/2026 18:00	0	1.8	9.7	13.8	14.5	1,024,753.8	0.00	1.00
08/16/2026 19:00	0	1.8	9.5	13.9	14.2	1,023,546.9	0.00	1.00
08/16/2026 20:00	1	1.8	10.4	13.8	16.8	1,017,424.5	0.00	1.00
08/16/2026 21:00	-1	1.6	8.0	14.6	10.6	999,245.1	0.00	1.00
08/16/2026 22:00	0	1.6	8.1	14.6	10.5	971,856.6	0.00	1.00
08/16/2026 23:00	-1	1.7	8.2	14.4	7.6	790,263.2	0.00	1.00
Average/Sum#:	-1	1.7	8.7	14.2	9.4	892,114.5	0.00 #	24.00 #
Minimum:	-2	1.6	7.7	13.6	4.8	774,440.1	0.00	1.00
Maximum:	1	1.9	10.4	14.6	16.8	1,037,198.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/17/2026 00:00	-1	1.7	8.2	14.3	7.6	779,327.0	0.00	1.00
08/17/2026 01:00	-1	1.7	8.2	14.3	7.6	779,534.5	0.00	1.00
08/17/2026 02:00	-1	1.7	8.5	14.3	7.5	779,741.9	0.00	1.00
08/17/2026 03:00	-1	1.7	8.5	14.3	7.4	780,364.4	0.00	1.00
08/17/2026 04:00	-1	1.7	8.4	14.3	7.1	788,871.4	0.00	1.00
08/17/2026 05:00	-1	1.7	8.5	14.3	7.2	781,609.3	0.00	1.00
08/17/2026 06:00	-1	1.7	8.5	14.3	6.9	780,986.9	0.00	1.00
08/17/2026 07:00	-1	1.7	8.4	14.3	7.6	780,986.9	0.00	1.00
08/17/2026 08:00	-1	1.7	8.4	14.3	8.0	780,571.9	0.00	1.00
08/17/2026 09:00	-1	1.7	8.3	14.4	7.5	791,527.3	0.00	1.00
08/17/2026 10:00	-1	1.7	8.3	14.4	7.3	790,263.2	0.00	1.00
08/17/2026 11:00	-1	1.7	8.3	14.4	7.1	789,209.8	0.00	1.00
08/17/2026 12:00	-1	1.7	7.8	14.5	7.1	859,955.7	0.00	1.00
08/17/2026 13:00	0	1.8	9.1	13.9	14.0	1,025,894.5	0.00	1.00
08/17/2026 14:00	2	2.0	11.2	13.2	20.0	1,034,360.0	0.00	1.00
08/17/2026 15:00	2	2.0	11.4	13.0	19.8	1,020,654.5	0.00	1.00
08/17/2026 16:00	1	1.9	10.6	13.4	17.9	1,026,885.7	0.00	1.00
08/17/2026 17:00	4	2.1	12.2	12.7	25.5	1,041,764.5	0.00	1.00
08/17/2026 18:00	2	2.0	11.5	13.1	20.7	1,034,793.2	0.00	1.00
08/17/2026 19:00	1	1.9	10.8	13.5	18.2	1,030,769.4	0.00	1.00
08/17/2026 20:00	1	1.8	10.7	13.8	18.1	1,020,510.5	0.00	1.00
08/17/2026 21:00	-1	1.6	8.5	14.5	9.6	884,348.6	0.00	1.00
08/17/2026 22:00	-1	1.7	8.3	14.4	9.0	834,295.5	0.00	1.00
08/17/2026 23:00	-1	1.7	8.3	14.3	8.0	779,741.9	0.00	1.00
Average/Sum#:	0	1.8	9.2	14.0	11.5	874,873.7	0.00 #	24.00 #
Minimum:	-1	1.6	7.8	12.7	6.9	779,327.0	0.00	1.00
Maximum:	4	2.1	12.2	14.5	25.5	1,041,764.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/18/2026 00:00	-1	1.7	8.3	14.3	7.6	780,571.9	0.00	1.00
08/18/2026 01:00	-1	1.7	8.3	14.3	7.3	780,779.4	0.00	1.00
08/18/2026 02:00	-1	1.7	8.6	14.3	6.8	781,609.3	0.00	1.00
08/18/2026 03:00	-1	1.7	8.5	14.3	6.4	782,231.8	0.00	1.00
08/18/2026 04:00	-2	1.7	8.5	14.3	5.6	783,061.8	0.00	1.00
08/18/2026 05:00	-2	1.7	8.5	14.3	5.2	783,269.2	0.00	1.00
08/18/2026 06:00	-2	1.7	8.5	14.3	5.8	783,476.7	0.00	1.00
08/18/2026 07:00	-1	1.7	8.4	14.3	6.6	782,024.3	0.00	1.00
08/18/2026 08:00	-1	1.7	8.4	14.3	7.6	781,194.4	0.00	1.00
08/18/2026 09:00	-1	1.7	8.3	14.4	7.2	791,738.0	0.00	1.00
08/18/2026 10:00	-1	1.7	8.3	14.4	6.5	790,263.2	0.00	1.00
08/18/2026 11:00	-1	1.7	8.2	14.4	6.5	788,999.1	0.00	1.00
08/18/2026 12:00	-1	1.7	8.1	14.4	7.9	836,823.6	0.00	1.00
08/18/2026 13:00	2	1.9	11.9	13.1	19.2	956,665.8	0.00	1.00
08/18/2026 14:00	3	2.1	12.8	12.7	23.5	940,059.7	0.00	1.00
08/18/2026 15:00	3	2.1	13.3	12.7	23.3	923,860.5	0.00	1.00
08/18/2026 16:00	4	2.1	13.4	12.6	26.1	963,546.8	0.00	1.00
08/18/2026 17:00	5	2.2	13.3	12.3	30.4	1,042,195.7	0.00	1.00
08/18/2026 18:00	3	2.1	13.3	12.6	25.5	1,034,327.9	0.00	1.00
08/18/2026 19:00	1	1.9	11.2	13.4	18.1	1,028,529.0	0.00	1.00
08/18/2026 20:00	0	1.8	9.5	14.0	14.6	1,034,213.1	0.00	1.00
08/18/2026 21:00	-1	1.6	7.9	14.3	8.4	879,751.4	0.00	1.00
08/18/2026 22:00	-1	1.7	8.0	14.4	8.2	833,452.7	0.00	1.00
08/18/2026 23:00	-1	1.7	8.4	14.3	8.4	793,228.7	0.00	1.00
Average/Sum#:	0	1.8	9.7	13.9	12.2	861,494.8	0.00 #	24.00 #
Minimum:	-2	1.6	7.9	12.3	5.2	780,571.9	0.00	1.00
Maximum:	5	2.2	13.4	14.4	30.4	1,042,195.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/19/2026 00:00	-1	1.7	8.3	14.3	7.6	780,156.9	0.00	1.00
08/19/2026 01:00	-1	1.7	8.3	14.3	7.5	780,986.9	0.00	1.00
08/19/2026 02:00	-1	1.7	8.6	14.3	7.0	781,401.9	0.00	1.00
08/19/2026 03:00	-1	1.7	8.5	14.3	6.6	781,816.8	0.00	1.00
08/19/2026 04:00	-1	1.7	8.5	14.3	6.8	782,231.8	0.00	1.00
08/19/2026 05:00	-1	1.7	8.5	14.3	6.4	783,061.8	0.00	1.00
08/19/2026 06:00	-1	1.7	8.5	14.3	6.7	782,646.8	0.00	1.00
08/19/2026 07:00	-1	1.7	8.4	14.3	7.5	781,816.8	0.00	1.00
08/19/2026 08:00	-1	1.7	8.3	14.3	7.9	780,986.9	0.00	1.00
08/19/2026 09:00	-1	1.7	8.3	14.4	7.7	791,316.6	0.00	1.00
08/19/2026 10:00	-1	1.7	8.3	14.4	7.1	790,895.3	0.00	1.00
08/19/2026 11:00	-1	1.7	8.2	14.4	7.1	790,263.2	0.00	1.00
08/19/2026 12:00	-1	1.7	8.3	14.4	8.7	833,031.4	0.00	1.00
08/19/2026 13:00	3	2.1	13.7	12.6	23.8	927,083.8	0.00	1.00
08/19/2026 14:00	4	2.1	13.4	12.5	25.4	950,934.8	0.00	1.00
08/19/2026 15:00	4	2.1	12.5	12.8	25.1	959,780.5	0.00	1.00
08/19/2026 16:00	5	2.2	13.3	12.4	27.1	930,403.0	0.00	1.00
08/19/2026 17:00	4	2.2	14.0	12.4	28.9	1,039,634.8	0.00	1.00
08/19/2026 18:00	4	2.2	14.0	12.4	28.4	1,041,245.9	0.00	1.00
08/19/2026 19:00	3	2.1	13.2	12.6	25.4	1,037,462.7	0.00	1.00
08/19/2026 20:00	2	2.0	11.6	13.1	20.4	1,026,717.2	0.00	1.00
08/19/2026 21:00	-1	1.6	7.7	14.5	9.2	968,867.8	0.00	1.00
08/19/2026 22:00	0	1.6	7.7	14.6	10.2	999,897.2	0.00	1.00
08/19/2026 23:00	0	1.6	7.8	14.5	10.4	980,850.2	0.00	1.00
Average/Sum#:	1	1.8	9.9	13.8	13.7	879,312.1	0.00 #	24.00 #
Minimum:	-1	1.6	7.7	12.4	6.4	780,156.9	0.00	1.00
Maximum:	5	2.2	14.0	14.6	28.9	1,041,245.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/20/2026 00:00	-1	1.6	8.3	14.4	9.3	885,490.9	0.00	1.00
08/20/2026 01:00	-1	1.7	8.5	14.3	8.0	785,759.1	0.00	1.00
08/20/2026 02:00	-1	1.7	8.8	14.3	7.6	784,929.2	0.00	1.00
08/20/2026 03:00	-1	1.6	8.7	14.3	7.2	783,061.8	0.00	1.00
08/20/2026 04:00	-1	1.7	8.6	14.3	6.7	783,476.7	0.00	1.00
08/20/2026 05:00	-2	1.7	8.6	14.3	5.9	785,344.1	0.00	1.00
08/20/2026 06:00	-1	1.7	8.5	14.3	6.6	790,738.8	0.00	1.00
08/20/2026 07:00	-1	1.7	8.4	14.3	7.2	784,721.7	0.00	1.00
08/20/2026 08:00	-1	1.7	8.4	14.3	7.8	784,099.2	0.00	1.00
08/20/2026 09:00	-1	1.7	8.3	14.4	7.5	794,476.8	0.00	1.00
08/20/2026 10:00	-1	1.7	8.3	14.4	7.1	793,844.8	0.00	1.00
08/20/2026 11:00	-1	1.7	8.2	14.4	6.8	798,479.8	0.00	1.00
08/20/2026 12:00	-1	1.7	8.1	14.4	8.2	855,152.9	0.00	1.00
08/20/2026 13:00	2	2.0	12.3	13.0	20.0	956,170.2	0.00	1.00
08/20/2026 14:00	2	2.0	11.9	13.1	20.6	974,222.6	0.00	1.00
08/20/2026 15:00	3	2.0	13.2	12.8	22.8	938,309.3	0.00	1.00
08/20/2026 16:00	3	2.1	13.0	12.7	23.9	950,747.9	0.00	1.00
08/20/2026 17:00	5	2.2	13.0	12.3	28.9	1,043,151.1	0.00	1.00
08/20/2026 18:00	4	2.1	13.0	12.6	27.1	1,048,187.1	0.00	1.00
08/20/2026 19:00	3	2.1	13.4	12.6	26.9	1,049,177.1	0.00	1.00
08/20/2026 20:00	2	2.0	11.9	13.1	21.6	1,036,197.8	0.00	1.00
08/20/2026 21:00	-1	1.6	7.8	14.5	9.4	980,850.2	0.00	1.00
08/20/2026 22:00	-1	1.6	7.8	14.5	9.9	979,994.3	0.00	1.00
08/20/2026 23:00	-1	1.6	7.9	14.5	9.4	980,208.3	0.00	1.00
Average/Sum#:	0	1.8	9.8	13.8	13.2	889,449.7	0.00 #	24.00 #
Minimum:	-2	1.6	7.8	12.3	5.9	783,061.8	0.00	1.00
Maximum:	5	2.2	13.4	14.5	28.9	1,049,177.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/21/2026 00:00	-1	1.6	7.9	14.4	9.0	965,128.2	0.00	1.00
08/21/2026 01:00	-1	1.7	8.4	14.3	6.7	818,957.3	0.00	1.00
08/21/2026 02:00	-2	1.6	8.4	14.3	7.1	862,944.9	0.00	1.00
08/21/2026 03:00	-2	1.7	8.4	14.3	5.6	801,320.8	0.00	1.00
08/21/2026 04:00	-2	1.7	8.4	14.3	5.4	798,000.9	0.00	1.00
08/21/2026 05:00	-1	1.7	8.0	14.4	7.7	971,027.2	0.00	1.00
08/21/2026 06:00	-1	1.7	8.4	14.3	7.1	845,723.3	0.00	1.00
08/21/2026 07:00	-1	1.7	8.3	14.3	6.6	785,759.1	0.00	1.00
08/21/2026 08:00	-1	1.7	8.2	14.3	7.3	785,966.6	0.00	1.00
08/21/2026 09:00	-1	1.7	8.2	14.3	7.1	784,721.7	0.00	1.00
08/21/2026 10:00	-1	1.7	8.1	14.4	7.0	795,740.9	0.00	1.00
08/21/2026 11:00	-1	1.7	8.1	14.4	6.4	794,266.1	0.00	1.00
08/21/2026 12:00	-1	1.6	7.8	14.5	6.6	865,305.0	0.00	1.00
08/21/2026 13:00	2	1.9	11.3	13.3	18.9	975,174.3	0.00	1.00
08/21/2026 14:00	2	2.1	12.9	12.9	21.4	943,362.2	0.00	1.00
08/21/2026 15:00	3	2.1	13.0	12.9	22.3	937,542.2	0.00	1.00
08/21/2026 16:00	3	2.1	13.1	12.7	23.3	941,061.8	0.00	1.00
08/21/2026 17:00	4	2.2	13.1	12.4	28.7	1,044,951.4	0.00	1.00
08/21/2026 18:00	1	1.8	10.3	13.7	15.9	1,036,007.6	0.00	1.00
08/21/2026 19:00	0	1.8	9.4	14.0	15.1	1,042,945.7	0.00	1.00
08/21/2026 20:00	1	1.8	9.3	14.0	15.6	1,043,541.1	0.00	1.00
08/21/2026 21:00	-1	1.7	8.1	14.3	7.7	794,266.1	0.00	1.00
08/21/2026 22:00	-1	1.7	8.1	14.3	7.7	782,439.3	0.00	1.00
08/21/2026 23:00	-1	1.6	8.0	14.4	9.0	907,823.0	0.00	1.00
Average/Sum#:	0	1.8	9.3	14.0	11.5	888,499.0	0.00 #	24.00 #
Minimum:	-2	1.6	7.8	12.4	5.4	782,439.3	0.00	1.00
Maximum:	4	2.2	13.1	14.5	28.7	1,044,951.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/22/2026 00:00	-1	1.7	8.1	14.4	8.6	892,864.7	0.00	1.00
08/22/2026 01:00	-1	1.7	8.2	14.4	8.2	871,586.0	0.00	1.00
08/22/2026 02:00	-1	1.7	8.5	14.3	6.6	783,891.7	0.00	1.00
08/22/2026 03:00	-2	1.7	8.5	14.3	6.4	784,514.2	0.00	1.00
08/22/2026 04:00	-1	1.7	8.2	14.3	6.7	851,118.0	0.00	1.00
08/22/2026 05:00	-2	1.7	8.6	14.3	5.9	789,078.9	0.00	1.00
08/22/2026 06:00	-1	1.7	8.4	14.3	6.3	785,759.1	0.00	1.00
08/22/2026 07:00	-1	1.7	8.3	14.3	7.1	785,136.6	0.00	1.00
08/22/2026 08:00	-1	1.7	8.3	14.3	7.9	784,099.2	0.00	1.00
08/22/2026 09:00	-1	1.7	8.2	14.4	7.5	795,530.2	0.00	1.00
08/22/2026 10:00	-1	1.7	8.3	14.4	7.0	794,476.8	0.00	1.00
08/22/2026 11:00	-1	1.6	8.2	14.4	6.9	792,159.3	0.00	1.00
08/22/2026 12:00	-1	1.6	8.0	14.5	7.9	860,383.7	0.00	1.00
08/22/2026 13:00	0	1.8	9.3	14.0	14.3	1,042,350.3	0.00	1.00
08/22/2026 14:00	0	1.8	9.3	14.0	14.5	1,041,953.3	0.00	1.00
08/22/2026 15:00	1	1.8	9.3	14.0	15.2	1,041,754.9	0.00	1.00
08/22/2026 16:00	1	1.8	9.6	13.9	16.9	1,031,567.8	0.00	1.00
08/22/2026 17:00	2	2.0	12.7	13.1	20.6	952,803.4	0.00	1.00
08/22/2026 18:00	2	2.0	12.5	13.1	20.5	949,994.3	0.00	1.00
08/22/2026 19:00	1	1.9	11.3	13.5	18.0	988,761.4	0.00	1.00
08/22/2026 20:00	1	1.8	10.3	13.8	16.5	1,020,510.5	0.00	1.00
08/22/2026 21:00	-1	1.7	8.3	14.4	8.3	819,126.5	0.00	1.00
08/22/2026 22:00	-1	1.7	8.3	14.4	8.0	794,055.5	0.00	1.00
08/22/2026 23:00	-1	1.7	8.3	14.3	7.8	783,684.2	0.00	1.00
Average/Sum#:	0	1.7	9.0	14.1	10.6	876,548.4	0.00 #	24.00 #
Minimum:	-2	1.6	8.0	13.1	5.9	783,684.2	0.00	1.00
Maximum:	2	2.0	12.7	14.5	20.6	1,042,350.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/23/2026 00:00	-1	1.7	8.3	14.4	8.8	859,577.2	0.00	1.00
08/23/2026 01:00	-1	1.7	8.4	14.3	7.7	787,004.0	0.00	1.00
08/23/2026 02:00	-1	1.7	8.6	14.3	7.5	783,891.7	0.00	1.00
08/23/2026 03:00	-1	1.7	8.6	14.3	7.3	784,514.2	0.00	1.00
08/23/2026 04:00	-1	1.7	8.6	14.3	7.2	785,344.1	0.00	1.00
08/23/2026 05:00	-2	1.7	8.6	14.3	6.3	786,174.1	0.00	1.00
08/23/2026 06:00	-1	1.7	8.6	14.3	7.5	785,759.1	0.00	1.00
08/23/2026 07:00	-1	1.7	8.5	14.3	8.1	784,306.7	0.00	1.00
08/23/2026 08:00	-1	1.7	8.4	14.4	8.1	794,687.5	0.00	1.00
08/23/2026 09:00	-1	1.7	8.4	14.4	7.7	793,212.7	0.00	1.00
08/23/2026 10:00	-1	1.7	8.3	14.4	7.2	791,948.7	0.00	1.00
08/23/2026 11:00	-1	1.6	8.2	14.5	7.1	803,253.0	0.00	1.00
08/23/2026 12:00	-1	1.7	7.7	14.5	7.3	866,802.8	0.00	1.00
08/23/2026 13:00	1	1.8	9.8	13.8	15.3	1,018,196.0	0.00	1.00
08/23/2026 14:00	3	2.1	13.8	12.8	24.2	929,010.7	0.00	1.00
08/23/2026 15:00	3	2.0	13.0	12.8	22.8	978,208.6	0.00	1.00
08/23/2026 16:00	3	2.1	11.8	13.0	22.6	1,038,162.4	0.00	1.00
08/23/2026 17:00	4	2.2	13.2	12.4	28.4	1,042,051.4	0.00	1.00
08/23/2026 18:00	4	2.1	13.2	12.5	27.4	1,042,392.8	0.00	1.00
08/23/2026 19:00	2	2.0	12.6	12.9	23.1	1,040,249.0	0.00	1.00
08/23/2026 20:00	2	2.0	11.7	13.2	20.9	1,041,118.2	0.00	1.00
08/23/2026 21:00	-1	1.6	7.8	14.4	9.2	970,184.5	0.00	1.00
08/23/2026 22:00	0	1.7	7.7	14.4	10.0	971,027.2	0.00	1.00
08/23/2026 23:00	0	1.7	7.7	14.4	9.7	968,288.4	0.00	1.00
Average/Sum#:	0	1.8	9.6	13.9	13.0	893,556.9	0.00 #	24.00 #
Minimum:	-2	1.6	7.7	12.4	6.3	783,891.7	0.00	1.00
Maximum:	4	2.2	13.8	14.5	28.4	1,042,392.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/24/2026 00:00	0	1.7	7.7	14.4	10.2	968,709.7	0.00	1.00
08/24/2026 01:00	0	1.6	8.0	14.6	11.0	999,245.1	0.00	1.00
08/24/2026 02:00	0	1.6	8.3	14.5	10.7	981,920.1	0.00	1.00
08/24/2026 03:00	-1	1.6	8.4	14.5	10.4	965,230.2	0.00	1.00
08/24/2026 04:00	0	1.6	8.2	14.5	10.7	975,714.9	0.00	1.00
08/24/2026 05:00	-1	1.7	8.5	14.3	7.0	793,436.2	0.00	1.00
08/24/2026 06:00	-1	1.7	8.3	14.4	8.4	873,271.4	0.00	1.00
08/24/2026 07:00	-1	1.7	8.4	14.3	8.0	817,297.4	0.00	1.00
08/24/2026 08:00	-1	1.7	8.4	14.3	8.1	782,439.3	0.00	1.00
08/24/2026 09:00	-1	1.7	8.4	14.4	7.9	793,634.1	0.00	1.00
08/24/2026 10:00	-1	1.7	8.4	14.4	7.6	792,580.7	0.00	1.00
08/24/2026 11:00	-1	1.6	8.4	14.5	7.1	804,536.8	0.00	1.00
08/24/2026 12:00	-1	1.6	8.2	14.5	8.4	870,654.3	0.00	1.00
08/24/2026 13:00	2	2.0	12.5	13.0	21.8	963,970.8	0.00	1.00
08/24/2026 14:00	4	2.2	13.2	12.4	27.8	992,913.2	0.00	1.00
08/24/2026 15:00	5	2.2	13.1	12.4	29.8	1,044,629.1	0.00	1.00
08/24/2026 16:00	3	2.1	12.8	12.7	26.2	1,039,927.5	0.00	1.00
08/24/2026 17:00	5	2.2	13.4	12.4	30.1	1,046,723.6	0.00	1.00
08/24/2026 18:00	5	2.2	13.8	12.4	30.4	1,052,845.7	0.00	1.00
08/24/2026 19:00	4	2.2	14.0	12.4	30.0	1,050,590.2	0.00	1.00
08/24/2026 20:00	2	1.9	11.5	13.3	20.9	1,042,564.4	0.00	1.00
08/24/2026 21:00	-1	1.6	7.7	14.6	9.7	1,000,114.5	0.00	1.00
08/24/2026 22:00	0	1.6	7.7	14.5	10.4	984,273.8	0.00	1.00
08/24/2026 23:00	0	1.6	7.9	14.5	9.8	950,894.1	0.00	1.00
Average/Sum#:	1	1.8	9.8	13.8	15.1	941,171.5	0.00 #	24.00 #
Minimum:	-1	1.6	7.7	12.4	7.0	782,439.3	0.00	1.00
Maximum:	5	2.2	14.0	14.6	30.4	1,052,845.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/25/2026 00:00	-1	1.6	8.1	14.4	8.8	889,283.1	0.00	1.00
08/25/2026 01:00	-1	1.7	8.3	14.3	7.1	791,983.8	0.00	1.00
08/25/2026 02:00	-1	1.7	8.6	14.3	6.6	784,306.7	0.00	1.00
08/25/2026 03:00	-2	1.7	8.5	14.3	6.1	785,344.1	0.00	1.00
08/25/2026 04:00	-1	1.7	8.2	14.3	6.7	868,547.0	0.00	1.00
08/25/2026 05:00	-2	1.7	8.6	14.3	6.3	827,049.3	0.00	1.00
08/25/2026 06:00	-1	1.7	8.3	14.3	6.6	836,593.8	0.00	1.00
08/25/2026 07:00	-1	1.7	8.3	14.3	6.8	784,929.2	0.00	1.00
08/25/2026 08:00	-1	1.7	8.2	14.3	7.6	784,306.7	0.00	1.00
08/25/2026 09:00	-1	1.7	8.2	14.3	7.2	783,684.2	0.00	1.00
08/25/2026 10:00	-1	1.7	8.2	14.4	6.5	794,266.1	0.00	1.00
08/25/2026 11:00	-1	1.6	7.7	14.4	6.3	878,538.4	0.00	1.00
08/25/2026 12:00	-1	1.7	7.6	14.4	7.2	939,425.1	0.00	1.00
08/25/2026 13:00	-1	1.6	7.7	14.5	9.2	1,002,033.5	0.00	1.00
08/25/2026 14:00	1	1.9	10.4	13.6	17.2	1,042,638.5	0.00	1.00
08/25/2026 15:00	1	1.8	9.8	13.8	15.7	1,034,397.6	0.00	1.00
08/25/2026 16:00	2	2.0	11.6	13.1	22.2	1,046,029.5	0.00	1.00
08/25/2026 17:00	5	2.2	12.9	12.3	30.2	1,047,768.9	0.00	1.00
08/25/2026 18:00	5	2.2	13.4	12.3	30.6	1,047,450.4	0.00	1.00
08/25/2026 19:00	3	2.1	13.0	12.8	24.8	1,056,147.4	0.00	1.00
08/25/2026 20:00	2	1.9	11.0	13.4	19.5	1,030,537.5	0.00	1.00
08/25/2026 21:00	2	1.9	11.0	13.5	19.9	1,017,260.2	0.00	1.00
08/25/2026 22:00	-1	1.6	8.2	14.4	8.7	863,369.4	0.00	1.00
08/25/2026 23:00	-1	1.7	8.3	14.4	8.0	795,740.9	0.00	1.00
Average/Sum#:	0	1.8	9.3	13.9	12.3	905,484.6	0.00 #	24.00 #
Minimum:	-2	1.6	7.6	12.3	6.1	783,684.2	0.00	1.00
Maximum:	5	2.2	13.4	14.5	30.6	1,056,147.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/26/2026 00:00	-1	1.7	8.3	14.4	8.3	809,435.2	0.00	1.00
08/26/2026 01:00	-1	1.7	8.4	14.3	7.9	783,269.2	0.00	1.00
08/26/2026 02:00	-1	1.7	8.5	14.4	8.5	851,149.9	0.00	1.00
08/26/2026 03:00	-1	1.5	8.6	14.3	7.1	783,684.2	0.00	1.00
08/26/2026 04:00	-1	1.7	8.2	14.4	7.9	893,286.1	0.00	1.00
08/26/2026 05:00	-1	1.6	8.2	14.5	9.2	982,776.0	0.00	1.00
08/26/2026 06:00	-1	1.7	8.5	14.4	8.5	870,743.2	0.00	1.00
08/26/2026 07:00	-1	1.7	8.4	14.3	7.5	784,306.7	0.00	1.00
08/26/2026 08:00	-1	1.7	8.4	14.4	8.3	795,530.2	0.00	1.00
08/26/2026 09:00	-1	1.7	8.3	14.4	7.7	793,844.8	0.00	1.00
08/26/2026 10:00	-1	1.6	8.3	14.4	7.1	793,423.4	0.00	1.00
08/26/2026 11:00	-1	1.6	7.6	14.5	8.9	977,854.6	0.00	1.00
08/26/2026 12:00	-1	1.6	8.0	14.5	10.3	989,623.1	0.00	1.00
08/26/2026 13:00	1	1.8	10.8	13.6	18.6	1,023,128.8	0.00	1.00
08/26/2026 14:00	3	2.0	13.3	12.9	22.8	935,830.4	0.00	1.00
08/26/2026 15:00	3	2.1	13.8	12.8	24.5	928,334.5	0.00	1.00
08/26/2026 16:00	4	2.1	14.3	12.7	25.7	918,349.4	0.00	1.00
08/26/2026 17:00	3	2.0	12.9	12.8	24.7	1,011,345.3	0.00	1.00
08/26/2026 18:00	1	1.9	11.6	13.4	19.7	1,023,233.9	0.00	1.00
08/26/2026 19:00	2	2.0	12.4	13.1	21.3	1,001,962.2	0.00	1.00
08/26/2026 20:00	2	2.0	11.8	13.3	21.2	1,018,599.5	0.00	1.00
08/26/2026 21:00	-1	1.6	8.5	14.6	11.5	994,462.9	0.00	1.00
08/26/2026 22:00	-1	1.7	8.5	14.4	8.7	810,699.2	0.00	1.00
08/26/2026 23:00	0	1.6	8.3	14.5	10.1	913,020.9	0.00	1.00
Average/Sum#:	0	1.8	9.7	14.0	13.2	903,662.2	0.00 #	24.00 #
Minimum:	-1	1.5	7.6	12.7	7.1	783,269.2	0.00	1.00
Maximum:	4	2.1	14.3	14.6	25.7	1,023,233.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/27/2026 00:00	-1	1.7	8.4	14.4	9.0	845,040.2	0.00	1.00
08/27/2026 01:00	-1	1.7	8.5	14.4	8.0	794,687.5	0.00	1.00
08/27/2026 02:00	-1	1.7	8.7	14.3	7.6	783,269.2	0.00	1.00
08/27/2026 03:00	-1	1.7	8.7	14.3	7.9	783,684.2	0.00	1.00
08/27/2026 04:00	-1	1.7	8.6	14.3	7.4	783,891.7	0.00	1.00
08/27/2026 05:00	-1	1.7	8.4	14.4	8.7	871,586.0	0.00	1.00
08/27/2026 06:00	-1	1.7	8.3	14.4	8.4	896,657.0	0.00	1.00
08/27/2026 07:00	-1	1.6	8.0	14.5	10.2	989,409.1	0.00	1.00
08/27/2026 08:00	0	1.6	7.9	14.6	10.8	1,004,679.3	0.00	1.00
08/27/2026 09:00	-1	1.6	8.0	14.6	10.6	1,004,896.7	0.00	1.00
08/27/2026 10:00	-1	1.6	7.7	14.5	8.9	986,627.5	0.00	1.00
08/27/2026 11:00	-1	1.7	7.3	14.5	8.3	987,055.4	0.00	1.00
08/27/2026 12:00	0	1.6	7.9	14.5	10.9	1,011,662.3	0.00	1.00
08/27/2026 13:00	3	2.1	11.9	12.8	24.0	1,041,269.7	0.00	1.00
08/27/2026 14:00	4	2.2	12.7	12.4	27.2	1,030,451.6	0.00	1.00
08/27/2026 15:00	1	1.8	10.2	13.6	15.8	1,024,817.2	0.00	1.00
08/27/2026 16:00	1	1.9	10.4	13.5	17.1	1,032,064.8	0.00	1.00
08/27/2026 17:00	1	1.8	9.4	13.8	14.9	1,019,353.2	0.00	1.00
08/27/2026 18:00	2	1.9	10.8	13.4	18.2	985,437.8	0.00	1.00
08/27/2026 19:00	2	1.9	11.1	13.3	19.1	977,516.7	0.00	1.00
08/27/2026 20:00	3	2.0	11.9	13.0	22.4	990,145.8	0.00	1.00
08/27/2026 21:00	-1	1.6	8.2	14.6	10.5	998,158.2	0.00	1.00
08/27/2026 22:00	0	1.6	8.0	14.6	11.0	1,003,809.8	0.00	1.00
08/27/2026 23:00	3	2.0	12.6	13.1	24.2	1,029,175.1	0.00	1.00
Average/Sum#:	0	1.8	9.3	14.0	13.4	953,139.4	0.00 #	24.00 #
Minimum:	-1	1.6	7.3	12.4	7.4	783,269.2	0.00	1.00
Maximum:	4	2.2	12.7	14.6	27.2	1,041,269.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/28/2026 00:00	1	1.9	11.3	13.6	19.6	1,028,569.0	0.00	1.00
08/28/2026 01:00	1	1.8	10.8	13.8	18.3	1,040,762.5	0.00	1.00
08/28/2026 02:00	0	1.8	10.8	13.9	16.7	1,030,980.9	0.00	1.00
08/28/2026 03:00	1	1.8	10.9	13.8	17.2	1,035,169.1	0.00	1.00
08/28/2026 04:00	2	1.9	12.1	13.3	21.8	1,041,303.1	0.00	1.00
08/28/2026 05:00	4	2.2	14.3	12.5	29.7	1,053,315.6	0.00	1.00
08/28/2026 06:00	4	2.1	13.7	12.7	28.0	1,048,277.7	0.00	1.00
08/28/2026 07:00	3	2.1	13.8	12.5	27.5	1,053,641.6	0.00	1.00
08/28/2026 08:00	1	1.8	10.9	13.6	17.9	1,046,577.9	0.00	1.00
08/28/2026 09:00	1	1.8	10.5	13.9	16.9	1,034,306.7	0.00	1.00
08/28/2026 10:00	1	1.8	10.9	13.7	18.6	1,027,638.9	0.00	1.00
08/28/2026 11:00	1	1.9	11.3	13.6	19.5	1,026,880.7	0.00	1.00
08/28/2026 12:00	1	1.8	11.3	13.6	19.7	1,020,877.7	0.00	1.00
08/28/2026 13:00	1	1.9	11.2	13.7	19.0	1,021,172.2	0.00	1.00
08/28/2026 14:00	1	1.9	11.6	13.5	19.8	1,000,049.9	0.00	1.00
08/28/2026 15:00	1	1.9	11.3	13.6	18.8	1,005,307.6	0.00	1.00
08/28/2026 16:00	1	1.8	10.7	13.7	17.3	1,014,325.0	0.00	1.00
08/28/2026 17:00	1	1.8	10.3	13.8	16.6	1,024,753.8	0.00	1.00
08/28/2026 18:00	1	1.8	10.5	13.8	17.8	1,029,189.9	0.00	1.00
08/28/2026 19:00	1	1.8	10.3	13.9	17.5	1,032,937.2	0.00	1.00
08/28/2026 20:00	1	1.8	10.1	13.9	16.7	1,027,850.8	0.00	1.00
08/28/2026 21:00	1	1.8	9.9	14.0	16.1	1,038,182.5	0.00	1.00
08/28/2026 22:00	0	1.8	9.8	14.0	15.6	1,036,991.7	0.00	1.00
08/28/2026 23:00	0	1.8	9.7	14.0	15.3	1,036,793.2	0.00	1.00
Average/Sum#:	1	1.9	11.2	13.6	19.2	1,031,494.0	0.00 #	24.00 #
Minimum:	0	1.8	9.7	12.5	15.3	1,000,049.9	0.00	1.00
Maximum:	4	2.2	14.3	14.0	29.7	1,053,641.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/29/2026 00:00	0	1.8	9.6	14.0	15.1	1,035,602.4	0.00	1.00
08/29/2026 01:00	0	1.8	9.7	14.0	15.3	1,036,396.3	0.00	1.00
08/29/2026 02:00	0	1.7	10.2	14.1	15.3	1,050,026.3	0.00	1.00
08/29/2026 03:00	0	1.7	10.0	14.1	15.1	1,047,811.0	0.00	1.00
08/29/2026 04:00	0	1.7	9.7	14.1	14.9	1,044,991.6	0.00	1.00
08/29/2026 05:00	0	1.7	9.5	14.2	14.2	1,056,296.3	0.00	1.00
08/29/2026 06:00	0	1.7	9.4	14.2	14.4	1,057,318.3	0.00	1.00
08/29/2026 07:00	0	1.7	9.4	14.1	15.3	1,048,012.4	0.00	1.00
08/29/2026 08:00	1	1.7	9.5	14.1	16.3	1,049,220.7	0.00	1.00
08/29/2026 09:00	1	1.8	9.9	14.0	16.6	1,039,770.2	0.00	1.00
08/29/2026 10:00	1	1.8	10.2	13.9	16.1	1,028,633.3	0.00	1.00
08/29/2026 11:00	0	1.8	10.6	13.8	16.4	1,021,089.1	0.00	1.00
08/29/2026 12:00	1	1.9	11.2	13.6	17.5	1,002,493.7	0.00	1.00
08/29/2026 13:00	1	1.9	11.4	13.5	18.1	995,608.5	0.00	1.00
08/29/2026 14:00	2	1.9	11.8	13.3	19.8	977,336.6	0.00	1.00
08/29/2026 15:00	1	1.8	10.5	13.7	15.9	1,009,570.1	0.00	1.00
08/29/2026 16:00	0	1.8	9.9	14.0	14.8	1,039,373.3	0.00	1.00
08/29/2026 17:00	1	1.9	10.7	13.7	17.3	1,043,615.5	0.00	1.00
08/29/2026 18:00	1	1.8	10.7	13.9	18.0	1,029,415.9	0.00	1.00
08/29/2026 19:00	1	1.8	10.8	13.9	17.7	1,028,242.1	0.00	1.00
08/29/2026 20:00	1	1.8	10.6	13.9	17.0	1,029,611.5	0.00	1.00
08/29/2026 21:00	0	1.8	10.4	13.9	16.4	1,027,459.6	0.00	1.00
08/29/2026 22:00	0	1.8	10.2	14.0	15.8	1,038,976.3	0.00	1.00
08/29/2026 23:00	0	1.8	10.1	14.0	15.3	1,036,197.8	0.00	1.00
Average/Sum#:	1	1.8	10.3	13.9	16.2	1,032,211.2	0.00 #	24.00 #
Minimum:	0	1.7	9.4	13.3	14.2	977,336.6	0.00	1.00
Maximum:	2	1.9	11.8	14.2	19.8	1,057,318.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/30/2026 00:00	0	1.7	9.8	14.1	15.0	1,047,609.7	0.00	1.00
08/30/2026 01:00	0	1.7	9.6	14.1	14.8	1,044,790.3	0.00	1.00
08/30/2026 02:00	0	1.7	9.9	14.1	14.7	1,044,790.3	0.00	1.00
08/30/2026 03:00	0	1.7	9.7	14.1	14.8	1,044,186.1	0.00	1.00
08/30/2026 04:00	0	1.7	9.6	14.1	14.6	1,043,380.5	0.00	1.00
08/30/2026 05:00	0	1.7	9.5	14.2	14.3	1,056,705.1	0.00	1.00
08/30/2026 06:00	0	1.7	9.5	14.2	14.4	1,055,274.3	0.00	1.00
08/30/2026 07:00	0	1.7	9.5	14.1	15.3	1,047,811.0	0.00	1.00
08/30/2026 08:00	1	1.8	9.5	14.1	16.1	1,052,040.1	0.00	1.00
08/30/2026 09:00	1	1.8	9.9	14.0	16.5	1,040,961.0	0.00	1.00
08/30/2026 10:00	1	1.8	10.3	13.9	16.7	1,033,719.8	0.00	1.00
08/30/2026 11:00	1	1.8	10.6	13.8	16.7	1,023,789.4	0.00	1.00
08/30/2026 12:00	0	1.8	10.9	13.7	16.5	1,015,466.2	0.00	1.00
08/30/2026 13:00	1	1.9	11.0	13.5	16.9	990,797.0	0.00	1.00
08/30/2026 14:00	1	1.9	11.1	13.4	17.1	976,856.1	0.00	1.00
08/30/2026 15:00	1	1.9	11.3	13.3	18.3	967,786.6	0.00	1.00
08/30/2026 16:00	2	2.0	11.8	13.2	19.8	971,224.2	0.00	1.00
08/30/2026 17:00	3	2.0	12.4	12.9	22.2	975,201.3	0.00	1.00
08/30/2026 18:00	1	1.9	11.0	13.6	17.1	999,679.8	0.00	1.00
08/30/2026 19:00	1	1.8	10.4	13.8	16.6	1,015,495.7	0.00	1.00
08/30/2026 20:00	1	1.8	10.2	13.9	16.4	1,028,437.7	0.00	1.00
08/30/2026 21:00	1	1.8	10.1	13.9	16.0	1,030,002.8	0.00	1.00
08/30/2026 22:00	0	1.8	9.9	14.0	15.4	1,041,357.9	0.00	1.00
08/30/2026 23:00	0	1.8	9.8	14.0	14.8	1,035,403.9	0.00	1.00
Average/Sum#:	1	1.8	10.3	13.8	16.3	1,024,282.0	0.00 #	24.00 #
Minimum:	0	1.7	9.5	12.9	14.3	967,786.6	0.00	1.00
Maximum:	3	2.0	12.4	14.2	22.2	1,056,705.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/31/2026 00:00	0	1.7	9.6	14.0	14.4	1,032,426.9	0.00	1.00
08/31/2026 01:00	0	1.7	9.6	14.1	14.2	1,044,790.3	0.00	1.00
08/31/2026 02:00	0	1.8	10.0	14.1	14.0	1,044,588.9	0.00	1.00
08/31/2026 03:00	0	1.7	9.8	14.1	13.9	1,043,783.3	0.00	1.00
08/31/2026 04:00	0	1.7	9.6	14.1	13.3	1,043,179.2	0.00	1.00
08/31/2026 05:00	-1	1.7	8.9	14.2	9.3	944,698.4	0.00	1.00
08/31/2026 06:00	-2	1.7	8.2	14.2	4.8	774,644.5	0.00	1.00
08/31/2026 07:00	-2	1.7	8.3	14.2	5.8	774,644.5	0.00	1.00
08/31/2026 08:00	-2	1.7	9.0	14.3	6.5	785,136.6	0.00	1.00
08/31/2026 09:00	-1	1.7	8.8	14.3	6.8	785,136.6	0.00	1.00
08/31/2026 10:00	-1	1.7	8.7	14.3	6.8	784,721.7	0.00	1.00
08/31/2026 11:00	-1	1.7	8.6	14.3	6.9	784,514.2	0.00	1.00
08/31/2026 12:00	-1	1.7	8.6	14.4	8.2	857,681.0	0.00	1.00
08/31/2026 13:00	0	1.8	10.8	13.9	15.7	1,036,654.3	0.00	1.00
08/31/2026 14:00	0	1.8	10.8	13.9	15.9	1,030,394.0	0.00	1.00
08/31/2026 15:00	0	1.8	10.8	13.9	16.1	1,029,807.1	0.00	1.00
08/31/2026 16:00	0	1.8	10.8	13.9	16.2	1,029,415.9	0.00	1.00
08/31/2026 17:00	0	1.8	10.5	14.0	15.8	1,038,976.3	0.00	1.00
08/31/2026 18:00	0	1.8	10.1	14.0	15.0	1,033,220.8	0.00	1.00
08/31/2026 19:00	0	1.7	10.0	14.1	14.8	1,050,429.1	0.00	1.00
08/31/2026 20:00	0	1.7	9.9	14.1	14.4	1,047,609.7	0.00	1.00
08/31/2026 21:00	-1	1.7	9.0	14.2	8.3	870,708.6	0.00	1.00
08/31/2026 22:00	-2	1.7	8.5	14.3	5.4	785,759.1	0.00	1.00
08/31/2026 23:00	-2	1.7	8.5	14.3	6.4	841,366.0	0.00	1.00
Average/Sum#:	-1	1.7	9.5	14.1	11.2	937,262.0	0.00 #	24.00 #
Minimum:	-2	1.7	8.2	13.9	4.8	774,644.5	0.00	1.00
Maximum:	0	1.8	10.8	14.4	16.2	1,050,429.1	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/01/2026 00:00	-2	1.7	8.6	14.3	6.5	839,498.6	0.00	1.00
09/01/2026 01:00	-2	1.7	8.8	14.2	5.6	774,031.4	0.00	1.00
09/01/2026 02:00	-2	1.7	9.1	14.2	5.6	773,827.0	0.00	1.00
09/01/2026 03:00	-2	1.7	9.0	14.2	5.7	773,213.8	0.00	1.00
09/01/2026 04:00	-2	1.7	8.9	14.2	5.7	773,622.6	0.00	1.00
09/01/2026 05:00	-2	1.7	8.9	14.2	5.6	774,031.4	0.00	1.00
09/01/2026 06:00	-2	1.7	8.9	14.2	6.0	773,213.8	0.00	1.00
09/01/2026 07:00	-2	1.7	8.8	14.3	6.6	784,721.7	0.00	1.00
09/01/2026 08:00	-1	1.7	8.8	14.3	7.0	784,514.2	0.00	1.00
09/01/2026 09:00	-1	1.7	8.7	14.3	7.5	783,061.8	0.00	1.00
09/01/2026 10:00	-1	1.7	8.7	14.3	7.4	782,854.3	0.00	1.00
09/01/2026 11:00	-1	1.7	8.7	14.3	7.2	781,401.9	0.00	1.00
09/01/2026 12:00	-1	1.7	8.7	14.3	6.8	780,571.9	0.00	1.00
09/01/2026 13:00	-1	1.7	8.8	14.4	7.5	791,738.0	0.00	1.00
09/01/2026 14:00	-1	1.7	8.8	14.4	7.0	791,316.6	0.00	1.00
09/01/2026 15:00	-1	1.7	8.8	14.4	7.5	790,473.9	0.00	1.00
09/01/2026 16:00	-2	1.7	8.8	14.4	7.0	790,473.9	0.00	1.00
09/01/2026 17:00	-1	1.7	8.7	14.4	7.6	824,814.8	0.00	1.00
09/01/2026 18:00	-1	1.7	9.0	14.3	7.4	780,571.9	0.00	1.00
09/01/2026 19:00	-1	1.7	8.8	14.3	7.4	780,986.9	0.00	1.00
09/01/2026 20:00	-1	1.7	8.8	14.3	7.3	782,854.3	0.00	1.00
09/01/2026 21:00	-1	1.7	8.8	14.3	7.0	783,684.2	0.00	1.00
09/01/2026 22:00	-2	1.7	8.8	14.3	6.7	784,929.2	0.00	1.00
09/01/2026 23:00	-2	1.7	8.8	14.2	6.5	774,235.8	0.00	1.00
Average/Sum#:	-1	1.7	8.8	14.3	6.8	785,610.2	0.00 #	24.00 #
Minimum:	-2	1.7	8.6	14.2	5.6	773,213.8	0.00	1.00
Maximum:	-1	1.7	9.1	14.4	7.6	839,498.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/02/2026 00:00	-2	1.7	8.8	14.2	6.3	775,053.3	0.00	1.00
09/02/2026 01:00	-2	1.7	8.8	14.2	6.5	775,053.3	0.00	1.00
09/02/2026 02:00	-2	1.7	9.0	14.2	6.4	775,257.7	0.00	1.00
09/02/2026 03:00	-2	1.7	8.9	14.2	6.3	775,053.3	0.00	1.00
09/02/2026 04:00	-2	1.7	8.8	14.2	6.5	775,462.1	0.00	1.00
09/02/2026 05:00	-2	1.7	8.8	14.2	6.4	775,257.7	0.00	1.00
09/02/2026 06:00	-1	1.7	8.8	14.2	6.7	774,848.9	0.00	1.00
09/02/2026 07:00	-1	1.7	8.6	14.3	6.9	786,174.1	0.00	1.00
09/02/2026 08:00	-1	1.7	8.6	14.3	7.3	785,966.6	0.00	1.00
09/02/2026 09:00	-1	1.7	8.6	14.3	7.5	785,344.1	0.00	1.00
09/02/2026 10:00	-2	1.7	8.5	14.3	6.3	783,891.7	0.00	1.00
09/02/2026 11:00	-2	1.7	8.5	14.3	6.1	781,816.8	0.00	1.00
09/02/2026 12:00	-1	1.7	8.6	14.3	6.7	779,534.5	0.00	1.00
09/02/2026 13:00	-2	1.7	8.6	14.4	6.4	790,684.6	0.00	1.00
09/02/2026 14:00	-2	1.7	8.6	14.4	5.9	790,473.9	0.00	1.00
09/02/2026 15:00	-2	1.7	8.6	14.4	6.0	790,263.2	0.00	1.00
09/02/2026 16:00	-2	1.7	8.6	14.4	6.6	798,690.4	0.00	1.00
09/02/2026 17:00	-1	1.7	8.6	14.4	7.8	852,203.3	0.00	1.00
09/02/2026 18:00	-1	1.7	8.9	14.3	7.6	779,327.0	0.00	1.00
09/02/2026 19:00	-1	1.7	8.8	14.3	7.9	777,874.5	0.00	1.00
09/02/2026 20:00	-1	1.7	8.8	14.3	7.9	778,912.0	0.00	1.00
09/02/2026 21:00	-1	1.7	8.8	14.3	7.6	779,741.9	0.00	1.00
09/02/2026 22:00	-1	1.7	8.8	14.3	7.6	779,949.4	0.00	1.00
09/02/2026 23:00	-1	1.7	8.8	14.3	7.4	780,779.4	0.00	1.00
Average/Sum#:	-2	1.7	8.7	14.3	6.9	784,483.9	0.00 #	24.00 #
Minimum:	-2	1.7	8.5	14.2	5.9	774,848.9	0.00	1.00
Maximum:	-1	1.7	9.0	14.4	7.9	852,203.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/03/2026 00:00	-1	1.7	8.8	14.3	7.3	781,401.9	0.00	1.00
09/03/2026 01:00	-1	1.7	8.8	14.3	7.0	781,816.8	0.00	1.00
09/03/2026 02:00	-2	1.7	9.0	14.2	6.4	770,761.1	0.00	1.00
09/03/2026 03:00	-2	1.7	8.9	14.2	6.0	770,761.1	0.00	1.00
09/03/2026 04:00	-2	1.7	8.9	14.2	6.2	770,556.7	0.00	1.00
09/03/2026 05:00	-2	1.7	8.8	14.2	6.0	771,987.4	0.00	1.00
09/03/2026 06:00	-2	1.7	8.8	14.2	6.4	780,980.7	0.00	1.00
09/03/2026 07:00	-1	1.7	8.5	14.3	7.1	837,216.3	0.00	1.00
09/03/2026 08:00	-1	1.7	8.7	14.3	8.0	828,294.3	0.00	1.00
09/03/2026 09:00	-1	1.7	8.3	14.4	8.6	887,808.4	0.00	1.00
09/03/2026 10:00	-1	1.7	8.6	14.3	8.1	845,515.8	0.00	1.00
09/03/2026 11:00	-2	1.7	8.5	14.3	6.0	780,156.9	0.00	1.00
09/03/2026 12:00	-2	1.7	8.3	14.4	6.5	857,049.0	0.00	1.00
09/03/2026 13:00	-1	1.7	8.2	14.5	9.0	973,575.1	0.00	1.00
09/03/2026 14:00	-1	1.6	8.1	14.5	8.9	975,500.9	0.00	1.00
09/03/2026 15:00	-1	1.6	8.1	14.5	8.7	974,217.1	0.00	1.00
09/03/2026 16:00	-2	1.7	8.3	14.3	5.9	819,787.2	0.00	1.00
09/03/2026 17:00	-1	1.7	8.2	14.4	7.3	893,707.4	0.00	1.00
09/03/2026 18:00	-1	1.7	8.6	14.2	7.2	776,075.3	0.00	1.00
09/03/2026 19:00	-1	1.7	8.5	14.3	7.6	854,852.8	0.00	1.00
09/03/2026 20:00	-1	1.7	8.0	14.4	8.4	963,232.0	0.00	1.00
09/03/2026 21:00	-1	1.7	8.0	14.4	8.7	970,184.5	0.00	1.00
09/03/2026 22:00	-1	1.7	7.9	14.4	9.0	971,659.3	0.00	1.00
09/03/2026 23:00	-1	1.7	8.0	14.4	9.3	961,757.3	0.00	1.00
Average/Sum#:	-1	1.7	8.5	14.3	7.5	858,285.6	0.00 #	24.00 #
Minimum:	-2	1.6	7.9	14.2	5.9	770,556.7	0.00	1.00
Maximum:	-1	1.7	9.0	14.5	9.3	975,500.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/04/2026 00:00	-1	1.7	8.3	14.3	7.2	821,032.2	0.00	1.00
09/04/2026 01:00	-1	1.7	8.3	14.2	7.1	771,783.1	0.00	1.00
09/04/2026 02:00	-1	1.7	8.7	14.2	7.3	771,578.7	0.00	1.00
09/04/2026 03:00	-1	1.7	8.6	14.2	7.3	771,578.7	0.00	1.00
09/04/2026 04:00	-1	1.7	8.4	14.2	7.5	796,923.2	0.00	1.00
09/04/2026 05:00	-1	1.7	8.4	14.4	9.6	951,644.6	0.00	1.00
09/04/2026 06:00	-1	1.7	8.6	14.3	8.0	827,256.8	0.00	1.00
09/04/2026 07:00	-1	1.7	8.6	14.3	8.7	840,121.1	0.00	1.00
09/04/2026 08:00	-1	1.7	8.6	14.3	8.1	782,854.3	0.00	1.00
09/04/2026 09:00	-1	1.7	8.6	14.3	8.6	782,231.8	0.00	1.00
09/04/2026 10:00	-1	1.7	8.6	14.4	9.2	864,844.2	0.00	1.00
09/04/2026 11:00	-1	1.7	8.6	14.3	7.9	780,364.4	0.00	1.00
09/04/2026 12:00	-1	1.7	8.7	14.4	7.3	791,948.7	0.00	1.00
09/04/2026 13:00	-1	1.7	8.7	14.4	7.0	792,370.0	0.00	1.00
09/04/2026 14:00	-2	1.7	8.7	14.4	6.8	791,316.6	0.00	1.00
09/04/2026 15:00	-1	1.7	8.7	14.4	7.5	790,684.6	0.00	1.00
09/04/2026 16:00	-2	1.7	8.6	14.4	7.0	825,025.5	0.00	1.00
09/04/2026 17:00	-1	1.6	8.6	14.5	8.1	873,863.9	0.00	1.00
09/04/2026 18:00	-1	1.6	8.4	14.5	10.3	981,920.1	0.00	1.00
09/04/2026 19:00	-1	1.6	8.5	14.5	10.8	979,138.4	0.00	1.00
09/04/2026 20:00	0	1.6	8.5	14.5	11.7	979,780.4	0.00	1.00
09/04/2026 21:00	0	1.6	8.4	14.5	11.9	982,562.0	0.00	1.00
09/04/2026 22:00	0	1.6	8.5	14.4	11.4	964,285.4	0.00	1.00
09/04/2026 23:00	-1	1.7	8.9	14.3	8.8	799,868.3	0.00	1.00
Average/Sum#:	-1	1.7	8.6	14.4	8.5	846,457.4	0.00 #	24.00 #
Minimum:	-2	1.6	8.3	14.2	6.8	771,578.7	0.00	1.00
Maximum:	0	1.7	8.9	14.5	11.9	982,562.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/05/2026 00:00	-1	1.7	8.8	14.3	8.7	824,767.0	0.00	1.00
09/05/2026 01:00	-1	1.7	8.9	14.3	8.1	819,579.7	0.00	1.00
09/05/2026 02:00	-1	1.9	9.2	14.3	7.0	842,818.5	0.00	1.00
09/05/2026 03:00	-1	1.7	9.2	14.2	7.0	774,031.4	0.00	1.00
09/05/2026 04:00	-1	1.7	8.7	14.3	8.5	900,085.3	0.00	1.00
09/05/2026 05:00	-1	1.7	8.8	14.4	9.6	964,074.8	0.00	1.00
09/05/2026 06:00	-2	1.7	9.0	14.2	6.6	771,578.7	0.00	1.00
09/05/2026 07:00	-1	1.7	8.9	14.3	8.0	783,061.8	0.00	1.00
09/05/2026 08:00	-1	1.7	8.7	14.3	8.4	782,024.3	0.00	1.00
09/05/2026 09:00	-1	1.7	8.7	14.3	8.6	781,816.8	0.00	1.00
09/05/2026 10:00	-1	1.7	8.7	14.4	8.0	792,580.7	0.00	1.00
09/05/2026 11:00	-1	1.7	8.7	14.4	8.2	791,105.9	0.00	1.00
09/05/2026 12:00	-1	1.7	8.7	14.4	8.0	790,473.9	0.00	1.00
09/05/2026 13:00	-1	1.7	8.8	14.4	7.8	790,684.6	0.00	1.00
09/05/2026 14:00	-1	1.6	8.8	14.4	7.6	791,316.6	0.00	1.00
09/05/2026 15:00	-2	1.6	8.7	14.4	6.3	791,316.6	0.00	1.00
09/05/2026 16:00	-2	1.7	8.6	14.4	6.4	790,684.6	0.00	1.00
09/05/2026 17:00	-1	1.7	8.3	14.4	7.4	858,734.4	0.00	1.00
09/05/2026 18:00	-1	1.6	9.1	14.4	8.9	813,227.4	0.00	1.00
09/05/2026 19:00	-1	1.7	8.9	14.4	8.9	826,078.9	0.00	1.00
09/05/2026 20:00	-1	1.7	8.9	14.4	8.8	795,951.6	0.00	1.00
09/05/2026 21:00	-1	1.7	9.0	14.4	9.7	826,711.0	0.00	1.00
09/05/2026 22:00	0	1.7	9.0	14.4	10.1	832,610.0	0.00	1.00
09/05/2026 23:00	-1	1.7	8.9	14.3	9.6	807,337.9	0.00	1.00
Average/Sum#:	-1	1.7	8.8	14.4	8.2	814,277.2	0.00 #	24.00 #
Minimum:	-2	1.6	8.3	14.2	6.3	771,578.7	0.00	1.00
Maximum:	0	1.9	9.2	14.4	10.1	964,074.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/06/2026 00:00	-1	1.7	9.0	14.3	8.8	782,854.3	0.00	1.00
09/06/2026 01:00	-1	1.7	9.0	14.3	8.7	790,323.9	0.00	1.00
09/06/2026 02:00	-1	1.7	9.1	14.3	8.6	815,637.5	0.00	1.00
09/06/2026 03:00	-1	1.7	9.1	14.3	7.6	782,231.8	0.00	1.00
09/06/2026 04:00	-1	1.7	9.0	14.3	7.3	791,153.8	0.00	1.00
09/06/2026 05:00	-1	1.7	9.1	14.2	7.4	772,600.6	0.00	1.00
09/06/2026 06:00	-1	1.7	8.8	14.3	8.0	855,060.3	0.00	1.00
09/06/2026 07:00	-1	1.7	8.8	14.3	7.6	782,231.8	0.00	1.00
09/06/2026 08:00	-1	1.7	8.7	14.3	8.5	781,609.3	0.00	1.00
09/06/2026 09:00	-1	1.7	8.7	14.3	8.8	780,779.4	0.00	1.00
09/06/2026 10:00	-1	1.7	8.7	14.4	8.4	792,159.3	0.00	1.00
09/06/2026 11:00	-1	1.7	8.9	14.4	8.3	790,473.9	0.00	1.00
09/06/2026 12:00	-1	1.6	8.9	14.4	8.2	788,577.8	0.00	1.00
09/06/2026 13:00	-1	1.6	9.0	14.4	8.0	788,999.1	0.00	1.00
09/06/2026 14:00	-1	1.7	9.0	14.5	7.8	803,680.9	0.00	1.00
09/06/2026 15:00	-1	1.6	9.1	14.6	9.2	894,473.2	0.00	1.00
09/06/2026 16:00	-2	1.6	9.1	14.5	7.7	850,113.0	0.00	1.00
09/06/2026 17:00	-2	1.7	9.1	14.4	6.8	788,999.1	0.00	1.00
09/06/2026 18:00	-1	1.7	8.9	14.4	8.0	790,473.9	0.00	1.00
09/06/2026 19:00	-1	1.7	8.8	14.4	9.0	791,316.6	0.00	1.00
09/06/2026 20:00	0	1.7	8.9	14.3	9.4	779,949.4	0.00	1.00
09/06/2026 21:00	0	1.7	8.9	14.3	9.1	781,194.4	0.00	1.00
09/06/2026 22:00	-1	1.7	8.8	14.3	8.8	782,439.3	0.00	1.00
09/06/2026 23:00	-1	1.7	8.8	14.4	9.4	853,256.7	0.00	1.00
Average/Sum#:	-1	1.7	8.9	14.4	8.3	800,441.2	0.00 #	24.00 #
Minimum:	-2	1.6	8.7	14.2	6.8	772,600.6	0.00	1.00
Maximum:	0	1.7	9.1	14.6	9.4	894,473.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/07/2026 00:00	-1	1.7	8.9	14.3	8.5	781,816.8	0.00	1.00
09/07/2026 01:00	-1	1.7	9.0	14.3	8.7	783,269.2	0.00	1.00
09/07/2026 02:00	-1	1.7	9.2	14.3	7.8	783,476.7	0.00	1.00
09/07/2026 03:00	-1	1.7	9.2	14.3	8.3	783,476.7	0.00	1.00
09/07/2026 04:00	-1	1.7	9.1	14.3	8.0	783,684.2	0.00	1.00
09/07/2026 05:00	-1	1.7	9.1	14.3	8.4	783,269.2	0.00	1.00
09/07/2026 06:00	-1	1.7	9.0	14.3	8.5	825,181.9	0.00	1.00
09/07/2026 07:00	-1	1.7	8.9	14.3	8.2	781,816.8	0.00	1.00
09/07/2026 08:00	-1	1.7	8.9	14.3	8.8	780,779.4	0.00	1.00
09/07/2026 09:00	-1	1.7	8.8	14.4	8.3	790,895.3	0.00	1.00
09/07/2026 10:00	-1	1.7	8.8	14.4	7.7	789,841.8	0.00	1.00
09/07/2026 11:00	-1	1.7	8.7	14.4	7.1	788,577.8	0.00	1.00
09/07/2026 12:00	-2	1.6	8.7	14.4	6.8	787,524.4	0.00	1.00
09/07/2026 13:00	-2	1.6	8.6	14.5	6.4	799,401.5	0.00	1.00
09/07/2026 14:00	-2	1.6	8.6	14.5	6.5	802,825.0	0.00	1.00
09/07/2026 15:00	-2	1.6	8.4	14.5	6.1	796,833.8	0.00	1.00
09/07/2026 16:00	-2	1.6	8.1	14.5	6.6	876,217.6	0.00	1.00
09/07/2026 17:00	-2	1.6	8.7	14.4	7.1	845,882.9	0.00	1.00
09/07/2026 18:00	-2	1.6	8.8	14.5	7.4	856,746.1	0.00	1.00
09/07/2026 19:00	-1	1.6	8.7	14.6	10.2	981,203.4	0.00	1.00
09/07/2026 20:00	0	1.6	8.6	14.6	11.9	985,985.6	0.00	1.00
09/07/2026 21:00	0	1.6	8.6	14.6	11.7	984,898.7	0.00	1.00
09/07/2026 22:00	0	1.6	8.6	14.5	11.3	968,225.8	0.00	1.00
09/07/2026 23:00	0	1.6	8.5	14.5	11.6	970,365.6	0.00	1.00
Average/Sum#:	-1	1.7	8.8	14.4	8.4	838,008.2	0.00 #	24.00 #
Minimum:	-2	1.6	8.1	14.3	6.1	780,779.4	0.00	1.00
Maximum:	0	1.7	9.2	14.6	11.9	985,985.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/08/2026 00:00	0	1.6	8.5	14.5	11.5	969,723.6	0.00	1.00
09/08/2026 01:00	-1	1.6	8.9	14.4	10.0	878,959.8	0.00	1.00
09/08/2026 02:00	-1	1.7	9.2	14.3	8.3	772,687.3	0.00	1.00
09/08/2026 03:00	-1	1.7	9.1	14.3	9.1	800,905.8	0.00	1.00
09/08/2026 04:00	-1	1.7	8.8	14.4	10.6	932,051.3	0.00	1.00
09/08/2026 05:00	0	1.7	8.7	14.4	11.3	955,436.9	0.00	1.00
09/08/2026 06:00	-1	1.7	8.9	14.3	8.5	834,103.9	0.00	1.00
09/08/2026 07:00	-1	1.7	8.9	14.3	7.8	773,517.3	0.00	1.00
09/08/2026 08:00	-1	1.7	8.8	14.4	7.8	784,785.5	0.00	1.00
09/08/2026 09:00	-1	1.7	8.7	14.4	7.2	784,574.8	0.00	1.00
09/08/2026 10:00	-2	1.6	8.5	14.4	6.6	782,468.0	0.00	1.00
09/08/2026 11:00	-2	1.6	8.5	14.4	6.1	780,993.3	0.00	1.00
09/08/2026 12:00	-2	1.6	8.4	14.5	5.9	816,733.3	0.00	1.00
09/08/2026 13:00	-1	1.6	7.8	14.5	7.7	972,719.3	0.00	1.00
09/08/2026 14:00	3	2.1	12.4	12.8	22.9	1,021,151.0	0.00	1.00
09/08/2026 15:00	4	2.2	13.5	12.4	27.2	1,020,623.9	0.00	1.00
09/08/2026 16:00	4	2.2	13.4	12.3	27.7	1,019,743.5	0.00	1.00
09/08/2026 17:00	5	2.2	13.3	12.2	29.7	1,024,707.2	0.00	1.00
09/08/2026 18:00	4	2.2	13.5	12.3	29.1	1,033,915.4	0.00	1.00
09/08/2026 19:00	4	2.2	13.7	12.3	29.2	1,030,889.9	0.00	1.00
09/08/2026 20:00	4	2.1	14.1	12.5	28.7	1,033,263.3	0.00	1.00
09/08/2026 21:00	5	2.2	14.2	12.4	30.5	1,015,629.6	0.00	1.00
09/08/2026 22:00	3	2.0	12.6	13.1	24.2	1,019,694.5	0.00	1.00
09/08/2026 23:00	-1	1.6	8.4	14.5	10.3	952,605.8	0.00	1.00
Average/Sum#:	1	1.8	10.5	13.7	15.7	917,161.8	0.00 #	24.00 #
Minimum:	-2	1.6	7.8	12.2	5.9	772,687.3	0.00	1.00
Maximum:	5	2.2	14.2	14.5	30.5	1,033,915.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/09/2026 00:00	0	1.7	8.8	14.4	11.3	900,238.5	0.00	1.00
09/09/2026 01:00	-1	1.7	8.8	14.3	9.3	817,712.3	0.00	1.00
09/09/2026 02:00	-1	1.7	8.9	14.3	8.9	775,384.7	0.00	1.00
09/09/2026 03:00	0	1.7	8.9	14.3	8.8	776,422.1	0.00	1.00
09/09/2026 04:00	0	1.7	8.9	14.3	9.7	808,790.3	0.00	1.00
09/09/2026 05:00	0	1.7	9.8	14.2	16.2	1,031,156.1	0.00	1.00
09/09/2026 06:00	1	1.8	10.5	13.9	18.5	1,039,588.7	0.00	1.00
09/09/2026 07:00	1	2.0	12.8	13.3	22.7	1,048,510.6	0.00	1.00
09/09/2026 08:00	2	2.1	14.8	12.6	30.2	1,039,607.6	0.00	1.00
09/09/2026 09:00	2	2.2	14.8	12.4	31.1	1,025,457.2	0.00	1.00
09/09/2026 10:00	2	2.3	14.4	12.2	31.8	986,143.0	0.00	1.00
09/09/2026 11:00	1	2.1	13.7	12.4	25.8	1,010,151.9	0.00	1.00
09/09/2026 12:00	1	2.1	13.5	12.6	24.4	1,021,293.6	0.00	1.00
09/09/2026 13:00	2	2.2	14.4	12.4	27.8	1,028,840.5	0.00	1.00
09/09/2026 14:00	2	2.2	13.6	12.3	28.8	1,020,061.9	0.00	1.00
09/09/2026 15:00	3	2.3	13.1	12.1	31.6	1,020,688.0	0.00	1.00
09/09/2026 16:00	3	2.2	13.1	12.1	31.8	1,018,353.8	0.00	1.00
09/09/2026 17:00	2	2.2	13.8	12.3	28.5	1,014,011.0	0.00	1.00
09/09/2026 18:00	2	2.3	12.9	12.1	30.8	1,014,930.2	0.00	1.00
09/09/2026 19:00	1	2.1	13.5	12.6	24.7	1,022,613.5	0.00	1.00
09/09/2026 20:00	2	2.3	13.2	12.2	30.0	1,025,966.5	0.00	1.00
09/09/2026 21:00	2	2.2	13.1	12.2	29.6	1,025,809.0	0.00	1.00
09/09/2026 22:00	2	2.1	13.4	12.6	26.7	1,030,203.1	0.00	1.00
09/09/2026 23:00	0	1.6	8.5	14.6	11.3	992,941.4	0.00	1.00
Average/Sum#:	1	2.0	12.1	13.0	22.9	978,953.1	0.00 #	24.00 #
Minimum:	-1	1.6	8.5	12.1	8.8	775,384.7	0.00	1.00
Maximum:	3	2.3	14.8	14.6	31.8	1,048,510.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/10/2026 00:00	0	1.6	8.5	14.6	11.8	992,289.3	0.00	1.00
09/10/2026 01:00	0	1.6	8.4	14.6	11.8	987,072.4	0.00	1.00
09/10/2026 02:00	0	1.6	8.9	14.6	11.9	967,291.8	0.00	1.00
09/10/2026 03:00	0	1.6	9.0	14.4	8.5	788,156.4	0.00	1.00
09/10/2026 04:00	0	1.7	8.7	14.4	8.7	804,168.1	0.00	1.00
09/10/2026 05:00	0	1.6	8.3	14.6	11.1	976,856.1	0.00	1.00
09/10/2026 06:00	0	1.6	8.6	14.5	9.5	863,379.3	0.00	1.00
09/10/2026 07:00	-1	1.6	8.6	14.4	7.2	781,203.9	0.00	1.00
09/10/2026 08:00	0	1.7	8.6	14.4	7.8	780,150.5	0.00	1.00
09/10/2026 09:00	-1	1.6	8.6	14.5	7.5	792,126.4	0.00	1.00
09/10/2026 10:00	-1	1.6	8.3	14.5	6.6	789,986.7	0.00	1.00
09/10/2026 11:00	-1	1.6	7.7	14.5	6.4	849,471.1	0.00	1.00
09/10/2026 12:00	0	1.8	10.0	13.8	14.4	1,002,958.7	0.00	1.00
09/10/2026 13:00	0	1.8	10.1	13.7	14.6	998,919.0	0.00	1.00
09/10/2026 14:00	0	1.9	10.2	13.6	15.3	994,802.4	0.00	1.00
09/10/2026 15:00	0	1.8	10.3	13.6	14.8	1,000,055.0	0.00	1.00
09/10/2026 16:00	1	2.0	11.2	13.2	18.7	1,003,236.7	0.00	1.00
09/10/2026 17:00	1	2.1	12.3	12.8	22.2	1,002,892.0	0.00	1.00
09/10/2026 18:00	0	1.8	10.1	13.7	14.6	1,004,244.5	0.00	1.00
09/10/2026 19:00	0	1.8	9.9	13.9	15.2	1,021,590.6	0.00	1.00
09/10/2026 20:00	0	1.8	10.1	13.9	17.0	1,021,395.0	0.00	1.00
09/10/2026 21:00	1	1.8	11.2	13.7	18.8	1,002,342.6	0.00	1.00
09/10/2026 22:00	0	1.8	11.1	13.8	18.7	1,009,709.4	0.00	1.00
09/10/2026 23:00	0	1.6	8.9	14.4	9.0	801,640.0	0.00	1.00
Average/Sum#:	0	1.7	9.5	14.1	12.6	926,497.4	0.00 #	24.00 #
Minimum:	-1	1.6	7.7	12.8	6.4	780,150.5	0.00	1.00
Maximum:	1	2.1	12.3	14.6	22.2	1,021,590.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/11/2026 00:00	0	1.7	8.9	14.4	9.1	784,153.5	0.00	1.00
09/11/2026 01:00	0	1.7	9.0	14.4	9.4	785,417.6	0.00	1.00
09/11/2026 02:00	0	1.7	9.4	14.4	9.3	785,206.9	0.00	1.00
09/11/2026 03:00	0	1.7	9.3	14.3	9.1	773,517.3	0.00	1.00
09/11/2026 04:00	0	1.7	9.2	14.3	9.0	774,347.2	0.00	1.00
09/11/2026 05:00	0	1.7	9.1	14.3	8.7	775,177.2	0.00	1.00
09/11/2026 06:00	0	1.7	9.0	14.3	8.4	775,592.2	0.00	1.00
09/11/2026 07:00	0	1.7	8.9	14.3	8.7	774,762.2	0.00	1.00
09/11/2026 08:00	0	1.7	8.8	14.3	9.2	773,932.3	0.00	1.00
09/11/2026 09:00	0	1.7	8.8	14.3	9.1	773,102.3	0.00	1.00
09/11/2026 10:00	0	1.7	8.7	14.4	8.7	784,153.5	0.00	1.00
09/11/2026 11:00	-1	1.7	8.7	14.4	7.5	783,100.1	0.00	1.00
09/11/2026 12:00	-1	1.7	8.7	14.4	6.7	782,468.0	0.00	1.00
09/11/2026 13:00	-1	1.6	8.7	14.5	7.1	794,052.2	0.00	1.00
09/11/2026 14:00	-1	1.6	8.7	14.5	7.1	794,480.1	0.00	1.00
09/11/2026 15:00	-1	1.6	8.0	14.5	7.9	933,990.2	0.00	1.00
09/11/2026 16:00	-1	1.7	8.2	14.4	7.1	855,784.9	0.00	1.00
09/11/2026 17:00	0	1.7	8.3	14.3	7.5	837,423.8	0.00	1.00
09/11/2026 18:00	-1	1.7	8.3	14.3	6.4	774,762.2	0.00	1.00
09/11/2026 19:00	0	1.7	8.2	14.2	7.4	763,811.8	0.00	1.00
09/11/2026 20:00	0	1.7	8.3	14.3	8.1	774,762.2	0.00	1.00
09/11/2026 21:00	0	1.7	8.6	14.3	8.6	773,309.8	0.00	1.00
09/11/2026 22:00	0	1.7	8.7	14.3	8.7	773,724.8	0.00	1.00
09/11/2026 23:00	0	1.7	8.7	14.3	8.4	773,102.3	0.00	1.00
Average/Sum#:	0	1.7	8.7	14.4	8.2	790,588.9	0.00 #	24.00 #
Minimum:	-1	1.6	8.0	14.2	6.4	763,811.8	0.00	1.00
Maximum:	0	1.7	9.4	14.5	9.4	933,990.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/12/2026 00:00	0	1.7	8.8	14.3	8.4	773,517.3	0.00	1.00
09/12/2026 01:00	0	1.7	8.8	14.3	8.4	773,309.8	0.00	1.00
09/12/2026 02:00	0	1.7	9.0	14.3	8.3	773,724.8	0.00	1.00
09/12/2026 03:00	0	1.7	9.0	14.3	8.3	774,139.8	0.00	1.00
09/12/2026 04:00	0	1.7	9.0	14.3	8.3	773,724.8	0.00	1.00
09/12/2026 05:00	0	1.7	9.1	14.3	8.3	774,347.2	0.00	1.00
09/12/2026 06:00	0	1.7	9.1	14.3	8.4	774,554.7	0.00	1.00
09/12/2026 07:00	0	1.7	8.9	14.3	8.5	774,554.7	0.00	1.00
09/12/2026 08:00	0	1.7	8.8	14.3	8.7	773,309.8	0.00	1.00
09/12/2026 09:00	-1	1.7	8.8	14.4	7.4	784,364.2	0.00	1.00
09/12/2026 10:00	0	1.7	8.7	14.4	7.7	782,889.4	0.00	1.00
09/12/2026 11:00	-1	1.7	8.7	14.4	7.3	781,203.9	0.00	1.00
09/12/2026 12:00	-1	1.7	8.7	14.4	6.8	780,782.6	0.00	1.00
09/12/2026 13:00	-1	1.6	8.7	14.5	6.6	792,126.4	0.00	1.00
09/12/2026 14:00	-1	1.6	8.7	14.5	6.7	791,484.5	0.00	1.00
09/12/2026 15:00	-1	1.6	8.7	14.5	6.7	791,912.4	0.00	1.00
09/12/2026 16:00	-1	1.6	8.6	14.5	7.6	840,056.3	0.00	1.00
09/12/2026 17:00	0	1.7	8.8	14.4	7.8	788,156.4	0.00	1.00
09/12/2026 18:00	0	1.7	8.8	14.4	8.0	783,100.1	0.00	1.00
09/12/2026 19:00	0	1.7	8.8	14.3	8.1	772,687.3	0.00	1.00
09/12/2026 20:00	0	1.7	8.8	14.3	7.8	773,102.3	0.00	1.00
09/12/2026 21:00	-1	1.7	8.8	14.3	7.3	774,347.2	0.00	1.00
09/12/2026 22:00	-1	1.7	8.8	14.3	7.4	782,439.3	0.00	1.00
09/12/2026 23:00	-1	1.7	8.9	14.3	6.9	775,592.2	0.00	1.00
Average/Sum#:	0	1.7	8.8	14.4	7.7	781,642.8	0.00 #	24.00 #
Minimum:	-1	1.6	8.6	14.3	6.6	772,687.3	0.00	1.00
Maximum:	0	1.7	9.1	14.5	8.7	840,056.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/13/2026 00:00	-1	1.7	8.9	14.3	6.8	776,422.1	0.00	1.00
09/13/2026 01:00	-1	1.7	9.0	14.3	6.7	777,044.6	0.00	1.00
09/13/2026 02:00	-1	1.7	9.3	14.3	6.5	777,667.1	0.00	1.00
09/13/2026 03:00	-1	1.7	9.2	14.3	6.2	777,874.5	0.00	1.00
09/13/2026 04:00	-1	1.7	9.2	14.3	6.3	778,289.5	0.00	1.00
09/13/2026 05:00	-1	1.7	8.8	14.3	7.4	887,013.5	0.00	1.00
09/13/2026 06:00	-1	1.7	9.3	14.3	7.5	823,937.0	0.00	1.00
09/13/2026 07:00	-1	1.7	9.1	14.3	7.5	777,044.6	0.00	1.00
09/13/2026 08:00	0	1.7	9.1	14.3	8.2	776,837.1	0.00	1.00
09/13/2026 09:00	0	1.7	9.0	14.3	8.3	776,422.1	0.00	1.00
09/13/2026 10:00	0	1.7	8.9	14.3	8.1	775,799.7	0.00	1.00
09/13/2026 11:00	0	1.7	8.9	14.3	8.5	774,969.7	0.00	1.00
09/13/2026 12:00	-1	1.7	8.8	14.4	7.6	785,838.9	0.00	1.00
09/13/2026 13:00	-1	1.7	8.8	14.4	6.8	785,838.9	0.00	1.00
09/13/2026 14:00	-1	1.7	8.8	14.4	6.1	784,996.2	0.00	1.00
09/13/2026 15:00	-1	1.7	8.8	14.4	6.1	784,574.8	0.00	1.00
09/13/2026 16:00	-1	1.7	8.6	14.5	6.8	851,182.8	0.00	1.00
09/13/2026 17:00	-1	1.6	8.8	14.6	8.7	940,990.2	0.00	1.00
09/13/2026 18:00	-1	1.6	9.2	14.4	6.8	791,316.6	0.00	1.00
09/13/2026 19:00	-1	1.7	9.1	14.4	6.6	785,838.9	0.00	1.00
09/13/2026 20:00	-1	1.7	9.1	14.4	7.2	787,313.7	0.00	1.00
09/13/2026 21:00	-1	1.7	9.0	14.3	7.0	775,177.2	0.00	1.00
09/13/2026 22:00	-1	1.7	9.1	14.3	7.0	776,214.6	0.00	1.00
09/13/2026 23:00	-1	1.7	9.2	14.3	7.3	776,837.1	0.00	1.00
Average/Sum#:	-1	1.7	9.0	14.4	7.2	796,060.1	0.00 #	24.00 #
Minimum:	-1	1.6	8.6	14.3	6.1	774,969.7	0.00	1.00
Maximum:	0	1.7	9.3	14.6	8.7	940,990.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/14/2026 00:00	-1	1.7	9.2	14.3	7.1	777,252.1	0.00	1.00
09/14/2026 01:00	-1	1.7	9.2	14.3	7.1	777,252.1	0.00	1.00
09/14/2026 02:00	-1	1.7	9.4	14.3	6.4	777,044.6	0.00	1.00
09/14/2026 03:00	-1	1.7	9.3	14.2	6.2	766,264.5	0.00	1.00
09/14/2026 04:00	-1	1.7	9.3	14.2	6.9	766,468.9	0.00	1.00
09/14/2026 05:00	-1	1.7	9.2	14.2	6.8	776,484.1	0.00	1.00
09/14/2026 06:00	-1	1.7	9.4	14.2	7.8	802,646.2	0.00	1.00
09/14/2026 07:00	-1	1.7	9.3	14.2	6.7	765,855.7	0.00	1.00
09/14/2026 08:00	-1	1.7	9.2	14.3	6.9	775,592.2	0.00	1.00
09/14/2026 09:00	-1	1.7	9.1	14.3	6.7	774,762.2	0.00	1.00
09/14/2026 10:00	-1	1.7	9.0	14.4	6.4	785,628.2	0.00	1.00
09/14/2026 11:00	-1	1.7	9.0	14.4	6.4	784,364.2	0.00	1.00
09/14/2026 12:00	-1	1.7	9.0	14.4	6.2	784,364.2	0.00	1.00
09/14/2026 13:00	-1	1.7	9.0	14.4	6.5	783,521.4	0.00	1.00
09/14/2026 14:00	-1	1.7	8.9	14.5	6.3	795,122.0	0.00	1.00
09/14/2026 15:00	-1	1.6	8.9	14.4	6.1	782,889.4	0.00	1.00
09/14/2026 16:00	-1	1.6	8.8	14.5	6.9	836,632.7	0.00	1.00
09/14/2026 17:00	-1	1.6	8.4	14.5	6.3	867,016.8	0.00	1.00
09/14/2026 18:00	-1	1.6	9.0	14.4	6.6	784,785.5	0.00	1.00
09/14/2026 19:00	-1	1.6	9.0	14.4	6.7	806,696.3	0.00	1.00
09/14/2026 20:00	-1	1.7	9.0	14.4	6.2	790,052.5	0.00	1.00
09/14/2026 21:00	-1	1.7	9.0	14.4	6.5	785,628.2	0.00	1.00
09/14/2026 22:00	-1	1.7	8.9	14.3	6.6	777,459.6	0.00	1.00
09/14/2026 23:00	-1	1.7	8.9	14.4	8.9	913,511.4	0.00	1.00
Average/Sum#:	-1	1.7	9.1	14.3	6.7	793,220.6	0.00 #	24.00 #
Minimum:	-1	1.6	8.4	14.2	6.1	765,855.7	0.00	1.00
Maximum:	-1	1.7	9.4	14.5	8.9	913,511.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/15/2026 00:00	-1	1.7	9.2	14.4	7.6	845,040.2	0.00	1.00
09/15/2026 01:00	-1	1.7	9.1	14.3	7.2	789,078.9	0.00	1.00
09/15/2026 02:00	-1	1.7	9.4	14.3	7.0	777,667.1	0.00	1.00
09/15/2026 03:00	-1	1.7	9.3	14.3	7.0	777,459.6	0.00	1.00
09/15/2026 04:00	-1	1.7	9.1	14.3	7.3	802,980.7	0.00	1.00
09/15/2026 05:00	0	1.7	8.7	14.4	9.6	960,282.5	0.00	1.00
09/15/2026 06:00	0	1.7	8.7	14.4	9.6	960,071.8	0.00	1.00
09/15/2026 07:00	-1	1.7	8.9	14.4	9.0	941,110.6	0.00	1.00
09/15/2026 08:00	-1	1.6	8.4	14.5	8.9	976,356.8	0.00	1.00
09/15/2026 09:00	-1	1.6	8.4	14.5	8.8	974,217.1	0.00	1.00
09/15/2026 10:00	-1	1.6	8.7	14.5	7.9	927,999.0	0.00	1.00
09/15/2026 11:00	-1	1.6	8.4	14.6	8.8	991,202.4	0.00	1.00
09/15/2026 12:00	-1	1.6	8.2	14.6	7.9	964,248.7	0.00	1.00
09/15/2026 13:00	-1	1.6	8.4	14.6	9.0	964,900.8	0.00	1.00
09/15/2026 14:00	-1	1.6	8.8	14.6	9.9	963,813.9	0.00	1.00
09/15/2026 15:00	-1	1.6	8.8	14.6	9.2	957,075.5	0.00	1.00
09/15/2026 16:00	-1	1.6	8.9	14.5	6.7	838,986.4	0.00	1.00
09/15/2026 17:00	-1	1.6	8.5	14.4	5.6	792,159.3	0.00	1.00
09/15/2026 18:00	-1	1.7	8.9	14.4	6.9	787,735.0	0.00	1.00
09/15/2026 19:00	-1	1.7	8.9	14.4	6.5	788,577.8	0.00	1.00
09/15/2026 20:00	-1	1.7	8.8	14.3	6.4	778,497.0	0.00	1.00
09/15/2026 21:00	-1	1.7	8.8	14.3	6.4	779,534.5	0.00	1.00
09/15/2026 22:00	-1	1.7	8.8	14.3	6.5	779,741.9	0.00	1.00
09/15/2026 23:00	-1	1.7	8.9	14.3	6.9	780,364.4	0.00	1.00
Average/Sum#:	-1	1.7	8.8	14.4	7.8	870,795.9	0.00 #	24.00 #
Minimum:	-1	1.6	8.2	14.3	5.6	777,459.6	0.00	1.00
Maximum:	0	1.7	9.4	14.6	9.9	991,202.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/16/2026 00:00	-1	1.7	9.0	14.2	6.8	769,126.0	0.00	1.00
09/16/2026 01:00	-1	1.7	9.0	14.2	6.7	769,739.1	0.00	1.00
09/16/2026 02:00	-1	1.7	9.2	14.2	6.7	770,352.3	0.00	1.00
09/16/2026 03:00	-1	1.7	9.1	14.2	6.7	771,169.9	0.00	1.00
09/16/2026 04:00	-1	1.7	9.0	14.2	6.4	771,987.4	0.00	1.00
09/16/2026 05:00	-1	1.7	9.0	14.2	6.4	773,213.8	0.00	1.00
09/16/2026 06:00	-1	1.7	9.0	14.2	6.5	787,316.8	0.00	1.00
09/16/2026 07:00	0	0.0	0.0	0.0	5.9	244,203.1	0.02	0.30
09/16/2026 08:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2026 09:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2026 10:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2026 11:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2026 12:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2026 13:00	0	0.0	0.0	0.0	0.0	0.0	0.00	0.00
09/16/2026 14:00	0	1.4	5.5	20.2	0.0	424,521.6	0.07	0.07
09/16/2026 15:00	0	7.6	13.6	15.4	4.0	806,217.5	0.93	0.97
09/16/2026 16:00	-1	1.7	8.8	14.4	5.6	792,370.0	0.00	1.00
09/16/2026 17:00	-1	1.7	8.7	14.3	5.7	779,741.9	0.00	1.00
09/16/2026 18:00	-1	1.7	8.7	14.3	5.8	780,986.9	0.00	1.00
09/16/2026 19:00	-1	1.7	8.8	14.3	6.0	781,816.8	0.00	1.00
09/16/2026 20:00	-1	1.7	8.8	14.3	6.1	782,646.8	0.00	1.00
09/16/2026 21:00	-1	1.7	8.8	14.3	6.1	783,269.2	0.00	1.00
09/16/2026 22:00	-1	1.7	8.7	14.3	6.0	783,891.7	0.00	1.00
09/16/2026 23:00	-1	1.7	8.7	14.3	6.1	783,684.2	0.00	1.00
Average/Sum#:	-1	2.0	9.0	14.7	5.8	759,532.5	1.02 #	16.34 #
Minimum:	-1	1.4	5.5	14.2	0.0	424,521.6	0.00	0.00
Maximum:	0	7.6	13.6	20.2	6.8	806,217.5	0.93	1.00
%SI	33.33	29.17	29.17	29.17	25.00	29.17	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/17/2026 00:00	-1	1.7	8.7	14.3	6.0	783,891.7	0.00	1.00
09/17/2026 01:00	-1	1.7	8.7	14.3	5.9	784,099.2	0.00	1.00
09/17/2026 02:00	-1	1.7	8.9	14.3	5.8	784,929.2	0.00	1.00
09/17/2026 03:00	-1	1.7	8.8	14.3	6.0	784,929.2	0.00	1.00
09/17/2026 04:00	-1	1.7	8.7	14.3	6.0	784,514.2	0.00	1.00
09/17/2026 05:00	-1	1.7	8.3	14.3	6.6	867,094.6	0.00	1.00
09/17/2026 06:00	-1	1.7	8.6	14.3	7.1	860,455.0	0.00	1.00
09/17/2026 07:00	-1	1.7	8.5	14.3	5.1	783,684.2	0.00	1.00
09/17/2026 08:00	-1	1.7	8.4	14.3	5.4	783,476.7	0.00	1.00
09/17/2026 09:00	-1	1.7	8.4	14.3	5.0	783,684.2	0.00	1.00
09/17/2026 10:00	-1	1.7	8.5	14.3	5.3	782,854.3	0.00	1.00
09/17/2026 11:00	-1	1.7	8.5	14.3	5.0	781,816.8	0.00	1.00
09/17/2026 12:00	-1	1.7	8.4	14.4	4.7	793,212.7	0.00	1.00
09/17/2026 13:00	-1	1.7	8.4	14.4	4.5	793,212.7	0.00	1.00
09/17/2026 14:00	-1	1.7	8.4	14.4	4.7	792,580.7	0.00	1.00
09/17/2026 15:00	-1	1.7	8.4	14.4	4.4	792,580.7	0.00	1.00
09/17/2026 16:00	-1	1.7	8.3	14.4	5.0	825,868.2	0.00	1.00
09/17/2026 17:00	-1	1.7	8.5	14.4	4.3	792,580.7	0.00	1.00
09/17/2026 18:00	-1	1.7	8.4	14.3	4.5	780,986.9	0.00	1.00
09/17/2026 19:00	-1	1.7	8.5	14.3	5.2	781,401.9	0.00	1.00
09/17/2026 20:00	-1	1.7	8.5	14.3	5.5	782,231.8	0.00	1.00
09/17/2026 21:00	-1	1.7	8.5	14.3	5.6	782,646.8	0.00	1.00
09/17/2026 22:00	-1	1.7	8.4	14.3	5.9	782,439.3	0.00	1.00
09/17/2026 23:00	-1	1.7	8.5	14.3	5.9	782,854.3	0.00	1.00
Average/Sum#:	-1	1.7	8.5	14.3	5.4	793,667.8	0.00 #	24.00 #
Minimum:	-1	1.7	8.3	14.3	4.3	780,986.9	0.00	1.00
Maximum:	-1	1.7	8.9	14.4	7.1	867,094.6	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/18/2026 00:00	-1	1.7	8.5	14.3	6.2	783,269.2	0.00	1.00
09/18/2026 01:00	-1	1.7	8.5	14.3	6.3	783,684.2	0.00	1.00
09/18/2026 02:00	-1	1.7	8.8	14.3	6.3	783,684.2	0.00	1.00
09/18/2026 03:00	-1	1.7	8.7	14.3	6.8	784,099.2	0.00	1.00
09/18/2026 04:00	-1	1.7	8.8	14.3	6.9	784,721.7	0.00	1.00
09/18/2026 05:00	-1	1.7	8.8	14.3	6.9	784,721.7	0.00	1.00
09/18/2026 06:00	0	1.7	8.6	14.3	8.0	864,397.3	0.00	1.00
09/18/2026 07:00	-1	1.7	8.7	14.3	6.1	788,456.5	0.00	1.00
09/18/2026 08:00	-1	1.7	8.5	14.3	5.7	783,269.2	0.00	1.00
09/18/2026 09:00	-1	1.7	8.4	14.3	5.3	782,024.3	0.00	1.00
09/18/2026 10:00	-1	1.7	8.3	14.4	4.9	793,634.1	0.00	1.00
09/18/2026 11:00	-1	1.7	8.2	14.4	4.8	792,159.3	0.00	1.00
09/18/2026 12:00	-1	1.7	8.2	14.4	4.3	791,527.3	0.00	1.00
09/18/2026 13:00	-1	1.7	8.2	14.4	4.4	795,530.2	0.00	1.00
09/18/2026 14:00	-1	1.6	8.3	14.4	4.3	789,841.8	0.00	1.00
09/18/2026 15:00	-1	1.7	8.3	14.4	4.6	789,841.8	0.00	1.00
09/18/2026 16:00	-1	1.6	8.2	14.5	7.2	916,444.5	0.00	1.00
09/18/2026 17:00	-1	1.6	8.5	14.6	8.7	991,202.4	0.00	1.00
09/18/2026 18:00	-1	1.7	8.4	14.4	4.7	794,266.1	0.00	1.00
09/18/2026 19:00	-1	1.7	8.4	14.4	5.3	790,263.2	0.00	1.00
09/18/2026 20:00	-1	1.7	8.3	14.4	5.2	791,527.3	0.00	1.00
09/18/2026 21:00	-1	1.7	8.3	14.3	5.4	780,571.9	0.00	1.00
09/18/2026 22:00	-1	1.7	8.4	14.3	5.6	781,609.3	0.00	1.00
09/18/2026 23:00	-1	1.7	8.4	14.3	5.7	781,816.8	0.00	1.00
Average/Sum#:	-1	1.7	8.4	14.4	5.8	804,273.5	0.00 #	24.00 #
Minimum:	-1	1.6	8.2	14.3	4.3	780,571.9	0.00	1.00
Maximum:	0	1.7	8.8	14.6	8.7	991,202.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/19/2026 00:00	-1	1.7	8.4	14.3	5.6	782,439.3	0.00	1.00
09/19/2026 01:00	-1	1.7	8.4	14.3	5.6	782,854.3	0.00	1.00
09/19/2026 02:00	-1	1.7	8.7	14.3	5.6	783,269.2	0.00	1.00
09/19/2026 03:00	-1	1.7	8.7	14.3	5.8	782,646.8	0.00	1.00
09/19/2026 04:00	-1	1.7	8.7	14.3	6.0	783,061.8	0.00	1.00
09/19/2026 05:00	-1	1.7	8.6	14.3	5.7	783,061.8	0.00	1.00
09/19/2026 06:00	-1	1.7	8.6	14.3	6.1	782,854.3	0.00	1.00
09/19/2026 07:00	-1	1.7	8.6	14.3	5.6	782,854.3	0.00	1.00
09/19/2026 08:00	-1	1.7	8.5	14.3	5.7	781,609.3	0.00	1.00
09/19/2026 09:00	-1	1.7	8.4	14.3	5.6	780,986.9	0.00	1.00
09/19/2026 10:00	-1	1.7	8.4	14.4	5.2	792,159.3	0.00	1.00
09/19/2026 11:00	-1	1.7	8.4	14.4	4.9	790,684.6	0.00	1.00
09/19/2026 12:00	-1	1.7	8.3	14.4	5.1	790,263.2	0.00	1.00
09/19/2026 13:00	-1	1.7	8.4	14.5	5.5	802,183.1	0.00	1.00
09/19/2026 14:00	-1	1.6	8.4	14.5	5.4	800,899.3	0.00	1.00
09/19/2026 15:00	-1	1.6	8.4	14.5	5.7	800,471.3	0.00	1.00
09/19/2026 16:00	-1	1.6	8.3	14.5	5.7	828,287.8	0.00	1.00
09/19/2026 17:00	-1	1.6	8.2	14.5	4.8	799,187.5	0.00	1.00
09/19/2026 18:00	-1	1.7	8.2	14.4	5.0	789,209.8	0.00	1.00
09/19/2026 19:00	-1	1.7	8.3	14.4	5.3	790,895.3	0.00	1.00
09/19/2026 20:00	-1	1.7	8.3	14.4	5.2	791,316.6	0.00	1.00
09/19/2026 21:00	-1	1.7	8.3	14.4	5.8	803,957.5	0.00	1.00
09/19/2026 22:00	-1	1.6	8.3	14.4	6.4	835,980.9	0.00	1.00
09/19/2026 23:00	-1	1.7	8.3	14.4	6.4	822,286.7	0.00	1.00
Average/Sum#:	-1	1.7	8.4	14.4	5.6	794,309.2	0.00 #	24.00 #
Minimum:	-1	1.6	8.2	14.3	4.8	780,986.9	0.00	1.00
Maximum:	-1	1.7	8.7	14.5	6.4	835,980.9	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/20/2026 00:00	-1	1.7	8.4	14.3	6.4	803,603.1	0.00	1.00
09/20/2026 01:00	-1	1.7	8.4	14.3	6.3	780,986.9	0.00	1.00
09/20/2026 02:00	-1	1.7	8.6	14.3	6.3	781,401.9	0.00	1.00
09/20/2026 03:00	-1	1.7	8.6	14.3	6.3	781,816.8	0.00	1.00
09/20/2026 04:00	-1	1.7	8.6	14.3	6.3	782,231.8	0.00	1.00
09/20/2026 05:00	-1	1.7	8.6	14.3	6.4	783,269.2	0.00	1.00
09/20/2026 06:00	-1	1.7	8.6	14.3	6.6	785,344.1	0.00	1.00
09/20/2026 07:00	-1	1.7	8.5	14.3	6.2	783,269.2	0.00	1.00
09/20/2026 08:00	-1	1.7	8.4	14.3	6.1	782,439.3	0.00	1.00
09/20/2026 09:00	-1	1.7	8.3	14.3	6.0	781,194.4	0.00	1.00
09/20/2026 10:00	-1	1.7	8.3	14.4	5.3	791,948.7	0.00	1.00
09/20/2026 11:00	-1	1.7	8.3	14.4	5.1	791,738.0	0.00	1.00
09/20/2026 12:00	-1	1.7	8.3	14.4	5.1	791,105.9	0.00	1.00
09/20/2026 13:00	-1	1.6	8.0	14.5	6.5	889,056.0	0.00	1.00
09/20/2026 14:00	-1	1.6	8.3	14.6	9.0	994,028.2	0.00	1.00
09/20/2026 15:00	-1	1.6	8.4	14.6	8.7	972,291.3	0.00	1.00
09/20/2026 16:00	-1	1.6	8.2	14.6	7.6	939,468.6	0.00	1.00
09/20/2026 17:00	-1	1.6	8.3	14.4	4.8	795,108.9	0.00	1.00
09/20/2026 18:00	-1	1.7	8.2	14.4	4.7	791,105.9	0.00	1.00
09/20/2026 19:00	-1	1.7	8.3	14.3	5.6	780,571.9	0.00	1.00
09/20/2026 20:00	-1	1.7	8.4	14.3	6.1	780,779.4	0.00	1.00
09/20/2026 21:00	-1	1.7	8.5	14.3	6.5	780,779.4	0.00	1.00
09/20/2026 22:00	-1	1.7	8.5	14.3	6.5	781,194.4	0.00	1.00
09/20/2026 23:00	-1	1.7	8.5	14.3	6.6	794,473.6	0.00	1.00
Average/Sum#:	-1	1.7	8.4	14.4	6.3	813,300.3	0.00 #	24.00 #
Minimum:	-1	1.6	8.0	14.3	4.7	780,571.9	0.00	1.00
Maximum:	-1	1.7	8.6	14.6	9.0	994,028.2	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/21/2026 00:00	-1	1.7	8.5	14.3	6.5	780,779.4	0.00	1.00
09/21/2026 01:00	-1	1.7	8.5	14.3	6.5	781,401.9	0.00	1.00
09/21/2026 02:00	-1	1.7	8.7	14.3	6.4	782,024.3	0.00	1.00
09/21/2026 03:00	-1	1.7	8.6	14.3	6.7	782,024.3	0.00	1.00
09/21/2026 04:00	-1	1.7	8.4	14.3	7.4	824,352.0	0.00	1.00
09/21/2026 05:00	0	1.6	8.2	14.4	8.2	937,950.4	0.00	1.00
09/21/2026 06:00	0	1.7	8.4	14.3	8.2	900,500.3	0.00	1.00
09/21/2026 07:00	-1	1.6	8.2	14.4	7.7	903,820.1	0.00	1.00
09/21/2026 08:00	-1	1.7	8.3	14.3	6.9	843,855.9	0.00	1.00
09/21/2026 09:00	-1	1.7	8.3	14.3	5.7	783,269.2	0.00	1.00
09/21/2026 10:00	-1	1.7	8.3	14.3	5.4	782,439.3	0.00	1.00
09/21/2026 11:00	-1	1.7	8.2	14.4	5.2	793,212.7	0.00	1.00
09/21/2026 12:00	-1	1.7	8.2	14.4	5.0	792,580.7	0.00	1.00
09/21/2026 13:00	-1	1.7	8.2	14.4	4.9	791,738.0	0.00	1.00
09/21/2026 14:00	-1	1.7	8.2	14.4	5.2	818,073.1	0.00	1.00
09/21/2026 15:00	-1	1.7	8.2	14.4	4.8	790,473.9	0.00	1.00
09/21/2026 16:00	-1	1.7	8.1	14.4	5.8	823,129.4	0.00	1.00
09/21/2026 17:00	-1	1.7	8.4	14.4	6.0	791,105.9	0.00	1.00
09/21/2026 18:00	-1	1.7	8.3	14.4	5.9	792,370.0	0.00	1.00
09/21/2026 19:00	-1	1.7	8.3	14.3	6.4	781,194.4	0.00	1.00
09/21/2026 20:00	-1	1.7	8.4	14.3	5.9	781,816.8	0.00	1.00
09/21/2026 21:00	-1	1.7	8.4	14.3	6.0	782,439.3	0.00	1.00
09/21/2026 22:00	-1	1.7	8.4	14.3	6.1	782,646.8	0.00	1.00
09/21/2026 23:00	-1	1.7	8.5	14.3	6.2	783,061.8	0.00	1.00
Average/Sum#:	-1	1.7	8.3	14.3	6.2	808,594.2	0.00 #	24.00 #
Minimum:	-1	1.6	8.1	14.3	4.8	780,779.4	0.00	1.00
Maximum:	0	1.7	8.7	14.4	8.2	937,950.4	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/22/2026 00:00	-1	1.7	8.5	14.3	6.5	783,061.8	0.00	1.00
09/22/2026 01:00	-1	1.7	8.5	14.3	6.4	783,684.2	0.00	1.00
09/22/2026 02:00	-1	1.7	8.7	14.3	6.3	784,306.7	0.00	1.00
09/22/2026 03:00	-1	1.7	8.7	14.3	6.6	784,721.7	0.00	1.00
09/22/2026 04:00	-1	1.7	8.7	14.3	6.7	784,929.2	0.00	1.00
09/22/2026 05:00	-1	1.7	8.6	14.3	6.6	786,796.6	0.00	1.00
09/22/2026 06:00	-1	1.7	8.6	14.3	6.9	818,127.3	0.00	1.00
09/22/2026 07:00	-1	1.7	8.5	14.3	6.0	785,759.1	0.00	1.00
09/22/2026 08:00	-1	1.7	8.4	14.3	5.7	784,929.2	0.00	1.00
09/22/2026 09:00	-1	1.7	8.3	14.3	5.4	783,476.7	0.00	1.00
09/22/2026 10:00	-1	1.7	8.2	14.3	5.2	781,816.8	0.00	1.00
09/22/2026 11:00	-1	1.7	8.2	14.4	4.7	792,791.4	0.00	1.00
09/22/2026 12:00	-1	1.7	8.2	14.4	4.4	792,159.3	0.00	1.00
09/22/2026 13:00	-1	1.7	8.2	14.4	4.4	790,473.9	0.00	1.00
09/22/2026 14:00	-1	1.7	8.1	14.4	4.4	790,052.5	0.00	1.00
09/22/2026 15:00	-1	1.7	8.1	14.4	4.6	789,841.8	0.00	1.00
09/22/2026 16:00	-1	1.7	8.1	14.4	4.8	807,960.4	0.00	1.00
09/22/2026 17:00	-1	1.7	8.3	14.4	4.9	788,999.1	0.00	1.00
09/22/2026 18:00	-1	1.7	8.3	14.4	5.0	789,841.8	0.00	1.00
09/22/2026 19:00	-1	1.7	8.3	14.4	4.9	791,948.7	0.00	1.00
09/22/2026 20:00	-1	1.7	8.3	14.4	5.4	792,791.4	0.00	1.00
09/22/2026 21:00	0	1.7	8.4	14.3	8.4	899,255.3	0.00	1.00
09/22/2026 22:00	0	1.8	9.5	14.0	13.9	1,031,831.5	0.00	1.00
09/22/2026 23:00	-1	1.6	8.3	14.3	6.4	829,746.7	0.00	1.00
Average/Sum#:	-1	1.7	8.4	14.3	6.0	806,221.0	0.00 #	24.00 #
Minimum:	-1	1.6	8.1	14.0	4.4	781,816.8	0.00	1.00
Maximum:	0	1.8	9.5	14.4	13.9	1,031,831.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/23/2026 00:00	-1	1.7	8.2	14.3	5.5	783,269.2	0.00	1.00
09/23/2026 01:00	-1	1.7	8.3	14.3	6.5	784,306.7	0.00	1.00
09/23/2026 02:00	-1	1.7	8.6	14.3	6.0	783,891.7	0.00	1.00
09/23/2026 03:00	-1	1.7	8.5	14.3	6.4	784,721.7	0.00	1.00
09/23/2026 04:00	-1	1.7	8.5	14.3	6.4	793,021.2	0.00	1.00
09/23/2026 05:00	-1	1.7	8.3	14.3	7.4	866,679.6	0.00	1.00
09/23/2026 06:00	-1	1.7	8.6	14.3	7.7	844,478.4	0.00	1.00
09/23/2026 07:00	-1	1.7	8.4	14.3	6.7	784,306.7	0.00	1.00
09/23/2026 08:00	-1	1.7	8.3	14.3	5.9	783,061.8	0.00	1.00
09/23/2026 09:00	-1	1.7	8.2	14.4	5.2	793,423.4	0.00	1.00
09/23/2026 10:00	-1	1.7	8.1	14.4	4.2	792,791.4	0.00	1.00
09/23/2026 11:00	-1	1.7	8.0	14.4	4.5	791,316.6	0.00	1.00
09/23/2026 12:00	-1	1.6	8.0	14.4	4.4	790,052.5	0.00	1.00
09/23/2026 13:00	-1	1.6	8.0	14.5	5.1	821,868.6	0.00	1.00
09/23/2026 14:00	-1	1.6	7.8	14.5	4.3	809,672.2	0.00	1.00
09/23/2026 15:00	-1	1.6	7.8	14.5	5.3	836,418.7	0.00	1.00
09/23/2026 16:00	-1	1.6	7.6	14.5	5.9	885,204.5	0.00	1.00
09/23/2026 17:00	-1	1.7	8.0	14.4	5.1	797,637.0	0.00	1.00
09/23/2026 18:00	-1	1.6	7.9	14.4	5.0	789,631.2	0.00	1.00
09/23/2026 19:00	-1	1.6	7.6	14.6	8.0	986,855.0	0.00	1.00
09/23/2026 20:00	-1	1.6	8.2	14.5	7.4	881,139.0	0.00	1.00
09/23/2026 21:00	-1	1.7	8.2	14.4	5.5	807,539.0	0.00	1.00
09/23/2026 22:00	-1	1.7	8.2	14.3	5.4	781,194.4	0.00	1.00
09/23/2026 23:00	-1	1.7	8.3	14.3	5.8	782,024.3	0.00	1.00
Average/Sum#:	-1	1.7	8.2	14.4	5.8	814,771.0	0.00 #	24.00 #
Minimum:	-1	1.6	7.6	14.3	4.2	781,194.4	0.00	1.00
Maximum:	-1	1.7	8.6	14.6	8.0	986,855.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/24/2026 00:00	-1	1.7	8.3	14.3	6.3	782,854.3	0.00	1.00
09/24/2026 01:00	-1	1.7	8.3	14.3	5.9	781,609.3	0.00	1.00
09/24/2026 02:00	-1	1.7	8.6	14.3	6.1	782,231.8	0.00	1.00
09/24/2026 03:00	-1	1.7	8.6	14.3	6.2	781,609.3	0.00	1.00
09/24/2026 04:00	-1	1.7	8.6	14.3	6.3	789,286.4	0.00	1.00
09/24/2026 05:00	-1	1.7	8.3	14.4	7.7	894,550.1	0.00	1.00
09/24/2026 06:00	-1	1.7	8.5	14.3	7.8	862,322.4	0.00	1.00
09/24/2026 07:00	-1	1.7	8.5	14.3	5.5	782,439.3	0.00	1.00
09/24/2026 08:00	-1	1.7	8.5	14.4	5.5	793,002.1	0.00	1.00
09/24/2026 09:00	-1	1.7	8.5	14.4	5.4	791,527.3	0.00	1.00
09/24/2026 10:00	-1	1.6	8.5	14.5	5.6	802,397.1	0.00	1.00
09/24/2026 11:00	-1	1.6	8.3	14.5	5.4	801,541.2	0.00	1.00
09/24/2026 12:00	-1	1.6	8.2	14.5	5.8	801,327.2	0.00	1.00
09/24/2026 13:00	-1	1.6	7.9	14.5	6.6	868,086.7	0.00	1.00
09/24/2026 14:00	-1	1.6	7.6	14.4	6.3	880,645.2	0.00	1.00
09/24/2026 15:00	-1	1.6	7.5	14.4	6.1	891,811.3	0.00	1.00
09/24/2026 16:00	-1	1.7	7.6	14.4	6.3	881,487.9	0.00	1.00
09/24/2026 17:00	0	1.7	8.0	14.3	10.2	974,781.2	0.00	1.00
09/24/2026 18:00	0	1.9	10.9	13.6	16.0	1,034,572.0	0.00	1.00
09/24/2026 19:00	-1	1.6	8.3	14.5	6.7	848,615.2	0.00	1.00
09/24/2026 20:00	-1	1.7	8.3	14.4	6.4	789,209.8	0.00	1.00
09/24/2026 21:00	-1	1.7	8.5	14.4	6.6	790,052.5	0.00	1.00
09/24/2026 22:00	-1	1.7	8.6	14.4	6.8	791,105.9	0.00	1.00
09/24/2026 23:00	-1	1.7	8.6	14.4	6.8	791,316.6	0.00	1.00
Average/Sum#:	-1	1.7	8.4	14.4	6.8	832,849.3	0.00 #	24.00 #
Minimum:	-1	1.6	7.5	13.6	5.4	781,609.3	0.00	1.00
Maximum:	0	1.9	10.9	14.5	16.0	1,034,572.0	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/25/2026 00:00	-1	1.7	8.7	14.3	6.8	779,327.0	0.00	1.00
09/25/2026 01:00	-1	1.7	8.7	14.3	6.9	779,741.9	0.00	1.00
09/25/2026 02:00	-1	1.7	9.0	14.3	6.8	779,949.4	0.00	1.00
09/25/2026 03:00	-1	1.7	8.9	14.3	6.9	780,571.9	0.00	1.00
09/25/2026 04:00	-1	1.7	8.9	14.3	6.9	780,779.4	0.00	1.00
09/25/2026 05:00	-1	1.7	8.8	14.3	7.0	787,626.5	0.00	1.00
09/25/2026 06:00	-1	1.7	8.8	14.3	7.7	811,902.7	0.00	1.00
09/25/2026 07:00	-1	1.7	8.6	14.4	6.7	830,292.5	0.00	1.00
09/25/2026 08:00	-1	1.7	8.4	14.3	6.3	778,497.0	0.00	1.00
09/25/2026 09:00	-1	1.7	8.3	14.4	5.8	789,631.2	0.00	1.00
09/25/2026 10:00	-1	1.7	8.2	14.4	5.4	788,999.1	0.00	1.00
09/25/2026 11:00	-1	1.7	8.2	14.4	5.2	786,892.3	0.00	1.00
09/25/2026 12:00	-1	1.7	8.2	14.4	5.1	785,206.9	0.00	1.00
09/25/2026 13:00	-1	1.6	8.3	14.4	5.7	784,574.8	0.00	1.00
09/25/2026 14:00	-1	1.6	8.5	14.5	6.2	796,191.9	0.00	1.00
09/25/2026 15:00	-1	1.6	8.5	14.5	6.1	795,550.0	0.00	1.00
09/25/2026 16:00	-1	1.6	8.4	14.5	6.2	813,095.7	0.00	1.00
09/25/2026 17:00	-1	1.7	8.5	14.4	5.8	784,996.2	0.00	1.00
09/25/2026 18:00	-1	1.7	8.4	14.4	5.5	786,681.6	0.00	1.00
09/25/2026 19:00	-1	1.7	8.4	14.4	6.2	787,735.0	0.00	1.00
09/25/2026 20:00	-1	1.7	8.5	14.4	6.7	788,999.1	0.00	1.00
09/25/2026 21:00	-1	1.7	8.7	14.4	7.0	789,631.2	0.00	1.00
09/25/2026 22:00	-1	1.7	8.7	14.3	7.0	778,082.0	0.00	1.00
09/25/2026 23:00	-1	1.7	8.7	14.3	6.9	778,082.0	0.00	1.00
Average/Sum#:	-1	1.7	8.6	14.4	6.4	789,293.2	0.00 #	24.00 #
Minimum:	-1	1.6	8.2	14.3	5.1	778,082.0	0.00	1.00
Maximum:	-1	1.7	9.0	14.5	7.7	830,292.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/26/2026 00:00	-1	1.7	8.6	14.3	6.9	778,704.5	0.00	1.00
09/26/2026 01:00	-1	1.7	8.7	14.3	6.8	779,741.9	0.00	1.00
09/26/2026 02:00	-1	1.7	8.9	14.3	6.8	780,156.9	0.00	1.00
09/26/2026 03:00	-1	1.7	8.9	14.3	6.8	779,949.4	0.00	1.00
09/26/2026 04:00	-1	1.7	8.8	14.3	7.1	779,534.5	0.00	1.00
09/26/2026 05:00	-1	1.7	8.8	14.3	7.1	780,156.9	0.00	1.00
09/26/2026 06:00	-1	1.7	8.7	14.3	7.0	780,156.9	0.00	1.00
09/26/2026 07:00	-1	1.7	8.6	14.3	6.7	780,779.4	0.00	1.00
09/26/2026 08:00	-1	1.7	8.5	14.3	6.5	781,194.4	0.00	1.00
09/26/2026 09:00	-1	1.7	8.5	14.3	5.8	780,156.9	0.00	1.00
09/26/2026 10:00	-1	1.7	8.4	14.4	5.4	791,738.0	0.00	1.00
09/26/2026 11:00	-1	1.7	8.4	14.4	5.5	790,473.9	0.00	1.00
09/26/2026 12:00	-1	1.7	8.3	14.4	5.1	789,631.2	0.00	1.00
09/26/2026 13:00	-1	1.7	8.5	14.4	5.5	788,367.1	0.00	1.00
09/26/2026 14:00	-1	1.6	8.7	14.5	6.0	800,043.4	0.00	1.00
09/26/2026 15:00	-1	1.7	8.7	14.5	5.9	799,401.5	0.00	1.00
09/26/2026 16:00	-1	1.7	8.0	14.4	5.8	884,648.2	0.00	1.00
09/26/2026 17:00	-1	1.7	8.0	14.4	7.3	964,285.4	0.00	1.00
09/26/2026 18:00	-1	1.6	8.7	14.5	7.3	880,925.0	0.00	1.00
09/26/2026 19:00	0	1.6	8.3	14.6	9.6	994,245.6	0.00	1.00
09/26/2026 20:00	-1	1.6	8.5	14.6	9.5	988,594.0	0.00	1.00
09/26/2026 21:00	0	1.6	8.5	14.6	9.6	988,811.4	0.00	1.00
09/26/2026 22:00	0	1.7	9.0	14.4	12.4	981,982.6	0.00	1.00
09/26/2026 23:00	1	2.1	14.6	12.7	26.8	1,050,782.7	0.00	1.00
Average/Sum#:	-1	1.7	8.8	14.3	7.9	845,602.6	0.00 #	24.00 #
Minimum:	-1	1.6	8.0	12.7	5.1	778,704.5	0.00	1.00
Maximum:	1	2.1	14.6	14.6	26.8	1,050,782.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/27/2026 00:00	0	1.8	10.4	14.0	15.6	1,038,579.4	0.00	1.00
09/27/2026 01:00	0	1.7	9.2	14.2	11.8	947,151.1	0.00	1.00
09/27/2026 02:00	-1	1.6	8.3	14.4	8.3	900,870.6	0.00	1.00
09/27/2026 03:00	0	1.6	8.7	14.3	7.6	834,311.4	0.00	1.00
09/27/2026 04:00	-1	1.7	8.6	14.3	6.7	793,643.7	0.00	1.00
09/27/2026 05:00	0	1.7	8.5	14.4	7.9	866,951.0	0.00	1.00
09/27/2026 06:00	0	1.6	8.4	14.4	9.2	948,273.7	0.00	1.00
09/27/2026 07:00	0	1.7	8.3	14.4	9.0	948,484.4	0.00	1.00
09/27/2026 08:00	-1	1.7	8.5	14.3	6.6	825,804.4	0.00	1.00
09/27/2026 09:00	-1	1.7	8.4	14.3	5.8	781,194.4	0.00	1.00
09/27/2026 10:00	-1	1.7	8.4	14.3	5.6	780,779.4	0.00	1.00
09/27/2026 11:00	-1	1.7	8.4	14.3	5.4	780,364.4	0.00	1.00
09/27/2026 12:00	-1	1.7	8.4	14.4	5.2	790,473.9	0.00	1.00
09/27/2026 13:00	-1	1.7	8.4	14.4	5.1	788,999.1	0.00	1.00
09/27/2026 14:00	-1	1.7	8.5	14.4	5.3	798,690.4	0.00	1.00
09/27/2026 15:00	-1	1.7	8.4	14.5	6.4	847,545.3	0.00	1.00
09/27/2026 16:00	-1	1.7	8.7	14.4	8.7	917,514.3	0.00	1.00
09/27/2026 17:00	0	2.0	13.0	12.9	20.4	1,048,465.5	0.00	1.00
09/27/2026 18:00	0	2.0	12.8	13.0	20.5	1,050,296.5	0.00	1.00
09/27/2026 19:00	1	2.0	12.7	13.0	21.0	1,048,563.1	0.00	1.00
09/27/2026 20:00	0	2.0	12.3	13.2	20.1	1,053,567.5	0.00	1.00
09/27/2026 21:00	0	1.8	10.5	13.9	15.5	1,042,914.5	0.00	1.00
09/27/2026 22:00	0	1.7	9.4	14.2	12.9	1,015,009.2	0.00	1.00
09/27/2026 23:00	-1	1.6	8.3	14.3	7.6	879,958.9	0.00	1.00
Average/Sum#:	0	1.7	9.4	14.1	10.3	905,350.3	0.00 #	24.00 #
Minimum:	-1	1.6	8.3	12.9	5.1	780,364.4	0.00	1.00
Maximum:	1	2.0	13.0	14.5	21.0	1,053,567.5	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/28/2026 00:00	-1	1.7	8.2	14.3	7.0	866,472.2	0.00	1.00
09/28/2026 01:00	-1	1.7	8.5	14.2	6.0	772,396.2	0.00	1.00
09/28/2026 02:00	-1	1.8	8.8	14.3	6.6	830,991.6	0.00	1.00
09/28/2026 03:00	0	1.7	8.8	14.3	8.5	901,330.2	0.00	1.00
09/28/2026 04:00	0	1.7	9.8	14.2	13.8	1,033,404.4	0.00	1.00
09/28/2026 05:00	0	1.7	10.1	14.1	14.4	1,047,408.3	0.00	1.00
09/28/2026 06:00	0	1.8	10.5	13.8	14.6	1,003,344.5	0.00	1.00
09/28/2026 07:00	-1	1.6	8.6	14.3	6.7	849,665.6	0.00	1.00
09/28/2026 08:00	-1	1.7	8.4	14.3	5.8	781,194.4	0.00	1.00
09/28/2026 09:00	-1	1.7	8.5	14.3	5.2	780,156.9	0.00	1.00
09/28/2026 10:00	-1	1.7	8.5	14.3	5.2	778,912.0	0.00	1.00
09/28/2026 11:00	-1	1.7	8.4	14.4	5.0	789,841.8	0.00	1.00
09/28/2026 12:00	-1	1.7	8.4	14.4	4.9	789,209.8	0.00	1.00
09/28/2026 13:00	-1	1.7	8.4	14.4	4.9	788,367.1	0.00	1.00
09/28/2026 14:00	-1	1.7	8.5	14.4	5.0	787,313.7	0.00	1.00
09/28/2026 15:00	-1	1.6	8.5	14.5	5.3	798,545.6	0.00	1.00
09/28/2026 16:00	-1	1.6	8.5	14.5	5.6	801,541.2	0.00	1.00
09/28/2026 17:00	-1	1.6	8.3	14.5	5.3	797,261.8	0.00	1.00
09/28/2026 18:00	-1	1.6	8.4	14.5	5.6	798,117.6	0.00	1.00
09/28/2026 19:00	-1	1.7	8.6	14.4	6.0	787,945.7	0.00	1.00
09/28/2026 20:00	-1	1.7	8.5	14.4	6.2	788,788.4	0.00	1.00
09/28/2026 21:00	-1	1.7	8.5	14.4	6.1	789,420.5	0.00	1.00
09/28/2026 22:00	-1	1.7	8.5	14.3	6.4	778,082.0	0.00	1.00
09/28/2026 23:00	-1	1.7	8.5	14.3	6.3	778,912.0	0.00	1.00
Average/Sum#:	-1	1.7	8.7	14.3	6.9	829,942.6	0.00 #	24.00 #
Minimum:	-1	1.6	8.2	13.8	4.9	772,396.2	0.00	1.00
Maximum:	0	1.8	10.5	14.5	14.6	1,047,408.3	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/29/2026 00:00	-1	1.7	8.6	14.3	6.3	779,534.5	0.00	1.00
09/29/2026 01:00	0	1.7	8.7	14.3	7.4	779,534.5	0.00	1.00
09/29/2026 02:00	0	1.7	9.0	14.3	7.5	779,949.4	0.00	1.00
09/29/2026 03:00	0	1.7	8.9	14.3	7.4	779,949.4	0.00	1.00
09/29/2026 04:00	0	1.7	8.8	14.3	7.6	780,364.4	0.00	1.00
09/29/2026 05:00	0	1.7	8.9	14.3	7.6	780,986.9	0.00	1.00
09/29/2026 06:00	-1	1.7	8.9	14.3	7.4	780,986.9	0.00	1.00
09/29/2026 07:00	-1	1.7	8.9	14.3	6.7	779,949.4	0.00	1.00
09/29/2026 08:00	-1	1.7	8.8	14.3	6.4	778,289.5	0.00	1.00
09/29/2026 09:00	-1	1.7	8.7	14.4	6.2	788,156.4	0.00	1.00
09/29/2026 10:00	-1	1.6	8.6	14.5	5.4	798,545.6	0.00	1.00
09/29/2026 11:00	-1	1.6	8.5	14.5	5.6	797,689.7	0.00	1.00
09/29/2026 12:00	-1	1.6	8.5	14.5	6.2	796,405.9	0.00	1.00
09/29/2026 13:00	-1	1.6	8.2	14.5	5.7	794,694.1	0.00	1.00
09/29/2026 14:00	-1	1.6	8.1	14.6	5.8	806,873.5	0.00	1.00
09/29/2026 15:00	-1	1.6	8.1	14.5	5.5	794,480.1	0.00	1.00
09/29/2026 16:00	-1	1.6	8.0	14.6	6.2	835,566.2	0.00	1.00
09/29/2026 17:00	-1	1.6	8.3	14.4	5.7	787,313.7	0.00	1.00
09/29/2026 18:00	-1	1.6	8.5	14.5	6.2	797,475.7	0.00	1.00
09/29/2026 19:00	-1	1.6	8.5	14.5	6.4	798,117.6	0.00	1.00
09/29/2026 20:00	-1	1.7	8.5	14.4	6.4	787,313.7	0.00	1.00
09/29/2026 21:00	-1	1.7	8.6	14.4	6.2	787,735.0	0.00	1.00
09/29/2026 22:00	-1	1.7	8.6	14.4	6.1	788,577.8	0.00	1.00
09/29/2026 23:00	0	1.6	8.6	14.5	10.5	976,356.8	0.00	1.00
Average/Sum#:	-1	1.7	8.6	14.4	6.6	798,118.6	0.00 #	24.00 #
Minimum:	-1	1.6	8.0	14.3	5.4	778,289.5	0.00	1.00
Maximum:	0	1.7	9.0	14.6	10.5	976,356.8	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NH3 Slip Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/01/2026 08:20 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag: > 10

	Unit CT2 NH3Slip, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 NOx, _SCR, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 NH3Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
09/30/2026 00:00	-1	1.7	8.7	14.4	7.5	788,156.4	0.00	1.00
09/30/2026 01:00	-1	1.7	8.7	14.4	6.3	793,212.7	0.00	1.00
09/30/2026 02:00	-1	1.7	8.7	14.4	6.9	840,194.5	0.00	1.00
09/30/2026 03:00	0	1.8	9.7	14.3	11.1	1,016,693.9	0.00	1.00
09/30/2026 04:00	0	1.7	10.1	14.1	15.4	1,037,339.0	0.00	1.00
09/30/2026 05:00	1	2.0	12.6	13.3	23.0	1,055,357.7	0.00	1.00
09/30/2026 06:00	0	1.8	10.8	13.8	15.0	918,285.8	0.00	1.00
09/30/2026 07:00	-1	1.7	8.6	14.3	5.1	779,327.0	0.00	1.00
09/30/2026 08:00	-1	1.7	8.6	14.4	6.7	796,794.3	0.00	1.00
09/30/2026 09:00	-1	1.7	8.5	14.4	6.0	786,260.3	0.00	1.00
09/30/2026 10:00	-1	1.7	8.3	14.5	6.5	828,929.7	0.00	1.00
09/30/2026 11:00	-1	1.6	8.4	14.5	7.1	881,353.0	0.00	1.00
09/30/2026 12:00	0	1.7	8.0	14.4	8.5	948,273.7	0.00	1.00
09/30/2026 13:00	0	1.8	9.5	13.9	13.2	1,023,938.2	0.00	1.00
09/30/2026 14:00	1	2.1	12.2	12.7	23.4	1,025,064.3	0.00	1.00
09/30/2026 15:00	1	2.1	13.1	12.6	24.3	1,023,108.5	0.00	1.00
09/30/2026 16:00	1	2.1	12.6	12.7	22.9	1,023,227.2	0.00	1.00
09/30/2026 17:00	1	2.0	12.5	12.9	20.2	1,019,707.6	0.00	1.00
09/30/2026 18:00	0	1.9	11.0	13.5	16.5	974,882.1	0.00	1.00
09/30/2026 19:00	0	1.8	10.1	13.9	13.9	962,509.7	0.00	1.00
09/30/2026 20:00	0	1.6	8.8	14.5	11.3	989,623.1	0.00	1.00
09/30/2026 21:00	0	1.8	10.8	13.8	15.4	1,008,937.9	0.00	1.00
09/30/2026 22:00	-1	1.6	8.4	14.4	6.5	838,930.4	0.00	1.00
09/30/2026 23:00	-1	1.7	8.4	14.4	7.3	852,624.7	0.00	1.00
Average/Sum#:	0	1.8	9.9	13.9	12.5	925,530.5	0.00 #	24.00 #
Minimum:	-1	1.6	8.0	12.6	5.1	779,327.0	0.00	1.00
Maximum:	1	2.1	13.1	14.5	24.3	1,055,357.7	0.00	1.00
%SI	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	NOx, Ppmvdc	NOx_Norm, LbPerHr	NOx_SUSD, LbPerHr	NOx, Ppm	O2, Dry, Pct	HI, MBtuPerHr	SUSD, Hr	OperatingTime, Hr
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/01/2026 00:00	1.5	2.2	0.0	1.7	14.3	390.4	0.00	1.00
07/01/2026 01:00	1.5	2.2	0.0	1.7	14.3	393.4	0.00	1.00
07/01/2026 02:00	1.5	2.1	0.0	1.7	14.3	392.9	0.00	1.00
07/01/2026 03:00	1.5	2.2	0.0	1.7	14.3	392.9	0.00	1.00
07/01/2026 04:00	1.5	2.2	0.0	1.7	14.3	392.1	0.00	1.00
07/01/2026 05:00	1.5	2.2	0.0	1.7	14.3	392.2	0.00	1.00
07/01/2026 06:00	1.5	2.2	0.0	1.7	14.3	391.6	0.00	1.00
07/01/2026 07:00	1.5	2.2	0.0	1.7	14.3	392.7	0.00	1.00
07/01/2026 08:00	1.5	2.2	0.0	1.7	14.3	392.3	0.00	1.00
07/01/2026 09:00	1.5	2.2	0.0	1.7	14.4	392.2	0.00	1.00
07/01/2026 10:00	1.5	2.2	0.0	1.7	14.4	390.0	0.00	1.00
07/01/2026 11:00	1.5	2.2	0.0	1.7	14.4	390.1	0.00	1.00
07/01/2026 12:00	1.5	2.2	0.0	1.6	14.4	391.3	0.00	1.00
07/01/2026 13:00	1.5	2.2	0.0	1.6	14.5	390.9	0.00	1.00
07/01/2026 14:00	1.5	2.2	0.0	1.6	14.5	390.9	0.00	1.00
07/01/2026 15:00	1.5	2.2	0.0	1.6	14.5	391.0	0.00	1.00
07/01/2026 16:00	1.5	2.2	0.0	1.6	14.5	399.2	0.00	1.00
07/01/2026 17:00	1.5	2.3	0.0	1.6	14.4	412.8	0.00	1.00
07/01/2026 18:00	1.5	2.5	0.0	1.7	14.4	440.3	0.00	1.00
07/01/2026 19:00	1.5	2.6	0.0	1.7	14.4	460.2	0.00	1.00
07/01/2026 20:00	1.5	2.4	0.0	1.7	14.3	438.7	0.00	1.00
07/01/2026 21:00	1.5	2.2	0.0	1.7	14.3	400.9	0.00	1.00
07/01/2026 22:00	1.5	2.2	0.0	1.7	14.3	402.7	0.00	1.00
07/01/2026 23:00	1.5	2.3	0.0	1.7	14.4	416.4	0.00	1.00
Average/Sum#:	1.5	2.2	0.0	1.7	14.4	401.6	0.00 #	24.00 #
Minimum:	1.5	2.1	0.0	1.6	14.3	390.0	0.00	1.00
Maximum:	1.5	2.6	0.0	1.7	14.5	460.2	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/02/2026 00:00	1.5	2.2	0.0	1.7	14.3	391.1	0.00	1.00
07/02/2026 01:00	1.5	2.2	0.0	1.7	14.3	390.4	0.00	1.00
07/02/2026 02:00	1.5	2.2	0.0	1.7	14.3	390.3	0.00	1.00
07/02/2026 03:00	1.5	2.2	0.0	1.7	14.3	390.1	0.00	1.00
07/02/2026 04:00	1.5	2.2	0.0	1.7	14.3	395.3	0.00	1.00
07/02/2026 05:00	1.5	2.2	0.0	1.7	14.2	391.0	0.00	1.00
07/02/2026 06:00	1.5	2.2	0.0	1.7	14.3	390.8	0.00	1.00
07/02/2026 07:00	1.5	2.2	0.0	1.7	14.3	390.7	0.00	1.00
07/02/2026 08:00	1.5	2.2	0.0	1.7	14.3	391.0	0.00	1.00
07/02/2026 09:00	1.5	2.2	0.0	1.7	14.3	391.5	0.00	1.00
07/02/2026 10:00	1.5	2.2	0.0	1.7	14.4	390.0	0.00	1.00
07/02/2026 11:00	1.5	2.2	0.0	1.7	14.4	388.3	0.00	1.00
07/02/2026 12:00	1.5	2.2	0.0	1.7	14.4	387.7	0.00	1.00
07/02/2026 13:00	1.5	2.2	0.0	1.6	14.4	388.4	0.00	1.00
07/02/2026 14:00	1.5	2.2	0.0	1.6	14.5	388.8	0.00	1.00
07/02/2026 15:00	1.5	2.2	0.0	1.6	14.5	389.1	0.00	1.00
07/02/2026 16:00	1.5	2.2	0.0	1.6	14.5	389.2	0.00	1.00
07/02/2026 17:00	1.5	2.3	0.0	1.6	14.5	403.5	0.00	1.00
07/02/2026 18:00	1.5	2.1	0.0	1.6	14.4	388.1	0.00	1.00
07/02/2026 19:00	1.5	2.2	0.0	1.7	14.4	386.7	0.00	1.00
07/02/2026 20:00	1.5	2.2	0.0	1.7	14.4	388.5	0.00	1.00
07/02/2026 21:00	1.5	2.2	0.0	1.7	14.4	388.7	0.00	1.00
07/02/2026 22:00	1.5	2.2	0.0	1.7	14.3	393.5	0.00	1.00
07/02/2026 23:00	1.5	2.5	0.0	1.6	14.4	447.2	0.00	1.00
Average/Sum#:	1.5	2.2	0.0	1.7	14.4	392.9	0.00 #	24.00 #
Minimum:	1.5	2.1	0.0	1.6	14.2	386.7	0.00	1.00
Maximum:	1.5	2.5	0.0	1.7	14.5	447.2	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/03/2026 00:00	1.5	2.2	0.0	1.7	14.3	395.3	0.00	1.00
07/03/2026 01:00	1.5	2.1	0.0	1.7	14.3	380.1	0.00	1.00
07/03/2026 02:00	1.5	2.1	0.0	1.7	14.3	378.2	0.00	1.00
07/03/2026 03:00	1.5	2.1	0.0	1.7	14.3	378.1	0.00	1.00
07/03/2026 04:00	1.5	2.1	0.0	1.7	14.3	391.7	0.00	1.00
07/03/2026 05:00	1.5	2.2	0.0	1.7	14.2	393.6	0.00	1.00
07/03/2026 06:00	1.5	2.2	0.0	1.7	14.3	394.7	0.00	1.00
07/03/2026 07:00	1.5	2.2	0.0	1.7	14.3	395.1	0.00	1.00
07/03/2026 08:00	1.5	2.2	0.0	1.7	14.3	395.9	0.00	1.00
07/03/2026 09:00	1.5	2.2	0.0	1.7	14.4	392.9	0.00	1.00
07/03/2026 10:00	1.5	2.2	0.0	1.7	14.4	392.3	0.00	1.00
07/03/2026 11:00	1.5	2.3	0.0	1.7	14.4	392.8	0.00	1.00
07/03/2026 12:00	1.5	2.2	0.0	1.6	14.5	393.3	0.00	1.00
07/03/2026 13:00	1.5	2.3	0.0	1.6	14.5	393.6	0.00	1.00
07/03/2026 14:00	1.5	2.2	0.0	1.6	14.5	393.3	0.00	1.00
07/03/2026 15:00	1.5	2.2	0.0	1.6	14.5	393.1	0.00	1.00
07/03/2026 16:00	1.5	2.2	0.0	1.6	14.5	406.8	0.00	1.00
07/03/2026 17:00	1.5	2.2	0.0	1.6	14.4	410.8	0.00	1.00
07/03/2026 18:00	1.5	2.2	0.0	1.7	14.3	392.7	0.00	1.00
07/03/2026 19:00	1.5	2.2	0.0	1.7	14.3	395.1	0.00	1.00
07/03/2026 20:00	1.5	2.2	0.0	1.7	14.3	394.2	0.00	1.00
07/03/2026 21:00	1.5	2.2	0.0	1.7	14.3	394.4	0.00	1.00
07/03/2026 22:00	1.5	2.2	0.0	1.7	14.3	393.3	0.00	1.00
07/03/2026 23:00	1.5	2.2	0.0	1.7	14.4	404.4	0.00	1.00
Average/Sum#:	1.5	2.2	0.0	1.7	14.4	393.6	0.00 #	24.00 #
Minimum:	1.5	2.1	0.0	1.6	14.2	378.1	0.00	1.00
Maximum:	1.5	2.3	0.0	1.7	14.5	410.8	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/04/2026 00:00	1.5	2.5	0.0	1.6	14.5	448.3	0.00	1.00
07/04/2026 01:00	1.5	2.2	0.0	1.7	14.3	392.8	0.00	1.00
07/04/2026 02:00	1.5	2.1	0.0	1.7	14.3	381.2	0.00	1.00
07/04/2026 03:00	1.5	2.1	0.0	1.7	14.3	377.8	0.00	1.00
07/04/2026 04:00	1.5	2.1	0.0	1.7	14.3	378.5	0.00	1.00
07/04/2026 05:00	1.5	2.5	0.0	1.7	14.4	442.9	0.00	1.00
07/04/2026 06:00	1.5	2.5	0.0	1.7	14.4	438.4	0.00	1.00
07/04/2026 07:00	1.5	2.3	0.0	1.7	14.3	405.3	0.00	1.00
07/04/2026 08:00	1.5	2.2	0.0	1.7	14.3	392.2	0.00	1.00
07/04/2026 09:00	1.5	2.2	0.0	1.7	14.4	392.1	0.00	1.00
07/04/2026 10:00	1.5	2.2	0.0	1.7	14.4	393.0	0.00	1.00
07/04/2026 11:00	1.5	2.3	0.0	1.7	14.4	391.0	0.00	1.00
07/04/2026 12:00	1.5	2.2	0.0	1.6	14.5	389.7	0.00	1.00
07/04/2026 13:00	1.5	2.2	0.0	1.6	14.5	389.7	0.00	1.00
07/04/2026 14:00	1.5	2.2	0.0	1.6	14.5	392.8	0.00	1.00
07/04/2026 15:00	1.5	2.5	0.0	1.6	14.5	456.3	0.00	1.00
07/04/2026 16:00	1.5	2.6	0.0	1.6	14.5	461.8	0.00	1.00
07/04/2026 17:00	1.5	2.5	0.0	1.6	14.5	455.7	0.00	1.00
07/04/2026 18:00	1.5	2.4	0.0	1.6	14.4	437.4	0.00	1.00
07/04/2026 19:00	1.5	2.8	0.0	1.7	13.9	514.9	0.00	1.00
07/04/2026 20:00	1.5	2.6	0.0	1.7	14.0	470.1	0.00	1.00
07/04/2026 21:00	1.5	2.1	0.0	1.7	14.3	379.8	0.00	1.00
07/04/2026 22:00	1.5	2.2	0.0	1.7	14.3	396.2	0.00	1.00
07/04/2026 23:00	1.5	2.5	0.0	1.7	14.4	441.2	0.00	1.00
Average/Sum#:	1.5	2.3	0.0	1.7	14.4	417.5	0.00 #	24.00 #
Minimum:	1.5	2.1	0.0	1.6	13.9	377.8	0.00	1.00
Maximum:	1.5	2.8	0.0	1.7	14.5	514.9	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/05/2026 00:00	1.5	2.3	0.0	1.7	14.3	413.1	0.00	1.00
07/05/2026 01:00	1.5	2.2	0.0	1.7	14.2	395.5	0.00	1.00
07/05/2026 02:00	1.6	2.3	0.0	1.7	14.3	396.6	0.00	1.00
07/05/2026 03:00	1.5	2.2	0.0	1.7	14.3	395.4	0.00	1.00
07/05/2026 04:00	1.5	2.2	0.0	1.7	14.3	396.3	0.00	1.00
07/05/2026 05:00	1.5	2.4	0.0	1.6	14.4	434.9	0.00	1.00
07/05/2026 06:00	1.5	2.3	0.0	1.7	14.3	412.0	0.00	1.00
07/05/2026 07:00	1.5	2.2	0.0	1.7	14.3	395.7	0.00	1.00
07/05/2026 08:00	1.5	2.2	0.0	1.7	14.3	394.3	0.00	1.00
07/05/2026 09:00	1.5	2.2	0.0	1.7	14.3	383.2	0.00	1.00
07/05/2026 10:00	1.5	2.2	0.0	1.7	14.4	383.6	0.00	1.00
07/05/2026 11:00	1.5	2.2	0.0	1.7	14.4	382.3	0.00	1.00
07/05/2026 12:00	1.5	2.2	0.0	1.7	14.4	379.5	0.00	1.00
07/05/2026 13:00	1.5	2.1	0.0	1.6	14.5	378.4	0.00	1.00
07/05/2026 14:00	1.5	2.1	0.0	1.6	14.5	377.8	0.00	1.00
07/05/2026 15:00	1.5	2.1	0.0	1.6	14.5	378.8	0.00	1.00
07/05/2026 16:00	1.5	2.1	0.0	1.6	14.5	382.2	0.00	1.00
07/05/2026 17:00	1.5	2.6	0.0	1.7	14.5	462.7	0.00	1.00
07/05/2026 18:00	1.5	2.6	0.0	1.7	14.4	461.8	0.00	1.00
07/05/2026 19:00	1.5	2.6	0.0	1.7	14.4	460.8	0.00	1.00
07/05/2026 20:00	1.5	2.6	0.0	1.7	14.4	460.7	0.00	1.00
07/05/2026 21:00	1.5	2.6	0.0	1.7	14.4	460.7	0.00	1.00
07/05/2026 22:00	1.5	2.2	0.0	1.7	14.3	406.8	0.00	1.00
07/05/2026 23:00	1.5	2.2	0.0	1.7	14.3	386.7	0.00	1.00
Average/Sum#:	1.5	2.3	0.0	1.7	14.4	407.5	0.00 #	24.00 #
Minimum:	1.5	2.1	0.0	1.6	14.2	377.8	0.00	1.00
Maximum:	1.6	2.6	0.0	1.7	14.5	462.7	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/06/2026 00:00	1.5	2.2	0.0	1.7	14.3	388.9	0.00	1.00
07/06/2026 01:00	1.5	2.1	0.0	1.7	14.3	382.5	0.00	1.00
07/06/2026 02:00	1.5	2.1	0.0	1.7	14.2	382.4	0.00	1.00
07/06/2026 03:00	1.5	2.1	0.0	1.7	14.2	382.5	0.00	1.00
07/06/2026 04:00	1.5	2.3	0.0	1.7	14.3	417.5	0.00	1.00
07/06/2026 05:00	1.5	2.2	0.0	1.7	14.2	401.1	0.00	1.00
07/06/2026 06:00	1.5	2.1	0.0	1.7	14.2	381.4	0.00	1.00
07/06/2026 07:00	1.5	2.1	0.0	1.7	14.3	381.4	0.00	1.00
07/06/2026 08:00	1.5	2.1	0.0	1.7	14.3	381.8	0.00	1.00
07/06/2026 09:00	1.5	2.2	0.0	1.7	14.3	383.0	0.00	1.00
07/06/2026 10:00	1.5	2.2	0.0	1.7	14.4	383.1	0.00	1.00
07/06/2026 11:00	1.5	2.2	0.0	1.7	14.4	382.2	0.00	1.00
07/06/2026 12:00	1.5	2.2	0.0	1.7	14.4	379.5	0.00	1.00
07/06/2026 13:00	1.5	2.3	0.0	1.7	14.5	395.7	0.00	1.00
07/06/2026 14:00	1.5	2.2	0.0	1.6	14.5	394.4	0.00	1.00
07/06/2026 15:00	1.5	2.3	0.0	1.6	14.6	417.5	0.00	1.00
07/06/2026 16:00	1.5	2.3	0.0	1.6	14.6	427.4	0.00	1.00
07/06/2026 17:00	1.5	2.4	0.0	1.7	14.4	422.4	0.00	1.00
07/06/2026 18:00	1.5	2.6	0.0	1.7	14.5	464.2	0.00	1.00
07/06/2026 19:00	1.5	2.6	0.0	1.7	14.4	464.8	0.00	1.00
07/06/2026 20:00	1.5	2.6	0.0	1.7	14.4	464.2	0.00	1.00
07/06/2026 21:00	1.5	2.6	0.0	1.7	14.4	464.4	0.00	1.00
07/06/2026 22:00	1.5	2.6	0.0	1.7	14.4	463.6	0.00	1.00
07/06/2026 23:00	1.5	2.6	0.0	1.7	14.4	462.5	0.00	1.00
Average/Sum#:	1.5	2.3	0.0	1.7	14.4	411.2	0.00 #	24.00 #
Minimum:	1.5	2.1	0.0	1.6	14.2	379.5	0.00	1.00
Maximum:	1.5	2.6	0.0	1.7	14.6	464.8	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/07/2026 00:00	1.5	2.6	0.0	1.7	14.4	461.8	0.00	1.00
07/07/2026 01:00	1.5	2.5	0.0	1.6	14.4	448.8	0.00	1.00
07/07/2026 02:00	1.6	2.7	0.0	1.8	14.4	460.7	0.00	1.00
07/07/2026 03:00	1.5	2.6	0.0	1.7	14.4	460.9	0.00	1.00
07/07/2026 04:00	1.5	2.6	0.0	1.7	14.4	462.3	0.00	1.00
07/07/2026 05:00	1.5	2.4	0.0	1.7	14.3	430.1	0.00	1.00
07/07/2026 06:00	1.5	2.1	0.0	1.7	14.2	383.4	0.00	1.00
07/07/2026 07:00	1.5	2.1	0.0	1.7	14.2	383.3	0.00	1.00
07/07/2026 08:00	1.5	2.2	0.0	1.7	14.3	383.5	0.00	1.00
07/07/2026 09:00	1.5	2.1	0.0	1.7	14.3	383.9	0.00	1.00
07/07/2026 10:00	1.5	2.2	0.0	1.7	14.3	383.8	0.00	1.00
07/07/2026 11:00	1.5	2.5	0.0	1.7	14.5	422.8	0.00	1.00
07/07/2026 12:00	1.5	2.3	0.0	1.6	14.4	409.2	0.00	1.00
07/07/2026 13:00	1.5	2.4	0.0	1.7	14.5	413.2	0.00	1.00
07/07/2026 14:00	1.5	2.5	0.0	1.6	14.6	441.6	0.00	1.00
07/07/2026 15:00	1.5	2.3	0.0	1.6	14.5	416.3	0.00	1.00
07/07/2026 16:00	1.5	2.4	0.0	1.7	14.5	419.9	0.00	1.00
07/07/2026 17:00	1.5	2.4	0.0	1.6	14.6	434.8	0.00	1.00
07/07/2026 18:00	1.5	2.5	0.0	1.6	14.6	456.9	0.00	1.00
07/07/2026 19:00	1.5	2.5	0.0	1.6	14.5	458.9	0.00	1.00
07/07/2026 20:00	1.5	2.5	0.0	1.6	14.5	457.8	0.00	1.00
07/07/2026 21:00	1.5	2.5	0.0	1.7	14.4	456.1	0.00	1.00
07/07/2026 22:00	1.5	2.5	0.0	1.7	14.4	455.9	0.00	1.00
07/07/2026 23:00	1.5	2.5	0.0	1.7	14.3	443.2	0.00	1.00
Average/Sum#:	1.5	2.4	0.0	1.7	14.4	430.4	0.00 #	24.00 #
Minimum:	1.5	2.1	0.0	1.6	14.2	383.3	0.00	1.00
Maximum:	1.6	2.7	0.0	1.8	14.6	462.3	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/08/2026 00:00	1.5	2.6	0.0	1.7	14.4	458.9	0.00	1.00
07/08/2026 01:00	1.5	2.1	0.0	1.6	14.2	395.3	0.00	1.00
07/08/2026 02:00	1.5	2.1	0.0	1.7	14.2	379.7	0.00	1.00
07/08/2026 03:00	1.5	2.1	0.0	1.7	14.2	379.8	0.00	1.00
07/08/2026 04:00	1.5	2.1	0.0	1.7	14.2	380.0	0.00	1.00
07/08/2026 05:00	1.5	2.1	0.0	1.7	14.2	381.1	0.00	1.00
07/08/2026 06:00	1.5	2.1	0.0	1.7	14.2	385.7	0.00	1.00
07/08/2026 07:00	1.5	2.1	0.0	1.7	14.2	380.6	0.00	1.00
07/08/2026 08:00	1.5	2.2	0.0	1.7	14.3	381.6	0.00	1.00
07/08/2026 09:00	1.5	2.2	0.0	1.7	14.3	382.7	0.00	1.00
07/08/2026 10:00	1.5	2.2	0.0	1.7	14.3	381.8	0.00	1.00
07/08/2026 11:00	1.5	2.2	0.0	1.7	14.4	380.8	0.00	1.00
07/08/2026 12:00	1.5	2.2	0.0	1.7	14.4	381.1	0.00	1.00
07/08/2026 13:00	1.5	2.2	0.0	1.7	14.4	381.8	0.00	1.00
07/08/2026 14:00	1.5	2.1	0.0	1.7	14.4	381.5	0.00	1.00
07/08/2026 15:00	1.5	2.1	0.0	1.6	14.5	379.1	0.00	1.00
07/08/2026 16:00	1.5	2.1	0.0	1.6	14.5	378.3	0.00	1.00
07/08/2026 17:00	1.5	2.3	0.0	1.7	14.5	406.2	0.00	1.00
07/08/2026 18:00	1.5	2.3	0.0	1.6	14.5	417.0	0.00	1.00
07/08/2026 19:00	1.5	2.1	0.0	1.7	14.4	381.2	0.00	1.00
07/08/2026 20:00	1.5	2.1	0.0	1.7	14.4	381.0	0.00	1.00
07/08/2026 21:00	1.5	2.1	0.0	1.7	14.3	380.8	0.00	1.00
07/08/2026 22:00	1.5	2.1	0.0	1.7	14.3	379.8	0.00	1.00
07/08/2026 23:00	1.5	2.1	0.0	1.7	14.3	378.9	0.00	1.00
Average/Sum#:	1.5	2.2	0.0	1.7	14.3	387.3	0.00 #	24.00 #
Minimum:	1.5	2.1	0.0	1.6	14.2	378.3	0.00	1.00
Maximum:	1.5	2.6	0.0	1.7	14.5	458.9	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/09/2026 00:00	1.5	2.1	0.0	1.7	14.3	378.8	0.00	1.00
07/09/2026 01:00	1.5	2.1	0.0	1.7	14.3	378.7	0.00	1.00
07/09/2026 02:00	1.5	2.1	0.0	1.7	14.3	378.5	0.00	1.00
07/09/2026 03:00	1.5	2.1	0.0	1.7	14.3	381.2	0.00	1.00
07/09/2026 04:00	1.5	2.2	0.0	1.7	14.3	400.3	0.00	1.00
07/09/2026 05:00	1.5	2.2	0.0	1.7	14.3	404.6	0.00	1.00
07/09/2026 06:00	1.5	2.2	0.0	1.7	14.3	382.0	0.00	1.00
07/09/2026 07:00	1.5	2.2	0.0	1.7	14.3	382.4	0.00	1.00
07/09/2026 08:00	1.5	2.2	0.0	1.7	14.3	381.3	0.00	1.00
07/09/2026 09:00	1.5	2.2	0.0	1.7	14.4	379.8	0.00	1.00
07/09/2026 10:00	1.5	2.2	0.0	1.7	14.4	379.7	0.00	1.00
07/09/2026 11:00	1.5	2.2	0.0	1.7	14.4	380.6	0.00	1.00
07/09/2026 12:00	1.5	2.2	0.0	1.6	14.5	379.6	0.00	1.00
07/09/2026 13:00	1.5	2.3	0.0	1.7	14.5	393.8	0.00	1.00
07/09/2026 14:00	1.5	2.1	0.0	1.6	14.5	378.6	0.00	1.00
07/09/2026 15:00	1.5	2.1	0.0	1.6	14.5	373.4	0.00	1.00
07/09/2026 16:00	1.5	2.2	0.0	1.6	14.5	405.2	0.00	1.00
07/09/2026 17:00	1.5	2.4	0.0	1.7	14.4	421.4	0.00	1.00
07/09/2026 18:00	1.5	2.6	0.0	1.6	14.5	461.8	0.00	1.00
07/09/2026 19:00	1.5	2.5	0.0	1.6	14.5	460.3	0.00	1.00
07/09/2026 20:00	1.5	2.4	0.0	1.6	14.5	427.3	0.00	1.00
07/09/2026 21:00	1.5	2.4	0.0	1.7	14.5	426.6	0.00	1.00
07/09/2026 22:00	1.5	2.4	0.0	1.6	14.5	429.3	0.00	1.00
07/09/2026 23:00	1.5	2.3	0.0	1.6	14.5	423.7	0.00	1.00
Average/Sum#:	1.5	2.2	0.0	1.7	14.4	399.5	0.00 #	24.00 #
Minimum:	1.5	2.1	0.0	1.6	14.3	373.4	0.00	1.00
Maximum:	1.5	2.6	0.0	1.7	14.5	461.8	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/10/2026 00:00	1.5	2.2	0.0	1.7	14.4	400.3	0.00	1.00
07/10/2026 01:00	1.5	2.1	0.0	1.7	14.3	386.6	0.00	1.00
07/10/2026 02:00	1.5	2.1	0.0	1.6	14.3	383.6	0.00	1.00
07/10/2026 03:00	1.5	2.5	0.0	1.7	14.4	449.6	0.00	1.00
07/10/2026 04:00	1.5	2.3	0.0	1.6	14.4	424.0	0.00	1.00
07/10/2026 05:00	1.5	2.3	0.0	1.7	14.4	425.2	0.00	1.00
07/10/2026 06:00	1.5	2.1	0.0	1.7	14.3	384.4	0.00	1.00
07/10/2026 07:00	1.5	2.2	0.0	1.7	14.3	384.1	0.00	1.00
07/10/2026 08:00	1.5	2.2	0.0	1.7	14.4	384.0	0.00	1.00
07/10/2026 09:00	1.5	2.2	0.0	1.7	14.4	383.1	0.00	1.00
07/10/2026 10:00	1.5	2.2	0.0	1.7	14.4	381.1	0.00	1.00
07/10/2026 11:00	1.5	2.2	0.0	1.7	14.4	380.9	0.00	1.00
07/10/2026 12:00	1.5	2.2	0.0	1.7	14.5	380.6	0.00	1.00
07/10/2026 13:00	1.5	2.2	0.0	1.6	14.5	379.4	0.00	1.00
07/10/2026 14:00	1.5	2.1	0.0	1.6	14.5	378.5	0.00	1.00
07/10/2026 15:00	1.5	2.2	0.0	1.6	14.5	391.2	0.00	1.00
07/10/2026 16:00	1.5	2.2	0.0	1.6	14.5	405.9	0.00	1.00
07/10/2026 17:00	1.5	2.9	0.0	1.8	13.8	513.7	0.00	1.00
07/10/2026 18:00	1.5	3.0	0.0	1.9	13.2	559.6	0.00	1.00
07/10/2026 19:00	1.5	3.0	0.0	1.9	13.4	550.1	0.00	1.00
07/10/2026 20:00	1.5	2.9	0.0	1.8	13.9	528.1	0.00	1.00
07/10/2026 21:00	1.5	2.9	0.0	1.8	13.9	525.1	0.00	1.00
07/10/2026 22:00	1.5	2.9	0.0	1.8	14.0	523.8	0.00	1.00
07/10/2026 23:00	1.5	2.9	0.0	1.7	14.1	522.6	0.00	1.00
Average/Sum#:	1.5	2.4	0.0	1.7	14.2	434.4	0.00 #	24.00 #
Minimum:	1.5	2.1	0.0	1.6	13.2	378.5	0.00	1.00
Maximum:	1.5	3.0	0.0	1.9	14.5	559.6	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/11/2026 00:00	1.5	2.9	0.0	1.7	14.1	521.3	0.00	1.00
07/11/2026 01:00	1.5	2.8	0.0	1.7	14.1	519.6	0.00	1.00
07/11/2026 02:00	1.5	2.8	0.0	1.7	14.1	517.8	0.00	1.00
07/11/2026 03:00	1.5	2.9	0.0	1.7	14.2	517.0	0.00	1.00
07/11/2026 04:00	1.5	2.6	0.0	1.7	14.2	476.5	0.00	1.00
07/11/2026 05:00	1.5	2.2	0.0	1.6	14.3	403.9	0.00	1.00
07/11/2026 06:00	1.5	2.2	0.0	1.7	14.3	389.2	0.00	1.00
07/11/2026 07:00	1.5	2.2	0.0	1.7	14.3	382.0	0.00	1.00
07/11/2026 08:00	1.5	2.1	0.0	1.7	14.3	382.9	0.00	1.00
07/11/2026 09:00	1.5	2.2	0.0	1.7	14.4	383.5	0.00	1.00
07/11/2026 10:00	1.5	2.2	0.0	1.7	14.4	381.6	0.00	1.00
07/11/2026 11:00	1.5	2.2	0.0	1.6	14.4	381.0	0.00	1.00
07/11/2026 12:00	1.5	2.2	0.0	1.7	14.4	380.9	0.00	1.00
07/11/2026 13:00	1.5	2.2	0.0	1.7	14.5	378.6	0.00	1.00
07/11/2026 14:00	1.5	2.1	0.0	1.6	14.5	378.1	0.00	1.00
07/11/2026 15:00	1.5	2.3	0.0	1.6	14.5	404.1	0.00	1.00
07/11/2026 16:00	1.5	2.2	0.0	1.6	14.5	396.3	0.00	1.00
07/11/2026 17:00	1.5	3.1	0.0	1.9	13.6	527.3	0.00	1.00
07/11/2026 18:00	1.5	3.0	0.0	1.8	13.8	534.7	0.00	1.00
07/11/2026 19:00	1.5	2.9	0.0	1.8	13.9	528.3	0.00	1.00
07/11/2026 20:00	1.5	3.0	0.0	1.8	13.7	534.0	0.00	1.00
07/11/2026 21:00	1.5	3.0	0.0	1.9	13.4	554.3	0.00	1.00
07/11/2026 22:00	1.5	3.0	0.0	1.8	13.8	530.3	0.00	1.00
07/11/2026 23:00	1.5	3.3	0.0	2.0	13.0	591.3	0.00	1.00
Average/Sum#:	1.5	2.6	0.0	1.7	14.1	458.1	0.00 #	24.00 #
Minimum:	1.5	2.1	0.0	1.6	13.0	378.1	0.00	1.00
Maximum:	1.5	3.3	0.0	2.0	14.5	591.3	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/12/2026 00:00	1.5	2.9	0.0	1.8	13.9	526.9	0.00	1.00
07/12/2026 01:00	1.5	2.9	0.0	1.8	13.9	525.3	0.00	1.00
07/12/2026 02:00	1.5	3.0	0.0	1.8	13.9	524.5	0.00	1.00
07/12/2026 03:00	1.5	2.9	0.0	1.8	13.9	524.3	0.00	1.00
07/12/2026 04:00	1.5	2.9	0.0	1.8	14.0	523.5	0.00	1.00
07/12/2026 05:00	1.5	2.9	0.0	1.8	14.0	522.9	0.00	1.00
07/12/2026 06:00	1.5	3.0	0.0	1.8	13.9	528.7	0.00	1.00
07/12/2026 07:00	1.5	3.3	0.0	2.0	13.2	587.0	0.00	1.00
07/12/2026 08:00	1.5	3.4	0.0	2.1	12.8	610.5	0.00	1.00
07/12/2026 09:00	1.5	3.0	0.0	1.8	13.7	540.7	0.00	1.00
07/12/2026 10:00	1.5	2.9	0.0	1.8	13.9	523.3	0.00	1.00
07/12/2026 11:00	1.5	2.9	0.0	1.8	13.8	528.4	0.00	1.00
07/12/2026 12:00	1.5	2.9	0.0	1.9	13.6	534.9	0.00	1.00
07/12/2026 13:00	1.5	3.2	0.0	2.1	12.9	583.5	0.00	1.00
07/12/2026 14:00	1.5	3.4	0.0	2.1	12.7	618.3	0.00	1.00
07/12/2026 15:00	1.5	3.7	0.0	2.2	12.3	651.0	0.00	1.00
07/12/2026 16:00	1.5	3.5	0.0	2.2	12.3	651.3	0.00	1.00
07/12/2026 17:00	1.5	3.2	0.0	2.0	13.2	581.9	0.00	1.00
07/12/2026 18:00	1.5	3.0	0.0	1.8	13.7	546.5	0.00	1.00
07/12/2026 19:00	1.5	3.6	0.0	2.2	12.4	642.2	0.00	1.00
07/12/2026 20:00	1.5	3.6	0.0	2.2	12.3	657.5	0.00	1.00
07/12/2026 21:00	1.5	3.6	0.0	2.2	12.3	654.6	0.00	1.00
07/12/2026 22:00	1.5	3.2	0.0	2.0	13.0	590.3	0.00	1.00
07/12/2026 23:00	1.5	2.2	0.0	1.6	14.3	398.3	0.00	1.00
Average/Sum#:	1.5	3.1	0.0	1.9	13.3	565.7	0.00 #	24.00 #
Minimum:	1.5	2.2	0.0	1.6	12.3	398.3	0.00	1.00
Maximum:	1.5	3.7	0.0	2.2	14.3	657.5	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/13/2026 00:00	1.5	2.3	0.0	1.7	14.4	411.1	0.00	1.00
07/13/2026 01:00	1.5	2.6	0.0	1.6	14.6	461.2	0.00	1.00
07/13/2026 02:00	1.5	2.6	0.0	1.7	14.6	461.6	0.00	1.00
07/13/2026 03:00	1.5	2.5	0.0	1.6	14.5	451.3	0.00	1.00
07/13/2026 04:00	1.5	2.5	0.0	1.6	14.5	458.6	0.00	1.00
07/13/2026 05:00	1.5	2.4	0.0	1.7	14.4	427.5	0.00	1.00
07/13/2026 06:00	1.5	2.6	0.0	1.6	14.5	458.9	0.00	1.00
07/13/2026 07:00	1.5	2.5	0.0	1.6	14.5	453.1	0.00	1.00
07/13/2026 08:00	1.5	3.2	0.0	2.0	13.0	582.1	0.00	1.00
07/13/2026 09:00	1.5	3.7	0.0	2.3	12.1	662.0	0.00	1.00
07/13/2026 10:00	1.5	3.7	0.0	2.2	12.1	660.2	0.00	1.00
07/13/2026 11:00	1.5	3.7	0.0	2.2	12.2	659.2	0.00	1.00
07/13/2026 12:00	1.5	3.7	0.0	2.2	12.2	658.2	0.00	1.00
07/13/2026 13:00	1.5	3.7	0.0	2.2	12.1	661.5	0.00	1.00
07/13/2026 14:00	1.5	3.7	0.0	2.2	12.1	660.9	0.00	1.00
07/13/2026 15:00	1.5	3.7	0.0	2.2	12.1	660.9	0.00	1.00
07/13/2026 16:00	1.5	3.7	0.0	2.2	12.1	661.0	0.00	1.00
07/13/2026 17:00	1.5	3.6	0.0	2.2	12.1	655.7	0.00	1.00
07/13/2026 18:00	1.5	3.7	0.0	2.2	12.2	654.7	0.00	1.00
07/13/2026 19:00	1.5	3.7	0.0	2.2	12.1	659.7	0.00	1.00
07/13/2026 20:00	1.5	3.6	0.0	2.2	12.2	655.7	0.00	1.00
07/13/2026 21:00	1.5	3.5	0.0	2.1	12.5	641.1	0.00	1.00
07/13/2026 22:00	1.5	3.1	0.0	1.9	13.4	561.9	0.00	1.00
07/13/2026 23:00	1.5	3.0	0.0	1.8	13.8	538.1	0.00	1.00
Average/Sum#:	1.5	3.2	0.0	2.0	13.1	575.7	0.00 #	24.00 #
Minimum:	1.5	2.3	0.0	1.6	12.1	411.1	0.00	1.00
Maximum:	1.5	3.7	0.0	2.3	14.6	662.0	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/14/2026 00:00	1.5	3.2	0.0	1.9	13.4	567.1	0.00	1.00
07/14/2026 01:00	1.5	2.9	0.0	1.8	13.9	525.7	0.00	1.00
07/14/2026 02:00	1.4	2.8	0.0	1.7	13.8	526.8	0.00	1.00
07/14/2026 03:00	1.5	2.9	0.0	1.8	13.9	525.2	0.00	1.00
07/14/2026 04:00	1.5	2.9	0.0	1.8	13.9	525.7	0.00	1.00
07/14/2026 05:00	1.5	3.1	0.0	1.9	13.5	556.4	0.00	1.00
07/14/2026 06:00	1.5	2.9	0.0	1.8	14.0	521.9	0.00	1.00
07/14/2026 07:00	1.5	2.9	0.0	1.8	13.9	524.6	0.00	1.00
07/14/2026 08:00	1.5	2.9	0.0	1.8	13.7	528.8	0.00	1.00
07/14/2026 09:00	1.5	3.0	0.0	1.9	13.4	536.8	0.00	1.00
07/14/2026 10:00	1.5	3.0	0.0	2.0	13.1	541.7	0.00	1.00
07/14/2026 11:00	1.5	3.0	0.0	2.1	12.8	548.9	0.00	1.00
07/14/2026 12:00	1.4	3.0	0.0	1.8	13.3	558.6	0.00	1.00
07/14/2026 13:00	1.5	3.3	0.0	2.0	13.0	589.2	0.00	1.00
07/14/2026 14:00	1.5	3.5	0.0	2.2	12.5	629.1	0.00	1.00
07/14/2026 15:00	1.5	3.6	0.0	2.2	12.2	646.6	0.00	1.00
07/14/2026 16:00	1.5	3.6	0.0	2.2	12.3	642.2	0.00	1.00
07/14/2026 17:00	1.5	3.6	0.0	2.2	12.2	651.8	0.00	1.00
07/14/2026 18:00	1.5	3.6	0.0	2.2	12.2	649.3	0.00	1.00
07/14/2026 19:00	1.5	3.4	0.0	2.1	12.4	632.0	0.00	1.00
07/14/2026 20:00	1.5	3.3	0.0	2.0	12.8	607.3	0.00	1.00
07/14/2026 21:00	1.5	3.5	0.0	2.1	12.7	618.8	0.00	1.00
07/14/2026 22:00	1.5	3.1	0.0	1.9	13.5	558.4	0.00	1.00
07/14/2026 23:00	1.5	2.9	0.0	1.8	13.9	525.7	0.00	1.00
Average/Sum#:	1.5	3.2	0.0	2.0	13.2	572.4	0.00 #	24.00 #
Minimum:	1.4	2.8	0.0	1.7	12.2	521.9	0.00	1.00
Maximum:	1.5	3.6	0.0	2.2	14.0	651.8	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/15/2026 00:00	1.5	3.0	0.0	1.8	13.8	528.7	0.00	1.00
07/15/2026 01:00	1.5	2.9	0.0	1.8	13.8	527.4	0.00	1.00
07/15/2026 02:00	1.5	2.9	0.0	1.8	13.8	524.0	0.00	1.00
07/15/2026 03:00	1.5	2.9	0.0	1.8	13.9	522.3	0.00	1.00
07/15/2026 04:00	1.5	2.9	0.0	1.8	13.9	521.9	0.00	1.00
07/15/2026 05:00	1.5	2.9	0.0	1.8	13.9	523.0	0.00	1.00
07/15/2026 06:00	1.5	2.9	0.0	1.8	13.9	525.6	0.00	1.00
07/15/2026 07:00	1.5	2.9	0.0	1.8	13.8	529.8	0.00	1.00
07/15/2026 08:00	1.5	3.0	0.0	1.9	13.6	535.2	0.00	1.00
07/15/2026 09:00	1.5	3.0	0.0	2.0	13.2	543.0	0.00	1.00
07/15/2026 10:00	1.5	3.6	0.0	2.3	12.1	644.2	0.00	1.00
07/15/2026 11:00	1.5	3.6	0.0	2.2	12.2	652.3	0.00	1.00
07/15/2026 12:00	1.5	3.4	0.0	2.1	12.9	599.3	0.00	1.00
07/15/2026 13:00	1.5	3.4	0.0	2.1	12.5	621.7	0.00	1.00
07/15/2026 14:00	1.5	3.8	0.0	2.3	12.0	663.6	0.00	1.00
07/15/2026 15:00	1.5	3.5	0.0	2.2	12.2	646.4	0.00	1.00
07/15/2026 16:00	1.5	3.8	0.0	2.3	11.9	671.1	0.00	1.00
07/15/2026 17:00	1.5	3.6	0.0	2.2	12.1	656.2	0.00	1.00
07/15/2026 18:00	1.5	3.7	0.0	2.2	12.1	660.4	0.00	1.00
07/15/2026 19:00	1.5	3.5	0.0	2.1	12.4	645.4	0.00	1.00
07/15/2026 20:00	1.5	3.5	0.0	2.1	12.7	626.6	0.00	1.00
07/15/2026 21:00	1.5	3.4	0.0	2.0	12.9	604.4	0.00	1.00
07/15/2026 22:00	1.5	3.0	0.0	1.9	13.5	548.0	0.00	1.00
07/15/2026 23:00	1.5	3.0	0.0	1.8	13.7	536.3	0.00	1.00
Average/Sum#:	1.5	3.3	0.0	2.0	13.0	585.7	0.00 #	24.00 #
Minimum:	1.5	2.9	0.0	1.8	11.9	521.9	0.00	1.00
Maximum:	1.5	3.8	0.0	2.3	13.9	671.1	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/16/2026 00:00	1.5	3.0	0.0	1.8	13.8	534.6	0.00	1.00
07/16/2026 01:00	1.5	2.9	0.0	1.8	13.9	531.1	0.00	1.00
07/16/2026 02:00	1.5	2.9	0.0	1.7	14.0	524.4	0.00	1.00
07/16/2026 03:00	1.5	2.9	0.0	1.8	14.0	522.7	0.00	1.00
07/16/2026 04:00	1.5	2.9	0.0	1.8	14.0	523.5	0.00	1.00
07/16/2026 05:00	1.5	2.9	0.0	1.8	14.0	523.1	0.00	1.00
07/16/2026 06:00	1.5	2.9	0.0	1.8	14.0	522.9	0.00	1.00
07/16/2026 07:00	1.5	2.9	0.0	1.8	14.0	525.0	0.00	1.00
07/16/2026 08:00	1.5	2.9	0.0	1.8	13.9	527.4	0.00	1.00
07/16/2026 09:00	1.5	2.9	0.0	1.8	13.8	529.4	0.00	1.00
07/16/2026 10:00	1.5	3.0	0.0	1.9	13.7	533.9	0.00	1.00
07/16/2026 11:00	1.5	3.0	0.0	1.9	13.4	537.5	0.00	1.00
07/16/2026 12:00	1.5	3.0	0.0	2.0	13.0	547.8	0.00	1.00
07/16/2026 13:00	1.5	3.1	0.0	2.1	12.9	548.4	0.00	1.00
07/16/2026 14:00	1.5	3.0	0.0	2.1	12.7	550.5	0.00	1.00
07/16/2026 15:00	1.5	3.1	0.0	2.1	12.6	554.0	0.00	1.00
07/16/2026 16:00	1.5	3.1	0.0	2.1	12.7	552.1	0.00	1.00
07/16/2026 17:00	1.5	3.1	0.0	2.1	12.9	551.4	0.00	1.00
07/16/2026 18:00	1.5	3.0	0.0	2.0	13.2	542.6	0.00	1.00
07/16/2026 19:00	1.5	3.0	0.0	1.9	13.6	534.5	0.00	1.00
07/16/2026 20:00	1.5	2.9	0.0	1.8	13.8	528.0	0.00	1.00
07/16/2026 21:00	1.5	2.9	0.0	1.8	13.9	525.3	0.00	1.00
07/16/2026 22:00	1.5	2.9	0.0	1.8	13.9	523.5	0.00	1.00
07/16/2026 23:00	1.5	2.9	0.0	1.8	14.0	521.6	0.00	1.00
Average/Sum#:	1.5	3.0	0.0	1.9	13.6	534.0	0.00 #	24.00 #
Minimum:	1.5	2.9	0.0	1.7	12.6	521.6	0.00	1.00
Maximum:	1.5	3.1	0.0	2.1	14.0	554.0	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/17/2026 00:00	1.5	2.9	0.0	1.8	14.0	521.4	0.00	1.00
07/17/2026 01:00	1.5	2.9	0.0	1.7	14.1	520.0	0.00	1.00
07/17/2026 02:00	1.4	2.8	0.0	1.7	14.1	521.4	0.00	1.00
07/17/2026 03:00	1.5	2.9	0.0	1.7	14.1	521.4	0.00	1.00
07/17/2026 04:00	1.5	2.9	0.0	1.7	14.1	520.1	0.00	1.00
07/17/2026 05:00	1.5	2.9	0.0	1.7	14.1	519.9	0.00	1.00
07/17/2026 06:00	1.5	2.9	0.0	1.7	14.1	521.5	0.00	1.00
07/17/2026 07:00	1.5	2.9	0.0	1.8	14.1	523.7	0.00	1.00
07/17/2026 08:00	1.5	2.9	0.0	1.8	14.0	526.2	0.00	1.00
07/17/2026 09:00	1.5	2.9	0.0	1.8	13.9	525.8	0.00	1.00
07/17/2026 10:00	1.5	2.9	0.0	1.8	13.9	527.2	0.00	1.00
07/17/2026 11:00	1.5	2.9	0.0	1.8	13.7	532.3	0.00	1.00
07/17/2026 12:00	1.5	3.0	0.0	1.9	13.4	537.0	0.00	1.00
07/17/2026 13:00	1.5	3.0	0.0	2.0	13.1	543.8	0.00	1.00
07/17/2026 14:00	1.5	3.0	0.0	2.0	12.9	549.4	0.00	1.00
07/17/2026 15:00	1.5	3.0	0.0	2.1	12.8	547.8	0.00	1.00
07/17/2026 16:00	1.5	3.0	0.0	2.1	12.8	548.3	0.00	1.00
07/17/2026 17:00	1.5	3.0	0.0	2.0	13.0	542.7	0.00	1.00
07/17/2026 18:00	1.5	3.0	0.0	1.9	13.4	533.0	0.00	1.00
07/17/2026 19:00	1.5	2.9	0.0	1.8	13.8	526.1	0.00	1.00
07/17/2026 20:00	1.5	2.9	0.0	1.8	13.9	523.4	0.00	1.00
07/17/2026 21:00	1.5	2.9	0.0	1.8	14.0	522.3	0.00	1.00
07/17/2026 22:00	1.5	2.9	0.0	1.7	14.0	520.7	0.00	1.00
07/17/2026 23:00	1.5	2.9	0.0	1.7	14.1	519.2	0.00	1.00
Average/Sum#:	1.5	2.9	0.0	1.8	13.7	528.9	0.00 #	24.00 #
Minimum:	1.4	2.8	0.0	1.7	12.8	519.2	0.00	1.00
Maximum:	1.5	3.0	0.0	2.1	14.1	549.4	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/18/2026 00:00	1.5	2.8	0.0	1.7	14.1	517.6	0.00	1.00
07/18/2026 01:00	1.5	2.8	0.0	1.7	14.1	516.5	0.00	1.00
07/18/2026 02:00	1.6	3.1	0.0	1.8	14.2	515.8	0.00	1.00
07/18/2026 03:00	1.5	2.9	0.0	1.7	14.2	515.9	0.00	1.00
07/18/2026 04:00	1.5	2.8	0.0	1.7	14.2	514.2	0.00	1.00
07/18/2026 05:00	1.5	3.0	0.0	1.8	14.0	529.7	0.00	1.00
07/18/2026 06:00	1.5	2.9	0.0	1.7	14.2	516.0	0.00	1.00
07/18/2026 07:00	1.5	2.9	0.0	1.7	14.2	518.6	0.00	1.00
07/18/2026 08:00	1.5	2.9	0.0	1.7	14.1	522.1	0.00	1.00
07/18/2026 09:00	1.5	2.9	0.0	1.8	14.0	524.0	0.00	1.00
07/18/2026 10:00	1.5	2.9	0.0	1.8	14.0	525.2	0.00	1.00
07/18/2026 11:00	1.5	2.6	0.0	1.7	14.1	457.7	0.00	1.00
07/18/2026 12:00	1.5	2.2	0.0	1.7	14.4	375.0	0.00	1.00
07/18/2026 13:00	1.5	2.3	0.0	1.7	14.5	399.1	0.00	1.00
07/18/2026 14:00	1.5	3.0	0.0	1.9	13.2	540.9	0.00	1.00
07/18/2026 15:00	1.5	3.0	0.0	2.0	13.1	541.7	0.00	1.00
07/18/2026 16:00	1.5	3.0	0.0	2.0	13.0	542.5	0.00	1.00
07/18/2026 17:00	1.5	3.0	0.0	2.0	13.0	542.6	0.00	1.00
07/18/2026 18:00	1.5	3.0	0.0	2.0	13.2	539.0	0.00	1.00
07/18/2026 19:00	1.5	3.0	0.0	1.9	13.6	530.8	0.00	1.00
07/18/2026 20:00	1.5	2.9	0.0	1.8	13.8	529.0	0.00	1.00
07/18/2026 21:00	1.5	2.9	0.0	1.8	13.8	529.8	0.00	1.00
07/18/2026 22:00	1.5	2.9	0.0	1.8	13.9	527.4	0.00	1.00
07/18/2026 23:00	1.5	2.9	0.0	1.8	13.9	525.7	0.00	1.00
Average/Sum#:	1.5	2.9	0.0	1.8	13.9	512.4	0.00 #	24.00 #
Minimum:	1.5	2.2	0.0	1.7	13.0	375.0	0.00	1.00
Maximum:	1.6	3.1	0.0	2.0	14.5	542.6	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/19/2026 00:00	1.5	2.9	0.0	1.8	14.0	524.9	0.00	1.00
07/19/2026 01:00	1.5	2.9	0.0	1.8	14.0	523.3	0.00	1.00
07/19/2026 02:00	1.5	2.8	0.0	1.7	14.1	521.6	0.00	1.00
07/19/2026 03:00	1.5	2.9	0.0	1.7	14.1	519.9	0.00	1.00
07/19/2026 04:00	1.5	2.9	0.0	1.7	14.1	518.2	0.00	1.00
07/19/2026 05:00	1.5	2.8	0.0	1.7	14.1	518.2	0.00	1.00
07/19/2026 06:00	1.5	2.9	0.0	1.7	14.1	519.8	0.00	1.00
07/19/2026 07:00	1.5	2.9	0.0	1.7	14.1	521.0	0.00	1.00
07/19/2026 08:00	1.5	2.9	0.0	1.8	14.0	522.7	0.00	1.00
07/19/2026 09:00	1.5	2.9	0.0	1.8	13.9	524.1	0.00	1.00
07/19/2026 10:00	1.5	2.9	0.0	1.8	13.8	528.2	0.00	1.00
07/19/2026 11:00	1.5	2.9	0.0	1.9	13.6	533.0	0.00	1.00
07/19/2026 12:00	1.5	3.0	0.0	2.0	13.2	541.7	0.00	1.00
07/19/2026 13:00	1.5	3.0	0.0	2.0	13.0	545.6	0.00	1.00
07/19/2026 14:00	1.5	3.0	0.0	2.1	12.9	547.9	0.00	1.00
07/19/2026 15:00	1.5	3.1	0.0	2.1	12.7	550.7	0.00	1.00
07/19/2026 16:00	1.5	3.1	0.0	2.1	12.7	556.0	0.00	1.00
07/19/2026 17:00	1.5	3.3	0.0	2.2	12.4	605.0	0.00	1.00
07/19/2026 18:00	1.5	3.3	0.0	2.0	12.7	619.4	0.00	1.00
07/19/2026 19:00	1.5	3.3	0.0	2.0	13.0	604.9	0.00	1.00
07/19/2026 20:00	1.5	3.7	0.0	2.2	12.4	652.0	0.00	1.00
07/19/2026 21:00	1.5	3.6	0.0	2.2	12.4	656.0	0.00	1.00
07/19/2026 22:00	1.5	3.6	0.0	2.2	12.4	649.5	0.00	1.00
07/19/2026 23:00	1.5	3.6	0.0	2.2	12.5	645.8	0.00	1.00
Average/Sum#:	1.5	3.1	0.0	1.9	13.3	560.4	0.00 #	24.00 #
Minimum:	1.5	2.8	0.0	1.7	12.4	518.2	0.00	1.00
Maximum:	1.5	3.7	0.0	2.2	14.1	656.0	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/20/2026 00:00	1.5	3.2	0.0	1.9	13.5	569.4	0.00	1.00
07/20/2026 01:00	1.5	2.9	0.0	1.8	14.0	524.9	0.00	1.00
07/20/2026 02:00	1.4	2.8	0.0	1.7	13.7	548.4	0.00	1.00
07/20/2026 03:00	1.6	3.8	0.0	2.3	12.4	648.8	0.00	1.00
07/20/2026 04:00	1.5	3.7	0.0	2.2	12.3	659.4	0.00	1.00
07/20/2026 05:00	1.5	3.6	0.0	2.2	12.3	657.3	0.00	1.00
07/20/2026 06:00	1.5	3.5	0.0	2.1	12.5	643.9	0.00	1.00
07/20/2026 07:00	1.5	3.5	0.0	2.1	12.6	630.9	0.00	1.00
07/20/2026 08:00	1.5	3.6	0.0	2.2	12.6	633.6	0.00	1.00
07/20/2026 09:00	1.5	3.4	0.0	2.1	12.8	612.0	0.00	1.00
07/20/2026 10:00	1.5	3.5	0.0	2.1	12.5	640.5	0.00	1.00
07/20/2026 11:00	1.5	3.5	0.0	2.1	12.6	635.5	0.00	1.00
07/20/2026 12:00	1.5	3.5	0.0	2.1	12.7	623.8	0.00	1.00
07/20/2026 13:00	1.5	3.6	0.0	2.2	12.4	644.3	0.00	1.00
07/20/2026 14:00	1.5	3.4	0.0	2.1	12.7	618.1	0.00	1.00
07/20/2026 15:00	1.5	3.4	0.0	2.1	12.7	619.3	0.00	1.00
07/20/2026 16:00	1.5	3.5	0.0	2.1	12.6	629.4	0.00	1.00
07/20/2026 17:00	1.5	3.5	0.0	2.1	12.6	629.2	0.00	1.00
07/20/2026 18:00	1.5	3.6	0.0	2.2	12.4	646.7	0.00	1.00
07/20/2026 19:00	1.5	3.5	0.0	2.1	12.6	635.8	0.00	1.00
07/20/2026 20:00	1.5	3.6	0.0	2.1	12.5	644.4	0.00	1.00
07/20/2026 21:00	1.5	3.5	0.0	2.1	12.7	627.3	0.00	1.00
07/20/2026 22:00	1.5	3.1	0.0	1.9	13.5	564.2	0.00	1.00
07/20/2026 23:00	1.5	3.2	0.0	2.0	13.2	575.9	0.00	1.00
Average/Sum#:	1.5	3.4	0.0	2.1	12.8	619.3	0.00 #	24.00 #
Minimum:	1.4	2.8	0.0	1.7	12.3	524.9	0.00	1.00
Maximum:	1.6	3.8	0.0	2.3	14.0	659.4	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/21/2026 00:00	1.5	2.9	0.0	1.8	13.8	528.4	0.00	1.00
07/21/2026 01:00	1.5	2.9	0.0	1.8	13.8	530.3	0.00	1.00
07/21/2026 02:00	1.5	3.0	0.0	1.8	13.8	530.5	0.00	1.00
07/21/2026 03:00	1.5	2.9	0.0	1.8	13.9	528.1	0.00	1.00
07/21/2026 04:00	1.5	3.1	0.0	1.9	13.6	553.1	0.00	1.00
07/21/2026 05:00	1.5	3.5	0.0	2.1	12.7	621.8	0.00	1.00
07/21/2026 06:00	1.5	3.2	0.0	1.9	13.3	568.2	0.00	1.00
07/21/2026 07:00	1.5	3.1	0.0	1.9	13.6	548.3	0.00	1.00
07/21/2026 08:00	1.5	3.1	0.0	1.9	13.4	561.1	0.00	1.00
07/21/2026 09:00	1.5	3.0	0.0	1.9	13.4	541.7	0.00	1.00
07/21/2026 10:00	1.5	3.1	0.0	2.0	13.0	551.9	0.00	1.00
07/21/2026 11:00	1.5	3.2	0.0	2.1	12.5	591.1	0.00	1.00
07/21/2026 12:00	1.5	3.6	0.0	2.2	12.3	651.6	0.00	1.00
07/21/2026 13:00	1.5	3.6	0.0	2.2	12.4	641.7	0.00	1.00
07/21/2026 14:00	1.5	3.6	0.0	2.2	12.3	645.8	0.00	1.00
07/21/2026 15:00	1.5	3.6	0.0	2.2	12.1	655.1	0.00	1.00
07/21/2026 16:00	1.5	3.6	0.0	2.2	12.3	642.5	0.00	1.00
07/21/2026 17:00	1.5	3.6	0.0	2.2	12.1	651.7	0.00	1.00
07/21/2026 18:00	1.5	3.7	0.0	2.3	12.0	664.2	0.00	1.00
07/21/2026 19:00	1.5	3.7	0.0	2.3	12.0	662.9	0.00	1.00
07/21/2026 20:00	1.5	3.6	0.0	2.2	12.2	657.6	0.00	1.00
07/21/2026 21:00	1.5	3.5	0.0	2.1	12.4	646.5	0.00	1.00
07/21/2026 22:00	1.5	3.5	0.0	2.1	12.5	633.7	0.00	1.00
07/21/2026 23:00	1.5	3.4	0.0	2.1	12.7	619.8	0.00	1.00
Average/Sum#:	1.5	3.3	0.0	2.1	12.8	601.2	0.00 #	24.00 #
Minimum:	1.5	2.9	0.0	1.8	12.0	528.1	0.00	1.00
Maximum:	1.5	3.7	0.0	2.3	13.9	664.2	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/22/2026 00:00	1.5	2.9	0.0	1.8	13.9	525.2	0.00	1.00
07/22/2026 01:00	1.5	2.9	0.0	1.8	13.8	524.9	0.00	1.00
07/22/2026 02:00	1.5	2.9	0.0	1.8	13.9	524.4	0.00	1.00
07/22/2026 03:00	1.5	2.9	0.0	1.8	13.9	523.2	0.00	1.00
07/22/2026 04:00	1.5	3.0	0.0	1.8	13.9	528.3	0.00	1.00
07/22/2026 05:00	1.5	3.1	0.0	1.9	13.5	556.2	0.00	1.00
07/22/2026 06:00	1.5	2.9	0.0	1.8	13.9	522.5	0.00	1.00
07/22/2026 07:00	1.5	3.0	0.0	1.8	13.8	534.2	0.00	1.00
07/22/2026 08:00	1.5	3.2	0.0	1.9	13.3	571.5	0.00	1.00
07/22/2026 09:00	1.5	2.9	0.0	1.8	13.9	523.2	0.00	1.00
07/22/2026 10:00	1.5	2.9	0.0	1.8	13.8	524.8	0.00	1.00
07/22/2026 11:00	1.5	2.9	0.0	1.8	13.8	527.2	0.00	1.00
07/22/2026 12:00	1.5	2.9	0.0	1.8	13.7	529.5	0.00	1.00
07/22/2026 13:00	1.5	2.9	0.0	1.9	13.6	532.0	0.00	1.00
07/22/2026 14:00	1.5	3.0	0.0	1.9	13.4	534.0	0.00	1.00
07/22/2026 15:00	1.5	3.0	0.0	1.9	13.4	533.5	0.00	1.00
07/22/2026 16:00	1.5	3.0	0.0	1.9	13.3	534.5	0.00	1.00
07/22/2026 17:00	1.5	2.9	0.0	1.9	13.4	532.4	0.00	1.00
07/22/2026 18:00	1.5	2.9	0.0	1.9	13.6	528.2	0.00	1.00
07/22/2026 19:00	1.5	2.9	0.0	1.8	13.8	524.1	0.00	1.00
07/22/2026 20:00	1.5	2.9	0.0	1.8	13.9	520.6	0.00	1.00
07/22/2026 21:00	1.5	2.9	0.0	1.8	14.0	518.7	0.00	1.00
07/22/2026 22:00	1.5	2.9	0.0	1.7	14.0	518.0	0.00	1.00
07/22/2026 23:00	1.5	2.8	0.0	1.7	14.1	516.7	0.00	1.00
Average/Sum#:	1.5	2.9	0.0	1.8	13.7	529.5	0.00 #	24.00 #
Minimum:	1.5	2.8	0.0	1.7	13.3	516.7	0.00	1.00
Maximum:	1.5	3.2	0.0	1.9	14.1	571.5	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/23/2026 00:00	1.5	2.8	0.0	1.7	14.1	516.8	0.00	1.00
07/23/2026 01:00	1.5	2.9	0.0	1.7	14.1	516.5	0.00	1.00
07/23/2026 02:00	1.5	2.9	0.0	1.7	14.1	515.2	0.00	1.00
07/23/2026 03:00	1.5	2.9	0.0	1.7	14.1	515.3	0.00	1.00
07/23/2026 04:00	1.5	2.8	0.0	1.7	14.2	515.9	0.00	1.00
07/23/2026 05:00	1.5	2.9	0.0	1.7	14.2	516.1	0.00	1.00
07/23/2026 06:00	1.5	2.9	0.0	1.7	14.1	519.0	0.00	1.00
07/23/2026 07:00	1.5	2.9	0.0	1.7	14.1	520.4	0.00	1.00
07/23/2026 08:00	1.5	2.8	0.0	1.7	14.2	501.8	0.00	1.00
07/23/2026 09:00	1.5	2.1	0.0	1.7	14.3	378.4	0.00	1.00
07/23/2026 10:00	1.5	2.1	0.0	1.7	14.4	375.6	0.00	1.00
07/23/2026 11:00	1.6	2.8	0.0	1.8	14.1	464.0	0.00	1.00
07/23/2026 12:00	1.5	3.0	0.0	1.9	13.6	533.6	0.00	1.00
07/23/2026 13:00	1.5	3.0	0.0	1.9	13.3	537.3	0.00	1.00
07/23/2026 14:00	1.5	3.0	0.0	2.0	13.2	539.3	0.00	1.00
07/23/2026 15:00	1.5	3.0	0.0	2.0	13.1	541.6	0.00	1.00
07/23/2026 16:00	1.5	3.0	0.0	2.0	13.0	542.4	0.00	1.00
07/23/2026 17:00	1.5	3.0	0.0	2.0	13.0	543.8	0.00	1.00
07/23/2026 18:00	1.5	3.1	0.0	2.1	12.8	561.0	0.00	1.00
07/23/2026 19:00	1.5	2.9	0.0	1.9	13.5	537.2	0.00	1.00
07/23/2026 20:00	1.5	3.0	0.0	1.9	13.5	553.3	0.00	1.00
07/23/2026 21:00	1.5	2.9	0.0	1.8	13.8	529.3	0.00	1.00
07/23/2026 22:00	1.5	2.9	0.0	1.8	13.9	530.1	0.00	1.00
07/23/2026 23:00	1.5	3.0	0.0	1.8	13.9	532.2	0.00	1.00
Average/Sum#:	1.5	2.9	0.0	1.8	13.8	514.0	0.00 #	24.00 #
Minimum:	1.5	2.1	0.0	1.7	12.8	375.6	0.00	1.00
Maximum:	1.6	3.1	0.0	2.1	14.4	561.0	0.00	1.00
%SI	0.00	0.00	12.50	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/24/2026 00:00	1.5	2.9	0.0	1.7	14.1	522.1	0.00	1.00
07/24/2026 01:00	1.5	2.9	0.0	1.7	14.1	521.9	0.00	1.00
07/24/2026 02:00	1.5	2.9	0.0	1.8	14.1	521.9	0.00	1.00
07/24/2026 03:00	1.5	2.9	0.0	1.7	14.1	520.8	0.00	1.00
07/24/2026 04:00	1.5	2.8	0.0	1.7	14.1	519.0	0.00	1.00
07/24/2026 05:00	1.5	2.9	0.0	1.7	14.1	518.8	0.00	1.00
07/24/2026 06:00	1.5	2.9	0.0	1.7	14.1	521.5	0.00	1.00
07/24/2026 07:00	1.5	2.9	0.0	1.7	14.1	523.5	0.00	1.00
07/24/2026 08:00	1.5	2.9	0.0	1.8	14.0	526.2	0.00	1.00
07/24/2026 09:00	1.5	2.9	0.0	1.8	13.9	528.7	0.00	1.00
07/24/2026 10:00	1.5	2.9	0.0	1.8	13.7	531.3	0.00	1.00
07/24/2026 11:00	1.5	2.2	0.0	1.6	14.4	383.0	0.00	1.00
07/24/2026 12:00	1.5	2.9	0.0	1.9	13.6	505.9	0.00	1.00
07/24/2026 13:00	1.5	3.4	0.0	2.2	12.5	602.9	0.00	1.00
07/24/2026 14:00	1.5	3.7	0.0	2.2	12.2	655.9	0.00	1.00
07/24/2026 15:00	1.5	3.6	0.0	2.2	12.2	653.1	0.00	1.00
07/24/2026 16:00	1.5	3.3	0.0	2.0	13.0	592.7	0.00	1.00
07/24/2026 17:00	1.6	3.5	0.0	2.1	12.9	607.5	0.00	1.00
07/24/2026 18:00	1.5	3.4	0.0	2.0	12.7	620.7	0.00	1.00
07/24/2026 19:00	1.5	3.1	0.0	1.9	13.6	552.8	0.00	1.00
07/24/2026 20:00	1.5	3.1	0.0	1.9	13.6	555.8	0.00	1.00
07/24/2026 21:00	1.5	3.0	0.0	1.8	13.9	536.7	0.00	1.00
07/24/2026 22:00	1.5	2.8	0.0	1.7	14.1	520.9	0.00	1.00
07/24/2026 23:00	1.5	2.9	0.0	1.8	14.0	522.2	0.00	1.00
Average/Sum#:	1.5	3.0	0.0	1.9	13.6	544.4	0.00 #	24.00 #
Minimum:	1.5	2.2	0.0	1.6	12.2	383.0	0.00	1.00
Maximum:	1.6	3.7	0.0	2.2	14.4	655.9	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/25/2026 00:00	1.5	2.9	0.0	1.7	14.1	521.7	0.00	1.00
07/25/2026 01:00	1.5	2.9	0.0	1.7	14.1	520.8	0.00	1.00
07/25/2026 02:00	1.5	2.9	0.0	1.7	14.1	520.5	0.00	1.00
07/25/2026 03:00	1.5	2.9	0.0	1.8	14.1	520.4	0.00	1.00
07/25/2026 04:00	1.5	2.9	0.0	1.7	14.1	519.5	0.00	1.00
07/25/2026 05:00	1.5	2.9	0.0	1.7	14.2	518.2	0.00	1.00
07/25/2026 06:00	1.5	2.9	0.0	1.7	14.1	520.0	0.00	1.00
07/25/2026 07:00	1.5	2.9	0.0	1.8	14.0	523.6	0.00	1.00
07/25/2026 08:00	1.5	2.9	0.0	1.8	14.0	526.2	0.00	1.00
07/25/2026 09:00	1.5	2.9	0.0	1.8	13.9	529.7	0.00	1.00
07/25/2026 10:00	1.5	2.9	0.0	1.8	13.8	532.8	0.00	1.00
07/25/2026 11:00	1.5	3.0	0.0	1.9	13.5	538.0	0.00	1.00
07/25/2026 12:00	1.5	3.0	0.0	2.0	13.2	543.7	0.00	1.00
07/25/2026 13:00	1.5	3.0	0.0	2.0	13.0	546.3	0.00	1.00
07/25/2026 14:00	1.5	3.0	0.0	2.0	12.9	548.2	0.00	1.00
07/25/2026 15:00	1.5	3.0	0.0	2.1	12.8	549.3	0.00	1.00
07/25/2026 16:00	1.5	3.1	0.0	2.1	12.6	551.5	0.00	1.00
07/25/2026 17:00	1.5	3.0	0.0	2.1	12.7	551.4	0.00	1.00
07/25/2026 18:00	1.5	3.0	0.0	2.0	13.0	543.7	0.00	1.00
07/25/2026 19:00	1.5	3.0	0.0	1.9	13.4	535.3	0.00	1.00
07/25/2026 20:00	1.5	3.0	0.0	1.8	13.7	530.5	0.00	1.00
07/25/2026 21:00	1.5	2.9	0.0	1.8	13.8	528.0	0.00	1.00
07/25/2026 22:00	1.5	2.9	0.0	1.8	13.9	526.5	0.00	1.00
07/25/2026 23:00	1.5	2.9	0.0	1.8	13.9	524.9	0.00	1.00
Average/Sum#:	1.5	2.9	0.0	1.9	13.6	532.1	0.00 #	24.00 #
Minimum:	1.5	2.9	0.0	1.7	12.6	518.2	0.00	1.00
Maximum:	1.5	3.1	0.0	2.1	14.2	551.5	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/26/2026 00:00	1.5	2.9	0.0	1.8	14.0	524.3	0.00	1.00
07/26/2026 01:00	1.5	2.9	0.0	1.8	14.0	523.0	0.00	1.00
07/26/2026 02:00	1.5	2.9	0.0	1.8	14.1	521.0	0.00	1.00
07/26/2026 03:00	1.5	2.9	0.0	1.7	14.1	519.4	0.00	1.00
07/26/2026 04:00	1.5	2.9	0.0	1.7	14.1	519.9	0.00	1.00
07/26/2026 05:00	1.5	2.9	0.0	1.7	14.1	520.5	0.00	1.00
07/26/2026 06:00	1.5	2.9	0.0	1.7	14.1	521.8	0.00	1.00
07/26/2026 07:00	1.5	2.1	0.0	1.7	14.3	383.2	0.00	1.00
07/26/2026 08:00	1.5	2.8	0.0	1.7	14.2	469.9	0.00	1.00
07/26/2026 09:00	1.5	2.9	0.0	1.8	13.9	529.6	0.00	1.00
07/26/2026 10:00	1.5	2.9	0.0	1.8	13.8	532.2	0.00	1.00
07/26/2026 11:00	1.5	2.9	0.0	1.8	13.6	533.5	0.00	1.00
07/26/2026 12:00	1.5	3.0	0.0	1.9	13.3	540.7	0.00	1.00
07/26/2026 13:00	1.5	3.0	0.0	2.0	13.1	544.7	0.00	1.00
07/26/2026 14:00	1.5	3.0	0.0	2.1	12.9	547.1	0.00	1.00
07/26/2026 15:00	1.5	3.0	0.0	2.1	12.8	548.9	0.00	1.00
07/26/2026 16:00	1.5	3.0	0.0	2.1	12.8	549.1	0.00	1.00
07/26/2026 17:00	1.5	3.1	0.0	2.1	12.8	550.4	0.00	1.00
07/26/2026 18:00	1.5	3.0	0.0	2.0	13.2	542.1	0.00	1.00
07/26/2026 19:00	1.5	3.0	0.0	1.9	13.6	536.7	0.00	1.00
07/26/2026 20:00	1.5	2.9	0.0	1.8	13.7	538.0	0.00	1.00
07/26/2026 21:00	1.5	3.2	0.0	2.0	13.2	582.5	0.00	1.00
07/26/2026 22:00	1.5	3.2	0.0	2.0	13.3	579.4	0.00	1.00
07/26/2026 23:00	1.5	2.9	0.0	1.8	14.1	521.2	0.00	1.00
Average/Sum#:	1.5	2.9	0.0	1.9	13.6	528.3	0.00 #	24.00 #
Minimum:	1.5	2.1	0.0	1.7	12.8	383.2	0.00	1.00
Maximum:	1.5	3.2	0.0	2.1	14.3	582.5	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/27/2026 00:00	1.5	3.0	0.0	1.8	13.9	536.8	0.00	1.00
07/27/2026 01:00	1.5	2.8	0.0	1.7	14.1	518.4	0.00	1.00
07/27/2026 02:00	1.5	2.9	0.0	1.7	14.2	517.6	0.00	1.00
07/27/2026 03:00	1.5	2.9	0.0	1.7	14.2	517.7	0.00	1.00
07/27/2026 04:00	1.5	2.8	0.0	1.7	14.2	516.5	0.00	1.00
07/27/2026 05:00	1.5	2.9	0.0	1.7	14.2	516.3	0.00	1.00
07/27/2026 06:00	1.5	2.9	0.0	1.7	14.2	518.5	0.00	1.00
07/27/2026 07:00	1.5	2.9	0.0	1.7	14.1	520.7	0.00	1.00
07/27/2026 08:00	1.5	3.0	0.0	1.8	14.0	523.3	0.00	1.00
07/27/2026 09:00	1.5	2.9	0.0	1.8	14.0	525.3	0.00	1.00
07/27/2026 10:00	1.4	2.7	0.0	1.7	13.8	527.7	0.00	1.00
07/27/2026 11:00	1.5	2.9	0.0	1.8	13.7	531.6	0.00	1.00
07/27/2026 12:00	1.5	3.0	0.0	1.9	13.4	537.1	0.00	1.00
07/27/2026 13:00	1.5	3.0	0.0	2.0	13.2	542.0	0.00	1.00
07/27/2026 14:00	1.5	3.0	0.0	2.0	13.0	544.0	0.00	1.00
07/27/2026 15:00	1.5	3.0	0.0	2.0	12.9	544.9	0.00	1.00
07/27/2026 16:00	1.5	3.0	0.0	2.1	12.9	547.8	0.00	1.00
07/27/2026 17:00	1.4	2.9	0.0	1.9	13.0	552.3	0.00	1.00
07/27/2026 18:00	1.5	3.3	0.0	2.0	13.2	584.6	0.00	1.00
07/27/2026 19:00	1.5	3.3	0.0	2.0	13.1	592.5	0.00	1.00
07/27/2026 20:00	1.5	3.1	0.0	1.9	13.5	560.9	0.00	1.00
07/27/2026 21:00	1.5	2.9	0.0	1.8	13.9	527.2	0.00	1.00
07/27/2026 22:00	1.5	2.9	0.0	1.8	14.0	524.4	0.00	1.00
07/27/2026 23:00	1.5	2.9	0.0	1.8	14.0	523.1	0.00	1.00
Average/Sum#:	1.5	3.0	0.0	1.8	13.7	535.5	0.00 #	24.00 #
Minimum:	1.4	2.7	0.0	1.7	12.9	516.3	0.00	1.00
Maximum:	1.5	3.3	0.0	2.1	14.2	592.5	0.00	1.00
%SI	0.00	0.00	29.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/28/2026 00:00	1.5	2.9	0.0	1.7	14.1	522.7	0.00	1.00
07/28/2026 01:00	1.5	2.9	0.0	1.7	14.1	521.3	0.00	1.00
07/28/2026 02:00	1.5	2.9	0.0	1.7	14.1	520.9	0.00	1.00
07/28/2026 03:00	1.5	2.9	0.0	1.7	14.1	519.7	0.00	1.00
07/28/2026 04:00	1.5	2.9	0.0	1.7	14.1	520.0	0.00	1.00
07/28/2026 05:00	1.5	2.9	0.0	1.7	14.2	519.0	0.00	1.00
07/28/2026 06:00	1.5	2.9	0.0	1.7	14.2	520.3	0.00	1.00
07/28/2026 07:00	1.5	2.4	0.0	1.7	14.3	428.6	0.00	1.00
07/28/2026 08:00	1.5	2.2	0.0	1.7	14.3	377.1	0.00	1.00
07/28/2026 09:00	1.5	2.1	0.0	1.7	14.4	376.8	0.00	1.00
07/28/2026 10:00	1.5	2.1	0.0	1.7	14.4	376.0	0.00	1.00
07/28/2026 11:00	1.5	2.4	0.0	1.7	14.5	407.0	0.00	1.00
07/28/2026 12:00	1.5	2.9	0.0	1.8	13.8	508.8	0.00	1.00
07/28/2026 13:00	1.5	2.1	0.0	1.6	14.4	376.9	0.00	1.00
07/28/2026 14:00	1.5	2.1	0.0	1.6	14.5	374.9	0.00	1.00
07/28/2026 15:00	1.5	2.3	0.0	1.7	14.5	405.7	0.00	1.00
07/28/2026 16:00	1.5	2.9	0.0	1.8	13.8	532.3	0.00	1.00
07/28/2026 17:00	1.5	2.9	0.0	1.8	13.8	533.8	0.00	1.00
07/28/2026 18:00	1.5	3.0	0.0	2.0	13.2	542.9	0.00	1.00
07/28/2026 19:00	1.5	3.0	0.0	1.9	13.4	537.1	0.00	1.00
07/28/2026 20:00	1.5	3.0	0.0	1.9	13.7	532.2	0.00	1.00
07/28/2026 21:00	1.5	3.0	0.0	1.8	13.7	532.6	0.00	1.00
07/28/2026 22:00	1.5	2.9	0.0	1.8	13.8	528.5	0.00	1.00
07/28/2026 23:00	1.5	2.1	0.0	1.6	14.3	385.9	0.00	1.00
Average/Sum#:	1.5	2.7	0.0	1.7	14.1	475.0	0.00 #	24.00 #
Minimum:	1.5	2.1	0.0	1.6	13.2	374.9	0.00	1.00
Maximum:	1.5	3.0	0.0	2.0	14.5	542.9	0.00	1.00
%SI	0.00	0.00	12.50	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/29/2026 00:00	1.5	2.1	0.0	1.7	14.3	376.2	0.00	1.00
07/29/2026 01:00	1.5	2.1	0.0	1.7	14.3	376.2	0.00	1.00
07/29/2026 02:00	1.6	2.2	0.0	1.8	14.3	376.6	0.00	1.00
07/29/2026 03:00	1.5	2.1	0.0	1.7	14.3	376.7	0.00	1.00
07/29/2026 04:00	1.5	2.1	0.0	1.7	14.3	376.8	0.00	1.00
07/29/2026 05:00	1.5	2.1	0.0	1.7	14.3	376.6	0.00	1.00
07/29/2026 06:00	1.5	2.2	0.0	1.7	14.3	376.6	0.00	1.00
07/29/2026 07:00	1.5	2.2	0.0	1.7	14.3	376.5	0.00	1.00
07/29/2026 08:00	1.5	2.2	0.0	1.7	14.3	376.0	0.00	1.00
07/29/2026 09:00	1.5	2.1	0.0	1.7	14.4	375.8	0.00	1.00
07/29/2026 10:00	1.5	2.3	0.0	1.7	14.5	402.0	0.00	1.00
07/29/2026 11:00	1.6	3.1	0.0	2.0	13.4	539.6	0.00	1.00
07/29/2026 12:00	1.5	3.0	0.0	2.0	13.1	543.9	0.00	1.00
07/29/2026 13:00	1.5	3.1	0.0	2.1	12.8	550.3	0.00	1.00
07/29/2026 14:00	1.5	3.1	0.0	2.1	12.7	551.0	0.00	1.00
07/29/2026 15:00	1.5	3.1	0.0	2.1	12.5	553.0	0.00	1.00
07/29/2026 16:00	1.5	3.1	0.0	2.1	12.5	553.2	0.00	1.00
07/29/2026 17:00	1.5	3.1	0.0	2.2	12.5	558.6	0.00	1.00
07/29/2026 18:00	1.5	3.1	0.0	2.1	12.6	561.2	0.00	1.00
07/29/2026 19:00	1.5	3.1	0.0	2.0	13.0	547.6	0.00	1.00
07/29/2026 20:00	1.5	3.0	0.0	1.9	13.5	535.9	0.00	1.00
07/29/2026 21:00	1.5	2.1	0.0	1.7	14.4	385.6	0.00	1.00
07/29/2026 22:00	1.5	2.1	0.0	1.7	14.4	375.7	0.00	1.00
07/29/2026 23:00	1.5	2.1	0.0	1.7	14.4	375.9	0.00	1.00
Average/Sum#:	1.5	2.5	0.0	1.9	13.7	449.9	0.00 #	24.00 #
Minimum:	1.5	2.1	0.0	1.7	12.5	375.7	0.00	1.00
Maximum:	1.6	3.1	0.0	2.2	14.5	561.2	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/30/2026 00:00	1.5	2.1	0.0	1.7	14.3	376.5	0.00	1.00
07/30/2026 01:00	1.5	2.1	0.0	1.7	14.3	376.7	0.00	1.00
07/30/2026 02:00	1.6	2.2	0.0	1.7	14.3	376.8	0.00	1.00
07/30/2026 03:00	1.5	2.1	0.0	1.7	14.3	376.7	0.00	1.00
07/30/2026 04:00	1.5	2.1	0.0	1.7	14.3	376.8	0.00	1.00
07/30/2026 05:00	1.5	2.1	0.0	1.7	14.3	376.8	0.00	1.00
07/30/2026 06:00	1.5	2.1	0.0	1.7	14.3	376.5	0.00	1.00
07/30/2026 07:00	1.5	2.2	0.0	1.7	14.3	376.1	0.00	1.00
07/30/2026 08:00	1.5	2.1	0.0	1.7	14.4	375.5	0.00	1.00
07/30/2026 09:00	1.5	2.1	0.0	1.7	14.4	375.2	0.00	1.00
07/30/2026 10:00	1.5	2.1	0.0	1.7	14.4	374.6	0.00	1.00
07/30/2026 11:00	1.5	2.2	0.0	1.6	14.4	374.2	0.00	1.00
07/30/2026 12:00	1.5	2.1	0.0	1.6	14.5	374.0	0.00	1.00
07/30/2026 13:00	1.5	2.2	0.0	1.7	14.5	373.7	0.00	1.00
07/30/2026 14:00	1.5	2.4	0.0	1.6	14.5	421.5	0.00	1.00
07/30/2026 15:00	1.5	2.2	0.0	1.6	14.5	394.8	0.00	1.00
07/30/2026 16:00	1.5	2.2	0.0	1.6	14.5	389.3	0.00	1.00
07/30/2026 17:00	1.5	2.4	0.0	1.7	14.4	423.9	0.00	1.00
07/30/2026 18:00	1.5	2.5	0.0	1.6	14.5	458.2	0.00	1.00
07/30/2026 19:00	1.5	2.2	0.0	1.6	14.5	393.8	0.00	1.00
07/30/2026 20:00	1.5	2.1	0.0	1.7	14.4	374.4	0.00	1.00
07/30/2026 21:00	1.5	2.1	0.0	1.7	14.4	382.8	0.00	1.00
07/30/2026 22:00	1.5	2.2	0.0	1.7	14.4	394.3	0.00	1.00
07/30/2026 23:00	1.5	2.1	0.0	1.7	14.4	377.3	0.00	1.00
Average/Sum#:	1.5	2.2	0.0	1.7	14.4	386.3	0.00 #	24.00 #
Minimum:	1.5	2.1	0.0	1.6	14.3	373.7	0.00	1.00
Maximum:	1.6	2.5	0.0	1.7	14.5	458.2	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
07/31/2026 00:00	1.5	2.1	0.0	1.7	14.3	375.6	0.00	1.00
07/31/2026 01:00	1.5	2.1	0.0	1.7	14.3	376.0	0.00	1.00
07/31/2026 02:00	1.5	2.1	0.0	1.7	14.3	376.3	0.00	1.00
07/31/2026 03:00	1.5	2.1	0.0	1.7	14.3	376.7	0.00	1.00
07/31/2026 04:00	1.5	2.2	0.0	1.7	14.3	397.1	0.00	1.00
07/31/2026 05:00	1.5	2.1	0.0	1.7	14.3	377.4	0.00	1.00
07/31/2026 06:00	1.5	2.1	0.0	1.7	14.3	377.1	0.00	1.00
07/31/2026 07:00	1.5	2.2	0.0	1.7	14.3	377.1	0.00	1.00
07/31/2026 08:00	1.5	2.2	0.0	1.7	14.4	376.7	0.00	1.00
07/31/2026 09:00	1.5	2.1	0.0	1.7	14.4	376.1	0.00	1.00
07/31/2026 10:00	1.5	2.1	0.0	1.7	14.4	375.4	0.00	1.00
07/31/2026 11:00	1.5	2.3	0.0	1.7	14.5	389.7	0.00	1.00
07/31/2026 12:00	1.5	2.7	0.0	1.6	14.5	462.7	0.00	1.00
07/31/2026 13:00	1.5	2.6	0.0	1.6	14.5	461.5	0.00	1.00
07/31/2026 14:00	1.5	2.6	0.0	1.6	14.5	465.6	0.00	1.00
07/31/2026 15:00	1.5	3.0	0.0	1.9	13.5	554.5	0.00	1.00
07/31/2026 16:00	1.5	3.2	0.0	2.0	13.2	580.4	0.00	1.00
07/31/2026 17:00	1.5	3.5	0.0	2.1	12.8	614.4	0.00	1.00
07/31/2026 18:00	1.5	3.6	0.0	2.2	12.2	659.4	0.00	1.00
07/31/2026 19:00	1.5	3.0	0.0	1.8	13.6	544.7	0.00	1.00
07/31/2026 20:00	1.5	2.9	0.0	1.9	13.5	534.6	0.00	1.00
07/31/2026 21:00	1.5	3.0	0.0	1.9	13.6	533.6	0.00	1.00
07/31/2026 22:00	1.5	2.9	0.0	1.8	13.8	528.6	0.00	1.00
07/31/2026 23:00	1.5	2.1	0.0	1.7	14.3	385.9	0.00	1.00
Average/Sum#:	1.5	2.5	0.0	1.8	14.0	453.2	0.00 #	24.00 #
Minimum:	1.5	2.1	0.0	1.6	12.2	375.4	0.00	1.00
Maximum:	1.5	3.6	0.0	2.2	14.5	659.4	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/01/2026 00:00	1.5	2.1	0.0	1.7	14.3	376.9	0.00	1.00
08/01/2026 01:00	1.5	2.1	0.0	1.7	14.3	376.3	0.00	1.00
08/01/2026 02:00	1.5	2.1	0.0	1.7	14.3	376.6	0.00	1.00
08/01/2026 03:00	1.5	2.1	0.0	1.7	14.3	376.8	0.00	1.00
08/01/2026 04:00	1.5	2.1	0.0	1.7	14.3	377.2	0.00	1.00
08/01/2026 05:00	1.5	2.1	0.0	1.7	14.3	377.1	0.00	1.00
08/01/2026 06:00	1.5	2.2	0.0	1.7	14.3	377.4	0.00	1.00
08/01/2026 07:00	1.5	2.1	0.0	1.7	14.3	376.7	0.00	1.00
08/01/2026 08:00	1.5	2.2	0.0	1.7	14.3	376.2	0.00	1.00
08/01/2026 09:00	1.5	2.1	0.0	1.7	14.4	375.3	0.00	1.00
08/01/2026 10:00	1.5	2.1	0.0	1.7	14.4	375.2	0.00	1.00
08/01/2026 11:00	1.5	2.2	0.0	1.7	14.5	375.2	0.00	1.00
08/01/2026 12:00	1.5	2.1	0.0	1.6	14.5	374.3	0.00	1.00
08/01/2026 13:00	1.5	2.1	0.0	1.6	14.5	372.9	0.00	1.00
08/01/2026 14:00	1.5	2.2	0.0	1.6	14.5	400.1	0.00	1.00
08/01/2026 15:00	1.5	2.9	0.0	1.8	13.7	532.1	0.00	1.00
08/01/2026 16:00	1.5	2.9	0.0	1.9	13.4	539.0	0.00	1.00
08/01/2026 17:00	1.5	3.3	0.0	2.1	12.9	592.2	0.00	1.00
08/01/2026 18:00	1.5	3.6	0.0	2.2	12.1	654.3	0.00	1.00
08/01/2026 19:00	1.5	3.3	0.0	2.1	12.7	611.6	0.00	1.00
08/01/2026 20:00	1.5	2.9	0.0	1.8	13.8	525.9	0.00	1.00
08/01/2026 21:00	1.5	3.0	0.0	1.9	13.3	541.6	0.00	1.00
08/01/2026 22:00	1.5	3.0	0.0	1.9	13.4	538.7	0.00	1.00
08/01/2026 23:00	1.5	2.4	0.0	1.6	14.5	430.2	0.00	1.00
Average/Sum#:	1.5	2.5	0.0	1.8	14.0	442.9	0.00 #	24.00 #
Minimum:	1.5	2.1	0.0	1.6	12.1	372.9	0.00	1.00
Maximum:	1.5	3.6	0.0	2.2	14.5	654.3	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/02/2026 00:00	1.5	2.1	0.0	1.7	14.4	378.5	0.00	1.00
08/02/2026 01:00	1.5	2.1	0.0	1.7	14.4	374.8	0.00	1.00
08/02/2026 02:00	1.5	2.1	0.0	1.7	14.3	375.2	0.00	1.00
08/02/2026 03:00	1.5	2.1	0.0	1.7	14.3	375.6	0.00	1.00
08/02/2026 04:00	1.5	2.1	0.0	1.7	14.3	375.4	0.00	1.00
08/02/2026 05:00	1.5	2.1	0.0	1.7	14.3	375.8	0.00	1.00
08/02/2026 06:00	1.5	2.1	0.0	1.7	14.3	375.6	0.00	1.00
08/02/2026 07:00	1.5	2.2	0.0	1.7	14.4	374.7	0.00	1.00
08/02/2026 08:00	1.5	2.2	0.0	1.7	14.4	373.7	0.00	1.00
08/02/2026 09:00	1.5	2.1	0.0	1.6	14.5	373.1	0.00	1.00
08/02/2026 10:00	1.5	2.1	0.0	1.7	14.5	373.2	0.00	1.00
08/02/2026 11:00	1.5	2.2	0.0	1.7	14.5	372.3	0.00	1.00
08/02/2026 12:00	1.5	2.1	0.0	1.6	14.5	371.4	0.00	1.00
08/02/2026 13:00	1.5	2.3	0.0	1.6	14.5	400.0	0.00	1.00
08/02/2026 14:00	1.5	3.0	0.0	1.9	13.7	528.6	0.00	1.00
08/02/2026 15:00	1.5	2.9	0.0	1.8	13.7	528.1	0.00	1.00
08/02/2026 16:00	1.5	3.1	0.0	1.9	13.4	553.6	0.00	1.00
08/02/2026 17:00	1.5	3.0	0.0	1.9	13.6	536.6	0.00	1.00
08/02/2026 18:00	1.5	3.0	0.0	1.9	13.6	533.4	0.00	1.00
08/02/2026 19:00	1.5	3.0	0.0	2.1	12.7	550.6	0.00	1.00
08/02/2026 20:00	1.5	3.0	0.0	2.1	12.9	545.8	0.00	1.00
08/02/2026 21:00	1.5	3.0	0.0	2.0	13.1	543.3	0.00	1.00
08/02/2026 22:00	1.5	2.6	0.0	1.7	14.4	460.7	0.00	1.00
08/02/2026 23:00	1.5	2.5	0.0	1.7	14.4	440.6	0.00	1.00
Average/Sum#:	1.5	2.5	0.0	1.8	14.0	437.1	0.00 #	24.00 #
Minimum:	1.5	2.1	0.0	1.6	12.7	371.4	0.00	1.00
Maximum:	1.5	3.1	0.0	2.1	14.5	553.6	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/03/2026 00:00	1.5	2.1	0.0	1.7	14.4	374.5	0.00	1.00
08/03/2026 01:00	1.5	2.3	0.0	1.7	14.4	405.3	0.00	1.00
08/03/2026 02:00	1.5	2.1	0.0	1.7	14.3	373.9	0.00	1.00
08/03/2026 03:00	1.5	2.1	0.0	1.7	14.4	374.1	0.00	1.00
08/03/2026 04:00	1.5	2.4	0.0	1.7	14.5	430.7	0.00	1.00
08/03/2026 05:00	1.5	2.3	0.0	1.6	14.4	418.8	0.00	1.00
08/03/2026 06:00	1.5	2.2	0.0	1.7	14.3	375.0	0.00	1.00
08/03/2026 07:00	1.5	2.2	0.0	1.7	14.4	373.9	0.00	1.00
08/03/2026 08:00	1.5	2.2	0.0	1.7	14.4	373.2	0.00	1.00
08/03/2026 09:00	1.5	2.1	0.0	1.6	14.5	372.9	0.00	1.00
08/03/2026 10:00	1.5	2.1	0.0	1.6	14.5	372.8	0.00	1.00
08/03/2026 11:00	1.5	2.1	0.0	1.6	14.5	371.7	0.00	1.00
08/03/2026 12:00	1.5	2.2	0.0	1.6	14.5	405.3	0.00	1.00
08/03/2026 13:00	1.5	2.4	0.0	1.7	14.4	423.6	0.00	1.00
08/03/2026 14:00	1.5	3.0	0.0	1.9	13.5	543.2	0.00	1.00
08/03/2026 15:00	1.5	2.9	0.0	1.8	13.6	536.2	0.00	1.00
08/03/2026 16:00	1.5	3.3	0.0	2.0	13.0	582.0	0.00	1.00
08/03/2026 17:00	1.5	3.4	0.0	2.1	12.9	595.5	0.00	1.00
08/03/2026 18:00	1.5	3.7	0.0	2.3	11.9	665.8	0.00	1.00
08/03/2026 19:00	1.5	3.5	0.0	2.2	12.3	638.7	0.00	1.00
08/03/2026 20:00	1.5	3.4	0.0	2.1	12.7	614.2	0.00	1.00
08/03/2026 21:00	1.5	3.1	0.0	2.0	13.2	557.6	0.00	1.00
08/03/2026 22:00	1.5	2.4	0.0	1.6	14.4	431.7	0.00	1.00
08/03/2026 23:00	1.5	2.5	0.0	1.6	14.6	449.4	0.00	1.00
Average/Sum#:	1.5	2.6	0.0	1.8	13.9	460.8	0.00 #	24.00 #
Minimum:	1.5	2.1	0.0	1.6	11.9	371.7	0.00	1.00
Maximum:	1.5	3.7	0.0	2.3	14.6	665.8	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/04/2026 00:00	1.5	2.2	0.0	1.7	14.4	391.3	0.00	1.00
08/04/2026 01:00	1.5	2.1	0.0	1.7	14.4	374.5	0.00	1.00
08/04/2026 02:00	1.5	2.1	0.0	1.7	14.3	374.8	0.00	1.00
08/04/2026 03:00	1.5	2.3	0.0	1.7	14.4	394.6	0.00	1.00
08/04/2026 04:00	1.5	2.4	0.0	1.6	14.4	434.1	0.00	1.00
08/04/2026 05:00	1.5	2.3	0.0	1.6	14.4	418.5	0.00	1.00
08/04/2026 06:00	1.5	2.3	0.0	1.7	14.4	403.8	0.00	1.00
08/04/2026 07:00	1.5	2.1	0.0	1.7	14.3	374.6	0.00	1.00
08/04/2026 08:00	1.5	2.2	0.0	1.7	14.3	374.3	0.00	1.00
08/04/2026 09:00	1.5	2.1	0.0	1.7	14.3	374.2	0.00	1.00
08/04/2026 10:00	1.5	2.1	0.0	1.7	14.4	376.4	0.00	1.00
08/04/2026 11:00	1.5	2.2	0.0	1.6	14.5	395.3	0.00	1.00
08/04/2026 12:00	1.5	2.4	0.0	1.6	14.4	428.7	0.00	1.00
08/04/2026 13:00	1.5	2.6	0.0	1.7	14.5	453.3	0.00	1.00
08/04/2026 14:00	1.5	3.2	0.0	2.0	13.2	564.3	0.00	1.00
08/04/2026 15:00	1.5	3.2	0.0	2.0	13.1	576.9	0.00	1.00
08/04/2026 16:00	1.5	3.1	0.0	1.9	13.3	559.4	0.00	1.00
08/04/2026 17:00	1.4	2.9	0.0	1.9	13.2	542.0	0.00	1.00
08/04/2026 18:00	1.5	3.5	0.0	2.2	12.4	625.2	0.00	1.00
08/04/2026 19:00	1.5	2.9	0.0	1.8	13.8	525.7	0.00	1.00
08/04/2026 20:00	1.5	2.9	0.0	1.8	13.7	533.0	0.00	1.00
08/04/2026 21:00	1.5	3.0	0.0	1.9	13.6	535.2	0.00	1.00
08/04/2026 22:00	1.5	2.1	0.0	1.7	14.3	386.3	0.00	1.00
08/04/2026 23:00	1.5	2.5	0.0	1.6	14.5	447.8	0.00	1.00
Average/Sum#:	1.5	2.5	0.0	1.8	14.0	452.7	0.00 #	24.00 #
Minimum:	1.4	2.1	0.0	1.6	12.4	374.2	0.00	1.00
Maximum:	1.5	3.5	0.0	2.2	14.5	625.2	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/05/2026 00:00	1.5	2.3	0.0	1.6	14.4	422.2	0.00	1.00
08/05/2026 01:00	1.5	2.1	0.0	1.7	14.3	377.0	0.00	1.00
08/05/2026 02:00	1.5	2.1	0.0	1.7	14.3	377.3	0.00	1.00
08/05/2026 03:00	1.5	2.1	0.0	1.7	14.3	377.4	0.00	1.00
08/05/2026 04:00	1.5	2.1	0.0	1.7	14.3	383.4	0.00	1.00
08/05/2026 05:00	1.5	2.1	0.0	1.7	14.3	377.8	0.00	1.00
08/05/2026 06:00	1.5	2.2	0.0	1.7	14.3	392.9	0.00	1.00
08/05/2026 07:00	1.5	2.1	0.0	1.7	14.3	377.3	0.00	1.00
08/05/2026 08:00	1.5	2.2	0.0	1.7	14.3	377.1	0.00	1.00
08/05/2026 09:00	1.5	2.1	0.0	1.7	14.3	376.7	0.00	1.00
08/05/2026 10:00	1.5	2.2	0.0	1.7	14.4	376.1	0.00	1.00
08/05/2026 11:00	1.5	2.2	0.0	1.7	14.4	375.5	0.00	1.00
08/05/2026 12:00	1.5	2.3	0.0	1.6	14.5	391.9	0.00	1.00
08/05/2026 13:00	1.5	2.3	0.0	1.7	14.4	407.4	0.00	1.00
08/05/2026 14:00	1.5	2.9	0.0	1.8	13.9	523.4	0.00	1.00
08/05/2026 15:00	1.5	3.0	0.0	1.8	13.7	533.1	0.00	1.00
08/05/2026 16:00	1.5	3.2	0.0	2.0	13.2	578.0	0.00	1.00
08/05/2026 17:00	1.5	3.1	0.0	1.9	13.4	559.6	0.00	1.00
08/05/2026 18:00	1.5	3.0	0.0	1.8	13.8	530.2	0.00	1.00
08/05/2026 19:00	1.5	3.0	0.0	1.9	13.6	535.5	0.00	1.00
08/05/2026 20:00	1.5	3.0	0.0	1.9	13.5	538.6	0.00	1.00
08/05/2026 21:00	1.5	2.9	0.0	1.8	13.7	531.0	0.00	1.00
08/05/2026 22:00	1.5	2.5	0.0	1.6	14.5	457.8	0.00	1.00
08/05/2026 23:00	1.5	2.4	0.0	1.6	14.5	441.4	0.00	1.00
Average/Sum#:	1.5	2.5	0.0	1.7	14.1	442.4	0.00 #	24.00 #
Minimum:	1.5	2.1	0.0	1.6	13.2	375.5	0.00	1.00
Maximum:	1.5	3.2	0.0	2.0	14.5	578.0	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/06/2026 00:00	1.5	2.2	0.0	1.7	14.4	390.1	0.00	1.00
08/06/2026 01:00	1.5	2.1	0.0	1.7	14.4	375.6	0.00	1.00
08/06/2026 02:00	1.5	2.1	0.0	1.7	14.3	375.7	0.00	1.00
08/06/2026 03:00	1.5	2.1	0.0	1.7	14.3	375.9	0.00	1.00
08/06/2026 04:00	1.5	2.1	0.0	1.7	14.3	380.4	0.00	1.00
08/06/2026 05:00	1.5	2.2	0.0	1.7	14.3	398.5	0.00	1.00
08/06/2026 06:00	1.5	2.1	0.0	1.7	14.3	376.7	0.00	1.00
08/06/2026 07:00	1.5	2.1	0.0	1.7	14.3	376.2	0.00	1.00
08/06/2026 08:00	1.5	2.2	0.0	1.7	14.3	375.9	0.00	1.00
08/06/2026 09:00	1.5	2.1	0.0	1.7	14.4	375.4	0.00	1.00
08/06/2026 10:00	1.5	2.1	0.0	1.7	14.4	374.8	0.00	1.00
08/06/2026 11:00	1.5	2.2	0.0	1.7	14.4	374.0	0.00	1.00
08/06/2026 12:00	1.5	2.2	0.0	1.6	14.5	373.6	0.00	1.00
08/06/2026 13:00	1.5	2.3	0.0	1.6	14.5	393.1	0.00	1.00
08/06/2026 14:00	1.5	3.0	0.0	2.1	12.8	539.9	0.00	1.00
08/06/2026 15:00	1.5	3.1	0.0	2.2	12.5	552.8	0.00	1.00
08/06/2026 16:00	1.5	3.2	0.0	2.2	12.4	572.3	0.00	1.00
08/06/2026 17:00	1.5	3.6	0.0	2.2	12.3	644.5	0.00	1.00
08/06/2026 18:00	1.5	3.4	0.0	2.1	12.7	621.4	0.00	1.00
08/06/2026 19:00	1.5	3.0	0.0	1.8	13.8	534.2	0.00	1.00
08/06/2026 20:00	1.5	3.0	0.0	1.9	13.4	544.3	0.00	1.00
08/06/2026 21:00	1.5	3.1	0.0	2.0	13.2	566.3	0.00	1.00
08/06/2026 22:00	1.5	2.5	0.0	1.6	14.6	458.0	0.00	1.00
08/06/2026 23:00	1.5	2.5	0.0	1.6	14.5	456.7	0.00	1.00
Average/Sum#:	1.5	2.5	0.0	1.8	13.9	450.3	0.00 #	24.00 #
Minimum:	1.5	2.1	0.0	1.6	12.3	373.6	0.00	1.00
Maximum:	1.5	3.6	0.0	2.2	14.6	644.5	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/07/2026 00:00	1.5	2.5	0.0	1.6	14.5	456.1	0.00	1.00
08/07/2026 01:00	1.5	2.5	0.0	1.6	14.5	456.9	0.00	1.00
08/07/2026 02:00	1.5	2.5	0.0	1.6	14.5	457.0	0.00	1.00
08/07/2026 03:00	1.5	2.1	0.0	1.7	14.3	401.0	0.00	1.00
08/07/2026 04:00	1.5	2.5	0.0	1.7	14.5	453.6	0.00	1.00
08/07/2026 05:00	1.5	2.5	0.0	1.7	14.5	456.6	0.00	1.00
08/07/2026 06:00	1.5	2.2	0.0	1.7	14.3	398.2	0.00	1.00
08/07/2026 07:00	1.5	2.2	0.0	1.7	14.3	376.8	0.00	1.00
08/07/2026 08:00	1.5	2.2	0.0	1.7	14.4	376.1	0.00	1.00
08/07/2026 09:00	1.5	2.1	0.0	1.7	14.4	375.6	0.00	1.00
08/07/2026 10:00	1.5	2.1	0.0	1.6	14.4	374.9	0.00	1.00
08/07/2026 11:00	1.5	2.3	0.0	1.6	14.5	405.0	0.00	1.00
08/07/2026 12:00	1.5	2.2	0.0	1.6	14.5	387.1	0.00	1.00
08/07/2026 13:00	1.5	2.5	0.0	1.6	14.5	437.6	0.00	1.00
08/07/2026 14:00	1.5	3.1	0.0	2.0	13.2	546.4	0.00	1.00
08/07/2026 15:00	1.5	3.1	0.0	2.2	12.3	559.7	0.00	1.00
08/07/2026 16:00	1.5	3.1	0.0	2.2	12.4	562.9	0.00	1.00
08/07/2026 17:00	1.5	3.2	0.0	2.0	13.2	574.9	0.00	1.00
08/07/2026 18:00	1.5	3.5	0.0	2.2	12.5	633.0	0.00	1.00
08/07/2026 19:00	1.5	3.1	0.0	1.9	13.4	560.6	0.00	1.00
08/07/2026 20:00	1.5	3.0	0.0	1.9	13.7	543.7	0.00	1.00
08/07/2026 21:00	1.5	3.0	0.0	1.9	13.5	545.2	0.00	1.00
08/07/2026 22:00	1.5	2.5	0.0	1.6	14.5	460.8	0.00	1.00
08/07/2026 23:00	1.5	2.6	0.0	1.6	14.6	469.9	0.00	1.00
Average/Sum#:	1.5	2.6	0.0	1.8	14.0	469.6	0.00 #	24.00 #
Minimum:	1.5	2.1	0.0	1.6	12.3	374.9	0.00	1.00
Maximum:	1.5	3.5	0.0	2.2	14.6	633.0	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/08/2026 00:00	1.5	2.6	0.0	1.6	14.6	469.9	0.00	1.00
08/08/2026 01:00	1.5	2.2	0.0	1.6	14.4	411.0	0.00	1.00
08/08/2026 02:00	1.5	2.1	0.0	1.7	14.3	378.4	0.00	1.00
08/08/2026 03:00	1.5	2.1	0.0	1.7	14.3	379.6	0.00	1.00
08/08/2026 04:00	1.5	2.5	0.0	1.7	14.5	453.2	0.00	1.00
08/08/2026 05:00	1.5	2.3	0.0	1.6	14.4	427.4	0.00	1.00
08/08/2026 06:00	1.5	2.1	0.0	1.7	14.3	379.1	0.00	1.00
08/08/2026 07:00	1.5	2.2	0.0	1.7	14.3	378.6	0.00	1.00
08/08/2026 08:00	1.5	2.2	0.0	1.7	14.3	379.5	0.00	1.00
08/08/2026 09:00	1.5	2.2	0.0	1.7	14.4	379.9	0.00	1.00
08/08/2026 10:00	1.5	2.2	0.0	1.7	14.4	379.0	0.00	1.00
08/08/2026 11:00	1.5	2.2	0.0	1.6	14.4	377.9	0.00	1.00
08/08/2026 12:00	1.5	2.2	0.0	1.6	14.5	376.8	0.00	1.00
08/08/2026 13:00	1.5	2.3	0.0	1.7	14.3	398.6	0.00	1.00
08/08/2026 14:00	1.5	3.2	0.0	2.2	12.4	563.1	0.00	1.00
08/08/2026 15:00	1.5	3.0	0.0	2.1	12.7	553.2	0.00	1.00
08/08/2026 16:00	1.5	3.0	0.0	1.8	13.6	540.2	0.00	1.00
08/08/2026 17:00	1.5	3.1	0.0	1.9	13.5	548.6	0.00	1.00
08/08/2026 18:00	1.5	3.0	0.0	1.9	13.6	540.5	0.00	1.00
08/08/2026 19:00	1.5	3.0	0.0	1.9	13.4	538.1	0.00	1.00
08/08/2026 20:00	1.5	3.0	0.0	1.9	13.5	536.1	0.00	1.00
08/08/2026 21:00	1.5	3.0	0.0	1.9	13.6	535.3	0.00	1.00
08/08/2026 22:00	1.5	2.6	0.0	1.6	14.6	460.1	0.00	1.00
08/08/2026 23:00	1.5	2.4	0.0	1.6	14.5	430.3	0.00	1.00
Average/Sum#:	1.5	2.5	0.0	1.8	14.0	450.6	0.00 #	24.00 #
Minimum:	1.5	2.1	0.0	1.6	12.4	376.8	0.00	1.00
Maximum:	1.5	3.2	0.0	2.2	14.6	563.1	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/09/2026 00:00	1.5	2.1	0.0	1.7	14.4	376.9	0.00	1.00
08/09/2026 01:00	1.5	2.1	0.0	1.7	14.3	377.3	0.00	1.00
08/09/2026 02:00	1.5	2.1	0.0	1.7	14.3	377.6	0.00	1.00
08/09/2026 03:00	1.5	2.1	0.0	1.7	14.3	377.9	0.00	1.00
08/09/2026 04:00	1.5	2.1	0.0	1.7	14.3	381.6	0.00	1.00
08/09/2026 05:00	1.5	2.3	0.0	1.6	14.4	425.4	0.00	1.00
08/09/2026 06:00	1.5	2.1	0.0	1.7	14.3	377.9	0.00	1.00
08/09/2026 07:00	1.5	2.2	0.0	1.7	14.3	377.6	0.00	1.00
08/09/2026 08:00	1.5	2.2	0.0	1.7	14.4	376.8	0.00	1.00
08/09/2026 09:00	1.5	2.1	0.0	1.6	14.4	376.1	0.00	1.00
08/09/2026 10:00	1.5	2.1	0.0	1.7	14.5	375.8	0.00	1.00
08/09/2026 11:00	1.5	2.2	0.0	1.6	14.5	375.0	0.00	1.00
08/09/2026 12:00	1.5	2.2	0.0	1.6	14.5	384.1	0.00	1.00
08/09/2026 13:00	1.5	2.5	0.0	1.6	14.5	445.9	0.00	1.00
08/09/2026 14:00	1.5	3.1	0.0	1.9	13.3	543.3	0.00	1.00
08/09/2026 15:00	1.5	3.5	0.0	2.2	12.4	633.0	0.00	1.00
08/09/2026 16:00	1.5	3.6	0.0	2.2	12.2	642.4	0.00	1.00
08/09/2026 17:00	1.5	3.5	0.0	2.2	12.5	622.2	0.00	1.00
08/09/2026 18:00	1.5	3.5	0.0	2.2	12.3	638.9	0.00	1.00
08/09/2026 19:00	1.5	2.9	0.0	1.8	13.6	537.2	0.00	1.00
08/09/2026 20:00	1.5	3.0	0.0	2.0	13.2	545.3	0.00	1.00
08/09/2026 21:00	1.5	2.9	0.0	1.9	13.5	536.0	0.00	1.00
08/09/2026 22:00	1.5	2.1	0.0	1.6	14.4	389.8	0.00	1.00
08/09/2026 23:00	1.5	2.1	0.0	1.7	14.4	375.8	0.00	1.00
Average/Sum#:	1.5	2.5	0.0	1.8	13.9	452.9	0.00 #	24.00 #
Minimum:	1.5	2.1	0.0	1.6	12.2	375.0	0.00	1.00
Maximum:	1.5	3.6	0.0	2.2	14.5	642.4	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/10/2026 00:00	1.5	2.1	0.0	1.7	14.3	376.6	0.00	1.00
08/10/2026 01:00	1.5	2.1	0.0	1.7	14.3	376.9	0.00	1.00
08/10/2026 02:00	1.5	2.1	0.0	1.7	14.3	377.0	0.00	1.00
08/10/2026 03:00	1.5	2.1	0.0	1.7	14.3	377.2	0.00	1.00
08/10/2026 04:00	1.5	2.3	0.0	1.7	14.4	418.7	0.00	1.00
08/10/2026 05:00	1.5	2.1	0.0	1.7	14.3	377.9	0.00	1.00
08/10/2026 06:00	1.5	2.3	0.0	1.7	14.4	413.5	0.00	1.00
08/10/2026 07:00	1.5	2.2	0.0	1.7	14.3	377.4	0.00	1.00
08/10/2026 08:00	1.5	2.2	0.0	1.7	14.4	376.7	0.00	1.00
08/10/2026 09:00	1.5	2.1	0.0	1.7	14.4	376.3	0.00	1.00
08/10/2026 10:00	1.5	2.1	0.0	1.7	14.4	376.2	0.00	1.00
08/10/2026 11:00	1.5	2.2	0.0	1.6	14.5	375.6	0.00	1.00
08/10/2026 12:00	1.5	2.3	0.0	1.6	14.5	395.0	0.00	1.00
08/10/2026 13:00	1.5	2.4	0.0	1.6	14.4	430.8	0.00	1.00
08/10/2026 14:00	1.5	2.4	0.0	1.7	14.4	420.1	0.00	1.00
08/10/2026 15:00	1.5	3.0	0.0	1.8	13.7	540.6	0.00	1.00
08/10/2026 16:00	1.5	3.5	0.0	2.1	12.8	609.4	0.00	1.00
08/10/2026 17:00	1.5	3.5	0.0	2.2	12.5	638.7	0.00	1.00
08/10/2026 18:00	1.5	3.4	0.0	2.0	12.7	620.0	0.00	1.00
08/10/2026 19:00	1.5	3.2	0.0	1.9	13.3	572.6	0.00	1.00
08/10/2026 20:00	1.5	3.0	0.0	1.8	13.8	541.7	0.00	1.00
08/10/2026 21:00	1.5	3.2	0.0	1.9	13.5	567.9	0.00	1.00
08/10/2026 22:00	1.5	2.5	0.0	1.6	14.5	460.1	0.00	1.00
08/10/2026 23:00	1.5	2.2	0.0	1.6	14.4	399.8	0.00	1.00
Average/Sum#:	1.5	2.5	0.0	1.8	14.0	449.9	0.00 #	24.00 #
Minimum:	1.5	2.1	0.0	1.6	12.5	375.6	0.00	1.00
Maximum:	1.5	3.5	0.0	2.2	14.5	638.7	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/11/2026 00:00	1.5	2.2	0.0	1.7	14.4	406.6	0.00	1.00
08/11/2026 01:00	1.5	2.1	0.0	1.7	14.3	378.2	0.00	1.00
08/11/2026 02:00	1.5	2.1	0.0	1.7	14.3	378.2	0.00	1.00
08/11/2026 03:00	1.5	2.1	0.0	1.7	14.3	378.7	0.00	1.00
08/11/2026 04:00	1.5	2.1	0.0	1.7	14.3	382.8	0.00	1.00
08/11/2026 05:00	1.5	2.3	0.0	1.7	14.3	406.9	0.00	1.00
08/11/2026 06:00	1.5	2.4	0.0	1.7	14.4	422.7	0.00	1.00
08/11/2026 07:00	1.5	2.2	0.0	1.7	14.3	378.6	0.00	1.00
08/11/2026 08:00	1.5	2.2	0.0	1.7	14.4	378.1	0.00	1.00
08/11/2026 09:00	1.5	2.1	0.0	1.7	14.4	377.9	0.00	1.00
08/11/2026 10:00	1.5	2.2	0.0	1.7	14.4	388.2	0.00	1.00
08/11/2026 11:00	1.5	2.6	0.0	1.6	14.6	452.9	0.00	1.00
08/11/2026 12:00	1.5	2.7	0.0	1.6	14.5	473.0	0.00	1.00
08/11/2026 13:00	1.5	3.1	0.0	1.9	13.5	564.9	0.00	1.00
08/11/2026 14:00	1.5	3.1	0.0	1.9	13.7	550.4	0.00	1.00
08/11/2026 15:00	1.5	3.0	0.0	1.8	13.7	546.1	0.00	1.00
08/11/2026 16:00	1.5	3.4	0.0	2.1	12.8	617.4	0.00	1.00
08/11/2026 17:00	1.5	3.7	0.0	2.2	12.3	657.5	0.00	1.00
08/11/2026 18:00	1.5	3.4	0.0	2.0	12.8	620.0	0.00	1.00
08/11/2026 19:00	1.5	3.4	0.0	2.1	12.8	617.3	0.00	1.00
08/11/2026 20:00	1.5	3.3	0.0	2.0	13.3	583.5	0.00	1.00
08/11/2026 21:00	1.5	2.5	0.0	1.6	14.5	460.3	0.00	1.00
08/11/2026 22:00	1.5	2.3	0.0	1.6	14.5	430.2	0.00	1.00
08/11/2026 23:00	1.5	2.2	0.0	1.7	14.4	386.0	0.00	1.00
Average/Sum#:	1.5	2.6	0.0	1.8	14.0	468.2	0.00 #	24.00 #
Minimum:	1.5	2.1	0.0	1.6	12.3	377.9	0.00	1.00
Maximum:	1.5	3.7	0.0	2.2	14.6	657.5	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/12/2026 00:00	1.5	2.1	0.0	1.7	14.3	377.5	0.00	1.00
08/12/2026 01:00	1.5	2.1	0.0	1.7	14.3	377.8	0.00	1.00
08/12/2026 02:00	1.5	2.1	0.0	1.7	14.3	377.9	0.00	1.00
08/12/2026 03:00	1.5	2.1	0.0	1.7	14.3	378.2	0.00	1.00
08/12/2026 04:00	1.5	2.3	0.0	1.7	14.4	415.3	0.00	1.00
08/12/2026 05:00	1.5	2.5	0.0	1.6	14.4	449.3	0.00	1.00
08/12/2026 06:00	1.5	2.1	0.0	1.7	14.3	377.7	0.00	1.00
08/12/2026 07:00	1.5	2.1	0.0	1.7	14.3	378.1	0.00	1.00
08/12/2026 08:00	1.5	2.1	0.0	1.7	14.3	377.6	0.00	1.00
08/12/2026 09:00	1.5	2.1	0.0	1.7	14.3	377.1	0.00	1.00
08/12/2026 10:00	1.5	2.1	0.0	1.7	14.4	376.5	0.00	1.00
08/12/2026 11:00	1.5	2.2	0.0	1.7	14.4	376.1	0.00	1.00
08/12/2026 12:00	1.5	2.2	0.0	1.7	14.4	379.4	0.00	1.00
08/12/2026 13:00	1.5	3.0	0.0	1.8	13.9	527.2	0.00	1.00
08/12/2026 14:00	1.5	2.9	0.0	1.8	13.9	526.9	0.00	1.00
08/12/2026 15:00	1.5	2.9	0.0	1.8	13.9	526.2	0.00	1.00
08/12/2026 16:00	1.5	2.9	0.0	1.8	13.9	526.2	0.00	1.00
08/12/2026 17:00	1.5	2.9	0.0	1.8	14.0	525.0	0.00	1.00
08/12/2026 18:00	1.5	3.0	0.0	1.8	14.0	524.0	0.00	1.00
08/12/2026 19:00	1.5	2.9	0.0	1.7	14.1	521.7	0.00	1.00
08/12/2026 20:00	1.5	2.9	0.0	1.8	14.0	522.7	0.00	1.00
08/12/2026 21:00	1.5	2.1	0.0	1.6	14.4	394.4	0.00	1.00
08/12/2026 22:00	1.5	2.1	0.0	1.7	14.3	376.7	0.00	1.00
08/12/2026 23:00	1.5	2.1	0.0	1.7	14.3	376.9	0.00	1.00
Average/Sum#:	1.5	2.4	0.0	1.7	14.2	431.9	0.00 #	24.00 #
Minimum:	1.5	2.1	0.0	1.6	13.9	376.1	0.00	1.00
Maximum:	1.5	3.0	0.0	1.8	14.4	527.2	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/13/2026 00:00	1.5	2.1	0.0	1.7	14.3	377.1	0.00	1.00
08/13/2026 01:00	1.5	2.1	0.0	1.7	14.3	377.5	0.00	1.00
08/13/2026 02:00	1.5	2.1	0.0	1.7	14.3	378.1	0.00	1.00
08/13/2026 03:00	1.5	2.1	0.0	1.7	14.3	378.6	0.00	1.00
08/13/2026 04:00	1.5	2.1	0.0	1.7	14.3	378.8	0.00	1.00
08/13/2026 05:00	1.5	2.1	0.0	1.7	14.2	379.3	0.00	1.00
08/13/2026 06:00	1.5	2.1	0.0	1.7	14.3	379.2	0.00	1.00
08/13/2026 07:00	1.5	2.1	0.0	1.7	14.3	378.8	0.00	1.00
08/13/2026 08:00	1.5	2.2	0.0	1.7	14.3	378.7	0.00	1.00
08/13/2026 09:00	1.5	2.1	0.0	1.7	14.3	378.3	0.00	1.00
08/13/2026 10:00	1.5	2.1	0.0	1.7	14.3	377.6	0.00	1.00
08/13/2026 11:00	1.5	2.2	0.0	1.7	14.3	377.0	0.00	1.00
08/13/2026 12:00	1.5	2.4	0.0	1.7	14.4	404.6	0.00	1.00
08/13/2026 13:00	1.5	2.9	0.0	1.8	13.9	526.6	0.00	1.00
08/13/2026 14:00	1.5	2.9	0.0	1.8	13.8	528.1	0.00	1.00
08/13/2026 15:00	1.5	2.9	0.0	1.8	13.8	527.3	0.00	1.00
08/13/2026 16:00	1.5	2.9	0.0	1.8	13.9	525.3	0.00	1.00
08/13/2026 17:00	1.5	2.9	0.0	1.8	13.9	523.7	0.00	1.00
08/13/2026 18:00	1.5	2.9	0.0	1.8	14.0	521.5	0.00	1.00
08/13/2026 19:00	1.5	2.1	0.0	1.7	14.3	382.2	0.00	1.00
08/13/2026 20:00	1.5	2.1	0.0	1.7	14.3	378.1	0.00	1.00
08/13/2026 21:00	1.5	2.1	0.0	1.7	14.3	378.3	0.00	1.00
08/13/2026 22:00	1.5	2.1	0.0	1.7	14.3	378.5	0.00	1.00
08/13/2026 23:00	1.5	2.1	0.0	1.7	14.3	378.5	0.00	1.00
Average/Sum#:	1.5	2.3	0.0	1.7	14.2	416.3	0.00 #	24.00 #
Minimum:	1.5	2.1	0.0	1.7	13.8	377.0	0.00	1.00
Maximum:	1.5	2.9	0.0	1.8	14.4	528.1	0.00	1.00
%SI	0.00	0.00	12.50	0.00	0.00	0.00	0.00	0.00

NOx Daily Summary

CT2

From: 07/01/2026 00:00 **To:** 09/30/2026 23:59 **Facility Name:** ROSEVILLE ENERGY

Generated: 10/12/2026 15:47 **Location:** Roseville, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> 2	> 5.1	> 37.1					
	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx_Norm, LbPerHr 1 Hour(s)	Unit CT2 NOx_SUSD, LbPerHr 1 Hour(s)	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 SUSD, Hr 1 Hour(s)	Unit CT2 OperatingTime, Hr 1 Hour(s)
08/14/2026 00:00	1.5	2.1	0.0	1.7	14.2	378.9	0.00	1.00
08/14/2026 01:00	1.5	2.1	0.0	1.7	14.2	379.2	0.00	1.00
08/14/2026 02:00	1.5	2.1	0.0	1.7	14.2	379.2	0.00	1.00
08/14/2026 03:00	1.5	2.1	0.0	1.7	14.2	379.1	0.00	1.00
08/14/2026 04:00	1.5	2.1	0.0	1.7	14.2	379.2	0.00	1.00
08/14/2026 05:00	1.5	2.1	0.0	1.7	14.2	382.6	0.00	1.00
08/14/2026 06:00	1.5	2.2	0.0	1.7	14.3	394.6	0.00	1.00
08/14/2026 07:00	1.5	2.1	0.0	1.7	14.3	379.0	0.00	1.00
08/14/2026 08:00	1.5	2.1	0.0	1.7	14.3	379.1	0.00	1.00
08/14/2026 09:00	1.5	2.1	0.0	1.7	14.3	378.7	0.00	1.00
08/14/2026 10:00	1.5	2.1	0.0	1.7	14.3	378.4	0.00	1.00
08/14/2026 11:00	1.5	2.2	0.0	1.7	14.3	378.3	0.00	1.00
08/14/2026 12:00	1.5	2.2	0.0	1.7	14.3	377.9	0.00	1.00
08/14/2026 13:00	1.5	2.2	0.0	1.7	14.4	377.6	0.00	1.00
08/14/2026 14:00	1.5	2.1	0.0	1.7	14.4	377.3	0.00	1.00
08/14/2026 15:00	1.5	2.1	0.0	1.7	14.4	377.3	0.00	1.00
08/14/2026 16:00	1.5	2.1	0.0	1.7	14.4	377.2	0.00	1.00
08/14/2026 17:00	1.5	2.3	0.0	1.7	14.4	396.0	0.00	1.00
08/14/2026 18:00	1.5	2.1	0.0	1.7	14.4	379.8	0.00	1.00
08/14/2026 19:00	1.5	2.1	0.0	1.7	14.3	378.4	0.00	1.00
08/14/2026 20:00	1.5	2.1	0.0	1.7	14.3	379.3	0.00	1.00
08/14/2026 21:00	1.5	2.1	0.0	1.7	14.3	379.7	0.00	1.00
08/14/2026 22:00	1.5	2.1	0.0	1.7	14.3	380.2	0.00	1.00
08/14/2026 23:00	1.5	2.1	0.0	1.7	14.2	380.4	0.00	1.00
Average/Sum#:	1.5	2.1	0.0	1.7	14.3	380.3	0.00 #	24.00 #
Minimum:	1.5	2.1	0.0	1.7	14.2	377.2	0.00	1.00
Maximum:	1.5	2.3	0.0	1.7	14.4	396.0	0.00	1.00
%SI	0.00	0.00	4.17	0.00	0.00	0.00	0.00	0.00