

DOCKETED

Docket Number:	93-AFC-03C
Project Title:	Compliance - Application for Certification for SMUD's Campbell Soup Cogeneration Project
TN #:	210275
Document Title:	Sacramento Power Authority's Campbell Cogeneration Project - Record of Conversation - Sodium Hypochlorite Discussion 20160210
Description:	N/A
Filer:	Patty Paul
Organization:	California Energy Commission
Submitter Role:	Commission Staff
Submission Date:	2/11/2016 2:52:24 PM
Docketed Date:	2/11/2016



Siting, Transmission, and Environmental Protection Division

FILE: 93-AFC-3C

PROJECT TITLE: SPA Campbell Soup

<input checked="" type="checkbox"/> Telephone		<input type="checkbox"/> Meeting Location:	
NAME:	Brett Fooks (916-654-5593)	DATE:	02/10/16
		TIME:	13:30
WITH:	John Carrier – Project Manager C2HMHill, Geoff Lesh – CEC, Karen Parker – C2HMHill, Joe Brown, Pedro Juarez – SPA Plant		
SUBJECT:	: Secondary Containment for the new Sodium Hypochlorite Tank		

Staff held a conference call with the petitioner to discuss and clarify the following items:

- Staff asked the petitioner to clarify if the new sodium hypochlorite tank would have secondary containment.
- The petitioner agreed that the new tank would have secondary containment either via being a double walled tank or modifications to the existing secondary containment if the purchased tank was not double walled. The modifications to the existing secondary tank would depend on the size of the single walled tank purchased. In any case, modifications to secondary containment would be made to provide for the entirety of the new total of on-site sodium hypochlorite storage volumes.

cc:	Signed: <SIGNED>
------------	-------------------------------

CALIFORNIA ENERGY COMMISSION

REPORT OF CONVERSATION Page 2 of 2



	Name: Brett Fooks
--	--------------------------