

DOCKETED

Docket Number:	15-AFC-01
Project Title:	Puente Power Project
TN #:	204667
Document Title:	Letter to Mr. Thomas A. DiCiolli re: Incomplete Application Notification, dated April 15, 2015
Description:	N/A
Filer:	Alicia Campos
Organization:	Ventura County Air Pollution Control District
Submitter Role:	Public Agency
Submission Date:	5/20/2015 8:11:09 AM
Docketed Date:	5/20/2015



Ventura County
Air Pollution
Control District

669 County Square Drive
Ventura, California 93003

tel 805/645-1400
fax 805/645-1444
www.vcapcd.org

Michael Villegas
Air Pollution Control Officer

April 15, 2015

Mr. Thomas A. DiCiulli
NRG Energy Center Oxnard LLC
5790 Fleet Street, Suite 200
Carlsbad, CA 92008

INCOMPLETE APPLICATION NOTIFICATION

Authority to Construct Application No. 00013-370

Install New Gas Turbine: Puente Power Project
 393 North Harbor Blvd.
 Oxnard, CA 93035

The Ventura County Air Pollution Control District (VCAPCD) has received your application for a new GE H-Class natural gas fired simple cycle gas turbine engine and a new emergency diesel generator engine at the existing Mandalay Generating Station at 393 North Harbor Blvd. in Oxnard. Based on our preliminary review, the application has been determined to be incomplete.

Below is a description of the information that you need to provide us in order to help complete your application. Please respond to the following issues:

1. Pursuant to Rule 26.6.C and Rule 26.2.B.4, please provide monthly fuel use data for 2010 through 2014 for the following existing equipment in order to calculate the quarterly profile for the actual emission reductions:
 - Each Steam Generator No. 1 and No. 2 at the Mandalay Generating Station
 - The 201 BHP emergency diesel generator engine
 - The 154 BHP emergency diesel firewater pump engine
2. Your project will require offsets pursuant to Rule 26.2.B. Please identify the specific offsets proposed for this project and identify if they will be "surplus at the time of use" as defined in Rule 26.11.
3. As required by Rule 26.2.D, please provide a certification of statewide compliance.
4. As required by Rule 26.2.E, please provide the analysis of alternatives for the project.
5. You have proposed that the installation of the new GE H-Class natural gas fired simple cycle gas turbine engine meets the definition of "replacement emissions unit" in Rule 26.1. In order to better understand your proposal, please compare and contrast the

electrical functions of the new gas turbine engine, existing Steam Generator Nos. 1 and 2, existing Turbine Peaking Unit No. 3, and the existing nearby McGrath Beach Turbine Peaking Unit owned and operated by Southern California Edison.


Please review these items carefully and mail the requested information to:

Ventura County Air Pollution Control District
669 County Square Drive, 2nd Floor
Ventura, CA 93003
Attention: Kerby E. Zozula

Please be aware that we cannot complete the processing of your application until we receive the requested information. On further review of your application, we may determine that more information is needed to complete it.

If you have any questions, or wish to discuss this matter in further detail, please call me at 805/645-1421.

Sincerely,



Kerby E. Zozula, Manager
Engineering Division

c: George L. Piantka
NRG Energy Center Oxnard LLC
5790 Fleet Street, Suite 200
Carlsbad, CA 92008

SJVAPCD