

## DOCKETED

|                         |  |
|-------------------------|--|
| <b>Docket Number:</b>   | 15-AFC-01  |
| <b>Project Title:</b>   | Puente Power Project   |
| <b>TN #:</b>            | 206056   |
| <b>Document Title:</b>  | Ventura County Air Pollution Control District's Additional Information Request |
| <b>Description:</b>     | N/A  |
| <b>Filer:</b>           | Paul Kihm  |
| <b>Organization:</b>    | Latham & Watkins LLP   |
| <b>Submitter Role:</b>  | Applicant Representative   |
| <b>Submission Date:</b> | 9/10/2015 2:37:59 PM   |
| <b>Docketed Date:</b>   | 9/10/2015  |



Ventura County  
Air Pollution  
Control District

669 County Square Drive  
Ventura, California 93003

tel 805/645-1400  
fax 805/645-1444  
www.vcapcd.org

**Michael Villegas**  
Air Pollution Control Officer

September 3, 2015

Mr. Thomas A. Di Ciolli  
NRG Energy Center Oxnard LLC  
5790 Fleet Street, Suite 200  
Carlsbad, CA 92008

Subject: Additional Information Request - Application for Authority to Construct No. 00013-370  
Install New Gas Turbine - Puente Power Project

Dear Mr. Di Ciolli:

The Ventura County Air Pollution Control District (VCAPCD) received your application for Authority to Construct No. 00013-370 on March 26, 2015, which was deemed complete on May 28, 2015. This permit application is for a new GE H-Class natural gas fired simple cycle gas turbine engine and a new emergency diesel generator engine at the existing Mandalay Generating Station at 393 North Harbor Blvd. in Oxnard, California.

Pursuant to Section E of Rule 26.9, "New Source Review - Power Plants", the VCAPCD may request additional information necessary for the completion of the Authority to Construct and Determination of Compliance review.

On August 3, 2015, EPA set standards to limit carbon dioxide (CO<sub>2</sub>) emissions from new power plants. These standards are included in 40 CFR Part 60, Subpart TTTT, "Standards of Performance for Greenhouse Gas Emissions from New, Modified, and Reconstructed Stationary Sources: Electric Utility Generating Units". Please provide a detailed explanation of how the Puente Power Project will comply with this new EPA regulation. In this submittal, please include the "design efficiency" and "potential electric output" of the Puente Power Project's new gas turbine.

If you have any questions regarding your Authority to Construct application, please call me at 805/645-1421.

Sincerely,

A handwritten signature in blue ink, appearing to read "K. Zozula", written over the word "Sincerely".

Kerby E. Zozula, Manager  
Engineering Division

c: George L. Piantka NRG Energy Center Oxnard LLC  
5790 Fleet Street, Suite 200 Carlsbad, CA 92008

SJVAPCD (via email)

Complete -Addl Info Request-00013-370.doc