


## DOCKETED

|                         |  |
|-------------------------|--|
| <b>Docket Number:</b>   | 15-AFC-01  |
| <b>Project Title:</b>   | Puente Power Project                             |
| <b>TN #:</b>            | 210893   |
| <b>Document Title:</b>  | Letter Regarding Enclosed NOx ERC Summary Tables |
| <b>Description:</b>     | N/A  |
| <b>Filer:</b>           | Paul Kihm  |
| <b>Organization:</b>    | Latham & Watkins LLP                             |
| <b>Submitter Role:</b>  | Applicant Representative                         |
| <b>Submission Date:</b> | 3/29/2016 4:41:22 PM                             |
| <b>Docketed Date:</b>   | 3/29/2016  |



**NRG Energy Center Oxnard LLC**  
5790 Fleet Street, Suite 200  
Carlsbad, CA 92008  
Phone: 760-710-2156  
Fax: 760-710-2158

March 29, 2016

Kerby E. Zozula  
Manager, Engineering Division  
Ventura County Air Pollution Control District  
669 County Square Drive, 2<sup>nd</sup> Floor  
Ventura, CA 93003

**Subject:** Application for an Authority to Construct/Determination of Compliance for the Proposed Puente Power Project (ATC No. 00013-370)

Dear Mr. Zozula:

The Puente Power Project (P3 or project) Application for an Authority to Construct (ATC)/Determination of Compliance (DOC) was submitted to the Ventura County Air Pollution Control District (VCAPCD) on March 19, 2015, and was accepted as complete on May 28, 2015. The project includes the installation of a new simple-cycle GE 7HA.01 natural gas fired combustion turbine generator (CTG). As discussed in the ATC/DOC application package, the P3 triggers the VCAPCD New Source Review (NSR) emission offset requirements for NO<sub>x</sub> emissions, and the Applicant has obtained a sufficient amount of NO<sub>x</sub> emission reduction credits (ERCs) from Southern California Edison (SCE) to cover this NO<sub>x</sub> ERC requirement.

VCAPCD Rule 26.6(F) requires that the quarterly operating profiles of the P3 be compared to the quarterly operating profiles of the SCE NO<sub>x</sub> ERCs to ensure that the minimum 80% total required by Rule 26.6(F) is achieved. The P3 is expected to be a peaking facility that will be dispatched and used only when needed for grid support requirements. Therefore, it is difficult to predict the expected number of hours the plant will actually operate. Because the P3 will replace many of the grid support activities currently being provided by Mandalay Generating Station (MGS) Units 1 and 2, the Applicant believes the quarterly operating profiles for the P3 will be similar to quarterly profiles for MGS Units 1 and 2. In the enclosed summary tables, the Applicant sets the P3 quarterly operating profiles equal to the three-year average quarterly operating profiles for MGS Units 1 and 2. This analysis is based on the actual gross electrical output for MGS Units 1 and 2. As shown in these tables, the expected quarterly operating profiles for the P3 comply with the 80% total required by Rule 26.6(F).

If you have any questions or comments, please do not hesitate to contact me at (760) 710-2156.

Sincerely,

A handwritten signature in cursive script, appearing to read "George L. Piantka".

George L. Piantka, PE  
Sr. Director, Regulatory Environmental Services  
NRG Energy, Inc.

Enclosures (Tables 1 and 2)

cc: CEC Dockets  
Leonard Scandura, SJVAPCD  
Michael J. Carroll, Latham & Watkins  
Anne Connell, AECOM

**Table 1**  
**Combined Gross Output (MW-hr) for MGS Units 1 and 2 (2013 to 2015)**

| <b>Quarter</b>    | <b>Gross Output (MW-hr)</b> |  |
|-------------------|-----------------------------|--|
| 2013-Q1           | 42,345                      |  |
| 2013-Q2           | 70,616                      |  |
| 2013-Q3           | 47,538                      |  |
| 2013-Q4           | 76,407                      |  |
| Total             | 236,906                     |  |
| 2014-Q1           | 31,665                      |  |
| 2014-Q2           | 28,688                      |  |
| 2014-Q3           | 27,856                      |  |
| 2014-Q4           | 69,204                      |  |
| Total             | 157,413                     |  |
| 2015-Q1           | 5,781                       |  |
| 2015-Q2           | 67,153                      |  |
| 2015-Q3           | 137,473                     |  |
| 2015-Q4           | 55,874                      |  |
| Total             | 266,281                     |  |
| <b>3-Year Avg</b> | <b>Gross Output (MW-hr)</b> |  |
| Q1                | 26,597                      |  |
| Q2                | 55,486                      |  |
| Q3                | 70,956                      |  |
| Q4                | 67,161                      |  |
| Total             | 220,200                     |  |

**Table 2**  
**VCAPCD Rule 26.6(F) Quarterly Operating Profile Check for P3 NOx ERCs**

| <b>Calendar Quarter</b> | <b>MGS Units 1 and 2 3-Year Average Combined Gross MW-hr Output</b> | <b>MGS Units 1 and 2 3-Year Average Quarterly Operating Profile</b> | <b>Expected P3 Average Quarterly Operating Profile</b> | <b>Quarterly Operating Profile of SCE NOx ERCs<sup>a</sup></b> | <b>VCAPCD Rule 26.6(F) Quarterly Operating Profile Adjustment<sup>b</sup></b> | <b>VCAPCD Rule 26.6(F) Minimum Threshold</b> | <b>P3 Complies with VCAPCD Rule 26.6(F)?</b> |
|-------------------------|---|---|--|--|---|--|--|
| Q1                      | 26,597  | 12.1%   | 12.1%  | 25.0%  | 12.1%   |  |  |
| Q2                      | 55,486  | 25.2%   | 25.2%  | 25.0%  | 25.0%   |  |  |
| Q3                      | 70,956  | 32.2%   | 32.2%  | 25.0%  | 25.0%   |  |  |
| Q4                      | 67,161  | 30.5%   | 30.5%  | 25.0%  | 25.0%   |  |  |
| Total =                 | 220,200   | 100.0%  | 100.0%   | 100.0%   | 87.1%   | 80%  | Yes  |

Notes:

- a. Based on SCE NOx ERCs quarterly operating profiles shown in <http://www.vcapcd.org/pubs/Engineering/permits2000/Forms/ERCReport.pdf>.
- b. Per VCAPCD Rule 26.6(F), lower of quarterly operating profile for project vs. quarterly operating profile for ERC used for project.