DOCKETED

Docket Number:	06-AFC-09C
Project Title:	Colusa Generating Station - Compliance
TN #:	203287
Document Title:	2014 3rd Quarter Operating Report
Description:	Quarterly Operating Report
Filer:	Charles Robert Price
Organization:	Pacific Gas & Electric Co.
Submitter Role:	Applicant
Submission Date:	10/30/2014 3:56:53 PM
Docketed Date:	10/30/2014

Ed Warner
Plant Manager

Mailing Address
Pacific Gas and Electric Company
Colusa Generating Station
P.O. Box 398
Maxwell, CA 95955

530.934.9061
Fax: 530.934.9024

CGS14-L-0025
October 29, 2014

Eric Veerkamp
California Energy Commission
1516 Ninth Street, MS-2000
Sacramento, CA 95814

Reference: Colusa Generating Station (06-AFC-9)

Subject: Condition of Certification AQSC-9 – Quarterly Operating Reports

Dear Eric:

Attached is the 2014 3rd Quarter Operating Report and is being submitted in accordance with Condition of Certification AQSC-9. If you have any questions, please contact me at (530) 934-9007.

Sincerely,

Charles Price
Senior Environmental Consultant

cc: File No. 3.6.3.1

Ed Warner, PG&E
Jason Vann, PG&E
Sarah Gassner, PG&E

Pacific Gas and
Electric Company

Colusa Generating Station

(CEC# 06-AFC-9C, PTO# 21006-259)

Quarterly Operating Report

Quarter Ending September 30, 2014

PACIFIC GAS AND ELECTRIC COMPANY
COLUSA GENERATING STATION

QUARTERLY OPERATIONS REPORT

QUARTER ENDING September 2014

This report documents compliance with the California Energy Commission's Conditions of Certification AQSC-9 and Colusa County Air Pollution Control District Permit Condition 17.

Attached are summaries of relevant permit conditions and compliance status as well as corresponding required documentation.

Attachment 1:	Air Quality Complaints (AQ-5)
Attachment 2:	Fuel Quality Data (AQ-10, 11)
Attachment 3:	Compliance Demonstration with KKKK (AQ-13)
Attachment 4:	Excess Emissions/Downtime Report (AQ-4, 19)
Attachment 5:	Hourly Emissions VOC (AQ-14)
Attachment 6:	Hourly Emissions NOx (AQ-15)
Attachment 7:	Hourly Emissions CO (AQ-16)
Attachment 8:	Hourly Emissions NH3 (AQ-18)
Attachment 9:	Quarterly/Annual Emission Report (Fuel Use, NH3 Use, Operating Hours) (AQ-23, 26)
Attachment 10:	Maximum Emissions Both Turbines (AQ-25)
Attachment 11:	RATA/Certification Testing (AQ-19)
Attachment 12:	Startup/Shutdowns (AQ-22)
Attachment 13:	Water Bath Heater Operations (AQ-17)
Attachment 14:	Toxics (AQ-29)

ATTACHMENT 1
Complaints (AQ-5)

During the 3rd quarter of 2014, there were no complaints issued from the public for the Colusa Generating Station. The site continues to be available for inspection by representatives of the CCAPCD.

ATTACHMENT 2
Fuel Quality Data (AQ-10, 11)

2014 Monthly Sulfur Content - Colusa Generating Station

All Units in Grains of Sulfur per Standard Cubic Foot

Jan-14	Feb-14	Mar-14	Apr-14	May-14	Jun-14	Jul-14	Aug-14	Sep-14	Oct-14	Nov-14	Dec-14	Avg
0.200	0.173	0.182	0.195	0.225	0.18	0.165	0.165	0.172				0.184

Permit Limits: .75 Grains/SCF per Month (PSD Condition X.I.4); .3 Grains/SCF Annual Average (PTO # 10, AQ-11)

Laboratory Test Report
Applied Technology Services (ATS)
3400 Crow Canyon Road
San Ramon, CA 94583

Report #: 562.1-14.98

Pacific Gas and Electric Company

SUBJECT: CHEMICAL ANALYSES OF GAS SAMPLE FROM COLUSA POWER PLANT
ATS CHEMISTRY SERVICES UNIT FILE 140716-914

On July 16, 2014, Steve North collected two samples of natural gas at Colusa Power Plant, in a 1-L Tedlar bag and in a 500-ml steel cylinder.

The Tedlar bag sample was analyzed for sulfur compounds on July 16, 2014, by Air Toxics Ltd. within 24 hours of the time it was collected. The Air Toxics report is attached.

The steel cylinder was received at ATS on July 16, 2014, and was analyzed on July 21, 2014, for hydrocarbons in the sample using an Agilent 3000 GC with thermal conductivity detector. The results are as follows:

Table 1: Hydrocarbon Content of Natural Gas from Colusa Power Plant on 07-16-14

GAS PHASE COMPONENT	VOLUME
METHANE, %	95.000
ETHANE, %	3.483
PROPANE, %	0.131
ISO-BUTANE, %	0.009
N-BUTANE, %	0.008
ISO-PENTANE, %	0.002
N-PENTANE, %	0.001
HEXANES, HEPTANES, OCTANES, %	000
CARBON DIOXIDE, %	0.826
NITROGEN, %	0.521
HYDROGEN, %	0.002
HELIUM, %	0.010
OXYGEN, %	0.000
TOTAL, %	100.000
CALC. BTU/CU.FT:	1029.79
REAL RELATIVE DENSITY	0.583

As shown in Table 2, the total sulfur content in the gas supply is 0.165 grains per 100 cu. ft. Please contact Surinder Sidhu at 925-866-5510 if there are any questions regarding the chemical analyses.

pc: Charles Price

Date: August 5, 2014

Tested by: S Sidhu
Surinder Sidhu

Approved by: Clement O. Da Silva
Clement O. Da Silva

Table 2: Sulfur Analysis of Natural Gas Supply to Colusa Power Plant on July 16, 2014

(All results in ppmv)

Gas Component	Concentration
Hydrogen Sulfide	0.520
Carbonyl Sulfide	0.420
Methyl Mercaptan	0.031
Ethyl Mercaptan	<0.016
Dimethyl Sulfide	<0.016
Isopropyl Mercaptan	<0.016
tert-Butyl Mercaptan	0.990
sec-Butyl Mercaptan	<0.016
Tetrahydrothiophene	0.820
Other Sulfur Compounds	<0.016
Total	2.781

Total sulfur in grains/100 cu. ft.= 0.165

eurofins | Air Toxics

7/23/2014
Mr. Clement Dasilva
PG&E
3400 Crow Canyon Road

San Ramon CA 94583

Project Name: Natural Gas Sampling
Project #:
Workorder #: 1407262

Dear Mr. Clement Dasilva

The following report includes the data for the above referenced project for sample(s) received on 7/15/2014 at Air Toxics Ltd.

The data and associated QC analyzed by ASTM D-5504 are compliant with the project requirements or laboratory criteria with the exception of the deviations noted in the attached case narrative.

Thank you for choosing Air Toxics Ltd. for your air analysis needs. Air Toxics Ltd. is committed to providing accurate data of the highest quality. Please feel free to contact the Project Manager: Kelly Buettner at 916-985-1000 if you have any questions regarding the data in this report.

Regards,

Kelly Buettner

Project Manager

eurofins | Air Toxics

WORK ORDER #: 1407262

Work Order Summary

CLIENT:	Mr. Clement Dasilva PG&E 3400 Crow Canyon Road San Ramon, CA 94583	**BILL TO:**	Mr. Clement Dasilva PG&E 3400 Crow Canyon Road San Ramon, CA 94583
PHONE:	925-866-5421	**P.O. #**	3500782251
FAX:	925-866-5681	**PROJECT #**	Natural Gas Sampling
DATE RECEIVED:	07/15/2014	**CONTACT:**	Kelly Buettner
DATE COMPLETED:	07/23/2014		

FRACTION #	NAME	TEST	RECEIPT VAC./PRES.	FINAL PRESSURE
01A	HBPP-GS-JUL-A	ASTM D-5504	Tedlar Bag	Tedlar Bag
02A	CPP-GS-JUL-A	ASTM D-5504	Tedlar Bag	Tedlar Bag
03A	Lab Blank	ASTM D-5504	NA	NA
04A	LCS	ASTM D-5504	NA	NA
04AA	LCSD	ASTM D-5504	NA	NA

CERTIFIED BY: Heidi Mayo

Technical Director

DATE: 07/23/14

Certification numbers: AZ Licensure AZ0775, CA NELAP - 12282CA, NJ NELAP - CA016, NY NELAP - 11291, TX NELAP - T104704434-13-6, UT NELAP CA009332013-4, VA NELAP - 460197, WA NELAP - C935
Name of Accrediting Agency: NELAP/ORELAP (Oregon Environmental Laboratory Accreditation Program)
Accreditation number: CA300005, Effective date: 10/18/2013, Expiration date: 10/17/2014.
Eurofins Air Toxics Inc.. certifies that the test results contained in this report meet all requirements of the NELAC standards

This report shall not be reproduced, except in full, without the written approval of Eurofins Air Toxics, Inc.

180 BLUE RAVINE ROAD, SUITE B FOLSOM, CA - 9563
(916) 985-1000 . (800) 985-5955 . FAX (916) 985-1020

eurofins | Air Toxics

LABORATORY NARRATIVE
ASTM D-5504
PG&E
Workorder# 1407262

Two Client Tedlar Bag samples were received on July 15, 2014. The laboratory performed the analysis of sulfur compounds via ASTM D-5504 using GC/SCD. The method involves direct injection of the air sample into the GC via a fixed 2.0 mL sampling loop. See the data sheets for the reporting limits for each compound.

Receiving Notes

There were no receiving discrepancies.

Analytical Notes

There were no analytical discrepancies.

Definition of Data Qualifying Flags

Seven qualifiers may have been used on the data analysis sheets and indicate as follows:
B - Compound present in laboratory blank greater than reporting limit.
J - Estimated value.
E - Exceeds instrument calibration range.
S - Saturated peak.
Q - Exceeds quality control limits.
U - Compound analyzed for but not detected above the detection limit.
M - Reported value may be biased due to apparent matrix interferences.
File extensions may have been used on the data analysis sheets and indicates as follows:
a-File was requantified
b-File was quantified by a second column and detector
r1-File was requantified for the purpose of reissue

eurofins | Air Toxics

Summary of Detected Compounds
SULFUR GASES BY ASTM D-5504 GC/SCD

Client Sample ID: HBPP-GS-JUL-A

Lab ID#: 1407262-01A

Compound	Rpt. Limit (ppbv)	Amount (ppbv)
Hydrogen Sulfide	16	400
Carbonyl Sulfide	16	390
Methyl Mercaptan	16	40
Dimethyl Sulfide	16	130
Isopropyl Mercaptan	16	46
tert-Butyl Mercaptan	16	900
n-Propyl Mercaptan	16	21
Tetrahydrothiophene	16	580

Client Sample ID: CPP-GS-JUL-A

Lab ID#: 1407262-02A

Compound	Rpt. Limit (ppbv)	Amount (ppbv)
Hydrogen Sulfide	16	520
Carbonyl Sulfide	16	420
Methyl Mercaptan	16	31
tert-Butyl Mercaptan	16	990
Tetrahydrothiophene	16	820

eurofins | Air Toxics

Client Sample ID: HBPP-GS-JUL-A

Lab ID#: 1407262-01A

SULFUR GASES BY ASTM D-5504 GC/SCD

File Name:	**k071606**	**Date of Collection:**	**7/15/14 9:13:00 AM**
Dil. Factor:	**4.00**	**Date of Analysis:**	**7/15/14 08:20 PM**

Compound	Rpt. Limit (ppbv)	Amount (ppbv)
Hydrogen Sulfide	16	400
Carbonyl Sulfide	16	390
Methyl Mercaptan	16	40
Ethyl Mercaptan	16	Not Detected
Dimethyl Sulfide	16	130
Carbon Disulfide	20	Not Detected
Isopropyl Mercaptan	16	46
tert-Butyl Mercaptan	16	900
n-Propyl Mercaptan	16	21
Ethyl Methyl Sulfide	16	Not Detected
Thiophene	16	Not Detected
Isobutyl Mercaptan	16	Not Detected
Diethyl Sulfide	16	Not Detected
n-Butyl Mercaptan	16	Not Detected
Dimethyl Disulfide	16	Not Detected
3-Methylthiophene	16	Not Detected
Tetrahydrothiophene	16	580
2-Ethylthiophene	16	Not Detected
2,5-Dimethylthiophene	16	Not Detected
Diethyl Disulfide	16	Not Detected

Container Type: Client Tedlar Bag

eurofins | Air Toxics

Client Sample ID: CPP-GS-JUL-A

Lab ID#: 1407262-02A

SULFUR GASES BY ASTM D-5504 GC/SCD

File Name:	**k071607**	**Date of Collection:**	**7/15/14 3:44:00 PM**
Dil. Factor:	**4.00**	**Date of Analysis:**	**7/15/14 08:47 PM**

Compound	Rpt. Limit (ppbv)	Amount (ppbv)
Hydrogen Sulfide	16	520
Carbonyl Sulfide	16	420
Methyl Mercaptan	16	31
Ethyl Mercaptan	16	Not Detected
Dimethyl Sulfide	16	Not Detected
Carbon Disulfide	20	Not Detected
Isopropyl Mercaptan	16	Not Detected
tert-Butyl Mercaptan	16	990
n-Propyl Mercaptan	16	Not Detected
Ethyl Methyl Sulfide	16	Not Detected
Thiophene	16	Not Detected
Isobutyl Mercaptan	16	Not Detected
Diethyl Sulfide	16	Not Detected
n-Butyl Mercaptan	16	Not Detected
Dimethyl Disulfide	16	Not Detected
3-Methylthiophene	16	Not Detected
Tetrahydrothiophene	16	820
2-Ethylthiophene	16	Not Detected
2,5-Dimethylthiophene	16	Not Detected
Diethyl Disulfide	16	Not Detected

Container Type: Client Tedlar Bag

eurofins | Air Toxics

Client Sample ID: Lab Blank

Lab ID#: 1407262-03A

SULFUR GASES BY ASTM D-5504 GC/SCD

File Name:	**k071605**	**Date of Collection: NA**	
Dil. Factor:	**1.00**	**Date of Analysis: 7/15/14 07:54 PM**	

Compound	**Rpt. Limit (ppbv)**	**Amount (ppbv)**
Hydrogen Sulfide	4.0	Not Detected
Carbonyl Sulfide	4.0	Not Detected
Methyl Mercaptan	4.0	Not Detected
Ethyl Mercaptan	4.0	Not Detected
Dimethyl Sulfide	4.0	Not Detected
Carbon Disulfide	5.0	Not Detected
Isopropyl Mercaptan	4.0	Not Detected
tert-Butyl Mercaptan	4.0	Not Detected
n-Propyl Mercaptan	4.0	Not Detected
Ethyl Methyl Sulfide	4.0	Not Detected
Thiophene	4.0	Not Detected
Isobutyl Mercaptan	4.0	Not Detected
Diethyl Sulfide	4.0	Not Detected
n-Butyl Mercaptan	4.0	Not Detected
Dimethyl Disulfide	4.0	Not Detected
3-Methylthiophene	4.0	Not Detected
Tetrahydrothiophene	4.0	Not Detected
2-Ethylthiophene	4.0	Not Detected
2,5-Dimethylthiophene	4.0	Not Detected
Diethyl Disulfide	4.0	Not Detected

Container Type: NA - Not Applicable

eurofins | Air Toxics

Client Sample ID: LCS

Lab ID#: 1407262-04A

SULFUR GASES BY ASTM D-5504 GC/SCD

File Name:	**k071602**	**Date of Collection: NA**	
Dil. Factor:	**1.00**	**Date of Analysis: 7/15/14 06:38 PM**	

Compound	**%Recovery**	**Method Limits**
Hydrogen Sulfide	78	70-130
Carbonyl Sulfide	75	70-130
Methyl Mercaptan	79	70-130
Ethyl Mercaptan	94	70-130
Dimethyl Sulfide	86	70-130
Carbon Disulfide	89	70-130
Isopropyl Mercaptan	94	70-130
tert-Butyl Mercaptan	101	70-130
n-Propyl Mercaptan	103	70-130
Ethyl Methyl Sulfide	111	70-130
Thiophene	101	70-130
Isobutyl Mercaptan	104	70-130
Diethyl Sulfide	93	70-130
n-Butyl Mercaptan	93	70-130
Dimethyl Disulfide	100	70-130
3-Methylthiophene	99	70-130
Tetrahydrothiophene	95	70-130
2-Ethylthiophene	95	70-130
2,5-Dimethylthiophene	94	70-130
Diethyl Disulfide	99	70-130

Container Type: NA - Not Applicable

eurofins | Air Toxics

Client Sample ID: LCSD

Lab ID#: 1407262-04AA

SULFUR GASES BY ASTM D-5504 GC/SCD

File Name:	**k071603**	**Date of Collection: NA**	
Dil. Factor:	**1.00**	**Date of Analysis: 7/15/14 07:05 PM**	

Compound	**%Recovery**	**Method Limits**
Hydrogen Sulfide	82	70-130
Carbonyl Sulfide	73	70-130
Methyl Mercaptan	80	70-130
Ethyl Mercaptan	95	70-130
Dimethyl Sulfide	88	70-130
Carbon Disulfide	90	70-130
Isopropyl Mercaptan	97	70-130
tert-Butyl Mercaptan	98	70-130
n-Propyl Mercaptan	87	70-130
Ethyl Methyl Sulfide	90	70-130
Thiophene	104	70-130
Isobutyl Mercaptan	111	70-130
Diethyl Sulfide	96	70-130
n-Butyl Mercaptan	106	70-130
Dimethyl Disulfide	98	70-130
3-Methylthiophene	96	70-130
Tetrahydrothiophene	96	70-130
2-Ethylthiophene	94	70-130
2,5-Dimethylthiophene	86	70-130
Diethyl Disulfide	96	70-130

Container Type: NA - Not Applicable

Chain of Custody Record

Pacific Gas and Electric Company

SAM #

Client: PG&E Environmental Services	Project Manager: Clem Da Silva		Date:
Address: 3400 Crow Canyon Road	Telephone Number: 925-866-5421	Email: codu@pge.com	Laboratory: Air Toxics
City: San Ramon / State: CA / Zip: 94583	Site Contacat: Clem Da Silva 925.866.5421		Laboratory Phone: 916-985-1000
Project Number/Name: Natural Gas Sampling	Sampler: Steve North 925-785-3039		Laboratory Fax:
Contract Number, PO Number:	Laboratory Contact: 180 Blue Ravine Rd. Folsom CA, 95630		

Preparation and Analysis

	PG&E Sample ID	SAM#-ID#	Date	Time	Sample Type	Containers: Volume	Containers: Type	Containers: No.	Preservative	Condition on Receipt/Comments	Sulfur
1A	HBPP-GS-JUL-A		7/15/14	09:13	Gas	1 liter	bag	1	None		X
2A	CPP-GS-JUL-A		7/15/14	15:44	Gas	1 liter	bag	1	None		X

Custody Seal Intact?
Y N None Temp NA
H/D

Special Instruction: Please hold samples for 45 days.
Email results to Clem daSilva CODU@PGE.COM and Lauren Eastman LKE1@PGE.COM

Turn Around Time Required: ☑ Normal ☐ Rush ☐ Other

QC Level: ☑ I. ☐ II. ☐ III.

Project Specific Requirements (Specify):

1. Relinquished By: Steve North	Date: 7/15/14	Time: 1741	1. Received By: EATL	Date: 7/15/14	Time: 1741
2. Relinquished By:	Date:	Time:	2. Received By:	Date:	Time:
3. Relinquished By:	Date:	Time:	3. Received By:	Date:	Time:

Comments:

1407262

Laboratory Test Report
Applied Technology Services (ATS)
3400 Crow Canyon Road
San Ramon, CA 94583

Report #: 562.1-14.139

Pacific Gas and Electric Company

SUBJECT: CHEMICAL ANALYSES OF GAS SAMPLE FROM COLUSA POWER PLANT
ATS CHEMISTRY SERVICES UNIT FILE ATS140909-1481

On September 8, 2014, Steve North collected two samples of natural gas at Colusa Power Plant, in a 1-L Tedlar bag and in a 500-ml steel cylinder.

The Tedlar bag sample was analyzed for sulfur compounds on September 8, 2014, by Air Toxics Ltd. within 24 hours of the time it was collected. The Air Toxics report is attached.

The steel cylinder was received at ATS on September 9, 2014, and the hydrocarbons in the sample were analyzed using an Agilent 3000 GC with thermal conductivity detector. The results are as follows:

Table 1: Hydrocarbon Content of Natural Gas from Colusa Power Plant on 09/08/2014

GAS PHASE COMPONENT	VOLUME
METHANE, %	94.615
ETHANE, %	4.000
PROPANE, %	0.130
ISO-BUTANE, %	0.006
N-BUTANE, %	0.013
ISO-PENTANE, %	0.003
N-PENTANE, %	0.002
HEXANES, HEPTANES, OCTANES, %	0.001
CARBON DIOXIDE, %	0.738
NITROGEN, %	0.472
HYDROGEN, %	0.002
HELIUM, %	0.011
OXYGEN, %	0.000
TOTAL, %	100.000
CALC. BTU/CU.FT:	1035.288
REAL RELATIVE DENSITY	0.585
METHANE NUMBER	88.719

As shown in Table 2, the total sulfur content in the gas supply is 0.172 grains per 100 cu. ft. Please contact Evan Cavalli at 925-866-5510 if there are any questions regarding the chemical analyses.

pc: Charles Price

Date: September 17, 2014

Tested by: Evan Cavalli

Approved by: Clement O. Da Silva

Table 2: Sulfur Analysis of Natural Gas Supply to Colusa Power Plant on September 8, 2014

(All results in ppmv)

Gas Component	Concentration
Hydrogen Sulfide	0.47
Carbonyl Sulfide	0.57
Methyl Mercaptan	0.05
Ethyl Mercaptan	0.02
Dimethyl Sulfide	<0.02
Isopropyl Mercaptan	<0.02
tert-Butyl Mercaptan	1.00
sec-Butyl Mercaptan	<0.02
Tetrahydrothiophene	0.79
Other Sulfur Compounds	<0.02
Total	2.90

Total sulfur in grains/100 cu. ft.= 0.172

Attachments

pc: Charles Price

Date: September 17, 2014

Tested by:

Evan M. Cavalli

Approved by: Clement O. Da Silva

Clement O. Da Silva

eurofins | Air Toxics

9/15/2014
Mr. Clement Dasilva
PG&E
3400 Crow Canyon Road

San Ramon CA 94583

Project Name: Natural Gas Sampling
Project #:
Workorder #: 1409074

Dear Mr. Clement Dasilva

The following report includes the data for the above referenced project for sample(s) received on 9/8/2014 at Air Toxics Ltd.

The data and associated QC analyzed by ASTM D-5504 are compliant with the project requirements or laboratory criteria with the exception of the deviations noted in the attached case narrative.

Thank you for choosing Air Toxics Ltd. for your air analysis needs. Air Toxics Ltd. is committed to providing accurate data of the highest quality. Please feel free to contact the Project Manager: Kelly Buettner at 916-985-1000 if you have any questions regarding the data in this report.

Regards,

Kelly Buettner

Project Manager

eurofins | Air Toxics

WORK ORDER #: 1409074

Work Order Summary

CLIENT:	Mr. Clement Dasilva PG&E 3400 Crow Canyon Road San Ramon, CA 94583	**BILL TO:**	Mr. Clement Dasilva PG&E 3400 Crow Canyon Road San Ramon, CA 94583
PHONE:	925-866-5421	**P.O. #**	3500782251
FAX:	925-866-5681	**PROJECT #**	Natural Gas Sampling
DATE RECEIVED:	09/08/2014	**CONTACT:**	Kelly Buettner
DATE COMPLETED:	09/15/2014		

FRACTION #	NAME	TEST	RECEIPT VAC./PRES.	FINAL PRESSURE
01A	CPP-GS-SEP-A	ASTM D-5504	Tedlar Bag	Tedlar Bag
02A	Lab Blank	ASTM D-5504	NA	NA
03A	LCS	ASTM D-5504	NA	NA
03AA	LCSD	ASTM D-5504	NA	NA

CERTIFIED BY: Heidi Mayo

Technical Director

DATE: 09/15/14

Certification numbers: AZ Licensure AZ0775, NJ NELAP - CA016, NY NELAP - 11291,
TX NELAP - T104704434-13-6, UT NELAP CA009332014-5, VA NELAP - 460197, WA NELAP - C935
Name of Accrediting Agency: NELAP/ORELAP (Oregon Environmental Laboratory Accreditation Program)
Accreditation number: CA300005, Effective date: 10/18/2013, Expiration date: 10/17/2014.
Eurofins Air Toxics Inc.. certifies that the test results contained in this report meet all requirements of the NELAC standards

This report shall not be reproduced, except in full, without the written approval of Eurofins Air Toxics, Inc.

180 BLUE RAVINE ROAD, SUITE B FOLSOM, CA - 9563
(916) 985-1000 . (800) 985-5955 . FAX (916) 985-1020

eurofins | Air Toxics

LABORATORY NARRATIVE
ASTM D-5504
PG&E
Workorder# 1409074

One Client Tedlar Bag sample was received on September 08, 2014. The laboratory performed the analysis of sulfur compounds via ASTM D-5504 using GC/SCD. The method involves direct injection of the air sample into the GC via a fixed 2.0 mL sampling loop. See the data sheets for the reporting limits for each compound.

Receiving Notes

There were no receiving discrepancies.

Analytical Notes

There were no analytical discrepancies.

Definition of Data Qualifying Flags

Seven qualifiers may have been used on the data analysis sheets and indicate as follows:
B - Compound present in laboratory blank greater than reporting limit.
J - Estimated value.
E - Exceeds instrument calibration range.
S - Saturated peak.
Q - Exceeds quality control limits.
U - Compound analyzed for but not detected above the detection limit.
M - Reported value may be biased due to apparent matrix interferences.
File extensions may have been used on the data analysis sheets and indicates as follows:
a-File was requantified
b-File was quantified by a second column and detector
r1-File was requantified for the purpose of reissue

eurofins | Air Toxics

Summary of Detected Compounds
SULFUR GASES BY ASTM D-5504 GC/SCD

Client Sample ID: CPP-GS-SEP-A

Lab ID#: 1409074-01A

Compound	Rpt. Limit (ppbv)	Amount (ppbv)
Hydrogen Sulfide	16	470
Carbonyl Sulfide	16	570
Methyl Mercaptan	16	54
Ethyl Mercaptan	16	17
tert-Butyl Mercaptan	16	1000
Tetrahydrothiophene	16	790

eurofins | Air Toxics

Client Sample ID: CPP-GS-SEP-A

Lab ID#: 1409074-01A

SULFUR GASES BY ASTM D-5504 GC/SCD

File Name:	**k090906**	**Date of Collection:**	**9/8/14 11:02:00 AM**
Dil. Factor:	**4.00**	**Date of Analysis:**	**9/8/14 09:21 PM**

Compound	Rpt. Limit (ppbv)	Amount (ppbv)
Hydrogen Sulfide	16	470
Carbonyl Sulfide	16	570
Methyl Mercaptan	16	54
Ethyl Mercaptan	16	17
Dimethyl Sulfide	16	Not Detected
Carbon Disulfide	20	Not Detected
Isopropyl Mercaptan	16	Not Detected
tert-Butyl Mercaptan	16	1000
n-Propyl Mercaptan	16	Not Detected
Ethyl Methyl Sulfide	16	Not Detected
Thiophene	16	Not Detected
Isobutyl Mercaptan	16	Not Detected
Diethyl Sulfide	16	Not Detected
n-Butyl Mercaptan	16	Not Detected
Dimethyl Disulfide	16	Not Detected
3-Methylthiophene	16	Not Detected
Tetrahydrothiophene	16	790
2-Ethylthiophene	16	Not Detected
2,5-Dimethylthiophene	16	Not Detected
Diethyl Disulfide	16	Not Detected

Container Type: Client Tedlar Bag

eurofins | Air Toxics

Client Sample ID: Lab Blank

Lab ID#: 1409074-02A

SULFUR GASES BY ASTM D-5504 GC/SCD

File Name:	**k090905**	**Date of Collection: NA**	
Dil. Factor:	**1.00**	**Date of Analysis: 9/8/14 08:55 PM**	

Compound	**Rpt. Limit (ppbv)**	**Amount (ppbv)**
Hydrogen Sulfide	4.0	Not Detected
Carbonyl Sulfide	4.0	Not Detected
Methyl Mercaptan	4.0	Not Detected
Ethyl Mercaptan	4.0	Not Detected
Dimethyl Sulfide	4.0	Not Detected
Carbon Disulfide	5.0	Not Detected
Isopropyl Mercaptan	4.0	Not Detected
tert-Butyl Mercaptan	4.0	Not Detected
n-Propyl Mercaptan	4.0	Not Detected
Ethyl Methyl Sulfide	4.0	Not Detected
Thiophene	4.0	Not Detected
Isobutyl Mercaptan	4.0	Not Detected
Diethyl Sulfide	4.0	Not Detected
n-Butyl Mercaptan	4.0	Not Detected
Dimethyl Disulfide	4.0	Not Detected
3-Methylthiophene	4.0	Not Detected
Tetrahydrothiophene	4.0	Not Detected
2-Ethylthiophene	4.0	Not Detected
2,5-Dimethylthiophene	4.0	Not Detected
Diethyl Disulfide	4.0	Not Detected

Container Type: NA - Not Applicable

eurofins | Air Toxics

Client Sample ID: LCS

Lab ID#: 1409074-03A

SULFUR GASES BY ASTM D-5504 GC/SCD

File Name:	**k090902**	**Date of Collection: NA**	
Dil. Factor:	**1.00**	**Date of Analysis: 9/8/14 07:17 PM**	

Compound	**%Recovery**	**Method Limits**
Hydrogen Sulfide	87	70-130
Carbonyl Sulfide	81	70-130
Methyl Mercaptan	90	70-130
Ethyl Mercaptan	90	70-130
Dimethyl Sulfide	82	70-130
Carbon Disulfide	87	70-130
Isopropyl Mercaptan	87	70-130
tert-Butyl Mercaptan	92	70-130
n-Propyl Mercaptan	92	70-130
Ethyl Methyl Sulfide	95	70-130
Thiophene	87	70-130
Isobutyl Mercaptan	109	70-130
Diethyl Sulfide	89	70-130
n-Butyl Mercaptan	95	70-130
Dimethyl Disulfide	88	70-130
3-Methylthiophene	89	70-130
Tetrahydrothiophene	90	70-130
2-Ethylthiophene	85	70-130
2,5-Dimethylthiophene	84	70-130
Diethyl Disulfide	85	70-130

Container Type: NA - Not Applicable

eurofins | Air Toxics

Client Sample ID: LCSD

Lab ID#: 1409074-03AA

SULFUR GASES BY ASTM D-5504 GC/SCD

File Name:	**k090903**	**Date of Collection: NA**	
Dil. Factor:	**1.00**	**Date of Analysis: 9/8/14 07:46 PM**	

Compound	**%Recovery**	**Method Limits**
Hydrogen Sulfide	85	70-130
Carbonyl Sulfide	76	70-130
Methyl Mercaptan	91	70-130
Ethyl Mercaptan	93	70-130
Dimethyl Sulfide	82	70-130
Carbon Disulfide	85	70-130
Isopropyl Mercaptan	86	70-130
tert-Butyl Mercaptan	89	70-130
n-Propyl Mercaptan	92	70-130
Ethyl Methyl Sulfide	91	70-130
Thiophene	87	70-130
Isobutyl Mercaptan	106	70-130
Diethyl Sulfide	87	70-130
n-Butyl Mercaptan	90	70-130
Dimethyl Disulfide	90	70-130
3-Methylthiophene	91	70-130
Tetrahydrothiophene	94	70-130
2-Ethylthiophene	88	70-130
2,5-Dimethylthiophene	86	70-130
Diethyl Disulfide	87	70-130

Container Type: NA - Not Applicable

ATTACHMENT 3
40 CFR 60 Section KKKK (AQ-13)

40 CFR 60 KKKK Emission Limits:

Natural Gas Fired Combustion Turbine > 850 MMBtu

15 PPMVDC @ 15% O_2; 4 Hour Rolling Average

During Normal Operations

96 PPMVDC @ 15%; 4 Hour Rolling Average

Turbines operating at less than 75% of Peak Load (Startup/Shutdown)

KKKK Compliance (Colusa Generating Station)

40 CFR Part 60 Subpart KKKK applies to all stationary gas turbines rated at greater than or equal to 10 MMBtu/hr that commence construction, modification, or reconstruction after February 18, 2005. The gas turbines involved in this project have a rating of 1612 MMBtu/hr and were installed after February 18, 2005. Therefore, this subpart applies to these gas turbines. The KKKK compliance summaries for the stationary natural gas turbines is summarized below and are based on the following applicable sections of the KKKK performance standards. The non-applicable portions of KKKK are not listed in the compliance summary:

Section	Requirement
60.4305	CGS Turbines/HRSGs are rated at larger than 10 mmbtu/hr and construction commenced after February 18, 2005. Subpart KKKK applies.
60.4310	No exemptions apply.
60.4315	Pollutants regulated under Subpart KKKK: NO_x and SO_2.
60.4320	NOx emissions limit: 15 ppmv @15%O_2
60.4330	SO2 emissions limit: 0.90 lbs SO2/MWh (gross output), or cannot burn any fuel which contains total potential sulfur emissions in excess of 0.060 lbs SO2/MMBtu (heat input).
60.4333	Operate turbine/HRSG, APC systems, and monitoring equipment to minimize emissions at all times including during startup, shutdown, and malfunction.
60.4340(b)(1)	For units with SCR, install a NO_x CEMS per 60.4335(b) or 60.4345. If Part 75 applies, NO_x can be monitored per Appendix E of Part 75. (CGS QAP applies here)
60.4345	Meet all CEMS Performance Specs and develop a QA Plan for the CEMS. . (CGS QAP applies here)
60.4350	All CEMS data must be reduced to hourly averages per 60.13(h). . (CGS QAP applies here)
60.4355	If applicable, develop and insure all parametric monitoring and monitoring plans comply with this section. . (CGS QAP applies here)
60.4360	Monitor fuel sulfur content, or invoke exemption per 60.4365.
60.4365	Exemption for fuel sulfur monitoring, if fuel is demonstrated not to exceed potential sulfur emissions of 0.060 lbs SO_2/MMBtu, Use PG&E gas quality data to show that exemption applies per 60.4365 (a) or (b).
60.4375	Submit excess emissions reports per 60.7(c). Within 30 days following the end of each 6 month period (see 60.4395). In compliance.
60.4380(b)	Determine excess emissions and monitor downtime per (b) (1-3)
60.4400	Initial and annual NO_X performance tests not required if CEMS used

	per 60.4340(b)(1)
60.4405	If NO_x CEMS used, use 60.4405 (a-d) procedures in lieu of performance test.
60.4415	Perform initial SO_2 performance test per 60.4415 (2) or (3). This test must be conducted even if the 60.4365 exemption is invoked.

Compliance with the applicable provisions of NSPS KKKK are summarized below. Specific data to support the compliance determinations listed below are included as attachments.

Section	Compliance
60.4305	KKKK is applicable to the facility. In compliance
60.4310	No exemptions apply.
60.4315	NO_x and SO_2 are in compliance with the KKKK emission standards and monitoring requirements.
60.4320	NO_x emissions limit: 9 ppmv @15%O_2 (See attached GE data sheet). In compliance.
60.4330	SO_2 emissions limit: CT1 172 MW 1.283 lb/hr (SO_2 source test date: 2010) CT2 172 MW 1.649 lb/hr (SO_2 source test date: 2010) CT1 - 1.283/172 = 0.0075 lb/MWh CT2 - 1.649/172 = 0.0096 lb/MWh In compliance with SO2 emission limits. The project will only use pipe quality natural gas with sulfur limits less than 0.06 lbs/MMBtu. See attached natural gas fuel analysis. In compliance with limits based on monthly fuel sampling.
60.4333	The facility will operate turbine/HRSG, APC systems, and monitoring equipment to minimize emissions at all times including during startup, shutdown, and malfunction. In compliance.
60.4340(b)(1)	CT1 and CT2 utilize SCR and NO_x CEMS per 60.4335(b) or 60.4345. In addition, Part 75 applies and NO_x is monitored per Appendix E of Part 75. See attached Quality Assurance Plan (attached). In compliance.
60.4345	In compliance. .
60.4350	In compliance
60.4355	In compliance
60.4360	In compliance through exemption per 60.4365.
60.4365	Requesting exemption (a) and (b) for sulfur monitoring. The fuel used is pipeline quality natural gas with an average grain loading less than 0.30 gr/100 SCF which converts to 0.0008 lb/MMBtu of SO_2. See fuel

	analysis Attachment 2. Annual compliance based on PG&E supplied fuel analysis data.
60.4375	No excess emissions during this reporting period. In compliance.
60.4380(b)	No excess emissions or monitor downtime, per (b) (1-3). In compliance.
60.4400	In compliance. NO_x CEMs used per 60.4340(b)(1). NO_x, CO, and VOC will be tested annually.
60.4405	In compliance. See QAP for CEMs certification.
60.4415	In compliance. Initial SO_2 source test results and QAP are available upon request. Future compliance under this requirement may be determined using one of three methods summarized in 60.4415.

Excess Emission Report

CT1 NOx 30 Day Rolling Average (KKKK)

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:04 **Location:** Maxwell, CA

Tag Name: CT1_NOx_30D_Ppmvdc_1D
Total Operating Time: 70.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 22.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	70.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

CT2 NOx 30 Day Rolling Average (KKKK)

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:04 **Location:** Maxwell, CA

Tag Name: CT2_NOx_30D_Ppmvdc_1D
Total Operating Time: 70.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 22.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	70.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/01/2014 00:00	1	1
07/01/2014 01:00	1	1
07/01/2014 02:00	1	1
07/01/2014 03:00	1	0
07/01/2014 04:00	1	0
07/01/2014 05:00	1	0
07/01/2014 06:00	1	0
07/01/2014 07:00	1	1
07/01/2014 08:00	1	1
07/01/2014 09:00	1	1
07/01/2014 10:00	1	1
07/01/2014 11:00	1	1
07/01/2014 12:00	1	1
07/01/2014 13:00	1	1
07/01/2014 14:00	1	1
07/01/2014 15:00	1	1
07/01/2014 16:00	1	1
07/01/2014 17:00	1	1
07/01/2014 18:00	1	1
07/01/2014 19:00	1	1
07/01/2014 20:00	1	1
07/01/2014 21:00	1	1
07/01/2014 22:00	1	1
07/01/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	0
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/02/2014 00:00	1	1
07/02/2014 01:00	1	1
07/02/2014 02:00	1	1
07/02/2014 03:00	1	1
07/02/2014 04:00	1	1
07/02/2014 05:00	1	1
07/02/2014 06:00	1	1
07/02/2014 07:00	1	1
07/02/2014 08:00	1	1
07/02/2014 09:00	1	1
07/02/2014 10:00	1	1
07/02/2014 11:00	1	1
07/02/2014 12:00	1	1
07/02/2014 13:00	1	1
07/02/2014 14:00	1	1
07/02/2014 15:00	1	1
07/02/2014 16:00	1	1
07/02/2014 17:00	1	1
07/02/2014 18:00	1	1
07/02/2014 19:00	1	1
07/02/2014 20:00	1	1
07/02/2014 21:00	1	1
07/02/2014 22:00	2	2
07/02/2014 23:00	2	2
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	2	2
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/03/2014 00:00	2	2
07/03/2014 01:00	2	2
07/03/2014 02:00	2	2
07/03/2014 03:00	2	2
07/03/2014 04:00	2	2
07/03/2014 05:00	2	2
07/03/2014 06:00	1	2
07/03/2014 07:00	1	10
07/03/2014 08:00	1	12
07/03/2014 09:00	1	12
07/03/2014 10:00	1	11
07/03/2014 11:00	1	3
07/03/2014 12:00	1	1
07/03/2014 13:00	1	1
07/03/2014 14:00	1	1
07/03/2014 15:00	1	1
07/03/2014 16:00	1	1
07/03/2014 17:00	1	1
07/03/2014 18:00	1	1
07/03/2014 19:00	1	1
07/03/2014 20:00	1	1
07/03/2014 21:00	1	1
07/03/2014 22:00	1	1
07/03/2014 23:00	1	1
Average/Sum#:	1	3
Minimum:	1	1
Maximum:	2	12
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/04/2014 00:00	1	1
07/04/2014 01:00	1	1
07/04/2014 02:00	1	1
07/04/2014 03:00	1	1
07/04/2014 04:00	1	1
07/04/2014 05:00	1	1
07/04/2014 06:00	1	1
07/04/2014 07:00	1	1
07/04/2014 08:00	1	1
07/04/2014 09:00	1	1
07/04/2014 10:00	1	1
07/04/2014 11:00	1	1
07/04/2014 12:00	1	1
07/04/2014 13:00	1	1
07/04/2014 14:00	1	1
07/04/2014 15:00	1	1
07/04/2014 16:00	1	1
07/04/2014 17:00	1	1
07/04/2014 18:00	1	1
07/04/2014 19:00	1	1
07/04/2014 20:00	2	1
07/04/2014 21:00	2	1
07/04/2014 22:00	2	1
07/04/2014 23:00	2	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	2	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/05/2014 00:00	2	1
07/05/2014 01:00	2	1
07/05/2014 02:00	2	1
07/05/2014 03:00	2	1
07/05/2014 04:00	2	1
07/05/2014 05:00	2	1
07/05/2014 06:00	10	1
07/05/2014 07:00	13	1
07/05/2014 08:00	13	1
07/05/2014 09:00	12	1
07/05/2014 10:00	4	13
07/05/2014 11:00	1	16
07/05/2014 12:00	1	16
07/05/2014 13:00	1	16
07/05/2014 14:00	1	4
07/05/2014 15:00	1	1
07/05/2014 16:00	1	1
07/05/2014 17:00	1	1
07/05/2014 18:00	1	1
07/05/2014 19:00	1	1
07/05/2014 20:00	1	1
07/05/2014 21:00	1	1
07/05/2014 22:00	1	1
07/05/2014 23:00	1	1
Average/Sum#:	3	4
Minimum:	1	1
Maximum:	13	16
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/06/2014 00:00	1	1
07/06/2014 01:00	1	1
07/06/2014 02:00	2	2
07/06/2014 03:00	2	2
07/06/2014 04:00	2	2
07/06/2014 05:00	4	2
07/06/2014 06:00	6	2
07/06/2014 07:00	6	2
07/06/2014 08:00	4	2
07/06/2014 09:00	2	7
07/06/2014 10:00	1	13
07/06/2014 11:00	1	13
07/06/2014 12:00	1	12
07/06/2014 13:00	1	7
07/06/2014 14:00	1	1
07/06/2014 15:00	1	1
07/06/2014 16:00	1	1
07/06/2014 17:00	1	1
07/06/2014 18:00	1	1
07/06/2014 19:00	1	1
07/06/2014 20:00	1	1
07/06/2014 21:00	1	1
07/06/2014 22:00	1	1
07/06/2014 23:00	1	1
Average/Sum#:	2	3
Minimum:	1	1
Maximum:	6	13
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/07/2014 00:00	1	1
07/07/2014 01:00	1	1
07/07/2014 02:00	1	1
07/07/2014 03:00	1	1
07/07/2014 04:00	1	1
07/07/2014 05:00	1	1
07/07/2014 06:00	1	1
07/07/2014 07:00	1	1
07/07/2014 08:00	1	1
07/07/2014 09:00	1	1
07/07/2014 10:00	1	1
07/07/2014 11:00	1	1
07/07/2014 12:00	1	1
07/07/2014 13:00	1	1
07/07/2014 14:00	1	1
07/07/2014 15:00	1	1
07/07/2014 16:00	1	1
07/07/2014 17:00	1	1
07/07/2014 18:00	1	1
07/07/2014 19:00	1	1
07/07/2014 20:00	1	1
07/07/2014 21:00	1	1
07/07/2014 22:00	1	1
07/07/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/08/2014 00:00	1	1
07/08/2014 01:00	1	1
07/08/2014 02:00	1	1
07/08/2014 03:00	1	1
07/08/2014 04:00	1	1
07/08/2014 05:00	1	1
07/08/2014 06:00	1	1
07/08/2014 07:00	1	1
07/08/2014 08:00	1	1
07/08/2014 09:00	1	1
07/08/2014 10:00	1	1
07/08/2014 11:00	1	1
07/08/2014 12:00	1	1
07/08/2014 13:00	1	1
07/08/2014 14:00	1	1
07/08/2014 15:00	1	1
07/08/2014 16:00	1	1
07/08/2014 17:00	1	1
07/08/2014 18:00	1	1
07/08/2014 19:00	1	1
07/08/2014 20:00	1	1
07/08/2014 21:00	1	1
07/08/2014 22:00	1	1
07/08/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/09/2014 00:00	1	1
07/09/2014 01:00	1	0
07/09/2014 02:00	0	0
07/09/2014 03:00	0	0
07/09/2014 04:00	0	0
07/09/2014 05:00	0	0
07/09/2014 06:00	1	0
07/09/2014 07:00	1	1
07/09/2014 08:00	1	1
07/09/2014 09:00	1	1
07/09/2014 10:00	1	1
07/09/2014 11:00	1	1
07/09/2014 12:00	1	1
07/09/2014 13:00	1	1
07/09/2014 14:00	1	1
07/09/2014 15:00	1	1
07/09/2014 16:00	1	1
07/09/2014 17:00	1	1
07/09/2014 18:00	1	1
07/09/2014 19:00	1	1
07/09/2014 20:00	1	1
07/09/2014 21:00	1	1
07/09/2014 22:00	1	1
07/09/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	0	0
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/10/2014 00:00	1	1
07/10/2014 01:00	1	1
07/10/2014 02:00	0	0
07/10/2014 03:00	0	0
07/10/2014 04:00	0	0
07/10/2014 05:00	0	0
07/10/2014 06:00	0	0
07/10/2014 07:00	0	0
07/10/2014 08:00	0	0
07/10/2014 09:00	1	1
07/10/2014 10:00	1	1
07/10/2014 11:00	1	1
07/10/2014 12:00	1	1
07/10/2014 13:00	1	1
07/10/2014 14:00	1	1
07/10/2014 15:00	1	1
07/10/2014 16:00	1	1
07/10/2014 17:00	1	1
07/10/2014 18:00	1	1
07/10/2014 19:00	1	1
07/10/2014 20:00	1	1
07/10/2014 21:00	1	1
07/10/2014 22:00	1	1
07/10/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	0	0
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/11/2014 00:00	1	3
07/11/2014 01:00	1	3
07/11/2014 02:00	1	3
07/11/2014 03:00	1	3
07/11/2014 04:00	1	3
07/11/2014 05:00	1	3
07/11/2014 06:00	3	3
07/11/2014 07:00	3	3
07/11/2014 08:00	2	3
07/11/2014 09:00	2	10
07/11/2014 10:00	0	15
07/11/2014 11:00	1	15
07/11/2014 12:00	1	13
07/11/2014 13:00	1	5
07/11/2014 14:00	1	1
07/11/2014 15:00	1	1
07/11/2014 16:00	1	1
07/11/2014 17:00	1	1
07/11/2014 18:00	1	1
07/11/2014 19:00	1	1
07/11/2014 20:00	1	1
07/11/2014 21:00	1	1
07/11/2014 22:00	0	1
07/11/2014 23:00	0	1
Average/Sum#:	1	4
Minimum:	0	1
Maximum:	3	15
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/12/2014 00:00	1	2
07/12/2014 01:00	1	2
07/12/2014 02:00	1	2
07/12/2014 03:00	1	2
07/12/2014 04:00	1	2
07/12/2014 05:00	1	2
07/12/2014 06:00	1	12
07/12/2014 07:00	1	15
07/12/2014 08:00	1	15
07/12/2014 09:00	1	13
07/12/2014 10:00	1	4
07/12/2014 11:00	10	1
07/12/2014 12:00	10	1
07/12/2014 13:00	10	1
07/12/2014 14:00	9	1
07/12/2014 15:00	1	1
07/12/2014 16:00	1	1
07/12/2014 17:00	1	1
07/12/2014 18:00	1	1
07/12/2014 19:00	1	1
07/12/2014 20:00	1	1
07/12/2014 21:00	1	1
07/12/2014 22:00	1	1
07/12/2014 23:00	1	1
Average/Sum#:	2	4
Minimum:	1	1
Maximum:	10	15
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/13/2014 00:00	1	1
07/13/2014 01:00	1	2
07/13/2014 02:00	1	2
07/13/2014 03:00	1	2
07/13/2014 04:00	1	2
07/13/2014 05:00	1	2
07/13/2014 06:00	7	2
07/13/2014 07:00	10	2
07/13/2014 08:00	10	2
07/13/2014 09:00	9	2
07/13/2014 10:00	3	12
07/13/2014 11:00	1	16
07/13/2014 12:00	1	16
07/13/2014 13:00	1	14
07/13/2014 14:00	1	5
07/13/2014 15:00	1	1
07/13/2014 16:00	1	1
07/13/2014 17:00	1	1
07/13/2014 18:00	1	1
07/13/2014 19:00	1	1
07/13/2014 20:00	1	1
07/13/2014 21:00	1	1
07/13/2014 22:00	1	1
07/13/2014 23:00	1	1
Average/Sum#:	2	4
Minimum:	1	1
Maximum:	10	16
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/14/2014 00:00	1	1
07/14/2014 01:00	1	1
07/14/2014 02:00	1	1
07/14/2014 03:00	1	1
07/14/2014 04:00	1	1
07/14/2014 05:00	1	1
07/14/2014 06:00	1	1
07/14/2014 07:00	1	1
07/14/2014 08:00	1	1
07/14/2014 09:00	1	1
07/14/2014 10:00	1	1
07/14/2014 11:00	1	1
07/14/2014 12:00	1	1
07/14/2014 13:00	1	1
07/14/2014 14:00	1	1
07/14/2014 15:00	1	1
07/14/2014 16:00	1	1
07/14/2014 17:00	1	1
07/14/2014 18:00	1	1
07/14/2014 19:00	1	1
07/14/2014 20:00	1	1
07/14/2014 21:00	1	1
07/14/2014 22:00	1	1
07/14/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/15/2014 00:00	1	1
07/15/2014 01:00	1	1
07/15/2014 02:00	1	1
07/15/2014 03:00	1	1
07/15/2014 04:00	1	1
07/15/2014 05:00	1	1
07/15/2014 06:00	1	1
07/15/2014 07:00	1	1
07/15/2014 08:00	1	1
07/15/2014 09:00	1	1
07/15/2014 10:00	1	1
07/15/2014 11:00	1	1
07/15/2014 12:00	1	1
07/15/2014 13:00	1	1
07/15/2014 14:00	1	1
07/15/2014 15:00	1	1
07/15/2014 16:00	1	1
07/15/2014 17:00	1	1
07/15/2014 18:00	1	1
07/15/2014 19:00	1	1
07/15/2014 20:00	1	1
07/15/2014 21:00	1	1
07/15/2014 22:00	1	1
07/15/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/16/2014 00:00	1	1
07/16/2014 01:00	1	1
07/16/2014 02:00	1	1
07/16/2014 03:00	1	1
07/16/2014 04:00	1	1
07/16/2014 05:00	1	1
07/16/2014 06:00	1	1
07/16/2014 07:00	1	1
07/16/2014 08:00	1	1
07/16/2014 09:00	1	1
07/16/2014 10:00	1	1
07/16/2014 11:00	1	1
07/16/2014 12:00	1	1
07/16/2014 13:00	1	1
07/16/2014 14:00	1	1
07/16/2014 15:00	1	1
07/16/2014 16:00	1	1
07/16/2014 17:00	1	1
07/16/2014 18:00	1	1
07/16/2014 19:00	1	1
07/16/2014 20:00	1	1
07/16/2014 21:00	1	1
07/16/2014 22:00	1	1
07/16/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/17/2014 00:00	1	2
07/17/2014 01:00	1	2
07/17/2014 02:00	1	2
07/17/2014 03:00	1	2
07/17/2014 04:00	1	6
07/17/2014 05:00	1	7
07/17/2014 06:00	1	7
07/17/2014 07:00	1	6
07/17/2014 08:00	8	3
07/17/2014 09:00	11	1
07/17/2014 10:00	11	1
07/17/2014 11:00	10	1
07/17/2014 12:00	4	1
07/17/2014 13:00	1	1
07/17/2014 14:00	1	1
07/17/2014 15:00	1	1
07/17/2014 16:00	1	1
07/17/2014 17:00	1	1
07/17/2014 18:00	1	1
07/17/2014 19:00	1	1
07/17/2014 20:00	1	1
07/17/2014 21:00	1	1
07/17/2014 22:00	1	1
07/17/2014 23:00	1	1
Average/Sum#:	3	2
Minimum:	1	1
Maximum:	11	7
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/18/2014 00:00	2	2
07/18/2014 01:00	2	2
07/18/2014 02:00	2	2
07/18/2014 03:00	2	3
07/18/2014 04:00	2	3
07/18/2014 05:00	2	3
07/18/2014 06:00	2	2
07/18/2014 07:00	2	1
07/18/2014 08:00	8	1
07/18/2014 09:00	8	1
07/18/2014 10:00	8	1
07/18/2014 11:00	8	1
07/18/2014 12:00	1	1
07/18/2014 13:00	1	1
07/18/2014 14:00	1	1
07/18/2014 15:00	1	1
07/18/2014 16:00	1	1
07/18/2014 17:00	1	1
07/18/2014 18:00	1	1
07/18/2014 19:00	1	1
07/18/2014 20:00	1	1
07/18/2014 21:00	1	1
07/18/2014 22:00	1	1
07/18/2014 23:00	1	1
Average/Sum#:	3	1
Minimum:	1	1
Maximum:	8	3
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/19/2014 00:00	1	2
07/19/2014 01:00	1	2
07/19/2014 02:00	1	2
07/19/2014 03:00	1	2
07/19/2014 04:00	1	2
07/19/2014 05:00	10	2
07/19/2014 06:00	12	2
07/19/2014 07:00	12	2
07/19/2014 08:00	11	2
07/19/2014 09:00	3	11
07/19/2014 10:00	1	15
07/19/2014 11:00	1	15
07/19/2014 12:00	1	14
07/19/2014 13:00	1	5
07/19/2014 14:00	1	1
07/19/2014 15:00	1	1
07/19/2014 16:00	1	1
07/19/2014 17:00	1	1
07/19/2014 18:00	1	1
07/19/2014 19:00	1	1
07/19/2014 20:00	1	1
07/19/2014 21:00	1	1
07/19/2014 22:00	1	1
07/19/2014 23:00	1	1
Average/Sum#:	3	4
Minimum:	1	1
Maximum:	12	15
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/20/2014 00:00	1	2
07/20/2014 01:00	1	2
07/20/2014 02:00	1	2
07/20/2014 03:00	1	2
07/20/2014 04:00	1	2
07/20/2014 05:00	1	2
07/20/2014 06:00	1	2
07/20/2014 07:00	1	2
07/20/2014 08:00	1	2
07/20/2014 09:00	1	2
07/20/2014 10:00	1	2
07/20/2014 11:00	1	2
07/20/2014 12:00	1	2
07/20/2014 13:00	1	2
07/20/2014 14:00	1	2
07/20/2014 15:00	1	2
07/20/2014 16:00	1	2
07/20/2014 17:00	1	2
07/20/2014 18:00	1	2
07/20/2014 19:00	1	2
07/20/2014 20:00	1	2
07/20/2014 21:00	1	2
07/20/2014 22:00	1	2
07/20/2014 23:00	1	2
Average/Sum#:	1	2
Minimum:	1	2
Maximum:	1	2
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/21/2014 00:00	1	2
07/21/2014 01:00	1	15
07/21/2014 02:00	1	19
07/21/2014 03:00	1	21
07/21/2014 04:00	1	20
07/21/2014 05:00	1	7
07/21/2014 06:00	13	3
07/21/2014 07:00	16	1
07/21/2014 08:00	16	1
07/21/2014 09:00	15	1
07/21/2014 10:00	3	1
07/21/2014 11:00	1	1
07/21/2014 12:00	1	1
07/21/2014 13:00	1	1
07/21/2014 14:00	1	1
07/21/2014 15:00	1	1
07/21/2014 16:00	1	1
07/21/2014 17:00	1	1
07/21/2014 18:00	1	1
07/21/2014 19:00	1	1
07/21/2014 20:00	1	1
07/21/2014 21:00	1	1
07/21/2014 22:00	1	1
07/21/2014 23:00	1	1
Average/Sum#:	3	4
Minimum:	1	1
Maximum:	16	21
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/22/2014 00:00	1	1
07/22/2014 01:00	1	1
07/22/2014 02:00	1	1
07/22/2014 03:00	1	1
07/22/2014 04:00	1	1
07/22/2014 05:00	1	1
07/22/2014 06:00	1	1
07/22/2014 07:00	1	1
07/22/2014 08:00	1	1
07/22/2014 09:00	1	1
07/22/2014 10:00	1	1
07/22/2014 11:00	1	1
07/22/2014 12:00	1	1
07/22/2014 13:00	1	1
07/22/2014 14:00	1	1
07/22/2014 15:00	1	1
07/22/2014 16:00	1	1
07/22/2014 17:00	1	1
07/22/2014 18:00	1	1
07/22/2014 19:00	1	1
07/22/2014 20:00	1	1
07/22/2014 21:00	1	1
07/22/2014 22:00	1	1
07/22/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/23/2014 00:00	1	1
07/23/2014 01:00	1	1
07/23/2014 02:00	1	1
07/23/2014 03:00	1	1
07/23/2014 04:00	1	1
07/23/2014 05:00	1	1
07/23/2014 06:00	1	1
07/23/2014 07:00	1	1
07/23/2014 08:00	0	1
07/23/2014 09:00	0	1
07/23/2014 10:00	0	1
07/23/2014 11:00	0	1
07/23/2014 12:00	1	1
07/23/2014 13:00	1	1
07/23/2014 14:00	1	1
07/23/2014 15:00	1	1
07/23/2014 16:00	1	1
07/23/2014 17:00	1	1
07/23/2014 18:00	1	1
07/23/2014 19:00	1	1
07/23/2014 20:00	1	1
07/23/2014 21:00	1	1
07/23/2014 22:00	1	1
07/23/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	17	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/24/2014 00:00	1	1
07/24/2014 01:00	1	1
07/24/2014 02:00	1	1
07/24/2014 03:00	1	1
07/24/2014 04:00	1	1
07/24/2014 05:00	1	1
07/24/2014 06:00	1	1
07/24/2014 07:00	1	1
07/24/2014 08:00	1	1
07/24/2014 09:00	1	1
07/24/2014 10:00	1	1
07/24/2014 11:00	1	1
07/24/2014 12:00	1	1
07/24/2014 13:00	1	1
07/24/2014 14:00	1	1
07/24/2014 15:00	1	1
07/24/2014 16:00	1	1
07/24/2014 17:00	1	1
07/24/2014 18:00	1	1
07/24/2014 19:00	1	1
07/24/2014 20:00	1	1
07/24/2014 21:00	1	1
07/24/2014 22:00	1	1
07/24/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/25/2014 00:00	1	1
07/25/2014 01:00	1	1
07/25/2014 02:00	1	1
07/25/2014 03:00	1	1
07/25/2014 04:00	1	1
07/25/2014 05:00	1	1
07/25/2014 06:00	1	1
07/25/2014 07:00	1	1
07/25/2014 08:00	1	1
07/25/2014 09:00	1	1
07/25/2014 10:00	1	1
07/25/2014 11:00	1	1
07/25/2014 12:00	1	1
07/25/2014 13:00	1	1
07/25/2014 14:00	1	1
07/25/2014 15:00	1	1
07/25/2014 16:00	1	1
07/25/2014 17:00	1	1
07/25/2014 18:00	1	1
07/25/2014 19:00	1	1
07/25/2014 20:00	1	1
07/25/2014 21:00	1	1
07/25/2014 22:00	1	1
07/25/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/26/2014 00:00	1	1
07/26/2014 01:00	1	1
07/26/2014 02:00	1	1
07/26/2014 03:00	1	1
07/26/2014 04:00	1	1
07/26/2014 05:00	1	1
07/26/2014 06:00	1	1
07/26/2014 07:00	1	1
07/26/2014 08:00	1	1
07/26/2014 09:00	1	1
07/26/2014 10:00	1	1
07/26/2014 11:00	1	1
07/26/2014 12:00	1	1
07/26/2014 13:00	1	1
07/26/2014 14:00	1	1
07/26/2014 15:00	1	1
07/26/2014 16:00	1	1
07/26/2014 17:00	1	1
07/26/2014 18:00	1	1
07/26/2014 19:00	1	1
07/26/2014 20:00	1	1
07/26/2014 21:00	1	1
07/26/2014 22:00	1	1
07/26/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/27/2014 00:00	1	1
07/27/2014 01:00	1	1
07/27/2014 02:00	1	1
07/27/2014 03:00	1	1
07/27/2014 04:00	1	1
07/27/2014 05:00	1	1
07/27/2014 06:00	1	1
07/27/2014 07:00	1	1
07/27/2014 08:00	1	1
07/27/2014 09:00	1	1
07/27/2014 10:00	1	1
07/27/2014 11:00	1	1
07/27/2014 12:00	1	1
07/27/2014 13:00	1	1
07/27/2014 14:00	1	1
07/27/2014 15:00	1	1
07/27/2014 16:00	1	1
07/27/2014 17:00	1	1
07/27/2014 18:00	1	1
07/27/2014 19:00	1	1
07/27/2014 20:00	1	1
07/27/2014 21:00	1	1
07/27/2014 22:00	1	1
07/27/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/28/2014 00:00	1	1
07/28/2014 01:00	1	1
07/28/2014 02:00	1	1
07/28/2014 03:00	1	1
07/28/2014 04:00	1	1
07/28/2014 05:00	1	1
07/28/2014 06:00	1	1
07/28/2014 07:00	1	1
07/28/2014 08:00	1	1
07/28/2014 09:00	1	1
07/28/2014 10:00	1	1
07/28/2014 11:00	1	1
07/28/2014 12:00	1	1
07/28/2014 13:00	1	1
07/28/2014 14:00	1	1
07/28/2014 15:00	1	1
07/28/2014 16:00	1	1
07/28/2014 17:00	1	1
07/28/2014 18:00	1	1
07/28/2014 19:00	1	1
07/28/2014 20:00	1	1
07/28/2014 21:00	1	1
07/28/2014 22:00	1	1
07/28/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/29/2014 00:00	1	1
07/29/2014 01:00	1	1
07/29/2014 02:00	1	1
07/29/2014 03:00	1	1
07/29/2014 04:00	1	1
07/29/2014 05:00	1	1
07/29/2014 06:00	1	1
07/29/2014 07:00	1	1
07/29/2014 08:00	1	1
07/29/2014 09:00	1	1
07/29/2014 10:00	1	1
07/29/2014 11:00	1	1
07/29/2014 12:00	1	1
07/29/2014 13:00	1	1
07/29/2014 14:00	1	1
07/29/2014 15:00	1	1
07/29/2014 16:00	1	1
07/29/2014 17:00	1	1
07/29/2014 18:00	1	1
07/29/2014 19:00	1	1
07/29/2014 20:00	1	1
07/29/2014 21:00	1	1
07/29/2014 22:00	1	1
07/29/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/30/2014 00:00	1	1
07/30/2014 01:00	1	1
07/30/2014 02:00	1	1
07/30/2014 03:00	1	1
07/30/2014 04:00	1	1
07/30/2014 05:00	1	1
07/30/2014 06:00	1	1
07/30/2014 07:00	1	1
07/30/2014 08:00	1	1
07/30/2014 09:00	1	1
07/30/2014 10:00	1	1
07/30/2014 11:00	1	1
07/30/2014 12:00	1	1
07/30/2014 13:00	1	1
07/30/2014 14:00	1	1
07/30/2014 15:00	1	1
07/30/2014 16:00	1	1
07/30/2014 17:00	1	1
07/30/2014 18:00	1	1
07/30/2014 19:00	1	1
07/30/2014 20:00	1	1
07/30/2014 21:00	1	1
07/30/2014 22:00	1	1
07/30/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
07/31/2014 00:00	1	1
07/31/2014 01:00	1	1
07/31/2014 02:00	1	1
07/31/2014 03:00	1	1
07/31/2014 04:00	1	1
07/31/2014 05:00	1	1
07/31/2014 06:00	1	1
07/31/2014 07:00	1	1
07/31/2014 08:00	1	1
07/31/2014 09:00	1	1
07/31/2014 10:00	1	1
07/31/2014 11:00	1	1
07/31/2014 12:00	1	1
07/31/2014 13:00	1	1
07/31/2014 14:00	1	1
07/31/2014 15:00	1	1
07/31/2014 16:00	1	1
07/31/2014 17:00	1	1
07/31/2014 18:00	1	1
07/31/2014 19:00	1	1
07/31/2014 20:00	1	1
07/31/2014 21:00	1	1
07/31/2014 22:00	1	1
07/31/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/01/2014 00:00	1	1
08/01/2014 01:00	1	1
08/01/2014 02:00	1	1
08/01/2014 03:00	1	1
08/01/2014 04:00	1	1
08/01/2014 05:00	1	1
08/01/2014 06:00	1	1
08/01/2014 07:00	1	1
08/01/2014 08:00	1	1
08/01/2014 09:00	1	1
08/01/2014 10:00	1	1
08/01/2014 11:00	1	1
08/01/2014 12:00	1	1
08/01/2014 13:00	1	1
08/01/2014 14:00	1	1
08/01/2014 15:00	1	1
08/01/2014 16:00	1	1
08/01/2014 17:00	1	1
08/01/2014 18:00	1	1
08/01/2014 19:00	1	1
08/01/2014 20:00	1	1
08/01/2014 21:00	1	1
08/01/2014 22:00	1	1
08/01/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/02/2014 00:00	1	1
08/02/2014 01:00	1	1
08/02/2014 02:00	1	1
08/02/2014 03:00	1	1
08/02/2014 04:00	1	1
08/02/2014 05:00	1	1
08/02/2014 06:00	1	1
08/02/2014 07:00	1	1
08/02/2014 08:00	1	1
08/02/2014 09:00	1	1
08/02/2014 10:00	1	1
08/02/2014 11:00	1	1
08/02/2014 12:00	1	1
08/02/2014 13:00	1	1
08/02/2014 14:00	1	1
08/02/2014 15:00	1	1
08/02/2014 16:00	1	1
08/02/2014 17:00	1	1
08/02/2014 18:00	1	1
08/02/2014 19:00	1	1
08/02/2014 20:00	1	1
08/02/2014 21:00	1	1
08/02/2014 22:00	1	1
08/02/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/03/2014 00:00	1	1
08/03/2014 01:00	1	1
08/03/2014 02:00	1	1
08/03/2014 03:00	1	1
08/03/2014 04:00	1	1
08/03/2014 05:00	1	1
08/03/2014 06:00	1	1
08/03/2014 07:00	1	1
08/03/2014 08:00	1	1
08/03/2014 09:00	1	1
08/03/2014 10:00	1	1
08/03/2014 11:00	1	1
08/03/2014 12:00	1	1
08/03/2014 13:00	1	1
08/03/2014 14:00	1	1
08/03/2014 15:00	1	1
08/03/2014 16:00	1	1
08/03/2014 17:00	1	1
08/03/2014 18:00	1	1
08/03/2014 19:00	1	1
08/03/2014 20:00	1	1
08/03/2014 21:00	1	1
08/03/2014 22:00	1	1
08/03/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/04/2014 00:00	1	1
08/04/2014 01:00	1	1
08/04/2014 02:00	1	1
08/04/2014 03:00	1	1
08/04/2014 04:00	1	1
08/04/2014 05:00	1	1
08/04/2014 06:00	1	1
08/04/2014 07:00	1	1
08/04/2014 08:00	1	1
08/04/2014 09:00	1	1
08/04/2014 10:00	1	1
08/04/2014 11:00	1	1
08/04/2014 12:00	1	1
08/04/2014 13:00	1	1
08/04/2014 14:00	1	1
08/04/2014 15:00	1	1
08/04/2014 16:00	1	1
08/04/2014 17:00	1	1
08/04/2014 18:00	1	1
08/04/2014 19:00	1	1
08/04/2014 20:00	1	1
08/04/2014 21:00	1	1
08/04/2014 22:00	1	1
08/04/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/05/2014 00:00	1	1
08/05/2014 01:00	1	1
08/05/2014 02:00	1	1
08/05/2014 03:00	1	1
08/05/2014 04:00	1	1
08/05/2014 05:00	1	1
08/05/2014 06:00	1	1
08/05/2014 07:00	1	1
08/05/2014 08:00	1	1
08/05/2014 09:00	1	1
08/05/2014 10:00	1	1
08/05/2014 11:00	1	1
08/05/2014 12:00	1	1
08/05/2014 13:00	1	1
08/05/2014 14:00	1	1
08/05/2014 15:00	1	1
08/05/2014 16:00	1	1
08/05/2014 17:00	1	1
08/05/2014 18:00	1	1
08/05/2014 19:00	1	1
08/05/2014 20:00	1	1
08/05/2014 21:00	1	1
08/05/2014 22:00	1	1
08/05/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/06/2014 00:00	1	1
08/06/2014 01:00	1	1
08/06/2014 02:00	1	1
08/06/2014 03:00	1	1
08/06/2014 04:00	1	1
08/06/2014 05:00	1	1
08/06/2014 06:00	1	1
08/06/2014 07:00	1	1
08/06/2014 08:00	1	1
08/06/2014 09:00	1	1
08/06/2014 10:00	1	1
08/06/2014 11:00	1	1
08/06/2014 12:00	1	1
08/06/2014 13:00	1	1
08/06/2014 14:00	1	1
08/06/2014 15:00	1	1
08/06/2014 16:00	1	1
08/06/2014 17:00	1	1
08/06/2014 18:00	1	1
08/06/2014 19:00	1	1
08/06/2014 20:00	1	1
08/06/2014 21:00	1	1
08/06/2014 22:00	1	1
08/06/2014 23:00	2	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	2	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/07/2014 00:00	2	1
08/07/2014 01:00	2	1
08/07/2014 02:00	2	1
08/07/2014 03:00	2	1
08/07/2014 04:00	2	1
08/07/2014 05:00	2	1
08/07/2014 06:00	2	1
08/07/2014 07:00	2	8
08/07/2014 08:00	2	10
08/07/2014 09:00	2	10
08/07/2014 10:00	2	10
08/07/2014 11:00	2	3
08/07/2014 12:00	2	1
08/07/2014 13:00	10	1
08/07/2014 14:00	16	1
08/07/2014 15:00	16	1
08/07/2014 16:00	15	1
08/07/2014 17:00	7	1
08/07/2014 18:00	1	1
08/07/2014 19:00	1	1
08/07/2014 20:00	1	1
08/07/2014 21:00	1	1
08/07/2014 22:00	1	1
08/07/2014 23:00	1	1
Average/Sum#:	4	3
Minimum:	1	1
Maximum:	16	10
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/08/2014 00:00	1	1
08/08/2014 01:00	1	1
08/08/2014 02:00	1	1
08/08/2014 03:00	1	1
08/08/2014 04:00	1	1
08/08/2014 05:00	1	1
08/08/2014 06:00	1	1
08/08/2014 07:00	1	1
08/08/2014 08:00	1	1
08/08/2014 09:00	1	1
08/08/2014 10:00	1	1
08/08/2014 11:00	1	1
08/08/2014 12:00	1	1
08/08/2014 13:00	1	1
08/08/2014 14:00	1	1
08/08/2014 15:00	1	1
08/08/2014 16:00	1	1
08/08/2014 17:00	1	1
08/08/2014 18:00	1	1
08/08/2014 19:00	1	1
08/08/2014 20:00	1	1
08/08/2014 21:00	1	1
08/08/2014 22:00	1	1
08/08/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/09/2014 00:00	1	1
08/09/2014 01:00	1	1
08/09/2014 02:00	1	2
08/09/2014 03:00	1	2
08/09/2014 04:00	1	2
08/09/2014 05:00	1	2
08/09/2014 06:00	1	7
08/09/2014 07:00	1	8
08/09/2014 08:00	1	8
08/09/2014 09:00	1	6
08/09/2014 10:00	7	2
08/09/2014 11:00	9	1
08/09/2014 12:00	9	1
08/09/2014 13:00	8	1
08/09/2014 14:00	2	1
08/09/2014 15:00	1	1
08/09/2014 16:00	1	1
08/09/2014 17:00	1	1
08/09/2014 18:00	1	1
08/09/2014 19:00	1	1
08/09/2014 20:00	1	1
08/09/2014 21:00	1	1
08/09/2014 22:00	1	1
08/09/2014 23:00	1	1
Average/Sum#:	2	2
Minimum:	1	1
Maximum:	9	8
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/10/2014 00:00	2	2
08/10/2014 01:00	2	2
08/10/2014 02:00	2	2
08/10/2014 03:00	2	2
08/10/2014 04:00	2	2
08/10/2014 05:00	2	2
08/10/2014 06:00	2	2
08/10/2014 07:00	2	9
08/10/2014 08:00	2	11
08/10/2014 09:00	2	11
08/10/2014 10:00	2	10
08/10/2014 11:00	9	2
08/10/2014 12:00	11	1
08/10/2014 13:00	11	1
08/10/2014 14:00	10	1
08/10/2014 15:00	2	1
08/10/2014 16:00	1	1
08/10/2014 17:00	1	1
08/10/2014 18:00	1	1
08/10/2014 19:00	1	1
08/10/2014 20:00	1	1
08/10/2014 21:00	1	1
08/10/2014 22:00	1	1
08/10/2014 23:00	1	1
Average/Sum#:	3	3
Minimum:	1	1
Maximum:	11	11
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/11/2014 00:00	1	1
08/11/2014 01:00	1	1
08/11/2014 02:00	1	1
08/11/2014 03:00	1	1
08/11/2014 04:00	1	1
08/11/2014 05:00	1	1
08/11/2014 06:00	1	1
08/11/2014 07:00	1	1
08/11/2014 08:00	1	1
08/11/2014 09:00	1	1
08/11/2014 10:00	1	1
08/11/2014 11:00	1	1
08/11/2014 12:00	1	1
08/11/2014 13:00	1	1
08/11/2014 14:00	1	1
08/11/2014 15:00	1	1
08/11/2014 16:00	1	1
08/11/2014 17:00	1	1
08/11/2014 18:00	1	1
08/11/2014 19:00	1	1
08/11/2014 20:00	1	1
08/11/2014 21:00	1	1
08/11/2014 22:00	1	1
08/11/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/12/2014 00:00	1	1
08/12/2014 01:00	1	1
08/12/2014 02:00	1	1
08/12/2014 03:00	1	1
08/12/2014 04:00	1	1
08/12/2014 05:00	1	1
08/12/2014 06:00	1	1
08/12/2014 07:00	1	1
08/12/2014 08:00	1	1
08/12/2014 09:00	1	1
08/12/2014 10:00	1	1
08/12/2014 11:00	1	1
08/12/2014 12:00	1	1
08/12/2014 13:00	1	1
08/12/2014 14:00	1	1
08/12/2014 15:00	1	1
08/12/2014 16:00	1	1
08/12/2014 17:00	1	1
08/12/2014 18:00	1	1
08/12/2014 19:00	1	1
08/12/2014 20:00	1	1
08/12/2014 21:00	1	1
08/12/2014 22:00	1	1
08/12/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/13/2014 00:00	1	1
08/13/2014 01:00	1	1
08/13/2014 02:00	1	1
08/13/2014 03:00	1	1
08/13/2014 04:00	1	1
08/13/2014 05:00	1	4
08/13/2014 06:00	1	5
08/13/2014 07:00	1	5
08/13/2014 08:00	7	5
08/13/2014 09:00	9	2
08/13/2014 10:00	9	1
08/13/2014 11:00	9	1
08/13/2014 12:00	2	1
08/13/2014 13:00	1	1
08/13/2014 14:00	1	1
08/13/2014 15:00	1	1
08/13/2014 16:00	1	1
08/13/2014 17:00	1	1
08/13/2014 18:00	1	1
08/13/2014 19:00	1	1
08/13/2014 20:00	1	1
08/13/2014 21:00	1	1
08/13/2014 22:00	1	1
08/13/2014 23:00	1	1
Average/Sum#:	2	2
Minimum:	1	1
Maximum:	9	5
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/14/2014 00:00	1	1
08/14/2014 01:00	1	1
08/14/2014 02:00	1	1
08/14/2014 03:00	1	1
08/14/2014 04:00	1	1
08/14/2014 05:00	1	1
08/14/2014 06:00	1	1
08/14/2014 07:00	1	1
08/14/2014 08:00	1	1
08/14/2014 09:00	1	1
08/14/2014 10:00	1	1
08/14/2014 11:00	1	1
08/14/2014 12:00	1	1
08/14/2014 13:00	1	1
08/14/2014 14:00	1	1
08/14/2014 15:00	1	1
08/14/2014 16:00	1	1
08/14/2014 17:00	1	1
08/14/2014 18:00	1	1
08/14/2014 19:00	1	1
08/14/2014 20:00	1	1
08/14/2014 21:00	1	1
08/14/2014 22:00	1	1
08/14/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/15/2014 00:00	1	1
08/15/2014 01:00	1	1
08/15/2014 02:00	1	1
08/15/2014 03:00	1	1
08/15/2014 04:00	1	1
08/15/2014 05:00	1	1
08/15/2014 06:00	1	1
08/15/2014 07:00	1	1
08/15/2014 08:00	1	1
08/15/2014 09:00	1	1
08/15/2014 10:00	1	1
08/15/2014 11:00	1	1
08/15/2014 12:00	1	1
08/15/2014 13:00	1	1
08/15/2014 14:00	1	1
08/15/2014 15:00	1	1
08/15/2014 16:00	1	1
08/15/2014 17:00	1	1
08/15/2014 18:00	1	1
08/15/2014 19:00	1	1
08/15/2014 20:00	1	1
08/15/2014 21:00	1	1
08/15/2014 22:00	1	1
08/15/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/16/2014 00:00	1	1
08/16/2014 01:00	1	1
08/16/2014 02:00	1	1
08/16/2014 03:00	1	1
08/16/2014 04:00	1	1
08/16/2014 05:00	1	1
08/16/2014 06:00	1	1
08/16/2014 07:00	1	1
08/16/2014 08:00	1	1
08/16/2014 09:00	1	1
08/16/2014 10:00	1	1
08/16/2014 11:00	1	1
08/16/2014 12:00	1	1
08/16/2014 13:00	1	1
08/16/2014 14:00	1	1
08/16/2014 15:00	1	1
08/16/2014 16:00	1	1
08/16/2014 17:00	1	1
08/16/2014 18:00	1	1
08/16/2014 19:00	1	1
08/16/2014 20:00	1	1
08/16/2014 21:00	1	1
08/16/2014 22:00	1	1
08/16/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/17/2014 00:00	1	1
08/17/2014 01:00	1	1
08/17/2014 02:00	1	1
08/17/2014 03:00	1	1
08/17/2014 04:00	1	1
08/17/2014 05:00	1	1
08/17/2014 06:00	1	1
08/17/2014 07:00	1	1
08/17/2014 08:00	1	1
08/17/2014 09:00	1	1
08/17/2014 10:00	1	1
08/17/2014 11:00	1	1
08/17/2014 12:00	1	1
08/17/2014 13:00	1	1
08/17/2014 14:00	1	1
08/17/2014 15:00	1	1
08/17/2014 16:00	1	1
08/17/2014 17:00	1	1
08/17/2014 18:00	1	1
08/17/2014 19:00	1	1
08/17/2014 20:00	1	1
08/17/2014 21:00	1	1
08/17/2014 22:00	1	1
08/17/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/18/2014 00:00	1	1
08/18/2014 01:00	1	1
08/18/2014 02:00	1	1
08/18/2014 03:00	1	1
08/18/2014 04:00	1	1
08/18/2014 05:00	1	1
08/18/2014 06:00	1	1
08/18/2014 07:00	1	1
08/18/2014 08:00	1	1
08/18/2014 09:00	1	1
08/18/2014 10:00	1	1
08/18/2014 11:00	1	1
08/18/2014 12:00	1	1
08/18/2014 13:00	1	1
08/18/2014 14:00	1	1
08/18/2014 15:00	1	1
08/18/2014 16:00	1	1
08/18/2014 17:00	1	1
08/18/2014 18:00	1	1
08/18/2014 19:00	1	1
08/18/2014 20:00	1	1
08/18/2014 21:00	1	1
08/18/2014 22:00	1	1
08/18/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/19/2014 00:00	1	1
08/19/2014 01:00	1	1
08/19/2014 02:00	1	1
08/19/2014 03:00	1	1
08/19/2014 04:00	1	1
08/19/2014 05:00	1	1
08/19/2014 06:00	1	1
08/19/2014 07:00	1	1
08/19/2014 08:00	1	1
08/19/2014 09:00	1	1
08/19/2014 10:00	1	1
08/19/2014 11:00	1	1
08/19/2014 12:00	1	1
08/19/2014 13:00	1	1
08/19/2014 14:00	1	1
08/19/2014 15:00	1	1
08/19/2014 16:00	1	1
08/19/2014 17:00	1	1
08/19/2014 18:00	1	1
08/19/2014 19:00	1	1
08/19/2014 20:00	1	1
08/19/2014 21:00	1	1
08/19/2014 22:00	1	1
08/19/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/20/2014 00:00	1	1
08/20/2014 01:00	1	1
08/20/2014 02:00	1	1
08/20/2014 03:00	1	1
08/20/2014 04:00	1	1
08/20/2014 05:00	1	1
08/20/2014 06:00	1	1
08/20/2014 07:00	1	1
08/20/2014 08:00	1	1
08/20/2014 09:00	1	1
08/20/2014 10:00	1	1
08/20/2014 11:00	1	1
08/20/2014 12:00	1	1
08/20/2014 13:00	1	1
08/20/2014 14:00	1	1
08/20/2014 15:00	1	1
08/20/2014 16:00	1	1
08/20/2014 17:00	1	1
08/20/2014 18:00	1	1
08/20/2014 19:00	1	1
08/20/2014 20:00	1	1
08/20/2014 21:00	1	1
08/20/2014 22:00	1	1
08/20/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/21/2014 00:00	1	1
08/21/2014 01:00	1	1
08/21/2014 02:00	1	1
08/21/2014 03:00	1	1
08/21/2014 04:00	1	1
08/21/2014 05:00	1	1
08/21/2014 06:00	1	1
08/21/2014 07:00	1	1
08/21/2014 08:00	1	1
08/21/2014 09:00	1	1
08/21/2014 10:00	1	1
08/21/2014 11:00	1	1
08/21/2014 12:00	1	1
08/21/2014 13:00	1	1
08/21/2014 14:00	1	1
08/21/2014 15:00	1	1
08/21/2014 16:00	1	1
08/21/2014 17:00	1	1
08/21/2014 18:00	1	1
08/21/2014 19:00	1	1
08/21/2014 20:00	1	1
08/21/2014 21:00	1	1
08/21/2014 22:00	1	1
08/21/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/22/2014 00:00	1	1
08/22/2014 01:00	1	1
08/22/2014 02:00	1	1
08/22/2014 03:00	1	1
08/22/2014 04:00	1	1
08/22/2014 05:00	1	1
08/22/2014 06:00	1	1
08/22/2014 07:00	1	1
08/22/2014 08:00	1	1
08/22/2014 09:00	1	1
08/22/2014 10:00	1	1
08/22/2014 11:00	1	1
08/22/2014 12:00	1	1
08/22/2014 13:00	1	1
08/22/2014 14:00	1	1
08/22/2014 15:00	1	1
08/22/2014 16:00	1	1
08/22/2014 17:00	1	1
08/22/2014 18:00	1	1
08/22/2014 19:00	1	1
08/22/2014 20:00	1	1
08/22/2014 21:00	1	1
08/22/2014 22:00	1	1
08/22/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/23/2014 00:00	1	1
08/23/2014 01:00	1	1
08/23/2014 02:00	1	1
08/23/2014 03:00	1	1
08/23/2014 04:00	1	1
08/23/2014 05:00	1	1
08/23/2014 06:00	1	1
08/23/2014 07:00	1	1
08/23/2014 08:00	1	1
08/23/2014 09:00	1	1
08/23/2014 10:00	1	1
08/23/2014 11:00	1	1
08/23/2014 12:00	1	1
08/23/2014 13:00	1	1
08/23/2014 14:00	1	1
08/23/2014 15:00	1	1
08/23/2014 16:00	1	1
08/23/2014 17:00	1	1
08/23/2014 18:00	1	1
08/23/2014 19:00	1	1
08/23/2014 20:00	1	1
08/23/2014 21:00	1	1
08/23/2014 22:00	1	1
08/23/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/24/2014 00:00	1	1
08/24/2014 01:00	1	1
08/24/2014 02:00	1	1
08/24/2014 03:00	1	1
08/24/2014 04:00	1	1
08/24/2014 05:00	1	1
08/24/2014 06:00	1	1
08/24/2014 07:00	1	1
08/24/2014 08:00	1	1
08/24/2014 09:00	1	1
08/24/2014 10:00	1	1
08/24/2014 11:00	1	1
08/24/2014 12:00	1	1
08/24/2014 13:00	1	1
08/24/2014 14:00	1	1
08/24/2014 15:00	1	1
08/24/2014 16:00	1	1
08/24/2014 17:00	1	1
08/24/2014 18:00	1	1
08/24/2014 19:00	1	1
08/24/2014 20:00	1	1
08/24/2014 21:00	1	1
08/24/2014 22:00	1	1
08/24/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/25/2014 00:00	1	1
08/25/2014 01:00	1	1
08/25/2014 02:00	1	1
08/25/2014 03:00	1	1
08/25/2014 04:00	1	1
08/25/2014 05:00	1	1
08/25/2014 06:00	1	1
08/25/2014 07:00	1	1
08/25/2014 08:00	1	1
08/25/2014 09:00	1	1
08/25/2014 10:00	1	1
08/25/2014 11:00	1	1
08/25/2014 12:00	1	1
08/25/2014 13:00	1	1
08/25/2014 14:00	1	1
08/25/2014 15:00	1	1
08/25/2014 16:00	1	1
08/25/2014 17:00	1	1
08/25/2014 18:00	1	1
08/25/2014 19:00	1	1
08/25/2014 20:00	1	1
08/25/2014 21:00	1	1
08/25/2014 22:00	1	1
08/25/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/26/2014 00:00	1	1
08/26/2014 01:00	1	1
08/26/2014 02:00	1	1
08/26/2014 03:00	1	1
08/26/2014 04:00	1	1
08/26/2014 05:00	1	1
08/26/2014 06:00	1	1
08/26/2014 07:00	1	1
08/26/2014 08:00	1	1
08/26/2014 09:00	1	1
08/26/2014 10:00	1	1
08/26/2014 11:00	1	1
08/26/2014 12:00	1	1
08/26/2014 13:00	1	1
08/26/2014 14:00	1	1
08/26/2014 15:00	1	1
08/26/2014 16:00	1	1
08/26/2014 17:00	1	1
08/26/2014 18:00	1	1
08/26/2014 19:00	1	1
08/26/2014 20:00	1	1
08/26/2014 21:00	1	1
08/26/2014 22:00	1	1
08/26/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/27/2014 00:00	1	1
08/27/2014 01:00	1	1
08/27/2014 02:00	1	1
08/27/2014 03:00	1	1
08/27/2014 04:00	1	1
08/27/2014 05:00	1	1
08/27/2014 06:00	1	1
08/27/2014 07:00	1	1
08/27/2014 08:00	1	1
08/27/2014 09:00	1	1
08/27/2014 10:00	1	1
08/27/2014 11:00	1	1
08/27/2014 12:00	1	1
08/27/2014 13:00	1	1
08/27/2014 14:00	1	1
08/27/2014 15:00	1	1
08/27/2014 16:00	1	1
08/27/2014 17:00	1	1
08/27/2014 18:00	1	1
08/27/2014 19:00	1	1
08/27/2014 20:00	1	1
08/27/2014 21:00	1	1
08/27/2014 22:00	1	1
08/27/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/28/2014 00:00	1	1
08/28/2014 01:00	1	1
08/28/2014 02:00	1	1
08/28/2014 03:00	1	1
08/28/2014 04:00	1	1
08/28/2014 05:00	1	1
08/28/2014 06:00	1	1
08/28/2014 07:00	1	1
08/28/2014 08:00	1	1
08/28/2014 09:00	1	1
08/28/2014 10:00	1	1
08/28/2014 11:00	1	1
08/28/2014 12:00	1	1
08/28/2014 13:00	1	1
08/28/2014 14:00	1	1
08/28/2014 15:00	1	1
08/28/2014 16:00	1	1
08/28/2014 17:00	1	1
08/28/2014 18:00	1	1
08/28/2014 19:00	1	1
08/28/2014 20:00	1	1
08/28/2014 21:00	1	1
08/28/2014 22:00	1	1
08/28/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/29/2014 00:00	1	1
08/29/2014 01:00	1	1
08/29/2014 02:00	1	1
08/29/2014 03:00	1	1
08/29/2014 04:00	1	1
08/29/2014 05:00	1	1
08/29/2014 06:00	1	1
08/29/2014 07:00	1	1
08/29/2014 08:00	1	1
08/29/2014 09:00	1	1
08/29/2014 10:00	1	1
08/29/2014 11:00	1	1
08/29/2014 12:00	1	1
08/29/2014 13:00	1	1
08/29/2014 14:00	1	1
08/29/2014 15:00	1	1
08/29/2014 16:00	1	1
08/29/2014 17:00	1	1
08/29/2014 18:00	1	1
08/29/2014 19:00	1	1
08/29/2014 20:00	1	1
08/29/2014 21:00	1	1
08/29/2014 22:00	1	1
08/29/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/30/2014 00:00	1	1
08/30/2014 01:00	1	1
08/30/2014 02:00	1	1
08/30/2014 03:00	1	1
08/30/2014 04:00	1	1
08/30/2014 05:00	1	1
08/30/2014 06:00	1	1
08/30/2014 07:00	1	1
08/30/2014 08:00	1	1
08/30/2014 09:00	1	1
08/30/2014 10:00	1	1
08/30/2014 11:00	1	1
08/30/2014 12:00	1	1
08/30/2014 13:00	1	1
08/30/2014 14:00	1	1
08/30/2014 15:00	1	1
08/30/2014 16:00	1	1
08/30/2014 17:00	1	1
08/30/2014 18:00	1	1
08/30/2014 19:00	1	1
08/30/2014 20:00	1	1
08/30/2014 21:00	1	1
08/30/2014 22:00	1	1
08/30/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
08/31/2014 00:00	1	1
08/31/2014 01:00	1	1
08/31/2014 02:00	1	1
08/31/2014 03:00	1	1
08/31/2014 04:00	1	1
08/31/2014 05:00	1	1
08/31/2014 06:00	1	1
08/31/2014 07:00	1	1
08/31/2014 08:00	1	1
08/31/2014 09:00	1	1
08/31/2014 10:00	1	1
08/31/2014 11:00	1	1
08/31/2014 12:00	1	1
08/31/2014 13:00	1	1
08/31/2014 14:00	1	1
08/31/2014 15:00	1	1
08/31/2014 16:00	1	1
08/31/2014 17:00	1	1
08/31/2014 18:00	1	1
08/31/2014 19:00	1	1
08/31/2014 20:00	1	1
08/31/2014 21:00	1	1
08/31/2014 22:00	1	1
08/31/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/01/2014 00:00	1	1
09/01/2014 01:00	1	1
09/01/2014 02:00	1	1
09/01/2014 03:00	1	1
09/01/2014 04:00	1	1
09/01/2014 05:00	1	1
09/01/2014 06:00	1	1
09/01/2014 07:00	1	1
09/01/2014 08:00	1	1
09/01/2014 09:00	1	1
09/01/2014 10:00	1	1
09/01/2014 11:00	1	1
09/01/2014 12:00	1	1
09/01/2014 13:00	1	1
09/01/2014 14:00	1	1
09/01/2014 15:00	1	1
09/01/2014 16:00	1	1
09/01/2014 17:00	1	1
09/01/2014 18:00	1	1
09/01/2014 19:00	1	1
09/01/2014 20:00	1	1
09/01/2014 21:00	1	1
09/01/2014 22:00	1	1
09/01/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/02/2014 00:00	1	1
09/02/2014 01:00	1	1
09/02/2014 02:00	1	1
09/02/2014 03:00	1	1
09/02/2014 04:00	1	1
09/02/2014 05:00	1	1
09/02/2014 06:00	1	1
09/02/2014 07:00	1	1
09/02/2014 08:00	1	1
09/02/2014 09:00	1	1
09/02/2014 10:00	1	1
09/02/2014 11:00	1	1
09/02/2014 12:00	1	1
09/02/2014 13:00	1	1
09/02/2014 14:00	1	1
09/02/2014 15:00	1	1
09/02/2014 16:00	1	1
09/02/2014 17:00	1	1
09/02/2014 18:00	1	1
09/02/2014 19:00	1	1
09/02/2014 20:00	1	1
09/02/2014 21:00	1	1
09/02/2014 22:00	1	1
09/02/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/03/2014 00:00	1	1
09/03/2014 01:00	1	1
09/03/2014 02:00	1	1
09/03/2014 03:00	1	1
09/03/2014 04:00	1	1
09/03/2014 05:00	1	1
09/03/2014 06:00	1	1
09/03/2014 07:00	1	1
09/03/2014 08:00	1	1
09/03/2014 09:00	1	1
09/03/2014 10:00	1	1
09/03/2014 11:00	1	1
09/03/2014 12:00	1	1
09/03/2014 13:00	1	1
09/03/2014 14:00	1	1
09/03/2014 15:00	1	1
09/03/2014 16:00	1	1
09/03/2014 17:00	1	1
09/03/2014 18:00	1	1
09/03/2014 19:00	1	1
09/03/2014 20:00	1	1
09/03/2014 21:00	1	1
09/03/2014 22:00	1	1
09/03/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/04/2014 00:00	1	1
09/04/2014 01:00	1	1
09/04/2014 02:00	1	1
09/04/2014 03:00	1	1
09/04/2014 04:00	1	1
09/04/2014 05:00	1	1
09/04/2014 06:00	1	1
09/04/2014 07:00	1	1
09/04/2014 08:00	1	1
09/04/2014 09:00	1	1
09/04/2014 10:00	1	1
09/04/2014 11:00	1	1
09/04/2014 12:00	1	1
09/04/2014 13:00	1	1
09/04/2014 14:00	1	1
09/04/2014 15:00	1	1
09/04/2014 16:00	1	1
09/04/2014 17:00	1	1
09/04/2014 18:00	1	1
09/04/2014 19:00	1	1
09/04/2014 20:00	1	1
09/04/2014 21:00	1	1
09/04/2014 22:00	1	1
09/04/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/05/2014 00:00	1	12
09/05/2014 01:00	1	30
09/05/2014 02:00	1	34
09/05/2014 03:00	1	37
09/05/2014 04:00	1	29
09/05/2014 05:00	1	11
09/05/2014 06:00	1	7
09/05/2014 07:00	15	4
09/05/2014 08:00	20	1
09/05/2014 09:00	20	1
09/05/2014 10:00	20	1
09/05/2014 11:00	6	1
09/05/2014 12:00	1	1
09/05/2014 13:00	1	1
09/05/2014 14:00	1	1
09/05/2014 15:00	1	1
09/05/2014 16:00	1	1
09/05/2014 17:00	1	1
09/05/2014 18:00	1	1
09/05/2014 19:00	1	1
09/05/2014 20:00	1	1
09/05/2014 21:00	1	1
09/05/2014 22:00	1	1
09/05/2014 23:00	1	1
Average/Sum#:	4	8
Minimum:	1	1
Maximum:	20	37
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/06/2014 00:00	1	1
09/06/2014 01:00	1	1
09/06/2014 02:00	1	1
09/06/2014 03:00	1	1
09/06/2014 04:00	1	1
09/06/2014 05:00	1	1
09/06/2014 06:00	1	1
09/06/2014 07:00	1	1
09/06/2014 08:00	1	1
09/06/2014 09:00	1	1
09/06/2014 10:00	1	1
09/06/2014 11:00	1	1
09/06/2014 12:00	1	1
09/06/2014 13:00	1	1
09/06/2014 14:00	1	1
09/06/2014 15:00	1	1
09/06/2014 16:00	1	1
09/06/2014 17:00	1	1
09/06/2014 18:00	1	1
09/06/2014 19:00	1	1
09/06/2014 20:00	1	1
09/06/2014 21:00	1	1
09/06/2014 22:00	1	1
09/06/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/07/2014 00:00	1	1
09/07/2014 01:00	1	1
09/07/2014 02:00	1	1
09/07/2014 03:00	1	1
09/07/2014 04:00	1	1
09/07/2014 05:00	1	1
09/07/2014 06:00	1	1
09/07/2014 07:00	1	1
09/07/2014 08:00	1	1
09/07/2014 09:00	1	1
09/07/2014 10:00	1	1
09/07/2014 11:00	1	1
09/07/2014 12:00	1	1
09/07/2014 13:00	1	1
09/07/2014 14:00	1	1
09/07/2014 15:00	1	1
09/07/2014 16:00	1	1
09/07/2014 17:00	1	1
09/07/2014 18:00	1	1
09/07/2014 19:00	1	1
09/07/2014 20:00	1	1
09/07/2014 21:00	1	1
09/07/2014 22:00	1	1
09/07/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/08/2014 00:00	1	1
09/08/2014 01:00	1	1
09/08/2014 02:00	1	1
09/08/2014 03:00	1	1
09/08/2014 04:00	1	1
09/08/2014 05:00	1	1
09/08/2014 06:00	1	1
09/08/2014 07:00	1	1
09/08/2014 08:00	1	1
09/08/2014 09:00	1	1
09/08/2014 10:00	1	1
09/08/2014 11:00	1	1
09/08/2014 12:00	1	1
09/08/2014 13:00	1	1
09/08/2014 14:00	1	1
09/08/2014 15:00	1	1
09/08/2014 16:00	1	1
09/08/2014 17:00	1	1
09/08/2014 18:00	1	1
09/08/2014 19:00	1	1
09/08/2014 20:00	1	1
09/08/2014 21:00	1	1
09/08/2014 22:00	1	1
09/08/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/09/2014 00:00	1	1
09/09/2014 01:00	1	1
09/09/2014 02:00	1	1
09/09/2014 03:00	1	1
09/09/2014 04:00	1	1
09/09/2014 05:00	1	1
09/09/2014 06:00	1	1
09/09/2014 07:00	1	1
09/09/2014 08:00	1	1
09/09/2014 09:00	1	1
09/09/2014 10:00	1	1
09/09/2014 11:00	1	1
09/09/2014 12:00	1	1
09/09/2014 13:00	1	1
09/09/2014 14:00	1	1
09/09/2014 15:00	1	1
09/09/2014 16:00	1	1
09/09/2014 17:00	1	1
09/09/2014 18:00	1	1
09/09/2014 19:00	1	1
09/09/2014 20:00	1	1
09/09/2014 21:00	1	1
09/09/2014 22:00	1	1
09/09/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/10/2014 00:00	1	1
09/10/2014 01:00	1	1
09/10/2014 02:00	1	1
09/10/2014 03:00	1	1
09/10/2014 04:00	1	1
09/10/2014 05:00	1	1
09/10/2014 06:00	1	1
09/10/2014 07:00	1	1
09/10/2014 08:00	1	1
09/10/2014 09:00	1	1
09/10/2014 10:00	1	1
09/10/2014 11:00	1	1
09/10/2014 12:00	1	1
09/10/2014 13:00	1	1
09/10/2014 14:00	1	1
09/10/2014 15:00	1	1
09/10/2014 16:00	1	1
09/10/2014 17:00	1	1
09/10/2014 18:00	1	1
09/10/2014 19:00	1	1
09/10/2014 20:00	1	1
09/10/2014 21:00	1	1
09/10/2014 22:00	1	1
09/10/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/11/2014 00:00	1	1
09/11/2014 01:00	1	1
09/11/2014 02:00	1	1
09/11/2014 03:00	1	1
09/11/2014 04:00	1	1
09/11/2014 05:00	1	1
09/11/2014 06:00	1	1
09/11/2014 07:00	1	1
09/11/2014 08:00	1	1
09/11/2014 09:00	1	1
09/11/2014 10:00	1	1
09/11/2014 11:00	1	1
09/11/2014 12:00	1	1
09/11/2014 13:00	1	1
09/11/2014 14:00	1	1
09/11/2014 15:00	1	1
09/11/2014 16:00	1	1
09/11/2014 17:00	1	1
09/11/2014 18:00	1	1
09/11/2014 19:00	1	1
09/11/2014 20:00	1	1
09/11/2014 21:00	1	1
09/11/2014 22:00	1	1
09/11/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/12/2014 00:00	1	1
09/12/2014 01:00	1	1
09/12/2014 02:00	1	1
09/12/2014 03:00	1	1
09/12/2014 04:00	1	1
09/12/2014 05:00	1	1
09/12/2014 06:00	1	1
09/12/2014 07:00	1	1
09/12/2014 08:00	1	1
09/12/2014 09:00	1	1
09/12/2014 10:00	1	1
09/12/2014 11:00	1	1
09/12/2014 12:00	1	1
09/12/2014 13:00	1	1
09/12/2014 14:00	1	1
09/12/2014 15:00	1	1
09/12/2014 16:00	1	1
09/12/2014 17:00	1	1
09/12/2014 18:00	1	1
09/12/2014 19:00	1	1
09/12/2014 20:00	1	1
09/12/2014 21:00	1	1
09/12/2014 22:00	1	1
09/12/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/13/2014 00:00	1	1
09/13/2014 01:00	1	1
09/13/2014 02:00	1	1
09/13/2014 03:00	1	1
09/13/2014 04:00	1	1
09/13/2014 05:00	1	1
09/13/2014 06:00	1	1
09/13/2014 07:00	1	1
09/13/2014 08:00	1	1
09/13/2014 09:00	1	1
09/13/2014 10:00	1	1
09/13/2014 11:00	1	1
09/13/2014 12:00	1	1
09/13/2014 13:00	1	1
09/13/2014 14:00	1	1
09/13/2014 15:00	1	1
09/13/2014 16:00	1	1
09/13/2014 17:00	1	1
09/13/2014 18:00	1	1
09/13/2014 19:00	1	1
09/13/2014 20:00	1	1
09/13/2014 21:00	1	1
09/13/2014 22:00	1	1
09/13/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/14/2014 00:00	1	1
09/14/2014 01:00	1	1
09/14/2014 02:00	1	1
09/14/2014 03:00	1	1
09/14/2014 04:00	1	1
09/14/2014 05:00	1	1
09/14/2014 06:00	1	1
09/14/2014 07:00	1	1
09/14/2014 08:00	1	1
09/14/2014 09:00	1	1
09/14/2014 10:00	1	1
09/14/2014 11:00	1	1
09/14/2014 12:00	1	1
09/14/2014 13:00	1	1
09/14/2014 14:00	1	1
09/14/2014 15:00	1	1
09/14/2014 16:00	1	1
09/14/2014 17:00	1	1
09/14/2014 18:00	1	1
09/14/2014 19:00	1	1
09/14/2014 20:00	1	1
09/14/2014 21:00	1	1
09/14/2014 22:00	1	1
09/14/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/15/2014 00:00	1	1
09/15/2014 01:00	1	1
09/15/2014 02:00	1	1
09/15/2014 03:00	1	1
09/15/2014 04:00	1	1
09/15/2014 05:00	1	1
09/15/2014 06:00	1	1
09/15/2014 07:00	1	1
09/15/2014 08:00	1	1
09/15/2014 09:00	1	1
09/15/2014 10:00	1	1
09/15/2014 11:00	1	1
09/15/2014 12:00	1	1
09/15/2014 13:00	1	1
09/15/2014 14:00	1	1
09/15/2014 15:00	1	1
09/15/2014 16:00	1	1
09/15/2014 17:00	1	1
09/15/2014 18:00	1	1
09/15/2014 19:00	1	1
09/15/2014 20:00	1	1
09/15/2014 21:00	1	1
09/15/2014 22:00	1	1
09/15/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/16/2014 00:00	1	1
09/16/2014 01:00	1	1
09/16/2014 02:00	1	1
09/16/2014 03:00	1	1
09/16/2014 04:00	1	1
09/16/2014 05:00	1	1
09/16/2014 06:00	1	1
09/16/2014 07:00	1	1
09/16/2014 08:00	1	1
09/16/2014 09:00	1	1
09/16/2014 10:00	1	1
09/16/2014 11:00	1	1
09/16/2014 12:00	1	1
09/16/2014 13:00	1	1
09/16/2014 14:00	1	1
09/16/2014 15:00	1	1
09/16/2014 16:00	1	1
09/16/2014 17:00	1	1
09/16/2014 18:00	1	1
09/16/2014 19:00	1	1
09/16/2014 20:00	1	1
09/16/2014 21:00	1	1
09/16/2014 22:00	1	1
09/16/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/17/2014 00:00	1	1
09/17/2014 01:00	1	1
09/17/2014 02:00	1	1
09/17/2014 03:00	1	1
09/17/2014 04:00	1	1
09/17/2014 05:00	1	1
09/17/2014 06:00	1	1
09/17/2014 07:00	1	1
09/17/2014 08:00	1	1
09/17/2014 09:00	1	1
09/17/2014 10:00	1	1
09/17/2014 11:00	1	1
09/17/2014 12:00	1	1
09/17/2014 13:00	1	1
09/17/2014 14:00	1	1
09/17/2014 15:00	1	1
09/17/2014 16:00	1	1
09/17/2014 17:00	1	1
09/17/2014 18:00	1	1
09/17/2014 19:00	1	1
09/17/2014 20:00	1	1
09/17/2014 21:00	1	1
09/17/2014 22:00	1	1
09/17/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/18/2014 00:00	1	1
09/18/2014 01:00	1	1
09/18/2014 02:00	1	1
09/18/2014 03:00	1	1
09/18/2014 04:00	1	1
09/18/2014 05:00	1	1
09/18/2014 06:00	1	1
09/18/2014 07:00	1	1
09/18/2014 08:00	1	1
09/18/2014 09:00	1	1
09/18/2014 10:00	1	1
09/18/2014 11:00	1	1
09/18/2014 12:00	1	1
09/18/2014 13:00	1	1
09/18/2014 14:00	1	1
09/18/2014 15:00	1	1
09/18/2014 16:00	1	1
09/18/2014 17:00	1	1
09/18/2014 18:00	1	1
09/18/2014 19:00	1	1
09/18/2014 20:00	1	1
09/18/2014 21:00	1	1
09/18/2014 22:00	1	1
09/18/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/19/2014 00:00	1	1
09/19/2014 01:00	1	1
09/19/2014 02:00	1	1
09/19/2014 03:00	1	1
09/19/2014 04:00	1	1
09/19/2014 05:00	1	1
09/19/2014 06:00	1	1
09/19/2014 07:00	1	1
09/19/2014 08:00	1	1
09/19/2014 09:00	1	1
09/19/2014 10:00	1	1
09/19/2014 11:00	1	1
09/19/2014 12:00	1	1
09/19/2014 13:00	1	1
09/19/2014 14:00	1	1
09/19/2014 15:00	1	1
09/19/2014 16:00	1	1
09/19/2014 17:00	1	1
09/19/2014 18:00	1	1
09/19/2014 19:00	1	1
09/19/2014 20:00	1	1
09/19/2014 21:00	1	1
09/19/2014 22:00	1	1
09/19/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/20/2014 00:00	1	1
09/20/2014 01:00	1	1
09/20/2014 02:00	1	1
09/20/2014 03:00	1	1
09/20/2014 04:00	1	1
09/20/2014 05:00	1	1
09/20/2014 06:00	1	1
09/20/2014 07:00	1	1
09/20/2014 08:00	1	1
09/20/2014 09:00	1	1
09/20/2014 10:00	1	1
09/20/2014 11:00	1	1
09/20/2014 12:00	1	1
09/20/2014 13:00	1	1
09/20/2014 14:00	1	1
09/20/2014 15:00	1	1
09/20/2014 16:00	1	1
09/20/2014 17:00	1	1
09/20/2014 18:00	1	1
09/20/2014 19:00	1	1
09/20/2014 20:00	1	1
09/20/2014 21:00	1	1
09/20/2014 22:00	1	1
09/20/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/21/2014 00:00	1	1
09/21/2014 01:00	1	1
09/21/2014 02:00	1	1
09/21/2014 03:00	1	1
09/21/2014 04:00	1	1
09/21/2014 05:00	1	1
09/21/2014 06:00	1	1
09/21/2014 07:00	1	1
09/21/2014 08:00	1	1
09/21/2014 09:00	1	1
09/21/2014 10:00	1	1
09/21/2014 11:00	1	1
09/21/2014 12:00	1	1
09/21/2014 13:00	1	1
09/21/2014 14:00	1	1
09/21/2014 15:00	1	1
09/21/2014 16:00	1	1
09/21/2014 17:00	1	1
09/21/2014 18:00	1	1
09/21/2014 19:00	1	1
09/21/2014 20:00	1	1
09/21/2014 21:00	1	1
09/21/2014 22:00	1	1
09/21/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/22/2014 00:00	1	1
09/22/2014 01:00	1	1
09/22/2014 02:00	1	1
09/22/2014 03:00	1	1
09/22/2014 04:00	1	1
09/22/2014 05:00	1	1
09/22/2014 06:00	1	1
09/22/2014 07:00	1	1
09/22/2014 08:00	1	1
09/22/2014 09:00	0	1
09/22/2014 10:00	0	1
09/22/2014 11:00	0	1
09/22/2014 12:00	0	1
09/22/2014 13:00	0	1
09/22/2014 14:00	0	1
09/22/2014 15:00	1	1
09/22/2014 16:00	1	1
09/22/2014 17:00	1	1
09/22/2014 18:00	1	1
09/22/2014 19:00	1	1
09/22/2014 20:00	1	1
09/22/2014 21:00	1	1
09/22/2014 22:00	1	1
09/22/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	0	1
Maximum:	1	1
%SI	21	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/23/2014 00:00	1	1
09/23/2014 01:00	1	1
09/23/2014 02:00	1	1
09/23/2014 03:00	1	1
09/23/2014 04:00	1	1
09/23/2014 05:00	1	1
09/23/2014 06:00	1	1
09/23/2014 07:00	1	1
09/23/2014 08:00	1	1
09/23/2014 09:00	1	1
09/23/2014 10:00	1	0
09/23/2014 11:00	1	0
09/23/2014 12:00	1	0
09/23/2014 13:00	1	0
09/23/2014 14:00	1	0
09/23/2014 15:00	1	1
09/23/2014 16:00	1	1
09/23/2014 17:00	1	1
09/23/2014 18:00	1	1
09/23/2014 19:00	1	1
09/23/2014 20:00	1	1
09/23/2014 21:00	1	1
09/23/2014 22:00	1	1
09/23/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	21

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/24/2014 00:00	1	1
09/24/2014 01:00	1	1
09/24/2014 02:00	1	1
09/24/2014 03:00	1	1
09/24/2014 04:00	1	1
09/24/2014 05:00	1	1
09/24/2014 06:00	1	1
09/24/2014 07:00	1	1
09/24/2014 08:00	1	1
09/24/2014 09:00	1	1
09/24/2014 10:00	1	1
09/24/2014 11:00	1	1
09/24/2014 12:00	1	1
09/24/2014 13:00	1	1
09/24/2014 14:00	1	1
09/24/2014 15:00	1	1
09/24/2014 16:00	1	1
09/24/2014 17:00	1	1
09/24/2014 18:00	1	1
09/24/2014 19:00	1	1
09/24/2014 20:00	1	1
09/24/2014 21:00	1	1
09/24/2014 22:00	1	1
09/24/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/25/2014 00:00	1	1
09/25/2014 01:00	1	1
09/25/2014 02:00	1	1
09/25/2014 03:00	1	1
09/25/2014 04:00	1	1
09/25/2014 05:00	1	1
09/25/2014 06:00	1	1
09/25/2014 07:00	1	1
09/25/2014 08:00	1	1
09/25/2014 09:00	1	1
09/25/2014 10:00	1	1
09/25/2014 11:00	1	1
09/25/2014 12:00	1	1
09/25/2014 13:00	1	1
09/25/2014 14:00	1	1
09/25/2014 15:00	1	1
09/25/2014 16:00	1	1
09/25/2014 17:00	1	1
09/25/2014 18:00	1	1
09/25/2014 19:00	1	1
09/25/2014 20:00	1	1
09/25/2014 21:00	1	1
09/25/2014 22:00	1	1
09/25/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/26/2014 00:00	1	1
09/26/2014 01:00	1	1
09/26/2014 02:00	1	1
09/26/2014 03:00	1	1
09/26/2014 04:00	1	1
09/26/2014 05:00	1	1
09/26/2014 06:00	1	1
09/26/2014 07:00	1	1
09/26/2014 08:00	1	1
09/26/2014 09:00	1	1
09/26/2014 10:00	1	1
09/26/2014 11:00	1	1
09/26/2014 12:00	1	1
09/26/2014 13:00	1	1
09/26/2014 14:00	1	1
09/26/2014 15:00	1	1
09/26/2014 16:00	1	1
09/26/2014 17:00	1	1
09/26/2014 18:00	1	1
09/26/2014 19:00	1	1
09/26/2014 20:00	1	1
09/26/2014 21:00	1	1
09/26/2014 22:00	1	1
09/26/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/27/2014 00:00	1	1
09/27/2014 01:00	1	1
09/27/2014 02:00	1	1
09/27/2014 03:00	1	1
09/27/2014 04:00	1	1
09/27/2014 05:00	1	1
09/27/2014 06:00	1	1
09/27/2014 07:00	1	1
09/27/2014 08:00	1	1
09/27/2014 09:00	1	1
09/27/2014 10:00	1	1
09/27/2014 11:00	1	1
09/27/2014 12:00	1	1
09/27/2014 13:00	1	1
09/27/2014 14:00	1	1
09/27/2014 15:00	1	1
09/27/2014 16:00	1	1
09/27/2014 17:00	1	1
09/27/2014 18:00	1	1
09/27/2014 19:00	1	1
09/27/2014 20:00	1	1
09/27/2014 21:00	1	1
09/27/2014 22:00	1	1
09/27/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/28/2014 00:00	1	1
09/28/2014 01:00	1	1
09/28/2014 02:00	1	1
09/28/2014 03:00	1	1
09/28/2014 04:00	1	1
09/28/2014 05:00	1	1
09/28/2014 06:00	1	1
09/28/2014 07:00	1	1
09/28/2014 08:00	1	1
09/28/2014 09:00	1	1
09/28/2014 10:00	1	1
09/28/2014 11:00	1	1
09/28/2014 12:00	1	1
09/28/2014 13:00	1	1
09/28/2014 14:00	1	1
09/28/2014 15:00	1	1
09/28/2014 16:00	1	1
09/28/2014 17:00	1	1
09/28/2014 18:00	1	1
09/28/2014 19:00	1	1
09/28/2014 20:00	1	1
09/28/2014 21:00	1	1
09/28/2014 22:00	1	1
09/28/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/29/2014 00:00	1	1
09/29/2014 01:00	1	1
09/29/2014 02:00	1	1
09/29/2014 03:00	1	1
09/29/2014 04:00	1	1
09/29/2014 05:00	1	1
09/29/2014 06:00	1	1
09/29/2014 07:00	1	1
09/29/2014 08:00	1	1
09/29/2014 09:00	1	1
09/29/2014 10:00	1	1
09/29/2014 11:00	1	1
09/29/2014 12:00	1	1
09/29/2014 13:00	1	1
09/29/2014 14:00	1	1
09/29/2014 15:00	1	1
09/29/2014 16:00	1	1
09/29/2014 17:00	1	1
09/29/2014 18:00	1	1
09/29/2014 19:00	1	1
09/29/2014 20:00	1	1
09/29/2014 21:00	1	1
09/29/2014 22:00	1	1
09/29/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

Daily Summary Report

KKKK NOx 4HR Rolling Avg

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:	> Limit Unit CT1 NOx_4Hr, Ppmvdc 1 Hour(s)	> Limit Unit CT2 NOx_4Hr, Ppmvdc 1 Hour(s)
09/30/2014 00:00	1	1
09/30/2014 01:00	1	1
09/30/2014 02:00	1	1
09/30/2014 03:00	1	1
09/30/2014 04:00	1	1
09/30/2014 05:00	1	1
09/30/2014 06:00	1	1
09/30/2014 07:00	1	1
09/30/2014 08:00	1	1
09/30/2014 09:00	1	1
09/30/2014 10:00	1	1
09/30/2014 11:00	1	1
09/30/2014 12:00	1	1
09/30/2014 13:00	1	1
09/30/2014 14:00	1	1
09/30/2014 15:00	1	1
09/30/2014 16:00	1	1
09/30/2014 17:00	1	1
09/30/2014 18:00	1	1
09/30/2014 19:00	1	1
09/30/2014 20:00	1	1
09/30/2014 21:00	1	1
09/30/2014 22:00	1	1
09/30/2014 23:00	1	1
Average/Sum#:	1	1
Minimum:	1	1
Maximum:	1	1
%SI	0	0

ATTACHMENT 4

Excess Emission/Downtime Report (AQ-4, 19)

EDS-CMS Reports

EDS/CMS Summary Report

CT1 - CO LbPerHr

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 08:40 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT1_CO_LbPerHr_1H
EDS Data from: CT1_CO_LbPerHr_1H
Emission Limitation: CT1_COLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Operating time for EDS: 1,558.00 Hour(s)
Operating time for CMS: 1,558.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	1
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	1
4. Time of Excess Emission as a percentage of operating time	0.06
5. Time in compliance as percentage of operating time	99.94

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	4
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime	4
3. Total Downtime as a percentage of operating time	0.26
4. Total Availability as a percentage of operating time	99.74

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT1 - CO Ppmvdc

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 08:40 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from:	CT1_CO_Ppmvdc_1H
EDS Data from:	CT1_CO_3Hr_Ppmvdc_1H
Emission Limitation:	CT1_COLimit_3Hr_Ppmvdc_1H
No Value Exclusions Allowed	
Monitor Manufacturer and Model No.:	TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit:	12/01/2009 00:00
Operating time for EDS:	1,558.00 Hour(s)
Operating time for CMS:	1,558.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	4
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime	4
3. Total Downtime as a percentage of operating time	0.26
4. Total Availability as a percentage of operating time	99.74

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT1 - NOx LbPerHr

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 08:40 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from:	CT1_NOx_LbPerHr_1H
EDS Data from:	CT1_NOx_LbPerHr_1H
Emission Limitation:	CT1_NOxLimit_LbPerHr_1H
No Value Exclusions Allowed	
Monitor Manufacturer and Model No.:	TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit:	12/01/2009 00:00
Operating time for EDS:	1,558.00 Hour(s)
Operating time for CMS:	1,558.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	4
d. Other known causes	3
e. Unknown causes	0
2. Total CMS Downtime	7
3. Total Downtime as a percentage of operating time	0.45
4. Total Availability as a percentage of operating time	99.55

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT1 - NOx Ppmvdc

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 08:40 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from:	CT1_NOx_Ppmvdc_1H
EDS Data from:	CT1_NOx_Ppmvdc_1H
Emission Limitation:	CT1_NOxLimit_Ppmvdc_1H
No Value Exclusions Allowed	
Monitor Manufacturer and Model No.:	TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit:	12/01/2009 00:00
Operating time for EDS:	1,558.00 Hour(s)
Operating time for CMS:	1,558.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	4
d. Other known causes	3
e. Unknown causes	0
2. Total CMS Downtime	7
3. Total Downtime as a percentage of operating time	0.45
4. Total Availability as a percentage of operating time	99.55

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - CO LbPerHr

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 08:40 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_CO_LbPerHr_1H
EDS Data from: CT2_CO_LbPerHr_1H
Emission Limitation: CT2_COLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Operating time for EDS: 1,577.00 Hour(s)
Operating time for CMS: 1,577.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	4
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime	4
3. Total Downtime as a percentage of operating time	0.25
4. Total Availability as a percentage of operating time	99.75

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - CO Ppmvdc

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 08:40 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from:	CT2_CO_Ppmvdc_1H
EDS Data from:	CT2_CO_3Hr_Ppmvdc_1H
Emission Limitation:	CT2_COLimit_3Hr_Ppmvdc_1H
No Value Exclusions Allowed	
Monitor Manufacturer and Model No.:	TELEDYNE MONITOR LABS INC, TML30
Date of Latest CMS Certification or Audit:	12/01/2009 00:00
Operating time for EDS:	1,577.00 Hour(s)
Operating time for CMS:	1,577.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	4
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime	4
3. Total Downtime as a percentage of operating time	0.25
4. Total Availability as a percentage of operating time	99.75

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - NOx LbPerHr

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 08:40 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from: CT2_NOx_LbPerHr_1H
EDS Data from: CT2_NOx_LbPerHr_1H
Emission Limitation: CT2_NOxLimit_LbPerHr_1H
No Value Exclusions Allowed
Monitor Manufacturer and Model No.: TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit: 12/01/2009 00:00
Operating time for EDS: 1,577.00 Hour(s)
Operating time for CMS: 1,577.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	4
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime	4
3. Total Downtime as a percentage of operating time	0.25
4. Total Availability as a percentage of operating time	99.75

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

EDS/CMS Summary Report

CT2 - NOx Ppmvdc

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 08:40 **Location:** Maxwell, CA
Description: Electric Utility

CMS Data from:	CT2_NOx_Ppmvdc_1H
EDS Data from:	CT2_NOx_Ppmvdc_1H
Emission Limitation:	CT2_NOxLimit_Ppmvdc_1H
No Value Exclusions Allowed	
Monitor Manufacturer and Model No.:	TELEDYNE MONITOR LABS INC, TML41-O2
Date of Latest CMS Certification or Audit:	12/01/2009 00:00
Operating time for EDS:	1,577.00 Hour(s)
Operating time for CMS:	1,577.00 Hour(s)

Emission Data Summary	
1. Duration of excess emission in reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process Problems	0
d. Other known causes	0
e. Unknown causes	0
2. Upset Conditions	0
3. Total Duration (Subtracts Exclusions and Upset Conditions)	0
4. Time of Excess Emission as a percentage of operating time	0.00
5. Time in compliance as percentage of operating time	100.00

CMS Performance Summary	
1. CMS downtime in reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	4
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime	4
3. Total Downtime as a percentage of operating time	0.25
4. Total Availability as a percentage of operating time	99.75

Note: The total duration of EDS (<1%) and CMS (<5%) incidents meets federal standard 40CFR60.7(d), therefore the excess emmission detail report may not be required as part of the quarterly/semi-annual submission unless requested by the Administrator.

Excess Emission Reports

Excess Emission Report

CT1 - CO LbPerHr 1-Hour Block Average

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:04 **Location:** Maxwell, CA

Tag Name: CT1_CO_Lb_1H
Total Operating Time: 1,558.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 650.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,558.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

CT1 - CO Ppmvdc 3-Hour Rolling Average

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:04 **Location:** Maxwell, CA

Tag Name: CT1_CO_3Hr_Ppmvdc_1H
Total Operating Time: 1,558.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 650.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,558.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

CT1 - NOx LbPerHr 1-Hour Block Average

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:04 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Lb_1H
Total Operating Time: 1,558.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 650.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,558.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

CT1 - NOx Ppmvdc 1-Hour Block Average

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:04 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Ppmvdc_1H
Total Operating Time: 1,558.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 650.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,558.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

CT2 - CO LbPerHr 1-Hour Block Average

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:04 **Location:** Maxwell, CA

Tag Name: CT2_CO_Lb_1H
Total Operating Time: 1,577.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 631.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,577.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

CT2 - CO Ppmvdc 3-Hour Rolling Average

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:04 **Location:** Maxwell, CA

Tag Name: CT2_CO_3Hr_Ppmvdc_1H
Total Operating Time: 1,577.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 631.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,577.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

CT2 - NOx LbPerHr 1-Hour Block Average

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:04 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Lb_1H
Total Operating Time: 1,577.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 631.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,577.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

CT2 - NOx Ppmvdc 1-Hour Block Average

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:04 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Ppmvdc_1H
Total Operating Time: 1,577.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 631.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,577.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Downtime Reports

Invalid Data Report

CT1 - Stack CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 08:44 **Location:** Maxwell, CA

Tag Name: CT1_CO_LbPerHr_1H

Total Operating Time: 1,558.00 Hour(s)
Non-Operating Time: 650.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	09/22/2014 09:00	09/22/2014 12:59	4	3 - Quality assurance calibration	4 - Quarterly linearity/cga

Total Operating Time:	1,558.00 Hour(s)
Total Monitor Downtime (Online only):	4.00 Hour(s)
Percent Monitor Availability:	99.74 %
Percent Monitor Downtime:	0.26 %

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	4	100.00
4	Action	Quarterly linearity/cga	4	100.00

Invalid Data Report

CT1 - Stack NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 08:44 **Location:** Maxwell, CA

Tag Name: CT1_NOx_LbPerHr_1H

Total Operating Time: 1,558.00 Hour(s)
Non-Operating Time: 650.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	07/23/2014 07:00	07/23/2014 09:59	3	9 - CEMS failed calibration	3 - Performed manual calibration
2	09/22/2014 09:00	09/22/2014 12:59	4	3 - Quality assurance calibration	4 - Quarterly linearity/cga

Total Operating Time:	1,558.00 Hour(s)
Total Monitor Downtime (Online only):	7.00 Hour(s)
Percent Monitor Availability:	99.55 %
Percent Monitor Downtime:	0.45 %

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	4	57.14
9	Reason	CEMS failed calibration	3	42.86
3	Action	Performed manual calibration	3	42.86
4	Action	Quarterly linearity/cga	4	57.14

Invalid Data Report

CT2 - Stack CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 08:44 **Location:** Maxwell, CA

Tag Name: CT2_CO_LbPerHr_1H

Total Operating Time: 1,577.00 Hour(s)
Non-Operating Time: 631.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	09/23/2014 09:00	09/23/2014 12:59	4	3 - Quality assurance calibration	4 - Quarterly linearity/cga

Total Operating Time:	1,577.00 Hour(s)
Total Monitor Downtime (Online only):	4.00 Hour(s)
Percent Monitor Availability:	99.75 %
Percent Monitor Downtime:	0.25 %

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	4	100.00
4	Action	Quarterly linearity/cga	4	100.00

Invalid Data Report

CT2 - Stack NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 08:44 **Location:** Maxwell, CA

Tag Name: CT2_NOx_LbPerHr_1H

Total Operating Time: 1,577.00 Hour(s)
Non-Operating Time: 631.00 Hour(s) Report Time: 2,208.00 Hour(s)

Inc No	Start Time	End Time	Duration in Hour(s)	Reason Code - Description	Action Code - Description
1	09/23/2014 09:00	09/23/2014 12:59	4	3 - Quality assurance calibration	4 - Quarterly linearity/cga

Total Operating Time:	1,577.00 Hour(s)
Total Monitor Downtime (Online only):	4.00 Hour(s)
Percent Monitor Availability:	99.75 %
Percent Monitor Downtime:	0.25 %

Report Code	Type	Text	Duration	Duration Percent
3	Reason	Quality assurance calibration	4	100.00
4	Action	Quarterly linearity/cga	4	100.00

ATTACHMENT 5
Hourly Emissions VOC (AQ-14)

Pursuant to the CEC conditions of certification, AQ-14 requires that a correlation be developed between emissions of CO and VOC in order to predict ongoing compliance with the VOC limits.

AQ-14 reads as follows:

AQ-14 The CTGs shall meet a VOC limit of 2.0 ppmvd with duct burner firing and 1.38 ppmvd without duct burner firing @ 15% O2 averaged over one hour. Maximum hourly steady state emission limits for each CTG are:

Pounds VOC with Duct Firing Pounds: 7.2

VOC without Duct Firing: 3.4

Verification: The project owner shall submit to the CPM and APCO CTG source test emissions data demonstrating compliance with this condition as required by condition **AQ-8** and shall provide operating data that establishes ongoing compliance with this condition using a determined relationship with CO emissions, previously approved by the CPM and APCO using source test data, as part of the Quarterly Operation Reports (**AQ-22**).

Analysis

Data derived from the December 2011 source tests were used to establish the initial correlation between CO and VOC. The 2011 tests were conducted by The Avogadro Group with concurrent testing for CO and VOC conducted on the following dates for the following load scenarios:

- Unit 1 – Baseload w/o duct burners – 11/8/11 (3 test runs)
- Unit 2 - Baseload w/o duct burners – 11/9/11 (3 test runs)
- Unit 1 – Maximum load w/duct burners – 11/11/11 (3 test runs)
- Unit 2 - Maximum load w/duct burners – 11/12/11 (3 test runs)

The summary test results for the above noted concurrent CO and VOC tests are presented in the 2011 test report at Tables 6-5, 6-6, 6-7, and 6-9. The correlation of CO versus VOC data was prepared using the six (6) test data sets for each load scenario, i.e., six values used for baseload w/o duct burners, and six values used for maximum load w/duct burners. The attached spreadsheet shows the data plots for each load scenario as well as the regression analysis for each data set.

As can be seen from the spreadsheet analysis, the correlation for both scenarios is not very robust, with the maximum load with duct burners giving the best correlation. The spreadsheet presents the predicted VOC calculations for a range of CO values, with the resultant VOC mass emissions based on a linear ratio from the average test data. It should be noted that due to the correlation equations, as CO increases the VOC decreases and begins to show “non-real” values. This is due to the small sample size for both scenarios.

Colusa GS Test Data for CO and VOC

	Date	Times	VOC, ppm	CO, ppm	
Unit 1	11/8/2011	0900-0930	0.57	0.18	
		1009-1030	0.25	0.23	w/o DB
		1431-1501	0.25	0.49	
	11/11/2011	1150-1220	0.43	0.17	
		1226-1256	0.42	0.19	w DB
		1304-1334	0.21	0.3	
Unit 2	11/9/2011	0905-0935	0.19	0.5	
		0938-1008	0.19	0.46	w/o DB
		1018-1048	0.29	0.47	
	11/12/2011	0850-0910	0.24	0.34	
		0930-1000	0.2	0.31	w DB
		1015-1045	0.15	0.35	

Permit Limits	VOC, ppm	CO, ppm
w/o DB	1.38	3
w DB	2	3

w/o DB		w DB	
VOC	CO	VOC	CO
0.57	0.18	0.43	0.17
0.25	0.23	0.42	0.19
0.25	0.49	0.21	0.3
0.19	0.5	0.24	0.34
0.19	0.46	0.2	0.31
0.29	0.47	0.15	0.35

all ppm values are dry at 15% O2
Data from Avogadro Test dated December 2011
CO and VOC data concurrent tests, see test report tables 6-5, 6-6, 6-7, and 6-9.

Without DB



With DB



SUMMARY OUTPUT - without DB

Regression Statistics	
Multiple R	0.726995721
R Square	0.528522779
Adjusted R Squ	0.410653473
Standard Error	0.109432726
Observations	6

Eq for predicting VOC based on CO:
VOC, ppm = (CO,ppm * -0.7217) + 0.5703

ANOVA

	df	*SS*	*MS*	*F*	*Significance F*
Regression	1	0.053697914	0.053697914	4.483972966	0.101623317
Residual	4	0.047902086	0.011975521		
Total	5	0.1016			

	Coefficients	*Standard Error*	*t Stat*	*P-value*	*Lower 95%*	*Upper 95%*	*Lower 95.0%*	*Upper 95.0%*
Intercept	0.570278092	0.139696681	4.082259434	0.015070461	0.182417927	0.958138257	0.182417927	0.958138257
X Variable 1	-0.72174616	0.340841909	-2.117539366	0.101623317	-1.66807501	0.22458269	-1.66807501	0.22458269

SUMMARY OUTPUT -with DB

Regression Statistics	
Multiple R	0.960221702
R Square	0.922025717
Adjusted R Squ	0.902532147
Standard Error	0.037398713
Observations	6

Eq for predicting VOC based on CO:
VOC, ppm = (CO, ppm * -1.4866) + 0.6863

ANOVA

	df	*SS*	*MS*	*F*	*Significance F*
Regression	1	0.066155345	0.066155345	47.29896497	0.002341999
Residual	4	0.005594655	0.001398664		
Total	5	0.07175			

	Coefficients	*Standard Error*	*t Stat*	*P-value*	*Lower 95%*	*Upper 95%*	*Lower 95.0%*	*Upper 95.0%*
Intercept	0.686302895	0.061722955	11.11908683	0.000372231	0.514932499	0.857673291	0.514932499	0.857673291
X Variable 1	-1.486636971	0.216161881	-6.877424298	0.002341999	-2.086798567	-0.886475375	-2.086798567	-0.886475375

Emissions Prediction-Range of Results based on Correlations

Baseload w/o duct burners

Avg VOC ppm at 15% O2 = 0.29

Avg VOC lb/hr = 0.683

CO Range Range	Predicted VOC, ppm	Predicted VOC, lb/hr	
0.1	0.50	1.17	
0.2	0.43	1.00	
0.3	0.35	0.83	
0.4	0.28	0.66	
0.5	0.21	0.49	
0.6	0.14	0.32	
0.7	0.07	0.15	
0.8	-0.01	-0.02	
0.9	-0.08	-0.19	Non-real
1	-0.15	-0.36	values

Maximum load w/duct burners

Avg VOC ppm at 15% O2 = 0.275

Avg VOC lb/hr = 0.823

CO Range Range	Predicted VOC, ppm	Predicted VOC, lb/hr	
0.1	0.54	1.61	
0.2	0.39	1.16	
0.3	0.24	0.72	
0.4	0.09	0.27	
0.5	-0.06	-0.17	
0.6	-0.21	-0.62	
0.7	-0.35	-1.06	
0.8	-0.50	-1.51	Non-real
0.9	-0.65	-1.95	Values
1	-0.80	-2.40	

Excess Emission Report

CT1 - VOC LbPerHr 1-Hour Block Average

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:04 **Location:** Maxwell, CA

Tag Name: CT1_VOC_LbPerHr_1H
Total Operating Time: 1,512.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 696.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,512.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

CT1 - VOC Lb 1-Day Block Average

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:04 **Location:** Maxwell, CA

Tag Name: CT1_VOC_Lb_1D
Total Operating Time: 70.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 22.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	70.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

CT1 - VOC Ppmvdc 1-Hour Block Average

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:04 **Location:** Maxwell, CA

Tag Name: CT1_VOC_Ppmvdc_1H
Total Operating Time: 1,512.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 696.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,512.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

CT2 -VOC Lb 1-Day Block Average

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:04 **Location:** Maxwell, CA

Tag Name: CT2_VOC_Lb_1D
Total Operating Time: 70.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 22.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	70.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

CT2 - VOC LbPerHr 1-Hour Block Average

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:04 **Location:** Maxwell, CA

Tag Name: CT2_VOC_LbPerHr_1H
Total Operating Time: 1,528.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 680.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,528.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

CT2 - VOC Ppmvdc 1-Hour Block Average

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:04 **Location:** Maxwell, CA

Tag Name: CT2_VOC_Ppmvdc_1H
Total Operating Time: 1,528.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 680.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,528.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Daily Summary Report

CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/01/2014 00:00	-0.5	13.1	1,831.5	-0.2	1.3	1	1	1
07/01/2014 01:00	0.1	13.5	1,573.7	0.2	1.1	1	1	1
07/01/2014 02:00	-0.1	13.4	1,558.2	0.1	1.1	1	1	1
07/01/2014 03:00	0.4	13.7	1,241.5	0.4	0.9	1	1	0
07/01/2014 04:00	0.3	13.7	1,282.1	0.4	0.9	1	1	0
07/01/2014 05:00	-0.2	13.4	1,556.7	-0.1	1.1	1	1	1
07/01/2014 06:00	-0.4	13.0	1,889.6	-0.1	1.3	1	1	1
07/01/2014 07:00	-0.4	13.0	1,879.9	-0.1	1.3	1	1	1
07/01/2014 08:00	-0.5	12.9	1,906.6	-0.2	1.3	1	1	1
07/01/2014 09:00	-0.5	12.8	1,916.8	-0.2	1.3	1	1	1
07/01/2014 10:00	-0.4	12.9	1,874.0	-0.1	1.3	1	1	1
07/01/2014 11:00	-0.2	13.0	1,842.0	0.1	1.3	1	1	1
07/01/2014 12:00	-0.4	13.0	1,870.3	-0.1	1.3	1	1	1
07/01/2014 13:00	-0.5	12.8	1,887.0	-0.2	1.3	1	1	1
07/01/2014 14:00	-0.7	12.8	1,894.5	-0.4	1.3	1	1	1
07/01/2014 15:00	-0.7	12.7	1,896.5	-0.2	1.3	1	1	1
07/01/2014 16:00	-0.8	12.1	2,019.6	-0.4	1.4	1	1	1
07/01/2014 17:00	-0.5	11.6	2,122.6	-0.1	1.5	1	1	1
07/01/2014 18:00	-0.4	11.7	2,106.2	0.1	1.5	1	1	1
07/01/2014 19:00	-0.2	12.9	1,871.4	0.1	1.3	1	1	1
07/01/2014 20:00	-0.4	13.0	1,859.7	-0.1	1.3	1	1	1
07/01/2014 21:00	-0.2	13.1	1,843.1	-0.1	1.3	1	1	1
07/01/2014 22:00	-0.4	13.2	1,840.7	-0.1	1.3	1	1	1
07/01/2014 23:00	-0.4	13.3	1,840.6	-0.1	1.3	1	1	1
Average/Sum#:	-0.3	12.9	1,808.5	-0.1	1.3	24 #	24 #	22 #
Minimum:	-0.8	11.6	1,241.5	-0.4	0.9	1	1	0
Maximum:	0.4	13.7	2,122.6	0.4	1.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/02/2014 00:00	-0.4	13.3	1,841.4	-0.1	1.3	1	1	1
07/02/2014 01:00	-0.2	13.3	1,842.9	-0.1	1.3	1	1	1
07/02/2014 02:00	-0.2	13.3	1,842.6	-0.1	1.3	1	1	1
07/02/2014 03:00	-0.2	13.3	1,842.4	-0.1	1.3	1	1	1
07/02/2014 04:00	-0.4	13.1	1,910.0	-0.1	1.3	1	1	1
07/02/2014 05:00	-0.8	12.4	2,058.3	-0.4	1.4	1	1	1
07/02/2014 06:00	-0.5	12.6	1,983.1	-0.2	1.4	1	1	1
07/02/2014 07:00	-0.2	13.2	1,866.3	-0.1	1.3	1	1	1
07/02/2014 08:00	-0.2	13.2	1,872.5	-0.1	1.3	1	1	1
07/02/2014 09:00	-0.4	13.2	1,872.9	-0.1	1.3	1	1	1
07/02/2014 10:00	-0.4	13.1	1,870.0	-0.1	1.3	1	1	1
07/02/2014 11:00	-0.4	13.0	1,874.7	-0.1	1.3	1	1	1
07/02/2014 12:00	-0.2	13.0	1,881.2	0.1	1.3	1	1	1
07/02/2014 13:00	-0.4	12.9	1,884.7	-0.1	1.3	1	1	1
07/02/2014 14:00	-0.8	12.3	2,011.4	-0.4	1.4	1	1	1
07/02/2014 15:00	-0.5	11.6	2,122.1	-0.1	1.5	1	1	1
07/02/2014 16:00	-0.7	12.2	2,007.8	-0.2	1.4	1	1	1
07/02/2014 17:00	-0.7	12.5	1,957.3	-0.2	1.4	1	1	1
07/02/2014 18:00	-0.7	12.4	1,970.7	-0.2	1.4	1	1	1
07/02/2014 19:00	-0.7	12.6	1,949.3	-0.2	1.4	1	1	1
07/02/2014 20:00	-0.7	12.6	1,944.8	-0.2	1.4	1	1	1
07/02/2014 21:00	0.2	13.7	1,322.6	0.4	0.9	1	1	1
07/02/2014 22:00	0.0	16.3	366.1	0.0	0.3	1	0	0
07/02/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	-0.4	13.0	1,830.2	-0.1	1.3	23 #	22 #	22 #
Minimum:	-0.8	11.6	366.1	-0.4	0.3	0	0	0
Maximum:	0.2	16.3	2,122.1	0.4	1.5	1	1	1
%SI	4.2	4.2	4.2	4.2	4.2	0	0	0

Daily Summary Report

CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/03/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2014 03:00	0.0	16.6	578.4	0.0	0.4	1	0	0
07/03/2014 04:00	0.0	13.8	1,503.3	0.0	1.1	1	0	0
07/03/2014 05:00	0.4	13.6	1,790.3	0.4	1.3	1	1	0
07/03/2014 06:00	0.4	13.6	1,780.8	0.4	1.2	1	1	0
07/03/2014 07:00	0.4	13.7	1,728.7	0.4	1.2	1	1	0
07/03/2014 08:00	0.2	13.7	1,581.8	0.4	1.1	1	1	1
07/03/2014 09:00	-0.4	13.0	1,889.0	-0.1	1.3	1	1	1
07/03/2014 10:00	-0.4	13.0	1,884.1	-0.1	1.3	1	1	1
07/03/2014 11:00	-0.5	12.9	1,906.6	-0.2	1.3	1	1	1
07/03/2014 12:00	-0.8	12.5	1,969.1	-0.4	1.4	1	1	1
07/03/2014 13:00	-0.7	11.8	2,105.3	-0.2	1.5	1	1	1
07/03/2014 14:00	-0.5	11.6	2,129.2	-0.1	1.5	1	1	1
07/03/2014 15:00	-0.4	11.5	2,135.6	0.1	1.5	1	1	1
07/03/2014 16:00	-0.4	11.5	2,139.6	0.1	1.5	1	1	1
07/03/2014 17:00	-0.4	11.5	2,143.4	0.1	1.5	1	1	1
07/03/2014 18:00	-0.4	11.3	2,175.3	0.1	1.5	1	1	1
07/03/2014 19:00	-0.4	11.3	2,169.3	0.1	1.5	1	1	1
07/03/2014 20:00	-0.5	12.0	2,048.3	-0.1	1.4	1	1	1
07/03/2014 21:00	-0.5	12.4	1,980.0	-0.2	1.4	1	1	1
07/03/2014 22:00	-0.5	12.3	2,017.9	-0.1	1.4	1	1	1
07/03/2014 23:00	-0.4	11.4	2,203.2	0.1	1.5	1	1	1
Average/Sum#:	-0.3	12.6	1,898.1	0.0	1.3	21 #	19 #	16 #
Minimum:	-0.8	11.3	578.4	-0.4	0.4	0	0	0
Maximum:	0.4	16.6	2,203.2	0.4	1.5	1	1	1
%SI	12.5	12.5	12.5	12.5	12.5	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/04/2014 00:00	-0.4	12.5	1,994.4	-0.1	1.4	1	1	1
07/04/2014 01:00	-0.4	12.8	1,954.7	-0.1	1.4	1	1	1
07/04/2014 02:00	-0.2	13.1	1,880.8	-0.1	1.3	1	1	1
07/04/2014 03:00	-0.2	13.3	1,841.4	-0.1	1.3	1	1	1
07/04/2014 04:00	-0.2	13.1	1,887.2	-0.1	1.3	1	1	1
07/04/2014 05:00	-0.2	13.2	1,874.0	-0.1	1.3	1	1	1
07/04/2014 06:00	-0.2	13.2	1,873.9	-0.1	1.3	1	1	1
07/04/2014 07:00	-0.2	13.2	1,871.3	-0.1	1.3	1	1	1
07/04/2014 08:00	-0.5	12.9	1,936.2	-0.2	1.4	1	1	1
07/04/2014 09:00	-0.7	12.8	1,945.0	-0.4	1.4	1	1	1
07/04/2014 10:00	-0.5	12.6	1,983.2	-0.2	1.4	1	1	1
07/04/2014 11:00	-0.4	11.3	2,211.8	0.1	1.5	1	1	1
07/04/2014 12:00	-0.5	11.9	2,084.9	-0.1	1.5	1	1	1
07/04/2014 13:00	-0.4	12.7	1,924.4	-0.1	1.3	1	1	1
07/04/2014 14:00	-0.5	12.7	1,928.0	-0.2	1.3	1	1	1
07/04/2014 15:00	-0.5	12.6	1,932.2	-0.2	1.4	1	1	1
07/04/2014 16:00	-0.5	12.5	1,960.6	-0.2	1.4	1	1	1
07/04/2014 17:00	-0.5	12.5	1,964.6	-0.2	1.4	1	1	1
07/04/2014 18:00	0.2	13.6	1,475.5	0.4	1.0	1	1	1
07/04/2014 19:00	0.4	14.0	1,281.6	0.4	0.9	1	1	0
07/04/2014 20:00	0.0	16.5	345.3	0.0	0.2	1	0	0
07/04/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	-0.3	13.0	1,816.7	-0.1	1.3	21 #	20 #	19 #
Minimum:	-0.7	11.3	345.3	-0.4	0.2	0	0	0
Maximum:	0.4	16.5	2,211.8	0.4	1.5	1	1	1
%SI	12.5	12.5	12.5	12.5	12.5	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/05/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2014 06:00	0.0	17.2	498.8	0.0	0.3	1	0	0
07/05/2014 07:00	0.0	15.2	838.3	0.0	0.6	1	0	0
07/05/2014 08:00	0.4	13.8	1,490.7	0.4	1.0	1	1	0
07/05/2014 09:00	0.4	13.8	1,775.1	0.4	1.2	1	1	0
07/05/2014 10:00	0.4	13.7	1,750.1	0.4	1.2	1	1	0
07/05/2014 11:00	0.4	13.8	1,498.2	0.4	1.0	1	1	0
07/05/2014 12:00	-0.7	12.7	1,959.9	-0.2	1.4	1	1	1
07/05/2014 13:00	-0.8	12.1	2,084.0	-0.4	1.5	1	1	1
07/05/2014 14:00	-0.4	12.8	1,920.1	-0.1	1.3	1	1	1
07/05/2014 15:00	-0.5	12.8	1,900.0	-0.2	1.3	1	1	1
07/05/2014 16:00	-0.7	12.6	1,927.2	-0.2	1.3	1	1	1
07/05/2014 17:00	-0.7	12.5	1,970.8	-0.2	1.4	1	1	1
07/05/2014 18:00	-0.5	12.7	1,930.5	-0.2	1.4	1	1	1
07/05/2014 19:00	-0.2	13.0	1,870.7	0.1	1.3	1	1	1
07/05/2014 20:00	-0.2	13.1	1,866.3	-0.1	1.3	1	1	1
07/05/2014 21:00	-0.2	13.1	1,860.0	-0.1	1.3	1	1	1
07/05/2014 22:00	0.1	13.6	1,548.7	0.2	1.1	1	1	1
07/05/2014 23:00	0.4	13.6	1,767.9	0.4	1.2	1	1	0
Average/Sum#:	-0.2	13.5	1,692.1	0.0	1.2	18 #	16 #	11 #
Minimum:	-0.8	12.1	498.8	-0.4	0.3	0	0	0
Maximum:	0.4	17.2	2,084.0	0.4	1.5	1	1	1
%SI	25.0	25.0	25.0	25.0	25.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/06/2014 00:00	0.4	13.6	1,775.9	0.4	1.2	1	1	0
07/06/2014 01:00	0.3	13.7	1,484.5	0.4	1.0	1	1	0
07/06/2014 02:00	0.0	16.7	308.3	0.0	0.2	1	0	0
07/06/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2014 05:00	0.0	17.5	458.8	0.0	0.3	1	0	0
07/06/2014 06:00	0.0	14.7	1,073.8	0.0	0.8	1	0	0
07/06/2014 07:00	0.4	13.7	1,767.2	0.4	1.2	1	1	0
07/06/2014 08:00	0.4	13.8	1,610.0	0.4	1.1	1	1	0
07/06/2014 09:00	0.4	13.9	1,692.7	0.4	1.2	1	1	0
07/06/2014 10:00	0.4	13.9	1,436.1	0.4	1.0	1	1	0
07/06/2014 11:00	-0.4	13.3	1,749.7	-0.1	1.2	1	1	1
07/06/2014 12:00	-0.7	12.9	1,897.0	-0.4	1.3	1	1	1
07/06/2014 13:00	-0.4	13.0	1,865.2	-0.1	1.3	1	1	1
07/06/2014 14:00	-0.2	13.1	1,861.0	-0.1	1.3	1	1	1
07/06/2014 15:00	-0.2	13.0	1,857.2	0.1	1.3	1	1	1
07/06/2014 16:00	-0.5	12.8	1,897.6	-0.2	1.3	1	1	1
07/06/2014 17:00	-0.7	12.2	2,040.0	-0.2	1.4	1	1	1
07/06/2014 18:00	-0.5	11.7	2,128.9	-0.1	1.5	1	1	1
07/06/2014 19:00	-0.7	12.1	2,051.6	-0.2	1.4	1	1	1
07/06/2014 20:00	-0.5	12.0	2,073.1	-0.1	1.5	1	1	1
07/06/2014 21:00	-0.4	12.9	1,885.8	-0.1	1.3	1	1	1
07/06/2014 22:00	-0.2	13.1	1,853.3	-0.1	1.3	1	1	1
07/06/2014 23:00	-0.4	13.2	1,835.8	-0.1	1.3	1	1	1
Average/Sum#:	-0.2	13.5	1,663.8	0.0	1.2	22 #	19 #	13 #
Minimum:	-0.7	11.7	308.3	-0.4	0.2	0	0	0
Maximum:	0.4	17.5	2,128.9	0.4	1.5	1	1	1
%SI	8.3	8.3	8.3	8.3	8.3	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/07/2014 00:00	0.4	13.9	1,275.2	0.4	0.9	1	1	0
07/07/2014 01:00	0.4	13.9	1,251.6	0.4	0.9	1	1	0
07/07/2014 02:00	0.4	13.9	1,279.7	0.4	0.9	1	1	0
07/07/2014 03:00	0.4	13.9	1,332.2	0.4	0.9	1	1	0
07/07/2014 04:00	-0.5	13.2	1,871.1	-0.2	1.3	1	1	1
07/07/2014 05:00	-0.5	13.3	1,866.1	-0.2	1.3	1	1	1
07/07/2014 06:00	-0.5	13.3	1,847.1	-0.2	1.3	1	1	1
07/07/2014 07:00	-0.5	13.2	1,847.6	-0.2	1.3	1	1	1
07/07/2014 08:00	-0.5	13.1	1,867.4	-0.2	1.3	1	1	1
07/07/2014 09:00	-0.4	13.1	1,853.8	-0.1	1.3	1	1	1
07/07/2014 10:00	-0.5	13.0	1,867.8	-0.2	1.3	1	1	1
07/07/2014 11:00	-0.4	13.1	1,844.5	-0.1	1.3	1	1	1
07/07/2014 12:00	-0.4	13.0	1,852.1	-0.1	1.3	1	1	1
07/07/2014 13:00	-0.5	13.0	1,855.6	-0.2	1.3	1	1	1
07/07/2014 14:00	-0.4	13.0	1,849.6	-0.1	1.3	1	1	1
07/07/2014 15:00	-0.5	13.0	1,848.1	-0.2	1.3	1	1	1
07/07/2014 16:00	-0.5	12.9	1,852.3	-0.2	1.3	1	1	1
07/07/2014 17:00	-0.7	12.9	1,874.1	-0.4	1.3	1	1	1
07/07/2014 18:00	-0.7	12.9	1,887.2	-0.4	1.3	1	1	1
07/07/2014 19:00	-0.7	12.8	1,900.3	-0.4	1.3	1	1	1
07/07/2014 20:00	-0.4	13.0	1,854.0	-0.1	1.3	1	1	1
07/07/2014 21:00	-0.2	13.1	1,839.9	-0.1	1.3	1	1	1
07/07/2014 22:00	-0.2	13.3	1,677.1	-0.1	1.2	1	1	1
07/07/2014 23:00	-0.4	13.2	1,846.1	-0.1	1.3	1	1	1
Average/Sum#:	-0.3	13.2	1,755.9	-0.1	1.2	24 #	24 #	20 #
Minimum:	-0.7	12.8	1,251.6	-0.4	0.9	1	1	0
Maximum:	0.4	13.9	1,900.3	0.4	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/08/2014 00:00	-0.7	13.0	1,873.0	-0.4	1.3	1	1	1
07/08/2014 01:00	-0.4	13.2	1,850.2	-0.1	1.3	1	1	1
07/08/2014 02:00	-0.4	13.2	1,847.9	-0.1	1.3	1	1	1
07/08/2014 03:00	-0.4	13.4	1,719.7	-0.2	1.2	1	1	1
07/08/2014 04:00	-0.9	12.9	1,913.5	-0.5	1.3	1	1	1
07/08/2014 05:00	-0.5	13.2	1,854.5	-0.2	1.3	1	1	1
07/08/2014 06:00	-0.9	12.8	1,925.8	-0.5	1.3	1	1	1
07/08/2014 07:00	-0.5	13.1	1,862.4	-0.2	1.3	1	1	1
07/08/2014 08:00	-0.5	13.0	1,883.1	-0.2	1.3	1	1	1
07/08/2014 09:00	-0.4	13.1	1,858.9	-0.1	1.3	1	1	1
07/08/2014 10:00	-0.8	12.7	1,939.6	-0.4	1.4	1	1	1
07/08/2014 11:00	-0.8	12.7	1,923.0	-0.4	1.3	1	1	1
07/08/2014 12:00	-0.8	12.1	2,063.8	-0.4	1.4	1	1	1
07/08/2014 13:00	-0.7	11.4	2,193.8	-0.2	1.5	1	1	1
07/08/2014 14:00	-0.5	11.6	2,119.4	-0.1	1.5	1	1	1
07/08/2014 15:00	-0.7	11.7	2,107.0	-0.2	1.5	1	1	1
07/08/2014 16:00	-0.5	11.7	2,115.1	-0.1	1.5	1	1	1
07/08/2014 17:00	-0.5	11.7	2,122.1	-0.1	1.5	1	1	1
07/08/2014 18:00	-0.5	12.0	2,058.5	-0.1	1.4	1	1	1
07/08/2014 19:00	-0.7	12.4	1,975.7	-0.2	1.4	1	1	1
07/08/2014 20:00	-0.4	13.0	1,871.9	-0.1	1.3	1	1	1
07/08/2014 21:00	-0.2	13.1	1,856.9	-0.1	1.3	1	1	1
07/08/2014 22:00	0.2	13.6	1,487.5	0.4	1.0	1	1	1
07/08/2014 23:00	0.4	13.9	1,381.5	0.4	1.0	1	1	0
Average/Sum#:	-0.5	12.7	1,908.5	-0.2	1.3	24 #	24 #	23 #
Minimum:	-0.9	11.4	1,381.5	-0.5	1.0	1	1	0
Maximum:	0.4	13.9	2,193.8	0.4	1.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/09/2014 00:00	0.3	13.9	1,245.0	0.4	0.9	1	1	0
07/09/2014 01:00	0.3	13.8	1,242.6	0.4	0.9	1	1	0
07/09/2014 02:00	0.3	13.8	1,241.6	0.4	0.9	1	1	0
07/09/2014 03:00	0.3	13.8	1,241.7	0.4	0.9	1	1	0
07/09/2014 04:00	0.3	13.8	1,252.1	0.4	0.9	1	1	0
07/09/2014 05:00	0.3	13.8	1,547.2	0.4	1.1	1	1	0
07/09/2014 06:00	-0.1	13.5	1,651.8	0.1	1.2	1	1	1
07/09/2014 07:00	-0.8	12.8	1,958.0	-0.4	1.4	1	1	1
07/09/2014 08:00	-0.5	12.8	1,937.8	-0.2	1.4	1	1	1
07/09/2014 09:00	-0.8	12.4	2,004.4	-0.4	1.4	1	1	1
07/09/2014 10:00	-0.7	11.9	2,102.5	-0.2	1.5	1	1	1
07/09/2014 11:00	-0.5	11.5	2,165.4	-0.1	1.5	1	1	1
07/09/2014 12:00	-0.4	11.4	2,187.1	0.1	1.5	1	1	1
07/09/2014 13:00	-0.4	11.5	2,147.8	0.1	1.5	1	1	1
07/09/2014 14:00	-0.5	12.2	1,998.1	-0.1	1.4	1	1	1
07/09/2014 15:00	-0.4	11.9	2,066.3	-0.1	1.4	1	1	1
07/09/2014 16:00	-0.4	11.6	2,113.3	0.1	1.5	1	1	1
07/09/2014 17:00	-0.4	11.6	2,105.5	0.1	1.5	1	1	1
07/09/2014 18:00	-0.5	12.1	2,008.0	-0.1	1.4	1	1	1
07/09/2014 19:00	-0.5	12.5	1,940.7	-0.2	1.4	1	1	1
07/09/2014 20:00	-0.7	12.5	1,960.0	-0.2	1.4	1	1	1
07/09/2014 21:00	-0.5	12.6	1,929.8	-0.2	1.4	1	1	1
07/09/2014 22:00	-0.5	12.8	1,909.0	-0.2	1.3	1	1	1
07/09/2014 23:00	-0.1	13.5	1,450.9	0.1	1.0	1	1	1
Average/Sum#:	-0.3	12.7	1,808.6	0.0	1.3	24 #	24 #	18 #
Minimum:	-0.8	11.4	1,241.6	-0.4	0.9	1	1	0
Maximum:	0.3	13.9	2,187.1	0.4	1.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/10/2014 00:00	0.4	13.8	1,238.8	0.4	0.9	1	1	0
07/10/2014 01:00	0.4	13.8	1,238.3	0.4	0.9	1	1	0
07/10/2014 02:00	0.3	13.8	1,238.7	0.4	0.9	1	1	0
07/10/2014 03:00	0.4	13.8	1,238.2	0.4	0.9	1	1	0
07/10/2014 04:00	0.3	13.8	1,238.7	0.4	0.9	1	1	0
07/10/2014 05:00	0.3	13.8	1,240.2	0.4	0.9	1	1	0
07/10/2014 06:00	0.4	13.8	1,241.5	0.4	0.9	1	1	0
07/10/2014 07:00	0.3	13.8	1,248.1	0.4	0.9	1	1	0
07/10/2014 08:00	0.4	13.8	1,258.6	0.4	0.9	1	1	0
07/10/2014 09:00	-0.2	13.5	1,563.1	-0.1	1.1	1	1	1
07/10/2014 10:00	-0.4	13.2	1,846.0	-0.1	1.3	1	1	1
07/10/2014 11:00	-0.4	13.2	1,841.5	-0.1	1.3	1	1	1
07/10/2014 12:00	-0.2	13.1	1,874.5	-0.1	1.3	1	1	1
07/10/2014 13:00	-0.5	12.9	1,889.1	-0.2	1.3	1	1	1
07/10/2014 14:00	-0.9	12.8	1,895.5	-0.5	1.3	1	1	1
07/10/2014 15:00	-0.8	12.8	1,884.3	-0.4	1.3	1	1	1
07/10/2014 16:00	-0.8	12.5	1,937.5	-0.4	1.4	1	1	1
07/10/2014 17:00	-0.9	12.8	1,897.4	-0.5	1.3	1	1	1
07/10/2014 18:00	-1.5	12.6	1,944.7	-0.9	1.4	1	1	1
07/10/2014 19:00	-0.8	13.1	1,841.3	-0.5	1.3	1	1	1
07/10/2014 20:00	-0.7	13.2	1,837.6	-0.4	1.3	1	1	1
07/10/2014 21:00	-0.5	13.2	1,849.0	-0.2	1.3	1	1	1
07/10/2014 22:00	-0.4	13.3	1,830.4	-0.1	1.3	1	1	1
07/10/2014 23:00	-0.4	13.3	1,641.4	-0.1	1.1	1	1	1
Average/Sum#:	-0.3	13.3	1,614.8	0.0	1.1	24 #	24 #	15 #
Minimum:	-1.5	12.5	1,238.2	-0.9	0.9	1	1	0
Maximum:	0.4	13.8	1,944.7	0.4	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/11/2014 00:00	0.3	13.8	1,271.9	0.4	0.9	1	1	0
07/11/2014 01:00	0.0	15.7	618.1	0.0	0.4	1	0	0
07/11/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2014 05:00	0.0	17.3	489.5	0.0	0.3	1	0	0
07/11/2014 06:00	0.0	14.5	1,039.4	0.0	0.7	1	0	0
07/11/2014 07:00	0.4	13.8	1,288.4	0.4	0.9	1	1	0
07/11/2014 08:00	0.3	13.8	1,292.3	0.4	0.9	1	1	0
07/11/2014 09:00	0.4	13.8	1,497.6	0.4	1.0	1	1	0
07/11/2014 10:00	0.4	13.9	1,298.3	0.4	0.9	1	1	0
07/11/2014 11:00	0.4	13.9	1,270.7	0.4	0.9	1	1	0
07/11/2014 12:00	0.4	13.9	1,271.3	0.4	0.9	1	1	0
07/11/2014 13:00	0.4	13.9	1,271.5	0.4	0.9	1	1	0
07/11/2014 14:00	0.4	13.9	1,273.6	0.4	0.9	1	1	0
07/11/2014 15:00	0.4	14.0	1,275.2	0.4	0.9	1	1	0
07/11/2014 16:00	0.4	14.0	1,275.8	0.4	0.9	1	1	0
07/11/2014 17:00	0.4	14.0	1,275.3	0.4	0.9	1	1	0
07/11/2014 18:00	0.4	13.9	1,271.2	0.4	0.9	1	1	0
07/11/2014 19:00	0.4	13.9	1,268.9	0.4	0.9	1	1	0
07/11/2014 20:00	0.4	13.9	1,269.3	0.4	0.9	1	1	0
07/11/2014 21:00	0.3	13.9	1,262.7	0.4	0.9	1	1	0
07/11/2014 22:00	0.3	13.8	1,262.6	0.4	0.9	1	1	0
07/11/2014 23:00	0.3	13.8	1,263.2	0.4	0.9	1	1	0
Average/Sum#:	0.3	14.2	1,205.1	0.3	0.8	21 #	18 #	0 #
Minimum:	0.0	13.8	489.5	0.0	0.3	0	0	0
Maximum:	0.4	17.3	1,497.6	0.4	1.0	1	1	0
%SI	12.5	12.5	12.5	12.5	12.5	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/12/2014 00:00	0.0	15.8	532.4	0.0	0.4	1	0	0
07/12/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2014 11:00	0.0	16.6	619.4	0.0	0.4	1	0	0
07/12/2014 12:00	0.0	13.9	1,344.5	0.0	0.9	1	0	0
07/12/2014 13:00	0.4	13.7	1,648.0	0.4	1.2	1	1	0
07/12/2014 14:00	-0.1	13.3	1,758.5	0.1	1.2	1	1	1
07/12/2014 15:00	-0.9	12.0	2,045.8	-0.4	1.4	1	1	1
07/12/2014 16:00	-0.7	12.7	1,917.9	-0.2	1.3	1	1	1
07/12/2014 17:00	-0.7	12.6	1,935.3	-0.2	1.4	1	1	1
07/12/2014 18:00	-0.5	12.7	1,923.9	-0.2	1.3	1	1	1
07/12/2014 19:00	-0.2	13.0	1,861.4	0.1	1.3	1	1	1
07/12/2014 20:00	-0.4	13.0	1,869.9	-0.1	1.3	1	1	1
07/12/2014 21:00	-0.8	12.7	1,950.9	-0.4	1.4	1	1	1
07/12/2014 22:00	-0.9	12.4	2,007.3	-0.5	1.4	1	1	1
07/12/2014 23:00	-0.7	12.7	1,946.8	-0.2	1.4	1	1	1
Average/Sum#:	-0.4	13.4	1,668.7	-0.1	1.2	14 #	11 #	10 #
Minimum:	-0.9	12.0	532.4	-0.5	0.4	0	0	0
Maximum:	0.4	16.6	2,045.8	0.4	1.4	1	1	1
%SI	41.7	41.7	41.7	41.7	41.7	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/13/2014 00:00	-0.1	13.3	1,654.0	0.1	1.2	1	1	1
07/13/2014 01:00	0.0	15.8	536.4	0.0	0.4	1	0	0
07/13/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2014 06:00	0.0	17.5	450.6	0.0	0.3	1	0	0
07/13/2014 07:00	0.0	15.1	940.5	0.0	0.7	1	0	0
07/13/2014 08:00	0.4	13.8	1,462.3	0.4	1.0	1	1	0
07/13/2014 09:00	0.4	13.7	1,737.2	0.4	1.2	1	1	0
07/13/2014 10:00	0.4	13.8	1,678.7	0.4	1.2	1	1	0
07/13/2014 11:00	0.2	13.8	1,492.9	0.4	1.0	1	1	1
07/13/2014 12:00	-0.5	12.9	1,889.4	-0.2	1.3	1	1	1
07/13/2014 13:00	-0.8	12.1	2,020.0	-0.4	1.4	1	1	1
07/13/2014 14:00	-0.5	11.8	2,076.1	-0.1	1.5	1	1	1
07/13/2014 15:00	-0.4	11.3	2,170.6	0.1	1.5	1	1	1
07/13/2014 16:00	-0.5	12.1	2,010.0	-0.1	1.4	1	1	1
07/13/2014 17:00	-0.5	12.3	1,978.9	-0.1	1.4	1	1	1
07/13/2014 18:00	-0.7	12.2	1,984.7	-0.2	1.4	1	1	1
07/13/2014 19:00	-0.5	12.8	1,881.4	-0.2	1.3	1	1	1
07/13/2014 20:00	0.1	13.6	1,539.0	0.2	1.1	1	1	1
07/13/2014 21:00	-0.1	13.3	1,755.2	0.1	1.2	1	1	1
07/13/2014 22:00	-0.8	12.7	1,896.1	-0.4	1.3	1	1	1
07/13/2014 23:00	0.2	13.6	1,465.0	0.4	1.0	1	1	1
Average/Sum#:	-0.2	13.4	1,631.0	0.0	1.1	20 #	17 #	14 #
Minimum:	-0.8	11.3	450.6	-0.4	0.3	0	0	0
Maximum:	0.4	17.5	2,170.6	0.4	1.5	1	1	1
%SI	16.7	16.7	16.7	16.7	16.7	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/14/2014 00:00	0.4	13.9	1,379.9	0.4	1.0	1	1	0
07/14/2014 01:00	0.4	13.9	1,471.6	0.4	1.0	1	1	0
07/14/2014 02:00	0.4	13.9	1,408.9	0.4	1.0	1	1	0
07/14/2014 03:00	0.4	13.7	1,722.2	0.4	1.2	1	1	0
07/14/2014 04:00	0.3	13.7	1,726.7	0.4	1.2	1	1	0
07/14/2014 05:00	0.1	13.7	1,607.7	0.2	1.1	1	1	1
07/14/2014 06:00	-0.9	12.5	2,026.1	-0.5	1.4	1	1	1
07/14/2014 07:00	-0.7	12.8	1,960.1	-0.4	1.4	1	1	1
07/14/2014 08:00	-0.4	12.9	1,897.6	-0.1	1.3	1	1	1
07/14/2014 09:00	-0.5	12.8	1,917.3	-0.2	1.3	1	1	1
07/14/2014 10:00	-0.4	13.0	1,860.8	-0.1	1.3	1	1	1
07/14/2014 11:00	-0.5	12.9	1,875.0	-0.2	1.3	1	1	1
07/14/2014 12:00	-0.7	12.8	1,883.4	-0.4	1.3	1	1	1
07/14/2014 13:00	-0.7	12.5	1,942.5	-0.2	1.4	1	1	1
07/14/2014 14:00	-0.5	11.7	2,077.2	-0.1	1.5	1	1	1
07/14/2014 15:00	-0.5	11.7	2,060.8	-0.1	1.4	1	1	1
07/14/2014 16:00	-0.5	11.9	2,017.8	-0.1	1.4	1	1	1
07/14/2014 17:00	-0.5	12.2	1,968.7	-0.1	1.4	1	1	1
07/14/2014 18:00	0.4	13.6	1,551.8	0.4	1.1	1	1	1
07/14/2014 19:00	0.4	13.9	1,439.1	0.4	1.0	1	1	0
07/14/2014 20:00	0.4	13.7	1,629.1	0.4	1.1	1	1	0
07/14/2014 21:00	0.4	13.8	1,637.9	0.4	1.1	1	1	0
07/14/2014 22:00	0.3	13.8	1,508.1	0.4	1.1	1	1	0
07/14/2014 23:00	0.4	13.7	1,646.9	0.4	1.2	1	1	0
Average/Sum#:	-0.1	13.1	1,759.1	0.1	1.2	24 #	24 #	14 #
Minimum:	-0.9	11.7	1,379.9	-0.5	1.0	1	1	0
Maximum:	0.4	13.9	2,077.2	0.4	1.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/15/2014 00:00	0.4	13.6	1,747.0	0.4	1.2	1	1	0
07/15/2014 01:00	0.4	13.6	1,773.9	0.4	1.2	1	1	0
07/15/2014 02:00	0.4	13.6	1,769.2	0.4	1.2	1	1	0
07/15/2014 03:00	-0.1	13.3	1,809.2	0.1	1.3	1	1	1
07/15/2014 04:00	-0.7	12.9	1,938.7	-0.4	1.4	1	1	1
07/15/2014 05:00	-0.7	12.6	1,989.8	-0.2	1.4	1	1	1
07/15/2014 06:00	-0.4	13.0	1,890.3	-0.1	1.3	1	1	1
07/15/2014 07:00	-0.2	13.3	1,844.4	-0.1	1.3	1	1	1
07/15/2014 08:00	-0.4	13.3	1,840.0	-0.1	1.3	1	1	1
07/15/2014 09:00	-0.8	13.2	1,851.3	-0.5	1.3	1	1	1
07/15/2014 10:00	-0.4	13.1	1,874.1	-0.1	1.3	1	1	1
07/15/2014 11:00	-0.4	13.1	1,869.6	-0.1	1.3	1	1	1
07/15/2014 12:00	-0.2	13.1	1,859.7	-0.1	1.3	1	1	1
07/15/2014 13:00	-0.2	13.2	1,855.3	-0.1	1.3	1	1	1
07/15/2014 14:00	-0.7	12.9	1,923.3	-0.4	1.3	1	1	1
07/15/2014 15:00	-0.7	12.7	1,925.1	-0.2	1.3	1	1	1
07/15/2014 16:00	-0.4	12.9	1,879.3	-0.1	1.3	1	1	1
07/15/2014 17:00	-0.7	12.8	1,908.7	-0.4	1.3	1	1	1
07/15/2014 18:00	-0.5	12.8	1,882.9	-0.2	1.3	1	1	1
07/15/2014 19:00	-0.7	12.8	1,903.6	-0.4	1.3	1	1	1
07/15/2014 20:00	-0.7	12.8	1,891.8	-0.4	1.3	1	1	1
07/15/2014 21:00	-0.7	12.8	1,901.4	-0.4	1.3	1	1	1
07/15/2014 22:00	-0.7	12.9	1,888.8	-0.4	1.3	1	1	1
07/15/2014 23:00	-0.9	12.8	1,915.0	-0.5	1.3	1	1	1
Average/Sum#:	-0.4	13.0	1,872.2	-0.2	1.3	24 #	24 #	21 #
Minimum:	-0.9	12.6	1,747.0	-0.5	1.2	1	1	0
Maximum:	0.4	13.6	1,989.8	0.4	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/16/2014 00:00	-0.7	12.9	1,880.1	-0.4	1.3	1	1	1
07/16/2014 01:00	-0.1	13.6	1,472.9	0.1	1.0	1	1	1
07/16/2014 02:00	0.4	13.8	1,421.7	0.4	1.0	1	1	0
07/16/2014 03:00	0.4	13.8	1,468.9	0.4	1.0	1	1	0
07/16/2014 04:00	0.4	13.6	1,743.9	0.4	1.2	1	1	0
07/16/2014 05:00	-0.1	13.5	1,618.2	0.1	1.1	1	1	1
07/16/2014 06:00	-0.2	13.4	1,709.5	-0.1	1.2	1	1	1
07/16/2014 07:00	0.4	13.8	1,587.8	0.4	1.1	1	1	0
07/16/2014 08:00	0.1	13.6	1,697.8	0.2	1.2	1	1	1
07/16/2014 09:00	-0.5	13.2	1,841.3	-0.2	1.3	1	1	1
07/16/2014 10:00	-0.2	13.2	1,844.3	-0.1	1.3	1	1	1
07/16/2014 11:00	-0.2	13.2	1,844.6	-0.1	1.3	1	1	1
07/16/2014 12:00	-0.2	13.2	1,840.2	-0.1	1.3	1	1	1
07/16/2014 13:00	-0.2	13.1	1,842.6	-0.1	1.3	1	1	1
07/16/2014 14:00	-0.4	13.0	1,849.6	-0.1	1.3	1	1	1
07/16/2014 15:00	-0.4	13.0	1,852.3	-0.1	1.3	1	1	1
07/16/2014 16:00	-0.5	12.9	1,863.8	-0.2	1.3	1	1	1
07/16/2014 17:00	-0.7	12.9	1,872.4	-0.4	1.3	1	1	1
07/16/2014 18:00	-0.5	12.9	1,867.5	-0.2	1.3	1	1	1
07/16/2014 19:00	-0.4	13.0	1,851.4	-0.1	1.3	1	1	1
07/16/2014 20:00	-0.4	13.0	1,844.4	-0.1	1.3	1	1	1
07/16/2014 21:00	0.2	13.6	1,580.6	0.4	1.1	1	1	1
07/16/2014 22:00	0.1	13.5	1,698.8	0.2	1.2	1	1	1
07/16/2014 23:00	-0.1	13.4	1,673.5	0.1	1.2	1	1	1
Average/Sum#:	-0.2	13.3	1,740.3	0.0	1.2	24 #	24 #	20 #
Minimum:	-0.7	12.9	1,421.7	-0.4	1.0	1	1	0
Maximum:	0.4	13.8	1,880.1	0.4	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/17/2014 00:00	0.0	15.7	561.9	0.0	0.4	1	0	0
07/17/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/17/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/17/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/17/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/17/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/17/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/17/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/17/2014 08:00	0.0	17.7	421.5	0.0	0.3	1	0	0
07/17/2014 09:00	0.0	14.5	1,202.2	0.0	0.8	1	0	0
07/17/2014 10:00	0.1	13.5	1,599.6	0.2	1.1	1	1	1
07/17/2014 11:00	-0.2	13.2	1,822.5	-0.1	1.3	1	1	1
07/17/2014 12:00	-0.1	13.2	1,818.0	0.1	1.3	1	1	1
07/17/2014 13:00	-0.1	13.1	1,826.4	0.1	1.3	1	1	1
07/17/2014 14:00	-0.2	13.1	1,823.4	-0.1	1.3	1	1	1
07/17/2014 15:00	-0.2	13.0	1,831.6	0.1	1.3	1	1	1
07/17/2014 16:00	-0.4	13.0	1,837.2	-0.1	1.3	1	1	1
07/17/2014 17:00	-0.4	12.9	1,850.3	-0.1	1.3	1	1	1
07/17/2014 18:00	-0.8	12.5	1,927.1	-0.4	1.3	1	1	1
07/17/2014 19:00	-0.8	12.4	1,950.1	-0.4	1.4	1	1	1
07/17/2014 20:00	-0.4	12.9	1,857.3	-0.1	1.3	1	1	1
07/17/2014 21:00	-0.7	12.8	1,896.9	-0.4	1.3	1	1	1
07/17/2014 22:00	-0.1	13.5	1,645.9	0.1	1.2	1	1	1
07/17/2014 23:00	0.4	13.8	1,405.0	0.4	1.0	1	1	0
Average/Sum#:	-0.2	13.6	1,604.5	0.0	1.1	17 #	14 #	13 #
Minimum:	-0.8	12.4	421.5	-0.4	0.3	0	0	0
Maximum:	0.4	17.7	1,950.1	0.4	1.4	1	1	1
%SI	29.2	29.2	29.2	29.2	29.2	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/18/2014 00:00	0.0	15.7	558.4	0.0	0.4	1	0	0
07/18/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/18/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/18/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/18/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/18/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/18/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/18/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/18/2014 08:00	0.0	16.4	649.6	0.0	0.5	1	0	0
07/18/2014 09:00	0.0	13.5	1,579.6	0.0	1.1	1	0	1
07/18/2014 10:00	-0.2	13.2	1,851.7	-0.1	1.3	1	1	1
07/18/2014 11:00	-0.2	13.2	1,843.0	-0.1	1.3	1	1	1
07/18/2014 12:00	-0.2	13.3	1,836.9	-0.1	1.3	1	1	1
07/18/2014 13:00	-0.2	13.2	1,838.2	-0.1	1.3	1	1	1
07/18/2014 14:00	-0.1	13.2	1,835.3	0.1	1.3	1	1	1
07/18/2014 15:00	-0.2	13.0	1,866.3	0.1	1.3	1	1	1
07/18/2014 16:00	-0.5	12.9	1,889.4	-0.2	1.3	1	1	1
07/18/2014 17:00	-0.7	11.7	2,120.5	-0.2	1.5	1	1	1
07/18/2014 18:00	-0.5	11.5	2,137.3	-0.1	1.5	1	1	1
07/18/2014 19:00	-0.5	11.9	2,074.8	-0.1	1.5	1	1	1
07/18/2014 20:00	-0.5	12.4	1,978.8	-0.2	1.4	1	1	1
07/18/2014 21:00	-0.1	13.1	1,849.9	0.1	1.3	1	1	1
07/18/2014 22:00	0.1	13.5	1,600.5	0.2	1.1	1	1	1
07/18/2014 23:00	0.4	13.8	1,298.0	0.4	0.9	1	1	0
Average/Sum#:	-0.2	13.3	1,694.6	0.0	1.2	17 #	14 #	14 #
Minimum:	-0.7	11.5	558.4	-0.2	0.4	0	0	0
Maximum:	0.4	16.4	2,137.3	0.4	1.5	1	1	1
%SI	29.2	29.2	29.2	29.2	29.2	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/19/2014 00:00	0.0	15.1	830.2	0.0	0.6	1	0	0
07/19/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/19/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/19/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/19/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/19/2014 05:00	0.0	17.6	436.7	0.0	0.3	1	0	0
07/19/2014 06:00	0.0	14.9	1,030.7	0.0	0.7	1	0	0
07/19/2014 07:00	0.4	13.6	1,768.0	0.4	1.2	1	1	0
07/19/2014 08:00	0.4	13.6	1,752.8	0.4	1.2	1	1	0
07/19/2014 09:00	0.4	13.7	1,739.6	0.4	1.2	1	1	0
07/19/2014 10:00	0.2	13.8	1,515.4	0.4	1.1	1	1	1
07/19/2014 11:00	-0.8	12.1	2,042.1	-0.4	1.4	1	1	1
07/19/2014 12:00	-0.5	11.5	2,129.9	-0.1	1.5	1	1	1
07/19/2014 13:00	-0.2	11.1	2,212.3	0.1	1.5	1	1	1
07/19/2014 14:00	-0.2	11.3	2,178.4	0.1	1.5	1	1	1
07/19/2014 15:00	-0.2	11.3	2,159.6	0.1	1.5	1	1	1
07/19/2014 16:00	-0.4	11.5	2,110.5	0.1	1.5	1	1	1
07/19/2014 17:00	-0.4	11.6	2,100.1	0.1	1.5	1	1	1
07/19/2014 18:00	-0.5	12.4	1,951.9	-0.2	1.4	1	1	1
07/19/2014 19:00	-0.5	11.9	2,049.3	-0.1	1.4	1	1	1
07/19/2014 20:00	-0.4	11.5	2,124.9	0.1	1.5	1	1	1
07/19/2014 21:00	-0.7	12.2	1,991.9	-0.2	1.4	1	1	1
07/19/2014 22:00	0.4	13.7	1,529.6	0.4	1.1	1	1	1
07/19/2014 23:00	0.4	13.8	1,502.3	0.4	1.1	1	1	0
Average/Sum#:	-0.1	12.9	1,757.8	0.1	1.2	20 #	17 #	13 #
Minimum:	-0.8	11.1	436.7	-0.4	0.3	0	0	0
Maximum:	0.4	17.6	2,212.3	0.4	1.5	1	1	1
%SI	16.7	16.7	16.7	16.7	16.7	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/20/2014 00:00	0.0	15.7	554.2	0.0	0.4	1	0	0
07/20/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	15.7	554.2	0.0	0.4	1 #	0 #	0 #
Minimum:	0.0	15.7	554.2	0.0	0.4	0	0	0
Maximum:	0.0	15.7	554.2	0.0	0.4	1	0	0
%SI	95.8	95.8	95.8	95.8	95.8	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/21/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2014 06:00	0.0	17.2	492.7	0.0	0.3	1	0	0
07/21/2014 07:00	0.0	14.4	1,206.8	0.0	0.8	1	0	1
07/21/2014 08:00	-0.2	13.0	1,890.5	0.1	1.3	1	1	1
07/21/2014 09:00	-0.7	12.7	1,934.8	-0.2	1.4	1	1	1
07/21/2014 10:00	-0.5	12.8	1,935.6	-0.2	1.4	1	1	1
07/21/2014 11:00	-0.4	12.9	1,922.3	-0.1	1.3	1	1	1
07/21/2014 12:00	-0.4	12.8	1,914.5	-0.1	1.3	1	1	1
07/21/2014 13:00	-0.4	12.9	1,906.6	-0.1	1.3	1	1	1
07/21/2014 14:00	-0.5	12.8	1,917.6	-0.2	1.3	1	1	1
07/21/2014 15:00	-0.7	12.5	1,981.1	-0.2	1.4	1	1	1
07/21/2014 16:00	-0.7	12.4	1,981.5	-0.2	1.4	1	1	1
07/21/2014 17:00	-0.4	11.5	2,162.5	0.1	1.5	1	1	1
07/21/2014 18:00	-0.2	11.1	2,236.5	0.1	1.6	1	1	1
07/21/2014 19:00	-0.2	11.1	2,246.6	0.1	1.6	1	1	1
07/21/2014 20:00	-0.2	11.1	2,247.7	0.1	1.6	1	1	1
07/21/2014 21:00	-0.4	11.7	2,144.9	0.1	1.5	1	1	1
07/21/2014 22:00	-0.5	12.4	2,005.2	-0.2	1.4	1	1	1
07/21/2014 23:00	-0.4	12.7	1,936.9	-0.1	1.4	1	1	1
Average/Sum#:	-0.4	12.7	1,892.5	-0.1	1.3	18 #	16 #	17 #
Minimum:	-0.7	11.1	492.7	-0.2	0.3	0	0	0
Maximum:	0.0	17.2	2,247.7	0.1	1.6	1	1	1
%SI	25.0	25.0	25.0	25.0	25.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/22/2014 00:00	-0.2	13.3	1,835.3	-0.1	1.3	1	1	1
07/22/2014 01:00	-0.2	13.2	1,853.4	-0.1	1.3	1	1	1
07/22/2014 02:00	-0.2	13.2	1,846.9	-0.1	1.3	1	1	1
07/22/2014 03:00	-0.2	13.3	1,835.9	-0.1	1.3	1	1	1
07/22/2014 04:00	-0.5	13.0	1,911.9	-0.2	1.3	1	1	1
07/22/2014 05:00	-0.4	13.2	1,868.5	-0.1	1.3	1	1	1
07/22/2014 06:00	-0.4	13.2	1,850.7	-0.1	1.3	1	1	1
07/22/2014 07:00	-0.7	12.8	1,937.5	-0.4	1.4	1	1	1
07/22/2014 08:00	-0.2	13.2	1,853.7	-0.1	1.3	1	1	1
07/22/2014 09:00	-0.2	13.3	1,842.3	-0.1	1.3	1	1	1
07/22/2014 10:00	-0.2	13.2	1,830.9	-0.1	1.3	1	1	1
07/22/2014 11:00	-0.5	12.8	1,913.4	-0.2	1.3	1	1	1
07/22/2014 12:00	-0.8	12.3	2,020.5	-0.4	1.4	1	1	1
07/22/2014 13:00	-0.7	12.5	1,975.0	-0.2	1.4	1	1	1
07/22/2014 14:00	-0.7	12.3	2,005.2	-0.2	1.4	1	1	1
07/22/2014 15:00	-0.4	11.6	2,139.3	0.1	1.5	1	1	1
07/22/2014 16:00	-0.4	11.9	2,069.2	-0.1	1.4	1	1	1
07/22/2014 17:00	-0.5	12.1	2,024.1	-0.1	1.4	1	1	1
07/22/2014 18:00	-0.4	11.7	2,133.0	0.1	1.5	1	1	1
07/22/2014 19:00	-0.4	12.1	2,085.5	-0.1	1.5	1	1	1
07/22/2014 20:00	-0.4	12.2	2,066.6	-0.1	1.4	1	1	1
07/22/2014 21:00	-0.4	12.2	2,066.4	-0.1	1.4	1	1	1
07/22/2014 22:00	-0.2	12.7	1,967.9	0.1	1.4	1	1	1
07/22/2014 23:00	0.2	13.6	1,541.9	0.4	1.1	1	1	1
Average/Sum#:	-0.4	12.7	1,936.5	-0.1	1.4	24 #	24 #	24 #
Minimum:	-0.8	11.6	1,541.9	-0.4	1.1	1	1	1
Maximum:	0.2	13.6	2,139.3	0.4	1.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/23/2014 00:00	0.4	13.8	1,282.3	0.4	0.9	1	1	0
07/23/2014 01:00	0.4	13.8	1,265.8	0.4	0.9	1	1	0
07/23/2014 02:00	0.4	13.8	1,248.3	0.4	0.9	1	1	0
07/23/2014 03:00	0.4	13.8	1,247.8	0.4	0.9	1	1	0
07/23/2014 04:00	0.4	13.8	1,269.3	0.4	0.9	1	1	0
07/23/2014 05:00	-0.1	13.6	1,554.2	0.1	1.1	1	1	1
07/23/2014 06:00	-0.4	13.1	1,915.8	-0.1	1.3	1	1	1
07/23/2014 07:00	-0.2	13.1	1,913.5	-0.1	1.3	1	1	1
07/23/2014 08:00	-0.2	13.2	1,886.6	-0.1	1.3	1	1	1
07/23/2014 09:00	-0.4	13.2	1,881.0	-0.1	1.3	1	1	1
07/23/2014 10:00	-0.4	13.2	1,856.1	-0.1	1.3	1	1	1
07/23/2014 11:00	-0.2	13.2	1,858.8	-0.1	1.3	1	1	1
07/23/2014 12:00	-0.2	13.2	1,860.3	-0.1	1.3	1	1	1
07/23/2014 13:00	-0.2	13.3	1,852.7	-0.1	1.3	1	1	1
07/23/2014 14:00	-0.4	13.0	1,894.5	-0.1	1.3	1	1	1
07/23/2014 15:00	-0.7	12.5	2,002.7	-0.2	1.4	1	1	1
07/23/2014 16:00	-0.5	12.0	2,077.5	-0.1	1.5	1	1	1
07/23/2014 17:00	-0.5	12.6	1,964.5	-0.2	1.4	1	1	1
07/23/2014 18:00	-0.7	12.4	2,013.6	-0.2	1.4	1	1	1
07/23/2014 19:00	-0.7	12.4	1,987.9	-0.2	1.4	1	1	1
07/23/2014 20:00	-0.5	12.7	1,946.6	-0.2	1.4	1	1	1
07/23/2014 21:00	-0.4	12.8	1,917.0	-0.1	1.3	1	1	1
07/23/2014 22:00	-0.4	13.2	1,859.7	-0.1	1.3	1	1	1
07/23/2014 23:00	-0.5	13.0	1,901.3	-0.2	1.3	1	1	1
Average/Sum#:	-0.2	13.1	1,769.1	0.0	1.2	24 #	24 #	19 #
Minimum:	-0.7	12.0	1,247.8	-0.2	0.9	1	1	0
Maximum:	0.4	13.8	2,077.5	0.4	1.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/24/2014 00:00	-0.2	13.2	1,866.4	-0.1	1.3	1	1	1
07/24/2014 01:00	-0.4	13.2	1,872.6	-0.1	1.3	1	1	1
07/24/2014 02:00	0.1	13.7	1,488.0	0.2	1.0	1	1	1
07/24/2014 03:00	0.4	13.9	1,251.5	0.4	0.9	1	1	0
07/24/2014 04:00	0.4	13.9	1,247.4	0.4	0.9	1	1	0
07/24/2014 05:00	0.4	13.9	1,251.7	0.4	0.9	1	1	0
07/24/2014 06:00	0.4	13.9	1,254.5	0.4	0.9	1	1	0
07/24/2014 07:00	0.4	13.9	1,258.9	0.4	0.9	1	1	0
07/24/2014 08:00	0.2	13.7	1,579.2	0.4	1.1	1	1	1
07/24/2014 09:00	-0.2	13.1	1,902.1	-0.1	1.3	1	1	1
07/24/2014 10:00	-0.4	13.0	1,914.0	-0.1	1.3	1	1	1
07/24/2014 11:00	-0.4	12.8	1,940.0	-0.1	1.4	1	1	1
07/24/2014 12:00	-0.5	12.1	2,074.6	-0.1	1.5	1	1	1
07/24/2014 13:00	-0.1	11.2	2,244.0	0.2	1.6	1	1	1
07/24/2014 14:00	-0.2	11.4	2,198.1	0.1	1.5	1	1	1
07/24/2014 15:00	-0.4	12.0	2,075.4	-0.1	1.5	1	1	1
07/24/2014 16:00	-0.4	12.0	2,080.2	-0.1	1.5	1	1	1
07/24/2014 17:00	-0.5	12.0	2,080.7	-0.1	1.5	1	1	1
07/24/2014 18:00	-0.5	12.0	2,073.9	-0.1	1.5	1	1	1
07/24/2014 19:00	-0.5	12.2	2,055.5	-0.1	1.4	1	1	1
07/24/2014 20:00	-0.5	12.3	2,021.4	-0.1	1.4	1	1	1
07/24/2014 21:00	0.1	13.4	1,684.7	0.2	1.2	1	1	1
07/24/2014 22:00	-0.2	13.1	1,878.5	-0.1	1.3	1	1	1
07/24/2014 23:00	-0.8	12.4	2,023.1	-0.4	1.4	1	1	1
Average/Sum#:	-0.2	12.8	1,804.9	0.1	1.3	24 #	24 #	19 #
Minimum:	-0.8	11.2	1,247.4	-0.4	0.9	1	1	0
Maximum:	0.4	13.9	2,244.0	0.4	1.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/25/2014 00:00	-0.7	13.1	1,881.4	-0.4	1.3	1	1	1
07/25/2014 01:00	-0.2	13.4	1,841.8	-0.1	1.3	1	1	1
07/25/2014 02:00	-0.2	13.4	1,839.3	-0.1	1.3	1	1	1
07/25/2014 03:00	-0.2	13.4	1,837.3	-0.1	1.3	1	1	1
07/25/2014 04:00	-0.4	13.2	1,880.8	-0.1	1.3	1	1	1
07/25/2014 05:00	-0.4	13.1	1,899.0	-0.1	1.3	1	1	1
07/25/2014 06:00	-0.4	13.1	1,900.3	-0.1	1.3	1	1	1
07/25/2014 07:00	-0.7	13.0	1,904.0	-0.4	1.3	1	1	1
07/25/2014 08:00	-0.5	13.2	1,865.3	-0.2	1.3	1	1	1
07/25/2014 09:00	-0.5	12.9	1,902.5	-0.2	1.3	1	1	1
07/25/2014 10:00	-0.7	12.2	2,045.8	-0.2	1.4	1	1	1
07/25/2014 11:00	-0.5	11.7	2,138.1	-0.1	1.5	1	1	1
07/25/2014 12:00	-0.5	11.9	2,098.0	-0.1	1.5	1	1	1
07/25/2014 13:00	-0.5	12.3	1,988.1	-0.1	1.4	1	1	1
07/25/2014 14:00	-0.7	12.2	2,040.3	-0.2	1.4	1	1	1
07/25/2014 15:00	-0.5	11.7	2,123.8	-0.1	1.5	1	1	1
07/25/2014 16:00	-0.5	11.8	2,100.4	-0.1	1.5	1	1	1
07/25/2014 17:00	-0.4	11.6	2,148.2	0.1	1.5	1	1	1
07/25/2014 18:00	-0.4	11.7	2,147.9	0.1	1.5	1	1	1
07/25/2014 19:00	-0.4	11.4	2,185.8	0.1	1.5	1	1	1
07/25/2014 20:00	-0.5	11.9	2,083.7	-0.1	1.5	1	1	1
07/25/2014 21:00	-0.7	12.3	2,013.1	-0.2	1.4	1	1	1
07/25/2014 22:00	-0.7	12.4	2,000.4	-0.2	1.4	1	1	1
07/25/2014 23:00	-0.5	12.9	1,903.4	-0.2	1.3	1	1	1
Average/Sum#:	-0.5	12.5	1,990.4	-0.1	1.4	24 #	24 #	24 #
Minimum:	-0.7	11.4	1,837.3	-0.4	1.3	1	1	1
Maximum:	-0.2	13.4	2,185.8	0.1	1.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/26/2014 00:00	-0.5	13.1	1,858.5	-0.2	1.3	1	1	1
07/26/2014 01:00	-0.4	13.3	1,839.3	-0.1	1.3	1	1	1
07/26/2014 02:00	-0.2	13.3	1,838.7	-0.1	1.3	1	1	1
07/26/2014 03:00	-0.2	13.3	1,836.3	-0.1	1.3	1	1	1
07/26/2014 04:00	-0.4	13.2	1,875.8	-0.1	1.3	1	1	1
07/26/2014 05:00	-0.2	13.3	1,834.2	-0.1	1.3	1	1	1
07/26/2014 06:00	-0.2	13.4	1,826.9	-0.1	1.3	1	1	1
07/26/2014 07:00	-0.2	13.2	1,847.5	-0.1	1.3	1	1	1
07/26/2014 08:00	-0.2	13.2	1,845.3	-0.1	1.3	1	1	1
07/26/2014 09:00	-0.2	13.2	1,830.7	-0.1	1.3	1	1	1
07/26/2014 10:00	-0.2	13.1	1,840.0	-0.1	1.3	1	1	1
07/26/2014 11:00	-0.5	12.6	1,965.1	-0.2	1.4	1	1	1
07/26/2014 12:00	-0.5	11.6	2,116.1	-0.1	1.5	1	1	1
07/26/2014 13:00	-0.4	11.6	2,119.2	0.1	1.5	1	1	1
07/26/2014 14:00	-0.5	12.1	2,007.7	-0.1	1.4	1	1	1
07/26/2014 15:00	0.1	13.4	1,655.6	0.2	1.2	1	1	1
07/26/2014 16:00	0.2	13.4	1,622.7	0.4	1.1	1	1	1
07/26/2014 17:00	-0.5	12.7	1,920.1	-0.2	1.3	1	1	1
07/26/2014 18:00	-0.5	13.0	1,818.0	-0.2	1.3	1	1	1
07/26/2014 19:00	0.4	13.9	1,260.1	0.4	0.9	1	1	0
07/26/2014 20:00	0.4	14.0	1,246.4	0.4	0.9	1	1	0
07/26/2014 21:00	0.4	14.0	1,246.0	0.4	0.9	1	1	0
07/26/2014 22:00	0.4	13.9	1,244.5	0.4	0.9	1	1	0
07/26/2014 23:00	0.3	13.9	1,405.3	0.4	1.0	1	1	0
Average/Sum#:	-0.2	13.2	1,745.8	0.0	1.2	24 #	24 #	19 #
Minimum:	-0.5	11.6	1,244.5	-0.2	0.9	1	1	0
Maximum:	0.4	14.0	2,119.2	0.4	1.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/27/2014 00:00	0.3	13.8	1,502.1	0.4	1.1	1	1	0
07/27/2014 01:00	0.2	13.9	1,352.2	0.3	0.9	1	1	0
07/27/2014 02:00	0.3	13.8	1,377.5	0.4	1.0	1	1	0
07/27/2014 03:00	0.3	13.9	1,272.9	0.4	0.9	1	1	0
07/27/2014 04:00	0.3	13.9	1,329.6	0.4	0.9	1	1	0
07/27/2014 05:00	0.3	13.9	1,283.8	0.4	0.9	1	1	0
07/27/2014 06:00	-0.4	13.6	1,527.8	-0.2	1.1	1	1	1
07/27/2014 07:00	-0.9	13.0	1,879.8	-0.5	1.3	1	1	1
07/27/2014 08:00	-0.5	13.3	1,775.9	-0.2	1.2	1	1	1
07/27/2014 09:00	-0.8	13.1	1,858.4	-0.5	1.3	1	1	1
07/27/2014 10:00	-0.8	12.9	1,882.6	-0.4	1.3	1	1	1
07/27/2014 11:00	-1.1	12.2	2,022.0	-0.5	1.4	1	1	1
07/27/2014 12:00	-0.9	12.5	1,971.8	-0.5	1.4	1	1	1
07/27/2014 13:00	-0.8	12.6	1,950.6	-0.4	1.4	1	1	1
07/27/2014 14:00	-0.5	12.9	1,898.8	-0.2	1.3	1	1	1
07/27/2014 15:00	-0.8	12.1	2,060.5	-0.4	1.4	1	1	1
07/27/2014 16:00	-0.5	11.9	2,087.9	-0.1	1.5	1	1	1
07/27/2014 17:00	-0.7	11.8	2,101.3	-0.2	1.5	1	1	1
07/27/2014 18:00	-0.7	11.8	2,101.0	-0.2	1.5	1	1	1
07/27/2014 19:00	-0.7	12.0	2,053.6	-0.2	1.4	1	1	1
07/27/2014 20:00	-0.5	13.1	1,822.1	-0.2	1.3	1	1	1
07/27/2014 21:00	-0.2	13.3	1,678.7	-0.1	1.2	1	1	1
07/27/2014 22:00	-0.1	13.5	1,659.3	0.1	1.2	1	1	1
07/27/2014 23:00	-0.5	13.1	1,840.2	-0.2	1.3	1	1	1
Average/Sum#:	-0.4	13.0	1,762.1	-0.1	1.2	24 #	24 #	18 #
Minimum:	-1.1	11.8	1,272.9	-0.5	0.9	1	1	0
Maximum:	0.3	13.9	2,101.3	0.4	1.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/28/2014 00:00	-0.5	13.2	1,844.6	-0.2	1.3	1	1	1
07/28/2014 01:00	-0.8	12.9	1,902.1	-0.4	1.3	1	1	1
07/28/2014 02:00	-0.5	13.2	1,743.2	-0.2	1.2	1	1	1
07/28/2014 03:00	0.3	13.8	1,279.2	0.4	0.9	1	1	0
07/28/2014 04:00	-0.4	13.5	1,614.6	-0.2	1.1	1	1	1
07/28/2014 05:00	-0.7	13.3	1,837.7	-0.4	1.3	1	1	1
07/28/2014 06:00	-0.5	13.2	1,861.0	-0.2	1.3	1	1	1
07/28/2014 07:00	-0.4	13.2	1,848.2	-0.1	1.3	1	1	1
07/28/2014 08:00	-0.4	13.1	1,875.2	-0.1	1.3	1	1	1
07/28/2014 09:00	-0.9	12.2	2,049.7	-0.4	1.4	1	1	1
07/28/2014 10:00	-0.7	12.1	2,066.8	-0.2	1.4	1	1	1
07/28/2014 11:00	-0.7	11.6	2,153.9	-0.2	1.5	1	1	1
07/28/2014 12:00	-0.5	11.8	2,089.9	-0.1	1.5	1	1	1
07/28/2014 13:00	-0.5	11.7	2,108.6	-0.1	1.5	1	1	1
07/28/2014 14:00	-0.5	11.8	2,079.2	-0.1	1.5	1	1	1
07/28/2014 15:00	-0.5	11.8	2,077.9	-0.1	1.5	1	1	1
07/28/2014 16:00	-0.5	11.8	2,066.0	-0.1	1.4	1	1	1
07/28/2014 17:00	-0.5	11.9	2,071.1	-0.1	1.4	1	1	1
07/28/2014 18:00	-0.5	12.6	1,938.0	-0.2	1.4	1	1	1
07/28/2014 19:00	-0.7	12.5	1,960.9	-0.2	1.4	1	1	1
07/28/2014 20:00	-0.5	12.6	1,931.0	-0.2	1.4	1	1	1
07/28/2014 21:00	-0.5	13.0	1,878.5	-0.2	1.3	1	1	1
07/28/2014 22:00	-0.5	12.8	1,911.1	-0.2	1.3	1	1	1
07/28/2014 23:00	-0.2	13.2	1,834.3	-0.1	1.3	1	1	1
Average/Sum#:	-0.5	12.6	1,917.6	-0.2	1.3	24 #	24 #	23 #
Minimum:	-0.9	11.6	1,279.2	-0.4	0.9	1	1	0
Maximum:	0.3	13.8	2,153.9	0.4	1.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/29/2014 00:00	-0.7	12.8	1,923.0	-0.4	1.3	1	1	1
07/29/2014 01:00	0.4	13.8	1,447.1	0.4	1.0	1	1	1
07/29/2014 02:00	0.4	13.9	1,253.0	0.4	0.9	1	1	0
07/29/2014 03:00	0.4	13.9	1,229.9	0.4	0.9	1	1	0
07/29/2014 04:00	0.2	13.8	1,368.4	0.4	1.0	1	1	1
07/29/2014 05:00	-0.4	13.4	1,832.2	-0.2	1.3	1	1	1
07/29/2014 06:00	-0.7	13.0	1,916.5	-0.4	1.3	1	1	1
07/29/2014 07:00	-0.8	12.2	2,073.6	-0.4	1.5	1	1	1
07/29/2014 08:00	-0.8	12.4	2,027.1	-0.4	1.4	1	1	1
07/29/2014 09:00	-0.7	12.6	1,966.1	-0.2	1.4	1	1	1
07/29/2014 10:00	-0.7	11.8	2,147.5	-0.2	1.5	1	1	1
07/29/2014 11:00	-0.5	12.4	1,999.2	-0.2	1.4	1	1	1
07/29/2014 12:00	-0.5	11.9	2,115.6	-0.1	1.5	1	1	1
07/29/2014 13:00	-0.2	11.4	2,199.2	0.1	1.5	1	1	1
07/29/2014 14:00	-0.2	11.4	2,185.5	0.1	1.5	1	1	1
07/29/2014 15:00	-0.2	11.5	2,144.5	0.1	1.5	1	1	1
07/29/2014 16:00	-0.4	11.9	2,034.2	-0.1	1.4	1	1	1
07/29/2014 17:00	-0.5	12.3	1,979.9	-0.1	1.4	1	1	1
07/29/2014 18:00	-0.7	12.3	1,976.1	-0.2	1.4	1	1	1
07/29/2014 19:00	-0.4	12.7	1,898.4	-0.1	1.3	1	1	1
07/29/2014 20:00	-0.7	13.1	1,840.4	-0.4	1.3	1	1	1
07/29/2014 21:00	-0.5	12.9	1,890.3	-0.2	1.3	1	1	1
07/29/2014 22:00	-0.1	13.1	1,837.2	0.1	1.3	1	1	1
07/29/2014 23:00	-0.4	13.2	1,825.7	-0.1	1.3	1	1	1
Average/Sum#:	-0.4	12.7	1,879.6	-0.1	1.3	24 #	24 #	22 #
Minimum:	-0.8	11.4	1,229.9	-0.4	0.9	1	1	0
Maximum:	0.4	13.9	2,199.2	0.4	1.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/30/2014 00:00	-0.9	13.3	1,817.0	-0.7	1.3	1	1	1
07/30/2014 01:00	-1.1	13.1	1,856.2	-0.7	1.3	1	1	1
07/30/2014 02:00	0.1	13.8	1,404.4	0.2	1.0	1	1	1
07/30/2014 03:00	-0.4	13.6	1,533.3	-0.2	1.1	1	1	1
07/30/2014 04:00	-0.4	13.3	1,840.3	-0.1	1.3	1	1	1
07/30/2014 05:00	-0.4	13.3	1,845.1	-0.1	1.3	1	1	1
07/30/2014 06:00	-0.4	13.2	1,842.9	-0.1	1.3	1	1	1
07/30/2014 07:00	-0.4	13.2	1,841.3	-0.1	1.3	1	1	1
07/30/2014 08:00	-0.4	13.2	1,842.6	-0.1	1.3	1	1	1
07/30/2014 09:00	-0.2	13.1	1,849.8	-0.1	1.3	1	1	1
07/30/2014 10:00	-0.2	13.1	1,848.0	-0.1	1.3	1	1	1
07/30/2014 11:00	-0.7	12.5	1,982.2	-0.2	1.4	1	1	1
07/30/2014 12:00	-0.4	11.4	2,182.4	0.1	1.5	1	1	1
07/30/2014 13:00	-0.2	11.3	2,197.8	0.1	1.5	1	1	1
07/30/2014 14:00	-0.2	11.3	2,166.6	0.1	1.5	1	1	1
07/30/2014 15:00	-0.4	11.4	2,138.9	0.1	1.5	1	1	1
07/30/2014 16:00	-0.4	11.4	2,138.6	0.1	1.5	1	1	1
07/30/2014 17:00	-0.4	11.4	2,139.9	0.1	1.5	1	1	1
07/30/2014 18:00	-0.4	11.5	2,139.0	0.1	1.5	1	1	1
07/30/2014 19:00	-0.5	11.7	2,094.0	-0.1	1.5	1	1	1
07/30/2014 20:00	-0.8	12.3	1,989.1	-0.4	1.4	1	1	1
07/30/2014 21:00	-0.7	11.6	2,127.5	-0.2	1.5	1	1	1
07/30/2014 22:00	-0.7	11.9	2,077.9	-0.2	1.5	1	1	1
07/30/2014 23:00	-0.8	12.2	2,028.8	-0.4	1.4	1	1	1
Average/Sum#:	-0.5	12.4	1,955.2	-0.1	1.4	24 #	24 #	24 #
Minimum:	-1.1	11.3	1,404.4	-0.7	1.0	1	1	1
Maximum:	0.1	13.8	2,197.8	0.2	1.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/31/2014 00:00	-0.1	13.4	1,696.9	0.1	1.2	1	1	1
07/31/2014 01:00	0.4	13.7	1,710.9	0.4	1.2	1	1	0
07/31/2014 02:00	-0.2	13.3	1,766.0	-0.1	1.2	1	1	1
07/31/2014 03:00	-0.5	13.0	1,877.3	-0.2	1.3	1	1	1
07/31/2014 04:00	-0.4	13.2	1,847.8	-0.1	1.3	1	1	1
07/31/2014 05:00	-0.5	13.2	1,843.4	-0.2	1.3	1	1	1
07/31/2014 06:00	-0.4	13.2	1,841.9	-0.1	1.3	1	1	1
07/31/2014 07:00	-0.4	13.2	1,844.5	-0.1	1.3	1	1	1
07/31/2014 08:00	-0.4	13.1	1,848.1	-0.1	1.3	1	1	1
07/31/2014 09:00	-0.8	12.7	1,924.6	-0.4	1.3	1	1	1
07/31/2014 10:00	-0.8	11.4	2,173.3	-0.2	1.5	1	1	1
07/31/2014 11:00	-0.5	11.2	2,198.8	-0.1	1.5	1	1	1
07/31/2014 12:00	-0.5	11.3	2,162.8	-0.1	1.5	1	1	1
07/31/2014 13:00	0.4	13.4	1,709.8	0.4	1.2	1	1	1
07/31/2014 14:00	-0.7	12.6	1,907.6	-0.2	1.3	1	1	1
07/31/2014 15:00	-0.8	12.2	1,983.5	-0.4	1.4	1	1	1
07/31/2014 16:00	-0.9	12.1	1,990.1	-0.4	1.4	1	1	1
07/31/2014 17:00	-0.9	12.0	1,996.9	-0.4	1.4	1	1	1
07/31/2014 18:00	-0.9	12.1	1,988.2	-0.4	1.4	1	1	1
07/31/2014 19:00	-1.1	12.2	1,975.8	-0.5	1.4	1	1	1
07/31/2014 20:00	-0.9	12.2	1,968.1	-0.4	1.4	1	1	1
07/31/2014 21:00	-0.9	12.4	1,954.5	-0.5	1.4	1	1	1
07/31/2014 22:00	-0.7	12.8	1,881.2	-0.4	1.3	1	1	1
07/31/2014 23:00	-0.7	12.8	1,880.0	-0.4	1.3	1	1	1
Average/Sum#:	-0.6	12.6	1,915.5	-0.2	1.3	24 #	24 #	23 #
Minimum:	-1.1	11.2	1,696.9	-0.5	1.2	1	1	0
Maximum:	0.4	13.7	2,198.8	0.4	1.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/01/2014 00:00	-0.7	12.9	1,882.6	-0.4	1.3	1	1	1
08/01/2014 01:00	0.1	13.6	1,580.9	0.2	1.1	1	1	1
08/01/2014 02:00	-0.1	13.6	1,595.6	0.1	1.1	1	1	1
08/01/2014 03:00	-0.7	13.0	1,886.0	-0.4	1.3	1	1	1
08/01/2014 04:00	-0.5	13.2	1,855.3	-0.2	1.3	1	1	1
08/01/2014 05:00	-0.7	13.0	1,899.0	-0.4	1.3	1	1	1
08/01/2014 06:00	-0.4	13.3	1,839.5	-0.1	1.3	1	1	1
08/01/2014 07:00	-0.4	13.2	1,837.6	-0.1	1.3	1	1	1
08/01/2014 08:00	-0.8	12.9	1,897.0	-0.4	1.3	1	1	1
08/01/2014 09:00	-1.2	12.3	2,008.9	-0.7	1.4	1	1	1
08/01/2014 10:00	-1.1	11.6	2,117.8	-0.5	1.5	1	1	1
08/01/2014 11:00	-0.8	11.3	2,189.8	-0.2	1.5	1	1	1
08/01/2014 12:00	-0.9	11.4	2,152.1	-0.4	1.5	1	1	1
08/01/2014 13:00	-0.8	11.4	2,138.7	-0.2	1.5	1	1	1
08/01/2014 14:00	-0.8	11.4	2,132.4	-0.2	1.5	1	1	1
08/01/2014 15:00	-0.9	11.5	2,092.1	-0.4	1.5	1	1	1
08/01/2014 16:00	-0.9	11.9	2,032.0	-0.4	1.4	1	1	1
08/01/2014 17:00	-0.9	12.1	1,997.9	-0.4	1.4	1	1	1
08/01/2014 18:00	-1.1	12.2	1,991.2	-0.5	1.4	1	1	1
08/01/2014 19:00	-1.1	12.3	1,990.8	-0.5	1.4	1	1	1
08/01/2014 20:00	-0.9	12.7	1,929.1	-0.5	1.4	1	1	1
08/01/2014 21:00	-0.8	12.9	1,900.9	-0.4	1.3	1	1	1
08/01/2014 22:00	-0.7	12.9	1,888.8	-0.4	1.3	1	1	1
08/01/2014 23:00	-0.9	12.7	1,926.6	-0.5	1.3	1	1	1
Average/Sum#:	-0.8	12.5	1,948.4	-0.3	1.4	24 #	24 #	24 #
Minimum:	-1.2	11.3	1,580.9	-0.7	1.1	1	1	1
Maximum:	0.1	13.6	2,189.8	0.2	1.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/02/2014 00:00	-0.8	13.0	1,872.6	-0.4	1.3	1	1	1
08/02/2014 01:00	-0.5	13.2	1,847.7	-0.2	1.3	1	1	1
08/02/2014 02:00	-0.5	13.2	1,825.1	-0.2	1.3	1	1	1
08/02/2014 03:00	0.3	13.9	1,304.0	0.4	0.9	1	1	0
08/02/2014 04:00	0.4	13.8	1,477.1	0.4	1.0	1	1	0
08/02/2014 05:00	0.4	13.9	1,262.5	0.4	0.9	1	1	0
08/02/2014 06:00	0.4	13.8	1,238.2	0.4	0.9	1	1	0
08/02/2014 07:00	-0.5	13.6	1,515.0	-0.2	1.1	1	1	1
08/02/2014 08:00	-1.2	13.2	1,849.6	-0.8	1.3	1	1	1
08/02/2014 09:00	-0.7	13.3	1,821.1	-0.4	1.3	1	1	1
08/02/2014 10:00	-0.5	13.2	1,832.7	-0.2	1.3	1	1	1
08/02/2014 11:00	-0.8	13.0	1,877.3	-0.4	1.3	1	1	1
08/02/2014 12:00	-1.1	12.8	1,918.0	-0.7	1.3	1	1	1
08/02/2014 13:00	-1.1	12.7	1,915.7	-0.7	1.3	1	1	1
08/02/2014 14:00	-0.8	12.9	1,858.2	-0.4	1.3	1	1	1
08/02/2014 15:00	-0.9	12.8	1,875.9	-0.5	1.3	1	1	1
08/02/2014 16:00	-1.1	12.7	1,887.9	-0.7	1.3	1	1	1
08/02/2014 17:00	-1.2	12.5	1,917.1	-0.7	1.3	1	1	1
08/02/2014 18:00	-1.2	12.6	1,906.0	-0.7	1.3	1	1	1
08/02/2014 19:00	-1.2	12.3	1,980.7	-0.7	1.4	1	1	1
08/02/2014 20:00	-1.2	12.3	1,977.1	-0.7	1.4	1	1	1
08/02/2014 21:00	-0.8	12.7	1,896.7	-0.4	1.3	1	1	1
08/02/2014 22:00	0.1	13.6	1,535.9	0.2	1.1	1	1	1
08/02/2014 23:00	0.4	13.9	1,276.1	0.4	0.9	1	1	0
Average/Sum#:	-0.6	13.1	1,736.2	-0.3	1.2	24 #	24 #	19 #
Minimum:	-1.2	12.3	1,238.2	-0.8	0.9	1	1	0
Maximum:	0.4	13.9	1,980.7	0.4	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/03/2014 00:00	0.4	13.8	1,594.3	0.4	1.1	1	1	0
08/03/2014 01:00	0.4	13.8	1,487.0	0.4	1.0	1	1	0
08/03/2014 02:00	0.4	13.8	1,410.3	0.4	1.0	1	1	0
08/03/2014 03:00	0.4	13.8	1,601.4	0.4	1.1	1	1	0
08/03/2014 04:00	0.2	13.7	1,750.3	0.4	1.2	1	1	1
08/03/2014 05:00	-1.2	13.4	1,821.6	-0.8	1.3	1	1	1
08/03/2014 06:00	-0.4	13.3	1,826.7	-0.1	1.3	1	1	1
08/03/2014 07:00	-0.9	12.8	1,939.5	-0.5	1.4	1	1	1
08/03/2014 08:00	-0.7	13.0	1,894.5	-0.4	1.3	1	1	1
08/03/2014 09:00	-0.7	13.0	1,883.2	-0.4	1.3	1	1	1
08/03/2014 10:00	-0.8	12.9	1,895.8	-0.4	1.3	1	1	1
08/03/2014 11:00	-0.8	12.8	1,903.6	-0.4	1.3	1	1	1
08/03/2014 12:00	-0.8	12.8	1,900.0	-0.4	1.3	1	1	1
08/03/2014 13:00	-1.2	11.9	2,068.1	-0.7	1.4	1	1	1
08/03/2014 14:00	-1.2	12.3	1,978.0	-0.7	1.4	1	1	1
08/03/2014 15:00	-1.2	11.7	2,102.8	-0.5	1.5	1	1	1
08/03/2014 16:00	-0.9	12.4	1,953.9	-0.5	1.4	1	1	1
08/03/2014 17:00	-1.1	12.5	1,941.1	-0.5	1.4	1	1	1
08/03/2014 18:00	-0.7	12.9	1,872.3	-0.4	1.3	1	1	1
08/03/2014 19:00	-1.1	12.6	1,945.1	-0.7	1.4	1	1	1
08/03/2014 20:00	-1.1	12.6	1,952.5	-0.7	1.4	1	1	1
08/03/2014 21:00	-0.5	13.0	1,864.0	-0.2	1.3	1	1	1
08/03/2014 22:00	-0.5	13.0	1,857.4	-0.2	1.3	1	1	1
08/03/2014 23:00	-0.8	12.8	1,935.0	-0.4	1.4	1	1	1
Average/Sum#:	-0.6	12.9	1,849.1	-0.3	1.3	24 #	24 #	20 #
Minimum:	-1.2	11.7	1,410.3	-0.8	1.0	1	1	0
Maximum:	0.4	13.8	2,102.8	0.4	1.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/04/2014 00:00	-0.7	13.1	1,876.1	-0.4	1.3	1	1	1
08/04/2014 01:00	-0.8	13.0	1,902.5	-0.4	1.3	1	1	1
08/04/2014 02:00	-0.5	13.2	1,866.0	-0.2	1.3	1	1	1
08/04/2014 03:00	-0.8	12.9	1,917.3	-0.4	1.3	1	1	1
08/04/2014 04:00	-0.5	13.3	1,842.2	-0.2	1.3	1	1	1
08/04/2014 05:00	-0.5	13.2	1,823.2	-0.2	1.3	1	1	1
08/04/2014 06:00	0.4	13.7	1,705.6	0.4	1.2	1	1	0
08/04/2014 07:00	0.4	13.7	1,676.5	0.4	1.2	1	1	0
08/04/2014 08:00	0.4	13.6	1,758.9	0.4	1.2	1	1	0
08/04/2014 09:00	0.4	13.6	1,756.8	0.4	1.2	1	1	0
08/04/2014 10:00	-0.5	13.2	1,801.5	-0.2	1.3	1	1	1
08/04/2014 11:00	-0.8	12.9	1,902.7	-0.4	1.3	1	1	1
08/04/2014 12:00	-0.4	13.2	1,837.9	-0.1	1.3	1	1	1
08/04/2014 13:00	-0.5	13.1	1,842.0	-0.2	1.3	1	1	1
08/04/2014 14:00	-0.5	13.1	1,846.3	-0.2	1.3	1	1	1
08/04/2014 15:00	-0.5	13.0	1,852.9	-0.2	1.3	1	1	1
08/04/2014 16:00	-0.4	13.1	1,839.8	-0.1	1.3	1	1	1
08/04/2014 17:00	-0.5	13.1	1,843.3	-0.2	1.3	1	1	1
08/04/2014 18:00	-0.5	13.1	1,839.7	-0.2	1.3	1	1	1
08/04/2014 19:00	-0.5	13.2	1,836.8	-0.2	1.3	1	1	1
08/04/2014 20:00	-0.5	13.2	1,836.6	-0.2	1.3	1	1	1
08/04/2014 21:00	-0.4	13.3	1,583.2	-0.1	1.1	1	1	1
08/04/2014 22:00	0.3	13.8	1,280.5	0.4	0.9	1	1	0
08/04/2014 23:00	0.3	13.7	1,613.8	0.4	1.1	1	1	0
Average/Sum#:	-0.3	13.3	1,786.8	-0.1	1.3	24 #	24 #	18 #
Minimum:	-0.8	12.9	1,280.5	-0.4	0.9	1	1	0
Maximum:	0.4	13.8	1,917.3	0.4	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/05/2014 00:00	-0.2	13.4	1,770.6	-0.1	1.2	1	1	1
08/05/2014 01:00	-0.8	12.9	1,895.1	-0.4	1.3	1	1	1
08/05/2014 02:00	-0.9	12.7	1,928.9	-0.5	1.4	1	1	1
08/05/2014 03:00	-0.8	12.9	1,905.5	-0.4	1.3	1	1	1
08/05/2014 04:00	-0.8	12.9	1,910.8	-0.4	1.3	1	1	1
08/05/2014 05:00	-0.5	13.2	1,840.4	-0.2	1.3	1	1	1
08/05/2014 06:00	-0.5	13.1	1,874.7	-0.2	1.3	1	1	1
08/05/2014 07:00	0.1	13.8	1,295.7	0.2	0.9	1	1	1
08/05/2014 08:00	0.4	13.8	1,250.1	0.4	0.9	1	1	0
08/05/2014 09:00	-0.2	13.3	1,571.2	-0.1	1.1	1	1	1
08/05/2014 10:00	-0.4	13.2	1,845.2	-0.1	1.3	1	1	1
08/05/2014 11:00	-0.2	13.2	1,853.8	-0.1	1.3	1	1	1
08/05/2014 12:00	-0.5	13.0	1,891.0	-0.2	1.3	1	1	1
08/05/2014 13:00	-0.7	12.8	1,920.8	-0.4	1.3	1	1	1
08/05/2014 14:00	-0.7	12.7	1,928.8	-0.2	1.4	1	1	1
08/05/2014 15:00	-0.8	12.6	1,965.0	-0.4	1.4	1	1	1
08/05/2014 16:00	-0.7	12.8	1,922.0	-0.4	1.3	1	1	1
08/05/2014 17:00	-0.8	12.7	1,930.2	-0.4	1.4	1	1	1
08/05/2014 18:00	-0.9	12.7	1,940.8	-0.5	1.4	1	1	1
08/05/2014 19:00	-0.8	12.6	1,953.7	-0.4	1.4	1	1	1
08/05/2014 20:00	-0.5	12.9	1,894.6	-0.2	1.3	1	1	1
08/05/2014 21:00	-0.5	12.8	1,905.6	-0.2	1.3	1	1	1
08/05/2014 22:00	0.1	13.4	1,474.3	0.2	1.0	1	1	1
08/05/2014 23:00	0.1	13.5	1,529.9	0.2	1.1	1	1	1
Average/Sum#:	-0.5	13.0	1,799.9	-0.2	1.3	24 #	24 #	23 #
Minimum:	-0.9	12.6	1,250.1	-0.5	0.9	1	1	0
Maximum:	0.4	13.8	1,965.0	0.4	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/06/2014 00:00	-0.9	12.7	1,939.1	-0.5	1.4	1	1	1
08/06/2014 01:00	-0.9	12.6	1,957.6	-0.5	1.4	1	1	1
08/06/2014 02:00	-0.7	12.9	1,897.7	-0.4	1.3	1	1	1
08/06/2014 03:00	-0.2	13.2	1,847.4	-0.1	1.3	1	1	1
08/06/2014 04:00	-0.9	12.6	1,966.1	-0.5	1.4	1	1	1
08/06/2014 05:00	-1.1	12.4	2,002.7	-0.5	1.4	1	1	1
08/06/2014 06:00	-0.8	12.7	1,933.5	-0.4	1.4	1	1	1
08/06/2014 07:00	-0.8	12.9	1,909.7	-0.4	1.3	1	1	1
08/06/2014 08:00	-0.9	12.6	1,955.9	-0.5	1.4	1	1	1
08/06/2014 09:00	-0.9	12.3	2,003.0	-0.5	1.4	1	1	1
08/06/2014 10:00	-0.9	12.1	2,016.5	-0.4	1.4	1	1	1
08/06/2014 11:00	-0.9	12.1	2,033.1	-0.4	1.4	1	1	1
08/06/2014 12:00	-0.9	12.3	1,999.7	-0.5	1.4	1	1	1
08/06/2014 13:00	-0.9	12.3	1,990.4	-0.5	1.4	1	1	1
08/06/2014 14:00	-0.9	12.0	2,050.3	-0.4	1.4	1	1	1
08/06/2014 15:00	-0.9	12.3	1,977.6	-0.5	1.4	1	1	1
08/06/2014 16:00	-0.5	12.9	1,857.3	-0.2	1.3	1	1	1
08/06/2014 17:00	-0.9	12.5	1,934.1	-0.5	1.4	1	1	1
08/06/2014 18:00	-1.1	12.4	1,947.8	-0.5	1.4	1	1	1
08/06/2014 19:00	-1.1	12.3	1,987.3	-0.5	1.4	1	1	1
08/06/2014 20:00	-0.9	12.3	1,982.5	-0.5	1.4	1	1	1
08/06/2014 21:00	-0.7	12.6	1,908.0	-0.2	1.3	1	1	1
08/06/2014 22:00	-0.1	13.4	1,449.7	0.1	1.0	1	1	1
08/06/2014 23:00	0.0	16.4	352.1	0.0	0.2	1	0	0
Average/Sum#:	-0.8	12.7	1,870.8	-0.4	1.3	24 #	23 #	23 #
Minimum:	-1.1	12.0	352.1	-0.5	0.2	1	0	0
Maximum:	0.0	16.4	2,050.3	0.1	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/07/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 13:00	0.0	17.8	356.8	0.0	0.2	1	0	0
08/07/2014 14:00	0.0	16.4	617.1	0.0	0.4	1	0	0
08/07/2014 15:00	0.0	13.1	1,686.6	0.0	1.2	1	0	1
08/07/2014 16:00	-0.8	12.1	1,982.6	-0.4	1.4	1	1	1
08/07/2014 17:00	-0.7	11.7	2,066.4	-0.2	1.4	1	1	1
08/07/2014 18:00	-0.7	11.8	1,997.5	-0.2	1.4	1	1	1
08/07/2014 19:00	-0.8	12.3	1,951.6	-0.4	1.4	1	1	1
08/07/2014 20:00	-0.4	13.0	1,838.9	-0.1	1.3	1	1	1
08/07/2014 21:00	-0.5	12.9	1,864.6	-0.2	1.3	1	1	1
08/07/2014 22:00	-0.2	13.2	1,813.9	-0.1	1.3	1	1	1
08/07/2014 23:00	-0.4	13.3	1,807.8	-0.1	1.3	1	1	1
Average/Sum#:	-0.4	13.4	1,634.9	-0.2	1.1	11 #	8 #	9 #
Minimum:	-0.8	11.7	356.8	-0.4	0.2	0	0	0
Maximum:	0.0	17.8	2,066.4	0.0	1.4	1	1	1
%SI	54.2	54.2	54.2	54.2	54.2	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/08/2014 00:00	-0.7	12.8	1,908.2	-0.4	1.3	1	1	1
08/08/2014 01:00	-0.5	12.9	1,893.2	-0.2	1.3	1	1	1
08/08/2014 02:00	-0.1	13.3	1,816.6	0.1	1.3	1	1	1
08/08/2014 03:00	-0.4	13.1	1,865.7	-0.1	1.3	1	1	1
08/08/2014 04:00	-0.5	13.0	1,898.1	-0.2	1.3	1	1	1
08/08/2014 05:00	-0.8	12.7	1,945.7	-0.4	1.4	1	1	1
08/08/2014 06:00	-0.7	12.7	1,946.5	-0.2	1.4	1	1	1
08/08/2014 07:00	-0.5	12.9	1,910.0	-0.2	1.3	1	1	1
08/08/2014 08:00	-0.4	13.0	1,875.9	-0.1	1.3	1	1	1
08/08/2014 09:00	-0.7	11.7	2,132.5	-0.2	1.5	1	1	1
08/08/2014 10:00	-0.7	12.1	2,030.3	-0.2	1.4	1	1	1
08/08/2014 11:00	-0.4	13.0	1,842.8	-0.1	1.3	1	1	1
08/08/2014 12:00	-0.5	12.9	1,878.4	-0.2	1.3	1	1	1
08/08/2014 13:00	-0.8	12.3	1,990.7	-0.4	1.4	1	1	1
08/08/2014 14:00	-0.7	11.7	2,106.2	-0.2	1.5	1	1	1
08/08/2014 15:00	-0.5	11.6	2,100.8	-0.1	1.5	1	1	1
08/08/2014 16:00	-0.7	11.6	2,083.1	-0.2	1.5	1	1	1
08/08/2014 17:00	-0.8	12.1	2,011.2	-0.4	1.4	1	1	1
08/08/2014 18:00	-0.5	11.5	2,135.6	-0.1	1.5	1	1	1
08/08/2014 19:00	-0.7	11.8	2,058.0	-0.2	1.4	1	1	1
08/08/2014 20:00	-0.8	12.4	1,971.0	-0.4	1.4	1	1	1
08/08/2014 21:00	-0.8	12.4	1,955.4	-0.4	1.4	1	1	1
08/08/2014 22:00	-0.5	12.9	1,872.9	-0.2	1.3	1	1	1
08/08/2014 23:00	-0.9	12.5	1,948.2	-0.5	1.4	1	1	1
Average/Sum#:	-0.6	12.5	1,965.7	-0.2	1.4	24 #	24 #	24 #
Minimum:	-0.9	11.5	1,816.6	-0.5	1.3	1	1	1
Maximum:	-0.1	13.3	2,135.6	0.1	1.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/09/2014 00:00	0.2	13.6	1,698.3	0.4	1.2	1	1	1
08/09/2014 01:00	0.4	13.7	1,544.6	0.4	1.1	1	1	0
08/09/2014 02:00	0.0	15.7	571.0	0.0	0.4	1	0	0
08/09/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/09/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/09/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/09/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/09/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/09/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/09/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/09/2014 10:00	0.0	16.7	556.0	0.0	0.4	1	0	0
08/09/2014 11:00	0.0	14.0	1,405.4	0.0	1.0	1	0	0
08/09/2014 12:00	0.1	13.7	1,467.0	0.2	1.0	1	1	1
08/09/2014 13:00	-0.5	13.0	1,843.8	-0.2	1.3	1	1	1
08/09/2014 14:00	-0.5	13.0	1,867.8	-0.2	1.3	1	1	1
08/09/2014 15:00	-0.9	12.6	1,915.0	-0.5	1.3	1	1	1
08/09/2014 16:00	-0.8	12.7	1,901.3	-0.4	1.3	1	1	1
08/09/2014 17:00	-0.7	12.8	1,899.9	-0.4	1.3	1	1	1
08/09/2014 18:00	-0.9	12.2	2,014.3	-0.4	1.4	1	1	1
08/09/2014 19:00	-0.5	11.4	2,172.3	-0.1	1.5	1	1	1
08/09/2014 20:00	-0.7	11.8	2,098.2	-0.2	1.5	1	1	1
08/09/2014 21:00	-0.7	12.0	2,071.3	-0.2	1.4	1	1	1
08/09/2014 22:00	-0.7	12.5	1,982.5	-0.2	1.4	1	1	1
08/09/2014 23:00	-0.1	13.4	1,683.2	0.1	1.2	1	1	1
Average/Sum#:	-0.4	13.2	1,687.8	-0.1	1.2	17 #	14 #	13 #
Minimum:	-0.9	11.4	556.0	-0.5	0.4	0	0	0
Maximum:	0.4	16.7	2,172.3	0.4	1.5	1	1	1
%SI	29.2	29.2	29.2	29.2	29.2	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/10/2014 00:00	0.0	15.7	567.0	0.0	0.4	1	0	0
08/10/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2014 11:00	0.0	17.0	530.2	0.0	0.4	1	0	0
08/10/2014 12:00	0.0	13.9	1,435.1	0.0	1.0	1	0	1
08/10/2014 13:00	-0.8	12.7	1,914.3	-0.4	1.3	1	1	1
08/10/2014 14:00	-0.9	12.6	1,912.1	-0.5	1.3	1	1	1
08/10/2014 15:00	-0.5	12.9	1,875.4	-0.2	1.3	1	1	1
08/10/2014 16:00	-0.9	12.4	1,974.4	-0.5	1.4	1	1	1
08/10/2014 17:00	-0.7	11.4	2,151.8	-0.2	1.5	1	1	1
08/10/2014 18:00	-0.5	11.6	2,138.3	-0.1	1.5	1	1	1
08/10/2014 19:00	-0.5	11.5	2,142.8	-0.1	1.5	1	1	1
08/10/2014 20:00	-0.7	11.7	2,123.3	-0.2	1.5	1	1	1
08/10/2014 21:00	-0.7	11.9	2,069.6	-0.2	1.4	1	1	1
08/10/2014 22:00	-0.7	12.8	1,901.0	-0.4	1.3	1	1	1
08/10/2014 23:00	-0.9	12.6	1,952.3	-0.5	1.4	1	1	1
Average/Sum#:	-0.6	12.9	1,763.4	-0.2	1.2	14 #	11 #	12 #
Minimum:	-0.9	11.4	530.2	-0.5	0.4	0	0	0
Maximum:	0.0	17.0	2,151.8	0.0	1.5	1	1	1
%SI	41.7	41.7	41.7	41.7	41.7	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/11/2014 00:00	-0.9	12.7	1,948.6	-0.5	1.4	1	1	1
08/11/2014 01:00	-0.9	12.7	1,949.9	-0.5	1.4	1	1	1
08/11/2014 02:00	-0.7	12.9	1,911.4	-0.4	1.3	1	1	1
08/11/2014 03:00	-0.9	12.7	1,955.1	-0.5	1.4	1	1	1
08/11/2014 04:00	-0.9	12.7	1,970.2	-0.5	1.4	1	1	1
08/11/2014 05:00	-0.7	12.9	1,923.2	-0.4	1.3	1	1	1
08/11/2014 06:00	-0.7	11.7	2,137.4	-0.2	1.5	1	1	1
08/11/2014 07:00	-0.9	12.6	1,979.0	-0.5	1.4	1	1	1
08/11/2014 08:00	-0.9	12.6	1,964.2	-0.5	1.4	1	1	1
08/11/2014 09:00	-0.7	11.4	2,182.3	-0.2	1.5	1	1	1
08/11/2014 10:00	-0.5	11.2	2,222.1	-0.1	1.6	1	1	1
08/11/2014 11:00	-0.4	11.1	2,231.4	0.1	1.6	1	1	1
08/11/2014 12:00	-0.4	11.1	2,221.3	0.1	1.6	1	1	1
08/11/2014 13:00	-0.5	11.3	2,196.8	-0.1	1.5	1	1	1
08/11/2014 14:00	-0.4	11.3	2,167.6	0.1	1.5	1	1	1
08/11/2014 15:00	-0.5	11.3	2,155.3	-0.1	1.5	1	1	1
08/11/2014 16:00	-0.5	11.3	2,162.5	-0.1	1.5	1	1	1
08/11/2014 17:00	-0.5	11.2	2,176.5	-0.1	1.5	1	1	1
08/11/2014 18:00	-0.5	11.3	2,170.9	-0.1	1.5	1	1	1
08/11/2014 19:00	-0.4	11.2	2,201.0	0.1	1.5	1	1	1
08/11/2014 20:00	-0.5	11.4	2,168.7	-0.1	1.5	1	1	1
08/11/2014 21:00	-0.7	12.6	1,916.0	-0.2	1.3	1	1	1
08/11/2014 22:00	0.4	13.8	1,694.3	0.4	1.2	1	1	0
08/11/2014 23:00	0.4	13.7	1,681.0	0.4	1.2	1	1	0
Average/Sum#:	-0.6	12.0	2,053.6	-0.2	1.4	24 #	24 #	22 #
Minimum:	-0.9	11.1	1,681.0	-0.5	1.2	1	1	0
Maximum:	0.4	13.8	2,231.4	0.4	1.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/12/2014 00:00	0.3	13.8	1,638.6	0.4	1.1	1	1	0
08/12/2014 01:00	0.4	13.8	1,665.7	0.4	1.2	1	1	0
08/12/2014 02:00	0.3	13.8	1,537.8	0.4	1.1	1	1	0
08/12/2014 03:00	0.4	13.8	1,529.6	0.4	1.1	1	1	0
08/12/2014 04:00	0.4	13.8	1,692.4	0.4	1.2	1	1	0
08/12/2014 05:00	0.4	13.7	1,762.6	0.4	1.2	1	1	0
08/12/2014 06:00	0.4	13.7	1,763.6	0.4	1.2	1	1	0
08/12/2014 07:00	0.4	13.7	1,727.9	0.4	1.2	1	1	0
08/12/2014 08:00	0.3	13.8	1,307.3	0.4	0.9	1	1	0
08/12/2014 09:00	0.4	13.8	1,633.8	0.4	1.1	1	1	0
08/12/2014 10:00	0.6	13.6	1,747.8	0.6	1.2	1	1	0
08/12/2014 11:00	0.6	13.8	1,648.9	0.6	1.2	1	1	0
08/12/2014 12:00	0.6	13.7	1,747.5	0.6	1.2	1	1	0
08/12/2014 13:00	0.6	13.7	1,744.8	0.6	1.2	1	1	0
08/12/2014 14:00	0.6	13.7	1,738.7	0.6	1.2	1	1	0
08/12/2014 15:00	0.6	13.7	1,733.5	0.6	1.2	1	1	0
08/12/2014 16:00	0.6	13.7	1,736.9	0.6	1.2	1	1	0
08/12/2014 17:00	0.6	13.7	1,743.3	0.6	1.2	1	1	0
08/12/2014 18:00	0.6	13.7	1,748.3	0.6	1.2	1	1	0
08/12/2014 19:00	0.6	13.7	1,758.2	0.6	1.2	1	1	0
08/12/2014 20:00	0.6	13.6	1,767.2	0.6	1.2	1	1	0
08/12/2014 21:00	0.6	13.6	1,771.8	0.6	1.2	1	1	0
08/12/2014 22:00	0.6	13.6	1,777.3	0.6	1.2	1	1	0
08/12/2014 23:00	0.6	13.6	1,779.5	0.6	1.2	1	1	0
Average/Sum#:	0.5	13.7	1,696.0	0.5	1.2	24 #	24 #	0 #
Minimum:	0.3	13.6	1,307.3	0.4	0.9	1	1	0
Maximum:	0.6	13.8	1,779.5	0.6	1.2	1	1	0
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/13/2014 00:00	0.6	13.6	1,772.6	0.6	1.2	1	1	0
08/13/2014 01:00	0.0	14.2	1,386.5	0.0	1.0	1	0	0
08/13/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2014 08:00	0.0	17.3	482.5	0.0	0.3	1	0	0
08/13/2014 09:00	0.0	14.9	1,149.6	0.0	0.8	1	0	0
08/13/2014 10:00	0.6	13.6	1,763.0	0.6	1.2	1	1	0
08/13/2014 11:00	0.6	13.6	1,756.0	0.6	1.2	1	1	0
08/13/2014 12:00	0.6	13.6	1,759.7	0.6	1.2	1	1	0
08/13/2014 13:00	0.6	13.6	1,754.9	0.6	1.2	1	1	0
08/13/2014 14:00	0.6	13.6	1,744.0	0.6	1.2	1	1	0
08/13/2014 15:00	0.6	13.7	1,728.3	0.6	1.2	1	1	0
08/13/2014 16:00	0.6	13.7	1,725.7	0.6	1.2	1	1	0
08/13/2014 17:00	0.6	13.7	1,726.2	0.6	1.2	1	1	0
08/13/2014 18:00	0.6	13.6	1,728.7	0.6	1.2	1	1	0
08/13/2014 19:00	0.6	13.6	1,735.5	0.6	1.2	1	1	0
08/13/2014 20:00	0.6	13.6	1,746.5	0.6	1.2	1	1	0
08/13/2014 21:00	0.6	13.7	1,731.8	0.6	1.2	1	1	0
08/13/2014 22:00	0.6	13.8	1,649.9	0.6	1.2	1	1	0
08/13/2014 23:00	0.0	14.9	929.1	0.0	0.7	1	0	0
Average/Sum#:	0.5	14.0	1,570.6	0.5	1.1	18 #	14 #	0 #
Minimum:	0.0	13.6	482.5	0.0	0.3	0	0	0
Maximum:	0.6	17.3	1,772.6	0.6	1.2	1	1	0
%SI	25.0	25.0	25.0	25.0	25.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/14/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/15/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/16/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/17/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/18/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/19/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/20/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/21/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/22/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/23/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/24/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/25/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/26/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/27/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/28/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/29/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/30/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/31/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/01/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/02/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/03/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/04/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/05/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/05/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/05/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/05/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/05/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/05/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/05/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/05/2014 07:00	0.0	17.0	487.1	0.0	0.3	1	0	0
09/05/2014 08:00	0.0	15.2	906.7	0.0	0.6	1	0	0
09/05/2014 09:00	0.6	13.9	1,417.4	0.6	1.0	1	1	0
09/05/2014 10:00	0.6	13.9	1,263.2	0.6	0.9	1	1	0
09/05/2014 11:00	0.6	14.0	1,365.2	0.6	1.0	1	1	0
09/05/2014 12:00	0.7	13.4	1,677.1	0.7	1.2	1	1	1
09/05/2014 13:00	0.7	12.9	1,905.1	0.7	1.3	1	1	1
09/05/2014 14:00	0.7	12.9	1,886.0	0.7	1.3	1	1	1
09/05/2014 15:00	0.7	12.7	1,920.6	0.7	1.3	1	1	1
09/05/2014 16:00	0.7	12.7	1,926.4	0.7	1.3	1	1	1
09/05/2014 17:00	0.7	11.7	2,132.5	0.7	1.5	1	1	1
09/05/2014 18:00	0.7	12.2	2,016.0	0.7	1.4	1	1	1
09/05/2014 19:00	0.7	12.7	1,935.2	0.7	1.4	1	1	1
09/05/2014 20:00	0.7	13.2	1,837.3	0.7	1.3	1	1	1
09/05/2014 21:00	0.7	12.9	1,903.2	0.7	1.3	1	1	1
09/05/2014 22:00	0.7	12.9	1,916.4	0.7	1.3	1	1	1
09/05/2014 23:00	0.7	11.8	2,151.4	0.7	1.5	1	1	1
Average/Sum#:	0.6	13.3	1,685.1	0.6	1.2	17 #	15 #	12 #
Minimum:	0.0	11.7	487.1	0.0	0.3	0	0	0
Maximum:	0.7	17.0	2,151.4	0.7	1.5	1	1	1
%SI	29.2	29.2	29.2	29.2	29.2	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/06/2014 00:00	0.7	12.3	2,027.8	0.7	1.4	1	1	1
09/06/2014 01:00	0.7	12.9	1,908.8	0.7	1.3	1	1	1
09/06/2014 02:00	0.7	12.8	1,955.9	0.7	1.4	1	1	1
09/06/2014 03:00	0.7	12.8	1,955.5	0.7	1.4	1	1	1
09/06/2014 04:00	0.7	12.8	1,946.2	0.7	1.4	1	1	1
09/06/2014 05:00	0.7	13.3	1,831.9	0.7	1.3	1	1	1
09/06/2014 06:00	0.7	13.3	1,843.2	0.7	1.3	1	1	1
09/06/2014 07:00	0.7	13.1	1,870.2	0.7	1.3	1	1	1
09/06/2014 08:00	0.7	13.4	1,835.7	0.7	1.3	1	1	1
09/06/2014 09:00	0.7	13.1	1,903.5	0.7	1.3	1	1	1
09/06/2014 10:00	0.7	13.1	1,882.2	0.7	1.3	1	1	1
09/06/2014 11:00	0.7	13.0	1,904.9	0.7	1.3	1	1	1
09/06/2014 12:00	0.7	12.3	2,017.3	0.7	1.4	1	1	1
09/06/2014 13:00	0.7	11.5	2,179.2	0.7	1.5	1	1	1
09/06/2014 14:00	0.7	12.2	2,030.4	0.7	1.4	1	1	1
09/06/2014 15:00	0.7	12.5	1,981.4	0.7	1.4	1	1	1
09/06/2014 16:00	0.7	12.6	1,960.5	0.7	1.4	1	1	1
09/06/2014 17:00	0.7	11.3	2,211.6	0.7	1.5	1	1	1
09/06/2014 18:00	0.7	11.7	2,135.1	0.7	1.5	1	1	1
09/06/2014 19:00	0.7	13.0	1,871.8	0.7	1.3	1	1	1
09/06/2014 20:00	0.7	13.3	1,837.4	0.7	1.3	1	1	1
09/06/2014 21:00	0.7	13.3	1,838.2	0.7	1.3	1	1	1
09/06/2014 22:00	0.7	13.1	1,874.9	0.7	1.3	1	1	1
09/06/2014 23:00	0.7	12.8	1,960.5	0.7	1.4	1	1	1
Average/Sum#:	0.7	12.7	1,948.5	0.7	1.4	24 #	24 #	24 #
Minimum:	0.7	11.3	1,831.9	0.7	1.3	1	1	1
Maximum:	0.7	13.4	2,211.6	0.7	1.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/07/2014 00:00	0.7	13.2	1,874.5	0.7	1.3	1	1	1
09/07/2014 01:00	0.7	13.2	1,880.4	0.7	1.3	1	1	1
09/07/2014 02:00	0.7	13.4	1,833.8	0.7	1.3	1	1	1
09/07/2014 03:00	0.7	13.4	1,830.6	0.7	1.3	1	1	1
09/07/2014 04:00	0.7	13.3	1,829.8	0.7	1.3	1	1	1
09/07/2014 05:00	0.7	13.3	1,831.2	0.7	1.3	1	1	1
09/07/2014 06:00	0.7	13.3	1,825.0	0.7	1.3	1	1	1
09/07/2014 07:00	0.7	13.3	1,836.8	0.7	1.3	1	1	1
09/07/2014 08:00	0.7	13.1	1,907.6	0.7	1.3	1	1	1
09/07/2014 09:00	0.7	12.5	2,008.8	0.7	1.4	1	1	1
09/07/2014 10:00	0.7	12.0	2,096.0	0.7	1.5	1	1	1
09/07/2014 11:00	0.7	12.0	2,082.5	0.7	1.5	1	1	1
09/07/2014 12:00	0.7	12.7	1,944.2	0.7	1.4	1	1	1
09/07/2014 13:00	0.7	12.8	1,927.5	0.7	1.3	1	1	1
09/07/2014 14:00	0.7	12.8	1,919.9	0.7	1.3	1	1	1
09/07/2014 15:00	0.7	12.7	1,933.6	0.7	1.4	1	1	1
09/07/2014 16:00	0.7	12.3	2,025.2	0.7	1.4	1	1	1
09/07/2014 17:00	0.7	11.4	2,182.8	0.7	1.5	1	1	1
09/07/2014 18:00	0.7	11.4	2,181.5	0.7	1.5	1	1	1
09/07/2014 19:00	0.7	11.5	2,179.3	0.7	1.5	1	1	1
09/07/2014 20:00	0.7	12.1	2,049.1	0.7	1.4	1	1	1
09/07/2014 21:00	0.7	13.0	1,873.8	0.7	1.3	1	1	1
09/07/2014 22:00	0.7	13.3	1,832.2	0.7	1.3	1	1	1
09/07/2014 23:00	0.7	13.1	1,897.2	0.7	1.3	1	1	1
Average/Sum#:	0.7	12.7	1,949.3	0.7	1.4	24 #	24 #	24 #
Minimum:	0.7	11.4	1,825.0	0.7	1.3	1	1	1
Maximum:	0.7	13.4	2,182.8	0.7	1.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/08/2014 00:00	0.7	13.6	1,499.4	0.7	1.0	1	1	1
09/08/2014 01:00	0.6	13.9	1,252.9	0.6	0.9	1	1	0
09/08/2014 02:00	0.6	13.9	1,247.5	0.6	0.9	1	1	0
09/08/2014 03:00	0.7	13.8	1,552.8	0.7	1.1	1	1	1
09/08/2014 04:00	0.7	13.0	1,914.5	0.7	1.3	1	1	1
09/08/2014 05:00	0.7	13.2	1,872.9	0.7	1.3	1	1	1
09/08/2014 06:00	0.7	12.3	2,095.5	0.7	1.5	1	1	1
09/08/2014 07:00	0.7	11.2	2,271.1	0.7	1.6	1	1	1
09/08/2014 08:00	0.7	12.0	2,113.0	0.7	1.5	1	1	1
09/08/2014 09:00	0.7	13.4	1,849.0	0.7	1.3	1	1	1
09/08/2014 10:00	0.7	13.4	1,837.1	0.7	1.3	1	1	1
09/08/2014 11:00	0.7	13.4	1,835.5	0.7	1.3	1	1	1
09/08/2014 12:00	0.7	13.3	1,836.3	0.7	1.3	1	1	1
09/08/2014 13:00	0.7	13.3	1,836.4	0.7	1.3	1	1	1
09/08/2014 14:00	0.7	13.3	1,838.3	0.7	1.3	1	1	1
09/08/2014 15:00	0.7	13.2	1,843.0	0.7	1.3	1	1	1
09/08/2014 16:00	0.7	13.4	1,598.3	0.7	1.1	1	1	1
09/08/2014 17:00	0.6	14.0	1,267.0	0.6	0.9	1	1	0
09/08/2014 18:00	0.6	14.0	1,513.3	0.6	1.1	1	1	0
09/08/2014 19:00	0.6	14.0	1,527.9	0.6	1.1	1	1	0
09/08/2014 20:00	0.6	13.9	1,439.8	0.6	1.0	1	1	0
09/08/2014 21:00	0.6	13.9	1,361.4	0.6	1.0	1	1	0
09/08/2014 22:00	0.6	13.9	1,295.7	0.6	0.9	1	1	0
09/08/2014 23:00	0.6	13.9	1,251.0	0.6	0.9	1	1	0
Average/Sum#:	0.7	13.4	1,664.6	0.7	1.2	24 #	24 #	15 #
Minimum:	0.6	11.2	1,247.5	0.6	0.9	1	1	0
Maximum:	0.7	14.0	2,271.1	0.7	1.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/09/2014 00:00	0.6	13.9	1,251.7	0.6	0.9	1	1	0
09/09/2014 01:00	0.6	13.9	1,251.6	0.6	0.9	1	1	0
09/09/2014 02:00	0.6	13.9	1,252.0	0.6	0.9	1	1	0
09/09/2014 03:00	0.6	13.9	1,353.2	0.6	0.9	1	1	0
09/09/2014 04:00	0.6	13.9	1,265.9	0.6	0.9	1	1	0
09/09/2014 05:00	0.6	13.9	1,304.7	0.6	0.9	1	1	0
09/09/2014 06:00	0.6	13.9	1,259.0	0.6	0.9	1	1	0
09/09/2014 07:00	0.6	13.9	1,266.0	0.6	0.9	1	1	0
09/09/2014 08:00	0.7	13.7	1,561.4	0.7	1.1	1	1	1
09/09/2014 09:00	0.7	13.3	1,862.9	0.7	1.3	1	1	1
09/09/2014 10:00	0.7	13.3	1,846.7	0.7	1.3	1	1	1
09/09/2014 11:00	0.7	13.2	1,841.0	0.7	1.3	1	1	1
09/09/2014 12:00	0.7	12.9	1,905.0	0.7	1.3	1	1	1
09/09/2014 13:00	0.7	12.7	1,909.4	0.7	1.3	1	1	1
09/09/2014 14:00	0.7	12.9	1,867.0	0.7	1.3	1	1	1
09/09/2014 15:00	0.7	13.0	1,846.3	0.7	1.3	1	1	1
09/09/2014 16:00	0.7	12.9	1,841.1	0.7	1.3	1	1	1
09/09/2014 17:00	0.7	12.9	1,854.0	0.7	1.3	1	1	1
09/09/2014 18:00	0.7	13.0	1,836.8	0.7	1.3	1	1	1
09/09/2014 19:00	0.7	13.0	1,835.2	0.7	1.3	1	1	1
09/09/2014 20:00	0.7	13.0	1,859.3	0.7	1.3	1	1	1
09/09/2014 21:00	0.7	12.8	1,890.8	0.7	1.3	1	1	1
09/09/2014 22:00	0.7	13.0	1,872.5	0.7	1.3	1	1	1
09/09/2014 23:00	0.7	12.5	1,975.6	0.7	1.4	1	1	1
Average/Sum#:	0.7	13.3	1,658.7	0.7	1.2	24 #	24 #	16 #
Minimum:	0.6	12.5	1,251.6	0.6	0.9	1	1	0
Maximum:	0.7	13.9	1,975.6	0.7	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/10/2014 00:00	0.7	12.5	1,978.6	0.7	1.4	1	1	1
09/10/2014 01:00	0.7	12.5	1,976.5	0.7	1.4	1	1	1
09/10/2014 02:00	0.7	13.0	1,874.7	0.7	1.3	1	1	1
09/10/2014 03:00	0.7	12.7	1,944.2	0.7	1.4	1	1	1
09/10/2014 04:00	0.7	12.4	1,996.4	0.7	1.4	1	1	1
09/10/2014 05:00	0.7	12.8	1,935.7	0.7	1.4	1	1	1
09/10/2014 06:00	0.7	13.3	1,831.2	0.7	1.3	1	1	1
09/10/2014 07:00	0.7	13.3	1,828.7	0.7	1.3	1	1	1
09/10/2014 08:00	0.7	13.3	1,828.2	0.7	1.3	1	1	1
09/10/2014 09:00	0.7	12.9	1,886.9	0.7	1.3	1	1	1
09/10/2014 10:00	0.7	13.6	1,537.8	0.7	1.1	1	1	1
09/10/2014 11:00	0.6	14.0	1,256.9	0.6	0.9	1	1	0
09/10/2014 12:00	0.7	13.4	1,709.3	0.7	1.2	1	1	1
09/10/2014 13:00	0.7	12.9	1,906.8	0.7	1.3	1	1	1
09/10/2014 14:00	0.7	12.7	1,952.5	0.7	1.4	1	1	1
09/10/2014 15:00	0.7	11.6	2,159.4	0.7	1.5	1	1	1
09/10/2014 16:00	0.7	11.3	2,208.6	0.7	1.5	1	1	1
09/10/2014 17:00	0.7	11.3	2,209.1	0.7	1.5	1	1	1
09/10/2014 18:00	0.7	11.4	2,186.6	0.7	1.5	1	1	1
09/10/2014 19:00	0.7	11.7	2,140.0	0.7	1.5	1	1	1
09/10/2014 20:00	0.7	12.0	2,069.1	0.7	1.4	1	1	1
09/10/2014 21:00	0.7	12.4	2,018.2	0.7	1.4	1	1	1
09/10/2014 22:00	0.7	12.5	2,006.7	0.7	1.4	1	1	1
09/10/2014 23:00	0.7	12.1	2,085.9	0.7	1.5	1	1	1
Average/Sum#:	0.7	12.6	1,938.7	0.7	1.4	24 #	24 #	23 #
Minimum:	0.6	11.3	1,256.9	0.6	0.9	1	1	0
Maximum:	0.7	14.0	2,209.1	0.7	1.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/11/2014 00:00	0.7	12.8	1,941.4	0.7	1.4	1	1	1
09/11/2014 01:00	0.7	13.3	1,840.4	0.7	1.3	1	1	1
09/11/2014 02:00	0.7	13.3	1,840.4	0.7	1.3	1	1	1
09/11/2014 03:00	0.7	13.3	1,839.9	0.7	1.3	1	1	1
09/11/2014 04:00	0.7	13.0	1,917.6	0.7	1.3	1	1	1
09/11/2014 05:00	0.7	12.3	2,051.4	0.7	1.4	1	1	1
09/11/2014 06:00	0.7	12.7	1,972.7	0.7	1.4	1	1	1
09/11/2014 07:00	0.7	12.8	1,957.7	0.7	1.4	1	1	1
09/11/2014 08:00	0.7	12.9	1,933.8	0.7	1.4	1	1	1
09/11/2014 09:00	0.7	12.7	1,978.6	0.7	1.4	1	1	1
09/11/2014 10:00	0.7	12.2	2,066.1	0.7	1.4	1	1	1
09/11/2014 11:00	0.7	11.9	2,091.6	0.7	1.5	1	1	1
09/11/2014 12:00	0.7	12.9	1,892.4	0.7	1.3	1	1	1
09/11/2014 13:00	0.7	12.9	1,884.0	0.7	1.3	1	1	1
09/11/2014 14:00	0.7	13.0	1,863.3	0.7	1.3	1	1	1
09/11/2014 15:00	0.7	13.0	1,872.0	0.7	1.3	1	1	1
09/11/2014 16:00	0.7	12.1	2,072.6	0.7	1.5	1	1	1
09/11/2014 17:00	0.7	11.4	2,191.8	0.7	1.5	1	1	1
09/11/2014 18:00	0.7	11.3	2,211.6	0.7	1.5	1	1	1
09/11/2014 19:00	0.7	11.6	2,147.1	0.7	1.5	1	1	1
09/11/2014 20:00	0.7	11.6	2,154.3	0.7	1.5	1	1	1
09/11/2014 21:00	0.7	12.4	1,995.9	0.7	1.4	1	1	1
09/11/2014 22:00	0.7	12.3	2,035.0	0.7	1.4	1	1	1
09/11/2014 23:00	0.7	11.4	2,231.2	0.7	1.6	1	1	1
Average/Sum#:	0.7	12.5	1,999.3	0.7	1.4	24 #	24 #	24 #
Minimum:	0.7	11.3	1,839.9	0.7	1.3	1	1	1
Maximum:	0.7	13.3	2,231.2	0.7	1.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/12/2014 00:00	0.7	11.8	2,143.7	0.7	1.5	1	1	1
09/12/2014 01:00	0.7	12.8	1,908.6	0.7	1.3	1	1	1
09/12/2014 02:00	0.7	12.3	1,986.1	0.7	1.4	1	1	1
09/12/2014 03:00	0.7	12.3	2,018.6	0.7	1.4	1	1	1
09/12/2014 04:00	0.7	11.5	2,219.1	0.7	1.6	1	1	1
09/12/2014 05:00	0.7	11.7	2,185.3	0.7	1.5	1	1	1
09/12/2014 06:00	0.7	11.5	2,230.8	0.7	1.6	1	1	1
09/12/2014 07:00	0.7	11.6	2,207.0	0.7	1.5	1	1	1
09/12/2014 08:00	0.7	11.9	2,125.9	0.7	1.5	1	1	1
09/12/2014 09:00	0.7	11.5	2,208.4	0.7	1.5	1	1	1
09/12/2014 10:00	0.7	11.6	2,192.6	0.7	1.5	1	1	1
09/12/2014 11:00	0.7	11.5	2,188.0	0.7	1.5	1	1	1
09/12/2014 12:00	0.7	11.4	2,204.7	0.7	1.5	1	1	1
09/12/2014 13:00	0.7	11.3	2,211.7	0.7	1.5	1	1	1
09/12/2014 14:00	0.7	11.4	2,172.6	0.7	1.5	1	1	1
09/12/2014 15:00	0.7	11.4	2,171.6	0.7	1.5	1	1	1
09/12/2014 16:00	0.7	11.4	2,161.7	0.7	1.5	1	1	1
09/12/2014 17:00	0.7	11.3	2,193.2	0.7	1.5	1	1	1
09/12/2014 18:00	0.7	11.3	2,206.3	0.7	1.5	1	1	1
09/12/2014 19:00	0.7	11.2	2,225.5	0.7	1.6	1	1	1
09/12/2014 20:00	0.7	11.7	2,163.5	0.7	1.5	1	1	1
09/12/2014 21:00	0.7	12.0	2,085.3	0.7	1.5	1	1	1
09/12/2014 22:00	0.7	12.7	1,950.5	0.7	1.4	1	1	1
09/12/2014 23:00	0.7	12.7	1,955.3	0.7	1.4	1	1	1
Average/Sum#:	0.7	11.7	2,138.2	0.7	1.5	24 #	24 #	24 #
Minimum:	0.7	11.2	1,908.6	0.7	1.3	1	1	1
Maximum:	0.7	12.8	2,230.8	0.7	1.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/13/2014 00:00	0.7	12.8	1,947.8	0.7	1.4	1	1	1
09/13/2014 01:00	0.7	12.9	1,918.2	0.7	1.3	1	1	1
09/13/2014 02:00	0.7	13.5	1,794.1	0.7	1.3	1	1	1
09/13/2014 03:00	0.7	13.3	1,846.3	0.7	1.3	1	1	1
09/13/2014 04:00	0.7	13.3	1,781.3	0.7	1.2	1	1	1
09/13/2014 05:00	0.6	13.9	1,256.8	0.6	0.9	1	1	0
09/13/2014 06:00	0.6	13.9	1,250.0	0.6	0.9	1	1	0
09/13/2014 07:00	0.6	13.9	1,249.9	0.6	0.9	1	1	0
09/13/2014 08:00	0.6	13.9	1,388.3	0.6	1.0	1	1	0
09/13/2014 09:00	0.6	14.0	1,509.1	0.6	1.1	1	1	0
09/13/2014 10:00	0.7	13.8	1,573.8	0.7	1.1	1	1	1
09/13/2014 11:00	0.7	12.6	1,978.8	0.7	1.4	1	1	1
09/13/2014 12:00	0.7	11.8	2,102.5	0.7	1.5	1	1	1
09/13/2014 13:00	0.7	12.3	1,997.1	0.7	1.4	1	1	1
09/13/2014 14:00	0.7	12.2	2,004.0	0.7	1.4	1	1	1
09/13/2014 15:00	0.7	11.7	2,108.0	0.7	1.5	1	1	1
09/13/2014 16:00	0.7	11.7	2,089.4	0.7	1.5	1	1	1
09/13/2014 17:00	0.7	11.9	2,062.6	0.7	1.4	1	1	1
09/13/2014 18:00	0.7	12.5	1,957.2	0.7	1.4	1	1	1
09/13/2014 19:00	0.7	12.3	2,008.7	0.7	1.4	1	1	1
09/13/2014 20:00	0.7	12.7	1,949.5	0.7	1.4	1	1	1
09/13/2014 21:00	0.7	12.7	1,948.4	0.7	1.4	1	1	1
09/13/2014 22:00	0.7	12.9	1,911.1	0.7	1.3	1	1	1
09/13/2014 23:00	0.7	12.8	1,941.9	0.7	1.4	1	1	1
Average/Sum#:	0.7	12.9	1,815.6	0.7	1.3	24 #	24 #	19 #
Minimum:	0.6	11.7	1,249.9	0.6	0.9	1	1	0
Maximum:	0.7	14.0	2,108.0	0.7	1.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/14/2014 00:00	0.7	13.0	1,896.9	0.7	1.3	1	1	1
09/14/2014 01:00	0.7	13.2	1,850.9	0.7	1.3	1	1	1
09/14/2014 02:00	0.7	13.3	1,844.9	0.7	1.3	1	1	1
09/14/2014 03:00	0.7	13.3	1,847.9	0.7	1.3	1	1	1
09/14/2014 04:00	0.7	13.3	1,793.5	0.7	1.3	1	1	1
09/14/2014 05:00	0.6	13.9	1,262.0	0.6	0.9	1	1	0
09/14/2014 06:00	0.6	13.9	1,250.7	0.6	0.9	1	1	0
09/14/2014 07:00	0.6	13.9	1,251.1	0.6	0.9	1	1	0
09/14/2014 08:00	0.6	13.9	1,435.4	0.6	1.0	1	1	0
09/14/2014 09:00	0.7	13.5	1,631.5	0.7	1.1	1	1	1
09/14/2014 10:00	0.7	13.0	1,900.7	0.7	1.3	1	1	1
09/14/2014 11:00	0.7	12.7	1,945.9	0.7	1.4	1	1	1
09/14/2014 12:00	0.7	11.6	2,169.8	0.7	1.5	1	1	1
09/14/2014 13:00	0.7	11.5	2,182.9	0.7	1.5	1	1	1
09/14/2014 14:00	0.7	11.5	2,173.9	0.7	1.5	1	1	1
09/14/2014 15:00	0.7	11.4	2,158.0	0.7	1.5	1	1	1
09/14/2014 16:00	0.7	11.4	2,151.0	0.7	1.5	1	1	1
09/14/2014 17:00	0.7	11.5	2,139.0	0.7	1.5	1	1	1
09/14/2014 18:00	0.7	11.6	2,129.5	0.7	1.5	1	1	1
09/14/2014 19:00	0.7	11.8	2,100.9	0.7	1.5	1	1	1
09/14/2014 20:00	0.7	12.1	2,057.1	0.7	1.4	1	1	1
09/14/2014 21:00	0.7	12.4	1,995.9	0.7	1.4	1	1	1
09/14/2014 22:00	0.7	12.8	1,916.5	0.7	1.3	1	1	1
09/14/2014 23:00	0.7	12.9	1,910.6	0.7	1.3	1	1	1
Average/Sum#:	0.7	12.6	1,874.9	0.7	1.3	24 #	24 #	20 #
Minimum:	0.6	11.4	1,250.7	0.6	0.9	1	1	0
Maximum:	0.7	13.9	2,182.9	0.7	1.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/15/2014 00:00	0.7	13.1	1,857.7	0.7	1.3	1	1	1
09/15/2014 01:00	0.7	13.3	1,834.3	0.7	1.3	1	1	1
09/15/2014 02:00	0.7	13.3	1,832.1	0.7	1.3	1	1	1
09/15/2014 03:00	0.7	13.3	1,835.5	0.7	1.3	1	1	1
09/15/2014 04:00	0.7	13.3	1,838.7	0.7	1.3	1	1	1
09/15/2014 05:00	0.7	13.3	1,841.7	0.7	1.3	1	1	1
09/15/2014 06:00	0.7	13.3	1,842.9	0.7	1.3	1	1	1
09/15/2014 07:00	0.7	13.2	1,861.7	0.7	1.3	1	1	1
09/15/2014 08:00	0.7	12.7	1,955.4	0.7	1.4	1	1	1
09/15/2014 09:00	0.7	12.0	2,108.6	0.7	1.5	1	1	1
09/15/2014 10:00	0.7	11.6	2,166.7	0.7	1.5	1	1	1
09/15/2014 11:00	0.7	11.5	2,173.6	0.7	1.5	1	1	1
09/15/2014 12:00	0.7	12.5	1,797.4	0.7	1.3	1	1	1
09/15/2014 13:00	0.6	14.0	1,320.5	0.6	0.9	1	1	0
09/15/2014 14:00	0.6	14.0	1,328.8	0.6	0.9	1	1	0
09/15/2014 15:00	0.7	12.7	1,902.1	0.7	1.3	1	1	1
09/15/2014 16:00	0.7	11.9	2,092.5	0.7	1.5	1	1	1
09/15/2014 17:00	0.7	12.0	2,080.7	0.7	1.5	1	1	1
09/15/2014 18:00	0.7	12.2	2,060.0	0.7	1.4	1	1	1
09/15/2014 19:00	0.7	12.3	2,039.2	0.7	1.4	1	1	1
09/15/2014 20:00	0.7	12.5	2,012.4	0.7	1.4	1	1	1
09/15/2014 21:00	0.7	13.0	1,904.8	0.7	1.3	1	1	1
09/15/2014 22:00	0.7	13.4	1,831.1	0.7	1.3	1	1	1
09/15/2014 23:00	0.7	13.3	1,841.8	0.7	1.3	1	1	1
Average/Sum#:	0.7	12.8	1,890.0	0.7	1.3	24 #	24 #	22 #
Minimum:	0.6	11.5	1,320.5	0.6	0.9	1	1	0
Maximum:	0.7	14.0	2,173.6	0.7	1.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/16/2014 00:00	0.7	13.4	1,832.9	0.7	1.3	1	1	1
09/16/2014 01:00	0.7	13.4	1,829.4	0.7	1.3	1	1	1
09/16/2014 02:00	0.7	13.7	1,573.8	0.7	1.1	1	1	1
09/16/2014 03:00	0.6	13.8	1,276.0	0.6	0.9	1	1	0
09/16/2014 04:00	0.7	13.6	1,654.2	0.7	1.2	1	1	1
09/16/2014 05:00	0.7	13.0	1,925.0	0.7	1.3	1	1	1
09/16/2014 06:00	0.7	13.0	1,937.8	0.7	1.4	1	1	1
09/16/2014 07:00	0.7	12.7	1,977.1	0.7	1.4	1	1	1
09/16/2014 08:00	0.7	12.6	2,006.5	0.7	1.4	1	1	1
09/16/2014 09:00	0.7	12.6	2,006.7	0.7	1.4	1	1	1
09/16/2014 10:00	0.7	11.8	2,159.6	0.7	1.5	1	1	1
09/16/2014 11:00	0.7	11.8	2,165.5	0.7	1.5	1	1	1
09/16/2014 12:00	0.7	11.8	2,169.1	0.7	1.5	1	1	1
09/16/2014 13:00	0.7	11.8	2,159.3	0.7	1.5	1	1	1
09/16/2014 14:00	0.7	12.5	2,008.1	0.7	1.4	1	1	1
09/16/2014 15:00	0.7	12.9	1,918.3	0.7	1.3	1	1	1
09/16/2014 16:00	0.7	12.4	2,036.8	0.7	1.4	1	1	1
09/16/2014 17:00	0.7	11.7	2,171.7	0.7	1.5	1	1	1
09/16/2014 18:00	0.7	11.7	2,176.0	0.7	1.5	1	1	1
09/16/2014 19:00	0.7	11.7	2,182.3	0.7	1.5	1	1	1
09/16/2014 20:00	0.7	12.0	2,128.7	0.7	1.5	1	1	1
09/16/2014 21:00	0.7	13.1	1,884.6	0.7	1.3	1	1	1
09/16/2014 22:00	0.7	13.6	1,691.0	0.7	1.2	1	1	1
09/16/2014 23:00	0.7	13.6	1,787.1	0.7	1.3	1	1	1
Average/Sum#:	0.7	12.7	1,944.1	0.7	1.4	24 #	24 #	23 #
Minimum:	0.6	11.7	1,276.0	0.6	0.9	1	1	0
Maximum:	0.7	13.8	2,182.3	0.7	1.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/17/2014 00:00	0.7	12.2	2,110.1	0.7	1.5	1	1	1
09/17/2014 01:00	0.7	12.2	2,099.8	0.7	1.5	1	1	1
09/17/2014 02:00	0.7	12.7	1,997.5	0.7	1.4	1	1	1
09/17/2014 03:00	0.7	11.9	2,161.2	0.7	1.5	1	1	1
09/17/2014 04:00	0.7	11.8	2,170.8	0.7	1.5	1	1	1
09/17/2014 05:00	0.7	12.0	2,143.1	0.7	1.5	1	1	1
09/17/2014 06:00	0.7	12.0	2,146.1	0.7	1.5	1	1	1
09/17/2014 07:00	0.7	11.8	2,166.7	0.7	1.5	1	1	1
09/17/2014 08:00	0.7	11.9	2,151.3	0.7	1.5	1	1	1
09/17/2014 09:00	0.7	11.9	2,128.3	0.7	1.5	1	1	1
09/17/2014 10:00	0.7	11.9	2,140.8	0.7	1.5	1	1	1
09/17/2014 11:00	0.7	11.8	2,157.0	0.7	1.5	1	1	1
09/17/2014 12:00	0.7	11.6	2,173.9	0.7	1.5	1	1	1
09/17/2014 13:00	0.7	11.7	2,153.5	0.7	1.5	1	1	1
09/17/2014 14:00	0.7	11.9	2,105.8	0.7	1.5	1	1	1
09/17/2014 15:00	0.7	12.1	2,070.4	0.7	1.4	1	1	1
09/17/2014 16:00	0.7	12.7	1,962.9	0.7	1.4	1	1	1
09/17/2014 17:00	0.7	12.7	1,962.2	0.7	1.4	1	1	1
09/17/2014 18:00	0.7	12.2	2,043.2	0.7	1.4	1	1	1
09/17/2014 19:00	0.7	12.5	1,977.0	0.7	1.4	1	1	1
09/17/2014 20:00	0.7	12.6	1,968.1	0.7	1.4	1	1	1
09/17/2014 21:00	0.7	13.2	1,845.7	0.7	1.3	1	1	1
09/17/2014 22:00	0.7	13.2	1,848.0	0.7	1.3	1	1	1
09/17/2014 23:00	0.7	13.2	1,857.6	0.7	1.3	1	1	1
Average/Sum#:	0.7	12.2	2,064.2	0.7	1.4	24 #	24 #	24 #
Minimum:	0.7	11.6	1,845.7	0.7	1.3	1	1	1
Maximum:	0.7	13.2	2,173.9	0.7	1.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/18/2014 00:00	0.7	12.7	1,968.3	0.7	1.4	1	1	1
09/18/2014 01:00	0.7	12.8	1,938.5	0.7	1.4	1	1	1
09/18/2014 02:00	0.7	13.3	1,848.5	0.7	1.3	1	1	1
09/18/2014 03:00	0.7	13.3	1,773.0	0.7	1.2	1	1	1
09/18/2014 04:00	0.6	13.8	1,568.1	0.6	1.1	1	1	0
09/18/2014 05:00	0.6	13.8	1,602.3	0.6	1.1	1	1	0
09/18/2014 06:00	0.6	13.8	1,585.4	0.6	1.1	1	1	0
09/18/2014 07:00	0.6	13.8	1,302.1	0.6	0.9	1	1	0
09/18/2014 08:00	0.6	13.8	1,409.6	0.6	1.0	1	1	0
09/18/2014 09:00	0.6	13.8	1,586.9	0.6	1.1	1	1	0
09/18/2014 10:00	0.6	13.9	1,286.1	0.6	0.9	1	1	0
09/18/2014 11:00	0.6	13.9	1,284.8	0.6	0.9	1	1	0
09/18/2014 12:00	0.6	13.9	1,475.6	0.6	1.0	1	1	0
09/18/2014 13:00	0.6	13.9	1,601.9	0.6	1.1	1	1	0
09/18/2014 14:00	0.6	13.8	1,664.2	0.6	1.2	1	1	0
09/18/2014 15:00	0.6	13.8	1,588.4	0.6	1.1	1	1	0
09/18/2014 16:00	0.7	13.5	1,711.8	0.7	1.2	1	1	1
09/18/2014 17:00	0.7	12.7	1,937.4	0.7	1.4	1	1	1
09/18/2014 18:00	0.7	12.3	2,023.1	0.7	1.4	1	1	1
09/18/2014 19:00	0.7	12.2	2,034.4	0.7	1.4	1	1	1
09/18/2014 20:00	0.7	13.1	1,849.5	0.7	1.3	1	1	1
09/18/2014 21:00	0.7	13.4	1,582.7	0.7	1.1	1	1	1
09/18/2014 22:00	0.6	13.9	1,238.1	0.6	0.9	1	1	0
09/18/2014 23:00	0.6	13.9	1,362.3	0.6	1.0	1	1	0
Average/Sum#:	0.6	13.5	1,634.3	0.6	1.1	24 #	24 #	10 #
Minimum:	0.6	12.2	1,238.1	0.6	0.9	1	1	0
Maximum:	0.7	13.9	2,034.4	0.7	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/19/2014 00:00	0.6	13.9	1,257.8	0.6	0.9	1	1	0
09/19/2014 01:00	0.6	13.9	1,248.4	0.6	0.9	1	1	0
09/19/2014 02:00	0.6	13.9	1,246.9	0.6	0.9	1	1	0
09/19/2014 03:00	0.6	13.9	1,314.6	0.6	0.9	1	1	0
09/19/2014 04:00	0.6	13.9	1,338.4	0.6	0.9	1	1	0
09/19/2014 05:00	0.7	13.6	1,612.1	0.7	1.1	1	1	1
09/19/2014 06:00	0.7	12.8	1,931.9	0.7	1.4	1	1	1
09/19/2014 07:00	0.7	13.3	1,840.9	0.7	1.3	1	1	1
09/19/2014 08:00	0.7	13.2	1,854.7	0.7	1.3	1	1	1
09/19/2014 09:00	0.7	13.2	1,864.3	0.7	1.3	1	1	1
09/19/2014 10:00	0.7	13.2	1,838.8	0.7	1.3	1	1	1
09/19/2014 11:00	0.7	13.2	1,840.3	0.7	1.3	1	1	1
09/19/2014 12:00	0.7	12.6	1,944.1	0.7	1.4	1	1	1
09/19/2014 13:00	0.7	12.6	1,942.2	0.7	1.4	1	1	1
09/19/2014 14:00	0.7	12.4	1,991.0	0.7	1.4	1	1	1
09/19/2014 15:00	0.7	11.4	2,166.7	0.7	1.5	1	1	1
09/19/2014 16:00	0.7	11.4	2,171.4	0.7	1.5	1	1	1
09/19/2014 17:00	0.7	11.5	2,166.1	0.7	1.5	1	1	1
09/19/2014 18:00	0.7	11.9	2,081.5	0.7	1.5	1	1	1
09/19/2014 19:00	0.7	12.8	1,915.8	0.7	1.3	1	1	1
09/19/2014 20:00	0.7	12.9	1,906.0	0.7	1.3	1	1	1
09/19/2014 21:00	0.7	12.8	1,917.5	0.7	1.3	1	1	1
09/19/2014 22:00	0.7	12.7	1,955.5	0.7	1.4	1	1	1
09/19/2014 23:00	0.7	12.5	2,001.2	0.7	1.4	1	1	1
Average/Sum#:	0.7	12.9	1,806.2	0.7	1.3	24 #	24 #	19 #
Minimum:	0.6	11.4	1,246.9	0.6	0.9	1	1	0
Maximum:	0.7	13.9	2,171.4	0.7	1.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/20/2014 00:00	0.7	12.3	2,042.4	0.7	1.4	1	1	1
09/20/2014 01:00	0.7	11.8	2,125.5	0.7	1.5	1	1	1
09/20/2014 02:00	0.7	12.6	1,975.2	0.7	1.4	1	1	1
09/20/2014 03:00	0.7	12.6	1,970.8	0.7	1.4	1	1	1
09/20/2014 04:00	0.7	12.6	1,985.1	0.7	1.4	1	1	1
09/20/2014 05:00	0.7	12.7	1,956.6	0.7	1.4	1	1	1
09/20/2014 06:00	0.7	12.7	1,971.3	0.7	1.4	1	1	1
09/20/2014 07:00	0.7	12.6	1,979.2	0.7	1.4	1	1	1
09/20/2014 08:00	0.7	13.2	1,842.3	0.7	1.3	1	1	1
09/20/2014 09:00	0.7	13.2	1,840.5	0.7	1.3	1	1	1
09/20/2014 10:00	0.7	13.2	1,839.2	0.7	1.3	1	1	1
09/20/2014 11:00	0.7	13.2	1,839.3	0.7	1.3	1	1	1
09/20/2014 12:00	0.7	13.1	1,842.8	0.7	1.3	1	1	1
09/20/2014 13:00	0.7	12.9	1,878.6	0.7	1.3	1	1	1
09/20/2014 14:00	0.7	12.9	1,887.2	0.7	1.3	1	1	1
09/20/2014 15:00	0.7	12.8	1,903.6	0.7	1.3	1	1	1
09/20/2014 16:00	0.7	13.1	1,855.2	0.7	1.3	1	1	1
09/20/2014 17:00	0.7	12.7	1,917.3	0.7	1.3	1	1	1
09/20/2014 18:00	0.7	12.7	1,927.9	0.7	1.3	1	1	1
09/20/2014 19:00	0.7	12.1	2,043.5	0.7	1.4	1	1	1
09/20/2014 20:00	0.7	13.0	1,870.8	0.7	1.3	1	1	1
09/20/2014 21:00	0.7	12.7	1,928.5	0.7	1.3	1	1	1
09/20/2014 22:00	0.7	13.2	1,846.4	0.7	1.3	1	1	1
09/20/2014 23:00	0.7	13.0	1,893.3	0.7	1.3	1	1	1
Average/Sum#:	0.7	12.8	1,923.4	0.7	1.3	24 #	24 #	24 #
Minimum:	0.7	11.8	1,839.2	0.7	1.3	1	1	1
Maximum:	0.7	13.2	2,125.5	0.7	1.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/21/2014 00:00	0.7	13.3	1,836.2	0.7	1.3	1	1	1
09/21/2014 01:00	0.7	13.3	1,835.6	0.7	1.3	1	1	1
09/21/2014 02:00	0.7	13.3	1,836.9	0.7	1.3	1	1	1
09/21/2014 03:00	0.7	13.3	1,834.8	0.7	1.3	1	1	1
09/21/2014 04:00	0.7	13.3	1,837.7	0.7	1.3	1	1	1
09/21/2014 05:00	0.7	13.3	1,837.9	0.7	1.3	1	1	1
09/21/2014 06:00	0.7	13.3	1,841.4	0.7	1.3	1	1	1
09/21/2014 07:00	0.7	13.3	1,846.5	0.7	1.3	1	1	1
09/21/2014 08:00	0.7	13.3	1,838.6	0.7	1.3	1	1	1
09/21/2014 09:00	0.7	13.3	1,836.7	0.7	1.3	1	1	1
09/21/2014 10:00	0.7	13.2	1,837.4	0.7	1.3	1	1	1
09/21/2014 11:00	0.7	13.2	1,719.9	0.7	1.2	1	1	1
09/21/2014 12:00	0.6	13.9	1,252.8	0.6	0.9	1	1	0
09/21/2014 13:00	0.6	13.9	1,244.6	0.6	0.9	1	1	0
09/21/2014 14:00	0.6	13.9	1,250.8	0.6	0.9	1	1	0
09/21/2014 15:00	0.6	13.9	1,261.7	0.6	0.9	1	1	0
09/21/2014 16:00	0.6	13.9	1,277.3	0.6	0.9	1	1	0
09/21/2014 17:00	0.7	13.5	1,701.1	0.7	1.2	1	1	1
09/21/2014 18:00	0.7	13.1	1,859.4	0.7	1.3	1	1	1
09/21/2014 19:00	0.7	12.9	1,907.6	0.7	1.3	1	1	1
09/21/2014 20:00	0.7	13.2	1,833.1	0.7	1.3	1	1	1
09/21/2014 21:00	0.7	13.2	1,832.7	0.7	1.3	1	1	1
09/21/2014 22:00	0.7	13.5	1,518.6	0.7	1.1	1	1	1
09/21/2014 23:00	0.6	13.8	1,244.1	0.6	0.9	1	1	0
Average/Sum#:	0.7	13.4	1,671.8	0.7	1.2	24 #	24 #	18 #
Minimum:	0.6	12.9	1,244.1	0.6	0.9	1	1	0
Maximum:	0.7	13.9	1,907.6	0.7	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/22/2014 00:00	0.6	13.8	1,244.2	0.6	0.9	1	1	0
09/22/2014 01:00	0.6	13.8	1,242.9	0.6	0.9	1	1	0
09/22/2014 02:00	0.6	13.8	1,271.7	0.6	0.9	1	1	0
09/22/2014 03:00	0.7	13.5	1,697.1	0.7	1.2	1	1	1
09/22/2014 04:00	0.7	13.3	1,850.1	0.7	1.3	1	1	1
09/22/2014 05:00	0.7	13.0	1,916.2	0.7	1.3	1	1	1
09/22/2014 06:00	0.7	12.5	2,016.7	0.7	1.4	1	1	1
09/22/2014 07:00	0.7	13.8	1,394.1	0.7	1.0	1	1	1
09/22/2014 08:00	0.6	13.8	1,276.4	0.6	0.9	1	1	0
09/22/2014 09:00	0.6	0.0	1,275.0	0.6	0.9	1	1	0
09/22/2014 10:00	0.6	0.0	1,287.8	0.6	0.9	1	1	0
09/22/2014 11:00	0.6	0.0	1,408.5	0.6	1.0	1	1	0
09/22/2014 12:00	0.6	0.0	1,724.1	0.6	1.2	1	1	0
09/22/2014 13:00	0.5	13.6	1,687.0	0.5	1.2	1	1	0
09/22/2014 14:00	0.5	13.6	1,726.9	0.5	1.2	1	1	0
09/22/2014 15:00	0.5	13.6	1,722.3	0.5	1.2	1	1	0
09/22/2014 16:00	0.5	13.6	1,722.1	0.5	1.2	1	1	0
09/22/2014 17:00	0.5	13.6	1,725.3	0.5	1.2	1	1	0
09/22/2014 18:00	0.5	13.6	1,730.8	0.5	1.2	1	1	0
09/22/2014 19:00	0.5	13.6	1,737.3	0.5	1.2	1	1	0
09/22/2014 20:00	0.5	13.6	1,736.3	0.5	1.2	1	1	0
09/22/2014 21:00	0.5	13.7	1,706.6	0.5	1.2	1	1	0
09/22/2014 22:00	0.5	13.8	1,544.3	0.5	1.1	1	1	0
09/22/2014 23:00	0.5	13.8	1,673.3	0.5	1.2	1	1	0
Average/Sum#:	0.6	13.6	1,596.5	0.6	1.1	24 #	24 #	5 #
Minimum:	0.5	12.5	1,242.9	0.5	0.9	1	1	0
Maximum:	0.7	13.8	2,016.7	0.7	1.4	1	1	1
%SI	16.7	16.7	0.0	16.7	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/23/2014 00:00	0.5	13.8	1,625.7	0.5	1.1	1	1	0
09/23/2014 01:00	0.5	13.8	1,589.9	0.5	1.1	1	1	0
09/23/2014 02:00	0.5	13.8	1,581.0	0.5	1.1	1	1	0
09/23/2014 03:00	0.5	13.7	1,695.5	0.5	1.2	1	1	0
09/23/2014 04:00	0.5	13.7	1,716.1	0.5	1.2	1	1	0
09/23/2014 05:00	0.5	13.7	1,720.3	0.5	1.2	1	1	0
09/23/2014 06:00	0.5	13.6	1,783.8	0.5	1.2	1	1	0
09/23/2014 07:00	0.5	13.8	1,680.2	0.5	1.2	1	1	0
09/23/2014 08:00	0.5	13.8	1,302.0	0.5	0.9	1	1	0
09/23/2014 09:00	0.5	13.8	1,283.9	0.5	0.9	1	1	0
09/23/2014 10:00	0.5	13.9	1,276.0	0.5	0.9	1	1	0
09/23/2014 11:00	0.6	13.9	1,461.2	0.6	1.0	1	1	0
09/23/2014 12:00	0.6	13.8	1,657.4	0.6	1.2	1	1	0
09/23/2014 13:00	0.5	13.8	1,642.1	0.5	1.1	1	1	0
09/23/2014 14:00	0.5	13.7	1,735.0	0.5	1.2	1	1	0
09/23/2014 15:00	0.5	13.7	1,734.7	0.5	1.2	1	1	0
09/23/2014 16:00	0.5	13.7	1,730.7	0.5	1.2	1	1	0
09/23/2014 17:00	0.5	13.7	1,733.8	0.5	1.2	1	1	0
09/23/2014 18:00	0.5	13.7	1,743.7	0.5	1.2	1	1	0
09/23/2014 19:00	0.5	13.7	1,749.9	0.5	1.2	1	1	0
09/23/2014 20:00	0.5	13.7	1,696.6	0.5	1.2	1	1	0
09/23/2014 21:00	0.5	13.6	1,755.0	0.5	1.2	1	1	0
09/23/2014 22:00	0.5	13.6	1,759.3	0.5	1.2	1	1	0
09/23/2014 23:00	0.5	13.6	1,772.4	0.5	1.2	1	1	0
Average/Sum#:	0.5	13.7	1,642.8	0.5	1.1	24 #	24 #	0 #
Minimum:	0.5	13.6	1,276.0	0.5	0.9	1	1	0
Maximum:	0.6	13.9	1,783.8	0.6	1.2	1	1	0
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/24/2014 00:00	0.5	13.6	1,779.3	0.5	1.2	1	1	0
09/24/2014 01:00	0.5	13.6	1,781.8	0.5	1.2	1	1	0
09/24/2014 02:00	0.5	13.6	1,781.6	0.5	1.2	1	1	0
09/24/2014 03:00	0.6	13.6	1,763.1	0.6	1.2	1	1	0
09/24/2014 04:00	0.5	13.6	1,743.7	0.5	1.2	1	1	0
09/24/2014 05:00	0.5	13.7	1,673.3	0.5	1.2	1	1	0
09/24/2014 06:00	0.6	13.6	1,775.0	0.6	1.2	1	1	0
09/24/2014 07:00	0.6	13.7	1,711.7	0.6	1.2	1	1	0
09/24/2014 08:00	0.6	13.8	1,596.6	0.6	1.1	1	1	0
09/24/2014 09:00	0.6	13.7	1,720.9	0.6	1.2	1	1	0
09/24/2014 10:00	0.6	13.6	1,758.6	0.6	1.2	1	1	0
09/24/2014 11:00	0.6	13.6	1,755.0	0.6	1.2	1	1	0
09/24/2014 12:00	0.6	13.6	1,748.9	0.6	1.2	1	1	0
09/24/2014 13:00	0.6	13.6	1,746.4	0.6	1.2	1	1	0
09/24/2014 14:00	0.6	13.7	1,747.5	0.6	1.2	1	1	0
09/24/2014 15:00	0.5	13.7	1,747.7	0.5	1.2	1	1	0
09/24/2014 16:00	0.5	13.7	1,743.8	0.5	1.2	1	1	0
09/24/2014 17:00	0.5	13.6	1,755.4	0.5	1.2	1	1	0
09/24/2014 18:00	0.6	13.6	1,762.4	0.6	1.2	1	1	0
09/24/2014 19:00	0.5	13.6	1,766.3	0.5	1.2	1	1	0
09/24/2014 20:00	0.6	13.6	1,773.8	0.6	1.2	1	1	0
09/24/2014 21:00	0.6	13.6	1,778.7	0.6	1.2	1	1	0
09/24/2014 22:00	0.6	13.6	1,782.1	0.6	1.2	1	1	0
09/24/2014 23:00	0.6	13.6	1,769.6	0.6	1.2	1	1	0
Average/Sum#:	0.6	13.6	1,748.5	0.6	1.2	24 #	24 #	0 #
Minimum:	0.5	13.6	1,596.6	0.5	1.1	1	1	0
Maximum:	0.6	13.8	1,782.1	0.6	1.2	1	1	0
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/25/2014 00:00	0.6	13.6	1,774.2	0.6	1.2	1	1	0
09/25/2014 01:00	0.6	13.6	1,772.1	0.6	1.2	1	1	0
09/25/2014 02:00	0.6	13.6	1,770.9	0.6	1.2	1	1	0
09/25/2014 03:00	0.6	13.7	1,730.2	0.6	1.2	1	1	0
09/25/2014 04:00	0.6	13.6	1,771.3	0.6	1.2	1	1	0
09/25/2014 05:00	0.6	13.7	1,738.4	0.6	1.2	1	1	0
09/25/2014 06:00	0.6	13.6	1,772.4	0.6	1.2	1	1	0
09/25/2014 07:00	0.6	13.7	1,748.3	0.6	1.2	1	1	0
09/25/2014 08:00	0.6	13.6	1,771.4	0.6	1.2	1	1	0
09/25/2014 09:00	0.6	13.6	1,767.9	0.6	1.2	1	1	0
09/25/2014 10:00	0.6	13.6	1,760.2	0.6	1.2	1	1	0
09/25/2014 11:00	0.6	13.6	1,785.0	0.6	1.2	1	1	0
09/25/2014 12:00	0.6	13.6	1,771.9	0.6	1.2	1	1	0
09/25/2014 13:00	-0.8	12.4	2,039.6	-0.4	1.4	1	1	1
09/25/2014 14:00	-0.2	11.9	2,141.5	0.1	1.5	1	1	1
09/25/2014 15:00	0.1	11.6	2,179.6	0.2	1.5	1	1	1
09/25/2014 16:00	0.1	12.8	1,944.2	0.2	1.4	1	1	1
09/25/2014 17:00	-0.2	12.5	2,022.8	0.1	1.4	1	1	1
09/25/2014 18:00	-0.2	12.4	2,060.4	0.1	1.4	1	1	1
09/25/2014 19:00	-0.1	12.3	2,070.5	0.2	1.4	1	1	1
09/25/2014 20:00	0.1	13.0	1,933.0	0.2	1.4	1	1	1
09/25/2014 21:00	0.1	13.1	1,897.7	0.2	1.3	1	1	1
09/25/2014 22:00	-0.1	12.9	1,936.8	0.1	1.4	1	1	1
09/25/2014 23:00	-0.2	12.4	2,040.6	0.1	1.4	1	1	1
Average/Sum#:	0.3	13.1	1,883.4	0.4	1.3	24 #	24 #	11 #
Minimum:	-0.8	11.6	1,730.2	-0.4	1.2	1	1	0
Maximum:	0.6	13.7	2,179.6	0.6	1.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/26/2014 00:00	0.1	12.9	1,940.1	0.2	1.4	1	1	1
09/26/2014 01:00	-0.1	12.9	1,953.3	0.1	1.4	1	1	1
09/26/2014 02:00	0.1	13.1	1,897.5	0.2	1.3	1	1	1
09/26/2014 03:00	-0.1	13.0	1,923.3	0.1	1.3	1	1	1
09/26/2014 04:00	-0.2	11.9	2,160.7	0.1	1.5	1	1	1
09/26/2014 05:00	-0.1	11.8	2,182.9	0.2	1.5	1	1	1
09/26/2014 06:00	-0.1	11.7	2,198.7	0.2	1.5	1	1	1
09/26/2014 07:00	-0.1	12.5	2,045.1	0.1	1.4	1	1	1
09/26/2014 08:00	0.2	13.3	1,870.5	0.4	1.3	1	1	1
09/26/2014 09:00	-0.2	12.8	1,983.2	0.1	1.4	1	1	1
09/26/2014 10:00	-0.2	12.6	2,011.4	0.1	1.4	1	1	1
09/26/2014 11:00	-0.1	12.8	1,963.7	0.1	1.4	1	1	1
09/26/2014 12:00	0.2	13.2	1,884.8	0.4	1.3	1	1	1
09/26/2014 13:00	0.1	13.3	1,857.2	0.2	1.3	1	1	1
09/26/2014 14:00	0.1	13.3	1,860.5	0.2	1.3	1	1	1
09/26/2014 15:00	0.1	13.3	1,853.7	0.2	1.3	1	1	1
09/26/2014 16:00	0.1	13.3	1,855.4	0.2	1.3	1	1	1
09/26/2014 17:00	-0.1	13.0	1,922.9	0.1	1.3	1	1	1
09/26/2014 18:00	-0.1	13.1	1,895.7	0.1	1.3	1	1	1
09/26/2014 19:00	0.1	13.3	1,860.5	0.2	1.3	1	1	1
09/26/2014 20:00	0.1	13.3	1,863.5	0.2	1.3	1	1	1
09/26/2014 21:00	-0.1	13.1	1,916.0	0.1	1.3	1	1	1
09/26/2014 22:00	0.1	13.2	1,887.0	0.2	1.3	1	1	1
09/26/2014 23:00	-0.4	12.6	2,023.7	-0.1	1.4	1	1	1
Average/Sum#:	0.0	12.9	1,950.5	0.2	1.4	24 #	24 #	24 #
Minimum:	-0.4	11.7	1,853.7	-0.1	1.3	1	1	1
Maximum:	0.2	13.3	2,198.7	0.4	1.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/27/2014 00:00	-0.4	12.5	2,052.4	-0.1	1.4	1	1	1
09/27/2014 01:00	-0.2	12.1	2,120.7	0.1	1.5	1	1	1
09/27/2014 02:00	-0.1	12.9	1,960.0	0.1	1.4	1	1	1
09/27/2014 03:00	0.1	13.1	1,915.3	0.2	1.3	1	1	1
09/27/2014 04:00	0.1	13.2	1,889.8	0.2	1.3	1	1	1
09/27/2014 05:00	0.1	13.1	1,906.6	0.2	1.3	1	1	1
09/27/2014 06:00	0.1	13.1	1,889.6	0.2	1.3	1	1	1
09/27/2014 07:00	0.5	13.7	1,592.0	0.5	1.1	1	1	1
09/27/2014 08:00	0.6	13.8	1,269.2	0.6	0.9	1	1	0
09/27/2014 09:00	0.6	13.9	1,345.4	0.6	0.9	1	1	0
09/27/2014 10:00	0.6	13.9	1,281.8	0.6	0.9	1	1	0
09/27/2014 11:00	0.6	13.9	1,254.6	0.6	0.9	1	1	0
09/27/2014 12:00	0.6	13.9	1,253.0	0.6	0.9	1	1	0
09/27/2014 13:00	0.6	13.9	1,253.6	0.6	0.9	1	1	0
09/27/2014 14:00	0.6	13.9	1,253.4	0.6	0.9	1	1	0
09/27/2014 15:00	0.6	13.9	1,250.6	0.6	0.9	1	1	0
09/27/2014 16:00	0.6	13.9	1,247.9	0.6	0.9	1	1	0
09/27/2014 17:00	0.2	13.5	1,608.2	0.4	1.1	1	1	1
09/27/2014 18:00	-0.2	11.8	2,150.9	0.1	1.5	1	1	1
09/27/2014 19:00	-0.1	12.7	1,949.9	0.1	1.4	1	1	1
09/27/2014 20:00	-0.2	13.1	1,895.1	-0.1	1.3	1	1	1
09/27/2014 21:00	-0.2	12.8	1,948.2	0.1	1.4	1	1	1
09/27/2014 22:00	-0.4	13.4	1,827.1	-0.2	1.3	1	1	1
09/27/2014 23:00	-0.8	13.4	1,856.5	-0.5	1.3	1	1	1
Average/Sum#:	0.2	13.3	1,665.5	0.3	1.2	24 #	24 #	15 #
Minimum:	-0.8	11.8	1,247.9	-0.5	0.9	1	1	0
Maximum:	0.6	13.9	2,150.9	0.6	1.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/28/2014 00:00	0.2	13.5	1,461.9	0.4	1.0	1	1	1
09/28/2014 01:00	0.6	13.9	1,251.2	0.6	0.9	1	1	0
09/28/2014 02:00	0.6	13.9	1,249.5	0.6	0.9	1	1	0
09/28/2014 03:00	0.5	13.9	1,518.4	0.5	1.1	1	1	0
09/28/2014 04:00	0.1	13.3	1,841.0	0.2	1.3	1	1	1
09/28/2014 05:00	-0.4	12.8	1,973.4	-0.1	1.4	1	1	1
09/28/2014 06:00	-0.4	12.6	2,002.2	-0.1	1.4	1	1	1
09/28/2014 07:00	0.1	13.3	1,862.7	0.2	1.3	1	1	1
09/28/2014 08:00	-0.1	13.1	1,881.7	0.1	1.3	1	1	1
09/28/2014 09:00	0.5	13.8	1,308.0	0.5	0.9	1	1	1
09/28/2014 10:00	0.5	13.8	1,252.5	0.5	0.9	1	1	0
09/28/2014 11:00	0.4	13.6	1,541.8	0.4	1.1	1	1	1
09/28/2014 12:00	0.1	13.3	1,839.6	0.2	1.3	1	1	1
09/28/2014 13:00	0.1	13.3	1,838.8	0.2	1.3	1	1	1
09/28/2014 14:00	0.1	13.3	1,838.9	0.2	1.3	1	1	1
09/28/2014 15:00	0.1	13.3	1,844.4	0.2	1.3	1	1	1
09/28/2014 16:00	-0.2	13.0	1,931.8	0.1	1.4	1	1	1
09/28/2014 17:00	-0.4	12.3	2,063.6	-0.1	1.4	1	1	1
09/28/2014 18:00	-0.1	11.4	2,244.6	0.2	1.6	1	1	1
09/28/2014 19:00	0.1	11.4	2,256.2	0.4	1.6	1	1	1
09/28/2014 20:00	-0.1	12.6	1,994.4	0.1	1.4	1	1	1
09/28/2014 21:00	-0.2	12.9	1,947.2	0.1	1.4	1	1	1
09/28/2014 22:00	-0.1	13.0	1,935.2	0.1	1.4	1	1	1
09/28/2014 23:00	-0.4	13.4	1,853.4	-0.2	1.3	1	1	1
Average/Sum#:	0.1	13.1	1,780.5	0.2	1.3	24 #	24 #	20 #
Minimum:	-0.4	11.4	1,249.5	-0.2	0.9	1	1	0
Maximum:	0.6	13.9	2,256.2	0.6	1.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/29/2014 00:00	-0.8	13.5	1,835.3	-0.5	1.3	1	1	1
09/29/2014 01:00	-0.9	13.5	1,836.5	-0.7	1.3	1	1	1
09/29/2014 02:00	-0.9	13.5	1,836.7	-0.7	1.3	1	1	1
09/29/2014 03:00	-0.9	13.5	1,836.2	-0.7	1.3	1	1	1
09/29/2014 04:00	-0.2	13.4	1,857.5	-0.1	1.3	1	1	1
09/29/2014 05:00	0.1	13.3	1,866.0	0.2	1.3	1	1	1
09/29/2014 06:00	-0.4	12.7	1,988.3	-0.1	1.4	1	1	1
09/29/2014 07:00	0.1	13.3	1,840.3	0.2	1.3	1	1	1
09/29/2014 08:00	0.1	13.3	1,839.3	0.2	1.3	1	1	1
09/29/2014 09:00	0.1	13.3	1,847.0	0.2	1.3	1	1	1
09/29/2014 10:00	0.1	13.2	1,855.3	0.2	1.3	1	1	1
09/29/2014 11:00	0.1	13.2	1,853.2	0.2	1.3	1	1	1
09/29/2014 12:00	0.5	13.8	1,283.9	0.5	0.9	1	1	0
09/29/2014 13:00	0.6	13.9	1,252.4	0.6	0.9	1	1	0
09/29/2014 14:00	0.4	13.6	1,519.0	0.4	1.1	1	1	1
09/29/2014 15:00	0.1	13.2	1,842.3	0.2	1.3	1	1	1
09/29/2014 16:00	-0.1	13.0	1,896.4	0.1	1.3	1	1	1
09/29/2014 17:00	-0.4	12.6	1,971.9	-0.1	1.4	1	1	1
09/29/2014 18:00	-0.4	11.8	2,141.2	-0.1	1.5	1	1	1
09/29/2014 19:00	-0.1	12.0	2,097.7	0.2	1.5	1	1	1
09/29/2014 20:00	-0.2	12.9	1,925.0	0.1	1.3	1	1	1
09/29/2014 21:00	0.1	13.3	1,715.2	0.2	1.2	1	1	1
09/29/2014 22:00	0.5	13.9	1,264.3	0.5	0.9	1	1	0
09/29/2014 23:00	0.5	13.8	1,298.1	0.5	0.9	1	1	0
Average/Sum#:	-0.1	13.2	1,770.8	0.1	1.2	24 #	24 #	20 #
Minimum:	-0.9	11.8	1,252.4	-0.7	0.9	1	1	0
Maximum:	0.6	13.9	2,141.2	0.6	1.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 VOC, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 VOC, Ppmvdc 1 Hour(s)	Unit CT1 VOC, LbPerHr 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/30/2014 00:00	0.5	13.8	1,252.5	0.5	0.9	1	1	0
09/30/2014 01:00	0.5	13.8	1,253.2	0.5	0.9	1	1	0
09/30/2014 02:00	0.4	13.8	1,253.6	0.4	0.9	1	1	0
09/30/2014 03:00	0.4	13.8	1,254.3	0.4	0.9	1	1	0
09/30/2014 04:00	0.4	13.8	1,376.5	0.4	1.0	1	1	0
09/30/2014 05:00	0.1	13.4	1,647.5	0.2	1.2	1	1	1
09/30/2014 06:00	0.1	13.2	1,879.9	0.2	1.3	1	1	1
09/30/2014 07:00	-0.1	13.3	1,851.9	0.1	1.3	1	1	1
09/30/2014 08:00	0.1	13.3	1,852.8	0.2	1.3	1	1	1
09/30/2014 09:00	0.1	13.2	1,851.7	0.2	1.3	1	1	1
09/30/2014 10:00	0.5	13.9	1,255.1	0.5	0.9	1	1	0
09/30/2014 11:00	0.6	13.9	1,251.9	0.6	0.9	1	1	0
09/30/2014 12:00	0.4	13.6	1,635.7	0.4	1.1	1	1	1
09/30/2014 13:00	0.1	13.3	1,848.7	0.2	1.3	1	1	1
09/30/2014 14:00	0.1	13.3	1,850.7	0.2	1.3	1	1	1
09/30/2014 15:00	0.1	13.3	1,855.8	0.2	1.3	1	1	1
09/30/2014 16:00	0.1	13.2	1,870.7	0.2	1.3	1	1	1
09/30/2014 17:00	0.1	13.3	1,860.5	0.2	1.3	1	1	1
09/30/2014 18:00	-0.2	12.6	2,006.2	0.1	1.4	1	1	1
09/30/2014 19:00	-0.2	12.2	2,076.5	0.1	1.5	1	1	1
09/30/2014 20:00	-0.1	13.4	1,857.5	0.1	1.3	1	1	1
09/30/2014 21:00	-0.1	13.7	1,468.2	0.1	1.0	1	1	1
09/30/2014 22:00	0.6	13.9	1,256.7	0.6	0.9	1	1	0
09/30/2014 23:00	0.6	13.9	1,254.7	0.6	0.9	1	1	0
Average/Sum#:	0.2	13.5	1,617.6	0.3	1.1	24 #	24 #	15 #
Minimum:	-0.2	12.2	1,251.9	0.1	0.9	1	1	0
Maximum:	0.6	13.9	2,076.5	0.6	1.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/01/2014 00:00	0.4	13.0	1,860.8	0.5	0.6	1	1	1
07/01/2014 01:00	0.5	13.5	1,578.8	0.5	0.5	1	1	1
07/01/2014 02:00	0.5	13.3	1,567.0	0.5	0.5	1	1	1
07/01/2014 03:00	0.6	13.7	1,246.5	0.6	0.4	1	1	0
07/01/2014 04:00	0.6	13.7	1,287.7	0.6	0.4	1	1	0
07/01/2014 05:00	0.5	13.4	1,558.6	0.5	0.5	1	1	1
07/01/2014 06:00	0.4	13.0	1,909.5	0.5	0.6	1	1	1
07/01/2014 07:00	0.4	12.9	1,896.3	0.5	0.6	1	1	1
07/01/2014 08:00	0.4	12.8	1,921.0	0.5	0.6	1	1	1
07/01/2014 09:00	0.4	12.7	1,924.7	0.5	0.6	1	1	1
07/01/2014 10:00	0.4	12.8	1,892.1	0.5	0.6	1	1	1
07/01/2014 11:00	0.4	12.8	1,881.9	0.5	0.6	1	1	1
07/01/2014 12:00	0.4	12.8	1,890.0	0.5	0.6	1	1	1
07/01/2014 13:00	0.4	12.7	1,900.9	0.5	0.6	1	1	1
07/01/2014 14:00	0.4	12.7	1,913.0	0.5	0.6	1	1	1
07/01/2014 15:00	0.4	12.6	1,925.7	0.5	0.6	1	1	1
07/01/2014 16:00	0.4	12.0	2,043.1	0.5	0.6	1	1	1
07/01/2014 17:00	0.5	11.7	2,135.1	0.5	0.6	1	1	1
07/01/2014 18:00	0.5	11.7	2,119.9	0.5	0.6	1	1	1
07/01/2014 19:00	0.5	12.8	1,894.4	0.5	0.6	1	1	1
07/01/2014 20:00	0.5	12.9	1,879.9	0.5	0.6	1	1	1
07/01/2014 21:00	0.5	13.0	1,864.0	0.5	0.6	1	1	1
07/01/2014 22:00	0.4	13.0	1,863.6	0.5	0.6	1	1	1
07/01/2014 23:00	0.4	13.1	1,862.5	0.4	0.6	1	1	1
Average/Sum#:	0.5	12.9	1,825.7	0.5	0.6	24 #	24 #	22 #
Minimum:	0.4	11.7	1,246.5	0.4	0.4	1	1	0
Maximum:	0.6	13.7	2,135.1	0.6	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/02/2014 00:00	0.4	13.1	1,863.8	0.4	0.6	1	1	1
07/02/2014 01:00	0.4	13.1	1,864.1	0.4	0.6	1	1	1
07/02/2014 02:00	0.4	13.1	1,862.8	0.4	0.6	1	1	1
07/02/2014 03:00	0.4	13.1	1,863.9	0.4	0.6	1	1	1
07/02/2014 04:00	0.4	12.9	1,928.5	0.5	0.6	1	1	1
07/02/2014 05:00	0.4	12.3	2,082.0	0.5	0.6	1	1	1
07/02/2014 06:00	0.4	12.7	2,013.3	0.5	0.6	1	1	1
07/02/2014 07:00	0.5	13.0	1,897.3	0.5	0.6	1	1	1
07/02/2014 08:00	0.5	13.0	1,893.5	0.5	0.6	1	1	1
07/02/2014 09:00	0.5	13.0	1,893.5	0.5	0.6	1	1	1
07/02/2014 10:00	0.4	13.0	1,891.2	0.5	0.6	1	1	1
07/02/2014 11:00	0.4	12.9	1,894.7	0.5	0.6	1	1	1
07/02/2014 12:00	0.4	12.8	1,894.9	0.5	0.6	1	1	1
07/02/2014 13:00	0.4	12.8	1,897.7	0.5	0.6	1	1	1
07/02/2014 14:00	0.4	12.2	2,025.7	0.5	0.6	1	1	1
07/02/2014 15:00	0.5	11.7	2,142.1	0.5	0.6	1	1	1
07/02/2014 16:00	0.4	12.1	2,037.6	0.5	0.6	1	1	1
07/02/2014 17:00	0.4	12.4	1,976.1	0.5	0.6	1	1	1
07/02/2014 18:00	0.4	12.3	1,989.8	0.5	0.6	1	1	1
07/02/2014 19:00	0.4	12.5	1,966.6	0.5	0.6	1	1	1
07/02/2014 20:00	0.4	12.5	1,965.4	0.5	0.6	1	1	1
07/02/2014 21:00	0.7	13.6	1,331.9	0.7	0.4	1	1	1
07/02/2014 22:00	0.0	15.9	443.7	0.0	0.1	1	0	0
07/02/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.4	12.9	1,853.0	0.5	0.6	23 #	22 #	22 #
Minimum:	0.0	11.7	443.7	0.0	0.1	0	0	0
Maximum:	0.7	15.9	2,142.1	0.7	0.6	1	1	1
%SI	4.2	4.2	4.2	4.2	4.2	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/03/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2014 07:00	0.0	16.9	529.2	0.0	0.2	1	0	0
07/03/2014 08:00	0.0	13.9	1,421.5	0.0	0.4	1	0	0
07/03/2014 09:00	0.4	13.0	1,885.3	0.5	0.6	1	1	1
07/03/2014 10:00	0.5	12.9	1,891.5	0.5	0.6	1	1	1
07/03/2014 11:00	0.4	12.8	1,918.0	0.5	0.6	1	1	1
07/03/2014 12:00	0.4	12.4	1,975.5	0.5	0.6	1	1	1
07/03/2014 13:00	0.5	11.8	2,109.6	0.5	0.6	1	1	1
07/03/2014 14:00	0.5	11.6	2,140.1	0.5	0.6	1	1	1
07/03/2014 15:00	0.5	11.6	2,157.5	0.5	0.6	1	1	1
07/03/2014 16:00	0.7	11.6	2,156.9	0.7	0.6	1	1	1
07/03/2014 17:00	0.7	11.5	2,155.8	0.7	0.6	1	1	1
07/03/2014 18:00	0.7	11.4	2,181.6	0.7	0.7	1	1	1
07/03/2014 19:00	0.5	11.4	2,179.4	0.5	0.7	1	1	1
07/03/2014 20:00	0.5	12.0	2,071.2	0.5	0.6	1	1	1
07/03/2014 21:00	0.4	12.3	2,002.3	0.5	0.6	1	1	1
07/03/2014 22:00	0.4	12.3	2,035.9	0.5	0.6	1	1	1
07/03/2014 23:00	0.7	11.5	2,207.6	0.7	0.7	1	1	1
Average/Sum#:	0.5	12.4	1,942.3	0.5	0.6	17 #	15 #	15 #
Minimum:	0.0	11.4	529.2	0.0	0.2	0	0	0
Maximum:	0.7	16.9	2,207.6	0.7	0.7	1	1	1
%SI	29.2	29.2	29.2	29.2	29.2	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/04/2014 00:00	0.5	12.4	2,013.9	0.5	0.6	1	1	1
07/04/2014 01:00	0.4	12.7	1,966.5	0.5	0.6	1	1	1
07/04/2014 02:00	0.5	13.0	1,900.7	0.5	0.6	1	1	1
07/04/2014 03:00	0.5	13.1	1,863.3	0.5	0.6	1	1	1
07/04/2014 04:00	0.5	13.0	1,905.5	0.5	0.6	1	1	1
07/04/2014 05:00	0.5	13.1	1,895.4	0.5	0.6	1	1	1
07/04/2014 06:00	0.5	13.0	1,893.5	0.5	0.6	1	1	1
07/04/2014 07:00	0.5	13.0	1,892.3	0.5	0.6	1	1	1
07/04/2014 08:00	0.4	12.7	1,953.5	0.5	0.6	1	1	1
07/04/2014 09:00	0.4	12.6	1,960.8	0.5	0.6	1	1	1
07/04/2014 10:00	0.4	12.5	1,993.9	0.5	0.6	1	1	1
07/04/2014 11:00	0.5	11.4	2,219.1	0.5	0.7	1	1	1
07/04/2014 12:00	0.5	11.9	2,099.7	0.5	0.6	1	1	1
07/04/2014 13:00	0.5	12.6	1,939.8	0.5	0.6	1	1	1
07/04/2014 14:00	0.4	12.5	1,954.0	0.5	0.6	1	1	1
07/04/2014 15:00	0.4	12.5	1,965.8	0.5	0.6	1	1	1
07/04/2014 16:00	0.4	12.4	1,997.7	0.5	0.6	1	1	1
07/04/2014 17:00	0.5	12.4	1,998.3	0.5	0.6	1	1	1
07/04/2014 18:00	0.7	13.5	1,484.7	0.7	0.4	1	1	1
07/04/2014 19:00	0.6	13.8	1,292.1	0.6	0.4	1	1	0
07/04/2014 20:00	0.0	14.6	973.1	0.0	0.3	1	0	0
07/04/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.5	12.8	1,864.9	0.5	0.6	21 #	20 #	19 #
Minimum:	0.0	11.4	973.1	0.0	0.3	0	0	0
Maximum:	0.7	14.6	2,219.1	0.7	0.7	1	1	1
%SI	12.5	12.5	12.5	12.5	12.5	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/05/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2014 10:00	0.0	17.4	454.2	0.0	0.1	1	0	0
07/05/2014 11:00	0.0	14.6	1,176.0	0.0	0.4	1	0	0
07/05/2014 12:00	0.4	12.7	1,934.1	0.5	0.6	1	1	1
07/05/2014 13:00	0.5	12.0	2,089.9	0.5	0.6	1	1	1
07/05/2014 14:00	0.5	12.7	1,937.1	0.5	0.6	1	1	1
07/05/2014 15:00	0.4	12.6	1,931.5	0.5	0.6	1	1	1
07/05/2014 16:00	0.4	12.5	1,958.7	0.5	0.6	1	1	1
07/05/2014 17:00	0.4	12.4	1,985.1	0.5	0.6	1	1	1
07/05/2014 18:00	0.4	12.5	1,941.2	0.5	0.6	1	1	1
07/05/2014 19:00	0.5	12.8	1,885.9	0.5	0.6	1	1	1
07/05/2014 20:00	0.5	12.9	1,879.7	0.5	0.6	1	1	1
07/05/2014 21:00	0.5	13.0	1,879.0	0.5	0.6	1	1	1
07/05/2014 22:00	0.7	13.5	1,547.7	0.7	0.5	1	1	1
07/05/2014 23:00	0.6	13.5	1,768.2	0.6	0.5	1	1	0
Average/Sum#:	0.4	13.2	1,740.6	0.5	0.5	14 #	12 #	11 #
Minimum:	0.0	12.0	454.2	0.0	0.1	0	0	0
Maximum:	0.7	17.4	2,089.9	0.7	0.6	1	1	1
%SI	41.7	41.7	41.7	41.7	41.7	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/06/2014 00:00	0.6	13.5	1,777.0	0.6	0.5	1	1	0
07/06/2014 01:00	0.6	13.6	1,498.4	0.6	0.4	1	1	0
07/06/2014 02:00	0.0	15.8	538.4	0.0	0.2	1	0	0
07/06/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2014 09:00	0.0	18.2	334.7	0.0	0.1	1	0	0
07/06/2014 10:00	0.0	15.2	900.2	0.0	0.3	1	0	0
07/06/2014 11:00	0.5	13.2	1,762.7	0.5	0.5	1	1	1
07/06/2014 12:00	0.4	12.8	1,926.6	0.5	0.6	1	1	1
07/06/2014 13:00	0.5	12.9	1,894.7	0.5	0.6	1	1	1
07/06/2014 14:00	0.5	12.9	1,895.9	0.5	0.6	1	1	1
07/06/2014 15:00	0.5	12.9	1,894.5	0.5	0.6	1	1	1
07/06/2014 16:00	0.4	12.7	1,927.7	0.5	0.6	1	1	1
07/06/2014 17:00	0.4	12.1	2,060.6	0.5	0.6	1	1	1
07/06/2014 18:00	0.5	11.7	2,138.7	0.5	0.6	1	1	1
07/06/2014 19:00	0.4	12.1	2,067.9	0.5	0.6	1	1	1
07/06/2014 20:00	0.5	12.0	2,085.3	0.5	0.6	1	1	1
07/06/2014 21:00	0.5	12.8	1,903.2	0.5	0.6	1	1	1
07/06/2014 22:00	0.4	12.9	1,873.1	0.5	0.6	1	1	1
07/06/2014 23:00	0.4	13.0	1,852.8	0.5	0.6	1	1	1
Average/Sum#:	0.4	13.4	1,685.1	0.4	0.5	18 #	15 #	13 #
Minimum:	0.0	11.7	334.7	0.0	0.1	0	0	0
Maximum:	0.6	18.2	2,138.7	0.6	0.6	1	1	1
%SI	25.0	25.0	25.0	25.0	25.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/07/2014 00:00	0.6	13.7	1,279.5	0.6	0.4	1	1	0
07/07/2014 01:00	0.6	13.7	1,257.0	0.6	0.4	1	1	0
07/07/2014 02:00	0.6	13.8	1,285.4	0.6	0.4	1	1	0
07/07/2014 03:00	0.6	13.8	1,337.3	0.6	0.4	1	1	0
07/07/2014 04:00	0.5	13.4	1,796.1	0.5	0.5	1	1	1
07/07/2014 05:00	0.4	13.1	1,879.8	0.4	0.6	1	1	1
07/07/2014 06:00	0.4	13.1	1,861.6	0.4	0.6	1	1	1
07/07/2014 07:00	0.4	13.1	1,861.1	0.4	0.6	1	1	1
07/07/2014 08:00	0.4	13.0	1,879.7	0.5	0.6	1	1	1
07/07/2014 09:00	0.5	13.0	1,871.9	0.5	0.6	1	1	1
07/07/2014 10:00	0.5	12.9	1,891.0	0.5	0.6	1	1	1
07/07/2014 11:00	0.5	12.9	1,883.2	0.5	0.6	1	1	1
07/07/2014 12:00	0.5	12.9	1,887.0	0.5	0.6	1	1	1
07/07/2014 13:00	0.5	12.8	1,889.3	0.5	0.6	1	1	1
07/07/2014 14:00	0.5	12.9	1,883.5	0.5	0.6	1	1	1
07/07/2014 15:00	0.4	12.8	1,881.0	0.5	0.6	1	1	1
07/07/2014 16:00	0.4	12.8	1,883.9	0.5	0.6	1	1	1
07/07/2014 17:00	0.4	12.7	1,894.4	0.5	0.6	1	1	1
07/07/2014 18:00	0.4	12.7	1,899.3	0.5	0.6	1	1	1
07/07/2014 19:00	0.4	12.7	1,914.0	0.5	0.6	1	1	1
07/07/2014 20:00	0.5	12.9	1,869.9	0.5	0.6	1	1	1
07/07/2014 21:00	0.5	13.0	1,855.9	0.5	0.6	1	1	1
07/07/2014 22:00	0.5	13.1	1,683.9	0.5	0.5	1	1	1
07/07/2014 23:00	0.4	13.1	1,843.5	0.4	0.6	1	1	1
Average/Sum#:	0.5	13.1	1,769.6	0.5	0.6	24 #	24 #	20 #
Minimum:	0.4	12.7	1,257.0	0.4	0.4	1	1	0
Maximum:	0.6	13.8	1,914.0	0.6	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/08/2014 00:00	0.2	12.9	1,887.5	0.4	0.6	1	1	1
07/08/2014 01:00	0.4	13.0	1,868.4	0.5	0.6	1	1	1
07/08/2014 02:00	0.5	13.0	1,865.2	0.5	0.6	1	1	1
07/08/2014 03:00	0.4	13.2	1,736.0	0.4	0.5	1	1	1
07/08/2014 04:00	0.2	12.7	1,925.6	0.4	0.6	1	1	1
07/08/2014 05:00	0.4	13.0	1,875.0	0.5	0.6	1	1	1
07/08/2014 06:00	0.2	12.6	1,941.7	0.4	0.6	1	1	1
07/08/2014 07:00	0.4	12.9	1,879.4	0.5	0.6	1	1	1
07/08/2014 08:00	0.4	12.8	1,893.6	0.5	0.6	1	1	1
07/08/2014 09:00	0.4	12.9	1,875.1	0.5	0.6	1	1	1
07/08/2014 10:00	0.4	12.6	1,953.2	0.5	0.6	1	1	1
07/08/2014 11:00	0.4	12.5	1,950.7	0.5	0.6	1	1	1
07/08/2014 12:00	0.4	12.0	2,083.8	0.5	0.6	1	1	1
07/08/2014 13:00	0.7	11.3	2,220.9	0.7	0.7	1	1	1
07/08/2014 14:00	0.5	11.5	2,154.8	0.5	0.6	1	1	1
07/08/2014 15:00	0.7	11.5	2,147.4	0.7	0.6	1	1	1
07/08/2014 16:00	0.7	11.5	2,154.2	0.7	0.6	1	1	1
07/08/2014 17:00	0.7	11.6	2,151.6	0.7	0.6	1	1	1
07/08/2014 18:00	0.5	11.9	2,087.2	0.5	0.6	1	1	1
07/08/2014 19:00	0.4	12.3	1,993.3	0.5	0.6	1	1	1
07/08/2014 20:00	0.5	12.8	1,885.5	0.5	0.6	1	1	1
07/08/2014 21:00	0.5	13.0	1,863.9	0.5	0.6	1	1	1
07/08/2014 22:00	0.7	13.5	1,489.9	0.7	0.4	1	1	1
07/08/2014 23:00	0.6	13.7	1,386.8	0.6	0.4	1	1	0
Average/Sum#:	0.5	12.5	1,927.9	0.5	0.6	24 #	24 #	23 #
Minimum:	0.2	11.3	1,386.8	0.4	0.4	1	1	0
Maximum:	0.7	13.7	2,220.9	0.7	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/09/2014 00:00	0.6	13.7	1,250.4	0.6	0.4	1	1	0
07/09/2014 01:00	0.6	13.7	1,248.5	0.6	0.4	1	1	0
07/09/2014 02:00	0.6	13.7	1,248.3	0.6	0.4	1	1	0
07/09/2014 03:00	0.6	13.7	1,248.5	0.6	0.4	1	1	0
07/09/2014 04:00	0.6	13.7	1,258.5	0.6	0.4	1	1	0
07/09/2014 05:00	0.5	13.7	1,543.7	0.5	0.5	1	1	0
07/09/2014 06:00	0.5	13.3	1,644.5	0.5	0.5	1	1	1
07/09/2014 07:00	0.2	12.6	1,972.8	0.4	0.6	1	1	1
07/09/2014 08:00	0.4	12.7	1,951.1	0.5	0.6	1	1	1
07/09/2014 09:00	0.4	12.4	2,010.5	0.5	0.6	1	1	1
07/09/2014 10:00	0.5	11.9	2,108.4	0.5	0.6	1	1	1
07/09/2014 11:00	0.5	11.6	2,171.2	0.5	0.7	1	1	1
07/09/2014 12:00	0.5	11.4	2,186.0	0.5	0.7	1	1	1
07/09/2014 13:00	0.5	11.5	2,159.5	0.5	0.6	1	1	1
07/09/2014 14:00	0.5	12.1	2,026.1	0.5	0.6	1	1	1
07/09/2014 15:00	0.5	11.9	2,097.3	0.5	0.6	1	1	1
07/09/2014 16:00	0.5	11.6	2,138.0	0.5	0.6	1	1	1
07/09/2014 17:00	0.7	11.6	2,135.1	0.7	0.6	1	1	1
07/09/2014 18:00	0.5	12.0	2,041.9	0.5	0.6	1	1	1
07/09/2014 19:00	0.4	12.4	1,970.8	0.5	0.6	1	1	1
07/09/2014 20:00	0.4	12.4	1,984.1	0.5	0.6	1	1	1
07/09/2014 21:00	0.4	12.5	1,956.7	0.5	0.6	1	1	1
07/09/2014 22:00	0.4	12.7	1,936.5	0.5	0.6	1	1	1
07/09/2014 23:00	0.7	13.4	1,457.2	0.7	0.4	1	1	1
Average/Sum#:	0.5	12.6	1,822.7	0.5	0.6	24 #	24 #	18 #
Minimum:	0.2	11.4	1,248.3	0.4	0.4	1	1	0
Maximum:	0.7	13.7	2,186.0	0.7	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/10/2014 00:00	0.6	13.7	1,244.7	0.6	0.4	1	1	0
07/10/2014 01:00	0.6	13.7	1,244.4	0.6	0.4	1	1	0
07/10/2014 02:00	0.6	13.7	1,244.9	0.6	0.4	1	1	0
07/10/2014 03:00	0.6	13.7	1,244.3	0.6	0.4	1	1	0
07/10/2014 04:00	0.6	13.7	1,244.9	0.6	0.4	1	1	0
07/10/2014 05:00	0.6	13.7	1,246.6	0.6	0.4	1	1	0
07/10/2014 06:00	0.6	13.7	1,247.9	0.6	0.4	1	1	0
07/10/2014 07:00	0.6	13.7	1,253.8	0.6	0.4	1	1	0
07/10/2014 08:00	0.6	13.7	1,264.1	0.6	0.4	1	1	0
07/10/2014 09:00	0.5	13.4	1,565.2	0.5	0.5	1	1	1
07/10/2014 10:00	0.4	13.0	1,863.4	0.5	0.6	1	1	1
07/10/2014 11:00	0.4	13.0	1,863.7	0.5	0.6	1	1	1
07/10/2014 12:00	0.5	12.9	1,885.9	0.5	0.6	1	1	1
07/10/2014 13:00	0.4	12.8	1,895.8	0.5	0.6	1	1	1
07/10/2014 14:00	0.2	12.8	1,897.5	0.4	0.6	1	1	1
07/10/2014 15:00	0.2	12.7	1,910.4	0.4	0.6	1	1	1
07/10/2014 16:00	0.2	12.4	1,969.0	0.4	0.6	1	1	1
07/10/2014 17:00	0.2	12.6	1,928.3	0.4	0.6	1	1	1
07/10/2014 18:00	-0.2	12.4	1,974.3	0.1	0.6	1	1	1
07/10/2014 19:00	0.1	12.9	1,874.5	0.2	0.6	1	1	1
07/10/2014 20:00	0.2	13.0	1,867.6	0.4	0.6	1	1	1
07/10/2014 21:00	0.4	13.0	1,877.9	0.5	0.6	1	1	1
07/10/2014 22:00	0.4	13.1	1,858.2	0.4	0.6	1	1	1
07/10/2014 23:00	0.5	13.2	1,635.7	0.5	0.5	1	1	1
Average/Sum#:	0.4	13.2	1,629.3	0.5	0.5	24 #	24 #	15 #
Minimum:	-0.2	12.4	1,244.3	0.1	0.4	1	1	0
Maximum:	0.6	13.7	1,974.3	0.6	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/11/2014 00:00	0.0	16.5	313.6	0.0	0.1	1	0	0
07/11/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2014 09:00	0.0	16.9	546.6	0.0	0.2	1	0	0
07/11/2014 10:00	0.0	14.8	956.5	0.0	0.3	1	0	0
07/11/2014 11:00	0.6	13.9	1,277.0	0.6	0.4	1	1	0
07/11/2014 12:00	0.6	13.9	1,277.3	0.6	0.4	1	1	0
07/11/2014 13:00	0.6	13.9	1,277.8	0.6	0.4	1	1	0
07/11/2014 14:00	0.6	13.9	1,280.4	0.6	0.4	1	1	0
07/11/2014 15:00	0.6	14.0	1,282.1	0.6	0.4	1	1	0
07/11/2014 16:00	0.6	14.0	1,282.3	0.6	0.4	1	1	0
07/11/2014 17:00	0.6	14.0	1,281.0	0.6	0.4	1	1	0
07/11/2014 18:00	0.6	13.9	1,277.8	0.6	0.4	1	1	0
07/11/2014 19:00	0.6	13.9	1,274.0	0.6	0.4	1	1	0
07/11/2014 20:00	0.6	13.9	1,273.9	0.6	0.4	1	1	0
07/11/2014 21:00	0.6	13.9	1,266.7	0.6	0.4	1	1	0
07/11/2014 22:00	0.6	13.8	1,266.6	0.6	0.4	1	1	0
07/11/2014 23:00	0.6	13.8	1,266.9	0.6	0.4	1	1	0
Average/Sum#:	0.5	14.3	1,150.0	0.5	0.4	16 #	13 #	0 #
Minimum:	0.0	13.8	313.6	0.0	0.1	0	0	0
Maximum:	0.6	16.9	1,282.3	0.6	0.4	1	1	0
%SI	33.3	33.3	33.3	33.3	33.3	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/12/2014 00:00	0.0	15.7	600.6	0.0	0.2	1	0	0
07/12/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2014 06:00	0.0	17.6	446.5	0.0	0.1	1	0	0
07/12/2014 07:00	0.0	14.8	988.3	0.0	0.3	1	0	0
07/12/2014 08:00	0.6	13.9	1,305.0	0.6	0.4	1	1	0
07/12/2014 09:00	0.6	13.9	1,305.2	0.6	0.4	1	1	0
07/12/2014 10:00	0.6	13.8	1,542.5	0.6	0.5	1	1	0
07/12/2014 11:00	0.6	13.8	1,566.0	0.6	0.5	1	1	0
07/12/2014 12:00	0.6	13.9	1,345.2	0.6	0.4	1	1	0
07/12/2014 13:00	0.6	13.8	1,656.4	0.6	0.5	1	1	0
07/12/2014 14:00	0.5	13.3	1,763.9	0.5	0.5	1	1	1
07/12/2014 15:00	0.4	12.0	2,097.4	0.5	0.6	1	1	1
07/12/2014 16:00	0.4	12.7	1,962.9	0.5	0.6	1	1	1
07/12/2014 17:00	0.4	12.6	1,966.4	0.5	0.6	1	1	1
07/12/2014 18:00	0.4	12.6	1,951.0	0.5	0.6	1	1	1
07/12/2014 19:00	0.4	13.0	1,887.0	0.5	0.6	1	1	1
07/12/2014 20:00	0.4	13.0	1,886.3	0.5	0.6	1	1	1
07/12/2014 21:00	0.2	12.6	1,983.6	0.4	0.6	1	1	1
07/12/2014 22:00	0.4	12.4	2,043.9	0.5	0.6	1	1	1
07/12/2014 23:00	0.4	12.6	1,976.7	0.5	0.6	1	1	1
Average/Sum#:	0.4	13.6	1,593.4	0.4	0.5	19 #	16 #	10 #
Minimum:	0.0	12.0	446.5	0.0	0.1	0	0	0
Maximum:	0.6	17.6	2,097.4	0.6	0.6	1	1	1
%SI	20.8	20.8	20.8	20.8	20.8	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/13/2014 00:00	0.5	13.3	1,658.0	0.5	0.5	1	1	1
07/13/2014 01:00	0.0	15.7	581.5	0.0	0.2	1	0	0
07/13/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2014 10:00	0.0	17.8	429.1	0.0	0.1	1	0	0
07/13/2014 11:00	0.0	14.7	1,158.2	0.0	0.3	1	0	1
07/13/2014 12:00	0.4	12.8	1,924.8	0.5	0.6	1	1	1
07/13/2014 13:00	0.4	12.1	2,070.3	0.5	0.6	1	1	1
07/13/2014 14:00	0.5	11.8	2,123.8	0.5	0.6	1	1	1
07/13/2014 15:00	0.7	11.4	2,210.1	0.7	0.7	1	1	1
07/13/2014 16:00	0.5	12.1	2,057.8	0.5	0.6	1	1	1
07/13/2014 17:00	0.5	12.3	2,022.4	0.5	0.6	1	1	1
07/13/2014 18:00	0.5	12.1	2,034.1	0.5	0.6	1	1	1
07/13/2014 19:00	0.5	12.7	1,912.8	0.5	0.6	1	1	1
07/13/2014 20:00	0.7	13.6	1,543.7	0.7	0.5	1	1	1
07/13/2014 21:00	0.5	13.3	1,761.6	0.5	0.5	1	1	1
07/13/2014 22:00	0.4	12.7	1,923.8	0.5	0.6	1	1	1
07/13/2014 23:00	0.7	13.6	1,471.4	0.7	0.4	1	1	1
Average/Sum#:	0.4	13.3	1,680.2	0.4	0.5	16 #	13 #	14 #
Minimum:	0.0	11.4	429.1	0.0	0.1	0	0	0
Maximum:	0.7	17.8	2,210.1	0.7	0.7	1	1	1
%SI	33.3	33.3	33.3	33.3	33.3	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/14/2014 00:00	0.6	13.9	1,384.1	0.6	0.4	1	1	0
07/14/2014 01:00	0.6	13.9	1,475.0	0.6	0.4	1	1	0
07/14/2014 02:00	0.6	13.9	1,411.3	0.6	0.4	1	1	0
07/14/2014 03:00	0.6	13.8	1,716.1	0.6	0.5	1	1	0
07/14/2014 04:00	0.6	13.7	1,717.5	0.6	0.5	1	1	0
07/14/2014 05:00	0.7	13.8	1,600.4	0.7	0.5	1	1	1
07/14/2014 06:00	0.4	12.3	1,983.0	0.5	0.6	1	1	1
07/14/2014 07:00	0.4	12.7	1,972.2	0.5	0.6	1	1	1
07/14/2014 08:00	0.5	12.9	1,910.3	0.5	0.6	1	1	1
07/14/2014 09:00	0.5	12.8	1,930.2	0.5	0.6	1	1	1
07/14/2014 10:00	0.5	13.0	1,889.6	0.5	0.6	1	1	1
07/14/2014 11:00	0.4	12.9	1,903.1	0.5	0.6	1	1	1
07/14/2014 12:00	0.5	12.8	1,905.6	0.5	0.6	1	1	1
07/14/2014 13:00	0.7	12.5	1,967.7	0.7	0.6	1	1	1
07/14/2014 14:00	0.7	11.8	2,106.4	0.7	0.6	1	1	1
07/14/2014 15:00	0.7	11.8	2,097.8	0.7	0.6	1	1	1
07/14/2014 16:00	0.7	12.0	2,057.9	0.7	0.6	1	1	1
07/14/2014 17:00	0.7	12.2	2,008.2	0.7	0.6	1	1	1
07/14/2014 18:00	0.7	13.6	1,561.3	0.7	0.5	1	1	1
07/14/2014 19:00	0.6	13.9	1,447.5	0.6	0.4	1	1	0
07/14/2014 20:00	0.6	13.8	1,633.9	0.6	0.5	1	1	0
07/14/2014 21:00	0.6	13.8	1,638.8	0.6	0.5	1	1	0
07/14/2014 22:00	0.6	13.8	1,510.5	0.6	0.5	1	1	0
07/14/2014 23:00	0.6	13.7	1,647.8	0.6	0.5	1	1	0
Average/Sum#:	0.6	13.1	1,769.8	0.6	0.5	24 #	24 #	14 #
Minimum:	0.4	11.8	1,384.1	0.5	0.4	1	1	0
Maximum:	0.7	13.9	2,106.4	0.7	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/15/2014 00:00	0.6	13.6	1,736.5	0.6	0.5	1	1	0
07/15/2014 01:00	0.6	13.6	1,760.4	0.6	0.5	1	1	0
07/15/2014 02:00	0.6	13.7	1,756.3	0.6	0.5	1	1	0
07/15/2014 03:00	0.7	13.4	1,793.7	0.7	0.5	1	1	1
07/15/2014 04:00	0.7	12.9	1,945.8	0.7	0.6	1	1	1
07/15/2014 05:00	0.7	12.7	1,998.8	0.7	0.6	1	1	1
07/15/2014 06:00	0.7	13.2	1,903.1	0.7	0.6	1	1	1
07/15/2014 07:00	0.7	13.3	1,855.1	0.7	0.6	1	1	1
07/15/2014 08:00	0.7	13.3	1,843.9	0.7	0.6	1	1	1
07/15/2014 09:00	0.7	13.2	1,856.9	0.7	0.6	1	1	1
07/15/2014 10:00	0.7	13.0	1,883.9	0.7	0.6	1	1	1
07/15/2014 11:00	0.7	13.0	1,874.1	0.7	0.6	1	1	1
07/15/2014 12:00	0.7	13.1	1,864.5	0.7	0.6	1	1	1
07/15/2014 13:00	0.7	13.1	1,862.9	0.7	0.6	1	1	1
07/15/2014 14:00	0.7	12.8	1,926.9	0.7	0.6	1	1	1
07/15/2014 15:00	0.7	12.7	1,941.1	0.7	0.6	1	1	1
07/15/2014 16:00	0.7	12.9	1,899.7	0.7	0.6	1	1	1
07/15/2014 17:00	0.7	12.8	1,918.5	0.7	0.6	1	1	1
07/15/2014 18:00	0.7	12.8	1,894.4	0.7	0.6	1	1	1
07/15/2014 19:00	0.7	12.8	1,913.9	0.7	0.6	1	1	1
07/15/2014 20:00	0.7	12.8	1,904.2	0.7	0.6	1	1	1
07/15/2014 21:00	0.7	12.8	1,913.9	0.7	0.6	1	1	1
07/15/2014 22:00	0.7	12.9	1,900.7	0.7	0.6	1	1	1
07/15/2014 23:00	0.7	12.8	1,925.3	0.7	0.6	1	1	1
Average/Sum#:	0.7	13.1	1,878.1	0.7	0.6	24 #	24 #	21 #
Minimum:	0.6	12.7	1,736.5	0.6	0.5	1	1	0
Maximum:	0.7	13.7	1,998.8	0.7	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/16/2014 00:00	0.7	12.9	1,891.5	0.7	0.6	1	1	1
07/16/2014 01:00	0.7	13.6	1,473.3	0.7	0.4	1	1	1
07/16/2014 02:00	0.6	13.8	1,427.8	0.6	0.4	1	1	0
07/16/2014 03:00	0.6	13.9	1,472.1	0.6	0.4	1	1	0
07/16/2014 04:00	0.6	13.6	1,738.0	0.6	0.5	1	1	0
07/16/2014 05:00	0.7	13.6	1,606.7	0.7	0.5	1	1	1
07/16/2014 06:00	0.7	13.5	1,711.4	0.7	0.5	1	1	1
07/16/2014 07:00	0.6	13.8	1,588.3	0.6	0.5	1	1	0
07/16/2014 08:00	0.7	13.6	1,688.9	0.7	0.5	1	1	1
07/16/2014 09:00	0.7	13.2	1,839.5	0.7	0.6	1	1	1
07/16/2014 10:00	0.7	13.2	1,839.9	0.7	0.6	1	1	1
07/16/2014 11:00	0.7	13.2	1,836.7	0.7	0.6	1	1	1
07/16/2014 12:00	0.7	13.2	1,833.4	0.7	0.6	1	1	1
07/16/2014 13:00	0.7	13.2	1,835.2	0.7	0.6	1	1	1
07/16/2014 14:00	0.7	13.1	1,838.2	0.7	0.6	1	1	1
07/16/2014 15:00	0.7	13.1	1,840.3	0.7	0.6	1	1	1
07/16/2014 16:00	0.7	13.0	1,866.3	0.7	0.6	1	1	1
07/16/2014 17:00	0.7	12.9	1,879.5	0.7	0.6	1	1	1
07/16/2014 18:00	0.7	12.9	1,881.1	0.7	0.6	1	1	1
07/16/2014 19:00	0.7	13.0	1,866.2	0.7	0.6	1	1	1
07/16/2014 20:00	0.7	13.0	1,858.5	0.7	0.6	1	1	1
07/16/2014 21:00	0.7	13.6	1,582.5	0.7	0.5	1	1	1
07/16/2014 22:00	0.7	13.5	1,692.3	0.7	0.5	1	1	1
07/16/2014 23:00	0.7	13.4	1,675.7	0.7	0.5	1	1	1
Average/Sum#:	0.7	13.3	1,740.1	0.7	0.5	24 #	24 #	20 #
Minimum:	0.6	12.9	1,427.8	0.6	0.4	1	1	0
Maximum:	0.7	13.9	1,891.5	0.7	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/17/2014 00:00	0.0	15.6	607.0	0.0	0.2	1	0	0
07/17/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/17/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/17/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/17/2014 04:00	0.0	17.4	476.0	0.0	0.1	1	0	0
07/17/2014 05:00	0.0	14.8	1,095.6	0.0	0.3	1	0	0
07/17/2014 06:00	0.6	13.7	1,738.4	0.6	0.5	1	1	0
07/17/2014 07:00	0.6	13.8	1,366.9	0.6	0.4	1	1	0
07/17/2014 08:00	0.6	13.7	1,716.6	0.6	0.5	1	1	0
07/17/2014 09:00	0.6	13.8	1,502.7	0.6	0.5	1	1	0
07/17/2014 10:00	0.7	13.6	1,596.1	0.7	0.5	1	1	1
07/17/2014 11:00	0.7	13.2	1,834.7	0.7	0.6	1	1	1
07/17/2014 12:00	0.7	13.2	1,840.1	0.7	0.6	1	1	1
07/17/2014 13:00	0.7	13.1	1,843.7	0.7	0.6	1	1	1
07/17/2014 14:00	0.7	13.1	1,846.4	0.7	0.6	1	1	1
07/17/2014 15:00	0.7	13.0	1,855.7	0.7	0.6	1	1	1
07/17/2014 16:00	0.7	13.0	1,862.5	0.7	0.6	1	1	1
07/17/2014 17:00	0.7	12.9	1,879.9	0.7	0.6	1	1	1
07/17/2014 18:00	0.7	12.6	1,953.1	0.7	0.6	1	1	1
07/17/2014 19:00	0.7	12.5	1,975.5	0.7	0.6	1	1	1
07/17/2014 20:00	0.7	12.9	1,883.3	0.7	0.6	1	1	1
07/17/2014 21:00	0.7	12.8	1,920.4	0.7	0.6	1	1	1
07/17/2014 22:00	0.7	13.5	1,645.9	0.7	0.5	1	1	1
07/17/2014 23:00	0.6	13.8	1,410.0	0.6	0.4	1	1	0
Average/Sum#:	0.6	13.6	1,611.9	0.6	0.5	21 #	18 #	13 #
Minimum:	0.0	12.5	476.0	0.0	0.1	0	0	0
Maximum:	0.7	17.4	1,975.5	0.7	0.6	1	1	1
%SI	12.5	12.5	12.5	12.5	12.5	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/18/2014 00:00	0.0	15.6	613.4	0.0	0.2	1	0	0
07/18/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/18/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/18/2014 03:00	0.0	16.4	625.7	0.0	0.2	1	0	0
07/18/2014 04:00	0.0	13.8	1,339.7	0.0	0.4	1	0	0
07/18/2014 05:00	0.6	13.8	1,514.5	0.6	0.5	1	1	0
07/18/2014 06:00	0.6	13.8	1,454.6	0.6	0.4	1	1	0
07/18/2014 07:00	0.6	13.7	1,601.6	0.6	0.5	1	1	0
07/18/2014 08:00	0.6	13.8	1,625.0	0.6	0.5	1	1	0
07/18/2014 09:00	0.7	13.6	1,564.1	0.7	0.5	1	1	1
07/18/2014 10:00	0.7	13.2	1,857.5	0.7	0.6	1	1	1
07/18/2014 11:00	0.7	13.2	1,848.2	0.7	0.6	1	1	1
07/18/2014 12:00	0.7	13.2	1,837.2	0.7	0.6	1	1	1
07/18/2014 13:00	0.7	13.2	1,841.4	0.7	0.6	1	1	1
07/18/2014 14:00	0.7	13.1	1,844.9	0.7	0.6	1	1	1
07/18/2014 15:00	0.7	13.0	1,877.3	0.7	0.6	1	1	1
07/18/2014 16:00	0.7	12.9	1,906.0	0.7	0.6	1	1	1
07/18/2014 17:00	0.7	11.8	2,125.2	0.7	0.6	1	1	1
07/18/2014 18:00	0.7	11.7	2,150.0	0.7	0.6	1	1	1
07/18/2014 19:00	0.7	12.0	2,093.4	0.7	0.6	1	1	1
07/18/2014 20:00	0.7	12.4	1,997.8	0.7	0.6	1	1	1
07/18/2014 21:00	0.7	13.0	1,866.2	0.7	0.6	1	1	1
07/18/2014 22:00	0.7	13.4	1,599.4	0.7	0.5	1	1	1
07/18/2014 23:00	0.6	13.8	1,302.4	0.6	0.4	1	1	0
Average/Sum#:	0.6	13.4	1,658.4	0.6	0.5	22 #	19 #	14 #
Minimum:	0.0	11.7	613.4	0.0	0.2	0	0	0
Maximum:	0.7	16.4	2,150.0	0.7	0.6	1	1	1
%SI	8.3	8.3	8.3	8.3	8.3	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/19/2014 00:00	0.0	15.1	853.5	0.0	0.3	1	0	0
07/19/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/19/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/19/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/19/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/19/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/19/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/19/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/19/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/19/2014 09:00	0.0	17.8	403.7	0.0	0.1	1	0	0
07/19/2014 10:00	0.0	14.6	1,198.1	0.0	0.4	1	0	0
07/19/2014 11:00	0.7	12.3	2,067.5	0.7	0.6	1	1	1
07/19/2014 12:00	0.7	11.7	2,155.7	0.7	0.6	1	1	1
07/19/2014 13:00	0.7	11.4	2,222.5	0.7	0.7	1	1	1
07/19/2014 14:00	0.7	11.5	2,192.9	0.7	0.7	1	1	1
07/19/2014 15:00	0.7	11.5	2,182.0	0.7	0.7	1	1	1
07/19/2014 16:00	0.7	11.6	2,142.9	0.7	0.6	1	1	1
07/19/2014 17:00	0.7	11.7	2,132.8	0.7	0.6	1	1	1
07/19/2014 18:00	0.7	12.4	1,987.0	0.7	0.6	1	1	1
07/19/2014 19:00	0.7	12.0	2,078.2	0.7	0.6	1	1	1
07/19/2014 20:00	0.7	11.7	2,148.8	0.7	0.6	1	1	1
07/19/2014 21:00	0.7	12.3	2,024.7	0.7	0.6	1	1	1
07/19/2014 22:00	0.7	13.7	1,533.4	0.7	0.5	1	1	1
07/19/2014 23:00	0.6	13.8	1,502.5	0.6	0.5	1	1	0
Average/Sum#:	0.6	12.8	1,801.6	0.6	0.5	16 #	13 #	12 #
Minimum:	0.0	11.4	403.7	0.0	0.1	0	0	0
Maximum:	0.7	17.8	2,222.5	0.7	0.7	1	1	1
%SI	33.3	33.3	33.3	33.3	33.3	0	0	0

Daily Summary Report

CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/20/2014 00:00	0.0	15.6	602.0	0.0	0.2	1	0	0
07/20/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	15.6	602.0	0.0	0.2	1 #	0 #	0 #
Minimum:	0.0	15.6	602.0	0.0	0.2	0	0	0
Maximum:	0.0	15.6	602.0	0.0	0.2	1	0	0
%SI	95.8	95.8	95.8	95.8	95.8	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/21/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2014 01:00	0.0	17.4	477.1	0.0	0.1	1	0	0
07/21/2014 02:00	0.0	16.7	580.1	0.0	0.2	1	0	0
07/21/2014 03:00	0.0	14.5	1,129.3	0.0	0.3	1	0	0
07/21/2014 04:00	0.6	13.8	1,619.8	0.6	0.5	1	1	0
07/21/2014 05:00	0.6	13.8	1,663.0	0.6	0.5	1	1	0
07/21/2014 06:00	0.6	13.9	1,643.8	0.6	0.5	1	1	0
07/21/2014 07:00	0.6	13.8	1,638.0	0.6	0.5	1	1	0
07/21/2014 08:00	0.7	13.0	1,914.6	0.7	0.6	1	1	1
07/21/2014 09:00	0.7	12.7	1,973.3	0.7	0.6	1	1	1
07/21/2014 10:00	0.7	12.7	1,974.9	0.7	0.6	1	1	1
07/21/2014 11:00	0.7	12.7	1,961.3	0.7	0.6	1	1	1
07/21/2014 12:00	0.7	12.8	1,948.6	0.7	0.6	1	1	1
07/21/2014 13:00	0.7	12.8	1,928.3	0.7	0.6	1	1	1
07/21/2014 14:00	0.7	12.7	1,937.5	0.7	0.6	1	1	1
07/21/2014 15:00	0.7	12.4	2,007.4	0.7	0.6	1	1	1
07/21/2014 16:00	0.7	12.4	2,012.0	0.7	0.6	1	1	1
07/21/2014 17:00	0.7	11.6	2,185.9	0.7	0.7	1	1	1
07/21/2014 18:00	0.7	11.2	2,253.2	0.7	0.7	1	1	1
07/21/2014 19:00	0.7	11.2	2,257.7	0.7	0.7	1	1	1
07/21/2014 20:00	0.7	11.3	2,259.8	0.7	0.7	1	1	1
07/21/2014 21:00	0.7	11.7	2,167.9	0.7	0.7	1	1	1
07/21/2014 22:00	0.7	12.4	2,026.8	0.7	0.6	1	1	1
07/21/2014 23:00	0.7	12.7	1,958.4	0.7	0.6	1	1	1
Average/Sum#:	0.6	13.1	1,805.2	0.6	0.6	23 #	20 #	16 #
Minimum:	0.0	11.2	477.1	0.0	0.1	0	0	0
Maximum:	0.7	17.4	2,259.8	0.7	0.7	1	1	1
%SI	4.2	4.2	4.2	4.2	4.2	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/22/2014 00:00	0.7	13.2	1,856.2	0.7	0.6	1	1	1
07/22/2014 01:00	0.7	13.2	1,872.5	0.7	0.6	1	1	1
07/22/2014 02:00	0.7	13.2	1,867.9	0.7	0.6	1	1	1
07/22/2014 03:00	0.7	13.2	1,857.4	0.7	0.6	1	1	1
07/22/2014 04:00	0.7	13.0	1,928.6	0.7	0.6	1	1	1
07/22/2014 05:00	0.7	13.2	1,885.8	0.7	0.6	1	1	1
07/22/2014 06:00	0.7	13.2	1,869.2	0.7	0.6	1	1	1
07/22/2014 07:00	0.7	12.9	1,950.3	0.7	0.6	1	1	1
07/22/2014 08:00	0.7	13.2	1,871.1	0.7	0.6	1	1	1
07/22/2014 09:00	0.7	13.2	1,858.2	0.7	0.6	1	1	1
07/22/2014 10:00	0.7	13.1	1,851.6	0.7	0.6	1	1	1
07/22/2014 11:00	0.7	12.7	1,953.3	0.7	0.6	1	1	1
07/22/2014 12:00	0.7	12.3	2,028.4	0.7	0.6	1	1	1
07/22/2014 13:00	0.7	12.5	1,987.3	0.7	0.6	1	1	1
07/22/2014 14:00	0.7	12.3	2,020.1	0.7	0.6	1	1	1
07/22/2014 15:00	0.7	11.7	2,153.5	0.7	0.6	1	1	1
07/22/2014 16:00	0.7	12.0	2,095.4	0.7	0.6	1	1	1
07/22/2014 17:00	0.7	12.2	2,045.9	0.7	0.6	1	1	1
07/22/2014 18:00	0.7	11.8	2,147.4	0.7	0.6	1	1	1
07/22/2014 19:00	0.7	12.1	2,102.5	0.7	0.6	1	1	1
07/22/2014 20:00	0.7	12.2	2,079.2	0.7	0.6	1	1	1
07/22/2014 21:00	0.7	12.3	2,078.9	0.7	0.6	1	1	1
07/22/2014 22:00	0.7	12.7	1,982.9	0.7	0.6	1	1	1
07/22/2014 23:00	0.7	13.6	1,542.3	0.7	0.5	1	1	1
Average/Sum#:	0.7	12.7	1,953.6	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	11.7	1,542.3	0.7	0.5	1	1	1
Maximum:	0.7	13.6	2,153.5	0.7	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/23/2014 00:00	0.6	13.8	1,286.2	0.6	0.4	1	1	0
07/23/2014 01:00	0.6	13.8	1,270.5	0.6	0.4	1	1	0
07/23/2014 02:00	0.6	13.8	1,252.7	0.6	0.4	1	1	0
07/23/2014 03:00	0.6	13.8	1,252.5	0.6	0.4	1	1	0
07/23/2014 04:00	0.6	13.8	1,272.5	0.6	0.4	1	1	0
07/23/2014 05:00	0.7	13.8	1,538.2	0.7	0.5	1	1	1
07/23/2014 06:00	0.7	13.1	1,932.8	0.7	0.6	1	1	1
07/23/2014 07:00	0.7	13.0	1,932.5	0.7	0.6	1	1	1
07/23/2014 08:00	0.7	13.1	1,908.1	0.7	0.6	1	1	1
07/23/2014 09:00	0.7	13.1	1,898.3	0.7	0.6	1	1	1
07/23/2014 10:00	0.7	13.2	1,875.5	0.7	0.6	1	1	1
07/23/2014 11:00	0.7	13.2	1,876.9	0.7	0.6	1	1	1
07/23/2014 12:00	0.7	13.2	1,876.6	0.7	0.6	1	1	1
07/23/2014 13:00	0.7	13.2	1,868.6	0.7	0.6	1	1	1
07/23/2014 14:00	0.7	13.0	1,909.4	0.7	0.6	1	1	1
07/23/2014 15:00	0.7	12.4	2,022.0	0.7	0.6	1	1	1
07/23/2014 16:00	0.7	12.0	2,105.5	0.7	0.6	1	1	1
07/23/2014 17:00	0.7	12.5	1,985.5	0.7	0.6	1	1	1
07/23/2014 18:00	0.7	12.3	2,039.1	0.7	0.6	1	1	1
07/23/2014 19:00	0.7	12.4	2,017.0	0.7	0.6	1	1	1
07/23/2014 20:00	0.7	12.7	1,970.8	0.7	0.6	1	1	1
07/23/2014 21:00	0.7	12.8	1,937.7	0.7	0.6	1	1	1
07/23/2014 22:00	0.7	13.1	1,877.3	0.7	0.6	1	1	1
07/23/2014 23:00	0.7	12.9	1,921.5	0.7	0.6	1	1	1
Average/Sum#:	0.7	13.1	1,784.5	0.7	0.6	24 #	24 #	19 #
Minimum:	0.6	12.0	1,252.5	0.6	0.4	1	1	0
Maximum:	0.7	13.8	2,105.5	0.7	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/24/2014 00:00	0.7	13.1	1,884.0	0.7	0.6	1	1	1
07/24/2014 01:00	0.7	13.2	1,888.7	0.7	0.6	1	1	1
07/24/2014 02:00	0.7	13.7	1,487.4	0.7	0.4	1	1	1
07/24/2014 03:00	0.6	13.9	1,257.5	0.6	0.4	1	1	0
07/24/2014 04:00	0.6	13.9	1,253.3	0.6	0.4	1	1	0
07/24/2014 05:00	0.6	13.9	1,257.7	0.6	0.4	1	1	0
07/24/2014 06:00	0.6	13.9	1,260.3	0.6	0.4	1	1	0
07/24/2014 07:00	0.6	13.9	1,265.1	0.6	0.4	1	1	0
07/24/2014 08:00	0.6	13.8	1,569.3	0.6	0.5	1	1	0
07/24/2014 09:00	0.7	13.1	1,908.3	0.7	0.6	1	1	1
07/24/2014 10:00	0.7	12.9	1,939.4	0.7	0.6	1	1	1
07/24/2014 11:00	0.7	12.8	1,971.7	0.7	0.6	1	1	1
07/24/2014 12:00	0.7	12.1	2,121.1	0.7	0.6	1	1	1
07/24/2014 13:00	0.7	11.3	2,284.2	0.7	0.7	1	1	1
07/24/2014 14:00	0.7	11.5	2,237.2	0.7	0.7	1	1	1
07/24/2014 15:00	0.7	12.0	2,123.0	0.7	0.6	1	1	1
07/24/2014 16:00	0.7	11.9	2,128.6	0.7	0.6	1	1	1
07/24/2014 17:00	0.7	12.0	2,125.8	0.7	0.6	1	1	1
07/24/2014 18:00	0.7	12.0	2,116.9	0.7	0.6	1	1	1
07/24/2014 19:00	0.7	12.1	2,089.5	0.7	0.6	1	1	1
07/24/2014 20:00	0.7	12.3	2,054.3	0.7	0.6	1	1	1
07/24/2014 21:00	0.7	13.3	1,751.3	0.7	0.5	1	1	1
07/24/2014 22:00	0.7	13.0	1,919.0	0.7	0.6	1	1	1
07/24/2014 23:00	0.7	12.3	2,070.7	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.8	1,831.8	0.7	0.6	24 #	24 #	18 #
Minimum:	0.6	11.3	1,253.3	0.6	0.4	1	1	0
Maximum:	0.7	13.9	2,284.2	0.7	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/25/2014 00:00	0.7	13.0	1,916.3	0.7	0.6	1	1	1
07/25/2014 01:00	0.7	13.3	1,873.0	0.7	0.6	1	1	1
07/25/2014 02:00	0.7	13.3	1,871.4	0.7	0.6	1	1	1
07/25/2014 03:00	0.7	13.3	1,868.8	0.7	0.6	1	1	1
07/25/2014 04:00	0.7	13.1	1,912.8	0.7	0.6	1	1	1
07/25/2014 05:00	0.7	13.1	1,933.8	0.7	0.6	1	1	1
07/25/2014 06:00	0.7	13.0	1,932.0	0.7	0.6	1	1	1
07/25/2014 07:00	0.7	12.9	1,939.4	0.7	0.6	1	1	1
07/25/2014 08:00	0.7	13.1	1,898.4	0.7	0.6	1	1	1
07/25/2014 09:00	0.7	12.9	1,937.2	0.7	0.6	1	1	1
07/25/2014 10:00	0.7	12.2	2,091.2	0.7	0.6	1	1	1
07/25/2014 11:00	0.7	11.7	2,184.8	0.7	0.7	1	1	1
07/25/2014 12:00	0.7	11.9	2,146.8	0.7	0.6	1	1	1
07/25/2014 13:00	0.7	12.3	2,032.5	0.7	0.6	1	1	1
07/25/2014 14:00	0.7	12.1	2,086.4	0.7	0.6	1	1	1
07/25/2014 15:00	0.7	11.7	2,173.3	0.7	0.7	1	1	1
07/25/2014 16:00	0.7	11.8	2,152.0	0.7	0.6	1	1	1
07/25/2014 17:00	0.7	11.7	2,179.7	0.7	0.7	1	1	1
07/25/2014 18:00	0.7	11.7	2,171.9	0.7	0.7	1	1	1
07/25/2014 19:00	0.7	11.5	2,205.3	0.7	0.7	1	1	1
07/25/2014 20:00	0.7	11.9	2,124.0	0.7	0.6	1	1	1
07/25/2014 21:00	0.7	12.3	2,053.2	0.7	0.6	1	1	1
07/25/2014 22:00	0.7	12.4	2,038.9	0.7	0.6	1	1	1
07/25/2014 23:00	0.7	12.9	1,934.4	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.5	2,027.4	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	11.5	1,868.8	0.7	0.6	1	1	1
Maximum:	0.7	13.3	2,205.3	0.7	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/26/2014 00:00	0.7	13.1	1,887.7	0.7	0.6	1	1	1
07/26/2014 01:00	0.7	13.2	1,867.2	0.7	0.6	1	1	1
07/26/2014 02:00	0.7	13.3	1,865.0	0.7	0.6	1	1	1
07/26/2014 03:00	0.7	13.3	1,862.0	0.7	0.6	1	1	1
07/26/2014 04:00	0.7	13.1	1,903.7	0.7	0.6	1	1	1
07/26/2014 05:00	0.7	13.3	1,860.8	0.7	0.6	1	1	1
07/26/2014 06:00	0.7	13.3	1,854.1	0.7	0.6	1	1	1
07/26/2014 07:00	0.7	13.2	1,872.2	0.7	0.6	1	1	1
07/26/2014 08:00	0.7	13.1	1,872.7	0.7	0.6	1	1	1
07/26/2014 09:00	0.7	13.1	1,861.1	0.7	0.6	1	1	1
07/26/2014 10:00	0.7	13.1	1,872.1	0.7	0.6	1	1	1
07/26/2014 11:00	0.7	12.5	2,000.6	0.7	0.6	1	1	1
07/26/2014 12:00	0.7	11.7	2,155.3	0.7	0.6	1	1	1
07/26/2014 13:00	0.7	11.7	2,156.1	0.7	0.6	1	1	1
07/26/2014 14:00	0.7	12.1	2,058.3	0.7	0.6	1	1	1
07/26/2014 15:00	0.7	13.4	1,675.7	0.7	0.5	1	1	1
07/26/2014 16:00	0.7	13.4	1,642.0	0.7	0.5	1	1	1
07/26/2014 17:00	0.7	12.6	1,960.2	0.7	0.6	1	1	1
07/26/2014 18:00	0.7	13.0	1,839.6	0.7	0.6	1	1	1
07/26/2014 19:00	0.6	13.9	1,265.7	0.6	0.4	1	1	0
07/26/2014 20:00	0.6	14.0	1,253.1	0.6	0.4	1	1	0
07/26/2014 21:00	0.6	14.0	1,252.3	0.6	0.4	1	1	0
07/26/2014 22:00	0.6	13.9	1,250.5	0.6	0.4	1	1	0
07/26/2014 23:00	0.6	13.9	1,410.0	0.6	0.4	1	1	0
Average/Sum#:	0.7	13.1	1,770.8	0.7	0.6	24 #	24 #	19 #
Minimum:	0.6	11.7	1,250.5	0.6	0.4	1	1	0
Maximum:	0.7	14.0	2,156.1	0.7	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/27/2014 00:00	0.6	13.8	1,503.4	0.6	0.5	1	1	0
07/27/2014 01:00	0.6	13.9	1,355.8	0.6	0.4	1	1	0
07/27/2014 02:00	0.6	13.8	1,382.1	0.6	0.4	1	1	0
07/27/2014 03:00	0.6	13.9	1,277.6	0.6	0.4	1	1	0
07/27/2014 04:00	0.6	13.9	1,334.2	0.6	0.4	1	1	0
07/27/2014 05:00	0.6	13.9	1,287.6	0.6	0.4	1	1	0
07/27/2014 06:00	0.7	13.5	1,532.8	0.7	0.5	1	1	1
07/27/2014 07:00	0.7	13.0	1,914.7	0.7	0.6	1	1	1
07/27/2014 08:00	0.7	13.3	1,782.0	0.7	0.5	1	1	1
07/27/2014 09:00	0.7	13.0	1,890.8	0.7	0.6	1	1	1
07/27/2014 10:00	0.7	12.9	1,916.2	0.7	0.6	1	1	1
07/27/2014 11:00	0.7	12.2	2,071.2	0.7	0.6	1	1	1
07/27/2014 12:00	0.7	12.4	2,014.8	0.7	0.6	1	1	1
07/27/2014 13:00	0.7	12.5	1,991.2	0.7	0.6	1	1	1
07/27/2014 14:00	0.7	12.8	1,934.3	0.7	0.6	1	1	1
07/27/2014 15:00	0.7	12.0	2,118.5	0.7	0.6	1	1	1
07/27/2014 16:00	0.7	11.8	2,147.1	0.7	0.6	1	1	1
07/27/2014 17:00	0.7	11.7	2,149.3	0.7	0.6	1	1	1
07/27/2014 18:00	0.7	11.7	2,148.2	0.7	0.6	1	1	1
07/27/2014 19:00	0.7	11.9	2,091.5	0.7	0.6	1	1	1
07/27/2014 20:00	0.7	13.0	1,849.4	0.7	0.6	1	1	1
07/27/2014 21:00	0.7	13.3	1,690.9	0.7	0.5	1	1	1
07/27/2014 22:00	0.7	13.4	1,672.6	0.7	0.5	1	1	1
07/27/2014 23:00	0.7	13.0	1,870.2	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.9	1,788.6	0.7	0.5	24 #	24 #	18 #
Minimum:	0.6	11.7	1,277.6	0.6	0.4	1	1	0
Maximum:	0.7	13.9	2,149.3	0.7	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/28/2014 00:00	0.7	13.1	1,874.1	0.7	0.6	1	1	1
07/28/2014 01:00	0.7	12.8	1,935.7	0.7	0.6	1	1	1
07/28/2014 02:00	0.7	13.2	1,762.8	0.7	0.5	1	1	1
07/28/2014 03:00	0.6	13.8	1,283.8	0.6	0.4	1	1	0
07/28/2014 04:00	0.7	13.5	1,606.5	0.7	0.5	1	1	1
07/28/2014 05:00	0.7	13.2	1,856.5	0.7	0.6	1	1	1
07/28/2014 06:00	0.7	13.2	1,854.2	0.7	0.6	1	1	1
07/28/2014 07:00	0.7	13.2	1,852.3	0.7	0.6	1	1	1
07/28/2014 08:00	0.7	13.2	1,851.6	0.7	0.6	1	1	1
07/28/2014 09:00	0.7	13.1	1,871.5	0.7	0.6	1	1	1
07/28/2014 10:00	0.7	12.0	2,115.2	0.7	0.6	1	1	1
07/28/2014 11:00	0.7	11.4	2,220.1	0.7	0.7	1	1	1
07/28/2014 12:00	0.7	11.7	2,144.9	0.7	0.6	1	1	1
07/28/2014 13:00	0.7	11.5	2,168.3	0.7	0.7	1	1	1
07/28/2014 14:00	0.7	11.7	2,148.3	0.7	0.6	1	1	1
07/28/2014 15:00	0.7	11.7	2,147.9	0.7	0.6	1	1	1
07/28/2014 16:00	0.7	11.7	2,130.6	0.7	0.6	1	1	1
07/28/2014 17:00	0.7	11.7	2,133.6	0.7	0.6	1	1	1
07/28/2014 18:00	0.7	12.5	1,980.1	0.7	0.6	1	1	1
07/28/2014 19:00	0.7	12.4	2,002.6	0.7	0.6	1	1	1
07/28/2014 20:00	0.7	12.6	1,974.6	0.7	0.6	1	1	1
07/28/2014 21:00	0.7	12.9	1,910.3	0.7	0.6	1	1	1
07/28/2014 22:00	0.7	12.8	1,943.9	0.7	0.6	1	1	1
07/28/2014 23:00	0.7	13.2	1,861.6	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.6	1,943.0	0.7	0.6	24 #	24 #	23 #
Minimum:	0.6	11.4	1,283.8	0.6	0.4	1	1	0
Maximum:	0.7	13.8	2,220.1	0.7	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/29/2014 00:00	0.7	12.8	1,954.7	0.7	0.6	1	1	1
07/29/2014 01:00	0.7	13.8	1,449.0	0.7	0.4	1	1	1
07/29/2014 02:00	0.6	13.9	1,257.6	0.6	0.4	1	1	0
07/29/2014 03:00	0.6	13.9	1,236.1	0.6	0.4	1	1	0
07/29/2014 04:00	0.7	13.8	1,373.7	0.7	0.4	1	1	1
07/29/2014 05:00	0.7	13.3	1,858.5	0.7	0.6	1	1	1
07/29/2014 06:00	0.7	12.9	1,941.3	0.7	0.6	1	1	1
07/29/2014 07:00	0.7	12.1	2,108.7	0.7	0.6	1	1	1
07/29/2014 08:00	0.7	12.3	2,060.8	0.7	0.6	1	1	1
07/29/2014 09:00	0.7	12.6	1,994.8	0.7	0.6	1	1	1
07/29/2014 10:00	0.7	11.7	2,175.2	0.7	0.7	1	1	1
07/29/2014 11:00	0.7	12.4	2,021.2	0.7	0.6	1	1	1
07/29/2014 12:00	0.7	11.9	2,136.0	0.7	0.6	1	1	1
07/29/2014 13:00	0.7	11.5	2,216.7	0.7	0.7	1	1	1
07/29/2014 14:00	0.7	11.5	2,212.1	0.7	0.7	1	1	1
07/29/2014 15:00	0.7	11.5	2,178.5	0.7	0.7	1	1	1
07/29/2014 16:00	0.7	12.0	2,076.2	0.7	0.6	1	1	1
07/29/2014 17:00	0.7	12.3	2,005.7	0.7	0.6	1	1	1
07/29/2014 18:00	0.7	12.3	1,997.9	0.7	0.6	1	1	1
07/29/2014 19:00	0.7	12.6	1,918.3	0.7	0.6	1	1	1
07/29/2014 20:00	0.7	13.1	1,850.7	0.7	0.6	1	1	1
07/29/2014 21:00	0.7	12.8	1,904.3	0.7	0.6	1	1	1
07/29/2014 22:00	0.7	13.2	1,836.5	0.7	0.6	1	1	1
07/29/2014 23:00	0.7	13.2	1,840.3	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.6	1,900.2	0.7	0.6	24 #	24 #	22 #
Minimum:	0.6	11.5	1,236.1	0.6	0.4	1	1	0
Maximum:	0.7	13.9	2,216.7	0.7	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/30/2014 00:00	0.7	13.2	1,827.8	0.7	0.5	1	1	1
07/30/2014 01:00	0.7	13.1	1,867.7	0.7	0.6	1	1	1
07/30/2014 02:00	0.7	13.7	1,404.7	0.7	0.4	1	1	1
07/30/2014 03:00	0.7	13.6	1,539.7	0.7	0.5	1	1	1
07/30/2014 04:00	0.7	13.2	1,865.3	0.7	0.6	1	1	1
07/30/2014 05:00	0.7	13.2	1,867.2	0.7	0.6	1	1	1
07/30/2014 06:00	0.7	13.2	1,856.3	0.7	0.6	1	1	1
07/30/2014 07:00	0.7	13.1	1,852.8	0.7	0.6	1	1	1
07/30/2014 08:00	0.7	13.2	1,855.6	0.7	0.6	1	1	1
07/30/2014 09:00	0.7	13.1	1,857.8	0.7	0.6	1	1	1
07/30/2014 10:00	0.7	13.1	1,862.2	0.7	0.6	1	1	1
07/30/2014 11:00	0.7	12.5	1,998.0	0.7	0.6	1	1	1
07/30/2014 12:00	0.7	11.5	2,195.1	0.7	0.7	1	1	1
07/30/2014 13:00	0.7	11.5	2,208.4	0.7	0.7	1	1	1
07/30/2014 14:00	0.7	11.5	2,189.5	0.7	0.7	1	1	1
07/30/2014 15:00	0.7	11.5	2,169.6	0.7	0.7	1	1	1
07/30/2014 16:00	0.7	11.5	2,170.8	0.7	0.7	1	1	1
07/30/2014 17:00	0.7	11.5	2,164.0	0.7	0.6	1	1	1
07/30/2014 18:00	0.7	11.6	2,162.0	0.7	0.6	1	1	1
07/30/2014 19:00	0.7	11.8	2,117.6	0.7	0.6	1	1	1
07/30/2014 20:00	0.7	12.3	2,005.1	0.7	0.6	1	1	1
07/30/2014 21:00	0.7	11.8	2,143.7	0.7	0.6	1	1	1
07/30/2014 22:00	0.7	12.0	2,097.3	0.7	0.6	1	1	1
07/30/2014 23:00	0.7	12.2	2,049.1	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.5	1,972.0	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	11.5	1,404.7	0.7	0.4	1	1	1
Maximum:	0.7	13.7	2,208.4	0.7	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/31/2014 00:00	0.7	13.4	1,697.7	0.7	0.5	1	1	1
07/31/2014 01:00	0.6	13.7	1,706.5	0.6	0.5	1	1	0
07/31/2014 02:00	0.7	13.3	1,762.8	0.7	0.5	1	1	1
07/31/2014 03:00	0.7	13.0	1,893.5	0.7	0.6	1	1	1
07/31/2014 04:00	0.7	13.1	1,866.6	0.7	0.6	1	1	1
07/31/2014 05:00	0.7	13.2	1,862.6	0.7	0.6	1	1	1
07/31/2014 06:00	0.7	13.1	1,860.8	0.7	0.6	1	1	1
07/31/2014 07:00	0.7	13.1	1,861.0	0.7	0.6	1	1	1
07/31/2014 08:00	0.7	13.0	1,865.3	0.7	0.6	1	1	1
07/31/2014 09:00	0.7	12.7	1,939.6	0.7	0.6	1	1	1
07/31/2014 10:00	0.7	11.5	2,176.9	0.7	0.7	1	1	1
07/31/2014 11:00	0.7	11.4	2,205.1	0.7	0.7	1	1	1
07/31/2014 12:00	0.7	11.5	2,178.3	0.7	0.7	1	1	1
07/31/2014 13:00	0.7	12.7	1,909.2	0.7	0.6	1	1	1
07/31/2014 14:00	0.7	12.6	1,942.2	0.7	0.6	1	1	1
07/31/2014 15:00	0.7	12.2	2,027.8	0.7	0.6	1	1	1
07/31/2014 16:00	0.7	12.1	2,037.9	0.7	0.6	1	1	1
07/31/2014 17:00	0.7	12.0	2,032.7	0.7	0.6	1	1	1
07/31/2014 18:00	0.7	12.1	2,028.8	0.7	0.6	1	1	1
07/31/2014 19:00	0.7	12.1	2,018.2	0.7	0.6	1	1	1
07/31/2014 20:00	0.7	12.3	1,999.5	0.7	0.6	1	1	1
07/31/2014 21:00	0.7	12.4	1,982.5	0.7	0.6	1	1	1
07/31/2014 22:00	0.7	12.7	1,912.5	0.7	0.6	1	1	1
07/31/2014 23:00	0.7	12.8	1,909.1	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.6	1,944.9	0.7	0.6	24 #	24 #	23 #
Minimum:	0.6	11.4	1,697.7	0.6	0.5	1	1	0
Maximum:	0.7	13.7	2,205.1	0.7	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/01/2014 00:00	0.7	12.8	1,910.6	0.7	0.6	1	1	1
08/01/2014 01:00	0.7	13.6	1,585.6	0.7	0.5	1	1	1
08/01/2014 02:00	0.7	13.6	1,593.2	0.7	0.5	1	1	1
08/01/2014 03:00	0.7	12.9	1,910.5	0.7	0.6	1	1	1
08/01/2014 04:00	0.7	13.1	1,874.3	0.7	0.6	1	1	1
08/01/2014 05:00	0.7	13.0	1,919.3	0.7	0.6	1	1	1
08/01/2014 06:00	0.7	13.2	1,854.0	0.7	0.6	1	1	1
08/01/2014 07:00	0.7	13.2	1,851.7	0.7	0.6	1	1	1
08/01/2014 08:00	0.7	12.8	1,917.7	0.7	0.6	1	1	1
08/01/2014 09:00	0.7	12.3	2,037.3	0.7	0.6	1	1	1
08/01/2014 10:00	0.7	11.8	2,135.6	0.7	0.6	1	1	1
08/01/2014 11:00	0.7	11.4	2,192.5	0.7	0.7	1	1	1
08/01/2014 12:00	0.7	11.5	2,162.4	0.7	0.6	1	1	1
08/01/2014 13:00	0.7	11.5	2,156.8	0.7	0.6	1	1	1
08/01/2014 14:00	0.7	11.5	2,158.6	0.7	0.6	1	1	1
08/01/2014 15:00	0.7	11.6	2,134.5	0.7	0.6	1	1	1
08/01/2014 16:00	0.7	11.9	2,079.3	0.7	0.6	1	1	1
08/01/2014 17:00	0.7	12.1	2,046.6	0.7	0.6	1	1	1
08/01/2014 18:00	0.7	12.1	2,035.3	0.7	0.6	1	1	1
08/01/2014 19:00	0.7	12.3	2,026.1	0.7	0.6	1	1	1
08/01/2014 20:00	0.7	12.7	1,962.1	0.7	0.6	1	1	1
08/01/2014 21:00	0.7	12.8	1,930.4	0.7	0.6	1	1	1
08/01/2014 22:00	0.7	12.9	1,917.3	0.7	0.6	1	1	1
08/01/2014 23:00	0.7	12.7	1,954.7	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.5	1,972.8	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	11.4	1,585.6	0.7	0.5	1	1	1
Maximum:	0.7	13.6	2,192.5	0.7	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/02/2014 00:00	0.7	13.0	1,901.4	0.7	0.6	1	1	1
08/02/2014 01:00	0.7	13.1	1,877.5	0.7	0.6	1	1	1
08/02/2014 02:00	0.7	13.2	1,854.5	0.7	0.6	1	1	1
08/02/2014 03:00	0.6	13.9	1,307.7	0.6	0.4	1	1	0
08/02/2014 04:00	0.6	13.9	1,476.7	0.6	0.4	1	1	0
08/02/2014 05:00	0.6	13.9	1,268.3	0.6	0.4	1	1	0
08/02/2014 06:00	0.6	13.8	1,243.7	0.6	0.4	1	1	0
08/02/2014 07:00	0.7	13.6	1,520.0	0.7	0.5	1	1	1
08/02/2014 08:00	0.7	13.1	1,874.3	0.7	0.6	1	1	1
08/02/2014 09:00	0.7	13.2	1,835.5	0.7	0.6	1	1	1
08/02/2014 10:00	0.7	13.2	1,844.1	0.7	0.6	1	1	1
08/02/2014 11:00	0.7	13.0	1,888.1	0.7	0.6	1	1	1
08/02/2014 12:00	0.7	12.8	1,929.7	0.7	0.6	1	1	1
08/02/2014 13:00	0.7	12.7	1,933.2	0.7	0.6	1	1	1
08/02/2014 14:00	0.7	12.8	1,890.5	0.7	0.6	1	1	1
08/02/2014 15:00	0.7	12.7	1,912.6	0.7	0.6	1	1	1
08/02/2014 16:00	0.7	12.6	1,921.2	0.7	0.6	1	1	1
08/02/2014 17:00	0.7	12.5	1,945.7	0.7	0.6	1	1	1
08/02/2014 18:00	0.7	12.6	1,934.6	0.7	0.6	1	1	1
08/02/2014 19:00	0.7	12.3	2,009.7	0.7	0.6	1	1	1
08/02/2014 20:00	0.7	12.3	2,004.2	0.7	0.6	1	1	1
08/02/2014 21:00	0.7	12.7	1,929.8	0.7	0.6	1	1	1
08/02/2014 22:00	0.7	13.6	1,543.0	0.7	0.5	1	1	1
08/02/2014 23:00	0.6	13.9	1,280.5	0.6	0.4	1	1	0
Average/Sum#:	0.7	13.1	1,755.3	0.7	0.6	24 #	24 #	19 #
Minimum:	0.6	12.3	1,243.7	0.6	0.4	1	1	0
Maximum:	0.7	13.9	2,009.7	0.7	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/03/2014 00:00	0.6	13.8	1,594.5	0.6	0.5	1	1	0
08/03/2014 01:00	0.6	13.8	1,491.5	0.6	0.4	1	1	0
08/03/2014 02:00	0.6	13.8	1,414.0	0.6	0.4	1	1	0
08/03/2014 03:00	0.6	13.8	1,598.2	0.6	0.5	1	1	0
08/03/2014 04:00	0.7	13.7	1,749.2	0.7	0.5	1	1	1
08/03/2014 05:00	0.7	13.4	1,840.9	0.7	0.6	1	1	1
08/03/2014 06:00	0.7	13.3	1,851.1	0.7	0.6	1	1	1
08/03/2014 07:00	0.7	12.7	1,975.3	0.7	0.6	1	1	1
08/03/2014 08:00	0.7	12.9	1,921.9	0.7	0.6	1	1	1
08/03/2014 09:00	0.7	12.9	1,909.1	0.7	0.6	1	1	1
08/03/2014 10:00	0.7	12.8	1,922.6	0.7	0.6	1	1	1
08/03/2014 11:00	0.7	12.8	1,932.9	0.7	0.6	1	1	1
08/03/2014 12:00	0.7	12.8	1,927.4	0.7	0.6	1	1	1
08/03/2014 13:00	0.7	11.9	2,105.6	0.7	0.6	1	1	1
08/03/2014 14:00	0.7	12.3	2,011.7	0.7	0.6	1	1	1
08/03/2014 15:00	0.7	11.7	2,137.2	0.7	0.6	1	1	1
08/03/2014 16:00	0.7	12.4	1,988.0	0.7	0.6	1	1	1
08/03/2014 17:00	0.7	12.5	1,971.7	0.7	0.6	1	1	1
08/03/2014 18:00	0.7	12.9	1,894.3	0.7	0.6	1	1	1
08/03/2014 19:00	0.7	12.6	1,973.2	0.7	0.6	1	1	1
08/03/2014 20:00	0.7	12.5	1,986.1	0.7	0.6	1	1	1
08/03/2014 21:00	0.7	12.9	1,888.0	0.7	0.6	1	1	1
08/03/2014 22:00	0.7	12.9	1,876.8	0.7	0.6	1	1	1
08/03/2014 23:00	0.7	12.7	1,954.8	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.9	1,871.5	0.7	0.6	24 #	24 #	20 #
Minimum:	0.6	11.7	1,414.0	0.6	0.4	1	1	0
Maximum:	0.7	13.8	2,137.2	0.7	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/04/2014 00:00	0.7	13.0	1,892.6	0.7	0.6	1	1	1
08/04/2014 01:00	0.7	12.9	1,923.8	0.7	0.6	1	1	1
08/04/2014 02:00	0.7	13.1	1,885.6	0.7	0.6	1	1	1
08/04/2014 03:00	0.7	12.9	1,938.1	0.7	0.6	1	1	1
08/04/2014 04:00	0.7	13.2	1,861.5	0.7	0.6	1	1	1
08/04/2014 05:00	0.7	13.0	1,829.8	0.7	0.5	1	1	1
08/04/2014 06:00	0.6	13.7	1,696.5	0.6	0.5	1	1	0
08/04/2014 07:00	0.6	13.7	1,680.4	0.6	0.5	1	1	0
08/04/2014 08:00	0.6	13.6	1,763.6	0.6	0.5	1	1	0
08/04/2014 09:00	0.6	13.6	1,757.1	0.6	0.5	1	1	0
08/04/2014 10:00	0.7	13.2	1,802.9	0.7	0.5	1	1	1
08/04/2014 11:00	0.7	12.8	1,925.6	0.7	0.6	1	1	1
08/04/2014 12:00	0.7	13.1	1,859.1	0.7	0.6	1	1	1
08/04/2014 13:00	0.7	13.1	1,862.8	0.7	0.6	1	1	1
08/04/2014 14:00	0.7	13.1	1,864.5	0.7	0.6	1	1	1
08/04/2014 15:00	0.7	13.0	1,863.9	0.7	0.6	1	1	1
08/04/2014 16:00	0.7	13.0	1,864.4	0.7	0.6	1	1	1
08/04/2014 17:00	0.7	13.1	1,863.2	0.7	0.6	1	1	1
08/04/2014 18:00	0.7	13.1	1,860.6	0.7	0.6	1	1	1
08/04/2014 19:00	0.7	13.1	1,859.5	0.7	0.6	1	1	1
08/04/2014 20:00	0.7	13.1	1,859.2	0.7	0.6	1	1	1
08/04/2014 21:00	0.7	13.3	1,589.4	0.7	0.5	1	1	1
08/04/2014 22:00	0.6	13.8	1,284.4	0.6	0.4	1	1	0
08/04/2014 23:00	0.6	13.7	1,609.1	0.6	0.5	1	1	0
Average/Sum#:	0.7	13.2	1,799.9	0.7	0.6	24 #	24 #	18 #
Minimum:	0.6	12.8	1,284.4	0.6	0.4	1	1	0
Maximum:	0.7	13.8	1,938.1	0.7	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/05/2014 00:00	0.7	13.4	1,765.9	0.7	0.5	1	1	1
08/05/2014 01:00	0.7	12.9	1,920.5	0.7	0.6	1	1	1
08/05/2014 02:00	0.7	12.7	1,955.5	0.7	0.6	1	1	1
08/05/2014 03:00	0.7	12.8	1,927.2	0.7	0.6	1	1	1
08/05/2014 04:00	0.7	12.8	1,934.7	0.7	0.6	1	1	1
08/05/2014 05:00	0.7	13.2	1,859.6	0.7	0.6	1	1	1
08/05/2014 06:00	0.7	13.0	1,896.0	0.7	0.6	1	1	1
08/05/2014 07:00	0.7	13.8	1,299.1	0.7	0.4	1	1	1
08/05/2014 08:00	0.6	13.8	1,254.9	0.6	0.4	1	1	0
08/05/2014 09:00	0.7	13.3	1,572.9	0.7	0.5	1	1	1
08/05/2014 10:00	0.7	13.1	1,866.4	0.7	0.6	1	1	1
08/05/2014 11:00	0.7	13.1	1,874.0	0.7	0.6	1	1	1
08/05/2014 12:00	0.7	12.9	1,911.7	0.7	0.6	1	1	1
08/05/2014 13:00	0.7	12.7	1,945.9	0.7	0.6	1	1	1
08/05/2014 14:00	0.7	12.7	1,955.0	0.7	0.6	1	1	1
08/05/2014 15:00	0.7	12.5	1,991.3	0.7	0.6	1	1	1
08/05/2014 16:00	0.7	12.7	1,943.3	0.7	0.6	1	1	1
08/05/2014 17:00	0.7	12.7	1,955.4	0.7	0.6	1	1	1
08/05/2014 18:00	0.7	12.6	1,968.0	0.7	0.6	1	1	1
08/05/2014 19:00	0.7	12.6	1,979.6	0.7	0.6	1	1	1
08/05/2014 20:00	0.7	12.8	1,913.2	0.7	0.6	1	1	1
08/05/2014 21:00	0.7	12.8	1,927.7	0.7	0.6	1	1	1
08/05/2014 22:00	0.7	13.4	1,476.3	0.7	0.4	1	1	1
08/05/2014 23:00	0.7	13.5	1,530.0	0.7	0.5	1	1	1
Average/Sum#:	0.7	13.0	1,817.7	0.7	0.6	24 #	24 #	23 #
Minimum:	0.6	12.5	1,254.9	0.6	0.4	1	1	0
Maximum:	0.7	13.8	1,991.3	0.7	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/06/2014 00:00	0.7	12.7	1,962.1	0.7	0.6	1	1	1
08/06/2014 01:00	0.7	12.6	1,984.1	0.7	0.6	1	1	1
08/06/2014 02:00	0.7	12.8	1,920.2	0.7	0.6	1	1	1
08/06/2014 03:00	0.7	13.1	1,865.4	0.7	0.6	1	1	1
08/06/2014 04:00	0.7	12.5	1,991.2	0.7	0.6	1	1	1
08/06/2014 05:00	0.7	12.4	2,029.4	0.7	0.6	1	1	1
08/06/2014 06:00	0.7	12.7	1,958.3	0.7	0.6	1	1	1
08/06/2014 07:00	0.7	12.8	1,933.2	0.7	0.6	1	1	1
08/06/2014 08:00	0.7	12.5	1,985.5	0.7	0.6	1	1	1
08/06/2014 09:00	0.7	12.3	2,037.1	0.7	0.6	1	1	1
08/06/2014 10:00	0.7	12.1	2,054.2	0.7	0.6	1	1	1
08/06/2014 11:00	0.7	12.0	2,073.7	0.7	0.6	1	1	1
08/06/2014 12:00	0.7	12.2	2,035.3	0.7	0.6	1	1	1
08/06/2014 13:00	0.7	12.2	2,023.0	0.7	0.6	1	1	1
08/06/2014 14:00	0.7	11.9	2,086.0	0.7	0.6	1	1	1
08/06/2014 15:00	0.7	12.2	2,007.1	0.7	0.6	1	1	1
08/06/2014 16:00	0.7	12.9	1,877.3	0.7	0.6	1	1	1
08/06/2014 17:00	0.7	12.5	1,960.3	0.7	0.6	1	1	1
08/06/2014 18:00	0.7	12.4	1,975.8	0.7	0.6	1	1	1
08/06/2014 19:00	0.7	12.2	2,017.0	0.7	0.6	1	1	1
08/06/2014 20:00	0.7	12.2	2,015.5	0.7	0.6	1	1	1
08/06/2014 21:00	0.7	12.6	1,935.0	0.7	0.6	1	1	1
08/06/2014 22:00	0.7	13.4	1,460.5	0.7	0.4	1	1	1
08/06/2014 23:00	0.6	13.7	1,659.5	0.6	0.5	1	1	0
Average/Sum#:	0.7	12.5	1,951.9	0.7	0.6	24 #	24 #	23 #
Minimum:	0.6	11.9	1,460.5	0.6	0.4	1	1	0
Maximum:	0.7	13.7	2,086.0	0.7	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/07/2014 00:00	0.0	14.3	1,138.0	0.0	0.3	1	0	0
08/07/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 07:00	0.0	17.2	504.2	0.0	0.2	1	0	0
08/07/2014 08:00	0.0	14.6	1,012.1	0.0	0.3	1	0	0
08/07/2014 09:00	0.6	13.9	1,340.3	0.6	0.4	1	1	0
08/07/2014 10:00	0.6	13.8	1,522.7	0.6	0.5	1	1	0
08/07/2014 11:00	0.6	13.6	1,721.7	0.6	0.5	1	1	0
08/07/2014 12:00	0.6	13.6	1,714.6	0.6	0.5	1	1	0
08/07/2014 13:00	0.6	13.6	1,711.7	0.6	0.5	1	1	0
08/07/2014 14:00	0.6	13.6	1,707.5	0.6	0.5	1	1	0
08/07/2014 15:00	0.7	13.0	1,721.9	0.7	0.5	1	1	1
08/07/2014 16:00	0.7	12.1	2,036.1	0.7	0.6	1	1	1
08/07/2014 17:00	0.7	11.6	2,128.9	0.7	0.6	1	1	1
08/07/2014 18:00	0.7	11.9	2,058.1	0.7	0.6	1	1	1
08/07/2014 19:00	0.7	12.3	2,003.3	0.7	0.6	1	1	1
08/07/2014 20:00	0.7	12.9	1,869.2	0.7	0.6	1	1	1
08/07/2014 21:00	0.7	12.8	1,899.9	0.7	0.6	1	1	1
08/07/2014 22:00	0.7	13.1	1,842.8	0.7	0.6	1	1	1
08/07/2014 23:00	0.7	13.2	1,829.5	0.7	0.5	1	1	1
Average/Sum#:	0.6	13.4	1,653.5	0.6	0.5	18 #	15 #	9 #
Minimum:	0.0	11.6	504.2	0.0	0.2	0	0	0
Maximum:	0.7	17.2	2,128.9	0.7	0.6	1	1	1
%SI	25.0	25.0	25.0	25.0	25.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/08/2014 00:00	0.7	12.8	1,945.3	0.7	0.6	1	1	1
08/08/2014 01:00	0.7	12.9	1,930.8	0.7	0.6	1	1	1
08/08/2014 02:00	0.7	13.3	1,844.6	0.7	0.6	1	1	1
08/08/2014 03:00	0.7	13.0	1,899.5	0.7	0.6	1	1	1
08/08/2014 04:00	0.7	12.9	1,934.3	0.7	0.6	1	1	1
08/08/2014 05:00	0.7	12.7	1,989.4	0.7	0.6	1	1	1
08/08/2014 06:00	0.7	12.6	1,990.0	0.7	0.6	1	1	1
08/08/2014 07:00	0.7	12.8	1,948.3	0.7	0.6	1	1	1
08/08/2014 08:00	0.7	13.0	1,900.5	0.7	0.6	1	1	1
08/08/2014 09:00	0.7	11.7	2,171.3	0.7	0.7	1	1	1
08/08/2014 10:00	0.7	12.0	2,064.6	0.7	0.6	1	1	1
08/08/2014 11:00	0.7	13.0	1,866.0	0.7	0.6	1	1	1
08/08/2014 12:00	0.7	12.8	1,900.6	0.7	0.6	1	1	1
08/08/2014 13:00	0.7	12.2	2,024.7	0.7	0.6	1	1	1
08/08/2014 14:00	0.7	11.6	2,148.5	0.7	0.6	1	1	1
08/08/2014 15:00	0.7	11.5	2,154.6	0.7	0.6	1	1	1
08/08/2014 16:00	0.7	11.6	2,143.8	0.7	0.6	1	1	1
08/08/2014 17:00	0.7	12.0	2,060.4	0.7	0.6	1	1	1
08/08/2014 18:00	0.7	11.4	2,178.8	0.7	0.7	1	1	1
08/08/2014 19:00	0.7	11.8	2,103.5	0.7	0.6	1	1	1
08/08/2014 20:00	0.7	12.3	2,005.2	0.7	0.6	1	1	1
08/08/2014 21:00	0.7	12.4	1,989.2	0.7	0.6	1	1	1
08/08/2014 22:00	0.7	12.8	1,896.9	0.7	0.6	1	1	1
08/08/2014 23:00	0.7	12.5	1,978.5	0.7	0.6	1	1	1
Average/Sum#:	0.7	12.4	2,002.9	0.7	0.6	24 #	24 #	24 #
Minimum:	0.7	11.4	1,844.6	0.7	0.6	1	1	1
Maximum:	0.7	13.3	2,178.8	0.7	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/09/2014 00:00	0.7	13.6	1,691.6	0.7	0.5	1	1	1
08/09/2014 01:00	0.6	13.7	1,541.2	0.6	0.5	1	1	0
08/09/2014 02:00	0.0	15.7	614.9	0.0	0.2	1	0	0
08/09/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/09/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/09/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/09/2014 06:00	0.0	16.2	585.4	0.0	0.2	1	0	0
08/09/2014 07:00	0.0	13.9	1,381.8	0.0	0.4	1	0	0
08/09/2014 08:00	0.6	13.9	1,346.9	0.6	0.4	1	1	0
08/09/2014 09:00	0.6	13.8	1,624.9	0.6	0.5	1	1	0
08/09/2014 10:00	0.6	13.7	1,741.7	0.6	0.5	1	1	0
08/09/2014 11:00	0.6	13.9	1,561.6	0.6	0.5	1	1	0
08/09/2014 12:00	0.7	13.7	1,469.0	0.7	0.4	1	1	1
08/09/2014 13:00	0.7	13.0	1,878.8	0.7	0.6	1	1	1
08/09/2014 14:00	0.7	12.9	1,905.5	0.7	0.6	1	1	1
08/09/2014 15:00	0.7	12.6	1,958.5	0.7	0.6	1	1	1
08/09/2014 16:00	0.7	12.6	1,938.9	0.7	0.6	1	1	1
08/09/2014 17:00	0.7	12.7	1,927.9	0.7	0.6	1	1	1
08/09/2014 18:00	0.7	12.1	2,053.3	0.7	0.6	1	1	1
08/09/2014 19:00	0.7	11.4	2,217.4	0.7	0.7	1	1	1
08/09/2014 20:00	0.7	11.8	2,139.7	0.7	0.6	1	1	1
08/09/2014 21:00	0.7	11.9	2,111.1	0.7	0.6	1	1	1
08/09/2014 22:00	0.7	12.5	2,014.2	0.7	0.6	1	1	1
08/09/2014 23:00	0.7	13.3	1,686.7	0.7	0.5	1	1	1
Average/Sum#:	0.6	13.3	1,685.3	0.6	0.5	21 #	18 #	13 #
Minimum:	0.0	11.4	585.4	0.0	0.2	0	0	0
Maximum:	0.7	16.2	2,217.4	0.7	0.7	1	1	1
%SI	12.5	12.5	12.5	12.5	12.5	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/10/2014 00:00	0.0	15.6	607.0	0.0	0.2	1	0	0
08/10/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2014 07:00	0.0	16.9	547.6	0.0	0.2	1	0	0
08/10/2014 08:00	0.0	14.2	1,225.8	0.0	0.4	1	0	0
08/10/2014 09:00	0.6	13.8	1,345.3	0.6	0.4	1	1	0
08/10/2014 10:00	0.6	13.8	1,700.9	0.6	0.5	1	1	0
08/10/2014 11:00	0.6	13.9	1,609.6	0.6	0.5	1	1	0
08/10/2014 12:00	0.7	13.8	1,587.3	0.7	0.5	1	1	1
08/10/2014 13:00	0.7	12.6	1,955.0	0.7	0.6	1	1	1
08/10/2014 14:00	0.7	12.6	1,957.4	0.7	0.6	1	1	1
08/10/2014 15:00	0.7	12.8	1,917.9	0.7	0.6	1	1	1
08/10/2014 16:00	0.7	12.3	2,022.9	0.7	0.6	1	1	1
08/10/2014 17:00	0.7	11.4	2,205.5	0.7	0.7	1	1	1
08/10/2014 18:00	0.7	11.5	2,192.1	0.7	0.7	1	1	1
08/10/2014 19:00	0.7	11.5	2,194.7	0.7	0.7	1	1	1
08/10/2014 20:00	0.7	11.6	2,176.5	0.7	0.7	1	1	1
08/10/2014 21:00	0.7	11.9	2,121.1	0.7	0.6	1	1	1
08/10/2014 22:00	0.7	12.8	1,935.3	0.7	0.6	1	1	1
08/10/2014 23:00	0.7	12.6	1,989.6	0.7	0.6	1	1	1
Average/Sum#:	0.6	13.1	1,738.4	0.6	0.5	18 #	15 #	12 #
Minimum:	0.0	11.4	547.6	0.0	0.2	0	0	0
Maximum:	0.7	16.9	2,205.5	0.7	0.7	1	1	1
%SI	25.0	25.0	25.0	25.0	25.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/11/2014 00:00	0.7	12.6	1,986.3	0.7	0.6	1	1	1
08/11/2014 01:00	0.7	12.6	1,991.7	0.7	0.6	1	1	1
08/11/2014 02:00	0.7	12.8	1,947.4	0.7	0.6	1	1	1
08/11/2014 03:00	0.7	12.6	1,993.3	0.7	0.6	1	1	1
08/11/2014 04:00	0.7	12.6	2,006.6	0.7	0.6	1	1	1
08/11/2014 05:00	0.7	12.9	1,956.2	0.7	0.6	1	1	1
08/11/2014 06:00	0.7	11.8	2,184.5	0.7	0.7	1	1	1
08/11/2014 07:00	0.7	12.5	2,008.9	0.7	0.6	1	1	1
08/11/2014 08:00	0.7	12.5	1,991.8	0.7	0.6	1	1	1
08/11/2014 09:00	0.7	11.5	2,219.1	0.7	0.7	1	1	1
08/11/2014 10:00	0.7	11.2	2,258.0	0.7	0.7	1	1	1
08/11/2014 11:00	0.7	11.2	2,267.0	0.7	0.7	1	1	1
08/11/2014 12:00	0.7	11.2	2,255.0	0.7	0.7	1	1	1
08/11/2014 13:00	0.7	11.3	2,232.9	0.7	0.7	1	1	1
08/11/2014 14:00	0.7	11.4	2,219.4	0.7	0.7	1	1	1
08/11/2014 15:00	0.7	11.4	2,216.0	0.7	0.7	1	1	1
08/11/2014 16:00	0.7	11.3	2,215.9	0.7	0.7	1	1	1
08/11/2014 17:00	0.7	11.3	2,214.0	0.7	0.7	1	1	1
08/11/2014 18:00	0.7	11.3	2,214.8	0.7	0.7	1	1	1
08/11/2014 19:00	0.7	11.3	2,239.7	0.7	0.7	1	1	1
08/11/2014 20:00	0.7	11.4	2,207.7	0.7	0.7	1	1	1
08/11/2014 21:00	0.7	12.5	1,939.4	0.7	0.6	1	1	1
08/11/2014 22:00	0.6	13.8	1,687.3	0.6	0.5	1	1	0
08/11/2014 23:00	0.6	13.8	1,677.6	0.6	0.5	1	1	0
Average/Sum#:	0.7	12.0	2,088.8	0.7	0.6	24 #	24 #	22 #
Minimum:	0.6	11.2	1,677.6	0.6	0.5	1	1	0
Maximum:	0.7	13.8	2,267.0	0.7	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/12/2014 00:00	0.6	13.8	1,633.0	0.6	0.5	1	1	0
08/12/2014 01:00	0.6	13.8	1,658.0	0.6	0.5	1	1	0
08/12/2014 02:00	0.6	13.8	1,536.7	0.6	0.5	1	1	0
08/12/2014 03:00	0.6	13.8	1,529.4	0.6	0.5	1	1	0
08/12/2014 04:00	0.6	13.8	1,691.4	0.6	0.5	1	1	0
08/12/2014 05:00	0.6	13.7	1,760.4	0.6	0.5	1	1	0
08/12/2014 06:00	0.6	13.7	1,760.4	0.6	0.5	1	1	0
08/12/2014 07:00	0.6	13.7	1,721.7	0.6	0.5	1	1	0
08/12/2014 08:00	0.6	13.8	1,311.0	0.6	0.4	1	1	0
08/12/2014 09:00	0.6	13.8	1,638.2	0.6	0.5	1	1	0
08/12/2014 10:00	0.6	13.7	1,747.0	0.6	0.5	1	1	0
08/12/2014 11:00	0.6	13.8	1,643.3	0.6	0.5	1	1	0
08/12/2014 12:00	0.6	13.6	1,737.2	0.6	0.5	1	1	0
08/12/2014 13:00	0.6	13.7	1,732.5	0.6	0.5	1	1	0
08/12/2014 14:00	0.6	13.6	1,731.4	0.6	0.5	1	1	0
08/12/2014 15:00	0.6	13.6	1,730.6	0.6	0.5	1	1	0
08/12/2014 16:00	0.6	13.7	1,731.1	0.6	0.5	1	1	0
08/12/2014 17:00	0.6	13.7	1,734.5	0.6	0.5	1	1	0
08/12/2014 18:00	0.6	13.6	1,739.1	0.6	0.5	1	1	0
08/12/2014 19:00	0.6	13.7	1,749.3	0.6	0.5	1	1	0
08/12/2014 20:00	0.6	13.7	1,752.8	0.6	0.5	1	1	0
08/12/2014 21:00	0.6	13.7	1,756.9	0.6	0.5	1	1	0
08/12/2014 22:00	0.6	13.7	1,766.9	0.6	0.5	1	1	0
08/12/2014 23:00	0.6	13.7	1,768.4	0.6	0.5	1	1	0
Average/Sum#:	0.6	13.7	1,690.1	0.6	0.5	24 #	24 #	0 #
Minimum:	0.6	13.6	1,311.0	0.6	0.4	1	1	0
Maximum:	0.6	13.8	1,768.4	0.6	0.5	1	1	0
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/13/2014 00:00	0.6	13.7	1,770.8	0.6	0.5	1	1	0
08/13/2014 01:00	0.0	14.4	1,364.5	0.0	0.4	1	0	0
08/13/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2014 05:00	0.0	17.0	568.8	0.0	0.2	1	0	0
08/13/2014 06:00	0.0	13.7	1,726.2	0.0	0.5	1	0	0
08/13/2014 07:00	0.6	13.7	1,787.3	0.6	0.5	1	1	0
08/13/2014 08:00	0.6	13.7	1,777.7	0.6	0.5	1	1	0
08/13/2014 09:00	0.6	13.6	1,771.8	0.6	0.5	1	1	0
08/13/2014 10:00	0.6	13.6	1,763.6	0.6	0.5	1	1	0
08/13/2014 11:00	0.6	13.6	1,756.1	0.6	0.5	1	1	0
08/13/2014 12:00	0.6	13.6	1,749.4	0.6	0.5	1	1	0
08/13/2014 13:00	0.6	13.6	1,741.5	0.6	0.5	1	1	0
08/13/2014 14:00	0.6	13.6	1,732.9	0.6	0.5	1	1	0
08/13/2014 15:00	0.6	13.6	1,731.4	0.6	0.5	1	1	0
08/13/2014 16:00	0.6	13.6	1,729.4	0.6	0.5	1	1	0
08/13/2014 17:00	0.6	13.6	1,729.3	0.6	0.5	1	1	0
08/13/2014 18:00	0.6	13.6	1,731.9	0.6	0.5	1	1	0
08/13/2014 19:00	0.6	13.6	1,739.3	0.6	0.5	1	1	0
08/13/2014 20:00	0.6	13.6	1,748.6	0.6	0.5	1	1	0
08/13/2014 21:00	0.6	13.7	1,733.5	0.6	0.5	1	1	0
08/13/2014 22:00	0.6	13.8	1,652.4	0.6	0.5	1	1	0
08/13/2014 23:00	0.0	14.8	961.1	0.0	0.3	1	0	0
Average/Sum#:	0.5	13.9	1,631.8	0.5	0.5	21 #	17 #	0 #
Minimum:	0.0	13.6	568.8	0.0	0.2	0	0	0
Maximum:	0.6	17.0	1,787.3	0.6	0.5	1	1	0
%SI	12.5	12.5	12.5	12.5	12.5	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/14/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/15/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/16/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/17/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/18/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/19/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/20/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/21/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/22/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/23/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/24/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/25/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/26/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/27/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/28/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/29/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/30/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/31/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/01/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/02/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/03/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/04/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/05/2014 00:00	0.0	18.0	394.7	0.0	0.1	1	0	0
09/05/2014 01:00	0.0	16.9	549.5	0.0	0.2	1	0	0
09/05/2014 02:00	0.0	17.7	606.9	0.0	0.2	1	0	0
09/05/2014 03:00	0.0	17.7	609.8	0.0	0.2	1	0	0
09/05/2014 04:00	0.0	15.5	945.8	0.0	0.3	1	0	0
09/05/2014 05:00	0.4	13.9	1,438.9	0.4	0.4	1	1	0
09/05/2014 06:00	0.4	13.9	1,733.5	0.4	0.5	1	1	0
09/05/2014 07:00	0.4	13.9	1,728.2	0.4	0.5	1	1	0
09/05/2014 08:00	0.4	13.8	1,654.6	0.4	0.5	1	1	0
09/05/2014 09:00	0.4	13.9	1,420.2	0.4	0.4	1	1	0
09/05/2014 10:00	0.4	13.9	1,267.8	0.4	0.4	1	1	0
09/05/2014 11:00	0.4	14.0	1,368.1	0.4	0.4	1	1	0
09/05/2014 12:00	0.2	13.7	1,673.5	0.4	0.5	1	1	1
09/05/2014 13:00	-0.2	12.8	1,942.7	0.1	0.6	1	1	1
09/05/2014 14:00	-0.2	12.8	1,925.9	0.1	0.6	1	1	1
09/05/2014 15:00	-0.2	12.6	1,963.4	0.1	0.6	1	1	1
09/05/2014 16:00	-0.2	12.6	1,971.1	0.1	0.6	1	1	1
09/05/2014 17:00	0.1	11.7	2,184.5	0.2	0.7	1	1	1
09/05/2014 18:00	-0.1	12.2	2,067.3	0.2	0.6	1	1	1
09/05/2014 19:00	-0.2	12.6	1,974.3	0.1	0.6	1	1	1
09/05/2014 20:00	-0.1	13.1	1,867.6	0.1	0.6	1	1	1
09/05/2014 21:00	-0.2	12.8	1,941.9	0.1	0.6	1	1	1
09/05/2014 22:00	-0.2	12.8	1,949.6	0.1	0.6	1	1	1
09/05/2014 23:00	0.1	11.7	2,202.5	0.2	0.7	1	1	1
Average/Sum#:	0.1	13.9	1,557.6	0.2	0.5	24 #	19 #	12 #
Minimum:	-0.2	11.7	394.7	0.0	0.1	1	0	0
Maximum:	0.4	18.0	2,202.5	0.4	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/06/2014 00:00	-0.1	12.2	2,074.3	0.2	0.6	1	1	1
09/06/2014 01:00	-0.1	12.9	1,950.6	0.1	0.6	1	1	1
09/06/2014 02:00	-0.2	12.7	1,997.0	0.1	0.6	1	1	1
09/06/2014 03:00	-0.1	12.7	1,997.8	0.1	0.6	1	1	1
09/06/2014 04:00	-0.2	12.7	1,989.4	0.1	0.6	1	1	1
09/06/2014 05:00	0.1	13.3	1,859.9	0.2	0.6	1	1	1
09/06/2014 06:00	-0.1	13.2	1,872.3	0.1	0.6	1	1	1
09/06/2014 07:00	-0.1	13.1	1,901.0	0.1	0.6	1	1	1
09/06/2014 08:00	-0.1	13.3	1,855.8	0.1	0.6	1	1	1
09/06/2014 09:00	-0.1	13.0	1,925.8	0.1	0.6	1	1	1
09/06/2014 10:00	-0.1	13.0	1,901.5	0.1	0.6	1	1	1
09/06/2014 11:00	-0.1	12.9	1,924.4	0.1	0.6	1	1	1
09/06/2014 12:00	-0.1	12.3	2,043.0	0.2	0.6	1	1	1
09/06/2014 13:00	0.1	11.5	2,214.9	0.2	0.7	1	1	1
09/06/2014 14:00	-0.1	12.1	2,071.3	0.2	0.6	1	1	1
09/06/2014 15:00	-0.2	12.4	2,012.5	0.1	0.6	1	1	1
09/06/2014 16:00	-0.1	12.5	1,986.7	0.1	0.6	1	1	1
09/06/2014 17:00	0.1	11.3	2,247.8	0.4	0.7	1	1	1
09/06/2014 18:00	0.1	11.6	2,176.0	0.2	0.7	1	1	1
09/06/2014 19:00	-0.1	13.0	1,892.4	0.1	0.6	1	1	1
09/06/2014 20:00	-0.1	13.2	1,853.9	0.1	0.6	1	1	1
09/06/2014 21:00	-0.1	13.2	1,854.6	0.1	0.6	1	1	1
09/06/2014 22:00	-0.2	13.1	1,894.5	-0.1	0.6	1	1	1
09/06/2014 23:00	-0.2	12.7	1,987.3	0.1	0.6	1	1	1
Average/Sum#:	-0.1	12.7	1,978.5	0.1	0.6	24 #	24 #	24 #
Minimum:	-0.2	11.3	1,853.9	-0.1	0.6	1	1	1
Maximum:	0.1	13.3	2,247.8	0.4	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/07/2014 00:00	-0.1	13.1	1,893.6	0.1	0.6	1	1	1
09/07/2014 01:00	-0.1	13.1	1,900.6	0.1	0.6	1	1	1
09/07/2014 02:00	-0.1	13.3	1,853.0	0.1	0.6	1	1	1
09/07/2014 03:00	-0.1	13.3	1,848.2	0.1	0.6	1	1	1
09/07/2014 04:00	-0.1	13.3	1,846.3	0.1	0.6	1	1	1
09/07/2014 05:00	-0.1	13.3	1,848.6	0.1	0.6	1	1	1
09/07/2014 06:00	-0.1	13.3	1,857.3	0.1	0.6	1	1	1
09/07/2014 07:00	-0.1	13.3	1,860.3	0.1	0.6	1	1	1
09/07/2014 08:00	-0.1	13.0	1,928.7	0.1	0.6	1	1	1
09/07/2014 09:00	-0.2	12.5	2,039.6	0.1	0.6	1	1	1
09/07/2014 10:00	0.1	12.0	2,136.4	0.2	0.6	1	1	1
09/07/2014 11:00	-0.1	12.0	2,122.4	0.2	0.6	1	1	1
09/07/2014 12:00	-0.2	12.6	1,972.4	0.1	0.6	1	1	1
09/07/2014 13:00	-0.2	12.7	1,951.2	0.1	0.6	1	1	1
09/07/2014 14:00	-0.2	12.7	1,946.3	0.1	0.6	1	1	1
09/07/2014 15:00	-0.2	12.7	1,958.1	0.1	0.6	1	1	1
09/07/2014 16:00	-0.1	12.2	2,053.6	0.2	0.6	1	1	1
09/07/2014 17:00	0.1	11.4	2,221.0	0.4	0.7	1	1	1
09/07/2014 18:00	0.2	11.4	2,223.5	0.4	0.7	1	1	1
09/07/2014 19:00	0.2	11.4	2,220.5	0.4	0.7	1	1	1
09/07/2014 20:00	0.1	12.0	2,086.4	0.2	0.6	1	1	1
09/07/2014 21:00	-0.1	13.0	1,897.3	0.1	0.6	1	1	1
09/07/2014 22:00	-0.1	13.2	1,852.4	0.1	0.6	1	1	1
09/07/2014 23:00	-0.2	13.0	1,918.4	0.1	0.6	1	1	1
Average/Sum#:	-0.1	12.7	1,976.5	0.2	0.6	24 #	24 #	24 #
Minimum:	-0.2	11.4	1,846.3	0.1	0.6	1	1	1
Maximum:	0.2	13.3	2,223.5	0.4	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/08/2014 00:00	0.1	13.6	1,499.2	0.2	0.4	1	1	1
09/08/2014 01:00	0.4	13.9	1,256.5	0.4	0.4	1	1	0
09/08/2014 02:00	0.4	13.9	1,251.7	0.4	0.4	1	1	0
09/08/2014 03:00	0.4	13.9	1,553.2	0.4	0.5	1	1	0
09/08/2014 04:00	-0.1	13.0	1,943.0	0.1	0.6	1	1	1
09/08/2014 05:00	0.1	13.2	1,898.9	0.2	0.6	1	1	1
09/08/2014 06:00	0.1	11.9	2,137.2	0.2	0.6	1	1	1
09/08/2014 07:00	0.2	11.4	2,304.7	0.4	0.7	1	1	1
09/08/2014 08:00	0.2	12.0	2,151.0	0.4	0.6	1	1	1
09/08/2014 09:00	0.1	13.3	1,860.7	0.2	0.6	1	1	1
09/08/2014 10:00	-0.1	13.4	1,840.3	0.1	0.6	1	1	1
09/08/2014 11:00	-0.1	13.4	1,837.7	0.1	0.6	1	1	1
09/08/2014 12:00	-0.1	13.3	1,838.1	0.1	0.6	1	1	1
09/08/2014 13:00	-0.1	13.3	1,839.5	0.1	0.6	1	1	1
09/08/2014 14:00	-0.1	13.2	1,844.0	0.1	0.6	1	1	1
09/08/2014 15:00	-0.1	13.2	1,850.7	0.1	0.6	1	1	1
09/08/2014 16:00	0.1	13.3	1,600.3	0.2	0.5	1	1	1
09/08/2014 17:00	0.4	13.9	1,269.8	0.4	0.4	1	1	0
09/08/2014 18:00	0.4	14.0	1,520.7	0.4	0.5	1	1	0
09/08/2014 19:00	0.4	14.0	1,535.8	0.4	0.5	1	1	0
09/08/2014 20:00	0.4	13.9	1,445.5	0.4	0.4	1	1	0
09/08/2014 21:00	0.4	13.9	1,363.3	0.4	0.4	1	1	0
09/08/2014 22:00	0.4	13.9	1,298.7	0.4	0.4	1	1	0
09/08/2014 23:00	0.4	13.9	1,255.1	0.4	0.4	1	1	0
Average/Sum#:	0.2	13.4	1,674.8	0.3	0.5	24 #	24 #	14 #
Minimum:	-0.1	11.4	1,251.7	0.1	0.4	1	1	0
Maximum:	0.4	14.0	2,304.7	0.4	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/09/2014 00:00	0.4	13.9	1,255.4	0.4	0.4	1	1	0
09/09/2014 01:00	0.4	13.9	1,255.2	0.4	0.4	1	1	0
09/09/2014 02:00	0.4	13.9	1,255.5	0.4	0.4	1	1	0
09/09/2014 03:00	0.4	13.9	1,355.0	0.4	0.4	1	1	0
09/09/2014 04:00	0.4	13.9	1,268.0	0.4	0.4	1	1	0
09/09/2014 05:00	0.4	13.8	1,305.6	0.4	0.4	1	1	0
09/09/2014 06:00	0.4	13.9	1,261.0	0.4	0.4	1	1	0
09/09/2014 07:00	0.4	13.9	1,269.1	0.4	0.4	1	1	0
09/09/2014 08:00	0.2	13.7	1,561.7	0.4	0.5	1	1	1
09/09/2014 09:00	0.1	13.2	1,878.8	0.2	0.6	1	1	1
09/09/2014 10:00	0.2	13.2	1,866.2	0.4	0.6	1	1	1
09/09/2014 11:00	0.2	13.1	1,859.4	0.4	0.6	1	1	1
09/09/2014 12:00	0.1	12.8	1,928.1	0.2	0.6	1	1	1
09/09/2014 13:00	0.1	12.7	1,935.9	0.2	0.6	1	1	1
09/09/2014 14:00	0.2	12.8	1,903.2	0.4	0.6	1	1	1
09/09/2014 15:00	0.2	12.9	1,881.4	0.4	0.6	1	1	1
09/09/2014 16:00	0.1	12.9	1,878.8	0.2	0.6	1	1	1
09/09/2014 17:00	0.1	12.8	1,892.9	0.2	0.6	1	1	1
09/09/2014 18:00	0.1	12.9	1,874.2	0.2	0.6	1	1	1
09/09/2014 19:00	0.1	13.0	1,869.3	0.2	0.6	1	1	1
09/09/2014 20:00	0.1	13.0	1,891.7	0.2	0.6	1	1	1
09/09/2014 21:00	0.1	12.8	1,927.3	0.2	0.6	1	1	1
09/09/2014 22:00	0.1	12.9	1,907.5	0.2	0.6	1	1	1
09/09/2014 23:00	0.1	12.4	2,017.2	0.2	0.6	1	1	1
Average/Sum#:	0.2	13.3	1,679.1	0.3	0.5	24 #	24 #	16 #
Minimum:	0.1	12.4	1,255.2	0.2	0.4	1	1	0
Maximum:	0.4	13.9	2,017.2	0.4	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/10/2014 00:00	0.1	12.4	2,015.0	0.2	0.6	1	1	1
09/10/2014 01:00	0.1	12.5	2,015.7	0.2	0.6	1	1	1
09/10/2014 02:00	0.2	12.9	1,908.0	0.4	0.6	1	1	1
09/10/2014 03:00	0.2	12.6	1,981.7	0.4	0.6	1	1	1
09/10/2014 04:00	0.2	12.3	2,039.3	0.4	0.6	1	1	1
09/10/2014 05:00	0.1	12.7	1,967.1	0.2	0.6	1	1	1
09/10/2014 06:00	0.2	13.3	1,866.7	0.4	0.6	1	1	1
09/10/2014 07:00	0.2	13.2	1,861.4	0.4	0.6	1	1	1
09/10/2014 08:00	0.2	13.2	1,859.8	0.4	0.6	1	1	1
09/10/2014 09:00	0.1	12.8	1,921.7	0.2	0.6	1	1	1
09/10/2014 10:00	0.4	13.6	1,542.0	0.4	0.5	1	1	1
09/10/2014 11:00	0.4	13.9	1,261.4	0.4	0.4	1	1	0
09/10/2014 12:00	0.1	13.4	1,718.5	0.2	0.5	1	1	1
09/10/2014 13:00	-0.2	12.8	1,940.3	0.1	0.6	1	1	1
09/10/2014 14:00	-0.2	12.6	1,992.7	0.1	0.6	1	1	1
09/10/2014 15:00	0.1	11.6	2,204.7	0.2	0.7	1	1	1
09/10/2014 16:00	0.1	11.3	2,252.6	0.4	0.7	1	1	1
09/10/2014 17:00	0.1	11.3	2,252.2	0.4	0.7	1	1	1
09/10/2014 18:00	0.1	11.4	2,234.5	0.4	0.7	1	1	1
09/10/2014 19:00	0.1	11.7	2,187.6	0.2	0.7	1	1	1
09/10/2014 20:00	-0.1	12.0	2,114.3	0.2	0.6	1	1	1
09/10/2014 21:00	-0.1	12.3	2,058.5	0.2	0.6	1	1	1
09/10/2014 22:00	-0.2	12.5	2,044.6	0.1	0.6	1	1	1
09/10/2014 23:00	-0.1	12.1	2,129.8	0.2	0.6	1	1	1
Average/Sum#:	0.1	12.5	1,973.8	0.3	0.6	24 #	24 #	23 #
Minimum:	-0.2	11.3	1,261.4	0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,252.6	0.4	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/11/2014 00:00	-0.2	12.8	1,978.5	0.1	0.6	1	1	1
09/11/2014 01:00	-0.1	13.3	1,866.1	0.1	0.6	1	1	1
09/11/2014 02:00	-0.1	13.3	1,866.1	0.1	0.6	1	1	1
09/11/2014 03:00	-0.1	13.3	1,866.3	0.1	0.6	1	1	1
09/11/2014 04:00	-0.2	12.9	1,947.3	0.1	0.6	1	1	1
09/11/2014 05:00	-0.2	12.3	2,091.1	0.1	0.6	1	1	1
09/11/2014 06:00	-0.2	12.7	2,007.5	0.1	0.6	1	1	1
09/11/2014 07:00	-0.2	12.7	1,992.8	0.1	0.6	1	1	1
09/11/2014 08:00	-0.2	12.8	1,967.4	0.1	0.6	1	1	1
09/11/2014 09:00	-0.2	12.6	2,014.9	0.1	0.6	1	1	1
09/11/2014 10:00	-0.1	12.1	2,107.0	0.2	0.6	1	1	1
09/11/2014 11:00	0.1	11.9	2,136.1	0.2	0.6	1	1	1
09/11/2014 12:00	-0.1	12.8	1,925.1	0.1	0.6	1	1	1
09/11/2014 13:00	-0.2	12.9	1,914.3	0.1	0.6	1	1	1
09/11/2014 14:00	-0.2	12.9	1,893.0	0.1	0.6	1	1	1
09/11/2014 15:00	-0.2	12.9	1,886.7	0.1	0.6	1	1	1
09/11/2014 16:00	-0.1	12.0	2,093.8	0.2	0.6	1	1	1
09/11/2014 17:00	0.1	11.4	2,219.1	0.4	0.7	1	1	1
09/11/2014 18:00	0.1	11.3	2,243.3	0.4	0.7	1	1	1
09/11/2014 19:00	0.1	11.7	2,182.1	0.2	0.7	1	1	1
09/11/2014 20:00	0.1	11.6	2,186.9	0.2	0.7	1	1	1
09/11/2014 21:00	-0.1	12.4	2,024.0	0.2	0.6	1	1	1
09/11/2014 22:00	-0.2	12.3	2,065.7	0.1	0.6	1	1	1
09/11/2014 23:00	0.2	11.5	2,261.1	0.4	0.7	1	1	1
Average/Sum#:	-0.1	12.4	2,030.7	0.2	0.6	24 #	24 #	24 #
Minimum:	-0.2	11.3	1,866.1	0.1	0.6	1	1	1
Maximum:	0.2	13.3	2,261.1	0.4	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/12/2014 00:00	0.1	11.8	2,177.1	0.2	0.7	1	1	1
09/12/2014 01:00	0.1	12.8	1,933.6	0.2	0.6	1	1	1
09/12/2014 02:00	0.2	12.3	2,020.5	0.4	0.6	1	1	1
09/12/2014 03:00	0.2	12.2	2,048.6	0.4	0.6	1	1	1
09/12/2014 04:00	0.2	11.5	2,249.6	0.4	0.7	1	1	1
09/12/2014 05:00	0.1	11.7	2,218.6	0.2	0.7	1	1	1
09/12/2014 06:00	0.2	11.6	2,260.9	0.4	0.7	1	1	1
09/12/2014 07:00	0.2	11.6	2,238.1	0.4	0.7	1	1	1
09/12/2014 08:00	0.1	11.9	2,161.1	0.2	0.6	1	1	1
09/12/2014 09:00	0.2	11.5	2,242.5	0.4	0.7	1	1	1
09/12/2014 10:00	0.2	11.6	2,227.8	0.4	0.7	1	1	1
09/12/2014 11:00	0.2	11.5	2,220.7	0.4	0.7	1	1	1
09/12/2014 12:00	0.2	11.4	2,232.4	0.4	0.7	1	1	1
09/12/2014 13:00	0.2	11.3	2,238.3	0.4	0.7	1	1	1
09/12/2014 14:00	0.1	11.4	2,213.7	0.4	0.7	1	1	1
09/12/2014 15:00	0.1	11.4	2,210.8	0.4	0.7	1	1	1
09/12/2014 16:00	0.1	11.4	2,204.4	0.4	0.7	1	1	1
09/12/2014 17:00	0.2	11.3	2,226.8	0.4	0.7	1	1	1
09/12/2014 18:00	0.2	11.4	2,233.1	0.4	0.7	1	1	1
09/12/2014 19:00	0.2	11.3	2,254.5	0.4	0.7	1	1	1
09/12/2014 20:00	0.1	11.7	2,196.1	0.2	0.7	1	1	1
09/12/2014 21:00	0.1	12.0	2,118.2	0.2	0.6	1	1	1
09/12/2014 22:00	-0.1	12.6	1,977.0	0.1	0.6	1	1	1
09/12/2014 23:00	-0.2	12.7	1,978.2	0.1	0.6	1	1	1
Average/Sum#:	0.1	11.7	2,170.1	0.3	0.7	24 #	24 #	24 #
Minimum:	-0.2	11.3	1,933.6	0.1	0.6	1	1	1
Maximum:	0.2	12.8	2,260.9	0.4	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/13/2014 00:00	-0.2	12.7	1,971.4	0.1	0.6	1	1	1
09/13/2014 01:00	-0.1	12.9	1,940.6	0.1	0.6	1	1	1
09/13/2014 02:00	0.1	13.4	1,793.4	0.2	0.5	1	1	1
09/13/2014 03:00	-0.1	13.2	1,866.2	0.1	0.6	1	1	1
09/13/2014 04:00	-0.1	13.3	1,790.6	0.1	0.5	1	1	1
09/13/2014 05:00	0.4	13.9	1,261.6	0.4	0.4	1	1	0
09/13/2014 06:00	0.4	13.9	1,255.0	0.4	0.4	1	1	0
09/13/2014 07:00	0.4	13.9	1,254.4	0.4	0.4	1	1	0
09/13/2014 08:00	0.4	13.9	1,392.3	0.4	0.4	1	1	0
09/13/2014 09:00	0.4	14.0	1,514.4	0.4	0.5	1	1	0
09/13/2014 10:00	0.4	13.8	1,577.1	0.4	0.5	1	1	1
09/13/2014 11:00	-0.2	12.5	2,017.7	0.1	0.6	1	1	1
09/13/2014 12:00	-0.1	11.8	2,152.4	0.2	0.6	1	1	1
09/13/2014 13:00	-0.2	12.2	2,037.1	0.1	0.6	1	1	1
09/13/2014 14:00	-0.1	12.1	2,049.9	0.2	0.6	1	1	1
09/13/2014 15:00	0.1	11.7	2,155.8	0.2	0.6	1	1	1
09/13/2014 16:00	0.1	11.7	2,140.6	0.2	0.6	1	1	1
09/13/2014 17:00	-0.1	11.8	2,107.7	0.2	0.6	1	1	1
09/13/2014 18:00	-0.2	12.4	1,993.3	0.1	0.6	1	1	1
09/13/2014 19:00	-0.2	12.2	2,039.3	0.1	0.6	1	1	1
09/13/2014 20:00	-0.2	12.6	1,977.7	0.1	0.6	1	1	1
09/13/2014 21:00	-0.2	12.6	1,971.8	0.1	0.6	1	1	1
09/13/2014 22:00	-0.2	12.8	1,933.4	0.1	0.6	1	1	1
09/13/2014 23:00	-0.2	12.7	1,966.1	0.1	0.6	1	1	1
Average/Sum#:	0.0	12.8	1,840.0	0.2	0.6	24 #	24 #	19 #
Minimum:	-0.2	11.7	1,254.4	0.1	0.4	1	1	0
Maximum:	0.4	14.0	2,155.8	0.4	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/14/2014 00:00	-0.1	12.9	1,918.3	0.1	0.6	1	1	1
09/14/2014 01:00	-0.1	13.2	1,867.8	0.1	0.6	1	1	1
09/14/2014 02:00	-0.1	13.3	1,863.4	0.1	0.6	1	1	1
09/14/2014 03:00	-0.2	13.2	1,864.9	-0.1	0.6	1	1	1
09/14/2014 04:00	-0.2	13.3	1,801.4	-0.1	0.5	1	1	1
09/14/2014 05:00	0.4	13.9	1,266.4	0.4	0.4	1	1	0
09/14/2014 06:00	0.4	13.9	1,256.6	0.4	0.4	1	1	0
09/14/2014 07:00	0.4	13.9	1,256.7	0.4	0.4	1	1	0
09/14/2014 08:00	0.4	13.9	1,439.5	0.4	0.4	1	1	0
09/14/2014 09:00	0.1	13.5	1,631.6	0.2	0.5	1	1	1
09/14/2014 10:00	-0.2	12.9	1,923.7	0.1	0.6	1	1	1
09/14/2014 11:00	-0.2	12.6	1,976.9	0.1	0.6	1	1	1
09/14/2014 12:00	0.1	11.4	2,233.9	0.4	0.7	1	1	1
09/14/2014 13:00	0.1	11.3	2,250.6	0.4	0.7	1	1	1
09/14/2014 14:00	0.1	11.3	2,250.5	0.4	0.7	1	1	1
09/14/2014 15:00	0.1	11.3	2,239.0	0.4	0.7	1	1	1
09/14/2014 16:00	0.2	11.3	2,230.5	0.4	0.7	1	1	1
09/14/2014 17:00	0.1	11.4	2,213.2	0.4	0.7	1	1	1
09/14/2014 18:00	0.1	11.5	2,193.8	0.2	0.7	1	1	1
09/14/2014 19:00	0.1	11.7	2,159.9	0.2	0.6	1	1	1
09/14/2014 20:00	0.1	12.0	2,108.8	0.2	0.6	1	1	1
09/14/2014 21:00	-0.1	12.3	2,038.7	0.2	0.6	1	1	1
09/14/2014 22:00	-0.1	12.8	1,949.4	0.1	0.6	1	1	1
09/14/2014 23:00	-0.2	12.8	1,940.5	0.1	0.6	1	1	1
Average/Sum#:	0.1	12.6	1,911.5	0.2	0.6	24 #	24 #	20 #
Minimum:	-0.2	11.3	1,256.6	-0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,250.6	0.4	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/15/2014 00:00	-0.1	13.1	1,885.4	0.1	0.6	1	1	1
09/15/2014 01:00	-0.1	13.2	1,860.5	0.1	0.6	1	1	1
09/15/2014 02:00	-0.1	13.2	1,860.2	0.1	0.6	1	1	1
09/15/2014 03:00	-0.1	13.2	1,862.6	0.1	0.6	1	1	1
09/15/2014 04:00	-0.1	13.2	1,865.0	0.1	0.6	1	1	1
09/15/2014 05:00	-0.1	13.2	1,869.1	0.1	0.6	1	1	1
09/15/2014 06:00	-0.1	13.2	1,870.4	0.1	0.6	1	1	1
09/15/2014 07:00	-0.1	13.1	1,888.7	0.1	0.6	1	1	1
09/15/2014 08:00	-0.2	12.7	1,990.6	0.1	0.6	1	1	1
09/15/2014 09:00	0.1	11.9	2,162.6	0.2	0.6	1	1	1
09/15/2014 10:00	0.2	11.5	2,227.7	0.4	0.7	1	1	1
09/15/2014 11:00	0.2	11.4	2,237.3	0.4	0.7	1	1	1
09/15/2014 12:00	0.2	12.4	1,819.1	0.4	0.5	1	1	1
09/15/2014 13:00	0.4	14.0	1,327.6	0.4	0.4	1	1	0
09/15/2014 14:00	0.5	14.0	1,335.4	0.5	0.4	1	1	0
09/15/2014 15:00	-0.1	12.6	1,938.5	0.1	0.6	1	1	1
09/15/2014 16:00	0.1	11.7	2,160.7	0.2	0.6	1	1	1
09/15/2014 17:00	0.1	11.9	2,140.7	0.2	0.6	1	1	1
09/15/2014 18:00	0.1	12.0	2,115.9	0.2	0.6	1	1	1
09/15/2014 19:00	-0.1	12.2	2,091.3	0.2	0.6	1	1	1
09/15/2014 20:00	-0.1	12.4	2,058.7	0.2	0.6	1	1	1
09/15/2014 21:00	-0.1	12.9	1,939.8	0.1	0.6	1	1	1
09/15/2014 22:00	-0.1	13.3	1,861.9	0.1	0.6	1	1	1
09/15/2014 23:00	-0.1	13.2	1,871.5	0.1	0.6	1	1	1
Average/Sum#:	0.0	12.7	1,926.7	0.2	0.6	24 #	24 #	22 #
Minimum:	-0.2	11.4	1,327.6	0.1	0.4	1	1	0
Maximum:	0.5	14.0	2,237.3	0.5	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/16/2014 00:00	-0.1	13.3	1,860.5	0.1	0.6	1	1	1
09/16/2014 01:00	-0.1	13.3	1,857.8	0.1	0.6	1	1	1
09/16/2014 02:00	0.2	13.7	1,573.0	0.4	0.5	1	1	1
09/16/2014 03:00	0.4	13.8	1,277.6	0.4	0.4	1	1	0
09/16/2014 04:00	0.2	13.5	1,648.3	0.4	0.5	1	1	1
09/16/2014 05:00	-0.1	12.9	1,956.5	0.1	0.6	1	1	1
09/16/2014 06:00	-0.1	12.8	1,970.9	0.1	0.6	1	1	1
09/16/2014 07:00	0.1	12.7	2,015.4	0.2	0.6	1	1	1
09/16/2014 08:00	0.1	12.5	2,051.0	0.2	0.6	1	1	1
09/16/2014 09:00	0.1	12.5	2,049.6	0.2	0.6	1	1	1
09/16/2014 10:00	0.2	11.7	2,218.3	0.4	0.7	1	1	1
09/16/2014 11:00	0.2	11.7	2,219.3	0.4	0.7	1	1	1
09/16/2014 12:00	0.2	11.7	2,224.3	0.4	0.7	1	1	1
09/16/2014 13:00	0.2	11.7	2,212.4	0.4	0.7	1	1	1
09/16/2014 14:00	0.1	12.4	2,043.3	0.2	0.6	1	1	1
09/16/2014 15:00	-0.1	12.9	1,939.9	0.1	0.6	1	1	1
09/16/2014 16:00	-0.1	12.3	2,067.4	0.2	0.6	1	1	1
09/16/2014 17:00	0.2	11.5	2,230.0	0.4	0.7	1	1	1
09/16/2014 18:00	0.2	11.5	2,232.5	0.4	0.7	1	1	1
09/16/2014 19:00	0.2	11.6	2,237.9	0.4	0.7	1	1	1
09/16/2014 20:00	0.1	11.8	2,178.1	0.2	0.7	1	1	1
09/16/2014 21:00	-0.1	13.0	1,904.3	0.1	0.6	1	1	1
09/16/2014 22:00	0.1	13.5	1,690.1	0.2	0.5	1	1	1
09/16/2014 23:00	0.1	13.5	1,779.7	0.2	0.5	1	1	1
Average/Sum#:	0.1	12.6	1,976.6	0.3	0.6	24 #	24 #	23 #
Minimum:	-0.1	11.5	1,277.6	0.1	0.4	1	1	0
Maximum:	0.4	13.8	2,237.9	0.4	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/17/2014 00:00	-0.2	12.1	2,146.4	0.1	0.6	1	1	1
09/17/2014 01:00	-0.1	12.1	2,132.3	0.2	0.6	1	1	1
09/17/2014 02:00	-0.2	12.6	2,028.5	0.1	0.6	1	1	1
09/17/2014 03:00	-0.1	11.8	2,219.9	0.2	0.7	1	1	1
09/17/2014 04:00	0.1	11.8	2,227.7	0.2	0.7	1	1	1
09/17/2014 05:00	0.1	11.9	2,198.8	0.2	0.7	1	1	1
09/17/2014 06:00	0.1	11.9	2,200.5	0.2	0.7	1	1	1
09/17/2014 07:00	0.1	11.8	2,221.9	0.2	0.7	1	1	1
09/17/2014 08:00	0.1	11.8	2,202.4	0.2	0.7	1	1	1
09/17/2014 09:00	0.1	11.8	2,181.4	0.2	0.7	1	1	1
09/17/2014 10:00	0.1	11.8	2,185.8	0.2	0.7	1	1	1
09/17/2014 11:00	0.1	11.7	2,197.7	0.2	0.7	1	1	1
09/17/2014 12:00	0.1	11.6	2,219.8	0.2	0.7	1	1	1
09/17/2014 13:00	0.1	11.6	2,204.0	0.2	0.7	1	1	1
09/17/2014 14:00	0.1	11.8	2,152.2	0.2	0.6	1	1	1
09/17/2014 15:00	0.1	12.0	2,104.5	0.2	0.6	1	1	1
09/17/2014 16:00	-0.1	12.6	1,982.8	0.1	0.6	1	1	1
09/17/2014 17:00	-0.1	12.6	1,980.0	0.1	0.6	1	1	1
09/17/2014 18:00	-0.1	12.1	2,071.7	0.2	0.6	1	1	1
09/17/2014 19:00	-0.1	12.4	2,003.1	0.2	0.6	1	1	1
09/17/2014 20:00	-0.1	12.6	1,982.3	0.1	0.6	1	1	1
09/17/2014 21:00	0.1	13.1	1,862.1	0.2	0.6	1	1	1
09/17/2014 22:00	0.1	13.1	1,862.3	0.2	0.6	1	1	1
09/17/2014 23:00	-0.1	13.1	1,873.5	0.1	0.6	1	1	1
Average/Sum#:	0.0	12.2	2,101.7	0.2	0.6	24 #	24 #	24 #
Minimum:	-0.2	11.6	1,862.1	0.1	0.6	1	1	1
Maximum:	0.1	13.1	2,227.7	0.2	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/18/2014 00:00	-0.2	12.7	1,979.9	0.1	0.6	1	1	1
09/18/2014 01:00	-0.2	12.8	1,953.5	0.1	0.6	1	1	1
09/18/2014 02:00	0.1	13.2	1,867.8	0.2	0.6	1	1	1
09/18/2014 03:00	0.2	13.3	1,769.9	0.4	0.5	1	1	1
09/18/2014 04:00	0.4	13.8	1,572.2	0.4	0.5	1	1	0
09/18/2014 05:00	0.4	13.8	1,601.6	0.4	0.5	1	1	0
09/18/2014 06:00	0.4	13.8	1,597.0	0.4	0.5	1	1	0
09/18/2014 07:00	0.4	13.8	1,307.6	0.4	0.4	1	1	0
09/18/2014 08:00	0.4	13.8	1,417.4	0.4	0.4	1	1	0
09/18/2014 09:00	0.4	13.8	1,593.2	0.4	0.5	1	1	0
09/18/2014 10:00	0.4	13.9	1,292.0	0.4	0.4	1	1	0
09/18/2014 11:00	0.4	13.9	1,291.3	0.4	0.4	1	1	0
09/18/2014 12:00	0.4	13.9	1,483.1	0.4	0.4	1	1	0
09/18/2014 13:00	0.4	13.9	1,610.2	0.4	0.5	1	1	0
09/18/2014 14:00	0.4	13.8	1,672.3	0.4	0.5	1	1	0
09/18/2014 15:00	0.4	13.8	1,595.5	0.4	0.5	1	1	0
09/18/2014 16:00	0.1	13.4	1,725.0	0.2	0.5	1	1	1
09/18/2014 17:00	-0.2	12.6	1,976.2	0.1	0.6	1	1	1
09/18/2014 18:00	-0.1	12.2	2,074.7	0.2	0.6	1	1	1
09/18/2014 19:00	0.1	12.1	2,091.4	0.2	0.6	1	1	1
09/18/2014 20:00	0.1	13.0	1,882.9	0.2	0.6	1	1	1
09/18/2014 21:00	0.1	13.3	1,595.9	0.2	0.5	1	1	1
09/18/2014 22:00	0.5	13.9	1,245.0	0.5	0.4	1	1	0
09/18/2014 23:00	0.5	13.9	1,366.6	0.5	0.4	1	1	0
Average/Sum#:	0.2	13.4	1,648.4	0.3	0.5	24 #	24 #	10 #
Minimum:	-0.2	12.1	1,245.0	0.1	0.4	1	1	0
Maximum:	0.5	13.9	2,091.4	0.5	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/19/2014 00:00	0.5	13.9	1,262.9	0.5	0.4	1	1	0
09/19/2014 01:00	0.5	13.9	1,253.8	0.5	0.4	1	1	0
09/19/2014 02:00	0.5	13.9	1,252.9	0.5	0.4	1	1	0
09/19/2014 03:00	0.5	13.9	1,320.6	0.5	0.4	1	1	0
09/19/2014 04:00	0.4	13.9	1,344.2	0.4	0.4	1	1	0
09/19/2014 05:00	0.2	13.6	1,618.6	0.4	0.5	1	1	1
09/19/2014 06:00	-0.1	12.6	1,959.8	0.1	0.6	1	1	1
09/19/2014 07:00	0.1	13.3	1,862.8	0.2	0.6	1	1	1
09/19/2014 08:00	-0.1	13.1	1,877.7	0.1	0.6	1	1	1
09/19/2014 09:00	-0.1	13.1	1,886.8	0.1	0.6	1	1	1
09/19/2014 10:00	0.1	13.1	1,860.2	0.2	0.6	1	1	1
09/19/2014 11:00	0.1	13.1	1,857.6	0.2	0.6	1	1	1
09/19/2014 12:00	-0.1	12.5	1,970.6	0.1	0.6	1	1	1
09/19/2014 13:00	-0.1	12.5	1,967.0	0.1	0.6	1	1	1
09/19/2014 14:00	-0.1	12.3	2,027.0	0.2	0.6	1	1	1
09/19/2014 15:00	0.2	11.2	2,233.8	0.4	0.7	1	1	1
09/19/2014 16:00	0.2	11.2	2,239.9	0.4	0.7	1	1	1
09/19/2014 17:00	0.2	11.3	2,227.5	0.4	0.7	1	1	1
09/19/2014 18:00	0.1	11.8	2,125.4	0.2	0.6	1	1	1
09/19/2014 19:00	0.1	12.7	1,939.5	0.2	0.6	1	1	1
09/19/2014 20:00	-0.1	12.8	1,926.1	0.1	0.6	1	1	1
09/19/2014 21:00	-0.1	12.8	1,937.0	0.1	0.6	1	1	1
09/19/2014 22:00	-0.1	12.6	1,978.5	0.1	0.6	1	1	1
09/19/2014 23:00	-0.1	12.4	2,029.8	0.2	0.6	1	1	1
Average/Sum#:	0.1	12.8	1,831.7	0.3	0.6	24 #	24 #	19 #
Minimum:	-0.1	11.2	1,252.9	0.1	0.4	1	1	0
Maximum:	0.5	13.9	2,239.9	0.5	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/20/2014 00:00	-0.1	12.2	2,071.1	0.2	0.6	1	1	1
09/20/2014 01:00	0.2	11.7	2,173.8	0.4	0.7	1	1	1
09/20/2014 02:00	-0.1	12.5	2,001.4	0.1	0.6	1	1	1
09/20/2014 03:00	-0.1	12.6	1,994.3	0.1	0.6	1	1	1
09/20/2014 04:00	-0.1	12.5	2,008.9	0.1	0.6	1	1	1
09/20/2014 05:00	-0.1	12.6	1,982.8	0.1	0.6	1	1	1
09/20/2014 06:00	-0.1	12.6	1,995.2	0.1	0.6	1	1	1
09/20/2014 07:00	-0.1	12.6	2,003.8	0.1	0.6	1	1	1
09/20/2014 08:00	0.1	13.2	1,860.3	0.2	0.6	1	1	1
09/20/2014 09:00	0.1	13.2	1,856.6	0.2	0.6	1	1	1
09/20/2014 10:00	0.1	13.1	1,854.0	0.2	0.6	1	1	1
09/20/2014 11:00	0.1	13.1	1,854.3	0.2	0.6	1	1	1
09/20/2014 12:00	0.1	13.1	1,857.1	0.2	0.6	1	1	1
09/20/2014 13:00	-0.1	12.9	1,895.6	0.1	0.6	1	1	1
09/20/2014 14:00	-0.1	12.8	1,907.8	0.1	0.6	1	1	1
09/20/2014 15:00	-0.1	12.7	1,924.4	0.1	0.6	1	1	1
09/20/2014 16:00	-0.1	13.0	1,869.7	0.1	0.6	1	1	1
09/20/2014 17:00	-0.1	12.6	1,938.6	0.1	0.6	1	1	1
09/20/2014 18:00	-0.1	12.6	1,951.9	0.1	0.6	1	1	1
09/20/2014 19:00	0.1	12.0	2,080.8	0.2	0.6	1	1	1
09/20/2014 20:00	0.1	12.9	1,890.5	0.2	0.6	1	1	1
09/20/2014 21:00	-0.1	12.7	1,952.2	0.1	0.6	1	1	1
09/20/2014 22:00	0.1	13.1	1,861.4	0.2	0.6	1	1	1
09/20/2014 23:00	-0.1	12.9	1,912.3	0.1	0.6	1	1	1
Average/Sum#:	0.0	12.7	1,945.8	0.2	0.6	24 #	24 #	24 #
Minimum:	-0.1	11.7	1,854.0	0.1	0.6	1	1	1
Maximum:	0.2	13.2	2,173.8	0.4	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/21/2014 00:00	-0.1	13.2	1,852.7	0.1	0.6	1	1	1
09/21/2014 01:00	-0.1	13.2	1,851.5	0.1	0.6	1	1	1
09/21/2014 02:00	-0.1	13.2	1,853.1	0.1	0.6	1	1	1
09/21/2014 03:00	-0.1	13.2	1,851.6	0.1	0.6	1	1	1
09/21/2014 04:00	0.1	13.2	1,854.9	0.2	0.6	1	1	1
09/21/2014 05:00	0.1	13.2	1,853.6	0.2	0.6	1	1	1
09/21/2014 06:00	0.1	13.3	1,856.8	0.2	0.6	1	1	1
09/21/2014 07:00	0.1	13.2	1,860.5	0.2	0.6	1	1	1
09/21/2014 08:00	0.1	13.2	1,852.6	0.2	0.6	1	1	1
09/21/2014 09:00	0.1	13.2	1,849.1	0.2	0.6	1	1	1
09/21/2014 10:00	0.1	13.2	1,849.3	0.2	0.6	1	1	1
09/21/2014 11:00	0.1	13.2	1,726.8	0.2	0.5	1	1	1
09/21/2014 12:00	0.4	13.8	1,257.2	0.4	0.4	1	1	0
09/21/2014 13:00	0.4	13.9	1,248.9	0.4	0.4	1	1	0
09/21/2014 14:00	0.4	13.9	1,255.8	0.4	0.4	1	1	0
09/21/2014 15:00	0.4	13.9	1,267.5	0.4	0.4	1	1	0
09/21/2014 16:00	0.4	13.9	1,283.0	0.4	0.4	1	1	0
09/21/2014 17:00	0.2	13.5	1,707.2	0.4	0.5	1	1	1
09/21/2014 18:00	-0.1	13.0	1,880.5	0.1	0.6	1	1	1
09/21/2014 19:00	-0.1	12.8	1,937.6	0.1	0.6	1	1	1
09/21/2014 20:00	-0.1	13.2	1,855.9	0.1	0.6	1	1	1
09/21/2014 21:00	-0.1	13.2	1,855.0	0.1	0.6	1	1	1
09/21/2014 22:00	0.1	13.5	1,523.4	0.2	0.5	1	1	1
09/21/2014 23:00	0.4	13.8	1,249.0	0.4	0.4	1	1	0
Average/Sum#:	0.1	13.4	1,684.7	0.2	0.5	24 #	24 #	18 #
Minimum:	-0.1	12.8	1,248.9	0.1	0.4	1	1	0
Maximum:	0.4	13.9	1,937.6	0.4	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/22/2014 00:00	0.4	13.8	1,249.5	0.4	0.4	1	1	0
09/22/2014 01:00	0.4	13.8	1,248.0	0.4	0.4	1	1	0
09/22/2014 02:00	0.4	13.8	1,275.3	0.4	0.4	1	1	0
09/22/2014 03:00	0.1	13.5	1,693.8	0.2	0.5	1	1	1
09/22/2014 04:00	-0.1	13.2	1,865.1	0.1	0.6	1	1	1
09/22/2014 05:00	-0.1	12.9	1,937.3	0.1	0.6	1	1	1
09/22/2014 06:00	-0.1	12.3	2,047.8	0.2	0.6	1	1	1
09/22/2014 07:00	0.4	13.8	1,394.5	0.4	0.4	1	1	1
09/22/2014 08:00	0.4	13.8	1,279.9	0.4	0.4	1	1	0
09/22/2014 09:00	0.4	13.8	1,279.9	0.4	0.4	1	1	0
09/22/2014 10:00	0.4	13.9	1,293.0	0.4	0.4	1	1	0
09/22/2014 11:00	0.4	13.9	1,414.9	0.4	0.4	1	1	0
09/22/2014 12:00	0.4	13.7	1,718.4	0.4	0.5	1	1	0
09/22/2014 13:00	0.4	13.7	1,691.5	0.4	0.5	1	1	0
09/22/2014 14:00	0.4	13.6	1,733.9	0.4	0.5	1	1	0
09/22/2014 15:00	0.4	13.6	1,728.7	0.4	0.5	1	1	0
09/22/2014 16:00	0.4	13.6	1,727.2	0.4	0.5	1	1	0
09/22/2014 17:00	0.4	13.6	1,729.5	0.4	0.5	1	1	0
09/22/2014 18:00	0.4	13.6	1,735.4	0.4	0.5	1	1	0
09/22/2014 19:00	0.4	13.6	1,741.8	0.4	0.5	1	1	0
09/22/2014 20:00	0.4	13.6	1,734.6	0.4	0.5	1	1	0
09/22/2014 21:00	0.4	13.7	1,707.3	0.4	0.5	1	1	0
09/22/2014 22:00	0.4	13.8	1,544.3	0.4	0.5	1	1	0
09/22/2014 23:00	0.4	13.8	1,663.0	0.4	0.5	1	1	0
Average/Sum#:	0.3	13.6	1,601.4	0.4	0.5	24 #	24 #	5 #
Minimum:	-0.1	12.3	1,248.0	0.1	0.4	1	1	0
Maximum:	0.4	13.9	2,047.8	0.4	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/23/2014 00:00	0.4	13.8	1,623.0	0.4	0.5	1	1	0
09/23/2014 01:00	0.4	13.9	1,587.7	0.4	0.5	1	1	0
09/23/2014 02:00	0.4	13.9	1,578.2	0.4	0.5	1	1	0
09/23/2014 03:00	0.4	13.8	1,683.8	0.4	0.5	1	1	0
09/23/2014 04:00	0.4	13.7	1,716.8	0.4	0.5	1	1	0
09/23/2014 05:00	0.4	13.7	1,719.4	0.4	0.5	1	1	0
09/23/2014 06:00	0.4	13.7	1,783.9	0.4	0.5	1	1	0
09/23/2014 07:00	0.4	13.7	1,679.9	0.4	0.5	1	1	0
09/23/2014 08:00	0.4	13.8	1,303.8	0.4	0.4	1	1	0
09/23/2014 09:00	0.6	0.0	1,288.0	0.6	0.4	1	1	0
09/23/2014 10:00	0.6	0.0	1,281.1	0.6	0.4	1	1	0
09/23/2014 11:00	0.6	0.0	1,467.5	0.6	0.4	1	1	0
09/23/2014 12:00	0.6	0.0	1,659.6	0.6	0.5	1	1	0
09/23/2014 13:00	0.4	13.7	1,648.3	0.4	0.5	1	1	0
09/23/2014 14:00	0.4	13.7	1,743.6	0.4	0.5	1	1	0
09/23/2014 15:00	0.4	13.7	1,743.3	0.4	0.5	1	1	0
09/23/2014 16:00	0.4	13.7	1,736.8	0.4	0.5	1	1	0
09/23/2014 17:00	0.4	13.6	1,737.3	0.4	0.5	1	1	0
09/23/2014 18:00	0.4	13.7	1,745.6	0.4	0.5	1	1	0
09/23/2014 19:00	0.4	13.7	1,749.0	0.4	0.5	1	1	0
09/23/2014 20:00	0.4	13.7	1,696.1	0.4	0.5	1	1	0
09/23/2014 21:00	0.4	13.6	1,753.1	0.4	0.5	1	1	0
09/23/2014 22:00	0.4	13.6	1,750.3	0.4	0.5	1	1	0
09/23/2014 23:00	0.4	13.6	1,757.2	0.4	0.5	1	1	0
Average/Sum#:	0.4	13.7	1,643.1	0.4	0.5	24 #	24 #	0 #
Minimum:	0.4	13.6	1,281.1	0.4	0.4	1	1	0
Maximum:	0.4	13.9	1,783.9	0.4	0.5	1	1	0
%SI	16.7	16.7	0.0	16.7	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/24/2014 00:00	0.4	13.6	1,765.1	0.4	0.5	1	1	0
09/24/2014 01:00	0.4	13.6	1,770.3	0.4	0.5	1	1	0
09/24/2014 02:00	0.4	13.6	1,768.2	0.4	0.5	1	1	0
09/24/2014 03:00	0.4	13.7	1,762.1	0.4	0.5	1	1	0
09/24/2014 04:00	0.4	13.6	1,746.4	0.4	0.5	1	1	0
09/24/2014 05:00	0.4	13.7	1,676.6	0.4	0.5	1	1	0
09/24/2014 06:00	0.4	13.6	1,780.5	0.4	0.5	1	1	0
09/24/2014 07:00	0.4	13.7	1,716.3	0.4	0.5	1	1	0
09/24/2014 08:00	0.4	13.8	1,596.2	0.4	0.5	1	1	0
09/24/2014 09:00	0.4	13.7	1,724.8	0.4	0.5	1	1	0
09/24/2014 10:00	0.4	13.6	1,753.2	0.4	0.5	1	1	0
09/24/2014 11:00	0.4	13.6	1,747.8	0.4	0.5	1	1	0
09/24/2014 12:00	0.4	13.6	1,742.3	0.4	0.5	1	1	0
09/24/2014 13:00	0.4	13.6	1,736.0	0.4	0.5	1	1	0
09/24/2014 14:00	0.4	13.7	1,733.3	0.4	0.5	1	1	0
09/24/2014 15:00	0.4	13.7	1,730.8	0.4	0.5	1	1	0
09/24/2014 16:00	0.4	13.7	1,730.9	0.4	0.5	1	1	0
09/24/2014 17:00	0.4	13.6	1,741.9	0.4	0.5	1	1	0
09/24/2014 18:00	0.4	13.6	1,751.2	0.4	0.5	1	1	0
09/24/2014 19:00	0.4	13.6	1,753.1	0.4	0.5	1	1	0
09/24/2014 20:00	0.4	13.6	1,762.2	0.4	0.5	1	1	0
09/24/2014 21:00	0.4	13.6	1,770.9	0.4	0.5	1	1	0
09/24/2014 22:00	0.4	13.6	1,773.3	0.4	0.5	1	1	0
09/24/2014 23:00	0.4	13.7	1,775.7	0.4	0.5	1	1	0
Average/Sum#:	0.4	13.6	1,742.0	0.4	0.5	24 #	24 #	0 #
Minimum:	0.4	13.6	1,596.2	0.4	0.5	1	1	0
Maximum:	0.4	13.8	1,780.5	0.4	0.5	1	1	0
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/25/2014 00:00	0.4	13.6	1,774.7	0.4	0.5	1	1	0
09/25/2014 01:00	0.4	13.6	1,776.5	0.4	0.5	1	1	0
09/25/2014 02:00	0.4	13.6	1,778.7	0.4	0.5	1	1	0
09/25/2014 03:00	0.4	13.7	1,736.1	0.4	0.5	1	1	0
09/25/2014 04:00	0.4	13.6	1,778.9	0.4	0.5	1	1	0
09/25/2014 05:00	0.4	13.7	1,741.1	0.4	0.5	1	1	0
09/25/2014 06:00	0.4	13.6	1,781.3	0.4	0.5	1	1	0
09/25/2014 07:00	0.4	13.7	1,759.3	0.4	0.5	1	1	0
09/25/2014 08:00	0.4	13.6	1,788.5	0.4	0.5	1	1	0
09/25/2014 09:00	0.4	13.7	1,772.0	0.4	0.5	1	1	0
09/25/2014 10:00	0.4	13.7	1,753.6	0.4	0.5	1	1	0
09/25/2014 11:00	0.4	13.6	1,774.8	0.4	0.5	1	1	0
09/25/2014 12:00	0.4	13.6	1,760.4	0.4	0.5	1	1	0
09/25/2014 13:00	-0.2	12.4	2,064.9	0.1	0.6	1	1	1
09/25/2014 14:00	0.1	11.9	2,176.9	0.2	0.7	1	1	1
09/25/2014 15:00	0.4	11.6	2,219.4	0.5	0.7	1	1	1
09/25/2014 16:00	0.1	12.8	1,970.5	0.2	0.6	1	1	1
09/25/2014 17:00	0.1	12.5	2,050.8	0.2	0.6	1	1	1
09/25/2014 18:00	0.1	12.3	2,088.0	0.2	0.6	1	1	1
09/25/2014 19:00	0.2	12.2	2,100.8	0.4	0.6	1	1	1
09/25/2014 20:00	0.1	12.9	1,952.9	0.2	0.6	1	1	1
09/25/2014 21:00	0.2	13.0	1,923.5	0.4	0.6	1	1	1
09/25/2014 22:00	0.1	12.9	1,970.9	0.2	0.6	1	1	1
09/25/2014 23:00	0.1	12.4	2,087.8	0.2	0.6	1	1	1
Average/Sum#:	0.3	13.1	1,899.3	0.3	0.6	24 #	24 #	11 #
Minimum:	-0.2	11.6	1,736.1	0.1	0.5	1	1	0
Maximum:	0.4	13.7	2,219.4	0.5	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/26/2014 00:00	0.1	12.9	1,978.9	0.2	0.6	1	1	1
09/26/2014 01:00	0.1	12.9	1,991.5	0.2	0.6	1	1	1
09/26/2014 02:00	0.2	13.1	1,931.9	0.4	0.6	1	1	1
09/26/2014 03:00	0.1	13.0	1,959.3	0.2	0.6	1	1	1
09/26/2014 04:00	0.2	11.9	2,212.8	0.4	0.7	1	1	1
09/26/2014 05:00	0.2	11.8	2,237.1	0.4	0.7	1	1	1
09/26/2014 06:00	0.4	11.8	2,254.1	0.5	0.7	1	1	1
09/26/2014 07:00	0.2	12.4	2,091.7	0.4	0.6	1	1	1
09/26/2014 08:00	0.2	13.2	1,894.7	0.4	0.6	1	1	1
09/26/2014 09:00	0.1	12.7	2,020.3	0.2	0.6	1	1	1
09/26/2014 10:00	0.1	12.6	2,048.9	0.2	0.6	1	1	1
09/26/2014 11:00	0.1	12.8	1,995.9	0.2	0.6	1	1	1
09/26/2014 12:00	0.2	13.1	1,903.8	0.4	0.6	1	1	1
09/26/2014 13:00	0.2	13.3	1,874.7	0.4	0.6	1	1	1
09/26/2014 14:00	0.2	13.3	1,878.7	0.4	0.6	1	1	1
09/26/2014 15:00	0.2	13.3	1,871.7	0.4	0.6	1	1	1
09/26/2014 16:00	0.1	13.3	1,874.3	0.2	0.6	1	1	1
09/26/2014 17:00	0.1	13.0	1,943.6	0.2	0.6	1	1	1
09/26/2014 18:00	0.1	13.1	1,916.6	0.2	0.6	1	1	1
09/26/2014 19:00	0.1	13.3	1,880.3	0.2	0.6	1	1	1
09/26/2014 20:00	0.1	13.3	1,882.9	0.2	0.6	1	1	1
09/26/2014 21:00	0.1	13.0	1,939.6	0.2	0.6	1	1	1
09/26/2014 22:00	0.1	13.2	1,906.3	0.2	0.6	1	1	1
09/26/2014 23:00	0.1	12.6	2,050.1	0.2	0.6	1	1	1
Average/Sum#:	0.2	12.9	1,980.8	0.3	0.6	24 #	24 #	24 #
Minimum:	0.1	11.8	1,871.7	0.2	0.6	1	1	1
Maximum:	0.4	13.3	2,254.1	0.5	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/27/2014 00:00	0.1	12.4	2,081.7	0.2	0.6	1	1	1
09/27/2014 01:00	0.2	12.1	2,156.4	0.4	0.6	1	1	1
09/27/2014 02:00	0.1	12.9	1,983.3	0.2	0.6	1	1	1
09/27/2014 03:00	0.1	13.0	1,936.8	0.2	0.6	1	1	1
09/27/2014 04:00	0.2	13.2	1,907.4	0.4	0.6	1	1	1
09/27/2014 05:00	0.1	13.1	1,933.0	0.2	0.6	1	1	1
09/27/2014 06:00	0.1	13.1	1,927.7	0.2	0.6	1	1	1
09/27/2014 07:00	0.4	13.5	1,600.0	0.4	0.5	1	1	1
09/27/2014 08:00	0.5	13.8	1,274.4	0.5	0.4	1	1	0
09/27/2014 09:00	0.5	13.8	1,350.2	0.5	0.4	1	1	0
09/27/2014 10:00	0.5	13.9	1,287.6	0.5	0.4	1	1	0
09/27/2014 11:00	0.5	13.9	1,260.9	0.5	0.4	1	1	0
09/27/2014 12:00	0.5	13.9	1,258.7	0.5	0.4	1	1	0
09/27/2014 13:00	0.5	13.9	1,258.7	0.5	0.4	1	1	0
09/27/2014 14:00	0.5	13.9	1,259.5	0.5	0.4	1	1	0
09/27/2014 15:00	0.5	13.9	1,257.4	0.5	0.4	1	1	0
09/27/2014 16:00	0.5	13.9	1,253.6	0.5	0.4	1	1	0
09/27/2014 17:00	0.2	13.5	1,620.3	0.4	0.5	1	1	1
09/27/2014 18:00	0.1	11.8	2,198.6	0.2	0.7	1	1	1
09/27/2014 19:00	0.1	12.7	1,977.7	0.2	0.6	1	1	1
09/27/2014 20:00	0.1	13.0	1,910.9	0.2	0.6	1	1	1
09/27/2014 21:00	0.1	12.8	1,969.5	0.2	0.6	1	1	1
09/27/2014 22:00	0.2	13.3	1,856.7	0.4	0.6	1	1	1
09/27/2014 23:00	0.1	13.2	1,884.5	0.2	0.6	1	1	1
Average/Sum#:	0.3	13.3	1,683.6	0.4	0.5	24 #	24 #	15 #
Minimum:	0.1	11.8	1,253.6	0.2	0.4	1	1	0
Maximum:	0.5	13.9	2,198.6	0.5	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/28/2014 00:00	0.4	13.5	1,464.0	0.4	0.4	1	1	1
09/28/2014 01:00	0.5	13.9	1,256.6	0.5	0.4	1	1	0
09/28/2014 02:00	0.5	13.9	1,256.2	0.5	0.4	1	1	0
09/28/2014 03:00	0.4	13.9	1,520.4	0.4	0.5	1	1	0
09/28/2014 04:00	0.1	13.3	1,839.8	0.2	0.6	1	1	1
09/28/2014 05:00	-0.1	12.7	2,003.5	0.1	0.6	1	1	1
09/28/2014 06:00	-0.1	12.6	2,027.7	0.1	0.6	1	1	1
09/28/2014 07:00	0.1	13.2	1,883.3	0.2	0.6	1	1	1
09/28/2014 08:00	0.1	13.1	1,904.5	0.2	0.6	1	1	1
09/28/2014 09:00	0.4	13.8	1,312.3	0.4	0.4	1	1	1
09/28/2014 10:00	0.4	13.8	1,257.5	0.4	0.4	1	1	0
09/28/2014 11:00	0.2	13.6	1,549.2	0.4	0.5	1	1	1
09/28/2014 12:00	0.1	13.3	1,867.7	0.2	0.6	1	1	1
09/28/2014 13:00	0.1	13.2	1,866.3	0.2	0.6	1	1	1
09/28/2014 14:00	0.1	13.3	1,866.2	0.2	0.6	1	1	1
09/28/2014 15:00	0.1	13.3	1,866.7	0.2	0.6	1	1	1
09/28/2014 16:00	0.1	12.9	1,953.9	0.2	0.6	1	1	1
09/28/2014 17:00	0.1	12.3	2,092.7	0.2	0.6	1	1	1
09/28/2014 18:00	0.2	11.5	2,276.5	0.4	0.7	1	1	1
09/28/2014 19:00	0.4	11.4	2,285.0	0.5	0.7	1	1	1
09/28/2014 20:00	0.1	12.6	2,018.6	0.2	0.6	1	1	1
09/28/2014 21:00	0.1	12.9	1,966.0	0.2	0.6	1	1	1
09/28/2014 22:00	0.1	12.9	1,954.5	0.2	0.6	1	1	1
09/28/2014 23:00	0.1	13.3	1,865.2	0.2	0.6	1	1	1
Average/Sum#:	0.2	13.1	1,798.1	0.3	0.6	24 #	24 #	20 #
Minimum:	-0.1	11.4	1,256.2	0.1	0.4	1	1	0
Maximum:	0.5	13.9	2,285.0	0.5	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/29/2014 00:00	-0.1	13.4	1,842.9	0.1	0.6	1	1	1
09/29/2014 01:00	-0.1	13.5	1,841.4	0.1	0.6	1	1	1
09/29/2014 02:00	-0.1	13.5	1,842.2	0.1	0.6	1	1	1
09/29/2014 03:00	-0.1	13.5	1,842.2	0.1	0.6	1	1	1
09/29/2014 04:00	0.1	13.3	1,869.2	0.2	0.6	1	1	1
09/29/2014 05:00	0.1	13.2	1,883.5	0.2	0.6	1	1	1
09/29/2014 06:00	-0.1	12.7	2,018.6	0.1	0.6	1	1	1
09/29/2014 07:00	0.1	13.2	1,866.3	0.2	0.6	1	1	1
09/29/2014 08:00	0.1	13.2	1,866.1	0.2	0.6	1	1	1
09/29/2014 09:00	0.1	13.2	1,874.7	0.2	0.6	1	1	1
09/29/2014 10:00	0.1	13.2	1,882.6	0.2	0.6	1	1	1
09/29/2014 11:00	0.1	13.2	1,879.4	0.2	0.6	1	1	1
09/29/2014 12:00	0.4	13.8	1,289.0	0.4	0.4	1	1	0
09/29/2014 13:00	0.4	13.9	1,257.8	0.4	0.4	1	1	0
09/29/2014 14:00	0.2	13.6	1,528.8	0.4	0.5	1	1	1
09/29/2014 15:00	0.1	13.2	1,869.4	0.2	0.6	1	1	1
09/29/2014 16:00	0.1	13.0	1,919.4	0.2	0.6	1	1	1
09/29/2014 17:00	-0.1	12.6	2,003.4	0.1	0.6	1	1	1
09/29/2014 18:00	0.1	11.8	2,179.1	0.2	0.7	1	1	1
09/29/2014 19:00	0.2	12.0	2,140.4	0.4	0.6	1	1	1
09/29/2014 20:00	0.1	12.8	1,948.4	0.2	0.6	1	1	1
09/29/2014 21:00	0.2	13.3	1,725.5	0.4	0.5	1	1	1
09/29/2014 22:00	0.5	13.8	1,269.7	0.5	0.4	1	1	0
09/29/2014 23:00	0.4	13.8	1,302.7	0.4	0.4	1	1	0
Average/Sum#:	0.1	13.2	1,789.3	0.2	0.6	24 #	24 #	20 #
Minimum:	-0.1	11.8	1,257.8	0.1	0.4	1	1	0
Maximum:	0.5	13.9	2,179.1	0.5	0.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - VOC

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 VOC, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 VOC, Ppmvdc 1 Hour(s)	Unit CT2 VOC, LbPerHr 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/30/2014 00:00	0.4	13.8	1,258.2	0.4	0.4	1	1	0
09/30/2014 01:00	0.4	13.8	1,259.2	0.4	0.4	1	1	0
09/30/2014 02:00	0.4	13.8	1,259.5	0.4	0.4	1	1	0
09/30/2014 03:00	0.4	13.8	1,260.2	0.4	0.4	1	1	0
09/30/2014 04:00	0.4	13.8	1,380.0	0.4	0.4	1	1	0
09/30/2014 05:00	0.1	13.4	1,650.0	0.2	0.5	1	1	1
09/30/2014 06:00	0.1	13.2	1,898.7	0.2	0.6	1	1	1
09/30/2014 07:00	0.1	13.2	1,872.1	0.2	0.6	1	1	1
09/30/2014 08:00	0.1	13.2	1,873.0	0.2	0.6	1	1	1
09/30/2014 09:00	0.1	13.2	1,869.8	0.2	0.6	1	1	1
09/30/2014 10:00	0.5	13.8	1,260.8	0.5	0.4	1	1	0
09/30/2014 11:00	0.5	13.9	1,257.9	0.5	0.4	1	1	0
09/30/2014 12:00	0.2	13.6	1,635.9	0.4	0.5	1	1	1
09/30/2014 13:00	0.1	13.2	1,869.1	0.2	0.6	1	1	1
09/30/2014 14:00	0.1	13.2	1,871.6	0.2	0.6	1	1	1
09/30/2014 15:00	0.1	13.2	1,876.2	0.2	0.6	1	1	1
09/30/2014 16:00	0.1	13.1	1,891.4	0.2	0.6	1	1	1
09/30/2014 17:00	0.1	13.2	1,881.3	0.2	0.6	1	1	1
09/30/2014 18:00	0.1	12.6	2,035.9	0.2	0.6	1	1	1
09/30/2014 19:00	0.2	12.2	2,110.5	0.4	0.6	1	1	1
09/30/2014 20:00	0.1	13.3	1,872.6	0.2	0.6	1	1	1
09/30/2014 21:00	0.2	13.7	1,470.8	0.4	0.4	1	1	1
09/30/2014 22:00	0.5	13.9	1,262.4	0.5	0.4	1	1	0
09/30/2014 23:00	0.5	13.9	1,261.3	0.5	0.4	1	1	0
Average/Sum#:	0.2	13.4	1,630.8	0.3	0.5	24 #	24 #	15 #
Minimum:	0.1	12.2	1,257.9	0.2	0.4	1	1	0
Maximum:	0.5	13.9	2,110.5	0.5	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

ATTACHMENT 6

Hourly Emissions NO_x (AQ-15)

Excess Emission Report

CT1 - NOx Lb 1-Day Block Average

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:03 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Lb_1D
Total Operating Time: 1,558.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 650.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,558.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

CT2 - NOx Lb 1-Day Block Average

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:04 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Lb_1D
Total Operating Time: 1,577.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 631.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,577.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 HI, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/01/2014 00:00	1.1	13.1	1,831.5	0.8	5.50	1	1	1
07/01/2014 01:00	1.0	13.5	1,573.7	0.8	4.70	1	1	1
07/01/2014 02:00	0.9	13.4	1,558.2	0.7	4.70	1	1	1
07/01/2014 03:00	0.7	13.7	1,241.5	0.6	2.50	1	1	0
07/01/2014 04:00	0.8	13.7	1,282.1	0.7	2.60	1	1	0
07/01/2014 05:00	1.0	13.4	1,556.7	0.8	4.70	1	1	1
07/01/2014 06:00	1.1	13.0	1,889.6	0.8	5.70	1	1	1
07/01/2014 07:00	1.0	13.0	1,879.9	0.7	5.60	1	1	1
07/01/2014 08:00	1.0	12.9	1,906.6	0.7	5.70	1	1	1
07/01/2014 09:00	0.9	12.8	1,916.8	0.7	3.80	1	1	1
07/01/2014 10:00	0.9	12.9	1,874.0	0.7	3.70	1	1	1
07/01/2014 11:00	0.9	13.0	1,842.0	0.7	3.70	1	1	1
07/01/2014 12:00	0.9	13.0	1,870.3	0.7	3.70	1	1	1
07/01/2014 13:00	0.9	12.8	1,887.0	0.7	3.80	1	1	1
07/01/2014 14:00	0.9	12.8	1,894.5	0.7	3.80	1	1	1
07/01/2014 15:00	0.9	12.7	1,896.5	0.6	3.80	1	1	1
07/01/2014 16:00	1.0	12.1	2,019.6	0.7	4.00	1	1	1
07/01/2014 17:00	1.2	11.6	2,122.6	0.8	6.40	1	1	1
07/01/2014 18:00	1.3	11.7	2,106.2	0.8	6.30	1	1	1
07/01/2014 19:00	0.8	12.9	1,871.4	0.6	3.70	1	1	1
07/01/2014 20:00	0.8	13.0	1,859.7	0.6	3.70	1	1	1
07/01/2014 21:00	0.7	13.1	1,843.1	0.5	3.70	1	1	1
07/01/2014 22:00	0.8	13.2	1,840.7	0.6	3.70	1	1	1
07/01/2014 23:00	0.9	13.3	1,840.6	0.7	5.50	1	1	1
Average/Sum#:	0.9	12.9	1,808.5	0.7	105.00 #	24 #	24 #	22 #
Minimum:	0.7	11.6	1,241.5	0.5	2.50	1	1	0
Maximum:	1.3	13.7	2,122.6	0.8	6.40	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/02/2014 00:00	0.9	13.3	1,841.4	0.7	5.50	1	1	1
07/02/2014 01:00	0.9	13.3	1,842.9	0.7	5.50	1	1	1
07/02/2014 02:00	0.9	13.3	1,842.6	0.7	5.50	1	1	1
07/02/2014 03:00	0.9	13.3	1,842.4	0.7	5.50	1	1	1
07/02/2014 04:00	1.0	13.1	1,910.0	0.8	5.70	1	1	1
07/02/2014 05:00	1.1	12.4	2,058.3	0.8	6.20	1	1	1
07/02/2014 06:00	1.0	12.6	1,983.1	0.7	5.90	1	1	1
07/02/2014 07:00	0.9	13.2	1,866.3	0.7	5.60	1	1	1
07/02/2014 08:00	0.8	13.2	1,872.5	0.6	3.70	1	1	1
07/02/2014 09:00	0.8	13.2	1,872.9	0.6	3.70	1	1	1
07/02/2014 10:00	0.8	13.1	1,870.0	0.6	3.70	1	1	1
07/02/2014 11:00	0.9	13.0	1,874.7	0.7	3.70	1	1	1
07/02/2014 12:00	0.9	13.0	1,881.2	0.7	3.80	1	1	1
07/02/2014 13:00	0.9	12.9	1,884.7	0.7	3.80	1	1	1
07/02/2014 14:00	1.0	12.3	2,011.4	0.7	6.00	1	1	1
07/02/2014 15:00	1.3	11.6	2,122.1	0.8	6.40	1	1	1
07/02/2014 16:00	1.0	12.2	2,007.8	0.7	4.00	1	1	1
07/02/2014 17:00	1.0	12.5	1,957.3	0.7	5.90	1	1	1
07/02/2014 18:00	0.9	12.4	1,970.7	0.6	3.90	1	1	1
07/02/2014 19:00	0.9	12.6	1,949.3	0.6	3.90	1	1	1
07/02/2014 20:00	0.9	12.6	1,944.8	0.6	3.90	1	1	1
07/02/2014 21:00	0.6	13.7	1,322.6	0.5	2.60	1	1	1
07/02/2014 22:00	3.5	16.3	366.1	4.5	1.05	1	0	0
07/02/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.0	13.0	1,830.2	0.8	105.45 #	23 #	22 #	22 #
Minimum:	0.6	11.6	366.1	0.5	1.05	0	0	0
Maximum:	3.5	16.3	2,122.1	4.5	6.40	1	1	1
%SI	4.2	4.2	4.2	4.2	4.17	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/03/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2014 03:00	1.7	16.6	578.4	2.3	3.48	1	0	0
07/03/2014 04:00	2.5	13.8	1,503.3	2.1	12.00	1	0	0
07/03/2014 05:00	0.9	13.6	1,790.3	0.7	5.40	1	1	0
07/03/2014 06:00	0.9	13.6	1,780.8	0.7	5.30	1	1	0
07/03/2014 07:00	0.8	13.7	1,728.7	0.7	3.50	1	1	0
07/03/2014 08:00	0.7	13.7	1,581.8	0.6	3.20	1	1	1
07/03/2014 09:00	0.9	13.0	1,889.0	0.7	3.80	1	1	1
07/03/2014 10:00	0.9	13.0	1,884.1	0.7	3.80	1	1	1
07/03/2014 11:00	0.9	12.9	1,906.6	0.7	3.80	1	1	1
07/03/2014 12:00	0.9	12.5	1,969.1	0.6	3.90	1	1	1
07/03/2014 13:00	1.2	11.8	2,105.3	0.8	6.30	1	1	1
07/03/2014 14:00	1.3	11.6	2,129.2	0.8	6.40	1	1	1
07/03/2014 15:00	1.3	11.5	2,135.6	0.8	6.40	1	1	1
07/03/2014 16:00	1.3	11.5	2,139.6	0.8	6.40	1	1	1
07/03/2014 17:00	1.3	11.5	2,143.4	0.8	6.40	1	1	1
07/03/2014 18:00	1.4	11.3	2,175.3	0.9	6.50	1	1	1
07/03/2014 19:00	1.4	11.3	2,169.3	0.9	6.50	1	1	1
07/03/2014 20:00	1.2	12.0	2,048.3	0.8	6.10	1	1	1
07/03/2014 21:00	1.0	12.4	1,980.0	0.7	5.90	1	1	1
07/03/2014 22:00	1.0	12.3	2,017.9	0.7	6.10	1	1	1
07/03/2014 23:00	1.5	11.4	2,203.2	0.9	6.60	1	1	1
Average/Sum#:	1.2	12.6	1,898.1	0.9	117.78 #	21 #	19 #	16 #
Minimum:	0.7	11.3	578.4	0.6	3.20	0	0	0
Maximum:	2.5	16.6	2,203.2	2.3	12.00	1	1	1
%SI	12.5	12.5	12.5	12.5	12.50	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/04/2014 00:00	1.1	12.5	1,994.4	0.8	6.00	1	1	1
07/04/2014 01:00	1.0	12.8	1,954.7	0.7	5.90	1	1	1
07/04/2014 02:00	0.9	13.1	1,880.8	0.7	5.60	1	1	1
07/04/2014 03:00	0.9	13.3	1,841.4	0.7	5.50	1	1	1
07/04/2014 04:00	0.9	13.1	1,887.2	0.7	5.70	1	1	1
07/04/2014 05:00	0.8	13.2	1,874.0	0.6	3.70	1	1	1
07/04/2014 06:00	0.8	13.2	1,873.9	0.6	3.70	1	1	1
07/04/2014 07:00	0.8	13.2	1,871.3	0.6	3.70	1	1	1
07/04/2014 08:00	0.9	12.9	1,936.2	0.7	3.90	1	1	1
07/04/2014 09:00	1.0	12.8	1,945.0	0.7	5.80	1	1	1
07/04/2014 10:00	1.0	12.6	1,983.2	0.7	5.90	1	1	1
07/04/2014 11:00	1.6	11.3	2,211.8	1.0	8.80	1	1	1
07/04/2014 12:00	1.3	11.9	2,084.9	0.9	6.30	1	1	1
07/04/2014 13:00	0.9	12.7	1,924.4	0.6	3.80	1	1	1
07/04/2014 14:00	0.9	12.7	1,928.0	0.6	3.90	1	1	1
07/04/2014 15:00	0.9	12.6	1,932.2	0.6	3.90	1	1	1
07/04/2014 16:00	1.0	12.5	1,960.6	0.7	5.90	1	1	1
07/04/2014 17:00	1.0	12.5	1,964.6	0.7	5.90	1	1	1
07/04/2014 18:00	0.7	13.6	1,475.5	0.6	3.00	1	1	1
07/04/2014 19:00	0.7	14.0	1,281.6	0.6	2.60	1	1	0
07/04/2014 20:00	5.2	16.5	345.3	7.0	1.53	1	0	0
07/04/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.2	13.0	1,816.7	1.0	101.03 #	21 #	20 #	19 #
Minimum:	0.7	11.3	345.3	0.6	1.53	0	0	0
Maximum:	5.2	16.5	2,211.8	7.0	8.80	1	1	1
%SI	12.5	12.5	12.5	12.5	12.50	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/05/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2014 06:00	20.5	17.2	498.8	32.7	52.11	1	0	0
07/05/2014 07:00	12.9	15.2	838.3	13.4	41.10	1	0	0
07/05/2014 08:00	0.4	13.8	1,490.7	0.3	1.50	1	1	0
07/05/2014 09:00	0.8	13.8	1,775.1	0.7	3.60	1	1	0
07/05/2014 10:00	0.8	13.7	1,750.1	0.7	3.50	1	1	0
07/05/2014 11:00	0.6	13.8	1,498.2	0.5	3.00	1	1	0
07/05/2014 12:00	1.0	12.7	1,959.9	0.7	5.90	1	1	1
07/05/2014 13:00	1.2	12.1	2,084.0	0.8	6.30	1	1	1
07/05/2014 14:00	1.0	12.8	1,920.1	0.7	5.80	1	1	1
07/05/2014 15:00	1.0	12.8	1,900.0	0.7	5.70	1	1	1
07/05/2014 16:00	1.0	12.6	1,927.2	0.7	5.80	1	1	1
07/05/2014 17:00	1.0	12.5	1,970.8	0.7	5.90	1	1	1
07/05/2014 18:00	1.0	12.7	1,930.5	0.7	5.80	1	1	1
07/05/2014 19:00	1.0	13.0	1,870.7	0.7	5.60	1	1	1
07/05/2014 20:00	0.9	13.1	1,866.3	0.7	5.60	1	1	1
07/05/2014 21:00	0.8	13.1	1,860.0	0.6	3.70	1	1	1
07/05/2014 22:00	0.8	13.6	1,548.7	0.6	3.10	1	1	1
07/05/2014 23:00	0.9	13.6	1,767.9	0.7	5.30	1	1	0
Average/Sum#:	2.6	13.5	1,692.1	3.1	169.31 #	18 #	16 #	11 #
Minimum:	0.4	12.1	498.8	0.3	1.50	0	0	0
Maximum:	20.5	17.2	2,084.0	32.7	52.11	1	1	1
%SI	25.0	25.0	25.0	25.0	25.00	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/06/2014 00:00	0.9	13.6	1,775.9	0.7	5.30	1	1	0
07/06/2014 01:00	0.7	13.7	1,484.5	0.6	3.00	1	1	0
07/06/2014 02:00	4.7	16.7	308.3	6.6	1.26	1	0	0
07/06/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2014 05:00	4.9	17.5	458.8	8.5	7.53	1	0	0
07/06/2014 06:00	7.6	14.7	1,073.8	7.2	29.00	1	0	0
07/06/2014 07:00	0.8	13.7	1,767.2	0.7	3.50	1	1	0
07/06/2014 08:00	0.7	13.8	1,610.0	0.6	3.20	1	1	0
07/06/2014 09:00	0.8	13.9	1,692.7	0.7	3.40	1	1	0
07/06/2014 10:00	0.7	13.9	1,436.1	0.6	2.90	1	1	0
07/06/2014 11:00	1.0	13.3	1,749.7	0.8	5.20	1	1	1
07/06/2014 12:00	1.1	12.9	1,897.0	0.8	5.70	1	1	1
07/06/2014 13:00	1.1	13.0	1,865.2	0.8	5.60	1	1	1
07/06/2014 14:00	1.1	13.1	1,861.0	0.8	5.60	1	1	1
07/06/2014 15:00	1.1	13.0	1,857.2	0.8	5.60	1	1	1
07/06/2014 16:00	1.1	12.8	1,897.6	0.8	5.70	1	1	1
07/06/2014 17:00	1.2	12.2	2,040.0	0.8	6.10	1	1	1
07/06/2014 18:00	1.5	11.7	2,128.9	1.0	8.50	1	1	1
07/06/2014 19:00	1.2	12.1	2,051.6	0.8	6.20	1	1	1
07/06/2014 20:00	1.3	12.0	2,073.1	0.9	6.20	1	1	1
07/06/2014 21:00	0.9	12.9	1,885.8	0.7	3.80	1	1	1
07/06/2014 22:00	0.8	13.1	1,853.3	0.6	3.70	1	1	1
07/06/2014 23:00	0.8	13.2	1,835.8	0.6	3.70	1	1	1
Average/Sum#:	1.6	13.5	1,663.8	1.7	130.69 #	22 #	19 #	13 #
Minimum:	0.7	11.7	308.3	0.6	1.26	0	0	0
Maximum:	7.6	17.5	2,128.9	8.5	29.00	1	1	1
%SI	8.3	8.3	8.3	8.3	8.33	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/07/2014 00:00	0.6	13.9	1,275.2	0.5	2.60	1	1	0
07/07/2014 01:00	0.6	13.9	1,251.6	0.5	2.50	1	1	0
07/07/2014 02:00	0.7	13.9	1,279.7	0.6	2.60	1	1	0
07/07/2014 03:00	0.7	13.9	1,332.2	0.6	2.70	1	1	0
07/07/2014 04:00	1.0	13.2	1,871.1	0.8	5.60	1	1	1
07/07/2014 05:00	0.9	13.3	1,866.1	0.7	5.60	1	1	1
07/07/2014 06:00	0.9	13.3	1,847.1	0.7	5.50	1	1	1
07/07/2014 07:00	0.9	13.2	1,847.6	0.7	5.50	1	1	1
07/07/2014 08:00	0.8	13.1	1,867.4	0.6	3.70	1	1	1
07/07/2014 09:00	0.8	13.1	1,853.8	0.6	3.70	1	1	1
07/07/2014 10:00	0.8	13.0	1,867.8	0.6	3.70	1	1	1
07/07/2014 11:00	0.9	13.1	1,844.5	0.7	5.50	1	1	1
07/07/2014 12:00	0.9	13.0	1,852.1	0.7	3.70	1	1	1
07/07/2014 13:00	0.9	13.0	1,855.6	0.7	3.70	1	1	1
07/07/2014 14:00	0.9	13.0	1,849.6	0.7	3.70	1	1	1
07/07/2014 15:00	0.9	13.0	1,848.1	0.7	3.70	1	1	1
07/07/2014 16:00	0.9	12.9	1,852.3	0.7	3.70	1	1	1
07/07/2014 17:00	0.9	12.9	1,874.1	0.7	3.70	1	1	1
07/07/2014 18:00	0.9	12.9	1,887.2	0.7	3.80	1	1	1
07/07/2014 19:00	0.9	12.8	1,900.3	0.7	3.80	1	1	1
07/07/2014 20:00	0.9	13.0	1,854.0	0.7	3.70	1	1	1
07/07/2014 21:00	0.9	13.1	1,839.9	0.7	5.50	1	1	1
07/07/2014 22:00	0.8	13.3	1,677.1	0.6	3.40	1	1	1
07/07/2014 23:00	0.8	13.2	1,846.1	0.6	3.70	1	1	1
Average/Sum#:	0.8	13.2	1,755.9	0.7	95.30 #	24 #	24 #	20 #
Minimum:	0.6	12.8	1,251.6	0.5	2.50	1	1	0
Maximum:	1.0	13.9	1,900.3	0.8	5.60	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/08/2014 00:00	0.9	13.0	1,873.0	0.7	3.70	1	1	1
07/08/2014 01:00	0.7	13.2	1,850.2	0.5	3.70	1	1	1
07/08/2014 02:00	0.7	13.2	1,847.9	0.5	3.70	1	1	1
07/08/2014 03:00	0.8	13.4	1,719.7	0.6	3.40	1	1	1
07/08/2014 04:00	0.9	12.9	1,913.5	0.7	3.80	1	1	1
07/08/2014 05:00	0.9	13.2	1,854.5	0.7	5.60	1	1	1
07/08/2014 06:00	0.9	12.8	1,925.8	0.7	3.90	1	1	1
07/08/2014 07:00	0.8	13.1	1,862.4	0.6	3.70	1	1	1
07/08/2014 08:00	0.8	13.0	1,883.1	0.6	3.80	1	1	1
07/08/2014 09:00	0.8	13.1	1,858.9	0.6	3.70	1	1	1
07/08/2014 10:00	0.9	12.7	1,939.6	0.6	3.90	1	1	1
07/08/2014 11:00	0.9	12.7	1,923.0	0.6	3.80	1	1	1
07/08/2014 12:00	1.2	12.1	2,063.8	0.8	6.20	1	1	1
07/08/2014 13:00	1.5	11.4	2,193.8	0.9	6.60	1	1	1
07/08/2014 14:00	1.3	11.6	2,119.4	0.8	6.40	1	1	1
07/08/2014 15:00	1.2	11.7	2,107.0	0.8	6.30	1	1	1
07/08/2014 16:00	1.3	11.7	2,115.1	0.8	6.30	1	1	1
07/08/2014 17:00	1.3	11.7	2,122.1	0.8	6.40	1	1	1
07/08/2014 18:00	1.2	12.0	2,058.5	0.8	6.20	1	1	1
07/08/2014 19:00	1.0	12.4	1,975.7	0.7	5.90	1	1	1
07/08/2014 20:00	0.9	13.0	1,871.9	0.7	3.70	1	1	1
07/08/2014 21:00	1.0	13.1	1,856.9	0.8	5.60	1	1	1
07/08/2014 22:00	0.8	13.6	1,487.5	0.6	3.00	1	1	1
07/08/2014 23:00	0.7	13.9	1,381.5	0.6	2.80	1	1	0
Average/Sum#:	1.0	12.7	1,908.5	0.7	112.10 #	24 #	24 #	23 #
Minimum:	0.7	11.4	1,381.5	0.5	2.80	1	1	0
Maximum:	1.5	13.9	2,193.8	0.9	6.60	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/09/2014 00:00	0.6	13.9	1,245.0	0.5	2.50	1	1	0
07/09/2014 01:00	0.5	13.8	1,242.6	0.4	2.50	1	1	0
07/09/2014 02:00	0.5	13.8	1,241.6	0.4	2.50	1	1	0
07/09/2014 03:00	0.5	13.8	1,241.7	0.4	2.50	1	1	0
07/09/2014 04:00	0.5	13.8	1,252.1	0.4	2.50	1	1	0
07/09/2014 05:00	0.8	13.8	1,547.2	0.7	3.10	1	1	0
07/09/2014 06:00	0.8	13.5	1,651.8	0.6	3.30	1	1	1
07/09/2014 07:00	1.1	12.8	1,958.0	0.8	5.90	1	1	1
07/09/2014 08:00	1.0	12.8	1,937.8	0.7	5.80	1	1	1
07/09/2014 09:00	1.0	12.4	2,004.4	0.7	6.00	1	1	1
07/09/2014 10:00	1.2	11.9	2,102.5	0.8	6.30	1	1	1
07/09/2014 11:00	1.4	11.5	2,165.4	0.9	6.50	1	1	1
07/09/2014 12:00	1.4	11.4	2,187.1	0.9	6.60	1	1	1
07/09/2014 13:00	1.4	11.5	2,147.8	0.9	6.40	1	1	1
07/09/2014 14:00	1.0	12.2	1,998.1	0.7	4.00	1	1	1
07/09/2014 15:00	1.2	11.9	2,066.3	0.8	6.20	1	1	1
07/09/2014 16:00	1.3	11.6	2,113.3	0.8	6.30	1	1	1
07/09/2014 17:00	1.3	11.6	2,105.5	0.8	6.30	1	1	1
07/09/2014 18:00	1.1	12.1	2,008.0	0.7	6.00	1	1	1
07/09/2014 19:00	1.0	12.5	1,940.7	0.7	5.80	1	1	1
07/09/2014 20:00	1.0	12.5	1,960.0	0.7	5.90	1	1	1
07/09/2014 21:00	1.0	12.6	1,929.8	0.7	5.80	1	1	1
07/09/2014 22:00	1.0	12.8	1,909.0	0.7	5.70	1	1	1
07/09/2014 23:00	0.7	13.5	1,450.9	0.6	2.90	1	1	1
Average/Sum#:	1.0	12.7	1,808.6	0.7	117.30 #	24 #	24 #	18 #
Minimum:	0.5	11.4	1,241.6	0.4	2.50	1	1	0
Maximum:	1.4	13.9	2,187.1	0.9	6.60	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/10/2014 00:00	0.5	13.8	1,238.8	0.4	2.50	1	1	0
07/10/2014 01:00	0.5	13.8	1,238.3	0.4	2.50	1	1	0
07/10/2014 02:00	0.5	13.8	1,238.7	0.4	2.50	1	1	0
07/10/2014 03:00	0.5	13.8	1,238.2	0.4	2.50	1	1	0
07/10/2014 04:00	0.5	13.8	1,238.7	0.4	2.50	1	1	0
07/10/2014 05:00	0.5	13.8	1,240.2	0.4	2.50	1	1	0
07/10/2014 06:00	0.5	13.8	1,241.5	0.4	2.50	1	1	0
07/10/2014 07:00	0.6	13.8	1,248.1	0.5	2.50	1	1	0
07/10/2014 08:00	0.6	13.8	1,258.6	0.5	2.50	1	1	0
07/10/2014 09:00	0.8	13.5	1,563.1	0.6	3.10	1	1	1
07/10/2014 10:00	0.8	13.2	1,846.0	0.6	3.70	1	1	1
07/10/2014 11:00	0.8	13.2	1,841.5	0.6	3.70	1	1	1
07/10/2014 12:00	0.9	13.1	1,874.5	0.7	5.60	1	1	1
07/10/2014 13:00	0.9	12.9	1,889.1	0.7	3.80	1	1	1
07/10/2014 14:00	1.0	12.8	1,895.5	0.7	5.70	1	1	1
07/10/2014 15:00	0.9	12.8	1,884.3	0.7	3.80	1	1	1
07/10/2014 16:00	0.9	12.5	1,937.5	0.6	3.90	1	1	1
07/10/2014 17:00	1.0	12.8	1,897.4	0.7	5.70	1	1	1
07/10/2014 18:00	1.2	12.6	1,944.7	0.9	5.80	1	1	1
07/10/2014 19:00	1.0	13.1	1,841.3	0.8	5.50	1	1	1
07/10/2014 20:00	0.9	13.2	1,837.6	0.7	5.50	1	1	1
07/10/2014 21:00	0.9	13.2	1,849.0	0.7	5.50	1	1	1
07/10/2014 22:00	0.9	13.3	1,830.4	0.7	5.50	1	1	1
07/10/2014 23:00	0.8	13.3	1,641.4	0.6	3.30	1	1	1
Average/Sum#:	0.8	13.3	1,614.8	0.6	92.60 #	24 #	24 #	15 #
Minimum:	0.5	12.5	1,238.2	0.4	2.50	1	1	0
Maximum:	1.2	13.8	1,944.7	0.9	5.80	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/11/2014 00:00	0.4	13.8	1,271.9	0.3	1.30	1	1	0
07/11/2014 01:00	2.2	15.7	618.1	2.5	1.51	1	0	0
07/11/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2014 05:00	1.1	17.3	489.5	1.8	2.04	1	0	0
07/11/2014 06:00	6.4	14.5	1,039.4	5.9	22.90	1	0	0
07/11/2014 07:00	0.4	13.8	1,288.4	0.3	1.30	1	1	0
07/11/2014 08:00	0.5	13.8	1,292.3	0.4	2.60	1	1	0
07/11/2014 09:00	0.7	13.8	1,497.6	0.6	3.00	1	1	0
07/11/2014 10:00	0.6	13.9	1,298.3	0.5	2.60	1	1	0
07/11/2014 11:00	0.6	13.9	1,270.7	0.5	2.50	1	1	0
07/11/2014 12:00	0.6	13.9	1,271.3	0.5	2.50	1	1	0
07/11/2014 13:00	0.6	13.9	1,271.5	0.5	2.50	1	1	0
07/11/2014 14:00	0.7	13.9	1,273.6	0.6	2.50	1	1	0
07/11/2014 15:00	0.7	14.0	1,275.2	0.6	2.60	1	1	0
07/11/2014 16:00	0.7	14.0	1,275.8	0.6	2.60	1	1	0
07/11/2014 17:00	0.6	14.0	1,275.3	0.5	2.60	1	1	0
07/11/2014 18:00	0.6	13.9	1,271.2	0.5	2.50	1	1	0
07/11/2014 19:00	0.6	13.9	1,268.9	0.5	2.50	1	1	0
07/11/2014 20:00	0.6	13.9	1,269.3	0.5	2.50	1	1	0
07/11/2014 21:00	0.6	13.9	1,262.7	0.5	2.50	1	1	0
07/11/2014 22:00	0.5	13.8	1,262.6	0.4	2.50	1	1	0
07/11/2014 23:00	0.5	13.8	1,263.2	0.4	2.50	1	1	0
Average/Sum#:	1.0	14.2	1,205.1	0.9	70.05 #	21 #	18 #	0 #
Minimum:	0.4	13.8	489.5	0.3	1.30	0	0	0
Maximum:	6.4	17.3	1,497.6	5.9	22.90	1	1	0
%SI	12.5	12.5	12.5	12.5	12.50	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/12/2014 00:00	3.2	15.8	532.4	3.7	1.65	1	0	0
07/12/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/12/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/12/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/12/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/12/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/12/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/12/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/12/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/12/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/12/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/12/2014 11:00	25.2	16.6	619.4	34.6	68.47	1	0	0
07/12/2014 12:00	1.2	13.9	1,344.5	1.0	5.40	1	0	0
07/12/2014 13:00	0.8	13.7	1,648.0	0.7	3.30	1	1	0
07/12/2014 14:00	0.8	13.3	1,758.5	0.6	3.50	1	1	1
07/12/2014 15:00	1.1	12.0	2,045.8	0.7	6.10	1	1	1
07/12/2014 16:00	1.0	12.7	1,917.9	0.7	5.80	1	1	1
07/12/2014 17:00	1.0	12.6	1,935.3	0.7	5.80	1	1	1
07/12/2014 18:00	1.0	12.7	1,923.9	0.7	5.80	1	1	1
07/12/2014 19:00	0.9	13.0	1,861.4	0.7	3.70	1	1	1
07/12/2014 20:00	1.0	13.0	1,869.9	0.7	5.60	1	1	1
07/12/2014 21:00	1.0	12.7	1,950.9	0.7	5.90	1	1	1
07/12/2014 22:00	1.1	12.4	2,007.3	0.8	6.00	1	1	1
07/12/2014 23:00	1.0	12.7	1,946.8	0.7	5.80	1	1	1
Average/Sum#:	2.9	13.4	1,668.7	3.4	132.82 #	14 #	11 #	10 #
Minimum:	0.8	12.0	532.4	0.6	1.65	0	0	0
Maximum:	25.2	16.6	2,045.8	34.6	68.47	1	1	1
%SI	41.7	41.7	41.7	41.7	41.67	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/13/2014 00:00	0.9	13.3	1,654.0	0.7	5.00	1	1	1
07/13/2014 01:00	3.2	15.8	536.4	3.7	1.65	1	0	0
07/13/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/13/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/13/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/13/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/13/2014 06:00	13.7	17.5	450.6	23.8	19.85	1	0	0
07/13/2014 07:00	10.4	15.1	940.5	10.6	36.70	1	0	0
07/13/2014 08:00	0.5	13.8	1,462.3	0.4	2.90	1	1	0
07/13/2014 09:00	0.7	13.7	1,737.2	0.6	3.50	1	1	0
07/13/2014 10:00	0.7	13.8	1,678.7	0.6	3.40	1	1	0
07/13/2014 11:00	0.7	13.8	1,492.9	0.6	3.00	1	1	1
07/13/2014 12:00	0.9	12.9	1,889.4	0.7	3.80	1	1	1
07/13/2014 13:00	1.0	12.1	2,020.0	0.7	4.00	1	1	1
07/13/2014 14:00	1.2	11.8	2,076.1	0.8	6.20	1	1	1
07/13/2014 15:00	1.5	11.3	2,170.6	0.9	6.50	1	1	1
07/13/2014 16:00	1.2	12.1	2,010.0	0.8	6.00	1	1	1
07/13/2014 17:00	1.0	12.3	1,978.9	0.7	5.90	1	1	1
07/13/2014 18:00	1.0	12.2	1,984.7	0.7	4.00	1	1	1
07/13/2014 19:00	0.9	12.8	1,881.4	0.7	3.80	1	1	1
07/13/2014 20:00	0.7	13.6	1,539.0	0.6	3.10	1	1	1
07/13/2014 21:00	0.8	13.3	1,755.2	0.6	3.50	1	1	1
07/13/2014 22:00	0.9	12.7	1,896.1	0.6	3.80	1	1	1
07/13/2014 23:00	0.7	13.6	1,465.0	0.6	2.90	1	1	1
Average/Sum#:	2.1	13.4	1,631.0	2.5	129.50 #	20 #	17 #	14 #
Minimum:	0.5	11.3	450.6	0.4	1.65	0	0	0
Maximum:	13.7	17.5	2,170.6	23.8	36.70	1	1	1
%SI	16.7	16.7	16.7	16.7	16.67	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/14/2014 00:00	0.6	13.9	1,379.9	0.5	2.80	1	1	0
07/14/2014 01:00	0.7	13.9	1,471.6	0.6	2.90	1	1	0
07/14/2014 02:00	0.7	13.9	1,408.9	0.6	2.80	1	1	0
07/14/2014 03:00	0.8	13.7	1,722.2	0.7	3.40	1	1	0
07/14/2014 04:00	0.8	13.7	1,726.7	0.7	3.50	1	1	0
07/14/2014 05:00	0.8	13.7	1,607.7	0.7	3.20	1	1	1
07/14/2014 06:00	1.1	12.5	2,026.1	0.8	6.10	1	1	1
07/14/2014 07:00	1.0	12.8	1,960.1	0.7	5.90	1	1	1
07/14/2014 08:00	0.9	12.9	1,897.6	0.7	3.80	1	1	1
07/14/2014 09:00	0.9	12.8	1,917.3	0.7	3.80	1	1	1
07/14/2014 10:00	0.9	13.0	1,860.8	0.7	3.70	1	1	1
07/14/2014 11:00	0.9	12.9	1,875.0	0.7	3.80	1	1	1
07/14/2014 12:00	1.0	12.8	1,883.4	0.7	5.70	1	1	1
07/14/2014 13:00	1.1	12.5	1,942.5	0.8	5.80	1	1	1
07/14/2014 14:00	1.3	11.7	2,077.2	0.8	6.20	1	1	1
07/14/2014 15:00	1.3	11.7	2,060.8	0.8	6.20	1	1	1
07/14/2014 16:00	1.2	11.9	2,017.8	0.8	6.10	1	1	1
07/14/2014 17:00	1.1	12.2	1,968.7	0.7	5.90	1	1	1
07/14/2014 18:00	0.8	13.6	1,551.8	0.6	3.10	1	1	1
07/14/2014 19:00	0.8	13.9	1,439.1	0.7	2.90	1	1	0
07/14/2014 20:00	1.0	13.7	1,629.1	0.8	4.90	1	1	0
07/14/2014 21:00	0.9	13.8	1,637.9	0.7	4.90	1	1	0
07/14/2014 22:00	0.8	13.8	1,508.1	0.7	3.00	1	1	0
07/14/2014 23:00	1.0	13.7	1,646.9	0.8	4.90	1	1	0
Average/Sum#:	0.9	13.1	1,759.1	0.7	105.30 #	24 #	24 #	14 #
Minimum:	0.6	11.7	1,379.9	0.5	2.80	1	1	0
Maximum:	1.3	13.9	2,077.2	0.8	6.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/15/2014 00:00	1.1	13.6	1,747.0	0.9	5.20	1	1	0
07/15/2014 01:00	1.1	13.6	1,773.9	0.9	5.30	1	1	0
07/15/2014 02:00	1.0	13.6	1,769.2	0.8	5.30	1	1	0
07/15/2014 03:00	1.0	13.3	1,809.2	0.8	5.40	1	1	1
07/15/2014 04:00	1.2	12.9	1,938.7	0.9	5.80	1	1	1
07/15/2014 05:00	1.2	12.6	1,989.8	0.9	6.00	1	1	1
07/15/2014 06:00	1.1	13.0	1,890.3	0.8	5.70	1	1	1
07/15/2014 07:00	1.0	13.3	1,844.4	0.8	5.50	1	1	1
07/15/2014 08:00	0.9	13.3	1,840.0	0.7	5.50	1	1	1
07/15/2014 09:00	1.1	13.2	1,851.3	0.8	5.60	1	1	1
07/15/2014 10:00	1.2	13.1	1,874.1	0.9	5.60	1	1	1
07/15/2014 11:00	1.2	13.1	1,869.6	0.9	5.60	1	1	1
07/15/2014 12:00	1.2	13.1	1,859.7	0.9	5.60	1	1	1
07/15/2014 13:00	1.2	13.2	1,855.3	0.9	5.60	1	1	1
07/15/2014 14:00	1.2	12.9	1,923.3	0.9	5.80	1	1	1
07/15/2014 15:00	1.2	12.7	1,925.1	0.9	5.80	1	1	1
07/15/2014 16:00	1.1	12.9	1,879.3	0.8	5.60	1	1	1
07/15/2014 17:00	1.1	12.8	1,908.7	0.8	5.70	1	1	1
07/15/2014 18:00	1.1	12.8	1,882.9	0.8	5.60	1	1	1
07/15/2014 19:00	1.1	12.8	1,903.6	0.8	5.70	1	1	1
07/15/2014 20:00	1.1	12.8	1,891.8	0.8	5.70	1	1	1
07/15/2014 21:00	1.1	12.8	1,901.4	0.8	5.70	1	1	1
07/15/2014 22:00	1.1	12.9	1,888.8	0.8	5.70	1	1	1
07/15/2014 23:00	1.2	12.8	1,915.0	0.9	5.70	1	1	1
Average/Sum#:	1.1	13.0	1,872.2	0.8	134.70 #	24 #	24 #	21 #
Minimum:	0.9	12.6	1,747.0	0.7	5.20	1	1	0
Maximum:	1.2	13.6	1,989.8	0.9	6.00	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/16/2014 00:00	1.1	12.9	1,880.1	0.8	5.60	1	1	1
07/16/2014 01:00	0.9	13.6	1,472.9	0.7	4.40	1	1	1
07/16/2014 02:00	0.9	13.8	1,421.7	0.7	4.30	1	1	0
07/16/2014 03:00	0.9	13.8	1,468.9	0.7	4.40	1	1	0
07/16/2014 04:00	1.0	13.6	1,743.9	0.8	5.20	1	1	0
07/16/2014 05:00	0.9	13.5	1,618.2	0.7	4.90	1	1	1
07/16/2014 06:00	1.1	13.4	1,709.5	0.9	5.10	1	1	1
07/16/2014 07:00	1.1	13.8	1,587.8	0.9	4.80	1	1	0
07/16/2014 08:00	1.0	13.6	1,697.8	0.8	5.10	1	1	1
07/16/2014 09:00	1.0	13.2	1,841.3	0.8	5.50	1	1	1
07/16/2014 10:00	1.0	13.2	1,844.3	0.8	5.50	1	1	1
07/16/2014 11:00	1.1	13.2	1,844.6	0.8	5.50	1	1	1
07/16/2014 12:00	1.1	13.2	1,840.2	0.8	5.50	1	1	1
07/16/2014 13:00	1.1	13.1	1,842.6	0.8	5.50	1	1	1
07/16/2014 14:00	1.1	13.0	1,849.6	0.8	5.50	1	1	1
07/16/2014 15:00	1.1	13.0	1,852.3	0.8	5.60	1	1	1
07/16/2014 16:00	1.1	12.9	1,863.8	0.8	5.60	1	1	1
07/16/2014 17:00	1.1	12.9	1,872.4	0.8	5.60	1	1	1
07/16/2014 18:00	1.1	12.9	1,867.5	0.8	5.60	1	1	1
07/16/2014 19:00	1.1	13.0	1,851.4	0.8	5.60	1	1	1
07/16/2014 20:00	1.0	13.0	1,844.4	0.7	5.50	1	1	1
07/16/2014 21:00	0.9	13.6	1,580.6	0.7	4.70	1	1	1
07/16/2014 22:00	1.0	13.5	1,698.8	0.8	5.10	1	1	1
07/16/2014 23:00	1.0	13.4	1,673.5	0.8	5.00	1	1	1
Average/Sum#:	1.0	13.3	1,740.3	0.8	125.10 #	24 #	24 #	20 #
Minimum:	0.9	12.9	1,421.7	0.7	4.30	1	1	0
Maximum:	1.1	13.8	1,880.1	0.9	5.60	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/17/2014 00:00	3.2	15.7	561.9	3.6	1.61	1	0	0
07/17/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/17/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/17/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/17/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/17/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/17/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/17/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/17/2014 08:00	15.1	17.7	421.5	27.8	16.06	1	0	0
07/17/2014 09:00	12.8	14.5	1,202.2	11.8	51.70	1	0	0
07/17/2014 10:00	0.9	13.5	1,599.6	0.7	4.80	1	1	1
07/17/2014 11:00	1.1	13.2	1,822.5	0.8	5.50	1	1	1
07/17/2014 12:00	1.1	13.2	1,818.0	0.8	5.50	1	1	1
07/17/2014 13:00	1.1	13.1	1,826.4	0.8	5.50	1	1	1
07/17/2014 14:00	1.1	13.1	1,823.4	0.8	5.50	1	1	1
07/17/2014 15:00	1.1	13.0	1,831.6	0.8	5.50	1	1	1
07/17/2014 16:00	1.0	13.0	1,837.2	0.7	5.50	1	1	1
07/17/2014 17:00	1.0	12.9	1,850.3	0.7	5.60	1	1	1
07/17/2014 18:00	1.1	12.5	1,927.1	0.8	5.80	1	1	1
07/17/2014 19:00	1.2	12.4	1,950.1	0.8	5.90	1	1	1
07/17/2014 20:00	1.0	12.9	1,857.3	0.7	5.60	1	1	1
07/17/2014 21:00	1.1	12.8	1,896.9	0.8	5.70	1	1	1
07/17/2014 22:00	0.9	13.5	1,645.9	0.7	4.90	1	1	1
07/17/2014 23:00	0.8	13.8	1,405.0	0.7	2.80	1	1	0
Average/Sum#:	2.7	13.6	1,604.5	3.2	143.47 #	17 #	14 #	13 #
Minimum:	0.8	12.4	421.5	0.7	1.61	0	0	0
Maximum:	15.1	17.7	1,950.1	27.8	51.70	1	1	1
%SI	29.2	29.2	29.2	29.2	29.17	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/18/2014 00:00	3.4	15.7	558.4	3.9	1.72	1	0	0
07/18/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/18/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/18/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/18/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/18/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/18/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/18/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/18/2014 08:00	21.5	16.4	649.6	28.2	58.81	1	0	0
07/18/2014 09:00	0.8	13.5	1,579.6	0.6	3.20	1	0	1
07/18/2014 10:00	1.1	13.2	1,851.7	0.8	5.60	1	1	1
07/18/2014 11:00	1.0	13.2	1,843.0	0.8	5.50	1	1	1
07/18/2014 12:00	1.0	13.3	1,836.9	0.8	5.50	1	1	1
07/18/2014 13:00	1.2	13.2	1,838.2	0.9	5.50	1	1	1
07/18/2014 14:00	1.1	13.2	1,835.3	0.8	5.50	1	1	1
07/18/2014 15:00	1.2	13.0	1,866.3	0.9	5.60	1	1	1
07/18/2014 16:00	1.1	12.9	1,889.4	0.8	5.70	1	1	1
07/18/2014 17:00	1.4	11.7	2,120.5	0.9	6.40	1	1	1
07/18/2014 18:00	1.5	11.5	2,137.3	0.9	6.40	1	1	1
07/18/2014 19:00	1.3	11.9	2,074.8	0.9	6.20	1	1	1
07/18/2014 20:00	1.2	12.4	1,978.8	0.8	5.90	1	1	1
07/18/2014 21:00	1.1	13.1	1,849.9	0.8	5.50	1	1	1
07/18/2014 22:00	0.9	13.5	1,600.5	0.7	4.80	1	1	1
07/18/2014 23:00	0.8	13.8	1,298.0	0.7	2.60	1	1	0
Average/Sum#:	2.4	13.3	1,694.6	2.6	140.43 #	17 #	14 #	14 #
Minimum:	0.8	11.5	558.4	0.6	1.72	0	0	0
Maximum:	21.5	16.4	2,137.3	28.2	58.81	1	1	1
%SI	29.2	29.2	29.2	29.2	29.17	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/19/2014 00:00	3.1	15.1	830.2	3.2	3.20	1	0	0
07/19/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/19/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/19/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/19/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/19/2014 05:00	18.8	17.6	436.7	33.6	23.31	1	0	0
07/19/2014 06:00	9.0	14.9	1,030.7	8.9	34.00	1	0	0
07/19/2014 07:00	1.0	13.6	1,768.0	0.8	5.30	1	1	0
07/19/2014 08:00	1.1	13.6	1,752.8	0.9	5.30	1	1	0
07/19/2014 09:00	1.1	13.7	1,739.6	0.9	5.20	1	1	0
07/19/2014 10:00	0.9	13.8	1,515.4	0.7	4.50	1	1	1
07/19/2014 11:00	1.3	12.1	2,042.1	0.9	6.10	1	1	1
07/19/2014 12:00	1.5	11.5	2,129.9	0.9	6.40	1	1	1
07/19/2014 13:00	1.6	11.1	2,212.3	1.0	8.80	1	1	1
07/19/2014 14:00	1.6	11.3	2,178.4	1.0	8.70	1	1	1
07/19/2014 15:00	1.6	11.3	2,159.6	1.0	8.60	1	1	1
07/19/2014 16:00	1.5	11.5	2,110.5	0.9	6.30	1	1	1
07/19/2014 17:00	1.4	11.6	2,100.1	0.9	6.30	1	1	1
07/19/2014 18:00	1.1	12.4	1,951.9	0.8	5.90	1	1	1
07/19/2014 19:00	1.3	11.9	2,049.3	0.9	6.10	1	1	1
07/19/2014 20:00	1.5	11.5	2,124.9	0.9	6.40	1	1	1
07/19/2014 21:00	1.3	12.2	1,991.9	0.9	6.00	1	1	1
07/19/2014 22:00	0.9	13.7	1,529.6	0.7	4.60	1	1	1
07/19/2014 23:00	0.9	13.8	1,502.3	0.7	4.50	1	1	0
Average/Sum#:	2.6	12.9	1,757.8	3.0	165.51 #	20 #	17 #	13 #
Minimum:	0.9	11.1	436.7	0.7	3.20	0	0	0
Maximum:	18.8	17.6	2,212.3	33.6	34.00	1	1	1
%SI	16.7	16.7	16.7	16.7	16.67	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/20/2014 00:00	3.1	15.7	554.2	3.5	1.58	1	0	0
07/20/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	3.1	15.7	554.2	3.5	1.58 #	1 #	0 #	0 #
Minimum:	3.1	15.7	554.2	3.5	1.58	0	0	0
Maximum:	3.1	15.7	554.2	3.5	1.58	1	0	0
%SI	95.8	95.8	95.8	95.8	95.83	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/21/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/21/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/21/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/21/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/21/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/21/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/21/2014 06:00	29.8	17.2	492.7	47.5	60.34	1	0	0
07/21/2014 07:00	11.9	14.4	1,206.8	10.8	48.30	1	0	1
07/21/2014 08:00	1.0	13.0	1,890.5	0.7	5.70	1	1	1
07/21/2014 09:00	1.2	12.7	1,934.8	0.9	5.80	1	1	1
07/21/2014 10:00	1.2	12.8	1,935.6	0.9	5.80	1	1	1
07/21/2014 11:00	1.2	12.9	1,922.3	0.9	5.80	1	1	1
07/21/2014 12:00	1.2	12.8	1,914.5	0.9	5.70	1	1	1
07/21/2014 13:00	1.2	12.9	1,906.6	0.9	5.70	1	1	1
07/21/2014 14:00	1.1	12.8	1,917.6	0.8	5.80	1	1	1
07/21/2014 15:00	1.2	12.5	1,981.1	0.8	5.90	1	1	1
07/21/2014 16:00	1.2	12.4	1,981.5	0.8	5.90	1	1	1
07/21/2014 17:00	1.5	11.5	2,162.5	0.9	6.50	1	1	1
07/21/2014 18:00	1.7	11.1	2,236.5	1.0	8.90	1	1	1
07/21/2014 19:00	1.7	11.1	2,246.6	1.0	9.00	1	1	1
07/21/2014 20:00	1.6	11.1	2,247.7	1.0	9.00	1	1	1
07/21/2014 21:00	1.5	11.7	2,144.9	1.0	8.60	1	1	1
07/21/2014 22:00	1.3	12.4	2,005.2	0.9	6.00	1	1	1
07/21/2014 23:00	1.2	12.7	1,936.9	0.9	5.80	1	1	1
Average/Sum#:	3.5	12.7	1,892.5	4.0	214.54 #	18 #	16 #	17 #
Minimum:	1.0	11.1	492.7	0.7	5.70	0	0	0
Maximum:	29.8	17.2	2,247.7	47.5	60.34	1	1	1
%SI	25.0	25.0	25.0	25.0	25.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/22/2014 00:00	1.0	13.3	1,835.3	0.8	5.50	1	1	1
07/22/2014 01:00	1.1	13.2	1,853.4	0.8	5.60	1	1	1
07/22/2014 02:00	1.1	13.2	1,846.9	0.8	5.50	1	1	1
07/22/2014 03:00	1.1	13.3	1,835.9	0.9	5.50	1	1	1
07/22/2014 04:00	1.2	13.0	1,911.9	0.9	5.70	1	1	1
07/22/2014 05:00	1.1	13.2	1,868.5	0.8	5.60	1	1	1
07/22/2014 06:00	1.1	13.2	1,850.7	0.8	5.60	1	1	1
07/22/2014 07:00	1.3	12.8	1,937.5	0.9	5.80	1	1	1
07/22/2014 08:00	1.1	13.2	1,853.7	0.8	5.60	1	1	1
07/22/2014 09:00	0.8	13.3	1,842.3	0.6	3.70	1	1	1
07/22/2014 10:00	0.9	13.2	1,830.9	0.7	5.50	1	1	1
07/22/2014 11:00	0.9	12.8	1,913.4	0.7	3.80	1	1	1
07/22/2014 12:00	1.1	12.3	2,020.5	0.8	6.10	1	1	1
07/22/2014 13:00	1.0	12.5	1,975.0	0.7	5.90	1	1	1
07/22/2014 14:00	1.0	12.3	2,005.2	0.7	6.00	1	1	1
07/22/2014 15:00	1.2	11.6	2,139.3	0.8	6.40	1	1	1
07/22/2014 16:00	1.1	11.9	2,069.2	0.7	6.20	1	1	1
07/22/2014 17:00	1.0	12.1	2,024.1	0.7	4.00	1	1	1
07/22/2014 18:00	1.3	11.7	2,133.0	0.8	6.40	1	1	1
07/22/2014 19:00	1.2	12.1	2,085.5	0.8	6.30	1	1	1
07/22/2014 20:00	1.1	12.2	2,066.6	0.7	6.20	1	1	1
07/22/2014 21:00	1.1	12.2	2,066.4	0.7	6.20	1	1	1
07/22/2014 22:00	1.0	12.7	1,967.9	0.7	5.90	1	1	1
07/22/2014 23:00	0.7	13.6	1,541.9	0.6	3.10	1	1	1
Average/Sum#:	1.1	12.7	1,936.5	0.8	132.10 #	24 #	24 #	24 #
Minimum:	0.7	11.6	1,541.9	0.6	3.10	1	1	1
Maximum:	1.3	13.6	2,139.3	0.9	6.40	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/23/2014 00:00	0.6	13.8	1,282.3	0.5	2.60	1	1	0
07/23/2014 01:00	0.6	13.8	1,265.8	0.5	2.50	1	1	0
07/23/2014 02:00	0.6	13.8	1,248.3	0.5	2.50	1	1	0
07/23/2014 03:00	0.6	13.8	1,247.8	0.5	2.50	1	1	0
07/23/2014 04:00	0.6	13.8	1,269.3	0.5	2.50	1	1	0
07/23/2014 05:00	0.8	13.6	1,554.2	0.6	3.10	1	1	1
07/23/2014 06:00	0.9	13.1	1,915.8	0.7	5.70	1	1	1
07/23/2014 07:00	0.0	13.1	1,913.5	0.0	0.00	1	1	1
07/23/2014 08:00	0.0	13.2	1,886.6	0.0	0.00	1	1	1
07/23/2014 09:00	0.0	13.2	1,881.0	0.0	0.00	1	1	1
07/23/2014 10:00	1.0	13.2	1,856.1	0.8	5.60	1	1	1
07/23/2014 11:00	1.0	13.2	1,858.8	0.8	5.60	1	1	1
07/23/2014 12:00	0.9	13.2	1,860.3	0.7	5.60	1	1	1
07/23/2014 13:00	0.9	13.3	1,852.7	0.7	5.60	1	1	1
07/23/2014 14:00	0.9	13.0	1,894.5	0.7	3.80	1	1	1
07/23/2014 15:00	0.9	12.5	2,002.7	0.6	4.00	1	1	1
07/23/2014 16:00	1.1	12.0	2,077.5	0.7	6.20	1	1	1
07/23/2014 17:00	1.0	12.6	1,964.5	0.7	5.90	1	1	1
07/23/2014 18:00	1.0	12.4	2,013.6	0.7	6.00	1	1	1
07/23/2014 19:00	0.9	12.4	1,987.9	0.6	4.00	1	1	1
07/23/2014 20:00	0.9	12.7	1,946.6	0.6	3.90	1	1	1
07/23/2014 21:00	1.1	12.8	1,917.0	0.8	5.80	1	1	1
07/23/2014 22:00	0.9	13.2	1,859.7	0.7	5.60	1	1	1
07/23/2014 23:00	0.9	13.0	1,901.3	0.7	3.80	1	1	1
Average/Sum#:	0.9	13.1	1,769.1	0.6	92.80 #	24 #	24 #	19 #
Minimum:	0.6	12.0	1,247.8	0.5	2.50	1	1	0
Maximum:	1.1	13.8	2,077.5	0.8	6.20	1	1	1
%SI	12.5	0.0	0.0	12.5	12.50	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/24/2014 00:00	0.8	13.2	1,866.4	0.6	3.70	1	1	1
07/24/2014 01:00	0.9	13.2	1,872.6	0.7	5.60	1	1	1
07/24/2014 02:00	0.7	13.7	1,488.0	0.6	3.00	1	1	1
07/24/2014 03:00	0.7	13.9	1,251.5	0.6	2.50	1	1	0
07/24/2014 04:00	0.6	13.9	1,247.4	0.5	2.50	1	1	0
07/24/2014 05:00	0.7	13.9	1,251.7	0.6	2.50	1	1	0
07/24/2014 06:00	0.7	13.9	1,254.5	0.6	2.50	1	1	0
07/24/2014 07:00	0.7	13.9	1,258.9	0.6	2.50	1	1	0
07/24/2014 08:00	0.9	13.7	1,579.2	0.7	4.70	1	1	1
07/24/2014 09:00	1.0	13.1	1,902.1	0.8	5.70	1	1	1
07/24/2014 10:00	1.0	13.0	1,914.0	0.7	5.70	1	1	1
07/24/2014 11:00	0.9	12.8	1,940.0	0.7	3.90	1	1	1
07/24/2014 12:00	1.1	12.1	2,074.6	0.7	6.20	1	1	1
07/24/2014 13:00	1.7	11.2	2,244.0	1.0	9.00	1	1	1
07/24/2014 14:00	1.5	11.4	2,198.1	0.9	6.60	1	1	1
07/24/2014 15:00	1.2	12.0	2,075.4	0.8	6.20	1	1	1
07/24/2014 16:00	1.2	12.0	2,080.2	0.8	6.20	1	1	1
07/24/2014 17:00	1.2	12.0	2,080.7	0.8	6.20	1	1	1
07/24/2014 18:00	1.2	12.0	2,073.9	0.8	6.20	1	1	1
07/24/2014 19:00	1.2	12.2	2,055.5	0.8	6.20	1	1	1
07/24/2014 20:00	1.1	12.3	2,021.4	0.8	6.10	1	1	1
07/24/2014 21:00	1.0	13.4	1,684.7	0.8	5.10	1	1	1
07/24/2014 22:00	1.0	13.1	1,878.5	0.8	5.60	1	1	1
07/24/2014 23:00	1.1	12.4	2,023.1	0.8	6.10	1	1	1
Average/Sum#:	1.0	12.8	1,804.9	0.7	120.50 #	24 #	24 #	19 #
Minimum:	0.6	11.2	1,247.4	0.5	2.50	1	1	0
Maximum:	1.7	13.9	2,244.0	1.0	9.00	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/25/2014 00:00	1.1	13.1	1,881.4	0.8	5.60	1	1	1
07/25/2014 01:00	1.1	13.4	1,841.8	0.9	5.50	1	1	1
07/25/2014 02:00	1.0	13.4	1,839.3	0.8	5.50	1	1	1
07/25/2014 03:00	1.0	13.4	1,837.3	0.8	5.50	1	1	1
07/25/2014 04:00	1.0	13.2	1,880.8	0.8	5.60	1	1	1
07/25/2014 05:00	1.0	13.1	1,899.0	0.8	5.70	1	1	1
07/25/2014 06:00	1.0	13.1	1,900.3	0.8	5.70	1	1	1
07/25/2014 07:00	1.1	13.0	1,904.0	0.8	5.70	1	1	1
07/25/2014 08:00	1.1	13.2	1,865.3	0.8	5.60	1	1	1
07/25/2014 09:00	1.0	12.9	1,902.5	0.7	5.70	1	1	1
07/25/2014 10:00	1.2	12.2	2,045.8	0.8	6.10	1	1	1
07/25/2014 11:00	1.4	11.7	2,138.1	0.9	6.40	1	1	1
07/25/2014 12:00	1.3	11.9	2,098.0	0.9	6.30	1	1	1
07/25/2014 13:00	1.1	12.3	1,988.1	0.8	6.00	1	1	1
07/25/2014 14:00	1.2	12.2	2,040.3	0.8	6.10	1	1	1
07/25/2014 15:00	1.5	11.7	2,123.8	1.0	8.50	1	1	1
07/25/2014 16:00	1.4	11.8	2,100.4	0.9	6.30	1	1	1
07/25/2014 17:00	1.5	11.6	2,148.2	1.0	8.60	1	1	1
07/25/2014 18:00	1.4	11.7	2,147.9	0.9	6.40	1	1	1
07/25/2014 19:00	1.5	11.4	2,185.8	0.9	6.60	1	1	1
07/25/2014 20:00	1.4	11.9	2,083.7	0.9	6.30	1	1	1
07/25/2014 21:00	1.2	12.3	2,013.1	0.8	6.00	1	1	1
07/25/2014 22:00	1.1	12.4	2,000.4	0.8	6.00	1	1	1
07/25/2014 23:00	1.0	12.9	1,903.4	0.7	5.70	1	1	1
Average/Sum#:	1.2	12.5	1,990.4	0.8	147.40 #	24 #	24 #	24 #
Minimum:	1.0	11.4	1,837.3	0.7	5.50	1	1	1
Maximum:	1.5	13.4	2,185.8	1.0	8.60	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/26/2014 00:00	1.0	13.1	1,858.5	0.8	5.60	1	1	1
07/26/2014 01:00	1.0	13.3	1,839.3	0.8	5.50	1	1	1
07/26/2014 02:00	0.9	13.3	1,838.7	0.7	5.50	1	1	1
07/26/2014 03:00	0.9	13.3	1,836.3	0.7	5.50	1	1	1
07/26/2014 04:00	1.0	13.2	1,875.8	0.8	5.60	1	1	1
07/26/2014 05:00	0.9	13.3	1,834.2	0.7	5.50	1	1	1
07/26/2014 06:00	1.0	13.4	1,826.9	0.8	5.50	1	1	1
07/26/2014 07:00	1.0	13.2	1,847.5	0.8	5.50	1	1	1
07/26/2014 08:00	1.0	13.2	1,845.3	0.8	5.50	1	1	1
07/26/2014 09:00	0.9	13.2	1,830.7	0.7	5.50	1	1	1
07/26/2014 10:00	0.9	13.1	1,840.0	0.7	5.50	1	1	1
07/26/2014 11:00	1.1	12.6	1,965.1	0.8	5.90	1	1	1
07/26/2014 12:00	1.4	11.6	2,116.1	0.9	6.30	1	1	1
07/26/2014 13:00	1.4	11.6	2,119.2	0.9	6.40	1	1	1
07/26/2014 14:00	1.2	12.1	2,007.7	0.8	6.00	1	1	1
07/26/2014 15:00	0.9	13.4	1,655.6	0.7	5.00	1	1	1
07/26/2014 16:00	0.9	13.4	1,622.7	0.7	4.90	1	1	1
07/26/2014 17:00	1.0	12.7	1,920.1	0.7	5.80	1	1	1
07/26/2014 18:00	1.0	13.0	1,818.0	0.7	5.50	1	1	1
07/26/2014 19:00	0.8	13.9	1,260.1	0.7	2.50	1	1	0
07/26/2014 20:00	1.0	14.0	1,246.4	0.9	3.70	1	1	0
07/26/2014 21:00	0.8	14.0	1,246.0	0.7	3.70	1	1	0
07/26/2014 22:00	0.8	13.9	1,244.5	0.7	2.50	1	1	0
07/26/2014 23:00	0.8	13.9	1,405.3	0.7	2.80	1	1	0
Average/Sum#:	1.0	13.2	1,745.8	0.8	121.70 #	24 #	24 #	19 #
Minimum:	0.8	11.6	1,244.5	0.7	2.50	1	1	0
Maximum:	1.4	14.0	2,119.2	0.9	6.40	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/27/2014 00:00	0.8	13.8	1,502.1	0.7	3.00	1	1	0
07/27/2014 01:00	0.8	13.9	1,352.2	0.7	2.70	1	1	0
07/27/2014 02:00	0.8	13.8	1,377.5	0.7	2.80	1	1	0
07/27/2014 03:00	0.7	13.9	1,272.9	0.6	2.50	1	1	0
07/27/2014 04:00	0.7	13.9	1,329.6	0.6	2.70	1	1	0
07/27/2014 05:00	0.7	13.9	1,283.8	0.6	2.60	1	1	0
07/27/2014 06:00	0.9	13.6	1,527.8	0.7	4.60	1	1	1
07/27/2014 07:00	1.0	13.0	1,879.8	0.7	5.60	1	1	1
07/27/2014 08:00	1.0	13.3	1,775.9	0.8	5.30	1	1	1
07/27/2014 09:00	1.0	13.1	1,858.4	0.8	5.60	1	1	1
07/27/2014 10:00	1.1	12.9	1,882.6	0.8	5.60	1	1	1
07/27/2014 11:00	1.2	12.2	2,022.0	0.8	6.10	1	1	1
07/27/2014 12:00	1.2	12.5	1,971.8	0.8	5.90	1	1	1
07/27/2014 13:00	1.1	12.6	1,950.6	0.8	5.90	1	1	1
07/27/2014 14:00	1.0	12.9	1,898.8	0.7	5.70	1	1	1
07/27/2014 15:00	1.3	12.1	2,060.5	0.9	6.20	1	1	1
07/27/2014 16:00	1.4	11.9	2,087.9	0.9	6.30	1	1	1
07/27/2014 17:00	1.4	11.8	2,101.3	0.9	6.30	1	1	1
07/27/2014 18:00	1.4	11.8	2,101.0	0.9	6.30	1	1	1
07/27/2014 19:00	1.3	12.0	2,053.6	0.9	6.20	1	1	1
07/27/2014 20:00	1.0	13.1	1,822.1	0.8	5.50	1	1	1
07/27/2014 21:00	1.0	13.3	1,678.7	0.8	5.00	1	1	1
07/27/2014 22:00	0.9	13.5	1,659.3	0.7	5.00	1	1	1
07/27/2014 23:00	0.9	13.1	1,840.2	0.7	5.50	1	1	1
Average/Sum#:	1.0	13.0	1,762.1	0.8	118.90 #	24 #	24 #	18 #
Minimum:	0.7	11.8	1,272.9	0.6	2.50	1	1	0
Maximum:	1.4	13.9	2,101.3	0.9	6.30	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/28/2014 00:00	1.0	13.2	1,844.6	0.8	5.50	1	1	1
07/28/2014 01:00	1.1	12.9	1,902.1	0.8	5.70	1	1	1
07/28/2014 02:00	1.0	13.2	1,743.2	0.8	5.20	1	1	1
07/28/2014 03:00	0.7	13.8	1,279.2	0.6	2.60	1	1	0
07/28/2014 04:00	0.9	13.5	1,614.6	0.7	4.80	1	1	1
07/28/2014 05:00	1.0	13.3	1,837.7	0.8	5.50	1	1	1
07/28/2014 06:00	0.9	13.2	1,861.0	0.7	5.60	1	1	1
07/28/2014 07:00	0.9	13.2	1,848.2	0.7	5.50	1	1	1
07/28/2014 08:00	0.9	13.1	1,875.2	0.7	5.60	1	1	1
07/28/2014 09:00	1.2	12.2	2,049.7	0.8	6.10	1	1	1
07/28/2014 10:00	1.2	12.1	2,066.8	0.8	6.20	1	1	1
07/28/2014 11:00	1.4	11.6	2,153.9	0.9	6.50	1	1	1
07/28/2014 12:00	1.2	11.8	2,089.9	0.8	6.30	1	1	1
07/28/2014 13:00	1.1	11.7	2,108.6	0.7	6.30	1	1	1
07/28/2014 14:00	1.2	11.8	2,079.2	0.8	6.20	1	1	1
07/28/2014 15:00	1.2	11.8	2,077.9	0.8	6.20	1	1	1
07/28/2014 16:00	1.1	11.8	2,066.0	0.7	6.20	1	1	1
07/28/2014 17:00	1.2	11.9	2,071.1	0.8	6.20	1	1	1
07/28/2014 18:00	1.0	12.6	1,938.0	0.7	5.80	1	1	1
07/28/2014 19:00	1.0	12.5	1,960.9	0.7	5.90	1	1	1
07/28/2014 20:00	1.0	12.6	1,931.0	0.7	5.80	1	1	1
07/28/2014 21:00	1.0	13.0	1,878.5	0.7	5.60	1	1	1
07/28/2014 22:00	0.9	12.8	1,911.1	0.7	3.80	1	1	1
07/28/2014 23:00	0.9	13.2	1,834.3	0.7	5.50	1	1	1
Average/Sum#:	1.0	12.6	1,917.6	0.7	134.60 #	24 #	24 #	23 #
Minimum:	0.7	11.6	1,279.2	0.6	2.60	1	1	0
Maximum:	1.4	13.8	2,153.9	0.9	6.50	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/29/2014 00:00	0.9	12.8	1,923.0	0.7	3.80	1	1	1
07/29/2014 01:00	0.7	13.8	1,447.1	0.6	2.90	1	1	1
07/29/2014 02:00	0.6	13.9	1,253.0	0.5	2.50	1	1	0
07/29/2014 03:00	0.6	13.9	1,229.9	0.5	2.50	1	1	0
07/29/2014 04:00	0.7	13.8	1,368.4	0.6	2.70	1	1	1
07/29/2014 05:00	0.9	13.4	1,832.2	0.7	5.50	1	1	1
07/29/2014 06:00	1.0	13.0	1,916.5	0.7	5.70	1	1	1
07/29/2014 07:00	1.1	12.2	2,073.6	0.7	6.20	1	1	1
07/29/2014 08:00	1.1	12.4	2,027.1	0.8	6.10	1	1	1
07/29/2014 09:00	1.0	12.6	1,966.1	0.7	5.90	1	1	1
07/29/2014 10:00	1.3	11.8	2,147.5	0.8	6.40	1	1	1
07/29/2014 11:00	1.1	12.4	1,999.2	0.8	6.00	1	1	1
07/29/2014 12:00	1.2	11.9	2,115.6	0.8	6.30	1	1	1
07/29/2014 13:00	1.5	11.4	2,199.2	0.9	6.60	1	1	1
07/29/2014 14:00	1.5	11.4	2,185.5	0.9	6.60	1	1	1
07/29/2014 15:00	1.4	11.5	2,144.5	0.9	6.40	1	1	1
07/29/2014 16:00	1.2	11.9	2,034.2	0.8	6.10	1	1	1
07/29/2014 17:00	1.0	12.3	1,979.9	0.7	5.90	1	1	1
07/29/2014 18:00	1.0	12.3	1,976.1	0.7	5.90	1	1	1
07/29/2014 19:00	1.0	12.7	1,898.4	0.7	5.70	1	1	1
07/29/2014 20:00	1.0	13.1	1,840.4	0.8	5.50	1	1	1
07/29/2014 21:00	1.0	12.9	1,890.3	0.7	5.70	1	1	1
07/29/2014 22:00	1.0	13.1	1,837.2	0.8	5.50	1	1	1
07/29/2014 23:00	0.9	13.2	1,825.7	0.7	5.50	1	1	1
Average/Sum#:	1.0	12.7	1,879.6	0.7	127.90 #	24 #	24 #	22 #
Minimum:	0.6	11.4	1,229.9	0.5	2.50	1	1	0
Maximum:	1.5	13.9	2,199.2	0.9	6.60	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/30/2014 00:00	1.0	13.3	1,817.0	0.8	5.50	1	1	1
07/30/2014 01:00	1.0	13.1	1,856.2	0.8	5.60	1	1	1
07/30/2014 02:00	0.7	13.8	1,404.4	0.6	2.80	1	1	1
07/30/2014 03:00	0.8	13.6	1,533.3	0.6	3.10	1	1	1
07/30/2014 04:00	0.9	13.3	1,840.3	0.7	5.50	1	1	1
07/30/2014 05:00	0.9	13.3	1,845.1	0.7	5.50	1	1	1
07/30/2014 06:00	0.9	13.2	1,842.9	0.7	5.50	1	1	1
07/30/2014 07:00	0.8	13.2	1,841.3	0.6	3.70	1	1	1
07/30/2014 08:00	0.8	13.2	1,842.6	0.6	3.70	1	1	1
07/30/2014 09:00	0.9	13.1	1,849.8	0.7	5.50	1	1	1
07/30/2014 10:00	0.9	13.1	1,848.0	0.7	5.50	1	1	1
07/30/2014 11:00	1.1	12.5	1,982.2	0.8	5.90	1	1	1
07/30/2014 12:00	1.5	11.4	2,182.4	0.9	6.50	1	1	1
07/30/2014 13:00	1.6	11.3	2,197.8	1.0	8.80	1	1	1
07/30/2014 14:00	1.4	11.3	2,166.6	0.9	6.50	1	1	1
07/30/2014 15:00	1.3	11.4	2,138.9	0.8	6.40	1	1	1
07/30/2014 16:00	1.4	11.4	2,138.6	0.9	6.40	1	1	1
07/30/2014 17:00	1.3	11.4	2,139.9	0.8	6.40	1	1	1
07/30/2014 18:00	1.3	11.5	2,139.0	0.8	6.40	1	1	1
07/30/2014 19:00	1.2	11.7	2,094.0	0.8	6.30	1	1	1
07/30/2014 20:00	1.1	12.3	1,989.1	0.8	6.00	1	1	1
07/30/2014 21:00	1.3	11.6	2,127.5	0.8	6.40	1	1	1
07/30/2014 22:00	1.3	11.9	2,077.9	0.9	6.20	1	1	1
07/30/2014 23:00	1.2	12.2	2,028.8	0.8	6.10	1	1	1
Average/Sum#:	1.1	12.4	1,955.2	0.8	136.20 #	24 #	24 #	24 #
Minimum:	0.7	11.3	1,404.4	0.6	2.80	1	1	1
Maximum:	1.6	13.8	2,197.8	1.0	8.80	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
07/31/2014 00:00	0.9	13.4	1,696.9	0.7	5.10	1	1	1
07/31/2014 01:00	0.9	13.7	1,710.9	0.7	5.10	1	1	0
07/31/2014 02:00	0.9	13.3	1,766.0	0.7	5.30	1	1	1
07/31/2014 03:00	1.0	13.0	1,877.3	0.7	5.60	1	1	1
07/31/2014 04:00	0.9	13.2	1,847.8	0.7	5.50	1	1	1
07/31/2014 05:00	0.9	13.2	1,843.4	0.7	5.50	1	1	1
07/31/2014 06:00	0.9	13.2	1,841.9	0.7	5.50	1	1	1
07/31/2014 07:00	0.9	13.2	1,844.5	0.7	5.50	1	1	1
07/31/2014 08:00	0.9	13.1	1,848.1	0.7	5.50	1	1	1
07/31/2014 09:00	1.0	12.7	1,924.6	0.7	5.80	1	1	1
07/31/2014 10:00	1.4	11.4	2,173.3	0.9	6.50	1	1	1
07/31/2014 11:00	1.6	11.2	2,198.8	1.0	8.80	1	1	1
07/31/2014 12:00	1.5	11.3	2,162.8	0.9	6.50	1	1	1
07/31/2014 13:00	0.8	13.4	1,709.8	0.6	3.40	1	1	1
07/31/2014 14:00	1.0	12.6	1,907.6	0.7	5.70	1	1	1
07/31/2014 15:00	1.1	12.2	1,983.5	0.7	6.00	1	1	1
07/31/2014 16:00	1.1	12.1	1,990.1	0.7	6.00	1	1	1
07/31/2014 17:00	1.1	12.0	1,996.9	0.7	6.00	1	1	1
07/31/2014 18:00	1.2	12.1	1,988.2	0.8	6.00	1	1	1
07/31/2014 19:00	1.1	12.2	1,975.8	0.7	5.90	1	1	1
07/31/2014 20:00	1.1	12.2	1,968.1	0.7	5.90	1	1	1
07/31/2014 21:00	1.1	12.4	1,954.5	0.8	5.90	1	1	1
07/31/2014 22:00	1.0	12.8	1,881.2	0.7	5.60	1	1	1
07/31/2014 23:00	1.0	12.8	1,880.0	0.7	5.60	1	1	1
Average/Sum#:	1.1	12.6	1,915.5	0.7	138.20 #	24 #	24 #	23 #
Minimum:	0.8	11.2	1,696.9	0.6	3.40	1	1	0
Maximum:	1.6	13.7	2,198.8	1.0	8.80	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/01/2014 00:00	1.0	12.9	1,882.6	0.7	5.60	1	1	1
08/01/2014 01:00	0.9	13.6	1,580.9	0.7	4.70	1	1	1
08/01/2014 02:00	0.9	13.6	1,595.6	0.7	4.80	1	1	1
08/01/2014 03:00	1.0	13.0	1,886.0	0.7	5.70	1	1	1
08/01/2014 04:00	1.0	13.2	1,855.3	0.8	5.60	1	1	1
08/01/2014 05:00	1.1	13.0	1,899.0	0.8	5.70	1	1	1
08/01/2014 06:00	1.0	13.3	1,839.5	0.8	5.50	1	1	1
08/01/2014 07:00	1.0	13.2	1,837.6	0.8	5.50	1	1	1
08/01/2014 08:00	1.1	12.9	1,897.0	0.8	5.70	1	1	1
08/01/2014 09:00	1.2	12.3	2,008.9	0.8	6.00	1	1	1
08/01/2014 10:00	1.5	11.6	2,117.8	1.0	8.50	1	1	1
08/01/2014 11:00	1.6	11.3	2,189.8	1.0	8.80	1	1	1
08/01/2014 12:00	1.5	11.4	2,152.1	0.9	6.50	1	1	1
08/01/2014 13:00	1.5	11.4	2,138.7	0.9	6.40	1	1	1
08/01/2014 14:00	1.5	11.4	2,132.4	0.9	6.40	1	1	1
08/01/2014 15:00	1.4	11.5	2,092.1	0.9	6.30	1	1	1
08/01/2014 16:00	1.4	11.9	2,032.0	0.9	6.10	1	1	1
08/01/2014 17:00	1.3	12.1	1,997.9	0.9	6.00	1	1	1
08/01/2014 18:00	1.3	12.2	1,991.2	0.9	6.00	1	1	1
08/01/2014 19:00	1.4	12.3	1,990.8	1.0	8.00	1	1	1
08/01/2014 20:00	1.3	12.7	1,929.1	0.9	5.80	1	1	1
08/01/2014 21:00	1.3	12.9	1,900.9	1.0	7.60	1	1	1
08/01/2014 22:00	1.3	12.9	1,888.8	1.0	7.60	1	1	1
08/01/2014 23:00	1.3	12.7	1,926.6	0.9	5.80	1	1	1
Average/Sum#:	1.2	12.5	1,948.4	0.9	150.60 #	24 #	24 #	24 #
Minimum:	0.9	11.3	1,580.9	0.7	4.70	1	1	1
Maximum:	1.6	13.6	2,189.8	1.0	8.80	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/02/2014 00:00	1.2	13.0	1,872.6	0.9	5.60	1	1	1
08/02/2014 01:00	1.2	13.2	1,847.7	0.9	5.50	1	1	1
08/02/2014 02:00	1.1	13.2	1,825.1	0.8	5.50	1	1	1
08/02/2014 03:00	0.8	13.9	1,304.0	0.7	2.60	1	1	0
08/02/2014 04:00	1.0	13.8	1,477.1	0.8	4.40	1	1	0
08/02/2014 05:00	0.6	13.9	1,262.5	0.5	2.50	1	1	0
08/02/2014 06:00	0.6	13.8	1,238.2	0.5	2.50	1	1	0
08/02/2014 07:00	0.8	13.6	1,515.0	0.6	3.00	1	1	1
08/02/2014 08:00	1.2	13.2	1,849.6	0.9	5.50	1	1	1
08/02/2014 09:00	1.2	13.3	1,821.1	0.9	5.50	1	1	1
08/02/2014 10:00	1.3	13.2	1,832.7	1.0	7.30	1	1	1
08/02/2014 11:00	1.3	13.0	1,877.3	1.0	7.50	1	1	1
08/02/2014 12:00	1.2	12.8	1,918.0	0.9	5.80	1	1	1
08/02/2014 13:00	1.3	12.7	1,915.7	0.9	5.70	1	1	1
08/02/2014 14:00	1.2	12.9	1,858.2	0.9	5.60	1	1	1
08/02/2014 15:00	1.2	12.8	1,875.9	0.9	5.60	1	1	1
08/02/2014 16:00	1.2	12.7	1,887.9	0.9	5.70	1	1	1
08/02/2014 17:00	1.2	12.5	1,917.1	0.8	5.80	1	1	1
08/02/2014 18:00	1.2	12.6	1,906.0	0.9	5.70	1	1	1
08/02/2014 19:00	1.2	12.3	1,980.7	0.8	5.90	1	1	1
08/02/2014 20:00	1.3	12.3	1,977.1	0.9	5.90	1	1	1
08/02/2014 21:00	1.1	12.7	1,896.7	0.8	5.70	1	1	1
08/02/2014 22:00	1.0	13.6	1,535.9	0.8	4.60	1	1	1
08/02/2014 23:00	0.6	13.9	1,276.1	0.5	2.60	1	1	0
Average/Sum#:	1.1	13.1	1,736.2	0.8	122.00 #	24 #	24 #	19 #
Minimum:	0.6	12.3	1,238.2	0.5	2.50	1	1	0
Maximum:	1.3	13.9	1,980.7	1.0	7.50	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/03/2014 00:00	1.0	13.8	1,594.3	0.8	4.80	1	1	0
08/03/2014 01:00	1.0	13.8	1,487.0	0.8	4.50	1	1	0
08/03/2014 02:00	0.8	13.8	1,410.3	0.7	2.80	1	1	0
08/03/2014 03:00	1.0	13.8	1,601.4	0.8	4.80	1	1	0
08/03/2014 04:00	1.0	13.7	1,750.3	0.8	5.30	1	1	1
08/03/2014 05:00	1.0	13.4	1,821.6	0.8	5.50	1	1	1
08/03/2014 06:00	1.1	13.3	1,826.7	0.9	5.50	1	1	1
08/03/2014 07:00	1.2	12.8	1,939.5	0.9	5.80	1	1	1
08/03/2014 08:00	1.2	13.0	1,894.5	0.9	5.70	1	1	1
08/03/2014 09:00	1.1	13.0	1,883.2	0.8	5.60	1	1	1
08/03/2014 10:00	1.2	12.9	1,895.8	0.9	5.70	1	1	1
08/03/2014 11:00	1.2	12.8	1,903.6	0.9	5.70	1	1	1
08/03/2014 12:00	1.2	12.8	1,900.0	0.9	5.70	1	1	1
08/03/2014 13:00	1.4	11.9	2,068.1	0.9	6.20	1	1	1
08/03/2014 14:00	1.3	12.3	1,978.0	0.9	5.90	1	1	1
08/03/2014 15:00	1.5	11.7	2,102.8	1.0	8.40	1	1	1
08/03/2014 16:00	1.3	12.4	1,953.9	0.9	5.90	1	1	1
08/03/2014 17:00	1.3	12.5	1,941.1	0.9	5.80	1	1	1
08/03/2014 18:00	1.2	12.9	1,872.3	0.9	5.60	1	1	1
08/03/2014 19:00	1.3	12.6	1,945.1	0.9	5.80	1	1	1
08/03/2014 20:00	1.4	12.6	1,952.5	1.0	7.80	1	1	1
08/03/2014 21:00	1.3	13.0	1,864.0	1.0	7.50	1	1	1
08/03/2014 22:00	1.3	13.0	1,857.4	1.0	7.40	1	1	1
08/03/2014 23:00	1.4	12.8	1,935.0	1.0	7.70	1	1	1
Average/Sum#:	1.2	12.9	1,849.1	0.9	141.40 #	24 #	24 #	20 #
Minimum:	0.8	11.7	1,410.3	0.7	2.80	1	1	0
Maximum:	1.5	13.8	2,102.8	1.0	8.40	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/04/2014 00:00	1.3	13.1	1,876.1	1.0	7.50	1	1	1
08/04/2014 01:00	1.3	13.0	1,902.5	1.0	7.60	1	1	1
08/04/2014 02:00	1.3	13.2	1,866.0	1.0	7.50	1	1	1
08/04/2014 03:00	1.3	12.9	1,917.3	1.0	7.70	1	1	1
08/04/2014 04:00	1.3	13.3	1,842.2	1.0	7.40	1	1	1
08/04/2014 05:00	1.3	13.2	1,823.2	1.0	7.30	1	1	1
08/04/2014 06:00	1.2	13.7	1,705.6	1.0	6.80	1	1	0
08/04/2014 07:00	1.2	13.7	1,676.5	1.0	6.70	1	1	0
08/04/2014 08:00	1.3	13.6	1,758.9	1.1	7.00	1	1	0
08/04/2014 09:00	1.2	13.6	1,756.8	1.0	7.00	1	1	0
08/04/2014 10:00	1.3	13.2	1,801.5	1.0	7.20	1	1	1
08/04/2014 11:00	1.3	12.9	1,902.7	1.0	7.60	1	1	1
08/04/2014 12:00	1.3	13.2	1,837.9	1.0	7.40	1	1	1
08/04/2014 13:00	1.2	13.1	1,842.0	0.9	5.50	1	1	1
08/04/2014 14:00	1.2	13.1	1,846.3	0.9	5.50	1	1	1
08/04/2014 15:00	1.3	13.0	1,852.9	1.0	7.40	1	1	1
08/04/2014 16:00	1.3	13.1	1,839.8	1.0	7.40	1	1	1
08/04/2014 17:00	1.3	13.1	1,843.3	1.0	7.40	1	1	1
08/04/2014 18:00	1.3	13.1	1,839.7	1.0	7.40	1	1	1
08/04/2014 19:00	1.3	13.2	1,836.8	1.0	7.30	1	1	1
08/04/2014 20:00	1.3	13.2	1,836.6	1.0	7.30	1	1	1
08/04/2014 21:00	1.0	13.3	1,583.2	0.8	4.70	1	1	1
08/04/2014 22:00	0.5	13.8	1,280.5	0.4	2.60	1	1	0
08/04/2014 23:00	0.9	13.7	1,613.8	0.7	4.80	1	1	0
Average/Sum#:	1.2	13.3	1,786.8	1.0	162.00 #	24 #	24 #	18 #
Minimum:	0.5	12.9	1,280.5	0.4	2.60	1	1	0
Maximum:	1.3	13.8	1,917.3	1.1	7.70	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/05/2014 00:00	1.2	13.4	1,770.6	0.9	5.30	1	1	1
08/05/2014 01:00	1.3	12.9	1,895.1	1.0	7.60	1	1	1
08/05/2014 02:00	1.4	12.7	1,928.9	1.0	7.70	1	1	1
08/05/2014 03:00	1.3	12.9	1,905.5	1.0	7.60	1	1	1
08/05/2014 04:00	1.4	12.9	1,910.8	1.0	7.60	1	1	1
08/05/2014 05:00	1.3	13.2	1,840.4	1.0	7.40	1	1	1
08/05/2014 06:00	1.3	13.1	1,874.7	1.0	7.50	1	1	1
08/05/2014 07:00	0.6	13.8	1,295.7	0.5	2.60	1	1	1
08/05/2014 08:00	0.4	13.8	1,250.1	0.3	1.30	1	1	0
08/05/2014 09:00	0.7	13.3	1,571.2	0.5	3.10	1	1	1
08/05/2014 10:00	1.2	13.2	1,845.2	0.9	5.50	1	1	1
08/05/2014 11:00	1.2	13.2	1,853.8	0.9	5.60	1	1	1
08/05/2014 12:00	1.3	13.0	1,891.0	1.0	7.60	1	1	1
08/05/2014 13:00	1.4	12.8	1,920.8	1.0	7.70	1	1	1
08/05/2014 14:00	1.4	12.7	1,928.8	1.0	7.70	1	1	1
08/05/2014 15:00	1.4	12.6	1,965.0	1.0	7.90	1	1	1
08/05/2014 16:00	1.4	12.8	1,922.0	1.0	7.70	1	1	1
08/05/2014 17:00	1.2	12.7	1,930.2	0.9	5.80	1	1	1
08/05/2014 18:00	1.1	12.7	1,940.8	0.8	5.80	1	1	1
08/05/2014 19:00	1.1	12.6	1,953.7	0.8	5.90	1	1	1
08/05/2014 20:00	1.0	12.9	1,894.6	0.7	5.70	1	1	1
08/05/2014 21:00	1.0	12.8	1,905.6	0.7	5.70	1	1	1
08/05/2014 22:00	0.7	13.4	1,474.3	0.6	2.90	1	1	1
08/05/2014 23:00	0.7	13.5	1,529.9	0.6	3.10	1	1	1
Average/Sum#:	1.1	13.0	1,799.9	0.8	142.30 #	24 #	24 #	23 #
Minimum:	0.4	12.6	1,250.1	0.3	1.30	1	1	0
Maximum:	1.4	13.8	1,965.0	1.0	7.90	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/06/2014 00:00	1.0	12.7	1,939.1	0.7	5.80	1	1	1
08/06/2014 01:00	1.0	12.6	1,957.6	0.7	5.90	1	1	1
08/06/2014 02:00	1.0	12.9	1,897.7	0.7	5.70	1	1	1
08/06/2014 03:00	0.8	13.2	1,847.4	0.6	3.70	1	1	1
08/06/2014 04:00	1.1	12.6	1,966.1	0.8	5.90	1	1	1
08/06/2014 05:00	1.2	12.4	2,002.7	0.8	6.00	1	1	1
08/06/2014 06:00	1.1	12.7	1,933.5	0.8	5.80	1	1	1
08/06/2014 07:00	1.1	12.9	1,909.7	0.8	5.70	1	1	1
08/06/2014 08:00	1.2	12.6	1,955.9	0.9	5.90	1	1	1
08/06/2014 09:00	1.1	12.3	2,003.0	0.8	6.00	1	1	1
08/06/2014 10:00	1.1	12.1	2,016.5	0.7	6.00	1	1	1
08/06/2014 11:00	1.2	12.1	2,033.1	0.8	6.10	1	1	1
08/06/2014 12:00	1.2	12.3	1,999.7	0.8	6.00	1	1	1
08/06/2014 13:00	1.2	12.3	1,990.4	0.8	6.00	1	1	1
08/06/2014 14:00	1.3	12.0	2,050.3	0.9	6.20	1	1	1
08/06/2014 15:00	1.2	12.3	1,977.6	0.8	5.90	1	1	1
08/06/2014 16:00	1.0	12.9	1,857.3	0.7	5.60	1	1	1
08/06/2014 17:00	1.1	12.5	1,934.1	0.8	5.80	1	1	1
08/06/2014 18:00	1.1	12.4	1,947.8	0.8	5.80	1	1	1
08/06/2014 19:00	1.2	12.3	1,987.3	0.8	6.00	1	1	1
08/06/2014 20:00	1.2	12.3	1,982.5	0.8	5.90	1	1	1
08/06/2014 21:00	1.1	12.6	1,908.0	0.8	5.70	1	1	1
08/06/2014 22:00	0.8	13.4	1,449.7	0.6	2.90	1	1	1
08/06/2014 23:00	3.7	16.4	352.1	4.9	1.07	1	0	0
Average/Sum#:	1.2	12.7	1,870.8	0.9	131.37 #	24 #	23 #	23 #
Minimum:	0.8	12.0	352.1	0.6	1.07	1	0	0
Maximum:	3.7	16.4	2,050.3	4.9	6.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/07/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/07/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/07/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/07/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/07/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/07/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/07/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/07/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/07/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/07/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/07/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/07/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/07/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/07/2014 13:00	17.6	17.8	356.8	33.5	20.63	1	0	0
08/07/2014 14:00	19.1	16.4	617.1	25.0	49.98	1	0	0
08/07/2014 15:00	2.5	13.1	1,686.6	1.9	11.80	1	0	1
08/07/2014 16:00	1.0	12.1	1,982.6	0.7	4.00	1	1	1
08/07/2014 17:00	1.2	11.7	2,066.4	0.8	6.20	1	1	1
08/07/2014 18:00	1.1	11.8	1,997.5	0.7	6.00	1	1	1
08/07/2014 19:00	1.0	12.3	1,951.6	0.7	5.90	1	1	1
08/07/2014 20:00	1.0	13.0	1,838.9	0.7	5.50	1	1	1
08/07/2014 21:00	0.9	12.9	1,864.6	0.7	3.70	1	1	1
08/07/2014 22:00	0.9	13.2	1,813.9	0.7	5.40	1	1	1
08/07/2014 23:00	1.0	13.3	1,807.8	0.8	5.40	1	1	1
Average/Sum#:	4.3	13.4	1,634.9	6.0	124.51 #	11 #	8 #	9 #
Minimum:	0.9	11.7	356.8	0.7	3.70	0	0	0
Maximum:	19.1	17.8	2,066.4	33.5	49.98	1	1	1
%SI	54.2	54.2	54.2	54.2	54.17	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/08/2014 00:00	1.0	12.8	1,908.2	0.7	5.70	1	1	1
08/08/2014 01:00	1.0	12.9	1,893.2	0.7	5.70	1	1	1
08/08/2014 02:00	0.9	13.3	1,816.6	0.7	5.40	1	1	1
08/08/2014 03:00	0.9	13.1	1,865.7	0.7	5.60	1	1	1
08/08/2014 04:00	0.9	13.0	1,898.1	0.7	3.80	1	1	1
08/08/2014 05:00	1.0	12.7	1,945.7	0.7	5.80	1	1	1
08/08/2014 06:00	1.0	12.7	1,946.5	0.7	5.80	1	1	1
08/08/2014 07:00	0.9	12.9	1,910.0	0.7	3.80	1	1	1
08/08/2014 08:00	0.9	13.0	1,875.9	0.7	3.80	1	1	1
08/08/2014 09:00	1.3	11.7	2,132.5	0.8	6.40	1	1	1
08/08/2014 10:00	1.2	12.1	2,030.3	0.8	6.10	1	1	1
08/08/2014 11:00	0.9	13.0	1,842.8	0.7	3.70	1	1	1
08/08/2014 12:00	1.0	12.9	1,878.4	0.7	5.60	1	1	1
08/08/2014 13:00	1.1	12.3	1,990.7	0.8	6.00	1	1	1
08/08/2014 14:00	1.3	11.7	2,106.2	0.8	6.30	1	1	1
08/08/2014 15:00	1.3	11.6	2,100.8	0.8	6.30	1	1	1
08/08/2014 16:00	1.3	11.6	2,083.1	0.8	6.20	1	1	1
08/08/2014 17:00	1.1	12.1	2,011.2	0.7	6.00	1	1	1
08/08/2014 18:00	1.4	11.5	2,135.6	0.9	6.40	1	1	1
08/08/2014 19:00	1.2	11.8	2,058.0	0.8	6.20	1	1	1
08/08/2014 20:00	1.1	12.4	1,971.0	0.8	5.90	1	1	1
08/08/2014 21:00	1.1	12.4	1,955.4	0.8	5.90	1	1	1
08/08/2014 22:00	1.0	12.9	1,872.9	0.7	5.60	1	1	1
08/08/2014 23:00	1.0	12.5	1,948.2	0.7	5.80	1	1	1
Average/Sum#:	1.1	12.5	1,965.7	0.7	133.80 #	24 #	24 #	24 #
Minimum:	0.9	11.5	1,816.6	0.7	3.70	1	1	1
Maximum:	1.4	13.3	2,135.6	0.9	6.40	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/09/2014 00:00	0.9	13.6	1,698.3	0.7	5.10	1	1	1
08/09/2014 01:00	0.8	13.7	1,544.6	0.7	3.10	1	1	0
08/09/2014 02:00	2.4	15.7	571.0	2.7	1.25	1	0	0
08/09/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/09/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/09/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/09/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/09/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/09/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/09/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/09/2014 10:00	18.2	16.7	556.0	25.6	35.56	1	0	0
08/09/2014 11:00	6.1	14.0	1,405.4	5.2	26.70	1	0	0
08/09/2014 12:00	0.7	13.7	1,467.0	0.6	2.90	1	1	1
08/09/2014 13:00	1.0	13.0	1,843.8	0.7	5.50	1	1	1
08/09/2014 14:00	1.0	13.0	1,867.8	0.7	5.60	1	1	1
08/09/2014 15:00	1.1	12.6	1,915.0	0.8	5.70	1	1	1
08/09/2014 16:00	1.0	12.7	1,901.3	0.7	5.70	1	1	1
08/09/2014 17:00	1.0	12.8	1,899.9	0.7	5.70	1	1	1
08/09/2014 18:00	1.1	12.2	2,014.3	0.7	6.00	1	1	1
08/09/2014 19:00	1.4	11.4	2,172.3	0.9	6.50	1	1	1
08/09/2014 20:00	1.3	11.8	2,098.2	0.8	6.30	1	1	1
08/09/2014 21:00	1.3	12.0	2,071.3	0.9	6.20	1	1	1
08/09/2014 22:00	1.0	12.5	1,982.5	0.7	5.90	1	1	1
08/09/2014 23:00	1.0	13.4	1,683.2	0.8	5.00	1	1	1
Average/Sum#:	2.4	13.2	1,687.8	2.6	138.71 #	17 #	14 #	13 #
Minimum:	0.7	11.4	556.0	0.6	1.25	0	0	0
Maximum:	18.2	16.7	2,172.3	25.6	35.56	1	1	1
%SI	29.2	29.2	29.2	29.2	29.17	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/10/2014 00:00	3.5	15.7	567.0	4.0	1.87	1	0	0
08/10/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2014 11:00	20.6	17.0	530.2	31.2	43.92	1	0	0
08/10/2014 12:00	8.1	13.9	1,435.1	6.8	35.90	1	0	1
08/10/2014 13:00	1.0	12.7	1,914.3	0.7	5.70	1	1	1
08/10/2014 14:00	1.0	12.6	1,912.1	0.7	5.70	1	1	1
08/10/2014 15:00	1.0	12.9	1,875.4	0.7	5.60	1	1	1
08/10/2014 16:00	1.1	12.4	1,974.4	0.8	5.90	1	1	1
08/10/2014 17:00	1.4	11.4	2,151.8	0.9	6.50	1	1	1
08/10/2014 18:00	1.5	11.6	2,138.3	1.0	8.60	1	1	1
08/10/2014 19:00	1.4	11.5	2,142.8	0.9	6.40	1	1	1
08/10/2014 20:00	1.4	11.7	2,123.3	0.9	6.40	1	1	1
08/10/2014 21:00	1.3	11.9	2,069.6	0.9	6.20	1	1	1
08/10/2014 22:00	1.0	12.8	1,901.0	0.7	5.70	1	1	1
08/10/2014 23:00	1.1	12.6	1,952.3	0.8	5.90	1	1	1
Average/Sum#:	3.2	12.9	1,763.4	3.6	150.29 #	14 #	11 #	12 #
Minimum:	1.0	11.4	530.2	0.7	1.87	0	0	0
Maximum:	20.6	17.0	2,151.8	31.2	43.92	1	1	1
%SI	41.7	41.7	41.7	41.7	41.67	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/11/2014 00:00	1.0	12.7	1,948.6	0.7	5.80	1	1	1
08/11/2014 01:00	1.1	12.7	1,949.9	0.8	5.80	1	1	1
08/11/2014 02:00	1.1	12.9	1,911.4	0.8	5.70	1	1	1
08/11/2014 03:00	1.1	12.7	1,955.1	0.8	5.90	1	1	1
08/11/2014 04:00	1.1	12.7	1,970.2	0.8	5.90	1	1	1
08/11/2014 05:00	1.1	12.9	1,923.2	0.8	5.80	1	1	1
08/11/2014 06:00	1.4	11.7	2,137.4	0.9	6.40	1	1	1
08/11/2014 07:00	1.1	12.6	1,979.0	0.8	5.90	1	1	1
08/11/2014 08:00	1.1	12.6	1,964.2	0.8	5.90	1	1	1
08/11/2014 09:00	1.5	11.4	2,182.3	0.9	6.50	1	1	1
08/11/2014 10:00	1.6	11.2	2,222.1	1.0	8.90	1	1	1
08/11/2014 11:00	1.6	11.1	2,231.4	1.0	8.90	1	1	1
08/11/2014 12:00	1.7	11.1	2,221.3	1.0	8.90	1	1	1
08/11/2014 13:00	1.6	11.3	2,196.8	1.0	8.80	1	1	1
08/11/2014 14:00	1.4	11.3	2,167.6	0.9	6.50	1	1	1
08/11/2014 15:00	1.6	11.3	2,155.3	1.0	8.60	1	1	1
08/11/2014 16:00	1.7	11.3	2,162.5	1.0	8.70	1	1	1
08/11/2014 17:00	1.6	11.2	2,176.5	1.0	8.70	1	1	1
08/11/2014 18:00	1.6	11.3	2,170.9	1.0	8.70	1	1	1
08/11/2014 19:00	1.7	11.2	2,201.0	1.0	8.80	1	1	1
08/11/2014 20:00	1.5	11.4	2,168.7	0.9	6.50	1	1	1
08/11/2014 21:00	1.2	12.6	1,916.0	0.9	5.70	1	1	1
08/11/2014 22:00	1.0	13.8	1,694.3	0.8	5.10	1	1	0
08/11/2014 23:00	1.0	13.7	1,681.0	0.8	5.00	1	1	0
Average/Sum#:	1.4	12.0	2,053.6	0.9	167.40 #	24 #	24 #	22 #
Minimum:	1.0	11.1	1,681.0	0.7	5.00	1	1	0
Maximum:	1.7	13.8	2,231.4	1.0	8.90	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/12/2014 00:00	0.9	13.8	1,638.6	0.7	4.90	1	1	0
08/12/2014 01:00	0.9	13.8	1,665.7	0.7	5.00	1	1	0
08/12/2014 02:00	0.9	13.8	1,537.8	0.7	4.60	1	1	0
08/12/2014 03:00	0.9	13.8	1,529.6	0.7	4.60	1	1	0
08/12/2014 04:00	0.9	13.8	1,692.4	0.7	5.10	1	1	0
08/12/2014 05:00	0.8	13.7	1,762.6	0.7	3.50	1	1	0
08/12/2014 06:00	0.8	13.7	1,763.6	0.7	3.50	1	1	0
08/12/2014 07:00	0.9	13.7	1,727.9	0.7	5.20	1	1	0
08/12/2014 08:00	0.7	13.8	1,307.3	0.6	2.60	1	1	0
08/12/2014 09:00	0.9	13.8	1,633.8	0.7	4.90	1	1	0
08/12/2014 10:00	0.9	13.6	1,747.8	0.7	5.20	1	1	0
08/12/2014 11:00	0.9	13.8	1,648.9	0.7	4.90	1	1	0
08/12/2014 12:00	0.9	13.7	1,747.5	0.7	5.20	1	1	0
08/12/2014 13:00	0.9	13.7	1,744.8	0.7	5.20	1	1	0
08/12/2014 14:00	0.8	13.7	1,738.7	0.7	3.50	1	1	0
08/12/2014 15:00	0.9	13.7	1,733.5	0.7	5.20	1	1	0
08/12/2014 16:00	0.9	13.7	1,736.9	0.7	5.20	1	1	0
08/12/2014 17:00	0.9	13.7	1,743.3	0.7	5.20	1	1	0
08/12/2014 18:00	0.9	13.7	1,748.3	0.7	5.20	1	1	0
08/12/2014 19:00	0.9	13.7	1,758.2	0.7	5.30	1	1	0
08/12/2014 20:00	0.9	13.6	1,767.2	0.7	5.30	1	1	0
08/12/2014 21:00	0.9	13.6	1,771.8	0.7	5.30	1	1	0
08/12/2014 22:00	0.9	13.6	1,777.3	0.7	5.30	1	1	0
08/12/2014 23:00	0.9	13.6	1,779.5	0.7	5.30	1	1	0
Average/Sum#:	0.9	13.7	1,696.0	0.7	115.20 #	24 #	24 #	0 #
Minimum:	0.7	13.6	1,307.3	0.6	2.60	1	1	0
Maximum:	0.9	13.8	1,779.5	0.7	5.30	1	1	0
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/13/2014 00:00	0.9	13.6	1,772.6	0.7	5.30	1	1	0
08/13/2014 01:00	1.6	14.2	1,386.5	1.4	4.69	1	0	0
08/13/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2014 08:00	16.5	17.3	482.5	27.0	28.01	1	0	0
08/13/2014 09:00	5.8	14.9	1,149.6	5.7	24.10	1	0	0
08/13/2014 10:00	0.8	13.6	1,763.0	0.6	3.50	1	1	0
08/13/2014 11:00	0.9	13.6	1,756.0	0.7	5.30	1	1	0
08/13/2014 12:00	0.9	13.6	1,759.7	0.7	5.30	1	1	0
08/13/2014 13:00	0.9	13.6	1,754.9	0.7	5.30	1	1	0
08/13/2014 14:00	0.9	13.6	1,744.0	0.7	5.20	1	1	0
08/13/2014 15:00	0.9	13.7	1,728.3	0.7	5.20	1	1	0
08/13/2014 16:00	0.9	13.7	1,725.7	0.7	5.20	1	1	0
08/13/2014 17:00	0.9	13.7	1,726.2	0.7	5.20	1	1	0
08/13/2014 18:00	0.9	13.6	1,728.7	0.7	5.20	1	1	0
08/13/2014 19:00	0.9	13.6	1,735.5	0.7	5.20	1	1	0
08/13/2014 20:00	0.9	13.6	1,746.5	0.7	5.20	1	1	0
08/13/2014 21:00	0.8	13.7	1,731.8	0.7	3.50	1	1	0
08/13/2014 22:00	0.7	13.8	1,649.9	0.6	3.30	1	1	0
08/13/2014 23:00	1.5	14.9	929.1	1.5	1.93	1	0	0
Average/Sum#:	2.1	14.0	1,570.6	2.5	126.63 #	18 #	14 #	0 #
Minimum:	0.7	13.6	482.5	0.6	1.93	0	0	0
Maximum:	16.5	17.3	1,772.6	27.0	28.01	1	1	0
%SI	25.0	25.0	25.0	25.0	25.00	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/14/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/15/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/16/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/17/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/18/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/19/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/20/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/21/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/22/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/23/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/24/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/25/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/26/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/27/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/28/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/29/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/30/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
08/31/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/01/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/02/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/03/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/04/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/05/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/05/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/05/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/05/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/05/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/05/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/05/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/05/2014 07:00	37.4	17.0	487.1	56.6	72.94	1	0	0
09/05/2014 08:00	20.9	15.2	906.7	21.6	72.50	1	0	0
09/05/2014 09:00	0.7	13.9	1,417.4	0.6	2.80	1	1	0
09/05/2014 10:00	0.7	13.9	1,263.2	0.6	2.50	1	1	0
09/05/2014 11:00	0.8	14.0	1,365.2	0.7	4.10	1	1	0
09/05/2014 12:00	1.0	13.4	1,677.1	0.8	5.00	1	1	1
09/05/2014 13:00	1.2	12.9	1,905.1	0.9	5.70	1	1	1
09/05/2014 14:00	1.1	12.9	1,886.0	0.8	5.70	1	1	1
09/05/2014 15:00	1.2	12.7	1,920.6	0.9	5.80	1	1	1
09/05/2014 16:00	1.2	12.7	1,926.4	0.9	5.80	1	1	1
09/05/2014 17:00	1.5	11.7	2,132.5	1.0	8.50	1	1	1
09/05/2014 18:00	1.4	12.2	2,016.0	0.9	6.00	1	1	1
09/05/2014 19:00	1.2	12.7	1,935.2	0.9	5.80	1	1	1
09/05/2014 20:00	1.0	13.2	1,837.3	0.8	5.50	1	1	1
09/05/2014 21:00	1.2	12.9	1,903.2	0.9	5.70	1	1	1
09/05/2014 22:00	1.1	12.9	1,916.4	0.8	5.70	1	1	1
09/05/2014 23:00	1.5	11.8	2,151.4	1.0	8.60	1	1	1
Average/Sum#:	4.4	13.3	1,685.1	5.3	228.64 #	17 #	15 #	12 #
Minimum:	0.7	11.7	487.1	0.6	2.50	0	0	0
Maximum:	37.4	17.0	2,151.4	56.6	72.94	1	1	1
%SI	29.2	29.2	29.2	29.2	29.17	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/06/2014 00:00	1.3	12.3	2,027.8	0.9	6.10	1	1	1
09/06/2014 01:00	1.1	12.9	1,908.8	0.8	5.70	1	1	1
09/06/2014 02:00	1.1	12.8	1,955.9	0.8	5.90	1	1	1
09/06/2014 03:00	1.1	12.8	1,955.5	0.8	5.90	1	1	1
09/06/2014 04:00	1.1	12.8	1,946.2	0.8	5.80	1	1	1
09/06/2014 05:00	1.1	13.3	1,831.9	0.9	5.50	1	1	1
09/06/2014 06:00	1.0	13.3	1,843.2	0.8	5.50	1	1	1
09/06/2014 07:00	1.1	13.1	1,870.2	0.8	5.60	1	1	1
09/06/2014 08:00	1.0	13.4	1,835.7	0.8	5.50	1	1	1
09/06/2014 09:00	1.1	13.1	1,903.5	0.8	5.70	1	1	1
09/06/2014 10:00	1.0	13.1	1,882.2	0.8	5.60	1	1	1
09/06/2014 11:00	1.1	13.0	1,904.9	0.8	5.70	1	1	1
09/06/2014 12:00	1.2	12.3	2,017.3	0.8	6.10	1	1	1
09/06/2014 13:00	1.6	11.5	2,179.2	1.0	8.70	1	1	1
09/06/2014 14:00	1.3	12.2	2,030.4	0.9	6.10	1	1	1
09/06/2014 15:00	1.2	12.5	1,981.4	0.8	5.90	1	1	1
09/06/2014 16:00	1.2	12.6	1,960.5	0.9	5.90	1	1	1
09/06/2014 17:00	1.6	11.3	2,211.6	1.0	8.80	1	1	1
09/06/2014 18:00	1.5	11.7	2,135.1	1.0	8.50	1	1	1
09/06/2014 19:00	1.1	13.0	1,871.8	0.8	5.60	1	1	1
09/06/2014 20:00	1.0	13.3	1,837.4	0.8	5.50	1	1	1
09/06/2014 21:00	1.0	13.3	1,838.2	0.8	5.50	1	1	1
09/06/2014 22:00	1.1	13.1	1,874.9	0.8	5.60	1	1	1
09/06/2014 23:00	1.2	12.8	1,960.5	0.9	5.90	1	1	1
Average/Sum#:	1.2	12.7	1,948.5	0.8	146.60 #	24 #	24 #	24 #
Minimum:	1.0	11.3	1,831.9	0.8	5.50	1	1	1
Maximum:	1.6	13.4	2,211.6	1.0	8.80	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/07/2014 00:00	1.1	13.2	1,874.5	0.8	5.60	1	1	1
09/07/2014 01:00	1.2	13.2	1,880.4	0.9	5.60	1	1	1
09/07/2014 02:00	1.1	13.4	1,833.8	0.9	5.50	1	1	1
09/07/2014 03:00	1.1	13.4	1,830.6	0.9	5.50	1	1	1
09/07/2014 04:00	1.1	13.3	1,829.8	0.9	5.50	1	1	1
09/07/2014 05:00	1.1	13.3	1,831.2	0.9	5.50	1	1	1
09/07/2014 06:00	1.1	13.3	1,825.0	0.9	5.50	1	1	1
09/07/2014 07:00	1.1	13.3	1,836.8	0.9	5.50	1	1	1
09/07/2014 08:00	1.1	13.1	1,907.6	0.8	5.70	1	1	1
09/07/2014 09:00	1.2	12.5	2,008.8	0.8	6.00	1	1	1
09/07/2014 10:00	1.4	12.0	2,096.0	0.9	6.30	1	1	1
09/07/2014 11:00	1.4	12.0	2,082.5	0.9	6.20	1	1	1
09/07/2014 12:00	1.2	12.7	1,944.2	0.9	5.80	1	1	1
09/07/2014 13:00	1.2	12.8	1,927.5	0.9	5.80	1	1	1
09/07/2014 14:00	1.2	12.8	1,919.9	0.9	5.80	1	1	1
09/07/2014 15:00	1.2	12.7	1,933.6	0.9	5.80	1	1	1
09/07/2014 16:00	1.3	12.3	2,025.2	0.9	6.10	1	1	1
09/07/2014 17:00	1.6	11.4	2,182.8	1.0	8.70	1	1	1
09/07/2014 18:00	1.6	11.4	2,181.5	1.0	8.70	1	1	1
09/07/2014 19:00	1.6	11.5	2,179.3	1.0	8.70	1	1	1
09/07/2014 20:00	1.4	12.1	2,049.1	0.9	6.10	1	1	1
09/07/2014 21:00	1.1	13.0	1,873.8	0.8	5.60	1	1	1
09/07/2014 22:00	1.0	13.3	1,832.2	0.8	5.50	1	1	1
09/07/2014 23:00	1.1	13.1	1,897.2	0.8	5.70	1	1	1
Average/Sum#:	1.2	12.7	1,949.3	0.9	146.70 #	24 #	24 #	24 #
Minimum:	1.0	11.4	1,825.0	0.8	5.50	1	1	1
Maximum:	1.6	13.4	2,182.8	1.0	8.70	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/08/2014 00:00	0.9	13.6	1,499.4	0.7	4.50	1	1	1
09/08/2014 01:00	0.6	13.9	1,252.9	0.5	2.50	1	1	0
09/08/2014 02:00	0.6	13.9	1,247.5	0.5	2.50	1	1	0
09/08/2014 03:00	0.9	13.8	1,552.8	0.7	4.70	1	1	1
09/08/2014 04:00	1.0	13.0	1,914.5	0.7	5.70	1	1	1
09/08/2014 05:00	1.0	13.2	1,872.9	0.8	5.60	1	1	1
09/08/2014 06:00	1.3	12.3	2,095.5	0.9	6.30	1	1	1
09/08/2014 07:00	1.6	11.2	2,271.1	1.0	9.10	1	1	1
09/08/2014 08:00	1.4	12.0	2,113.0	0.9	6.30	1	1	1
09/08/2014 09:00	1.1	13.4	1,849.0	0.9	5.50	1	1	1
09/08/2014 10:00	1.0	13.4	1,837.1	0.8	5.50	1	1	1
09/08/2014 11:00	1.0	13.4	1,835.5	0.8	5.50	1	1	1
09/08/2014 12:00	1.1	13.3	1,836.3	0.9	5.50	1	1	1
09/08/2014 13:00	1.2	13.3	1,836.4	0.9	5.50	1	1	1
09/08/2014 14:00	1.1	13.3	1,838.3	0.9	5.50	1	1	1
09/08/2014 15:00	1.1	13.2	1,843.0	0.8	5.50	1	1	1
09/08/2014 16:00	1.0	13.4	1,598.3	0.8	4.80	1	1	1
09/08/2014 17:00	0.7	14.0	1,267.0	0.6	2.50	1	1	0
09/08/2014 18:00	0.8	14.0	1,513.3	0.7	4.50	1	1	0
09/08/2014 19:00	0.9	14.0	1,527.9	0.8	4.60	1	1	0
09/08/2014 20:00	0.8	13.9	1,439.8	0.7	2.90	1	1	0
09/08/2014 21:00	0.8	13.9	1,361.4	0.7	2.70	1	1	0
09/08/2014 22:00	0.7	13.9	1,295.7	0.6	2.60	1	1	0
09/08/2014 23:00	0.6	13.9	1,251.0	0.5	2.50	1	1	0
Average/Sum#:	1.0	13.4	1,664.6	0.8	112.80 #	24 #	24 #	15 #
Minimum:	0.6	11.2	1,247.5	0.5	2.50	1	1	0
Maximum:	1.6	14.0	2,271.1	1.0	9.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/09/2014 00:00	0.6	13.9	1,251.7	0.5	2.50	1	1	0
09/09/2014 01:00	0.6	13.9	1,251.6	0.5	2.50	1	1	0
09/09/2014 02:00	0.6	13.9	1,252.0	0.5	2.50	1	1	0
09/09/2014 03:00	0.7	13.9	1,353.2	0.6	2.70	1	1	0
09/09/2014 04:00	0.6	13.9	1,265.9	0.5	2.50	1	1	0
09/09/2014 05:00	0.6	13.9	1,304.7	0.5	2.60	1	1	0
09/09/2014 06:00	0.6	13.9	1,259.0	0.5	2.50	1	1	0
09/09/2014 07:00	0.6	13.9	1,266.0	0.5	2.50	1	1	0
09/09/2014 08:00	0.9	13.7	1,561.4	0.7	4.70	1	1	1
09/09/2014 09:00	1.0	13.3	1,862.9	0.8	5.60	1	1	1
09/09/2014 10:00	0.9	13.3	1,846.7	0.7	5.50	1	1	1
09/09/2014 11:00	1.0	13.2	1,841.0	0.8	5.50	1	1	1
09/09/2014 12:00	1.1	12.9	1,905.0	0.8	5.70	1	1	1
09/09/2014 13:00	1.2	12.7	1,909.4	0.9	5.70	1	1	1
09/09/2014 14:00	1.2	12.9	1,867.0	0.9	5.60	1	1	1
09/09/2014 15:00	1.2	13.0	1,846.3	0.9	5.50	1	1	1
09/09/2014 16:00	1.2	12.9	1,841.1	0.9	5.50	1	1	1
09/09/2014 17:00	1.2	12.9	1,854.0	0.9	5.60	1	1	1
09/09/2014 18:00	1.2	13.0	1,836.8	0.9	5.50	1	1	1
09/09/2014 19:00	1.2	13.0	1,835.2	0.9	5.50	1	1	1
09/09/2014 20:00	1.1	13.0	1,859.3	0.8	5.60	1	1	1
09/09/2014 21:00	1.2	12.8	1,890.8	0.9	5.70	1	1	1
09/09/2014 22:00	1.2	13.0	1,872.5	0.9	5.60	1	1	1
09/09/2014 23:00	1.3	12.5	1,975.6	0.9	5.90	1	1	1
Average/Sum#:	1.0	13.3	1,658.7	0.7	109.00 #	24 #	24 #	16 #
Minimum:	0.6	12.5	1,251.6	0.5	2.50	1	1	0
Maximum:	1.3	13.9	1,975.6	0.9	5.90	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/10/2014 00:00	1.3	12.5	1,978.6	0.9	5.90	1	1	1
09/10/2014 01:00	1.3	12.5	1,976.5	0.9	5.90	1	1	1
09/10/2014 02:00	1.1	13.0	1,874.7	0.8	5.60	1	1	1
09/10/2014 03:00	1.3	12.7	1,944.2	0.9	5.80	1	1	1
09/10/2014 04:00	1.4	12.4	1,996.4	1.0	8.00	1	1	1
09/10/2014 05:00	1.2	12.8	1,935.7	0.9	5.80	1	1	1
09/10/2014 06:00	1.1	13.3	1,831.2	0.9	5.50	1	1	1
09/10/2014 07:00	1.0	13.3	1,828.7	0.8	5.50	1	1	1
09/10/2014 08:00	1.0	13.3	1,828.2	0.8	5.50	1	1	1
09/10/2014 09:00	1.2	12.9	1,886.9	0.9	5.70	1	1	1
09/10/2014 10:00	1.0	13.6	1,537.8	0.8	4.60	1	1	1
09/10/2014 11:00	0.8	14.0	1,256.9	0.7	3.80	1	1	0
09/10/2014 12:00	1.0	13.4	1,709.3	0.8	5.10	1	1	1
09/10/2014 13:00	1.1	12.9	1,906.8	0.8	5.70	1	1	1
09/10/2014 14:00	1.2	12.7	1,952.5	0.9	5.90	1	1	1
09/10/2014 15:00	1.6	11.6	2,159.4	1.0	8.60	1	1	1
09/10/2014 16:00	1.6	11.3	2,208.6	1.0	8.80	1	1	1
09/10/2014 17:00	1.6	11.3	2,209.1	1.0	8.80	1	1	1
09/10/2014 18:00	1.7	11.4	2,186.6	1.1	8.70	1	1	1
09/10/2014 19:00	1.5	11.7	2,140.0	1.0	8.60	1	1	1
09/10/2014 20:00	1.4	12.0	2,069.1	0.9	6.20	1	1	1
09/10/2014 21:00	1.3	12.4	2,018.2	0.9	6.10	1	1	1
09/10/2014 22:00	1.3	12.5	2,006.7	0.9	6.00	1	1	1
09/10/2014 23:00	1.4	12.1	2,085.9	0.9	6.30	1	1	1
Average/Sum#:	1.3	12.6	1,938.7	0.9	152.40 #	24 #	24 #	23 #
Minimum:	0.8	11.3	1,256.9	0.7	3.80	1	1	0
Maximum:	1.7	14.0	2,209.1	1.1	8.80	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/11/2014 00:00	1.2	12.8	1,941.4	0.9	5.80	1	1	1
09/11/2014 01:00	1.1	13.3	1,840.4	0.9	5.50	1	1	1
09/11/2014 02:00	1.1	13.3	1,840.4	0.9	5.50	1	1	1
09/11/2014 03:00	1.1	13.3	1,839.9	0.9	5.50	1	1	1
09/11/2014 04:00	1.2	13.0	1,917.6	0.9	5.80	1	1	1
09/11/2014 05:00	1.3	12.3	2,051.4	0.9	6.20	1	1	1
09/11/2014 06:00	1.2	12.7	1,972.7	0.9	5.90	1	1	1
09/11/2014 07:00	1.2	12.8	1,957.7	0.9	5.90	1	1	1
09/11/2014 08:00	1.2	12.9	1,933.8	0.9	5.80	1	1	1
09/11/2014 09:00	1.2	12.7	1,978.6	0.9	5.90	1	1	1
09/11/2014 10:00	1.4	12.2	2,066.1	0.9	6.20	1	1	1
09/11/2014 11:00	1.4	11.9	2,091.6	0.9	6.30	1	1	1
09/11/2014 12:00	1.2	12.9	1,892.4	0.9	5.70	1	1	1
09/11/2014 13:00	1.1	12.9	1,884.0	0.8	5.70	1	1	1
09/11/2014 14:00	1.1	13.0	1,863.3	0.8	5.60	1	1	1
09/11/2014 15:00	1.1	13.0	1,872.0	0.8	5.60	1	1	1
09/11/2014 16:00	1.3	12.1	2,072.6	0.9	6.20	1	1	1
09/11/2014 17:00	1.6	11.4	2,191.8	1.0	8.80	1	1	1
09/11/2014 18:00	1.6	11.3	2,211.6	1.0	8.80	1	1	1
09/11/2014 19:00	1.5	11.6	2,147.1	1.0	8.60	1	1	1
09/11/2014 20:00	1.5	11.6	2,154.3	1.0	8.60	1	1	1
09/11/2014 21:00	1.3	12.4	1,995.9	0.9	6.00	1	1	1
09/11/2014 22:00	1.3	12.3	2,035.0	0.9	6.10	1	1	1
09/11/2014 23:00	1.6	11.4	2,231.2	1.0	8.90	1	1	1
Average/Sum#:	1.3	12.5	1,999.3	0.9	154.90 #	24 #	24 #	24 #
Minimum:	1.1	11.3	1,839.9	0.8	5.50	1	1	1
Maximum:	1.6	13.3	2,231.2	1.0	8.90	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/12/2014 00:00	1.5	11.8	2,143.7	1.0	8.60	1	1	1
09/12/2014 01:00	1.2	12.8	1,908.6	0.9	5.70	1	1	1
09/12/2014 02:00	1.3	12.3	1,986.1	0.9	6.00	1	1	1
09/12/2014 03:00	1.4	12.3	2,018.6	1.0	8.10	1	1	1
09/12/2014 04:00	1.6	11.5	2,219.1	1.0	8.90	1	1	1
09/12/2014 05:00	1.6	11.7	2,185.3	1.0	8.70	1	1	1
09/12/2014 06:00	1.6	11.5	2,230.8	1.0	8.90	1	1	1
09/12/2014 07:00	1.3	11.6	2,207.0	0.8	6.60	1	1	1
09/12/2014 08:00	1.4	11.9	2,125.9	0.9	6.40	1	1	1
09/12/2014 09:00	1.6	11.5	2,208.4	1.0	8.80	1	1	1
09/12/2014 10:00	1.6	11.6	2,192.6	1.0	8.80	1	1	1
09/12/2014 11:00	1.6	11.5	2,188.0	1.0	8.80	1	1	1
09/12/2014 12:00	1.6	11.4	2,204.7	1.0	8.80	1	1	1
09/12/2014 13:00	1.6	11.3	2,211.7	1.0	8.80	1	1	1
09/12/2014 14:00	1.6	11.4	2,172.6	1.0	8.70	1	1	1
09/12/2014 15:00	1.7	11.4	2,171.6	1.1	8.70	1	1	1
09/12/2014 16:00	1.6	11.4	2,161.7	1.0	8.60	1	1	1
09/12/2014 17:00	1.7	11.3	2,193.2	1.0	8.80	1	1	1
09/12/2014 18:00	1.6	11.3	2,206.3	1.0	8.80	1	1	1
09/12/2014 19:00	1.6	11.2	2,225.5	1.0	8.90	1	1	1
09/12/2014 20:00	1.6	11.7	2,163.5	1.0	8.70	1	1	1
09/12/2014 21:00	1.4	12.0	2,085.3	0.9	6.30	1	1	1
09/12/2014 22:00	1.2	12.7	1,950.5	0.9	5.90	1	1	1
09/12/2014 23:00	1.2	12.7	1,955.3	0.9	5.90	1	1	1
Average/Sum#:	1.5	11.7	2,138.2	1.0	191.20 #	24 #	24 #	24 #
Minimum:	1.2	11.2	1,908.6	0.8	5.70	1	1	1
Maximum:	1.7	12.8	2,230.8	1.1	8.90	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/13/2014 00:00	1.2	12.8	1,947.8	0.9	5.80	1	1	1
09/13/2014 01:00	1.2	12.9	1,918.2	0.9	5.80	1	1	1
09/13/2014 02:00	1.0	13.5	1,794.1	0.8	5.40	1	1	1
09/13/2014 03:00	1.1	13.3	1,846.3	0.9	5.50	1	1	1
09/13/2014 04:00	1.1	13.3	1,781.3	0.9	5.30	1	1	1
09/13/2014 05:00	0.8	13.9	1,256.8	0.7	2.50	1	1	0
09/13/2014 06:00	0.7	13.9	1,250.0	0.6	2.50	1	1	0
09/13/2014 07:00	0.8	13.9	1,249.9	0.7	2.50	1	1	0
09/13/2014 08:00	0.8	13.9	1,388.3	0.7	2.80	1	1	0
09/13/2014 09:00	0.9	14.0	1,509.1	0.8	4.50	1	1	0
09/13/2014 10:00	0.9	13.8	1,573.8	0.7	4.70	1	1	1
09/13/2014 11:00	1.2	12.6	1,978.8	0.9	5.90	1	1	1
09/13/2014 12:00	1.5	11.8	2,102.5	1.0	8.40	1	1	1
09/13/2014 13:00	1.3	12.3	1,997.1	0.9	6.00	1	1	1
09/13/2014 14:00	1.3	12.2	2,004.0	0.9	6.00	1	1	1
09/13/2014 15:00	1.5	11.7	2,108.0	1.0	8.40	1	1	1
09/13/2014 16:00	1.5	11.7	2,089.4	1.0	8.40	1	1	1
09/13/2014 17:00	1.4	11.9	2,062.6	0.9	6.20	1	1	1
09/13/2014 18:00	1.2	12.5	1,957.2	0.8	5.90	1	1	1
09/13/2014 19:00	1.3	12.3	2,008.7	0.9	6.00	1	1	1
09/13/2014 20:00	1.3	12.7	1,949.5	0.9	5.80	1	1	1
09/13/2014 21:00	1.2	12.7	1,948.4	0.9	5.80	1	1	1
09/13/2014 22:00	1.1	12.9	1,911.1	0.8	5.70	1	1	1
09/13/2014 23:00	1.2	12.8	1,941.9	0.9	5.80	1	1	1
Average/Sum#:	1.1	12.9	1,815.6	0.9	131.60 #	24 #	24 #	19 #
Minimum:	0.7	11.7	1,249.9	0.6	2.50	1	1	0
Maximum:	1.5	14.0	2,108.0	1.0	8.40	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/14/2014 00:00	1.1	13.0	1,896.9	0.8	5.70	1	1	1
09/14/2014 01:00	1.0	13.2	1,850.9	0.8	5.60	1	1	1
09/14/2014 02:00	1.1	13.3	1,844.9	0.9	5.50	1	1	1
09/14/2014 03:00	1.1	13.3	1,847.9	0.9	5.50	1	1	1
09/14/2014 04:00	1.1	13.3	1,793.5	0.9	5.40	1	1	1
09/14/2014 05:00	0.7	13.9	1,262.0	0.6	2.50	1	1	0
09/14/2014 06:00	0.7	13.9	1,250.7	0.6	2.50	1	1	0
09/14/2014 07:00	0.8	13.9	1,251.1	0.7	2.50	1	1	0
09/14/2014 08:00	0.8	13.9	1,435.4	0.7	2.90	1	1	0
09/14/2014 09:00	0.9	13.5	1,631.5	0.7	4.90	1	1	1
09/14/2014 10:00	1.0	13.0	1,900.7	0.7	5.70	1	1	1
09/14/2014 11:00	1.1	12.7	1,945.9	0.8	5.80	1	1	1
09/14/2014 12:00	1.6	11.6	2,169.8	1.0	8.70	1	1	1
09/14/2014 13:00	1.6	11.5	2,182.9	1.0	8.70	1	1	1
09/14/2014 14:00	1.6	11.5	2,173.9	1.0	8.70	1	1	1
09/14/2014 15:00	1.6	11.4	2,158.0	1.0	8.60	1	1	1
09/14/2014 16:00	1.6	11.4	2,151.0	1.0	8.60	1	1	1
09/14/2014 17:00	1.6	11.5	2,139.0	1.0	8.60	1	1	1
09/14/2014 18:00	1.5	11.6	2,129.5	1.0	8.50	1	1	1
09/14/2014 19:00	1.5	11.8	2,100.9	1.0	8.40	1	1	1
09/14/2014 20:00	1.4	12.1	2,057.1	0.9	6.20	1	1	1
09/14/2014 21:00	1.3	12.4	1,995.9	0.9	6.00	1	1	1
09/14/2014 22:00	1.1	12.8	1,916.5	0.8	5.70	1	1	1
09/14/2014 23:00	1.1	12.9	1,910.6	0.8	5.70	1	1	1
Average/Sum#:	1.2	12.6	1,874.9	0.9	146.90 #	24 #	24 #	20 #
Minimum:	0.7	11.4	1,250.7	0.6	2.50	1	1	0
Maximum:	1.6	13.9	2,182.9	1.0	8.70	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/15/2014 00:00	1.0	13.1	1,857.7	0.8	5.60	1	1	1
09/15/2014 01:00	1.0	13.3	1,834.3	0.8	5.50	1	1	1
09/15/2014 02:00	1.0	13.3	1,832.1	0.8	5.50	1	1	1
09/15/2014 03:00	1.0	13.3	1,835.5	0.8	5.50	1	1	1
09/15/2014 04:00	1.1	13.3	1,838.7	0.9	5.50	1	1	1
09/15/2014 05:00	1.1	13.3	1,841.7	0.9	5.50	1	1	1
09/15/2014 06:00	1.1	13.3	1,842.9	0.9	5.50	1	1	1
09/15/2014 07:00	1.1	13.2	1,861.7	0.8	5.60	1	1	1
09/15/2014 08:00	1.2	12.7	1,955.4	0.9	5.90	1	1	1
09/15/2014 09:00	1.4	12.0	2,108.6	0.9	6.30	1	1	1
09/15/2014 10:00	1.6	11.6	2,166.7	1.0	8.70	1	1	1
09/15/2014 11:00	1.6	11.5	2,173.6	1.0	8.70	1	1	1
09/15/2014 12:00	1.3	12.5	1,797.4	0.9	5.40	1	1	1
09/15/2014 13:00	0.7	14.0	1,320.5	0.6	2.60	1	1	0
09/15/2014 14:00	0.7	14.0	1,328.8	0.6	2.70	1	1	0
09/15/2014 15:00	1.1	12.7	1,902.1	0.8	5.70	1	1	1
09/15/2014 16:00	1.5	11.9	2,092.5	1.0	8.40	1	1	1
09/15/2014 17:00	1.5	12.0	2,080.7	1.0	8.30	1	1	1
09/15/2014 18:00	1.4	12.2	2,060.0	0.9	6.20	1	1	1
09/15/2014 19:00	1.3	12.3	2,039.2	0.9	6.10	1	1	1
09/15/2014 20:00	1.3	12.5	2,012.4	0.9	6.00	1	1	1
09/15/2014 21:00	1.1	13.0	1,904.8	0.8	5.70	1	1	1
09/15/2014 22:00	1.1	13.4	1,831.1	0.9	5.50	1	1	1
09/15/2014 23:00	1.1	13.3	1,841.8	0.9	5.50	1	1	1
Average/Sum#:	1.2	12.8	1,890.0	0.9	141.90 #	24 #	24 #	22 #
Minimum:	0.7	11.5	1,320.5	0.6	2.60	1	1	0
Maximum:	1.6	14.0	2,173.6	1.0	8.70	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/16/2014 00:00	1.1	13.4	1,832.9	0.9	5.50	1	1	1
09/16/2014 01:00	1.1	13.4	1,829.4	0.9	5.50	1	1	1
09/16/2014 02:00	1.0	13.7	1,573.8	0.8	4.70	1	1	1
09/16/2014 03:00	0.7	13.8	1,276.0	0.6	2.60	1	1	0
09/16/2014 04:00	0.9	13.6	1,654.2	0.7	5.00	1	1	1
09/16/2014 05:00	1.1	13.0	1,925.0	0.8	5.80	1	1	1
09/16/2014 06:00	1.0	13.0	1,937.8	0.7	5.80	1	1	1
09/16/2014 07:00	1.2	12.7	1,977.1	0.9	5.90	1	1	1
09/16/2014 08:00	1.1	12.6	2,006.5	0.8	6.00	1	1	1
09/16/2014 09:00	1.1	12.6	2,006.7	0.8	6.00	1	1	1
09/16/2014 10:00	1.5	11.8	2,159.6	1.0	8.60	1	1	1
09/16/2014 11:00	1.5	11.8	2,165.5	1.0	8.70	1	1	1
09/16/2014 12:00	1.6	11.8	2,169.1	1.0	8.70	1	1	1
09/16/2014 13:00	1.5	11.8	2,159.3	1.0	8.60	1	1	1
09/16/2014 14:00	1.3	12.5	2,008.1	0.9	6.00	1	1	1
09/16/2014 15:00	1.1	12.9	1,918.3	0.8	5.80	1	1	1
09/16/2014 16:00	1.3	12.4	2,036.8	0.9	6.10	1	1	1
09/16/2014 17:00	1.6	11.7	2,171.7	1.0	8.70	1	1	1
09/16/2014 18:00	1.6	11.7	2,176.0	1.0	8.70	1	1	1
09/16/2014 19:00	1.6	11.7	2,182.3	1.0	8.70	1	1	1
09/16/2014 20:00	1.5	12.0	2,128.7	1.0	8.50	1	1	1
09/16/2014 21:00	1.0	13.1	1,884.6	0.8	5.70	1	1	1
09/16/2014 22:00	1.0	13.6	1,691.0	0.8	5.10	1	1	1
09/16/2014 23:00	1.0	13.6	1,787.1	0.8	5.40	1	1	1
Average/Sum#:	1.2	12.7	1,944.1	0.9	156.10 #	24 #	24 #	23 #
Minimum:	0.7	11.7	1,276.0	0.6	2.60	1	1	0
Maximum:	1.6	13.8	2,182.3	1.0	8.70	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/17/2014 00:00	1.3	12.2	2,110.1	0.9	6.30	1	1	1
09/17/2014 01:00	1.3	12.2	2,099.8	0.9	6.30	1	1	1
09/17/2014 02:00	1.1	12.7	1,997.5	0.8	6.00	1	1	1
09/17/2014 03:00	1.4	11.9	2,161.2	0.9	6.50	1	1	1
09/17/2014 04:00	1.5	11.8	2,170.8	1.0	8.70	1	1	1
09/17/2014 05:00	1.4	12.0	2,143.1	0.9	6.40	1	1	1
09/17/2014 06:00	1.4	12.0	2,146.1	0.9	6.40	1	1	1
09/17/2014 07:00	1.5	11.8	2,166.7	1.0	8.70	1	1	1
09/17/2014 08:00	1.5	11.9	2,151.3	1.0	8.60	1	1	1
09/17/2014 09:00	1.5	11.9	2,128.3	1.0	8.50	1	1	1
09/17/2014 10:00	1.5	11.9	2,140.8	1.0	8.60	1	1	1
09/17/2014 11:00	1.5	11.8	2,157.0	1.0	8.60	1	1	1
09/17/2014 12:00	1.6	11.6	2,173.9	1.0	8.70	1	1	1
09/17/2014 13:00	1.5	11.7	2,153.5	1.0	8.60	1	1	1
09/17/2014 14:00	1.4	11.9	2,105.8	0.9	6.30	1	1	1
09/17/2014 15:00	1.4	12.1	2,070.4	0.9	6.20	1	1	1
09/17/2014 16:00	1.1	12.7	1,962.9	0.8	5.90	1	1	1
09/17/2014 17:00	1.2	12.7	1,962.2	0.9	5.90	1	1	1
09/17/2014 18:00	1.2	12.2	2,043.2	0.8	6.10	1	1	1
09/17/2014 19:00	1.1	12.5	1,977.0	0.8	5.90	1	1	1
09/17/2014 20:00	1.1	12.6	1,968.1	0.8	5.90	1	1	1
09/17/2014 21:00	0.9	13.2	1,845.7	0.7	5.50	1	1	1
09/17/2014 22:00	0.9	13.2	1,848.0	0.7	5.50	1	1	1
09/17/2014 23:00	1.0	13.2	1,857.6	0.8	5.60	1	1	1
Average/Sum#:	1.3	12.2	2,064.2	0.9	165.70 #	24 #	24 #	24 #
Minimum:	0.9	11.6	1,845.7	0.7	5.50	1	1	1
Maximum:	1.6	13.2	2,173.9	1.0	8.70	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/18/2014 00:00	1.1	12.7	1,968.3	0.8	5.90	1	1	1
09/18/2014 01:00	1.1	12.8	1,938.5	0.8	5.80	1	1	1
09/18/2014 02:00	0.9	13.3	1,848.5	0.7	5.50	1	1	1
09/18/2014 03:00	0.9	13.3	1,773.0	0.7	5.30	1	1	1
09/18/2014 04:00	0.8	13.8	1,568.1	0.7	3.10	1	1	0
09/18/2014 05:00	0.8	13.8	1,602.3	0.7	3.20	1	1	0
09/18/2014 06:00	0.8	13.8	1,585.4	0.7	3.20	1	1	0
09/18/2014 07:00	0.5	13.8	1,302.1	0.4	2.60	1	1	0
09/18/2014 08:00	0.7	13.8	1,409.6	0.6	2.80	1	1	0
09/18/2014 09:00	0.8	13.8	1,586.9	0.7	3.20	1	1	0
09/18/2014 10:00	0.6	13.9	1,286.1	0.5	2.60	1	1	0
09/18/2014 11:00	0.6	13.9	1,284.8	0.5	2.60	1	1	0
09/18/2014 12:00	0.8	13.9	1,475.6	0.7	3.00	1	1	0
09/18/2014 13:00	0.8	13.9	1,601.9	0.7	3.20	1	1	0
09/18/2014 14:00	0.9	13.8	1,664.2	0.7	5.00	1	1	0
09/18/2014 15:00	0.9	13.8	1,588.4	0.7	4.80	1	1	0
09/18/2014 16:00	0.9	13.5	1,711.8	0.7	5.10	1	1	1
09/18/2014 17:00	1.1	12.7	1,937.4	0.8	5.80	1	1	1
09/18/2014 18:00	1.2	12.3	2,023.1	0.8	6.10	1	1	1
09/18/2014 19:00	1.3	12.2	2,034.4	0.9	6.10	1	1	1
09/18/2014 20:00	1.0	13.1	1,849.5	0.8	5.50	1	1	1
09/18/2014 21:00	0.9	13.4	1,582.7	0.7	4.70	1	1	1
09/18/2014 22:00	0.6	13.9	1,238.1	0.5	2.50	1	1	0
09/18/2014 23:00	0.7	13.9	1,362.3	0.6	2.70	1	1	0
Average/Sum#:	0.9	13.5	1,634.3	0.7	100.30 #	24 #	24 #	10 #
Minimum:	0.5	12.2	1,238.1	0.4	2.50	1	1	0
Maximum:	1.3	13.9	2,034.4	0.9	6.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/19/2014 00:00	0.6	13.9	1,257.8	0.5	2.50	1	1	0
09/19/2014 01:00	0.6	13.9	1,248.4	0.5	2.50	1	1	0
09/19/2014 02:00	0.6	13.9	1,246.9	0.5	2.50	1	1	0
09/19/2014 03:00	0.7	13.9	1,314.6	0.6	2.60	1	1	0
09/19/2014 04:00	0.7	13.9	1,338.4	0.6	2.70	1	1	0
09/19/2014 05:00	0.8	13.6	1,612.1	0.6	3.20	1	1	1
09/19/2014 06:00	1.1	12.8	1,931.9	0.8	5.80	1	1	1
09/19/2014 07:00	1.1	13.3	1,840.9	0.9	5.50	1	1	1
09/19/2014 08:00	1.0	13.2	1,854.7	0.8	5.60	1	1	1
09/19/2014 09:00	1.0	13.2	1,864.3	0.8	5.60	1	1	1
09/19/2014 10:00	0.9	13.2	1,838.8	0.7	5.50	1	1	1
09/19/2014 11:00	0.8	13.2	1,840.3	0.6	3.70	1	1	1
09/19/2014 12:00	1.0	12.6	1,944.1	0.7	5.80	1	1	1
09/19/2014 13:00	1.1	12.6	1,942.2	0.8	5.80	1	1	1
09/19/2014 14:00	1.1	12.4	1,991.0	0.8	6.00	1	1	1
09/19/2014 15:00	1.6	11.4	2,166.7	1.0	8.70	1	1	1
09/19/2014 16:00	1.6	11.4	2,171.4	1.0	8.70	1	1	1
09/19/2014 17:00	1.6	11.5	2,166.1	1.0	8.70	1	1	1
09/19/2014 18:00	1.4	11.9	2,081.5	0.9	6.20	1	1	1
09/19/2014 19:00	1.1	12.8	1,915.8	0.8	5.70	1	1	1
09/19/2014 20:00	1.1	12.9	1,906.0	0.8	5.70	1	1	1
09/19/2014 21:00	1.1	12.8	1,917.5	0.8	5.80	1	1	1
09/19/2014 22:00	1.1	12.7	1,955.5	0.8	5.90	1	1	1
09/19/2014 23:00	1.2	12.5	2,001.2	0.8	6.00	1	1	1
Average/Sum#:	1.0	12.9	1,806.2	0.8	126.70 #	24 #	24 #	19 #
Minimum:	0.6	11.4	1,246.9	0.5	2.50	1	1	0
Maximum:	1.6	13.9	2,171.4	1.0	8.70	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/20/2014 00:00	1.2	12.3	2,042.4	0.8	6.10	1	1	1
09/20/2014 01:00	1.4	11.8	2,125.5	0.9	6.40	1	1	1
09/20/2014 02:00	1.1	12.6	1,975.2	0.8	5.90	1	1	1
09/20/2014 03:00	1.1	12.6	1,970.8	0.8	5.90	1	1	1
09/20/2014 04:00	1.1	12.6	1,985.1	0.8	6.00	1	1	1
09/20/2014 05:00	1.1	12.7	1,956.6	0.8	5.90	1	1	1
09/20/2014 06:00	1.1	12.7	1,971.3	0.8	5.90	1	1	1
09/20/2014 07:00	1.1	12.6	1,979.2	0.8	5.90	1	1	1
09/20/2014 08:00	1.0	13.2	1,842.3	0.8	5.50	1	1	1
09/20/2014 09:00	0.9	13.2	1,840.5	0.7	5.50	1	1	1
09/20/2014 10:00	0.9	13.2	1,839.2	0.7	5.50	1	1	1
09/20/2014 11:00	0.9	13.2	1,839.3	0.7	5.50	1	1	1
09/20/2014 12:00	0.9	13.1	1,842.8	0.7	5.50	1	1	1
09/20/2014 13:00	1.0	12.9	1,878.6	0.7	5.60	1	1	1
09/20/2014 14:00	1.0	12.9	1,887.2	0.7	5.70	1	1	1
09/20/2014 15:00	1.0	12.8	1,903.6	0.7	5.70	1	1	1
09/20/2014 16:00	1.1	13.1	1,855.2	0.8	5.60	1	1	1
09/20/2014 17:00	1.0	12.7	1,917.3	0.7	5.80	1	1	1
09/20/2014 18:00	1.0	12.7	1,927.9	0.7	5.80	1	1	1
09/20/2014 19:00	1.2	12.1	2,043.5	0.8	6.10	1	1	1
09/20/2014 20:00	1.0	13.0	1,870.8	0.7	5.60	1	1	1
09/20/2014 21:00	1.1	12.7	1,928.5	0.8	5.80	1	1	1
09/20/2014 22:00	0.9	13.2	1,846.4	0.7	5.50	1	1	1
09/20/2014 23:00	1.0	13.0	1,893.3	0.7	5.70	1	1	1
Average/Sum#:	1.0	12.8	1,923.4	0.8	138.40 #	24 #	24 #	24 #
Minimum:	0.9	11.8	1,839.2	0.7	5.50	1	1	1
Maximum:	1.4	13.2	2,125.5	0.9	6.40	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/21/2014 00:00	1.0	13.3	1,836.2	0.8	5.50	1	1	1
09/21/2014 01:00	0.9	13.3	1,835.6	0.7	5.50	1	1	1
09/21/2014 02:00	1.0	13.3	1,836.9	0.8	5.50	1	1	1
09/21/2014 03:00	0.9	13.3	1,834.8	0.7	5.50	1	1	1
09/21/2014 04:00	1.0	13.3	1,837.7	0.8	5.50	1	1	1
09/21/2014 05:00	1.0	13.3	1,837.9	0.8	5.50	1	1	1
09/21/2014 06:00	1.0	13.3	1,841.4	0.8	5.50	1	1	1
09/21/2014 07:00	1.1	13.3	1,846.5	0.9	5.50	1	1	1
09/21/2014 08:00	1.0	13.3	1,838.6	0.8	5.50	1	1	1
09/21/2014 09:00	0.9	13.3	1,836.7	0.7	5.50	1	1	1
09/21/2014 10:00	0.9	13.2	1,837.4	0.7	5.50	1	1	1
09/21/2014 11:00	0.9	13.2	1,719.9	0.7	5.20	1	1	1
09/21/2014 12:00	0.6	13.9	1,252.8	0.5	2.50	1	1	0
09/21/2014 13:00	0.6	13.9	1,244.6	0.5	2.50	1	1	0
09/21/2014 14:00	0.7	13.9	1,250.8	0.6	2.50	1	1	0
09/21/2014 15:00	0.7	13.9	1,261.7	0.6	2.50	1	1	0
09/21/2014 16:00	0.7	13.9	1,277.3	0.6	2.60	1	1	0
09/21/2014 17:00	0.8	13.5	1,701.1	0.6	3.40	1	1	1
09/21/2014 18:00	0.9	13.1	1,859.4	0.7	5.60	1	1	1
09/21/2014 19:00	1.1	12.9	1,907.6	0.8	5.70	1	1	1
09/21/2014 20:00	0.9	13.2	1,833.1	0.7	5.50	1	1	1
09/21/2014 21:00	0.9	13.2	1,832.7	0.7	5.50	1	1	1
09/21/2014 22:00	0.8	13.5	1,518.6	0.6	3.00	1	1	1
09/21/2014 23:00	0.6	13.8	1,244.1	0.5	2.50	1	1	0
Average/Sum#:	0.9	13.4	1,671.8	0.7	109.50 #	24 #	24 #	18 #
Minimum:	0.6	12.9	1,244.1	0.5	2.50	1	1	0
Maximum:	1.1	13.9	1,907.6	0.9	5.70	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/22/2014 00:00	0.6	13.8	1,244.2	0.5	2.50	1	1	0
09/22/2014 01:00	0.6	13.8	1,242.9	0.5	2.50	1	1	0
09/22/2014 02:00	0.6	13.8	1,271.7	0.5	2.50	1	1	0
09/22/2014 03:00	1.0	13.5	1,697.1	0.8	5.10	1	1	1
09/22/2014 04:00	1.0	13.3	1,850.1	0.8	5.60	1	1	1
09/22/2014 05:00	1.1	13.0	1,916.2	0.8	5.70	1	1	1
09/22/2014 06:00	1.1	12.5	2,016.7	0.8	6.10	1	1	1
09/22/2014 07:00	0.4	13.8	1,394.1	0.3	1.40	1	1	1
09/22/2014 08:00	0.4	13.8	1,276.4	0.3	1.30	1	1	0
09/22/2014 09:00	0.0	0.0	1,275.0	0.0	0.00	1	1	0
09/22/2014 10:00	0.0	0.0	1,287.8	0.0	0.00	1	1	0
09/22/2014 11:00	0.0	0.0	1,408.5	0.0	0.00	1	1	0
09/22/2014 12:00	0.0	0.0	1,724.1	0.0	0.00	1	1	0
09/22/2014 13:00	0.9	13.6	1,687.0	0.7	5.10	1	1	0
09/22/2014 14:00	0.9	13.6	1,726.9	0.7	5.20	1	1	0
09/22/2014 15:00	0.9	13.6	1,722.3	0.7	5.20	1	1	0
09/22/2014 16:00	0.9	13.6	1,722.1	0.7	5.20	1	1	0
09/22/2014 17:00	0.9	13.6	1,725.3	0.7	5.20	1	1	0
09/22/2014 18:00	0.9	13.6	1,730.8	0.7	5.20	1	1	0
09/22/2014 19:00	1.0	13.6	1,737.3	0.8	5.20	1	1	0
09/22/2014 20:00	1.0	13.6	1,736.3	0.8	5.20	1	1	0
09/22/2014 21:00	0.9	13.7	1,706.6	0.7	5.10	1	1	0
09/22/2014 22:00	0.9	13.8	1,544.3	0.7	4.60	1	1	0
09/22/2014 23:00	1.0	13.8	1,673.3	0.8	5.00	1	1	0
Average/Sum#:	0.9	13.6	1,596.5	0.7	88.90 #	24 #	24 #	5 #
Minimum:	0.4	12.5	1,242.9	0.3	1.30	1	1	0
Maximum:	1.1	13.8	2,016.7	0.8	6.10	1	1	1
%SI	16.7	16.7	0.0	16.7	16.67	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/23/2014 00:00	0.9	13.8	1,625.7	0.7	4.90	1	1	0
09/23/2014 01:00	1.0	13.8	1,589.9	0.8	4.80	1	1	0
09/23/2014 02:00	1.0	13.8	1,581.0	0.8	4.70	1	1	0
09/23/2014 03:00	1.0	13.7	1,695.5	0.8	5.10	1	1	0
09/23/2014 04:00	1.0	13.7	1,716.1	0.8	5.10	1	1	0
09/23/2014 05:00	1.0	13.7	1,720.3	0.8	5.20	1	1	0
09/23/2014 06:00	1.0	13.6	1,783.8	0.8	5.40	1	1	0
09/23/2014 07:00	1.0	13.8	1,680.2	0.8	5.00	1	1	0
09/23/2014 08:00	0.7	13.8	1,302.0	0.6	2.60	1	1	0
09/23/2014 09:00	0.7	13.8	1,283.9	0.6	2.60	1	1	0
09/23/2014 10:00	0.7	13.9	1,276.0	0.6	2.60	1	1	0
09/23/2014 11:00	0.9	13.9	1,461.2	0.8	4.40	1	1	0
09/23/2014 12:00	0.9	13.8	1,657.4	0.7	5.00	1	1	0
09/23/2014 13:00	0.9	13.8	1,642.1	0.7	4.90	1	1	0
09/23/2014 14:00	0.9	13.7	1,735.0	0.7	5.20	1	1	0
09/23/2014 15:00	1.0	13.7	1,734.7	0.8	5.20	1	1	0
09/23/2014 16:00	0.9	13.7	1,730.7	0.7	5.20	1	1	0
09/23/2014 17:00	0.9	13.7	1,733.8	0.7	5.20	1	1	0
09/23/2014 18:00	0.9	13.7	1,743.7	0.7	5.20	1	1	0
09/23/2014 19:00	1.0	13.7	1,749.9	0.8	5.20	1	1	0
09/23/2014 20:00	1.0	13.7	1,696.6	0.8	5.10	1	1	0
09/23/2014 21:00	0.9	13.6	1,755.0	0.7	5.30	1	1	0
09/23/2014 22:00	0.9	13.6	1,759.3	0.7	5.30	1	1	0
09/23/2014 23:00	0.9	13.6	1,772.4	0.7	5.30	1	1	0
Average/Sum#:	0.9	13.7	1,642.8	0.7	114.50 #	24 #	24 #	0 #
Minimum:	0.7	13.6	1,276.0	0.6	2.60	1	1	0
Maximum:	1.0	13.9	1,783.8	0.8	5.40	1	1	0
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/24/2014 00:00	0.9	13.6	1,779.3	0.7	5.30	1	1	0
09/24/2014 01:00	0.9	13.6	1,781.8	0.7	5.30	1	1	0
09/24/2014 02:00	0.9	13.6	1,781.6	0.7	5.30	1	1	0
09/24/2014 03:00	0.8	13.6	1,763.1	0.6	3.50	1	1	0
09/24/2014 04:00	0.9	13.6	1,743.7	0.7	5.20	1	1	0
09/24/2014 05:00	0.8	13.7	1,673.3	0.7	3.30	1	1	0
09/24/2014 06:00	0.8	13.6	1,775.0	0.6	3.60	1	1	0
09/24/2014 07:00	0.8	13.7	1,711.7	0.7	3.40	1	1	0
09/24/2014 08:00	0.8	13.8	1,596.6	0.7	3.20	1	1	0
09/24/2014 09:00	0.9	13.7	1,720.9	0.7	5.20	1	1	0
09/24/2014 10:00	0.9	13.6	1,758.6	0.7	5.30	1	1	0
09/24/2014 11:00	0.9	13.6	1,755.0	0.7	5.30	1	1	0
09/24/2014 12:00	0.9	13.6	1,748.9	0.7	5.20	1	1	0
09/24/2014 13:00	0.9	13.6	1,746.4	0.7	5.20	1	1	0
09/24/2014 14:00	0.9	13.7	1,747.5	0.7	5.20	1	1	0
09/24/2014 15:00	0.9	13.7	1,747.7	0.7	5.20	1	1	0
09/24/2014 16:00	0.8	13.7	1,743.8	0.7	3.50	1	1	0
09/24/2014 17:00	0.9	13.6	1,755.4	0.7	5.30	1	1	0
09/24/2014 18:00	0.9	13.6	1,762.4	0.7	5.30	1	1	0
09/24/2014 19:00	0.9	13.6	1,766.3	0.7	5.30	1	1	0
09/24/2014 20:00	0.9	13.6	1,773.8	0.7	5.30	1	1	0
09/24/2014 21:00	0.9	13.6	1,778.7	0.7	5.30	1	1	0
09/24/2014 22:00	0.9	13.6	1,782.1	0.7	5.30	1	1	0
09/24/2014 23:00	0.8	13.6	1,769.6	0.6	3.50	1	1	0
Average/Sum#:	0.9	13.6	1,748.5	0.7	113.50 #	24 #	24 #	0 #
Minimum:	0.8	13.6	1,596.6	0.6	3.20	1	1	0
Maximum:	0.9	13.8	1,782.1	0.7	5.30	1	1	0
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/25/2014 00:00	0.9	13.6	1,774.2	0.7	5.30	1	1	0
09/25/2014 01:00	0.8	13.6	1,772.1	0.6	3.50	1	1	0
09/25/2014 02:00	0.8	13.6	1,770.9	0.6	3.50	1	1	0
09/25/2014 03:00	0.8	13.7	1,730.2	0.7	3.50	1	1	0
09/25/2014 04:00	0.8	13.6	1,771.3	0.6	3.50	1	1	0
09/25/2014 05:00	0.8	13.7	1,738.4	0.7	3.50	1	1	0
09/25/2014 06:00	0.8	13.6	1,772.4	0.6	3.50	1	1	0
09/25/2014 07:00	0.8	13.7	1,748.3	0.7	3.50	1	1	0
09/25/2014 08:00	0.8	13.6	1,771.4	0.6	3.50	1	1	0
09/25/2014 09:00	0.8	13.6	1,767.9	0.6	3.50	1	1	0
09/25/2014 10:00	0.8	13.6	1,760.2	0.6	3.50	1	1	0
09/25/2014 11:00	0.8	13.6	1,785.0	0.6	3.60	1	1	0
09/25/2014 12:00	0.8	13.6	1,771.9	0.6	3.50	1	1	0
09/25/2014 13:00	0.9	12.4	2,039.6	0.6	4.10	1	1	1
09/25/2014 14:00	1.2	11.9	2,141.5	0.8	6.40	1	1	1
09/25/2014 15:00	1.3	11.6	2,179.6	0.8	6.50	1	1	1
09/25/2014 16:00	0.9	12.8	1,944.2	0.7	3.90	1	1	1
09/25/2014 17:00	1.0	12.5	2,022.8	0.7	6.10	1	1	1
09/25/2014 18:00	1.1	12.4	2,060.4	0.8	6.20	1	1	1
09/25/2014 19:00	1.1	12.3	2,070.5	0.8	6.20	1	1	1
09/25/2014 20:00	0.9	13.0	1,933.0	0.7	3.90	1	1	1
09/25/2014 21:00	0.9	13.1	1,897.7	0.7	5.70	1	1	1
09/25/2014 22:00	0.9	12.9	1,936.8	0.7	3.90	1	1	1
09/25/2014 23:00	1.0	12.4	2,040.6	0.7	6.10	1	1	1
Average/Sum#:	0.9	13.1	1,883.4	0.7	106.40 #	24 #	24 #	11 #
Minimum:	0.8	11.6	1,730.2	0.6	3.50	1	1	0
Maximum:	1.3	13.7	2,179.6	0.8	6.50	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report
CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/26/2014 00:00	0.9	12.9	1,940.1	0.7	3.90	1	1	1
09/26/2014 01:00	0.9	12.9	1,953.3	0.7	3.90	1	1	1
09/26/2014 02:00	0.9	13.1	1,897.5	0.7	5.70	1	1	1
09/26/2014 03:00	0.9	13.0	1,923.3	0.7	3.80	1	1	1
09/26/2014 04:00	1.2	11.9	2,160.7	0.8	6.50	1	1	1
09/26/2014 05:00	1.3	11.8	2,182.9	0.8	6.50	1	1	1
09/26/2014 06:00	1.4	11.7	2,198.7	0.9	6.60	1	1	1
09/26/2014 07:00	1.1	12.5	2,045.1	0.8	6.10	1	1	1
09/26/2014 08:00	0.9	13.3	1,870.5	0.7	5.60	1	1	1
09/26/2014 09:00	1.0	12.8	1,983.2	0.7	5.90	1	1	1
09/26/2014 10:00	1.0	12.6	2,011.4	0.7	6.00	1	1	1
09/26/2014 11:00	1.0	12.8	1,963.7	0.7	5.90	1	1	1
09/26/2014 12:00	0.9	13.2	1,884.8	0.7	5.70	1	1	1
09/26/2014 13:00	0.9	13.3	1,857.2	0.7	5.60	1	1	1
09/26/2014 14:00	0.9	13.3	1,860.5	0.7	5.60	1	1	1
09/26/2014 15:00	0.9	13.3	1,853.7	0.7	5.60	1	1	1
09/26/2014 16:00	0.9	13.3	1,855.4	0.7	5.60	1	1	1
09/26/2014 17:00	1.0	13.0	1,922.9	0.7	5.80	1	1	1
09/26/2014 18:00	0.9	13.1	1,895.7	0.7	5.70	1	1	1
09/26/2014 19:00	0.9	13.3	1,860.5	0.7	5.60	1	1	1
09/26/2014 20:00	1.0	13.3	1,863.5	0.8	5.60	1	1	1
09/26/2014 21:00	1.0	13.1	1,916.0	0.8	5.70	1	1	1
09/26/2014 22:00	1.0	13.2	1,887.0	0.8	5.70	1	1	1
09/26/2014 23:00	1.1	12.6	2,023.7	0.8	6.10	1	1	1
Average/Sum#:	1.0	12.9	1,950.5	0.7	134.70 #	24 #	24 #	24 #
Minimum:	0.9	11.7	1,853.7	0.7	3.80	1	1	1
Maximum:	1.4	13.3	2,198.7	0.9	6.60	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/27/2014 00:00	1.1	12.5	2,052.4	0.8	6.20	1	1	1
09/27/2014 01:00	1.3	12.1	2,120.7	0.9	6.40	1	1	1
09/27/2014 02:00	1.0	12.9	1,960.0	0.7	5.90	1	1	1
09/27/2014 03:00	1.0	13.1	1,915.3	0.8	5.70	1	1	1
09/27/2014 04:00	1.0	13.2	1,889.8	0.8	5.70	1	1	1
09/27/2014 05:00	1.0	13.1	1,906.6	0.8	5.70	1	1	1
09/27/2014 06:00	0.9	13.1	1,889.6	0.7	5.70	1	1	1
09/27/2014 07:00	0.7	13.7	1,592.0	0.6	3.20	1	1	1
09/27/2014 08:00	0.5	13.8	1,269.2	0.4	2.50	1	1	0
09/27/2014 09:00	0.7	13.9	1,345.4	0.6	2.70	1	1	0
09/27/2014 10:00	0.6	13.9	1,281.8	0.5	2.60	1	1	0
09/27/2014 11:00	0.6	13.9	1,254.6	0.5	2.50	1	1	0
09/27/2014 12:00	0.6	13.9	1,253.0	0.5	2.50	1	1	0
09/27/2014 13:00	0.6	13.9	1,253.6	0.5	2.50	1	1	0
09/27/2014 14:00	0.6	13.9	1,253.4	0.5	2.50	1	1	0
09/27/2014 15:00	0.6	13.9	1,250.6	0.5	2.50	1	1	0
09/27/2014 16:00	0.6	13.9	1,247.9	0.5	2.50	1	1	0
09/27/2014 17:00	0.8	13.5	1,608.2	0.6	3.20	1	1	1
09/27/2014 18:00	1.3	11.8	2,150.9	0.8	6.50	1	1	1
09/27/2014 19:00	1.1	12.7	1,949.9	0.8	5.80	1	1	1
09/27/2014 20:00	1.0	13.1	1,895.1	0.8	5.70	1	1	1
09/27/2014 21:00	1.0	12.8	1,948.2	0.7	5.80	1	1	1
09/27/2014 22:00	0.9	13.4	1,827.1	0.7	5.50	1	1	1
09/27/2014 23:00	1.0	13.4	1,856.5	0.8	5.60	1	1	1
Average/Sum#:	0.9	13.3	1,665.5	0.7	105.40 #	24 #	24 #	15 #
Minimum:	0.5	11.8	1,247.9	0.4	2.50	1	1	0
Maximum:	1.3	13.9	2,150.9	0.9	6.50	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/28/2014 00:00	0.8	13.5	1,461.9	0.6	2.90	1	1	1
09/28/2014 01:00	0.6	13.9	1,251.2	0.5	2.50	1	1	0
09/28/2014 02:00	0.6	13.9	1,249.5	0.5	2.50	1	1	0
09/28/2014 03:00	0.8	13.9	1,518.4	0.7	3.00	1	1	0
09/28/2014 04:00	0.9	13.3	1,841.0	0.7	5.50	1	1	1
09/28/2014 05:00	1.0	12.8	1,973.4	0.7	5.90	1	1	1
09/28/2014 06:00	1.0	12.6	2,002.2	0.7	6.00	1	1	1
09/28/2014 07:00	0.9	13.3	1,862.7	0.7	5.60	1	1	1
09/28/2014 08:00	1.0	13.1	1,881.7	0.8	5.60	1	1	1
09/28/2014 09:00	0.6	13.8	1,308.0	0.5	2.60	1	1	1
09/28/2014 10:00	0.5	13.8	1,252.5	0.4	2.50	1	1	0
09/28/2014 11:00	0.8	13.6	1,541.8	0.6	3.10	1	1	1
09/28/2014 12:00	0.9	13.3	1,839.6	0.7	5.50	1	1	1
09/28/2014 13:00	0.9	13.3	1,838.8	0.7	5.50	1	1	1
09/28/2014 14:00	0.9	13.3	1,838.9	0.7	5.50	1	1	1
09/28/2014 15:00	0.9	13.3	1,844.4	0.7	5.50	1	1	1
09/28/2014 16:00	1.0	13.0	1,931.8	0.7	5.80	1	1	1
09/28/2014 17:00	1.1	12.3	2,063.6	0.8	6.20	1	1	1
09/28/2014 18:00	1.6	11.4	2,244.6	1.0	9.00	1	1	1
09/28/2014 19:00	1.6	11.4	2,256.2	1.0	9.00	1	1	1
09/28/2014 20:00	1.0	12.6	1,994.4	0.7	6.00	1	1	1
09/28/2014 21:00	1.0	12.9	1,947.2	0.7	5.80	1	1	1
09/28/2014 22:00	1.0	13.0	1,935.2	0.7	5.80	1	1	1
09/28/2014 23:00	0.9	13.4	1,853.4	0.7	5.60	1	1	1
Average/Sum#:	0.9	13.1	1,780.5	0.7	122.90 #	24 #	24 #	20 #
Minimum:	0.5	11.4	1,249.5	0.4	2.50	1	1	0
Maximum:	1.6	13.9	2,256.2	1.0	9.00	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/29/2014 00:00	0.9	13.5	1,835.3	0.7	5.50	1	1	1
09/29/2014 01:00	0.9	13.5	1,836.5	0.7	5.50	1	1	1
09/29/2014 02:00	0.9	13.5	1,836.7	0.7	5.50	1	1	1
09/29/2014 03:00	0.9	13.5	1,836.2	0.7	5.50	1	1	1
09/29/2014 04:00	1.0	13.4	1,857.5	0.8	5.60	1	1	1
09/29/2014 05:00	1.0	13.3	1,866.0	0.8	5.60	1	1	1
09/29/2014 06:00	1.0	12.7	1,988.3	0.7	6.00	1	1	1
09/29/2014 07:00	1.0	13.3	1,840.3	0.8	5.50	1	1	1
09/29/2014 08:00	1.0	13.3	1,839.3	0.8	5.50	1	1	1
09/29/2014 09:00	1.0	13.3	1,847.0	0.8	5.50	1	1	1
09/29/2014 10:00	1.2	13.2	1,855.3	0.9	5.60	1	1	1
09/29/2014 11:00	1.2	13.2	1,853.2	0.9	5.60	1	1	1
09/29/2014 12:00	0.6	13.8	1,283.9	0.5	2.60	1	1	0
09/29/2014 13:00	0.6	13.9	1,252.4	0.5	2.50	1	1	0
09/29/2014 14:00	0.8	13.6	1,519.0	0.6	3.00	1	1	1
09/29/2014 15:00	0.9	13.2	1,842.3	0.7	5.50	1	1	1
09/29/2014 16:00	0.9	13.0	1,896.4	0.7	3.80	1	1	1
09/29/2014 17:00	1.0	12.6	1,971.9	0.7	5.90	1	1	1
09/29/2014 18:00	1.3	11.8	2,141.2	0.8	6.40	1	1	1
09/29/2014 19:00	1.3	12.0	2,097.7	0.9	6.30	1	1	1
09/29/2014 20:00	1.0	12.9	1,925.0	0.7	5.80	1	1	1
09/29/2014 21:00	0.9	13.3	1,715.2	0.7	5.10	1	1	1
09/29/2014 22:00	0.6	13.9	1,264.3	0.5	2.50	1	1	0
09/29/2014 23:00	0.7	13.8	1,298.1	0.6	2.60	1	1	0
Average/Sum#:	0.9	13.2	1,770.8	0.7	118.90 #	24 #	24 #	20 #
Minimum:	0.6	11.8	1,252.4	0.5	2.50	1	1	0
Maximum:	1.3	13.9	2,141.2	0.9	6.40	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT1 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1 NOx, Ppm 1 Hour(s)	Unit CT1 O2, Dry, Pct 1 Hour(s)	Unit CT1 Hr, MBtuPerHr 1 Hour(s)	Unit CT1 NOx, Ppmvdc 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)	Unit CT1 DBOn, TF 1 Hour(s)
09/30/2014 00:00	0.6	13.8	1,252.5	0.5	2.50	1	1	0
09/30/2014 01:00	0.6	13.8	1,253.2	0.5	2.50	1	1	0
09/30/2014 02:00	0.6	13.8	1,253.6	0.5	2.50	1	1	0
09/30/2014 03:00	0.6	13.8	1,254.3	0.5	2.50	1	1	0
09/30/2014 04:00	0.7	13.8	1,376.5	0.6	2.80	1	1	0
09/30/2014 05:00	0.9	13.4	1,647.5	0.7	4.90	1	1	1
09/30/2014 06:00	1.0	13.2	1,879.9	0.8	5.60	1	1	1
09/30/2014 07:00	1.0	13.3	1,851.9	0.8	5.60	1	1	1
09/30/2014 08:00	0.9	13.3	1,852.8	0.7	5.60	1	1	1
09/30/2014 09:00	1.0	13.2	1,851.7	0.8	5.60	1	1	1
09/30/2014 10:00	0.6	13.9	1,255.1	0.5	2.50	1	1	0
09/30/2014 11:00	0.7	13.9	1,251.9	0.6	2.50	1	1	0
09/30/2014 12:00	1.1	13.6	1,635.7	0.9	4.90	1	1	1
09/30/2014 13:00	1.1	13.3	1,848.7	0.9	5.50	1	1	1
09/30/2014 14:00	0.9	13.3	1,850.7	0.7	5.60	1	1	1
09/30/2014 15:00	0.9	13.3	1,855.8	0.7	5.60	1	1	1
09/30/2014 16:00	0.9	13.2	1,870.7	0.7	5.60	1	1	1
09/30/2014 17:00	0.9	13.3	1,860.5	0.7	5.60	1	1	1
09/30/2014 18:00	1.1	12.6	2,006.2	0.8	6.00	1	1	1
09/30/2014 19:00	1.3	12.2	2,076.5	0.9	6.20	1	1	1
09/30/2014 20:00	1.0	13.4	1,857.5	0.8	5.60	1	1	1
09/30/2014 21:00	0.9	13.7	1,468.2	0.7	4.40	1	1	1
09/30/2014 22:00	0.8	13.9	1,256.7	0.7	2.50	1	1	0
09/30/2014 23:00	0.8	13.9	1,254.7	0.7	2.50	1	1	0
Average/Sum#:	0.9	13.5	1,617.6	0.7	105.10 #	24 #	24 #	15 #
Minimum:	0.6	12.2	1,251.9	0.5	2.50	1	1	0
Maximum:	1.3	13.9	2,076.5	0.9	6.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/01/2014 00:00	0.8	13.0	1,860.8	0.6	3.70	1	1	1
07/01/2014 01:00	0.6	13.5	1,578.8	0.5	3.20	1	1	1
07/01/2014 02:00	0.7	13.3	1,567.0	0.5	3.10	1	1	1
07/01/2014 03:00	0.4	13.7	1,246.5	0.3	1.20	1	1	0
07/01/2014 04:00	0.4	13.7	1,287.7	0.3	1.30	1	1	0
07/01/2014 05:00	0.7	13.4	1,558.6	0.6	3.10	1	1	1
07/01/2014 06:00	1.0	13.0	1,909.5	0.7	5.70	1	1	1
07/01/2014 07:00	0.9	12.9	1,896.3	0.7	3.80	1	1	1
07/01/2014 08:00	1.0	12.8	1,921.0	0.7	5.80	1	1	1
07/01/2014 09:00	1.0	12.7	1,924.7	0.7	5.80	1	1	1
07/01/2014 10:00	1.0	12.8	1,892.1	0.7	5.70	1	1	1
07/01/2014 11:00	1.0	12.8	1,881.9	0.7	5.60	1	1	1
07/01/2014 12:00	1.0	12.8	1,890.0	0.7	5.70	1	1	1
07/01/2014 13:00	1.0	12.7	1,900.9	0.7	5.70	1	1	1
07/01/2014 14:00	0.9	12.7	1,913.0	0.6	3.80	1	1	1
07/01/2014 15:00	0.9	12.6	1,925.7	0.6	3.90	1	1	1
07/01/2014 16:00	1.0	12.0	2,043.1	0.7	4.10	1	1	1
07/01/2014 17:00	1.2	11.7	2,135.1	0.8	6.40	1	1	1
07/01/2014 18:00	1.3	11.7	2,119.9	0.8	6.40	1	1	1
07/01/2014 19:00	0.8	12.8	1,894.4	0.6	3.80	1	1	1
07/01/2014 20:00	0.9	12.9	1,879.9	0.7	3.80	1	1	1
07/01/2014 21:00	0.7	13.0	1,864.0	0.5	3.70	1	1	1
07/01/2014 22:00	0.8	13.0	1,863.6	0.6	3.70	1	1	1
07/01/2014 23:00	0.9	13.1	1,862.5	0.7	5.60	1	1	1
Average/Sum#:	0.9	12.9	1,825.7	0.6	104.60 #	24 #	24 #	22 #
Minimum:	0.4	11.7	1,246.5	0.3	1.20	1	1	0
Maximum:	1.3	13.7	2,135.1	0.8	6.40	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/02/2014 00:00	1.0	13.1	1,863.8	0.8	5.60	1	1	1
07/02/2014 01:00	1.0	13.1	1,864.1	0.8	5.60	1	1	1
07/02/2014 02:00	1.1	13.1	1,862.8	0.8	5.60	1	1	1
07/02/2014 03:00	1.1	13.1	1,863.9	0.8	5.60	1	1	1
07/02/2014 04:00	1.1	12.9	1,928.5	0.8	5.80	1	1	1
07/02/2014 05:00	1.3	12.3	2,082.0	0.9	6.20	1	1	1
07/02/2014 06:00	1.0	12.7	2,013.3	0.7	6.00	1	1	1
07/02/2014 07:00	1.0	13.0	1,897.3	0.7	5.70	1	1	1
07/02/2014 08:00	0.9	13.0	1,893.5	0.7	3.80	1	1	1
07/02/2014 09:00	0.9	13.0	1,893.5	0.7	3.80	1	1	1
07/02/2014 10:00	0.8	13.0	1,891.2	0.6	3.80	1	1	1
07/02/2014 11:00	0.9	12.9	1,894.7	0.7	3.80	1	1	1
07/02/2014 12:00	1.0	12.8	1,894.9	0.7	5.70	1	1	1
07/02/2014 13:00	1.0	12.8	1,897.7	0.7	5.70	1	1	1
07/02/2014 14:00	1.1	12.2	2,025.7	0.7	6.10	1	1	1
07/02/2014 15:00	1.3	11.7	2,142.1	0.8	6.40	1	1	1
07/02/2014 16:00	1.1	12.1	2,037.6	0.7	6.10	1	1	1
07/02/2014 17:00	1.1	12.4	1,976.1	0.8	5.90	1	1	1
07/02/2014 18:00	1.1	12.3	1,989.8	0.8	6.00	1	1	1
07/02/2014 19:00	1.0	12.5	1,966.6	0.7	5.90	1	1	1
07/02/2014 20:00	1.0	12.5	1,965.4	0.7	5.90	1	1	1
07/02/2014 21:00	0.4	13.6	1,331.9	0.3	1.30	1	1	1
07/02/2014 22:00	5.0	15.9	443.7	5.9	1.76	1	0	0
07/02/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.2	12.9	1,853.0	0.9	118.06 #	23 #	22 #	22 #
Minimum:	0.4	11.7	443.7	0.3	1.30	0	0	0
Maximum:	5.0	15.9	2,142.1	5.9	6.40	1	1	1
%SI	4.2	4.2	4.2	4.2	4.17	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/03/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/03/2014 07:00	23.1	16.9	529.2	34.1	46.69	1	0	0
07/03/2014 08:00	9.5	13.9	1,421.5	8.0	41.20	1	0	0
07/03/2014 09:00	0.9	13.0	1,885.3	0.7	3.80	1	1	1
07/03/2014 10:00	1.1	12.9	1,891.5	0.8	5.70	1	1	1
07/03/2014 11:00	1.2	12.8	1,918.0	0.9	5.80	1	1	1
07/03/2014 12:00	1.1	12.4	1,975.5	0.8	5.90	1	1	1
07/03/2014 13:00	1.3	11.8	2,109.6	0.8	6.30	1	1	1
07/03/2014 14:00	1.3	11.6	2,140.1	0.8	6.40	1	1	1
07/03/2014 15:00	1.3	11.6	2,157.5	0.8	6.50	1	1	1
07/03/2014 16:00	1.3	11.6	2,156.9	0.8	6.50	1	1	1
07/03/2014 17:00	1.3	11.5	2,155.8	0.8	6.50	1	1	1
07/03/2014 18:00	1.3	11.4	2,181.6	0.8	6.50	1	1	1
07/03/2014 19:00	1.4	11.4	2,179.4	0.9	6.50	1	1	1
07/03/2014 20:00	1.2	12.0	2,071.2	0.8	6.20	1	1	1
07/03/2014 21:00	1.1	12.3	2,002.3	0.8	6.00	1	1	1
07/03/2014 22:00	1.2	12.3	2,035.9	0.8	6.10	1	1	1
07/03/2014 23:00	1.6	11.5	2,207.6	1.0	8.80	1	1	1
Average/Sum#:	3.0	12.4	1,942.3	3.2	181.39 #	17 #	15 #	15 #
Minimum:	0.9	11.4	529.2	0.7	3.80	0	0	0
Maximum:	23.1	16.9	2,207.6	34.1	46.69	1	1	1
%SI	29.2	29.2	29.2	29.2	29.17	0	0	0

Daily Summary Report
CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/04/2014 00:00	1.2	12.4	2,013.9	0.8	6.00	1	1	1
07/04/2014 01:00	1.1	12.7	1,966.5	0.8	5.90	1	1	1
07/04/2014 02:00	1.0	13.0	1,900.7	0.7	5.70	1	1	1
07/04/2014 03:00	1.0	13.1	1,863.3	0.8	5.60	1	1	1
07/04/2014 04:00	1.0	13.0	1,905.5	0.7	5.70	1	1	1
07/04/2014 05:00	1.0	13.1	1,895.4	0.8	5.70	1	1	1
07/04/2014 06:00	1.0	13.0	1,893.5	0.7	5.70	1	1	1
07/04/2014 07:00	0.9	13.0	1,892.3	0.7	3.80	1	1	1
07/04/2014 08:00	1.0	12.7	1,953.5	0.7	5.90	1	1	1
07/04/2014 09:00	1.2	12.6	1,960.8	0.9	5.90	1	1	1
07/04/2014 10:00	1.2	12.5	1,993.9	0.8	6.00	1	1	1
07/04/2014 11:00	1.6	11.4	2,219.1	1.0	8.90	1	1	1
07/04/2014 12:00	1.3	11.9	2,099.7	0.9	6.30	1	1	1
07/04/2014 13:00	1.0	12.6	1,939.8	0.7	5.80	1	1	1
07/04/2014 14:00	1.1	12.5	1,954.0	0.8	5.90	1	1	1
07/04/2014 15:00	1.0	12.5	1,965.8	0.7	5.90	1	1	1
07/04/2014 16:00	1.1	12.4	1,997.7	0.8	6.00	1	1	1
07/04/2014 17:00	1.1	12.4	1,998.3	0.8	6.00	1	1	1
07/04/2014 18:00	0.6	13.5	1,484.7	0.5	3.00	1	1	1
07/04/2014 19:00	0.5	13.8	1,292.1	0.4	2.60	1	1	0
07/04/2014 20:00	3.5	14.6	973.1	3.3	6.20	1	0	0
07/04/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/04/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	1.2	12.8	1,864.9	0.9	118.50 #	21 #	20 #	19 #
Minimum:	0.5	11.4	973.1	0.4	2.60	0	0	0
Maximum:	3.5	14.6	2,219.1	3.3	8.90	1	1	1
%SI	12.5	12.5	12.5	12.5	12.50	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/05/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/05/2014 10:00	27.3	17.4	454.2	46.0	40.92	1	0	0
07/05/2014 11:00	15.9	14.6	1,176.0	14.9	64.70	1	0	0
07/05/2014 12:00	0.9	12.7	1,934.1	0.6	3.90	1	1	1
07/05/2014 13:00	1.3	12.0	2,089.9	0.9	6.30	1	1	1
07/05/2014 14:00	1.1	12.7	1,937.1	0.8	5.80	1	1	1
07/05/2014 15:00	1.0	12.6	1,931.5	0.7	5.80	1	1	1
07/05/2014 16:00	1.1	12.5	1,958.7	0.8	5.90	1	1	1
07/05/2014 17:00	1.0	12.4	1,985.1	0.7	6.00	1	1	1
07/05/2014 18:00	1.0	12.5	1,941.2	0.7	5.80	1	1	1
07/05/2014 19:00	1.0	12.8	1,885.9	0.7	5.70	1	1	1
07/05/2014 20:00	0.8	12.9	1,879.7	0.6	3.80	1	1	1
07/05/2014 21:00	0.8	13.0	1,879.0	0.6	3.80	1	1	1
07/05/2014 22:00	0.7	13.5	1,547.7	0.6	3.10	1	1	1
07/05/2014 23:00	0.8	13.5	1,768.2	0.6	3.50	1	1	0
Average/Sum#:	3.9	13.2	1,740.6	4.9	165.02 #	14 #	12 #	11 #
Minimum:	0.7	12.0	454.2	0.6	3.10	0	0	0
Maximum:	27.3	17.4	2,089.9	46.0	64.70	1	1	1
%SI	41.7	41.7	41.7	41.7	41.67	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/06/2014 00:00	0.8	13.5	1,777.0	0.6	3.60	1	1	0
07/06/2014 01:00	0.6	13.6	1,498.4	0.5	3.00	1	1	0
07/06/2014 02:00	5.9	15.8	538.4	6.8	3.11	1	0	0
07/06/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/06/2014 09:00	10.0	18.2	334.7	21.9	7.32	1	0	0
07/06/2014 10:00	23.3	15.2	900.2	24.1	80.10	1	0	0
07/06/2014 11:00	0.7	13.2	1,762.7	0.5	3.50	1	1	1
07/06/2014 12:00	1.2	12.8	1,926.6	0.9	5.80	1	1	1
07/06/2014 13:00	1.4	12.9	1,894.7	1.0	7.60	1	1	1
07/06/2014 14:00	1.1	12.9	1,895.9	0.8	5.70	1	1	1
07/06/2014 15:00	1.3	12.9	1,894.5	1.0	7.60	1	1	1
07/06/2014 16:00	1.3	12.7	1,927.7	0.9	5.80	1	1	1
07/06/2014 17:00	1.3	12.1	2,060.6	0.9	6.20	1	1	1
07/06/2014 18:00	1.5	11.7	2,138.7	1.0	8.60	1	1	1
07/06/2014 19:00	1.3	12.1	2,067.9	0.9	6.20	1	1	1
07/06/2014 20:00	1.4	12.0	2,085.3	0.9	6.30	1	1	1
07/06/2014 21:00	1.0	12.8	1,903.2	0.7	5.70	1	1	1
07/06/2014 22:00	0.8	12.9	1,873.1	0.6	3.70	1	1	1
07/06/2014 23:00	0.9	13.0	1,852.8	0.7	3.70	1	1	1
Average/Sum#:	3.1	13.4	1,685.1	3.6	173.53 #	18 #	15 #	13 #
Minimum:	0.6	11.7	334.7	0.5	3.00	0	0	0
Maximum:	23.3	18.2	2,138.7	24.1	80.10	1	1	1
%SI	25.0	25.0	25.0	25.0	25.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/07/2014 00:00	0.5	13.7	1,279.5	0.4	2.60	1	1	0
07/07/2014 01:00	0.6	13.7	1,257.0	0.5	2.50	1	1	0
07/07/2014 02:00	0.7	13.8	1,285.4	0.6	2.60	1	1	0
07/07/2014 03:00	0.7	13.8	1,337.3	0.6	2.70	1	1	0
07/07/2014 04:00	0.8	13.4	1,796.1	0.6	3.60	1	1	1
07/07/2014 05:00	0.9	13.1	1,879.8	0.7	5.60	1	1	1
07/07/2014 06:00	0.9	13.1	1,861.6	0.7	5.60	1	1	1
07/07/2014 07:00	0.9	13.1	1,861.1	0.7	5.60	1	1	1
07/07/2014 08:00	0.9	13.0	1,879.7	0.7	3.80	1	1	1
07/07/2014 09:00	0.9	13.0	1,871.9	0.7	3.70	1	1	1
07/07/2014 10:00	0.9	12.9	1,891.0	0.7	3.80	1	1	1
07/07/2014 11:00	0.9	12.9	1,883.2	0.7	3.80	1	1	1
07/07/2014 12:00	1.1	12.9	1,887.0	0.8	5.70	1	1	1
07/07/2014 13:00	1.0	12.8	1,889.3	0.7	5.70	1	1	1
07/07/2014 14:00	1.1	12.9	1,883.5	0.8	5.70	1	1	1
07/07/2014 15:00	1.0	12.8	1,881.0	0.7	5.60	1	1	1
07/07/2014 16:00	0.9	12.8	1,883.9	0.7	3.80	1	1	1
07/07/2014 17:00	0.9	12.7	1,894.4	0.6	3.80	1	1	1
07/07/2014 18:00	0.9	12.7	1,899.3	0.6	3.80	1	1	1
07/07/2014 19:00	0.9	12.7	1,914.0	0.6	3.80	1	1	1
07/07/2014 20:00	1.0	12.9	1,869.9	0.7	5.60	1	1	1
07/07/2014 21:00	1.0	13.0	1,855.9	0.7	5.60	1	1	1
07/07/2014 22:00	0.8	13.1	1,683.9	0.6	3.40	1	1	1
07/07/2014 23:00	0.8	13.1	1,843.5	0.6	3.70	1	1	1
Average/Sum#:	0.9	13.1	1,769.6	0.7	102.10 #	24 #	24 #	20 #
Minimum:	0.5	12.7	1,257.0	0.4	2.50	1	1	0
Maximum:	1.1	13.8	1,914.0	0.8	5.70	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/08/2014 00:00	0.9	12.9	1,887.5	0.7	3.80	1	1	1
07/08/2014 01:00	0.8	13.0	1,868.4	0.6	3.70	1	1	1
07/08/2014 02:00	0.8	13.0	1,865.2	0.6	3.70	1	1	1
07/08/2014 03:00	0.8	13.2	1,736.0	0.6	3.50	1	1	1
07/08/2014 04:00	1.0	12.7	1,925.6	0.7	5.80	1	1	1
07/08/2014 05:00	1.0	13.0	1,875.0	0.7	5.60	1	1	1
07/08/2014 06:00	1.3	12.6	1,941.7	0.9	5.80	1	1	1
07/08/2014 07:00	0.9	12.9	1,879.4	0.7	3.80	1	1	1
07/08/2014 08:00	0.9	12.8	1,893.6	0.7	3.80	1	1	1
07/08/2014 09:00	0.8	12.9	1,875.1	0.6	3.80	1	1	1
07/08/2014 10:00	1.0	12.6	1,953.2	0.7	5.90	1	1	1
07/08/2014 11:00	0.9	12.5	1,950.7	0.6	3.90	1	1	1
07/08/2014 12:00	0.8	12.0	2,083.8	0.5	4.20	1	1	1
07/08/2014 13:00	1.5	11.3	2,220.9	0.9	6.70	1	1	1
07/08/2014 14:00	1.3	11.5	2,154.8	0.8	6.50	1	1	1
07/08/2014 15:00	1.2	11.5	2,147.4	0.8	6.40	1	1	1
07/08/2014 16:00	1.3	11.5	2,154.2	0.8	6.50	1	1	1
07/08/2014 17:00	1.3	11.6	2,151.6	0.8	6.50	1	1	1
07/08/2014 18:00	1.2	11.9	2,087.2	0.8	6.30	1	1	1
07/08/2014 19:00	1.0	12.3	1,993.3	0.7	6.00	1	1	1
07/08/2014 20:00	0.8	12.8	1,885.5	0.6	3.80	1	1	1
07/08/2014 21:00	1.0	13.0	1,863.9	0.7	5.60	1	1	1
07/08/2014 22:00	0.7	13.5	1,489.9	0.6	3.00	1	1	1
07/08/2014 23:00	0.5	13.7	1,386.8	0.4	2.80	1	1	0
Average/Sum#:	1.0	12.5	1,927.9	0.7	117.40 #	24 #	24 #	23 #
Minimum:	0.5	11.3	1,386.8	0.4	2.80	1	1	0
Maximum:	1.5	13.7	2,220.9	0.9	6.70	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/09/2014 00:00	0.4	13.7	1,250.4	0.3	1.30	1	1	0
07/09/2014 01:00	0.4	13.7	1,248.5	0.3	1.20	1	1	0
07/09/2014 02:00	0.4	13.7	1,248.3	0.3	1.20	1	1	0
07/09/2014 03:00	0.4	13.7	1,248.5	0.3	1.20	1	1	0
07/09/2014 04:00	0.4	13.7	1,258.5	0.3	1.30	1	1	0
07/09/2014 05:00	0.7	13.7	1,543.7	0.6	3.10	1	1	0
07/09/2014 06:00	0.7	13.3	1,644.5	0.5	3.30	1	1	1
07/09/2014 07:00	1.0	12.6	1,972.8	0.7	5.90	1	1	1
07/09/2014 08:00	1.0	12.7	1,951.1	0.7	5.90	1	1	1
07/09/2014 09:00	1.1	12.4	2,010.5	0.8	6.00	1	1	1
07/09/2014 10:00	1.2	11.9	2,108.4	0.8	6.30	1	1	1
07/09/2014 11:00	1.4	11.6	2,171.2	0.9	6.50	1	1	1
07/09/2014 12:00	1.4	11.4	2,186.0	0.9	6.60	1	1	1
07/09/2014 13:00	1.3	11.5	2,159.5	0.8	6.50	1	1	1
07/09/2014 14:00	1.1	12.1	2,026.1	0.7	6.10	1	1	1
07/09/2014 15:00	1.3	11.9	2,097.3	0.9	6.30	1	1	1
07/09/2014 16:00	1.3	11.6	2,138.0	0.8	6.40	1	1	1
07/09/2014 17:00	1.2	11.6	2,135.1	0.8	6.40	1	1	1
07/09/2014 18:00	1.2	12.0	2,041.9	0.8	6.10	1	1	1
07/09/2014 19:00	1.1	12.4	1,970.8	0.8	5.90	1	1	1
07/09/2014 20:00	1.1	12.4	1,984.1	0.8	6.00	1	1	1
07/09/2014 21:00	1.1	12.5	1,956.7	0.8	5.90	1	1	1
07/09/2014 22:00	1.0	12.7	1,936.5	0.7	5.80	1	1	1
07/09/2014 23:00	0.7	13.4	1,457.2	0.6	2.90	1	1	1
Average/Sum#:	1.0	12.6	1,822.7	0.7	114.10 #	24 #	24 #	18 #
Minimum:	0.4	11.4	1,248.3	0.3	1.20	1	1	0
Maximum:	1.4	13.7	2,186.0	0.9	6.60	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/10/2014 00:00	0.5	13.7	1,244.7	0.4	2.50	1	1	0
07/10/2014 01:00	0.5	13.7	1,244.4	0.4	2.50	1	1	0
07/10/2014 02:00	0.5	13.7	1,244.9	0.4	2.50	1	1	0
07/10/2014 03:00	0.5	13.7	1,244.3	0.4	2.50	1	1	0
07/10/2014 04:00	0.5	13.7	1,244.9	0.4	2.50	1	1	0
07/10/2014 05:00	0.5	13.7	1,246.6	0.4	2.50	1	1	0
07/10/2014 06:00	0.6	13.7	1,247.9	0.5	2.50	1	1	0
07/10/2014 07:00	0.5	13.7	1,253.8	0.4	2.50	1	1	0
07/10/2014 08:00	0.7	13.7	1,264.1	0.6	2.50	1	1	0
07/10/2014 09:00	0.8	13.4	1,565.2	0.6	3.10	1	1	1
07/10/2014 10:00	0.8	13.0	1,863.4	0.6	3.70	1	1	1
07/10/2014 11:00	0.8	13.0	1,863.7	0.6	3.70	1	1	1
07/10/2014 12:00	0.9	12.9	1,885.9	0.7	3.80	1	1	1
07/10/2014 13:00	1.0	12.8	1,895.8	0.7	5.70	1	1	1
07/10/2014 14:00	1.0	12.8	1,897.5	0.7	5.70	1	1	1
07/10/2014 15:00	1.0	12.7	1,910.4	0.7	5.70	1	1	1
07/10/2014 16:00	1.0	12.4	1,969.0	0.7	5.90	1	1	1
07/10/2014 17:00	1.1	12.6	1,928.3	0.8	5.80	1	1	1
07/10/2014 18:00	1.3	12.4	1,974.3	0.9	5.90	1	1	1
07/10/2014 19:00	1.0	12.9	1,874.5	0.7	5.60	1	1	1
07/10/2014 20:00	0.9	13.0	1,867.6	0.7	3.70	1	1	1
07/10/2014 21:00	1.0	13.0	1,877.9	0.7	5.60	1	1	1
07/10/2014 22:00	0.9	13.1	1,858.2	0.7	5.60	1	1	1
07/10/2014 23:00	0.8	13.2	1,635.7	0.6	3.30	1	1	1
Average/Sum#:	0.8	13.2	1,629.3	0.6	95.30 #	24 #	24 #	15 #
Minimum:	0.5	12.4	1,244.3	0.4	2.50	1	1	0
Maximum:	1.3	13.7	1,974.3	0.9	5.90	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/11/2014 00:00	6.7	16.5	313.6	9.0	1.75	1	0	0
07/11/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/11/2014 09:00	20.8	16.9	546.6	30.7	51.29	1	0	0
07/11/2014 10:00	19.6	14.8	956.5	19.0	67.00	1	0	0
07/11/2014 11:00	0.6	13.9	1,277.0	0.5	2.60	1	1	0
07/11/2014 12:00	0.8	13.9	1,277.3	0.7	2.60	1	1	0
07/11/2014 13:00	0.9	13.9	1,277.8	0.8	3.80	1	1	0
07/11/2014 14:00	0.9	13.9	1,280.4	0.8	3.80	1	1	0
07/11/2014 15:00	1.0	14.0	1,282.1	0.9	3.80	1	1	0
07/11/2014 16:00	0.9	14.0	1,282.3	0.8	3.80	1	1	0
07/11/2014 17:00	1.0	14.0	1,281.0	0.9	3.80	1	1	0
07/11/2014 18:00	0.9	13.9	1,277.8	0.8	3.80	1	1	0
07/11/2014 19:00	0.9	13.9	1,274.0	0.8	3.80	1	1	0
07/11/2014 20:00	0.9	13.9	1,273.9	0.8	3.80	1	1	0
07/11/2014 21:00	0.9	13.9	1,266.7	0.8	3.80	1	1	0
07/11/2014 22:00	0.8	13.8	1,266.6	0.7	2.50	1	1	0
07/11/2014 23:00	0.8	13.8	1,266.9	0.7	2.50	1	1	0
Average/Sum#:	3.7	14.3	1,150.0	4.3	164.44 #	16 #	13 #	0 #
Minimum:	0.6	13.8	313.6	0.5	1.75	0	0	0
Maximum:	20.8	16.9	1,282.3	30.7	67.00	1	1	0
%SI	33.3	33.3	33.3	33.3	33.33	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/12/2014 00:00	5.1	15.7	600.6	5.8	2.90	1	0	0
07/12/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/12/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/12/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/12/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/12/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/12/2014 06:00	22.1	17.6	446.5	39.5	33.90	1	0	0
07/12/2014 07:00	12.8	14.8	988.3	12.4	45.50	1	0	0
07/12/2014 08:00	0.5	13.9	1,305.0	0.4	2.60	1	1	0
07/12/2014 09:00	0.8	13.9	1,305.2	0.7	2.60	1	1	0
07/12/2014 10:00	1.0	13.8	1,542.5	0.8	4.60	1	1	0
07/12/2014 11:00	0.9	13.8	1,566.0	0.7	4.70	1	1	0
07/12/2014 12:00	0.9	13.9	1,345.2	0.8	4.00	1	1	0
07/12/2014 13:00	0.9	13.8	1,656.4	0.7	5.00	1	1	0
07/12/2014 14:00	1.1	13.3	1,763.9	0.9	5.30	1	1	1
07/12/2014 15:00	1.6	12.0	2,097.4	1.1	8.40	1	1	1
07/12/2014 16:00	1.4	12.7	1,962.9	1.0	7.90	1	1	1
07/12/2014 17:00	1.4	12.6	1,966.4	1.0	7.90	1	1	1
07/12/2014 18:00	1.3	12.6	1,951.0	0.9	5.90	1	1	1
07/12/2014 19:00	1.3	13.0	1,887.0	1.0	7.50	1	1	1
07/12/2014 20:00	1.3	13.0	1,886.3	1.0	7.50	1	1	1
07/12/2014 21:00	1.5	12.6	1,983.6	1.1	7.90	1	1	1
07/12/2014 22:00	1.5	12.4	2,043.9	1.0	8.20	1	1	1
07/12/2014 23:00	1.5	12.6	1,976.7	1.1	7.90	1	1	1
Average/Sum#:	3.1	13.6	1,593.4	3.8	180.20 #	19 #	16 #	10 #
Minimum:	0.5	12.0	446.5	0.4	2.60	0	0	0
Maximum:	22.1	17.6	2,097.4	39.5	45.50	1	1	1
%SI	20.8	20.8	20.8	20.8	20.83	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/13/2014 00:00	1.2	13.3	1,658.0	0.9	5.00	1	1	1
07/13/2014 01:00	4.9	15.7	581.5	5.6	2.67	1	0	0
07/13/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/13/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/13/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/13/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/13/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/13/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/13/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/13/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/13/2014 10:00	20.7	17.8	429.1	39.4	26.12	1	0	0
07/13/2014 11:00	17.1	14.7	1,158.2	16.3	69.50	1	0	1
07/13/2014 12:00	1.1	12.8	1,924.8	0.8	5.80	1	1	1
07/13/2014 13:00	1.6	12.1	2,070.3	1.1	8.30	1	1	1
07/13/2014 14:00	1.7	11.8	2,123.8	1.1	8.50	1	1	1
07/13/2014 15:00	1.8	11.4	2,210.1	1.1	8.80	1	1	1
07/13/2014 16:00	1.5	12.1	2,057.8	1.0	8.20	1	1	1
07/13/2014 17:00	1.5	12.3	2,022.4	1.0	8.10	1	1	1
07/13/2014 18:00	1.5	12.1	2,034.1	1.0	8.10	1	1	1
07/13/2014 19:00	1.3	12.7	1,912.8	0.9	5.70	1	1	1
07/13/2014 20:00	1.0	13.6	1,543.7	0.8	4.60	1	1	1
07/13/2014 21:00	1.1	13.3	1,761.6	0.9	5.30	1	1	1
07/13/2014 22:00	1.3	12.7	1,923.8	0.9	5.80	1	1	1
07/13/2014 23:00	1.0	13.6	1,471.4	0.8	4.40	1	1	1
Average/Sum#:	3.8	13.3	1,680.2	4.6	184.89 #	16 #	13 #	14 #
Minimum:	1.0	11.4	429.1	0.8	2.67	0	0	0
Maximum:	20.7	17.8	2,210.1	39.4	69.50	1	1	1
%SI	33.3	33.3	33.3	33.3	33.33	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/14/2014 00:00	0.9	13.9	1,384.1	0.8	4.20	1	1	0
07/14/2014 01:00	0.9	13.9	1,475.0	0.8	4.40	1	1	0
07/14/2014 02:00	1.0	13.9	1,411.3	0.8	4.20	1	1	0
07/14/2014 03:00	1.1	13.8	1,716.1	0.9	5.10	1	1	0
07/14/2014 04:00	1.0	13.7	1,717.5	0.8	5.20	1	1	0
07/14/2014 05:00	1.0	13.8	1,600.4	0.8	4.80	1	1	1
07/14/2014 06:00	1.5	12.3	1,983.0	1.0	7.90	1	1	1
07/14/2014 07:00	1.4	12.7	1,972.2	1.0	7.90	1	1	1
07/14/2014 08:00	1.3	12.9	1,910.3	1.0	7.60	1	1	1
07/14/2014 09:00	1.4	12.8	1,930.2	1.0	7.70	1	1	1
07/14/2014 10:00	1.4	13.0	1,889.6	1.0	7.60	1	1	1
07/14/2014 11:00	1.3	12.9	1,903.1	1.0	7.60	1	1	1
07/14/2014 12:00	1.2	12.8	1,905.6	0.9	5.70	1	1	1
07/14/2014 13:00	1.3	12.5	1,967.7	0.9	5.90	1	1	1
07/14/2014 14:00	1.6	11.8	2,106.4	1.0	8.40	1	1	1
07/14/2014 15:00	1.4	11.8	2,097.8	0.9	6.30	1	1	1
07/14/2014 16:00	1.4	12.0	2,057.9	0.9	6.20	1	1	1
07/14/2014 17:00	1.4	12.2	2,008.2	0.9	6.00	1	1	1
07/14/2014 18:00	1.0	13.6	1,561.3	0.8	4.70	1	1	1
07/14/2014 19:00	0.9	13.9	1,447.5	0.8	4.30	1	1	0
07/14/2014 20:00	1.1	13.8	1,633.9	0.9	4.90	1	1	0
07/14/2014 21:00	1.0	13.8	1,638.8	0.8	4.90	1	1	0
07/14/2014 22:00	1.0	13.8	1,510.5	0.8	4.50	1	1	0
07/14/2014 23:00	1.2	13.7	1,647.8	1.0	6.60	1	1	0
Average/Sum#:	1.2	13.1	1,769.8	0.9	142.60 #	24 #	24 #	14 #
Minimum:	0.9	11.8	1,384.1	0.8	4.20	1	1	0
Maximum:	1.6	13.9	2,106.4	1.0	8.40	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/15/2014 00:00	1.3	13.6	1,736.5	1.1	6.90	1	1	0
07/15/2014 01:00	1.2	13.6	1,760.4	1.0	7.00	1	1	0
07/15/2014 02:00	1.2	13.7	1,756.3	1.0	7.00	1	1	0
07/15/2014 03:00	1.3	13.4	1,793.7	1.0	7.20	1	1	1
07/15/2014 04:00	1.5	12.9	1,945.8	1.1	7.80	1	1	1
07/15/2014 05:00	1.6	12.7	1,998.8	1.2	8.00	1	1	1
07/15/2014 06:00	1.3	13.2	1,903.1	1.0	7.60	1	1	1
07/15/2014 07:00	1.3	13.3	1,855.1	1.0	7.40	1	1	1
07/15/2014 08:00	1.3	13.3	1,843.9	1.0	7.40	1	1	1
07/15/2014 09:00	1.5	13.2	1,856.9	1.1	7.40	1	1	1
07/15/2014 10:00	1.5	13.0	1,883.9	1.1	7.50	1	1	1
07/15/2014 11:00	1.5	13.0	1,874.1	1.1	7.50	1	1	1
07/15/2014 12:00	1.5	13.1	1,864.5	1.1	7.50	1	1	1
07/15/2014 13:00	1.5	13.1	1,862.9	1.1	7.50	1	1	1
07/15/2014 14:00	1.3	12.8	1,926.9	0.9	5.80	1	1	1
07/15/2014 15:00	1.5	12.7	1,941.1	1.1	7.80	1	1	1
07/15/2014 16:00	1.4	12.9	1,899.7	1.0	7.60	1	1	1
07/15/2014 17:00	1.4	12.8	1,918.5	1.0	7.70	1	1	1
07/15/2014 18:00	1.3	12.8	1,894.4	0.9	5.70	1	1	1
07/15/2014 19:00	1.4	12.8	1,913.9	1.0	7.70	1	1	1
07/15/2014 20:00	1.4	12.8	1,904.2	1.0	7.60	1	1	1
07/15/2014 21:00	1.4	12.8	1,913.9	1.0	7.70	1	1	1
07/15/2014 22:00	1.4	12.9	1,900.7	1.0	7.60	1	1	1
07/15/2014 23:00	1.5	12.8	1,925.3	1.1	7.70	1	1	1
Average/Sum#:	1.4	13.1	1,878.1	1.0	176.60 #	24 #	24 #	21 #
Minimum:	1.2	12.7	1,736.5	0.9	5.70	1	1	0
Maximum:	1.6	13.7	1,998.8	1.2	8.00	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/16/2014 00:00	1.4	12.9	1,891.5	1.0	7.60	1	1	1
07/16/2014 01:00	1.1	13.6	1,473.3	0.9	4.40	1	1	1
07/16/2014 02:00	1.0	13.8	1,427.8	0.8	4.30	1	1	0
07/16/2014 03:00	1.1	13.9	1,472.1	0.9	4.40	1	1	0
07/16/2014 04:00	1.2	13.6	1,738.0	1.0	7.00	1	1	0
07/16/2014 05:00	1.1	13.6	1,606.7	0.9	4.80	1	1	1
07/16/2014 06:00	0.9	13.5	1,711.4	0.7	5.10	1	1	1
07/16/2014 07:00	1.1	13.8	1,588.3	0.9	4.80	1	1	0
07/16/2014 08:00	1.2	13.6	1,688.9	1.0	6.80	1	1	1
07/16/2014 09:00	1.3	13.2	1,839.5	1.0	7.40	1	1	1
07/16/2014 10:00	1.3	13.2	1,839.9	1.0	7.40	1	1	1
07/16/2014 11:00	1.4	13.2	1,836.7	1.1	7.30	1	1	1
07/16/2014 12:00	1.4	13.2	1,833.4	1.1	7.30	1	1	1
07/16/2014 13:00	1.4	13.2	1,835.2	1.1	7.30	1	1	1
07/16/2014 14:00	1.4	13.1	1,838.2	1.1	7.40	1	1	1
07/16/2014 15:00	1.4	13.1	1,840.3	1.1	7.40	1	1	1
07/16/2014 16:00	1.4	13.0	1,866.3	1.0	7.50	1	1	1
07/16/2014 17:00	1.3	12.9	1,879.5	1.0	7.50	1	1	1
07/16/2014 18:00	1.3	12.9	1,881.1	1.0	7.50	1	1	1
07/16/2014 19:00	1.4	13.0	1,866.2	1.0	7.50	1	1	1
07/16/2014 20:00	1.3	13.0	1,858.5	1.0	7.40	1	1	1
07/16/2014 21:00	1.0	13.6	1,582.5	0.8	4.70	1	1	1
07/16/2014 22:00	1.1	13.5	1,692.3	0.9	5.10	1	1	1
07/16/2014 23:00	1.2	13.4	1,675.7	0.9	5.00	1	1	1
Average/Sum#:	1.2	13.3	1,740.1	1.0	152.90 #	24 #	24 #	20 #
Minimum:	0.9	12.9	1,427.8	0.7	4.30	1	1	0
Maximum:	1.4	13.9	1,891.5	1.1	7.60	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report
CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/17/2014 00:00	5.1	15.6	607.0	5.7	2.92	1	0	0
07/17/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/17/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/17/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/17/2014 04:00	8.6	17.4	476.0	14.5	17.64	1	0	0
07/17/2014 05:00	7.8	14.8	1,095.6	7.5	30.70	1	0	0
07/17/2014 06:00	1.2	13.7	1,738.4	1.0	7.00	1	1	0
07/17/2014 07:00	0.9	13.8	1,366.9	0.7	4.10	1	1	0
07/17/2014 08:00	1.3	13.7	1,716.6	1.1	6.90	1	1	0
07/17/2014 09:00	1.0	13.8	1,502.7	0.8	4.50	1	1	0
07/17/2014 10:00	1.1	13.6	1,596.1	0.9	4.80	1	1	1
07/17/2014 11:00	1.3	13.2	1,834.7	1.0	7.30	1	1	1
07/17/2014 12:00	1.4	13.2	1,840.1	1.1	7.40	1	1	1
07/17/2014 13:00	1.4	13.1	1,843.7	1.1	7.40	1	1	1
07/17/2014 14:00	1.4	13.1	1,846.4	1.1	7.40	1	1	1
07/17/2014 15:00	1.3	13.0	1,855.7	1.0	7.40	1	1	1
07/17/2014 16:00	1.3	13.0	1,862.5	1.0	7.50	1	1	1
07/17/2014 17:00	1.3	12.9	1,879.9	1.0	7.50	1	1	1
07/17/2014 18:00	1.4	12.6	1,953.1	1.0	7.80	1	1	1
07/17/2014 19:00	1.4	12.5	1,975.5	1.0	7.90	1	1	1
07/17/2014 20:00	1.3	12.9	1,883.3	1.0	7.50	1	1	1
07/17/2014 21:00	1.4	12.8	1,920.4	1.0	7.70	1	1	1
07/17/2014 22:00	1.2	13.5	1,645.9	1.0	6.60	1	1	1
07/17/2014 23:00	1.0	13.8	1,410.0	0.8	4.20	1	1	0
Average/Sum#:	2.1	13.6	1,611.9	2.2	172.16 #	21 #	18 #	13 #
Minimum:	0.9	12.5	476.0	0.7	2.92	0	0	0
Maximum:	8.6	17.4	1,975.5	14.5	30.70	1	1	1
%SI	12.5	12.5	12.5	12.5	12.50	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/18/2014 00:00	5.1	15.6	613.4	5.7	2.97	1	0	0
07/18/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/18/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/18/2014 03:00	3.9	16.4	625.7	5.1	8.33	1	0	0
07/18/2014 04:00	2.7	13.8	1,339.7	2.2	10.70	1	0	0
07/18/2014 05:00	1.1	13.8	1,514.5	0.9	4.50	1	1	0
07/18/2014 06:00	1.0	13.8	1,454.6	0.8	4.40	1	1	0
07/18/2014 07:00	1.1	13.7	1,601.6	0.9	4.80	1	1	0
07/18/2014 08:00	1.1	13.8	1,625.0	0.9	4.90	1	1	0
07/18/2014 09:00	1.1	13.6	1,564.1	0.9	4.70	1	1	1
07/18/2014 10:00	1.4	13.2	1,857.5	1.1	7.40	1	1	1
07/18/2014 11:00	1.3	13.2	1,848.2	1.0	7.40	1	1	1
07/18/2014 12:00	1.3	13.2	1,837.2	1.0	7.30	1	1	1
07/18/2014 13:00	1.4	13.2	1,841.4	1.1	7.40	1	1	1
07/18/2014 14:00	1.5	13.1	1,844.9	1.1	7.40	1	1	1
07/18/2014 15:00	1.5	13.0	1,877.3	1.1	7.50	1	1	1
07/18/2014 16:00	1.5	12.9	1,906.0	1.1	7.60	1	1	1
07/18/2014 17:00	1.7	11.8	2,125.2	1.1	8.50	1	1	1
07/18/2014 18:00	1.7	11.7	2,150.0	1.1	8.60	1	1	1
07/18/2014 19:00	1.6	12.0	2,093.4	1.1	8.40	1	1	1
07/18/2014 20:00	1.5	12.4	1,997.8	1.0	8.00	1	1	1
07/18/2014 21:00	1.4	13.0	1,866.2	1.0	7.50	1	1	1
07/18/2014 22:00	1.1	13.4	1,599.4	0.9	4.80	1	1	1
07/18/2014 23:00	1.1	13.8	1,302.4	0.9	3.90	1	1	0
Average/Sum#:	1.7	13.4	1,658.4	1.5	147.00 #	22 #	19 #	14 #
Minimum:	1.0	11.7	613.4	0.8	2.97	0	0	0
Maximum:	5.1	16.4	2,150.0	5.7	10.70	1	1	1
%SI	8.3	8.3	8.3	8.3	8.33	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/19/2014 00:00	4.7	15.1	853.5	4.8	5.08	1	0	0
07/19/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/19/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/19/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/19/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/19/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/19/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/19/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/19/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/19/2014 09:00	19.4	17.8	403.7	36.9	20.31	1	0	0
07/19/2014 10:00	19.5	14.6	1,198.1	18.3	80.30	1	0	0
07/19/2014 11:00	1.5	12.3	2,067.5	1.0	8.30	1	1	1
07/19/2014 12:00	1.6	11.7	2,155.7	1.0	8.60	1	1	1
07/19/2014 13:00	1.7	11.4	2,222.5	1.1	8.90	1	1	1
07/19/2014 14:00	1.7	11.5	2,192.9	1.1	8.80	1	1	1
07/19/2014 15:00	1.7	11.5	2,182.0	1.1	8.70	1	1	1
07/19/2014 16:00	1.7	11.6	2,142.9	1.1	8.60	1	1	1
07/19/2014 17:00	1.7	11.7	2,132.8	1.1	8.50	1	1	1
07/19/2014 18:00	1.5	12.4	1,987.0	1.0	7.90	1	1	1
07/19/2014 19:00	1.5	12.0	2,078.2	1.0	8.30	1	1	1
07/19/2014 20:00	1.6	11.7	2,148.8	1.0	8.60	1	1	1
07/19/2014 21:00	1.6	12.3	2,024.7	1.1	8.10	1	1	1
07/19/2014 22:00	1.1	13.7	1,533.4	0.9	4.60	1	1	1
07/19/2014 23:00	1.1	13.8	1,502.5	0.9	4.50	1	1	0
Average/Sum#:	4.0	12.8	1,801.6	4.6	208.09 #	16 #	13 #	12 #
Minimum:	1.1	11.4	403.7	0.9	4.50	0	0	0
Maximum:	19.5	17.8	2,222.5	36.9	80.30	1	1	1
%SI	33.3	33.3	33.3	33.3	33.33	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/20/2014 00:00	4.6	15.6	602.0	5.1	2.62	1	0	0
07/20/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/20/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	4.6	15.6	602.0	5.1	2.62 #	1 #	0 #	0 #
Minimum:	4.6	15.6	602.0	5.1	2.62	0	0	0
Maximum:	4.6	15.6	602.0	5.1	2.62	1	0	0
%SI	95.8	95.8	95.8	95.8	95.83	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/21/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
07/21/2014 01:00	31.3	17.4	477.1	52.8	64.82	1	0	0
07/21/2014 02:00	10.9	16.7	580.1	15.3	32.50	1	0	0
07/21/2014 03:00	10.9	14.5	1,129.3	10.0	41.80	1	0	0
07/21/2014 04:00	1.1	13.8	1,619.8	0.9	4.90	1	1	0
07/21/2014 05:00	1.1	13.8	1,663.0	0.9	5.00	1	1	0
07/21/2014 06:00	1.1	13.9	1,643.8	0.9	4.90	1	1	0
07/21/2014 07:00	1.1	13.8	1,638.0	0.9	4.90	1	1	0
07/21/2014 08:00	1.4	13.0	1,914.6	1.0	7.70	1	1	1
07/21/2014 09:00	1.5	12.7	1,973.3	1.1	7.90	1	1	1
07/21/2014 10:00	1.5	12.7	1,974.9	1.1	7.90	1	1	1
07/21/2014 11:00	1.5	12.7	1,961.3	1.1	7.80	1	1	1
07/21/2014 12:00	1.5	12.8	1,948.6	1.1	7.80	1	1	1
07/21/2014 13:00	1.5	12.8	1,928.3	1.1	7.70	1	1	1
07/21/2014 14:00	1.4	12.7	1,937.5	1.0	7.80	1	1	1
07/21/2014 15:00	1.5	12.4	2,007.4	1.0	8.00	1	1	1
07/21/2014 16:00	1.5	12.4	2,012.0	1.0	8.00	1	1	1
07/21/2014 17:00	1.7	11.6	2,185.9	1.1	8.70	1	1	1
07/21/2014 18:00	1.8	11.2	2,253.2	1.1	9.00	1	1	1
07/21/2014 19:00	1.8	11.2	2,257.7	1.1	9.00	1	1	1
07/21/2014 20:00	1.7	11.3	2,259.8	1.0	9.00	1	1	1
07/21/2014 21:00	1.7	11.7	2,167.9	1.1	8.70	1	1	1
07/21/2014 22:00	1.5	12.4	2,026.8	1.0	8.10	1	1	1
07/21/2014 23:00	1.5	12.7	1,958.4	1.1	7.80	1	1	1
Average/Sum#:	3.6	13.1	1,805.2	4.3	289.72 #	23 #	20 #	16 #
Minimum:	1.1	11.2	477.1	0.9	4.90	0	0	0
Maximum:	31.3	17.4	2,259.8	52.8	64.82	1	1	1
%SI	4.2	4.2	4.2	4.2	4.17	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/22/2014 00:00	1.3	13.2	1,856.2	1.0	7.40	1	1	1
07/22/2014 01:00	1.4	13.2	1,872.5	1.1	7.50	1	1	1
07/22/2014 02:00	1.4	13.2	1,867.9	1.1	7.50	1	1	1
07/22/2014 03:00	1.5	13.2	1,857.4	1.1	7.40	1	1	1
07/22/2014 04:00	1.5	13.0	1,928.6	1.1	7.70	1	1	1
07/22/2014 05:00	1.5	13.2	1,885.8	1.1	7.50	1	1	1
07/22/2014 06:00	1.4	13.2	1,869.2	1.1	7.50	1	1	1
07/22/2014 07:00	1.5	12.9	1,950.3	1.1	7.80	1	1	1
07/22/2014 08:00	1.4	13.2	1,871.1	1.1	7.50	1	1	1
07/22/2014 09:00	1.3	13.2	1,858.2	1.0	7.40	1	1	1
07/22/2014 10:00	1.3	13.1	1,851.6	1.0	7.40	1	1	1
07/22/2014 11:00	1.5	12.7	1,953.3	1.1	7.80	1	1	1
07/22/2014 12:00	1.5	12.3	2,028.4	1.0	8.10	1	1	1
07/22/2014 13:00	1.5	12.5	1,987.3	1.1	7.90	1	1	1
07/22/2014 14:00	1.5	12.3	2,020.1	1.0	8.10	1	1	1
07/22/2014 15:00	1.7	11.7	2,153.5	1.1	8.60	1	1	1
07/22/2014 16:00	1.6	12.0	2,095.4	1.1	8.40	1	1	1
07/22/2014 17:00	1.5	12.2	2,045.9	1.0	8.20	1	1	1
07/22/2014 18:00	1.7	11.8	2,147.4	1.1	8.60	1	1	1
07/22/2014 19:00	1.6	12.1	2,102.5	1.1	8.40	1	1	1
07/22/2014 20:00	1.6	12.2	2,079.2	1.1	8.30	1	1	1
07/22/2014 21:00	1.6	12.3	2,078.9	1.1	8.30	1	1	1
07/22/2014 22:00	1.5	12.7	1,982.9	1.1	7.90	1	1	1
07/22/2014 23:00	1.2	13.6	1,542.3	1.0	6.20	1	1	1
Average/Sum#:	1.5	12.7	1,953.6	1.1	187.40 #	24 #	24 #	24 #
Minimum:	1.2	11.7	1,542.3	1.0	6.20	1	1	1
Maximum:	1.7	13.6	2,153.5	1.1	8.60	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/23/2014 00:00	1.0	13.8	1,286.2	0.8	3.90	1	1	0
07/23/2014 01:00	1.0	13.8	1,270.5	0.8	3.80	1	1	0
07/23/2014 02:00	0.9	13.8	1,252.7	0.7	3.80	1	1	0
07/23/2014 03:00	0.9	13.8	1,252.5	0.7	3.80	1	1	0
07/23/2014 04:00	1.0	13.8	1,272.5	0.8	3.80	1	1	0
07/23/2014 05:00	1.1	13.8	1,538.2	0.9	4.60	1	1	1
07/23/2014 06:00	1.4	13.1	1,932.8	1.1	7.70	1	1	1
07/23/2014 07:00	1.4	13.0	1,932.5	1.0	7.70	1	1	1
07/23/2014 08:00	1.4	13.1	1,908.1	1.1	7.60	1	1	1
07/23/2014 09:00	1.4	13.1	1,898.3	1.1	7.60	1	1	1
07/23/2014 10:00	1.4	13.2	1,875.5	1.1	7.50	1	1	1
07/23/2014 11:00	1.4	13.2	1,876.9	1.1	7.50	1	1	1
07/23/2014 12:00	1.4	13.2	1,876.6	1.1	7.50	1	1	1
07/23/2014 13:00	1.3	13.2	1,868.6	1.0	7.50	1	1	1
07/23/2014 14:00	1.4	13.0	1,909.4	1.0	7.60	1	1	1
07/23/2014 15:00	1.6	12.4	2,022.0	1.1	8.10	1	1	1
07/23/2014 16:00	1.7	12.0	2,105.5	1.1	8.40	1	1	1
07/23/2014 17:00	1.4	12.5	1,985.5	1.0	7.90	1	1	1
07/23/2014 18:00	1.5	12.3	2,039.1	1.0	8.20	1	1	1
07/23/2014 19:00	1.5	12.4	2,017.0	1.0	8.10	1	1	1
07/23/2014 20:00	1.5	12.7	1,970.8	1.1	7.90	1	1	1
07/23/2014 21:00	1.5	12.8	1,937.7	1.1	7.80	1	1	1
07/23/2014 22:00	1.3	13.1	1,877.3	1.0	7.50	1	1	1
07/23/2014 23:00	1.4	12.9	1,921.5	1.0	7.70	1	1	1
Average/Sum#:	1.3	13.1	1,784.5	1.0	163.50 #	24 #	24 #	19 #
Minimum:	0.9	12.0	1,252.5	0.7	3.80	1	1	0
Maximum:	1.7	13.8	2,105.5	1.1	8.40	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/24/2014 00:00	1.3	13.1	1,884.0	1.0	7.50	1	1	1
07/24/2014 01:00	1.4	13.2	1,888.7	1.1	7.60	1	1	1
07/24/2014 02:00	1.1	13.7	1,487.4	0.9	4.50	1	1	1
07/24/2014 03:00	1.0	13.9	1,257.5	0.8	3.80	1	1	0
07/24/2014 04:00	1.0	13.9	1,253.3	0.8	3.80	1	1	0
07/24/2014 05:00	1.1	13.9	1,257.7	0.9	3.80	1	1	0
07/24/2014 06:00	1.1	13.9	1,260.3	0.9	3.80	1	1	0
07/24/2014 07:00	1.2	13.9	1,265.1	1.0	5.10	1	1	0
07/24/2014 08:00	1.3	13.8	1,569.3	1.1	6.30	1	1	0
07/24/2014 09:00	1.4	13.1	1,908.3	1.1	7.60	1	1	1
07/24/2014 10:00	1.5	12.9	1,939.4	1.1	7.80	1	1	1
07/24/2014 11:00	1.5	12.8	1,971.7	1.1	7.90	1	1	1
07/24/2014 12:00	1.6	12.1	2,121.1	1.1	8.50	1	1	1
07/24/2014 13:00	1.7	11.3	2,284.2	1.0	9.10	1	1	1
07/24/2014 14:00	1.7	11.5	2,237.2	1.1	8.90	1	1	1
07/24/2014 15:00	1.7	12.0	2,123.0	1.1	8.50	1	1	1
07/24/2014 16:00	1.7	11.9	2,128.6	1.1	8.50	1	1	1
07/24/2014 17:00	1.7	12.0	2,125.8	1.1	8.50	1	1	1
07/24/2014 18:00	1.6	12.0	2,116.9	1.1	8.50	1	1	1
07/24/2014 19:00	1.6	12.1	2,089.5	1.1	8.40	1	1	1
07/24/2014 20:00	1.6	12.3	2,054.3	1.1	8.20	1	1	1
07/24/2014 21:00	1.3	13.3	1,751.3	1.0	7.00	1	1	1
07/24/2014 22:00	1.4	13.0	1,919.0	1.0	7.70	1	1	1
07/24/2014 23:00	1.6	12.3	2,070.7	1.1	8.30	1	1	1
Average/Sum#:	1.4	12.8	1,831.8	1.0	169.60 #	24 #	24 #	18 #
Minimum:	1.0	11.3	1,253.3	0.8	3.80	1	1	0
Maximum:	1.7	13.9	2,284.2	1.1	9.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/25/2014 00:00	1.4	13.0	1,916.3	1.0	7.70	1	1	1
07/25/2014 01:00	1.2	13.3	1,873.0	0.9	5.60	1	1	1
07/25/2014 02:00	1.4	13.3	1,871.4	1.1	7.50	1	1	1
07/25/2014 03:00	1.3	13.3	1,868.8	1.0	7.50	1	1	1
07/25/2014 04:00	1.4	13.1	1,912.8	1.1	7.70	1	1	1
07/25/2014 05:00	1.5	13.1	1,933.8	1.1	7.70	1	1	1
07/25/2014 06:00	1.4	13.0	1,932.0	1.0	7.70	1	1	1
07/25/2014 07:00	1.5	12.9	1,939.4	1.1	7.80	1	1	1
07/25/2014 08:00	1.5	13.1	1,898.4	1.1	7.60	1	1	1
07/25/2014 09:00	1.5	12.9	1,937.2	1.1	7.70	1	1	1
07/25/2014 10:00	1.6	12.2	2,091.2	1.1	8.40	1	1	1
07/25/2014 11:00	1.7	11.7	2,184.8	1.1	8.70	1	1	1
07/25/2014 12:00	1.7	11.9	2,146.8	1.1	8.60	1	1	1
07/25/2014 13:00	1.6	12.3	2,032.5	1.1	8.10	1	1	1
07/25/2014 14:00	1.6	12.1	2,086.4	1.1	8.30	1	1	1
07/25/2014 15:00	1.7	11.7	2,173.3	1.1	8.70	1	1	1
07/25/2014 16:00	1.7	11.8	2,152.0	1.1	8.60	1	1	1
07/25/2014 17:00	1.7	11.7	2,179.7	1.1	8.70	1	1	1
07/25/2014 18:00	1.7	11.7	2,171.9	1.1	8.70	1	1	1
07/25/2014 19:00	1.7	11.5	2,205.3	1.1	8.80	1	1	1
07/25/2014 20:00	1.7	11.9	2,124.0	1.1	8.50	1	1	1
07/25/2014 21:00	1.6	12.3	2,053.2	1.1	8.20	1	1	1
07/25/2014 22:00	1.6	12.4	2,038.9	1.1	8.20	1	1	1
07/25/2014 23:00	1.5	12.9	1,934.4	1.1	7.70	1	1	1
Average/Sum#:	1.6	12.5	2,027.4	1.1	192.70 #	24 #	24 #	24 #
Minimum:	1.2	11.5	1,868.8	0.9	5.60	1	1	1
Maximum:	1.7	13.3	2,205.3	1.1	8.80	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/26/2014 00:00	1.4	13.1	1,887.7	1.1	7.60	1	1	1
07/26/2014 01:00	1.4	13.2	1,867.2	1.1	7.50	1	1	1
07/26/2014 02:00	1.4	13.3	1,865.0	1.1	7.50	1	1	1
07/26/2014 03:00	1.4	13.3	1,862.0	1.1	7.40	1	1	1
07/26/2014 04:00	1.4	13.1	1,903.7	1.1	7.60	1	1	1
07/26/2014 05:00	1.4	13.3	1,860.8	1.1	7.40	1	1	1
07/26/2014 06:00	1.3	13.3	1,854.1	1.0	7.40	1	1	1
07/26/2014 07:00	1.4	13.2	1,872.2	1.1	7.50	1	1	1
07/26/2014 08:00	1.4	13.1	1,872.7	1.1	7.50	1	1	1
07/26/2014 09:00	1.3	13.1	1,861.1	1.0	7.40	1	1	1
07/26/2014 10:00	1.3	13.1	1,872.1	1.0	7.50	1	1	1
07/26/2014 11:00	1.5	12.5	2,000.6	1.1	8.00	1	1	1
07/26/2014 12:00	1.7	11.7	2,155.3	1.1	8.60	1	1	1
07/26/2014 13:00	1.7	11.7	2,156.1	1.1	8.60	1	1	1
07/26/2014 14:00	1.6	12.1	2,058.3	1.1	8.20	1	1	1
07/26/2014 15:00	1.2	13.4	1,675.7	0.9	5.00	1	1	1
07/26/2014 16:00	1.2	13.4	1,642.0	0.9	4.90	1	1	1
07/26/2014 17:00	1.4	12.6	1,960.2	1.0	7.80	1	1	1
07/26/2014 18:00	1.3	13.0	1,839.6	1.0	7.40	1	1	1
07/26/2014 19:00	1.1	13.9	1,265.7	0.9	3.80	1	1	0
07/26/2014 20:00	1.2	14.0	1,253.1	1.0	5.00	1	1	0
07/26/2014 21:00	1.2	14.0	1,252.3	1.0	5.00	1	1	0
07/26/2014 22:00	1.2	13.9	1,250.5	1.0	5.00	1	1	0
07/26/2014 23:00	1.2	13.9	1,410.0	1.0	5.60	1	1	0
Average/Sum#:	1.4	13.1	1,770.8	1.0	165.20 #	24 #	24 #	19 #
Minimum:	1.1	11.7	1,250.5	0.9	3.80	1	1	0
Maximum:	1.7	14.0	2,156.1	1.1	8.60	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/27/2014 00:00	1.1	13.8	1,503.4	0.9	4.50	1	1	0
07/27/2014 01:00	1.1	13.9	1,355.8	0.9	4.10	1	1	0
07/27/2014 02:00	1.1	13.8	1,382.1	0.9	4.10	1	1	0
07/27/2014 03:00	1.0	13.9	1,277.6	0.8	3.80	1	1	0
07/27/2014 04:00	1.1	13.9	1,334.2	0.9	4.00	1	1	0
07/27/2014 05:00	1.1	13.9	1,287.6	0.9	3.90	1	1	0
07/27/2014 06:00	1.3	13.5	1,532.8	1.0	6.10	1	1	1
07/27/2014 07:00	1.4	13.0	1,914.7	1.0	7.70	1	1	1
07/27/2014 08:00	1.3	13.3	1,782.0	1.0	7.10	1	1	1
07/27/2014 09:00	1.4	13.0	1,890.8	1.0	7.60	1	1	1
07/27/2014 10:00	1.5	12.9	1,916.2	1.1	7.70	1	1	1
07/27/2014 11:00	1.6	12.2	2,071.2	1.1	8.30	1	1	1
07/27/2014 12:00	1.4	12.4	2,014.8	1.0	8.10	1	1	1
07/27/2014 13:00	1.5	12.5	1,991.2	1.1	8.00	1	1	1
07/27/2014 14:00	1.5	12.8	1,934.3	1.1	7.70	1	1	1
07/27/2014 15:00	1.6	12.0	2,118.5	1.1	8.50	1	1	1
07/27/2014 16:00	1.7	11.8	2,147.1	1.1	8.60	1	1	1
07/27/2014 17:00	1.7	11.7	2,149.3	1.1	8.60	1	1	1
07/27/2014 18:00	1.7	11.7	2,148.2	1.1	8.60	1	1	1
07/27/2014 19:00	1.7	11.9	2,091.5	1.1	8.40	1	1	1
07/27/2014 20:00	1.4	13.0	1,849.4	1.0	7.40	1	1	1
07/27/2014 21:00	1.3	13.3	1,690.9	1.0	6.80	1	1	1
07/27/2014 22:00	1.2	13.4	1,672.6	0.9	5.00	1	1	1
07/27/2014 23:00	1.3	13.0	1,870.2	1.0	7.50	1	1	1
Average/Sum#:	1.4	12.9	1,788.6	1.0	162.10 #	24 #	24 #	18 #
Minimum:	1.0	11.7	1,277.6	0.8	3.80	1	1	0
Maximum:	1.7	13.9	2,149.3	1.1	8.60	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/28/2014 00:00	1.4	13.1	1,874.1	1.1	7.50	1	1	1
07/28/2014 01:00	1.5	12.8	1,935.7	1.1	7.70	1	1	1
07/28/2014 02:00	1.3	13.2	1,762.8	1.0	7.10	1	1	1
07/28/2014 03:00	1.0	13.8	1,283.8	0.8	3.90	1	1	0
07/28/2014 04:00	1.2	13.5	1,606.5	1.0	6.40	1	1	1
07/28/2014 05:00	1.4	13.2	1,856.5	1.1	7.40	1	1	1
07/28/2014 06:00	1.3	13.2	1,854.2	1.0	7.40	1	1	1
07/28/2014 07:00	1.4	13.2	1,852.3	1.1	7.40	1	1	1
07/28/2014 08:00	1.3	13.2	1,851.6	1.0	7.40	1	1	1
07/28/2014 09:00	1.3	13.1	1,871.5	1.0	7.50	1	1	1
07/28/2014 10:00	1.7	12.0	2,115.2	1.1	8.50	1	1	1
07/28/2014 11:00	1.7	11.4	2,220.1	1.1	8.90	1	1	1
07/28/2014 12:00	1.7	11.7	2,144.9	1.1	8.60	1	1	1
07/28/2014 13:00	1.7	11.5	2,168.3	1.1	8.70	1	1	1
07/28/2014 14:00	1.7	11.7	2,148.3	1.1	8.60	1	1	1
07/28/2014 15:00	1.7	11.7	2,147.9	1.1	8.60	1	1	1
07/28/2014 16:00	1.6	11.7	2,130.6	1.0	8.50	1	1	1
07/28/2014 17:00	1.7	11.7	2,133.6	1.1	8.50	1	1	1
07/28/2014 18:00	1.4	12.5	1,980.1	1.0	7.90	1	1	1
07/28/2014 19:00	1.5	12.4	2,002.6	1.0	8.00	1	1	1
07/28/2014 20:00	1.5	12.6	1,974.6	1.1	7.90	1	1	1
07/28/2014 21:00	1.4	12.9	1,910.3	1.0	7.60	1	1	1
07/28/2014 22:00	1.4	12.8	1,943.9	1.0	7.80	1	1	1
07/28/2014 23:00	1.3	13.2	1,861.6	1.0	7.40	1	1	1
Average/Sum#:	1.5	12.6	1,943.0	1.0	185.20 #	24 #	24 #	23 #
Minimum:	1.0	11.4	1,283.8	0.8	3.90	1	1	0
Maximum:	1.7	13.8	2,220.1	1.1	8.90	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/29/2014 00:00	1.5	12.8	1,954.7	1.1	7.80	1	1	1
07/29/2014 01:00	1.0	13.8	1,449.0	0.8	4.30	1	1	1
07/29/2014 02:00	1.0	13.9	1,257.6	0.8	3.80	1	1	0
07/29/2014 03:00	0.9	13.9	1,236.1	0.8	3.70	1	1	0
07/29/2014 04:00	1.0	13.8	1,373.7	0.8	4.10	1	1	1
07/29/2014 05:00	1.3	13.3	1,858.5	1.0	7.40	1	1	1
07/29/2014 06:00	1.5	12.9	1,941.3	1.1	7.80	1	1	1
07/29/2014 07:00	1.7	12.1	2,108.7	1.1	8.40	1	1	1
07/29/2014 08:00	1.6	12.3	2,060.8	1.1	8.20	1	1	1
07/29/2014 09:00	1.6	12.6	1,994.8	1.1	8.00	1	1	1
07/29/2014 10:00	1.7	11.7	2,175.2	1.1	8.70	1	1	1
07/29/2014 11:00	1.6	12.4	2,021.2	1.1	8.10	1	1	1
07/29/2014 12:00	1.7	11.9	2,136.0	1.1	8.50	1	1	1
07/29/2014 13:00	1.7	11.5	2,216.7	1.1	8.90	1	1	1
07/29/2014 14:00	1.7	11.5	2,212.1	1.1	8.80	1	1	1
07/29/2014 15:00	1.7	11.5	2,178.5	1.1	8.70	1	1	1
07/29/2014 16:00	1.6	12.0	2,076.2	1.1	8.30	1	1	1
07/29/2014 17:00	1.5	12.3	2,005.7	1.0	8.00	1	1	1
07/29/2014 18:00	1.5	12.3	1,997.9	1.0	8.00	1	1	1
07/29/2014 19:00	1.4	12.6	1,918.3	1.0	7.70	1	1	1
07/29/2014 20:00	1.4	13.1	1,850.7	1.1	7.40	1	1	1
07/29/2014 21:00	1.5	12.8	1,904.3	1.1	7.60	1	1	1
07/29/2014 22:00	1.3	13.2	1,836.5	1.0	7.30	1	1	1
07/29/2014 23:00	1.3	13.2	1,840.3	1.0	7.40	1	1	1
Average/Sum#:	1.4	12.6	1,900.2	1.0	176.90 #	24 #	24 #	22 #
Minimum:	0.9	11.5	1,236.1	0.8	3.70	1	1	0
Maximum:	1.7	13.9	2,216.7	1.1	8.90	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/30/2014 00:00	1.5	13.2	1,827.8	1.1	7.30	1	1	1
07/30/2014 01:00	1.5	13.1	1,867.7	1.1	7.50	1	1	1
07/30/2014 02:00	1.1	13.7	1,404.7	0.9	4.20	1	1	1
07/30/2014 03:00	1.2	13.6	1,539.7	1.0	6.20	1	1	1
07/30/2014 04:00	1.4	13.2	1,865.3	1.1	7.50	1	1	1
07/30/2014 05:00	1.4	13.2	1,867.2	1.1	7.50	1	1	1
07/30/2014 06:00	1.4	13.2	1,856.3	1.1	7.40	1	1	1
07/30/2014 07:00	1.3	13.1	1,852.8	1.0	7.40	1	1	1
07/30/2014 08:00	1.3	13.2	1,855.6	1.0	7.40	1	1	1
07/30/2014 09:00	1.2	13.1	1,857.8	0.9	5.60	1	1	1
07/30/2014 10:00	1.2	13.1	1,862.2	0.9	5.60	1	1	1
07/30/2014 11:00	1.5	12.5	1,998.0	1.1	8.00	1	1	1
07/30/2014 12:00	1.7	11.5	2,195.1	1.1	8.80	1	1	1
07/30/2014 13:00	1.7	11.5	2,208.4	1.1	8.80	1	1	1
07/30/2014 14:00	1.7	11.5	2,189.5	1.1	8.80	1	1	1
07/30/2014 15:00	1.8	11.5	2,169.6	1.1	8.70	1	1	1
07/30/2014 16:00	1.8	11.5	2,170.8	1.1	8.70	1	1	1
07/30/2014 17:00	1.7	11.5	2,164.0	1.1	8.70	1	1	1
07/30/2014 18:00	1.7	11.6	2,162.0	1.1	8.60	1	1	1
07/30/2014 19:00	1.7	11.8	2,117.6	1.1	8.50	1	1	1
07/30/2014 20:00	1.5	12.3	2,005.1	1.0	8.00	1	1	1
07/30/2014 21:00	1.7	11.8	2,143.7	1.1	8.60	1	1	1
07/30/2014 22:00	1.6	12.0	2,097.3	1.1	8.40	1	1	1
07/30/2014 23:00	1.6	12.2	2,049.1	1.1	8.20	1	1	1
Average/Sum#:	1.5	12.5	1,972.0	1.1	184.40 #	24 #	24 #	24 #
Minimum:	1.1	11.5	1,404.7	0.9	4.20	1	1	1
Maximum:	1.8	13.7	2,208.4	1.1	8.80	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
07/31/2014 00:00	1.3	13.4	1,697.7	1.0	6.80	1	1	1
07/31/2014 01:00	1.2	13.7	1,706.5	1.0	6.80	1	1	0
07/31/2014 02:00	1.2	13.3	1,762.8	0.9	5.30	1	1	1
07/31/2014 03:00	1.4	13.0	1,893.5	1.0	7.60	1	1	1
07/31/2014 04:00	1.4	13.1	1,866.6	1.1	7.50	1	1	1
07/31/2014 05:00	1.4	13.2	1,862.6	1.1	7.50	1	1	1
07/31/2014 06:00	1.2	13.1	1,860.8	0.9	5.60	1	1	1
07/31/2014 07:00	1.3	13.1	1,861.0	1.0	7.40	1	1	1
07/31/2014 08:00	1.3	13.0	1,865.3	1.0	7.50	1	1	1
07/31/2014 09:00	1.4	12.7	1,939.6	1.0	7.80	1	1	1
07/31/2014 10:00	1.8	11.5	2,176.9	1.1	8.70	1	1	1
07/31/2014 11:00	1.8	11.4	2,205.1	1.1	8.80	1	1	1
07/31/2014 12:00	1.7	11.5	2,178.3	1.1	8.70	1	1	1
07/31/2014 13:00	1.4	12.7	1,909.2	1.0	7.60	1	1	1
07/31/2014 14:00	1.5	12.6	1,942.2	1.1	7.80	1	1	1
07/31/2014 15:00	1.5	12.2	2,027.8	1.0	8.10	1	1	1
07/31/2014 16:00	1.5	12.1	2,037.9	1.0	8.20	1	1	1
07/31/2014 17:00	1.5	12.0	2,032.7	1.0	8.10	1	1	1
07/31/2014 18:00	1.5	12.1	2,028.8	1.0	8.10	1	1	1
07/31/2014 19:00	1.5	12.1	2,018.2	1.0	8.10	1	1	1
07/31/2014 20:00	1.5	12.3	1,999.5	1.0	8.00	1	1	1
07/31/2014 21:00	1.5	12.4	1,982.5	1.0	7.90	1	1	1
07/31/2014 22:00	1.4	12.7	1,912.5	1.0	7.70	1	1	1
07/31/2014 23:00	1.4	12.8	1,909.1	1.0	7.60	1	1	1
Average/Sum#:	1.4	12.6	1,944.9	1.0	183.20 #	24 #	24 #	23 #
Minimum:	1.2	11.4	1,697.7	0.9	5.30	1	1	0
Maximum:	1.8	13.7	2,205.1	1.1	8.80	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/01/2014 00:00	1.4	12.8	1,910.6	1.0	7.60	1	1	1
08/01/2014 01:00	1.2	13.6	1,585.6	1.0	6.30	1	1	1
08/01/2014 02:00	1.2	13.6	1,593.2	1.0	6.40	1	1	1
08/01/2014 03:00	1.4	12.9	1,910.5	1.0	7.60	1	1	1
08/01/2014 04:00	1.4	13.1	1,874.3	1.1	7.50	1	1	1
08/01/2014 05:00	1.4	13.0	1,919.3	1.0	7.70	1	1	1
08/01/2014 06:00	1.2	13.2	1,854.0	0.9	5.60	1	1	1
08/01/2014 07:00	1.3	13.2	1,851.7	1.0	7.40	1	1	1
08/01/2014 08:00	1.5	12.8	1,917.7	1.1	7.70	1	1	1
08/01/2014 09:00	1.6	12.3	2,037.3	1.1	8.10	1	1	1
08/01/2014 10:00	1.7	11.8	2,135.6	1.1	8.50	1	1	1
08/01/2014 11:00	1.7	11.4	2,192.5	1.1	8.80	1	1	1
08/01/2014 12:00	1.7	11.5	2,162.4	1.1	8.60	1	1	1
08/01/2014 13:00	1.7	11.5	2,156.8	1.1	8.60	1	1	1
08/01/2014 14:00	1.8	11.5	2,158.6	1.1	8.60	1	1	1
08/01/2014 15:00	1.7	11.6	2,134.5	1.1	8.50	1	1	1
08/01/2014 16:00	1.7	11.9	2,079.3	1.1	8.30	1	1	1
08/01/2014 17:00	1.6	12.1	2,046.6	1.1	8.20	1	1	1
08/01/2014 18:00	1.6	12.1	2,035.3	1.1	8.10	1	1	1
08/01/2014 19:00	1.6	12.3	2,026.1	1.1	8.10	1	1	1
08/01/2014 20:00	1.5	12.7	1,962.1	1.1	7.80	1	1	1
08/01/2014 21:00	1.5	12.8	1,930.4	1.1	7.70	1	1	1
08/01/2014 22:00	1.5	12.9	1,917.3	1.1	7.70	1	1	1
08/01/2014 23:00	1.5	12.7	1,954.7	1.1	7.80	1	1	1
Average/Sum#:	1.5	12.5	1,972.8	1.1	187.20 #	24 #	24 #	24 #
Minimum:	1.2	11.4	1,585.6	0.9	5.60	1	1	1
Maximum:	1.8	13.6	2,192.5	1.1	8.80	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/02/2014 00:00	1.5	13.0	1,901.4	1.1	7.60	1	1	1
08/02/2014 01:00	1.4	13.1	1,877.5	1.1	7.50	1	1	1
08/02/2014 02:00	1.5	13.2	1,854.5	1.1	7.40	1	1	1
08/02/2014 03:00	1.0	13.9	1,307.7	0.8	3.90	1	1	0
08/02/2014 04:00	1.2	13.9	1,476.7	1.0	5.90	1	1	0
08/02/2014 05:00	1.0	13.9	1,268.3	0.8	3.80	1	1	0
08/02/2014 06:00	1.1	13.8	1,243.7	0.9	3.70	1	1	0
08/02/2014 07:00	1.2	13.6	1,520.0	1.0	6.10	1	1	1
08/02/2014 08:00	1.5	13.1	1,874.3	1.1	7.50	1	1	1
08/02/2014 09:00	1.4	13.2	1,835.5	1.1	7.30	1	1	1
08/02/2014 10:00	1.5	13.2	1,844.1	1.1	7.40	1	1	1
08/02/2014 11:00	1.5	13.0	1,888.1	1.1	7.60	1	1	1
08/02/2014 12:00	1.5	12.8	1,929.7	1.1	7.70	1	1	1
08/02/2014 13:00	1.5	12.7	1,933.2	1.1	7.70	1	1	1
08/02/2014 14:00	1.4	12.8	1,890.5	1.0	7.60	1	1	1
08/02/2014 15:00	1.5	12.7	1,912.6	1.1	7.70	1	1	1
08/02/2014 16:00	1.4	12.6	1,921.2	1.0	7.70	1	1	1
08/02/2014 17:00	1.4	12.5	1,945.7	1.0	7.80	1	1	1
08/02/2014 18:00	1.4	12.6	1,934.6	1.0	7.70	1	1	1
08/02/2014 19:00	1.6	12.3	2,009.7	1.1	8.00	1	1	1
08/02/2014 20:00	1.4	12.3	2,004.2	1.0	8.00	1	1	1
08/02/2014 21:00	1.5	12.7	1,929.8	1.1	7.70	1	1	1
08/02/2014 22:00	1.2	13.6	1,543.0	1.0	6.20	1	1	1
08/02/2014 23:00	1.0	13.9	1,280.5	0.8	3.80	1	1	0
Average/Sum#:	1.4	13.1	1,755.3	1.0	163.30 #	24 #	24 #	19 #
Minimum:	1.0	12.3	1,243.7	0.8	3.70	1	1	0
Maximum:	1.6	13.9	2,009.7	1.1	8.00	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/03/2014 00:00	1.2	13.8	1,594.5	1.0	6.40	1	1	0
08/03/2014 01:00	1.1	13.8	1,491.5	0.9	4.50	1	1	0
08/03/2014 02:00	1.1	13.8	1,414.0	0.9	4.20	1	1	0
08/03/2014 03:00	1.2	13.8	1,598.2	1.0	6.40	1	1	0
08/03/2014 04:00	1.3	13.7	1,749.2	1.1	7.00	1	1	1
08/03/2014 05:00	1.4	13.4	1,840.9	1.1	7.40	1	1	1
08/03/2014 06:00	1.3	13.3	1,851.1	1.0	7.40	1	1	1
08/03/2014 07:00	1.5	12.7	1,975.3	1.1	7.90	1	1	1
08/03/2014 08:00	1.5	12.9	1,921.9	1.1	7.70	1	1	1
08/03/2014 09:00	1.4	12.9	1,909.1	1.0	7.60	1	1	1
08/03/2014 10:00	1.5	12.8	1,922.6	1.1	7.70	1	1	1
08/03/2014 11:00	1.5	12.8	1,932.9	1.1	7.70	1	1	1
08/03/2014 12:00	1.5	12.8	1,927.4	1.1	7.70	1	1	1
08/03/2014 13:00	1.7	11.9	2,105.6	1.1	8.40	1	1	1
08/03/2014 14:00	1.4	12.3	2,011.7	1.0	8.00	1	1	1
08/03/2014 15:00	1.7	11.7	2,137.2	1.1	8.50	1	1	1
08/03/2014 16:00	1.5	12.4	1,988.0	1.0	8.00	1	1	1
08/03/2014 17:00	1.5	12.5	1,971.7	1.1	7.90	1	1	1
08/03/2014 18:00	1.3	12.9	1,894.3	1.0	7.60	1	1	1
08/03/2014 19:00	1.5	12.6	1,973.2	1.1	7.90	1	1	1
08/03/2014 20:00	1.6	12.5	1,986.1	1.1	7.90	1	1	1
08/03/2014 21:00	1.3	12.9	1,888.0	1.0	7.60	1	1	1
08/03/2014 22:00	1.5	12.9	1,876.8	1.1	7.50	1	1	1
08/03/2014 23:00	1.5	12.7	1,954.8	1.1	7.80	1	1	1
Average/Sum#:	1.4	12.9	1,871.5	1.1	176.70 #	24 #	24 #	20 #
Minimum:	1.1	11.7	1,414.0	0.9	4.20	1	1	0
Maximum:	1.7	13.8	2,137.2	1.1	8.50	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/04/2014 00:00	1.4	13.0	1,892.6	1.0	7.60	1	1	1
08/04/2014 01:00	1.5	12.9	1,923.8	1.1	7.70	1	1	1
08/04/2014 02:00	1.4	13.1	1,885.6	1.1	7.50	1	1	1
08/04/2014 03:00	1.5	12.9	1,938.1	1.1	7.80	1	1	1
08/04/2014 04:00	1.4	13.2	1,861.5	1.1	7.40	1	1	1
08/04/2014 05:00	1.4	13.0	1,829.8	1.0	7.30	1	1	1
08/04/2014 06:00	1.3	13.7	1,696.5	1.1	6.80	1	1	0
08/04/2014 07:00	1.3	13.7	1,680.4	1.1	6.70	1	1	0
08/04/2014 08:00	1.3	13.6	1,763.6	1.1	7.10	1	1	0
08/04/2014 09:00	1.3	13.6	1,757.1	1.1	7.00	1	1	0
08/04/2014 10:00	1.4	13.2	1,802.9	1.1	7.20	1	1	1
08/04/2014 11:00	1.5	12.8	1,925.6	1.1	7.70	1	1	1
08/04/2014 12:00	1.3	13.1	1,859.1	1.0	7.40	1	1	1
08/04/2014 13:00	1.3	13.1	1,862.8	1.0	7.50	1	1	1
08/04/2014 14:00	1.3	13.1	1,864.5	1.0	7.50	1	1	1
08/04/2014 15:00	1.3	13.0	1,863.9	1.0	7.50	1	1	1
08/04/2014 16:00	1.3	13.0	1,864.4	1.0	7.50	1	1	1
08/04/2014 17:00	1.2	13.1	1,863.2	0.9	5.60	1	1	1
08/04/2014 18:00	1.3	13.1	1,860.6	1.0	7.40	1	1	1
08/04/2014 19:00	1.3	13.1	1,859.5	1.0	7.40	1	1	1
08/04/2014 20:00	1.3	13.1	1,859.2	1.0	7.40	1	1	1
08/04/2014 21:00	1.2	13.3	1,589.4	0.9	4.80	1	1	1
08/04/2014 22:00	1.0	13.8	1,284.4	0.8	3.90	1	1	0
08/04/2014 23:00	1.2	13.7	1,609.1	1.0	6.40	1	1	0
Average/Sum#:	1.3	13.2	1,799.9	1.0	168.10 #	24 #	24 #	18 #
Minimum:	1.0	12.8	1,284.4	0.8	3.90	1	1	0
Maximum:	1.5	13.8	1,938.1	1.1	7.80	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/05/2014 00:00	1.3	13.4	1,765.9	1.0	7.10	1	1	1
08/05/2014 01:00	1.4	12.9	1,920.5	1.0	7.70	1	1	1
08/05/2014 02:00	1.5	12.7	1,955.5	1.1	7.80	1	1	1
08/05/2014 03:00	1.4	12.8	1,927.2	1.0	7.70	1	1	1
08/05/2014 04:00	1.5	12.8	1,934.7	1.1	7.70	1	1	1
08/05/2014 05:00	1.4	13.2	1,859.6	1.1	7.40	1	1	1
08/05/2014 06:00	1.4	13.0	1,896.0	1.0	7.60	1	1	1
08/05/2014 07:00	0.9	13.8	1,299.1	0.7	3.90	1	1	1
08/05/2014 08:00	0.8	13.8	1,254.9	0.7	2.50	1	1	0
08/05/2014 09:00	1.1	13.3	1,572.9	0.9	4.70	1	1	1
08/05/2014 10:00	1.3	13.1	1,866.4	1.0	7.50	1	1	1
08/05/2014 11:00	1.3	13.1	1,874.0	1.0	7.50	1	1	1
08/05/2014 12:00	1.3	12.9	1,911.7	1.0	7.60	1	1	1
08/05/2014 13:00	1.5	12.7	1,945.9	1.1	7.80	1	1	1
08/05/2014 14:00	1.5	12.7	1,955.0	1.1	7.80	1	1	1
08/05/2014 15:00	1.5	12.5	1,991.3	1.1	8.00	1	1	1
08/05/2014 16:00	1.5	12.7	1,943.3	1.1	7.80	1	1	1
08/05/2014 17:00	1.5	12.7	1,955.4	1.1	7.80	1	1	1
08/05/2014 18:00	1.5	12.6	1,968.0	1.1	7.90	1	1	1
08/05/2014 19:00	1.5	12.6	1,979.6	1.1	7.90	1	1	1
08/05/2014 20:00	1.4	12.8	1,913.2	1.0	7.70	1	1	1
08/05/2014 21:00	1.4	12.8	1,927.7	1.0	7.70	1	1	1
08/05/2014 22:00	1.1	13.4	1,476.3	0.9	4.40	1	1	1
08/05/2014 23:00	1.0	13.5	1,530.0	0.8	4.60	1	1	1
Average/Sum#:	1.3	13.0	1,817.7	1.0	166.10 #	24 #	24 #	23 #
Minimum:	0.8	12.5	1,254.9	0.7	2.50	1	1	0
Maximum:	1.5	13.8	1,991.3	1.1	8.00	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/06/2014 00:00	1.5	12.7	1,962.1	1.1	7.80	1	1	1
08/06/2014 01:00	1.5	12.6	1,984.1	1.1	7.90	1	1	1
08/06/2014 02:00	1.4	12.8	1,920.2	1.0	7.70	1	1	1
08/06/2014 03:00	1.3	13.1	1,865.4	1.0	7.50	1	1	1
08/06/2014 04:00	1.6	12.5	1,991.2	1.1	8.00	1	1	1
08/06/2014 05:00	1.6	12.4	2,029.4	1.1	8.10	1	1	1
08/06/2014 06:00	1.5	12.7	1,958.3	1.1	7.80	1	1	1
08/06/2014 07:00	1.4	12.8	1,933.2	1.0	7.70	1	1	1
08/06/2014 08:00	1.6	12.5	1,985.5	1.1	7.90	1	1	1
08/06/2014 09:00	1.6	12.3	2,037.1	1.1	8.10	1	1	1
08/06/2014 10:00	1.6	12.1	2,054.2	1.1	8.20	1	1	1
08/06/2014 11:00	1.6	12.0	2,073.7	1.1	8.30	1	1	1
08/06/2014 12:00	1.6	12.2	2,035.3	1.1	8.10	1	1	1
08/06/2014 13:00	1.6	12.2	2,023.0	1.1	8.10	1	1	1
08/06/2014 14:00	1.7	11.9	2,086.0	1.1	8.30	1	1	1
08/06/2014 15:00	1.5	12.2	2,007.1	1.0	8.00	1	1	1
08/06/2014 16:00	1.3	12.9	1,877.3	1.0	7.50	1	1	1
08/06/2014 17:00	1.4	12.5	1,960.3	1.0	7.80	1	1	1
08/06/2014 18:00	1.4	12.4	1,975.8	1.0	7.90	1	1	1
08/06/2014 19:00	1.5	12.2	2,017.0	1.0	8.10	1	1	1
08/06/2014 20:00	1.6	12.2	2,015.5	1.1	8.10	1	1	1
08/06/2014 21:00	1.5	12.6	1,935.0	1.1	7.70	1	1	1
08/06/2014 22:00	1.0	13.4	1,460.5	0.8	4.40	1	1	1
08/06/2014 23:00	1.3	13.7	1,659.5	1.1	6.60	1	1	0
Average/Sum#:	1.5	12.5	1,951.9	1.1	185.60 #	24 #	24 #	23 #
Minimum:	1.0	11.9	1,460.5	0.8	4.40	1	1	0
Maximum:	1.7	13.7	2,086.0	1.1	8.30	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/07/2014 00:00	1.5	14.3	1,138.0	1.3	5.24	1	0	0
08/07/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/07/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/07/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/07/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/07/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/07/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/07/2014 07:00	18.0	17.2	504.2	28.7	36.31	1	0	0
08/07/2014 08:00	11.4	14.6	1,012.1	10.7	39.50	1	0	0
08/07/2014 09:00	0.8	13.9	1,340.3	0.7	2.70	1	1	0
08/07/2014 10:00	1.0	13.8	1,522.7	0.8	4.60	1	1	0
08/07/2014 11:00	1.3	13.6	1,721.7	1.1	6.90	1	1	0
08/07/2014 12:00	1.2	13.6	1,714.6	1.0	6.90	1	1	0
08/07/2014 13:00	1.2	13.6	1,711.7	1.0	6.80	1	1	0
08/07/2014 14:00	1.2	13.6	1,707.5	1.0	6.80	1	1	0
08/07/2014 15:00	1.1	13.0	1,721.9	0.8	5.20	1	1	1
08/07/2014 16:00	1.6	12.1	2,036.1	1.1	8.10	1	1	1
08/07/2014 17:00	1.7	11.6	2,128.9	1.1	8.50	1	1	1
08/07/2014 18:00	1.6	11.9	2,058.1	1.0	8.20	1	1	1
08/07/2014 19:00	1.6	12.3	2,003.3	1.1	8.00	1	1	1
08/07/2014 20:00	1.4	12.9	1,869.2	1.0	7.50	1	1	1
08/07/2014 21:00	1.4	12.8	1,899.9	1.0	7.60	1	1	1
08/07/2014 22:00	1.3	13.1	1,842.8	1.0	7.40	1	1	1
08/07/2014 23:00	1.4	13.2	1,829.5	1.1	7.30	1	1	1
Average/Sum#:	2.8	13.4	1,653.5	3.1	183.55 #	18 #	15 #	9 #
Minimum:	0.8	11.6	504.2	0.7	2.70	0	0	0
Maximum:	18.0	17.2	2,128.9	28.7	39.50	1	1	1
%SI	25.0	25.0	25.0	25.0	25.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/08/2014 00:00	1.5	12.8	1,945.3	1.1	7.80	1	1	1
08/08/2014 01:00	1.4	12.9	1,930.8	1.0	7.70	1	1	1
08/08/2014 02:00	1.4	13.3	1,844.6	1.1	7.40	1	1	1
08/08/2014 03:00	1.4	13.0	1,899.5	1.0	7.60	1	1	1
08/08/2014 04:00	1.5	12.9	1,934.3	1.1	7.70	1	1	1
08/08/2014 05:00	1.6	12.7	1,989.4	1.2	8.00	1	1	1
08/08/2014 06:00	1.5	12.6	1,990.0	1.1	8.00	1	1	1
08/08/2014 07:00	1.5	12.8	1,948.3	1.1	7.80	1	1	1
08/08/2014 08:00	1.4	13.0	1,900.5	1.0	7.60	1	1	1
08/08/2014 09:00	1.7	11.7	2,171.3	1.1	8.70	1	1	1
08/08/2014 10:00	1.6	12.0	2,064.6	1.1	8.30	1	1	1
08/08/2014 11:00	1.4	13.0	1,866.0	1.0	7.50	1	1	1
08/08/2014 12:00	1.5	12.8	1,900.6	1.1	7.60	1	1	1
08/08/2014 13:00	1.5	12.2	2,024.7	1.0	8.10	1	1	1
08/08/2014 14:00	1.7	11.6	2,148.5	1.1	8.60	1	1	1
08/08/2014 15:00	1.7	11.5	2,154.6	1.1	8.60	1	1	1
08/08/2014 16:00	1.7	11.6	2,143.8	1.1	8.60	1	1	1
08/08/2014 17:00	1.6	12.0	2,060.4	1.1	8.20	1	1	1
08/08/2014 18:00	1.8	11.4	2,178.8	1.1	8.70	1	1	1
08/08/2014 19:00	1.7	11.8	2,103.5	1.1	8.40	1	1	1
08/08/2014 20:00	1.5	12.3	2,005.2	1.0	8.00	1	1	1
08/08/2014 21:00	1.6	12.4	1,989.2	1.1	8.00	1	1	1
08/08/2014 22:00	1.5	12.8	1,896.9	1.1	7.60	1	1	1
08/08/2014 23:00	1.6	12.5	1,978.5	1.1	7.90	1	1	1
Average/Sum#:	1.6	12.4	2,002.9	1.1	192.40 #	24 #	24 #	24 #
Minimum:	1.4	11.4	1,844.6	1.0	7.40	1	1	1
Maximum:	1.8	13.3	2,178.8	1.2	8.70	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/09/2014 00:00	1.3	13.6	1,691.6	1.1	6.80	1	1	1
08/09/2014 01:00	1.1	13.7	1,541.2	0.9	4.60	1	1	0
08/09/2014 02:00	5.6	15.7	614.9	6.4	3.53	1	0	0
08/09/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/09/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/09/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/09/2014 06:00	15.6	16.2	585.4	19.6	29.47	1	0	0
08/09/2014 07:00	4.6	13.9	1,381.8	3.9	19.30	1	0	0
08/09/2014 08:00	0.6	13.9	1,346.9	0.5	2.70	1	1	0
08/09/2014 09:00	0.9	13.8	1,624.9	0.7	4.90	1	1	0
08/09/2014 10:00	1.2	13.7	1,741.7	1.0	7.00	1	1	0
08/09/2014 11:00	1.0	13.9	1,561.6	0.8	4.70	1	1	0
08/09/2014 12:00	1.1	13.7	1,469.0	0.9	4.40	1	1	1
08/09/2014 13:00	1.5	13.0	1,878.8	1.1	7.50	1	1	1
08/09/2014 14:00	1.5	12.9	1,905.5	1.1	7.60	1	1	1
08/09/2014 15:00	1.5	12.6	1,958.5	1.1	7.80	1	1	1
08/09/2014 16:00	1.5	12.6	1,938.9	1.1	7.80	1	1	1
08/09/2014 17:00	1.5	12.7	1,927.9	1.1	7.70	1	1	1
08/09/2014 18:00	1.6	12.1	2,053.3	1.1	8.20	1	1	1
08/09/2014 19:00	1.7	11.4	2,217.4	1.1	8.90	1	1	1
08/09/2014 20:00	1.7	11.8	2,139.7	1.1	8.60	1	1	1
08/09/2014 21:00	1.6	11.9	2,111.1	1.0	8.40	1	1	1
08/09/2014 22:00	1.6	12.5	2,014.2	1.1	8.10	1	1	1
08/09/2014 23:00	1.3	13.3	1,686.7	1.0	6.70	1	1	1
Average/Sum#:	2.4	13.3	1,685.3	2.3	174.70 #	21 #	18 #	13 #
Minimum:	0.6	11.4	585.4	0.5	2.70	0	0	0
Maximum:	15.6	16.2	2,217.4	19.6	29.47	1	1	1
%SI	12.5	12.5	12.5	12.5	12.50	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/10/2014 00:00	5.1	15.6	607.0	5.7	2.92	1	0	0
08/10/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/10/2014 07:00	20.3	16.9	547.6	29.9	46.35	1	0	0
08/10/2014 08:00	7.6	14.2	1,225.8	6.7	30.60	1	0	0
08/10/2014 09:00	1.0	13.8	1,345.3	0.8	4.00	1	1	0
08/10/2014 10:00	1.3	13.8	1,700.9	1.1	6.80	1	1	0
08/10/2014 11:00	1.1	13.9	1,609.6	0.9	4.80	1	1	0
08/10/2014 12:00	1.2	13.8	1,587.3	1.0	6.30	1	1	1
08/10/2014 13:00	1.5	12.6	1,955.0	1.1	7.80	1	1	1
08/10/2014 14:00	1.6	12.6	1,957.4	1.1	7.80	1	1	1
08/10/2014 15:00	1.5	12.8	1,917.9	1.1	7.70	1	1	1
08/10/2014 16:00	1.6	12.3	2,022.9	1.1	8.10	1	1	1
08/10/2014 17:00	1.7	11.4	2,205.5	1.1	8.80	1	1	1
08/10/2014 18:00	1.7	11.5	2,192.1	1.1	8.80	1	1	1
08/10/2014 19:00	1.7	11.5	2,194.7	1.1	8.80	1	1	1
08/10/2014 20:00	1.7	11.6	2,176.5	1.1	8.70	1	1	1
08/10/2014 21:00	1.6	11.9	2,121.1	1.0	8.50	1	1	1
08/10/2014 22:00	1.5	12.8	1,935.3	1.1	7.70	1	1	1
08/10/2014 23:00	1.4	12.6	1,989.6	1.0	8.00	1	1	1
Average/Sum#:	3.1	13.1	1,738.4	3.2	192.47 #	18 #	15 #	12 #
Minimum:	1.0	11.4	547.6	0.8	2.92	0	0	0
Maximum:	20.3	16.9	2,205.5	29.9	46.35	1	1	1
%SI	25.0	25.0	25.0	25.0	25.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/11/2014 00:00	1.6	12.6	1,986.3	1.1	7.90	1	1	1
08/11/2014 01:00	1.5	12.6	1,991.7	1.1	8.00	1	1	1
08/11/2014 02:00	1.5	12.8	1,947.4	1.1	7.80	1	1	1
08/11/2014 03:00	1.5	12.6	1,993.3	1.1	8.00	1	1	1
08/11/2014 04:00	1.5	12.6	2,006.6	1.1	8.00	1	1	1
08/11/2014 05:00	1.5	12.9	1,956.2	1.1	7.80	1	1	1
08/11/2014 06:00	1.3	11.8	2,184.5	0.8	6.60	1	1	1
08/11/2014 07:00	1.6	12.5	2,008.9	1.1	8.00	1	1	1
08/11/2014 08:00	1.6	12.5	1,991.8	1.1	8.00	1	1	1
08/11/2014 09:00	1.7	11.5	2,219.1	1.1	8.90	1	1	1
08/11/2014 10:00	1.7	11.2	2,258.0	1.0	9.00	1	1	1
08/11/2014 11:00	1.7	11.2	2,267.0	1.0	9.10	1	1	1
08/11/2014 12:00	1.7	11.2	2,255.0	1.0	9.00	1	1	1
08/11/2014 13:00	1.7	11.3	2,232.9	1.0	8.90	1	1	1
08/11/2014 14:00	1.7	11.4	2,219.4	1.1	8.90	1	1	1
08/11/2014 15:00	1.7	11.4	2,216.0	1.1	8.90	1	1	1
08/11/2014 16:00	1.7	11.3	2,215.9	1.0	8.90	1	1	1
08/11/2014 17:00	1.7	11.3	2,214.0	1.0	8.90	1	1	1
08/11/2014 18:00	1.7	11.3	2,214.8	1.0	8.90	1	1	1
08/11/2014 19:00	1.7	11.3	2,239.7	1.0	9.00	1	1	1
08/11/2014 20:00	1.7	11.4	2,207.7	1.1	8.80	1	1	1
08/11/2014 21:00	1.5	12.5	1,939.4	1.1	7.80	1	1	1
08/11/2014 22:00	1.3	13.8	1,687.3	1.1	6.70	1	1	0
08/11/2014 23:00	1.3	13.8	1,677.6	1.1	6.70	1	1	0
Average/Sum#:	1.6	12.0	2,088.8	1.1	198.50 #	24 #	24 #	22 #
Minimum:	1.3	11.2	1,677.6	0.8	6.60	1	1	0
Maximum:	1.7	13.8	2,267.0	1.1	9.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/12/2014 00:00	1.2	13.8	1,633.0	1.0	6.50	1	1	0
08/12/2014 01:00	1.2	13.8	1,658.0	1.0	6.60	1	1	0
08/12/2014 02:00	1.2	13.8	1,536.7	1.0	6.10	1	1	0
08/12/2014 03:00	1.2	13.8	1,529.4	1.0	6.10	1	1	0
08/12/2014 04:00	1.3	13.8	1,691.4	1.1	6.80	1	1	0
08/12/2014 05:00	1.2	13.7	1,760.4	1.0	7.00	1	1	0
08/12/2014 06:00	1.2	13.7	1,760.4	1.0	7.00	1	1	0
08/12/2014 07:00	1.1	13.7	1,721.7	0.9	5.20	1	1	0
08/12/2014 08:00	1.0	13.8	1,311.0	0.8	3.90	1	1	0
08/12/2014 09:00	1.2	13.8	1,638.2	1.0	6.60	1	1	0
08/12/2014 10:00	1.2	13.7	1,747.0	1.0	7.00	1	1	0
08/12/2014 11:00	1.2	13.8	1,643.3	1.0	6.60	1	1	0
08/12/2014 12:00	1.2	13.6	1,737.2	1.0	6.90	1	1	0
08/12/2014 13:00	1.3	13.7	1,732.5	1.1	6.90	1	1	0
08/12/2014 14:00	1.2	13.6	1,731.4	1.0	6.90	1	1	0
08/12/2014 15:00	1.2	13.6	1,730.6	1.0	6.90	1	1	0
08/12/2014 16:00	1.2	13.7	1,731.1	1.0	6.90	1	1	0
08/12/2014 17:00	1.2	13.7	1,734.5	1.0	6.90	1	1	0
08/12/2014 18:00	1.3	13.6	1,739.1	1.1	7.00	1	1	0
08/12/2014 19:00	1.3	13.7	1,749.3	1.1	7.00	1	1	0
08/12/2014 20:00	1.3	13.7	1,752.8	1.1	7.00	1	1	0
08/12/2014 21:00	1.3	13.7	1,756.9	1.1	7.00	1	1	0
08/12/2014 22:00	1.3	13.7	1,766.9	1.1	7.10	1	1	0
08/12/2014 23:00	1.2	13.7	1,768.4	1.0	7.10	1	1	0
Average/Sum#:	1.2	13.7	1,690.1	1.0	159.00 #	24 #	24 #	0 #
Minimum:	1.0	13.6	1,311.0	0.8	3.90	1	1	0
Maximum:	1.3	13.8	1,768.4	1.1	7.10	1	1	0
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/13/2014 00:00	1.3	13.7	1,770.8	1.1	7.10	1	1	0
08/13/2014 01:00	2.2	14.4	1,364.5	2.0	6.72	1	0	0
08/13/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/13/2014 05:00	8.9	17.0	568.8	13.5	13.35	1	0	0
08/13/2014 06:00	4.0	13.7	1,726.2	3.3	20.70	1	0	0
08/13/2014 07:00	1.3	13.7	1,787.3	1.1	7.10	1	1	0
08/13/2014 08:00	1.3	13.7	1,777.7	1.1	7.10	1	1	0
08/13/2014 09:00	1.3	13.6	1,771.8	1.1	7.10	1	1	0
08/13/2014 10:00	1.2	13.6	1,763.6	1.0	7.10	1	1	0
08/13/2014 11:00	1.3	13.6	1,756.1	1.1	7.00	1	1	0
08/13/2014 12:00	1.3	13.6	1,749.4	1.1	7.00	1	1	0
08/13/2014 13:00	1.2	13.6	1,741.5	1.0	7.00	1	1	0
08/13/2014 14:00	1.2	13.6	1,732.9	1.0	6.90	1	1	0
08/13/2014 15:00	1.2	13.6	1,731.4	1.0	6.90	1	1	0
08/13/2014 16:00	1.2	13.6	1,729.4	1.0	6.90	1	1	0
08/13/2014 17:00	1.2	13.6	1,729.3	1.0	6.90	1	1	0
08/13/2014 18:00	1.2	13.6	1,731.9	1.0	6.90	1	1	0
08/13/2014 19:00	1.2	13.6	1,739.3	1.0	7.00	1	1	0
08/13/2014 20:00	1.3	13.6	1,748.6	1.1	7.00	1	1	0
08/13/2014 21:00	1.2	13.7	1,733.5	1.0	6.90	1	1	0
08/13/2014 22:00	1.0	13.8	1,652.4	0.8	5.00	1	1	0
08/13/2014 23:00	2.9	14.8	961.1	2.8	4.51	1	0	0
Average/Sum#:	1.9	13.9	1,631.8	1.9	162.18 #	21 #	17 #	0 #
Minimum:	1.0	13.6	568.8	0.8	4.51	0	0	0
Maximum:	8.9	17.0	1,787.3	13.5	20.70	1	1	0
%SI	12.5	12.5	12.5	12.5	12.50	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/14/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/14/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/15/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/15/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/16/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/16/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/17/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/17/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/18/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/18/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/19/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/19/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/20/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/20/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/21/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/21/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/22/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/22/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/23/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/23/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/24/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/24/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/25/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/25/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/26/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/26/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/27/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/27/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/28/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/28/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/29/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/29/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/30/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/30/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
08/31/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
08/31/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/01/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/01/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/02/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/02/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/03/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/03/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/04/2014 00:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 01:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 02:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 03:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 04:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 05:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 06:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 07:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 08:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 09:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 10:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 11:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 12:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 13:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 14:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 15:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 16:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 17:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 18:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 19:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 20:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 21:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 22:00	0.0	0.0	0.0	0.0	0.00	0	0	0
09/04/2014 23:00	0.0	0.0	0.0	0.0	0.00	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.00 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.00	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.00	0	0	0
%SI	100.0	100.0	100.0	100.0	100.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/05/2014 00:00	20.9	18.0	394.7	42.5	21.70	1	0	0
09/05/2014 01:00	49.5	16.9	549.5	73.0	147.80	1	0	0
09/05/2014 02:00	10.3	17.7	606.9	19.0	42.50	1	0	0
09/05/2014 03:00	7.4	17.7	609.8	13.6	30.50	1	0	0
09/05/2014 04:00	11.2	15.5	945.8	12.2	42.60	1	0	0
09/05/2014 05:00	1.0	13.9	1,438.9	0.8	4.30	1	1	0
09/05/2014 06:00	1.3	13.9	1,733.5	1.1	6.90	1	1	0
09/05/2014 07:00	1.3	13.9	1,728.2	1.1	6.90	1	1	0
09/05/2014 08:00	1.3	13.8	1,654.6	1.1	6.60	1	1	0
09/05/2014 09:00	1.2	13.9	1,420.2	1.0	5.70	1	1	0
09/05/2014 10:00	1.1	13.9	1,267.8	0.9	3.80	1	1	0
09/05/2014 11:00	1.2	14.0	1,368.1	1.0	5.50	1	1	0
09/05/2014 12:00	1.3	13.7	1,673.5	1.1	6.70	1	1	1
09/05/2014 13:00	1.5	12.8	1,942.7	1.1	7.80	1	1	1
09/05/2014 14:00	1.5	12.8	1,925.9	1.1	7.70	1	1	1
09/05/2014 15:00	1.5	12.6	1,963.4	1.1	7.90	1	1	1
09/05/2014 16:00	1.5	12.6	1,971.1	1.1	7.90	1	1	1
09/05/2014 17:00	1.6	11.7	2,184.5	1.0	8.70	1	1	1
09/05/2014 18:00	1.6	12.2	2,067.3	1.1	8.30	1	1	1
09/05/2014 19:00	1.5	12.6	1,974.3	1.1	7.90	1	1	1
09/05/2014 20:00	1.5	13.1	1,867.6	1.1	7.50	1	1	1
09/05/2014 21:00	1.4	12.8	1,941.9	1.0	7.80	1	1	1
09/05/2014 22:00	1.4	12.8	1,949.6	1.0	7.80	1	1	1
09/05/2014 23:00	1.6	11.7	2,202.5	1.0	8.80	1	1	1
Average/Sum#:	5.2	13.9	1,557.6	7.5	419.60 #	24 #	19 #	12 #
Minimum:	1.0	11.7	394.7	0.8	3.80	1	0	0
Maximum:	49.5	18.0	2,202.5	73.0	147.80	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/06/2014 00:00	1.5	12.2	2,074.3	1.0	8.30	1	1	1
09/06/2014 01:00	1.5	12.9	1,950.6	1.1	7.80	1	1	1
09/06/2014 02:00	1.5	12.7	1,997.0	1.1	8.00	1	1	1
09/06/2014 03:00	1.5	12.7	1,997.8	1.1	8.00	1	1	1
09/06/2014 04:00	1.5	12.7	1,989.4	1.1	8.00	1	1	1
09/06/2014 05:00	1.4	13.3	1,859.9	1.1	7.40	1	1	1
09/06/2014 06:00	1.4	13.2	1,872.3	1.1	7.50	1	1	1
09/06/2014 07:00	1.4	13.1	1,901.0	1.1	7.60	1	1	1
09/06/2014 08:00	1.4	13.3	1,855.8	1.1	7.40	1	1	1
09/06/2014 09:00	1.4	13.0	1,925.8	1.0	7.70	1	1	1
09/06/2014 10:00	1.4	13.0	1,901.5	1.0	7.60	1	1	1
09/06/2014 11:00	1.4	12.9	1,924.4	1.0	7.70	1	1	1
09/06/2014 12:00	1.6	12.3	2,043.0	1.1	8.20	1	1	1
09/06/2014 13:00	1.6	11.5	2,214.9	1.0	8.90	1	1	1
09/06/2014 14:00	1.6	12.1	2,071.3	1.1	8.30	1	1	1
09/06/2014 15:00	1.5	12.4	2,012.5	1.0	8.10	1	1	1
09/06/2014 16:00	1.5	12.5	1,986.7	1.1	7.90	1	1	1
09/06/2014 17:00	1.6	11.3	2,247.8	1.0	9.00	1	1	1
09/06/2014 18:00	1.5	11.6	2,176.0	1.0	8.70	1	1	1
09/06/2014 19:00	1.5	13.0	1,892.4	1.1	7.60	1	1	1
09/06/2014 20:00	1.4	13.2	1,853.9	1.1	7.40	1	1	1
09/06/2014 21:00	1.4	13.2	1,854.6	1.1	7.40	1	1	1
09/06/2014 22:00	1.3	13.1	1,894.5	1.0	7.60	1	1	1
09/06/2014 23:00	1.5	12.7	1,987.3	1.1	7.90	1	1	1
Average/Sum#:	1.5	12.7	1,978.5	1.1	190.00 #	24 #	24 #	24 #
Minimum:	1.3	11.3	1,853.9	1.0	7.40	1	1	1
Maximum:	1.6	13.3	2,247.8	1.1	9.00	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/07/2014 00:00	1.4	13.1	1,893.6	1.1	7.60	1	1	1
09/07/2014 01:00	1.4	13.1	1,900.6	1.1	7.60	1	1	1
09/07/2014 02:00	1.4	13.3	1,853.0	1.1	7.40	1	1	1
09/07/2014 03:00	1.4	13.3	1,848.2	1.1	7.40	1	1	1
09/07/2014 04:00	1.4	13.3	1,846.3	1.1	7.40	1	1	1
09/07/2014 05:00	1.4	13.3	1,848.6	1.1	7.40	1	1	1
09/07/2014 06:00	1.1	13.3	1,857.3	0.9	5.60	1	1	1
09/07/2014 07:00	1.4	13.3	1,860.3	1.1	7.40	1	1	1
09/07/2014 08:00	1.4	13.0	1,928.7	1.0	7.70	1	1	1
09/07/2014 09:00	1.5	12.5	2,039.6	1.1	8.20	1	1	1
09/07/2014 10:00	1.6	12.0	2,136.4	1.1	8.50	1	1	1
09/07/2014 11:00	1.6	12.0	2,122.4	1.1	8.50	1	1	1
09/07/2014 12:00	1.5	12.6	1,972.4	1.1	7.90	1	1	1
09/07/2014 13:00	1.5	12.7	1,951.2	1.1	7.80	1	1	1
09/07/2014 14:00	1.5	12.7	1,946.3	1.1	7.80	1	1	1
09/07/2014 15:00	1.5	12.7	1,958.1	1.1	7.80	1	1	1
09/07/2014 16:00	1.5	12.2	2,053.6	1.0	8.20	1	1	1
09/07/2014 17:00	1.6	11.4	2,221.0	1.0	8.90	1	1	1
09/07/2014 18:00	1.6	11.4	2,223.5	1.0	8.90	1	1	1
09/07/2014 19:00	1.6	11.4	2,220.5	1.0	8.90	1	1	1
09/07/2014 20:00	1.6	12.0	2,086.4	1.1	8.30	1	1	1
09/07/2014 21:00	1.5	13.0	1,897.3	1.1	7.60	1	1	1
09/07/2014 22:00	1.3	13.2	1,852.4	1.0	7.40	1	1	1
09/07/2014 23:00	1.4	13.0	1,918.4	1.0	7.70	1	1	1
Average/Sum#:	1.5	12.7	1,976.5	1.1	187.90 #	24 #	24 #	24 #
Minimum:	1.1	11.4	1,846.3	0.9	5.60	1	1	1
Maximum:	1.6	13.3	2,223.5	1.1	8.90	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/08/2014 00:00	1.2	13.6	1,499.2	1.0	6.00	1	1	1
09/08/2014 01:00	1.1	13.9	1,256.5	0.9	3.80	1	1	0
09/08/2014 02:00	1.1	13.9	1,251.7	0.9	3.80	1	1	0
09/08/2014 03:00	1.2	13.9	1,553.2	1.0	6.20	1	1	0
09/08/2014 04:00	1.4	13.0	1,943.0	1.0	7.80	1	1	1
09/08/2014 05:00	1.4	13.2	1,898.9	1.1	7.60	1	1	1
09/08/2014 06:00	1.5	11.9	2,137.2	1.0	8.50	1	1	1
09/08/2014 07:00	1.6	11.4	2,304.7	1.0	9.20	1	1	1
09/08/2014 08:00	1.5	12.0	2,151.0	1.0	8.60	1	1	1
09/08/2014 09:00	1.4	13.3	1,860.7	1.1	7.40	1	1	1
09/08/2014 10:00	1.4	13.4	1,840.3	1.1	7.40	1	1	1
09/08/2014 11:00	1.4	13.4	1,837.7	1.1	7.40	1	1	1
09/08/2014 12:00	1.3	13.3	1,838.1	1.0	7.40	1	1	1
09/08/2014 13:00	1.4	13.3	1,839.5	1.1	7.40	1	1	1
09/08/2014 14:00	1.4	13.2	1,844.0	1.1	7.40	1	1	1
09/08/2014 15:00	1.4	13.2	1,850.7	1.1	7.40	1	1	1
09/08/2014 16:00	1.3	13.3	1,600.3	1.0	6.40	1	1	1
09/08/2014 17:00	1.3	13.9	1,269.8	1.1	5.10	1	1	0
09/08/2014 18:00	1.2	14.0	1,520.7	1.0	6.10	1	1	0
09/08/2014 19:00	1.2	14.0	1,535.8	1.0	6.10	1	1	0
09/08/2014 20:00	1.2	13.9	1,445.5	1.0	5.80	1	1	0
09/08/2014 21:00	1.1	13.9	1,363.3	0.9	4.10	1	1	0
09/08/2014 22:00	1.1	13.9	1,298.7	0.9	3.90	1	1	0
09/08/2014 23:00	1.1	13.9	1,255.1	0.9	3.80	1	1	0
Average/Sum#:	1.3	13.4	1,674.8	1.0	154.60 #	24 #	24 #	14 #
Minimum:	1.1	11.4	1,251.7	0.9	3.80	1	1	0
Maximum:	1.6	14.0	2,304.7	1.1	9.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/09/2014 00:00	1.1	13.9	1,255.4	0.9	3.80	1	1	0
09/09/2014 01:00	1.1	13.9	1,255.2	0.9	3.80	1	1	0
09/09/2014 02:00	1.1	13.9	1,255.5	0.9	3.80	1	1	0
09/09/2014 03:00	1.1	13.9	1,355.0	0.9	4.10	1	1	0
09/09/2014 04:00	1.0	13.9	1,268.0	0.8	3.80	1	1	0
09/09/2014 05:00	1.2	13.8	1,305.6	1.0	5.20	1	1	0
09/09/2014 06:00	0.4	13.9	1,261.0	0.3	1.30	1	1	0
09/09/2014 07:00	0.8	13.9	1,269.1	0.7	2.50	1	1	0
09/09/2014 08:00	1.2	13.7	1,561.7	1.0	6.20	1	1	1
09/09/2014 09:00	1.3	13.2	1,878.8	1.0	7.50	1	1	1
09/09/2014 10:00	1.3	13.2	1,866.2	1.0	7.50	1	1	1
09/09/2014 11:00	1.3	13.1	1,859.4	1.0	7.40	1	1	1
09/09/2014 12:00	1.4	12.8	1,928.1	1.0	7.70	1	1	1
09/09/2014 13:00	1.4	12.7	1,935.9	1.0	7.70	1	1	1
09/09/2014 14:00	1.4	12.8	1,903.2	1.0	7.60	1	1	1
09/09/2014 15:00	1.3	12.9	1,881.4	1.0	7.50	1	1	1
09/09/2014 16:00	1.4	12.9	1,878.8	1.0	7.50	1	1	1
09/09/2014 17:00	1.4	12.8	1,892.9	1.0	7.60	1	1	1
09/09/2014 18:00	1.4	12.9	1,874.2	1.0	7.50	1	1	1
09/09/2014 19:00	1.4	13.0	1,869.3	1.0	7.50	1	1	1
09/09/2014 20:00	1.3	13.0	1,891.7	1.0	7.60	1	1	1
09/09/2014 21:00	1.2	12.8	1,927.3	0.9	5.80	1	1	1
09/09/2014 22:00	1.0	12.9	1,907.5	0.7	5.70	1	1	1
09/09/2014 23:00	1.5	12.4	2,017.2	1.0	8.10	1	1	1
Average/Sum#:	1.2	13.3	1,679.1	0.9	144.70 #	24 #	24 #	16 #
Minimum:	0.4	12.4	1,255.2	0.3	1.30	1	1	0
Maximum:	1.5	13.9	2,017.2	1.0	8.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/10/2014 00:00	1.5	12.4	2,015.0	1.0	8.10	1	1	1
09/10/2014 01:00	1.1	12.5	2,015.7	0.8	6.00	1	1	1
09/10/2014 02:00	0.9	12.9	1,908.0	0.7	3.80	1	1	1
09/10/2014 03:00	1.4	12.6	1,981.7	1.0	7.90	1	1	1
09/10/2014 04:00	1.4	12.3	2,039.3	1.0	8.20	1	1	1
09/10/2014 05:00	1.4	12.7	1,967.1	1.0	7.90	1	1	1
09/10/2014 06:00	1.2	13.3	1,866.7	0.9	5.60	1	1	1
09/10/2014 07:00	1.4	13.2	1,861.4	1.1	7.40	1	1	1
09/10/2014 08:00	1.4	13.2	1,859.8	1.1	7.40	1	1	1
09/10/2014 09:00	1.4	12.8	1,921.7	1.0	7.70	1	1	1
09/10/2014 10:00	1.2	13.6	1,542.0	1.0	6.20	1	1	1
09/10/2014 11:00	1.2	13.9	1,261.4	1.0	5.00	1	1	0
09/10/2014 12:00	1.4	13.4	1,718.5	1.1	6.90	1	1	1
09/10/2014 13:00	1.4	12.8	1,940.3	1.0	7.80	1	1	1
09/10/2014 14:00	1.5	12.6	1,992.7	1.1	8.00	1	1	1
09/10/2014 15:00	1.6	11.6	2,204.7	1.0	8.80	1	1	1
09/10/2014 16:00	1.6	11.3	2,252.6	1.0	9.00	1	1	1
09/10/2014 17:00	1.6	11.3	2,252.2	1.0	9.00	1	1	1
09/10/2014 18:00	1.6	11.4	2,234.5	1.0	8.90	1	1	1
09/10/2014 19:00	1.6	11.7	2,187.6	1.0	8.80	1	1	1
09/10/2014 20:00	1.5	12.0	2,114.3	1.0	8.50	1	1	1
09/10/2014 21:00	1.5	12.3	2,058.5	1.0	8.20	1	1	1
09/10/2014 22:00	1.5	12.5	2,044.6	1.1	8.20	1	1	1
09/10/2014 23:00	1.5	12.1	2,129.8	1.0	8.50	1	1	1
Average/Sum#:	1.4	12.5	1,973.8	1.0	181.80 #	24 #	24 #	23 #
Minimum:	0.9	11.3	1,261.4	0.7	3.80	1	1	0
Maximum:	1.6	13.9	2,252.6	1.1	9.00	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/11/2014 00:00	1.4	12.8	1,978.5	1.0	7.90	1	1	1
09/11/2014 01:00	1.4	13.3	1,866.1	1.1	7.50	1	1	1
09/11/2014 02:00	1.4	13.3	1,866.1	1.1	7.50	1	1	1
09/11/2014 03:00	1.4	13.3	1,866.3	1.1	7.50	1	1	1
09/11/2014 04:00	1.4	12.9	1,947.3	1.0	7.80	1	1	1
09/11/2014 05:00	1.5	12.3	2,091.1	1.0	8.40	1	1	1
09/11/2014 06:00	1.5	12.7	2,007.5	1.1	8.00	1	1	1
09/11/2014 07:00	1.5	12.7	1,992.8	1.1	8.00	1	1	1
09/11/2014 08:00	1.5	12.8	1,967.4	1.1	7.90	1	1	1
09/11/2014 09:00	1.5	12.6	2,014.9	1.1	8.10	1	1	1
09/11/2014 10:00	1.6	12.1	2,107.0	1.1	8.40	1	1	1
09/11/2014 11:00	1.6	11.9	2,136.1	1.0	8.50	1	1	1
09/11/2014 12:00	1.5	12.8	1,925.1	1.1	7.70	1	1	1
09/11/2014 13:00	1.5	12.9	1,914.3	1.1	7.70	1	1	1
09/11/2014 14:00	1.5	12.9	1,893.0	1.1	7.60	1	1	1
09/11/2014 15:00	1.5	12.9	1,886.7	1.1	7.50	1	1	1
09/11/2014 16:00	1.6	12.0	2,093.8	1.1	8.40	1	1	1
09/11/2014 17:00	1.6	11.4	2,219.1	1.0	8.90	1	1	1
09/11/2014 18:00	1.6	11.3	2,243.3	1.0	9.00	1	1	1
09/11/2014 19:00	1.6	11.7	2,182.1	1.0	8.70	1	1	1
09/11/2014 20:00	1.6	11.6	2,186.9	1.0	8.70	1	1	1
09/11/2014 21:00	1.5	12.4	2,024.0	1.0	8.10	1	1	1
09/11/2014 22:00	1.5	12.3	2,065.7	1.0	8.30	1	1	1
09/11/2014 23:00	1.6	11.5	2,261.1	1.0	9.00	1	1	1
Average/Sum#:	1.5	12.4	2,030.7	1.1	195.10 #	24 #	24 #	24 #
Minimum:	1.4	11.3	1,866.1	1.0	7.50	1	1	1
Maximum:	1.6	13.3	2,261.1	1.1	9.00	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/12/2014 00:00	1.6	11.8	2,177.1	1.0	8.70	1	1	1
09/12/2014 01:00	1.4	12.8	1,933.6	1.0	7.70	1	1	1
09/12/2014 02:00	1.4	12.3	2,020.5	1.0	8.10	1	1	1
09/12/2014 03:00	1.4	12.2	2,048.6	0.9	6.10	1	1	1
09/12/2014 04:00	1.6	11.5	2,249.6	1.0	9.00	1	1	1
09/12/2014 05:00	1.6	11.7	2,218.6	1.0	8.90	1	1	1
09/12/2014 06:00	1.5	11.6	2,260.9	1.0	9.00	1	1	1
09/12/2014 07:00	1.6	11.6	2,238.1	1.0	9.00	1	1	1
09/12/2014 08:00	1.6	11.9	2,161.1	1.0	8.60	1	1	1
09/12/2014 09:00	1.6	11.5	2,242.5	1.0	9.00	1	1	1
09/12/2014 10:00	1.6	11.6	2,227.8	1.0	8.90	1	1	1
09/12/2014 11:00	1.6	11.5	2,220.7	1.0	8.90	1	1	1
09/12/2014 12:00	1.6	11.4	2,232.4	1.0	8.90	1	1	1
09/12/2014 13:00	1.6	11.3	2,238.3	1.0	9.00	1	1	1
09/12/2014 14:00	1.6	11.4	2,213.7	1.0	8.90	1	1	1
09/12/2014 15:00	1.6	11.4	2,210.8	1.0	8.80	1	1	1
09/12/2014 16:00	1.6	11.4	2,204.4	1.0	8.80	1	1	1
09/12/2014 17:00	1.6	11.3	2,226.8	1.0	8.90	1	1	1
09/12/2014 18:00	1.6	11.4	2,233.1	1.0	8.90	1	1	1
09/12/2014 19:00	1.6	11.3	2,254.5	1.0	9.00	1	1	1
09/12/2014 20:00	1.6	11.7	2,196.1	1.0	8.80	1	1	1
09/12/2014 21:00	1.5	12.0	2,118.2	1.0	8.50	1	1	1
09/12/2014 22:00	1.5	12.6	1,977.0	1.1	7.90	1	1	1
09/12/2014 23:00	1.5	12.7	1,978.2	1.1	7.90	1	1	1
Average/Sum#:	1.6	11.7	2,170.1	1.0	206.20 #	24 #	24 #	24 #
Minimum:	1.4	11.3	1,933.6	0.9	6.10	1	1	1
Maximum:	1.6	12.8	2,260.9	1.1	9.00	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report
CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/13/2014 00:00	1.5	12.7	1,971.4	1.1	7.90	1	1	1
09/13/2014 01:00	1.4	12.9	1,940.6	1.0	7.80	1	1	1
09/13/2014 02:00	1.4	13.4	1,793.4	1.1	7.20	1	1	1
09/13/2014 03:00	1.4	13.2	1,866.2	1.1	7.50	1	1	1
09/13/2014 04:00	1.3	13.3	1,790.6	1.0	7.20	1	1	1
09/13/2014 05:00	1.2	13.9	1,261.6	1.0	5.00	1	1	0
09/13/2014 06:00	1.3	13.9	1,255.0	1.1	5.00	1	1	0
09/13/2014 07:00	1.3	13.9	1,254.4	1.1	5.00	1	1	0
09/13/2014 08:00	1.3	13.9	1,392.3	1.1	5.60	1	1	0
09/13/2014 09:00	1.2	14.0	1,514.4	1.0	6.10	1	1	0
09/13/2014 10:00	1.3	13.8	1,577.1	1.1	6.30	1	1	1
09/13/2014 11:00	1.5	12.5	2,017.7	1.1	8.10	1	1	1
09/13/2014 12:00	1.6	11.8	2,152.4	1.0	8.60	1	1	1
09/13/2014 13:00	1.5	12.2	2,037.1	1.0	8.10	1	1	1
09/13/2014 14:00	1.6	12.1	2,049.9	1.1	8.20	1	1	1
09/13/2014 15:00	1.6	11.7	2,155.8	1.0	8.60	1	1	1
09/13/2014 16:00	1.6	11.7	2,140.6	1.0	8.60	1	1	1
09/13/2014 17:00	1.6	11.8	2,107.7	1.0	8.40	1	1	1
09/13/2014 18:00	1.5	12.4	1,993.3	1.0	8.00	1	1	1
09/13/2014 19:00	1.6	12.2	2,039.3	1.1	8.20	1	1	1
09/13/2014 20:00	1.5	12.6	1,977.7	1.1	7.90	1	1	1
09/13/2014 21:00	1.5	12.6	1,971.8	1.1	7.90	1	1	1
09/13/2014 22:00	1.4	12.8	1,933.4	1.0	7.70	1	1	1
09/13/2014 23:00	1.4	12.7	1,966.1	1.0	7.90	1	1	1
Average/Sum#:	1.4	12.8	1,840.0	1.1	176.80 #	24 #	24 #	19 #
Minimum:	1.2	11.7	1,254.4	1.0	5.00	1	1	0
Maximum:	1.6	14.0	2,155.8	1.1	8.60	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/14/2014 00:00	1.4	12.9	1,918.3	1.0	7.70	1	1	1
09/14/2014 01:00	1.4	13.2	1,867.8	1.1	7.50	1	1	1
09/14/2014 02:00	1.4	13.3	1,863.4	1.1	7.50	1	1	1
09/14/2014 03:00	1.4	13.2	1,864.9	1.1	7.50	1	1	1
09/14/2014 04:00	1.3	13.3	1,801.4	1.0	7.20	1	1	1
09/14/2014 05:00	1.2	13.9	1,266.4	1.0	5.10	1	1	0
09/14/2014 06:00	1.1	13.9	1,256.6	0.9	3.80	1	1	0
09/14/2014 07:00	1.3	13.9	1,256.7	1.1	5.00	1	1	0
09/14/2014 08:00	1.2	13.9	1,439.5	1.0	5.80	1	1	0
09/14/2014 09:00	1.3	13.5	1,631.6	1.0	6.50	1	1	1
09/14/2014 10:00	1.4	12.9	1,923.7	1.0	7.70	1	1	1
09/14/2014 11:00	1.4	12.6	1,976.9	1.0	7.90	1	1	1
09/14/2014 12:00	1.6	11.4	2,233.9	1.0	8.90	1	1	1
09/14/2014 13:00	1.6	11.3	2,250.6	1.0	9.00	1	1	1
09/14/2014 14:00	1.6	11.3	2,250.5	1.0	9.00	1	1	1
09/14/2014 15:00	1.6	11.3	2,239.0	1.0	9.00	1	1	1
09/14/2014 16:00	1.6	11.3	2,230.5	1.0	8.90	1	1	1
09/14/2014 17:00	1.6	11.4	2,213.2	1.0	8.90	1	1	1
09/14/2014 18:00	1.6	11.5	2,193.8	1.0	8.80	1	1	1
09/14/2014 19:00	1.6	11.7	2,159.9	1.0	8.60	1	1	1
09/14/2014 20:00	1.6	12.0	2,108.8	1.1	8.40	1	1	1
09/14/2014 21:00	1.5	12.3	2,038.7	1.0	8.20	1	1	1
09/14/2014 22:00	1.5	12.8	1,949.4	1.1	7.80	1	1	1
09/14/2014 23:00	1.4	12.8	1,940.5	1.0	7.80	1	1	1
Average/Sum#:	1.4	12.6	1,911.5	1.0	182.50 #	24 #	24 #	20 #
Minimum:	1.1	11.3	1,256.6	0.9	3.80	1	1	0
Maximum:	1.6	13.9	2,250.6	1.1	9.00	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/15/2014 00:00	1.4	13.1	1,885.4	1.1	7.50	1	1	1
09/15/2014 01:00	1.4	13.2	1,860.5	1.1	7.40	1	1	1
09/15/2014 02:00	1.4	13.2	1,860.2	1.1	7.40	1	1	1
09/15/2014 03:00	1.4	13.2	1,862.6	1.1	7.50	1	1	1
09/15/2014 04:00	1.4	13.2	1,865.0	1.1	7.50	1	1	1
09/15/2014 05:00	1.4	13.2	1,869.1	1.1	7.50	1	1	1
09/15/2014 06:00	0.9	13.2	1,870.4	0.7	5.60	1	1	1
09/15/2014 07:00	1.4	13.1	1,888.7	1.1	7.60	1	1	1
09/15/2014 08:00	1.5	12.7	1,990.6	1.1	8.00	1	1	1
09/15/2014 09:00	1.6	11.9	2,162.6	1.0	8.70	1	1	1
09/15/2014 10:00	1.6	11.5	2,227.7	1.0	8.90	1	1	1
09/15/2014 11:00	1.6	11.4	2,237.3	1.0	8.90	1	1	1
09/15/2014 12:00	1.4	12.4	1,819.1	1.0	7.30	1	1	1
09/15/2014 13:00	1.2	14.0	1,327.6	1.0	5.30	1	1	0
09/15/2014 14:00	1.3	14.0	1,335.4	1.1	5.30	1	1	0
09/15/2014 15:00	1.5	12.6	1,938.5	1.1	7.80	1	1	1
09/15/2014 16:00	1.6	11.7	2,160.7	1.0	8.60	1	1	1
09/15/2014 17:00	1.6	11.9	2,140.7	1.0	8.60	1	1	1
09/15/2014 18:00	1.5	12.0	2,115.9	1.0	8.50	1	1	1
09/15/2014 19:00	1.5	12.2	2,091.3	1.0	8.40	1	1	1
09/15/2014 20:00	1.5	12.4	2,058.7	1.0	8.20	1	1	1
09/15/2014 21:00	1.4	12.9	1,939.8	1.0	7.80	1	1	1
09/15/2014 22:00	1.4	13.3	1,861.9	1.1	7.40	1	1	1
09/15/2014 23:00	1.4	13.2	1,871.5	1.1	7.50	1	1	1
Average/Sum#:	1.4	12.7	1,926.7	1.0	183.20 #	24 #	24 #	22 #
Minimum:	0.9	11.4	1,327.6	0.7	5.30	1	1	0
Maximum:	1.6	14.0	2,237.3	1.1	8.90	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/16/2014 00:00	1.4	13.3	1,860.5	1.1	7.40	1	1	1
09/16/2014 01:00	1.4	13.3	1,857.8	1.1	7.40	1	1	1
09/16/2014 02:00	1.3	13.7	1,573.0	1.1	6.30	1	1	1
09/16/2014 03:00	1.1	13.8	1,277.6	0.9	3.80	1	1	0
09/16/2014 04:00	1.3	13.5	1,648.3	1.0	6.60	1	1	1
09/16/2014 05:00	1.4	12.9	1,956.5	1.0	7.80	1	1	1
09/16/2014 06:00	1.4	12.8	1,970.9	1.0	7.90	1	1	1
09/16/2014 07:00	1.4	12.7	2,015.4	1.0	8.10	1	1	1
09/16/2014 08:00	1.4	12.5	2,051.0	1.0	8.20	1	1	1
09/16/2014 09:00	1.5	12.5	2,049.6	1.1	8.20	1	1	1
09/16/2014 10:00	1.5	11.7	2,218.3	1.0	8.90	1	1	1
09/16/2014 11:00	1.6	11.7	2,219.3	1.0	8.90	1	1	1
09/16/2014 12:00	1.6	11.7	2,224.3	1.0	8.90	1	1	1
09/16/2014 13:00	1.7	11.7	2,212.4	1.1	8.80	1	1	1
09/16/2014 14:00	1.6	12.4	2,043.3	1.1	8.20	1	1	1
09/16/2014 15:00	1.5	12.9	1,939.9	1.1	7.80	1	1	1
09/16/2014 16:00	1.6	12.3	2,067.4	1.1	8.30	1	1	1
09/16/2014 17:00	1.7	11.5	2,230.0	1.1	8.90	1	1	1
09/16/2014 18:00	1.7	11.5	2,232.5	1.1	8.90	1	1	1
09/16/2014 19:00	1.7	11.6	2,237.9	1.1	9.00	1	1	1
09/16/2014 20:00	1.6	11.8	2,178.1	1.0	8.70	1	1	1
09/16/2014 21:00	1.3	13.0	1,904.3	1.0	7.60	1	1	1
09/16/2014 22:00	1.2	13.5	1,690.1	1.0	6.80	1	1	1
09/16/2014 23:00	1.2	13.5	1,779.7	1.0	7.10	1	1	1
Average/Sum#:	1.5	12.6	1,976.6	1.0	188.50 #	24 #	24 #	23 #
Minimum:	1.1	11.5	1,277.6	0.9	3.80	1	1	0
Maximum:	1.7	13.8	2,237.9	1.1	9.00	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/17/2014 00:00	1.5	12.1	2,146.4	1.0	8.60	1	1	1
09/17/2014 01:00	1.6	12.1	2,132.3	1.1	8.50	1	1	1
09/17/2014 02:00	1.5	12.6	2,028.5	1.1	8.10	1	1	1
09/17/2014 03:00	1.7	11.8	2,219.9	1.1	8.90	1	1	1
09/17/2014 04:00	1.7	11.8	2,227.7	1.1	8.90	1	1	1
09/17/2014 05:00	1.7	11.9	2,198.8	1.1	8.80	1	1	1
09/17/2014 06:00	1.6	11.9	2,200.5	1.0	8.80	1	1	1
09/17/2014 07:00	1.7	11.8	2,221.9	1.1	8.90	1	1	1
09/17/2014 08:00	1.7	11.8	2,202.4	1.1	8.80	1	1	1
09/17/2014 09:00	1.7	11.8	2,181.4	1.1	8.70	1	1	1
09/17/2014 10:00	1.7	11.8	2,185.8	1.1	8.70	1	1	1
09/17/2014 11:00	1.7	11.7	2,197.7	1.1	8.80	1	1	1
09/17/2014 12:00	1.7	11.6	2,219.8	1.1	8.90	1	1	1
09/17/2014 13:00	1.7	11.6	2,204.0	1.1	8.80	1	1	1
09/17/2014 14:00	1.7	11.8	2,152.2	1.1	8.60	1	1	1
09/17/2014 15:00	1.6	12.0	2,104.5	1.1	8.40	1	1	1
09/17/2014 16:00	1.5	12.6	1,982.8	1.1	7.90	1	1	1
09/17/2014 17:00	1.5	12.6	1,980.0	1.1	7.90	1	1	1
09/17/2014 18:00	1.6	12.1	2,071.7	1.1	8.30	1	1	1
09/17/2014 19:00	1.5	12.4	2,003.1	1.0	8.00	1	1	1
09/17/2014 20:00	1.4	12.6	1,982.3	1.0	7.90	1	1	1
09/17/2014 21:00	1.1	13.1	1,862.1	0.8	5.60	1	1	1
09/17/2014 22:00	1.1	13.1	1,862.3	0.8	5.60	1	1	1
09/17/2014 23:00	1.2	13.1	1,873.5	0.9	5.60	1	1	1
Average/Sum#:	1.6	12.2	2,101.7	1.1	196.00 #	24 #	24 #	24 #
Minimum:	1.1	11.6	1,862.1	0.8	5.60	1	1	1
Maximum:	1.7	13.1	2,227.7	1.1	8.90	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/18/2014 00:00	1.4	12.7	1,979.9	1.0	7.90	1	1	1
09/18/2014 01:00	1.4	12.8	1,953.5	1.0	7.80	1	1	1
09/18/2014 02:00	1.1	13.2	1,867.8	0.8	5.60	1	1	1
09/18/2014 03:00	1.2	13.3	1,769.9	0.9	5.30	1	1	1
09/18/2014 04:00	0.9	13.8	1,572.2	0.7	4.70	1	1	0
09/18/2014 05:00	0.9	13.8	1,601.6	0.7	4.80	1	1	0
09/18/2014 06:00	0.9	13.8	1,597.0	0.7	4.80	1	1	0
09/18/2014 07:00	0.7	13.8	1,307.6	0.6	2.60	1	1	0
09/18/2014 08:00	0.8	13.8	1,417.4	0.7	2.80	1	1	0
09/18/2014 09:00	0.8	13.8	1,593.2	0.7	3.20	1	1	0
09/18/2014 10:00	0.7	13.9	1,292.0	0.6	2.60	1	1	0
09/18/2014 11:00	0.7	13.9	1,291.3	0.6	2.60	1	1	0
09/18/2014 12:00	0.9	13.9	1,483.1	0.8	4.40	1	1	0
09/18/2014 13:00	0.8	13.9	1,610.2	0.7	3.20	1	1	0
09/18/2014 14:00	1.0	13.8	1,672.3	0.8	5.00	1	1	0
09/18/2014 15:00	1.0	13.8	1,595.5	0.8	4.80	1	1	0
09/18/2014 16:00	1.1	13.4	1,725.0	0.9	5.20	1	1	1
09/18/2014 17:00	1.5	12.6	1,976.2	1.1	7.90	1	1	1
09/18/2014 18:00	1.6	12.2	2,074.7	1.1	8.30	1	1	1
09/18/2014 19:00	1.6	12.1	2,091.4	1.1	8.40	1	1	1
09/18/2014 20:00	1.4	13.0	1,882.9	1.0	7.50	1	1	1
09/18/2014 21:00	1.2	13.3	1,595.9	0.9	4.80	1	1	1
09/18/2014 22:00	0.9	13.9	1,245.0	0.8	3.70	1	1	0
09/18/2014 23:00	0.9	13.9	1,366.6	0.8	4.10	1	1	0
Average/Sum#:	1.1	13.4	1,648.4	0.8	122.00 #	24 #	24 #	10 #
Minimum:	0.7	12.1	1,245.0	0.6	2.60	1	1	0
Maximum:	1.6	13.9	2,091.4	1.1	8.40	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report
CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/19/2014 00:00	0.9	13.9	1,262.9	0.8	3.80	1	1	0
09/19/2014 01:00	0.8	13.9	1,253.8	0.7	2.50	1	1	0
09/19/2014 02:00	0.8	13.9	1,252.9	0.7	2.50	1	1	0
09/19/2014 03:00	0.9	13.9	1,320.6	0.8	4.00	1	1	0
09/19/2014 04:00	0.9	13.9	1,344.2	0.8	4.00	1	1	0
09/19/2014 05:00	1.1	13.6	1,618.6	0.9	4.90	1	1	1
09/19/2014 06:00	1.3	12.6	1,959.8	0.9	5.90	1	1	1
09/19/2014 07:00	1.4	13.3	1,862.8	1.1	7.50	1	1	1
09/19/2014 08:00	1.4	13.1	1,877.7	1.1	7.50	1	1	1
09/19/2014 09:00	1.4	13.1	1,886.8	1.1	7.50	1	1	1
09/19/2014 10:00	1.2	13.1	1,860.2	0.9	5.60	1	1	1
09/19/2014 11:00	1.1	13.1	1,857.6	0.8	5.60	1	1	1
09/19/2014 12:00	1.4	12.5	1,970.6	1.0	7.90	1	1	1
09/19/2014 13:00	1.4	12.5	1,967.0	1.0	7.90	1	1	1
09/19/2014 14:00	1.5	12.3	2,027.0	1.0	8.10	1	1	1
09/19/2014 15:00	1.7	11.2	2,233.8	1.0	8.90	1	1	1
09/19/2014 16:00	1.8	11.2	2,239.9	1.1	9.00	1	1	1
09/19/2014 17:00	1.7	11.3	2,227.5	1.0	8.90	1	1	1
09/19/2014 18:00	1.7	11.8	2,125.4	1.1	8.50	1	1	1
09/19/2014 19:00	1.3	12.7	1,939.5	0.9	5.80	1	1	1
09/19/2014 20:00	1.4	12.8	1,926.1	1.0	7.70	1	1	1
09/19/2014 21:00	1.4	12.8	1,937.0	1.0	7.70	1	1	1
09/19/2014 22:00	1.5	12.6	1,978.5	1.1	7.90	1	1	1
09/19/2014 23:00	1.5	12.4	2,029.8	1.0	8.10	1	1	1
Average/Sum#:	1.3	12.8	1,831.7	1.0	157.70 #	24 #	24 #	19 #
Minimum:	0.8	11.2	1,252.9	0.7	2.50	1	1	0
Maximum:	1.8	13.9	2,239.9	1.1	9.00	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report
CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/20/2014 00:00	1.6	12.2	2,071.1	1.1	8.30	1	1	1
09/20/2014 01:00	1.7	11.7	2,173.8	1.1	8.70	1	1	1
09/20/2014 02:00	1.5	12.5	2,001.4	1.1	8.00	1	1	1
09/20/2014 03:00	1.5	12.6	1,994.3	1.1	8.00	1	1	1
09/20/2014 04:00	1.5	12.5	2,008.9	1.1	8.00	1	1	1
09/20/2014 05:00	1.6	12.6	1,982.8	1.1	7.90	1	1	1
09/20/2014 06:00	1.5	12.6	1,995.2	1.1	8.00	1	1	1
09/20/2014 07:00	1.6	12.6	2,003.8	1.1	8.00	1	1	1
09/20/2014 08:00	1.3	13.2	1,860.3	1.0	7.40	1	1	1
09/20/2014 09:00	1.2	13.2	1,856.6	0.9	5.60	1	1	1
09/20/2014 10:00	1.1	13.1	1,854.0	0.8	5.60	1	1	1
09/20/2014 11:00	1.1	13.1	1,854.3	0.8	5.60	1	1	1
09/20/2014 12:00	1.1	13.1	1,857.1	0.8	5.60	1	1	1
09/20/2014 13:00	1.3	12.9	1,895.6	1.0	7.60	1	1	1
09/20/2014 14:00	1.3	12.8	1,907.8	0.9	5.70	1	1	1
09/20/2014 15:00	1.4	12.7	1,924.4	1.0	7.70	1	1	1
09/20/2014 16:00	1.3	13.0	1,869.7	1.0	7.50	1	1	1
09/20/2014 17:00	1.3	12.6	1,938.6	0.9	5.80	1	1	1
09/20/2014 18:00	1.3	12.6	1,951.9	0.9	5.90	1	1	1
09/20/2014 19:00	1.6	12.0	2,080.8	1.1	8.30	1	1	1
09/20/2014 20:00	1.3	12.9	1,890.5	1.0	7.60	1	1	1
09/20/2014 21:00	1.4	12.7	1,952.2	1.0	7.80	1	1	1
09/20/2014 22:00	1.2	13.1	1,861.4	0.9	5.60	1	1	1
09/20/2014 23:00	1.4	12.9	1,912.3	1.0	7.60	1	1	1
Average/Sum#:	1.4	12.7	1,945.8	1.0	171.80 #	24 #	24 #	24 #
Minimum:	1.1	11.7	1,854.0	0.8	5.60	1	1	1
Maximum:	1.7	13.2	2,173.8	1.1	8.70	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/21/2014 00:00	1.3	13.2	1,852.7	1.0	7.40	1	1	1
09/21/2014 01:00	1.2	13.2	1,851.5	0.9	5.60	1	1	1
09/21/2014 02:00	1.3	13.2	1,853.1	1.0	7.40	1	1	1
09/21/2014 03:00	1.2	13.2	1,851.6	0.9	5.60	1	1	1
09/21/2014 04:00	1.3	13.2	1,854.9	1.0	7.40	1	1	1
09/21/2014 05:00	1.3	13.2	1,853.6	1.0	7.40	1	1	1
09/21/2014 06:00	1.4	13.3	1,856.8	1.1	7.40	1	1	1
09/21/2014 07:00	1.4	13.2	1,860.5	1.1	7.40	1	1	1
09/21/2014 08:00	1.3	13.2	1,852.6	1.0	7.40	1	1	1
09/21/2014 09:00	1.2	13.2	1,849.1	0.9	5.50	1	1	1
09/21/2014 10:00	1.1	13.2	1,849.3	0.8	5.50	1	1	1
09/21/2014 11:00	1.2	13.2	1,726.8	0.9	5.20	1	1	1
09/21/2014 12:00	0.8	13.8	1,257.2	0.7	2.50	1	1	0
09/21/2014 13:00	0.9	13.9	1,248.9	0.8	3.70	1	1	0
09/21/2014 14:00	0.9	13.9	1,255.8	0.8	3.80	1	1	0
09/21/2014 15:00	0.9	13.9	1,267.5	0.8	3.80	1	1	0
09/21/2014 16:00	0.9	13.9	1,283.0	0.8	3.80	1	1	0
09/21/2014 17:00	1.0	13.5	1,707.2	0.8	5.10	1	1	1
09/21/2014 18:00	1.2	13.0	1,880.5	0.9	5.60	1	1	1
09/21/2014 19:00	1.4	12.8	1,937.6	1.0	7.80	1	1	1
09/21/2014 20:00	1.3	13.2	1,855.9	1.0	7.40	1	1	1
09/21/2014 21:00	1.3	13.2	1,855.0	1.0	7.40	1	1	1
09/21/2014 22:00	1.1	13.5	1,523.4	0.9	4.60	1	1	1
09/21/2014 23:00	0.8	13.8	1,249.0	0.7	2.50	1	1	0
Average/Sum#:	1.2	13.4	1,684.7	0.9	137.20 #	24 #	24 #	18 #
Minimum:	0.8	12.8	1,248.9	0.7	2.50	1	1	0
Maximum:	1.4	13.9	1,937.6	1.1	7.80	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/22/2014 00:00	0.8	13.8	1,249.5	0.7	2.50	1	1	0
09/22/2014 01:00	0.9	13.8	1,248.0	0.7	3.70	1	1	0
09/22/2014 02:00	0.9	13.8	1,275.3	0.7	3.80	1	1	0
09/22/2014 03:00	1.3	13.5	1,693.8	1.0	6.80	1	1	1
09/22/2014 04:00	1.4	13.2	1,865.1	1.1	7.50	1	1	1
09/22/2014 05:00	1.4	12.9	1,937.3	1.0	7.70	1	1	1
09/22/2014 06:00	1.5	12.3	2,047.8	1.0	8.20	1	1	1
09/22/2014 07:00	0.9	13.8	1,394.5	0.7	4.20	1	1	1
09/22/2014 08:00	0.9	13.8	1,279.9	0.7	3.80	1	1	0
09/22/2014 09:00	0.9	13.8	1,279.9	0.7	3.80	1	1	0
09/22/2014 10:00	0.9	13.9	1,293.0	0.8	3.90	1	1	0
09/22/2014 11:00	0.9	13.9	1,414.9	0.8	4.20	1	1	0
09/22/2014 12:00	1.1	13.7	1,718.4	0.9	5.20	1	1	0
09/22/2014 13:00	1.0	13.7	1,691.5	0.8	5.10	1	1	0
09/22/2014 14:00	1.1	13.6	1,733.9	0.9	5.20	1	1	0
09/22/2014 15:00	1.1	13.6	1,728.7	0.9	5.20	1	1	0
09/22/2014 16:00	1.1	13.6	1,727.2	0.9	5.20	1	1	0
09/22/2014 17:00	1.1	13.6	1,729.5	0.9	5.20	1	1	0
09/22/2014 18:00	1.1	13.6	1,735.4	0.9	5.20	1	1	0
09/22/2014 19:00	1.1	13.6	1,741.8	0.9	5.20	1	1	0
09/22/2014 20:00	1.1	13.6	1,734.6	0.9	5.20	1	1	0
09/22/2014 21:00	1.1	13.7	1,707.3	0.9	5.10	1	1	0
09/22/2014 22:00	1.0	13.8	1,544.3	0.8	4.60	1	1	0
09/22/2014 23:00	1.1	13.8	1,663.0	0.9	5.00	1	1	0
Average/Sum#:	1.1	13.6	1,601.4	0.9	121.50 #	24 #	24 #	5 #
Minimum:	0.8	12.3	1,248.0	0.7	2.50	1	1	0
Maximum:	1.5	13.9	2,047.8	1.1	8.20	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/23/2014 00:00	1.1	13.8	1,623.0	0.9	4.90	1	1	0
09/23/2014 01:00	1.1	13.9	1,587.7	0.9	4.80	1	1	0
09/23/2014 02:00	1.1	13.9	1,578.2	0.9	4.70	1	1	0
09/23/2014 03:00	1.2	13.8	1,683.8	1.0	6.70	1	1	0
09/23/2014 04:00	1.2	13.7	1,716.8	1.0	6.90	1	1	0
09/23/2014 05:00	1.1	13.7	1,719.4	0.9	5.20	1	1	0
09/23/2014 06:00	1.1	13.7	1,783.9	0.9	5.40	1	1	0
09/23/2014 07:00	1.1	13.7	1,679.9	0.9	5.00	1	1	0
09/23/2014 08:00	0.6	13.8	1,303.8	0.5	2.60	1	1	0
09/23/2014 09:00	0.0	0.0	1,288.0	0.0	0.00	1	1	0
09/23/2014 10:00	0.0	0.0	1,281.1	0.0	0.00	1	1	0
09/23/2014 11:00	0.0	0.0	1,467.5	0.0	0.00	1	1	0
09/23/2014 12:00	0.0	0.0	1,659.6	0.0	0.00	1	1	0
09/23/2014 13:00	1.0	13.7	1,648.3	0.8	4.90	1	1	0
09/23/2014 14:00	1.1	13.7	1,743.6	0.9	5.20	1	1	0
09/23/2014 15:00	1.2	13.7	1,743.3	1.0	7.00	1	1	0
09/23/2014 16:00	1.1	13.7	1,736.8	0.9	5.20	1	1	0
09/23/2014 17:00	1.1	13.6	1,737.3	0.9	5.20	1	1	0
09/23/2014 18:00	1.1	13.7	1,745.6	0.9	5.20	1	1	0
09/23/2014 19:00	1.1	13.7	1,749.0	0.9	5.20	1	1	0
09/23/2014 20:00	1.0	13.7	1,696.1	0.8	5.10	1	1	0
09/23/2014 21:00	1.1	13.6	1,753.1	0.9	5.30	1	1	0
09/23/2014 22:00	1.1	13.6	1,750.3	0.9	5.30	1	1	0
09/23/2014 23:00	1.1	13.6	1,757.2	0.9	5.30	1	1	0
Average/Sum#:	1.1	13.7	1,643.1	0.9	105.10 #	24 #	24 #	0 #
Minimum:	0.6	13.6	1,281.1	0.5	2.60	1	1	0
Maximum:	1.2	13.9	1,783.9	1.0	7.00	1	1	0
%SI	16.7	16.7	0.0	16.7	16.67	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/24/2014 00:00	1.0	13.6	1,765.1	0.8	5.30	1	1	0
09/24/2014 01:00	1.0	13.6	1,770.3	0.8	5.30	1	1	0
09/24/2014 02:00	1.0	13.6	1,768.2	0.8	5.30	1	1	0
09/24/2014 03:00	0.9	13.7	1,762.1	0.7	5.30	1	1	0
09/24/2014 04:00	1.0	13.6	1,746.4	0.8	5.20	1	1	0
09/24/2014 05:00	0.9	13.7	1,676.6	0.7	5.00	1	1	0
09/24/2014 06:00	1.2	13.6	1,780.5	1.0	7.10	1	1	0
09/24/2014 07:00	1.0	13.7	1,716.3	0.8	5.10	1	1	0
09/24/2014 08:00	0.7	13.8	1,596.2	0.6	3.20	1	1	0
09/24/2014 09:00	0.8	13.7	1,724.8	0.7	3.40	1	1	0
09/24/2014 10:00	0.9	13.6	1,753.2	0.7	5.30	1	1	0
09/24/2014 11:00	0.8	13.6	1,747.8	0.6	3.50	1	1	0
09/24/2014 12:00	0.8	13.6	1,742.3	0.6	3.50	1	1	0
09/24/2014 13:00	0.8	13.6	1,736.0	0.6	3.50	1	1	0
09/24/2014 14:00	0.8	13.7	1,733.3	0.7	3.50	1	1	0
09/24/2014 15:00	0.9	13.7	1,730.8	0.7	5.20	1	1	0
09/24/2014 16:00	0.8	13.7	1,730.9	0.7	3.50	1	1	0
09/24/2014 17:00	0.9	13.6	1,741.9	0.7	5.20	1	1	0
09/24/2014 18:00	1.0	13.6	1,751.2	0.8	5.30	1	1	0
09/24/2014 19:00	0.9	13.6	1,753.1	0.7	5.30	1	1	0
09/24/2014 20:00	1.0	13.6	1,762.2	0.8	5.30	1	1	0
09/24/2014 21:00	1.0	13.6	1,770.9	0.8	5.30	1	1	0
09/24/2014 22:00	1.1	13.6	1,773.3	0.9	5.30	1	1	0
09/24/2014 23:00	1.0	13.7	1,775.7	0.8	5.30	1	1	0
Average/Sum#:	0.9	13.6	1,742.0	0.7	115.20 #	24 #	24 #	0 #
Minimum:	0.7	13.6	1,596.2	0.6	3.20	1	1	0
Maximum:	1.2	13.8	1,780.5	1.0	7.10	1	1	0
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/25/2014 00:00	1.0	13.6	1,774.7	0.8	5.30	1	1	0
09/25/2014 01:00	1.0	13.6	1,776.5	0.8	5.30	1	1	0
09/25/2014 02:00	1.1	13.6	1,778.7	0.9	5.30	1	1	0
09/25/2014 03:00	1.0	13.7	1,736.1	0.8	5.20	1	1	0
09/25/2014 04:00	0.9	13.6	1,778.9	0.7	5.30	1	1	0
09/25/2014 05:00	0.8	13.7	1,741.1	0.7	3.50	1	1	0
09/25/2014 06:00	1.0	13.6	1,781.3	0.8	5.30	1	1	0
09/25/2014 07:00	0.8	13.7	1,759.3	0.7	3.50	1	1	0
09/25/2014 08:00	0.8	13.6	1,788.5	0.6	3.60	1	1	0
09/25/2014 09:00	0.7	13.7	1,772.0	0.6	3.50	1	1	0
09/25/2014 10:00	0.7	13.7	1,753.6	0.6	3.50	1	1	0
09/25/2014 11:00	0.8	13.6	1,774.8	0.6	3.50	1	1	0
09/25/2014 12:00	0.8	13.6	1,760.4	0.6	3.50	1	1	0
09/25/2014 13:00	1.2	12.4	2,064.9	0.8	6.20	1	1	1
09/25/2014 14:00	1.6	11.9	2,176.9	1.0	8.70	1	1	1
09/25/2014 15:00	1.7	11.6	2,219.4	1.1	8.90	1	1	1
09/25/2014 16:00	1.3	12.8	1,970.5	0.9	5.90	1	1	1
09/25/2014 17:00	1.4	12.5	2,050.8	1.0	8.20	1	1	1
09/25/2014 18:00	1.5	12.3	2,088.0	1.0	8.40	1	1	1
09/25/2014 19:00	1.5	12.2	2,100.8	1.0	8.40	1	1	1
09/25/2014 20:00	1.3	12.9	1,952.9	1.0	7.80	1	1	1
09/25/2014 21:00	1.3	13.0	1,923.5	1.0	7.70	1	1	1
09/25/2014 22:00	1.4	12.9	1,970.9	1.0	7.90	1	1	1
09/25/2014 23:00	1.5	12.4	2,087.8	1.0	8.40	1	1	1
Average/Sum#:	1.1	13.1	1,899.3	0.8	142.80 #	24 #	24 #	11 #
Minimum:	0.7	11.6	1,736.1	0.6	3.50	1	1	0
Maximum:	1.7	13.7	2,219.4	1.1	8.90	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/26/2014 00:00	1.4	12.9	1,978.9	1.0	7.90	1	1	1
09/26/2014 01:00	1.3	12.9	1,991.5	1.0	8.00	1	1	1
09/26/2014 02:00	1.4	13.1	1,931.9	1.1	7.70	1	1	1
09/26/2014 03:00	1.4	13.0	1,959.3	1.0	7.80	1	1	1
09/26/2014 04:00	1.7	11.9	2,212.8	1.1	8.90	1	1	1
09/26/2014 05:00	1.7	11.8	2,237.1	1.1	8.90	1	1	1
09/26/2014 06:00	1.6	11.8	2,254.1	1.0	9.00	1	1	1
09/26/2014 07:00	1.5	12.4	2,091.7	1.0	8.40	1	1	1
09/26/2014 08:00	1.3	13.2	1,894.7	1.0	7.60	1	1	1
09/26/2014 09:00	1.4	12.7	2,020.3	1.0	8.10	1	1	1
09/26/2014 10:00	1.4	12.6	2,048.9	1.0	8.20	1	1	1
09/26/2014 11:00	1.4	12.8	1,995.9	1.0	8.00	1	1	1
09/26/2014 12:00	1.3	13.1	1,903.8	1.0	7.60	1	1	1
09/26/2014 13:00	1.3	13.3	1,874.7	1.0	7.50	1	1	1
09/26/2014 14:00	1.3	13.3	1,878.7	1.0	7.50	1	1	1
09/26/2014 15:00	1.2	13.3	1,871.7	0.9	5.60	1	1	1
09/26/2014 16:00	1.2	13.3	1,874.3	0.9	5.60	1	1	1
09/26/2014 17:00	1.3	13.0	1,943.6	1.0	7.80	1	1	1
09/26/2014 18:00	1.4	13.1	1,916.6	1.1	7.70	1	1	1
09/26/2014 19:00	1.3	13.3	1,880.3	1.0	7.50	1	1	1
09/26/2014 20:00	1.4	13.3	1,882.9	1.1	7.50	1	1	1
09/26/2014 21:00	1.4	13.0	1,939.6	1.0	7.80	1	1	1
09/26/2014 22:00	1.4	13.2	1,906.3	1.1	7.60	1	1	1
09/26/2014 23:00	1.5	12.6	2,050.1	1.1	8.20	1	1	1
Average/Sum#:	1.4	12.9	1,980.8	1.0	186.40 #	24 #	24 #	24 #
Minimum:	1.2	11.8	1,871.7	0.9	5.60	1	1	1
Maximum:	1.7	13.3	2,254.1	1.1	9.00	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/27/2014 00:00	1.5	12.4	2,081.7	1.0	8.30	1	1	1
09/27/2014 01:00	1.6	12.1	2,156.4	1.1	8.60	1	1	1
09/27/2014 02:00	1.4	12.9	1,983.3	1.0	7.90	1	1	1
09/27/2014 03:00	1.4	13.0	1,936.8	1.0	7.70	1	1	1
09/27/2014 04:00	1.4	13.2	1,907.4	1.1	7.60	1	1	1
09/27/2014 05:00	1.5	13.1	1,933.0	1.1	7.70	1	1	1
09/27/2014 06:00	1.3	13.1	1,927.7	1.0	7.70	1	1	1
09/27/2014 07:00	1.1	13.5	1,600.0	0.9	4.80	1	1	1
09/27/2014 08:00	0.7	13.8	1,274.4	0.6	2.50	1	1	0
09/27/2014 09:00	0.9	13.8	1,350.2	0.7	4.10	1	1	0
09/27/2014 10:00	0.9	13.9	1,287.6	0.8	3.90	1	1	0
09/27/2014 11:00	0.9	13.9	1,260.9	0.8	3.80	1	1	0
09/27/2014 12:00	0.9	13.9	1,258.7	0.8	3.80	1	1	0
09/27/2014 13:00	0.9	13.9	1,258.7	0.8	3.80	1	1	0
09/27/2014 14:00	0.9	13.9	1,259.5	0.8	3.80	1	1	0
09/27/2014 15:00	0.9	13.9	1,257.4	0.8	3.80	1	1	0
09/27/2014 16:00	0.9	13.9	1,253.6	0.8	3.80	1	1	0
09/27/2014 17:00	1.1	13.5	1,620.3	0.9	4.90	1	1	1
09/27/2014 18:00	1.6	11.8	2,198.6	1.0	8.80	1	1	1
09/27/2014 19:00	1.4	12.7	1,977.7	1.0	7.90	1	1	1
09/27/2014 20:00	1.3	13.0	1,910.9	1.0	7.60	1	1	1
09/27/2014 21:00	1.4	12.8	1,969.5	1.0	7.90	1	1	1
09/27/2014 22:00	1.2	13.3	1,856.7	0.9	5.60	1	1	1
09/27/2014 23:00	1.3	13.2	1,884.5	1.0	7.50	1	1	1
Average/Sum#:	1.2	13.3	1,683.6	0.9	143.80 #	24 #	24 #	15 #
Minimum:	0.7	11.8	1,253.6	0.6	2.50	1	1	0
Maximum:	1.6	13.9	2,198.6	1.1	8.80	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/28/2014 00:00	1.0	13.5	1,464.0	0.8	4.40	1	1	1
09/28/2014 01:00	0.9	13.9	1,256.6	0.8	3.80	1	1	0
09/28/2014 02:00	0.9	13.9	1,256.2	0.8	3.80	1	1	0
09/28/2014 03:00	1.1	13.9	1,520.4	0.9	4.60	1	1	0
09/28/2014 04:00	1.2	13.3	1,839.8	0.9	5.50	1	1	1
09/28/2014 05:00	1.4	12.7	2,003.5	1.0	8.00	1	1	1
09/28/2014 06:00	1.4	12.6	2,027.7	1.0	8.10	1	1	1
09/28/2014 07:00	1.4	13.2	1,883.3	1.1	7.50	1	1	1
09/28/2014 08:00	1.4	13.1	1,904.5	1.1	7.60	1	1	1
09/28/2014 09:00	0.8	13.8	1,312.3	0.7	2.60	1	1	1
09/28/2014 10:00	0.7	13.8	1,257.5	0.6	2.50	1	1	0
09/28/2014 11:00	1.0	13.6	1,549.2	0.8	4.60	1	1	1
09/28/2014 12:00	1.3	13.3	1,867.7	1.0	7.50	1	1	1
09/28/2014 13:00	1.2	13.2	1,866.3	0.9	5.60	1	1	1
09/28/2014 14:00	1.2	13.3	1,866.2	0.9	5.60	1	1	1
09/28/2014 15:00	1.3	13.3	1,866.7	1.0	7.50	1	1	1
09/28/2014 16:00	1.4	12.9	1,953.9	1.0	7.80	1	1	1
09/28/2014 17:00	1.5	12.3	2,092.7	1.0	8.40	1	1	1
09/28/2014 18:00	1.7	11.5	2,276.5	1.1	9.10	1	1	1
09/28/2014 19:00	1.7	11.4	2,285.0	1.1	9.10	1	1	1
09/28/2014 20:00	1.4	12.6	2,018.6	1.0	8.10	1	1	1
09/28/2014 21:00	1.4	12.9	1,966.0	1.0	7.90	1	1	1
09/28/2014 22:00	1.4	12.9	1,954.5	1.0	7.80	1	1	1
09/28/2014 23:00	1.3	13.3	1,865.2	1.0	7.50	1	1	1
Average/Sum#:	1.3	13.1	1,798.1	0.9	154.90 #	24 #	24 #	20 #
Minimum:	0.7	11.4	1,256.2	0.6	2.50	1	1	0
Maximum:	1.7	13.9	2,285.0	1.1	9.10	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report

CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/29/2014 00:00	1.3	13.4	1,842.9	1.0	7.40	1	1	1
09/29/2014 01:00	1.3	13.5	1,841.4	1.0	7.40	1	1	1
09/29/2014 02:00	1.3	13.5	1,842.2	1.0	7.40	1	1	1
09/29/2014 03:00	1.3	13.5	1,842.2	1.0	7.40	1	1	1
09/29/2014 04:00	1.4	13.3	1,869.2	1.1	7.50	1	1	1
09/29/2014 05:00	1.4	13.2	1,883.5	1.1	7.50	1	1	1
09/29/2014 06:00	1.2	12.7	2,018.6	0.9	6.10	1	1	1
09/29/2014 07:00	1.4	13.2	1,866.3	1.1	7.50	1	1	1
09/29/2014 08:00	1.4	13.2	1,866.1	1.1	7.50	1	1	1
09/29/2014 09:00	1.2	13.2	1,874.7	0.9	5.60	1	1	1
09/29/2014 10:00	1.2	13.2	1,882.6	0.9	5.60	1	1	1
09/29/2014 11:00	1.3	13.2	1,879.4	1.0	7.50	1	1	1
09/29/2014 12:00	0.8	13.8	1,289.0	0.7	2.60	1	1	0
09/29/2014 13:00	0.8	13.9	1,257.8	0.7	2.50	1	1	0
09/29/2014 14:00	1.0	13.6	1,528.8	0.8	4.60	1	1	1
09/29/2014 15:00	1.1	13.2	1,869.4	0.8	5.60	1	1	1
09/29/2014 16:00	1.3	13.0	1,919.4	1.0	7.70	1	1	1
09/29/2014 17:00	1.4	12.6	2,003.4	1.0	8.00	1	1	1
09/29/2014 18:00	1.7	11.8	2,179.1	1.1	8.70	1	1	1
09/29/2014 19:00	1.6	12.0	2,140.4	1.1	8.60	1	1	1
09/29/2014 20:00	1.3	12.8	1,948.4	0.9	5.80	1	1	1
09/29/2014 21:00	1.2	13.3	1,725.5	0.9	5.20	1	1	1
09/29/2014 22:00	0.8	13.8	1,269.7	0.7	2.50	1	1	0
09/29/2014 23:00	0.9	13.8	1,302.7	0.7	3.90	1	1	0
Average/Sum#:	1.2	13.2	1,789.3	0.9	150.10 #	24 #	24 #	20 #
Minimum:	0.8	11.8	1,257.8	0.7	2.50	1	1	0
Maximum:	1.7	13.9	2,179.1	1.1	8.70	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

Daily Summary Report
CT2 - NOx

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:28 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2 NOx, Ppm 1 Hour(s)	Unit CT2 O2, Dry, Pct 1 Hour(s)	Unit CT2 Hr, MBtuPerHr 1 Hour(s)	Unit CT2 NOx, Ppmvdc 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)	Unit CT2 DBOn, TF 1 Hour(s)
09/30/2014 00:00	0.8	13.8	1,258.2	0.7	2.50	1	1	0
09/30/2014 01:00	0.8	13.8	1,259.2	0.7	2.50	1	1	0
09/30/2014 02:00	0.8	13.8	1,259.5	0.7	2.50	1	1	0
09/30/2014 03:00	0.8	13.8	1,260.2	0.7	2.50	1	1	0
09/30/2014 04:00	0.9	13.8	1,380.0	0.7	4.10	1	1	0
09/30/2014 05:00	1.1	13.4	1,650.0	0.9	5.00	1	1	1
09/30/2014 06:00	1.4	13.2	1,898.7	1.1	7.60	1	1	1
09/30/2014 07:00	1.5	13.2	1,872.1	1.1	7.50	1	1	1
09/30/2014 08:00	1.3	13.2	1,873.0	1.0	7.50	1	1	1
09/30/2014 09:00	1.4	13.2	1,869.8	1.1	7.50	1	1	1
09/30/2014 10:00	0.8	13.8	1,260.8	0.7	2.50	1	1	0
09/30/2014 11:00	1.0	13.9	1,257.9	0.8	3.80	1	1	0
09/30/2014 12:00	1.1	13.6	1,635.9	0.9	4.90	1	1	1
09/30/2014 13:00	1.2	13.2	1,869.1	0.9	5.60	1	1	1
09/30/2014 14:00	1.2	13.2	1,871.6	0.9	5.60	1	1	1
09/30/2014 15:00	1.2	13.2	1,876.2	0.9	5.60	1	1	1
09/30/2014 16:00	1.3	13.1	1,891.4	1.0	7.60	1	1	1
09/30/2014 17:00	1.3	13.2	1,881.3	1.0	7.50	1	1	1
09/30/2014 18:00	1.5	12.6	2,035.9	1.1	8.10	1	1	1
09/30/2014 19:00	1.6	12.2	2,110.5	1.1	8.40	1	1	1
09/30/2014 20:00	1.4	13.3	1,872.6	1.1	7.50	1	1	1
09/30/2014 21:00	1.1	13.7	1,470.8	0.9	4.40	1	1	1
09/30/2014 22:00	1.3	13.9	1,262.4	1.1	5.00	1	1	0
09/30/2014 23:00	1.3	13.9	1,261.3	1.1	5.00	1	1	0
Average/Sum#:	1.2	13.4	1,630.8	0.9	130.70 #	24 #	24 #	15 #
Minimum:	0.8	12.2	1,257.9	0.7	2.50	1	1	0
Maximum:	1.6	13.9	2,110.5	1.1	8.40	1	1	1
%SI	0.0	0.0	0.0	0.0	0.00	0	0	0

ATTACHMENT 7
Hourly Emissions CO (AQ-16)

Excess Emission Report

CT1 - CO Lb 1-Day Block Average

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:04 **Location:** Maxwell, CA

Tag Name: CT1_CO_Lb_1D
Total Operating Time: 1,558.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 650.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,558.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

CT2 - CO Lb 1-Day Block Average

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:04 **Location:** Maxwell, CA

Tag Name: CT2_CO_Lb_1D
Total Operating Time: 1,577.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 631.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,577.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Daily Summary Report

CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/01/2014 00:00	0.8	13.1	1,831.5	0.6	2.5	1	1	1
07/01/2014 01:00	0.4	13.5	1,573.7	0.5	1.1	1	1	1
07/01/2014 02:00	0.5	13.4	1,558.2	0.4	1.4	1	1	1
07/01/2014 03:00	0.3	13.7	1,241.5	0.3	0.7	1	1	0
07/01/2014 04:00	0.4	13.7	1,282.1	0.3	0.9	1	1	0
07/01/2014 05:00	0.6	13.4	1,556.7	0.3	1.6	1	1	1
07/01/2014 06:00	0.7	13.0	1,889.6	0.4	2.2	1	1	1
07/01/2014 07:00	0.7	13.0	1,879.9	0.5	2.2	1	1	1
07/01/2014 08:00	0.8	12.9	1,906.6	0.5	2.5	1	1	1
07/01/2014 09:00	0.8	12.8	1,916.8	0.6	2.5	1	1	1
07/01/2014 10:00	0.7	12.9	1,874.0	0.6	2.2	1	1	1
07/01/2014 11:00	0.6	13.0	1,842.0	0.5	1.8	1	1	1
07/01/2014 12:00	0.7	13.0	1,870.3	0.5	2.2	1	1	1
07/01/2014 13:00	0.8	12.8	1,887.0	0.5	2.5	1	1	1
07/01/2014 14:00	0.9	12.8	1,894.5	0.6	2.8	1	1	1
07/01/2014 15:00	0.9	12.7	1,896.5	0.6	2.7	1	1	1
07/01/2014 16:00	1.0	12.1	2,019.6	0.7	3.0	1	1	1
07/01/2014 17:00	0.8	11.6	2,122.6	0.6	2.4	1	1	1
07/01/2014 18:00	0.7	11.7	2,106.2	0.5	2.1	1	1	1
07/01/2014 19:00	0.6	12.9	1,871.4	0.4	1.9	1	1	1
07/01/2014 20:00	0.7	13.0	1,859.7	0.4	2.2	1	1	1
07/01/2014 21:00	0.6	13.1	1,843.1	0.5	1.9	1	1	1
07/01/2014 22:00	0.7	13.2	1,840.7	0.5	2.2	1	1	1
07/01/2014 23:00	0.7	13.3	1,840.6	0.5	2.2	1	1	1
Average/Sum#:	0.7	12.9	1,808.5	0.5	49.7 #	24 #	24 #	22 #
Minimum:	0.3	11.6	1,241.5	0.3	0.7	1	1	0
Maximum:	1.0	13.7	2,122.6	0.7	3.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/02/2014 00:00	0.7	13.3	1,841.4	0.5	2.2	1	1	1
07/02/2014 01:00	0.6	13.3	1,842.9	0.5	1.9	1	1	1
07/02/2014 02:00	0.6	13.3	1,842.6	0.5	1.9	1	1	1
07/02/2014 03:00	0.6	13.3	1,842.4	0.5	1.9	1	1	1
07/02/2014 04:00	0.7	13.1	1,910.0	0.5	2.3	1	1	1
07/02/2014 05:00	1.0	12.4	2,058.3	0.6	3.2	1	1	1
07/02/2014 06:00	0.8	12.6	1,983.1	0.6	2.5	1	1	1
07/02/2014 07:00	0.6	13.2	1,866.3	0.6	1.9	1	1	1
07/02/2014 08:00	0.6	13.2	1,872.5	0.5	1.9	1	1	1
07/02/2014 09:00	0.7	13.2	1,872.9	0.5	2.2	1	1	1
07/02/2014 10:00	0.7	13.1	1,870.0	0.5	2.2	1	1	1
07/02/2014 11:00	0.7	13.0	1,874.7	0.5	2.2	1	1	1
07/02/2014 12:00	0.6	13.0	1,881.2	0.5	1.9	1	1	1
07/02/2014 13:00	0.7	12.9	1,884.7	0.5	2.2	1	1	1
07/02/2014 14:00	1.0	12.3	2,011.4	0.5	3.1	1	1	1
07/02/2014 15:00	0.8	11.6	2,122.1	0.6	2.4	1	1	1
07/02/2014 16:00	0.9	12.2	2,007.8	0.6	2.7	1	1	1
07/02/2014 17:00	0.9	12.5	1,957.3	0.6	2.8	1	1	1
07/02/2014 18:00	0.9	12.4	1,970.7	0.6	2.8	1	1	1
07/02/2014 19:00	0.9	12.6	1,949.3	0.6	2.8	1	1	1
07/02/2014 20:00	0.9	12.6	1,944.8	0.6	2.8	1	1	1
07/02/2014 21:00	0.3	13.7	1,322.6	0.5	0.7	1	1	1
07/02/2014 22:00	22.5	16.3	366.1	0.0	4.0	1	0	0
07/02/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	1.7	13.0	1,830.2	0.5	54.5 #	23 #	22 #	22 #
Minimum:	0.3	11.6	366.1	0.5	0.7	0	0	0
Maximum:	22.5	16.3	2,122.1	0.6	4.0	1	1	1
%SI	4.2	4.2	4.2	8.3	4.2	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/03/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2014 03:00	28.5	16.6	578.4	0.0	33.9	1	0	0
07/03/2014 04:00	1.5	13.8	1,503.3	0.0	4.2	1	0	0
07/03/2014 05:00	0.3	13.6	1,790.3	0.0	1.0	1	0	0
07/03/2014 06:00	0.3	13.6	1,780.8	0.0	1.0	1	0	0
07/03/2014 07:00	0.3	13.7	1,728.7	0.2	1.0	1	0	0
07/03/2014 08:00	0.3	13.7	1,581.8	0.2	0.9	1	0	1
07/03/2014 09:00	0.7	13.0	1,889.0	0.3	2.2	1	1	1
07/03/2014 10:00	0.7	13.0	1,884.1	0.4	2.2	1	1	1
07/03/2014 11:00	0.8	12.9	1,906.6	0.5	2.5	1	1	1
07/03/2014 12:00	1.0	12.5	1,969.1	0.6	3.1	1	1	1
07/03/2014 13:00	0.9	11.8	2,105.3	0.6	2.7	1	1	1
07/03/2014 14:00	0.8	11.6	2,129.2	0.6	2.4	1	1	1
07/03/2014 15:00	0.7	11.5	2,135.6	0.5	2.1	1	1	1
07/03/2014 16:00	0.7	11.5	2,139.6	0.4	2.1	1	1	1
07/03/2014 17:00	0.7	11.5	2,143.4	0.4	2.1	1	1	1
07/03/2014 18:00	0.7	11.3	2,175.3	0.4	2.1	1	1	1
07/03/2014 19:00	0.7	11.3	2,169.3	0.4	2.1	1	1	1
07/03/2014 20:00	0.8	12.0	2,048.3	0.4	2.4	1	1	1
07/03/2014 21:00	0.8	12.4	1,980.0	0.5	2.5	1	1	1
07/03/2014 22:00	0.8	12.3	2,017.9	0.5	2.5	1	1	1
07/03/2014 23:00	0.7	11.4	2,203.2	0.5	2.1	1	1	1
Average/Sum#:	2.0	12.6	1,898.1	0.4	77.1 #	21 #	15 #	16 #
Minimum:	0.3	11.3	578.4	0.2	0.9	0	0	0
Maximum:	28.5	16.6	2,203.2	0.6	33.9	1	1	1
%SI	12.5	12.5	12.5	29.2	12.5	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/04/2014 00:00	0.7	12.5	1,994.4	0.5	2.2	1	1	1
07/04/2014 01:00	0.7	12.8	1,954.7	0.5	2.2	1	1	1
07/04/2014 02:00	0.6	13.1	1,880.8	0.5	1.9	1	1	1
07/04/2014 03:00	0.6	13.3	1,841.4	0.5	1.9	1	1	1
07/04/2014 04:00	0.6	13.1	1,887.2	0.5	1.9	1	1	1
07/04/2014 05:00	0.6	13.2	1,874.0	0.5	1.9	1	1	1
07/04/2014 06:00	0.6	13.2	1,873.9	0.5	1.9	1	1	1
07/04/2014 07:00	0.6	13.2	1,871.3	0.5	1.9	1	1	1
07/04/2014 08:00	0.8	12.9	1,936.2	0.5	2.6	1	1	1
07/04/2014 09:00	0.9	12.8	1,945.0	0.6	2.9	1	1	1
07/04/2014 10:00	0.8	12.6	1,983.2	0.6	2.5	1	1	1
07/04/2014 11:00	0.7	11.3	2,211.8	0.6	2.1	1	1	1
07/04/2014 12:00	0.8	11.9	2,084.9	0.5	2.4	1	1	1
07/04/2014 13:00	0.7	12.7	1,924.4	0.5	2.2	1	1	1
07/04/2014 14:00	0.8	12.7	1,928.0	0.5	2.5	1	1	1
07/04/2014 15:00	0.8	12.6	1,932.2	0.6	2.5	1	1	1
07/04/2014 16:00	0.8	12.5	1,960.6	0.6	2.5	1	1	1
07/04/2014 17:00	0.8	12.5	1,964.6	0.6	2.5	1	1	1
07/04/2014 18:00	0.3	13.6	1,475.5	0.5	0.8	1	1	1
07/04/2014 19:00	0.2	14.0	1,281.6	0.3	0.5	1	1	0
07/04/2014 20:00	27.4	16.5	345.3	0.0	4.8	1	0	0
07/04/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	1.9	13.0	1,816.7	0.5	46.6 #	21 #	20 #	19 #
Minimum:	0.2	11.3	345.3	0.3	0.5	0	0	0
Maximum:	27.4	16.5	2,211.8	0.6	4.8	1	1	1
%SI	12.5	12.5	12.5	16.7	12.5	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/05/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2014 06:00	19.1	17.2	498.8	0.0	29.6	1	0	0
07/05/2014 07:00	36.4	15.2	838.3	0.0	70.7	1	0	0
07/05/2014 08:00	0.3	13.8	1,490.7	0.0	0.8	1	0	0
07/05/2014 09:00	0.3	13.8	1,775.1	0.0	1.0	1	0	0
07/05/2014 10:00	0.3	13.7	1,750.1	0.2	1.0	1	0	0
07/05/2014 11:00	0.3	13.8	1,498.2	0.2	0.8	1	0	0
07/05/2014 12:00	0.9	12.7	1,959.9	0.3	2.8	1	1	1
07/05/2014 13:00	1.0	12.1	2,084.0	0.5	3.1	1	1	1
07/05/2014 14:00	0.7	12.8	1,920.1	0.6	2.2	1	1	1
07/05/2014 15:00	0.8	12.8	1,900.0	0.6	2.5	1	1	1
07/05/2014 16:00	0.9	12.6	1,927.2	0.6	2.8	1	1	1
07/05/2014 17:00	0.9	12.5	1,970.8	0.6	2.8	1	1	1
07/05/2014 18:00	0.8	12.7	1,930.5	0.6	2.5	1	1	1
07/05/2014 19:00	0.6	13.0	1,870.7	0.5	1.9	1	1	1
07/05/2014 20:00	0.6	13.1	1,866.3	0.5	1.9	1	1	1
07/05/2014 21:00	0.6	13.1	1,860.0	0.5	1.9	1	1	1
07/05/2014 22:00	0.4	13.6	1,548.7	0.4	1.1	1	1	1
07/05/2014 23:00	0.3	13.6	1,767.9	0.3	1.0	1	1	0
Average/Sum#:	3.6	13.5	1,692.1	0.5	130.4 #	18 #	12 #	11 #
Minimum:	0.3	12.1	498.8	0.2	0.8	0	0	0
Maximum:	36.4	17.2	2,084.0	0.6	70.7	1	1	1
%SI	25.0	25.0	25.0	41.7	25.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/06/2014 00:00	0.3	13.6	1,775.9	0.2	1.0	1	1	0
07/06/2014 01:00	0.4	13.7	1,484.5	0.2	1.1	1	1	0
07/06/2014 02:00	34.9	16.7	308.3	0.0	5.7	1	0	0
07/06/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2014 05:00	19.6	17.5	458.8	0.0	18.5	1	0	0
07/06/2014 06:00	20.9	14.7	1,073.8	0.0	47.8	1	0	0
07/06/2014 07:00	0.3	13.7	1,767.2	0.0	1.0	1	0	0
07/06/2014 08:00	0.3	13.8	1,610.0	0.0	0.9	1	0	0
07/06/2014 09:00	0.3	13.9	1,692.7	0.2	1.0	1	0	0
07/06/2014 10:00	0.3	13.9	1,436.1	0.3	0.8	1	0	0
07/06/2014 11:00	0.7	13.3	1,749.7	0.4	2.1	1	1	1
07/06/2014 12:00	0.9	12.9	1,897.0	0.5	2.8	1	1	1
07/06/2014 13:00	0.7	13.0	1,865.2	0.6	2.2	1	1	1
07/06/2014 14:00	0.6	13.1	1,861.0	0.6	1.9	1	1	1
07/06/2014 15:00	0.6	13.0	1,857.2	0.5	1.9	1	1	1
07/06/2014 16:00	0.8	12.8	1,897.6	0.5	2.5	1	1	1
07/06/2014 17:00	0.9	12.2	2,040.0	0.5	2.8	1	1	1
07/06/2014 18:00	0.8	11.7	2,128.9	0.6	2.4	1	1	1
07/06/2014 19:00	0.9	12.1	2,051.6	0.6	2.8	1	1	1
07/06/2014 20:00	0.8	12.0	2,073.1	0.5	2.5	1	1	1
07/06/2014 21:00	0.7	12.9	1,885.8	0.5	2.2	1	1	1
07/06/2014 22:00	0.6	13.1	1,853.3	0.5	1.9	1	1	1
07/06/2014 23:00	0.7	13.2	1,835.8	0.5	2.2	1	1	1
Average/Sum#:	4.0	13.5	1,663.8	0.5	108.0 #	22 #	15 #	13 #
Minimum:	0.3	11.7	308.3	0.2	0.8	0	0	0
Maximum:	34.9	17.5	2,128.9	0.6	47.8	1	1	1
%SI	8.3	8.3	8.3	29.2	8.3	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/07/2014 00:00	0.3	13.9	1,275.2	0.4	0.7	1	1	0
07/07/2014 01:00	0.3	13.9	1,251.6	0.4	0.7	1	1	0
07/07/2014 02:00	0.3	13.9	1,279.7	0.3	0.7	1	1	0
07/07/2014 03:00	0.3	13.9	1,332.2	0.3	0.8	1	1	0
07/07/2014 04:00	0.8	13.2	1,871.1	0.4	2.6	1	1	1
07/07/2014 05:00	0.8	13.3	1,866.1	0.5	2.6	1	1	1
07/07/2014 06:00	0.8	13.3	1,847.1	0.6	2.6	1	1	1
07/07/2014 07:00	0.8	13.2	1,847.6	0.6	2.5	1	1	1
07/07/2014 08:00	0.8	13.1	1,867.4	0.6	2.5	1	1	1
07/07/2014 09:00	0.7	13.1	1,853.8	0.6	2.2	1	1	1
07/07/2014 10:00	0.8	13.0	1,867.8	0.6	2.5	1	1	1
07/07/2014 11:00	0.7	13.1	1,844.5	0.5	2.2	1	1	1
07/07/2014 12:00	0.7	13.0	1,852.1	0.5	2.2	1	1	1
07/07/2014 13:00	0.8	13.0	1,855.6	0.5	2.5	1	1	1
07/07/2014 14:00	0.7	13.0	1,849.6	0.5	2.2	1	1	1
07/07/2014 15:00	0.8	13.0	1,848.1	0.6	2.5	1	1	1
07/07/2014 16:00	0.8	12.9	1,852.3	0.6	2.4	1	1	1
07/07/2014 17:00	0.9	12.9	1,874.1	0.6	2.8	1	1	1
07/07/2014 18:00	0.9	12.9	1,887.2	0.7	2.8	1	1	1
07/07/2014 19:00	0.9	12.8	1,900.3	0.7	2.8	1	1	1
07/07/2014 20:00	0.7	13.0	1,854.0	0.6	2.2	1	1	1
07/07/2014 21:00	0.6	13.1	1,839.9	0.6	1.9	1	1	1
07/07/2014 22:00	0.6	13.3	1,677.1	0.5	1.7	1	1	1
07/07/2014 23:00	0.7	13.2	1,846.1	0.5	2.2	1	1	1
Average/Sum#:	0.7	13.2	1,755.9	0.5	50.8 #	24 #	24 #	20 #
Minimum:	0.3	12.8	1,251.6	0.3	0.7	1	1	0
Maximum:	0.9	13.9	1,900.3	0.7	2.8	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/08/2014 00:00	0.9	13.0	1,873.0	0.6	2.8	1	1	1
07/08/2014 01:00	0.7	13.2	1,850.2	0.6	2.2	1	1	1
07/08/2014 02:00	0.7	13.2	1,847.9	0.6	2.2	1	1	1
07/08/2014 03:00	0.7	13.4	1,719.7	0.5	2.1	1	1	1
07/08/2014 04:00	1.1	12.9	1,913.5	0.6	3.5	1	1	1
07/08/2014 05:00	0.8	13.2	1,854.5	0.7	2.5	1	1	1
07/08/2014 06:00	1.1	12.8	1,925.8	0.7	3.5	1	1	1
07/08/2014 07:00	0.8	13.1	1,862.4	0.7	2.5	1	1	1
07/08/2014 08:00	0.8	13.0	1,883.1	0.7	2.5	1	1	1
07/08/2014 09:00	0.7	13.1	1,858.9	0.6	2.2	1	1	1
07/08/2014 10:00	1.0	12.7	1,939.6	0.6	3.1	1	1	1
07/08/2014 11:00	1.0	12.7	1,923.0	0.6	3.1	1	1	1
07/08/2014 12:00	1.0	12.1	2,063.8	0.7	3.1	1	1	1
07/08/2014 13:00	0.9	11.4	2,193.8	0.7	2.7	1	1	1
07/08/2014 14:00	0.8	11.6	2,119.4	0.6	2.4	1	1	1
07/08/2014 15:00	0.9	11.7	2,107.0	0.6	2.7	1	1	1
07/08/2014 16:00	0.8	11.7	2,115.1	0.5	2.4	1	1	1
07/08/2014 17:00	0.8	11.7	2,122.1	0.5	2.4	1	1	1
07/08/2014 18:00	0.8	12.0	2,058.5	0.5	2.4	1	1	1
07/08/2014 19:00	0.9	12.4	1,975.7	0.5	2.8	1	1	1
07/08/2014 20:00	0.7	13.0	1,871.9	0.5	2.2	1	1	1
07/08/2014 21:00	0.6	13.1	1,856.9	0.5	1.9	1	1	1
07/08/2014 22:00	0.3	13.6	1,487.5	0.4	0.8	1	1	1
07/08/2014 23:00	0.3	13.9	1,381.5	0.3	0.8	1	1	0
Average/Sum#:	0.8	12.7	1,908.5	0.6	58.8 #	24 #	24 #	23 #
Minimum:	0.3	11.4	1,381.5	0.3	0.8	1	1	0
Maximum:	1.1	13.9	2,193.8	0.7	3.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/09/2014 00:00	0.4	13.9	1,245.0	0.3	0.9	1	1	0
07/09/2014 01:00	0.4	13.8	1,242.6	0.3	0.9	1	1	0
07/09/2014 02:00	0.4	13.8	1,241.6	0.3	0.9	1	1	0
07/09/2014 03:00	0.4	13.8	1,241.7	0.3	0.9	1	1	0
07/09/2014 04:00	0.4	13.8	1,252.1	0.3	0.9	1	1	0
07/09/2014 05:00	0.4	13.8	1,547.2	0.3	1.2	1	1	0
07/09/2014 06:00	0.5	13.5	1,651.8	0.3	1.5	1	1	1
07/09/2014 07:00	1.0	12.8	1,958.0	0.5	3.2	1	1	1
07/09/2014 08:00	0.8	12.8	1,937.8	0.6	2.5	1	1	1
07/09/2014 09:00	1.0	12.4	2,004.4	0.7	3.1	1	1	1
07/09/2014 10:00	0.9	11.9	2,102.5	0.6	2.8	1	1	1
07/09/2014 11:00	0.8	11.5	2,165.4	0.6	2.4	1	1	1
07/09/2014 12:00	0.7	11.4	2,187.1	0.5	2.1	1	1	1
07/09/2014 13:00	0.7	11.5	2,147.8	0.4	2.1	1	1	1
07/09/2014 14:00	0.8	12.2	1,998.1	0.4	2.4	1	1	1
07/09/2014 15:00	0.7	11.9	2,066.3	0.5	2.1	1	1	1
07/09/2014 16:00	0.7	11.6	2,113.3	0.5	2.1	1	1	1
07/09/2014 17:00	0.7	11.6	2,105.5	0.4	2.1	1	1	1
07/09/2014 18:00	0.8	12.1	2,008.0	0.4	2.4	1	1	1
07/09/2014 19:00	0.8	12.5	1,940.7	0.5	2.4	1	1	1
07/09/2014 20:00	0.9	12.5	1,960.0	0.6	2.8	1	1	1
07/09/2014 21:00	0.8	12.6	1,929.8	0.6	2.5	1	1	1
07/09/2014 22:00	0.8	12.8	1,909.0	0.6	2.5	1	1	1
07/09/2014 23:00	0.5	13.5	1,450.9	0.5	1.3	1	1	1
Average/Sum#:	0.7	12.7	1,808.6	0.5	48.0 #	24 #	24 #	18 #
Minimum:	0.4	11.4	1,241.6	0.3	0.9	1	1	0
Maximum:	1.0	13.9	2,187.1	0.7	3.2	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/10/2014 00:00	0.3	13.8	1,238.8	0.4	0.7	1	1	0
07/10/2014 01:00	0.3	13.8	1,238.3	0.3	0.7	1	1	0
07/10/2014 02:00	0.4	13.8	1,238.7	0.2	0.9	1	1	0
07/10/2014 03:00	0.3	13.8	1,238.2	0.2	0.7	1	1	0
07/10/2014 04:00	0.4	13.8	1,238.7	0.3	0.9	1	1	0
07/10/2014 05:00	0.4	13.8	1,240.2	0.3	0.9	1	1	0
07/10/2014 06:00	0.3	13.8	1,241.5	0.3	0.7	1	1	0
07/10/2014 07:00	0.4	13.8	1,248.1	0.3	0.9	1	1	0
07/10/2014 08:00	0.3	13.8	1,258.6	0.2	0.7	1	1	0
07/10/2014 09:00	0.6	13.5	1,563.1	0.3	1.7	1	1	1
07/10/2014 10:00	0.7	13.2	1,846.0	0.4	2.2	1	1	1
07/10/2014 11:00	0.7	13.2	1,841.5	0.5	2.2	1	1	1
07/10/2014 12:00	0.6	13.1	1,874.5	0.5	1.9	1	1	1
07/10/2014 13:00	0.8	12.9	1,889.1	0.5	2.5	1	1	1
07/10/2014 14:00	1.1	12.8	1,895.5	0.6	3.4	1	1	1
07/10/2014 15:00	1.0	12.8	1,884.3	0.7	3.1	1	1	1
07/10/2014 16:00	1.0	12.5	1,937.5	0.7	3.0	1	1	1
07/10/2014 17:00	1.1	12.8	1,897.4	0.7	3.4	1	1	1
07/10/2014 18:00	1.5	12.6	1,944.7	0.9	4.6	1	1	1
07/10/2014 19:00	1.0	13.1	1,841.3	0.9	3.1	1	1	1
07/10/2014 20:00	0.9	13.2	1,837.6	0.9	2.8	1	1	1
07/10/2014 21:00	0.8	13.2	1,849.0	0.7	2.5	1	1	1
07/10/2014 22:00	0.7	13.3	1,830.4	0.6	2.2	1	1	1
07/10/2014 23:00	0.7	13.3	1,641.4	0.5	2.0	1	1	1
Average/Sum#:	0.7	13.3	1,614.8	0.5	47.7 #	24 #	24 #	15 #
Minimum:	0.3	12.5	1,238.2	0.2	0.7	1	1	0
Maximum:	1.5	13.8	1,944.7	0.9	4.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/11/2014 00:00	0.4	13.8	1,271.9	0.4	0.9	1	0	0
07/11/2014 01:00	15.0	15.7	618.1	0.0	6.3	1	0	0
07/11/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2014 05:00	16.0	17.3	489.5	0.0	17.2	1	0	0
07/11/2014 06:00	21.7	14.5	1,039.4	0.0	46.5	1	0	0
07/11/2014 07:00	0.3	13.8	1,288.4	0.0	0.7	1	0	0
07/11/2014 08:00	0.4	13.8	1,292.3	0.0	1.0	1	0	0
07/11/2014 09:00	0.3	13.8	1,497.6	0.2	0.8	1	0	0
07/11/2014 10:00	0.3	13.9	1,298.3	0.3	0.7	1	0	0
07/11/2014 11:00	0.3	13.9	1,270.7	0.3	0.7	1	1	0
07/11/2014 12:00	0.3	13.9	1,271.3	0.3	0.7	1	1	0
07/11/2014 13:00	0.3	13.9	1,271.5	0.3	0.7	1	1	0
07/11/2014 14:00	0.3	13.9	1,273.6	0.3	0.7	1	1	0
07/11/2014 15:00	0.3	14.0	1,275.2	0.3	0.7	1	1	0
07/11/2014 16:00	0.3	14.0	1,275.8	0.3	0.7	1	1	0
07/11/2014 17:00	0.3	14.0	1,275.3	0.3	0.7	1	1	0
07/11/2014 18:00	0.3	13.9	1,271.2	0.3	0.7	1	1	0
07/11/2014 19:00	0.3	13.9	1,268.9	0.3	0.7	1	1	0
07/11/2014 20:00	0.3	13.9	1,269.3	0.3	0.7	1	1	0
07/11/2014 21:00	0.4	13.9	1,262.7	0.3	1.0	1	1	0
07/11/2014 22:00	0.4	13.8	1,262.6	0.3	0.9	1	1	0
07/11/2014 23:00	0.4	13.8	1,263.2	0.3	0.9	1	1	0
Average/Sum#:	2.8	14.2	1,205.1	0.3	83.9 #	21 #	13 #	0 #
Minimum:	0.3	13.8	489.5	0.2	0.7	0	0	0
Maximum:	21.7	17.3	1,497.6	0.4	46.5	1	1	0
%SI	12.5	12.5	12.5	33.3	12.5	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/12/2014 00:00	26.1	15.8	532.4	0.0	7.9	1	0	0
07/12/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/12/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/12/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/12/2014 11:00	22.0	16.6	619.4	0.0	36.5	1	1	0
07/12/2014 12:00	0.2	13.9	1,344.5	0.0	0.5	1	1	0
07/12/2014 13:00	0.2	13.7	1,648.0	0.0	0.6	1	1	0
07/12/2014 14:00	0.5	13.3	1,758.5	0.0	1.5	1	1	1
07/12/2014 15:00	1.1	12.0	2,045.8	0.4	3.3	1	1	1
07/12/2014 16:00	0.9	12.7	1,917.9	0.6	2.8	1	1	1
07/12/2014 17:00	0.9	12.6	1,935.3	0.6	2.8	1	1	1
07/12/2014 18:00	0.8	12.7	1,923.9	0.6	2.5	1	1	1
07/12/2014 19:00	0.6	13.0	1,861.4	0.5	1.9	1	1	1
07/12/2014 20:00	0.7	13.0	1,869.9	0.5	2.2	1	1	1
07/12/2014 21:00	1.0	12.7	1,950.9	0.5	3.1	1	1	1
07/12/2014 22:00	1.1	12.4	2,007.3	0.7	3.4	1	1	1
07/12/2014 23:00	0.9	12.7	1,946.8	0.7	2.8	1	1	1
Average/Sum#:	4.1	13.4	1,668.7	0.6	71.8 #	14 #	16 #	10 #
Minimum:	0.2	12.0	532.4	0.4	0.5	0	0	0
Maximum:	26.1	16.6	2,045.8	0.7	36.5	1	1	1
%SI	41.7	41.7	41.7	62.5	41.7	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/13/2014 00:00	0.5	13.3	1,654.0	0.6	1.4	1	1	1
07/13/2014 01:00	20.9	15.8	536.4	0.0	6.4	1	0	0
07/13/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2014 06:00	17.3	17.5	450.6	0.0	15.2	1	0	0
07/13/2014 07:00	21.4	15.1	940.5	0.0	45.8	1	0	0
07/13/2014 08:00	0.2	13.8	1,462.3	0.0	0.5	1	0	0
07/13/2014 09:00	0.2	13.7	1,737.2	0.0	0.6	1	0	0
07/13/2014 10:00	0.2	13.8	1,678.7	0.2	0.6	1	0	0
07/13/2014 11:00	0.3	13.8	1,492.9	0.2	0.8	1	0	1
07/13/2014 12:00	0.8	12.9	1,889.4	0.3	2.5	1	1	1
07/13/2014 13:00	1.0	12.1	2,020.0	0.5	3.0	1	1	1
07/13/2014 14:00	0.8	11.8	2,076.1	0.6	2.4	1	1	1
07/13/2014 15:00	0.7	11.3	2,170.6	0.5	2.1	1	1	1
07/13/2014 16:00	0.8	12.1	2,010.0	0.5	2.4	1	1	1
07/13/2014 17:00	0.8	12.3	1,978.9	0.5	2.4	1	1	1
07/13/2014 18:00	0.9	12.2	1,984.7	0.5	2.7	1	1	1
07/13/2014 19:00	0.8	12.8	1,881.4	0.6	2.5	1	1	1
07/13/2014 20:00	0.4	13.6	1,539.0	0.5	1.1	1	1	1
07/13/2014 21:00	0.5	13.3	1,755.2	0.4	1.5	1	1	1
07/13/2014 22:00	1.0	12.7	1,896.1	0.5	3.1	1	1	1
07/13/2014 23:00	0.3	13.6	1,465.0	0.4	0.8	1	1	1
Average/Sum#:	3.5	13.4	1,631.0	0.5	97.8 #	20 #	13 #	14 #
Minimum:	0.2	11.3	450.6	0.2	0.5	0	0	0
Maximum:	21.4	17.5	2,170.6	0.6	45.8	1	1	1
%SI	16.7	16.7	16.7	37.5	16.7	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/14/2014 00:00	0.2	13.9	1,379.9	0.4	0.5	1	1	0
07/14/2014 01:00	0.2	13.9	1,471.6	0.2	0.6	1	1	0
07/14/2014 02:00	0.3	13.9	1,408.9	0.2	0.8	1	1	0
07/14/2014 03:00	0.3	13.7	1,722.2	0.2	0.9	1	1	0
07/14/2014 04:00	0.4	13.7	1,726.7	0.3	1.3	1	1	0
07/14/2014 05:00	0.4	13.7	1,607.7	0.3	1.2	1	1	1
07/14/2014 06:00	1.1	12.5	2,026.1	0.5	3.5	1	1	1
07/14/2014 07:00	0.9	12.8	1,960.1	0.6	2.9	1	1	1
07/14/2014 08:00	0.7	12.9	1,897.6	0.7	2.2	1	1	1
07/14/2014 09:00	0.8	12.8	1,917.3	0.6	2.5	1	1	1
07/14/2014 10:00	0.7	13.0	1,860.8	0.5	2.2	1	1	1
07/14/2014 11:00	0.8	12.9	1,875.0	0.6	2.5	1	1	1
07/14/2014 12:00	0.9	12.8	1,883.4	0.6	2.8	1	1	1
07/14/2014 13:00	0.9	12.5	1,942.5	0.6	2.7	1	1	1
07/14/2014 14:00	0.8	11.7	2,077.2	0.6	2.4	1	1	1
07/14/2014 15:00	0.8	11.7	2,060.8	0.5	2.4	1	1	1
07/14/2014 16:00	0.8	11.9	2,017.8	0.5	2.4	1	1	1
07/14/2014 17:00	0.8	12.2	1,968.7	0.5	2.4	1	1	1
07/14/2014 18:00	0.2	13.6	1,551.8	0.4	0.6	1	1	1
07/14/2014 19:00	0.2	13.9	1,439.1	0.3	0.5	1	1	0
07/14/2014 20:00	0.3	13.7	1,629.1	0.2	0.9	1	1	0
07/14/2014 21:00	0.3	13.8	1,637.9	0.2	0.9	1	1	0
07/14/2014 22:00	0.4	13.8	1,508.1	0.2	1.1	1	1	0
07/14/2014 23:00	0.3	13.7	1,646.9	0.2	0.9	1	1	0
Average/Sum#:	0.6	13.1	1,759.1	0.4	41.1 #	24 #	24 #	14 #
Minimum:	0.2	11.7	1,379.9	0.2	0.5	1	1	0
Maximum:	1.1	13.9	2,077.2	0.7	3.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/15/2014 00:00	0.3	13.6	1,747.0	0.2	0.9	1	1	0
07/15/2014 01:00	0.3	13.6	1,773.9	0.2	1.0	1	1	0
07/15/2014 02:00	0.2	13.6	1,769.2	0.2	0.6	1	1	0
07/15/2014 03:00	0.5	13.3	1,809.2	0.3	1.6	1	1	1
07/15/2014 04:00	0.9	12.9	1,938.7	0.4	2.9	1	1	1
07/15/2014 05:00	0.9	12.6	1,989.8	0.6	2.8	1	1	1
07/15/2014 06:00	0.7	13.0	1,890.3	0.6	2.2	1	1	1
07/15/2014 07:00	0.6	13.3	1,844.4	0.5	1.9	1	1	1
07/15/2014 08:00	0.7	13.3	1,840.0	0.5	2.2	1	1	1
07/15/2014 09:00	1.0	13.2	1,851.3	0.6	3.2	1	1	1
07/15/2014 10:00	0.7	13.1	1,874.1	0.6	2.2	1	1	1
07/15/2014 11:00	0.7	13.1	1,869.6	0.6	2.2	1	1	1
07/15/2014 12:00	0.6	13.1	1,859.7	0.5	1.9	1	1	1
07/15/2014 13:00	0.6	13.2	1,855.3	0.5	1.9	1	1	1
07/15/2014 14:00	0.9	12.9	1,923.3	0.6	2.9	1	1	1
07/15/2014 15:00	0.9	12.7	1,925.1	0.6	2.8	1	1	1
07/15/2014 16:00	0.7	12.9	1,879.3	0.6	2.2	1	1	1
07/15/2014 17:00	0.9	12.8	1,908.7	0.6	2.8	1	1	1
07/15/2014 18:00	0.8	12.8	1,882.9	0.6	2.5	1	1	1
07/15/2014 19:00	0.9	12.8	1,903.6	0.7	2.8	1	1	1
07/15/2014 20:00	0.9	12.8	1,891.8	0.7	2.8	1	1	1
07/15/2014 21:00	0.9	12.8	1,901.4	0.7	2.8	1	1	1
07/15/2014 22:00	0.9	12.9	1,888.8	0.7	2.8	1	1	1
07/15/2014 23:00	1.1	12.8	1,915.0	0.7	3.4	1	1	1
Average/Sum#:	0.7	13.0	1,872.2	0.5	55.3 #	24 #	24 #	21 #
Minimum:	0.2	12.6	1,747.0	0.2	0.6	1	1	0
Maximum:	1.1	13.6	1,989.8	0.7	3.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/16/2014 00:00	0.9	12.9	1,880.1	0.7	2.8	1	1	1
07/16/2014 01:00	0.5	13.6	1,472.9	0.6	1.3	1	1	1
07/16/2014 02:00	0.3	13.8	1,421.7	0.4	0.8	1	1	0
07/16/2014 03:00	0.3	13.8	1,468.9	0.3	0.8	1	1	0
07/16/2014 04:00	0.3	13.6	1,743.9	0.2	0.9	1	1	0
07/16/2014 05:00	0.5	13.5	1,618.2	0.3	1.4	1	1	1
07/16/2014 06:00	0.6	13.4	1,709.5	0.4	1.8	1	1	1
07/16/2014 07:00	0.3	13.8	1,587.8	0.4	0.9	1	1	0
07/16/2014 08:00	0.4	13.6	1,697.8	0.3	1.2	1	1	1
07/16/2014 09:00	0.8	13.2	1,841.3	0.4	2.5	1	1	1
07/16/2014 10:00	0.6	13.2	1,844.3	0.5	1.9	1	1	1
07/16/2014 11:00	0.6	13.2	1,844.6	0.5	1.9	1	1	1
07/16/2014 12:00	0.6	13.2	1,840.2	0.5	1.9	1	1	1
07/16/2014 13:00	0.6	13.1	1,842.6	0.5	1.9	1	1	1
07/16/2014 14:00	0.7	13.0	1,849.6	0.5	2.2	1	1	1
07/16/2014 15:00	0.7	13.0	1,852.3	0.5	2.2	1	1	1
07/16/2014 16:00	0.8	12.9	1,863.8	0.5	2.5	1	1	1
07/16/2014 17:00	0.9	12.9	1,872.4	0.6	2.8	1	1	1
07/16/2014 18:00	0.8	12.9	1,867.5	0.6	2.5	1	1	1
07/16/2014 19:00	0.7	13.0	1,851.4	0.6	2.2	1	1	1
07/16/2014 20:00	0.7	13.0	1,844.4	0.5	2.2	1	1	1
07/16/2014 21:00	0.3	13.6	1,580.6	0.4	0.9	1	1	1
07/16/2014 22:00	0.4	13.5	1,698.8	0.3	1.2	1	1	1
07/16/2014 23:00	0.5	13.4	1,673.5	0.3	1.5	1	1	1
Average/Sum#:	0.6	13.3	1,740.3	0.5	42.2 #	24 #	24 #	20 #
Minimum:	0.3	12.9	1,421.7	0.2	0.8	1	1	0
Maximum:	0.9	13.8	1,880.1	0.7	2.8	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/17/2014 00:00	19.2	15.7	561.9	0.0	6.0	1	0	0
07/17/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/17/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/17/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/17/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/17/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/17/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/17/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/17/2014 08:00	17.3	17.7	421.5	0.0	11.1	1	1	0
07/17/2014 09:00	12.1	14.5	1,202.2	0.0	30.0	1	1	0
07/17/2014 10:00	0.4	13.5	1,599.6	0.0	1.1	1	1	1
07/17/2014 11:00	0.6	13.2	1,822.5	0.0	1.9	1	1	1
07/17/2014 12:00	0.5	13.2	1,818.0	0.4	1.6	1	1	1
07/17/2014 13:00	0.5	13.1	1,826.4	0.4	1.5	1	1	1
07/17/2014 14:00	0.6	13.1	1,823.4	0.4	1.9	1	1	1
07/17/2014 15:00	0.6	13.0	1,831.6	0.4	1.8	1	1	1
07/17/2014 16:00	0.7	13.0	1,837.2	0.5	2.1	1	1	1
07/17/2014 17:00	0.7	12.9	1,850.3	0.5	2.1	1	1	1
07/17/2014 18:00	1.0	12.5	1,927.1	0.6	3.0	1	1	1
07/17/2014 19:00	1.0	12.4	1,950.1	0.6	3.0	1	1	1
07/17/2014 20:00	0.7	12.9	1,857.3	0.6	2.1	1	1	1
07/17/2014 21:00	0.9	12.8	1,896.9	0.6	2.8	1	1	1
07/17/2014 22:00	0.5	13.5	1,645.9	0.5	1.5	1	1	1
07/17/2014 23:00	0.3	13.8	1,405.0	0.4	0.8	1	1	0
Average/Sum#:	3.4	13.6	1,604.5	0.5	74.3 #	17 #	18 #	13 #
Minimum:	0.3	12.4	421.5	0.4	0.8	0	0	0
Maximum:	19.2	17.7	1,950.1	0.6	30.0	1	1	1
%SI	29.2	29.2	29.2	50.0	29.2	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/18/2014 00:00	19.9	15.7	558.4	0.0	6.2	1	0	0
07/18/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/18/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/18/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/18/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/18/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/18/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/18/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/18/2014 08:00	22.5	16.4	649.6	0.0	37.3	1	1	0
07/18/2014 09:00	0.4	13.5	1,579.6	0.0	1.1	1	1	1
07/18/2014 10:00	0.6	13.2	1,851.7	0.0	1.9	1	1	1
07/18/2014 11:00	0.6	13.2	1,843.0	0.0	1.9	1	1	1
07/18/2014 12:00	0.6	13.3	1,836.9	0.5	1.9	1	1	1
07/18/2014 13:00	0.6	13.2	1,838.2	0.5	1.9	1	1	1
07/18/2014 14:00	0.5	13.2	1,835.3	0.5	1.6	1	1	1
07/18/2014 15:00	0.6	13.0	1,866.3	0.4	1.9	1	1	1
07/18/2014 16:00	0.8	12.9	1,889.4	0.5	2.5	1	1	1
07/18/2014 17:00	0.9	11.7	2,120.5	0.5	2.7	1	1	1
07/18/2014 18:00	0.8	11.5	2,137.3	0.6	2.4	1	1	1
07/18/2014 19:00	0.8	11.9	2,074.8	0.5	2.4	1	1	1
07/18/2014 20:00	0.8	12.4	1,978.8	0.5	2.5	1	1	1
07/18/2014 21:00	0.5	13.1	1,849.9	0.5	1.6	1	1	1
07/18/2014 22:00	0.4	13.5	1,600.5	0.4	1.1	1	1	1
07/18/2014 23:00	0.3	13.8	1,298.0	0.3	0.7	1	1	0
Average/Sum#:	3.0	13.3	1,694.6	0.5	71.6 #	17 #	19 #	14 #
Minimum:	0.3	11.5	558.4	0.3	0.7	0	0	0
Maximum:	22.5	16.4	2,137.3	0.6	37.3	1	1	1
%SI	29.2	29.2	29.2	50.0	29.2	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/19/2014 00:00	12.7	15.1	830.2	0.0	7.7	1	0	0
07/19/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/19/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/19/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/19/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/19/2014 05:00	16.4	17.6	436.7	0.0	12.3	1	0	0
07/19/2014 06:00	19.0	14.9	1,030.7	0.0	43.1	1	0	0
07/19/2014 07:00	0.3	13.6	1,768.0	0.0	1.0	1	0	0
07/19/2014 08:00	0.2	13.6	1,752.8	0.0	0.6	1	0	0
07/19/2014 09:00	0.2	13.7	1,739.6	0.2	0.6	1	0	0
07/19/2014 10:00	0.3	13.8	1,515.4	0.2	0.8	1	0	1
07/19/2014 11:00	1.0	12.1	2,042.1	0.4	3.1	1	1	1
07/19/2014 12:00	0.8	11.5	2,129.9	0.5	2.4	1	1	1
07/19/2014 13:00	0.6	11.1	2,212.3	0.5	1.8	1	1	1
07/19/2014 14:00	0.6	11.3	2,178.4	0.4	1.8	1	1	1
07/19/2014 15:00	0.6	11.3	2,159.6	0.4	1.8	1	1	1
07/19/2014 16:00	0.7	11.5	2,110.5	0.4	2.1	1	1	1
07/19/2014 17:00	0.7	11.6	2,100.1	0.4	2.1	1	1	1
07/19/2014 18:00	0.8	12.4	1,951.9	0.5	2.4	1	1	1
07/19/2014 19:00	0.8	11.9	2,049.3	0.5	2.4	1	1	1
07/19/2014 20:00	0.7	11.5	2,124.9	0.5	2.1	1	1	1
07/19/2014 21:00	0.9	12.2	1,991.9	0.5	2.7	1	1	1
07/19/2014 22:00	0.2	13.7	1,529.6	0.4	0.6	1	1	1
07/19/2014 23:00	0.2	13.8	1,502.3	0.3	0.6	1	1	0
Average/Sum#:	2.9	12.9	1,757.8	0.4	92.0 #	20 #	13 #	13 #
Minimum:	0.2	11.1	436.7	0.2	0.6	0	0	0
Maximum:	19.0	17.6	2,212.3	0.5	43.1	1	1	1
%SI	16.7	16.7	16.7	37.5	16.7	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/20/2014 00:00	21.1	15.7	554.2	0.0	6.5	1	0	0
07/20/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	21.1	15.7	554.2	0.0	6.5 #	1 #	0 #	0 #
Minimum:	21.1	15.7	554.2	0.0	6.5	0	0	0
Maximum:	21.1	15.7	554.2	0.0	6.5	1	0	0
%SI	95.8	95.8	95.8	100.0	95.8	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/21/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/21/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
07/21/2014 06:00	63.5	17.2	492.7	0.0	78.2	1	1	0
07/21/2014 07:00	13.8	14.4	1,206.8	0.0	33.8	1	1	1
07/21/2014 08:00	0.6	13.0	1,890.5	0.0	1.9	1	1	1
07/21/2014 09:00	0.9	12.7	1,934.8	0.0	2.8	1	1	1
07/21/2014 10:00	0.8	12.8	1,935.6	0.5	2.5	1	1	1
07/21/2014 11:00	0.7	12.9	1,922.3	0.6	2.2	1	1	1
07/21/2014 12:00	0.7	12.8	1,914.5	0.5	2.2	1	1	1
07/21/2014 13:00	0.7	12.9	1,906.6	0.5	2.2	1	1	1
07/21/2014 14:00	0.8	12.8	1,917.6	0.5	2.5	1	1	1
07/21/2014 15:00	0.9	12.5	1,981.1	0.6	2.8	1	1	1
07/21/2014 16:00	0.9	12.4	1,981.5	0.6	2.8	1	1	1
07/21/2014 17:00	0.7	11.5	2,162.5	0.5	2.1	1	1	1
07/21/2014 18:00	0.6	11.1	2,236.5	0.5	1.8	1	1	1
07/21/2014 19:00	0.6	11.1	2,246.6	0.4	1.8	1	1	1
07/21/2014 20:00	0.6	11.1	2,247.7	0.4	1.8	1	1	1
07/21/2014 21:00	0.7	11.7	2,144.9	0.4	2.2	1	1	1
07/21/2014 22:00	0.8	12.4	2,005.2	0.5	2.5	1	1	1
07/21/2014 23:00	0.7	12.7	1,936.9	0.5	2.2	1	1	1
Average/Sum#:	4.9	12.7	1,892.5	0.5	148.3 #	18 #	20 #	17 #
Minimum:	0.6	11.1	492.7	0.4	1.8	0	0	0
Maximum:	63.5	17.2	2,247.7	0.6	78.2	1	1	1
%SI	25.0	25.0	25.0	41.7	25.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/22/2014 00:00	0.6	13.3	1,835.3	0.5	1.9	1	1	1
07/22/2014 01:00	0.6	13.2	1,853.4	0.5	1.9	1	1	1
07/22/2014 02:00	0.6	13.2	1,846.9	0.5	1.9	1	1	1
07/22/2014 03:00	0.6	13.3	1,835.9	0.5	1.9	1	1	1
07/22/2014 04:00	0.8	13.0	1,911.9	0.5	2.6	1	1	1
07/22/2014 05:00	0.7	13.2	1,868.5	0.5	2.2	1	1	1
07/22/2014 06:00	0.7	13.2	1,850.7	0.5	2.2	1	1	1
07/22/2014 07:00	0.9	12.8	1,937.5	0.6	2.8	1	1	1
07/22/2014 08:00	0.6	13.2	1,853.7	0.6	1.9	1	1	1
07/22/2014 09:00	0.6	13.3	1,842.3	0.6	1.9	1	1	1
07/22/2014 10:00	0.6	13.2	1,830.9	0.5	1.9	1	1	1
07/22/2014 11:00	0.8	12.8	1,913.4	0.5	2.5	1	1	1
07/22/2014 12:00	1.0	12.3	2,020.5	0.6	3.1	1	1	1
07/22/2014 13:00	0.9	12.5	1,975.0	0.6	2.8	1	1	1
07/22/2014 14:00	0.9	12.3	2,005.2	0.6	2.8	1	1	1
07/22/2014 15:00	0.7	11.6	2,139.3	0.5	2.1	1	1	1
07/22/2014 16:00	0.7	11.9	2,069.2	0.5	2.1	1	1	1
07/22/2014 17:00	0.8	12.1	2,024.1	0.5	2.4	1	1	1
07/22/2014 18:00	0.7	11.7	2,133.0	0.5	2.1	1	1	1
07/22/2014 19:00	0.7	12.1	2,085.5	0.5	2.2	1	1	1
07/22/2014 20:00	0.7	12.2	2,066.6	0.5	2.2	1	1	1
07/22/2014 21:00	0.7	12.2	2,066.4	0.5	2.2	1	1	1
07/22/2014 22:00	0.6	12.7	1,967.9	0.5	1.9	1	1	1
07/22/2014 23:00	0.3	13.6	1,541.9	0.4	0.8	1	1	1
Average/Sum#:	0.7	12.7	1,936.5	0.5	52.3 #	24 #	24 #	24 #
Minimum:	0.3	11.6	1,541.9	0.4	0.8	1	1	1
Maximum:	1.0	13.6	2,139.3	0.6	3.1	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/23/2014 00:00	0.2	13.8	1,282.3	0.3	0.5	1	1	0
07/23/2014 01:00	0.2	13.8	1,265.8	0.2	0.5	1	1	0
07/23/2014 02:00	0.3	13.8	1,248.3	0.2	0.7	1	1	0
07/23/2014 03:00	0.3	13.8	1,247.8	0.2	0.7	1	1	0
07/23/2014 04:00	0.3	13.8	1,269.3	0.2	0.7	1	1	0
07/23/2014 05:00	0.5	13.6	1,554.2	0.3	1.4	1	1	1
07/23/2014 06:00	0.7	13.1	1,915.8	0.4	2.3	1	1	1
07/23/2014 07:00	0.6	13.1	1,913.5	0.5	1.9	1	1	1
07/23/2014 08:00	0.6	13.2	1,886.6	0.5	1.9	1	1	1
07/23/2014 09:00	0.7	13.2	1,881.0	0.5	2.3	1	1	1
07/23/2014 10:00	0.7	13.2	1,856.1	0.5	2.2	1	1	1
07/23/2014 11:00	0.6	13.2	1,858.8	0.5	1.9	1	1	1
07/23/2014 12:00	0.6	13.2	1,860.3	0.5	1.9	1	1	1
07/23/2014 13:00	0.6	13.3	1,852.7	0.5	1.9	1	1	1
07/23/2014 14:00	0.7	13.0	1,894.5	0.5	2.2	1	1	1
07/23/2014 15:00	0.9	12.5	2,002.7	0.5	2.8	1	1	1
07/23/2014 16:00	0.8	12.0	2,077.5	0.5	2.5	1	1	1
07/23/2014 17:00	0.8	12.6	1,964.5	0.6	2.5	1	1	1
07/23/2014 18:00	0.9	12.4	2,013.6	0.6	2.8	1	1	1
07/23/2014 19:00	0.9	12.4	1,987.9	0.6	2.8	1	1	1
07/23/2014 20:00	0.8	12.7	1,946.6	0.6	2.5	1	1	1
07/23/2014 21:00	0.7	12.8	1,917.0	0.6	2.2	1	1	1
07/23/2014 22:00	0.7	13.2	1,859.7	0.5	2.2	1	1	1
07/23/2014 23:00	0.8	13.0	1,901.3	0.5	2.5	1	1	1
Average/Sum#:	0.6	13.1	1,769.1	0.5	45.8 #	24 #	24 #	19 #
Minimum:	0.2	12.0	1,247.8	0.2	0.5	1	1	0
Maximum:	0.9	13.8	2,077.5	0.6	2.8	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/24/2014 00:00	0.6	13.2	1,866.4	0.5	1.9	1	1	1
07/24/2014 01:00	0.7	13.2	1,872.6	0.5	2.2	1	1	1
07/24/2014 02:00	0.4	13.7	1,488.0	0.4	1.1	1	1	1
07/24/2014 03:00	0.3	13.9	1,251.5	0.4	0.7	1	1	0
07/24/2014 04:00	0.3	13.9	1,247.4	0.3	0.7	1	1	0
07/24/2014 05:00	0.3	13.9	1,251.7	0.3	0.7	1	1	0
07/24/2014 06:00	0.3	13.9	1,254.5	0.3	0.7	1	1	0
07/24/2014 07:00	0.2	13.9	1,258.9	0.3	0.5	1	1	0
07/24/2014 08:00	0.3	13.7	1,579.2	0.2	0.9	1	1	1
07/24/2014 09:00	0.6	13.1	1,902.1	0.3	1.9	1	1	1
07/24/2014 10:00	0.7	13.0	1,914.0	0.4	2.2	1	1	1
07/24/2014 11:00	0.7	12.8	1,940.0	0.5	2.2	1	1	1
07/24/2014 12:00	0.8	12.1	2,074.6	0.5	2.5	1	1	1
07/24/2014 13:00	0.5	11.2	2,244.0	0.4	1.5	1	1	1
07/24/2014 14:00	0.6	11.4	2,198.1	0.4	1.8	1	1	1
07/24/2014 15:00	0.7	12.0	2,075.4	0.4	2.2	1	1	1
07/24/2014 16:00	0.7	12.0	2,080.2	0.5	2.2	1	1	1
07/24/2014 17:00	0.8	12.0	2,080.7	0.5	2.5	1	1	1
07/24/2014 18:00	0.8	12.0	2,073.9	0.5	2.5	1	1	1
07/24/2014 19:00	0.8	12.2	2,055.5	0.5	2.5	1	1	1
07/24/2014 20:00	0.8	12.3	2,021.4	0.5	2.5	1	1	1
07/24/2014 21:00	0.4	13.4	1,684.7	0.4	1.2	1	1	1
07/24/2014 22:00	0.6	13.1	1,878.5	0.4	1.9	1	1	1
07/24/2014 23:00	1.0	12.4	2,023.1	0.5	3.1	1	1	1
Average/Sum#:	0.6	12.8	1,804.9	0.4	42.1 #	24 #	24 #	19 #
Minimum:	0.2	11.2	1,247.4	0.2	0.5	1	1	0
Maximum:	1.0	13.9	2,244.0	0.5	3.1	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/25/2014 00:00	0.9	13.1	1,881.4	0.6	2.9	1	1	1
07/25/2014 01:00	0.6	13.4	1,841.8	0.6	1.9	1	1	1
07/25/2014 02:00	0.6	13.4	1,839.3	0.6	1.9	1	1	1
07/25/2014 03:00	0.6	13.4	1,837.3	0.5	1.9	1	1	1
07/25/2014 04:00	0.7	13.2	1,880.8	0.5	2.3	1	1	1
07/25/2014 05:00	0.7	13.1	1,899.0	0.5	2.3	1	1	1
07/25/2014 06:00	0.7	13.1	1,900.3	0.5	2.3	1	1	1
07/25/2014 07:00	0.9	13.0	1,904.0	0.6	2.9	1	1	1
07/25/2014 08:00	0.8	13.2	1,865.3	0.6	2.6	1	1	1
07/25/2014 09:00	0.8	12.9	1,902.5	0.6	2.5	1	1	1
07/25/2014 10:00	0.9	12.2	2,045.8	0.6	2.8	1	1	1
07/25/2014 11:00	0.8	11.7	2,138.1	0.6	2.5	1	1	1
07/25/2014 12:00	0.8	11.9	2,098.0	0.5	2.5	1	1	1
07/25/2014 13:00	0.8	12.3	1,988.1	0.5	2.4	1	1	1
07/25/2014 14:00	0.9	12.2	2,040.3	0.5	2.8	1	1	1
07/25/2014 15:00	0.8	11.7	2,123.8	0.5	2.4	1	1	1
07/25/2014 16:00	0.8	11.8	2,100.4	0.5	2.4	1	1	1
07/25/2014 17:00	0.7	11.6	2,148.2	0.5	2.1	1	1	1
07/25/2014 18:00	0.7	11.7	2,147.9	0.4	2.2	1	1	1
07/25/2014 19:00	0.7	11.4	2,185.8	0.4	2.1	1	1	1
07/25/2014 20:00	0.8	11.9	2,083.7	0.4	2.4	1	1	1
07/25/2014 21:00	0.9	12.3	2,013.1	0.5	2.8	1	1	1
07/25/2014 22:00	0.9	12.4	2,000.4	0.6	2.8	1	1	1
07/25/2014 23:00	0.8	12.9	1,903.4	0.6	2.5	1	1	1
Average/Sum#:	0.8	12.5	1,990.4	0.5	58.2 #	24 #	24 #	24 #
Minimum:	0.6	11.4	1,837.3	0.4	1.9	1	1	1
Maximum:	0.9	13.4	2,185.8	0.6	2.9	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/26/2014 00:00	0.8	13.1	1,858.5	0.6	2.5	1	1	1
07/26/2014 01:00	0.7	13.3	1,839.3	0.6	2.2	1	1	1
07/26/2014 02:00	0.6	13.3	1,838.7	0.5	1.9	1	1	1
07/26/2014 03:00	0.6	13.3	1,836.3	0.5	1.9	1	1	1
07/26/2014 04:00	0.7	13.2	1,875.8	0.5	2.3	1	1	1
07/26/2014 05:00	0.6	13.3	1,834.2	0.5	1.9	1	1	1
07/26/2014 06:00	0.6	13.4	1,826.9	0.5	1.9	1	1	1
07/26/2014 07:00	0.6	13.2	1,847.5	0.5	1.9	1	1	1
07/26/2014 08:00	0.6	13.2	1,845.3	0.5	1.9	1	1	1
07/26/2014 09:00	0.6	13.2	1,830.7	0.5	1.9	1	1	1
07/26/2014 10:00	0.6	13.1	1,840.0	0.5	1.9	1	1	1
07/26/2014 11:00	0.8	12.6	1,965.1	0.5	2.5	1	1	1
07/26/2014 12:00	0.8	11.6	2,116.1	0.5	2.4	1	1	1
07/26/2014 13:00	0.7	11.6	2,119.2	0.5	2.1	1	1	1
07/26/2014 14:00	0.8	12.1	2,007.7	0.5	2.4	1	1	1
07/26/2014 15:00	0.4	13.4	1,655.6	0.4	1.2	1	1	1
07/26/2014 16:00	0.3	13.4	1,622.7	0.3	0.9	1	1	1
07/26/2014 17:00	0.8	12.7	1,920.1	0.4	2.5	1	1	1
07/26/2014 18:00	0.8	13.0	1,818.0	0.5	2.4	1	1	1
07/26/2014 19:00	0.2	13.9	1,260.1	0.5	0.5	1	1	0
07/26/2014 20:00	0.2	14.0	1,246.4	0.3	0.5	1	1	0
07/26/2014 21:00	0.2	14.0	1,246.0	0.2	0.5	1	1	0
07/26/2014 22:00	0.3	13.9	1,244.5	0.2	0.7	1	1	0
07/26/2014 23:00	0.4	13.9	1,405.3	0.3	1.1	1	1	0
Average/Sum#:	0.6	13.2	1,745.8	0.5	41.9 #	24 #	24 #	19 #
Minimum:	0.2	11.6	1,244.5	0.2	0.5	1	1	0
Maximum:	0.8	14.0	2,119.2	0.6	2.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/27/2014 00:00	0.4	13.8	1,502.1	0.3	1.1	1	1	0
07/27/2014 01:00	0.5	13.9	1,352.2	0.3	1.3	1	1	0
07/27/2014 02:00	0.4	13.8	1,377.5	0.3	1.0	1	1	0
07/27/2014 03:00	0.4	13.9	1,272.9	0.3	1.0	1	1	0
07/27/2014 04:00	0.4	13.9	1,329.6	0.3	1.0	1	1	0
07/27/2014 05:00	0.4	13.9	1,283.8	0.3	1.0	1	1	0
07/27/2014 06:00	0.7	13.6	1,527.8	0.4	1.9	1	1	1
07/27/2014 07:00	1.1	13.0	1,879.8	0.6	3.5	1	1	1
07/27/2014 08:00	0.8	13.3	1,775.9	0.7	2.5	1	1	1
07/27/2014 09:00	1.0	13.1	1,858.4	0.7	3.1	1	1	1
07/27/2014 10:00	1.0	12.9	1,882.6	0.7	3.1	1	1	1
07/27/2014 11:00	1.2	12.2	2,022.0	0.8	3.7	1	1	1
07/27/2014 12:00	1.1	12.5	1,971.8	0.8	3.4	1	1	1
07/27/2014 13:00	1.0	12.6	1,950.6	0.8	3.1	1	1	1
07/27/2014 14:00	0.8	12.9	1,898.8	0.7	2.5	1	1	1
07/27/2014 15:00	1.0	12.1	2,060.5	0.7	3.1	1	1	1
07/27/2014 16:00	0.8	11.9	2,087.9	0.6	2.5	1	1	1
07/27/2014 17:00	0.9	11.8	2,101.3	0.6	2.7	1	1	1
07/27/2014 18:00	0.9	11.8	2,101.0	0.6	2.7	1	1	1
07/27/2014 19:00	0.9	12.0	2,053.6	0.6	2.7	1	1	1
07/27/2014 20:00	0.8	13.1	1,822.1	0.6	2.5	1	1	1
07/27/2014 21:00	0.6	13.3	1,678.7	0.6	1.8	1	1	1
07/27/2014 22:00	0.5	13.5	1,659.3	0.5	1.5	1	1	1
07/27/2014 23:00	0.8	13.1	1,840.2	0.5	2.5	1	1	1
Average/Sum#:	0.8	13.0	1,762.1	0.6	55.2 #	24 #	24 #	18 #
Minimum:	0.4	11.8	1,272.9	0.3	1.0	1	1	0
Maximum:	1.2	13.9	2,101.3	0.8	3.7	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/28/2014 00:00	0.8	13.2	1,844.6	0.5	2.5	1	1	1
07/28/2014 01:00	1.0	12.9	1,902.1	0.6	3.1	1	1	1
07/28/2014 02:00	0.8	13.2	1,743.2	0.6	2.4	1	1	1
07/28/2014 03:00	0.4	13.8	1,279.2	0.5	1.0	1	1	0
07/28/2014 04:00	0.7	13.5	1,614.6	0.5	2.0	1	1	1
07/28/2014 05:00	0.9	13.3	1,837.7	0.5	2.9	1	1	1
07/28/2014 06:00	0.8	13.2	1,861.0	0.6	2.6	1	1	1
07/28/2014 07:00	0.7	13.2	1,848.2	0.6	2.2	1	1	1
07/28/2014 08:00	0.7	13.1	1,875.2	0.5	2.2	1	1	1
07/28/2014 09:00	1.1	12.2	2,049.7	0.6	3.4	1	1	1
07/28/2014 10:00	0.9	12.1	2,066.8	0.6	2.8	1	1	1
07/28/2014 11:00	0.9	11.6	2,153.9	0.6	2.8	1	1	1
07/28/2014 12:00	0.8	11.8	2,089.9	0.6	2.4	1	1	1
07/28/2014 13:00	0.8	11.7	2,108.6	0.5	2.4	1	1	1
07/28/2014 14:00	0.8	11.8	2,079.2	0.5	2.4	1	1	1
07/28/2014 15:00	0.8	11.8	2,077.9	0.5	2.4	1	1	1
07/28/2014 16:00	0.8	11.8	2,066.0	0.5	2.4	1	1	1
07/28/2014 17:00	0.8	11.9	2,071.1	0.5	2.4	1	1	1
07/28/2014 18:00	0.8	12.6	1,938.0	0.5	2.5	1	1	1
07/28/2014 19:00	0.9	12.5	1,960.9	0.6	2.8	1	1	1
07/28/2014 20:00	0.8	12.6	1,931.0	0.6	2.5	1	1	1
07/28/2014 21:00	0.8	13.0	1,878.5	0.6	2.5	1	1	1
07/28/2014 22:00	0.8	12.8	1,911.1	0.6	2.5	1	1	1
07/28/2014 23:00	0.6	13.2	1,834.3	0.6	1.9	1	1	1
Average/Sum#:	0.8	12.6	1,917.6	0.6	59.0 #	24 #	24 #	23 #
Minimum:	0.4	11.6	1,279.2	0.5	1.0	1	1	0
Maximum:	1.1	13.8	2,153.9	0.6	3.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/29/2014 00:00	0.9	12.8	1,923.0	0.6	2.8	1	1	1
07/29/2014 01:00	0.2	13.8	1,447.1	0.5	0.5	1	1	1
07/29/2014 02:00	0.2	13.9	1,253.0	0.4	0.5	1	1	0
07/29/2014 03:00	0.2	13.9	1,229.9	0.2	0.5	1	1	0
07/29/2014 04:00	0.3	13.8	1,368.4	0.2	0.8	1	1	1
07/29/2014 05:00	0.7	13.4	1,832.2	0.3	2.3	1	1	1
07/29/2014 06:00	0.9	13.0	1,916.5	0.5	2.9	1	1	1
07/29/2014 07:00	1.0	12.2	2,073.6	0.7	3.1	1	1	1
07/29/2014 08:00	1.0	12.4	2,027.1	0.7	3.1	1	1	1
07/29/2014 09:00	0.9	12.6	1,966.1	0.7	2.8	1	1	1
07/29/2014 10:00	0.9	11.8	2,147.5	0.6	2.8	1	1	1
07/29/2014 11:00	0.8	12.4	1,999.2	0.6	2.5	1	1	1
07/29/2014 12:00	0.8	11.9	2,115.6	0.6	2.5	1	1	1
07/29/2014 13:00	0.6	11.4	2,199.2	0.5	1.8	1	1	1
07/29/2014 14:00	0.6	11.4	2,185.5	0.4	1.8	1	1	1
07/29/2014 15:00	0.6	11.5	2,144.5	0.4	1.8	1	1	1
07/29/2014 16:00	0.7	11.9	2,034.2	0.4	2.1	1	1	1
07/29/2014 17:00	0.8	12.3	1,979.9	0.5	2.4	1	1	1
07/29/2014 18:00	0.9	12.3	1,976.1	0.5	2.7	1	1	1
07/29/2014 19:00	0.7	12.7	1,898.4	0.5	2.1	1	1	1
07/29/2014 20:00	0.9	13.1	1,840.4	0.6	2.8	1	1	1
07/29/2014 21:00	0.8	12.9	1,890.3	0.6	2.5	1	1	1
07/29/2014 22:00	0.5	13.1	1,837.2	0.6	1.6	1	1	1
07/29/2014 23:00	0.7	13.2	1,825.7	0.5	2.2	1	1	1
Average/Sum#:	0.7	12.7	1,879.6	0.5	50.9 #	24 #	24 #	22 #
Minimum:	0.2	11.4	1,229.9	0.2	0.5	1	1	0
Maximum:	1.0	13.9	2,199.2	0.7	3.1	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/30/2014 00:00	1.1	13.3	1,817.0	0.6	3.5	1	1	1
07/30/2014 01:00	1.2	13.1	1,856.2	0.8	3.8	1	1	1
07/30/2014 02:00	0.4	13.8	1,404.4	0.7	1.0	1	1	1
07/30/2014 03:00	0.7	13.6	1,533.3	0.6	1.9	1	1	1
07/30/2014 04:00	0.7	13.3	1,840.3	0.5	2.2	1	1	1
07/30/2014 05:00	0.7	13.3	1,845.1	0.5	2.2	1	1	1
07/30/2014 06:00	0.7	13.2	1,842.9	0.5	2.2	1	1	1
07/30/2014 07:00	0.7	13.2	1,841.3	0.5	2.2	1	1	1
07/30/2014 08:00	0.7	13.2	1,842.6	0.5	2.2	1	1	1
07/30/2014 09:00	0.6	13.1	1,849.8	0.5	1.9	1	1	1
07/30/2014 10:00	0.6	13.1	1,848.0	0.5	1.9	1	1	1
07/30/2014 11:00	0.9	12.5	1,982.2	0.5	2.8	1	1	1
07/30/2014 12:00	0.7	11.4	2,182.4	0.5	2.1	1	1	1
07/30/2014 13:00	0.6	11.3	2,197.8	0.5	1.8	1	1	1
07/30/2014 14:00	0.6	11.3	2,166.6	0.4	1.8	1	1	1
07/30/2014 15:00	0.7	11.4	2,138.9	0.4	2.1	1	1	1
07/30/2014 16:00	0.7	11.4	2,138.6	0.4	2.1	1	1	1
07/30/2014 17:00	0.7	11.4	2,139.9	0.4	2.1	1	1	1
07/30/2014 18:00	0.7	11.5	2,139.0	0.4	2.1	1	1	1
07/30/2014 19:00	0.8	11.7	2,094.0	0.4	2.4	1	1	1
07/30/2014 20:00	1.0	12.3	1,989.1	0.5	3.1	1	1	1
07/30/2014 21:00	0.9	11.6	2,127.5	0.6	2.7	1	1	1
07/30/2014 22:00	0.9	11.9	2,077.9	0.6	2.7	1	1	1
07/30/2014 23:00	1.0	12.2	2,028.8	0.6	3.1	1	1	1
Average/Sum#:	0.8	12.4	1,955.2	0.5	55.9 #	24 #	24 #	24 #
Minimum:	0.4	11.3	1,404.4	0.4	1.0	1	1	1
Maximum:	1.2	13.8	2,197.8	0.8	3.8	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/31/2014 00:00	0.5	13.4	1,696.9	0.6	1.5	1	1	1
07/31/2014 01:00	0.3	13.7	1,710.9	0.4	0.9	1	1	0
07/31/2014 02:00	0.6	13.3	1,766.0	0.4	1.8	1	1	1
07/31/2014 03:00	0.8	13.0	1,877.3	0.4	2.5	1	1	1
07/31/2014 04:00	0.7	13.2	1,847.8	0.5	2.2	1	1	1
07/31/2014 05:00	0.8	13.2	1,843.4	0.6	2.5	1	1	1
07/31/2014 06:00	0.7	13.2	1,841.9	0.5	2.2	1	1	1
07/31/2014 07:00	0.7	13.2	1,844.5	0.5	2.2	1	1	1
07/31/2014 08:00	0.7	13.1	1,848.1	0.5	2.2	1	1	1
07/31/2014 09:00	1.0	12.7	1,924.6	0.6	3.1	1	1	1
07/31/2014 10:00	1.0	11.4	2,173.3	0.6	3.0	1	1	1
07/31/2014 11:00	0.8	11.2	2,198.8	0.6	2.4	1	1	1
07/31/2014 12:00	0.8	11.3	2,162.8	0.5	2.4	1	1	1
07/31/2014 13:00	0.2	13.4	1,709.8	0.4	0.6	1	1	1
07/31/2014 14:00	0.9	12.6	1,907.6	0.4	2.7	1	1	1
07/31/2014 15:00	1.0	12.2	1,983.5	0.5	3.0	1	1	1
07/31/2014 16:00	1.1	12.1	1,990.1	0.7	3.3	1	1	1
07/31/2014 17:00	1.1	12.0	1,996.9	0.7	3.3	1	1	1
07/31/2014 18:00	1.1	12.1	1,988.2	0.7	3.3	1	1	1
07/31/2014 19:00	1.2	12.2	1,975.8	0.7	3.6	1	1	1
07/31/2014 20:00	1.1	12.2	1,968.1	0.7	3.3	1	1	1
07/31/2014 21:00	1.1	12.4	1,954.5	0.8	3.3	1	1	1
07/31/2014 22:00	0.9	12.8	1,881.2	0.7	2.8	1	1	1
07/31/2014 23:00	0.9	12.8	1,880.0	0.7	2.8	1	1	1
Average/Sum#:	0.8	12.6	1,915.5	0.6	60.9 #	24 #	24 #	23 #
Minimum:	0.2	11.2	1,696.9	0.4	0.6	1	1	0
Maximum:	1.2	13.7	2,198.8	0.8	3.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/01/2014 00:00	0.9	12.9	1,882.6	0.7	2.8	1	1	1
08/01/2014 01:00	0.4	13.6	1,580.9	0.6	1.1	1	1	1
08/01/2014 02:00	0.5	13.6	1,595.6	0.5	1.4	1	1	1
08/01/2014 03:00	0.9	13.0	1,886.0	0.5	2.8	1	1	1
08/01/2014 04:00	0.8	13.2	1,855.3	0.6	2.5	1	1	1
08/01/2014 05:00	0.9	13.0	1,899.0	0.7	2.9	1	1	1
08/01/2014 06:00	0.7	13.3	1,839.5	0.6	2.2	1	1	1
08/01/2014 07:00	0.7	13.2	1,837.6	0.6	2.2	1	1	1
08/01/2014 08:00	1.0	12.9	1,897.0	0.6	3.1	1	1	1
08/01/2014 09:00	1.3	12.3	2,008.9	0.7	4.0	1	1	1
08/01/2014 10:00	1.2	11.6	2,117.8	0.8	3.6	1	1	1
08/01/2014 11:00	1.0	11.3	2,189.8	0.8	3.0	1	1	1
08/01/2014 12:00	1.1	11.4	2,152.1	0.7	3.3	1	1	1
08/01/2014 13:00	1.0	11.4	2,138.7	0.6	3.0	1	1	1
08/01/2014 14:00	1.0	11.4	2,132.4	0.6	3.0	1	1	1
08/01/2014 15:00	1.1	11.5	2,092.1	0.6	3.2	1	1	1
08/01/2014 16:00	1.1	11.9	2,032.0	0.7	3.3	1	1	1
08/01/2014 17:00	1.1	12.1	1,997.9	0.7	3.3	1	1	1
08/01/2014 18:00	1.2	12.2	1,991.2	0.7	3.6	1	1	1
08/01/2014 19:00	1.2	12.3	1,990.8	0.8	3.7	1	1	1
08/01/2014 20:00	1.1	12.7	1,929.1	0.8	3.4	1	1	1
08/01/2014 21:00	1.0	12.9	1,900.9	0.8	3.1	1	1	1
08/01/2014 22:00	0.9	12.9	1,888.8	0.7	2.8	1	1	1
08/01/2014 23:00	1.1	12.7	1,926.6	0.7	3.4	1	1	1
Average/Sum#:	1.0	12.5	1,948.4	0.7	70.7 #	24 #	24 #	24 #
Minimum:	0.4	11.3	1,580.9	0.5	1.1	1	1	1
Maximum:	1.3	13.6	2,189.8	0.8	4.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/02/2014 00:00	1.0	13.0	1,872.6	0.7	3.1	1	1	1
08/02/2014 01:00	0.8	13.2	1,847.7	0.7	2.5	1	1	1
08/02/2014 02:00	0.8	13.2	1,825.1	0.6	2.5	1	1	1
08/02/2014 03:00	0.4	13.9	1,304.0	0.5	1.0	1	1	0
08/02/2014 04:00	0.3	13.8	1,477.1	0.4	0.8	1	1	0
08/02/2014 05:00	0.3	13.9	1,262.5	0.3	0.7	1	1	0
08/02/2014 06:00	0.3	13.8	1,238.2	0.2	0.7	1	1	0
08/02/2014 07:00	0.8	13.6	1,515.0	0.4	2.2	1	1	1
08/02/2014 08:00	1.3	13.2	1,849.6	0.6	4.1	1	1	1
08/02/2014 09:00	0.9	13.3	1,821.1	0.8	2.8	1	1	1
08/02/2014 10:00	0.8	13.2	1,832.7	0.8	2.5	1	1	1
08/02/2014 11:00	1.0	13.0	1,877.3	0.7	3.1	1	1	1
08/02/2014 12:00	1.2	12.8	1,918.0	0.7	3.8	1	1	1
08/02/2014 13:00	1.2	12.7	1,915.7	0.8	3.7	1	1	1
08/02/2014 14:00	1.0	12.9	1,858.2	0.8	3.1	1	1	1
08/02/2014 15:00	1.1	12.8	1,875.9	0.8	3.4	1	1	1
08/02/2014 16:00	1.2	12.7	1,887.9	0.8	3.6	1	1	1
08/02/2014 17:00	1.3	12.5	1,917.1	0.9	3.9	1	1	1
08/02/2014 18:00	1.3	12.6	1,906.0	0.9	3.9	1	1	1
08/02/2014 19:00	1.3	12.3	1,980.7	0.9	4.0	1	1	1
08/02/2014 20:00	1.3	12.3	1,977.1	0.9	3.9	1	1	1
08/02/2014 21:00	1.0	12.7	1,896.7	0.8	3.1	1	1	1
08/02/2014 22:00	0.4	13.6	1,535.9	0.6	1.1	1	1	1
08/02/2014 23:00	0.3	13.9	1,276.1	0.4	0.7	1	1	0
Average/Sum#:	0.9	13.1	1,736.2	0.7	64.2 #	24 #	24 #	19 #
Minimum:	0.3	12.3	1,238.2	0.2	0.7	1	1	0
Maximum:	1.3	13.9	1,980.7	0.9	4.1	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/03/2014 00:00	0.3	13.8	1,594.3	0.3	0.9	1	1	0
08/03/2014 01:00	0.3	13.8	1,487.0	0.2	0.8	1	1	0
08/03/2014 02:00	0.3	13.8	1,410.3	0.2	0.8	1	1	0
08/03/2014 03:00	0.3	13.8	1,601.4	0.2	0.9	1	1	0
08/03/2014 04:00	0.3	13.7	1,750.3	0.2	1.0	1	1	1
08/03/2014 05:00	1.3	13.4	1,821.6	0.5	4.2	1	1	1
08/03/2014 06:00	0.7	13.3	1,826.7	0.6	2.2	1	1	1
08/03/2014 07:00	1.1	12.8	1,939.5	0.8	3.5	1	1	1
08/03/2014 08:00	0.9	13.0	1,894.5	0.7	2.9	1	1	1
08/03/2014 09:00	0.9	13.0	1,883.2	0.7	2.8	1	1	1
08/03/2014 10:00	1.0	12.9	1,895.8	0.7	3.1	1	1	1
08/03/2014 11:00	1.0	12.8	1,903.6	0.7	3.1	1	1	1
08/03/2014 12:00	1.0	12.8	1,900.0	0.7	3.1	1	1	1
08/03/2014 13:00	1.3	11.9	2,068.1	0.8	3.9	1	1	1
08/03/2014 14:00	1.3	12.3	1,978.0	0.8	3.9	1	1	1
08/03/2014 15:00	1.3	11.7	2,102.8	0.9	3.9	1	1	1
08/03/2014 16:00	1.1	12.4	1,953.9	0.8	3.3	1	1	1
08/03/2014 17:00	1.2	12.5	1,941.1	0.8	3.7	1	1	1
08/03/2014 18:00	0.9	12.9	1,872.3	0.8	2.8	1	1	1
08/03/2014 19:00	1.2	12.6	1,945.1	0.8	3.7	1	1	1
08/03/2014 20:00	1.2	12.6	1,952.5	0.8	3.7	1	1	1
08/03/2014 21:00	0.8	13.0	1,864.0	0.8	2.5	1	1	1
08/03/2014 22:00	0.8	13.0	1,857.4	0.7	2.5	1	1	1
08/03/2014 23:00	1.0	12.8	1,935.0	0.6	3.2	1	1	1
Average/Sum#:	0.9	12.9	1,849.1	0.6	66.4 #	24 #	24 #	20 #
Minimum:	0.3	11.7	1,410.3	0.2	0.8	1	1	0
Maximum:	1.3	13.8	2,102.8	0.9	4.2	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/04/2014 00:00	0.9	13.1	1,876.1	0.7	2.9	1	1	1
08/04/2014 01:00	1.0	13.0	1,902.5	0.7	3.2	1	1	1
08/04/2014 02:00	0.8	13.2	1,866.0	0.7	2.6	1	1	1
08/04/2014 03:00	1.0	12.9	1,917.3	0.7	3.2	1	1	1
08/04/2014 04:00	0.8	13.3	1,842.2	0.6	2.6	1	1	1
08/04/2014 05:00	0.8	13.2	1,823.2	0.6	2.5	1	1	1
08/04/2014 06:00	0.3	13.7	1,705.6	0.5	0.9	1	1	0
08/04/2014 07:00	0.3	13.7	1,676.5	0.3	0.9	1	1	0
08/04/2014 08:00	0.3	13.6	1,758.9	0.2	1.0	1	1	0
08/04/2014 09:00	0.3	13.6	1,756.8	0.2	1.0	1	1	0
08/04/2014 10:00	0.8	13.2	1,801.5	0.3	2.5	1	1	1
08/04/2014 11:00	1.0	12.9	1,902.7	0.5	3.1	1	1	1
08/04/2014 12:00	0.7	13.2	1,837.9	0.6	2.2	1	1	1
08/04/2014 13:00	0.8	13.1	1,842.0	0.6	2.5	1	1	1
08/04/2014 14:00	0.8	13.1	1,846.3	0.6	2.5	1	1	1
08/04/2014 15:00	0.8	13.0	1,852.9	0.6	2.5	1	1	1
08/04/2014 16:00	0.7	13.1	1,839.8	0.6	2.2	1	1	1
08/04/2014 17:00	0.8	13.1	1,843.3	0.6	2.5	1	1	1
08/04/2014 18:00	0.8	13.1	1,839.7	0.6	2.5	1	1	1
08/04/2014 19:00	0.8	13.2	1,836.8	0.6	2.5	1	1	1
08/04/2014 20:00	0.8	13.2	1,836.6	0.6	2.5	1	1	1
08/04/2014 21:00	0.7	13.3	1,583.2	0.6	1.9	1	1	1
08/04/2014 22:00	0.4	13.8	1,280.5	0.5	1.0	1	1	0
08/04/2014 23:00	0.4	13.7	1,613.8	0.4	1.2	1	1	0
Average/Sum#:	0.7	13.3	1,786.8	0.5	52.4 #	24 #	24 #	18 #
Minimum:	0.3	12.9	1,280.5	0.2	0.9	1	1	0
Maximum:	1.0	13.8	1,917.3	0.7	3.2	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/05/2014 00:00	0.6	13.4	1,770.6	0.4	1.9	1	1	1
08/05/2014 01:00	1.0	12.9	1,895.1	0.5	3.1	1	1	1
08/05/2014 02:00	1.1	12.7	1,928.9	0.7	3.4	1	1	1
08/05/2014 03:00	1.0	12.9	1,905.5	0.7	3.1	1	1	1
08/05/2014 04:00	1.0	12.9	1,910.8	0.7	3.2	1	1	1
08/05/2014 05:00	0.8	13.2	1,840.4	0.7	2.5	1	1	1
08/05/2014 06:00	0.8	13.1	1,874.7	0.6	2.5	1	1	1
08/05/2014 07:00	0.4	13.8	1,295.7	0.5	1.0	1	1	1
08/05/2014 08:00	0.3	13.8	1,250.1	0.4	0.7	1	1	0
08/05/2014 09:00	0.6	13.3	1,571.2	0.3	1.6	1	1	1
08/05/2014 10:00	0.7	13.2	1,845.2	0.4	2.2	1	1	1
08/05/2014 11:00	0.6	13.2	1,853.8	0.5	1.9	1	1	1
08/05/2014 12:00	0.8	13.0	1,891.0	0.5	2.5	1	1	1
08/05/2014 13:00	0.9	12.8	1,920.8	0.6	2.8	1	1	1
08/05/2014 14:00	0.9	12.7	1,928.8	0.6	2.8	1	1	1
08/05/2014 15:00	1.0	12.6	1,965.0	0.7	3.1	1	1	1
08/05/2014 16:00	0.9	12.8	1,922.0	0.7	2.8	1	1	1
08/05/2014 17:00	1.0	12.7	1,930.2	0.7	3.1	1	1	1
08/05/2014 18:00	1.1	12.7	1,940.8	0.7	3.4	1	1	1
08/05/2014 19:00	1.0	12.6	1,953.7	0.7	3.1	1	1	1
08/05/2014 20:00	0.8	12.9	1,894.6	0.7	2.5	1	1	1
08/05/2014 21:00	0.8	12.8	1,905.6	0.6	2.5	1	1	1
08/05/2014 22:00	0.4	13.4	1,474.3	0.5	1.0	1	1	1
08/05/2014 23:00	0.4	13.5	1,529.9	0.4	1.1	1	1	1
Average/Sum#:	0.8	13.0	1,799.9	0.6	57.8 #	24 #	24 #	23 #
Minimum:	0.3	12.6	1,250.1	0.3	0.7	1	1	0
Maximum:	1.1	13.8	1,965.0	0.7	3.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/06/2014 00:00	1.1	12.7	1,939.1	0.5	3.4	1	1	1
08/06/2014 01:00	1.1	12.6	1,957.6	0.6	3.4	1	1	1
08/06/2014 02:00	0.9	12.9	1,897.7	0.8	2.8	1	1	1
08/06/2014 03:00	0.6	13.2	1,847.4	0.7	1.9	1	1	1
08/06/2014 04:00	1.1	12.6	1,966.1	0.7	3.4	1	1	1
08/06/2014 05:00	1.2	12.4	2,002.7	0.7	3.7	1	1	1
08/06/2014 06:00	1.0	12.7	1,933.5	0.8	3.1	1	1	1
08/06/2014 07:00	1.0	12.9	1,909.7	0.7	3.2	1	1	1
08/06/2014 08:00	1.1	12.6	1,955.9	0.7	3.4	1	1	1
08/06/2014 09:00	1.1	12.3	2,003.0	0.8	3.4	1	1	1
08/06/2014 10:00	1.1	12.1	2,016.5	0.8	3.3	1	1	1
08/06/2014 11:00	1.1	12.1	2,033.1	0.7	3.4	1	1	1
08/06/2014 12:00	1.1	12.3	1,999.7	0.7	3.4	1	1	1
08/06/2014 13:00	1.1	12.3	1,990.4	0.8	3.4	1	1	1
08/06/2014 14:00	1.1	12.0	2,050.3	0.8	3.3	1	1	1
08/06/2014 15:00	1.1	12.3	1,977.6	0.8	3.3	1	1	1
08/06/2014 16:00	0.8	12.9	1,857.3	0.7	2.5	1	1	1
08/06/2014 17:00	1.1	12.5	1,934.1	0.7	3.3	1	1	1
08/06/2014 18:00	1.2	12.4	1,947.8	0.7	3.6	1	1	1
08/06/2014 19:00	1.2	12.3	1,987.3	0.8	3.7	1	1	1
08/06/2014 20:00	1.1	12.3	1,982.5	0.8	3.3	1	1	1
08/06/2014 21:00	0.9	12.6	1,908.0	0.7	2.7	1	1	1
08/06/2014 22:00	0.5	13.4	1,449.7	0.6	1.3	1	1	1
08/06/2014 23:00	24.6	16.4	352.1	0.0	4.3	1	1	0
Average/Sum#:	2.0	12.7	1,870.8	0.7	76.5 #	24 #	24 #	23 #
Minimum:	0.5	12.0	352.1	0.5	1.3	1	1	0
Maximum:	24.6	16.4	2,050.3	0.8	4.3	1	1	1
%SI	0.0	0.0	0.0	4.2	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/07/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/07/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/07/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/07/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/07/2014 13:00	410.5	17.8	356.8	0.0	293.3	1	1	0
08/07/2014 14:00	30.8	16.4	617.1	0.0	49.1	1	1	0
08/07/2014 15:00	0.7	13.1	1,686.6	0.0	2.0	1	1	1
08/07/2014 16:00	1.0	12.1	1,982.6	0.0	3.0	1	1	1
08/07/2014 17:00	0.9	11.7	2,066.4	0.0	2.7	1	1	1
08/07/2014 18:00	0.9	11.8	1,997.5	0.6	2.6	1	1	1
08/07/2014 19:00	1.0	12.3	1,951.6	0.6	3.0	1	1	1
08/07/2014 20:00	0.7	13.0	1,838.9	0.6	2.2	1	1	1
08/07/2014 21:00	0.8	12.9	1,864.6	0.6	2.5	1	1	1
08/07/2014 22:00	0.6	13.2	1,813.9	0.5	1.9	1	1	1
08/07/2014 23:00	0.7	13.3	1,807.8	0.5	2.2	1	1	1
Average/Sum#:	40.8	13.4	1,634.9	0.6	364.5 #	11 #	15 #	9 #
Minimum:	0.6	11.7	356.8	0.5	1.9	0	0	0
Maximum:	410.5	17.8	2,066.4	0.6	293.3	1	1	1
%SI	54.2	54.2	54.2	75.0	54.2	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/08/2014 00:00	0.9	12.8	1,908.2	0.6	2.8	1	1	1
08/08/2014 01:00	0.8	12.9	1,893.2	0.6	2.5	1	1	1
08/08/2014 02:00	0.5	13.3	1,816.6	0.6	1.6	1	1	1
08/08/2014 03:00	0.7	13.1	1,865.7	0.5	2.2	1	1	1
08/08/2014 04:00	0.8	13.0	1,898.1	0.5	2.5	1	1	1
08/08/2014 05:00	1.0	12.7	1,945.7	0.6	3.1	1	1	1
08/08/2014 06:00	0.9	12.7	1,946.5	0.6	2.8	1	1	1
08/08/2014 07:00	0.8	12.9	1,910.0	0.6	2.5	1	1	1
08/08/2014 08:00	0.7	13.0	1,875.9	0.6	2.2	1	1	1
08/08/2014 09:00	0.9	11.7	2,132.5	0.6	2.8	1	1	1
08/08/2014 10:00	0.9	12.1	2,030.3	0.6	2.7	1	1	1
08/08/2014 11:00	0.7	13.0	1,842.8	0.6	2.2	1	1	1
08/08/2014 12:00	0.8	12.9	1,878.4	0.6	2.5	1	1	1
08/08/2014 13:00	1.0	12.3	1,990.7	0.6	3.1	1	1	1
08/08/2014 14:00	0.9	11.7	2,106.2	0.6	2.7	1	1	1
08/08/2014 15:00	0.8	11.6	2,100.8	0.6	2.4	1	1	1
08/08/2014 16:00	0.9	11.6	2,083.1	0.6	2.7	1	1	1
08/08/2014 17:00	1.0	12.1	2,011.2	0.6	3.0	1	1	1
08/08/2014 18:00	0.8	11.5	2,135.6	0.6	2.4	1	1	1
08/08/2014 19:00	0.9	11.8	2,058.0	0.6	2.7	1	1	1
08/08/2014 20:00	1.0	12.4	1,971.0	0.6	3.1	1	1	1
08/08/2014 21:00	1.0	12.4	1,955.4	0.7	3.0	1	1	1
08/08/2014 22:00	0.8	12.9	1,872.9	0.7	2.5	1	1	1
08/08/2014 23:00	1.1	12.5	1,948.2	0.7	3.4	1	1	1
Average/Sum#:	0.9	12.5	1,965.7	0.6	63.4 #	24 #	24 #	24 #
Minimum:	0.5	11.5	1,816.6	0.5	1.6	1	1	1
Maximum:	1.1	13.3	2,135.6	0.7	3.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/09/2014 00:00	0.3	13.6	1,698.3	0.5	0.9	1	1	1
08/09/2014 01:00	0.3	13.7	1,544.6	0.4	0.8	1	1	0
08/09/2014 02:00	17.4	15.7	571.0	0.0	5.5	1	0	0
08/09/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/09/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/09/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/09/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/09/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/09/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/09/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/09/2014 10:00	21.8	16.7	556.0	0.0	25.9	1	1	0
08/09/2014 11:00	3.7	14.0	1,405.4	0.0	10.0	1	1	0
08/09/2014 12:00	0.4	13.7	1,467.0	0.0	1.1	1	1	1
08/09/2014 13:00	0.8	13.0	1,843.8	0.0	2.5	1	1	1
08/09/2014 14:00	0.8	13.0	1,867.8	0.5	2.5	1	1	1
08/09/2014 15:00	1.1	12.6	1,915.0	0.7	3.4	1	1	1
08/09/2014 16:00	1.0	12.7	1,901.3	0.7	3.1	1	1	1
08/09/2014 17:00	0.9	12.8	1,899.9	0.7	2.8	1	1	1
08/09/2014 18:00	1.1	12.2	2,014.3	0.7	3.4	1	1	1
08/09/2014 19:00	0.8	11.4	2,172.3	0.6	2.4	1	1	1
08/09/2014 20:00	0.9	11.8	2,098.2	0.6	2.7	1	1	1
08/09/2014 21:00	0.9	12.0	2,071.3	0.6	2.8	1	1	1
08/09/2014 22:00	0.9	12.5	1,982.5	0.6	2.8	1	1	1
08/09/2014 23:00	0.5	13.4	1,683.2	0.5	1.5	1	1	1
Average/Sum#:	3.2	13.2	1,687.8	0.6	74.1 #	17 #	18 #	13 #
Minimum:	0.3	11.4	556.0	0.4	0.8	0	0	0
Maximum:	21.8	16.7	2,172.3	0.7	25.9	1	1	1
%SI	29.2	29.2	29.2	50.0	29.2	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/10/2014 00:00	18.2	15.7	567.0	0.0	5.8	1	0	0
08/10/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/10/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/10/2014 11:00	35.5	17.0	530.2	0.0	45.9	1	1	0
08/10/2014 12:00	5.6	13.9	1,435.1	0.0	15.2	1	1	1
08/10/2014 13:00	1.0	12.7	1,914.3	0.0	3.1	1	1	1
08/10/2014 14:00	1.1	12.6	1,912.1	0.0	3.3	1	1	1
08/10/2014 15:00	0.8	12.9	1,875.4	0.7	2.5	1	1	1
08/10/2014 16:00	1.1	12.4	1,974.4	0.7	3.4	1	1	1
08/10/2014 17:00	0.9	11.4	2,151.8	0.7	2.7	1	1	1
08/10/2014 18:00	0.8	11.6	2,138.3	0.6	2.4	1	1	1
08/10/2014 19:00	0.8	11.5	2,142.8	0.5	2.4	1	1	1
08/10/2014 20:00	0.9	11.7	2,123.3	0.5	2.7	1	1	1
08/10/2014 21:00	0.9	11.9	2,069.6	0.6	2.7	1	1	1
08/10/2014 22:00	0.9	12.8	1,901.0	0.6	2.8	1	1	1
08/10/2014 23:00	1.1	12.6	1,952.3	0.7	3.4	1	1	1
Average/Sum#:	5.0	12.9	1,763.4	0.6	98.3 #	14 #	15 #	12 #
Minimum:	0.8	11.4	530.2	0.5	2.4	0	0	0
Maximum:	35.5	17.0	2,151.8	0.7	45.9	1	1	1
%SI	41.7	41.7	41.7	62.5	41.7	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/11/2014 00:00	1.1	12.7	1,948.6	0.8	3.5	1	1	1
08/11/2014 01:00	1.1	12.7	1,949.9	0.8	3.5	1	1	1
08/11/2014 02:00	0.9	12.9	1,911.4	0.8	2.8	1	1	1
08/11/2014 03:00	1.1	12.7	1,955.1	0.8	3.5	1	1	1
08/11/2014 04:00	1.1	12.7	1,970.2	0.8	3.5	1	1	1
08/11/2014 05:00	0.9	12.9	1,923.2	0.8	2.9	1	1	1
08/11/2014 06:00	0.9	11.7	2,137.4	0.7	2.8	1	1	1
08/11/2014 07:00	1.1	12.6	1,979.0	0.7	3.5	1	1	1
08/11/2014 08:00	1.1	12.6	1,964.2	0.7	3.4	1	1	1
08/11/2014 09:00	0.9	11.4	2,182.3	0.7	2.7	1	1	1
08/11/2014 10:00	0.8	11.2	2,222.1	0.6	2.4	1	1	1
08/11/2014 11:00	0.7	11.1	2,231.4	0.5	2.1	1	1	1
08/11/2014 12:00	0.7	11.1	2,221.3	0.4	2.1	1	1	1
08/11/2014 13:00	0.8	11.3	2,196.8	0.4	2.4	1	1	1
08/11/2014 14:00	0.7	11.3	2,167.6	0.4	2.1	1	1	1
08/11/2014 15:00	0.8	11.3	2,155.3	0.5	2.4	1	1	1
08/11/2014 16:00	0.8	11.3	2,162.5	0.5	2.4	1	1	1
08/11/2014 17:00	0.8	11.2	2,176.5	0.5	2.4	1	1	1
08/11/2014 18:00	0.8	11.3	2,170.9	0.5	2.4	1	1	1
08/11/2014 19:00	0.7	11.2	2,201.0	0.5	2.1	1	1	1
08/11/2014 20:00	0.8	11.4	2,168.7	0.5	2.4	1	1	1
08/11/2014 21:00	0.9	12.6	1,916.0	0.5	2.7	1	1	1
08/11/2014 22:00	0.3	13.8	1,694.3	0.4	0.9	1	1	0
08/11/2014 23:00	0.3	13.7	1,681.0	0.3	0.9	1	1	0
Average/Sum#:	0.8	12.0	2,053.6	0.6	61.8 #	24 #	24 #	22 #
Minimum:	0.3	11.1	1,681.0	0.3	0.9	1	1	0
Maximum:	1.1	13.8	2,231.4	0.8	3.5	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/12/2014 00:00	0.4	13.8	1,638.6	0.2	1.2	1	1	0
08/12/2014 01:00	0.3	13.8	1,665.7	0.2	0.9	1	1	0
08/12/2014 02:00	0.4	13.8	1,537.8	0.3	1.1	1	1	0
08/12/2014 03:00	0.3	13.8	1,529.6	0.2	0.9	1	1	0
08/12/2014 04:00	0.2	13.8	1,692.4	0.2	0.6	1	1	0
08/12/2014 05:00	0.3	13.7	1,762.6	0.2	1.0	1	1	0
08/12/2014 06:00	0.3	13.7	1,763.6	0.2	1.0	1	1	0
08/12/2014 07:00	0.3	13.7	1,727.9	0.2	1.0	1	1	0
08/12/2014 08:00	0.4	13.8	1,307.3	0.2	1.0	1	1	0
08/12/2014 09:00	0.2	13.8	1,633.8	0.2	0.6	1	1	0
08/12/2014 10:00	0.0	13.6	1,747.8	0.2	0.0	1	1	0
08/12/2014 11:00	0.0	13.8	1,648.9	0.1	0.0	1	1	0
08/12/2014 12:00	0.0	13.7	1,747.5	0.0	0.0	1	1	0
08/12/2014 13:00	0.0	13.7	1,744.8	0.0	0.0	1	1	0
08/12/2014 14:00	0.0	13.7	1,738.7	0.0	0.0	1	1	0
08/12/2014 15:00	0.0	13.7	1,733.5	0.0	0.0	1	1	0
08/12/2014 16:00	0.0	13.7	1,736.9	0.0	0.0	1	1	0
08/12/2014 17:00	0.0	13.7	1,743.3	0.0	0.0	1	1	0
08/12/2014 18:00	0.0	13.7	1,748.3	0.0	0.0	1	1	0
08/12/2014 19:00	0.0	13.7	1,758.2	0.0	0.0	1	1	0
08/12/2014 20:00	0.0	13.6	1,767.2	0.0	0.0	1	1	0
08/12/2014 21:00	0.0	13.6	1,771.8	0.0	0.0	1	1	0
08/12/2014 22:00	0.0	13.6	1,777.3	0.0	0.0	1	1	0
08/12/2014 23:00	0.0	13.6	1,779.5	0.0	0.0	1	1	0
Average/Sum#:	0.1	13.7	1,696.0	0.1	9.3 #	24 #	24 #	0 #
Minimum:	0.0	13.6	1,307.3	0.0	0.0	1	1	0
Maximum:	0.4	13.8	1,779.5	0.3	1.2	1	1	0
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/13/2014 00:00	0.0	13.6	1,772.6	0.0	0.0	1	1	0
08/13/2014 01:00	4.3	14.2	1,386.5	0.0	8.0	1	0	0
08/13/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	1	0
08/13/2014 08:00	15.5	17.3	482.5	0.0	15.9	1	1	0
08/13/2014 09:00	10.0	14.9	1,149.6	0.0	25.3	1	1	0
08/13/2014 10:00	0.0	13.6	1,763.0	0.0	0.0	1	1	0
08/13/2014 11:00	0.0	13.6	1,756.0	0.0	0.0	1	1	0
08/13/2014 12:00	0.0	13.6	1,759.7	0.0	0.0	1	1	0
08/13/2014 13:00	0.0	13.6	1,754.9	0.0	0.0	1	1	0
08/13/2014 14:00	0.0	13.6	1,744.0	0.0	0.0	1	1	0
08/13/2014 15:00	0.0	13.7	1,728.3	0.0	0.0	1	1	0
08/13/2014 16:00	0.0	13.7	1,725.7	0.0	0.0	1	1	0
08/13/2014 17:00	0.0	13.7	1,726.2	0.0	0.0	1	1	0
08/13/2014 18:00	0.0	13.6	1,728.7	0.0	0.0	1	1	0
08/13/2014 19:00	0.0	13.6	1,735.5	0.0	0.0	1	1	0
08/13/2014 20:00	0.0	13.6	1,746.5	0.0	0.0	1	1	0
08/13/2014 21:00	0.0	13.7	1,731.8	0.0	0.0	1	1	0
08/13/2014 22:00	0.0	13.8	1,649.9	0.0	0.0	1	1	0
08/13/2014 23:00	8.6	14.9	929.1	0.0	7.4	1	0	0
Average/Sum#:	2.1	14.0	1,570.6	0.0	56.6 #	18 #	17 #	0 #
Minimum:	0.0	13.6	482.5	0.0	0.0	0	0	0
Maximum:	15.5	17.3	1,772.6	0.0	25.3	1	1	0
%SI	25.0	25.0	25.0	50.0	25.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/14/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/15/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/16/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/17/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/18/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/19/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/20/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/21/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/22/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/23/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/24/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/25/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/26/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/27/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/28/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/29/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/30/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/31/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/01/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/02/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/03/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/04/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/05/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/05/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/05/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/05/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/05/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/05/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/05/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	1	0
09/05/2014 07:00	66.9	17.0	487.1	0.0	79.5	1	1	0
09/05/2014 08:00	17.6	15.2	906.7	0.0	37.0	1	1	0
09/05/2014 09:00	0.0	13.9	1,417.4	0.0	0.0	1	1	0
09/05/2014 10:00	0.0	13.9	1,263.2	0.0	0.0	1	1	0
09/05/2014 11:00	0.0	14.0	1,365.2	0.0	0.0	1	1	0
09/05/2014 12:00	0.0	13.4	1,677.1	0.0	0.0	1	1	1
09/05/2014 13:00	0.0	12.9	1,905.1	0.0	0.0	1	1	1
09/05/2014 14:00	0.0	12.9	1,886.0	0.0	0.0	1	1	1
09/05/2014 15:00	0.0	12.7	1,920.6	0.0	0.0	1	1	1
09/05/2014 16:00	0.0	12.7	1,926.4	0.0	0.0	1	1	1
09/05/2014 17:00	0.0	11.7	2,132.5	0.0	0.0	1	1	1
09/05/2014 18:00	0.0	12.2	2,016.0	0.0	0.0	1	1	1
09/05/2014 19:00	0.0	12.7	1,935.2	0.0	0.0	1	1	1
09/05/2014 20:00	0.0	13.2	1,837.3	0.0	0.0	1	1	1
09/05/2014 21:00	0.0	12.9	1,903.2	0.0	0.0	1	1	1
09/05/2014 22:00	0.0	12.9	1,916.4	0.0	0.0	1	1	1
09/05/2014 23:00	0.0	11.8	2,151.4	0.0	0.0	1	1	1
Average/Sum#:	5.0	13.3	1,685.1	0.0	116.5 #	17 #	19 #	12 #
Minimum:	0.0	11.7	487.1	0.0	0.0	0	0	0
Maximum:	66.9	17.0	2,151.4	0.0	79.5	1	1	1
%SI	29.2	29.2	29.2	45.8	29.2	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/06/2014 00:00	0.0	12.3	2,027.8	0.0	0.0	1	1	1
09/06/2014 01:00	0.0	12.9	1,908.8	0.0	0.0	1	1	1
09/06/2014 02:00	0.0	12.8	1,955.9	0.0	0.0	1	1	1
09/06/2014 03:00	0.0	12.8	1,955.5	0.0	0.0	1	1	1
09/06/2014 04:00	0.0	12.8	1,946.2	0.0	0.0	1	1	1
09/06/2014 05:00	0.0	13.3	1,831.9	0.0	0.0	1	1	1
09/06/2014 06:00	0.0	13.3	1,843.2	0.0	0.0	1	1	1
09/06/2014 07:00	0.0	13.1	1,870.2	0.0	0.0	1	1	1
09/06/2014 08:00	0.0	13.4	1,835.7	0.0	0.0	1	1	1
09/06/2014 09:00	0.0	13.1	1,903.5	0.0	0.0	1	1	1
09/06/2014 10:00	0.0	13.1	1,882.2	0.0	0.0	1	1	1
09/06/2014 11:00	0.0	13.0	1,904.9	0.0	0.0	1	1	1
09/06/2014 12:00	0.0	12.3	2,017.3	0.0	0.0	1	1	1
09/06/2014 13:00	0.0	11.5	2,179.2	0.0	0.0	1	1	1
09/06/2014 14:00	0.0	12.2	2,030.4	0.0	0.0	1	1	1
09/06/2014 15:00	0.0	12.5	1,981.4	0.0	0.0	1	1	1
09/06/2014 16:00	0.0	12.6	1,960.5	0.0	0.0	1	1	1
09/06/2014 17:00	0.0	11.3	2,211.6	0.0	0.0	1	1	1
09/06/2014 18:00	0.0	11.7	2,135.1	0.0	0.0	1	1	1
09/06/2014 19:00	0.0	13.0	1,871.8	0.0	0.0	1	1	1
09/06/2014 20:00	0.0	13.3	1,837.4	0.0	0.0	1	1	1
09/06/2014 21:00	0.0	13.3	1,838.2	0.0	0.0	1	1	1
09/06/2014 22:00	0.0	13.1	1,874.9	0.0	0.0	1	1	1
09/06/2014 23:00	0.0	12.8	1,960.5	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.7	1,948.5	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.3	1,831.9	0.0	0.0	1	1	1
Maximum:	0.0	13.4	2,211.6	0.0	0.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/07/2014 00:00	0.0	13.2	1,874.5	0.0	0.0	1	1	1
09/07/2014 01:00	0.0	13.2	1,880.4	0.0	0.0	1	1	1
09/07/2014 02:00	0.0	13.4	1,833.8	0.0	0.0	1	1	1
09/07/2014 03:00	0.0	13.4	1,830.6	0.0	0.0	1	1	1
09/07/2014 04:00	0.0	13.3	1,829.8	0.0	0.0	1	1	1
09/07/2014 05:00	0.0	13.3	1,831.2	0.0	0.0	1	1	1
09/07/2014 06:00	0.0	13.3	1,825.0	0.0	0.0	1	1	1
09/07/2014 07:00	0.0	13.3	1,836.8	0.0	0.0	1	1	1
09/07/2014 08:00	0.0	13.1	1,907.6	0.0	0.0	1	1	1
09/07/2014 09:00	0.0	12.5	2,008.8	0.0	0.0	1	1	1
09/07/2014 10:00	0.0	12.0	2,096.0	0.0	0.0	1	1	1
09/07/2014 11:00	0.0	12.0	2,082.5	0.0	0.0	1	1	1
09/07/2014 12:00	0.0	12.7	1,944.2	0.0	0.0	1	1	1
09/07/2014 13:00	0.0	12.8	1,927.5	0.0	0.0	1	1	1
09/07/2014 14:00	0.0	12.8	1,919.9	0.0	0.0	1	1	1
09/07/2014 15:00	0.0	12.7	1,933.6	0.0	0.0	1	1	1
09/07/2014 16:00	0.0	12.3	2,025.2	0.0	0.0	1	1	1
09/07/2014 17:00	0.0	11.4	2,182.8	0.0	0.0	1	1	1
09/07/2014 18:00	0.0	11.4	2,181.5	0.0	0.0	1	1	1
09/07/2014 19:00	0.0	11.5	2,179.3	0.0	0.0	1	1	1
09/07/2014 20:00	0.0	12.1	2,049.1	0.0	0.0	1	1	1
09/07/2014 21:00	0.0	13.0	1,873.8	0.0	0.0	1	1	1
09/07/2014 22:00	0.0	13.3	1,832.2	0.0	0.0	1	1	1
09/07/2014 23:00	0.0	13.1	1,897.2	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.7	1,949.3	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.4	1,825.0	0.0	0.0	1	1	1
Maximum:	0.0	13.4	2,182.8	0.0	0.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/08/2014 00:00	0.0	13.6	1,499.4	0.0	0.0	1	1	1
09/08/2014 01:00	0.0	13.9	1,252.9	0.0	0.0	1	1	0
09/08/2014 02:00	0.0	13.9	1,247.5	0.0	0.0	1	1	0
09/08/2014 03:00	0.0	13.8	1,552.8	0.0	0.0	1	1	1
09/08/2014 04:00	0.0	13.0	1,914.5	0.0	0.0	1	1	1
09/08/2014 05:00	0.0	13.2	1,872.9	0.0	0.0	1	1	1
09/08/2014 06:00	0.0	12.3	2,095.5	0.0	0.0	1	1	1
09/08/2014 07:00	0.0	11.2	2,271.1	0.0	0.0	1	1	1
09/08/2014 08:00	0.0	12.0	2,113.0	0.0	0.0	1	1	1
09/08/2014 09:00	0.0	13.4	1,849.0	0.0	0.0	1	1	1
09/08/2014 10:00	0.0	13.4	1,837.1	0.0	0.0	1	1	1
09/08/2014 11:00	0.0	13.4	1,835.5	0.0	0.0	1	1	1
09/08/2014 12:00	0.0	13.3	1,836.3	0.0	0.0	1	1	1
09/08/2014 13:00	0.0	13.3	1,836.4	0.0	0.0	1	1	1
09/08/2014 14:00	0.0	13.3	1,838.3	0.0	0.0	1	1	1
09/08/2014 15:00	0.0	13.2	1,843.0	0.0	0.0	1	1	1
09/08/2014 16:00	0.0	13.4	1,598.3	0.0	0.0	1	1	1
09/08/2014 17:00	0.0	14.0	1,267.0	0.0	0.0	1	1	0
09/08/2014 18:00	0.0	14.0	1,513.3	0.0	0.0	1	1	0
09/08/2014 19:00	0.0	14.0	1,527.9	0.0	0.0	1	1	0
09/08/2014 20:00	0.0	13.9	1,439.8	0.0	0.0	1	1	0
09/08/2014 21:00	0.0	13.9	1,361.4	0.0	0.0	1	1	0
09/08/2014 22:00	0.0	13.9	1,295.7	0.0	0.0	1	1	0
09/08/2014 23:00	0.0	13.9	1,251.0	0.0	0.0	1	1	0
Average/Sum#:	0.0	13.4	1,664.6	0.0	0.0 #	24 #	24 #	15 #
Minimum:	0.0	11.2	1,247.5	0.0	0.0	1	1	0
Maximum:	0.0	14.0	2,271.1	0.0	0.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/09/2014 00:00	0.0	13.9	1,251.7	0.0	0.0	1	1	0
09/09/2014 01:00	0.0	13.9	1,251.6	0.0	0.0	1	1	0
09/09/2014 02:00	0.0	13.9	1,252.0	0.0	0.0	1	1	0
09/09/2014 03:00	0.0	13.9	1,353.2	0.0	0.0	1	1	0
09/09/2014 04:00	0.0	13.9	1,265.9	0.0	0.0	1	1	0
09/09/2014 05:00	0.0	13.9	1,304.7	0.0	0.0	1	1	0
09/09/2014 06:00	0.0	13.9	1,259.0	0.0	0.0	1	1	0
09/09/2014 07:00	0.0	13.9	1,266.0	0.0	0.0	1	1	0
09/09/2014 08:00	0.0	13.7	1,561.4	0.0	0.0	1	1	1
09/09/2014 09:00	0.0	13.3	1,862.9	0.0	0.0	1	1	1
09/09/2014 10:00	0.0	13.3	1,846.7	0.0	0.0	1	1	1
09/09/2014 11:00	0.0	13.2	1,841.0	0.0	0.0	1	1	1
09/09/2014 12:00	0.0	12.9	1,905.0	0.0	0.0	1	1	1
09/09/2014 13:00	0.0	12.7	1,909.4	0.0	0.0	1	1	1
09/09/2014 14:00	0.0	12.9	1,867.0	0.0	0.0	1	1	1
09/09/2014 15:00	0.0	13.0	1,846.3	0.0	0.0	1	1	1
09/09/2014 16:00	0.0	12.9	1,841.1	0.0	0.0	1	1	1
09/09/2014 17:00	0.0	12.9	1,854.0	0.0	0.0	1	1	1
09/09/2014 18:00	0.0	13.0	1,836.8	0.0	0.0	1	1	1
09/09/2014 19:00	0.0	13.0	1,835.2	0.0	0.0	1	1	1
09/09/2014 20:00	0.0	13.0	1,859.3	0.0	0.0	1	1	1
09/09/2014 21:00	0.0	12.8	1,890.8	0.0	0.0	1	1	1
09/09/2014 22:00	0.0	13.0	1,872.5	0.0	0.0	1	1	1
09/09/2014 23:00	0.0	12.5	1,975.6	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.3	1,658.7	0.0	0.0 #	24 #	24 #	16 #
Minimum:	0.0	12.5	1,251.6	0.0	0.0	1	1	0
Maximum:	0.0	13.9	1,975.6	0.0	0.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/10/2014 00:00	0.0	12.5	1,978.6	0.0	0.0	1	1	1
09/10/2014 01:00	0.0	12.5	1,976.5	0.0	0.0	1	1	1
09/10/2014 02:00	0.0	13.0	1,874.7	0.0	0.0	1	1	1
09/10/2014 03:00	0.0	12.7	1,944.2	0.0	0.0	1	1	1
09/10/2014 04:00	0.0	12.4	1,996.4	0.0	0.0	1	1	1
09/10/2014 05:00	0.0	12.8	1,935.7	0.0	0.0	1	1	1
09/10/2014 06:00	0.0	13.3	1,831.2	0.0	0.0	1	1	1
09/10/2014 07:00	0.0	13.3	1,828.7	0.0	0.0	1	1	1
09/10/2014 08:00	0.0	13.3	1,828.2	0.0	0.0	1	1	1
09/10/2014 09:00	0.0	12.9	1,886.9	0.0	0.0	1	1	1
09/10/2014 10:00	0.0	13.6	1,537.8	0.0	0.0	1	1	1
09/10/2014 11:00	0.0	14.0	1,256.9	0.0	0.0	1	1	0
09/10/2014 12:00	0.0	13.4	1,709.3	0.0	0.0	1	1	1
09/10/2014 13:00	0.0	12.9	1,906.8	0.0	0.0	1	1	1
09/10/2014 14:00	0.0	12.7	1,952.5	0.0	0.0	1	1	1
09/10/2014 15:00	0.0	11.6	2,159.4	0.0	0.0	1	1	1
09/10/2014 16:00	0.0	11.3	2,208.6	0.0	0.0	1	1	1
09/10/2014 17:00	0.0	11.3	2,209.1	0.0	0.0	1	1	1
09/10/2014 18:00	0.0	11.4	2,186.6	0.0	0.0	1	1	1
09/10/2014 19:00	0.0	11.7	2,140.0	0.0	0.0	1	1	1
09/10/2014 20:00	0.0	12.0	2,069.1	0.0	0.0	1	1	1
09/10/2014 21:00	0.0	12.4	2,018.2	0.0	0.0	1	1	1
09/10/2014 22:00	0.0	12.5	2,006.7	0.0	0.0	1	1	1
09/10/2014 23:00	0.0	12.1	2,085.9	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.6	1,938.7	0.0	0.0 #	24 #	24 #	23 #
Minimum:	0.0	11.3	1,256.9	0.0	0.0	1	1	0
Maximum:	0.0	14.0	2,209.1	0.0	0.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/11/2014 00:00	0.0	12.8	1,941.4	0.0	0.0	1	1	1
09/11/2014 01:00	0.0	13.3	1,840.4	0.0	0.0	1	1	1
09/11/2014 02:00	0.0	13.3	1,840.4	0.0	0.0	1	1	1
09/11/2014 03:00	0.0	13.3	1,839.9	0.0	0.0	1	1	1
09/11/2014 04:00	0.0	13.0	1,917.6	0.0	0.0	1	1	1
09/11/2014 05:00	0.0	12.3	2,051.4	0.0	0.0	1	1	1
09/11/2014 06:00	0.0	12.7	1,972.7	0.0	0.0	1	1	1
09/11/2014 07:00	0.0	12.8	1,957.7	0.0	0.0	1	1	1
09/11/2014 08:00	0.0	12.9	1,933.8	0.0	0.0	1	1	1
09/11/2014 09:00	0.0	12.7	1,978.6	0.0	0.0	1	1	1
09/11/2014 10:00	0.0	12.2	2,066.1	0.0	0.0	1	1	1
09/11/2014 11:00	0.0	11.9	2,091.6	0.0	0.0	1	1	1
09/11/2014 12:00	0.0	12.9	1,892.4	0.0	0.0	1	1	1
09/11/2014 13:00	0.0	12.9	1,884.0	0.0	0.0	1	1	1
09/11/2014 14:00	0.0	13.0	1,863.3	0.0	0.0	1	1	1
09/11/2014 15:00	0.0	13.0	1,872.0	0.0	0.0	1	1	1
09/11/2014 16:00	0.0	12.1	2,072.6	0.0	0.0	1	1	1
09/11/2014 17:00	0.0	11.4	2,191.8	0.0	0.0	1	1	1
09/11/2014 18:00	0.0	11.3	2,211.6	0.0	0.0	1	1	1
09/11/2014 19:00	0.0	11.6	2,147.1	0.0	0.0	1	1	1
09/11/2014 20:00	0.0	11.6	2,154.3	0.0	0.0	1	1	1
09/11/2014 21:00	0.0	12.4	1,995.9	0.0	0.0	1	1	1
09/11/2014 22:00	0.0	12.3	2,035.0	0.0	0.0	1	1	1
09/11/2014 23:00	0.0	11.4	2,231.2	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.5	1,999.3	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.3	1,839.9	0.0	0.0	1	1	1
Maximum:	0.0	13.3	2,231.2	0.0	0.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/12/2014 00:00	0.0	11.8	2,143.7	0.0	0.0	1	1	1
09/12/2014 01:00	0.0	12.8	1,908.6	0.0	0.0	1	1	1
09/12/2014 02:00	0.0	12.3	1,986.1	0.0	0.0	1	1	1
09/12/2014 03:00	0.0	12.3	2,018.6	0.0	0.0	1	1	1
09/12/2014 04:00	0.0	11.5	2,219.1	0.0	0.0	1	1	1
09/12/2014 05:00	0.0	11.7	2,185.3	0.0	0.0	1	1	1
09/12/2014 06:00	0.0	11.5	2,230.8	0.0	0.0	1	1	1
09/12/2014 07:00	0.0	11.6	2,207.0	0.0	0.0	1	1	1
09/12/2014 08:00	0.0	11.9	2,125.9	0.0	0.0	1	1	1
09/12/2014 09:00	0.0	11.5	2,208.4	0.0	0.0	1	1	1
09/12/2014 10:00	0.0	11.6	2,192.6	0.0	0.0	1	1	1
09/12/2014 11:00	0.0	11.5	2,188.0	0.0	0.0	1	1	1
09/12/2014 12:00	0.0	11.4	2,204.7	0.0	0.0	1	1	1
09/12/2014 13:00	0.0	11.3	2,211.7	0.0	0.0	1	1	1
09/12/2014 14:00	0.0	11.4	2,172.6	0.0	0.0	1	1	1
09/12/2014 15:00	0.0	11.4	2,171.6	0.0	0.0	1	1	1
09/12/2014 16:00	0.0	11.4	2,161.7	0.0	0.0	1	1	1
09/12/2014 17:00	0.0	11.3	2,193.2	0.0	0.0	1	1	1
09/12/2014 18:00	0.0	11.3	2,206.3	0.0	0.0	1	1	1
09/12/2014 19:00	0.0	11.2	2,225.5	0.0	0.0	1	1	1
09/12/2014 20:00	0.0	11.7	2,163.5	0.0	0.0	1	1	1
09/12/2014 21:00	0.0	12.0	2,085.3	0.0	0.0	1	1	1
09/12/2014 22:00	0.0	12.7	1,950.5	0.0	0.0	1	1	1
09/12/2014 23:00	0.0	12.7	1,955.3	0.0	0.0	1	1	1
Average/Sum#:	0.0	11.7	2,138.2	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.2	1,908.6	0.0	0.0	1	1	1
Maximum:	0.0	12.8	2,230.8	0.0	0.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/13/2014 00:00	0.0	12.8	1,947.8	0.0	0.0	1	1	1
09/13/2014 01:00	0.0	12.9	1,918.2	0.0	0.0	1	1	1
09/13/2014 02:00	0.0	13.5	1,794.1	0.0	0.0	1	1	1
09/13/2014 03:00	0.0	13.3	1,846.3	0.0	0.0	1	1	1
09/13/2014 04:00	0.0	13.3	1,781.3	0.0	0.0	1	1	1
09/13/2014 05:00	0.0	13.9	1,256.8	0.0	0.0	1	1	0
09/13/2014 06:00	0.0	13.9	1,250.0	0.0	0.0	1	1	0
09/13/2014 07:00	0.0	13.9	1,249.9	0.0	0.0	1	1	0
09/13/2014 08:00	0.0	13.9	1,388.3	0.0	0.0	1	1	0
09/13/2014 09:00	0.0	14.0	1,509.1	0.0	0.0	1	1	0
09/13/2014 10:00	0.0	13.8	1,573.8	0.0	0.0	1	1	1
09/13/2014 11:00	0.0	12.6	1,978.8	0.0	0.0	1	1	1
09/13/2014 12:00	0.0	11.8	2,102.5	0.0	0.0	1	1	1
09/13/2014 13:00	0.0	12.3	1,997.1	0.0	0.0	1	1	1
09/13/2014 14:00	0.0	12.2	2,004.0	0.0	0.0	1	1	1
09/13/2014 15:00	0.0	11.7	2,108.0	0.0	0.0	1	1	1
09/13/2014 16:00	0.0	11.7	2,089.4	0.0	0.0	1	1	1
09/13/2014 17:00	0.0	11.9	2,062.6	0.0	0.0	1	1	1
09/13/2014 18:00	0.0	12.5	1,957.2	0.0	0.0	1	1	1
09/13/2014 19:00	0.0	12.3	2,008.7	0.0	0.0	1	1	1
09/13/2014 20:00	0.0	12.7	1,949.5	0.0	0.0	1	1	1
09/13/2014 21:00	0.0	12.7	1,948.4	0.0	0.0	1	1	1
09/13/2014 22:00	0.0	12.9	1,911.1	0.0	0.0	1	1	1
09/13/2014 23:00	0.0	12.8	1,941.9	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.9	1,815.6	0.0	0.0 #	24 #	24 #	19 #
Minimum:	0.0	11.7	1,249.9	0.0	0.0	1	1	0
Maximum:	0.0	14.0	2,108.0	0.0	0.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/14/2014 00:00	0.0	13.0	1,896.9	0.0	0.0	1	1	1
09/14/2014 01:00	0.0	13.2	1,850.9	0.0	0.0	1	1	1
09/14/2014 02:00	0.0	13.3	1,844.9	0.0	0.0	1	1	1
09/14/2014 03:00	0.0	13.3	1,847.9	0.0	0.0	1	1	1
09/14/2014 04:00	0.0	13.3	1,793.5	0.0	0.0	1	1	1
09/14/2014 05:00	0.0	13.9	1,262.0	0.0	0.0	1	1	0
09/14/2014 06:00	0.0	13.9	1,250.7	0.0	0.0	1	1	0
09/14/2014 07:00	0.0	13.9	1,251.1	0.0	0.0	1	1	0
09/14/2014 08:00	0.0	13.9	1,435.4	0.0	0.0	1	1	0
09/14/2014 09:00	0.0	13.5	1,631.5	0.0	0.0	1	1	1
09/14/2014 10:00	0.0	13.0	1,900.7	0.0	0.0	1	1	1
09/14/2014 11:00	0.0	12.7	1,945.9	0.0	0.0	1	1	1
09/14/2014 12:00	0.0	11.6	2,169.8	0.0	0.0	1	1	1
09/14/2014 13:00	0.0	11.5	2,182.9	0.0	0.0	1	1	1
09/14/2014 14:00	0.0	11.5	2,173.9	0.0	0.0	1	1	1
09/14/2014 15:00	0.0	11.4	2,158.0	0.0	0.0	1	1	1
09/14/2014 16:00	0.0	11.4	2,151.0	0.0	0.0	1	1	1
09/14/2014 17:00	0.0	11.5	2,139.0	0.0	0.0	1	1	1
09/14/2014 18:00	0.0	11.6	2,129.5	0.0	0.0	1	1	1
09/14/2014 19:00	0.0	11.8	2,100.9	0.0	0.0	1	1	1
09/14/2014 20:00	0.0	12.1	2,057.1	0.0	0.0	1	1	1
09/14/2014 21:00	0.0	12.4	1,995.9	0.0	0.0	1	1	1
09/14/2014 22:00	0.0	12.8	1,916.5	0.0	0.0	1	1	1
09/14/2014 23:00	0.0	12.9	1,910.6	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.6	1,874.9	0.0	0.0 #	24 #	24 #	20 #
Minimum:	0.0	11.4	1,250.7	0.0	0.0	1	1	0
Maximum:	0.0	13.9	2,182.9	0.0	0.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/15/2014 00:00	0.0	13.1	1,857.7	0.0	0.0	1	1	1
09/15/2014 01:00	0.0	13.3	1,834.3	0.0	0.0	1	1	1
09/15/2014 02:00	0.0	13.3	1,832.1	0.0	0.0	1	1	1
09/15/2014 03:00	0.0	13.3	1,835.5	0.0	0.0	1	1	1
09/15/2014 04:00	0.0	13.3	1,838.7	0.0	0.0	1	1	1
09/15/2014 05:00	0.0	13.3	1,841.7	0.0	0.0	1	1	1
09/15/2014 06:00	0.0	13.3	1,842.9	0.0	0.0	1	1	1
09/15/2014 07:00	0.0	13.2	1,861.7	0.0	0.0	1	1	1
09/15/2014 08:00	0.0	12.7	1,955.4	0.0	0.0	1	1	1
09/15/2014 09:00	0.0	12.0	2,108.6	0.0	0.0	1	1	1
09/15/2014 10:00	0.0	11.6	2,166.7	0.0	0.0	1	1	1
09/15/2014 11:00	0.0	11.5	2,173.6	0.0	0.0	1	1	1
09/15/2014 12:00	0.0	12.5	1,797.4	0.0	0.0	1	1	1
09/15/2014 13:00	0.0	14.0	1,320.5	0.0	0.0	1	1	0
09/15/2014 14:00	0.0	14.0	1,328.8	0.0	0.0	1	1	0
09/15/2014 15:00	0.0	12.7	1,902.1	0.0	0.0	1	1	1
09/15/2014 16:00	0.0	11.9	2,092.5	0.0	0.0	1	1	1
09/15/2014 17:00	0.0	12.0	2,080.7	0.0	0.0	1	1	1
09/15/2014 18:00	0.0	12.2	2,060.0	0.0	0.0	1	1	1
09/15/2014 19:00	0.0	12.3	2,039.2	0.0	0.0	1	1	1
09/15/2014 20:00	0.0	12.5	2,012.4	0.0	0.0	1	1	1
09/15/2014 21:00	0.0	13.0	1,904.8	0.0	0.0	1	1	1
09/15/2014 22:00	0.0	13.4	1,831.1	0.0	0.0	1	1	1
09/15/2014 23:00	0.0	13.3	1,841.8	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.8	1,890.0	0.0	0.0 #	24 #	24 #	22 #
Minimum:	0.0	11.5	1,320.5	0.0	0.0	1	1	0
Maximum:	0.0	14.0	2,173.6	0.0	0.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/16/2014 00:00	0.0	13.4	1,832.9	0.0	0.0	1	1	1
09/16/2014 01:00	0.0	13.4	1,829.4	0.0	0.0	1	1	1
09/16/2014 02:00	0.0	13.7	1,573.8	0.0	0.0	1	1	1
09/16/2014 03:00	0.0	13.8	1,276.0	0.0	0.0	1	1	0
09/16/2014 04:00	0.0	13.6	1,654.2	0.0	0.0	1	1	1
09/16/2014 05:00	0.0	13.0	1,925.0	0.0	0.0	1	1	1
09/16/2014 06:00	0.0	13.0	1,937.8	0.0	0.0	1	1	1
09/16/2014 07:00	0.0	12.7	1,977.1	0.0	0.0	1	1	1
09/16/2014 08:00	0.0	12.6	2,006.5	0.0	0.0	1	1	1
09/16/2014 09:00	0.0	12.6	2,006.7	0.0	0.0	1	1	1
09/16/2014 10:00	0.0	11.8	2,159.6	0.0	0.0	1	1	1
09/16/2014 11:00	0.0	11.8	2,165.5	0.0	0.0	1	1	1
09/16/2014 12:00	0.0	11.8	2,169.1	0.0	0.0	1	1	1
09/16/2014 13:00	0.0	11.8	2,159.3	0.0	0.0	1	1	1
09/16/2014 14:00	0.0	12.5	2,008.1	0.0	0.0	1	1	1
09/16/2014 15:00	0.0	12.9	1,918.3	0.0	0.0	1	1	1
09/16/2014 16:00	0.0	12.4	2,036.8	0.0	0.0	1	1	1
09/16/2014 17:00	0.0	11.7	2,171.7	0.0	0.0	1	1	1
09/16/2014 18:00	0.0	11.7	2,176.0	0.0	0.0	1	1	1
09/16/2014 19:00	0.0	11.7	2,182.3	0.0	0.0	1	1	1
09/16/2014 20:00	0.0	12.0	2,128.7	0.0	0.0	1	1	1
09/16/2014 21:00	0.0	13.1	1,884.6	0.0	0.0	1	1	1
09/16/2014 22:00	0.0	13.6	1,691.0	0.0	0.0	1	1	1
09/16/2014 23:00	0.0	13.6	1,787.1	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.7	1,944.1	0.0	0.0 #	24 #	24 #	23 #
Minimum:	0.0	11.7	1,276.0	0.0	0.0	1	1	0
Maximum:	0.0	13.8	2,182.3	0.0	0.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/17/2014 00:00	0.0	12.2	2,110.1	0.0	0.0	1	1	1
09/17/2014 01:00	0.0	12.2	2,099.8	0.0	0.0	1	1	1
09/17/2014 02:00	0.0	12.7	1,997.5	0.0	0.0	1	1	1
09/17/2014 03:00	0.0	11.9	2,161.2	0.0	0.0	1	1	1
09/17/2014 04:00	0.0	11.8	2,170.8	0.0	0.0	1	1	1
09/17/2014 05:00	0.0	12.0	2,143.1	0.0	0.0	1	1	1
09/17/2014 06:00	0.0	12.0	2,146.1	0.0	0.0	1	1	1
09/17/2014 07:00	0.0	11.8	2,166.7	0.0	0.0	1	1	1
09/17/2014 08:00	0.0	11.9	2,151.3	0.0	0.0	1	1	1
09/17/2014 09:00	0.0	11.9	2,128.3	0.0	0.0	1	1	1
09/17/2014 10:00	0.0	11.9	2,140.8	0.0	0.0	1	1	1
09/17/2014 11:00	0.0	11.8	2,157.0	0.0	0.0	1	1	1
09/17/2014 12:00	0.0	11.6	2,173.9	0.0	0.0	1	1	1
09/17/2014 13:00	0.0	11.7	2,153.5	0.0	0.0	1	1	1
09/17/2014 14:00	0.0	11.9	2,105.8	0.0	0.0	1	1	1
09/17/2014 15:00	0.0	12.1	2,070.4	0.0	0.0	1	1	1
09/17/2014 16:00	0.0	12.7	1,962.9	0.0	0.0	1	1	1
09/17/2014 17:00	0.0	12.7	1,962.2	0.0	0.0	1	1	1
09/17/2014 18:00	0.0	12.2	2,043.2	0.0	0.0	1	1	1
09/17/2014 19:00	0.0	12.5	1,977.0	0.0	0.0	1	1	1
09/17/2014 20:00	0.0	12.6	1,968.1	0.0	0.0	1	1	1
09/17/2014 21:00	0.0	13.2	1,845.7	0.0	0.0	1	1	1
09/17/2014 22:00	0.0	13.2	1,848.0	0.0	0.0	1	1	1
09/17/2014 23:00	0.0	13.2	1,857.6	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.2	2,064.2	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.6	1,845.7	0.0	0.0	1	1	1
Maximum:	0.0	13.2	2,173.9	0.0	0.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/18/2014 00:00	0.0	12.7	1,968.3	0.0	0.0	1	1	1
09/18/2014 01:00	0.0	12.8	1,938.5	0.0	0.0	1	1	1
09/18/2014 02:00	0.0	13.3	1,848.5	0.0	0.0	1	1	1
09/18/2014 03:00	0.0	13.3	1,773.0	0.0	0.0	1	1	1
09/18/2014 04:00	0.0	13.8	1,568.1	0.0	0.0	1	1	0
09/18/2014 05:00	0.0	13.8	1,602.3	0.0	0.0	1	1	0
09/18/2014 06:00	0.0	13.8	1,585.4	0.0	0.0	1	1	0
09/18/2014 07:00	0.0	13.8	1,302.1	0.0	0.0	1	1	0
09/18/2014 08:00	0.0	13.8	1,409.6	0.0	0.0	1	1	0
09/18/2014 09:00	0.0	13.8	1,586.9	0.0	0.0	1	1	0
09/18/2014 10:00	0.0	13.9	1,286.1	0.0	0.0	1	1	0
09/18/2014 11:00	0.0	13.9	1,284.8	0.0	0.0	1	1	0
09/18/2014 12:00	0.0	13.9	1,475.6	0.0	0.0	1	1	0
09/18/2014 13:00	0.0	13.9	1,601.9	0.0	0.0	1	1	0
09/18/2014 14:00	0.0	13.8	1,664.2	0.0	0.0	1	1	0
09/18/2014 15:00	0.0	13.8	1,588.4	0.0	0.0	1	1	0
09/18/2014 16:00	0.0	13.5	1,711.8	0.0	0.0	1	1	1
09/18/2014 17:00	0.0	12.7	1,937.4	0.0	0.0	1	1	1
09/18/2014 18:00	0.0	12.3	2,023.1	0.0	0.0	1	1	1
09/18/2014 19:00	0.0	12.2	2,034.4	0.0	0.0	1	1	1
09/18/2014 20:00	0.0	13.1	1,849.5	0.0	0.0	1	1	1
09/18/2014 21:00	0.0	13.4	1,582.7	0.0	0.0	1	1	1
09/18/2014 22:00	0.0	13.9	1,238.1	0.0	0.0	1	1	0
09/18/2014 23:00	0.0	13.9	1,362.3	0.0	0.0	1	1	0
Average/Sum#:	0.0	13.5	1,634.3	0.0	0.0 #	24 #	24 #	10 #
Minimum:	0.0	12.2	1,238.1	0.0	0.0	1	1	0
Maximum:	0.0	13.9	2,034.4	0.0	0.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/19/2014 00:00	0.0	13.9	1,257.8	0.0	0.0	1	1	0
09/19/2014 01:00	0.0	13.9	1,248.4	0.0	0.0	1	1	0
09/19/2014 02:00	0.0	13.9	1,246.9	0.0	0.0	1	1	0
09/19/2014 03:00	0.0	13.9	1,314.6	0.0	0.0	1	1	0
09/19/2014 04:00	0.0	13.9	1,338.4	0.0	0.0	1	1	0
09/19/2014 05:00	0.0	13.6	1,612.1	0.0	0.0	1	1	1
09/19/2014 06:00	0.0	12.8	1,931.9	0.0	0.0	1	1	1
09/19/2014 07:00	0.0	13.3	1,840.9	0.0	0.0	1	1	1
09/19/2014 08:00	0.0	13.2	1,854.7	0.0	0.0	1	1	1
09/19/2014 09:00	0.0	13.2	1,864.3	0.0	0.0	1	1	1
09/19/2014 10:00	0.0	13.2	1,838.8	0.0	0.0	1	1	1
09/19/2014 11:00	0.0	13.2	1,840.3	0.0	0.0	1	1	1
09/19/2014 12:00	0.0	12.6	1,944.1	0.0	0.0	1	1	1
09/19/2014 13:00	0.0	12.6	1,942.2	0.0	0.0	1	1	1
09/19/2014 14:00	0.0	12.4	1,991.0	0.0	0.0	1	1	1
09/19/2014 15:00	0.0	11.4	2,166.7	0.0	0.0	1	1	1
09/19/2014 16:00	0.0	11.4	2,171.4	0.0	0.0	1	1	1
09/19/2014 17:00	0.0	11.5	2,166.1	0.0	0.0	1	1	1
09/19/2014 18:00	0.0	11.9	2,081.5	0.0	0.0	1	1	1
09/19/2014 19:00	0.0	12.8	1,915.8	0.0	0.0	1	1	1
09/19/2014 20:00	0.0	12.9	1,906.0	0.0	0.0	1	1	1
09/19/2014 21:00	0.0	12.8	1,917.5	0.0	0.0	1	1	1
09/19/2014 22:00	0.0	12.7	1,955.5	0.0	0.0	1	1	1
09/19/2014 23:00	0.0	12.5	2,001.2	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.9	1,806.2	0.0	0.0 #	24 #	24 #	19 #
Minimum:	0.0	11.4	1,246.9	0.0	0.0	1	1	0
Maximum:	0.0	13.9	2,171.4	0.0	0.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/20/2014 00:00	0.0	12.3	2,042.4	0.0	0.0	1	1	1
09/20/2014 01:00	0.0	11.8	2,125.5	0.0	0.0	1	1	1
09/20/2014 02:00	0.0	12.6	1,975.2	0.0	0.0	1	1	1
09/20/2014 03:00	0.0	12.6	1,970.8	0.0	0.0	1	1	1
09/20/2014 04:00	0.0	12.6	1,985.1	0.0	0.0	1	1	1
09/20/2014 05:00	0.0	12.7	1,956.6	0.0	0.0	1	1	1
09/20/2014 06:00	0.0	12.7	1,971.3	0.0	0.0	1	1	1
09/20/2014 07:00	0.0	12.6	1,979.2	0.0	0.0	1	1	1
09/20/2014 08:00	0.0	13.2	1,842.3	0.0	0.0	1	1	1
09/20/2014 09:00	0.0	13.2	1,840.5	0.0	0.0	1	1	1
09/20/2014 10:00	0.0	13.2	1,839.2	0.0	0.0	1	1	1
09/20/2014 11:00	0.0	13.2	1,839.3	0.0	0.0	1	1	1
09/20/2014 12:00	0.0	13.1	1,842.8	0.0	0.0	1	1	1
09/20/2014 13:00	0.0	12.9	1,878.6	0.0	0.0	1	1	1
09/20/2014 14:00	0.0	12.9	1,887.2	0.0	0.0	1	1	1
09/20/2014 15:00	0.0	12.8	1,903.6	0.0	0.0	1	1	1
09/20/2014 16:00	0.0	13.1	1,855.2	0.0	0.0	1	1	1
09/20/2014 17:00	0.0	12.7	1,917.3	0.0	0.0	1	1	1
09/20/2014 18:00	0.0	12.7	1,927.9	0.0	0.0	1	1	1
09/20/2014 19:00	0.0	12.1	2,043.5	0.0	0.0	1	1	1
09/20/2014 20:00	0.0	13.0	1,870.8	0.0	0.0	1	1	1
09/20/2014 21:00	0.0	12.7	1,928.5	0.0	0.0	1	1	1
09/20/2014 22:00	0.0	13.2	1,846.4	0.0	0.0	1	1	1
09/20/2014 23:00	0.0	13.0	1,893.3	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.8	1,923.4	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.8	1,839.2	0.0	0.0	1	1	1
Maximum:	0.0	13.2	2,125.5	0.0	0.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/21/2014 00:00	0.0	13.3	1,836.2	0.0	0.0	1	1	1
09/21/2014 01:00	0.0	13.3	1,835.6	0.0	0.0	1	1	1
09/21/2014 02:00	0.0	13.3	1,836.9	0.0	0.0	1	1	1
09/21/2014 03:00	0.0	13.3	1,834.8	0.0	0.0	1	1	1
09/21/2014 04:00	0.0	13.3	1,837.7	0.0	0.0	1	1	1
09/21/2014 05:00	0.0	13.3	1,837.9	0.0	0.0	1	1	1
09/21/2014 06:00	0.0	13.3	1,841.4	0.0	0.0	1	1	1
09/21/2014 07:00	0.0	13.3	1,846.5	0.0	0.0	1	1	1
09/21/2014 08:00	0.0	13.3	1,838.6	0.0	0.0	1	1	1
09/21/2014 09:00	0.0	13.3	1,836.7	0.0	0.0	1	1	1
09/21/2014 10:00	0.0	13.2	1,837.4	0.0	0.0	1	1	1
09/21/2014 11:00	0.0	13.2	1,719.9	0.0	0.0	1	1	1
09/21/2014 12:00	0.0	13.9	1,252.8	0.0	0.0	1	1	0
09/21/2014 13:00	0.0	13.9	1,244.6	0.0	0.0	1	1	0
09/21/2014 14:00	0.0	13.9	1,250.8	0.0	0.0	1	1	0
09/21/2014 15:00	0.0	13.9	1,261.7	0.0	0.0	1	1	0
09/21/2014 16:00	0.0	13.9	1,277.3	0.0	0.0	1	1	0
09/21/2014 17:00	0.0	13.5	1,701.1	0.0	0.0	1	1	1
09/21/2014 18:00	0.0	13.1	1,859.4	0.0	0.0	1	1	1
09/21/2014 19:00	0.0	12.9	1,907.6	0.0	0.0	1	1	1
09/21/2014 20:00	0.0	13.2	1,833.1	0.0	0.0	1	1	1
09/21/2014 21:00	0.0	13.2	1,832.7	0.0	0.0	1	1	1
09/21/2014 22:00	0.0	13.5	1,518.6	0.0	0.0	1	1	1
09/21/2014 23:00	0.0	13.8	1,244.1	0.0	0.0	1	1	0
Average/Sum#:	0.0	13.4	1,671.8	0.0	0.0 #	24 #	24 #	18 #
Minimum:	0.0	12.9	1,244.1	0.0	0.0	1	1	0
Maximum:	0.0	13.9	1,907.6	0.0	0.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/22/2014 00:00	0.0	13.8	1,244.2	0.0	0.0	1	1	0
09/22/2014 01:00	0.0	13.8	1,242.9	0.0	0.0	1	1	0
09/22/2014 02:00	0.0	13.8	1,271.7	0.0	0.0	1	1	0
09/22/2014 03:00	0.0	13.5	1,697.1	0.0	0.0	1	1	1
09/22/2014 04:00	0.0	13.3	1,850.1	0.0	0.0	1	1	1
09/22/2014 05:00	0.0	13.0	1,916.2	0.0	0.0	1	1	1
09/22/2014 06:00	0.0	12.5	2,016.7	0.0	0.0	1	1	1
09/22/2014 07:00	0.0	13.8	1,394.1	0.0	0.0	1	1	1
09/22/2014 08:00	0.0	13.8	1,276.4	0.0	0.0	1	1	0
09/22/2014 09:00	0.0	0.0	1,275.0	0.0	0.0	1	1	0
09/22/2014 10:00	0.0	0.0	1,287.8	0.0	0.0	1	1	0
09/22/2014 11:00	0.0	0.0	1,408.5	0.0	0.0	1	1	0
09/22/2014 12:00	0.0	0.0	1,724.1	0.0	0.0	1	1	0
09/22/2014 13:00	0.1	13.6	1,687.0	0.0	0.3	1	1	0
09/22/2014 14:00	0.1	13.6	1,726.9	0.0	0.3	1	1	0
09/22/2014 15:00	0.1	13.6	1,722.3	0.1	0.3	1	1	0
09/22/2014 16:00	0.1	13.6	1,722.1	0.1	0.3	1	1	0
09/22/2014 17:00	0.1	13.6	1,725.3	0.1	0.3	1	1	0
09/22/2014 18:00	0.1	13.6	1,730.8	0.1	0.3	1	1	0
09/22/2014 19:00	0.1	13.6	1,737.3	0.1	0.3	1	1	0
09/22/2014 20:00	0.1	13.6	1,736.3	0.1	0.3	1	1	0
09/22/2014 21:00	0.1	13.7	1,706.6	0.1	0.3	1	1	0
09/22/2014 22:00	0.1	13.8	1,544.3	0.1	0.3	1	1	0
09/22/2014 23:00	0.1	13.8	1,673.3	0.1	0.3	1	1	0
Average/Sum#:	0.1	13.6	1,596.5	0.1	3.3 #	24 #	24 #	5 #
Minimum:	0.0	12.5	1,242.9	0.0	0.0	1	1	0
Maximum:	0.1	13.8	2,016.7	0.1	0.3	1	1	1
%SI	16.7	16.7	0.0	25.0	16.7	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/23/2014 00:00	0.1	13.8	1,625.7	0.1	0.3	1	1	0
09/23/2014 01:00	0.1	13.8	1,589.9	0.1	0.3	1	1	0
09/23/2014 02:00	0.1	13.8	1,581.0	0.1	0.3	1	1	0
09/23/2014 03:00	0.1	13.7	1,695.5	0.1	0.3	1	1	0
09/23/2014 04:00	0.1	13.7	1,716.1	0.1	0.3	1	1	0
09/23/2014 05:00	0.1	13.7	1,720.3	0.1	0.3	1	1	0
09/23/2014 06:00	0.1	13.6	1,783.8	0.1	0.3	1	1	0
09/23/2014 07:00	0.1	13.8	1,680.2	0.1	0.3	1	1	0
09/23/2014 08:00	0.1	13.8	1,302.0	0.1	0.2	1	1	0
09/23/2014 09:00	0.1	13.8	1,283.9	0.1	0.2	1	1	0
09/23/2014 10:00	0.1	13.9	1,276.0	0.1	0.2	1	1	0
09/23/2014 11:00	0.0	13.9	1,461.2	0.1	0.0	1	1	0
09/23/2014 12:00	0.0	13.8	1,657.4	0.0	0.0	1	1	0
09/23/2014 13:00	0.1	13.8	1,642.1	0.0	0.3	1	1	0
09/23/2014 14:00	0.1	13.7	1,735.0	0.1	0.3	1	1	0
09/23/2014 15:00	0.1	13.7	1,734.7	0.1	0.3	1	1	0
09/23/2014 16:00	0.1	13.7	1,730.7	0.1	0.3	1	1	0
09/23/2014 17:00	0.1	13.7	1,733.8	0.1	0.3	1	1	0
09/23/2014 18:00	0.1	13.7	1,743.7	0.1	0.3	1	1	0
09/23/2014 19:00	0.1	13.7	1,749.9	0.1	0.3	1	1	0
09/23/2014 20:00	0.1	13.7	1,696.6	0.1	0.3	1	1	0
09/23/2014 21:00	0.1	13.6	1,755.0	0.1	0.3	1	1	0
09/23/2014 22:00	0.1	13.6	1,759.3	0.1	0.3	1	1	0
09/23/2014 23:00	0.1	13.6	1,772.4	0.1	0.3	1	1	0
Average/Sum#:	0.1	13.7	1,642.8	0.1	6.3 #	24 #	24 #	0 #
Minimum:	0.0	13.6	1,276.0	0.0	0.0	1	1	0
Maximum:	0.1	13.9	1,783.8	0.1	0.3	1	1	0
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/24/2014 00:00	0.1	13.6	1,779.3	0.1	0.3	1	1	0
09/24/2014 01:00	0.1	13.6	1,781.8	0.1	0.3	1	1	0
09/24/2014 02:00	0.1	13.6	1,781.6	0.1	0.3	1	1	0
09/24/2014 03:00	0.0	13.6	1,763.1	0.1	0.0	1	1	0
09/24/2014 04:00	0.1	13.6	1,743.7	0.1	0.3	1	1	0
09/24/2014 05:00	0.1	13.7	1,673.3	0.1	0.3	1	1	0
09/24/2014 06:00	0.0	13.6	1,775.0	0.1	0.0	1	1	0
09/24/2014 07:00	0.0	13.7	1,711.7	0.0	0.0	1	1	0
09/24/2014 08:00	0.0	13.8	1,596.6	0.0	0.0	1	1	0
09/24/2014 09:00	0.0	13.7	1,720.9	0.0	0.0	1	1	0
09/24/2014 10:00	0.0	13.6	1,758.6	0.0	0.0	1	1	0
09/24/2014 11:00	0.0	13.6	1,755.0	0.0	0.0	1	1	0
09/24/2014 12:00	0.0	13.6	1,748.9	0.0	0.0	1	1	0
09/24/2014 13:00	0.0	13.6	1,746.4	0.0	0.0	1	1	0
09/24/2014 14:00	0.0	13.7	1,747.5	0.0	0.0	1	1	0
09/24/2014 15:00	0.1	13.7	1,747.7	0.0	0.3	1	1	0
09/24/2014 16:00	0.1	13.7	1,743.8	0.1	0.3	1	1	0
09/24/2014 17:00	0.1	13.6	1,755.4	0.1	0.3	1	1	0
09/24/2014 18:00	0.0	13.6	1,762.4	0.1	0.0	1	1	0
09/24/2014 19:00	0.1	13.6	1,766.3	0.1	0.3	1	1	0
09/24/2014 20:00	0.0	13.6	1,773.8	0.0	0.0	1	1	0
09/24/2014 21:00	0.0	13.6	1,778.7	0.0	0.0	1	1	0
09/24/2014 22:00	0.0	13.6	1,782.1	0.0	0.0	1	1	0
09/24/2014 23:00	0.0	13.6	1,769.6	0.0	0.0	1	1	0
Average/Sum#:	0.0	13.6	1,748.5	0.0	2.7 #	24 #	24 #	0 #
Minimum:	0.0	13.6	1,596.6	0.0	0.0	1	1	0
Maximum:	0.1	13.8	1,782.1	0.1	0.3	1	1	0
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/25/2014 00:00	0.0	13.6	1,774.2	0.0	0.0	1	1	0
09/25/2014 01:00	0.0	13.6	1,772.1	0.0	0.0	1	1	0
09/25/2014 02:00	0.0	13.6	1,770.9	0.0	0.0	1	1	0
09/25/2014 03:00	0.0	13.7	1,730.2	0.0	0.0	1	1	0
09/25/2014 04:00	0.0	13.6	1,771.3	0.0	0.0	1	1	0
09/25/2014 05:00	0.0	13.7	1,738.4	0.0	0.0	1	1	0
09/25/2014 06:00	0.0	13.6	1,772.4	0.0	0.0	1	1	0
09/25/2014 07:00	0.0	13.7	1,748.3	0.0	0.0	1	1	0
09/25/2014 08:00	0.0	13.6	1,771.4	0.0	0.0	1	1	0
09/25/2014 09:00	0.0	13.6	1,767.9	0.0	0.0	1	1	0
09/25/2014 10:00	0.0	13.6	1,760.2	0.0	0.0	1	1	0
09/25/2014 11:00	0.0	13.6	1,785.0	0.0	0.0	1	1	0
09/25/2014 12:00	0.0	13.6	1,771.9	0.0	0.0	1	1	0
09/25/2014 13:00	1.0	12.4	2,039.6	0.2	3.2	1	1	1
09/25/2014 14:00	0.6	11.9	2,141.5	0.4	1.9	1	1	1
09/25/2014 15:00	0.4	11.6	2,179.6	0.5	1.2	1	1	1
09/25/2014 16:00	0.4	12.8	1,944.2	0.3	1.3	1	1	1
09/25/2014 17:00	0.6	12.5	2,022.8	0.3	1.9	1	1	1
09/25/2014 18:00	0.6	12.4	2,060.4	0.4	1.9	1	1	1
09/25/2014 19:00	0.5	12.3	2,070.5	0.4	1.6	1	1	1
09/25/2014 20:00	0.4	13.0	1,933.0	0.3	1.3	1	1	1
09/25/2014 21:00	0.4	13.1	1,897.7	0.3	1.3	1	1	1
09/25/2014 22:00	0.5	12.9	1,936.8	0.3	1.6	1	1	1
09/25/2014 23:00	0.6	12.4	2,040.6	0.4	1.9	1	1	1
Average/Sum#:	0.3	13.1	1,883.4	0.2	19.1 #	24 #	24 #	11 #
Minimum:	0.0	11.6	1,730.2	0.0	0.0	1	1	0
Maximum:	1.0	13.7	2,179.6	0.5	3.2	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/26/2014 00:00	0.4	12.9	1,940.1	0.4	1.3	1	1	1
09/26/2014 01:00	0.5	12.9	1,953.3	0.4	1.6	1	1	1
09/26/2014 02:00	0.4	13.1	1,897.5	0.3	1.3	1	1	1
09/26/2014 03:00	0.5	13.0	1,923.3	0.4	1.6	1	1	1
09/26/2014 04:00	0.6	11.9	2,160.7	0.4	1.9	1	1	1
09/26/2014 05:00	0.5	11.8	2,182.9	0.4	1.6	1	1	1
09/26/2014 06:00	0.5	11.7	2,198.7	0.3	1.6	1	1	1
09/26/2014 07:00	0.5	12.5	2,045.1	0.3	1.6	1	1	1
09/26/2014 08:00	0.3	13.3	1,870.5	0.3	1.0	1	1	1
09/26/2014 09:00	0.6	12.8	1,983.2	0.3	1.9	1	1	1
09/26/2014 10:00	0.6	12.6	2,011.4	0.3	1.9	1	1	1
09/26/2014 11:00	0.5	12.8	1,963.7	0.4	1.6	1	1	1
09/26/2014 12:00	0.3	13.2	1,884.8	0.3	1.0	1	1	1
09/26/2014 13:00	0.4	13.3	1,857.2	0.3	1.3	1	1	1
09/26/2014 14:00	0.4	13.3	1,860.5	0.3	1.3	1	1	1
09/26/2014 15:00	0.4	13.3	1,853.7	0.3	1.3	1	1	1
09/26/2014 16:00	0.4	13.3	1,855.4	0.3	1.3	1	1	1
09/26/2014 17:00	0.5	13.0	1,922.9	0.3	1.6	1	1	1
09/26/2014 18:00	0.5	13.1	1,895.7	0.4	1.6	1	1	1
09/26/2014 19:00	0.4	13.3	1,860.5	0.4	1.3	1	1	1
09/26/2014 20:00	0.4	13.3	1,863.5	0.3	1.3	1	1	1
09/26/2014 21:00	0.5	13.1	1,916.0	0.3	1.6	1	1	1
09/26/2014 22:00	0.4	13.2	1,887.0	0.3	1.3	1	1	1
09/26/2014 23:00	0.7	12.6	2,023.7	0.4	2.3	1	1	1
Average/Sum#:	0.5	12.9	1,950.5	0.3	36.1 #	24 #	24 #	24 #
Minimum:	0.3	11.7	1,853.7	0.3	1.0	1	1	1
Maximum:	0.7	13.3	2,198.7	0.4	2.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/27/2014 00:00	0.7	12.5	2,052.4	0.4	2.3	1	1	1
09/27/2014 01:00	0.6	12.1	2,120.7	0.5	1.9	1	1	1
09/27/2014 02:00	0.5	12.9	1,960.0	0.4	1.6	1	1	1
09/27/2014 03:00	0.4	13.1	1,915.3	0.4	1.3	1	1	1
09/27/2014 04:00	0.4	13.2	1,889.8	0.3	1.3	1	1	1
09/27/2014 05:00	0.4	13.1	1,906.6	0.3	1.3	1	1	1
09/27/2014 06:00	0.4	13.1	1,889.6	0.3	1.3	1	1	1
09/27/2014 07:00	0.1	13.7	1,592.0	0.2	0.3	1	1	1
09/27/2014 08:00	0.0	13.8	1,269.2	0.1	0.0	1	1	0
09/27/2014 09:00	0.0	13.9	1,345.4	0.0	0.0	1	1	0
09/27/2014 10:00	0.0	13.9	1,281.8	0.0	0.0	1	1	0
09/27/2014 11:00	0.0	13.9	1,254.6	0.0	0.0	1	1	0
09/27/2014 12:00	0.0	13.9	1,253.0	0.0	0.0	1	1	0
09/27/2014 13:00	0.0	13.9	1,253.6	0.0	0.0	1	1	0
09/27/2014 14:00	0.0	13.9	1,253.4	0.0	0.0	1	1	0
09/27/2014 15:00	0.0	13.9	1,250.6	0.0	0.0	1	1	0
09/27/2014 16:00	0.0	13.9	1,247.9	0.0	0.0	1	1	0
09/27/2014 17:00	0.3	13.5	1,608.2	0.1	0.9	1	1	1
09/27/2014 18:00	0.6	11.8	2,150.9	0.2	1.9	1	1	1
09/27/2014 19:00	0.5	12.7	1,949.9	0.3	1.6	1	1	1
09/27/2014 20:00	0.6	13.1	1,895.1	0.4	1.9	1	1	1
09/27/2014 21:00	0.6	12.8	1,948.2	0.4	1.9	1	1	1
09/27/2014 22:00	0.7	13.4	1,827.1	0.5	2.3	1	1	1
09/27/2014 23:00	1.0	13.4	1,856.5	0.6	3.3	1	1	1
Average/Sum#:	0.3	13.3	1,665.5	0.2	25.1 #	24 #	24 #	15 #
Minimum:	0.0	11.8	1,247.9	0.0	0.0	1	1	0
Maximum:	1.0	13.9	2,150.9	0.6	3.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/28/2014 00:00	0.3	13.5	1,461.9	0.5	0.8	1	1	1
09/28/2014 01:00	0.0	13.9	1,251.2	0.3	0.0	1	1	0
09/28/2014 02:00	0.0	13.9	1,249.5	0.1	0.0	1	1	0
09/28/2014 03:00	0.1	13.9	1,518.4	0.0	0.3	1	1	0
09/28/2014 04:00	0.4	13.3	1,841.0	0.1	1.3	1	1	1
09/28/2014 05:00	0.7	12.8	1,973.4	0.3	2.3	1	1	1
09/28/2014 06:00	0.7	12.6	2,002.2	0.4	2.2	1	1	1
09/28/2014 07:00	0.4	13.3	1,862.7	0.4	1.3	1	1	1
09/28/2014 08:00	0.5	13.1	1,881.7	0.4	1.6	1	1	1
09/28/2014 09:00	0.1	13.8	1,308.0	0.3	0.2	1	1	1
09/28/2014 10:00	0.1	13.8	1,252.5	0.2	0.2	1	1	0
09/28/2014 11:00	0.2	13.6	1,541.8	0.1	0.6	1	1	1
09/28/2014 12:00	0.4	13.3	1,839.6	0.2	1.3	1	1	1
09/28/2014 13:00	0.4	13.3	1,838.8	0.3	1.3	1	1	1
09/28/2014 14:00	0.4	13.3	1,838.9	0.3	1.3	1	1	1
09/28/2014 15:00	0.4	13.3	1,844.4	0.3	1.3	1	1	1
09/28/2014 16:00	0.6	13.0	1,931.8	0.3	1.9	1	1	1
09/28/2014 17:00	0.7	12.3	2,063.6	0.4	2.2	1	1	1
09/28/2014 18:00	0.5	11.4	2,244.6	0.4	1.6	1	1	1
09/28/2014 19:00	0.4	11.4	2,256.2	0.3	1.3	1	1	1
09/28/2014 20:00	0.5	12.6	1,994.4	0.3	1.6	1	1	1
09/28/2014 21:00	0.6	12.9	1,947.2	0.3	1.9	1	1	1
09/28/2014 22:00	0.5	13.0	1,935.2	0.4	1.6	1	1	1
09/28/2014 23:00	0.7	13.4	1,853.4	0.5	2.3	1	1	1
Average/Sum#:	0.4	13.1	1,780.5	0.3	30.4 #	24 #	24 #	20 #
Minimum:	0.0	11.4	1,249.5	0.0	0.0	1	1	0
Maximum:	0.7	13.9	2,256.2	0.5	2.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/29/2014 00:00	1.0	13.5	1,835.3	0.6	3.3	1	1	1
09/29/2014 01:00	1.1	13.5	1,836.5	0.8	3.6	1	1	1
09/29/2014 02:00	1.1	13.5	1,836.7	0.9	3.6	1	1	1
09/29/2014 03:00	1.1	13.5	1,836.2	0.9	3.6	1	1	1
09/29/2014 04:00	0.6	13.4	1,857.5	0.8	2.0	1	1	1
09/29/2014 05:00	0.4	13.3	1,866.0	0.6	1.3	1	1	1
09/29/2014 06:00	0.7	12.7	1,988.3	0.4	2.2	1	1	1
09/29/2014 07:00	0.4	13.3	1,840.3	0.4	1.3	1	1	1
09/29/2014 08:00	0.4	13.3	1,839.3	0.4	1.3	1	1	1
09/29/2014 09:00	0.4	13.3	1,847.0	0.3	1.3	1	1	1
09/29/2014 10:00	0.4	13.2	1,855.3	0.3	1.3	1	1	1
09/29/2014 11:00	0.4	13.2	1,853.2	0.3	1.3	1	1	1
09/29/2014 12:00	0.1	13.8	1,283.9	0.2	0.2	1	1	0
09/29/2014 13:00	0.0	13.9	1,252.4	0.1	0.0	1	1	0
09/29/2014 14:00	0.2	13.6	1,519.0	0.1	0.5	1	1	1
09/29/2014 15:00	0.4	13.2	1,842.3	0.2	1.3	1	1	1
09/29/2014 16:00	0.5	13.0	1,896.4	0.3	1.6	1	1	1
09/29/2014 17:00	0.7	12.6	1,971.9	0.4	2.2	1	1	1
09/29/2014 18:00	0.7	11.8	2,141.2	0.5	2.2	1	1	1
09/29/2014 19:00	0.5	12.0	2,097.7	0.4	1.6	1	1	1
09/29/2014 20:00	0.6	12.9	1,925.0	0.4	1.9	1	1	1
09/29/2014 21:00	0.4	13.3	1,715.2	0.3	1.2	1	1	1
09/29/2014 22:00	0.1	13.9	1,264.3	0.3	0.2	1	1	0
09/29/2014 23:00	0.1	13.8	1,298.1	0.2	0.2	1	1	0
Average/Sum#:	0.5	13.2	1,770.8	0.4	39.2 #	24 #	24 #	20 #
Minimum:	0.0	11.8	1,252.4	0.1	0.0	1	1	0
Maximum:	1.1	13.9	2,141.2	0.9	3.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT2	Unit CT1
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/30/2014 00:00	0.1	13.8	1,252.5	0.1	0.2	1	1	0
09/30/2014 01:00	0.1	13.8	1,253.2	0.1	0.2	1	1	0
09/30/2014 02:00	0.2	13.8	1,253.6	0.1	0.5	1	1	0
09/30/2014 03:00	0.2	13.8	1,254.3	0.2	0.5	1	1	0
09/30/2014 04:00	0.2	13.8	1,376.5	0.2	0.5	1	1	0
09/30/2014 05:00	0.4	13.4	1,647.5	0.2	1.2	1	1	1
09/30/2014 06:00	0.4	13.2	1,879.9	0.3	1.3	1	1	1
09/30/2014 07:00	0.5	13.3	1,851.9	0.3	1.6	1	1	1
09/30/2014 08:00	0.4	13.3	1,852.8	0.3	1.3	1	1	1
09/30/2014 09:00	0.4	13.2	1,851.7	0.3	1.3	1	1	1
09/30/2014 10:00	0.1	13.9	1,255.1	0.2	0.2	1	1	0
09/30/2014 11:00	0.0	13.9	1,251.9	0.1	0.0	1	1	0
09/30/2014 12:00	0.2	13.6	1,635.7	0.1	0.6	1	1	1
09/30/2014 13:00	0.4	13.3	1,848.7	0.2	1.3	1	1	1
09/30/2014 14:00	0.4	13.3	1,850.7	0.3	1.3	1	1	1
09/30/2014 15:00	0.4	13.3	1,855.8	0.3	1.3	1	1	1
09/30/2014 16:00	0.4	13.2	1,870.7	0.3	1.3	1	1	1
09/30/2014 17:00	0.4	13.3	1,860.5	0.3	1.3	1	1	1
09/30/2014 18:00	0.6	12.6	2,006.2	0.3	1.9	1	1	1
09/30/2014 19:00	0.6	12.2	2,076.5	0.4	1.9	1	1	1
09/30/2014 20:00	0.5	13.4	1,857.5	0.4	1.6	1	1	1
09/30/2014 21:00	0.5	13.7	1,468.2	0.4	1.3	1	1	1
09/30/2014 22:00	0.0	13.9	1,256.7	0.3	0.0	1	1	0
09/30/2014 23:00	0.0	13.9	1,254.7	0.1	0.0	1	1	0
Average/Sum#:	0.3	13.5	1,617.6	0.2	22.6 #	24 #	24 #	15 #
Minimum:	0.0	12.2	1,251.9	0.1	0.0	1	1	0
Maximum:	0.6	13.9	2,076.5	0.4	1.9	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	Hr, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/01/2014 00:00	0.2	13.0	1,860.8	0.1	0.6	1	1	1
07/01/2014 01:00	0.1	13.5	1,578.8	0.1	0.3	1	1	1
07/01/2014 02:00	0.1	13.3	1,567.0	0.1	0.3	1	1	1
07/01/2014 03:00	0.0	13.7	1,246.5	0.1	0.0	1	1	0
07/01/2014 04:00	0.0	13.7	1,287.7	0.0	0.0	1	1	0
07/01/2014 05:00	0.1	13.4	1,558.6	0.0	0.3	1	1	1
07/01/2014 06:00	0.2	13.0	1,909.5	0.1	0.6	1	1	1
07/01/2014 07:00	0.2	12.9	1,896.3	0.1	0.6	1	1	1
07/01/2014 08:00	0.2	12.8	1,921.0	0.1	0.6	1	1	1
07/01/2014 09:00	0.2	12.7	1,924.7	0.1	0.6	1	1	1
07/01/2014 10:00	0.2	12.8	1,892.1	0.1	0.6	1	1	1
07/01/2014 11:00	0.2	12.8	1,881.9	0.1	0.6	1	1	1
07/01/2014 12:00	0.2	12.8	1,890.0	0.1	0.6	1	1	1
07/01/2014 13:00	0.2	12.7	1,900.9	0.1	0.6	1	1	1
07/01/2014 14:00	0.2	12.7	1,913.0	0.1	0.6	1	1	1
07/01/2014 15:00	0.2	12.6	1,925.7	0.1	0.6	1	1	1
07/01/2014 16:00	0.2	12.0	2,043.1	0.1	0.6	1	1	1
07/01/2014 17:00	0.1	11.7	2,135.1	0.1	0.3	1	1	1
07/01/2014 18:00	0.1	11.7	2,119.9	0.1	0.3	1	1	1
07/01/2014 19:00	0.1	12.8	1,894.4	0.1	0.3	1	1	1
07/01/2014 20:00	0.1	12.9	1,879.9	0.1	0.3	1	1	1
07/01/2014 21:00	0.1	13.0	1,864.0	0.1	0.3	1	1	1
07/01/2014 22:00	0.2	13.0	1,863.6	0.1	0.6	1	1	1
07/01/2014 23:00	0.2	13.1	1,862.5	0.1	0.6	1	1	1
Average/Sum#:	0.2	12.9	1,825.7	0.1	10.8 #	24 #	24 #	22 #
Minimum:	0.0	11.7	1,246.5	0.0	0.0	1	1	0
Maximum:	0.2	13.7	2,135.1	0.1	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/02/2014 00:00	0.2	13.1	1,863.8	0.2	0.6	1	1	1
07/02/2014 01:00	0.2	13.1	1,864.1	0.2	0.6	1	1	1
07/02/2014 02:00	0.2	13.1	1,862.8	0.2	0.6	1	1	1
07/02/2014 03:00	0.2	13.1	1,863.9	0.2	0.6	1	1	1
07/02/2014 04:00	0.2	12.9	1,928.5	0.2	0.6	1	1	1
07/02/2014 05:00	0.2	12.3	2,082.0	0.1	0.6	1	1	1
07/02/2014 06:00	0.2	12.7	2,013.3	0.1	0.6	1	1	1
07/02/2014 07:00	0.1	13.0	1,897.3	0.1	0.3	1	1	1
07/02/2014 08:00	0.1	13.0	1,893.5	0.1	0.3	1	1	1
07/02/2014 09:00	0.1	13.0	1,893.5	0.1	0.3	1	1	1
07/02/2014 10:00	0.2	13.0	1,891.2	0.1	0.6	1	1	1
07/02/2014 11:00	0.2	12.9	1,894.7	0.1	0.6	1	1	1
07/02/2014 12:00	0.2	12.8	1,894.9	0.1	0.6	1	1	1
07/02/2014 13:00	0.2	12.8	1,897.7	0.1	0.6	1	1	1
07/02/2014 14:00	0.2	12.2	2,025.7	0.1	0.6	1	1	1
07/02/2014 15:00	0.1	11.7	2,142.1	0.1	0.3	1	1	1
07/02/2014 16:00	0.2	12.1	2,037.6	0.1	0.6	1	1	1
07/02/2014 17:00	0.2	12.4	1,976.1	0.1	0.6	1	1	1
07/02/2014 18:00	0.2	12.3	1,989.8	0.1	0.6	1	1	1
07/02/2014 19:00	0.2	12.5	1,966.6	0.1	0.6	1	1	1
07/02/2014 20:00	0.2	12.5	1,965.4	0.1	0.6	1	1	1
07/02/2014 21:00	0.0	13.6	1,331.9	0.1	0.0	1	1	1
07/02/2014 22:00	18.2	15.9	443.7	0.0	3.8	1	0	0
07/02/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	1.0	12.9	1,853.0	0.1	15.2 #	23 #	22 #	22 #
Minimum:	0.0	11.7	443.7	0.1	0.0	0	0	0
Maximum:	18.2	15.9	2,142.1	0.2	3.8	1	1	1
%SI	4.2	4.2	4.2	8.3	4.2	0	0	0

Daily Summary Report

CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/03/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/03/2014 07:00	23.7	16.9	529.2	0.0	29.0	1	0	0
07/03/2014 08:00	8.6	13.9	1,421.5	0.0	23.1	1	0	0
07/03/2014 09:00	0.2	13.0	1,885.3	0.0	0.6	1	1	1
07/03/2014 10:00	0.1	12.9	1,891.5	0.0	0.3	1	1	1
07/03/2014 11:00	0.2	12.8	1,918.0	0.1	0.6	1	1	1
07/03/2014 12:00	0.2	12.4	1,975.5	0.1	0.6	1	1	1
07/03/2014 13:00	0.1	11.8	2,109.6	0.1	0.3	1	1	1
07/03/2014 14:00	0.1	11.6	2,140.1	0.1	0.3	1	1	1
07/03/2014 15:00	0.1	11.6	2,157.5	0.1	0.3	1	1	1
07/03/2014 16:00	0.0	11.6	2,156.9	0.1	0.0	1	1	1
07/03/2014 17:00	0.0	11.5	2,155.8	0.0	0.0	1	1	1
07/03/2014 18:00	0.0	11.4	2,181.6	0.0	0.0	1	1	1
07/03/2014 19:00	0.1	11.4	2,179.4	0.0	0.3	1	1	1
07/03/2014 20:00	0.1	12.0	2,071.2	0.1	0.3	1	1	1
07/03/2014 21:00	0.2	12.3	2,002.3	0.1	0.6	1	1	1
07/03/2014 22:00	0.2	12.3	2,035.9	0.1	0.6	1	1	1
07/03/2014 23:00	0.0	11.5	2,207.6	0.1	0.0	1	1	1
Average/Sum#:	2.0	12.4	1,942.3	0.1	56.9 #	17 #	15 #	15 #
Minimum:	0.0	11.4	529.2	0.0	0.0	0	0	0
Maximum:	23.7	16.9	2,207.6	0.1	29.0	1	1	1
%SI	29.2	29.2	29.2	45.8	29.2	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/04/2014 00:00	0.1	12.4	2,013.9	0.1	0.3	1	1	1
07/04/2014 01:00	0.2	12.7	1,966.5	0.1	0.6	1	1	1
07/04/2014 02:00	0.1	13.0	1,900.7	0.1	0.3	1	1	1
07/04/2014 03:00	0.1	13.1	1,863.3	0.1	0.3	1	1	1
07/04/2014 04:00	0.1	13.0	1,905.5	0.1	0.3	1	1	1
07/04/2014 05:00	0.1	13.1	1,895.4	0.1	0.3	1	1	1
07/04/2014 06:00	0.1	13.0	1,893.5	0.1	0.3	1	1	1
07/04/2014 07:00	0.1	13.0	1,892.3	0.1	0.3	1	1	1
07/04/2014 08:00	0.2	12.7	1,953.5	0.1	0.6	1	1	1
07/04/2014 09:00	0.2	12.6	1,960.8	0.1	0.6	1	1	1
07/04/2014 10:00	0.2	12.5	1,993.9	0.1	0.6	1	1	1
07/04/2014 11:00	0.1	11.4	2,219.1	0.1	0.3	1	1	1
07/04/2014 12:00	0.1	11.9	2,099.7	0.1	0.3	1	1	1
07/04/2014 13:00	0.1	12.6	1,939.8	0.1	0.3	1	1	1
07/04/2014 14:00	0.2	12.5	1,954.0	0.1	0.6	1	1	1
07/04/2014 15:00	0.2	12.5	1,965.8	0.1	0.6	1	1	1
07/04/2014 16:00	0.2	12.4	1,997.7	0.1	0.6	1	1	1
07/04/2014 17:00	0.1	12.4	1,998.3	0.1	0.3	1	1	1
07/04/2014 18:00	0.0	13.5	1,484.7	0.1	0.0	1	1	1
07/04/2014 19:00	0.0	13.8	1,292.1	0.0	0.0	1	1	0
07/04/2014 20:00	6.8	14.6	973.1	0.0	7.4	1	0	0
07/04/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/04/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.4	12.8	1,864.9	0.1	14.9 #	21 #	20 #	19 #
Minimum:	0.0	11.4	973.1	0.0	0.0	0	0	0
Maximum:	6.8	14.6	2,219.1	0.1	7.4	1	1	1
%SI	12.5	12.5	12.5	16.7	12.5	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/05/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/05/2014 10:00	29.4	17.4	454.2	0.0	26.7	1	0	0
07/05/2014 11:00	14.5	14.6	1,176.0	0.0	35.7	1	0	0
07/05/2014 12:00	0.2	12.7	1,934.1	0.0	0.6	1	1	1
07/05/2014 13:00	0.1	12.0	2,089.9	0.0	0.3	1	1	1
07/05/2014 14:00	0.1	12.7	1,937.1	0.1	0.3	1	1	1
07/05/2014 15:00	0.2	12.6	1,931.5	0.1	0.6	1	1	1
07/05/2014 16:00	0.2	12.5	1,958.7	0.1	0.6	1	1	1
07/05/2014 17:00	0.2	12.4	1,985.1	0.1	0.6	1	1	1
07/05/2014 18:00	0.2	12.5	1,941.2	0.1	0.6	1	1	1
07/05/2014 19:00	0.1	12.8	1,885.9	0.1	0.3	1	1	1
07/05/2014 20:00	0.1	12.9	1,879.7	0.1	0.3	1	1	1
07/05/2014 21:00	0.1	13.0	1,879.0	0.1	0.3	1	1	1
07/05/2014 22:00	0.0	13.5	1,547.7	0.1	0.0	1	1	1
07/05/2014 23:00	0.0	13.5	1,768.2	0.0	0.0	1	1	0
Average/Sum#:	3.2	13.2	1,740.6	0.1	66.9 #	14 #	12 #	11 #
Minimum:	0.0	12.0	454.2	0.0	0.0	0	0	0
Maximum:	29.4	17.4	2,089.9	0.1	35.7	1	1	1
%SI	41.7	41.7	41.7	58.3	41.7	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/06/2014 00:00	0.0	13.5	1,777.0	0.0	0.0	1	1	0
07/06/2014 01:00	0.0	13.6	1,498.4	0.0	0.0	1	1	0
07/06/2014 02:00	21.0	15.8	538.4	0.0	6.7	1	0	0
07/06/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/06/2014 09:00	11.0	18.2	334.7	0.0	4.9	1	0	0
07/06/2014 10:00	20.2	15.2	900.2	0.0	42.1	1	0	0
07/06/2014 11:00	0.1	13.2	1,762.7	0.0	0.3	1	1	1
07/06/2014 12:00	0.2	12.8	1,926.6	0.0	0.6	1	1	1
07/06/2014 13:00	0.1	12.9	1,894.7	0.1	0.3	1	1	1
07/06/2014 14:00	0.1	12.9	1,895.9	0.1	0.3	1	1	1
07/06/2014 15:00	0.1	12.9	1,894.5	0.1	0.3	1	1	1
07/06/2014 16:00	0.2	12.7	1,927.7	0.1	0.6	1	1	1
07/06/2014 17:00	0.2	12.1	2,060.6	0.1	0.6	1	1	1
07/06/2014 18:00	0.1	11.7	2,138.7	0.1	0.3	1	1	1
07/06/2014 19:00	0.2	12.1	2,067.9	0.1	0.6	1	1	1
07/06/2014 20:00	0.1	12.0	2,085.3	0.1	0.3	1	1	1
07/06/2014 21:00	0.1	12.8	1,903.2	0.1	0.3	1	1	1
07/06/2014 22:00	0.2	12.9	1,873.1	0.1	0.6	1	1	1
07/06/2014 23:00	0.2	13.0	1,852.8	0.1	0.6	1	1	1
Average/Sum#:	3.0	13.4	1,685.1	0.1	59.4 #	18 #	15 #	13 #
Minimum:	0.0	11.7	334.7	0.0	0.0	0	0	0
Maximum:	21.0	18.2	2,138.7	0.1	42.1	1	1	1
%SI	25.0	25.0	25.0	45.8	25.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/07/2014 00:00	0.0	13.7	1,279.5	0.1	0.0	1	1	0
07/07/2014 01:00	0.0	13.7	1,257.0	0.0	0.0	1	1	0
07/07/2014 02:00	0.0	13.8	1,285.4	0.0	0.0	1	1	0
07/07/2014 03:00	0.0	13.8	1,337.3	0.0	0.0	1	1	0
07/07/2014 04:00	0.1	13.4	1,796.1	0.0	0.3	1	1	1
07/07/2014 05:00	0.2	13.1	1,879.8	0.1	0.6	1	1	1
07/07/2014 06:00	0.2	13.1	1,861.6	0.2	0.6	1	1	1
07/07/2014 07:00	0.2	13.1	1,861.1	0.2	0.6	1	1	1
07/07/2014 08:00	0.2	13.0	1,879.7	0.2	0.6	1	1	1
07/07/2014 09:00	0.1	13.0	1,871.9	0.1	0.3	1	1	1
07/07/2014 10:00	0.1	12.9	1,891.0	0.1	0.3	1	1	1
07/07/2014 11:00	0.1	12.9	1,883.2	0.1	0.3	1	1	1
07/07/2014 12:00	0.1	12.9	1,887.0	0.1	0.3	1	1	1
07/07/2014 13:00	0.1	12.8	1,889.3	0.1	0.3	1	1	1
07/07/2014 14:00	0.1	12.9	1,883.5	0.1	0.3	1	1	1
07/07/2014 15:00	0.2	12.8	1,881.0	0.1	0.6	1	1	1
07/07/2014 16:00	0.2	12.8	1,883.9	0.1	0.6	1	1	1
07/07/2014 17:00	0.2	12.7	1,894.4	0.1	0.6	1	1	1
07/07/2014 18:00	0.2	12.7	1,899.3	0.1	0.6	1	1	1
07/07/2014 19:00	0.2	12.7	1,914.0	0.1	0.6	1	1	1
07/07/2014 20:00	0.1	12.9	1,869.9	0.1	0.3	1	1	1
07/07/2014 21:00	0.1	13.0	1,855.9	0.1	0.3	1	1	1
07/07/2014 22:00	0.1	13.1	1,683.9	0.1	0.3	1	1	1
07/07/2014 23:00	0.2	13.1	1,843.5	0.1	0.6	1	1	1
Average/Sum#:	0.1	13.1	1,769.6	0.1	9.0 #	24 #	24 #	20 #
Minimum:	0.0	12.7	1,257.0	0.0	0.0	1	1	0
Maximum:	0.2	13.8	1,914.0	0.2	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/08/2014 00:00	0.3	12.9	1,887.5	0.2	0.9	1	1	1
07/08/2014 01:00	0.2	13.0	1,868.4	0.2	0.6	1	1	1
07/08/2014 02:00	0.1	13.0	1,865.2	0.1	0.3	1	1	1
07/08/2014 03:00	0.2	13.2	1,736.0	0.1	0.6	1	1	1
07/08/2014 04:00	0.3	12.7	1,925.6	0.2	0.9	1	1	1
07/08/2014 05:00	0.2	13.0	1,875.0	0.2	0.6	1	1	1
07/08/2014 06:00	0.3	12.6	1,941.7	0.2	0.9	1	1	1
07/08/2014 07:00	0.2	12.9	1,879.4	0.1	0.6	1	1	1
07/08/2014 08:00	0.2	12.8	1,893.6	0.1	0.6	1	1	1
07/08/2014 09:00	0.2	12.9	1,875.1	0.1	0.6	1	1	1
07/08/2014 10:00	0.2	12.6	1,953.2	0.1	0.6	1	1	1
07/08/2014 11:00	0.2	12.5	1,950.7	0.1	0.6	1	1	1
07/08/2014 12:00	0.2	12.0	2,083.8	0.1	0.6	1	1	1
07/08/2014 13:00	0.0	11.3	2,220.9	0.1	0.0	1	1	1
07/08/2014 14:00	0.1	11.5	2,154.8	0.1	0.3	1	1	1
07/08/2014 15:00	0.0	11.5	2,147.4	0.0	0.0	1	1	1
07/08/2014 16:00	0.0	11.5	2,154.2	0.0	0.0	1	1	1
07/08/2014 17:00	0.0	11.6	2,151.6	0.0	0.0	1	1	1
07/08/2014 18:00	0.1	11.9	2,087.2	0.0	0.3	1	1	1
07/08/2014 19:00	0.2	12.3	1,993.3	0.1	0.6	1	1	1
07/08/2014 20:00	0.1	12.8	1,885.5	0.1	0.3	1	1	1
07/08/2014 21:00	0.1	13.0	1,863.9	0.1	0.3	1	1	1
07/08/2014 22:00	0.0	13.5	1,489.9	0.1	0.0	1	1	1
07/08/2014 23:00	0.0	13.7	1,386.8	0.0	0.0	1	1	0
Average/Sum#:	0.1	12.5	1,927.9	0.1	10.2 #	24 #	24 #	23 #
Minimum:	0.0	11.3	1,386.8	0.0	0.0	1	1	0
Maximum:	0.3	13.7	2,220.9	0.2	0.9	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/09/2014 00:00	0.0	13.7	1,250.4	0.0	0.0	1	1	0
07/09/2014 01:00	0.0	13.7	1,248.5	0.0	0.0	1	1	0
07/09/2014 02:00	0.0	13.7	1,248.3	0.0	0.0	1	1	0
07/09/2014 03:00	0.0	13.7	1,248.5	0.0	0.0	1	1	0
07/09/2014 04:00	0.0	13.7	1,258.5	0.0	0.0	1	1	0
07/09/2014 05:00	0.1	13.7	1,543.7	0.0	0.3	1	1	0
07/09/2014 06:00	0.1	13.3	1,644.5	0.1	0.3	1	1	1
07/09/2014 07:00	0.3	12.6	1,972.8	0.1	0.9	1	1	1
07/09/2014 08:00	0.2	12.7	1,951.1	0.1	0.6	1	1	1
07/09/2014 09:00	0.2	12.4	2,010.5	0.1	0.6	1	1	1
07/09/2014 10:00	0.1	11.9	2,108.4	0.1	0.3	1	1	1
07/09/2014 11:00	0.1	11.6	2,171.2	0.1	0.3	1	1	1
07/09/2014 12:00	0.1	11.4	2,186.0	0.1	0.3	1	1	1
07/09/2014 13:00	0.1	11.5	2,159.5	0.1	0.3	1	1	1
07/09/2014 14:00	0.1	12.1	2,026.1	0.1	0.3	1	1	1
07/09/2014 15:00	0.1	11.9	2,097.3	0.1	0.3	1	1	1
07/09/2014 16:00	0.1	11.6	2,138.0	0.1	0.3	1	1	1
07/09/2014 17:00	0.0	11.6	2,135.1	0.1	0.0	1	1	1
07/09/2014 18:00	0.1	12.0	2,041.9	0.1	0.3	1	1	1
07/09/2014 19:00	0.2	12.4	1,970.8	0.1	0.6	1	1	1
07/09/2014 20:00	0.2	12.4	1,984.1	0.1	0.6	1	1	1
07/09/2014 21:00	0.2	12.5	1,956.7	0.1	0.6	1	1	1
07/09/2014 22:00	0.2	12.7	1,936.5	0.1	0.6	1	1	1
07/09/2014 23:00	0.0	13.4	1,457.2	0.1	0.0	1	1	1
Average/Sum#:	0.1	12.6	1,822.7	0.1	7.5 #	24 #	24 #	18 #
Minimum:	0.0	11.4	1,248.3	0.0	0.0	1	1	0
Maximum:	0.3	13.7	2,186.0	0.1	0.9	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/10/2014 00:00	0.0	13.7	1,244.7	0.0	0.0	1	1	0
07/10/2014 01:00	0.0	13.7	1,244.4	0.0	0.0	1	1	0
07/10/2014 02:00	0.0	13.7	1,244.9	0.0	0.0	1	1	0
07/10/2014 03:00	0.0	13.7	1,244.3	0.0	0.0	1	1	0
07/10/2014 04:00	0.0	13.7	1,244.9	0.0	0.0	1	1	0
07/10/2014 05:00	0.0	13.7	1,246.6	0.0	0.0	1	1	0
07/10/2014 06:00	0.0	13.7	1,247.9	0.0	0.0	1	1	0
07/10/2014 07:00	0.0	13.7	1,253.8	0.0	0.0	1	1	0
07/10/2014 08:00	0.0	13.7	1,264.1	0.0	0.0	1	1	0
07/10/2014 09:00	0.1	13.4	1,565.2	0.0	0.3	1	1	1
07/10/2014 10:00	0.2	13.0	1,863.4	0.1	0.6	1	1	1
07/10/2014 11:00	0.2	13.0	1,863.7	0.1	0.6	1	1	1
07/10/2014 12:00	0.1	12.9	1,885.9	0.1	0.3	1	1	1
07/10/2014 13:00	0.2	12.8	1,895.8	0.1	0.6	1	1	1
07/10/2014 14:00	0.3	12.8	1,897.5	0.1	0.9	1	1	1
07/10/2014 15:00	0.3	12.7	1,910.4	0.2	0.9	1	1	1
07/10/2014 16:00	0.3	12.4	1,969.0	0.2	0.9	1	1	1
07/10/2014 17:00	0.3	12.6	1,928.3	0.2	0.9	1	1	1
07/10/2014 18:00	0.6	12.4	1,974.3	0.3	1.8	1	1	1
07/10/2014 19:00	0.4	12.9	1,874.5	0.3	1.2	1	1	1
07/10/2014 20:00	0.3	13.0	1,867.6	0.3	0.9	1	1	1
07/10/2014 21:00	0.2	13.0	1,877.9	0.2	0.6	1	1	1
07/10/2014 22:00	0.2	13.1	1,858.2	0.2	0.6	1	1	1
07/10/2014 23:00	0.1	13.2	1,635.7	0.1	0.3	1	1	1
Average/Sum#:	0.2	13.2	1,629.3	0.1	11.4 #	24 #	24 #	15 #
Minimum:	0.0	12.4	1,244.3	0.0	0.0	1	1	0
Maximum:	0.6	13.7	1,974.3	0.3	1.8	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/11/2014 00:00	33.0	16.5	313.6	0.0	5.3	1	0	0
07/11/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/11/2014 09:00	29.7	16.9	546.6	0.0	44.5	1	0	0
07/11/2014 10:00	33.0	14.8	956.5	0.0	68.3	1	0	0
07/11/2014 11:00	0.0	13.9	1,277.0	0.0	0.0	1	1	0
07/11/2014 12:00	0.0	13.9	1,277.3	0.0	0.0	1	1	0
07/11/2014 13:00	0.0	13.9	1,277.8	0.0	0.0	1	1	0
07/11/2014 14:00	0.0	13.9	1,280.4	0.0	0.0	1	1	0
07/11/2014 15:00	0.0	14.0	1,282.1	0.0	0.0	1	1	0
07/11/2014 16:00	0.0	14.0	1,282.3	0.0	0.0	1	1	0
07/11/2014 17:00	0.0	14.0	1,281.0	0.0	0.0	1	1	0
07/11/2014 18:00	0.0	13.9	1,277.8	0.0	0.0	1	1	0
07/11/2014 19:00	0.0	13.9	1,274.0	0.0	0.0	1	1	0
07/11/2014 20:00	0.0	13.9	1,273.9	0.0	0.0	1	1	0
07/11/2014 21:00	0.0	13.9	1,266.7	0.0	0.0	1	1	0
07/11/2014 22:00	0.0	13.8	1,266.6	0.0	0.0	1	1	0
07/11/2014 23:00	0.0	13.8	1,266.9	0.0	0.0	1	1	0
Average/Sum#:	6.0	14.3	1,150.0	0.0	118.1 #	16 #	13 #	0 #
Minimum:	0.0	13.8	313.6	0.0	0.0	0	0	0
Maximum:	33.0	16.9	1,282.3	0.0	68.3	1	1	0
%SI	33.3	33.3	33.3	54.2	33.3	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/12/2014 00:00	24.2	15.7	600.6	0.0	8.5	1	0	0
07/12/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/12/2014 06:00	17.8	17.6	446.5	0.0	16.5	1	0	0
07/12/2014 07:00	31.4	14.8	988.3	0.0	67.2	1	0	0
07/12/2014 08:00	0.0	13.9	1,305.0	0.0	0.0	1	1	0
07/12/2014 09:00	0.0	13.9	1,305.2	0.0	0.0	1	1	0
07/12/2014 10:00	0.0	13.8	1,542.5	0.0	0.0	1	1	0
07/12/2014 11:00	0.0	13.8	1,566.0	0.0	0.0	1	1	0
07/12/2014 12:00	0.0	13.9	1,345.2	0.0	0.0	1	1	0
07/12/2014 13:00	0.0	13.8	1,656.4	0.0	0.0	1	1	0
07/12/2014 14:00	0.1	13.3	1,763.9	0.0	0.3	1	1	1
07/12/2014 15:00	0.2	12.0	2,097.4	0.1	0.6	1	1	1
07/12/2014 16:00	0.2	12.7	1,962.9	0.1	0.6	1	1	1
07/12/2014 17:00	0.2	12.6	1,966.4	0.1	0.6	1	1	1
07/12/2014 18:00	0.2	12.6	1,951.0	0.1	0.6	1	1	1
07/12/2014 19:00	0.2	13.0	1,887.0	0.1	0.6	1	1	1
07/12/2014 20:00	0.2	13.0	1,886.3	0.1	0.6	1	1	1
07/12/2014 21:00	0.3	12.6	1,983.6	0.1	0.9	1	1	1
07/12/2014 22:00	0.2	12.4	2,043.9	0.1	0.6	1	1	1
07/12/2014 23:00	0.2	12.6	1,976.7	0.1	0.6	1	1	1
Average/Sum#:	4.0	13.6	1,593.4	0.1	98.2 #	19 #	16 #	10 #
Minimum:	0.0	12.0	446.5	0.0	0.0	0	0	0
Maximum:	31.4	17.6	2,097.4	0.1	67.2	1	1	1
%SI	20.8	20.8	20.8	41.7	20.8	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/13/2014 00:00	0.1	13.3	1,658.0	0.1	0.3	1	1	1
07/13/2014 01:00	18.3	15.7	581.5	0.0	6.2	1	0	0
07/13/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/13/2014 10:00	17.3	17.8	429.1	0.0	13.3	1	0	0
07/13/2014 11:00	20.7	14.7	1,158.2	0.0	51.1	1	0	1
07/13/2014 12:00	0.2	12.8	1,924.8	0.0	0.6	1	1	1
07/13/2014 13:00	0.2	12.1	2,070.3	0.0	0.6	1	1	1
07/13/2014 14:00	0.1	11.8	2,123.8	0.1	0.3	1	1	1
07/13/2014 15:00	0.0	11.4	2,210.1	0.1	0.0	1	1	1
07/13/2014 16:00	0.1	12.1	2,057.8	0.1	0.3	1	1	1
07/13/2014 17:00	0.1	12.3	2,022.4	0.1	0.3	1	1	1
07/13/2014 18:00	0.1	12.1	2,034.1	0.1	0.3	1	1	1
07/13/2014 19:00	0.1	12.7	1,912.8	0.1	0.3	1	1	1
07/13/2014 20:00	0.0	13.6	1,543.7	0.1	0.0	1	1	1
07/13/2014 21:00	0.1	13.3	1,761.6	0.1	0.3	1	1	1
07/13/2014 22:00	0.2	12.7	1,923.8	0.1	0.6	1	1	1
07/13/2014 23:00	0.0	13.6	1,471.4	0.1	0.0	1	1	1
Average/Sum#:	3.6	13.3	1,680.2	0.1	74.5 #	16 #	13 #	14 #
Minimum:	0.0	11.4	429.1	0.1	0.0	0	0	0
Maximum:	20.7	17.8	2,210.1	0.1	51.1	1	1	1
%SI	33.3	33.3	33.3	54.2	33.3	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/14/2014 00:00	0.0	13.9	1,384.1	0.0	0.0	1	1	0
07/14/2014 01:00	0.0	13.9	1,475.0	0.0	0.0	1	1	0
07/14/2014 02:00	0.0	13.9	1,411.3	0.0	0.0	1	1	0
07/14/2014 03:00	0.0	13.8	1,716.1	0.0	0.0	1	1	0
07/14/2014 04:00	0.0	13.7	1,717.5	0.0	0.0	1	1	0
07/14/2014 05:00	0.0	13.8	1,600.4	0.0	0.0	1	1	1
07/14/2014 06:00	0.2	12.3	1,983.0	0.0	0.6	1	1	1
07/14/2014 07:00	0.2	12.7	1,972.2	0.1	0.6	1	1	1
07/14/2014 08:00	0.1	12.9	1,910.3	0.1	0.3	1	1	1
07/14/2014 09:00	0.1	12.8	1,930.2	0.1	0.3	1	1	1
07/14/2014 10:00	0.1	13.0	1,889.6	0.1	0.3	1	1	1
07/14/2014 11:00	0.2	12.9	1,903.1	0.1	0.6	1	1	1
07/14/2014 12:00	0.1	12.8	1,905.6	0.1	0.3	1	1	1
07/14/2014 13:00	0.0	12.5	1,967.7	0.1	0.0	1	1	1
07/14/2014 14:00	0.0	11.8	2,106.4	0.0	0.0	1	1	1
07/14/2014 15:00	0.0	11.8	2,097.8	0.0	0.0	1	1	1
07/14/2014 16:00	0.0	12.0	2,057.9	0.0	0.0	1	1	1
07/14/2014 17:00	0.0	12.2	2,008.2	0.0	0.0	1	1	1
07/14/2014 18:00	0.0	13.6	1,561.3	0.0	0.0	1	1	1
07/14/2014 19:00	0.0	13.9	1,447.5	0.0	0.0	1	1	0
07/14/2014 20:00	0.0	13.8	1,633.9	0.0	0.0	1	1	0
07/14/2014 21:00	0.0	13.8	1,638.8	0.0	0.0	1	1	0
07/14/2014 22:00	0.0	13.8	1,510.5	0.0	0.0	1	1	0
07/14/2014 23:00	0.0	13.7	1,647.8	0.0	0.0	1	1	0
Average/Sum#:	0.0	13.1	1,769.8	0.0	3.0 #	24 #	24 #	14 #
Minimum:	0.0	11.8	1,384.1	0.0	0.0	1	1	0
Maximum:	0.2	13.9	2,106.4	0.1	0.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/15/2014 00:00	0.0	13.6	1,736.5	0.0	0.0	1	1	0
07/15/2014 01:00	0.0	13.6	1,760.4	0.0	0.0	1	1	0
07/15/2014 02:00	0.0	13.7	1,756.3	0.0	0.0	1	1	0
07/15/2014 03:00	0.0	13.4	1,793.7	0.0	0.0	1	1	1
07/15/2014 04:00	0.0	12.9	1,945.8	0.0	0.0	1	1	1
07/15/2014 05:00	0.0	12.7	1,998.8	0.0	0.0	1	1	1
07/15/2014 06:00	0.0	13.2	1,903.1	0.0	0.0	1	1	1
07/15/2014 07:00	0.0	13.3	1,855.1	0.0	0.0	1	1	1
07/15/2014 08:00	0.0	13.3	1,843.9	0.0	0.0	1	1	1
07/15/2014 09:00	0.0	13.2	1,856.9	0.0	0.0	1	1	1
07/15/2014 10:00	0.0	13.0	1,883.9	0.0	0.0	1	1	1
07/15/2014 11:00	0.0	13.0	1,874.1	0.0	0.0	1	1	1
07/15/2014 12:00	0.0	13.1	1,864.5	0.0	0.0	1	1	1
07/15/2014 13:00	0.0	13.1	1,862.9	0.0	0.0	1	1	1
07/15/2014 14:00	0.0	12.8	1,926.9	0.0	0.0	1	1	1
07/15/2014 15:00	0.0	12.7	1,941.1	0.0	0.0	1	1	1
07/15/2014 16:00	0.0	12.9	1,899.7	0.0	0.0	1	1	1
07/15/2014 17:00	0.0	12.8	1,918.5	0.0	0.0	1	1	1
07/15/2014 18:00	0.0	12.8	1,894.4	0.0	0.0	1	1	1
07/15/2014 19:00	0.0	12.8	1,913.9	0.0	0.0	1	1	1
07/15/2014 20:00	0.0	12.8	1,904.2	0.0	0.0	1	1	1
07/15/2014 21:00	0.0	12.8	1,913.9	0.0	0.0	1	1	1
07/15/2014 22:00	0.0	12.9	1,900.7	0.0	0.0	1	1	1
07/15/2014 23:00	0.0	12.8	1,925.3	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.1	1,878.1	0.0	0.0 #	24 #	24 #	21 #
Minimum:	0.0	12.7	1,736.5	0.0	0.0	1	1	0
Maximum:	0.0	13.7	1,998.8	0.0	0.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/16/2014 00:00	0.0	12.9	1,891.5	0.0	0.0	1	1	1
07/16/2014 01:00	0.0	13.6	1,473.3	0.0	0.0	1	1	1
07/16/2014 02:00	0.0	13.8	1,427.8	0.0	0.0	1	1	0
07/16/2014 03:00	0.0	13.9	1,472.1	0.0	0.0	1	1	0
07/16/2014 04:00	0.0	13.6	1,738.0	0.0	0.0	1	1	0
07/16/2014 05:00	0.0	13.6	1,606.7	0.0	0.0	1	1	1
07/16/2014 06:00	0.0	13.5	1,711.4	0.0	0.0	1	1	1
07/16/2014 07:00	0.0	13.8	1,588.3	0.0	0.0	1	1	0
07/16/2014 08:00	0.0	13.6	1,688.9	0.0	0.0	1	1	1
07/16/2014 09:00	0.0	13.2	1,839.5	0.0	0.0	1	1	1
07/16/2014 10:00	0.0	13.2	1,839.9	0.0	0.0	1	1	1
07/16/2014 11:00	0.0	13.2	1,836.7	0.0	0.0	1	1	1
07/16/2014 12:00	0.0	13.2	1,833.4	0.0	0.0	1	1	1
07/16/2014 13:00	0.0	13.2	1,835.2	0.0	0.0	1	1	1
07/16/2014 14:00	0.0	13.1	1,838.2	0.0	0.0	1	1	1
07/16/2014 15:00	0.0	13.1	1,840.3	0.0	0.0	1	1	1
07/16/2014 16:00	0.0	13.0	1,866.3	0.0	0.0	1	1	1
07/16/2014 17:00	0.0	12.9	1,879.5	0.0	0.0	1	1	1
07/16/2014 18:00	0.0	12.9	1,881.1	0.0	0.0	1	1	1
07/16/2014 19:00	0.0	13.0	1,866.2	0.0	0.0	1	1	1
07/16/2014 20:00	0.0	13.0	1,858.5	0.0	0.0	1	1	1
07/16/2014 21:00	0.0	13.6	1,582.5	0.0	0.0	1	1	1
07/16/2014 22:00	0.0	13.5	1,692.3	0.0	0.0	1	1	1
07/16/2014 23:00	0.0	13.4	1,675.7	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.3	1,740.1	0.0	0.0 #	24 #	24 #	20 #
Minimum:	0.0	12.9	1,427.8	0.0	0.0	1	1	0
Maximum:	0.0	13.9	1,891.5	0.0	0.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/17/2014 00:00	15.0	15.6	607.0	0.0	5.2	1	0	0
07/17/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/17/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/17/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/17/2014 04:00	14.5	17.4	476.0	0.0	18.2	1	0	0
07/17/2014 05:00	12.6	14.8	1,095.6	0.0	29.9	1	0	0
07/17/2014 06:00	0.0	13.7	1,738.4	0.0	0.0	1	1	0
07/17/2014 07:00	0.0	13.8	1,366.9	0.0	0.0	1	1	0
07/17/2014 08:00	0.0	13.7	1,716.6	0.0	0.0	1	1	0
07/17/2014 09:00	0.0	13.8	1,502.7	0.0	0.0	1	1	0
07/17/2014 10:00	0.0	13.6	1,596.1	0.0	0.0	1	1	1
07/17/2014 11:00	0.0	13.2	1,834.7	0.0	0.0	1	1	1
07/17/2014 12:00	0.0	13.2	1,840.1	0.0	0.0	1	1	1
07/17/2014 13:00	0.0	13.1	1,843.7	0.0	0.0	1	1	1
07/17/2014 14:00	0.0	13.1	1,846.4	0.0	0.0	1	1	1
07/17/2014 15:00	0.0	13.0	1,855.7	0.0	0.0	1	1	1
07/17/2014 16:00	0.0	13.0	1,862.5	0.0	0.0	1	1	1
07/17/2014 17:00	0.0	12.9	1,879.9	0.0	0.0	1	1	1
07/17/2014 18:00	0.0	12.6	1,953.1	0.0	0.0	1	1	1
07/17/2014 19:00	0.0	12.5	1,975.5	0.0	0.0	1	1	1
07/17/2014 20:00	0.0	12.9	1,883.3	0.0	0.0	1	1	1
07/17/2014 21:00	0.0	12.8	1,920.4	0.0	0.0	1	1	1
07/17/2014 22:00	0.0	13.5	1,645.9	0.0	0.0	1	1	1
07/17/2014 23:00	0.0	13.8	1,410.0	0.0	0.0	1	1	0
Average/Sum#:	2.0	13.6	1,611.9	0.0	53.3 #	21 #	18 #	13 #
Minimum:	0.0	12.5	476.0	0.0	0.0	0	0	0
Maximum:	15.0	17.4	1,975.5	0.0	29.9	1	1	1
%SI	12.5	12.5	12.5	33.3	12.5	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/18/2014 00:00	14.2	15.6	613.4	0.0	5.0	1	0	0
07/18/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/18/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/18/2014 03:00	29.4	16.4	625.7	0.0	37.8	1	0	0
07/18/2014 04:00	0.0	13.8	1,339.7	0.0	0.0	1	0	0
07/18/2014 05:00	0.0	13.8	1,514.5	0.0	0.0	1	1	0
07/18/2014 06:00	0.0	13.8	1,454.6	0.0	0.0	1	1	0
07/18/2014 07:00	0.0	13.7	1,601.6	0.0	0.0	1	1	0
07/18/2014 08:00	0.0	13.8	1,625.0	0.0	0.0	1	1	0
07/18/2014 09:00	0.0	13.6	1,564.1	0.0	0.0	1	1	1
07/18/2014 10:00	0.0	13.2	1,857.5	0.0	0.0	1	1	1
07/18/2014 11:00	0.0	13.2	1,848.2	0.0	0.0	1	1	1
07/18/2014 12:00	0.0	13.2	1,837.2	0.0	0.0	1	1	1
07/18/2014 13:00	0.0	13.2	1,841.4	0.0	0.0	1	1	1
07/18/2014 14:00	0.0	13.1	1,844.9	0.0	0.0	1	1	1
07/18/2014 15:00	0.0	13.0	1,877.3	0.0	0.0	1	1	1
07/18/2014 16:00	0.0	12.9	1,906.0	0.0	0.0	1	1	1
07/18/2014 17:00	0.0	11.8	2,125.2	0.0	0.0	1	1	1
07/18/2014 18:00	0.0	11.7	2,150.0	0.0	0.0	1	1	1
07/18/2014 19:00	0.0	12.0	2,093.4	0.0	0.0	1	1	1
07/18/2014 20:00	0.0	12.4	1,997.8	0.0	0.0	1	1	1
07/18/2014 21:00	0.0	13.0	1,866.2	0.0	0.0	1	1	1
07/18/2014 22:00	0.0	13.4	1,599.4	0.0	0.0	1	1	1
07/18/2014 23:00	0.0	13.8	1,302.4	0.0	0.0	1	1	0
Average/Sum#:	2.0	13.4	1,658.4	0.0	42.8 #	22 #	19 #	14 #
Minimum:	0.0	11.7	613.4	0.0	0.0	0	0	0
Maximum:	29.4	16.4	2,150.0	0.0	37.8	1	1	1
%SI	8.3	8.3	8.3	29.2	8.3	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/19/2014 00:00	10.1	15.1	853.5	0.0	6.5	1	0	0
07/19/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/19/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/19/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/19/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/19/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/19/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/19/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/19/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/19/2014 09:00	15.3	17.8	403.7	0.0	9.7	1	0	0
07/19/2014 10:00	11.8	14.6	1,198.1	0.0	29.6	1	0	0
07/19/2014 11:00	0.0	12.3	2,067.5	0.0	0.0	1	1	1
07/19/2014 12:00	0.0	11.7	2,155.7	0.0	0.0	1	1	1
07/19/2014 13:00	0.0	11.4	2,222.5	0.0	0.0	1	1	1
07/19/2014 14:00	0.0	11.5	2,192.9	0.0	0.0	1	1	1
07/19/2014 15:00	0.0	11.5	2,182.0	0.0	0.0	1	1	1
07/19/2014 16:00	0.0	11.6	2,142.9	0.0	0.0	1	1	1
07/19/2014 17:00	0.0	11.7	2,132.8	0.0	0.0	1	1	1
07/19/2014 18:00	0.0	12.4	1,987.0	0.0	0.0	1	1	1
07/19/2014 19:00	0.0	12.0	2,078.2	0.0	0.0	1	1	1
07/19/2014 20:00	0.0	11.7	2,148.8	0.0	0.0	1	1	1
07/19/2014 21:00	0.0	12.3	2,024.7	0.0	0.0	1	1	1
07/19/2014 22:00	0.0	13.7	1,533.4	0.0	0.0	1	1	1
07/19/2014 23:00	0.0	13.8	1,502.5	0.0	0.0	1	1	0
Average/Sum#:	2.3	12.8	1,801.6	0.0	45.8 #	16 #	13 #	12 #
Minimum:	0.0	11.4	403.7	0.0	0.0	0	0	0
Maximum:	15.3	17.8	2,222.5	0.0	29.6	1	1	1
%SI	33.3	33.3	33.3	54.2	33.3	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/20/2014 00:00	16.5	15.6	602.0	0.0	5.7	1	0	0
07/20/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	16.5	15.6	602.0	0.0	5.7 #	1 #	0 #	0 #
Minimum:	16.5	15.6	602.0	0.0	5.7	0	0	0
Maximum:	16.5	15.6	602.0	0.0	5.7	1	0	0
%SI	95.8	95.8	95.8	100.0	95.8	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/21/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
07/21/2014 01:00	53.8	17.4	477.1	0.0	67.8	1	0	0
07/21/2014 02:00	18.7	16.7	580.1	0.0	34.1	1	0	0
07/21/2014 03:00	18.8	14.5	1,129.3	0.0	43.8	1	0	0
07/21/2014 04:00	0.0	13.8	1,619.8	0.0	0.0	1	1	0
07/21/2014 05:00	0.0	13.8	1,663.0	0.0	0.0	1	1	0
07/21/2014 06:00	0.0	13.9	1,643.8	0.0	0.0	1	1	0
07/21/2014 07:00	0.0	13.8	1,638.0	0.0	0.0	1	1	0
07/21/2014 08:00	0.0	13.0	1,914.6	0.0	0.0	1	1	1
07/21/2014 09:00	0.0	12.7	1,973.3	0.0	0.0	1	1	1
07/21/2014 10:00	0.0	12.7	1,974.9	0.0	0.0	1	1	1
07/21/2014 11:00	0.0	12.7	1,961.3	0.0	0.0	1	1	1
07/21/2014 12:00	0.0	12.8	1,948.6	0.0	0.0	1	1	1
07/21/2014 13:00	0.0	12.8	1,928.3	0.0	0.0	1	1	1
07/21/2014 14:00	0.0	12.7	1,937.5	0.0	0.0	1	1	1
07/21/2014 15:00	0.0	12.4	2,007.4	0.0	0.0	1	1	1
07/21/2014 16:00	0.0	12.4	2,012.0	0.0	0.0	1	1	1
07/21/2014 17:00	0.0	11.6	2,185.9	0.0	0.0	1	1	1
07/21/2014 18:00	0.0	11.2	2,253.2	0.0	0.0	1	1	1
07/21/2014 19:00	0.0	11.2	2,257.7	0.0	0.0	1	1	1
07/21/2014 20:00	0.0	11.3	2,259.8	0.0	0.0	1	1	1
07/21/2014 21:00	0.0	11.7	2,167.9	0.0	0.0	1	1	1
07/21/2014 22:00	0.0	12.4	2,026.8	0.0	0.0	1	1	1
07/21/2014 23:00	0.0	12.7	1,958.4	0.0	0.0	1	1	1
Average/Sum#:	4.0	13.1	1,805.2	0.0	145.7 #	23 #	20 #	16 #
Minimum:	0.0	11.2	477.1	0.0	0.0	0	0	0
Maximum:	53.8	17.4	2,259.8	0.0	67.8	1	1	1
%SI	4.2	4.2	4.2	25.0	4.2	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/22/2014 00:00	0.0	13.2	1,856.2	0.0	0.0	1	1	1
07/22/2014 01:00	0.0	13.2	1,872.5	0.0	0.0	1	1	1
07/22/2014 02:00	0.0	13.2	1,867.9	0.0	0.0	1	1	1
07/22/2014 03:00	0.0	13.2	1,857.4	0.0	0.0	1	1	1
07/22/2014 04:00	0.0	13.0	1,928.6	0.0	0.0	1	1	1
07/22/2014 05:00	0.0	13.2	1,885.8	0.0	0.0	1	1	1
07/22/2014 06:00	0.0	13.2	1,869.2	0.0	0.0	1	1	1
07/22/2014 07:00	0.0	12.9	1,950.3	0.0	0.0	1	1	1
07/22/2014 08:00	0.0	13.2	1,871.1	0.0	0.0	1	1	1
07/22/2014 09:00	0.0	13.2	1,858.2	0.0	0.0	1	1	1
07/22/2014 10:00	0.0	13.1	1,851.6	0.0	0.0	1	1	1
07/22/2014 11:00	0.0	12.7	1,953.3	0.0	0.0	1	1	1
07/22/2014 12:00	0.0	12.3	2,028.4	0.0	0.0	1	1	1
07/22/2014 13:00	0.0	12.5	1,987.3	0.0	0.0	1	1	1
07/22/2014 14:00	0.0	12.3	2,020.1	0.0	0.0	1	1	1
07/22/2014 15:00	0.0	11.7	2,153.5	0.0	0.0	1	1	1
07/22/2014 16:00	0.0	12.0	2,095.4	0.0	0.0	1	1	1
07/22/2014 17:00	0.0	12.2	2,045.9	0.0	0.0	1	1	1
07/22/2014 18:00	0.0	11.8	2,147.4	0.0	0.0	1	1	1
07/22/2014 19:00	0.0	12.1	2,102.5	0.0	0.0	1	1	1
07/22/2014 20:00	0.0	12.2	2,079.2	0.0	0.0	1	1	1
07/22/2014 21:00	0.0	12.3	2,078.9	0.0	0.0	1	1	1
07/22/2014 22:00	0.0	12.7	1,982.9	0.0	0.0	1	1	1
07/22/2014 23:00	0.0	13.6	1,542.3	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.7	1,953.6	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.7	1,542.3	0.0	0.0	1	1	1
Maximum:	0.0	13.6	2,153.5	0.0	0.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/23/2014 00:00	0.0	13.8	1,286.2	0.0	0.0	1	1	0
07/23/2014 01:00	0.0	13.8	1,270.5	0.0	0.0	1	1	0
07/23/2014 02:00	0.0	13.8	1,252.7	0.0	0.0	1	1	0
07/23/2014 03:00	0.0	13.8	1,252.5	0.0	0.0	1	1	0
07/23/2014 04:00	0.0	13.8	1,272.5	0.0	0.0	1	1	0
07/23/2014 05:00	0.0	13.8	1,538.2	0.0	0.0	1	1	1
07/23/2014 06:00	0.0	13.1	1,932.8	0.0	0.0	1	1	1
07/23/2014 07:00	0.0	13.0	1,932.5	0.0	0.0	1	1	1
07/23/2014 08:00	0.0	13.1	1,908.1	0.0	0.0	1	1	1
07/23/2014 09:00	0.0	13.1	1,898.3	0.0	0.0	1	1	1
07/23/2014 10:00	0.0	13.2	1,875.5	0.0	0.0	1	1	1
07/23/2014 11:00	0.0	13.2	1,876.9	0.0	0.0	1	1	1
07/23/2014 12:00	0.0	13.2	1,876.6	0.0	0.0	1	1	1
07/23/2014 13:00	0.0	13.2	1,868.6	0.0	0.0	1	1	1
07/23/2014 14:00	0.0	13.0	1,909.4	0.0	0.0	1	1	1
07/23/2014 15:00	0.0	12.4	2,022.0	0.0	0.0	1	1	1
07/23/2014 16:00	0.0	12.0	2,105.5	0.0	0.0	1	1	1
07/23/2014 17:00	0.0	12.5	1,985.5	0.0	0.0	1	1	1
07/23/2014 18:00	0.0	12.3	2,039.1	0.0	0.0	1	1	1
07/23/2014 19:00	0.0	12.4	2,017.0	0.0	0.0	1	1	1
07/23/2014 20:00	0.0	12.7	1,970.8	0.0	0.0	1	1	1
07/23/2014 21:00	0.0	12.8	1,937.7	0.0	0.0	1	1	1
07/23/2014 22:00	0.0	13.1	1,877.3	0.0	0.0	1	1	1
07/23/2014 23:00	0.0	12.9	1,921.5	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.1	1,784.5	0.0	0.0 #	24 #	24 #	19 #
Minimum:	0.0	12.0	1,252.5	0.0	0.0	1	1	0
Maximum:	0.0	13.8	2,105.5	0.0	0.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/24/2014 00:00	0.0	13.1	1,884.0	0.0	0.0	1	1	1
07/24/2014 01:00	0.0	13.2	1,888.7	0.0	0.0	1	1	1
07/24/2014 02:00	0.0	13.7	1,487.4	0.0	0.0	1	1	1
07/24/2014 03:00	0.0	13.9	1,257.5	0.0	0.0	1	1	0
07/24/2014 04:00	0.0	13.9	1,253.3	0.0	0.0	1	1	0
07/24/2014 05:00	0.0	13.9	1,257.7	0.0	0.0	1	1	0
07/24/2014 06:00	0.0	13.9	1,260.3	0.0	0.0	1	1	0
07/24/2014 07:00	0.0	13.9	1,265.1	0.0	0.0	1	1	0
07/24/2014 08:00	0.0	13.8	1,569.3	0.0	0.0	1	1	0
07/24/2014 09:00	0.0	13.1	1,908.3	0.0	0.0	1	1	1
07/24/2014 10:00	0.0	12.9	1,939.4	0.0	0.0	1	1	1
07/24/2014 11:00	0.0	12.8	1,971.7	0.0	0.0	1	1	1
07/24/2014 12:00	0.0	12.1	2,121.1	0.0	0.0	1	1	1
07/24/2014 13:00	0.0	11.3	2,284.2	0.0	0.0	1	1	1
07/24/2014 14:00	0.0	11.5	2,237.2	0.0	0.0	1	1	1
07/24/2014 15:00	0.0	12.0	2,123.0	0.0	0.0	1	1	1
07/24/2014 16:00	0.0	11.9	2,128.6	0.0	0.0	1	1	1
07/24/2014 17:00	0.0	12.0	2,125.8	0.0	0.0	1	1	1
07/24/2014 18:00	0.0	12.0	2,116.9	0.0	0.0	1	1	1
07/24/2014 19:00	0.0	12.1	2,089.5	0.0	0.0	1	1	1
07/24/2014 20:00	0.0	12.3	2,054.3	0.0	0.0	1	1	1
07/24/2014 21:00	0.0	13.3	1,751.3	0.0	0.0	1	1	1
07/24/2014 22:00	0.0	13.0	1,919.0	0.0	0.0	1	1	1
07/24/2014 23:00	0.0	12.3	2,070.7	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.8	1,831.8	0.0	0.0 #	24 #	24 #	18 #
Minimum:	0.0	11.3	1,253.3	0.0	0.0	1	1	0
Maximum:	0.0	13.9	2,284.2	0.0	0.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/25/2014 00:00	0.0	13.0	1,916.3	0.0	0.0	1	1	1
07/25/2014 01:00	0.0	13.3	1,873.0	0.0	0.0	1	1	1
07/25/2014 02:00	0.0	13.3	1,871.4	0.0	0.0	1	1	1
07/25/2014 03:00	0.0	13.3	1,868.8	0.0	0.0	1	1	1
07/25/2014 04:00	0.0	13.1	1,912.8	0.0	0.0	1	1	1
07/25/2014 05:00	0.0	13.1	1,933.8	0.0	0.0	1	1	1
07/25/2014 06:00	0.0	13.0	1,932.0	0.0	0.0	1	1	1
07/25/2014 07:00	0.0	12.9	1,939.4	0.0	0.0	1	1	1
07/25/2014 08:00	0.0	13.1	1,898.4	0.0	0.0	1	1	1
07/25/2014 09:00	0.0	12.9	1,937.2	0.0	0.0	1	1	1
07/25/2014 10:00	0.0	12.2	2,091.2	0.0	0.0	1	1	1
07/25/2014 11:00	0.0	11.7	2,184.8	0.0	0.0	1	1	1
07/25/2014 12:00	0.0	11.9	2,146.8	0.0	0.0	1	1	1
07/25/2014 13:00	0.0	12.3	2,032.5	0.0	0.0	1	1	1
07/25/2014 14:00	0.0	12.1	2,086.4	0.0	0.0	1	1	1
07/25/2014 15:00	0.0	11.7	2,173.3	0.0	0.0	1	1	1
07/25/2014 16:00	0.0	11.8	2,152.0	0.0	0.0	1	1	1
07/25/2014 17:00	0.0	11.7	2,179.7	0.0	0.0	1	1	1
07/25/2014 18:00	0.0	11.7	2,171.9	0.0	0.0	1	1	1
07/25/2014 19:00	0.0	11.5	2,205.3	0.0	0.0	1	1	1
07/25/2014 20:00	0.0	11.9	2,124.0	0.0	0.0	1	1	1
07/25/2014 21:00	0.0	12.3	2,053.2	0.0	0.0	1	1	1
07/25/2014 22:00	0.0	12.4	2,038.9	0.0	0.0	1	1	1
07/25/2014 23:00	0.0	12.9	1,934.4	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.5	2,027.4	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.5	1,868.8	0.0	0.0	1	1	1
Maximum:	0.0	13.3	2,205.3	0.0	0.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/26/2014 00:00	0.0	13.1	1,887.7	0.0	0.0	1	1	1
07/26/2014 01:00	0.0	13.2	1,867.2	0.0	0.0	1	1	1
07/26/2014 02:00	0.0	13.3	1,865.0	0.0	0.0	1	1	1
07/26/2014 03:00	0.0	13.3	1,862.0	0.0	0.0	1	1	1
07/26/2014 04:00	0.0	13.1	1,903.7	0.0	0.0	1	1	1
07/26/2014 05:00	0.0	13.3	1,860.8	0.0	0.0	1	1	1
07/26/2014 06:00	0.0	13.3	1,854.1	0.0	0.0	1	1	1
07/26/2014 07:00	0.0	13.2	1,872.2	0.0	0.0	1	1	1
07/26/2014 08:00	0.0	13.1	1,872.7	0.0	0.0	1	1	1
07/26/2014 09:00	0.0	13.1	1,861.1	0.0	0.0	1	1	1
07/26/2014 10:00	0.0	13.1	1,872.1	0.0	0.0	1	1	1
07/26/2014 11:00	0.0	12.5	2,000.6	0.0	0.0	1	1	1
07/26/2014 12:00	0.0	11.7	2,155.3	0.0	0.0	1	1	1
07/26/2014 13:00	0.0	11.7	2,156.1	0.0	0.0	1	1	1
07/26/2014 14:00	0.0	12.1	2,058.3	0.0	0.0	1	1	1
07/26/2014 15:00	0.0	13.4	1,675.7	0.0	0.0	1	1	1
07/26/2014 16:00	0.0	13.4	1,642.0	0.0	0.0	1	1	1
07/26/2014 17:00	0.0	12.6	1,960.2	0.0	0.0	1	1	1
07/26/2014 18:00	0.0	13.0	1,839.6	0.0	0.0	1	1	1
07/26/2014 19:00	0.0	13.9	1,265.7	0.0	0.0	1	1	0
07/26/2014 20:00	0.0	14.0	1,253.1	0.0	0.0	1	1	0
07/26/2014 21:00	0.0	14.0	1,252.3	0.0	0.0	1	1	0
07/26/2014 22:00	0.0	13.9	1,250.5	0.0	0.0	1	1	0
07/26/2014 23:00	0.0	13.9	1,410.0	0.0	0.0	1	1	0
Average/Sum#:	0.0	13.1	1,770.8	0.0	0.0 #	24 #	24 #	19 #
Minimum:	0.0	11.7	1,250.5	0.0	0.0	1	1	0
Maximum:	0.0	14.0	2,156.1	0.0	0.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/27/2014 00:00	0.0	13.8	1,503.4	0.0	0.0	1	1	0
07/27/2014 01:00	0.0	13.9	1,355.8	0.0	0.0	1	1	0
07/27/2014 02:00	0.0	13.8	1,382.1	0.0	0.0	1	1	0
07/27/2014 03:00	0.0	13.9	1,277.6	0.0	0.0	1	1	0
07/27/2014 04:00	0.0	13.9	1,334.2	0.0	0.0	1	1	0
07/27/2014 05:00	0.0	13.9	1,287.6	0.0	0.0	1	1	0
07/27/2014 06:00	0.0	13.5	1,532.8	0.0	0.0	1	1	1
07/27/2014 07:00	0.0	13.0	1,914.7	0.0	0.0	1	1	1
07/27/2014 08:00	0.0	13.3	1,782.0	0.0	0.0	1	1	1
07/27/2014 09:00	0.0	13.0	1,890.8	0.0	0.0	1	1	1
07/27/2014 10:00	0.0	12.9	1,916.2	0.0	0.0	1	1	1
07/27/2014 11:00	0.0	12.2	2,071.2	0.0	0.0	1	1	1
07/27/2014 12:00	0.0	12.4	2,014.8	0.0	0.0	1	1	1
07/27/2014 13:00	0.0	12.5	1,991.2	0.0	0.0	1	1	1
07/27/2014 14:00	0.0	12.8	1,934.3	0.0	0.0	1	1	1
07/27/2014 15:00	0.0	12.0	2,118.5	0.0	0.0	1	1	1
07/27/2014 16:00	0.0	11.8	2,147.1	0.0	0.0	1	1	1
07/27/2014 17:00	0.0	11.7	2,149.3	0.0	0.0	1	1	1
07/27/2014 18:00	0.0	11.7	2,148.2	0.0	0.0	1	1	1
07/27/2014 19:00	0.0	11.9	2,091.5	0.0	0.0	1	1	1
07/27/2014 20:00	0.0	13.0	1,849.4	0.0	0.0	1	1	1
07/27/2014 21:00	0.0	13.3	1,690.9	0.0	0.0	1	1	1
07/27/2014 22:00	0.0	13.4	1,672.6	0.0	0.0	1	1	1
07/27/2014 23:00	0.0	13.0	1,870.2	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.9	1,788.6	0.0	0.0 #	24 #	24 #	18 #
Minimum:	0.0	11.7	1,277.6	0.0	0.0	1	1	0
Maximum:	0.0	13.9	2,149.3	0.0	0.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/28/2014 00:00	0.0	13.1	1,874.1	0.0	0.0	1	1	1
07/28/2014 01:00	0.0	12.8	1,935.7	0.0	0.0	1	1	1
07/28/2014 02:00	0.0	13.2	1,762.8	0.0	0.0	1	1	1
07/28/2014 03:00	0.0	13.8	1,283.8	0.0	0.0	1	1	0
07/28/2014 04:00	0.0	13.5	1,606.5	0.0	0.0	1	1	1
07/28/2014 05:00	0.0	13.2	1,856.5	0.0	0.0	1	1	1
07/28/2014 06:00	0.0	13.2	1,854.2	0.0	0.0	1	1	1
07/28/2014 07:00	0.0	13.2	1,852.3	0.0	0.0	1	1	1
07/28/2014 08:00	0.0	13.2	1,851.6	0.0	0.0	1	1	1
07/28/2014 09:00	0.0	13.1	1,871.5	0.0	0.0	1	1	1
07/28/2014 10:00	0.0	12.0	2,115.2	0.0	0.0	1	1	1
07/28/2014 11:00	0.0	11.4	2,220.1	0.0	0.0	1	1	1
07/28/2014 12:00	0.0	11.7	2,144.9	0.0	0.0	1	1	1
07/28/2014 13:00	0.0	11.5	2,168.3	0.0	0.0	1	1	1
07/28/2014 14:00	0.0	11.7	2,148.3	0.0	0.0	1	1	1
07/28/2014 15:00	0.0	11.7	2,147.9	0.0	0.0	1	1	1
07/28/2014 16:00	0.0	11.7	2,130.6	0.0	0.0	1	1	1
07/28/2014 17:00	0.0	11.7	2,133.6	0.0	0.0	1	1	1
07/28/2014 18:00	0.0	12.5	1,980.1	0.0	0.0	1	1	1
07/28/2014 19:00	0.0	12.4	2,002.6	0.0	0.0	1	1	1
07/28/2014 20:00	0.0	12.6	1,974.6	0.0	0.0	1	1	1
07/28/2014 21:00	0.0	12.9	1,910.3	0.0	0.0	1	1	1
07/28/2014 22:00	0.0	12.8	1,943.9	0.0	0.0	1	1	1
07/28/2014 23:00	0.0	13.2	1,861.6	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.6	1,943.0	0.0	0.0 #	24 #	24 #	23 #
Minimum:	0.0	11.4	1,283.8	0.0	0.0	1	1	0
Maximum:	0.0	13.8	2,220.1	0.0	0.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/29/2014 00:00	0.0	12.8	1,954.7	0.0	0.0	1	1	1
07/29/2014 01:00	0.0	13.8	1,449.0	0.0	0.0	1	1	1
07/29/2014 02:00	0.0	13.9	1,257.6	0.0	0.0	1	1	0
07/29/2014 03:00	0.0	13.9	1,236.1	0.0	0.0	1	1	0
07/29/2014 04:00	0.0	13.8	1,373.7	0.0	0.0	1	1	1
07/29/2014 05:00	0.0	13.3	1,858.5	0.0	0.0	1	1	1
07/29/2014 06:00	0.0	12.9	1,941.3	0.0	0.0	1	1	1
07/29/2014 07:00	0.0	12.1	2,108.7	0.0	0.0	1	1	1
07/29/2014 08:00	0.0	12.3	2,060.8	0.0	0.0	1	1	1
07/29/2014 09:00	0.0	12.6	1,994.8	0.0	0.0	1	1	1
07/29/2014 10:00	0.0	11.7	2,175.2	0.0	0.0	1	1	1
07/29/2014 11:00	0.0	12.4	2,021.2	0.0	0.0	1	1	1
07/29/2014 12:00	0.0	11.9	2,136.0	0.0	0.0	1	1	1
07/29/2014 13:00	0.0	11.5	2,216.7	0.0	0.0	1	1	1
07/29/2014 14:00	0.0	11.5	2,212.1	0.0	0.0	1	1	1
07/29/2014 15:00	0.0	11.5	2,178.5	0.0	0.0	1	1	1
07/29/2014 16:00	0.0	12.0	2,076.2	0.0	0.0	1	1	1
07/29/2014 17:00	0.0	12.3	2,005.7	0.0	0.0	1	1	1
07/29/2014 18:00	0.0	12.3	1,997.9	0.0	0.0	1	1	1
07/29/2014 19:00	0.0	12.6	1,918.3	0.0	0.0	1	1	1
07/29/2014 20:00	0.0	13.1	1,850.7	0.0	0.0	1	1	1
07/29/2014 21:00	0.0	12.8	1,904.3	0.0	0.0	1	1	1
07/29/2014 22:00	0.0	13.2	1,836.5	0.0	0.0	1	1	1
07/29/2014 23:00	0.0	13.2	1,840.3	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.6	1,900.2	0.0	0.0 #	24 #	24 #	22 #
Minimum:	0.0	11.5	1,236.1	0.0	0.0	1	1	0
Maximum:	0.0	13.9	2,216.7	0.0	0.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/30/2014 00:00	0.0	13.2	1,827.8	0.0	0.0	1	1	1
07/30/2014 01:00	0.0	13.1	1,867.7	0.0	0.0	1	1	1
07/30/2014 02:00	0.0	13.7	1,404.7	0.0	0.0	1	1	1
07/30/2014 03:00	0.0	13.6	1,539.7	0.0	0.0	1	1	1
07/30/2014 04:00	0.0	13.2	1,865.3	0.0	0.0	1	1	1
07/30/2014 05:00	0.0	13.2	1,867.2	0.0	0.0	1	1	1
07/30/2014 06:00	0.0	13.2	1,856.3	0.0	0.0	1	1	1
07/30/2014 07:00	0.0	13.1	1,852.8	0.0	0.0	1	1	1
07/30/2014 08:00	0.0	13.2	1,855.6	0.0	0.0	1	1	1
07/30/2014 09:00	0.0	13.1	1,857.8	0.0	0.0	1	1	1
07/30/2014 10:00	0.0	13.1	1,862.2	0.0	0.0	1	1	1
07/30/2014 11:00	0.0	12.5	1,998.0	0.0	0.0	1	1	1
07/30/2014 12:00	0.0	11.5	2,195.1	0.0	0.0	1	1	1
07/30/2014 13:00	0.0	11.5	2,208.4	0.0	0.0	1	1	1
07/30/2014 14:00	0.0	11.5	2,189.5	0.0	0.0	1	1	1
07/30/2014 15:00	0.0	11.5	2,169.6	0.0	0.0	1	1	1
07/30/2014 16:00	0.0	11.5	2,170.8	0.0	0.0	1	1	1
07/30/2014 17:00	0.0	11.5	2,164.0	0.0	0.0	1	1	1
07/30/2014 18:00	0.0	11.6	2,162.0	0.0	0.0	1	1	1
07/30/2014 19:00	0.0	11.8	2,117.6	0.0	0.0	1	1	1
07/30/2014 20:00	0.0	12.3	2,005.1	0.0	0.0	1	1	1
07/30/2014 21:00	0.0	11.8	2,143.7	0.0	0.0	1	1	1
07/30/2014 22:00	0.0	12.0	2,097.3	0.0	0.0	1	1	1
07/30/2014 23:00	0.0	12.2	2,049.1	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.5	1,972.0	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.5	1,404.7	0.0	0.0	1	1	1
Maximum:	0.0	13.7	2,208.4	0.0	0.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/31/2014 00:00	0.0	13.4	1,697.7	0.0	0.0	1	1	1
07/31/2014 01:00	0.0	13.7	1,706.5	0.0	0.0	1	1	0
07/31/2014 02:00	0.0	13.3	1,762.8	0.0	0.0	1	1	1
07/31/2014 03:00	0.0	13.0	1,893.5	0.0	0.0	1	1	1
07/31/2014 04:00	0.0	13.1	1,866.6	0.0	0.0	1	1	1
07/31/2014 05:00	0.0	13.2	1,862.6	0.0	0.0	1	1	1
07/31/2014 06:00	0.0	13.1	1,860.8	0.0	0.0	1	1	1
07/31/2014 07:00	0.0	13.1	1,861.0	0.0	0.0	1	1	1
07/31/2014 08:00	0.0	13.0	1,865.3	0.0	0.0	1	1	1
07/31/2014 09:00	0.0	12.7	1,939.6	0.0	0.0	1	1	1
07/31/2014 10:00	0.0	11.5	2,176.9	0.0	0.0	1	1	1
07/31/2014 11:00	0.0	11.4	2,205.1	0.0	0.0	1	1	1
07/31/2014 12:00	0.0	11.5	2,178.3	0.0	0.0	1	1	1
07/31/2014 13:00	0.0	12.7	1,909.2	0.0	0.0	1	1	1
07/31/2014 14:00	0.0	12.6	1,942.2	0.0	0.0	1	1	1
07/31/2014 15:00	0.0	12.2	2,027.8	0.0	0.0	1	1	1
07/31/2014 16:00	0.0	12.1	2,037.9	0.0	0.0	1	1	1
07/31/2014 17:00	0.0	12.0	2,032.7	0.0	0.0	1	1	1
07/31/2014 18:00	0.0	12.1	2,028.8	0.0	0.0	1	1	1
07/31/2014 19:00	0.0	12.1	2,018.2	0.0	0.0	1	1	1
07/31/2014 20:00	0.0	12.3	1,999.5	0.0	0.0	1	1	1
07/31/2014 21:00	0.0	12.4	1,982.5	0.0	0.0	1	1	1
07/31/2014 22:00	0.0	12.7	1,912.5	0.0	0.0	1	1	1
07/31/2014 23:00	0.0	12.8	1,909.1	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.6	1,944.9	0.0	0.0 #	24 #	24 #	23 #
Minimum:	0.0	11.4	1,697.7	0.0	0.0	1	1	0
Maximum:	0.0	13.7	2,205.1	0.0	0.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/01/2014 00:00	0.0	12.8	1,910.6	0.0	0.0	1	1	1
08/01/2014 01:00	0.0	13.6	1,585.6	0.0	0.0	1	1	1
08/01/2014 02:00	0.0	13.6	1,593.2	0.0	0.0	1	1	1
08/01/2014 03:00	0.0	12.9	1,910.5	0.0	0.0	1	1	1
08/01/2014 04:00	0.0	13.1	1,874.3	0.0	0.0	1	1	1
08/01/2014 05:00	0.0	13.0	1,919.3	0.0	0.0	1	1	1
08/01/2014 06:00	0.0	13.2	1,854.0	0.0	0.0	1	1	1
08/01/2014 07:00	0.0	13.2	1,851.7	0.0	0.0	1	1	1
08/01/2014 08:00	0.0	12.8	1,917.7	0.0	0.0	1	1	1
08/01/2014 09:00	0.0	12.3	2,037.3	0.0	0.0	1	1	1
08/01/2014 10:00	0.0	11.8	2,135.6	0.0	0.0	1	1	1
08/01/2014 11:00	0.0	11.4	2,192.5	0.0	0.0	1	1	1
08/01/2014 12:00	0.0	11.5	2,162.4	0.0	0.0	1	1	1
08/01/2014 13:00	0.0	11.5	2,156.8	0.0	0.0	1	1	1
08/01/2014 14:00	0.0	11.5	2,158.6	0.0	0.0	1	1	1
08/01/2014 15:00	0.0	11.6	2,134.5	0.0	0.0	1	1	1
08/01/2014 16:00	0.0	11.9	2,079.3	0.0	0.0	1	1	1
08/01/2014 17:00	0.0	12.1	2,046.6	0.0	0.0	1	1	1
08/01/2014 18:00	0.0	12.1	2,035.3	0.0	0.0	1	1	1
08/01/2014 19:00	0.0	12.3	2,026.1	0.0	0.0	1	1	1
08/01/2014 20:00	0.0	12.7	1,962.1	0.0	0.0	1	1	1
08/01/2014 21:00	0.0	12.8	1,930.4	0.0	0.0	1	1	1
08/01/2014 22:00	0.0	12.9	1,917.3	0.0	0.0	1	1	1
08/01/2014 23:00	0.0	12.7	1,954.7	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.5	1,972.8	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.4	1,585.6	0.0	0.0	1	1	1
Maximum:	0.0	13.6	2,192.5	0.0	0.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/02/2014 00:00	0.0	13.0	1,901.4	0.0	0.0	1	1	1
08/02/2014 01:00	0.0	13.1	1,877.5	0.0	0.0	1	1	1
08/02/2014 02:00	0.0	13.2	1,854.5	0.0	0.0	1	1	1
08/02/2014 03:00	0.0	13.9	1,307.7	0.0	0.0	1	1	0
08/02/2014 04:00	0.0	13.9	1,476.7	0.0	0.0	1	1	0
08/02/2014 05:00	0.0	13.9	1,268.3	0.0	0.0	1	1	0
08/02/2014 06:00	0.0	13.8	1,243.7	0.0	0.0	1	1	0
08/02/2014 07:00	0.0	13.6	1,520.0	0.0	0.0	1	1	1
08/02/2014 08:00	0.0	13.1	1,874.3	0.0	0.0	1	1	1
08/02/2014 09:00	0.0	13.2	1,835.5	0.0	0.0	1	1	1
08/02/2014 10:00	0.0	13.2	1,844.1	0.0	0.0	1	1	1
08/02/2014 11:00	0.0	13.0	1,888.1	0.0	0.0	1	1	1
08/02/2014 12:00	0.0	12.8	1,929.7	0.0	0.0	1	1	1
08/02/2014 13:00	0.0	12.7	1,933.2	0.0	0.0	1	1	1
08/02/2014 14:00	0.0	12.8	1,890.5	0.0	0.0	1	1	1
08/02/2014 15:00	0.0	12.7	1,912.6	0.0	0.0	1	1	1
08/02/2014 16:00	0.0	12.6	1,921.2	0.0	0.0	1	1	1
08/02/2014 17:00	0.0	12.5	1,945.7	0.0	0.0	1	1	1
08/02/2014 18:00	0.0	12.6	1,934.6	0.0	0.0	1	1	1
08/02/2014 19:00	0.0	12.3	2,009.7	0.0	0.0	1	1	1
08/02/2014 20:00	0.0	12.3	2,004.2	0.0	0.0	1	1	1
08/02/2014 21:00	0.0	12.7	1,929.8	0.0	0.0	1	1	1
08/02/2014 22:00	0.0	13.6	1,543.0	0.0	0.0	1	1	1
08/02/2014 23:00	0.0	13.9	1,280.5	0.0	0.0	1	1	0
Average/Sum#:	0.0	13.1	1,755.3	0.0	0.0 #	24 #	24 #	19 #
Minimum:	0.0	12.3	1,243.7	0.0	0.0	1	1	0
Maximum:	0.0	13.9	2,009.7	0.0	0.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/03/2014 00:00	0.0	13.8	1,594.5	0.0	0.0	1	1	0
08/03/2014 01:00	0.0	13.8	1,491.5	0.0	0.0	1	1	0
08/03/2014 02:00	0.0	13.8	1,414.0	0.0	0.0	1	1	0
08/03/2014 03:00	0.0	13.8	1,598.2	0.0	0.0	1	1	0
08/03/2014 04:00	0.0	13.7	1,749.2	0.0	0.0	1	1	1
08/03/2014 05:00	0.0	13.4	1,840.9	0.0	0.0	1	1	1
08/03/2014 06:00	0.0	13.3	1,851.1	0.0	0.0	1	1	1
08/03/2014 07:00	0.0	12.7	1,975.3	0.0	0.0	1	1	1
08/03/2014 08:00	0.0	12.9	1,921.9	0.0	0.0	1	1	1
08/03/2014 09:00	0.0	12.9	1,909.1	0.0	0.0	1	1	1
08/03/2014 10:00	0.0	12.8	1,922.6	0.0	0.0	1	1	1
08/03/2014 11:00	0.0	12.8	1,932.9	0.0	0.0	1	1	1
08/03/2014 12:00	0.0	12.8	1,927.4	0.0	0.0	1	1	1
08/03/2014 13:00	0.0	11.9	2,105.6	0.0	0.0	1	1	1
08/03/2014 14:00	0.0	12.3	2,011.7	0.0	0.0	1	1	1
08/03/2014 15:00	0.0	11.7	2,137.2	0.0	0.0	1	1	1
08/03/2014 16:00	0.0	12.4	1,988.0	0.0	0.0	1	1	1
08/03/2014 17:00	0.0	12.5	1,971.7	0.0	0.0	1	1	1
08/03/2014 18:00	0.0	12.9	1,894.3	0.0	0.0	1	1	1
08/03/2014 19:00	0.0	12.6	1,973.2	0.0	0.0	1	1	1
08/03/2014 20:00	0.0	12.5	1,986.1	0.0	0.0	1	1	1
08/03/2014 21:00	0.0	12.9	1,888.0	0.0	0.0	1	1	1
08/03/2014 22:00	0.0	12.9	1,876.8	0.0	0.0	1	1	1
08/03/2014 23:00	0.0	12.7	1,954.8	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.9	1,871.5	0.0	0.0 #	24 #	24 #	20 #
Minimum:	0.0	11.7	1,414.0	0.0	0.0	1	1	0
Maximum:	0.0	13.8	2,137.2	0.0	0.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/04/2014 00:00	0.0	13.0	1,892.6	0.0	0.0	1	1	1
08/04/2014 01:00	0.0	12.9	1,923.8	0.0	0.0	1	1	1
08/04/2014 02:00	0.0	13.1	1,885.6	0.0	0.0	1	1	1
08/04/2014 03:00	0.0	12.9	1,938.1	0.0	0.0	1	1	1
08/04/2014 04:00	0.0	13.2	1,861.5	0.0	0.0	1	1	1
08/04/2014 05:00	0.0	13.0	1,829.8	0.0	0.0	1	1	1
08/04/2014 06:00	0.0	13.7	1,696.5	0.0	0.0	1	1	0
08/04/2014 07:00	0.0	13.7	1,680.4	0.0	0.0	1	1	0
08/04/2014 08:00	0.0	13.6	1,763.6	0.0	0.0	1	1	0
08/04/2014 09:00	0.0	13.6	1,757.1	0.0	0.0	1	1	0
08/04/2014 10:00	0.0	13.2	1,802.9	0.0	0.0	1	1	1
08/04/2014 11:00	0.0	12.8	1,925.6	0.0	0.0	1	1	1
08/04/2014 12:00	0.0	13.1	1,859.1	0.0	0.0	1	1	1
08/04/2014 13:00	0.0	13.1	1,862.8	0.0	0.0	1	1	1
08/04/2014 14:00	0.0	13.1	1,864.5	0.0	0.0	1	1	1
08/04/2014 15:00	0.0	13.0	1,863.9	0.0	0.0	1	1	1
08/04/2014 16:00	0.0	13.0	1,864.4	0.0	0.0	1	1	1
08/04/2014 17:00	0.0	13.1	1,863.2	0.0	0.0	1	1	1
08/04/2014 18:00	0.0	13.1	1,860.6	0.0	0.0	1	1	1
08/04/2014 19:00	0.0	13.1	1,859.5	0.0	0.0	1	1	1
08/04/2014 20:00	0.0	13.1	1,859.2	0.0	0.0	1	1	1
08/04/2014 21:00	0.0	13.3	1,589.4	0.0	0.0	1	1	1
08/04/2014 22:00	0.0	13.8	1,284.4	0.0	0.0	1	1	0
08/04/2014 23:00	0.0	13.7	1,609.1	0.0	0.0	1	1	0
Average/Sum#:	0.0	13.2	1,799.9	0.0	0.0 #	24 #	24 #	18 #
Minimum:	0.0	12.8	1,284.4	0.0	0.0	1	1	0
Maximum:	0.0	13.8	1,938.1	0.0	0.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/05/2014 00:00	0.0	13.4	1,765.9	0.0	0.0	1	1	1
08/05/2014 01:00	0.0	12.9	1,920.5	0.0	0.0	1	1	1
08/05/2014 02:00	0.0	12.7	1,955.5	0.0	0.0	1	1	1
08/05/2014 03:00	0.0	12.8	1,927.2	0.0	0.0	1	1	1
08/05/2014 04:00	0.0	12.8	1,934.7	0.0	0.0	1	1	1
08/05/2014 05:00	0.0	13.2	1,859.6	0.0	0.0	1	1	1
08/05/2014 06:00	0.0	13.0	1,896.0	0.0	0.0	1	1	1
08/05/2014 07:00	0.0	13.8	1,299.1	0.0	0.0	1	1	1
08/05/2014 08:00	0.0	13.8	1,254.9	0.0	0.0	1	1	0
08/05/2014 09:00	0.0	13.3	1,572.9	0.0	0.0	1	1	1
08/05/2014 10:00	0.0	13.1	1,866.4	0.0	0.0	1	1	1
08/05/2014 11:00	0.0	13.1	1,874.0	0.0	0.0	1	1	1
08/05/2014 12:00	0.0	12.9	1,911.7	0.0	0.0	1	1	1
08/05/2014 13:00	0.0	12.7	1,945.9	0.0	0.0	1	1	1
08/05/2014 14:00	0.0	12.7	1,955.0	0.0	0.0	1	1	1
08/05/2014 15:00	0.0	12.5	1,991.3	0.0	0.0	1	1	1
08/05/2014 16:00	0.0	12.7	1,943.3	0.0	0.0	1	1	1
08/05/2014 17:00	0.0	12.7	1,955.4	0.0	0.0	1	1	1
08/05/2014 18:00	0.0	12.6	1,968.0	0.0	0.0	1	1	1
08/05/2014 19:00	0.0	12.6	1,979.6	0.0	0.0	1	1	1
08/05/2014 20:00	0.0	12.8	1,913.2	0.0	0.0	1	1	1
08/05/2014 21:00	0.0	12.8	1,927.7	0.0	0.0	1	1	1
08/05/2014 22:00	0.0	13.4	1,476.3	0.0	0.0	1	1	1
08/05/2014 23:00	0.0	13.5	1,530.0	0.0	0.0	1	1	1
Average/Sum#:	0.0	13.0	1,817.7	0.0	0.0 #	24 #	24 #	23 #
Minimum:	0.0	12.5	1,254.9	0.0	0.0	1	1	0
Maximum:	0.0	13.8	1,991.3	0.0	0.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/06/2014 00:00	0.0	12.7	1,962.1	0.0	0.0	1	1	1
08/06/2014 01:00	0.0	12.6	1,984.1	0.0	0.0	1	1	1
08/06/2014 02:00	0.0	12.8	1,920.2	0.0	0.0	1	1	1
08/06/2014 03:00	0.0	13.1	1,865.4	0.0	0.0	1	1	1
08/06/2014 04:00	0.0	12.5	1,991.2	0.0	0.0	1	1	1
08/06/2014 05:00	0.0	12.4	2,029.4	0.0	0.0	1	1	1
08/06/2014 06:00	0.0	12.7	1,958.3	0.0	0.0	1	1	1
08/06/2014 07:00	0.0	12.8	1,933.2	0.0	0.0	1	1	1
08/06/2014 08:00	0.0	12.5	1,985.5	0.0	0.0	1	1	1
08/06/2014 09:00	0.0	12.3	2,037.1	0.0	0.0	1	1	1
08/06/2014 10:00	0.0	12.1	2,054.2	0.0	0.0	1	1	1
08/06/2014 11:00	0.0	12.0	2,073.7	0.0	0.0	1	1	1
08/06/2014 12:00	0.0	12.2	2,035.3	0.0	0.0	1	1	1
08/06/2014 13:00	0.0	12.2	2,023.0	0.0	0.0	1	1	1
08/06/2014 14:00	0.0	11.9	2,086.0	0.0	0.0	1	1	1
08/06/2014 15:00	0.0	12.2	2,007.1	0.0	0.0	1	1	1
08/06/2014 16:00	0.0	12.9	1,877.3	0.0	0.0	1	1	1
08/06/2014 17:00	0.0	12.5	1,960.3	0.0	0.0	1	1	1
08/06/2014 18:00	0.0	12.4	1,975.8	0.0	0.0	1	1	1
08/06/2014 19:00	0.0	12.2	2,017.0	0.0	0.0	1	1	1
08/06/2014 20:00	0.0	12.2	2,015.5	0.0	0.0	1	1	1
08/06/2014 21:00	0.0	12.6	1,935.0	0.0	0.0	1	1	1
08/06/2014 22:00	0.0	13.4	1,460.5	0.0	0.0	1	1	1
08/06/2014 23:00	0.0	13.7	1,659.5	0.0	0.0	1	1	0
Average/Sum#:	0.0	12.5	1,951.9	0.0	0.0 #	24 #	24 #	23 #
Minimum:	0.0	11.9	1,460.5	0.0	0.0	1	1	0
Maximum:	0.0	13.7	2,086.0	0.0	0.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/07/2014 00:00	4.1	14.3	1,138.0	0.0	8.6	1	0	0
08/07/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 07:00	22.3	17.2	504.2	0.0	27.3	1	0	0
08/07/2014 08:00	19.4	14.6	1,012.1	0.0	41.2	1	0	0
08/07/2014 09:00	0.0	13.9	1,340.3	0.0	0.0	1	1	0
08/07/2014 10:00	0.0	13.8	1,522.7	0.0	0.0	1	1	0
08/07/2014 11:00	0.0	13.6	1,721.7	0.0	0.0	1	1	0
08/07/2014 12:00	0.0	13.6	1,714.6	0.0	0.0	1	1	0
08/07/2014 13:00	0.0	13.6	1,711.7	0.0	0.0	1	1	0
08/07/2014 14:00	0.0	13.6	1,707.5	0.0	0.0	1	1	0
08/07/2014 15:00	0.0	13.0	1,721.9	0.0	0.0	1	1	1
08/07/2014 16:00	0.0	12.1	2,036.1	0.0	0.0	1	1	1
08/07/2014 17:00	0.0	11.6	2,128.9	0.0	0.0	1	1	1
08/07/2014 18:00	0.0	11.9	2,058.1	0.0	0.0	1	1	1
08/07/2014 19:00	0.0	12.3	2,003.3	0.0	0.0	1	1	1
08/07/2014 20:00	0.0	12.9	1,869.2	0.0	0.0	1	1	1
08/07/2014 21:00	0.0	12.8	1,899.9	0.0	0.0	1	1	1
08/07/2014 22:00	0.0	13.1	1,842.8	0.0	0.0	1	1	1
08/07/2014 23:00	0.0	13.2	1,829.5	0.0	0.0	1	1	1
Average/Sum#:	2.5	13.4	1,653.5	0.0	77.1 #	18 #	15 #	9 #
Minimum:	0.0	11.6	504.2	0.0	0.0	0	0	0
Maximum:	22.3	17.2	2,128.9	0.0	41.2	1	1	1
%SI	25.0	25.0	25.0	45.8	25.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/08/2014 00:00	0.0	12.8	1,945.3	0.0	0.0	1	1	1
08/08/2014 01:00	0.0	12.9	1,930.8	0.0	0.0	1	1	1
08/08/2014 02:00	0.0	13.3	1,844.6	0.0	0.0	1	1	1
08/08/2014 03:00	0.0	13.0	1,899.5	0.0	0.0	1	1	1
08/08/2014 04:00	0.0	12.9	1,934.3	0.0	0.0	1	1	1
08/08/2014 05:00	0.0	12.7	1,989.4	0.0	0.0	1	1	1
08/08/2014 06:00	0.0	12.6	1,990.0	0.0	0.0	1	1	1
08/08/2014 07:00	0.0	12.8	1,948.3	0.0	0.0	1	1	1
08/08/2014 08:00	0.0	13.0	1,900.5	0.0	0.0	1	1	1
08/08/2014 09:00	0.0	11.7	2,171.3	0.0	0.0	1	1	1
08/08/2014 10:00	0.0	12.0	2,064.6	0.0	0.0	1	1	1
08/08/2014 11:00	0.0	13.0	1,866.0	0.0	0.0	1	1	1
08/08/2014 12:00	0.0	12.8	1,900.6	0.0	0.0	1	1	1
08/08/2014 13:00	0.0	12.2	2,024.7	0.0	0.0	1	1	1
08/08/2014 14:00	0.0	11.6	2,148.5	0.0	0.0	1	1	1
08/08/2014 15:00	0.0	11.5	2,154.6	0.0	0.0	1	1	1
08/08/2014 16:00	0.0	11.6	2,143.8	0.0	0.0	1	1	1
08/08/2014 17:00	0.0	12.0	2,060.4	0.0	0.0	1	1	1
08/08/2014 18:00	0.0	11.4	2,178.8	0.0	0.0	1	1	1
08/08/2014 19:00	0.0	11.8	2,103.5	0.0	0.0	1	1	1
08/08/2014 20:00	0.0	12.3	2,005.2	0.0	0.0	1	1	1
08/08/2014 21:00	0.0	12.4	1,989.2	0.0	0.0	1	1	1
08/08/2014 22:00	0.0	12.8	1,896.9	0.0	0.0	1	1	1
08/08/2014 23:00	0.0	12.5	1,978.5	0.0	0.0	1	1	1
Average/Sum#:	0.0	12.4	2,002.9	0.0	0.0 #	24 #	24 #	24 #
Minimum:	0.0	11.4	1,844.6	0.0	0.0	1	1	1
Maximum:	0.0	13.3	2,178.8	0.0	0.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/09/2014 00:00	0.0	13.6	1,691.6	0.0	0.0	1	1	1
08/09/2014 01:00	0.0	13.7	1,541.2	0.0	0.0	1	1	0
08/09/2014 02:00	15.0	15.7	614.9	0.0	5.9	1	0	0
08/09/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/09/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/09/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/09/2014 06:00	31.0	16.2	585.4	0.0	35.7	1	0	0
08/09/2014 07:00	0.4	13.9	1,381.8	0.0	1.0	1	0	0
08/09/2014 08:00	0.0	13.9	1,346.9	0.0	0.0	1	1	0
08/09/2014 09:00	0.0	13.8	1,624.9	0.0	0.0	1	1	0
08/09/2014 10:00	0.0	13.7	1,741.7	0.0	0.0	1	1	0
08/09/2014 11:00	0.0	13.9	1,561.6	0.0	0.0	1	1	0
08/09/2014 12:00	0.0	13.7	1,469.0	0.0	0.0	1	1	1
08/09/2014 13:00	0.0	13.0	1,878.8	0.0	0.0	1	1	1
08/09/2014 14:00	0.0	12.9	1,905.5	0.0	0.0	1	1	1
08/09/2014 15:00	0.0	12.6	1,958.5	0.0	0.0	1	1	1
08/09/2014 16:00	0.0	12.6	1,938.9	0.0	0.0	1	1	1
08/09/2014 17:00	0.0	12.7	1,927.9	0.0	0.0	1	1	1
08/09/2014 18:00	0.0	12.1	2,053.3	0.0	0.0	1	1	1
08/09/2014 19:00	0.0	11.4	2,217.4	0.0	0.0	1	1	1
08/09/2014 20:00	0.0	11.8	2,139.7	0.0	0.0	1	1	1
08/09/2014 21:00	0.0	11.9	2,111.1	0.0	0.0	1	1	1
08/09/2014 22:00	0.0	12.5	2,014.2	0.0	0.0	1	1	1
08/09/2014 23:00	0.0	13.3	1,686.7	0.0	0.0	1	1	1
Average/Sum#:	2.2	13.3	1,685.3	0.0	42.6 #	21 #	18 #	13 #
Minimum:	0.0	11.4	585.4	0.0	0.0	0	0	0
Maximum:	31.0	16.2	2,217.4	0.0	35.7	1	1	1
%SI	12.5	12.5	12.5	33.3	12.5	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/10/2014 00:00	14.5	15.6	607.0	0.0	5.0	1	0	0
08/10/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/10/2014 07:00	24.1	16.9	547.6	0.0	33.6	1	0	0
08/10/2014 08:00	7.7	14.2	1,225.8	0.0	18.6	1	0	0
08/10/2014 09:00	0.0	13.8	1,345.3	0.0	0.0	1	1	0
08/10/2014 10:00	0.0	13.8	1,700.9	0.0	0.0	1	1	0
08/10/2014 11:00	0.0	13.9	1,609.6	0.0	0.0	1	1	0
08/10/2014 12:00	0.0	13.8	1,587.3	0.0	0.0	1	1	1
08/10/2014 13:00	0.0	12.6	1,955.0	0.0	0.0	1	1	1
08/10/2014 14:00	0.0	12.6	1,957.4	0.0	0.0	1	1	1
08/10/2014 15:00	0.0	12.8	1,917.9	0.0	0.0	1	1	1
08/10/2014 16:00	0.0	12.3	2,022.9	0.0	0.0	1	1	1
08/10/2014 17:00	0.0	11.4	2,205.5	0.0	0.0	1	1	1
08/10/2014 18:00	0.0	11.5	2,192.1	0.0	0.0	1	1	1
08/10/2014 19:00	0.0	11.5	2,194.7	0.0	0.0	1	1	1
08/10/2014 20:00	0.0	11.6	2,176.5	0.0	0.0	1	1	1
08/10/2014 21:00	0.0	11.9	2,121.1	0.0	0.0	1	1	1
08/10/2014 22:00	0.0	12.8	1,935.3	0.0	0.0	1	1	1
08/10/2014 23:00	0.0	12.6	1,989.6	0.0	0.0	1	1	1
Average/Sum#:	2.6	13.1	1,738.4	0.0	57.2 #	18 #	15 #	12 #
Minimum:	0.0	11.4	547.6	0.0	0.0	0	0	0
Maximum:	24.1	16.9	2,205.5	0.0	33.6	1	1	1
%SI	25.0	25.0	25.0	45.8	25.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/11/2014 00:00	0.0	12.6	1,986.3	0.0	0.0	1	1	1
08/11/2014 01:00	0.0	12.6	1,991.7	0.0	0.0	1	1	1
08/11/2014 02:00	0.0	12.8	1,947.4	0.0	0.0	1	1	1
08/11/2014 03:00	0.0	12.6	1,993.3	0.0	0.0	1	1	1
08/11/2014 04:00	0.0	12.6	2,006.6	0.0	0.0	1	1	1
08/11/2014 05:00	0.0	12.9	1,956.2	0.0	0.0	1	1	1
08/11/2014 06:00	0.0	11.8	2,184.5	0.0	0.0	1	1	1
08/11/2014 07:00	0.0	12.5	2,008.9	0.0	0.0	1	1	1
08/11/2014 08:00	0.0	12.5	1,991.8	0.0	0.0	1	1	1
08/11/2014 09:00	0.0	11.5	2,219.1	0.0	0.0	1	1	1
08/11/2014 10:00	0.0	11.2	2,258.0	0.0	0.0	1	1	1
08/11/2014 11:00	0.0	11.2	2,267.0	0.0	0.0	1	1	1
08/11/2014 12:00	0.0	11.2	2,255.0	0.0	0.0	1	1	1
08/11/2014 13:00	0.0	11.3	2,232.9	0.0	0.0	1	1	1
08/11/2014 14:00	0.0	11.4	2,219.4	0.0	0.0	1	1	1
08/11/2014 15:00	0.0	11.4	2,216.0	0.0	0.0	1	1	1
08/11/2014 16:00	0.0	11.3	2,215.9	0.0	0.0	1	1	1
08/11/2014 17:00	0.0	11.3	2,214.0	0.0	0.0	1	1	1
08/11/2014 18:00	0.0	11.3	2,214.8	0.0	0.0	1	1	1
08/11/2014 19:00	0.0	11.3	2,239.7	0.0	0.0	1	1	1
08/11/2014 20:00	0.0	11.4	2,207.7	0.0	0.0	1	1	1
08/11/2014 21:00	0.0	12.5	1,939.4	0.0	0.0	1	1	1
08/11/2014 22:00	0.0	13.8	1,687.3	0.0	0.0	1	1	0
08/11/2014 23:00	0.0	13.8	1,677.6	0.0	0.0	1	1	0
Average/Sum#:	0.0	12.0	2,088.8	0.0	0.0 #	24 #	24 #	22 #
Minimum:	0.0	11.2	1,677.6	0.0	0.0	1	1	0
Maximum:	0.0	13.8	2,267.0	0.0	0.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/12/2014 00:00	0.0	13.8	1,633.0	0.0	0.0	1	1	0
08/12/2014 01:00	0.0	13.8	1,658.0	0.0	0.0	1	1	0
08/12/2014 02:00	0.0	13.8	1,536.7	0.0	0.0	1	1	0
08/12/2014 03:00	0.0	13.8	1,529.4	0.0	0.0	1	1	0
08/12/2014 04:00	0.0	13.8	1,691.4	0.0	0.0	1	1	0
08/12/2014 05:00	0.0	13.7	1,760.4	0.0	0.0	1	1	0
08/12/2014 06:00	0.0	13.7	1,760.4	0.0	0.0	1	1	0
08/12/2014 07:00	0.0	13.7	1,721.7	0.0	0.0	1	1	0
08/12/2014 08:00	0.0	13.8	1,311.0	0.0	0.0	1	1	0
08/12/2014 09:00	0.0	13.8	1,638.2	0.0	0.0	1	1	0
08/12/2014 10:00	0.0	13.7	1,747.0	0.0	0.0	1	1	0
08/12/2014 11:00	0.0	13.8	1,643.3	0.0	0.0	1	1	0
08/12/2014 12:00	0.0	13.6	1,737.2	0.0	0.0	1	1	0
08/12/2014 13:00	0.0	13.7	1,732.5	0.0	0.0	1	1	0
08/12/2014 14:00	0.0	13.6	1,731.4	0.0	0.0	1	1	0
08/12/2014 15:00	0.0	13.6	1,730.6	0.0	0.0	1	1	0
08/12/2014 16:00	0.0	13.7	1,731.1	0.0	0.0	1	1	0
08/12/2014 17:00	0.0	13.7	1,734.5	0.0	0.0	1	1	0
08/12/2014 18:00	0.0	13.6	1,739.1	0.0	0.0	1	1	0
08/12/2014 19:00	0.0	13.7	1,749.3	0.0	0.0	1	1	0
08/12/2014 20:00	0.0	13.7	1,752.8	0.0	0.0	1	1	0
08/12/2014 21:00	0.0	13.7	1,756.9	0.0	0.0	1	1	0
08/12/2014 22:00	0.0	13.7	1,766.9	0.0	0.0	1	1	0
08/12/2014 23:00	0.0	13.7	1,768.4	0.0	0.0	1	1	0
Average/Sum#:	0.0	13.7	1,690.1	0.0	0.0 #	24 #	24 #	0 #
Minimum:	0.0	13.6	1,311.0	0.0	0.0	1	1	0
Maximum:	0.0	13.8	1,768.4	0.0	0.0	1	1	0
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/13/2014 00:00	0.0	13.7	1,770.8	0.0	0.0	1	1	0
08/13/2014 01:00	4.5	14.4	1,364.5	0.0	8.8	1	0	0
08/13/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/13/2014 05:00	20.3	17.0	568.8	0.0	18.4	1	0	0
08/13/2014 06:00	0.0	13.7	1,726.2	0.0	0.0	1	0	0
08/13/2014 07:00	0.0	13.7	1,787.3	0.0	0.0	1	1	0
08/13/2014 08:00	0.0	13.7	1,777.7	0.0	0.0	1	1	0
08/13/2014 09:00	0.0	13.6	1,771.8	0.0	0.0	1	1	0
08/13/2014 10:00	0.0	13.6	1,763.6	0.0	0.0	1	1	0
08/13/2014 11:00	0.0	13.6	1,756.1	0.0	0.0	1	1	0
08/13/2014 12:00	0.0	13.6	1,749.4	0.0	0.0	1	1	0
08/13/2014 13:00	0.0	13.6	1,741.5	0.0	0.0	1	1	0
08/13/2014 14:00	0.0	13.6	1,732.9	0.0	0.0	1	1	0
08/13/2014 15:00	0.0	13.6	1,731.4	0.0	0.0	1	1	0
08/13/2014 16:00	0.0	13.6	1,729.4	0.0	0.0	1	1	0
08/13/2014 17:00	0.0	13.6	1,729.3	0.0	0.0	1	1	0
08/13/2014 18:00	0.0	13.6	1,731.9	0.0	0.0	1	1	0
08/13/2014 19:00	0.0	13.6	1,739.3	0.0	0.0	1	1	0
08/13/2014 20:00	0.0	13.6	1,748.6	0.0	0.0	1	1	0
08/13/2014 21:00	0.0	13.7	1,733.5	0.0	0.0	1	1	0
08/13/2014 22:00	0.0	13.8	1,652.4	0.0	0.0	1	1	0
08/13/2014 23:00	7.4	14.8	961.1	0.0	7.2	1	0	0
Average/Sum#:	1.5	13.9	1,631.8	0.0	34.4 #	21 #	17 #	0 #
Minimum:	0.0	13.6	568.8	0.0	0.0	0	0	0
Maximum:	20.3	17.0	1,787.3	0.0	18.4	1	1	0
%SI	12.5	12.5	12.5	37.5	12.5	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/14/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/15/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/16/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/17/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/18/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/19/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/20/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/21/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/22/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/23/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/24/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/25/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/26/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/27/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/28/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/29/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/30/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/31/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/01/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/02/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/03/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/04/2014 00:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 01:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 02:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 03:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 04:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 05:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 06:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 07:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 08:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 09:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 10:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 11:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 12:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 13:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 14:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 15:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 16:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 17:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 18:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 19:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 20:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 21:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 22:00	0.0	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 23:00	0.0	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0 #	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/05/2014 00:00	112.8	18.0	394.7	0.0	71.0	1	0	0
09/05/2014 01:00	21.0	16.9	549.5	0.0	38.1	1	0	0
09/05/2014 02:00	18.4	17.7	606.9	0.0	46.1	1	0	0
09/05/2014 03:00	17.2	17.7	609.8	0.0	43.3	1	0	0
09/05/2014 04:00	13.1	15.5	945.8	0.0	30.3	1	0	0
09/05/2014 05:00	0.2	13.9	1,438.9	0.0	0.5	1	1	0
09/05/2014 06:00	0.2	13.9	1,733.5	0.0	0.7	1	1	0
09/05/2014 07:00	0.2	13.9	1,728.2	0.2	0.7	1	1	0
09/05/2014 08:00	0.2	13.8	1,654.6	0.2	0.6	1	1	0
09/05/2014 09:00	0.2	13.9	1,420.2	0.2	0.5	1	1	0
09/05/2014 10:00	0.2	13.9	1,267.8	0.2	0.5	1	1	0
09/05/2014 11:00	0.2	14.0	1,368.1	0.2	0.5	1	1	0
09/05/2014 12:00	0.3	13.7	1,673.5	0.2	0.9	1	1	1
09/05/2014 13:00	0.6	12.8	1,942.7	0.3	1.9	1	1	1
09/05/2014 14:00	0.6	12.8	1,925.9	0.3	1.9	1	1	1
09/05/2014 15:00	0.6	12.6	1,963.4	0.4	1.9	1	1	1
09/05/2014 16:00	0.6	12.6	1,971.1	0.4	1.9	1	1	1
09/05/2014 17:00	0.4	11.7	2,184.5	0.4	1.3	1	1	1
09/05/2014 18:00	0.5	12.2	2,067.3	0.3	1.6	1	1	1
09/05/2014 19:00	0.6	12.6	1,974.3	0.3	1.9	1	1	1
09/05/2014 20:00	0.5	13.1	1,867.6	0.4	1.6	1	1	1
09/05/2014 21:00	0.6	12.8	1,941.9	0.4	1.9	1	1	1
09/05/2014 22:00	0.6	12.8	1,949.6	0.4	1.9	1	1	1
09/05/2014 23:00	0.4	11.7	2,202.5	0.4	1.3	1	1	1
Average/Sum#:	7.9	13.9	1,557.6	0.3	252.8 #	24 #	19 #	12 #
Minimum:	0.2	11.7	394.7	0.2	0.5	1	0	0
Maximum:	112.8	18.0	2,202.5	0.4	71.0	1	1	1
%SI	0.0	0.0	0.0	29.2	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/06/2014 00:00	0.5	12.2	2,074.3	0.3	1.6	1	1	1
09/06/2014 01:00	0.5	12.9	1,950.6	0.3	1.6	1	1	1
09/06/2014 02:00	0.6	12.7	1,997.0	0.4	1.9	1	1	1
09/06/2014 03:00	0.5	12.7	1,997.8	0.4	1.6	1	1	1
09/06/2014 04:00	0.6	12.7	1,989.4	0.4	1.9	1	1	1
09/06/2014 05:00	0.4	13.3	1,859.9	0.4	1.3	1	1	1
09/06/2014 06:00	0.5	13.2	1,872.3	0.4	1.6	1	1	1
09/06/2014 07:00	0.5	13.1	1,901.0	0.4	1.6	1	1	1
09/06/2014 08:00	0.5	13.3	1,855.8	0.4	1.6	1	1	1
09/06/2014 09:00	0.5	13.0	1,925.8	0.4	1.6	1	1	1
09/06/2014 10:00	0.5	13.0	1,901.5	0.4	1.6	1	1	1
09/06/2014 11:00	0.5	12.9	1,924.4	0.4	1.6	1	1	1
09/06/2014 12:00	0.5	12.3	2,043.0	0.4	1.6	1	1	1
09/06/2014 13:00	0.4	11.5	2,214.9	0.3	1.2	1	1	1
09/06/2014 14:00	0.5	12.1	2,071.3	0.3	1.6	1	1	1
09/06/2014 15:00	0.6	12.4	2,012.5	0.3	1.9	1	1	1
09/06/2014 16:00	0.5	12.5	1,986.7	0.4	1.6	1	1	1
09/06/2014 17:00	0.4	11.3	2,247.8	0.3	1.2	1	1	1
09/06/2014 18:00	0.4	11.6	2,176.0	0.3	1.2	1	1	1
09/06/2014 19:00	0.5	13.0	1,892.4	0.3	1.6	1	1	1
09/06/2014 20:00	0.5	13.2	1,853.9	0.4	1.6	1	1	1
09/06/2014 21:00	0.5	13.2	1,854.6	0.4	1.6	1	1	1
09/06/2014 22:00	0.6	13.1	1,894.5	0.4	1.9	1	1	1
09/06/2014 23:00	0.6	12.7	1,987.3	0.4	1.9	1	1	1
Average/Sum#:	0.5	12.7	1,978.5	0.4	38.4 #	24 #	24 #	24 #
Minimum:	0.4	11.3	1,853.9	0.3	1.2	1	1	1
Maximum:	0.6	13.3	2,247.8	0.4	1.9	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/07/2014 00:00	0.5	13.1	1,893.6	0.4	1.6	1	1	1
09/07/2014 01:00	0.5	13.1	1,900.6	0.4	1.6	1	1	1
09/07/2014 02:00	0.5	13.3	1,853.0	0.4	1.6	1	1	1
09/07/2014 03:00	0.5	13.3	1,848.2	0.4	1.6	1	1	1
09/07/2014 04:00	0.5	13.3	1,846.3	0.4	1.6	1	1	1
09/07/2014 05:00	0.5	13.3	1,848.6	0.4	1.6	1	1	1
09/07/2014 06:00	0.5	13.3	1,857.3	0.4	1.6	1	1	1
09/07/2014 07:00	0.5	13.3	1,860.3	0.4	1.6	1	1	1
09/07/2014 08:00	0.5	13.0	1,928.7	0.4	1.6	1	1	1
09/07/2014 09:00	0.6	12.5	2,039.6	0.4	1.9	1	1	1
09/07/2014 10:00	0.4	12.0	2,136.4	0.4	1.3	1	1	1
09/07/2014 11:00	0.5	12.0	2,122.4	0.3	1.6	1	1	1
09/07/2014 12:00	0.6	12.6	1,972.4	0.3	1.9	1	1	1
09/07/2014 13:00	0.6	12.7	1,951.2	0.4	1.9	1	1	1
09/07/2014 14:00	0.6	12.7	1,946.3	0.4	1.9	1	1	1
09/07/2014 15:00	0.6	12.7	1,958.1	0.4	1.9	1	1	1
09/07/2014 16:00	0.5	12.2	2,053.6	0.4	1.6	1	1	1
09/07/2014 17:00	0.4	11.4	2,221.0	0.3	1.2	1	1	1
09/07/2014 18:00	0.3	11.4	2,223.5	0.2	0.9	1	1	1
09/07/2014 19:00	0.3	11.4	2,220.5	0.2	0.9	1	1	1
09/07/2014 20:00	0.4	12.0	2,086.4	0.2	1.2	1	1	1
09/07/2014 21:00	0.5	13.0	1,897.3	0.3	1.6	1	1	1
09/07/2014 22:00	0.5	13.2	1,852.4	0.4	1.6	1	1	1
09/07/2014 23:00	0.6	13.0	1,918.4	0.4	1.9	1	1	1
Average/Sum#:	0.5	12.7	1,976.5	0.4	37.7 #	24 #	24 #	24 #
Minimum:	0.3	11.4	1,846.3	0.2	0.9	1	1	1
Maximum:	0.6	13.3	2,223.5	0.4	1.9	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/08/2014 00:00	0.4	13.6	1,499.2	0.4	1.1	1	1	1
09/08/2014 01:00	0.2	13.9	1,256.5	0.3	0.5	1	1	0
09/08/2014 02:00	0.2	13.9	1,251.7	0.2	0.5	1	1	0
09/08/2014 03:00	0.2	13.9	1,553.2	0.2	0.6	1	1	0
09/08/2014 04:00	0.5	13.0	1,943.0	0.3	1.6	1	1	1
09/08/2014 05:00	0.4	13.2	1,898.9	0.3	1.3	1	1	1
09/08/2014 06:00	0.4	11.9	2,137.2	0.3	1.3	1	1	1
09/08/2014 07:00	0.3	11.4	2,304.7	0.3	1.0	1	1	1
09/08/2014 08:00	0.3	12.0	2,151.0	0.2	1.0	1	1	1
09/08/2014 09:00	0.4	13.3	1,860.7	0.2	1.3	1	1	1
09/08/2014 10:00	0.5	13.4	1,840.3	0.3	1.6	1	1	1
09/08/2014 11:00	0.5	13.4	1,837.7	0.4	1.6	1	1	1
09/08/2014 12:00	0.5	13.3	1,838.1	0.4	1.6	1	1	1
09/08/2014 13:00	0.5	13.3	1,839.5	0.4	1.6	1	1	1
09/08/2014 14:00	0.5	13.2	1,844.0	0.4	1.6	1	1	1
09/08/2014 15:00	0.5	13.2	1,850.7	0.4	1.6	1	1	1
09/08/2014 16:00	0.4	13.3	1,600.3	0.4	1.1	1	1	1
09/08/2014 17:00	0.2	13.9	1,269.8	0.3	0.5	1	1	0
09/08/2014 18:00	0.2	14.0	1,520.7	0.2	0.6	1	1	0
09/08/2014 19:00	0.2	14.0	1,535.8	0.2	0.6	1	1	0
09/08/2014 20:00	0.2	13.9	1,445.5	0.2	0.5	1	1	0
09/08/2014 21:00	0.2	13.9	1,363.3	0.2	0.5	1	1	0
09/08/2014 22:00	0.2	13.9	1,298.7	0.2	0.5	1	1	0
09/08/2014 23:00	0.2	13.9	1,255.1	0.2	0.5	1	1	0
Average/Sum#:	0.3	13.4	1,674.8	0.3	24.6 #	24 #	24 #	14 #
Minimum:	0.2	11.4	1,251.7	0.2	0.5	1	1	0
Maximum:	0.5	14.0	2,304.7	0.4	1.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/09/2014 00:00	0.2	13.9	1,255.4	0.2	0.5	1	1	0
09/09/2014 01:00	0.2	13.9	1,255.2	0.2	0.5	1	1	0
09/09/2014 02:00	0.2	13.9	1,255.5	0.2	0.5	1	1	0
09/09/2014 03:00	0.2	13.9	1,355.0	0.2	0.5	1	1	0
09/09/2014 04:00	0.2	13.9	1,268.0	0.2	0.5	1	1	0
09/09/2014 05:00	0.2	13.8	1,305.6	0.2	0.5	1	1	0
09/09/2014 06:00	0.2	13.9	1,261.0	0.2	0.5	1	1	0
09/09/2014 07:00	0.2	13.9	1,269.1	0.2	0.5	1	1	0
09/09/2014 08:00	0.3	13.7	1,561.7	0.2	0.9	1	1	1
09/09/2014 09:00	0.4	13.2	1,878.8	0.2	1.3	1	1	1
09/09/2014 10:00	0.3	13.2	1,866.2	0.2	1.0	1	1	1
09/09/2014 11:00	0.3	13.1	1,859.4	0.2	0.9	1	1	1
09/09/2014 12:00	0.4	12.8	1,928.1	0.2	1.3	1	1	1
09/09/2014 13:00	0.4	12.7	1,935.9	0.3	1.2	1	1	1
09/09/2014 14:00	0.3	12.8	1,903.2	0.3	0.9	1	1	1
09/09/2014 15:00	0.3	12.9	1,881.4	0.2	0.9	1	1	1
09/09/2014 16:00	0.4	12.9	1,878.8	0.2	1.2	1	1	1
09/09/2014 17:00	0.4	12.8	1,892.9	0.3	1.2	1	1	1
09/09/2014 18:00	0.4	12.9	1,874.2	0.3	1.2	1	1	1
09/09/2014 19:00	0.4	13.0	1,869.3	0.3	1.3	1	1	1
09/09/2014 20:00	0.4	13.0	1,891.7	0.3	1.3	1	1	1
09/09/2014 21:00	0.4	12.8	1,927.3	0.3	1.3	1	1	1
09/09/2014 22:00	0.4	12.9	1,907.5	0.3	1.3	1	1	1
09/09/2014 23:00	0.4	12.4	2,017.2	0.3	1.3	1	1	1
Average/Sum#:	0.3	13.3	1,679.1	0.2	22.5 #	24 #	24 #	16 #
Minimum:	0.2	12.4	1,255.2	0.2	0.5	1	1	0
Maximum:	0.4	13.9	2,017.2	0.3	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/10/2014 00:00	0.4	12.4	2,015.0	0.3	1.3	1	1	1
09/10/2014 01:00	0.4	12.5	2,015.7	0.3	1.3	1	1	1
09/10/2014 02:00	0.3	12.9	1,908.0	0.3	0.9	1	1	1
09/10/2014 03:00	0.3	12.6	1,981.7	0.2	0.9	1	1	1
09/10/2014 04:00	0.3	12.3	2,039.3	0.2	0.9	1	1	1
09/10/2014 05:00	0.4	12.7	1,967.1	0.2	1.3	1	1	1
09/10/2014 06:00	0.3	13.3	1,866.7	0.2	1.0	1	1	1
09/10/2014 07:00	0.3	13.2	1,861.4	0.2	1.0	1	1	1
09/10/2014 08:00	0.3	13.2	1,859.8	0.2	1.0	1	1	1
09/10/2014 09:00	0.4	12.8	1,921.7	0.2	1.3	1	1	1
09/10/2014 10:00	0.2	13.6	1,542.0	0.2	0.6	1	1	1
09/10/2014 11:00	0.2	13.9	1,261.4	0.2	0.5	1	1	0
09/10/2014 12:00	0.4	13.4	1,718.5	0.2	1.2	1	1	1
09/10/2014 13:00	0.6	12.8	1,940.3	0.3	1.9	1	1	1
09/10/2014 14:00	0.6	12.6	1,992.7	0.4	1.9	1	1	1
09/10/2014 15:00	0.4	11.6	2,204.7	0.4	1.3	1	1	1
09/10/2014 16:00	0.4	11.3	2,252.6	0.3	1.2	1	1	1
09/10/2014 17:00	0.4	11.3	2,252.2	0.2	1.2	1	1	1
09/10/2014 18:00	0.4	11.4	2,234.5	0.2	1.2	1	1	1
09/10/2014 19:00	0.4	11.7	2,187.6	0.2	1.3	1	1	1
09/10/2014 20:00	0.5	12.0	2,114.3	0.3	1.6	1	1	1
09/10/2014 21:00	0.5	12.3	2,058.5	0.3	1.6	1	1	1
09/10/2014 22:00	0.6	12.5	2,044.6	0.3	1.9	1	1	1
09/10/2014 23:00	0.5	12.1	2,129.8	0.3	1.6	1	1	1
Average/Sum#:	0.4	12.5	1,973.8	0.3	29.9 #	24 #	24 #	23 #
Minimum:	0.2	11.3	1,261.4	0.2	0.5	1	1	0
Maximum:	0.6	13.9	2,252.6	0.4	1.9	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/11/2014 00:00	0.6	12.8	1,978.5	0.4	1.9	1	1	1
09/11/2014 01:00	0.5	13.3	1,866.1	0.4	1.6	1	1	1
09/11/2014 02:00	0.5	13.3	1,866.1	0.4	1.6	1	1	1
09/11/2014 03:00	0.5	13.3	1,866.3	0.4	1.6	1	1	1
09/11/2014 04:00	0.6	12.9	1,947.3	0.4	1.9	1	1	1
09/11/2014 05:00	0.6	12.3	2,091.1	0.4	1.9	1	1	1
09/11/2014 06:00	0.6	12.7	2,007.5	0.4	1.9	1	1	1
09/11/2014 07:00	0.6	12.7	1,992.8	0.4	1.9	1	1	1
09/11/2014 08:00	0.6	12.8	1,967.4	0.4	1.9	1	1	1
09/11/2014 09:00	0.6	12.6	2,014.9	0.4	1.9	1	1	1
09/11/2014 10:00	0.5	12.1	2,107.0	0.4	1.6	1	1	1
09/11/2014 11:00	0.4	11.9	2,136.1	0.3	1.3	1	1	1
09/11/2014 12:00	0.5	12.8	1,925.1	0.3	1.6	1	1	1
09/11/2014 13:00	0.6	12.9	1,914.3	0.4	1.9	1	1	1
09/11/2014 14:00	0.6	12.9	1,893.0	0.4	1.9	1	1	1
09/11/2014 15:00	0.6	12.9	1,886.7	0.4	1.9	1	1	1
09/11/2014 16:00	0.5	12.0	2,093.8	0.4	1.6	1	1	1
09/11/2014 17:00	0.4	11.4	2,219.1	0.3	1.2	1	1	1
09/11/2014 18:00	0.4	11.3	2,243.3	0.2	1.2	1	1	1
09/11/2014 19:00	0.4	11.7	2,182.1	0.2	1.3	1	1	1
09/11/2014 20:00	0.4	11.6	2,186.9	0.3	1.2	1	1	1
09/11/2014 21:00	0.5	12.4	2,024.0	0.3	1.6	1	1	1
09/11/2014 22:00	0.6	12.3	2,065.7	0.3	1.9	1	1	1
09/11/2014 23:00	0.3	11.5	2,261.1	0.3	1.0	1	1	1
Average/Sum#:	0.5	12.4	2,030.7	0.4	39.3 #	24 #	24 #	24 #
Minimum:	0.3	11.3	1,866.1	0.2	1.0	1	1	1
Maximum:	0.6	13.3	2,261.1	0.4	1.9	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/12/2014 00:00	0.4	11.8	2,177.1	0.3	1.3	1	1	1
09/12/2014 01:00	0.4	12.8	1,933.6	0.3	1.3	1	1	1
09/12/2014 02:00	0.3	12.3	2,020.5	0.3	0.9	1	1	1
09/12/2014 03:00	0.3	12.2	2,048.6	0.2	0.9	1	1	1
09/12/2014 04:00	0.3	11.5	2,249.6	0.2	0.9	1	1	1
09/12/2014 05:00	0.4	11.7	2,218.6	0.2	1.3	1	1	1
09/12/2014 06:00	0.3	11.6	2,260.9	0.2	1.0	1	1	1
09/12/2014 07:00	0.3	11.6	2,238.1	0.2	1.0	1	1	1
09/12/2014 08:00	0.4	11.9	2,161.1	0.2	1.3	1	1	1
09/12/2014 09:00	0.3	11.5	2,242.5	0.2	0.9	1	1	1
09/12/2014 10:00	0.3	11.6	2,227.8	0.2	0.9	1	1	1
09/12/2014 11:00	0.3	11.5	2,220.7	0.2	0.9	1	1	1
09/12/2014 12:00	0.3	11.4	2,232.4	0.2	0.9	1	1	1
09/12/2014 13:00	0.3	11.3	2,238.3	0.2	0.9	1	1	1
09/12/2014 14:00	0.4	11.4	2,213.7	0.2	1.2	1	1	1
09/12/2014 15:00	0.4	11.4	2,210.8	0.2	1.2	1	1	1
09/12/2014 16:00	0.4	11.4	2,204.4	0.2	1.2	1	1	1
09/12/2014 17:00	0.3	11.3	2,226.8	0.2	0.9	1	1	1
09/12/2014 18:00	0.3	11.4	2,233.1	0.2	0.9	1	1	1
09/12/2014 19:00	0.3	11.3	2,254.5	0.2	0.9	1	1	1
09/12/2014 20:00	0.4	11.7	2,196.1	0.2	1.3	1	1	1
09/12/2014 21:00	0.4	12.0	2,118.2	0.3	1.3	1	1	1
09/12/2014 22:00	0.5	12.6	1,977.0	0.3	1.6	1	1	1
09/12/2014 23:00	0.6	12.7	1,978.2	0.4	1.9	1	1	1
Average/Sum#:	0.4	11.7	2,170.1	0.2	26.8 #	24 #	24 #	24 #
Minimum:	0.3	11.3	1,933.6	0.2	0.9	1	1	1
Maximum:	0.6	12.8	2,260.9	0.4	1.9	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/13/2014 00:00	0.6	12.7	1,971.4	0.4	1.9	1	1	1
09/13/2014 01:00	0.5	12.9	1,940.6	0.4	1.6	1	1	1
09/13/2014 02:00	0.4	13.4	1,793.4	0.4	1.3	1	1	1
09/13/2014 03:00	0.5	13.2	1,866.2	0.4	1.6	1	1	1
09/13/2014 04:00	0.5	13.3	1,790.6	0.4	1.6	1	1	1
09/13/2014 05:00	0.2	13.9	1,261.6	0.3	0.5	1	1	0
09/13/2014 06:00	0.2	13.9	1,255.0	0.3	0.5	1	1	0
09/13/2014 07:00	0.2	13.9	1,254.4	0.2	0.5	1	1	0
09/13/2014 08:00	0.2	13.9	1,392.3	0.2	0.5	1	1	0
09/13/2014 09:00	0.2	14.0	1,514.4	0.2	0.6	1	1	0
09/13/2014 10:00	0.2	13.8	1,577.1	0.2	0.6	1	1	1
09/13/2014 11:00	0.6	12.5	2,017.7	0.3	1.9	1	1	1
09/13/2014 12:00	0.5	11.8	2,152.4	0.3	1.6	1	1	1
09/13/2014 13:00	0.6	12.2	2,037.1	0.4	1.9	1	1	1
09/13/2014 14:00	0.5	12.1	2,049.9	0.3	1.5	1	1	1
09/13/2014 15:00	0.4	11.7	2,155.8	0.3	1.2	1	1	1
09/13/2014 16:00	0.4	11.7	2,140.6	0.3	1.2	1	1	1
09/13/2014 17:00	0.5	11.8	2,107.7	0.3	1.5	1	1	1
09/13/2014 18:00	0.6	12.4	1,993.3	0.3	1.9	1	1	1
09/13/2014 19:00	0.6	12.2	2,039.3	0.4	1.9	1	1	1
09/13/2014 20:00	0.6	12.6	1,977.7	0.4	1.9	1	1	1
09/13/2014 21:00	0.6	12.6	1,971.8	0.4	1.9	1	1	1
09/13/2014 22:00	0.6	12.8	1,933.4	0.4	1.9	1	1	1
09/13/2014 23:00	0.6	12.7	1,966.1	0.4	1.9	1	1	1
Average/Sum#:	0.5	12.8	1,840.0	0.3	33.4 #	24 #	24 #	19 #
Minimum:	0.2	11.7	1,254.4	0.2	0.5	1	1	0
Maximum:	0.6	14.0	2,155.8	0.4	1.9	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/14/2014 00:00	0.5	12.9	1,918.3	0.4	1.6	1	1	1
09/14/2014 01:00	0.5	13.2	1,867.8	0.4	1.6	1	1	1
09/14/2014 02:00	0.5	13.3	1,863.4	0.4	1.6	1	1	1
09/14/2014 03:00	0.6	13.2	1,864.9	0.4	1.9	1	1	1
09/14/2014 04:00	0.6	13.3	1,801.4	0.5	1.9	1	1	1
09/14/2014 05:00	0.3	13.9	1,266.4	0.4	0.7	1	1	0
09/14/2014 06:00	0.2	13.9	1,256.6	0.3	0.5	1	1	0
09/14/2014 07:00	0.2	13.9	1,256.7	0.2	0.5	1	1	0
09/14/2014 08:00	0.2	13.9	1,439.5	0.2	0.5	1	1	0
09/14/2014 09:00	0.4	13.5	1,631.6	0.2	1.2	1	1	1
09/14/2014 10:00	0.6	12.9	1,923.7	0.3	1.9	1	1	1
09/14/2014 11:00	0.6	12.6	1,976.9	0.4	1.9	1	1	1
09/14/2014 12:00	0.4	11.4	2,233.9	0.3	1.2	1	1	1
09/14/2014 13:00	0.4	11.3	2,250.6	0.3	1.2	1	1	1
09/14/2014 14:00	0.4	11.3	2,250.5	0.2	1.2	1	1	1
09/14/2014 15:00	0.4	11.3	2,239.0	0.2	1.2	1	1	1
09/14/2014 16:00	0.3	11.3	2,230.5	0.2	0.9	1	1	1
09/14/2014 17:00	0.4	11.4	2,213.2	0.2	1.2	1	1	1
09/14/2014 18:00	0.4	11.5	2,193.8	0.2	1.2	1	1	1
09/14/2014 19:00	0.4	11.7	2,159.9	0.3	1.2	1	1	1
09/14/2014 20:00	0.4	12.0	2,108.8	0.3	1.3	1	1	1
09/14/2014 21:00	0.5	12.3	2,038.7	0.3	1.6	1	1	1
09/14/2014 22:00	0.5	12.8	1,949.4	0.3	1.6	1	1	1
09/14/2014 23:00	0.6	12.8	1,940.5	0.4	1.9	1	1	1
Average/Sum#:	0.4	12.6	1,911.5	0.3	31.5 #	24 #	24 #	20 #
Minimum:	0.2	11.3	1,256.6	0.2	0.5	1	1	0
Maximum:	0.6	13.9	2,250.6	0.5	1.9	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/15/2014 00:00	0.5	13.1	1,885.4	0.4	1.6	1	1	1
09/15/2014 01:00	0.5	13.2	1,860.5	0.4	1.6	1	1	1
09/15/2014 02:00	0.5	13.2	1,860.2	0.4	1.6	1	1	1
09/15/2014 03:00	0.5	13.2	1,862.6	0.4	1.6	1	1	1
09/15/2014 04:00	0.5	13.2	1,865.0	0.4	1.6	1	1	1
09/15/2014 05:00	0.5	13.2	1,869.1	0.4	1.6	1	1	1
09/15/2014 06:00	0.5	13.2	1,870.4	0.4	1.6	1	1	1
09/15/2014 07:00	0.5	13.1	1,888.7	0.4	1.6	1	1	1
09/15/2014 08:00	0.6	12.7	1,990.6	0.4	1.9	1	1	1
09/15/2014 09:00	0.4	11.9	2,162.6	0.4	1.3	1	1	1
09/15/2014 10:00	0.3	11.5	2,227.7	0.3	0.9	1	1	1
09/15/2014 11:00	0.3	11.4	2,237.3	0.2	0.9	1	1	1
09/15/2014 12:00	0.3	12.4	1,819.1	0.2	0.8	1	1	1
09/15/2014 13:00	0.2	14.0	1,327.6	0.2	0.5	1	1	0
09/15/2014 14:00	0.1	14.0	1,335.4	0.2	0.3	1	1	0
09/15/2014 15:00	0.5	12.6	1,938.5	0.2	1.5	1	1	1
09/15/2014 16:00	0.4	11.7	2,160.7	0.3	1.2	1	1	1
09/15/2014 17:00	0.4	11.9	2,140.7	0.3	1.3	1	1	1
09/15/2014 18:00	0.4	12.0	2,115.9	0.3	1.3	1	1	1
09/15/2014 19:00	0.5	12.2	2,091.3	0.3	1.6	1	1	1
09/15/2014 20:00	0.5	12.4	2,058.7	0.3	1.6	1	1	1
09/15/2014 21:00	0.5	12.9	1,939.8	0.3	1.6	1	1	1
09/15/2014 22:00	0.5	13.3	1,861.9	0.4	1.6	1	1	1
09/15/2014 23:00	0.5	13.2	1,871.5	0.4	1.6	1	1	1
Average/Sum#:	0.4	12.7	1,926.7	0.3	32.7 #	24 #	24 #	22 #
Minimum:	0.1	11.4	1,327.6	0.2	0.3	1	1	0
Maximum:	0.6	14.0	2,237.3	0.4	1.9	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/16/2014 00:00	0.5	13.3	1,860.5	0.4	1.6	1	1	1
09/16/2014 01:00	0.5	13.3	1,857.8	0.4	1.6	1	1	1
09/16/2014 02:00	0.3	13.7	1,573.0	0.3	0.9	1	1	1
09/16/2014 03:00	0.2	13.8	1,277.6	0.3	0.5	1	1	0
09/16/2014 04:00	0.3	13.5	1,648.3	0.2	0.9	1	1	1
09/16/2014 05:00	0.5	12.9	1,956.5	0.3	1.6	1	1	1
09/16/2014 06:00	0.5	12.8	1,970.9	0.3	1.6	1	1	1
09/16/2014 07:00	0.4	12.7	2,015.4	0.4	1.3	1	1	1
09/16/2014 08:00	0.4	12.5	2,051.0	0.3	1.3	1	1	1
09/16/2014 09:00	0.4	12.5	2,049.6	0.3	1.3	1	1	1
09/16/2014 10:00	0.3	11.7	2,218.3	0.3	1.0	1	1	1
09/16/2014 11:00	0.3	11.7	2,219.3	0.2	1.0	1	1	1
09/16/2014 12:00	0.3	11.7	2,224.3	0.2	1.0	1	1	1
09/16/2014 13:00	0.3	11.7	2,212.4	0.2	1.0	1	1	1
09/16/2014 14:00	0.4	12.4	2,043.3	0.2	1.3	1	1	1
09/16/2014 15:00	0.5	12.9	1,939.9	0.3	1.6	1	1	1
09/16/2014 16:00	0.5	12.3	2,067.4	0.3	1.6	1	1	1
09/16/2014 17:00	0.3	11.5	2,230.0	0.3	0.9	1	1	1
09/16/2014 18:00	0.3	11.5	2,232.5	0.2	0.9	1	1	1
09/16/2014 19:00	0.3	11.6	2,237.9	0.2	1.0	1	1	1
09/16/2014 20:00	0.4	11.8	2,178.1	0.2	1.3	1	1	1
09/16/2014 21:00	0.5	13.0	1,904.3	0.3	1.6	1	1	1
09/16/2014 22:00	0.4	13.5	1,690.1	0.3	1.2	1	1	1
09/16/2014 23:00	0.4	13.5	1,779.7	0.3	1.3	1	1	1
Average/Sum#:	0.4	12.6	1,976.6	0.3	29.3 #	24 #	24 #	23 #
Minimum:	0.2	11.5	1,277.6	0.2	0.5	1	1	0
Maximum:	0.5	13.8	2,237.9	0.4	1.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/17/2014 00:00	0.6	12.1	2,146.4	0.3	1.9	1	1	1
09/17/2014 01:00	0.5	12.1	2,132.3	0.3	1.6	1	1	1
09/17/2014 02:00	0.6	12.6	2,028.5	0.4	1.9	1	1	1
09/17/2014 03:00	0.5	11.8	2,219.9	0.3	1.6	1	1	1
09/17/2014 04:00	0.4	11.8	2,227.7	0.3	1.3	1	1	1
09/17/2014 05:00	0.4	11.9	2,198.8	0.3	1.3	1	1	1
09/17/2014 06:00	0.4	11.9	2,200.5	0.3	1.3	1	1	1
09/17/2014 07:00	0.4	11.8	2,221.9	0.3	1.3	1	1	1
09/17/2014 08:00	0.4	11.8	2,202.4	0.3	1.3	1	1	1
09/17/2014 09:00	0.4	11.8	2,181.4	0.3	1.3	1	1	1
09/17/2014 10:00	0.4	11.8	2,185.8	0.3	1.3	1	1	1
09/17/2014 11:00	0.4	11.7	2,197.7	0.3	1.3	1	1	1
09/17/2014 12:00	0.4	11.6	2,219.8	0.3	1.3	1	1	1
09/17/2014 13:00	0.4	11.6	2,204.0	0.3	1.3	1	1	1
09/17/2014 14:00	0.4	11.8	2,152.2	0.3	1.2	1	1	1
09/17/2014 15:00	0.4	12.0	2,104.5	0.3	1.2	1	1	1
09/17/2014 16:00	0.5	12.6	1,982.8	0.3	1.6	1	1	1
09/17/2014 17:00	0.5	12.6	1,980.0	0.4	1.6	1	1	1
09/17/2014 18:00	0.5	12.1	2,071.7	0.4	1.6	1	1	1
09/17/2014 19:00	0.5	12.4	2,003.1	0.3	1.6	1	1	1
09/17/2014 20:00	0.5	12.6	1,982.3	0.3	1.6	1	1	1
09/17/2014 21:00	0.4	13.1	1,862.1	0.3	1.3	1	1	1
09/17/2014 22:00	0.4	13.1	1,862.3	0.3	1.3	1	1	1
09/17/2014 23:00	0.5	13.1	1,873.5	0.3	1.6	1	1	1
Average/Sum#:	0.5	12.2	2,101.7	0.3	34.6 #	24 #	24 #	24 #
Minimum:	0.4	11.6	1,862.1	0.3	1.2	1	1	1
Maximum:	0.6	13.1	2,227.7	0.4	1.9	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/18/2014 00:00	0.6	12.7	1,979.9	0.4	1.9	1	1	1
09/18/2014 01:00	0.6	12.8	1,953.5	0.4	1.9	1	1	1
09/18/2014 02:00	0.4	13.2	1,867.8	0.4	1.3	1	1	1
09/18/2014 03:00	0.3	13.3	1,769.9	0.3	0.9	1	1	1
09/18/2014 04:00	0.2	13.8	1,572.2	0.2	0.6	1	1	0
09/18/2014 05:00	0.2	13.8	1,601.6	0.2	0.6	1	1	0
09/18/2014 06:00	0.2	13.8	1,597.0	0.2	0.6	1	1	0
09/18/2014 07:00	0.2	13.8	1,307.6	0.2	0.5	1	1	0
09/18/2014 08:00	0.2	13.8	1,417.4	0.2	0.5	1	1	0
09/18/2014 09:00	0.2	13.8	1,593.2	0.2	0.6	1	1	0
09/18/2014 10:00	0.2	13.9	1,292.0	0.2	0.5	1	1	0
09/18/2014 11:00	0.2	13.9	1,291.3	0.2	0.5	1	1	0
09/18/2014 12:00	0.2	13.9	1,483.1	0.2	0.6	1	1	0
09/18/2014 13:00	0.2	13.9	1,610.2	0.2	0.6	1	1	0
09/18/2014 14:00	0.2	13.8	1,672.3	0.2	0.6	1	1	0
09/18/2014 15:00	0.2	13.8	1,595.5	0.2	0.6	1	1	0
09/18/2014 16:00	0.4	13.4	1,725.0	0.2	1.2	1	1	1
09/18/2014 17:00	0.6	12.6	1,976.2	0.3	1.9	1	1	1
09/18/2014 18:00	0.5	12.2	2,074.7	0.3	1.6	1	1	1
09/18/2014 19:00	0.4	12.1	2,091.4	0.3	1.3	1	1	1
09/18/2014 20:00	0.4	13.0	1,882.9	0.3	1.3	1	1	1
09/18/2014 21:00	0.4	13.3	1,595.9	0.3	1.1	1	1	1
09/18/2014 22:00	0.1	13.9	1,245.0	0.2	0.2	1	1	0
09/18/2014 23:00	0.1	13.9	1,366.6	0.2	0.3	1	1	0
Average/Sum#:	0.3	13.4	1,648.4	0.3	21.7 #	24 #	24 #	10 #
Minimum:	0.1	12.1	1,245.0	0.2	0.2	1	1	0
Maximum:	0.6	13.9	2,091.4	0.4	1.9	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/19/2014 00:00	0.1	13.9	1,262.9	0.1	0.2	1	1	0
09/19/2014 01:00	0.1	13.9	1,253.8	0.1	0.2	1	1	0
09/19/2014 02:00	0.1	13.9	1,252.9	0.1	0.2	1	1	0
09/19/2014 03:00	0.1	13.9	1,320.6	0.1	0.2	1	1	0
09/19/2014 04:00	0.2	13.9	1,344.2	0.1	0.5	1	1	0
09/19/2014 05:00	0.3	13.6	1,618.6	0.2	0.9	1	1	1
09/19/2014 06:00	0.5	12.6	1,959.8	0.3	1.6	1	1	1
09/19/2014 07:00	0.4	13.3	1,862.8	0.3	1.3	1	1	1
09/19/2014 08:00	0.5	13.1	1,877.7	0.4	1.6	1	1	1
09/19/2014 09:00	0.5	13.1	1,886.8	0.4	1.6	1	1	1
09/19/2014 10:00	0.4	13.1	1,860.2	0.4	1.3	1	1	1
09/19/2014 11:00	0.4	13.1	1,857.6	0.3	1.3	1	1	1
09/19/2014 12:00	0.5	12.5	1,970.6	0.3	1.5	1	1	1
09/19/2014 13:00	0.5	12.5	1,967.0	0.4	1.5	1	1	1
09/19/2014 14:00	0.5	12.3	2,027.0	0.4	1.6	1	1	1
09/19/2014 15:00	0.3	11.2	2,233.8	0.3	0.9	1	1	1
09/19/2014 16:00	0.3	11.2	2,239.9	0.2	0.9	1	1	1
09/19/2014 17:00	0.3	11.3	2,227.5	0.2	0.9	1	1	1
09/19/2014 18:00	0.4	11.8	2,125.4	0.2	1.2	1	1	1
09/19/2014 19:00	0.4	12.7	1,939.5	0.3	1.2	1	1	1
09/19/2014 20:00	0.5	12.8	1,926.1	0.3	1.6	1	1	1
09/19/2014 21:00	0.5	12.8	1,937.0	0.4	1.6	1	1	1
09/19/2014 22:00	0.5	12.6	1,978.5	0.4	1.6	1	1	1
09/19/2014 23:00	0.5	12.4	2,029.8	0.4	1.6	1	1	1
Average/Sum#:	0.4	12.8	1,831.7	0.3	27.0 #	24 #	24 #	19 #
Minimum:	0.1	11.2	1,252.9	0.1	0.2	1	1	0
Maximum:	0.5	13.9	2,239.9	0.4	1.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/20/2014 00:00	0.5	12.2	2,071.1	0.3	1.6	1	1	1
09/20/2014 01:00	0.3	11.7	2,173.8	0.3	0.9	1	1	1
09/20/2014 02:00	0.5	12.5	2,001.4	0.3	1.6	1	1	1
09/20/2014 03:00	0.5	12.6	1,994.3	0.3	1.6	1	1	1
09/20/2014 04:00	0.5	12.5	2,008.9	0.4	1.6	1	1	1
09/20/2014 05:00	0.5	12.6	1,982.8	0.4	1.6	1	1	1
09/20/2014 06:00	0.5	12.6	1,995.2	0.4	1.6	1	1	1
09/20/2014 07:00	0.5	12.6	2,003.8	0.4	1.6	1	1	1
09/20/2014 08:00	0.4	13.2	1,860.3	0.4	1.3	1	1	1
09/20/2014 09:00	0.4	13.2	1,856.6	0.3	1.3	1	1	1
09/20/2014 10:00	0.4	13.1	1,854.0	0.3	1.3	1	1	1
09/20/2014 11:00	0.4	13.1	1,854.3	0.3	1.3	1	1	1
09/20/2014 12:00	0.4	13.1	1,857.1	0.3	1.3	1	1	1
09/20/2014 13:00	0.5	12.9	1,895.6	0.3	1.6	1	1	1
09/20/2014 14:00	0.5	12.8	1,907.8	0.4	1.6	1	1	1
09/20/2014 15:00	0.5	12.7	1,924.4	0.4	1.5	1	1	1
09/20/2014 16:00	0.5	13.0	1,869.7	0.4	1.6	1	1	1
09/20/2014 17:00	0.5	12.6	1,938.6	0.4	1.5	1	1	1
09/20/2014 18:00	0.5	12.6	1,951.9	0.4	1.6	1	1	1
09/20/2014 19:00	0.4	12.0	2,080.8	0.4	1.2	1	1	1
09/20/2014 20:00	0.4	12.9	1,890.5	0.3	1.2	1	1	1
09/20/2014 21:00	0.5	12.7	1,952.2	0.3	1.6	1	1	1
09/20/2014 22:00	0.4	13.1	1,861.4	0.3	1.3	1	1	1
09/20/2014 23:00	0.5	12.9	1,912.3	0.4	1.6	1	1	1
Average/Sum#:	0.5	12.7	1,945.8	0.4	34.9 #	24 #	24 #	24 #
Minimum:	0.3	11.7	1,854.0	0.3	0.9	1	1	1
Maximum:	0.5	13.2	2,173.8	0.4	1.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/21/2014 00:00	0.5	13.2	1,852.7	0.4	1.6	1	1	1
09/21/2014 01:00	0.5	13.2	1,851.5	0.4	1.6	1	1	1
09/21/2014 02:00	0.5	13.2	1,853.1	0.4	1.6	1	1	1
09/21/2014 03:00	0.5	13.2	1,851.6	0.4	1.6	1	1	1
09/21/2014 04:00	0.4	13.2	1,854.9	0.4	1.3	1	1	1
09/21/2014 05:00	0.4	13.2	1,853.6	0.3	1.3	1	1	1
09/21/2014 06:00	0.4	13.3	1,856.8	0.3	1.3	1	1	1
09/21/2014 07:00	0.4	13.2	1,860.5	0.3	1.3	1	1	1
09/21/2014 08:00	0.4	13.2	1,852.6	0.3	1.3	1	1	1
09/21/2014 09:00	0.4	13.2	1,849.1	0.3	1.3	1	1	1
09/21/2014 10:00	0.4	13.2	1,849.3	0.3	1.3	1	1	1
09/21/2014 11:00	0.4	13.2	1,726.8	0.3	1.2	1	1	1
09/21/2014 12:00	0.2	13.8	1,257.2	0.3	0.5	1	1	0
09/21/2014 13:00	0.2	13.9	1,248.9	0.2	0.5	1	1	0
09/21/2014 14:00	0.2	13.9	1,255.8	0.2	0.5	1	1	0
09/21/2014 15:00	0.2	13.9	1,267.5	0.2	0.5	1	1	0
09/21/2014 16:00	0.2	13.9	1,283.0	0.2	0.5	1	1	0
09/21/2014 17:00	0.3	13.5	1,707.2	0.2	0.9	1	1	1
09/21/2014 18:00	0.5	13.0	1,880.5	0.3	1.6	1	1	1
09/21/2014 19:00	0.5	12.8	1,937.6	0.3	1.6	1	1	1
09/21/2014 20:00	0.5	13.2	1,855.9	0.4	1.6	1	1	1
09/21/2014 21:00	0.5	13.2	1,855.0	0.4	1.6	1	1	1
09/21/2014 22:00	0.4	13.5	1,523.4	0.4	1.1	1	1	1
09/21/2014 23:00	0.2	13.8	1,249.0	0.3	0.5	1	1	0
Average/Sum#:	0.4	13.4	1,684.7	0.3	28.1 #	24 #	24 #	18 #
Minimum:	0.2	12.8	1,248.9	0.2	0.5	1	1	0
Maximum:	0.5	13.9	1,937.6	0.4	1.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/22/2014 00:00	0.2	13.8	1,249.5	0.2	0.5	1	1	0
09/22/2014 01:00	0.2	13.8	1,248.0	0.2	0.5	1	1	0
09/22/2014 02:00	0.2	13.8	1,275.3	0.2	0.5	1	1	0
09/22/2014 03:00	0.4	13.5	1,693.8	0.2	1.2	1	1	1
09/22/2014 04:00	0.5	13.2	1,865.1	0.3	1.6	1	1	1
09/22/2014 05:00	0.5	12.9	1,937.3	0.4	1.6	1	1	1
09/22/2014 06:00	0.5	12.3	2,047.8	0.4	1.6	1	1	1
09/22/2014 07:00	0.2	13.8	1,394.5	0.3	0.5	1	1	1
09/22/2014 08:00	0.2	13.8	1,279.9	0.2	0.5	1	1	0
09/22/2014 09:00	0.2	13.8	1,279.9	0.2	0.5	1	1	0
09/22/2014 10:00	0.2	13.9	1,293.0	0.2	0.5	1	1	0
09/22/2014 11:00	0.2	13.9	1,414.9	0.2	0.5	1	1	0
09/22/2014 12:00	0.2	13.7	1,718.4	0.2	0.6	1	1	0
09/22/2014 13:00	0.3	13.7	1,691.5	0.2	0.9	1	1	0
09/22/2014 14:00	0.3	13.6	1,733.9	0.2	0.9	1	1	0
09/22/2014 15:00	0.3	13.6	1,728.7	0.2	0.9	1	1	0
09/22/2014 16:00	0.3	13.6	1,727.2	0.2	0.9	1	1	0
09/22/2014 17:00	0.3	13.6	1,729.5	0.2	0.9	1	1	0
09/22/2014 18:00	0.3	13.6	1,735.4	0.2	0.9	1	1	0
09/22/2014 19:00	0.3	13.6	1,741.8	0.2	0.9	1	1	0
09/22/2014 20:00	0.3	13.6	1,734.6	0.2	0.9	1	1	0
09/22/2014 21:00	0.3	13.7	1,707.3	0.2	0.9	1	1	0
09/22/2014 22:00	0.3	13.8	1,544.3	0.2	0.9	1	1	0
09/22/2014 23:00	0.3	13.8	1,663.0	0.2	0.9	1	1	0
Average/Sum#:	0.3	13.6	1,601.4	0.2	20.5 #	24 #	24 #	5 #
Minimum:	0.2	12.3	1,248.0	0.2	0.5	1	1	0
Maximum:	0.5	13.9	2,047.8	0.4	1.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/23/2014 00:00	0.3	13.8	1,623.0	0.2	0.9	1	1	0
09/23/2014 01:00	0.3	13.9	1,587.7	0.2	0.9	1	1	0
09/23/2014 02:00	0.3	13.9	1,578.2	0.3	0.9	1	1	0
09/23/2014 03:00	0.3	13.8	1,683.8	0.3	0.9	1	1	0
09/23/2014 04:00	0.3	13.7	1,716.8	0.2	0.9	1	1	0
09/23/2014 05:00	0.3	13.7	1,719.4	0.2	0.9	1	1	0
09/23/2014 06:00	0.3	13.7	1,783.9	0.2	1.0	1	1	0
09/23/2014 07:00	0.2	13.7	1,679.9	0.2	0.6	1	1	0
09/23/2014 08:00	0.2	13.8	1,303.8	0.2	0.5	1	1	0
09/23/2014 09:00	0.0	0.0	1,288.0	0.0	0.0	1	1	0
09/23/2014 10:00	0.0	0.0	1,281.1	0.0	0.0	1	1	0
09/23/2014 11:00	0.0	0.0	1,467.5	0.0	0.0	1	1	0
09/23/2014 12:00	0.0	0.0	1,659.6	0.0	0.0	1	1	0
09/23/2014 13:00	0.3	13.7	1,648.3	0.0	0.9	1	1	0
09/23/2014 14:00	0.3	13.7	1,743.6	0.0	1.0	1	1	0
09/23/2014 15:00	0.3	13.7	1,743.3	0.2	1.0	1	1	0
09/23/2014 16:00	0.3	13.7	1,736.8	0.2	1.0	1	1	0
09/23/2014 17:00	0.3	13.6	1,737.3	0.2	0.9	1	1	0
09/23/2014 18:00	0.3	13.7	1,745.6	0.2	1.0	1	1	0
09/23/2014 19:00	0.3	13.7	1,749.0	0.2	1.0	1	1	0
09/23/2014 20:00	0.3	13.7	1,696.1	0.2	0.9	1	1	0
09/23/2014 21:00	0.3	13.6	1,753.1	0.2	1.0	1	1	0
09/23/2014 22:00	0.3	13.6	1,750.3	0.2	0.9	1	1	0
09/23/2014 23:00	0.3	13.6	1,757.2	0.2	1.0	1	1	0
Average/Sum#:	0.3	13.7	1,643.1	0.2	18.1 #	24 #	24 #	0 #
Minimum:	0.2	13.6	1,281.1	0.2	0.5	1	1	0
Maximum:	0.3	13.9	1,783.9	0.3	1.0	1	1	0
%SI	16.7	16.7	0.0	25.0	16.7	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/24/2014 00:00	0.3	13.6	1,765.1	0.2	1.0	1	1	0
09/24/2014 01:00	0.3	13.6	1,770.3	0.2	1.0	1	1	0
09/24/2014 02:00	0.2	13.6	1,768.2	0.2	0.6	1	1	0
09/24/2014 03:00	0.2	13.7	1,762.1	0.2	0.6	1	1	0
09/24/2014 04:00	0.2	13.6	1,746.4	0.2	0.6	1	1	0
09/24/2014 05:00	0.2	13.7	1,676.6	0.2	0.6	1	1	0
09/24/2014 06:00	0.2	13.6	1,780.5	0.2	0.6	1	1	0
09/24/2014 07:00	0.2	13.7	1,716.3	0.2	0.6	1	1	0
09/24/2014 08:00	0.2	13.8	1,596.2	0.2	0.6	1	1	0
09/24/2014 09:00	0.2	13.7	1,724.8	0.2	0.6	1	1	0
09/24/2014 10:00	0.2	13.6	1,753.2	0.2	0.6	1	1	0
09/24/2014 11:00	0.2	13.6	1,747.8	0.2	0.6	1	1	0
09/24/2014 12:00	0.2	13.6	1,742.3	0.2	0.6	1	1	0
09/24/2014 13:00	0.2	13.6	1,736.0	0.2	0.6	1	1	0
09/24/2014 14:00	0.2	13.7	1,733.3	0.2	0.6	1	1	0
09/24/2014 15:00	0.2	13.7	1,730.8	0.2	0.6	1	1	0
09/24/2014 16:00	0.2	13.7	1,730.9	0.2	0.6	1	1	0
09/24/2014 17:00	0.2	13.6	1,741.9	0.2	0.6	1	1	0
09/24/2014 18:00	0.2	13.6	1,751.2	0.2	0.6	1	1	0
09/24/2014 19:00	0.2	13.6	1,753.1	0.2	0.6	1	1	0
09/24/2014 20:00	0.2	13.6	1,762.2	0.2	0.6	1	1	0
09/24/2014 21:00	0.2	13.6	1,770.9	0.2	0.6	1	1	0
09/24/2014 22:00	0.2	13.6	1,773.3	0.2	0.6	1	1	0
09/24/2014 23:00	0.2	13.7	1,775.7	0.2	0.7	1	1	0
Average/Sum#:	0.2	13.6	1,742.0	0.2	15.3 #	24 #	24 #	0 #
Minimum:	0.2	13.6	1,596.2	0.2	0.6	1	1	0
Maximum:	0.3	13.8	1,780.5	0.2	1.0	1	1	0
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/25/2014 00:00	0.2	13.6	1,774.7	0.2	0.6	1	1	0
09/25/2014 01:00	0.2	13.6	1,776.5	0.2	0.6	1	1	0
09/25/2014 02:00	0.2	13.6	1,778.7	0.2	0.6	1	1	0
09/25/2014 03:00	0.2	13.7	1,736.1	0.2	0.6	1	1	0
09/25/2014 04:00	0.2	13.6	1,778.9	0.2	0.6	1	1	0
09/25/2014 05:00	0.2	13.7	1,741.1	0.2	0.6	1	1	0
09/25/2014 06:00	0.2	13.6	1,781.3	0.2	0.6	1	1	0
09/25/2014 07:00	0.2	13.7	1,759.3	0.2	0.6	1	1	0
09/25/2014 08:00	0.2	13.6	1,788.5	0.2	0.6	1	1	0
09/25/2014 09:00	0.2	13.7	1,772.0	0.2	0.7	1	1	0
09/25/2014 10:00	0.2	13.7	1,753.6	0.2	0.6	1	1	0
09/25/2014 11:00	0.2	13.6	1,774.8	0.2	0.6	1	1	0
09/25/2014 12:00	0.2	13.6	1,760.4	0.2	0.6	1	1	0
09/25/2014 13:00	0.6	12.4	2,064.9	0.3	1.9	1	1	1
09/25/2014 14:00	0.4	11.9	2,176.9	0.3	1.3	1	1	1
09/25/2014 15:00	0.2	11.6	2,219.4	0.3	0.6	1	1	1
09/25/2014 16:00	0.4	12.8	1,970.5	0.2	1.3	1	1	1
09/25/2014 17:00	0.4	12.5	2,050.8	0.2	1.3	1	1	1
09/25/2014 18:00	0.4	12.3	2,088.0	0.3	1.3	1	1	1
09/25/2014 19:00	0.3	12.2	2,100.8	0.3	1.0	1	1	1
09/25/2014 20:00	0.4	12.9	1,952.9	0.3	1.3	1	1	1
09/25/2014 21:00	0.3	13.0	1,923.5	0.2	1.0	1	1	1
09/25/2014 22:00	0.4	12.9	1,970.9	0.3	1.3	1	1	1
09/25/2014 23:00	0.4	12.4	2,087.8	0.3	1.3	1	1	1
Average/Sum#:	0.3	13.1	1,899.3	0.2	21.5 #	24 #	24 #	11 #
Minimum:	0.2	11.6	1,736.1	0.2	0.6	1	1	0
Maximum:	0.6	13.7	2,219.4	0.3	1.9	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/26/2014 00:00	0.4	12.9	1,978.9	0.3	1.3	1	1	1
09/26/2014 01:00	0.4	12.9	1,991.5	0.3	1.3	1	1	1
09/26/2014 02:00	0.3	13.1	1,931.9	0.3	1.0	1	1	1
09/26/2014 03:00	0.4	13.0	1,959.3	0.3	1.3	1	1	1
09/26/2014 04:00	0.3	11.9	2,212.8	0.2	1.0	1	1	1
09/26/2014 05:00	0.3	11.8	2,237.1	0.2	1.0	1	1	1
09/26/2014 06:00	0.2	11.8	2,254.1	0.2	0.7	1	1	1
09/26/2014 07:00	0.3	12.4	2,091.7	0.2	1.0	1	1	1
09/26/2014 08:00	0.3	13.2	1,894.7	0.2	1.0	1	1	1
09/26/2014 09:00	0.4	12.7	2,020.3	0.2	1.3	1	1	1
09/26/2014 10:00	0.4	12.6	2,048.9	0.3	1.3	1	1	1
09/26/2014 11:00	0.4	12.8	1,995.9	0.3	1.3	1	1	1
09/26/2014 12:00	0.3	13.1	1,903.8	0.3	1.0	1	1	1
09/26/2014 13:00	0.3	13.3	1,874.7	0.2	1.0	1	1	1
09/26/2014 14:00	0.3	13.3	1,878.7	0.2	1.0	1	1	1
09/26/2014 15:00	0.3	13.3	1,871.7	0.2	1.0	1	1	1
09/26/2014 16:00	0.4	13.3	1,874.3	0.2	1.3	1	1	1
09/26/2014 17:00	0.4	13.0	1,943.6	0.3	1.3	1	1	1
09/26/2014 18:00	0.4	13.1	1,916.6	0.3	1.3	1	1	1
09/26/2014 19:00	0.4	13.3	1,880.3	0.3	1.3	1	1	1
09/26/2014 20:00	0.4	13.3	1,882.9	0.3	1.3	1	1	1
09/26/2014 21:00	0.4	13.0	1,939.6	0.3	1.3	1	1	1
09/26/2014 22:00	0.4	13.2	1,906.3	0.3	1.3	1	1	1
09/26/2014 23:00	0.4	12.6	2,050.1	0.3	1.3	1	1	1
Average/Sum#:	0.4	12.9	1,980.8	0.3	27.9 #	24 #	24 #	24 #
Minimum:	0.2	11.8	1,871.7	0.2	0.7	1	1	1
Maximum:	0.4	13.3	2,254.1	0.3	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/27/2014 00:00	0.4	12.4	2,081.7	0.3	1.3	1	1	1
09/27/2014 01:00	0.3	12.1	2,156.4	0.3	1.0	1	1	1
09/27/2014 02:00	0.4	12.9	1,983.3	0.3	1.3	1	1	1
09/27/2014 03:00	0.4	13.0	1,936.8	0.3	1.3	1	1	1
09/27/2014 04:00	0.3	13.2	1,907.4	0.3	1.0	1	1	1
09/27/2014 05:00	0.4	13.1	1,933.0	0.3	1.3	1	1	1
09/27/2014 06:00	0.4	13.1	1,927.7	0.3	1.3	1	1	1
09/27/2014 07:00	0.2	13.5	1,600.0	0.3	0.6	1	1	1
09/27/2014 08:00	0.1	13.8	1,274.4	0.2	0.2	1	1	0
09/27/2014 09:00	0.1	13.8	1,350.2	0.1	0.3	1	1	0
09/27/2014 10:00	0.1	13.9	1,287.6	0.1	0.2	1	1	0
09/27/2014 11:00	0.1	13.9	1,260.9	0.1	0.2	1	1	0
09/27/2014 12:00	0.1	13.9	1,258.7	0.1	0.2	1	1	0
09/27/2014 13:00	0.1	13.9	1,258.7	0.1	0.2	1	1	0
09/27/2014 14:00	0.1	13.9	1,259.5	0.1	0.2	1	1	0
09/27/2014 15:00	0.1	13.9	1,257.4	0.1	0.2	1	1	0
09/27/2014 16:00	0.1	13.9	1,253.6	0.1	0.2	1	1	0
09/27/2014 17:00	0.3	13.5	1,620.3	0.1	0.9	1	1	1
09/27/2014 18:00	0.4	11.8	2,198.6	0.2	1.3	1	1	1
09/27/2014 19:00	0.4	12.7	1,977.7	0.3	1.3	1	1	1
09/27/2014 20:00	0.4	13.0	1,910.9	0.3	1.3	1	1	1
09/27/2014 21:00	0.4	12.8	1,969.5	0.3	1.3	1	1	1
09/27/2014 22:00	0.3	13.3	1,856.7	0.3	1.0	1	1	1
09/27/2014 23:00	0.4	13.2	1,884.5	0.3	1.3	1	1	1
Average/Sum#:	0.3	13.3	1,683.6	0.2	19.4 #	24 #	24 #	15 #
Minimum:	0.1	11.8	1,253.6	0.1	0.2	1	1	0
Maximum:	0.4	13.9	2,198.6	0.3	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/28/2014 00:00	0.2	13.5	1,464.0	0.2	0.5	1	1	1
09/28/2014 01:00	0.1	13.9	1,256.6	0.2	0.2	1	1	0
09/28/2014 02:00	0.1	13.9	1,256.2	0.1	0.2	1	1	0
09/28/2014 03:00	0.2	13.9	1,520.4	0.1	0.6	1	1	0
09/28/2014 04:00	0.4	13.3	1,839.8	0.2	1.3	1	1	1
09/28/2014 05:00	0.5	12.7	2,003.5	0.3	1.6	1	1	1
09/28/2014 06:00	0.5	12.6	2,027.7	0.4	1.6	1	1	1
09/28/2014 07:00	0.4	13.2	1,883.3	0.4	1.3	1	1	1
09/28/2014 08:00	0.4	13.1	1,904.5	0.3	1.3	1	1	1
09/28/2014 09:00	0.2	13.8	1,312.3	0.3	0.5	1	1	1
09/28/2014 10:00	0.2	13.8	1,257.5	0.2	0.5	1	1	0
09/28/2014 11:00	0.3	13.6	1,549.2	0.2	0.8	1	1	1
09/28/2014 12:00	0.4	13.3	1,867.7	0.2	1.3	1	1	1
09/28/2014 13:00	0.4	13.2	1,866.3	0.3	1.3	1	1	1
09/28/2014 14:00	0.4	13.3	1,866.2	0.3	1.3	1	1	1
09/28/2014 15:00	0.4	13.3	1,866.7	0.3	1.3	1	1	1
09/28/2014 16:00	0.4	12.9	1,953.9	0.3	1.3	1	1	1
09/28/2014 17:00	0.4	12.3	2,092.7	0.3	1.3	1	1	1
09/28/2014 18:00	0.3	11.5	2,276.5	0.3	1.0	1	1	1
09/28/2014 19:00	0.2	11.4	2,285.0	0.2	0.6	1	1	1
09/28/2014 20:00	0.4	12.6	2,018.6	0.2	1.3	1	1	1
09/28/2014 21:00	0.4	12.9	1,966.0	0.2	1.3	1	1	1
09/28/2014 22:00	0.4	12.9	1,954.5	0.3	1.3	1	1	1
09/28/2014 23:00	0.4	13.3	1,865.2	0.3	1.3	1	1	1
Average/Sum#:	0.3	13.1	1,798.1	0.3	25.0 #	24 #	24 #	20 #
Minimum:	0.1	11.4	1,256.2	0.1	0.2	1	1	0
Maximum:	0.5	13.9	2,285.0	0.4	1.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/29/2014 00:00	0.5	13.4	1,842.9	0.3	1.6	1	1	1
09/29/2014 01:00	0.5	13.5	1,841.4	0.4	1.6	1	1	1
09/29/2014 02:00	0.5	13.5	1,842.2	0.4	1.6	1	1	1
09/29/2014 03:00	0.5	13.5	1,842.2	0.4	1.6	1	1	1
09/29/2014 04:00	0.4	13.3	1,869.2	0.4	1.3	1	1	1
09/29/2014 05:00	0.4	13.2	1,883.5	0.3	1.3	1	1	1
09/29/2014 06:00	0.5	12.7	2,018.6	0.3	1.6	1	1	1
09/29/2014 07:00	0.4	13.2	1,866.3	0.3	1.3	1	1	1
09/29/2014 08:00	0.4	13.2	1,866.1	0.3	1.3	1	1	1
09/29/2014 09:00	0.4	13.2	1,874.7	0.3	1.3	1	1	1
09/29/2014 10:00	0.4	13.2	1,882.6	0.3	1.3	1	1	1
09/29/2014 11:00	0.4	13.2	1,879.4	0.3	1.3	1	1	1
09/29/2014 12:00	0.2	13.8	1,289.0	0.3	0.5	1	1	0
09/29/2014 13:00	0.2	13.9	1,257.8	0.2	0.5	1	1	0
09/29/2014 14:00	0.3	13.6	1,528.8	0.2	0.8	1	1	1
09/29/2014 15:00	0.4	13.2	1,869.4	0.2	1.3	1	1	1
09/29/2014 16:00	0.4	13.0	1,919.4	0.3	1.3	1	1	1
09/29/2014 17:00	0.5	12.6	2,003.4	0.3	1.6	1	1	1
09/29/2014 18:00	0.4	11.8	2,179.1	0.3	1.3	1	1	1
09/29/2014 19:00	0.3	12.0	2,140.4	0.3	1.0	1	1	1
09/29/2014 20:00	0.4	12.8	1,948.4	0.3	1.3	1	1	1
09/29/2014 21:00	0.3	13.3	1,725.5	0.2	0.9	1	1	1
09/29/2014 22:00	0.1	13.8	1,269.7	0.2	0.2	1	1	0
09/29/2014 23:00	0.2	13.8	1,302.7	0.2	0.5	1	1	0
Average/Sum#:	0.4	13.2	1,789.3	0.3	28.3 #	24 #	24 #	20 #
Minimum:	0.1	11.8	1,257.8	0.2	0.2	1	1	0
Maximum:	0.5	13.9	2,179.1	0.4	1.6	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT2 - CO

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:27 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:				> Limit	> Limit			
	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2	Unit CT2
	CO, Ppm	O2, Dry, Pct	HI, MBtuPerHr	CO, _3Hr, Ppmvdc	CO, Lb	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/30/2014 00:00	0.2	13.8	1,258.2	0.2	0.5	1	1	0
09/30/2014 01:00	0.2	13.8	1,259.2	0.2	0.5	1	1	0
09/30/2014 02:00	0.2	13.8	1,259.5	0.2	0.5	1	1	0
09/30/2014 03:00	0.2	13.8	1,260.2	0.2	0.5	1	1	0
09/30/2014 04:00	0.2	13.8	1,380.0	0.2	0.5	1	1	0
09/30/2014 05:00	0.4	13.4	1,650.0	0.2	1.2	1	1	1
09/30/2014 06:00	0.4	13.2	1,898.7	0.3	1.3	1	1	1
09/30/2014 07:00	0.4	13.2	1,872.1	0.3	1.3	1	1	1
09/30/2014 08:00	0.4	13.2	1,873.0	0.3	1.3	1	1	1
09/30/2014 09:00	0.4	13.2	1,869.8	0.3	1.3	1	1	1
09/30/2014 10:00	0.1	13.8	1,260.8	0.2	0.2	1	1	0
09/30/2014 11:00	0.1	13.9	1,257.9	0.2	0.2	1	1	0
09/30/2014 12:00	0.3	13.6	1,635.9	0.1	0.9	1	1	1
09/30/2014 13:00	0.4	13.2	1,869.1	0.2	1.3	1	1	1
09/30/2014 14:00	0.4	13.2	1,871.6	0.3	1.3	1	1	1
09/30/2014 15:00	0.4	13.2	1,876.2	0.3	1.3	1	1	1
09/30/2014 16:00	0.4	13.1	1,891.4	0.3	1.3	1	1	1
09/30/2014 17:00	0.4	13.2	1,881.3	0.3	1.3	1	1	1
09/30/2014 18:00	0.4	12.6	2,035.9	0.3	1.3	1	1	1
09/30/2014 19:00	0.3	12.2	2,110.5	0.3	1.0	1	1	1
09/30/2014 20:00	0.4	13.3	1,872.6	0.3	1.3	1	1	1
09/30/2014 21:00	0.3	13.7	1,470.8	0.2	0.8	1	1	1
09/30/2014 22:00	0.1	13.9	1,262.4	0.2	0.2	1	1	0
09/30/2014 23:00	0.1	13.9	1,261.3	0.1	0.2	1	1	0
Average/Sum#:	0.3	13.4	1,630.8	0.2	21.5 #	24 #	24 #	15 #
Minimum:	0.1	12.2	1,257.9	0.1	0.2	1	1	0
Maximum:	0.4	13.9	2,110.5	0.3	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0.0	0	0	0

ATTACHMENT 8
Hourly Emissions NH_3 (AQ-18)

AQ-18

Pursuant to the CEC conditions of certification, AQ-18 requires that a calculation be developed to determine the ammonia slip emissions, using source test data, based on NOx concentration and Ammonia Injection Rate. AQ-18 reads as follows:

AQ-18 Ammonia slip shall be limited to 5.0 ppmvd @ 15% O_2 over one hour. Formaldehyde emissions will be limited to 0.917 lbs per million standard cubic feet (MMscf) of natural gas. Maximum hourly steady state emission limits for each CTG are:

Pounds NH_3 with Duct Firing Pounds: 19.2

NH_3 without Duct Firing: 14.2

Verification: The project owner shall submit to the CPM and APCO CTG emissions data demonstrating compliance with this condition as part of the Quarterly Operation Reports (AQ-22). The project owner shall provide approval of the CPM and APCO a calculation method to determine the ammonia slip emissions, using source test data, based on the NO_x concentration and the ammonia injection rate; and this calculation shall be revised for approval as necessary after each source test performed under AQ-9.

<u>Calculation</u>

The Calculation used is the standard calculation for determining slip. The constant was updated using 2013 Source Test Data. The correction calculations is attached.

(((NH3Inj_LbPerHr_1H/MoleWtNH3_constant)/(ExhaustFlow_LbPerHr_1H/MoleWtExhaustGas const*1000000)-(NOxInlet_Ppmvdc_1H-NOx_Ppmvdc_1J))*NH3 Correction Constant

Correction Constant

CT1 - .0190

CT2 - .0192

Ammonia Correction Constant Calculations Yellow cells are user input values. **Page 1**

Site ID: PG&E Colusa GS

Unit ID:		1	1	1	2	2	2	1	1	1	2	2	2
Load Condition:		Min Load	Min Load	Min Load	Min Load	Min Load	Min Load	Mid Load	Mid Load	Mid Load	Mid Load	Mid Load	Mid Load
Test Date:		10/29/2013	10/29/2013	10/29/2013	11/1/2013	11/1/2013	11/1/2013	10/29/2013	10/29/2013	10/29/2013	11/1/2013	11/1/2013	11/1/2013
Test Duration, minutes:		36	30	30	30	30	30	30	30	30	30	30	30
NH3 Conc, ppm volume dry:		1.54	1.52	1.47	0.96	0.81	0.78	1.63	1.47	1.42	1.32	1.29	1.27
Stack flow rate, dscfm:		559798	553601	551494	533159	534379	532958	622349	618408	618456	617746	619924	620534
NH3 MW:		17.01	17.01	17.01	17.01	17.01	17.01	17.01	17.01	17.01	17.01	17.01	17.01
Agency STP ft^3/lb-mol (see Tab):		385.3	385.3	385.3	385.3	385.3	385.3	385.3	385.3	385.3	385.3	385.3	385.3
NH3 Conc, ppm at 15% O2:		1.31	1.27	1.24	0.82	0.69	0.67	1.37	1.23	1.19	1.12	1.1	1.09
Calculated NH3 slip, lbs/hr:		*2.28*	*2.23*	*2.15*	*1.36*	*1.15*	*1.10*	*2.69*	*2.41*	*2.33*	*2.16*	*2.12*	*2.09*
Fuel Flow, scf/hr:		1249960	1257590	1251020	1192200	1194930	1190030	1413760	1402810	1402920	1385340	1382210	1383570
Btu/scf: (avg all tests)		1020	1020	1020	1020	1020	1020	1020	1020	1020	1020	1020	1020
Calculated MMBTU/Hr:		1274.96	1282.74	1276.04	1216.04	1218.83	1213.83	1442.04	1430.87	1430.98	1413.05	1409.85	1411.24
Calculated MMSCF/Hr:		1.23	1.23	1.23	1.17	1.17	1.17	1.39	1.38	1.38	1.36	1.36	1.36
NH3 Injection Rate, lbs/hr:		98.6	101.8	102.8	77.5	79.5	80.4	102.2	101.7	102.2	84.8	84.2	84.2
Stack Temp, deg F:		196	196	196	196	196	196	196	196	196	196	196	196
Approx Exhaust Density, lb/ft3: (see Tab):		0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062
Exhaust flow rate dry, lbs/hr:		2082448.6	2059395.7	2051557.7	1983351.5	1987889.9	1982603.8	2315138.3	2300477.8	2300656.3	2298015.1	2306117.3	2308386.5
Inlet Nox, ppm at 15% O2:		9.6	9.5	9.5	8.4	8.4	8.3	8.8	8.7	8.7	7.1	7.4	8.7
Outlet Nox, ppm at 15% O2:		1.1	1.1	1.1	0.8	0.8	0.7	1.1	1.1	1.1	0.6	0.7	1.1
calc 1	a = (NH3 Inj/NH3 MW)	5.80	5.98	6.04	4.56	4.67	4.72	6.01	5.98	6.01	4.98	4.95	4.95
calc 2	b = (Exhaust Flow Rate/29)	71808.57	71013.65	70743.37	68391.43	68547.93	68365.65	79832.35	79326.82	79332.98	79241.90	79521.29	79599.53
calc 3	c = (Nox Inlet - Nox Outlet)\	8.54	8.47	8.43	7.56	7.63	7.59	7.70	7.65	7.66	6.47	6.68	7.66
Calculated NH3 slip, ppm @ 15% O2:	(((a/b)*1000000)-c)	72.17	75.76	77.02	59.09	60.51	61.51	67.54	67.75	68.06	56.43	55.56	54.49
Correction Constant, d:	NH3 Conc/Calculated NH3	0.0182	0.0168	0.0161	0.0139	0.0114	0.0109	0.0203	0.0182	0.0175	0.0198	0.0198	0.0200

Avg Correction Constant:

Unit 1-Min	**0.0170**
Unit 1-Mid	**0.0186**
Unit 1-Base	**0.0245**
Unit 1-Max	**0.0159**
Unit 2-Min	**0.0121**
Unit 2-Mid	**0.0199**
Unit 2-Base	**0.0311**
Unit 2-Max	**0.0138**

Correction Constants (all loads-tested)

Unit 1	**0.0190**
Unit 2	**0.0192**

The equations for all values in **RED** must be revised each year depending upon the number of loads tested and number of tests per load.

1/27/2014 16:18

1	1	1	2	2	2	1	1	1	2	2	2
Base wo DB	Base wo DB	Base wo DB	Base wo DB	Base wo DB	Base wo DB	Max w DB	Max w DB	Max w DB	Max w DB	Max w DB	Max w DB
10/29/2013	10/29/2013	10/29/2013	11/1/2013	11/1/2013	11/12013	10/30/2013	10/30/2013	10/30/2013	11/1/2013	11/1/2013	11/1/2013
32	30	30	30	30	30	30	30	30	30	30	30
2.05	1.98	2	2.57	2.18	1.77	2.39	2.91	3.2	1.88	1.88	1.9
779044	755972	752689	759979	758400	756272	730310	724782	721431	753523	753227	756446
17.01	17.01	17.01	17.01	17.01	17.01	17.01	17.01	17.01	17.01	17.01	17.01
385.3	385.3	385.3	385.3	385.3	385.3	385.3	385.3	385.3	385.3	385.3	385.3
1.72	1.62	1.64	2.12	1.8	1.46	1.52	1.85	2.04	1.24	1.24	1.26
4.23	*3.96*	*3.99*	*5.17*	*4.38*	*3.55*	*4.62*	*5.59*	*6.12*	*3.75*	*3.75*	*3.81*
1767200	1763720	1756060	1760790	1757130	1752200	2182910	2171070	2158700	2176810	2178390	2170590
1020	1020	1020	1020	1020	1020	1020	1020	1020	1020	1020	1020
1802.54	1798.99	1791.18	1796.01	1792.27	1787.24	2226.57	2214.49	2201.87	2220.35	2221.96	2214.00
1.73	1.73	1.72	1.73	1.72	1.72	2.14	2.13	2.12	2.13	2.14	2.13
124.6	124.4	123.9	106.9	105.9	105.6	189.0	188.6	193.5	164.6	162.8	155.7
196	196	196	196	196	196	170	170	170	170	170	170
0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062	0.062
2898043.7	2812215.8	2800003.1	2827121.9	2821248.0	2813331.8	2716753.2	2696189.0	2683723.3	2803105.6	2802004.4	2813979.1
8.0	7.9	7.9	7.4	7.4	7.4	8.1	8.1	8.2	8.3	8.3	8.1
1.1	1.1	1.1	0.9	0.9	1.0	1.0	1.0	1.0	1.1	1.1	1.1
7.33	7.32	7.29	6.28	6.23	6.21	11.11	11.09	11.38	9.68	9.57	9.15
99932.54	96972.96	96551.83	97486.96	97284.41	97011.44	93681.14	92972.04	92542.18	96658.81	96620.84	97033.76
6.91	6.84	6.81	6.50	6.47	6.38	7.08	7.05	7.18	7.16	7.17	6.99
66.40	68.60	68.64	57.94	57.54	57.59	111.56	112.22	115.76	92.95	91.90	87.33
0.0259	0.0236	0.0239	0.0366	0.0313	0.0254	0.0136	0.0165	0.0176	0.0133	0.0135	0.0144

Reference: all input data derived from "Colusa Generating Station-2012 Source Test Report, December 10, 2012", Avogadro.
Supplemental data derived from CEMS data for the specified test dates and times for each unit tested.

Excess Emission Report

CT1 - NH3 LbPerHr 1-Hour Block Average

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:03 **Location:** Maxwell, CA

Tag Name: CT1_NH3slip_LbPerHr_1H
Total Operating Time: 1,558.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 650.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,558.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

CT1 - NH3 Ppmvdc 1-Hour Block Average

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:04 **Location:** Maxwell, CA

Tag Name: CT1_NH3Slip_Ppmvdc_1H
Total Operating Time: 1,558.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 650.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,558.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

CT2 - NH3 LbPerHr 1-Hour Block Average

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:04 **Location:** Maxwell, CA

Tag Name: CT2_NH3slip_LbPerHr_1H
Total Operating Time: 1,577.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 631.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,577.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

CT2 - NH3 Ppmvdc 1-Hour Block Average

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:04 **Location:** Maxwell, CA

Tag Name: CT2_NH3Slip_Ppmvdc_1H
Total Operating Time: 1,577.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 631.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,577.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Daily Summary Report

CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/01/2014 00:00	13.1	1,831.5	1.0	0.7	1	1	1
07/01/2014 01:00	13.5	1,573.7	1.1	0.6	1	1	1
07/01/2014 02:00	13.4	1,558.2	1.1	0.6	1	1	1
07/01/2014 03:00	13.7	1,241.5	1.2	0.6	1	1	0
07/01/2014 04:00	13.7	1,282.1	1.1	0.5	1	1	0
07/01/2014 05:00	13.4	1,556.7	1.1	0.6	1	1	1
07/01/2014 06:00	13.0	1,889.6	1.1	0.8	1	1	1
07/01/2014 07:00	13.0	1,879.9	1.0	0.8	1	1	1
07/01/2014 08:00	12.9	1,906.6	1.1	0.8	1	1	1
07/01/2014 09:00	12.8	1,916.8	1.1	0.8	1	1	1
07/01/2014 10:00	12.9	1,874.0	1.1	0.7	1	1	1
07/01/2014 11:00	13.0	1,842.0	1.1	0.7	1	1	1
07/01/2014 12:00	13.0	1,870.3	1.1	0.7	1	1	1
07/01/2014 13:00	12.8	1,887.0	1.1	0.8	1	1	1
07/01/2014 14:00	12.8	1,894.5	1.1	0.8	1	1	1
07/01/2014 15:00	12.7	1,896.5	1.1	0.8	1	1	1
07/01/2014 16:00	12.1	2,019.6	1.3	1.0	1	1	1
07/01/2014 17:00	11.6	2,122.6	1.4	1.1	1	1	1
07/01/2014 18:00	11.7	2,106.2	1.3	1.1	1	1	1
07/01/2014 19:00	12.9	1,871.4	1.1	0.7	1	1	1
07/01/2014 20:00	13.0	1,859.7	1.1	0.7	1	1	1
07/01/2014 21:00	13.1	1,843.1	1.0	0.7	1	1	1
07/01/2014 22:00	13.2	1,840.7	1.0	0.7	1	1	1
07/01/2014 23:00	13.3	1,840.6	1.0	0.7	1	1	1
Average/Sum#:	12.9	1,808.5	1.1	0.8	24 #	24 #	22 #
Minimum:	11.6	1,241.5	1.0	0.5	1	1	0
Maximum:	13.7	2,122.6	1.4	1.1	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/02/2014 00:00	13.3	1,841.4	1.0	0.7	1	1	1
07/02/2014 01:00	13.3	1,842.9	1.0	0.7	1	1	1
07/02/2014 02:00	13.3	1,842.6	1.0	0.7	1	1	1
07/02/2014 03:00	13.3	1,842.4	1.0	0.7	1	1	1
07/02/2014 04:00	13.1	1,910.0	1.1	0.8	1	1	1
07/02/2014 05:00	12.4	2,058.3	1.2	1.0	1	1	1
07/02/2014 06:00	12.6	1,983.1	1.2	1.0	1	1	1
07/02/2014 07:00	13.2	1,866.3	1.0	0.7	1	1	1
07/02/2014 08:00	13.2	1,872.5	1.0	0.7	1	1	1
07/02/2014 09:00	13.2	1,872.9	1.0	0.7	1	1	1
07/02/2014 10:00	13.1	1,870.0	1.0	0.7	1	1	1
07/02/2014 11:00	13.0	1,874.7	1.1	0.7	1	1	1
07/02/2014 12:00	13.0	1,881.2	1.1	0.8	1	1	1
07/02/2014 13:00	12.9	1,884.7	1.1	0.8	1	1	1
07/02/2014 14:00	12.3	2,011.4	1.2	1.0	1	1	1
07/02/2014 15:00	11.6	2,122.1	1.4	1.1	1	1	1
07/02/2014 16:00	12.2	2,007.8	1.2	1.0	1	1	1
07/02/2014 17:00	12.5	1,957.3	1.2	1.0	1	1	1
07/02/2014 18:00	12.4	1,970.7	1.2	1.0	1	1	1
07/02/2014 19:00	12.6	1,949.3	1.1	0.8	1	1	1
07/02/2014 20:00	12.6	1,944.8	1.1	0.8	1	1	1
07/02/2014 21:00	13.7	1,322.6	1.2	0.7	1	1	1
07/02/2014 22:00	16.3	366.1	7.6	1.1	1	0	0
07/02/2014 23:00	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	13.0	1,830.2	1.4	0.8	23 #	22 #	22 #
Minimum:	11.6	366.1	1.0	0.7	0	0	0
Maximum:	16.3	2,122.1	7.6	1.1	1	1	1
%SI	4.2	4.2	4.2	4.2	0	0	0

Daily Summary Report

CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/03/2014 00:00	0.0	0.0	0.0	0.0	0	0	0
07/03/2014 01:00	0.0	0.0	0.0	0.0	0	0	0
07/03/2014 02:00	0.0	0.0	0.0	0.0	0	0	0
07/03/2014 03:00	16.6	578.4	3.9	0.9	1	0	0
07/03/2014 04:00	13.8	1,503.3	1.6	0.9	1	0	0
07/03/2014 05:00	13.6	1,790.3	1.0	0.7	1	1	0
07/03/2014 06:00	13.6	1,780.8	1.0	0.7	1	1	0
07/03/2014 07:00	13.7	1,728.7	1.0	0.7	1	1	0
07/03/2014 08:00	13.7	1,581.8	1.1	0.6	1	1	1
07/03/2014 09:00	13.0	1,889.0	1.1	0.8	1	1	1
07/03/2014 10:00	13.0	1,884.1	1.1	0.8	1	1	1
07/03/2014 11:00	12.9	1,906.6	1.1	0.8	1	1	1
07/03/2014 12:00	12.5	1,969.1	1.2	1.0	1	1	1
07/03/2014 13:00	11.8	2,105.3	1.3	1.1	1	1	1
07/03/2014 14:00	11.6	2,129.2	1.4	1.1	1	1	1
07/03/2014 15:00	11.5	2,135.6	1.4	1.1	1	1	1
07/03/2014 16:00	11.5	2,139.6	1.4	1.1	1	1	1
07/03/2014 17:00	11.5	2,143.4	1.4	1.1	1	1	1
07/03/2014 18:00	11.3	2,175.3	1.4	1.1	1	1	1
07/03/2014 19:00	11.3	2,169.3	1.4	1.1	1	1	1
07/03/2014 20:00	12.0	2,048.3	1.3	1.0	1	1	1
07/03/2014 21:00	12.4	1,980.0	1.2	1.0	1	1	1
07/03/2014 22:00	12.3	2,017.9	1.2	1.0	1	1	1
07/03/2014 23:00	11.4	2,203.2	1.4	1.1	1	1	1
Average/Sum#:	12.6	1,898.1	1.4	0.9	21 #	19 #	16 #
Minimum:	11.3	578.4	1.0	0.6	0	0	0
Maximum:	16.6	2,203.2	3.9	1.1	1	1	1
%SI	12.5	12.5	12.5	12.5	0	0	0

Daily Summary Report

CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/04/2014 00:00	12.5	1,994.4	1.2	1.0	1	1	1
07/04/2014 01:00	12.8	1,954.7	1.1	0.8	1	1	1
07/04/2014 02:00	13.1	1,880.8	1.0	0.8	1	1	1
07/04/2014 03:00	13.3	1,841.4	1.0	0.7	1	1	1
07/04/2014 04:00	13.1	1,887.2	1.0	0.8	1	1	1
07/04/2014 05:00	13.2	1,874.0	1.0	0.7	1	1	1
07/04/2014 06:00	13.2	1,873.9	1.0	0.7	1	1	1
07/04/2014 07:00	13.2	1,871.3	1.0	0.7	1	1	1
07/04/2014 08:00	12.9	1,936.2	1.1	0.8	1	1	1
07/04/2014 09:00	12.8	1,945.0	1.1	0.8	1	1	1
07/04/2014 10:00	12.6	1,983.2	1.1	0.8	1	1	1
07/04/2014 11:00	11.3	2,211.8	1.4	1.1	1	1	1
07/04/2014 12:00	11.9	2,084.9	1.3	1.0	1	1	1
07/04/2014 13:00	12.7	1,924.4	1.1	0.8	1	1	1
07/04/2014 14:00	12.7	1,928.0	1.1	0.8	1	1	1
07/04/2014 15:00	12.6	1,932.2	1.1	0.8	1	1	1
07/04/2014 16:00	12.5	1,960.6	1.2	1.0	1	1	1
07/04/2014 17:00	12.5	1,964.6	1.2	1.0	1	1	1
07/04/2014 18:00	13.6	1,475.5	1.1	0.6	1	1	1
07/04/2014 19:00	14.0	1,281.6	1.1	0.5	1	1	0
07/04/2014 20:00	16.5	345.3	7.4	1.0	1	0	0
07/04/2014 21:00	0.0	0.0	0.0	0.0	0	0	0
07/04/2014 22:00	0.0	0.0	0.0	0.0	0	0	0
07/04/2014 23:00	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	13.0	1,816.7	1.4	0.8	21 #	20 #	19 #
Minimum:	11.3	345.3	1.0	0.5	0	0	0
Maximum:	16.5	2,211.8	7.4	1.1	1	1	1
%SI	12.5	12.5	12.5	12.5	0	0	0

Daily Summary Report

CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/05/2014 00:00	0.0	0.0	0.0	0.0	0	0	0
07/05/2014 01:00	0.0	0.0	0.0	0.0	0	0	0
07/05/2014 02:00	0.0	0.0	0.0	0.0	0	0	0
07/05/2014 03:00	0.0	0.0	0.0	0.0	0	0	0
07/05/2014 04:00	0.0	0.0	0.0	0.0	0	0	0
07/05/2014 05:00	0.0	0.0	0.0	0.0	0	0	0
07/05/2014 06:00	17.2	498.8	0.0	0.0	1	0	0
07/05/2014 07:00	15.2	838.3	3.8	1.3	1	0	0
07/05/2014 08:00	13.8	1,490.7	1.3	0.7	1	1	0
07/05/2014 09:00	13.8	1,775.1	1.0	0.7	1	1	0
07/05/2014 10:00	13.7	1,750.1	1.0	0.7	1	1	0
07/05/2014 11:00	13.8	1,498.2	1.1	0.6	1	1	0
07/05/2014 12:00	12.7	1,959.9	1.1	0.8	1	1	1
07/05/2014 13:00	12.1	2,084.0	1.2	1.0	1	1	1
07/05/2014 14:00	12.8	1,920.1	1.1	0.8	1	1	1
07/05/2014 15:00	12.8	1,900.0	1.1	0.8	1	1	1
07/05/2014 16:00	12.6	1,927.2	1.1	0.8	1	1	1
07/05/2014 17:00	12.5	1,970.8	1.2	1.0	1	1	1
07/05/2014 18:00	12.7	1,930.5	1.1	0.8	1	1	1
07/05/2014 19:00	13.0	1,870.7	1.1	0.7	1	1	1
07/05/2014 20:00	13.1	1,866.3	1.0	0.7	1	1	1
07/05/2014 21:00	13.1	1,860.0	1.0	0.7	1	1	1
07/05/2014 22:00	13.6	1,548.7	1.1	0.6	1	1	1
07/05/2014 23:00	13.6	1,767.9	1.0	0.7	1	1	0
Average/Sum#:	13.5	1,692.1	1.2	0.7	18 #	16 #	11 #
Minimum:	12.1	498.8	0.0	0.0	0	0	0
Maximum:	17.2	2,084.0	3.8	1.3	1	1	1
%SI	25.0	25.0	25.0	25.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/06/2014 00:00	13.6	1,775.9	1.0	0.7	1	1	0
07/06/2014 01:00	13.7	1,484.5	1.1	0.6	1	1	0
07/06/2014 02:00	16.7	308.3	7.7	0.9	1	0	0
07/06/2014 03:00	0.0	0.0	0.0	0.0	0	0	0
07/06/2014 04:00	0.0	0.0	0.0	0.0	0	0	0
07/06/2014 05:00	17.5	458.8	2.4	0.4	1	0	0
07/06/2014 06:00	14.7	1,073.8	2.5	1.1	1	0	0
07/06/2014 07:00	13.7	1,767.2	1.0	0.7	1	1	0
07/06/2014 08:00	13.8	1,610.0	1.0	0.6	1	1	0
07/06/2014 09:00	13.9	1,692.7	1.0	0.7	1	1	0
07/06/2014 10:00	13.9	1,436.1	1.1	0.6	1	1	0
07/06/2014 11:00	13.3	1,749.7	1.1	0.7	1	1	1
07/06/2014 12:00	12.9	1,897.0	1.1	0.8	1	1	1
07/06/2014 13:00	13.0	1,865.2	1.1	0.7	1	1	1
07/06/2014 14:00	13.1	1,861.0	1.1	0.7	1	1	1
07/06/2014 15:00	13.0	1,857.2	1.1	0.7	1	1	1
07/06/2014 16:00	12.8	1,897.6	1.1	0.8	1	1	1
07/06/2014 17:00	12.2	2,040.0	1.2	1.0	1	1	1
07/06/2014 18:00	11.7	2,128.9	1.3	1.1	1	1	1
07/06/2014 19:00	12.1	2,051.6	1.2	1.0	1	1	1
07/06/2014 20:00	12.0	2,073.1	1.3	1.0	1	1	1
07/06/2014 21:00	12.9	1,885.8	1.1	0.8	1	1	1
07/06/2014 22:00	13.1	1,853.3	1.0	0.7	1	1	1
07/06/2014 23:00	13.2	1,835.8	1.0	0.7	1	1	1
Average/Sum#:	13.5	1,663.8	1.5	0.8	22 #	19 #	13 #
Minimum:	11.7	308.3	1.0	0.4	0	0	0
Maximum:	17.5	2,128.9	7.7	1.1	1	1	1
%SI	8.3	8.3	8.3	8.3	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/07/2014 00:00	13.9	1,275.2	1.1	0.5	1	1	0
07/07/2014 01:00	13.9	1,251.6	1.1	0.5	1	1	0
07/07/2014 02:00	13.9	1,279.7	1.1	0.5	1	1	0
07/07/2014 03:00	13.9	1,332.2	1.1	0.5	1	1	0
07/07/2014 04:00	13.2	1,871.1	1.0	0.7	1	1	1
07/07/2014 05:00	13.3	1,866.1	1.0	0.7	1	1	1
07/07/2014 06:00	13.3	1,847.1	1.0	0.7	1	1	1
07/07/2014 07:00	13.2	1,847.6	1.0	0.7	1	1	1
07/07/2014 08:00	13.1	1,867.4	1.0	0.7	1	1	1
07/07/2014 09:00	13.1	1,853.8	1.1	0.7	1	1	1
07/07/2014 10:00	13.0	1,867.8	1.1	0.7	1	1	1
07/07/2014 11:00	13.1	1,844.5	1.1	0.7	1	1	1
07/07/2014 12:00	13.0	1,852.1	1.1	0.7	1	1	1
07/07/2014 13:00	13.0	1,855.6	1.1	0.7	1	1	1
07/07/2014 14:00	13.0	1,849.6	1.1	0.7	1	1	1
07/07/2014 15:00	13.0	1,848.1	1.1	0.7	1	1	1
07/07/2014 16:00	12.9	1,852.3	1.1	0.7	1	1	1
07/07/2014 17:00	12.9	1,874.1	1.1	0.7	1	1	1
07/07/2014 18:00	12.9	1,887.2	1.1	0.8	1	1	1
07/07/2014 19:00	12.8	1,900.3	1.1	0.8	1	1	1
07/07/2014 20:00	13.0	1,854.0	1.1	0.7	1	1	1
07/07/2014 21:00	13.1	1,839.9	1.0	0.7	1	1	1
07/07/2014 22:00	13.3	1,677.1	1.1	0.7	1	1	1
07/07/2014 23:00	13.2	1,846.1	1.0	0.7	1	1	1
Average/Sum#:	13.2	1,755.9	1.1	0.7	24 #	24 #	20 #
Minimum:	12.8	1,251.6	1.0	0.5	1	1	0
Maximum:	13.9	1,900.3	1.1	0.8	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/08/2014 00:00	13.0	1,873.0	1.1	0.7	1	1	1
07/08/2014 01:00	13.2	1,850.2	1.0	0.7	1	1	1
07/08/2014 02:00	13.2	1,847.9	1.0	0.7	1	1	1
07/08/2014 03:00	13.4	1,719.7	1.0	0.7	1	1	1
07/08/2014 04:00	12.9	1,913.5	1.1	0.8	1	1	1
07/08/2014 05:00	13.2	1,854.5	1.0	0.7	1	1	1
07/08/2014 06:00	12.8	1,925.8	1.1	0.8	1	1	1
07/08/2014 07:00	13.1	1,862.4	1.1	0.7	1	1	1
07/08/2014 08:00	13.0	1,883.1	1.1	0.8	1	1	1
07/08/2014 09:00	13.1	1,858.9	1.0	0.7	1	1	1
07/08/2014 10:00	12.7	1,939.6	1.1	0.8	1	1	1
07/08/2014 11:00	12.7	1,923.0	1.1	0.8	1	1	1
07/08/2014 12:00	12.1	2,063.8	1.3	1.0	1	1	1
07/08/2014 13:00	11.4	2,193.8	1.4	1.1	1	1	1
07/08/2014 14:00	11.6	2,119.4	1.4	1.1	1	1	1
07/08/2014 15:00	11.7	2,107.0	1.4	1.1	1	1	1
07/08/2014 16:00	11.7	2,115.1	1.4	1.1	1	1	1
07/08/2014 17:00	11.7	2,122.1	1.4	1.1	1	1	1
07/08/2014 18:00	12.0	2,058.5	1.3	1.0	1	1	1
07/08/2014 19:00	12.4	1,975.7	1.2	1.0	1	1	1
07/08/2014 20:00	13.0	1,871.9	1.1	0.7	1	1	1
07/08/2014 21:00	13.1	1,856.9	1.0	0.7	1	1	1
07/08/2014 22:00	13.6	1,487.5	1.1	0.6	1	1	1
07/08/2014 23:00	13.9	1,381.5	1.1	0.6	1	1	0
Average/Sum#:	12.7	1,908.5	1.2	0.8	24 #	24 #	23 #
Minimum:	11.4	1,381.5	1.0	0.6	1	1	0
Maximum:	13.9	2,193.8	1.4	1.1	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/09/2014 00:00	13.9	1,245.0	1.1	0.5	1	1	0
07/09/2014 01:00	13.8	1,242.6	1.1	0.5	1	1	0
07/09/2014 02:00	13.8	1,241.6	1.1	0.5	1	1	0
07/09/2014 03:00	13.8	1,241.7	1.1	0.5	1	1	0
07/09/2014 04:00	13.8	1,252.1	1.1	0.5	1	1	0
07/09/2014 05:00	13.8	1,547.2	1.0	0.6	1	1	0
07/09/2014 06:00	13.5	1,651.8	1.1	0.7	1	1	1
07/09/2014 07:00	12.8	1,958.0	1.0	0.8	1	1	1
07/09/2014 08:00	12.8	1,937.8	1.1	0.8	1	1	1
07/09/2014 09:00	12.4	2,004.4	1.2	1.0	1	1	1
07/09/2014 10:00	11.9	2,102.5	1.3	1.1	1	1	1
07/09/2014 11:00	11.5	2,165.4	1.4	1.1	1	1	1
07/09/2014 12:00	11.4	2,187.1	1.4	1.1	1	1	1
07/09/2014 13:00	11.5	2,147.8	1.4	1.1	1	1	1
07/09/2014 14:00	12.2	1,998.1	1.2	1.0	1	1	1
07/09/2014 15:00	11.9	2,066.3	1.3	1.0	1	1	1
07/09/2014 16:00	11.6	2,113.3	1.4	1.1	1	1	1
07/09/2014 17:00	11.6	2,105.5	1.4	1.1	1	1	1
07/09/2014 18:00	12.1	2,008.0	1.3	1.0	1	1	1
07/09/2014 19:00	12.5	1,940.7	1.2	1.0	1	1	1
07/09/2014 20:00	12.5	1,960.0	1.2	1.0	1	1	1
07/09/2014 21:00	12.6	1,929.8	1.1	0.8	1	1	1
07/09/2014 22:00	12.8	1,909.0	1.1	0.8	1	1	1
07/09/2014 23:00	13.5	1,450.9	1.1	0.6	1	1	1
Average/Sum#:	12.7	1,808.6	1.2	0.8	24 #	24 #	18 #
Minimum:	11.4	1,241.6	1.0	0.5	1	1	0
Maximum:	13.9	2,187.1	1.4	1.1	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/10/2014 00:00	13.8	1,238.8	1.1	0.5	1	1	0
07/10/2014 01:00	13.8	1,238.3	1.1	0.5	1	1	0
07/10/2014 02:00	13.8	1,238.7	1.1	0.5	1	1	0
07/10/2014 03:00	13.8	1,238.2	1.1	0.5	1	1	0
07/10/2014 04:00	13.8	1,238.7	1.1	0.5	1	1	0
07/10/2014 05:00	13.8	1,240.2	1.1	0.5	1	1	0
07/10/2014 06:00	13.8	1,241.5	1.1	0.5	1	1	0
07/10/2014 07:00	13.8	1,248.1	1.1	0.5	1	1	0
07/10/2014 08:00	13.8	1,258.6	1.1	0.5	1	1	0
07/10/2014 09:00	13.5	1,563.1	1.0	0.6	1	1	1
07/10/2014 10:00	13.2	1,846.0	1.0	0.7	1	1	1
07/10/2014 11:00	13.2	1,841.5	1.0	0.7	1	1	1
07/10/2014 12:00	13.1	1,874.5	1.0	0.7	1	1	1
07/10/2014 13:00	12.9	1,889.1	1.1	0.8	1	1	1
07/10/2014 14:00	12.8	1,895.5	1.1	0.8	1	1	1
07/10/2014 15:00	12.8	1,884.3	1.1	0.8	1	1	1
07/10/2014 16:00	12.5	1,937.5	1.2	1.0	1	1	1
07/10/2014 17:00	12.8	1,897.4	1.1	0.8	1	1	1
07/10/2014 18:00	12.6	1,944.7	1.2	1.0	1	1	1
07/10/2014 19:00	13.1	1,841.3	1.1	0.7	1	1	1
07/10/2014 20:00	13.2	1,837.6	1.0	0.7	1	1	1
07/10/2014 21:00	13.2	1,849.0	1.0	0.7	1	1	1
07/10/2014 22:00	13.3	1,830.4	1.0	0.7	1	1	1
07/10/2014 23:00	13.3	1,641.4	1.1	0.7	1	1	1
Average/Sum#:	13.3	1,614.8	1.1	0.7	24 #	24 #	15 #
Minimum:	12.5	1,238.2	1.0	0.5	1	1	0
Maximum:	13.8	1,944.7	1.2	1.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/11/2014 00:00	13.8	1,271.9	1.1	0.5	1	1	0
07/11/2014 01:00	15.7	618.1	3.7	0.9	1	0	0
07/11/2014 02:00	0.0	0.0	0.0	0.0	0	0	0
07/11/2014 03:00	0.0	0.0	0.0	0.0	0	0	0
07/11/2014 04:00	0.0	0.0	0.0	0.0	0	0	0
07/11/2014 05:00	17.3	489.5	3.5	0.6	1	0	0
07/11/2014 06:00	14.5	1,039.4	2.8	1.1	1	0	0
07/11/2014 07:00	13.8	1,288.4	1.1	0.5	1	1	0
07/11/2014 08:00	13.8	1,292.3	1.1	0.5	1	1	0
07/11/2014 09:00	13.8	1,497.6	1.0	0.6	1	1	0
07/11/2014 10:00	13.9	1,298.3	1.2	0.6	1	1	0
07/11/2014 11:00	13.9	1,270.7	1.1	0.5	1	1	0
07/11/2014 12:00	13.9	1,271.3	1.1	0.5	1	1	0
07/11/2014 13:00	13.9	1,271.5	1.1	0.5	1	1	0
07/11/2014 14:00	13.9	1,273.6	1.1	0.5	1	1	0
07/11/2014 15:00	14.0	1,275.2	1.1	0.5	1	1	0
07/11/2014 16:00	14.0	1,275.8	1.1	0.5	1	1	0
07/11/2014 17:00	14.0	1,275.3	1.1	0.5	1	1	0
07/11/2014 18:00	13.9	1,271.2	1.1	0.5	1	1	0
07/11/2014 19:00	13.9	1,268.9	1.1	0.5	1	1	0
07/11/2014 20:00	13.9	1,269.3	1.1	0.5	1	1	0
07/11/2014 21:00	13.9	1,262.7	1.1	0.5	1	1	0
07/11/2014 22:00	13.8	1,262.6	1.1	0.5	1	1	0
07/11/2014 23:00	13.8	1,263.2	1.1	0.5	1	1	0
Average/Sum#:	14.2	1,205.1	1.4	0.6	21 #	18 #	0 #
Minimum:	13.8	489.5	1.0	0.5	0	0	0
Maximum:	17.3	1,497.6	3.7	1.1	1	1	0
%SI	12.5	12.5	12.5	12.5	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/12/2014 00:00	15.8	532.4	4.8	1.0	1	0	0
07/12/2014 01:00	0.0	0.0	0.0	0.0	0	0	0
07/12/2014 02:00	0.0	0.0	0.0	0.0	0	0	0
07/12/2014 03:00	0.0	0.0	0.0	0.0	0	0	0
07/12/2014 04:00	0.0	0.0	0.0	0.0	0	0	0
07/12/2014 05:00	0.0	0.0	0.0	0.0	0	0	0
07/12/2014 06:00	0.0	0.0	0.0	0.0	0	0	0
07/12/2014 07:00	0.0	0.0	0.0	0.0	0	0	0
07/12/2014 08:00	0.0	0.0	0.0	0.0	0	0	0
07/12/2014 09:00	0.0	0.0	0.0	0.0	0	0	0
07/12/2014 10:00	0.0	0.0	0.0	0.0	0	0	0
07/12/2014 11:00	16.6	619.4	0.0	0.0	1	0	0
07/12/2014 12:00	13.9	1,344.5	1.6	0.8	1	0	0
07/12/2014 13:00	13.7	1,648.0	1.0	0.7	1	1	0
07/12/2014 14:00	13.3	1,758.5	1.1	0.7	1	1	1
07/12/2014 15:00	12.0	2,045.8	1.3	1.0	1	1	1
07/12/2014 16:00	12.7	1,917.9	1.2	1.0	1	1	1
07/12/2014 17:00	12.6	1,935.3	1.2	1.0	1	1	1
07/12/2014 18:00	12.7	1,923.9	1.1	0.8	1	1	1
07/12/2014 19:00	13.0	1,861.4	1.1	0.7	1	1	1
07/12/2014 20:00	13.0	1,869.9	1.1	0.7	1	1	1
07/12/2014 21:00	12.7	1,950.9	1.2	1.0	1	1	1
07/12/2014 22:00	12.4	2,007.3	1.2	1.0	1	1	1
07/12/2014 23:00	12.7	1,946.8	1.1	0.8	1	1	1
Average/Sum#:	13.4	1,668.7	1.4	0.8	14 #	11 #	10 #
Minimum:	12.0	532.4	0.0	0.0	0	0	0
Maximum:	16.6	2,045.8	4.8	1.0	1	1	1
%SI	41.7	41.7	41.7	41.7	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/13/2014 00:00	13.3	1,654.0	1.1	0.7	1	1	1
07/13/2014 01:00	15.8	536.4	4.6	1.0	1	0	0
07/13/2014 02:00	0.0	0.0	0.0	0.0	0	0	0
07/13/2014 03:00	0.0	0.0	0.0	0.0	0	0	0
07/13/2014 04:00	0.0	0.0	0.0	0.0	0	0	0
07/13/2014 05:00	0.0	0.0	0.0	0.0	0	0	0
07/13/2014 06:00	17.5	450.6	0.0	0.0	1	0	0
07/13/2014 07:00	15.1	940.5	3.1	1.1	1	0	0
07/13/2014 08:00	13.8	1,462.3	1.1	0.6	1	1	0
07/13/2014 09:00	13.7	1,737.2	1.0	0.7	1	1	0
07/13/2014 10:00	13.8	1,678.7	1.0	0.7	1	1	0
07/13/2014 11:00	13.8	1,492.9	1.0	0.6	1	1	1
07/13/2014 12:00	12.9	1,889.4	1.1	0.8	1	1	1
07/13/2014 13:00	12.1	2,020.0	1.3	1.0	1	1	1
07/13/2014 14:00	11.8	2,076.1	1.3	1.0	1	1	1
07/13/2014 15:00	11.3	2,170.6	1.4	1.1	1	1	1
07/13/2014 16:00	12.1	2,010.0	1.3	1.0	1	1	1
07/13/2014 17:00	12.3	1,978.9	1.2	1.0	1	1	1
07/13/2014 18:00	12.2	1,984.7	1.2	1.0	1	1	1
07/13/2014 19:00	12.8	1,881.4	1.1	0.8	1	1	1
07/13/2014 20:00	13.6	1,539.0	1.1	0.6	1	1	1
07/13/2014 21:00	13.3	1,755.2	1.1	0.7	1	1	1
07/13/2014 22:00	12.7	1,896.1	1.1	0.8	1	1	1
07/13/2014 23:00	13.6	1,465.0	1.1	0.6	1	1	1
Average/Sum#:	13.4	1,631.0	1.4	0.8	20 #	17 #	14 #
Minimum:	11.3	450.6	0.0	0.0	0	0	0
Maximum:	17.5	2,170.6	4.6	1.1	1	1	1
%SI	16.7	16.7	16.7	16.7	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/14/2014 00:00	13.9	1,379.9	1.0	0.6	1	1	0
07/14/2014 01:00	13.9	1,471.6	1.0	0.6	1	1	0
07/14/2014 02:00	13.9	1,408.9	1.1	0.6	1	1	0
07/14/2014 03:00	13.7	1,722.2	1.0	0.7	1	1	0
07/14/2014 04:00	13.7	1,726.7	1.0	0.7	1	1	0
07/14/2014 05:00	13.7	1,607.7	1.0	0.6	1	1	1
07/14/2014 06:00	12.5	2,026.1	1.2	1.0	1	1	1
07/14/2014 07:00	12.8	1,960.1	1.1	0.8	1	1	1
07/14/2014 08:00	12.9	1,897.6	1.1	0.8	1	1	1
07/14/2014 09:00	12.8	1,917.3	1.1	0.8	1	1	1
07/14/2014 10:00	13.0	1,860.8	1.1	0.7	1	1	1
07/14/2014 11:00	12.9	1,875.0	1.1	0.8	1	1	1
07/14/2014 12:00	12.8	1,883.4	1.1	0.8	1	1	1
07/14/2014 13:00	12.5	1,942.5	1.2	1.0	1	1	1
07/14/2014 14:00	11.7	2,077.2	1.3	1.0	1	1	1
07/14/2014 15:00	11.7	2,060.8	1.3	1.0	1	1	1
07/14/2014 16:00	11.9	2,017.8	1.3	1.0	1	1	1
07/14/2014 17:00	12.2	1,968.7	1.2	1.0	1	1	1
07/14/2014 18:00	13.6	1,551.8	1.1	0.6	1	1	1
07/14/2014 19:00	13.9	1,439.1	1.0	0.6	1	1	0
07/14/2014 20:00	13.7	1,629.1	1.0	0.7	1	1	0
07/14/2014 21:00	13.8	1,637.9	1.0	0.7	1	1	0
07/14/2014 22:00	13.8	1,508.1	1.0	0.6	1	1	0
07/14/2014 23:00	13.7	1,646.9	1.0	0.7	1	1	0
Average/Sum#:	13.1	1,759.1	1.1	0.8	24 #	24 #	14 #
Minimum:	11.7	1,379.9	1.0	0.6	1	1	0
Maximum:	13.9	2,077.2	1.3	1.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/15/2014 00:00	13.6	1,747.0	1.0	0.7	1	1	0
07/15/2014 01:00	13.6	1,773.9	1.0	0.7	1	1	0
07/15/2014 02:00	13.6	1,769.2	1.0	0.7	1	1	0
07/15/2014 03:00	13.3	1,809.2	1.1	0.7	1	1	1
07/15/2014 04:00	12.9	1,938.7	1.1	0.8	1	1	1
07/15/2014 05:00	12.6	1,989.8	1.2	1.0	1	1	1
07/15/2014 06:00	13.0	1,890.3	1.1	0.8	1	1	1
07/15/2014 07:00	13.3	1,844.4	1.0	0.7	1	1	1
07/15/2014 08:00	13.3	1,840.0	1.0	0.7	1	1	1
07/15/2014 09:00	13.2	1,851.3	1.0	0.7	1	1	1
07/15/2014 10:00	13.1	1,874.1	1.0	0.7	1	1	1
07/15/2014 11:00	13.1	1,869.6	1.0	0.7	1	1	1
07/15/2014 12:00	13.1	1,859.7	1.0	0.7	1	1	1
07/15/2014 13:00	13.2	1,855.3	1.0	0.7	1	1	1
07/15/2014 14:00	12.9	1,923.3	1.1	0.8	1	1	1
07/15/2014 15:00	12.7	1,925.1	1.1	0.8	1	1	1
07/15/2014 16:00	12.9	1,879.3	1.1	0.8	1	1	1
07/15/2014 17:00	12.8	1,908.7	1.1	0.8	1	1	1
07/15/2014 18:00	12.8	1,882.9	1.1	0.8	1	1	1
07/15/2014 19:00	12.8	1,903.6	1.1	0.8	1	1	1
07/15/2014 20:00	12.8	1,891.8	1.1	0.8	1	1	1
07/15/2014 21:00	12.8	1,901.4	1.1	0.8	1	1	1
07/15/2014 22:00	12.9	1,888.8	1.1	0.8	1	1	1
07/15/2014 23:00	12.8	1,915.0	1.1	0.8	1	1	1
Average/Sum#:	13.0	1,872.2	1.1	0.8	24 #	24 #	21 #
Minimum:	12.6	1,747.0	1.0	0.7	1	1	0
Maximum:	13.6	1,989.8	1.2	1.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/16/2014 00:00	12.9	1,880.1	1.1	0.8	1	1	1
07/16/2014 01:00	13.6	1,472.9	1.1	0.6	1	1	1
07/16/2014 02:00	13.8	1,421.7	1.1	0.6	1	1	0
07/16/2014 03:00	13.8	1,468.9	1.1	0.6	1	1	0
07/16/2014 04:00	13.6	1,743.9	1.0	0.7	1	1	0
07/16/2014 05:00	13.5	1,618.2	1.1	0.6	1	1	1
07/16/2014 06:00	13.4	1,709.5	1.0	0.7	1	1	1
07/16/2014 07:00	13.8	1,587.8	1.0	0.6	1	1	0
07/16/2014 08:00	13.6	1,697.8	1.0	0.7	1	1	1
07/16/2014 09:00	13.2	1,841.3	1.0	0.7	1	1	1
07/16/2014 10:00	13.2	1,844.3	1.0	0.7	1	1	1
07/16/2014 11:00	13.2	1,844.6	1.0	0.7	1	1	1
07/16/2014 12:00	13.2	1,840.2	1.0	0.7	1	1	1
07/16/2014 13:00	13.1	1,842.6	1.0	0.7	1	1	1
07/16/2014 14:00	13.0	1,849.6	1.1	0.7	1	1	1
07/16/2014 15:00	13.0	1,852.3	1.1	0.7	1	1	1
07/16/2014 16:00	12.9	1,863.8	1.1	0.7	1	1	1
07/16/2014 17:00	12.9	1,872.4	1.1	0.7	1	1	1
07/16/2014 18:00	12.9	1,867.5	1.1	0.7	1	1	1
07/16/2014 19:00	13.0	1,851.4	1.1	0.7	1	1	1
07/16/2014 20:00	13.0	1,844.4	1.1	0.7	1	1	1
07/16/2014 21:00	13.6	1,580.6	1.1	0.6	1	1	1
07/16/2014 22:00	13.5	1,698.8	1.1	0.7	1	1	1
07/16/2014 23:00	13.4	1,673.5	1.1	0.7	1	1	1
Average/Sum#:	13.3	1,740.3	1.1	0.7	24 #	24 #	20 #
Minimum:	12.9	1,421.7	1.0	0.6	1	1	0
Maximum:	13.8	1,880.1	1.1	0.8	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/17/2014 00:00	15.7	561.9	4.9	1.1	1	0	0
07/17/2014 01:00	0.0	0.0	0.0	0.0	0	0	0
07/17/2014 02:00	0.0	0.0	0.0	0.0	0	0	0
07/17/2014 03:00	0.0	0.0	0.0	0.0	0	0	0
07/17/2014 04:00	0.0	0.0	0.0	0.0	0	0	0
07/17/2014 05:00	0.0	0.0	0.0	0.0	0	0	0
07/17/2014 06:00	0.0	0.0	0.0	0.0	0	0	0
07/17/2014 07:00	0.0	0.0	0.0	0.0	0	0	0
07/17/2014 08:00	17.7	421.5	0.0	0.0	1	0	0
07/17/2014 09:00	14.5	1,202.2	2.2	1.0	1	0	0
07/17/2014 10:00	13.5	1,599.6	1.1	0.6	1	1	1
07/17/2014 11:00	13.2	1,822.5	1.0	0.7	1	1	1
07/17/2014 12:00	13.2	1,818.0	1.0	0.7	1	1	1
07/17/2014 13:00	13.1	1,826.4	1.0	0.7	1	1	1
07/17/2014 14:00	13.1	1,823.4	1.1	0.7	1	1	1
07/17/2014 15:00	13.0	1,831.6	1.1	0.7	1	1	1
07/17/2014 16:00	13.0	1,837.2	1.1	0.7	1	1	1
07/17/2014 17:00	12.9	1,850.3	1.1	0.7	1	1	1
07/17/2014 18:00	12.5	1,927.1	1.2	1.0	1	1	1
07/17/2014 19:00	12.4	1,950.1	1.2	1.0	1	1	1
07/17/2014 20:00	12.9	1,857.3	1.1	0.7	1	1	1
07/17/2014 21:00	12.8	1,896.9	1.1	0.8	1	1	1
07/17/2014 22:00	13.5	1,645.9	1.1	0.7	1	1	1
07/17/2014 23:00	13.8	1,405.0	1.1	0.6	1	1	0
Average/Sum#:	13.6	1,604.5	1.3	0.7	17 #	14 #	13 #
Minimum:	12.4	421.5	0.0	0.0	0	0	0
Maximum:	17.7	1,950.1	4.9	1.1	1	1	1
%SI	29.2	29.2	29.2	29.2	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/18/2014 00:00	15.7	558.4	4.7	1.0	1	0	0
07/18/2014 01:00	0.0	0.0	0.0	0.0	0	0	0
07/18/2014 02:00	0.0	0.0	0.0	0.0	0	0	0
07/18/2014 03:00	0.0	0.0	0.0	0.0	0	0	0
07/18/2014 04:00	0.0	0.0	0.0	0.0	0	0	0
07/18/2014 05:00	0.0	0.0	0.0	0.0	0	0	0
07/18/2014 06:00	0.0	0.0	0.0	0.0	0	0	0
07/18/2014 07:00	0.0	0.0	0.0	0.0	0	0	0
07/18/2014 08:00	16.4	649.6	1.7	0.5	1	0	0
07/18/2014 09:00	13.5	1,579.6	1.5	0.9	1	0	1
07/18/2014 10:00	13.2	1,851.7	1.0	0.7	1	1	1
07/18/2014 11:00	13.2	1,843.0	1.0	0.7	1	1	1
07/18/2014 12:00	13.3	1,836.9	1.0	0.7	1	1	1
07/18/2014 13:00	13.2	1,838.2	1.0	0.7	1	1	1
07/18/2014 14:00	13.2	1,835.3	1.0	0.7	1	1	1
07/18/2014 15:00	13.0	1,866.3	1.1	0.7	1	1	1
07/18/2014 16:00	12.9	1,889.4	1.1	0.8	1	1	1
07/18/2014 17:00	11.7	2,120.5	1.3	1.1	1	1	1
07/18/2014 18:00	11.5	2,137.3	1.4	1.1	1	1	1
07/18/2014 19:00	11.9	2,074.8	1.3	1.0	1	1	1
07/18/2014 20:00	12.4	1,978.8	1.2	1.0	1	1	1
07/18/2014 21:00	13.1	1,849.9	1.0	0.7	1	1	1
07/18/2014 22:00	13.5	1,600.5	1.1	0.6	1	1	1
07/18/2014 23:00	13.8	1,298.0	1.1	0.5	1	1	0
Average/Sum#:	13.3	1,694.6	1.4	0.8	17 #	14 #	14 #
Minimum:	11.5	558.4	1.0	0.5	0	0	0
Maximum:	16.4	2,137.3	4.7	1.1	1	1	1
%SI	29.2	29.2	29.2	29.2	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/19/2014 00:00	15.1	830.2	2.7	0.8	1	0	0
07/19/2014 01:00	0.0	0.0	0.0	0.0	0	0	0
07/19/2014 02:00	0.0	0.0	0.0	0.0	0	0	0
07/19/2014 03:00	0.0	0.0	0.0	0.0	0	0	0
07/19/2014 04:00	0.0	0.0	0.0	0.0	0	0	0
07/19/2014 05:00	17.6	436.7	0.0	0.0	1	0	0
07/19/2014 06:00	14.9	1,030.7	2.8	1.1	1	0	0
07/19/2014 07:00	13.6	1,768.0	1.1	0.7	1	1	0
07/19/2014 08:00	13.6	1,752.8	1.0	0.7	1	1	0
07/19/2014 09:00	13.7	1,739.6	1.0	0.7	1	1	0
07/19/2014 10:00	13.8	1,515.4	1.1	0.6	1	1	1
07/19/2014 11:00	12.1	2,042.1	1.3	1.0	1	1	1
07/19/2014 12:00	11.5	2,129.9	1.4	1.1	1	1	1
07/19/2014 13:00	11.1	2,212.3	1.5	1.3	1	1	1
07/19/2014 14:00	11.3	2,178.4	1.4	1.1	1	1	1
07/19/2014 15:00	11.3	2,159.6	1.4	1.1	1	1	1
07/19/2014 16:00	11.5	2,110.5	1.4	1.1	1	1	1
07/19/2014 17:00	11.6	2,100.1	1.4	1.1	1	1	1
07/19/2014 18:00	12.4	1,951.9	1.2	1.0	1	1	1
07/19/2014 19:00	11.9	2,049.3	1.3	1.0	1	1	1
07/19/2014 20:00	11.5	2,124.9	1.4	1.1	1	1	1
07/19/2014 21:00	12.2	1,991.9	1.2	1.0	1	1	1
07/19/2014 22:00	13.7	1,529.6	1.1	0.6	1	1	1
07/19/2014 23:00	13.8	1,502.3	1.1	0.6	1	1	0
Average/Sum#:	12.9	1,757.8	1.3	0.9	20 #	17 #	13 #
Minimum:	11.1	436.7	0.0	0.0	0	0	0
Maximum:	17.6	2,212.3	2.8	1.3	1	1	1
%SI	16.7	16.7	16.7	16.7	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/20/2014 00:00	15.7	554.2	4.8	1.0	1	0	0
07/20/2014 01:00	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 02:00	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 03:00	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 04:00	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 05:00	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 06:00	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 07:00	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 08:00	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 09:00	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 10:00	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 11:00	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 12:00	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 13:00	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 14:00	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 15:00	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 16:00	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 17:00	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 18:00	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 19:00	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 20:00	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 21:00	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 22:00	0.0	0.0	0.0	0.0	0	0	0
07/20/2014 23:00	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	15.7	554.2	4.8	1.0	1 #	0 #	0 #
Minimum:	15.7	554.2	4.8	1.0	0	0	0
Maximum:	15.7	554.2	4.8	1.0	1	0	0
%SI	95.8	95.8	95.8	95.8	0	0	0

Daily Summary Report

CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/21/2014 00:00	0.0	0.0	0.0	0.0	0	0	0
07/21/2014 01:00	0.0	0.0	0.0	0.0	0	0	0
07/21/2014 02:00	0.0	0.0	0.0	0.0	0	0	0
07/21/2014 03:00	0.0	0.0	0.0	0.0	0	0	0
07/21/2014 04:00	0.0	0.0	0.0	0.0	0	0	0
07/21/2014 05:00	0.0	0.0	0.0	0.0	0	0	0
07/21/2014 06:00	17.2	492.7	0.0	0.0	1	0	0
07/21/2014 07:00	14.4	1,206.8	2.5	1.2	1	0	1
07/21/2014 08:00	13.0	1,890.5	1.1	0.8	1	1	1
07/21/2014 09:00	12.7	1,934.8	1.1	0.8	1	1	1
07/21/2014 10:00	12.8	1,935.6	1.1	0.8	1	1	1
07/21/2014 11:00	12.9	1,922.3	1.1	0.8	1	1	1
07/21/2014 12:00	12.8	1,914.5	1.1	0.8	1	1	1
07/21/2014 13:00	12.9	1,906.6	1.1	0.8	1	1	1
07/21/2014 14:00	12.8	1,917.6	1.1	0.8	1	1	1
07/21/2014 15:00	12.5	1,981.1	1.2	1.0	1	1	1
07/21/2014 16:00	12.4	1,981.5	1.2	1.0	1	1	1
07/21/2014 17:00	11.5	2,162.5	1.4	1.1	1	1	1
07/21/2014 18:00	11.1	2,236.5	1.5	1.3	1	1	1
07/21/2014 19:00	11.1	2,246.6	1.5	1.3	1	1	1
07/21/2014 20:00	11.1	2,247.7	1.6	1.3	1	1	1
07/21/2014 21:00	11.7	2,144.9	1.4	1.1	1	1	1
07/21/2014 22:00	12.4	2,005.2	1.2	1.0	1	1	1
07/21/2014 23:00	12.7	1,936.9	1.1	0.8	1	1	1
Average/Sum#:	12.7	1,892.5	1.2	0.9	18 #	16 #	17 #
Minimum:	11.1	492.7	0.0	0.0	0	0	0
Maximum:	17.2	2,247.7	2.5	1.3	1	1	1
%SI	25.0	25.0	25.0	25.0	0	0	0

Daily Summary Report

CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/22/2014 00:00	13.3	1,835.3	1.0	0.7	1	1	1
07/22/2014 01:00	13.2	1,853.4	1.0	0.7	1	1	1
07/22/2014 02:00	13.2	1,846.9	1.0	0.7	1	1	1
07/22/2014 03:00	13.3	1,835.9	1.0	0.7	1	1	1
07/22/2014 04:00	13.0	1,911.9	1.1	0.8	1	1	1
07/22/2014 05:00	13.2	1,868.5	1.0	0.7	1	1	1
07/22/2014 06:00	13.2	1,850.7	1.0	0.7	1	1	1
07/22/2014 07:00	12.8	1,937.5	1.1	0.8	1	1	1
07/22/2014 08:00	13.2	1,853.7	1.2	0.9	1	1	1
07/22/2014 09:00	13.3	1,842.3	1.2	0.9	1	1	1
07/22/2014 10:00	13.2	1,830.9	1.0	0.7	1	1	1
07/22/2014 11:00	12.8	1,913.4	1.1	0.8	1	1	1
07/22/2014 12:00	12.3	2,020.5	1.2	1.0	1	1	1
07/22/2014 13:00	12.5	1,975.0	1.2	1.0	1	1	1
07/22/2014 14:00	12.3	2,005.2	1.2	1.0	1	1	1
07/22/2014 15:00	11.6	2,139.3	1.4	1.1	1	1	1
07/22/2014 16:00	11.9	2,069.2	1.3	1.0	1	1	1
07/22/2014 17:00	12.1	2,024.1	1.3	1.0	1	1	1
07/22/2014 18:00	11.7	2,133.0	1.3	1.1	1	1	1
07/22/2014 19:00	12.1	2,085.5	1.3	1.0	1	1	1
07/22/2014 20:00	12.2	2,066.6	1.3	1.0	1	1	1
07/22/2014 21:00	12.2	2,066.4	1.2	1.0	1	1	1
07/22/2014 22:00	12.7	1,967.9	1.1	0.8	1	1	1
07/22/2014 23:00	13.6	1,541.9	1.1	0.6	1	1	1
Average/Sum#:	12.7	1,936.5	1.1	0.9	24 #	24 #	24 #
Minimum:	11.6	1,541.9	1.0	0.6	1	1	1
Maximum:	13.6	2,139.3	1.4	1.1	1	1	1
%SI	0.0	0.0	8.3	8.3	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/23/2014 00:00	13.8	1,282.3	1.1	0.5	1	1	0
07/23/2014 01:00	13.8	1,265.8	1.1	0.5	1	1	0
07/23/2014 02:00	13.8	1,248.3	1.1	0.5	1	1	0
07/23/2014 03:00	13.8	1,247.8	1.1	0.5	1	1	0
07/23/2014 04:00	13.8	1,269.3	1.1	0.5	1	1	0
07/23/2014 05:00	13.6	1,554.2	1.1	0.6	1	1	1
07/23/2014 06:00	13.1	1,915.8	1.1	0.8	1	1	1
07/23/2014 07:00	13.1	1,913.5	1.1	0.8	1	1	1
07/23/2014 08:00	13.2	1,886.6	1.2	0.9	1	1	1
07/23/2014 09:00	13.2	1,881.0	1.0	0.8	1	1	1
07/23/2014 10:00	13.2	1,856.1	1.1	0.7	1	1	1
07/23/2014 11:00	13.2	1,858.8	1.0	0.7	1	1	1
07/23/2014 12:00	13.2	1,860.3	1.0	0.7	1	1	1
07/23/2014 13:00	13.3	1,852.7	1.0	0.7	1	1	1
07/23/2014 14:00	13.0	1,894.5	1.1	0.8	1	1	1
07/23/2014 15:00	12.5	2,002.7	1.2	1.0	1	1	1
07/23/2014 16:00	12.0	2,077.5	1.3	1.0	1	1	1
07/23/2014 17:00	12.6	1,964.5	1.1	0.8	1	1	1
07/23/2014 18:00	12.4	2,013.6	1.2	1.0	1	1	1
07/23/2014 19:00	12.4	1,987.9	1.3	1.0	1	1	1
07/23/2014 20:00	12.7	1,946.6	1.1	0.8	1	1	1
07/23/2014 21:00	12.8	1,917.0	1.1	0.8	1	1	1
07/23/2014 22:00	13.2	1,859.7	1.0	0.7	1	1	1
07/23/2014 23:00	13.0	1,901.3	1.1	0.8	1	1	1
Average/Sum#:	13.1	1,769.1	1.1	0.7	24 #	24 #	19 #
Minimum:	12.0	1,247.8	1.0	0.5	1	1	0
Maximum:	13.8	2,077.5	1.3	1.0	1	1	1
%SI	0.0	0.0	12.5	12.5	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/24/2014 00:00	13.2	1,866.4	1.0	0.7	1	1	1
07/24/2014 01:00	13.2	1,872.6	1.0	0.7	1	1	1
07/24/2014 02:00	13.7	1,488.0	1.1	0.6	1	1	1
07/24/2014 03:00	13.9	1,251.5	1.1	0.5	1	1	0
07/24/2014 04:00	13.9	1,247.4	1.1	0.5	1	1	0
07/24/2014 05:00	13.9	1,251.7	1.1	0.5	1	1	0
07/24/2014 06:00	13.9	1,254.5	1.1	0.5	1	1	0
07/24/2014 07:00	13.9	1,258.9	1.1	0.5	1	1	0
07/24/2014 08:00	13.7	1,579.2	1.0	0.6	1	1	1
07/24/2014 09:00	13.1	1,902.1	1.1	0.8	1	1	1
07/24/2014 10:00	13.0	1,914.0	1.1	0.8	1	1	1
07/24/2014 11:00	12.8	1,940.0	1.1	0.8	1	1	1
07/24/2014 12:00	12.1	2,074.6	1.3	1.0	1	1	1
07/24/2014 13:00	11.2	2,244.0	1.5	1.3	1	1	1
07/24/2014 14:00	11.4	2,198.1	1.4	1.1	1	1	1
07/24/2014 15:00	12.0	2,075.4	1.3	1.0	1	1	1
07/24/2014 16:00	12.0	2,080.2	1.3	1.0	1	1	1
07/24/2014 17:00	12.0	2,080.7	1.3	1.0	1	1	1
07/24/2014 18:00	12.0	2,073.9	1.3	1.0	1	1	1
07/24/2014 19:00	12.2	2,055.5	1.3	1.0	1	1	1
07/24/2014 20:00	12.3	2,021.4	1.3	1.0	1	1	1
07/24/2014 21:00	13.4	1,684.7	1.1	0.7	1	1	1
07/24/2014 22:00	13.1	1,878.5	1.1	0.8	1	1	1
07/24/2014 23:00	12.4	2,023.1	1.2	1.0	1	1	1
Average/Sum#:	12.8	1,804.9	1.2	0.8	24 #	24 #	19 #
Minimum:	11.2	1,247.4	1.0	0.5	1	1	0
Maximum:	13.9	2,244.0	1.5	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/25/2014 00:00	13.1	1,881.4	1.1	0.8	1	1	1
07/25/2014 01:00	13.4	1,841.8	1.0	0.7	1	1	1
07/25/2014 02:00	13.4	1,839.3	1.0	0.7	1	1	1
07/25/2014 03:00	13.4	1,837.3	1.0	0.7	1	1	1
07/25/2014 04:00	13.2	1,880.8	1.0	0.8	1	1	1
07/25/2014 05:00	13.1	1,899.0	1.1	0.8	1	1	1
07/25/2014 06:00	13.1	1,900.3	1.1	0.8	1	1	1
07/25/2014 07:00	13.0	1,904.0	1.1	0.8	1	1	1
07/25/2014 08:00	13.2	1,865.3	1.0	0.7	1	1	1
07/25/2014 09:00	12.9	1,902.5	1.1	0.8	1	1	1
07/25/2014 10:00	12.2	2,045.8	1.2	1.0	1	1	1
07/25/2014 11:00	11.7	2,138.1	1.4	1.1	1	1	1
07/25/2014 12:00	11.9	2,098.0	1.4	1.0	1	1	1
07/25/2014 13:00	12.3	1,988.1	1.3	1.0	1	1	1
07/25/2014 14:00	12.2	2,040.3	1.2	1.0	1	1	1
07/25/2014 15:00	11.7	2,123.8	1.4	1.1	1	1	1
07/25/2014 16:00	11.8	2,100.4	1.3	1.1	1	1	1
07/25/2014 17:00	11.6	2,148.2	1.4	1.1	1	1	1
07/25/2014 18:00	11.7	2,147.9	1.4	1.1	1	1	1
07/25/2014 19:00	11.4	2,185.8	1.4	1.1	1	1	1
07/25/2014 20:00	11.9	2,083.7	1.3	1.0	1	1	1
07/25/2014 21:00	12.3	2,013.1	1.2	1.0	1	1	1
07/25/2014 22:00	12.4	2,000.4	1.2	1.0	1	1	1
07/25/2014 23:00	12.9	1,903.4	1.1	0.8	1	1	1
Average/Sum#:	12.5	1,990.4	1.2	0.9	24 #	24 #	24 #
Minimum:	11.4	1,837.3	1.0	0.7	1	1	1
Maximum:	13.4	2,185.8	1.4	1.1	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/26/2014 00:00	13.1	1,858.5	1.1	0.7	1	1	1
07/26/2014 01:00	13.3	1,839.3	1.0	0.7	1	1	1
07/26/2014 02:00	13.3	1,838.7	1.0	0.7	1	1	1
07/26/2014 03:00	13.3	1,836.3	1.0	0.7	1	1	1
07/26/2014 04:00	13.2	1,875.8	1.0	0.8	1	1	1
07/26/2014 05:00	13.3	1,834.2	1.0	0.7	1	1	1
07/26/2014 06:00	13.4	1,826.9	1.0	0.7	1	1	1
07/26/2014 07:00	13.2	1,847.5	1.0	0.7	1	1	1
07/26/2014 08:00	13.2	1,845.3	1.0	0.7	1	1	1
07/26/2014 09:00	13.2	1,830.7	1.0	0.7	1	1	1
07/26/2014 10:00	13.1	1,840.0	1.1	0.7	1	1	1
07/26/2014 11:00	12.6	1,965.1	1.2	1.0	1	1	1
07/26/2014 12:00	11.6	2,116.1	1.4	1.1	1	1	1
07/26/2014 13:00	11.6	2,119.2	1.4	1.1	1	1	1
07/26/2014 14:00	12.1	2,007.7	1.3	1.0	1	1	1
07/26/2014 15:00	13.4	1,655.6	1.1	0.7	1	1	1
07/26/2014 16:00	13.4	1,622.7	1.1	0.6	1	1	1
07/26/2014 17:00	12.7	1,920.1	1.1	0.8	1	1	1
07/26/2014 18:00	13.0	1,818.0	1.1	0.7	1	1	1
07/26/2014 19:00	13.9	1,260.1	1.1	0.5	1	1	0
07/26/2014 20:00	14.0	1,246.4	1.1	0.5	1	1	0
07/26/2014 21:00	14.0	1,246.0	1.1	0.5	1	1	0
07/26/2014 22:00	13.9	1,244.5	1.1	0.5	1	1	0
07/26/2014 23:00	13.9	1,405.3	1.1	0.6	1	1	0
Average/Sum#:	13.2	1,745.8	1.1	0.7	24 #	24 #	19 #
Minimum:	11.6	1,244.5	1.0	0.5	1	1	0
Maximum:	14.0	2,119.2	1.4	1.1	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/27/2014 00:00	13.8	1,502.1	1.1	0.6	1	1	0
07/27/2014 01:00	13.9	1,352.2	1.1	0.5	1	1	0
07/27/2014 02:00	13.8	1,377.5	1.1	0.6	1	1	0
07/27/2014 03:00	13.9	1,272.9	1.1	0.5	1	1	0
07/27/2014 04:00	13.9	1,329.6	1.1	0.5	1	1	0
07/27/2014 05:00	13.9	1,283.8	1.1	0.5	1	1	0
07/27/2014 06:00	13.6	1,527.8	1.1	0.6	1	1	1
07/27/2014 07:00	13.0	1,879.8	1.1	0.8	1	1	1
07/27/2014 08:00	13.3	1,775.9	1.1	0.7	1	1	1
07/27/2014 09:00	13.1	1,858.4	1.1	0.7	1	1	1
07/27/2014 10:00	12.9	1,882.6	1.1	0.8	1	1	1
07/27/2014 11:00	12.2	2,022.0	1.2	1.0	1	1	1
07/27/2014 12:00	12.5	1,971.8	1.2	1.0	1	1	1
07/27/2014 13:00	12.6	1,950.6	1.2	1.0	1	1	1
07/27/2014 14:00	12.9	1,898.8	1.1	0.8	1	1	1
07/27/2014 15:00	12.1	2,060.5	1.3	1.0	1	1	1
07/27/2014 16:00	11.9	2,087.9	1.3	1.0	1	1	1
07/27/2014 17:00	11.8	2,101.3	1.3	1.1	1	1	1
07/27/2014 18:00	11.8	2,101.0	1.3	1.1	1	1	1
07/27/2014 19:00	12.0	2,053.6	1.3	1.0	1	1	1
07/27/2014 20:00	13.1	1,822.1	1.1	0.7	1	1	1
07/27/2014 21:00	13.3	1,678.7	1.1	0.7	1	1	1
07/27/2014 22:00	13.5	1,659.3	1.0	0.7	1	1	1
07/27/2014 23:00	13.1	1,840.2	1.0	0.7	1	1	1
Average/Sum#:	13.0	1,762.1	1.1	0.8	24 #	24 #	18 #
Minimum:	11.8	1,272.9	1.0	0.5	1	1	0
Maximum:	13.9	2,101.3	1.3	1.1	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/28/2014 00:00	13.2	1,844.6	1.0	0.7	1	1	1
07/28/2014 01:00	12.9	1,902.1	1.1	0.8	1	1	1
07/28/2014 02:00	13.2	1,743.2	1.1	0.7	1	1	1
07/28/2014 03:00	13.8	1,279.2	1.1	0.5	1	1	0
07/28/2014 04:00	13.5	1,614.6	1.1	0.6	1	1	1
07/28/2014 05:00	13.3	1,837.7	1.0	0.7	1	1	1
07/28/2014 06:00	13.2	1,861.0	1.0	0.7	1	1	1
07/28/2014 07:00	13.2	1,848.2	1.0	0.7	1	1	1
07/28/2014 08:00	13.1	1,875.2	1.1	0.8	1	1	1
07/28/2014 09:00	12.2	2,049.7	1.2	1.0	1	1	1
07/28/2014 10:00	12.1	2,066.8	1.2	1.0	1	1	1
07/28/2014 11:00	11.6	2,153.9	1.4	1.1	1	1	1
07/28/2014 12:00	11.8	2,089.9	1.3	1.0	1	1	1
07/28/2014 13:00	11.7	2,108.6	1.4	1.1	1	1	1
07/28/2014 14:00	11.8	2,079.2	1.3	1.0	1	1	1
07/28/2014 15:00	11.8	2,077.9	1.3	1.0	1	1	1
07/28/2014 16:00	11.8	2,066.0	1.3	1.0	1	1	1
07/28/2014 17:00	11.9	2,071.1	1.3	1.0	1	1	1
07/28/2014 18:00	12.6	1,938.0	1.2	1.0	1	1	1
07/28/2014 19:00	12.5	1,960.9	1.2	1.0	1	1	1
07/28/2014 20:00	12.6	1,931.0	1.2	1.0	1	1	1
07/28/2014 21:00	13.0	1,878.5	1.1	0.8	1	1	1
07/28/2014 22:00	12.8	1,911.1	1.1	0.8	1	1	1
07/28/2014 23:00	13.2	1,834.3	1.0	0.7	1	1	1
Average/Sum#:	12.6	1,917.6	1.2	0.9	24 #	24 #	23 #
Minimum:	11.6	1,279.2	1.0	0.5	1	1	0
Maximum:	13.8	2,153.9	1.4	1.1	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/29/2014 00:00	12.8	1,923.0	1.2	1.0	1	1	1
07/29/2014 01:00	13.8	1,447.1	1.1	0.6	1	1	1
07/29/2014 02:00	13.9	1,253.0	1.1	0.5	1	1	0
07/29/2014 03:00	13.9	1,229.9	1.1	0.5	1	1	0
07/29/2014 04:00	13.8	1,368.4	1.1	0.5	1	1	1
07/29/2014 05:00	13.4	1,832.2	1.0	0.7	1	1	1
07/29/2014 06:00	13.0	1,916.5	1.1	0.8	1	1	1
07/29/2014 07:00	12.2	2,073.6	1.2	1.0	1	1	1
07/29/2014 08:00	12.4	2,027.1	1.2	1.0	1	1	1
07/29/2014 09:00	12.6	1,966.1	1.2	1.0	1	1	1
07/29/2014 10:00	11.8	2,147.5	1.3	1.1	1	1	1
07/29/2014 11:00	12.4	1,999.2	1.2	1.0	1	1	1
07/29/2014 12:00	11.9	2,115.6	1.3	1.1	1	1	1
07/29/2014 13:00	11.4	2,199.2	1.4	1.1	1	1	1
07/29/2014 14:00	11.4	2,185.5	1.4	1.1	1	1	1
07/29/2014 15:00	11.5	2,144.5	1.4	1.1	1	1	1
07/29/2014 16:00	11.9	2,034.2	1.3	1.0	1	1	1
07/29/2014 17:00	12.3	1,979.9	1.2	1.0	1	1	1
07/29/2014 18:00	12.3	1,976.1	1.2	1.0	1	1	1
07/29/2014 19:00	12.7	1,898.4	1.1	0.8	1	1	1
07/29/2014 20:00	13.1	1,840.4	1.0	0.7	1	1	1
07/29/2014 21:00	12.9	1,890.3	1.1	0.8	1	1	1
07/29/2014 22:00	13.1	1,837.2	1.0	0.7	1	1	1
07/29/2014 23:00	13.2	1,825.7	1.0	0.7	1	1	1
Average/Sum#:	12.7	1,879.6	1.2	0.9	24 #	24 #	22 #
Minimum:	11.4	1,229.9	1.0	0.5	1	1	0
Maximum:	13.9	2,199.2	1.4	1.1	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/30/2014 00:00	13.3	1,817.0	1.0	0.7	1	1	1
07/30/2014 01:00	13.1	1,856.2	1.0	0.7	1	1	1
07/30/2014 02:00	13.8	1,404.4	1.1	0.6	1	1	1
07/30/2014 03:00	13.6	1,533.3	1.0	0.6	1	1	1
07/30/2014 04:00	13.3	1,840.3	1.0	0.7	1	1	1
07/30/2014 05:00	13.3	1,845.1	1.0	0.7	1	1	1
07/30/2014 06:00	13.2	1,842.9	1.0	0.7	1	1	1
07/30/2014 07:00	13.2	1,841.3	1.0	0.7	1	1	1
07/30/2014 08:00	13.2	1,842.6	1.0	0.7	1	1	1
07/30/2014 09:00	13.1	1,849.8	1.0	0.7	1	1	1
07/30/2014 10:00	13.1	1,848.0	1.0	0.7	1	1	1
07/30/2014 11:00	12.5	1,982.2	1.2	1.0	1	1	1
07/30/2014 12:00	11.4	2,182.4	1.4	1.1	1	1	1
07/30/2014 13:00	11.3	2,197.8	1.4	1.1	1	1	1
07/30/2014 14:00	11.3	2,166.6	1.4	1.1	1	1	1
07/30/2014 15:00	11.4	2,138.9	1.4	1.1	1	1	1
07/30/2014 16:00	11.4	2,138.6	1.4	1.1	1	1	1
07/30/2014 17:00	11.4	2,139.9	1.4	1.1	1	1	1
07/30/2014 18:00	11.5	2,139.0	1.4	1.1	1	1	1
07/30/2014 19:00	11.7	2,094.0	1.3	1.0	1	1	1
07/30/2014 20:00	12.3	1,989.1	1.2	1.0	1	1	1
07/30/2014 21:00	11.6	2,127.5	1.3	1.1	1	1	1
07/30/2014 22:00	11.9	2,077.9	1.3	1.0	1	1	1
07/30/2014 23:00	12.2	2,028.8	1.2	1.0	1	1	1
Average/Sum#:	12.4	1,955.2	1.2	0.9	24 #	24 #	24 #
Minimum:	11.3	1,404.4	1.0	0.6	1	1	1
Maximum:	13.8	2,197.8	1.4	1.1	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
07/31/2014 00:00	13.4	1,696.9	1.0	0.7	1	1	1
07/31/2014 01:00	13.7	1,710.9	1.0	0.7	1	1	0
07/31/2014 02:00	13.3	1,766.0	1.0	0.7	1	1	1
07/31/2014 03:00	13.0	1,877.3	1.0	0.8	1	1	1
07/31/2014 04:00	13.2	1,847.8	1.0	0.7	1	1	1
07/31/2014 05:00	13.2	1,843.4	1.0	0.7	1	1	1
07/31/2014 06:00	13.2	1,841.9	1.0	0.7	1	1	1
07/31/2014 07:00	13.2	1,844.5	1.0	0.7	1	1	1
07/31/2014 08:00	13.1	1,848.1	1.0	0.7	1	1	1
07/31/2014 09:00	12.7	1,924.6	1.1	0.8	1	1	1
07/31/2014 10:00	11.4	2,173.3	1.3	1.1	1	1	1
07/31/2014 11:00	11.2	2,198.8	1.4	1.1	1	1	1
07/31/2014 12:00	11.3	2,162.8	1.4	1.1	1	1	1
07/31/2014 13:00	13.4	1,709.8	1.1	0.7	1	1	1
07/31/2014 14:00	12.6	1,907.6	1.1	0.8	1	1	1
07/31/2014 15:00	12.2	1,983.5	1.2	1.0	1	1	1
07/31/2014 16:00	12.1	1,990.1	1.2	1.0	1	1	1
07/31/2014 17:00	12.0	1,996.9	1.2	1.0	1	1	1
07/31/2014 18:00	12.1	1,988.2	1.2	1.0	1	1	1
07/31/2014 19:00	12.2	1,975.8	1.2	1.0	1	1	1
07/31/2014 20:00	12.2	1,968.1	1.2	1.0	1	1	1
07/31/2014 21:00	12.4	1,954.5	1.2	1.0	1	1	1
07/31/2014 22:00	12.8	1,881.2	1.1	0.8	1	1	1
07/31/2014 23:00	12.8	1,880.0	1.1	0.8	1	1	1
Average/Sum#:	12.6	1,915.5	1.1	0.9	24 #	24 #	23 #
Minimum:	11.2	1,696.9	1.0	0.7	1	1	0
Maximum:	13.7	2,198.8	1.4	1.1	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/01/2014 00:00	12.9	1,882.6	1.0	0.8	1	1	1
08/01/2014 01:00	13.6	1,580.9	1.0	0.6	1	1	1
08/01/2014 02:00	13.6	1,595.6	1.0	0.6	1	1	1
08/01/2014 03:00	13.0	1,886.0	1.0	0.8	1	1	1
08/01/2014 04:00	13.2	1,855.3	1.0	0.7	1	1	1
08/01/2014 05:00	13.0	1,899.0	1.0	0.8	1	1	1
08/01/2014 06:00	13.3	1,839.5	1.0	0.7	1	1	1
08/01/2014 07:00	13.2	1,837.6	1.0	0.7	1	1	1
08/01/2014 08:00	12.9	1,897.0	1.0	0.8	1	1	1
08/01/2014 09:00	12.3	2,008.9	1.1	0.8	1	1	1
08/01/2014 10:00	11.6	2,117.8	1.3	1.1	1	1	1
08/01/2014 11:00	11.3	2,189.8	1.3	1.1	1	1	1
08/01/2014 12:00	11.4	2,152.1	1.3	1.1	1	1	1
08/01/2014 13:00	11.4	2,138.7	1.3	1.1	1	1	1
08/01/2014 14:00	11.4	2,132.4	1.3	1.1	1	1	1
08/01/2014 15:00	11.5	2,092.1	1.3	1.0	1	1	1
08/01/2014 16:00	11.9	2,032.0	1.2	1.0	1	1	1
08/01/2014 17:00	12.1	1,997.9	1.2	1.0	1	1	1
08/01/2014 18:00	12.2	1,991.2	1.2	1.0	1	1	1
08/01/2014 19:00	12.3	1,990.8	1.1	0.8	1	1	1
08/01/2014 20:00	12.7	1,929.1	1.1	0.8	1	1	1
08/01/2014 21:00	12.9	1,900.9	1.0	0.8	1	1	1
08/01/2014 22:00	12.9	1,888.8	1.0	0.8	1	1	1
08/01/2014 23:00	12.7	1,926.6	1.1	0.8	1	1	1
Average/Sum#:	12.5	1,948.4	1.1	0.9	24 #	24 #	24 #
Minimum:	11.3	1,580.9	1.0	0.6	1	1	1
Maximum:	13.6	2,189.8	1.3	1.1	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/02/2014 00:00	13.0	1,872.6	1.0	0.7	1	1	1
08/02/2014 01:00	13.2	1,847.7	1.0	0.7	1	1	1
08/02/2014 02:00	13.2	1,825.1	1.0	0.7	1	1	1
08/02/2014 03:00	13.9	1,304.0	1.1	0.5	1	1	0
08/02/2014 04:00	13.8	1,477.1	1.0	0.6	1	1	0
08/02/2014 05:00	13.9	1,262.5	1.2	0.6	1	1	0
08/02/2014 06:00	13.8	1,238.2	1.2	0.6	1	1	0
08/02/2014 07:00	13.6	1,515.0	1.0	0.6	1	1	1
08/02/2014 08:00	13.2	1,849.6	1.0	0.7	1	1	1
08/02/2014 09:00	13.3	1,821.1	0.9	0.5	1	1	1
08/02/2014 10:00	13.2	1,832.7	1.0	0.7	1	1	1
08/02/2014 11:00	13.0	1,877.3	1.0	0.8	1	1	1
08/02/2014 12:00	12.8	1,918.0	1.0	0.8	1	1	1
08/02/2014 13:00	12.7	1,915.7	1.0	0.8	1	1	1
08/02/2014 14:00	12.9	1,858.2	1.0	0.7	1	1	1
08/02/2014 15:00	12.8	1,875.9	1.0	0.8	1	1	1
08/02/2014 16:00	12.7	1,887.9	1.0	0.8	1	1	1
08/02/2014 17:00	12.5	1,917.1	1.1	0.8	1	1	1
08/02/2014 18:00	12.6	1,906.0	1.1	0.8	1	1	1
08/02/2014 19:00	12.3	1,980.7	1.1	0.8	1	1	1
08/02/2014 20:00	12.3	1,977.1	1.1	0.8	1	1	1
08/02/2014 21:00	12.7	1,896.7	1.1	0.8	1	1	1
08/02/2014 22:00	13.6	1,535.9	1.0	0.6	1	1	1
08/02/2014 23:00	13.9	1,276.1	1.1	0.5	1	1	0
Average/Sum#:	13.1	1,736.2	1.0	0.7	24 #	24 #	19 #
Minimum:	12.3	1,238.2	0.9	0.5	1	1	0
Maximum:	13.9	1,980.7	1.2	0.8	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/03/2014 00:00	13.8	1,594.3	1.0	0.6	1	1	0
08/03/2014 01:00	13.8	1,487.0	1.0	0.6	1	1	0
08/03/2014 02:00	13.8	1,410.3	1.0	0.6	1	1	0
08/03/2014 03:00	13.8	1,601.4	1.0	0.6	1	1	0
08/03/2014 04:00	13.7	1,750.3	1.0	0.7	1	1	1
08/03/2014 05:00	13.4	1,821.6	0.9	0.5	1	1	1
08/03/2014 06:00	13.3	1,826.7	0.9	0.5	1	1	1
08/03/2014 07:00	12.8	1,939.5	1.0	0.8	1	1	1
08/03/2014 08:00	13.0	1,894.5	1.0	0.8	1	1	1
08/03/2014 09:00	13.0	1,883.2	1.0	0.8	1	1	1
08/03/2014 10:00	12.9	1,895.8	1.0	0.8	1	1	1
08/03/2014 11:00	12.8	1,903.6	1.0	0.8	1	1	1
08/03/2014 12:00	12.8	1,900.0	1.0	0.8	1	1	1
08/03/2014 13:00	11.9	2,068.1	1.2	1.0	1	1	1
08/03/2014 14:00	12.3	1,978.0	1.1	0.8	1	1	1
08/03/2014 15:00	11.7	2,102.8	1.2	1.1	1	1	1
08/03/2014 16:00	12.4	1,953.9	1.1	0.8	1	1	1
08/03/2014 17:00	12.5	1,941.1	1.0	0.8	1	1	1
08/03/2014 18:00	12.9	1,872.3	1.0	0.7	1	1	1
08/03/2014 19:00	12.6	1,945.1	1.0	0.8	1	1	1
08/03/2014 20:00	12.6	1,952.5	1.0	0.8	1	1	1
08/03/2014 21:00	13.0	1,864.0	0.9	0.6	1	1	1
08/03/2014 22:00	13.0	1,857.4	1.0	0.7	1	1	1
08/03/2014 23:00	12.8	1,935.0	1.0	0.8	1	1	1
Average/Sum#:	12.9	1,849.1	1.0	0.7	24 #	24 #	20 #
Minimum:	11.7	1,410.3	0.9	0.5	1	1	0
Maximum:	13.8	2,102.8	1.2	1.1	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/04/2014 00:00	13.1	1,876.1	0.9	0.6	1	1	1
08/04/2014 01:00	13.0	1,902.5	1.0	0.8	1	1	1
08/04/2014 02:00	13.2	1,866.0	0.9	0.6	1	1	1
08/04/2014 03:00	12.9	1,917.3	1.0	0.8	1	1	1
08/04/2014 04:00	13.3	1,842.2	0.9	0.6	1	1	1
08/04/2014 05:00	13.2	1,823.2	1.0	0.7	1	1	1
08/04/2014 06:00	13.7	1,705.6	0.9	0.5	1	1	0
08/04/2014 07:00	13.7	1,676.5	0.9	0.5	1	1	0
08/04/2014 08:00	13.6	1,758.9	0.9	0.5	1	1	0
08/04/2014 09:00	13.6	1,756.8	0.9	0.5	1	1	0
08/04/2014 10:00	13.2	1,801.5	0.9	0.5	1	1	1
08/04/2014 11:00	12.9	1,902.7	1.0	0.8	1	1	1
08/04/2014 12:00	13.2	1,837.9	0.9	0.6	1	1	1
08/04/2014 13:00	13.1	1,842.0	0.9	0.6	1	1	1
08/04/2014 14:00	13.1	1,846.3	0.9	0.6	1	1	1
08/04/2014 15:00	13.0	1,852.9	0.9	0.6	1	1	1
08/04/2014 16:00	13.1	1,839.8	0.8	0.6	1	1	1
08/04/2014 17:00	13.1	1,843.3	0.8	0.6	1	1	1
08/04/2014 18:00	13.1	1,839.7	0.8	0.6	1	1	1
08/04/2014 19:00	13.2	1,836.8	0.8	0.6	1	1	1
08/04/2014 20:00	13.2	1,836.6	0.8	0.6	1	1	1
08/04/2014 21:00	13.3	1,583.2	1.1	0.6	1	1	1
08/04/2014 22:00	13.8	1,280.5	1.3	0.6	1	1	0
08/04/2014 23:00	13.7	1,613.8	0.9	0.5	1	1	0
Average/Sum#:	13.3	1,786.8	0.9	0.6	24 #	24 #	18 #
Minimum:	12.9	1,280.5	0.8	0.5	1	1	0
Maximum:	13.8	1,917.3	1.3	0.8	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/05/2014 00:00	13.4	1,770.6	0.8	0.5	1	1	1
08/05/2014 01:00	12.9	1,895.1	0.9	0.6	1	1	1
08/05/2014 02:00	12.7	1,928.9	0.9	0.6	1	1	1
08/05/2014 03:00	12.9	1,905.5	0.9	0.6	1	1	1
08/05/2014 04:00	12.9	1,910.8	0.9	0.6	1	1	1
08/05/2014 05:00	13.2	1,840.4	0.8	0.6	1	1	1
08/05/2014 06:00	13.1	1,874.7	0.8	0.6	1	1	1
08/05/2014 07:00	13.8	1,295.7	1.3	0.6	1	1	1
08/05/2014 08:00	13.8	1,250.1	1.3	0.6	1	1	0
08/05/2014 09:00	13.3	1,571.2	1.1	0.6	1	1	1
08/05/2014 10:00	13.2	1,845.2	0.8	0.6	1	1	1
08/05/2014 11:00	13.2	1,853.8	0.8	0.6	1	1	1
08/05/2014 12:00	13.0	1,891.0	0.8	0.6	1	1	1
08/05/2014 13:00	12.8	1,920.8	0.9	0.6	1	1	1
08/05/2014 14:00	12.7	1,928.8	0.9	0.6	1	1	1
08/05/2014 15:00	12.6	1,965.0	0.9	0.6	1	1	1
08/05/2014 16:00	12.8	1,922.0	0.9	0.6	1	1	1
08/05/2014 17:00	12.7	1,930.2	1.0	0.8	1	1	1
08/05/2014 18:00	12.7	1,940.8	1.0	0.8	1	1	1
08/05/2014 19:00	12.6	1,953.7	1.0	0.8	1	1	1
08/05/2014 20:00	12.9	1,894.6	1.0	0.8	1	1	1
08/05/2014 21:00	12.8	1,905.6	1.0	0.8	1	1	1
08/05/2014 22:00	13.4	1,474.3	1.1	0.6	1	1	1
08/05/2014 23:00	13.5	1,529.9	1.0	0.6	1	1	1
Average/Sum#:	13.0	1,799.9	1.0	0.6	24 #	24 #	23 #
Minimum:	12.6	1,250.1	0.8	0.5	1	1	0
Maximum:	13.8	1,965.0	1.3	0.8	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/06/2014 00:00	12.7	1,939.1	1.0	0.8	1	1	1
08/06/2014 01:00	12.6	1,957.6	1.0	0.8	1	1	1
08/06/2014 02:00	12.9	1,897.7	1.0	0.8	1	1	1
08/06/2014 03:00	13.2	1,847.4	0.9	0.6	1	1	1
08/06/2014 04:00	12.6	1,966.1	1.1	0.8	1	1	1
08/06/2014 05:00	12.4	2,002.7	1.1	0.8	1	1	1
08/06/2014 06:00	12.7	1,933.5	1.0	0.8	1	1	1
08/06/2014 07:00	12.9	1,909.7	1.0	0.8	1	1	1
08/06/2014 08:00	12.6	1,955.9	1.0	0.8	1	1	1
08/06/2014 09:00	12.3	2,003.0	1.1	0.8	1	1	1
08/06/2014 10:00	12.1	2,016.5	1.2	1.0	1	1	1
08/06/2014 11:00	12.1	2,033.1	1.2	1.0	1	1	1
08/06/2014 12:00	12.3	1,999.7	1.1	0.8	1	1	1
08/06/2014 13:00	12.3	1,990.4	1.1	0.8	1	1	1
08/06/2014 14:00	12.0	2,050.3	1.2	1.0	1	1	1
08/06/2014 15:00	12.3	1,977.6	1.1	0.8	1	1	1
08/06/2014 16:00	12.9	1,857.3	1.0	0.7	1	1	1
08/06/2014 17:00	12.5	1,934.1	1.1	0.8	1	1	1
08/06/2014 18:00	12.4	1,947.8	1.1	0.8	1	1	1
08/06/2014 19:00	12.3	1,987.3	1.1	0.8	1	1	1
08/06/2014 20:00	12.3	1,982.5	1.1	0.8	1	1	1
08/06/2014 21:00	12.6	1,908.0	1.1	0.8	1	1	1
08/06/2014 22:00	13.4	1,449.7	1.1	0.6	1	1	1
08/06/2014 23:00	16.4	352.1	7.8 *	1.1	1	0	0
Average/Sum#:	12.7	1,870.8	1.4	0.8	24 #	23 #	23 #
Minimum:	12.0	352.1	0.9	0.6	1	0	0
Maximum:	16.4	2,050.3	7.8	1.1	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/07/2014 00:00	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 01:00	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 02:00	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 03:00	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 04:00	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 05:00	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 06:00	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 07:00	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 08:00	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 09:00	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 10:00	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 11:00	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 12:00	0.0	0.0	0.0	0.0	0	0	0
08/07/2014 13:00	17.8	356.8	0.0	0.0	1	0	0
08/07/2014 14:00	16.4	617.1	0.0	0.0	1	0	0
08/07/2014 15:00	13.1	1,686.6	1.6	1.0	1	0	1
08/07/2014 16:00	12.1	1,982.6	1.3	1.0	1	1	1
08/07/2014 17:00	11.7	2,066.4	1.3	1.0	1	1	1
08/07/2014 18:00	11.8	1,997.5	1.3	1.0	1	1	1
08/07/2014 19:00	12.3	1,951.6	1.2	1.0	1	1	1
08/07/2014 20:00	13.0	1,838.9	1.1	0.7	1	1	1
08/07/2014 21:00	12.9	1,864.6	1.1	0.7	1	1	1
08/07/2014 22:00	13.2	1,813.9	1.0	0.7	1	1	1
08/07/2014 23:00	13.3	1,807.8	1.0	0.7	1	1	1
Average/Sum#:	13.4	1,634.9	1.1	0.8	11 #	8 #	9 #
Minimum:	11.7	356.8	0.0	0.0	0	0	0
Maximum:	17.8	2,066.4	1.6	1.0	1	1	1
%SI	54.2	54.2	58.3	58.3	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/08/2014 00:00	12.8	1,908.2	1.1	0.8	1	1	1
08/08/2014 01:00	12.9	1,893.2	1.1	0.8	1	1	1
08/08/2014 02:00	13.3	1,816.6	1.0	0.7	1	1	1
08/08/2014 03:00	13.1	1,865.7	1.1	0.7	1	1	1
08/08/2014 04:00	13.0	1,898.1	1.1	0.8	1	1	1
08/08/2014 05:00	12.7	1,945.7	1.1	0.8	1	1	1
08/08/2014 06:00	12.7	1,946.5	1.2	1.0	1	1	1
08/08/2014 07:00	12.9	1,910.0	1.1	0.8	1	1	1
08/08/2014 08:00	13.0	1,875.9	1.1	0.8	1	1	1
08/08/2014 09:00	11.7	2,132.5	1.3	1.1	1	1	1
08/08/2014 10:00	12.1	2,030.3	1.3	1.0	1	1	1
08/08/2014 11:00	13.0	1,842.8	1.1	0.7	1	1	1
08/08/2014 12:00	12.9	1,878.4	1.1	0.8	1	1	1
08/08/2014 13:00	12.3	1,990.7	1.2	1.0	1	1	1
08/08/2014 14:00	11.7	2,106.2	1.3	1.1	1	1	1
08/08/2014 15:00	11.6	2,100.8	1.4	1.1	1	1	1
08/08/2014 16:00	11.6	2,083.1	1.4	1.0	1	1	1
08/08/2014 17:00	12.1	2,011.2	1.3	1.0	1	1	1
08/08/2014 18:00	11.5	2,135.6	1.4	1.1	1	1	1
08/08/2014 19:00	11.8	2,058.0	1.3	1.0	1	1	1
08/08/2014 20:00	12.4	1,971.0	1.2	1.0	1	1	1
08/08/2014 21:00	12.4	1,955.4	1.2	1.0	1	1	1
08/08/2014 22:00	12.9	1,872.9	1.1	0.7	1	1	1
08/08/2014 23:00	12.5	1,948.2	1.2	1.0	1	1	1
Average/Sum#:	12.5	1,965.7	1.2	0.9	24 #	24 #	24 #
Minimum:	11.5	1,816.6	1.0	0.7	1	1	1
Maximum:	13.3	2,135.6	1.4	1.1	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/09/2014 00:00	13.6	1,698.3	1.1	0.7	1	1	1
08/09/2014 01:00	13.7	1,544.6	1.1	0.6	1	1	0
08/09/2014 02:00	15.7	571.0	4.7	1.0	1	0	0
08/09/2014 03:00	0.0	0.0	0.0	0.0	0	0	0
08/09/2014 04:00	0.0	0.0	0.0	0.0	0	0	0
08/09/2014 05:00	0.0	0.0	0.0	0.0	0	0	0
08/09/2014 06:00	0.0	0.0	0.0	0.0	0	0	0
08/09/2014 07:00	0.0	0.0	0.0	0.0	0	0	0
08/09/2014 08:00	0.0	0.0	0.0	0.0	0	0	0
08/09/2014 09:00	0.0	0.0	0.0	0.0	0	0	0
08/09/2014 10:00	16.7	556.0	0.0	0.0	1	0	0
08/09/2014 11:00	14.0	1,405.4	1.8	1.0	1	0	0
08/09/2014 12:00	13.7	1,467.0	1.1	0.6	1	1	1
08/09/2014 13:00	13.0	1,843.8	1.1	0.7	1	1	1
08/09/2014 14:00	13.0	1,867.8	1.1	0.7	1	1	1
08/09/2014 15:00	12.6	1,915.0	1.2	1.0	1	1	1
08/09/2014 16:00	12.7	1,901.3	1.1	0.8	1	1	1
08/09/2014 17:00	12.8	1,899.9	1.1	0.8	1	1	1
08/09/2014 18:00	12.2	2,014.3	1.2	1.0	1	1	1
08/09/2014 19:00	11.4	2,172.3	1.4	1.1	1	1	1
08/09/2014 20:00	11.8	2,098.2	1.4	1.0	1	1	1
08/09/2014 21:00	12.0	2,071.3	1.3	1.0	1	1	1
08/09/2014 22:00	12.5	1,982.5	1.2	1.0	1	1	1
08/09/2014 23:00	13.4	1,683.2	1.1	0.7	1	1	1
Average/Sum#:	13.2	1,687.8	1.4	0.8	17 #	14 #	13 #
Minimum:	11.4	556.0	0.0	0.0	0	0	0
Maximum:	16.7	2,172.3	4.7	1.1	1	1	1
%SI	29.2	29.2	29.2	29.2	0	0	0

Daily Summary Report

CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/10/2014 00:00	15.7	567.0	4.4	1.0	1	0	0
08/10/2014 01:00	0.0	0.0	0.0	0.0	0	0	0
08/10/2014 02:00	0.0	0.0	0.0	0.0	0	0	0
08/10/2014 03:00	0.0	0.0	0.0	0.0	0	0	0
08/10/2014 04:00	0.0	0.0	0.0	0.0	0	0	0
08/10/2014 05:00	0.0	0.0	0.0	0.0	0	0	0
08/10/2014 06:00	0.0	0.0	0.0	0.0	0	0	0
08/10/2014 07:00	0.0	0.0	0.0	0.0	0	0	0
08/10/2014 08:00	0.0	0.0	0.0	0.0	0	0	0
08/10/2014 09:00	0.0	0.0	0.0	0.0	0	0	0
08/10/2014 10:00	0.0	0.0	0.0	0.0	0	0	0
08/10/2014 11:00	17.0	530.2	0.0	0.0	1	0	0
08/10/2014 12:00	13.9	1,435.1	1.9	1.0	1	0	1
08/10/2014 13:00	12.7	1,914.3	1.1	0.8	1	1	1
08/10/2014 14:00	12.6	1,912.1	1.2	1.0	1	1	1
08/10/2014 15:00	12.9	1,875.4	1.1	0.8	1	1	1
08/10/2014 16:00	12.4	1,974.4	1.2	1.0	1	1	1
08/10/2014 17:00	11.4	2,151.8	1.4	1.1	1	1	1
08/10/2014 18:00	11.6	2,138.3	1.4	1.1	1	1	1
08/10/2014 19:00	11.5	2,142.8	1.4	1.1	1	1	1
08/10/2014 20:00	11.7	2,123.3	1.4	1.1	1	1	1
08/10/2014 21:00	11.9	2,069.6	1.3	1.0	1	1	1
08/10/2014 22:00	12.8	1,901.0	1.1	0.8	1	1	1
08/10/2014 23:00	12.6	1,952.3	1.2	1.0	1	1	1
Average/Sum#:	12.9	1,763.4	1.4	0.9	14 #	11 #	12 #
Minimum:	11.4	530.2	0.0	0.0	0	0	0
Maximum:	17.0	2,151.8	4.4	1.1	1	1	1
%SI	41.7	41.7	41.7	41.7	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/11/2014 00:00	12.7	1,948.6	1.2	1.0	1	1	1
08/11/2014 01:00	12.7	1,949.9	1.2	1.0	1	1	1
08/11/2014 02:00	12.9	1,911.4	1.1	0.8	1	1	1
08/11/2014 03:00	12.7	1,955.1	1.2	1.0	1	1	1
08/11/2014 04:00	12.7	1,970.2	1.2	1.0	1	1	1
08/11/2014 05:00	12.9	1,923.2	1.1	0.8	1	1	1
08/11/2014 06:00	11.7	2,137.4	1.4	1.1	1	1	1
08/11/2014 07:00	12.6	1,979.0	1.2	1.0	1	1	1
08/11/2014 08:00	12.6	1,964.2	1.2	1.0	1	1	1
08/11/2014 09:00	11.4	2,182.3	1.4	1.1	1	1	1
08/11/2014 10:00	11.2	2,222.1	1.5	1.3	1	1	1
08/11/2014 11:00	11.1	2,231.4	1.5	1.3	1	1	1
08/11/2014 12:00	11.1	2,221.3	1.5	1.3	1	1	1
08/11/2014 13:00	11.3	2,196.8	1.5	1.3	1	1	1
08/11/2014 14:00	11.3	2,167.6	1.6	1.3	1	1	1
08/11/2014 15:00	11.3	2,155.3	1.4	1.1	1	1	1
08/11/2014 16:00	11.3	2,162.5	1.4	1.1	1	1	1
08/11/2014 17:00	11.2	2,176.5	1.4	1.1	1	1	1
08/11/2014 18:00	11.3	2,170.9	1.4	1.1	1	1	1
08/11/2014 19:00	11.2	2,201.0	1.5	1.3	1	1	1
08/11/2014 20:00	11.4	2,168.7	1.5	1.3	1	1	1
08/11/2014 21:00	12.6	1,916.0	1.2	1.0	1	1	1
08/11/2014 22:00	13.8	1,694.3	1.0	0.7	1	1	0
08/11/2014 23:00	13.7	1,681.0	1.0	0.7	1	1	0
Average/Sum#:	12.0	2,053.6	1.3	1.1	24 #	24 #	22 #
Minimum:	11.1	1,681.0	1.0	0.7	1	1	0
Maximum:	13.8	2,231.4	1.6	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/12/2014 00:00	13.8	1,638.6	1.0	0.7	1	1	0
08/12/2014 01:00	13.8	1,665.7	1.0	0.7	1	1	0
08/12/2014 02:00	13.8	1,537.8	1.1	0.6	1	1	0
08/12/2014 03:00	13.8	1,529.6	1.0	0.6	1	1	0
08/12/2014 04:00	13.8	1,692.4	1.0	0.7	1	1	0
08/12/2014 05:00	13.7	1,762.6	1.0	0.7	1	1	0
08/12/2014 06:00	13.7	1,763.6	1.0	0.7	1	1	0
08/12/2014 07:00	13.7	1,727.9	1.1	0.7	1	1	0
08/12/2014 08:00	13.8	1,307.3	1.1	0.5	1	1	0
08/12/2014 09:00	13.8	1,633.8	1.0	0.7	1	1	0
08/12/2014 10:00	13.6	1,747.8	1.0	0.7	1	1	0
08/12/2014 11:00	13.8	1,648.9	1.0	0.7	1	1	0
08/12/2014 12:00	13.7	1,747.5	1.0	0.7	1	1	0
08/12/2014 13:00	13.7	1,744.8	1.0	0.7	1	1	0
08/12/2014 14:00	13.7	1,738.7	1.0	0.7	1	1	0
08/12/2014 15:00	13.7	1,733.5	1.0	0.7	1	1	0
08/12/2014 16:00	13.7	1,736.9	1.0	0.7	1	1	0
08/12/2014 17:00	13.7	1,743.3	1.0	0.7	1	1	0
08/12/2014 18:00	13.7	1,748.3	1.0	0.7	1	1	0
08/12/2014 19:00	13.7	1,758.2	1.0	0.7	1	1	0
08/12/2014 20:00	13.6	1,767.2	1.0	0.7	1	1	0
08/12/2014 21:00	13.6	1,771.8	1.0	0.7	1	1	0
08/12/2014 22:00	13.6	1,777.3	1.0	0.7	1	1	0
08/12/2014 23:00	13.6	1,779.5	1.0	0.7	1	1	0
Average/Sum#:	13.7	1,696.0	1.0	0.7	24 #	24 #	0 #
Minimum:	13.6	1,307.3	1.0	0.5	1	1	0
Maximum:	13.8	1,779.5	1.1	0.7	1	1	0
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/13/2014 00:00	13.6	1,772.6	1.0	0.7	1	1	0
08/13/2014 01:00	14.2	1,386.5	1.5	0.8	1	0	0
08/13/2014 02:00	0.0	0.0	0.0	0.0	0	0	0
08/13/2014 03:00	0.0	0.0	0.0	0.0	0	0	0
08/13/2014 04:00	0.0	0.0	0.0	0.0	0	0	0
08/13/2014 05:00	0.0	0.0	0.0	0.0	0	0	0
08/13/2014 06:00	0.0	0.0	0.0	0.0	0	0	0
08/13/2014 07:00	0.0	0.0	0.0	0.0	0	0	0
08/13/2014 08:00	17.3	482.5	0.0	0.0	1	0	0
08/13/2014 09:00	14.9	1,149.6	2.3	1.0	1	0	0
08/13/2014 10:00	13.6	1,763.0	1.1	0.7	1	1	0
08/13/2014 11:00	13.6	1,756.0	1.0	0.7	1	1	0
08/13/2014 12:00	13.6	1,759.7	1.0	0.7	1	1	0
08/13/2014 13:00	13.6	1,754.9	1.0	0.7	1	1	0
08/13/2014 14:00	13.6	1,744.0	1.0	0.7	1	1	0
08/13/2014 15:00	13.7	1,728.3	1.0	0.7	1	1	0
08/13/2014 16:00	13.7	1,725.7	1.0	0.7	1	1	0
08/13/2014 17:00	13.7	1,726.2	1.0	0.7	1	1	0
08/13/2014 18:00	13.6	1,728.7	1.1	0.7	1	1	0
08/13/2014 19:00	13.6	1,735.5	1.1	0.7	1	1	0
08/13/2014 20:00	13.6	1,746.5	1.1	0.7	1	1	0
08/13/2014 21:00	13.7	1,731.8	1.0	0.7	1	1	0
08/13/2014 22:00	13.8	1,649.9	1.0	0.7	1	1	0
08/13/2014 23:00	14.9	929.1	2.3	0.8	1	0	0
Average/Sum#:	14.0	1,570.6	1.1	0.7	18 #	14 #	0 #
Minimum:	13.6	482.5	0.0	0.0	0	0	0
Maximum:	17.3	1,772.6	2.3	1.0	1	1	0
%SI	25.0	25.0	25.0	25.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/14/2014 00:00	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 01:00	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 02:00	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 03:00	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 04:00	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 05:00	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 06:00	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 07:00	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 08:00	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 09:00	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 10:00	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 11:00	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 12:00	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 13:00	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 14:00	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 15:00	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 16:00	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 17:00	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 18:00	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 19:00	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 20:00	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 21:00	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 22:00	0.0	0.0	0.0	0.0	0	0	0
08/14/2014 23:00	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/15/2014 00:00	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 01:00	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 02:00	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 03:00	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 04:00	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 05:00	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 06:00	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 07:00	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 08:00	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 09:00	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 10:00	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 11:00	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 12:00	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 13:00	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 14:00	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 15:00	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 16:00	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 17:00	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 18:00	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 19:00	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 20:00	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 21:00	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 22:00	0.0	0.0	0.0	0.0	0	0	0
08/15/2014 23:00	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/16/2014 00:00	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 01:00	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 02:00	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 03:00	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 04:00	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 05:00	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 06:00	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 07:00	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 08:00	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 09:00	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 10:00	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 11:00	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 12:00	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 13:00	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 14:00	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 15:00	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 16:00	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 17:00	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 18:00	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 19:00	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 20:00	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 21:00	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 22:00	0.0	0.0	0.0	0.0	0	0	0
08/16/2014 23:00	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/17/2014 00:00	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 01:00	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 02:00	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 03:00	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 04:00	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 05:00	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 06:00	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 07:00	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 08:00	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 09:00	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 10:00	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 11:00	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 12:00	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 13:00	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 14:00	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 15:00	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 16:00	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 17:00	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 18:00	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 19:00	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 20:00	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 21:00	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 22:00	0.0	0.0	0.0	0.0	0	0	0
08/17/2014 23:00	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/18/2014 00:00	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 01:00	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 02:00	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 03:00	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 04:00	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 05:00	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 06:00	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 07:00	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 08:00	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 09:00	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 10:00	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 11:00	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 12:00	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 13:00	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 14:00	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 15:00	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 16:00	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 17:00	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 18:00	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 19:00	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 20:00	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 21:00	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 22:00	0.0	0.0	0.0	0.0	0	0	0
08/18/2014 23:00	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/19/2014 00:00	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 01:00	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 02:00	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 03:00	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 04:00	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 05:00	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 06:00	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 07:00	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 08:00	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 09:00	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 10:00	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 11:00	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 12:00	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 13:00	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 14:00	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 15:00	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 16:00	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 17:00	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 18:00	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 19:00	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 20:00	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 21:00	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 22:00	0.0	0.0	0.0	0.0	0	0	0
08/19/2014 23:00	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/20/2014 00:00	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 01:00	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 02:00	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 03:00	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 04:00	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 05:00	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 06:00	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 07:00	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 08:00	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 09:00	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 10:00	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 11:00	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 12:00	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 13:00	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 14:00	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 15:00	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 16:00	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 17:00	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 18:00	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 19:00	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 20:00	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 21:00	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 22:00	0.0	0.0	0.0	0.0	0	0	0
08/20/2014 23:00	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/21/2014 00:00	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 01:00	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 02:00	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 03:00	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 04:00	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 05:00	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 06:00	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 07:00	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 08:00	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 09:00	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 10:00	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 11:00	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 12:00	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 13:00	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 14:00	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 15:00	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 16:00	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 17:00	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 18:00	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 19:00	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 20:00	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 21:00	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 22:00	0.0	0.0	0.0	0.0	0	0	0
08/21/2014 23:00	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/22/2014 00:00	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 01:00	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 02:00	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 03:00	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 04:00	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 05:00	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 06:00	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 07:00	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 08:00	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 09:00	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 10:00	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 11:00	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 12:00	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 13:00	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 14:00	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 15:00	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 16:00	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 17:00	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 18:00	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 19:00	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 20:00	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 21:00	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 22:00	0.0	0.0	0.0	0.0	0	0	0
08/22/2014 23:00	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/23/2014 00:00	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 01:00	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 02:00	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 03:00	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 04:00	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 05:00	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 06:00	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 07:00	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 08:00	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 09:00	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 10:00	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 11:00	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 12:00	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 13:00	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 14:00	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 15:00	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 16:00	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 17:00	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 18:00	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 19:00	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 20:00	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 21:00	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 22:00	0.0	0.0	0.0	0.0	0	0	0
08/23/2014 23:00	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/24/2014 00:00	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 01:00	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 02:00	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 03:00	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 04:00	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 05:00	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 06:00	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 07:00	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 08:00	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 09:00	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 10:00	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 11:00	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 12:00	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 13:00	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 14:00	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 15:00	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 16:00	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 17:00	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 18:00	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 19:00	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 20:00	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 21:00	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 22:00	0.0	0.0	0.0	0.0	0	0	0
08/24/2014 23:00	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/25/2014 00:00	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 01:00	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 02:00	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 03:00	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 04:00	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 05:00	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 06:00	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 07:00	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 08:00	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 09:00	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 10:00	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 11:00	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 12:00	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 13:00	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 14:00	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 15:00	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 16:00	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 17:00	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 18:00	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 19:00	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 20:00	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 21:00	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 22:00	0.0	0.0	0.0	0.0	0	0	0
08/25/2014 23:00	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/26/2014 00:00	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 01:00	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 02:00	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 03:00	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 04:00	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 05:00	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 06:00	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 07:00	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 08:00	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 09:00	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 10:00	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 11:00	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 12:00	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 13:00	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 14:00	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 15:00	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 16:00	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 17:00	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 18:00	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 19:00	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 20:00	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 21:00	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 22:00	0.0	0.0	0.0	0.0	0	0	0
08/26/2014 23:00	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/27/2014 00:00	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 01:00	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 02:00	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 03:00	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 04:00	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 05:00	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 06:00	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 07:00	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 08:00	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 09:00	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 10:00	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 11:00	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 12:00	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 13:00	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 14:00	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 15:00	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 16:00	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 17:00	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 18:00	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 19:00	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 20:00	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 21:00	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 22:00	0.0	0.0	0.0	0.0	0	0	0
08/27/2014 23:00	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/28/2014 00:00	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 01:00	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 02:00	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 03:00	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 04:00	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 05:00	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 06:00	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 07:00	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 08:00	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 09:00	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 10:00	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 11:00	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 12:00	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 13:00	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 14:00	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 15:00	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 16:00	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 17:00	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 18:00	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 19:00	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 20:00	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 21:00	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 22:00	0.0	0.0	0.0	0.0	0	0	0
08/28/2014 23:00	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/29/2014 00:00	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 01:00	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 02:00	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 03:00	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 04:00	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 05:00	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 06:00	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 07:00	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 08:00	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 09:00	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 10:00	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 11:00	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 12:00	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 13:00	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 14:00	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 15:00	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 16:00	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 17:00	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 18:00	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 19:00	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 20:00	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 21:00	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 22:00	0.0	0.0	0.0	0.0	0	0	0
08/29/2014 23:00	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/30/2014 00:00	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 01:00	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 02:00	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 03:00	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 04:00	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 05:00	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 06:00	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 07:00	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 08:00	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 09:00	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 10:00	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 11:00	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 12:00	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 13:00	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 14:00	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 15:00	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 16:00	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 17:00	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 18:00	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 19:00	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 20:00	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 21:00	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 22:00	0.0	0.0	0.0	0.0	0	0	0
08/30/2014 23:00	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
08/31/2014 00:00	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 01:00	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 02:00	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 03:00	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 04:00	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 05:00	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 06:00	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 07:00	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 08:00	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 09:00	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 10:00	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 11:00	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 12:00	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 13:00	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 14:00	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 15:00	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 16:00	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 17:00	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 18:00	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 19:00	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 20:00	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 21:00	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 22:00	0.0	0.0	0.0	0.0	0	0	0
08/31/2014 23:00	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/01/2014 00:00	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 01:00	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 02:00	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 03:00	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 04:00	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 05:00	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 06:00	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 07:00	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 08:00	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 09:00	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 10:00	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 11:00	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 12:00	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 13:00	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 14:00	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 15:00	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 16:00	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 17:00	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 18:00	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 19:00	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 20:00	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 21:00	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 22:00	0.0	0.0	0.0	0.0	0	0	0
09/01/2014 23:00	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/02/2014 00:00	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 01:00	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 02:00	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 03:00	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 04:00	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 05:00	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 06:00	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 07:00	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 08:00	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 09:00	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 10:00	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 11:00	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 12:00	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 13:00	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 14:00	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 15:00	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 16:00	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 17:00	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 18:00	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 19:00	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 20:00	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 21:00	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 22:00	0.0	0.0	0.0	0.0	0	0	0
09/02/2014 23:00	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/03/2014 00:00	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 01:00	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 02:00	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 03:00	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 04:00	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 05:00	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 06:00	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 07:00	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 08:00	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 09:00	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 10:00	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 11:00	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 12:00	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 13:00	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 14:00	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 15:00	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 16:00	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 17:00	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 18:00	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 19:00	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 20:00	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 21:00	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 22:00	0.0	0.0	0.0	0.0	0	0	0
09/03/2014 23:00	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/04/2014 00:00	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 01:00	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 02:00	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 03:00	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 04:00	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 05:00	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 06:00	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 07:00	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 08:00	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 09:00	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 10:00	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 11:00	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 12:00	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 13:00	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 14:00	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 15:00	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 16:00	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 17:00	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 18:00	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 19:00	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 20:00	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 21:00	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 22:00	0.0	0.0	0.0	0.0	0	0	0
09/04/2014 23:00	0.0	0.0	0.0	0.0	0	0	0
Average/Sum#:	0.0	0.0	0.0	0.0	0 #	0 #	0 #
Minimum:	0.0	0.0	0.0	0.0	0	0	0
Maximum:	0.0	0.0	0.0	0.0	0	0	0
%SI	100.0	100.0	100.0	100.0	0	0	0

Daily Summary Report

CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/05/2014 00:00	0.0	0.0	0.0	0.0	0	0	0
09/05/2014 01:00	0.0	0.0	0.0	0.0	0	0	0
09/05/2014 02:00	0.0	0.0	0.0	0.0	0	0	0
09/05/2014 03:00	0.0	0.0	0.0	0.0	0	0	0
09/05/2014 04:00	0.0	0.0	0.0	0.0	0	0	0
09/05/2014 05:00	0.0	0.0	0.0	0.0	0	0	0
09/05/2014 06:00	0.0	0.0	0.0	0.0	0	0	0
09/05/2014 07:00	17.0	487.1	0.0	0.0	1	0	0
09/05/2014 08:00	15.2	906.7	2.8	1.0	1	0	0
09/05/2014 09:00	13.9	1,417.4	1.1	0.6	1	1	0
09/05/2014 10:00	13.9	1,263.2	1.1	0.5	1	1	0
09/05/2014 11:00	14.0	1,365.2	1.0	0.5	1	1	0
09/05/2014 12:00	13.4	1,677.1	1.1	0.7	1	1	1
09/05/2014 13:00	12.9	1,905.1	1.1	0.8	1	1	1
09/05/2014 14:00	12.9	1,886.0	1.1	0.8	1	1	1
09/05/2014 15:00	12.7	1,920.6	1.1	0.8	1	1	1
09/05/2014 16:00	12.7	1,926.4	1.2	1.0	1	1	1
09/05/2014 17:00	11.7	2,132.5	1.4	1.1	1	1	1
09/05/2014 18:00	12.2	2,016.0	1.3	1.0	1	1	1
09/05/2014 19:00	12.7	1,935.2	1.2	1.0	1	1	1
09/05/2014 20:00	13.2	1,837.3	1.0	0.7	1	1	1
09/05/2014 21:00	12.9	1,903.2	1.1	0.8	1	1	1
09/05/2014 22:00	12.9	1,916.4	1.1	0.8	1	1	1
09/05/2014 23:00	11.8	2,151.4	1.3	1.1	1	1	1
Average/Sum#:	13.3	1,685.1	1.2	0.8	17 #	15 #	12 #
Minimum:	11.7	487.1	0.0	0.0	0	0	0
Maximum:	17.0	2,151.4	2.8	1.1	1	1	1
%SI	29.2	29.2	29.2	29.2	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/06/2014 00:00	12.3	2,027.8	1.2	1.0	1	1	1
09/06/2014 01:00	12.9	1,908.8	1.1	0.8	1	1	1
09/06/2014 02:00	12.8	1,955.9	1.1	0.8	1	1	1
09/06/2014 03:00	12.8	1,955.5	1.1	0.8	1	1	1
09/06/2014 04:00	12.8	1,946.2	1.1	0.8	1	1	1
09/06/2014 05:00	13.3	1,831.9	1.0	0.7	1	1	1
09/06/2014 06:00	13.3	1,843.2	1.1	0.7	1	1	1
09/06/2014 07:00	13.1	1,870.2	1.1	0.7	1	1	1
09/06/2014 08:00	13.4	1,835.7	1.0	0.7	1	1	1
09/06/2014 09:00	13.1	1,903.5	1.1	0.8	1	1	1
09/06/2014 10:00	13.1	1,882.2	1.1	0.8	1	1	1
09/06/2014 11:00	13.0	1,904.9	1.1	0.8	1	1	1
09/06/2014 12:00	12.3	2,017.3	1.2	1.0	1	1	1
09/06/2014 13:00	11.5	2,179.2	1.4	1.1	1	1	1
09/06/2014 14:00	12.2	2,030.4	1.3	1.0	1	1	1
09/06/2014 15:00	12.5	1,981.4	1.2	1.0	1	1	1
09/06/2014 16:00	12.6	1,960.5	1.2	1.0	1	1	1
09/06/2014 17:00	11.3	2,211.6	1.5	1.3	1	1	1
09/06/2014 18:00	11.7	2,135.1	1.4	1.1	1	1	1
09/06/2014 19:00	13.0	1,871.8	1.1	0.7	1	1	1
09/06/2014 20:00	13.3	1,837.4	1.0	0.7	1	1	1
09/06/2014 21:00	13.3	1,838.2	1.0	0.7	1	1	1
09/06/2014 22:00	13.1	1,874.9	1.1	0.7	1	1	1
09/06/2014 23:00	12.8	1,960.5	1.1	0.8	1	1	1
Average/Sum#:	12.7	1,948.5	1.2	0.9	24 #	24 #	24 #
Minimum:	11.3	1,831.9	1.0	0.7	1	1	1
Maximum:	13.4	2,211.6	1.5	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/07/2014 00:00	13.2	1,874.5	1.0	0.7	1	1	1
09/07/2014 01:00	13.2	1,880.4	1.1	0.8	1	1	1
09/07/2014 02:00	13.4	1,833.8	1.1	0.7	1	1	1
09/07/2014 03:00	13.4	1,830.6	1.0	0.7	1	1	1
09/07/2014 04:00	13.3	1,829.8	1.0	0.7	1	1	1
09/07/2014 05:00	13.3	1,831.2	1.0	0.7	1	1	1
09/07/2014 06:00	13.3	1,825.0	1.0	0.7	1	1	1
09/07/2014 07:00	13.3	1,836.8	1.0	0.7	1	1	1
09/07/2014 08:00	13.1	1,907.6	1.1	0.8	1	1	1
09/07/2014 09:00	12.5	2,008.8	1.2	1.0	1	1	1
09/07/2014 10:00	12.0	2,096.0	1.3	1.0	1	1	1
09/07/2014 11:00	12.0	2,082.5	1.3	1.0	1	1	1
09/07/2014 12:00	12.7	1,944.2	1.2	1.0	1	1	1
09/07/2014 13:00	12.8	1,927.5	1.1	0.8	1	1	1
09/07/2014 14:00	12.8	1,919.9	1.1	0.8	1	1	1
09/07/2014 15:00	12.7	1,933.6	1.1	0.8	1	1	1
09/07/2014 16:00	12.3	2,025.2	1.2	1.0	1	1	1
09/07/2014 17:00	11.4	2,182.8	1.5	1.3	1	1	1
09/07/2014 18:00	11.4	2,181.5	1.5	1.3	1	1	1
09/07/2014 19:00	11.5	2,179.3	1.5	1.3	1	1	1
09/07/2014 20:00	12.1	2,049.1	1.3	1.0	1	1	1
09/07/2014 21:00	13.0	1,873.8	1.1	0.7	1	1	1
09/07/2014 22:00	13.3	1,832.2	1.0	0.7	1	1	1
09/07/2014 23:00	13.1	1,897.2	1.1	0.8	1	1	1
Average/Sum#:	12.7	1,949.3	1.2	0.9	24 #	24 #	24 #
Minimum:	11.4	1,825.0	1.0	0.7	1	1	1
Maximum:	13.4	2,182.8	1.5	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/08/2014 00:00	13.6	1,499.4	1.1	0.6	1	1	1
09/08/2014 01:00	13.9	1,252.9	1.1	0.5	1	1	0
09/08/2014 02:00	13.9	1,247.5	1.1	0.5	1	1	0
09/08/2014 03:00	13.8	1,552.8	1.0	0.6	1	1	1
09/08/2014 04:00	13.0	1,914.5	1.1	0.8	1	1	1
09/08/2014 05:00	13.2	1,872.9	1.0	0.7	1	1	1
09/08/2014 06:00	12.3	2,095.5	1.2	1.0	1	1	1
09/08/2014 07:00	11.2	2,271.1	1.6	1.4	1	1	1
09/08/2014 08:00	12.0	2,113.0	1.3	1.1	1	1	1
09/08/2014 09:00	13.4	1,849.0	1.0	0.7	1	1	1
09/08/2014 10:00	13.4	1,837.1	1.0	0.7	1	1	1
09/08/2014 11:00	13.4	1,835.5	1.0	0.7	1	1	1
09/08/2014 12:00	13.3	1,836.3	1.0	0.7	1	1	1
09/08/2014 13:00	13.3	1,836.4	1.0	0.7	1	1	1
09/08/2014 14:00	13.3	1,838.3	1.0	0.7	1	1	1
09/08/2014 15:00	13.2	1,843.0	1.0	0.7	1	1	1
09/08/2014 16:00	13.4	1,598.3	1.1	0.6	1	1	1
09/08/2014 17:00	14.0	1,267.0	1.1	0.5	1	1	0
09/08/2014 18:00	14.0	1,513.3	1.0	0.6	1	1	0
09/08/2014 19:00	14.0	1,527.9	1.0	0.6	1	1	0
09/08/2014 20:00	13.9	1,439.8	1.0	0.6	1	1	0
09/08/2014 21:00	13.9	1,361.4	1.1	0.5	1	1	0
09/08/2014 22:00	13.9	1,295.7	1.1	0.5	1	1	0
09/08/2014 23:00	13.9	1,251.0	1.1	0.5	1	1	0
Average/Sum#:	13.4	1,664.6	1.1	0.7	24 #	24 #	15 #
Minimum:	11.2	1,247.5	1.0	0.5	1	1	0
Maximum:	14.0	2,271.1	1.6	1.4	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/09/2014 00:00	13.9	1,251.7	1.1	0.5	1	1	0
09/09/2014 01:00	13.9	1,251.6	1.1	0.5	1	1	0
09/09/2014 02:00	13.9	1,252.0	1.1	0.5	1	1	0
09/09/2014 03:00	13.9	1,353.2	1.1	0.5	1	1	0
09/09/2014 04:00	13.9	1,265.9	1.1	0.5	1	1	0
09/09/2014 05:00	13.9	1,304.7	1.1	0.5	1	1	0
09/09/2014 06:00	13.9	1,259.0	1.1	0.5	1	1	0
09/09/2014 07:00	13.9	1,266.0	1.0	0.5	1	1	0
09/09/2014 08:00	13.7	1,561.4	1.0	0.6	1	1	1
09/09/2014 09:00	13.3	1,862.9	1.0	0.7	1	1	1
09/09/2014 10:00	13.3	1,846.7	1.0	0.7	1	1	1
09/09/2014 11:00	13.2	1,841.0	1.0	0.7	1	1	1
09/09/2014 12:00	12.9	1,905.0	1.1	0.8	1	1	1
09/09/2014 13:00	12.7	1,909.4	1.2	1.0	1	1	1
09/09/2014 14:00	12.9	1,867.0	1.1	0.7	1	1	1
09/09/2014 15:00	13.0	1,846.3	1.1	0.7	1	1	1
09/09/2014 16:00	12.9	1,841.1	1.1	0.7	1	1	1
09/09/2014 17:00	12.9	1,854.0	1.1	0.7	1	1	1
09/09/2014 18:00	13.0	1,836.8	1.1	0.7	1	1	1
09/09/2014 19:00	13.0	1,835.2	1.1	0.7	1	1	1
09/09/2014 20:00	13.0	1,859.3	1.1	0.7	1	1	1
09/09/2014 21:00	12.8	1,890.8	1.1	0.8	1	1	1
09/09/2014 22:00	13.0	1,872.5	1.1	0.7	1	1	1
09/09/2014 23:00	12.5	1,975.6	1.2	1.0	1	1	1
Average/Sum#:	13.3	1,658.7	1.1	0.7	24 #	24 #	16 #
Minimum:	12.5	1,251.6	1.0	0.5	1	1	0
Maximum:	13.9	1,975.6	1.2	1.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/10/2014 00:00	12.5	1,978.6	1.2	1.0	1	1	1
09/10/2014 01:00	12.5	1,976.5	1.2	1.0	1	1	1
09/10/2014 02:00	13.0	1,874.7	1.1	0.7	1	1	1
09/10/2014 03:00	12.7	1,944.2	1.2	1.0	1	1	1
09/10/2014 04:00	12.4	1,996.4	1.3	1.0	1	1	1
09/10/2014 05:00	12.8	1,935.7	1.1	0.8	1	1	1
09/10/2014 06:00	13.3	1,831.2	1.0	0.7	1	1	1
09/10/2014 07:00	13.3	1,828.7	1.0	0.7	1	1	1
09/10/2014 08:00	13.3	1,828.2	1.0	0.7	1	1	1
09/10/2014 09:00	12.9	1,886.9	1.1	0.8	1	1	1
09/10/2014 10:00	13.6	1,537.8	1.1	0.6	1	1	1
09/10/2014 11:00	14.0	1,256.9	1.1	0.5	1	1	0
09/10/2014 12:00	13.4	1,709.3	1.1	0.7	1	1	1
09/10/2014 13:00	12.9	1,906.8	1.1	0.8	1	1	1
09/10/2014 14:00	12.7	1,952.5	1.2	1.0	1	1	1
09/10/2014 15:00	11.6	2,159.4	1.4	1.1	1	1	1
09/10/2014 16:00	11.3	2,208.6	1.5	1.3	1	1	1
09/10/2014 17:00	11.3	2,209.1	1.5	1.3	1	1	1
09/10/2014 18:00	11.4	2,186.6	1.5	1.3	1	1	1
09/10/2014 19:00	11.7	2,140.0	1.4	1.1	1	1	1
09/10/2014 20:00	12.0	2,069.1	1.3	1.0	1	1	1
09/10/2014 21:00	12.4	2,018.2	1.2	1.0	1	1	1
09/10/2014 22:00	12.5	2,006.7	1.2	1.0	1	1	1
09/10/2014 23:00	12.1	2,085.9	1.3	1.0	1	1	1
Average/Sum#:	12.6	1,938.7	1.2	0.9	24 #	24 #	23 #
Minimum:	11.3	1,256.9	1.0	0.5	1	1	0
Maximum:	14.0	2,209.1	1.5	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/11/2014 00:00	12.8	1,941.4	1.1	0.8	1	1	1
09/11/2014 01:00	13.3	1,840.4	1.0	0.7	1	1	1
09/11/2014 02:00	13.3	1,840.4	1.0	0.7	1	1	1
09/11/2014 03:00	13.3	1,839.9	1.0	0.7	1	1	1
09/11/2014 04:00	13.0	1,917.6	1.1	0.8	1	1	1
09/11/2014 05:00	12.3	2,051.4	1.2	1.0	1	1	1
09/11/2014 06:00	12.7	1,972.7	1.2	1.0	1	1	1
09/11/2014 07:00	12.8	1,957.7	1.1	0.8	1	1	1
09/11/2014 08:00	12.9	1,933.8	1.1	0.8	1	1	1
09/11/2014 09:00	12.7	1,978.6	1.1	0.8	1	1	1
09/11/2014 10:00	12.2	2,066.1	1.3	1.0	1	1	1
09/11/2014 11:00	11.9	2,091.6	1.3	1.0	1	1	1
09/11/2014 12:00	12.9	1,892.4	1.1	0.8	1	1	1
09/11/2014 13:00	12.9	1,884.0	1.1	0.8	1	1	1
09/11/2014 14:00	13.0	1,863.3	1.1	0.7	1	1	1
09/11/2014 15:00	13.0	1,872.0	1.1	0.7	1	1	1
09/11/2014 16:00	12.1	2,072.6	1.3	1.0	1	1	1
09/11/2014 17:00	11.4	2,191.8	1.4	1.1	1	1	1
09/11/2014 18:00	11.3	2,211.6	1.5	1.3	1	1	1
09/11/2014 19:00	11.6	2,147.1	1.4	1.1	1	1	1
09/11/2014 20:00	11.6	2,154.3	1.4	1.1	1	1	1
09/11/2014 21:00	12.4	1,995.9	1.2	1.0	1	1	1
09/11/2014 22:00	12.3	2,035.0	1.2	1.0	1	1	1
09/11/2014 23:00	11.4	2,231.2	1.5	1.3	1	1	1
Average/Sum#:	12.5	1,999.3	1.2	0.9	24 #	24 #	24 #
Minimum:	11.3	1,839.9	1.0	0.7	1	1	1
Maximum:	13.3	2,231.2	1.5	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/12/2014 00:00	11.8	2,143.7	1.4	1.1	1	1	1
09/12/2014 01:00	12.8	1,908.6	1.1	0.8	1	1	1
09/12/2014 02:00	12.3	1,986.1	1.2	1.0	1	1	1
09/12/2014 03:00	12.3	2,018.6	1.2	1.0	1	1	1
09/12/2014 04:00	11.5	2,219.1	1.5	1.3	1	1	1
09/12/2014 05:00	11.7	2,185.3	1.4	1.1	1	1	1
09/12/2014 06:00	11.5	2,230.8	1.5	1.3	1	1	1
09/12/2014 07:00	11.6	2,207.0	1.6	1.3	1	1	1
09/12/2014 08:00	11.9	2,125.9	1.3	1.1	1	1	1
09/12/2014 09:00	11.5	2,208.4	1.5	1.3	1	1	1
09/12/2014 10:00	11.6	2,192.6	1.4	1.1	1	1	1
09/12/2014 11:00	11.5	2,188.0	1.4	1.1	1	1	1
09/12/2014 12:00	11.4	2,204.7	1.5	1.3	1	1	1
09/12/2014 13:00	11.3	2,211.7	1.5	1.3	1	1	1
09/12/2014 14:00	11.4	2,172.6	1.4	1.1	1	1	1
09/12/2014 15:00	11.4	2,171.6	1.4	1.1	1	1	1
09/12/2014 16:00	11.4	2,161.7	1.4	1.1	1	1	1
09/12/2014 17:00	11.3	2,193.2	1.5	1.3	1	1	1
09/12/2014 18:00	11.3	2,206.3	1.5	1.3	1	1	1
09/12/2014 19:00	11.2	2,225.5	1.6	1.3	1	1	1
09/12/2014 20:00	11.7	2,163.5	1.4	1.1	1	1	1
09/12/2014 21:00	12.0	2,085.3	1.3	1.0	1	1	1
09/12/2014 22:00	12.7	1,950.5	1.1	0.8	1	1	1
09/12/2014 23:00	12.7	1,955.3	1.1	0.8	1	1	1
Average/Sum#:	11.7	2,138.2	1.4	1.1	24 #	24 #	24 #
Minimum:	11.2	1,908.6	1.1	0.8	1	1	1
Maximum:	12.8	2,230.8	1.6	1.3	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/13/2014 00:00	12.8	1,947.8	1.1	0.8	1	1	1
09/13/2014 01:00	12.9	1,918.2	1.1	0.8	1	1	1
09/13/2014 02:00	13.5	1,794.1	1.1	0.7	1	1	1
09/13/2014 03:00	13.3	1,846.3	1.0	0.7	1	1	1
09/13/2014 04:00	13.3	1,781.3	1.1	0.7	1	1	1
09/13/2014 05:00	13.9	1,256.8	1.1	0.5	1	1	0
09/13/2014 06:00	13.9	1,250.0	1.1	0.5	1	1	0
09/13/2014 07:00	13.9	1,249.9	1.1	0.5	1	1	0
09/13/2014 08:00	13.9	1,388.3	1.1	0.6	1	1	0
09/13/2014 09:00	14.0	1,509.1	1.0	0.6	1	1	0
09/13/2014 10:00	13.8	1,573.8	1.0	0.6	1	1	1
09/13/2014 11:00	12.6	1,978.8	1.2	1.0	1	1	1
09/13/2014 12:00	11.8	2,102.5	1.3	1.1	1	1	1
09/13/2014 13:00	12.3	1,997.1	1.2	1.0	1	1	1
09/13/2014 14:00	12.2	2,004.0	1.3	1.0	1	1	1
09/13/2014 15:00	11.7	2,108.0	1.4	1.1	1	1	1
09/13/2014 16:00	11.7	2,089.4	1.4	1.0	1	1	1
09/13/2014 17:00	11.9	2,062.6	1.3	1.0	1	1	1
09/13/2014 18:00	12.5	1,957.2	1.2	1.0	1	1	1
09/13/2014 19:00	12.3	2,008.7	1.2	1.0	1	1	1
09/13/2014 20:00	12.7	1,949.5	1.2	1.0	1	1	1
09/13/2014 21:00	12.7	1,948.4	1.1	0.8	1	1	1
09/13/2014 22:00	12.9	1,911.1	1.1	0.8	1	1	1
09/13/2014 23:00	12.8	1,941.9	1.1	0.8	1	1	1
Average/Sum#:	12.9	1,815.6	1.2	0.8	24 #	24 #	19 #
Minimum:	11.7	1,249.9	1.0	0.5	1	1	0
Maximum:	14.0	2,108.0	1.4	1.1	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/14/2014 00:00	13.0	1,896.9	1.1	0.8	1	1	1
09/14/2014 01:00	13.2	1,850.9	1.0	0.7	1	1	1
09/14/2014 02:00	13.3	1,844.9	1.0	0.7	1	1	1
09/14/2014 03:00	13.3	1,847.9	1.0	0.7	1	1	1
09/14/2014 04:00	13.3	1,793.5	1.0	0.7	1	1	1
09/14/2014 05:00	13.9	1,262.0	1.1	0.5	1	1	0
09/14/2014 06:00	13.9	1,250.7	1.1	0.5	1	1	0
09/14/2014 07:00	13.9	1,251.1	1.1	0.5	1	1	0
09/14/2014 08:00	13.9	1,435.4	1.0	0.6	1	1	0
09/14/2014 09:00	13.5	1,631.5	1.1	0.7	1	1	1
09/14/2014 10:00	13.0	1,900.7	1.1	0.8	1	1	1
09/14/2014 11:00	12.7	1,945.9	1.2	1.0	1	1	1
09/14/2014 12:00	11.6	2,169.8	1.4	1.1	1	1	1
09/14/2014 13:00	11.5	2,182.9	1.4	1.1	1	1	1
09/14/2014 14:00	11.5	2,173.9	1.4	1.1	1	1	1
09/14/2014 15:00	11.4	2,158.0	1.4	1.1	1	1	1
09/14/2014 16:00	11.4	2,151.0	1.4	1.1	1	1	1
09/14/2014 17:00	11.5	2,139.0	1.4	1.1	1	1	1
09/14/2014 18:00	11.6	2,129.5	1.4	1.1	1	1	1
09/14/2014 19:00	11.8	2,100.9	1.4	1.1	1	1	1
09/14/2014 20:00	12.1	2,057.1	1.3	1.0	1	1	1
09/14/2014 21:00	12.4	1,995.9	1.2	1.0	1	1	1
09/14/2014 22:00	12.8	1,916.5	1.1	0.8	1	1	1
09/14/2014 23:00	12.9	1,910.6	1.1	0.8	1	1	1
Average/Sum#:	12.6	1,874.9	1.2	0.9	24 #	24 #	20 #
Minimum:	11.4	1,250.7	1.0	0.5	1	1	0
Maximum:	13.9	2,182.9	1.4	1.1	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/15/2014 00:00	13.1	1,857.7	1.1	0.7	1	1	1
09/15/2014 01:00	13.3	1,834.3	1.0	0.7	1	1	1
09/15/2014 02:00	13.3	1,832.1	1.0	0.7	1	1	1
09/15/2014 03:00	13.3	1,835.5	1.0	0.7	1	1	1
09/15/2014 04:00	13.3	1,838.7	1.0	0.7	1	1	1
09/15/2014 05:00	13.3	1,841.7	1.0	0.7	1	1	1
09/15/2014 06:00	13.3	1,842.9	1.0	0.7	1	1	1
09/15/2014 07:00	13.2	1,861.7	1.0	0.7	1	1	1
09/15/2014 08:00	12.7	1,955.4	1.1	0.8	1	1	1
09/15/2014 09:00	12.0	2,108.6	1.3	1.1	1	1	1
09/15/2014 10:00	11.6	2,166.7	1.4	1.1	1	1	1
09/15/2014 11:00	11.5	2,173.6	1.4	1.1	1	1	1
09/15/2014 12:00	12.5	1,797.4	1.3	0.9	1	1	1
09/15/2014 13:00	14.0	1,320.5	1.0	0.5	1	1	0
09/15/2014 14:00	14.0	1,328.8	1.0	0.5	1	1	0
09/15/2014 15:00	12.7	1,902.1	1.2	1.0	1	1	1
09/15/2014 16:00	11.9	2,092.5	1.3	1.0	1	1	1
09/15/2014 17:00	12.0	2,080.7	1.3	1.0	1	1	1
09/15/2014 18:00	12.2	2,060.0	1.3	1.0	1	1	1
09/15/2014 19:00	12.3	2,039.2	1.2	1.0	1	1	1
09/15/2014 20:00	12.5	2,012.4	1.2	1.0	1	1	1
09/15/2014 21:00	13.0	1,904.8	1.1	0.8	1	1	1
09/15/2014 22:00	13.4	1,831.1	1.0	0.7	1	1	1
09/15/2014 23:00	13.3	1,841.8	1.0	0.7	1	1	1
Average/Sum#:	12.8	1,890.0	1.1	0.8	24 #	24 #	22 #
Minimum:	11.5	1,320.5	1.0	0.5	1	1	0
Maximum:	14.0	2,173.6	1.4	1.1	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/16/2014 00:00	13.4	1,832.9	1.0	0.7	1	1	1
09/16/2014 01:00	13.4	1,829.4	1.0	0.7	1	1	1
09/16/2014 02:00	13.7	1,573.8	1.1	0.6	1	1	1
09/16/2014 03:00	13.8	1,276.0	1.1	0.5	1	1	0
09/16/2014 04:00	13.6	1,654.2	1.0	0.7	1	1	1
09/16/2014 05:00	13.0	1,925.0	1.1	0.8	1	1	1
09/16/2014 06:00	13.0	1,937.8	1.1	0.8	1	1	1
09/16/2014 07:00	12.7	1,977.1	1.1	0.8	1	1	1
09/16/2014 08:00	12.6	2,006.5	1.2	1.0	1	1	1
09/16/2014 09:00	12.6	2,006.7	1.2	1.0	1	1	1
09/16/2014 10:00	11.8	2,159.6	1.4	1.1	1	1	1
09/16/2014 11:00	11.8	2,165.5	1.4	1.1	1	1	1
09/16/2014 12:00	11.8	2,169.1	1.4	1.1	1	1	1
09/16/2014 13:00	11.8	2,159.3	1.4	1.1	1	1	1
09/16/2014 14:00	12.5	2,008.1	1.2	1.0	1	1	1
09/16/2014 15:00	12.9	1,918.3	1.1	0.8	1	1	1
09/16/2014 16:00	12.4	2,036.8	1.2	1.0	1	1	1
09/16/2014 17:00	11.7	2,171.7	1.4	1.1	1	1	1
09/16/2014 18:00	11.7	2,176.0	1.4	1.1	1	1	1
09/16/2014 19:00	11.7	2,182.3	1.4	1.1	1	1	1
09/16/2014 20:00	12.0	2,128.7	1.3	1.1	1	1	1
09/16/2014 21:00	13.1	1,884.6	1.1	0.8	1	1	1
09/16/2014 22:00	13.6	1,691.0	1.0	0.7	1	1	1
09/16/2014 23:00	13.6	1,787.1	1.0	0.7	1	1	1
Average/Sum#:	12.7	1,944.1	1.2	0.9	24 #	24 #	23 #
Minimum:	11.7	1,276.0	1.0	0.5	1	1	0
Maximum:	13.8	2,182.3	1.4	1.1	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/17/2014 00:00	12.2	2,110.1	1.2	1.1	1	1	1
09/17/2014 01:00	12.2	2,099.8	1.2	1.0	1	1	1
09/17/2014 02:00	12.7	1,997.5	1.2	1.0	1	1	1
09/17/2014 03:00	11.9	2,161.2	1.4	1.1	1	1	1
09/17/2014 04:00	11.8	2,170.8	1.3	1.1	1	1	1
09/17/2014 05:00	12.0	2,143.1	1.3	1.1	1	1	1
09/17/2014 06:00	12.0	2,146.1	1.3	1.1	1	1	1
09/17/2014 07:00	11.8	2,166.7	1.3	1.1	1	1	1
09/17/2014 08:00	11.9	2,151.3	1.3	1.1	1	1	1
09/17/2014 09:00	11.9	2,128.3	1.3	1.1	1	1	1
09/17/2014 10:00	11.9	2,140.8	1.3	1.1	1	1	1
09/17/2014 11:00	11.8	2,157.0	1.3	1.1	1	1	1
09/17/2014 12:00	11.6	2,173.9	1.4	1.1	1	1	1
09/17/2014 13:00	11.7	2,153.5	1.4	1.1	1	1	1
09/17/2014 14:00	11.9	2,105.8	1.3	1.1	1	1	1
09/17/2014 15:00	12.1	2,070.4	1.3	1.0	1	1	1
09/17/2014 16:00	12.7	1,962.9	1.1	0.8	1	1	1
09/17/2014 17:00	12.7	1,962.2	1.1	0.8	1	1	1
09/17/2014 18:00	12.2	2,043.2	1.2	1.0	1	1	1
09/17/2014 19:00	12.5	1,977.0	1.2	1.0	1	1	1
09/17/2014 20:00	12.6	1,968.1	1.2	1.0	1	1	1
09/17/2014 21:00	13.2	1,845.7	1.0	0.7	1	1	1
09/17/2014 22:00	13.2	1,848.0	1.0	0.7	1	1	1
09/17/2014 23:00	13.2	1,857.6	1.0	0.7	1	1	1
Average/Sum#:	12.2	2,064.2	1.2	1.0	24 #	24 #	24 #
Minimum:	11.6	1,845.7	1.0	0.7	1	1	1
Maximum:	13.2	2,173.9	1.4	1.1	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/18/2014 00:00	12.7	1,968.3	1.1	0.8	1	1	1
09/18/2014 01:00	12.8	1,938.5	1.1	0.8	1	1	1
09/18/2014 02:00	13.3	1,848.5	1.0	0.7	1	1	1
09/18/2014 03:00	13.3	1,773.0	1.1	0.7	1	1	1
09/18/2014 04:00	13.8	1,568.1	1.0	0.6	1	1	0
09/18/2014 05:00	13.8	1,602.3	1.0	0.6	1	1	0
09/18/2014 06:00	13.8	1,585.4	1.0	0.6	1	1	0
09/18/2014 07:00	13.8	1,302.1	1.2	0.7	1	1	0
09/18/2014 08:00	13.8	1,409.6	1.1	0.6	1	1	0
09/18/2014 09:00	13.8	1,586.9	1.0	0.6	1	1	0
09/18/2014 10:00	13.9	1,286.1	1.1	0.5	1	1	0
09/18/2014 11:00	13.9	1,284.8	1.1	0.5	1	1	0
09/18/2014 12:00	13.9	1,475.6	1.0	0.6	1	1	0
09/18/2014 13:00	13.9	1,601.9	1.0	0.6	1	1	0
09/18/2014 14:00	13.8	1,664.2	1.0	0.7	1	1	0
09/18/2014 15:00	13.8	1,588.4	1.0	0.6	1	1	0
09/18/2014 16:00	13.5	1,711.8	1.1	0.7	1	1	1
09/18/2014 17:00	12.7	1,937.4	1.2	1.0	1	1	1
09/18/2014 18:00	12.3	2,023.1	1.2	1.0	1	1	1
09/18/2014 19:00	12.2	2,034.4	1.3	1.0	1	1	1
09/18/2014 20:00	13.1	1,849.5	1.1	0.7	1	1	1
09/18/2014 21:00	13.4	1,582.7	1.1	0.6	1	1	1
09/18/2014 22:00	13.9	1,238.1	1.1	0.5	1	1	0
09/18/2014 23:00	13.9	1,362.3	1.1	0.5	1	1	0
Average/Sum#:	13.5	1,634.3	1.1	0.7	24 #	24 #	10 #
Minimum:	12.2	1,238.1	1.0	0.5	1	1	0
Maximum:	13.9	2,034.4	1.3	1.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/19/2014 00:00	13.9	1,257.8	1.1	0.5	1	1	0
09/19/2014 01:00	13.9	1,248.4	1.1	0.5	1	1	0
09/19/2014 02:00	13.9	1,246.9	1.1	0.5	1	1	0
09/19/2014 03:00	13.9	1,314.6	1.1	0.5	1	1	0
09/19/2014 04:00	13.9	1,338.4	1.1	0.5	1	1	0
09/19/2014 05:00	13.6	1,612.1	1.0	0.6	1	1	1
09/19/2014 06:00	12.8	1,931.9	1.1	0.8	1	1	1
09/19/2014 07:00	13.3	1,840.9	1.0	0.7	1	1	1
09/19/2014 08:00	13.2	1,854.7	1.0	0.7	1	1	1
09/19/2014 09:00	13.2	1,864.3	1.0	0.7	1	1	1
09/19/2014 10:00	13.2	1,838.8	1.0	0.7	1	1	1
09/19/2014 11:00	13.2	1,840.3	1.0	0.7	1	1	1
09/19/2014 12:00	12.6	1,944.1	1.2	1.0	1	1	1
09/19/2014 13:00	12.6	1,942.2	1.2	1.0	1	1	1
09/19/2014 14:00	12.4	1,991.0	1.2	1.0	1	1	1
09/19/2014 15:00	11.4	2,166.7	1.4	1.1	1	1	1
09/19/2014 16:00	11.4	2,171.4	1.4	1.1	1	1	1
09/19/2014 17:00	11.5	2,166.1	1.4	1.1	1	1	1
09/19/2014 18:00	11.9	2,081.5	1.3	1.0	1	1	1
09/19/2014 19:00	12.8	1,915.8	1.1	0.8	1	1	1
09/19/2014 20:00	12.9	1,906.0	1.1	0.8	1	1	1
09/19/2014 21:00	12.8	1,917.5	1.1	0.8	1	1	1
09/19/2014 22:00	12.7	1,955.5	1.1	0.8	1	1	1
09/19/2014 23:00	12.5	2,001.2	1.2	1.0	1	1	1
Average/Sum#:	12.9	1,806.2	1.1	0.8	24 #	24 #	19 #
Minimum:	11.4	1,246.9	1.0	0.5	1	1	0
Maximum:	13.9	2,171.4	1.4	1.1	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/20/2014 00:00	12.3	2,042.4	1.2	1.0	1	1	1
09/20/2014 01:00	11.8	2,125.5	1.4	1.1	1	1	1
09/20/2014 02:00	12.6	1,975.2	1.2	1.0	1	1	1
09/20/2014 03:00	12.6	1,970.8	1.2	1.0	1	1	1
09/20/2014 04:00	12.6	1,985.1	1.2	1.0	1	1	1
09/20/2014 05:00	12.7	1,956.6	1.1	0.8	1	1	1
09/20/2014 06:00	12.7	1,971.3	1.1	0.8	1	1	1
09/20/2014 07:00	12.6	1,979.2	1.1	0.8	1	1	1
09/20/2014 08:00	13.2	1,842.3	1.0	0.7	1	1	1
09/20/2014 09:00	13.2	1,840.5	1.0	0.7	1	1	1
09/20/2014 10:00	13.2	1,839.2	1.0	0.7	1	1	1
09/20/2014 11:00	13.2	1,839.3	1.0	0.7	1	1	1
09/20/2014 12:00	13.1	1,842.8	1.1	0.7	1	1	1
09/20/2014 13:00	12.9	1,878.6	1.1	0.8	1	1	1
09/20/2014 14:00	12.9	1,887.2	1.1	0.8	1	1	1
09/20/2014 15:00	12.8	1,903.6	1.1	0.8	1	1	1
09/20/2014 16:00	13.1	1,855.2	1.0	0.7	1	1	1
09/20/2014 17:00	12.7	1,917.3	1.2	1.0	1	1	1
09/20/2014 18:00	12.7	1,927.9	1.1	0.8	1	1	1
09/20/2014 19:00	12.1	2,043.5	1.3	1.0	1	1	1
09/20/2014 20:00	13.0	1,870.8	1.1	0.7	1	1	1
09/20/2014 21:00	12.7	1,928.5	1.1	0.8	1	1	1
09/20/2014 22:00	13.2	1,846.4	1.0	0.7	1	1	1
09/20/2014 23:00	13.0	1,893.3	1.1	0.8	1	1	1
Average/Sum#:	12.8	1,923.4	1.1	0.8	24 #	24 #	24 #
Minimum:	11.8	1,839.2	1.0	0.7	1	1	1
Maximum:	13.2	2,125.5	1.4	1.1	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/21/2014 00:00	13.3	1,836.2	1.0	0.7	1	1	1
09/21/2014 01:00	13.3	1,835.6	1.0	0.7	1	1	1
09/21/2014 02:00	13.3	1,836.9	1.0	0.7	1	1	1
09/21/2014 03:00	13.3	1,834.8	1.0	0.7	1	1	1
09/21/2014 04:00	13.3	1,837.7	1.0	0.7	1	1	1
09/21/2014 05:00	13.3	1,837.9	1.0	0.7	1	1	1
09/21/2014 06:00	13.3	1,841.4	1.0	0.7	1	1	1
09/21/2014 07:00	13.3	1,846.5	1.0	0.7	1	1	1
09/21/2014 08:00	13.3	1,838.6	1.0	0.7	1	1	1
09/21/2014 09:00	13.3	1,836.7	1.0	0.7	1	1	1
09/21/2014 10:00	13.2	1,837.4	1.0	0.7	1	1	1
09/21/2014 11:00	13.2	1,719.9	1.1	0.7	1	1	1
09/21/2014 12:00	13.9	1,252.8	1.1	0.5	1	1	0
09/21/2014 13:00	13.9	1,244.6	1.1	0.5	1	1	0
09/21/2014 14:00	13.9	1,250.8	1.1	0.5	1	1	0
09/21/2014 15:00	13.9	1,261.7	1.1	0.5	1	1	0
09/21/2014 16:00	13.9	1,277.3	1.1	0.5	1	1	0
09/21/2014 17:00	13.5	1,701.1	1.0	0.7	1	1	1
09/21/2014 18:00	13.1	1,859.4	1.1	0.7	1	1	1
09/21/2014 19:00	12.9	1,907.6	1.1	0.8	1	1	1
09/21/2014 20:00	13.2	1,833.1	1.0	0.7	1	1	1
09/21/2014 21:00	13.2	1,832.7	1.0	0.7	1	1	1
09/21/2014 22:00	13.5	1,518.6	1.1	0.6	1	1	1
09/21/2014 23:00	13.8	1,244.1	1.1	0.5	1	1	0
Average/Sum#:	13.4	1,671.8	1.0	0.7	24 #	24 #	18 #
Minimum:	12.9	1,244.1	1.0	0.5	1	1	0
Maximum:	13.9	1,907.6	1.1	0.8	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/22/2014 00:00	13.8	1,244.2	1.1	0.5	1	1	0
09/22/2014 01:00	13.8	1,242.9	1.1	0.5	1	1	0
09/22/2014 02:00	13.8	1,271.7	1.1	0.5	1	1	0
09/22/2014 03:00	13.5	1,697.1	1.1	0.7	1	1	1
09/22/2014 04:00	13.3	1,850.1	1.1	0.7	1	1	1
09/22/2014 05:00	13.0	1,916.2	1.1	0.8	1	1	1
09/22/2014 06:00	12.5	2,016.7	1.2	1.0	1	1	1
09/22/2014 07:00	13.8	1,394.1	1.5	0.8	1	1	1
09/22/2014 08:00	13.8	1,276.4	1.6	0.8	1	1	0
09/22/2014 09:00	0.0	1,275.0	4.5	2.2	1	1	0
09/22/2014 10:00	0.0	1,287.8	4.5	2.2	1	1	0
09/22/2014 11:00	0.0	1,408.5	4.0	2.1	1	1	0
09/22/2014 12:00	0.0	1,724.1	3.3	2.2	1	1	0
09/22/2014 13:00	13.6	1,687.0	1.1	0.7	1	1	0
09/22/2014 14:00	13.6	1,726.9	1.1	0.7	1	1	0
09/22/2014 15:00	13.6	1,722.3	1.1	0.7	1	1	0
09/22/2014 16:00	13.6	1,722.1	1.1	0.7	1	1	0
09/22/2014 17:00	13.6	1,725.3	1.1	0.7	1	1	0
09/22/2014 18:00	13.6	1,730.8	1.1	0.7	1	1	0
09/22/2014 19:00	13.6	1,737.3	1.1	0.7	1	1	0
09/22/2014 20:00	13.6	1,736.3	1.1	0.7	1	1	0
09/22/2014 21:00	13.7	1,706.6	1.1	0.7	1	1	0
09/22/2014 22:00	13.8	1,544.3	1.1	0.6	1	1	0
09/22/2014 23:00	13.8	1,673.3	1.0	0.7	1	1	0
Average/Sum#:	13.6	1,596.5	1.1	0.7	24 #	24 #	5 #
Minimum:	12.5	1,242.9	1.0	0.5	1	1	0
Maximum:	13.8	2,016.7	1.5	1.0	1	1	1
%SI	16.7	0.0	20.8	20.8	0	0	0

Daily Summary Report

CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/23/2014 00:00	13.8	1,625.7	1.0	0.7	1	1	0
09/23/2014 01:00	13.8	1,589.9	1.0	0.6	1	1	0
09/23/2014 02:00	13.8	1,581.0	1.1	0.6	1	1	0
09/23/2014 03:00	13.7	1,695.5	1.0	0.7	1	1	0
09/23/2014 04:00	13.7	1,716.1	1.1	0.7	1	1	0
09/23/2014 05:00	13.7	1,720.3	1.0	0.7	1	1	0
09/23/2014 06:00	13.6	1,783.8	1.0	0.7	1	1	0
09/23/2014 07:00	13.8	1,680.2	1.0	0.7	1	1	0
09/23/2014 08:00	13.8	1,302.0	1.1	0.5	1	1	0
09/23/2014 09:00	13.8	1,283.9	1.1	0.5	1	1	0
09/23/2014 10:00	13.9	1,276.0	1.1	0.5	1	1	0
09/23/2014 11:00	13.9	1,461.2	1.0	0.6	1	1	0
09/23/2014 12:00	13.8	1,657.4	1.0	0.7	1	1	0
09/23/2014 13:00	13.8	1,642.1	1.1	0.7	1	1	0
09/23/2014 14:00	13.7	1,735.0	1.1	0.7	1	1	0
09/23/2014 15:00	13.7	1,734.7	1.0	0.7	1	1	0
09/23/2014 16:00	13.7	1,730.7	1.1	0.7	1	1	0
09/23/2014 17:00	13.7	1,733.8	1.1	0.7	1	1	0
09/23/2014 18:00	13.7	1,743.7	1.1	0.7	1	1	0
09/23/2014 19:00	13.7	1,749.9	1.0	0.7	1	1	0
09/23/2014 20:00	13.7	1,696.6	1.1	0.7	1	1	0
09/23/2014 21:00	13.6	1,755.0	1.1	0.7	1	1	0
09/23/2014 22:00	13.6	1,759.3	1.1	0.7	1	1	0
09/23/2014 23:00	13.6	1,772.4	1.1	0.7	1	1	0
Average/Sum#:	13.7	1,642.8	1.1	0.7	24 #	24 #	0 #
Minimum:	13.6	1,276.0	1.0	0.5	1	1	0
Maximum:	13.9	1,783.8	1.1	0.7	1	1	0
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/24/2014 00:00	13.6	1,779.3	1.0	0.7	1	1	0
09/24/2014 01:00	13.6	1,781.8	1.0	0.7	1	1	0
09/24/2014 02:00	13.6	1,781.6	1.0	0.7	1	1	0
09/24/2014 03:00	13.6	1,763.1	1.0	0.7	1	1	0
09/24/2014 04:00	13.6	1,743.7	1.1	0.7	1	1	0
09/24/2014 05:00	13.7	1,673.3	1.0	0.7	1	1	0
09/24/2014 06:00	13.6	1,775.0	1.0	0.7	1	1	0
09/24/2014 07:00	13.7	1,711.7	1.1	0.7	1	1	0
09/24/2014 08:00	13.8	1,596.6	1.0	0.6	1	1	0
09/24/2014 09:00	13.7	1,720.9	1.0	0.7	1	1	0
09/24/2014 10:00	13.6	1,758.6	1.0	0.7	1	1	0
09/24/2014 11:00	13.6	1,755.0	1.0	0.7	1	1	0
09/24/2014 12:00	13.6	1,748.9	1.0	0.7	1	1	0
09/24/2014 13:00	13.6	1,746.4	1.0	0.7	1	1	0
09/24/2014 14:00	13.7	1,747.5	1.0	0.7	1	1	0
09/24/2014 15:00	13.7	1,747.7	1.0	0.7	1	1	0
09/24/2014 16:00	13.7	1,743.8	1.0	0.7	1	1	0
09/24/2014 17:00	13.6	1,755.4	1.0	0.7	1	1	0
09/24/2014 18:00	13.6	1,762.4	1.0	0.7	1	1	0
09/24/2014 19:00	13.6	1,766.3	1.0	0.7	1	1	0
09/24/2014 20:00	13.6	1,773.8	1.0	0.7	1	1	0
09/24/2014 21:00	13.6	1,778.7	1.0	0.7	1	1	0
09/24/2014 22:00	13.6	1,782.1	1.0	0.7	1	1	0
09/24/2014 23:00	13.6	1,769.6	1.0	0.7	1	1	0
Average/Sum#:	13.6	1,748.5	1.0	0.7	24 #	24 #	0 #
Minimum:	13.6	1,596.6	1.0	0.6	1	1	0
Maximum:	13.8	1,782.1	1.1	0.7	1	1	0
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/25/2014 00:00	13.6	1,774.2	1.0	0.7	1	1	0
09/25/2014 01:00	13.6	1,772.1	1.0	0.7	1	1	0
09/25/2014 02:00	13.6	1,770.9	1.0	0.7	1	1	0
09/25/2014 03:00	13.7	1,730.2	1.0	0.7	1	1	0
09/25/2014 04:00	13.6	1,771.3	1.0	0.7	1	1	0
09/25/2014 05:00	13.7	1,738.4	1.0	0.7	1	1	0
09/25/2014 06:00	13.6	1,772.4	1.0	0.7	1	1	0
09/25/2014 07:00	13.7	1,748.3	1.1	0.7	1	1	0
09/25/2014 08:00	13.6	1,771.4	1.0	0.7	1	1	0
09/25/2014 09:00	13.6	1,767.9	1.0	0.7	1	1	0
09/25/2014 10:00	13.6	1,760.2	1.0	0.7	1	1	0
09/25/2014 11:00	13.6	1,785.0	1.0	0.7	1	1	0
09/25/2014 12:00	13.6	1,771.9	1.0	0.7	1	1	0
09/25/2014 13:00	12.4	2,039.6	1.2	1.0	1	1	1
09/25/2014 14:00	11.9	2,141.5	1.3	1.1	1	1	1
09/25/2014 15:00	11.6	2,179.6	1.4	1.1	1	1	1
09/25/2014 16:00	12.8	1,944.2	1.1	0.8	1	1	1
09/25/2014 17:00	12.5	2,022.8	1.2	1.0	1	1	1
09/25/2014 18:00	12.4	2,060.4	1.2	1.0	1	1	1
09/25/2014 19:00	12.3	2,070.5	1.2	1.0	1	1	1
09/25/2014 20:00	13.0	1,933.0	1.1	0.8	1	1	1
09/25/2014 21:00	13.1	1,897.7	1.1	0.8	1	1	1
09/25/2014 22:00	12.9	1,936.8	1.1	0.8	1	1	1
09/25/2014 23:00	12.4	2,040.6	1.2	1.0	1	1	1
Average/Sum#:	13.1	1,883.4	1.1	0.8	24 #	24 #	11 #
Minimum:	11.6	1,730.2	1.0	0.7	1	1	0
Maximum:	13.7	2,179.6	1.4	1.1	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/26/2014 00:00	12.9	1,940.1	1.1	0.8	1	1	1
09/26/2014 01:00	12.9	1,953.3	1.1	0.8	1	1	1
09/26/2014 02:00	13.1	1,897.5	1.1	0.8	1	1	1
09/26/2014 03:00	13.0	1,923.3	1.1	0.8	1	1	1
09/26/2014 04:00	11.9	2,160.7	1.3	1.1	1	1	1
09/26/2014 05:00	11.8	2,182.9	1.3	1.1	1	1	1
09/26/2014 06:00	11.7	2,198.7	1.4	1.1	1	1	1
09/26/2014 07:00	12.5	2,045.1	1.2	1.0	1	1	1
09/26/2014 08:00	13.3	1,870.5	1.0	0.7	1	1	1
09/26/2014 09:00	12.8	1,983.2	1.1	0.8	1	1	1
09/26/2014 10:00	12.6	2,011.4	1.2	1.0	1	1	1
09/26/2014 11:00	12.8	1,963.7	1.1	0.8	1	1	1
09/26/2014 12:00	13.2	1,884.8	1.0	0.8	1	1	1
09/26/2014 13:00	13.3	1,857.2	1.0	0.7	1	1	1
09/26/2014 14:00	13.3	1,860.5	1.0	0.7	1	1	1
09/26/2014 15:00	13.3	1,853.7	1.0	0.7	1	1	1
09/26/2014 16:00	13.3	1,855.4	1.0	0.7	1	1	1
09/26/2014 17:00	13.0	1,922.9	1.1	0.8	1	1	1
09/26/2014 18:00	13.1	1,895.7	1.1	0.8	1	1	1
09/26/2014 19:00	13.3	1,860.5	1.0	0.7	1	1	1
09/26/2014 20:00	13.3	1,863.5	1.0	0.7	1	1	1
09/26/2014 21:00	13.1	1,916.0	1.1	0.8	1	1	1
09/26/2014 22:00	13.2	1,887.0	1.0	0.8	1	1	1
09/26/2014 23:00	12.6	2,023.7	1.2	1.0	1	1	1
Average/Sum#:	12.9	1,950.5	1.1	0.8	24 #	24 #	24 #
Minimum:	11.7	1,853.7	1.0	0.7	1	1	1
Maximum:	13.3	2,198.7	1.4	1.1	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/27/2014 00:00	12.5	2,052.4	1.2	1.0	1	1	1
09/27/2014 01:00	12.1	2,120.7	1.3	1.1	1	1	1
09/27/2014 02:00	12.9	1,960.0	1.1	0.8	1	1	1
09/27/2014 03:00	13.1	1,915.3	1.1	0.8	1	1	1
09/27/2014 04:00	13.2	1,889.8	1.0	0.8	1	1	1
09/27/2014 05:00	13.1	1,906.6	1.1	0.8	1	1	1
09/27/2014 06:00	13.1	1,889.6	1.1	0.8	1	1	1
09/27/2014 07:00	13.7	1,592.0	1.1	0.6	1	1	1
09/27/2014 08:00	13.8	1,269.2	1.1	0.5	1	1	0
09/27/2014 09:00	13.9	1,345.4	1.1	0.5	1	1	0
09/27/2014 10:00	13.9	1,281.8	1.1	0.5	1	1	0
09/27/2014 11:00	13.9	1,254.6	1.1	0.5	1	1	0
09/27/2014 12:00	13.9	1,253.0	1.1	0.5	1	1	0
09/27/2014 13:00	13.9	1,253.6	1.1	0.5	1	1	0
09/27/2014 14:00	13.9	1,253.4	1.1	0.5	1	1	0
09/27/2014 15:00	13.9	1,250.6	1.1	0.5	1	1	0
09/27/2014 16:00	13.9	1,247.9	1.1	0.5	1	1	0
09/27/2014 17:00	13.5	1,608.2	1.1	0.6	1	1	1
09/27/2014 18:00	11.8	2,150.9	1.3	1.1	1	1	1
09/27/2014 19:00	12.7	1,949.9	1.1	0.8	1	1	1
09/27/2014 20:00	13.1	1,895.1	1.0	0.8	1	1	1
09/27/2014 21:00	12.8	1,948.2	1.1	0.8	1	1	1
09/27/2014 22:00	13.4	1,827.1	1.0	0.7	1	1	1
09/27/2014 23:00	13.4	1,856.5	1.0	0.7	1	1	1
Average/Sum#:	13.3	1,665.5	1.1	0.7	24 #	24 #	15 #
Minimum:	11.8	1,247.9	1.0	0.5	1	1	0
Maximum:	13.9	2,150.9	1.3	1.1	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/28/2014 00:00	13.5	1,461.9	1.1	0.6	1	1	1
09/28/2014 01:00	13.9	1,251.2	1.1	0.5	1	1	0
09/28/2014 02:00	13.9	1,249.5	1.1	0.5	1	1	0
09/28/2014 03:00	13.9	1,518.4	1.0	0.6	1	1	0
09/28/2014 04:00	13.3	1,841.0	1.1	0.7	1	1	1
09/28/2014 05:00	12.8	1,973.4	1.1	0.8	1	1	1
09/28/2014 06:00	12.6	2,002.2	1.2	1.0	1	1	1
09/28/2014 07:00	13.3	1,862.7	1.0	0.7	1	1	1
09/28/2014 08:00	13.1	1,881.7	1.1	0.8	1	1	1
09/28/2014 09:00	13.8	1,308.0	1.1	0.5	1	1	1
09/28/2014 10:00	13.8	1,252.5	1.1	0.5	1	1	0
09/28/2014 11:00	13.6	1,541.8	1.1	0.6	1	1	1
09/28/2014 12:00	13.3	1,839.6	1.0	0.7	1	1	1
09/28/2014 13:00	13.3	1,838.8	1.0	0.7	1	1	1
09/28/2014 14:00	13.3	1,838.9	1.0	0.7	1	1	1
09/28/2014 15:00	13.3	1,844.4	1.0	0.7	1	1	1
09/28/2014 16:00	13.0	1,931.8	1.1	0.8	1	1	1
09/28/2014 17:00	12.3	2,063.6	1.2	1.0	1	1	1
09/28/2014 18:00	11.4	2,244.6	1.4	1.1	1	1	1
09/28/2014 19:00	11.4	2,256.2	1.4	1.1	1	1	1
09/28/2014 20:00	12.6	1,994.4	1.2	1.0	1	1	1
09/28/2014 21:00	12.9	1,947.2	1.1	0.8	1	1	1
09/28/2014 22:00	13.0	1,935.2	1.1	0.8	1	1	1
09/28/2014 23:00	13.4	1,853.4	1.0	0.7	1	1	1
Average/Sum#:	13.1	1,780.5	1.1	0.7	24 #	24 #	20 #
Minimum:	11.4	1,249.5	1.0	0.5	1	1	0
Maximum:	13.9	2,256.2	1.4	1.1	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/29/2014 00:00	13.5	1,835.3	1.0	0.7	1	1	1
09/29/2014 01:00	13.5	1,836.5	1.0	0.7	1	1	1
09/29/2014 02:00	13.5	1,836.7	1.0	0.7	1	1	1
09/29/2014 03:00	13.5	1,836.2	1.0	0.7	1	1	1
09/29/2014 04:00	13.4	1,857.5	1.0	0.7	1	1	1
09/29/2014 05:00	13.3	1,866.0	1.0	0.7	1	1	1
09/29/2014 06:00	12.7	1,988.3	1.1	0.8	1	1	1
09/29/2014 07:00	13.3	1,840.3	1.0	0.7	1	1	1
09/29/2014 08:00	13.3	1,839.3	1.0	0.7	1	1	1
09/29/2014 09:00	13.3	1,847.0	1.0	0.7	1	1	1
09/29/2014 10:00	13.2	1,855.3	0.9	0.6	1	1	1
09/29/2014 11:00	13.2	1,853.2	0.9	0.6	1	1	1
09/29/2014 12:00	13.8	1,283.9	1.2	0.6	1	1	0
09/29/2014 13:00	13.9	1,252.4	1.1	0.5	1	1	0
09/29/2014 14:00	13.6	1,519.0	1.1	0.6	1	1	1
09/29/2014 15:00	13.2	1,842.3	1.0	0.7	1	1	1
09/29/2014 16:00	13.0	1,896.4	1.1	0.8	1	1	1
09/29/2014 17:00	12.6	1,971.9	1.1	0.8	1	1	1
09/29/2014 18:00	11.8	2,141.2	1.3	1.1	1	1	1
09/29/2014 19:00	12.0	2,097.7	1.3	1.0	1	1	1
09/29/2014 20:00	12.9	1,925.0	1.1	0.8	1	1	1
09/29/2014 21:00	13.3	1,715.2	1.1	0.7	1	1	1
09/29/2014 22:00	13.9	1,264.3	1.1	0.5	1	1	0
09/29/2014 23:00	13.8	1,298.1	1.1	0.5	1	1	0
Average/Sum#:	13.2	1,770.8	1.1	0.7	24 #	24 #	20 #
Minimum:	11.8	1,252.4	0.9	0.5	1	1	0
Maximum:	13.9	2,141.2	1.3	1.1	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report
CT1 - NH3

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:26 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

Const. Value/Limit Tag:			> Limit	> Limit			
	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1	Unit CT1
	O2, Dry, Pct	HI, MBtuPerHr	NH3, Slip, Ppmvdc	NH3slip, LbPerHr	UnitOn, TF	NormalOp, TF	DBOn, TF
	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)	1 Hour(s)
09/30/2014 00:00	13.8	1,252.5	1.1	0.5	1	1	0
09/30/2014 01:00	13.8	1,253.2	1.1	0.5	1	1	0
09/30/2014 02:00	13.8	1,253.6	1.1	0.5	1	1	0
09/30/2014 03:00	13.8	1,254.3	1.1	0.5	1	1	0
09/30/2014 04:00	13.8	1,376.5	1.1	0.6	1	1	0
09/30/2014 05:00	13.4	1,647.5	1.1	0.7	1	1	1
09/30/2014 06:00	13.2	1,879.9	1.0	0.8	1	1	1
09/30/2014 07:00	13.3	1,851.9	1.0	0.7	1	1	1
09/30/2014 08:00	13.3	1,852.8	1.0	0.7	1	1	1
09/30/2014 09:00	13.2	1,851.7	1.0	0.7	1	1	1
09/30/2014 10:00	13.9	1,255.1	1.2	0.6	1	1	0
09/30/2014 11:00	13.9	1,251.9	1.1	0.5	1	1	0
09/30/2014 12:00	13.6	1,635.7	0.8	0.5	1	1	1
09/30/2014 13:00	13.3	1,848.7	1.0	0.7	1	1	1
09/30/2014 14:00	13.3	1,850.7	1.0	0.7	1	1	1
09/30/2014 15:00	13.3	1,855.8	1.0	0.7	1	1	1
09/30/2014 16:00	13.2	1,870.7	1.0	0.7	1	1	1
09/30/2014 17:00	13.3	1,860.5	1.0	0.7	1	1	1
09/30/2014 18:00	12.6	2,006.2	1.2	1.0	1	1	1
09/30/2014 19:00	12.2	2,076.5	1.3	1.0	1	1	1
09/30/2014 20:00	13.4	1,857.5	1.0	0.7	1	1	1
09/30/2014 21:00	13.7	1,468.2	1.0	0.6	1	1	1
09/30/2014 22:00	13.9	1,256.7	1.0	0.5	1	1	0
09/30/2014 23:00	13.9	1,254.7	1.0	0.5	1	1	0
Average/Sum#:	13.5	1,617.6	1.1	0.7	24 #	24 #	15 #
Minimum:	12.2	1,251.9	0.8	0.5	1	1	0
Maximum:	13.9	2,076.5	1.3	1.0	1	1	1
%SI	0.0	0.0	0.0	0.0	0	0	0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/01/2014 00:00	9.3	13.5	7.4	102.2	3,225,601.1	1,860.8	0.9	0.6
07/01/2014 01:00	9.5	13.7	7.8	96.3	2,921,685.4	1,578.8	0.9	0.5
07/01/2014 02:00	9.9	13.6	8.0	95.9	2,823,536.9	1,567.0	1.0	0.6
07/01/2014 03:00	10.3	13.8	8.6	83.8	2,370,816.0	1,246.5	1.0	0.5
07/01/2014 04:00	10.3	13.8	8.6	85.0	2,449,177.5	1,287.7	1.0	0.5
07/01/2014 05:00	10.2	13.7	8.4	94.7	2,845,846.5	1,558.6	0.9	0.5
07/01/2014 06:00	10.0	13.4	7.9	107.3	3,310,020.1	1,909.5	0.9	0.6
07/01/2014 07:00	9.8	13.5	7.8	105.6	3,246,049.3	1,896.3	0.9	0.6
07/01/2014 08:00	10.3	13.4	8.1	108.7	3,247,733.6	1,921.0	1.0	0.8
07/01/2014 09:00	10.2	13.4	8.0	109.4	3,214,306.2	1,924.7	1.0	0.8
07/01/2014 10:00	9.9	13.4	7.8	104.5	3,198,873.9	1,892.1	0.9	0.6
07/01/2014 11:00	10.0	13.4	7.9	103.9	3,181,629.3	1,881.9	0.9	0.6
07/01/2014 12:00	10.0	13.4	7.9	103.7	3,195,323.6	1,890.0	0.9	0.6
07/01/2014 13:00	9.9	13.4	7.8	104.4	3,174,559.5	1,900.9	0.9	0.6
07/01/2014 14:00	9.8	13.3	7.6	107.7	3,194,766.9	1,913.0	1.0	0.8
07/01/2014 15:00	9.9	13.3	7.7	108.8	3,177,229.6	1,925.7	1.0	0.8
07/01/2014 16:00	10.0	13.2	7.7	117.5	3,143,675.2	2,043.1	1.1	0.8
07/01/2014 17:00	10.3	13.2	7.9	125.5	3,178,106.5	2,135.1	1.2	1.1
07/01/2014 18:00	10.4	13.2	8.0	124.6	3,155,481.3	2,119.9	1.2	1.1
07/01/2014 19:00	9.6	13.4	7.6	105.5	3,202,762.4	1,894.4	0.9	0.6
07/01/2014 20:00	9.3	13.5	7.4	100.6	3,217,976.1	1,879.9	0.9	0.6
07/01/2014 21:00	9.2	13.5	7.3	101.6	3,231,148.2	1,864.0	0.9	0.6
07/01/2014 22:00	9.3	13.6	7.5	101.8	3,230,454.8	1,863.6	0.9	0.6
07/01/2014 23:00	9.5	13.6	7.7	102.7	3,269,939.6	1,862.5	0.9	0.6
Average/Sum#:	9.9	13.5	7.9	104.2	3,100,279.1	1,825.7	1.0	0.7
Minimum:	9.2	13.2	7.3	83.8	2,370,816.0	1,246.5	0.9	0.5
Maximum:	10.4	13.8	8.6	125.5	3,310,020.1	2,135.1	1.2	1.1
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/02/2014 00:00	9.8	13.7	8.0	103.6	3,272,222.0	1,863.8	0.9	0.6
07/02/2014 01:00	9.9	13.7	8.1	103.9	3,272,748.7	1,864.1	0.9	0.6
07/02/2014 02:00	9.9	13.6	8.0	103.0	3,270,466.3	1,862.8	0.9	0.6
07/02/2014 03:00	10.0	13.6	8.1	103.7	3,272,397.6	1,863.9	0.9	0.6
07/02/2014 04:00	10.1	13.5	8.1	107.9	3,301,168.7	1,928.5	0.9	0.6
07/02/2014 05:00	10.6	13.3	8.2	120.1	3,315,280.9	2,082.0	1.0	0.8
07/02/2014 06:00	10.4	13.3	8.1	118.3	3,362,270.9	2,013.3	1.0	0.8
07/02/2014 07:00	9.8	13.6	7.9	105.3	3,288,872.0	1,897.3	0.9	0.6
07/02/2014 08:00	9.7	13.6	7.8	104.8	3,282,284.9	1,893.5	0.9	0.6
07/02/2014 09:00	9.6	13.5	7.7	102.8	3,282,284.9	1,893.5	0.9	0.6
07/02/2014 10:00	9.4	13.5	7.5	103.6	3,278,298.0	1,891.2	0.9	0.6
07/02/2014 11:00	9.8	13.4	7.7	105.0	3,243,310.5	1,894.7	0.9	0.6
07/02/2014 12:00	10.1	13.4	7.9	105.9	3,203,607.7	1,894.9	0.9	0.6
07/02/2014 13:00	10.0	13.4	7.9	105.9	3,208,341.5	1,897.7	0.9	0.6
07/02/2014 14:00	10.1	13.2	7.7	113.6	3,188,555.1	2,025.7	1.0	0.8
07/02/2014 15:00	10.3	13.1	7.8	125.8	3,188,526.1	2,142.1	1.2	1.1
07/02/2014 16:00	10.1	13.2	7.7	117.6	3,170,839.9	2,037.6	1.1	0.8
07/02/2014 17:00	10.0	13.3	7.8	109.0	3,183,670.0	1,976.1	1.0	0.8
07/02/2014 18:00	10.0	13.3	7.8	111.4	3,168,465.9	1,989.8	1.0	0.8
07/02/2014 19:00	10.0	13.3	7.8	109.7	3,206,083.3	1,966.6	1.0	0.8
07/02/2014 20:00	10.0	13.3	7.8	111.4	3,204,127.0	1,965.4	1.0	0.8
07/02/2014 21:00	9.4	13.8	7.8	85.6	2,498,542.9	1,331.9	1.0	0.5
07/02/2014 22:00	32.6	16.5	43.7	248.1	1,215,227.2	443.7	6.0	1.0
07/02/2014 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	10.9	13.6	9.4	114.2	3,125,112.7	1,853.0	1.2	0.7
Minimum:	9.4	13.1	7.5	85.6	1,215,227.2	443.7	0.9	0.5
Maximum:	32.6	16.5	43.7	248.1	3,362,270.9	2,142.1	6.0	1.1
%SI	4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/03/2014 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2014 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2014 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2014 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2014 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2014 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2014 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/03/2014 07:00	44.6	16.8	64.2	78.3	1,811,748.5	529.2	0.8	0.2
07/03/2014 08:00	29.2	14.0	25.0	176.0	2,780,909.7	1,421.5	1.7	1.0
07/03/2014 09:00	9.9	13.4	7.8	102.8	3,268,070.6	1,885.3	0.9	0.6
07/03/2014 10:00	10.0	13.4	7.9	106.4	3,237,832.8	1,891.5	0.9	0.6
07/03/2014 11:00	9.9	13.4	7.8	102.6	3,242,661.7	1,918.0	0.9	0.6
07/03/2014 12:00	10.0	13.3	7.8	110.2	3,182,703.4	1,975.5	1.0	0.8
07/03/2014 13:00	10.3	13.2	7.9	123.2	3,174,656.8	2,109.6	1.1	0.8
07/03/2014 14:00	10.3	13.1	7.8	125.9	3,151,295.8	2,140.1	1.2	1.1
07/03/2014 15:00	10.2	13.1	7.7	127.2	3,176,917.3	2,157.5	1.2	1.1
07/03/2014 16:00	10.3	13.1	7.8	127.1	3,176,033.8	2,156.9	1.2	1.1
07/03/2014 17:00	10.2	13.1	7.7	126.9	3,140,643.7	2,155.8	1.2	1.1
07/03/2014 18:00	10.3	13.1	7.8	128.6	3,144,775.0	2,181.6	1.2	1.1
07/03/2014 19:00	10.2	13.1	7.7	128.6	3,141,603.7	2,179.4	1.2	1.1
07/03/2014 20:00	10.2	13.2	7.8	120.3	3,186,912.1	2,071.2	1.1	0.8
07/03/2014 21:00	10.2	13.2	7.8	114.8	3,188,370.3	2,002.3	1.0	0.8
07/03/2014 22:00	10.3	13.2	7.9	116.7	3,241,873.4	2,035.9	1.0	0.8
07/03/2014 23:00	10.7	13.1	8.1	131.0	3,216,107.7	2,207.6	1.2	1.1
Average/Sum#:	13.3	13.5	12.1	120.4	3,086,065.7	1,942.3	1.1	0.9
Minimum:	9.9	13.1	7.7	78.3	1,811,748.5	529.2	0.8	0.2
Maximum:	44.6	16.8	64.2	176.0	3,268,070.6	2,207.6	1.7	1.1
%SI	29.2	29.2	29.2	29.2	29.2	29.2	29.2	29.2

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/04/2014 00:00	10.2	13.3	7.9	116.1	3,244,569.1	2,013.9	1.0	0.8
07/04/2014 01:00	10.1	13.3	7.8	110.4	3,284,113.5	1,966.5	1.0	0.8
07/04/2014 02:00	9.7	13.5	7.7	103.7	3,294,765.7	1,900.7	0.9	0.6
07/04/2014 03:00	9.7	13.6	7.8	103.4	3,271,344.2	1,863.3	0.9	0.6
07/04/2014 04:00	9.6	13.5	7.7	104.8	3,303,086.3	1,905.5	0.9	0.6
07/04/2014 05:00	9.6	13.6	7.8	104.3	3,327,701.3	1,895.4	0.9	0.6
07/04/2014 06:00	9.5	13.6	7.7	104.2	3,282,284.9	1,893.5	0.9	0.6
07/04/2014 07:00	9.4	13.5	7.5	103.8	3,280,204.8	1,892.3	0.9	0.6
07/04/2014 08:00	9.9	13.4	7.8	108.9	3,262,403.1	1,953.5	1.0	0.8
07/04/2014 09:00	10.1	13.3	7.8	109.4	3,235,141.4	1,960.8	1.0	0.8
07/04/2014 10:00	10.0	13.3	7.8	109.8	3,250,589.6	1,993.9	1.0	0.8
07/04/2014 11:00	10.6	13.0	7.9	131.5	3,198,831.2	2,219.1	1.2	1.1
07/04/2014 12:00	10.2	13.2	7.8	122.8	3,194,867.1	2,099.7	1.1	0.8
07/04/2014 13:00	9.9	13.3	7.7	108.3	3,200,493.3	1,939.8	1.0	0.8
07/04/2014 14:00	9.9	13.3	7.7	106.7	3,185,542.0	1,954.0	1.0	0.8
07/04/2014 15:00	9.9	13.3	7.7	110.6	3,204,779.1	1,965.8	1.0	0.8
07/04/2014 16:00	10.1	13.3	7.8	113.5	3,218,469.5	1,997.7	1.0	0.8
07/04/2014 17:00	10.2	13.3	7.9	114.4	3,219,436.2	1,998.3	1.0	0.8
07/04/2014 18:00	9.6	13.7	7.9	91.4	2,747,546.5	1,484.7	0.9	0.4
07/04/2014 19:00	9.8	13.9	8.3	83.1	2,492,159.5	1,292.1	0.9	0.4
07/04/2014 20:00	18.4	14.9	18.1	142.1	2,115,217.3	973.1	1.9	0.7
07/04/2014 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2014 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/04/2014 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	10.3	13.5	8.3	109.7	3,133,978.4	1,864.9	1.0	0.7
Minimum:	9.4	13.0	7.5	83.1	2,115,217.3	973.1	0.9	0.4
Maximum:	18.4	14.9	18.1	142.1	3,327,701.3	2,219.1	1.9	1.1
%SI	12.5	12.5	12.5	12.5	12.5	12.5	12.5	12.5

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/05/2014 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2014 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2014 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2014 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2014 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2014 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2014 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2014 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2014 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2014 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/05/2014 10:00	40.1	17.3	65.7	0.1	1,777,121.6	454.2	-0.4	-0.1
07/05/2014 11:00	37.7	14.7	35.9	180.6	2,556,258.8	1,176.0	1.9	0.8
07/05/2014 12:00	10.2	13.4	8.0	111.9	3,230,004.5	1,934.1	1.0	0.8
07/05/2014 13:00	10.3	13.2	7.9	121.5	3,215,685.4	2,089.9	1.1	0.8
07/05/2014 14:00	9.9	13.4	7.8	109.6	3,235,014.6	1,937.1	1.0	0.8
07/05/2014 15:00	9.8	13.3	7.6	108.4	3,186,799.0	1,931.5	1.0	0.8
07/05/2014 16:00	9.9	13.3	7.7	110.7	3,193,204.2	1,958.7	1.0	0.8
07/05/2014 17:00	9.8	13.3	7.6	112.5	3,198,169.8	1,985.1	1.0	0.8
07/05/2014 18:00	9.7	13.3	7.5	109.1	3,164,674.5	1,941.2	1.0	0.8
07/05/2014 19:00	9.6	13.4	7.6	103.8	3,188,391.9	1,885.9	0.9	0.6
07/05/2014 20:00	9.0	13.5	7.2	101.9	3,217,633.8	1,879.7	0.9	0.6
07/05/2014 21:00	9.1	13.5	7.3	102.0	3,257,149.9	1,879.0	0.9	0.6
07/05/2014 22:00	9.4	13.7	7.7	95.0	2,864,132.6	1,547.7	1.0	0.6
07/05/2014 23:00	9.7	13.6	7.8	104.8	3,272,184.0	1,768.2	0.9	0.5
Average/Sum#:	13.9	13.8	13.8	105.1	3,039,744.6	1,740.6	0.9	0.7
Minimum:	9.0	13.2	7.2	0.1	1,777,121.6	454.2	-0.4	-0.1
Maximum:	40.1	17.3	65.7	180.6	3,272,184.0	2,089.9	1.9	0.8
%SI	41.7	41.7	41.7	41.7	41.7	41.7	41.7	41.7

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/06/2014 00:00	9.7	13.6	7.8	105.8	3,288,469.1	1,777.0	0.9	0.5
07/06/2014 01:00	9.4	13.7	7.7	92.4	2,810,884.2	1,498.4	0.9	0.4
07/06/2014 02:00	29.2	16.3	37.5	208.7	1,445,682.5	538.4	4.1	0.9
07/06/2014 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2014 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2014 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2014 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2014 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2014 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/06/2014 09:00	28.9	17.8	55.0	0.1	1,697,579.0	334.7	-0.6	-0.1
07/06/2014 10:00	51.9	15.3	54.7	201.7	2,162,729.5	900.2	2.5	0.9
07/06/2014 11:00	10.3	13.5	8.2	106.9	3,134,914.8	1,762.7	1.0	0.7
07/06/2014 12:00	10.1	13.4	7.9	107.4	3,257,201.3	1,926.6	0.9	0.6
07/06/2014 13:00	9.9	13.4	7.8	100.0	3,243,310.5	1,894.7	0.9	0.6
07/06/2014 14:00	10.0	13.4	7.9	109.2	3,245,364.6	1,895.9	1.0	0.8
07/06/2014 15:00	10.0	13.4	7.9	104.1	3,242,968.1	1,894.5	0.9	0.6
07/06/2014 16:00	10.0	13.4	7.9	105.1	3,219,316.3	1,927.7	0.9	0.6
07/06/2014 17:00	10.3	13.2	7.9	119.3	3,206,631.7	2,060.6	1.1	0.8
07/06/2014 18:00	10.4	13.1	7.9	126.4	3,183,465.1	2,138.7	1.2	1.1
07/06/2014 19:00	10.2	13.2	7.8	120.1	3,217,991.7	2,067.9	1.1	0.8
07/06/2014 20:00	10.2	13.2	7.8	121.8	3,208,607.5	2,085.3	1.1	0.8
07/06/2014 21:00	9.4	13.4	7.4	105.4	3,217,640.1	1,903.2	0.9	0.6
07/06/2014 22:00	9.0	13.5	7.2	101.4	3,206,336.0	1,873.1	0.9	0.6
07/06/2014 23:00	9.2	13.5	7.3	102.1	3,211,733.5	1,852.8	0.9	0.6
Average/Sum#:	14.3	13.9	14.6	113.2	2,955,601.4	1,685.1	1.1	0.7
Minimum:	9.0	13.1	7.2	0.1	1,445,682.5	334.7	-0.6	-0.1
Maximum:	51.9	17.8	55.0	208.7	3,288,469.1	2,138.7	4.1	1.1
%SI	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/07/2014 00:00	10.0	13.8	8.3	85.1	2,433,581.2	1,279.5	1.0	0.5
07/07/2014 01:00	10.6	13.9	8.9	84.3	2,390,786.7	1,257.0	1.0	0.5
07/07/2014 02:00	10.4	13.9	8.8	84.5	2,479,236.8	1,285.4	1.0	0.5
07/07/2014 03:00	10.2	13.9	8.6	85.5	2,579,339.8	1,337.3	0.9	0.4
07/07/2014 04:00	9.7	13.6	7.8	104.7	3,279,497.5	1,796.1	0.9	0.5
07/07/2014 05:00	9.4	13.6	7.6	103.6	3,300,312.8	1,879.8	0.9	0.6
07/07/2014 06:00	9.4	13.6	7.6	102.6	3,268,359.5	1,861.6	0.9	0.6
07/07/2014 07:00	9.2	13.6	7.4	102.2	3,267,481.7	1,861.1	0.9	0.6
07/07/2014 08:00	9.3	13.5	7.4	103.4	3,258,363.3	1,879.7	0.9	0.6
07/07/2014 09:00	9.2	13.5	7.3	102.6	3,244,842.4	1,871.9	0.9	0.6
07/07/2014 10:00	9.3	13.4	7.3	102.7	3,236,976.9	1,891.0	0.9	0.6
07/07/2014 11:00	9.5	13.4	7.5	103.4	3,223,625.0	1,883.2	0.9	0.6
07/07/2014 12:00	9.8	13.4	7.7	103.4	3,230,129.8	1,887.0	0.9	0.6
07/07/2014 13:00	9.7	13.4	7.6	105.2	3,194,140.1	1,889.3	0.9	0.6
07/07/2014 14:00	9.7	13.4	7.6	104.5	3,224,138.5	1,883.5	0.9	0.6
07/07/2014 15:00	9.6	13.4	7.6	104.4	3,180,107.7	1,881.0	0.9	0.6
07/07/2014 16:00	9.6	13.4	7.6	105.0	3,185,010.6	1,883.9	0.9	0.6
07/07/2014 17:00	9.5	13.3	7.4	105.6	3,163,704.3	1,894.4	1.0	0.8
07/07/2014 18:00	9.5	13.3	7.4	105.9	3,171,887.5	1,899.3	1.0	0.8
07/07/2014 19:00	9.6	13.3	7.5	106.9	3,196,436.9	1,914.0	1.0	0.8
07/07/2014 20:00	9.5	13.4	7.5	103.3	3,200,858.3	1,869.9	0.9	0.6
07/07/2014 21:00	9.6	13.4	7.6	101.8	3,217,107.2	1,855.9	0.9	0.6
07/07/2014 22:00	9.3	13.5	7.4	98.9	2,956,376.6	1,683.9	1.0	0.7
07/07/2014 23:00	9.2	13.5	7.3	100.3	3,236,581.9	1,843.5	0.9	0.6
Average/Sum#:	9.6	13.5	7.7	100.4	3,088,286.8	1,769.6	0.9	0.6
Minimum:	9.2	13.3	7.3	84.3	2,390,786.7	1,257.0	0.9	0.4
Maximum:	10.6	13.9	8.9	106.9	3,300,312.8	1,914.0	1.0	0.8
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/08/2014 00:00	9.3	13.4	7.3	103.7	3,230,985.7	1,887.5	0.9	0.6
07/08/2014 01:00	8.8	13.5	7.0	100.8	3,238,775.3	1,868.4	0.9	0.6
07/08/2014 02:00	9.0	13.5	7.2	100.9	3,233,228.3	1,865.2	0.9	0.6
07/08/2014 03:00	9.2	13.5	7.3	98.0	3,087,429.5	1,736.0	0.9	0.5
07/08/2014 04:00	9.5	13.4	7.5	106.4	3,215,809.3	1,925.6	1.0	0.8
07/08/2014 05:00	9.1	13.5	7.3	102.3	3,250,216.1	1,875.0	0.9	0.6
07/08/2014 06:00	9.5	13.4	7.5	105.8	3,203,628.1	1,941.7	1.0	0.8
07/08/2014 07:00	9.2	13.5	7.3	102.6	3,217,120.2	1,879.4	0.9	0.6
07/08/2014 08:00	9.2	13.4	7.2	103.5	3,201,409.9	1,893.6	0.9	0.6
07/08/2014 09:00	8.9	13.5	7.1	101.4	3,209,759.6	1,875.1	0.9	0.6
07/08/2014 10:00	9.6	13.3	7.5	108.8	3,222,602.1	1,953.2	1.0	0.8
07/08/2014 11:00	9.6	13.3	7.5	113.7	3,180,162.1	1,950.7	1.0	0.8
07/08/2014 12:00	10.6	13.1	8.0	130.0	3,206,299.5	2,083.8	1.2	1.0
07/08/2014 13:00	10.6	13.0	7.9	131.9	3,168,077.7	2,220.9	1.2	1.1
07/08/2014 14:00	10.3	13.1	7.8	127.0	3,139,186.9	2,154.8	1.2	1.1
07/08/2014 15:00	10.2	13.1	7.7	126.4	3,128,406.3	2,147.4	1.2	1.1
07/08/2014 16:00	10.3	13.1	7.8	127.2	3,138,312.8	2,154.2	1.2	1.1
07/08/2014 17:00	10.4	13.1	7.9	127.1	3,168,229.6	2,151.6	1.2	1.1
07/08/2014 18:00	10.3	13.2	7.9	122.1	3,175,847.3	2,087.2	1.1	0.8
07/08/2014 19:00	10.2	13.3	7.9	114.4	3,174,039.1	1,993.3	1.0	0.8
07/08/2014 20:00	9.5	13.4	7.5	104.6	3,187,715.6	1,885.5	0.9	0.6
07/08/2014 21:00	10.0	13.4	7.9	102.8	3,230,974.8	1,863.9	0.9	0.6
07/08/2014 22:00	9.9	13.7	8.1	92.4	2,757,169.4	1,489.9	1.0	0.6
07/08/2014 23:00	9.9	13.9	8.3	88.1	2,637,663.5	1,386.8	0.9	0.4
Average/Sum#:	9.7	13.4	7.6	110.1	3,150,127.0	1,927.9	1.0	0.8
Minimum:	8.8	13.0	7.0	88.1	2,637,663.5	1,386.8	0.9	0.4
Maximum:	10.6	13.9	8.3	131.9	3,250,216.1	2,220.9	1.2	1.1
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/09/2014 00:00	10.3	13.8	8.6	83.8	2,378,233.7	1,250.4	1.0	0.5
07/09/2014 01:00	10.2	13.8	8.5	83.6	2,374,619.9	1,248.5	1.0	0.5
07/09/2014 02:00	10.3	13.8	8.6	83.7	2,374,239.5	1,248.3	1.0	0.5
07/09/2014 03:00	10.2	13.8	8.5	83.7	2,374,619.9	1,248.5	1.0	0.5
07/09/2014 04:00	10.2	13.8	8.5	83.7	2,393,639.7	1,258.5	1.0	0.5
07/09/2014 05:00	10.0	13.8	8.3	94.1	2,936,083.9	1,543.7	0.9	0.5
07/09/2014 06:00	9.8	13.7	8.0	104.4	2,963,182.1	1,644.5	1.0	0.7
07/09/2014 07:00	10.3	13.3	8.0	111.4	3,254,940.3	1,972.8	1.0	0.8
07/09/2014 08:00	10.2	13.3	7.9	110.2	3,258,395.0	1,951.1	1.0	0.8
07/09/2014 09:00	10.3	13.3	8.0	115.1	3,239,091.4	2,010.5	1.0	0.8
07/09/2014 10:00	10.4	13.2	8.0	123.3	3,208,104.9	2,108.4	1.1	0.8
07/09/2014 11:00	10.5	13.1	7.9	128.5	3,197,090.6	2,171.2	1.2	1.1
07/09/2014 12:00	10.4	13.1	7.9	129.3	3,151,117.6	2,186.0	1.2	1.1
07/09/2014 13:00	10.3	13.1	7.8	126.7	3,146,034.0	2,159.5	1.2	1.1
07/09/2014 14:00	10.1	13.2	7.7	115.8	3,152,944.0	2,026.1	1.1	0.8
07/09/2014 15:00	10.3	13.2	7.9	120.2	3,191,215.3	2,097.3	1.1	0.8
07/09/2014 16:00	10.3	13.1	7.8	125.3	3,148,203.6	2,138.0	1.2	1.1
07/09/2014 17:00	10.2	13.1	7.7	125.1	3,143,933.3	2,135.1	1.2	1.1
07/09/2014 18:00	10.0	13.2	7.7	114.3	3,141,828.8	2,041.9	1.1	0.8
07/09/2014 19:00	10.0	13.3	7.8	109.2	3,175,131.3	1,970.8	1.0	0.8
07/09/2014 20:00	10.1	13.3	7.8	113.2	3,196,558.7	1,984.1	1.0	0.8
07/09/2014 21:00	10.1	13.3	7.8	111.2	3,189,943.7	1,956.7	1.0	0.8
07/09/2014 22:00	10.0	13.4	7.9	109.1	3,234,012.6	1,936.5	1.0	0.8
07/09/2014 23:00	9.7	13.7	7.9	89.7	2,660,700.3	1,457.2	1.0	0.6
Average/Sum#:	10.2	13.4	8.0	108.1	2,978,494.3	1,822.7	1.1	0.8
Minimum:	9.7	13.1	7.7	83.6	2,374,239.5	1,248.3	0.9	0.5
Maximum:	10.5	13.8	8.6	129.3	3,258,395.0	2,186.0	1.2	1.1
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/10/2014 00:00	10.0	13.8	8.3	77.5	2,367,392.4	1,244.7	0.9	0.4
07/10/2014 01:00	10.1	13.8	8.4	78.5	2,366,821.8	1,244.4	0.9	0.4
07/10/2014 02:00	10.1	13.8	8.4	79.0	2,367,772.8	1,244.9	0.9	0.4
07/10/2014 03:00	10.1	13.8	8.4	79.0	2,366,631.6	1,244.3	0.9	0.4
07/10/2014 04:00	10.1	13.8	8.4	79.1	2,367,772.8	1,244.9	0.9	0.4
07/10/2014 05:00	10.1	13.8	8.4	79.2	2,371,006.2	1,246.6	0.9	0.4
07/10/2014 06:00	10.2	13.8	8.5	79.1	2,373,478.7	1,247.9	0.9	0.4
07/10/2014 07:00	10.2	13.8	8.5	79.4	2,384,700.4	1,253.8	0.9	0.4
07/10/2014 08:00	10.3	13.8	8.6	79.6	2,404,290.8	1,264.1	0.9	0.4
07/10/2014 09:00	9.8	13.7	8.0	90.4	2,857,897.4	1,565.2	0.9	0.5
07/10/2014 10:00	9.3	13.6	7.5	102.2	3,230,108.1	1,863.4	0.9	0.6
07/10/2014 11:00	9.2	13.5	7.3	101.8	3,230,628.1	1,863.7	0.9	0.6
07/10/2014 12:00	9.7	13.4	7.6	104.5	3,228,246.8	1,885.9	0.9	0.6
07/10/2014 13:00	9.9	13.4	7.8	106.0	3,205,129.3	1,895.8	0.9	0.6
07/10/2014 14:00	9.5	13.4	7.5	104.9	3,208,003.4	1,897.5	0.9	0.6
07/10/2014 15:00	9.7	13.3	7.5	107.1	3,190,424.8	1,910.4	1.0	0.8
07/10/2014 16:00	9.9	13.3	7.7	111.5	3,172,231.3	1,969.0	1.0	0.8
07/10/2014 17:00	9.9	13.3	7.7	108.8	3,181,519.3	1,928.3	1.0	0.8
07/10/2014 18:00	10.2	13.3	7.9	112.7	3,180,770.1	1,974.3	1.0	0.8
07/10/2014 19:00	9.3	13.5	7.4	103.1	3,208,732.5	1,874.5	0.9	0.6
07/10/2014 20:00	9.3	13.5	7.4	102.2	3,237,388.6	1,867.6	0.9	0.6
07/10/2014 21:00	9.6	13.5	7.7	103.9	3,255,243.1	1,877.9	0.9	0.6
07/10/2014 22:00	9.3	13.6	7.5	101.8	3,262,390.2	1,858.2	0.9	0.6
07/10/2014 23:00	9.8	13.6	7.9	102.7	2,909,048.7	1,635.7	1.0	0.7
Average/Sum#:	9.8	13.6	7.9	94.8	2,871,984.6	1,629.3	0.9	0.6
Minimum:	9.2	13.3	7.3	77.5	2,366,631.6	1,244.3	0.9	0.4
Maximum:	10.3	13.8	8.6	112.7	3,262,390.2	1,974.3	1.0	0.8
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/11/2014 00:00	34.0	17.1	52.8	239.4	976,026.1	313.6	7.2	0.9
07/11/2014 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/11/2014 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/11/2014 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/11/2014 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/11/2014 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/11/2014 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/11/2014 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/11/2014 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/11/2014 09:00	46.0	16.7	64.6	106.8	1,871,318.4	546.6	1.2	0.3
07/11/2014 10:00	55.3	14.8	53.5	243.0	2,147,302.3	956.5	3.0	1.1
07/11/2014 11:00	10.7	13.9	9.0	88.6	2,498,221.3	1,277.0	1.0	0.5
07/11/2014 12:00	10.4	13.9	8.8	84.3	2,498,808.2	1,277.3	0.9	0.4
07/11/2014 13:00	10.3	13.9	8.7	84.0	2,499,786.4	1,277.8	0.9	0.4
07/11/2014 14:00	10.4	13.9	8.8	84.2	2,504,872.8	1,280.4	0.9	0.4
07/11/2014 15:00	10.3	13.9	8.7	84.1	2,544,549.3	1,282.1	0.9	0.4
07/11/2014 16:00	10.2	13.9	8.6	83.9	2,544,946.2	1,282.3	0.9	0.4
07/11/2014 17:00	10.3	13.9	8.7	83.9	2,542,366.1	1,281.0	0.9	0.4
07/11/2014 18:00	10.1	13.9	8.5	83.6	2,499,786.4	1,277.8	0.9	0.4
07/11/2014 19:00	10.2	13.9	8.6	83.7	2,492,352.4	1,274.0	1.0	0.5
07/11/2014 20:00	10.4	13.9	8.8	84.1	2,492,156.7	1,273.9	1.0	0.5
07/11/2014 21:00	10.4	13.8	8.6	84.1	2,478,071.2	1,266.7	1.0	0.5
07/11/2014 22:00	10.3	13.8	8.6	83.9	2,442,976.0	1,266.6	1.0	0.5
07/11/2014 23:00	10.3	13.8	8.6	83.9	2,443,554.6	1,266.9	1.0	0.5
Average/Sum#:	16.9	14.3	17.7	105.3	2,342,318.4	1,150.0	1.5	0.5
Minimum:	10.1	13.8	8.5	83.6	976,026.1	313.6	0.9	0.3
Maximum:	55.3	17.1	64.6	243.0	2,544,946.2	1,282.3	7.2	1.1
%SI	33.3	33.3	33.3	33.3	33.3	33.3	33.3	33.3

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/12/2014 00:00	29.4	16.0	35.4	203.6	1,581,685.2	600.6	3.6	0.8
07/12/2014 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/12/2014 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/12/2014 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/12/2014 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/12/2014 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/12/2014 06:00	39.8	17.3	65.2	40.9	1,852,872.7	446.5	0.2	0.0
07/12/2014 07:00	58.7	15.1	59.7	263.9	2,218,692.0	988.3	3.0	1.2
07/12/2014 08:00	10.0	13.8	8.3	88.3	2,552,998.3	1,305.0	1.0	0.5
07/12/2014 09:00	10.2	13.8	8.5	84.4	2,553,389.6	1,305.2	0.9	0.4
07/12/2014 10:00	9.9	13.8	8.2	94.1	2,975,122.7	1,542.5	0.9	0.5
07/12/2014 11:00	9.2	13.8	7.6	95.2	3,020,448.7	1,566.0	0.9	0.5
07/12/2014 12:00	9.8	13.9	8.3	83.1	2,631,642.4	1,345.2	0.9	0.4
07/12/2014 13:00	9.5	13.7	7.8	98.6	3,194,809.2	1,656.4	0.9	0.5
07/12/2014 14:00	9.8	13.5	7.8	104.1	3,178,325.9	1,763.9	0.9	0.5
07/12/2014 15:00	10.5	13.2	8.0	120.8	3,227,225.5	2,097.4	1.1	0.8
07/12/2014 16:00	10.2	13.3	7.9	111.3	3,278,101.4	1,962.9	1.0	0.8
07/12/2014 17:00	10.2	13.3	7.9	111.1	3,244,380.9	1,966.4	1.0	0.8
07/12/2014 18:00	10.1	13.3	7.8	109.8	3,218,972.3	1,951.0	1.0	0.8
07/12/2014 19:00	9.9	13.4	7.8	103.8	3,271,017.5	1,887.0	0.9	0.6
07/12/2014 20:00	9.7	13.4	7.6	103.8	3,269,804.1	1,886.3	0.9	0.6
07/12/2014 21:00	10.3	13.3	8.0	111.8	3,272,759.3	1,983.6	1.0	0.8
07/12/2014 22:00	10.4	13.2	8.0	116.7	3,292,901.8	2,043.9	1.0	0.8
07/12/2014 23:00	10.3	13.3	8.0	112.1	3,261,374.9	1,976.7	1.0	0.8
Average/Sum#:	15.2	13.9	15.1	113.5	2,899,817.1	1,593.4	1.2	0.6
Minimum:	9.2	13.2	7.6	40.9	1,581,685.2	446.5	0.2	0.0
Maximum:	58.7	17.3	65.2	263.9	3,292,901.8	2,097.4	3.6	1.2
%SI	20.8	20.8	20.8	20.8	20.8	20.8	20.8	20.8

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/13/2014 00:00	9.8	13.6	7.9	100.4	2,987,507.4	1,658.0	1.0	0.7
07/13/2014 01:00	27.6	16.1	33.9	200.4	1,531,385.2	581.5	3.7	0.8
07/13/2014 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/13/2014 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/13/2014 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/13/2014 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/13/2014 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/13/2014 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/13/2014 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/13/2014 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/13/2014 10:00	35.5	17.4	59.8	0.1	1,895,548.4	429.1	-0.4	-0.1
07/13/2014 11:00	41.1	14.6	38.5	205.1	2,558,173.1	1,158.2	2.2	0.9
07/13/2014 12:00	10.1	13.4	7.9	108.7	3,254,158.1	1,924.8	1.0	0.8
07/13/2014 13:00	10.4	13.2	8.0	118.8	3,221,726.5	2,070.3	1.1	0.8
07/13/2014 14:00	10.4	13.1	7.9	124.1	3,196,025.8	2,123.8	1.1	0.8
07/13/2014 15:00	10.5	13.0	7.8	130.7	3,185,857.7	2,210.1	1.2	1.1
07/13/2014 16:00	10.2	13.2	7.8	119.4	3,202,274.4	2,057.8	1.1	0.8
07/13/2014 17:00	10.2	13.2	7.8	114.1	3,220,376.6	2,022.4	1.0	0.8
07/13/2014 18:00	10.1	13.2	7.7	116.5	3,165,393.3	2,034.1	1.1	0.8
07/13/2014 19:00	9.9	13.3	7.7	107.7	3,194,432.9	1,912.8	1.0	0.8
07/13/2014 20:00	9.2	13.7	7.5	91.8	2,895,863.6	1,543.7	0.9	0.5
07/13/2014 21:00	9.6	13.5	7.7	102.8	3,174,181.6	1,761.6	0.9	0.5
07/13/2014 22:00	9.8	13.3	7.6	108.2	3,212,803.2	1,923.8	1.0	0.8
07/13/2014 23:00	9.5	13.7	7.8	91.8	2,760,234.3	1,471.4	1.0	0.6
Average/Sum#:	14.6	13.8	14.6	115.0	2,915,996.4	1,680.2	1.2	0.7
Minimum:	9.2	13.0	7.5	0.1	1,531,385.2	429.1	-0.4	-0.1
Maximum:	41.1	17.4	59.8	205.1	3,254,158.1	2,210.1	3.7	1.1
%SI	33.3	33.3	33.3	33.3	33.3	33.3	33.3	33.3

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/14/2014 00:00	9.5	13.9	8.0	86.2	2,707,743.3	1,384.1	0.9	0.4
07/14/2014 01:00	9.3	13.9	7.8	89.1	2,885,572.8	1,475.0	0.9	0.4
07/14/2014 02:00	9.6	13.9	8.1	83.6	2,760,955.2	1,411.3	0.9	0.4
07/14/2014 03:00	9.7	13.7	7.9	101.6	3,309,956.6	1,716.1	0.9	0.5
07/14/2014 04:00	9.5	13.7	7.8	102.8	3,266,647.7	1,717.5	0.9	0.5
07/14/2014 05:00	9.7	13.8	8.1	97.1	3,086,798.3	1,600.4	0.9	0.5
07/14/2014 06:00	10.4	13.4	8.2	116.7	3,157,637.9	1,983.0	1.1	0.8
07/14/2014 07:00	10.4	13.4	8.2	113.6	3,293,632.6	1,972.2	1.0	0.8
07/14/2014 08:00	9.9	13.4	7.8	107.5	3,270,014.3	1,910.3	0.9	0.6
07/14/2014 09:00	10.2	13.4	8.0	109.8	3,263,287.6	1,930.2	1.0	0.8
07/14/2014 10:00	10.0	13.4	7.9	105.0	3,275,524.5	1,889.6	0.9	0.6
07/14/2014 11:00	9.8	13.4	7.7	107.1	3,257,689.4	1,903.1	0.9	0.6
07/14/2014 12:00	9.7	13.3	7.5	107.0	3,221,697.7	1,905.6	1.0	0.8
07/14/2014 13:00	9.7	13.3	7.5	111.2	3,207,876.6	1,967.7	1.0	0.8
07/14/2014 14:00	9.9	13.1	7.5	121.7	3,169,841.2	2,106.4	1.1	0.8
07/14/2014 15:00	9.9	13.1	7.5	126.5	3,156,899.4	2,097.8	1.2	1.0
07/14/2014 16:00	9.7	13.2	7.4	117.7	3,166,447.7	2,057.9	1.1	0.8
07/14/2014 17:00	9.6	13.2	7.4	114.1	3,161,009.3	2,008.2	1.1	0.8
07/14/2014 18:00	8.8	13.7	7.2	94.5	2,928,879.9	1,561.3	0.9	0.5
07/14/2014 19:00	9.2	13.9	7.8	88.3	2,831,774.0	1,447.5	0.9	0.4
07/14/2014 20:00	9.0	13.7	7.4	97.3	3,151,412.0	1,633.9	0.9	0.5
07/14/2014 21:00	9.0	13.8	7.5	97.5	3,160,862.9	1,638.8	0.9	0.5
07/14/2014 22:00	8.9	13.8	7.4	91.6	2,913,402.2	1,510.5	0.9	0.5
07/14/2014 23:00	9.4	13.7	7.7	98.4	3,134,079.9	1,647.8	0.9	0.5
Average/Sum#:	9.6	13.5	7.7	103.6	3,114,151.8	1,769.8	1.0	0.6
Minimum:	8.8	13.1	7.2	83.6	2,707,743.3	1,384.1	0.9	0.4
Maximum:	10.4	13.9	8.2	126.5	3,309,956.6	2,106.4	1.2	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/15/2014 00:00	9.7	13.6	7.8	103.7	3,257,541.7	1,736.5	0.9	0.5
07/15/2014 01:00	9.8	13.6	7.9	105.6	3,302,376.3	1,760.4	0.9	0.5
07/15/2014 02:00	9.7	13.6	7.8	105.1	3,340,444.5	1,756.3	0.9	0.5
07/15/2014 03:00	9.9	13.5	7.9	106.6	3,275,115.4	1,793.7	0.9	0.5
07/15/2014 04:00	10.2	13.4	8.0	109.8	3,330,782.5	1,945.8	0.9	0.6
07/15/2014 05:00	10.2	13.3	7.9	114.4	3,338,055.4	1,998.8	1.0	0.8
07/15/2014 06:00	9.9	13.4	7.8	111.0	3,384,612.4	1,903.1	0.9	0.6
07/15/2014 07:00	9.3	13.6	7.5	101.5	3,342,656.8	1,855.1	0.9	0.6
07/15/2014 08:00	9.2	13.5	7.3	99.7	3,322,475.8	1,843.9	0.9	0.6
07/15/2014 09:00	9.8	13.5	7.8	102.7	3,302,446.9	1,856.9	0.9	0.6
07/15/2014 10:00	9.9	13.4	7.8	105.6	3,265,643.8	1,883.9	0.9	0.6
07/15/2014 11:00	9.8	13.4	7.7	104.5	3,248,656.0	1,874.1	0.9	0.6
07/15/2014 12:00	9.8	13.4	7.7	103.1	3,273,451.0	1,864.5	0.9	0.6
07/15/2014 13:00	9.9	13.4	7.8	104.5	3,270,641.9	1,862.9	0.9	0.6
07/15/2014 14:00	9.9	13.3	7.7	121.7	3,257,708.5	1,926.9	1.1	0.8
07/15/2014 15:00	9.9	13.3	7.7	110.8	3,241,694.7	1,941.1	1.0	0.8
07/15/2014 16:00	9.8	13.4	7.7	107.7	3,251,869.4	1,899.7	1.0	0.8
07/15/2014 17:00	9.7	13.3	7.5	109.0	3,243,507.0	1,918.5	1.0	0.8
07/15/2014 18:00	9.4	13.3	7.3	106.3	3,202,762.4	1,894.4	1.0	0.8
07/15/2014 19:00	9.6	13.3	7.5	107.9	3,235,730.0	1,913.9	1.0	0.8
07/15/2014 20:00	9.6	13.4	7.6	107.4	3,219,330.8	1,904.2	1.0	0.8
07/15/2014 21:00	9.6	13.3	7.5	106.8	3,235,730.0	1,913.9	1.0	0.8
07/15/2014 22:00	9.5	13.4	7.5	106.4	3,253,581.2	1,900.7	0.9	0.6
07/15/2014 23:00	9.7	13.3	7.5	108.9	3,255,003.4	1,925.3	1.0	0.8
Average/Sum#:	9.7	13.4	7.7	107.1	3,277,159.1	1,878.1	0.9	0.7
Minimum:	9.2	13.3	7.3	99.7	3,202,762.4	1,736.5	0.9	0.5
Maximum:	10.2	13.6	8.0	121.7	3,384,612.4	1,998.8	1.1	0.8
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/16/2014 00:00	9.5	13.4	7.5	106.7	3,237,832.8	1,891.5	1.0	0.8
07/16/2014 01:00	9.3	13.7	7.6	92.4	2,763,798.6	1,473.3	1.0	0.6
07/16/2014 02:00	9.4	13.8	7.8	89.4	2,753,893.1	1,427.8	0.9	0.4
07/16/2014 03:00	9.4	13.8	7.8	91.1	2,879,899.5	1,472.1	0.9	0.4
07/16/2014 04:00	9.5	13.6	7.7	104.6	3,260,355.6	1,738.0	0.9	0.5
07/16/2014 05:00	9.3	13.7	7.6	96.3	3,014,046.8	1,606.7	0.9	0.5
07/16/2014 06:00	9.7	13.6	7.8	119.5	3,167,071.5	1,711.4	1.1	0.7
07/16/2014 07:00	9.3	13.8	7.7	93.0	3,063,460.2	1,588.3	0.9	0.5
07/16/2014 08:00	9.4	13.7	7.7	96.9	3,168,247.7	1,688.9	0.9	0.5
07/16/2014 09:00	9.3	13.5	7.4	101.0	3,271,501.5	1,839.5	0.9	0.6
07/16/2014 10:00	9.2	13.5	7.3	100.7	3,272,212.9	1,839.9	0.9	0.6
07/16/2014 11:00	9.5	13.4	7.5	101.3	3,266,521.8	1,836.7	0.9	0.6
07/16/2014 12:00	9.6	13.4	7.6	101.4	3,260,652.8	1,833.4	0.9	0.6
07/16/2014 13:00	9.6	13.4	7.6	101.8	3,263,854.1	1,835.2	0.9	0.6
07/16/2014 14:00	9.5	13.4	7.5	102.4	3,227,276.8	1,838.2	0.9	0.6
07/16/2014 15:00	9.5	13.4	7.5	102.6	3,230,963.7	1,840.3	0.9	0.6
07/16/2014 16:00	9.4	13.4	7.4	104.6	3,235,135.1	1,866.3	0.9	0.6
07/16/2014 17:00	9.3	13.4	7.3	105.6	3,217,291.4	1,879.5	1.0	0.8
07/16/2014 18:00	9.4	13.4	7.4	105.8	3,220,030.3	1,881.1	1.0	0.8
07/16/2014 19:00	9.5	13.4	7.5	104.9	3,234,961.8	1,866.2	0.9	0.6
07/16/2014 20:00	9.1	13.4	7.2	103.5	3,221,614.2	1,858.5	0.9	0.6
07/16/2014 21:00	8.8	13.7	7.2	95.6	2,968,649.4	1,582.5	0.9	0.5
07/16/2014 22:00	9.3	13.6	7.5	100.8	3,131,725.5	1,692.3	0.9	0.5
07/16/2014 23:00	9.3	13.6	7.5	100.8	3,059,659.3	1,675.7	1.0	0.7
Average/Sum#:	9.4	13.5	7.5	100.9	3,141,277.4	1,740.1	0.9	0.6
Minimum:	8.8	13.4	7.2	89.4	2,753,893.1	1,427.8	0.9	0.4
Maximum:	9.7	13.8	7.8	119.5	3,272,212.9	1,891.5	1.1	0.8
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/17/2014 00:00	27.0	16.0	32.5	205.4	1,568,378.5	607.0	3.8	0.9
07/17/2014 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/17/2014 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/17/2014 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/17/2014 04:00	40.6	17.2	64.7	173.0	1,862,417.2	476.0	2.1	0.4
07/17/2014 05:00	34.1	14.7	32.5	203.6	2,459,576.0	1,095.6	2.2	0.9
07/17/2014 06:00	9.7	13.6	7.8	105.1	3,306,399.1	1,738.4	0.9	0.5
07/17/2014 07:00	9.5	13.8	7.9	88.6	2,636,431.3	1,366.9	1.0	0.5
07/17/2014 08:00	9.5	13.7	7.8	103.5	3,264,936.0	1,716.6	0.9	0.5
07/17/2014 09:00	9.2	13.8	7.6	92.1	2,898,357.8	1,502.7	0.9	0.5
07/17/2014 10:00	9.2	13.7	7.5	95.2	2,994,162.0	1,596.1	0.9	0.5
07/17/2014 11:00	9.1	13.5	7.3	101.0	3,262,964.8	1,834.7	0.9	0.6
07/17/2014 12:00	9.4	13.4	7.4	101.8	3,272,568.6	1,840.1	0.9	0.6
07/17/2014 13:00	9.4	13.4	7.4	102.7	3,236,933.0	1,843.7	0.9	0.6
07/17/2014 14:00	9.4	13.4	7.4	103.1	3,241,673.3	1,846.4	0.9	0.6
07/17/2014 15:00	9.3	13.4	7.3	103.7	3,216,760.5	1,855.7	0.9	0.6
07/17/2014 16:00	9.3	13.4	7.3	104.0	3,228,548.0	1,862.5	0.9	0.6
07/17/2014 17:00	9.4	13.4	7.4	105.4	3,217,976.1	1,879.9	0.9	0.6
07/17/2014 18:00	9.5	13.3	7.4	111.5	3,222,437.1	1,953.1	1.0	0.8
07/17/2014 19:00	9.7	13.3	7.5	113.7	3,220,592.7	1,975.5	1.0	0.8
07/17/2014 20:00	9.2	13.4	7.2	105.6	3,223,796.2	1,883.3	1.0	0.8
07/17/2014 21:00	9.4	13.4	7.4	108.7	3,246,719.2	1,920.4	1.0	0.8
07/17/2014 22:00	8.9	13.7	7.3	98.1	3,045,858.9	1,645.9	0.9	0.5
07/17/2014 23:00	9.2	13.8	7.6	88.4	2,719,561.1	1,410.0	0.9	0.4
Average/Sum#:	12.9	13.9	12.6	115.0	2,968,907.0	1,611.9	1.2	0.6
Minimum:	8.9	13.3	7.2	88.4	1,568,378.5	476.0	0.9	0.4
Maximum:	40.6	17.2	64.7	205.4	3,306,399.1	1,975.5	3.8	0.9
%SI	12.5	12.5	12.5	12.5	12.5	12.5	12.5	12.5

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/18/2014 00:00	27.2	16.0	32.8	207.0	1,584,914.9	613.4	3.8	0.9
07/18/2014 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/18/2014 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/18/2014 03:00	47.5	16.2	59.6	260.1	1,904,108.5	625.7	3.4	0.8
07/18/2014 04:00	11.9	13.8	9.9	118.3	2,583,968.8	1,339.7	1.4	0.7
07/18/2014 05:00	9.6	13.8	8.0	94.5	2,921,117.2	1,514.5	0.9	0.5
07/18/2014 06:00	9.6	13.8	8.0	101.8	2,805,584.1	1,454.6	1.1	0.6
07/18/2014 07:00	9.6	13.7	7.9	99.8	3,046,208.5	1,601.6	0.9	0.5
07/18/2014 08:00	9.3	13.8	7.7	100.3	3,134,245.9	1,625.0	0.9	0.5
07/18/2014 09:00	9.3	13.7	7.6	94.2	2,934,132.4	1,564.1	0.9	0.5
07/18/2014 10:00	9.4	13.5	7.5	104.6	3,303,514.0	1,857.5	0.9	0.6
07/18/2014 11:00	9.1	13.5	7.3	102.6	3,286,974.2	1,848.2	0.9	0.6
07/18/2014 12:00	8.8	13.5	7.0	99.9	3,267,411.0	1,837.2	0.9	0.6
07/18/2014 13:00	9.2	13.5	7.3	101.7	3,274,880.6	1,841.4	0.9	0.6
07/18/2014 14:00	9.6	13.4	7.6	104.2	3,239,039.8	1,844.9	0.9	0.6
07/18/2014 15:00	9.6	13.4	7.6	106.8	3,254,203.0	1,877.3	1.0	0.8
07/18/2014 16:00	9.6	13.4	7.6	108.0	3,262,653.6	1,906.0	1.0	0.8
07/18/2014 17:00	9.9	13.1	7.5	126.7	3,198,132.6	2,125.2	1.2	1.1
07/18/2014 18:00	10.0	13.1	7.6	133.2	3,200,285.2	2,150.0	1.2	1.1
07/18/2014 19:00	9.9	13.1	7.5	126.0	3,221,070.8	2,093.4	1.2	1.0
07/18/2014 20:00	9.8	13.2	7.5	117.0	3,218,630.6	1,997.8	1.1	0.8
07/18/2014 21:00	9.3	13.4	7.3	103.6	3,234,961.8	1,866.2	0.9	0.6
07/18/2014 22:00	8.8	13.6	7.1	94.8	2,920,343.1	1,599.4	0.9	0.5
07/18/2014 23:00	9.4	13.8	7.8	80.9	2,512,025.8	1,302.4	0.9	0.4
Average/Sum#:	12.1	13.7	11.2	117.5	2,968,563.9	1,658.4	1.2	0.7
Minimum:	8.8	13.1	7.0	80.9	1,584,914.9	613.4	0.9	0.4
Maximum:	47.5	16.2	59.6	260.1	3,303,514.0	2,150.0	3.8	1.1
%SI	8.3	8.3	8.3	8.3	8.3	8.3	8.3	8.3

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/19/2014 00:00	21.9	15.3	23.1	170.0	2,015,178.8	853.5	2.4	0.8
07/19/2014 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/19/2014 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/19/2014 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/19/2014 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/19/2014 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/19/2014 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/19/2014 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/19/2014 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/19/2014 09:00	34.0	17.5	59.0	0.1	1,783,343.9	403.7	-0.4	-0.1
07/19/2014 10:00	36.3	14.5	33.5	175.9	2,604,297.4	1,198.1	1.9	0.8
07/19/2014 11:00	10.2	13.2	7.8	126.8	3,292,191.8	2,067.5	1.1	0.8
07/19/2014 12:00	10.2	13.1	7.7	139.1	3,208,769.7	2,155.7	1.3	1.1
07/19/2014 13:00	10.3	13.0	7.7	144.2	3,203,732.3	2,222.5	1.3	1.1
07/19/2014 14:00	10.2	13.0	7.6	140.8	3,194,692.3	2,192.9	1.3	1.1
07/19/2014 15:00	10.0	13.1	7.6	136.8	3,178,812.8	2,182.0	1.3	1.1
07/19/2014 16:00	9.9	13.1	7.5	128.3	3,155,418.8	2,142.9	1.2	1.1
07/19/2014 17:00	9.9	13.1	7.5	127.8	3,174,683.0	2,132.8	1.2	1.1
07/19/2014 18:00	9.6	13.2	7.4	114.6	3,201,230.9	1,987.0	1.0	0.8
07/19/2014 19:00	9.8	13.2	7.5	133.5	3,197,682.9	2,078.2	1.2	1.0
07/19/2014 20:00	10.0	13.1	7.6	134.0	3,198,499.0	2,148.8	1.2	1.1
07/19/2014 21:00	9.8	13.2	7.5	119.7	3,224,039.0	2,024.7	1.1	0.8
07/19/2014 22:00	8.7	13.7	7.1	97.3	2,916,493.5	1,533.4	1.0	0.6
07/19/2014 23:00	9.0	13.8	7.5	92.1	2,897,972.0	1,502.5	0.9	0.5
Average/Sum#:	13.7	13.7	13.4	123.8	2,965,439.9	1,801.6	1.2	0.9
Minimum:	8.7	13.0	7.1	0.1	1,783,343.9	403.7	-0.4	-0.1
Maximum:	36.3	17.5	59.0	175.9	3,292,191.8	2,222.5	2.4	1.1
%SI	33.3	33.3	33.3	33.3	33.3	33.3	33.3	33.3

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/20/2014 00:00	24.9	16.0	30.0	200.0	1,555,459.4	602.0	3.7	0.8
07/20/2014 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/20/2014 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/20/2014 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/20/2014 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/20/2014 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/20/2014 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/20/2014 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/20/2014 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/20/2014 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/20/2014 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/20/2014 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/20/2014 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/20/2014 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/20/2014 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/20/2014 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/20/2014 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/20/2014 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/20/2014 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/20/2014 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/20/2014 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/20/2014 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/20/2014 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/20/2014 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	24.9	16.0	30.0	200.0	1,555,459.4	602.0	3.7	0.8
Minimum:	24.9	16.0	30.0	200.0	1,555,459.4	602.0	3.7	0.8
Maximum:	24.9	16.0	30.0	200.0	1,555,459.4	602.0	3.7	0.8
%SI	95.8	95.8	95.8	95.8	95.8	95.8	95.8	95.8

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/21/2014 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
07/21/2014 01:00	42.6	17.1	66.1	0.1	1,866,721.1	477.1	-0.3	0.0
07/21/2014 02:00	54.7	16.6	75.1	257.0	1,891,435.9	580.1	3.3	0.8
07/21/2014 03:00	38.4	14.4	34.9	206.7	2,416,392.1	1,129.3	2.3	1.0
07/21/2014 04:00	10.2	13.7	8.4	104.4	3,124,216.4	1,619.8	1.0	0.6
07/21/2014 05:00	10.1	13.7	8.3	103.6	3,207,539.1	1,663.0	0.9	0.5
07/21/2014 06:00	9.7	13.8	8.1	103.1	3,215,799.7	1,643.8	0.9	0.5
07/21/2014 07:00	9.8	13.8	8.1	100.5	3,159,319.9	1,638.0	0.9	0.5
07/21/2014 08:00	10.4	13.4	8.2	109.0	3,318,860.7	1,914.6	0.9	0.6
07/21/2014 09:00	10.5	13.3	8.2	113.9	3,295,469.7	1,973.3	1.0	0.8
07/21/2014 10:00	10.4	13.3	8.1	113.1	3,298,141.7	1,974.9	1.0	0.8
07/21/2014 11:00	10.4	13.3	8.1	112.4	3,275,429.3	1,961.3	1.0	0.8
07/21/2014 12:00	10.3	13.3	8.0	111.1	3,294,395.5	1,948.6	1.0	0.8
07/21/2014 13:00	10.3	13.3	8.0	110.1	3,260,075.4	1,928.3	1.0	0.8
07/21/2014 14:00	10.2	13.3	7.9	110.7	3,235,682.6	1,937.5	1.0	0.8
07/21/2014 15:00	10.4	13.3	8.1	115.8	3,234,097.1	2,007.4	1.0	0.8
07/21/2014 16:00	10.3	13.2	7.9	116.7	3,241,508.1	2,012.0	1.0	0.8
07/21/2014 17:00	10.7	13.1	8.1	135.5	3,218,736.3	2,185.9	1.2	1.1
07/21/2014 18:00	10.8	13.0	8.1	143.9	3,181,017.5	2,253.2	1.3	1.1
07/21/2014 19:00	10.9	13.0	8.1	145.3	3,187,370.5	2,257.7	1.4	1.1
07/21/2014 20:00	11.0	13.0	8.2	149.9	3,223,567.9	2,259.8	1.4	1.1
07/21/2014 21:00	10.8	13.1	8.2	136.4	3,226,929.5	2,167.9	1.2	1.1
07/21/2014 22:00	10.5	13.2	8.0	120.2	3,265,352.2	2,026.8	1.1	0.8
07/21/2014 23:00	10.2	13.3	7.9	113.2	3,270,586.2	1,958.4	1.0	0.8
Average/Sum#:	14.9	13.7	14.7	123.2	3,082,984.5	1,805.2	1.2	0.8
Minimum:	9.7	13.0	7.9	0.1	1,866,721.1	477.1	-0.3	0.0
Maximum:	54.7	17.1	75.1	257.0	3,318,860.7	2,259.8	3.3	1.1
%SI	4.2	4.2	4.2	4.2	4.2	4.2	4.2	4.2

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/22/2014 00:00	9.5	13.6	7.7	104.1	3,301,202.0	1,856.2	0.9	0.6
07/22/2014 01:00	9.8	13.5	7.8	107.2	3,330,191.1	1,872.5	0.9	0.6
07/22/2014 02:00	9.8	13.6	7.9	105.6	3,322,010.1	1,867.9	0.9	0.6
07/22/2014 03:00	9.9	13.6	8.0	105.2	3,303,336.2	1,857.4	0.9	0.6
07/22/2014 04:00	10.2	13.4	8.0	112.0	3,343,128.9	1,928.6	1.0	0.8
07/22/2014 05:00	9.9	13.5	7.9	109.3	3,353,844.8	1,885.8	0.9	0.6
07/22/2014 06:00	10.0	13.5	8.0	110.3	3,324,322.2	1,869.2	1.0	0.7
07/22/2014 07:00	10.3	13.3	8.0	113.9	3,338,485.5	1,950.3	1.0	0.8
07/22/2014 08:00	9.7	13.5	7.7	106.5	3,327,701.3	1,871.1	0.9	0.6
07/22/2014 09:00	9.6	13.5	7.7	106.9	3,304,758.9	1,858.2	0.9	0.6
07/22/2014 10:00	9.5	13.5	7.6	104.1	3,250,802.8	1,851.6	0.9	0.6
07/22/2014 11:00	10.3	13.3	8.0	113.6	3,262,069.1	1,953.3	1.0	0.8
07/22/2014 12:00	10.3	13.2	7.9	118.6	3,229,930.7	2,028.4	1.1	0.8
07/22/2014 13:00	10.2	13.2	7.8	115.9	3,239,829.9	1,987.3	1.0	0.8
07/22/2014 14:00	10.2	13.2	7.8	117.7	3,216,714.2	2,020.1	1.1	0.8
07/22/2014 15:00	10.5	13.1	7.9	130.9	3,205,495.0	2,153.5	1.2	1.1
07/22/2014 16:00	10.4	13.1	7.9	124.5	3,224,148.2	2,095.4	1.1	0.8
07/22/2014 17:00	10.2	13.2	7.8	120.2	3,220,351.0	2,045.9	1.1	0.8
07/22/2014 18:00	10.6	13.1	8.0	130.5	3,231,540.6	2,147.4	1.2	1.1
07/22/2014 19:00	10.8	13.2	8.3	127.6	3,271,835.0	2,102.5	1.1	0.8
07/22/2014 20:00	10.7	13.2	8.2	123.7	3,272,766.9	2,079.2	1.1	0.8
07/22/2014 21:00	10.7	13.2	8.2	124.3	3,310,344.6	2,078.9	1.1	0.8
07/22/2014 22:00	10.4	13.3	8.1	115.0	3,311,502.0	1,982.9	1.0	0.8
07/22/2014 23:00	9.9	13.7	8.1	97.5	2,893,237.3	1,542.3	1.0	0.6
Average/Sum#:	10.1	13.4	7.9	114.4	3,266,231.2	1,953.6	1.0	0.7
Minimum:	9.5	13.1	7.6	97.5	2,893,237.3	1,542.3	0.9	0.6
Maximum:	10.8	13.7	8.3	130.9	3,353,844.8	2,153.5	1.2	1.1
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/23/2014 00:00	10.6	13.8	8.8	85.5	2,480,779.8	1,286.2	1.0	0.5
07/23/2014 01:00	10.4	13.8	8.6	85.2	2,450,498.1	1,270.5	1.0	0.5
07/23/2014 02:00	10.3	13.8	8.6	84.9	2,416,166.1	1,252.7	1.0	0.5
07/23/2014 03:00	10.4	13.8	8.6	85.0	2,415,780.3	1,252.5	1.0	0.5
07/23/2014 04:00	10.4	13.8	8.6	85.2	2,454,355.7	1,272.5	1.0	0.5
07/23/2014 05:00	10.2	13.8	8.5	99.1	2,966,829.0	1,538.2	0.9	0.5
07/23/2014 06:00	10.1	13.4	7.9	109.7	3,393,363.4	1,932.8	0.9	0.6
07/23/2014 07:00	10.2	13.4	8.0	117.6	3,349,889.4	1,932.5	1.0	0.8
07/23/2014 08:00	10.0	13.5	8.0	109.3	3,349,998.3	1,908.1	0.9	0.6
07/23/2014 09:00	10.0	13.5	8.0	115.7	3,332,792.7	1,898.3	1.0	0.8
07/23/2014 10:00	9.9	13.6	8.0	110.1	3,335,526.5	1,875.5	0.9	0.6
07/23/2014 11:00	9.8	13.5	7.8	107.8	3,338,016.4	1,876.9	0.9	0.6
07/23/2014 12:00	9.7	13.5	7.7	107.5	3,337,482.9	1,876.6	0.9	0.6
07/23/2014 13:00	9.5	13.6	7.7	104.6	3,323,255.1	1,868.6	0.9	0.6
07/23/2014 14:00	10.0	13.4	7.9	108.4	3,309,846.7	1,909.4	0.9	0.6
07/23/2014 15:00	10.4	13.2	8.0	117.5	3,257,618.9	2,022.0	1.0	0.8
07/23/2014 16:00	10.5	13.1	7.9	127.3	3,239,688.8	2,105.5	1.2	1.1
07/23/2014 17:00	10.3	13.3	8.0	115.3	3,236,895.4	1,985.5	1.0	0.8
07/23/2014 18:00	10.4	13.2	8.0	118.8	3,246,968.9	2,039.1	1.1	0.8
07/23/2014 19:00	10.4	13.2	8.0	117.4	3,249,563.5	2,017.0	1.0	0.8
07/23/2014 20:00	10.3	13.3	8.0	113.5	3,291,294.6	1,970.8	1.0	0.8
07/23/2014 21:00	10.1	13.3	7.8	111.3	3,275,967.4	1,937.7	1.0	0.8
07/23/2014 22:00	9.5	13.5	7.6	105.0	3,295,923.6	1,877.3	0.9	0.6
07/23/2014 23:00	9.9	13.4	7.8	108.7	3,289,186.2	1,921.5	1.0	0.8
Average/Sum#:	10.1	13.5	8.1	106.3	3,109,903.7	1,784.5	1.0	0.7
Minimum:	9.5	13.1	7.6	84.9	2,415,780.3	1,252.5	0.9	0.5
Maximum:	10.6	13.8	8.8	127.3	3,393,363.4	2,105.5	1.2	1.1
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/24/2014 00:00	9.4	13.5	7.5	105.0	3,307,686.6	1,884.0	0.9	0.6
07/24/2014 01:00	9.6	13.5	7.7	107.0	3,359,002.4	1,888.7	0.9	0.6
07/24/2014 02:00	9.7	13.7	7.9	94.7	2,829,002.5	1,487.4	1.0	0.6
07/24/2014 03:00	10.4	13.8	8.6	85.1	2,460,073.1	1,257.5	1.0	0.5
07/24/2014 04:00	10.5	13.8	8.7	85.3	2,451,856.5	1,253.3	1.0	0.5
07/24/2014 05:00	10.6	13.8	8.8	85.2	2,460,464.4	1,257.7	1.0	0.5
07/24/2014 06:00	10.7	13.8	8.9	85.0	2,465,550.8	1,260.3	1.0	0.5
07/24/2014 07:00	11.0	13.9	9.3	86.2	2,474,941.1	1,265.1	1.0	0.5
07/24/2014 08:00	10.4	13.8	8.6	97.8	3,026,813.6	1,569.3	0.9	0.5
07/24/2014 09:00	10.4	13.4	8.2	109.3	3,350,349.4	1,908.3	0.9	0.6
07/24/2014 10:00	10.4	13.4	8.2	110.5	3,319,827.1	1,939.4	1.0	0.8
07/24/2014 11:00	10.4	13.3	8.1	113.0	3,333,449.5	1,971.7	1.0	0.8
07/24/2014 12:00	10.7	13.2	8.2	132.2	3,300,779.6	2,121.1	1.2	1.1
07/24/2014 13:00	11.2	13.0	8.4	156.8	3,258,374.1	2,284.2	1.4	1.1
07/24/2014 14:00	11.1	13.0	8.3	147.8	3,259,230.0	2,237.2	1.3	1.1
07/24/2014 15:00	10.8	13.2	8.3	129.1	3,266,615.7	2,123.0	1.2	1.1
07/24/2014 16:00	10.7	13.2	8.2	129.3	3,238,840.8	2,128.6	1.2	1.1
07/24/2014 17:00	10.7	13.2	8.2	131.6	3,270,924.0	2,125.8	1.2	1.1
07/24/2014 18:00	10.7	13.2	8.2	129.1	3,257,229.8	2,116.9	1.2	1.1
07/24/2014 19:00	10.6	13.2	8.1	127.2	3,251,604.8	2,089.5	1.1	0.8
07/24/2014 20:00	10.5	13.2	8.0	122.7	3,271,172.7	2,054.3	1.1	0.8
07/24/2014 21:00	9.9	13.6	8.0	105.6	3,155,622.3	1,751.3	1.0	0.7
07/24/2014 22:00	10.0	13.5	8.0	109.1	3,326,487.8	1,919.0	0.9	0.6
07/24/2014 23:00	10.6	13.2	8.1	125.7	3,297,287.3	2,070.7	1.1	0.8
Average/Sum#:	10.5	13.4	8.3	112.9	3,083,049.4	1,831.8	1.1	0.8
Minimum:	9.4	13.0	7.5	85.0	2,451,856.5	1,253.3	0.9	0.5
Maximum:	11.2	13.9	9.3	156.8	3,359,002.4	2,284.2	1.4	1.1
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/25/2014 00:00	10.1	13.5	8.1	124.9	3,321,807.5	1,916.3	1.1	0.8
07/25/2014 01:00	10.1	13.7	8.3	126.9	3,374,910.4	1,873.0	1.1	0.7
07/25/2014 02:00	10.1	13.7	8.3	107.9	3,372,027.4	1,871.4	0.9	0.6
07/25/2014 03:00	10.0	13.7	8.2	121.6	3,367,342.5	1,868.8	1.0	0.7
07/25/2014 04:00	10.1	13.5	8.1	112.6	3,358,250.0	1,912.8	1.0	0.8
07/25/2014 05:00	10.2	13.5	8.1	111.7	3,395,119.1	1,933.8	0.9	0.6
07/25/2014 06:00	10.1	13.5	8.1	115.3	3,349,022.7	1,932.0	1.0	0.8
07/25/2014 07:00	10.2	13.4	8.0	114.2	3,319,827.1	1,939.4	1.0	0.8
07/25/2014 08:00	9.9	13.5	7.9	110.2	3,332,968.3	1,898.4	1.0	0.8
07/25/2014 09:00	10.2	13.4	8.0	111.7	3,316,061.1	1,937.2	1.0	0.8
07/25/2014 10:00	10.5	13.2	8.0	128.7	3,291,655.5	2,091.2	1.1	0.8
07/25/2014 11:00	10.7	13.1	8.1	140.4	3,252,085.2	2,184.8	1.3	1.1
07/25/2014 12:00	10.6	13.1	8.0	134.5	3,266,533.6	2,146.8	1.2	1.1
07/25/2014 13:00	10.3	13.2	7.9	120.3	3,236,459.4	2,032.5	1.1	0.8
07/25/2014 14:00	10.4	13.2	8.0	126.3	3,246,780.7	2,086.4	1.1	0.8
07/25/2014 15:00	10.7	13.1	8.1	140.6	3,234,967.4	2,173.3	1.3	1.1
07/25/2014 16:00	10.6	13.1	8.0	134.1	3,238,462.9	2,152.0	1.2	1.1
07/25/2014 17:00	10.7	13.1	8.1	140.9	3,244,493.8	2,179.7	1.3	1.1
07/25/2014 18:00	10.6	13.1	8.0	137.5	3,232,883.5	2,171.9	1.3	1.1
07/25/2014 19:00	10.6	13.1	8.0	140.5	3,212,757.0	2,205.3	1.3	1.1
07/25/2014 20:00	10.4	13.1	7.9	132.4	3,231,841.5	2,124.0	1.2	1.1
07/25/2014 21:00	10.4	13.2	8.0	123.6	3,269,421.1	2,053.2	1.1	0.8
07/25/2014 22:00	10.4	13.3	8.1	123.4	3,284,846.3	2,038.9	1.1	0.8
07/25/2014 23:00	10.1	13.4	7.9	112.7	3,311,268.2	1,934.4	1.0	0.8
Average/Sum#:	10.3	13.3	8.1	124.7	3,294,241.3	2,027.4	1.1	0.9
Minimum:	9.9	13.1	7.9	107.9	3,212,757.0	1,868.8	0.9	0.6
Maximum:	10.7	13.7	8.3	140.9	3,395,119.1	2,205.3	1.3	1.1
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/26/2014 00:00	9.7	13.5	7.7	108.5	3,314,182.6	1,887.7	0.9	0.6
07/26/2014 01:00	9.6	13.6	7.8	108.7	3,320,765.2	1,867.2	0.9	0.6
07/26/2014 02:00	9.6	13.6	7.8	104.9	3,360,495.4	1,865.0	0.9	0.6
07/26/2014 03:00	9.7	13.6	7.8	109.7	3,355,089.7	1,862.0	0.9	0.6
07/26/2014 04:00	9.9	13.5	7.9	110.1	3,342,273.3	1,903.7	0.9	0.6
07/26/2014 05:00	9.7	13.6	7.8	106.9	3,352,927.5	1,860.8	0.9	0.6
07/26/2014 06:00	9.8	13.7	8.0	112.3	3,340,854.9	1,854.1	1.0	0.7
07/26/2014 07:00	9.7	13.6	7.8	107.1	3,329,657.6	1,872.2	0.9	0.6
07/26/2014 08:00	9.6	13.5	7.7	105.9	3,287,847.5	1,872.7	0.9	0.6
07/26/2014 09:00	9.2	13.5	7.3	103.7	3,267,481.7	1,861.1	0.9	0.6
07/26/2014 10:00	9.4	13.5	7.5	104.8	3,286,794.1	1,872.1	0.9	0.6
07/26/2014 11:00	10.1	13.3	7.8	117.9	3,261,512.4	2,000.6	1.1	0.8
07/26/2014 12:00	10.4	13.1	7.9	135.1	3,208,174.3	2,155.3	1.2	1.1
07/26/2014 13:00	10.4	13.1	7.9	133.6	3,209,365.1	2,156.1	1.2	1.1
07/26/2014 14:00	10.3	13.2	7.9	123.1	3,203,052.5	2,058.3	1.1	0.8
07/26/2014 15:00	9.6	13.6	7.8	103.5	3,059,659.3	1,675.7	1.0	0.7
07/26/2014 16:00	9.4	13.6	7.6	99.9	2,998,126.5	1,642.0	1.0	0.7
07/26/2014 17:00	9.9	13.3	7.7	111.2	3,234,151.4	1,960.2	1.0	0.8
07/26/2014 18:00	9.5	13.4	7.5	105.7	3,188,852.0	1,839.6	1.0	0.7
07/26/2014 19:00	9.9	13.9	8.3	84.9	2,476,114.9	1,265.7	1.0	0.5
07/26/2014 20:00	10.4	13.9	8.8	85.1	2,486,993.8	1,253.1	1.0	0.5
07/26/2014 21:00	10.5	13.9	8.9	85.2	2,485,406.0	1,252.3	1.0	0.5
07/26/2014 22:00	10.5	13.9	8.9	85.2	2,446,378.8	1,250.5	1.0	0.5
07/26/2014 23:00	9.8	13.9	8.3	89.9	2,758,412.0	1,410.0	0.9	0.4
Average/Sum#:	9.9	13.6	7.9	106.0	3,107,273.7	1,770.8	1.0	0.7
Minimum:	9.2	13.1	7.3	84.9	2,446,378.8	1,250.5	0.9	0.4
Maximum:	10.5	13.9	8.9	135.1	3,360,495.4	2,156.1	1.2	1.1
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/27/2014 00:00	9.1	13.8	7.6	93.2	2,899,707.9	1,503.4	0.9	0.5
07/27/2014 01:00	9.6	13.9	8.1	86.5	2,652,379.4	1,355.8	0.9	0.4
07/27/2014 02:00	9.8	13.8	8.1	90.2	2,665,748.5	1,382.1	1.0	0.6
07/27/2014 03:00	9.7	13.8	8.1	84.6	2,499,395.1	1,277.6	1.0	0.5
07/27/2014 04:00	9.8	13.8	8.1	86.5	2,610,122.9	1,334.2	0.9	0.4
07/27/2014 05:00	9.8	13.9	8.3	82.6	2,518,958.3	1,287.6	0.9	0.4
07/27/2014 06:00	9.6	13.8	8.0	92.0	2,836,559.0	1,532.8	0.9	0.5
07/27/2014 07:00	9.6	13.4	7.6	111.7	3,319,034.0	1,914.7	1.0	0.8
07/27/2014 08:00	9.6	13.5	7.7	108.2	3,210,939.8	1,782.0	1.0	0.7
07/27/2014 09:00	9.5	13.4	7.5	107.0	3,277,604.6	1,890.8	0.9	0.6
07/27/2014 10:00	9.8	13.4	7.7	110.4	3,280,113.8	1,916.2	1.0	0.8
07/27/2014 11:00	10.1	13.2	7.7	123.9	3,260,174.5	2,071.2	1.1	0.8
07/27/2014 12:00	10.0	13.3	7.8	128.3	3,246,019.1	2,014.8	1.2	1.0
07/27/2014 13:00	10.0	13.3	7.8	117.2	3,246,187.9	1,991.2	1.1	0.8
07/27/2014 14:00	9.8	13.3	7.6	111.5	3,270,219.2	1,934.3	1.0	0.8
07/27/2014 15:00	10.4	13.2	8.0	133.0	3,259,691.6	2,118.5	1.2	1.1
07/27/2014 16:00	10.3	13.1	7.8	133.2	3,231,089.1	2,147.1	1.2	1.1
07/27/2014 17:00	10.2	13.1	7.7	132.1	3,199,243.3	2,149.3	1.2	1.1
07/27/2014 18:00	10.2	13.1	7.7	132.0	3,197,605.9	2,148.2	1.2	1.1
07/27/2014 19:00	10.0	13.1	7.6	127.5	3,182,390.1	2,091.5	1.2	1.0
07/27/2014 20:00	9.2	13.4	7.2	104.0	3,205,839.8	1,849.4	0.9	0.6
07/27/2014 21:00	9.0	13.6	7.3	101.8	3,046,789.1	1,690.9	1.0	0.7
07/27/2014 22:00	9.1	13.6	7.4	98.3	3,053,999.0	1,672.6	0.9	0.5
07/27/2014 23:00	9.1	13.4	7.2	103.5	3,241,895.5	1,870.2	0.9	0.6
Average/Sum#:	9.7	13.5	7.7	108.3	3,058,821.1	1,788.6	1.0	0.7
Minimum:	9.0	13.1	7.2	82.6	2,499,395.1	1,277.6	0.9	0.4
Maximum:	10.4	13.9	8.3	133.2	3,319,034.0	2,149.3	1.2	1.1
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/28/2014 00:00	9.3	13.5	7.4	105.8	3,290,305.4	1,874.1	0.9	0.6
07/28/2014 01:00	9.8	13.4	7.7	112.7	3,272,586.1	1,935.7	1.0	0.8
07/28/2014 02:00	9.3	13.5	7.4	108.3	3,135,092.6	1,762.8	1.0	0.7
07/28/2014 03:00	9.5	13.8	7.9	84.4	2,476,150.7	1,283.8	1.0	0.5
07/28/2014 04:00	9.5	13.6	7.7	97.3	2,972,946.3	1,606.5	0.9	0.5
07/28/2014 05:00	9.2	13.6	7.4	102.9	3,301,735.5	1,856.5	0.9	0.6
07/28/2014 06:00	9.6	13.6	7.8	106.4	3,297,645.1	1,854.2	0.9	0.6
07/28/2014 07:00	9.9	13.6	8.0	105.3	3,294,266.0	1,852.3	0.9	0.6
07/28/2014 08:00	9.7	13.6	7.8	104.3	3,293,021.0	1,851.6	0.9	0.6
07/28/2014 09:00	9.8	13.5	7.8	105.4	3,285,740.7	1,871.5	0.9	0.6
07/28/2014 10:00	10.9	13.1	8.2	128.5	3,254,614.0	2,115.2	1.2	1.1
07/28/2014 11:00	11.0	13.0	8.2	143.4	3,200,272.7	2,220.1	1.3	1.1
07/28/2014 12:00	10.8	13.1	8.2	130.2	3,192,693.9	2,144.9	1.2	1.1
07/28/2014 13:00	10.7	13.0	8.0	131.4	3,158,854.1	2,168.3	1.2	1.1
07/28/2014 14:00	10.7	13.1	8.1	128.5	3,197,754.8	2,148.3	1.2	1.1
07/28/2014 15:00	10.6	13.1	8.0	127.6	3,197,159.4	2,147.9	1.2	1.1
07/28/2014 16:00	10.4	13.0	7.8	126.2	3,171,408.3	2,130.6	1.2	1.1
07/28/2014 17:00	10.6	13.1	8.0	126.6	3,175,873.8	2,133.6	1.2	1.1
07/28/2014 18:00	10.4	13.2	8.0	115.3	3,228,091.9	1,980.1	1.0	0.8
07/28/2014 19:00	10.4	13.2	8.0	116.4	3,226,363.8	2,002.6	1.0	0.8
07/28/2014 20:00	10.5	13.2	8.0	114.5	3,257,910.1	1,974.6	1.0	0.8
07/28/2014 21:00	10.3	13.3	8.0	109.4	3,270,014.3	1,910.3	1.0	0.8
07/28/2014 22:00	10.2	13.3	7.9	111.5	3,286,449.5	1,943.9	1.0	0.8
07/28/2014 23:00	9.7	13.5	7.7	105.1	3,310,805.8	1,861.6	0.9	0.6
Average/Sum#:	10.1	13.3	7.9	114.5	3,197,823.2	1,943.0	1.0	0.8
Minimum:	9.2	13.0	7.4	84.4	2,476,150.7	1,283.8	0.9	0.5
Maximum:	11.0	13.8	8.2	143.4	3,310,805.8	2,220.1	1.3	1.1
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/29/2014 00:00	10.4	13.3	8.1	112.3	3,304,708.4	1,954.7	1.0	0.8
07/29/2014 01:00	9.9	13.8	8.2	93.0	2,794,783.0	1,449.0	0.9	0.4
07/29/2014 02:00	10.4	13.8	8.6	84.3	2,460,268.7	1,257.6	1.0	0.5
07/29/2014 03:00	10.6	13.8	8.8	84.7	2,418,207.8	1,236.1	1.0	0.5
07/29/2014 04:00	10.6	13.8	8.8	89.4	2,649,546.9	1,373.7	1.0	0.5
07/29/2014 05:00	10.0	13.6	8.1	104.6	3,348,783.2	1,858.5	0.9	0.6
07/29/2014 06:00	10.4	13.4	8.2	113.7	3,323,079.4	1,941.3	1.0	0.8
07/29/2014 07:00	10.9	13.2	8.4	127.5	3,281,483.2	2,108.7	1.1	0.8
07/29/2014 08:00	10.8	13.2	8.3	123.4	3,281,523.0	2,060.8	1.1	0.8
07/29/2014 09:00	10.6	13.2	8.1	116.8	3,291,238.3	1,994.8	1.0	0.8
07/29/2014 10:00	11.0	13.1	8.3	142.0	3,237,795.6	2,175.2	1.3	1.1
07/29/2014 11:00	10.6	13.2	8.1	120.7	3,256,330.1	2,021.2	1.1	0.8
07/29/2014 12:00	10.8	13.1	8.2	133.5	3,250,100.5	2,136.0	1.2	1.1
07/29/2014 13:00	11.0	13.0	8.2	144.8	3,229,364.9	2,216.7	1.3	1.1
07/29/2014 14:00	10.9	13.0	8.1	144.0	3,222,663.5	2,212.1	1.3	1.1
07/29/2014 15:00	10.7	13.0	8.0	135.5	3,173,713.9	2,178.5	1.3	1.1
07/29/2014 16:00	10.4	13.1	7.9	125.5	3,194,605.5	2,076.2	1.2	1.0
07/29/2014 17:00	10.2	13.2	7.8	117.1	3,193,784.3	2,005.7	1.1	0.8
07/29/2014 18:00	10.1	13.2	7.7	116.4	3,181,363.9	1,997.9	1.1	0.8
07/29/2014 19:00	10.0	13.3	7.8	110.4	3,165,020.2	1,918.3	1.0	0.8
07/29/2014 20:00	9.8	13.4	7.7	104.8	3,249,222.7	1,850.7	0.9	0.6
07/29/2014 21:00	10.1	13.3	7.8	109.2	3,219,499.8	1,904.3	1.0	0.8
07/29/2014 22:00	9.5	13.4	7.5	102.1	3,266,166.1	1,836.5	0.9	0.6
07/29/2014 23:00	9.5	13.4	7.5	102.6	3,272,924.3	1,840.3	0.9	0.6
Average/Sum#:	10.4	13.3	8.1	114.9	3,136,090.7	1,900.2	1.1	0.8
Minimum:	9.5	13.0	7.5	84.3	2,418,207.8	1,236.1	0.9	0.4
Maximum:	11.0	13.8	8.8	144.8	3,348,783.2	2,216.7	1.3	1.1
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/30/2014 00:00	10.1	13.4	7.9	106.0	3,250,693.4	1,827.8	0.9	0.5
07/30/2014 01:00	10.1	13.4	7.9	107.9	3,279,069.1	1,867.7	0.9	0.6
07/30/2014 02:00	9.7	13.8	8.1	91.4	2,671,708.9	1,404.7	1.0	0.6
07/30/2014 03:00	10.1	13.7	8.3	95.4	2,888,359.9	1,539.7	0.9	0.5
07/30/2014 04:00	9.5	13.6	7.7	104.2	3,317,386.1	1,865.3	0.9	0.6
07/30/2014 05:00	9.5	13.5	7.6	104.2	3,320,765.2	1,867.2	0.9	0.6
07/30/2014 06:00	9.5	13.5	7.6	104.5	3,301,379.8	1,856.3	0.9	0.6
07/30/2014 07:00	9.2	13.5	7.3	103.4	3,252,909.6	1,852.8	0.9	0.6
07/30/2014 08:00	9.3	13.5	7.4	103.5	3,300,134.9	1,855.6	0.9	0.6
07/30/2014 09:00	9.1	13.5	7.3	103.1	3,261,688.0	1,857.8	0.9	0.6
07/30/2014 10:00	9.2	13.5	7.3	103.5	3,269,412.9	1,862.2	0.9	0.6
07/30/2014 11:00	10.3	13.2	7.9	117.8	3,257,273.7	1,998.0	1.1	0.8
07/30/2014 12:00	10.8	13.0	8.1	141.6	3,197,897.3	2,195.1	1.3	1.1
07/30/2014 13:00	10.8	13.0	8.1	143.7	3,217,273.2	2,208.4	1.3	1.1
07/30/2014 14:00	10.6	13.0	7.9	136.4	3,189,739.0	2,189.5	1.3	1.1
07/30/2014 15:00	10.3	13.0	7.7	130.2	3,160,748.0	2,169.6	1.2	1.1
07/30/2014 16:00	10.4	13.0	7.8	131.4	3,162,496.2	2,170.8	1.2	1.1
07/30/2014 17:00	10.3	13.0	7.7	129.6	3,152,589.8	2,164.0	1.2	1.1
07/30/2014 18:00	10.3	13.0	7.7	129.6	3,183,543.6	2,162.0	1.2	1.1
07/30/2014 19:00	10.3	13.1	7.8	126.4	3,186,695.7	2,117.6	1.2	1.1
07/30/2014 20:00	10.0	13.2	7.7	117.0	3,192,828.9	2,005.1	1.1	0.8
07/30/2014 21:00	10.4	13.1	7.9	132.2	3,225,972.6	2,143.7	1.2	1.1
07/30/2014 22:00	10.3	13.1	7.8	127.5	3,227,071.6	2,097.3	1.2	1.0
07/30/2014 23:00	10.3	13.2	7.9	124.0	3,225,387.9	2,049.1	1.1	0.8
Average/Sum#:	10.0	13.3	7.8	117.3	3,195,542.7	1,972.0	1.1	0.8
Minimum:	9.1	13.0	7.3	91.4	2,671,708.9	1,404.7	0.9	0.5
Maximum:	10.8	13.8	8.3	143.7	3,320,765.2	2,208.4	1.3	1.1
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
07/31/2014 00:00	9.6	13.5	7.7	103.2	3,099,829.0	1,697.7	1.0	0.7
07/31/2014 01:00	9.4	13.6	7.6	103.3	3,245,726.0	1,706.5	0.9	0.5
07/31/2014 02:00	9.5	13.5	7.6	104.9	3,176,343.8	1,762.8	1.0	0.7
07/31/2014 03:00	9.8	13.4	7.7	107.7	3,282,284.9	1,893.5	0.9	0.6
07/31/2014 04:00	9.5	13.5	7.6	108.1	3,277,137.9	1,866.6	1.0	0.7
07/31/2014 05:00	9.4	13.5	7.5	103.7	3,312,584.2	1,862.6	0.9	0.6
07/31/2014 06:00	9.4	13.5	7.5	110.5	3,266,955.0	1,860.8	1.0	0.7
07/31/2014 07:00	9.3	13.5	7.4	104.0	3,267,306.1	1,861.0	0.9	0.6
07/31/2014 08:00	9.1	13.4	7.2	103.4	3,233,401.6	1,865.3	0.9	0.6
07/31/2014 09:00	9.6	13.3	7.5	109.3	3,239,189.7	1,939.6	1.0	0.8
07/31/2014 10:00	10.7	13.0	8.0	135.9	3,171,382.9	2,176.9	1.3	1.1
07/31/2014 11:00	10.9	13.0	8.1	143.0	3,178,650.2	2,205.1	1.3	1.1
07/31/2014 12:00	10.8	13.0	8.1	133.9	3,173,422.5	2,178.3	1.2	1.1
07/31/2014 13:00	10.2	13.3	7.9	111.4	3,188,420.8	1,909.2	1.0	0.8
07/31/2014 14:00	10.1	13.3	7.8	108.7	3,204,453.1	1,942.2	1.0	0.8
07/31/2014 15:00	10.4	13.2	8.0	119.4	3,191,860.7	2,027.8	1.1	0.8
07/31/2014 16:00	10.3	13.2	7.9	120.0	3,171,306.8	2,037.9	1.1	0.8
07/31/2014 17:00	10.1	13.1	7.6	118.5	3,127,673.0	2,032.7	1.1	0.8
07/31/2014 18:00	10.2	13.2	7.8	118.9	3,157,145.7	2,028.8	1.1	0.8
07/31/2014 19:00	10.2	13.2	7.8	118.3	3,140,650.3	2,018.2	1.1	0.8
07/31/2014 20:00	10.2	13.2	7.8	117.5	3,183,911.7	1,999.5	1.1	0.8
07/31/2014 21:00	10.3	13.2	7.9	116.2	3,193,981.0	1,982.5	1.1	0.8
07/31/2014 22:00	9.8	13.3	7.6	109.3	3,193,931.9	1,912.5	1.0	0.8
07/31/2014 23:00	10.0	13.3	7.8	109.0	3,227,614.9	1,909.1	1.0	0.8
Average/Sum#:	10.0	13.3	7.7	114.1	3,204,381.8	1,944.9	1.0	0.8
Minimum:	9.1	13.0	7.2	103.2	3,099,829.0	1,697.7	0.9	0.5
Maximum:	10.9	13.6	8.1	143.0	3,312,584.2	2,205.1	1.3	1.1
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/01/2014 00:00	10.1	13.3	7.8	109.4	3,230,150.9	1,910.6	1.0	0.8
08/01/2014 01:00	9.6	13.7	7.9	98.5	2,974,464.8	1,585.6	1.0	0.6
08/01/2014 02:00	9.7	13.7	7.9	97.3	2,988,721.8	1,593.2	0.9	0.5
08/01/2014 03:00	9.9	13.4	7.8	107.8	3,270,356.6	1,910.5	0.9	0.6
08/01/2014 04:00	9.8	13.5	7.8	108.8	3,290,656.6	1,874.3	1.0	0.7
08/01/2014 05:00	10.1	13.4	7.9	112.0	3,327,007.9	1,919.3	1.0	0.8
08/01/2014 06:00	9.5	13.5	7.6	106.5	3,297,289.4	1,854.0	0.9	0.6
08/01/2014 07:00	9.6	13.4	7.6	102.9	3,293,198.9	1,851.7	0.9	0.6
08/01/2014 08:00	10.1	13.3	7.8	109.1	3,242,154.5	1,917.7	1.0	0.8
08/01/2014 09:00	10.4	13.2	8.0	120.9	3,244,102.7	2,037.3	1.1	0.8
08/01/2014 10:00	10.6	13.1	8.0	132.3	3,213,783.2	2,135.6	1.2	1.1
08/01/2014 11:00	10.6	13.0	7.9	137.8	3,160,487.3	2,192.5	1.3	1.1
08/01/2014 12:00	10.5	13.0	7.8	134.2	3,150,258.8	2,162.4	1.3	1.1
08/01/2014 13:00	10.4	13.0	7.8	131.0	3,142,100.5	2,156.8	1.2	1.1
08/01/2014 14:00	10.4	13.0	7.8	129.9	3,144,722.8	2,158.6	1.2	1.1
08/01/2014 15:00	10.2	13.1	7.7	127.2	3,143,049.8	2,134.5	1.2	1.1
08/01/2014 16:00	10.3	13.2	7.9	123.0	3,163,826.8	2,079.3	1.1	0.8
08/01/2014 17:00	10.3	13.2	7.9	120.0	3,184,845.4	2,046.6	1.1	0.8
08/01/2014 18:00	10.2	13.2	7.8	119.3	3,167,260.7	2,035.3	1.1	0.8
08/01/2014 19:00	10.6	13.2	8.1	125.0	3,226,268.3	2,026.1	1.1	0.8
08/01/2014 20:00	10.6	13.3	8.2	119.4	3,276,765.3	1,962.1	1.1	0.8
08/01/2014 21:00	10.5	13.3	8.2	115.7	3,263,625.7	1,930.4	1.0	0.8
08/01/2014 22:00	10.4	13.4	8.2	114.1	3,281,996.7	1,917.3	1.0	0.8
08/01/2014 23:00	10.5	13.3	8.2	117.2	3,264,407.1	1,954.7	1.0	0.8
Average/Sum#:	10.2	13.3	7.9	117.5	3,205,895.9	1,972.8	1.1	0.8
Minimum:	9.5	13.0	7.6	97.3	2,974,464.8	1,585.6	0.9	0.5
Maximum:	10.6	13.7	8.2	137.8	3,327,007.9	2,192.5	1.3	1.1
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/02/2014 00:00	10.1	13.4	7.9	114.0	3,295,979.1	1,901.4	1.0	0.8
08/02/2014 01:00	9.8	13.5	7.8	111.8	3,296,274.7	1,877.5	1.0	0.8
08/02/2014 02:00	9.8	13.5	7.8	110.3	3,298,178.6	1,854.5	1.0	0.7
08/02/2014 03:00	9.6	13.8	8.0	85.4	2,558,280.4	1,307.7	1.0	0.5
08/02/2014 04:00	9.9	13.8	8.2	91.8	2,888,898.6	1,476.7	0.9	0.4
08/02/2014 05:00	10.2	13.8	8.5	85.1	2,481,201.4	1,268.3	1.0	0.5
08/02/2014 06:00	10.3	13.8	8.6	81.8	2,398,807.2	1,243.7	1.0	0.5
08/02/2014 07:00	10.2	13.6	8.2	97.8	2,851,404.2	1,520.0	1.0	0.6
08/02/2014 08:00	10.2	13.4	8.0	109.4	3,290,656.6	1,874.3	1.0	0.7
08/02/2014 09:00	10.1	13.4	7.9	111.1	3,264,387.6	1,835.5	1.0	0.7
08/02/2014 10:00	10.2	13.4	8.0	110.0	3,279,682.5	1,844.1	1.0	0.7
08/02/2014 11:00	10.1	13.4	7.9	110.1	3,272,924.3	1,888.1	1.0	0.8
08/02/2014 12:00	10.2	13.3	7.9	114.7	3,262,442.3	1,929.7	1.0	0.8
08/02/2014 13:00	10.2	13.3	7.9	113.9	3,228,501.5	1,933.2	1.0	0.8
08/02/2014 14:00	9.9	13.3	7.7	109.9	3,196,168.9	1,890.5	1.0	0.8
08/02/2014 15:00	9.9	13.3	7.7	112.4	3,194,098.9	1,912.6	1.0	0.8
08/02/2014 16:00	9.9	13.3	7.7	110.8	3,169,805.0	1,921.2	1.0	0.8
08/02/2014 17:00	9.8	13.3	7.6	112.2	3,172,010.7	1,945.7	1.0	0.8
08/02/2014 18:00	9.8	13.3	7.6	111.2	3,191,913.8	1,934.6	1.0	0.8
08/02/2014 19:00	10.0	13.2	7.7	123.2	3,200,153.7	2,009.7	1.1	0.8
08/02/2014 20:00	10.1	13.2	7.7	118.6	3,191,395.8	2,004.2	1.1	0.8
08/02/2014 21:00	9.8	13.3	7.6	111.4	3,222,823.4	1,929.8	1.0	0.8
08/02/2014 22:00	9.4	13.7	7.7	96.7	2,894,550.4	1,543.0	1.0	0.6
08/02/2014 23:00	9.7	13.8	8.1	83.8	2,505,068.5	1,280.5	1.0	0.5
Average/Sum#:	10.0	13.5	7.9	105.7	3,066,900.3	1,755.3	1.0	0.7
Minimum:	9.4	13.2	7.6	81.8	2,398,807.2	1,243.7	0.9	0.4
Maximum:	10.3	13.8	8.6	123.2	3,298,178.6	2,009.7	1.1	0.8
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/03/2014 00:00	9.8	13.8	8.1	99.8	3,075,418.6	1,594.5	0.9	0.5
08/03/2014 01:00	9.7	13.8	8.1	93.3	2,876,755.6	1,491.5	0.9	0.4
08/03/2014 02:00	9.9	13.8	8.2	90.0	2,727,276.2	1,414.0	0.9	0.4
08/03/2014 03:00	9.8	13.8	8.1	99.5	3,082,555.0	1,598.2	0.9	0.5
08/03/2014 04:00	9.8	13.6	7.9	106.9	3,326,940.5	1,749.2	0.9	0.5
08/03/2014 05:00	9.7	13.5	7.7	102.7	3,361,297.8	1,840.9	0.9	0.6
08/03/2014 06:00	9.8	13.5	7.8	111.7	3,335,449.3	1,851.1	1.0	0.7
08/03/2014 07:00	10.3	13.3	8.0	116.2	3,298,809.7	1,975.3	1.0	0.8
08/03/2014 08:00	10.0	13.4	7.9	111.8	3,289,870.9	1,921.9	1.0	0.8
08/03/2014 09:00	9.8	13.4	7.7	111.9	3,267,960.1	1,909.1	1.0	0.8
08/03/2014 10:00	10.0	13.3	7.8	112.5	3,250,438.7	1,922.6	1.0	0.8
08/03/2014 11:00	10.1	13.3	7.8	112.4	3,267,852.3	1,932.9	1.0	0.8
08/03/2014 12:00	9.8	13.3	7.6	109.7	3,258,553.8	1,927.4	1.0	0.8
08/03/2014 13:00	10.2	13.1	7.7	127.7	3,203,844.4	2,105.6	1.2	1.1
08/03/2014 14:00	10.0	13.2	7.7	128.4	3,203,338.4	2,011.7	1.2	1.0
08/03/2014 15:00	10.2	13.1	7.7	130.1	3,181,232.4	2,137.2	1.2	1.1
08/03/2014 16:00	9.9	13.2	7.6	116.6	3,202,842.0	1,988.0	1.1	0.8
08/03/2014 17:00	9.9	13.2	7.6	112.9	3,214,397.7	1,971.7	1.0	0.8
08/03/2014 18:00	9.3	13.3	7.2	108.3	3,242,625.8	1,894.3	1.0	0.8
08/03/2014 19:00	10.0	13.3	7.8	115.7	3,255,600.2	1,973.2	1.0	0.8
08/03/2014 20:00	10.1	13.2	7.7	116.0	3,237,873.5	1,986.1	1.0	0.8
08/03/2014 21:00	9.6	13.4	7.6	112.9	3,231,841.5	1,888.0	1.0	0.8
08/03/2014 22:00	10.2	13.4	8.0	112.1	3,212,669.6	1,876.8	1.0	0.8
08/03/2014 23:00	10.2	13.3	7.9	116.9	3,264,574.1	1,954.8	1.0	0.8
Average/Sum#:	9.9	13.4	7.8	111.5	3,202,917.4	1,871.5	1.0	0.8
Minimum:	9.3	13.1	7.2	90.0	2,727,276.2	1,414.0	0.9	0.4
Maximum:	10.3	13.8	8.2	130.1	3,361,297.8	2,137.2	1.2	1.1
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/04/2014 00:00	9.7	13.4	7.6	113.4	3,280,724.8	1,892.6	1.0	0.8
08/04/2014 01:00	9.9	13.4	7.8	114.8	3,293,123.3	1,923.8	1.0	0.8
08/04/2014 02:00	9.7	13.5	7.7	113.2	3,310,495.7	1,885.6	1.0	0.8
08/04/2014 03:00	9.9	13.4	7.8	114.8	3,317,601.7	1,938.1	1.0	0.8
08/04/2014 04:00	9.6	13.6	7.8	110.1	3,310,627.9	1,861.5	1.0	0.7
08/04/2014 05:00	9.8	13.5	7.8	111.7	3,171,864.2	1,829.8	1.0	0.7
08/04/2014 06:00	9.6	13.7	7.9	106.0	3,226,706.2	1,696.5	0.9	0.5
08/04/2014 07:00	9.6	13.7	7.9	102.3	3,196,084.4	1,680.4	0.9	0.5
08/04/2014 08:00	9.7	13.6	7.8	106.5	3,308,379.2	1,763.6	0.9	0.5
08/04/2014 09:00	9.6	13.6	7.8	106.3	3,296,185.7	1,757.1	0.9	0.5
08/04/2014 10:00	9.7	13.5	7.7	106.4	3,206,409.4	1,802.9	1.0	0.7
08/04/2014 11:00	9.8	13.3	7.6	112.1	3,255,510.6	1,925.6	1.0	0.8
08/04/2014 12:00	9.0	13.5	7.2	105.3	3,263,970.3	1,859.1	0.9	0.6
08/04/2014 13:00	8.8	13.5	7.0	102.6	3,270,466.3	1,862.8	0.9	0.6
08/04/2014 14:00	8.8	13.4	6.9	102.2	3,273,451.0	1,864.5	0.9	0.6
08/04/2014 15:00	8.8	13.4	6.9	102.2	3,230,974.8	1,863.9	0.9	0.6
08/04/2014 16:00	8.9	13.4	7.0	102.5	3,231,841.5	1,864.4	0.9	0.6
08/04/2014 17:00	8.7	13.5	6.9	101.8	3,271,168.6	1,863.2	0.9	0.6
08/04/2014 18:00	8.8	13.5	7.0	101.9	3,266,603.9	1,860.6	0.9	0.6
08/04/2014 19:00	8.8	13.5	7.0	101.9	3,264,672.6	1,859.5	0.9	0.6
08/04/2014 20:00	8.9	13.5	7.1	102.3	3,264,145.9	1,859.2	0.9	0.6
08/04/2014 21:00	9.3	13.6	7.5	98.8	2,863,898.8	1,589.4	1.0	0.6
08/04/2014 22:00	9.5	13.8	7.9	83.2	2,477,308.0	1,284.4	1.0	0.5
08/04/2014 23:00	9.2	13.7	7.5	98.3	3,060,473.3	1,609.1	0.9	0.5
Average/Sum#:	9.3	13.5	7.5	105.0	3,204,695.3	1,799.9	0.9	0.6
Minimum:	8.7	13.3	6.9	83.2	2,477,308.0	1,284.4	0.9	0.5
Maximum:	9.9	13.8	7.9	114.8	3,317,601.7	1,938.1	1.0	0.8
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/05/2014 00:00	9.3	13.5	7.4	103.8	3,224,355.4	1,765.9	0.9	0.5
08/05/2014 01:00	9.5	13.3	7.4	107.7	3,287,474.4	1,920.5	1.0	0.8
08/05/2014 02:00	9.9	13.2	7.6	110.8	3,265,743.1	1,955.5	1.0	0.8
08/05/2014 03:00	9.6	13.4	7.6	111.6	3,258,215.6	1,927.2	1.0	0.8
08/05/2014 04:00	9.7	13.3	7.5	113.3	3,270,895.5	1,934.7	1.0	0.8
08/05/2014 05:00	8.9	13.5	7.1	102.2	3,307,248.8	1,859.6	0.9	0.6
08/05/2014 06:00	9.2	13.4	7.2	105.9	3,286,618.5	1,896.0	0.9	0.6
08/05/2014 07:00	9.2	13.7	7.5	85.8	2,505,660.9	1,299.1	1.0	0.5
08/05/2014 08:00	9.5	13.7	7.8	83.1	2,420,409.4	1,254.9	1.0	0.5
08/05/2014 09:00	9.6	13.5	7.7	96.0	2,834,167.9	1,572.9	1.0	0.6
08/05/2014 10:00	8.9	13.5	7.1	102.6	3,276,786.8	1,866.4	0.9	0.6
08/05/2014 11:00	9.0	13.5	7.2	102.9	3,290,129.9	1,874.0	0.9	0.6
08/05/2014 12:00	9.2	13.4	7.2	105.7	3,272,410.7	1,911.7	0.9	0.6
08/05/2014 13:00	9.7	13.3	7.5	111.1	3,249,710.9	1,945.9	1.0	0.8
08/05/2014 14:00	9.8	13.3	7.6	110.2	3,264,908.1	1,955.0	1.0	0.8
08/05/2014 15:00	9.8	13.2	7.5	113.9	3,246,350.9	1,991.3	1.0	0.8
08/05/2014 16:00	9.7	13.2	7.4	109.7	3,245,368.8	1,943.3	1.0	0.8
08/05/2014 17:00	9.7	13.2	7.4	110.0	3,265,576.1	1,955.4	1.0	0.8
08/05/2014 18:00	9.7	13.2	7.4	110.8	3,247,020.7	1,968.0	1.0	0.8
08/05/2014 19:00	9.8	13.2	7.5	113.2	3,266,159.7	1,979.6	1.0	0.8
08/05/2014 20:00	9.3	13.3	7.2	106.4	3,234,546.6	1,913.2	1.0	0.8
08/05/2014 21:00	9.4	13.3	7.3	107.2	3,259,061.0	1,927.7	1.0	0.8
08/05/2014 22:00	9.2	13.6	7.4	93.9	2,695,575.0	1,476.3	1.0	0.6
08/05/2014 23:00	9.2	13.6	7.4	91.5	2,831,377.4	1,530.0	0.9	0.5
Average/Sum#:	9.5	13.4	7.4	104.6	3,137,740.5	1,817.7	1.0	0.7
Minimum:	8.9	13.2	7.1	83.1	2,420,409.4	1,254.9	0.9	0.5
Maximum:	9.9	13.7	7.8	113.9	3,307,248.8	1,991.3	1.0	0.8
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/06/2014 00:00	9.6	13.2	7.4	109.7	3,276,765.3	1,962.1	1.0	0.8
08/06/2014 01:00	9.8	13.2	7.5	112.4	3,273,584.2	1,984.1	1.0	0.8
08/06/2014 02:00	9.4	13.4	7.4	107.5	3,246,381.1	1,920.2	1.0	0.8
08/06/2014 03:00	8.8	13.5	7.0	101.4	3,275,031.1	1,865.4	0.9	0.6
08/06/2014 04:00	9.8	13.2	7.5	112.8	3,246,187.9	1,991.2	1.0	0.8
08/06/2014 05:00	9.9	13.2	7.6	117.5	3,269,541.0	2,029.4	1.1	0.8
08/06/2014 06:00	9.6	13.3	7.5	115.4	3,270,419.2	1,958.3	1.0	0.8
08/06/2014 07:00	9.3	13.3	7.2	108.0	3,268,359.5	1,933.2	1.0	0.8
08/06/2014 08:00	9.7	13.2	7.4	112.5	3,236,895.4	1,985.5	1.0	0.8
08/06/2014 09:00	9.8	13.2	7.5	117.6	3,243,784.2	2,037.1	1.1	0.8
08/06/2014 10:00	9.7	13.1	7.3	117.9	3,196,672.2	2,054.2	1.1	0.8
08/06/2014 11:00	9.8	13.1	7.4	121.7	3,190,758.8	2,073.7	1.1	0.8
08/06/2014 12:00	10.4	13.1	7.9	118.9	3,203,666.0	2,035.3	1.1	0.8
08/06/2014 13:00	0.0	0.0	0.0	118.4	3,184,305.2	2,023.0	1.2	1.0
08/06/2014 14:00	10.8	13.1	8.2	123.2	3,174,021.4	2,086.0	1.1	0.8
08/06/2014 15:00	10.5	13.1	7.9	117.5	3,159,277.8	2,007.1	1.1	0.8
08/06/2014 16:00	10.1	13.3	7.8	106.9	3,213,525.5	1,877.3	1.0	0.8
08/06/2014 17:00	10.4	13.2	8.0	112.9	3,195,812.6	1,960.3	1.0	0.8
08/06/2014 18:00	10.4	13.2	8.0	114.4	3,183,186.7	1,975.8	1.0	0.8
08/06/2014 19:00	10.5	13.2	8.0	117.5	3,174,860.9	2,017.0	1.1	0.8
08/06/2014 20:00	10.5	13.2	8.0	117.9	3,172,499.8	2,015.5	1.1	0.8
08/06/2014 21:00	10.2	13.3	7.9	111.8	3,192,573.7	1,935.0	1.0	0.8
08/06/2014 22:00	9.7	13.6	7.8	94.6	2,666,725.8	1,460.5	1.0	0.6
08/06/2014 23:00	9.9	13.6	8.0	99.9	3,156,333.0	1,659.5	0.9	0.5
Average/Sum#:	9.9	13.3	7.7	112.8	3,194,632.0	1,951.9	1.0	0.8
Minimum:	8.8	13.1	7.0	94.6	2,666,725.8	1,460.5	0.9	0.5
Maximum:	10.8	13.6	8.2	123.2	3,276,765.3	2,086.0	1.1	0.8
%SI	4.2	4.2	4.2	0.0	0.0	0.0	4.2	4.2

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/07/2014 00:00	14.0	14.4	12.7	118.9	2,361,219.6	1,138.0	1.4	0.6
08/07/2014 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/07/2014 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/07/2014 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/07/2014 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/07/2014 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/07/2014 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/07/2014 07:00	41.1	16.9	60.6	87.3	1,866,118.3	504.2	0.9	0.2
08/07/2014 08:00	43.3	14.5	39.9	210.3	2,199,991.1	1,012.1	2.6	1.0
08/07/2014 09:00	9.6	13.8	8.0	84.9	2,622,056.4	1,340.3	0.9	0.4
08/07/2014 10:00	9.6	13.7	7.9	93.3	2,936,933.1	1,522.7	0.9	0.5
08/07/2014 11:00	9.7	13.6	7.8	103.0	3,229,778.0	1,721.7	0.9	0.5
08/07/2014 12:00	9.6	13.6	7.8	104.2	3,216,459.0	1,714.6	0.9	0.5
08/07/2014 13:00	9.6	13.6	7.8	103.7	3,211,018.8	1,711.7	0.9	0.5
08/07/2014 14:00	9.6	13.6	7.8	103.3	3,203,139.9	1,707.5	0.9	0.5
08/07/2014 15:00	9.6	13.4	7.6	104.1	2,984,825.1	1,721.9	1.0	0.7
08/07/2014 16:00	10.1	13.2	7.7	117.8	3,168,505.7	2,036.1	1.1	0.8
08/07/2014 17:00	10.2	13.0	7.6	125.1	3,134,803.8	2,128.9	1.2	1.1
08/07/2014 18:00	10.0	13.1	7.6	119.0	3,131,569.2	2,058.1	1.1	0.8
08/07/2014 19:00	10.1	13.2	7.7	115.1	3,189,962.6	2,003.3	1.1	0.8
08/07/2014 20:00	9.6	13.3	7.5	105.1	3,199,660.1	1,869.2	1.0	0.7
08/07/2014 21:00	9.6	13.3	7.5	106.9	3,212,061.0	1,899.9	1.0	0.8
08/07/2014 22:00	9.6	13.4	7.6	104.5	3,235,352.9	1,842.8	0.9	0.6
08/07/2014 23:00	9.7	13.4	7.6	103.8	3,253,716.8	1,829.5	0.9	0.5
Average/Sum#:	13.6	13.7	12.7	111.7	2,964,287.3	1,653.5	1.1	0.6
Minimum:	9.6	13.0	7.5	84.9	1,866,118.3	504.2	0.9	0.2
Maximum:	43.3	16.9	60.6	210.3	3,253,716.8	2,128.9	2.6	1.1
%SI	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/08/2014 00:00	10.3	13.3	8.0	111.4	3,288,816.4	1,945.3	1.0	0.8
08/08/2014 01:00	10.2	13.3	7.9	118.6	3,305,105.8	1,930.8	1.0	0.8
08/08/2014 02:00	9.7	13.5	7.7	105.2	3,323,737.1	1,844.6	0.9	0.6
08/08/2014 03:00	10.0	13.4	7.9	108.7	3,292,685.6	1,899.5	0.9	0.6
08/08/2014 04:00	10.1	13.4	7.9	111.8	3,311,097.0	1,934.3	1.0	0.8
08/08/2014 05:00	10.5	13.3	8.2	117.9	3,322,357.2	1,989.4	1.0	0.8
08/08/2014 06:00	10.5	13.3	8.2	117.2	3,283,318.7	1,990.0	1.0	0.8
08/08/2014 07:00	10.2	13.4	8.0	112.9	3,293,888.3	1,948.3	1.0	0.8
08/08/2014 08:00	9.9	13.4	7.8	109.8	3,294,419.0	1,900.5	1.0	0.8
08/08/2014 09:00	10.7	13.0	8.0	137.9	3,231,990.4	2,171.3	1.3	1.1
08/08/2014 10:00	10.4	13.1	7.9	126.5	3,176,756.8	2,064.6	1.2	1.0
08/08/2014 11:00	9.6	13.3	7.5	104.1	3,234,615.1	1,866.0	0.9	0.6
08/08/2014 12:00	9.9	13.3	7.7	107.6	3,213,244.4	1,900.6	1.0	0.8
08/08/2014 13:00	10.1	13.2	7.7	124.5	3,186,981.1	2,024.7	1.2	1.0
08/08/2014 14:00	10.5	13.0	7.8	135.0	3,163,664.8	2,148.5	1.3	1.1
08/08/2014 15:00	10.4	13.0	7.8	133.7	3,138,895.5	2,154.6	1.3	1.1
08/08/2014 16:00	10.4	13.1	7.9	132.9	3,156,744.1	2,143.8	1.2	1.1
08/08/2014 17:00	10.2	13.1	7.7	127.4	3,170,294.4	2,060.4	1.2	1.0
08/08/2014 18:00	10.4	13.0	7.8	135.7	3,140,738.8	2,178.8	1.3	1.1
08/08/2014 19:00	10.3	13.1	7.8	128.6	3,165,477.1	2,103.5	1.2	1.1
08/08/2014 20:00	10.1	13.2	7.7	120.6	3,192,988.1	2,005.2	1.1	0.8
08/08/2014 21:00	10.2	13.2	7.8	115.6	3,204,775.3	1,989.2	1.1	0.8
08/08/2014 22:00	9.8	13.3	7.6	107.8	3,206,989.0	1,896.9	1.0	0.8
08/08/2014 23:00	10.2	13.2	7.8	115.3	3,225,483.5	1,978.5	1.0	0.8
Average/Sum#:	10.2	13.2	7.8	119.4	3,230,211.0	2,002.9	1.1	0.9
Minimum:	9.6	13.0	7.5	104.1	3,138,895.5	1,844.6	0.9	0.6
Maximum:	10.7	13.5	8.2	137.9	3,323,737.1	2,178.8	1.3	1.1
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/09/2014 00:00	9.6	13.6	7.8	104.5	3,173,312.7	1,691.6	0.9	0.5
08/09/2014 01:00	9.6	13.7	7.9	96.7	2,931,329.0	1,541.2	0.9	0.5
08/09/2014 02:00	27.0	16.0	32.5	195.8	1,619,344.3	614.9	3.5	0.8
08/09/2014 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/09/2014 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/09/2014 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/09/2014 06:00	47.2	16.4	61.9	164.4	1,705,661.8	585.4	2.3	0.5
08/09/2014 07:00	19.2	13.8	16.0	151.6	2,703,243.7	1,381.8	1.6	0.8
08/09/2014 08:00	9.8	13.9	8.3	120.5	2,634,968.1	1,346.9	1.3	0.7
08/09/2014 09:00	9.4	13.7	7.7	103.7	3,134,053.1	1,624.9	0.9	0.5
08/09/2014 10:00	9.3	13.6	7.5	104.7	3,312,675.6	1,741.7	0.9	0.5
08/09/2014 11:00	9.2	13.8	7.6	97.2	3,054,990.2	1,561.6	0.9	0.5
08/09/2014 12:00	9.6	13.8	8.0	91.6	2,794,006.1	1,469.0	0.9	0.4
08/09/2014 13:00	9.9	13.4	7.8	106.1	3,256,803.2	1,878.8	0.9	0.6
08/09/2014 14:00	10.0	13.4	7.9	109.2	3,261,797.7	1,905.5	1.0	0.8
08/09/2014 15:00	10.0	13.3	7.8	117.2	3,231,346.6	1,958.5	1.1	0.8
08/09/2014 16:00	9.8	13.3	7.6	110.8	3,199,008.4	1,938.9	1.0	0.8
08/09/2014 17:00	9.8	13.3	7.6	109.5	3,219,650.3	1,927.9	1.0	0.8
08/09/2014 18:00	10.1	13.2	7.7	122.9	3,195,271.7	2,053.3	1.1	0.8
08/09/2014 19:00	10.6	13.0	7.9	147.6	3,196,380.7	2,217.4	1.4	1.1
08/09/2014 20:00	10.5	13.1	7.9	140.0	3,219,953.1	2,139.7	1.3	1.1
08/09/2014 21:00	10.5	13.1	7.9	134.4	3,212,213.1	2,111.1	1.2	1.1
08/09/2014 22:00	10.3	13.2	7.9	122.3	3,283,684.0	2,014.2	1.1	0.8
08/09/2014 23:00	9.7	13.5	7.7	104.4	3,039,221.2	1,686.7	1.0	0.7
Average/Sum#:	12.9	13.7	11.9	121.7	2,970,424.5	1,685.3	1.2	0.7
Minimum:	9.2	13.0	7.5	91.6	1,619,344.3	585.4	0.9	0.4
Maximum:	47.2	16.4	61.9	195.8	3,312,675.6	2,217.4	3.5	1.1
%SI	12.5	12.5	12.5	12.5	12.5	12.5	12.5	12.5

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/10/2014 00:00	27.6	15.9	32.6	206.3	1,568,378.5	607.0	3.8	0.9
08/10/2014 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2014 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2014 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2014 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2014 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2014 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/10/2014 07:00	43.4	16.7	61.0	101.2	1,874,742.0	547.6	1.2	0.3
08/10/2014 08:00	25.9	14.1	22.5	160.6	2,505,433.4	1,225.8	1.8	0.9
08/10/2014 09:00	10.0	13.8	8.3	87.7	2,594,769.9	1,345.3	1.0	0.5
08/10/2014 10:00	9.8	13.7	8.0	106.8	3,280,639.3	1,700.9	0.9	0.5
08/10/2014 11:00	9.1	13.8	7.6	97.7	3,148,893.6	1,609.6	0.9	0.5
08/10/2014 12:00	9.3	13.7	7.6	95.5	3,061,531.4	1,587.3	0.9	0.5
08/10/2014 13:00	9.9	13.3	7.7	113.5	3,225,571.9	1,955.0	1.0	0.8
08/10/2014 14:00	9.9	13.3	7.7	113.0	3,229,531.7	1,957.4	1.0	0.8
08/10/2014 15:00	9.7	13.3	7.5	111.9	3,242,492.6	1,917.9	1.0	0.8
08/10/2014 16:00	10.0	13.2	7.7	120.3	3,221,172.8	2,022.9	1.1	0.8
08/10/2014 17:00	10.3	13.0	7.7	143.6	3,179,226.8	2,205.5	1.4	1.1
08/10/2014 18:00	10.4	13.0	7.8	148.6	3,193,526.8	2,192.1	1.4	1.1
08/10/2014 19:00	10.5	13.0	7.8	150.0	3,197,314.6	2,194.7	1.4	1.1
08/10/2014 20:00	10.5	13.1	7.9	147.1	3,204,894.8	2,176.5	1.4	1.1
08/10/2014 21:00	10.4	13.1	7.9	136.0	3,227,429.0	2,121.1	1.2	1.1
08/10/2014 22:00	9.8	13.3	7.6	117.7	3,271,909.9	1,935.3	1.1	0.8
08/10/2014 23:00	10.1	13.3	7.8	128.0	3,282,658.7	1,989.6	1.1	0.8
Average/Sum#:	13.7	13.7	12.9	127.0	2,972,784.3	1,738.4	1.3	0.8
Minimum:	9.1	13.0	7.5	87.7	1,568,378.5	547.6	0.9	0.3
Maximum:	43.4	16.7	61.0	206.3	3,282,658.7	2,205.5	3.8	1.1
%SI	25.0	25.0	25.0	25.0	25.0	25.0	25.0	25.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/11/2014 00:00	10.2	13.3	7.9	122.1	3,277,214.0	1,986.3	1.1	0.8
08/11/2014 01:00	10.1	13.3	7.8	120.3	3,286,123.5	1,991.7	1.1	0.8
08/11/2014 02:00	10.0	13.4	7.9	122.0	3,292,366.7	1,947.4	1.1	0.8
08/11/2014 03:00	10.2	13.3	7.9	122.8	3,288,763.4	1,993.3	1.1	0.8
08/11/2014 04:00	10.2	13.3	7.9	121.7	3,310,707.2	2,006.6	1.1	0.8
08/11/2014 05:00	9.9	13.4	7.8	121.1	3,348,585.0	1,956.2	1.1	0.8
08/11/2014 06:00	10.6	13.1	8.0	157.3	3,287,371.0	2,184.5	1.4	1.1
08/11/2014 07:00	10.2	13.3	7.9	121.4	3,275,043.6	2,008.9	1.1	0.8
08/11/2014 08:00	10.1	13.3	7.8	119.8	3,247,166.1	1,991.8	1.1	0.8
08/11/2014 09:00	10.6	13.0	7.9	152.3	3,232,861.3	2,219.1	1.4	1.1
08/11/2014 10:00	10.5	12.9	7.7	157.4	3,187,794.1	2,258.0	1.5	1.4
08/11/2014 11:00	10.6	12.9	7.8	160.6	3,200,500.1	2,267.0	1.5	1.4
08/11/2014 12:00	10.6	12.9	7.8	160.5	3,183,558.7	2,255.0	1.5	1.4
08/11/2014 13:00	10.5	13.0	7.8	155.7	3,185,195.5	2,232.9	1.5	1.3
08/11/2014 14:00	10.5	13.0	7.8	154.2	3,199,263.7	2,219.4	1.5	1.3
08/11/2014 15:00	10.4	13.0	7.8	153.3	3,194,362.6	2,216.0	1.4	1.1
08/11/2014 16:00	10.3	13.0	7.7	152.0	3,160,945.3	2,215.9	1.4	1.1
08/11/2014 17:00	10.2	13.0	7.6	147.7	3,158,235.0	2,214.0	1.4	1.1
08/11/2014 18:00	10.3	13.0	7.7	151.7	3,159,376.2	2,214.8	1.4	1.1
08/11/2014 19:00	10.6	13.0	7.9	159.4	3,194,895.6	2,239.7	1.5	1.3
08/11/2014 20:00	10.5	13.0	7.8	158.8	3,182,398.1	2,207.7	1.5	1.3
08/11/2014 21:00	10.0	13.3	7.8	126.8	3,161,740.1	1,939.4	1.2	1.0
08/11/2014 22:00	9.5	13.7	7.8	105.4	3,254,408.1	1,687.3	0.9	0.5
08/11/2014 23:00	9.5	13.7	7.8	106.8	3,235,699.1	1,677.6	1.0	0.7
Average/Sum#:	10.3	13.2	7.8	138.8	3,229,357.3	2,088.8	1.3	1.0
Minimum:	9.5	12.9	7.6	105.4	3,158,235.0	1,677.6	0.9	0.5
Maximum:	10.6	13.7	8.0	160.6	3,348,585.0	2,267.0	1.5	1.4
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/12/2014 00:00	9.2	13.8	7.6	100.4	3,149,676.1	1,633.0	0.9	0.5
08/12/2014 01:00	9.3	13.7	7.6	101.9	3,197,895.3	1,658.0	0.9	0.5
08/12/2014 02:00	9.3	13.8	7.7	95.5	2,963,935.8	1,536.7	0.9	0.5
08/12/2014 03:00	9.5	13.8	7.9	94.4	2,949,855.8	1,529.4	0.9	0.5
08/12/2014 04:00	9.6	13.7	7.9	103.6	3,262,316.1	1,691.4	0.9	0.5
08/12/2014 05:00	8.9	13.7	7.3	105.0	3,348,242.6	1,760.4	0.9	0.5
08/12/2014 06:00	8.9	13.6	7.2	105.1	3,348,242.6	1,760.4	0.9	0.5
08/12/2014 07:00	9.0	13.7	7.4	103.5	3,274,636.1	1,721.7	0.9	0.5
08/12/2014 08:00	9.4	13.8	7.8	85.3	2,528,613.2	1,311.0	1.0	0.5
08/12/2014 09:00	9.8	13.7	8.0	100.7	3,159,705.7	1,638.2	0.9	0.5
08/12/2014 10:00	9.8	13.6	7.9	108.6	3,322,756.1	1,747.0	0.9	0.5
08/12/2014 11:00	9.6	13.7	7.9	101.0	3,169,542.4	1,643.3	0.9	0.5
08/12/2014 12:00	9.6	13.6	7.8	105.7	3,258,854.8	1,737.2	0.9	0.5
08/12/2014 13:00	9.6	13.6	7.8	103.2	3,295,177.4	1,732.5	0.9	0.5
08/12/2014 14:00	9.9	13.6	8.0	106.1	3,247,974.5	1,731.4	0.9	0.5
08/12/2014 15:00	9.9	13.6	8.0	106.0	3,246,473.8	1,730.6	0.9	0.5
08/12/2014 16:00	9.9	13.6	8.0	106.1	3,292,514.7	1,731.1	0.9	0.5
08/12/2014 17:00	9.9	13.6	8.0	106.2	3,298,981.4	1,734.5	0.9	0.5
08/12/2014 18:00	9.9	13.6	8.0	106.4	3,262,419.1	1,739.1	0.9	0.5
08/12/2014 19:00	9.9	13.6	8.0	107.7	3,327,130.7	1,749.3	0.9	0.5
08/12/2014 20:00	9.9	13.6	8.0	106.6	3,333,787.6	1,752.8	0.9	0.5
08/12/2014 21:00	9.9	13.6	8.0	106.8	3,341,585.7	1,756.9	0.9	0.5
08/12/2014 22:00	9.9	13.6	8.0	107.8	3,360,605.5	1,766.9	0.9	0.5
08/12/2014 23:00	9.9	13.6	8.0	107.9	3,363,458.4	1,768.4	0.9	0.5
Average/Sum#:	9.6	13.7	7.8	103.4	3,221,015.9	1,690.1	0.9	0.5
Minimum:	8.9	13.6	7.2	85.3	2,528,613.2	1,311.0	0.9	0.5
Maximum:	9.9	13.8	8.0	108.6	3,363,458.4	1,768.4	1.0	0.5
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/13/2014 00:00	9.9	13.6	8.0	108.0	3,368,023.2	1,770.8	0.9	0.5
08/13/2014 01:00	15.7	14.4	14.3	137.3	2,874,737.8	1,364.5	1.3	0.7
08/13/2014 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/13/2014 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/13/2014 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/13/2014 05:00	44.1	16.6	60.5	164.5	1,997,252.8	568.8	1.8	0.4
08/13/2014 06:00	14.8	13.6	12.0	138.9	3,283,195.0	1,726.2	1.2	0.9
08/13/2014 07:00	10.0	13.6	8.1	106.5	3,399,405.8	1,787.3	0.9	0.5
08/13/2014 08:00	10.0	13.6	8.1	104.8	3,381,146.8	1,777.7	0.9	0.5
08/13/2014 09:00	10.0	13.6	8.1	106.8	3,323,761.8	1,771.8	0.9	0.5
08/13/2014 10:00	9.9	13.6	8.0	107.8	3,308,379.2	1,763.6	0.9	0.5
08/13/2014 11:00	9.9	13.6	8.0	107.1	3,294,309.8	1,756.1	0.9	0.5
08/13/2014 12:00	9.9	13.6	8.0	106.8	3,281,741.1	1,749.4	0.9	0.5
08/13/2014 13:00	9.9	13.6	8.0	106.6	3,266,921.3	1,741.5	0.9	0.5
08/13/2014 14:00	9.8	13.6	7.9	106.0	3,250,788.4	1,732.9	0.9	0.5
08/13/2014 15:00	9.8	13.6	7.9	105.8	3,247,974.5	1,731.4	0.9	0.5
08/13/2014 16:00	9.8	13.6	7.9	105.5	3,244,222.6	1,729.4	0.9	0.5
08/13/2014 17:00	9.8	13.6	7.9	105.6	3,244,035.1	1,729.3	0.9	0.5
08/13/2014 18:00	9.8	13.6	7.9	105.8	3,248,912.5	1,731.9	0.9	0.5
08/13/2014 19:00	9.9	13.6	8.0	106.3	3,262,794.3	1,739.3	0.9	0.5
08/13/2014 20:00	9.9	13.6	8.0	107.0	3,280,240.4	1,748.6	0.9	0.5
08/13/2014 21:00	9.5	13.7	7.8	105.4	3,297,079.4	1,733.5	0.9	0.5
08/13/2014 22:00	9.4	13.8	7.8	101.6	3,187,094.2	1,652.4	0.9	0.5
08/13/2014 23:00	18.2	15.0	18.2	145.2	2,157,629.1	961.1	1.9	0.7
Average/Sum#:	12.4	13.9	11.4	113.8	3,152,364.1	1,631.8	1.0	0.5
Minimum:	9.4	13.6	7.8	101.6	1,997,252.8	568.8	0.9	0.4
Maximum:	44.1	16.6	60.5	164.5	3,399,405.8	1,787.3	1.9	0.9
%SI	12.5	12.5	12.5	12.5	12.5	12.5	12.5	12.5

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/14/2014 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2014 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2014 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2014 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2014 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2014 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2014 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2014 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2014 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2014 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2014 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2014 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2014 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2014 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2014 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2014 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2014 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2014 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2014 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2014 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2014 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2014 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2014 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/14/2014 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/15/2014 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2014 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2014 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2014 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2014 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2014 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2014 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2014 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2014 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2014 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2014 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2014 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2014 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2014 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2014 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2014 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2014 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2014 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2014 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2014 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2014 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2014 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2014 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/15/2014 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/16/2014 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/16/2014 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/16/2014 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/16/2014 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/16/2014 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/16/2014 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/16/2014 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/16/2014 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/16/2014 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/16/2014 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/16/2014 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/16/2014 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/16/2014 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/16/2014 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/16/2014 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/16/2014 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/16/2014 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/16/2014 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/16/2014 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/16/2014 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/16/2014 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/16/2014 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/16/2014 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/16/2014 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/17/2014 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2014 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2014 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2014 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2014 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2014 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2014 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2014 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2014 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2014 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2014 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2014 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2014 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2014 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2014 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2014 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2014 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2014 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2014 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2014 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2014 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2014 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2014 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/17/2014 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/18/2014 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2014 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2014 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2014 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2014 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2014 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2014 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2014 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2014 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2014 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2014 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2014 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2014 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2014 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2014 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2014 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2014 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2014 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2014 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2014 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2014 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2014 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2014 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/18/2014 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/19/2014 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/19/2014 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/19/2014 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/19/2014 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/19/2014 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/19/2014 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/19/2014 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/19/2014 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/19/2014 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/19/2014 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/19/2014 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/19/2014 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/19/2014 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/19/2014 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/19/2014 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/19/2014 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/19/2014 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/19/2014 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/19/2014 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/19/2014 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/19/2014 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/19/2014 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/19/2014 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/19/2014 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/20/2014 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2014 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2014 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2014 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2014 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2014 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2014 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2014 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2014 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2014 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2014 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2014 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2014 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2014 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2014 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2014 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2014 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2014 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2014 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2014 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2014 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2014 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2014 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/20/2014 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/21/2014 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2014 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2014 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2014 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2014 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2014 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2014 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2014 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2014 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2014 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2014 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2014 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2014 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2014 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2014 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2014 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2014 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2014 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2014 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2014 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2014 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2014 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2014 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/21/2014 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/22/2014 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2014 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2014 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2014 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2014 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2014 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2014 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2014 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2014 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2014 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2014 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2014 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2014 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2014 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2014 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2014 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2014 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2014 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2014 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2014 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2014 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2014 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2014 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/22/2014 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/23/2014 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2014 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2014 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2014 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2014 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2014 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2014 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2014 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2014 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2014 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2014 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2014 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2014 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2014 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2014 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2014 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2014 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2014 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2014 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2014 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2014 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2014 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2014 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/23/2014 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/24/2014 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2014 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2014 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2014 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2014 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2014 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2014 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2014 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2014 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2014 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2014 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2014 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2014 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2014 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2014 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2014 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2014 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2014 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2014 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2014 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2014 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2014 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2014 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/24/2014 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/25/2014 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2014 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2014 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2014 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2014 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2014 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2014 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2014 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2014 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2014 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2014 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2014 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2014 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2014 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2014 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2014 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2014 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2014 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2014 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2014 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2014 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2014 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2014 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/25/2014 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/26/2014 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/26/2014 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/26/2014 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/26/2014 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/26/2014 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/26/2014 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/26/2014 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/26/2014 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/26/2014 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/26/2014 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/26/2014 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/26/2014 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/26/2014 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/26/2014 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/26/2014 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/26/2014 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/26/2014 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/26/2014 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/26/2014 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/26/2014 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/26/2014 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/26/2014 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/26/2014 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/26/2014 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/27/2014 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/27/2014 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/27/2014 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/27/2014 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/27/2014 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/27/2014 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/27/2014 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/27/2014 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/27/2014 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/27/2014 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/27/2014 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/27/2014 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/27/2014 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/27/2014 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/27/2014 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/27/2014 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/27/2014 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/27/2014 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/27/2014 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/27/2014 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/27/2014 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/27/2014 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/27/2014 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/27/2014 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/28/2014 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/28/2014 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/28/2014 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/28/2014 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/28/2014 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/28/2014 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/28/2014 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/28/2014 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/28/2014 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/28/2014 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/28/2014 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/28/2014 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/28/2014 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/28/2014 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/28/2014 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/28/2014 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/28/2014 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/28/2014 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/28/2014 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/28/2014 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/28/2014 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/28/2014 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/28/2014 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/28/2014 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/29/2014 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/29/2014 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/29/2014 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/29/2014 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/29/2014 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/29/2014 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/29/2014 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/29/2014 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/29/2014 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/29/2014 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/29/2014 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/29/2014 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/29/2014 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/29/2014 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/29/2014 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/29/2014 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/29/2014 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/29/2014 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/29/2014 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/29/2014 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/29/2014 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/29/2014 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/29/2014 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/29/2014 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/30/2014 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/30/2014 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/30/2014 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/30/2014 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/30/2014 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/30/2014 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/30/2014 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/30/2014 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/30/2014 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/30/2014 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/30/2014 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/30/2014 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/30/2014 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/30/2014 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/30/2014 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/30/2014 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/30/2014 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/30/2014 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/30/2014 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/30/2014 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/30/2014 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/30/2014 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/30/2014 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/30/2014 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
08/31/2014 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/31/2014 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/31/2014 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/31/2014 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/31/2014 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/31/2014 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/31/2014 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/31/2014 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/31/2014 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/31/2014 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/31/2014 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/31/2014 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/31/2014 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/31/2014 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/31/2014 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/31/2014 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/31/2014 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/31/2014 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/31/2014 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/31/2014 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/31/2014 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/31/2014 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/31/2014 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
08/31/2014 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/01/2014 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/01/2014 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/01/2014 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/01/2014 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/01/2014 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/01/2014 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/01/2014 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/01/2014 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/01/2014 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/01/2014 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/01/2014 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/01/2014 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/01/2014 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/01/2014 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/01/2014 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/01/2014 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/01/2014 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/01/2014 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/01/2014 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/01/2014 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/01/2014 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/01/2014 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/01/2014 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/01/2014 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/02/2014 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2014 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2014 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2014 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2014 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2014 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2014 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2014 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2014 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2014 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2014 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2014 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2014 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2014 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2014 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2014 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2014 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2014 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2014 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2014 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2014 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2014 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2014 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/02/2014 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/03/2014 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/03/2014 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/03/2014 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/03/2014 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/03/2014 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/03/2014 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/03/2014 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/03/2014 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/03/2014 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/03/2014 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/03/2014 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/03/2014 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/03/2014 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/03/2014 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/03/2014 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/03/2014 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/03/2014 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/03/2014 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/03/2014 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/03/2014 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/03/2014 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/03/2014 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/03/2014 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/03/2014 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/04/2014 00:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/04/2014 01:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/04/2014 02:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/04/2014 03:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/04/2014 04:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/04/2014 05:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/04/2014 06:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/04/2014 07:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/04/2014 08:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/04/2014 09:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/04/2014 10:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/04/2014 11:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/04/2014 12:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/04/2014 13:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/04/2014 14:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/04/2014 15:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/04/2014 16:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/04/2014 17:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/04/2014 18:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/04/2014 19:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/04/2014 20:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/04/2014 21:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/04/2014 22:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
09/04/2014 23:00	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Average/Sum#:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Minimum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Maximum:	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
%SI	100.0	100.0	100.0	100.0	100.0	100.0	100.0	100.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/05/2014 00:00	11.9	17.6	21.3	0.1	1,863,833.8	394.7	0.4	0.1
09/05/2014 01:00	38.2	16.8	55.0	0.1	1,881,246.7	549.5	0.3	0.1
09/05/2014 02:00	28.4	17.7	52.4	259.5	2,597,198.9	606.9	2.6	0.6
09/05/2014 03:00	29.1	17.7	53.7	260.9	2,609,609.3	609.8	2.5	0.6
09/05/2014 04:00	33.0	15.4	35.4	223.7	2,398,521.4	945.8	2.6	0.9
09/05/2014 05:00	7.2	13.8	6.0	84.2	2,814,949.6	1,438.9	0.9	0.4
09/05/2014 06:00	7.4	13.9	6.2	101.6	3,391,281.7	1,733.5	0.9	0.5
09/05/2014 07:00	7.3	13.8	6.1	99.6	3,380,913.2	1,728.2	0.9	0.5
09/05/2014 08:00	7.1	13.8	5.9	93.0	3,191,337.4	1,654.6	0.9	0.5
09/05/2014 09:00	7.3	13.9	6.2	83.2	2,778,366.4	1,420.2	0.9	0.4
09/05/2014 10:00	7.7	13.9	6.5	79.1	2,480,223.2	1,267.8	0.9	0.4
09/05/2014 11:00	7.6	13.9	6.4	83.2	2,715,231.2	1,368.1	0.9	0.4
09/05/2014 12:00	7.5	13.7	6.1	99.6	3,182,960.7	1,673.5	0.9	0.5
09/05/2014 13:00	7.7	13.4	6.1	110.1	3,284,420.7	1,942.7	1.0	0.8
09/05/2014 14:00	7.6	13.3	5.9	107.9	3,256,017.8	1,925.9	1.0	0.8
09/05/2014 15:00	7.7	13.3	6.0	112.6	3,239,431.1	1,963.4	1.0	0.8
09/05/2014 16:00	7.7	13.3	6.0	114.0	3,252,135.4	1,971.1	1.1	0.8
09/05/2014 17:00	7.8	13.1	5.9	145.8	3,251,638.7	2,184.5	1.4	1.1
09/05/2014 18:00	7.7	13.2	5.9	127.4	3,254,035.7	2,067.3	1.2	1.0
09/05/2014 19:00	7.7	13.3	6.0	116.1	3,257,415.1	1,974.3	1.1	0.8
09/05/2014 20:00	7.0	13.5	5.6	98.9	3,278,893.6	1,867.6	0.9	0.6
09/05/2014 21:00	7.6	13.4	6.0	114.0	3,283,068.2	1,941.9	1.0	0.8
09/05/2014 22:00	7.5	13.4	5.9	111.2	3,296,086.1	1,949.6	1.0	0.8
09/05/2014 23:00	7.6	13.1	5.7	147.1	3,278,431.7	2,202.5	1.4	1.1
Average/Sum#:	11.8	14.3	13.8	115.5	2,967,385.3	1,557.6	1.2	0.6
Minimum:	7.0	13.1	5.6	0.1	1,863,833.8	394.7	0.3	0.1
Maximum:	38.2	17.7	55.0	260.9	3,391,281.7	2,202.5	2.6	1.1
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/06/2014 00:00	7.5	13.2	5.7	129.8	3,265,054.0	2,074.3	1.2	1.0
09/06/2014 01:00	7.4	13.4	5.8	108.5	3,338,999.0	1,950.6	1.0	0.8
09/06/2014 02:00	7.6	13.3	5.9	115.2	3,335,049.4	1,997.0	1.0	0.8
09/06/2014 03:00	7.3	13.3	5.7	113.1	3,336,385.4	1,997.8	1.0	0.8
09/06/2014 04:00	7.5	13.3	5.8	113.2	3,322,357.2	1,989.4	1.0	0.8
09/06/2014 05:00	6.9	13.6	5.6	104.7	3,351,305.8	1,859.9	0.9	0.6
09/06/2014 06:00	7.3	13.6	5.9	111.9	3,329,835.4	1,872.3	1.0	0.7
09/06/2014 07:00	7.2	13.5	5.7	107.7	3,337,533.0	1,901.0	1.0	0.8
09/06/2014 08:00	7.0	13.6	5.7	102.8	3,343,918.1	1,855.8	0.9	0.6
09/06/2014 09:00	7.3	13.4	5.7	109.5	3,338,275.3	1,925.8	1.0	0.8
09/06/2014 10:00	7.2	13.4	5.7	107.4	3,296,152.5	1,901.5	1.0	0.8
09/06/2014 11:00	7.3	13.4	5.7	107.7	3,294,150.4	1,924.4	1.0	0.8
09/06/2014 12:00	7.6	13.2	5.8	121.2	3,253,179.1	2,043.0	1.1	0.8
09/06/2014 13:00	7.5	13.1	5.7	147.8	3,226,742.6	2,214.9	1.4	1.1
09/06/2014 14:00	7.6	13.2	5.8	126.4	3,223,282.6	2,071.3	1.2	1.0
09/06/2014 15:00	7.7	13.2	5.9	121.0	3,242,313.6	2,012.5	1.1	0.8
09/06/2014 16:00	7.6	13.3	5.9	117.8	3,238,851.7	1,986.7	1.1	0.8
09/06/2014 17:00	7.6	13.0	5.7	158.5	3,206,450.1	2,247.8	1.5	1.3
09/06/2014 18:00	7.6	13.1	5.7	144.4	3,204,158.6	2,176.0	1.4	1.1
09/06/2014 19:00	7.3	13.4	5.7	104.9	3,280,378.1	1,892.4	1.0	0.8
09/06/2014 20:00	7.1	13.5	5.7	98.3	3,297,111.5	1,853.9	0.9	0.6
09/06/2014 21:00	7.0	13.6	5.7	99.6	3,298,356.4	1,854.6	0.9	0.6
09/06/2014 22:00	7.4	13.5	5.9	113.2	3,326,121.1	1,894.5	1.0	0.8
09/06/2014 23:00	7.6	13.3	5.9	116.1	3,318,850.1	1,987.3	1.1	0.8
Average/Sum#:	7.4	13.4	5.8	116.7	3,291,867.1	1,978.5	1.1	0.8
Minimum:	6.9	13.0	5.6	98.3	3,204,158.6	1,853.9	0.9	0.6
Maximum:	7.7	13.6	5.9	158.5	3,351,305.8	2,247.8	1.5	1.3
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/07/2014 00:00	7.4	13.5	5.9	110.3	3,324,541.0	1,893.6	1.0	0.8
09/07/2014 01:00	7.5	13.5	6.0	111.2	3,336,830.7	1,900.6	1.0	0.8
09/07/2014 02:00	7.3	13.6	5.9	108.1	3,338,872.9	1,853.0	1.0	0.7
09/07/2014 03:00	7.3	13.6	5.9	109.5	3,330,223.9	1,848.2	1.0	0.7
09/07/2014 04:00	7.1	13.6	5.7	109.6	3,326,800.3	1,846.3	1.0	0.7
09/07/2014 05:00	7.2	13.6	5.8	110.6	3,330,944.6	1,848.6	1.0	0.7
09/07/2014 06:00	7.3	13.6	5.9	115.0	3,346,620.9	1,857.3	1.0	0.7
09/07/2014 07:00	7.2	13.6	5.8	110.8	3,352,026.6	1,860.3	1.0	0.7
09/07/2014 08:00	7.4	13.4	5.8	111.9	3,343,302.3	1,928.7	1.0	0.8
09/07/2014 09:00	7.6	13.2	5.8	123.8	3,325,092.8	2,039.6	1.1	0.8
09/07/2014 10:00	7.6	13.1	5.7	137.8	3,287,234.0	2,136.4	1.3	1.1
09/07/2014 11:00	7.7	13.1	5.8	137.6	3,265,692.5	2,122.4	1.3	1.1
09/07/2014 12:00	7.7	13.3	6.0	117.3	3,254,280.3	1,972.4	1.1	0.8
09/07/2014 13:00	7.7	13.3	6.0	113.8	3,258,562.0	1,951.2	1.0	0.8
09/07/2014 14:00	7.7	13.3	6.0	114.2	3,250,378.9	1,946.3	1.1	0.8
09/07/2014 15:00	7.7	13.3	6.0	115.5	3,270,085.2	1,958.1	1.1	0.8
09/07/2014 16:00	7.7	13.2	5.9	127.9	3,232,471.2	2,053.6	1.2	1.0
09/07/2014 17:00	7.6	13.0	5.7	155.3	3,201,570.1	2,221.0	1.5	1.3
09/07/2014 18:00	7.5	13.0	5.6	151.2	3,205,173.8	2,223.5	1.5	1.3
09/07/2014 19:00	7.6	13.0	5.7	153.2	3,200,849.3	2,220.5	1.5	1.3
09/07/2014 20:00	7.6	13.2	5.8	134.1	3,210,300.0	2,086.4	1.3	1.0
09/07/2014 21:00	7.3	13.4	5.7	109.4	3,288,872.0	1,897.3	1.0	0.8
09/07/2014 22:00	7.1	13.6	5.7	102.2	3,294,443.8	1,852.4	0.9	0.6
09/07/2014 23:00	7.4	13.4	5.8	110.2	3,325,447.8	1,918.4	1.0	0.8
Average/Sum#:	7.5	13.4	5.8	120.9	3,287,525.7	1,976.5	1.1	0.9
Minimum:	7.1	13.0	5.6	102.2	3,200,849.3	1,846.3	0.9	0.6
Maximum:	7.7	13.6	6.0	155.3	3,352,026.6	2,223.5	1.5	1.3
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/08/2014 00:00	7.4	13.7	6.1	91.3	2,812,385.0	1,499.2	1.0	0.6
09/08/2014 01:00	7.7	13.8	6.4	78.1	2,458,116.8	1,256.5	0.9	0.4
09/08/2014 02:00	7.8	13.8	6.5	78.5	2,448,726.4	1,251.7	0.9	0.4
09/08/2014 03:00	7.6	13.8	6.3	95.0	3,038,557.1	1,553.2	0.9	0.5
09/08/2014 04:00	7.4	13.4	5.8	112.0	3,368,090.6	1,943.0	1.0	0.8
09/08/2014 05:00	7.0	13.6	5.7	111.2	3,377,142.8	1,898.9	1.0	0.8
09/08/2014 06:00	7.6	13.2	5.8	137.1	3,251,926.4	2,137.2	1.3	1.1
09/08/2014 07:00	7.4	13.1	5.6	164.7	3,322,223.6	2,304.7	1.5	1.4
09/08/2014 08:00	7.1	13.2	5.4	139.5	3,309,698.7	2,151.0	1.3	1.1
09/08/2014 09:00	7.1	13.6	5.7	105.9	3,352,747.3	1,860.7	0.9	0.6
09/08/2014 10:00	6.9	13.6	5.6	97.1	3,360,202.3	1,840.3	0.9	0.6
09/08/2014 11:00	7.1	13.5	5.7	97.0	3,355,454.9	1,837.7	0.9	0.6
09/08/2014 12:00	7.3	13.5	5.8	107.0	3,312,024.9	1,838.1	1.0	0.7
09/08/2014 13:00	7.5	13.4	5.9	103.1	3,314,547.6	1,839.5	0.9	0.6
09/08/2014 14:00	7.6	13.4	6.0	104.1	3,279,504.6	1,844.0	0.9	0.6
09/08/2014 15:00	7.5	13.4	5.9	104.2	3,291,420.4	1,850.7	0.9	0.6
09/08/2014 16:00	7.2	13.6	5.8	94.1	2,883,539.3	1,600.3	1.0	0.6
09/08/2014 17:00	7.6	13.9	6.4	77.4	2,484,135.8	1,269.8	0.9	0.4
09/08/2014 18:00	7.0	13.9	5.9	87.2	3,018,092.3	1,520.7	0.9	0.5
09/08/2014 19:00	6.7	13.9	5.6	84.8	3,048,060.8	1,535.8	0.8	0.5
09/08/2014 20:00	7.1	13.9	6.0	82.2	2,827,861.4	1,445.5	0.9	0.4
09/08/2014 21:00	7.4	13.8	6.1	83.7	2,667,051.8	1,363.3	0.9	0.4
09/08/2014 22:00	7.6	13.8	6.3	81.2	2,540,673.5	1,298.7	0.9	0.4
09/08/2014 23:00	7.9	13.8	6.6	78.4	2,455,377.9	1,255.1	0.9	0.4
Average/Sum#:	7.4	13.6	6.0	99.8	3,024,065.1	1,674.8	1.0	0.6
Minimum:	6.7	13.1	5.4	77.4	2,448,726.4	1,251.7	0.8	0.4
Maximum:	7.9	13.9	6.6	164.7	3,377,142.8	2,304.7	1.5	1.4
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/09/2014 00:00	7.9	13.8	6.6	78.5	2,455,964.8	1,255.4	0.9	0.4
09/09/2014 01:00	7.9	13.8	6.6	78.4	2,455,573.6	1,255.2	0.9	0.4
09/09/2014 02:00	7.9	13.8	6.6	78.2	2,456,160.4	1,255.5	0.9	0.4
09/09/2014 03:00	7.8	13.8	6.5	88.0	2,650,814.3	1,355.0	1.0	0.5
09/09/2014 04:00	7.7	13.8	6.4	79.1	2,480,614.5	1,268.0	0.9	0.4
09/09/2014 05:00	7.7	13.8	6.4	81.3	2,518,197.9	1,305.6	1.0	0.5
09/09/2014 06:00	7.6	13.8	6.3	115.5	2,466,920.2	1,261.0	1.4	0.6
09/09/2014 07:00	7.5	13.8	6.2	77.6	2,482,766.4	1,269.1	0.9	0.4
09/09/2014 08:00	7.5	13.7	6.1	94.0	2,970,319.5	1,561.7	0.9	0.5
09/09/2014 09:00	7.0	13.6	5.7	109.7	3,341,395.5	1,878.8	1.0	0.8
09/09/2014 10:00	6.7	13.6	5.4	102.3	3,318,986.7	1,866.2	0.9	0.6
09/09/2014 11:00	6.9	13.5	5.5	113.0	3,264,497.1	1,859.4	1.0	0.7
09/09/2014 12:00	7.2	13.4	5.7	115.6	3,259,737.2	1,928.1	1.1	0.8
09/09/2014 13:00	7.1	13.4	5.6	121.5	3,233,010.6	1,935.9	1.1	0.8
09/09/2014 14:00	7.2	13.5	5.7	124.0	3,217,640.1	1,903.2	1.2	1.0
09/09/2014 15:00	7.3	13.5	5.8	121.5	3,220,543.8	1,881.4	1.1	0.8
09/09/2014 16:00	7.3	13.5	5.8	120.2	3,216,093.2	1,878.8	1.1	0.8
09/09/2014 17:00	7.2	13.5	5.7	117.2	3,200,226.4	1,892.9	1.1	0.8
09/09/2014 18:00	7.3	13.5	5.8	119.9	3,208,219.0	1,874.2	1.1	0.7
09/09/2014 19:00	7.4	13.5	5.9	117.0	3,240,335.4	1,869.3	1.1	0.7
09/09/2014 20:00	7.0	13.4	5.5	118.7	3,279,164.7	1,891.7	1.1	0.8
09/09/2014 21:00	7.2	13.4	5.7	127.8	3,258,384.7	1,927.3	1.2	1.0
09/09/2014 22:00	7.2	13.4	5.7	128.1	3,265,221.3	1,907.5	1.2	1.0
09/09/2014 23:00	7.4	13.3	5.7	127.5	3,249,885.7	2,017.2	1.2	1.0
Average/Sum#:	7.4	13.6	6.0	106.4	2,987,944.7	1,679.1	1.1	0.7
Minimum:	6.7	13.3	5.4	77.6	2,455,573.6	1,255.2	0.9	0.4
Maximum:	7.9	13.8	6.6	128.1	3,341,395.5	2,017.2	1.4	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/10/2014 00:00	7.3	13.3	5.7	131.3	3,246,341.3	2,015.0	1.2	1.0
09/10/2014 01:00	7.3	13.3	5.7	144.4	3,286,129.4	2,015.7	1.3	1.0
09/10/2014 02:00	6.9	13.5	5.5	134.7	3,266,077.2	1,908.0	1.3	1.0
09/10/2014 03:00	7.3	13.4	5.7	127.0	3,269,624.5	1,981.7	1.2	1.0
09/10/2014 04:00	7.3	13.3	5.7	142.3	3,247,287.4	2,039.3	1.3	1.0
09/10/2014 05:00	7.2	13.4	5.7	128.3	3,285,115.5	1,967.1	1.2	1.0
09/10/2014 06:00	6.8	13.6	5.5	123.4	3,363,558.5	1,866.7	1.1	0.7
09/10/2014 07:00	6.7	13.6	5.4	107.9	3,310,450.1	1,861.4	1.0	0.7
09/10/2014 08:00	6.6	13.6	5.3	105.4	3,307,604.5	1,859.8	1.0	0.7
09/10/2014 09:00	7.2	13.4	5.7	120.6	3,248,917.1	1,921.7	1.1	0.8
09/10/2014 10:00	7.0	13.7	5.7	97.9	2,892,674.5	1,542.0	1.0	0.6
09/10/2014 11:00	8.0	13.9	6.7	81.4	2,467,702.7	1,261.4	1.0	0.5
09/10/2014 12:00	7.7	13.6	6.2	101.6	3,137,807.7	1,718.5	1.0	0.7
09/10/2014 13:00	7.6	13.4	6.0	114.4	3,280,363.1	1,940.3	1.0	0.8
09/10/2014 14:00	7.7	13.3	6.0	117.8	3,287,773.5	1,992.7	1.1	0.8
09/10/2014 15:00	7.6	13.1	5.7	151.3	3,246,419.3	2,204.7	1.4	1.1
09/10/2014 16:00	7.5	13.0	5.6	160.6	3,213,297.3	2,252.6	1.5	1.4
09/10/2014 17:00	7.5	13.0	5.6	157.9	3,212,726.7	2,252.2	1.5	1.4
09/10/2014 18:00	7.5	13.0	5.6	157.8	3,221,030.3	2,234.5	1.5	1.3
09/10/2014 19:00	7.6	13.1	5.7	148.4	3,256,253.0	2,187.6	1.4	1.1
09/10/2014 20:00	7.6	13.2	5.8	137.1	3,253,229.2	2,114.3	1.3	1.1
09/10/2014 21:00	7.6	13.2	5.8	130.0	3,277,860.6	2,058.5	1.2	1.0
09/10/2014 22:00	7.6	13.3	5.9	124.5	3,333,244.2	2,044.6	1.1	0.8
09/10/2014 23:00	7.5	13.2	5.7	140.5	3,314,318.2	2,129.8	1.3	1.1
Average/Sum#:	7.4	13.4	5.7	128.6	3,217,741.9	1,973.8	1.2	0.9
Minimum:	6.6	13.0	5.3	81.4	2,467,702.7	1,261.4	1.0	0.5
Maximum:	8.0	13.9	6.7	160.6	3,363,558.5	2,252.6	1.5	1.4
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/11/2014 00:00	7.5	13.3	5.8	117.5	3,344,945.9	1,978.5	1.1	0.8
09/11/2014 01:00	7.1	13.6	5.7	108.7	3,362,477.4	1,866.1	1.0	0.7
09/11/2014 02:00	7.1	13.6	5.7	108.3	3,362,477.4	1,866.1	1.0	0.7
09/11/2014 03:00	7.1	13.6	5.7	107.2	3,362,837.8	1,866.3	1.0	0.7
09/11/2014 04:00	7.4	13.5	5.9	116.7	3,333,350.1	1,947.3	1.1	0.8
09/11/2014 05:00	7.6	13.2	5.8	131.8	3,329,771.3	2,091.1	1.2	1.0
09/11/2014 06:00	7.5	13.3	5.8	126.2	3,352,584.7	2,007.5	1.1	0.8
09/11/2014 07:00	7.6	13.3	5.9	118.6	3,328,035.3	1,992.8	1.1	0.8
09/11/2014 08:00	7.5	13.3	5.8	116.0	3,326,179.7	1,967.4	1.1	0.8
09/11/2014 09:00	7.6	13.3	5.9	121.7	3,324,401.4	2,014.9	1.1	0.8
09/11/2014 10:00	7.5	13.2	5.7	133.1	3,278,837.7	2,107.0	1.2	1.1
09/11/2014 11:00	7.4	13.1	5.6	137.7	3,250,252.7	2,136.1	1.3	1.1
09/11/2014 12:00	7.5	13.3	5.8	111.1	3,254,665.3	1,925.1	1.0	0.8
09/11/2014 13:00	7.4	13.3	5.7	108.6	3,276,861.4	1,914.3	1.0	0.8
09/11/2014 14:00	7.5	13.4	5.9	108.0	3,240,400.4	1,893.0	1.0	0.8
09/11/2014 15:00	7.4	13.4	5.8	105.6	3,229,616.2	1,886.7	1.0	0.8
09/11/2014 16:00	7.5	13.2	5.7	131.0	3,221,686.3	2,093.8	1.2	1.0
09/11/2014 17:00	7.4	13.0	5.5	147.5	3,198,831.2	2,219.1	1.4	1.1
09/11/2014 18:00	7.4	13.0	5.5	156.4	3,200,031.0	2,243.3	1.5	1.3
09/11/2014 19:00	7.4	13.1	5.6	145.7	3,248,066.2	2,182.1	1.4	1.1
09/11/2014 20:00	7.4	13.1	5.6	147.7	3,220,208.8	2,186.9	1.4	1.1
09/11/2014 21:00	7.4	13.2	5.7	124.5	3,260,841.1	2,024.0	1.2	1.0
09/11/2014 22:00	7.5	13.2	5.7	127.6	3,289,325.5	2,065.7	1.2	1.0
09/11/2014 23:00	7.5	13.0	5.6	164.3	3,294,048.4	2,261.1	1.5	1.4
Average/Sum#:	7.4	13.3	5.7	125.9	3,287,113.9	2,030.7	1.2	0.9
Minimum:	7.1	13.0	5.5	105.6	3,198,831.2	1,866.1	1.0	0.7
Maximum:	7.6	13.6	5.9	164.3	3,362,837.8	2,261.1	1.5	1.4
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/12/2014 00:00	7.4	13.1	5.6	150.1	3,276,235.0	2,177.1	1.4	1.1
09/12/2014 01:00	7.1	13.4	5.6	119.9	3,269,035.8	1,933.6	1.1	0.8
09/12/2014 02:00	6.9	13.3	5.4	134.5	3,217,351.1	2,020.5	1.3	1.0
09/12/2014 03:00	6.9	13.3	5.4	139.4	3,224,600.9	2,048.6	1.3	1.0
09/12/2014 04:00	7.3	13.1	5.5	161.8	3,277,294.8	2,249.6	1.5	1.3
09/12/2014 05:00	7.4	13.1	5.6	154.8	3,302,396.7	2,218.6	1.4	1.1
09/12/2014 06:00	7.4	13.0	5.5	155.2	3,329,173.8	2,260.9	1.4	1.1
09/12/2014 07:00	7.3	13.1	5.5	159.4	3,295,600.8	2,238.1	1.5	1.3
09/12/2014 08:00	7.5	13.1	5.7	143.9	3,288,292.3	2,161.1	1.3	1.1
09/12/2014 09:00	7.6	13.0	5.7	158.0	3,266,951.3	2,242.5	1.5	1.3
09/12/2014 10:00	7.5	13.1	5.7	155.5	3,280,434.0	2,227.8	1.5	1.3
09/12/2014 11:00	7.5	13.0	5.6	153.9	3,235,192.3	2,220.7	1.5	1.3
09/12/2014 12:00	7.4	13.0	5.5	155.5	3,218,003.2	2,232.4	1.5	1.3
09/12/2014 13:00	7.3	13.0	5.5	153.1	3,192,898.5	2,238.3	1.5	1.3
09/12/2014 14:00	7.3	13.0	5.5	147.6	3,191,047.1	2,213.7	1.4	1.1
09/12/2014 15:00	7.3	13.0	5.5	149.6	3,186,866.8	2,210.8	1.5	1.3
09/12/2014 16:00	7.3	13.0	5.5	148.4	3,177,641.2	2,204.4	1.4	1.1
09/12/2014 17:00	7.2	13.0	5.4	149.8	3,176,494.0	2,226.8	1.5	1.3
09/12/2014 18:00	7.4	13.0	5.5	156.9	3,219,012.2	2,233.1	1.5	1.3
09/12/2014 19:00	7.5	13.0	5.6	162.7	3,216,007.6	2,254.5	1.6	1.4
09/12/2014 20:00	7.5	13.1	5.7	153.9	3,268,905.3	2,196.1	1.5	1.3
09/12/2014 21:00	7.5	13.2	5.7	137.3	3,259,230.0	2,118.2	1.3	1.1
09/12/2014 22:00	7.5	13.3	5.8	118.5	3,261,869.9	1,977.0	1.1	0.8
09/12/2014 23:00	7.5	13.3	5.8	118.0	3,303,652.8	1,978.2	1.1	0.8
Average/Sum#:	7.4	13.1	5.6	147.4	3,247,257.8	2,170.1	1.4	1.2
Minimum:	6.9	13.0	5.4	118.0	3,176,494.0	1,933.6	1.1	0.8
Maximum:	7.6	13.4	5.8	162.7	3,329,173.8	2,260.9	1.6	1.4
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/13/2014 00:00	7.5	13.3	5.8	116.4	3,292,296.6	1,971.4	1.1	0.8
09/13/2014 01:00	7.4	13.4	5.8	116.2	3,321,881.2	1,940.6	1.1	0.8
09/13/2014 02:00	7.3	13.6	5.9	103.7	3,274,567.6	1,793.4	0.9	0.5
09/13/2014 03:00	7.0	13.6	5.7	106.0	3,318,986.7	1,866.2	1.0	0.7
09/13/2014 04:00	7.3	13.6	5.9	108.5	3,226,435.9	1,790.6	1.0	0.7
09/13/2014 05:00	7.7	13.9	6.5	81.7	2,468,094.0	1,261.6	1.0	0.5
09/13/2014 06:00	7.8	13.9	6.6	85.4	2,455,182.3	1,255.0	1.0	0.5
09/13/2014 07:00	7.7	13.9	6.5	83.2	2,454,008.5	1,254.4	1.0	0.5
09/13/2014 08:00	7.4	13.9	6.2	87.0	2,723,785.1	1,392.3	0.9	0.4
09/13/2014 09:00	6.9	13.9	5.8	88.5	3,005,588.8	1,514.4	0.9	0.5
09/13/2014 10:00	7.0	13.8	5.8	91.8	3,041,858.0	1,577.1	0.9	0.5
09/13/2014 11:00	7.7	13.3	6.0	122.1	3,289,390.0	2,017.7	1.1	0.8
09/13/2014 12:00	7.5	13.1	5.7	138.9	3,239,064.9	2,152.4	1.3	1.1
09/13/2014 13:00	7.4	13.2	5.7	121.9	3,206,499.3	2,037.1	1.2	1.0
09/13/2014 14:00	7.4	13.2	5.7	124.7	3,189,980.7	2,049.9	1.2	1.0
09/13/2014 15:00	7.3	13.1	5.5	138.9	3,208,918.6	2,155.8	1.3	1.1
09/13/2014 16:00	7.3	13.1	5.5	137.4	3,186,293.3	2,140.6	1.3	1.1
09/13/2014 17:00	7.3	13.1	5.5	130.0	3,171,797.6	2,107.7	1.3	1.1
09/13/2014 18:00	7.4	13.3	5.7	114.9	3,211,380.7	1,993.3	1.1	0.8
09/13/2014 19:00	7.5	13.2	5.7	124.1	3,209,962.2	2,039.3	1.2	1.0
09/13/2014 20:00	7.6	13.3	5.9	120.8	3,263,024.8	1,977.7	1.1	0.8
09/13/2014 21:00	7.5	13.3	5.8	117.2	3,253,290.4	1,971.8	1.1	0.8
09/13/2014 22:00	7.2	13.4	5.7	110.5	3,268,697.7	1,933.4	1.0	0.8
09/13/2014 23:00	7.5	13.3	5.8	118.8	3,283,445.5	1,966.1	1.1	0.8
Average/Sum#:	7.4	13.4	5.9	112.0	3,106,851.3	1,840.0	1.1	0.8
Minimum:	6.9	13.1	5.5	81.7	2,454,008.5	1,254.4	0.9	0.4
Maximum:	7.8	13.9	6.6	138.9	3,321,881.2	2,155.8	1.3	1.1
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/14/2014 00:00	7.1	13.4	5.6	110.0	3,283,708.5	1,918.3	1.0	0.8
09/14/2014 01:00	6.9	13.5	5.5	100.1	3,321,832.3	1,867.8	0.9	0.6
09/14/2014 02:00	6.9	13.6	5.6	105.5	3,357,612.4	1,863.4	0.9	0.6
09/14/2014 03:00	6.9	13.6	5.6	104.0	3,316,674.7	1,864.9	0.9	0.6
09/14/2014 04:00	7.0	13.6	5.7	102.8	3,245,896.2	1,801.4	0.9	0.5
09/14/2014 05:00	7.5	13.8	6.2	78.3	2,477,484.3	1,266.4	0.9	0.4
09/14/2014 06:00	7.9	13.9	6.7	84.3	2,458,312.4	1,256.6	1.0	0.5
09/14/2014 07:00	7.8	13.9	6.6	80.5	2,458,508.0	1,256.7	1.0	0.5
09/14/2014 08:00	7.2	13.8	6.0	88.0	2,816,123.4	1,439.5	0.9	0.4
09/14/2014 09:00	7.3	13.6	5.9	94.0	3,019,395.7	1,631.6	0.9	0.5
09/14/2014 10:00	7.2	13.4	5.7	108.4	3,292,952.1	1,923.7	1.0	0.8
09/14/2014 11:00	7.4	13.3	5.7	117.3	3,261,704.9	1,976.9	1.1	0.8
09/14/2014 12:00	7.3	13.1	5.5	154.0	3,220,165.4	2,233.9	1.5	1.3
09/14/2014 13:00	7.2	13.0	5.4	155.2	3,210,444.3	2,250.6	1.5	1.4
09/14/2014 14:00	7.2	13.1	5.4	155.1	3,210,301.6	2,250.5	1.5	1.4
09/14/2014 15:00	7.1	13.0	5.3	151.7	3,193,897.1	2,239.0	1.5	1.3
09/14/2014 16:00	7.0	13.0	5.2	148.1	3,181,772.0	2,230.5	1.4	1.1
09/14/2014 17:00	7.0	13.0	5.2	145.7	3,190,326.4	2,213.2	1.4	1.1
09/14/2014 18:00	7.1	13.1	5.4	142.1	3,196,003.4	2,193.8	1.4	1.1
09/14/2014 19:00	7.2	13.1	5.4	139.4	3,215,021.4	2,159.9	1.3	1.1
09/14/2014 20:00	7.3	13.2	5.6	134.4	3,244,766.5	2,108.8	1.3	1.1
09/14/2014 21:00	7.4	13.3	5.7	123.7	3,246,332.0	2,038.7	1.2	1.0
09/14/2014 22:00	7.2	13.4	5.7	117.0	3,295,748.0	1,949.4	1.1	0.8
09/14/2014 23:00	7.2	13.4	5.7	109.9	3,280,701.3	1,940.5	1.0	0.8
Average/Sum#:	7.2	13.4	5.7	118.7	3,124,820.2	1,911.5	1.1	0.9
Minimum:	6.9	13.0	5.2	78.3	2,458,312.4	1,256.6	0.9	0.4
Maximum:	7.9	13.9	6.7	155.2	3,357,612.4	2,250.6	1.5	1.4
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/15/2014 00:00	6.9	13.5	5.5	107.9	3,310,144.5	1,885.4	1.0	0.8
09/15/2014 01:00	6.8	13.6	5.5	100.5	3,308,849.4	1,860.5	0.9	0.6
09/15/2014 02:00	6.8	13.6	5.5	100.8	3,308,315.9	1,860.2	0.9	0.6
09/15/2014 03:00	6.9	13.6	5.6	104.1	3,312,584.2	1,862.6	0.9	0.6
09/15/2014 04:00	6.9	13.6	5.6	105.2	3,316,852.6	1,865.0	1.0	0.7
09/15/2014 05:00	6.9	13.6	5.6	105.2	3,324,144.3	1,869.1	1.0	0.7
09/15/2014 06:00	7.1	13.6	5.7	128.2	3,326,456.3	1,870.4	1.2	0.9
09/15/2014 07:00	7.2	13.5	5.7	108.5	3,315,938.2	1,888.7	1.0	0.8
09/15/2014 08:00	7.4	13.3	5.7	114.9	3,324,361.2	1,990.6	1.0	0.8
09/15/2014 09:00	7.3	13.1	5.5	142.4	3,290,574.6	2,162.6	1.3	1.1
09/15/2014 10:00	7.2	13.0	5.4	151.1	3,245,390.1	2,227.7	1.4	1.1
09/15/2014 11:00	7.1	13.0	5.3	152.2	3,225,066.5	2,237.3	1.5	1.3
09/15/2014 12:00	6.8	13.3	5.3	123.5	2,930,729.3	1,819.1	1.3	0.9
09/15/2014 13:00	6.7	13.9	5.6	75.0	2,634,851.9	1,327.6	0.8	0.4
09/15/2014 14:00	6.9	14.0	5.9	79.5	2,650,332.4	1,335.4	0.9	0.4
09/15/2014 15:00	7.3	13.3	5.7	113.8	3,198,348.4	1,938.5	1.1	0.8
09/15/2014 16:00	7.4	13.1	5.6	144.5	3,216,212.2	2,160.7	1.4	1.1
09/15/2014 17:00	7.4	13.1	5.6	141.9	3,257,252.0	2,140.7	1.3	1.1
09/15/2014 18:00	7.3	13.2	5.6	138.4	3,255,691.1	2,115.9	1.3	1.1
09/15/2014 19:00	7.2	13.2	5.5	131.6	3,291,812.9	2,091.3	1.2	1.0
09/15/2014 20:00	7.3	13.3	5.7	128.5	3,316,745.9	2,058.7	1.2	1.0
09/15/2014 21:00	7.1	13.4	5.6	116.2	3,320,511.8	1,939.8	1.1	0.8
09/15/2014 22:00	6.9	13.7	5.7	106.0	3,354,909.6	1,861.9	0.9	0.6
09/15/2014 23:00	6.9	13.6	5.6	109.6	3,328,412.6	1,871.5	1.0	0.7
Average/Sum#:	7.1	13.4	5.6	117.9	3,223,520.3	1,926.7	1.1	0.8
Minimum:	6.7	13.0	5.3	75.0	2,634,851.9	1,327.6	0.8	0.4
Maximum:	7.4	14.0	5.9	152.2	3,354,909.6	2,237.3	1.5	1.3
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/16/2014 00:00	7.0	13.7	5.7	108.4	3,352,386.9	1,860.5	1.0	0.7
09/16/2014 01:00	7.1	13.7	5.8	112.0	3,347,521.9	1,857.8	1.0	0.7
09/16/2014 02:00	7.3	13.8	6.1	94.9	2,991,811.9	1,573.0	0.9	0.5
09/16/2014 03:00	7.4	13.8	6.1	76.9	2,464,192.4	1,277.6	0.9	0.4
09/16/2014 04:00	7.2	13.7	5.9	101.7	3,050,300.3	1,648.3	1.0	0.7
09/16/2014 05:00	7.0	13.4	5.5	116.9	3,349,098.5	1,956.5	1.1	0.8
09/16/2014 06:00	6.8	13.4	5.3	115.4	3,332,096.9	1,970.9	1.1	0.8
09/16/2014 07:00	6.8	13.3	5.3	121.2	3,365,777.9	2,015.4	1.1	0.8
09/16/2014 08:00	6.9	13.3	5.4	126.7	3,343,677.9	2,051.0	1.2	1.0
09/16/2014 09:00	6.9	13.3	5.4	126.8	3,341,395.5	2,049.6	1.2	1.0
09/16/2014 10:00	7.1	13.1	5.4	151.5	3,301,950.1	2,218.3	1.4	1.1
09/16/2014 11:00	7.3	13.1	5.5	153.5	3,303,438.6	2,219.3	1.4	1.1
09/16/2014 12:00	7.3	13.1	5.5	147.4	3,310,881.1	2,224.3	1.4	1.1
09/16/2014 13:00	11.2	13.1	8.5	144.7	3,293,167.9	2,212.4	1.3	1.1
09/16/2014 14:00	10.8	13.2	8.3	121.7	3,291,935.1	2,043.3	1.1	0.8
09/16/2014 15:00	10.5	13.3	8.2	111.4	3,320,683.0	1,939.9	1.0	0.8
09/16/2014 16:00	10.8	13.2	8.3	124.8	3,292,032.5	2,067.4	1.1	0.8
09/16/2014 17:00	11.1	13.1	8.4	148.7	3,248,740.8	2,230.0	1.4	1.1
09/16/2014 18:00	11.1	13.1	8.4	146.6	3,252,382.9	2,232.5	1.3	1.1
09/16/2014 19:00	11.0	13.1	8.3	144.4	3,295,306.3	2,237.9	1.3	1.1
09/16/2014 20:00	10.9	13.1	8.2	138.0	3,277,739.8	2,178.1	1.2	1.1
09/16/2014 21:00	9.9	13.5	7.9	108.2	3,301,006.1	1,904.3	0.9	0.6
09/16/2014 22:00	9.7	13.7	7.9	101.8	3,127,654.3	1,690.1	0.9	0.5
09/16/2014 23:00	10.0	13.6	8.1	106.1	3,293,465.6	1,779.7	0.9	0.5
Average/Sum#:	8.7	13.4	6.8	122.9	3,243,693.5	1,976.6	1.1	0.8
Minimum:	6.8	13.1	5.3	76.9	2,464,192.4	1,277.6	0.9	0.4
Maximum:	11.2	13.8	8.5	153.5	3,365,777.9	2,237.9	1.4	1.1
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/17/2014 00:00	10.7	13.2	8.2	130.1	3,340,150.6	2,146.4	1.1	0.9
09/17/2014 01:00	10.7	13.2	8.2	129.9	3,318,208.7	2,132.3	1.1	0.9
09/17/2014 02:00	10.4	13.3	8.1	116.0	3,346,840.2	2,028.5	1.0	0.8
09/17/2014 03:00	10.8	13.1	8.2	141.7	3,340,643.1	2,219.9	1.3	1.1
09/17/2014 04:00	10.9	13.1	8.2	140.0	3,352,381.0	2,227.7	1.2	1.1
09/17/2014 05:00	10.8	13.1	8.2	138.3	3,345,655.9	2,198.8	1.2	1.1
09/17/2014 06:00	10.8	13.1	8.2	139.6	3,348,242.6	2,200.5	1.2	1.1
09/17/2014 07:00	10.9	13.1	8.2	140.5	3,343,652.8	2,221.9	1.2	1.1
09/17/2014 08:00	10.9	13.1	8.2	139.6	3,314,308.0	2,202.4	1.2	1.1
09/17/2014 09:00	10.8	13.1	8.2	135.4	3,282,705.9	2,181.4	1.2	1.1
09/17/2014 10:00	10.8	13.1	8.2	136.5	3,289,327.3	2,185.8	1.2	1.1
09/17/2014 11:00	10.8	13.1	8.2	139.3	3,271,286.9	2,197.7	1.3	1.1
09/17/2014 12:00	10.9	13.1	8.2	144.1	3,268,654.0	2,219.8	1.3	1.1
09/17/2014 13:00	10.8	13.1	8.2	142.1	3,245,388.5	2,204.0	1.3	1.1
09/17/2014 14:00	10.7	13.1	8.1	132.6	3,238,763.9	2,152.2	1.2	1.1
09/17/2014 15:00	10.6	13.2	8.1	128.4	3,238,150.1	2,104.5	1.2	1.1
09/17/2014 16:00	10.4	13.3	8.1	114.7	3,271,439.4	1,982.8	1.0	0.8
09/17/2014 17:00	10.4	13.3	8.1	114.6	3,266,819.6	1,980.0	1.0	0.8
09/17/2014 18:00	10.5	13.2	8.0	122.2	3,223,905.1	2,071.7	1.1	0.8
09/17/2014 19:00	10.2	13.2	7.8	116.6	3,227,169.4	2,003.1	1.1	0.8
09/17/2014 20:00	10.2	13.3	7.9	114.1	3,270,614.4	1,982.3	1.0	0.8
09/17/2014 21:00	9.2	13.5	7.3	103.9	3,269,237.4	1,862.1	0.9	0.6
09/17/2014 22:00	9.2	13.5	7.3	103.1	3,269,588.5	1,862.3	0.9	0.6
09/17/2014 23:00	9.4	13.4	7.4	104.2	3,289,252.0	1,873.5	0.9	0.6
Average/Sum#:	10.5	13.2	8.0	127.8	3,290,516.1	2,101.7	1.1	0.9
Minimum:	9.2	13.1	7.3	103.1	3,223,905.1	1,862.1	0.9	0.6
Maximum:	10.9	13.5	8.2	144.1	3,352,381.0	2,227.7	1.3	1.1
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/18/2014 00:00	10.2	13.3	7.9	113.4	3,306,491.9	1,979.9	1.0	0.8
09/18/2014 01:00	10.1	13.4	7.9	112.0	3,302,679.7	1,953.5	1.0	0.8
09/18/2014 02:00	9.3	13.5	7.4	103.5	3,321,832.3	1,867.8	0.9	0.6
09/18/2014 03:00	9.7	13.5	7.7	105.8	3,189,137.1	1,769.9	1.0	0.7
09/18/2014 04:00	9.5	13.8	7.9	96.7	3,032,407.1	1,572.2	0.9	0.5
09/18/2014 05:00	9.6	13.8	8.0	98.2	3,089,112.8	1,601.6	0.9	0.5
09/18/2014 06:00	9.5	13.8	7.9	98.8	3,080,240.5	1,597.0	0.9	0.5
09/18/2014 07:00	9.6	13.8	8.0	85.2	2,522,055.4	1,307.6	1.0	0.5
09/18/2014 08:00	9.6	13.8	8.0	88.8	2,733,834.0	1,417.4	0.9	0.4
09/18/2014 09:00	9.4	13.8	7.8	97.2	3,072,911.2	1,593.2	0.9	0.5
09/18/2014 10:00	9.6	13.8	8.0	84.5	2,527,566.1	1,292.0	1.0	0.5
09/18/2014 11:00	9.7	13.8	8.1	83.8	2,526,196.7	1,291.3	0.9	0.4
09/18/2014 12:00	9.5	13.8	7.9	91.4	2,901,419.0	1,483.1	0.9	0.4
09/18/2014 13:00	9.3	13.9	7.8	97.9	3,150,067.3	1,610.2	0.9	0.5
09/18/2014 14:00	9.4	13.7	7.7	100.1	3,225,476.6	1,672.3	0.9	0.5
09/18/2014 15:00	9.6	13.7	7.9	97.2	3,077,347.3	1,595.5	0.9	0.5
09/18/2014 16:00	9.7	13.6	7.8	104.3	3,149,676.1	1,725.0	1.0	0.7
09/18/2014 17:00	10.3	13.3	8.0	113.7	3,260,550.0	1,976.2	1.0	0.8
09/18/2014 18:00	10.5	13.2	8.0	126.3	3,265,683.6	2,074.7	1.1	0.8
09/18/2014 19:00	10.6	13.2	8.1	129.9	3,254,561.5	2,091.4	1.2	1.0
09/18/2014 20:00	9.7	13.5	7.7	106.7	3,263,910.3	1,882.9	0.9	0.6
09/18/2014 21:00	9.9	13.6	8.0	99.7	2,875,611.0	1,595.9	1.0	0.6
09/18/2014 22:00	10.5	13.8	8.7	83.1	2,435,619.1	1,245.0	1.0	0.5
09/18/2014 23:00	10.2	13.8	8.5	88.6	2,673,507.7	1,366.6	0.9	0.4
Average/Sum#:	9.8	13.6	7.9	100.3	3,009,912.3	1,648.4	1.0	0.6
Minimum:	9.3	13.2	7.4	83.1	2,435,619.1	1,245.0	0.9	0.4
Maximum:	10.6	13.9	8.7	129.9	3,321,832.3	2,091.4	1.2	1.0
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/19/2014 00:00	10.3	13.8	8.6	84.9	2,470,637.2	1,262.9	1.0	0.5
09/19/2014 01:00	10.4	13.8	8.6	85.0	2,452,834.7	1,253.8	1.0	0.5
09/19/2014 02:00	10.4	13.8	8.6	85.0	2,451,074.0	1,252.9	1.0	0.5
09/19/2014 03:00	10.3	13.8	8.6	85.6	2,583,516.9	1,320.6	0.9	0.4
09/19/2014 04:00	10.1	13.8	8.4	85.4	2,629,686.1	1,344.2	0.9	0.4
09/19/2014 05:00	10.2	13.7	8.4	98.4	3,036,370.3	1,618.6	0.9	0.5
09/19/2014 06:00	10.6	13.4	8.3	121.5	3,233,491.5	1,959.8	1.1	0.8
09/19/2014 07:00	9.8	13.6	7.9	105.7	3,356,531.2	1,862.8	0.9	0.6
09/19/2014 08:00	9.8	13.5	7.8	107.0	3,296,625.9	1,877.7	0.9	0.6
09/19/2014 09:00	9.8	13.5	7.8	106.7	3,312,602.5	1,886.8	0.9	0.6
09/19/2014 10:00	9.3	13.5	7.4	103.8	3,265,901.6	1,860.2	0.9	0.6
09/19/2014 11:00	9.2	13.4	7.2	103.1	3,261,336.8	1,857.6	0.9	0.6
09/19/2014 12:00	10.1	13.3	7.8	113.1	3,212,604.4	1,970.6	1.0	0.8
09/19/2014 13:00	10.4	13.3	8.1	114.1	3,206,735.4	1,967.0	1.0	0.8
09/19/2014 14:00	10.5	13.2	8.0	119.6	3,227,701.4	2,027.0	1.1	0.8
09/19/2014 15:00	10.9	13.0	8.1	145.5	3,153,629.1	2,233.8	1.4	1.1
09/19/2014 16:00	10.9	13.0	8.1	145.2	3,162,240.9	2,239.9	1.4	1.1
09/19/2014 17:00	10.9	13.0	8.1	144.0	3,177,492.5	2,227.5	1.3	1.1
09/19/2014 18:00	10.8	13.1	8.2	131.8	3,198,433.6	2,125.4	1.2	1.1
09/19/2014 19:00	10.1	13.3	7.8	112.9	3,239,022.7	1,939.5	1.0	0.8
09/19/2014 20:00	10.2	13.3	7.9	110.2	3,256,355.9	1,926.1	1.0	0.8
09/19/2014 21:00	10.2	13.3	7.9	111.8	3,274,784.0	1,937.0	1.0	0.8
09/19/2014 22:00	10.5	13.3	8.2	114.6	3,264,344.8	1,978.5	1.0	0.8
09/19/2014 23:00	10.6	13.2	8.1	120.7	3,270,185.4	2,029.8	1.1	0.8
Average/Sum#:	10.3	13.4	8.1	110.7	3,083,089.1	1,831.7	1.0	0.7
Minimum:	9.2	13.0	7.2	84.9	2,451,074.0	1,252.9	0.9	0.4
Maximum:	10.9	13.8	8.6	145.5	3,356,531.2	2,239.9	1.4	1.1
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/20/2014 00:00	10.7	13.2	8.2	126.6	3,260,017.1	2,071.1	1.1	0.8
09/20/2014 01:00	11.0	13.1	8.3	137.7	3,235,711.7	2,173.8	1.3	1.1
09/20/2014 02:00	10.6	13.3	8.2	116.9	3,262,816.6	2,001.4	1.0	0.8
09/20/2014 03:00	10.6	13.3	8.2	115.8	3,290,413.3	1,994.3	1.0	0.8
09/20/2014 04:00	10.6	13.3	8.2	117.6	3,275,043.6	2,008.9	1.0	0.8
09/20/2014 05:00	10.6	13.3	8.2	115.1	3,271,439.4	1,982.8	1.0	0.8
09/20/2014 06:00	10.6	13.3	8.2	115.6	3,291,898.2	1,995.2	1.0	0.8
09/20/2014 07:00	10.6	13.3	8.2	116.6	3,306,087.4	2,003.8	1.0	0.8
09/20/2014 08:00	9.7	13.5	7.7	105.6	3,308,493.7	1,860.3	0.9	0.6
09/20/2014 09:00	9.6	13.5	7.7	104.5	3,301,913.4	1,856.6	0.9	0.6
09/20/2014 10:00	9.3	13.5	7.4	103.6	3,255,016.4	1,854.0	0.9	0.6
09/20/2014 11:00	9.3	13.5	7.4	103.6	3,255,543.1	1,854.3	0.9	0.6
09/20/2014 12:00	9.4	13.4	7.4	103.7	3,260,459.0	1,857.1	0.9	0.6
09/20/2014 13:00	10.0	13.3	7.8	107.9	3,244,851.1	1,895.6	1.0	0.8
09/20/2014 14:00	10.1	13.3	7.8	109.1	3,225,417.1	1,907.8	1.0	0.8
09/20/2014 15:00	10.3	13.3	8.0	110.9	3,213,805.2	1,924.4	1.0	0.8
09/20/2014 16:00	10.0	13.3	7.8	106.3	3,241,028.8	1,869.7	0.9	0.6
09/20/2014 17:00	10.2	13.3	7.9	111.7	3,198,513.4	1,938.6	1.0	0.8
09/20/2014 18:00	10.1	13.3	7.8	111.7	3,220,457.2	1,951.9	1.0	0.8
09/20/2014 19:00	10.6	13.1	8.0	125.8	3,201,683.4	2,080.8	1.2	1.0
09/20/2014 20:00	9.9	13.3	7.7	107.7	3,236,121.0	1,890.5	1.0	0.8
09/20/2014 21:00	10.3	13.3	8.0	112.6	3,260,232.1	1,952.2	1.0	0.8
09/20/2014 22:00	9.6	13.5	7.7	104.6	3,268,008.4	1,861.4	0.9	0.6
09/20/2014 23:00	10.1	13.4	7.9	109.6	3,273,437.8	1,912.3	1.0	0.8
Average/Sum#:	10.2	13.3	7.9	112.5	3,256,600.4	1,945.8	1.0	0.8
Minimum:	9.3	13.1	7.4	103.6	3,198,513.4	1,854.0	0.9	0.6
Maximum:	11.0	13.5	8.3	137.7	3,308,493.7	2,173.8	1.3	1.1
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/21/2014 00:00	9.6	13.6	7.8	104.7	3,294,977.3	1,852.7	0.9	0.6
09/21/2014 01:00	9.5	13.5	7.6	104.2	3,292,843.2	1,851.5	0.9	0.6
09/21/2014 02:00	9.6	13.6	7.8	104.4	3,295,688.7	1,853.1	0.9	0.6
09/21/2014 03:00	9.6	13.6	7.8	104.3	3,293,021.0	1,851.6	0.9	0.6
09/21/2014 04:00	9.7	13.6	7.8	104.6	3,298,890.0	1,854.9	0.9	0.6
09/21/2014 05:00	9.7	13.6	7.8	104.7	3,296,578.0	1,853.6	0.9	0.6
09/21/2014 06:00	9.9	13.6	8.0	106.2	3,345,720.0	1,856.8	0.9	0.6
09/21/2014 07:00	9.9	13.5	7.9	105.7	3,308,849.4	1,860.5	0.9	0.6
09/21/2014 08:00	9.7	13.6	7.8	104.4	3,294,799.5	1,852.6	0.9	0.6
09/21/2014 09:00	9.5	13.5	7.6	103.8	3,288,574.8	1,849.1	0.9	0.6
09/21/2014 10:00	9.5	13.5	7.6	103.7	3,288,930.5	1,849.3	0.9	0.6
09/21/2014 11:00	9.7	13.5	7.7	102.1	3,071,067.6	1,726.8	1.0	0.7
09/21/2014 12:00	10.3	13.8	8.6	85.1	2,424,845.5	1,257.2	1.0	0.5
09/21/2014 13:00	10.7	13.8	8.9	85.6	2,443,248.7	1,248.9	1.0	0.5
09/21/2014 14:00	10.7	13.8	8.9	85.6	2,456,747.3	1,255.8	1.0	0.5
09/21/2014 15:00	10.5	13.8	8.7	85.3	2,479,636.3	1,267.5	1.0	0.5
09/21/2014 16:00	10.4	13.8	8.6	85.3	2,509,959.3	1,283.0	1.0	0.5
09/21/2014 17:00	9.7	13.6	7.8	101.1	3,159,299.1	1,707.2	0.9	0.5
09/21/2014 18:00	9.8	13.4	7.7	105.9	3,259,750.1	1,880.5	0.9	0.6
09/21/2014 19:00	10.2	13.3	7.9	111.8	3,275,798.4	1,937.6	1.0	0.8
09/21/2014 20:00	9.6	13.5	7.7	104.4	3,300,668.5	1,855.9	0.9	0.6
09/21/2014 21:00	9.7	13.6	7.8	104.5	3,299,067.8	1,855.0	0.9	0.6
09/21/2014 22:00	9.9	13.7	8.1	95.7	2,819,163.7	1,523.4	1.0	0.6
09/21/2014 23:00	10.5	13.8	8.7	85.2	2,409,029.7	1,249.0	1.0	0.5
Average/Sum#:	9.9	13.6	8.0	99.5	3,050,298.1	1,684.7	0.9	0.6
Minimum:	9.5	13.3	7.6	85.1	2,409,029.7	1,248.9	0.9	0.5
Maximum:	10.7	13.8	8.9	111.8	3,345,720.0	1,937.6	1.0	0.8
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/22/2014 00:00	10.7	13.8	8.9	85.5	2,409,994.0	1,249.5	1.0	0.5
09/22/2014 01:00	10.8	13.8	9.0	85.6	2,407,100.9	1,248.0	1.0	0.5
09/22/2014 02:00	10.7	13.8	8.9	85.8	2,459,756.2	1,275.3	1.0	0.5
09/22/2014 03:00	10.4	13.7	8.5	102.4	3,134,501.4	1,693.8	0.9	0.5
09/22/2014 04:00	10.4	13.6	8.4	110.2	3,317,030.4	1,865.1	0.9	0.6
09/22/2014 05:00	10.5	13.4	8.3	114.1	3,316,232.3	1,937.3	1.0	0.8
09/22/2014 06:00	10.8	13.3	8.4	125.6	3,260,822.4	2,047.8	1.1	0.8
09/22/2014 07:00	10.2	13.7	8.4	92.4	2,689,665.2	1,394.5	1.0	0.6
09/22/2014 08:00	10.4	13.8	8.6	85.3	2,468,628.5	1,279.9	1.0	0.5
09/22/2014 09:00	10.4	13.8	8.6	85.4	2,468,628.5	1,279.9	1.0	0.5
09/22/2014 10:00	10.3	13.8	8.6	85.5	2,529,522.5	1,293.0	1.0	0.5
09/22/2014 11:00	10.1	13.8	8.4	89.9	2,767,997.9	1,414.9	0.9	0.4
09/22/2014 12:00	10.1	13.6	8.2	105.2	3,268,359.5	1,718.4	0.9	0.5
09/22/2014 13:00	9.9	13.6	8.0	104.1	3,217,196.3	1,691.5	0.9	0.5
09/22/2014 14:00	10.1	13.5	8.1	106.5	3,252,664.3	1,733.9	0.9	0.5
09/22/2014 15:00	10.0	13.5	8.0	103.1	3,242,909.5	1,728.7	0.9	0.5
09/22/2014 16:00	10.0	13.5	8.0	105.7	3,240,095.6	1,727.2	0.9	0.5
09/22/2014 17:00	10.0	13.5	8.0	104.5	3,244,410.2	1,729.5	0.9	0.5
09/22/2014 18:00	10.1	13.5	8.1	106.5	3,255,478.2	1,735.4	0.9	0.5
09/22/2014 19:00	10.1	13.5	8.1	107.0	3,267,484.1	1,741.8	0.9	0.5
09/22/2014 20:00	10.0	13.5	8.0	106.8	3,253,977.4	1,734.6	0.9	0.5
09/22/2014 21:00	10.1	13.6	8.2	105.5	3,247,247.6	1,707.3	0.9	0.5
09/22/2014 22:00	9.9	13.7	8.1	97.4	2,978,594.5	1,544.3	0.9	0.5
09/22/2014 23:00	10.4	13.7	8.5	103.5	3,207,539.1	1,663.0	0.9	0.5
Average/Sum#:	10.3	13.6	8.3	100.1	2,996,076.5	1,601.4	0.9	0.5
Minimum:	9.9	13.3	8.0	85.3	2,407,100.9	1,248.0	0.9	0.4
Maximum:	10.8	13.8	9.0	125.6	3,317,030.4	2,047.8	1.1	0.8
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/23/2014 00:00	10.4	13.7	8.5	101.8	3,130,388.4	1,623.0	0.9	0.5
09/23/2014 01:00	10.3	13.8	8.6	100.0	3,106,050.1	1,587.7	0.9	0.5
09/23/2014 02:00	10.4	13.8	8.6	99.8	3,087,465.1	1,578.2	0.9	0.5
09/23/2014 03:00	10.3	13.7	8.4	104.1	3,247,657.4	1,683.8	0.9	0.5
09/23/2014 04:00	10.3	13.7	8.4	106.4	3,265,316.4	1,716.8	0.9	0.5
09/23/2014 05:00	10.3	13.7	8.4	106.6	3,270,261.5	1,719.4	0.9	0.5
09/23/2014 06:00	10.2	13.6	8.2	110.6	3,392,939.1	1,783.9	0.9	0.5
09/23/2014 07:00	10.2	13.6	8.2	105.1	3,195,133.4	1,679.9	0.9	0.5
09/23/2014 08:00	0.0	0.0	0.0	100.4	2,514,726.1	1,303.8	1.3	0.7
09/23/2014 09:00	10.5	13.8	8.7	102.4	843,932.3	1,288.0	3.8	1.9
09/23/2014 10:00	10.5	13.8	8.7	104.7	839,411.3	1,281.1	3.9	1.9
09/23/2014 11:00	10.2	13.8	8.5	106.6	961,545.6	1,467.5	3.5	1.9
09/23/2014 12:00	10.1	13.8	8.4	115.5	1,087,414.7	1,659.6	3.3	2.2
09/23/2014 13:00	9.9	13.7	8.1	109.8	3,135,030.9	1,648.3	1.0	0.7
09/23/2014 14:00	10.3	13.6	8.3	107.6	3,316,289.4	1,743.6	0.9	0.5
09/23/2014 15:00	10.3	13.6	8.3	107.6	3,315,718.8	1,743.3	0.9	0.5
09/23/2014 16:00	10.2	13.6	8.2	107.3	3,303,355.9	1,736.8	0.9	0.5
09/23/2014 17:00	10.2	13.6	8.2	107.1	3,259,042.4	1,737.3	0.9	0.5
09/23/2014 18:00	10.1	13.6	8.2	107.5	3,320,093.3	1,745.6	0.9	0.5
09/23/2014 19:00	10.2	13.6	8.2	107.9	3,326,560.1	1,749.0	0.9	0.5
09/23/2014 20:00	10.0	13.7	8.2	105.2	3,225,945.4	1,696.1	0.9	0.5
09/23/2014 21:00	10.2	13.5	8.1	107.5	3,288,682.0	1,753.1	0.9	0.5
09/23/2014 22:00	10.1	13.6	8.2	107.6	3,283,429.5	1,750.3	0.9	0.5
09/23/2014 23:00	10.1	13.6	8.2	107.9	3,296,373.3	1,757.2	0.9	0.5
Average/Sum#:	10.2	13.7	8.3	106.1	3,214,022.9	1,643.1	0.9	0.5
Minimum:	9.9	13.5	8.1	99.8	2,514,726.1	1,281.1	0.9	0.5
Maximum:	10.5	13.8	8.7	115.5	3,392,939.1	1,783.9	1.0	0.7
%SI	4.2	4.2	4.2	0.0	16.7	0.0	20.8	20.8

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/24/2014 00:00	10.1	13.6	8.2	108.3	3,311,193.1	1,765.1	0.9	0.5
09/24/2014 01:00	10.1	13.6	8.2	108.3	3,320,947.9	1,770.3	0.9	0.5
09/24/2014 02:00	9.8	13.6	7.9	107.5	3,317,008.5	1,768.2	0.9	0.5
09/24/2014 03:00	9.6	13.6	7.8	106.5	3,351,476.0	1,762.1	0.9	0.5
09/24/2014 04:00	10.0	13.6	8.1	106.8	3,276,113.3	1,746.4	0.9	0.5
09/24/2014 05:00	10.0	13.6	8.1	101.8	3,188,856.8	1,676.6	0.9	0.5
09/24/2014 06:00	9.9	13.6	8.0	101.1	3,340,082.4	1,780.5	0.9	0.5
09/24/2014 07:00	9.9	13.6	8.0	111.5	3,264,365.4	1,716.3	1.0	0.7
09/24/2014 08:00	9.7	13.7	7.9	111.6	3,078,697.5	1,596.2	1.0	0.6
09/24/2014 09:00	10.0	13.6	8.1	111.6	3,280,532.2	1,724.8	1.0	0.7
09/24/2014 10:00	9.9	13.5	7.9	113.0	3,288,869.6	1,753.2	1.0	0.7
09/24/2014 11:00	9.9	13.5	7.9	114.0	3,278,739.6	1,747.8	1.0	0.7
09/24/2014 12:00	9.9	13.5	7.9	113.2	3,268,422.1	1,742.3	1.0	0.7
09/24/2014 13:00	9.9	13.6	8.0	114.4	3,256,603.7	1,736.0	1.0	0.7
09/24/2014 14:00	9.7	13.6	7.8	108.5	3,296,699.0	1,733.3	0.9	0.5
09/24/2014 15:00	9.4	13.6	7.6	104.3	3,291,944.1	1,730.8	0.9	0.5
09/24/2014 16:00	9.4	13.6	7.6	104.1	3,292,134.3	1,730.9	0.9	0.5
09/24/2014 17:00	9.7	13.6	7.8	105.5	3,267,671.7	1,741.9	0.9	0.5
09/24/2014 18:00	9.9	13.5	7.9	106.4	3,285,117.8	1,751.2	0.9	0.5
09/24/2014 19:00	9.9	13.5	7.9	106.6	3,288,682.0	1,753.1	0.9	0.5
09/24/2014 20:00	9.9	13.6	8.0	107.1	3,305,752.9	1,762.2	0.9	0.5
09/24/2014 21:00	9.9	13.6	8.0	101.8	3,322,073.5	1,770.9	0.9	0.5
09/24/2014 22:00	10.0	13.6	8.1	103.0	3,326,575.7	1,773.3	0.9	0.5
09/24/2014 23:00	9.9	13.6	8.0	108.2	3,377,342.9	1,775.7	0.9	0.5
Average/Sum#:	9.9	13.6	7.9	107.7	3,286,495.9	1,742.0	0.9	0.6
Minimum:	9.4	13.5	7.6	101.1	3,078,697.5	1,596.2	0.9	0.5
Maximum:	10.1	13.7	8.2	114.4	3,377,342.9	1,780.5	1.0	0.7
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/25/2014 00:00	10.0	13.6	8.1	106.6	3,329,202.0	1,774.7	0.9	0.5
09/25/2014 01:00	10.0	13.6	8.1	103.9	3,332,578.7	1,776.5	0.9	0.5
09/25/2014 02:00	10.0	13.6	8.1	104.4	3,336,705.7	1,778.7	0.9	0.5
09/25/2014 03:00	9.9	13.6	8.0	103.9	3,302,024.5	1,736.1	0.9	0.5
09/25/2014 04:00	9.9	13.6	8.0	108.2	3,337,080.9	1,778.9	0.9	0.5
09/25/2014 05:00	10.0	13.6	8.1	109.0	3,311,534.4	1,741.1	0.9	0.5
09/25/2014 06:00	9.9	13.6	8.0	110.8	3,341,583.1	1,781.3	0.9	0.5
09/25/2014 07:00	9.8	13.6	7.9	117.0	3,346,150.4	1,759.3	1.0	0.7
09/25/2014 08:00	9.9	13.6	8.0	115.9	3,355,089.7	1,788.5	1.0	0.7
09/25/2014 09:00	9.3	13.6	7.5	113.8	3,370,305.6	1,772.0	1.0	0.7
09/25/2014 10:00	9.4	13.6	7.6	113.6	3,335,309.2	1,753.6	1.0	0.7
09/25/2014 11:00	9.7	13.5	7.7	113.9	3,329,389.6	1,774.8	1.0	0.7
09/25/2014 12:00	9.8	13.6	7.9	112.1	3,302,376.3	1,760.4	1.0	0.7
09/25/2014 13:00	10.5	13.2	8.0	118.3	3,326,734.6	2,064.9	1.0	0.8
09/25/2014 14:00	10.8	13.1	8.2	128.0	3,312,333.3	2,176.9	1.1	0.9
09/25/2014 15:00	10.9	13.0	8.1	133.6	3,268,065.0	2,219.4	1.2	1.1
09/25/2014 16:00	10.4	13.3	8.1	113.2	3,331,420.7	1,970.5	1.0	0.8
09/25/2014 17:00	10.6	13.2	8.1	118.0	3,343,351.8	2,050.8	1.0	0.8
09/25/2014 18:00	10.7	13.2	8.2	122.0	3,324,835.0	2,088.0	1.1	0.8
09/25/2014 19:00	10.8	13.2	8.3	124.8	3,306,766.4	2,100.8	1.1	0.8
09/25/2014 20:00	10.3	13.4	8.1	111.6	3,342,936.1	1,952.9	1.0	0.8
09/25/2014 21:00	10.2	13.5	8.1	108.6	3,334,288.4	1,923.5	0.9	0.6
09/25/2014 22:00	10.3	13.4	8.1	110.1	3,373,748.1	1,970.9	0.9	0.6
09/25/2014 23:00	10.7	13.2	8.2	122.2	3,363,628.5	2,087.8	1.1	0.8
Average/Sum#:	10.2	13.4	8.0	114.3	3,331,559.9	1,899.3	1.0	0.7
Minimum:	9.3	13.0	7.5	103.9	3,268,065.0	1,736.1	0.9	0.5
Maximum:	10.9	13.6	8.3	133.6	3,373,748.1	2,219.4	1.2	1.1
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/26/2014 00:00	10.5	13.3	8.2	113.0	3,387,442.4	1,978.9	1.0	0.8
09/26/2014 01:00	10.5	13.3	8.2	114.1	3,409,010.8	1,991.5	1.0	0.8
09/26/2014 02:00	10.4	13.4	8.2	110.0	3,391,783.3	1,931.9	0.9	0.6
09/26/2014 03:00	10.4	13.4	8.2	111.2	3,396,345.8	1,959.3	0.9	0.6
09/26/2014 04:00	11.0	13.1	8.3	135.4	3,366,958.1	2,212.8	1.2	1.1
09/26/2014 05:00	11.2	13.1	8.5	139.9	3,366,526.7	2,237.1	1.2	1.1
09/26/2014 06:00	11.2	13.0	8.4	149.4	3,392,109.3	2,254.1	1.3	1.1
09/26/2014 07:00	10.8	13.2	8.3	123.0	3,369,911.7	2,091.7	1.1	0.8
09/26/2014 08:00	10.3	13.5	8.2	107.8	3,369,673.2	1,894.7	0.9	0.6
09/26/2014 09:00	10.7	13.3	8.3	115.6	3,373,961.1	2,020.3	1.0	0.8
09/26/2014 10:00	10.7	13.3	8.3	118.3	3,380,498.3	2,048.9	1.0	0.8
09/26/2014 11:00	10.6	13.3	8.2	114.4	3,374,363.1	1,995.9	1.0	0.8
09/26/2014 12:00	10.1	13.5	8.1	107.5	3,342,448.9	1,903.8	0.9	0.6
09/26/2014 13:00	9.9	13.6	8.0	104.2	3,377,973.5	1,874.7	0.9	0.6
09/26/2014 14:00	9.9	13.6	8.0	105.3	3,385,181.0	1,878.7	0.9	0.6
09/26/2014 15:00	9.9	13.6	8.0	105.0	3,372,567.9	1,871.7	0.9	0.6
09/26/2014 16:00	9.8	13.6	7.9	104.9	3,377,252.8	1,874.3	0.9	0.6
09/26/2014 17:00	10.3	13.4	8.1	110.0	3,369,130.7	1,943.6	0.9	0.6
09/26/2014 18:00	10.2	13.5	8.1	106.7	3,364,921.5	1,916.6	0.9	0.6
09/26/2014 19:00	10.0	13.6	8.1	106.2	3,388,064.0	1,880.3	0.9	0.6
09/26/2014 20:00	10.2	13.6	8.2	106.5	3,392,748.9	1,882.9	0.9	0.6
09/26/2014 21:00	10.4	13.5	8.3	110.5	3,362,196.9	1,939.6	0.9	0.6
09/26/2014 22:00	10.2	13.5	8.1	107.6	3,390,303.5	1,906.3	0.9	0.6
09/26/2014 23:00	10.8	13.3	8.4	119.7	3,382,478.2	2,050.1	1.0	0.8
Average/Sum#:	10.4	13.4	8.2	114.4	3,378,493.8	1,980.8	1.0	0.7
Minimum:	9.8	13.0	7.9	104.2	3,342,448.9	1,871.7	0.9	0.6
Maximum:	11.2	13.6	8.5	149.4	3,409,010.8	2,254.1	1.3	1.1
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/27/2014 00:00	10.8	13.2	8.3	121.1	3,353,800.9	2,081.7	1.0	0.8
09/27/2014 01:00	11.0	13.1	8.3	134.9	3,355,712.2	2,156.4	1.2	1.1
09/27/2014 02:00	10.6	13.3	8.2	113.6	3,394,974.2	1,983.3	1.0	0.8
09/27/2014 03:00	10.5	13.4	8.3	110.3	3,357,343.2	1,936.8	0.9	0.6
09/27/2014 04:00	10.5	13.5	8.4	109.5	3,392,259.8	1,907.4	0.9	0.6
09/27/2014 05:00	10.6	13.4	8.3	111.5	3,393,714.5	1,933.0	0.9	0.6
09/27/2014 06:00	10.6	13.4	8.3	114.7	3,384,409.5	1,927.7	1.0	0.8
09/27/2014 07:00	10.4	13.6	8.4	101.1	2,960,917.6	1,600.0	1.0	0.6
09/27/2014 08:00	10.6	13.8	8.8	85.7	2,458,020.3	1,274.4	1.0	0.5
09/27/2014 09:00	10.7	13.8	8.9	88.3	2,604,220.8	1,350.2	1.0	0.5
09/27/2014 10:00	10.8	13.8	9.0	86.6	2,518,958.3	1,287.6	1.0	0.5
09/27/2014 11:00	10.9	13.8	9.1	86.0	2,466,724.6	1,260.9	1.0	0.5
09/27/2014 12:00	10.9	13.8	9.1	86.0	2,462,420.7	1,258.7	1.0	0.5
09/27/2014 13:00	10.9	13.8	9.1	86.0	2,462,420.7	1,258.7	1.0	0.5
09/27/2014 14:00	10.9	13.8	9.1	85.9	2,463,985.7	1,259.5	1.0	0.5
09/27/2014 15:00	10.9	13.8	9.1	86.0	2,459,877.5	1,257.4	1.0	0.5
09/27/2014 16:00	10.9	13.9	9.2	85.9	2,452,443.4	1,253.6	1.0	0.5
09/27/2014 17:00	10.5	13.6	8.5	99.0	2,998,484.2	1,620.3	0.9	0.5
09/27/2014 18:00	11.1	13.1	8.4	138.7	3,308,589.5	2,198.6	1.2	1.1
09/27/2014 19:00	10.5	13.3	8.2	115.7	3,302,817.8	1,977.7	1.0	0.8
09/27/2014 20:00	10.2	13.4	8.0	108.2	3,312,446.9	1,910.9	0.9	0.6
09/27/2014 21:00	10.5	13.3	8.2	113.3	3,329,730.0	1,969.5	1.0	0.8
09/27/2014 22:00	9.8	13.5	7.8	103.7	3,345,539.8	1,856.7	0.9	0.6
09/27/2014 23:00	10.3	13.5	8.2	105.7	3,351,532.8	1,884.5	0.9	0.6
Average/Sum#:	10.6	13.5	8.6	103.2	2,995,472.7	1,683.6	1.0	0.6
Minimum:	9.8	13.1	7.8	85.7	2,452,443.4	1,253.6	0.9	0.5
Maximum:	11.1	13.9	9.2	138.7	3,394,974.2	2,198.6	1.2	1.1
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/28/2014 00:00	10.3	13.7	8.4	95.7	2,709,239.6	1,464.0	1.0	0.6
09/28/2014 01:00	11.0	13.8	9.1	86.2	2,458,312.4	1,256.6	1.0	0.5
09/28/2014 02:00	11.1	13.8	9.2	86.3	2,457,529.9	1,256.2	1.0	0.5
09/28/2014 03:00	10.7	13.8	8.9	96.1	2,974,389.8	1,520.4	0.9	0.5
09/28/2014 04:00	10.5	13.5	8.4	110.8	3,315,088.1	1,839.8	1.0	0.7
09/28/2014 05:00	10.7	13.3	8.3	114.8	3,345,904.6	2,003.5	1.0	0.8
09/28/2014 06:00	10.7	13.3	8.3	121.0	3,345,520.3	2,027.7	1.0	0.8
09/28/2014 07:00	10.2	13.5	8.1	107.4	3,349,398.6	1,883.3	0.9	0.6
09/28/2014 08:00	10.2	13.5	8.1	107.9	3,343,677.9	1,904.5	0.9	0.6
09/28/2014 09:00	10.2	13.8	8.5	87.8	2,531,120.6	1,312.3	1.0	0.5
09/28/2014 10:00	10.4	13.7	8.5	84.6	2,425,424.2	1,257.5	1.0	0.5
09/28/2014 11:00	10.3	13.7	8.4	93.6	2,906,181.2	1,549.2	0.9	0.5
09/28/2014 12:00	9.9	13.6	8.0	104.8	3,365,360.4	1,867.7	0.9	0.6
09/28/2014 13:00	9.8	13.6	7.9	104.6	3,319,164.6	1,866.3	0.9	0.6
09/28/2014 14:00	9.8	13.6	7.9	104.5	3,362,657.6	1,866.2	0.9	0.6
09/28/2014 15:00	9.9	13.6	8.0	104.9	3,363,558.5	1,866.7	0.9	0.6
09/28/2014 16:00	10.3	13.4	8.1	110.8	3,344,647.9	1,953.9	0.9	0.6
09/28/2014 17:00	10.8	13.2	8.3	124.0	3,332,319.1	2,092.7	1.1	0.8
09/28/2014 18:00	11.2	13.0	8.4	150.0	3,316,483.6	2,276.5	1.3	1.1
09/28/2014 19:00	11.3	13.0	8.4	151.8	3,293,826.0	2,285.0	1.4	1.1
09/28/2014 20:00	10.6	13.3	8.2	117.7	3,330,506.1	2,018.6	1.0	0.8
09/28/2014 21:00	10.5	13.3	8.2	112.3	3,365,360.4	1,966.0	1.0	0.8
09/28/2014 22:00	10.4	13.4	8.2	111.5	3,345,674.9	1,954.5	1.0	0.8
09/28/2014 23:00	10.0	13.6	8.1	105.5	3,360,855.7	1,865.2	0.9	0.6
Average/Sum#:	10.5	13.5	8.3	108.1	3,135,925.1	1,798.1	1.0	0.7
Minimum:	9.8	13.0	7.9	84.6	2,425,424.2	1,256.2	0.9	0.5
Maximum:	11.3	13.8	9.2	151.8	3,365,360.4	2,285.0	1.4	1.1
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/29/2014 00:00	9.9	13.6	8.0	100.8	3,364,949.6	1,842.9	0.8	0.6
09/29/2014 01:00	10.0	13.6	8.1	106.4	3,407,646.0	1,841.4	0.9	0.6
09/29/2014 02:00	9.9	13.6	8.0	100.8	3,409,126.5	1,842.2	0.8	0.6
09/29/2014 03:00	10.0	13.6	8.1	101.8	3,409,126.5	1,842.2	0.8	0.6
09/29/2014 04:00	10.2	13.6	8.2	105.9	3,368,063.2	1,869.2	0.9	0.6
09/29/2014 05:00	10.4	13.6	8.4	107.2	3,349,754.3	1,883.5	0.9	0.6
09/29/2014 06:00	10.6	13.3	8.2	124.3	3,371,122.0	2,018.6	1.1	0.8
09/29/2014 07:00	10.4	13.6	8.4	107.0	3,319,164.6	1,866.3	0.9	0.6
09/29/2014 08:00	10.3	13.6	8.3	106.3	3,318,808.9	1,866.1	0.9	0.6
09/29/2014 09:00	10.2	13.6	8.2	113.3	3,334,103.8	1,874.7	1.0	0.7
09/29/2014 10:00	10.0	13.5	8.0	106.4	3,348,153.7	1,882.6	0.9	0.6
09/29/2014 11:00	10.0	13.5	8.0	105.9	3,342,462.6	1,879.4	0.9	0.6
09/29/2014 12:00	10.2	13.8	8.5	86.7	2,486,180.3	1,289.0	1.0	0.5
09/29/2014 13:00	10.8	13.8	9.0	85.5	2,460,660.0	1,257.8	1.0	0.5
09/29/2014 14:00	10.3	13.7	8.4	94.2	2,867,912.3	1,528.8	0.9	0.5
09/29/2014 15:00	9.6	13.5	7.7	104.0	3,324,677.8	1,869.4	0.9	0.6
09/29/2014 16:00	10.1	13.4	7.9	107.9	3,327,181.2	1,919.4	0.9	0.6
09/29/2014 17:00	10.6	13.3	8.2	114.9	3,305,427.5	2,003.4	1.0	0.8
09/29/2014 18:00	11.0	13.1	8.3	136.2	3,279,244.7	2,179.1	1.2	1.1
09/29/2014 19:00	10.9	13.1	8.2	130.1	3,293,388.7	2,140.4	1.2	1.1
09/29/2014 20:00	10.3	13.3	8.0	110.9	3,294,057.4	1,948.4	1.0	0.8
09/29/2014 21:00	10.1	13.5	8.1	102.7	3,109,133.9	1,725.5	0.9	0.5
09/29/2014 22:00	10.6	13.8	8.8	85.6	2,448,955.1	1,269.7	1.0	0.5
09/29/2014 23:00	10.6	13.8	8.8	86.6	2,512,604.4	1,302.7	1.0	0.5
Average/Sum#:	10.3	13.5	8.2	105.5	3,168,829.4	1,789.3	1.0	0.6
Minimum:	9.6	13.1	7.7	85.5	2,448,955.1	1,257.8	0.8	0.5
Maximum:	11.0	13.8	9.0	136.2	3,409,126.5	2,179.1	1.2	1.1
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Daily Summary Report

CT2 - NH3 Slip

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:24 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx, Inlet, Ppm 1 Hour(s)	Unit CT2 O2Dry, Inlet, Pct 1 Hour(s)	Unit CT2 NOx, Inlet, Ppmvdc 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 ExhaustFlow, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtuPerHr 1 Hour(s)	Unit CT2 NH3, Slip, Ppmvdc 1 Hour(s)	Unit CT2 NH3slip, LbPerHr 1 Hour(s)
09/30/2014 00:00	10.6	13.8	8.8	85.4	2,426,774.3	1,258.2	1.0	0.5
09/30/2014 01:00	10.6	13.8	8.8	85.5	2,428,703.1	1,259.2	1.0	0.5
09/30/2014 02:00	10.6	13.8	8.8	85.4	2,429,281.7	1,259.5	1.0	0.5
09/30/2014 03:00	10.6	13.8	8.8	85.3	2,430,631.8	1,260.2	1.0	0.5
09/30/2014 04:00	10.5	13.8	8.7	89.3	2,661,698.1	1,380.0	0.9	0.4
09/30/2014 05:00	10.5	13.6	8.5	98.9	3,012,733.6	1,650.0	0.9	0.5
09/30/2014 06:00	10.4	13.5	8.3	109.8	3,376,787.1	1,898.7	0.9	0.6
09/30/2014 07:00	10.3	13.6	8.3	106.5	3,329,479.7	1,872.1	0.9	0.6
09/30/2014 08:00	10.0	13.6	8.1	105.3	3,331,080.4	1,873.0	0.9	0.6
09/30/2014 09:00	10.0	13.5	8.0	105.1	3,325,389.2	1,869.8	0.9	0.6
09/30/2014 10:00	10.4	13.8	8.6	84.0	2,431,789.1	1,260.8	1.0	0.5
09/30/2014 11:00	11.5	13.8	9.6	86.8	2,460,855.6	1,257.9	1.0	0.5
09/30/2014 12:00	10.3	13.7	8.4	99.1	3,068,823.8	1,635.9	0.9	0.5
09/30/2014 13:00	9.8	13.6	7.9	105.1	3,324,144.3	1,869.1	0.9	0.6
09/30/2014 14:00	9.8	13.6	7.9	105.2	3,328,590.5	1,871.6	0.9	0.6
09/30/2014 15:00	9.9	13.5	7.9	105.6	3,336,771.5	1,876.2	0.9	0.6
09/30/2014 16:00	10.2	13.5	8.1	108.0	3,320,678.6	1,891.4	0.9	0.6
09/30/2014 17:00	10.1	13.5	8.1	106.8	3,345,841.7	1,881.3	0.9	0.6
09/30/2014 18:00	10.9	13.3	8.5	121.0	3,359,049.5	2,035.9	1.0	0.8
09/30/2014 19:00	11.2	13.2	8.6	132.3	3,322,034.7	2,110.5	1.2	1.1
09/30/2014 20:00	10.3	13.6	8.3	106.6	3,374,189.6	1,872.6	0.9	0.6
09/30/2014 21:00	10.5	13.7	8.6	91.7	2,797,429.7	1,470.8	0.9	0.4
09/30/2014 22:00	11.5	13.9	9.7	83.0	2,469,659.1	1,262.4	0.9	0.4
09/30/2014 23:00	11.5	13.9	9.7	83.5	2,467,507.1	1,261.3	0.9	0.4
Average/Sum#:	10.5	13.6	8.5	99.0	2,964,996.8	1,630.8	0.9	0.6
Minimum:	9.8	13.2	7.9	83.0	2,426,774.3	1,257.9	0.9	0.4
Maximum:	11.5	13.9	9.7	132.3	3,376,787.1	2,110.5	1.2	1.1
%SI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

ATTACHMENT 9

Quarterly/Annual Emissions (AQ-23, 26)
(Fuel Use, Hours of Operation and NH3 Injection)

Emissions Limits Per AQ-26

Quarterly and Annual Combustion Emissions from CGS Facility					
Pollutant	1st Quarter Emissions (tons)	2nd Quarter Emissions (tons)	3rd Quarter Emissions (tons)	4th Quarter Emissions (tons)	Annual Emissions (tons)
NO_x	45.56	43.58	51.30	44.27	184.7
CO	54.29	52.49	107.15	53.95	267.9
VOC's	12.30	11.63	11.84	11.76	47.5
PM10	25.54	25.78	26.02	26.02	103.4
SO_2	4.07	3.85	3.89	3.89	15.7

Notes

1. Emissions are based on CT1 and CT2.
2. VOC Mass Emissions are based on Average Souce Test Results for lbs/MMBtu. CT1 EF = .0009 Prior to 10/30/2013 and .0007 After 10/30/2013. CT2 EF = .0007 Prior to 11/01/2014 and .0003 after 11/01/2014.
3. PM10 is based on 2010 lb/MMBtu Source Test Results. CT1 EF = .0025; CT2 EF = .003

Quarterly Emissions

Cumulative Emissions Report

From: 01/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/22/2014 13:11 **Location:** Maxwell, CA

Month	PlantWide NOx, Tons 1 Day(s)	PlantWide CO, Tons 1 Day(s)	PlantWide VOC, Tons 1 Day(s)	PlantWide PM10, Tons 1 Day(s)	PlantWide SO2, Tons 1 Day(s)
January	2.0	0.6	0.2	1.2	0.1
February	4.7	1.1	0.6	3.5	0.8
March	2.1	0.7	0.3	1.4	0.3
April	0.1	0.1	0.0	0.0	0.0
May	0.8	0.4	0.0	0.2	0.0
June	2.0	1.1	0.1	0.8	0.2
July	4.3	1.4	0.6	3.2	0.6
August	2.1	0.7	0.3	1.4	0.3
September	4.0	0.6	0.6	3.1	0.7
Quarter 1	8.8	2.4	1.1	6.1	1.2
Quarter 2	2.9	1.6	0.1	1.0	0.2
Quarter 3	10.4	2.7	1.5	7.7	1.6
YTD	22.1	6.7	2.7	14.8	3.0

Monthly Summary by Day (Pounds)

Monthly Summary By Day Report

CT1 and CT2 - Pounds

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:14 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value

Date/Time	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)
07/01/2014	49.7	105.00	25.7	10.8	104.60	25.9
07/02/2014	54.5	105.45	24.9	15.2	118.06	25.0
07/03/2014	77.1	117.78	23.7	56.9	181.39	19.7
07/04/2014	46.6	101.03	22.9	14.9	118.50	23.2
07/05/2014	130.4	169.31	18.5	66.9	165.02	14.6
07/06/2014	108.0	130.69	21.4	59.4	173.53	17.8
07/07/2014	50.8	95.30	25.1	9.0	102.10	25.1
07/08/2014	58.8	112.10	27.4	10.2	117.40	27.7
07/09/2014	48.0	117.30	26.1	7.5	114.10	26.4
07/10/2014	47.7	92.60	22.8	11.4	95.30	23.0
07/11/2014	83.9	70.05	15.4	118.1	164.44	11.3
07/12/2014	71.8	132.82	13.9	98.2	180.20	17.8
07/13/2014	97.8	129.50	19.1	74.5	184.89	15.7
07/14/2014	41.1	105.30	25.2	3.0	142.60	25.4
07/15/2014	55.3	134.70	26.7	0.0	176.60	26.9
07/16/2014	42.2	125.10	24.9	0.0	152.90	24.9
07/17/2014	74.3	143.47	16.0	53.3	172.16	19.9
07/18/2014	71.6	140.43	16.9	42.8	147.00	21.6
07/19/2014	92.0	165.51	20.7	45.8	208.09	16.7
07/20/2014	6.5	1.58	0.1	5.7	2.62	0.1
07/21/2014	148.3	214.54	20.3	145.7	289.72	25.1
07/22/2014	52.3	132.10	27.7	0.0	187.40	28.0
07/23/2014	45.8	92.80	25.2	0.0	163.50	25.8
07/24/2014	42.1	120.50	25.6	0.0	169.60	26.7
07/25/2014	58.2	147.40	28.5	0.0	192.70	29.2
07/26/2014	41.9	121.70	25.1	0.0	165.20	25.4
07/27/2014	55.2	118.90	25.4	0.0	162.10	25.7
07/28/2014	59.0	134.60	27.4	0.0	185.20	28.1
07/29/2014	50.9	127.90	27.0	0.0	176.90	27.3
07/30/2014	55.9	136.20	28.1	0.0	184.40	28.2
07/31/2014	60.9	138.20	27.5	0.0	183.20	27.7
Monthly Avg/Sum*:	1,978.6 *	3,779.86 *	705.2 *	849.3 *	4,881.42 *	705.9 *
Daily Min:	6.5	1.58	0.1	0.0	2.62	0.1
Daily Max:	148.3	214.54	28.5	145.7	289.72	29.2
Jul 14 - Jul 14	1,978.6	3,779.86	705.2	849.3	4,881.42	705.9
QTD:	1,978.6 *	3,779.86 *	705.2 *	849.3 *	4,881.42 *	705.9 *
YTD 14:	7,396.4 *	14,318.24 *	2,251.4 *	3,397.2 *	17,856.35 *	2,247.4 *

Monthly Summary By Day Report

CT1 and CT2 - Pounds

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:14 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value

Date/Time	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)
08/01/2014	70.7	150.60	28.0	0.0	187.20	28.5
08/02/2014	64.2	122.00	24.9	0.0	163.30	25.3
08/03/2014	66.4	141.40	26.7	0.0	176.70	27.1
08/04/2014	52.4	162.00	25.7	0.0	168.10	26.0
08/05/2014	57.8	142.30	26.0	0.0	166.10	26.4
08/06/2014	76.5	131.37	26.8	0.0	185.60	28.2
08/07/2014	364.5	124.51	10.6	77.1	183.55	17.4
08/08/2014	63.4	133.80	28.2	0.0	192.40	28.8
08/09/2014	74.1	138.71	16.6	42.6	174.70	20.7
08/10/2014	98.3	150.29	14.4	57.2	192.47	18.6
08/11/2014	61.8	167.40	29.5	0.0	198.50	30.0
08/12/2014	9.3	115.20	24.3	0.0	159.00	24.2
08/13/2014	56.6	126.63	16.2	34.4	162.18	19.7
08/14/2014	0.0	0.00	0.0	0.0	0.00	0.0
08/15/2014	0.0	0.00	0.0	0.0	0.00	0.0
08/16/2014	0.0	0.00	0.0	0.0	0.00	0.0
08/17/2014	0.0	0.00	0.0	0.0	0.00	0.0
08/18/2014	0.0	0.00	0.0	0.0	0.00	0.0
08/19/2014	0.0	0.00	0.0	0.0	0.00	0.0
08/20/2014	0.0	0.00	0.0	0.0	0.00	0.0
08/21/2014	0.0	0.00	0.0	0.0	0.00	0.0
08/22/2014	0.0	0.00	0.0	0.0	0.00	0.0
08/23/2014	0.0	0.00	0.0	0.0	0.00	0.0
08/24/2014	0.0	0.00	0.0	0.0	0.00	0.0
08/25/2014	0.0	0.00	0.0	0.0	0.00	0.0
08/26/2014	0.0	0.00	0.0	0.0	0.00	0.0
08/27/2014	0.0	0.00	0.0	0.0	0.00	0.0
08/28/2014	0.0	0.00	0.0	0.0	0.00	0.0
08/29/2014	0.0	0.00	0.0	0.0	0.00	0.0
08/30/2014	0.0	0.00	0.0	0.0	0.00	0.0
08/31/2014	0.0	0.00	0.0	0.0	0.00	0.0
Monthly Avg/Sum*:	1,116.0 *	1,806.21 *	297.9 *	211.3 *	2,309.80 *	320.9 *
Daily Min:	9.3	115.20	10.6	0.0	159.00	17.4
Daily Max:	364.5	167.40	29.5	77.1	198.50	30.0
Jul 14 - Aug 14	3,094.6	5,586.07	1,003.1	1,060.6	7,191.22	1,026.8
QTD:	3,094.6 *	5,586.07 *	1,003.1 *	1,060.6 *	7,191.22 *	1,026.8 *
YTD 14:	8,512.4 *	16,124.45 *	2,549.3 *	3,608.5 *	20,166.15 *	2,568.3 *

Monthly Summary By Day Report

CT1 and CT2 - Pounds

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:14 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value

Date/Time	Unit CT1 CO, Lb 1 Hour(s)	Unit CT1 NOx, Lb 1 Hour(s)	Unit CT1 SO2, Lb 1 Hour(s)	Unit CT2 CO, Lb 1 Hour(s)	Unit CT2 NOx, Lb 1 Hour(s)	Unit CT2 SO2, Lb 1 Hour(s)
09/01/2014	0.0	0.00	0.0	0.0	0.00	0.0
09/02/2014	0.0	0.00	0.0	0.0	0.00	0.0
09/03/2014	0.0	0.00	0.0	0.0	0.00	0.0
09/04/2014	0.0	0.00	0.0	0.0	0.00	0.0
09/05/2014	116.5	228.64	17.1	252.8	419.60	22.5
09/06/2014	0.0	146.60	27.9	38.4	190.00	28.2
09/07/2014	0.0	146.70	28.0	37.7	187.90	28.4
09/08/2014	0.0	112.80	24.1	24.6	154.60	24.3
09/09/2014	0.0	109.00	23.9	22.5	144.70	24.2
09/10/2014	0.0	152.40	27.9	29.9	181.80	28.4
09/11/2014	0.0	154.90	28.7	39.3	195.10	29.2
09/12/2014	0.0	191.20	30.6	26.8	206.20	30.9
09/13/2014	0.0	131.60	26.4	33.4	176.80	26.7
09/14/2014	0.0	146.90	27.1	31.5	182.50	27.8
09/15/2014	0.0	141.90	27.1	32.7	183.20	27.6
09/16/2014	0.0	156.10	28.1	29.3	188.50	28.1
09/17/2014	0.0	165.70	29.9	34.6	196.00	30.0
09/18/2014	0.0	100.30	23.7	21.7	122.00	24.0
09/19/2014	0.0	126.70	26.0	27.0	157.70	26.5
09/20/2014	0.0	138.40	27.7	34.9	171.80	27.8
09/21/2014	0.0	109.50	24.0	28.1	137.20	24.1
09/22/2014	3.3	88.90	22.5	20.5	121.50	22.6
09/23/2014	6.3	114.50	23.6	18.1	105.10	23.6
09/24/2014	2.7	113.50	25.4	15.3	115.20	25.2
09/25/2014	19.1	106.40	27.3	21.5	142.80	27.8
09/26/2014	36.1	134.70	27.9	27.9	186.40	28.4
09/27/2014	25.1	105.40	24.2	19.4	143.80	24.6
09/28/2014	30.4	122.90	25.7	25.0	154.90	26.0
09/29/2014	39.2	118.90	25.6	28.3	150.10	25.7
09/30/2014	22.6	105.10	23.5	21.5	130.70	23.6
Monthly Avg/Sum*:	301.3 *	3,469.64 *	673.9 *	942.7 *	4,446.10 *	686.2 *
Daily Min:	0.0	88.90	17.1	15.3	105.10	22.5
Daily Max:	116.5	228.64	30.6	252.8	419.60	30.9
Jul 14 - Sep 14	3,395.9	9,055.71	1,677.0	2,003.3	11,637.32	1,713.0
QTD:	3,395.9 *	9,055.71 *	1,677.0 *	2,003.3 *	11,637.32 *	1,713.0 *
YTD 14:	8,813.7 *	19,594.09 *	3,223.2 *	4,551.2 *	24,612.25 *	3,254.5 *

Monthly Summary By Day Report

VOC PM10

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:14 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value

Date/Time	Unit CT1 VOC, Lb 1 Day(s)	Unit CT1 PM10, Lb 1 Day(s)	Unit CT2 VOC, Lb 1 Day(s)	Unit CT2 PM10, Lb 1 Day(s)
07/01/2014	30.3	108.4	13.7	131.5
07/02/2014	29.3	104.6	13.0	126.8
07/03/2014	27.7	99.1	9.8	98.6
07/04/2014	26.5	94.7	11.9	116.3
07/05/2014	21.1	75.9	7.5	72.4
07/06/2014	25.1	90.1	8.9	89.2
07/07/2014	29.5	105.2	13.4	127.5
07/08/2014	31.9	114.4	14.0	139.2
07/09/2014	30.7	108.6	13.2	131.2
07/10/2014	27.4	96.7	12.4	117.1
07/11/2014	17.3	61.8	5.7	53.8
07/12/2014	15.9	57.2	9.0	88.9
07/13/2014	22.4	79.9	7.7	78.6
07/14/2014	29.5	105.6	12.8	127.2
07/15/2014	31.1	112.2	14.0	135.3
07/16/2014	29.2	104.5	13.0	125.1
07/17/2014	18.7	66.4	10.3	99.5
07/18/2014	19.9	70.5	11.0	107.4
07/19/2014	24.0	85.9	8.4	84.0
07/20/2014	0.1	0.3	0.0	0.4
07/21/2014	23.7	84.7	12.7	124.1
07/22/2014	32.5	116.2	14.3	140.8
07/23/2014	29.7	106.1	13.3	128.5
07/24/2014	30.5	108.3	13.2	132.4
07/25/2014	33.3	119.6	14.9	145.9
07/26/2014	29.6	104.7	13.2	127.7
07/27/2014	29.7	105.7	12.9	128.5
07/28/2014	32.2	115.2	14.2	139.8
07/29/2014	31.6	112.8	14.0	136.8
07/30/2014	33.0	117.0	14.5	142.1
07/31/2014	32.1	114.9	14.4	139.9

Monthly Avg/Sum*:	825.5 *	2,947.2 *	361.3 *	3,536.5 *
Daily Min:	0.1	0.3	0.0	0.4
Daily Max:	33.3	119.6	14.9	145.9
Jul 14 - Jul 14	825.5	2,947.2	361.3	3,536.5

QTD:	825.5 *	2,947.2 *	361.3 *	3,536.5 *
YTD 14:	2,635.2 *	9,394.1 *	1,142.7 *	11,259.0 *

Monthly Summary By Day Report

VOC PM10

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:14 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value

Date/Time	Unit CT1 VOC, Lb 1 Day(s)	Unit CT1 PM10, Lb 1 Day(s)	Unit CT2 VOC, Lb 1 Day(s)	Unit CT2 PM10, Lb 1 Day(s)
08/01/2014	32.6	116.8	14.3	142.3
08/02/2014	29.1	104.3	13.2	126.2
08/03/2014	31.1	111.1	13.7	134.8
08/04/2014	30.0	107.4	13.4	129.9
08/05/2014	30.2	107.8	13.5	130.9
08/06/2014	31.3	111.4	14.1	140.8
08/07/2014	12.5	44.3	8.8	88.4
08/08/2014	33.1	118.0	14.6	144.1
08/09/2014	19.6	70.2	10.5	104.3
08/10/2014	16.8	60.3	9.5	92.2
08/11/2014	34.5	123.2	15.5	150.4
08/12/2014	28.1	101.6	11.9	121.7
08/13/2014	18.8	67.7	9.5	99.2
08/14/2014	0.0	0.0	0.0	0.0
08/15/2014	0.0	0.0	0.0	0.0
08/16/2014	0.0	0.0	0.0	0.0
08/17/2014	0.0	0.0	0.0	0.0
08/18/2014	0.0	0.0	0.0	0.0
08/19/2014	0.0	0.0	0.0	0.0
08/20/2014	0.0	0.0	0.0	0.0
08/21/2014	0.0	0.0	0.0	0.0
08/22/2014	0.0	0.0	0.0	0.0
08/23/2014	0.0	0.0	0.0	0.0
08/24/2014	0.0	0.0	0.0	0.0
08/25/2014	0.0	0.0	0.0	0.0
08/26/2014	0.0	0.0	0.0	0.0
08/27/2014	0.0	0.0	0.0	0.0
08/28/2014	0.0	0.0	0.0	0.0
08/29/2014	0.0	0.0	0.0	0.0
08/30/2014	0.0	0.0	0.0	0.0
08/31/2014	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	347.7 *	1,244.1 *	162.5 *	1,605.2 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	34.5	123.2	15.5	150.4
Jul 14 - Aug 14	1,173.2	4,191.3	523.8	5,141.7
QTD:	1,173.2 *	4,191.3 *	523.8 *	5,141.7 *
YTD 14:	2,982.9 *	10,638.2 *	1,305.2 *	12,864.2 *

Monthly Summary By Day Report

VOC PM10

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:14 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value

Date/Time	Unit CT1 VOC, Lb 1 Day(s)	Unit CT1 PM10, Lb 1 Day(s)	Unit CT2 VOC, Lb 1 Day(s)	Unit CT2 PM10, Lb 1 Day(s)
09/01/2014	0.0	0.0	0.0	0.0
09/02/2014	0.0	0.0	0.0	0.0
09/03/2014	0.0	0.0	0.0	0.0
09/04/2014	0.0	0.0	0.0	0.0
09/05/2014	19.8	71.3	11.3	111.2
09/06/2014	32.7	117.1	14.7	142.6
09/07/2014	32.7	117.1	14.7	142.6
09/08/2014	28.2	99.8	12.5	120.7
09/09/2014	27.9	99.5	12.7	121.0
09/10/2014	32.6	116.3	14.5	142.1
09/11/2014	33.6	120.0	14.9	146.2
09/12/2014	35.7	128.3	16.1	156.2
09/13/2014	30.8	109.1	13.2	132.5
09/14/2014	31.4	112.5	14.1	137.7
09/15/2014	31.8	113.5	14.1	138.9
09/16/2014	32.6	116.4	14.6	142.2
09/17/2014	34.7	123.8	15.5	151.3
09/18/2014	27.5	98.1	12.0	118.6
09/19/2014	30.4	108.3	13.6	132.1
09/20/2014	32.2	115.2	14.5	140.2
09/21/2014	28.4	100.4	12.9	121.5
09/22/2014	26.9	95.6	11.5	115.1
09/23/2014	27.3	98.6	11.6	118.4
09/24/2014	28.7	105.1	12.0	125.3
09/25/2014	31.1	112.8	13.3	136.8
09/26/2014	32.5	117.1	14.7	142.4
09/27/2014	28.0	99.8	12.5	121.4
09/28/2014	30.2	106.8	13.4	129.6
09/29/2014	29.9	106.1	13.5	128.7
09/30/2014	27.4	96.6	12.2	117.4
Monthly Avg/Sum*:	785.0 *	2,805.2 *	350.6 *	3,432.7 *
Daily Min:	0.0	0.0	0.0	0.0
Daily Max:	35.7	128.3	16.1	156.2
Jul 14 - Sep 14	1,958.2	6,996.5	874.4	8,574.4
QTD:	1,958.2 *	6,996.5 *	874.4 *	8,574.4 *
YTD 14:	3,767.9 *	13,443.4 *	1,655.8 *	16,296.9 *

Annual Fuel Use, NH3 Injection and Operating Hours

Cumulative Emissions Report

CT1

From: 01/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:11 **Location:** Maxwell, CA

Month	Unit CT1 GasFlowCT, 100scf 1 Day(s)	Unit CT1 GasFlowDB, 100scf 1 Day(s)	Unit CT1 GasFlow, Total, 100scf 1 Hour(s)	Unit CT1 UnitOn, TF 1 Hour(s)	Unit CT1 UnitOn, TF 1 Day(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)
January	3,892,677	349,668	4,242,342.8	237	11	30,633.2
February	11,287,989	1,230,260	12,518,249.5	663	28	87,147.8
March	4,433,117	385,804	4,818,918.3	278	13	34,763.4
April	0	0	0.0	0	0	0.0
May	682,790	0	682,789.5	53	5	6,958.3
June	2,691,325	173,665	2,864,989.3	196	13	26,077.8
July	10,439,393	991,268	11,430,656.4	665	31	83,112.4
August	4,422,921	409,478	4,832,396.1	276	13	33,363.1
September	9,945,993	901,499	10,847,488.9	617	26	76,638.2
Quarter 1	19,613,783	1,965,732	21,579,510.6	1,178	52	152,544.4
Quarter 2	3,374,115	173,665	3,547,778.8	249	18	33,036.1
Quarter 3	24,808,307	2,302,245	27,110,541.4	1,558	70	193,113.7
YTD	47,796,205	4,441,642	52,237,830.8	2,985	140	378,694.2

Cumulative Emissions Report

CT2

From: 01/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:11 **Location:** Maxwell, CA

Month	Unit CT2 GasFlowCT, 100scf 1 Day(s)	Unit CT2 GasFlowDB, 100scf 1 Day(s)	Unit CT2 GasFlow, Total, 100scf 1 Hour(s)	Unit CT2 UnitOn, TF 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)
January	4,010,781	415,075	4,425,855.7	246	30,683.5
February	11,244,892	1,408,066	12,652,950.9	658	81,199.0
March	4,631,059	439,442	5,070,498.8	289	33,497.1
April	35,480	0	35,480.1	7	1,053.4
May	408,886	0	408,885.8	30	3,344.4
June	2,377,496	122,780	2,500,274.8	172	19,119.4
July	10,310,983	1,115,847	11,426,823.9	659	73,283.3
August	4,716,764	476,805	5,193,566.6	294	33,690.4
September	10,001,909	1,054,775	11,056,679.7	624	70,609.4
Quarter 1	19,886,732	2,262,583	22,149,305.4	1,193	145,379.6
Quarter 2	2,821,862	122,780	2,944,640.7	209	23,517.2
Quarter 3	25,029,656	2,647,427	27,677,070.2	1,577	177,583.1
YTD	47,738,250	5,032,790	52,771,016.3	2,979	346,479.9

Monthly Summary By Day Report

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/22/2014 13:17 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value

Date/Time	Unit CT1 OperatingTime, Hr 1 Hour(s)	Unit CT1 GasFlowCT, 100scf 1 Hour(s)	Unit CT1 DBOn, Hr 1 Hour(s)	Unit CT1 GasFlowDB, 100scf 1 Hour(s)	Unit CT1 GasFlow, Total, 100scf 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtu 1 Hour(s)
07/01/2014	24.00	388,088.8	20.14	31,809.7	419,898.5	2,846.0	43,404.800
07/02/2014	22.17	368,232.7	21.07	36,055.5	404,288.2	3,006.2	41,791.237
07/03/2014	20.67	338,264.9	15.03	45,486.0	383,750.9	2,951.8	39,668.328
07/04/2014	20.17	332,521.1	18.22	33,779.2	366,300.3	2,746.1	37,864.401
07/05/2014	17.87	276,718.8	10.17	17,295.9	294,014.7	2,312.6	30,392.456
07/06/2014	20.70	326,165.3	12.65	23,375.7	349,541.0	2,971.1	36,131.975
07/07/2014	24.00	384,482.1	19.52	23,185.1	407,667.2	2,764.9	42,140.500
07/08/2014	24.00	397,491.3	21.93	45,622.6	443,113.9	3,021.3	45,804.800
07/09/2014	24.00	374,754.5	16.58	45,158.1	419,912.6	2,937.0	43,406.600
07/10/2014	24.00	356,061.0	14.00	18,848.1	374,909.1	2,599.8	38,754.400
07/11/2014	19.87	238,557.3	0.00	0.0	238,557.3	2,486.7	24,659.787
07/12/2014	13.09	204,051.5	9.50	17,157.5	221,209.0	1,883.1	22,866.206
07/13/2014	18.72	284,721.3	10.56	24,610.0	309,331.3	2,666.3	31,975.308
07/14/2014	24.00	381,276.5	12.34	27,132.7	408,409.2	2,835.3	42,217.200
07/15/2014	24.00	407,343.9	20.50	27,332.5	434,676.4	2,880.1	44,932.400
07/16/2014	24.00	389,817.2	15.92	15,778.7	405,595.9	2,716.7	41,768.100
07/17/2014	15.59	242,943.4	11.94	15,100.9	258,044.3	2,096.4	26,573.073
07/18/2014	16.09	252,996.7	12.93	21,702.2	274,698.9	2,234.2	28,288.200
07/19/2014	18.75	293,190.2	11.08	40,301.4	333,491.6	2,729.6	34,342.745
07/20/2014	0.22	1,183.9	0.00	0.0	1,183.9	244.3	121.924
07/21/2014	17.70	287,790.1	16.02	41,560.8	329,350.9	2,389.9	33,916.490
07/22/2014	24.00	405,050.0	23.27	46,257.3	451,307.3	3,040.6	46,475.000
07/23/2014	24.00	383,832.2	18.32	28,460.8	412,293.0	2,864.0	42,457.800
07/24/2014	24.00	378,884.1	17.12	41,748.7	420,632.8	2,983.6	43,316.400
07/25/2014	24.00	406,067.9	24.00	57,800.7	463,868.6	3,188.3	47,768.700
07/26/2014	24.00	377,949.7	17.59	28,931.6	406,881.3	2,797.2	41,900.000
07/27/2014	24.00	377,031.7	15.93	33,638.3	410,670.0	2,863.4	42,290.400
07/28/2014	24.00	397,120.2	22.26	49,794.7	446,914.9	3,066.8	46,022.700
07/29/2014	24.00	390,031.4	20.18	48,026.6	438,058.0	3,029.0	45,110.600
07/30/2014	24.00	397,774.3	22.53	57,890.6	455,664.9	3,053.2	46,923.600
07/31/2014	24.00	398,998.7	21.33	47,421.8	446,420.5	2,906.9	45,972.000
Monthly Avg/Sum*:	653.61 *	10,439,392.7 *	492.63 *	991,263.7 *	11,430,656.4 *	83,112.4 *	1,179,258.130 *
Daily Min:	0.22	1,183.9	0.00	0.0	1,183.9	244.3	121.924
Daily Max:	24.00	407,343.9	24.00	57,890.6	463,868.6	3,188.3	47,768.700
Jul 14 - Jul 14	653.61	10,439,392.7	492.63	991,263.7	11,430,656.4	83,112.4	1,179,258.130
QTD:	653.61 *	10,439,392.7 *	492.63 *	991,263.7 *	11,430,656.4 *	83,112.4 *	1,179,258.130 *
YTD 14:	2,056.85 *	33,427,289.0 *	1,558.40 *	3,130,656.7 *	36,557,945.8 *	268,692.9 *	3,757,571.021 *

Monthly Summary By Day Report

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/22/2014 13:17 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value

Date/Time	Unit CT1 OperatingTime, Hr 1 Hour(s)	Unit CT1 GasFlowCT, 100scf 1 Hour(s)	Unit CT1 DBOn, Hr 1 Hour(s)	Unit CT1 GasFlowDB, 100scf 1 Hour(s)	Unit CT1 GasFlow, Total, 100scf 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtu 1 Hour(s)
08/01/2014	24.00	399,393.0	22.52	54,708.0	454,101.0	2,889.1	46,762.600
08/02/2014	24.00	377,629.1	17.50	27,000.8	404,629.9	2,611.3	41,668.200
08/03/2014	24.00	397,199.7	19.05	33,745.3	430,945.0	2,643.4	44,378.400
08/04/2014	24.00	396,736.6	16.92	19,682.1	416,418.7	2,441.3	42,882.100
08/05/2014	24.00	391,739.1	19.64	27,751.5	419,490.6	2,492.6	43,198.700
08/06/2014	23.17	386,537.8	22.25	46,627.8	433,165.6	2,982.8	44,606.857
08/07/2014	10.35	155,238.3	8.58	16,839.7	172,078.0	1,318.7	17,720.644
08/08/2014	24.00	403,613.7	24.00	54,509.2	458,122.9	3,133.7	47,177.000
08/09/2014	15.90	248,364.3	10.85	24,200.6	272,564.9	2,323.2	28,068.600
08/10/2014	12.94	203,679.5	11.18	30,318.1	233,997.6	1,984.1	24,096.884
08/11/2014	24.00	404,516.7	21.87	74,093.7	478,610.4	3,383.2	49,286.700
08/12/2014	24.00	395,252.8	0.00	0.0	395,252.8	2,811.8	40,703.000
08/13/2014	16.68	263,018.7	0.00	0.0	263,018.7	2,347.9	27,085.292
08/14/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/15/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/16/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/17/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/18/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/19/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/20/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/21/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/22/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/23/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/24/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/25/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/26/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/27/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/28/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/29/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/30/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/31/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
Monthly Avg/Sum*:	271.04 *	4,422,919.3 *	194.36 *	409,476.8 *	4,832,396.1 *	33,363.1 *	497,634.977 *
Daily Min:	10.35	155,238.3	0.00	0.0	172,078.0	1,318.7	17,720.644
Daily Max:	24.00	404,516.7	24.00	74,093.7	478,610.4	3,383.2	49,286.700
Jul 14 - Aug 14	924.65	14,862,312.0	686.99	1,400,740.5	16,263,052.5	116,475.5	1,676,893.107
QTD:	924.65 *	14,862,312.0 *	686.99 *	1,400,740.5 *	16,263,052.5 *	116,475.5 *	1,676,893.107 *
YTD 14:	2,327.89 *	37,850,208.3 *	1,752.76 *	3,540,133.5 *	41,390,341.9 *	302,056.0 *	4,255,205.998 *

Monthly Summary By Day Report

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/22/2014 13:17 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value

Date/Time	Unit CT1 OperatingTime, Hr 1 Hour(s)	Unit CT1 GasFlowCT, 100scf 1 Hour(s)	Unit CT1 DBOn, Hr 1 Hour(s)	Unit CT1 GasFlowDB, 100scf 1 Hour(s)	Unit CT1 GasFlow, Total, 100scf 1 Hour(s)	Unit CT1 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT1 HI, MBtu 1 Hour(s)
09/01/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
09/02/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
09/03/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
09/04/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
09/05/2014	16.72	253,046.8	11.33	23,810.1	276,856.9	2,095.0	28,510.412
09/06/2014	24.00	406,882.7	24.00	47,232.7	454,115.4	3,108.1	46,764.100
09/07/2014	24.00	405,012.9	24.00	49,287.4	454,300.3	3,143.1	46,783.300
09/08/2014	24.00	366,687.4	12.82	19,191.1	385,878.5	2,763.2	39,949.600
09/09/2014	24.00	360,041.4	15.23	24,480.6	384,522.0	2,749.4	39,809.100
09/10/2014	24.00	394,629.0	21.84	54,792.8	449,421.8	3,207.9	46,528.000
09/11/2014	24.00	406,066.2	24.00	57,407.0	463,473.2	3,242.0	47,982.800
09/12/2014	24.00	405,776.5	24.00	89,891.5	495,668.0	3,640.0	51,316.000
09/13/2014	24.00	381,310.3	17.64	39,585.0	420,895.3	2,973.9	43,574.800
09/14/2014	24.00	383,926.1	19.23	50,703.6	434,629.7	3,081.0	44,996.500
09/15/2014	24.00	393,197.4	21.55	44,943.8	438,141.2	3,050.9	45,360.200
09/16/2014	24.00	400,512.3	20.56	50,159.9	450,672.2	3,158.9	46,657.500
09/17/2014	24.00	409,505.7	24.00	69,016.6	478,522.3	3,353.5	49,541.000
09/18/2014	24.00	364,522.6	8.45	14,340.8	378,863.4	2,721.4	39,223.000
09/19/2014	24.00	378,756.5	18.50	39,948.7	418,705.2	2,949.1	43,348.100
09/20/2014	24.00	403,864.9	24.00	42,025.5	445,890.4	3,030.3	46,162.500
09/21/2014	24.00	368,815.3	16.77	18,742.2	387,557.5	2,693.8	40,123.400
09/22/2014	24.00	364,951.4	3.58	5,158.1	370,109.5	2,831.2	38,317.000
09/23/2014	24.00	380,825.2	0.00	0.0	380,825.2	2,796.1	39,426.200
09/24/2014	24.00	405,327.8	0.00	0.0	405,327.8	2,876.5	41,963.200
09/25/2014	24.00	411,021.2	11.00	25,581.8	436,603.0	3,048.2	45,200.900
09/26/2014	24.00	411,403.3	24.00	40,755.1	452,158.4	3,059.3	46,811.300
09/27/2014	24.00	363,800.3	13.94	22,292.7	386,093.0	2,764.9	39,971.800
09/28/2014	24.00	382,666.0	17.29	30,093.8	412,759.8	2,886.9	42,732.400
09/29/2014	24.00	385,143.5	19.11	25,360.1	410,503.6	2,788.2	42,499.000
09/30/2014	24.00	358,300.7	13.24	16,694.6	374,995.3	2,625.4	38,822.800
Monthly Avg/Sum*:	616.72 *	9,945,993.4 *	430.08 *	901,495.5 *	10,847,488.9 *	76,638.2 *	1,122,374.912 *
Daily Min:	16.72	253,046.8	0.00	0.0	276,856.9	2,095.0	28,510.412
Daily Max:	24.00	411,403.3	24.00	89,891.5	495,668.0	3,640.0	51,316.000
Jul 14 - Sep 14	1,541.37	24,808,305.4	1,117.07	2,302,236.0	27,110,541.4	193,113.7	2,799,268.019
QTD:	1,541.37 *	24,808,305.4 *	1,117.07 *	2,302,236.0 *	27,110,541.4 *	193,113.7 *	2,799,268.019 *
YTD 14:	2,944.61 *	47,796,201.7 *	2,182.84 *	4,441,629.0 *	52,237,830.8 *	378,694.2 *	5,377,580.910 *

Monthly Summary By Day Report

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/22/2014 13:16 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value

Date/Time	Unit CT2 OperatingTime, Hr 1 Hour(s)	Unit CT2 GasFlowCT, 100scf 1 Hour(s)	Unit CT2 DBOn, Hr 1 Hour(s)	Unit CT2 GasFlowDB, 100scf 1 Hour(s)	Unit CT2 GasFlow, Total, 100scf 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtu 1 Hour(s)
07/01/2014	24.00	387,363.0	20.16	36,522.5	423,885.5	2,501.7	43,817.000
07/02/2014	22.18	367,108.5	21.07	41,675.9	408,784.4	2,626.0	42,256.266
07/03/2014	16.70	269,964.4	14.98	47,924.1	317,888.5	2,046.6	32,860.140
07/04/2014	20.53	336,199.0	18.22	38,243.8	374,442.8	2,303.2	38,706.243
07/05/2014	13.53	214,377.7	10.08	19,295.0	233,672.7	1,471.9	24,154.826
07/06/2014	16.50	260,937.8	12.59	26,123.1	287,060.9	2,037.9	29,673.501
07/07/2014	24.00	384,277.6	18.99	26,569.6	410,847.2	2,409.8	42,469.200
07/08/2014	24.00	395,814.7	21.98	51,809.5	447,624.2	2,641.9	46,270.700
07/09/2014	24.00	374,707.7	16.51	48,486.8	423,194.5	2,594.6	43,745.600
07/10/2014	24.00	356,328.3	13.98	21,952.0	378,280.3	2,274.0	39,103.000
07/11/2014	15.00	174,589.2	0.00	0.0	174,589.2	1,685.5	18,047.290
07/12/2014	17.75	266,073.6	9.45	20,257.0	286,330.6	2,157.4	29,598.018
07/13/2014	14.65	225,537.6	10.53	27,793.6	253,331.2	1,840.6	26,186.767
07/14/2014	24.00	381,926.1	12.02	28,987.0	410,913.1	2,485.9	42,476.200
07/15/2014	24.00	404,707.6	20.45	31,345.4	436,053.0	2,570.7	45,074.500
07/16/2014	24.00	388,283.0	15.77	17,268.4	405,551.4	2,422.7	41,763.300
07/17/2014	19.93	305,639.6	11.87	17,145.8	322,785.4	2,414.2	33,240.310
07/18/2014	20.93	323,892.3	12.85	23,999.1	347,891.4	2,586.0	35,825.472
07/19/2014	14.70	229,707.8	11.03	42,190.9	271,898.7	1,981.0	28,000.024
07/20/2014	0.23	1,344.6	0.00	0.0	1,344.6	200.0	138.460
07/21/2014	22.70	355,130.4	15.98	46,655.2	401,785.6	2,832.6	41,375.570
07/22/2014	24.00	402,714.1	23.28	52,582.9	455,297.0	2,745.1	46,885.900
07/23/2014	24.00	381,971.3	18.02	33,915.0	415,886.3	2,550.4	42,827.700
07/24/2014	24.00	379,567.7	16.74	47,357.6	426,925.3	2,710.3	43,964.300
07/25/2014	24.00	406,264.6	24.00	66,233.6	472,498.2	2,992.9	48,657.500
07/26/2014	24.00	378,914.0	17.63	33,775.0	412,689.0	2,542.9	42,498.000
07/27/2014	24.00	377,808.6	15.89	39,039.5	416,848.1	2,599.2	42,926.400
07/28/2014	24.00	395,825.9	22.16	56,993.6	452,819.5	2,747.4	46,631.000
07/29/2014	24.00	388,497.1	20.17	54,358.8	442,855.9	2,758.3	45,604.800
07/30/2014	24.00	396,721.4	22.53	62,860.3	459,581.7	2,814.5	47,327.300
07/31/2014	24.00	398,784.5	22.02	54,483.2	453,267.7	2,738.1	46,677.100
Monthly Avg/Sum*:	647.33 *	10,310,979.7 *	490.95 *	1,115,844.2 *	11,426,823.9 *	73,283.3 *	1,178,782.387 *
Daily Min:	0.23	1,344.6	0.00	0.0	1,344.6	200.0	138.460
Daily Max:	24.00	406,264.6	24.00	66,233.6	472,498.2	2,992.9	48,657.500
Jul 14 - Jul 14	647.33	10,310,979.7	490.95	1,115,844.2	11,426,823.9	73,283.3	1,178,782.387
QTD:	647.33 *	10,310,979.7 *	490.95 *	1,115,844.2 *	11,426,823.9 *	73,283.3 *	1,178,782.387 *
YTD 14:	2,023.64 *	33,019,567.4 *	1,494.57 *	3,501,202.7 *	36,520,770.0 *	242,180.1 *	3,753,161.653 *

Monthly Summary By Day Report

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/22/2014 13:16 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value

Date/Time	Unit CT2 OperatingTime, Hr 1 Hour(s)	Unit CT2 GasFlowCT, 100scf 1 Hour(s)	Unit CT2 DBOn, Hr 1 Hour(s)	Unit CT2 GasFlowDB, 100scf 1 Hour(s)	Unit CT2 GasFlow, Total, 100scf 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtu 1 Hour(s)
08/01/2014	24.00	399,145.8	22.50	60,622.5	459,768.3	2,819.3	47,346.400
08/02/2014	24.00	378,097.7	17.50	30,979.7	409,077.4	2,537.4	42,126.500
08/03/2014	24.00	396,042.3	19.03	40,125.1	436,167.4	2,676.0	44,916.000
08/04/2014	24.00	394,952.7	16.89	24,527.7	419,480.4	2,520.6	43,197.600
08/05/2014	24.00	389,561.9	19.61	34,059.0	423,620.9	2,509.3	43,624.100
08/06/2014	24.00	399,761.5	22.25	55,154.1	454,915.6	2,708.3	46,846.700
08/07/2014	17.60	266,601.9	8.57	19,964.1	286,566.0	2,010.3	29,510.116
08/08/2014	24.00	402,410.1	24.00	64,376.0	466,786.1	2,866.7	48,069.300
08/09/2014	19.95	309,054.2	10.85	28,433.6	337,487.8	2,555.1	34,754.205
08/10/2014	17.00	263,047.6	11.07	35,055.2	298,102.8	2,285.5	30,698.162
08/11/2014	24.00	403,295.2	21.87	83,506.6	486,801.8	3,331.1	50,130.500
08/12/2014	24.00	393,879.3	0.00	0.0	393,879.3	2,481.5	40,561.200
08/13/2014	19.64	320,912.8	0.00	0.0	320,912.8	2,389.3	33,047.303
08/14/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/15/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/16/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/17/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/18/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/19/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/20/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/21/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/22/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/23/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/24/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/25/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/26/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/27/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/28/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/29/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/30/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
08/31/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
Monthly Avg/Sum*:	290.19 *	4,716,763.0 *	194.14 *	476,803.6 *	5,193,566.6 *	33,690.4 *	534,828.086 *
Daily Min:	17.00	263,047.6	0.00	0.0	286,566.0	2,010.3	29,510.116
Daily Max:	24.00	403,295.2	24.00	83,506.6	486,801.8	3,331.1	50,130.500
Jul 14 - Aug 14	937.52	15,027,742.7	685.09	1,592,647.8	16,620,390.5	106,973.7	1,713,610.473
QTD:	937.52 *	15,027,742.7 *	685.09 *	1,592,647.8 *	16,620,390.5 *	106,973.7 *	1,713,610.473 *
YTD 14:	2,313.83 *	37,736,330.4 *	1,688.71 *	3,978,006.3 *	41,714,336.6 *	275,870.5 *	4,287,989.739 *

Monthly Summary By Day Report

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/22/2014 13:16 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value

Date/Time	Unit CT2 OperatingTime, Hr 1 Hour(s)	Unit CT2 GasFlowCT, 100scf 1 Hour(s)	Unit CT2 DBOn, Hr 1 Hour(s)	Unit CT2 GasFlowDB, 100scf 1 Hour(s)	Unit CT2 GasFlow, Total, 100scf 1 Hour(s)	Unit CT2 NH3, Inj, LbPerHr 1 Hour(s)	Unit CT2 HI, MBtu 1 Hour(s)
09/01/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
09/02/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
09/03/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
09/04/2014	0.00	0.0	0.00	0.0	0.0	0.0	0.000
09/05/2014	23.35	332,627.4	11.28	27,891.3	360,518.7	2,772.9	37,125.745
09/06/2014	24.00	405,051.1	24.00	56,056.5	461,107.6	2,800.7	47,484.700
09/07/2014	24.00	402,339.1	24.00	58,301.6	460,640.7	2,900.5	47,436.100
09/08/2014	24.00	365,926.3	12.80	22,329.2	388,255.5	2,394.8	40,195.600
09/09/2014	24.00	359,568.9	15.25	29,678.1	389,247.0	2,554.6	40,298.400
09/10/2014	24.00	394,728.8	21.82	62,826.4	457,555.2	3,086.5	47,370.100
09/11/2014	24.00	405,125.2	24.00	65,624.8	470,750.0	3,021.5	48,736.200
09/12/2014	24.00	403,599.9	24.00	99,475.0	503,074.9	3,537.7	52,082.600
09/13/2014	24.00	380,704.9	17.60	45,839.8	426,544.7	2,688.6	44,159.800
09/14/2014	24.00	383,490.0	19.20	59,634.6	443,124.6	2,849.5	45,876.000
09/15/2014	24.00	393,455.0	21.51	53,195.3	446,650.3	2,829.5	46,241.200
09/16/2014	24.00	398,982.5	20.54	59,229.1	458,211.6	2,949.7	47,438.100
09/17/2014	24.00	408,063.7	24.00	79,159.6	487,223.3	3,067.5	50,441.600
09/18/2014	24.00	365,138.0	8.47	16,997.8	382,135.8	2,406.8	39,562.200
09/19/2014	24.00	377,347.2	18.52	47,270.5	424,617.7	2,655.6	43,960.000
09/20/2014	24.00	401,480.5	24.00	49,591.9	451,072.4	2,700.8	46,698.800
09/21/2014	24.00	367,442.5	16.74	23,110.4	390,552.9	2,388.3	40,433.500
09/22/2014	24.00	364,967.5	3.55	6,276.9	371,244.4	2,403.5	38,434.600
09/23/2014	24.00	380,891.8	0.00	0.0	380,891.8	2,547.0	39,433.300
09/24/2014	24.00	403,841.7	0.00	0.0	403,841.7	2,585.1	41,809.100
09/25/2014	24.00	410,467.6	10.98	29,816.5	440,284.1	2,743.5	45,582.300
09/26/2014	24.00	410,315.2	24.00	48,874.4	459,189.6	2,746.2	47,539.700
09/27/2014	24.00	363,232.9	13.94	27,048.5	390,281.4	2,477.4	40,405.500
09/28/2014	24.00	381,452.5	17.26	35,380.2	416,832.7	2,594.6	43,154.300
09/29/2014	24.00	384,092.0	19.13	30,696.4	414,788.4	2,531.4	42,942.700
09/30/2014	24.00	357,574.1	13.20	20,468.6	378,042.7	2,375.2	39,138.400
Monthly Avg/Sum*:	623.35 *	10,001,906.3 *	429.79 *	1,054,773.4 *	11,056,679.7 *	70,609.4 *	1,143,980.545 *
Daily Min:	23.35	332,627.4	0.00	0.0	360,518.7	2,375.2	37,125.745
Daily Max:	24.00	410,467.6	24.00	99,475.0	503,074.9	3,537.7	52,082.600
Jul 14 - Sep 14	1,560.87	25,029,649.0	1,114.88	2,647,421.2	27,677,070.2	177,583.1	2,857,591.018
QTD:	1,560.87 *	25,029,649.0 *	1,114.88 *	2,647,421.2 *	27,677,070.2 *	177,583.1 *	2,857,591.018 *
YTD 14:	2,937.18 *	47,738,236.7 *	2,118.50 *	5,032,779.7 *	52,771,016.3 *	346,479.9 *	5,431,970.284 *

ATTACHMENT 10
Maximum Emissions (AQ-25)

AQ-25 Emission Limits

Maximum Emissions Both Turbines (lbs)		
Pollutant	1-Hour Emissions	24-Hour Emissions
NO_x	666.60	2,994.60
CO	967.00	7,659.00
VOC	55.40	630.60
PM10	27.00	648.00
SO_2	14.80	355.20

Excess Emission Report

CT1 and CT2 CO Lb/Day

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:03 **Location:** Maxwell, CA

Tag Name: ALL_CO_Lb_1D
Total Operating Time: 70.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 22.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	70.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

CT1 and CT2 CO Lb/Hr

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:03 **Location:** Maxwell, CA

Tag Name: ALL_CO_Lb_1H
Total Operating Time: 1,602.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 606.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,602.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

CT1 and CT2 NOx Lb/Hr

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:04 **Location:** Maxwell, CA

Tag Name: ALL_NOx_Lb_1H
Total Operating Time: 1,602.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 606.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,602.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

CT1 and CT2 NOx Lb/Day

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:04 **Location:** Maxwell, CA

Tag Name: ALL_NOx_Lb_1D
Total Operating Time: 70.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 22.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	70.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

CT1 and CT2 PM10 Lb/Day

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:03 **Location:** Maxwell, CA

Tag Name: ALL_PM10_Lb_1D
Total Operating Time: 70.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 22.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	70.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

CT1 and CT2 PM10 Lb/Hr

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:04 **Location:** Maxwell, CA

Tag Name: ALL_PM10_Lb_1H
Total Operating Time: 1,602.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 606.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,602.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

CT1 and CT2 SO2 Lb/Day

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:03 **Location:** Maxwell, CA

Tag Name: ALL_SO2_Lb_1D
Total Operating Time: 70.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 22.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	70.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

CT1 and CT2 VOC Lb/Day

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:04 **Location:** Maxwell, CA

Tag Name: ALL_VOC_Lb_1D
Total Operating Time: 70.00 Day(s) **No Exclusions Allowed**
Non-Operating Time: 22.00 Day(s) Report Time: 92.00 Day(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	70.00 Day(s)
Total Duration (Online only):	0.00 Day(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Excess Emission Report

CT1 and CT2 VOC Lb/Hr

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION
Generated: 10/21/2014 09:03 **Location:** Maxwell, CA

Tag Name: ALL_VOC_Lb_1H
Total Operating Time: 1,602.00 Hour(s) **No Exclusions Allowed**
Non-Operating Time: 606.00 Hour(s) Report Time: 2,208.00 Hour(s)

No incidents have been reported for this reporting period. Data is 100% in compliance.

Total Operating Time:	1,602.00 Hour(s)
Total Duration (Online only):	0.00 Hour(s)
Time in exceedance as a percentage of operating time:	0.00 %
Time in compliance as a percentage of operating time:	100.00 %

Monthly Summary By Day Report

AQ-25

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value

Date/Time	PlantWide NOx, Lb 1 Day(s)	PlantWide CO, Lb 1 Day(s)	PlantWide VOC, Lb 1 Day(s)	PlantWide PM10, Lb 1 Day(s)	PlantWide SO2, Lb 1 Day(s)
07/01/2014	209.6	60.5	44.0	239.9	51.6
07/02/2014	223.6	69.7	42.3	231.4	49.9
07/03/2014	299.2	134.0	37.5	197.7	43.4
07/04/2014	219.5	61.5	38.4	211.0	46.1
07/05/2014	334.3	197.3	28.6	148.3	33.1
07/06/2014	304.2	167.4	34.0	179.3	39.2
07/07/2014	197.4	59.8	42.9	232.7	50.2
07/08/2014	229.5	69.0	45.9	253.6	55.1
07/09/2014	231.4	55.5	43.9	239.8	0.0
07/10/2014	187.9	59.1	39.8	213.8	0.0
07/11/2014	234.5	202.0	23.0	115.6	0.0
07/12/2014	313.0	170.0	24.9	146.1	0.0
07/13/2014	314.4	172.3	30.1	158.5	0.0
07/14/2014	247.9	44.1	42.3	232.8	0.0
07/15/2014	311.3	55.3	45.1	247.5	0.0
07/16/2014	278.0	42.2	42.2	229.6	49.8
07/17/2014	315.7	127.6	29.0	165.9	35.9
07/18/2014	287.4	114.4	30.9	177.9	38.5
07/19/2014	373.6	137.8	32.4	169.9	37.4
07/20/2014	4.2	12.2	0.1	0.7	0.2
07/21/2014	504.2	294.0	36.4	208.8	45.4
07/22/2014	319.5	52.3	46.8	257.0	55.7
07/23/2014	256.3	45.8	43.0	234.6	51.0
07/24/2014	290.1	42.1	43.7	240.7	52.3
07/25/2014	340.1	58.2	48.2	265.5	57.7
07/26/2014	286.9	41.9	42.8	232.4	50.5
07/27/2014	281.0	55.2	42.6	234.2	51.1
07/28/2014	319.8	59.0	46.4	255.0	55.5
07/29/2014	304.8	50.9	45.6	249.6	54.3
07/30/2014	320.6	55.9	47.5	259.1	56.3
07/31/2014	321.4	60.9	46.5	254.8	55.2
Monthly Avg/Sum*:	8,661.3 *	2,827.9 *	1,186.8 *	6,483.7 *	1,115.4 *
Daily Min:	4.2	12.2	0.1	0.7	0.2
Daily Max:	504.2	294.0	48.2	265.5	57.7
Jul 14 - Jul 14	8,661.3	2,827.9	1,186.8	6,483.7	1,115.4
QTD:	8,661.3 *	2,827.9 *	1,186.8 *	6,483.7 *	1,115.4 *
YTD 14:	32,175.0 *	10,793.6 *	3,777.9 *	20,653.1 *	3,771.1 *

Monthly Summary By Day Report

AQ-25

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value

Date/Time	PlantWide NOx, Lb 1 Day(s)	PlantWide CO, Lb 1 Day(s)	PlantWide VOC, Lb 1 Day(s)	PlantWide PM10, Lb 1 Day(s)	PlantWide SO2, Lb 1 Day(s)
08/01/2014	337.8	70.7	46.9	259.1	56.5
08/02/2014	285.3	64.2	42.3	230.5	50.2
08/03/2014	318.1	66.4	44.8	245.9	53.8
08/04/2014	330.1	52.4	43.4	237.3	51.7
08/05/2014	308.4	57.8	43.7	238.7	52.4
08/06/2014	317.0	76.5	45.4	252.2	55.0
08/07/2014	308.1	441.6	21.3	132.7	28.0
08/08/2014	326.2	63.4	47.7	262.1	57.0
08/09/2014	313.4	116.7	30.1	174.5	37.3
08/10/2014	342.8	155.5	26.3	152.5	33.0
08/11/2014	365.9	61.8	50.0	273.6	59.5
08/12/2014	274.2	9.3	40.0	223.3	48.5
08/13/2014	288.8	91.0	28.3	166.9	35.9
08/14/2014	0.0	0.0	0.0	0.0	0.0
08/15/2014	0.0	0.0	0.0	0.0	0.0
08/16/2014	0.0	0.0	0.0	0.0	0.0
08/17/2014	0.0	0.0	0.0	0.0	0.0
08/18/2014	0.0	0.0	0.0	0.0	0.0
08/19/2014	0.0	0.0	0.0	0.0	0.0
08/20/2014	0.0	0.0	0.0	0.0	0.0
08/21/2014	0.0	0.0	0.0	0.0	0.0
08/22/2014	0.0	0.0	0.0	0.0	0.0
08/23/2014	0.0	0.0	0.0	0.0	0.0
08/24/2014	0.0	0.0	0.0	0.0	0.0
08/25/2014	0.0	0.0	0.0	0.0	0.0
08/26/2014	0.0	0.0	0.0	0.0	0.0
08/27/2014	0.0	0.0	0.0	0.0	0.0
08/28/2014	0.0	0.0	0.0	0.0	0.0
08/29/2014	0.0	0.0	0.0	0.0	0.0
08/30/2014	0.0	0.0	0.0	0.0	0.0
08/31/2014	0.0	0.0	0.0	0.0	0.0
Monthly Avg/Sum*:	4,116.1 *	1,327.3 *	510.2 *	2,849.3 *	618.8 *
Daily Min:	0.0	0.0	0.0	0.0	0.0
Daily Max:	365.9	441.6	50.0	273.6	59.5
Jul 14 - Aug 14	12,777.4	4,155.2	1,697.0	9,333.0	1,734.2
QTD:	12,777.4 *	4,155.2 *	1,697.0 *	9,333.0 *	1,734.2 *
YTD 14:	36,291.1 *	12,120.9 *	4,288.1 *	23,502.4 *	4,389.9 *

Monthly Summary By Day Report

AQ-25

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/21/2014 09:25 **Location:** Maxwell, CA

Red = Invalid Data | Green = Edited Status | Blue = Edited Value

Date/Time	PlantWide NOx, Lb 1 Day(s)	PlantWide CO, Lb 1 Day(s)	PlantWide VOC, Lb 1 Day(s)	PlantWide PM10, Lb 1 Day(s)	PlantWide SO2, Lb 1 Day(s)
09/01/2014	0.0	0.0	0.0	0.0	0.0
09/02/2014	0.0	0.0	0.0	0.0	0.0
09/03/2014	0.0	0.0	0.0	0.0	0.0
09/04/2014	0.0	0.0	0.0	0.0	0.0
09/05/2014	648.2	369.3	31.1	182.5	39.6
09/06/2014	336.6	38.4	47.4	259.7	56.1
09/07/2014	334.6	37.7	47.4	259.7	56.4
09/08/2014	267.4	24.6	40.7	220.5	48.4
09/09/2014	253.7	22.5	40.6	220.5	48.1
09/10/2014	334.2	29.9	47.1	258.4	56.3
09/11/2014	350.0	39.3	48.5	266.2	57.9
09/12/2014	397.4	26.8	51.8	284.5	61.5
09/13/2014	308.4	33.4	44.0	241.6	53.1
09/14/2014	329.4	31.5	45.5	250.2	54.9
09/15/2014	325.1	32.7	45.9	252.4	54.7
09/16/2014	344.6	29.3	47.2	258.6	56.2
09/17/2014	361.7	34.6	50.2	275.1	59.9
09/18/2014	222.3	21.7	39.5	216.7	47.7
09/19/2014	284.4	27.0	44.0	240.4	52.5
09/20/2014	310.2	34.9	46.7	255.4	55.5
09/21/2014	246.7	28.1	41.3	221.9	48.1
09/22/2014	210.4	23.8	38.4	210.7	45.1
09/23/2014	219.6	24.4	38.9	217.0	47.2
09/24/2014	228.7	18.0	40.7	230.4	50.6
09/25/2014	249.2	40.6	44.4	249.6	55.1
09/26/2014	321.1	64.0	47.2	259.5	56.3
09/27/2014	249.2	44.5	40.5	221.2	48.8
09/28/2014	277.8	55.4	43.6	236.4	51.7
09/29/2014	269.0	67.5	43.4	234.8	51.3
09/30/2014	235.8	44.1	39.6	214.0	47.1
Monthly Avg/Sum*:	7,915.7 *	1,244.0 *	1,135.6 *	6,237.9 *	1,360.1 *
Daily Min:	0.0	0.0	0.0	0.0	0.0
Daily Max:	648.2	369.3	51.8	284.5	61.5
Jul 14 - Sep 14	20,693.1	5,399.2	2,832.6	15,570.9	3,094.3
QTD:	20,693.1 *	5,399.2 *	2,832.6 *	15,570.9 *	3,094.3 *
YTD 14:	44,206.8 *	13,364.9 *	5,423.7 *	29,740.3 *	5,750.0 *

ATTACHMENT 11
CGA/Linearity (AQ-19)

CGA’s

Cylinder Gas Audit

10/22/2014

Facility: COLUSA GENERATION

Unit/Stack: CT1

Parameter/Scale: CO / High

Test Date: 09/22/2014

Test Result: **Pass**

Instrument Name: CT1_CODualRg_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
09/22/2014	10:47	L	2000	508.800	494.700	25.4 %
09/22/2014	10:53	M	2000	1144.000	1154.400	57.2 %
09/22/2014	11:01	L	2000	508.800	494.700	25.4 %
09/22/2014	11:07	M	2000	1144.000	1153.100	57.2 %
09/22/2014	11:15	L	2000	508.800	495.600	25.4 %
09/22/2014	11:21	M	2000	1144.000	1153.100	57.2 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	508.800	495.000	Std	**2.7**
M	1144.000	1153.533	Std	**0.8**

Cylinder Gas Audit

10/22/2014

Facility: COLUSA GENERATION

Unit/Stack: CT1

Parameter/Scale: CO / Low

Test Date: 09/22/2014

Test Result: **Pass**

Instrument Name: CT1_CODualRg_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
09/22/2014	09:21	L	20	4.900	4.900	24.5 %
09/22/2014	09:27	M	20	10.900	10.900	54.5 %
09/22/2014	09:36	L	20	4.900	4.800	24.5 %
09/22/2014	09:42	M	20	10.900	10.800	54.5 %
09/22/2014	09:50	L	20	4.900	4.800	24.5 %
09/22/2014	09:56	M	20	10.900	10.800	54.5 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	4.900	4.833	Std	**1.4**
M	10.900	10.833	Std	**0.6**

Cylinder Gas Audit

10/22/2014

Facility: COLUSA GENERATION

Unit/Stack: CT1

Parameter/Scale: NOX / High

Test Date: 09/22/2014

Test Result: **Pass**

Instrument Name: CT1_NOXInlet_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
09/22/2014	07:58	L	200	50.600	50.300	25.3 %
09/22/2014	08:04	M	200	109.100	108.100	54.6 %
09/22/2014	08:13	L	200	50.600	50.000	25.3 %
09/22/2014	08:19	M	200	109.100	108.600	54.6 %
09/22/2014	08:27	L	200	50.600	50.100	25.3 %
09/22/2014	08:33	M	200	109.100	107.600	54.6 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	50.600	50.133	Std	**0.9**
M	109.100	108.100	Std	**0.9**

Cylinder Gas Audit

10/22/2014

Facility:	COLUSA GENERATION			Instrument Name:	CT1_NOXDualRg_P_Instru
Unit/Stack:	CT1	Test Date:	09/22/2014	Performance Spec:	15 Pct
Parameter/Scale:	NOX / Low	Test Result:	**Pass**	Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
09/22/2014	10:05	L	10	2.500	2.200	25.0 %
09/22/2014	10:11	M	10	5.500	5.200	55.0 %
09/22/2014	10:20	L	10	2.500	2.200	25.0 %
09/22/2014	10:26	M	10	5.500	5.200	55.0 %
09/22/2014	10:34	L	10	2.500	2.200	25.0 %
09/22/2014	10:40	M	10	5.500	5.200	55.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	2.500	2.200	Std	**12.0**
M	5.500	5.200	Std	**5.5**

Cylinder Gas Audit

10/22/2014

Facility: COLUSA GENERATION

Unit/Stack: CT1

Parameter/Scale: O2D / High

Test Date: 09/22/2014

Test Result: **Pass**

Instrument Name: CT1_O2DInlet_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 0.5 Pct

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
09/22/2014	08:40	L	25	5.500	5.500	22.0 %
09/22/2014	08:46	M	25	13.200	13.300	52.8 %
09/22/2014	08:55	L	25	5.500	5.500	22.0 %
09/22/2014	09:01	M	25	13.200	13.300	52.8 %
09/22/2014	09:09	L	25	5.500	5.500	22.0 %
09/22/2014	09:15	M	25	13.200	13.300	52.8 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	5.500	5.500	Std	**0.0**
M	13.200	13.300	Std	**0.8**

Cylinder Gas Audit

10/22/2014

Facility: COLUSA GENERATION

Unit/Stack: CT2

Parameter/Scale: O2D / High

Test Date: 09/23/2014

Test Result: **Pass**

Instrument Name: CT2_O2DInlet_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 0.5 Pct

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
09/23/2014	08:36	L	25	5.500	5.500	22.0 %
09/23/2014	08:42	M	25	13.000	13.000	52.0 %
09/23/2014	08:51	L	25	5.500	5.500	22.0 %
09/23/2014	08:57	M	25	13.000	13.000	52.0 %
09/23/2014	09:05	L	25	5.500	5.500	22.0 %
09/23/2014	09:11	M	25	13.000	13.000	52.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	5.500	5.500	Std	**0.0**
M	13.000	13.000	Std	**0.0**

Cylinder Gas Audit

10/22/2014

Facility: COLUSA GENERATION
Unit/Stack: CT2
Parameter/Scale: CO / High

Test Date: 09/23/2014
Test Result: **Pass**

Instrument Name: CT2_CODualRg_P_Instrum
Performance Spec: 15 Pct
Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
09/23/2014	10:42	L	2000	509.800	504.200	25.5 %
09/23/2014	10:48	M	2000	1165.000	1170.000	58.3 %
09/23/2014	10:57	L	2000	509.800	504.700	25.5 %
09/23/2014	11:03	M	2000	1165.000	1170.000	58.3 %
09/23/2014	11:11	L	2000	509.800	504.700	25.5 %
09/23/2014	11:17	M	2000	1165.000	1170.300	58.3 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	509.800	504.533	Std	**1.0**
M	1165.000	1170.100	Std	**0.4**

Cylinder Gas Audit

10/22/2014

Facility: COLUSA GENERATION

Unit/Stack: CT2

Parameter/Scale: CO / Low

Test Date: 09/23/2014

Test Result: **Pass**

Instrument Name: CT2_CODualRg_P_Instrum

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
09/23/2014	09:18	L	20	4.900	4.800	24.5 %
09/23/2014	09:24	M	20	11.300	11.200	56.5 %
09/23/2014	09:33	L	20	4.900	4.700	24.5 %
09/23/2014	09:39	M	20	11.300	11.200	56.5 %
09/23/2014	09:47	L	20	4.900	4.800	24.5 %
09/23/2014	09:53	M	20	11.300	11.200	56.5 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	4.900	4.767	Std	**2.7**
M	11.300	11.200	Std	**0.9**

Cylinder Gas Audit

10/22/2014

Facility:	COLUSA GENERATION			Instrument Name:	CT2_NOXInlet_P_Instrum
Unit/Stack:	CT2	Test Date:	09/23/2014	Performance Spec:	15 Pct
Parameter/Scale:	NOX / High	Test Result:	**Pass**	Alternate Spec:	5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
09/23/2014	07:55	L	200	49.700	48.100	24.9 %
09/23/2014	08:01	M	200	108.500	106.700	54.3 %
09/23/2014	08:10	L	200	49.700	48.200	24.9 %
09/23/2014	08:16	M	200	108.500	106.500	54.3 %
09/23/2014	08:24	L	200	49.700	48.200	24.9 %
09/23/2014	08:30	M	200	108.500	106.200	54.3 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	49.700	48.167	Std	**3.1**
M	108.500	106.467	Std	**1.9**

Cylinder Gas Audit

10/22/2014

Facility: COLUSA GENERATION

Unit/Stack: CT2

Parameter/Scale: NOX / Low

Test Date: 09/23/2014

Test Result: **Pass**

Instrument Name: CT2_NOXDualRg_P_Instru

Performance Spec: 15 Pct

Alternate Spec: 5 Ppm

Date	Time	Test Level	Span Value	Reference Value	Measured Value	Ref Value As Pct Span
09/23/2014	10:00	L	10	2.400	2.100	24.0 %
09/23/2014	10:06	M	10	5.600	5.200	56.0 %
09/23/2014	10:15	L	10	2.400	2.100	24.0 %
09/23/2014	10:21	M	10	5.600	5.200	56.0 %
09/23/2014	10:29	L	10	2.400	2.100	24.0 %
09/23/2014	10:35	M	10	5.600	5.200	56.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Specification Used	Results
L	2.400	2.100	Std	**12.5**
M	5.600	5.200	Std	**7.1**

Linearity’s

Linearity Report

10/22/2014

ORIS Code:	56298	Facility Name:	COLUSA GENERATION		
EDR Site ID:	CT1	Component ID:	A11	ReasonForTest:	QA
		Component Type:	NOXA	Grace Period:	0
Instrument Name:	CT1_NOXDualRg_P_Instrume	Test End Date/Time:	09/22/2014	Scale:	High
Performance Spec:	5 %	Test No.:	46	Highest Error:	1.9
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
09/22/2014	1133	L	200.0	50.6	49.4		25.3 %
09/22/2014	1139	M	200.0	109.1	107.1		54.6 %
09/22/2014	1145	H	200.0	179.4	179.1		89.7 %
09/22/2014	1154	L	200.0	50.6	49.8		25.3 %
09/22/2014	1200	M	200.0	109.1	107.4		54.6 %
09/22/2014	1206	H	200.0	179.4	178.5		89.7 %
09/22/2014	1214	L	200.0	50.6	49.7		25.3 %
09/22/2014	1220	M	200.0	109.1	107.3		54.6 %
09/22/2014	1226	H	200.0	179.4	178.7		89.7 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	50.600	49.633	No	**1.9**
M	109.100	107.267	No	**1.7**
H	179.400	178.767	No	**0.4**

Linearity Report

ORIS Code:	56298	Facility Name:	COLUSA GENERATION		
EDR Site ID:	CT1	Component ID:	A12	ReasonForTest:	QA
		Component Type:	O2D	Grace Period:	0
Instrument Name:	CT1_O2D_P_Instrument	Test End Date/Time:	09/22/2014	Scale:	High
Performance Spec:	5 %	Test No.:	47	Highest Error:	0.0
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
09/22/2014	1235	L	25.0	5.5	5.5		22.0 %
09/22/2014	1241	M	25.0	13.2	13.2		52.8 %
09/22/2014	1247	H	25.0	21.0	21.0		84.0 %
09/22/2014	1256	L	25.0	5.5	5.5		22.0 %
09/22/2014	1302	M	25.0	13.2	13.2		52.8 %
09/22/2014	1308	H	25.0	21.0	21.0		84.0 %
09/22/2014	1316	L	25.0	5.5	5.5		22.0 %
09/22/2014	1322	M	25.0	13.2	13.2		52.8 %
09/22/2014	1328	H	25.0	21.0	21.0		84.0 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500	5.500	No	**0.0**
M	13.200	13.200	No	**0.0**
H	21.000	21.000	No	**0.0**

Linearity Report

ORIS Code:	56298	Facility Name:	COLUSA GENERATION		
EDR Site ID:	CT2	Component ID:	A21	ReasonForTest:	QA
		Component Type:	NOXA	Grace Period:	0
Instrument Name:	CT2_NOXDualRg_P_Instrume	Test End Date/Time:	09/23/2014	Scale:	High
Performance Spec:	5 %	Test No.:	42	Highest Error:	1.7
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
09/23/2014	1126	L	200.0	49.7	49.3		24.9 %
09/23/2014	1132	M	200.0	108.5	108.9		54.3 %
09/23/2014	1138	H	200.0	175.2	178.0		87.6 %
09/23/2014	1147	L	200.0	49.7	49.4		24.9 %
09/23/2014	1153	M	200.0	108.5	108.9		54.3 %
09/23/2014	1159	H	200.0	175.2	178.2		87.6 %
09/23/2014	1207	L	200.0	49.7	49.4		24.9 %
09/23/2014	1213	M	200.0	108.5	109.2		54.3 %
09/23/2014	1219	H	200.0	175.2	178.5		87.6 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	49.700	49.367	No	**0.7**
M	108.500	109.000	No	**0.5**
H	175.200	178.233	No	**1.7**

Linearity Report

ORIS Code:	56298	Facility Name:	COLUSA GENERATION		
EDR Site ID:	CT2	Component ID:	A22	ReasonForTest:	QA
		Component Type:	O2D	Grace Period:	0
Instrument Name:	CT2_O2D_P_Instrument	Test End Date/Time:	09/23/2014	Scale:	High
Performance Spec:	5 %	Test No.:	43	Highest Error:	0.3
		Status (Pass/Fail):	**Passed**		

Date	Time	Cal Gas Level	Span Value	Ref Value	Meas Value	Aborted Test Indicator	Ref Value As Pct Span
09/23/2014	1225	L	25.0	5.5	5.5		22.0 %
09/23/2014	1231	M	25.0	13.0	13.0		52.0 %
09/23/2014	1237	H	25.0	20.3	20.3		81.2 %
09/23/2014	1246	L	25.0	5.5	5.5		22.0 %
09/23/2014	1252	M	25.0	13.0	13.1		52.0 %
09/23/2014	1258	H	25.0	20.3	20.3		81.2 %
09/23/2014	1306	L	25.0	5.5	5.5		22.0 %
09/23/2014	1312	M	25.0	13.0	13.0		52.0 %
09/23/2014	1318	H	25.0	20.3	20.3		81.2 %

Summary Statistics:

Cal Gas Level	Reference Mean	CEMS Mean	Alt Perf Spec	Results
L	5.500	5.500	No	**0.0**
M	13.000	13.033	No	**0.3**
H	20.300	20.300	No	**0.0**

ATTACHMENT 12
Startup/Shutdown Emissions (AQ-22)

Pound Per Event Report

CT1 - CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,541.32 Hours

Non-Operating Time: 666.68 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
07/02/2014 22:01 07/02/2014 22:09 Shut Down - Gas	9	2.6	483.5		
07/03/2014 03:20 07/03/2014 04:09 Hot Start - Gas	50	37.2	679.6		
07/04/2014 20:01 07/04/2014 20:09 Shut Down - Gas	9	3.4	483.5		
07/05/2014 06:08 07/05/2014 07:57 Warm Start - Gas	110	88.9	790.5		
07/06/2014 02:01 07/06/2014 02:09 Shut Down - Gas	9	4.2	483.5		
07/06/2014 05:28 07/06/2014 06:36 Hot Start - Gas	69	58.0	679.6		
07/11/2014 01:08 07/11/2014 01:15 Shut Down - Gas	8	2.3	483.5		
07/11/2014 05:24 07/11/2014 06:36 Hot Start - Gas	73	55.9	679.6		
07/12/2014 00:05 07/12/2014 00:12 Shut Down - Gas	8	3.8	483.5		
07/12/2014 11:08 07/12/2014 12:05 Warm Start - Gas	58	35.2	790.5		
07/13/2014 01:05 07/13/2014 01:12 Shut Down - Gas	8	2.9	483.5		
07/13/2014 06:30 07/13/2014 07:47 Hot Start - Gas	78	54.5	679.6		
07/17/2014 00:05 07/17/2014 00:12 Shut Down - Gas	8	2.8	483.5		

Pound Per Event Report

CT1 - CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,541.32 Hours

Non-Operating Time: 666.68 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
07/17/2014 08:38 07/17/2014 09:33 Warm Start - Gas	56	33.9	790.5		
07/18/2014 00:05 07/18/2014 00:12 Shut Down - Gas	8	3.0	483.5		
07/18/2014 08:08 07/18/2014 09:04 Hot Start - Gas	57	35.9	679.6		
07/19/2014 00:11 07/19/2014 00:18 Shut Down - Gas	8	2.6	483.5		
07/19/2014 05:34 07/19/2014 06:39 Hot Start - Gas	66	47.2	679.6		
07/20/2014 00:05 07/20/2014 00:12 Shut Down - Gas	8	3.1	483.5		
07/21/2014 06:18 07/21/2014 07:34 Warm Start - Gas	77	99.6	790.5		
08/06/2014 23:02 08/06/2014 23:09 Shut Down - Gas	8	2.5	483.5		
08/07/2014 13:01 08/07/2014 13:28 Warm Start - Gas	28	322.3	790.5		
08/07/2014 14:07 08/07/2014 15:06 Hot Start - Gas	60	49.3	679.6		
08/09/2014 02:05 08/09/2014 02:12 Shut Down - Gas	8	2.6	483.5		
08/09/2014 10:19 08/09/2014 11:16 Warm Start - Gas	58	33.4	790.5		
08/10/2014 00:05 08/10/2014 00:12 Shut Down - Gas	8	2.6	483.5		
08/10/2014 11:17 08/10/2014 12:21 Warm Start - Gas	65	55.1	790.5		

Pound Per Event Report

CT1 - CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,541.32 Hours

Non-Operating Time: 666.68 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
08/13/2014 01:32 08/13/2014 01:40 Shut Down - Gas	9	2.5	483.5		
08/13/2014 08:25 08/13/2014 09:35 Hot Start - Gas	71	35.1	679.6		
08/13/2014 23:16 08/13/2014 23:24 Shut Down - Gas	9	2.6	483.5		
09/05/2014 07:17 09/05/2014 08:51 Cold Start - Gas	95	106.6	1,355.6		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT1 - CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,541.32 Hours

Non-Operating Time: 666.68 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Pound Per Event Report

CT1 - CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Tag Name: CT1_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,541.32 Hours

Non-Operating Time: 666.68 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary

1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Pound Per Event Report

CT1 - NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,541.32 Hours

Non-Operating Time: 666.68 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
07/02/2014 22:01 07/02/2014 22:09 Shut Down - Gas	9	1.18	115.00		
07/03/2014 03:20 07/03/2014 04:09 Hot Start - Gas	50	11.88	259.90		
07/04/2014 20:01 07/04/2014 20:09 Shut Down - Gas	9	1.66	115.00		
07/05/2014 06:08 07/05/2014 07:57 Warm Start - Gas	110	90.77	456.20		
07/06/2014 02:01 07/06/2014 02:09 Shut Down - Gas	9	1.17	115.00		
07/06/2014 05:28 07/06/2014 06:36 Hot Start - Gas	69	33.33	259.90		
07/11/2014 01:08 07/11/2014 01:15 Shut Down - Gas	8	0.57	115.00		
07/11/2014 05:24 07/11/2014 06:36 Hot Start - Gas	73	23.20	259.90		
07/12/2014 00:05 07/12/2014 00:12 Shut Down - Gas	8	0.87	115.00		
07/12/2014 11:08 07/12/2014 12:05 Warm Start - Gas	58	72.28	456.20		
07/13/2014 01:05 07/13/2014 01:12 Shut Down - Gas	8	0.90	115.00		
07/13/2014 06:30 07/13/2014 07:47 Hot Start - Gas	78	54.17	259.90		
07/17/2014 00:05 07/17/2014 00:12 Shut Down - Gas	8	0.95	115.00		

Pound Per Event Report

CT1 - NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,541.32 Hours

Non-Operating Time: 666.68 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
07/17/2014 08:38 07/17/2014 09:33 Warm Start - Gas	56	57.78	456.20		
07/18/2014 00:05 07/18/2014 00:12 Shut Down - Gas	8	0.95	115.00		
07/18/2014 08:08 07/18/2014 09:04 Hot Start - Gas	57	60.54	259.90		
07/19/2014 00:11 07/19/2014 00:18 Shut Down - Gas	8	1.17	115.00		
07/19/2014 05:34 07/19/2014 06:39 Hot Start - Gas	66	53.12	259.90		
07/20/2014 00:05 07/20/2014 00:12 Shut Down - Gas	8	0.86	115.00		
07/21/2014 06:18 07/21/2014 07:34 Warm Start - Gas	77	98.27	456.20		
08/06/2014 23:02 08/06/2014 23:09 Shut Down - Gas	8	0.74	115.00		
08/07/2014 13:01 08/07/2014 13:28 Warm Start - Gas	28	21.71	456.20		
08/07/2014 14:07 08/07/2014 15:06 Hot Start - Gas	60	59.65	259.90		
08/09/2014 02:05 08/09/2014 02:12 Shut Down - Gas	8	0.80	115.00		
08/09/2014 10:19 08/09/2014 11:16 Warm Start - Gas	58	57.31	456.20		
08/10/2014 00:05 08/10/2014 00:12 Shut Down - Gas	8	1.06	115.00		
08/10/2014 11:17 08/10/2014 12:21 Warm Start - Gas	65	70.74	456.20		

Pound Per Event Report

CT1 - NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,541.32 Hours

Non-Operating Time: 666.68 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
08/13/2014 01:32 08/13/2014 01:40 Shut Down - Gas	9	1.35	115.00		
08/13/2014 08:25 08/13/2014 09:35 Hot Start - Gas	71	47.93	259.90		
08/13/2014 23:16 08/13/2014 23:24 Shut Down - Gas	9	0.92	115.00		
09/05/2014 07:17 09/05/2014 08:51 Cold Start - Gas	95	139.04	779.10		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT1 - NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,541.32 Hours

Non-Operating Time: 666.68 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Pound Per Event Report

CT1 - NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Tag Name: CT1_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,541.32 Hours

Non-Operating Time: 666.68 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary

1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,541.32 Hours

Non-Operating Time: 666.68 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
07/02/2014 22:01 07/02/2014 22:09 Shut Down - Gas	9	7.3		
07/03/2014 03:20 07/03/2014 04:09 Hot Start - Gas	50	96.2		
07/04/2014 20:01 07/04/2014 20:09 Shut Down - Gas	9	6.8		
07/05/2014 06:08 07/05/2014 07:57 Warm Start - Gas	110	197.4		
07/06/2014 02:01 07/06/2014 02:09 Shut Down - Gas	9	6.0		
07/06/2014 05:28 07/06/2014 06:36 Hot Start - Gas	69	124.0		
07/11/2014 01:08 07/11/2014 01:15 Shut Down - Gas	8	4.1		
07/11/2014 05:24 07/11/2014 06:36 Hot Start - Gas	73	134.6		
07/12/2014 00:05 07/12/2014 00:12 Shut Down - Gas	8	4.9		
07/12/2014 11:08 07/12/2014 12:05 Warm Start - Gas	58	108.5		
07/13/2014 01:05 07/13/2014 01:12 Shut Down - Gas	8	5.0		
07/13/2014 06:30 07/13/2014 07:47 Hot Start - Gas	78	142.7		
07/17/2014 00:05 07/17/2014 00:12 Shut Down - Gas	8	5.6		

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,541.32 Hours

Non-Operating Time: 666.68 Hours Report Time: 2,208.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
07/17/2014 08:38 07/17/2014 09:33 Warm Start - Gas	56	108.7		
07/18/2014 00:05 07/18/2014 00:12 Shut Down - Gas	8	5.5		
07/18/2014 08:08 07/18/2014 09:04 Hot Start - Gas	57	109.6		
07/19/2014 00:11 07/19/2014 00:18 Shut Down - Gas	8	5.3		
07/19/2014 05:34 07/19/2014 06:39 Hot Start - Gas	66	118.4		
07/20/2014 00:05 07/20/2014 00:12 Shut Down - Gas	8	5.4		
07/21/2014 06:18 07/21/2014 07:34 Warm Start - Gas	77	142.3		
08/06/2014 23:02 08/06/2014 23:09 Shut Down - Gas	8	4.9		
08/07/2014 13:01 08/07/2014 13:28 Warm Start - Gas	28	26.9		
08/07/2014 14:07 08/07/2014 15:06 Hot Start - Gas	60	112.4		
08/09/2014 02:05 08/09/2014 02:12 Shut Down - Gas	8	5.8		
08/09/2014 10:19 08/09/2014 11:16 Warm Start - Gas	58	111.4		
08/10/2014 00:05 08/10/2014 00:12 Shut Down - Gas	8	5.5		
08/10/2014 11:17 08/10/2014 12:21 Warm Start - Gas	65	123.1		

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,541.32 Hours

Non-Operating Time: 666.68 Hours Report Time: 2,208.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
08/13/2014 01:32 08/13/2014 01:40 Shut Down - Gas	9	9.0		
08/13/2014 08:25 08/13/2014 09:35 Hot Start - Gas	71	124.2		
08/13/2014 23:16 08/13/2014 23:24 Shut Down - Gas	9	6.5		
09/05/2014 07:17 09/05/2014 08:51 Cold Start - Gas	95	172.8		

No excess emissions were found in the reporting period.

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,541.32 Hours

Non-Operating Time: 666.68 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

100scf Per Event Report

CT1 - GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:18 **Location:** Maxwell, CA

Tag Name: CT1_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,541.32 Hours

Non-Operating Time: 666.68 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary

1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/01/2014 00:00	0.0	0	0	0	0	1
07/01/2014 01:00	0.0	0	0	0	0	1
07/01/2014 02:00	0.0	0	0	0	0	1
07/01/2014 03:00	0.0	0	0	0	0	1
07/01/2014 04:00	0.0	0	0	0	0	1
07/01/2014 05:00	0.0	0	0	0	0	1
07/01/2014 06:00	0.0	0	0	0	0	1
07/01/2014 07:00	0.0	0	0	0	0	1
07/01/2014 08:00	0.0	0	0	0	0	1
07/01/2014 09:00	0.0	0	0	0	0	1
07/01/2014 10:00	0.0	0	0	0	0	1
07/01/2014 11:00	0.0	0	0	0	0	1
07/01/2014 12:00	0.0	0	0	0	0	1
07/01/2014 13:00	0.0	0	0	0	0	1
07/01/2014 14:00	0.0	0	0	0	0	1
07/01/2014 15:00	0.0	0	0	0	0	1
07/01/2014 16:00	0.0	0	0	0	0	1
07/01/2014 17:00	0.0	0	0	0	0	1
07/01/2014 18:00	0.0	0	0	0	0	1
07/01/2014 19:00	0.0	0	0	0	0	1
07/01/2014 20:00	0.0	0	0	0	0	1
07/01/2014 21:00	0.0	0	0	0	0	1
07/01/2014 22:00	0.0	0	0	0	0	1
07/01/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/02/2014 00:00	0.0	0	0	0	0	1
07/02/2014 01:00	0.0	0	0	0	0	1
07/02/2014 02:00	0.0	0	0	0	0	1
07/02/2014 03:00	0.0	0	0	0	0	1
07/02/2014 04:00	0.0	0	0	0	0	1
07/02/2014 05:00	0.0	0	0	0	0	1
07/02/2014 06:00	0.0	0	0	0	0	1
07/02/2014 07:00	0.0	0	0	0	0	1
07/02/2014 08:00	0.0	0	0	0	0	1
07/02/2014 09:00	0.0	0	0	0	0	1
07/02/2014 10:00	0.0	0	0	0	0	1
07/02/2014 11:00	0.0	0	0	0	0	1
07/02/2014 12:00	0.0	0	0	0	0	1
07/02/2014 13:00	0.0	0	0	0	0	1
07/02/2014 14:00	0.0	0	0	0	0	1
07/02/2014 15:00	0.0	0	0	0	0	1
07/02/2014 16:00	0.0	0	0	0	0	1
07/02/2014 17:00	0.0	0	0	0	0	1
07/02/2014 18:00	0.0	0	0	0	0	1
07/02/2014 19:00	0.0	0	0	0	0	1
07/02/2014 20:00	0.0	0	0	0	0	1
07/02/2014 21:00	0.0	0	0	0	0	1
07/02/2014 22:00	3.5	0	0	0	1	0
07/02/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	3.5 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3.5	0	0	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/03/2014 00:00	0.0	0	0	0	0	0
07/03/2014 01:00	0.0	0	0	0	0	0
07/03/2014 02:00	0.0	0	0	0	0	0
07/03/2014 03:00	33.9	0	0	1	0	0
07/03/2014 04:00	0.7	0	0	1	0	0
07/03/2014 05:00	0.0	0	0	0	0	1
07/03/2014 06:00	0.0	0	0	0	0	1
07/03/2014 07:00	0.0	0	0	0	0	1
07/03/2014 08:00	0.0	0	0	0	0	1
07/03/2014 09:00	0.0	0	0	0	0	1
07/03/2014 10:00	0.0	0	0	0	0	1
07/03/2014 11:00	0.0	0	0	0	0	1
07/03/2014 12:00	0.0	0	0	0	0	1
07/03/2014 13:00	0.0	0	0	0	0	1
07/03/2014 14:00	0.0	0	0	0	0	1
07/03/2014 15:00	0.0	0	0	0	0	1
07/03/2014 16:00	0.0	0	0	0	0	1
07/03/2014 17:00	0.0	0	0	0	0	1
07/03/2014 18:00	0.0	0	0	0	0	1
07/03/2014 19:00	0.0	0	0	0	0	1
07/03/2014 20:00	0.0	0	0	0	0	1
07/03/2014 21:00	0.0	0	0	0	0	1
07/03/2014 22:00	0.0	0	0	0	0	1
07/03/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	34.6 #	0 #	0 #	2 #	0 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	33.9	0	0	1	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/04/2014 00:00	0.0	0	0	0	0	1
07/04/2014 01:00	0.0	0	0	0	0	1
07/04/2014 02:00	0.0	0	0	0	0	1
07/04/2014 03:00	0.0	0	0	0	0	1
07/04/2014 04:00	0.0	0	0	0	0	1
07/04/2014 05:00	0.0	0	0	0	0	1
07/04/2014 06:00	0.0	0	0	0	0	1
07/04/2014 07:00	0.0	0	0	0	0	1
07/04/2014 08:00	0.0	0	0	0	0	1
07/04/2014 09:00	0.0	0	0	0	0	1
07/04/2014 10:00	0.0	0	0	0	0	1
07/04/2014 11:00	0.0	0	0	0	0	1
07/04/2014 12:00	0.0	0	0	0	0	1
07/04/2014 13:00	0.0	0	0	0	0	1
07/04/2014 14:00	0.0	0	0	0	0	1
07/04/2014 15:00	0.0	0	0	0	0	1
07/04/2014 16:00	0.0	0	0	0	0	1
07/04/2014 17:00	0.0	0	0	0	0	1
07/04/2014 18:00	0.0	0	0	0	0	1
07/04/2014 19:00	0.0	0	0	0	0	1
07/04/2014 20:00	4.3	0	0	0	1	0
07/04/2014 21:00	0.0	0	0	0	0	0
07/04/2014 22:00	0.0	0	0	0	0	0
07/04/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	4.3 #	0 #	0 #	0 #	1 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4.3	0	0	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/05/2014 00:00	0.0	0	0	0	0	0
07/05/2014 01:00	0.0	0	0	0	0	0
07/05/2014 02:00	0.0	0	0	0	0	0
07/05/2014 03:00	0.0	0	0	0	0	0
07/05/2014 04:00	0.0	0	0	0	0	0
07/05/2014 05:00	0.0	0	0	0	0	0
07/05/2014 06:00	29.6	0	1	0	0	0
07/05/2014 07:00	68.6	0	1	0	0	0
07/05/2014 08:00	0.0	0	0	0	0	1
07/05/2014 09:00	0.0	0	0	0	0	1
07/05/2014 10:00	0.0	0	0	0	0	1
07/05/2014 11:00	0.0	0	0	0	0	1
07/05/2014 12:00	0.0	0	0	0	0	1
07/05/2014 13:00	0.0	0	0	0	0	1
07/05/2014 14:00	0.0	0	0	0	0	1
07/05/2014 15:00	0.0	0	0	0	0	1
07/05/2014 16:00	0.0	0	0	0	0	1
07/05/2014 17:00	0.0	0	0	0	0	1
07/05/2014 18:00	0.0	0	0	0	0	1
07/05/2014 19:00	0.0	0	0	0	0	1
07/05/2014 20:00	0.0	0	0	0	0	1
07/05/2014 21:00	0.0	0	0	0	0	1
07/05/2014 22:00	0.0	0	0	0	0	1
07/05/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	98.2 #	0 #	2 #	0 #	0 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	68.6	0	1	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/06/2014 00:00	0.0	0	0	0	0	1
07/06/2014 01:00	0.0	0	0	0	0	1
07/06/2014 02:00	5.1	0	0	0	1	0
07/06/2014 03:00	0.0	0	0	0	0	0
07/06/2014 04:00	0.0	0	0	0	0	0
07/06/2014 05:00	18.5	0	0	1	0	0
07/06/2014 06:00	29.6	0	0	1	0	0
07/06/2014 07:00	0.0	0	0	0	0	1
07/06/2014 08:00	0.0	0	0	0	0	1
07/06/2014 09:00	0.0	0	0	0	0	1
07/06/2014 10:00	0.0	0	0	0	0	1
07/06/2014 11:00	0.0	0	0	0	0	1
07/06/2014 12:00	0.0	0	0	0	0	1
07/06/2014 13:00	0.0	0	0	0	0	1
07/06/2014 14:00	0.0	0	0	0	0	1
07/06/2014 15:00	0.0	0	0	0	0	1
07/06/2014 16:00	0.0	0	0	0	0	1
07/06/2014 17:00	0.0	0	0	0	0	1
07/06/2014 18:00	0.0	0	0	0	0	1
07/06/2014 19:00	0.0	0	0	0	0	1
07/06/2014 20:00	0.0	0	0	0	0	1
07/06/2014 21:00	0.0	0	0	0	0	1
07/06/2014 22:00	0.0	0	0	0	0	1
07/06/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	53.2 #	0 #	0 #	2 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	29.6	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/07/2014 00:00	0.0	0	0	0	0	1
07/07/2014 01:00	0.0	0	0	0	0	1
07/07/2014 02:00	0.0	0	0	0	0	1
07/07/2014 03:00	0.0	0	0	0	0	1
07/07/2014 04:00	0.0	0	0	0	0	1
07/07/2014 05:00	0.0	0	0	0	0	1
07/07/2014 06:00	0.0	0	0	0	0	1
07/07/2014 07:00	0.0	0	0	0	0	1
07/07/2014 08:00	0.0	0	0	0	0	1
07/07/2014 09:00	0.0	0	0	0	0	1
07/07/2014 10:00	0.0	0	0	0	0	1
07/07/2014 11:00	0.0	0	0	0	0	1
07/07/2014 12:00	0.0	0	0	0	0	1
07/07/2014 13:00	0.0	0	0	0	0	1
07/07/2014 14:00	0.0	0	0	0	0	1
07/07/2014 15:00	0.0	0	0	0	0	1
07/07/2014 16:00	0.0	0	0	0	0	1
07/07/2014 17:00	0.0	0	0	0	0	1
07/07/2014 18:00	0.0	0	0	0	0	1
07/07/2014 19:00	0.0	0	0	0	0	1
07/07/2014 20:00	0.0	0	0	0	0	1
07/07/2014 21:00	0.0	0	0	0	0	1
07/07/2014 22:00	0.0	0	0	0	0	1
07/07/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/08/2014 00:00	0.0	0	0	0	0	1
07/08/2014 01:00	0.0	0	0	0	0	1
07/08/2014 02:00	0.0	0	0	0	0	1
07/08/2014 03:00	0.0	0	0	0	0	1
07/08/2014 04:00	0.0	0	0	0	0	1
07/08/2014 05:00	0.0	0	0	0	0	1
07/08/2014 06:00	0.0	0	0	0	0	1
07/08/2014 07:00	0.0	0	0	0	0	1
07/08/2014 08:00	0.0	0	0	0	0	1
07/08/2014 09:00	0.0	0	0	0	0	1
07/08/2014 10:00	0.0	0	0	0	0	1
07/08/2014 11:00	0.0	0	0	0	0	1
07/08/2014 12:00	0.0	0	0	0	0	1
07/08/2014 13:00	0.0	0	0	0	0	1
07/08/2014 14:00	0.0	0	0	0	0	1
07/08/2014 15:00	0.0	0	0	0	0	1
07/08/2014 16:00	0.0	0	0	0	0	1
07/08/2014 17:00	0.0	0	0	0	0	1
07/08/2014 18:00	0.0	0	0	0	0	1
07/08/2014 19:00	0.0	0	0	0	0	1
07/08/2014 20:00	0.0	0	0	0	0	1
07/08/2014 21:00	0.0	0	0	0	0	1
07/08/2014 22:00	0.0	0	0	0	0	1
07/08/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/09/2014 00:00	0.0	0	0	0	0	1
07/09/2014 01:00	0.0	0	0	0	0	1
07/09/2014 02:00	0.0	0	0	0	0	1
07/09/2014 03:00	0.0	0	0	0	0	1
07/09/2014 04:00	0.0	0	0	0	0	1
07/09/2014 05:00	0.0	0	0	0	0	1
07/09/2014 06:00	0.0	0	0	0	0	1
07/09/2014 07:00	0.0	0	0	0	0	1
07/09/2014 08:00	0.0	0	0	0	0	1
07/09/2014 09:00	0.0	0	0	0	0	1
07/09/2014 10:00	0.0	0	0	0	0	1
07/09/2014 11:00	0.0	0	0	0	0	1
07/09/2014 12:00	0.0	0	0	0	0	1
07/09/2014 13:00	0.0	0	0	0	0	1
07/09/2014 14:00	0.0	0	0	0	0	1
07/09/2014 15:00	0.0	0	0	0	0	1
07/09/2014 16:00	0.0	0	0	0	0	1
07/09/2014 17:00	0.0	0	0	0	0	1
07/09/2014 18:00	0.0	0	0	0	0	1
07/09/2014 19:00	0.0	0	0	0	0	1
07/09/2014 20:00	0.0	0	0	0	0	1
07/09/2014 21:00	0.0	0	0	0	0	1
07/09/2014 22:00	0.0	0	0	0	0	1
07/09/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/10/2014 00:00	0.0	0	0	0	0	1
07/10/2014 01:00	0.0	0	0	0	0	1
07/10/2014 02:00	0.0	0	0	0	0	1
07/10/2014 03:00	0.0	0	0	0	0	1
07/10/2014 04:00	0.0	0	0	0	0	1
07/10/2014 05:00	0.0	0	0	0	0	1
07/10/2014 06:00	0.0	0	0	0	0	1
07/10/2014 07:00	0.0	0	0	0	0	1
07/10/2014 08:00	0.0	0	0	0	0	1
07/10/2014 09:00	0.0	0	0	0	0	1
07/10/2014 10:00	0.0	0	0	0	0	1
07/10/2014 11:00	0.0	0	0	0	0	1
07/10/2014 12:00	0.0	0	0	0	0	1
07/10/2014 13:00	0.0	0	0	0	0	1
07/10/2014 14:00	0.0	0	0	0	0	1
07/10/2014 15:00	0.0	0	0	0	0	1
07/10/2014 16:00	0.0	0	0	0	0	1
07/10/2014 17:00	0.0	0	0	0	0	1
07/10/2014 18:00	0.0	0	0	0	0	1
07/10/2014 19:00	0.0	0	0	0	0	1
07/10/2014 20:00	0.0	0	0	0	0	1
07/10/2014 21:00	0.0	0	0	0	0	1
07/10/2014 22:00	0.0	0	0	0	0	1
07/10/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/11/2014 00:00	0.0	0	0	0	0	1
07/11/2014 01:00	3.1	0	0	0	1	0
07/11/2014 02:00	0.0	0	0	0	0	0
07/11/2014 03:00	0.0	0	0	0	0	0
07/11/2014 04:00	0.0	0	0	0	0	0
07/11/2014 05:00	17.2	0	0	1	0	0
07/11/2014 06:00	28.8	0	0	1	0	0
07/11/2014 07:00	0.0	0	0	0	0	1
07/11/2014 08:00	0.0	0	0	0	0	1
07/11/2014 09:00	0.0	0	0	0	0	1
07/11/2014 10:00	0.0	0	0	0	0	1
07/11/2014 11:00	0.0	0	0	0	0	1
07/11/2014 12:00	0.0	0	0	0	0	1
07/11/2014 13:00	0.0	0	0	0	0	1
07/11/2014 14:00	0.0	0	0	0	0	1
07/11/2014 15:00	0.0	0	0	0	0	1
07/11/2014 16:00	0.0	0	0	0	0	1
07/11/2014 17:00	0.0	0	0	0	0	1
07/11/2014 18:00	0.0	0	0	0	0	1
07/11/2014 19:00	0.0	0	0	0	0	1
07/11/2014 20:00	0.0	0	0	0	0	1
07/11/2014 21:00	0.0	0	0	0	0	1
07/11/2014 22:00	0.0	0	0	0	0	1
07/11/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	49.1 #	0 #	0 #	2 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	28.8	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/12/2014 00:00	4.7	0	0	0	1	0
07/12/2014 01:00	0.0	0	0	0	0	0
07/12/2014 02:00	0.0	0	0	0	0	0
07/12/2014 03:00	0.0	0	0	0	0	0
07/12/2014 04:00	0.0	0	0	0	0	0
07/12/2014 05:00	0.0	0	0	0	0	0
07/12/2014 06:00	0.0	0	0	0	0	0
07/12/2014 07:00	0.0	0	0	0	0	0
07/12/2014 08:00	0.0	0	0	0	0	0
07/12/2014 09:00	0.0	0	0	0	0	0
07/12/2014 10:00	0.0	0	0	0	0	0
07/12/2014 11:00	36.5	0	1	0	0	0
07/12/2014 12:00	0.1	0	1	0	0	0
07/12/2014 13:00	0.0	0	0	0	0	1
07/12/2014 14:00	0.0	0	0	0	0	1
07/12/2014 15:00	0.0	0	0	0	0	1
07/12/2014 16:00	0.0	0	0	0	0	1
07/12/2014 17:00	0.0	0	0	0	0	1
07/12/2014 18:00	0.0	0	0	0	0	1
07/12/2014 19:00	0.0	0	0	0	0	1
07/12/2014 20:00	0.0	0	0	0	0	1
07/12/2014 21:00	0.0	0	0	0	0	1
07/12/2014 22:00	0.0	0	0	0	0	1
07/12/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	41.3 #	0 #	2 #	0 #	1 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	36.5	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/13/2014 00:00	0.0	0	0	0	0	1
07/13/2014 01:00	3.8	0	0	0	1	0
07/13/2014 02:00	0.0	0	0	0	0	0
07/13/2014 03:00	0.0	0	0	0	0	0
07/13/2014 04:00	0.0	0	0	0	0	0
07/13/2014 05:00	0.0	0	0	0	0	0
07/13/2014 06:00	15.2	0	0	1	0	0
07/13/2014 07:00	36.6	0	0	1	0	0
07/13/2014 08:00	0.0	0	0	0	0	1
07/13/2014 09:00	0.0	0	0	0	0	1
07/13/2014 10:00	0.0	0	0	0	0	1
07/13/2014 11:00	0.0	0	0	0	0	1
07/13/2014 12:00	0.0	0	0	0	0	1
07/13/2014 13:00	0.0	0	0	0	0	1
07/13/2014 14:00	0.0	0	0	0	0	1
07/13/2014 15:00	0.0	0	0	0	0	1
07/13/2014 16:00	0.0	0	0	0	0	1
07/13/2014 17:00	0.0	0	0	0	0	1
07/13/2014 18:00	0.0	0	0	0	0	1
07/13/2014 19:00	0.0	0	0	0	0	1
07/13/2014 20:00	0.0	0	0	0	0	1
07/13/2014 21:00	0.0	0	0	0	0	1
07/13/2014 22:00	0.0	0	0	0	0	1
07/13/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	55.6 #	0 #	0 #	2 #	1 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	36.6	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/14/2014 00:00	0.0	0	0	0	0	1
07/14/2014 01:00	0.0	0	0	0	0	1
07/14/2014 02:00	0.0	0	0	0	0	1
07/14/2014 03:00	0.0	0	0	0	0	1
07/14/2014 04:00	0.0	0	0	0	0	1
07/14/2014 05:00	0.0	0	0	0	0	1
07/14/2014 06:00	0.0	0	0	0	0	1
07/14/2014 07:00	0.0	0	0	0	0	1
07/14/2014 08:00	0.0	0	0	0	0	1
07/14/2014 09:00	0.0	0	0	0	0	1
07/14/2014 10:00	0.0	0	0	0	0	1
07/14/2014 11:00	0.0	0	0	0	0	1
07/14/2014 12:00	0.0	0	0	0	0	1
07/14/2014 13:00	0.0	0	0	0	0	1
07/14/2014 14:00	0.0	0	0	0	0	1
07/14/2014 15:00	0.0	0	0	0	0	1
07/14/2014 16:00	0.0	0	0	0	0	1
07/14/2014 17:00	0.0	0	0	0	0	1
07/14/2014 18:00	0.0	0	0	0	0	1
07/14/2014 19:00	0.0	0	0	0	0	1
07/14/2014 20:00	0.0	0	0	0	0	1
07/14/2014 21:00	0.0	0	0	0	0	1
07/14/2014 22:00	0.0	0	0	0	0	1
07/14/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/15/2014 00:00	0.0	0	0	0	0	1
07/15/2014 01:00	0.0	0	0	0	0	1
07/15/2014 02:00	0.0	0	0	0	0	1
07/15/2014 03:00	0.0	0	0	0	0	1
07/15/2014 04:00	0.0	0	0	0	0	1
07/15/2014 05:00	0.0	0	0	0	0	1
07/15/2014 06:00	0.0	0	0	0	0	1
07/15/2014 07:00	0.0	0	0	0	0	1
07/15/2014 08:00	0.0	0	0	0	0	1
07/15/2014 09:00	0.0	0	0	0	0	1
07/15/2014 10:00	0.0	0	0	0	0	1
07/15/2014 11:00	0.0	0	0	0	0	1
07/15/2014 12:00	0.0	0	0	0	0	1
07/15/2014 13:00	0.0	0	0	0	0	1
07/15/2014 14:00	0.0	0	0	0	0	1
07/15/2014 15:00	0.0	0	0	0	0	1
07/15/2014 16:00	0.0	0	0	0	0	1
07/15/2014 17:00	0.0	0	0	0	0	1
07/15/2014 18:00	0.0	0	0	0	0	1
07/15/2014 19:00	0.0	0	0	0	0	1
07/15/2014 20:00	0.0	0	0	0	0	1
07/15/2014 21:00	0.0	0	0	0	0	1
07/15/2014 22:00	0.0	0	0	0	0	1
07/15/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/16/2014 00:00	0.0	0	0	0	0	1
07/16/2014 01:00	0.0	0	0	0	0	1
07/16/2014 02:00	0.0	0	0	0	0	1
07/16/2014 03:00	0.0	0	0	0	0	1
07/16/2014 04:00	0.0	0	0	0	0	1
07/16/2014 05:00	0.0	0	0	0	0	1
07/16/2014 06:00	0.0	0	0	0	0	1
07/16/2014 07:00	0.0	0	0	0	0	1
07/16/2014 08:00	0.0	0	0	0	0	1
07/16/2014 09:00	0.0	0	0	0	0	1
07/16/2014 10:00	0.0	0	0	0	0	1
07/16/2014 11:00	0.0	0	0	0	0	1
07/16/2014 12:00	0.0	0	0	0	0	1
07/16/2014 13:00	0.0	0	0	0	0	1
07/16/2014 14:00	0.0	0	0	0	0	1
07/16/2014 15:00	0.0	0	0	0	0	1
07/16/2014 16:00	0.0	0	0	0	0	1
07/16/2014 17:00	0.0	0	0	0	0	1
07/16/2014 18:00	0.0	0	0	0	0	1
07/16/2014 19:00	0.0	0	0	0	0	1
07/16/2014 20:00	0.0	0	0	0	0	1
07/16/2014 21:00	0.0	0	0	0	0	1
07/16/2014 22:00	0.0	0	0	0	0	1
07/16/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/17/2014 00:00	3.6	0	0	0	1	0
07/17/2014 01:00	0.0	0	0	0	0	0
07/17/2014 02:00	0.0	0	0	0	0	0
07/17/2014 03:00	0.0	0	0	0	0	0
07/17/2014 04:00	0.0	0	0	0	0	0
07/17/2014 05:00	0.0	0	0	0	0	0
07/17/2014 06:00	0.0	0	0	0	0	0
07/17/2014 07:00	0.0	0	0	0	0	0
07/17/2014 08:00	11.1	0	1	0	0	0
07/17/2014 09:00	17.1	0	1	0	0	0
07/17/2014 10:00	0.0	0	0	0	0	1
07/17/2014 11:00	0.0	0	0	0	0	1
07/17/2014 12:00	0.0	0	0	0	0	1
07/17/2014 13:00	0.0	0	0	0	0	1
07/17/2014 14:00	0.0	0	0	0	0	1
07/17/2014 15:00	0.0	0	0	0	0	1
07/17/2014 16:00	0.0	0	0	0	0	1
07/17/2014 17:00	0.0	0	0	0	0	1
07/17/2014 18:00	0.0	0	0	0	0	1
07/17/2014 19:00	0.0	0	0	0	0	1
07/17/2014 20:00	0.0	0	0	0	0	1
07/17/2014 21:00	0.0	0	0	0	0	1
07/17/2014 22:00	0.0	0	0	0	0	1
07/17/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	31.8 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	17.1	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/18/2014 00:00	3.7	0	0	0	1	0
07/18/2014 01:00	0.0	0	0	0	0	0
07/18/2014 02:00	0.0	0	0	0	0	0
07/18/2014 03:00	0.0	0	0	0	0	0
07/18/2014 04:00	0.0	0	0	0	0	0
07/18/2014 05:00	0.0	0	0	0	0	0
07/18/2014 06:00	0.0	0	0	0	0	0
07/18/2014 07:00	0.0	0	0	0	0	0
07/18/2014 08:00	37.3	0	0	1	0	0
07/18/2014 09:00	0.1	0	0	1	0	0
07/18/2014 10:00	0.0	0	0	0	0	1
07/18/2014 11:00	0.0	0	0	0	0	1
07/18/2014 12:00	0.0	0	0	0	0	1
07/18/2014 13:00	0.0	0	0	0	0	1
07/18/2014 14:00	0.0	0	0	0	0	1
07/18/2014 15:00	0.0	0	0	0	0	1
07/18/2014 16:00	0.0	0	0	0	0	1
07/18/2014 17:00	0.0	0	0	0	0	1
07/18/2014 18:00	0.0	0	0	0	0	1
07/18/2014 19:00	0.0	0	0	0	0	1
07/18/2014 20:00	0.0	0	0	0	0	1
07/18/2014 21:00	0.0	0	0	0	0	1
07/18/2014 22:00	0.0	0	0	0	0	1
07/18/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	41.1 #	0 #	0 #	2 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	37.3	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/19/2014 00:00	3.1	0	0	0	1	0
07/19/2014 01:00	0.0	0	0	0	0	0
07/19/2014 02:00	0.0	0	0	0	0	0
07/19/2014 03:00	0.0	0	0	0	0	0
07/19/2014 04:00	0.0	0	0	0	0	0
07/19/2014 05:00	12.3	0	0	1	0	0
07/19/2014 06:00	28.9	0	0	1	0	0
07/19/2014 07:00	0.0	0	0	0	0	1
07/19/2014 08:00	0.0	0	0	0	0	1
07/19/2014 09:00	0.0	0	0	0	0	1
07/19/2014 10:00	0.0	0	0	0	0	1
07/19/2014 11:00	0.0	0	0	0	0	1
07/19/2014 12:00	0.0	0	0	0	0	1
07/19/2014 13:00	0.0	0	0	0	0	1
07/19/2014 14:00	0.0	0	0	0	0	1
07/19/2014 15:00	0.0	0	0	0	0	1
07/19/2014 16:00	0.0	0	0	0	0	1
07/19/2014 17:00	0.0	0	0	0	0	1
07/19/2014 18:00	0.0	0	0	0	0	1
07/19/2014 19:00	0.0	0	0	0	0	1
07/19/2014 20:00	0.0	0	0	0	0	1
07/19/2014 21:00	0.0	0	0	0	0	1
07/19/2014 22:00	0.0	0	0	0	0	1
07/19/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	44.3 #	0 #	0 #	2 #	1 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	28.9	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/20/2014 00:00	3.9	0	0	0	1	0
07/20/2014 01:00	0.0	0	0	0	0	0
07/20/2014 02:00	0.0	0	0	0	0	0
07/20/2014 03:00	0.0	0	0	0	0	0
07/20/2014 04:00	0.0	0	0	0	0	0
07/20/2014 05:00	0.0	0	0	0	0	0
07/20/2014 06:00	0.0	0	0	0	0	0
07/20/2014 07:00	0.0	0	0	0	0	0
07/20/2014 08:00	0.0	0	0	0	0	0
07/20/2014 09:00	0.0	0	0	0	0	0
07/20/2014 10:00	0.0	0	0	0	0	0
07/20/2014 11:00	0.0	0	0	0	0	0
07/20/2014 12:00	0.0	0	0	0	0	0
07/20/2014 13:00	0.0	0	0	0	0	0
07/20/2014 14:00	0.0	0	0	0	0	0
07/20/2014 15:00	0.0	0	0	0	0	0
07/20/2014 16:00	0.0	0	0	0	0	0
07/20/2014 17:00	0.0	0	0	0	0	0
07/20/2014 18:00	0.0	0	0	0	0	0
07/20/2014 19:00	0.0	0	0	0	0	0
07/20/2014 20:00	0.0	0	0	0	0	0
07/20/2014 21:00	0.0	0	0	0	0	0
07/20/2014 22:00	0.0	0	0	0	0	0
07/20/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	3.9 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3.9	0	0	0	1	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/21/2014 00:00	0.0	0	0	0	0	0
07/21/2014 01:00	0.0	0	0	0	0	0
07/21/2014 02:00	0.0	0	0	0	0	0
07/21/2014 03:00	0.0	0	0	0	0	0
07/21/2014 04:00	0.0	0	0	0	0	0
07/21/2014 05:00	0.0	0	0	0	0	0
07/21/2014 06:00	78.2	0	1	0	0	0
07/21/2014 07:00	19.6	0	1	0	0	0
07/21/2014 08:00	0.0	0	0	0	0	1
07/21/2014 09:00	0.0	0	0	0	0	1
07/21/2014 10:00	0.0	0	0	0	0	1
07/21/2014 11:00	0.0	0	0	0	0	1
07/21/2014 12:00	0.0	0	0	0	0	1
07/21/2014 13:00	0.0	0	0	0	0	1
07/21/2014 14:00	0.0	0	0	0	0	1
07/21/2014 15:00	0.0	0	0	0	0	1
07/21/2014 16:00	0.0	0	0	0	0	1
07/21/2014 17:00	0.0	0	0	0	0	1
07/21/2014 18:00	0.0	0	0	0	0	1
07/21/2014 19:00	0.0	0	0	0	0	1
07/21/2014 20:00	0.0	0	0	0	0	1
07/21/2014 21:00	0.0	0	0	0	0	1
07/21/2014 22:00	0.0	0	0	0	0	1
07/21/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	97.8 #	0 #	2 #	0 #	0 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	78.2	0	1	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/22/2014 00:00	0.0	0	0	0	0	1
07/22/2014 01:00	0.0	0	0	0	0	1
07/22/2014 02:00	0.0	0	0	0	0	1
07/22/2014 03:00	0.0	0	0	0	0	1
07/22/2014 04:00	0.0	0	0	0	0	1
07/22/2014 05:00	0.0	0	0	0	0	1
07/22/2014 06:00	0.0	0	0	0	0	1
07/22/2014 07:00	0.0	0	0	0	0	1
07/22/2014 08:00	0.0	0	0	0	0	1
07/22/2014 09:00	0.0	0	0	0	0	1
07/22/2014 10:00	0.0	0	0	0	0	1
07/22/2014 11:00	0.0	0	0	0	0	1
07/22/2014 12:00	0.0	0	0	0	0	1
07/22/2014 13:00	0.0	0	0	0	0	1
07/22/2014 14:00	0.0	0	0	0	0	1
07/22/2014 15:00	0.0	0	0	0	0	1
07/22/2014 16:00	0.0	0	0	0	0	1
07/22/2014 17:00	0.0	0	0	0	0	1
07/22/2014 18:00	0.0	0	0	0	0	1
07/22/2014 19:00	0.0	0	0	0	0	1
07/22/2014 20:00	0.0	0	0	0	0	1
07/22/2014 21:00	0.0	0	0	0	0	1
07/22/2014 22:00	0.0	0	0	0	0	1
07/22/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/23/2014 00:00	0.0	0	0	0	0	1
07/23/2014 01:00	0.0	0	0	0	0	1
07/23/2014 02:00	0.0	0	0	0	0	1
07/23/2014 03:00	0.0	0	0	0	0	1
07/23/2014 04:00	0.0	0	0	0	0	1
07/23/2014 05:00	0.0	0	0	0	0	1
07/23/2014 06:00	0.0	0	0	0	0	1
07/23/2014 07:00	0.0	0	0	0	0	1
07/23/2014 08:00	0.0	0	0	0	0	1
07/23/2014 09:00	0.0	0	0	0	0	1
07/23/2014 10:00	0.0	0	0	0	0	1
07/23/2014 11:00	0.0	0	0	0	0	1
07/23/2014 12:00	0.0	0	0	0	0	1
07/23/2014 13:00	0.0	0	0	0	0	1
07/23/2014 14:00	0.0	0	0	0	0	1
07/23/2014 15:00	0.0	0	0	0	0	1
07/23/2014 16:00	0.0	0	0	0	0	1
07/23/2014 17:00	0.0	0	0	0	0	1
07/23/2014 18:00	0.0	0	0	0	0	1
07/23/2014 19:00	0.0	0	0	0	0	1
07/23/2014 20:00	0.0	0	0	0	0	1
07/23/2014 21:00	0.0	0	0	0	0	1
07/23/2014 22:00	0.0	0	0	0	0	1
07/23/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/24/2014 00:00	0.0	0	0	0	0	1
07/24/2014 01:00	0.0	0	0	0	0	1
07/24/2014 02:00	0.0	0	0	0	0	1
07/24/2014 03:00	0.0	0	0	0	0	1
07/24/2014 04:00	0.0	0	0	0	0	1
07/24/2014 05:00	0.0	0	0	0	0	1
07/24/2014 06:00	0.0	0	0	0	0	1
07/24/2014 07:00	0.0	0	0	0	0	1
07/24/2014 08:00	0.0	0	0	0	0	1
07/24/2014 09:00	0.0	0	0	0	0	1
07/24/2014 10:00	0.0	0	0	0	0	1
07/24/2014 11:00	0.0	0	0	0	0	1
07/24/2014 12:00	0.0	0	0	0	0	1
07/24/2014 13:00	0.0	0	0	0	0	1
07/24/2014 14:00	0.0	0	0	0	0	1
07/24/2014 15:00	0.0	0	0	0	0	1
07/24/2014 16:00	0.0	0	0	0	0	1
07/24/2014 17:00	0.0	0	0	0	0	1
07/24/2014 18:00	0.0	0	0	0	0	1
07/24/2014 19:00	0.0	0	0	0	0	1
07/24/2014 20:00	0.0	0	0	0	0	1
07/24/2014 21:00	0.0	0	0	0	0	1
07/24/2014 22:00	0.0	0	0	0	0	1
07/24/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/25/2014 00:00	0.0	0	0	0	0	1
07/25/2014 01:00	0.0	0	0	0	0	1
07/25/2014 02:00	0.0	0	0	0	0	1
07/25/2014 03:00	0.0	0	0	0	0	1
07/25/2014 04:00	0.0	0	0	0	0	1
07/25/2014 05:00	0.0	0	0	0	0	1
07/25/2014 06:00	0.0	0	0	0	0	1
07/25/2014 07:00	0.0	0	0	0	0	1
07/25/2014 08:00	0.0	0	0	0	0	1
07/25/2014 09:00	0.0	0	0	0	0	1
07/25/2014 10:00	0.0	0	0	0	0	1
07/25/2014 11:00	0.0	0	0	0	0	1
07/25/2014 12:00	0.0	0	0	0	0	1
07/25/2014 13:00	0.0	0	0	0	0	1
07/25/2014 14:00	0.0	0	0	0	0	1
07/25/2014 15:00	0.0	0	0	0	0	1
07/25/2014 16:00	0.0	0	0	0	0	1
07/25/2014 17:00	0.0	0	0	0	0	1
07/25/2014 18:00	0.0	0	0	0	0	1
07/25/2014 19:00	0.0	0	0	0	0	1
07/25/2014 20:00	0.0	0	0	0	0	1
07/25/2014 21:00	0.0	0	0	0	0	1
07/25/2014 22:00	0.0	0	0	0	0	1
07/25/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/26/2014 00:00	0.0	0	0	0	0	1
07/26/2014 01:00	0.0	0	0	0	0	1
07/26/2014 02:00	0.0	0	0	0	0	1
07/26/2014 03:00	0.0	0	0	0	0	1
07/26/2014 04:00	0.0	0	0	0	0	1
07/26/2014 05:00	0.0	0	0	0	0	1
07/26/2014 06:00	0.0	0	0	0	0	1
07/26/2014 07:00	0.0	0	0	0	0	1
07/26/2014 08:00	0.0	0	0	0	0	1
07/26/2014 09:00	0.0	0	0	0	0	1
07/26/2014 10:00	0.0	0	0	0	0	1
07/26/2014 11:00	0.0	0	0	0	0	1
07/26/2014 12:00	0.0	0	0	0	0	1
07/26/2014 13:00	0.0	0	0	0	0	1
07/26/2014 14:00	0.0	0	0	0	0	1
07/26/2014 15:00	0.0	0	0	0	0	1
07/26/2014 16:00	0.0	0	0	0	0	1
07/26/2014 17:00	0.0	0	0	0	0	1
07/26/2014 18:00	0.0	0	0	0	0	1
07/26/2014 19:00	0.0	0	0	0	0	1
07/26/2014 20:00	0.0	0	0	0	0	1
07/26/2014 21:00	0.0	0	0	0	0	1
07/26/2014 22:00	0.0	0	0	0	0	1
07/26/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/27/2014 00:00	0.0	0	0	0	0	1
07/27/2014 01:00	0.0	0	0	0	0	1
07/27/2014 02:00	0.0	0	0	0	0	1
07/27/2014 03:00	0.0	0	0	0	0	1
07/27/2014 04:00	0.0	0	0	0	0	1
07/27/2014 05:00	0.0	0	0	0	0	1
07/27/2014 06:00	0.0	0	0	0	0	1
07/27/2014 07:00	0.0	0	0	0	0	1
07/27/2014 08:00	0.0	0	0	0	0	1
07/27/2014 09:00	0.0	0	0	0	0	1
07/27/2014 10:00	0.0	0	0	0	0	1
07/27/2014 11:00	0.0	0	0	0	0	1
07/27/2014 12:00	0.0	0	0	0	0	1
07/27/2014 13:00	0.0	0	0	0	0	1
07/27/2014 14:00	0.0	0	0	0	0	1
07/27/2014 15:00	0.0	0	0	0	0	1
07/27/2014 16:00	0.0	0	0	0	0	1
07/27/2014 17:00	0.0	0	0	0	0	1
07/27/2014 18:00	0.0	0	0	0	0	1
07/27/2014 19:00	0.0	0	0	0	0	1
07/27/2014 20:00	0.0	0	0	0	0	1
07/27/2014 21:00	0.0	0	0	0	0	1
07/27/2014 22:00	0.0	0	0	0	0	1
07/27/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/28/2014 00:00	0.0	0	0	0	0	1
07/28/2014 01:00	0.0	0	0	0	0	1
07/28/2014 02:00	0.0	0	0	0	0	1
07/28/2014 03:00	0.0	0	0	0	0	1
07/28/2014 04:00	0.0	0	0	0	0	1
07/28/2014 05:00	0.0	0	0	0	0	1
07/28/2014 06:00	0.0	0	0	0	0	1
07/28/2014 07:00	0.0	0	0	0	0	1
07/28/2014 08:00	0.0	0	0	0	0	1
07/28/2014 09:00	0.0	0	0	0	0	1
07/28/2014 10:00	0.0	0	0	0	0	1
07/28/2014 11:00	0.0	0	0	0	0	1
07/28/2014 12:00	0.0	0	0	0	0	1
07/28/2014 13:00	0.0	0	0	0	0	1
07/28/2014 14:00	0.0	0	0	0	0	1
07/28/2014 15:00	0.0	0	0	0	0	1
07/28/2014 16:00	0.0	0	0	0	0	1
07/28/2014 17:00	0.0	0	0	0	0	1
07/28/2014 18:00	0.0	0	0	0	0	1
07/28/2014 19:00	0.0	0	0	0	0	1
07/28/2014 20:00	0.0	0	0	0	0	1
07/28/2014 21:00	0.0	0	0	0	0	1
07/28/2014 22:00	0.0	0	0	0	0	1
07/28/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/29/2014 00:00	0.0	0	0	0	0	1
07/29/2014 01:00	0.0	0	0	0	0	1
07/29/2014 02:00	0.0	0	0	0	0	1
07/29/2014 03:00	0.0	0	0	0	0	1
07/29/2014 04:00	0.0	0	0	0	0	1
07/29/2014 05:00	0.0	0	0	0	0	1
07/29/2014 06:00	0.0	0	0	0	0	1
07/29/2014 07:00	0.0	0	0	0	0	1
07/29/2014 08:00	0.0	0	0	0	0	1
07/29/2014 09:00	0.0	0	0	0	0	1
07/29/2014 10:00	0.0	0	0	0	0	1
07/29/2014 11:00	0.0	0	0	0	0	1
07/29/2014 12:00	0.0	0	0	0	0	1
07/29/2014 13:00	0.0	0	0	0	0	1
07/29/2014 14:00	0.0	0	0	0	0	1
07/29/2014 15:00	0.0	0	0	0	0	1
07/29/2014 16:00	0.0	0	0	0	0	1
07/29/2014 17:00	0.0	0	0	0	0	1
07/29/2014 18:00	0.0	0	0	0	0	1
07/29/2014 19:00	0.0	0	0	0	0	1
07/29/2014 20:00	0.0	0	0	0	0	1
07/29/2014 21:00	0.0	0	0	0	0	1
07/29/2014 22:00	0.0	0	0	0	0	1
07/29/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/30/2014 00:00	0.0	0	0	0	0	1
07/30/2014 01:00	0.0	0	0	0	0	1
07/30/2014 02:00	0.0	0	0	0	0	1
07/30/2014 03:00	0.0	0	0	0	0	1
07/30/2014 04:00	0.0	0	0	0	0	1
07/30/2014 05:00	0.0	0	0	0	0	1
07/30/2014 06:00	0.0	0	0	0	0	1
07/30/2014 07:00	0.0	0	0	0	0	1
07/30/2014 08:00	0.0	0	0	0	0	1
07/30/2014 09:00	0.0	0	0	0	0	1
07/30/2014 10:00	0.0	0	0	0	0	1
07/30/2014 11:00	0.0	0	0	0	0	1
07/30/2014 12:00	0.0	0	0	0	0	1
07/30/2014 13:00	0.0	0	0	0	0	1
07/30/2014 14:00	0.0	0	0	0	0	1
07/30/2014 15:00	0.0	0	0	0	0	1
07/30/2014 16:00	0.0	0	0	0	0	1
07/30/2014 17:00	0.0	0	0	0	0	1
07/30/2014 18:00	0.0	0	0	0	0	1
07/30/2014 19:00	0.0	0	0	0	0	1
07/30/2014 20:00	0.0	0	0	0	0	1
07/30/2014 21:00	0.0	0	0	0	0	1
07/30/2014 22:00	0.0	0	0	0	0	1
07/30/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/31/2014 00:00	0.0	0	0	0	0	1
07/31/2014 01:00	0.0	0	0	0	0	1
07/31/2014 02:00	0.0	0	0	0	0	1
07/31/2014 03:00	0.0	0	0	0	0	1
07/31/2014 04:00	0.0	0	0	0	0	1
07/31/2014 05:00	0.0	0	0	0	0	1
07/31/2014 06:00	0.0	0	0	0	0	1
07/31/2014 07:00	0.0	0	0	0	0	1
07/31/2014 08:00	0.0	0	0	0	0	1
07/31/2014 09:00	0.0	0	0	0	0	1
07/31/2014 10:00	0.0	0	0	0	0	1
07/31/2014 11:00	0.0	0	0	0	0	1
07/31/2014 12:00	0.0	0	0	0	0	1
07/31/2014 13:00	0.0	0	0	0	0	1
07/31/2014 14:00	0.0	0	0	0	0	1
07/31/2014 15:00	0.0	0	0	0	0	1
07/31/2014 16:00	0.0	0	0	0	0	1
07/31/2014 17:00	0.0	0	0	0	0	1
07/31/2014 18:00	0.0	0	0	0	0	1
07/31/2014 19:00	0.0	0	0	0	0	1
07/31/2014 20:00	0.0	0	0	0	0	1
07/31/2014 21:00	0.0	0	0	0	0	1
07/31/2014 22:00	0.0	0	0	0	0	1
07/31/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/01/2014 00:00	0.0	0	0	0	0	1
08/01/2014 01:00	0.0	0	0	0	0	1
08/01/2014 02:00	0.0	0	0	0	0	1
08/01/2014 03:00	0.0	0	0	0	0	1
08/01/2014 04:00	0.0	0	0	0	0	1
08/01/2014 05:00	0.0	0	0	0	0	1
08/01/2014 06:00	0.0	0	0	0	0	1
08/01/2014 07:00	0.0	0	0	0	0	1
08/01/2014 08:00	0.0	0	0	0	0	1
08/01/2014 09:00	0.0	0	0	0	0	1
08/01/2014 10:00	0.0	0	0	0	0	1
08/01/2014 11:00	0.0	0	0	0	0	1
08/01/2014 12:00	0.0	0	0	0	0	1
08/01/2014 13:00	0.0	0	0	0	0	1
08/01/2014 14:00	0.0	0	0	0	0	1
08/01/2014 15:00	0.0	0	0	0	0	1
08/01/2014 16:00	0.0	0	0	0	0	1
08/01/2014 17:00	0.0	0	0	0	0	1
08/01/2014 18:00	0.0	0	0	0	0	1
08/01/2014 19:00	0.0	0	0	0	0	1
08/01/2014 20:00	0.0	0	0	0	0	1
08/01/2014 21:00	0.0	0	0	0	0	1
08/01/2014 22:00	0.0	0	0	0	0	1
08/01/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/02/2014 00:00	0.0	0	0	0	0	1
08/02/2014 01:00	0.0	0	0	0	0	1
08/02/2014 02:00	0.0	0	0	0	0	1
08/02/2014 03:00	0.0	0	0	0	0	1
08/02/2014 04:00	0.0	0	0	0	0	1
08/02/2014 05:00	0.0	0	0	0	0	1
08/02/2014 06:00	0.0	0	0	0	0	1
08/02/2014 07:00	0.0	0	0	0	0	1
08/02/2014 08:00	0.0	0	0	0	0	1
08/02/2014 09:00	0.0	0	0	0	0	1
08/02/2014 10:00	0.0	0	0	0	0	1
08/02/2014 11:00	0.0	0	0	0	0	1
08/02/2014 12:00	0.0	0	0	0	0	1
08/02/2014 13:00	0.0	0	0	0	0	1
08/02/2014 14:00	0.0	0	0	0	0	1
08/02/2014 15:00	0.0	0	0	0	0	1
08/02/2014 16:00	0.0	0	0	0	0	1
08/02/2014 17:00	0.0	0	0	0	0	1
08/02/2014 18:00	0.0	0	0	0	0	1
08/02/2014 19:00	0.0	0	0	0	0	1
08/02/2014 20:00	0.0	0	0	0	0	1
08/02/2014 21:00	0.0	0	0	0	0	1
08/02/2014 22:00	0.0	0	0	0	0	1
08/02/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/03/2014 00:00	0.0	0	0	0	0	1
08/03/2014 01:00	0.0	0	0	0	0	1
08/03/2014 02:00	0.0	0	0	0	0	1
08/03/2014 03:00	0.0	0	0	0	0	1
08/03/2014 04:00	0.0	0	0	0	0	1
08/03/2014 05:00	0.0	0	0	0	0	1
08/03/2014 06:00	0.0	0	0	0	0	1
08/03/2014 07:00	0.0	0	0	0	0	1
08/03/2014 08:00	0.0	0	0	0	0	1
08/03/2014 09:00	0.0	0	0	0	0	1
08/03/2014 10:00	0.0	0	0	0	0	1
08/03/2014 11:00	0.0	0	0	0	0	1
08/03/2014 12:00	0.0	0	0	0	0	1
08/03/2014 13:00	0.0	0	0	0	0	1
08/03/2014 14:00	0.0	0	0	0	0	1
08/03/2014 15:00	0.0	0	0	0	0	1
08/03/2014 16:00	0.0	0	0	0	0	1
08/03/2014 17:00	0.0	0	0	0	0	1
08/03/2014 18:00	0.0	0	0	0	0	1
08/03/2014 19:00	0.0	0	0	0	0	1
08/03/2014 20:00	0.0	0	0	0	0	1
08/03/2014 21:00	0.0	0	0	0	0	1
08/03/2014 22:00	0.0	0	0	0	0	1
08/03/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/04/2014 00:00	0.0	0	0	0	0	1
08/04/2014 01:00	0.0	0	0	0	0	1
08/04/2014 02:00	0.0	0	0	0	0	1
08/04/2014 03:00	0.0	0	0	0	0	1
08/04/2014 04:00	0.0	0	0	0	0	1
08/04/2014 05:00	0.0	0	0	0	0	1
08/04/2014 06:00	0.0	0	0	0	0	1
08/04/2014 07:00	0.0	0	0	0	0	1
08/04/2014 08:00	0.0	0	0	0	0	1
08/04/2014 09:00	0.0	0	0	0	0	1
08/04/2014 10:00	0.0	0	0	0	0	1
08/04/2014 11:00	0.0	0	0	0	0	1
08/04/2014 12:00	0.0	0	0	0	0	1
08/04/2014 13:00	0.0	0	0	0	0	1
08/04/2014 14:00	0.0	0	0	0	0	1
08/04/2014 15:00	0.0	0	0	0	0	1
08/04/2014 16:00	0.0	0	0	0	0	1
08/04/2014 17:00	0.0	0	0	0	0	1
08/04/2014 18:00	0.0	0	0	0	0	1
08/04/2014 19:00	0.0	0	0	0	0	1
08/04/2014 20:00	0.0	0	0	0	0	1
08/04/2014 21:00	0.0	0	0	0	0	1
08/04/2014 22:00	0.0	0	0	0	0	1
08/04/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/05/2014 00:00	0.0	0	0	0	0	1
08/05/2014 01:00	0.0	0	0	0	0	1
08/05/2014 02:00	0.0	0	0	0	0	1
08/05/2014 03:00	0.0	0	0	0	0	1
08/05/2014 04:00	0.0	0	0	0	0	1
08/05/2014 05:00	0.0	0	0	0	0	1
08/05/2014 06:00	0.0	0	0	0	0	1
08/05/2014 07:00	0.0	0	0	0	0	1
08/05/2014 08:00	0.0	0	0	0	0	1
08/05/2014 09:00	0.0	0	0	0	0	1
08/05/2014 10:00	0.0	0	0	0	0	1
08/05/2014 11:00	0.0	0	0	0	0	1
08/05/2014 12:00	0.0	0	0	0	0	1
08/05/2014 13:00	0.0	0	0	0	0	1
08/05/2014 14:00	0.0	0	0	0	0	1
08/05/2014 15:00	0.0	0	0	0	0	1
08/05/2014 16:00	0.0	0	0	0	0	1
08/05/2014 17:00	0.0	0	0	0	0	1
08/05/2014 18:00	0.0	0	0	0	0	1
08/05/2014 19:00	0.0	0	0	0	0	1
08/05/2014 20:00	0.0	0	0	0	0	1
08/05/2014 21:00	0.0	0	0	0	0	1
08/05/2014 22:00	0.0	0	0	0	0	1
08/05/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/06/2014 00:00	0.0	0	0	0	0	1
08/06/2014 01:00	0.0	0	0	0	0	1
08/06/2014 02:00	0.0	0	0	0	0	1
08/06/2014 03:00	0.0	0	0	0	0	1
08/06/2014 04:00	0.0	0	0	0	0	1
08/06/2014 05:00	0.0	0	0	0	0	1
08/06/2014 06:00	0.0	0	0	0	0	1
08/06/2014 07:00	0.0	0	0	0	0	1
08/06/2014 08:00	0.0	0	0	0	0	1
08/06/2014 09:00	0.0	0	0	0	0	1
08/06/2014 10:00	0.0	0	0	0	0	1
08/06/2014 11:00	0.0	0	0	0	0	1
08/06/2014 12:00	0.0	0	0	0	0	1
08/06/2014 13:00	0.0	0	0	0	0	1
08/06/2014 14:00	0.0	0	0	0	0	1
08/06/2014 15:00	0.0	0	0	0	0	1
08/06/2014 16:00	0.0	0	0	0	0	1
08/06/2014 17:00	0.0	0	0	0	0	1
08/06/2014 18:00	0.0	0	0	0	0	1
08/06/2014 19:00	0.0	0	0	0	0	1
08/06/2014 20:00	0.0	0	0	0	0	1
08/06/2014 21:00	0.0	0	0	0	0	1
08/06/2014 22:00	0.0	0	0	0	0	1
08/06/2014 23:00	3.3	0	0	0	1	0
Average/Sum#:	3.3 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3.3	0	0	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/07/2014 00:00	0.0	0	0	0	0	0
08/07/2014 01:00	0.0	0	0	0	0	0
08/07/2014 02:00	0.0	0	0	0	0	0
08/07/2014 03:00	0.0	0	0	0	0	0
08/07/2014 04:00	0.0	0	0	0	0	0
08/07/2014 05:00	0.0	0	0	0	0	0
08/07/2014 06:00	0.0	0	0	0	0	0
08/07/2014 07:00	0.0	0	0	0	0	0
08/07/2014 08:00	0.0	0	0	0	0	0
08/07/2014 09:00	0.0	0	0	0	0	0
08/07/2014 10:00	0.0	0	0	0	0	0
08/07/2014 11:00	0.0	0	0	0	0	0
08/07/2014 12:00	0.0	0	0	0	0	0
08/07/2014 13:00	293.3	0	1	0	0	0
08/07/2014 14:00	49.1	0	0	1	0	0
08/07/2014 15:00	0.2	0	0	1	0	0
08/07/2014 16:00	0.0	0	0	0	0	1
08/07/2014 17:00	0.0	0	0	0	0	1
08/07/2014 18:00	0.0	0	0	0	0	1
08/07/2014 19:00	0.0	0	0	0	0	1
08/07/2014 20:00	0.0	0	0	0	0	1
08/07/2014 21:00	0.0	0	0	0	0	1
08/07/2014 22:00	0.0	0	0	0	0	1
08/07/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	342.6 #	0 #	1 #	2 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	293.3	0	1	1	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/08/2014 00:00	0.0	0	0	0	0	1
08/08/2014 01:00	0.0	0	0	0	0	1
08/08/2014 02:00	0.0	0	0	0	0	1
08/08/2014 03:00	0.0	0	0	0	0	1
08/08/2014 04:00	0.0	0	0	0	0	1
08/08/2014 05:00	0.0	0	0	0	0	1
08/08/2014 06:00	0.0	0	0	0	0	1
08/08/2014 07:00	0.0	0	0	0	0	1
08/08/2014 08:00	0.0	0	0	0	0	1
08/08/2014 09:00	0.0	0	0	0	0	1
08/08/2014 10:00	0.0	0	0	0	0	1
08/08/2014 11:00	0.0	0	0	0	0	1
08/08/2014 12:00	0.0	0	0	0	0	1
08/08/2014 13:00	0.0	0	0	0	0	1
08/08/2014 14:00	0.0	0	0	0	0	1
08/08/2014 15:00	0.0	0	0	0	0	1
08/08/2014 16:00	0.0	0	0	0	0	1
08/08/2014 17:00	0.0	0	0	0	0	1
08/08/2014 18:00	0.0	0	0	0	0	1
08/08/2014 19:00	0.0	0	0	0	0	1
08/08/2014 20:00	0.0	0	0	0	0	1
08/08/2014 21:00	0.0	0	0	0	0	1
08/08/2014 22:00	0.0	0	0	0	0	1
08/08/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/09/2014 00:00	0.0	0	0	0	0	1
08/09/2014 01:00	0.0	0	0	0	0	1
08/09/2014 02:00	3.3	0	0	0	1	0
08/09/2014 03:00	0.0	0	0	0	0	0
08/09/2014 04:00	0.0	0	0	0	0	0
08/09/2014 05:00	0.0	0	0	0	0	0
08/09/2014 06:00	0.0	0	0	0	0	0
08/09/2014 07:00	0.0	0	0	0	0	0
08/09/2014 08:00	0.0	0	0	0	0	0
08/09/2014 09:00	0.0	0	0	0	0	0
08/09/2014 10:00	25.9	0	1	0	0	0
08/09/2014 11:00	2.8	0	1	0	0	0
08/09/2014 12:00	0.0	0	0	0	0	1
08/09/2014 13:00	0.0	0	0	0	0	1
08/09/2014 14:00	0.0	0	0	0	0	1
08/09/2014 15:00	0.0	0	0	0	0	1
08/09/2014 16:00	0.0	0	0	0	0	1
08/09/2014 17:00	0.0	0	0	0	0	1
08/09/2014 18:00	0.0	0	0	0	0	1
08/09/2014 19:00	0.0	0	0	0	0	1
08/09/2014 20:00	0.0	0	0	0	0	1
08/09/2014 21:00	0.0	0	0	0	0	1
08/09/2014 22:00	0.0	0	0	0	0	1
08/09/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	32.0 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	25.9	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/10/2014 00:00	3.4	0	0	0	1	0
08/10/2014 01:00	0.0	0	0	0	0	0
08/10/2014 02:00	0.0	0	0	0	0	0
08/10/2014 03:00	0.0	0	0	0	0	0
08/10/2014 04:00	0.0	0	0	0	0	0
08/10/2014 05:00	0.0	0	0	0	0	0
08/10/2014 06:00	0.0	0	0	0	0	0
08/10/2014 07:00	0.0	0	0	0	0	0
08/10/2014 08:00	0.0	0	0	0	0	0
08/10/2014 09:00	0.0	0	0	0	0	0
08/10/2014 10:00	0.0	0	0	0	0	0
08/10/2014 11:00	45.9	0	1	0	0	0
08/10/2014 12:00	5.6	0	1	0	0	0
08/10/2014 13:00	0.0	0	0	0	0	1
08/10/2014 14:00	0.0	0	0	0	0	1
08/10/2014 15:00	0.0	0	0	0	0	1
08/10/2014 16:00	0.0	0	0	0	0	1
08/10/2014 17:00	0.0	0	0	0	0	1
08/10/2014 18:00	0.0	0	0	0	0	1
08/10/2014 19:00	0.0	0	0	0	0	1
08/10/2014 20:00	0.0	0	0	0	0	1
08/10/2014 21:00	0.0	0	0	0	0	1
08/10/2014 22:00	0.0	0	0	0	0	1
08/10/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	54.9 #	0 #	2 #	0 #	1 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	45.9	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/11/2014 00:00	0.0	0	0	0	0	1
08/11/2014 01:00	0.0	0	0	0	0	1
08/11/2014 02:00	0.0	0	0	0	0	1
08/11/2014 03:00	0.0	0	0	0	0	1
08/11/2014 04:00	0.0	0	0	0	0	1
08/11/2014 05:00	0.0	0	0	0	0	1
08/11/2014 06:00	0.0	0	0	0	0	1
08/11/2014 07:00	0.0	0	0	0	0	1
08/11/2014 08:00	0.0	0	0	0	0	1
08/11/2014 09:00	0.0	0	0	0	0	1
08/11/2014 10:00	0.0	0	0	0	0	1
08/11/2014 11:00	0.0	0	0	0	0	1
08/11/2014 12:00	0.0	0	0	0	0	1
08/11/2014 13:00	0.0	0	0	0	0	1
08/11/2014 14:00	0.0	0	0	0	0	1
08/11/2014 15:00	0.0	0	0	0	0	1
08/11/2014 16:00	0.0	0	0	0	0	1
08/11/2014 17:00	0.0	0	0	0	0	1
08/11/2014 18:00	0.0	0	0	0	0	1
08/11/2014 19:00	0.0	0	0	0	0	1
08/11/2014 20:00	0.0	0	0	0	0	1
08/11/2014 21:00	0.0	0	0	0	0	1
08/11/2014 22:00	0.0	0	0	0	0	1
08/11/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/12/2014 00:00	0.0	0	0	0	0	1
08/12/2014 01:00	0.0	0	0	0	0	1
08/12/2014 02:00	0.0	0	0	0	0	1
08/12/2014 03:00	0.0	0	0	0	0	1
08/12/2014 04:00	0.0	0	0	0	0	1
08/12/2014 05:00	0.0	0	0	0	0	1
08/12/2014 06:00	0.0	0	0	0	0	1
08/12/2014 07:00	0.0	0	0	0	0	1
08/12/2014 08:00	0.0	0	0	0	0	1
08/12/2014 09:00	0.0	0	0	0	0	1
08/12/2014 10:00	0.0	0	0	0	0	1
08/12/2014 11:00	0.0	0	0	0	0	1
08/12/2014 12:00	0.0	0	0	0	0	1
08/12/2014 13:00	0.0	0	0	0	0	1
08/12/2014 14:00	0.0	0	0	0	0	1
08/12/2014 15:00	0.0	0	0	0	0	1
08/12/2014 16:00	0.0	0	0	0	0	1
08/12/2014 17:00	0.0	0	0	0	0	1
08/12/2014 18:00	0.0	0	0	0	0	1
08/12/2014 19:00	0.0	0	0	0	0	1
08/12/2014 20:00	0.0	0	0	0	0	1
08/12/2014 21:00	0.0	0	0	0	0	1
08/12/2014 22:00	0.0	0	0	0	0	1
08/12/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/13/2014 00:00	0.0	0	0	0	0	1
08/13/2014 01:00	1.8	0	0	0	1	0
08/13/2014 02:00	0.0	0	0	0	0	0
08/13/2014 03:00	0.0	0	0	0	0	0
08/13/2014 04:00	0.0	0	0	0	0	0
08/13/2014 05:00	0.0	0	0	0	0	0
08/13/2014 06:00	0.0	0	0	0	0	0
08/13/2014 07:00	0.0	0	0	0	0	0
08/13/2014 08:00	15.9	0	0	1	0	0
08/13/2014 09:00	15.2	0	0	1	0	0
08/13/2014 10:00	0.0	0	0	0	0	1
08/13/2014 11:00	0.0	0	0	0	0	1
08/13/2014 12:00	0.0	0	0	0	0	1
08/13/2014 13:00	0.0	0	0	0	0	1
08/13/2014 14:00	0.0	0	0	0	0	1
08/13/2014 15:00	0.0	0	0	0	0	1
08/13/2014 16:00	0.0	0	0	0	0	1
08/13/2014 17:00	0.0	0	0	0	0	1
08/13/2014 18:00	0.0	0	0	0	0	1
08/13/2014 19:00	0.0	0	0	0	0	1
08/13/2014 20:00	0.0	0	0	0	0	1
08/13/2014 21:00	0.0	0	0	0	0	1
08/13/2014 22:00	0.0	0	0	0	0	1
08/13/2014 23:00	2.6	0	0	0	1	0
Average/Sum#:	35.5 #	0 #	0 #	2 #	2 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	15.9	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/14/2014 00:00	0.0	0	0	0	0	0
08/14/2014 01:00	0.0	0	0	0	0	0
08/14/2014 02:00	0.0	0	0	0	0	0
08/14/2014 03:00	0.0	0	0	0	0	0
08/14/2014 04:00	0.0	0	0	0	0	0
08/14/2014 05:00	0.0	0	0	0	0	0
08/14/2014 06:00	0.0	0	0	0	0	0
08/14/2014 07:00	0.0	0	0	0	0	0
08/14/2014 08:00	0.0	0	0	0	0	0
08/14/2014 09:00	0.0	0	0	0	0	0
08/14/2014 10:00	0.0	0	0	0	0	0
08/14/2014 11:00	0.0	0	0	0	0	0
08/14/2014 12:00	0.0	0	0	0	0	0
08/14/2014 13:00	0.0	0	0	0	0	0
08/14/2014 14:00	0.0	0	0	0	0	0
08/14/2014 15:00	0.0	0	0	0	0	0
08/14/2014 16:00	0.0	0	0	0	0	0
08/14/2014 17:00	0.0	0	0	0	0	0
08/14/2014 18:00	0.0	0	0	0	0	0
08/14/2014 19:00	0.0	0	0	0	0	0
08/14/2014 20:00	0.0	0	0	0	0	0
08/14/2014 21:00	0.0	0	0	0	0	0
08/14/2014 22:00	0.0	0	0	0	0	0
08/14/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/15/2014 00:00	0.0	0	0	0	0	0
08/15/2014 01:00	0.0	0	0	0	0	0
08/15/2014 02:00	0.0	0	0	0	0	0
08/15/2014 03:00	0.0	0	0	0	0	0
08/15/2014 04:00	0.0	0	0	0	0	0
08/15/2014 05:00	0.0	0	0	0	0	0
08/15/2014 06:00	0.0	0	0	0	0	0
08/15/2014 07:00	0.0	0	0	0	0	0
08/15/2014 08:00	0.0	0	0	0	0	0
08/15/2014 09:00	0.0	0	0	0	0	0
08/15/2014 10:00	0.0	0	0	0	0	0
08/15/2014 11:00	0.0	0	0	0	0	0
08/15/2014 12:00	0.0	0	0	0	0	0
08/15/2014 13:00	0.0	0	0	0	0	0
08/15/2014 14:00	0.0	0	0	0	0	0
08/15/2014 15:00	0.0	0	0	0	0	0
08/15/2014 16:00	0.0	0	0	0	0	0
08/15/2014 17:00	0.0	0	0	0	0	0
08/15/2014 18:00	0.0	0	0	0	0	0
08/15/2014 19:00	0.0	0	0	0	0	0
08/15/2014 20:00	0.0	0	0	0	0	0
08/15/2014 21:00	0.0	0	0	0	0	0
08/15/2014 22:00	0.0	0	0	0	0	0
08/15/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/16/2014 00:00	0.0	0	0	0	0	0
08/16/2014 01:00	0.0	0	0	0	0	0
08/16/2014 02:00	0.0	0	0	0	0	0
08/16/2014 03:00	0.0	0	0	0	0	0
08/16/2014 04:00	0.0	0	0	0	0	0
08/16/2014 05:00	0.0	0	0	0	0	0
08/16/2014 06:00	0.0	0	0	0	0	0
08/16/2014 07:00	0.0	0	0	0	0	0
08/16/2014 08:00	0.0	0	0	0	0	0
08/16/2014 09:00	0.0	0	0	0	0	0
08/16/2014 10:00	0.0	0	0	0	0	0
08/16/2014 11:00	0.0	0	0	0	0	0
08/16/2014 12:00	0.0	0	0	0	0	0
08/16/2014 13:00	0.0	0	0	0	0	0
08/16/2014 14:00	0.0	0	0	0	0	0
08/16/2014 15:00	0.0	0	0	0	0	0
08/16/2014 16:00	0.0	0	0	0	0	0
08/16/2014 17:00	0.0	0	0	0	0	0
08/16/2014 18:00	0.0	0	0	0	0	0
08/16/2014 19:00	0.0	0	0	0	0	0
08/16/2014 20:00	0.0	0	0	0	0	0
08/16/2014 21:00	0.0	0	0	0	0	0
08/16/2014 22:00	0.0	0	0	0	0	0
08/16/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/17/2014 00:00	0.0	0	0	0	0	0
08/17/2014 01:00	0.0	0	0	0	0	0
08/17/2014 02:00	0.0	0	0	0	0	0
08/17/2014 03:00	0.0	0	0	0	0	0
08/17/2014 04:00	0.0	0	0	0	0	0
08/17/2014 05:00	0.0	0	0	0	0	0
08/17/2014 06:00	0.0	0	0	0	0	0
08/17/2014 07:00	0.0	0	0	0	0	0
08/17/2014 08:00	0.0	0	0	0	0	0
08/17/2014 09:00	0.0	0	0	0	0	0
08/17/2014 10:00	0.0	0	0	0	0	0
08/17/2014 11:00	0.0	0	0	0	0	0
08/17/2014 12:00	0.0	0	0	0	0	0
08/17/2014 13:00	0.0	0	0	0	0	0
08/17/2014 14:00	0.0	0	0	0	0	0
08/17/2014 15:00	0.0	0	0	0	0	0
08/17/2014 16:00	0.0	0	0	0	0	0
08/17/2014 17:00	0.0	0	0	0	0	0
08/17/2014 18:00	0.0	0	0	0	0	0
08/17/2014 19:00	0.0	0	0	0	0	0
08/17/2014 20:00	0.0	0	0	0	0	0
08/17/2014 21:00	0.0	0	0	0	0	0
08/17/2014 22:00	0.0	0	0	0	0	0
08/17/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/18/2014 00:00	0.0	0	0	0	0	0
08/18/2014 01:00	0.0	0	0	0	0	0
08/18/2014 02:00	0.0	0	0	0	0	0
08/18/2014 03:00	0.0	0	0	0	0	0
08/18/2014 04:00	0.0	0	0	0	0	0
08/18/2014 05:00	0.0	0	0	0	0	0
08/18/2014 06:00	0.0	0	0	0	0	0
08/18/2014 07:00	0.0	0	0	0	0	0
08/18/2014 08:00	0.0	0	0	0	0	0
08/18/2014 09:00	0.0	0	0	0	0	0
08/18/2014 10:00	0.0	0	0	0	0	0
08/18/2014 11:00	0.0	0	0	0	0	0
08/18/2014 12:00	0.0	0	0	0	0	0
08/18/2014 13:00	0.0	0	0	0	0	0
08/18/2014 14:00	0.0	0	0	0	0	0
08/18/2014 15:00	0.0	0	0	0	0	0
08/18/2014 16:00	0.0	0	0	0	0	0
08/18/2014 17:00	0.0	0	0	0	0	0
08/18/2014 18:00	0.0	0	0	0	0	0
08/18/2014 19:00	0.0	0	0	0	0	0
08/18/2014 20:00	0.0	0	0	0	0	0
08/18/2014 21:00	0.0	0	0	0	0	0
08/18/2014 22:00	0.0	0	0	0	0	0
08/18/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/19/2014 00:00	0.0	0	0	0	0	0
08/19/2014 01:00	0.0	0	0	0	0	0
08/19/2014 02:00	0.0	0	0	0	0	0
08/19/2014 03:00	0.0	0	0	0	0	0
08/19/2014 04:00	0.0	0	0	0	0	0
08/19/2014 05:00	0.0	0	0	0	0	0
08/19/2014 06:00	0.0	0	0	0	0	0
08/19/2014 07:00	0.0	0	0	0	0	0
08/19/2014 08:00	0.0	0	0	0	0	0
08/19/2014 09:00	0.0	0	0	0	0	0
08/19/2014 10:00	0.0	0	0	0	0	0
08/19/2014 11:00	0.0	0	0	0	0	0
08/19/2014 12:00	0.0	0	0	0	0	0
08/19/2014 13:00	0.0	0	0	0	0	0
08/19/2014 14:00	0.0	0	0	0	0	0
08/19/2014 15:00	0.0	0	0	0	0	0
08/19/2014 16:00	0.0	0	0	0	0	0
08/19/2014 17:00	0.0	0	0	0	0	0
08/19/2014 18:00	0.0	0	0	0	0	0
08/19/2014 19:00	0.0	0	0	0	0	0
08/19/2014 20:00	0.0	0	0	0	0	0
08/19/2014 21:00	0.0	0	0	0	0	0
08/19/2014 22:00	0.0	0	0	0	0	0
08/19/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/20/2014 00:00	0.0	0	0	0	0	0
08/20/2014 01:00	0.0	0	0	0	0	0
08/20/2014 02:00	0.0	0	0	0	0	0
08/20/2014 03:00	0.0	0	0	0	0	0
08/20/2014 04:00	0.0	0	0	0	0	0
08/20/2014 05:00	0.0	0	0	0	0	0
08/20/2014 06:00	0.0	0	0	0	0	0
08/20/2014 07:00	0.0	0	0	0	0	0
08/20/2014 08:00	0.0	0	0	0	0	0
08/20/2014 09:00	0.0	0	0	0	0	0
08/20/2014 10:00	0.0	0	0	0	0	0
08/20/2014 11:00	0.0	0	0	0	0	0
08/20/2014 12:00	0.0	0	0	0	0	0
08/20/2014 13:00	0.0	0	0	0	0	0
08/20/2014 14:00	0.0	0	0	0	0	0
08/20/2014 15:00	0.0	0	0	0	0	0
08/20/2014 16:00	0.0	0	0	0	0	0
08/20/2014 17:00	0.0	0	0	0	0	0
08/20/2014 18:00	0.0	0	0	0	0	0
08/20/2014 19:00	0.0	0	0	0	0	0
08/20/2014 20:00	0.0	0	0	0	0	0
08/20/2014 21:00	0.0	0	0	0	0	0
08/20/2014 22:00	0.0	0	0	0	0	0
08/20/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/21/2014 00:00	0.0	0	0	0	0	0
08/21/2014 01:00	0.0	0	0	0	0	0
08/21/2014 02:00	0.0	0	0	0	0	0
08/21/2014 03:00	0.0	0	0	0	0	0
08/21/2014 04:00	0.0	0	0	0	0	0
08/21/2014 05:00	0.0	0	0	0	0	0
08/21/2014 06:00	0.0	0	0	0	0	0
08/21/2014 07:00	0.0	0	0	0	0	0
08/21/2014 08:00	0.0	0	0	0	0	0
08/21/2014 09:00	0.0	0	0	0	0	0
08/21/2014 10:00	0.0	0	0	0	0	0
08/21/2014 11:00	0.0	0	0	0	0	0
08/21/2014 12:00	0.0	0	0	0	0	0
08/21/2014 13:00	0.0	0	0	0	0	0
08/21/2014 14:00	0.0	0	0	0	0	0
08/21/2014 15:00	0.0	0	0	0	0	0
08/21/2014 16:00	0.0	0	0	0	0	0
08/21/2014 17:00	0.0	0	0	0	0	0
08/21/2014 18:00	0.0	0	0	0	0	0
08/21/2014 19:00	0.0	0	0	0	0	0
08/21/2014 20:00	0.0	0	0	0	0	0
08/21/2014 21:00	0.0	0	0	0	0	0
08/21/2014 22:00	0.0	0	0	0	0	0
08/21/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/22/2014 00:00	0.0	0	0	0	0	0
08/22/2014 01:00	0.0	0	0	0	0	0
08/22/2014 02:00	0.0	0	0	0	0	0
08/22/2014 03:00	0.0	0	0	0	0	0
08/22/2014 04:00	0.0	0	0	0	0	0
08/22/2014 05:00	0.0	0	0	0	0	0
08/22/2014 06:00	0.0	0	0	0	0	0
08/22/2014 07:00	0.0	0	0	0	0	0
08/22/2014 08:00	0.0	0	0	0	0	0
08/22/2014 09:00	0.0	0	0	0	0	0
08/22/2014 10:00	0.0	0	0	0	0	0
08/22/2014 11:00	0.0	0	0	0	0	0
08/22/2014 12:00	0.0	0	0	0	0	0
08/22/2014 13:00	0.0	0	0	0	0	0
08/22/2014 14:00	0.0	0	0	0	0	0
08/22/2014 15:00	0.0	0	0	0	0	0
08/22/2014 16:00	0.0	0	0	0	0	0
08/22/2014 17:00	0.0	0	0	0	0	0
08/22/2014 18:00	0.0	0	0	0	0	0
08/22/2014 19:00	0.0	0	0	0	0	0
08/22/2014 20:00	0.0	0	0	0	0	0
08/22/2014 21:00	0.0	0	0	0	0	0
08/22/2014 22:00	0.0	0	0	0	0	0
08/22/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/23/2014 00:00	0.0	0	0	0	0	0
08/23/2014 01:00	0.0	0	0	0	0	0
08/23/2014 02:00	0.0	0	0	0	0	0
08/23/2014 03:00	0.0	0	0	0	0	0
08/23/2014 04:00	0.0	0	0	0	0	0
08/23/2014 05:00	0.0	0	0	0	0	0
08/23/2014 06:00	0.0	0	0	0	0	0
08/23/2014 07:00	0.0	0	0	0	0	0
08/23/2014 08:00	0.0	0	0	0	0	0
08/23/2014 09:00	0.0	0	0	0	0	0
08/23/2014 10:00	0.0	0	0	0	0	0
08/23/2014 11:00	0.0	0	0	0	0	0
08/23/2014 12:00	0.0	0	0	0	0	0
08/23/2014 13:00	0.0	0	0	0	0	0
08/23/2014 14:00	0.0	0	0	0	0	0
08/23/2014 15:00	0.0	0	0	0	0	0
08/23/2014 16:00	0.0	0	0	0	0	0
08/23/2014 17:00	0.0	0	0	0	0	0
08/23/2014 18:00	0.0	0	0	0	0	0
08/23/2014 19:00	0.0	0	0	0	0	0
08/23/2014 20:00	0.0	0	0	0	0	0
08/23/2014 21:00	0.0	0	0	0	0	0
08/23/2014 22:00	0.0	0	0	0	0	0
08/23/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/24/2014 00:00	0.0	0	0	0	0	0
08/24/2014 01:00	0.0	0	0	0	0	0
08/24/2014 02:00	0.0	0	0	0	0	0
08/24/2014 03:00	0.0	0	0	0	0	0
08/24/2014 04:00	0.0	0	0	0	0	0
08/24/2014 05:00	0.0	0	0	0	0	0
08/24/2014 06:00	0.0	0	0	0	0	0
08/24/2014 07:00	0.0	0	0	0	0	0
08/24/2014 08:00	0.0	0	0	0	0	0
08/24/2014 09:00	0.0	0	0	0	0	0
08/24/2014 10:00	0.0	0	0	0	0	0
08/24/2014 11:00	0.0	0	0	0	0	0
08/24/2014 12:00	0.0	0	0	0	0	0
08/24/2014 13:00	0.0	0	0	0	0	0
08/24/2014 14:00	0.0	0	0	0	0	0
08/24/2014 15:00	0.0	0	0	0	0	0
08/24/2014 16:00	0.0	0	0	0	0	0
08/24/2014 17:00	0.0	0	0	0	0	0
08/24/2014 18:00	0.0	0	0	0	0	0
08/24/2014 19:00	0.0	0	0	0	0	0
08/24/2014 20:00	0.0	0	0	0	0	0
08/24/2014 21:00	0.0	0	0	0	0	0
08/24/2014 22:00	0.0	0	0	0	0	0
08/24/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/25/2014 00:00	0.0	0	0	0	0	0
08/25/2014 01:00	0.0	0	0	0	0	0
08/25/2014 02:00	0.0	0	0	0	0	0
08/25/2014 03:00	0.0	0	0	0	0	0
08/25/2014 04:00	0.0	0	0	0	0	0
08/25/2014 05:00	0.0	0	0	0	0	0
08/25/2014 06:00	0.0	0	0	0	0	0
08/25/2014 07:00	0.0	0	0	0	0	0
08/25/2014 08:00	0.0	0	0	0	0	0
08/25/2014 09:00	0.0	0	0	0	0	0
08/25/2014 10:00	0.0	0	0	0	0	0
08/25/2014 11:00	0.0	0	0	0	0	0
08/25/2014 12:00	0.0	0	0	0	0	0
08/25/2014 13:00	0.0	0	0	0	0	0
08/25/2014 14:00	0.0	0	0	0	0	0
08/25/2014 15:00	0.0	0	0	0	0	0
08/25/2014 16:00	0.0	0	0	0	0	0
08/25/2014 17:00	0.0	0	0	0	0	0
08/25/2014 18:00	0.0	0	0	0	0	0
08/25/2014 19:00	0.0	0	0	0	0	0
08/25/2014 20:00	0.0	0	0	0	0	0
08/25/2014 21:00	0.0	0	0	0	0	0
08/25/2014 22:00	0.0	0	0	0	0	0
08/25/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/26/2014 00:00	0.0	0	0	0	0	0
08/26/2014 01:00	0.0	0	0	0	0	0
08/26/2014 02:00	0.0	0	0	0	0	0
08/26/2014 03:00	0.0	0	0	0	0	0
08/26/2014 04:00	0.0	0	0	0	0	0
08/26/2014 05:00	0.0	0	0	0	0	0
08/26/2014 06:00	0.0	0	0	0	0	0
08/26/2014 07:00	0.0	0	0	0	0	0
08/26/2014 08:00	0.0	0	0	0	0	0
08/26/2014 09:00	0.0	0	0	0	0	0
08/26/2014 10:00	0.0	0	0	0	0	0
08/26/2014 11:00	0.0	0	0	0	0	0
08/26/2014 12:00	0.0	0	0	0	0	0
08/26/2014 13:00	0.0	0	0	0	0	0
08/26/2014 14:00	0.0	0	0	0	0	0
08/26/2014 15:00	0.0	0	0	0	0	0
08/26/2014 16:00	0.0	0	0	0	0	0
08/26/2014 17:00	0.0	0	0	0	0	0
08/26/2014 18:00	0.0	0	0	0	0	0
08/26/2014 19:00	0.0	0	0	0	0	0
08/26/2014 20:00	0.0	0	0	0	0	0
08/26/2014 21:00	0.0	0	0	0	0	0
08/26/2014 22:00	0.0	0	0	0	0	0
08/26/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/27/2014 00:00	0.0	0	0	0	0	0
08/27/2014 01:00	0.0	0	0	0	0	0
08/27/2014 02:00	0.0	0	0	0	0	0
08/27/2014 03:00	0.0	0	0	0	0	0
08/27/2014 04:00	0.0	0	0	0	0	0
08/27/2014 05:00	0.0	0	0	0	0	0
08/27/2014 06:00	0.0	0	0	0	0	0
08/27/2014 07:00	0.0	0	0	0	0	0
08/27/2014 08:00	0.0	0	0	0	0	0
08/27/2014 09:00	0.0	0	0	0	0	0
08/27/2014 10:00	0.0	0	0	0	0	0
08/27/2014 11:00	0.0	0	0	0	0	0
08/27/2014 12:00	0.0	0	0	0	0	0
08/27/2014 13:00	0.0	0	0	0	0	0
08/27/2014 14:00	0.0	0	0	0	0	0
08/27/2014 15:00	0.0	0	0	0	0	0
08/27/2014 16:00	0.0	0	0	0	0	0
08/27/2014 17:00	0.0	0	0	0	0	0
08/27/2014 18:00	0.0	0	0	0	0	0
08/27/2014 19:00	0.0	0	0	0	0	0
08/27/2014 20:00	0.0	0	0	0	0	0
08/27/2014 21:00	0.0	0	0	0	0	0
08/27/2014 22:00	0.0	0	0	0	0	0
08/27/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/28/2014 00:00	0.0	0	0	0	0	0
08/28/2014 01:00	0.0	0	0	0	0	0
08/28/2014 02:00	0.0	0	0	0	0	0
08/28/2014 03:00	0.0	0	0	0	0	0
08/28/2014 04:00	0.0	0	0	0	0	0
08/28/2014 05:00	0.0	0	0	0	0	0
08/28/2014 06:00	0.0	0	0	0	0	0
08/28/2014 07:00	0.0	0	0	0	0	0
08/28/2014 08:00	0.0	0	0	0	0	0
08/28/2014 09:00	0.0	0	0	0	0	0
08/28/2014 10:00	0.0	0	0	0	0	0
08/28/2014 11:00	0.0	0	0	0	0	0
08/28/2014 12:00	0.0	0	0	0	0	0
08/28/2014 13:00	0.0	0	0	0	0	0
08/28/2014 14:00	0.0	0	0	0	0	0
08/28/2014 15:00	0.0	0	0	0	0	0
08/28/2014 16:00	0.0	0	0	0	0	0
08/28/2014 17:00	0.0	0	0	0	0	0
08/28/2014 18:00	0.0	0	0	0	0	0
08/28/2014 19:00	0.0	0	0	0	0	0
08/28/2014 20:00	0.0	0	0	0	0	0
08/28/2014 21:00	0.0	0	0	0	0	0
08/28/2014 22:00	0.0	0	0	0	0	0
08/28/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/29/2014 00:00	0.0	0	0	0	0	0
08/29/2014 01:00	0.0	0	0	0	0	0
08/29/2014 02:00	0.0	0	0	0	0	0
08/29/2014 03:00	0.0	0	0	0	0	0
08/29/2014 04:00	0.0	0	0	0	0	0
08/29/2014 05:00	0.0	0	0	0	0	0
08/29/2014 06:00	0.0	0	0	0	0	0
08/29/2014 07:00	0.0	0	0	0	0	0
08/29/2014 08:00	0.0	0	0	0	0	0
08/29/2014 09:00	0.0	0	0	0	0	0
08/29/2014 10:00	0.0	0	0	0	0	0
08/29/2014 11:00	0.0	0	0	0	0	0
08/29/2014 12:00	0.0	0	0	0	0	0
08/29/2014 13:00	0.0	0	0	0	0	0
08/29/2014 14:00	0.0	0	0	0	0	0
08/29/2014 15:00	0.0	0	0	0	0	0
08/29/2014 16:00	0.0	0	0	0	0	0
08/29/2014 17:00	0.0	0	0	0	0	0
08/29/2014 18:00	0.0	0	0	0	0	0
08/29/2014 19:00	0.0	0	0	0	0	0
08/29/2014 20:00	0.0	0	0	0	0	0
08/29/2014 21:00	0.0	0	0	0	0	0
08/29/2014 22:00	0.0	0	0	0	0	0
08/29/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/30/2014 00:00	0.0	0	0	0	0	0
08/30/2014 01:00	0.0	0	0	0	0	0
08/30/2014 02:00	0.0	0	0	0	0	0
08/30/2014 03:00	0.0	0	0	0	0	0
08/30/2014 04:00	0.0	0	0	0	0	0
08/30/2014 05:00	0.0	0	0	0	0	0
08/30/2014 06:00	0.0	0	0	0	0	0
08/30/2014 07:00	0.0	0	0	0	0	0
08/30/2014 08:00	0.0	0	0	0	0	0
08/30/2014 09:00	0.0	0	0	0	0	0
08/30/2014 10:00	0.0	0	0	0	0	0
08/30/2014 11:00	0.0	0	0	0	0	0
08/30/2014 12:00	0.0	0	0	0	0	0
08/30/2014 13:00	0.0	0	0	0	0	0
08/30/2014 14:00	0.0	0	0	0	0	0
08/30/2014 15:00	0.0	0	0	0	0	0
08/30/2014 16:00	0.0	0	0	0	0	0
08/30/2014 17:00	0.0	0	0	0	0	0
08/30/2014 18:00	0.0	0	0	0	0	0
08/30/2014 19:00	0.0	0	0	0	0	0
08/30/2014 20:00	0.0	0	0	0	0	0
08/30/2014 21:00	0.0	0	0	0	0	0
08/30/2014 22:00	0.0	0	0	0	0	0
08/30/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/31/2014 00:00	0.0	0	0	0	0	0
08/31/2014 01:00	0.0	0	0	0	0	0
08/31/2014 02:00	0.0	0	0	0	0	0
08/31/2014 03:00	0.0	0	0	0	0	0
08/31/2014 04:00	0.0	0	0	0	0	0
08/31/2014 05:00	0.0	0	0	0	0	0
08/31/2014 06:00	0.0	0	0	0	0	0
08/31/2014 07:00	0.0	0	0	0	0	0
08/31/2014 08:00	0.0	0	0	0	0	0
08/31/2014 09:00	0.0	0	0	0	0	0
08/31/2014 10:00	0.0	0	0	0	0	0
08/31/2014 11:00	0.0	0	0	0	0	0
08/31/2014 12:00	0.0	0	0	0	0	0
08/31/2014 13:00	0.0	0	0	0	0	0
08/31/2014 14:00	0.0	0	0	0	0	0
08/31/2014 15:00	0.0	0	0	0	0	0
08/31/2014 16:00	0.0	0	0	0	0	0
08/31/2014 17:00	0.0	0	0	0	0	0
08/31/2014 18:00	0.0	0	0	0	0	0
08/31/2014 19:00	0.0	0	0	0	0	0
08/31/2014 20:00	0.0	0	0	0	0	0
08/31/2014 21:00	0.0	0	0	0	0	0
08/31/2014 22:00	0.0	0	0	0	0	0
08/31/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/01/2014 00:00	0.0	0	0	0	0	0
09/01/2014 01:00	0.0	0	0	0	0	0
09/01/2014 02:00	0.0	0	0	0	0	0
09/01/2014 03:00	0.0	0	0	0	0	0
09/01/2014 04:00	0.0	0	0	0	0	0
09/01/2014 05:00	0.0	0	0	0	0	0
09/01/2014 06:00	0.0	0	0	0	0	0
09/01/2014 07:00	0.0	0	0	0	0	0
09/01/2014 08:00	0.0	0	0	0	0	0
09/01/2014 09:00	0.0	0	0	0	0	0
09/01/2014 10:00	0.0	0	0	0	0	0
09/01/2014 11:00	0.0	0	0	0	0	0
09/01/2014 12:00	0.0	0	0	0	0	0
09/01/2014 13:00	0.0	0	0	0	0	0
09/01/2014 14:00	0.0	0	0	0	0	0
09/01/2014 15:00	0.0	0	0	0	0	0
09/01/2014 16:00	0.0	0	0	0	0	0
09/01/2014 17:00	0.0	0	0	0	0	0
09/01/2014 18:00	0.0	0	0	0	0	0
09/01/2014 19:00	0.0	0	0	0	0	0
09/01/2014 20:00	0.0	0	0	0	0	0
09/01/2014 21:00	0.0	0	0	0	0	0
09/01/2014 22:00	0.0	0	0	0	0	0
09/01/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/02/2014 00:00	0.0	0	0	0	0	0
09/02/2014 01:00	0.0	0	0	0	0	0
09/02/2014 02:00	0.0	0	0	0	0	0
09/02/2014 03:00	0.0	0	0	0	0	0
09/02/2014 04:00	0.0	0	0	0	0	0
09/02/2014 05:00	0.0	0	0	0	0	0
09/02/2014 06:00	0.0	0	0	0	0	0
09/02/2014 07:00	0.0	0	0	0	0	0
09/02/2014 08:00	0.0	0	0	0	0	0
09/02/2014 09:00	0.0	0	0	0	0	0
09/02/2014 10:00	0.0	0	0	0	0	0
09/02/2014 11:00	0.0	0	0	0	0	0
09/02/2014 12:00	0.0	0	0	0	0	0
09/02/2014 13:00	0.0	0	0	0	0	0
09/02/2014 14:00	0.0	0	0	0	0	0
09/02/2014 15:00	0.0	0	0	0	0	0
09/02/2014 16:00	0.0	0	0	0	0	0
09/02/2014 17:00	0.0	0	0	0	0	0
09/02/2014 18:00	0.0	0	0	0	0	0
09/02/2014 19:00	0.0	0	0	0	0	0
09/02/2014 20:00	0.0	0	0	0	0	0
09/02/2014 21:00	0.0	0	0	0	0	0
09/02/2014 22:00	0.0	0	0	0	0	0
09/02/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/03/2014 00:00	0.0	0	0	0	0	0
09/03/2014 01:00	0.0	0	0	0	0	0
09/03/2014 02:00	0.0	0	0	0	0	0
09/03/2014 03:00	0.0	0	0	0	0	0
09/03/2014 04:00	0.0	0	0	0	0	0
09/03/2014 05:00	0.0	0	0	0	0	0
09/03/2014 06:00	0.0	0	0	0	0	0
09/03/2014 07:00	0.0	0	0	0	0	0
09/03/2014 08:00	0.0	0	0	0	0	0
09/03/2014 09:00	0.0	0	0	0	0	0
09/03/2014 10:00	0.0	0	0	0	0	0
09/03/2014 11:00	0.0	0	0	0	0	0
09/03/2014 12:00	0.0	0	0	0	0	0
09/03/2014 13:00	0.0	0	0	0	0	0
09/03/2014 14:00	0.0	0	0	0	0	0
09/03/2014 15:00	0.0	0	0	0	0	0
09/03/2014 16:00	0.0	0	0	0	0	0
09/03/2014 17:00	0.0	0	0	0	0	0
09/03/2014 18:00	0.0	0	0	0	0	0
09/03/2014 19:00	0.0	0	0	0	0	0
09/03/2014 20:00	0.0	0	0	0	0	0
09/03/2014 21:00	0.0	0	0	0	0	0
09/03/2014 22:00	0.0	0	0	0	0	0
09/03/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/04/2014 00:00	0.0	0	0	0	0	0
09/04/2014 01:00	0.0	0	0	0	0	0
09/04/2014 02:00	0.0	0	0	0	0	0
09/04/2014 03:00	0.0	0	0	0	0	0
09/04/2014 04:00	0.0	0	0	0	0	0
09/04/2014 05:00	0.0	0	0	0	0	0
09/04/2014 06:00	0.0	0	0	0	0	0
09/04/2014 07:00	0.0	0	0	0	0	0
09/04/2014 08:00	0.0	0	0	0	0	0
09/04/2014 09:00	0.0	0	0	0	0	0
09/04/2014 10:00	0.0	0	0	0	0	0
09/04/2014 11:00	0.0	0	0	0	0	0
09/04/2014 12:00	0.0	0	0	0	0	0
09/04/2014 13:00	0.0	0	0	0	0	0
09/04/2014 14:00	0.0	0	0	0	0	0
09/04/2014 15:00	0.0	0	0	0	0	0
09/04/2014 16:00	0.0	0	0	0	0	0
09/04/2014 17:00	0.0	0	0	0	0	0
09/04/2014 18:00	0.0	0	0	0	0	0
09/04/2014 19:00	0.0	0	0	0	0	0
09/04/2014 20:00	0.0	0	0	0	0	0
09/04/2014 21:00	0.0	0	0	0	0	0
09/04/2014 22:00	0.0	0	0	0	0	0
09/04/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/05/2014 00:00	0.0	0	0	0	0	0
09/05/2014 01:00	0.0	0	0	0	0	0
09/05/2014 02:00	0.0	0	0	0	0	0
09/05/2014 03:00	0.0	0	0	0	0	0
09/05/2014 04:00	0.0	0	0	0	0	0
09/05/2014 05:00	0.0	0	0	0	0	0
09/05/2014 06:00	0.0	0	0	0	0	0
09/05/2014 07:00	79.5	1	0	0	0	0
09/05/2014 08:00	32.2	1	0	0	0	0
09/05/2014 09:00	0.0	0	0	0	0	1
09/05/2014 10:00	0.0	0	0	0	0	1
09/05/2014 11:00	0.0	0	0	0	0	1
09/05/2014 12:00	0.0	0	0	0	0	1
09/05/2014 13:00	0.0	0	0	0	0	1
09/05/2014 14:00	0.0	0	0	0	0	1
09/05/2014 15:00	0.0	0	0	0	0	1
09/05/2014 16:00	0.0	0	0	0	0	1
09/05/2014 17:00	0.0	0	0	0	0	1
09/05/2014 18:00	0.0	0	0	0	0	1
09/05/2014 19:00	0.0	0	0	0	0	1
09/05/2014 20:00	0.0	0	0	0	0	1
09/05/2014 21:00	0.0	0	0	0	0	1
09/05/2014 22:00	0.0	0	0	0	0	1
09/05/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	111.7 #	2 #	0 #	0 #	0 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	79.5	1	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/06/2014 00:00	0.0	0	0	0	0	1
09/06/2014 01:00	0.0	0	0	0	0	1
09/06/2014 02:00	0.0	0	0	0	0	1
09/06/2014 03:00	0.0	0	0	0	0	1
09/06/2014 04:00	0.0	0	0	0	0	1
09/06/2014 05:00	0.0	0	0	0	0	1
09/06/2014 06:00	0.0	0	0	0	0	1
09/06/2014 07:00	0.0	0	0	0	0	1
09/06/2014 08:00	0.0	0	0	0	0	1
09/06/2014 09:00	0.0	0	0	0	0	1
09/06/2014 10:00	0.0	0	0	0	0	1
09/06/2014 11:00	0.0	0	0	0	0	1
09/06/2014 12:00	0.0	0	0	0	0	1
09/06/2014 13:00	0.0	0	0	0	0	1
09/06/2014 14:00	0.0	0	0	0	0	1
09/06/2014 15:00	0.0	0	0	0	0	1
09/06/2014 16:00	0.0	0	0	0	0	1
09/06/2014 17:00	0.0	0	0	0	0	1
09/06/2014 18:00	0.0	0	0	0	0	1
09/06/2014 19:00	0.0	0	0	0	0	1
09/06/2014 20:00	0.0	0	0	0	0	1
09/06/2014 21:00	0.0	0	0	0	0	1
09/06/2014 22:00	0.0	0	0	0	0	1
09/06/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/07/2014 00:00	0.0	0	0	0	0	1
09/07/2014 01:00	0.0	0	0	0	0	1
09/07/2014 02:00	0.0	0	0	0	0	1
09/07/2014 03:00	0.0	0	0	0	0	1
09/07/2014 04:00	0.0	0	0	0	0	1
09/07/2014 05:00	0.0	0	0	0	0	1
09/07/2014 06:00	0.0	0	0	0	0	1
09/07/2014 07:00	0.0	0	0	0	0	1
09/07/2014 08:00	0.0	0	0	0	0	1
09/07/2014 09:00	0.0	0	0	0	0	1
09/07/2014 10:00	0.0	0	0	0	0	1
09/07/2014 11:00	0.0	0	0	0	0	1
09/07/2014 12:00	0.0	0	0	0	0	1
09/07/2014 13:00	0.0	0	0	0	0	1
09/07/2014 14:00	0.0	0	0	0	0	1
09/07/2014 15:00	0.0	0	0	0	0	1
09/07/2014 16:00	0.0	0	0	0	0	1
09/07/2014 17:00	0.0	0	0	0	0	1
09/07/2014 18:00	0.0	0	0	0	0	1
09/07/2014 19:00	0.0	0	0	0	0	1
09/07/2014 20:00	0.0	0	0	0	0	1
09/07/2014 21:00	0.0	0	0	0	0	1
09/07/2014 22:00	0.0	0	0	0	0	1
09/07/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/08/2014 00:00	0.0	0	0	0	0	1
09/08/2014 01:00	0.0	0	0	0	0	1
09/08/2014 02:00	0.0	0	0	0	0	1
09/08/2014 03:00	0.0	0	0	0	0	1
09/08/2014 04:00	0.0	0	0	0	0	1
09/08/2014 05:00	0.0	0	0	0	0	1
09/08/2014 06:00	0.0	0	0	0	0	1
09/08/2014 07:00	0.0	0	0	0	0	1
09/08/2014 08:00	0.0	0	0	0	0	1
09/08/2014 09:00	0.0	0	0	0	0	1
09/08/2014 10:00	0.0	0	0	0	0	1
09/08/2014 11:00	0.0	0	0	0	0	1
09/08/2014 12:00	0.0	0	0	0	0	1
09/08/2014 13:00	0.0	0	0	0	0	1
09/08/2014 14:00	0.0	0	0	0	0	1
09/08/2014 15:00	0.0	0	0	0	0	1
09/08/2014 16:00	0.0	0	0	0	0	1
09/08/2014 17:00	0.0	0	0	0	0	1
09/08/2014 18:00	0.0	0	0	0	0	1
09/08/2014 19:00	0.0	0	0	0	0	1
09/08/2014 20:00	0.0	0	0	0	0	1
09/08/2014 21:00	0.0	0	0	0	0	1
09/08/2014 22:00	0.0	0	0	0	0	1
09/08/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/09/2014 00:00	0.0	0	0	0	0	1
09/09/2014 01:00	0.0	0	0	0	0	1
09/09/2014 02:00	0.0	0	0	0	0	1
09/09/2014 03:00	0.0	0	0	0	0	1
09/09/2014 04:00	0.0	0	0	0	0	1
09/09/2014 05:00	0.0	0	0	0	0	1
09/09/2014 06:00	0.0	0	0	0	0	1
09/09/2014 07:00	0.0	0	0	0	0	1
09/09/2014 08:00	0.0	0	0	0	0	1
09/09/2014 09:00	0.0	0	0	0	0	1
09/09/2014 10:00	0.0	0	0	0	0	1
09/09/2014 11:00	0.0	0	0	0	0	1
09/09/2014 12:00	0.0	0	0	0	0	1
09/09/2014 13:00	0.0	0	0	0	0	1
09/09/2014 14:00	0.0	0	0	0	0	1
09/09/2014 15:00	0.0	0	0	0	0	1
09/09/2014 16:00	0.0	0	0	0	0	1
09/09/2014 17:00	0.0	0	0	0	0	1
09/09/2014 18:00	0.0	0	0	0	0	1
09/09/2014 19:00	0.0	0	0	0	0	1
09/09/2014 20:00	0.0	0	0	0	0	1
09/09/2014 21:00	0.0	0	0	0	0	1
09/09/2014 22:00	0.0	0	0	0	0	1
09/09/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/10/2014 00:00	0.0	0	0	0	0	1
09/10/2014 01:00	0.0	0	0	0	0	1
09/10/2014 02:00	0.0	0	0	0	0	1
09/10/2014 03:00	0.0	0	0	0	0	1
09/10/2014 04:00	0.0	0	0	0	0	1
09/10/2014 05:00	0.0	0	0	0	0	1
09/10/2014 06:00	0.0	0	0	0	0	1
09/10/2014 07:00	0.0	0	0	0	0	1
09/10/2014 08:00	0.0	0	0	0	0	1
09/10/2014 09:00	0.0	0	0	0	0	1
09/10/2014 10:00	0.0	0	0	0	0	1
09/10/2014 11:00	0.0	0	0	0	0	1
09/10/2014 12:00	0.0	0	0	0	0	1
09/10/2014 13:00	0.0	0	0	0	0	1
09/10/2014 14:00	0.0	0	0	0	0	1
09/10/2014 15:00	0.0	0	0	0	0	1
09/10/2014 16:00	0.0	0	0	0	0	1
09/10/2014 17:00	0.0	0	0	0	0	1
09/10/2014 18:00	0.0	0	0	0	0	1
09/10/2014 19:00	0.0	0	0	0	0	1
09/10/2014 20:00	0.0	0	0	0	0	1
09/10/2014 21:00	0.0	0	0	0	0	1
09/10/2014 22:00	0.0	0	0	0	0	1
09/10/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/11/2014 00:00	0.0	0	0	0	0	1
09/11/2014 01:00	0.0	0	0	0	0	1
09/11/2014 02:00	0.0	0	0	0	0	1
09/11/2014 03:00	0.0	0	0	0	0	1
09/11/2014 04:00	0.0	0	0	0	0	1
09/11/2014 05:00	0.0	0	0	0	0	1
09/11/2014 06:00	0.0	0	0	0	0	1
09/11/2014 07:00	0.0	0	0	0	0	1
09/11/2014 08:00	0.0	0	0	0	0	1
09/11/2014 09:00	0.0	0	0	0	0	1
09/11/2014 10:00	0.0	0	0	0	0	1
09/11/2014 11:00	0.0	0	0	0	0	1
09/11/2014 12:00	0.0	0	0	0	0	1
09/11/2014 13:00	0.0	0	0	0	0	1
09/11/2014 14:00	0.0	0	0	0	0	1
09/11/2014 15:00	0.0	0	0	0	0	1
09/11/2014 16:00	0.0	0	0	0	0	1
09/11/2014 17:00	0.0	0	0	0	0	1
09/11/2014 18:00	0.0	0	0	0	0	1
09/11/2014 19:00	0.0	0	0	0	0	1
09/11/2014 20:00	0.0	0	0	0	0	1
09/11/2014 21:00	0.0	0	0	0	0	1
09/11/2014 22:00	0.0	0	0	0	0	1
09/11/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/12/2014 00:00	0.0	0	0	0	0	1
09/12/2014 01:00	0.0	0	0	0	0	1
09/12/2014 02:00	0.0	0	0	0	0	1
09/12/2014 03:00	0.0	0	0	0	0	1
09/12/2014 04:00	0.0	0	0	0	0	1
09/12/2014 05:00	0.0	0	0	0	0	1
09/12/2014 06:00	0.0	0	0	0	0	1
09/12/2014 07:00	0.0	0	0	0	0	1
09/12/2014 08:00	0.0	0	0	0	0	1
09/12/2014 09:00	0.0	0	0	0	0	1
09/12/2014 10:00	0.0	0	0	0	0	1
09/12/2014 11:00	0.0	0	0	0	0	1
09/12/2014 12:00	0.0	0	0	0	0	1
09/12/2014 13:00	0.0	0	0	0	0	1
09/12/2014 14:00	0.0	0	0	0	0	1
09/12/2014 15:00	0.0	0	0	0	0	1
09/12/2014 16:00	0.0	0	0	0	0	1
09/12/2014 17:00	0.0	0	0	0	0	1
09/12/2014 18:00	0.0	0	0	0	0	1
09/12/2014 19:00	0.0	0	0	0	0	1
09/12/2014 20:00	0.0	0	0	0	0	1
09/12/2014 21:00	0.0	0	0	0	0	1
09/12/2014 22:00	0.0	0	0	0	0	1
09/12/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/13/2014 00:00	0.0	0	0	0	0	1
09/13/2014 01:00	0.0	0	0	0	0	1
09/13/2014 02:00	0.0	0	0	0	0	1
09/13/2014 03:00	0.0	0	0	0	0	1
09/13/2014 04:00	0.0	0	0	0	0	1
09/13/2014 05:00	0.0	0	0	0	0	1
09/13/2014 06:00	0.0	0	0	0	0	1
09/13/2014 07:00	0.0	0	0	0	0	1
09/13/2014 08:00	0.0	0	0	0	0	1
09/13/2014 09:00	0.0	0	0	0	0	1
09/13/2014 10:00	0.0	0	0	0	0	1
09/13/2014 11:00	0.0	0	0	0	0	1
09/13/2014 12:00	0.0	0	0	0	0	1
09/13/2014 13:00	0.0	0	0	0	0	1
09/13/2014 14:00	0.0	0	0	0	0	1
09/13/2014 15:00	0.0	0	0	0	0	1
09/13/2014 16:00	0.0	0	0	0	0	1
09/13/2014 17:00	0.0	0	0	0	0	1
09/13/2014 18:00	0.0	0	0	0	0	1
09/13/2014 19:00	0.0	0	0	0	0	1
09/13/2014 20:00	0.0	0	0	0	0	1
09/13/2014 21:00	0.0	0	0	0	0	1
09/13/2014 22:00	0.0	0	0	0	0	1
09/13/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/14/2014 00:00	0.0	0	0	0	0	1
09/14/2014 01:00	0.0	0	0	0	0	1
09/14/2014 02:00	0.0	0	0	0	0	1
09/14/2014 03:00	0.0	0	0	0	0	1
09/14/2014 04:00	0.0	0	0	0	0	1
09/14/2014 05:00	0.0	0	0	0	0	1
09/14/2014 06:00	0.0	0	0	0	0	1
09/14/2014 07:00	0.0	0	0	0	0	1
09/14/2014 08:00	0.0	0	0	0	0	1
09/14/2014 09:00	0.0	0	0	0	0	1
09/14/2014 10:00	0.0	0	0	0	0	1
09/14/2014 11:00	0.0	0	0	0	0	1
09/14/2014 12:00	0.0	0	0	0	0	1
09/14/2014 13:00	0.0	0	0	0	0	1
09/14/2014 14:00	0.0	0	0	0	0	1
09/14/2014 15:00	0.0	0	0	0	0	1
09/14/2014 16:00	0.0	0	0	0	0	1
09/14/2014 17:00	0.0	0	0	0	0	1
09/14/2014 18:00	0.0	0	0	0	0	1
09/14/2014 19:00	0.0	0	0	0	0	1
09/14/2014 20:00	0.0	0	0	0	0	1
09/14/2014 21:00	0.0	0	0	0	0	1
09/14/2014 22:00	0.0	0	0	0	0	1
09/14/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/15/2014 00:00	0.0	0	0	0	0	1
09/15/2014 01:00	0.0	0	0	0	0	1
09/15/2014 02:00	0.0	0	0	0	0	1
09/15/2014 03:00	0.0	0	0	0	0	1
09/15/2014 04:00	0.0	0	0	0	0	1
09/15/2014 05:00	0.0	0	0	0	0	1
09/15/2014 06:00	0.0	0	0	0	0	1
09/15/2014 07:00	0.0	0	0	0	0	1
09/15/2014 08:00	0.0	0	0	0	0	1
09/15/2014 09:00	0.0	0	0	0	0	1
09/15/2014 10:00	0.0	0	0	0	0	1
09/15/2014 11:00	0.0	0	0	0	0	1
09/15/2014 12:00	0.0	0	0	0	0	1
09/15/2014 13:00	0.0	0	0	0	0	1
09/15/2014 14:00	0.0	0	0	0	0	1
09/15/2014 15:00	0.0	0	0	0	0	1
09/15/2014 16:00	0.0	0	0	0	0	1
09/15/2014 17:00	0.0	0	0	0	0	1
09/15/2014 18:00	0.0	0	0	0	0	1
09/15/2014 19:00	0.0	0	0	0	0	1
09/15/2014 20:00	0.0	0	0	0	0	1
09/15/2014 21:00	0.0	0	0	0	0	1
09/15/2014 22:00	0.0	0	0	0	0	1
09/15/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/16/2014 00:00	0.0	0	0	0	0	1
09/16/2014 01:00	0.0	0	0	0	0	1
09/16/2014 02:00	0.0	0	0	0	0	1
09/16/2014 03:00	0.0	0	0	0	0	1
09/16/2014 04:00	0.0	0	0	0	0	1
09/16/2014 05:00	0.0	0	0	0	0	1
09/16/2014 06:00	0.0	0	0	0	0	1
09/16/2014 07:00	0.0	0	0	0	0	1
09/16/2014 08:00	0.0	0	0	0	0	1
09/16/2014 09:00	0.0	0	0	0	0	1
09/16/2014 10:00	0.0	0	0	0	0	1
09/16/2014 11:00	0.0	0	0	0	0	1
09/16/2014 12:00	0.0	0	0	0	0	1
09/16/2014 13:00	0.0	0	0	0	0	1
09/16/2014 14:00	0.0	0	0	0	0	1
09/16/2014 15:00	0.0	0	0	0	0	1
09/16/2014 16:00	0.0	0	0	0	0	1
09/16/2014 17:00	0.0	0	0	0	0	1
09/16/2014 18:00	0.0	0	0	0	0	1
09/16/2014 19:00	0.0	0	0	0	0	1
09/16/2014 20:00	0.0	0	0	0	0	1
09/16/2014 21:00	0.0	0	0	0	0	1
09/16/2014 22:00	0.0	0	0	0	0	1
09/16/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/17/2014 00:00	0.0	0	0	0	0	1
09/17/2014 01:00	0.0	0	0	0	0	1
09/17/2014 02:00	0.0	0	0	0	0	1
09/17/2014 03:00	0.0	0	0	0	0	1
09/17/2014 04:00	0.0	0	0	0	0	1
09/17/2014 05:00	0.0	0	0	0	0	1
09/17/2014 06:00	0.0	0	0	0	0	1
09/17/2014 07:00	0.0	0	0	0	0	1
09/17/2014 08:00	0.0	0	0	0	0	1
09/17/2014 09:00	0.0	0	0	0	0	1
09/17/2014 10:00	0.0	0	0	0	0	1
09/17/2014 11:00	0.0	0	0	0	0	1
09/17/2014 12:00	0.0	0	0	0	0	1
09/17/2014 13:00	0.0	0	0	0	0	1
09/17/2014 14:00	0.0	0	0	0	0	1
09/17/2014 15:00	0.0	0	0	0	0	1
09/17/2014 16:00	0.0	0	0	0	0	1
09/17/2014 17:00	0.0	0	0	0	0	1
09/17/2014 18:00	0.0	0	0	0	0	1
09/17/2014 19:00	0.0	0	0	0	0	1
09/17/2014 20:00	0.0	0	0	0	0	1
09/17/2014 21:00	0.0	0	0	0	0	1
09/17/2014 22:00	0.0	0	0	0	0	1
09/17/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/18/2014 00:00	0.0	0	0	0	0	1
09/18/2014 01:00	0.0	0	0	0	0	1
09/18/2014 02:00	0.0	0	0	0	0	1
09/18/2014 03:00	0.0	0	0	0	0	1
09/18/2014 04:00	0.0	0	0	0	0	1
09/18/2014 05:00	0.0	0	0	0	0	1
09/18/2014 06:00	0.0	0	0	0	0	1
09/18/2014 07:00	0.0	0	0	0	0	1
09/18/2014 08:00	0.0	0	0	0	0	1
09/18/2014 09:00	0.0	0	0	0	0	1
09/18/2014 10:00	0.0	0	0	0	0	1
09/18/2014 11:00	0.0	0	0	0	0	1
09/18/2014 12:00	0.0	0	0	0	0	1
09/18/2014 13:00	0.0	0	0	0	0	1
09/18/2014 14:00	0.0	0	0	0	0	1
09/18/2014 15:00	0.0	0	0	0	0	1
09/18/2014 16:00	0.0	0	0	0	0	1
09/18/2014 17:00	0.0	0	0	0	0	1
09/18/2014 18:00	0.0	0	0	0	0	1
09/18/2014 19:00	0.0	0	0	0	0	1
09/18/2014 20:00	0.0	0	0	0	0	1
09/18/2014 21:00	0.0	0	0	0	0	1
09/18/2014 22:00	0.0	0	0	0	0	1
09/18/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/19/2014 00:00	0.0	0	0	0	0	1
09/19/2014 01:00	0.0	0	0	0	0	1
09/19/2014 02:00	0.0	0	0	0	0	1
09/19/2014 03:00	0.0	0	0	0	0	1
09/19/2014 04:00	0.0	0	0	0	0	1
09/19/2014 05:00	0.0	0	0	0	0	1
09/19/2014 06:00	0.0	0	0	0	0	1
09/19/2014 07:00	0.0	0	0	0	0	1
09/19/2014 08:00	0.0	0	0	0	0	1
09/19/2014 09:00	0.0	0	0	0	0	1
09/19/2014 10:00	0.0	0	0	0	0	1
09/19/2014 11:00	0.0	0	0	0	0	1
09/19/2014 12:00	0.0	0	0	0	0	1
09/19/2014 13:00	0.0	0	0	0	0	1
09/19/2014 14:00	0.0	0	0	0	0	1
09/19/2014 15:00	0.0	0	0	0	0	1
09/19/2014 16:00	0.0	0	0	0	0	1
09/19/2014 17:00	0.0	0	0	0	0	1
09/19/2014 18:00	0.0	0	0	0	0	1
09/19/2014 19:00	0.0	0	0	0	0	1
09/19/2014 20:00	0.0	0	0	0	0	1
09/19/2014 21:00	0.0	0	0	0	0	1
09/19/2014 22:00	0.0	0	0	0	0	1
09/19/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/20/2014 00:00	0.0	0	0	0	0	1
09/20/2014 01:00	0.0	0	0	0	0	1
09/20/2014 02:00	0.0	0	0	0	0	1
09/20/2014 03:00	0.0	0	0	0	0	1
09/20/2014 04:00	0.0	0	0	0	0	1
09/20/2014 05:00	0.0	0	0	0	0	1
09/20/2014 06:00	0.0	0	0	0	0	1
09/20/2014 07:00	0.0	0	0	0	0	1
09/20/2014 08:00	0.0	0	0	0	0	1
09/20/2014 09:00	0.0	0	0	0	0	1
09/20/2014 10:00	0.0	0	0	0	0	1
09/20/2014 11:00	0.0	0	0	0	0	1
09/20/2014 12:00	0.0	0	0	0	0	1
09/20/2014 13:00	0.0	0	0	0	0	1
09/20/2014 14:00	0.0	0	0	0	0	1
09/20/2014 15:00	0.0	0	0	0	0	1
09/20/2014 16:00	0.0	0	0	0	0	1
09/20/2014 17:00	0.0	0	0	0	0	1
09/20/2014 18:00	0.0	0	0	0	0	1
09/20/2014 19:00	0.0	0	0	0	0	1
09/20/2014 20:00	0.0	0	0	0	0	1
09/20/2014 21:00	0.0	0	0	0	0	1
09/20/2014 22:00	0.0	0	0	0	0	1
09/20/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/21/2014 00:00	0.0	0	0	0	0	1
09/21/2014 01:00	0.0	0	0	0	0	1
09/21/2014 02:00	0.0	0	0	0	0	1
09/21/2014 03:00	0.0	0	0	0	0	1
09/21/2014 04:00	0.0	0	0	0	0	1
09/21/2014 05:00	0.0	0	0	0	0	1
09/21/2014 06:00	0.0	0	0	0	0	1
09/21/2014 07:00	0.0	0	0	0	0	1
09/21/2014 08:00	0.0	0	0	0	0	1
09/21/2014 09:00	0.0	0	0	0	0	1
09/21/2014 10:00	0.0	0	0	0	0	1
09/21/2014 11:00	0.0	0	0	0	0	1
09/21/2014 12:00	0.0	0	0	0	0	1
09/21/2014 13:00	0.0	0	0	0	0	1
09/21/2014 14:00	0.0	0	0	0	0	1
09/21/2014 15:00	0.0	0	0	0	0	1
09/21/2014 16:00	0.0	0	0	0	0	1
09/21/2014 17:00	0.0	0	0	0	0	1
09/21/2014 18:00	0.0	0	0	0	0	1
09/21/2014 19:00	0.0	0	0	0	0	1
09/21/2014 20:00	0.0	0	0	0	0	1
09/21/2014 21:00	0.0	0	0	0	0	1
09/21/2014 22:00	0.0	0	0	0	0	1
09/21/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/22/2014 00:00	0.0	0	0	0	0	1
09/22/2014 01:00	0.0	0	0	0	0	1
09/22/2014 02:00	0.0	0	0	0	0	1
09/22/2014 03:00	0.0	0	0	0	0	1
09/22/2014 04:00	0.0	0	0	0	0	1
09/22/2014 05:00	0.0	0	0	0	0	1
09/22/2014 06:00	0.0	0	0	0	0	1
09/22/2014 07:00	0.0	0	0	0	0	1
09/22/2014 08:00	0.0	0	0	0	0	1
09/22/2014 09:00	0.0	0	0	0	0	1
09/22/2014 10:00	0.0	0	0	0	0	1
09/22/2014 11:00	0.0	0	0	0	0	1
09/22/2014 12:00	0.0	0	0	0	0	1
09/22/2014 13:00	0.0	0	0	0	0	1
09/22/2014 14:00	0.0	0	0	0	0	1
09/22/2014 15:00	0.0	0	0	0	0	1
09/22/2014 16:00	0.0	0	0	0	0	1
09/22/2014 17:00	0.0	0	0	0	0	1
09/22/2014 18:00	0.0	0	0	0	0	1
09/22/2014 19:00	0.0	0	0	0	0	1
09/22/2014 20:00	0.0	0	0	0	0	1
09/22/2014 21:00	0.0	0	0	0	0	1
09/22/2014 22:00	0.0	0	0	0	0	1
09/22/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/23/2014 00:00	0.0	0	0	0	0	1
09/23/2014 01:00	0.0	0	0	0	0	1
09/23/2014 02:00	0.0	0	0	0	0	1
09/23/2014 03:00	0.0	0	0	0	0	1
09/23/2014 04:00	0.0	0	0	0	0	1
09/23/2014 05:00	0.0	0	0	0	0	1
09/23/2014 06:00	0.0	0	0	0	0	1
09/23/2014 07:00	0.0	0	0	0	0	1
09/23/2014 08:00	0.0	0	0	0	0	1
09/23/2014 09:00	0.0	0	0	0	0	1
09/23/2014 10:00	0.0	0	0	0	0	1
09/23/2014 11:00	0.0	0	0	0	0	1
09/23/2014 12:00	0.0	0	0	0	0	1
09/23/2014 13:00	0.0	0	0	0	0	1
09/23/2014 14:00	0.0	0	0	0	0	1
09/23/2014 15:00	0.0	0	0	0	0	1
09/23/2014 16:00	0.0	0	0	0	0	1
09/23/2014 17:00	0.0	0	0	0	0	1
09/23/2014 18:00	0.0	0	0	0	0	1
09/23/2014 19:00	0.0	0	0	0	0	1
09/23/2014 20:00	0.0	0	0	0	0	1
09/23/2014 21:00	0.0	0	0	0	0	1
09/23/2014 22:00	0.0	0	0	0	0	1
09/23/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/24/2014 00:00	0.0	0	0	0	0	1
09/24/2014 01:00	0.0	0	0	0	0	1
09/24/2014 02:00	0.0	0	0	0	0	1
09/24/2014 03:00	0.0	0	0	0	0	1
09/24/2014 04:00	0.0	0	0	0	0	1
09/24/2014 05:00	0.0	0	0	0	0	1
09/24/2014 06:00	0.0	0	0	0	0	1
09/24/2014 07:00	0.0	0	0	0	0	1
09/24/2014 08:00	0.0	0	0	0	0	1
09/24/2014 09:00	0.0	0	0	0	0	1
09/24/2014 10:00	0.0	0	0	0	0	1
09/24/2014 11:00	0.0	0	0	0	0	1
09/24/2014 12:00	0.0	0	0	0	0	1
09/24/2014 13:00	0.0	0	0	0	0	1
09/24/2014 14:00	0.0	0	0	0	0	1
09/24/2014 15:00	0.0	0	0	0	0	1
09/24/2014 16:00	0.0	0	0	0	0	1
09/24/2014 17:00	0.0	0	0	0	0	1
09/24/2014 18:00	0.0	0	0	0	0	1
09/24/2014 19:00	0.0	0	0	0	0	1
09/24/2014 20:00	0.0	0	0	0	0	1
09/24/2014 21:00	0.0	0	0	0	0	1
09/24/2014 22:00	0.0	0	0	0	0	1
09/24/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/25/2014 00:00	0.0	0	0	0	0	1
09/25/2014 01:00	0.0	0	0	0	0	1
09/25/2014 02:00	0.0	0	0	0	0	1
09/25/2014 03:00	0.0	0	0	0	0	1
09/25/2014 04:00	0.0	0	0	0	0	1
09/25/2014 05:00	0.0	0	0	0	0	1
09/25/2014 06:00	0.0	0	0	0	0	1
09/25/2014 07:00	0.0	0	0	0	0	1
09/25/2014 08:00	0.0	0	0	0	0	1
09/25/2014 09:00	0.0	0	0	0	0	1
09/25/2014 10:00	0.0	0	0	0	0	1
09/25/2014 11:00	0.0	0	0	0	0	1
09/25/2014 12:00	0.0	0	0	0	0	1
09/25/2014 13:00	0.0	0	0	0	0	1
09/25/2014 14:00	0.0	0	0	0	0	1
09/25/2014 15:00	0.0	0	0	0	0	1
09/25/2014 16:00	0.0	0	0	0	0	1
09/25/2014 17:00	0.0	0	0	0	0	1
09/25/2014 18:00	0.0	0	0	0	0	1
09/25/2014 19:00	0.0	0	0	0	0	1
09/25/2014 20:00	0.0	0	0	0	0	1
09/25/2014 21:00	0.0	0	0	0	0	1
09/25/2014 22:00	0.0	0	0	0	0	1
09/25/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/26/2014 00:00	0.0	0	0	0	0	1
09/26/2014 01:00	0.0	0	0	0	0	1
09/26/2014 02:00	0.0	0	0	0	0	1
09/26/2014 03:00	0.0	0	0	0	0	1
09/26/2014 04:00	0.0	0	0	0	0	1
09/26/2014 05:00	0.0	0	0	0	0	1
09/26/2014 06:00	0.0	0	0	0	0	1
09/26/2014 07:00	0.0	0	0	0	0	1
09/26/2014 08:00	0.0	0	0	0	0	1
09/26/2014 09:00	0.0	0	0	0	0	1
09/26/2014 10:00	0.0	0	0	0	0	1
09/26/2014 11:00	0.0	0	0	0	0	1
09/26/2014 12:00	0.0	0	0	0	0	1
09/26/2014 13:00	0.0	0	0	0	0	1
09/26/2014 14:00	0.0	0	0	0	0	1
09/26/2014 15:00	0.0	0	0	0	0	1
09/26/2014 16:00	0.0	0	0	0	0	1
09/26/2014 17:00	0.0	0	0	0	0	1
09/26/2014 18:00	0.0	0	0	0	0	1
09/26/2014 19:00	0.0	0	0	0	0	1
09/26/2014 20:00	0.0	0	0	0	0	1
09/26/2014 21:00	0.0	0	0	0	0	1
09/26/2014 22:00	0.0	0	0	0	0	1
09/26/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/27/2014 00:00	0.0	0	0	0	0	1
09/27/2014 01:00	0.0	0	0	0	0	1
09/27/2014 02:00	0.0	0	0	0	0	1
09/27/2014 03:00	0.0	0	0	0	0	1
09/27/2014 04:00	0.0	0	0	0	0	1
09/27/2014 05:00	0.0	0	0	0	0	1
09/27/2014 06:00	0.0	0	0	0	0	1
09/27/2014 07:00	0.0	0	0	0	0	1
09/27/2014 08:00	0.0	0	0	0	0	1
09/27/2014 09:00	0.0	0	0	0	0	1
09/27/2014 10:00	0.0	0	0	0	0	1
09/27/2014 11:00	0.0	0	0	0	0	1
09/27/2014 12:00	0.0	0	0	0	0	1
09/27/2014 13:00	0.0	0	0	0	0	1
09/27/2014 14:00	0.0	0	0	0	0	1
09/27/2014 15:00	0.0	0	0	0	0	1
09/27/2014 16:00	0.0	0	0	0	0	1
09/27/2014 17:00	0.0	0	0	0	0	1
09/27/2014 18:00	0.0	0	0	0	0	1
09/27/2014 19:00	0.0	0	0	0	0	1
09/27/2014 20:00	0.0	0	0	0	0	1
09/27/2014 21:00	0.0	0	0	0	0	1
09/27/2014 22:00	0.0	0	0	0	0	1
09/27/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/28/2014 00:00	0.0	0	0	0	0	1
09/28/2014 01:00	0.0	0	0	0	0	1
09/28/2014 02:00	0.0	0	0	0	0	1
09/28/2014 03:00	0.0	0	0	0	0	1
09/28/2014 04:00	0.0	0	0	0	0	1
09/28/2014 05:00	0.0	0	0	0	0	1
09/28/2014 06:00	0.0	0	0	0	0	1
09/28/2014 07:00	0.0	0	0	0	0	1
09/28/2014 08:00	0.0	0	0	0	0	1
09/28/2014 09:00	0.0	0	0	0	0	1
09/28/2014 10:00	0.0	0	0	0	0	1
09/28/2014 11:00	0.0	0	0	0	0	1
09/28/2014 12:00	0.0	0	0	0	0	1
09/28/2014 13:00	0.0	0	0	0	0	1
09/28/2014 14:00	0.0	0	0	0	0	1
09/28/2014 15:00	0.0	0	0	0	0	1
09/28/2014 16:00	0.0	0	0	0	0	1
09/28/2014 17:00	0.0	0	0	0	0	1
09/28/2014 18:00	0.0	0	0	0	0	1
09/28/2014 19:00	0.0	0	0	0	0	1
09/28/2014 20:00	0.0	0	0	0	0	1
09/28/2014 21:00	0.0	0	0	0	0	1
09/28/2014 22:00	0.0	0	0	0	0	1
09/28/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/29/2014 00:00	0.0	0	0	0	0	1
09/29/2014 01:00	0.0	0	0	0	0	1
09/29/2014 02:00	0.0	0	0	0	0	1
09/29/2014 03:00	0.0	0	0	0	0	1
09/29/2014 04:00	0.0	0	0	0	0	1
09/29/2014 05:00	0.0	0	0	0	0	1
09/29/2014 06:00	0.0	0	0	0	0	1
09/29/2014 07:00	0.0	0	0	0	0	1
09/29/2014 08:00	0.0	0	0	0	0	1
09/29/2014 09:00	0.0	0	0	0	0	1
09/29/2014 10:00	0.0	0	0	0	0	1
09/29/2014 11:00	0.0	0	0	0	0	1
09/29/2014 12:00	0.0	0	0	0	0	1
09/29/2014 13:00	0.0	0	0	0	0	1
09/29/2014 14:00	0.0	0	0	0	0	1
09/29/2014 15:00	0.0	0	0	0	0	1
09/29/2014 16:00	0.0	0	0	0	0	1
09/29/2014 17:00	0.0	0	0	0	0	1
09/29/2014 18:00	0.0	0	0	0	0	1
09/29/2014 19:00	0.0	0	0	0	0	1
09/29/2014 20:00	0.0	0	0	0	0	1
09/29/2014 21:00	0.0	0	0	0	0	1
09/29/2014 22:00	0.0	0	0	0	0	1
09/29/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 CO_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/30/2014 00:00	0.0	0	0	0	0	1
09/30/2014 01:00	0.0	0	0	0	0	1
09/30/2014 02:00	0.0	0	0	0	0	1
09/30/2014 03:00	0.0	0	0	0	0	1
09/30/2014 04:00	0.0	0	0	0	0	1
09/30/2014 05:00	0.0	0	0	0	0	1
09/30/2014 06:00	0.0	0	0	0	0	1
09/30/2014 07:00	0.0	0	0	0	0	1
09/30/2014 08:00	0.0	0	0	0	0	1
09/30/2014 09:00	0.0	0	0	0	0	1
09/30/2014 10:00	0.0	0	0	0	0	1
09/30/2014 11:00	0.0	0	0	0	0	1
09/30/2014 12:00	0.0	0	0	0	0	1
09/30/2014 13:00	0.0	0	0	0	0	1
09/30/2014 14:00	0.0	0	0	0	0	1
09/30/2014 15:00	0.0	0	0	0	0	1
09/30/2014 16:00	0.0	0	0	0	0	1
09/30/2014 17:00	0.0	0	0	0	0	1
09/30/2014 18:00	0.0	0	0	0	0	1
09/30/2014 19:00	0.0	0	0	0	0	1
09/30/2014 20:00	0.0	0	0	0	0	1
09/30/2014 21:00	0.0	0	0	0	0	1
09/30/2014 22:00	0.0	0	0	0	0	1
09/30/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/01/2014 00:00	0.0	0	0	0	0	1
07/01/2014 01:00	0.0	0	0	0	0	1
07/01/2014 02:00	0.0	0	0	0	0	1
07/01/2014 03:00	0.0	0	0	0	0	1
07/01/2014 04:00	0.0	0	0	0	0	1
07/01/2014 05:00	0.0	0	0	0	0	1
07/01/2014 06:00	0.0	0	0	0	0	1
07/01/2014 07:00	0.0	0	0	0	0	1
07/01/2014 08:00	0.0	0	0	0	0	1
07/01/2014 09:00	0.0	0	0	0	0	1
07/01/2014 10:00	0.0	0	0	0	0	1
07/01/2014 11:00	0.0	0	0	0	0	1
07/01/2014 12:00	0.0	0	0	0	0	1
07/01/2014 13:00	0.0	0	0	0	0	1
07/01/2014 14:00	0.0	0	0	0	0	1
07/01/2014 15:00	0.0	0	0	0	0	1
07/01/2014 16:00	0.0	0	0	0	0	1
07/01/2014 17:00	0.0	0	0	0	0	1
07/01/2014 18:00	0.0	0	0	0	0	1
07/01/2014 19:00	0.0	0	0	0	0	1
07/01/2014 20:00	0.0	0	0	0	0	1
07/01/2014 21:00	0.0	0	0	0	0	1
07/01/2014 22:00	0.0	0	0	0	0	1
07/01/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/02/2014 00:00	0.0	0	0	0	0	1
07/02/2014 01:00	0.0	0	0	0	0	1
07/02/2014 02:00	0.0	0	0	0	0	1
07/02/2014 03:00	0.0	0	0	0	0	1
07/02/2014 04:00	0.0	0	0	0	0	1
07/02/2014 05:00	0.0	0	0	0	0	1
07/02/2014 06:00	0.0	0	0	0	0	1
07/02/2014 07:00	0.0	0	0	0	0	1
07/02/2014 08:00	0.0	0	0	0	0	1
07/02/2014 09:00	0.0	0	0	0	0	1
07/02/2014 10:00	0.0	0	0	0	0	1
07/02/2014 11:00	0.0	0	0	0	0	1
07/02/2014 12:00	0.0	0	0	0	0	1
07/02/2014 13:00	0.0	0	0	0	0	1
07/02/2014 14:00	0.0	0	0	0	0	1
07/02/2014 15:00	0.0	0	0	0	0	1
07/02/2014 16:00	0.0	0	0	0	0	1
07/02/2014 17:00	0.0	0	0	0	0	1
07/02/2014 18:00	0.0	0	0	0	0	1
07/02/2014 19:00	0.0	0	0	0	0	1
07/02/2014 20:00	0.0	0	0	0	0	1
07/02/2014 21:00	0.0	0	0	0	0	1
07/02/2014 22:00	0.9	0	0	0	1	0
07/02/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.9 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.9	0	0	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/03/2014 00:00	0.0	0	0	0	0	0
07/03/2014 01:00	0.0	0	0	0	0	0
07/03/2014 02:00	0.0	0	0	0	0	0
07/03/2014 03:00	3.5	0	0	1	0	0
07/03/2014 04:00	2.0	0	0	1	0	0
07/03/2014 05:00	0.0	0	0	0	0	1
07/03/2014 06:00	0.0	0	0	0	0	1
07/03/2014 07:00	0.0	0	0	0	0	1
07/03/2014 08:00	0.0	0	0	0	0	1
07/03/2014 09:00	0.0	0	0	0	0	1
07/03/2014 10:00	0.0	0	0	0	0	1
07/03/2014 11:00	0.0	0	0	0	0	1
07/03/2014 12:00	0.0	0	0	0	0	1
07/03/2014 13:00	0.0	0	0	0	0	1
07/03/2014 14:00	0.0	0	0	0	0	1
07/03/2014 15:00	0.0	0	0	0	0	1
07/03/2014 16:00	0.0	0	0	0	0	1
07/03/2014 17:00	0.0	0	0	0	0	1
07/03/2014 18:00	0.0	0	0	0	0	1
07/03/2014 19:00	0.0	0	0	0	0	1
07/03/2014 20:00	0.0	0	0	0	0	1
07/03/2014 21:00	0.0	0	0	0	0	1
07/03/2014 22:00	0.0	0	0	0	0	1
07/03/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	5.5 #	0 #	0 #	2 #	0 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3.5	0	0	1	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/04/2014 00:00	0.0	0	0	0	0	1
07/04/2014 01:00	0.0	0	0	0	0	1
07/04/2014 02:00	0.0	0	0	0	0	1
07/04/2014 03:00	0.0	0	0	0	0	1
07/04/2014 04:00	0.0	0	0	0	0	1
07/04/2014 05:00	0.0	0	0	0	0	1
07/04/2014 06:00	0.0	0	0	0	0	1
07/04/2014 07:00	0.0	0	0	0	0	1
07/04/2014 08:00	0.0	0	0	0	0	1
07/04/2014 09:00	0.0	0	0	0	0	1
07/04/2014 10:00	0.0	0	0	0	0	1
07/04/2014 11:00	0.0	0	0	0	0	1
07/04/2014 12:00	0.0	0	0	0	0	1
07/04/2014 13:00	0.0	0	0	0	0	1
07/04/2014 14:00	0.0	0	0	0	0	1
07/04/2014 15:00	0.0	0	0	0	0	1
07/04/2014 16:00	0.0	0	0	0	0	1
07/04/2014 17:00	0.0	0	0	0	0	1
07/04/2014 18:00	0.0	0	0	0	0	1
07/04/2014 19:00	0.0	0	0	0	0	1
07/04/2014 20:00	1.4	0	0	0	1	0
07/04/2014 21:00	0.0	0	0	0	0	0
07/04/2014 22:00	0.0	0	0	0	0	0
07/04/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.4 #	0 #	0 #	0 #	1 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.4	0	0	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/05/2014 00:00	0.0	0	0	0	0	0
07/05/2014 01:00	0.0	0	0	0	0	0
07/05/2014 02:00	0.0	0	0	0	0	0
07/05/2014 03:00	0.0	0	0	0	0	0
07/05/2014 04:00	0.0	0	0	0	0	0
07/05/2014 05:00	0.0	0	0	0	0	0
07/05/2014 06:00	52.1	0	1	0	0	0
07/05/2014 07:00	39.9	0	1	0	0	0
07/05/2014 08:00	0.0	0	0	0	0	1
07/05/2014 09:00	0.0	0	0	0	0	1
07/05/2014 10:00	0.0	0	0	0	0	1
07/05/2014 11:00	0.0	0	0	0	0	1
07/05/2014 12:00	0.0	0	0	0	0	1
07/05/2014 13:00	0.0	0	0	0	0	1
07/05/2014 14:00	0.0	0	0	0	0	1
07/05/2014 15:00	0.0	0	0	0	0	1
07/05/2014 16:00	0.0	0	0	0	0	1
07/05/2014 17:00	0.0	0	0	0	0	1
07/05/2014 18:00	0.0	0	0	0	0	1
07/05/2014 19:00	0.0	0	0	0	0	1
07/05/2014 20:00	0.0	0	0	0	0	1
07/05/2014 21:00	0.0	0	0	0	0	1
07/05/2014 22:00	0.0	0	0	0	0	1
07/05/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	92.0 #	0 #	2 #	0 #	0 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	52.1	0	1	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/06/2014 00:00	0.0	0	0	0	0	1
07/06/2014 01:00	0.0	0	0	0	0	1
07/06/2014 02:00	1.1	0	0	0	1	0
07/06/2014 03:00	0.0	0	0	0	0	0
07/06/2014 04:00	0.0	0	0	0	0	0
07/06/2014 05:00	7.5	0	0	1	0	0
07/06/2014 06:00	18.0	0	0	1	0	0
07/06/2014 07:00	0.0	0	0	0	0	1
07/06/2014 08:00	0.0	0	0	0	0	1
07/06/2014 09:00	0.0	0	0	0	0	1
07/06/2014 10:00	0.0	0	0	0	0	1
07/06/2014 11:00	0.0	0	0	0	0	1
07/06/2014 12:00	0.0	0	0	0	0	1
07/06/2014 13:00	0.0	0	0	0	0	1
07/06/2014 14:00	0.0	0	0	0	0	1
07/06/2014 15:00	0.0	0	0	0	0	1
07/06/2014 16:00	0.0	0	0	0	0	1
07/06/2014 17:00	0.0	0	0	0	0	1
07/06/2014 18:00	0.0	0	0	0	0	1
07/06/2014 19:00	0.0	0	0	0	0	1
07/06/2014 20:00	0.0	0	0	0	0	1
07/06/2014 21:00	0.0	0	0	0	0	1
07/06/2014 22:00	0.0	0	0	0	0	1
07/06/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	26.6 #	0 #	0 #	2 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	18.0	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/07/2014 00:00	0.0	0	0	0	0	1
07/07/2014 01:00	0.0	0	0	0	0	1
07/07/2014 02:00	0.0	0	0	0	0	1
07/07/2014 03:00	0.0	0	0	0	0	1
07/07/2014 04:00	0.0	0	0	0	0	1
07/07/2014 05:00	0.0	0	0	0	0	1
07/07/2014 06:00	0.0	0	0	0	0	1
07/07/2014 07:00	0.0	0	0	0	0	1
07/07/2014 08:00	0.0	0	0	0	0	1
07/07/2014 09:00	0.0	0	0	0	0	1
07/07/2014 10:00	0.0	0	0	0	0	1
07/07/2014 11:00	0.0	0	0	0	0	1
07/07/2014 12:00	0.0	0	0	0	0	1
07/07/2014 13:00	0.0	0	0	0	0	1
07/07/2014 14:00	0.0	0	0	0	0	1
07/07/2014 15:00	0.0	0	0	0	0	1
07/07/2014 16:00	0.0	0	0	0	0	1
07/07/2014 17:00	0.0	0	0	0	0	1
07/07/2014 18:00	0.0	0	0	0	0	1
07/07/2014 19:00	0.0	0	0	0	0	1
07/07/2014 20:00	0.0	0	0	0	0	1
07/07/2014 21:00	0.0	0	0	0	0	1
07/07/2014 22:00	0.0	0	0	0	0	1
07/07/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/08/2014 00:00	0.0	0	0	0	0	1
07/08/2014 01:00	0.0	0	0	0	0	1
07/08/2014 02:00	0.0	0	0	0	0	1
07/08/2014 03:00	0.0	0	0	0	0	1
07/08/2014 04:00	0.0	0	0	0	0	1
07/08/2014 05:00	0.0	0	0	0	0	1
07/08/2014 06:00	0.0	0	0	0	0	1
07/08/2014 07:00	0.0	0	0	0	0	1
07/08/2014 08:00	0.0	0	0	0	0	1
07/08/2014 09:00	0.0	0	0	0	0	1
07/08/2014 10:00	0.0	0	0	0	0	1
07/08/2014 11:00	0.0	0	0	0	0	1
07/08/2014 12:00	0.0	0	0	0	0	1
07/08/2014 13:00	0.0	0	0	0	0	1
07/08/2014 14:00	0.0	0	0	0	0	1
07/08/2014 15:00	0.0	0	0	0	0	1
07/08/2014 16:00	0.0	0	0	0	0	1
07/08/2014 17:00	0.0	0	0	0	0	1
07/08/2014 18:00	0.0	0	0	0	0	1
07/08/2014 19:00	0.0	0	0	0	0	1
07/08/2014 20:00	0.0	0	0	0	0	1
07/08/2014 21:00	0.0	0	0	0	0	1
07/08/2014 22:00	0.0	0	0	0	0	1
07/08/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/09/2014 00:00	0.0	0	0	0	0	1
07/09/2014 01:00	0.0	0	0	0	0	1
07/09/2014 02:00	0.0	0	0	0	0	1
07/09/2014 03:00	0.0	0	0	0	0	1
07/09/2014 04:00	0.0	0	0	0	0	1
07/09/2014 05:00	0.0	0	0	0	0	1
07/09/2014 06:00	0.0	0	0	0	0	1
07/09/2014 07:00	0.0	0	0	0	0	1
07/09/2014 08:00	0.0	0	0	0	0	1
07/09/2014 09:00	0.0	0	0	0	0	1
07/09/2014 10:00	0.0	0	0	0	0	1
07/09/2014 11:00	0.0	0	0	0	0	1
07/09/2014 12:00	0.0	0	0	0	0	1
07/09/2014 13:00	0.0	0	0	0	0	1
07/09/2014 14:00	0.0	0	0	0	0	1
07/09/2014 15:00	0.0	0	0	0	0	1
07/09/2014 16:00	0.0	0	0	0	0	1
07/09/2014 17:00	0.0	0	0	0	0	1
07/09/2014 18:00	0.0	0	0	0	0	1
07/09/2014 19:00	0.0	0	0	0	0	1
07/09/2014 20:00	0.0	0	0	0	0	1
07/09/2014 21:00	0.0	0	0	0	0	1
07/09/2014 22:00	0.0	0	0	0	0	1
07/09/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/10/2014 00:00	0.0	0	0	0	0	1
07/10/2014 01:00	0.0	0	0	0	0	1
07/10/2014 02:00	0.0	0	0	0	0	1
07/10/2014 03:00	0.0	0	0	0	0	1
07/10/2014 04:00	0.0	0	0	0	0	1
07/10/2014 05:00	0.0	0	0	0	0	1
07/10/2014 06:00	0.0	0	0	0	0	1
07/10/2014 07:00	0.0	0	0	0	0	1
07/10/2014 08:00	0.0	0	0	0	0	1
07/10/2014 09:00	0.0	0	0	0	0	1
07/10/2014 10:00	0.0	0	0	0	0	1
07/10/2014 11:00	0.0	0	0	0	0	1
07/10/2014 12:00	0.0	0	0	0	0	1
07/10/2014 13:00	0.0	0	0	0	0	1
07/10/2014 14:00	0.0	0	0	0	0	1
07/10/2014 15:00	0.0	0	0	0	0	1
07/10/2014 16:00	0.0	0	0	0	0	1
07/10/2014 17:00	0.0	0	0	0	0	1
07/10/2014 18:00	0.0	0	0	0	0	1
07/10/2014 19:00	0.0	0	0	0	0	1
07/10/2014 20:00	0.0	0	0	0	0	1
07/10/2014 21:00	0.0	0	0	0	0	1
07/10/2014 22:00	0.0	0	0	0	0	1
07/10/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/11/2014 00:00	0.0	0	0	0	0	1
07/11/2014 01:00	0.7	0	0	0	1	0
07/11/2014 02:00	0.0	0	0	0	0	0
07/11/2014 03:00	0.0	0	0	0	0	0
07/11/2014 04:00	0.0	0	0	0	0	0
07/11/2014 05:00	2.0	0	0	1	0	0
07/11/2014 06:00	14.2	0	0	1	0	0
07/11/2014 07:00	0.0	0	0	0	0	1
07/11/2014 08:00	0.0	0	0	0	0	1
07/11/2014 09:00	0.0	0	0	0	0	1
07/11/2014 10:00	0.0	0	0	0	0	1
07/11/2014 11:00	0.0	0	0	0	0	1
07/11/2014 12:00	0.0	0	0	0	0	1
07/11/2014 13:00	0.0	0	0	0	0	1
07/11/2014 14:00	0.0	0	0	0	0	1
07/11/2014 15:00	0.0	0	0	0	0	1
07/11/2014 16:00	0.0	0	0	0	0	1
07/11/2014 17:00	0.0	0	0	0	0	1
07/11/2014 18:00	0.0	0	0	0	0	1
07/11/2014 19:00	0.0	0	0	0	0	1
07/11/2014 20:00	0.0	0	0	0	0	1
07/11/2014 21:00	0.0	0	0	0	0	1
07/11/2014 22:00	0.0	0	0	0	0	1
07/11/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	16.9 #	0 #	0 #	2 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	14.2	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/12/2014 00:00	1.0	0	0	0	1	0
07/12/2014 01:00	0.0	0	0	0	0	0
07/12/2014 02:00	0.0	0	0	0	0	0
07/12/2014 03:00	0.0	0	0	0	0	0
07/12/2014 04:00	0.0	0	0	0	0	0
07/12/2014 05:00	0.0	0	0	0	0	0
07/12/2014 06:00	0.0	0	0	0	0	0
07/12/2014 07:00	0.0	0	0	0	0	0
07/12/2014 08:00	0.0	0	0	0	0	0
07/12/2014 09:00	0.0	0	0	0	0	0
07/12/2014 10:00	0.0	0	0	0	0	0
07/12/2014 11:00	68.5	0	1	0	0	0
07/12/2014 12:00	0.5	0	1	0	0	0
07/12/2014 13:00	0.0	0	0	0	0	1
07/12/2014 14:00	0.0	0	0	0	0	1
07/12/2014 15:00	0.0	0	0	0	0	1
07/12/2014 16:00	0.0	0	0	0	0	1
07/12/2014 17:00	0.0	0	0	0	0	1
07/12/2014 18:00	0.0	0	0	0	0	1
07/12/2014 19:00	0.0	0	0	0	0	1
07/12/2014 20:00	0.0	0	0	0	0	1
07/12/2014 21:00	0.0	0	0	0	0	1
07/12/2014 22:00	0.0	0	0	0	0	1
07/12/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	70.0 #	0 #	2 #	0 #	1 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	68.5	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/13/2014 00:00	0.0	0	0	0	0	1
07/13/2014 01:00	1.0	0	0	0	1	0
07/13/2014 02:00	0.0	0	0	0	0	0
07/13/2014 03:00	0.0	0	0	0	0	0
07/13/2014 04:00	0.0	0	0	0	0	0
07/13/2014 05:00	0.0	0	0	0	0	0
07/13/2014 06:00	19.9	0	0	1	0	0
07/13/2014 07:00	29.4	0	0	1	0	0
07/13/2014 08:00	0.0	0	0	0	0	1
07/13/2014 09:00	0.0	0	0	0	0	1
07/13/2014 10:00	0.0	0	0	0	0	1
07/13/2014 11:00	0.0	0	0	0	0	1
07/13/2014 12:00	0.0	0	0	0	0	1
07/13/2014 13:00	0.0	0	0	0	0	1
07/13/2014 14:00	0.0	0	0	0	0	1
07/13/2014 15:00	0.0	0	0	0	0	1
07/13/2014 16:00	0.0	0	0	0	0	1
07/13/2014 17:00	0.0	0	0	0	0	1
07/13/2014 18:00	0.0	0	0	0	0	1
07/13/2014 19:00	0.0	0	0	0	0	1
07/13/2014 20:00	0.0	0	0	0	0	1
07/13/2014 21:00	0.0	0	0	0	0	1
07/13/2014 22:00	0.0	0	0	0	0	1
07/13/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	50.3 #	0 #	0 #	2 #	1 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	29.4	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/14/2014 00:00	0.0	0	0	0	0	1
07/14/2014 01:00	0.0	0	0	0	0	1
07/14/2014 02:00	0.0	0	0	0	0	1
07/14/2014 03:00	0.0	0	0	0	0	1
07/14/2014 04:00	0.0	0	0	0	0	1
07/14/2014 05:00	0.0	0	0	0	0	1
07/14/2014 06:00	0.0	0	0	0	0	1
07/14/2014 07:00	0.0	0	0	0	0	1
07/14/2014 08:00	0.0	0	0	0	0	1
07/14/2014 09:00	0.0	0	0	0	0	1
07/14/2014 10:00	0.0	0	0	0	0	1
07/14/2014 11:00	0.0	0	0	0	0	1
07/14/2014 12:00	0.0	0	0	0	0	1
07/14/2014 13:00	0.0	0	0	0	0	1
07/14/2014 14:00	0.0	0	0	0	0	1
07/14/2014 15:00	0.0	0	0	0	0	1
07/14/2014 16:00	0.0	0	0	0	0	1
07/14/2014 17:00	0.0	0	0	0	0	1
07/14/2014 18:00	0.0	0	0	0	0	1
07/14/2014 19:00	0.0	0	0	0	0	1
07/14/2014 20:00	0.0	0	0	0	0	1
07/14/2014 21:00	0.0	0	0	0	0	1
07/14/2014 22:00	0.0	0	0	0	0	1
07/14/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/15/2014 00:00	0.0	0	0	0	0	1
07/15/2014 01:00	0.0	0	0	0	0	1
07/15/2014 02:00	0.0	0	0	0	0	1
07/15/2014 03:00	0.0	0	0	0	0	1
07/15/2014 04:00	0.0	0	0	0	0	1
07/15/2014 05:00	0.0	0	0	0	0	1
07/15/2014 06:00	0.0	0	0	0	0	1
07/15/2014 07:00	0.0	0	0	0	0	1
07/15/2014 08:00	0.0	0	0	0	0	1
07/15/2014 09:00	0.0	0	0	0	0	1
07/15/2014 10:00	0.0	0	0	0	0	1
07/15/2014 11:00	0.0	0	0	0	0	1
07/15/2014 12:00	0.0	0	0	0	0	1
07/15/2014 13:00	0.0	0	0	0	0	1
07/15/2014 14:00	0.0	0	0	0	0	1
07/15/2014 15:00	0.0	0	0	0	0	1
07/15/2014 16:00	0.0	0	0	0	0	1
07/15/2014 17:00	0.0	0	0	0	0	1
07/15/2014 18:00	0.0	0	0	0	0	1
07/15/2014 19:00	0.0	0	0	0	0	1
07/15/2014 20:00	0.0	0	0	0	0	1
07/15/2014 21:00	0.0	0	0	0	0	1
07/15/2014 22:00	0.0	0	0	0	0	1
07/15/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/16/2014 00:00	0.0	0	0	0	0	1
07/16/2014 01:00	0.0	0	0	0	0	1
07/16/2014 02:00	0.0	0	0	0	0	1
07/16/2014 03:00	0.0	0	0	0	0	1
07/16/2014 04:00	0.0	0	0	0	0	1
07/16/2014 05:00	0.0	0	0	0	0	1
07/16/2014 06:00	0.0	0	0	0	0	1
07/16/2014 07:00	0.0	0	0	0	0	1
07/16/2014 08:00	0.0	0	0	0	0	1
07/16/2014 09:00	0.0	0	0	0	0	1
07/16/2014 10:00	0.0	0	0	0	0	1
07/16/2014 11:00	0.0	0	0	0	0	1
07/16/2014 12:00	0.0	0	0	0	0	1
07/16/2014 13:00	0.0	0	0	0	0	1
07/16/2014 14:00	0.0	0	0	0	0	1
07/16/2014 15:00	0.0	0	0	0	0	1
07/16/2014 16:00	0.0	0	0	0	0	1
07/16/2014 17:00	0.0	0	0	0	0	1
07/16/2014 18:00	0.0	0	0	0	0	1
07/16/2014 19:00	0.0	0	0	0	0	1
07/16/2014 20:00	0.0	0	0	0	0	1
07/16/2014 21:00	0.0	0	0	0	0	1
07/16/2014 22:00	0.0	0	0	0	0	1
07/16/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/17/2014 00:00	0.9	0	0	0	1	0
07/17/2014 01:00	0.0	0	0	0	0	0
07/17/2014 02:00	0.0	0	0	0	0	0
07/17/2014 03:00	0.0	0	0	0	0	0
07/17/2014 04:00	0.0	0	0	0	0	0
07/17/2014 05:00	0.0	0	0	0	0	0
07/17/2014 06:00	0.0	0	0	0	0	0
07/17/2014 07:00	0.0	0	0	0	0	0
07/17/2014 08:00	16.1	0	1	0	0	0
07/17/2014 09:00	29.5	0	1	0	0	0
07/17/2014 10:00	0.0	0	0	0	0	1
07/17/2014 11:00	0.0	0	0	0	0	1
07/17/2014 12:00	0.0	0	0	0	0	1
07/17/2014 13:00	0.0	0	0	0	0	1
07/17/2014 14:00	0.0	0	0	0	0	1
07/17/2014 15:00	0.0	0	0	0	0	1
07/17/2014 16:00	0.0	0	0	0	0	1
07/17/2014 17:00	0.0	0	0	0	0	1
07/17/2014 18:00	0.0	0	0	0	0	1
07/17/2014 19:00	0.0	0	0	0	0	1
07/17/2014 20:00	0.0	0	0	0	0	1
07/17/2014 21:00	0.0	0	0	0	0	1
07/17/2014 22:00	0.0	0	0	0	0	1
07/17/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	46.5 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	29.5	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/18/2014 00:00	1.0	0	0	0	1	0
07/18/2014 01:00	0.0	0	0	0	0	0
07/18/2014 02:00	0.0	0	0	0	0	0
07/18/2014 03:00	0.0	0	0	0	0	0
07/18/2014 04:00	0.0	0	0	0	0	0
07/18/2014 05:00	0.0	0	0	0	0	0
07/18/2014 06:00	0.0	0	0	0	0	0
07/18/2014 07:00	0.0	0	0	0	0	0
07/18/2014 08:00	58.8	0	0	1	0	0
07/18/2014 09:00	0.3	0	0	1	0	0
07/18/2014 10:00	0.0	0	0	0	0	1
07/18/2014 11:00	0.0	0	0	0	0	1
07/18/2014 12:00	0.0	0	0	0	0	1
07/18/2014 13:00	0.0	0	0	0	0	1
07/18/2014 14:00	0.0	0	0	0	0	1
07/18/2014 15:00	0.0	0	0	0	0	1
07/18/2014 16:00	0.0	0	0	0	0	1
07/18/2014 17:00	0.0	0	0	0	0	1
07/18/2014 18:00	0.0	0	0	0	0	1
07/18/2014 19:00	0.0	0	0	0	0	1
07/18/2014 20:00	0.0	0	0	0	0	1
07/18/2014 21:00	0.0	0	0	0	0	1
07/18/2014 22:00	0.0	0	0	0	0	1
07/18/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	60.1 #	0 #	0 #	2 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	58.8	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/19/2014 00:00	1.3	0	0	0	1	0
07/19/2014 01:00	0.0	0	0	0	0	0
07/19/2014 02:00	0.0	0	0	0	0	0
07/19/2014 03:00	0.0	0	0	0	0	0
07/19/2014 04:00	0.0	0	0	0	0	0
07/19/2014 05:00	23.3	0	0	1	0	0
07/19/2014 06:00	22.8	0	0	1	0	0
07/19/2014 07:00	0.0	0	0	0	0	1
07/19/2014 08:00	0.0	0	0	0	0	1
07/19/2014 09:00	0.0	0	0	0	0	1
07/19/2014 10:00	0.0	0	0	0	0	1
07/19/2014 11:00	0.0	0	0	0	0	1
07/19/2014 12:00	0.0	0	0	0	0	1
07/19/2014 13:00	0.0	0	0	0	0	1
07/19/2014 14:00	0.0	0	0	0	0	1
07/19/2014 15:00	0.0	0	0	0	0	1
07/19/2014 16:00	0.0	0	0	0	0	1
07/19/2014 17:00	0.0	0	0	0	0	1
07/19/2014 18:00	0.0	0	0	0	0	1
07/19/2014 19:00	0.0	0	0	0	0	1
07/19/2014 20:00	0.0	0	0	0	0	1
07/19/2014 21:00	0.0	0	0	0	0	1
07/19/2014 22:00	0.0	0	0	0	0	1
07/19/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	47.4 #	0 #	0 #	2 #	1 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	23.3	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/20/2014 00:00	0.9	0	0	0	1	0
07/20/2014 01:00	0.0	0	0	0	0	0
07/20/2014 02:00	0.0	0	0	0	0	0
07/20/2014 03:00	0.0	0	0	0	0	0
07/20/2014 04:00	0.0	0	0	0	0	0
07/20/2014 05:00	0.0	0	0	0	0	0
07/20/2014 06:00	0.0	0	0	0	0	0
07/20/2014 07:00	0.0	0	0	0	0	0
07/20/2014 08:00	0.0	0	0	0	0	0
07/20/2014 09:00	0.0	0	0	0	0	0
07/20/2014 10:00	0.0	0	0	0	0	0
07/20/2014 11:00	0.0	0	0	0	0	0
07/20/2014 12:00	0.0	0	0	0	0	0
07/20/2014 13:00	0.0	0	0	0	0	0
07/20/2014 14:00	0.0	0	0	0	0	0
07/20/2014 15:00	0.0	0	0	0	0	0
07/20/2014 16:00	0.0	0	0	0	0	0
07/20/2014 17:00	0.0	0	0	0	0	0
07/20/2014 18:00	0.0	0	0	0	0	0
07/20/2014 19:00	0.0	0	0	0	0	0
07/20/2014 20:00	0.0	0	0	0	0	0
07/20/2014 21:00	0.0	0	0	0	0	0
07/20/2014 22:00	0.0	0	0	0	0	0
07/20/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.9 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.9	0	0	0	1	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/21/2014 00:00	0.0	0	0	0	0	0
07/21/2014 01:00	0.0	0	0	0	0	0
07/21/2014 02:00	0.0	0	0	0	0	0
07/21/2014 03:00	0.0	0	0	0	0	0
07/21/2014 04:00	0.0	0	0	0	0	0
07/21/2014 05:00	0.0	0	0	0	0	0
07/21/2014 06:00	60.3	0	1	0	0	0
07/21/2014 07:00	28.0	0	1	0	0	0
07/21/2014 08:00	0.0	0	0	0	0	1
07/21/2014 09:00	0.0	0	0	0	0	1
07/21/2014 10:00	0.0	0	0	0	0	1
07/21/2014 11:00	0.0	0	0	0	0	1
07/21/2014 12:00	0.0	0	0	0	0	1
07/21/2014 13:00	0.0	0	0	0	0	1
07/21/2014 14:00	0.0	0	0	0	0	1
07/21/2014 15:00	0.0	0	0	0	0	1
07/21/2014 16:00	0.0	0	0	0	0	1
07/21/2014 17:00	0.0	0	0	0	0	1
07/21/2014 18:00	0.0	0	0	0	0	1
07/21/2014 19:00	0.0	0	0	0	0	1
07/21/2014 20:00	0.0	0	0	0	0	1
07/21/2014 21:00	0.0	0	0	0	0	1
07/21/2014 22:00	0.0	0	0	0	0	1
07/21/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	88.3 #	0 #	2 #	0 #	0 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	60.3	0	1	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/22/2014 00:00	0.0	0	0	0	0	1
07/22/2014 01:00	0.0	0	0	0	0	1
07/22/2014 02:00	0.0	0	0	0	0	1
07/22/2014 03:00	0.0	0	0	0	0	1
07/22/2014 04:00	0.0	0	0	0	0	1
07/22/2014 05:00	0.0	0	0	0	0	1
07/22/2014 06:00	0.0	0	0	0	0	1
07/22/2014 07:00	0.0	0	0	0	0	1
07/22/2014 08:00	0.0	0	0	0	0	1
07/22/2014 09:00	0.0	0	0	0	0	1
07/22/2014 10:00	0.0	0	0	0	0	1
07/22/2014 11:00	0.0	0	0	0	0	1
07/22/2014 12:00	0.0	0	0	0	0	1
07/22/2014 13:00	0.0	0	0	0	0	1
07/22/2014 14:00	0.0	0	0	0	0	1
07/22/2014 15:00	0.0	0	0	0	0	1
07/22/2014 16:00	0.0	0	0	0	0	1
07/22/2014 17:00	0.0	0	0	0	0	1
07/22/2014 18:00	0.0	0	0	0	0	1
07/22/2014 19:00	0.0	0	0	0	0	1
07/22/2014 20:00	0.0	0	0	0	0	1
07/22/2014 21:00	0.0	0	0	0	0	1
07/22/2014 22:00	0.0	0	0	0	0	1
07/22/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/23/2014 00:00	0.0	0	0	0	0	1
07/23/2014 01:00	0.0	0	0	0	0	1
07/23/2014 02:00	0.0	0	0	0	0	1
07/23/2014 03:00	0.0	0	0	0	0	1
07/23/2014 04:00	0.0	0	0	0	0	1
07/23/2014 05:00	0.0	0	0	0	0	1
07/23/2014 06:00	0.0	0	0	0	0	1
07/23/2014 07:00	0.0	0	0	0	0	1
07/23/2014 08:00	0.0	0	0	0	0	1
07/23/2014 09:00	0.0	0	0	0	0	1
07/23/2014 10:00	0.0	0	0	0	0	1
07/23/2014 11:00	0.0	0	0	0	0	1
07/23/2014 12:00	0.0	0	0	0	0	1
07/23/2014 13:00	0.0	0	0	0	0	1
07/23/2014 14:00	0.0	0	0	0	0	1
07/23/2014 15:00	0.0	0	0	0	0	1
07/23/2014 16:00	0.0	0	0	0	0	1
07/23/2014 17:00	0.0	0	0	0	0	1
07/23/2014 18:00	0.0	0	0	0	0	1
07/23/2014 19:00	0.0	0	0	0	0	1
07/23/2014 20:00	0.0	0	0	0	0	1
07/23/2014 21:00	0.0	0	0	0	0	1
07/23/2014 22:00	0.0	0	0	0	0	1
07/23/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/24/2014 00:00	0.0	0	0	0	0	1
07/24/2014 01:00	0.0	0	0	0	0	1
07/24/2014 02:00	0.0	0	0	0	0	1
07/24/2014 03:00	0.0	0	0	0	0	1
07/24/2014 04:00	0.0	0	0	0	0	1
07/24/2014 05:00	0.0	0	0	0	0	1
07/24/2014 06:00	0.0	0	0	0	0	1
07/24/2014 07:00	0.0	0	0	0	0	1
07/24/2014 08:00	0.0	0	0	0	0	1
07/24/2014 09:00	0.0	0	0	0	0	1
07/24/2014 10:00	0.0	0	0	0	0	1
07/24/2014 11:00	0.0	0	0	0	0	1
07/24/2014 12:00	0.0	0	0	0	0	1
07/24/2014 13:00	0.0	0	0	0	0	1
07/24/2014 14:00	0.0	0	0	0	0	1
07/24/2014 15:00	0.0	0	0	0	0	1
07/24/2014 16:00	0.0	0	0	0	0	1
07/24/2014 17:00	0.0	0	0	0	0	1
07/24/2014 18:00	0.0	0	0	0	0	1
07/24/2014 19:00	0.0	0	0	0	0	1
07/24/2014 20:00	0.0	0	0	0	0	1
07/24/2014 21:00	0.0	0	0	0	0	1
07/24/2014 22:00	0.0	0	0	0	0	1
07/24/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/25/2014 00:00	0.0	0	0	0	0	1
07/25/2014 01:00	0.0	0	0	0	0	1
07/25/2014 02:00	0.0	0	0	0	0	1
07/25/2014 03:00	0.0	0	0	0	0	1
07/25/2014 04:00	0.0	0	0	0	0	1
07/25/2014 05:00	0.0	0	0	0	0	1
07/25/2014 06:00	0.0	0	0	0	0	1
07/25/2014 07:00	0.0	0	0	0	0	1
07/25/2014 08:00	0.0	0	0	0	0	1
07/25/2014 09:00	0.0	0	0	0	0	1
07/25/2014 10:00	0.0	0	0	0	0	1
07/25/2014 11:00	0.0	0	0	0	0	1
07/25/2014 12:00	0.0	0	0	0	0	1
07/25/2014 13:00	0.0	0	0	0	0	1
07/25/2014 14:00	0.0	0	0	0	0	1
07/25/2014 15:00	0.0	0	0	0	0	1
07/25/2014 16:00	0.0	0	0	0	0	1
07/25/2014 17:00	0.0	0	0	0	0	1
07/25/2014 18:00	0.0	0	0	0	0	1
07/25/2014 19:00	0.0	0	0	0	0	1
07/25/2014 20:00	0.0	0	0	0	0	1
07/25/2014 21:00	0.0	0	0	0	0	1
07/25/2014 22:00	0.0	0	0	0	0	1
07/25/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/26/2014 00:00	0.0	0	0	0	0	1
07/26/2014 01:00	0.0	0	0	0	0	1
07/26/2014 02:00	0.0	0	0	0	0	1
07/26/2014 03:00	0.0	0	0	0	0	1
07/26/2014 04:00	0.0	0	0	0	0	1
07/26/2014 05:00	0.0	0	0	0	0	1
07/26/2014 06:00	0.0	0	0	0	0	1
07/26/2014 07:00	0.0	0	0	0	0	1
07/26/2014 08:00	0.0	0	0	0	0	1
07/26/2014 09:00	0.0	0	0	0	0	1
07/26/2014 10:00	0.0	0	0	0	0	1
07/26/2014 11:00	0.0	0	0	0	0	1
07/26/2014 12:00	0.0	0	0	0	0	1
07/26/2014 13:00	0.0	0	0	0	0	1
07/26/2014 14:00	0.0	0	0	0	0	1
07/26/2014 15:00	0.0	0	0	0	0	1
07/26/2014 16:00	0.0	0	0	0	0	1
07/26/2014 17:00	0.0	0	0	0	0	1
07/26/2014 18:00	0.0	0	0	0	0	1
07/26/2014 19:00	0.0	0	0	0	0	1
07/26/2014 20:00	0.0	0	0	0	0	1
07/26/2014 21:00	0.0	0	0	0	0	1
07/26/2014 22:00	0.0	0	0	0	0	1
07/26/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/27/2014 00:00	0.0	0	0	0	0	1
07/27/2014 01:00	0.0	0	0	0	0	1
07/27/2014 02:00	0.0	0	0	0	0	1
07/27/2014 03:00	0.0	0	0	0	0	1
07/27/2014 04:00	0.0	0	0	0	0	1
07/27/2014 05:00	0.0	0	0	0	0	1
07/27/2014 06:00	0.0	0	0	0	0	1
07/27/2014 07:00	0.0	0	0	0	0	1
07/27/2014 08:00	0.0	0	0	0	0	1
07/27/2014 09:00	0.0	0	0	0	0	1
07/27/2014 10:00	0.0	0	0	0	0	1
07/27/2014 11:00	0.0	0	0	0	0	1
07/27/2014 12:00	0.0	0	0	0	0	1
07/27/2014 13:00	0.0	0	0	0	0	1
07/27/2014 14:00	0.0	0	0	0	0	1
07/27/2014 15:00	0.0	0	0	0	0	1
07/27/2014 16:00	0.0	0	0	0	0	1
07/27/2014 17:00	0.0	0	0	0	0	1
07/27/2014 18:00	0.0	0	0	0	0	1
07/27/2014 19:00	0.0	0	0	0	0	1
07/27/2014 20:00	0.0	0	0	0	0	1
07/27/2014 21:00	0.0	0	0	0	0	1
07/27/2014 22:00	0.0	0	0	0	0	1
07/27/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/28/2014 00:00	0.0	0	0	0	0	1
07/28/2014 01:00	0.0	0	0	0	0	1
07/28/2014 02:00	0.0	0	0	0	0	1
07/28/2014 03:00	0.0	0	0	0	0	1
07/28/2014 04:00	0.0	0	0	0	0	1
07/28/2014 05:00	0.0	0	0	0	0	1
07/28/2014 06:00	0.0	0	0	0	0	1
07/28/2014 07:00	0.0	0	0	0	0	1
07/28/2014 08:00	0.0	0	0	0	0	1
07/28/2014 09:00	0.0	0	0	0	0	1
07/28/2014 10:00	0.0	0	0	0	0	1
07/28/2014 11:00	0.0	0	0	0	0	1
07/28/2014 12:00	0.0	0	0	0	0	1
07/28/2014 13:00	0.0	0	0	0	0	1
07/28/2014 14:00	0.0	0	0	0	0	1
07/28/2014 15:00	0.0	0	0	0	0	1
07/28/2014 16:00	0.0	0	0	0	0	1
07/28/2014 17:00	0.0	0	0	0	0	1
07/28/2014 18:00	0.0	0	0	0	0	1
07/28/2014 19:00	0.0	0	0	0	0	1
07/28/2014 20:00	0.0	0	0	0	0	1
07/28/2014 21:00	0.0	0	0	0	0	1
07/28/2014 22:00	0.0	0	0	0	0	1
07/28/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/29/2014 00:00	0.0	0	0	0	0	1
07/29/2014 01:00	0.0	0	0	0	0	1
07/29/2014 02:00	0.0	0	0	0	0	1
07/29/2014 03:00	0.0	0	0	0	0	1
07/29/2014 04:00	0.0	0	0	0	0	1
07/29/2014 05:00	0.0	0	0	0	0	1
07/29/2014 06:00	0.0	0	0	0	0	1
07/29/2014 07:00	0.0	0	0	0	0	1
07/29/2014 08:00	0.0	0	0	0	0	1
07/29/2014 09:00	0.0	0	0	0	0	1
07/29/2014 10:00	0.0	0	0	0	0	1
07/29/2014 11:00	0.0	0	0	0	0	1
07/29/2014 12:00	0.0	0	0	0	0	1
07/29/2014 13:00	0.0	0	0	0	0	1
07/29/2014 14:00	0.0	0	0	0	0	1
07/29/2014 15:00	0.0	0	0	0	0	1
07/29/2014 16:00	0.0	0	0	0	0	1
07/29/2014 17:00	0.0	0	0	0	0	1
07/29/2014 18:00	0.0	0	0	0	0	1
07/29/2014 19:00	0.0	0	0	0	0	1
07/29/2014 20:00	0.0	0	0	0	0	1
07/29/2014 21:00	0.0	0	0	0	0	1
07/29/2014 22:00	0.0	0	0	0	0	1
07/29/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/30/2014 00:00	0.0	0	0	0	0	1
07/30/2014 01:00	0.0	0	0	0	0	1
07/30/2014 02:00	0.0	0	0	0	0	1
07/30/2014 03:00	0.0	0	0	0	0	1
07/30/2014 04:00	0.0	0	0	0	0	1
07/30/2014 05:00	0.0	0	0	0	0	1
07/30/2014 06:00	0.0	0	0	0	0	1
07/30/2014 07:00	0.0	0	0	0	0	1
07/30/2014 08:00	0.0	0	0	0	0	1
07/30/2014 09:00	0.0	0	0	0	0	1
07/30/2014 10:00	0.0	0	0	0	0	1
07/30/2014 11:00	0.0	0	0	0	0	1
07/30/2014 12:00	0.0	0	0	0	0	1
07/30/2014 13:00	0.0	0	0	0	0	1
07/30/2014 14:00	0.0	0	0	0	0	1
07/30/2014 15:00	0.0	0	0	0	0	1
07/30/2014 16:00	0.0	0	0	0	0	1
07/30/2014 17:00	0.0	0	0	0	0	1
07/30/2014 18:00	0.0	0	0	0	0	1
07/30/2014 19:00	0.0	0	0	0	0	1
07/30/2014 20:00	0.0	0	0	0	0	1
07/30/2014 21:00	0.0	0	0	0	0	1
07/30/2014 22:00	0.0	0	0	0	0	1
07/30/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/31/2014 00:00	0.0	0	0	0	0	1
07/31/2014 01:00	0.0	0	0	0	0	1
07/31/2014 02:00	0.0	0	0	0	0	1
07/31/2014 03:00	0.0	0	0	0	0	1
07/31/2014 04:00	0.0	0	0	0	0	1
07/31/2014 05:00	0.0	0	0	0	0	1
07/31/2014 06:00	0.0	0	0	0	0	1
07/31/2014 07:00	0.0	0	0	0	0	1
07/31/2014 08:00	0.0	0	0	0	0	1
07/31/2014 09:00	0.0	0	0	0	0	1
07/31/2014 10:00	0.0	0	0	0	0	1
07/31/2014 11:00	0.0	0	0	0	0	1
07/31/2014 12:00	0.0	0	0	0	0	1
07/31/2014 13:00	0.0	0	0	0	0	1
07/31/2014 14:00	0.0	0	0	0	0	1
07/31/2014 15:00	0.0	0	0	0	0	1
07/31/2014 16:00	0.0	0	0	0	0	1
07/31/2014 17:00	0.0	0	0	0	0	1
07/31/2014 18:00	0.0	0	0	0	0	1
07/31/2014 19:00	0.0	0	0	0	0	1
07/31/2014 20:00	0.0	0	0	0	0	1
07/31/2014 21:00	0.0	0	0	0	0	1
07/31/2014 22:00	0.0	0	0	0	0	1
07/31/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/01/2014 00:00	0.0	0	0	0	0	1
08/01/2014 01:00	0.0	0	0	0	0	1
08/01/2014 02:00	0.0	0	0	0	0	1
08/01/2014 03:00	0.0	0	0	0	0	1
08/01/2014 04:00	0.0	0	0	0	0	1
08/01/2014 05:00	0.0	0	0	0	0	1
08/01/2014 06:00	0.0	0	0	0	0	1
08/01/2014 07:00	0.0	0	0	0	0	1
08/01/2014 08:00	0.0	0	0	0	0	1
08/01/2014 09:00	0.0	0	0	0	0	1
08/01/2014 10:00	0.0	0	0	0	0	1
08/01/2014 11:00	0.0	0	0	0	0	1
08/01/2014 12:00	0.0	0	0	0	0	1
08/01/2014 13:00	0.0	0	0	0	0	1
08/01/2014 14:00	0.0	0	0	0	0	1
08/01/2014 15:00	0.0	0	0	0	0	1
08/01/2014 16:00	0.0	0	0	0	0	1
08/01/2014 17:00	0.0	0	0	0	0	1
08/01/2014 18:00	0.0	0	0	0	0	1
08/01/2014 19:00	0.0	0	0	0	0	1
08/01/2014 20:00	0.0	0	0	0	0	1
08/01/2014 21:00	0.0	0	0	0	0	1
08/01/2014 22:00	0.0	0	0	0	0	1
08/01/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/02/2014 00:00	0.0	0	0	0	0	1
08/02/2014 01:00	0.0	0	0	0	0	1
08/02/2014 02:00	0.0	0	0	0	0	1
08/02/2014 03:00	0.0	0	0	0	0	1
08/02/2014 04:00	0.0	0	0	0	0	1
08/02/2014 05:00	0.0	0	0	0	0	1
08/02/2014 06:00	0.0	0	0	0	0	1
08/02/2014 07:00	0.0	0	0	0	0	1
08/02/2014 08:00	0.0	0	0	0	0	1
08/02/2014 09:00	0.0	0	0	0	0	1
08/02/2014 10:00	0.0	0	0	0	0	1
08/02/2014 11:00	0.0	0	0	0	0	1
08/02/2014 12:00	0.0	0	0	0	0	1
08/02/2014 13:00	0.0	0	0	0	0	1
08/02/2014 14:00	0.0	0	0	0	0	1
08/02/2014 15:00	0.0	0	0	0	0	1
08/02/2014 16:00	0.0	0	0	0	0	1
08/02/2014 17:00	0.0	0	0	0	0	1
08/02/2014 18:00	0.0	0	0	0	0	1
08/02/2014 19:00	0.0	0	0	0	0	1
08/02/2014 20:00	0.0	0	0	0	0	1
08/02/2014 21:00	0.0	0	0	0	0	1
08/02/2014 22:00	0.0	0	0	0	0	1
08/02/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/03/2014 00:00	0.0	0	0	0	0	1
08/03/2014 01:00	0.0	0	0	0	0	1
08/03/2014 02:00	0.0	0	0	0	0	1
08/03/2014 03:00	0.0	0	0	0	0	1
08/03/2014 04:00	0.0	0	0	0	0	1
08/03/2014 05:00	0.0	0	0	0	0	1
08/03/2014 06:00	0.0	0	0	0	0	1
08/03/2014 07:00	0.0	0	0	0	0	1
08/03/2014 08:00	0.0	0	0	0	0	1
08/03/2014 09:00	0.0	0	0	0	0	1
08/03/2014 10:00	0.0	0	0	0	0	1
08/03/2014 11:00	0.0	0	0	0	0	1
08/03/2014 12:00	0.0	0	0	0	0	1
08/03/2014 13:00	0.0	0	0	0	0	1
08/03/2014 14:00	0.0	0	0	0	0	1
08/03/2014 15:00	0.0	0	0	0	0	1
08/03/2014 16:00	0.0	0	0	0	0	1
08/03/2014 17:00	0.0	0	0	0	0	1
08/03/2014 18:00	0.0	0	0	0	0	1
08/03/2014 19:00	0.0	0	0	0	0	1
08/03/2014 20:00	0.0	0	0	0	0	1
08/03/2014 21:00	0.0	0	0	0	0	1
08/03/2014 22:00	0.0	0	0	0	0	1
08/03/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/04/2014 00:00	0.0	0	0	0	0	1
08/04/2014 01:00	0.0	0	0	0	0	1
08/04/2014 02:00	0.0	0	0	0	0	1
08/04/2014 03:00	0.0	0	0	0	0	1
08/04/2014 04:00	0.0	0	0	0	0	1
08/04/2014 05:00	0.0	0	0	0	0	1
08/04/2014 06:00	0.0	0	0	0	0	1
08/04/2014 07:00	0.0	0	0	0	0	1
08/04/2014 08:00	0.0	0	0	0	0	1
08/04/2014 09:00	0.0	0	0	0	0	1
08/04/2014 10:00	0.0	0	0	0	0	1
08/04/2014 11:00	0.0	0	0	0	0	1
08/04/2014 12:00	0.0	0	0	0	0	1
08/04/2014 13:00	0.0	0	0	0	0	1
08/04/2014 14:00	0.0	0	0	0	0	1
08/04/2014 15:00	0.0	0	0	0	0	1
08/04/2014 16:00	0.0	0	0	0	0	1
08/04/2014 17:00	0.0	0	0	0	0	1
08/04/2014 18:00	0.0	0	0	0	0	1
08/04/2014 19:00	0.0	0	0	0	0	1
08/04/2014 20:00	0.0	0	0	0	0	1
08/04/2014 21:00	0.0	0	0	0	0	1
08/04/2014 22:00	0.0	0	0	0	0	1
08/04/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/05/2014 00:00	0.0	0	0	0	0	1
08/05/2014 01:00	0.0	0	0	0	0	1
08/05/2014 02:00	0.0	0	0	0	0	1
08/05/2014 03:00	0.0	0	0	0	0	1
08/05/2014 04:00	0.0	0	0	0	0	1
08/05/2014 05:00	0.0	0	0	0	0	1
08/05/2014 06:00	0.0	0	0	0	0	1
08/05/2014 07:00	0.0	0	0	0	0	1
08/05/2014 08:00	0.0	0	0	0	0	1
08/05/2014 09:00	0.0	0	0	0	0	1
08/05/2014 10:00	0.0	0	0	0	0	1
08/05/2014 11:00	0.0	0	0	0	0	1
08/05/2014 12:00	0.0	0	0	0	0	1
08/05/2014 13:00	0.0	0	0	0	0	1
08/05/2014 14:00	0.0	0	0	0	0	1
08/05/2014 15:00	0.0	0	0	0	0	1
08/05/2014 16:00	0.0	0	0	0	0	1
08/05/2014 17:00	0.0	0	0	0	0	1
08/05/2014 18:00	0.0	0	0	0	0	1
08/05/2014 19:00	0.0	0	0	0	0	1
08/05/2014 20:00	0.0	0	0	0	0	1
08/05/2014 21:00	0.0	0	0	0	0	1
08/05/2014 22:00	0.0	0	0	0	0	1
08/05/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/06/2014 00:00	0.0	0	0	0	0	1
08/06/2014 01:00	0.0	0	0	0	0	1
08/06/2014 02:00	0.0	0	0	0	0	1
08/06/2014 03:00	0.0	0	0	0	0	1
08/06/2014 04:00	0.0	0	0	0	0	1
08/06/2014 05:00	0.0	0	0	0	0	1
08/06/2014 06:00	0.0	0	0	0	0	1
08/06/2014 07:00	0.0	0	0	0	0	1
08/06/2014 08:00	0.0	0	0	0	0	1
08/06/2014 09:00	0.0	0	0	0	0	1
08/06/2014 10:00	0.0	0	0	0	0	1
08/06/2014 11:00	0.0	0	0	0	0	1
08/06/2014 12:00	0.0	0	0	0	0	1
08/06/2014 13:00	0.0	0	0	0	0	1
08/06/2014 14:00	0.0	0	0	0	0	1
08/06/2014 15:00	0.0	0	0	0	0	1
08/06/2014 16:00	0.0	0	0	0	0	1
08/06/2014 17:00	0.0	0	0	0	0	1
08/06/2014 18:00	0.0	0	0	0	0	1
08/06/2014 19:00	0.0	0	0	0	0	1
08/06/2014 20:00	0.0	0	0	0	0	1
08/06/2014 21:00	0.0	0	0	0	0	1
08/06/2014 22:00	0.0	0	0	0	0	1
08/06/2014 23:00	0.8	0	0	0	1	0
Average/Sum#:	0.8 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.8	0	0	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/07/2014 00:00	0.0	0	0	0	0	0
08/07/2014 01:00	0.0	0	0	0	0	0
08/07/2014 02:00	0.0	0	0	0	0	0
08/07/2014 03:00	0.0	0	0	0	0	0
08/07/2014 04:00	0.0	0	0	0	0	0
08/07/2014 05:00	0.0	0	0	0	0	0
08/07/2014 06:00	0.0	0	0	0	0	0
08/07/2014 07:00	0.0	0	0	0	0	0
08/07/2014 08:00	0.0	0	0	0	0	0
08/07/2014 09:00	0.0	0	0	0	0	0
08/07/2014 10:00	0.0	0	0	0	0	0
08/07/2014 11:00	0.0	0	0	0	0	0
08/07/2014 12:00	0.0	0	0	0	0	0
08/07/2014 13:00	20.6	0	1	0	0	0
08/07/2014 14:00	50.0	0	0	1	0	0
08/07/2014 15:00	1.4	0	0	1	0	0
08/07/2014 16:00	0.0	0	0	0	0	1
08/07/2014 17:00	0.0	0	0	0	0	1
08/07/2014 18:00	0.0	0	0	0	0	1
08/07/2014 19:00	0.0	0	0	0	0	1
08/07/2014 20:00	0.0	0	0	0	0	1
08/07/2014 21:00	0.0	0	0	0	0	1
08/07/2014 22:00	0.0	0	0	0	0	1
08/07/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	72.0 #	0 #	1 #	2 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	50.0	0	1	1	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/08/2014 00:00	0.0	0	0	0	0	1
08/08/2014 01:00	0.0	0	0	0	0	1
08/08/2014 02:00	0.0	0	0	0	0	1
08/08/2014 03:00	0.0	0	0	0	0	1
08/08/2014 04:00	0.0	0	0	0	0	1
08/08/2014 05:00	0.0	0	0	0	0	1
08/08/2014 06:00	0.0	0	0	0	0	1
08/08/2014 07:00	0.0	0	0	0	0	1
08/08/2014 08:00	0.0	0	0	0	0	1
08/08/2014 09:00	0.0	0	0	0	0	1
08/08/2014 10:00	0.0	0	0	0	0	1
08/08/2014 11:00	0.0	0	0	0	0	1
08/08/2014 12:00	0.0	0	0	0	0	1
08/08/2014 13:00	0.0	0	0	0	0	1
08/08/2014 14:00	0.0	0	0	0	0	1
08/08/2014 15:00	0.0	0	0	0	0	1
08/08/2014 16:00	0.0	0	0	0	0	1
08/08/2014 17:00	0.0	0	0	0	0	1
08/08/2014 18:00	0.0	0	0	0	0	1
08/08/2014 19:00	0.0	0	0	0	0	1
08/08/2014 20:00	0.0	0	0	0	0	1
08/08/2014 21:00	0.0	0	0	0	0	1
08/08/2014 22:00	0.0	0	0	0	0	1
08/08/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/09/2014 00:00	0.0	0	0	0	0	1
08/09/2014 01:00	0.0	0	0	0	0	1
08/09/2014 02:00	0.7	0	0	0	1	0
08/09/2014 03:00	0.0	0	0	0	0	0
08/09/2014 04:00	0.0	0	0	0	0	0
08/09/2014 05:00	0.0	0	0	0	0	0
08/09/2014 06:00	0.0	0	0	0	0	0
08/09/2014 07:00	0.0	0	0	0	0	0
08/09/2014 08:00	0.0	0	0	0	0	0
08/09/2014 09:00	0.0	0	0	0	0	0
08/09/2014 10:00	35.6	0	1	0	0	0
08/09/2014 11:00	7.5	0	1	0	0	0
08/09/2014 12:00	0.0	0	0	0	0	1
08/09/2014 13:00	0.0	0	0	0	0	1
08/09/2014 14:00	0.0	0	0	0	0	1
08/09/2014 15:00	0.0	0	0	0	0	1
08/09/2014 16:00	0.0	0	0	0	0	1
08/09/2014 17:00	0.0	0	0	0	0	1
08/09/2014 18:00	0.0	0	0	0	0	1
08/09/2014 19:00	0.0	0	0	0	0	1
08/09/2014 20:00	0.0	0	0	0	0	1
08/09/2014 21:00	0.0	0	0	0	0	1
08/09/2014 22:00	0.0	0	0	0	0	1
08/09/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	43.8 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	35.6	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/10/2014 00:00	1.1	0	0	0	1	0
08/10/2014 01:00	0.0	0	0	0	0	0
08/10/2014 02:00	0.0	0	0	0	0	0
08/10/2014 03:00	0.0	0	0	0	0	0
08/10/2014 04:00	0.0	0	0	0	0	0
08/10/2014 05:00	0.0	0	0	0	0	0
08/10/2014 06:00	0.0	0	0	0	0	0
08/10/2014 07:00	0.0	0	0	0	0	0
08/10/2014 08:00	0.0	0	0	0	0	0
08/10/2014 09:00	0.0	0	0	0	0	0
08/10/2014 10:00	0.0	0	0	0	0	0
08/10/2014 11:00	43.9	0	1	0	0	0
08/10/2014 12:00	13.3	0	1	0	0	0
08/10/2014 13:00	0.0	0	0	0	0	1
08/10/2014 14:00	0.0	0	0	0	0	1
08/10/2014 15:00	0.0	0	0	0	0	1
08/10/2014 16:00	0.0	0	0	0	0	1
08/10/2014 17:00	0.0	0	0	0	0	1
08/10/2014 18:00	0.0	0	0	0	0	1
08/10/2014 19:00	0.0	0	0	0	0	1
08/10/2014 20:00	0.0	0	0	0	0	1
08/10/2014 21:00	0.0	0	0	0	0	1
08/10/2014 22:00	0.0	0	0	0	0	1
08/10/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	58.3 #	0 #	2 #	0 #	1 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	43.9	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/11/2014 00:00	0.0	0	0	0	0	1
08/11/2014 01:00	0.0	0	0	0	0	1
08/11/2014 02:00	0.0	0	0	0	0	1
08/11/2014 03:00	0.0	0	0	0	0	1
08/11/2014 04:00	0.0	0	0	0	0	1
08/11/2014 05:00	0.0	0	0	0	0	1
08/11/2014 06:00	0.0	0	0	0	0	1
08/11/2014 07:00	0.0	0	0	0	0	1
08/11/2014 08:00	0.0	0	0	0	0	1
08/11/2014 09:00	0.0	0	0	0	0	1
08/11/2014 10:00	0.0	0	0	0	0	1
08/11/2014 11:00	0.0	0	0	0	0	1
08/11/2014 12:00	0.0	0	0	0	0	1
08/11/2014 13:00	0.0	0	0	0	0	1
08/11/2014 14:00	0.0	0	0	0	0	1
08/11/2014 15:00	0.0	0	0	0	0	1
08/11/2014 16:00	0.0	0	0	0	0	1
08/11/2014 17:00	0.0	0	0	0	0	1
08/11/2014 18:00	0.0	0	0	0	0	1
08/11/2014 19:00	0.0	0	0	0	0	1
08/11/2014 20:00	0.0	0	0	0	0	1
08/11/2014 21:00	0.0	0	0	0	0	1
08/11/2014 22:00	0.0	0	0	0	0	1
08/11/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/12/2014 00:00	0.0	0	0	0	0	1
08/12/2014 01:00	0.0	0	0	0	0	1
08/12/2014 02:00	0.0	0	0	0	0	1
08/12/2014 03:00	0.0	0	0	0	0	1
08/12/2014 04:00	0.0	0	0	0	0	1
08/12/2014 05:00	0.0	0	0	0	0	1
08/12/2014 06:00	0.0	0	0	0	0	1
08/12/2014 07:00	0.0	0	0	0	0	1
08/12/2014 08:00	0.0	0	0	0	0	1
08/12/2014 09:00	0.0	0	0	0	0	1
08/12/2014 10:00	0.0	0	0	0	0	1
08/12/2014 11:00	0.0	0	0	0	0	1
08/12/2014 12:00	0.0	0	0	0	0	1
08/12/2014 13:00	0.0	0	0	0	0	1
08/12/2014 14:00	0.0	0	0	0	0	1
08/12/2014 15:00	0.0	0	0	0	0	1
08/12/2014 16:00	0.0	0	0	0	0	1
08/12/2014 17:00	0.0	0	0	0	0	1
08/12/2014 18:00	0.0	0	0	0	0	1
08/12/2014 19:00	0.0	0	0	0	0	1
08/12/2014 20:00	0.0	0	0	0	0	1
08/12/2014 21:00	0.0	0	0	0	0	1
08/12/2014 22:00	0.0	0	0	0	0	1
08/12/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/13/2014 00:00	0.0	0	0	0	0	1
08/13/2014 01:00	1.0	0	0	0	1	0
08/13/2014 02:00	0.0	0	0	0	0	0
08/13/2014 03:00	0.0	0	0	0	0	0
08/13/2014 04:00	0.0	0	0	0	0	0
08/13/2014 05:00	0.0	0	0	0	0	0
08/13/2014 06:00	0.0	0	0	0	0	0
08/13/2014 07:00	0.0	0	0	0	0	0
08/13/2014 08:00	28.0	0	0	1	0	0
08/13/2014 09:00	14.5	0	0	1	0	0
08/13/2014 10:00	0.0	0	0	0	0	1
08/13/2014 11:00	0.0	0	0	0	0	1
08/13/2014 12:00	0.0	0	0	0	0	1
08/13/2014 13:00	0.0	0	0	0	0	1
08/13/2014 14:00	0.0	0	0	0	0	1
08/13/2014 15:00	0.0	0	0	0	0	1
08/13/2014 16:00	0.0	0	0	0	0	1
08/13/2014 17:00	0.0	0	0	0	0	1
08/13/2014 18:00	0.0	0	0	0	0	1
08/13/2014 19:00	0.0	0	0	0	0	1
08/13/2014 20:00	0.0	0	0	0	0	1
08/13/2014 21:00	0.0	0	0	0	0	1
08/13/2014 22:00	0.0	0	0	0	0	1
08/13/2014 23:00	0.7	0	0	0	1	0
Average/Sum#:	44.2 #	0 #	0 #	2 #	2 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	28.0	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/14/2014 00:00	0.0	0	0	0	0	0
08/14/2014 01:00	0.0	0	0	0	0	0
08/14/2014 02:00	0.0	0	0	0	0	0
08/14/2014 03:00	0.0	0	0	0	0	0
08/14/2014 04:00	0.0	0	0	0	0	0
08/14/2014 05:00	0.0	0	0	0	0	0
08/14/2014 06:00	0.0	0	0	0	0	0
08/14/2014 07:00	0.0	0	0	0	0	0
08/14/2014 08:00	0.0	0	0	0	0	0
08/14/2014 09:00	0.0	0	0	0	0	0
08/14/2014 10:00	0.0	0	0	0	0	0
08/14/2014 11:00	0.0	0	0	0	0	0
08/14/2014 12:00	0.0	0	0	0	0	0
08/14/2014 13:00	0.0	0	0	0	0	0
08/14/2014 14:00	0.0	0	0	0	0	0
08/14/2014 15:00	0.0	0	0	0	0	0
08/14/2014 16:00	0.0	0	0	0	0	0
08/14/2014 17:00	0.0	0	0	0	0	0
08/14/2014 18:00	0.0	0	0	0	0	0
08/14/2014 19:00	0.0	0	0	0	0	0
08/14/2014 20:00	0.0	0	0	0	0	0
08/14/2014 21:00	0.0	0	0	0	0	0
08/14/2014 22:00	0.0	0	0	0	0	0
08/14/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/15/2014 00:00	0.0	0	0	0	0	0
08/15/2014 01:00	0.0	0	0	0	0	0
08/15/2014 02:00	0.0	0	0	0	0	0
08/15/2014 03:00	0.0	0	0	0	0	0
08/15/2014 04:00	0.0	0	0	0	0	0
08/15/2014 05:00	0.0	0	0	0	0	0
08/15/2014 06:00	0.0	0	0	0	0	0
08/15/2014 07:00	0.0	0	0	0	0	0
08/15/2014 08:00	0.0	0	0	0	0	0
08/15/2014 09:00	0.0	0	0	0	0	0
08/15/2014 10:00	0.0	0	0	0	0	0
08/15/2014 11:00	0.0	0	0	0	0	0
08/15/2014 12:00	0.0	0	0	0	0	0
08/15/2014 13:00	0.0	0	0	0	0	0
08/15/2014 14:00	0.0	0	0	0	0	0
08/15/2014 15:00	0.0	0	0	0	0	0
08/15/2014 16:00	0.0	0	0	0	0	0
08/15/2014 17:00	0.0	0	0	0	0	0
08/15/2014 18:00	0.0	0	0	0	0	0
08/15/2014 19:00	0.0	0	0	0	0	0
08/15/2014 20:00	0.0	0	0	0	0	0
08/15/2014 21:00	0.0	0	0	0	0	0
08/15/2014 22:00	0.0	0	0	0	0	0
08/15/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/16/2014 00:00	0.0	0	0	0	0	0
08/16/2014 01:00	0.0	0	0	0	0	0
08/16/2014 02:00	0.0	0	0	0	0	0
08/16/2014 03:00	0.0	0	0	0	0	0
08/16/2014 04:00	0.0	0	0	0	0	0
08/16/2014 05:00	0.0	0	0	0	0	0
08/16/2014 06:00	0.0	0	0	0	0	0
08/16/2014 07:00	0.0	0	0	0	0	0
08/16/2014 08:00	0.0	0	0	0	0	0
08/16/2014 09:00	0.0	0	0	0	0	0
08/16/2014 10:00	0.0	0	0	0	0	0
08/16/2014 11:00	0.0	0	0	0	0	0
08/16/2014 12:00	0.0	0	0	0	0	0
08/16/2014 13:00	0.0	0	0	0	0	0
08/16/2014 14:00	0.0	0	0	0	0	0
08/16/2014 15:00	0.0	0	0	0	0	0
08/16/2014 16:00	0.0	0	0	0	0	0
08/16/2014 17:00	0.0	0	0	0	0	0
08/16/2014 18:00	0.0	0	0	0	0	0
08/16/2014 19:00	0.0	0	0	0	0	0
08/16/2014 20:00	0.0	0	0	0	0	0
08/16/2014 21:00	0.0	0	0	0	0	0
08/16/2014 22:00	0.0	0	0	0	0	0
08/16/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/17/2014 00:00	0.0	0	0	0	0	0
08/17/2014 01:00	0.0	0	0	0	0	0
08/17/2014 02:00	0.0	0	0	0	0	0
08/17/2014 03:00	0.0	0	0	0	0	0
08/17/2014 04:00	0.0	0	0	0	0	0
08/17/2014 05:00	0.0	0	0	0	0	0
08/17/2014 06:00	0.0	0	0	0	0	0
08/17/2014 07:00	0.0	0	0	0	0	0
08/17/2014 08:00	0.0	0	0	0	0	0
08/17/2014 09:00	0.0	0	0	0	0	0
08/17/2014 10:00	0.0	0	0	0	0	0
08/17/2014 11:00	0.0	0	0	0	0	0
08/17/2014 12:00	0.0	0	0	0	0	0
08/17/2014 13:00	0.0	0	0	0	0	0
08/17/2014 14:00	0.0	0	0	0	0	0
08/17/2014 15:00	0.0	0	0	0	0	0
08/17/2014 16:00	0.0	0	0	0	0	0
08/17/2014 17:00	0.0	0	0	0	0	0
08/17/2014 18:00	0.0	0	0	0	0	0
08/17/2014 19:00	0.0	0	0	0	0	0
08/17/2014 20:00	0.0	0	0	0	0	0
08/17/2014 21:00	0.0	0	0	0	0	0
08/17/2014 22:00	0.0	0	0	0	0	0
08/17/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/18/2014 00:00	0.0	0	0	0	0	0
08/18/2014 01:00	0.0	0	0	0	0	0
08/18/2014 02:00	0.0	0	0	0	0	0
08/18/2014 03:00	0.0	0	0	0	0	0
08/18/2014 04:00	0.0	0	0	0	0	0
08/18/2014 05:00	0.0	0	0	0	0	0
08/18/2014 06:00	0.0	0	0	0	0	0
08/18/2014 07:00	0.0	0	0	0	0	0
08/18/2014 08:00	0.0	0	0	0	0	0
08/18/2014 09:00	0.0	0	0	0	0	0
08/18/2014 10:00	0.0	0	0	0	0	0
08/18/2014 11:00	0.0	0	0	0	0	0
08/18/2014 12:00	0.0	0	0	0	0	0
08/18/2014 13:00	0.0	0	0	0	0	0
08/18/2014 14:00	0.0	0	0	0	0	0
08/18/2014 15:00	0.0	0	0	0	0	0
08/18/2014 16:00	0.0	0	0	0	0	0
08/18/2014 17:00	0.0	0	0	0	0	0
08/18/2014 18:00	0.0	0	0	0	0	0
08/18/2014 19:00	0.0	0	0	0	0	0
08/18/2014 20:00	0.0	0	0	0	0	0
08/18/2014 21:00	0.0	0	0	0	0	0
08/18/2014 22:00	0.0	0	0	0	0	0
08/18/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/19/2014 00:00	0.0	0	0	0	0	0
08/19/2014 01:00	0.0	0	0	0	0	0
08/19/2014 02:00	0.0	0	0	0	0	0
08/19/2014 03:00	0.0	0	0	0	0	0
08/19/2014 04:00	0.0	0	0	0	0	0
08/19/2014 05:00	0.0	0	0	0	0	0
08/19/2014 06:00	0.0	0	0	0	0	0
08/19/2014 07:00	0.0	0	0	0	0	0
08/19/2014 08:00	0.0	0	0	0	0	0
08/19/2014 09:00	0.0	0	0	0	0	0
08/19/2014 10:00	0.0	0	0	0	0	0
08/19/2014 11:00	0.0	0	0	0	0	0
08/19/2014 12:00	0.0	0	0	0	0	0
08/19/2014 13:00	0.0	0	0	0	0	0
08/19/2014 14:00	0.0	0	0	0	0	0
08/19/2014 15:00	0.0	0	0	0	0	0
08/19/2014 16:00	0.0	0	0	0	0	0
08/19/2014 17:00	0.0	0	0	0	0	0
08/19/2014 18:00	0.0	0	0	0	0	0
08/19/2014 19:00	0.0	0	0	0	0	0
08/19/2014 20:00	0.0	0	0	0	0	0
08/19/2014 21:00	0.0	0	0	0	0	0
08/19/2014 22:00	0.0	0	0	0	0	0
08/19/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/20/2014 00:00	0.0	0	0	0	0	0
08/20/2014 01:00	0.0	0	0	0	0	0
08/20/2014 02:00	0.0	0	0	0	0	0
08/20/2014 03:00	0.0	0	0	0	0	0
08/20/2014 04:00	0.0	0	0	0	0	0
08/20/2014 05:00	0.0	0	0	0	0	0
08/20/2014 06:00	0.0	0	0	0	0	0
08/20/2014 07:00	0.0	0	0	0	0	0
08/20/2014 08:00	0.0	0	0	0	0	0
08/20/2014 09:00	0.0	0	0	0	0	0
08/20/2014 10:00	0.0	0	0	0	0	0
08/20/2014 11:00	0.0	0	0	0	0	0
08/20/2014 12:00	0.0	0	0	0	0	0
08/20/2014 13:00	0.0	0	0	0	0	0
08/20/2014 14:00	0.0	0	0	0	0	0
08/20/2014 15:00	0.0	0	0	0	0	0
08/20/2014 16:00	0.0	0	0	0	0	0
08/20/2014 17:00	0.0	0	0	0	0	0
08/20/2014 18:00	0.0	0	0	0	0	0
08/20/2014 19:00	0.0	0	0	0	0	0
08/20/2014 20:00	0.0	0	0	0	0	0
08/20/2014 21:00	0.0	0	0	0	0	0
08/20/2014 22:00	0.0	0	0	0	0	0
08/20/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/21/2014 00:00	0.0	0	0	0	0	0
08/21/2014 01:00	0.0	0	0	0	0	0
08/21/2014 02:00	0.0	0	0	0	0	0
08/21/2014 03:00	0.0	0	0	0	0	0
08/21/2014 04:00	0.0	0	0	0	0	0
08/21/2014 05:00	0.0	0	0	0	0	0
08/21/2014 06:00	0.0	0	0	0	0	0
08/21/2014 07:00	0.0	0	0	0	0	0
08/21/2014 08:00	0.0	0	0	0	0	0
08/21/2014 09:00	0.0	0	0	0	0	0
08/21/2014 10:00	0.0	0	0	0	0	0
08/21/2014 11:00	0.0	0	0	0	0	0
08/21/2014 12:00	0.0	0	0	0	0	0
08/21/2014 13:00	0.0	0	0	0	0	0
08/21/2014 14:00	0.0	0	0	0	0	0
08/21/2014 15:00	0.0	0	0	0	0	0
08/21/2014 16:00	0.0	0	0	0	0	0
08/21/2014 17:00	0.0	0	0	0	0	0
08/21/2014 18:00	0.0	0	0	0	0	0
08/21/2014 19:00	0.0	0	0	0	0	0
08/21/2014 20:00	0.0	0	0	0	0	0
08/21/2014 21:00	0.0	0	0	0	0	0
08/21/2014 22:00	0.0	0	0	0	0	0
08/21/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/22/2014 00:00	0.0	0	0	0	0	0
08/22/2014 01:00	0.0	0	0	0	0	0
08/22/2014 02:00	0.0	0	0	0	0	0
08/22/2014 03:00	0.0	0	0	0	0	0
08/22/2014 04:00	0.0	0	0	0	0	0
08/22/2014 05:00	0.0	0	0	0	0	0
08/22/2014 06:00	0.0	0	0	0	0	0
08/22/2014 07:00	0.0	0	0	0	0	0
08/22/2014 08:00	0.0	0	0	0	0	0
08/22/2014 09:00	0.0	0	0	0	0	0
08/22/2014 10:00	0.0	0	0	0	0	0
08/22/2014 11:00	0.0	0	0	0	0	0
08/22/2014 12:00	0.0	0	0	0	0	0
08/22/2014 13:00	0.0	0	0	0	0	0
08/22/2014 14:00	0.0	0	0	0	0	0
08/22/2014 15:00	0.0	0	0	0	0	0
08/22/2014 16:00	0.0	0	0	0	0	0
08/22/2014 17:00	0.0	0	0	0	0	0
08/22/2014 18:00	0.0	0	0	0	0	0
08/22/2014 19:00	0.0	0	0	0	0	0
08/22/2014 20:00	0.0	0	0	0	0	0
08/22/2014 21:00	0.0	0	0	0	0	0
08/22/2014 22:00	0.0	0	0	0	0	0
08/22/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/23/2014 00:00	0.0	0	0	0	0	0
08/23/2014 01:00	0.0	0	0	0	0	0
08/23/2014 02:00	0.0	0	0	0	0	0
08/23/2014 03:00	0.0	0	0	0	0	0
08/23/2014 04:00	0.0	0	0	0	0	0
08/23/2014 05:00	0.0	0	0	0	0	0
08/23/2014 06:00	0.0	0	0	0	0	0
08/23/2014 07:00	0.0	0	0	0	0	0
08/23/2014 08:00	0.0	0	0	0	0	0
08/23/2014 09:00	0.0	0	0	0	0	0
08/23/2014 10:00	0.0	0	0	0	0	0
08/23/2014 11:00	0.0	0	0	0	0	0
08/23/2014 12:00	0.0	0	0	0	0	0
08/23/2014 13:00	0.0	0	0	0	0	0
08/23/2014 14:00	0.0	0	0	0	0	0
08/23/2014 15:00	0.0	0	0	0	0	0
08/23/2014 16:00	0.0	0	0	0	0	0
08/23/2014 17:00	0.0	0	0	0	0	0
08/23/2014 18:00	0.0	0	0	0	0	0
08/23/2014 19:00	0.0	0	0	0	0	0
08/23/2014 20:00	0.0	0	0	0	0	0
08/23/2014 21:00	0.0	0	0	0	0	0
08/23/2014 22:00	0.0	0	0	0	0	0
08/23/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/24/2014 00:00	0.0	0	0	0	0	0
08/24/2014 01:00	0.0	0	0	0	0	0
08/24/2014 02:00	0.0	0	0	0	0	0
08/24/2014 03:00	0.0	0	0	0	0	0
08/24/2014 04:00	0.0	0	0	0	0	0
08/24/2014 05:00	0.0	0	0	0	0	0
08/24/2014 06:00	0.0	0	0	0	0	0
08/24/2014 07:00	0.0	0	0	0	0	0
08/24/2014 08:00	0.0	0	0	0	0	0
08/24/2014 09:00	0.0	0	0	0	0	0
08/24/2014 10:00	0.0	0	0	0	0	0
08/24/2014 11:00	0.0	0	0	0	0	0
08/24/2014 12:00	0.0	0	0	0	0	0
08/24/2014 13:00	0.0	0	0	0	0	0
08/24/2014 14:00	0.0	0	0	0	0	0
08/24/2014 15:00	0.0	0	0	0	0	0
08/24/2014 16:00	0.0	0	0	0	0	0
08/24/2014 17:00	0.0	0	0	0	0	0
08/24/2014 18:00	0.0	0	0	0	0	0
08/24/2014 19:00	0.0	0	0	0	0	0
08/24/2014 20:00	0.0	0	0	0	0	0
08/24/2014 21:00	0.0	0	0	0	0	0
08/24/2014 22:00	0.0	0	0	0	0	0
08/24/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/25/2014 00:00	0.0	0	0	0	0	0
08/25/2014 01:00	0.0	0	0	0	0	0
08/25/2014 02:00	0.0	0	0	0	0	0
08/25/2014 03:00	0.0	0	0	0	0	0
08/25/2014 04:00	0.0	0	0	0	0	0
08/25/2014 05:00	0.0	0	0	0	0	0
08/25/2014 06:00	0.0	0	0	0	0	0
08/25/2014 07:00	0.0	0	0	0	0	0
08/25/2014 08:00	0.0	0	0	0	0	0
08/25/2014 09:00	0.0	0	0	0	0	0
08/25/2014 10:00	0.0	0	0	0	0	0
08/25/2014 11:00	0.0	0	0	0	0	0
08/25/2014 12:00	0.0	0	0	0	0	0
08/25/2014 13:00	0.0	0	0	0	0	0
08/25/2014 14:00	0.0	0	0	0	0	0
08/25/2014 15:00	0.0	0	0	0	0	0
08/25/2014 16:00	0.0	0	0	0	0	0
08/25/2014 17:00	0.0	0	0	0	0	0
08/25/2014 18:00	0.0	0	0	0	0	0
08/25/2014 19:00	0.0	0	0	0	0	0
08/25/2014 20:00	0.0	0	0	0	0	0
08/25/2014 21:00	0.0	0	0	0	0	0
08/25/2014 22:00	0.0	0	0	0	0	0
08/25/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/26/2014 00:00	0.0	0	0	0	0	0
08/26/2014 01:00	0.0	0	0	0	0	0
08/26/2014 02:00	0.0	0	0	0	0	0
08/26/2014 03:00	0.0	0	0	0	0	0
08/26/2014 04:00	0.0	0	0	0	0	0
08/26/2014 05:00	0.0	0	0	0	0	0
08/26/2014 06:00	0.0	0	0	0	0	0
08/26/2014 07:00	0.0	0	0	0	0	0
08/26/2014 08:00	0.0	0	0	0	0	0
08/26/2014 09:00	0.0	0	0	0	0	0
08/26/2014 10:00	0.0	0	0	0	0	0
08/26/2014 11:00	0.0	0	0	0	0	0
08/26/2014 12:00	0.0	0	0	0	0	0
08/26/2014 13:00	0.0	0	0	0	0	0
08/26/2014 14:00	0.0	0	0	0	0	0
08/26/2014 15:00	0.0	0	0	0	0	0
08/26/2014 16:00	0.0	0	0	0	0	0
08/26/2014 17:00	0.0	0	0	0	0	0
08/26/2014 18:00	0.0	0	0	0	0	0
08/26/2014 19:00	0.0	0	0	0	0	0
08/26/2014 20:00	0.0	0	0	0	0	0
08/26/2014 21:00	0.0	0	0	0	0	0
08/26/2014 22:00	0.0	0	0	0	0	0
08/26/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/27/2014 00:00	0.0	0	0	0	0	0
08/27/2014 01:00	0.0	0	0	0	0	0
08/27/2014 02:00	0.0	0	0	0	0	0
08/27/2014 03:00	0.0	0	0	0	0	0
08/27/2014 04:00	0.0	0	0	0	0	0
08/27/2014 05:00	0.0	0	0	0	0	0
08/27/2014 06:00	0.0	0	0	0	0	0
08/27/2014 07:00	0.0	0	0	0	0	0
08/27/2014 08:00	0.0	0	0	0	0	0
08/27/2014 09:00	0.0	0	0	0	0	0
08/27/2014 10:00	0.0	0	0	0	0	0
08/27/2014 11:00	0.0	0	0	0	0	0
08/27/2014 12:00	0.0	0	0	0	0	0
08/27/2014 13:00	0.0	0	0	0	0	0
08/27/2014 14:00	0.0	0	0	0	0	0
08/27/2014 15:00	0.0	0	0	0	0	0
08/27/2014 16:00	0.0	0	0	0	0	0
08/27/2014 17:00	0.0	0	0	0	0	0
08/27/2014 18:00	0.0	0	0	0	0	0
08/27/2014 19:00	0.0	0	0	0	0	0
08/27/2014 20:00	0.0	0	0	0	0	0
08/27/2014 21:00	0.0	0	0	0	0	0
08/27/2014 22:00	0.0	0	0	0	0	0
08/27/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/28/2014 00:00	0.0	0	0	0	0	0
08/28/2014 01:00	0.0	0	0	0	0	0
08/28/2014 02:00	0.0	0	0	0	0	0
08/28/2014 03:00	0.0	0	0	0	0	0
08/28/2014 04:00	0.0	0	0	0	0	0
08/28/2014 05:00	0.0	0	0	0	0	0
08/28/2014 06:00	0.0	0	0	0	0	0
08/28/2014 07:00	0.0	0	0	0	0	0
08/28/2014 08:00	0.0	0	0	0	0	0
08/28/2014 09:00	0.0	0	0	0	0	0
08/28/2014 10:00	0.0	0	0	0	0	0
08/28/2014 11:00	0.0	0	0	0	0	0
08/28/2014 12:00	0.0	0	0	0	0	0
08/28/2014 13:00	0.0	0	0	0	0	0
08/28/2014 14:00	0.0	0	0	0	0	0
08/28/2014 15:00	0.0	0	0	0	0	0
08/28/2014 16:00	0.0	0	0	0	0	0
08/28/2014 17:00	0.0	0	0	0	0	0
08/28/2014 18:00	0.0	0	0	0	0	0
08/28/2014 19:00	0.0	0	0	0	0	0
08/28/2014 20:00	0.0	0	0	0	0	0
08/28/2014 21:00	0.0	0	0	0	0	0
08/28/2014 22:00	0.0	0	0	0	0	0
08/28/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/29/2014 00:00	0.0	0	0	0	0	0
08/29/2014 01:00	0.0	0	0	0	0	0
08/29/2014 02:00	0.0	0	0	0	0	0
08/29/2014 03:00	0.0	0	0	0	0	0
08/29/2014 04:00	0.0	0	0	0	0	0
08/29/2014 05:00	0.0	0	0	0	0	0
08/29/2014 06:00	0.0	0	0	0	0	0
08/29/2014 07:00	0.0	0	0	0	0	0
08/29/2014 08:00	0.0	0	0	0	0	0
08/29/2014 09:00	0.0	0	0	0	0	0
08/29/2014 10:00	0.0	0	0	0	0	0
08/29/2014 11:00	0.0	0	0	0	0	0
08/29/2014 12:00	0.0	0	0	0	0	0
08/29/2014 13:00	0.0	0	0	0	0	0
08/29/2014 14:00	0.0	0	0	0	0	0
08/29/2014 15:00	0.0	0	0	0	0	0
08/29/2014 16:00	0.0	0	0	0	0	0
08/29/2014 17:00	0.0	0	0	0	0	0
08/29/2014 18:00	0.0	0	0	0	0	0
08/29/2014 19:00	0.0	0	0	0	0	0
08/29/2014 20:00	0.0	0	0	0	0	0
08/29/2014 21:00	0.0	0	0	0	0	0
08/29/2014 22:00	0.0	0	0	0	0	0
08/29/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/30/2014 00:00	0.0	0	0	0	0	0
08/30/2014 01:00	0.0	0	0	0	0	0
08/30/2014 02:00	0.0	0	0	0	0	0
08/30/2014 03:00	0.0	0	0	0	0	0
08/30/2014 04:00	0.0	0	0	0	0	0
08/30/2014 05:00	0.0	0	0	0	0	0
08/30/2014 06:00	0.0	0	0	0	0	0
08/30/2014 07:00	0.0	0	0	0	0	0
08/30/2014 08:00	0.0	0	0	0	0	0
08/30/2014 09:00	0.0	0	0	0	0	0
08/30/2014 10:00	0.0	0	0	0	0	0
08/30/2014 11:00	0.0	0	0	0	0	0
08/30/2014 12:00	0.0	0	0	0	0	0
08/30/2014 13:00	0.0	0	0	0	0	0
08/30/2014 14:00	0.0	0	0	0	0	0
08/30/2014 15:00	0.0	0	0	0	0	0
08/30/2014 16:00	0.0	0	0	0	0	0
08/30/2014 17:00	0.0	0	0	0	0	0
08/30/2014 18:00	0.0	0	0	0	0	0
08/30/2014 19:00	0.0	0	0	0	0	0
08/30/2014 20:00	0.0	0	0	0	0	0
08/30/2014 21:00	0.0	0	0	0	0	0
08/30/2014 22:00	0.0	0	0	0	0	0
08/30/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/31/2014 00:00	0.0	0	0	0	0	0
08/31/2014 01:00	0.0	0	0	0	0	0
08/31/2014 02:00	0.0	0	0	0	0	0
08/31/2014 03:00	0.0	0	0	0	0	0
08/31/2014 04:00	0.0	0	0	0	0	0
08/31/2014 05:00	0.0	0	0	0	0	0
08/31/2014 06:00	0.0	0	0	0	0	0
08/31/2014 07:00	0.0	0	0	0	0	0
08/31/2014 08:00	0.0	0	0	0	0	0
08/31/2014 09:00	0.0	0	0	0	0	0
08/31/2014 10:00	0.0	0	0	0	0	0
08/31/2014 11:00	0.0	0	0	0	0	0
08/31/2014 12:00	0.0	0	0	0	0	0
08/31/2014 13:00	0.0	0	0	0	0	0
08/31/2014 14:00	0.0	0	0	0	0	0
08/31/2014 15:00	0.0	0	0	0	0	0
08/31/2014 16:00	0.0	0	0	0	0	0
08/31/2014 17:00	0.0	0	0	0	0	0
08/31/2014 18:00	0.0	0	0	0	0	0
08/31/2014 19:00	0.0	0	0	0	0	0
08/31/2014 20:00	0.0	0	0	0	0	0
08/31/2014 21:00	0.0	0	0	0	0	0
08/31/2014 22:00	0.0	0	0	0	0	0
08/31/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/01/2014 00:00	0.0	0	0	0	0	0
09/01/2014 01:00	0.0	0	0	0	0	0
09/01/2014 02:00	0.0	0	0	0	0	0
09/01/2014 03:00	0.0	0	0	0	0	0
09/01/2014 04:00	0.0	0	0	0	0	0
09/01/2014 05:00	0.0	0	0	0	0	0
09/01/2014 06:00	0.0	0	0	0	0	0
09/01/2014 07:00	0.0	0	0	0	0	0
09/01/2014 08:00	0.0	0	0	0	0	0
09/01/2014 09:00	0.0	0	0	0	0	0
09/01/2014 10:00	0.0	0	0	0	0	0
09/01/2014 11:00	0.0	0	0	0	0	0
09/01/2014 12:00	0.0	0	0	0	0	0
09/01/2014 13:00	0.0	0	0	0	0	0
09/01/2014 14:00	0.0	0	0	0	0	0
09/01/2014 15:00	0.0	0	0	0	0	0
09/01/2014 16:00	0.0	0	0	0	0	0
09/01/2014 17:00	0.0	0	0	0	0	0
09/01/2014 18:00	0.0	0	0	0	0	0
09/01/2014 19:00	0.0	0	0	0	0	0
09/01/2014 20:00	0.0	0	0	0	0	0
09/01/2014 21:00	0.0	0	0	0	0	0
09/01/2014 22:00	0.0	0	0	0	0	0
09/01/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/02/2014 00:00	0.0	0	0	0	0	0
09/02/2014 01:00	0.0	0	0	0	0	0
09/02/2014 02:00	0.0	0	0	0	0	0
09/02/2014 03:00	0.0	0	0	0	0	0
09/02/2014 04:00	0.0	0	0	0	0	0
09/02/2014 05:00	0.0	0	0	0	0	0
09/02/2014 06:00	0.0	0	0	0	0	0
09/02/2014 07:00	0.0	0	0	0	0	0
09/02/2014 08:00	0.0	0	0	0	0	0
09/02/2014 09:00	0.0	0	0	0	0	0
09/02/2014 10:00	0.0	0	0	0	0	0
09/02/2014 11:00	0.0	0	0	0	0	0
09/02/2014 12:00	0.0	0	0	0	0	0
09/02/2014 13:00	0.0	0	0	0	0	0
09/02/2014 14:00	0.0	0	0	0	0	0
09/02/2014 15:00	0.0	0	0	0	0	0
09/02/2014 16:00	0.0	0	0	0	0	0
09/02/2014 17:00	0.0	0	0	0	0	0
09/02/2014 18:00	0.0	0	0	0	0	0
09/02/2014 19:00	0.0	0	0	0	0	0
09/02/2014 20:00	0.0	0	0	0	0	0
09/02/2014 21:00	0.0	0	0	0	0	0
09/02/2014 22:00	0.0	0	0	0	0	0
09/02/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/03/2014 00:00	0.0	0	0	0	0	0
09/03/2014 01:00	0.0	0	0	0	0	0
09/03/2014 02:00	0.0	0	0	0	0	0
09/03/2014 03:00	0.0	0	0	0	0	0
09/03/2014 04:00	0.0	0	0	0	0	0
09/03/2014 05:00	0.0	0	0	0	0	0
09/03/2014 06:00	0.0	0	0	0	0	0
09/03/2014 07:00	0.0	0	0	0	0	0
09/03/2014 08:00	0.0	0	0	0	0	0
09/03/2014 09:00	0.0	0	0	0	0	0
09/03/2014 10:00	0.0	0	0	0	0	0
09/03/2014 11:00	0.0	0	0	0	0	0
09/03/2014 12:00	0.0	0	0	0	0	0
09/03/2014 13:00	0.0	0	0	0	0	0
09/03/2014 14:00	0.0	0	0	0	0	0
09/03/2014 15:00	0.0	0	0	0	0	0
09/03/2014 16:00	0.0	0	0	0	0	0
09/03/2014 17:00	0.0	0	0	0	0	0
09/03/2014 18:00	0.0	0	0	0	0	0
09/03/2014 19:00	0.0	0	0	0	0	0
09/03/2014 20:00	0.0	0	0	0	0	0
09/03/2014 21:00	0.0	0	0	0	0	0
09/03/2014 22:00	0.0	0	0	0	0	0
09/03/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/04/2014 00:00	0.0	0	0	0	0	0
09/04/2014 01:00	0.0	0	0	0	0	0
09/04/2014 02:00	0.0	0	0	0	0	0
09/04/2014 03:00	0.0	0	0	0	0	0
09/04/2014 04:00	0.0	0	0	0	0	0
09/04/2014 05:00	0.0	0	0	0	0	0
09/04/2014 06:00	0.0	0	0	0	0	0
09/04/2014 07:00	0.0	0	0	0	0	0
09/04/2014 08:00	0.0	0	0	0	0	0
09/04/2014 09:00	0.0	0	0	0	0	0
09/04/2014 10:00	0.0	0	0	0	0	0
09/04/2014 11:00	0.0	0	0	0	0	0
09/04/2014 12:00	0.0	0	0	0	0	0
09/04/2014 13:00	0.0	0	0	0	0	0
09/04/2014 14:00	0.0	0	0	0	0	0
09/04/2014 15:00	0.0	0	0	0	0	0
09/04/2014 16:00	0.0	0	0	0	0	0
09/04/2014 17:00	0.0	0	0	0	0	0
09/04/2014 18:00	0.0	0	0	0	0	0
09/04/2014 19:00	0.0	0	0	0	0	0
09/04/2014 20:00	0.0	0	0	0	0	0
09/04/2014 21:00	0.0	0	0	0	0	0
09/04/2014 22:00	0.0	0	0	0	0	0
09/04/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/05/2014 00:00	0.0	0	0	0	0	0
09/05/2014 01:00	0.0	0	0	0	0	0
09/05/2014 02:00	0.0	0	0	0	0	0
09/05/2014 03:00	0.0	0	0	0	0	0
09/05/2014 04:00	0.0	0	0	0	0	0
09/05/2014 05:00	0.0	0	0	0	0	0
09/05/2014 06:00	0.0	0	0	0	0	0
09/05/2014 07:00	72.9	1	0	0	0	0
09/05/2014 08:00	63.1	1	0	0	0	0
09/05/2014 09:00	0.0	0	0	0	0	1
09/05/2014 10:00	0.0	0	0	0	0	1
09/05/2014 11:00	0.0	0	0	0	0	1
09/05/2014 12:00	0.0	0	0	0	0	1
09/05/2014 13:00	0.0	0	0	0	0	1
09/05/2014 14:00	0.0	0	0	0	0	1
09/05/2014 15:00	0.0	0	0	0	0	1
09/05/2014 16:00	0.0	0	0	0	0	1
09/05/2014 17:00	0.0	0	0	0	0	1
09/05/2014 18:00	0.0	0	0	0	0	1
09/05/2014 19:00	0.0	0	0	0	0	1
09/05/2014 20:00	0.0	0	0	0	0	1
09/05/2014 21:00	0.0	0	0	0	0	1
09/05/2014 22:00	0.0	0	0	0	0	1
09/05/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	136.0 #	2 #	0 #	0 #	0 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	72.9	1	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/06/2014 00:00	0.0	0	0	0	0	1
09/06/2014 01:00	0.0	0	0	0	0	1
09/06/2014 02:00	0.0	0	0	0	0	1
09/06/2014 03:00	0.0	0	0	0	0	1
09/06/2014 04:00	0.0	0	0	0	0	1
09/06/2014 05:00	0.0	0	0	0	0	1
09/06/2014 06:00	0.0	0	0	0	0	1
09/06/2014 07:00	0.0	0	0	0	0	1
09/06/2014 08:00	0.0	0	0	0	0	1
09/06/2014 09:00	0.0	0	0	0	0	1
09/06/2014 10:00	0.0	0	0	0	0	1
09/06/2014 11:00	0.0	0	0	0	0	1
09/06/2014 12:00	0.0	0	0	0	0	1
09/06/2014 13:00	0.0	0	0	0	0	1
09/06/2014 14:00	0.0	0	0	0	0	1
09/06/2014 15:00	0.0	0	0	0	0	1
09/06/2014 16:00	0.0	0	0	0	0	1
09/06/2014 17:00	0.0	0	0	0	0	1
09/06/2014 18:00	0.0	0	0	0	0	1
09/06/2014 19:00	0.0	0	0	0	0	1
09/06/2014 20:00	0.0	0	0	0	0	1
09/06/2014 21:00	0.0	0	0	0	0	1
09/06/2014 22:00	0.0	0	0	0	0	1
09/06/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/07/2014 00:00	0.0	0	0	0	0	1
09/07/2014 01:00	0.0	0	0	0	0	1
09/07/2014 02:00	0.0	0	0	0	0	1
09/07/2014 03:00	0.0	0	0	0	0	1
09/07/2014 04:00	0.0	0	0	0	0	1
09/07/2014 05:00	0.0	0	0	0	0	1
09/07/2014 06:00	0.0	0	0	0	0	1
09/07/2014 07:00	0.0	0	0	0	0	1
09/07/2014 08:00	0.0	0	0	0	0	1
09/07/2014 09:00	0.0	0	0	0	0	1
09/07/2014 10:00	0.0	0	0	0	0	1
09/07/2014 11:00	0.0	0	0	0	0	1
09/07/2014 12:00	0.0	0	0	0	0	1
09/07/2014 13:00	0.0	0	0	0	0	1
09/07/2014 14:00	0.0	0	0	0	0	1
09/07/2014 15:00	0.0	0	0	0	0	1
09/07/2014 16:00	0.0	0	0	0	0	1
09/07/2014 17:00	0.0	0	0	0	0	1
09/07/2014 18:00	0.0	0	0	0	0	1
09/07/2014 19:00	0.0	0	0	0	0	1
09/07/2014 20:00	0.0	0	0	0	0	1
09/07/2014 21:00	0.0	0	0	0	0	1
09/07/2014 22:00	0.0	0	0	0	0	1
09/07/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/08/2014 00:00	0.0	0	0	0	0	1
09/08/2014 01:00	0.0	0	0	0	0	1
09/08/2014 02:00	0.0	0	0	0	0	1
09/08/2014 03:00	0.0	0	0	0	0	1
09/08/2014 04:00	0.0	0	0	0	0	1
09/08/2014 05:00	0.0	0	0	0	0	1
09/08/2014 06:00	0.0	0	0	0	0	1
09/08/2014 07:00	0.0	0	0	0	0	1
09/08/2014 08:00	0.0	0	0	0	0	1
09/08/2014 09:00	0.0	0	0	0	0	1
09/08/2014 10:00	0.0	0	0	0	0	1
09/08/2014 11:00	0.0	0	0	0	0	1
09/08/2014 12:00	0.0	0	0	0	0	1
09/08/2014 13:00	0.0	0	0	0	0	1
09/08/2014 14:00	0.0	0	0	0	0	1
09/08/2014 15:00	0.0	0	0	0	0	1
09/08/2014 16:00	0.0	0	0	0	0	1
09/08/2014 17:00	0.0	0	0	0	0	1
09/08/2014 18:00	0.0	0	0	0	0	1
09/08/2014 19:00	0.0	0	0	0	0	1
09/08/2014 20:00	0.0	0	0	0	0	1
09/08/2014 21:00	0.0	0	0	0	0	1
09/08/2014 22:00	0.0	0	0	0	0	1
09/08/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/09/2014 00:00	0.0	0	0	0	0	1
09/09/2014 01:00	0.0	0	0	0	0	1
09/09/2014 02:00	0.0	0	0	0	0	1
09/09/2014 03:00	0.0	0	0	0	0	1
09/09/2014 04:00	0.0	0	0	0	0	1
09/09/2014 05:00	0.0	0	0	0	0	1
09/09/2014 06:00	0.0	0	0	0	0	1
09/09/2014 07:00	0.0	0	0	0	0	1
09/09/2014 08:00	0.0	0	0	0	0	1
09/09/2014 09:00	0.0	0	0	0	0	1
09/09/2014 10:00	0.0	0	0	0	0	1
09/09/2014 11:00	0.0	0	0	0	0	1
09/09/2014 12:00	0.0	0	0	0	0	1
09/09/2014 13:00	0.0	0	0	0	0	1
09/09/2014 14:00	0.0	0	0	0	0	1
09/09/2014 15:00	0.0	0	0	0	0	1
09/09/2014 16:00	0.0	0	0	0	0	1
09/09/2014 17:00	0.0	0	0	0	0	1
09/09/2014 18:00	0.0	0	0	0	0	1
09/09/2014 19:00	0.0	0	0	0	0	1
09/09/2014 20:00	0.0	0	0	0	0	1
09/09/2014 21:00	0.0	0	0	0	0	1
09/09/2014 22:00	0.0	0	0	0	0	1
09/09/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/10/2014 00:00	0.0	0	0	0	0	1
09/10/2014 01:00	0.0	0	0	0	0	1
09/10/2014 02:00	0.0	0	0	0	0	1
09/10/2014 03:00	0.0	0	0	0	0	1
09/10/2014 04:00	0.0	0	0	0	0	1
09/10/2014 05:00	0.0	0	0	0	0	1
09/10/2014 06:00	0.0	0	0	0	0	1
09/10/2014 07:00	0.0	0	0	0	0	1
09/10/2014 08:00	0.0	0	0	0	0	1
09/10/2014 09:00	0.0	0	0	0	0	1
09/10/2014 10:00	0.0	0	0	0	0	1
09/10/2014 11:00	0.0	0	0	0	0	1
09/10/2014 12:00	0.0	0	0	0	0	1
09/10/2014 13:00	0.0	0	0	0	0	1
09/10/2014 14:00	0.0	0	0	0	0	1
09/10/2014 15:00	0.0	0	0	0	0	1
09/10/2014 16:00	0.0	0	0	0	0	1
09/10/2014 17:00	0.0	0	0	0	0	1
09/10/2014 18:00	0.0	0	0	0	0	1
09/10/2014 19:00	0.0	0	0	0	0	1
09/10/2014 20:00	0.0	0	0	0	0	1
09/10/2014 21:00	0.0	0	0	0	0	1
09/10/2014 22:00	0.0	0	0	0	0	1
09/10/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/11/2014 00:00	0.0	0	0	0	0	1
09/11/2014 01:00	0.0	0	0	0	0	1
09/11/2014 02:00	0.0	0	0	0	0	1
09/11/2014 03:00	0.0	0	0	0	0	1
09/11/2014 04:00	0.0	0	0	0	0	1
09/11/2014 05:00	0.0	0	0	0	0	1
09/11/2014 06:00	0.0	0	0	0	0	1
09/11/2014 07:00	0.0	0	0	0	0	1
09/11/2014 08:00	0.0	0	0	0	0	1
09/11/2014 09:00	0.0	0	0	0	0	1
09/11/2014 10:00	0.0	0	0	0	0	1
09/11/2014 11:00	0.0	0	0	0	0	1
09/11/2014 12:00	0.0	0	0	0	0	1
09/11/2014 13:00	0.0	0	0	0	0	1
09/11/2014 14:00	0.0	0	0	0	0	1
09/11/2014 15:00	0.0	0	0	0	0	1
09/11/2014 16:00	0.0	0	0	0	0	1
09/11/2014 17:00	0.0	0	0	0	0	1
09/11/2014 18:00	0.0	0	0	0	0	1
09/11/2014 19:00	0.0	0	0	0	0	1
09/11/2014 20:00	0.0	0	0	0	0	1
09/11/2014 21:00	0.0	0	0	0	0	1
09/11/2014 22:00	0.0	0	0	0	0	1
09/11/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/12/2014 00:00	0.0	0	0	0	0	1
09/12/2014 01:00	0.0	0	0	0	0	1
09/12/2014 02:00	0.0	0	0	0	0	1
09/12/2014 03:00	0.0	0	0	0	0	1
09/12/2014 04:00	0.0	0	0	0	0	1
09/12/2014 05:00	0.0	0	0	0	0	1
09/12/2014 06:00	0.0	0	0	0	0	1
09/12/2014 07:00	0.0	0	0	0	0	1
09/12/2014 08:00	0.0	0	0	0	0	1
09/12/2014 09:00	0.0	0	0	0	0	1
09/12/2014 10:00	0.0	0	0	0	0	1
09/12/2014 11:00	0.0	0	0	0	0	1
09/12/2014 12:00	0.0	0	0	0	0	1
09/12/2014 13:00	0.0	0	0	0	0	1
09/12/2014 14:00	0.0	0	0	0	0	1
09/12/2014 15:00	0.0	0	0	0	0	1
09/12/2014 16:00	0.0	0	0	0	0	1
09/12/2014 17:00	0.0	0	0	0	0	1
09/12/2014 18:00	0.0	0	0	0	0	1
09/12/2014 19:00	0.0	0	0	0	0	1
09/12/2014 20:00	0.0	0	0	0	0	1
09/12/2014 21:00	0.0	0	0	0	0	1
09/12/2014 22:00	0.0	0	0	0	0	1
09/12/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/13/2014 00:00	0.0	0	0	0	0	1
09/13/2014 01:00	0.0	0	0	0	0	1
09/13/2014 02:00	0.0	0	0	0	0	1
09/13/2014 03:00	0.0	0	0	0	0	1
09/13/2014 04:00	0.0	0	0	0	0	1
09/13/2014 05:00	0.0	0	0	0	0	1
09/13/2014 06:00	0.0	0	0	0	0	1
09/13/2014 07:00	0.0	0	0	0	0	1
09/13/2014 08:00	0.0	0	0	0	0	1
09/13/2014 09:00	0.0	0	0	0	0	1
09/13/2014 10:00	0.0	0	0	0	0	1
09/13/2014 11:00	0.0	0	0	0	0	1
09/13/2014 12:00	0.0	0	0	0	0	1
09/13/2014 13:00	0.0	0	0	0	0	1
09/13/2014 14:00	0.0	0	0	0	0	1
09/13/2014 15:00	0.0	0	0	0	0	1
09/13/2014 16:00	0.0	0	0	0	0	1
09/13/2014 17:00	0.0	0	0	0	0	1
09/13/2014 18:00	0.0	0	0	0	0	1
09/13/2014 19:00	0.0	0	0	0	0	1
09/13/2014 20:00	0.0	0	0	0	0	1
09/13/2014 21:00	0.0	0	0	0	0	1
09/13/2014 22:00	0.0	0	0	0	0	1
09/13/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/14/2014 00:00	0.0	0	0	0	0	1
09/14/2014 01:00	0.0	0	0	0	0	1
09/14/2014 02:00	0.0	0	0	0	0	1
09/14/2014 03:00	0.0	0	0	0	0	1
09/14/2014 04:00	0.0	0	0	0	0	1
09/14/2014 05:00	0.0	0	0	0	0	1
09/14/2014 06:00	0.0	0	0	0	0	1
09/14/2014 07:00	0.0	0	0	0	0	1
09/14/2014 08:00	0.0	0	0	0	0	1
09/14/2014 09:00	0.0	0	0	0	0	1
09/14/2014 10:00	0.0	0	0	0	0	1
09/14/2014 11:00	0.0	0	0	0	0	1
09/14/2014 12:00	0.0	0	0	0	0	1
09/14/2014 13:00	0.0	0	0	0	0	1
09/14/2014 14:00	0.0	0	0	0	0	1
09/14/2014 15:00	0.0	0	0	0	0	1
09/14/2014 16:00	0.0	0	0	0	0	1
09/14/2014 17:00	0.0	0	0	0	0	1
09/14/2014 18:00	0.0	0	0	0	0	1
09/14/2014 19:00	0.0	0	0	0	0	1
09/14/2014 20:00	0.0	0	0	0	0	1
09/14/2014 21:00	0.0	0	0	0	0	1
09/14/2014 22:00	0.0	0	0	0	0	1
09/14/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/15/2014 00:00	0.0	0	0	0	0	1
09/15/2014 01:00	0.0	0	0	0	0	1
09/15/2014 02:00	0.0	0	0	0	0	1
09/15/2014 03:00	0.0	0	0	0	0	1
09/15/2014 04:00	0.0	0	0	0	0	1
09/15/2014 05:00	0.0	0	0	0	0	1
09/15/2014 06:00	0.0	0	0	0	0	1
09/15/2014 07:00	0.0	0	0	0	0	1
09/15/2014 08:00	0.0	0	0	0	0	1
09/15/2014 09:00	0.0	0	0	0	0	1
09/15/2014 10:00	0.0	0	0	0	0	1
09/15/2014 11:00	0.0	0	0	0	0	1
09/15/2014 12:00	0.0	0	0	0	0	1
09/15/2014 13:00	0.0	0	0	0	0	1
09/15/2014 14:00	0.0	0	0	0	0	1
09/15/2014 15:00	0.0	0	0	0	0	1
09/15/2014 16:00	0.0	0	0	0	0	1
09/15/2014 17:00	0.0	0	0	0	0	1
09/15/2014 18:00	0.0	0	0	0	0	1
09/15/2014 19:00	0.0	0	0	0	0	1
09/15/2014 20:00	0.0	0	0	0	0	1
09/15/2014 21:00	0.0	0	0	0	0	1
09/15/2014 22:00	0.0	0	0	0	0	1
09/15/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/16/2014 00:00	0.0	0	0	0	0	1
09/16/2014 01:00	0.0	0	0	0	0	1
09/16/2014 02:00	0.0	0	0	0	0	1
09/16/2014 03:00	0.0	0	0	0	0	1
09/16/2014 04:00	0.0	0	0	0	0	1
09/16/2014 05:00	0.0	0	0	0	0	1
09/16/2014 06:00	0.0	0	0	0	0	1
09/16/2014 07:00	0.0	0	0	0	0	1
09/16/2014 08:00	0.0	0	0	0	0	1
09/16/2014 09:00	0.0	0	0	0	0	1
09/16/2014 10:00	0.0	0	0	0	0	1
09/16/2014 11:00	0.0	0	0	0	0	1
09/16/2014 12:00	0.0	0	0	0	0	1
09/16/2014 13:00	0.0	0	0	0	0	1
09/16/2014 14:00	0.0	0	0	0	0	1
09/16/2014 15:00	0.0	0	0	0	0	1
09/16/2014 16:00	0.0	0	0	0	0	1
09/16/2014 17:00	0.0	0	0	0	0	1
09/16/2014 18:00	0.0	0	0	0	0	1
09/16/2014 19:00	0.0	0	0	0	0	1
09/16/2014 20:00	0.0	0	0	0	0	1
09/16/2014 21:00	0.0	0	0	0	0	1
09/16/2014 22:00	0.0	0	0	0	0	1
09/16/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/17/2014 00:00	0.0	0	0	0	0	1
09/17/2014 01:00	0.0	0	0	0	0	1
09/17/2014 02:00	0.0	0	0	0	0	1
09/17/2014 03:00	0.0	0	0	0	0	1
09/17/2014 04:00	0.0	0	0	0	0	1
09/17/2014 05:00	0.0	0	0	0	0	1
09/17/2014 06:00	0.0	0	0	0	0	1
09/17/2014 07:00	0.0	0	0	0	0	1
09/17/2014 08:00	0.0	0	0	0	0	1
09/17/2014 09:00	0.0	0	0	0	0	1
09/17/2014 10:00	0.0	0	0	0	0	1
09/17/2014 11:00	0.0	0	0	0	0	1
09/17/2014 12:00	0.0	0	0	0	0	1
09/17/2014 13:00	0.0	0	0	0	0	1
09/17/2014 14:00	0.0	0	0	0	0	1
09/17/2014 15:00	0.0	0	0	0	0	1
09/17/2014 16:00	0.0	0	0	0	0	1
09/17/2014 17:00	0.0	0	0	0	0	1
09/17/2014 18:00	0.0	0	0	0	0	1
09/17/2014 19:00	0.0	0	0	0	0	1
09/17/2014 20:00	0.0	0	0	0	0	1
09/17/2014 21:00	0.0	0	0	0	0	1
09/17/2014 22:00	0.0	0	0	0	0	1
09/17/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/18/2014 00:00	0.0	0	0	0	0	1
09/18/2014 01:00	0.0	0	0	0	0	1
09/18/2014 02:00	0.0	0	0	0	0	1
09/18/2014 03:00	0.0	0	0	0	0	1
09/18/2014 04:00	0.0	0	0	0	0	1
09/18/2014 05:00	0.0	0	0	0	0	1
09/18/2014 06:00	0.0	0	0	0	0	1
09/18/2014 07:00	0.0	0	0	0	0	1
09/18/2014 08:00	0.0	0	0	0	0	1
09/18/2014 09:00	0.0	0	0	0	0	1
09/18/2014 10:00	0.0	0	0	0	0	1
09/18/2014 11:00	0.0	0	0	0	0	1
09/18/2014 12:00	0.0	0	0	0	0	1
09/18/2014 13:00	0.0	0	0	0	0	1
09/18/2014 14:00	0.0	0	0	0	0	1
09/18/2014 15:00	0.0	0	0	0	0	1
09/18/2014 16:00	0.0	0	0	0	0	1
09/18/2014 17:00	0.0	0	0	0	0	1
09/18/2014 18:00	0.0	0	0	0	0	1
09/18/2014 19:00	0.0	0	0	0	0	1
09/18/2014 20:00	0.0	0	0	0	0	1
09/18/2014 21:00	0.0	0	0	0	0	1
09/18/2014 22:00	0.0	0	0	0	0	1
09/18/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/19/2014 00:00	0.0	0	0	0	0	1
09/19/2014 01:00	0.0	0	0	0	0	1
09/19/2014 02:00	0.0	0	0	0	0	1
09/19/2014 03:00	0.0	0	0	0	0	1
09/19/2014 04:00	0.0	0	0	0	0	1
09/19/2014 05:00	0.0	0	0	0	0	1
09/19/2014 06:00	0.0	0	0	0	0	1
09/19/2014 07:00	0.0	0	0	0	0	1
09/19/2014 08:00	0.0	0	0	0	0	1
09/19/2014 09:00	0.0	0	0	0	0	1
09/19/2014 10:00	0.0	0	0	0	0	1
09/19/2014 11:00	0.0	0	0	0	0	1
09/19/2014 12:00	0.0	0	0	0	0	1
09/19/2014 13:00	0.0	0	0	0	0	1
09/19/2014 14:00	0.0	0	0	0	0	1
09/19/2014 15:00	0.0	0	0	0	0	1
09/19/2014 16:00	0.0	0	0	0	0	1
09/19/2014 17:00	0.0	0	0	0	0	1
09/19/2014 18:00	0.0	0	0	0	0	1
09/19/2014 19:00	0.0	0	0	0	0	1
09/19/2014 20:00	0.0	0	0	0	0	1
09/19/2014 21:00	0.0	0	0	0	0	1
09/19/2014 22:00	0.0	0	0	0	0	1
09/19/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/20/2014 00:00	0.0	0	0	0	0	1
09/20/2014 01:00	0.0	0	0	0	0	1
09/20/2014 02:00	0.0	0	0	0	0	1
09/20/2014 03:00	0.0	0	0	0	0	1
09/20/2014 04:00	0.0	0	0	0	0	1
09/20/2014 05:00	0.0	0	0	0	0	1
09/20/2014 06:00	0.0	0	0	0	0	1
09/20/2014 07:00	0.0	0	0	0	0	1
09/20/2014 08:00	0.0	0	0	0	0	1
09/20/2014 09:00	0.0	0	0	0	0	1
09/20/2014 10:00	0.0	0	0	0	0	1
09/20/2014 11:00	0.0	0	0	0	0	1
09/20/2014 12:00	0.0	0	0	0	0	1
09/20/2014 13:00	0.0	0	0	0	0	1
09/20/2014 14:00	0.0	0	0	0	0	1
09/20/2014 15:00	0.0	0	0	0	0	1
09/20/2014 16:00	0.0	0	0	0	0	1
09/20/2014 17:00	0.0	0	0	0	0	1
09/20/2014 18:00	0.0	0	0	0	0	1
09/20/2014 19:00	0.0	0	0	0	0	1
09/20/2014 20:00	0.0	0	0	0	0	1
09/20/2014 21:00	0.0	0	0	0	0	1
09/20/2014 22:00	0.0	0	0	0	0	1
09/20/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/21/2014 00:00	0.0	0	0	0	0	1
09/21/2014 01:00	0.0	0	0	0	0	1
09/21/2014 02:00	0.0	0	0	0	0	1
09/21/2014 03:00	0.0	0	0	0	0	1
09/21/2014 04:00	0.0	0	0	0	0	1
09/21/2014 05:00	0.0	0	0	0	0	1
09/21/2014 06:00	0.0	0	0	0	0	1
09/21/2014 07:00	0.0	0	0	0	0	1
09/21/2014 08:00	0.0	0	0	0	0	1
09/21/2014 09:00	0.0	0	0	0	0	1
09/21/2014 10:00	0.0	0	0	0	0	1
09/21/2014 11:00	0.0	0	0	0	0	1
09/21/2014 12:00	0.0	0	0	0	0	1
09/21/2014 13:00	0.0	0	0	0	0	1
09/21/2014 14:00	0.0	0	0	0	0	1
09/21/2014 15:00	0.0	0	0	0	0	1
09/21/2014 16:00	0.0	0	0	0	0	1
09/21/2014 17:00	0.0	0	0	0	0	1
09/21/2014 18:00	0.0	0	0	0	0	1
09/21/2014 19:00	0.0	0	0	0	0	1
09/21/2014 20:00	0.0	0	0	0	0	1
09/21/2014 21:00	0.0	0	0	0	0	1
09/21/2014 22:00	0.0	0	0	0	0	1
09/21/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/22/2014 00:00	0.0	0	0	0	0	1
09/22/2014 01:00	0.0	0	0	0	0	1
09/22/2014 02:00	0.0	0	0	0	0	1
09/22/2014 03:00	0.0	0	0	0	0	1
09/22/2014 04:00	0.0	0	0	0	0	1
09/22/2014 05:00	0.0	0	0	0	0	1
09/22/2014 06:00	0.0	0	0	0	0	1
09/22/2014 07:00	0.0	0	0	0	0	1
09/22/2014 08:00	0.0	0	0	0	0	1
09/22/2014 09:00	0.0	0	0	0	0	1
09/22/2014 10:00	0.0	0	0	0	0	1
09/22/2014 11:00	0.0	0	0	0	0	1
09/22/2014 12:00	0.0	0	0	0	0	1
09/22/2014 13:00	0.0	0	0	0	0	1
09/22/2014 14:00	0.0	0	0	0	0	1
09/22/2014 15:00	0.0	0	0	0	0	1
09/22/2014 16:00	0.0	0	0	0	0	1
09/22/2014 17:00	0.0	0	0	0	0	1
09/22/2014 18:00	0.0	0	0	0	0	1
09/22/2014 19:00	0.0	0	0	0	0	1
09/22/2014 20:00	0.0	0	0	0	0	1
09/22/2014 21:00	0.0	0	0	0	0	1
09/22/2014 22:00	0.0	0	0	0	0	1
09/22/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/23/2014 00:00	0.0	0	0	0	0	1
09/23/2014 01:00	0.0	0	0	0	0	1
09/23/2014 02:00	0.0	0	0	0	0	1
09/23/2014 03:00	0.0	0	0	0	0	1
09/23/2014 04:00	0.0	0	0	0	0	1
09/23/2014 05:00	0.0	0	0	0	0	1
09/23/2014 06:00	0.0	0	0	0	0	1
09/23/2014 07:00	0.0	0	0	0	0	1
09/23/2014 08:00	0.0	0	0	0	0	1
09/23/2014 09:00	0.0	0	0	0	0	1
09/23/2014 10:00	0.0	0	0	0	0	1
09/23/2014 11:00	0.0	0	0	0	0	1
09/23/2014 12:00	0.0	0	0	0	0	1
09/23/2014 13:00	0.0	0	0	0	0	1
09/23/2014 14:00	0.0	0	0	0	0	1
09/23/2014 15:00	0.0	0	0	0	0	1
09/23/2014 16:00	0.0	0	0	0	0	1
09/23/2014 17:00	0.0	0	0	0	0	1
09/23/2014 18:00	0.0	0	0	0	0	1
09/23/2014 19:00	0.0	0	0	0	0	1
09/23/2014 20:00	0.0	0	0	0	0	1
09/23/2014 21:00	0.0	0	0	0	0	1
09/23/2014 22:00	0.0	0	0	0	0	1
09/23/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/24/2014 00:00	0.0	0	0	0	0	1
09/24/2014 01:00	0.0	0	0	0	0	1
09/24/2014 02:00	0.0	0	0	0	0	1
09/24/2014 03:00	0.0	0	0	0	0	1
09/24/2014 04:00	0.0	0	0	0	0	1
09/24/2014 05:00	0.0	0	0	0	0	1
09/24/2014 06:00	0.0	0	0	0	0	1
09/24/2014 07:00	0.0	0	0	0	0	1
09/24/2014 08:00	0.0	0	0	0	0	1
09/24/2014 09:00	0.0	0	0	0	0	1
09/24/2014 10:00	0.0	0	0	0	0	1
09/24/2014 11:00	0.0	0	0	0	0	1
09/24/2014 12:00	0.0	0	0	0	0	1
09/24/2014 13:00	0.0	0	0	0	0	1
09/24/2014 14:00	0.0	0	0	0	0	1
09/24/2014 15:00	0.0	0	0	0	0	1
09/24/2014 16:00	0.0	0	0	0	0	1
09/24/2014 17:00	0.0	0	0	0	0	1
09/24/2014 18:00	0.0	0	0	0	0	1
09/24/2014 19:00	0.0	0	0	0	0	1
09/24/2014 20:00	0.0	0	0	0	0	1
09/24/2014 21:00	0.0	0	0	0	0	1
09/24/2014 22:00	0.0	0	0	0	0	1
09/24/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/25/2014 00:00	0.0	0	0	0	0	1
09/25/2014 01:00	0.0	0	0	0	0	1
09/25/2014 02:00	0.0	0	0	0	0	1
09/25/2014 03:00	0.0	0	0	0	0	1
09/25/2014 04:00	0.0	0	0	0	0	1
09/25/2014 05:00	0.0	0	0	0	0	1
09/25/2014 06:00	0.0	0	0	0	0	1
09/25/2014 07:00	0.0	0	0	0	0	1
09/25/2014 08:00	0.0	0	0	0	0	1
09/25/2014 09:00	0.0	0	0	0	0	1
09/25/2014 10:00	0.0	0	0	0	0	1
09/25/2014 11:00	0.0	0	0	0	0	1
09/25/2014 12:00	0.0	0	0	0	0	1
09/25/2014 13:00	0.0	0	0	0	0	1
09/25/2014 14:00	0.0	0	0	0	0	1
09/25/2014 15:00	0.0	0	0	0	0	1
09/25/2014 16:00	0.0	0	0	0	0	1
09/25/2014 17:00	0.0	0	0	0	0	1
09/25/2014 18:00	0.0	0	0	0	0	1
09/25/2014 19:00	0.0	0	0	0	0	1
09/25/2014 20:00	0.0	0	0	0	0	1
09/25/2014 21:00	0.0	0	0	0	0	1
09/25/2014 22:00	0.0	0	0	0	0	1
09/25/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/26/2014 00:00	0.0	0	0	0	0	1
09/26/2014 01:00	0.0	0	0	0	0	1
09/26/2014 02:00	0.0	0	0	0	0	1
09/26/2014 03:00	0.0	0	0	0	0	1
09/26/2014 04:00	0.0	0	0	0	0	1
09/26/2014 05:00	0.0	0	0	0	0	1
09/26/2014 06:00	0.0	0	0	0	0	1
09/26/2014 07:00	0.0	0	0	0	0	1
09/26/2014 08:00	0.0	0	0	0	0	1
09/26/2014 09:00	0.0	0	0	0	0	1
09/26/2014 10:00	0.0	0	0	0	0	1
09/26/2014 11:00	0.0	0	0	0	0	1
09/26/2014 12:00	0.0	0	0	0	0	1
09/26/2014 13:00	0.0	0	0	0	0	1
09/26/2014 14:00	0.0	0	0	0	0	1
09/26/2014 15:00	0.0	0	0	0	0	1
09/26/2014 16:00	0.0	0	0	0	0	1
09/26/2014 17:00	0.0	0	0	0	0	1
09/26/2014 18:00	0.0	0	0	0	0	1
09/26/2014 19:00	0.0	0	0	0	0	1
09/26/2014 20:00	0.0	0	0	0	0	1
09/26/2014 21:00	0.0	0	0	0	0	1
09/26/2014 22:00	0.0	0	0	0	0	1
09/26/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/27/2014 00:00	0.0	0	0	0	0	1
09/27/2014 01:00	0.0	0	0	0	0	1
09/27/2014 02:00	0.0	0	0	0	0	1
09/27/2014 03:00	0.0	0	0	0	0	1
09/27/2014 04:00	0.0	0	0	0	0	1
09/27/2014 05:00	0.0	0	0	0	0	1
09/27/2014 06:00	0.0	0	0	0	0	1
09/27/2014 07:00	0.0	0	0	0	0	1
09/27/2014 08:00	0.0	0	0	0	0	1
09/27/2014 09:00	0.0	0	0	0	0	1
09/27/2014 10:00	0.0	0	0	0	0	1
09/27/2014 11:00	0.0	0	0	0	0	1
09/27/2014 12:00	0.0	0	0	0	0	1
09/27/2014 13:00	0.0	0	0	0	0	1
09/27/2014 14:00	0.0	0	0	0	0	1
09/27/2014 15:00	0.0	0	0	0	0	1
09/27/2014 16:00	0.0	0	0	0	0	1
09/27/2014 17:00	0.0	0	0	0	0	1
09/27/2014 18:00	0.0	0	0	0	0	1
09/27/2014 19:00	0.0	0	0	0	0	1
09/27/2014 20:00	0.0	0	0	0	0	1
09/27/2014 21:00	0.0	0	0	0	0	1
09/27/2014 22:00	0.0	0	0	0	0	1
09/27/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/28/2014 00:00	0.0	0	0	0	0	1
09/28/2014 01:00	0.0	0	0	0	0	1
09/28/2014 02:00	0.0	0	0	0	0	1
09/28/2014 03:00	0.0	0	0	0	0	1
09/28/2014 04:00	0.0	0	0	0	0	1
09/28/2014 05:00	0.0	0	0	0	0	1
09/28/2014 06:00	0.0	0	0	0	0	1
09/28/2014 07:00	0.0	0	0	0	0	1
09/28/2014 08:00	0.0	0	0	0	0	1
09/28/2014 09:00	0.0	0	0	0	0	1
09/28/2014 10:00	0.0	0	0	0	0	1
09/28/2014 11:00	0.0	0	0	0	0	1
09/28/2014 12:00	0.0	0	0	0	0	1
09/28/2014 13:00	0.0	0	0	0	0	1
09/28/2014 14:00	0.0	0	0	0	0	1
09/28/2014 15:00	0.0	0	0	0	0	1
09/28/2014 16:00	0.0	0	0	0	0	1
09/28/2014 17:00	0.0	0	0	0	0	1
09/28/2014 18:00	0.0	0	0	0	0	1
09/28/2014 19:00	0.0	0	0	0	0	1
09/28/2014 20:00	0.0	0	0	0	0	1
09/28/2014 21:00	0.0	0	0	0	0	1
09/28/2014 22:00	0.0	0	0	0	0	1
09/28/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/29/2014 00:00	0.0	0	0	0	0	1
09/29/2014 01:00	0.0	0	0	0	0	1
09/29/2014 02:00	0.0	0	0	0	0	1
09/29/2014 03:00	0.0	0	0	0	0	1
09/29/2014 04:00	0.0	0	0	0	0	1
09/29/2014 05:00	0.0	0	0	0	0	1
09/29/2014 06:00	0.0	0	0	0	0	1
09/29/2014 07:00	0.0	0	0	0	0	1
09/29/2014 08:00	0.0	0	0	0	0	1
09/29/2014 09:00	0.0	0	0	0	0	1
09/29/2014 10:00	0.0	0	0	0	0	1
09/29/2014 11:00	0.0	0	0	0	0	1
09/29/2014 12:00	0.0	0	0	0	0	1
09/29/2014 13:00	0.0	0	0	0	0	1
09/29/2014 14:00	0.0	0	0	0	0	1
09/29/2014 15:00	0.0	0	0	0	0	1
09/29/2014 16:00	0.0	0	0	0	0	1
09/29/2014 17:00	0.0	0	0	0	0	1
09/29/2014 18:00	0.0	0	0	0	0	1
09/29/2014 19:00	0.0	0	0	0	0	1
09/29/2014 20:00	0.0	0	0	0	0	1
09/29/2014 21:00	0.0	0	0	0	0	1
09/29/2014 22:00	0.0	0	0	0	0	1
09/29/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 NOx_Event, Lb 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/30/2014 00:00	0.0	0	0	0	0	1
09/30/2014 01:00	0.0	0	0	0	0	1
09/30/2014 02:00	0.0	0	0	0	0	1
09/30/2014 03:00	0.0	0	0	0	0	1
09/30/2014 04:00	0.0	0	0	0	0	1
09/30/2014 05:00	0.0	0	0	0	0	1
09/30/2014 06:00	0.0	0	0	0	0	1
09/30/2014 07:00	0.0	0	0	0	0	1
09/30/2014 08:00	0.0	0	0	0	0	1
09/30/2014 09:00	0.0	0	0	0	0	1
09/30/2014 10:00	0.0	0	0	0	0	1
09/30/2014 11:00	0.0	0	0	0	0	1
09/30/2014 12:00	0.0	0	0	0	0	1
09/30/2014 13:00	0.0	0	0	0	0	1
09/30/2014 14:00	0.0	0	0	0	0	1
09/30/2014 15:00	0.0	0	0	0	0	1
09/30/2014 16:00	0.0	0	0	0	0	1
09/30/2014 17:00	0.0	0	0	0	0	1
09/30/2014 18:00	0.0	0	0	0	0	1
09/30/2014 19:00	0.0	0	0	0	0	1
09/30/2014 20:00	0.0	0	0	0	0	1
09/30/2014 21:00	0.0	0	0	0	0	1
09/30/2014 22:00	0.0	0	0	0	0	1
09/30/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/01/2014 00:00	0.0	0	0	0	0	1
07/01/2014 01:00	0.0	0	0	0	0	1
07/01/2014 02:00	0.0	0	0	0	0	1
07/01/2014 03:00	0.0	0	0	0	0	1
07/01/2014 04:00	0.0	0	0	0	0	1
07/01/2014 05:00	0.0	0	0	0	0	1
07/01/2014 06:00	0.0	0	0	0	0	1
07/01/2014 07:00	0.0	0	0	0	0	1
07/01/2014 08:00	0.0	0	0	0	0	1
07/01/2014 09:00	0.0	0	0	0	0	1
07/01/2014 10:00	0.0	0	0	0	0	1
07/01/2014 11:00	0.0	0	0	0	0	1
07/01/2014 12:00	0.0	0	0	0	0	1
07/01/2014 13:00	0.0	0	0	0	0	1
07/01/2014 14:00	0.0	0	0	0	0	1
07/01/2014 15:00	0.0	0	0	0	0	1
07/01/2014 16:00	0.0	0	0	0	0	1
07/01/2014 17:00	0.0	0	0	0	0	1
07/01/2014 18:00	0.0	0	0	0	0	1
07/01/2014 19:00	0.0	0	0	0	0	1
07/01/2014 20:00	0.0	0	0	0	0	1
07/01/2014 21:00	0.0	0	0	0	0	1
07/01/2014 22:00	0.0	0	0	0	0	1
07/01/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/02/2014 00:00	0.0	0	0	0	0	1
07/02/2014 01:00	0.0	0	0	0	0	1
07/02/2014 02:00	0.0	0	0	0	0	1
07/02/2014 03:00	0.0	0	0	0	0	1
07/02/2014 04:00	0.0	0	0	0	0	1
07/02/2014 05:00	0.0	0	0	0	0	1
07/02/2014 06:00	0.0	0	0	0	0	1
07/02/2014 07:00	0.0	0	0	0	0	1
07/02/2014 08:00	0.0	0	0	0	0	1
07/02/2014 09:00	0.0	0	0	0	0	1
07/02/2014 10:00	0.0	0	0	0	0	1
07/02/2014 11:00	0.0	0	0	0	0	1
07/02/2014 12:00	0.0	0	0	0	0	1
07/02/2014 13:00	0.0	0	0	0	0	1
07/02/2014 14:00	0.0	0	0	0	0	1
07/02/2014 15:00	0.0	0	0	0	0	1
07/02/2014 16:00	0.0	0	0	0	0	1
07/02/2014 17:00	0.0	0	0	0	0	1
07/02/2014 18:00	0.0	0	0	0	0	1
07/02/2014 19:00	0.0	0	0	0	0	1
07/02/2014 20:00	0.0	0	0	0	0	1
07/02/2014 21:00	0.0	0	0	0	0	1
07/02/2014 22:00	439.4	0	0	0	1	0
07/02/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	439.4 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	439.4	0	0	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/03/2014 00:00	0.0	0	0	0	0	0
07/03/2014 01:00	0.0	0	0	0	0	0
07/03/2014 02:00	0.0	0	0	0	0	0
07/03/2014 03:00	3,730.6	0	0	1	0	0
07/03/2014 04:00	2,041.8	0	0	1	0	0
07/03/2014 05:00	0.0	0	0	0	0	1
07/03/2014 06:00	0.0	0	0	0	0	1
07/03/2014 07:00	0.0	0	0	0	0	1
07/03/2014 08:00	0.0	0	0	0	0	1
07/03/2014 09:00	0.0	0	0	0	0	1
07/03/2014 10:00	0.0	0	0	0	0	1
07/03/2014 11:00	0.0	0	0	0	0	1
07/03/2014 12:00	0.0	0	0	0	0	1
07/03/2014 13:00	0.0	0	0	0	0	1
07/03/2014 14:00	0.0	0	0	0	0	1
07/03/2014 15:00	0.0	0	0	0	0	1
07/03/2014 16:00	0.0	0	0	0	0	1
07/03/2014 17:00	0.0	0	0	0	0	1
07/03/2014 18:00	0.0	0	0	0	0	1
07/03/2014 19:00	0.0	0	0	0	0	1
07/03/2014 20:00	0.0	0	0	0	0	1
07/03/2014 21:00	0.0	0	0	0	0	1
07/03/2014 22:00	0.0	0	0	0	0	1
07/03/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	5,772.4 #	0 #	0 #	2 #	0 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3,730.6	0	0	1	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/04/2014 00:00	0.0	0	0	0	0	1
07/04/2014 01:00	0.0	0	0	0	0	1
07/04/2014 02:00	0.0	0	0	0	0	1
07/04/2014 03:00	0.0	0	0	0	0	1
07/04/2014 04:00	0.0	0	0	0	0	1
07/04/2014 05:00	0.0	0	0	0	0	1
07/04/2014 06:00	0.0	0	0	0	0	1
07/04/2014 07:00	0.0	0	0	0	0	1
07/04/2014 08:00	0.0	0	0	0	0	1
07/04/2014 09:00	0.0	0	0	0	0	1
07/04/2014 10:00	0.0	0	0	0	0	1
07/04/2014 11:00	0.0	0	0	0	0	1
07/04/2014 12:00	0.0	0	0	0	0	1
07/04/2014 13:00	0.0	0	0	0	0	1
07/04/2014 14:00	0.0	0	0	0	0	1
07/04/2014 15:00	0.0	0	0	0	0	1
07/04/2014 16:00	0.0	0	0	0	0	1
07/04/2014 17:00	0.0	0	0	0	0	1
07/04/2014 18:00	0.0	0	0	0	0	1
07/04/2014 19:00	0.0	0	0	0	0	1
07/04/2014 20:00	409.8	0	0	0	1	0
07/04/2014 21:00	0.0	0	0	0	0	0
07/04/2014 22:00	0.0	0	0	0	0	0
07/04/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	409.8 #	0 #	0 #	0 #	1 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	409.8	0	0	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/05/2014 00:00	0.0	0	0	0	0	0
07/05/2014 01:00	0.0	0	0	0	0	0
07/05/2014 02:00	0.0	0	0	0	0	0
07/05/2014 03:00	0.0	0	0	0	0	0
07/05/2014 04:00	0.0	0	0	0	0	0
07/05/2014 05:00	0.0	0	0	0	0	0
07/05/2014 06:00	4,182.0	0	1	0	0	0
07/05/2014 07:00	7,662.6	0	1	0	0	0
07/05/2014 08:00	0.0	0	0	0	0	1
07/05/2014 09:00	0.0	0	0	0	0	1
07/05/2014 10:00	0.0	0	0	0	0	1
07/05/2014 11:00	0.0	0	0	0	0	1
07/05/2014 12:00	0.0	0	0	0	0	1
07/05/2014 13:00	0.0	0	0	0	0	1
07/05/2014 14:00	0.0	0	0	0	0	1
07/05/2014 15:00	0.0	0	0	0	0	1
07/05/2014 16:00	0.0	0	0	0	0	1
07/05/2014 17:00	0.0	0	0	0	0	1
07/05/2014 18:00	0.0	0	0	0	0	1
07/05/2014 19:00	0.0	0	0	0	0	1
07/05/2014 20:00	0.0	0	0	0	0	1
07/05/2014 21:00	0.0	0	0	0	0	1
07/05/2014 22:00	0.0	0	0	0	0	1
07/05/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	11,844.6 #	0 #	2 #	0 #	0 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	7,662.6	0	1	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/06/2014 00:00	0.0	0	0	0	0	1
07/06/2014 01:00	0.0	0	0	0	0	1
07/06/2014 02:00	358.8	0	0	0	1	0
07/06/2014 03:00	0.0	0	0	0	0	0
07/06/2014 04:00	0.0	0	0	0	0	0
07/06/2014 05:00	2,367.2	0	0	1	0	0
07/06/2014 06:00	5,075.5	0	0	1	0	0
07/06/2014 07:00	0.0	0	0	0	0	1
07/06/2014 08:00	0.0	0	0	0	0	1
07/06/2014 09:00	0.0	0	0	0	0	1
07/06/2014 10:00	0.0	0	0	0	0	1
07/06/2014 11:00	0.0	0	0	0	0	1
07/06/2014 12:00	0.0	0	0	0	0	1
07/06/2014 13:00	0.0	0	0	0	0	1
07/06/2014 14:00	0.0	0	0	0	0	1
07/06/2014 15:00	0.0	0	0	0	0	1
07/06/2014 16:00	0.0	0	0	0	0	1
07/06/2014 17:00	0.0	0	0	0	0	1
07/06/2014 18:00	0.0	0	0	0	0	1
07/06/2014 19:00	0.0	0	0	0	0	1
07/06/2014 20:00	0.0	0	0	0	0	1
07/06/2014 21:00	0.0	0	0	0	0	1
07/06/2014 22:00	0.0	0	0	0	0	1
07/06/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,801.5 #	0 #	0 #	2 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,075.5	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/07/2014 00:00	0.0	0	0	0	0	1
07/07/2014 01:00	0.0	0	0	0	0	1
07/07/2014 02:00	0.0	0	0	0	0	1
07/07/2014 03:00	0.0	0	0	0	0	1
07/07/2014 04:00	0.0	0	0	0	0	1
07/07/2014 05:00	0.0	0	0	0	0	1
07/07/2014 06:00	0.0	0	0	0	0	1
07/07/2014 07:00	0.0	0	0	0	0	1
07/07/2014 08:00	0.0	0	0	0	0	1
07/07/2014 09:00	0.0	0	0	0	0	1
07/07/2014 10:00	0.0	0	0	0	0	1
07/07/2014 11:00	0.0	0	0	0	0	1
07/07/2014 12:00	0.0	0	0	0	0	1
07/07/2014 13:00	0.0	0	0	0	0	1
07/07/2014 14:00	0.0	0	0	0	0	1
07/07/2014 15:00	0.0	0	0	0	0	1
07/07/2014 16:00	0.0	0	0	0	0	1
07/07/2014 17:00	0.0	0	0	0	0	1
07/07/2014 18:00	0.0	0	0	0	0	1
07/07/2014 19:00	0.0	0	0	0	0	1
07/07/2014 20:00	0.0	0	0	0	0	1
07/07/2014 21:00	0.0	0	0	0	0	1
07/07/2014 22:00	0.0	0	0	0	0	1
07/07/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/08/2014 00:00	0.0	0	0	0	0	1
07/08/2014 01:00	0.0	0	0	0	0	1
07/08/2014 02:00	0.0	0	0	0	0	1
07/08/2014 03:00	0.0	0	0	0	0	1
07/08/2014 04:00	0.0	0	0	0	0	1
07/08/2014 05:00	0.0	0	0	0	0	1
07/08/2014 06:00	0.0	0	0	0	0	1
07/08/2014 07:00	0.0	0	0	0	0	1
07/08/2014 08:00	0.0	0	0	0	0	1
07/08/2014 09:00	0.0	0	0	0	0	1
07/08/2014 10:00	0.0	0	0	0	0	1
07/08/2014 11:00	0.0	0	0	0	0	1
07/08/2014 12:00	0.0	0	0	0	0	1
07/08/2014 13:00	0.0	0	0	0	0	1
07/08/2014 14:00	0.0	0	0	0	0	1
07/08/2014 15:00	0.0	0	0	0	0	1
07/08/2014 16:00	0.0	0	0	0	0	1
07/08/2014 17:00	0.0	0	0	0	0	1
07/08/2014 18:00	0.0	0	0	0	0	1
07/08/2014 19:00	0.0	0	0	0	0	1
07/08/2014 20:00	0.0	0	0	0	0	1
07/08/2014 21:00	0.0	0	0	0	0	1
07/08/2014 22:00	0.0	0	0	0	0	1
07/08/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/09/2014 00:00	0.0	0	0	0	0	1
07/09/2014 01:00	0.0	0	0	0	0	1
07/09/2014 02:00	0.0	0	0	0	0	1
07/09/2014 03:00	0.0	0	0	0	0	1
07/09/2014 04:00	0.0	0	0	0	0	1
07/09/2014 05:00	0.0	0	0	0	0	1
07/09/2014 06:00	0.0	0	0	0	0	1
07/09/2014 07:00	0.0	0	0	0	0	1
07/09/2014 08:00	0.0	0	0	0	0	1
07/09/2014 09:00	0.0	0	0	0	0	1
07/09/2014 10:00	0.0	0	0	0	0	1
07/09/2014 11:00	0.0	0	0	0	0	1
07/09/2014 12:00	0.0	0	0	0	0	1
07/09/2014 13:00	0.0	0	0	0	0	1
07/09/2014 14:00	0.0	0	0	0	0	1
07/09/2014 15:00	0.0	0	0	0	0	1
07/09/2014 16:00	0.0	0	0	0	0	1
07/09/2014 17:00	0.0	0	0	0	0	1
07/09/2014 18:00	0.0	0	0	0	0	1
07/09/2014 19:00	0.0	0	0	0	0	1
07/09/2014 20:00	0.0	0	0	0	0	1
07/09/2014 21:00	0.0	0	0	0	0	1
07/09/2014 22:00	0.0	0	0	0	0	1
07/09/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/10/2014 00:00	0.0	0	0	0	0	1
07/10/2014 01:00	0.0	0	0	0	0	1
07/10/2014 02:00	0.0	0	0	0	0	1
07/10/2014 03:00	0.0	0	0	0	0	1
07/10/2014 04:00	0.0	0	0	0	0	1
07/10/2014 05:00	0.0	0	0	0	0	1
07/10/2014 06:00	0.0	0	0	0	0	1
07/10/2014 07:00	0.0	0	0	0	0	1
07/10/2014 08:00	0.0	0	0	0	0	1
07/10/2014 09:00	0.0	0	0	0	0	1
07/10/2014 10:00	0.0	0	0	0	0	1
07/10/2014 11:00	0.0	0	0	0	0	1
07/10/2014 12:00	0.0	0	0	0	0	1
07/10/2014 13:00	0.0	0	0	0	0	1
07/10/2014 14:00	0.0	0	0	0	0	1
07/10/2014 15:00	0.0	0	0	0	0	1
07/10/2014 16:00	0.0	0	0	0	0	1
07/10/2014 17:00	0.0	0	0	0	0	1
07/10/2014 18:00	0.0	0	0	0	0	1
07/10/2014 19:00	0.0	0	0	0	0	1
07/10/2014 20:00	0.0	0	0	0	0	1
07/10/2014 21:00	0.0	0	0	0	0	1
07/10/2014 22:00	0.0	0	0	0	0	1
07/10/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/11/2014 00:00	0.0	0	0	0	0	1
07/11/2014 01:00	243.0	0	0	0	1	0
07/11/2014 02:00	0.0	0	0	0	0	0
07/11/2014 03:00	0.0	0	0	0	0	0
07/11/2014 04:00	0.0	0	0	0	0	0
07/11/2014 05:00	2,841.1	0	0	1	0	0
07/11/2014 06:00	5,237.3	0	0	1	0	0
07/11/2014 07:00	0.0	0	0	0	0	1
07/11/2014 08:00	0.0	0	0	0	0	1
07/11/2014 09:00	0.0	0	0	0	0	1
07/11/2014 10:00	0.0	0	0	0	0	1
07/11/2014 11:00	0.0	0	0	0	0	1
07/11/2014 12:00	0.0	0	0	0	0	1
07/11/2014 13:00	0.0	0	0	0	0	1
07/11/2014 14:00	0.0	0	0	0	0	1
07/11/2014 15:00	0.0	0	0	0	0	1
07/11/2014 16:00	0.0	0	0	0	0	1
07/11/2014 17:00	0.0	0	0	0	0	1
07/11/2014 18:00	0.0	0	0	0	0	1
07/11/2014 19:00	0.0	0	0	0	0	1
07/11/2014 20:00	0.0	0	0	0	0	1
07/11/2014 21:00	0.0	0	0	0	0	1
07/11/2014 22:00	0.0	0	0	0	0	1
07/11/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,321.4 #	0 #	0 #	2 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,237.3	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/12/2014 00:00	291.0	0	0	0	1	0
07/12/2014 01:00	0.0	0	0	0	0	0
07/12/2014 02:00	0.0	0	0	0	0	0
07/12/2014 03:00	0.0	0	0	0	0	0
07/12/2014 04:00	0.0	0	0	0	0	0
07/12/2014 05:00	0.0	0	0	0	0	0
07/12/2014 06:00	0.0	0	0	0	0	0
07/12/2014 07:00	0.0	0	0	0	0	0
07/12/2014 08:00	0.0	0	0	0	0	0
07/12/2014 09:00	0.0	0	0	0	0	0
07/12/2014 10:00	0.0	0	0	0	0	0
07/12/2014 11:00	5,193.0	0	1	0	0	0
07/12/2014 12:00	1,316.3	0	1	0	0	0
07/12/2014 13:00	0.0	0	0	0	0	1
07/12/2014 14:00	0.0	0	0	0	0	1
07/12/2014 15:00	0.0	0	0	0	0	1
07/12/2014 16:00	0.0	0	0	0	0	1
07/12/2014 17:00	0.0	0	0	0	0	1
07/12/2014 18:00	0.0	0	0	0	0	1
07/12/2014 19:00	0.0	0	0	0	0	1
07/12/2014 20:00	0.0	0	0	0	0	1
07/12/2014 21:00	0.0	0	0	0	0	1
07/12/2014 22:00	0.0	0	0	0	0	1
07/12/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,800.3 #	0 #	2 #	0 #	1 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,193.0	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/13/2014 00:00	0.0	0	0	0	0	1
07/13/2014 01:00	297.5	0	0	0	1	0
07/13/2014 02:00	0.0	0	0	0	0	0
07/13/2014 03:00	0.0	0	0	0	0	0
07/13/2014 04:00	0.0	0	0	0	0	0
07/13/2014 05:00	0.0	0	0	0	0	0
07/13/2014 06:00	2,179.7	0	0	1	0	0
07/13/2014 07:00	6,385.0	0	0	1	0	0
07/13/2014 08:00	0.0	0	0	0	0	1
07/13/2014 09:00	0.0	0	0	0	0	1
07/13/2014 10:00	0.0	0	0	0	0	1
07/13/2014 11:00	0.0	0	0	0	0	1
07/13/2014 12:00	0.0	0	0	0	0	1
07/13/2014 13:00	0.0	0	0	0	0	1
07/13/2014 14:00	0.0	0	0	0	0	1
07/13/2014 15:00	0.0	0	0	0	0	1
07/13/2014 16:00	0.0	0	0	0	0	1
07/13/2014 17:00	0.0	0	0	0	0	1
07/13/2014 18:00	0.0	0	0	0	0	1
07/13/2014 19:00	0.0	0	0	0	0	1
07/13/2014 20:00	0.0	0	0	0	0	1
07/13/2014 21:00	0.0	0	0	0	0	1
07/13/2014 22:00	0.0	0	0	0	0	1
07/13/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,862.2 #	0 #	0 #	2 #	1 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,385.0	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/14/2014 00:00	0.0	0	0	0	0	1
07/14/2014 01:00	0.0	0	0	0	0	1
07/14/2014 02:00	0.0	0	0	0	0	1
07/14/2014 03:00	0.0	0	0	0	0	1
07/14/2014 04:00	0.0	0	0	0	0	1
07/14/2014 05:00	0.0	0	0	0	0	1
07/14/2014 06:00	0.0	0	0	0	0	1
07/14/2014 07:00	0.0	0	0	0	0	1
07/14/2014 08:00	0.0	0	0	0	0	1
07/14/2014 09:00	0.0	0	0	0	0	1
07/14/2014 10:00	0.0	0	0	0	0	1
07/14/2014 11:00	0.0	0	0	0	0	1
07/14/2014 12:00	0.0	0	0	0	0	1
07/14/2014 13:00	0.0	0	0	0	0	1
07/14/2014 14:00	0.0	0	0	0	0	1
07/14/2014 15:00	0.0	0	0	0	0	1
07/14/2014 16:00	0.0	0	0	0	0	1
07/14/2014 17:00	0.0	0	0	0	0	1
07/14/2014 18:00	0.0	0	0	0	0	1
07/14/2014 19:00	0.0	0	0	0	0	1
07/14/2014 20:00	0.0	0	0	0	0	1
07/14/2014 21:00	0.0	0	0	0	0	1
07/14/2014 22:00	0.0	0	0	0	0	1
07/14/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/15/2014 00:00	0.0	0	0	0	0	1
07/15/2014 01:00	0.0	0	0	0	0	1
07/15/2014 02:00	0.0	0	0	0	0	1
07/15/2014 03:00	0.0	0	0	0	0	1
07/15/2014 04:00	0.0	0	0	0	0	1
07/15/2014 05:00	0.0	0	0	0	0	1
07/15/2014 06:00	0.0	0	0	0	0	1
07/15/2014 07:00	0.0	0	0	0	0	1
07/15/2014 08:00	0.0	0	0	0	0	1
07/15/2014 09:00	0.0	0	0	0	0	1
07/15/2014 10:00	0.0	0	0	0	0	1
07/15/2014 11:00	0.0	0	0	0	0	1
07/15/2014 12:00	0.0	0	0	0	0	1
07/15/2014 13:00	0.0	0	0	0	0	1
07/15/2014 14:00	0.0	0	0	0	0	1
07/15/2014 15:00	0.0	0	0	0	0	1
07/15/2014 16:00	0.0	0	0	0	0	1
07/15/2014 17:00	0.0	0	0	0	0	1
07/15/2014 18:00	0.0	0	0	0	0	1
07/15/2014 19:00	0.0	0	0	0	0	1
07/15/2014 20:00	0.0	0	0	0	0	1
07/15/2014 21:00	0.0	0	0	0	0	1
07/15/2014 22:00	0.0	0	0	0	0	1
07/15/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/16/2014 00:00	0.0	0	0	0	0	1
07/16/2014 01:00	0.0	0	0	0	0	1
07/16/2014 02:00	0.0	0	0	0	0	1
07/16/2014 03:00	0.0	0	0	0	0	1
07/16/2014 04:00	0.0	0	0	0	0	1
07/16/2014 05:00	0.0	0	0	0	0	1
07/16/2014 06:00	0.0	0	0	0	0	1
07/16/2014 07:00	0.0	0	0	0	0	1
07/16/2014 08:00	0.0	0	0	0	0	1
07/16/2014 09:00	0.0	0	0	0	0	1
07/16/2014 10:00	0.0	0	0	0	0	1
07/16/2014 11:00	0.0	0	0	0	0	1
07/16/2014 12:00	0.0	0	0	0	0	1
07/16/2014 13:00	0.0	0	0	0	0	1
07/16/2014 14:00	0.0	0	0	0	0	1
07/16/2014 15:00	0.0	0	0	0	0	1
07/16/2014 16:00	0.0	0	0	0	0	1
07/16/2014 17:00	0.0	0	0	0	0	1
07/16/2014 18:00	0.0	0	0	0	0	1
07/16/2014 19:00	0.0	0	0	0	0	1
07/16/2014 20:00	0.0	0	0	0	0	1
07/16/2014 21:00	0.0	0	0	0	0	1
07/16/2014 22:00	0.0	0	0	0	0	1
07/16/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/17/2014 00:00	338.7	0	0	0	1	0
07/17/2014 01:00	0.0	0	0	0	0	0
07/17/2014 02:00	0.0	0	0	0	0	0
07/17/2014 03:00	0.0	0	0	0	0	0
07/17/2014 04:00	0.0	0	0	0	0	0
07/17/2014 05:00	0.0	0	0	0	0	0
07/17/2014 06:00	0.0	0	0	0	0	0
07/17/2014 07:00	0.0	0	0	0	0	0
07/17/2014 08:00	1,500.6	0	1	0	0	0
07/17/2014 09:00	5,019.3	0	1	0	0	0
07/17/2014 10:00	0.0	0	0	0	0	1
07/17/2014 11:00	0.0	0	0	0	0	1
07/17/2014 12:00	0.0	0	0	0	0	1
07/17/2014 13:00	0.0	0	0	0	0	1
07/17/2014 14:00	0.0	0	0	0	0	1
07/17/2014 15:00	0.0	0	0	0	0	1
07/17/2014 16:00	0.0	0	0	0	0	1
07/17/2014 17:00	0.0	0	0	0	0	1
07/17/2014 18:00	0.0	0	0	0	0	1
07/17/2014 19:00	0.0	0	0	0	0	1
07/17/2014 20:00	0.0	0	0	0	0	1
07/17/2014 21:00	0.0	0	0	0	0	1
07/17/2014 22:00	0.0	0	0	0	0	1
07/17/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,858.6 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,019.3	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/18/2014 00:00	328.8	0	0	0	1	0
07/18/2014 01:00	0.0	0	0	0	0	0
07/18/2014 02:00	0.0	0	0	0	0	0
07/18/2014 03:00	0.0	0	0	0	0	0
07/18/2014 04:00	0.0	0	0	0	0	0
07/18/2014 05:00	0.0	0	0	0	0	0
07/18/2014 06:00	0.0	0	0	0	0	0
07/18/2014 07:00	0.0	0	0	0	0	0
07/18/2014 08:00	5,467.0	0	0	1	0	0
07/18/2014 09:00	1,108.4	0	0	1	0	0
07/18/2014 10:00	0.0	0	0	0	0	1
07/18/2014 11:00	0.0	0	0	0	0	1
07/18/2014 12:00	0.0	0	0	0	0	1
07/18/2014 13:00	0.0	0	0	0	0	1
07/18/2014 14:00	0.0	0	0	0	0	1
07/18/2014 15:00	0.0	0	0	0	0	1
07/18/2014 16:00	0.0	0	0	0	0	1
07/18/2014 17:00	0.0	0	0	0	0	1
07/18/2014 18:00	0.0	0	0	0	0	1
07/18/2014 19:00	0.0	0	0	0	0	1
07/18/2014 20:00	0.0	0	0	0	0	1
07/18/2014 21:00	0.0	0	0	0	0	1
07/18/2014 22:00	0.0	0	0	0	0	1
07/18/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,904.2 #	0 #	0 #	2 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,467.0	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/19/2014 00:00	316.1	0	0	0	1	0
07/19/2014 01:00	0.0	0	0	0	0	0
07/19/2014 02:00	0.0	0	0	0	0	0
07/19/2014 03:00	0.0	0	0	0	0	0
07/19/2014 04:00	0.0	0	0	0	0	0
07/19/2014 05:00	1,837.9	0	0	1	0	0
07/19/2014 06:00	5,266.6	0	0	1	0	0
07/19/2014 07:00	0.0	0	0	0	0	1
07/19/2014 08:00	0.0	0	0	0	0	1
07/19/2014 09:00	0.0	0	0	0	0	1
07/19/2014 10:00	0.0	0	0	0	0	1
07/19/2014 11:00	0.0	0	0	0	0	1
07/19/2014 12:00	0.0	0	0	0	0	1
07/19/2014 13:00	0.0	0	0	0	0	1
07/19/2014 14:00	0.0	0	0	0	0	1
07/19/2014 15:00	0.0	0	0	0	0	1
07/19/2014 16:00	0.0	0	0	0	0	1
07/19/2014 17:00	0.0	0	0	0	0	1
07/19/2014 18:00	0.0	0	0	0	0	1
07/19/2014 19:00	0.0	0	0	0	0	1
07/19/2014 20:00	0.0	0	0	0	0	1
07/19/2014 21:00	0.0	0	0	0	0	1
07/19/2014 22:00	0.0	0	0	0	0	1
07/19/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,420.6 #	0 #	0 #	2 #	1 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,266.6	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/20/2014 00:00	321.0	0	0	0	1	0
07/20/2014 01:00	0.0	0	0	0	0	0
07/20/2014 02:00	0.0	0	0	0	0	0
07/20/2014 03:00	0.0	0	0	0	0	0
07/20/2014 04:00	0.0	0	0	0	0	0
07/20/2014 05:00	0.0	0	0	0	0	0
07/20/2014 06:00	0.0	0	0	0	0	0
07/20/2014 07:00	0.0	0	0	0	0	0
07/20/2014 08:00	0.0	0	0	0	0	0
07/20/2014 09:00	0.0	0	0	0	0	0
07/20/2014 10:00	0.0	0	0	0	0	0
07/20/2014 11:00	0.0	0	0	0	0	0
07/20/2014 12:00	0.0	0	0	0	0	0
07/20/2014 13:00	0.0	0	0	0	0	0
07/20/2014 14:00	0.0	0	0	0	0	0
07/20/2014 15:00	0.0	0	0	0	0	0
07/20/2014 16:00	0.0	0	0	0	0	0
07/20/2014 17:00	0.0	0	0	0	0	0
07/20/2014 18:00	0.0	0	0	0	0	0
07/20/2014 19:00	0.0	0	0	0	0	0
07/20/2014 20:00	0.0	0	0	0	0	0
07/20/2014 21:00	0.0	0	0	0	0	0
07/20/2014 22:00	0.0	0	0	0	0	0
07/20/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	321.0 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	321.0	0	0	0	1	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/21/2014 00:00	0.0	0	0	0	0	0
07/21/2014 01:00	0.0	0	0	0	0	0
07/21/2014 02:00	0.0	0	0	0	0	0
07/21/2014 03:00	0.0	0	0	0	0	0
07/21/2014 04:00	0.0	0	0	0	0	0
07/21/2014 05:00	0.0	0	0	0	0	0
07/21/2014 06:00	3,349.6	0	1	0	0	0
07/21/2014 07:00	5,188.5	0	1	0	0	0
07/21/2014 08:00	0.0	0	0	0	0	1
07/21/2014 09:00	0.0	0	0	0	0	1
07/21/2014 10:00	0.0	0	0	0	0	1
07/21/2014 11:00	0.0	0	0	0	0	1
07/21/2014 12:00	0.0	0	0	0	0	1
07/21/2014 13:00	0.0	0	0	0	0	1
07/21/2014 14:00	0.0	0	0	0	0	1
07/21/2014 15:00	0.0	0	0	0	0	1
07/21/2014 16:00	0.0	0	0	0	0	1
07/21/2014 17:00	0.0	0	0	0	0	1
07/21/2014 18:00	0.0	0	0	0	0	1
07/21/2014 19:00	0.0	0	0	0	0	1
07/21/2014 20:00	0.0	0	0	0	0	1
07/21/2014 21:00	0.0	0	0	0	0	1
07/21/2014 22:00	0.0	0	0	0	0	1
07/21/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,538.1 #	0 #	2 #	0 #	0 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,188.5	0	1	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/22/2014 00:00	0.0	0	0	0	0	1
07/22/2014 01:00	0.0	0	0	0	0	1
07/22/2014 02:00	0.0	0	0	0	0	1
07/22/2014 03:00	0.0	0	0	0	0	1
07/22/2014 04:00	0.0	0	0	0	0	1
07/22/2014 05:00	0.0	0	0	0	0	1
07/22/2014 06:00	0.0	0	0	0	0	1
07/22/2014 07:00	0.0	0	0	0	0	1
07/22/2014 08:00	0.0	0	0	0	0	1
07/22/2014 09:00	0.0	0	0	0	0	1
07/22/2014 10:00	0.0	0	0	0	0	1
07/22/2014 11:00	0.0	0	0	0	0	1
07/22/2014 12:00	0.0	0	0	0	0	1
07/22/2014 13:00	0.0	0	0	0	0	1
07/22/2014 14:00	0.0	0	0	0	0	1
07/22/2014 15:00	0.0	0	0	0	0	1
07/22/2014 16:00	0.0	0	0	0	0	1
07/22/2014 17:00	0.0	0	0	0	0	1
07/22/2014 18:00	0.0	0	0	0	0	1
07/22/2014 19:00	0.0	0	0	0	0	1
07/22/2014 20:00	0.0	0	0	0	0	1
07/22/2014 21:00	0.0	0	0	0	0	1
07/22/2014 22:00	0.0	0	0	0	0	1
07/22/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/23/2014 00:00	0.0	0	0	0	0	1
07/23/2014 01:00	0.0	0	0	0	0	1
07/23/2014 02:00	0.0	0	0	0	0	1
07/23/2014 03:00	0.0	0	0	0	0	1
07/23/2014 04:00	0.0	0	0	0	0	1
07/23/2014 05:00	0.0	0	0	0	0	1
07/23/2014 06:00	0.0	0	0	0	0	1
07/23/2014 07:00	0.0	0	0	0	0	1
07/23/2014 08:00	0.0	0	0	0	0	1
07/23/2014 09:00	0.0	0	0	0	0	1
07/23/2014 10:00	0.0	0	0	0	0	1
07/23/2014 11:00	0.0	0	0	0	0	1
07/23/2014 12:00	0.0	0	0	0	0	1
07/23/2014 13:00	0.0	0	0	0	0	1
07/23/2014 14:00	0.0	0	0	0	0	1
07/23/2014 15:00	0.0	0	0	0	0	1
07/23/2014 16:00	0.0	0	0	0	0	1
07/23/2014 17:00	0.0	0	0	0	0	1
07/23/2014 18:00	0.0	0	0	0	0	1
07/23/2014 19:00	0.0	0	0	0	0	1
07/23/2014 20:00	0.0	0	0	0	0	1
07/23/2014 21:00	0.0	0	0	0	0	1
07/23/2014 22:00	0.0	0	0	0	0	1
07/23/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/24/2014 00:00	0.0	0	0	0	0	1
07/24/2014 01:00	0.0	0	0	0	0	1
07/24/2014 02:00	0.0	0	0	0	0	1
07/24/2014 03:00	0.0	0	0	0	0	1
07/24/2014 04:00	0.0	0	0	0	0	1
07/24/2014 05:00	0.0	0	0	0	0	1
07/24/2014 06:00	0.0	0	0	0	0	1
07/24/2014 07:00	0.0	0	0	0	0	1
07/24/2014 08:00	0.0	0	0	0	0	1
07/24/2014 09:00	0.0	0	0	0	0	1
07/24/2014 10:00	0.0	0	0	0	0	1
07/24/2014 11:00	0.0	0	0	0	0	1
07/24/2014 12:00	0.0	0	0	0	0	1
07/24/2014 13:00	0.0	0	0	0	0	1
07/24/2014 14:00	0.0	0	0	0	0	1
07/24/2014 15:00	0.0	0	0	0	0	1
07/24/2014 16:00	0.0	0	0	0	0	1
07/24/2014 17:00	0.0	0	0	0	0	1
07/24/2014 18:00	0.0	0	0	0	0	1
07/24/2014 19:00	0.0	0	0	0	0	1
07/24/2014 20:00	0.0	0	0	0	0	1
07/24/2014 21:00	0.0	0	0	0	0	1
07/24/2014 22:00	0.0	0	0	0	0	1
07/24/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/25/2014 00:00	0.0	0	0	0	0	1
07/25/2014 01:00	0.0	0	0	0	0	1
07/25/2014 02:00	0.0	0	0	0	0	1
07/25/2014 03:00	0.0	0	0	0	0	1
07/25/2014 04:00	0.0	0	0	0	0	1
07/25/2014 05:00	0.0	0	0	0	0	1
07/25/2014 06:00	0.0	0	0	0	0	1
07/25/2014 07:00	0.0	0	0	0	0	1
07/25/2014 08:00	0.0	0	0	0	0	1
07/25/2014 09:00	0.0	0	0	0	0	1
07/25/2014 10:00	0.0	0	0	0	0	1
07/25/2014 11:00	0.0	0	0	0	0	1
07/25/2014 12:00	0.0	0	0	0	0	1
07/25/2014 13:00	0.0	0	0	0	0	1
07/25/2014 14:00	0.0	0	0	0	0	1
07/25/2014 15:00	0.0	0	0	0	0	1
07/25/2014 16:00	0.0	0	0	0	0	1
07/25/2014 17:00	0.0	0	0	0	0	1
07/25/2014 18:00	0.0	0	0	0	0	1
07/25/2014 19:00	0.0	0	0	0	0	1
07/25/2014 20:00	0.0	0	0	0	0	1
07/25/2014 21:00	0.0	0	0	0	0	1
07/25/2014 22:00	0.0	0	0	0	0	1
07/25/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/26/2014 00:00	0.0	0	0	0	0	1
07/26/2014 01:00	0.0	0	0	0	0	1
07/26/2014 02:00	0.0	0	0	0	0	1
07/26/2014 03:00	0.0	0	0	0	0	1
07/26/2014 04:00	0.0	0	0	0	0	1
07/26/2014 05:00	0.0	0	0	0	0	1
07/26/2014 06:00	0.0	0	0	0	0	1
07/26/2014 07:00	0.0	0	0	0	0	1
07/26/2014 08:00	0.0	0	0	0	0	1
07/26/2014 09:00	0.0	0	0	0	0	1
07/26/2014 10:00	0.0	0	0	0	0	1
07/26/2014 11:00	0.0	0	0	0	0	1
07/26/2014 12:00	0.0	0	0	0	0	1
07/26/2014 13:00	0.0	0	0	0	0	1
07/26/2014 14:00	0.0	0	0	0	0	1
07/26/2014 15:00	0.0	0	0	0	0	1
07/26/2014 16:00	0.0	0	0	0	0	1
07/26/2014 17:00	0.0	0	0	0	0	1
07/26/2014 18:00	0.0	0	0	0	0	1
07/26/2014 19:00	0.0	0	0	0	0	1
07/26/2014 20:00	0.0	0	0	0	0	1
07/26/2014 21:00	0.0	0	0	0	0	1
07/26/2014 22:00	0.0	0	0	0	0	1
07/26/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/27/2014 00:00	0.0	0	0	0	0	1
07/27/2014 01:00	0.0	0	0	0	0	1
07/27/2014 02:00	0.0	0	0	0	0	1
07/27/2014 03:00	0.0	0	0	0	0	1
07/27/2014 04:00	0.0	0	0	0	0	1
07/27/2014 05:00	0.0	0	0	0	0	1
07/27/2014 06:00	0.0	0	0	0	0	1
07/27/2014 07:00	0.0	0	0	0	0	1
07/27/2014 08:00	0.0	0	0	0	0	1
07/27/2014 09:00	0.0	0	0	0	0	1
07/27/2014 10:00	0.0	0	0	0	0	1
07/27/2014 11:00	0.0	0	0	0	0	1
07/27/2014 12:00	0.0	0	0	0	0	1
07/27/2014 13:00	0.0	0	0	0	0	1
07/27/2014 14:00	0.0	0	0	0	0	1
07/27/2014 15:00	0.0	0	0	0	0	1
07/27/2014 16:00	0.0	0	0	0	0	1
07/27/2014 17:00	0.0	0	0	0	0	1
07/27/2014 18:00	0.0	0	0	0	0	1
07/27/2014 19:00	0.0	0	0	0	0	1
07/27/2014 20:00	0.0	0	0	0	0	1
07/27/2014 21:00	0.0	0	0	0	0	1
07/27/2014 22:00	0.0	0	0	0	0	1
07/27/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/28/2014 00:00	0.0	0	0	0	0	1
07/28/2014 01:00	0.0	0	0	0	0	1
07/28/2014 02:00	0.0	0	0	0	0	1
07/28/2014 03:00	0.0	0	0	0	0	1
07/28/2014 04:00	0.0	0	0	0	0	1
07/28/2014 05:00	0.0	0	0	0	0	1
07/28/2014 06:00	0.0	0	0	0	0	1
07/28/2014 07:00	0.0	0	0	0	0	1
07/28/2014 08:00	0.0	0	0	0	0	1
07/28/2014 09:00	0.0	0	0	0	0	1
07/28/2014 10:00	0.0	0	0	0	0	1
07/28/2014 11:00	0.0	0	0	0	0	1
07/28/2014 12:00	0.0	0	0	0	0	1
07/28/2014 13:00	0.0	0	0	0	0	1
07/28/2014 14:00	0.0	0	0	0	0	1
07/28/2014 15:00	0.0	0	0	0	0	1
07/28/2014 16:00	0.0	0	0	0	0	1
07/28/2014 17:00	0.0	0	0	0	0	1
07/28/2014 18:00	0.0	0	0	0	0	1
07/28/2014 19:00	0.0	0	0	0	0	1
07/28/2014 20:00	0.0	0	0	0	0	1
07/28/2014 21:00	0.0	0	0	0	0	1
07/28/2014 22:00	0.0	0	0	0	0	1
07/28/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/29/2014 00:00	0.0	0	0	0	0	1
07/29/2014 01:00	0.0	0	0	0	0	1
07/29/2014 02:00	0.0	0	0	0	0	1
07/29/2014 03:00	0.0	0	0	0	0	1
07/29/2014 04:00	0.0	0	0	0	0	1
07/29/2014 05:00	0.0	0	0	0	0	1
07/29/2014 06:00	0.0	0	0	0	0	1
07/29/2014 07:00	0.0	0	0	0	0	1
07/29/2014 08:00	0.0	0	0	0	0	1
07/29/2014 09:00	0.0	0	0	0	0	1
07/29/2014 10:00	0.0	0	0	0	0	1
07/29/2014 11:00	0.0	0	0	0	0	1
07/29/2014 12:00	0.0	0	0	0	0	1
07/29/2014 13:00	0.0	0	0	0	0	1
07/29/2014 14:00	0.0	0	0	0	0	1
07/29/2014 15:00	0.0	0	0	0	0	1
07/29/2014 16:00	0.0	0	0	0	0	1
07/29/2014 17:00	0.0	0	0	0	0	1
07/29/2014 18:00	0.0	0	0	0	0	1
07/29/2014 19:00	0.0	0	0	0	0	1
07/29/2014 20:00	0.0	0	0	0	0	1
07/29/2014 21:00	0.0	0	0	0	0	1
07/29/2014 22:00	0.0	0	0	0	0	1
07/29/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/30/2014 00:00	0.0	0	0	0	0	1
07/30/2014 01:00	0.0	0	0	0	0	1
07/30/2014 02:00	0.0	0	0	0	0	1
07/30/2014 03:00	0.0	0	0	0	0	1
07/30/2014 04:00	0.0	0	0	0	0	1
07/30/2014 05:00	0.0	0	0	0	0	1
07/30/2014 06:00	0.0	0	0	0	0	1
07/30/2014 07:00	0.0	0	0	0	0	1
07/30/2014 08:00	0.0	0	0	0	0	1
07/30/2014 09:00	0.0	0	0	0	0	1
07/30/2014 10:00	0.0	0	0	0	0	1
07/30/2014 11:00	0.0	0	0	0	0	1
07/30/2014 12:00	0.0	0	0	0	0	1
07/30/2014 13:00	0.0	0	0	0	0	1
07/30/2014 14:00	0.0	0	0	0	0	1
07/30/2014 15:00	0.0	0	0	0	0	1
07/30/2014 16:00	0.0	0	0	0	0	1
07/30/2014 17:00	0.0	0	0	0	0	1
07/30/2014 18:00	0.0	0	0	0	0	1
07/30/2014 19:00	0.0	0	0	0	0	1
07/30/2014 20:00	0.0	0	0	0	0	1
07/30/2014 21:00	0.0	0	0	0	0	1
07/30/2014 22:00	0.0	0	0	0	0	1
07/30/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
07/31/2014 00:00	0.0	0	0	0	0	1
07/31/2014 01:00	0.0	0	0	0	0	1
07/31/2014 02:00	0.0	0	0	0	0	1
07/31/2014 03:00	0.0	0	0	0	0	1
07/31/2014 04:00	0.0	0	0	0	0	1
07/31/2014 05:00	0.0	0	0	0	0	1
07/31/2014 06:00	0.0	0	0	0	0	1
07/31/2014 07:00	0.0	0	0	0	0	1
07/31/2014 08:00	0.0	0	0	0	0	1
07/31/2014 09:00	0.0	0	0	0	0	1
07/31/2014 10:00	0.0	0	0	0	0	1
07/31/2014 11:00	0.0	0	0	0	0	1
07/31/2014 12:00	0.0	0	0	0	0	1
07/31/2014 13:00	0.0	0	0	0	0	1
07/31/2014 14:00	0.0	0	0	0	0	1
07/31/2014 15:00	0.0	0	0	0	0	1
07/31/2014 16:00	0.0	0	0	0	0	1
07/31/2014 17:00	0.0	0	0	0	0	1
07/31/2014 18:00	0.0	0	0	0	0	1
07/31/2014 19:00	0.0	0	0	0	0	1
07/31/2014 20:00	0.0	0	0	0	0	1
07/31/2014 21:00	0.0	0	0	0	0	1
07/31/2014 22:00	0.0	0	0	0	0	1
07/31/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/01/2014 00:00	0.0	0	0	0	0	1
08/01/2014 01:00	0.0	0	0	0	0	1
08/01/2014 02:00	0.0	0	0	0	0	1
08/01/2014 03:00	0.0	0	0	0	0	1
08/01/2014 04:00	0.0	0	0	0	0	1
08/01/2014 05:00	0.0	0	0	0	0	1
08/01/2014 06:00	0.0	0	0	0	0	1
08/01/2014 07:00	0.0	0	0	0	0	1
08/01/2014 08:00	0.0	0	0	0	0	1
08/01/2014 09:00	0.0	0	0	0	0	1
08/01/2014 10:00	0.0	0	0	0	0	1
08/01/2014 11:00	0.0	0	0	0	0	1
08/01/2014 12:00	0.0	0	0	0	0	1
08/01/2014 13:00	0.0	0	0	0	0	1
08/01/2014 14:00	0.0	0	0	0	0	1
08/01/2014 15:00	0.0	0	0	0	0	1
08/01/2014 16:00	0.0	0	0	0	0	1
08/01/2014 17:00	0.0	0	0	0	0	1
08/01/2014 18:00	0.0	0	0	0	0	1
08/01/2014 19:00	0.0	0	0	0	0	1
08/01/2014 20:00	0.0	0	0	0	0	1
08/01/2014 21:00	0.0	0	0	0	0	1
08/01/2014 22:00	0.0	0	0	0	0	1
08/01/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/02/2014 00:00	0.0	0	0	0	0	1
08/02/2014 01:00	0.0	0	0	0	0	1
08/02/2014 02:00	0.0	0	0	0	0	1
08/02/2014 03:00	0.0	0	0	0	0	1
08/02/2014 04:00	0.0	0	0	0	0	1
08/02/2014 05:00	0.0	0	0	0	0	1
08/02/2014 06:00	0.0	0	0	0	0	1
08/02/2014 07:00	0.0	0	0	0	0	1
08/02/2014 08:00	0.0	0	0	0	0	1
08/02/2014 09:00	0.0	0	0	0	0	1
08/02/2014 10:00	0.0	0	0	0	0	1
08/02/2014 11:00	0.0	0	0	0	0	1
08/02/2014 12:00	0.0	0	0	0	0	1
08/02/2014 13:00	0.0	0	0	0	0	1
08/02/2014 14:00	0.0	0	0	0	0	1
08/02/2014 15:00	0.0	0	0	0	0	1
08/02/2014 16:00	0.0	0	0	0	0	1
08/02/2014 17:00	0.0	0	0	0	0	1
08/02/2014 18:00	0.0	0	0	0	0	1
08/02/2014 19:00	0.0	0	0	0	0	1
08/02/2014 20:00	0.0	0	0	0	0	1
08/02/2014 21:00	0.0	0	0	0	0	1
08/02/2014 22:00	0.0	0	0	0	0	1
08/02/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/03/2014 00:00	0.0	0	0	0	0	1
08/03/2014 01:00	0.0	0	0	0	0	1
08/03/2014 02:00	0.0	0	0	0	0	1
08/03/2014 03:00	0.0	0	0	0	0	1
08/03/2014 04:00	0.0	0	0	0	0	1
08/03/2014 05:00	0.0	0	0	0	0	1
08/03/2014 06:00	0.0	0	0	0	0	1
08/03/2014 07:00	0.0	0	0	0	0	1
08/03/2014 08:00	0.0	0	0	0	0	1
08/03/2014 09:00	0.0	0	0	0	0	1
08/03/2014 10:00	0.0	0	0	0	0	1
08/03/2014 11:00	0.0	0	0	0	0	1
08/03/2014 12:00	0.0	0	0	0	0	1
08/03/2014 13:00	0.0	0	0	0	0	1
08/03/2014 14:00	0.0	0	0	0	0	1
08/03/2014 15:00	0.0	0	0	0	0	1
08/03/2014 16:00	0.0	0	0	0	0	1
08/03/2014 17:00	0.0	0	0	0	0	1
08/03/2014 18:00	0.0	0	0	0	0	1
08/03/2014 19:00	0.0	0	0	0	0	1
08/03/2014 20:00	0.0	0	0	0	0	1
08/03/2014 21:00	0.0	0	0	0	0	1
08/03/2014 22:00	0.0	0	0	0	0	1
08/03/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/04/2014 00:00	0.0	0	0	0	0	1
08/04/2014 01:00	0.0	0	0	0	0	1
08/04/2014 02:00	0.0	0	0	0	0	1
08/04/2014 03:00	0.0	0	0	0	0	1
08/04/2014 04:00	0.0	0	0	0	0	1
08/04/2014 05:00	0.0	0	0	0	0	1
08/04/2014 06:00	0.0	0	0	0	0	1
08/04/2014 07:00	0.0	0	0	0	0	1
08/04/2014 08:00	0.0	0	0	0	0	1
08/04/2014 09:00	0.0	0	0	0	0	1
08/04/2014 10:00	0.0	0	0	0	0	1
08/04/2014 11:00	0.0	0	0	0	0	1
08/04/2014 12:00	0.0	0	0	0	0	1
08/04/2014 13:00	0.0	0	0	0	0	1
08/04/2014 14:00	0.0	0	0	0	0	1
08/04/2014 15:00	0.0	0	0	0	0	1
08/04/2014 16:00	0.0	0	0	0	0	1
08/04/2014 17:00	0.0	0	0	0	0	1
08/04/2014 18:00	0.0	0	0	0	0	1
08/04/2014 19:00	0.0	0	0	0	0	1
08/04/2014 20:00	0.0	0	0	0	0	1
08/04/2014 21:00	0.0	0	0	0	0	1
08/04/2014 22:00	0.0	0	0	0	0	1
08/04/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/05/2014 00:00	0.0	0	0	0	0	1
08/05/2014 01:00	0.0	0	0	0	0	1
08/05/2014 02:00	0.0	0	0	0	0	1
08/05/2014 03:00	0.0	0	0	0	0	1
08/05/2014 04:00	0.0	0	0	0	0	1
08/05/2014 05:00	0.0	0	0	0	0	1
08/05/2014 06:00	0.0	0	0	0	0	1
08/05/2014 07:00	0.0	0	0	0	0	1
08/05/2014 08:00	0.0	0	0	0	0	1
08/05/2014 09:00	0.0	0	0	0	0	1
08/05/2014 10:00	0.0	0	0	0	0	1
08/05/2014 11:00	0.0	0	0	0	0	1
08/05/2014 12:00	0.0	0	0	0	0	1
08/05/2014 13:00	0.0	0	0	0	0	1
08/05/2014 14:00	0.0	0	0	0	0	1
08/05/2014 15:00	0.0	0	0	0	0	1
08/05/2014 16:00	0.0	0	0	0	0	1
08/05/2014 17:00	0.0	0	0	0	0	1
08/05/2014 18:00	0.0	0	0	0	0	1
08/05/2014 19:00	0.0	0	0	0	0	1
08/05/2014 20:00	0.0	0	0	0	0	1
08/05/2014 21:00	0.0	0	0	0	0	1
08/05/2014 22:00	0.0	0	0	0	0	1
08/05/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/06/2014 00:00	0.0	0	0	0	0	1
08/06/2014 01:00	0.0	0	0	0	0	1
08/06/2014 02:00	0.0	0	0	0	0	1
08/06/2014 03:00	0.0	0	0	0	0	1
08/06/2014 04:00	0.0	0	0	0	0	1
08/06/2014 05:00	0.0	0	0	0	0	1
08/06/2014 06:00	0.0	0	0	0	0	1
08/06/2014 07:00	0.0	0	0	0	0	1
08/06/2014 08:00	0.0	0	0	0	0	1
08/06/2014 09:00	0.0	0	0	0	0	1
08/06/2014 10:00	0.0	0	0	0	0	1
08/06/2014 11:00	0.0	0	0	0	0	1
08/06/2014 12:00	0.0	0	0	0	0	1
08/06/2014 13:00	0.0	0	0	0	0	1
08/06/2014 14:00	0.0	0	0	0	0	1
08/06/2014 15:00	0.0	0	0	0	0	1
08/06/2014 16:00	0.0	0	0	0	0	1
08/06/2014 17:00	0.0	0	0	0	0	1
08/06/2014 18:00	0.0	0	0	0	0	1
08/06/2014 19:00	0.0	0	0	0	0	1
08/06/2014 20:00	0.0	0	0	0	0	1
08/06/2014 21:00	0.0	0	0	0	0	1
08/06/2014 22:00	0.0	0	0	0	0	1
08/06/2014 23:00	296.4	0	0	0	1	0
Average/Sum#:	296.4 #	0 #	0 #	0 #	1 #	23 #
Minimum:	0.0	0	0	0	0	0
Maximum:	296.4	0	0	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/07/2014 00:00	0.0	0	0	0	0	0
08/07/2014 01:00	0.0	0	0	0	0	0
08/07/2014 02:00	0.0	0	0	0	0	0
08/07/2014 03:00	0.0	0	0	0	0	0
08/07/2014 04:00	0.0	0	0	0	0	0
08/07/2014 05:00	0.0	0	0	0	0	0
08/07/2014 06:00	0.0	0	0	0	0	0
08/07/2014 07:00	0.0	0	0	0	0	0
08/07/2014 08:00	0.0	0	0	0	0	0
08/07/2014 09:00	0.0	0	0	0	0	0
08/07/2014 10:00	0.0	0	0	0	0	0
08/07/2014 11:00	0.0	0	0	0	0	0
08/07/2014 12:00	0.0	0	0	0	0	0
08/07/2014 13:00	1,616.9	0	1	0	0	0
08/07/2014 14:00	5,293.1	0	0	1	0	0
08/07/2014 15:00	1,450.1	0	0	1	0	0
08/07/2014 16:00	0.0	0	0	0	0	1
08/07/2014 17:00	0.0	0	0	0	0	1
08/07/2014 18:00	0.0	0	0	0	0	1
08/07/2014 19:00	0.0	0	0	0	0	1
08/07/2014 20:00	0.0	0	0	0	0	1
08/07/2014 21:00	0.0	0	0	0	0	1
08/07/2014 22:00	0.0	0	0	0	0	1
08/07/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,360.1 #	0 #	1 #	2 #	0 #	8 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,293.1	0	1	1	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/08/2014 00:00	0.0	0	0	0	0	1
08/08/2014 01:00	0.0	0	0	0	0	1
08/08/2014 02:00	0.0	0	0	0	0	1
08/08/2014 03:00	0.0	0	0	0	0	1
08/08/2014 04:00	0.0	0	0	0	0	1
08/08/2014 05:00	0.0	0	0	0	0	1
08/08/2014 06:00	0.0	0	0	0	0	1
08/08/2014 07:00	0.0	0	0	0	0	1
08/08/2014 08:00	0.0	0	0	0	0	1
08/08/2014 09:00	0.0	0	0	0	0	1
08/08/2014 10:00	0.0	0	0	0	0	1
08/08/2014 11:00	0.0	0	0	0	0	1
08/08/2014 12:00	0.0	0	0	0	0	1
08/08/2014 13:00	0.0	0	0	0	0	1
08/08/2014 14:00	0.0	0	0	0	0	1
08/08/2014 15:00	0.0	0	0	0	0	1
08/08/2014 16:00	0.0	0	0	0	0	1
08/08/2014 17:00	0.0	0	0	0	0	1
08/08/2014 18:00	0.0	0	0	0	0	1
08/08/2014 19:00	0.0	0	0	0	0	1
08/08/2014 20:00	0.0	0	0	0	0	1
08/08/2014 21:00	0.0	0	0	0	0	1
08/08/2014 22:00	0.0	0	0	0	0	1
08/08/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/09/2014 00:00	0.0	0	0	0	0	1
08/09/2014 01:00	0.0	0	0	0	0	1
08/09/2014 02:00	346.8	0	0	0	1	0
08/09/2014 03:00	0.0	0	0	0	0	0
08/09/2014 04:00	0.0	0	0	0	0	0
08/09/2014 05:00	0.0	0	0	0	0	0
08/09/2014 06:00	0.0	0	0	0	0	0
08/09/2014 07:00	0.0	0	0	0	0	0
08/09/2014 08:00	0.0	0	0	0	0	0
08/09/2014 09:00	0.0	0	0	0	0	0
08/09/2014 10:00	3,689.3	0	1	0	0	0
08/09/2014 11:00	2,996.4	0	1	0	0	0
08/09/2014 12:00	0.0	0	0	0	0	1
08/09/2014 13:00	0.0	0	0	0	0	1
08/09/2014 14:00	0.0	0	0	0	0	1
08/09/2014 15:00	0.0	0	0	0	0	1
08/09/2014 16:00	0.0	0	0	0	0	1
08/09/2014 17:00	0.0	0	0	0	0	1
08/09/2014 18:00	0.0	0	0	0	0	1
08/09/2014 19:00	0.0	0	0	0	0	1
08/09/2014 20:00	0.0	0	0	0	0	1
08/09/2014 21:00	0.0	0	0	0	0	1
08/09/2014 22:00	0.0	0	0	0	0	1
08/09/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,032.5 #	0 #	2 #	0 #	1 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3,689.3	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/10/2014 00:00	331.5	0	0	0	1	0
08/10/2014 01:00	0.0	0	0	0	0	0
08/10/2014 02:00	0.0	0	0	0	0	0
08/10/2014 03:00	0.0	0	0	0	0	0
08/10/2014 04:00	0.0	0	0	0	0	0
08/10/2014 05:00	0.0	0	0	0	0	0
08/10/2014 06:00	0.0	0	0	0	0	0
08/10/2014 07:00	0.0	0	0	0	0	0
08/10/2014 08:00	0.0	0	0	0	0	0
08/10/2014 09:00	0.0	0	0	0	0	0
08/10/2014 10:00	0.0	0	0	0	0	0
08/10/2014 11:00	3,690.0	0	1	0	0	0
08/10/2014 12:00	3,694.1	0	1	0	0	0
08/10/2014 13:00	0.0	0	0	0	0	1
08/10/2014 14:00	0.0	0	0	0	0	1
08/10/2014 15:00	0.0	0	0	0	0	1
08/10/2014 16:00	0.0	0	0	0	0	1
08/10/2014 17:00	0.0	0	0	0	0	1
08/10/2014 18:00	0.0	0	0	0	0	1
08/10/2014 19:00	0.0	0	0	0	0	1
08/10/2014 20:00	0.0	0	0	0	0	1
08/10/2014 21:00	0.0	0	0	0	0	1
08/10/2014 22:00	0.0	0	0	0	0	1
08/10/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,715.6 #	0 #	2 #	0 #	1 #	11 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3,694.1	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/11/2014 00:00	0.0	0	0	0	0	1
08/11/2014 01:00	0.0	0	0	0	0	1
08/11/2014 02:00	0.0	0	0	0	0	1
08/11/2014 03:00	0.0	0	0	0	0	1
08/11/2014 04:00	0.0	0	0	0	0	1
08/11/2014 05:00	0.0	0	0	0	0	1
08/11/2014 06:00	0.0	0	0	0	0	1
08/11/2014 07:00	0.0	0	0	0	0	1
08/11/2014 08:00	0.0	0	0	0	0	1
08/11/2014 09:00	0.0	0	0	0	0	1
08/11/2014 10:00	0.0	0	0	0	0	1
08/11/2014 11:00	0.0	0	0	0	0	1
08/11/2014 12:00	0.0	0	0	0	0	1
08/11/2014 13:00	0.0	0	0	0	0	1
08/11/2014 14:00	0.0	0	0	0	0	1
08/11/2014 15:00	0.0	0	0	0	0	1
08/11/2014 16:00	0.0	0	0	0	0	1
08/11/2014 17:00	0.0	0	0	0	0	1
08/11/2014 18:00	0.0	0	0	0	0	1
08/11/2014 19:00	0.0	0	0	0	0	1
08/11/2014 20:00	0.0	0	0	0	0	1
08/11/2014 21:00	0.0	0	0	0	0	1
08/11/2014 22:00	0.0	0	0	0	0	1
08/11/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/12/2014 00:00	0.0	0	0	0	0	1
08/12/2014 01:00	0.0	0	0	0	0	1
08/12/2014 02:00	0.0	0	0	0	0	1
08/12/2014 03:00	0.0	0	0	0	0	1
08/12/2014 04:00	0.0	0	0	0	0	1
08/12/2014 05:00	0.0	0	0	0	0	1
08/12/2014 06:00	0.0	0	0	0	0	1
08/12/2014 07:00	0.0	0	0	0	0	1
08/12/2014 08:00	0.0	0	0	0	0	1
08/12/2014 09:00	0.0	0	0	0	0	1
08/12/2014 10:00	0.0	0	0	0	0	1
08/12/2014 11:00	0.0	0	0	0	0	1
08/12/2014 12:00	0.0	0	0	0	0	1
08/12/2014 13:00	0.0	0	0	0	0	1
08/12/2014 14:00	0.0	0	0	0	0	1
08/12/2014 15:00	0.0	0	0	0	0	1
08/12/2014 16:00	0.0	0	0	0	0	1
08/12/2014 17:00	0.0	0	0	0	0	1
08/12/2014 18:00	0.0	0	0	0	0	1
08/12/2014 19:00	0.0	0	0	0	0	1
08/12/2014 20:00	0.0	0	0	0	0	1
08/12/2014 21:00	0.0	0	0	0	0	1
08/12/2014 22:00	0.0	0	0	0	0	1
08/12/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/13/2014 00:00	0.0	0	0	0	0	1
08/13/2014 01:00	538.3	0	0	0	1	0
08/13/2014 02:00	0.0	0	0	0	0	0
08/13/2014 03:00	0.0	0	0	0	0	0
08/13/2014 04:00	0.0	0	0	0	0	0
08/13/2014 05:00	0.0	0	0	0	0	0
08/13/2014 06:00	0.0	0	0	0	0	0
08/13/2014 07:00	0.0	0	0	0	0	0
08/13/2014 08:00	2,733.0	0	0	1	0	0
08/13/2014 09:00	4,716.5	0	0	1	0	0
08/13/2014 10:00	0.0	0	0	0	0	1
08/13/2014 11:00	0.0	0	0	0	0	1
08/13/2014 12:00	0.0	0	0	0	0	1
08/13/2014 13:00	0.0	0	0	0	0	1
08/13/2014 14:00	0.0	0	0	0	0	1
08/13/2014 15:00	0.0	0	0	0	0	1
08/13/2014 16:00	0.0	0	0	0	0	1
08/13/2014 17:00	0.0	0	0	0	0	1
08/13/2014 18:00	0.0	0	0	0	0	1
08/13/2014 19:00	0.0	0	0	0	0	1
08/13/2014 20:00	0.0	0	0	0	0	1
08/13/2014 21:00	0.0	0	0	0	0	1
08/13/2014 22:00	0.0	0	0	0	0	1
08/13/2014 23:00	391.0	0	0	0	1	0
Average/Sum#:	8,378.8 #	0 #	0 #	2 #	2 #	14 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,716.5	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/14/2014 00:00	0.0	0	0	0	0	0
08/14/2014 01:00	0.0	0	0	0	0	0
08/14/2014 02:00	0.0	0	0	0	0	0
08/14/2014 03:00	0.0	0	0	0	0	0
08/14/2014 04:00	0.0	0	0	0	0	0
08/14/2014 05:00	0.0	0	0	0	0	0
08/14/2014 06:00	0.0	0	0	0	0	0
08/14/2014 07:00	0.0	0	0	0	0	0
08/14/2014 08:00	0.0	0	0	0	0	0
08/14/2014 09:00	0.0	0	0	0	0	0
08/14/2014 10:00	0.0	0	0	0	0	0
08/14/2014 11:00	0.0	0	0	0	0	0
08/14/2014 12:00	0.0	0	0	0	0	0
08/14/2014 13:00	0.0	0	0	0	0	0
08/14/2014 14:00	0.0	0	0	0	0	0
08/14/2014 15:00	0.0	0	0	0	0	0
08/14/2014 16:00	0.0	0	0	0	0	0
08/14/2014 17:00	0.0	0	0	0	0	0
08/14/2014 18:00	0.0	0	0	0	0	0
08/14/2014 19:00	0.0	0	0	0	0	0
08/14/2014 20:00	0.0	0	0	0	0	0
08/14/2014 21:00	0.0	0	0	0	0	0
08/14/2014 22:00	0.0	0	0	0	0	0
08/14/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/15/2014 00:00	0.0	0	0	0	0	0
08/15/2014 01:00	0.0	0	0	0	0	0
08/15/2014 02:00	0.0	0	0	0	0	0
08/15/2014 03:00	0.0	0	0	0	0	0
08/15/2014 04:00	0.0	0	0	0	0	0
08/15/2014 05:00	0.0	0	0	0	0	0
08/15/2014 06:00	0.0	0	0	0	0	0
08/15/2014 07:00	0.0	0	0	0	0	0
08/15/2014 08:00	0.0	0	0	0	0	0
08/15/2014 09:00	0.0	0	0	0	0	0
08/15/2014 10:00	0.0	0	0	0	0	0
08/15/2014 11:00	0.0	0	0	0	0	0
08/15/2014 12:00	0.0	0	0	0	0	0
08/15/2014 13:00	0.0	0	0	0	0	0
08/15/2014 14:00	0.0	0	0	0	0	0
08/15/2014 15:00	0.0	0	0	0	0	0
08/15/2014 16:00	0.0	0	0	0	0	0
08/15/2014 17:00	0.0	0	0	0	0	0
08/15/2014 18:00	0.0	0	0	0	0	0
08/15/2014 19:00	0.0	0	0	0	0	0
08/15/2014 20:00	0.0	0	0	0	0	0
08/15/2014 21:00	0.0	0	0	0	0	0
08/15/2014 22:00	0.0	0	0	0	0	0
08/15/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/16/2014 00:00	0.0	0	0	0	0	0
08/16/2014 01:00	0.0	0	0	0	0	0
08/16/2014 02:00	0.0	0	0	0	0	0
08/16/2014 03:00	0.0	0	0	0	0	0
08/16/2014 04:00	0.0	0	0	0	0	0
08/16/2014 05:00	0.0	0	0	0	0	0
08/16/2014 06:00	0.0	0	0	0	0	0
08/16/2014 07:00	0.0	0	0	0	0	0
08/16/2014 08:00	0.0	0	0	0	0	0
08/16/2014 09:00	0.0	0	0	0	0	0
08/16/2014 10:00	0.0	0	0	0	0	0
08/16/2014 11:00	0.0	0	0	0	0	0
08/16/2014 12:00	0.0	0	0	0	0	0
08/16/2014 13:00	0.0	0	0	0	0	0
08/16/2014 14:00	0.0	0	0	0	0	0
08/16/2014 15:00	0.0	0	0	0	0	0
08/16/2014 16:00	0.0	0	0	0	0	0
08/16/2014 17:00	0.0	0	0	0	0	0
08/16/2014 18:00	0.0	0	0	0	0	0
08/16/2014 19:00	0.0	0	0	0	0	0
08/16/2014 20:00	0.0	0	0	0	0	0
08/16/2014 21:00	0.0	0	0	0	0	0
08/16/2014 22:00	0.0	0	0	0	0	0
08/16/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/17/2014 00:00	0.0	0	0	0	0	0
08/17/2014 01:00	0.0	0	0	0	0	0
08/17/2014 02:00	0.0	0	0	0	0	0
08/17/2014 03:00	0.0	0	0	0	0	0
08/17/2014 04:00	0.0	0	0	0	0	0
08/17/2014 05:00	0.0	0	0	0	0	0
08/17/2014 06:00	0.0	0	0	0	0	0
08/17/2014 07:00	0.0	0	0	0	0	0
08/17/2014 08:00	0.0	0	0	0	0	0
08/17/2014 09:00	0.0	0	0	0	0	0
08/17/2014 10:00	0.0	0	0	0	0	0
08/17/2014 11:00	0.0	0	0	0	0	0
08/17/2014 12:00	0.0	0	0	0	0	0
08/17/2014 13:00	0.0	0	0	0	0	0
08/17/2014 14:00	0.0	0	0	0	0	0
08/17/2014 15:00	0.0	0	0	0	0	0
08/17/2014 16:00	0.0	0	0	0	0	0
08/17/2014 17:00	0.0	0	0	0	0	0
08/17/2014 18:00	0.0	0	0	0	0	0
08/17/2014 19:00	0.0	0	0	0	0	0
08/17/2014 20:00	0.0	0	0	0	0	0
08/17/2014 21:00	0.0	0	0	0	0	0
08/17/2014 22:00	0.0	0	0	0	0	0
08/17/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/18/2014 00:00	0.0	0	0	0	0	0
08/18/2014 01:00	0.0	0	0	0	0	0
08/18/2014 02:00	0.0	0	0	0	0	0
08/18/2014 03:00	0.0	0	0	0	0	0
08/18/2014 04:00	0.0	0	0	0	0	0
08/18/2014 05:00	0.0	0	0	0	0	0
08/18/2014 06:00	0.0	0	0	0	0	0
08/18/2014 07:00	0.0	0	0	0	0	0
08/18/2014 08:00	0.0	0	0	0	0	0
08/18/2014 09:00	0.0	0	0	0	0	0
08/18/2014 10:00	0.0	0	0	0	0	0
08/18/2014 11:00	0.0	0	0	0	0	0
08/18/2014 12:00	0.0	0	0	0	0	0
08/18/2014 13:00	0.0	0	0	0	0	0
08/18/2014 14:00	0.0	0	0	0	0	0
08/18/2014 15:00	0.0	0	0	0	0	0
08/18/2014 16:00	0.0	0	0	0	0	0
08/18/2014 17:00	0.0	0	0	0	0	0
08/18/2014 18:00	0.0	0	0	0	0	0
08/18/2014 19:00	0.0	0	0	0	0	0
08/18/2014 20:00	0.0	0	0	0	0	0
08/18/2014 21:00	0.0	0	0	0	0	0
08/18/2014 22:00	0.0	0	0	0	0	0
08/18/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/19/2014 00:00	0.0	0	0	0	0	0
08/19/2014 01:00	0.0	0	0	0	0	0
08/19/2014 02:00	0.0	0	0	0	0	0
08/19/2014 03:00	0.0	0	0	0	0	0
08/19/2014 04:00	0.0	0	0	0	0	0
08/19/2014 05:00	0.0	0	0	0	0	0
08/19/2014 06:00	0.0	0	0	0	0	0
08/19/2014 07:00	0.0	0	0	0	0	0
08/19/2014 08:00	0.0	0	0	0	0	0
08/19/2014 09:00	0.0	0	0	0	0	0
08/19/2014 10:00	0.0	0	0	0	0	0
08/19/2014 11:00	0.0	0	0	0	0	0
08/19/2014 12:00	0.0	0	0	0	0	0
08/19/2014 13:00	0.0	0	0	0	0	0
08/19/2014 14:00	0.0	0	0	0	0	0
08/19/2014 15:00	0.0	0	0	0	0	0
08/19/2014 16:00	0.0	0	0	0	0	0
08/19/2014 17:00	0.0	0	0	0	0	0
08/19/2014 18:00	0.0	0	0	0	0	0
08/19/2014 19:00	0.0	0	0	0	0	0
08/19/2014 20:00	0.0	0	0	0	0	0
08/19/2014 21:00	0.0	0	0	0	0	0
08/19/2014 22:00	0.0	0	0	0	0	0
08/19/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/20/2014 00:00	0.0	0	0	0	0	0
08/20/2014 01:00	0.0	0	0	0	0	0
08/20/2014 02:00	0.0	0	0	0	0	0
08/20/2014 03:00	0.0	0	0	0	0	0
08/20/2014 04:00	0.0	0	0	0	0	0
08/20/2014 05:00	0.0	0	0	0	0	0
08/20/2014 06:00	0.0	0	0	0	0	0
08/20/2014 07:00	0.0	0	0	0	0	0
08/20/2014 08:00	0.0	0	0	0	0	0
08/20/2014 09:00	0.0	0	0	0	0	0
08/20/2014 10:00	0.0	0	0	0	0	0
08/20/2014 11:00	0.0	0	0	0	0	0
08/20/2014 12:00	0.0	0	0	0	0	0
08/20/2014 13:00	0.0	0	0	0	0	0
08/20/2014 14:00	0.0	0	0	0	0	0
08/20/2014 15:00	0.0	0	0	0	0	0
08/20/2014 16:00	0.0	0	0	0	0	0
08/20/2014 17:00	0.0	0	0	0	0	0
08/20/2014 18:00	0.0	0	0	0	0	0
08/20/2014 19:00	0.0	0	0	0	0	0
08/20/2014 20:00	0.0	0	0	0	0	0
08/20/2014 21:00	0.0	0	0	0	0	0
08/20/2014 22:00	0.0	0	0	0	0	0
08/20/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/21/2014 00:00	0.0	0	0	0	0	0
08/21/2014 01:00	0.0	0	0	0	0	0
08/21/2014 02:00	0.0	0	0	0	0	0
08/21/2014 03:00	0.0	0	0	0	0	0
08/21/2014 04:00	0.0	0	0	0	0	0
08/21/2014 05:00	0.0	0	0	0	0	0
08/21/2014 06:00	0.0	0	0	0	0	0
08/21/2014 07:00	0.0	0	0	0	0	0
08/21/2014 08:00	0.0	0	0	0	0	0
08/21/2014 09:00	0.0	0	0	0	0	0
08/21/2014 10:00	0.0	0	0	0	0	0
08/21/2014 11:00	0.0	0	0	0	0	0
08/21/2014 12:00	0.0	0	0	0	0	0
08/21/2014 13:00	0.0	0	0	0	0	0
08/21/2014 14:00	0.0	0	0	0	0	0
08/21/2014 15:00	0.0	0	0	0	0	0
08/21/2014 16:00	0.0	0	0	0	0	0
08/21/2014 17:00	0.0	0	0	0	0	0
08/21/2014 18:00	0.0	0	0	0	0	0
08/21/2014 19:00	0.0	0	0	0	0	0
08/21/2014 20:00	0.0	0	0	0	0	0
08/21/2014 21:00	0.0	0	0	0	0	0
08/21/2014 22:00	0.0	0	0	0	0	0
08/21/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/22/2014 00:00	0.0	0	0	0	0	0
08/22/2014 01:00	0.0	0	0	0	0	0
08/22/2014 02:00	0.0	0	0	0	0	0
08/22/2014 03:00	0.0	0	0	0	0	0
08/22/2014 04:00	0.0	0	0	0	0	0
08/22/2014 05:00	0.0	0	0	0	0	0
08/22/2014 06:00	0.0	0	0	0	0	0
08/22/2014 07:00	0.0	0	0	0	0	0
08/22/2014 08:00	0.0	0	0	0	0	0
08/22/2014 09:00	0.0	0	0	0	0	0
08/22/2014 10:00	0.0	0	0	0	0	0
08/22/2014 11:00	0.0	0	0	0	0	0
08/22/2014 12:00	0.0	0	0	0	0	0
08/22/2014 13:00	0.0	0	0	0	0	0
08/22/2014 14:00	0.0	0	0	0	0	0
08/22/2014 15:00	0.0	0	0	0	0	0
08/22/2014 16:00	0.0	0	0	0	0	0
08/22/2014 17:00	0.0	0	0	0	0	0
08/22/2014 18:00	0.0	0	0	0	0	0
08/22/2014 19:00	0.0	0	0	0	0	0
08/22/2014 20:00	0.0	0	0	0	0	0
08/22/2014 21:00	0.0	0	0	0	0	0
08/22/2014 22:00	0.0	0	0	0	0	0
08/22/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/23/2014 00:00	0.0	0	0	0	0	0
08/23/2014 01:00	0.0	0	0	0	0	0
08/23/2014 02:00	0.0	0	0	0	0	0
08/23/2014 03:00	0.0	0	0	0	0	0
08/23/2014 04:00	0.0	0	0	0	0	0
08/23/2014 05:00	0.0	0	0	0	0	0
08/23/2014 06:00	0.0	0	0	0	0	0
08/23/2014 07:00	0.0	0	0	0	0	0
08/23/2014 08:00	0.0	0	0	0	0	0
08/23/2014 09:00	0.0	0	0	0	0	0
08/23/2014 10:00	0.0	0	0	0	0	0
08/23/2014 11:00	0.0	0	0	0	0	0
08/23/2014 12:00	0.0	0	0	0	0	0
08/23/2014 13:00	0.0	0	0	0	0	0
08/23/2014 14:00	0.0	0	0	0	0	0
08/23/2014 15:00	0.0	0	0	0	0	0
08/23/2014 16:00	0.0	0	0	0	0	0
08/23/2014 17:00	0.0	0	0	0	0	0
08/23/2014 18:00	0.0	0	0	0	0	0
08/23/2014 19:00	0.0	0	0	0	0	0
08/23/2014 20:00	0.0	0	0	0	0	0
08/23/2014 21:00	0.0	0	0	0	0	0
08/23/2014 22:00	0.0	0	0	0	0	0
08/23/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/24/2014 00:00	0.0	0	0	0	0	0
08/24/2014 01:00	0.0	0	0	0	0	0
08/24/2014 02:00	0.0	0	0	0	0	0
08/24/2014 03:00	0.0	0	0	0	0	0
08/24/2014 04:00	0.0	0	0	0	0	0
08/24/2014 05:00	0.0	0	0	0	0	0
08/24/2014 06:00	0.0	0	0	0	0	0
08/24/2014 07:00	0.0	0	0	0	0	0
08/24/2014 08:00	0.0	0	0	0	0	0
08/24/2014 09:00	0.0	0	0	0	0	0
08/24/2014 10:00	0.0	0	0	0	0	0
08/24/2014 11:00	0.0	0	0	0	0	0
08/24/2014 12:00	0.0	0	0	0	0	0
08/24/2014 13:00	0.0	0	0	0	0	0
08/24/2014 14:00	0.0	0	0	0	0	0
08/24/2014 15:00	0.0	0	0	0	0	0
08/24/2014 16:00	0.0	0	0	0	0	0
08/24/2014 17:00	0.0	0	0	0	0	0
08/24/2014 18:00	0.0	0	0	0	0	0
08/24/2014 19:00	0.0	0	0	0	0	0
08/24/2014 20:00	0.0	0	0	0	0	0
08/24/2014 21:00	0.0	0	0	0	0	0
08/24/2014 22:00	0.0	0	0	0	0	0
08/24/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/25/2014 00:00	0.0	0	0	0	0	0
08/25/2014 01:00	0.0	0	0	0	0	0
08/25/2014 02:00	0.0	0	0	0	0	0
08/25/2014 03:00	0.0	0	0	0	0	0
08/25/2014 04:00	0.0	0	0	0	0	0
08/25/2014 05:00	0.0	0	0	0	0	0
08/25/2014 06:00	0.0	0	0	0	0	0
08/25/2014 07:00	0.0	0	0	0	0	0
08/25/2014 08:00	0.0	0	0	0	0	0
08/25/2014 09:00	0.0	0	0	0	0	0
08/25/2014 10:00	0.0	0	0	0	0	0
08/25/2014 11:00	0.0	0	0	0	0	0
08/25/2014 12:00	0.0	0	0	0	0	0
08/25/2014 13:00	0.0	0	0	0	0	0
08/25/2014 14:00	0.0	0	0	0	0	0
08/25/2014 15:00	0.0	0	0	0	0	0
08/25/2014 16:00	0.0	0	0	0	0	0
08/25/2014 17:00	0.0	0	0	0	0	0
08/25/2014 18:00	0.0	0	0	0	0	0
08/25/2014 19:00	0.0	0	0	0	0	0
08/25/2014 20:00	0.0	0	0	0	0	0
08/25/2014 21:00	0.0	0	0	0	0	0
08/25/2014 22:00	0.0	0	0	0	0	0
08/25/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/26/2014 00:00	0.0	0	0	0	0	0
08/26/2014 01:00	0.0	0	0	0	0	0
08/26/2014 02:00	0.0	0	0	0	0	0
08/26/2014 03:00	0.0	0	0	0	0	0
08/26/2014 04:00	0.0	0	0	0	0	0
08/26/2014 05:00	0.0	0	0	0	0	0
08/26/2014 06:00	0.0	0	0	0	0	0
08/26/2014 07:00	0.0	0	0	0	0	0
08/26/2014 08:00	0.0	0	0	0	0	0
08/26/2014 09:00	0.0	0	0	0	0	0
08/26/2014 10:00	0.0	0	0	0	0	0
08/26/2014 11:00	0.0	0	0	0	0	0
08/26/2014 12:00	0.0	0	0	0	0	0
08/26/2014 13:00	0.0	0	0	0	0	0
08/26/2014 14:00	0.0	0	0	0	0	0
08/26/2014 15:00	0.0	0	0	0	0	0
08/26/2014 16:00	0.0	0	0	0	0	0
08/26/2014 17:00	0.0	0	0	0	0	0
08/26/2014 18:00	0.0	0	0	0	0	0
08/26/2014 19:00	0.0	0	0	0	0	0
08/26/2014 20:00	0.0	0	0	0	0	0
08/26/2014 21:00	0.0	0	0	0	0	0
08/26/2014 22:00	0.0	0	0	0	0	0
08/26/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/27/2014 00:00	0.0	0	0	0	0	0
08/27/2014 01:00	0.0	0	0	0	0	0
08/27/2014 02:00	0.0	0	0	0	0	0
08/27/2014 03:00	0.0	0	0	0	0	0
08/27/2014 04:00	0.0	0	0	0	0	0
08/27/2014 05:00	0.0	0	0	0	0	0
08/27/2014 06:00	0.0	0	0	0	0	0
08/27/2014 07:00	0.0	0	0	0	0	0
08/27/2014 08:00	0.0	0	0	0	0	0
08/27/2014 09:00	0.0	0	0	0	0	0
08/27/2014 10:00	0.0	0	0	0	0	0
08/27/2014 11:00	0.0	0	0	0	0	0
08/27/2014 12:00	0.0	0	0	0	0	0
08/27/2014 13:00	0.0	0	0	0	0	0
08/27/2014 14:00	0.0	0	0	0	0	0
08/27/2014 15:00	0.0	0	0	0	0	0
08/27/2014 16:00	0.0	0	0	0	0	0
08/27/2014 17:00	0.0	0	0	0	0	0
08/27/2014 18:00	0.0	0	0	0	0	0
08/27/2014 19:00	0.0	0	0	0	0	0
08/27/2014 20:00	0.0	0	0	0	0	0
08/27/2014 21:00	0.0	0	0	0	0	0
08/27/2014 22:00	0.0	0	0	0	0	0
08/27/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/28/2014 00:00	0.0	0	0	0	0	0
08/28/2014 01:00	0.0	0	0	0	0	0
08/28/2014 02:00	0.0	0	0	0	0	0
08/28/2014 03:00	0.0	0	0	0	0	0
08/28/2014 04:00	0.0	0	0	0	0	0
08/28/2014 05:00	0.0	0	0	0	0	0
08/28/2014 06:00	0.0	0	0	0	0	0
08/28/2014 07:00	0.0	0	0	0	0	0
08/28/2014 08:00	0.0	0	0	0	0	0
08/28/2014 09:00	0.0	0	0	0	0	0
08/28/2014 10:00	0.0	0	0	0	0	0
08/28/2014 11:00	0.0	0	0	0	0	0
08/28/2014 12:00	0.0	0	0	0	0	0
08/28/2014 13:00	0.0	0	0	0	0	0
08/28/2014 14:00	0.0	0	0	0	0	0
08/28/2014 15:00	0.0	0	0	0	0	0
08/28/2014 16:00	0.0	0	0	0	0	0
08/28/2014 17:00	0.0	0	0	0	0	0
08/28/2014 18:00	0.0	0	0	0	0	0
08/28/2014 19:00	0.0	0	0	0	0	0
08/28/2014 20:00	0.0	0	0	0	0	0
08/28/2014 21:00	0.0	0	0	0	0	0
08/28/2014 22:00	0.0	0	0	0	0	0
08/28/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/29/2014 00:00	0.0	0	0	0	0	0
08/29/2014 01:00	0.0	0	0	0	0	0
08/29/2014 02:00	0.0	0	0	0	0	0
08/29/2014 03:00	0.0	0	0	0	0	0
08/29/2014 04:00	0.0	0	0	0	0	0
08/29/2014 05:00	0.0	0	0	0	0	0
08/29/2014 06:00	0.0	0	0	0	0	0
08/29/2014 07:00	0.0	0	0	0	0	0
08/29/2014 08:00	0.0	0	0	0	0	0
08/29/2014 09:00	0.0	0	0	0	0	0
08/29/2014 10:00	0.0	0	0	0	0	0
08/29/2014 11:00	0.0	0	0	0	0	0
08/29/2014 12:00	0.0	0	0	0	0	0
08/29/2014 13:00	0.0	0	0	0	0	0
08/29/2014 14:00	0.0	0	0	0	0	0
08/29/2014 15:00	0.0	0	0	0	0	0
08/29/2014 16:00	0.0	0	0	0	0	0
08/29/2014 17:00	0.0	0	0	0	0	0
08/29/2014 18:00	0.0	0	0	0	0	0
08/29/2014 19:00	0.0	0	0	0	0	0
08/29/2014 20:00	0.0	0	0	0	0	0
08/29/2014 21:00	0.0	0	0	0	0	0
08/29/2014 22:00	0.0	0	0	0	0	0
08/29/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/30/2014 00:00	0.0	0	0	0	0	0
08/30/2014 01:00	0.0	0	0	0	0	0
08/30/2014 02:00	0.0	0	0	0	0	0
08/30/2014 03:00	0.0	0	0	0	0	0
08/30/2014 04:00	0.0	0	0	0	0	0
08/30/2014 05:00	0.0	0	0	0	0	0
08/30/2014 06:00	0.0	0	0	0	0	0
08/30/2014 07:00	0.0	0	0	0	0	0
08/30/2014 08:00	0.0	0	0	0	0	0
08/30/2014 09:00	0.0	0	0	0	0	0
08/30/2014 10:00	0.0	0	0	0	0	0
08/30/2014 11:00	0.0	0	0	0	0	0
08/30/2014 12:00	0.0	0	0	0	0	0
08/30/2014 13:00	0.0	0	0	0	0	0
08/30/2014 14:00	0.0	0	0	0	0	0
08/30/2014 15:00	0.0	0	0	0	0	0
08/30/2014 16:00	0.0	0	0	0	0	0
08/30/2014 17:00	0.0	0	0	0	0	0
08/30/2014 18:00	0.0	0	0	0	0	0
08/30/2014 19:00	0.0	0	0	0	0	0
08/30/2014 20:00	0.0	0	0	0	0	0
08/30/2014 21:00	0.0	0	0	0	0	0
08/30/2014 22:00	0.0	0	0	0	0	0
08/30/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
08/31/2014 00:00	0.0	0	0	0	0	0
08/31/2014 01:00	0.0	0	0	0	0	0
08/31/2014 02:00	0.0	0	0	0	0	0
08/31/2014 03:00	0.0	0	0	0	0	0
08/31/2014 04:00	0.0	0	0	0	0	0
08/31/2014 05:00	0.0	0	0	0	0	0
08/31/2014 06:00	0.0	0	0	0	0	0
08/31/2014 07:00	0.0	0	0	0	0	0
08/31/2014 08:00	0.0	0	0	0	0	0
08/31/2014 09:00	0.0	0	0	0	0	0
08/31/2014 10:00	0.0	0	0	0	0	0
08/31/2014 11:00	0.0	0	0	0	0	0
08/31/2014 12:00	0.0	0	0	0	0	0
08/31/2014 13:00	0.0	0	0	0	0	0
08/31/2014 14:00	0.0	0	0	0	0	0
08/31/2014 15:00	0.0	0	0	0	0	0
08/31/2014 16:00	0.0	0	0	0	0	0
08/31/2014 17:00	0.0	0	0	0	0	0
08/31/2014 18:00	0.0	0	0	0	0	0
08/31/2014 19:00	0.0	0	0	0	0	0
08/31/2014 20:00	0.0	0	0	0	0	0
08/31/2014 21:00	0.0	0	0	0	0	0
08/31/2014 22:00	0.0	0	0	0	0	0
08/31/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/01/2014 00:00	0.0	0	0	0	0	0
09/01/2014 01:00	0.0	0	0	0	0	0
09/01/2014 02:00	0.0	0	0	0	0	0
09/01/2014 03:00	0.0	0	0	0	0	0
09/01/2014 04:00	0.0	0	0	0	0	0
09/01/2014 05:00	0.0	0	0	0	0	0
09/01/2014 06:00	0.0	0	0	0	0	0
09/01/2014 07:00	0.0	0	0	0	0	0
09/01/2014 08:00	0.0	0	0	0	0	0
09/01/2014 09:00	0.0	0	0	0	0	0
09/01/2014 10:00	0.0	0	0	0	0	0
09/01/2014 11:00	0.0	0	0	0	0	0
09/01/2014 12:00	0.0	0	0	0	0	0
09/01/2014 13:00	0.0	0	0	0	0	0
09/01/2014 14:00	0.0	0	0	0	0	0
09/01/2014 15:00	0.0	0	0	0	0	0
09/01/2014 16:00	0.0	0	0	0	0	0
09/01/2014 17:00	0.0	0	0	0	0	0
09/01/2014 18:00	0.0	0	0	0	0	0
09/01/2014 19:00	0.0	0	0	0	0	0
09/01/2014 20:00	0.0	0	0	0	0	0
09/01/2014 21:00	0.0	0	0	0	0	0
09/01/2014 22:00	0.0	0	0	0	0	0
09/01/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/02/2014 00:00	0.0	0	0	0	0	0
09/02/2014 01:00	0.0	0	0	0	0	0
09/02/2014 02:00	0.0	0	0	0	0	0
09/02/2014 03:00	0.0	0	0	0	0	0
09/02/2014 04:00	0.0	0	0	0	0	0
09/02/2014 05:00	0.0	0	0	0	0	0
09/02/2014 06:00	0.0	0	0	0	0	0
09/02/2014 07:00	0.0	0	0	0	0	0
09/02/2014 08:00	0.0	0	0	0	0	0
09/02/2014 09:00	0.0	0	0	0	0	0
09/02/2014 10:00	0.0	0	0	0	0	0
09/02/2014 11:00	0.0	0	0	0	0	0
09/02/2014 12:00	0.0	0	0	0	0	0
09/02/2014 13:00	0.0	0	0	0	0	0
09/02/2014 14:00	0.0	0	0	0	0	0
09/02/2014 15:00	0.0	0	0	0	0	0
09/02/2014 16:00	0.0	0	0	0	0	0
09/02/2014 17:00	0.0	0	0	0	0	0
09/02/2014 18:00	0.0	0	0	0	0	0
09/02/2014 19:00	0.0	0	0	0	0	0
09/02/2014 20:00	0.0	0	0	0	0	0
09/02/2014 21:00	0.0	0	0	0	0	0
09/02/2014 22:00	0.0	0	0	0	0	0
09/02/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/03/2014 00:00	0.0	0	0	0	0	0
09/03/2014 01:00	0.0	0	0	0	0	0
09/03/2014 02:00	0.0	0	0	0	0	0
09/03/2014 03:00	0.0	0	0	0	0	0
09/03/2014 04:00	0.0	0	0	0	0	0
09/03/2014 05:00	0.0	0	0	0	0	0
09/03/2014 06:00	0.0	0	0	0	0	0
09/03/2014 07:00	0.0	0	0	0	0	0
09/03/2014 08:00	0.0	0	0	0	0	0
09/03/2014 09:00	0.0	0	0	0	0	0
09/03/2014 10:00	0.0	0	0	0	0	0
09/03/2014 11:00	0.0	0	0	0	0	0
09/03/2014 12:00	0.0	0	0	0	0	0
09/03/2014 13:00	0.0	0	0	0	0	0
09/03/2014 14:00	0.0	0	0	0	0	0
09/03/2014 15:00	0.0	0	0	0	0	0
09/03/2014 16:00	0.0	0	0	0	0	0
09/03/2014 17:00	0.0	0	0	0	0	0
09/03/2014 18:00	0.0	0	0	0	0	0
09/03/2014 19:00	0.0	0	0	0	0	0
09/03/2014 20:00	0.0	0	0	0	0	0
09/03/2014 21:00	0.0	0	0	0	0	0
09/03/2014 22:00	0.0	0	0	0	0	0
09/03/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/04/2014 00:00	0.0	0	0	0	0	0
09/04/2014 01:00	0.0	0	0	0	0	0
09/04/2014 02:00	0.0	0	0	0	0	0
09/04/2014 03:00	0.0	0	0	0	0	0
09/04/2014 04:00	0.0	0	0	0	0	0
09/04/2014 05:00	0.0	0	0	0	0	0
09/04/2014 06:00	0.0	0	0	0	0	0
09/04/2014 07:00	0.0	0	0	0	0	0
09/04/2014 08:00	0.0	0	0	0	0	0
09/04/2014 09:00	0.0	0	0	0	0	0
09/04/2014 10:00	0.0	0	0	0	0	0
09/04/2014 11:00	0.0	0	0	0	0	0
09/04/2014 12:00	0.0	0	0	0	0	0
09/04/2014 13:00	0.0	0	0	0	0	0
09/04/2014 14:00	0.0	0	0	0	0	0
09/04/2014 15:00	0.0	0	0	0	0	0
09/04/2014 16:00	0.0	0	0	0	0	0
09/04/2014 17:00	0.0	0	0	0	0	0
09/04/2014 18:00	0.0	0	0	0	0	0
09/04/2014 19:00	0.0	0	0	0	0	0
09/04/2014 20:00	0.0	0	0	0	0	0
09/04/2014 21:00	0.0	0	0	0	0	0
09/04/2014 22:00	0.0	0	0	0	0	0
09/04/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/05/2014 00:00	0.0	0	0	0	0	0
09/05/2014 01:00	0.0	0	0	0	0	0
09/05/2014 02:00	0.0	0	0	0	0	0
09/05/2014 03:00	0.0	0	0	0	0	0
09/05/2014 04:00	0.0	0	0	0	0	0
09/05/2014 05:00	0.0	0	0	0	0	0
09/05/2014 06:00	0.0	0	0	0	0	0
09/05/2014 07:00	3,390.0	1	0	0	0	0
09/05/2014 08:00	6,977.5	1	0	0	0	0
09/05/2014 09:00	0.0	0	0	0	0	1
09/05/2014 10:00	0.0	0	0	0	0	1
09/05/2014 11:00	0.0	0	0	0	0	1
09/05/2014 12:00	0.0	0	0	0	0	1
09/05/2014 13:00	0.0	0	0	0	0	1
09/05/2014 14:00	0.0	0	0	0	0	1
09/05/2014 15:00	0.0	0	0	0	0	1
09/05/2014 16:00	0.0	0	0	0	0	1
09/05/2014 17:00	0.0	0	0	0	0	1
09/05/2014 18:00	0.0	0	0	0	0	1
09/05/2014 19:00	0.0	0	0	0	0	1
09/05/2014 20:00	0.0	0	0	0	0	1
09/05/2014 21:00	0.0	0	0	0	0	1
09/05/2014 22:00	0.0	0	0	0	0	1
09/05/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	10,367.5 #	2 #	0 #	0 #	0 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,977.5	1	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/06/2014 00:00	0.0	0	0	0	0	1
09/06/2014 01:00	0.0	0	0	0	0	1
09/06/2014 02:00	0.0	0	0	0	0	1
09/06/2014 03:00	0.0	0	0	0	0	1
09/06/2014 04:00	0.0	0	0	0	0	1
09/06/2014 05:00	0.0	0	0	0	0	1
09/06/2014 06:00	0.0	0	0	0	0	1
09/06/2014 07:00	0.0	0	0	0	0	1
09/06/2014 08:00	0.0	0	0	0	0	1
09/06/2014 09:00	0.0	0	0	0	0	1
09/06/2014 10:00	0.0	0	0	0	0	1
09/06/2014 11:00	0.0	0	0	0	0	1
09/06/2014 12:00	0.0	0	0	0	0	1
09/06/2014 13:00	0.0	0	0	0	0	1
09/06/2014 14:00	0.0	0	0	0	0	1
09/06/2014 15:00	0.0	0	0	0	0	1
09/06/2014 16:00	0.0	0	0	0	0	1
09/06/2014 17:00	0.0	0	0	0	0	1
09/06/2014 18:00	0.0	0	0	0	0	1
09/06/2014 19:00	0.0	0	0	0	0	1
09/06/2014 20:00	0.0	0	0	0	0	1
09/06/2014 21:00	0.0	0	0	0	0	1
09/06/2014 22:00	0.0	0	0	0	0	1
09/06/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/07/2014 00:00	0.0	0	0	0	0	1
09/07/2014 01:00	0.0	0	0	0	0	1
09/07/2014 02:00	0.0	0	0	0	0	1
09/07/2014 03:00	0.0	0	0	0	0	1
09/07/2014 04:00	0.0	0	0	0	0	1
09/07/2014 05:00	0.0	0	0	0	0	1
09/07/2014 06:00	0.0	0	0	0	0	1
09/07/2014 07:00	0.0	0	0	0	0	1
09/07/2014 08:00	0.0	0	0	0	0	1
09/07/2014 09:00	0.0	0	0	0	0	1
09/07/2014 10:00	0.0	0	0	0	0	1
09/07/2014 11:00	0.0	0	0	0	0	1
09/07/2014 12:00	0.0	0	0	0	0	1
09/07/2014 13:00	0.0	0	0	0	0	1
09/07/2014 14:00	0.0	0	0	0	0	1
09/07/2014 15:00	0.0	0	0	0	0	1
09/07/2014 16:00	0.0	0	0	0	0	1
09/07/2014 17:00	0.0	0	0	0	0	1
09/07/2014 18:00	0.0	0	0	0	0	1
09/07/2014 19:00	0.0	0	0	0	0	1
09/07/2014 20:00	0.0	0	0	0	0	1
09/07/2014 21:00	0.0	0	0	0	0	1
09/07/2014 22:00	0.0	0	0	0	0	1
09/07/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/08/2014 00:00	0.0	0	0	0	0	1
09/08/2014 01:00	0.0	0	0	0	0	1
09/08/2014 02:00	0.0	0	0	0	0	1
09/08/2014 03:00	0.0	0	0	0	0	1
09/08/2014 04:00	0.0	0	0	0	0	1
09/08/2014 05:00	0.0	0	0	0	0	1
09/08/2014 06:00	0.0	0	0	0	0	1
09/08/2014 07:00	0.0	0	0	0	0	1
09/08/2014 08:00	0.0	0	0	0	0	1
09/08/2014 09:00	0.0	0	0	0	0	1
09/08/2014 10:00	0.0	0	0	0	0	1
09/08/2014 11:00	0.0	0	0	0	0	1
09/08/2014 12:00	0.0	0	0	0	0	1
09/08/2014 13:00	0.0	0	0	0	0	1
09/08/2014 14:00	0.0	0	0	0	0	1
09/08/2014 15:00	0.0	0	0	0	0	1
09/08/2014 16:00	0.0	0	0	0	0	1
09/08/2014 17:00	0.0	0	0	0	0	1
09/08/2014 18:00	0.0	0	0	0	0	1
09/08/2014 19:00	0.0	0	0	0	0	1
09/08/2014 20:00	0.0	0	0	0	0	1
09/08/2014 21:00	0.0	0	0	0	0	1
09/08/2014 22:00	0.0	0	0	0	0	1
09/08/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/09/2014 00:00	0.0	0	0	0	0	1
09/09/2014 01:00	0.0	0	0	0	0	1
09/09/2014 02:00	0.0	0	0	0	0	1
09/09/2014 03:00	0.0	0	0	0	0	1
09/09/2014 04:00	0.0	0	0	0	0	1
09/09/2014 05:00	0.0	0	0	0	0	1
09/09/2014 06:00	0.0	0	0	0	0	1
09/09/2014 07:00	0.0	0	0	0	0	1
09/09/2014 08:00	0.0	0	0	0	0	1
09/09/2014 09:00	0.0	0	0	0	0	1
09/09/2014 10:00	0.0	0	0	0	0	1
09/09/2014 11:00	0.0	0	0	0	0	1
09/09/2014 12:00	0.0	0	0	0	0	1
09/09/2014 13:00	0.0	0	0	0	0	1
09/09/2014 14:00	0.0	0	0	0	0	1
09/09/2014 15:00	0.0	0	0	0	0	1
09/09/2014 16:00	0.0	0	0	0	0	1
09/09/2014 17:00	0.0	0	0	0	0	1
09/09/2014 18:00	0.0	0	0	0	0	1
09/09/2014 19:00	0.0	0	0	0	0	1
09/09/2014 20:00	0.0	0	0	0	0	1
09/09/2014 21:00	0.0	0	0	0	0	1
09/09/2014 22:00	0.0	0	0	0	0	1
09/09/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/10/2014 00:00	0.0	0	0	0	0	1
09/10/2014 01:00	0.0	0	0	0	0	1
09/10/2014 02:00	0.0	0	0	0	0	1
09/10/2014 03:00	0.0	0	0	0	0	1
09/10/2014 04:00	0.0	0	0	0	0	1
09/10/2014 05:00	0.0	0	0	0	0	1
09/10/2014 06:00	0.0	0	0	0	0	1
09/10/2014 07:00	0.0	0	0	0	0	1
09/10/2014 08:00	0.0	0	0	0	0	1
09/10/2014 09:00	0.0	0	0	0	0	1
09/10/2014 10:00	0.0	0	0	0	0	1
09/10/2014 11:00	0.0	0	0	0	0	1
09/10/2014 12:00	0.0	0	0	0	0	1
09/10/2014 13:00	0.0	0	0	0	0	1
09/10/2014 14:00	0.0	0	0	0	0	1
09/10/2014 15:00	0.0	0	0	0	0	1
09/10/2014 16:00	0.0	0	0	0	0	1
09/10/2014 17:00	0.0	0	0	0	0	1
09/10/2014 18:00	0.0	0	0	0	0	1
09/10/2014 19:00	0.0	0	0	0	0	1
09/10/2014 20:00	0.0	0	0	0	0	1
09/10/2014 21:00	0.0	0	0	0	0	1
09/10/2014 22:00	0.0	0	0	0	0	1
09/10/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/11/2014 00:00	0.0	0	0	0	0	1
09/11/2014 01:00	0.0	0	0	0	0	1
09/11/2014 02:00	0.0	0	0	0	0	1
09/11/2014 03:00	0.0	0	0	0	0	1
09/11/2014 04:00	0.0	0	0	0	0	1
09/11/2014 05:00	0.0	0	0	0	0	1
09/11/2014 06:00	0.0	0	0	0	0	1
09/11/2014 07:00	0.0	0	0	0	0	1
09/11/2014 08:00	0.0	0	0	0	0	1
09/11/2014 09:00	0.0	0	0	0	0	1
09/11/2014 10:00	0.0	0	0	0	0	1
09/11/2014 11:00	0.0	0	0	0	0	1
09/11/2014 12:00	0.0	0	0	0	0	1
09/11/2014 13:00	0.0	0	0	0	0	1
09/11/2014 14:00	0.0	0	0	0	0	1
09/11/2014 15:00	0.0	0	0	0	0	1
09/11/2014 16:00	0.0	0	0	0	0	1
09/11/2014 17:00	0.0	0	0	0	0	1
09/11/2014 18:00	0.0	0	0	0	0	1
09/11/2014 19:00	0.0	0	0	0	0	1
09/11/2014 20:00	0.0	0	0	0	0	1
09/11/2014 21:00	0.0	0	0	0	0	1
09/11/2014 22:00	0.0	0	0	0	0	1
09/11/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/12/2014 00:00	0.0	0	0	0	0	1
09/12/2014 01:00	0.0	0	0	0	0	1
09/12/2014 02:00	0.0	0	0	0	0	1
09/12/2014 03:00	0.0	0	0	0	0	1
09/12/2014 04:00	0.0	0	0	0	0	1
09/12/2014 05:00	0.0	0	0	0	0	1
09/12/2014 06:00	0.0	0	0	0	0	1
09/12/2014 07:00	0.0	0	0	0	0	1
09/12/2014 08:00	0.0	0	0	0	0	1
09/12/2014 09:00	0.0	0	0	0	0	1
09/12/2014 10:00	0.0	0	0	0	0	1
09/12/2014 11:00	0.0	0	0	0	0	1
09/12/2014 12:00	0.0	0	0	0	0	1
09/12/2014 13:00	0.0	0	0	0	0	1
09/12/2014 14:00	0.0	0	0	0	0	1
09/12/2014 15:00	0.0	0	0	0	0	1
09/12/2014 16:00	0.0	0	0	0	0	1
09/12/2014 17:00	0.0	0	0	0	0	1
09/12/2014 18:00	0.0	0	0	0	0	1
09/12/2014 19:00	0.0	0	0	0	0	1
09/12/2014 20:00	0.0	0	0	0	0	1
09/12/2014 21:00	0.0	0	0	0	0	1
09/12/2014 22:00	0.0	0	0	0	0	1
09/12/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/13/2014 00:00	0.0	0	0	0	0	1
09/13/2014 01:00	0.0	0	0	0	0	1
09/13/2014 02:00	0.0	0	0	0	0	1
09/13/2014 03:00	0.0	0	0	0	0	1
09/13/2014 04:00	0.0	0	0	0	0	1
09/13/2014 05:00	0.0	0	0	0	0	1
09/13/2014 06:00	0.0	0	0	0	0	1
09/13/2014 07:00	0.0	0	0	0	0	1
09/13/2014 08:00	0.0	0	0	0	0	1
09/13/2014 09:00	0.0	0	0	0	0	1
09/13/2014 10:00	0.0	0	0	0	0	1
09/13/2014 11:00	0.0	0	0	0	0	1
09/13/2014 12:00	0.0	0	0	0	0	1
09/13/2014 13:00	0.0	0	0	0	0	1
09/13/2014 14:00	0.0	0	0	0	0	1
09/13/2014 15:00	0.0	0	0	0	0	1
09/13/2014 16:00	0.0	0	0	0	0	1
09/13/2014 17:00	0.0	0	0	0	0	1
09/13/2014 18:00	0.0	0	0	0	0	1
09/13/2014 19:00	0.0	0	0	0	0	1
09/13/2014 20:00	0.0	0	0	0	0	1
09/13/2014 21:00	0.0	0	0	0	0	1
09/13/2014 22:00	0.0	0	0	0	0	1
09/13/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/14/2014 00:00	0.0	0	0	0	0	1
09/14/2014 01:00	0.0	0	0	0	0	1
09/14/2014 02:00	0.0	0	0	0	0	1
09/14/2014 03:00	0.0	0	0	0	0	1
09/14/2014 04:00	0.0	0	0	0	0	1
09/14/2014 05:00	0.0	0	0	0	0	1
09/14/2014 06:00	0.0	0	0	0	0	1
09/14/2014 07:00	0.0	0	0	0	0	1
09/14/2014 08:00	0.0	0	0	0	0	1
09/14/2014 09:00	0.0	0	0	0	0	1
09/14/2014 10:00	0.0	0	0	0	0	1
09/14/2014 11:00	0.0	0	0	0	0	1
09/14/2014 12:00	0.0	0	0	0	0	1
09/14/2014 13:00	0.0	0	0	0	0	1
09/14/2014 14:00	0.0	0	0	0	0	1
09/14/2014 15:00	0.0	0	0	0	0	1
09/14/2014 16:00	0.0	0	0	0	0	1
09/14/2014 17:00	0.0	0	0	0	0	1
09/14/2014 18:00	0.0	0	0	0	0	1
09/14/2014 19:00	0.0	0	0	0	0	1
09/14/2014 20:00	0.0	0	0	0	0	1
09/14/2014 21:00	0.0	0	0	0	0	1
09/14/2014 22:00	0.0	0	0	0	0	1
09/14/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/15/2014 00:00	0.0	0	0	0	0	1
09/15/2014 01:00	0.0	0	0	0	0	1
09/15/2014 02:00	0.0	0	0	0	0	1
09/15/2014 03:00	0.0	0	0	0	0	1
09/15/2014 04:00	0.0	0	0	0	0	1
09/15/2014 05:00	0.0	0	0	0	0	1
09/15/2014 06:00	0.0	0	0	0	0	1
09/15/2014 07:00	0.0	0	0	0	0	1
09/15/2014 08:00	0.0	0	0	0	0	1
09/15/2014 09:00	0.0	0	0	0	0	1
09/15/2014 10:00	0.0	0	0	0	0	1
09/15/2014 11:00	0.0	0	0	0	0	1
09/15/2014 12:00	0.0	0	0	0	0	1
09/15/2014 13:00	0.0	0	0	0	0	1
09/15/2014 14:00	0.0	0	0	0	0	1
09/15/2014 15:00	0.0	0	0	0	0	1
09/15/2014 16:00	0.0	0	0	0	0	1
09/15/2014 17:00	0.0	0	0	0	0	1
09/15/2014 18:00	0.0	0	0	0	0	1
09/15/2014 19:00	0.0	0	0	0	0	1
09/15/2014 20:00	0.0	0	0	0	0	1
09/15/2014 21:00	0.0	0	0	0	0	1
09/15/2014 22:00	0.0	0	0	0	0	1
09/15/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/16/2014 00:00	0.0	0	0	0	0	1
09/16/2014 01:00	0.0	0	0	0	0	1
09/16/2014 02:00	0.0	0	0	0	0	1
09/16/2014 03:00	0.0	0	0	0	0	1
09/16/2014 04:00	0.0	0	0	0	0	1
09/16/2014 05:00	0.0	0	0	0	0	1
09/16/2014 06:00	0.0	0	0	0	0	1
09/16/2014 07:00	0.0	0	0	0	0	1
09/16/2014 08:00	0.0	0	0	0	0	1
09/16/2014 09:00	0.0	0	0	0	0	1
09/16/2014 10:00	0.0	0	0	0	0	1
09/16/2014 11:00	0.0	0	0	0	0	1
09/16/2014 12:00	0.0	0	0	0	0	1
09/16/2014 13:00	0.0	0	0	0	0	1
09/16/2014 14:00	0.0	0	0	0	0	1
09/16/2014 15:00	0.0	0	0	0	0	1
09/16/2014 16:00	0.0	0	0	0	0	1
09/16/2014 17:00	0.0	0	0	0	0	1
09/16/2014 18:00	0.0	0	0	0	0	1
09/16/2014 19:00	0.0	0	0	0	0	1
09/16/2014 20:00	0.0	0	0	0	0	1
09/16/2014 21:00	0.0	0	0	0	0	1
09/16/2014 22:00	0.0	0	0	0	0	1
09/16/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/17/2014 00:00	0.0	0	0	0	0	1
09/17/2014 01:00	0.0	0	0	0	0	1
09/17/2014 02:00	0.0	0	0	0	0	1
09/17/2014 03:00	0.0	0	0	0	0	1
09/17/2014 04:00	0.0	0	0	0	0	1
09/17/2014 05:00	0.0	0	0	0	0	1
09/17/2014 06:00	0.0	0	0	0	0	1
09/17/2014 07:00	0.0	0	0	0	0	1
09/17/2014 08:00	0.0	0	0	0	0	1
09/17/2014 09:00	0.0	0	0	0	0	1
09/17/2014 10:00	0.0	0	0	0	0	1
09/17/2014 11:00	0.0	0	0	0	0	1
09/17/2014 12:00	0.0	0	0	0	0	1
09/17/2014 13:00	0.0	0	0	0	0	1
09/17/2014 14:00	0.0	0	0	0	0	1
09/17/2014 15:00	0.0	0	0	0	0	1
09/17/2014 16:00	0.0	0	0	0	0	1
09/17/2014 17:00	0.0	0	0	0	0	1
09/17/2014 18:00	0.0	0	0	0	0	1
09/17/2014 19:00	0.0	0	0	0	0	1
09/17/2014 20:00	0.0	0	0	0	0	1
09/17/2014 21:00	0.0	0	0	0	0	1
09/17/2014 22:00	0.0	0	0	0	0	1
09/17/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/18/2014 00:00	0.0	0	0	0	0	1
09/18/2014 01:00	0.0	0	0	0	0	1
09/18/2014 02:00	0.0	0	0	0	0	1
09/18/2014 03:00	0.0	0	0	0	0	1
09/18/2014 04:00	0.0	0	0	0	0	1
09/18/2014 05:00	0.0	0	0	0	0	1
09/18/2014 06:00	0.0	0	0	0	0	1
09/18/2014 07:00	0.0	0	0	0	0	1
09/18/2014 08:00	0.0	0	0	0	0	1
09/18/2014 09:00	0.0	0	0	0	0	1
09/18/2014 10:00	0.0	0	0	0	0	1
09/18/2014 11:00	0.0	0	0	0	0	1
09/18/2014 12:00	0.0	0	0	0	0	1
09/18/2014 13:00	0.0	0	0	0	0	1
09/18/2014 14:00	0.0	0	0	0	0	1
09/18/2014 15:00	0.0	0	0	0	0	1
09/18/2014 16:00	0.0	0	0	0	0	1
09/18/2014 17:00	0.0	0	0	0	0	1
09/18/2014 18:00	0.0	0	0	0	0	1
09/18/2014 19:00	0.0	0	0	0	0	1
09/18/2014 20:00	0.0	0	0	0	0	1
09/18/2014 21:00	0.0	0	0	0	0	1
09/18/2014 22:00	0.0	0	0	0	0	1
09/18/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/19/2014 00:00	0.0	0	0	0	0	1
09/19/2014 01:00	0.0	0	0	0	0	1
09/19/2014 02:00	0.0	0	0	0	0	1
09/19/2014 03:00	0.0	0	0	0	0	1
09/19/2014 04:00	0.0	0	0	0	0	1
09/19/2014 05:00	0.0	0	0	0	0	1
09/19/2014 06:00	0.0	0	0	0	0	1
09/19/2014 07:00	0.0	0	0	0	0	1
09/19/2014 08:00	0.0	0	0	0	0	1
09/19/2014 09:00	0.0	0	0	0	0	1
09/19/2014 10:00	0.0	0	0	0	0	1
09/19/2014 11:00	0.0	0	0	0	0	1
09/19/2014 12:00	0.0	0	0	0	0	1
09/19/2014 13:00	0.0	0	0	0	0	1
09/19/2014 14:00	0.0	0	0	0	0	1
09/19/2014 15:00	0.0	0	0	0	0	1
09/19/2014 16:00	0.0	0	0	0	0	1
09/19/2014 17:00	0.0	0	0	0	0	1
09/19/2014 18:00	0.0	0	0	0	0	1
09/19/2014 19:00	0.0	0	0	0	0	1
09/19/2014 20:00	0.0	0	0	0	0	1
09/19/2014 21:00	0.0	0	0	0	0	1
09/19/2014 22:00	0.0	0	0	0	0	1
09/19/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/20/2014 00:00	0.0	0	0	0	0	1
09/20/2014 01:00	0.0	0	0	0	0	1
09/20/2014 02:00	0.0	0	0	0	0	1
09/20/2014 03:00	0.0	0	0	0	0	1
09/20/2014 04:00	0.0	0	0	0	0	1
09/20/2014 05:00	0.0	0	0	0	0	1
09/20/2014 06:00	0.0	0	0	0	0	1
09/20/2014 07:00	0.0	0	0	0	0	1
09/20/2014 08:00	0.0	0	0	0	0	1
09/20/2014 09:00	0.0	0	0	0	0	1
09/20/2014 10:00	0.0	0	0	0	0	1
09/20/2014 11:00	0.0	0	0	0	0	1
09/20/2014 12:00	0.0	0	0	0	0	1
09/20/2014 13:00	0.0	0	0	0	0	1
09/20/2014 14:00	0.0	0	0	0	0	1
09/20/2014 15:00	0.0	0	0	0	0	1
09/20/2014 16:00	0.0	0	0	0	0	1
09/20/2014 17:00	0.0	0	0	0	0	1
09/20/2014 18:00	0.0	0	0	0	0	1
09/20/2014 19:00	0.0	0	0	0	0	1
09/20/2014 20:00	0.0	0	0	0	0	1
09/20/2014 21:00	0.0	0	0	0	0	1
09/20/2014 22:00	0.0	0	0	0	0	1
09/20/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/21/2014 00:00	0.0	0	0	0	0	1
09/21/2014 01:00	0.0	0	0	0	0	1
09/21/2014 02:00	0.0	0	0	0	0	1
09/21/2014 03:00	0.0	0	0	0	0	1
09/21/2014 04:00	0.0	0	0	0	0	1
09/21/2014 05:00	0.0	0	0	0	0	1
09/21/2014 06:00	0.0	0	0	0	0	1
09/21/2014 07:00	0.0	0	0	0	0	1
09/21/2014 08:00	0.0	0	0	0	0	1
09/21/2014 09:00	0.0	0	0	0	0	1
09/21/2014 10:00	0.0	0	0	0	0	1
09/21/2014 11:00	0.0	0	0	0	0	1
09/21/2014 12:00	0.0	0	0	0	0	1
09/21/2014 13:00	0.0	0	0	0	0	1
09/21/2014 14:00	0.0	0	0	0	0	1
09/21/2014 15:00	0.0	0	0	0	0	1
09/21/2014 16:00	0.0	0	0	0	0	1
09/21/2014 17:00	0.0	0	0	0	0	1
09/21/2014 18:00	0.0	0	0	0	0	1
09/21/2014 19:00	0.0	0	0	0	0	1
09/21/2014 20:00	0.0	0	0	0	0	1
09/21/2014 21:00	0.0	0	0	0	0	1
09/21/2014 22:00	0.0	0	0	0	0	1
09/21/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/22/2014 00:00	0.0	0	0	0	0	1
09/22/2014 01:00	0.0	0	0	0	0	1
09/22/2014 02:00	0.0	0	0	0	0	1
09/22/2014 03:00	0.0	0	0	0	0	1
09/22/2014 04:00	0.0	0	0	0	0	1
09/22/2014 05:00	0.0	0	0	0	0	1
09/22/2014 06:00	0.0	0	0	0	0	1
09/22/2014 07:00	0.0	0	0	0	0	1
09/22/2014 08:00	0.0	0	0	0	0	1
09/22/2014 09:00	0.0	0	0	0	0	1
09/22/2014 10:00	0.0	0	0	0	0	1
09/22/2014 11:00	0.0	0	0	0	0	1
09/22/2014 12:00	0.0	0	0	0	0	1
09/22/2014 13:00	0.0	0	0	0	0	1
09/22/2014 14:00	0.0	0	0	0	0	1
09/22/2014 15:00	0.0	0	0	0	0	1
09/22/2014 16:00	0.0	0	0	0	0	1
09/22/2014 17:00	0.0	0	0	0	0	1
09/22/2014 18:00	0.0	0	0	0	0	1
09/22/2014 19:00	0.0	0	0	0	0	1
09/22/2014 20:00	0.0	0	0	0	0	1
09/22/2014 21:00	0.0	0	0	0	0	1
09/22/2014 22:00	0.0	0	0	0	0	1
09/22/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/23/2014 00:00	0.0	0	0	0	0	1
09/23/2014 01:00	0.0	0	0	0	0	1
09/23/2014 02:00	0.0	0	0	0	0	1
09/23/2014 03:00	0.0	0	0	0	0	1
09/23/2014 04:00	0.0	0	0	0	0	1
09/23/2014 05:00	0.0	0	0	0	0	1
09/23/2014 06:00	0.0	0	0	0	0	1
09/23/2014 07:00	0.0	0	0	0	0	1
09/23/2014 08:00	0.0	0	0	0	0	1
09/23/2014 09:00	0.0	0	0	0	0	1
09/23/2014 10:00	0.0	0	0	0	0	1
09/23/2014 11:00	0.0	0	0	0	0	1
09/23/2014 12:00	0.0	0	0	0	0	1
09/23/2014 13:00	0.0	0	0	0	0	1
09/23/2014 14:00	0.0	0	0	0	0	1
09/23/2014 15:00	0.0	0	0	0	0	1
09/23/2014 16:00	0.0	0	0	0	0	1
09/23/2014 17:00	0.0	0	0	0	0	1
09/23/2014 18:00	0.0	0	0	0	0	1
09/23/2014 19:00	0.0	0	0	0	0	1
09/23/2014 20:00	0.0	0	0	0	0	1
09/23/2014 21:00	0.0	0	0	0	0	1
09/23/2014 22:00	0.0	0	0	0	0	1
09/23/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/24/2014 00:00	0.0	0	0	0	0	1
09/24/2014 01:00	0.0	0	0	0	0	1
09/24/2014 02:00	0.0	0	0	0	0	1
09/24/2014 03:00	0.0	0	0	0	0	1
09/24/2014 04:00	0.0	0	0	0	0	1
09/24/2014 05:00	0.0	0	0	0	0	1
09/24/2014 06:00	0.0	0	0	0	0	1
09/24/2014 07:00	0.0	0	0	0	0	1
09/24/2014 08:00	0.0	0	0	0	0	1
09/24/2014 09:00	0.0	0	0	0	0	1
09/24/2014 10:00	0.0	0	0	0	0	1
09/24/2014 11:00	0.0	0	0	0	0	1
09/24/2014 12:00	0.0	0	0	0	0	1
09/24/2014 13:00	0.0	0	0	0	0	1
09/24/2014 14:00	0.0	0	0	0	0	1
09/24/2014 15:00	0.0	0	0	0	0	1
09/24/2014 16:00	0.0	0	0	0	0	1
09/24/2014 17:00	0.0	0	0	0	0	1
09/24/2014 18:00	0.0	0	0	0	0	1
09/24/2014 19:00	0.0	0	0	0	0	1
09/24/2014 20:00	0.0	0	0	0	0	1
09/24/2014 21:00	0.0	0	0	0	0	1
09/24/2014 22:00	0.0	0	0	0	0	1
09/24/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/25/2014 00:00	0.0	0	0	0	0	1
09/25/2014 01:00	0.0	0	0	0	0	1
09/25/2014 02:00	0.0	0	0	0	0	1
09/25/2014 03:00	0.0	0	0	0	0	1
09/25/2014 04:00	0.0	0	0	0	0	1
09/25/2014 05:00	0.0	0	0	0	0	1
09/25/2014 06:00	0.0	0	0	0	0	1
09/25/2014 07:00	0.0	0	0	0	0	1
09/25/2014 08:00	0.0	0	0	0	0	1
09/25/2014 09:00	0.0	0	0	0	0	1
09/25/2014 10:00	0.0	0	0	0	0	1
09/25/2014 11:00	0.0	0	0	0	0	1
09/25/2014 12:00	0.0	0	0	0	0	1
09/25/2014 13:00	0.0	0	0	0	0	1
09/25/2014 14:00	0.0	0	0	0	0	1
09/25/2014 15:00	0.0	0	0	0	0	1
09/25/2014 16:00	0.0	0	0	0	0	1
09/25/2014 17:00	0.0	0	0	0	0	1
09/25/2014 18:00	0.0	0	0	0	0	1
09/25/2014 19:00	0.0	0	0	0	0	1
09/25/2014 20:00	0.0	0	0	0	0	1
09/25/2014 21:00	0.0	0	0	0	0	1
09/25/2014 22:00	0.0	0	0	0	0	1
09/25/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/26/2014 00:00	0.0	0	0	0	0	1
09/26/2014 01:00	0.0	0	0	0	0	1
09/26/2014 02:00	0.0	0	0	0	0	1
09/26/2014 03:00	0.0	0	0	0	0	1
09/26/2014 04:00	0.0	0	0	0	0	1
09/26/2014 05:00	0.0	0	0	0	0	1
09/26/2014 06:00	0.0	0	0	0	0	1
09/26/2014 07:00	0.0	0	0	0	0	1
09/26/2014 08:00	0.0	0	0	0	0	1
09/26/2014 09:00	0.0	0	0	0	0	1
09/26/2014 10:00	0.0	0	0	0	0	1
09/26/2014 11:00	0.0	0	0	0	0	1
09/26/2014 12:00	0.0	0	0	0	0	1
09/26/2014 13:00	0.0	0	0	0	0	1
09/26/2014 14:00	0.0	0	0	0	0	1
09/26/2014 15:00	0.0	0	0	0	0	1
09/26/2014 16:00	0.0	0	0	0	0	1
09/26/2014 17:00	0.0	0	0	0	0	1
09/26/2014 18:00	0.0	0	0	0	0	1
09/26/2014 19:00	0.0	0	0	0	0	1
09/26/2014 20:00	0.0	0	0	0	0	1
09/26/2014 21:00	0.0	0	0	0	0	1
09/26/2014 22:00	0.0	0	0	0	0	1
09/26/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/27/2014 00:00	0.0	0	0	0	0	1
09/27/2014 01:00	0.0	0	0	0	0	1
09/27/2014 02:00	0.0	0	0	0	0	1
09/27/2014 03:00	0.0	0	0	0	0	1
09/27/2014 04:00	0.0	0	0	0	0	1
09/27/2014 05:00	0.0	0	0	0	0	1
09/27/2014 06:00	0.0	0	0	0	0	1
09/27/2014 07:00	0.0	0	0	0	0	1
09/27/2014 08:00	0.0	0	0	0	0	1
09/27/2014 09:00	0.0	0	0	0	0	1
09/27/2014 10:00	0.0	0	0	0	0	1
09/27/2014 11:00	0.0	0	0	0	0	1
09/27/2014 12:00	0.0	0	0	0	0	1
09/27/2014 13:00	0.0	0	0	0	0	1
09/27/2014 14:00	0.0	0	0	0	0	1
09/27/2014 15:00	0.0	0	0	0	0	1
09/27/2014 16:00	0.0	0	0	0	0	1
09/27/2014 17:00	0.0	0	0	0	0	1
09/27/2014 18:00	0.0	0	0	0	0	1
09/27/2014 19:00	0.0	0	0	0	0	1
09/27/2014 20:00	0.0	0	0	0	0	1
09/27/2014 21:00	0.0	0	0	0	0	1
09/27/2014 22:00	0.0	0	0	0	0	1
09/27/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/28/2014 00:00	0.0	0	0	0	0	1
09/28/2014 01:00	0.0	0	0	0	0	1
09/28/2014 02:00	0.0	0	0	0	0	1
09/28/2014 03:00	0.0	0	0	0	0	1
09/28/2014 04:00	0.0	0	0	0	0	1
09/28/2014 05:00	0.0	0	0	0	0	1
09/28/2014 06:00	0.0	0	0	0	0	1
09/28/2014 07:00	0.0	0	0	0	0	1
09/28/2014 08:00	0.0	0	0	0	0	1
09/28/2014 09:00	0.0	0	0	0	0	1
09/28/2014 10:00	0.0	0	0	0	0	1
09/28/2014 11:00	0.0	0	0	0	0	1
09/28/2014 12:00	0.0	0	0	0	0	1
09/28/2014 13:00	0.0	0	0	0	0	1
09/28/2014 14:00	0.0	0	0	0	0	1
09/28/2014 15:00	0.0	0	0	0	0	1
09/28/2014 16:00	0.0	0	0	0	0	1
09/28/2014 17:00	0.0	0	0	0	0	1
09/28/2014 18:00	0.0	0	0	0	0	1
09/28/2014 19:00	0.0	0	0	0	0	1
09/28/2014 20:00	0.0	0	0	0	0	1
09/28/2014 21:00	0.0	0	0	0	0	1
09/28/2014 22:00	0.0	0	0	0	0	1
09/28/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/29/2014 00:00	0.0	0	0	0	0	1
09/29/2014 01:00	0.0	0	0	0	0	1
09/29/2014 02:00	0.0	0	0	0	0	1
09/29/2014 03:00	0.0	0	0	0	0	1
09/29/2014 04:00	0.0	0	0	0	0	1
09/29/2014 05:00	0.0	0	0	0	0	1
09/29/2014 06:00	0.0	0	0	0	0	1
09/29/2014 07:00	0.0	0	0	0	0	1
09/29/2014 08:00	0.0	0	0	0	0	1
09/29/2014 09:00	0.0	0	0	0	0	1
09/29/2014 10:00	0.0	0	0	0	0	1
09/29/2014 11:00	0.0	0	0	0	0	1
09/29/2014 12:00	0.0	0	0	0	0	1
09/29/2014 13:00	0.0	0	0	0	0	1
09/29/2014 14:00	0.0	0	0	0	0	1
09/29/2014 15:00	0.0	0	0	0	0	1
09/29/2014 16:00	0.0	0	0	0	0	1
09/29/2014 17:00	0.0	0	0	0	0	1
09/29/2014 18:00	0.0	0	0	0	0	1
09/29/2014 19:00	0.0	0	0	0	0	1
09/29/2014 20:00	0.0	0	0	0	0	1
09/29/2014 21:00	0.0	0	0	0	0	1
09/29/2014 22:00	0.0	0	0	0	0	1
09/29/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT1 Event GasFlow Total 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT1 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT1 Startup, Cold, TF 1 Hour(s)	Unit CT1 Startup, Warm, TF 1 Hour(s)	Unit CT1 Startup, Hot, TF 1 Hour(s)	Unit CT1 Shutdown, TF 1 Hour(s)	Unit CT1 NormalOp, TF 1 Hour(s)
09/30/2014 00:00	0.0	0	0	0	0	1
09/30/2014 01:00	0.0	0	0	0	0	1
09/30/2014 02:00	0.0	0	0	0	0	1
09/30/2014 03:00	0.0	0	0	0	0	1
09/30/2014 04:00	0.0	0	0	0	0	1
09/30/2014 05:00	0.0	0	0	0	0	1
09/30/2014 06:00	0.0	0	0	0	0	1
09/30/2014 07:00	0.0	0	0	0	0	1
09/30/2014 08:00	0.0	0	0	0	0	1
09/30/2014 09:00	0.0	0	0	0	0	1
09/30/2014 10:00	0.0	0	0	0	0	1
09/30/2014 11:00	0.0	0	0	0	0	1
09/30/2014 12:00	0.0	0	0	0	0	1
09/30/2014 13:00	0.0	0	0	0	0	1
09/30/2014 14:00	0.0	0	0	0	0	1
09/30/2014 15:00	0.0	0	0	0	0	1
09/30/2014 16:00	0.0	0	0	0	0	1
09/30/2014 17:00	0.0	0	0	0	0	1
09/30/2014 18:00	0.0	0	0	0	0	1
09/30/2014 19:00	0.0	0	0	0	0	1
09/30/2014 20:00	0.0	0	0	0	0	1
09/30/2014 21:00	0.0	0	0	0	0	1
09/30/2014 22:00	0.0	0	0	0	0	1
09/30/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Pound Per Event Report

CT2 - CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,541.32 Hours

Non-Operating Time: 666.68 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
07/02/2014 22:03 07/02/2014 22:10 Shut Down - Gas	8	2.0	483.5		
07/03/2014 07:18 07/03/2014 08:21 Warm Start - Gas	64	44.2	790.5		
07/04/2014 20:23 07/04/2014 20:31 Shut Down - Gas	9	2.5	483.5		
07/05/2014 10:28 07/05/2014 11:35 Warm Start - Gas	68	49.8	790.5		
07/06/2014 02:04 07/06/2014 02:13 Shut Down - Gas	10	3.7	483.5		
07/06/2014 09:44 07/06/2014 10:49 Hot Start - Gas	66	40.0	679.6		
07/11/2014 00:02 07/11/2014 00:09 Shut Down - Gas	8	3.2	483.5		
07/11/2014 09:10 07/11/2014 10:48 Warm Start - Gas	99	103.9	790.5		
07/12/2014 00:06 07/12/2014 00:13 Shut Down - Gas	8	4.2	483.5		
07/12/2014 06:29 07/12/2014 07:41 Hot Start - Gas	73	74.8	679.6		
07/13/2014 01:06 07/13/2014 01:13 Shut Down - Gas	8	2.8	483.5		
07/13/2014 10:35 07/13/2014 11:37 Warm Start - Gas	63	51.7	790.5		
07/17/2014 00:06 07/17/2014 00:13 Shut Down - Gas	8	2.3	483.5		

Pound Per Event Report

CT2 - CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,541.32 Hours

Non-Operating Time: 666.68 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
07/17/2014 04:18 07/17/2014 05:33 Hot Start - Gas	76	42.7	679.6		
07/18/2014 00:06 07/18/2014 00:13 Shut Down - Gas	8	2.2	483.5		
07/18/2014 03:18 07/18/2014 04:06 Hot Start - Gas	49	38.7	679.6		
07/19/2014 00:12 07/19/2014 00:19 Shut Down - Gas	8	2.2	483.5		
07/19/2014 09:38 07/19/2014 10:33 Warm Start - Gas	56	32.8	790.5		
07/20/2014 00:06 07/20/2014 00:13 Shut Down - Gas	8	2.6	483.5		
07/21/2014 01:18 07/21/2014 03:33 Warm Start - Gas	136	127.6	790.5		
08/07/2014 00:47 08/07/2014 00:54 Shut Down - Gas	8	2.4	483.5		
08/07/2014 07:19 08/07/2014 08:38 Hot Start - Gas	80	63.1	679.6		
08/09/2014 02:06 08/09/2014 02:14 Shut Down - Gas	9	2.7	483.5		
08/09/2014 06:18 08/09/2014 07:09 Hot Start - Gas	52	37.4	679.6		
08/10/2014 00:06 08/10/2014 00:13 Shut Down - Gas	8	2.3	483.5		
08/10/2014 07:14 08/10/2014 08:21 Hot Start - Gas	68	48.6	679.6		
08/13/2014 01:32 08/13/2014 01:41 Shut Down - Gas	10	2.3	483.5		

Pound Per Event Report

CT2 - CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,541.32 Hours

Non-Operating Time: 666.68 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
08/13/2014 05:32 08/13/2014 06:05 Hot Start - Gas	34	19.2	679.6		
08/13/2014 23:19 08/13/2014 23:27 Shut Down - Gas	9	2.2	483.5		
09/05/2014 00:39 09/05/2014 04:45 Cold Start - Gas	247	219.9	1,355.6		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT2 - CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,541.32 Hours

Non-Operating Time: 666.68 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Pound Per Event Report

CT2 - CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Tag Name: CT2_CO_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,541.32 Hours

Non-Operating Time: 666.68 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary

1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Pound Per Event Report

CT2 - NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,560.88 Hours

Non-Operating Time: 647.12 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
07/02/2014 22:03 07/02/2014 22:10 Shut Down - Gas	8	1.36	115.00		
07/03/2014 07:18 07/03/2014 08:21 Warm Start - Gas	64	78.06	456.20		
07/04/2014 20:23 07/04/2014 20:31 Shut Down - Gas	9	2.01	115.00		
07/05/2014 10:28 07/05/2014 11:35 Warm Start - Gas	68	92.60	456.20		
07/06/2014 02:04 07/06/2014 02:13 Shut Down - Gas	10	2.68	115.00		
07/06/2014 09:44 07/06/2014 10:49 Hot Start - Gas	66	79.32	259.90		
07/11/2014 00:02 07/11/2014 00:09 Shut Down - Gas	8	1.12	115.00		
07/11/2014 09:10 07/11/2014 10:48 Warm Start - Gas	99	114.20	456.20		
07/12/2014 00:06 07/12/2014 00:13 Shut Down - Gas	8	1.62	115.00		
07/12/2014 06:29 07/12/2014 07:41 Hot Start - Gas	73	76.24	259.90		
07/13/2014 01:06 07/13/2014 01:13 Shut Down - Gas	8	1.50	115.00		
07/13/2014 10:35 07/13/2014 11:37 Warm Start - Gas	63	81.40	456.20		
07/17/2014 00:06 07/17/2014 00:13 Shut Down - Gas	8	1.64	115.00		

Pound Per Event Report

CT2 - NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,560.88 Hours

Non-Operating Time: 647.12 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
07/17/2014 04:18 07/17/2014 05:33 Hot Start - Gas	76	44.21	259.90		
07/18/2014 00:06 07/18/2014 00:13 Shut Down - Gas	8	1.67	115.00		
07/18/2014 03:18 07/18/2014 04:06 Hot Start - Gas	49	17.37	259.90		
07/19/2014 00:12 07/19/2014 00:19 Shut Down - Gas	8	2.00	115.00		
07/19/2014 09:38 07/19/2014 10:33 Warm Start - Gas	56	83.51	456.20		
07/20/2014 00:06 07/20/2014 00:13 Shut Down - Gas	8	1.42	115.00		
07/21/2014 01:18 07/21/2014 03:33 Warm Start - Gas	136	132.92	456.20		
08/07/2014 00:47 08/07/2014 00:54 Shut Down - Gas	8	0.81	115.00		
08/07/2014 07:19 08/07/2014 08:38 Hot Start - Gas	80	72.47	259.90		
08/09/2014 02:06 08/09/2014 02:14 Shut Down - Gas	9	1.79	115.00		
08/09/2014 06:18 08/09/2014 07:09 Hot Start - Gas	52	45.78	259.90		
08/10/2014 00:06 08/10/2014 00:13 Shut Down - Gas	8	1.67	115.00		
08/10/2014 07:14 08/10/2014 08:21 Hot Start - Gas	68	72.16	259.90		
08/13/2014 01:32 08/13/2014 01:41 Shut Down - Gas	10	1.91	115.00		

Pound Per Event Report

CT2 - NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,560.88 Hours

Non-Operating Time: 647.12 Hours Report Time: 2,208.00 Hours

Event Period				Reason	Action
Begin/End	Duration in Minute(s)	Value (Sum)	Limit	Code - Description	Code - Description
08/13/2014 05:32 08/13/2014 06:05 Hot Start - Gas	34	25.36	259.90		
08/13/2014 23:19 08/13/2014 23:27 Shut Down - Gas	9	1.81	115.00		
09/05/2014 00:39 09/05/2014 04:45 Cold Start - Gas	247	279.88	779.10		

No excess emissions were found in the reporting period.

Pound Per Event Report

CT2 - NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,560.88 Hours

Non-Operating Time: 647.12 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

Pound Per Event Report

CT2 - NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:20 **Location:** Maxwell, CA

Tag Name: CT2_NOx_Event_Lbs_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,560.88 Hours

Non-Operating Time: 647.12 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary

1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,560.88 Hours

Non-Operating Time: 647.12 Hours Report Time: 2,208.00 Hours

Unit Operation and Excess Events

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
07/02/2014 22:03 07/02/2014 22:10 Shut Down - Gas	8	5.5		
07/03/2014 07:18 07/03/2014 08:21 Warm Start - Gas	64	119.6		
07/04/2014 20:23 07/04/2014 20:31 Shut Down - Gas	9	6.3		
07/05/2014 10:28 07/05/2014 11:35 Warm Start - Gas	68	124.1		
07/06/2014 02:04 07/06/2014 02:13 Shut Down - Gas	10	8.2		
07/06/2014 09:44 07/06/2014 10:49 Hot Start - Gas	66	121.8		
07/11/2014 00:02 07/11/2014 00:09 Shut Down - Gas	8	4.1		
07/11/2014 09:10 07/11/2014 10:48 Warm Start - Gas	99	189.2		
07/12/2014 00:06 07/12/2014 00:13 Shut Down - Gas	8	5.2		
07/12/2014 06:29 07/12/2014 07:41 Hot Start - Gas	73	133.6		
07/13/2014 01:06 07/13/2014 01:13 Shut Down - Gas	8	4.8		
07/13/2014 10:35 07/13/2014 11:37 Warm Start - Gas	63	119.2		
07/17/2014 00:06 07/17/2014 00:13 Shut Down - Gas	8	5.4		

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,560.88 Hours

Non-Operating Time: 647.12 Hours Report Time: 2,208.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
07/17/2014 04:18 07/17/2014 05:33 Hot Start - Gas	76	129.8		
07/18/2014 00:06 07/18/2014 00:13 Shut Down - Gas	8	5.6		
07/18/2014 03:18 07/18/2014 04:06 Hot Start - Gas	49	96.3		
07/19/2014 00:12 07/19/2014 00:19 Shut Down - Gas	8	5.3		
07/19/2014 09:38 07/19/2014 10:33 Warm Start - Gas	56	105.3		
07/20/2014 00:06 07/20/2014 00:13 Shut Down - Gas	8	5.2		
07/21/2014 01:18 07/21/2014 03:33 Warm Start - Gas	136	230.9		
08/07/2014 00:47 08/07/2014 00:54 Shut Down - Gas	8	4.4		
08/07/2014 07:19 08/07/2014 08:38 Hot Start - Gas	80	146.5		
08/09/2014 02:06 08/09/2014 02:14 Shut Down - Gas	9	6.5		
08/09/2014 06:18 08/09/2014 07:09 Hot Start - Gas	52	100.9		
08/10/2014 00:06 08/10/2014 00:13 Shut Down - Gas	8	5.4		
08/10/2014 07:14 08/10/2014 08:21 Hot Start - Gas	68	128.5		
08/13/2014 01:32 08/13/2014 01:41 Shut Down - Gas	10	9.4		

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,560.88 Hours

Non-Operating Time: 647.12 Hours Report Time: 2,208.00 Hours

Event Period			Reason	Action
Begin/End	Duration in Minute(s)	Lb/Event	Code - Description	Code - Description
08/13/2014 05:32 08/13/2014 06:05 Hot Start - Gas	34	64.8		
08/13/2014 23:19 08/13/2014 23:27 Shut Down - Gas	9	6.1		
09/05/2014 00:39 09/05/2014 04:45 Cold Start - Gas	247	409.7		

No excess emissions were found in the reporting period.

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,560.88 Hours

Non-Operating Time: 647.12 Hours Report Time: 2,208.00 Hours

Event Invalid Information

No invalid events were found in the reporting period.

100scf Per Event Report

CT2 - GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Tag Name: CT2_GasFlowTot_Event_100scf_1M

SI = SampleInvalid, * = Excess Emission

Total Operating Time: 1,560.88 Hours

Non-Operating Time: 647.12 Hours Report Time: 2,208.00 Hours

Periodic Excess and Invalid Summary

Emission Data Summary

1. Duration of excess emission in event reporting period due to:	
a. Startup/shutdown	0
b. Control equipment problems	0
c. Process problems	0
d. Other known causes	0
e. Unknown causes	0
2. Total Duration of Excess Emission in Minute(s)	0
3. Time of Excess Emission as a percentage of operating time	0.00
4. Time in compliance as percentage of operating time	100.00

CMS Performance Summary

1. CMS downtime in event reporting period due to:	
a. Monitor equipment malfunctions	0
b. Non-Monitor equipment malfunctions	0
c. Quality assurance calibration	0
d. Other known causes	0
e. Unknown causes	0
2. Total CMS Downtime in Minute(s)	0
3. Total Downtime as a percentage of operating time	0.00
4. Total Availability as a percentage of operating time	100.00

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/01/2014 00:00	0.0	0	0	0	0	1
07/01/2014 01:00	0.0	0	0	0	0	1
07/01/2014 02:00	0.0	0	0	0	0	1
07/01/2014 03:00	0.0	0	0	0	0	1
07/01/2014 04:00	0.0	0	0	0	0	1
07/01/2014 05:00	0.0	0	0	0	0	1
07/01/2014 06:00	0.0	0	0	0	0	1
07/01/2014 07:00	0.0	0	0	0	0	1
07/01/2014 08:00	0.0	0	0	0	0	1
07/01/2014 09:00	0.0	0	0	0	0	1
07/01/2014 10:00	0.0	0	0	0	0	1
07/01/2014 11:00	0.0	0	0	0	0	1
07/01/2014 12:00	0.0	0	0	0	0	1
07/01/2014 13:00	0.0	0	0	0	0	1
07/01/2014 14:00	0.0	0	0	0	0	1
07/01/2014 15:00	0.0	0	0	0	0	1
07/01/2014 16:00	0.0	0	0	0	0	1
07/01/2014 17:00	0.0	0	0	0	0	1
07/01/2014 18:00	0.0	0	0	0	0	1
07/01/2014 19:00	0.0	0	0	0	0	1
07/01/2014 20:00	0.0	0	0	0	0	1
07/01/2014 21:00	0.0	0	0	0	0	1
07/01/2014 22:00	0.0	0	0	0	0	1
07/01/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/02/2014 00:00	0.0	0	0	0	0	1
07/02/2014 01:00	0.0	0	0	0	0	1
07/02/2014 02:00	0.0	0	0	0	0	1
07/02/2014 03:00	0.0	0	0	0	0	1
07/02/2014 04:00	0.0	0	0	0	0	1
07/02/2014 05:00	0.0	0	0	0	0	1
07/02/2014 06:00	0.0	0	0	0	0	1
07/02/2014 07:00	0.0	0	0	0	0	1
07/02/2014 08:00	0.0	0	0	0	0	1
07/02/2014 09:00	0.0	0	0	0	0	1
07/02/2014 10:00	0.0	0	0	0	0	1
07/02/2014 11:00	0.0	0	0	0	0	1
07/02/2014 12:00	0.0	0	0	0	0	1
07/02/2014 13:00	0.0	0	0	0	0	1
07/02/2014 14:00	0.0	0	0	0	0	1
07/02/2014 15:00	0.0	0	0	0	0	1
07/02/2014 16:00	0.0	0	0	0	0	1
07/02/2014 17:00	0.0	0	0	0	0	1
07/02/2014 18:00	0.0	0	0	0	0	1
07/02/2014 19:00	0.0	0	0	0	0	1
07/02/2014 20:00	0.0	0	0	0	0	1
07/02/2014 21:00	0.0	0	0	0	0	1
07/02/2014 22:00	2.8	0	0	0	1	0
07/02/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	2.8 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.8	0	0	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/03/2014 00:00	0.0	0	0	0	0	0
07/03/2014 01:00	0.0	0	0	0	0	0
07/03/2014 02:00	0.0	0	0	0	0	0
07/03/2014 03:00	0.0	0	0	0	0	0
07/03/2014 04:00	0.0	0	0	0	0	0
07/03/2014 05:00	0.0	0	0	0	0	0
07/03/2014 06:00	0.0	0	0	0	0	0
07/03/2014 07:00	29.0	0	1	0	0	0
07/03/2014 08:00	8.5	0	1	0	0	0
07/03/2014 09:00	0.0	0	0	0	0	1
07/03/2014 10:00	0.0	0	0	0	0	1
07/03/2014 11:00	0.0	0	0	0	0	1
07/03/2014 12:00	0.0	0	0	0	0	1
07/03/2014 13:00	0.0	0	0	0	0	1
07/03/2014 14:00	0.0	0	0	0	0	1
07/03/2014 15:00	0.0	0	0	0	0	1
07/03/2014 16:00	0.0	0	0	0	0	1
07/03/2014 17:00	0.0	0	0	0	0	1
07/03/2014 18:00	0.0	0	0	0	0	1
07/03/2014 19:00	0.0	0	0	0	0	1
07/03/2014 20:00	0.0	0	0	0	0	1
07/03/2014 21:00	0.0	0	0	0	0	1
07/03/2014 22:00	0.0	0	0	0	0	1
07/03/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	37.5 #	0 #	2 #	0 #	0 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	29.0	0	1	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/04/2014 00:00	0.0	0	0	0	0	1
07/04/2014 01:00	0.0	0	0	0	0	1
07/04/2014 02:00	0.0	0	0	0	0	1
07/04/2014 03:00	0.0	0	0	0	0	1
07/04/2014 04:00	0.0	0	0	0	0	1
07/04/2014 05:00	0.0	0	0	0	0	1
07/04/2014 06:00	0.0	0	0	0	0	1
07/04/2014 07:00	0.0	0	0	0	0	1
07/04/2014 08:00	0.0	0	0	0	0	1
07/04/2014 09:00	0.0	0	0	0	0	1
07/04/2014 10:00	0.0	0	0	0	0	1
07/04/2014 11:00	0.0	0	0	0	0	1
07/04/2014 12:00	0.0	0	0	0	0	1
07/04/2014 13:00	0.0	0	0	0	0	1
07/04/2014 14:00	0.0	0	0	0	0	1
07/04/2014 15:00	0.0	0	0	0	0	1
07/04/2014 16:00	0.0	0	0	0	0	1
07/04/2014 17:00	0.0	0	0	0	0	1
07/04/2014 18:00	0.0	0	0	0	0	1
07/04/2014 19:00	0.0	0	0	0	0	1
07/04/2014 20:00	2.1	0	0	0	1	0
07/04/2014 21:00	0.0	0	0	0	0	0
07/04/2014 22:00	0.0	0	0	0	0	0
07/04/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	2.1 #	0 #	0 #	0 #	1 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2.1	0	0	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/05/2014 00:00	0.0	0	0	0	0	0
07/05/2014 01:00	0.0	0	0	0	0	0
07/05/2014 02:00	0.0	0	0	0	0	0
07/05/2014 03:00	0.0	0	0	0	0	0
07/05/2014 04:00	0.0	0	0	0	0	0
07/05/2014 05:00	0.0	0	0	0	0	0
07/05/2014 06:00	0.0	0	0	0	0	0
07/05/2014 07:00	0.0	0	0	0	0	0
07/05/2014 08:00	0.0	0	0	0	0	0
07/05/2014 09:00	0.0	0	0	0	0	0
07/05/2014 10:00	26.7	0	1	0	0	0
07/05/2014 11:00	21.4	0	1	0	0	0
07/05/2014 12:00	0.0	0	0	0	0	1
07/05/2014 13:00	0.0	0	0	0	0	1
07/05/2014 14:00	0.0	0	0	0	0	1
07/05/2014 15:00	0.0	0	0	0	0	1
07/05/2014 16:00	0.0	0	0	0	0	1
07/05/2014 17:00	0.0	0	0	0	0	1
07/05/2014 18:00	0.0	0	0	0	0	1
07/05/2014 19:00	0.0	0	0	0	0	1
07/05/2014 20:00	0.0	0	0	0	0	1
07/05/2014 21:00	0.0	0	0	0	0	1
07/05/2014 22:00	0.0	0	0	0	0	1
07/05/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	48.1 #	0 #	2 #	0 #	0 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	26.7	0	1	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/06/2014 00:00	0.0	0	0	0	0	1
07/06/2014 01:00	0.0	0	0	0	0	1
07/06/2014 02:00	5.0	0	0	0	1	0
07/06/2014 03:00	0.0	0	0	0	0	0
07/06/2014 04:00	0.0	0	0	0	0	0
07/06/2014 05:00	0.0	0	0	0	0	0
07/06/2014 06:00	0.0	0	0	0	0	0
07/06/2014 07:00	0.0	0	0	0	0	0
07/06/2014 08:00	0.0	0	0	0	0	0
07/06/2014 09:00	4.9	0	0	1	0	0
07/06/2014 10:00	34.9	0	0	1	0	0
07/06/2014 11:00	0.0	0	0	0	0	1
07/06/2014 12:00	0.0	0	0	0	0	1
07/06/2014 13:00	0.0	0	0	0	0	1
07/06/2014 14:00	0.0	0	0	0	0	1
07/06/2014 15:00	0.0	0	0	0	0	1
07/06/2014 16:00	0.0	0	0	0	0	1
07/06/2014 17:00	0.0	0	0	0	0	1
07/06/2014 18:00	0.0	0	0	0	0	1
07/06/2014 19:00	0.0	0	0	0	0	1
07/06/2014 20:00	0.0	0	0	0	0	1
07/06/2014 21:00	0.0	0	0	0	0	1
07/06/2014 22:00	0.0	0	0	0	0	1
07/06/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	44.8 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	34.9	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/07/2014 00:00	0.0	0	0	0	0	1
07/07/2014 01:00	0.0	0	0	0	0	1
07/07/2014 02:00	0.0	0	0	0	0	1
07/07/2014 03:00	0.0	0	0	0	0	1
07/07/2014 04:00	0.0	0	0	0	0	1
07/07/2014 05:00	0.0	0	0	0	0	1
07/07/2014 06:00	0.0	0	0	0	0	1
07/07/2014 07:00	0.0	0	0	0	0	1
07/07/2014 08:00	0.0	0	0	0	0	1
07/07/2014 09:00	0.0	0	0	0	0	1
07/07/2014 10:00	0.0	0	0	0	0	1
07/07/2014 11:00	0.0	0	0	0	0	1
07/07/2014 12:00	0.0	0	0	0	0	1
07/07/2014 13:00	0.0	0	0	0	0	1
07/07/2014 14:00	0.0	0	0	0	0	1
07/07/2014 15:00	0.0	0	0	0	0	1
07/07/2014 16:00	0.0	0	0	0	0	1
07/07/2014 17:00	0.0	0	0	0	0	1
07/07/2014 18:00	0.0	0	0	0	0	1
07/07/2014 19:00	0.0	0	0	0	0	1
07/07/2014 20:00	0.0	0	0	0	0	1
07/07/2014 21:00	0.0	0	0	0	0	1
07/07/2014 22:00	0.0	0	0	0	0	1
07/07/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/08/2014 00:00	0.0	0	0	0	0	1
07/08/2014 01:00	0.0	0	0	0	0	1
07/08/2014 02:00	0.0	0	0	0	0	1
07/08/2014 03:00	0.0	0	0	0	0	1
07/08/2014 04:00	0.0	0	0	0	0	1
07/08/2014 05:00	0.0	0	0	0	0	1
07/08/2014 06:00	0.0	0	0	0	0	1
07/08/2014 07:00	0.0	0	0	0	0	1
07/08/2014 08:00	0.0	0	0	0	0	1
07/08/2014 09:00	0.0	0	0	0	0	1
07/08/2014 10:00	0.0	0	0	0	0	1
07/08/2014 11:00	0.0	0	0	0	0	1
07/08/2014 12:00	0.0	0	0	0	0	1
07/08/2014 13:00	0.0	0	0	0	0	1
07/08/2014 14:00	0.0	0	0	0	0	1
07/08/2014 15:00	0.0	0	0	0	0	1
07/08/2014 16:00	0.0	0	0	0	0	1
07/08/2014 17:00	0.0	0	0	0	0	1
07/08/2014 18:00	0.0	0	0	0	0	1
07/08/2014 19:00	0.0	0	0	0	0	1
07/08/2014 20:00	0.0	0	0	0	0	1
07/08/2014 21:00	0.0	0	0	0	0	1
07/08/2014 22:00	0.0	0	0	0	0	1
07/08/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/09/2014 00:00	0.0	0	0	0	0	1
07/09/2014 01:00	0.0	0	0	0	0	1
07/09/2014 02:00	0.0	0	0	0	0	1
07/09/2014 03:00	0.0	0	0	0	0	1
07/09/2014 04:00	0.0	0	0	0	0	1
07/09/2014 05:00	0.0	0	0	0	0	1
07/09/2014 06:00	0.0	0	0	0	0	1
07/09/2014 07:00	0.0	0	0	0	0	1
07/09/2014 08:00	0.0	0	0	0	0	1
07/09/2014 09:00	0.0	0	0	0	0	1
07/09/2014 10:00	0.0	0	0	0	0	1
07/09/2014 11:00	0.0	0	0	0	0	1
07/09/2014 12:00	0.0	0	0	0	0	1
07/09/2014 13:00	0.0	0	0	0	0	1
07/09/2014 14:00	0.0	0	0	0	0	1
07/09/2014 15:00	0.0	0	0	0	0	1
07/09/2014 16:00	0.0	0	0	0	0	1
07/09/2014 17:00	0.0	0	0	0	0	1
07/09/2014 18:00	0.0	0	0	0	0	1
07/09/2014 19:00	0.0	0	0	0	0	1
07/09/2014 20:00	0.0	0	0	0	0	1
07/09/2014 21:00	0.0	0	0	0	0	1
07/09/2014 22:00	0.0	0	0	0	0	1
07/09/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/10/2014 00:00	0.0	0	0	0	0	1
07/10/2014 01:00	0.0	0	0	0	0	1
07/10/2014 02:00	0.0	0	0	0	0	1
07/10/2014 03:00	0.0	0	0	0	0	1
07/10/2014 04:00	0.0	0	0	0	0	1
07/10/2014 05:00	0.0	0	0	0	0	1
07/10/2014 06:00	0.0	0	0	0	0	1
07/10/2014 07:00	0.0	0	0	0	0	1
07/10/2014 08:00	0.0	0	0	0	0	1
07/10/2014 09:00	0.0	0	0	0	0	1
07/10/2014 10:00	0.0	0	0	0	0	1
07/10/2014 11:00	0.0	0	0	0	0	1
07/10/2014 12:00	0.0	0	0	0	0	1
07/10/2014 13:00	0.0	0	0	0	0	1
07/10/2014 14:00	0.0	0	0	0	0	1
07/10/2014 15:00	0.0	0	0	0	0	1
07/10/2014 16:00	0.0	0	0	0	0	1
07/10/2014 17:00	0.0	0	0	0	0	1
07/10/2014 18:00	0.0	0	0	0	0	1
07/10/2014 19:00	0.0	0	0	0	0	1
07/10/2014 20:00	0.0	0	0	0	0	1
07/10/2014 21:00	0.0	0	0	0	0	1
07/10/2014 22:00	0.0	0	0	0	0	1
07/10/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/11/2014 00:00	4.0	0	0	0	1	0
07/11/2014 01:00	0.0	0	0	0	0	0
07/11/2014 02:00	0.0	0	0	0	0	0
07/11/2014 03:00	0.0	0	0	0	0	0
07/11/2014 04:00	0.0	0	0	0	0	0
07/11/2014 05:00	0.0	0	0	0	0	0
07/11/2014 06:00	0.0	0	0	0	0	0
07/11/2014 07:00	0.0	0	0	0	0	0
07/11/2014 08:00	0.0	0	0	0	0	0
07/11/2014 09:00	44.5	0	1	0	0	0
07/11/2014 10:00	56.0	0	1	0	0	0
07/11/2014 11:00	0.0	0	0	0	0	1
07/11/2014 12:00	0.0	0	0	0	0	1
07/11/2014 13:00	0.0	0	0	0	0	1
07/11/2014 14:00	0.0	0	0	0	0	1
07/11/2014 15:00	0.0	0	0	0	0	1
07/11/2014 16:00	0.0	0	0	0	0	1
07/11/2014 17:00	0.0	0	0	0	0	1
07/11/2014 18:00	0.0	0	0	0	0	1
07/11/2014 19:00	0.0	0	0	0	0	1
07/11/2014 20:00	0.0	0	0	0	0	1
07/11/2014 21:00	0.0	0	0	0	0	1
07/11/2014 22:00	0.0	0	0	0	0	1
07/11/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	104.5 #	0 #	2 #	0 #	1 #	13 #
Minimum:	0.0	0	0	0	0	0
Maximum:	56.0	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/12/2014 00:00	4.8	0	0	0	1	0
07/12/2014 01:00	0.0	0	0	0	0	0
07/12/2014 02:00	0.0	0	0	0	0	0
07/12/2014 03:00	0.0	0	0	0	0	0
07/12/2014 04:00	0.0	0	0	0	0	0
07/12/2014 05:00	0.0	0	0	0	0	0
07/12/2014 06:00	16.5	0	0	1	0	0
07/12/2014 07:00	47.0	0	0	1	0	0
07/12/2014 08:00	0.0	0	0	0	0	1
07/12/2014 09:00	0.0	0	0	0	0	1
07/12/2014 10:00	0.0	0	0	0	0	1
07/12/2014 11:00	0.0	0	0	0	0	1
07/12/2014 12:00	0.0	0	0	0	0	1
07/12/2014 13:00	0.0	0	0	0	0	1
07/12/2014 14:00	0.0	0	0	0	0	1
07/12/2014 15:00	0.0	0	0	0	0	1
07/12/2014 16:00	0.0	0	0	0	0	1
07/12/2014 17:00	0.0	0	0	0	0	1
07/12/2014 18:00	0.0	0	0	0	0	1
07/12/2014 19:00	0.0	0	0	0	0	1
07/12/2014 20:00	0.0	0	0	0	0	1
07/12/2014 21:00	0.0	0	0	0	0	1
07/12/2014 22:00	0.0	0	0	0	0	1
07/12/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	68.3 #	0 #	0 #	2 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	47.0	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/13/2014 00:00	0.0	0	0	0	0	1
07/13/2014 01:00	3.5	0	0	0	1	0
07/13/2014 02:00	0.0	0	0	0	0	0
07/13/2014 03:00	0.0	0	0	0	0	0
07/13/2014 04:00	0.0	0	0	0	0	0
07/13/2014 05:00	0.0	0	0	0	0	0
07/13/2014 06:00	0.0	0	0	0	0	0
07/13/2014 07:00	0.0	0	0	0	0	0
07/13/2014 08:00	0.0	0	0	0	0	0
07/13/2014 09:00	0.0	0	0	0	0	0
07/13/2014 10:00	13.3	0	1	0	0	0
07/13/2014 11:00	32.2	0	1	0	0	0
07/13/2014 12:00	0.0	0	0	0	0	1
07/13/2014 13:00	0.0	0	0	0	0	1
07/13/2014 14:00	0.0	0	0	0	0	1
07/13/2014 15:00	0.0	0	0	0	0	1
07/13/2014 16:00	0.0	0	0	0	0	1
07/13/2014 17:00	0.0	0	0	0	0	1
07/13/2014 18:00	0.0	0	0	0	0	1
07/13/2014 19:00	0.0	0	0	0	0	1
07/13/2014 20:00	0.0	0	0	0	0	1
07/13/2014 21:00	0.0	0	0	0	0	1
07/13/2014 22:00	0.0	0	0	0	0	1
07/13/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	49.0 #	0 #	2 #	0 #	1 #	13 #
Minimum:	0.0	0	0	0	0	0
Maximum:	32.2	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/14/2014 00:00	0.0	0	0	0	0	1
07/14/2014 01:00	0.0	0	0	0	0	1
07/14/2014 02:00	0.0	0	0	0	0	1
07/14/2014 03:00	0.0	0	0	0	0	1
07/14/2014 04:00	0.0	0	0	0	0	1
07/14/2014 05:00	0.0	0	0	0	0	1
07/14/2014 06:00	0.0	0	0	0	0	1
07/14/2014 07:00	0.0	0	0	0	0	1
07/14/2014 08:00	0.0	0	0	0	0	1
07/14/2014 09:00	0.0	0	0	0	0	1
07/14/2014 10:00	0.0	0	0	0	0	1
07/14/2014 11:00	0.0	0	0	0	0	1
07/14/2014 12:00	0.0	0	0	0	0	1
07/14/2014 13:00	0.0	0	0	0	0	1
07/14/2014 14:00	0.0	0	0	0	0	1
07/14/2014 15:00	0.0	0	0	0	0	1
07/14/2014 16:00	0.0	0	0	0	0	1
07/14/2014 17:00	0.0	0	0	0	0	1
07/14/2014 18:00	0.0	0	0	0	0	1
07/14/2014 19:00	0.0	0	0	0	0	1
07/14/2014 20:00	0.0	0	0	0	0	1
07/14/2014 21:00	0.0	0	0	0	0	1
07/14/2014 22:00	0.0	0	0	0	0	1
07/14/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/15/2014 00:00	0.0	0	0	0	0	1
07/15/2014 01:00	0.0	0	0	0	0	1
07/15/2014 02:00	0.0	0	0	0	0	1
07/15/2014 03:00	0.0	0	0	0	0	1
07/15/2014 04:00	0.0	0	0	0	0	1
07/15/2014 05:00	0.0	0	0	0	0	1
07/15/2014 06:00	0.0	0	0	0	0	1
07/15/2014 07:00	0.0	0	0	0	0	1
07/15/2014 08:00	0.0	0	0	0	0	1
07/15/2014 09:00	0.0	0	0	0	0	1
07/15/2014 10:00	0.0	0	0	0	0	1
07/15/2014 11:00	0.0	0	0	0	0	1
07/15/2014 12:00	0.0	0	0	0	0	1
07/15/2014 13:00	0.0	0	0	0	0	1
07/15/2014 14:00	0.0	0	0	0	0	1
07/15/2014 15:00	0.0	0	0	0	0	1
07/15/2014 16:00	0.0	0	0	0	0	1
07/15/2014 17:00	0.0	0	0	0	0	1
07/15/2014 18:00	0.0	0	0	0	0	1
07/15/2014 19:00	0.0	0	0	0	0	1
07/15/2014 20:00	0.0	0	0	0	0	1
07/15/2014 21:00	0.0	0	0	0	0	1
07/15/2014 22:00	0.0	0	0	0	0	1
07/15/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/16/2014 00:00	0.0	0	0	0	0	1
07/16/2014 01:00	0.0	0	0	0	0	1
07/16/2014 02:00	0.0	0	0	0	0	1
07/16/2014 03:00	0.0	0	0	0	0	1
07/16/2014 04:00	0.0	0	0	0	0	1
07/16/2014 05:00	0.0	0	0	0	0	1
07/16/2014 06:00	0.0	0	0	0	0	1
07/16/2014 07:00	0.0	0	0	0	0	1
07/16/2014 08:00	0.0	0	0	0	0	1
07/16/2014 09:00	0.0	0	0	0	0	1
07/16/2014 10:00	0.0	0	0	0	0	1
07/16/2014 11:00	0.0	0	0	0	0	1
07/16/2014 12:00	0.0	0	0	0	0	1
07/16/2014 13:00	0.0	0	0	0	0	1
07/16/2014 14:00	0.0	0	0	0	0	1
07/16/2014 15:00	0.0	0	0	0	0	1
07/16/2014 16:00	0.0	0	0	0	0	1
07/16/2014 17:00	0.0	0	0	0	0	1
07/16/2014 18:00	0.0	0	0	0	0	1
07/16/2014 19:00	0.0	0	0	0	0	1
07/16/2014 20:00	0.0	0	0	0	0	1
07/16/2014 21:00	0.0	0	0	0	0	1
07/16/2014 22:00	0.0	0	0	0	0	1
07/16/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/17/2014 00:00	3.0	0	0	0	1	0
07/17/2014 01:00	0.0	0	0	0	0	0
07/17/2014 02:00	0.0	0	0	0	0	0
07/17/2014 03:00	0.0	0	0	0	0	0
07/17/2014 04:00	18.2	0	0	1	0	0
07/17/2014 05:00	17.0	0	0	1	0	0
07/17/2014 06:00	0.0	0	0	0	0	1
07/17/2014 07:00	0.0	0	0	0	0	1
07/17/2014 08:00	0.0	0	0	0	0	1
07/17/2014 09:00	0.0	0	0	0	0	1
07/17/2014 10:00	0.0	0	0	0	0	1
07/17/2014 11:00	0.0	0	0	0	0	1
07/17/2014 12:00	0.0	0	0	0	0	1
07/17/2014 13:00	0.0	0	0	0	0	1
07/17/2014 14:00	0.0	0	0	0	0	1
07/17/2014 15:00	0.0	0	0	0	0	1
07/17/2014 16:00	0.0	0	0	0	0	1
07/17/2014 17:00	0.0	0	0	0	0	1
07/17/2014 18:00	0.0	0	0	0	0	1
07/17/2014 19:00	0.0	0	0	0	0	1
07/17/2014 20:00	0.0	0	0	0	0	1
07/17/2014 21:00	0.0	0	0	0	0	1
07/17/2014 22:00	0.0	0	0	0	0	1
07/17/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	38.2 #	0 #	0 #	2 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	18.2	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/18/2014 00:00	2.8	0	0	0	1	0
07/18/2014 01:00	0.0	0	0	0	0	0
07/18/2014 02:00	0.0	0	0	0	0	0
07/18/2014 03:00	37.8	0	0	1	0	0
07/18/2014 04:00	0.0	0	0	1	0	0
07/18/2014 05:00	0.0	0	0	0	0	1
07/18/2014 06:00	0.0	0	0	0	0	1
07/18/2014 07:00	0.0	0	0	0	0	1
07/18/2014 08:00	0.0	0	0	0	0	1
07/18/2014 09:00	0.0	0	0	0	0	1
07/18/2014 10:00	0.0	0	0	0	0	1
07/18/2014 11:00	0.0	0	0	0	0	1
07/18/2014 12:00	0.0	0	0	0	0	1
07/18/2014 13:00	0.0	0	0	0	0	1
07/18/2014 14:00	0.0	0	0	0	0	1
07/18/2014 15:00	0.0	0	0	0	0	1
07/18/2014 16:00	0.0	0	0	0	0	1
07/18/2014 17:00	0.0	0	0	0	0	1
07/18/2014 18:00	0.0	0	0	0	0	1
07/18/2014 19:00	0.0	0	0	0	0	1
07/18/2014 20:00	0.0	0	0	0	0	1
07/18/2014 21:00	0.0	0	0	0	0	1
07/18/2014 22:00	0.0	0	0	0	0	1
07/18/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	40.6 #	0 #	0 #	2 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	37.8	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/19/2014 00:00	2.5	0	0	0	1	0
07/19/2014 01:00	0.0	0	0	0	0	0
07/19/2014 02:00	0.0	0	0	0	0	0
07/19/2014 03:00	0.0	0	0	0	0	0
07/19/2014 04:00	0.0	0	0	0	0	0
07/19/2014 05:00	0.0	0	0	0	0	0
07/19/2014 06:00	0.0	0	0	0	0	0
07/19/2014 07:00	0.0	0	0	0	0	0
07/19/2014 08:00	0.0	0	0	0	0	0
07/19/2014 09:00	9.7	0	1	0	0	0
07/19/2014 10:00	16.9	0	1	0	0	0
07/19/2014 11:00	0.0	0	0	0	0	1
07/19/2014 12:00	0.0	0	0	0	0	1
07/19/2014 13:00	0.0	0	0	0	0	1
07/19/2014 14:00	0.0	0	0	0	0	1
07/19/2014 15:00	0.0	0	0	0	0	1
07/19/2014 16:00	0.0	0	0	0	0	1
07/19/2014 17:00	0.0	0	0	0	0	1
07/19/2014 18:00	0.0	0	0	0	0	1
07/19/2014 19:00	0.0	0	0	0	0	1
07/19/2014 20:00	0.0	0	0	0	0	1
07/19/2014 21:00	0.0	0	0	0	0	1
07/19/2014 22:00	0.0	0	0	0	0	1
07/19/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	29.1 #	0 #	2 #	0 #	1 #	13 #
Minimum:	0.0	0	0	0	0	0
Maximum:	16.9	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/20/2014 00:00	3.2	0	0	0	1	0
07/20/2014 01:00	0.0	0	0	0	0	0
07/20/2014 02:00	0.0	0	0	0	0	0
07/20/2014 03:00	0.0	0	0	0	0	0
07/20/2014 04:00	0.0	0	0	0	0	0
07/20/2014 05:00	0.0	0	0	0	0	0
07/20/2014 06:00	0.0	0	0	0	0	0
07/20/2014 07:00	0.0	0	0	0	0	0
07/20/2014 08:00	0.0	0	0	0	0	0
07/20/2014 09:00	0.0	0	0	0	0	0
07/20/2014 10:00	0.0	0	0	0	0	0
07/20/2014 11:00	0.0	0	0	0	0	0
07/20/2014 12:00	0.0	0	0	0	0	0
07/20/2014 13:00	0.0	0	0	0	0	0
07/20/2014 14:00	0.0	0	0	0	0	0
07/20/2014 15:00	0.0	0	0	0	0	0
07/20/2014 16:00	0.0	0	0	0	0	0
07/20/2014 17:00	0.0	0	0	0	0	0
07/20/2014 18:00	0.0	0	0	0	0	0
07/20/2014 19:00	0.0	0	0	0	0	0
07/20/2014 20:00	0.0	0	0	0	0	0
07/20/2014 21:00	0.0	0	0	0	0	0
07/20/2014 22:00	0.0	0	0	0	0	0
07/20/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	3.2 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3.2	0	0	0	1	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/21/2014 00:00	0.0	0	0	0	0	0
07/21/2014 01:00	67.8	0	1	0	0	0
07/21/2014 02:00	34.1	0	1	0	0	0
07/21/2014 03:00	25.0	0	1	0	0	0
07/21/2014 04:00	0.0	0	0	0	0	1
07/21/2014 05:00	0.0	0	0	0	0	1
07/21/2014 06:00	0.0	0	0	0	0	1
07/21/2014 07:00	0.0	0	0	0	0	1
07/21/2014 08:00	0.0	0	0	0	0	1
07/21/2014 09:00	0.0	0	0	0	0	1
07/21/2014 10:00	0.0	0	0	0	0	1
07/21/2014 11:00	0.0	0	0	0	0	1
07/21/2014 12:00	0.0	0	0	0	0	1
07/21/2014 13:00	0.0	0	0	0	0	1
07/21/2014 14:00	0.0	0	0	0	0	1
07/21/2014 15:00	0.0	0	0	0	0	1
07/21/2014 16:00	0.0	0	0	0	0	1
07/21/2014 17:00	0.0	0	0	0	0	1
07/21/2014 18:00	0.0	0	0	0	0	1
07/21/2014 19:00	0.0	0	0	0	0	1
07/21/2014 20:00	0.0	0	0	0	0	1
07/21/2014 21:00	0.0	0	0	0	0	1
07/21/2014 22:00	0.0	0	0	0	0	1
07/21/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	126.9 #	0 #	3 #	0 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	67.8	0	1	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/22/2014 00:00	0.0	0	0	0	0	1
07/22/2014 01:00	0.0	0	0	0	0	1
07/22/2014 02:00	0.0	0	0	0	0	1
07/22/2014 03:00	0.0	0	0	0	0	1
07/22/2014 04:00	0.0	0	0	0	0	1
07/22/2014 05:00	0.0	0	0	0	0	1
07/22/2014 06:00	0.0	0	0	0	0	1
07/22/2014 07:00	0.0	0	0	0	0	1
07/22/2014 08:00	0.0	0	0	0	0	1
07/22/2014 09:00	0.0	0	0	0	0	1
07/22/2014 10:00	0.0	0	0	0	0	1
07/22/2014 11:00	0.0	0	0	0	0	1
07/22/2014 12:00	0.0	0	0	0	0	1
07/22/2014 13:00	0.0	0	0	0	0	1
07/22/2014 14:00	0.0	0	0	0	0	1
07/22/2014 15:00	0.0	0	0	0	0	1
07/22/2014 16:00	0.0	0	0	0	0	1
07/22/2014 17:00	0.0	0	0	0	0	1
07/22/2014 18:00	0.0	0	0	0	0	1
07/22/2014 19:00	0.0	0	0	0	0	1
07/22/2014 20:00	0.0	0	0	0	0	1
07/22/2014 21:00	0.0	0	0	0	0	1
07/22/2014 22:00	0.0	0	0	0	0	1
07/22/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/23/2014 00:00	0.0	0	0	0	0	1
07/23/2014 01:00	0.0	0	0	0	0	1
07/23/2014 02:00	0.0	0	0	0	0	1
07/23/2014 03:00	0.0	0	0	0	0	1
07/23/2014 04:00	0.0	0	0	0	0	1
07/23/2014 05:00	0.0	0	0	0	0	1
07/23/2014 06:00	0.0	0	0	0	0	1
07/23/2014 07:00	0.0	0	0	0	0	1
07/23/2014 08:00	0.0	0	0	0	0	1
07/23/2014 09:00	0.0	0	0	0	0	1
07/23/2014 10:00	0.0	0	0	0	0	1
07/23/2014 11:00	0.0	0	0	0	0	1
07/23/2014 12:00	0.0	0	0	0	0	1
07/23/2014 13:00	0.0	0	0	0	0	1
07/23/2014 14:00	0.0	0	0	0	0	1
07/23/2014 15:00	0.0	0	0	0	0	1
07/23/2014 16:00	0.0	0	0	0	0	1
07/23/2014 17:00	0.0	0	0	0	0	1
07/23/2014 18:00	0.0	0	0	0	0	1
07/23/2014 19:00	0.0	0	0	0	0	1
07/23/2014 20:00	0.0	0	0	0	0	1
07/23/2014 21:00	0.0	0	0	0	0	1
07/23/2014 22:00	0.0	0	0	0	0	1
07/23/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/24/2014 00:00	0.0	0	0	0	0	1
07/24/2014 01:00	0.0	0	0	0	0	1
07/24/2014 02:00	0.0	0	0	0	0	1
07/24/2014 03:00	0.0	0	0	0	0	1
07/24/2014 04:00	0.0	0	0	0	0	1
07/24/2014 05:00	0.0	0	0	0	0	1
07/24/2014 06:00	0.0	0	0	0	0	1
07/24/2014 07:00	0.0	0	0	0	0	1
07/24/2014 08:00	0.0	0	0	0	0	1
07/24/2014 09:00	0.0	0	0	0	0	1
07/24/2014 10:00	0.0	0	0	0	0	1
07/24/2014 11:00	0.0	0	0	0	0	1
07/24/2014 12:00	0.0	0	0	0	0	1
07/24/2014 13:00	0.0	0	0	0	0	1
07/24/2014 14:00	0.0	0	0	0	0	1
07/24/2014 15:00	0.0	0	0	0	0	1
07/24/2014 16:00	0.0	0	0	0	0	1
07/24/2014 17:00	0.0	0	0	0	0	1
07/24/2014 18:00	0.0	0	0	0	0	1
07/24/2014 19:00	0.0	0	0	0	0	1
07/24/2014 20:00	0.0	0	0	0	0	1
07/24/2014 21:00	0.0	0	0	0	0	1
07/24/2014 22:00	0.0	0	0	0	0	1
07/24/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/25/2014 00:00	0.0	0	0	0	0	1
07/25/2014 01:00	0.0	0	0	0	0	1
07/25/2014 02:00	0.0	0	0	0	0	1
07/25/2014 03:00	0.0	0	0	0	0	1
07/25/2014 04:00	0.0	0	0	0	0	1
07/25/2014 05:00	0.0	0	0	0	0	1
07/25/2014 06:00	0.0	0	0	0	0	1
07/25/2014 07:00	0.0	0	0	0	0	1
07/25/2014 08:00	0.0	0	0	0	0	1
07/25/2014 09:00	0.0	0	0	0	0	1
07/25/2014 10:00	0.0	0	0	0	0	1
07/25/2014 11:00	0.0	0	0	0	0	1
07/25/2014 12:00	0.0	0	0	0	0	1
07/25/2014 13:00	0.0	0	0	0	0	1
07/25/2014 14:00	0.0	0	0	0	0	1
07/25/2014 15:00	0.0	0	0	0	0	1
07/25/2014 16:00	0.0	0	0	0	0	1
07/25/2014 17:00	0.0	0	0	0	0	1
07/25/2014 18:00	0.0	0	0	0	0	1
07/25/2014 19:00	0.0	0	0	0	0	1
07/25/2014 20:00	0.0	0	0	0	0	1
07/25/2014 21:00	0.0	0	0	0	0	1
07/25/2014 22:00	0.0	0	0	0	0	1
07/25/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/26/2014 00:00	0.0	0	0	0	0	1
07/26/2014 01:00	0.0	0	0	0	0	1
07/26/2014 02:00	0.0	0	0	0	0	1
07/26/2014 03:00	0.0	0	0	0	0	1
07/26/2014 04:00	0.0	0	0	0	0	1
07/26/2014 05:00	0.0	0	0	0	0	1
07/26/2014 06:00	0.0	0	0	0	0	1
07/26/2014 07:00	0.0	0	0	0	0	1
07/26/2014 08:00	0.0	0	0	0	0	1
07/26/2014 09:00	0.0	0	0	0	0	1
07/26/2014 10:00	0.0	0	0	0	0	1
07/26/2014 11:00	0.0	0	0	0	0	1
07/26/2014 12:00	0.0	0	0	0	0	1
07/26/2014 13:00	0.0	0	0	0	0	1
07/26/2014 14:00	0.0	0	0	0	0	1
07/26/2014 15:00	0.0	0	0	0	0	1
07/26/2014 16:00	0.0	0	0	0	0	1
07/26/2014 17:00	0.0	0	0	0	0	1
07/26/2014 18:00	0.0	0	0	0	0	1
07/26/2014 19:00	0.0	0	0	0	0	1
07/26/2014 20:00	0.0	0	0	0	0	1
07/26/2014 21:00	0.0	0	0	0	0	1
07/26/2014 22:00	0.0	0	0	0	0	1
07/26/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/27/2014 00:00	0.0	0	0	0	0	1
07/27/2014 01:00	0.0	0	0	0	0	1
07/27/2014 02:00	0.0	0	0	0	0	1
07/27/2014 03:00	0.0	0	0	0	0	1
07/27/2014 04:00	0.0	0	0	0	0	1
07/27/2014 05:00	0.0	0	0	0	0	1
07/27/2014 06:00	0.0	0	0	0	0	1
07/27/2014 07:00	0.0	0	0	0	0	1
07/27/2014 08:00	0.0	0	0	0	0	1
07/27/2014 09:00	0.0	0	0	0	0	1
07/27/2014 10:00	0.0	0	0	0	0	1
07/27/2014 11:00	0.0	0	0	0	0	1
07/27/2014 12:00	0.0	0	0	0	0	1
07/27/2014 13:00	0.0	0	0	0	0	1
07/27/2014 14:00	0.0	0	0	0	0	1
07/27/2014 15:00	0.0	0	0	0	0	1
07/27/2014 16:00	0.0	0	0	0	0	1
07/27/2014 17:00	0.0	0	0	0	0	1
07/27/2014 18:00	0.0	0	0	0	0	1
07/27/2014 19:00	0.0	0	0	0	0	1
07/27/2014 20:00	0.0	0	0	0	0	1
07/27/2014 21:00	0.0	0	0	0	0	1
07/27/2014 22:00	0.0	0	0	0	0	1
07/27/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/28/2014 00:00	0.0	0	0	0	0	1
07/28/2014 01:00	0.0	0	0	0	0	1
07/28/2014 02:00	0.0	0	0	0	0	1
07/28/2014 03:00	0.0	0	0	0	0	1
07/28/2014 04:00	0.0	0	0	0	0	1
07/28/2014 05:00	0.0	0	0	0	0	1
07/28/2014 06:00	0.0	0	0	0	0	1
07/28/2014 07:00	0.0	0	0	0	0	1
07/28/2014 08:00	0.0	0	0	0	0	1
07/28/2014 09:00	0.0	0	0	0	0	1
07/28/2014 10:00	0.0	0	0	0	0	1
07/28/2014 11:00	0.0	0	0	0	0	1
07/28/2014 12:00	0.0	0	0	0	0	1
07/28/2014 13:00	0.0	0	0	0	0	1
07/28/2014 14:00	0.0	0	0	0	0	1
07/28/2014 15:00	0.0	0	0	0	0	1
07/28/2014 16:00	0.0	0	0	0	0	1
07/28/2014 17:00	0.0	0	0	0	0	1
07/28/2014 18:00	0.0	0	0	0	0	1
07/28/2014 19:00	0.0	0	0	0	0	1
07/28/2014 20:00	0.0	0	0	0	0	1
07/28/2014 21:00	0.0	0	0	0	0	1
07/28/2014 22:00	0.0	0	0	0	0	1
07/28/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/29/2014 00:00	0.0	0	0	0	0	1
07/29/2014 01:00	0.0	0	0	0	0	1
07/29/2014 02:00	0.0	0	0	0	0	1
07/29/2014 03:00	0.0	0	0	0	0	1
07/29/2014 04:00	0.0	0	0	0	0	1
07/29/2014 05:00	0.0	0	0	0	0	1
07/29/2014 06:00	0.0	0	0	0	0	1
07/29/2014 07:00	0.0	0	0	0	0	1
07/29/2014 08:00	0.0	0	0	0	0	1
07/29/2014 09:00	0.0	0	0	0	0	1
07/29/2014 10:00	0.0	0	0	0	0	1
07/29/2014 11:00	0.0	0	0	0	0	1
07/29/2014 12:00	0.0	0	0	0	0	1
07/29/2014 13:00	0.0	0	0	0	0	1
07/29/2014 14:00	0.0	0	0	0	0	1
07/29/2014 15:00	0.0	0	0	0	0	1
07/29/2014 16:00	0.0	0	0	0	0	1
07/29/2014 17:00	0.0	0	0	0	0	1
07/29/2014 18:00	0.0	0	0	0	0	1
07/29/2014 19:00	0.0	0	0	0	0	1
07/29/2014 20:00	0.0	0	0	0	0	1
07/29/2014 21:00	0.0	0	0	0	0	1
07/29/2014 22:00	0.0	0	0	0	0	1
07/29/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/30/2014 00:00	0.0	0	0	0	0	1
07/30/2014 01:00	0.0	0	0	0	0	1
07/30/2014 02:00	0.0	0	0	0	0	1
07/30/2014 03:00	0.0	0	0	0	0	1
07/30/2014 04:00	0.0	0	0	0	0	1
07/30/2014 05:00	0.0	0	0	0	0	1
07/30/2014 06:00	0.0	0	0	0	0	1
07/30/2014 07:00	0.0	0	0	0	0	1
07/30/2014 08:00	0.0	0	0	0	0	1
07/30/2014 09:00	0.0	0	0	0	0	1
07/30/2014 10:00	0.0	0	0	0	0	1
07/30/2014 11:00	0.0	0	0	0	0	1
07/30/2014 12:00	0.0	0	0	0	0	1
07/30/2014 13:00	0.0	0	0	0	0	1
07/30/2014 14:00	0.0	0	0	0	0	1
07/30/2014 15:00	0.0	0	0	0	0	1
07/30/2014 16:00	0.0	0	0	0	0	1
07/30/2014 17:00	0.0	0	0	0	0	1
07/30/2014 18:00	0.0	0	0	0	0	1
07/30/2014 19:00	0.0	0	0	0	0	1
07/30/2014 20:00	0.0	0	0	0	0	1
07/30/2014 21:00	0.0	0	0	0	0	1
07/30/2014 22:00	0.0	0	0	0	0	1
07/30/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/31/2014 00:00	0.0	0	0	0	0	1
07/31/2014 01:00	0.0	0	0	0	0	1
07/31/2014 02:00	0.0	0	0	0	0	1
07/31/2014 03:00	0.0	0	0	0	0	1
07/31/2014 04:00	0.0	0	0	0	0	1
07/31/2014 05:00	0.0	0	0	0	0	1
07/31/2014 06:00	0.0	0	0	0	0	1
07/31/2014 07:00	0.0	0	0	0	0	1
07/31/2014 08:00	0.0	0	0	0	0	1
07/31/2014 09:00	0.0	0	0	0	0	1
07/31/2014 10:00	0.0	0	0	0	0	1
07/31/2014 11:00	0.0	0	0	0	0	1
07/31/2014 12:00	0.0	0	0	0	0	1
07/31/2014 13:00	0.0	0	0	0	0	1
07/31/2014 14:00	0.0	0	0	0	0	1
07/31/2014 15:00	0.0	0	0	0	0	1
07/31/2014 16:00	0.0	0	0	0	0	1
07/31/2014 17:00	0.0	0	0	0	0	1
07/31/2014 18:00	0.0	0	0	0	0	1
07/31/2014 19:00	0.0	0	0	0	0	1
07/31/2014 20:00	0.0	0	0	0	0	1
07/31/2014 21:00	0.0	0	0	0	0	1
07/31/2014 22:00	0.0	0	0	0	0	1
07/31/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/01/2014 00:00	0.0	0	0	0	0	1
08/01/2014 01:00	0.0	0	0	0	0	1
08/01/2014 02:00	0.0	0	0	0	0	1
08/01/2014 03:00	0.0	0	0	0	0	1
08/01/2014 04:00	0.0	0	0	0	0	1
08/01/2014 05:00	0.0	0	0	0	0	1
08/01/2014 06:00	0.0	0	0	0	0	1
08/01/2014 07:00	0.0	0	0	0	0	1
08/01/2014 08:00	0.0	0	0	0	0	1
08/01/2014 09:00	0.0	0	0	0	0	1
08/01/2014 10:00	0.0	0	0	0	0	1
08/01/2014 11:00	0.0	0	0	0	0	1
08/01/2014 12:00	0.0	0	0	0	0	1
08/01/2014 13:00	0.0	0	0	0	0	1
08/01/2014 14:00	0.0	0	0	0	0	1
08/01/2014 15:00	0.0	0	0	0	0	1
08/01/2014 16:00	0.0	0	0	0	0	1
08/01/2014 17:00	0.0	0	0	0	0	1
08/01/2014 18:00	0.0	0	0	0	0	1
08/01/2014 19:00	0.0	0	0	0	0	1
08/01/2014 20:00	0.0	0	0	0	0	1
08/01/2014 21:00	0.0	0	0	0	0	1
08/01/2014 22:00	0.0	0	0	0	0	1
08/01/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/02/2014 00:00	0.0	0	0	0	0	1
08/02/2014 01:00	0.0	0	0	0	0	1
08/02/2014 02:00	0.0	0	0	0	0	1
08/02/2014 03:00	0.0	0	0	0	0	1
08/02/2014 04:00	0.0	0	0	0	0	1
08/02/2014 05:00	0.0	0	0	0	0	1
08/02/2014 06:00	0.0	0	0	0	0	1
08/02/2014 07:00	0.0	0	0	0	0	1
08/02/2014 08:00	0.0	0	0	0	0	1
08/02/2014 09:00	0.0	0	0	0	0	1
08/02/2014 10:00	0.0	0	0	0	0	1
08/02/2014 11:00	0.0	0	0	0	0	1
08/02/2014 12:00	0.0	0	0	0	0	1
08/02/2014 13:00	0.0	0	0	0	0	1
08/02/2014 14:00	0.0	0	0	0	0	1
08/02/2014 15:00	0.0	0	0	0	0	1
08/02/2014 16:00	0.0	0	0	0	0	1
08/02/2014 17:00	0.0	0	0	0	0	1
08/02/2014 18:00	0.0	0	0	0	0	1
08/02/2014 19:00	0.0	0	0	0	0	1
08/02/2014 20:00	0.0	0	0	0	0	1
08/02/2014 21:00	0.0	0	0	0	0	1
08/02/2014 22:00	0.0	0	0	0	0	1
08/02/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/03/2014 00:00	0.0	0	0	0	0	1
08/03/2014 01:00	0.0	0	0	0	0	1
08/03/2014 02:00	0.0	0	0	0	0	1
08/03/2014 03:00	0.0	0	0	0	0	1
08/03/2014 04:00	0.0	0	0	0	0	1
08/03/2014 05:00	0.0	0	0	0	0	1
08/03/2014 06:00	0.0	0	0	0	0	1
08/03/2014 07:00	0.0	0	0	0	0	1
08/03/2014 08:00	0.0	0	0	0	0	1
08/03/2014 09:00	0.0	0	0	0	0	1
08/03/2014 10:00	0.0	0	0	0	0	1
08/03/2014 11:00	0.0	0	0	0	0	1
08/03/2014 12:00	0.0	0	0	0	0	1
08/03/2014 13:00	0.0	0	0	0	0	1
08/03/2014 14:00	0.0	0	0	0	0	1
08/03/2014 15:00	0.0	0	0	0	0	1
08/03/2014 16:00	0.0	0	0	0	0	1
08/03/2014 17:00	0.0	0	0	0	0	1
08/03/2014 18:00	0.0	0	0	0	0	1
08/03/2014 19:00	0.0	0	0	0	0	1
08/03/2014 20:00	0.0	0	0	0	0	1
08/03/2014 21:00	0.0	0	0	0	0	1
08/03/2014 22:00	0.0	0	0	0	0	1
08/03/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/04/2014 00:00	0.0	0	0	0	0	1
08/04/2014 01:00	0.0	0	0	0	0	1
08/04/2014 02:00	0.0	0	0	0	0	1
08/04/2014 03:00	0.0	0	0	0	0	1
08/04/2014 04:00	0.0	0	0	0	0	1
08/04/2014 05:00	0.0	0	0	0	0	1
08/04/2014 06:00	0.0	0	0	0	0	1
08/04/2014 07:00	0.0	0	0	0	0	1
08/04/2014 08:00	0.0	0	0	0	0	1
08/04/2014 09:00	0.0	0	0	0	0	1
08/04/2014 10:00	0.0	0	0	0	0	1
08/04/2014 11:00	0.0	0	0	0	0	1
08/04/2014 12:00	0.0	0	0	0	0	1
08/04/2014 13:00	0.0	0	0	0	0	1
08/04/2014 14:00	0.0	0	0	0	0	1
08/04/2014 15:00	0.0	0	0	0	0	1
08/04/2014 16:00	0.0	0	0	0	0	1
08/04/2014 17:00	0.0	0	0	0	0	1
08/04/2014 18:00	0.0	0	0	0	0	1
08/04/2014 19:00	0.0	0	0	0	0	1
08/04/2014 20:00	0.0	0	0	0	0	1
08/04/2014 21:00	0.0	0	0	0	0	1
08/04/2014 22:00	0.0	0	0	0	0	1
08/04/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/05/2014 00:00	0.0	0	0	0	0	1
08/05/2014 01:00	0.0	0	0	0	0	1
08/05/2014 02:00	0.0	0	0	0	0	1
08/05/2014 03:00	0.0	0	0	0	0	1
08/05/2014 04:00	0.0	0	0	0	0	1
08/05/2014 05:00	0.0	0	0	0	0	1
08/05/2014 06:00	0.0	0	0	0	0	1
08/05/2014 07:00	0.0	0	0	0	0	1
08/05/2014 08:00	0.0	0	0	0	0	1
08/05/2014 09:00	0.0	0	0	0	0	1
08/05/2014 10:00	0.0	0	0	0	0	1
08/05/2014 11:00	0.0	0	0	0	0	1
08/05/2014 12:00	0.0	0	0	0	0	1
08/05/2014 13:00	0.0	0	0	0	0	1
08/05/2014 14:00	0.0	0	0	0	0	1
08/05/2014 15:00	0.0	0	0	0	0	1
08/05/2014 16:00	0.0	0	0	0	0	1
08/05/2014 17:00	0.0	0	0	0	0	1
08/05/2014 18:00	0.0	0	0	0	0	1
08/05/2014 19:00	0.0	0	0	0	0	1
08/05/2014 20:00	0.0	0	0	0	0	1
08/05/2014 21:00	0.0	0	0	0	0	1
08/05/2014 22:00	0.0	0	0	0	0	1
08/05/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/06/2014 00:00	0.0	0	0	0	0	1
08/06/2014 01:00	0.0	0	0	0	0	1
08/06/2014 02:00	0.0	0	0	0	0	1
08/06/2014 03:00	0.0	0	0	0	0	1
08/06/2014 04:00	0.0	0	0	0	0	1
08/06/2014 05:00	0.0	0	0	0	0	1
08/06/2014 06:00	0.0	0	0	0	0	1
08/06/2014 07:00	0.0	0	0	0	0	1
08/06/2014 08:00	0.0	0	0	0	0	1
08/06/2014 09:00	0.0	0	0	0	0	1
08/06/2014 10:00	0.0	0	0	0	0	1
08/06/2014 11:00	0.0	0	0	0	0	1
08/06/2014 12:00	0.0	0	0	0	0	1
08/06/2014 13:00	0.0	0	0	0	0	1
08/06/2014 14:00	0.0	0	0	0	0	1
08/06/2014 15:00	0.0	0	0	0	0	1
08/06/2014 16:00	0.0	0	0	0	0	1
08/06/2014 17:00	0.0	0	0	0	0	1
08/06/2014 18:00	0.0	0	0	0	0	1
08/06/2014 19:00	0.0	0	0	0	0	1
08/06/2014 20:00	0.0	0	0	0	0	1
08/06/2014 21:00	0.0	0	0	0	0	1
08/06/2014 22:00	0.0	0	0	0	0	1
08/06/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/07/2014 00:00	1.2	0	0	0	1	0
08/07/2014 01:00	0.0	0	0	0	0	0
08/07/2014 02:00	0.0	0	0	0	0	0
08/07/2014 03:00	0.0	0	0	0	0	0
08/07/2014 04:00	0.0	0	0	0	0	0
08/07/2014 05:00	0.0	0	0	0	0	0
08/07/2014 06:00	0.0	0	0	0	0	0
08/07/2014 07:00	27.3	0	0	1	0	0
08/07/2014 08:00	26.8	0	0	1	0	0
08/07/2014 09:00	0.0	0	0	0	0	1
08/07/2014 10:00	0.0	0	0	0	0	1
08/07/2014 11:00	0.0	0	0	0	0	1
08/07/2014 12:00	0.0	0	0	0	0	1
08/07/2014 13:00	0.0	0	0	0	0	1
08/07/2014 14:00	0.0	0	0	0	0	1
08/07/2014 15:00	0.0	0	0	0	0	1
08/07/2014 16:00	0.0	0	0	0	0	1
08/07/2014 17:00	0.0	0	0	0	0	1
08/07/2014 18:00	0.0	0	0	0	0	1
08/07/2014 19:00	0.0	0	0	0	0	1
08/07/2014 20:00	0.0	0	0	0	0	1
08/07/2014 21:00	0.0	0	0	0	0	1
08/07/2014 22:00	0.0	0	0	0	0	1
08/07/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	55.3 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	27.3	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/08/2014 00:00	0.0	0	0	0	0	1
08/08/2014 01:00	0.0	0	0	0	0	1
08/08/2014 02:00	0.0	0	0	0	0	1
08/08/2014 03:00	0.0	0	0	0	0	1
08/08/2014 04:00	0.0	0	0	0	0	1
08/08/2014 05:00	0.0	0	0	0	0	1
08/08/2014 06:00	0.0	0	0	0	0	1
08/08/2014 07:00	0.0	0	0	0	0	1
08/08/2014 08:00	0.0	0	0	0	0	1
08/08/2014 09:00	0.0	0	0	0	0	1
08/08/2014 10:00	0.0	0	0	0	0	1
08/08/2014 11:00	0.0	0	0	0	0	1
08/08/2014 12:00	0.0	0	0	0	0	1
08/08/2014 13:00	0.0	0	0	0	0	1
08/08/2014 14:00	0.0	0	0	0	0	1
08/08/2014 15:00	0.0	0	0	0	0	1
08/08/2014 16:00	0.0	0	0	0	0	1
08/08/2014 17:00	0.0	0	0	0	0	1
08/08/2014 18:00	0.0	0	0	0	0	1
08/08/2014 19:00	0.0	0	0	0	0	1
08/08/2014 20:00	0.0	0	0	0	0	1
08/08/2014 21:00	0.0	0	0	0	0	1
08/08/2014 22:00	0.0	0	0	0	0	1
08/08/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/09/2014 00:00	0.0	0	0	0	0	1
08/09/2014 01:00	0.0	0	0	0	0	1
08/09/2014 02:00	3.5	0	0	0	1	0
08/09/2014 03:00	0.0	0	0	0	0	0
08/09/2014 04:00	0.0	0	0	0	0	0
08/09/2014 05:00	0.0	0	0	0	0	0
08/09/2014 06:00	35.7	0	0	1	0	0
08/09/2014 07:00	0.2	0	0	1	0	0
08/09/2014 08:00	0.0	0	0	0	0	1
08/09/2014 09:00	0.0	0	0	0	0	1
08/09/2014 10:00	0.0	0	0	0	0	1
08/09/2014 11:00	0.0	0	0	0	0	1
08/09/2014 12:00	0.0	0	0	0	0	1
08/09/2014 13:00	0.0	0	0	0	0	1
08/09/2014 14:00	0.0	0	0	0	0	1
08/09/2014 15:00	0.0	0	0	0	0	1
08/09/2014 16:00	0.0	0	0	0	0	1
08/09/2014 17:00	0.0	0	0	0	0	1
08/09/2014 18:00	0.0	0	0	0	0	1
08/09/2014 19:00	0.0	0	0	0	0	1
08/09/2014 20:00	0.0	0	0	0	0	1
08/09/2014 21:00	0.0	0	0	0	0	1
08/09/2014 22:00	0.0	0	0	0	0	1
08/09/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	39.4 #	0 #	0 #	2 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	35.7	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/10/2014 00:00	2.8	0	0	0	1	0
08/10/2014 01:00	0.0	0	0	0	0	0
08/10/2014 02:00	0.0	0	0	0	0	0
08/10/2014 03:00	0.0	0	0	0	0	0
08/10/2014 04:00	0.0	0	0	0	0	0
08/10/2014 05:00	0.0	0	0	0	0	0
08/10/2014 06:00	0.0	0	0	0	0	0
08/10/2014 07:00	33.6	0	0	1	0	0
08/10/2014 08:00	6.9	0	0	1	0	0
08/10/2014 09:00	0.0	0	0	0	0	1
08/10/2014 10:00	0.0	0	0	0	0	1
08/10/2014 11:00	0.0	0	0	0	0	1
08/10/2014 12:00	0.0	0	0	0	0	1
08/10/2014 13:00	0.0	0	0	0	0	1
08/10/2014 14:00	0.0	0	0	0	0	1
08/10/2014 15:00	0.0	0	0	0	0	1
08/10/2014 16:00	0.0	0	0	0	0	1
08/10/2014 17:00	0.0	0	0	0	0	1
08/10/2014 18:00	0.0	0	0	0	0	1
08/10/2014 19:00	0.0	0	0	0	0	1
08/10/2014 20:00	0.0	0	0	0	0	1
08/10/2014 21:00	0.0	0	0	0	0	1
08/10/2014 22:00	0.0	0	0	0	0	1
08/10/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	43.3 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	33.6	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/11/2014 00:00	0.0	0	0	0	0	1
08/11/2014 01:00	0.0	0	0	0	0	1
08/11/2014 02:00	0.0	0	0	0	0	1
08/11/2014 03:00	0.0	0	0	0	0	1
08/11/2014 04:00	0.0	0	0	0	0	1
08/11/2014 05:00	0.0	0	0	0	0	1
08/11/2014 06:00	0.0	0	0	0	0	1
08/11/2014 07:00	0.0	0	0	0	0	1
08/11/2014 08:00	0.0	0	0	0	0	1
08/11/2014 09:00	0.0	0	0	0	0	1
08/11/2014 10:00	0.0	0	0	0	0	1
08/11/2014 11:00	0.0	0	0	0	0	1
08/11/2014 12:00	0.0	0	0	0	0	1
08/11/2014 13:00	0.0	0	0	0	0	1
08/11/2014 14:00	0.0	0	0	0	0	1
08/11/2014 15:00	0.0	0	0	0	0	1
08/11/2014 16:00	0.0	0	0	0	0	1
08/11/2014 17:00	0.0	0	0	0	0	1
08/11/2014 18:00	0.0	0	0	0	0	1
08/11/2014 19:00	0.0	0	0	0	0	1
08/11/2014 20:00	0.0	0	0	0	0	1
08/11/2014 21:00	0.0	0	0	0	0	1
08/11/2014 22:00	0.0	0	0	0	0	1
08/11/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/12/2014 00:00	0.0	0	0	0	0	1
08/12/2014 01:00	0.0	0	0	0	0	1
08/12/2014 02:00	0.0	0	0	0	0	1
08/12/2014 03:00	0.0	0	0	0	0	1
08/12/2014 04:00	0.0	0	0	0	0	1
08/12/2014 05:00	0.0	0	0	0	0	1
08/12/2014 06:00	0.0	0	0	0	0	1
08/12/2014 07:00	0.0	0	0	0	0	1
08/12/2014 08:00	0.0	0	0	0	0	1
08/12/2014 09:00	0.0	0	0	0	0	1
08/12/2014 10:00	0.0	0	0	0	0	1
08/12/2014 11:00	0.0	0	0	0	0	1
08/12/2014 12:00	0.0	0	0	0	0	1
08/12/2014 13:00	0.0	0	0	0	0	1
08/12/2014 14:00	0.0	0	0	0	0	1
08/12/2014 15:00	0.0	0	0	0	0	1
08/12/2014 16:00	0.0	0	0	0	0	1
08/12/2014 17:00	0.0	0	0	0	0	1
08/12/2014 18:00	0.0	0	0	0	0	1
08/12/2014 19:00	0.0	0	0	0	0	1
08/12/2014 20:00	0.0	0	0	0	0	1
08/12/2014 21:00	0.0	0	0	0	0	1
08/12/2014 22:00	0.0	0	0	0	0	1
08/12/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/13/2014 00:00	0.0	0	0	0	0	1
08/13/2014 01:00	2.1	0	0	0	1	0
08/13/2014 02:00	0.0	0	0	0	0	0
08/13/2014 03:00	0.0	0	0	0	0	0
08/13/2014 04:00	0.0	0	0	0	0	0
08/13/2014 05:00	18.4	0	0	1	0	0
08/13/2014 06:00	0.0	0	0	1	0	0
08/13/2014 07:00	0.0	0	0	0	0	1
08/13/2014 08:00	0.0	0	0	0	0	1
08/13/2014 09:00	0.0	0	0	0	0	1
08/13/2014 10:00	0.0	0	0	0	0	1
08/13/2014 11:00	0.0	0	0	0	0	1
08/13/2014 12:00	0.0	0	0	0	0	1
08/13/2014 13:00	0.0	0	0	0	0	1
08/13/2014 14:00	0.0	0	0	0	0	1
08/13/2014 15:00	0.0	0	0	0	0	1
08/13/2014 16:00	0.0	0	0	0	0	1
08/13/2014 17:00	0.0	0	0	0	0	1
08/13/2014 18:00	0.0	0	0	0	0	1
08/13/2014 19:00	0.0	0	0	0	0	1
08/13/2014 20:00	0.0	0	0	0	0	1
08/13/2014 21:00	0.0	0	0	0	0	1
08/13/2014 22:00	0.0	0	0	0	0	1
08/13/2014 23:00	2.3	0	0	0	1	0
Average/Sum#:	22.8 #	0 #	0 #	2 #	2 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	18.4	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/14/2014 00:00	0.0	0	0	0	0	0
08/14/2014 01:00	0.0	0	0	0	0	0
08/14/2014 02:00	0.0	0	0	0	0	0
08/14/2014 03:00	0.0	0	0	0	0	0
08/14/2014 04:00	0.0	0	0	0	0	0
08/14/2014 05:00	0.0	0	0	0	0	0
08/14/2014 06:00	0.0	0	0	0	0	0
08/14/2014 07:00	0.0	0	0	0	0	0
08/14/2014 08:00	0.0	0	0	0	0	0
08/14/2014 09:00	0.0	0	0	0	0	0
08/14/2014 10:00	0.0	0	0	0	0	0
08/14/2014 11:00	0.0	0	0	0	0	0
08/14/2014 12:00	0.0	0	0	0	0	0
08/14/2014 13:00	0.0	0	0	0	0	0
08/14/2014 14:00	0.0	0	0	0	0	0
08/14/2014 15:00	0.0	0	0	0	0	0
08/14/2014 16:00	0.0	0	0	0	0	0
08/14/2014 17:00	0.0	0	0	0	0	0
08/14/2014 18:00	0.0	0	0	0	0	0
08/14/2014 19:00	0.0	0	0	0	0	0
08/14/2014 20:00	0.0	0	0	0	0	0
08/14/2014 21:00	0.0	0	0	0	0	0
08/14/2014 22:00	0.0	0	0	0	0	0
08/14/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/15/2014 00:00	0.0	0	0	0	0	0
08/15/2014 01:00	0.0	0	0	0	0	0
08/15/2014 02:00	0.0	0	0	0	0	0
08/15/2014 03:00	0.0	0	0	0	0	0
08/15/2014 04:00	0.0	0	0	0	0	0
08/15/2014 05:00	0.0	0	0	0	0	0
08/15/2014 06:00	0.0	0	0	0	0	0
08/15/2014 07:00	0.0	0	0	0	0	0
08/15/2014 08:00	0.0	0	0	0	0	0
08/15/2014 09:00	0.0	0	0	0	0	0
08/15/2014 10:00	0.0	0	0	0	0	0
08/15/2014 11:00	0.0	0	0	0	0	0
08/15/2014 12:00	0.0	0	0	0	0	0
08/15/2014 13:00	0.0	0	0	0	0	0
08/15/2014 14:00	0.0	0	0	0	0	0
08/15/2014 15:00	0.0	0	0	0	0	0
08/15/2014 16:00	0.0	0	0	0	0	0
08/15/2014 17:00	0.0	0	0	0	0	0
08/15/2014 18:00	0.0	0	0	0	0	0
08/15/2014 19:00	0.0	0	0	0	0	0
08/15/2014 20:00	0.0	0	0	0	0	0
08/15/2014 21:00	0.0	0	0	0	0	0
08/15/2014 22:00	0.0	0	0	0	0	0
08/15/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/16/2014 00:00	0.0	0	0	0	0	0
08/16/2014 01:00	0.0	0	0	0	0	0
08/16/2014 02:00	0.0	0	0	0	0	0
08/16/2014 03:00	0.0	0	0	0	0	0
08/16/2014 04:00	0.0	0	0	0	0	0
08/16/2014 05:00	0.0	0	0	0	0	0
08/16/2014 06:00	0.0	0	0	0	0	0
08/16/2014 07:00	0.0	0	0	0	0	0
08/16/2014 08:00	0.0	0	0	0	0	0
08/16/2014 09:00	0.0	0	0	0	0	0
08/16/2014 10:00	0.0	0	0	0	0	0
08/16/2014 11:00	0.0	0	0	0	0	0
08/16/2014 12:00	0.0	0	0	0	0	0
08/16/2014 13:00	0.0	0	0	0	0	0
08/16/2014 14:00	0.0	0	0	0	0	0
08/16/2014 15:00	0.0	0	0	0	0	0
08/16/2014 16:00	0.0	0	0	0	0	0
08/16/2014 17:00	0.0	0	0	0	0	0
08/16/2014 18:00	0.0	0	0	0	0	0
08/16/2014 19:00	0.0	0	0	0	0	0
08/16/2014 20:00	0.0	0	0	0	0	0
08/16/2014 21:00	0.0	0	0	0	0	0
08/16/2014 22:00	0.0	0	0	0	0	0
08/16/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/17/2014 00:00	0.0	0	0	0	0	0
08/17/2014 01:00	0.0	0	0	0	0	0
08/17/2014 02:00	0.0	0	0	0	0	0
08/17/2014 03:00	0.0	0	0	0	0	0
08/17/2014 04:00	0.0	0	0	0	0	0
08/17/2014 05:00	0.0	0	0	0	0	0
08/17/2014 06:00	0.0	0	0	0	0	0
08/17/2014 07:00	0.0	0	0	0	0	0
08/17/2014 08:00	0.0	0	0	0	0	0
08/17/2014 09:00	0.0	0	0	0	0	0
08/17/2014 10:00	0.0	0	0	0	0	0
08/17/2014 11:00	0.0	0	0	0	0	0
08/17/2014 12:00	0.0	0	0	0	0	0
08/17/2014 13:00	0.0	0	0	0	0	0
08/17/2014 14:00	0.0	0	0	0	0	0
08/17/2014 15:00	0.0	0	0	0	0	0
08/17/2014 16:00	0.0	0	0	0	0	0
08/17/2014 17:00	0.0	0	0	0	0	0
08/17/2014 18:00	0.0	0	0	0	0	0
08/17/2014 19:00	0.0	0	0	0	0	0
08/17/2014 20:00	0.0	0	0	0	0	0
08/17/2014 21:00	0.0	0	0	0	0	0
08/17/2014 22:00	0.0	0	0	0	0	0
08/17/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/18/2014 00:00	0.0	0	0	0	0	0
08/18/2014 01:00	0.0	0	0	0	0	0
08/18/2014 02:00	0.0	0	0	0	0	0
08/18/2014 03:00	0.0	0	0	0	0	0
08/18/2014 04:00	0.0	0	0	0	0	0
08/18/2014 05:00	0.0	0	0	0	0	0
08/18/2014 06:00	0.0	0	0	0	0	0
08/18/2014 07:00	0.0	0	0	0	0	0
08/18/2014 08:00	0.0	0	0	0	0	0
08/18/2014 09:00	0.0	0	0	0	0	0
08/18/2014 10:00	0.0	0	0	0	0	0
08/18/2014 11:00	0.0	0	0	0	0	0
08/18/2014 12:00	0.0	0	0	0	0	0
08/18/2014 13:00	0.0	0	0	0	0	0
08/18/2014 14:00	0.0	0	0	0	0	0
08/18/2014 15:00	0.0	0	0	0	0	0
08/18/2014 16:00	0.0	0	0	0	0	0
08/18/2014 17:00	0.0	0	0	0	0	0
08/18/2014 18:00	0.0	0	0	0	0	0
08/18/2014 19:00	0.0	0	0	0	0	0
08/18/2014 20:00	0.0	0	0	0	0	0
08/18/2014 21:00	0.0	0	0	0	0	0
08/18/2014 22:00	0.0	0	0	0	0	0
08/18/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/19/2014 00:00	0.0	0	0	0	0	0
08/19/2014 01:00	0.0	0	0	0	0	0
08/19/2014 02:00	0.0	0	0	0	0	0
08/19/2014 03:00	0.0	0	0	0	0	0
08/19/2014 04:00	0.0	0	0	0	0	0
08/19/2014 05:00	0.0	0	0	0	0	0
08/19/2014 06:00	0.0	0	0	0	0	0
08/19/2014 07:00	0.0	0	0	0	0	0
08/19/2014 08:00	0.0	0	0	0	0	0
08/19/2014 09:00	0.0	0	0	0	0	0
08/19/2014 10:00	0.0	0	0	0	0	0
08/19/2014 11:00	0.0	0	0	0	0	0
08/19/2014 12:00	0.0	0	0	0	0	0
08/19/2014 13:00	0.0	0	0	0	0	0
08/19/2014 14:00	0.0	0	0	0	0	0
08/19/2014 15:00	0.0	0	0	0	0	0
08/19/2014 16:00	0.0	0	0	0	0	0
08/19/2014 17:00	0.0	0	0	0	0	0
08/19/2014 18:00	0.0	0	0	0	0	0
08/19/2014 19:00	0.0	0	0	0	0	0
08/19/2014 20:00	0.0	0	0	0	0	0
08/19/2014 21:00	0.0	0	0	0	0	0
08/19/2014 22:00	0.0	0	0	0	0	0
08/19/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/20/2014 00:00	0.0	0	0	0	0	0
08/20/2014 01:00	0.0	0	0	0	0	0
08/20/2014 02:00	0.0	0	0	0	0	0
08/20/2014 03:00	0.0	0	0	0	0	0
08/20/2014 04:00	0.0	0	0	0	0	0
08/20/2014 05:00	0.0	0	0	0	0	0
08/20/2014 06:00	0.0	0	0	0	0	0
08/20/2014 07:00	0.0	0	0	0	0	0
08/20/2014 08:00	0.0	0	0	0	0	0
08/20/2014 09:00	0.0	0	0	0	0	0
08/20/2014 10:00	0.0	0	0	0	0	0
08/20/2014 11:00	0.0	0	0	0	0	0
08/20/2014 12:00	0.0	0	0	0	0	0
08/20/2014 13:00	0.0	0	0	0	0	0
08/20/2014 14:00	0.0	0	0	0	0	0
08/20/2014 15:00	0.0	0	0	0	0	0
08/20/2014 16:00	0.0	0	0	0	0	0
08/20/2014 17:00	0.0	0	0	0	0	0
08/20/2014 18:00	0.0	0	0	0	0	0
08/20/2014 19:00	0.0	0	0	0	0	0
08/20/2014 20:00	0.0	0	0	0	0	0
08/20/2014 21:00	0.0	0	0	0	0	0
08/20/2014 22:00	0.0	0	0	0	0	0
08/20/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/21/2014 00:00	0.0	0	0	0	0	0
08/21/2014 01:00	0.0	0	0	0	0	0
08/21/2014 02:00	0.0	0	0	0	0	0
08/21/2014 03:00	0.0	0	0	0	0	0
08/21/2014 04:00	0.0	0	0	0	0	0
08/21/2014 05:00	0.0	0	0	0	0	0
08/21/2014 06:00	0.0	0	0	0	0	0
08/21/2014 07:00	0.0	0	0	0	0	0
08/21/2014 08:00	0.0	0	0	0	0	0
08/21/2014 09:00	0.0	0	0	0	0	0
08/21/2014 10:00	0.0	0	0	0	0	0
08/21/2014 11:00	0.0	0	0	0	0	0
08/21/2014 12:00	0.0	0	0	0	0	0
08/21/2014 13:00	0.0	0	0	0	0	0
08/21/2014 14:00	0.0	0	0	0	0	0
08/21/2014 15:00	0.0	0	0	0	0	0
08/21/2014 16:00	0.0	0	0	0	0	0
08/21/2014 17:00	0.0	0	0	0	0	0
08/21/2014 18:00	0.0	0	0	0	0	0
08/21/2014 19:00	0.0	0	0	0	0	0
08/21/2014 20:00	0.0	0	0	0	0	0
08/21/2014 21:00	0.0	0	0	0	0	0
08/21/2014 22:00	0.0	0	0	0	0	0
08/21/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/22/2014 00:00	0.0	0	0	0	0	0
08/22/2014 01:00	0.0	0	0	0	0	0
08/22/2014 02:00	0.0	0	0	0	0	0
08/22/2014 03:00	0.0	0	0	0	0	0
08/22/2014 04:00	0.0	0	0	0	0	0
08/22/2014 05:00	0.0	0	0	0	0	0
08/22/2014 06:00	0.0	0	0	0	0	0
08/22/2014 07:00	0.0	0	0	0	0	0
08/22/2014 08:00	0.0	0	0	0	0	0
08/22/2014 09:00	0.0	0	0	0	0	0
08/22/2014 10:00	0.0	0	0	0	0	0
08/22/2014 11:00	0.0	0	0	0	0	0
08/22/2014 12:00	0.0	0	0	0	0	0
08/22/2014 13:00	0.0	0	0	0	0	0
08/22/2014 14:00	0.0	0	0	0	0	0
08/22/2014 15:00	0.0	0	0	0	0	0
08/22/2014 16:00	0.0	0	0	0	0	0
08/22/2014 17:00	0.0	0	0	0	0	0
08/22/2014 18:00	0.0	0	0	0	0	0
08/22/2014 19:00	0.0	0	0	0	0	0
08/22/2014 20:00	0.0	0	0	0	0	0
08/22/2014 21:00	0.0	0	0	0	0	0
08/22/2014 22:00	0.0	0	0	0	0	0
08/22/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/23/2014 00:00	0.0	0	0	0	0	0
08/23/2014 01:00	0.0	0	0	0	0	0
08/23/2014 02:00	0.0	0	0	0	0	0
08/23/2014 03:00	0.0	0	0	0	0	0
08/23/2014 04:00	0.0	0	0	0	0	0
08/23/2014 05:00	0.0	0	0	0	0	0
08/23/2014 06:00	0.0	0	0	0	0	0
08/23/2014 07:00	0.0	0	0	0	0	0
08/23/2014 08:00	0.0	0	0	0	0	0
08/23/2014 09:00	0.0	0	0	0	0	0
08/23/2014 10:00	0.0	0	0	0	0	0
08/23/2014 11:00	0.0	0	0	0	0	0
08/23/2014 12:00	0.0	0	0	0	0	0
08/23/2014 13:00	0.0	0	0	0	0	0
08/23/2014 14:00	0.0	0	0	0	0	0
08/23/2014 15:00	0.0	0	0	0	0	0
08/23/2014 16:00	0.0	0	0	0	0	0
08/23/2014 17:00	0.0	0	0	0	0	0
08/23/2014 18:00	0.0	0	0	0	0	0
08/23/2014 19:00	0.0	0	0	0	0	0
08/23/2014 20:00	0.0	0	0	0	0	0
08/23/2014 21:00	0.0	0	0	0	0	0
08/23/2014 22:00	0.0	0	0	0	0	0
08/23/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/24/2014 00:00	0.0	0	0	0	0	0
08/24/2014 01:00	0.0	0	0	0	0	0
08/24/2014 02:00	0.0	0	0	0	0	0
08/24/2014 03:00	0.0	0	0	0	0	0
08/24/2014 04:00	0.0	0	0	0	0	0
08/24/2014 05:00	0.0	0	0	0	0	0
08/24/2014 06:00	0.0	0	0	0	0	0
08/24/2014 07:00	0.0	0	0	0	0	0
08/24/2014 08:00	0.0	0	0	0	0	0
08/24/2014 09:00	0.0	0	0	0	0	0
08/24/2014 10:00	0.0	0	0	0	0	0
08/24/2014 11:00	0.0	0	0	0	0	0
08/24/2014 12:00	0.0	0	0	0	0	0
08/24/2014 13:00	0.0	0	0	0	0	0
08/24/2014 14:00	0.0	0	0	0	0	0
08/24/2014 15:00	0.0	0	0	0	0	0
08/24/2014 16:00	0.0	0	0	0	0	0
08/24/2014 17:00	0.0	0	0	0	0	0
08/24/2014 18:00	0.0	0	0	0	0	0
08/24/2014 19:00	0.0	0	0	0	0	0
08/24/2014 20:00	0.0	0	0	0	0	0
08/24/2014 21:00	0.0	0	0	0	0	0
08/24/2014 22:00	0.0	0	0	0	0	0
08/24/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/25/2014 00:00	0.0	0	0	0	0	0
08/25/2014 01:00	0.0	0	0	0	0	0
08/25/2014 02:00	0.0	0	0	0	0	0
08/25/2014 03:00	0.0	0	0	0	0	0
08/25/2014 04:00	0.0	0	0	0	0	0
08/25/2014 05:00	0.0	0	0	0	0	0
08/25/2014 06:00	0.0	0	0	0	0	0
08/25/2014 07:00	0.0	0	0	0	0	0
08/25/2014 08:00	0.0	0	0	0	0	0
08/25/2014 09:00	0.0	0	0	0	0	0
08/25/2014 10:00	0.0	0	0	0	0	0
08/25/2014 11:00	0.0	0	0	0	0	0
08/25/2014 12:00	0.0	0	0	0	0	0
08/25/2014 13:00	0.0	0	0	0	0	0
08/25/2014 14:00	0.0	0	0	0	0	0
08/25/2014 15:00	0.0	0	0	0	0	0
08/25/2014 16:00	0.0	0	0	0	0	0
08/25/2014 17:00	0.0	0	0	0	0	0
08/25/2014 18:00	0.0	0	0	0	0	0
08/25/2014 19:00	0.0	0	0	0	0	0
08/25/2014 20:00	0.0	0	0	0	0	0
08/25/2014 21:00	0.0	0	0	0	0	0
08/25/2014 22:00	0.0	0	0	0	0	0
08/25/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/26/2014 00:00	0.0	0	0	0	0	0
08/26/2014 01:00	0.0	0	0	0	0	0
08/26/2014 02:00	0.0	0	0	0	0	0
08/26/2014 03:00	0.0	0	0	0	0	0
08/26/2014 04:00	0.0	0	0	0	0	0
08/26/2014 05:00	0.0	0	0	0	0	0
08/26/2014 06:00	0.0	0	0	0	0	0
08/26/2014 07:00	0.0	0	0	0	0	0
08/26/2014 08:00	0.0	0	0	0	0	0
08/26/2014 09:00	0.0	0	0	0	0	0
08/26/2014 10:00	0.0	0	0	0	0	0
08/26/2014 11:00	0.0	0	0	0	0	0
08/26/2014 12:00	0.0	0	0	0	0	0
08/26/2014 13:00	0.0	0	0	0	0	0
08/26/2014 14:00	0.0	0	0	0	0	0
08/26/2014 15:00	0.0	0	0	0	0	0
08/26/2014 16:00	0.0	0	0	0	0	0
08/26/2014 17:00	0.0	0	0	0	0	0
08/26/2014 18:00	0.0	0	0	0	0	0
08/26/2014 19:00	0.0	0	0	0	0	0
08/26/2014 20:00	0.0	0	0	0	0	0
08/26/2014 21:00	0.0	0	0	0	0	0
08/26/2014 22:00	0.0	0	0	0	0	0
08/26/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/27/2014 00:00	0.0	0	0	0	0	0
08/27/2014 01:00	0.0	0	0	0	0	0
08/27/2014 02:00	0.0	0	0	0	0	0
08/27/2014 03:00	0.0	0	0	0	0	0
08/27/2014 04:00	0.0	0	0	0	0	0
08/27/2014 05:00	0.0	0	0	0	0	0
08/27/2014 06:00	0.0	0	0	0	0	0
08/27/2014 07:00	0.0	0	0	0	0	0
08/27/2014 08:00	0.0	0	0	0	0	0
08/27/2014 09:00	0.0	0	0	0	0	0
08/27/2014 10:00	0.0	0	0	0	0	0
08/27/2014 11:00	0.0	0	0	0	0	0
08/27/2014 12:00	0.0	0	0	0	0	0
08/27/2014 13:00	0.0	0	0	0	0	0
08/27/2014 14:00	0.0	0	0	0	0	0
08/27/2014 15:00	0.0	0	0	0	0	0
08/27/2014 16:00	0.0	0	0	0	0	0
08/27/2014 17:00	0.0	0	0	0	0	0
08/27/2014 18:00	0.0	0	0	0	0	0
08/27/2014 19:00	0.0	0	0	0	0	0
08/27/2014 20:00	0.0	0	0	0	0	0
08/27/2014 21:00	0.0	0	0	0	0	0
08/27/2014 22:00	0.0	0	0	0	0	0
08/27/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/28/2014 00:00	0.0	0	0	0	0	0
08/28/2014 01:00	0.0	0	0	0	0	0
08/28/2014 02:00	0.0	0	0	0	0	0
08/28/2014 03:00	0.0	0	0	0	0	0
08/28/2014 04:00	0.0	0	0	0	0	0
08/28/2014 05:00	0.0	0	0	0	0	0
08/28/2014 06:00	0.0	0	0	0	0	0
08/28/2014 07:00	0.0	0	0	0	0	0
08/28/2014 08:00	0.0	0	0	0	0	0
08/28/2014 09:00	0.0	0	0	0	0	0
08/28/2014 10:00	0.0	0	0	0	0	0
08/28/2014 11:00	0.0	0	0	0	0	0
08/28/2014 12:00	0.0	0	0	0	0	0
08/28/2014 13:00	0.0	0	0	0	0	0
08/28/2014 14:00	0.0	0	0	0	0	0
08/28/2014 15:00	0.0	0	0	0	0	0
08/28/2014 16:00	0.0	0	0	0	0	0
08/28/2014 17:00	0.0	0	0	0	0	0
08/28/2014 18:00	0.0	0	0	0	0	0
08/28/2014 19:00	0.0	0	0	0	0	0
08/28/2014 20:00	0.0	0	0	0	0	0
08/28/2014 21:00	0.0	0	0	0	0	0
08/28/2014 22:00	0.0	0	0	0	0	0
08/28/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/29/2014 00:00	0.0	0	0	0	0	0
08/29/2014 01:00	0.0	0	0	0	0	0
08/29/2014 02:00	0.0	0	0	0	0	0
08/29/2014 03:00	0.0	0	0	0	0	0
08/29/2014 04:00	0.0	0	0	0	0	0
08/29/2014 05:00	0.0	0	0	0	0	0
08/29/2014 06:00	0.0	0	0	0	0	0
08/29/2014 07:00	0.0	0	0	0	0	0
08/29/2014 08:00	0.0	0	0	0	0	0
08/29/2014 09:00	0.0	0	0	0	0	0
08/29/2014 10:00	0.0	0	0	0	0	0
08/29/2014 11:00	0.0	0	0	0	0	0
08/29/2014 12:00	0.0	0	0	0	0	0
08/29/2014 13:00	0.0	0	0	0	0	0
08/29/2014 14:00	0.0	0	0	0	0	0
08/29/2014 15:00	0.0	0	0	0	0	0
08/29/2014 16:00	0.0	0	0	0	0	0
08/29/2014 17:00	0.0	0	0	0	0	0
08/29/2014 18:00	0.0	0	0	0	0	0
08/29/2014 19:00	0.0	0	0	0	0	0
08/29/2014 20:00	0.0	0	0	0	0	0
08/29/2014 21:00	0.0	0	0	0	0	0
08/29/2014 22:00	0.0	0	0	0	0	0
08/29/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/30/2014 00:00	0.0	0	0	0	0	0
08/30/2014 01:00	0.0	0	0	0	0	0
08/30/2014 02:00	0.0	0	0	0	0	0
08/30/2014 03:00	0.0	0	0	0	0	0
08/30/2014 04:00	0.0	0	0	0	0	0
08/30/2014 05:00	0.0	0	0	0	0	0
08/30/2014 06:00	0.0	0	0	0	0	0
08/30/2014 07:00	0.0	0	0	0	0	0
08/30/2014 08:00	0.0	0	0	0	0	0
08/30/2014 09:00	0.0	0	0	0	0	0
08/30/2014 10:00	0.0	0	0	0	0	0
08/30/2014 11:00	0.0	0	0	0	0	0
08/30/2014 12:00	0.0	0	0	0	0	0
08/30/2014 13:00	0.0	0	0	0	0	0
08/30/2014 14:00	0.0	0	0	0	0	0
08/30/2014 15:00	0.0	0	0	0	0	0
08/30/2014 16:00	0.0	0	0	0	0	0
08/30/2014 17:00	0.0	0	0	0	0	0
08/30/2014 18:00	0.0	0	0	0	0	0
08/30/2014 19:00	0.0	0	0	0	0	0
08/30/2014 20:00	0.0	0	0	0	0	0
08/30/2014 21:00	0.0	0	0	0	0	0
08/30/2014 22:00	0.0	0	0	0	0	0
08/30/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/31/2014 00:00	0.0	0	0	0	0	0
08/31/2014 01:00	0.0	0	0	0	0	0
08/31/2014 02:00	0.0	0	0	0	0	0
08/31/2014 03:00	0.0	0	0	0	0	0
08/31/2014 04:00	0.0	0	0	0	0	0
08/31/2014 05:00	0.0	0	0	0	0	0
08/31/2014 06:00	0.0	0	0	0	0	0
08/31/2014 07:00	0.0	0	0	0	0	0
08/31/2014 08:00	0.0	0	0	0	0	0
08/31/2014 09:00	0.0	0	0	0	0	0
08/31/2014 10:00	0.0	0	0	0	0	0
08/31/2014 11:00	0.0	0	0	0	0	0
08/31/2014 12:00	0.0	0	0	0	0	0
08/31/2014 13:00	0.0	0	0	0	0	0
08/31/2014 14:00	0.0	0	0	0	0	0
08/31/2014 15:00	0.0	0	0	0	0	0
08/31/2014 16:00	0.0	0	0	0	0	0
08/31/2014 17:00	0.0	0	0	0	0	0
08/31/2014 18:00	0.0	0	0	0	0	0
08/31/2014 19:00	0.0	0	0	0	0	0
08/31/2014 20:00	0.0	0	0	0	0	0
08/31/2014 21:00	0.0	0	0	0	0	0
08/31/2014 22:00	0.0	0	0	0	0	0
08/31/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/01/2014 00:00	0.0	0	0	0	0	0
09/01/2014 01:00	0.0	0	0	0	0	0
09/01/2014 02:00	0.0	0	0	0	0	0
09/01/2014 03:00	0.0	0	0	0	0	0
09/01/2014 04:00	0.0	0	0	0	0	0
09/01/2014 05:00	0.0	0	0	0	0	0
09/01/2014 06:00	0.0	0	0	0	0	0
09/01/2014 07:00	0.0	0	0	0	0	0
09/01/2014 08:00	0.0	0	0	0	0	0
09/01/2014 09:00	0.0	0	0	0	0	0
09/01/2014 10:00	0.0	0	0	0	0	0
09/01/2014 11:00	0.0	0	0	0	0	0
09/01/2014 12:00	0.0	0	0	0	0	0
09/01/2014 13:00	0.0	0	0	0	0	0
09/01/2014 14:00	0.0	0	0	0	0	0
09/01/2014 15:00	0.0	0	0	0	0	0
09/01/2014 16:00	0.0	0	0	0	0	0
09/01/2014 17:00	0.0	0	0	0	0	0
09/01/2014 18:00	0.0	0	0	0	0	0
09/01/2014 19:00	0.0	0	0	0	0	0
09/01/2014 20:00	0.0	0	0	0	0	0
09/01/2014 21:00	0.0	0	0	0	0	0
09/01/2014 22:00	0.0	0	0	0	0	0
09/01/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/02/2014 00:00	0.0	0	0	0	0	0
09/02/2014 01:00	0.0	0	0	0	0	0
09/02/2014 02:00	0.0	0	0	0	0	0
09/02/2014 03:00	0.0	0	0	0	0	0
09/02/2014 04:00	0.0	0	0	0	0	0
09/02/2014 05:00	0.0	0	0	0	0	0
09/02/2014 06:00	0.0	0	0	0	0	0
09/02/2014 07:00	0.0	0	0	0	0	0
09/02/2014 08:00	0.0	0	0	0	0	0
09/02/2014 09:00	0.0	0	0	0	0	0
09/02/2014 10:00	0.0	0	0	0	0	0
09/02/2014 11:00	0.0	0	0	0	0	0
09/02/2014 12:00	0.0	0	0	0	0	0
09/02/2014 13:00	0.0	0	0	0	0	0
09/02/2014 14:00	0.0	0	0	0	0	0
09/02/2014 15:00	0.0	0	0	0	0	0
09/02/2014 16:00	0.0	0	0	0	0	0
09/02/2014 17:00	0.0	0	0	0	0	0
09/02/2014 18:00	0.0	0	0	0	0	0
09/02/2014 19:00	0.0	0	0	0	0	0
09/02/2014 20:00	0.0	0	0	0	0	0
09/02/2014 21:00	0.0	0	0	0	0	0
09/02/2014 22:00	0.0	0	0	0	0	0
09/02/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/03/2014 00:00	0.0	0	0	0	0	0
09/03/2014 01:00	0.0	0	0	0	0	0
09/03/2014 02:00	0.0	0	0	0	0	0
09/03/2014 03:00	0.0	0	0	0	0	0
09/03/2014 04:00	0.0	0	0	0	0	0
09/03/2014 05:00	0.0	0	0	0	0	0
09/03/2014 06:00	0.0	0	0	0	0	0
09/03/2014 07:00	0.0	0	0	0	0	0
09/03/2014 08:00	0.0	0	0	0	0	0
09/03/2014 09:00	0.0	0	0	0	0	0
09/03/2014 10:00	0.0	0	0	0	0	0
09/03/2014 11:00	0.0	0	0	0	0	0
09/03/2014 12:00	0.0	0	0	0	0	0
09/03/2014 13:00	0.0	0	0	0	0	0
09/03/2014 14:00	0.0	0	0	0	0	0
09/03/2014 15:00	0.0	0	0	0	0	0
09/03/2014 16:00	0.0	0	0	0	0	0
09/03/2014 17:00	0.0	0	0	0	0	0
09/03/2014 18:00	0.0	0	0	0	0	0
09/03/2014 19:00	0.0	0	0	0	0	0
09/03/2014 20:00	0.0	0	0	0	0	0
09/03/2014 21:00	0.0	0	0	0	0	0
09/03/2014 22:00	0.0	0	0	0	0	0
09/03/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/04/2014 00:00	0.0	0	0	0	0	0
09/04/2014 01:00	0.0	0	0	0	0	0
09/04/2014 02:00	0.0	0	0	0	0	0
09/04/2014 03:00	0.0	0	0	0	0	0
09/04/2014 04:00	0.0	0	0	0	0	0
09/04/2014 05:00	0.0	0	0	0	0	0
09/04/2014 06:00	0.0	0	0	0	0	0
09/04/2014 07:00	0.0	0	0	0	0	0
09/04/2014 08:00	0.0	0	0	0	0	0
09/04/2014 09:00	0.0	0	0	0	0	0
09/04/2014 10:00	0.0	0	0	0	0	0
09/04/2014 11:00	0.0	0	0	0	0	0
09/04/2014 12:00	0.0	0	0	0	0	0
09/04/2014 13:00	0.0	0	0	0	0	0
09/04/2014 14:00	0.0	0	0	0	0	0
09/04/2014 15:00	0.0	0	0	0	0	0
09/04/2014 16:00	0.0	0	0	0	0	0
09/04/2014 17:00	0.0	0	0	0	0	0
09/04/2014 18:00	0.0	0	0	0	0	0
09/04/2014 19:00	0.0	0	0	0	0	0
09/04/2014 20:00	0.0	0	0	0	0	0
09/04/2014 21:00	0.0	0	0	0	0	0
09/04/2014 22:00	0.0	0	0	0	0	0
09/04/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/05/2014 00:00	71.0	1	0	0	0	0
09/05/2014 01:00	38.1	1	0	0	0	0
09/05/2014 02:00	46.1	1	0	0	0	0
09/05/2014 03:00	43.3	1	0	0	0	0
09/05/2014 04:00	23.3	1	0	0	0	0
09/05/2014 05:00	0.0	0	0	0	0	1
09/05/2014 06:00	0.0	0	0	0	0	1
09/05/2014 07:00	0.0	0	0	0	0	1
09/05/2014 08:00	0.0	0	0	0	0	1
09/05/2014 09:00	0.0	0	0	0	0	1
09/05/2014 10:00	0.0	0	0	0	0	1
09/05/2014 11:00	0.0	0	0	0	0	1
09/05/2014 12:00	0.0	0	0	0	0	1
09/05/2014 13:00	0.0	0	0	0	0	1
09/05/2014 14:00	0.0	0	0	0	0	1
09/05/2014 15:00	0.0	0	0	0	0	1
09/05/2014 16:00	0.0	0	0	0	0	1
09/05/2014 17:00	0.0	0	0	0	0	1
09/05/2014 18:00	0.0	0	0	0	0	1
09/05/2014 19:00	0.0	0	0	0	0	1
09/05/2014 20:00	0.0	0	0	0	0	1
09/05/2014 21:00	0.0	0	0	0	0	1
09/05/2014 22:00	0.0	0	0	0	0	1
09/05/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	221.8 #	5 #	0 #	0 #	0 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	71.0	1	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/06/2014 00:00	0.0	0	0	0	0	1
09/06/2014 01:00	0.0	0	0	0	0	1
09/06/2014 02:00	0.0	0	0	0	0	1
09/06/2014 03:00	0.0	0	0	0	0	1
09/06/2014 04:00	0.0	0	0	0	0	1
09/06/2014 05:00	0.0	0	0	0	0	1
09/06/2014 06:00	0.0	0	0	0	0	1
09/06/2014 07:00	0.0	0	0	0	0	1
09/06/2014 08:00	0.0	0	0	0	0	1
09/06/2014 09:00	0.0	0	0	0	0	1
09/06/2014 10:00	0.0	0	0	0	0	1
09/06/2014 11:00	0.0	0	0	0	0	1
09/06/2014 12:00	0.0	0	0	0	0	1
09/06/2014 13:00	0.0	0	0	0	0	1
09/06/2014 14:00	0.0	0	0	0	0	1
09/06/2014 15:00	0.0	0	0	0	0	1
09/06/2014 16:00	0.0	0	0	0	0	1
09/06/2014 17:00	0.0	0	0	0	0	1
09/06/2014 18:00	0.0	0	0	0	0	1
09/06/2014 19:00	0.0	0	0	0	0	1
09/06/2014 20:00	0.0	0	0	0	0	1
09/06/2014 21:00	0.0	0	0	0	0	1
09/06/2014 22:00	0.0	0	0	0	0	1
09/06/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/07/2014 00:00	0.0	0	0	0	0	1
09/07/2014 01:00	0.0	0	0	0	0	1
09/07/2014 02:00	0.0	0	0	0	0	1
09/07/2014 03:00	0.0	0	0	0	0	1
09/07/2014 04:00	0.0	0	0	0	0	1
09/07/2014 05:00	0.0	0	0	0	0	1
09/07/2014 06:00	0.0	0	0	0	0	1
09/07/2014 07:00	0.0	0	0	0	0	1
09/07/2014 08:00	0.0	0	0	0	0	1
09/07/2014 09:00	0.0	0	0	0	0	1
09/07/2014 10:00	0.0	0	0	0	0	1
09/07/2014 11:00	0.0	0	0	0	0	1
09/07/2014 12:00	0.0	0	0	0	0	1
09/07/2014 13:00	0.0	0	0	0	0	1
09/07/2014 14:00	0.0	0	0	0	0	1
09/07/2014 15:00	0.0	0	0	0	0	1
09/07/2014 16:00	0.0	0	0	0	0	1
09/07/2014 17:00	0.0	0	0	0	0	1
09/07/2014 18:00	0.0	0	0	0	0	1
09/07/2014 19:00	0.0	0	0	0	0	1
09/07/2014 20:00	0.0	0	0	0	0	1
09/07/2014 21:00	0.0	0	0	0	0	1
09/07/2014 22:00	0.0	0	0	0	0	1
09/07/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/08/2014 00:00	0.0	0	0	0	0	1
09/08/2014 01:00	0.0	0	0	0	0	1
09/08/2014 02:00	0.0	0	0	0	0	1
09/08/2014 03:00	0.0	0	0	0	0	1
09/08/2014 04:00	0.0	0	0	0	0	1
09/08/2014 05:00	0.0	0	0	0	0	1
09/08/2014 06:00	0.0	0	0	0	0	1
09/08/2014 07:00	0.0	0	0	0	0	1
09/08/2014 08:00	0.0	0	0	0	0	1
09/08/2014 09:00	0.0	0	0	0	0	1
09/08/2014 10:00	0.0	0	0	0	0	1
09/08/2014 11:00	0.0	0	0	0	0	1
09/08/2014 12:00	0.0	0	0	0	0	1
09/08/2014 13:00	0.0	0	0	0	0	1
09/08/2014 14:00	0.0	0	0	0	0	1
09/08/2014 15:00	0.0	0	0	0	0	1
09/08/2014 16:00	0.0	0	0	0	0	1
09/08/2014 17:00	0.0	0	0	0	0	1
09/08/2014 18:00	0.0	0	0	0	0	1
09/08/2014 19:00	0.0	0	0	0	0	1
09/08/2014 20:00	0.0	0	0	0	0	1
09/08/2014 21:00	0.0	0	0	0	0	1
09/08/2014 22:00	0.0	0	0	0	0	1
09/08/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/09/2014 00:00	0.0	0	0	0	0	1
09/09/2014 01:00	0.0	0	0	0	0	1
09/09/2014 02:00	0.0	0	0	0	0	1
09/09/2014 03:00	0.0	0	0	0	0	1
09/09/2014 04:00	0.0	0	0	0	0	1
09/09/2014 05:00	0.0	0	0	0	0	1
09/09/2014 06:00	0.0	0	0	0	0	1
09/09/2014 07:00	0.0	0	0	0	0	1
09/09/2014 08:00	0.0	0	0	0	0	1
09/09/2014 09:00	0.0	0	0	0	0	1
09/09/2014 10:00	0.0	0	0	0	0	1
09/09/2014 11:00	0.0	0	0	0	0	1
09/09/2014 12:00	0.0	0	0	0	0	1
09/09/2014 13:00	0.0	0	0	0	0	1
09/09/2014 14:00	0.0	0	0	0	0	1
09/09/2014 15:00	0.0	0	0	0	0	1
09/09/2014 16:00	0.0	0	0	0	0	1
09/09/2014 17:00	0.0	0	0	0	0	1
09/09/2014 18:00	0.0	0	0	0	0	1
09/09/2014 19:00	0.0	0	0	0	0	1
09/09/2014 20:00	0.0	0	0	0	0	1
09/09/2014 21:00	0.0	0	0	0	0	1
09/09/2014 22:00	0.0	0	0	0	0	1
09/09/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/10/2014 00:00	0.0	0	0	0	0	1
09/10/2014 01:00	0.0	0	0	0	0	1
09/10/2014 02:00	0.0	0	0	0	0	1
09/10/2014 03:00	0.0	0	0	0	0	1
09/10/2014 04:00	0.0	0	0	0	0	1
09/10/2014 05:00	0.0	0	0	0	0	1
09/10/2014 06:00	0.0	0	0	0	0	1
09/10/2014 07:00	0.0	0	0	0	0	1
09/10/2014 08:00	0.0	0	0	0	0	1
09/10/2014 09:00	0.0	0	0	0	0	1
09/10/2014 10:00	0.0	0	0	0	0	1
09/10/2014 11:00	0.0	0	0	0	0	1
09/10/2014 12:00	0.0	0	0	0	0	1
09/10/2014 13:00	0.0	0	0	0	0	1
09/10/2014 14:00	0.0	0	0	0	0	1
09/10/2014 15:00	0.0	0	0	0	0	1
09/10/2014 16:00	0.0	0	0	0	0	1
09/10/2014 17:00	0.0	0	0	0	0	1
09/10/2014 18:00	0.0	0	0	0	0	1
09/10/2014 19:00	0.0	0	0	0	0	1
09/10/2014 20:00	0.0	0	0	0	0	1
09/10/2014 21:00	0.0	0	0	0	0	1
09/10/2014 22:00	0.0	0	0	0	0	1
09/10/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/11/2014 00:00	0.0	0	0	0	0	1
09/11/2014 01:00	0.0	0	0	0	0	1
09/11/2014 02:00	0.0	0	0	0	0	1
09/11/2014 03:00	0.0	0	0	0	0	1
09/11/2014 04:00	0.0	0	0	0	0	1
09/11/2014 05:00	0.0	0	0	0	0	1
09/11/2014 06:00	0.0	0	0	0	0	1
09/11/2014 07:00	0.0	0	0	0	0	1
09/11/2014 08:00	0.0	0	0	0	0	1
09/11/2014 09:00	0.0	0	0	0	0	1
09/11/2014 10:00	0.0	0	0	0	0	1
09/11/2014 11:00	0.0	0	0	0	0	1
09/11/2014 12:00	0.0	0	0	0	0	1
09/11/2014 13:00	0.0	0	0	0	0	1
09/11/2014 14:00	0.0	0	0	0	0	1
09/11/2014 15:00	0.0	0	0	0	0	1
09/11/2014 16:00	0.0	0	0	0	0	1
09/11/2014 17:00	0.0	0	0	0	0	1
09/11/2014 18:00	0.0	0	0	0	0	1
09/11/2014 19:00	0.0	0	0	0	0	1
09/11/2014 20:00	0.0	0	0	0	0	1
09/11/2014 21:00	0.0	0	0	0	0	1
09/11/2014 22:00	0.0	0	0	0	0	1
09/11/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/12/2014 00:00	0.0	0	0	0	0	1
09/12/2014 01:00	0.0	0	0	0	0	1
09/12/2014 02:00	0.0	0	0	0	0	1
09/12/2014 03:00	0.0	0	0	0	0	1
09/12/2014 04:00	0.0	0	0	0	0	1
09/12/2014 05:00	0.0	0	0	0	0	1
09/12/2014 06:00	0.0	0	0	0	0	1
09/12/2014 07:00	0.0	0	0	0	0	1
09/12/2014 08:00	0.0	0	0	0	0	1
09/12/2014 09:00	0.0	0	0	0	0	1
09/12/2014 10:00	0.0	0	0	0	0	1
09/12/2014 11:00	0.0	0	0	0	0	1
09/12/2014 12:00	0.0	0	0	0	0	1
09/12/2014 13:00	0.0	0	0	0	0	1
09/12/2014 14:00	0.0	0	0	0	0	1
09/12/2014 15:00	0.0	0	0	0	0	1
09/12/2014 16:00	0.0	0	0	0	0	1
09/12/2014 17:00	0.0	0	0	0	0	1
09/12/2014 18:00	0.0	0	0	0	0	1
09/12/2014 19:00	0.0	0	0	0	0	1
09/12/2014 20:00	0.0	0	0	0	0	1
09/12/2014 21:00	0.0	0	0	0	0	1
09/12/2014 22:00	0.0	0	0	0	0	1
09/12/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/13/2014 00:00	0.0	0	0	0	0	1
09/13/2014 01:00	0.0	0	0	0	0	1
09/13/2014 02:00	0.0	0	0	0	0	1
09/13/2014 03:00	0.0	0	0	0	0	1
09/13/2014 04:00	0.0	0	0	0	0	1
09/13/2014 05:00	0.0	0	0	0	0	1
09/13/2014 06:00	0.0	0	0	0	0	1
09/13/2014 07:00	0.0	0	0	0	0	1
09/13/2014 08:00	0.0	0	0	0	0	1
09/13/2014 09:00	0.0	0	0	0	0	1
09/13/2014 10:00	0.0	0	0	0	0	1
09/13/2014 11:00	0.0	0	0	0	0	1
09/13/2014 12:00	0.0	0	0	0	0	1
09/13/2014 13:00	0.0	0	0	0	0	1
09/13/2014 14:00	0.0	0	0	0	0	1
09/13/2014 15:00	0.0	0	0	0	0	1
09/13/2014 16:00	0.0	0	0	0	0	1
09/13/2014 17:00	0.0	0	0	0	0	1
09/13/2014 18:00	0.0	0	0	0	0	1
09/13/2014 19:00	0.0	0	0	0	0	1
09/13/2014 20:00	0.0	0	0	0	0	1
09/13/2014 21:00	0.0	0	0	0	0	1
09/13/2014 22:00	0.0	0	0	0	0	1
09/13/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/14/2014 00:00	0.0	0	0	0	0	1
09/14/2014 01:00	0.0	0	0	0	0	1
09/14/2014 02:00	0.0	0	0	0	0	1
09/14/2014 03:00	0.0	0	0	0	0	1
09/14/2014 04:00	0.0	0	0	0	0	1
09/14/2014 05:00	0.0	0	0	0	0	1
09/14/2014 06:00	0.0	0	0	0	0	1
09/14/2014 07:00	0.0	0	0	0	0	1
09/14/2014 08:00	0.0	0	0	0	0	1
09/14/2014 09:00	0.0	0	0	0	0	1
09/14/2014 10:00	0.0	0	0	0	0	1
09/14/2014 11:00	0.0	0	0	0	0	1
09/14/2014 12:00	0.0	0	0	0	0	1
09/14/2014 13:00	0.0	0	0	0	0	1
09/14/2014 14:00	0.0	0	0	0	0	1
09/14/2014 15:00	0.0	0	0	0	0	1
09/14/2014 16:00	0.0	0	0	0	0	1
09/14/2014 17:00	0.0	0	0	0	0	1
09/14/2014 18:00	0.0	0	0	0	0	1
09/14/2014 19:00	0.0	0	0	0	0	1
09/14/2014 20:00	0.0	0	0	0	0	1
09/14/2014 21:00	0.0	0	0	0	0	1
09/14/2014 22:00	0.0	0	0	0	0	1
09/14/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/15/2014 00:00	0.0	0	0	0	0	1
09/15/2014 01:00	0.0	0	0	0	0	1
09/15/2014 02:00	0.0	0	0	0	0	1
09/15/2014 03:00	0.0	0	0	0	0	1
09/15/2014 04:00	0.0	0	0	0	0	1
09/15/2014 05:00	0.0	0	0	0	0	1
09/15/2014 06:00	0.0	0	0	0	0	1
09/15/2014 07:00	0.0	0	0	0	0	1
09/15/2014 08:00	0.0	0	0	0	0	1
09/15/2014 09:00	0.0	0	0	0	0	1
09/15/2014 10:00	0.0	0	0	0	0	1
09/15/2014 11:00	0.0	0	0	0	0	1
09/15/2014 12:00	0.0	0	0	0	0	1
09/15/2014 13:00	0.0	0	0	0	0	1
09/15/2014 14:00	0.0	0	0	0	0	1
09/15/2014 15:00	0.0	0	0	0	0	1
09/15/2014 16:00	0.0	0	0	0	0	1
09/15/2014 17:00	0.0	0	0	0	0	1
09/15/2014 18:00	0.0	0	0	0	0	1
09/15/2014 19:00	0.0	0	0	0	0	1
09/15/2014 20:00	0.0	0	0	0	0	1
09/15/2014 21:00	0.0	0	0	0	0	1
09/15/2014 22:00	0.0	0	0	0	0	1
09/15/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/16/2014 00:00	0.0	0	0	0	0	1
09/16/2014 01:00	0.0	0	0	0	0	1
09/16/2014 02:00	0.0	0	0	0	0	1
09/16/2014 03:00	0.0	0	0	0	0	1
09/16/2014 04:00	0.0	0	0	0	0	1
09/16/2014 05:00	0.0	0	0	0	0	1
09/16/2014 06:00	0.0	0	0	0	0	1
09/16/2014 07:00	0.0	0	0	0	0	1
09/16/2014 08:00	0.0	0	0	0	0	1
09/16/2014 09:00	0.0	0	0	0	0	1
09/16/2014 10:00	0.0	0	0	0	0	1
09/16/2014 11:00	0.0	0	0	0	0	1
09/16/2014 12:00	0.0	0	0	0	0	1
09/16/2014 13:00	0.0	0	0	0	0	1
09/16/2014 14:00	0.0	0	0	0	0	1
09/16/2014 15:00	0.0	0	0	0	0	1
09/16/2014 16:00	0.0	0	0	0	0	1
09/16/2014 17:00	0.0	0	0	0	0	1
09/16/2014 18:00	0.0	0	0	0	0	1
09/16/2014 19:00	0.0	0	0	0	0	1
09/16/2014 20:00	0.0	0	0	0	0	1
09/16/2014 21:00	0.0	0	0	0	0	1
09/16/2014 22:00	0.0	0	0	0	0	1
09/16/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/17/2014 00:00	0.0	0	0	0	0	1
09/17/2014 01:00	0.0	0	0	0	0	1
09/17/2014 02:00	0.0	0	0	0	0	1
09/17/2014 03:00	0.0	0	0	0	0	1
09/17/2014 04:00	0.0	0	0	0	0	1
09/17/2014 05:00	0.0	0	0	0	0	1
09/17/2014 06:00	0.0	0	0	0	0	1
09/17/2014 07:00	0.0	0	0	0	0	1
09/17/2014 08:00	0.0	0	0	0	0	1
09/17/2014 09:00	0.0	0	0	0	0	1
09/17/2014 10:00	0.0	0	0	0	0	1
09/17/2014 11:00	0.0	0	0	0	0	1
09/17/2014 12:00	0.0	0	0	0	0	1
09/17/2014 13:00	0.0	0	0	0	0	1
09/17/2014 14:00	0.0	0	0	0	0	1
09/17/2014 15:00	0.0	0	0	0	0	1
09/17/2014 16:00	0.0	0	0	0	0	1
09/17/2014 17:00	0.0	0	0	0	0	1
09/17/2014 18:00	0.0	0	0	0	0	1
09/17/2014 19:00	0.0	0	0	0	0	1
09/17/2014 20:00	0.0	0	0	0	0	1
09/17/2014 21:00	0.0	0	0	0	0	1
09/17/2014 22:00	0.0	0	0	0	0	1
09/17/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/18/2014 00:00	0.0	0	0	0	0	1
09/18/2014 01:00	0.0	0	0	0	0	1
09/18/2014 02:00	0.0	0	0	0	0	1
09/18/2014 03:00	0.0	0	0	0	0	1
09/18/2014 04:00	0.0	0	0	0	0	1
09/18/2014 05:00	0.0	0	0	0	0	1
09/18/2014 06:00	0.0	0	0	0	0	1
09/18/2014 07:00	0.0	0	0	0	0	1
09/18/2014 08:00	0.0	0	0	0	0	1
09/18/2014 09:00	0.0	0	0	0	0	1
09/18/2014 10:00	0.0	0	0	0	0	1
09/18/2014 11:00	0.0	0	0	0	0	1
09/18/2014 12:00	0.0	0	0	0	0	1
09/18/2014 13:00	0.0	0	0	0	0	1
09/18/2014 14:00	0.0	0	0	0	0	1
09/18/2014 15:00	0.0	0	0	0	0	1
09/18/2014 16:00	0.0	0	0	0	0	1
09/18/2014 17:00	0.0	0	0	0	0	1
09/18/2014 18:00	0.0	0	0	0	0	1
09/18/2014 19:00	0.0	0	0	0	0	1
09/18/2014 20:00	0.0	0	0	0	0	1
09/18/2014 21:00	0.0	0	0	0	0	1
09/18/2014 22:00	0.0	0	0	0	0	1
09/18/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/19/2014 00:00	0.0	0	0	0	0	1
09/19/2014 01:00	0.0	0	0	0	0	1
09/19/2014 02:00	0.0	0	0	0	0	1
09/19/2014 03:00	0.0	0	0	0	0	1
09/19/2014 04:00	0.0	0	0	0	0	1
09/19/2014 05:00	0.0	0	0	0	0	1
09/19/2014 06:00	0.0	0	0	0	0	1
09/19/2014 07:00	0.0	0	0	0	0	1
09/19/2014 08:00	0.0	0	0	0	0	1
09/19/2014 09:00	0.0	0	0	0	0	1
09/19/2014 10:00	0.0	0	0	0	0	1
09/19/2014 11:00	0.0	0	0	0	0	1
09/19/2014 12:00	0.0	0	0	0	0	1
09/19/2014 13:00	0.0	0	0	0	0	1
09/19/2014 14:00	0.0	0	0	0	0	1
09/19/2014 15:00	0.0	0	0	0	0	1
09/19/2014 16:00	0.0	0	0	0	0	1
09/19/2014 17:00	0.0	0	0	0	0	1
09/19/2014 18:00	0.0	0	0	0	0	1
09/19/2014 19:00	0.0	0	0	0	0	1
09/19/2014 20:00	0.0	0	0	0	0	1
09/19/2014 21:00	0.0	0	0	0	0	1
09/19/2014 22:00	0.0	0	0	0	0	1
09/19/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/20/2014 00:00	0.0	0	0	0	0	1
09/20/2014 01:00	0.0	0	0	0	0	1
09/20/2014 02:00	0.0	0	0	0	0	1
09/20/2014 03:00	0.0	0	0	0	0	1
09/20/2014 04:00	0.0	0	0	0	0	1
09/20/2014 05:00	0.0	0	0	0	0	1
09/20/2014 06:00	0.0	0	0	0	0	1
09/20/2014 07:00	0.0	0	0	0	0	1
09/20/2014 08:00	0.0	0	0	0	0	1
09/20/2014 09:00	0.0	0	0	0	0	1
09/20/2014 10:00	0.0	0	0	0	0	1
09/20/2014 11:00	0.0	0	0	0	0	1
09/20/2014 12:00	0.0	0	0	0	0	1
09/20/2014 13:00	0.0	0	0	0	0	1
09/20/2014 14:00	0.0	0	0	0	0	1
09/20/2014 15:00	0.0	0	0	0	0	1
09/20/2014 16:00	0.0	0	0	0	0	1
09/20/2014 17:00	0.0	0	0	0	0	1
09/20/2014 18:00	0.0	0	0	0	0	1
09/20/2014 19:00	0.0	0	0	0	0	1
09/20/2014 20:00	0.0	0	0	0	0	1
09/20/2014 21:00	0.0	0	0	0	0	1
09/20/2014 22:00	0.0	0	0	0	0	1
09/20/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/21/2014 00:00	0.0	0	0	0	0	1
09/21/2014 01:00	0.0	0	0	0	0	1
09/21/2014 02:00	0.0	0	0	0	0	1
09/21/2014 03:00	0.0	0	0	0	0	1
09/21/2014 04:00	0.0	0	0	0	0	1
09/21/2014 05:00	0.0	0	0	0	0	1
09/21/2014 06:00	0.0	0	0	0	0	1
09/21/2014 07:00	0.0	0	0	0	0	1
09/21/2014 08:00	0.0	0	0	0	0	1
09/21/2014 09:00	0.0	0	0	0	0	1
09/21/2014 10:00	0.0	0	0	0	0	1
09/21/2014 11:00	0.0	0	0	0	0	1
09/21/2014 12:00	0.0	0	0	0	0	1
09/21/2014 13:00	0.0	0	0	0	0	1
09/21/2014 14:00	0.0	0	0	0	0	1
09/21/2014 15:00	0.0	0	0	0	0	1
09/21/2014 16:00	0.0	0	0	0	0	1
09/21/2014 17:00	0.0	0	0	0	0	1
09/21/2014 18:00	0.0	0	0	0	0	1
09/21/2014 19:00	0.0	0	0	0	0	1
09/21/2014 20:00	0.0	0	0	0	0	1
09/21/2014 21:00	0.0	0	0	0	0	1
09/21/2014 22:00	0.0	0	0	0	0	1
09/21/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/22/2014 00:00	0.0	0	0	0	0	1
09/22/2014 01:00	0.0	0	0	0	0	1
09/22/2014 02:00	0.0	0	0	0	0	1
09/22/2014 03:00	0.0	0	0	0	0	1
09/22/2014 04:00	0.0	0	0	0	0	1
09/22/2014 05:00	0.0	0	0	0	0	1
09/22/2014 06:00	0.0	0	0	0	0	1
09/22/2014 07:00	0.0	0	0	0	0	1
09/22/2014 08:00	0.0	0	0	0	0	1
09/22/2014 09:00	0.0	0	0	0	0	1
09/22/2014 10:00	0.0	0	0	0	0	1
09/22/2014 11:00	0.0	0	0	0	0	1
09/22/2014 12:00	0.0	0	0	0	0	1
09/22/2014 13:00	0.0	0	0	0	0	1
09/22/2014 14:00	0.0	0	0	0	0	1
09/22/2014 15:00	0.0	0	0	0	0	1
09/22/2014 16:00	0.0	0	0	0	0	1
09/22/2014 17:00	0.0	0	0	0	0	1
09/22/2014 18:00	0.0	0	0	0	0	1
09/22/2014 19:00	0.0	0	0	0	0	1
09/22/2014 20:00	0.0	0	0	0	0	1
09/22/2014 21:00	0.0	0	0	0	0	1
09/22/2014 22:00	0.0	0	0	0	0	1
09/22/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/23/2014 00:00	0.0	0	0	0	0	1
09/23/2014 01:00	0.0	0	0	0	0	1
09/23/2014 02:00	0.0	0	0	0	0	1
09/23/2014 03:00	0.0	0	0	0	0	1
09/23/2014 04:00	0.0	0	0	0	0	1
09/23/2014 05:00	0.0	0	0	0	0	1
09/23/2014 06:00	0.0	0	0	0	0	1
09/23/2014 07:00	0.0	0	0	0	0	1
09/23/2014 08:00	0.0	0	0	0	0	1
09/23/2014 09:00	0.0	0	0	0	0	1
09/23/2014 10:00	0.0	0	0	0	0	1
09/23/2014 11:00	0.0	0	0	0	0	1
09/23/2014 12:00	0.0	0	0	0	0	1
09/23/2014 13:00	0.0	0	0	0	0	1
09/23/2014 14:00	0.0	0	0	0	0	1
09/23/2014 15:00	0.0	0	0	0	0	1
09/23/2014 16:00	0.0	0	0	0	0	1
09/23/2014 17:00	0.0	0	0	0	0	1
09/23/2014 18:00	0.0	0	0	0	0	1
09/23/2014 19:00	0.0	0	0	0	0	1
09/23/2014 20:00	0.0	0	0	0	0	1
09/23/2014 21:00	0.0	0	0	0	0	1
09/23/2014 22:00	0.0	0	0	0	0	1
09/23/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/24/2014 00:00	0.0	0	0	0	0	1
09/24/2014 01:00	0.0	0	0	0	0	1
09/24/2014 02:00	0.0	0	0	0	0	1
09/24/2014 03:00	0.0	0	0	0	0	1
09/24/2014 04:00	0.0	0	0	0	0	1
09/24/2014 05:00	0.0	0	0	0	0	1
09/24/2014 06:00	0.0	0	0	0	0	1
09/24/2014 07:00	0.0	0	0	0	0	1
09/24/2014 08:00	0.0	0	0	0	0	1
09/24/2014 09:00	0.0	0	0	0	0	1
09/24/2014 10:00	0.0	0	0	0	0	1
09/24/2014 11:00	0.0	0	0	0	0	1
09/24/2014 12:00	0.0	0	0	0	0	1
09/24/2014 13:00	0.0	0	0	0	0	1
09/24/2014 14:00	0.0	0	0	0	0	1
09/24/2014 15:00	0.0	0	0	0	0	1
09/24/2014 16:00	0.0	0	0	0	0	1
09/24/2014 17:00	0.0	0	0	0	0	1
09/24/2014 18:00	0.0	0	0	0	0	1
09/24/2014 19:00	0.0	0	0	0	0	1
09/24/2014 20:00	0.0	0	0	0	0	1
09/24/2014 21:00	0.0	0	0	0	0	1
09/24/2014 22:00	0.0	0	0	0	0	1
09/24/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/25/2014 00:00	0.0	0	0	0	0	1
09/25/2014 01:00	0.0	0	0	0	0	1
09/25/2014 02:00	0.0	0	0	0	0	1
09/25/2014 03:00	0.0	0	0	0	0	1
09/25/2014 04:00	0.0	0	0	0	0	1
09/25/2014 05:00	0.0	0	0	0	0	1
09/25/2014 06:00	0.0	0	0	0	0	1
09/25/2014 07:00	0.0	0	0	0	0	1
09/25/2014 08:00	0.0	0	0	0	0	1
09/25/2014 09:00	0.0	0	0	0	0	1
09/25/2014 10:00	0.0	0	0	0	0	1
09/25/2014 11:00	0.0	0	0	0	0	1
09/25/2014 12:00	0.0	0	0	0	0	1
09/25/2014 13:00	0.0	0	0	0	0	1
09/25/2014 14:00	0.0	0	0	0	0	1
09/25/2014 15:00	0.0	0	0	0	0	1
09/25/2014 16:00	0.0	0	0	0	0	1
09/25/2014 17:00	0.0	0	0	0	0	1
09/25/2014 18:00	0.0	0	0	0	0	1
09/25/2014 19:00	0.0	0	0	0	0	1
09/25/2014 20:00	0.0	0	0	0	0	1
09/25/2014 21:00	0.0	0	0	0	0	1
09/25/2014 22:00	0.0	0	0	0	0	1
09/25/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/26/2014 00:00	0.0	0	0	0	0	1
09/26/2014 01:00	0.0	0	0	0	0	1
09/26/2014 02:00	0.0	0	0	0	0	1
09/26/2014 03:00	0.0	0	0	0	0	1
09/26/2014 04:00	0.0	0	0	0	0	1
09/26/2014 05:00	0.0	0	0	0	0	1
09/26/2014 06:00	0.0	0	0	0	0	1
09/26/2014 07:00	0.0	0	0	0	0	1
09/26/2014 08:00	0.0	0	0	0	0	1
09/26/2014 09:00	0.0	0	0	0	0	1
09/26/2014 10:00	0.0	0	0	0	0	1
09/26/2014 11:00	0.0	0	0	0	0	1
09/26/2014 12:00	0.0	0	0	0	0	1
09/26/2014 13:00	0.0	0	0	0	0	1
09/26/2014 14:00	0.0	0	0	0	0	1
09/26/2014 15:00	0.0	0	0	0	0	1
09/26/2014 16:00	0.0	0	0	0	0	1
09/26/2014 17:00	0.0	0	0	0	0	1
09/26/2014 18:00	0.0	0	0	0	0	1
09/26/2014 19:00	0.0	0	0	0	0	1
09/26/2014 20:00	0.0	0	0	0	0	1
09/26/2014 21:00	0.0	0	0	0	0	1
09/26/2014 22:00	0.0	0	0	0	0	1
09/26/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/27/2014 00:00	0.0	0	0	0	0	1
09/27/2014 01:00	0.0	0	0	0	0	1
09/27/2014 02:00	0.0	0	0	0	0	1
09/27/2014 03:00	0.0	0	0	0	0	1
09/27/2014 04:00	0.0	0	0	0	0	1
09/27/2014 05:00	0.0	0	0	0	0	1
09/27/2014 06:00	0.0	0	0	0	0	1
09/27/2014 07:00	0.0	0	0	0	0	1
09/27/2014 08:00	0.0	0	0	0	0	1
09/27/2014 09:00	0.0	0	0	0	0	1
09/27/2014 10:00	0.0	0	0	0	0	1
09/27/2014 11:00	0.0	0	0	0	0	1
09/27/2014 12:00	0.0	0	0	0	0	1
09/27/2014 13:00	0.0	0	0	0	0	1
09/27/2014 14:00	0.0	0	0	0	0	1
09/27/2014 15:00	0.0	0	0	0	0	1
09/27/2014 16:00	0.0	0	0	0	0	1
09/27/2014 17:00	0.0	0	0	0	0	1
09/27/2014 18:00	0.0	0	0	0	0	1
09/27/2014 19:00	0.0	0	0	0	0	1
09/27/2014 20:00	0.0	0	0	0	0	1
09/27/2014 21:00	0.0	0	0	0	0	1
09/27/2014 22:00	0.0	0	0	0	0	1
09/27/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/28/2014 00:00	0.0	0	0	0	0	1
09/28/2014 01:00	0.0	0	0	0	0	1
09/28/2014 02:00	0.0	0	0	0	0	1
09/28/2014 03:00	0.0	0	0	0	0	1
09/28/2014 04:00	0.0	0	0	0	0	1
09/28/2014 05:00	0.0	0	0	0	0	1
09/28/2014 06:00	0.0	0	0	0	0	1
09/28/2014 07:00	0.0	0	0	0	0	1
09/28/2014 08:00	0.0	0	0	0	0	1
09/28/2014 09:00	0.0	0	0	0	0	1
09/28/2014 10:00	0.0	0	0	0	0	1
09/28/2014 11:00	0.0	0	0	0	0	1
09/28/2014 12:00	0.0	0	0	0	0	1
09/28/2014 13:00	0.0	0	0	0	0	1
09/28/2014 14:00	0.0	0	0	0	0	1
09/28/2014 15:00	0.0	0	0	0	0	1
09/28/2014 16:00	0.0	0	0	0	0	1
09/28/2014 17:00	0.0	0	0	0	0	1
09/28/2014 18:00	0.0	0	0	0	0	1
09/28/2014 19:00	0.0	0	0	0	0	1
09/28/2014 20:00	0.0	0	0	0	0	1
09/28/2014 21:00	0.0	0	0	0	0	1
09/28/2014 22:00	0.0	0	0	0	0	1
09/28/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/29/2014 00:00	0.0	0	0	0	0	1
09/29/2014 01:00	0.0	0	0	0	0	1
09/29/2014 02:00	0.0	0	0	0	0	1
09/29/2014 03:00	0.0	0	0	0	0	1
09/29/2014 04:00	0.0	0	0	0	0	1
09/29/2014 05:00	0.0	0	0	0	0	1
09/29/2014 06:00	0.0	0	0	0	0	1
09/29/2014 07:00	0.0	0	0	0	0	1
09/29/2014 08:00	0.0	0	0	0	0	1
09/29/2014 09:00	0.0	0	0	0	0	1
09/29/2014 10:00	0.0	0	0	0	0	1
09/29/2014 11:00	0.0	0	0	0	0	1
09/29/2014 12:00	0.0	0	0	0	0	1
09/29/2014 13:00	0.0	0	0	0	0	1
09/29/2014 14:00	0.0	0	0	0	0	1
09/29/2014 15:00	0.0	0	0	0	0	1
09/29/2014 16:00	0.0	0	0	0	0	1
09/29/2014 17:00	0.0	0	0	0	0	1
09/29/2014 18:00	0.0	0	0	0	0	1
09/29/2014 19:00	0.0	0	0	0	0	1
09/29/2014 20:00	0.0	0	0	0	0	1
09/29/2014 21:00	0.0	0	0	0	0	1
09/29/2014 22:00	0.0	0	0	0	0	1
09/29/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event CO Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 CO_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/30/2014 00:00	0.0	0	0	0	0	1
09/30/2014 01:00	0.0	0	0	0	0	1
09/30/2014 02:00	0.0	0	0	0	0	1
09/30/2014 03:00	0.0	0	0	0	0	1
09/30/2014 04:00	0.0	0	0	0	0	1
09/30/2014 05:00	0.0	0	0	0	0	1
09/30/2014 06:00	0.0	0	0	0	0	1
09/30/2014 07:00	0.0	0	0	0	0	1
09/30/2014 08:00	0.0	0	0	0	0	1
09/30/2014 09:00	0.0	0	0	0	0	1
09/30/2014 10:00	0.0	0	0	0	0	1
09/30/2014 11:00	0.0	0	0	0	0	1
09/30/2014 12:00	0.0	0	0	0	0	1
09/30/2014 13:00	0.0	0	0	0	0	1
09/30/2014 14:00	0.0	0	0	0	0	1
09/30/2014 15:00	0.0	0	0	0	0	1
09/30/2014 16:00	0.0	0	0	0	0	1
09/30/2014 17:00	0.0	0	0	0	0	1
09/30/2014 18:00	0.0	0	0	0	0	1
09/30/2014 19:00	0.0	0	0	0	0	1
09/30/2014 20:00	0.0	0	0	0	0	1
09/30/2014 21:00	0.0	0	0	0	0	1
09/30/2014 22:00	0.0	0	0	0	0	1
09/30/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/01/2014 00:00	0.0	0	0	0	0	1
07/01/2014 01:00	0.0	0	0	0	0	1
07/01/2014 02:00	0.0	0	0	0	0	1
07/01/2014 03:00	0.0	0	0	0	0	1
07/01/2014 04:00	0.0	0	0	0	0	1
07/01/2014 05:00	0.0	0	0	0	0	1
07/01/2014 06:00	0.0	0	0	0	0	1
07/01/2014 07:00	0.0	0	0	0	0	1
07/01/2014 08:00	0.0	0	0	0	0	1
07/01/2014 09:00	0.0	0	0	0	0	1
07/01/2014 10:00	0.0	0	0	0	0	1
07/01/2014 11:00	0.0	0	0	0	0	1
07/01/2014 12:00	0.0	0	0	0	0	1
07/01/2014 13:00	0.0	0	0	0	0	1
07/01/2014 14:00	0.0	0	0	0	0	1
07/01/2014 15:00	0.0	0	0	0	0	1
07/01/2014 16:00	0.0	0	0	0	0	1
07/01/2014 17:00	0.0	0	0	0	0	1
07/01/2014 18:00	0.0	0	0	0	0	1
07/01/2014 19:00	0.0	0	0	0	0	1
07/01/2014 20:00	0.0	0	0	0	0	1
07/01/2014 21:00	0.0	0	0	0	0	1
07/01/2014 22:00	0.0	0	0	0	0	1
07/01/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/02/2014 00:00	0.0	0	0	0	0	1
07/02/2014 01:00	0.0	0	0	0	0	1
07/02/2014 02:00	0.0	0	0	0	0	1
07/02/2014 03:00	0.0	0	0	0	0	1
07/02/2014 04:00	0.0	0	0	0	0	1
07/02/2014 05:00	0.0	0	0	0	0	1
07/02/2014 06:00	0.0	0	0	0	0	1
07/02/2014 07:00	0.0	0	0	0	0	1
07/02/2014 08:00	0.0	0	0	0	0	1
07/02/2014 09:00	0.0	0	0	0	0	1
07/02/2014 10:00	0.0	0	0	0	0	1
07/02/2014 11:00	0.0	0	0	0	0	1
07/02/2014 12:00	0.0	0	0	0	0	1
07/02/2014 13:00	0.0	0	0	0	0	1
07/02/2014 14:00	0.0	0	0	0	0	1
07/02/2014 15:00	0.0	0	0	0	0	1
07/02/2014 16:00	0.0	0	0	0	0	1
07/02/2014 17:00	0.0	0	0	0	0	1
07/02/2014 18:00	0.0	0	0	0	0	1
07/02/2014 19:00	0.0	0	0	0	0	1
07/02/2014 20:00	0.0	0	0	0	0	1
07/02/2014 21:00	0.0	0	0	0	0	1
07/02/2014 22:00	1.3	0	0	0	1	0
07/02/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.3 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.3	0	0	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/03/2014 00:00	0.0	0	0	0	0	0
07/03/2014 01:00	0.0	0	0	0	0	0
07/03/2014 02:00	0.0	0	0	0	0	0
07/03/2014 03:00	0.0	0	0	0	0	0
07/03/2014 04:00	0.0	0	0	0	0	0
07/03/2014 05:00	0.0	0	0	0	0	0
07/03/2014 06:00	0.0	0	0	0	0	0
07/03/2014 07:00	46.7	0	1	0	0	0
07/03/2014 08:00	15.2	0	1	0	0	0
07/03/2014 09:00	0.0	0	0	0	0	1
07/03/2014 10:00	0.0	0	0	0	0	1
07/03/2014 11:00	0.0	0	0	0	0	1
07/03/2014 12:00	0.0	0	0	0	0	1
07/03/2014 13:00	0.0	0	0	0	0	1
07/03/2014 14:00	0.0	0	0	0	0	1
07/03/2014 15:00	0.0	0	0	0	0	1
07/03/2014 16:00	0.0	0	0	0	0	1
07/03/2014 17:00	0.0	0	0	0	0	1
07/03/2014 18:00	0.0	0	0	0	0	1
07/03/2014 19:00	0.0	0	0	0	0	1
07/03/2014 20:00	0.0	0	0	0	0	1
07/03/2014 21:00	0.0	0	0	0	0	1
07/03/2014 22:00	0.0	0	0	0	0	1
07/03/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	61.9 #	0 #	2 #	0 #	0 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	46.7	0	1	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/04/2014 00:00	0.0	0	0	0	0	1
07/04/2014 01:00	0.0	0	0	0	0	1
07/04/2014 02:00	0.0	0	0	0	0	1
07/04/2014 03:00	0.0	0	0	0	0	1
07/04/2014 04:00	0.0	0	0	0	0	1
07/04/2014 05:00	0.0	0	0	0	0	1
07/04/2014 06:00	0.0	0	0	0	0	1
07/04/2014 07:00	0.0	0	0	0	0	1
07/04/2014 08:00	0.0	0	0	0	0	1
07/04/2014 09:00	0.0	0	0	0	0	1
07/04/2014 10:00	0.0	0	0	0	0	1
07/04/2014 11:00	0.0	0	0	0	0	1
07/04/2014 12:00	0.0	0	0	0	0	1
07/04/2014 13:00	0.0	0	0	0	0	1
07/04/2014 14:00	0.0	0	0	0	0	1
07/04/2014 15:00	0.0	0	0	0	0	1
07/04/2014 16:00	0.0	0	0	0	0	1
07/04/2014 17:00	0.0	0	0	0	0	1
07/04/2014 18:00	0.0	0	0	0	0	1
07/04/2014 19:00	0.0	0	0	0	0	1
07/04/2014 20:00	1.8	0	0	0	1	0
07/04/2014 21:00	0.0	0	0	0	0	0
07/04/2014 22:00	0.0	0	0	0	0	0
07/04/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.8 #	0 #	0 #	0 #	1 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.8	0	0	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/05/2014 00:00	0.0	0	0	0	0	0
07/05/2014 01:00	0.0	0	0	0	0	0
07/05/2014 02:00	0.0	0	0	0	0	0
07/05/2014 03:00	0.0	0	0	0	0	0
07/05/2014 04:00	0.0	0	0	0	0	0
07/05/2014 05:00	0.0	0	0	0	0	0
07/05/2014 06:00	0.0	0	0	0	0	0
07/05/2014 07:00	0.0	0	0	0	0	0
07/05/2014 08:00	0.0	0	0	0	0	0
07/05/2014 09:00	0.0	0	0	0	0	0
07/05/2014 10:00	40.9	0	1	0	0	0
07/05/2014 11:00	38.8	0	1	0	0	0
07/05/2014 12:00	0.0	0	0	0	0	1
07/05/2014 13:00	0.0	0	0	0	0	1
07/05/2014 14:00	0.0	0	0	0	0	1
07/05/2014 15:00	0.0	0	0	0	0	1
07/05/2014 16:00	0.0	0	0	0	0	1
07/05/2014 17:00	0.0	0	0	0	0	1
07/05/2014 18:00	0.0	0	0	0	0	1
07/05/2014 19:00	0.0	0	0	0	0	1
07/05/2014 20:00	0.0	0	0	0	0	1
07/05/2014 21:00	0.0	0	0	0	0	1
07/05/2014 22:00	0.0	0	0	0	0	1
07/05/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	79.7 #	0 #	2 #	0 #	0 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	40.9	0	1	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/06/2014 00:00	0.0	0	0	0	0	1
07/06/2014 01:00	0.0	0	0	0	0	1
07/06/2014 02:00	2.3	0	0	0	1	0
07/06/2014 03:00	0.0	0	0	0	0	0
07/06/2014 04:00	0.0	0	0	0	0	0
07/06/2014 05:00	0.0	0	0	0	0	0
07/06/2014 06:00	0.0	0	0	0	0	0
07/06/2014 07:00	0.0	0	0	0	0	0
07/06/2014 08:00	0.0	0	0	0	0	0
07/06/2014 09:00	7.3	0	0	1	0	0
07/06/2014 10:00	66.5	0	0	1	0	0
07/06/2014 11:00	0.0	0	0	0	0	1
07/06/2014 12:00	0.0	0	0	0	0	1
07/06/2014 13:00	0.0	0	0	0	0	1
07/06/2014 14:00	0.0	0	0	0	0	1
07/06/2014 15:00	0.0	0	0	0	0	1
07/06/2014 16:00	0.0	0	0	0	0	1
07/06/2014 17:00	0.0	0	0	0	0	1
07/06/2014 18:00	0.0	0	0	0	0	1
07/06/2014 19:00	0.0	0	0	0	0	1
07/06/2014 20:00	0.0	0	0	0	0	1
07/06/2014 21:00	0.0	0	0	0	0	1
07/06/2014 22:00	0.0	0	0	0	0	1
07/06/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	76.1 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	66.5	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/07/2014 00:00	0.0	0	0	0	0	1
07/07/2014 01:00	0.0	0	0	0	0	1
07/07/2014 02:00	0.0	0	0	0	0	1
07/07/2014 03:00	0.0	0	0	0	0	1
07/07/2014 04:00	0.0	0	0	0	0	1
07/07/2014 05:00	0.0	0	0	0	0	1
07/07/2014 06:00	0.0	0	0	0	0	1
07/07/2014 07:00	0.0	0	0	0	0	1
07/07/2014 08:00	0.0	0	0	0	0	1
07/07/2014 09:00	0.0	0	0	0	0	1
07/07/2014 10:00	0.0	0	0	0	0	1
07/07/2014 11:00	0.0	0	0	0	0	1
07/07/2014 12:00	0.0	0	0	0	0	1
07/07/2014 13:00	0.0	0	0	0	0	1
07/07/2014 14:00	0.0	0	0	0	0	1
07/07/2014 15:00	0.0	0	0	0	0	1
07/07/2014 16:00	0.0	0	0	0	0	1
07/07/2014 17:00	0.0	0	0	0	0	1
07/07/2014 18:00	0.0	0	0	0	0	1
07/07/2014 19:00	0.0	0	0	0	0	1
07/07/2014 20:00	0.0	0	0	0	0	1
07/07/2014 21:00	0.0	0	0	0	0	1
07/07/2014 22:00	0.0	0	0	0	0	1
07/07/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/08/2014 00:00	0.0	0	0	0	0	1
07/08/2014 01:00	0.0	0	0	0	0	1
07/08/2014 02:00	0.0	0	0	0	0	1
07/08/2014 03:00	0.0	0	0	0	0	1
07/08/2014 04:00	0.0	0	0	0	0	1
07/08/2014 05:00	0.0	0	0	0	0	1
07/08/2014 06:00	0.0	0	0	0	0	1
07/08/2014 07:00	0.0	0	0	0	0	1
07/08/2014 08:00	0.0	0	0	0	0	1
07/08/2014 09:00	0.0	0	0	0	0	1
07/08/2014 10:00	0.0	0	0	0	0	1
07/08/2014 11:00	0.0	0	0	0	0	1
07/08/2014 12:00	0.0	0	0	0	0	1
07/08/2014 13:00	0.0	0	0	0	0	1
07/08/2014 14:00	0.0	0	0	0	0	1
07/08/2014 15:00	0.0	0	0	0	0	1
07/08/2014 16:00	0.0	0	0	0	0	1
07/08/2014 17:00	0.0	0	0	0	0	1
07/08/2014 18:00	0.0	0	0	0	0	1
07/08/2014 19:00	0.0	0	0	0	0	1
07/08/2014 20:00	0.0	0	0	0	0	1
07/08/2014 21:00	0.0	0	0	0	0	1
07/08/2014 22:00	0.0	0	0	0	0	1
07/08/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/09/2014 00:00	0.0	0	0	0	0	1
07/09/2014 01:00	0.0	0	0	0	0	1
07/09/2014 02:00	0.0	0	0	0	0	1
07/09/2014 03:00	0.0	0	0	0	0	1
07/09/2014 04:00	0.0	0	0	0	0	1
07/09/2014 05:00	0.0	0	0	0	0	1
07/09/2014 06:00	0.0	0	0	0	0	1
07/09/2014 07:00	0.0	0	0	0	0	1
07/09/2014 08:00	0.0	0	0	0	0	1
07/09/2014 09:00	0.0	0	0	0	0	1
07/09/2014 10:00	0.0	0	0	0	0	1
07/09/2014 11:00	0.0	0	0	0	0	1
07/09/2014 12:00	0.0	0	0	0	0	1
07/09/2014 13:00	0.0	0	0	0	0	1
07/09/2014 14:00	0.0	0	0	0	0	1
07/09/2014 15:00	0.0	0	0	0	0	1
07/09/2014 16:00	0.0	0	0	0	0	1
07/09/2014 17:00	0.0	0	0	0	0	1
07/09/2014 18:00	0.0	0	0	0	0	1
07/09/2014 19:00	0.0	0	0	0	0	1
07/09/2014 20:00	0.0	0	0	0	0	1
07/09/2014 21:00	0.0	0	0	0	0	1
07/09/2014 22:00	0.0	0	0	0	0	1
07/09/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/10/2014 00:00	0.0	0	0	0	0	1
07/10/2014 01:00	0.0	0	0	0	0	1
07/10/2014 02:00	0.0	0	0	0	0	1
07/10/2014 03:00	0.0	0	0	0	0	1
07/10/2014 04:00	0.0	0	0	0	0	1
07/10/2014 05:00	0.0	0	0	0	0	1
07/10/2014 06:00	0.0	0	0	0	0	1
07/10/2014 07:00	0.0	0	0	0	0	1
07/10/2014 08:00	0.0	0	0	0	0	1
07/10/2014 09:00	0.0	0	0	0	0	1
07/10/2014 10:00	0.0	0	0	0	0	1
07/10/2014 11:00	0.0	0	0	0	0	1
07/10/2014 12:00	0.0	0	0	0	0	1
07/10/2014 13:00	0.0	0	0	0	0	1
07/10/2014 14:00	0.0	0	0	0	0	1
07/10/2014 15:00	0.0	0	0	0	0	1
07/10/2014 16:00	0.0	0	0	0	0	1
07/10/2014 17:00	0.0	0	0	0	0	1
07/10/2014 18:00	0.0	0	0	0	0	1
07/10/2014 19:00	0.0	0	0	0	0	1
07/10/2014 20:00	0.0	0	0	0	0	1
07/10/2014 21:00	0.0	0	0	0	0	1
07/10/2014 22:00	0.0	0	0	0	0	1
07/10/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/11/2014 00:00	1.3	0	0	0	1	0
07/11/2014 01:00	0.0	0	0	0	0	0
07/11/2014 02:00	0.0	0	0	0	0	0
07/11/2014 03:00	0.0	0	0	0	0	0
07/11/2014 04:00	0.0	0	0	0	0	0
07/11/2014 05:00	0.0	0	0	0	0	0
07/11/2014 06:00	0.0	0	0	0	0	0
07/11/2014 07:00	0.0	0	0	0	0	0
07/11/2014 08:00	0.0	0	0	0	0	0
07/11/2014 09:00	51.3	0	1	0	0	0
07/11/2014 10:00	54.9	0	1	0	0	0
07/11/2014 11:00	0.0	0	0	0	0	1
07/11/2014 12:00	0.0	0	0	0	0	1
07/11/2014 13:00	0.0	0	0	0	0	1
07/11/2014 14:00	0.0	0	0	0	0	1
07/11/2014 15:00	0.0	0	0	0	0	1
07/11/2014 16:00	0.0	0	0	0	0	1
07/11/2014 17:00	0.0	0	0	0	0	1
07/11/2014 18:00	0.0	0	0	0	0	1
07/11/2014 19:00	0.0	0	0	0	0	1
07/11/2014 20:00	0.0	0	0	0	0	1
07/11/2014 21:00	0.0	0	0	0	0	1
07/11/2014 22:00	0.0	0	0	0	0	1
07/11/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	107.5 #	0 #	2 #	0 #	1 #	13 #
Minimum:	0.0	0	0	0	0	0
Maximum:	54.9	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/12/2014 00:00	1.6	0	0	0	1	0
07/12/2014 01:00	0.0	0	0	0	0	0
07/12/2014 02:00	0.0	0	0	0	0	0
07/12/2014 03:00	0.0	0	0	0	0	0
07/12/2014 04:00	0.0	0	0	0	0	0
07/12/2014 05:00	0.0	0	0	0	0	0
07/12/2014 06:00	33.9	0	0	1	0	0
07/12/2014 07:00	31.9	0	0	1	0	0
07/12/2014 08:00	0.0	0	0	0	0	1
07/12/2014 09:00	0.0	0	0	0	0	1
07/12/2014 10:00	0.0	0	0	0	0	1
07/12/2014 11:00	0.0	0	0	0	0	1
07/12/2014 12:00	0.0	0	0	0	0	1
07/12/2014 13:00	0.0	0	0	0	0	1
07/12/2014 14:00	0.0	0	0	0	0	1
07/12/2014 15:00	0.0	0	0	0	0	1
07/12/2014 16:00	0.0	0	0	0	0	1
07/12/2014 17:00	0.0	0	0	0	0	1
07/12/2014 18:00	0.0	0	0	0	0	1
07/12/2014 19:00	0.0	0	0	0	0	1
07/12/2014 20:00	0.0	0	0	0	0	1
07/12/2014 21:00	0.0	0	0	0	0	1
07/12/2014 22:00	0.0	0	0	0	0	1
07/12/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	67.4 #	0 #	0 #	2 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	33.9	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/13/2014 00:00	0.0	0	0	0	0	1
07/13/2014 01:00	1.5	0	0	0	1	0
07/13/2014 02:00	0.0	0	0	0	0	0
07/13/2014 03:00	0.0	0	0	0	0	0
07/13/2014 04:00	0.0	0	0	0	0	0
07/13/2014 05:00	0.0	0	0	0	0	0
07/13/2014 06:00	0.0	0	0	0	0	0
07/13/2014 07:00	0.0	0	0	0	0	0
07/13/2014 08:00	0.0	0	0	0	0	0
07/13/2014 09:00	0.0	0	0	0	0	0
07/13/2014 10:00	26.1	0	1	0	0	0
07/13/2014 11:00	43.8	0	1	0	0	0
07/13/2014 12:00	0.0	0	0	0	0	1
07/13/2014 13:00	0.0	0	0	0	0	1
07/13/2014 14:00	0.0	0	0	0	0	1
07/13/2014 15:00	0.0	0	0	0	0	1
07/13/2014 16:00	0.0	0	0	0	0	1
07/13/2014 17:00	0.0	0	0	0	0	1
07/13/2014 18:00	0.0	0	0	0	0	1
07/13/2014 19:00	0.0	0	0	0	0	1
07/13/2014 20:00	0.0	0	0	0	0	1
07/13/2014 21:00	0.0	0	0	0	0	1
07/13/2014 22:00	0.0	0	0	0	0	1
07/13/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	71.4 #	0 #	2 #	0 #	1 #	13 #
Minimum:	0.0	0	0	0	0	0
Maximum:	43.8	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/14/2014 00:00	0.0	0	0	0	0	1
07/14/2014 01:00	0.0	0	0	0	0	1
07/14/2014 02:00	0.0	0	0	0	0	1
07/14/2014 03:00	0.0	0	0	0	0	1
07/14/2014 04:00	0.0	0	0	0	0	1
07/14/2014 05:00	0.0	0	0	0	0	1
07/14/2014 06:00	0.0	0	0	0	0	1
07/14/2014 07:00	0.0	0	0	0	0	1
07/14/2014 08:00	0.0	0	0	0	0	1
07/14/2014 09:00	0.0	0	0	0	0	1
07/14/2014 10:00	0.0	0	0	0	0	1
07/14/2014 11:00	0.0	0	0	0	0	1
07/14/2014 12:00	0.0	0	0	0	0	1
07/14/2014 13:00	0.0	0	0	0	0	1
07/14/2014 14:00	0.0	0	0	0	0	1
07/14/2014 15:00	0.0	0	0	0	0	1
07/14/2014 16:00	0.0	0	0	0	0	1
07/14/2014 17:00	0.0	0	0	0	0	1
07/14/2014 18:00	0.0	0	0	0	0	1
07/14/2014 19:00	0.0	0	0	0	0	1
07/14/2014 20:00	0.0	0	0	0	0	1
07/14/2014 21:00	0.0	0	0	0	0	1
07/14/2014 22:00	0.0	0	0	0	0	1
07/14/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/15/2014 00:00	0.0	0	0	0	0	1
07/15/2014 01:00	0.0	0	0	0	0	1
07/15/2014 02:00	0.0	0	0	0	0	1
07/15/2014 03:00	0.0	0	0	0	0	1
07/15/2014 04:00	0.0	0	0	0	0	1
07/15/2014 05:00	0.0	0	0	0	0	1
07/15/2014 06:00	0.0	0	0	0	0	1
07/15/2014 07:00	0.0	0	0	0	0	1
07/15/2014 08:00	0.0	0	0	0	0	1
07/15/2014 09:00	0.0	0	0	0	0	1
07/15/2014 10:00	0.0	0	0	0	0	1
07/15/2014 11:00	0.0	0	0	0	0	1
07/15/2014 12:00	0.0	0	0	0	0	1
07/15/2014 13:00	0.0	0	0	0	0	1
07/15/2014 14:00	0.0	0	0	0	0	1
07/15/2014 15:00	0.0	0	0	0	0	1
07/15/2014 16:00	0.0	0	0	0	0	1
07/15/2014 17:00	0.0	0	0	0	0	1
07/15/2014 18:00	0.0	0	0	0	0	1
07/15/2014 19:00	0.0	0	0	0	0	1
07/15/2014 20:00	0.0	0	0	0	0	1
07/15/2014 21:00	0.0	0	0	0	0	1
07/15/2014 22:00	0.0	0	0	0	0	1
07/15/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/16/2014 00:00	0.0	0	0	0	0	1
07/16/2014 01:00	0.0	0	0	0	0	1
07/16/2014 02:00	0.0	0	0	0	0	1
07/16/2014 03:00	0.0	0	0	0	0	1
07/16/2014 04:00	0.0	0	0	0	0	1
07/16/2014 05:00	0.0	0	0	0	0	1
07/16/2014 06:00	0.0	0	0	0	0	1
07/16/2014 07:00	0.0	0	0	0	0	1
07/16/2014 08:00	0.0	0	0	0	0	1
07/16/2014 09:00	0.0	0	0	0	0	1
07/16/2014 10:00	0.0	0	0	0	0	1
07/16/2014 11:00	0.0	0	0	0	0	1
07/16/2014 12:00	0.0	0	0	0	0	1
07/16/2014 13:00	0.0	0	0	0	0	1
07/16/2014 14:00	0.0	0	0	0	0	1
07/16/2014 15:00	0.0	0	0	0	0	1
07/16/2014 16:00	0.0	0	0	0	0	1
07/16/2014 17:00	0.0	0	0	0	0	1
07/16/2014 18:00	0.0	0	0	0	0	1
07/16/2014 19:00	0.0	0	0	0	0	1
07/16/2014 20:00	0.0	0	0	0	0	1
07/16/2014 21:00	0.0	0	0	0	0	1
07/16/2014 22:00	0.0	0	0	0	0	1
07/16/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/17/2014 00:00	1.7	0	0	0	1	0
07/17/2014 01:00	0.0	0	0	0	0	0
07/17/2014 02:00	0.0	0	0	0	0	0
07/17/2014 03:00	0.0	0	0	0	0	0
07/17/2014 04:00	17.6	0	0	1	0	0
07/17/2014 05:00	17.5	0	0	1	0	0
07/17/2014 06:00	0.0	0	0	0	0	1
07/17/2014 07:00	0.0	0	0	0	0	1
07/17/2014 08:00	0.0	0	0	0	0	1
07/17/2014 09:00	0.0	0	0	0	0	1
07/17/2014 10:00	0.0	0	0	0	0	1
07/17/2014 11:00	0.0	0	0	0	0	1
07/17/2014 12:00	0.0	0	0	0	0	1
07/17/2014 13:00	0.0	0	0	0	0	1
07/17/2014 14:00	0.0	0	0	0	0	1
07/17/2014 15:00	0.0	0	0	0	0	1
07/17/2014 16:00	0.0	0	0	0	0	1
07/17/2014 17:00	0.0	0	0	0	0	1
07/17/2014 18:00	0.0	0	0	0	0	1
07/17/2014 19:00	0.0	0	0	0	0	1
07/17/2014 20:00	0.0	0	0	0	0	1
07/17/2014 21:00	0.0	0	0	0	0	1
07/17/2014 22:00	0.0	0	0	0	0	1
07/17/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	36.8 #	0 #	0 #	2 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	17.6	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/18/2014 00:00	1.7	0	0	0	1	0
07/18/2014 01:00	0.0	0	0	0	0	0
07/18/2014 02:00	0.0	0	0	0	0	0
07/18/2014 03:00	8.3	0	0	1	0	0
07/18/2014 04:00	1.3	0	0	1	0	0
07/18/2014 05:00	0.0	0	0	0	0	1
07/18/2014 06:00	0.0	0	0	0	0	1
07/18/2014 07:00	0.0	0	0	0	0	1
07/18/2014 08:00	0.0	0	0	0	0	1
07/18/2014 09:00	0.0	0	0	0	0	1
07/18/2014 10:00	0.0	0	0	0	0	1
07/18/2014 11:00	0.0	0	0	0	0	1
07/18/2014 12:00	0.0	0	0	0	0	1
07/18/2014 13:00	0.0	0	0	0	0	1
07/18/2014 14:00	0.0	0	0	0	0	1
07/18/2014 15:00	0.0	0	0	0	0	1
07/18/2014 16:00	0.0	0	0	0	0	1
07/18/2014 17:00	0.0	0	0	0	0	1
07/18/2014 18:00	0.0	0	0	0	0	1
07/18/2014 19:00	0.0	0	0	0	0	1
07/18/2014 20:00	0.0	0	0	0	0	1
07/18/2014 21:00	0.0	0	0	0	0	1
07/18/2014 22:00	0.0	0	0	0	0	1
07/18/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	11.3 #	0 #	0 #	2 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	8.3	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/19/2014 00:00	2.0	0	0	0	1	0
07/19/2014 01:00	0.0	0	0	0	0	0
07/19/2014 02:00	0.0	0	0	0	0	0
07/19/2014 03:00	0.0	0	0	0	0	0
07/19/2014 04:00	0.0	0	0	0	0	0
07/19/2014 05:00	0.0	0	0	0	0	0
07/19/2014 06:00	0.0	0	0	0	0	0
07/19/2014 07:00	0.0	0	0	0	0	0
07/19/2014 08:00	0.0	0	0	0	0	0
07/19/2014 09:00	20.3	0	1	0	0	0
07/19/2014 10:00	45.8	0	1	0	0	0
07/19/2014 11:00	0.0	0	0	0	0	1
07/19/2014 12:00	0.0	0	0	0	0	1
07/19/2014 13:00	0.0	0	0	0	0	1
07/19/2014 14:00	0.0	0	0	0	0	1
07/19/2014 15:00	0.0	0	0	0	0	1
07/19/2014 16:00	0.0	0	0	0	0	1
07/19/2014 17:00	0.0	0	0	0	0	1
07/19/2014 18:00	0.0	0	0	0	0	1
07/19/2014 19:00	0.0	0	0	0	0	1
07/19/2014 20:00	0.0	0	0	0	0	1
07/19/2014 21:00	0.0	0	0	0	0	1
07/19/2014 22:00	0.0	0	0	0	0	1
07/19/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	68.1 #	0 #	2 #	0 #	1 #	13 #
Minimum:	0.0	0	0	0	0	0
Maximum:	45.8	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/20/2014 00:00	1.5	0	0	0	1	0
07/20/2014 01:00	0.0	0	0	0	0	0
07/20/2014 02:00	0.0	0	0	0	0	0
07/20/2014 03:00	0.0	0	0	0	0	0
07/20/2014 04:00	0.0	0	0	0	0	0
07/20/2014 05:00	0.0	0	0	0	0	0
07/20/2014 06:00	0.0	0	0	0	0	0
07/20/2014 07:00	0.0	0	0	0	0	0
07/20/2014 08:00	0.0	0	0	0	0	0
07/20/2014 09:00	0.0	0	0	0	0	0
07/20/2014 10:00	0.0	0	0	0	0	0
07/20/2014 11:00	0.0	0	0	0	0	0
07/20/2014 12:00	0.0	0	0	0	0	0
07/20/2014 13:00	0.0	0	0	0	0	0
07/20/2014 14:00	0.0	0	0	0	0	0
07/20/2014 15:00	0.0	0	0	0	0	0
07/20/2014 16:00	0.0	0	0	0	0	0
07/20/2014 17:00	0.0	0	0	0	0	0
07/20/2014 18:00	0.0	0	0	0	0	0
07/20/2014 19:00	0.0	0	0	0	0	0
07/20/2014 20:00	0.0	0	0	0	0	0
07/20/2014 21:00	0.0	0	0	0	0	0
07/20/2014 22:00	0.0	0	0	0	0	0
07/20/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	1.5 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	1.5	0	0	0	1	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/21/2014 00:00	0.0	0	0	0	0	0
07/21/2014 01:00	64.8	0	1	0	0	0
07/21/2014 02:00	32.5	0	1	0	0	0
07/21/2014 03:00	23.8	0	1	0	0	0
07/21/2014 04:00	0.0	0	0	0	0	1
07/21/2014 05:00	0.0	0	0	0	0	1
07/21/2014 06:00	0.0	0	0	0	0	1
07/21/2014 07:00	0.0	0	0	0	0	1
07/21/2014 08:00	0.0	0	0	0	0	1
07/21/2014 09:00	0.0	0	0	0	0	1
07/21/2014 10:00	0.0	0	0	0	0	1
07/21/2014 11:00	0.0	0	0	0	0	1
07/21/2014 12:00	0.0	0	0	0	0	1
07/21/2014 13:00	0.0	0	0	0	0	1
07/21/2014 14:00	0.0	0	0	0	0	1
07/21/2014 15:00	0.0	0	0	0	0	1
07/21/2014 16:00	0.0	0	0	0	0	1
07/21/2014 17:00	0.0	0	0	0	0	1
07/21/2014 18:00	0.0	0	0	0	0	1
07/21/2014 19:00	0.0	0	0	0	0	1
07/21/2014 20:00	0.0	0	0	0	0	1
07/21/2014 21:00	0.0	0	0	0	0	1
07/21/2014 22:00	0.0	0	0	0	0	1
07/21/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	121.1 #	0 #	3 #	0 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	64.8	0	1	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/22/2014 00:00	0.0	0	0	0	0	1
07/22/2014 01:00	0.0	0	0	0	0	1
07/22/2014 02:00	0.0	0	0	0	0	1
07/22/2014 03:00	0.0	0	0	0	0	1
07/22/2014 04:00	0.0	0	0	0	0	1
07/22/2014 05:00	0.0	0	0	0	0	1
07/22/2014 06:00	0.0	0	0	0	0	1
07/22/2014 07:00	0.0	0	0	0	0	1
07/22/2014 08:00	0.0	0	0	0	0	1
07/22/2014 09:00	0.0	0	0	0	0	1
07/22/2014 10:00	0.0	0	0	0	0	1
07/22/2014 11:00	0.0	0	0	0	0	1
07/22/2014 12:00	0.0	0	0	0	0	1
07/22/2014 13:00	0.0	0	0	0	0	1
07/22/2014 14:00	0.0	0	0	0	0	1
07/22/2014 15:00	0.0	0	0	0	0	1
07/22/2014 16:00	0.0	0	0	0	0	1
07/22/2014 17:00	0.0	0	0	0	0	1
07/22/2014 18:00	0.0	0	0	0	0	1
07/22/2014 19:00	0.0	0	0	0	0	1
07/22/2014 20:00	0.0	0	0	0	0	1
07/22/2014 21:00	0.0	0	0	0	0	1
07/22/2014 22:00	0.0	0	0	0	0	1
07/22/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/23/2014 00:00	0.0	0	0	0	0	1
07/23/2014 01:00	0.0	0	0	0	0	1
07/23/2014 02:00	0.0	0	0	0	0	1
07/23/2014 03:00	0.0	0	0	0	0	1
07/23/2014 04:00	0.0	0	0	0	0	1
07/23/2014 05:00	0.0	0	0	0	0	1
07/23/2014 06:00	0.0	0	0	0	0	1
07/23/2014 07:00	0.0	0	0	0	0	1
07/23/2014 08:00	0.0	0	0	0	0	1
07/23/2014 09:00	0.0	0	0	0	0	1
07/23/2014 10:00	0.0	0	0	0	0	1
07/23/2014 11:00	0.0	0	0	0	0	1
07/23/2014 12:00	0.0	0	0	0	0	1
07/23/2014 13:00	0.0	0	0	0	0	1
07/23/2014 14:00	0.0	0	0	0	0	1
07/23/2014 15:00	0.0	0	0	0	0	1
07/23/2014 16:00	0.0	0	0	0	0	1
07/23/2014 17:00	0.0	0	0	0	0	1
07/23/2014 18:00	0.0	0	0	0	0	1
07/23/2014 19:00	0.0	0	0	0	0	1
07/23/2014 20:00	0.0	0	0	0	0	1
07/23/2014 21:00	0.0	0	0	0	0	1
07/23/2014 22:00	0.0	0	0	0	0	1
07/23/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/24/2014 00:00	0.0	0	0	0	0	1
07/24/2014 01:00	0.0	0	0	0	0	1
07/24/2014 02:00	0.0	0	0	0	0	1
07/24/2014 03:00	0.0	0	0	0	0	1
07/24/2014 04:00	0.0	0	0	0	0	1
07/24/2014 05:00	0.0	0	0	0	0	1
07/24/2014 06:00	0.0	0	0	0	0	1
07/24/2014 07:00	0.0	0	0	0	0	1
07/24/2014 08:00	0.0	0	0	0	0	1
07/24/2014 09:00	0.0	0	0	0	0	1
07/24/2014 10:00	0.0	0	0	0	0	1
07/24/2014 11:00	0.0	0	0	0	0	1
07/24/2014 12:00	0.0	0	0	0	0	1
07/24/2014 13:00	0.0	0	0	0	0	1
07/24/2014 14:00	0.0	0	0	0	0	1
07/24/2014 15:00	0.0	0	0	0	0	1
07/24/2014 16:00	0.0	0	0	0	0	1
07/24/2014 17:00	0.0	0	0	0	0	1
07/24/2014 18:00	0.0	0	0	0	0	1
07/24/2014 19:00	0.0	0	0	0	0	1
07/24/2014 20:00	0.0	0	0	0	0	1
07/24/2014 21:00	0.0	0	0	0	0	1
07/24/2014 22:00	0.0	0	0	0	0	1
07/24/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/25/2014 00:00	0.0	0	0	0	0	1
07/25/2014 01:00	0.0	0	0	0	0	1
07/25/2014 02:00	0.0	0	0	0	0	1
07/25/2014 03:00	0.0	0	0	0	0	1
07/25/2014 04:00	0.0	0	0	0	0	1
07/25/2014 05:00	0.0	0	0	0	0	1
07/25/2014 06:00	0.0	0	0	0	0	1
07/25/2014 07:00	0.0	0	0	0	0	1
07/25/2014 08:00	0.0	0	0	0	0	1
07/25/2014 09:00	0.0	0	0	0	0	1
07/25/2014 10:00	0.0	0	0	0	0	1
07/25/2014 11:00	0.0	0	0	0	0	1
07/25/2014 12:00	0.0	0	0	0	0	1
07/25/2014 13:00	0.0	0	0	0	0	1
07/25/2014 14:00	0.0	0	0	0	0	1
07/25/2014 15:00	0.0	0	0	0	0	1
07/25/2014 16:00	0.0	0	0	0	0	1
07/25/2014 17:00	0.0	0	0	0	0	1
07/25/2014 18:00	0.0	0	0	0	0	1
07/25/2014 19:00	0.0	0	0	0	0	1
07/25/2014 20:00	0.0	0	0	0	0	1
07/25/2014 21:00	0.0	0	0	0	0	1
07/25/2014 22:00	0.0	0	0	0	0	1
07/25/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/26/2014 00:00	0.0	0	0	0	0	1
07/26/2014 01:00	0.0	0	0	0	0	1
07/26/2014 02:00	0.0	0	0	0	0	1
07/26/2014 03:00	0.0	0	0	0	0	1
07/26/2014 04:00	0.0	0	0	0	0	1
07/26/2014 05:00	0.0	0	0	0	0	1
07/26/2014 06:00	0.0	0	0	0	0	1
07/26/2014 07:00	0.0	0	0	0	0	1
07/26/2014 08:00	0.0	0	0	0	0	1
07/26/2014 09:00	0.0	0	0	0	0	1
07/26/2014 10:00	0.0	0	0	0	0	1
07/26/2014 11:00	0.0	0	0	0	0	1
07/26/2014 12:00	0.0	0	0	0	0	1
07/26/2014 13:00	0.0	0	0	0	0	1
07/26/2014 14:00	0.0	0	0	0	0	1
07/26/2014 15:00	0.0	0	0	0	0	1
07/26/2014 16:00	0.0	0	0	0	0	1
07/26/2014 17:00	0.0	0	0	0	0	1
07/26/2014 18:00	0.0	0	0	0	0	1
07/26/2014 19:00	0.0	0	0	0	0	1
07/26/2014 20:00	0.0	0	0	0	0	1
07/26/2014 21:00	0.0	0	0	0	0	1
07/26/2014 22:00	0.0	0	0	0	0	1
07/26/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/27/2014 00:00	0.0	0	0	0	0	1
07/27/2014 01:00	0.0	0	0	0	0	1
07/27/2014 02:00	0.0	0	0	0	0	1
07/27/2014 03:00	0.0	0	0	0	0	1
07/27/2014 04:00	0.0	0	0	0	0	1
07/27/2014 05:00	0.0	0	0	0	0	1
07/27/2014 06:00	0.0	0	0	0	0	1
07/27/2014 07:00	0.0	0	0	0	0	1
07/27/2014 08:00	0.0	0	0	0	0	1
07/27/2014 09:00	0.0	0	0	0	0	1
07/27/2014 10:00	0.0	0	0	0	0	1
07/27/2014 11:00	0.0	0	0	0	0	1
07/27/2014 12:00	0.0	0	0	0	0	1
07/27/2014 13:00	0.0	0	0	0	0	1
07/27/2014 14:00	0.0	0	0	0	0	1
07/27/2014 15:00	0.0	0	0	0	0	1
07/27/2014 16:00	0.0	0	0	0	0	1
07/27/2014 17:00	0.0	0	0	0	0	1
07/27/2014 18:00	0.0	0	0	0	0	1
07/27/2014 19:00	0.0	0	0	0	0	1
07/27/2014 20:00	0.0	0	0	0	0	1
07/27/2014 21:00	0.0	0	0	0	0	1
07/27/2014 22:00	0.0	0	0	0	0	1
07/27/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/28/2014 00:00	0.0	0	0	0	0	1
07/28/2014 01:00	0.0	0	0	0	0	1
07/28/2014 02:00	0.0	0	0	0	0	1
07/28/2014 03:00	0.0	0	0	0	0	1
07/28/2014 04:00	0.0	0	0	0	0	1
07/28/2014 05:00	0.0	0	0	0	0	1
07/28/2014 06:00	0.0	0	0	0	0	1
07/28/2014 07:00	0.0	0	0	0	0	1
07/28/2014 08:00	0.0	0	0	0	0	1
07/28/2014 09:00	0.0	0	0	0	0	1
07/28/2014 10:00	0.0	0	0	0	0	1
07/28/2014 11:00	0.0	0	0	0	0	1
07/28/2014 12:00	0.0	0	0	0	0	1
07/28/2014 13:00	0.0	0	0	0	0	1
07/28/2014 14:00	0.0	0	0	0	0	1
07/28/2014 15:00	0.0	0	0	0	0	1
07/28/2014 16:00	0.0	0	0	0	0	1
07/28/2014 17:00	0.0	0	0	0	0	1
07/28/2014 18:00	0.0	0	0	0	0	1
07/28/2014 19:00	0.0	0	0	0	0	1
07/28/2014 20:00	0.0	0	0	0	0	1
07/28/2014 21:00	0.0	0	0	0	0	1
07/28/2014 22:00	0.0	0	0	0	0	1
07/28/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/29/2014 00:00	0.0	0	0	0	0	1
07/29/2014 01:00	0.0	0	0	0	0	1
07/29/2014 02:00	0.0	0	0	0	0	1
07/29/2014 03:00	0.0	0	0	0	0	1
07/29/2014 04:00	0.0	0	0	0	0	1
07/29/2014 05:00	0.0	0	0	0	0	1
07/29/2014 06:00	0.0	0	0	0	0	1
07/29/2014 07:00	0.0	0	0	0	0	1
07/29/2014 08:00	0.0	0	0	0	0	1
07/29/2014 09:00	0.0	0	0	0	0	1
07/29/2014 10:00	0.0	0	0	0	0	1
07/29/2014 11:00	0.0	0	0	0	0	1
07/29/2014 12:00	0.0	0	0	0	0	1
07/29/2014 13:00	0.0	0	0	0	0	1
07/29/2014 14:00	0.0	0	0	0	0	1
07/29/2014 15:00	0.0	0	0	0	0	1
07/29/2014 16:00	0.0	0	0	0	0	1
07/29/2014 17:00	0.0	0	0	0	0	1
07/29/2014 18:00	0.0	0	0	0	0	1
07/29/2014 19:00	0.0	0	0	0	0	1
07/29/2014 20:00	0.0	0	0	0	0	1
07/29/2014 21:00	0.0	0	0	0	0	1
07/29/2014 22:00	0.0	0	0	0	0	1
07/29/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/30/2014 00:00	0.0	0	0	0	0	1
07/30/2014 01:00	0.0	0	0	0	0	1
07/30/2014 02:00	0.0	0	0	0	0	1
07/30/2014 03:00	0.0	0	0	0	0	1
07/30/2014 04:00	0.0	0	0	0	0	1
07/30/2014 05:00	0.0	0	0	0	0	1
07/30/2014 06:00	0.0	0	0	0	0	1
07/30/2014 07:00	0.0	0	0	0	0	1
07/30/2014 08:00	0.0	0	0	0	0	1
07/30/2014 09:00	0.0	0	0	0	0	1
07/30/2014 10:00	0.0	0	0	0	0	1
07/30/2014 11:00	0.0	0	0	0	0	1
07/30/2014 12:00	0.0	0	0	0	0	1
07/30/2014 13:00	0.0	0	0	0	0	1
07/30/2014 14:00	0.0	0	0	0	0	1
07/30/2014 15:00	0.0	0	0	0	0	1
07/30/2014 16:00	0.0	0	0	0	0	1
07/30/2014 17:00	0.0	0	0	0	0	1
07/30/2014 18:00	0.0	0	0	0	0	1
07/30/2014 19:00	0.0	0	0	0	0	1
07/30/2014 20:00	0.0	0	0	0	0	1
07/30/2014 21:00	0.0	0	0	0	0	1
07/30/2014 22:00	0.0	0	0	0	0	1
07/30/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/31/2014 00:00	0.0	0	0	0	0	1
07/31/2014 01:00	0.0	0	0	0	0	1
07/31/2014 02:00	0.0	0	0	0	0	1
07/31/2014 03:00	0.0	0	0	0	0	1
07/31/2014 04:00	0.0	0	0	0	0	1
07/31/2014 05:00	0.0	0	0	0	0	1
07/31/2014 06:00	0.0	0	0	0	0	1
07/31/2014 07:00	0.0	0	0	0	0	1
07/31/2014 08:00	0.0	0	0	0	0	1
07/31/2014 09:00	0.0	0	0	0	0	1
07/31/2014 10:00	0.0	0	0	0	0	1
07/31/2014 11:00	0.0	0	0	0	0	1
07/31/2014 12:00	0.0	0	0	0	0	1
07/31/2014 13:00	0.0	0	0	0	0	1
07/31/2014 14:00	0.0	0	0	0	0	1
07/31/2014 15:00	0.0	0	0	0	0	1
07/31/2014 16:00	0.0	0	0	0	0	1
07/31/2014 17:00	0.0	0	0	0	0	1
07/31/2014 18:00	0.0	0	0	0	0	1
07/31/2014 19:00	0.0	0	0	0	0	1
07/31/2014 20:00	0.0	0	0	0	0	1
07/31/2014 21:00	0.0	0	0	0	0	1
07/31/2014 22:00	0.0	0	0	0	0	1
07/31/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/01/2014 00:00	0.0	0	0	0	0	1
08/01/2014 01:00	0.0	0	0	0	0	1
08/01/2014 02:00	0.0	0	0	0	0	1
08/01/2014 03:00	0.0	0	0	0	0	1
08/01/2014 04:00	0.0	0	0	0	0	1
08/01/2014 05:00	0.0	0	0	0	0	1
08/01/2014 06:00	0.0	0	0	0	0	1
08/01/2014 07:00	0.0	0	0	0	0	1
08/01/2014 08:00	0.0	0	0	0	0	1
08/01/2014 09:00	0.0	0	0	0	0	1
08/01/2014 10:00	0.0	0	0	0	0	1
08/01/2014 11:00	0.0	0	0	0	0	1
08/01/2014 12:00	0.0	0	0	0	0	1
08/01/2014 13:00	0.0	0	0	0	0	1
08/01/2014 14:00	0.0	0	0	0	0	1
08/01/2014 15:00	0.0	0	0	0	0	1
08/01/2014 16:00	0.0	0	0	0	0	1
08/01/2014 17:00	0.0	0	0	0	0	1
08/01/2014 18:00	0.0	0	0	0	0	1
08/01/2014 19:00	0.0	0	0	0	0	1
08/01/2014 20:00	0.0	0	0	0	0	1
08/01/2014 21:00	0.0	0	0	0	0	1
08/01/2014 22:00	0.0	0	0	0	0	1
08/01/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/02/2014 00:00	0.0	0	0	0	0	1
08/02/2014 01:00	0.0	0	0	0	0	1
08/02/2014 02:00	0.0	0	0	0	0	1
08/02/2014 03:00	0.0	0	0	0	0	1
08/02/2014 04:00	0.0	0	0	0	0	1
08/02/2014 05:00	0.0	0	0	0	0	1
08/02/2014 06:00	0.0	0	0	0	0	1
08/02/2014 07:00	0.0	0	0	0	0	1
08/02/2014 08:00	0.0	0	0	0	0	1
08/02/2014 09:00	0.0	0	0	0	0	1
08/02/2014 10:00	0.0	0	0	0	0	1
08/02/2014 11:00	0.0	0	0	0	0	1
08/02/2014 12:00	0.0	0	0	0	0	1
08/02/2014 13:00	0.0	0	0	0	0	1
08/02/2014 14:00	0.0	0	0	0	0	1
08/02/2014 15:00	0.0	0	0	0	0	1
08/02/2014 16:00	0.0	0	0	0	0	1
08/02/2014 17:00	0.0	0	0	0	0	1
08/02/2014 18:00	0.0	0	0	0	0	1
08/02/2014 19:00	0.0	0	0	0	0	1
08/02/2014 20:00	0.0	0	0	0	0	1
08/02/2014 21:00	0.0	0	0	0	0	1
08/02/2014 22:00	0.0	0	0	0	0	1
08/02/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/03/2014 00:00	0.0	0	0	0	0	1
08/03/2014 01:00	0.0	0	0	0	0	1
08/03/2014 02:00	0.0	0	0	0	0	1
08/03/2014 03:00	0.0	0	0	0	0	1
08/03/2014 04:00	0.0	0	0	0	0	1
08/03/2014 05:00	0.0	0	0	0	0	1
08/03/2014 06:00	0.0	0	0	0	0	1
08/03/2014 07:00	0.0	0	0	0	0	1
08/03/2014 08:00	0.0	0	0	0	0	1
08/03/2014 09:00	0.0	0	0	0	0	1
08/03/2014 10:00	0.0	0	0	0	0	1
08/03/2014 11:00	0.0	0	0	0	0	1
08/03/2014 12:00	0.0	0	0	0	0	1
08/03/2014 13:00	0.0	0	0	0	0	1
08/03/2014 14:00	0.0	0	0	0	0	1
08/03/2014 15:00	0.0	0	0	0	0	1
08/03/2014 16:00	0.0	0	0	0	0	1
08/03/2014 17:00	0.0	0	0	0	0	1
08/03/2014 18:00	0.0	0	0	0	0	1
08/03/2014 19:00	0.0	0	0	0	0	1
08/03/2014 20:00	0.0	0	0	0	0	1
08/03/2014 21:00	0.0	0	0	0	0	1
08/03/2014 22:00	0.0	0	0	0	0	1
08/03/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/04/2014 00:00	0.0	0	0	0	0	1
08/04/2014 01:00	0.0	0	0	0	0	1
08/04/2014 02:00	0.0	0	0	0	0	1
08/04/2014 03:00	0.0	0	0	0	0	1
08/04/2014 04:00	0.0	0	0	0	0	1
08/04/2014 05:00	0.0	0	0	0	0	1
08/04/2014 06:00	0.0	0	0	0	0	1
08/04/2014 07:00	0.0	0	0	0	0	1
08/04/2014 08:00	0.0	0	0	0	0	1
08/04/2014 09:00	0.0	0	0	0	0	1
08/04/2014 10:00	0.0	0	0	0	0	1
08/04/2014 11:00	0.0	0	0	0	0	1
08/04/2014 12:00	0.0	0	0	0	0	1
08/04/2014 13:00	0.0	0	0	0	0	1
08/04/2014 14:00	0.0	0	0	0	0	1
08/04/2014 15:00	0.0	0	0	0	0	1
08/04/2014 16:00	0.0	0	0	0	0	1
08/04/2014 17:00	0.0	0	0	0	0	1
08/04/2014 18:00	0.0	0	0	0	0	1
08/04/2014 19:00	0.0	0	0	0	0	1
08/04/2014 20:00	0.0	0	0	0	0	1
08/04/2014 21:00	0.0	0	0	0	0	1
08/04/2014 22:00	0.0	0	0	0	0	1
08/04/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/05/2014 00:00	0.0	0	0	0	0	1
08/05/2014 01:00	0.0	0	0	0	0	1
08/05/2014 02:00	0.0	0	0	0	0	1
08/05/2014 03:00	0.0	0	0	0	0	1
08/05/2014 04:00	0.0	0	0	0	0	1
08/05/2014 05:00	0.0	0	0	0	0	1
08/05/2014 06:00	0.0	0	0	0	0	1
08/05/2014 07:00	0.0	0	0	0	0	1
08/05/2014 08:00	0.0	0	0	0	0	1
08/05/2014 09:00	0.0	0	0	0	0	1
08/05/2014 10:00	0.0	0	0	0	0	1
08/05/2014 11:00	0.0	0	0	0	0	1
08/05/2014 12:00	0.0	0	0	0	0	1
08/05/2014 13:00	0.0	0	0	0	0	1
08/05/2014 14:00	0.0	0	0	0	0	1
08/05/2014 15:00	0.0	0	0	0	0	1
08/05/2014 16:00	0.0	0	0	0	0	1
08/05/2014 17:00	0.0	0	0	0	0	1
08/05/2014 18:00	0.0	0	0	0	0	1
08/05/2014 19:00	0.0	0	0	0	0	1
08/05/2014 20:00	0.0	0	0	0	0	1
08/05/2014 21:00	0.0	0	0	0	0	1
08/05/2014 22:00	0.0	0	0	0	0	1
08/05/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/06/2014 00:00	0.0	0	0	0	0	1
08/06/2014 01:00	0.0	0	0	0	0	1
08/06/2014 02:00	0.0	0	0	0	0	1
08/06/2014 03:00	0.0	0	0	0	0	1
08/06/2014 04:00	0.0	0	0	0	0	1
08/06/2014 05:00	0.0	0	0	0	0	1
08/06/2014 06:00	0.0	0	0	0	0	1
08/06/2014 07:00	0.0	0	0	0	0	1
08/06/2014 08:00	0.0	0	0	0	0	1
08/06/2014 09:00	0.0	0	0	0	0	1
08/06/2014 10:00	0.0	0	0	0	0	1
08/06/2014 11:00	0.0	0	0	0	0	1
08/06/2014 12:00	0.0	0	0	0	0	1
08/06/2014 13:00	0.0	0	0	0	0	1
08/06/2014 14:00	0.0	0	0	0	0	1
08/06/2014 15:00	0.0	0	0	0	0	1
08/06/2014 16:00	0.0	0	0	0	0	1
08/06/2014 17:00	0.0	0	0	0	0	1
08/06/2014 18:00	0.0	0	0	0	0	1
08/06/2014 19:00	0.0	0	0	0	0	1
08/06/2014 20:00	0.0	0	0	0	0	1
08/06/2014 21:00	0.0	0	0	0	0	1
08/06/2014 22:00	0.0	0	0	0	0	1
08/06/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/07/2014 00:00	0.7	0	0	0	1	0
08/07/2014 01:00	0.0	0	0	0	0	0
08/07/2014 02:00	0.0	0	0	0	0	0
08/07/2014 03:00	0.0	0	0	0	0	0
08/07/2014 04:00	0.0	0	0	0	0	0
08/07/2014 05:00	0.0	0	0	0	0	0
08/07/2014 06:00	0.0	0	0	0	0	0
08/07/2014 07:00	36.3	0	0	1	0	0
08/07/2014 08:00	25.7	0	0	1	0	0
08/07/2014 09:00	0.0	0	0	0	0	1
08/07/2014 10:00	0.0	0	0	0	0	1
08/07/2014 11:00	0.0	0	0	0	0	1
08/07/2014 12:00	0.0	0	0	0	0	1
08/07/2014 13:00	0.0	0	0	0	0	1
08/07/2014 14:00	0.0	0	0	0	0	1
08/07/2014 15:00	0.0	0	0	0	0	1
08/07/2014 16:00	0.0	0	0	0	0	1
08/07/2014 17:00	0.0	0	0	0	0	1
08/07/2014 18:00	0.0	0	0	0	0	1
08/07/2014 19:00	0.0	0	0	0	0	1
08/07/2014 20:00	0.0	0	0	0	0	1
08/07/2014 21:00	0.0	0	0	0	0	1
08/07/2014 22:00	0.0	0	0	0	0	1
08/07/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	62.7 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	36.3	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/08/2014 00:00	0.0	0	0	0	0	1
08/08/2014 01:00	0.0	0	0	0	0	1
08/08/2014 02:00	0.0	0	0	0	0	1
08/08/2014 03:00	0.0	0	0	0	0	1
08/08/2014 04:00	0.0	0	0	0	0	1
08/08/2014 05:00	0.0	0	0	0	0	1
08/08/2014 06:00	0.0	0	0	0	0	1
08/08/2014 07:00	0.0	0	0	0	0	1
08/08/2014 08:00	0.0	0	0	0	0	1
08/08/2014 09:00	0.0	0	0	0	0	1
08/08/2014 10:00	0.0	0	0	0	0	1
08/08/2014 11:00	0.0	0	0	0	0	1
08/08/2014 12:00	0.0	0	0	0	0	1
08/08/2014 13:00	0.0	0	0	0	0	1
08/08/2014 14:00	0.0	0	0	0	0	1
08/08/2014 15:00	0.0	0	0	0	0	1
08/08/2014 16:00	0.0	0	0	0	0	1
08/08/2014 17:00	0.0	0	0	0	0	1
08/08/2014 18:00	0.0	0	0	0	0	1
08/08/2014 19:00	0.0	0	0	0	0	1
08/08/2014 20:00	0.0	0	0	0	0	1
08/08/2014 21:00	0.0	0	0	0	0	1
08/08/2014 22:00	0.0	0	0	0	0	1
08/08/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/09/2014 00:00	0.0	0	0	0	0	1
08/09/2014 01:00	0.0	0	0	0	0	1
08/09/2014 02:00	2.1	0	0	0	1	0
08/09/2014 03:00	0.0	0	0	0	0	0
08/09/2014 04:00	0.0	0	0	0	0	0
08/09/2014 05:00	0.0	0	0	0	0	0
08/09/2014 06:00	29.5	0	0	1	0	0
08/09/2014 07:00	3.3	0	0	1	0	0
08/09/2014 08:00	0.0	0	0	0	0	1
08/09/2014 09:00	0.0	0	0	0	0	1
08/09/2014 10:00	0.0	0	0	0	0	1
08/09/2014 11:00	0.0	0	0	0	0	1
08/09/2014 12:00	0.0	0	0	0	0	1
08/09/2014 13:00	0.0	0	0	0	0	1
08/09/2014 14:00	0.0	0	0	0	0	1
08/09/2014 15:00	0.0	0	0	0	0	1
08/09/2014 16:00	0.0	0	0	0	0	1
08/09/2014 17:00	0.0	0	0	0	0	1
08/09/2014 18:00	0.0	0	0	0	0	1
08/09/2014 19:00	0.0	0	0	0	0	1
08/09/2014 20:00	0.0	0	0	0	0	1
08/09/2014 21:00	0.0	0	0	0	0	1
08/09/2014 22:00	0.0	0	0	0	0	1
08/09/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	34.9 #	0 #	0 #	2 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	29.5	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/10/2014 00:00	1.7	0	0	0	1	0
08/10/2014 01:00	0.0	0	0	0	0	0
08/10/2014 02:00	0.0	0	0	0	0	0
08/10/2014 03:00	0.0	0	0	0	0	0
08/10/2014 04:00	0.0	0	0	0	0	0
08/10/2014 05:00	0.0	0	0	0	0	0
08/10/2014 06:00	0.0	0	0	0	0	0
08/10/2014 07:00	46.4	0	0	1	0	0
08/10/2014 08:00	11.3	0	0	1	0	0
08/10/2014 09:00	0.0	0	0	0	0	1
08/10/2014 10:00	0.0	0	0	0	0	1
08/10/2014 11:00	0.0	0	0	0	0	1
08/10/2014 12:00	0.0	0	0	0	0	1
08/10/2014 13:00	0.0	0	0	0	0	1
08/10/2014 14:00	0.0	0	0	0	0	1
08/10/2014 15:00	0.0	0	0	0	0	1
08/10/2014 16:00	0.0	0	0	0	0	1
08/10/2014 17:00	0.0	0	0	0	0	1
08/10/2014 18:00	0.0	0	0	0	0	1
08/10/2014 19:00	0.0	0	0	0	0	1
08/10/2014 20:00	0.0	0	0	0	0	1
08/10/2014 21:00	0.0	0	0	0	0	1
08/10/2014 22:00	0.0	0	0	0	0	1
08/10/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	59.4 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	46.4	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/11/2014 00:00	0.0	0	0	0	0	1
08/11/2014 01:00	0.0	0	0	0	0	1
08/11/2014 02:00	0.0	0	0	0	0	1
08/11/2014 03:00	0.0	0	0	0	0	1
08/11/2014 04:00	0.0	0	0	0	0	1
08/11/2014 05:00	0.0	0	0	0	0	1
08/11/2014 06:00	0.0	0	0	0	0	1
08/11/2014 07:00	0.0	0	0	0	0	1
08/11/2014 08:00	0.0	0	0	0	0	1
08/11/2014 09:00	0.0	0	0	0	0	1
08/11/2014 10:00	0.0	0	0	0	0	1
08/11/2014 11:00	0.0	0	0	0	0	1
08/11/2014 12:00	0.0	0	0	0	0	1
08/11/2014 13:00	0.0	0	0	0	0	1
08/11/2014 14:00	0.0	0	0	0	0	1
08/11/2014 15:00	0.0	0	0	0	0	1
08/11/2014 16:00	0.0	0	0	0	0	1
08/11/2014 17:00	0.0	0	0	0	0	1
08/11/2014 18:00	0.0	0	0	0	0	1
08/11/2014 19:00	0.0	0	0	0	0	1
08/11/2014 20:00	0.0	0	0	0	0	1
08/11/2014 21:00	0.0	0	0	0	0	1
08/11/2014 22:00	0.0	0	0	0	0	1
08/11/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/12/2014 00:00	0.0	0	0	0	0	1
08/12/2014 01:00	0.0	0	0	0	0	1
08/12/2014 02:00	0.0	0	0	0	0	1
08/12/2014 03:00	0.0	0	0	0	0	1
08/12/2014 04:00	0.0	0	0	0	0	1
08/12/2014 05:00	0.0	0	0	0	0	1
08/12/2014 06:00	0.0	0	0	0	0	1
08/12/2014 07:00	0.0	0	0	0	0	1
08/12/2014 08:00	0.0	0	0	0	0	1
08/12/2014 09:00	0.0	0	0	0	0	1
08/12/2014 10:00	0.0	0	0	0	0	1
08/12/2014 11:00	0.0	0	0	0	0	1
08/12/2014 12:00	0.0	0	0	0	0	1
08/12/2014 13:00	0.0	0	0	0	0	1
08/12/2014 14:00	0.0	0	0	0	0	1
08/12/2014 15:00	0.0	0	0	0	0	1
08/12/2014 16:00	0.0	0	0	0	0	1
08/12/2014 17:00	0.0	0	0	0	0	1
08/12/2014 18:00	0.0	0	0	0	0	1
08/12/2014 19:00	0.0	0	0	0	0	1
08/12/2014 20:00	0.0	0	0	0	0	1
08/12/2014 21:00	0.0	0	0	0	0	1
08/12/2014 22:00	0.0	0	0	0	0	1
08/12/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/13/2014 00:00	0.0	0	0	0	0	1
08/13/2014 01:00	1.6	0	0	0	1	0
08/13/2014 02:00	0.0	0	0	0	0	0
08/13/2014 03:00	0.0	0	0	0	0	0
08/13/2014 04:00	0.0	0	0	0	0	0
08/13/2014 05:00	13.3	0	0	1	0	0
08/13/2014 06:00	2.1	0	0	1	0	0
08/13/2014 07:00	0.0	0	0	0	0	1
08/13/2014 08:00	0.0	0	0	0	0	1
08/13/2014 09:00	0.0	0	0	0	0	1
08/13/2014 10:00	0.0	0	0	0	0	1
08/13/2014 11:00	0.0	0	0	0	0	1
08/13/2014 12:00	0.0	0	0	0	0	1
08/13/2014 13:00	0.0	0	0	0	0	1
08/13/2014 14:00	0.0	0	0	0	0	1
08/13/2014 15:00	0.0	0	0	0	0	1
08/13/2014 16:00	0.0	0	0	0	0	1
08/13/2014 17:00	0.0	0	0	0	0	1
08/13/2014 18:00	0.0	0	0	0	0	1
08/13/2014 19:00	0.0	0	0	0	0	1
08/13/2014 20:00	0.0	0	0	0	0	1
08/13/2014 21:00	0.0	0	0	0	0	1
08/13/2014 22:00	0.0	0	0	0	0	1
08/13/2014 23:00	1.4	0	0	0	1	0
Average/Sum#:	18.4 #	0 #	0 #	2 #	2 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	13.3	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/14/2014 00:00	0.0	0	0	0	0	0
08/14/2014 01:00	0.0	0	0	0	0	0
08/14/2014 02:00	0.0	0	0	0	0	0
08/14/2014 03:00	0.0	0	0	0	0	0
08/14/2014 04:00	0.0	0	0	0	0	0
08/14/2014 05:00	0.0	0	0	0	0	0
08/14/2014 06:00	0.0	0	0	0	0	0
08/14/2014 07:00	0.0	0	0	0	0	0
08/14/2014 08:00	0.0	0	0	0	0	0
08/14/2014 09:00	0.0	0	0	0	0	0
08/14/2014 10:00	0.0	0	0	0	0	0
08/14/2014 11:00	0.0	0	0	0	0	0
08/14/2014 12:00	0.0	0	0	0	0	0
08/14/2014 13:00	0.0	0	0	0	0	0
08/14/2014 14:00	0.0	0	0	0	0	0
08/14/2014 15:00	0.0	0	0	0	0	0
08/14/2014 16:00	0.0	0	0	0	0	0
08/14/2014 17:00	0.0	0	0	0	0	0
08/14/2014 18:00	0.0	0	0	0	0	0
08/14/2014 19:00	0.0	0	0	0	0	0
08/14/2014 20:00	0.0	0	0	0	0	0
08/14/2014 21:00	0.0	0	0	0	0	0
08/14/2014 22:00	0.0	0	0	0	0	0
08/14/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/15/2014 00:00	0.0	0	0	0	0	0
08/15/2014 01:00	0.0	0	0	0	0	0
08/15/2014 02:00	0.0	0	0	0	0	0
08/15/2014 03:00	0.0	0	0	0	0	0
08/15/2014 04:00	0.0	0	0	0	0	0
08/15/2014 05:00	0.0	0	0	0	0	0
08/15/2014 06:00	0.0	0	0	0	0	0
08/15/2014 07:00	0.0	0	0	0	0	0
08/15/2014 08:00	0.0	0	0	0	0	0
08/15/2014 09:00	0.0	0	0	0	0	0
08/15/2014 10:00	0.0	0	0	0	0	0
08/15/2014 11:00	0.0	0	0	0	0	0
08/15/2014 12:00	0.0	0	0	0	0	0
08/15/2014 13:00	0.0	0	0	0	0	0
08/15/2014 14:00	0.0	0	0	0	0	0
08/15/2014 15:00	0.0	0	0	0	0	0
08/15/2014 16:00	0.0	0	0	0	0	0
08/15/2014 17:00	0.0	0	0	0	0	0
08/15/2014 18:00	0.0	0	0	0	0	0
08/15/2014 19:00	0.0	0	0	0	0	0
08/15/2014 20:00	0.0	0	0	0	0	0
08/15/2014 21:00	0.0	0	0	0	0	0
08/15/2014 22:00	0.0	0	0	0	0	0
08/15/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/16/2014 00:00	0.0	0	0	0	0	0
08/16/2014 01:00	0.0	0	0	0	0	0
08/16/2014 02:00	0.0	0	0	0	0	0
08/16/2014 03:00	0.0	0	0	0	0	0
08/16/2014 04:00	0.0	0	0	0	0	0
08/16/2014 05:00	0.0	0	0	0	0	0
08/16/2014 06:00	0.0	0	0	0	0	0
08/16/2014 07:00	0.0	0	0	0	0	0
08/16/2014 08:00	0.0	0	0	0	0	0
08/16/2014 09:00	0.0	0	0	0	0	0
08/16/2014 10:00	0.0	0	0	0	0	0
08/16/2014 11:00	0.0	0	0	0	0	0
08/16/2014 12:00	0.0	0	0	0	0	0
08/16/2014 13:00	0.0	0	0	0	0	0
08/16/2014 14:00	0.0	0	0	0	0	0
08/16/2014 15:00	0.0	0	0	0	0	0
08/16/2014 16:00	0.0	0	0	0	0	0
08/16/2014 17:00	0.0	0	0	0	0	0
08/16/2014 18:00	0.0	0	0	0	0	0
08/16/2014 19:00	0.0	0	0	0	0	0
08/16/2014 20:00	0.0	0	0	0	0	0
08/16/2014 21:00	0.0	0	0	0	0	0
08/16/2014 22:00	0.0	0	0	0	0	0
08/16/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/17/2014 00:00	0.0	0	0	0	0	0
08/17/2014 01:00	0.0	0	0	0	0	0
08/17/2014 02:00	0.0	0	0	0	0	0
08/17/2014 03:00	0.0	0	0	0	0	0
08/17/2014 04:00	0.0	0	0	0	0	0
08/17/2014 05:00	0.0	0	0	0	0	0
08/17/2014 06:00	0.0	0	0	0	0	0
08/17/2014 07:00	0.0	0	0	0	0	0
08/17/2014 08:00	0.0	0	0	0	0	0
08/17/2014 09:00	0.0	0	0	0	0	0
08/17/2014 10:00	0.0	0	0	0	0	0
08/17/2014 11:00	0.0	0	0	0	0	0
08/17/2014 12:00	0.0	0	0	0	0	0
08/17/2014 13:00	0.0	0	0	0	0	0
08/17/2014 14:00	0.0	0	0	0	0	0
08/17/2014 15:00	0.0	0	0	0	0	0
08/17/2014 16:00	0.0	0	0	0	0	0
08/17/2014 17:00	0.0	0	0	0	0	0
08/17/2014 18:00	0.0	0	0	0	0	0
08/17/2014 19:00	0.0	0	0	0	0	0
08/17/2014 20:00	0.0	0	0	0	0	0
08/17/2014 21:00	0.0	0	0	0	0	0
08/17/2014 22:00	0.0	0	0	0	0	0
08/17/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/18/2014 00:00	0.0	0	0	0	0	0
08/18/2014 01:00	0.0	0	0	0	0	0
08/18/2014 02:00	0.0	0	0	0	0	0
08/18/2014 03:00	0.0	0	0	0	0	0
08/18/2014 04:00	0.0	0	0	0	0	0
08/18/2014 05:00	0.0	0	0	0	0	0
08/18/2014 06:00	0.0	0	0	0	0	0
08/18/2014 07:00	0.0	0	0	0	0	0
08/18/2014 08:00	0.0	0	0	0	0	0
08/18/2014 09:00	0.0	0	0	0	0	0
08/18/2014 10:00	0.0	0	0	0	0	0
08/18/2014 11:00	0.0	0	0	0	0	0
08/18/2014 12:00	0.0	0	0	0	0	0
08/18/2014 13:00	0.0	0	0	0	0	0
08/18/2014 14:00	0.0	0	0	0	0	0
08/18/2014 15:00	0.0	0	0	0	0	0
08/18/2014 16:00	0.0	0	0	0	0	0
08/18/2014 17:00	0.0	0	0	0	0	0
08/18/2014 18:00	0.0	0	0	0	0	0
08/18/2014 19:00	0.0	0	0	0	0	0
08/18/2014 20:00	0.0	0	0	0	0	0
08/18/2014 21:00	0.0	0	0	0	0	0
08/18/2014 22:00	0.0	0	0	0	0	0
08/18/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/19/2014 00:00	0.0	0	0	0	0	0
08/19/2014 01:00	0.0	0	0	0	0	0
08/19/2014 02:00	0.0	0	0	0	0	0
08/19/2014 03:00	0.0	0	0	0	0	0
08/19/2014 04:00	0.0	0	0	0	0	0
08/19/2014 05:00	0.0	0	0	0	0	0
08/19/2014 06:00	0.0	0	0	0	0	0
08/19/2014 07:00	0.0	0	0	0	0	0
08/19/2014 08:00	0.0	0	0	0	0	0
08/19/2014 09:00	0.0	0	0	0	0	0
08/19/2014 10:00	0.0	0	0	0	0	0
08/19/2014 11:00	0.0	0	0	0	0	0
08/19/2014 12:00	0.0	0	0	0	0	0
08/19/2014 13:00	0.0	0	0	0	0	0
08/19/2014 14:00	0.0	0	0	0	0	0
08/19/2014 15:00	0.0	0	0	0	0	0
08/19/2014 16:00	0.0	0	0	0	0	0
08/19/2014 17:00	0.0	0	0	0	0	0
08/19/2014 18:00	0.0	0	0	0	0	0
08/19/2014 19:00	0.0	0	0	0	0	0
08/19/2014 20:00	0.0	0	0	0	0	0
08/19/2014 21:00	0.0	0	0	0	0	0
08/19/2014 22:00	0.0	0	0	0	0	0
08/19/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/20/2014 00:00	0.0	0	0	0	0	0
08/20/2014 01:00	0.0	0	0	0	0	0
08/20/2014 02:00	0.0	0	0	0	0	0
08/20/2014 03:00	0.0	0	0	0	0	0
08/20/2014 04:00	0.0	0	0	0	0	0
08/20/2014 05:00	0.0	0	0	0	0	0
08/20/2014 06:00	0.0	0	0	0	0	0
08/20/2014 07:00	0.0	0	0	0	0	0
08/20/2014 08:00	0.0	0	0	0	0	0
08/20/2014 09:00	0.0	0	0	0	0	0
08/20/2014 10:00	0.0	0	0	0	0	0
08/20/2014 11:00	0.0	0	0	0	0	0
08/20/2014 12:00	0.0	0	0	0	0	0
08/20/2014 13:00	0.0	0	0	0	0	0
08/20/2014 14:00	0.0	0	0	0	0	0
08/20/2014 15:00	0.0	0	0	0	0	0
08/20/2014 16:00	0.0	0	0	0	0	0
08/20/2014 17:00	0.0	0	0	0	0	0
08/20/2014 18:00	0.0	0	0	0	0	0
08/20/2014 19:00	0.0	0	0	0	0	0
08/20/2014 20:00	0.0	0	0	0	0	0
08/20/2014 21:00	0.0	0	0	0	0	0
08/20/2014 22:00	0.0	0	0	0	0	0
08/20/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/21/2014 00:00	0.0	0	0	0	0	0
08/21/2014 01:00	0.0	0	0	0	0	0
08/21/2014 02:00	0.0	0	0	0	0	0
08/21/2014 03:00	0.0	0	0	0	0	0
08/21/2014 04:00	0.0	0	0	0	0	0
08/21/2014 05:00	0.0	0	0	0	0	0
08/21/2014 06:00	0.0	0	0	0	0	0
08/21/2014 07:00	0.0	0	0	0	0	0
08/21/2014 08:00	0.0	0	0	0	0	0
08/21/2014 09:00	0.0	0	0	0	0	0
08/21/2014 10:00	0.0	0	0	0	0	0
08/21/2014 11:00	0.0	0	0	0	0	0
08/21/2014 12:00	0.0	0	0	0	0	0
08/21/2014 13:00	0.0	0	0	0	0	0
08/21/2014 14:00	0.0	0	0	0	0	0
08/21/2014 15:00	0.0	0	0	0	0	0
08/21/2014 16:00	0.0	0	0	0	0	0
08/21/2014 17:00	0.0	0	0	0	0	0
08/21/2014 18:00	0.0	0	0	0	0	0
08/21/2014 19:00	0.0	0	0	0	0	0
08/21/2014 20:00	0.0	0	0	0	0	0
08/21/2014 21:00	0.0	0	0	0	0	0
08/21/2014 22:00	0.0	0	0	0	0	0
08/21/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/22/2014 00:00	0.0	0	0	0	0	0
08/22/2014 01:00	0.0	0	0	0	0	0
08/22/2014 02:00	0.0	0	0	0	0	0
08/22/2014 03:00	0.0	0	0	0	0	0
08/22/2014 04:00	0.0	0	0	0	0	0
08/22/2014 05:00	0.0	0	0	0	0	0
08/22/2014 06:00	0.0	0	0	0	0	0
08/22/2014 07:00	0.0	0	0	0	0	0
08/22/2014 08:00	0.0	0	0	0	0	0
08/22/2014 09:00	0.0	0	0	0	0	0
08/22/2014 10:00	0.0	0	0	0	0	0
08/22/2014 11:00	0.0	0	0	0	0	0
08/22/2014 12:00	0.0	0	0	0	0	0
08/22/2014 13:00	0.0	0	0	0	0	0
08/22/2014 14:00	0.0	0	0	0	0	0
08/22/2014 15:00	0.0	0	0	0	0	0
08/22/2014 16:00	0.0	0	0	0	0	0
08/22/2014 17:00	0.0	0	0	0	0	0
08/22/2014 18:00	0.0	0	0	0	0	0
08/22/2014 19:00	0.0	0	0	0	0	0
08/22/2014 20:00	0.0	0	0	0	0	0
08/22/2014 21:00	0.0	0	0	0	0	0
08/22/2014 22:00	0.0	0	0	0	0	0
08/22/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/23/2014 00:00	0.0	0	0	0	0	0
08/23/2014 01:00	0.0	0	0	0	0	0
08/23/2014 02:00	0.0	0	0	0	0	0
08/23/2014 03:00	0.0	0	0	0	0	0
08/23/2014 04:00	0.0	0	0	0	0	0
08/23/2014 05:00	0.0	0	0	0	0	0
08/23/2014 06:00	0.0	0	0	0	0	0
08/23/2014 07:00	0.0	0	0	0	0	0
08/23/2014 08:00	0.0	0	0	0	0	0
08/23/2014 09:00	0.0	0	0	0	0	0
08/23/2014 10:00	0.0	0	0	0	0	0
08/23/2014 11:00	0.0	0	0	0	0	0
08/23/2014 12:00	0.0	0	0	0	0	0
08/23/2014 13:00	0.0	0	0	0	0	0
08/23/2014 14:00	0.0	0	0	0	0	0
08/23/2014 15:00	0.0	0	0	0	0	0
08/23/2014 16:00	0.0	0	0	0	0	0
08/23/2014 17:00	0.0	0	0	0	0	0
08/23/2014 18:00	0.0	0	0	0	0	0
08/23/2014 19:00	0.0	0	0	0	0	0
08/23/2014 20:00	0.0	0	0	0	0	0
08/23/2014 21:00	0.0	0	0	0	0	0
08/23/2014 22:00	0.0	0	0	0	0	0
08/23/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/24/2014 00:00	0.0	0	0	0	0	0
08/24/2014 01:00	0.0	0	0	0	0	0
08/24/2014 02:00	0.0	0	0	0	0	0
08/24/2014 03:00	0.0	0	0	0	0	0
08/24/2014 04:00	0.0	0	0	0	0	0
08/24/2014 05:00	0.0	0	0	0	0	0
08/24/2014 06:00	0.0	0	0	0	0	0
08/24/2014 07:00	0.0	0	0	0	0	0
08/24/2014 08:00	0.0	0	0	0	0	0
08/24/2014 09:00	0.0	0	0	0	0	0
08/24/2014 10:00	0.0	0	0	0	0	0
08/24/2014 11:00	0.0	0	0	0	0	0
08/24/2014 12:00	0.0	0	0	0	0	0
08/24/2014 13:00	0.0	0	0	0	0	0
08/24/2014 14:00	0.0	0	0	0	0	0
08/24/2014 15:00	0.0	0	0	0	0	0
08/24/2014 16:00	0.0	0	0	0	0	0
08/24/2014 17:00	0.0	0	0	0	0	0
08/24/2014 18:00	0.0	0	0	0	0	0
08/24/2014 19:00	0.0	0	0	0	0	0
08/24/2014 20:00	0.0	0	0	0	0	0
08/24/2014 21:00	0.0	0	0	0	0	0
08/24/2014 22:00	0.0	0	0	0	0	0
08/24/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/25/2014 00:00	0.0	0	0	0	0	0
08/25/2014 01:00	0.0	0	0	0	0	0
08/25/2014 02:00	0.0	0	0	0	0	0
08/25/2014 03:00	0.0	0	0	0	0	0
08/25/2014 04:00	0.0	0	0	0	0	0
08/25/2014 05:00	0.0	0	0	0	0	0
08/25/2014 06:00	0.0	0	0	0	0	0
08/25/2014 07:00	0.0	0	0	0	0	0
08/25/2014 08:00	0.0	0	0	0	0	0
08/25/2014 09:00	0.0	0	0	0	0	0
08/25/2014 10:00	0.0	0	0	0	0	0
08/25/2014 11:00	0.0	0	0	0	0	0
08/25/2014 12:00	0.0	0	0	0	0	0
08/25/2014 13:00	0.0	0	0	0	0	0
08/25/2014 14:00	0.0	0	0	0	0	0
08/25/2014 15:00	0.0	0	0	0	0	0
08/25/2014 16:00	0.0	0	0	0	0	0
08/25/2014 17:00	0.0	0	0	0	0	0
08/25/2014 18:00	0.0	0	0	0	0	0
08/25/2014 19:00	0.0	0	0	0	0	0
08/25/2014 20:00	0.0	0	0	0	0	0
08/25/2014 21:00	0.0	0	0	0	0	0
08/25/2014 22:00	0.0	0	0	0	0	0
08/25/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/26/2014 00:00	0.0	0	0	0	0	0
08/26/2014 01:00	0.0	0	0	0	0	0
08/26/2014 02:00	0.0	0	0	0	0	0
08/26/2014 03:00	0.0	0	0	0	0	0
08/26/2014 04:00	0.0	0	0	0	0	0
08/26/2014 05:00	0.0	0	0	0	0	0
08/26/2014 06:00	0.0	0	0	0	0	0
08/26/2014 07:00	0.0	0	0	0	0	0
08/26/2014 08:00	0.0	0	0	0	0	0
08/26/2014 09:00	0.0	0	0	0	0	0
08/26/2014 10:00	0.0	0	0	0	0	0
08/26/2014 11:00	0.0	0	0	0	0	0
08/26/2014 12:00	0.0	0	0	0	0	0
08/26/2014 13:00	0.0	0	0	0	0	0
08/26/2014 14:00	0.0	0	0	0	0	0
08/26/2014 15:00	0.0	0	0	0	0	0
08/26/2014 16:00	0.0	0	0	0	0	0
08/26/2014 17:00	0.0	0	0	0	0	0
08/26/2014 18:00	0.0	0	0	0	0	0
08/26/2014 19:00	0.0	0	0	0	0	0
08/26/2014 20:00	0.0	0	0	0	0	0
08/26/2014 21:00	0.0	0	0	0	0	0
08/26/2014 22:00	0.0	0	0	0	0	0
08/26/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/27/2014 00:00	0.0	0	0	0	0	0
08/27/2014 01:00	0.0	0	0	0	0	0
08/27/2014 02:00	0.0	0	0	0	0	0
08/27/2014 03:00	0.0	0	0	0	0	0
08/27/2014 04:00	0.0	0	0	0	0	0
08/27/2014 05:00	0.0	0	0	0	0	0
08/27/2014 06:00	0.0	0	0	0	0	0
08/27/2014 07:00	0.0	0	0	0	0	0
08/27/2014 08:00	0.0	0	0	0	0	0
08/27/2014 09:00	0.0	0	0	0	0	0
08/27/2014 10:00	0.0	0	0	0	0	0
08/27/2014 11:00	0.0	0	0	0	0	0
08/27/2014 12:00	0.0	0	0	0	0	0
08/27/2014 13:00	0.0	0	0	0	0	0
08/27/2014 14:00	0.0	0	0	0	0	0
08/27/2014 15:00	0.0	0	0	0	0	0
08/27/2014 16:00	0.0	0	0	0	0	0
08/27/2014 17:00	0.0	0	0	0	0	0
08/27/2014 18:00	0.0	0	0	0	0	0
08/27/2014 19:00	0.0	0	0	0	0	0
08/27/2014 20:00	0.0	0	0	0	0	0
08/27/2014 21:00	0.0	0	0	0	0	0
08/27/2014 22:00	0.0	0	0	0	0	0
08/27/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/28/2014 00:00	0.0	0	0	0	0	0
08/28/2014 01:00	0.0	0	0	0	0	0
08/28/2014 02:00	0.0	0	0	0	0	0
08/28/2014 03:00	0.0	0	0	0	0	0
08/28/2014 04:00	0.0	0	0	0	0	0
08/28/2014 05:00	0.0	0	0	0	0	0
08/28/2014 06:00	0.0	0	0	0	0	0
08/28/2014 07:00	0.0	0	0	0	0	0
08/28/2014 08:00	0.0	0	0	0	0	0
08/28/2014 09:00	0.0	0	0	0	0	0
08/28/2014 10:00	0.0	0	0	0	0	0
08/28/2014 11:00	0.0	0	0	0	0	0
08/28/2014 12:00	0.0	0	0	0	0	0
08/28/2014 13:00	0.0	0	0	0	0	0
08/28/2014 14:00	0.0	0	0	0	0	0
08/28/2014 15:00	0.0	0	0	0	0	0
08/28/2014 16:00	0.0	0	0	0	0	0
08/28/2014 17:00	0.0	0	0	0	0	0
08/28/2014 18:00	0.0	0	0	0	0	0
08/28/2014 19:00	0.0	0	0	0	0	0
08/28/2014 20:00	0.0	0	0	0	0	0
08/28/2014 21:00	0.0	0	0	0	0	0
08/28/2014 22:00	0.0	0	0	0	0	0
08/28/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/29/2014 00:00	0.0	0	0	0	0	0
08/29/2014 01:00	0.0	0	0	0	0	0
08/29/2014 02:00	0.0	0	0	0	0	0
08/29/2014 03:00	0.0	0	0	0	0	0
08/29/2014 04:00	0.0	0	0	0	0	0
08/29/2014 05:00	0.0	0	0	0	0	0
08/29/2014 06:00	0.0	0	0	0	0	0
08/29/2014 07:00	0.0	0	0	0	0	0
08/29/2014 08:00	0.0	0	0	0	0	0
08/29/2014 09:00	0.0	0	0	0	0	0
08/29/2014 10:00	0.0	0	0	0	0	0
08/29/2014 11:00	0.0	0	0	0	0	0
08/29/2014 12:00	0.0	0	0	0	0	0
08/29/2014 13:00	0.0	0	0	0	0	0
08/29/2014 14:00	0.0	0	0	0	0	0
08/29/2014 15:00	0.0	0	0	0	0	0
08/29/2014 16:00	0.0	0	0	0	0	0
08/29/2014 17:00	0.0	0	0	0	0	0
08/29/2014 18:00	0.0	0	0	0	0	0
08/29/2014 19:00	0.0	0	0	0	0	0
08/29/2014 20:00	0.0	0	0	0	0	0
08/29/2014 21:00	0.0	0	0	0	0	0
08/29/2014 22:00	0.0	0	0	0	0	0
08/29/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/30/2014 00:00	0.0	0	0	0	0	0
08/30/2014 01:00	0.0	0	0	0	0	0
08/30/2014 02:00	0.0	0	0	0	0	0
08/30/2014 03:00	0.0	0	0	0	0	0
08/30/2014 04:00	0.0	0	0	0	0	0
08/30/2014 05:00	0.0	0	0	0	0	0
08/30/2014 06:00	0.0	0	0	0	0	0
08/30/2014 07:00	0.0	0	0	0	0	0
08/30/2014 08:00	0.0	0	0	0	0	0
08/30/2014 09:00	0.0	0	0	0	0	0
08/30/2014 10:00	0.0	0	0	0	0	0
08/30/2014 11:00	0.0	0	0	0	0	0
08/30/2014 12:00	0.0	0	0	0	0	0
08/30/2014 13:00	0.0	0	0	0	0	0
08/30/2014 14:00	0.0	0	0	0	0	0
08/30/2014 15:00	0.0	0	0	0	0	0
08/30/2014 16:00	0.0	0	0	0	0	0
08/30/2014 17:00	0.0	0	0	0	0	0
08/30/2014 18:00	0.0	0	0	0	0	0
08/30/2014 19:00	0.0	0	0	0	0	0
08/30/2014 20:00	0.0	0	0	0	0	0
08/30/2014 21:00	0.0	0	0	0	0	0
08/30/2014 22:00	0.0	0	0	0	0	0
08/30/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/31/2014 00:00	0.0	0	0	0	0	0
08/31/2014 01:00	0.0	0	0	0	0	0
08/31/2014 02:00	0.0	0	0	0	0	0
08/31/2014 03:00	0.0	0	0	0	0	0
08/31/2014 04:00	0.0	0	0	0	0	0
08/31/2014 05:00	0.0	0	0	0	0	0
08/31/2014 06:00	0.0	0	0	0	0	0
08/31/2014 07:00	0.0	0	0	0	0	0
08/31/2014 08:00	0.0	0	0	0	0	0
08/31/2014 09:00	0.0	0	0	0	0	0
08/31/2014 10:00	0.0	0	0	0	0	0
08/31/2014 11:00	0.0	0	0	0	0	0
08/31/2014 12:00	0.0	0	0	0	0	0
08/31/2014 13:00	0.0	0	0	0	0	0
08/31/2014 14:00	0.0	0	0	0	0	0
08/31/2014 15:00	0.0	0	0	0	0	0
08/31/2014 16:00	0.0	0	0	0	0	0
08/31/2014 17:00	0.0	0	0	0	0	0
08/31/2014 18:00	0.0	0	0	0	0	0
08/31/2014 19:00	0.0	0	0	0	0	0
08/31/2014 20:00	0.0	0	0	0	0	0
08/31/2014 21:00	0.0	0	0	0	0	0
08/31/2014 22:00	0.0	0	0	0	0	0
08/31/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/01/2014 00:00	0.0	0	0	0	0	0
09/01/2014 01:00	0.0	0	0	0	0	0
09/01/2014 02:00	0.0	0	0	0	0	0
09/01/2014 03:00	0.0	0	0	0	0	0
09/01/2014 04:00	0.0	0	0	0	0	0
09/01/2014 05:00	0.0	0	0	0	0	0
09/01/2014 06:00	0.0	0	0	0	0	0
09/01/2014 07:00	0.0	0	0	0	0	0
09/01/2014 08:00	0.0	0	0	0	0	0
09/01/2014 09:00	0.0	0	0	0	0	0
09/01/2014 10:00	0.0	0	0	0	0	0
09/01/2014 11:00	0.0	0	0	0	0	0
09/01/2014 12:00	0.0	0	0	0	0	0
09/01/2014 13:00	0.0	0	0	0	0	0
09/01/2014 14:00	0.0	0	0	0	0	0
09/01/2014 15:00	0.0	0	0	0	0	0
09/01/2014 16:00	0.0	0	0	0	0	0
09/01/2014 17:00	0.0	0	0	0	0	0
09/01/2014 18:00	0.0	0	0	0	0	0
09/01/2014 19:00	0.0	0	0	0	0	0
09/01/2014 20:00	0.0	0	0	0	0	0
09/01/2014 21:00	0.0	0	0	0	0	0
09/01/2014 22:00	0.0	0	0	0	0	0
09/01/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/02/2014 00:00	0.0	0	0	0	0	0
09/02/2014 01:00	0.0	0	0	0	0	0
09/02/2014 02:00	0.0	0	0	0	0	0
09/02/2014 03:00	0.0	0	0	0	0	0
09/02/2014 04:00	0.0	0	0	0	0	0
09/02/2014 05:00	0.0	0	0	0	0	0
09/02/2014 06:00	0.0	0	0	0	0	0
09/02/2014 07:00	0.0	0	0	0	0	0
09/02/2014 08:00	0.0	0	0	0	0	0
09/02/2014 09:00	0.0	0	0	0	0	0
09/02/2014 10:00	0.0	0	0	0	0	0
09/02/2014 11:00	0.0	0	0	0	0	0
09/02/2014 12:00	0.0	0	0	0	0	0
09/02/2014 13:00	0.0	0	0	0	0	0
09/02/2014 14:00	0.0	0	0	0	0	0
09/02/2014 15:00	0.0	0	0	0	0	0
09/02/2014 16:00	0.0	0	0	0	0	0
09/02/2014 17:00	0.0	0	0	0	0	0
09/02/2014 18:00	0.0	0	0	0	0	0
09/02/2014 19:00	0.0	0	0	0	0	0
09/02/2014 20:00	0.0	0	0	0	0	0
09/02/2014 21:00	0.0	0	0	0	0	0
09/02/2014 22:00	0.0	0	0	0	0	0
09/02/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/03/2014 00:00	0.0	0	0	0	0	0
09/03/2014 01:00	0.0	0	0	0	0	0
09/03/2014 02:00	0.0	0	0	0	0	0
09/03/2014 03:00	0.0	0	0	0	0	0
09/03/2014 04:00	0.0	0	0	0	0	0
09/03/2014 05:00	0.0	0	0	0	0	0
09/03/2014 06:00	0.0	0	0	0	0	0
09/03/2014 07:00	0.0	0	0	0	0	0
09/03/2014 08:00	0.0	0	0	0	0	0
09/03/2014 09:00	0.0	0	0	0	0	0
09/03/2014 10:00	0.0	0	0	0	0	0
09/03/2014 11:00	0.0	0	0	0	0	0
09/03/2014 12:00	0.0	0	0	0	0	0
09/03/2014 13:00	0.0	0	0	0	0	0
09/03/2014 14:00	0.0	0	0	0	0	0
09/03/2014 15:00	0.0	0	0	0	0	0
09/03/2014 16:00	0.0	0	0	0	0	0
09/03/2014 17:00	0.0	0	0	0	0	0
09/03/2014 18:00	0.0	0	0	0	0	0
09/03/2014 19:00	0.0	0	0	0	0	0
09/03/2014 20:00	0.0	0	0	0	0	0
09/03/2014 21:00	0.0	0	0	0	0	0
09/03/2014 22:00	0.0	0	0	0	0	0
09/03/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/04/2014 00:00	0.0	0	0	0	0	0
09/04/2014 01:00	0.0	0	0	0	0	0
09/04/2014 02:00	0.0	0	0	0	0	0
09/04/2014 03:00	0.0	0	0	0	0	0
09/04/2014 04:00	0.0	0	0	0	0	0
09/04/2014 05:00	0.0	0	0	0	0	0
09/04/2014 06:00	0.0	0	0	0	0	0
09/04/2014 07:00	0.0	0	0	0	0	0
09/04/2014 08:00	0.0	0	0	0	0	0
09/04/2014 09:00	0.0	0	0	0	0	0
09/04/2014 10:00	0.0	0	0	0	0	0
09/04/2014 11:00	0.0	0	0	0	0	0
09/04/2014 12:00	0.0	0	0	0	0	0
09/04/2014 13:00	0.0	0	0	0	0	0
09/04/2014 14:00	0.0	0	0	0	0	0
09/04/2014 15:00	0.0	0	0	0	0	0
09/04/2014 16:00	0.0	0	0	0	0	0
09/04/2014 17:00	0.0	0	0	0	0	0
09/04/2014 18:00	0.0	0	0	0	0	0
09/04/2014 19:00	0.0	0	0	0	0	0
09/04/2014 20:00	0.0	0	0	0	0	0
09/04/2014 21:00	0.0	0	0	0	0	0
09/04/2014 22:00	0.0	0	0	0	0	0
09/04/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/05/2014 00:00	21.7	1	0	0	0	0
09/05/2014 01:00	147.8	1	0	0	0	0
09/05/2014 02:00	42.5	1	0	0	0	0
09/05/2014 03:00	30.5	1	0	0	0	0
09/05/2014 04:00	32.8	1	0	0	0	0
09/05/2014 05:00	0.0	0	0	0	0	1
09/05/2014 06:00	0.0	0	0	0	0	1
09/05/2014 07:00	0.0	0	0	0	0	1
09/05/2014 08:00	0.0	0	0	0	0	1
09/05/2014 09:00	0.0	0	0	0	0	1
09/05/2014 10:00	0.0	0	0	0	0	1
09/05/2014 11:00	0.0	0	0	0	0	1
09/05/2014 12:00	0.0	0	0	0	0	1
09/05/2014 13:00	0.0	0	0	0	0	1
09/05/2014 14:00	0.0	0	0	0	0	1
09/05/2014 15:00	0.0	0	0	0	0	1
09/05/2014 16:00	0.0	0	0	0	0	1
09/05/2014 17:00	0.0	0	0	0	0	1
09/05/2014 18:00	0.0	0	0	0	0	1
09/05/2014 19:00	0.0	0	0	0	0	1
09/05/2014 20:00	0.0	0	0	0	0	1
09/05/2014 21:00	0.0	0	0	0	0	1
09/05/2014 22:00	0.0	0	0	0	0	1
09/05/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	275.3 #	5 #	0 #	0 #	0 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	147.8	1	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/06/2014 00:00	0.0	0	0	0	0	1
09/06/2014 01:00	0.0	0	0	0	0	1
09/06/2014 02:00	0.0	0	0	0	0	1
09/06/2014 03:00	0.0	0	0	0	0	1
09/06/2014 04:00	0.0	0	0	0	0	1
09/06/2014 05:00	0.0	0	0	0	0	1
09/06/2014 06:00	0.0	0	0	0	0	1
09/06/2014 07:00	0.0	0	0	0	0	1
09/06/2014 08:00	0.0	0	0	0	0	1
09/06/2014 09:00	0.0	0	0	0	0	1
09/06/2014 10:00	0.0	0	0	0	0	1
09/06/2014 11:00	0.0	0	0	0	0	1
09/06/2014 12:00	0.0	0	0	0	0	1
09/06/2014 13:00	0.0	0	0	0	0	1
09/06/2014 14:00	0.0	0	0	0	0	1
09/06/2014 15:00	0.0	0	0	0	0	1
09/06/2014 16:00	0.0	0	0	0	0	1
09/06/2014 17:00	0.0	0	0	0	0	1
09/06/2014 18:00	0.0	0	0	0	0	1
09/06/2014 19:00	0.0	0	0	0	0	1
09/06/2014 20:00	0.0	0	0	0	0	1
09/06/2014 21:00	0.0	0	0	0	0	1
09/06/2014 22:00	0.0	0	0	0	0	1
09/06/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/07/2014 00:00	0.0	0	0	0	0	1
09/07/2014 01:00	0.0	0	0	0	0	1
09/07/2014 02:00	0.0	0	0	0	0	1
09/07/2014 03:00	0.0	0	0	0	0	1
09/07/2014 04:00	0.0	0	0	0	0	1
09/07/2014 05:00	0.0	0	0	0	0	1
09/07/2014 06:00	0.0	0	0	0	0	1
09/07/2014 07:00	0.0	0	0	0	0	1
09/07/2014 08:00	0.0	0	0	0	0	1
09/07/2014 09:00	0.0	0	0	0	0	1
09/07/2014 10:00	0.0	0	0	0	0	1
09/07/2014 11:00	0.0	0	0	0	0	1
09/07/2014 12:00	0.0	0	0	0	0	1
09/07/2014 13:00	0.0	0	0	0	0	1
09/07/2014 14:00	0.0	0	0	0	0	1
09/07/2014 15:00	0.0	0	0	0	0	1
09/07/2014 16:00	0.0	0	0	0	0	1
09/07/2014 17:00	0.0	0	0	0	0	1
09/07/2014 18:00	0.0	0	0	0	0	1
09/07/2014 19:00	0.0	0	0	0	0	1
09/07/2014 20:00	0.0	0	0	0	0	1
09/07/2014 21:00	0.0	0	0	0	0	1
09/07/2014 22:00	0.0	0	0	0	0	1
09/07/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/08/2014 00:00	0.0	0	0	0	0	1
09/08/2014 01:00	0.0	0	0	0	0	1
09/08/2014 02:00	0.0	0	0	0	0	1
09/08/2014 03:00	0.0	0	0	0	0	1
09/08/2014 04:00	0.0	0	0	0	0	1
09/08/2014 05:00	0.0	0	0	0	0	1
09/08/2014 06:00	0.0	0	0	0	0	1
09/08/2014 07:00	0.0	0	0	0	0	1
09/08/2014 08:00	0.0	0	0	0	0	1
09/08/2014 09:00	0.0	0	0	0	0	1
09/08/2014 10:00	0.0	0	0	0	0	1
09/08/2014 11:00	0.0	0	0	0	0	1
09/08/2014 12:00	0.0	0	0	0	0	1
09/08/2014 13:00	0.0	0	0	0	0	1
09/08/2014 14:00	0.0	0	0	0	0	1
09/08/2014 15:00	0.0	0	0	0	0	1
09/08/2014 16:00	0.0	0	0	0	0	1
09/08/2014 17:00	0.0	0	0	0	0	1
09/08/2014 18:00	0.0	0	0	0	0	1
09/08/2014 19:00	0.0	0	0	0	0	1
09/08/2014 20:00	0.0	0	0	0	0	1
09/08/2014 21:00	0.0	0	0	0	0	1
09/08/2014 22:00	0.0	0	0	0	0	1
09/08/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/09/2014 00:00	0.0	0	0	0	0	1
09/09/2014 01:00	0.0	0	0	0	0	1
09/09/2014 02:00	0.0	0	0	0	0	1
09/09/2014 03:00	0.0	0	0	0	0	1
09/09/2014 04:00	0.0	0	0	0	0	1
09/09/2014 05:00	0.0	0	0	0	0	1
09/09/2014 06:00	0.0	0	0	0	0	1
09/09/2014 07:00	0.0	0	0	0	0	1
09/09/2014 08:00	0.0	0	0	0	0	1
09/09/2014 09:00	0.0	0	0	0	0	1
09/09/2014 10:00	0.0	0	0	0	0	1
09/09/2014 11:00	0.0	0	0	0	0	1
09/09/2014 12:00	0.0	0	0	0	0	1
09/09/2014 13:00	0.0	0	0	0	0	1
09/09/2014 14:00	0.0	0	0	0	0	1
09/09/2014 15:00	0.0	0	0	0	0	1
09/09/2014 16:00	0.0	0	0	0	0	1
09/09/2014 17:00	0.0	0	0	0	0	1
09/09/2014 18:00	0.0	0	0	0	0	1
09/09/2014 19:00	0.0	0	0	0	0	1
09/09/2014 20:00	0.0	0	0	0	0	1
09/09/2014 21:00	0.0	0	0	0	0	1
09/09/2014 22:00	0.0	0	0	0	0	1
09/09/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/10/2014 00:00	0.0	0	0	0	0	1
09/10/2014 01:00	0.0	0	0	0	0	1
09/10/2014 02:00	0.0	0	0	0	0	1
09/10/2014 03:00	0.0	0	0	0	0	1
09/10/2014 04:00	0.0	0	0	0	0	1
09/10/2014 05:00	0.0	0	0	0	0	1
09/10/2014 06:00	0.0	0	0	0	0	1
09/10/2014 07:00	0.0	0	0	0	0	1
09/10/2014 08:00	0.0	0	0	0	0	1
09/10/2014 09:00	0.0	0	0	0	0	1
09/10/2014 10:00	0.0	0	0	0	0	1
09/10/2014 11:00	0.0	0	0	0	0	1
09/10/2014 12:00	0.0	0	0	0	0	1
09/10/2014 13:00	0.0	0	0	0	0	1
09/10/2014 14:00	0.0	0	0	0	0	1
09/10/2014 15:00	0.0	0	0	0	0	1
09/10/2014 16:00	0.0	0	0	0	0	1
09/10/2014 17:00	0.0	0	0	0	0	1
09/10/2014 18:00	0.0	0	0	0	0	1
09/10/2014 19:00	0.0	0	0	0	0	1
09/10/2014 20:00	0.0	0	0	0	0	1
09/10/2014 21:00	0.0	0	0	0	0	1
09/10/2014 22:00	0.0	0	0	0	0	1
09/10/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/11/2014 00:00	0.0	0	0	0	0	1
09/11/2014 01:00	0.0	0	0	0	0	1
09/11/2014 02:00	0.0	0	0	0	0	1
09/11/2014 03:00	0.0	0	0	0	0	1
09/11/2014 04:00	0.0	0	0	0	0	1
09/11/2014 05:00	0.0	0	0	0	0	1
09/11/2014 06:00	0.0	0	0	0	0	1
09/11/2014 07:00	0.0	0	0	0	0	1
09/11/2014 08:00	0.0	0	0	0	0	1
09/11/2014 09:00	0.0	0	0	0	0	1
09/11/2014 10:00	0.0	0	0	0	0	1
09/11/2014 11:00	0.0	0	0	0	0	1
09/11/2014 12:00	0.0	0	0	0	0	1
09/11/2014 13:00	0.0	0	0	0	0	1
09/11/2014 14:00	0.0	0	0	0	0	1
09/11/2014 15:00	0.0	0	0	0	0	1
09/11/2014 16:00	0.0	0	0	0	0	1
09/11/2014 17:00	0.0	0	0	0	0	1
09/11/2014 18:00	0.0	0	0	0	0	1
09/11/2014 19:00	0.0	0	0	0	0	1
09/11/2014 20:00	0.0	0	0	0	0	1
09/11/2014 21:00	0.0	0	0	0	0	1
09/11/2014 22:00	0.0	0	0	0	0	1
09/11/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/12/2014 00:00	0.0	0	0	0	0	1
09/12/2014 01:00	0.0	0	0	0	0	1
09/12/2014 02:00	0.0	0	0	0	0	1
09/12/2014 03:00	0.0	0	0	0	0	1
09/12/2014 04:00	0.0	0	0	0	0	1
09/12/2014 05:00	0.0	0	0	0	0	1
09/12/2014 06:00	0.0	0	0	0	0	1
09/12/2014 07:00	0.0	0	0	0	0	1
09/12/2014 08:00	0.0	0	0	0	0	1
09/12/2014 09:00	0.0	0	0	0	0	1
09/12/2014 10:00	0.0	0	0	0	0	1
09/12/2014 11:00	0.0	0	0	0	0	1
09/12/2014 12:00	0.0	0	0	0	0	1
09/12/2014 13:00	0.0	0	0	0	0	1
09/12/2014 14:00	0.0	0	0	0	0	1
09/12/2014 15:00	0.0	0	0	0	0	1
09/12/2014 16:00	0.0	0	0	0	0	1
09/12/2014 17:00	0.0	0	0	0	0	1
09/12/2014 18:00	0.0	0	0	0	0	1
09/12/2014 19:00	0.0	0	0	0	0	1
09/12/2014 20:00	0.0	0	0	0	0	1
09/12/2014 21:00	0.0	0	0	0	0	1
09/12/2014 22:00	0.0	0	0	0	0	1
09/12/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/13/2014 00:00	0.0	0	0	0	0	1
09/13/2014 01:00	0.0	0	0	0	0	1
09/13/2014 02:00	0.0	0	0	0	0	1
09/13/2014 03:00	0.0	0	0	0	0	1
09/13/2014 04:00	0.0	0	0	0	0	1
09/13/2014 05:00	0.0	0	0	0	0	1
09/13/2014 06:00	0.0	0	0	0	0	1
09/13/2014 07:00	0.0	0	0	0	0	1
09/13/2014 08:00	0.0	0	0	0	0	1
09/13/2014 09:00	0.0	0	0	0	0	1
09/13/2014 10:00	0.0	0	0	0	0	1
09/13/2014 11:00	0.0	0	0	0	0	1
09/13/2014 12:00	0.0	0	0	0	0	1
09/13/2014 13:00	0.0	0	0	0	0	1
09/13/2014 14:00	0.0	0	0	0	0	1
09/13/2014 15:00	0.0	0	0	0	0	1
09/13/2014 16:00	0.0	0	0	0	0	1
09/13/2014 17:00	0.0	0	0	0	0	1
09/13/2014 18:00	0.0	0	0	0	0	1
09/13/2014 19:00	0.0	0	0	0	0	1
09/13/2014 20:00	0.0	0	0	0	0	1
09/13/2014 21:00	0.0	0	0	0	0	1
09/13/2014 22:00	0.0	0	0	0	0	1
09/13/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/14/2014 00:00	0.0	0	0	0	0	1
09/14/2014 01:00	0.0	0	0	0	0	1
09/14/2014 02:00	0.0	0	0	0	0	1
09/14/2014 03:00	0.0	0	0	0	0	1
09/14/2014 04:00	0.0	0	0	0	0	1
09/14/2014 05:00	0.0	0	0	0	0	1
09/14/2014 06:00	0.0	0	0	0	0	1
09/14/2014 07:00	0.0	0	0	0	0	1
09/14/2014 08:00	0.0	0	0	0	0	1
09/14/2014 09:00	0.0	0	0	0	0	1
09/14/2014 10:00	0.0	0	0	0	0	1
09/14/2014 11:00	0.0	0	0	0	0	1
09/14/2014 12:00	0.0	0	0	0	0	1
09/14/2014 13:00	0.0	0	0	0	0	1
09/14/2014 14:00	0.0	0	0	0	0	1
09/14/2014 15:00	0.0	0	0	0	0	1
09/14/2014 16:00	0.0	0	0	0	0	1
09/14/2014 17:00	0.0	0	0	0	0	1
09/14/2014 18:00	0.0	0	0	0	0	1
09/14/2014 19:00	0.0	0	0	0	0	1
09/14/2014 20:00	0.0	0	0	0	0	1
09/14/2014 21:00	0.0	0	0	0	0	1
09/14/2014 22:00	0.0	0	0	0	0	1
09/14/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/15/2014 00:00	0.0	0	0	0	0	1
09/15/2014 01:00	0.0	0	0	0	0	1
09/15/2014 02:00	0.0	0	0	0	0	1
09/15/2014 03:00	0.0	0	0	0	0	1
09/15/2014 04:00	0.0	0	0	0	0	1
09/15/2014 05:00	0.0	0	0	0	0	1
09/15/2014 06:00	0.0	0	0	0	0	1
09/15/2014 07:00	0.0	0	0	0	0	1
09/15/2014 08:00	0.0	0	0	0	0	1
09/15/2014 09:00	0.0	0	0	0	0	1
09/15/2014 10:00	0.0	0	0	0	0	1
09/15/2014 11:00	0.0	0	0	0	0	1
09/15/2014 12:00	0.0	0	0	0	0	1
09/15/2014 13:00	0.0	0	0	0	0	1
09/15/2014 14:00	0.0	0	0	0	0	1
09/15/2014 15:00	0.0	0	0	0	0	1
09/15/2014 16:00	0.0	0	0	0	0	1
09/15/2014 17:00	0.0	0	0	0	0	1
09/15/2014 18:00	0.0	0	0	0	0	1
09/15/2014 19:00	0.0	0	0	0	0	1
09/15/2014 20:00	0.0	0	0	0	0	1
09/15/2014 21:00	0.0	0	0	0	0	1
09/15/2014 22:00	0.0	0	0	0	0	1
09/15/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/16/2014 00:00	0.0	0	0	0	0	1
09/16/2014 01:00	0.0	0	0	0	0	1
09/16/2014 02:00	0.0	0	0	0	0	1
09/16/2014 03:00	0.0	0	0	0	0	1
09/16/2014 04:00	0.0	0	0	0	0	1
09/16/2014 05:00	0.0	0	0	0	0	1
09/16/2014 06:00	0.0	0	0	0	0	1
09/16/2014 07:00	0.0	0	0	0	0	1
09/16/2014 08:00	0.0	0	0	0	0	1
09/16/2014 09:00	0.0	0	0	0	0	1
09/16/2014 10:00	0.0	0	0	0	0	1
09/16/2014 11:00	0.0	0	0	0	0	1
09/16/2014 12:00	0.0	0	0	0	0	1
09/16/2014 13:00	0.0	0	0	0	0	1
09/16/2014 14:00	0.0	0	0	0	0	1
09/16/2014 15:00	0.0	0	0	0	0	1
09/16/2014 16:00	0.0	0	0	0	0	1
09/16/2014 17:00	0.0	0	0	0	0	1
09/16/2014 18:00	0.0	0	0	0	0	1
09/16/2014 19:00	0.0	0	0	0	0	1
09/16/2014 20:00	0.0	0	0	0	0	1
09/16/2014 21:00	0.0	0	0	0	0	1
09/16/2014 22:00	0.0	0	0	0	0	1
09/16/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/17/2014 00:00	0.0	0	0	0	0	1
09/17/2014 01:00	0.0	0	0	0	0	1
09/17/2014 02:00	0.0	0	0	0	0	1
09/17/2014 03:00	0.0	0	0	0	0	1
09/17/2014 04:00	0.0	0	0	0	0	1
09/17/2014 05:00	0.0	0	0	0	0	1
09/17/2014 06:00	0.0	0	0	0	0	1
09/17/2014 07:00	0.0	0	0	0	0	1
09/17/2014 08:00	0.0	0	0	0	0	1
09/17/2014 09:00	0.0	0	0	0	0	1
09/17/2014 10:00	0.0	0	0	0	0	1
09/17/2014 11:00	0.0	0	0	0	0	1
09/17/2014 12:00	0.0	0	0	0	0	1
09/17/2014 13:00	0.0	0	0	0	0	1
09/17/2014 14:00	0.0	0	0	0	0	1
09/17/2014 15:00	0.0	0	0	0	0	1
09/17/2014 16:00	0.0	0	0	0	0	1
09/17/2014 17:00	0.0	0	0	0	0	1
09/17/2014 18:00	0.0	0	0	0	0	1
09/17/2014 19:00	0.0	0	0	0	0	1
09/17/2014 20:00	0.0	0	0	0	0	1
09/17/2014 21:00	0.0	0	0	0	0	1
09/17/2014 22:00	0.0	0	0	0	0	1
09/17/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/18/2014 00:00	0.0	0	0	0	0	1
09/18/2014 01:00	0.0	0	0	0	0	1
09/18/2014 02:00	0.0	0	0	0	0	1
09/18/2014 03:00	0.0	0	0	0	0	1
09/18/2014 04:00	0.0	0	0	0	0	1
09/18/2014 05:00	0.0	0	0	0	0	1
09/18/2014 06:00	0.0	0	0	0	0	1
09/18/2014 07:00	0.0	0	0	0	0	1
09/18/2014 08:00	0.0	0	0	0	0	1
09/18/2014 09:00	0.0	0	0	0	0	1
09/18/2014 10:00	0.0	0	0	0	0	1
09/18/2014 11:00	0.0	0	0	0	0	1
09/18/2014 12:00	0.0	0	0	0	0	1
09/18/2014 13:00	0.0	0	0	0	0	1
09/18/2014 14:00	0.0	0	0	0	0	1
09/18/2014 15:00	0.0	0	0	0	0	1
09/18/2014 16:00	0.0	0	0	0	0	1
09/18/2014 17:00	0.0	0	0	0	0	1
09/18/2014 18:00	0.0	0	0	0	0	1
09/18/2014 19:00	0.0	0	0	0	0	1
09/18/2014 20:00	0.0	0	0	0	0	1
09/18/2014 21:00	0.0	0	0	0	0	1
09/18/2014 22:00	0.0	0	0	0	0	1
09/18/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/19/2014 00:00	0.0	0	0	0	0	1
09/19/2014 01:00	0.0	0	0	0	0	1
09/19/2014 02:00	0.0	0	0	0	0	1
09/19/2014 03:00	0.0	0	0	0	0	1
09/19/2014 04:00	0.0	0	0	0	0	1
09/19/2014 05:00	0.0	0	0	0	0	1
09/19/2014 06:00	0.0	0	0	0	0	1
09/19/2014 07:00	0.0	0	0	0	0	1
09/19/2014 08:00	0.0	0	0	0	0	1
09/19/2014 09:00	0.0	0	0	0	0	1
09/19/2014 10:00	0.0	0	0	0	0	1
09/19/2014 11:00	0.0	0	0	0	0	1
09/19/2014 12:00	0.0	0	0	0	0	1
09/19/2014 13:00	0.0	0	0	0	0	1
09/19/2014 14:00	0.0	0	0	0	0	1
09/19/2014 15:00	0.0	0	0	0	0	1
09/19/2014 16:00	0.0	0	0	0	0	1
09/19/2014 17:00	0.0	0	0	0	0	1
09/19/2014 18:00	0.0	0	0	0	0	1
09/19/2014 19:00	0.0	0	0	0	0	1
09/19/2014 20:00	0.0	0	0	0	0	1
09/19/2014 21:00	0.0	0	0	0	0	1
09/19/2014 22:00	0.0	0	0	0	0	1
09/19/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/20/2014 00:00	0.0	0	0	0	0	1
09/20/2014 01:00	0.0	0	0	0	0	1
09/20/2014 02:00	0.0	0	0	0	0	1
09/20/2014 03:00	0.0	0	0	0	0	1
09/20/2014 04:00	0.0	0	0	0	0	1
09/20/2014 05:00	0.0	0	0	0	0	1
09/20/2014 06:00	0.0	0	0	0	0	1
09/20/2014 07:00	0.0	0	0	0	0	1
09/20/2014 08:00	0.0	0	0	0	0	1
09/20/2014 09:00	0.0	0	0	0	0	1
09/20/2014 10:00	0.0	0	0	0	0	1
09/20/2014 11:00	0.0	0	0	0	0	1
09/20/2014 12:00	0.0	0	0	0	0	1
09/20/2014 13:00	0.0	0	0	0	0	1
09/20/2014 14:00	0.0	0	0	0	0	1
09/20/2014 15:00	0.0	0	0	0	0	1
09/20/2014 16:00	0.0	0	0	0	0	1
09/20/2014 17:00	0.0	0	0	0	0	1
09/20/2014 18:00	0.0	0	0	0	0	1
09/20/2014 19:00	0.0	0	0	0	0	1
09/20/2014 20:00	0.0	0	0	0	0	1
09/20/2014 21:00	0.0	0	0	0	0	1
09/20/2014 22:00	0.0	0	0	0	0	1
09/20/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/21/2014 00:00	0.0	0	0	0	0	1
09/21/2014 01:00	0.0	0	0	0	0	1
09/21/2014 02:00	0.0	0	0	0	0	1
09/21/2014 03:00	0.0	0	0	0	0	1
09/21/2014 04:00	0.0	0	0	0	0	1
09/21/2014 05:00	0.0	0	0	0	0	1
09/21/2014 06:00	0.0	0	0	0	0	1
09/21/2014 07:00	0.0	0	0	0	0	1
09/21/2014 08:00	0.0	0	0	0	0	1
09/21/2014 09:00	0.0	0	0	0	0	1
09/21/2014 10:00	0.0	0	0	0	0	1
09/21/2014 11:00	0.0	0	0	0	0	1
09/21/2014 12:00	0.0	0	0	0	0	1
09/21/2014 13:00	0.0	0	0	0	0	1
09/21/2014 14:00	0.0	0	0	0	0	1
09/21/2014 15:00	0.0	0	0	0	0	1
09/21/2014 16:00	0.0	0	0	0	0	1
09/21/2014 17:00	0.0	0	0	0	0	1
09/21/2014 18:00	0.0	0	0	0	0	1
09/21/2014 19:00	0.0	0	0	0	0	1
09/21/2014 20:00	0.0	0	0	0	0	1
09/21/2014 21:00	0.0	0	0	0	0	1
09/21/2014 22:00	0.0	0	0	0	0	1
09/21/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/22/2014 00:00	0.0	0	0	0	0	1
09/22/2014 01:00	0.0	0	0	0	0	1
09/22/2014 02:00	0.0	0	0	0	0	1
09/22/2014 03:00	0.0	0	0	0	0	1
09/22/2014 04:00	0.0	0	0	0	0	1
09/22/2014 05:00	0.0	0	0	0	0	1
09/22/2014 06:00	0.0	0	0	0	0	1
09/22/2014 07:00	0.0	0	0	0	0	1
09/22/2014 08:00	0.0	0	0	0	0	1
09/22/2014 09:00	0.0	0	0	0	0	1
09/22/2014 10:00	0.0	0	0	0	0	1
09/22/2014 11:00	0.0	0	0	0	0	1
09/22/2014 12:00	0.0	0	0	0	0	1
09/22/2014 13:00	0.0	0	0	0	0	1
09/22/2014 14:00	0.0	0	0	0	0	1
09/22/2014 15:00	0.0	0	0	0	0	1
09/22/2014 16:00	0.0	0	0	0	0	1
09/22/2014 17:00	0.0	0	0	0	0	1
09/22/2014 18:00	0.0	0	0	0	0	1
09/22/2014 19:00	0.0	0	0	0	0	1
09/22/2014 20:00	0.0	0	0	0	0	1
09/22/2014 21:00	0.0	0	0	0	0	1
09/22/2014 22:00	0.0	0	0	0	0	1
09/22/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/23/2014 00:00	0.0	0	0	0	0	1
09/23/2014 01:00	0.0	0	0	0	0	1
09/23/2014 02:00	0.0	0	0	0	0	1
09/23/2014 03:00	0.0	0	0	0	0	1
09/23/2014 04:00	0.0	0	0	0	0	1
09/23/2014 05:00	0.0	0	0	0	0	1
09/23/2014 06:00	0.0	0	0	0	0	1
09/23/2014 07:00	0.0	0	0	0	0	1
09/23/2014 08:00	0.0	0	0	0	0	1
09/23/2014 09:00	0.0	0	0	0	0	1
09/23/2014 10:00	0.0	0	0	0	0	1
09/23/2014 11:00	0.0	0	0	0	0	1
09/23/2014 12:00	0.0	0	0	0	0	1
09/23/2014 13:00	0.0	0	0	0	0	1
09/23/2014 14:00	0.0	0	0	0	0	1
09/23/2014 15:00	0.0	0	0	0	0	1
09/23/2014 16:00	0.0	0	0	0	0	1
09/23/2014 17:00	0.0	0	0	0	0	1
09/23/2014 18:00	0.0	0	0	0	0	1
09/23/2014 19:00	0.0	0	0	0	0	1
09/23/2014 20:00	0.0	0	0	0	0	1
09/23/2014 21:00	0.0	0	0	0	0	1
09/23/2014 22:00	0.0	0	0	0	0	1
09/23/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/24/2014 00:00	0.0	0	0	0	0	1
09/24/2014 01:00	0.0	0	0	0	0	1
09/24/2014 02:00	0.0	0	0	0	0	1
09/24/2014 03:00	0.0	0	0	0	0	1
09/24/2014 04:00	0.0	0	0	0	0	1
09/24/2014 05:00	0.0	0	0	0	0	1
09/24/2014 06:00	0.0	0	0	0	0	1
09/24/2014 07:00	0.0	0	0	0	0	1
09/24/2014 08:00	0.0	0	0	0	0	1
09/24/2014 09:00	0.0	0	0	0	0	1
09/24/2014 10:00	0.0	0	0	0	0	1
09/24/2014 11:00	0.0	0	0	0	0	1
09/24/2014 12:00	0.0	0	0	0	0	1
09/24/2014 13:00	0.0	0	0	0	0	1
09/24/2014 14:00	0.0	0	0	0	0	1
09/24/2014 15:00	0.0	0	0	0	0	1
09/24/2014 16:00	0.0	0	0	0	0	1
09/24/2014 17:00	0.0	0	0	0	0	1
09/24/2014 18:00	0.0	0	0	0	0	1
09/24/2014 19:00	0.0	0	0	0	0	1
09/24/2014 20:00	0.0	0	0	0	0	1
09/24/2014 21:00	0.0	0	0	0	0	1
09/24/2014 22:00	0.0	0	0	0	0	1
09/24/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/25/2014 00:00	0.0	0	0	0	0	1
09/25/2014 01:00	0.0	0	0	0	0	1
09/25/2014 02:00	0.0	0	0	0	0	1
09/25/2014 03:00	0.0	0	0	0	0	1
09/25/2014 04:00	0.0	0	0	0	0	1
09/25/2014 05:00	0.0	0	0	0	0	1
09/25/2014 06:00	0.0	0	0	0	0	1
09/25/2014 07:00	0.0	0	0	0	0	1
09/25/2014 08:00	0.0	0	0	0	0	1
09/25/2014 09:00	0.0	0	0	0	0	1
09/25/2014 10:00	0.0	0	0	0	0	1
09/25/2014 11:00	0.0	0	0	0	0	1
09/25/2014 12:00	0.0	0	0	0	0	1
09/25/2014 13:00	0.0	0	0	0	0	1
09/25/2014 14:00	0.0	0	0	0	0	1
09/25/2014 15:00	0.0	0	0	0	0	1
09/25/2014 16:00	0.0	0	0	0	0	1
09/25/2014 17:00	0.0	0	0	0	0	1
09/25/2014 18:00	0.0	0	0	0	0	1
09/25/2014 19:00	0.0	0	0	0	0	1
09/25/2014 20:00	0.0	0	0	0	0	1
09/25/2014 21:00	0.0	0	0	0	0	1
09/25/2014 22:00	0.0	0	0	0	0	1
09/25/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/26/2014 00:00	0.0	0	0	0	0	1
09/26/2014 01:00	0.0	0	0	0	0	1
09/26/2014 02:00	0.0	0	0	0	0	1
09/26/2014 03:00	0.0	0	0	0	0	1
09/26/2014 04:00	0.0	0	0	0	0	1
09/26/2014 05:00	0.0	0	0	0	0	1
09/26/2014 06:00	0.0	0	0	0	0	1
09/26/2014 07:00	0.0	0	0	0	0	1
09/26/2014 08:00	0.0	0	0	0	0	1
09/26/2014 09:00	0.0	0	0	0	0	1
09/26/2014 10:00	0.0	0	0	0	0	1
09/26/2014 11:00	0.0	0	0	0	0	1
09/26/2014 12:00	0.0	0	0	0	0	1
09/26/2014 13:00	0.0	0	0	0	0	1
09/26/2014 14:00	0.0	0	0	0	0	1
09/26/2014 15:00	0.0	0	0	0	0	1
09/26/2014 16:00	0.0	0	0	0	0	1
09/26/2014 17:00	0.0	0	0	0	0	1
09/26/2014 18:00	0.0	0	0	0	0	1
09/26/2014 19:00	0.0	0	0	0	0	1
09/26/2014 20:00	0.0	0	0	0	0	1
09/26/2014 21:00	0.0	0	0	0	0	1
09/26/2014 22:00	0.0	0	0	0	0	1
09/26/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/27/2014 00:00	0.0	0	0	0	0	1
09/27/2014 01:00	0.0	0	0	0	0	1
09/27/2014 02:00	0.0	0	0	0	0	1
09/27/2014 03:00	0.0	0	0	0	0	1
09/27/2014 04:00	0.0	0	0	0	0	1
09/27/2014 05:00	0.0	0	0	0	0	1
09/27/2014 06:00	0.0	0	0	0	0	1
09/27/2014 07:00	0.0	0	0	0	0	1
09/27/2014 08:00	0.0	0	0	0	0	1
09/27/2014 09:00	0.0	0	0	0	0	1
09/27/2014 10:00	0.0	0	0	0	0	1
09/27/2014 11:00	0.0	0	0	0	0	1
09/27/2014 12:00	0.0	0	0	0	0	1
09/27/2014 13:00	0.0	0	0	0	0	1
09/27/2014 14:00	0.0	0	0	0	0	1
09/27/2014 15:00	0.0	0	0	0	0	1
09/27/2014 16:00	0.0	0	0	0	0	1
09/27/2014 17:00	0.0	0	0	0	0	1
09/27/2014 18:00	0.0	0	0	0	0	1
09/27/2014 19:00	0.0	0	0	0	0	1
09/27/2014 20:00	0.0	0	0	0	0	1
09/27/2014 21:00	0.0	0	0	0	0	1
09/27/2014 22:00	0.0	0	0	0	0	1
09/27/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/28/2014 00:00	0.0	0	0	0	0	1
09/28/2014 01:00	0.0	0	0	0	0	1
09/28/2014 02:00	0.0	0	0	0	0	1
09/28/2014 03:00	0.0	0	0	0	0	1
09/28/2014 04:00	0.0	0	0	0	0	1
09/28/2014 05:00	0.0	0	0	0	0	1
09/28/2014 06:00	0.0	0	0	0	0	1
09/28/2014 07:00	0.0	0	0	0	0	1
09/28/2014 08:00	0.0	0	0	0	0	1
09/28/2014 09:00	0.0	0	0	0	0	1
09/28/2014 10:00	0.0	0	0	0	0	1
09/28/2014 11:00	0.0	0	0	0	0	1
09/28/2014 12:00	0.0	0	0	0	0	1
09/28/2014 13:00	0.0	0	0	0	0	1
09/28/2014 14:00	0.0	0	0	0	0	1
09/28/2014 15:00	0.0	0	0	0	0	1
09/28/2014 16:00	0.0	0	0	0	0	1
09/28/2014 17:00	0.0	0	0	0	0	1
09/28/2014 18:00	0.0	0	0	0	0	1
09/28/2014 19:00	0.0	0	0	0	0	1
09/28/2014 20:00	0.0	0	0	0	0	1
09/28/2014 21:00	0.0	0	0	0	0	1
09/28/2014 22:00	0.0	0	0	0	0	1
09/28/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/29/2014 00:00	0.0	0	0	0	0	1
09/29/2014 01:00	0.0	0	0	0	0	1
09/29/2014 02:00	0.0	0	0	0	0	1
09/29/2014 03:00	0.0	0	0	0	0	1
09/29/2014 04:00	0.0	0	0	0	0	1
09/29/2014 05:00	0.0	0	0	0	0	1
09/29/2014 06:00	0.0	0	0	0	0	1
09/29/2014 07:00	0.0	0	0	0	0	1
09/29/2014 08:00	0.0	0	0	0	0	1
09/29/2014 09:00	0.0	0	0	0	0	1
09/29/2014 10:00	0.0	0	0	0	0	1
09/29/2014 11:00	0.0	0	0	0	0	1
09/29/2014 12:00	0.0	0	0	0	0	1
09/29/2014 13:00	0.0	0	0	0	0	1
09/29/2014 14:00	0.0	0	0	0	0	1
09/29/2014 15:00	0.0	0	0	0	0	1
09/29/2014 16:00	0.0	0	0	0	0	1
09/29/2014 17:00	0.0	0	0	0	0	1
09/29/2014 18:00	0.0	0	0	0	0	1
09/29/2014 19:00	0.0	0	0	0	0	1
09/29/2014 20:00	0.0	0	0	0	0	1
09/29/2014 21:00	0.0	0	0	0	0	1
09/29/2014 22:00	0.0	0	0	0	0	1
09/29/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event NOx Lbs

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:19 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 NOx_Event, Lb 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/30/2014 00:00	0.0	0	0	0	0	1
09/30/2014 01:00	0.0	0	0	0	0	1
09/30/2014 02:00	0.0	0	0	0	0	1
09/30/2014 03:00	0.0	0	0	0	0	1
09/30/2014 04:00	0.0	0	0	0	0	1
09/30/2014 05:00	0.0	0	0	0	0	1
09/30/2014 06:00	0.0	0	0	0	0	1
09/30/2014 07:00	0.0	0	0	0	0	1
09/30/2014 08:00	0.0	0	0	0	0	1
09/30/2014 09:00	0.0	0	0	0	0	1
09/30/2014 10:00	0.0	0	0	0	0	1
09/30/2014 11:00	0.0	0	0	0	0	1
09/30/2014 12:00	0.0	0	0	0	0	1
09/30/2014 13:00	0.0	0	0	0	0	1
09/30/2014 14:00	0.0	0	0	0	0	1
09/30/2014 15:00	0.0	0	0	0	0	1
09/30/2014 16:00	0.0	0	0	0	0	1
09/30/2014 17:00	0.0	0	0	0	0	1
09/30/2014 18:00	0.0	0	0	0	0	1
09/30/2014 19:00	0.0	0	0	0	0	1
09/30/2014 20:00	0.0	0	0	0	0	1
09/30/2014 21:00	0.0	0	0	0	0	1
09/30/2014 22:00	0.0	0	0	0	0	1
09/30/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, _Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/01/2014 00:00	0.0	0	0	0	0	1
07/01/2014 01:00	0.0	0	0	0	0	1
07/01/2014 02:00	0.0	0	0	0	0	1
07/01/2014 03:00	0.0	0	0	0	0	1
07/01/2014 04:00	0.0	0	0	0	0	1
07/01/2014 05:00	0.0	0	0	0	0	1
07/01/2014 06:00	0.0	0	0	0	0	1
07/01/2014 07:00	0.0	0	0	0	0	1
07/01/2014 08:00	0.0	0	0	0	0	1
07/01/2014 09:00	0.0	0	0	0	0	1
07/01/2014 10:00	0.0	0	0	0	0	1
07/01/2014 11:00	0.0	0	0	0	0	1
07/01/2014 12:00	0.0	0	0	0	0	1
07/01/2014 13:00	0.0	0	0	0	0	1
07/01/2014 14:00	0.0	0	0	0	0	1
07/01/2014 15:00	0.0	0	0	0	0	1
07/01/2014 16:00	0.0	0	0	0	0	1
07/01/2014 17:00	0.0	0	0	0	0	1
07/01/2014 18:00	0.0	0	0	0	0	1
07/01/2014 19:00	0.0	0	0	0	0	1
07/01/2014 20:00	0.0	0	0	0	0	1
07/01/2014 21:00	0.0	0	0	0	0	1
07/01/2014 22:00	0.0	0	0	0	0	1
07/01/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/02/2014 00:00	0.0	0	0	0	0	1
07/02/2014 01:00	0.0	0	0	0	0	1
07/02/2014 02:00	0.0	0	0	0	0	1
07/02/2014 03:00	0.0	0	0	0	0	1
07/02/2014 04:00	0.0	0	0	0	0	1
07/02/2014 05:00	0.0	0	0	0	0	1
07/02/2014 06:00	0.0	0	0	0	0	1
07/02/2014 07:00	0.0	0	0	0	0	1
07/02/2014 08:00	0.0	0	0	0	0	1
07/02/2014 09:00	0.0	0	0	0	0	1
07/02/2014 10:00	0.0	0	0	0	0	1
07/02/2014 11:00	0.0	0	0	0	0	1
07/02/2014 12:00	0.0	0	0	0	0	1
07/02/2014 13:00	0.0	0	0	0	0	1
07/02/2014 14:00	0.0	0	0	0	0	1
07/02/2014 15:00	0.0	0	0	0	0	1
07/02/2014 16:00	0.0	0	0	0	0	1
07/02/2014 17:00	0.0	0	0	0	0	1
07/02/2014 18:00	0.0	0	0	0	0	1
07/02/2014 19:00	0.0	0	0	0	0	1
07/02/2014 20:00	0.0	0	0	0	0	1
07/02/2014 21:00	0.0	0	0	0	0	1
07/02/2014 22:00	327.8	0	0	0	1	0
07/02/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	327.8 #	0 #	0 #	0 #	1 #	22 #
Minimum:	0.0	0	0	0	0	0
Maximum:	327.8	0	0	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/03/2014 00:00	0.0	0	0	0	0	0
07/03/2014 01:00	0.0	0	0	0	0	0
07/03/2014 02:00	0.0	0	0	0	0	0
07/03/2014 03:00	0.0	0	0	0	0	0
07/03/2014 04:00	0.0	0	0	0	0	0
07/03/2014 05:00	0.0	0	0	0	0	0
07/03/2014 06:00	0.0	0	0	0	0	0
07/03/2014 07:00	3,583.8	0	1	0	0	0
07/03/2014 08:00	3,591.3	0	1	0	0	0
07/03/2014 09:00	0.0	0	0	0	0	1
07/03/2014 10:00	0.0	0	0	0	0	1
07/03/2014 11:00	0.0	0	0	0	0	1
07/03/2014 12:00	0.0	0	0	0	0	1
07/03/2014 13:00	0.0	0	0	0	0	1
07/03/2014 14:00	0.0	0	0	0	0	1
07/03/2014 15:00	0.0	0	0	0	0	1
07/03/2014 16:00	0.0	0	0	0	0	1
07/03/2014 17:00	0.0	0	0	0	0	1
07/03/2014 18:00	0.0	0	0	0	0	1
07/03/2014 19:00	0.0	0	0	0	0	1
07/03/2014 20:00	0.0	0	0	0	0	1
07/03/2014 21:00	0.0	0	0	0	0	1
07/03/2014 22:00	0.0	0	0	0	0	1
07/03/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,175.1 #	0 #	2 #	0 #	0 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3,591.3	0	1	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/04/2014 00:00	0.0	0	0	0	0	1
07/04/2014 01:00	0.0	0	0	0	0	1
07/04/2014 02:00	0.0	0	0	0	0	1
07/04/2014 03:00	0.0	0	0	0	0	1
07/04/2014 04:00	0.0	0	0	0	0	1
07/04/2014 05:00	0.0	0	0	0	0	1
07/04/2014 06:00	0.0	0	0	0	0	1
07/04/2014 07:00	0.0	0	0	0	0	1
07/04/2014 08:00	0.0	0	0	0	0	1
07/04/2014 09:00	0.0	0	0	0	0	1
07/04/2014 10:00	0.0	0	0	0	0	1
07/04/2014 11:00	0.0	0	0	0	0	1
07/04/2014 12:00	0.0	0	0	0	0	1
07/04/2014 13:00	0.0	0	0	0	0	1
07/04/2014 14:00	0.0	0	0	0	0	1
07/04/2014 15:00	0.0	0	0	0	0	1
07/04/2014 16:00	0.0	0	0	0	0	1
07/04/2014 17:00	0.0	0	0	0	0	1
07/04/2014 18:00	0.0	0	0	0	0	1
07/04/2014 19:00	0.0	0	0	0	0	1
07/04/2014 20:00	377.7	0	0	0	1	0
07/04/2014 21:00	0.0	0	0	0	0	0
07/04/2014 22:00	0.0	0	0	0	0	0
07/04/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	377.7 #	0 #	0 #	0 #	1 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	377.7	0	0	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/05/2014 00:00	0.0	0	0	0	0	0
07/05/2014 01:00	0.0	0	0	0	0	0
07/05/2014 02:00	0.0	0	0	0	0	0
07/05/2014 03:00	0.0	0	0	0	0	0
07/05/2014 04:00	0.0	0	0	0	0	0
07/05/2014 05:00	0.0	0	0	0	0	0
07/05/2014 06:00	0.0	0	0	0	0	0
07/05/2014 07:00	0.0	0	0	0	0	0
07/05/2014 08:00	0.0	0	0	0	0	0
07/05/2014 09:00	0.0	0	0	0	0	0
07/05/2014 10:00	2,343.4	0	1	0	0	0
07/05/2014 11:00	5,102.6	0	1	0	0	0
07/05/2014 12:00	0.0	0	0	0	0	1
07/05/2014 13:00	0.0	0	0	0	0	1
07/05/2014 14:00	0.0	0	0	0	0	1
07/05/2014 15:00	0.0	0	0	0	0	1
07/05/2014 16:00	0.0	0	0	0	0	1
07/05/2014 17:00	0.0	0	0	0	0	1
07/05/2014 18:00	0.0	0	0	0	0	1
07/05/2014 19:00	0.0	0	0	0	0	1
07/05/2014 20:00	0.0	0	0	0	0	1
07/05/2014 21:00	0.0	0	0	0	0	1
07/05/2014 22:00	0.0	0	0	0	0	1
07/05/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,446.0 #	0 #	2 #	0 #	0 #	12 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,102.6	0	1	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/06/2014 00:00	0.0	0	0	0	0	1
07/06/2014 01:00	0.0	0	0	0	0	1
07/06/2014 02:00	490.1	0	0	0	1	0
07/06/2014 03:00	0.0	0	0	0	0	0
07/06/2014 04:00	0.0	0	0	0	0	0
07/06/2014 05:00	0.0	0	0	0	0	0
07/06/2014 06:00	0.0	0	0	0	0	0
07/06/2014 07:00	0.0	0	0	0	0	0
07/06/2014 08:00	0.0	0	0	0	0	0
07/06/2014 09:00	863.3	0	0	1	0	0
07/06/2014 10:00	6,443.6	0	0	1	0	0
07/06/2014 11:00	0.0	0	0	0	0	1
07/06/2014 12:00	0.0	0	0	0	0	1
07/06/2014 13:00	0.0	0	0	0	0	1
07/06/2014 14:00	0.0	0	0	0	0	1
07/06/2014 15:00	0.0	0	0	0	0	1
07/06/2014 16:00	0.0	0	0	0	0	1
07/06/2014 17:00	0.0	0	0	0	0	1
07/06/2014 18:00	0.0	0	0	0	0	1
07/06/2014 19:00	0.0	0	0	0	0	1
07/06/2014 20:00	0.0	0	0	0	0	1
07/06/2014 21:00	0.0	0	0	0	0	1
07/06/2014 22:00	0.0	0	0	0	0	1
07/06/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,797.0 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,443.6	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/07/2014 00:00	0.0	0	0	0	0	1
07/07/2014 01:00	0.0	0	0	0	0	1
07/07/2014 02:00	0.0	0	0	0	0	1
07/07/2014 03:00	0.0	0	0	0	0	1
07/07/2014 04:00	0.0	0	0	0	0	1
07/07/2014 05:00	0.0	0	0	0	0	1
07/07/2014 06:00	0.0	0	0	0	0	1
07/07/2014 07:00	0.0	0	0	0	0	1
07/07/2014 08:00	0.0	0	0	0	0	1
07/07/2014 09:00	0.0	0	0	0	0	1
07/07/2014 10:00	0.0	0	0	0	0	1
07/07/2014 11:00	0.0	0	0	0	0	1
07/07/2014 12:00	0.0	0	0	0	0	1
07/07/2014 13:00	0.0	0	0	0	0	1
07/07/2014 14:00	0.0	0	0	0	0	1
07/07/2014 15:00	0.0	0	0	0	0	1
07/07/2014 16:00	0.0	0	0	0	0	1
07/07/2014 17:00	0.0	0	0	0	0	1
07/07/2014 18:00	0.0	0	0	0	0	1
07/07/2014 19:00	0.0	0	0	0	0	1
07/07/2014 20:00	0.0	0	0	0	0	1
07/07/2014 21:00	0.0	0	0	0	0	1
07/07/2014 22:00	0.0	0	0	0	0	1
07/07/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/08/2014 00:00	0.0	0	0	0	0	1
07/08/2014 01:00	0.0	0	0	0	0	1
07/08/2014 02:00	0.0	0	0	0	0	1
07/08/2014 03:00	0.0	0	0	0	0	1
07/08/2014 04:00	0.0	0	0	0	0	1
07/08/2014 05:00	0.0	0	0	0	0	1
07/08/2014 06:00	0.0	0	0	0	0	1
07/08/2014 07:00	0.0	0	0	0	0	1
07/08/2014 08:00	0.0	0	0	0	0	1
07/08/2014 09:00	0.0	0	0	0	0	1
07/08/2014 10:00	0.0	0	0	0	0	1
07/08/2014 11:00	0.0	0	0	0	0	1
07/08/2014 12:00	0.0	0	0	0	0	1
07/08/2014 13:00	0.0	0	0	0	0	1
07/08/2014 14:00	0.0	0	0	0	0	1
07/08/2014 15:00	0.0	0	0	0	0	1
07/08/2014 16:00	0.0	0	0	0	0	1
07/08/2014 17:00	0.0	0	0	0	0	1
07/08/2014 18:00	0.0	0	0	0	0	1
07/08/2014 19:00	0.0	0	0	0	0	1
07/08/2014 20:00	0.0	0	0	0	0	1
07/08/2014 21:00	0.0	0	0	0	0	1
07/08/2014 22:00	0.0	0	0	0	0	1
07/08/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/09/2014 00:00	0.0	0	0	0	0	1
07/09/2014 01:00	0.0	0	0	0	0	1
07/09/2014 02:00	0.0	0	0	0	0	1
07/09/2014 03:00	0.0	0	0	0	0	1
07/09/2014 04:00	0.0	0	0	0	0	1
07/09/2014 05:00	0.0	0	0	0	0	1
07/09/2014 06:00	0.0	0	0	0	0	1
07/09/2014 07:00	0.0	0	0	0	0	1
07/09/2014 08:00	0.0	0	0	0	0	1
07/09/2014 09:00	0.0	0	0	0	0	1
07/09/2014 10:00	0.0	0	0	0	0	1
07/09/2014 11:00	0.0	0	0	0	0	1
07/09/2014 12:00	0.0	0	0	0	0	1
07/09/2014 13:00	0.0	0	0	0	0	1
07/09/2014 14:00	0.0	0	0	0	0	1
07/09/2014 15:00	0.0	0	0	0	0	1
07/09/2014 16:00	0.0	0	0	0	0	1
07/09/2014 17:00	0.0	0	0	0	0	1
07/09/2014 18:00	0.0	0	0	0	0	1
07/09/2014 19:00	0.0	0	0	0	0	1
07/09/2014 20:00	0.0	0	0	0	0	1
07/09/2014 21:00	0.0	0	0	0	0	1
07/09/2014 22:00	0.0	0	0	0	0	1
07/09/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/10/2014 00:00	0.0	0	0	0	0	1
07/10/2014 01:00	0.0	0	0	0	0	1
07/10/2014 02:00	0.0	0	0	0	0	1
07/10/2014 03:00	0.0	0	0	0	0	1
07/10/2014 04:00	0.0	0	0	0	0	1
07/10/2014 05:00	0.0	0	0	0	0	1
07/10/2014 06:00	0.0	0	0	0	0	1
07/10/2014 07:00	0.0	0	0	0	0	1
07/10/2014 08:00	0.0	0	0	0	0	1
07/10/2014 09:00	0.0	0	0	0	0	1
07/10/2014 10:00	0.0	0	0	0	0	1
07/10/2014 11:00	0.0	0	0	0	0	1
07/10/2014 12:00	0.0	0	0	0	0	1
07/10/2014 13:00	0.0	0	0	0	0	1
07/10/2014 14:00	0.0	0	0	0	0	1
07/10/2014 15:00	0.0	0	0	0	0	1
07/10/2014 16:00	0.0	0	0	0	0	1
07/10/2014 17:00	0.0	0	0	0	0	1
07/10/2014 18:00	0.0	0	0	0	0	1
07/10/2014 19:00	0.0	0	0	0	0	1
07/10/2014 20:00	0.0	0	0	0	0	1
07/10/2014 21:00	0.0	0	0	0	0	1
07/10/2014 22:00	0.0	0	0	0	0	1
07/10/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/11/2014 00:00	244.0	0	0	0	1	0
07/11/2014 01:00	0.0	0	0	0	0	0
07/11/2014 02:00	0.0	0	0	0	0	0
07/11/2014 03:00	0.0	0	0	0	0	0
07/11/2014 04:00	0.0	0	0	0	0	0
07/11/2014 05:00	0.0	0	0	0	0	0
07/11/2014 06:00	0.0	0	0	0	0	0
07/11/2014 07:00	0.0	0	0	0	0	0
07/11/2014 08:00	0.0	0	0	0	0	0
07/11/2014 09:00	4,406.2	0	1	0	0	0
07/11/2014 10:00	6,946.3	0	1	0	0	0
07/11/2014 11:00	0.0	0	0	0	0	1
07/11/2014 12:00	0.0	0	0	0	0	1
07/11/2014 13:00	0.0	0	0	0	0	1
07/11/2014 14:00	0.0	0	0	0	0	1
07/11/2014 15:00	0.0	0	0	0	0	1
07/11/2014 16:00	0.0	0	0	0	0	1
07/11/2014 17:00	0.0	0	0	0	0	1
07/11/2014 18:00	0.0	0	0	0	0	1
07/11/2014 19:00	0.0	0	0	0	0	1
07/11/2014 20:00	0.0	0	0	0	0	1
07/11/2014 21:00	0.0	0	0	0	0	1
07/11/2014 22:00	0.0	0	0	0	0	1
07/11/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	11,596.5 #	0 #	2 #	0 #	1 #	13 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,946.3	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/12/2014 00:00	309.6	0	0	0	1	0
07/12/2014 01:00	0.0	0	0	0	0	0
07/12/2014 02:00	0.0	0	0	0	0	0
07/12/2014 03:00	0.0	0	0	0	0	0
07/12/2014 04:00	0.0	0	0	0	0	0
07/12/2014 05:00	0.0	0	0	0	0	0
07/12/2014 06:00	2,231.6	0	0	1	0	0
07/12/2014 07:00	5,785.5	0	0	1	0	0
07/12/2014 08:00	0.0	0	0	0	0	1
07/12/2014 09:00	0.0	0	0	0	0	1
07/12/2014 10:00	0.0	0	0	0	0	1
07/12/2014 11:00	0.0	0	0	0	0	1
07/12/2014 12:00	0.0	0	0	0	0	1
07/12/2014 13:00	0.0	0	0	0	0	1
07/12/2014 14:00	0.0	0	0	0	0	1
07/12/2014 15:00	0.0	0	0	0	0	1
07/12/2014 16:00	0.0	0	0	0	0	1
07/12/2014 17:00	0.0	0	0	0	0	1
07/12/2014 18:00	0.0	0	0	0	0	1
07/12/2014 19:00	0.0	0	0	0	0	1
07/12/2014 20:00	0.0	0	0	0	0	1
07/12/2014 21:00	0.0	0	0	0	0	1
07/12/2014 22:00	0.0	0	0	0	0	1
07/12/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,326.7 #	0 #	0 #	2 #	1 #	16 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,785.5	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/13/2014 00:00	0.0	0	0	0	0	1
07/13/2014 01:00	287.0	0	0	0	1	0
07/13/2014 02:00	0.0	0	0	0	0	0
07/13/2014 03:00	0.0	0	0	0	0	0
07/13/2014 04:00	0.0	0	0	0	0	0
07/13/2014 05:00	0.0	0	0	0	0	0
07/13/2014 06:00	0.0	0	0	0	0	0
07/13/2014 07:00	0.0	0	0	0	0	0
07/13/2014 08:00	0.0	0	0	0	0	0
07/13/2014 09:00	0.0	0	0	0	0	0
07/13/2014 10:00	1,729.4	0	1	0	0	0
07/13/2014 11:00	5,425.0	0	1	0	0	0
07/13/2014 12:00	0.0	0	0	0	0	1
07/13/2014 13:00	0.0	0	0	0	0	1
07/13/2014 14:00	0.0	0	0	0	0	1
07/13/2014 15:00	0.0	0	0	0	0	1
07/13/2014 16:00	0.0	0	0	0	0	1
07/13/2014 17:00	0.0	0	0	0	0	1
07/13/2014 18:00	0.0	0	0	0	0	1
07/13/2014 19:00	0.0	0	0	0	0	1
07/13/2014 20:00	0.0	0	0	0	0	1
07/13/2014 21:00	0.0	0	0	0	0	1
07/13/2014 22:00	0.0	0	0	0	0	1
07/13/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	7,441.4 #	0 #	2 #	0 #	1 #	13 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,425.0	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/14/2014 00:00	0.0	0	0	0	0	1
07/14/2014 01:00	0.0	0	0	0	0	1
07/14/2014 02:00	0.0	0	0	0	0	1
07/14/2014 03:00	0.0	0	0	0	0	1
07/14/2014 04:00	0.0	0	0	0	0	1
07/14/2014 05:00	0.0	0	0	0	0	1
07/14/2014 06:00	0.0	0	0	0	0	1
07/14/2014 07:00	0.0	0	0	0	0	1
07/14/2014 08:00	0.0	0	0	0	0	1
07/14/2014 09:00	0.0	0	0	0	0	1
07/14/2014 10:00	0.0	0	0	0	0	1
07/14/2014 11:00	0.0	0	0	0	0	1
07/14/2014 12:00	0.0	0	0	0	0	1
07/14/2014 13:00	0.0	0	0	0	0	1
07/14/2014 14:00	0.0	0	0	0	0	1
07/14/2014 15:00	0.0	0	0	0	0	1
07/14/2014 16:00	0.0	0	0	0	0	1
07/14/2014 17:00	0.0	0	0	0	0	1
07/14/2014 18:00	0.0	0	0	0	0	1
07/14/2014 19:00	0.0	0	0	0	0	1
07/14/2014 20:00	0.0	0	0	0	0	1
07/14/2014 21:00	0.0	0	0	0	0	1
07/14/2014 22:00	0.0	0	0	0	0	1
07/14/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/15/2014 00:00	0.0	0	0	0	0	1
07/15/2014 01:00	0.0	0	0	0	0	1
07/15/2014 02:00	0.0	0	0	0	0	1
07/15/2014 03:00	0.0	0	0	0	0	1
07/15/2014 04:00	0.0	0	0	0	0	1
07/15/2014 05:00	0.0	0	0	0	0	1
07/15/2014 06:00	0.0	0	0	0	0	1
07/15/2014 07:00	0.0	0	0	0	0	1
07/15/2014 08:00	0.0	0	0	0	0	1
07/15/2014 09:00	0.0	0	0	0	0	1
07/15/2014 10:00	0.0	0	0	0	0	1
07/15/2014 11:00	0.0	0	0	0	0	1
07/15/2014 12:00	0.0	0	0	0	0	1
07/15/2014 13:00	0.0	0	0	0	0	1
07/15/2014 14:00	0.0	0	0	0	0	1
07/15/2014 15:00	0.0	0	0	0	0	1
07/15/2014 16:00	0.0	0	0	0	0	1
07/15/2014 17:00	0.0	0	0	0	0	1
07/15/2014 18:00	0.0	0	0	0	0	1
07/15/2014 19:00	0.0	0	0	0	0	1
07/15/2014 20:00	0.0	0	0	0	0	1
07/15/2014 21:00	0.0	0	0	0	0	1
07/15/2014 22:00	0.0	0	0	0	0	1
07/15/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/16/2014 00:00	0.0	0	0	0	0	1
07/16/2014 01:00	0.0	0	0	0	0	1
07/16/2014 02:00	0.0	0	0	0	0	1
07/16/2014 03:00	0.0	0	0	0	0	1
07/16/2014 04:00	0.0	0	0	0	0	1
07/16/2014 05:00	0.0	0	0	0	0	1
07/16/2014 06:00	0.0	0	0	0	0	1
07/16/2014 07:00	0.0	0	0	0	0	1
07/16/2014 08:00	0.0	0	0	0	0	1
07/16/2014 09:00	0.0	0	0	0	0	1
07/16/2014 10:00	0.0	0	0	0	0	1
07/16/2014 11:00	0.0	0	0	0	0	1
07/16/2014 12:00	0.0	0	0	0	0	1
07/16/2014 13:00	0.0	0	0	0	0	1
07/16/2014 14:00	0.0	0	0	0	0	1
07/16/2014 15:00	0.0	0	0	0	0	1
07/16/2014 16:00	0.0	0	0	0	0	1
07/16/2014 17:00	0.0	0	0	0	0	1
07/16/2014 18:00	0.0	0	0	0	0	1
07/16/2014 19:00	0.0	0	0	0	0	1
07/16/2014 20:00	0.0	0	0	0	0	1
07/16/2014 21:00	0.0	0	0	0	0	1
07/16/2014 22:00	0.0	0	0	0	0	1
07/16/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/17/2014 00:00	326.8	0	0	0	1	0
07/17/2014 01:00	0.0	0	0	0	0	0
07/17/2014 02:00	0.0	0	0	0	0	0
07/17/2014 03:00	0.0	0	0	0	0	0
07/17/2014 04:00	3,235.9	0	0	1	0	0
07/17/2014 05:00	4,551.1	0	0	1	0	0
07/17/2014 06:00	0.0	0	0	0	0	1
07/17/2014 07:00	0.0	0	0	0	0	1
07/17/2014 08:00	0.0	0	0	0	0	1
07/17/2014 09:00	0.0	0	0	0	0	1
07/17/2014 10:00	0.0	0	0	0	0	1
07/17/2014 11:00	0.0	0	0	0	0	1
07/17/2014 12:00	0.0	0	0	0	0	1
07/17/2014 13:00	0.0	0	0	0	0	1
07/17/2014 14:00	0.0	0	0	0	0	1
07/17/2014 15:00	0.0	0	0	0	0	1
07/17/2014 16:00	0.0	0	0	0	0	1
07/17/2014 17:00	0.0	0	0	0	0	1
07/17/2014 18:00	0.0	0	0	0	0	1
07/17/2014 19:00	0.0	0	0	0	0	1
07/17/2014 20:00	0.0	0	0	0	0	1
07/17/2014 21:00	0.0	0	0	0	0	1
07/17/2014 22:00	0.0	0	0	0	0	1
07/17/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,113.8 #	0 #	0 #	2 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,551.1	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/18/2014 00:00	334.2	0	0	0	1	0
07/18/2014 01:00	0.0	0	0	0	0	0
07/18/2014 02:00	0.0	0	0	0	0	0
07/18/2014 03:00	4,253.2	0	0	1	0	0
07/18/2014 04:00	1,527.1	0	0	1	0	0
07/18/2014 05:00	0.0	0	0	0	0	1
07/18/2014 06:00	0.0	0	0	0	0	1
07/18/2014 07:00	0.0	0	0	0	0	1
07/18/2014 08:00	0.0	0	0	0	0	1
07/18/2014 09:00	0.0	0	0	0	0	1
07/18/2014 10:00	0.0	0	0	0	0	1
07/18/2014 11:00	0.0	0	0	0	0	1
07/18/2014 12:00	0.0	0	0	0	0	1
07/18/2014 13:00	0.0	0	0	0	0	1
07/18/2014 14:00	0.0	0	0	0	0	1
07/18/2014 15:00	0.0	0	0	0	0	1
07/18/2014 16:00	0.0	0	0	0	0	1
07/18/2014 17:00	0.0	0	0	0	0	1
07/18/2014 18:00	0.0	0	0	0	0	1
07/18/2014 19:00	0.0	0	0	0	0	1
07/18/2014 20:00	0.0	0	0	0	0	1
07/18/2014 21:00	0.0	0	0	0	0	1
07/18/2014 22:00	0.0	0	0	0	0	1
07/18/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,114.5 #	0 #	0 #	2 #	1 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,253.2	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/19/2014 00:00	315.7	0	0	0	1	0
07/19/2014 01:00	0.0	0	0	0	0	0
07/19/2014 02:00	0.0	0	0	0	0	0
07/19/2014 03:00	0.0	0	0	0	0	0
07/19/2014 04:00	0.0	0	0	0	0	0
07/19/2014 05:00	0.0	0	0	0	0	0
07/19/2014 06:00	0.0	0	0	0	0	0
07/19/2014 07:00	0.0	0	0	0	0	0
07/19/2014 08:00	0.0	0	0	0	0	0
07/19/2014 09:00	1,437.5	0	1	0	0	0
07/19/2014 10:00	4,881.1	0	1	0	0	0
07/19/2014 11:00	0.0	0	0	0	0	1
07/19/2014 12:00	0.0	0	0	0	0	1
07/19/2014 13:00	0.0	0	0	0	0	1
07/19/2014 14:00	0.0	0	0	0	0	1
07/19/2014 15:00	0.0	0	0	0	0	1
07/19/2014 16:00	0.0	0	0	0	0	1
07/19/2014 17:00	0.0	0	0	0	0	1
07/19/2014 18:00	0.0	0	0	0	0	1
07/19/2014 19:00	0.0	0	0	0	0	1
07/19/2014 20:00	0.0	0	0	0	0	1
07/19/2014 21:00	0.0	0	0	0	0	1
07/19/2014 22:00	0.0	0	0	0	0	1
07/19/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,634.3 #	0 #	2 #	0 #	1 #	13 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,881.1	0	1	0	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/20/2014 00:00	310.5	0	0	0	1	0
07/20/2014 01:00	0.0	0	0	0	0	0
07/20/2014 02:00	0.0	0	0	0	0	0
07/20/2014 03:00	0.0	0	0	0	0	0
07/20/2014 04:00	0.0	0	0	0	0	0
07/20/2014 05:00	0.0	0	0	0	0	0
07/20/2014 06:00	0.0	0	0	0	0	0
07/20/2014 07:00	0.0	0	0	0	0	0
07/20/2014 08:00	0.0	0	0	0	0	0
07/20/2014 09:00	0.0	0	0	0	0	0
07/20/2014 10:00	0.0	0	0	0	0	0
07/20/2014 11:00	0.0	0	0	0	0	0
07/20/2014 12:00	0.0	0	0	0	0	0
07/20/2014 13:00	0.0	0	0	0	0	0
07/20/2014 14:00	0.0	0	0	0	0	0
07/20/2014 15:00	0.0	0	0	0	0	0
07/20/2014 16:00	0.0	0	0	0	0	0
07/20/2014 17:00	0.0	0	0	0	0	0
07/20/2014 18:00	0.0	0	0	0	0	0
07/20/2014 19:00	0.0	0	0	0	0	0
07/20/2014 20:00	0.0	0	0	0	0	0
07/20/2014 21:00	0.0	0	0	0	0	0
07/20/2014 22:00	0.0	0	0	0	0	0
07/20/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	310.5 #	0 #	0 #	0 #	1 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	310.5	0	0	0	1	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/21/2014 00:00	0.0	0	0	0	0	0
07/21/2014 01:00	3,243.0	0	1	0	0	0
07/21/2014 02:00	5,632.8	0	1	0	0	0
07/21/2014 03:00	4,979.9	0	1	0	0	0
07/21/2014 04:00	0.0	0	0	0	0	1
07/21/2014 05:00	0.0	0	0	0	0	1
07/21/2014 06:00	0.0	0	0	0	0	1
07/21/2014 07:00	0.0	0	0	0	0	1
07/21/2014 08:00	0.0	0	0	0	0	1
07/21/2014 09:00	0.0	0	0	0	0	1
07/21/2014 10:00	0.0	0	0	0	0	1
07/21/2014 11:00	0.0	0	0	0	0	1
07/21/2014 12:00	0.0	0	0	0	0	1
07/21/2014 13:00	0.0	0	0	0	0	1
07/21/2014 14:00	0.0	0	0	0	0	1
07/21/2014 15:00	0.0	0	0	0	0	1
07/21/2014 16:00	0.0	0	0	0	0	1
07/21/2014 17:00	0.0	0	0	0	0	1
07/21/2014 18:00	0.0	0	0	0	0	1
07/21/2014 19:00	0.0	0	0	0	0	1
07/21/2014 20:00	0.0	0	0	0	0	1
07/21/2014 21:00	0.0	0	0	0	0	1
07/21/2014 22:00	0.0	0	0	0	0	1
07/21/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	13,855.7 #	0 #	3 #	0 #	0 #	20 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,632.8	0	1	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/22/2014 00:00	0.0	0	0	0	0	1
07/22/2014 01:00	0.0	0	0	0	0	1
07/22/2014 02:00	0.0	0	0	0	0	1
07/22/2014 03:00	0.0	0	0	0	0	1
07/22/2014 04:00	0.0	0	0	0	0	1
07/22/2014 05:00	0.0	0	0	0	0	1
07/22/2014 06:00	0.0	0	0	0	0	1
07/22/2014 07:00	0.0	0	0	0	0	1
07/22/2014 08:00	0.0	0	0	0	0	1
07/22/2014 09:00	0.0	0	0	0	0	1
07/22/2014 10:00	0.0	0	0	0	0	1
07/22/2014 11:00	0.0	0	0	0	0	1
07/22/2014 12:00	0.0	0	0	0	0	1
07/22/2014 13:00	0.0	0	0	0	0	1
07/22/2014 14:00	0.0	0	0	0	0	1
07/22/2014 15:00	0.0	0	0	0	0	1
07/22/2014 16:00	0.0	0	0	0	0	1
07/22/2014 17:00	0.0	0	0	0	0	1
07/22/2014 18:00	0.0	0	0	0	0	1
07/22/2014 19:00	0.0	0	0	0	0	1
07/22/2014 20:00	0.0	0	0	0	0	1
07/22/2014 21:00	0.0	0	0	0	0	1
07/22/2014 22:00	0.0	0	0	0	0	1
07/22/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/23/2014 00:00	0.0	0	0	0	0	1
07/23/2014 01:00	0.0	0	0	0	0	1
07/23/2014 02:00	0.0	0	0	0	0	1
07/23/2014 03:00	0.0	0	0	0	0	1
07/23/2014 04:00	0.0	0	0	0	0	1
07/23/2014 05:00	0.0	0	0	0	0	1
07/23/2014 06:00	0.0	0	0	0	0	1
07/23/2014 07:00	0.0	0	0	0	0	1
07/23/2014 08:00	0.0	0	0	0	0	1
07/23/2014 09:00	0.0	0	0	0	0	1
07/23/2014 10:00	0.0	0	0	0	0	1
07/23/2014 11:00	0.0	0	0	0	0	1
07/23/2014 12:00	0.0	0	0	0	0	1
07/23/2014 13:00	0.0	0	0	0	0	1
07/23/2014 14:00	0.0	0	0	0	0	1
07/23/2014 15:00	0.0	0	0	0	0	1
07/23/2014 16:00	0.0	0	0	0	0	1
07/23/2014 17:00	0.0	0	0	0	0	1
07/23/2014 18:00	0.0	0	0	0	0	1
07/23/2014 19:00	0.0	0	0	0	0	1
07/23/2014 20:00	0.0	0	0	0	0	1
07/23/2014 21:00	0.0	0	0	0	0	1
07/23/2014 22:00	0.0	0	0	0	0	1
07/23/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/24/2014 00:00	0.0	0	0	0	0	1
07/24/2014 01:00	0.0	0	0	0	0	1
07/24/2014 02:00	0.0	0	0	0	0	1
07/24/2014 03:00	0.0	0	0	0	0	1
07/24/2014 04:00	0.0	0	0	0	0	1
07/24/2014 05:00	0.0	0	0	0	0	1
07/24/2014 06:00	0.0	0	0	0	0	1
07/24/2014 07:00	0.0	0	0	0	0	1
07/24/2014 08:00	0.0	0	0	0	0	1
07/24/2014 09:00	0.0	0	0	0	0	1
07/24/2014 10:00	0.0	0	0	0	0	1
07/24/2014 11:00	0.0	0	0	0	0	1
07/24/2014 12:00	0.0	0	0	0	0	1
07/24/2014 13:00	0.0	0	0	0	0	1
07/24/2014 14:00	0.0	0	0	0	0	1
07/24/2014 15:00	0.0	0	0	0	0	1
07/24/2014 16:00	0.0	0	0	0	0	1
07/24/2014 17:00	0.0	0	0	0	0	1
07/24/2014 18:00	0.0	0	0	0	0	1
07/24/2014 19:00	0.0	0	0	0	0	1
07/24/2014 20:00	0.0	0	0	0	0	1
07/24/2014 21:00	0.0	0	0	0	0	1
07/24/2014 22:00	0.0	0	0	0	0	1
07/24/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/25/2014 00:00	0.0	0	0	0	0	1
07/25/2014 01:00	0.0	0	0	0	0	1
07/25/2014 02:00	0.0	0	0	0	0	1
07/25/2014 03:00	0.0	0	0	0	0	1
07/25/2014 04:00	0.0	0	0	0	0	1
07/25/2014 05:00	0.0	0	0	0	0	1
07/25/2014 06:00	0.0	0	0	0	0	1
07/25/2014 07:00	0.0	0	0	0	0	1
07/25/2014 08:00	0.0	0	0	0	0	1
07/25/2014 09:00	0.0	0	0	0	0	1
07/25/2014 10:00	0.0	0	0	0	0	1
07/25/2014 11:00	0.0	0	0	0	0	1
07/25/2014 12:00	0.0	0	0	0	0	1
07/25/2014 13:00	0.0	0	0	0	0	1
07/25/2014 14:00	0.0	0	0	0	0	1
07/25/2014 15:00	0.0	0	0	0	0	1
07/25/2014 16:00	0.0	0	0	0	0	1
07/25/2014 17:00	0.0	0	0	0	0	1
07/25/2014 18:00	0.0	0	0	0	0	1
07/25/2014 19:00	0.0	0	0	0	0	1
07/25/2014 20:00	0.0	0	0	0	0	1
07/25/2014 21:00	0.0	0	0	0	0	1
07/25/2014 22:00	0.0	0	0	0	0	1
07/25/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/26/2014 00:00	0.0	0	0	0	0	1
07/26/2014 01:00	0.0	0	0	0	0	1
07/26/2014 02:00	0.0	0	0	0	0	1
07/26/2014 03:00	0.0	0	0	0	0	1
07/26/2014 04:00	0.0	0	0	0	0	1
07/26/2014 05:00	0.0	0	0	0	0	1
07/26/2014 06:00	0.0	0	0	0	0	1
07/26/2014 07:00	0.0	0	0	0	0	1
07/26/2014 08:00	0.0	0	0	0	0	1
07/26/2014 09:00	0.0	0	0	0	0	1
07/26/2014 10:00	0.0	0	0	0	0	1
07/26/2014 11:00	0.0	0	0	0	0	1
07/26/2014 12:00	0.0	0	0	0	0	1
07/26/2014 13:00	0.0	0	0	0	0	1
07/26/2014 14:00	0.0	0	0	0	0	1
07/26/2014 15:00	0.0	0	0	0	0	1
07/26/2014 16:00	0.0	0	0	0	0	1
07/26/2014 17:00	0.0	0	0	0	0	1
07/26/2014 18:00	0.0	0	0	0	0	1
07/26/2014 19:00	0.0	0	0	0	0	1
07/26/2014 20:00	0.0	0	0	0	0	1
07/26/2014 21:00	0.0	0	0	0	0	1
07/26/2014 22:00	0.0	0	0	0	0	1
07/26/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/27/2014 00:00	0.0	0	0	0	0	1
07/27/2014 01:00	0.0	0	0	0	0	1
07/27/2014 02:00	0.0	0	0	0	0	1
07/27/2014 03:00	0.0	0	0	0	0	1
07/27/2014 04:00	0.0	0	0	0	0	1
07/27/2014 05:00	0.0	0	0	0	0	1
07/27/2014 06:00	0.0	0	0	0	0	1
07/27/2014 07:00	0.0	0	0	0	0	1
07/27/2014 08:00	0.0	0	0	0	0	1
07/27/2014 09:00	0.0	0	0	0	0	1
07/27/2014 10:00	0.0	0	0	0	0	1
07/27/2014 11:00	0.0	0	0	0	0	1
07/27/2014 12:00	0.0	0	0	0	0	1
07/27/2014 13:00	0.0	0	0	0	0	1
07/27/2014 14:00	0.0	0	0	0	0	1
07/27/2014 15:00	0.0	0	0	0	0	1
07/27/2014 16:00	0.0	0	0	0	0	1
07/27/2014 17:00	0.0	0	0	0	0	1
07/27/2014 18:00	0.0	0	0	0	0	1
07/27/2014 19:00	0.0	0	0	0	0	1
07/27/2014 20:00	0.0	0	0	0	0	1
07/27/2014 21:00	0.0	0	0	0	0	1
07/27/2014 22:00	0.0	0	0	0	0	1
07/27/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/28/2014 00:00	0.0	0	0	0	0	1
07/28/2014 01:00	0.0	0	0	0	0	1
07/28/2014 02:00	0.0	0	0	0	0	1
07/28/2014 03:00	0.0	0	0	0	0	1
07/28/2014 04:00	0.0	0	0	0	0	1
07/28/2014 05:00	0.0	0	0	0	0	1
07/28/2014 06:00	0.0	0	0	0	0	1
07/28/2014 07:00	0.0	0	0	0	0	1
07/28/2014 08:00	0.0	0	0	0	0	1
07/28/2014 09:00	0.0	0	0	0	0	1
07/28/2014 10:00	0.0	0	0	0	0	1
07/28/2014 11:00	0.0	0	0	0	0	1
07/28/2014 12:00	0.0	0	0	0	0	1
07/28/2014 13:00	0.0	0	0	0	0	1
07/28/2014 14:00	0.0	0	0	0	0	1
07/28/2014 15:00	0.0	0	0	0	0	1
07/28/2014 16:00	0.0	0	0	0	0	1
07/28/2014 17:00	0.0	0	0	0	0	1
07/28/2014 18:00	0.0	0	0	0	0	1
07/28/2014 19:00	0.0	0	0	0	0	1
07/28/2014 20:00	0.0	0	0	0	0	1
07/28/2014 21:00	0.0	0	0	0	0	1
07/28/2014 22:00	0.0	0	0	0	0	1
07/28/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/29/2014 00:00	0.0	0	0	0	0	1
07/29/2014 01:00	0.0	0	0	0	0	1
07/29/2014 02:00	0.0	0	0	0	0	1
07/29/2014 03:00	0.0	0	0	0	0	1
07/29/2014 04:00	0.0	0	0	0	0	1
07/29/2014 05:00	0.0	0	0	0	0	1
07/29/2014 06:00	0.0	0	0	0	0	1
07/29/2014 07:00	0.0	0	0	0	0	1
07/29/2014 08:00	0.0	0	0	0	0	1
07/29/2014 09:00	0.0	0	0	0	0	1
07/29/2014 10:00	0.0	0	0	0	0	1
07/29/2014 11:00	0.0	0	0	0	0	1
07/29/2014 12:00	0.0	0	0	0	0	1
07/29/2014 13:00	0.0	0	0	0	0	1
07/29/2014 14:00	0.0	0	0	0	0	1
07/29/2014 15:00	0.0	0	0	0	0	1
07/29/2014 16:00	0.0	0	0	0	0	1
07/29/2014 17:00	0.0	0	0	0	0	1
07/29/2014 18:00	0.0	0	0	0	0	1
07/29/2014 19:00	0.0	0	0	0	0	1
07/29/2014 20:00	0.0	0	0	0	0	1
07/29/2014 21:00	0.0	0	0	0	0	1
07/29/2014 22:00	0.0	0	0	0	0	1
07/29/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/30/2014 00:00	0.0	0	0	0	0	1
07/30/2014 01:00	0.0	0	0	0	0	1
07/30/2014 02:00	0.0	0	0	0	0	1
07/30/2014 03:00	0.0	0	0	0	0	1
07/30/2014 04:00	0.0	0	0	0	0	1
07/30/2014 05:00	0.0	0	0	0	0	1
07/30/2014 06:00	0.0	0	0	0	0	1
07/30/2014 07:00	0.0	0	0	0	0	1
07/30/2014 08:00	0.0	0	0	0	0	1
07/30/2014 09:00	0.0	0	0	0	0	1
07/30/2014 10:00	0.0	0	0	0	0	1
07/30/2014 11:00	0.0	0	0	0	0	1
07/30/2014 12:00	0.0	0	0	0	0	1
07/30/2014 13:00	0.0	0	0	0	0	1
07/30/2014 14:00	0.0	0	0	0	0	1
07/30/2014 15:00	0.0	0	0	0	0	1
07/30/2014 16:00	0.0	0	0	0	0	1
07/30/2014 17:00	0.0	0	0	0	0	1
07/30/2014 18:00	0.0	0	0	0	0	1
07/30/2014 19:00	0.0	0	0	0	0	1
07/30/2014 20:00	0.0	0	0	0	0	1
07/30/2014 21:00	0.0	0	0	0	0	1
07/30/2014 22:00	0.0	0	0	0	0	1
07/30/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
07/31/2014 00:00	0.0	0	0	0	0	1
07/31/2014 01:00	0.0	0	0	0	0	1
07/31/2014 02:00	0.0	0	0	0	0	1
07/31/2014 03:00	0.0	0	0	0	0	1
07/31/2014 04:00	0.0	0	0	0	0	1
07/31/2014 05:00	0.0	0	0	0	0	1
07/31/2014 06:00	0.0	0	0	0	0	1
07/31/2014 07:00	0.0	0	0	0	0	1
07/31/2014 08:00	0.0	0	0	0	0	1
07/31/2014 09:00	0.0	0	0	0	0	1
07/31/2014 10:00	0.0	0	0	0	0	1
07/31/2014 11:00	0.0	0	0	0	0	1
07/31/2014 12:00	0.0	0	0	0	0	1
07/31/2014 13:00	0.0	0	0	0	0	1
07/31/2014 14:00	0.0	0	0	0	0	1
07/31/2014 15:00	0.0	0	0	0	0	1
07/31/2014 16:00	0.0	0	0	0	0	1
07/31/2014 17:00	0.0	0	0	0	0	1
07/31/2014 18:00	0.0	0	0	0	0	1
07/31/2014 19:00	0.0	0	0	0	0	1
07/31/2014 20:00	0.0	0	0	0	0	1
07/31/2014 21:00	0.0	0	0	0	0	1
07/31/2014 22:00	0.0	0	0	0	0	1
07/31/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/01/2014 00:00	0.0	0	0	0	0	1
08/01/2014 01:00	0.0	0	0	0	0	1
08/01/2014 02:00	0.0	0	0	0	0	1
08/01/2014 03:00	0.0	0	0	0	0	1
08/01/2014 04:00	0.0	0	0	0	0	1
08/01/2014 05:00	0.0	0	0	0	0	1
08/01/2014 06:00	0.0	0	0	0	0	1
08/01/2014 07:00	0.0	0	0	0	0	1
08/01/2014 08:00	0.0	0	0	0	0	1
08/01/2014 09:00	0.0	0	0	0	0	1
08/01/2014 10:00	0.0	0	0	0	0	1
08/01/2014 11:00	0.0	0	0	0	0	1
08/01/2014 12:00	0.0	0	0	0	0	1
08/01/2014 13:00	0.0	0	0	0	0	1
08/01/2014 14:00	0.0	0	0	0	0	1
08/01/2014 15:00	0.0	0	0	0	0	1
08/01/2014 16:00	0.0	0	0	0	0	1
08/01/2014 17:00	0.0	0	0	0	0	1
08/01/2014 18:00	0.0	0	0	0	0	1
08/01/2014 19:00	0.0	0	0	0	0	1
08/01/2014 20:00	0.0	0	0	0	0	1
08/01/2014 21:00	0.0	0	0	0	0	1
08/01/2014 22:00	0.0	0	0	0	0	1
08/01/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/02/2014 00:00	0.0	0	0	0	0	1
08/02/2014 01:00	0.0	0	0	0	0	1
08/02/2014 02:00	0.0	0	0	0	0	1
08/02/2014 03:00	0.0	0	0	0	0	1
08/02/2014 04:00	0.0	0	0	0	0	1
08/02/2014 05:00	0.0	0	0	0	0	1
08/02/2014 06:00	0.0	0	0	0	0	1
08/02/2014 07:00	0.0	0	0	0	0	1
08/02/2014 08:00	0.0	0	0	0	0	1
08/02/2014 09:00	0.0	0	0	0	0	1
08/02/2014 10:00	0.0	0	0	0	0	1
08/02/2014 11:00	0.0	0	0	0	0	1
08/02/2014 12:00	0.0	0	0	0	0	1
08/02/2014 13:00	0.0	0	0	0	0	1
08/02/2014 14:00	0.0	0	0	0	0	1
08/02/2014 15:00	0.0	0	0	0	0	1
08/02/2014 16:00	0.0	0	0	0	0	1
08/02/2014 17:00	0.0	0	0	0	0	1
08/02/2014 18:00	0.0	0	0	0	0	1
08/02/2014 19:00	0.0	0	0	0	0	1
08/02/2014 20:00	0.0	0	0	0	0	1
08/02/2014 21:00	0.0	0	0	0	0	1
08/02/2014 22:00	0.0	0	0	0	0	1
08/02/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/03/2014 00:00	0.0	0	0	0	0	1
08/03/2014 01:00	0.0	0	0	0	0	1
08/03/2014 02:00	0.0	0	0	0	0	1
08/03/2014 03:00	0.0	0	0	0	0	1
08/03/2014 04:00	0.0	0	0	0	0	1
08/03/2014 05:00	0.0	0	0	0	0	1
08/03/2014 06:00	0.0	0	0	0	0	1
08/03/2014 07:00	0.0	0	0	0	0	1
08/03/2014 08:00	0.0	0	0	0	0	1
08/03/2014 09:00	0.0	0	0	0	0	1
08/03/2014 10:00	0.0	0	0	0	0	1
08/03/2014 11:00	0.0	0	0	0	0	1
08/03/2014 12:00	0.0	0	0	0	0	1
08/03/2014 13:00	0.0	0	0	0	0	1
08/03/2014 14:00	0.0	0	0	0	0	1
08/03/2014 15:00	0.0	0	0	0	0	1
08/03/2014 16:00	0.0	0	0	0	0	1
08/03/2014 17:00	0.0	0	0	0	0	1
08/03/2014 18:00	0.0	0	0	0	0	1
08/03/2014 19:00	0.0	0	0	0	0	1
08/03/2014 20:00	0.0	0	0	0	0	1
08/03/2014 21:00	0.0	0	0	0	0	1
08/03/2014 22:00	0.0	0	0	0	0	1
08/03/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/04/2014 00:00	0.0	0	0	0	0	1
08/04/2014 01:00	0.0	0	0	0	0	1
08/04/2014 02:00	0.0	0	0	0	0	1
08/04/2014 03:00	0.0	0	0	0	0	1
08/04/2014 04:00	0.0	0	0	0	0	1
08/04/2014 05:00	0.0	0	0	0	0	1
08/04/2014 06:00	0.0	0	0	0	0	1
08/04/2014 07:00	0.0	0	0	0	0	1
08/04/2014 08:00	0.0	0	0	0	0	1
08/04/2014 09:00	0.0	0	0	0	0	1
08/04/2014 10:00	0.0	0	0	0	0	1
08/04/2014 11:00	0.0	0	0	0	0	1
08/04/2014 12:00	0.0	0	0	0	0	1
08/04/2014 13:00	0.0	0	0	0	0	1
08/04/2014 14:00	0.0	0	0	0	0	1
08/04/2014 15:00	0.0	0	0	0	0	1
08/04/2014 16:00	0.0	0	0	0	0	1
08/04/2014 17:00	0.0	0	0	0	0	1
08/04/2014 18:00	0.0	0	0	0	0	1
08/04/2014 19:00	0.0	0	0	0	0	1
08/04/2014 20:00	0.0	0	0	0	0	1
08/04/2014 21:00	0.0	0	0	0	0	1
08/04/2014 22:00	0.0	0	0	0	0	1
08/04/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/05/2014 00:00	0.0	0	0	0	0	1
08/05/2014 01:00	0.0	0	0	0	0	1
08/05/2014 02:00	0.0	0	0	0	0	1
08/05/2014 03:00	0.0	0	0	0	0	1
08/05/2014 04:00	0.0	0	0	0	0	1
08/05/2014 05:00	0.0	0	0	0	0	1
08/05/2014 06:00	0.0	0	0	0	0	1
08/05/2014 07:00	0.0	0	0	0	0	1
08/05/2014 08:00	0.0	0	0	0	0	1
08/05/2014 09:00	0.0	0	0	0	0	1
08/05/2014 10:00	0.0	0	0	0	0	1
08/05/2014 11:00	0.0	0	0	0	0	1
08/05/2014 12:00	0.0	0	0	0	0	1
08/05/2014 13:00	0.0	0	0	0	0	1
08/05/2014 14:00	0.0	0	0	0	0	1
08/05/2014 15:00	0.0	0	0	0	0	1
08/05/2014 16:00	0.0	0	0	0	0	1
08/05/2014 17:00	0.0	0	0	0	0	1
08/05/2014 18:00	0.0	0	0	0	0	1
08/05/2014 19:00	0.0	0	0	0	0	1
08/05/2014 20:00	0.0	0	0	0	0	1
08/05/2014 21:00	0.0	0	0	0	0	1
08/05/2014 22:00	0.0	0	0	0	0	1
08/05/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/06/2014 00:00	0.0	0	0	0	0	1
08/06/2014 01:00	0.0	0	0	0	0	1
08/06/2014 02:00	0.0	0	0	0	0	1
08/06/2014 03:00	0.0	0	0	0	0	1
08/06/2014 04:00	0.0	0	0	0	0	1
08/06/2014 05:00	0.0	0	0	0	0	1
08/06/2014 06:00	0.0	0	0	0	0	1
08/06/2014 07:00	0.0	0	0	0	0	1
08/06/2014 08:00	0.0	0	0	0	0	1
08/06/2014 09:00	0.0	0	0	0	0	1
08/06/2014 10:00	0.0	0	0	0	0	1
08/06/2014 11:00	0.0	0	0	0	0	1
08/06/2014 12:00	0.0	0	0	0	0	1
08/06/2014 13:00	0.0	0	0	0	0	1
08/06/2014 14:00	0.0	0	0	0	0	1
08/06/2014 15:00	0.0	0	0	0	0	1
08/06/2014 16:00	0.0	0	0	0	0	1
08/06/2014 17:00	0.0	0	0	0	0	1
08/06/2014 18:00	0.0	0	0	0	0	1
08/06/2014 19:00	0.0	0	0	0	0	1
08/06/2014 20:00	0.0	0	0	0	0	1
08/06/2014 21:00	0.0	0	0	0	0	1
08/06/2014 22:00	0.0	0	0	0	0	1
08/06/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/07/2014 00:00	263.5	0	0	0	1	0
08/07/2014 01:00	0.0	0	0	0	0	0
08/07/2014 02:00	0.0	0	0	0	0	0
08/07/2014 03:00	0.0	0	0	0	0	0
08/07/2014 04:00	0.0	0	0	0	0	0
08/07/2014 05:00	0.0	0	0	0	0	0
08/07/2014 06:00	0.0	0	0	0	0	0
08/07/2014 07:00	3,345.7	0	0	1	0	0
08/07/2014 08:00	5,445.3	0	0	1	0	0
08/07/2014 09:00	0.0	0	0	0	0	1
08/07/2014 10:00	0.0	0	0	0	0	1
08/07/2014 11:00	0.0	0	0	0	0	1
08/07/2014 12:00	0.0	0	0	0	0	1
08/07/2014 13:00	0.0	0	0	0	0	1
08/07/2014 14:00	0.0	0	0	0	0	1
08/07/2014 15:00	0.0	0	0	0	0	1
08/07/2014 16:00	0.0	0	0	0	0	1
08/07/2014 17:00	0.0	0	0	0	0	1
08/07/2014 18:00	0.0	0	0	0	0	1
08/07/2014 19:00	0.0	0	0	0	0	1
08/07/2014 20:00	0.0	0	0	0	0	1
08/07/2014 21:00	0.0	0	0	0	0	1
08/07/2014 22:00	0.0	0	0	0	0	1
08/07/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	9,054.5 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	5,445.3	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/08/2014 00:00	0.0	0	0	0	0	1
08/08/2014 01:00	0.0	0	0	0	0	1
08/08/2014 02:00	0.0	0	0	0	0	1
08/08/2014 03:00	0.0	0	0	0	0	1
08/08/2014 04:00	0.0	0	0	0	0	1
08/08/2014 05:00	0.0	0	0	0	0	1
08/08/2014 06:00	0.0	0	0	0	0	1
08/08/2014 07:00	0.0	0	0	0	0	1
08/08/2014 08:00	0.0	0	0	0	0	1
08/08/2014 09:00	0.0	0	0	0	0	1
08/08/2014 10:00	0.0	0	0	0	0	1
08/08/2014 11:00	0.0	0	0	0	0	1
08/08/2014 12:00	0.0	0	0	0	0	1
08/08/2014 13:00	0.0	0	0	0	0	1
08/08/2014 14:00	0.0	0	0	0	0	1
08/08/2014 15:00	0.0	0	0	0	0	1
08/08/2014 16:00	0.0	0	0	0	0	1
08/08/2014 17:00	0.0	0	0	0	0	1
08/08/2014 18:00	0.0	0	0	0	0	1
08/08/2014 19:00	0.0	0	0	0	0	1
08/08/2014 20:00	0.0	0	0	0	0	1
08/08/2014 21:00	0.0	0	0	0	0	1
08/08/2014 22:00	0.0	0	0	0	0	1
08/08/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/09/2014 00:00	0.0	0	0	0	0	1
08/09/2014 01:00	0.0	0	0	0	0	1
08/09/2014 02:00	392.6	0	0	0	1	0
08/09/2014 03:00	0.0	0	0	0	0	0
08/09/2014 04:00	0.0	0	0	0	0	0
08/09/2014 05:00	0.0	0	0	0	0	0
08/09/2014 06:00	3,978.9	0	0	1	0	0
08/09/2014 07:00	2,078.0	0	0	1	0	0
08/09/2014 08:00	0.0	0	0	0	0	1
08/09/2014 09:00	0.0	0	0	0	0	1
08/09/2014 10:00	0.0	0	0	0	0	1
08/09/2014 11:00	0.0	0	0	0	0	1
08/09/2014 12:00	0.0	0	0	0	0	1
08/09/2014 13:00	0.0	0	0	0	0	1
08/09/2014 14:00	0.0	0	0	0	0	1
08/09/2014 15:00	0.0	0	0	0	0	1
08/09/2014 16:00	0.0	0	0	0	0	1
08/09/2014 17:00	0.0	0	0	0	0	1
08/09/2014 18:00	0.0	0	0	0	0	1
08/09/2014 19:00	0.0	0	0	0	0	1
08/09/2014 20:00	0.0	0	0	0	0	1
08/09/2014 21:00	0.0	0	0	0	0	1
08/09/2014 22:00	0.0	0	0	0	0	1
08/09/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	6,449.5 #	0 #	0 #	2 #	1 #	18 #
Minimum:	0.0	0	0	0	0	0
Maximum:	3,978.9	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/10/2014 00:00	326.1	0	0	0	1	0
08/10/2014 01:00	0.0	0	0	0	0	0
08/10/2014 02:00	0.0	0	0	0	0	0
08/10/2014 03:00	0.0	0	0	0	0	0
08/10/2014 04:00	0.0	0	0	0	0	0
08/10/2014 05:00	0.0	0	0	0	0	0
08/10/2014 06:00	0.0	0	0	0	0	0
08/10/2014 07:00	4,077.0	0	0	1	0	0
08/10/2014 08:00	3,635.8	0	0	1	0	0
08/10/2014 09:00	0.0	0	0	0	0	1
08/10/2014 10:00	0.0	0	0	0	0	1
08/10/2014 11:00	0.0	0	0	0	0	1
08/10/2014 12:00	0.0	0	0	0	0	1
08/10/2014 13:00	0.0	0	0	0	0	1
08/10/2014 14:00	0.0	0	0	0	0	1
08/10/2014 15:00	0.0	0	0	0	0	1
08/10/2014 16:00	0.0	0	0	0	0	1
08/10/2014 17:00	0.0	0	0	0	0	1
08/10/2014 18:00	0.0	0	0	0	0	1
08/10/2014 19:00	0.0	0	0	0	0	1
08/10/2014 20:00	0.0	0	0	0	0	1
08/10/2014 21:00	0.0	0	0	0	0	1
08/10/2014 22:00	0.0	0	0	0	0	1
08/10/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	8,038.9 #	0 #	0 #	2 #	1 #	15 #
Minimum:	0.0	0	0	0	0	0
Maximum:	4,077.0	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/11/2014 00:00	0.0	0	0	0	0	1
08/11/2014 01:00	0.0	0	0	0	0	1
08/11/2014 02:00	0.0	0	0	0	0	1
08/11/2014 03:00	0.0	0	0	0	0	1
08/11/2014 04:00	0.0	0	0	0	0	1
08/11/2014 05:00	0.0	0	0	0	0	1
08/11/2014 06:00	0.0	0	0	0	0	1
08/11/2014 07:00	0.0	0	0	0	0	1
08/11/2014 08:00	0.0	0	0	0	0	1
08/11/2014 09:00	0.0	0	0	0	0	1
08/11/2014 10:00	0.0	0	0	0	0	1
08/11/2014 11:00	0.0	0	0	0	0	1
08/11/2014 12:00	0.0	0	0	0	0	1
08/11/2014 13:00	0.0	0	0	0	0	1
08/11/2014 14:00	0.0	0	0	0	0	1
08/11/2014 15:00	0.0	0	0	0	0	1
08/11/2014 16:00	0.0	0	0	0	0	1
08/11/2014 17:00	0.0	0	0	0	0	1
08/11/2014 18:00	0.0	0	0	0	0	1
08/11/2014 19:00	0.0	0	0	0	0	1
08/11/2014 20:00	0.0	0	0	0	0	1
08/11/2014 21:00	0.0	0	0	0	0	1
08/11/2014 22:00	0.0	0	0	0	0	1
08/11/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/12/2014 00:00	0.0	0	0	0	0	1
08/12/2014 01:00	0.0	0	0	0	0	1
08/12/2014 02:00	0.0	0	0	0	0	1
08/12/2014 03:00	0.0	0	0	0	0	1
08/12/2014 04:00	0.0	0	0	0	0	1
08/12/2014 05:00	0.0	0	0	0	0	1
08/12/2014 06:00	0.0	0	0	0	0	1
08/12/2014 07:00	0.0	0	0	0	0	1
08/12/2014 08:00	0.0	0	0	0	0	1
08/12/2014 09:00	0.0	0	0	0	0	1
08/12/2014 10:00	0.0	0	0	0	0	1
08/12/2014 11:00	0.0	0	0	0	0	1
08/12/2014 12:00	0.0	0	0	0	0	1
08/12/2014 13:00	0.0	0	0	0	0	1
08/12/2014 14:00	0.0	0	0	0	0	1
08/12/2014 15:00	0.0	0	0	0	0	1
08/12/2014 16:00	0.0	0	0	0	0	1
08/12/2014 17:00	0.0	0	0	0	0	1
08/12/2014 18:00	0.0	0	0	0	0	1
08/12/2014 19:00	0.0	0	0	0	0	1
08/12/2014 20:00	0.0	0	0	0	0	1
08/12/2014 21:00	0.0	0	0	0	0	1
08/12/2014 22:00	0.0	0	0	0	0	1
08/12/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/13/2014 00:00	0.0	0	0	0	0	1
08/13/2014 01:00	566.0	0	0	0	1	0
08/13/2014 02:00	0.0	0	0	0	0	0
08/13/2014 03:00	0.0	0	0	0	0	0
08/13/2014 04:00	0.0	0	0	0	0	0
08/13/2014 05:00	2,577.3	0	0	1	0	0
08/13/2014 06:00	1,309.7	0	0	1	0	0
08/13/2014 07:00	0.0	0	0	0	0	1
08/13/2014 08:00	0.0	0	0	0	0	1
08/13/2014 09:00	0.0	0	0	0	0	1
08/13/2014 10:00	0.0	0	0	0	0	1
08/13/2014 11:00	0.0	0	0	0	0	1
08/13/2014 12:00	0.0	0	0	0	0	1
08/13/2014 13:00	0.0	0	0	0	0	1
08/13/2014 14:00	0.0	0	0	0	0	1
08/13/2014 15:00	0.0	0	0	0	0	1
08/13/2014 16:00	0.0	0	0	0	0	1
08/13/2014 17:00	0.0	0	0	0	0	1
08/13/2014 18:00	0.0	0	0	0	0	1
08/13/2014 19:00	0.0	0	0	0	0	1
08/13/2014 20:00	0.0	0	0	0	0	1
08/13/2014 21:00	0.0	0	0	0	0	1
08/13/2014 22:00	0.0	0	0	0	0	1
08/13/2014 23:00	365.1	0	0	0	1	0
Average/Sum#:	4,818.1 #	0 #	0 #	2 #	2 #	17 #
Minimum:	0.0	0	0	0	0	0
Maximum:	2,577.3	0	0	1	1	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/14/2014 00:00	0.0	0	0	0	0	0
08/14/2014 01:00	0.0	0	0	0	0	0
08/14/2014 02:00	0.0	0	0	0	0	0
08/14/2014 03:00	0.0	0	0	0	0	0
08/14/2014 04:00	0.0	0	0	0	0	0
08/14/2014 05:00	0.0	0	0	0	0	0
08/14/2014 06:00	0.0	0	0	0	0	0
08/14/2014 07:00	0.0	0	0	0	0	0
08/14/2014 08:00	0.0	0	0	0	0	0
08/14/2014 09:00	0.0	0	0	0	0	0
08/14/2014 10:00	0.0	0	0	0	0	0
08/14/2014 11:00	0.0	0	0	0	0	0
08/14/2014 12:00	0.0	0	0	0	0	0
08/14/2014 13:00	0.0	0	0	0	0	0
08/14/2014 14:00	0.0	0	0	0	0	0
08/14/2014 15:00	0.0	0	0	0	0	0
08/14/2014 16:00	0.0	0	0	0	0	0
08/14/2014 17:00	0.0	0	0	0	0	0
08/14/2014 18:00	0.0	0	0	0	0	0
08/14/2014 19:00	0.0	0	0	0	0	0
08/14/2014 20:00	0.0	0	0	0	0	0
08/14/2014 21:00	0.0	0	0	0	0	0
08/14/2014 22:00	0.0	0	0	0	0	0
08/14/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/15/2014 00:00	0.0	0	0	0	0	0
08/15/2014 01:00	0.0	0	0	0	0	0
08/15/2014 02:00	0.0	0	0	0	0	0
08/15/2014 03:00	0.0	0	0	0	0	0
08/15/2014 04:00	0.0	0	0	0	0	0
08/15/2014 05:00	0.0	0	0	0	0	0
08/15/2014 06:00	0.0	0	0	0	0	0
08/15/2014 07:00	0.0	0	0	0	0	0
08/15/2014 08:00	0.0	0	0	0	0	0
08/15/2014 09:00	0.0	0	0	0	0	0
08/15/2014 10:00	0.0	0	0	0	0	0
08/15/2014 11:00	0.0	0	0	0	0	0
08/15/2014 12:00	0.0	0	0	0	0	0
08/15/2014 13:00	0.0	0	0	0	0	0
08/15/2014 14:00	0.0	0	0	0	0	0
08/15/2014 15:00	0.0	0	0	0	0	0
08/15/2014 16:00	0.0	0	0	0	0	0
08/15/2014 17:00	0.0	0	0	0	0	0
08/15/2014 18:00	0.0	0	0	0	0	0
08/15/2014 19:00	0.0	0	0	0	0	0
08/15/2014 20:00	0.0	0	0	0	0	0
08/15/2014 21:00	0.0	0	0	0	0	0
08/15/2014 22:00	0.0	0	0	0	0	0
08/15/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/16/2014 00:00	0.0	0	0	0	0	0
08/16/2014 01:00	0.0	0	0	0	0	0
08/16/2014 02:00	0.0	0	0	0	0	0
08/16/2014 03:00	0.0	0	0	0	0	0
08/16/2014 04:00	0.0	0	0	0	0	0
08/16/2014 05:00	0.0	0	0	0	0	0
08/16/2014 06:00	0.0	0	0	0	0	0
08/16/2014 07:00	0.0	0	0	0	0	0
08/16/2014 08:00	0.0	0	0	0	0	0
08/16/2014 09:00	0.0	0	0	0	0	0
08/16/2014 10:00	0.0	0	0	0	0	0
08/16/2014 11:00	0.0	0	0	0	0	0
08/16/2014 12:00	0.0	0	0	0	0	0
08/16/2014 13:00	0.0	0	0	0	0	0
08/16/2014 14:00	0.0	0	0	0	0	0
08/16/2014 15:00	0.0	0	0	0	0	0
08/16/2014 16:00	0.0	0	0	0	0	0
08/16/2014 17:00	0.0	0	0	0	0	0
08/16/2014 18:00	0.0	0	0	0	0	0
08/16/2014 19:00	0.0	0	0	0	0	0
08/16/2014 20:00	0.0	0	0	0	0	0
08/16/2014 21:00	0.0	0	0	0	0	0
08/16/2014 22:00	0.0	0	0	0	0	0
08/16/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/17/2014 00:00	0.0	0	0	0	0	0
08/17/2014 01:00	0.0	0	0	0	0	0
08/17/2014 02:00	0.0	0	0	0	0	0
08/17/2014 03:00	0.0	0	0	0	0	0
08/17/2014 04:00	0.0	0	0	0	0	0
08/17/2014 05:00	0.0	0	0	0	0	0
08/17/2014 06:00	0.0	0	0	0	0	0
08/17/2014 07:00	0.0	0	0	0	0	0
08/17/2014 08:00	0.0	0	0	0	0	0
08/17/2014 09:00	0.0	0	0	0	0	0
08/17/2014 10:00	0.0	0	0	0	0	0
08/17/2014 11:00	0.0	0	0	0	0	0
08/17/2014 12:00	0.0	0	0	0	0	0
08/17/2014 13:00	0.0	0	0	0	0	0
08/17/2014 14:00	0.0	0	0	0	0	0
08/17/2014 15:00	0.0	0	0	0	0	0
08/17/2014 16:00	0.0	0	0	0	0	0
08/17/2014 17:00	0.0	0	0	0	0	0
08/17/2014 18:00	0.0	0	0	0	0	0
08/17/2014 19:00	0.0	0	0	0	0	0
08/17/2014 20:00	0.0	0	0	0	0	0
08/17/2014 21:00	0.0	0	0	0	0	0
08/17/2014 22:00	0.0	0	0	0	0	0
08/17/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/18/2014 00:00	0.0	0	0	0	0	0
08/18/2014 01:00	0.0	0	0	0	0	0
08/18/2014 02:00	0.0	0	0	0	0	0
08/18/2014 03:00	0.0	0	0	0	0	0
08/18/2014 04:00	0.0	0	0	0	0	0
08/18/2014 05:00	0.0	0	0	0	0	0
08/18/2014 06:00	0.0	0	0	0	0	0
08/18/2014 07:00	0.0	0	0	0	0	0
08/18/2014 08:00	0.0	0	0	0	0	0
08/18/2014 09:00	0.0	0	0	0	0	0
08/18/2014 10:00	0.0	0	0	0	0	0
08/18/2014 11:00	0.0	0	0	0	0	0
08/18/2014 12:00	0.0	0	0	0	0	0
08/18/2014 13:00	0.0	0	0	0	0	0
08/18/2014 14:00	0.0	0	0	0	0	0
08/18/2014 15:00	0.0	0	0	0	0	0
08/18/2014 16:00	0.0	0	0	0	0	0
08/18/2014 17:00	0.0	0	0	0	0	0
08/18/2014 18:00	0.0	0	0	0	0	0
08/18/2014 19:00	0.0	0	0	0	0	0
08/18/2014 20:00	0.0	0	0	0	0	0
08/18/2014 21:00	0.0	0	0	0	0	0
08/18/2014 22:00	0.0	0	0	0	0	0
08/18/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/19/2014 00:00	0.0	0	0	0	0	0
08/19/2014 01:00	0.0	0	0	0	0	0
08/19/2014 02:00	0.0	0	0	0	0	0
08/19/2014 03:00	0.0	0	0	0	0	0
08/19/2014 04:00	0.0	0	0	0	0	0
08/19/2014 05:00	0.0	0	0	0	0	0
08/19/2014 06:00	0.0	0	0	0	0	0
08/19/2014 07:00	0.0	0	0	0	0	0
08/19/2014 08:00	0.0	0	0	0	0	0
08/19/2014 09:00	0.0	0	0	0	0	0
08/19/2014 10:00	0.0	0	0	0	0	0
08/19/2014 11:00	0.0	0	0	0	0	0
08/19/2014 12:00	0.0	0	0	0	0	0
08/19/2014 13:00	0.0	0	0	0	0	0
08/19/2014 14:00	0.0	0	0	0	0	0
08/19/2014 15:00	0.0	0	0	0	0	0
08/19/2014 16:00	0.0	0	0	0	0	0
08/19/2014 17:00	0.0	0	0	0	0	0
08/19/2014 18:00	0.0	0	0	0	0	0
08/19/2014 19:00	0.0	0	0	0	0	0
08/19/2014 20:00	0.0	0	0	0	0	0
08/19/2014 21:00	0.0	0	0	0	0	0
08/19/2014 22:00	0.0	0	0	0	0	0
08/19/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/20/2014 00:00	0.0	0	0	0	0	0
08/20/2014 01:00	0.0	0	0	0	0	0
08/20/2014 02:00	0.0	0	0	0	0	0
08/20/2014 03:00	0.0	0	0	0	0	0
08/20/2014 04:00	0.0	0	0	0	0	0
08/20/2014 05:00	0.0	0	0	0	0	0
08/20/2014 06:00	0.0	0	0	0	0	0
08/20/2014 07:00	0.0	0	0	0	0	0
08/20/2014 08:00	0.0	0	0	0	0	0
08/20/2014 09:00	0.0	0	0	0	0	0
08/20/2014 10:00	0.0	0	0	0	0	0
08/20/2014 11:00	0.0	0	0	0	0	0
08/20/2014 12:00	0.0	0	0	0	0	0
08/20/2014 13:00	0.0	0	0	0	0	0
08/20/2014 14:00	0.0	0	0	0	0	0
08/20/2014 15:00	0.0	0	0	0	0	0
08/20/2014 16:00	0.0	0	0	0	0	0
08/20/2014 17:00	0.0	0	0	0	0	0
08/20/2014 18:00	0.0	0	0	0	0	0
08/20/2014 19:00	0.0	0	0	0	0	0
08/20/2014 20:00	0.0	0	0	0	0	0
08/20/2014 21:00	0.0	0	0	0	0	0
08/20/2014 22:00	0.0	0	0	0	0	0
08/20/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/21/2014 00:00	0.0	0	0	0	0	0
08/21/2014 01:00	0.0	0	0	0	0	0
08/21/2014 02:00	0.0	0	0	0	0	0
08/21/2014 03:00	0.0	0	0	0	0	0
08/21/2014 04:00	0.0	0	0	0	0	0
08/21/2014 05:00	0.0	0	0	0	0	0
08/21/2014 06:00	0.0	0	0	0	0	0
08/21/2014 07:00	0.0	0	0	0	0	0
08/21/2014 08:00	0.0	0	0	0	0	0
08/21/2014 09:00	0.0	0	0	0	0	0
08/21/2014 10:00	0.0	0	0	0	0	0
08/21/2014 11:00	0.0	0	0	0	0	0
08/21/2014 12:00	0.0	0	0	0	0	0
08/21/2014 13:00	0.0	0	0	0	0	0
08/21/2014 14:00	0.0	0	0	0	0	0
08/21/2014 15:00	0.0	0	0	0	0	0
08/21/2014 16:00	0.0	0	0	0	0	0
08/21/2014 17:00	0.0	0	0	0	0	0
08/21/2014 18:00	0.0	0	0	0	0	0
08/21/2014 19:00	0.0	0	0	0	0	0
08/21/2014 20:00	0.0	0	0	0	0	0
08/21/2014 21:00	0.0	0	0	0	0	0
08/21/2014 22:00	0.0	0	0	0	0	0
08/21/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/22/2014 00:00	0.0	0	0	0	0	0
08/22/2014 01:00	0.0	0	0	0	0	0
08/22/2014 02:00	0.0	0	0	0	0	0
08/22/2014 03:00	0.0	0	0	0	0	0
08/22/2014 04:00	0.0	0	0	0	0	0
08/22/2014 05:00	0.0	0	0	0	0	0
08/22/2014 06:00	0.0	0	0	0	0	0
08/22/2014 07:00	0.0	0	0	0	0	0
08/22/2014 08:00	0.0	0	0	0	0	0
08/22/2014 09:00	0.0	0	0	0	0	0
08/22/2014 10:00	0.0	0	0	0	0	0
08/22/2014 11:00	0.0	0	0	0	0	0
08/22/2014 12:00	0.0	0	0	0	0	0
08/22/2014 13:00	0.0	0	0	0	0	0
08/22/2014 14:00	0.0	0	0	0	0	0
08/22/2014 15:00	0.0	0	0	0	0	0
08/22/2014 16:00	0.0	0	0	0	0	0
08/22/2014 17:00	0.0	0	0	0	0	0
08/22/2014 18:00	0.0	0	0	0	0	0
08/22/2014 19:00	0.0	0	0	0	0	0
08/22/2014 20:00	0.0	0	0	0	0	0
08/22/2014 21:00	0.0	0	0	0	0	0
08/22/2014 22:00	0.0	0	0	0	0	0
08/22/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/23/2014 00:00	0.0	0	0	0	0	0
08/23/2014 01:00	0.0	0	0	0	0	0
08/23/2014 02:00	0.0	0	0	0	0	0
08/23/2014 03:00	0.0	0	0	0	0	0
08/23/2014 04:00	0.0	0	0	0	0	0
08/23/2014 05:00	0.0	0	0	0	0	0
08/23/2014 06:00	0.0	0	0	0	0	0
08/23/2014 07:00	0.0	0	0	0	0	0
08/23/2014 08:00	0.0	0	0	0	0	0
08/23/2014 09:00	0.0	0	0	0	0	0
08/23/2014 10:00	0.0	0	0	0	0	0
08/23/2014 11:00	0.0	0	0	0	0	0
08/23/2014 12:00	0.0	0	0	0	0	0
08/23/2014 13:00	0.0	0	0	0	0	0
08/23/2014 14:00	0.0	0	0	0	0	0
08/23/2014 15:00	0.0	0	0	0	0	0
08/23/2014 16:00	0.0	0	0	0	0	0
08/23/2014 17:00	0.0	0	0	0	0	0
08/23/2014 18:00	0.0	0	0	0	0	0
08/23/2014 19:00	0.0	0	0	0	0	0
08/23/2014 20:00	0.0	0	0	0	0	0
08/23/2014 21:00	0.0	0	0	0	0	0
08/23/2014 22:00	0.0	0	0	0	0	0
08/23/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/24/2014 00:00	0.0	0	0	0	0	0
08/24/2014 01:00	0.0	0	0	0	0	0
08/24/2014 02:00	0.0	0	0	0	0	0
08/24/2014 03:00	0.0	0	0	0	0	0
08/24/2014 04:00	0.0	0	0	0	0	0
08/24/2014 05:00	0.0	0	0	0	0	0
08/24/2014 06:00	0.0	0	0	0	0	0
08/24/2014 07:00	0.0	0	0	0	0	0
08/24/2014 08:00	0.0	0	0	0	0	0
08/24/2014 09:00	0.0	0	0	0	0	0
08/24/2014 10:00	0.0	0	0	0	0	0
08/24/2014 11:00	0.0	0	0	0	0	0
08/24/2014 12:00	0.0	0	0	0	0	0
08/24/2014 13:00	0.0	0	0	0	0	0
08/24/2014 14:00	0.0	0	0	0	0	0
08/24/2014 15:00	0.0	0	0	0	0	0
08/24/2014 16:00	0.0	0	0	0	0	0
08/24/2014 17:00	0.0	0	0	0	0	0
08/24/2014 18:00	0.0	0	0	0	0	0
08/24/2014 19:00	0.0	0	0	0	0	0
08/24/2014 20:00	0.0	0	0	0	0	0
08/24/2014 21:00	0.0	0	0	0	0	0
08/24/2014 22:00	0.0	0	0	0	0	0
08/24/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/25/2014 00:00	0.0	0	0	0	0	0
08/25/2014 01:00	0.0	0	0	0	0	0
08/25/2014 02:00	0.0	0	0	0	0	0
08/25/2014 03:00	0.0	0	0	0	0	0
08/25/2014 04:00	0.0	0	0	0	0	0
08/25/2014 05:00	0.0	0	0	0	0	0
08/25/2014 06:00	0.0	0	0	0	0	0
08/25/2014 07:00	0.0	0	0	0	0	0
08/25/2014 08:00	0.0	0	0	0	0	0
08/25/2014 09:00	0.0	0	0	0	0	0
08/25/2014 10:00	0.0	0	0	0	0	0
08/25/2014 11:00	0.0	0	0	0	0	0
08/25/2014 12:00	0.0	0	0	0	0	0
08/25/2014 13:00	0.0	0	0	0	0	0
08/25/2014 14:00	0.0	0	0	0	0	0
08/25/2014 15:00	0.0	0	0	0	0	0
08/25/2014 16:00	0.0	0	0	0	0	0
08/25/2014 17:00	0.0	0	0	0	0	0
08/25/2014 18:00	0.0	0	0	0	0	0
08/25/2014 19:00	0.0	0	0	0	0	0
08/25/2014 20:00	0.0	0	0	0	0	0
08/25/2014 21:00	0.0	0	0	0	0	0
08/25/2014 22:00	0.0	0	0	0	0	0
08/25/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/26/2014 00:00	0.0	0	0	0	0	0
08/26/2014 01:00	0.0	0	0	0	0	0
08/26/2014 02:00	0.0	0	0	0	0	0
08/26/2014 03:00	0.0	0	0	0	0	0
08/26/2014 04:00	0.0	0	0	0	0	0
08/26/2014 05:00	0.0	0	0	0	0	0
08/26/2014 06:00	0.0	0	0	0	0	0
08/26/2014 07:00	0.0	0	0	0	0	0
08/26/2014 08:00	0.0	0	0	0	0	0
08/26/2014 09:00	0.0	0	0	0	0	0
08/26/2014 10:00	0.0	0	0	0	0	0
08/26/2014 11:00	0.0	0	0	0	0	0
08/26/2014 12:00	0.0	0	0	0	0	0
08/26/2014 13:00	0.0	0	0	0	0	0
08/26/2014 14:00	0.0	0	0	0	0	0
08/26/2014 15:00	0.0	0	0	0	0	0
08/26/2014 16:00	0.0	0	0	0	0	0
08/26/2014 17:00	0.0	0	0	0	0	0
08/26/2014 18:00	0.0	0	0	0	0	0
08/26/2014 19:00	0.0	0	0	0	0	0
08/26/2014 20:00	0.0	0	0	0	0	0
08/26/2014 21:00	0.0	0	0	0	0	0
08/26/2014 22:00	0.0	0	0	0	0	0
08/26/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/27/2014 00:00	0.0	0	0	0	0	0
08/27/2014 01:00	0.0	0	0	0	0	0
08/27/2014 02:00	0.0	0	0	0	0	0
08/27/2014 03:00	0.0	0	0	0	0	0
08/27/2014 04:00	0.0	0	0	0	0	0
08/27/2014 05:00	0.0	0	0	0	0	0
08/27/2014 06:00	0.0	0	0	0	0	0
08/27/2014 07:00	0.0	0	0	0	0	0
08/27/2014 08:00	0.0	0	0	0	0	0
08/27/2014 09:00	0.0	0	0	0	0	0
08/27/2014 10:00	0.0	0	0	0	0	0
08/27/2014 11:00	0.0	0	0	0	0	0
08/27/2014 12:00	0.0	0	0	0	0	0
08/27/2014 13:00	0.0	0	0	0	0	0
08/27/2014 14:00	0.0	0	0	0	0	0
08/27/2014 15:00	0.0	0	0	0	0	0
08/27/2014 16:00	0.0	0	0	0	0	0
08/27/2014 17:00	0.0	0	0	0	0	0
08/27/2014 18:00	0.0	0	0	0	0	0
08/27/2014 19:00	0.0	0	0	0	0	0
08/27/2014 20:00	0.0	0	0	0	0	0
08/27/2014 21:00	0.0	0	0	0	0	0
08/27/2014 22:00	0.0	0	0	0	0	0
08/27/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/28/2014 00:00	0.0	0	0	0	0	0
08/28/2014 01:00	0.0	0	0	0	0	0
08/28/2014 02:00	0.0	0	0	0	0	0
08/28/2014 03:00	0.0	0	0	0	0	0
08/28/2014 04:00	0.0	0	0	0	0	0
08/28/2014 05:00	0.0	0	0	0	0	0
08/28/2014 06:00	0.0	0	0	0	0	0
08/28/2014 07:00	0.0	0	0	0	0	0
08/28/2014 08:00	0.0	0	0	0	0	0
08/28/2014 09:00	0.0	0	0	0	0	0
08/28/2014 10:00	0.0	0	0	0	0	0
08/28/2014 11:00	0.0	0	0	0	0	0
08/28/2014 12:00	0.0	0	0	0	0	0
08/28/2014 13:00	0.0	0	0	0	0	0
08/28/2014 14:00	0.0	0	0	0	0	0
08/28/2014 15:00	0.0	0	0	0	0	0
08/28/2014 16:00	0.0	0	0	0	0	0
08/28/2014 17:00	0.0	0	0	0	0	0
08/28/2014 18:00	0.0	0	0	0	0	0
08/28/2014 19:00	0.0	0	0	0	0	0
08/28/2014 20:00	0.0	0	0	0	0	0
08/28/2014 21:00	0.0	0	0	0	0	0
08/28/2014 22:00	0.0	0	0	0	0	0
08/28/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/29/2014 00:00	0.0	0	0	0	0	0
08/29/2014 01:00	0.0	0	0	0	0	0
08/29/2014 02:00	0.0	0	0	0	0	0
08/29/2014 03:00	0.0	0	0	0	0	0
08/29/2014 04:00	0.0	0	0	0	0	0
08/29/2014 05:00	0.0	0	0	0	0	0
08/29/2014 06:00	0.0	0	0	0	0	0
08/29/2014 07:00	0.0	0	0	0	0	0
08/29/2014 08:00	0.0	0	0	0	0	0
08/29/2014 09:00	0.0	0	0	0	0	0
08/29/2014 10:00	0.0	0	0	0	0	0
08/29/2014 11:00	0.0	0	0	0	0	0
08/29/2014 12:00	0.0	0	0	0	0	0
08/29/2014 13:00	0.0	0	0	0	0	0
08/29/2014 14:00	0.0	0	0	0	0	0
08/29/2014 15:00	0.0	0	0	0	0	0
08/29/2014 16:00	0.0	0	0	0	0	0
08/29/2014 17:00	0.0	0	0	0	0	0
08/29/2014 18:00	0.0	0	0	0	0	0
08/29/2014 19:00	0.0	0	0	0	0	0
08/29/2014 20:00	0.0	0	0	0	0	0
08/29/2014 21:00	0.0	0	0	0	0	0
08/29/2014 22:00	0.0	0	0	0	0	0
08/29/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/30/2014 00:00	0.0	0	0	0	0	0
08/30/2014 01:00	0.0	0	0	0	0	0
08/30/2014 02:00	0.0	0	0	0	0	0
08/30/2014 03:00	0.0	0	0	0	0	0
08/30/2014 04:00	0.0	0	0	0	0	0
08/30/2014 05:00	0.0	0	0	0	0	0
08/30/2014 06:00	0.0	0	0	0	0	0
08/30/2014 07:00	0.0	0	0	0	0	0
08/30/2014 08:00	0.0	0	0	0	0	0
08/30/2014 09:00	0.0	0	0	0	0	0
08/30/2014 10:00	0.0	0	0	0	0	0
08/30/2014 11:00	0.0	0	0	0	0	0
08/30/2014 12:00	0.0	0	0	0	0	0
08/30/2014 13:00	0.0	0	0	0	0	0
08/30/2014 14:00	0.0	0	0	0	0	0
08/30/2014 15:00	0.0	0	0	0	0	0
08/30/2014 16:00	0.0	0	0	0	0	0
08/30/2014 17:00	0.0	0	0	0	0	0
08/30/2014 18:00	0.0	0	0	0	0	0
08/30/2014 19:00	0.0	0	0	0	0	0
08/30/2014 20:00	0.0	0	0	0	0	0
08/30/2014 21:00	0.0	0	0	0	0	0
08/30/2014 22:00	0.0	0	0	0	0	0
08/30/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
08/31/2014 00:00	0.0	0	0	0	0	0
08/31/2014 01:00	0.0	0	0	0	0	0
08/31/2014 02:00	0.0	0	0	0	0	0
08/31/2014 03:00	0.0	0	0	0	0	0
08/31/2014 04:00	0.0	0	0	0	0	0
08/31/2014 05:00	0.0	0	0	0	0	0
08/31/2014 06:00	0.0	0	0	0	0	0
08/31/2014 07:00	0.0	0	0	0	0	0
08/31/2014 08:00	0.0	0	0	0	0	0
08/31/2014 09:00	0.0	0	0	0	0	0
08/31/2014 10:00	0.0	0	0	0	0	0
08/31/2014 11:00	0.0	0	0	0	0	0
08/31/2014 12:00	0.0	0	0	0	0	0
08/31/2014 13:00	0.0	0	0	0	0	0
08/31/2014 14:00	0.0	0	0	0	0	0
08/31/2014 15:00	0.0	0	0	0	0	0
08/31/2014 16:00	0.0	0	0	0	0	0
08/31/2014 17:00	0.0	0	0	0	0	0
08/31/2014 18:00	0.0	0	0	0	0	0
08/31/2014 19:00	0.0	0	0	0	0	0
08/31/2014 20:00	0.0	0	0	0	0	0
08/31/2014 21:00	0.0	0	0	0	0	0
08/31/2014 22:00	0.0	0	0	0	0	0
08/31/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/01/2014 00:00	0.0	0	0	0	0	0
09/01/2014 01:00	0.0	0	0	0	0	0
09/01/2014 02:00	0.0	0	0	0	0	0
09/01/2014 03:00	0.0	0	0	0	0	0
09/01/2014 04:00	0.0	0	0	0	0	0
09/01/2014 05:00	0.0	0	0	0	0	0
09/01/2014 06:00	0.0	0	0	0	0	0
09/01/2014 07:00	0.0	0	0	0	0	0
09/01/2014 08:00	0.0	0	0	0	0	0
09/01/2014 09:00	0.0	0	0	0	0	0
09/01/2014 10:00	0.0	0	0	0	0	0
09/01/2014 11:00	0.0	0	0	0	0	0
09/01/2014 12:00	0.0	0	0	0	0	0
09/01/2014 13:00	0.0	0	0	0	0	0
09/01/2014 14:00	0.0	0	0	0	0	0
09/01/2014 15:00	0.0	0	0	0	0	0
09/01/2014 16:00	0.0	0	0	0	0	0
09/01/2014 17:00	0.0	0	0	0	0	0
09/01/2014 18:00	0.0	0	0	0	0	0
09/01/2014 19:00	0.0	0	0	0	0	0
09/01/2014 20:00	0.0	0	0	0	0	0
09/01/2014 21:00	0.0	0	0	0	0	0
09/01/2014 22:00	0.0	0	0	0	0	0
09/01/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/02/2014 00:00	0.0	0	0	0	0	0
09/02/2014 01:00	0.0	0	0	0	0	0
09/02/2014 02:00	0.0	0	0	0	0	0
09/02/2014 03:00	0.0	0	0	0	0	0
09/02/2014 04:00	0.0	0	0	0	0	0
09/02/2014 05:00	0.0	0	0	0	0	0
09/02/2014 06:00	0.0	0	0	0	0	0
09/02/2014 07:00	0.0	0	0	0	0	0
09/02/2014 08:00	0.0	0	0	0	0	0
09/02/2014 09:00	0.0	0	0	0	0	0
09/02/2014 10:00	0.0	0	0	0	0	0
09/02/2014 11:00	0.0	0	0	0	0	0
09/02/2014 12:00	0.0	0	0	0	0	0
09/02/2014 13:00	0.0	0	0	0	0	0
09/02/2014 14:00	0.0	0	0	0	0	0
09/02/2014 15:00	0.0	0	0	0	0	0
09/02/2014 16:00	0.0	0	0	0	0	0
09/02/2014 17:00	0.0	0	0	0	0	0
09/02/2014 18:00	0.0	0	0	0	0	0
09/02/2014 19:00	0.0	0	0	0	0	0
09/02/2014 20:00	0.0	0	0	0	0	0
09/02/2014 21:00	0.0	0	0	0	0	0
09/02/2014 22:00	0.0	0	0	0	0	0
09/02/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/03/2014 00:00	0.0	0	0	0	0	0
09/03/2014 01:00	0.0	0	0	0	0	0
09/03/2014 02:00	0.0	0	0	0	0	0
09/03/2014 03:00	0.0	0	0	0	0	0
09/03/2014 04:00	0.0	0	0	0	0	0
09/03/2014 05:00	0.0	0	0	0	0	0
09/03/2014 06:00	0.0	0	0	0	0	0
09/03/2014 07:00	0.0	0	0	0	0	0
09/03/2014 08:00	0.0	0	0	0	0	0
09/03/2014 09:00	0.0	0	0	0	0	0
09/03/2014 10:00	0.0	0	0	0	0	0
09/03/2014 11:00	0.0	0	0	0	0	0
09/03/2014 12:00	0.0	0	0	0	0	0
09/03/2014 13:00	0.0	0	0	0	0	0
09/03/2014 14:00	0.0	0	0	0	0	0
09/03/2014 15:00	0.0	0	0	0	0	0
09/03/2014 16:00	0.0	0	0	0	0	0
09/03/2014 17:00	0.0	0	0	0	0	0
09/03/2014 18:00	0.0	0	0	0	0	0
09/03/2014 19:00	0.0	0	0	0	0	0
09/03/2014 20:00	0.0	0	0	0	0	0
09/03/2014 21:00	0.0	0	0	0	0	0
09/03/2014 22:00	0.0	0	0	0	0	0
09/03/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/04/2014 00:00	0.0	0	0	0	0	0
09/04/2014 01:00	0.0	0	0	0	0	0
09/04/2014 02:00	0.0	0	0	0	0	0
09/04/2014 03:00	0.0	0	0	0	0	0
09/04/2014 04:00	0.0	0	0	0	0	0
09/04/2014 05:00	0.0	0	0	0	0	0
09/04/2014 06:00	0.0	0	0	0	0	0
09/04/2014 07:00	0.0	0	0	0	0	0
09/04/2014 08:00	0.0	0	0	0	0	0
09/04/2014 09:00	0.0	0	0	0	0	0
09/04/2014 10:00	0.0	0	0	0	0	0
09/04/2014 11:00	0.0	0	0	0	0	0
09/04/2014 12:00	0.0	0	0	0	0	0
09/04/2014 13:00	0.0	0	0	0	0	0
09/04/2014 14:00	0.0	0	0	0	0	0
09/04/2014 15:00	0.0	0	0	0	0	0
09/04/2014 16:00	0.0	0	0	0	0	0
09/04/2014 17:00	0.0	0	0	0	0	0
09/04/2014 18:00	0.0	0	0	0	0	0
09/04/2014 19:00	0.0	0	0	0	0	0
09/04/2014 20:00	0.0	0	0	0	0	0
09/04/2014 21:00	0.0	0	0	0	0	0
09/04/2014 22:00	0.0	0	0	0	0	0
09/04/2014 23:00	0.0	0	0	0	0	0
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	0 #
Minimum:	0.0	0	0	0	0	0
Maximum:	0.0	0	0	0	0	0
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/05/2014 00:00	1,341.6	1	0	0	0	0
09/05/2014 01:00	5,336.4	1	0	0	0	0
09/05/2014 02:00	5,893.7	1	0	0	0	0
09/05/2014 03:00	5,921.8	1	0	0	0	0
09/05/2014 04:00	6,086.6	1	0	0	0	0
09/05/2014 05:00	0.0	0	0	0	0	1
09/05/2014 06:00	0.0	0	0	0	0	1
09/05/2014 07:00	0.0	0	0	0	0	1
09/05/2014 08:00	0.0	0	0	0	0	1
09/05/2014 09:00	0.0	0	0	0	0	1
09/05/2014 10:00	0.0	0	0	0	0	1
09/05/2014 11:00	0.0	0	0	0	0	1
09/05/2014 12:00	0.0	0	0	0	0	1
09/05/2014 13:00	0.0	0	0	0	0	1
09/05/2014 14:00	0.0	0	0	0	0	1
09/05/2014 15:00	0.0	0	0	0	0	1
09/05/2014 16:00	0.0	0	0	0	0	1
09/05/2014 17:00	0.0	0	0	0	0	1
09/05/2014 18:00	0.0	0	0	0	0	1
09/05/2014 19:00	0.0	0	0	0	0	1
09/05/2014 20:00	0.0	0	0	0	0	1
09/05/2014 21:00	0.0	0	0	0	0	1
09/05/2014 22:00	0.0	0	0	0	0	1
09/05/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	24,580.1 #	5 #	0 #	0 #	0 #	19 #
Minimum:	0.0	0	0	0	0	0
Maximum:	6,086.6	1	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/06/2014 00:00	0.0	0	0	0	0	1
09/06/2014 01:00	0.0	0	0	0	0	1
09/06/2014 02:00	0.0	0	0	0	0	1
09/06/2014 03:00	0.0	0	0	0	0	1
09/06/2014 04:00	0.0	0	0	0	0	1
09/06/2014 05:00	0.0	0	0	0	0	1
09/06/2014 06:00	0.0	0	0	0	0	1
09/06/2014 07:00	0.0	0	0	0	0	1
09/06/2014 08:00	0.0	0	0	0	0	1
09/06/2014 09:00	0.0	0	0	0	0	1
09/06/2014 10:00	0.0	0	0	0	0	1
09/06/2014 11:00	0.0	0	0	0	0	1
09/06/2014 12:00	0.0	0	0	0	0	1
09/06/2014 13:00	0.0	0	0	0	0	1
09/06/2014 14:00	0.0	0	0	0	0	1
09/06/2014 15:00	0.0	0	0	0	0	1
09/06/2014 16:00	0.0	0	0	0	0	1
09/06/2014 17:00	0.0	0	0	0	0	1
09/06/2014 18:00	0.0	0	0	0	0	1
09/06/2014 19:00	0.0	0	0	0	0	1
09/06/2014 20:00	0.0	0	0	0	0	1
09/06/2014 21:00	0.0	0	0	0	0	1
09/06/2014 22:00	0.0	0	0	0	0	1
09/06/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/07/2014 00:00	0.0	0	0	0	0	1
09/07/2014 01:00	0.0	0	0	0	0	1
09/07/2014 02:00	0.0	0	0	0	0	1
09/07/2014 03:00	0.0	0	0	0	0	1
09/07/2014 04:00	0.0	0	0	0	0	1
09/07/2014 05:00	0.0	0	0	0	0	1
09/07/2014 06:00	0.0	0	0	0	0	1
09/07/2014 07:00	0.0	0	0	0	0	1
09/07/2014 08:00	0.0	0	0	0	0	1
09/07/2014 09:00	0.0	0	0	0	0	1
09/07/2014 10:00	0.0	0	0	0	0	1
09/07/2014 11:00	0.0	0	0	0	0	1
09/07/2014 12:00	0.0	0	0	0	0	1
09/07/2014 13:00	0.0	0	0	0	0	1
09/07/2014 14:00	0.0	0	0	0	0	1
09/07/2014 15:00	0.0	0	0	0	0	1
09/07/2014 16:00	0.0	0	0	0	0	1
09/07/2014 17:00	0.0	0	0	0	0	1
09/07/2014 18:00	0.0	0	0	0	0	1
09/07/2014 19:00	0.0	0	0	0	0	1
09/07/2014 20:00	0.0	0	0	0	0	1
09/07/2014 21:00	0.0	0	0	0	0	1
09/07/2014 22:00	0.0	0	0	0	0	1
09/07/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/08/2014 00:00	0.0	0	0	0	0	1
09/08/2014 01:00	0.0	0	0	0	0	1
09/08/2014 02:00	0.0	0	0	0	0	1
09/08/2014 03:00	0.0	0	0	0	0	1
09/08/2014 04:00	0.0	0	0	0	0	1
09/08/2014 05:00	0.0	0	0	0	0	1
09/08/2014 06:00	0.0	0	0	0	0	1
09/08/2014 07:00	0.0	0	0	0	0	1
09/08/2014 08:00	0.0	0	0	0	0	1
09/08/2014 09:00	0.0	0	0	0	0	1
09/08/2014 10:00	0.0	0	0	0	0	1
09/08/2014 11:00	0.0	0	0	0	0	1
09/08/2014 12:00	0.0	0	0	0	0	1
09/08/2014 13:00	0.0	0	0	0	0	1
09/08/2014 14:00	0.0	0	0	0	0	1
09/08/2014 15:00	0.0	0	0	0	0	1
09/08/2014 16:00	0.0	0	0	0	0	1
09/08/2014 17:00	0.0	0	0	0	0	1
09/08/2014 18:00	0.0	0	0	0	0	1
09/08/2014 19:00	0.0	0	0	0	0	1
09/08/2014 20:00	0.0	0	0	0	0	1
09/08/2014 21:00	0.0	0	0	0	0	1
09/08/2014 22:00	0.0	0	0	0	0	1
09/08/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/09/2014 00:00	0.0	0	0	0	0	1
09/09/2014 01:00	0.0	0	0	0	0	1
09/09/2014 02:00	0.0	0	0	0	0	1
09/09/2014 03:00	0.0	0	0	0	0	1
09/09/2014 04:00	0.0	0	0	0	0	1
09/09/2014 05:00	0.0	0	0	0	0	1
09/09/2014 06:00	0.0	0	0	0	0	1
09/09/2014 07:00	0.0	0	0	0	0	1
09/09/2014 08:00	0.0	0	0	0	0	1
09/09/2014 09:00	0.0	0	0	0	0	1
09/09/2014 10:00	0.0	0	0	0	0	1
09/09/2014 11:00	0.0	0	0	0	0	1
09/09/2014 12:00	0.0	0	0	0	0	1
09/09/2014 13:00	0.0	0	0	0	0	1
09/09/2014 14:00	0.0	0	0	0	0	1
09/09/2014 15:00	0.0	0	0	0	0	1
09/09/2014 16:00	0.0	0	0	0	0	1
09/09/2014 17:00	0.0	0	0	0	0	1
09/09/2014 18:00	0.0	0	0	0	0	1
09/09/2014 19:00	0.0	0	0	0	0	1
09/09/2014 20:00	0.0	0	0	0	0	1
09/09/2014 21:00	0.0	0	0	0	0	1
09/09/2014 22:00	0.0	0	0	0	0	1
09/09/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/10/2014 00:00	0.0	0	0	0	0	1
09/10/2014 01:00	0.0	0	0	0	0	1
09/10/2014 02:00	0.0	0	0	0	0	1
09/10/2014 03:00	0.0	0	0	0	0	1
09/10/2014 04:00	0.0	0	0	0	0	1
09/10/2014 05:00	0.0	0	0	0	0	1
09/10/2014 06:00	0.0	0	0	0	0	1
09/10/2014 07:00	0.0	0	0	0	0	1
09/10/2014 08:00	0.0	0	0	0	0	1
09/10/2014 09:00	0.0	0	0	0	0	1
09/10/2014 10:00	0.0	0	0	0	0	1
09/10/2014 11:00	0.0	0	0	0	0	1
09/10/2014 12:00	0.0	0	0	0	0	1
09/10/2014 13:00	0.0	0	0	0	0	1
09/10/2014 14:00	0.0	0	0	0	0	1
09/10/2014 15:00	0.0	0	0	0	0	1
09/10/2014 16:00	0.0	0	0	0	0	1
09/10/2014 17:00	0.0	0	0	0	0	1
09/10/2014 18:00	0.0	0	0	0	0	1
09/10/2014 19:00	0.0	0	0	0	0	1
09/10/2014 20:00	0.0	0	0	0	0	1
09/10/2014 21:00	0.0	0	0	0	0	1
09/10/2014 22:00	0.0	0	0	0	0	1
09/10/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/11/2014 00:00	0.0	0	0	0	0	1
09/11/2014 01:00	0.0	0	0	0	0	1
09/11/2014 02:00	0.0	0	0	0	0	1
09/11/2014 03:00	0.0	0	0	0	0	1
09/11/2014 04:00	0.0	0	0	0	0	1
09/11/2014 05:00	0.0	0	0	0	0	1
09/11/2014 06:00	0.0	0	0	0	0	1
09/11/2014 07:00	0.0	0	0	0	0	1
09/11/2014 08:00	0.0	0	0	0	0	1
09/11/2014 09:00	0.0	0	0	0	0	1
09/11/2014 10:00	0.0	0	0	0	0	1
09/11/2014 11:00	0.0	0	0	0	0	1
09/11/2014 12:00	0.0	0	0	0	0	1
09/11/2014 13:00	0.0	0	0	0	0	1
09/11/2014 14:00	0.0	0	0	0	0	1
09/11/2014 15:00	0.0	0	0	0	0	1
09/11/2014 16:00	0.0	0	0	0	0	1
09/11/2014 17:00	0.0	0	0	0	0	1
09/11/2014 18:00	0.0	0	0	0	0	1
09/11/2014 19:00	0.0	0	0	0	0	1
09/11/2014 20:00	0.0	0	0	0	0	1
09/11/2014 21:00	0.0	0	0	0	0	1
09/11/2014 22:00	0.0	0	0	0	0	1
09/11/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/12/2014 00:00	0.0	0	0	0	0	1
09/12/2014 01:00	0.0	0	0	0	0	1
09/12/2014 02:00	0.0	0	0	0	0	1
09/12/2014 03:00	0.0	0	0	0	0	1
09/12/2014 04:00	0.0	0	0	0	0	1
09/12/2014 05:00	0.0	0	0	0	0	1
09/12/2014 06:00	0.0	0	0	0	0	1
09/12/2014 07:00	0.0	0	0	0	0	1
09/12/2014 08:00	0.0	0	0	0	0	1
09/12/2014 09:00	0.0	0	0	0	0	1
09/12/2014 10:00	0.0	0	0	0	0	1
09/12/2014 11:00	0.0	0	0	0	0	1
09/12/2014 12:00	0.0	0	0	0	0	1
09/12/2014 13:00	0.0	0	0	0	0	1
09/12/2014 14:00	0.0	0	0	0	0	1
09/12/2014 15:00	0.0	0	0	0	0	1
09/12/2014 16:00	0.0	0	0	0	0	1
09/12/2014 17:00	0.0	0	0	0	0	1
09/12/2014 18:00	0.0	0	0	0	0	1
09/12/2014 19:00	0.0	0	0	0	0	1
09/12/2014 20:00	0.0	0	0	0	0	1
09/12/2014 21:00	0.0	0	0	0	0	1
09/12/2014 22:00	0.0	0	0	0	0	1
09/12/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/13/2014 00:00	0.0	0	0	0	0	1
09/13/2014 01:00	0.0	0	0	0	0	1
09/13/2014 02:00	0.0	0	0	0	0	1
09/13/2014 03:00	0.0	0	0	0	0	1
09/13/2014 04:00	0.0	0	0	0	0	1
09/13/2014 05:00	0.0	0	0	0	0	1
09/13/2014 06:00	0.0	0	0	0	0	1
09/13/2014 07:00	0.0	0	0	0	0	1
09/13/2014 08:00	0.0	0	0	0	0	1
09/13/2014 09:00	0.0	0	0	0	0	1
09/13/2014 10:00	0.0	0	0	0	0	1
09/13/2014 11:00	0.0	0	0	0	0	1
09/13/2014 12:00	0.0	0	0	0	0	1
09/13/2014 13:00	0.0	0	0	0	0	1
09/13/2014 14:00	0.0	0	0	0	0	1
09/13/2014 15:00	0.0	0	0	0	0	1
09/13/2014 16:00	0.0	0	0	0	0	1
09/13/2014 17:00	0.0	0	0	0	0	1
09/13/2014 18:00	0.0	0	0	0	0	1
09/13/2014 19:00	0.0	0	0	0	0	1
09/13/2014 20:00	0.0	0	0	0	0	1
09/13/2014 21:00	0.0	0	0	0	0	1
09/13/2014 22:00	0.0	0	0	0	0	1
09/13/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/14/2014 00:00	0.0	0	0	0	0	1
09/14/2014 01:00	0.0	0	0	0	0	1
09/14/2014 02:00	0.0	0	0	0	0	1
09/14/2014 03:00	0.0	0	0	0	0	1
09/14/2014 04:00	0.0	0	0	0	0	1
09/14/2014 05:00	0.0	0	0	0	0	1
09/14/2014 06:00	0.0	0	0	0	0	1
09/14/2014 07:00	0.0	0	0	0	0	1
09/14/2014 08:00	0.0	0	0	0	0	1
09/14/2014 09:00	0.0	0	0	0	0	1
09/14/2014 10:00	0.0	0	0	0	0	1
09/14/2014 11:00	0.0	0	0	0	0	1
09/14/2014 12:00	0.0	0	0	0	0	1
09/14/2014 13:00	0.0	0	0	0	0	1
09/14/2014 14:00	0.0	0	0	0	0	1
09/14/2014 15:00	0.0	0	0	0	0	1
09/14/2014 16:00	0.0	0	0	0	0	1
09/14/2014 17:00	0.0	0	0	0	0	1
09/14/2014 18:00	0.0	0	0	0	0	1
09/14/2014 19:00	0.0	0	0	0	0	1
09/14/2014 20:00	0.0	0	0	0	0	1
09/14/2014 21:00	0.0	0	0	0	0	1
09/14/2014 22:00	0.0	0	0	0	0	1
09/14/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/15/2014 00:00	0.0	0	0	0	0	1
09/15/2014 01:00	0.0	0	0	0	0	1
09/15/2014 02:00	0.0	0	0	0	0	1
09/15/2014 03:00	0.0	0	0	0	0	1
09/15/2014 04:00	0.0	0	0	0	0	1
09/15/2014 05:00	0.0	0	0	0	0	1
09/15/2014 06:00	0.0	0	0	0	0	1
09/15/2014 07:00	0.0	0	0	0	0	1
09/15/2014 08:00	0.0	0	0	0	0	1
09/15/2014 09:00	0.0	0	0	0	0	1
09/15/2014 10:00	0.0	0	0	0	0	1
09/15/2014 11:00	0.0	0	0	0	0	1
09/15/2014 12:00	0.0	0	0	0	0	1
09/15/2014 13:00	0.0	0	0	0	0	1
09/15/2014 14:00	0.0	0	0	0	0	1
09/15/2014 15:00	0.0	0	0	0	0	1
09/15/2014 16:00	0.0	0	0	0	0	1
09/15/2014 17:00	0.0	0	0	0	0	1
09/15/2014 18:00	0.0	0	0	0	0	1
09/15/2014 19:00	0.0	0	0	0	0	1
09/15/2014 20:00	0.0	0	0	0	0	1
09/15/2014 21:00	0.0	0	0	0	0	1
09/15/2014 22:00	0.0	0	0	0	0	1
09/15/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/16/2014 00:00	0.0	0	0	0	0	1
09/16/2014 01:00	0.0	0	0	0	0	1
09/16/2014 02:00	0.0	0	0	0	0	1
09/16/2014 03:00	0.0	0	0	0	0	1
09/16/2014 04:00	0.0	0	0	0	0	1
09/16/2014 05:00	0.0	0	0	0	0	1
09/16/2014 06:00	0.0	0	0	0	0	1
09/16/2014 07:00	0.0	0	0	0	0	1
09/16/2014 08:00	0.0	0	0	0	0	1
09/16/2014 09:00	0.0	0	0	0	0	1
09/16/2014 10:00	0.0	0	0	0	0	1
09/16/2014 11:00	0.0	0	0	0	0	1
09/16/2014 12:00	0.0	0	0	0	0	1
09/16/2014 13:00	0.0	0	0	0	0	1
09/16/2014 14:00	0.0	0	0	0	0	1
09/16/2014 15:00	0.0	0	0	0	0	1
09/16/2014 16:00	0.0	0	0	0	0	1
09/16/2014 17:00	0.0	0	0	0	0	1
09/16/2014 18:00	0.0	0	0	0	0	1
09/16/2014 19:00	0.0	0	0	0	0	1
09/16/2014 20:00	0.0	0	0	0	0	1
09/16/2014 21:00	0.0	0	0	0	0	1
09/16/2014 22:00	0.0	0	0	0	0	1
09/16/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/17/2014 00:00	0.0	0	0	0	0	1
09/17/2014 01:00	0.0	0	0	0	0	1
09/17/2014 02:00	0.0	0	0	0	0	1
09/17/2014 03:00	0.0	0	0	0	0	1
09/17/2014 04:00	0.0	0	0	0	0	1
09/17/2014 05:00	0.0	0	0	0	0	1
09/17/2014 06:00	0.0	0	0	0	0	1
09/17/2014 07:00	0.0	0	0	0	0	1
09/17/2014 08:00	0.0	0	0	0	0	1
09/17/2014 09:00	0.0	0	0	0	0	1
09/17/2014 10:00	0.0	0	0	0	0	1
09/17/2014 11:00	0.0	0	0	0	0	1
09/17/2014 12:00	0.0	0	0	0	0	1
09/17/2014 13:00	0.0	0	0	0	0	1
09/17/2014 14:00	0.0	0	0	0	0	1
09/17/2014 15:00	0.0	0	0	0	0	1
09/17/2014 16:00	0.0	0	0	0	0	1
09/17/2014 17:00	0.0	0	0	0	0	1
09/17/2014 18:00	0.0	0	0	0	0	1
09/17/2014 19:00	0.0	0	0	0	0	1
09/17/2014 20:00	0.0	0	0	0	0	1
09/17/2014 21:00	0.0	0	0	0	0	1
09/17/2014 22:00	0.0	0	0	0	0	1
09/17/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/18/2014 00:00	0.0	0	0	0	0	1
09/18/2014 01:00	0.0	0	0	0	0	1
09/18/2014 02:00	0.0	0	0	0	0	1
09/18/2014 03:00	0.0	0	0	0	0	1
09/18/2014 04:00	0.0	0	0	0	0	1
09/18/2014 05:00	0.0	0	0	0	0	1
09/18/2014 06:00	0.0	0	0	0	0	1
09/18/2014 07:00	0.0	0	0	0	0	1
09/18/2014 08:00	0.0	0	0	0	0	1
09/18/2014 09:00	0.0	0	0	0	0	1
09/18/2014 10:00	0.0	0	0	0	0	1
09/18/2014 11:00	0.0	0	0	0	0	1
09/18/2014 12:00	0.0	0	0	0	0	1
09/18/2014 13:00	0.0	0	0	0	0	1
09/18/2014 14:00	0.0	0	0	0	0	1
09/18/2014 15:00	0.0	0	0	0	0	1
09/18/2014 16:00	0.0	0	0	0	0	1
09/18/2014 17:00	0.0	0	0	0	0	1
09/18/2014 18:00	0.0	0	0	0	0	1
09/18/2014 19:00	0.0	0	0	0	0	1
09/18/2014 20:00	0.0	0	0	0	0	1
09/18/2014 21:00	0.0	0	0	0	0	1
09/18/2014 22:00	0.0	0	0	0	0	1
09/18/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/19/2014 00:00	0.0	0	0	0	0	1
09/19/2014 01:00	0.0	0	0	0	0	1
09/19/2014 02:00	0.0	0	0	0	0	1
09/19/2014 03:00	0.0	0	0	0	0	1
09/19/2014 04:00	0.0	0	0	0	0	1
09/19/2014 05:00	0.0	0	0	0	0	1
09/19/2014 06:00	0.0	0	0	0	0	1
09/19/2014 07:00	0.0	0	0	0	0	1
09/19/2014 08:00	0.0	0	0	0	0	1
09/19/2014 09:00	0.0	0	0	0	0	1
09/19/2014 10:00	0.0	0	0	0	0	1
09/19/2014 11:00	0.0	0	0	0	0	1
09/19/2014 12:00	0.0	0	0	0	0	1
09/19/2014 13:00	0.0	0	0	0	0	1
09/19/2014 14:00	0.0	0	0	0	0	1
09/19/2014 15:00	0.0	0	0	0	0	1
09/19/2014 16:00	0.0	0	0	0	0	1
09/19/2014 17:00	0.0	0	0	0	0	1
09/19/2014 18:00	0.0	0	0	0	0	1
09/19/2014 19:00	0.0	0	0	0	0	1
09/19/2014 20:00	0.0	0	0	0	0	1
09/19/2014 21:00	0.0	0	0	0	0	1
09/19/2014 22:00	0.0	0	0	0	0	1
09/19/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/20/2014 00:00	0.0	0	0	0	0	1
09/20/2014 01:00	0.0	0	0	0	0	1
09/20/2014 02:00	0.0	0	0	0	0	1
09/20/2014 03:00	0.0	0	0	0	0	1
09/20/2014 04:00	0.0	0	0	0	0	1
09/20/2014 05:00	0.0	0	0	0	0	1
09/20/2014 06:00	0.0	0	0	0	0	1
09/20/2014 07:00	0.0	0	0	0	0	1
09/20/2014 08:00	0.0	0	0	0	0	1
09/20/2014 09:00	0.0	0	0	0	0	1
09/20/2014 10:00	0.0	0	0	0	0	1
09/20/2014 11:00	0.0	0	0	0	0	1
09/20/2014 12:00	0.0	0	0	0	0	1
09/20/2014 13:00	0.0	0	0	0	0	1
09/20/2014 14:00	0.0	0	0	0	0	1
09/20/2014 15:00	0.0	0	0	0	0	1
09/20/2014 16:00	0.0	0	0	0	0	1
09/20/2014 17:00	0.0	0	0	0	0	1
09/20/2014 18:00	0.0	0	0	0	0	1
09/20/2014 19:00	0.0	0	0	0	0	1
09/20/2014 20:00	0.0	0	0	0	0	1
09/20/2014 21:00	0.0	0	0	0	0	1
09/20/2014 22:00	0.0	0	0	0	0	1
09/20/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/21/2014 00:00	0.0	0	0	0	0	1
09/21/2014 01:00	0.0	0	0	0	0	1
09/21/2014 02:00	0.0	0	0	0	0	1
09/21/2014 03:00	0.0	0	0	0	0	1
09/21/2014 04:00	0.0	0	0	0	0	1
09/21/2014 05:00	0.0	0	0	0	0	1
09/21/2014 06:00	0.0	0	0	0	0	1
09/21/2014 07:00	0.0	0	0	0	0	1
09/21/2014 08:00	0.0	0	0	0	0	1
09/21/2014 09:00	0.0	0	0	0	0	1
09/21/2014 10:00	0.0	0	0	0	0	1
09/21/2014 11:00	0.0	0	0	0	0	1
09/21/2014 12:00	0.0	0	0	0	0	1
09/21/2014 13:00	0.0	0	0	0	0	1
09/21/2014 14:00	0.0	0	0	0	0	1
09/21/2014 15:00	0.0	0	0	0	0	1
09/21/2014 16:00	0.0	0	0	0	0	1
09/21/2014 17:00	0.0	0	0	0	0	1
09/21/2014 18:00	0.0	0	0	0	0	1
09/21/2014 19:00	0.0	0	0	0	0	1
09/21/2014 20:00	0.0	0	0	0	0	1
09/21/2014 21:00	0.0	0	0	0	0	1
09/21/2014 22:00	0.0	0	0	0	0	1
09/21/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/22/2014 00:00	0.0	0	0	0	0	1
09/22/2014 01:00	0.0	0	0	0	0	1
09/22/2014 02:00	0.0	0	0	0	0	1
09/22/2014 03:00	0.0	0	0	0	0	1
09/22/2014 04:00	0.0	0	0	0	0	1
09/22/2014 05:00	0.0	0	0	0	0	1
09/22/2014 06:00	0.0	0	0	0	0	1
09/22/2014 07:00	0.0	0	0	0	0	1
09/22/2014 08:00	0.0	0	0	0	0	1
09/22/2014 09:00	0.0	0	0	0	0	1
09/22/2014 10:00	0.0	0	0	0	0	1
09/22/2014 11:00	0.0	0	0	0	0	1
09/22/2014 12:00	0.0	0	0	0	0	1
09/22/2014 13:00	0.0	0	0	0	0	1
09/22/2014 14:00	0.0	0	0	0	0	1
09/22/2014 15:00	0.0	0	0	0	0	1
09/22/2014 16:00	0.0	0	0	0	0	1
09/22/2014 17:00	0.0	0	0	0	0	1
09/22/2014 18:00	0.0	0	0	0	0	1
09/22/2014 19:00	0.0	0	0	0	0	1
09/22/2014 20:00	0.0	0	0	0	0	1
09/22/2014 21:00	0.0	0	0	0	0	1
09/22/2014 22:00	0.0	0	0	0	0	1
09/22/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/23/2014 00:00	0.0	0	0	0	0	1
09/23/2014 01:00	0.0	0	0	0	0	1
09/23/2014 02:00	0.0	0	0	0	0	1
09/23/2014 03:00	0.0	0	0	0	0	1
09/23/2014 04:00	0.0	0	0	0	0	1
09/23/2014 05:00	0.0	0	0	0	0	1
09/23/2014 06:00	0.0	0	0	0	0	1
09/23/2014 07:00	0.0	0	0	0	0	1
09/23/2014 08:00	0.0	0	0	0	0	1
09/23/2014 09:00	0.0	0	0	0	0	1
09/23/2014 10:00	0.0	0	0	0	0	1
09/23/2014 11:00	0.0	0	0	0	0	1
09/23/2014 12:00	0.0	0	0	0	0	1
09/23/2014 13:00	0.0	0	0	0	0	1
09/23/2014 14:00	0.0	0	0	0	0	1
09/23/2014 15:00	0.0	0	0	0	0	1
09/23/2014 16:00	0.0	0	0	0	0	1
09/23/2014 17:00	0.0	0	0	0	0	1
09/23/2014 18:00	0.0	0	0	0	0	1
09/23/2014 19:00	0.0	0	0	0	0	1
09/23/2014 20:00	0.0	0	0	0	0	1
09/23/2014 21:00	0.0	0	0	0	0	1
09/23/2014 22:00	0.0	0	0	0	0	1
09/23/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/24/2014 00:00	0.0	0	0	0	0	1
09/24/2014 01:00	0.0	0	0	0	0	1
09/24/2014 02:00	0.0	0	0	0	0	1
09/24/2014 03:00	0.0	0	0	0	0	1
09/24/2014 04:00	0.0	0	0	0	0	1
09/24/2014 05:00	0.0	0	0	0	0	1
09/24/2014 06:00	0.0	0	0	0	0	1
09/24/2014 07:00	0.0	0	0	0	0	1
09/24/2014 08:00	0.0	0	0	0	0	1
09/24/2014 09:00	0.0	0	0	0	0	1
09/24/2014 10:00	0.0	0	0	0	0	1
09/24/2014 11:00	0.0	0	0	0	0	1
09/24/2014 12:00	0.0	0	0	0	0	1
09/24/2014 13:00	0.0	0	0	0	0	1
09/24/2014 14:00	0.0	0	0	0	0	1
09/24/2014 15:00	0.0	0	0	0	0	1
09/24/2014 16:00	0.0	0	0	0	0	1
09/24/2014 17:00	0.0	0	0	0	0	1
09/24/2014 18:00	0.0	0	0	0	0	1
09/24/2014 19:00	0.0	0	0	0	0	1
09/24/2014 20:00	0.0	0	0	0	0	1
09/24/2014 21:00	0.0	0	0	0	0	1
09/24/2014 22:00	0.0	0	0	0	0	1
09/24/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/25/2014 00:00	0.0	0	0	0	0	1
09/25/2014 01:00	0.0	0	0	0	0	1
09/25/2014 02:00	0.0	0	0	0	0	1
09/25/2014 03:00	0.0	0	0	0	0	1
09/25/2014 04:00	0.0	0	0	0	0	1
09/25/2014 05:00	0.0	0	0	0	0	1
09/25/2014 06:00	0.0	0	0	0	0	1
09/25/2014 07:00	0.0	0	0	0	0	1
09/25/2014 08:00	0.0	0	0	0	0	1
09/25/2014 09:00	0.0	0	0	0	0	1
09/25/2014 10:00	0.0	0	0	0	0	1
09/25/2014 11:00	0.0	0	0	0	0	1
09/25/2014 12:00	0.0	0	0	0	0	1
09/25/2014 13:00	0.0	0	0	0	0	1
09/25/2014 14:00	0.0	0	0	0	0	1
09/25/2014 15:00	0.0	0	0	0	0	1
09/25/2014 16:00	0.0	0	0	0	0	1
09/25/2014 17:00	0.0	0	0	0	0	1
09/25/2014 18:00	0.0	0	0	0	0	1
09/25/2014 19:00	0.0	0	0	0	0	1
09/25/2014 20:00	0.0	0	0	0	0	1
09/25/2014 21:00	0.0	0	0	0	0	1
09/25/2014 22:00	0.0	0	0	0	0	1
09/25/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/26/2014 00:00	0.0	0	0	0	0	1
09/26/2014 01:00	0.0	0	0	0	0	1
09/26/2014 02:00	0.0	0	0	0	0	1
09/26/2014 03:00	0.0	0	0	0	0	1
09/26/2014 04:00	0.0	0	0	0	0	1
09/26/2014 05:00	0.0	0	0	0	0	1
09/26/2014 06:00	0.0	0	0	0	0	1
09/26/2014 07:00	0.0	0	0	0	0	1
09/26/2014 08:00	0.0	0	0	0	0	1
09/26/2014 09:00	0.0	0	0	0	0	1
09/26/2014 10:00	0.0	0	0	0	0	1
09/26/2014 11:00	0.0	0	0	0	0	1
09/26/2014 12:00	0.0	0	0	0	0	1
09/26/2014 13:00	0.0	0	0	0	0	1
09/26/2014 14:00	0.0	0	0	0	0	1
09/26/2014 15:00	0.0	0	0	0	0	1
09/26/2014 16:00	0.0	0	0	0	0	1
09/26/2014 17:00	0.0	0	0	0	0	1
09/26/2014 18:00	0.0	0	0	0	0	1
09/26/2014 19:00	0.0	0	0	0	0	1
09/26/2014 20:00	0.0	0	0	0	0	1
09/26/2014 21:00	0.0	0	0	0	0	1
09/26/2014 22:00	0.0	0	0	0	0	1
09/26/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/27/2014 00:00	0.0	0	0	0	0	1
09/27/2014 01:00	0.0	0	0	0	0	1
09/27/2014 02:00	0.0	0	0	0	0	1
09/27/2014 03:00	0.0	0	0	0	0	1
09/27/2014 04:00	0.0	0	0	0	0	1
09/27/2014 05:00	0.0	0	0	0	0	1
09/27/2014 06:00	0.0	0	0	0	0	1
09/27/2014 07:00	0.0	0	0	0	0	1
09/27/2014 08:00	0.0	0	0	0	0	1
09/27/2014 09:00	0.0	0	0	0	0	1
09/27/2014 10:00	0.0	0	0	0	0	1
09/27/2014 11:00	0.0	0	0	0	0	1
09/27/2014 12:00	0.0	0	0	0	0	1
09/27/2014 13:00	0.0	0	0	0	0	1
09/27/2014 14:00	0.0	0	0	0	0	1
09/27/2014 15:00	0.0	0	0	0	0	1
09/27/2014 16:00	0.0	0	0	0	0	1
09/27/2014 17:00	0.0	0	0	0	0	1
09/27/2014 18:00	0.0	0	0	0	0	1
09/27/2014 19:00	0.0	0	0	0	0	1
09/27/2014 20:00	0.0	0	0	0	0	1
09/27/2014 21:00	0.0	0	0	0	0	1
09/27/2014 22:00	0.0	0	0	0	0	1
09/27/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/28/2014 00:00	0.0	0	0	0	0	1
09/28/2014 01:00	0.0	0	0	0	0	1
09/28/2014 02:00	0.0	0	0	0	0	1
09/28/2014 03:00	0.0	0	0	0	0	1
09/28/2014 04:00	0.0	0	0	0	0	1
09/28/2014 05:00	0.0	0	0	0	0	1
09/28/2014 06:00	0.0	0	0	0	0	1
09/28/2014 07:00	0.0	0	0	0	0	1
09/28/2014 08:00	0.0	0	0	0	0	1
09/28/2014 09:00	0.0	0	0	0	0	1
09/28/2014 10:00	0.0	0	0	0	0	1
09/28/2014 11:00	0.0	0	0	0	0	1
09/28/2014 12:00	0.0	0	0	0	0	1
09/28/2014 13:00	0.0	0	0	0	0	1
09/28/2014 14:00	0.0	0	0	0	0	1
09/28/2014 15:00	0.0	0	0	0	0	1
09/28/2014 16:00	0.0	0	0	0	0	1
09/28/2014 17:00	0.0	0	0	0	0	1
09/28/2014 18:00	0.0	0	0	0	0	1
09/28/2014 19:00	0.0	0	0	0	0	1
09/28/2014 20:00	0.0	0	0	0	0	1
09/28/2014 21:00	0.0	0	0	0	0	1
09/28/2014 22:00	0.0	0	0	0	0	1
09/28/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/29/2014 00:00	0.0	0	0	0	0	1
09/29/2014 01:00	0.0	0	0	0	0	1
09/29/2014 02:00	0.0	0	0	0	0	1
09/29/2014 03:00	0.0	0	0	0	0	1
09/29/2014 04:00	0.0	0	0	0	0	1
09/29/2014 05:00	0.0	0	0	0	0	1
09/29/2014 06:00	0.0	0	0	0	0	1
09/29/2014 07:00	0.0	0	0	0	0	1
09/29/2014 08:00	0.0	0	0	0	0	1
09/29/2014 09:00	0.0	0	0	0	0	1
09/29/2014 10:00	0.0	0	0	0	0	1
09/29/2014 11:00	0.0	0	0	0	0	1
09/29/2014 12:00	0.0	0	0	0	0	1
09/29/2014 13:00	0.0	0	0	0	0	1
09/29/2014 14:00	0.0	0	0	0	0	1
09/29/2014 15:00	0.0	0	0	0	0	1
09/29/2014 16:00	0.0	0	0	0	0	1
09/29/2014 17:00	0.0	0	0	0	0	1
09/29/2014 18:00	0.0	0	0	0	0	1
09/29/2014 19:00	0.0	0	0	0	0	1
09/29/2014 20:00	0.0	0	0	0	0	1
09/29/2014 21:00	0.0	0	0	0	0	1
09/29/2014 22:00	0.0	0	0	0	0	1
09/29/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

Daily Summary Report

CT2 Event GasFlowTotal 100scf

From: 07/01/2014 00:00 **To:** 09/30/2014 23:59 **Facility Name:** COLUSA GENERATING STATION

Generated: 10/22/2014 13:21 **Location:** Maxwell, CA

Red = Invalid or Excluded Data | Green = Edited Status | Blue = Edited Value | * = Excess Emission

	Unit CT2 GasFlowTot, Event, 100scf 1 Hour(s)	Unit CT2 Startup, Cold, TF 1 Hour(s)	Unit CT2 Startup, Warm, TF 1 Hour(s)	Unit CT2 Startup, Hot, TF 1 Hour(s)	Unit CT2 Shutdown, TF 1 Hour(s)	Unit CT2 NormalOp, TF 1 Hour(s)
09/30/2014 00:00	0.0	0	0	0	0	1
09/30/2014 01:00	0.0	0	0	0	0	1
09/30/2014 02:00	0.0	0	0	0	0	1
09/30/2014 03:00	0.0	0	0	0	0	1
09/30/2014 04:00	0.0	0	0	0	0	1
09/30/2014 05:00	0.0	0	0	0	0	1
09/30/2014 06:00	0.0	0	0	0	0	1
09/30/2014 07:00	0.0	0	0	0	0	1
09/30/2014 08:00	0.0	0	0	0	0	1
09/30/2014 09:00	0.0	0	0	0	0	1
09/30/2014 10:00	0.0	0	0	0	0	1
09/30/2014 11:00	0.0	0	0	0	0	1
09/30/2014 12:00	0.0	0	0	0	0	1
09/30/2014 13:00	0.0	0	0	0	0	1
09/30/2014 14:00	0.0	0	0	0	0	1
09/30/2014 15:00	0.0	0	0	0	0	1
09/30/2014 16:00	0.0	0	0	0	0	1
09/30/2014 17:00	0.0	0	0	0	0	1
09/30/2014 18:00	0.0	0	0	0	0	1
09/30/2014 19:00	0.0	0	0	0	0	1
09/30/2014 20:00	0.0	0	0	0	0	1
09/30/2014 21:00	0.0	0	0	0	0	1
09/30/2014 22:00	0.0	0	0	0	0	1
09/30/2014 23:00	0.0	0	0	0	0	1
Average/Sum#:	0.0 #	0 #	0 #	0 #	0 #	24 #
Minimum:	0.0	0	0	0	0	1
Maximum:	0.0	0	0	0	0	1
%SI	0.0	0	0	0	0	0

ATTACHMENT 13
Water Bath Heater Operations (AQ-17)

The Natural Gas Fired Water Bath Heater did not operate in the 3rd Quarter of 2014.

ATTACHMENT 14
Toxics (AQ-29)

TOXICS AND GHG TRACKING AND COMPLIANCE PLAN

PG&E Colusa Generating Station

Reporting/Tracking Year: 2014

Combustion Turbines/HRSGs

	CAS #	Emissions Factors lb/mmbtu	Emissions Factors lb/mmscf	EF Source	Source Test Results lb/hr	Max Hourly Emissions lbs	Annual Emissions lbs	Annual Emissions tons
Ammonia Unit #1	7664417	0.00E+00	0.00E+00	Test 11/10	4.06	4.06	12119.10	6.060
Formaldehyde Unit #1	50000	7.00E-05	9.19E-02	Test	0.029	0.029	86.57	0.043
Ammonia Unit #2	7664417	0.00E+00	0.00E+00	Test 11/10	4.37	4.37	13018.23	6.509
Formaldehyde Unit #2	50000	7.00E-05	9.19E-02	Test	0.014	0.014	41.71	0.021
1-3 Butadiene	106990	1.24E-07	1.27E-04	CATEF	0	0.001	1.33	0.001
Acetaldehyde	75070	1.34E-04	1.37E-01	CATEF	0	0.656	1438.62	0.719
Acrolein	107028	1.85E-05	1.89E-02	CATEF	0	0.091	198.47	0.099
Benzene	71432	1.30E-05	1.33E-02	CATEF	0	0.064	139.66	0.070
Ethylbenzene	100414	1.75E-05	1.79E-02	CATEF	0	0.086	187.97	0.094
Hexane	110543	2.53E-04	2.59E-01	CATEF	0	1.240	2719.73	1.360
Propylene	115071	7.53E-04	7.71E-01	CATEF	0	3.692	8096.18	4.048
Propylene Oxide	75569	4.67E-05	4.78E-02	CATEF	0	0.229	501.94	0.251
Toluene	108883	6.93E-05	7.10E-02	CATEF	0	0.340	745.56	0.373
Xylenes	1330207	2.55E-05	2.61E-02	CATEF	0	0.125	274.07	0.137
Naphthalene	91203	1.62E-06	1.66E-03	CATEF	0	0.008	17.43	0.009
Total PAH w/o Naph	1151	1.30E-07	1.31E-04	CATEF	0	0.001	1.38	0.001

GHG	kg/mmbtu	Frac Ox.	lbs/mmbtu	lb/mmscf				
CO2	53.06	1	1.17E+02	1.20E+05	CCAR	0	573603.7	1.258E+09	6.289E+05
CH4	0.003901	na	8.60E-03	8.81E+00	CCAR	0	42.172	9.248E+04	46.238
N2O	0.001361	na	3.00E-03	3.07E+00	CCAR	0	14.713	3.226E+04	16.132
CO2e	634888.0	tons/yr		*CO2e*	*575862.1*	*metric tons/yr*			

Total Turbines/HRSGs

Fuel Use Rate Data			
NG HHV	1024	btu/scf	
Fuel Meter Data			
Max Hourly Fuel Use	4.7887	mmscf	(for both units)
Annual Fuel Use	10500.88	mmscf	(for both units)
Calculated Heat Rate Data			
Max Hourly Heat Rate	4903.60	mmbtu	(for both units)
Annual Heat Rate	10752901.1	mmbtu	(for both units)
DAHS/Op Log Data			
Unit #1 Annual Ops Hrs	2985	Hrs/Yr	
Unit #2 Annual Ops Hrs	2979	Hrs/Yr	
Total Hrs, All Units	5964	Hrs/Yr	(for both units)
CT1 Annual Fuel Use	5223.78	mmscf	
CT2 Annual Fuel Use	5277.1	mmscf	

Fuel Gas Heater (10 mmbtu/hr)

	CAS #	Emissions Factors lb/mmbtu	Emissions Factors lb/mmscf	EF Source	Source Test Results lb/hr	Max Hourly Emissions lbs	Annual Emissions lbs	Annual Emissions tons
Acetaldehyde	75070	8.66E-06	8.87E-03	CATEF	0	0.0001	0.000	0.0000
Benzene	71432	4.21E-06	4.31E-03	CATEF	0	0.0000	0.000	0.0000
Formaldehyde	50000	2.16E-04	2.21E-01	CATEF	0	0.0022	0.000	0.0000

Total FG Heater

Fuel Use Rate Data		
NG HHV	1000	btu/scf
Fuel Use Data		
Max Hourly Fuel Use	0.00977	mmscf
Annual Fuel Use	0.00	mmscf
Calculated Heat Rate Data		
Max Hourly Heat Rate	9.77	mmbtu
Annual Heat Rate	0.00	mmbtu